UNCLASSIFIED

X-822

OAK RIDGE NATIONAL LABORATORY

Operated By

UNION CARBIDE NUCLEAR COMPANY

UCC

1POST OFFICE BOX X
OAK RIDGE, TENNESSEE**ORNL**
CENTRAL FILES NUMBERCF-57-1-159

"External Transmittal

COPY NO. 87 Authorized

DATE: January 17, 1957

SUBJECT: HRT Temperature Measurement Systems - Issue No. 3

TO: Distribution

FROM: J. D. Grimes

(Distribution on Page 2)

NOTICE

This document contains information of a preliminary nature and was prepared primarily for internal use at the Oak Ridge National Laboratory. It is subject to revision or correction and therefore does not represent a final report.

UNCLASSIFIED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.

2

DISTRIBUTION

1. HRP Director's Office
Rm. 259 Bldg. 9204-1	45. R. A. McNees
2. R. K. Adams	46. E. C. Miller
3. G. M. Adamson	47. F. C. Moesel - AEC
4. S. E. Beall	48-51. R. L. Moore
5. A. M. Billings	52. E. O. Nurmi
6. E. G. Bohlmann	53. L. F. Parsly
7. F. R. Bruce	54. R. C. Robertson
8. W. D. Burch	55. A. M. Rom
9. E. L. Compere	56. H. C. Savage
10. J. S. Culver	57. C. H. Secoy
11. D. G. Davis	58. Martin J. Skinner
12. W. K. Eister	59. I. Spiewak
13. D. E. Ferguson	60. C. L. Segaser
14. C. H. Gabbard	61. R. W. Stoughton
15. W. R. Gall	62. J. A. Swartout
16. J. C. Griess	63. E. H. Taylor
17-19. J. D. Grimes	64. D. G. Thomas
20. P. H. Harley	65-69. D. S. Toomb
21. C. S. Harrill	70. W. E. Unger
22. P. N. Haubenreich	71. R. Van Winkle
23-32. J. W. Hill	72-75. K. W. West
33. G. H. Jenks	76. C. E. Winters
34. S. I. Kaplan	77. F. C. Zapp
35. A. S. Kitzes	78. ORNL-RC
36. R. B. Korsmeyer	79-81. Laboratory Records
37. K. A. Kraus	82. ORNL Document Reference
Library Y-12
38. J. A. Lane	83-84. REED Library
39. M. I. Lundin	85-86. Central Research Library
40. R. N. Lyon	87-96. TISE-PAR
41. R. E. Leuze	97-111. TISE-AEC
42. R. B. Lindauer	
43. J. P. McBride	
44. H. M. McLeod	

The following temperature measurement tabulation consists of two parts. Part I lists all HRT thermocouples, their location, the junction box thru which the leads pass, and their termination, if on an instrument. Part II lists all temperature read out instruments and their location.

Each "TE" number represents a thermocouple. If the "TE" number ends with an "S", it is designated as a spare thermocouple. Each spare thermocouple is placed on the pipe or vessel 180° from the live thermocouple unless otherwise noted. Thermocouples installed inside the reactor cell have 20-ga. chromel-alumel leads coated with enamel and covered over with silicone varnish impregnated fiber-glass insulation.

Thermocouples are installed by individually spot welding to pipe or vessel; in wells spot welded to the bottom of the well when possible or with the thermocouple electrically insulated from grounding to pipe or vessel. After placing a thermocouple, it is taped with asbestos tape and this covered over with fiber-glass tape. Six inches or so from the couple the wires are banded to the pipe or vessel.

The thermocouple lead from the couple goes into a quick disconnect. The mating portion of this disconnect is rigidly mounted in a section of unistrut where it is visible from the top of the cell. From here the thermocouple leads enter thru a compression-type fitting into a water tight junction box. Leads are thence carried in a pressurized conduit thru the north shield wall to a thermocouple patch panel located on the auxiliary floor.

At the patch panel all thermocouple leads are initially terminated unless otherwise noted under remarks. Ultimate termination of thermocouples may be readily changed at the patch panel. Red coded lines at the patch panel have been selected for a particular e.m.f. and should not be changed or removed. On the patch panel the thermocouple jack to the right of the thermocouple number is the live couple and to the left is the spare couple.

Thermocouple leads to instrument termination points pass thru numbered holes on the left side of the upper thermocouple patch panel and thru similar holes on each side of the lower patch panel. Numbered holes beside the lower patch panel are for differential temperature measuring instruments and have a suffix of + (plus) or - (minus). The + indicates where the thermocouple reading the higher temperature should be connected and the - indicates the same thing for the contrasted lower temperature. The hole may also carry a "P" or "W" designation. This occurs where the instrument is used to measure flow by a heat exchanger method and the "P" designates the process line (fuel or blanket); the "W", a water line (may be warm or cold). Changing of leads at the patch panel on differential temperature measuring instruments should only be to the corresponding spare thermocouple.

A total of 577 thermocouples are listed in this tabulation. The roughly 77,000 ft of wire used in connecting them up cost \$6,799. Temperatures are read on 24 instruments. Cost of these was approximately \$15,688. Accessories such as patch panels, conduit, disconnects, etc., used in installing the thermocouples cost about \$8,069. Total cost for material and instruments for temperature measurement comes to approximately \$30,556.

J. D. Grimes
J. D. Grimes

HRT THERMOCOUPLES
FUEL HIGH PRESSURE SYSTEM

4

Page 4

Part I.

<u>Thermo- couple Numbers</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-165	TdT-6520 pt. 1	100	JB-18	Core Outlet	
TE-165S		100	JB-18	Core Outlet	
TE-165.1	TI-7000 pt. 41	LE-145	JB-63	Fuel Pressurizer Level Pot (LE-145) Bottom	
TE-165.1S	TI-7000 pt. 42	LE-145	JB-63	Fuel Pressurizer Level Pot (LE-145) Top	With TC disconnect at pot
TE-166	TR-6560 purp. (2)	100	JB-18	Core Outlet	
TE-166S		100	JB-18	Core Outlet	
TE-166.1	TI-7000 pt. 43	LE-147	JB-63	Fuel Pressurizer Level Pot (LE-147) Bottom	
TE-166.1S	TI-7000 pt. 44	LE-147	JB-63	Fuel Pressurizer Level Pot (LE-147) Top	With TC disconnect at pot
TE-167		146	JB-17	Pressurizer Gas Letdown Outlet	
TE-167S		146	JB-17	Pressurizer Gas Letdown Outlet	
TE-168	TR-6500 pt. 74	5	JB-25	Circulating Pump Bearing	TC Well (W/spare in well)
TE-168S		5	JB-25	Circulating Pump Bearing	TC Well (W/live in well)
TE-169	TR-6560 red (1)	103	JB-22	Core Inlet	
TE-169S		103	JB-22	Core Inlet	
TE-170		125	JB-21	Circulating Pump Bleed Outlet	
TE-170S		125	JB-21	Circulating Pump Bleed Outlet	
TE-171	TR-6510 pt. 9	101	JB-24	Heat Exchanger Inlet	
TE-171S		101	JB-24	Heat Exchanger Inlet	
TE-172	TR-6510 pt. 10	102	JB-24	Heat Exchanger Outlet	
TE-172S		102	JB-24	Heat Exchanger Outlet	
TE-173		106	JB-21	Dump Line Cooler Outlet	

Page 5 Thermo- couple Numbers	Instr. Termi- nation	Vessel or Line No.	Junction Box No.	Location	Remarks
TE-173S		106	JB-21	Dump Line Cooler Outlet	
TE-175	TI-175	25*		Sample Station	Leads do not pass thru patch panel
TE-175S		25*		Sample Station	Leads do not pass thru patch panel
TE-176		129	JB-30	Sample Cooler Outlet	
TE-176S		129	JB-30	Sample Cooler Outlet	
TE-177	TR-6500 pt. 14	110	JB-21	Letdown Heat Exchanger Fuel Feed Inlet	
TE-177S		110	JB-21	Letdown Heat Exchanger Fuel Feed Inlet	
TE-178	TR-6500 pt. 15	112	JB-18	Letdown Heat Exchanger Fuel Feed Outlet	
TE-178S		112	JB-18	Letdown Heat Exchanger Fuel Feed Outlet	
TE-179	TR-6500 pt. 18	113	JB-18	Letdown Heat Exchanger Letdown Inlet	
TE-179S		113	JB-18	Letdown Heat Exchanger Letdown Inlet	
TE-180	TR-6510 pt. 1	114	JB-21	Letdown Heat Exchanger Letdown Outlet	
TE-180S	TR-6500 pt. 19	114	JB-21	Letdown Heat Exchanger Letdown Outlet	
TE-181		129	JB-30	Sample Valve (HCV-136) Outlet	
TE-181S		129	JB-30	Sample Valve (HCV-136) Outlet	
TE-182	TR-6510 pt. 5	2	JB-17	Pressurizer Liquid	TC Well (W/spare in well)
TE-182S		2	JB-17	Pressurizer Liquid	TC Well (W/live in well)
TE-183	TR-6510 pt. 6	2	JB-17	Pressurizer Leg	TC Well (W/spare in well)
TE-183S		2	JB-17	Pressurizer Leg	TC Well (W/live in well)

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-184	TdR-6530 pt. 1	101	JB-24	Heat Exchanger Inlet	
TE-184S		101	JB-24	Heat Exchanger Inlet	
TE-185	TdR-6530 pt. 2	102	JB-24	Heat Exchanger Outlet	
TE-185S		102	JB-24	Heat Exchanger Outlet	
TE-186	TdR-6570 pt. 1	100	JB-18	Core Outlet	
TE-186S		100	JB-18	Core Outlet	
TE-187	TdR-6570 pt. 2	103	JB-22	Core Inlet	
TE-187S		103	JB-22	Core Inlet	
TE-188	TR-6580 pt. 1	2d	JB-17	Pressurizer Heater Upper	Inserted thru jacket with TC disc't at heater
TE-188S	TR-6580 pt. 2	2d	JB-17	Pressurizer Heater Lower	" " " " " "
TE-189	TR-6580 pt. 3	2c	JB-17	Pressurizer Heater Upper	" " " " " "
TE-189S	TR-6580 pt. 4	2c	JB-17	Pressurizer Heater Lower	" " " " " "
TE-190	TR-6580 pt. 5	2b	JB-17	Pressurizer Heater Upper	" " " " " "
TE-190S	TR-6580 pt. 6	2b	JB-17	Pressurizer Heater Lower	" " " " " "
TE-191	TR-6500 pt. 16	124	JB-21	Letdown Heat Exch. Purge Inlet	
TE-191S		124	JB-21	Letdown Heat Exch. Purge Inlet	
TE-192	TR-6500 pt. 17	111	JB-21	Letdown Heat Exch. Purge Outlet	
TE-192S		111	JB-21	Letdown Heat Exch. Purge Outlet	
TE-193	TR-6500 pt. 87	166	JB-25	Chem. Proc. Return Valve (HCV-141) Inlet	
TE-193S		166	JB-25	Chem. Proc. Return Valve (HCV-141) Inlet	
TE-194	TR-6500 pt. 89	167	JB-24	Chem. Proc. Take-off Valve (HCV-142) Outlet	
TE-194S		167	JB-24	Chem. Proc. Take-off Valve (HCV-142) Outlet	
TE-195	FR-1500 pt. 1P+	107	JB-31	Fuel Feed Cooler Inlet	With TC insl. from gnd.

Page 7
Thermo-
couple
Number

Instr.
Termi-
nation

Vessel
or
Line No.

Junction
Box No.

7

Location

Remarks

TE-195S	TR-6500 pt. 1	107	JB-31	Fuel Feed Cooler Inlet	With TC insl. from ground
TE-195.1	FR-1500 pt. 1P-	109	JB-20	Fuel Feed Cooler Outlet	With TC insl. from ground
TE-195.1S	TR-6500 pt. 2	109	JB-58	Fuel Feed Cooler Outlet	With TC insl. from ground
TE-196	TdR-6520 pt. 2	103	JB-22	Core Inlet	
TE-196S		103	JB-22	Core Inlet	
TE-197	TR-6580 pt. 7	2a	JB-17	Pressurizer Heater Upper Inserted thru jacket	With TC disc't at heater
TE-197S	TR-6580 pt. 8	2a	JB-17	Pressurizer Heater Lower Inserted thru jacket	With TC disc't at heater
TE-198	FR-1500 pt. 2P+	123	JB-28	Fuel Purge Pump Cooler Inlet	With TC insl. from ground
TE-198S	TR-6500 pt. 5	123	JB-28	Fuel Purge Pump Cooler Inlet	With TC insl. from ground
TE-198.1	FR-1500 pt. 2P-	123	JB-20	Fuel Purge Pump Cooler Outlet	With TC insl. from ground
TE-198.1S	TR-6500 pt. 6	123	JB-58	Fuel Purge Pump Cooler Outlet	With TC insl. from ground
TE-199	FR-1500 pt. 3P-	125	JB-63	Fuel Circ. Pump Purge Heater Inlet	With TC insl. from ground
TE-199S	TR-6500 pt. 9	125	JB-63	Fuel Circ. Pump Purge Heater Inlet	With TC insl. from ground
TE-199.1	FR-1500 pt. 3P+	125	JB-63	Fuel Circ. Pump Purge Heater Outlet	With TC insl. from ground
TE-199.1S	TR-6500 pt. 10	125	JB-63	Fuel Circ. Pump Purge Heater Outlet	With TC insl. from ground

BLANKET HIGH PRESSURE SYSTEM

8

Page 8 Thermo- couple Number	Instr. Termi- nation	Vessel or Line No.	Junction Box No.	Location	Remarks
TE-265	TdT-6520	200	JB-18	Pressure Vessel Outlet	
TE-265S		200	JB-18	Pressure Vessel Outlet	
TE-265.1	TI-7000 pt. 45	LE-247	JB-63	Blanket Pressurizer Level Pot(LE-247) Bottom	
TE-265.1S	TI-7000 pt. 46	LE-247	JB-63	Blanket Pressurizer Level Pot(LE-247) Top With TC disc't at pot	
TE-266		200	JB-18	Pressure Vessel Outlet	
TE-266S		200	JB-18	Pressure Vessel Outlet	
TE-266.1	TI-7000 pt. 47	LE-245	JB-63	Pressure Vessel Outlet Pot (LE-245) Bottom	
TE-266.1S	TI-7000 pt. 48	LE-245	JB-63	Pressure Vessel Outlet Pot (LE-245) Top With TC disc't at pot	
TE-267		246	JB-17	Pressurizer Gas Letdown Outlet	
TE-267S		246	JB-17	Pressurizer Gas Letdown Outlet	
TE-268	TR-6500 pt. 71	28	JB-45	Circulating Pump Bearing	TC Well (W/spare in well)
TE-268S		28	JB-45	Circulating Pump Bearing	TC Well (W/live in well)
TE-269		203	JB-22	Pressure Vessel Inlet	
TE-269S		203	JB-22	Pressure Vessel Inlet	
TE-270		225	JB-42	Circulating Pump Bleed Outlet	
TE-270S		225	JB-42	Circulating Pump Bleed Outlet	
TE-271	TR-6510 pt. 11	201	JB-44	Heat Exchanger Inlet	
TE-271S		201	JB-44	Heat Exchanger Inlet	
TE-272	TR-6510 pt. 12	202	JB-44	Heat Exchanger Outlet	
TE-272S		202	JB-44	Heat Exchanger Outlet	
TE-273		206	JB-42	Dump Line Cooler Outlet	
TE-273S		206	JB-42	Dump Line Cooler Outlet	

Page 9 Thermo- couple Number	Instr. Termi- nation	Vessel or Line No.	Junction Box No.	<u>9</u> Location	Remarks
TE-275	TI-275	38*		Sample Station	Leads do not pass thru patch panel
TE-275S		38*		Sample Station	Leads do not pass thru patch panel
TE-276		229	JB-37	Sample Cooler Outlet	
TE-276S		229	JB-37	Sample Cooler Outlet	
TE-277	TR-6500 pt. 37	210	JB-42	Letdown Heat Exch. Blkt. Feed Inlet	
TE-277S		210	JB-42	Letdown Heat Exch. Blkt. Feed Inlet	
TE-278	TR-6500 pt. 38	212	JB-44	Letdown Heat Exch. Blkt. Feed Outlet	
TE-278S		212	JB-44	Letdown Heat Exch. Blkt. Feed Outlet	
TE-279	TR-6500 pt. 41	213	JB-44	Letdown Heat Exch. Letdown Inlet	
TE-279S		213	JB-44	Letdown Heat Exch. Letdown Inlet	
TE-280	TR-6510 pt. 2	214	JB-42	Letdown Heat Exch. Letdown Outlet	
TE-280S	TR-6500 pt. 42	214	JB-42	Letdown Heat Exch. Letdown Outlet	
TE-281		229	JB-37	Sample Valve (HCV-236) Outlet	
TE-281S		229	JB-37	Sample Valve (HCV-236) Outlet	
TE-282	TR-6510 pt. 7	29	JB-17	Pressurizer Liquid	TC Well (W/spare in well)
TE-282S		29	JB-17	Pressurizer Liquid	TC Well (W/live in well)
TE-283	TR-6510 pt. 8	29	JB-17	Pressurizer Leg	TC Well (W/spare in well)
TE-283S		29	JB-17	Pressurizer Leg	TC Well (W/live in well)
TE-284	TR-6500 pt. 81	32	JB-18	Pressure Vessel North top	
TE-284S	TR-6500 pt. 83	32	JB-22	Pressure Vessel North Bottom	

<u>Thermo-</u> <u>couple</u> <u>Number</u>	<u>Inst.</u> <u>Termin-</u> <u>ation</u>	<u>Vessel</u> <u>or</u> <u>Line No.</u>	<u>Junction</u> <u>Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-285	TI-7000 pt. 11	32	JB-18	Pressure Vessel East Top	
TE-285S	TI-7000 pt. 12	32	JB-22	Pressure Vessel East Bottom	
TE-286	TR-6500 pt. 82	32	JB-18	Pressure Vessel South Top	
TE-286S	TR-6500 pt. 84	32	JB-22	Pressure Vessel South Bottom	
TE-287	TdR-6590 pt. 5+	32	JB-18	Pressure Vessel West Top	
TE-287S	TI-7000 pt. 13	32	JB-22	Pressure Vessel West Bottom	
TE-288	TR-6580 pt. 9	29d	JB-17	Pressurizer Heater Upper	Inserted thru jacket W/TC disc't at heater
TE-288S	TR-6580 pt. 10	29d	JB-17	Pressurizer Heater Lower	Inserted thru jacket W/TC disc't at heater
TE-289	TR-6580 pt. 11	29c	JB-17	Pressurizer Heater Upper	Inserted thru jacket W/TC disc't at heater
TE-289S	TR-6580 pt. 12	29c	JB-17	Pressurizer Heater Lower	Inserted thru jacket W/TC disc't at heater
TE-290	TR-6580 pt. 13	29b	JB-17	Pressurizer Heater Upper	Inserted thru jacket W/TC disc't at heater
TE-290S	TR-6580 pt. 14	29b	JB-17	Pressurizer Heater Lower	Inserted thru jacket W/TC disc't at heater
TE-291	TR-6500 pt. 39	224	JB-42	Letdown Heat Exch. Purge Inlet	
TE-291S		224	JB-42	Letdown Heat Exch. Purge Inlet	
TE-292	TR-6500 pt. 40	211	JB-44	Letdown Heat Exch. Purge Outlet	
TE-292S		211	JB-44	Letdown Heat Exch. Purge Outlet	
TE-293	TR-6500 pt. 85	266	JB-45	Chem. Proc. Return Valve (HCV-241) Inlet	
TE-293S		266	JB-45	Chem. Proc. Return Valve (HCV-241) Inlet	
TE-294	TR-6500 pt. 86	267	JB-44	Chem. Proc. Take-off Valve (HCV-242) Outlet	
TE-294S		267	JB-44	Chem. Proc. Take-off Valve (HCV-242) Outlet	
TE-295	FR-1500 pt. 4P+	207	JB-38	Blanket Feed Cooler Inlet	With TC insl. from ground
TE-295S	TR-6500 pt. 24	207	JB-38	Blanket Feed Cooler Inlet	With TC insl. from ground
TE-295.1	FR-1500 pt. 4P-	209	JB-41	Blanket Feed Cooler Outlet	With TC insl. from ground

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-295.1S	TR-6500 pt. 25	209	JB-61	Blanket Feed Cooler Outlet	With TC insl. from ground
TE-296	TR-6590 pt. 5	203	JB-22	Pressure Vessel Inlet	With TC insl. from ground
TE-296S		203	JB-22	Pressure Vessel Inlet	With TC ins. from ground
TE-297	TR-6580 pt. 15	29a	JB-17	Pressurizer Heater Upper	Inserted thru jacket W/TC disc't at heater
TE-297S	TR-6580 pt. 16	29a	JB-17	Pressurizer Heater Lower	Inserted thru jacket W/TC disc't at heater
TE-298	FR-1500 pt. 5P+	223	JB-35	Blanket Purge Pump Cooler Inlet	With TC insl. from ground
TE-298S	TR-6500 pt. 28	223	JB-35	Blanket Purge Pump Cooler Inlet	With TC insl. from ground
TE-298.1	FR-1500 pt. 5P-	223	JB-41	Blanket Purge Pump Cooler Outlet	With TC insl. from ground
TE-298.1S	TR-6500 pt. 29	223	JB-61	Blanket Purge Pump Cooler Outlet	With TC insl. from ground
TE-299	FR-1500 pt. 6P-	225	JB-60	Blanket Circ. Pump Purge Heater Inlet	With TC insl. from ground
TE-299S	TR-6500 pt. 32	225	JB-60	Blanket Circ. Pump Purge Heater Inlet	With TC insl. from ground
TE-299.1	FR-1500 pt. 6P+	225	JB-60	Blanket Circ. Pump Purge Heater Outlet	With TC insl. from ground
TE-299.1S	TR-6500 pt. 34	225	JB-60	Blanket Circ. Pump Purge Heater Outlet	With TC insl. from ground

12 FUEL LOW PRESSURE SYSTEM

Page 12

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-365		106	JB-21	Dump Valve (PCV-152) Outlet	
TE-365S		106	JB-21	Dump Valve (PCV-152) Outlet	
TE-366	TR-6500 pt. 56	19	JB-30	Transfer Tank South Side	TC Well
TE-366S		19	JB-30	Transfer Tank North Side	TC Well
TE-367	TI-367	18*		Sample Station	Leads do not pass thru patch panel
TE-367S		18*		Sample Station	Leads do not pass thru patch panel
TE-368	TR-6500 pt. 54	116	JB-27	Recombiner Cond. Off Gas Outlet	
TE-368S		116	JB-27	Recombiner Cond. Off Gas Outlet	
TE-369		122	JB-26	Condensate Tank Outlet	
TE-369S		122	JB-26	Condensate Tank Outlet	
TE-370		135	JB-30	Fuel Transfer Junction Lines 135 and 154	
TE-370S		135	JB-30	Fuel Transfer Junction Lines 135 and 154	

TE-375	TI-375	8a	JB-26	Recombiner	Insert in well nearest center
TE-375S		8a	JB-26	Recombiner	Insert in well next nearest to center

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-376	TR-6510 pt. 3	7a	JB-31	Dump Tank Evaporator Inlet	
TE-376S		7a	JB-31	Dump Tank Evaporator Inlet	
TE-377		7b	JB -31	Dump Tank Evaporator Inlet	
TE-377S		7b	JB-31	Dump Tank Evaporator Inlet	
TE-378	TR-6500 pt. 47	16a	JB-32	Storage Tank Evaporator Inlet	
TE-378S		16a	JB-32	Storage Tank Evaporator Inlet	
TE-379		16b	JB-32	Storage Tank Evaporator Inlet	
TE-379S		16b	JB-32	Storage Tank Evaporator Inlet	
TE-381	TR-6500 pt. 57	138	JB-30	Transfer Tank Vent Valve (HCV-733) Outlet	
TE-381S		138	JB-30	Transfer Tank Vent Valve (HCV-733) Outlet	
TE-382		141	JB-23	Chem. Proc. Take-off Valve (HCV-340) Outlet	
TE-382S		141	JB-23	Chem. Proc. Take-off Valve (HCV-340) Outlet	
TE-383		108	JB-30	Fuel Transfer Junction Lines 135 and 108	
TE-383S		108	JB-39	Fuel Transfer Junction Lines 135 and 108	
TE-384	TR-6500 pt. 53	8a	JB-26	Recombiner	TC Well (W/Spare in well)(Outmost well)
TE-384S		8a	JB-26	Recombiner	TC Well (W/Live in well)(Outmost well)
TE-385		107	JB-31	Fuel Feed Transfer Junc. Lines 107 and 108	
TE-385S		107	JB-31	Fuel Feed Transfer Junc. Lines 107 and 108	
TE-386		162	JB-28	Processed Fuel Return Valve (HCV-937) Outlet	
TE-386S		162	JB-28	Processed Fuel Return Valve (HCV-937) Outlet	
TE-387	TR-6500 pt. 79	127	JB-26	Gas Bleed Valve (HCV-139) Outlet	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-387S		127	JB-26	Gas Bleed Valve (HCV-139) Outlet	
TE-389	TR-6500 pt. 46	16a	JB-23	Storage Tank Evaporator Outlet	
TE-389S		16a	JB-23	Storage Tank Evaporator Outlet	
TE-390		16b	JB-23	Storage Tank Evaporator Outlet	
TE-390S		16b	JB-23	Storage Tank Evaporator Outlet	
TE-391	TR-6500 pt. 45	7a	JB-29	Dump Tank Evaporator Outlet	
TE-391S		7a	JB-29	Dump Tank Evaporator Outlet	
TE-392		7b	JB-29	Dump Tank Evaporator Outlet	
TE-392S		7b	JB-29	Dump Tank Evaporator Outlet	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-465		206	JB-42	Dump Valve (PCV-252) Outlet	
TE-465S		206	JB-42	Dump Valve (PCV-252) Outlet	
TE-466	TR-6500 pt. 69	42	JB-37	Transfer Tank South Side	TC Well
TE-466S		42	JB-37	Transfer Tank North Side	TC Well
TE-467	TI-467	44*		Sample Station	Leads do not pass thru patch panel
TE-467S		44*		Sample Station	Leads do not pass thru patch panel
TE-468	TR-6500 pt. 68	216	JB-34	Recombiner Condenser Off Gas Outlet	
TE-468S		216	JB-34	Recombiner Condenser Off Gas Outlet	
TE-469		222	JB-33	Condensate Tank Outlet	
TE-469S		222	JB-33	Condensate Tank Outlet	
TE-470		235	JB-37	Fuel Transfer Junction Lines 235 and 264	
TE-470S		235	JB-37	Fuel Transfer Junction Lines 235 and 264	

TE-475	TI-475	35a	JB-33	Recombiner	Insert in well nearest center
TE-475S		35a	JB-33	Recombiner	Insert in well next nearest to center
TE-476	TR-6510 pt. 4	34a	JB-38	Dump Tank Evaporator Inlet	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-476S		34a	JB-38	Dump Tank Evaporator Inlet	
TE-477		34b	JB-38	Dump Tank Evaporator Inlet	
TE-477S		34b	JB-39	Dump Tank Evaporator Inlet	
TE-478	TR-6500 pt. 60	49a	JB-39	Storage Tank Evaporator Inlet	
TE-478S		49a	JB-39	Storage Tank Evaporator Inlet	
TE-479		49b	JB-39	Storage Tank Evaporator Inlet	
TE-479S		49b	JB-39	Storage Tank Evaporator Inlet	
TE-480		241	JB-42	Chem. Proc. Take-off Valve (HCV-440) Outlet	
TE-480S		241	JB-42	Chem. Proc. Take-off Valve (HCV-440) Outlet	
TE-481	TR-6500 pt. 70	238	JB-37	Transfer Tank Vent Valve (HCV-734) Outlet	
TE-481S		238	JB-37	Transfer Tank Vent Valve (HCV-734) Outlet	
TE-482		270	JB-40	LP Systems Withdrawal Valve (HCV-939) Outlet	
TE-482S		270	JB-40	LP Systems Withdrawal Valve (HCV-939) Outlet	
TE-483		208	JB-37	Blkt. Transfer Junction Lines 235 and 208	
TE-483S		208	JB-37	Blkt. Transfer Junction Lines 235 and 208	
TE-484	TR-6500 pt. 67	35a	JB-33	Recombiner	TC Well (W/spare inwell)(Outmost well)
TE-484S		35a	JB-33	Recombiner	TC Well W/live in well) (Outmost well)
TE-485		207	JB-38	Blkt. Feed-Transfer Junct. Lines 207 and 208	
TE-485S		207	JB-38	Blkt. Feed-Transfer Junct. Lines 207 and 208	
TE-486		262	JB-35	Processed Blkt. Return Valve (HCV-938) Outlet	
TE-486S		262	JB-35	Processed Blkt. Return Valve (HCV-938) Outlet	
TE-487	TR-6500 pt. 80	227	JB-33	Gas Bleed Valve (HCV-239) Outlet	
TE-487S		227	JB-33	Gas Bleed Valve (HCV-239) Outlet	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-489	TR-6500 pt. 59	49a	JB-43	Storage Tank Evaporator Outlet	
TE-489S		49a	JB-43	Storage Tank Evaporator Outlet	
TE-490		49b	JB-43	Storage Tank Evaporator Outlet	
TE-490S		49b	JB-43	Storage Tank Evaporator Outlet	
TE-491	TR-6500 pt. 58	34a	JB-36	Dump Tank Evaporator Outlet	
TE-491S		34a	JB-36	Dump Tank Evaporator Outlet	
TE-492		34b	JB-36	Dump Tank Evaporator Outlet	
TE-492S		34b	JB-36	Dump Tank Evaporator Outlet	

STEAM SYSTEM

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-565	TdR-6590 pt. 1-	301*		Fuel Steam Drum Outlet	
TE-565S		301*		Fuel Steam Drum Outlet	
TE-566	TdR-6590 pt. 7-	303*		Blanket Steam Drum Outlet	
TE-566S		303*		Blanket Steam Drum Outlet	
TE-567	TR-6500 pt. 90	358*		Fuel Heat Exchanger Feedwater	
TE-567S		358*		Fuel Heat Exchanger Feedwater	
TE-568	TR-6500 pt. 91	368*		Blanket Heat Exchanger Feedwater	
TE-568S		368*		Blanket Heat Exchanger Feed Water	
TE-569	TI-7000 pt. 40	354*		Feedwater Pumps Inlet	
TE-569S		354*		Feedwater Pumps Inlet	
TE-570		397*		Deaerator Cond. Coolant Outlet	
TE-570S		397*		Deaerator Cond. Coolant Outlet	
TE-571	TI-7000 pt. 23	389*		Turbine Cond. Coolant Inlet	
TE-571S		389*		Turbine Cond. Coolant Inlet	
TE-572	TI-7000 pt. 24	392*		Turbine Cond. Coolant Outlet	
TE-572S		392*		Turbine Cond. Coolant Outlet	
TE-573	TI-7000 pt. 36	334*		Turbine Steam Flow Orifice	
TE-573S		334*		Turbine Steam Flow Orifice	
TE-574	TI-7000 pt. 34	328*		Fuel Steam Flow Orifice	
TE-574S		328*		Fuel Steam Flow Orifice	
TE-575	TI-7000 pt. 35	331*		Blanket Steam Flow Orifice	
TE-575S		331*		Blanket Steam Flow Orifice	
TE-576	TI-7000 pt. 38	328*		Air Condenser Steam Inlet	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-576S		328*		Air Condenser Steam Inlet	
TE-577	TI-7000 pt. 39	345*		Air Condenser Condensate Outlet	
TE-577S		345*		Air Condenser Condensate Outlet	
TE-578	TI-7000 pt. 37	334*		Turbine Steam Inlet	
TE-578S		334*		Turbine Steam Inlet	
TE-579		59*		Turbine Cond. Hotwell	
TE-579S		59*		Turbine Cond. Hotwell	
TE-580	TR-6500 pt. 94	393*		Cooling Tower Inlet	
TE-580S		393*		Cooling Tower Inlet	
TE-581	TR-6500 pt. 93	390*		Cooling Tower Outlet	
TE-581S		390*		Cooling Tower Outlet	
TE-582	TI-7000 pt. 30	320	JB-27	Fuel Heat Exch. Relief Valve	
TE-582S		320	JB-27	Fuel Heat Exch. Relief Valve	
TE-583	TI-7000 pt. 31	322	JB-23	Fuel Heat Exch. Relief Valve	
TE-583S		322	JB-23	Fuel Heat Exch. Relief Valve	
TE-584	TI-7000 pt. 32	321	JB-34	Blanket Heat Exch. Relief Valve	
TE-584S		321	JB-34	Blanket Heat Exch. Relief Valve	
TE-585	TI-7000 pt. 33	323	JB-43	Blanket Heat Exch. Relief Valve	
TE-585S		323	JB-43	Blanket Heat Exch. Relief Valve	
TE-586	TdR-6590 pt.2-	4	JB-27	Fuel Heat Exch. Shell, Bottom	With TC insl. from ground
TE-586S		4	JB-27	Fuel Heat Exch. Shell, Bottom	With TC insl. from ground
TE-586.1	TdR-6590 pt. 2+	4	JB-23	Fuel Heat Exch. Shell, Bottom	TC Well (W/spare in well)
TE-586.1S	TdR-6590 pt. 3-	4	JB-23	Fuel Heat Exch. Shell, Bottom	TC Well (W/live in well)

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-587	TdR-6590 pt. 3+	4	JB-27	Fuel Heat Exch. Shell, Top, North Side	With TC insl. from ground
TE-587S	TdR-6590 pt. 1+	4	JB-27	Fuel Heat Exch. Shell, Top, South Side	With TC insl. from ground
TE-588	TdR-6590 pt. 4-	31	JB-34	Blanket Heat Exch. Shell, Bottom	With TC insl. from ground
TE-588S		31	JB-34	Blanket Heat Exch. Shell, Bottom	
TE-588.1	TdR-6590 pt. 4+	31	JB-43	Blanket Heat Exch. Shell, Bottom	TC Well (W/spare in well)
TE-588.1S	TdR-6590 pt. 6-	31	JB-43	Blanket Heat Exch. Shell, Bottom	TC Well (W/live in well)
TE-589	TdR-6590 pt. 7+	31	JB-34	Blanket Heat Exch. Shell, top, North Side	With TC insl from ground
TE-589S	TdR-6590 pt. 6+	31	JB-34	Blanket Heat Exch. Shell, Top, South Side	With TC insl. from ground
TE-589.1	TI-7000 pt. 22	*		Turbine Oil Cooler, Oil Outlet	
TE-589.1S		*		Turbine Oil Cooler, Oil Outlet	

Thermo-
couple
NumberInstr.
Termin-
ationVessel
or
Line No.Junction
Box No.WARM WATER SYSTEMLocationRemarks

TE-666A	TI-666	846*		Test Heat Exchanger Steam Inlet	Leads do not pass thru patch Panel
TE-666B	TI-666	847*		Test Heat Exchanger Steam Outlet	Leads do not pass thru patch Panel

OFF GAS SYSTEM

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-765	TR-6500 pt. 50	134	JB-23	Fuel Reflux Cond. Off Gas	
TE-765S		134	JB-23	Fuel Reflux Cond. Off Gas	
TE-766	TR-6500 pt. 63	234	JB-43	Blanket Reflux Cond. Off Gas	
TE-766S		234	JB-43	Blanket Reflux Cond. Off Gas	
TE-767	TR-6500 pt. 101	10a*	JB-56	Adsorber Bed A; 1/2" Line	TC in 3/16" SS Shield
TE-768	TI-7000 pt. 1	10a*	JB-56	Adsorber Bed A' 1" Line	TC in 3/16" SS Shield
TE-769	TI-7000 pt 2	10a*	JB-56	Adsorber Bed A; 2" Line	TC in 3/16" SS Shield
TE-770	TI-7000 pt. 3	10a*	JB-56	Adsorber Bed A' 6" Line	TC in 3/16" SS Shield
TE-771	TI-6500 pt. 102	10b*	JB-56	Adsorber Bed B, 1/2" Line	TC in 3/16" SS Shield
TE-772	TI-7000 pt. 4	10b*	JB-56	Adsorber Bed B, 1" Line	TC in 3/16" SS Shield
TE-773	TI-7000 pt. 5	10b*	JB-56	Adsorber Bed B; 2" Line	TC in 3/16" SS Shield
TE-774	TI-7000 pt. 6	10b*	JB-56	Adsorber Bed B; 6" Line	TC in 3/16" SS Shield
TE-775	TR-6500 pt. 103	10c *	JB-56	Adsorber Bed C; 1/2" Line	TC in 3/16" SS Shield

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-776	TI-7000 pt. 7	10c*	JB-56	Adsorber Bed C; 1" Line	TC in 3/16" SS Shield
TE-777	TI-7000 pt. 8	10c*	JB-56	Adsorber Bed C; 2" Line	TC in 3/16" SS Shield
TE-778	TI-7000 pt. 9	10c*	JB-56	Adsorber Bed C; 6" Line	TC in 3/16" SS Shield
TE-779		117	JB-59	Fuel Storage Recombiner, Top	
TE-779S		117	JB-59	Fuel Storage Recombiner, Top	
TE-780		165	JB-40	Storage Cold Trap Off Gas Line	
TE-780S		165	JB-40	Storage Cold Trap Off Gas Line	

UTILITIES SYSTEM

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-865	TR-6500pt.20	424	JB-21	Fuel Letdown Heat Exch. CWD	
TE-865S		424	JB-21	Fuel Letdown Heat Exch. CWD	
TE-866	TR-6500 pt. 43	448	JB-42	Blanket Letdown Heat Exch. CWD	
TE-866S		448	JB-42	Blanket Letdown Heat Exch. CWD	
TE-867	TR-6500 pt. 75	422	JB-25	Fuel Circulating Pump CWD	
TE-867S		422	JB-25	Fuel Circulating Pump CWD	
TE-868	TR-6500 pt. 73	446	JB-45	Blanket Circulating Pump CWD	
TE-868S		446	JB-45	Blanket Circulating Pump CWD	
TE-873		410	JB-27	Fuel Recombiner Condenser CWD	
TE-873S		410	JB-27	Fuel Recombiner Condenser CWD	
TE-873.1		409	JB-27	Fuel Recombiner Condenser CWI	
TE-873.1S		409	JB-27	Fuel Recombiner Condenser CWI	
TE-874		434	JB-34	Blanket Recombiner Condenser CWD	
TE-874S		434	JB-34	Blanket Recombiner Condenser CWD	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-875		428	JB-25	Fuel Dump Line Cooler CWD	
TE-875S		428	JB-25	Fuel Dump Line Cooler CWD	
TE-876		452	JB-45	Blanket Dump Line Cooler CWD	
TE-876S		452	JB-45	Blanket Dump Line Cooler CWD	
TE-877	FR-1500 pt. 1W-	417	JB-20	Fuel Feed Line Cooler CWI	With TC insl. from ground
TE-877S	TR-6500 pt. 3	417	JB-58	Fuel Feed Line Cooler CWI	With TC insl. from ground
TE-877.1	FR-1500 pt. 1W+	418	JB-31	Fuel Feed Line Cooler CWD	With TC insl. from ground
TE-877.1S	TR-6500 Pt. 4	418	JB-31	Fuel Feed Line Cooler CWD	With TC insl. from ground
TE-878	FR-1500 pt. 4W-	441	JB-41	Blanket Feed Line Cooler CWI	With TC insl. from ground
TE-878S	TR-6500 pt. 26	441	JB-61	Blanket Feed Line Cooler CWI	With TC insl. from ground
TE-878.1	FR-1500 pt. 4W+	442	JB-38	Blanket Feed Line Cooler CWD	With TC insl. from ground
TE-878.1S	TR-6500 pt. 27	442	JB-38	Blanket Feed Line Cooler CWD	With TC insl. from ground
TE-879		420	JB-25	Fuel Sample Line Cooler CWD	
TE-879S		420	JB-25	Fuel Sample Line Cooler CWD	
TE-880		444	JB-45	Blanket Sample Line Cooler CWD	
TE-880S		444	JB-45	Blanket Sample Line Cooler CWD	
TE-881	TR-6500 pt. 49	414	JB-32	Fuel Reflux Condenser CWD	
TE-881S		414	JB-32	Fuel Reflux Condenser CWD	
TE-881.1	TR-6500 pt. 48	413	JB-32	Fuel Reflux Condenser CWI	
TE-881.1S		413	JB-32	Fuel Reflux Condenser CWI	
TE-882	TR-6500 pt. 62	438	JB-39	Blanket Reflux Condenser CWD	
TE-882S		438	JB-39	Blanket Reflux Condenser CWD	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-882.1	TR-6500 pt. 61	437	JB-39	Blanket Reflux Condenser CWI	
TE-882.1S		437	JB-39	Blanket Reflux Condenser CWI	
TE-883	TR-6500 pt. 52	454	JB-27	Fuel Entrainment Separator CWD	
TE-883S		454	JB-27	Fuel Entrainment Separator CWD	
TE-883.1	TR-6500 pt. 51	453	JB-27	Fuel Entrainment Separator CWI	
TE-883.1S		453	JB-27	Fuel Entrainment Separator CWI	
TE-884	TR-6500 pt. 64	456	JB-34	Blanket Entrainment Separator CWD	
TE-884S		456	JB-34	Blanket Entrainment Separator CWD	
TE-884.1	TR-6500 pt. 65	455	JB-34	Blanket Entrainment Separator CWI	
TE-884.1S		455	JB-34	Blanket Entrainment Separator CWI	
TE-885		620*		Fuel Sample Stations CWD	With TC disc't at sample station
TE-885S		620*		Fuel Sample Station CWD	With TC disc't at sample station
TE-886		621*		Blanket Sample Stations CWD	With TC disc't at sample station
TE-886S		621*		Blanket Sample Stations CWD	With TC disc't at sample station
TE-887		500*		Adsorber Pit Coolant Outlet	TC in 3/16" SS Shield
TE-887S		500*		Adsorber Pit Coolant Outlet	TC in 3/16" SS Shield
TE-888		494*		Waste Evaporator CWD	
TE-888S		494*		Waste Evaporator CWD	
TE-888.1		790	JB-21	Thermal Shield Cooler CWD	
TE-888.1S		790	JB-21	Thermal Shield Cooler CWD	
TE-889	TI-7000 pt. 17	401	JB-18	Thermal Shield Cooler CWD	
TE-889S		401	JB-18	Thermal Shield Cooler CWD	
TE-889.1	TI-7000 pt. 18	793	JB-18	Thermal Shield Cooler CWD	

<u>Thermocouple Number</u>	<u>Instr. Termination</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-889.1S		793	JB-18	Thermal Shield Cooler CWD	
TE-890	TI-7000 pt. 16	490	JB-18	Reactor Vessel Cooler CWD	
TE-890S		490	JB-18	Reactor Vessel Cooler CWD	
TE-890.1	TI-7000 pt. 19	792	JB-18	Thermal Shield Cooler CWD	
TE-890.1S		792	JB-18	Thermal Shield Cooler CWD	
TE-891	TI-7000 pt. 14	482	JB-27	Fuel Space Coolers CWD	
TE-891S		482	JB-27	Fuel Space Coolers CWD	
TE-891.1	TI-7000 pt. 20	791	JB-22	Thermal Shield Cooler CWD	
TE-891.1S		791	JB-22	Thermal Shield Cooler CWD	
TE-892	TI-7000 pt. 15	488	JB-34	Blanket Space Coolers CWD	
TE-892S		488	JB-34	Blanket Space Coolers CWD	
TE-893	FR-1500 pt. 3W+	425	JB-63	Fuel Circ. Pump Purge Heater, WI	With TC insl. from ground
TE-893S	TR-6500 pt. 12	425	JB-63	Fuel Circ. Pump Purge Heater, WI	With TC insl. from ground
TE-893.1	FR-1500 pt. 3W-	426	JB-63	Fuel Circ. Pump Purge Heater WD	With TC insl. from ground
TE-893.1S	TR-6500 pt. 13	426	JB-63	Fuel Circ. Pump Purge Heater WD	With TC insl. from ground
TE-894	FR-1500 pt. 6W+	449	JB-60	Blanket Circ. Pump Purge Heater, WI	With TC insl. from ground
TE-894S	TR-6500 pt. 35	449	JB-60	Blanket Circ. Pump Purge Heater, WI	With TC insl. from ground
TE-894.1	FR-1500 pt. 6W-	450	JB-60	Blanket Circ. Pump Purge Heater, WD	With TC insl. from ground
TE-894.1S	TR-6500 pt. 36	450	JB-60	Blanket Circ. Pump Purge Heater, WD	With TC insl. from ground

MISCELLANEOUS

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-965	TI-7000 pt. 10	*		Nuclear Instrument Shaft	In 30' Waterproof well (W/spare in well)
TE-965S		*		Nuclear Instrument Shaft	In 30' Waterproof well (W/live in well)
TE-966		264	JB-40	Junction Lines 164 & 264 on inlet to (HCV-939)	
TE-966S		264	JB-40	Junction Lines 164 & 264 on inlet to (HCV-939)	
TE-967	TR-6500 pt. 78	246	JB-17	Core-Blanket Rupture Disc	
TE-967S		246	JB-17	Core-Blanket Rupture Disc	
TE-968		80a*		Waste Evaporator (80a)	
TE-968S		80a*		Waste Evaporator (80a)	
TE-969		130	JB-63	Fuel Gas Purge Line	
TE-969S		130	JB-63	Fuel Gas Purge Line	
TE-970		230	JB-63	Blanket Gas Venting Line	
TE-970S		230	JB-63	Blanket Gas Venting Line	
TE-971	TR-6500 pt. 21	497*		Fuel Cooling Water Header Inlet	Inserted in line
TE-971S		497*		Fuel Cooling Water Header Inlet	Inserted in line
TE-972	TR-6500 pt. 23	498*		Blanket Cooling Water Heater Inlet	Inserted in line
TE-972S		498*		Blanket Cooling Water Heater Inlet	Inserted in line
TE-973	TR-6500 pt. 92	493*		Cooling Water Header	
TE-973S		493*		Cooling Water Header	
TE-974	FR-1500 pt. 2W-	457	JB-20	Fuel Purge Pump Cooler, WI	With TC insl. from ground
TE-974S	TR-6500 pt. 7	457	JB-58	Fuel Purge Pump Cooler, WI	With TC insl. from ground
TE-974.1	FR-1500 pt. 2W+	458	JB-28	Fuel Purge Pump Cooler, WD	With TC insl. from ground
TE-974.1S	TR-6500 pt. 8	458	JB-28	Fuel Purge Pump Cooler, WD	With TC insl. from ground
TE-975	FR-1500 pt. 5W-	406	JB-41	Blanket Purge Pump Cooler, WI	With TC insl. from ground

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-975S	TR-6500 pt. 30	406	JB-61	Blanket Purge Pump Cooler, WI	With TC insl. from ground
TE-975.1	FR-1500 pt. 5W+	405	JB-35	Blanket Purge Pump Cooler, WD	With TC insl. from ground
TE-975.1S	TR-6500 pt. 31	405	JB-35	Blanket Purge Pump Cooler, WD	With TC insl. from ground
TE-976		663*		Warm Water Header	
TE-976S		663*		Warm Water Header	
TE-976.1		457*		Fuel Purge Pump Coolant Heat Exch. Coolant Outlet	
TE-976.1S		457*		Fuel Purge Pump Coolant Heat Exch. Coolant Outlet	
TE-977	TR-6500 pt. 76	421	JB-63	Fuel Circulating Pump CWI	
TE-977S		421	JB-63	Fuel Circulating Pump CWI	
TE-977.1		406*		Blanket Purge Pump Coolant Heat Exch. Coolant Outlet	
TE-977.1S		406*		Blanket Purge Pump Coolant Heat Exch. Coolant Outlet	
TE-978	TR-6500 pt. 72	445	JB-60	Blanket Circulating Pump CWI	
TE-978S		445	JB-60	Blanket Circulating Pump CWI	
TE-979		171	JB-63	Fuel-Blk't Equalizer Valve (HCV-926) Fuel Side	
TE-979S		171	JB-63	Fuel-Blk't Equalizer Valve (HCV-926) Fuel Side	
TE-980		839*		Demineralized Water Heat Exch. Outlet	
TE-980S		839*		Demineralized Water Heat Exch. Outlet	
TE-982	TI-982	*		Package Boiler Stack	Leads do not pass thru patch panel Iron-Const. TC in well

Thermo-
couple
NumberInstr.
Termi-
nationVessel
or
Line No.Junction
Box No.FUEL-BLANKET OXYGEN SUPPLY SYSTEMLocationRemarks

TE-5001A	TI-5001 pt. 1	*		Oxygen Generator, lower	Copper-Const. TC Leads do not pass thru patch panel
TE-5001AS	TI-5001 pt. 2	*		Oxygen Generator, lower	Copper-Const. TC Leads do not pass thru patch panel
TE-5001B	TI-5001 pt. 3	*		Oxygen Generator, upper	Copper-Const. TC Leads do not pass thru patch panel
TE-5001BS	TI-5001 pt. 4	*		Oxygen Generator, upper	Copper-Const. TC Leads do not pass thru patch panel
TE-5002	TI-5002	*		Oxygen Generator, heater	Leads do not pass thru patch panel

REFRIGERATION AND COLD TRAP SYSTEM

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-T66	TI-T66	712*		Cold F-11 Pump Outlet	Leads do not pass thru patch panel
TE-T74A	TI-T74	741*		Outside WIC at Elevation 821'	Leads do not pass thru patch panel
TE-T74B	TI-T74	739*		Outside WIC at Elevation 807'	" " " " " " "
TE-T74C	TI-T74	737*		Outside WIC at Elevation 807'	" " " " " " "
TE-T74D	TI-T74	735*		Outside WIC at Elevation 807'	" " " " " " "
TE-T74E	TI-T74	733*		Outside WIC at Elevation 808'	" " " " " " "
TE-T74F	TI-T74	731*		Outside WIC at Elevation 807'	" " " " " " "
TE-T74G	TI-T74	472*		Fuel Cold Trap (9a) Outlet to ECV-E08D	" " " " " " "
TE-T74H	TI-T74	470*		Fuel Cold Trap (9a) Outlet to ECV-E07B	" " " " " " "
TE-T74I	TI-T74	466*		Blanket Cold Trap (36b) Outlet to ECV-E06B	" " " " " " "
TE-T74J	TI-T74	71*		Chiller and Storage Tank	" " " " " " "
TE-T74K	TI-T74	704*		Inlet to Valve ECV-E09	" " " " " " "
TE-T74L	TI-T74	492*		Condenser (75) Outlet	" " " " " " "
TE-T75A	TI-T75	717*		Outside EIC at Elevation 821'	" " " " " " "
TE-T75B	TI-T75	719*		Outside WIC at Elevation 823'	" " " " " " "

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-T75C	TI-T75	721*		Outside EIC at Elevation 807'	Leads do not pass thru patch panel
TE-T75D	TI-T75	723*		Outside EIC at Elevation 807'	" " " " " "
TE-T75E	TI-T75	725*		Outside EIC at Elevation 807'	" " " " " "
TE-T75F	TI-T75	727*		Outside EIC at Elevation 821'	" " " " " "
TE-T75G	TI-T75	729*		Outside EIC at Elevation 807'	" " " " " "
TE-T75H	TI-T75	464*		Storage Cold Trap Outlet to Valve 464A	" " " " " "
TE-T75I	TI-T75	468*		Blkt. Cold Trap (36a) Outlet to ECV-EO5B	" " " " " "
TE-T75J	TI-T75	72*		Heater and Storage Tank	" " " " " "
TE-T75J ^{1/2}	TI-T75	491*		Condenser (75) Inlet	" " " " " "
TE-T75L	TI-T75	705-2*		Chiller and Storage Tank Outlet	" " " " " "
TE-T76A	TI-T76	811*		Above WIC at Elevation 830'	" " " " " "
TE-T76B	TI-T76	815*		Outside WIC at Elevation 809'	" " " " " "
TE-T76C	TI-T76	817*		Outside WIC at Elevation 809'	" " " " " "
TE-T76D	TI-T76	823*		Outside WIC at Elevation 819'	" " " " " "
TE-T76E	TI-T76	831*		Outside WIC at Elevation 808'	" " " " " "
TE-T76F	TI-T76	813*		Above EIC at Elevation 830'	" " " " " "
TE-T76G	TI-T76	819*		Outside EIC at Elevation 808'	" " " " " "
TE-T76H	TI-T76	821*		Outside EIC at Elevation 808'	" " " " " "
TE-T76I	TI-T76	827*		Outside EIC at Elevation 818'	" " " " " "
TE-T76J	TI-T76	833*		Outside EIC at Elevation 819'	" " " " " "
TE-T76M	TI-T74	471*		Outside WIC at Elevation 824'	Leads do not pass thru patch panel Plug in and read at T74G

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-76N	TI-T74	469*		Outside WIC at Elevation 824'	Leads do not pass thru patch panel Plug in and read at T74H
TE-T76P	TI-T75	467*		Outside EIC at Elevation 824'	Leads do not pass thru patch panel Plug in and read at T75I
TE-T76Q	TI-T74	465*		Outside EIC at Elevation 824'	Leads do not pass thru patch panel Plug in and read at T74I
TE-T76R	TI-T76	825*		Outside WIC at Elevation 819'	Leads do not pass thru patch panel Plug in and read at T76D
TE-T76S	TI-T76	829*		Outside EIC at Elevation 818'	Leads do not pas thru patch panel Plug in and read at T76I

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-SP-1			JB-28		
TE-SP-2			JB-28		
TE-SP-3			JB-28	Air at Floor of Fuel Reactor Cell	Redesignated TE-X30
TE-SP-4			JB-28		
TE-SP-5	TI-7000 pt. 21	790	JB-21	Thermal Shield Cooler CWD	Redesignated TE-888.1
TE-SP-6		790	JB-21	Thermal Shield Cooler CWD	Redesignated TE-888.1S
TE-SP-7	TR-6500 pt. 17	111	JB-21	Letdown Heat Exch. Purge Outlet	Redesignated TE-192
TE-SP-8		111	JB-21	Letdown Heat Exch. Purge Outlet	Redesignated TE-192S
TE-SP-9	TdR-6590 pt. 2+	4	JB-23	Fuel Heat Exch. Shell, Bottom	Redesignated TE-586.1
TE-SP-10	TdR-6590 pt. 3-	4	JB-23	Fuel Heat Exch. Shell, Bottom	Redesignated TE-586.1S
TE-SP-11			JB-23		
TE-SP-12	TdR-6590 pt. 4+	31	JB-43	Blanket Heat Exch. Shell, Bottom	Redesignated TE-588.1
TE-SP-13	TdR-6590 pt. 6-	31	JB-43	Blanket Heat Exch. Shell, Bottom	Redesignated TE-588.1S
TE-SP-14			JB-43		
TE-SP-15			JB-35		
TE-SP-16			JB-35		
TE-SP-17			JB-35	Air at Floor of Blanket Reactor Cell	Redesignated TE-X31
TE-SP-18			JB-35		
TE-SP-19			JB-42		
TE-SP-20			JB-42		
TE-SP-21			JB-42	Chem. Proc. Take-off Valve (HCV-440) Outlet	Redesignated TE-480
TE-SP-22			JB-42	Chem. Proc. Take-off Valve (HCV-440) Outlet	Redesignated TE-480S
TE-SP-23		10*	JB-56		TC in 3/16" SS Shield

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-SP-24		10*	JB-56		TC in 3/16" SS Shield
TE-SP-25		*			At Steam Pit
TE-SP-26		*			At Wast Evap.
TE-SP-27			JB-26		Deleted TE-174
TE-SP-28			JB-26		Deleted TE-174S
TE-SP-29			JB-33		Deleted TE-274
TE-SP-30			JB-33		Deleted TE-274S
TE-SP-31			JB-57		
TE-SP-32			JB-57		
TE-SP-33			JB-57		
TE-SP-34			JB-57		
TE-SP-35			JB-58		
TE-SP-36			JB-58		
TE-SP-37			JB-58		
TE-SP-38			JB-58		
TE-SP-39			JB-59		
TE-SP-40			JB-59		
TE-SP-41			JB-59		
TE-SP-42			JB-59		
TE-SP-43			JB-60		
TE-SP-44			JB-60		
TE-SP-45			JB-60		
TE-SP-46			JB-61		

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-SP-47			JB-61		
TE-SP-48			JB-61		
TE-SP-49			JB-61		
TE-SP-50			JB-62		
TE-SP-51			JB-62		
TE-SP-52			JB-62		
TE-SP-53			JB-62		
TE-SP-54			JB-62		
TE-SP-55			JB-62		
TE-SP-56			JB-62		
TE-SP-57			JB-62		
TE-SP-58			JB-62		
TE-SP-59			JB-62		
TE-SP-60			JB-63		
TE-SP-61			JB-63		
TE-SP-62			JB-57		
TE-SP-63		*			At Waste Evap.

TE-X1		300	JB-59	Fuel Heat Exch. Steam Outlet	
TE-X2		4	JB-59	Fuel Heat Exch. Shell between Steam Outlets	
TE-X3		1	JB-57	Core Vessel Specimen Holder - Top	Tentative
TE-X4		1	JB-57	Core Vessel Specimen Holder - Middle	"
TE-X5		1	JB-57	Core Vessel Specimen Holder - Bottom	"

TE-X13		10d*	JB-56	Adsorber Bed; 1/2" Line	Leads do not pass thru patch panel. HRT-CP TC in 3/16" SS Shield
TE-X14		10d*	JB-56	Adsorber Bed; 1" Line	" " " " "
TE-X15		10d*	JB-56	Adsorber Bed; 2" Line	" " " " "
TE-X16		10d*	JB-56	Adsorber Bed; 6" Line	" " " " "
TE-X17	TI-7000 pt 25	92	JB-17	Thermal Shield E. Side	
TE-X18	TI-7000 pt 26	92	JB-17	Thermal Shield E. Side	
TE-X19	TI-7000 pt 27	92	JB-22	Thermal Shield N. Side	
TE-X20	TI-7000 pt 28	92	JB-22	Thermal Shield Bottom	
TE-X21	TI-7000 pt 29	92	JB-17	Thermal Shield Top	

<u>Thermo- couple Number</u>	<u>Instr. Termi- nation</u>	<u>Vessel or Line No.</u>	<u>Junction Box No.</u>	<u>Location</u>	<u>Remarks</u>
TE-X22	TR-6500 pt. 95		JB-57	Air at Fuel Space Cooler A	
TE-X23	TR-6500 pt. 96		JB-57	Air at Fuel Space Cooler B	
TE-X24	TR-6500 pt. 97		JB-60	Air at Blanket Space Cooler C	
TE-X25	TR-6500 pt. 98		JB-60	Air at Blanket Space Cooler D	
TE-X26			JB-57	Air at Fuel Circulating Pump	
TE-X27			JB-60	Air at Blanket Circulating Pump	
TE-X28		*		Air at Top in West Inst. Cubicle	
TE-X29		*		Air at Top in East Inst. Cubicle	
TE-X30			JB-28	Air at Floor of Fuel Rctr. Cell	
TE-X31			JB-35	Air at Floor of Blanket Rctr. Cell	
TE-X32			JB-57	Air above Fuel Pressurizer	

Instr.
Termi-
nation

Vessel
pr
Line No.

Junction
Box. No. _____

REACTOR SHIELD WALLS

Location

Remarks

TE-A1	*	JB-55	S. Shield wall near E Reactor at elevation 816'	Leads do not pass thru patch panel
TE-A2	*	JB-55	" " " " "	" " " " " " "
TE-A3	*	JB-55	" " " " "	" " " " " " "
TE-A4	*	JB-55	" " " " "	" " " " " " "
TE-A5	*	JB-55	" " " " "	" " " " " " "
TE-A6	*	JB-55	" " " " "	" " " " " " "
TE-B1	*	JB-55	S. Shield wall 16' W. of Reactor E at elevation 819'	" " " " " " "
TE-B2	*	JB-55	" " " " "	" " " " " " "
TE-B3	*	JB-55	" " " " "	" " " " " " "
TE-C1	*	JB-55	W. Shield Wall near E Reactor at elevation 815'	" " " " " " "
TE-C2	*	JB-55	" " " " "	" " " " " " "
TE-C3	*	JB-55	" " " " "	" " " " " " "

<u>Instr. No.</u>	<u>Description and Function</u>
TI-175	Simplytrol; 0-300°F C.A.; Single indication; Fuel HP Sampler at Sample Station
TI-275	Simplytrol; 0-300°F C.A.; Single indication; Blanket HP Sampler at Sample Station
TI-367	Simplytrol; 0-300°F C.A.; Single indication; Fuel LP Sampler at Sample Station
TI-375	Simplytrol; 0-800°C C.A.; Single indication with high and low contacts; Fuel Recombiner Control; Main Board 2
TI-467	Simplytrol; 0-300°F C.A.; Single indication; Blanket LP Sampler at Sample Station
TI-475	Simplytrol; 0-800°C C.A.; Single indication with high and low contacts; Blanket Recombiner Control; Main Board 10
TI-665	American Thermometer 30° to 240°F, indicates the temperature of the warm water header, Line 663, Second Level
TI-666	Simplytrol; -75° to 225°F, C.A.; Single indication working into 4 point selector switch for test heat exchanger steam lines, Second Level
TI-982	Simplytrol, 0° to 750°F, Iron-Constantan; Single indication; Flue gas leaving package boiler; package boiler room
FR-1500	M-H Recorder C.A.; 12 point record, records the calculated flow rate of the feed and purge pumps at rated CW and HW flow on coolers and heat exchanger; works in conjunction with TdM-1500A and TdM-1500B and XX-1500, Auxiliary Board 6 coolers and heat exchangers; works 15/0000 15/0000 15/0000
TI-5001	Simplytrol; -400° to +100°F Copper-Constantan; Single indication with high contact working thru 4 point selector switch for oxygen generator control; Oxygen supply station panel in control room.
TI-5002	Simplytrol; 0° to 800°C Chromel-Alumel; Single indication with high contact for oxygen generator heater control; Oxygen Generator Supply Station Panel in Control Room
TR-6500	M-H Scanner; 0-350°C C.A.; 108 point record; for secondary readout; alarm set point for each bank of nine thermocouples; Scanner Cabinet in Control Room
TR-6510	M-H Recorder; 0-350°C C.A.; 12 point record; for primary readout; single alarm set point; Main Board 6
TdT-6520	M-H Electro-Pneumatic Transducer; $\pm 20^\circ\text{C}$ C. 347 SS at 280°C; Blanket Steam Load Control; Auxiliary Panel 4
TdR-6530	M-H Recorder; 0-1.5 to 0-3.0 mv; Single pen record; Reactor Power; Four interlock contacts; Main Board 7
TR-6560	M-H Recorder; 0-350°C C.A.; Two pen record; Core inlet and outlet; five interlock contacts; Main Board 5
TaT-6570	M-H Electro-Pneumatic Transducer; 0-40°C C.A. with adjustable zero; Core average; Auxiliary Board 4
TR-6580	M-H Recorder; 0-700°C C.A.; 16 point record; Pressurizer Heaters; Two interlock contacts; Auxiliary Board 3

Part II Cont'd.Instr. No.

TdR-6590	M-H Recorder; + 100°C C.A.; 12 point record; Reactor Vessels Differentials; high and low alarm contacts; Auxiliary Board 7
TI-7000	M-H Precision Indicator; 0-700°C C.A.; 48 point indicator; for secondary readout; Auxiliary Board 6
TI-T66	Simplytrol; -75°F to 225°F C.A.; Single indication; Cold F-11 Pump Outlet; Refrigeration Panel
TI-T74	Simplytrol; -75°F to 225°F C.A.; Single indication working into 12 point selector switch for refrigerant lines; Refrigeration Panel
TI-T75	Simplytrol; -75°F to 225°F C.A.; Single indication working into 12 point selector switch for refrigerant lines; Refrigeration Panel
TI-T76	Simplytrol; -75°F to 225°F C.A.; Single indication working into 12 point selector switch for refrigerant lines; Refrigeration Panel

* Not in Reactor Cell

1-41

OAK RIDGE NATIONAL LABORATORY

OPERATED BY

UNION CARBIDE NUCLEAR COMPANY

POST OFFICE BOX X
OAK RIDGE, TENNESSEE

February 14, 1958

U. S. Atomic Energy Commission
Technical Information Service Extension
Post Office Box 62
Oak Ridge, Tennessee

Attention: Miss Margaret Pflueger

Gentlemen:

Subject: CF 57-1-159, Issue No. 4 (Unclassified)

Enclosed are seven copies of the subject document which we feel are of interest to the Pennsylvania Advanced Reactor Project. We will appreciate you making these copies available to them. This document may also be made available to the Civilian Application Program if considered applicable.

Very truly yours,

OAK RIDGE NATIONAL LABORATORY

for N. T. Bray
N. T. Bray, Supervisor
Laboratory Records Department
Technical Information Division

/mh

Enclosures (7)

ORNL:RC

CC: J. W. Norris

*1 cy. Carbide
5 cyp. Westinghouse*