228/6-2-75
ANCR-1199

No 1384 ~~1384~~
UC-78a

EXPERIMENT DATA REPORT FOR SEMISCALE
MOD-1 TEST S-01-1B
(ISOTHERMAL BLOWDOWN WITH CORE RESISTANCE SIMULATOR)

H.S. Crapo
M.F. Jensen
K.E. Sackett
S.N. Zender

Aerojet Nuclear Company

IDAHO NATIONAL ENGINEERING LABORATORY

Idaho Falls, Idaho — 83401

MASTER

DATE PUBLISHED - MAY 1975

PREPARED FOR THE
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION
IDAHO OPERATIONS OFFICE UNDER CONTRACT AT(10-1)-1375

DISTRIBUTION OF THIS DOCUMENT UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Printed in the United States of America
Available from
National Technical Information Service
U. S. Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22161
Price: Printed Copy \$7.60; Microfiche \$2.25

LEGAL NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

ANCR-1199

Light Water Reactor Safety and Technology –
System Interactions and Effects
TID-4500

EXPERIMENT DATA REPORT FOR SEMISCALE MOD-1

TEST S-01-1B

(Isothermal Blowdown with Core Resistance Simulator)

by

H.S. Crapo
M.F. Jensen
K.E. Sackett
S. N. Zender

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Date Published - May 1975

PREPARED FOR THE
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION
IDAHO OPERATIONS OFFICE
UNDER CONTRACT NO: AT(10-1)-1375

MASTER

DISTRIBUTION OF THIS DOCUMENT UNLIMITED

ABSTRACT

Recorded test data are presented for Test S-01-1B of the semiscale Mod-1 isothermal blowdown test series. Test S-01-1B is one of several semiscale Mod-1 experiments which are counterparts of the planned Loss-of-Fluid Test (LOFT) nonnuclear experiments. System hardware is representative of the LOFT design, selected using volumetric scaling methods, and initial conditions duplicate those identified for the LOFT nonnuclear tests.

Test S-01-1B is a repeat of Test S-01-1 with the exception that simulated ECC was injected into the cold leg of the intact loop rather than into the inlet annulus of the downcomer. The principal objective of Test S-01-1B was to determine whether a different ECC injection would significantly alter the system response during the period of ECC injection.

Test S-01-1B was conducted from an initial temperature of 541°F and an initial pressure of 1630 psig. A simulated intermediate size double-ended hot leg break (0.00145 ft² break area on each end) was used to investigate the system response to a slow depressurization transient. An orificed structure was used in the pressure vessel to simulate the LOFT core simulator. Following the blowdown portion of Test S-01-1B, coolant spray was introduced into the pressure suppression tank to determine the response of the pressure suppression system.

The purpose of this report is to make available the uninterpreted data from Test S-01-1B for future data analysis and test results reporting activities. The data, presented in the form of graphs in engineering units, have been analyzed only to the extent necessary to assure that they are reasonable and consistent.

SUMMARY

Test S-01-1B was performed as part of the semiscale Mod-1 portion of the Semiscale Blowdown and Emergency Core Cooling (ECC) Project conducted by Aerojet Nuclear Company for the United States Energy Research and Development Administration. This test was one of the semiscale Mod-1 tests in Test Group 1 performed with hardware configuration and test parameters selected to yield a system response that simulates the Loss-of-Fluid Test (LOFT) system response during the LOFT nonnuclear blowdown experiments. Test S-01-1B utilized a pressure vessel with internals; an intact loop with active pump, steam generator, and pressurizer; a broken loop with simulated pump, simulated steam generator, and rupture assemblies; a pressure suppression system with header and pressure suppression tank; and a coolant injection system with low-pressure injection pumps, high-pressure injection pumps, and accumulators. An orificed structure was used in the core barrel of the pressure vessel to simulate the flow resistance of the core simulator to be used in the LOFT nonnuclear tests.

The overall objective of the semiscale program is to provide data for use in the development and verification of analytical models that are used to predict the transient thermal-hydraulic response of a water-cooled nuclear reactor system during a hypothetical loss-of-coolant accident (LOCA). The semiscale Mod-1 program has the further general objective of providing support to other experimental programs in the form of instrumentation assessment, optimization of test series, selection of test parameters, and evaluation of test results.

The area of interest specific to Test S-01-1B was the effect of the location of the emergency core cooling injection point on the delivery of coolant to the lower plenum during a slow depressurization transient. Test S-01-1B was conducted essentially as Test S-01-1, except that ECC was injected into the cold leg of the intact loop piping rather than into the downcomer inlet annulus. Test S-01-1B was conducted from initial conditions of 1630 psig and 541°F with an intermediate size simulated hot leg break (0.00290 ft^2).

The recorded initial conditions were within acceptable bounds to allow analysis of the test data. An instantaneous offset shear of the broken loop hot leg piping was satisfactorily simulated by almost simultaneous (within 10 milliseconds) actuation of the rupture assemblies. The instrumentation used for Test S-01-1B generally functioned as intended. Of about 200 measurements attempted, 186 produced usable data.

CONTENTS

ABSTRACT	ii
SUMMARY	iii
I. INTRODUCTION	1
II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-01-1B	3
1. SYSTEM CONFIGURATION AND TEST PROCEDURES	3
2. INITIAL TEST CONDITIONS AND SEQUENCE OF EVENTS	6
III. DATA PRESENTATION	11
IV. REFERENCES	159

FIGURES

1. Semiscale Mod-1 system and instrumentation for hot leg break configuration -- isometric	4
2. Semiscale Mod-1 system and instrumentation for hot leg break configuration -- schematic	5
3. Semiscale Mod-1 pressure vessel -- cross section showing instrumentation	12
4. Semiscale Mod-1 pressure vessel -- isometric showing instrumentation	13
5. Semiscale Mod-1 pressure vessel -- penetrations and instrumentation	14
6. Fluid temperatures in intact loop (RBU-2, TFU-5, TSU-7, TFU-10, and TFU-15) from -2 to 110 seconds	26
7. Fluid temperatures in intact loop (RBU-2, TFU-5, TSU-7, TFU-10, and TFU-15) from -2 to 30 seconds	26
8. Fluid temperatures in intact loop (RBU-14A and TFU-14B) from -2 to 110 seconds	27

9.	Fluid temperatures in intact loop (RBU-14A and TFU-14B) from -2 to 30 seconds	27
10.	Fluid temperatures in broken loop from -2 to 110 seconds	28
11.	Fluid temperatures in broken loop from -2 to 30 seconds	28
12.	Fluid temperatures in inlet annulus from -2 to 110 seconds	29
13.	Fluid temperatures in inlet annulus from -2 to 30 seconds	29
14.	Fluid temperatures in downcomer annulus (TFV-ANN-15A, TFV-ANN-15M, and TFV-ANN-15T) from -2 to 110 seconds	30
15.	Fluid temperatures in downcomer annulus (TFV-ANN-15A, TFV-ANN-15M, and TFV-ANN-15T) from -2 to 30 seconds	30
16.	Fluid temperatures in downcomer annulus (TFV-ANN-35A, TFV-ANN-35M, and TFV-ANN-35T) from -2 to 110 seconds	31
17.	Fluid temperatures in downcomer annulus (TFV-ANN-35A, TFV-ANN-35M, and TFV-ANN-35T) from -2 to 30 seconds	31
18.	Fluid temperatures in downcomer annulus (TFV-ANN-115A and TFV-ANN-156A) from -2 to 110 seconds	32
19.	Fluid temperatures in downcomer annulus (TFV-ANN-115A and TFV-ANN-156A) from -2 to 30 seconds	32
20.	Fluid temperatures in lower plenum from -2 to 110 seconds	33
21.	Fluid temperatures in lower plenum from -2 to 30 seconds	33
22.	Fluid temperatures in core (LOFT) from -2 to 110 seconds	34
23.	Fluid temperatures in core (LOFT) from -2 to 30 seconds	34
24.	Fluid temperatures in core barrel insulation gap from -2 to 110 seconds	35
25.	Fluid temperatures in core barrel insulation gap from -2 to 30 seconds	35
26.	Fluid temperatures in vessel filler insulation gap from -2 to 110 seconds	36
27.	Fluid temperatures in vessel filler insulation gap from -2 to 30 seconds	36
28.	Fluid temperatures in steam generator from -2 to 110 seconds	37

29.	Fluid temperatures in steam generator from -2 to 30 seconds	37
30.	Fluid temperature in pressurizer surge line from -2 to 110 seconds	38
31.	Fluid temperature in pressurizer surge line from -2 to 30 seconds	38
32.	Fluid temperatures in pressure suppression tank from -2 to 110 seconds	39
33.	Fluid temperatures in pressure suppression tank from -2 to 30 seconds	39
34.	Material temperatures in intact loop (TMU-1T16, TMU-1S16, TMU-1B16, TMU-5B16, and TMU-7S16) from -2 to 110 seconds	40
35.	Material temperatures in intact loop (TMU-1T16, TMU-1S16, TMU-1B16, TMU-5B16, and TMU-7S16) from -2 to 30 seconds	40
36.	Material temperatures in intact loop (TMU-8S16, TMU-10S16, TMU-15T16, and TMU-15B16) from -2 to 110 seconds	41
37.	Material temperatures in intact loop (TMU-8S16, TMU-10S16, TMU-15T16, and TMU-15B16) from -2 to 30 seconds	41
38.	Material temperatures in broken loop from -2 to 110 seconds	42
39.	Material temperatures in broken loop from -2 to 30 seconds	42
40.	Material temperatures in vessel wall from -2 to 110 seconds	43
41.	Material temperatures in vessel wall from -2 to 30 seconds	43
42.	Material temperatures in vessel filler outside diameter from -2 to 110 seconds	44
43.	Material temperatures in vessel filler outside diameter from -2 to 30 seconds	44
44.	Material temperatures in vessel filler inside diameter (TMV-FI-4M, TMV-FI-15A, TMV-FI-35A, and TMV-FI-35M) from -2 to 110 seconds	45
45.	Material temperatures in vessel filler inside diameter (TMV-FI-4M, TMV-FI-15A, TMV-FI-35A, and TMV-FI-35M) from -2 to 30 seconds	45
46.	Material temperatures in vessel filler inside diameter (TMV-FI-70A, TMV-FI-115A, TMV-FI-156A, TMV-FI-156M, and TMV-FI-177M) from -2 to 110 seconds	46

47.	Material temperatures in vessel filler inside diameter (TMV-FI-70A, TMV-FI-115A, TMV-FI-156A, TMV-FI-156M, and TMV-FI-177M) from -2 to 30 seconds	46
48.	Material temperatures in vessel filler insulator from -2 to 110 seconds	47
49.	Material temperatures in vessel filler insulator from -2 to 30 seconds	47
50.	Material temperature in vessel lower head from -2 to 110 seconds	48
51.	Material temperature in vessel lower head from -2 to 30 seconds	48
52.	Material temperatures in core barrel outside diameter (TMV-CO-4A, TMV-CO-4M, TMV-CO-15A, TMV-CO-70A, TMV-CO-115A, and TMV-CO-115M) from -2 to 110 seconds	49
53.	Material temperatures in core barrel outside diameter (TMV-CO-4A, TMV-CO-4M, TMV-CO-15A, TMV-CO-70A, TMV-CO-115A, and TMV-CO-115M) from -2 to 30 seconds	49
54.	Material temperatures in core barrel inside diameter (TMV-CI-70A and TMV-CI-115A) from -2 to 110 seconds	50
55.	Material temperatures in core barrel inside diameter (TMV-CI-70A and TMV-CI-115A) from -2 to 30 seconds	50
56.	Material temperatures in steam generator from -2 to 110 seconds	51
57.	Material temperatures in steam generator from -2 to 30 seconds	51
58.	Pressures in vessel side of broken loop from -2 to 110 seconds	52
59.	Pressures in vessel side of broken loop from -2 to 30 seconds	52
60.	Pressures in pump side of broken loop from -2 to 110 seconds	53
61.	Pressures in pump side of broken loop from -2 to 30 seconds	53
62.	Pressures in vessel from -2 to 110 seconds	54
63.	Pressures in vessel from -2 to 30 seconds	54

64.	Pressure in intact loop ECC accumulator from -2 to 110 seconds	55
65.	Pressure in pressurizer from -2 to 110 seconds	56
66.	Pressure in pressurizer from -2 to 30 seconds	56
67.	Pressure in pressure suppression tank from -2 to 110 seconds	57
68.	Pressure in pressure suppression tank from -2 to 30 seconds	57
69.	Differential pressure in intact loop (upper plenum to Spool 3) from -2 to 110 seconds	58
70.	Differential pressure in intact loop (upper plenum to Spool 3) from -2 to 30 seconds	58
71.	Differential pressure in intact loop (Spool 3 to Spool 7) from -2 to 110 seconds	59
72.	Differential pressure in intact loop (Spool 3 to Spool 7) from -2 to 30 seconds	59
73.	Differential pressure in intact loop, low range (Spool 3 to Spool 7) from -2 to 110 seconds	60
74.	Differential pressure in intact loop, low range (Spool 3 to Spool 7) from -2 to 30 seconds	60
75.	Differential pressure in intact loop (Spool 6 to steam generator inlet plenum) from -2 to 110 seconds	61
76.	Differential pressure in intact loop (Spool 6 to steam generator inlet plenum) from -2 to 30 seconds	61
77.	Differential pressure in intact loop (SG1 to SG2) from -2 to 110 seconds	62
78.	Differential pressure in intact loop (SG1 to SG2) from -2 to 30 seconds	62
79.	Differential pressure in intact loop (steam generator outlet plenum to Spool 7) from -2 to 110 seconds	63
80.	Differential pressure in intact loop (steam generator outlet plenum to Spool 7) from -2 to 30 seconds	63

81.	Differential pressure in intact loop (Spool 7 to Spool 10) from -2 to 110 seconds	64
82.	Differential pressure in intact loop (Spool 7 to Spool 10) from -2 to 30 seconds	64
83.	Differential pressure in intact loop (Spool 8C to Spool 8D) from -2 to 110 seconds	65
84.	Differential pressure in intact loop (Spool 8C to Spool 8D) from -2 to 30 seconds	65
85.	Differential pressure in intact loop (Spool 8D to Spool 8E) from -2 to 110 seconds	66
86.	Differential pressure in intact loop (Spool 8D to Spool 8E) from -2 to 30 seconds	66
87.	Differential pressure in intact loop (Spool 12 to Spool 10) from -2 to 110 seconds	67
88.	Differential pressure in intact loop (Spool 12 to Spool 10) from -2 to 30 seconds	67
89.	Differential pressure in intact loop, low range (Spool 12 to Spool 10) from 02 to 110 seconds	68
90.	Differential pressure in intact loop, low range (Spool 12 to Spool 10) from -2 to 30 seconds	68
91.	Differential pressure in intact loop (Spool 12 to Spool 15) from -2 to 110 seconds	69
92.	Differential pressure in intact loop (Spool 12 to Spool 15) from -2 to 30 seconds	69
93.	Differential pressure in intact loop (Spool 15 to Spool 1) from -2 to 110 seconds	70
94.	Differential pressure in intact loop (Spool 15 to Spool 1) from -2 to 30 seconds	70
95.	Differential pressure in intact loop, low range (Spool 15 to Spool 1) from -2 to 110 seconds	71

96.	Differential pressure in intact loop, low range (Spool 15 to Spool 1) from -2 to 30 seconds	71
97.	Differential pressure in intact loop (Spool 15 to vessel inlet annulus) from -2 to 110 seconds	72
98.	Differential pressure in intact loop (Spool 15 to vessel inlet annulus) from -2 to 30 seconds	72
99.	Differential pressure in intact loop (Spool 15 to atmosphere) from -2 to 110 seconds	73
100.	Differential pressure in intact loop (pressurizer liquid level) from -2 to 110 seconds	74
101.	Differential pressure in intact loop (pressurizer liquid level) from -2 to 30 seconds	74
102.	Differential pressure in broken loop (vessel upper plenum to Spool 21A) from -2 to 110 seconds	75
103.	Differential pressure in broken loop (vessel upper plenum to Spool 21A) from -2 to 30 seconds	75
104.	Differential pressure in broken loop (Spool 21A to Spool 23) from -2 to 110 seconds	76
105.	Differential pressure in broken loop (Spool 21A to Spool 23) from -2 to 30 seconds	76
106.	Differential pressure in broken loop (Spool 23 to vessel-side nozzle throat) from -2 to 110 seconds	77
107.	Differential pressure in broken loop (Spool 23 to vessel-side nozzle throat) from -2 to 30 seconds	77
108.	Differential pressure in broken loop (vessel-side nozzle throat to divergent section) from -2 to 110 seconds	78
109.	Differential pressure in broken loop (vessel-side nozzle throat to divergent section) from -2 to 30 seconds	78
110.	Differential pressure in broken loop (Spool 23 to Spool 24) from -2 to 110 seconds	79

111. Differential pressure in broken loop (Spool 23 to Spool 24) from -2 to 30 seconds	79
112. Differential pressure in broken loop (vessel inlet annulus to Spool 30) from -2 to 110 seconds	80
113. Differential pressure in broken loop (vessel inlet annulus to Spool 30) from -2 to 30 seconds	80
114. Differential pressure in broken loop (Spool 30 to Spool 40) from -2 to 110 seconds	81
115. Differential pressure in broken loop (Spool 30 to Spool 40) from -2 to 30 seconds	81
116. Differential pressure in broken loop (Spool 40 to Spool 38) from -2 to 110 seconds	82
117. Differential pressure in broken loop (Spool 40 to Spool 38) from -2 to 30 seconds	82
118. Differential pressure in broken loop, low range (Spool 40 to Spool 38) from -2 to 110 seconds	83
119. Differential pressure in broken loop (Spool 38 to Spool 36U) from -2 to 110 seconds	84
120. Differential pressure in broken loop (Spool 38 to Spool 36U) from -2 to 30 seconds	84
121. Differential pressure in broken loop (Spool 37 to Spool 36U) from -2 to 110 seconds	85
122. Differential pressure in broken loop (Spool 37 to Spool 36U) from -2 to 30 seconds	85
123. Differential pressure in broken loop (Spool 37 to Spool 42) from -2 to 110 seconds	86
124. Differential pressure in broken loop (Spool 37 to Spool 42) from -2 to 30 seconds	86
125. Differential pressure in broken loop (Spool 36U to Spool 32L) from -2 to 110 seconds	87

126. Differential pressure in broken loop (Spool 36U to Spool 32L) from -2 to 30 seconds	87
127. Differential pressure in broken loop (Spool 42 to Spool 43) Ffrom -2 to 110 seconds	88
128. Differential pressure in broken loop (Spool 42 to Spool 43) from -2 to 30 seconds	88
129. Differential pressure in broken loop (Spool 42 to pump-side nozzle throat) from -2 to 110 seconds	89
130. Differential pressure in broken loop (Spool 42 to pump-side nozzle throat) from -2 to 30 seconds	89
131. Differential pressure in broken loop (pump-side nozzle throat to divergent section) from -2 to 110 seconds	90
132. Differential pressure in broken loop (pump-side nozzle throat to divergent section) from -2 to 30 seconds	90
133. Differential pressure in broken loop (pump-side nozzle divergent section to Spool 43) from -2 to 110 seconds	91
134. Differential pressure in broken loop (pump-side nozzle divergent section to Spool 43) from -2 to 30 seconds	91
135. Differential pressure in vessel (upper plenum to inlet annulus) from -2 to 110 seconds	92
136. Differential pressure in vessel (upper plenum to inlet annulus) from -2 to 30 seconds	92
137. Differential pressure in vessel (DPV-9-26QQ) from -2 to 110 seconds	93
138. Differential pressure in vessel (DPV-9-26QQ) from -2 to 30 seconds	93
139. Differential pressure in vessel (DPV-26-55QM) from -2 to 110 seconds	94
140. Differential pressure in vessel (DPV-26-55QM) from -2 to 30 seconds	94
141. Differential pressure in vessel (DPV-55-110AM) from -2 to 110 seconds	95
142. Differential pressure in vessel (DPV-55-110AM) from -2 to 20 seconds	95
143. Differential pressure in vessel (DPV-156-173QQ) from -2 to 110 seconds	96

144. Differential pressure in vessel (DPV-156-173QQ) from -2 to 30 seconds	96
145. Differential pressure in vessel (DPV-166-173QQ) from -2 to 110 seconds	97
146. Differential pressure in vessel (DPV-166-173QQ) from -2 to 30 seconds	97
147. Differential pressure in vessel (DPV-166-191QT) from -2 to 110 seconds	98
148. Differential pressure in vessel (DPV-166-191QT) from -2 to 30 seconds	98
149. Differential pressure in vessel (DPV-LP-UP) from -2 to 110 seconds	99
150. Differential pressure in vessel (DPV-LP-UP) from -2 to 30 seconds	99
151. Differential pressure in steam generator secondary (secondary liquid level) from -2 to 110 seconds	100
152. Differential pressure in steam generator secondary (secondary liquid level) from -2 to 30 seconds	100
153. Volumetric flows in intact loop (FTU-1 and FTU-9) from -2 to 110 seconds . .	101
154. Volumetric flows in intact loop (FTU-1 and FTU-9) from -2 to 30 seconds . . .	101
155. Volumetric flows in intact loop (FTU-13 and FTU-15) from -2 to 110 seconds .	102
156. Volumetric flows in intact loop (FTU-13 and FTU-15) from -2 to 30 seconds .	102
157. Volumetric flows in broken loop (FTB-21A, FTB-30, and FTB-37) from -2 to 110 seconds	103
158. Volumetric flows in broken loop (FTB-21A, FTB-30, and FTB-37) from -2 to 30 seconds	103
159. Volumetric flow in core entrance from -2 to 110 seconds	104
160. Volumetric flow in core entrance from -2 to 30 seconds	104
161. Volumetric flow from high-pressure injection system from -2 to 110 seconds . .	105
162. Volumetric flow from low-pressure injection system from -2 to 110 seconds . .	106
163. Volumetric flow from intact loop accumulator from -2 to 110 seconds	107
164. Volumetric flow from pressurizer from -2 to 110 seconds	108

165. Volumetric flow from pressurizer from -2 to 30 seconds	108
166. Fluid velocity in vessel (FTV-22M) from -2 to 110 seconds	109
167. Fluid velocity in vessel (FTV-22M) from -2 to 30 seconds	109
168. Fluid velocity in vessel (FTV-40A) from -2 to 110 seconds	110
169. Fluid velocity in vessel (FTV-40A) from -2 to 30 seconds	110
170. Fluid velocity in vessel (FTV-40M) from -2 to 110 seconds	111
171. Fluid velocity in vessel (FTV-40M) from -2 to 30 seconds	111
172. Fluid velocity in vessel (FTV-83A) from -2 to 110 seconds	112
173. Fluid velocity in vessel (FTV-83A) from -2 to 30 seconds	112
174. Fluid velocity in vessel (FTV-83M) from -2 to 110 seconds	113
175. Fluid velocity in vessel (FTV-83M) from -2 to 30 seconds	113
176. Momentum flux in intact loop (Spool 1) from -2 to 110 seconds	114
177. Momentum flux in intact loop (Spool 1) from -2 to 30 seconds	114
178. Momentum flux in intact loop (Spool 5) from -2 to 110 seconds	115
179. Momentum flux in intact loop (Spool 5) from -2 to 30 seconds	115
180. Momentum flux in intact loop (Spool 10) from -2 to 110 seconds	116
181. Momentum flux in intact loop (Spool 10) from -2 to 30 seconds	116
182. Momentum flux in intact loop (Spool 13) from -2 to 110 seconds	117
183. Momentum flux in intact loop (Spool 13) from -2 to 30 seconds	117
184. Momentum flux in intact loop (Spool 15) from -2 to 110 seconds	118
185. Momentum flux in intact loop (Spool 15) from -2 to 30 seconds	118
186. Momentum flux in broken loop (Spool 21A) from -2 to 110 seconds	119
187. Momentum flux in broken loop (Spool 21A) from -2 to 30 seconds	119

188. Momentum flux in broken loop (Spool 23) from -2 to 110 seconds	120
189. Momentum flux in broken loop (Spool 23) from -2 to 30 seconds	120
190. Momentum flux in broken loop (Spool 37) from -2 to 110 seconds	121
191. Momentum flux in broken loop (Spool 37) from -2 to 30 seconds	121
192. Momentum flux in broken loop (Spool 42) from -2 to 110 seconds	122
193. Momentum flux in broken loop (Spool 42) from -2 to 30 seconds	122
194. Momentum flux in core entrance from -2 to 110 seconds	123
195. Momentum flux in core entrance from -2 to 30 seconds	123
196. Densities in intact loop (GU-1VR and GU-1HZ) from -2 to 110 seconds	124
197. Densities in intact loop (GU-1VR and GU-1HZ) from -2 to 30 seconds	124
198. Densities in intact loop (GU-5VR and GU-10VR) from -2 to 110 seconds . . .	125
199. Densities in intact loop (GU-5VR and GU-10VR) from -2 to 30 seconds	125
200. Density in intact loop (GU-13VR) from -2 to 110 seconds	126
201. Density in intact loop (GU-13VR) from -2 to 30 seconds	126
202. Densities in intact loop (GU-15VR and GU-15HZ) from -2 to 110 seconds . . .	127
203. Densities in intact loop (GU-15VR and GU-15HZ) from -2 to 30 seconds . . .	127
204. Densities in broken loop (GB-21AVR and GB-23VR) from -2 to 110 seconds . .	128
205. Densities in broken loop (GB-21AVR and GB-23VR) from -2 to 30 seconds. . .	128
206. Densities in broken loop (GB-30VR and GB-42VR) from -2 to 110 seconds . .	129
207. Densities in broken loop (GB-30VR and GB-42VR) from -2 to 30 seconds . . .	129
208. Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 110 seconds.	130
209. Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 30 seconds .	130
210. Density in vessel (GVLP-172HZ) from -2 to 110 seconds	131

211. Density in vessel (GVLP-172HZ) from -2 to 30 seconds	131
212. Density in pressurizer surge line from -2 to 110 seconds	132
213. Density in pressurizer surge line from -2 to 30 seconds	132
214. Mass flow in intact loop (FDU-1 and GU-1VR) from -2 to 110 seconds	133
215. Mass flow in intact loop (FDU-1 and GU-1VR) from -2 to 30 seconds	133
216. Mass flow in intact loop (FTU-1 and GU-1VR) from -2 to 110 seconds	134
217. Mass flow in intact loop (FTU-1 and GU-1VR) from -2 to 30 seconds	134
218. Mass flow from pressurizer from -2 to 110 seconds	135
219. Mass flow from pressurizer from -2 to 30 seconds	135
220. Mass flow in intact loop (FDU-5 and GU-5VR) from -2 to 110 seconds	136
221. Mass flow in intact loop (FDU-5 and GU-5VR) from -2 to 30 seconds	136
222. Mass flow in intact loop (FDU-10 and GU-10VR) from -2 to 110 seconds	137
223. Mass flow in intact loop (FDU-10 and GU-10VR) from -2 to 30 seconds	137
224. Mass flow in intact loop (FDU-13 and GU-13VR) from -2 to 110 seconds	138
225. Mass flow in intact loop (FDU-13 and GU-13VR) from -2 to 30 seconds	138
226. Mass flow in intact loop (FTU-13 and GU-13VR) from -2 to 110 seconds	139
227. Mass flow in intact loop (FTU-13 and GU-13VR) from -2 to 30 seconds	139
228. Mass flow in intact loop (FDU-15 and GU-15VR) from -2 to 110 seconds	140
229. Mass flow in intact loop (FDU-15 and GU-15VR) from -2 to 30 seconds	140
230. Mass flow in intact loop (FTU-15 and GU-15VR) from -2 to 110 seconds	141
231. Mass flow in intact loop (FTU-15 and GU-15VR) from -2 to 30 seconds	141
232. Mass flow in broken loop (FDB-21A and GB-21AVR) from -2 to 110 seconds	142
233. Mass flow in broken loop (FDB-21A and GB-21AVR) from -2 to 30 seconds	142

234. Mass flow in broken loop (FTB-21A and GB-21AVR) from -2 to 110 seconds . .	143
235. Mass flow in broken loop (FTB-21A and GB-21AVR) from -2 to 30 seconds. . .	143
236. Mass flow in broken loop (FDB-23 and GB-23VR) from -2 to 110 seconds . . .	144
237. Mass flow in broken loop (FDB-23 and GB-23VR) from -2 to 30 seconds . . .	144
238. Mass flow in broken loop (FTB-30 and GB-30VR) from -2 to 110 seconds . . .	145
239. Mass flow in broken loop (FTB-30 and GB-30VR) from -2 to 30 seconds	145
240. Mass flow in broken loop (FDB-42 and GB-42VR) from -2 to 110 seconds . . .	146
241. Mass flow in broken loop (FDB-42 and GB-42VR) from -2 to 30 seconds . . .	146
242. Mass flow in vessel (FTV-CORE-IN and GV-COR-150HZ) from -2 to 110 seconds	147
243. Mass flow in vessel (FTV-CORE-IN and GV-COR-150HZ) from -2 to 30 seconds	147
244. Mass flow in vessel (FDV-CORE-IN and GV-COR-150HZ) from -2 to 110 seconds	148
245. Mass flow in vessel (FDV-CORE-IN and GV-COR-150HZ) from -2 to 30 seconds	148
246. Primary pump torque from -2 to 110 seconds	149
247. Primary pump torque from -2 to 30 seconds	149
248. Primary pump power from -2 to 110 seconds	150
249. Primary pump power from -2 to 30 seconds	150
250. Primary pump speed from -2 to 110 seconds	151
251. Primary pump speed from -2 to 30 seconds	151
252. Fluid temperature in intact loop (TFU-14B) from -2 to 230 seconds	152
253. Fluid temperature in vessel (TFV-LOFT-COR, TFV-ANN-156A, and TFV-LP-7-1/2) from -2 to 230 seconds	152

254. Fluid temperatures in pressure suppression tank from -2 to 230 seconds	153
255. Pressure in intact loop ECC accumulator from -2 to 230 seconds	153
256. Pressure in pressure suppression tank from -2 to 230 seconds	154
257. Differential pressure in intact loop (DPU-15-ATM) from -2 to 230 seconds	154
258. Differential pressure in intact loop (pressurizer liquid level) from -2 to 230 seconds	155
259. Differential pressure in vessel (DPV-LP-UP) from -2 to 230 seconds	155
260. Volumetric flow in core entrance (FTV-CORE-IN) from -2 to 230 seconds	156
261. Volumetric flow from intact loop accumulator from -2 to 230 seconds	156
262. Volumetric flow from pressure suppression spray system from -2 to 230 seconds	157
263. Momentum flux in core entrance from -2 to 230 seconds	157
264. Density in broken loop (GB-30VR) from -2 to 230 seconds	158
265. Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 230 seconds	158

TABLES

I. Conditions at Blowdown Initiation	7
II. Primary Coolant Temperature Distribution at Rupture	8
III. Water Chemistry Prior to Blowdown	9
IV. Sequence of Events During Test	10
V. Data Presentation for Semiscale Mod-1 Test S-01-1B	15

EXPERIMENT DATA REPORT FOR SEMISCALE MOD-1

TEST S-01-1B

(Isothermal Blowdown with Core Resistance Simulator)

I. INTRODUCTION

The semiscale Mod-1 experimental program is part of the Semiscale Blowdown and Emergency Core Cooling (ECC) Project conducted by Aerojet Nuclear Company. The semiscale project in turn is part of the United States Energy Research and Development Administration-sponsored research and development program to investigate the response of a water-cooled nuclear reactor system to a hypothesized loss-of-coolant accident (LOCA). The underlying objectives of the semiscale project are to quantify the physical processes controlling system behavior during an LOCA and to provide an experimental data base for assessing reactor safety evaluation models. The semiscale Mod-1 program has the further objective of providing support to other experimental programs in the form of instrumentation assessment, optimization of test series, selection of test parameters, and evaluation of test results.

The semiscale Mod-1 program is conducted with an experimental system designed to simulate the major components of a pressurized water reactor (PWR). Relative to previous experimental systems, the semiscale Mod-1 system advances the representation of a PWR and thus provides a means of acquiring coupled-system response data from which to obtain a more comprehensive understanding of the thermal and hydraulic processes occurring during an LOCA.

Test S-01-1B was conducted in the semiscale Mod-1 system as part of a series of tests (Test Group 1) to provide data for comparison of the isothermal blowdown response of the semiscale system with that of the Loss-of-Fluid Test (LOFT) system. The semiscale Mod-1 experimental configuration for this test utilized hardware components selected to produce a system performance which simulates LOFT system performance during the LOFT nonnuclear tests. An orificed structure was used in the core barrel of the pressure vessel to simulate the flow resistance of the core simulator to be used in the LOFT nonnuclear tests.

Test S-01-1B was conducted with system subcooling and break area reduced to duplicate the first isothermal test in the LOFT system. The test was initiated by a simulated intermediate size (0.00290 ft^2) double-ended break in the hot leg broken loop piping. The blowdown was accompanied by coolant injection into the intact cold leg piping to determine whether an injection location different from that used in Test S-01-1^[1] would produce significantly different system response during the period of ECC injection. Following blowdown, coolant spray was introduced into the pressure suppression tank.

The purpose of this report is to present the test data in an uninterpreted, but readily usable, form for use by the nuclear community in advance of detailed analysis and interpretation. Section II briefly describes the system configuration, procedures, initial test conditions, and events that are applicable to Test S-01-1B. Section III presents the data graphs and provides comments and supporting information necessary for interpretation of the data. A description of the overall semiscale program and test series, a detailed description of the semiscale Mod-1 system, and a description of the measurement and data processing techniques and uncertainties can be found in Appendices A, B, and C of Reference 2. Results from previous tests in this series are presented in References 1 through 5.

II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-01-1B

The following system configuration, procedures, initial test conditions, and events are specific to Test S-01-1B.

1. SYSTEM CONFIGURATION AND TEST PROCEDURES

The semiscale Mod-1 system used for Test S-01-1B consisted of a pressure vessel with internals; an intact loop with steam generator, pump, and pressurizer; a blowdown loop with simulated steam generator, simulated pump, and two rupture assemblies; a coolant injection system with accumulators and both high- and low-pressure injection pumps; and a pressure suppression system with a suppression tank and header. The semiscale Mod-1 experimental system is described in detail in Appendix B of Reference 2. The system configuration for Test S-01-1B differs from that described in Reference 2 only to the extent that the simulated break was in the hot leg as shown in Figures 1 and 2 of this report. This configuration has a volume in the broken loop hot leg of 0.321 ft^3 and a volume in the broken loop cold leg of 1.054 ft^3 .

For Test S-01-1B, the intact loop steam generator was maintained in the hot standby condition, in which the secondary side was valved off and the primary tubes were completely covered with water (at isothermal system temperature) when blowdown occurred.

In preparation for Test S-01-1B, the system was filled with treated demineralized water and vented at strategic points to assure a liquid full system. Prior to warmup, the system was pressurized to check for leakage. Warmup to initial test conditions was accomplished with heaters located in the bypass lines which served to allow circulation through the broken loop. During warmup, the purification and sampling systems were valved into the primary system to maintain water chemistry requirements and to provide a water sample at system conditions for subsequent analysis. These systems were valved out just prior to initiation of blowdown. At 100°F temperature intervals during warmup, detector readings were sampled to allow the integrity of the measurement instrumentation and the operability of the data acquisition system to be checked.

Prior to initiation of the blowdown test, initial test conditions were held for about 20 minutes to establish equilibrium in the system. At the end of this period, all auxiliary systems including the bypass lines were isolated to prevent blowdown through those systems.

Pressure to operate the rupture assemblies and initiate blowdown was taken from the system through lines connected to the reflood bypass simulators. Immediately following initiation of blowdown (0.02 second after initiation of blowdown), these lines were again isolated.

Fig. 1 Semiscale Mod-1 system and instrumentation for hot leg break configuration -- isometric.

Fig. 2 Semiscale Mod-1 system and instrumentation for hot leg break configuration -- schematic.

The speed of the primary coolant circulating pump was held constant for 30 seconds following initiation of blowdown. At 30 seconds, the power to the pump was shut off, and the pump was allowed to coast down for the remainder of the test. A flywheel mounted on the pump motor shaft provided a simulation of the predicted coastdown of the LOFT pumps.

The system was successfully subjected to a simulated double-ended hot leg pipe break through two blowdown nozzles, each having a break area of 0.00145 ft^2 . The effluent was ejected from the primary system into the pressure suppression system.

During the blowdown transient, simulated emergency core cooling (ECC) water was injected into the intact loop cold leg piping through use of the high-pressure injection system (HPIS), accumulator, and low-pressure injection system (LPIS).

2. INITIAL TEST CONDITIONS AND SEQUENCE OF EVENTS

Conditions in the semiscale Mod-1 system at initiation of blowdown are given in Tables I and II, the primary system water chemistry prior to blowdown is given in Table III, and the sequence of events relative to rupture is given in Table IV.

TABLE I
CONDITIONS AT BLOWDOWN INITIATION

	<u>Measured^[a]</u>	<u>Specified</u>
System Fluid Temperature (intact loop, vessel outlet)	540°F	540±2°F
System Pressure (vessel upper plenum)	1630 psig	1600±50 psig
Intact Loop Cold Leg Flow	174 gpm	173±2 gpm
Intact Loop Accumulator Pressure	599 psig	600 psig ^[b]
Temperature of Injected Coolant	62°F	85°F ^[b]
Intact Loop Accumulator Water Volume	1.54 ft ³	1.63 ft ³ ^[b]
Intact Loop Accumulator Gas Volume	1.16 ft ³	1.11 ft ³ ^[b]
Pressurizer Water Volume	0.67 ft ³	0.69 ft ³ ^[b]
Steam Generator Secondary Steam Dome Pressure	945 psig	963±40 psig
Steam Generator Secondary Fluid Temperature	542°F	540±5°F
Steam Generator Liquid Level (from bottom of tube sheet)	115.9 in.	116 in. ^[b]
Pressure Suppression Tank Water Level	47 in.	47.5 in. ^[b]
Pressure Suppression Tank Pressure	15.1 psig	15 psig ^[b]
Pressure Suppression Tank Water Temperature	191°F	193±5°F

[a] Measured initial conditions which did not meet the specified initial conditions were considered acceptable for analysis purposes within the test objectives.

[b] Tolerance not specified.

TABLE II

PRIMARY COOLANT TEMPERATURE DISTRIBUTION AT RUPTURE

	<u>Detector</u>	<u>Temperature (°F)</u>
Vessel lower plenum (lower portion)	TFV-LP-1-1/2	536
Vessel lower plenum (upper portion)	TFV-LP-27-1/2	544
Intact loop hot leg (near vessel)	RBU-2	540
Intact loop hot leg (104 in. from vessel center)	TFU-5	542
Intact loop cold leg (near steam generator)	TSU-7	543
Intact loop cold leg	RBU-14A	542
Broken loop hot leg (near vessel)	TFB-20	540
Broken loop hot leg (near vessel-side nozzle)	TFB-23	541
Broken loop cold leg (near vessel)	TFB-30	542
Broken loop hot leg (near pump-side nozzle)	TFB-42	538
Reflood bypass, cold leg	TFB-RFBC	537
Reflood bypass, hot leg	TFB-RFBH	541

TABLE III

WATER CHEMISTRY PRIOR TO BLOWDOWN^[a]

pH	10.48
Conductivity (μmhos/cm)	52.8
Suspended Solids (ppm)	3.17
Chlorides (ppm)	0.42
Lithium (ppm)	2.5
O ₂ (cc/l)	0.3
N ₂ (cc/l)	121.3
CO ₂ (cc/l)	0.02
Total Gas (cc/l)	126.0

[a] Water sample taken at a system pressure of 2250 psig and a system temperature of 540°F.

TABLE IV

SEQUENCE OF EVENTS DURING TEST^[a]

Event	Time Relative To Rupture (sec)
Heatup Bypass Lines Valved Out of System	-2
Initiation of Blowdown	0
Initiation of ECC Injection from Intact Loop High-Pressure Injection System Pumps	1
Initiation of ECC Injection from Intact Loop ECC Accumulator	33
Initiation of ECC Injection from Intact Loop ECC Low-Pressure Injection System Pumps	46
Termination of ECC Injection from Intact Loop ECC Accumulator	76
Initiation of Spray to Suppression Tank	114
Termination of ECC Injection from Intact Loop High- and Low-Pressure Injection Systems	>230

[a] A time-control sequencer was used to control critical events during the test.

III. DATA PRESENTATION

The data from semiscale Mod-1 Test S-01-1B are presented with brief comment. Processing analysis has been performed only to the extent necessary to obtain appropriate engineering units and to assure that the data are reasonable and consistent. In all cases, in converting transducer output to engineering units, a homogeneous fluid was assumed. Further interpretation and analysis should consider that sudden decompression processes such as those occurring during blowdown may have subjected the measurement devices to nonhomogeneous fluid conditions.

The performance of the system during Test S-01-1B was monitored by about 200 detectors. The data obtained were recorded on both a digital data acquisition system and an analog data acquisition system. The digital system was used to process the data presented in this report. The analog system was used to provide better resolution capability (needed as input to various data analysis codes) and to provide redundancy.

The data are presented, in many instances, in the form of composite graphs to facilitate comparison of a given variable at several locations. Each set of data is presented on two time scales. The first time scale presents data for the entire blowdown, or from -2 to 110 seconds. The second time scale expands the data for the first 30 seconds of the test. The data for each time scale were generated from a separate digital data tape. Since different time intervals exist between sampled data points for different time-base graphs, small differences are present in the transient data. The scales selected do not reflect the obtainable resolution of the data. The data processing techniques are described in greater detail in Appendix C of Reference 2.

Figures 1 through 5 and Table V provide supporting information for interpretation of the data graphs shown in Figures 6 through 265. Figures 1 through 5 show the relative locations of all detectors used during the Mod-1 isothermal series. Table V groups the measurements taken during Test S-01-1B according to measurement type; identifies the specific measurement location and the range of the detector and actual recording range of the data acquisition system; provides brief comments regarding the data; and references the measurements and comments to the corresponding figure. Figures 6 through 251 present all the blowdown data obtained. In addition, selected measurements are repeated in Figures 252 through 265 to provide data on the effects of pressure suppression system cooling spray. Time zero on the graphs is the time of rupture initiation.

Fig. 3 Semiscale Mod-1 pressure vessel -- cross section showing instrumentation.

Fig. 4 Semiscale Mod-1 pressure vessel -- isometric showing instrumentation.

TABLE V

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments [a]	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
FLUID TEMPERATURE					
Chromel-Alumel thermocouples unless specified otherwise					
<u>Intact Loop</u>					
RBU-2	Hot leg, Spool 2, 46 in. from vessel center (platinum resistance bulb)	0-2300°F	0-591°F	6, 7	
TFU-5	Hot leg, Spool 5, 104 in. from vessel center			6, 7	
TSU-7	Cold leg, Spool 7, 243 in. from vessel center (shielded)			6, 7	
TFU-10	Cold leg, Spool 10, 144 in. from vessel center			6, 7	
RBU-14A	Cold leg, Spool 14, 43 in. from vessel center, upstream of cold leg injection port (platinum resistance bulb)	0-1000°F	0-1000°F	8, 9	
TFU-14B	Cold leg, Spool 14, 39 in. from vessel center, downstream of cold leg injection port			8, 9, 252	
TFU-15	Cold leg, Spool 15, 16 in. from vessel center			6, 7	
<u>Broken Loop</u>					
TFB-20	Hot leg, Spool 20, 21 in. from vessel center	0-2300°F	0-591°F	10, 11	
TFB-23	Hot leg, Spool 23, 91 in. from vessel center, upstream of vessel-side nozzle				
TFB-30	Cold leg, Spool 30, 16 in. from vessel center				
TFB-42	Hot leg, Spool 42, 414 in. from vessel center along cold leg, upstream of pump-side nozzle				
TFB-RFBC	Reflood bypass, near end cap, cold-leg side				
TFB-RFBH	Reflood bypass, near end cap, hot-leg side				
<u>Inlet Annulus</u>					
	4 in. below cold leg centerline, 0.2 in. from vessel wall, Type J iron-constantan thermocouples	0-1400°F	0-692°F	12, 13	
TFV-ANN-4A	0°				
TFV-ANN-4M	180°				
<u>Downcomer Annulus</u>					
	Centered in annulus, Type J iron-constantan thermocouples	0-1400°F	0-692°F		
TFV-ANN-15A	15 in. below cold leg centerline, 0°			14, 15	
TFV-ANN-15M	15 in. below cold leg centerline, 180°			14, 15	
TFV-ANN-15T	15 in. below cold leg centerline, 270°			14, 15	
TFV-ANN-35A	35 in. below cold leg centerline, 0°			16, 17	
TFV-ANN-35M	35 in. below cold leg centerline, 180°			16, 17	
TFV-ANN-35T	35 in. below cold leg centerline, 270°			16, 17	
TFV-ANN-70A	70 in. below cold leg centerline, 0°				Data not available due to loss of time correlation signal
TFV-ANN-115A	115 in. below cold leg centerline, 0°			18, 19	
TFV-ANN-156A	156 in. below cold leg centerline, 0°			18, 19, 253	
<u>Lower Plenum</u>					
	On fluid thermocouple rack, 1 in. from vessel center, 45°	0-2300°F	0-591°F	20, 21	
TFV-LP-1-1/2	1.5 in. from bottom				
TFV-LP-7-1/2	7.5 in. from bottom			253	
TFV-LP-14-1/2	14.5 in. from bottom				
TFV-LP-21-1/2	21.5 in. from bottom				
TFV-LP-27-1/2	27.5 in. from bottom				

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments ^(a)	Range ^(a)		Figure ^(a)	Measurement Comments ^(b)
		Detector	Data Acquisition System		
<u>Core</u>		0-2300°F	0-591°F		
TFV-LOFT-COR	Near LOFT core turbine flowmeter, 14 in. below cold leg centerline			22, 23, 253	Increase in temperature from t=2 sec to t=5 sec questionable
<u>Core Barrel Insulation Cap</u>	Type J iron-constantan thermocouples	0-1400°F	0-692°F	24, 25	
TFV-CIG-70A	70 in. below cold leg centerline, 0°				
TFV-CIG-115A	115 in. below cold leg centerline, 0°				
<u>Vessel Filler - Insulation Cap</u>		0-1400°F	0-692°F	26, 27	
TFV-FIC-70A	70 in. below cold leg centerline, 0°				
TFV-FIC-156A	156 in. below cold leg centerline, 0°				
<u>Steam Generator</u>		0-2300°F	0-591°F	28, 29	
TFU-SG1	Secondary side, 12 in. above bottom of tube sheet				
TFU-SG2	Secondary side, 24 in. above bottom of tube sheet				
TFU-SG3	Secondary side, 48 in. above bottom of tube sheet				
TFU-SG4	Secondary side, 96 in. above bottom of tube sheet				
<u>Pressurizer</u>		0-2300°F	0-591°F	30, 31	
TFU-PR12E	In surge line, near pressurizer exit, between turbine flowmeter and pressurizer				
<u>Pressure Suppression System</u>		0-2300°F	0-591°F	32, 33, 254	
TF-PSS-17	17 in. from bottom of tank				
TF-PSS-33	33 in. from bottom of tank				
TF-PSS-130	130 in. from bottom of tank				
MATERIAL TEMPERATURE	Chromel-Alumel thermocouples unless specified otherwise	0-2300°F	0-591°F		
<u>Intact Loop</u>					
TMU-1T16	Hot leg, Spool 1, top, 1/16 in. from pipe ID, 29 in. from vessel center			34, 35	
TMU-1S16	Hot leg, Spool 1, side, 1/16 in. from pipe ID, 29 in. from vessel center			34, 35	
TMU-1B16	Hot leg, Spool 1, bottom, 1/16 in. from pipe ID, 29 in. from vessel center			34, 35	
TMU-5B16	Hot leg, Spool 5, bottom, 1/16 in. from pipe ID, 102 in. from vessel center			34, 35	
TMU-7S16	Cold leg, Spool 7, side, 1/16 in. from pipe ID, 242 in. from vessel center (vertical pipe)			34, 35	
TMU-8S16	Cold leg, Spool 8, side, in pump trap, 1/16 in. from pipe ID, 195 in. from vessel center			36, 37	
TMU-10S16	Cold leg, Spool 10, side, 1/16 in. from pipe ID, 144 in. from vessel center			36, 37	
TMU-15T16	Cold leg, Spool 15, top, 1/16 in. from pipe ID, 17 in. from vessel center			36, 37	
TMU-15B16	Cold leg, Spool 15, bottom, 1/16 in. from pipe ID, 17 in. from vessel center			36, 37	
<u>Broken Loop</u>		0-2300°F	0-591°F	38, 39	
TMB-20B4	Hot leg, Spool 20, bottom, 1/4 in. from pipe ID, 21 in. from vessel center				
TMB-20S16	Hot leg, Spool 20, side, 1/16 in. from pipe ID, 21 in. from vessel center				

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments [a]	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
<u>Broken Loop (Contd.)</u>					
TMB-20B16	Hot leg, Spool 20, bottom, 1/16 in. from pipe ID, 21 in. from vessel center				
TMB-30B16	Cold leg, Spool 30, bottom, 1/16 in. from pipe ID, 16 in. from vessel center				
TMB-40S16	Cold leg, Spool 40, discharge of simulated pump, vertical section, side, 1/16 in. from pipe ID, 60 in. from vessel center				
<u>Vessel Wall</u>	1/8 in. from vessel ID	0-2300°F	0-591°F	40, 41	
TMV-VI-35A	35 in. below cold leg centerline, 0°				
TMV-VI-177M	177 in. below cold leg centerline, 180°				
<u>Vessel Filler</u>	Type J iron-constantan thermocouples	0-1400°F	0-692°F		
TMV-FO-35A	35 in. below cold leg centerline, 0.65 in. from filler ID, 0°			42, 43	
TMV-FO-156A	156 in. below cold leg centerline, 0.65 in. from filler ID, 0°			42, 43	
TMV-FO-177M	177 in. below cold leg centerline, 0.65 in. from filler ID, 180°			42, 43	
TMV-FI-4M	4 in. below cold leg centerline, 1/16 in. from filler ID, 180°			44, 45	Thinness of filler at this location exposes thermocouple to fluid
TMV-FI-15A	15 in. below cold leg centerline, 1/16 in. from filler ID, 0°			44, 45	
TMV-FI-35A	35 in. below cold leg centerline, 1/16 in. from filler ID, 0°			44, 45	
TMV-FI-35M	35 in. below cold leg centerline, 1/16 in. from filler ID, 180°			44, 45	
TMV-FI-70A	70 in. below cold leg centerline, 1/16 in. from filler ID, 0°			46, 47	
TMV-FI-115A	115 in. below cold leg centerline, 1/16 in. from filler ID, 0°			46, 47	
TMV-FI-156A	156 in. below cold leg centerline, 1/16 in. from filler ID, 0°			46, 47	
TMV-FI-156M	156 in. below cold leg centerline, 1/16 in. from filler ID, 180°			46, 47	
TMV-FI-177M	177 in. below cold leg centerline, 1/16 in. from filler ID, 180°			46, 47	
<u>Vessel Filler Insulator</u>	Outer surface of insulator, Type J iron-constantan thermocouples	0-1400°F	0-692°F	48, 49	
TIV-FO-4A	4 in. below cold leg centerline, 0°				
TIV-FO-35A	35 in. below cold leg centerline, 0°				
TIV-FO-35M	35 in. below cold leg centerline, 180°				
TIV-FO-70A	70 in. below cold leg centerline, 0°				
TIV-FO-115A	115 in. below cold leg centerline, 0°				
TIV-FO-156A	156 in. below cold leg centerline, 0°				
<u>Lower Plenum</u>	Chromel-Alumel thermocouple	0-2300°F	0-591°F	50, 51	
TMV-LH	In vessel bottom head, 1/8 in. from inside surface, 2 in. from vessel centerline, 90°				
<u>Core Barrel</u>	Type J iron-constantan thermocouples	0-1400°F	0-692°F		
TMV-CO-4A	4 in. below cold leg centerline, in inlet annulus region, 1/16 in. from core barrel OD, 0°			52, 53	
TMV-CO-4M	4 in. below cold leg centerline, in inlet annulus region, 1/16 in. from core barrel OD, 180°			52, 53	
TMV-CO-15A	15 in. below cold leg centerline, 1/16 in. from core barrel OD, 0°			52, 53	
TMV-CO-70A	70 in. below cold leg centerline, 1/16 in. from core barrel OD, 0°			52, 53	

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments [a]	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
<u>Core Barrel (Contd.)</u>					
TMV-CO-115A	115 in. below cold leg centerline, 1/16 in. from core barrel OD, 0°			52, 53	
TMV-CO-115M	115 in. below cold leg centerline, 1/16 in. from core barrel OD, 180°			52, 53	
TMV-CI-70A	70 in. below cold leg centerline, 1/16 in. from core barrel ID, 0°			54, 55	
TMV CI 115A	115 in. below cold leg centerline, 1/16 in. from core barrel ID, 0°			54, 55	
<u>Steam Generator</u>		0-2300°F	0-591°F	56, 57	
TMU-SG1	On steam generator tubes, 12 in. above bottom of tube sheet, on OD of tube				
TMU-SG2	On steam generator tubes, 24 in. above bottom of tube sheet, on OD of tube				
TMU-SG3	On steam generator tubes, 48 in. above bottom of tube sheet, on OD of tube				
TMU-SG4	On steam generator tubes, 96 in. above bottom of tube sheet, on OD of tube				
<u>PRESSURE</u>					
<u>Intact Loop</u>		0-3000 psig	0-4000 psig		
PU-13(F)	Cold leg, Spool 13, 54 in. from vessel center (flush mount)				Data not digitized due to limited channel availability; data available from analog system
<u>Broken Loop</u>		0-3000 psig	0-4000 psig		
PB-23	Hot leg, Spool 23, 92 in. from vessel center, upstream of vessel-side nozzle (tee off DP tap)			58, 59	
PB-CN1	Vessel-side nozzle, nozzle throat, 96 in. from vessel center, (tee off DP tap)			58, 59	
PB-RUPC	Vessel side of break, between rupture discs				Data not available due to loss of time correlation signal
PB-42	Hot leg, Spool 42, 414 in. from vessel center along cold leg, upstream of pump-side nozzle (tee off DP tap)			60, 61	
PB-HN1	Pump-side nozzle, nozzle throat, 418 in. from vessel center along cold leg (tee off DP tap)			60, 61	
PB-RUPH	Pump side of break, between rupture discs				Data not available due to loss of time correlation signal
<u>Vessel</u>		0-3000 psig	0-4000 psig	62, 63	
PV-UP+10	In upper plenum, 10 in. above cold leg centerline, mounted on standoff, 30°				
PV-LP-180	In upper part of lower plenum, 180 in. below cold leg centerline, mounted on standoff, 225°				
PV-IANN-9	In vessel inlet annulus, 9 in. below cold leg centerline, mounted on standoff, 225°				
<u>ECC System</u>		0-750 psig	0-750 psig	64, 255	Pressure decrease at t=3 sec caused by automatic opening of accumulator valve prior to ECC injection
PECC-UL-ACC	In intact loop accumulator				
<u>Pressurizer</u>		0-3000 psig	0-4000 psig	65, 66	
PU-PRIZE	Steam dome				
<u>Pressure Suppression System</u>		0-100 psig	0-100 psig	67, 68, 256	
P-PSS	Suppression tank top				

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments [a]	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
DIFFERENTIAL PRESSURE	Elevation difference between transducer taps is zero unless otherwise specified				
<u>Intact Loop</u>					
DPU-UP-1	Upper plenum 10.5 in. above cold leg centerline at 30° to hot leg, Spool 1, 31 in. from vessel center, upper plenum tap approximately 2 in. above Spool 1 tap	+50 in. water	+2.5 psid		Data not valid; faulty detector calibration
DPU-UP-3	Upper plenum 10.5 in. above cold leg centerline at 30° to hot leg, Spool 3, 62 in. from vessel center, upper plenum tap approximately 2 in. above Spool 3 tap	+300 in. water	+15 psid	69, 70	
DPU-3-7	Across steam generator, hot leg, Spool 3, 62 in. from vessel center to cold leg Spool 7, 231 in. from vessel center, Spool 3 tap approximately 18 in. above Spool 7 tap	+500 in. water	+25 psid	71, 72	
DPU-3-7L	Across steam generator, hot leg, Spool 3, 62 in. from vessel center to cold leg Spool 7, 231 in. from vessel center, Spool 3 tap approximately 18 in. above Spool 7 tap (low range)	+50 in. water	+2.5 psid	73, 74	
DPU-3-SGIP	Across inlet orifice of steam generator, hot leg, Spool 3, 62 in. from vessel center to steam generator inlet plenum, 145 in. from vessel center, Spool 3 tap is 16 in. below SGIP tap	+500 in. water	+25 psid		Data not valid; faulty detector calibration
DPU-6-SGIP	Hot leg, Spool 6, 114 in. from vessel center to steam generator inlet plenum, 145 in. from vessel center, Spool 6 tap is 16 in. below SGIP tap	+800 in. water	+40 psid	75, 76	
DPU-SG1-SG2	Across primary side tubes, 12 to 24 in. above bottom of tube sheet, SG1 tap is 12 in. below SG2 tap	+20 in. water	+1.0 psid	77, 78	Data doubtful; cell sense lines have potential for draining
DPU-SGOP-7	From steam generator outlet plenum, 269 in. from vessel center along cold leg to cold leg Spool 7, 231 in. from vessel center, including orifice, Spool 7 tap is 35 in. below SGOP tap	+500 in. water	+25 psid	79, 80	
DPU-7-10	Steam generator outlet to pump inlet, cold leg Spool 7, 231 in. from vessel center to cold leg Spool 10, 141 in. from vessel center	+50 in. water	+2.5 psid	81, 82	
DPU-8C-8D	In pump trap, cold leg Spool 8, Tap 8C, 197 in. from vessel center to Tap 8D, 184 in. from vessel center, Tap 8C is 10 in. below Tap 8D	+20 in. water	+1.0 psid	83, 84	Data suspect due to questionable calibration
DPU-8D-8E	In pump trap, cold leg Spool 8, Tap 8D, 184 in. from vessel center to Tap 8E, 174 in. from vessel center, Tap 8D is 10 in. below Tap 8E	+20 in. water	+1.0 psid	85, 86	Data suspect due to questionable calibration
DPU-12-10	Pump outlet to pump inlet, cold leg Spool 12, 75 in. from vessel center to cold leg Spool 10, 141 in. from vessel center, Spool 10 tap is 10 in. below Spool 12 tap	+50 psid	+50 psid	87, 88	
DPU-12-10L	Pump outlet to pump inlet, cold leg Spool 12, 75 in. from vessel center to cold leg Spool 10, 141 in. from vessel center, Spool 10 tap is 10 in. below Spool 12 tap (low range)	+100 in. water	+5.0 psid	89, 90	
DPU-12-15	Across cold leg injection point, cold leg Spool 12, 75 in. from vessel center to cold leg Spool 15, 16 in. from vessel center	+100 in. water	+5.0 psid	91, 92	Prerupture measured differential pressure is greater than expected from flow calibrations prior to test series
DPU-15-1	Cold leg to hot leg, cold leg Spool 15, 16 in. from vessel center to hot leg Spool 1, 31 in. from vessel center, Spool 15 tap is 8.5 in. below Spool 1 tap	+500 in. water	+25 psid	93, 94	
DPU-15-1L	Cold leg to hot leg, cold leg Spool 15, 16 in. from vessel center to hot leg Spool 1, 31 in. from vessel center, Spool 15 tap is 8.5 in. below Spool 1 tap (low range)	+50 in. water	+2.5 psid	95, 96	Detector range exceeded and data acquisition system saturated at various times during test

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments ^[a]	Range ^[a]		Figure ^[a]	Measurement Comments ^[b]
		Detector	Data Acquisition System		
<u>Intact Loop (Contd.)</u>					
DPU-15-IANN	Cold leg Spool 15, 16 in. from vessel center to inlet annulus 9 in. below cold leg centerline at 225°, Spool 15 tap is 9 in. above inlet annulus tap	+100 in. water	+5.0 psid	97, 98	Detector range exceeded at t=50 sec
DPU-15-ATM	Cold leg Spool 15, 16 in. from vessel center to atmosphere	+500 psid	+500 psid	99, 257	Data acquisition system saturated until t=34 sec
DPU-PRESLL	Pressurizer water level, elevation difference between taps is 34 in., lower tap is approximately 3.5 in. above pressurizer exit	+50 in. water	+2.5 psid	100, 101, 258	Measured liquid level resulted in a liquid volume at blowdown of 0.67 ft ³
<u>Broken Loop</u>					
DPB-UP-21A	Upper plenum 10.5 in. above cold leg centerline at 30° to hot leg Spool 21A, 48 in. from vessel center, upper plenum tap is approximately 2 in. above Spool 21A tap	+100 in. water	+5.0 psid	102, 103	
DPB-21A-23	Hot leg Spool 21A, 48 in. from vessel center to hot leg Spool 23, 92 in. from vessel center	+800 in. water	+40 psid	104, 105	
DPB-23-CN1	Hot leg Spool 23, 92 in. from vessel center to vessel-side nozzle throat, 96 in. from vessel center	+500 psid	+500 psid	106, 107	
DPB-CN1-CN4	Vessel-side nozzle, nozzle throat, 96 in. from vessel center to nozzle divergent section, 101 in. from vessel center	+1000 psid	+1300 psid	108, 109	Data have an apparent 15 psid drift by 110 sec; detector should measure 0 psid for no flow
DPB-23-24	Across vessel-side nozzle, Spool 23, 92 in. from vessel center to Spool 24, 103 in. from vessel center	+1000 psid	+1300 psid	110, 111	
DPB-IANN-30	Vessel inlet annulus 9 in. below cold leg centerline at 225° to cold leg Spool 30, 18 in. from vessel center, inlet annulus tap is approximately 8 in. below Spool 30 tap	+100 in. water	+5.0 psid	112, 113	
DPB-30-40	Cold leg Spool 30, 18 in. from vessel center to cold leg Spool 40, 63 in. from vessel center, Spool 30 is 31 in. above Spool 40 tap	+100 psid	+100 psid	114, 115	
DPB-40-38	Across simulated pump, cold leg Spool 40, 63 in. from vessel center to cold leg Spool 38, 123 in. from vessel center	+500 psid	+500 psid	116, 117	
DPB-40-38L	Across simulated pump, cold leg Spool 40, 63 in. from vessel center to cold leg Spool 38, 123 in. from vessel center (low range)	+500 in. water	+25 psid	118	Data acquisition system saturated until t=47 sec and from t=53 sec to t=60 sec
DPB-38-36U	Cold leg Spool 38, 123 in. from vessel center to cold leg Spool 36, upper tap 196 in. from vessel center, Spool 38 tap is 70 in. lower than Spool 36 upper tap	+500 in. water	+25 psid	119, 120	
DPB-37-36U	Cold leg Spool 37, 146 in. from vessel center to cold leg Spool 36 upper tap 196 in. from vessel center, Spool 37 tap is 47 in. below Spool 36 upper tap	+50 psid	+50 psid	121, 122	Data questionable after t=45 sec
DPB-37-42	Across simulated steam generator assembly, cold leg Spool 37, 146 in. from vessel center to hot leg Spool 42, 414 in. from vessel center along cold leg, Spool 37 is approximately 7 in. below Spool 42 tap	+100 psid	+100 psid	123, 124	Data have an apparent 2.7 psid drift by 110 sec; detector should measure 0.22 psid for empty system with no flow
DPB-36U-32L	Across simulated steam generator assembly; cold leg Spool 36 upper tap 196 in. from vessel center to hot leg Spool 32 lower tap 365 in. from vessel center along cold leg, Spool 36 upper tap is 10 in. above Spool 32 lower tap	+50 psid	+50 psid	125, 126	
DPB-42-43	Across pump-side nozzle, cold leg Spool 42, 414 in. from vessel center along cold leg to cold leg Spool 43, 426 in. from vessel center along cold leg	+1000 psid	+1300 psid	127, 128	
DPB-42-HN1	Spool 42 upstream of pump-side nozzle, 414 in. from vessel center along hot leg to nozzle throat, 418 in. from vessel center along cold leg	+500 psid	+500 psid	129, 130	Data have an apparent 8 psid drift by 110 sec; detector should measure 0 psid for empty system with no flow

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

		Range [a]			
Measurement	Location and Comments [a]	Detector	Data Acquisition System	Figure [a]	Measurement Comments [b]
Broken Loop (Contd.)					
DPB-HN1-HN4	Pump-side nozzle, nozzle throat, 418 in. from vessel center along cold leg to nozzle divergent section, 423 in. from vessel center along cold leg	+1000 psid	+1300 psid	131, 132	Data have an apparent -15 psid drift by 110 sec; detector should measure 0 psid for empty system with no flow
DPB-HN4-43	Pump-side nozzle, divergent section, 423 in. from vessel center along cold leg to downstream Spool 43, 426 in. from vessel center along cold leg	+50 psid	+50 psid	133, 134	
Vessel					
DPU-15-IANN	Intact loop cold leg Spool 15, 16 in. from vessel center to inlet annulus 9 in. below cold leg centerline at 225°, Spool 15 tap is 9 in. above inlet annulus tap	+100 in. water	+5.0 psid	97, 98	Detector range exceeded at t=50 sec
DPB-UP-21A	Upper plenum 10.5 in. above cold leg centerline at 30° to hot leg Spool 21A, 48 in. from vessel center, upper plenum tap is approximately 2 in. above Spool 21A tap	+100 in. water	+5.0 psid	102, 103	
DPV-UP-IANN	Upper plenum, 10.5 in. above cold leg centerline at 30° to inlet annulus, 9 in. below cold leg centerline at 225°, elevation difference between taps is 19 in.	+300 in. water	+15 psid	135, 136	
DPV-O-9GQ	Inlet annulus cold leg centerline at 90° to 9 in. below cold leg centerline at 225°, elevation difference between taps is 9 in.	+20 in. water	+1.0 psid		Data not valid; leaking manifold common to differential pressure cells at 9 in. below cold leg centerline
DPV-9-26QQ	Inlet annulus, 9 in. below cold leg centerline at 225° to downcomer gap approximately 26 in. below cold leg centerline at 225°, elevation difference between taps is 17 in.	+50 in. water	+2.5 psid	137, 138	Data questionable; leaking manifold common to differential pressure cells at 9 in. below cold leg centerline
DPV-9-180QQ	Inlet annulus, 9 in. below cold leg centerline at 225° to lower plenum, 180 in. below cold leg centerline at 225°, elevation difference between taps is 171 in.	+300 in. water	+15 psid		Data not valid; leaking manifold common to differential pressure cells at 9 in. and 180 in. below cold leg centerline
DPV-26-55QM	Across part of downcomer, 26 in. (225°) to 55 in. (180°) below centerline of cold leg, elevation difference between taps is 29 in.	+50 in. water	+2.5 psid	139, 140	
DPV-55-110AM	Across part of downcomer, 55 in. (0°) to 110 in. (180°) below cold leg centerline, elevation difference between taps is 55 in.	+100 in. water	+5.0 psid	141, 142	
DPV-110-156MQ	Across part of downcomer, 110 in. (180°) to 156 in. (225°) below cold leg centerline, elevation difference between taps is 46 in.	+100 in. water	+5.0 psid		Detector failed
DPV-156-173QQ	Across downcomer exit, 7 in. above exit to 10 in. below exit, taps at 156 in. (225°) and 173 in. (225°) below cold leg centerline, elevation difference between taps is 17 in.	+20 in. water	+1.0 psid	143, 144	Data suspect due to questionable calibration
DPV-166-173QQ	Across part of lower plenum, 166 in. (225°) to 173 in. (225°) below cold leg centerline, elevation difference between taps is 7 in.	+20 in. water	+1.0 psid	145, 146	Data suspect due to questionable calibration
DPV-173-180QQ	Across part of lower plenum, 173 in. (225°) to 180 in. (225°) below cold leg centerline, elevation difference between taps is 7 in.	+20 in. water	+1.0 psid		Data not valid; leaking manifold common to differential pressure cells at 180 in. below cold leg centerline
DPV-180-191QT	Across part of lower plenum, 180 in. (225°) to 191 in. (270°) below cold leg centerline, elevation difference between taps is 11 in.	+20 in. water	+1.0 psid		Data not valid; leaking manifold common to differential pressure cells at 180 in. below cold leg centerline
DPV-166-191QT	Across lower plenum, 166 in. (225°) to 191 in. (270°) below cold leg centerline, elevation difference between taps is 25 in.	+50 in. water	+2.5 psid	147, 148	
DPV-LP-UP	Lower plenum, 180 in. below cold leg centerline at 225° to upper plenum 10.5 in. above cold leg centerline at 30°, elevation difference between taps is 191 in.	+300 in. water	+15 psid	149, 150, 259	Data questionable; leaking manifold common to differential pressure cells at 180 in. below cold leg centerline

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
<u>Vessel (Contd.)</u>					
DPU-UP-1	Upper plenum, 10.5 in. above cold leg centerline at 30° to intact loop hot leg Spool 1, 31 in. from vessel center, upper plenum tap is approximately 2 in. above Spool 1 tap	+50 in. water	+2.5 psid		Data not valid; faulty detector calibration
DPU-UP-3	Vessel upper plenum, 10.5 in. above cold leg centerline at 30° to intact loop hot leg Spool 3, 62 in. from vessel center, upper plenum tap is approximately 2 in. above Spool 3 tap	+300 in. water	+15 psid	69, 70	
DPB-IANN-30	Vessel inlet annulus 9 in. below cold leg centerline at 225° to cold leg Spool 30, 18 in. from vessel center, inlet annulus tap is approximately 8 in. below Spool 30 tap	+100 in. water	+5.0 psid	112, 113	
<u>Steam Generator</u>					
DPU-3-SGIP	Across inlet orifice, hot leg Spool 3, 62 in. from vessel center to steam generator inlet plenum, 145 in. from vessel center, Spool 3 tap is 16 in. below SGIP tap	+500 in. water	+25 psid		Data not valid; fault detector calibration
DPU-6-SGIP	Hot leg Spool 6, 114 in. from vessel center to steam generator inlet plenum, 145 in. from vessel center, Spool 6 tap is 16 in. below SGIP tap	+800 in. water	+40 psid	75, 76	
DPU-SG1-SG2	Across primary side tubes, 12 to 24 in. above bottom of tube sheet, SG1 tap is 12 in. below SG2 tap	+20 in. water	+1.0 psid	77, 78	Data doubtful; cell sense lines have potential for draining
DPU-SGOP-7	From steam generator outlet plenum, 269 in. from vessel center along cold leg to cold leg Spool 7, 231 in. from vessel center, including orifice, Spool 7 tap is 35 in. below SGOP tap	+500 in. water	+25 psid	79, 80	
DPU-SG-SEC	Secondary side, differential pressure taps at 45 and 126 in. above bottom of tube sheet, elevation difference between taps is 81 in.	+100 in. water	+5.0 psid	151, 152	Secondary wide liquid level calculated from this measurement is 112 in.
<u>Pressurizer</u>					
DPU-PRESLL	Pressurizer water level, elevation difference between taps is 34 in., lower tap is approximately 3.5 in. above pressurizer exit	+50 in. water	+2.5 psid	100, 101, 258	Measured liquid level resulted in liquid volume at blowdown of 0.67 ft ³
<u>VOLUMETRIC FLOW RATE</u>					
<u>Intact Loop</u>					
FTU-1	Hot leg, Spool 1, 18 in. from vessel center	+20-400 gpm	+655 gpm	153, 154	Detector range exceeded and data acquisition system saturated at various times during test
FTU-9	Cold leg, Spool 9, 154 in. from vessel center	+20-400 gpm	+649 gpm	153, 154	Detector range exceeded and data acquisition system saturated at various times during test
FTU-13	Cold leg, Spool 13, 64 in. from vessel center	+20-400 gpm	+640 gpm	155, 156	Data questionable from t=20 to t=26 sec and from t=60 to t=77 sec. Detector range exceeded and data acquisition system saturated at various times during test
FTU-15	Cold leg, Spool 15, 29 in. from vessel center	+10-200 gpm	+389 gpm	155, 156	Detector range exceeded after t=104 sec
<u>Broken Loop</u>					
All measurements bidirectional, Schedule 160 pipe					
FTB-21A	Hot leg, Spool 21A, 57 in. from vessel center, 3-in. pipe	+20-400 gpm	+847 gpm		Data acquisition system saturated at various times during test
FTB-30	Cold leg, Spool 30, 24 in. from vessel center, 3-in. pipe	+20-400 gpm	+408 gpm		
FTB-37	Cold leg, Spool 37, 138 in. from vessel center, 2-in. pipe	+10-200 gpm	+647 gpm		Detector range exceeded from t=26 to t=43 sec. Erratic data prior to rupture caused by electronic interference with detector during heatup bypass valve closure
<u>Core</u>					
FTV-CORE-IN	Entrance to core, approximately 158 in. below cold leg centerline	+20-400 gpm	+405 gpm	159, 160, 260	
FTV-LOFT-COR	In LOFT core simulator, 14 in. below cold leg centerline (LOFT drag-disc, turbine flowmeter combination)				Experimental detector; data not processed for this report

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments [a]	Range [a]		Figure [a]	Measurement Comments [b]
		Detector	Data Acquisition System		
<u>ECC System</u>					
FTU-HPIS	In line immediately after HPIS pump for intact loop, 1/2-in. line	0.1-1.0 gpm	1.0 gpm	161	Data spike at t=3 sec caused by automatic opening of accumulator valve in common ECC line prior to accumulator ECC injection
FTU-LPIS	In line leading from LPIS for intact loop, 1/2-in. line	0.5-10 gpm	10 gpm	162	
FTU-ACC	In line immediately after intact loop accumulator, 1-in. line	4-75 gpm	75 gpm	163, 261	Data spike at t=3 sec caused by automatic opening of accumulator valve prior to ECC injection
<u>Pressurizer</u>	1-1/2-in. turbine	5-100 gpm	111 gpm	164, 165	
FTU-PRIZE	Surge line				
PRESSURE SUPPRESSION SYSTEM		+0.5-10 gpm	10 gpm	262	
FTPSS-SPRAY	1-1/2-in. line from accumulator for suppression tank spray				
FLUID VELOCITY					
Turbine flowmeter, bidirectional					
<u>Downcomer Gap</u>					
FTV-22M	22 in. below cold leg centerline, 180°	+2.5-50 ft/sec	+50.4 ft/sec	166, 167	
FTV-40A	40 in. below cold leg centerline, 0°	+2.5-50 ft/sec	+50.4 ft/sec	168, 169	Zero reading prior to rupture caused by sticking turbine bearing. Detector should have measured a positive velocity prior to test
FTV-40M	40 in. below cold leg centerline, 180°	+2.5-50 ft/sec	+50.4 ft/sec	170, 171	
FTV-83A	83 in. below cold leg centerline, 0°	+1.8-36 ft/sec	+36 ft/sec	172, 173	
FTV-83M	83 in. below cold leg centerline, 180°	+1.8-36 ft/sec	+36 ft/sec	174, 175	
FTV-130M	130 in. below cold leg centerline, 180°	+0.9-18 ft/sec	+18 ft/sec		Detector failed
FTV-161M	161 in. below cold leg centerline, 180°	+0.9-18 ft/sec	+18 ft/sec		Detector failed
MOMENTUM FLUX					
Drag-disc bidirectional. Computer conversion of voltage output to momentum flux is unidirectional and therefore shows magnitude only.					
<u>Intact Loop</u>					
3-in. pipe					
FDU-1	Hot leg, Spool 1, 29 in. from vessel center, target size 0.875	+250-11,500 lb _m /ft-sec ²	+15,000 lb _m /ft-sec ²	176, 177	
FDU-5	Hot leg, Spool 5, 100 in. from vessel center, target size 1.0	+1-2000 lb _m /ft-sec ²	+2000 lb _m /ft-sec ²	178, 179	
FDU-10	Cold leg, Spool 10, 137 in. from vessel center, target size 0.875	+200-204,000 lb _m /ft-sec ²	+130,000 lb _m /ft-sec ²	180, 181	
FDU-13	Cold leg, Spool 13, 54 in. from vessel center, target size 0.875	+200-11,000 lb _m /ft-sec ²	+14,800 lb _m /ft-sec ²	182, 183	
FDU-15	Cold leg, Spool 15, 19 in. from vessel center, target size 0.875	+200-11,600 lb _m /ft-sec ²	+15,500 lb _m /ft-sec ²	184, 185	
<u>Broken Loop</u>					
FDB-21A	Hot leg, Spool 21A, 52 in. from vessel center, 3-in. pipe, target size 4.06	+200-70,500 lb _m /ft-sec ²	+94,000 lb _m /ft-sec ²	186, 187	
FDB-23	Hot leg, Spool 23, 93 in. from vessel center, upstream of vessel-side nozzle, downstream of injection point, 1.5 in. pipe, target size 0.406	+200-125,000 lb _m /ft-sec ²	+167,000 lb _m /ft-sec ²	188, 189	
FDB-30	Cold leg, Spool 30, 20 in. from vessel center, 3-in. pipe, target size 0.656	+200-60,000 lb _m /ft-sec ²	+80,000 lb _m /ft-sec ²		Range of detector causes insensitivity to flow at this location
FDB-37	Cold leg, Spool 37, 143 in. from vessel center, steam generator outlet vertical pipe, 2-in. pipe, target size 0.406	+200-131,000 lb _m /ft-sec ²	+175,000 lb _m /ft-sec ²	190, 191	
FDB-42	Hot leg, Spool 42, 416 in. from vessel center along cold leg, upstream of pump-side nozzle, downstream of injection point, 1.5-in. pipe, target size 0.406	+200-116,000 lb _m /ft-sec ²	+155,000 lb _m /ft-sec ²	192, 193	

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments ^[a]	Range ^[a]		Figure ^[a]	Measurement Comments ^[b]
		Detector	Data Acquisition System		
<u>Vessel</u>					
FDV-CORE-IN	In core flow mixer box, 150 in. below cold leg centerline, target size 1.0	+100-1000 lb _m /ft-sec ²	+1000 lb _m /ft-sec ²	194, 195, 263	
FDV-LOFT-COR	In LOFT core simulator, 14 in. below cold leg centerline (LOFT drag-disc, turbine flowmeter combination) target size 0.500 in.				Experimental detector; data not processed for this report
<u>DENSITY</u>					
<u>Intact Loop</u>		0.1-100 lb _m /ft ³	0-100 lb _m /ft ³		
GU-1VR	Hot leg, Spool 1, 24 in. from vessel center, vertical			196, 197	
GU-1HZ	Hot leg, Spool 1, 26 in. from vessel center, horizontal			196, 197	
GU-5VR	Hot leg, Spool 5, 96 in. from vessel center, vertical			198, 199	
GU-10VR	Cold leg, Spool 10, 141 in. from vessel center, vertical			198, 199	
GU-13VR	Cold leg, Spool 13, 59 in. from vessel center, vertical			200, 201	
GU-15HZ	Cold leg, Spool 15, 20 in. from vessel center, horizontal			202, 203	
GU-15VR	Cold leg, Spool 15, 23 in. from vessel center, vertical			202, 203	
<u>Broken Loop</u>		0.1-100 lb _m /ft-sec ²	0-100 lb _m /ft-sec ²		
GB-21AVR	Hot leg, Spool 21A, 48 in. from vessel center, vertical			204, 205	
GB-23VR	Hot leg, Spool 23, 92 in. from vessel center, vertical			204, 205	
GB-30VR	Cold leg, Spool 30, 18 in. from vessel center, vertical			206, 207, 264	
GB-42VR	Cold leg, Spool 42, 414 in. from vessel center along cold leg, vertical			206, 207	
<u>Vessel</u>					
		0.1-100 lb _m /ft-sec ²	0-100 lb _m /ft-sec ²		
GV-COR-150HZ	Core flow mixer box, 152 in. below cold leg centerline, horizontal, 0-180°			208, 209, 265	
GV-161/192D	Lower plenum 161 in. below cold leg centerline (270°) to 192 in. below cold leg centerline (90°), 31 in. vertical 32.2 in. diagonal			208, 209, 265	Due to instrument resolution limitation data are inaccurate outside selected limits of 15 lb _m /ft ³ and 45 lb _m /ft ³
GVLP-172HZ	Lower plenum, 172 in. below cold leg centerline, 8.729 in. below downcomer exit, horizontal, 90-270°			210, 211	
<u>Pressurizer</u>		0.1-100 lb _m /ft-sec ²	0-100 lb _m /ft-sec ²	212, 213	
GU-PRIZE	Surge line				
<u>LIQUID LEVEL</u>					
<u>Steam Generator</u>					
DPU-SG-SEC	Secondary side, differential pressure taps at 45 and 126 in. above tube sheet, elevation difference between taps is 81 in.	+100 in. water	+5.0 psid	151, 152	Secondary side liquid level calculated from this measurement is 112 in.
<u>Pressurizer</u>					
DPU-PRESLL	Pressurizer water level, elevation difference between taps is 34 in., lower tap is approximately 3.5 in. above pressurizer exit	+50 in. water	+2.5 psid	100, 101, 258	Liquid level results in liquid volume at blowdown of 0.67 ft ³

TABLE V (Contd.)

DATA PRESENTATION FOR SEMISCALE MOD-1 TEST S-01-1B

Measurement	Location and Comments ^[a]	Range ^[a]		Figure ^[a]	Measurement Comments ^[b]
		Detector	Data Acquisition System		
MASS FLOW RATE	Mass flow rate obtained by combining density (gamma attenuation technique) with volumetric flow rate (turbine flowmeter) or momentum flux (drag disc)	0.1-100 lb _m /ft ³	0.1-100 lb _m /ft ³		
<u>Intact Loop</u>					
FDU-1 GU-1VR	Hot leg, Spool 1			214, 215	Data questionable from t=20 to t=26 sec and from t=66 to t=72 sec
FTU-1 GU-1VR				216, 217	
FTU-PRIZE and GU-PRIZE	Pressurizer surge line			218, 219	
FDU-5 GU-5VR	Hot leg, Spool 5			220, 221	
FDU-10 GU-10VR	Cold leg, Spool 10			222, 223	
FDU-13 GU-13VR	Cold leg, Spool 13			224, 225	
FTU-13 GU-13VR				226, 227	
FDU-15 GU-15VR	Cold leg, Spool 15			228, 229	
FTU-15 GU-15VR				230, 231	
<u>Broken Loop</u>					
FDB-21A GB-21AVR	Hot leg, Spool 21			232, 233	
FTB-21A GB-21AVR				234, 235	
FDB-23 GB-23VR	Hot leg, Spool 23			236, 237	
FTB-30 GB-30VR	Cold leg, Spool 30			238, 239	
FDB-42 GB-42VR	Hot leg, Spool 42			240, 241	
<u>Vessel</u>					
FTV-CORE-IN GV-COR-150HZ	Entrance to core			242, 243	
FDV-CORE-IN GV-COR-150HZ	Entrance to core			244, 245	
<u>PUMP CHARACTERISTICS</u>					
PUMPU-TORQ	Pump torque	0-500 in.-lb	0-500 in.-lb	246, 247	Data not valid after t=90 sec
PUMPU-POW	Pump motor power		0-24.2 kW	248, 249	
PUMPU-RPM	Pump speed	0-3600 rpm	0-3600 rpm	250, 251	

[a] Statements at the beginning of a measurement category regarding location and comments, range, and figure apply to all subsequent measurements within the given category unless specified otherwise.

[b] Detectors which were subjected to overrange conditions during portions of the test were capable of withstanding these conditions without change in operating or measuring characteristics when the physical conditions were again within the detector range.

Fig. 6 Fluid temperatures in intact loop (RBU-2, TFU-5, TSU-7, TFU-10, and TFU-15) from -2 to 110 seconds.

Fig. 7 Fluid temperatures in intact loop (RBU-2, TFU-5, TSU-7, TFU-10, and TFU-15) from -2 to 30 seconds.

Fig. 8 Fluid temperatures in intact loop (RBU-14A and TFU-14B) from -2 to 110 seconds.

Fig. 9 Fluid temperatures in intact loop (RBU-14A and TFU-14B) from -2 to 30 seconds.

Fig. 10 Fluid temperatures in broken loop from -2 to 110 seconds.

Fig. 11 Fluid temperatures in broken loop from -2 to 30 seconds.

Fig. 12 Fluid temperatures in inlet annulus from -2 to 110 seconds.

Fig. 13 Fluid temperatures in inlet annulus from -2 to 30 seconds.

Fig. 14 Fluid temperatures in downcomer annulus (TFV-ANN-15A, TFV-ANN-15M, and TFV-ANN-15T) from -2 to 110 seconds.

Fig. 15 Fluid temperatures in downcomer annulus (TFV-ANN-15A, TFV-ANN-15M, and TFV-ANN-15T) from -2 to 30 seconds.

Fig. 16 Fluid temperatures in downcomer annulus (TFV-ANN-35A, TFV-ANN-35M, and TFV-ANN-35T) from -2 to 110 seconds.

Fig. 17 Fluid temperatures in downcomer annulus (TFV-ANN-35A, TFV-ANN-35M, and TFV-ANN-35T) from -2 to 30 seconds.

Fig. 18 Fluid temperatures in downcomer annulus (TFV-ANN-115A and TFV-ANN-156A) from -2 to 110 seconds.

Fig. 19 Fluid temperatures in downcomer annulus (TFV-ANN-115A and TFV-ANN-156A) from -2 to 30 seconds.

Fig. 20 Fluid temperatures in lower plenum from -2 to 110 seconds.

Fig. 21 Fluid temperatures in lower plenum from -2 to 30 seconds.

Fig. 22 Fluid temperatures in core (LOFT) from -2 to 110 seconds.

Fig. 23 Fluid temperatures in core (LOFT) from -2 to 30 seconds.

Fig. 24 Fluid temperatures in core barrel insulation gap from -2 to 110 seconds.

Fig. 25 Fluid temperatures in core barrel insulation gap from -2 to 30 seconds.

Fig. 26 Fluid temperatures in vessel filler insulation gap from -2 to 110 seconds.

Fig. 27 Fluid temperatures in vessel filler insulation gap from -2 to 30 seconds.

Fig. 28 Fluid temperatures in steam generator from -2 to 110 seconds.

Fig. 29 Fluid temperatures in steam generator from -2 to 30 seconds.

Fig. 30 Fluid temperature in pressurizer surge line from -2 to 110 seconds.

Fig. 31 Fluid temperature in pressurizer surge line from -2 to 30 seconds.

Fig. 32 Fluid temperatures in pressure suppression tank from -2 to 110 seconds.

Fig. 33 Fluid temperatures in pressure suppression tank from -2 to 30 seconds.

Fig. 34 Material temperatures in intact loop (TMU-1T16, TMU-1S16, TMU-1B16, TMU-5B16, and TMU-7S16) from -2 to 110 seconds.

Fig. 35 Material temperatures in intact loop (TMU-1T16, TMU-1S16, TMU-1B16, TMU-5B16, and TMU-7S16) from -2 to 30 seconds.

Fig. 36 Material temperatures in intact loop (TMU-8S16, TMU-10S16, TMU-15T16, and TMU-15B16) from -2 to 110 seconds.

Fig. 37 Material temperatures in intact loop (TMU-8S16, TMU-10S16, TMU-15T16, and TMU-15B16) from -2 to 30 seconds.

Fig. 38 Material temperatures in broken loop from -2 to 110 seconds.

Fig. 39 Material temperatures in broken loop from -2 to 30 seconds.

Fig. 40 Material temperatures in vessel wall from -2 to 110 seconds.

Fig. 41 Material temperatures in vessel wall from -2 to 30 seconds.

Fig. 42 Material temperatures in vessel filler outside diameter from -2 to 110 seconds.

Fig. 43 Material temperatures in vessel filler outside diameter from -2 to 30 seconds.

Fig. 44 Material temperatures in vessel filler inside diameter (TMV-FI-4M, TMV-FI-15A, TMV-FI-35A, and TMV-FI-35M) from -2 to 110 seconds.

Fig. 45 Material temperatures in vessel filler inside diameter (TMV-FI-4M, TMV-FI-15A, TMV-FI-35A, and TMV-FI-35M) from -2 to 30 seconds.

Fig. 46 Material temperatures in vessel filler inside diameter (TMV-FI-70A, TMV-FI-115A, TMV-FI-156A, TMV-FI-156M, and TMV-FI-177M) from -2 to 110 seconds.

Fig. 47 Material temperatures in vessel filler inside diameter (TMV-FI-70A, TMV-FI-115A, TMV-FI-156A, TMV-FI-156M, and TMV-FI-177M) from -2 to 30 seconds.

Fig. 48 Material temperatures in vessel filler insulator from -2 to 110 seconds.

Fig. 49 Material temperatures in vessel filler insulator from -2 to 30 seconds.

Fig. 50 Material temperature in vessel lower head from -2 to 110 seconds.

Fig. 51 Material temperature in vessel lower head from -2 to 30 seconds.

Fig. 52 Material temperatures in core barrel outside diameter (TMV-CO-4A, TMV-CO-4M, TMV-CO-15A, TMV-CO-70A, TMV-CO-115A, and TMV-CO-115M) from -2 to 110 seconds.

Fig. 53 Material temperatures in core barrel outside diameter (TMV-CO-4A, TMV-CO-4M, TMV-CO-15A, TMV-CO-70A, TMV-CO-115A, and TMV-CO-115M) from -2 to 30 seconds.

Fig. 54 Material temperatures in core barrel inside diameter (TMV-CI-70A and TMV-CI-115A) from -2 to 110 seconds.

Fig. 55 Material temperatures in core barrel inside diameter (TMV-CI-70A and TMV-CI-115A) from -2 to 30 seconds.

Fig. 56 Material temperatures in steam generator from -2 to 110 seconds.

Fig. 57 Material temperatures in steam generator from -2 to 30 seconds.

Fig. 58 Pressures in vessel side of broken loop from -2 to 110 seconds.

Fig. 59 Pressures in vessel side of broken loop from -2 to 30 seconds.

Fig. 60 Pressures in pump side of broken loop from -2 to 110 seconds.

Fig. 61 Pressures in pump side of broken loop from -2 to 30 seconds.

Fig. 62 Pressures in vessel from -2 to 110 seconds.

Fig. 63 Pressures in vessel from -2 to 30 seconds.

Fig. 64 Pressure in intact loop ECC accumulator from -2 to 110 seconds.

Fig. 65 Pressure in pressurizer from -2 to 110 seconds.

Fig. 66 Pressure in pressurizer from -2 to 30 seconds.

Fig. 67 Pressure in pressure suppression tank from -2 to 110 seconds.

Fig. 68 Pressure in pressure suppression tank from -2 to 30 seconds.

Fig. 69 Differential pressure in intact loop (upper plenum to Spool 3) from -2 to 110 seconds.

Fig. 70 Differential pressure in intact loop (upper plenum to Spool 3) from -2 to 30 seconds.

Fig. 71 Differential pressure in intact loop (Spool 3 to Spool 7) from -2 to 110 seconds.

Fig. 72 Differential pressure in intact loop (Spool 3 to Spool 7) from -2 to 30 seconds.

Fig. 73 Differential pressure in intact loop, low range (Spool 3 to Spool 7) from -2 to 110 seconds.

Fig. 74 Differential pressure in intact loop, low range (Spool 3 to Spool 7) from -2 to 30 seconds.

Fig. 75 Differential pressure in intact loop (Spool 6 to steam generator inlet plenum) from -2 to 110 seconds.

Fig. 76 Differential pressure in intact loop (Spool 6 to steam generator inlet plenum) from -2 to 30 seconds.

Fig. 77 Differential pressure in intact loop (SG1 to SG2) from -2 to 110 seconds.

Fig. 78 Differential pressure in intact loop (SG1 to SG2) from -2 to 30 seconds.

Fig. 79 Differential pressure in intact loop (steam generator outlet plenum to Spool 7) from -2 to 110 seconds.

Fig. 80 Differential pressure in intact loop (steam generator outlet plenum to Spool 7) from -2 to 30 seconds.

Fig. 81 Differential pressure in intact loop (Spool 7 to Spool 10) from -2 to 110 seconds.

Fig. 82 Differential pressure in intact loop (Spool 7 to Spool 10) from -2 to 30 seconds.

Fig. 83 Differential pressure in intact loop (Spool 8C to Spool 8D) from -2 to 110 seconds.

Fig. 84 Differential pressure in intact loop (Spool 8C to Spool 8D) from -2 to 30 seconds.

Fig. 85 Differential pressure in intact loop (Spool 8D to Spool 8E) from -2 to 110 seconds.

Fig. 86 Differential pressure in intact loop (Spool 8D to Spool 8E) from -2 to 30 seconds.

Fig. 87 Differential pressure in intact loop (Spool 12 to Spool 10) from -2 to 110 seconds.

Fig. 88 Differential pressure in intact loop (Spool 12 to Spool 10) from -2 to 30 seconds.

Fig. 89 Differential pressure in intact loop, low range (Spool 12 to Spool 10) from -2 to 110 seconds.

Fig. 90 Differential pressure in intact loop, low range (Spool 12 to Spool 10) from -2 to 30 seconds.

Fig. 91 Differential pressure in intact loop (Spool 12 to Spool 15) from -2 to 110 seconds.

Fig. 92 Differential pressure in intact loop (Spool 12 to Spool 15) from -2 to 30 seconds.

Fig. 93 Differential pressure in intact loop (Spool 15 to Spool 1) from -2 to 110 seconds.

Fig. 94 Differential pressure in intact loop (Spool 15 to Spool 1) from -2 to 30 seconds.

Fig. 95 Differential pressure in intact loop, low range (Spool 15 to Spool 1) from -2 to 110 seconds.

Fig. 96 Differential pressure in intact loop, low range (Spool 15 to Spool 1) from -2 to 30 seconds.

Fig. 97 Differential pressure in intact loop (Spool 15 to vessel inlet annulus) from -2 to 110 seconds.

Fig. 98 Differential pressure in intact loop (Spool 15 to vessel inlet annulus) from -2 to 30 seconds.

Fig. 99 Differential pressure in intact loop (Spool 15 to atmosphere) from -2 to 110 seconds.

Fig. 100 Differential pressure in intact loop (pressurizer liquid level) from -2 to 110 seconds.

Fig. 101 Differential pressure in intact loop (pressurizer liquid level) from -2 to 30 seconds.

Fig. 102 Differential pressure in broken loop (vessel upper plenum to Spool 21A) from -2 to 110 seconds.

Fig. 103 Differential pressure in broken loop (vessel upper plenum to Spool 21A) from -2 to 30 seconds.

Fig. 104 Differential pressure in broken loop (Spool 21A to Spool 23) from -2 to 110 seconds.

Fig. 105 Differential pressure in broken loop (Spool 21A to Spool 23) from -2 to 30 seconds.

Fig. 106 Differential pressure in broken loop (Spool 23 to vessel-side nozzle throat) from -2 to 110 seconds.

Fig. 107 Differential pressure in broken loop (Spool 23 to vessel-side nozzle throat) from -2 to 30 seconds.

Fig. 108 Differential pressure in broken loop (vessel-side nozzle throat to divergent section) from -2 to 110 seconds.

Fig. 109 Differential pressure in broken loop (vessel-side nozzle throat to divergent section) from -2 to 30 seconds.

Fig. 110 Differential pressure in broken loop (Spool 23 to Spool 24) from -2 to 110 seconds.

Fig. 111 Differential pressure in broken loop (Spool 23 to Spool 24) from -2 to 30 seconds.

Fig. 112 Differential pressure in broken loop (vessel inlet annulus to Spool 30) from -2 to 110 seconds.

Fig. 113 Differential pressure in broken loop (vessel inlet annulus to Spool 30) from -2 to 30 seconds.

Fig. 114 Differential pressure in broken loop (Spool 30 to Spool 40) from -2 to 110 seconds.

Fig. 115 Differential pressure in broken loop (Spool 30 to Spool 40) from -2 to 30 seconds.

Fig. 116 Differential pressure in broken loop (Spool 40 to Spool 38) from -2 to 110 seconds.

Fig. 117 Differential pressure in broken loop (Spool 40 to Spool 38) from -2 to 30 seconds.

Fig. 118 Differential pressure in broken loop, low range (Spool 40 to Spool 38) from -2 to 110 seconds.

Fig. 119 Differential pressure in broken loop (Spool 38 to Spool 36U) from -2 to 110 seconds.

Fig. 120 Differential pressure in broken loop (Spool 38 to Spool 36U) from -2 to 30 seconds.

Fig. 121 Differential pressure in broken loop (Spool 37 to Spool 36U) from -2 to 110 seconds.

Fig. 122 Differential pressure in broken loop (Spool 37 to Spool 36U) from -2 to 30 seconds.

Fig. 123 Differential pressure in broken loop (Spool 37 to Spool 42) from -2 to 110 seconds.

Fig. 124 Differential pressure in broken loop (Spool 37 to Spool 42) from -2 to 30 seconds.

Fig. 125 Differential pressure in broken loop (Spool 36U to Spool 32L) from -2 to 110 seconds.

Fig. 126 Differential pressure in broken loop (Spool 36U to Spool 32L) from -2 to 30 seconds.

Fig. 127 Differential pressure in broken loop (Spool 42 to Spool 43) from -2 to 110 seconds.

Fig. 128 Differential pressure in broken loop (Spool 42 to Spool 43) from -2 to 30 seconds.

Fig. 129 Differential pressure in broken loop (Spool 42 to pump-side nozzle throat) from -2 to 110 seconds.

Fig. 130 Differential pressure in broken loop (Spool 42 to pump-side nozzle throat) from -2 to 30 seconds.

Fig. 131 Differential pressure in broken loop (pump-side nozzle throat to divergent section) from -2 to 110 seconds.

Fig. 132 Differential pressure in broken loop (pump-side nozzle throat to divergent section) from -2 to 30 seconds.

Fig. 133 Differential pressure in broken loop (pump-side nozzle divergent section to Spool 43) from -2 to 110 seconds.

Fig. 134 Differential pressure in broken loop (pump-side nozzle divergent section to Spool 43) from -2 to 30 seconds.

Fig. 135 Differential pressure in vessel (upper plenum to inlet annulus) from -2 to 110 seconds.

Fig. 136 Differential pressure in vessel (upper plenum to inlet annulus) from -2 to 30 seconds.

Fig. 137 Differential pressure in vessel (DPV-9-26QQ) from -2 to 110 seconds.

Fig. 138 Differential pressure in vessel (DPV-9-26QQ) from -2 to 30 seconds.

Fig. 139 Differential pressure in vessel (DPV-26-55QM) from -2 to 110 seconds.

Fig. 140 Differential pressure in vessel (DPV-26-55QM) from -2 to 30 seconds.

Fig. 141 Differential pressure in vessel (DPV-55-110AM) from -2 to 110 seconds.

Fig. 142 Differential pressure in vessel (DPV-55-110AM) from -2 to 30 seconds.

Fig. 143 Differential pressure in vessel (DPV-156-173QQ) from -2 to 110 seconds.

Fig. 144 Differential pressure in vessel (DPV-156-173QQ) from -2 to 30 seconds.

Fig. 145 Differential pressure in vessel (DPV-166-173QQ) from -2 to 110 seconds.

Fig. 146 Differential pressure in vessel (DPV-166-173QQ) from -2 to 30 seconds.

Fig. 147 Differential pressure in vessel (DPV-166-191QT) from -2 to 110 seconds.

Fig. 148 Differential pressure in vessel (DPV-166-191QT) from -2 to 30 seconds.

Fig. 149 Differential pressure in vessel (DPV-LP-UP) from -2 to 110 seconds.

Fig. 150 Differential pressure in vessel (DPV-LP-UP) from -2 to 30 seconds.

Fig. 151 Differential pressure in steam generator secondary (secondary liquid level) from -2 to 110 seconds.

Fig. 152 Differential pressure in steam generator secondary (secondary liquid level) from -2 to 30 seconds.

Fig. 153 Volumetric flows in intact loop (FTU-1 and FTU-9) from -2 to 110 seconds.

Fig. 154 Volumetric flows in intact loop (FTU-1 and FTU-9) from -2 to 30 seconds.

Fig. 155 Volumetric flows in intact loop (FTU-13 and FTU-15) from -2 to 110 seconds.

Fig. 156 Volumetric flows in intact loop (FTU-13 and FTU-15) from -2 to 30 seconds.

Fig. 157 Volumetric flows in broken loop (FTB-21A, FTB-30, and FTB-37) from -2 to 110 seconds.

Fig. 158 Volumetric flows in broken loop (FTB-21A, FTB-30, and FTB-37) from -2 to 30 seconds.

Fig. 159 Volumetric flow in core entrance from -2 to 110 seconds.

Fig. 160 Volumetric flow in core entrance from -2 to 30 seconds.

Fig. 161 Volumetric flow from high-pressure injection system from -2 to 110 seconds.

Fig. 162 Volumetric flow from low-pressure injection system from -2 to 110 seconds.

Fig. 163 Volumetric flow from intact loop accumulator from -2 to 110 seconds.

Fig. 164 Volumetric flow from pressurizer from -2 to 110 seconds.

Fig. 165 Volumetric flow from pressurizer from -2 to 30 seconds.

Fig. 166 Fluid velocity in vessel (FTV-22M) from -2 to 110 seconds.

Fig. 167 Fluid velocity in vessel (FTV-22M) from -2 to 30 seconds.

Fig. 168 Fluid velocity in vessel (FTV-40A) from -2 to 110 seconds.

Fig. 169 Fluid velocity in vessel (FTV-40A) from -2 to 30 seconds.

Fig. 170 Fluid velocity in vessel (FTV-40M) from -2 to 110 seconds.

Fig. 171 Fluid velocity in vessel (FTV-40M) from -2 to 30 seconds.

Fig. 172 Fluid velocity in vessel (FTV-83A) from -2 to 110 seconds.

Fig. 173 Fluid velocity in vessel (FTV-83A) from -2 to 30 seconds.

Fig. 174 Fluid velocity in vessel (FTV-83M) from -2 to 110 seconds.

Fig. 175 Fluid velocity in vessel (FTV-83M) from -2 to 30 seconds.

Fig. 176 Momentum flux in intact loop (Spool 1) from -2 to 110 seconds.

Fig. 177 Momentum flux in intact loop (Spool 1) from -2 to 30 seconds.

Fig. 178 Momentum flux in intact loop (Spool 5) from -2 to 110 seconds.

Fig. 179 Momentum flux in intact loop (Spool 5) from -2 to 30 seconds.

Fig. 180 Momentum flux in intact loop (Spool 10) from -2 to 110 seconds.

Fig. 181 Momentum flux in intact loop (Spool 10) from -2 to 30 seconds.

Fig. 182 Momentum flux in intact loop (Spool 13) from -2 to 110 seconds.

Fig. 183 Momentum flux in intact loop (Spool 13) from -2 to 30 seconds.

Fig. 184 Momentum flux in intact loop (Spool 15) from -2 to 110 seconds.

Fig. 185 Momentum flux in intact loop (Spool 15) from -2 to 30 seconds.

Fig. 186 Momentum flux in broken loop (Spool 21A) from -2 to 110 seconds.

Fig. 187 Momentum flux in broken loop (Spool 21A) from -2 to 30 seconds.

Fig. 188 Momentum flux in broken loop (Spool 23) from -2 to 110 seconds.

Fig. 189 Momentum flux in broken loop (Spool 23) from -2 to 30 seconds.

Fig. 190 Momentum flux in broken loop (Spool 37) from -2 to 110 seconds.

Fig. 191 Momentum flux in broken loop (Spool 37) from -2 to 30 seconds.

Fig. 192 Momentum flux in broken loop (Spool 42) from -2 to 110 seconds.

Fig. 193 Momentum flux in broken loop (Spool 42) from -2 to 30 seconds.

Fig. 194 Momentum flux in core entrance from -2 to 110 seconds.

Fig. 195 Momentum flux in core entrance from -2 to 30 seconds.

Fig. 196 Densities in intact loop (GU-1VR and GU-1HZ) from -2 to 110 seconds.

Fig. 197 Densities in intact loop (GU-1VR and GU-1HZ) from -2 to 30 seconds.

Fig. 198 Densities in intact loop (GU-5VR and GU-10VR) from -2 to 110 seconds.

Fig. 199 Densities in intact loop (GU-5VR and GU-10VR) from -2 to 30 seconds.

Fig. 200 Density in intact loop (GU-13VR) from -2 to 110 seconds.

Fig. 201 Density in intact loop (GU-13VR) from -2 to 30 seconds.

Fig. 202 Densities in intact loop (GU-15VR and GU-15HZ) from -2 to 110 seconds.

Fig. 203 Densities in intact loop (GU-15VR and GU-15HZ) from -2 to 30 seconds.

Fig. 204 Densities in broken loop (GB-21AVR and GB-23VR) from -2 to 110 seconds.

Fig. 205 Densities in broken loop (GB-21AVR and GB-23VR) from -2 to 30 seconds.

Fig. 206 Densities in broken loop (GB-30VR and GB-42VR) from -2 to 110 seconds.

Fig. 207 Densities in broken loop (GB-30VR and GB-42VR) from -2 to 30 seconds.

Fig. 208 Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 110 seconds.

Fig. 209 Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 30 seconds.

Fig. 210 Density in vessel (GVLP-172HZ) from -2 to 110 seconds.

Fig. 211 Density in vessel (GVLP-172HZ) from -2 to 30 seconds.

Fig. 212 Density in pressurizer surge line from -2 to 110 seconds.

Fig. 213 Density in pressurizer surge line from -2 to 30 seconds.

Fig. 214 Mass flow in intact loop (FDU-1 and GU-1VR) from -2 to 110 seconds.

Fig. 215 Mass flow in intact loop (FDU-1 and GU-1VR) from -2 to 30 seconds.

Fig. 216 Mass flow in intact loop (FTU-1 and GU-1VR) from -2 to 110 seconds.

Fig. 217 Mass flow in intact loop (FTU-1 and GU-1VR) from -2 to 30 seconds.

Fig. 218 Mass flow from pressurizer from -2 to 110 seconds.

Fig. 219 Mass flow from pressurizer from -2 to 30 seconds.

Fig. 220 Mass flow in intact loop (FDU-5 and GU-5VR) from -2 to 110 seconds.

Fig. 221 Mass flow in intact loop (FDU-5 and GU-5VR) from -2 to 30 seconds.

Fig. 222 Mass flow in intact loop (FDU-10 and GU-10VR) from -2 to 110 seconds.

Fig. 223 Mass flow in intact loop (FDU-10 and GU-10VR) from -2 to 30 seconds.

Fig. 224 Mass flow in intact loop (FDU-13 and GU-13VR) from -2 to 110 seconds.

Fig. 225 Mass flow in intact loop (FDU-13 and GU-13VR) from -2 to 30 seconds.

Fig. 226 Mass flow in intact loop (FTU-13 and GU-13VR) from -2 to 110 seconds.

Fig. 227 Mass flow in intact loop (FTU-13 and GU-13VR) from -2 to 30 seconds.

Fig. 228 Mass flow in intact loop (FDU-15 and GU-15VR) from -2 to 110 seconds.

Fig. 229 Mass flow in intact loop (FDU-15 and GU-15VR) from -2 to 30 seconds.

Fig. 230 Mass flow in intact loop (FTU-15 and GU-15VR) from -2 to 110 seconds.

Fig. 231 Mass flow in intact loop (FTU-15 and GU-15VR) from -2 to 30 seconds.

Fig. 232 Mass flow in broken loop (FDB-21A and GB-21AVR) from -2 to 110 seconds.

Fig. 233 Mass flow in broken loop (FDB-21A and GB-21AVR) from -2 to 30 seconds.

Fig. 234 Mass flow in broken loop (FTB-21A and GB-21AVR) from -2 to 110 seconds.

Fig. 235 Mass flow in broken loop (FTB-21A and GB-21AVR) from -2 to 30 seconds.

Fig. 236 Mass flow in broken loop (FDB-23 and GB-23VR) from -2 to 110 seconds.

Fig. 237 Mass flow in broken loop (FDB-23 and GB-23VR) from -2 to 30 seconds.

Fig. 238 Mass flow in broken loop (FTB-30 and GB-30VR) from -2 to 110 seconds.

Fig. 239 Mass flow in broken loop (FTB-30 and GB-30VR) from -2 to 30 seconds.

Fig. 240 Mass flow in broken loop (FDB-42 and GB-42VR) from -2 to 110 seconds.

Fig. 241 Mass flow in broken loop (FDB-42 and GB-42VR) from -2 to 30 seconds.

Fig. 242 Mass flow in vessel (FTV-CORE-IN and GV-COR-150HZ) from -2 to 110 seconds.

Fig. 243 Mass flow in vessel (FTV-CORE-IN and GV-COR-150HZ) from -2 to 30 seconds.

Fig. 244 Mass flow in vessel (FDV-CORE-IN and GV-COR-150HZ) from -2 to 110 seconds.

Fig. 245 Mass flow in vessel (FDV-CORE-IN and GV-COR-150HZ) from -2 to 30 seconds.

Fig. 246 Primary pump torque from -2 to 110 seconds.

Fig. 247 Primary pump torque from -2 to 30 seconds.

Fig. 248 Primary pump power from -2 to 110 seconds.

Fig. 249 Primary pump power from -2 to 30 seconds.

Fig. 250 Primary pump speed from -2 to 110 seconds.

Fig. 251 Primary pump speed from -2 to 30 seconds.

Fig. 252 Fluid temperature in intact loop (TFU-14B) from -2 to 230 seconds.

Fig. 253 Fluid temperature in vessel (TFV-LOFT-COR, TFV-ANN-156A, and TFV-LP-7-1/2) from -2 to 230 seconds.

Fig. 254 Fluid temperatures in pressure suppression tank from -2 to 230 seconds.

Fig. 255 Pressure in intact loop ECC accumulator from -2 to 230 seconds.

Fig. 256 Pressure in pressure suppression tank from -2 to 230 seconds.

Fig. 257 Differential pressure in intact loop (DPU-15-ATM) from -2 to 230 seconds.

Fig. 258 Differential pressure in intact loop (pressurizer liquid level) from -2 to 230 seconds.

Fig. 259 Differential pressure in vessel (DPV-LP-UP) from -2 to 230 seconds.

Fig. 260 Volumetric flow in core entrance (FTV-CORE-IN) from -2 to 230 seconds.

Fig. 261 Volumetric flow from intact loop accumulator from -2 to 230 seconds.

Fig. 262 Volumetric flow from pressure suppression spray system from -2 to 230 seconds.

Fig. 263 Momentum flux in core entrance from -2 to 230 seconds.

Fig. 264 Density in broken loop (GB-30VR) from -2 to 230 seconds.

Fig. 265 Densities in vessel (GV-COR-150HZ and GV-161/192D) from -2 to 230 seconds.

IV. REFERENCES

1. S. N. Zender, H. S. Crapo, M. F. Jensen, K. E. Sackett, *Experiment Data Report for Semiscale Mod-1 Test S-01-1 (Isothermal Blowdown with Core Resistance Simulator)*, ANCR-1198 (April 1975).
2. S. N. Zender, *Experiment Data Report for Semiscale Mod-1 Test S-01-2 (Isothermal Blowdown with Core Resistance Simulator)*, ANCR-1194 (February 1975).
3. S. N. Zender, *Experiment Data Report for Semiscale Mod-1 Test S-01-3 (Isothermal Blowdown with Core Resistance Simulator)*, ANCR-1195 (March 1975).
4. S. N. Zender, M. F. Jensen, K. E. Sackett, *Experiment Data Report for Semiscale Mod-1 Test S-01-4 and S-01-4A (Isothermal Blowdown with Core Resistance Simulator)*, ANCR-1196 (March 1975).
5. S. N. Zender, H. S. Crapo, M. F. Jensen, K. E. Sackett, *Experiment Data Report for Semiscale Mod-1 Test S-01-5 (Isothermal Blowdown with Core Resistance Simulator)*, ANCR-1197 (April 1975).

DISTRIBUTION RECORD FOR ANCR-1199

External

231 - UC-78a (TID-4500, R-62) Light Water Reactor Safety & Technology -
System Interactions & Effects

Internal

2 - H. J. C. Kouts, NRC
Washington, D.C. 20555

2 - R. W. Barber, RSRC-ERDA
Washington, D.C. 20545

1 - W. Bixby, NRC
Washington, D.C. 20555

1 - Chicago Patent Group - ERDA
9800 South Cass Ave.
Argonne, Illinois 60439

3 - A. T. Morphew, Classification & Technical Information Officer
ERDA-ID
Idaho Falls, Idaho 83401

1 - R. J. Beers, ERDA-ID

1 - P. E. Litteneker, ERDA-ID

1 - R. E. Swanson, ERDA-ID

1 - V. A. Walker, ERDA-ID

1 - R. E. Wood, ERDA-ID

11 - INEL Technical Library

42 - ANC Internal Distribution

70 - Author

Total Copies Printed - 368