

SNPO-C  
*See*  
*Vault*

# REON

ROCKET ENGINE OPERATIONS - NUCLEAR

REPORT NO. 2652

AGC--2652

TO

AEC-NASE SPACE NUCLEAR PROPULSION OFFICE

ANALYSIS OF THE FAST NEUTRON

AND

GAMMA RAY SPECTRUM

FOR

LRP MECHANICAL TEST 901

NERVA PROGRAM, CONTRACT SNP-1

30 SEPTEMBER 1963

MASTER



AEROJET-GENERAL CORPORATION

AZUSA, CALIFORNIA

DISTRIBUTION OF THIS DOCUMENT UNLIMITED

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

**AEROJET  
GENERAL**

ANALYSIS OF THE FAST NEUTRON  
AND  
GAMMA RAY SPECTRUM  
FOR  
LRP MECHANICAL TEST 901



ROCKET ENGINE OPERATIONS - NUCLEAR

30 SEPTEMBER 1963

**NOTICE**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission nor any of their employees nor any of their contractors, subcontractors or their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

REPORT NO. 2652  
NERVA PROGRAM  
CONTRACT SNP-1

**AEROJET - GENERAL CORPORATION**  
A SUBSIDIARY OF THE GENERAL TIRE & RUBBER COMPANY

UNLIMITED

56



# UNCLASSIFIED

Report No. 2652

---

## ABSTRACT

The gamma ray and fast neutron fluxes and the gamma ray heating rates produced by the ASTR in the LRP Mechanical Radiation Test No. 901 were calculated and are herein reported. The Los Alamos QAD Code was used for the calculations.

  
for  W. D. Stinnett  
NERVA Technical  
Systems Manager

---

Prepared by

r. d. Fogg

30 August 1963

SECTION I

INTRODUCTION

PAGE BLANK

I. INTRODUCTION

The analytical results reported herein are a description of the nuclear environment produced by the Aerospace Systems Test Reactor at General Dynamics/Ft. Worth in the LRP Mechanical Radiation Test No. 901. The gamma ray and fast neutron fluxes and the gamma ray heating rates were calculated for selected points throughout the test components using the Los Alamos QAD Code.

The test components from the NERVA Propellant Feed System include a tank shut-off valve, a turbine power control valve, the turbopump bearings, and assorted flanges and seals.



PAGE BLANK

SECTION II

GENERAL

PAGE BLANK

# UNCLASSIFIED

Report No. 2652

---

## II. GENERAL

### A. OBJECTIVES OF ANALYTIC PROGRAM

A radiation analysis program, executed concurrently with the Radiation Effects Testing program, will provide necessary information in the following areas:

#### Prior to the test:

Analysis will provide an evaluation of the radiation fluxes and integrated doses expected in the test components during the test. It can then be established whether the intended levels will be attained in the components during the test. Analysis will further provide an evaluation of the nuclear activation so that pre-estimates may be made of handling problems and evaluation of possible structural failure of any part of the test or support structure due to radiation damage or excessive localized nuclear heating.

#### After the test:

The results of the analysis will allow interpolation of values in areas of the test where no experimental data are available. Comparison of the experimental data with the analytical results will allow evaluation of the analytical technique. Such evaluations will lead to improvement of the technique and induce confidence in it, which will be essential later, when reliance must be placed almost entirely on analytical techniques for a description of the NERVA engine nuclear environment.

PAGE BLANK

SECTION III

DISCUSSION OF ANALYSIS  
LRP MECHANICAL RADIATION TEST 901

PAGE BLANK

III. DISCUSSION OF ANALYSIS, LRP MECHANICAL RADIATION TEST 901

The analytical results are used in this report to predict the radiation environment of LRP Mechanical Radiation Test 901. This test is the first of a series which will expose components of the NERVA Engine propellant-feed system to a radiation environment which will closely approximate the NERVA environment.

It should be noted that the analysis was performed without the benefit of a measured gamma source term for the test reactor\* or the results of the radiation distribution mapping of the test volume performed for the same reactor in April 1963. It was therefore necessary to approximate the source gamma ray and neutron spectra with reasonable assumptions.

The detail of the analysis is sufficient to satisfy the requirements of II,A, but the primary value will be the evaluation of the analytical technique. Comparison of the experimental data of the test with the analytical results will permit normalization of the analytical results for interpolation purposes. However, when the experimentally determined source term and the mapping run data are available, the results can be re-evaluated to determine the extent of the error introduced by using the source spectra approximations. After these known errors have been removed from the analytical results, a critical evaluation may be made of the use of the code to approximate experimental data by comparison of the two sources of data.

---

\*The Modified Aerospace Systems Test Reactor (ASTR) operated by General Dynamics/Fort Worth, Texas.



PAGE BLANK

SECTION IV

LRP MECHANICAL RADIATION TEST NO. 901

PAGE BLANK

IV. LRP MECHANICAL RADIATION TEST NO. 901

The series of which this is the first test is of special interest to the NERVA program because it investigates some of the problems unique to the use of nuclear power for rocket propulsion. In particular, the effects of a combined cryogenic and high intensity radiation environment on the materials and operation of mechanical and electromechanical components are little known. In addition, the process of hydrogen embrittlement with all its implications relative to the reliability of components will be aggravated by intense neutron radiation. The apparent inability of petroleum-based and other types of lubricants to function properly in cryogenic environments has required that a search be initiated for means of lubricating high-speed bearing surfaces. The problem of structural damage to metals and electric components caused by high intensity radiation must also be solved for the NERVA application.

Test No. 901 attempts to approach some specific examples of these problems. In this context, the primary objectives of the test are to investigate:

The effects of the environment on metal-to-metal seals of such components as line connections and valves.

The lubricating ability of glass-impregnated Teflon (called "Armalon") when used as a caging material for bearings rotating in the vicinity of 20,000 rpm while exposed to cryogenic hydrogen and high intensity radiation.

The feasibility of operating typical components containing these features in a cryogenic and radiation environment.

The particular components to be tested are described, in the following pages, together with a general discussion of the nuclear and non-nuclear aspects of the test. Greater detail concerning the nuclear aspects of these components is contained in the Radiation Effects Data Book, REON Report 2277. Further details of the non-nuclear aspects are contained in the relevant test requests, test plans, and specifications contained in Radiation Effects Testing Data Book, REON Report 2510.

# UNCLASSIFIED

Report No. 2652

---

## A. RADIATION EFFECTS TEST 1/L001

Radiation Effects Test 1/L001 involves Configuration 1 of the Tank Shutoff Valve (TSOV).

Figure 1 shows the TSOV in the NERVA context. This valve is a  $\text{GH}_2$ -operated poppet valve designed for operation at settings of completely open or completely closed, and functioning to control  $\text{LH}_2$  propellant flow from the propellant tank into the propellant feed line.

In this test the TSOV will be immersed in  $\text{LH}_2$  with the fluid present on both sides of the valve. The liquid flow rate when the valve is open will be relatively small, approximately 0.05 lb/sec. During irradiation the valve will be periodically cycled from closed, to open, to closed; and will operate in (expected) flux levels of  $1 \times 10^{11}$  to  $1 \times 10^{12}$  nV for fast neutrons, and  $1 \times 10^5$  to  $1 \times 10^6$  ergs/gm( $\text{cm}^2$ )-sec for gamma rays.

The effect of the environment on the metal-to-metal seal of the valve is of primary interest in the test. Hydrogen embrittlement of the sealing surfaces and other metal parts, as aggravated by radiation, may cause structural failure of the seal as well as the actuating components. Visual examination of the sealing surfaces and records of the leak rate through the valve during the test will provide the basis for evaluation of possible damage, and consequent implications relative to reliability.

In addition, the valve-position-sensing transducer is being tested for reliability. Exposure of the device to the environment of the valve in the NERVA application may cause structural or electrical failure, resulting in a loss of control of the valve position, which would be a critical parameter during engine operation.

In addition to the test factors previously mentioned, structural failure of the non-moving parts of the valve, sticking of the moving parts due to damage or contraction, or changes in the actuating gas because of the cryogenic temperature, may all contribute to possible overall failure of the valve.

UNCLASSIFIED




Figure 1

Location of the TSOV on the NERVA Engine

# UNCLASSIFIED

Report No. 2652

---

Figure 2 shows the TSOV in the context of Test 901. The position transducer with its mechanical linkage is visible at the left side of the valve, the actuating gas line is on the right, and the LH<sub>2</sub> reservoir is below. The static flange and seal tester with its multiple Marman clamp configuration, and the bearing tester support are in the foreground.

UNCLASSIFIED

Report No. 2652




Figure 2

Uncovered LRP Mechanical Radiation  
Test 901 Pallet Showing the TSOV in the Background

UNCLASSIFIED



# UNCLASSIFIED

Report No. 2652

---

## B. RADIATION EFFECTS TEST 3/L001

Radiation Effects Test 3/L001 involves the Turbopump Bearing Assembly, which is shown by Figure 3 in the NERVA context.

This assembly includes the turbopump shaft with its bearing sets and bearing spacers, the housing, and the shaft RPM transducer. An actuating electric motor to drive the shaft from the turbine end at approximately 21,000 rpm, and a closure at the pump end are provided.

No attempt is being made to approximate the axial loads of the NERVA application. During the test LH<sub>2</sub> will flow through the assembly at about 0.1 lb/sec. The assembly is expected to be exposed to irradiation levels of approximately  $1 \times 10^{11}$  to  $1 \times 10^{12}$  nv for fast neutrons, and  $1 \times 10^5$  to  $1 \times 10^6$  ergs/gm(C)-sec for gamma rays.

The caging material and lubrication of the bearings are of primary importance in this test. Liquid hydrogen is to be used as the coolant for the bearing assembly, but, since petroleum-based lubricants become brittle and extremely inefficient when exposed to cryogenic temperatures, a satisfactory substitute lubricant must be found. Teflon is known to have the property of remaining pliable when exposed to cryogenic temperatures, and would provide a good lubricating surface for the bearing, but it is easily damaged by radiation. Teflon impregnated with glass (under the trade name of "Armalon") will be used in this test as the bearing caging material, in an attempt to solve this problem.

UNCLASSIFIED




Figure 3

Location of Turbopump on the NERVA Engine

# UNCLASSIFIED

Report No. 2652

---

Figure 4 shows the bearing test assembly. The section from the middle to the right end is the electric motor drive; the turbine-end bearing-temperature transducer connections are seen in the center of the picture. The connection to the left of center is the rpm transducer connection. The support flange is seen at the left.

UNCLASSIFIED

Report No. 2652




Figure 4

Turbopump Bearing Assembly Tester

UNCLASSIFIED

## C. RADIATION EFFECTS TEST 8/L001

Radiation Effects Test 8/L001 involves static flanges and metal-to-metal seal combinations, typical examples of which are located on the NERVA engine in Figure 5. The test configuration includes three seal combinations; aluminum-to-aluminum, aluminum-to-steel, steel-to-steel; and end covers secured by Marman clamps to form an enclosure.

During irradiation, LH<sub>2</sub> will flow under 250 psia at a rate of 0.05 lb/sec through the enclosure. It is anticipated that the assembly will be exposed irradiation of  $1 \times 10^{11}$  to  $1 \times 10^{12}$  nv for fast neutrons, and  $1 \times 10^5$  to  $1 \times 10^6$  ergs/gm(C)-sec for gamma rays. The reliability of the seals is of primary concern in the test. On the NERVA engine, warping of the sealing surfaces due to the cryogenic temperature, embrittlement and possible resultant structural failure due to exposure to cryogenic hydrogen and intense neutron radiation, and structural damage due to neutrons alone, may all result in intolerable leakage in critical systems.

Reference is again made to Figure 2. The seal and flange test configuration is mounted on the test pallet with the aluminum seals to the left, and the steel flanges to the right. The LH<sub>2</sub> pressure transducer is located in the lower center foreground.




Figure 5

Typical Flange and Seal Locations on the NERVA Engine

# UNCLASSIFIED

Report No. 2652

---

## D. RADIATION EFFECTS TEST 4/LO01

Radiation Effects Test 4/LO01 involves the Turbine Power Control Valve (TPCV) which is located on the NERVA engine in Figure 6. The TPCV is a butterfly-type valve designed to regulate the flow of high temperature  $\text{GH}_2$  to the turbopump turbine, thus controlling the turbine power. The loss of the valve or knowledge of its position during NERVA operation would be most serious for engine operation, making imperative the design of a reliable valve.

The test configuration includes a pneumatic linear actuator which will position the valve blade during the test to regulate the flow of ambient temperature  $\text{GH}_2$ . The test actuator is not intended for NERVA application. The operational actuator is being developed under a different program, and will be mated to the TPCV in a later radiation effects test.

It is anticipated that the assembly will be exposed to irradiation of  $1 \times 10^{11}$  to  $1 \times 10^{12}$  nv for fast neutrons, and  $1 \times 10^5$  to  $1 \times 10^6$  ergs/gm(C)-sec for gamma rays.

As with the TSCV, the metal-to-metal seal is of primary interest in this test. However, cryogenic temperature  $\text{LH}_2$  will not be present in the TPCV test, but the controlled gas may still produce hydrogen embrittlement in the valve materials. The problem of structural damage due to neutron radiation alone resulting in failure of the valve and/or the position sensing transducer is also to be investigated in this test.

# UNCLASSIFIED

Report No. 2652




Figure 6

Location of TPCV on the NERVA Engine



# UNCLASSIFIED

Report No. 2652

---

Figure 7 shows the TPCV with its actuator, and other test components, mounted in their relative positions on the test pallet. The light colored box on top of the actuator is the position sensing transducer. The valves which will regulate the environmental gases and liquids can be seen in the background, as can some of the necessary piping. The TSOV is enclosed in a cryostat to contain the  $\text{LH}_2$  bath. The remainder of the components will be enclosed by a cover (as shown by Figure 8), which will contain an inert atmosphere of helium to prevent an explosion if leaking  $\text{GH}_2$ .

UNCLASSIFIED

UNCLASSIFIED

Report No. 2652




Figure 7

Uncovered LRP Mechanical Radiation Test 901 Pallet

UNCLASSIFIED

Report No. 2652




Figure 8

Covered LRP Mechanical Radiation Test 901 Pallet

UNCLASSIFIED

SECTION V

THE TEST REACTOR  
ASTR

PAGE BLANK

# UNCLASSIFIED

Report No. 2652

---

## v. THE TEST REACTOR - ASTR

The test series for propellant-feed system components will be conducted at the Aerospace Systems Test Reactor, General Dynamics/Fort Worth, Texas. This facility was selected because of the following considerations:

The ASTR and the necessary support functions and facilities are available for the program.

The ASTR and other facilities are capable of modification to produce a radiation environment in excess of the NERVA operational environment with a comparable spatial radiation distribution.

The ASTR power is capable of being increased from 3 megawatts thermal to the necessary 10 Mw.

The minimal construction necessary to make the ASTR facility compatible with the test requirements.

To produce the necessary compatibility, the following modifications and additions were made to the ASTR facility.

Two aluminum air voids were fabricated, one being placed inside the reactor pressure vessel next to the core, and the other attached to the outside of the pressure vessel opposite the internal void.

An indentation was constructed in the Outside ASTR Tank, within an inch of the measure-vessel void location. The rear wall of the indentation closest to the reactor is composed of an aluminum plate and a plate made of an aluminum and boral sandwich. The combined effect of the air voids and boral plate is to "harden" the spectrum of the leakage neutron flux. The air voids essentially remove water (which is used as moderator and shielding for the reactor) from the intended irradiation direction, resulting in exposure of the test volume to the fast neutrons of the bare core. The boral further removes thermal neutrons from the leakage flux which then is primarily composed of fast neutrons.




Figure 9

ASTR - LRP Pallet Test 901  
Top View

UNCLASSIFIED

Report No. 2652




Figure 10

ASTR - LRP Pallet Test 901  
Side View



# UNCLASSIFIED

Report No. 2652

---

A movable carriage was constructed for positioning the pallet,  $\text{LH}_2$  stowage facilities, and the necessary facilities<sup>2</sup> and equipment to provide other gases, electric power, and instrumentation to the test area.

Figures 9 and 10 illustrate the analytical representation of the ASTR and the relative position of Test 901.

SECTION VI

THE ANALYSIS

PAGE BLANK

VI. THE ANALYSIS

A. ANALYTICAL OBJECTIVES

The analytical objectives for Test 901 are:

To calculate the perturbed fast neutron and gamma ray fluxes and integrated doses experienced by the test components. These values will be used to evaluate the nuclear activation produced in the test components and to compare the test environment with the NERVA application.

To calculate the radiation induced heating rates and heat distribution for evaluation of the cooling requirements, for anticipation of mechanical failure as a result of excessive localized heating, and for comparison purposes.

To establish an analytical model of the test to permit interpolation in those areas where no experimental data will be available.

To compare the calculated values with the experimental data for evaluation of the analytical technique - the major objective of this analysis.

Evaluations thus based will contribute to the necessary development of an analytical technique, by use of which the NERVA nuclear environment can be confidently predicted with increasing accuracy.

# UNCLASSIFIED

Report No. 2652

---

## B. THE CALCULATION

The gamma ray and neutron fluxes were calculated through use of the Point Kernel Approximation of Removal theory. This method calculates the flux produced at a distance,  $R$ , from a volume distribution of point sources by means of the equation

$$I = K \sum_i S_i B(R)_i \frac{e^{-R\Sigma_{ij}}}{4\pi R^2} \quad (1)$$

where

$i$  =  $i$  th energy group

$S_i$  = source strength

$\Sigma_{ij}$  = the homogeneous macroscopic absorption cross section for the  $j$  th material when the equation is used to calculate gamma flux

or the fast-neutron removal cross section when the equation is used to calculate fast neutron flux.

The computer code, called "QAD," developed by the Los Alamos Scientific Laboratory, was used for these calculations.

It should be noted that  $R$  in Equation (1) is defined as

$$R = \sum_j r \quad (2)$$

where

$r$  = distance through the  $j$  th material.

As an integral part of the calculation, the source volume is divided into a large number of incremental volumes to approximate point sources. The source strength,  $S_i$ , is determined by the reactor power, the distribution of relative power level in space, and the group-dependent energy spectrum.

# UNCLASSIFIED

Report No. 2652

---

When Equation (1) is used for neutron calculations, one energy group is used and  $B(R)$  is taken to be 1.

By insertion of the proper factor for  $K$ , gamma heating rates or doses can be calculated directly.

Figures 9 and 10 have been referenced as illustrations of the analytical model used to represent the test. The surfaces were described to QAD by expressing them in the equation

$$Ax^2 + Bx + Cy^2 + Dy + Ez^2 + Fz - K = 0 \quad (3)$$

or one of its simplifications. It will be noted that all piping, structural members, wiring, and instrumentation have been omitted from the representation. Evaluation of the contribution of these items showed that they will produce localized perturbations of the incident flux, but not of sufficient magnitude in the gross flux distribution to justify increasing the complexity of the geometry.

# UNCLASSIFIED

Report No. 2652

---

## C. INPUT PARAMETERS

The nuclear input parameters for the calculation are

1. Reactor Power

10 megawatts

2. Relative Power Distribution

Presented in cylindrical coordinates - tabulated in Table 1.

TABLE 1

INPUT PARAMETERS  
RELATIVE POWER DISTRIBUTION

<u>Radial and Azimuthal Coordinates</u>	<u>Axial Coordinate</u>	
	<u>Distance from Reactor Upper End</u>	<u>Relative Power</u>
Assumed flat	0 cm	0.583
	1.75	0.518
	3.5	0.500
	5.25	0.532
	10.0	0.660
	20.0	0.880
	30.0	1.000
	40.0	0.853
	50.0	0.650
	56.0	0.520
	58.5	0.460
	59.75	0.471
	60.0	0.500

# UNCLASSIFIED

Report No. 2652

---

## 3. Energy Spectrum

### a. Gamma

The gamma energy spectrum used is the result of a choice between spectrums calculated by REON, and General Dynamics/Fort Worth, and the measured spectrum of the Bulk Shielding Reactor (BSR) at ORNL. The REON calculated spectrum was based on computations of the gamma source strength from the fission of U235 after steady-state operation of 100 hours. These calculations omitted the capture-gamma contribution from the reactor structure and supports. Evaluation of this contribution proved to be unnecessarily involved, and estimates were substituted.

The calculated spectrum furnished by General Dynamics proved to be a reasonable approximation up to gamma energies of about 4 Mev. However, above that energy the spectrum exceeds the fission spectrum by an amount greater than could be attributed to capture gammas.

The measured leakage gamma spectrum of the BSR provides the best approximation of ASTR due to the nuclear similarities of the two cores. The added advantage of the use of this spectrum is that it includes some capture gamma contribution. The gamma spectrum derived from this reactor is tabulated in Table 2.

TABLE 2

### BSR GAMMA SPECTRUM FOR ASTR

<u>Energy Group</u> <u>Mev</u>	<u>Energy</u> <u>Mev-watt<sup>-1</sup>-sec<sup>-1</sup></u>	<u>Energy Group</u> <u>Mev</u>	<u>Energy</u> <u>Mev-watt<sup>-1</sup>-sec<sup>-1</sup></u>
0 - 0.4	6.775 x 10 <sup>10</sup>	2.6 - 3.0	3.66 x 10 <sup>10</sup>
0.4 - 0.9	8.87	3.0 - 4.0	5.60
0.9 - 1.35	7.40	4.0 - 5.0	3.10
1.35 - 1.8	7.35	5.0 - 6.0	1.50
1.8 - 2.2	7.90	6.0 - 7.0	1.15
2.2 - 2.6	5.38	7.0 - 8.0	1.10



# UNCLASSIFIED

Report No. 2652

---

While the choice between these alternatives admittedly results in a compromise, this is necessitated by the fact that no experimental measurement has been made by General Dynamics of the ASTR gamma spectrum.

Since these calculations were completed, measurements have been made of the unperturbed fluxes produced by ASTR in the irradiation volume, but the data has not yet been used to derive a spectrum.

b. Neutron

Calculated U235 fission prompt-neutron flux per watt of reactor power used for the neutron removal calculation of fast neutron flux was calculated in this manner:

$$\begin{aligned} & 3.09 \times 10^{10} \frac{\text{fission}}{\text{watts} \cdot \text{sec}} \times 2.56 \frac{\text{neutrons}}{\text{fission}} & (4) \\ & = 7.9 \times 10^6 \frac{\text{neutrons}}{\text{watt} \cdot \text{sec}} & (E > 0.1 \text{ Mev}) \end{aligned}$$

SECTION VII

RESULTS OF THE CALCULATIONS

PAGE BLANK

VII. RESULTS OF THE CALCULATIONS

Table III is a tabulation of the gamma-ray and fast neutron fluxes and the gamma-ray heating rates at the detector points shown on Figures 9 and 10. Table 4 compares the analytical environments of the test and NERVA with respect to gamma-ray flux.

# UNCLASSIFIED

Report No. 2652

TABLE 3

## FLUXES AND HEATING RATES AT DETECTOR POINTS

Detector Point	Detector Location	Material/Density at Detector Point		Gamma Flux (ergs/gm(C)-sec)	Gamma Heating Rates for Pure Iron at Detector Point (Btu/in. <sup>3</sup> -sec)	Fast Neutron Flux (N/cm <sup>2</sup> -sec)
			(gm/cm <sup>3</sup> )			
1	Flange and seal test - Al to Al flange	Al 6061-T6	2.71	$2.9 \times 10^5$	$3 \times 10^{-4}$	$1.98 \times 10^{11}$
2	Flange and seal test - Al to SS flange	Al SS	2.71 8.04	$4.15 \times 10^5$	$4.3 \times 10^{-4}$	$4.3 \times 10^{11}$
3	Flange and seal test - SS to SS flange	SS 347	8.04	$6.16 \times 10^5$	$6.5 \times 10^{-4}$	$8.5 \times 10^{11}$
4	Bearing test	SS 302	7.92	$2.32 \times 10^5$	$2.4 \times 10^{-4}$	$4.23 \times 10^{11}$
5	Bearing test	Inconel X	8.42	$2.1 \times 10^4$	$2.1 \times 10^{-5}$	$1.1 \times 10^{11}$
6	Bearing test	SS 302	7.92	$1.37 \times 10^5$	$1.4 \times 10^{-4}$	$3.02 \times 10^{11}$
7	Bearing test - pump end bearing	SS 302	7.92	$7.5 \times 10^4$	$7.6 \times 10^{-5}$	$1.84 \times 10^{11}$
8	Bearing test	Inconel X	8.42	$1.4 \times 10^4$	$1.4 \times 10^{-5}$	$8.0 \times 10^{10}$
9	Bearing test	H Monel	8.44	$7.4 \times 10^4$	$7.6 \times 10^{-5}$	$2.26 \times 10^{11}$
10	Bearing test	Inconel X	8.42	$3.78 \times 10^3$	$3.8 \times 10^{-6}$	$2.9 \times 10^{10}$
11	Bearing test	A 286	7.92	$6.8 \times 10^3$	$6.8 \times 10^{-6}$	$3.65 \times 10^{10}$
12	Bearing test	Inconel X	8.42	$3.3 \times 10^4$	$3.3 \times 10^{-5}$	$1.06 \times 10^{11}$
13	Bearing test - turbine end bearings	SS 302	7.92	$7.4 \times 10^3$	$7.4 \times 10^{-6}$	$3.57 \times 10^{10}$
14	Bearing test - turbine end bearings	SS 302	7.92	$3.52 \times 10^3$	$3.5 \times 10^{-6}$	$2.11 \times 10^{10}$
15	Bearing test	Inconel X	8.42	$9.1 \times 10^2$	$9.1 \times 10^{-7}$	$1.07 \times 10^{10}$
16	Bearing test - turbine end bearing	SS 302	7.92	$1.30 \times 10^3$	$1.4 \times 10^{-6}$	$1.24 \times 10^{10}$
17	Bearing test	H Monel	8.44	$6.1 \times 10^3$	$6.1 \times 10^{-6}$	$2.9 \times 10^{10}$
18	Bearing test	Inconel X	8.42	$5.0 \times 10^2$	$5.0 \times 10^{-7}$	$4.0 \times 10^9$
19	Bearing test	Inconel X	8.42	$2.76 \times 10^3$	$2.8 \times 10^{-6}$	$1.15 \times 10^{10}$
20	TPCV	Hastelloy B	9.17	$3.7 \times 10^5$	$3.8 \times 10^{-3}$	$5.4 \times 10^{11}$
21	TSOV	Al 356-T6	2.71	$1.2 \times 10^5$	$1.2 \times 10^{-4}$	$1.35 \times 10^{11}$

**UNCLASSIFIED**

Report No. 2652

---

TABLE 4

<u>Component</u>	<u>Test Gamma Flux (ergs/gm(c)-sec)</u>	<u>NERVA Gamma Flux (ergs/gm(c)-sec)</u>
ISOV	$1.2 \times 10^5$	$5 \times 10^5 \rightarrow 3 \times 10^7$
Turbopump Bearings	Turbine end - $3.4 \times 10^3$	$7 \times 10^7$
	Pump end - $7.5 \times 10^4$	$3 \times 10^7$
Static Seals and Flanges	$3 \times 10^5 \rightarrow 6 \times 10^5$	$1 \times 10^8 \rightarrow 3 \times 10^{10}$
EPCV	$3.7 \times 10^5$	$7 \times 10^8$

# UNCLASSIFIED

Report No. 2652

---

It is apparent that the flux predictions of the test fall several factors of 10 short of the predictions of NERVA application. The gross effects will be even further divergent when the 5-minute exposure of the test is compared with the NERVA operating period.

An important limitation of QAD should be noted. QAD does not directly evaluate the contribution to the gamma-ray flux due to  $(n, \gamma)$  reactors of thermalized neutrons. The modification of ASTR is intended to produce a "hard" leakage spectrum, but large reservoirs of  $\text{LH}_2$  in the test components will produce thermalization of the incident flux. Thermal neutrons will be scattered from the thermalization volumes and may interact at random locations. The effect will be to produce gamma rays in areas shielded from the direct gamma rays of the reactor. For the present calculations this contribution to the gamma ray flux has been neglected. As a result, predictions of the gamma ray fluxes in (or in the immediate vicinity of) the larger reservoirs of  $\text{LH}_2$  may be low.

