


**UNCLASSIFIED****LEGAL NOTICE**

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission

A. Makes any warranty or representation expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights, or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to any information pursuant to his employment or contract with the Commission, or his employment with such contractor

**OAK RIDGE NATIONAL LABORATORY**

Operated by

**UNION CARBIDE NUCLEAR COMPANY**

Division of Union Carbide Corporation



Post Office Box X  
Oak Ridge, Tennessee

**ORNL**  
**CENTRAL FILES NUMBER**

(CF. 58-4-48)

DATE: April 15, 1958

COPY NO. 87

SUBJECT: HRP Dynamic Corrosion Studies (In-Pile Development) Summary of  
Runs HT-20, HT-21, and HT-22 (Thorium Oxide Slurry)

TO: H. C. Savage

FROM: D. W. Hubbard *Jerm*I. Summary

Runs HT-20, - 21, and - 22 were made to determine the handling characteristics of a slurry containing thoria calcined at 1600°C and to evaluate the operation of the 5-gpm slurry loop using this slurry. The low velocity core section was removed from the loop prior to these runs.

Thorium oxide slurry at ~ 500 g/kg H<sub>2</sub>O was circulated for 192 hr during run HT-21 with no operating difficulty. Run HT-22 consisted of an additional 524 hr of trouble-free operation circulating thorium oxide slurry of the same concentration. After 524 hr, run HT-22, the pump became noisy; and on disassembly it was seen that considerable wear had occurred on the thrust surfaces of the front bearing and journal. This was presumably due to improper thrust balance of the pump.

It can be concluded that the 1600°C-calcined, 0.7 μ mean particle size, thoria slurry can be circulated in a 5-gpm loop, and that the improved operation of the 5-gpm loop is due to the improved handling properties of the slurry and elimination of the low velocity core section since previous attempts to circulate slurries of different character were unsuccessful. <sup>(1)</sup>

**NOTICE**

This document contains information of a preliminary nature and was prepared primarily for internal use at the Oak Ridge National Laboratory. It is subject to revision or correction and therefore does not represent a final report.

**UNCLASSIFIED**

001

RELEASE APPROVED

BY PATENT BRANCH

7-6-59

*MS*

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

TABLE OF CONTENTS

	Page
I. Summary	1
II. Loop Design	3
III. Run HT-20	3
IV. Run HT-21	4
V. Run HT-22	5
VI. Summary of Operations	6

APPENDIX

A. Schematic Drawing of Loop	9
B. Chemical Analyses of Samples	10

## II. Loop Design

When it was decided to resume operation of the 5-gpm loop,<sup>(1)</sup> after it had been idle for nearly a year, some minor changes to the loop were made. Figure 1 shows schematically the present appearance of the loop.

Altering the pressurizer for full flow through a side inlet was one change made. The full stream of fluid now flows into the side of the pressurizer and out the bottom. All other lines on the pressurizer were removed except the vapor line to the condenser and the condensate return line.

The standard in-pile type of core body and sample holder was replaced by a hairpin bend of 3/8-in. schedule-40 stainless steel (type 347) pipe. A drain line was welded to the bottom of this bend so that the entire loop could be drained easily. In previous tests, liquid remained in some of the lower parts of the loop in spite of all efforts to remove it.

A venturi was installed in the main stream for measurement of flow. This is the only flow restrictor now in the system, all the orifice plates used previously having been removed.

The pump used was modified so that it is now equivalent to the standard 5-gpm in-pile double-bearing pump with aluminum oxide bearings and journal bushings. A 110-v, single-phase stator with class A windings was used.

## III. Run HT-20

Run HT-20 was made to clean the loop, make flow measurements, and check the operation of all parts of the loop in preparation for slurry tests. A 3% trisodium phosphate solution was circulated in the loop for 4 hr at 100°C with 60 psi helium overpressure. The loop was then rinsed with distilled water and charged with a 5% nitric acid solution. After 22 hr of operation at 100°C and 60 psi helium pressure, a leak developed at the pump scroll gasket. This was repaired, and a second nitric acid run was made under the same conditions for 24 hr. Following the nitric acid treatment, the loop was again rinsed with distilled water and charged with distilled water. The flow was measured as 7.1 gpm at room temperature with an oxygen overpressure of 60 psi. The heaters, condensate system, and slurry addition system were checked for proper operation with the loop at ~ 250°C and ~ 600 psi total pressure (60 psi oxygen pressure added at room temperature). The total operating time for the distilled-water run was 8 hr. During this

time, the loop operated in a normal fashion except that the pump temperature was  $85^{\circ}\text{C}$  compared to a normal temperature of  $60^{\circ}\text{C}$  usually observed for this type of pump.

#### IV. Run HT-21

Run HT-21 was made to determine whether the loop would satisfactorily circulate thorium oxide slurry. The slurry used was the same as that used in 100A loop BS for runs BS-17<sup>(2)</sup> and BS-18. It is a mixture of thoria from batches LO-17 and TO-10-1000 recalcined to  $1600^{\circ}\text{C}$  and having a mean particle size of  $0.7\ \mu$ . The run was started by charging the loop system with 1788 ml of distilled water. This included filling the pressurizer, the condensate tank, and the slurry addition tank. Enough oxygen was added to the loop to produce a pressure of 90 psi at room temperature. The flow through the loop was assumed to be the same as measured in run HT-20 -- 7.1 gpm. The loop temperature was brought to  $\sim 250^{\circ}\text{C}$ , and the loop was operated for 51 hr while final operational checks were made. At this temperature, the total pressure was 670 psi.

After 41 hr of operation, the loop was charged with approximately 690 g of thorium oxide contained in a dense slurry. This dense slurry was placed in the slurry addition tank and pumped into the loop. The volume of the slurry in the addition tank was replaced by an equal volume of condensate from the loop, so that the fluid volume in the loop remained essentially the same before and after the addition. No difficulty was noted during the addition of the slurry, and inspection of the addition tank after the loading had been completed showed that all the thorium oxide has been transferred to the loop. For some reason, the pump temperature decreased markedly, from  $85^{\circ}\text{C}$  to  $60^{\circ}\text{C}$ , after the slurry addition.

A considerable amount of instrument trouble during the run made it necessary to shut down for adjustments. Two such shutdowns were made, one of 43 hr duration after 144 hr of slurry operation and another of 65 hr duration after 174 hr of slurry operation. When the loop was restarted after each shutdown, the slurry resuspended easily.

Twice during the run, at hour 164 and hour 188, the pump power demand decreased from 1020 watts to 900 watts, indicating that the density of the slurry had been reduced or that the flow had decreased. Samples taken immediately following these decreases in pump power demand showed that the

thorium concentration in the circulating stream had decreased to ~ 200 g Th per kg water. The average thorium concentration for the run was ~ 500 g Th per kg water. This condition was corrected by adding 20 ml of water to the loop and adding oxygen to increase the total pressure from 600 to 690 psi. Evidently, the pressure on the suction side of the pump had decreased below the vapor pressure of the fluid and allowed vapor to form in the pump, causing the flow to decrease.

At times, it was difficult to produce enough condensate to keep a steady purge stream flowing to the pump bearings. This difficulty may have been due to having too little liquid in the system, blocking the condenser with noncondensable gases, or having an insufficient temperature differential in the condenser system. When the pump bearing purge was cut off for periods of 3 hr, no adverse effects were noticed in the operation of the pump.

The loop was operated for 192 hr while circulating thorium oxide slurry in run HT-21. Two general conclusions may be drawn from this run. The 1600°C-calcined thorium oxide slurry used can be added, circulated, and resuspended after a shutdown, without difficulty. With a small-volume loop such as this, the operation with thoria slurry is very sensitive to changes in fluid volume, temperature, or pressure. From Table 2, it is seen that the thorium concentration of samples taken during the run deviated considerably from the calculated concentration of the circulating stream. Poor sampling techniques may be the cause of this difficulty.

#### V. Run HT-22

No additional changes were made to the loop after the previous run, HT-21. The purpose of run HT-22 was to continue evaluation of the handling properties of the 1600°C-calcined slurry. The slurry used was the same as that used in run HT-21.

The loop was filled with distilled water and enough oxygen was added to give a pressure of 60 psi (room temperature). After the water had been heated to 250°C and the system had reached equilibrium, 700 g of ThO<sub>2</sub> was placed in the addition tank and added to the loop. Operation was normal while the slurry was being circulated. When the system pressure was low, the power demand would decrease, indicating that the flow had been reduced

and some of the thoria had settled in the lines. This was probably caused by pump cavitation. This situation could always be corrected by adding oxygen and/or water to bring the system pressure to about 100 psi over the vapor pressure of water at operating temperature.

During this run, the pump bearings were purged with a stream of condensate at the rate of 20 ml/min, a flow rate which was easily maintained throughout the run. When 523 hr of operation with slurry had elapsed, the pump temperature rose suddenly to 90°C -- it had been operating at 55°C. Also at this time, a scraping or dragging noise was heard in the pump. The run was terminated and the pump was disassembled. It was noted that 0.0130 in. of material had been worn from both the front-bearing thrust surface and the front-rotor-journal thrust surface. The bearing and journal bushings (aluminum oxide) were rather badly cracked and scarred, making it difficult to obtain accurate measurements. It was evident that the thrust-surface wear had allowed the rotor to move forward far enough to enable the front-journal lock ring to strike the bearing spacer and produce the scraping sound when the pump was operating. The inside surfaces of both bearings were worn approximately 0.005 in.; the journal bushings (on the rotor) showed no wear.

The sampling technique was not changed during this run; and, as in run HT-21, the thorium concentration of the samples deviates considerably from the calculated values.

## VI. Summary of Operations

### Run HT-20

- (a) Purpose: Clean, measure flow, and check operation of redesigned "HT" loop.

Charge No. 1: 1200 ml 3% TSP

Gas pressure: Helium, 60 psi at 25°C

Temperature: 90°C

Time: 4 hours

- (b) Charge No. 2: 1200 ml, 5% HNO<sub>3</sub>

Gas pressure: 60 psi helium at 25°C

Temperature: 95°C

Time: 46 hours



(c) Charge No. 3: 1200 ml H<sub>2</sub>O  
Gas pressure: O<sub>2</sub>, 60 psi at 25°C  
Temperature: 250°C  
Time: 8 hours  
Flow rate: 7.1 gpm  
Operation: Loop functioned normally

Run HT-21

Purpose: Operate the loop using 1600°C-calcined thorium oxide slurry.  
Charge: 1200 ml H<sub>2</sub>O (690 g ThO<sub>2</sub> were added during the period from hr 51-97)  
Gas pressure: O<sub>2</sub>, 90 psi at 25°C  
Temperature: 250°C  
Pressure: 670 psi  
Slurry concentration: 500 g ThO<sub>2</sub>/kg H<sub>2</sub>O  
Time: 243 hr (192 hr with ThO<sub>2</sub> slurry)  
Flow rate: 7.1 gpm  
Operation: Loop operated satisfactorily.

Run HT-22

Purpose: Continue to evaluate the handling properties of 1600°C-calcined thoria slurry in the 5-gpm slurry loop.  
Charge: 1200 ml H<sub>2</sub>O (at hour 23, 700 g ThO<sub>2</sub> were added)  
Gas pressure: 60 psi O<sub>2</sub> at 25°C  
Temperature: 250°C  
Pressure: 610 psi  
Slurry concentration: 550 g Th/kg H<sub>2</sub>O  
Time: 547 hours (544 hr with ThO<sub>2</sub> slurry)  
Flow Rate: 7.1 gpm  
Bearing purge rate: 10 ml/min  
Pump temperature: 55°C  
Operation: No difficulty was experienced until the final hours of the run. The front thrust surfaces of the bearings and journals were worn so that the rotor moved forward and began to rub on the bearing spacer. This caused the pump temperature to rise, and the run was terminated.

APPENDIX

	Page
A. Schematic Drawing of Loop	9
B. Chemical Analyses of Samples, Run HT-20	10
Chemical Analyses of Samples, Run HT-21	11
Chemical Analyses of Samples, Run HT-22	12
C. References	13

VOLUME OF LOOP = 1400 cc  
VOLUME OF ADDITION SYSTEM = 485 cc (ADDITION TANK = 300 cc)  
VOLUME OF CONDENSATE SYSTEM = 200 cc

UNCLASSIFIED  
ORNL-LR-DWG. 29942




Fig. 1. 5 GPM Slurry Development Loop (Runs HT-20, HT-21, HT-22)

TABLE I

## Chemical Analysis of Samples Taken During Run HT-20

Fluid	Loop Temperature (°C)	Operation Time (hours)	pH	Analysis (mg/gram of sample)								
				Fe (mg/g)	Ni (mg/g)	Cr (mg/g)	Cu (mg/g)	Al (mg/g)	Ti (mg/g)	Th (mg/g)	Cl <sup>-</sup> (mg/g)	PO <sub>4</sub> <sup>=</sup> (mg/g)
TSP (3%)	-	0	11.0	< 1x10 <sup>-3</sup>	2x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	-	2x10 <sup>-3</sup>	-	8x10 <sup>-3</sup>	13.4
TSP (3%)	90	2.2	12.0	< 0.005	< 0.005	< 0.005	< 0.005	-	< 0.02	0.17	< 0.01	17.4
TSP (3%)	40	4.5	11.9	< 0.005	< 0.005	< 0.005	< 0.005	-	< 0.02	< 0.02	< 0.01	17.6
HNO <sub>3</sub> (5%)	-	0	0.4	< 1x10 <sup>-3</sup>	2x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	2x10 <sup>-3</sup>	23x10 <sup>-3</sup>	-	< 2x10 <sup>-3</sup>	-
HNO <sub>3</sub> (5%)	100	0.6	0.4	0.055	0.011	0.019	< 0.005	< 0.02	< 0.02	0.09	< 0.01	< 0.02
HNO <sub>3</sub> (5%)	90	18.1	0.6	0.089	0.022	< 0.005	0.059	< 0.02	< 0.02	0.03	< 0.01	< 0.02
HNO <sub>3</sub> (5%)	-	19.8	0.6	0.094	0.023	0.006	0.063	< 0.02	< 0.02	0.05	< 0.01	< 0.02
HNO <sub>3</sub> (5%)	-	0	0.2	< 1x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	< 1x10 <sup>-3</sup>	1x10 <sup>-3</sup>	1x10 <sup>-3</sup>	-	< 1x10 <sup>-3</sup>	-
HNO <sub>3</sub> (5%)	94	1.9	1.3	12x10 <sup>-3</sup>	2x10 <sup>-3</sup>	1x10 <sup>-3</sup>	1x10 <sup>-3</sup>	6x10 <sup>-3</sup>	2x10 <sup>-3</sup>	< 2x10 <sup>-3</sup>	< 2x10 <sup>-3</sup>	-
HNO <sub>3</sub> (5%)	94	19.3	1.1	31x10 <sup>-3</sup>	4x10 <sup>-3</sup>	3x10 <sup>-3</sup>	3x10 <sup>-3</sup>	12x10 <sup>-3</sup>	2x10 <sup>-3</sup>	9x10 <sup>-3</sup>	< 2x10 <sup>-3</sup>	-
HNO <sub>3</sub> (5%)	100	25.3	1.0	37x10 <sup>-3</sup>	5x10 <sup>-3</sup>	4x10 <sup>-3</sup>	3x10 <sup>-3</sup>	11x10 <sup>-3</sup>	2x10 <sup>-3</sup>	14x10 <sup>-3</sup>	< 2x10 <sup>-3</sup>	-

↑  
Helium  
↓

TABLE 2

## Chemical Analysis of Samples Taken During Run HT-21

Fluid	Loop Temp. (°C)	Gas	Operation Time (hours) <sup>(1)</sup>	Analysis (mg/g of sample)				Th <sup>(2)</sup> (g Th/kg H <sub>2</sub> O)	Load Concentration Calculated (g Th/kg H <sub>2</sub> O)
				Fe	Al	Density (g/ml)	pH		
ThO <sub>2</sub> -H <sub>2</sub> O slurry	250	O <sub>2</sub>	71.5	0.73	0.15	1.18	6.6	210 <sup>(3)</sup>	(3)
"	250	"	97.4	1.80	0.33	1.59	6.7	590	500
"	250	"	163.9	1.10	0.33	1.20	6.2	220 <sup>(4)</sup>	"
"	250	"	187.8	0.54	0.06	1.17	6.2	190 <sup>(4)</sup>	"
"	250	"	194.1	1.30	0.16	1.49	6.6	550	"
"	254	"	198.6	2.33	0.26	1.94	6.4	1020	"
"	-	"	222.5	2.05	0.28	1.65	6.4	710	"
"	250	"	230.5	1.76	0.46	1.45	6.4	490	"
"	250	"	237.9	2.23	0.37	1.66	5.8	590	"
"	42	"	243.2	1.55	0.24	1.34	5.9	350	"
"	55	"	244.6	1.30	0.18	1.32	5.9	340	"

(1) 700 g ThO<sub>2</sub> added during the period between hrs 51-97.

(2) Calculated from the density

(3) Sample taken while adding slurry

(4) Samples taken during period when there was evidence of pump cavitation.

TABLE 3

## Chemical Analysis of Samples Taken During Run HT-22

Fluid	Loop Temp. (°C)	Pump Power (watts)	Gas	Operating Time Hours*	Load Concentration Calculated g/kg H <sub>2</sub> O	Analysis (mg/g of sample)					
						Th (g/kg of H <sub>2</sub> O)	Ni	Cr	Fe	Al	pH
↑ Thorium Oxide Slurry ↓	250	955	↑ Oxygen ↓	118	550	368	-	-	1.49	0.31	6.5
	250	1050		139		768	-	-	2.31	0.40	6.0
	250	996		143		710	-	-	2.08	0.36	5.7
	245	1020		186		762	-	-	2.41	0.35	6.2
	250	1080		209		800	-	-	2.21	0.35	5.6
	250	990		282		590	-	-	1.86	0.32	5.6
	249	1056		330		364	0.21	0.19	1.59	0.27	3.5
	248	1038		336		429	0.20	0.20	1.66	0.27	3.5
	250	930		450		243	0.12	0.11	0.96	0.23	4.4
	250	930		525		606	0.21	0.22	1.82	0.34	4.2
-	-	547	428	0.21	0.23	1.85	0.38	5.5			

\* 700 g ThO<sub>2</sub> added at hr 23.

REFERENCES

- (1) R. M. Warner, et al., HRP Dynamic Corrosion Studies, ORNL CF-56-11-40, November 2, 1956.

see also HRP Quarterly Progress Reports; July 31, 1956 (ORNL-2148);  
October 31, 1956 (ORNL-2222).

- (2) S. A. Reed, et al.; HRP Dynamic Corrosion Studies; ORNL CF 57-10-95, October 23, 1957.

DISTRIBUTION

1. HRP Director's Office  
Rm. 259, Bldg. 9204-1
2. G. M. Adamson
3. S. E. Beall
4. A. M. Billings
5. E. G. Bohlmann
6. S. E. Bolt
7. E. S. Bomar
8. J. R. Brown
9. W. D. Burch
10. R. H. Chapman
11. R. D. Cheverton
12. H. C. Claiborne
13. E. L. Compere
14. R. S. Crouse
15. J. S. Culver
16. D. G. Davis
17. R. J. Davis
18. J. R. Engel
19. J. L. English
20. D. E. Ferguson
21. J. D. Flynn
22. C. H. Gabbard
23. W. R. Gall
24. J. C. Griess
25. R. S. Greeley
26. P. A. Haas
27. P. H. Harley
28. P. N. Haubenreich
29. J. W. Hill
30. E. C. Hise
31. C. J. Hochanadel
32. D. W. Hubbard
33. G. H. Jenks
34. D. T. Jones
35. S. I. Kaplan
36. P. R. Kasten
37. F. Kertesz
38. J. O. Kolb
39. R. B. Korsmeyer
40. K. A. Kraus
41. C. G. Lawson
42. R. E. Leuze
43. R. A. Lorenz
44. M. I. Lundin
45. R. N. Lyon
46. W. L. Marshall
47. J. P. McBride
48. H. F. McDuffie
49. H. A. McLain
50. R. A. McNeas
51. J. R. McWherter
52. R. L. Moore
53. L. F. Parsly, Jr.
54. F. N. Peebles
55. M. L. Picklesimer
56. S. A. Reed
57. D. M. Richardson
58. G. W. Rivenbark
59. R. C. Robertson
60. M. W. Rosenthal
61. H. C. Savage
62. C. L. Segaser
63. E. M. Shank
64. A. J. Shor
65. M. D. Silverman
66. M. J. Skinner
67. I. Spiewak
68. R. W. Stoughton
69. J. A. Swartout
70. E. H. Taylor
71. D. G. Thomas
72. D. S. Toomb
73. W. E. Unger
74. R. Van Winkle
75. A. M. Weinberg
76. K. W. West
77. J. C. Wilson
78. C. E. Winters
79. F. C. Zapp
- 80-81. REED Library (2)
- 82-83. Central Research Library (2)
- 84-85. Document Reference Library (2)
- 86-100. Laboratory Records (15)
101. ORNL-RC

**DO NOT  
PHOTOSTAT**