2

HARVARD SCHOOL OF PUBLIC HEALTH

665 HUNTINGTON AVENUE
BOSTON, MASSACHUSETTS 02115

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

REPORT DISTRIBUTION LIST

<u>Recipient</u>	<u>No. of Copies</u>
Aerojet Nuclear Company	3
Air Reduction Company	1
American Nuclear Society	1
Argonne National Laboratory	1
Atomic Energy Commission, Advisory Committee on Reactor Safeguards	17
Atomic Energy Commission, Brookhaven Patent Group	1
Atomic Energy Commission, Canoga Park Area Office	1
Atomic Energy Commission, Chicago Operations Office Contracts Division	2
Atomic Energy Commission, Contracts Division, Cambridge	1
Atomic Energy Commission, Division of Compliance	1
Atomic Energy Commission, Division of Waste Management & Transportation	1
Atomic Energy Commission, Division of Production	1
Atomic Energy Commission, Division of Reactor Licensing	1
Atomic Energy Commission, Division of Reactor Development and Technology	18
Atomic Energy Commission, Division of Technical Information Extension, Oak Ridge	1
Atomic Industrial Forum, Reactor Safety Committee	1
Atomics International	3
Battelle Memorial Institute	3
Bechtel Corporation, FFTF Project	3
Brookhaven National Laboratory	1
California Institute of Technology, Pasadena	1
Environmental Protection Agency, Division of Surveillance and Inspection, Winchester	1
Environmental Protection Agency, Eastern Environmental Radiation Laboratory, Montgomery	1
Environmental Protection Agency, National Environmental Research Center, Cincinnati	1
Environmental Protection Agency, Office for Air Programs, Rockville	2
Environmental Protection Agency, Office of Radiation Programs, Rockville	11
Environmental Protection Agency, Western Environmental Research Laboratory, Las Vegas	1
General Electric Corporation, Atomic Power Equipment Department	1

Iowa State College	1
Johns Hopkins University	1
Knolls Atomic Power Laboratory	1
Los Alamos Scientific Laboratory	1
MFR Associates, Library	1
Mine Safety Appliances	1
Monsanto Research Corporation	1
North American Carbon, Inc.	1
National Lead Company of Ohio	1
Naval Research Laboratory	5
Oak Ridge National Laboratory, Chemical Technical Division	2
Oak Ridge National Laboratory, Nuclear Safety Program Office	2
Oak Ridge National Laboratory, Nuclear Safety Information Center	1
Pacific Northwest Laboratories, Battelle Memorial Institute	7
Savannah River Laboratories	1
Teledyne Isotopes	1
Union Carbide Corporation	1
U.S. Bureau of Mines	1
University of California, Lawrence Berkeley Laboratory	1
WADCO, FFTF Project	3
Westinghouse Electric Corporation, Atomic Power Division	1
Westinghouse Electric Corporation, Research and Development Center	1
World Health Organization, Environmental Pollution Unit	1

COO-3019-8

UNCLASSIFIED

Harvard Air Cleaning Laboratory
School of Public Health
Harvard University
665 Huntington Avenue
Boston, Massachusetts 02115

MASTER

COO-3019-8

SEMIANNUAL PROGRESS REPORT

January 1 - June 30, 1973

M. W. First, A. Goldin,

R. R. Hall,

D. W. Underhill and D. W. Moeller

Report Issued December, 1973

Prepared for the United States Atomic Energy Commission,
Division of Reactor Development and Technology, under Contract
Number AT(11-1)3019

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

SUMMARY

A hermetic gas booster was tested on a prolonged sodium oxide and sodium metal aerosol load. The blower performed well under the tested conditions and was capable of maintaining a flow of 1400 SCFM at over 30 inches of water gauge. When switching from low to high speed, a gas flow control valve must be closed or the flow will exceed 1700 SCFM and the fan will be overloaded. The amount of sodium deposited in the 8 and 12 inch diameter ducts leading to and from the blowers was determined. These results give better data than can be predicted by theory.

Studies of the adsorption of krypton and xenon from argon were extended to low partial pressures of argon to determine the shape of the curve of adsorption coefficient vs. argon loading of charcoal at low loadings. It was found that the fall-off of adsorption was extremely rapid even with very low loadings. The adsorption of the fission noble gases from nitrogen was also studied. General trends were similar to those noted in adsorption from argon and numerical values were not markedly different. The Polanyi adsorption theory was found useful in explaining the results from both argon and nitrogen. Adsorption from air and from a 60:20:20 mixture of nitrogen-argon-oxygen was substantially the same as for nitrogen.

The effect of decay heat on the operation of a fission gas holdup bed was examined using a one dimensional model which is valid for the case of a small temperature increase. The effects of axial and radial heat conduction, convection, and radiodecay on bed temperature were taken into account in both the analytical solution and the numerical analysis. An important conclusion is that a significant temperature rise can result from a fairly small, but constant, input of fission gas.

TABLE OF CONTENTS

	<u>Page No.</u>
Summary	v
List of Figures	vii
List of Tables	viii
Deposition of Sodium Aerosols in Centrifugal Blowers	1
Introduction	1
Experimental Arrangement	2
Procedure	5
Results	6
Adsorption of Fission Noble Gases on Activated Charcoal	16
Introduction	16
Adsorption from Argon	16
Adsorption of Krypton and Xenon from Nitrogen	20
Adsorption of Krypton and Xenon from Air and from Argon-Nitrogen-Oxygen Mixture	28
Discussion and Future Work	31
Theoretical Evaluations of the Effects of Decay Heat on Holdup Bed Efficiency	34
Introduction	34
Analysis	34
Future Work	37
References	41

LIST OF FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page No.</u>
1	Experimental equipment for sodium deposition studies	3
2	Thermocouple imbedded in motor fin	3
3	Sodium aerosol deposits on blower motor	3
4	Sodium aerosol deposits in motor compartment	9
5	Sodium aerosol deposits in impeller compartment	9
6	Effect of Argon loading on Krypton adsorption	19
7	Effect of pressure on Argon adsorption	22
8	Variation of Kr and Xe adsorption with pressure	24
9	Temperature variation of adsorption of Kr and Xe	25
10	Polanyi plot for Nitrogen adsorption on charcoal	27
11	Effect of Nitrogen loading on Krypton adsorption	29
12	Calculated temperature increase from fission gas input as a function of time and axial distance	38

LIST OF TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page No.</u>
1	Sodium Deposited on Blower Parts	8
2	Gas and Motor Casing Temperatures During the Third Experiment	11
3	Blower Performance and Test Conditions	13
4	Sodium Deposited in Pipes and Blower as % of Total Sodium Passed Through the System	15
5	Adsorption of Noble Gases from Argon	18
6	Adsorption of Argon	21
7	Adsorption of Noble Gases from Nitrogen	23
8	Adsorption of Noble Gases from Air	30
9	Adsorption of Noble Gases from Nitrogen-Argon-Oxygen	32
10	Values Used to Calculate Temperature Increase in a Fission Gas Adsorption Bed	39
11	Comparison of Numeric and Analytic Solutions for the Average Increase Resulting from Decay Heat	40

I. Deposition of Sodium Aerosols in Centrifugal Blowers

M. W. First and R. R. Hall

A. Introduction

Our previous reports (1-4) described laboratory investigations of the rate of deposition of freshly generated sodium aerosol particles in filters, ducts, and heat exchangers. This report covers investigations of sodium aerosol particle deposition in a full-scale centrifugal blower selected for service in the recirculating cooling systems of closed loop cells of the FFTF and in the duct leading into and away from the blower.

Closed loop cells in the FFTF contain major sodium recirculation equipment and must be cooled to protect the machinery enclosed in the space from overheating. Plans call for the atmosphere inside the cell to be nitrogen with no more than 1% oxygen. This atmosphere will be recirculated continuously through an external heat exchanger by a centrifugal blower. Because leakage of molten sodium from the equipment inside the closed loop cell will generate sodium oxide aerosols and metallic sodium aerosols when the sodium spill is of sufficient magnitude to consume all available oxygen in the sealed space, the system must be protected from excessive deposition of aerosol particles in the heat

exchanger and blower if the cooling function is to be maintained during and after a spill.

B. Experimental Arrangement

Sodium oxide aerosol was generated in a 3300 ft³ chamber containing less than 1.2% oxygen; the remainder being nitrogen. In our previous experiments, a rectangular steel pot with four 2000-watt electrical heaters imbedded in the bottom was used to evaporate about 5 pounds of sodium per experiment. For this series, a second pot was needed to make it possible to evaporate 12 pounds of sodium. The new pot was constructed with heaters imbedded in the sides of the pot instead of in the bottom, as previously, because it was observed that a thick scale-like deposit of oxide formed on the bottom of the sodium evaporation pot and interfered seriously with heat transfer from the heaters to the molten sodium pool. When this occurred, the resistance heaters overheated and burned out rapidly. Details of the aerosol chamber and the manner of generating sodium aerosols can be found in our previous reports.

Figure 1 is a photograph of the system used to test aerosol deposition in the recirculating blower. To the right of the picture is the wall of the chamber in which the aerosol was generated. The fan that was tested, a Spencer Gas Booster, catalog number GH-1010-HMOD, is in the center with

FIGURE 1 Experimental equipment for sodium deposition studies

FIGURE 2 Thermocouple imbedded in motor fin

FIGURE 3 Sodium aerosol deposits on blower motor

the discharge in front. Aerosol was recirculated from the top of the aerosol chamber to the blower and returned to the bottom of the chamber through large black iron pipes. These were 8- and 12-inch diameter, thin walled, flanged steel pipes with 1/4-inch O-ring gaskets between the flanges. Richer Controls Company's 12-inch butterfly valves were used at the two chamber ports to seal the chamber when aerosol was not recirculated. The entry valve can be seen in the upper right hand corner of the picture. A port for aerosol loading and particle size sampling was located in the 8-inch diameter vertical pipe entering the blower. It can be seen in the photograph behind the vertical perforated angle brace. Pressure taps were installed before and after the blower to measure pressure increase across the fan as a signal that deposition was occurring. The pressure change across the 8-to-12-inch expansion piece located above the fan outlet was used to measure the gas flow rate after it had been calibrated by pilot-static tube traverses. A second sampling port, located in the 12-inch horizontal discharge pipe, may be seen in the foreground of the picture.

Gas temperature was measured by thermometer before and after the blower. Amperage drawn by the blower motor was measured with an Amprobe meter. Two thermocouples

installed in the motor housing, shown in Figure 2, were used to monitor temperature rise in the motor in response to the insulating effect of deposited aerosol particles. A gas chromatograph was used to monitor oxygen concentration.

C. Procedure

The first step was to charge sodium metal to the evaporation pots. This was done by pushing slices from one pound bars of sodium metal through 2-inch diameter ports in the chamber wall and allowing them to fall into the pots below. The metal was heated to 1600°F. After an opaque white cloud (approximately 1 g/m³, expressed as elemental sodium) had formed in the chamber, the blower was started. During all experiments the butterfly valve at the inlet side of the blower remained fully open and the return air butterfly valve was used to maintain gas flow at 1400 SCFM. For 1400 SCFM, the control valve was less than 1/4 open. Running time for each of this series of experiments was from 3 to 10 hours at constant gas flow rate.

During the early part of each experiment, the aerosol particles were sodium oxide, but later all of the oxygen was consumed and sodium metal aerosol particles formed that deposited in the system. Therefore, before the piping and fan could be disassembled safely, the deposited sodium metal had to be converted to a safe compound.

Therefore, sodium metal was reacted with a recirculated stream of nitrogen containing water vapor and carbon dioxide to form sodium carbonate and hydrogen according to the following reaction:

A hydrogen meter was used to measure the generated hydrogen. When no more hydrogen was being generated, the reaction was complete. This procedure worked well. It was described in detail in a previous report.⁽⁵⁾

After all of the sodium metal had reacted, the system was disassembled. Parts of the fan were washed with measured volumes of distilled water and the wash water analyzed by flame photometry to measure the amount of sodium deposited on each part. Each piece of pipe was analyzed in a similar manner for deposited sodium.

D. Results

Blower performance during three experimental runs was similar. At the start, the pressure drop across the blower averaged 35.5 in.w.g. During the experiments, pressure across the blower tended to drop slightly in response to increasing temperature of the recirculating gas. It averaged 32.9 in.w.g. at the end. Gas temperature at fan exit was 18-21.5°F higher than at the blower entrance and reached a maximum of 150°F. No problems were encountered

in maintaining a constant flow of 1400 SCFM. /

The quantity of aerosol that passed through the recirculation loop varied. The first experiment, run for 313 min. at 1400 SCFM, had an average aerosol loading of 2.5 gNa/m^3 . Therefore, a total of 30,000 grams of sodium went through the system. One of the O-ring gaskets slipped during the second experiment, causing a large air leak, and it had to be terminated after only 184 minutes of running time. The average loading during the second experiment was 1.21 gNa/m^3 and 8,600 grams of sodium went through the system. The final experiment was run for 621 minutes. The average loading was 1.05 gNa/m^3 and 25,000 grams of sodium passed through the system. Blower performance, as measured by air volume rate, pressure development, and current draw, was unaffected throughout each experiment.

A total of 620 grams of sodium was deposited in the blower during the first experiment. A very large percentage, 71%, of the deposited sodium was on the cylindrical fan housing, the motor, and the center divider. The amounts of sodium deposited on the several interior parts of the blower are listed in Table 1. Figures 3 and 4 show sodium deposits on the fan motor after they had been converted to Na_2CO_3 . Only 11.6 grams of sodium, 1.9% of the total deposit, was found on the fan impeller. Visual inspection, Figure 5, of the area near the fan impeller and of the

SODIUM DEPOSITED ON BLOWER PARTS

TABLE 1

	Grams Na	% of Blower Deposit	% of Na Throughput
1. Entrance head plate	17.2	2.8	0.06
2. Cylindrical blower housing, motor and deflector	444	71	1.5
3. Impeller	11.6	1.9	0.04
4. Deflector and piece between impeller and spacer	75 - 100	16.3	0.33
5. Exit head plate and spacer	49.6	<u>8.0</u>	<u>0.17</u>
		100.0	2.10

FIGURE 4 Sodium aerosol deposits in motor compartment

FIGURE 5 Sodium aerosol deposits in impeller compartment

fan impeller itself confirm the small amount of sodium deposited in this area and indicate that sodium deposition on the impeller should not be a problem in the FFTF closed loop recirculation systems.

Additional data were collected on the performance of the blower motor, a totally enclosed, 3 phase, 480 volt, 15 horsepower, two speed motor. During these experiments the motor was run only at high speed, 3600 RPM. Motor current was measured between 14.8 and 15.8 amperes; variations were attributed to flow adjustments to compensate for gas temperature changes during the experiments. The two thermocouples in the blower motor casing, shown in Figure 2, gave identical temperature readings. Temperature rose from 72°F to 162°F during the first 130 minutes of operation. After a total of 621 minutes running time, the motor casing temperature was 191°F, 95°F above the gas temperature. When the motor was turned off, the motor casing temperature went over 212°F. A rise in temperature after the motor was shut off indicates that the motor core temperature was over 212°F. Table 2 lists the rise in motor temperature and simultaneous inlet and outlet gas temperatures.

A malfunctioning flowmeter resulted in the termination of the first experiment after 312 minutes. When the flowmeter falsely indicated a flow rate below 1400 SCFM and the control valve was opened to admit more air to the system, the motor

GAS AND MOTOR CASING TEMPERATURES
DURING THE THIRD EXPERIMENT

TABLE 2

Time from Start min	Inlet Gas Temperature °C	Motor Casing Temperature °C	Outlet Gas Temperature °C
0	22	22	22
13	--	--	45
28	38	49	50
78	45	64	--
130	48	72	61
184	49	76	61
245	50	80	62
309	50.5	82	62
411	52	86	63
474-487 Blower turned off		92	
518	53	87.5	64
552	53	88	64
634 Blower turned off	53	88	65
		>100	

became overloaded and shut off, ending the experiment. During later experiments it was found that the flowmeter pressure taps tended to plug and produce false flow readings. The characteristics of this type of blower are such that the 15 horsepower motor was overloaded when the flow exceeded 1700 SCFM. Table 3 is a summary of blower performance and test conditions during the three experiments.

Sodium oxide aerosol was formed at the beginning of each experiment but during the later stages the aerosol particles were metallic sodium. The change in composition was evidenced by a change in the color of the aerosol from white to dark grey. Immediately after the first experiment, a part of the piping system was opened and, upon contact with the air, the deposit began to burn. The system was resealed promptly with a nitrogen atmosphere and the sodium was reacted to the carbonate form in the manner previously noted. A change to sodium metal aerosol was observed about half way through the first and second experiments. Oxygen concentration for the first experiment was 1.2% at the start and 0.34% at the end. For the second experiment, it was 1.15% at the start and 0.55% at the end. During the third experiment, oxygen was added periodically to the chamber to avoid the formation of sodium metal aerosol. The percent oxygen in the chamber was maintained between 0.7% and 1.2%, averaging 0.9%. However, after about three hours, the aerosol became grey and remained grey during the remainder of the experiment.

BLOWER PERFORMANCE AND TEST CONDITIONS

TABLE 3

	Experiment No.		
	1 2/22/73	2 3/12/73	3 3/28/73
Flow - SCFM	1,400	1,400	1,400
Running Time - min.	313	184	621
Blower Pressure Drop-in.w.g.			
Start	34.3	35.2	36.8
End	32.3	33.0 at 13 ⁴ min	33.5
Motor Amps			
Start	--	14.8 - 15.2	15.2 - 15.8
End	--	14.8 - 15.2	15.2 - 15.8
Gas Temp. at End-°C			
Fan inlet	--	51.5 at 147 min	53
Fan outlet	>60	61	65
Motor Casing Temp. at End-°C	--	--	88
Average Loading gNa/m ³	2.5	1.21	1.05
Grams Na Put Through System	30,000	8,600	25,000
Oxygen - %			
Start	1.2	1.15	1.05
End	0.3	0.55 at 15 ⁴ min	1.05 (O ₂ was added)

Particle deposition in the ducts leading to and from the blower was measured. (These measurements were made so that radiation exposures to workers required to perform emergency procedures in the vicinity could be calculated. Table 4 lists the total amount of sodium that passed through the system and the percent deposited in each piece of pipe during each experiment. Also listed, is the average percent deposited. Because the percent of sodium deposited in the several sections varied widely from experiment to experiment, the most reliable figure is thought to be the average percent deposited. This is listed in the last column of Table 4. Variations in the percent of sodium deposited can be attributed to flow disturbances caused by poorly fitting flanges that differed slightly between experiments and loss of deposited sodium during the reaction period and during disassembly.

SODIUM DEPOSITED IN PIPES AND BLOWER
AS % OF TOTAL SODIUM
THAT PASSED THROUGH THE SYSTEM

TABLE 4

Parts Listed from Inlet to Outlet	2/22/73 %	3/12/73 %	3/28/73 %	Average %
1. Valve face, 12" spool piece, 12" elbow and 12" x 8" reducer	0.052	0.10	0.10	0.084
2. 8" x 62" downpipe	0.052	0.17	0.064	0.095
3. 8" elbow	0.029	0.058	0.067	0.051
4. 8" x 16-1/2" inlet pipe to blower	0.027	0.022	0.022	0.024
5. Blower	2.2	7.65	3.14	4.3
6. 8" x 54" exit pipe from blower	0.096	0.14	See #14	0.12
7. 8" x 12" expanding section	0.025	0.035	See #14	0.030
8. 12" elbow above blower	0.027	0.023	See #14	0.025
9. 12" x 61" overhead pipe	0.056	0.036	0.054	0.049
10. 12" elbow	0.027	0.019	0.026	0.024
11. 12" x 69" downpipe	0.038	0.087	0.053	0.059
12. 12" elbow	0.025	0.074	0.060	0.053
13. 12" x 138" test section	0.10	0.28	0.17	0.183
14. Total of 6,7, and 8	0.148	0.198	0.24	0.20
Total Sodium Throughput, grams	30,000	8,600	25,000	

II. Adsorption of Fission Noble Gases On Activated Charcoal

A. S. Goldin and H. A. Trindade*

A. Introduction

Recent work at the Harvard School of Public Health on the adsorption of fission noble gases on charcoal has been concentrated on adsorption from argon at high pressures and low temperatures.^(3,4) By applying the Polanyi adsorption theory⁽⁶⁾, we have shown that large reductions in adsorption result from coverage of a relatively small fraction of the charcoal with carrier molecules.

Data obtained on very small beds at Harvard have been in good agreement with those obtained by Kabele⁽⁷⁾ on pilot plant sized equipment. This gives us confidence in the validity of laboratory data for design purposes.

B. Adsorption from Argon

Adsorption of fission product xenon and krypton on activated carbon from argon carrier gas has been reported in our last two progress reports. Anomalous behavior at low temperatures and high pressures was reported by Ratney and Underhill.⁽³⁾ This anomaly consisted of abnormally low and even negative slopes of the adsorption coefficient vs. pressure curves, especially at low temperatures. This was

* Universidade Federal Do Rio De Janeiro, Rio de Janeiro, Brazil

explained by Underhill, Goldin, and Trindade⁽⁴⁾ as being due to increased occupation of adsorption sites by liquid (or quasi-liquid) argon and consequent competition between fission gas and argon at the high pressures and low temperatures involved. The Polanyi adsorption theory⁽⁶⁾ was used to calculate the argon adsorption.

During the current period, this work was extended to lower partial pressures of argon. These results, with a few additional new data points at higher partial pressures, are listed in Table 5. The low partial pressures were obtained by 3:1 dilution with helium so that the pressure of argon at a total pressure of 5 psig was 0.34 atmospheres (absolute). Figure 6 shows the variation of the pressure normalized adsorption coefficient of krypton as a function of the volume of argon adsorbed on the charcoal. The value for zero coverage was taken from data on the adsorption of krypton from helium. Figure 6 may be compared with Figure 2-7 of reference (4). It will be seen that the added data at low partial pressures of argon define the left hand side of the curves more accurately and show the extremely rapid decrease in adsorption coefficient with initial argon loading of the charcoal.

The adsorption of argon itself is of interest for the hold-up of argon-41. Values of argon adsorption coefficients at temperatures from -75°C to -140°C and pressures from 1.3

TABLE 5

Adsorption of Noble Gases from Argon

KRYPTON			XENON		
Temp. °C	Absolute Pressure atm	Adsorption Coefficient l(STP)/g	Temp. °C	Absolute Pressure atm	Adsorption Coefficient l(STP)/g
-140	0.34*	32.9			
-120	0.34*	14.8			
-100	0.34*	6.93			
-20	3.04	0.33			
+23	1.29	0.061	+22	3.04	1.83
+24	3.04	0.123			

*0.34 atmospheres partial pressure of Ar, from a 25:75 Ar-He mixture at 5 psig (=1.34 atm)

FIGURE 6 EFFECT OF ARGON LOADING ON KRYPTON ADSORPTION

to 10 atmospheres have been reported⁽⁴⁾. These values were extended to ambient (+25°C) temperatures and all are listed in Table 6. The points at -78°C, +25°C, and 0.34 atmospheres have not been previously reported. All these data are plotted in Figure 7. The greater slope of the pressure dependence curve at ambient temperature is apparent.

C. Adsorption of Krypton and Xenon from Nitrogen

In some FFTF environments, nitrogen can become contaminated with fission kryptons and xenons. Experiments were accordingly performed to determine the characteristics of adsorption of these gases from nitrogen. These experiments were carried out from ambient temperature down to -100°C and at pressures from 1.3 atmospheres (5 psig) to 5.76 atmospheres (70 psig). Xenon measurements were not made at temperatures below -50°C. These results are given in Table 7. Figure 8 shows the adsorption coefficients for both elements as a function of pressure for the various temperatures. The decrease in pressure dependence at the lower temperatures is clearly shown. The adsorption coefficients of krypton and xenon from nitrogen are not very different from those obtained for these elements from argon carrier gas. These relationships are shown a little more clearly in Figure 9 in which the adsorption coefficients at 1.3 atmospheres and 3.0 atmospheres are plotted against $1/T$.

The Polanyi procedure, which had been successful in correlating the adsorption data of krypton over a wide range

TABLE 6
Adsorption of Argon

Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g	Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g
-140	0.34*	0.194	-75	0.34*	0.032
	1.68	0.257		3.72	0.119
	3.72	0.284		5.76	0.136
	5.76	0.287		7.79	0.159
	7.79	0.294		10.51	0.174
	10.51	0.307	-78	5.76	0.140
-120	0.34*	0.118		7.79	0.155
-115	1.34	0.176		1.00	0.0055
	1.68	0.181	+25	3.72	0.020
	3.72	0.214		6.44	0.032
	5.76	0.235		10.54	0.049
	7.79	0.243			
	10.51	0.256			
	0.34*	0.068			
-100	1.68	0.139			
	3.72	0.174			
	5.76	0.190			
	7.11	0.200			
	10.51	0.217			

*0.34 atmospheres partial pressure of Ar, from a 25:75 Ar-He mixture at 5 psig (=1.34 atm)

FIGURE 7

EFFECT OF PRESSURE ON ARGON ADSORPTION

TABLE 7

Adsorption of Noble Gases from Nitrogen

KRYPTON			XENON		
Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g	Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g
-100	1.29	2.07	-50	1.29	17.9
	1.95	2.40		3.04	21.0
	3.04	2.58			
	5.76	2.80			
-50	1.29	0.42	-20	1.29	4.73
	2.00	0.53		2.00	5.94
	3.04	0.62		3.04	6.79
-20	1.29	0.18	+22	1.29	0.97
	1.68	0.22		2.00	1.27
	2.90	0.29		3.04	1.62
+25	1.29	0.061			
	2.00	0.085			
	3.04	0.115			

FIGURE 8

VARIATION OF KR AND XE ADSORPTION WITH PRESSURE

FIGURE 9

TEMPERATURE VARIATION OF ADSORPTION OF KR AND XE

of temperature and pressure, was applied to the adsorption from nitrogen. Necessary data were obtained by measuring the adsorption of nitrogen on activated charcoal at various temperatures and pressures. The charcoal bed was brought to equilibrium with nitrogen at the temperature and pressure of interest, and then the volume of nitrogen desorbed when the bed was allowed to come to room temperature and pressure was measured. A correction was applied for residual adsorption at room temperature and pressure and for dead space in the bed. The results are shown in Figure 10. The ordinate is the volume of nitrogen adsorbed per 100 grams of charcoal expressed as cubic centimeters of liquid nitrogen at the temperature at which the vapor pressure would be equal to the adsorption pressure. The abscissa is $(T/V_b) \log_{10}(f_s/f)$ in which T is the absolute temperature, $^{\circ}\text{K}$; V_b is the molar volume of liquefied nitrogen at the adsorption pressure, cm^3 ; and f_s and f are the fugacities of nitrogen liquid at adsorption temperature and of the nitrogen gas, respectively. Since the measurements were made above the critical temperature of nitrogen, pressure and fugacity of the liquid phase were obtained by extrapolation.

The nitrogen loading data of Figure 10 were used to correlate the adsorption data of krypton from nitrogen. To do this, the adsorption coefficients (normalized to unit pressure) were plotted against the volume of liquid (or quasi-liquid) nitrogen adsorbed at the particular temperature

FIGURE 10

NITROGEN ADSORPTION

POLANYI PLOT FOR NITROGEN ADSORPTION ON CHARCOAL

and pressure. These data are presented in Figure 11. As in Figure 6, the zero coverage point was obtained from helium cover gas data. One curve for adsorption from argon (at -100°C) is included for comparison. The general similarity in shape of the curves relating krypton adsorption coefficients to coverage of charcoal by liquid nitrogen (Figure 11) to those relating coefficients to coverage by liquid argon (Figure 6) is striking. In both sets of curves, there is a very marked decrease in noble gas adsorption with initial coverage of the charcoal, followed by a much slower decrease with further coverage. The difference between the argon curve at -100°C and the nitrogen curve at -100°C , although small, is real. It had been our hope that these curves of krypton adsorption vs. coverage would be identical for different gases, and so useable for prediction, but this hope was not fulfilled.

D. Adsorption of Krypton and Xenon from Air and from Argon-Nitrogen-Oxygen Mixture

Some inleakage of air into the nitrogen cover gas which was the concern of the previous section must be expected. Accordingly the adsorption of krypton and xenon from mixtures of nitrogen and oxygen ranging from 0 to 20% oxygen could be important. Initial measurements were made with 20% oxygen (air). Table 8 gives these data. The adsorption was found to be not significantly different from that observed from nitrogen carrier gas. Accordingly, it was concluded that the adsorptions from nitrogen and from nitrogen-oxygen mix-

FIGURE 11 EFFECT OF NITROGEN LOADING ON KRYPTON ADSORPTION

TABLE 8

Adsorption of Noble Gases from Air

KRYPTON			XENON		
Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g	Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g
-50	1.29	0.45	-50	1.29	17.2
	3.04	0.64		3.04	19.7
+25	1.29	0.060	-20	1.29	4.73
	2.00	0.088		3.04	6.79
	3.04	0.115	+22	1.29	0.96
				3.04	1.70

tures, at least over the range of concern, were essentially equivalent, and no experiments on intermediate mixtures were made.

Some measurements were also made of the adsorption of the two noble gas elements from a 60:20:20 mixture of nitrogen-argon-oxygen. The similarity in adsorption coefficients between argon and nitrogen and the identity between the coefficients from nitrogen and from air led us to expect little or no difference in adsorption from this mixture, as compared with nitrogen. Early data, presented in Table 9, confirmed these expectations, and accordingly the experiments were terminated.

E. Discussion and Future Work

The investigations of fission gas adsorption on charcoal have been directed towards hold-up of the gases on a bed for delay. This concept is useful for short-lived nuclides such as all the radiokryptons except krypton-85 (longest half-life = 28 hours) and for essentially all the radioxenons. Xenon 133 has a 5.3 day half-life, but xenon is retained better than krypton. Xenon-129m and xenon-131m, with half-lives of 8.0 and 12.0 days respectively, are produced in very small yields.

The removal of krypton-85 from effluents, especially from fuel reprocessing effluents, has been suggested often, beginning in the middle to late 1950's^(8,9,10). Several processes have been investigated for the separation, including low-temperature adsorption on charcoal⁽¹¹⁾, absorption in organic

TABLE 9

Adsorption of Noble Gases from Nitrogen-Argon-Oxygen
(60:20:20)

KRYPTON			XENON		
Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g	Temp. °C	Absolute Pressure atm	Adsorption Coefficient 1(STP)/g
-70	3.04	1.14			
-20	3.04	0.31	-20	3.04	7.16
+24	3.04	0.121	+22	3.04	1.72

solvents⁽¹⁰⁾, cryogenic distillation⁽¹²⁾, and passage through permselective membranes⁽¹³⁾. Removal by pressure swing sorption-desorption appears to offer advantages in simplicity of equipment and operation. The technique has been applied for "heatless drying" of air⁽¹³⁾ and a preliminary application to concentration of krypton-85 has been reported⁽¹⁴⁾. Briefly, the technique involves a four-step cycle: (1) pressurization of bed with carrier gas, (2) passage of high pressure contaminated carrier gas until just before breakthrough, (3) depressurization, and (4) backwash with clean carrier gas at low (atmospheric) pressure to remove all contaminant in concentrated form. The clean carrier gas produced in step (2) is divided into two parts (a) a pure "product" which in this case can be discharged to the environment, and (b) the backflush carrier for step (4). Investigations of feasibility with both charcoal and inorganic beds are in process.

III. Theoretical Evaluations of the Effects of Decay Heat on Holdup Bed Efficiency

D. W. Underhill

A. Introduction

There is at present no complete mathematical solution available for calculation of the temperature rise in a fission gas holdup bed. The basic difficulty is the nonlinear effect of temperature on the adsorption coefficient. Glueckauf (1959) found an analytic solution for a nonlinear radial distribution of fission gas resulting from the radial temperature distribution, but this solution neglects other factors, including the channeling of hot gases through the center of the bed making it less useful than would first appear.

B. Analysis

Our analysis began with the following differential equation (First, et al. 1970) which gives the effects of radial and axial heat conduction, convection, and radioactive decay on the average bed temperature at a distance, x , from the inlet.

$$k \frac{\partial^2 t_I}{\partial x^2} - v \frac{\partial t_I}{\partial x} - \beta t_I + q_I e^{-\alpha_I x} = \rho C_k \frac{\partial t_I}{\partial \tau}$$

where C_k = heat capacity of charcoal, cal/gm-°C

C_p = heat capacity of carrier gas at constant pressure, cal/cm³-°C

k = thermal conductivity of the charcoal, cal/cm-sec-°C

K = adsorption coefficient for fission gas,
cm³/gm

q_I = production of decay heat per unit volume
of bed from the I^{th} isotope at the inlet,
cal/cm³-sec

t_I = average temperature increase resulting
from the decay of the I^{th} isotope, °C

V_s = superficial carrier gas velocity, cm/sec

x = distance from inlet of bed, cm

α_I = linear decay coefficient for the I^{th}
isotope, cm⁻¹
= $\lambda p K / V_s$

β = coefficient for radial heat loss, cal/cm³-
sec-°C

For an infinite cylinder, $\beta = 2k/r^2$.

γ = convection coefficient, cal/cm²-sec-°C
= $C_p \cdot V_s$

λ = isotopic decay coefficient, sec⁻¹

ρ = bulk density of charcoal, gm/cm³

τ = time, sec

Assuming that the temperature rise is small, the
adsorption coefficient will remain constant across the bed. At
steady state, $\frac{\partial t}{\partial \tau} I = 0$ and the above differential equation
can be integrated to give

$$t_I = \frac{q_I}{\beta - \alpha_I \gamma - \{\alpha_I\}^2 k} \{e^{-\alpha_I x} - e^{(\sqrt{\gamma^2 + 4\beta k} - \gamma) x / 2k}\}.$$

A general solution to the problem of decay heat
can be obtained by numerical analysis with a digital computer.

At present we have only a one dimension model with a constant adsorption coefficient, i.e., a numerical equivalent of the analytical solution we have just described. These computer calculations replace the differential equation with the following difference equation for $t_I(x)$, the temperature increase resulting from decay of the I^{th} isotope at a distance, x , from the inlet.

$$k \{t_I(x-\Delta x) + t_I^*(x-\Delta x) - 2t_I(x) - 2t_I^*(x) + t_I(x+\Delta x) + t_I^*(x+\Delta x)\} / 2\Delta x^2 - \gamma \{t_I(x+\Delta x) + t_I^*(x+\Delta x) - t_I(x-\Delta x) - t_I^*(x-\Delta x)\} / 4\Delta x - b \{t_I(x) + t_I^*(x)\} / 2 + q_I e^{-\alpha_I x} = \rho C_K \{t_I^*(x) - t_I(x)\} \Delta \tau$$

where Δx = incremental distance, cm

$\Delta \tau$ = incremental time, sec

$t_I^*(x) = t_I(x)$ at time $\tau + \Delta \tau$

The set of simultaneous equations describing the temperature increase across the bed is then solved by use of the tridiagonal matrix procedure described by Westlake (1968). We assumed, in making these computer calculations, that both the inlet and effluent gas temperatures were controlled by coming into contact with cold walls; in contrast, the analytical model discussed earlier assumed a semi-infinite adsorption bed with only one cold end. Figure 12 shows the heating in an adsorption bed following a steady state input of a fission gas mixture in an argon carrier gas starting

at time $\tau=0$. The numerical values used in this calculation are listed in Table 10. Table 11 gives a comparison between the steady state numerical and analytical solution. Where the difference in boundary conditions can be ignored, the agreement is quite close.

C. Future Work

It would be useful to extend this numerical analysis to a more general analysis which can take into account the difference in the adsorption coefficient brought about by radial and axial heating. A particularly interesting result would be to extend this model to the point where it can be used to follow the effect of a sudden release of a large number of curies of fission gas isotopes into an adsorption bed.

FIGURE 12

**CALCULATED TEMPERATURE INCREASE FROM
FISSION GAS INPUT AS A FUNCTION OF
TIME AND AXIAL DISTANCE.**

Table 10

VALUES USED TO CALCULATE TEMPERATURE INCREASE
IN A FISSION GAS ADSORPTION BED

Bed Length = 310 cm

Bed Diameter = 90 cm

Thermal conductivity of Argon + Charcoal = 0.00021 cal/cm-sec-°C

Heat Capacity (per unit volume)

of Charcoal	0.085 cal/cm ³ -°C
of Argon	0.000194 cal/cm ³ -°C

Adsorption Coefficient (volume/volume)

for Krypton	14 cc/cc
for Xenon	250 cc/cc

Flow of Argon 1610 cc/sec

Fission Gas Data:

Isotope	Curies Released per day	Initial volume production of decay heat, q_I cal/cc-sec $\times 10^{-8}$	Linear decay constant α_I $\text{cm}^{-1} \times 10^{-4}$
Xe-131m	1.392	0.055	66.8
Xe-133m	.03369	1.9	34.8
Xe-133	676.50	29	15.1
Xe-135	3420	481	20.90
Kr-83m	235.86	0.27	118
Kr-85m	391.50	5.2	50
Kr-85	.026	0.000183	0.0023
Kr-87	679.20	46	160
Kr-88	824.40	53	78.5

Incremental distance = 1 cm

Incremental time = 15,000 sec

Table 11

COMPARISON OF NUMERIC AND ANALYTIC SOLUTIONS FOR
THE AVERAGE INCREASE RESULTING FROM DECAY HEAT

Note: For numeric analysis $\Delta x = 1$ cm and $\Delta t = 15,000$ sec
See text for boundary conditions.

<u>Distance from Inlet, cm</u>	<u>Calculated Temperature Increase °C</u>	
	Numeric	Analytic
0	0.0	0.0
1	11.52	11.52
2	22.78	22.79
10	104.79	104.80
100	462.22	462.39
200	453.67	458.39
300	353.74	389.93
309	81.16	383.34
310	0.0	382.61

REFERENCES

1. First, M. W., Underhill, D.W., Tadmor, J., Hall, R.R., Ratney, R.S., Baldwin, T.W., and Moeller, D.W., "Semi-annual Progress Report, Harvard Air Cleaning Laboratory", March 1, 1971-August 31, 1971, Report Number NYO-841-25, issued November, 1971, Boston, Mass.
2. First, M.W., Underhill, D.W., Hall, R.R., Baldwin, T.W., and Moeller, D.W., "Semiannual Progress Report, Harvard Air Cleaning Laboratory", September 1, 1971-February 29, 1972, Report Number COO-3019-1 issued April, 1972, Boston, Mass.
3. First, M.W., Underhill, D.W., Ratney, R.S., Jochem, E., Hall, R.R., Baldwin, T.W., and Moeller, D.W., "Semi-annual Progress Report, Harvard Air Cleaning Laboratory", March 1, 1972-August 31, 1972, Report Number COO-3019-3, issued October, 1972, Boston, Mass.
4. Underhill, D.W., Hall, R.R., Gold, A., Goldin, A., First, M.W., and Moeller, D.W., "Semiannual Progress Report, Harvard Air Cleaning Laboratory", September 1, 1972-December 31, 1972, Report Number COO-3019-4 issued February, 1973, Boston, Mass.
5. Viles, F.J., Jr., Himot, P., and First, M.W., "High Capacity - High Efficiency Filters for Sodium Aerosols", Report Number NYO-841-10, Harvard School of Public Health, August, 1967, Boston, Mass.
6. Young, D. and Crowell, A., "Physical Adsorption of Gases", Butterworths, London, (1962).
7. Ratney, R., and Underhill, D., "The Effect of High Pressure and Low Temperature on the Adsorption of Xenon and Krypton from Helium and Argon Streams", Proceedings of the 12th AEC Air Cleaning Conference, Oak Ridge, Tennessee, (August 28-31, 1972).
8. Glueckauf, E., "Long Term Aspect of Fission Product Disposal", in 1st International Conference on the Peaceful Uses of Atomic Energy, Vol 9, p. 3, United Nations, New York, (1956).

9. McIlroy, R.W., Glueckauf, E., de Nordwall, H.J., and Pummery, F.C.W., Proceedings of the 2nd International Conference on the Peaceful Uses of Atomic Energy, Vol. 18, pp. 190-199, United Nations, New York, (1958).
10. Steinberg, M. and Manowitz, B., BNL 493 (T-115), February, 1958.
11. Werner, L., DP-Report 290 AERE, Winfrith, England, March, 1965. (And many others).
12. Bendixsen, C.L., Offutt, G.F., and Wheeler, B.R., Trans. Am. Nucl. Soc. 12:497-8 (1969).
13. Skarstrom, C.W., U.S. Patent No. 2,944,627.
14. Kawazoe, K. and Kawai, T., Kagaku Kogaku 37:288-294 (1973). (In Japanese with English summary.)