5986

19 flc
8-15-58

MASTER

~~FOR INTERNAL USE ONLY~~

ORNL
Central Files Number
58-6-83

REMOTE MAINTENANCE TOOLS CATALOG

DO NOT
PHOTOSTAT

OAK RIDGE NATIONAL LABORATORY
operated by
UNION CARBIDE CORPORATION
for the
U.S. ATOMIC ENERGY COMMISSION

APPROVED BY
PATENT DEPARTMENT
4-8-59 *W. Collins*
DATE SIGNATURE

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

~~FOR INTERNAL USE ONLY~~

ORNL
Central Files Number
CF-58-6-83

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

REMOTE MAINTENANCE TOOLS

CATALOG

Compiled by

Mechanical Department
Engineering and Mechanical Division
Oak Ridge National Laboratory

CATALOG No. 58

INTRODUCTION

This catalog has been compiled by the Mechanical Department, Engineering and Mechanical Division, Oak Ridge National Laboratory. Its purpose is to consolidate and disseminate information concerning remote maintenance tools which have been used at ORNL.

It is hoped that this catalog will serve two useful functions. First, it is intended to serve as a guide to groups confronted with remote maintenance problems as to what tools and tool designs are available which might be applicable to their needs. Second, it is intended to serve as a starting point for the modification or alteration of existing designs or the design of new tools for unique applications.

It is believed that use of this catalog will aid in eliminating some time, expense and duplication of effort which has occurred in the past as a result of lack of information on available tools and tool designs.

The information contained herein has been obtained from many sources in both the research and service divisions of ORNL who have had occasion to use remote maintenance tools. Due to many factors, such as field development of tools without formal design, complete information is not available on all tools. Nor was it possible to locate and include all the tools developed and used at ORNL over the past several years.

Since the utility of this catalog is largely dependent upon its completeness, the assistance of users is requested in making corrections and additions. Please return the following form.

SUGGESTION SHEET

If you have suggestions concerning the format of this catalog,
Or you have corrections concerning any of the items contained in
the catalog,
Or you have information concerning items which should be included
in the catalog because they might be of interest to others,
Or you desire further information on any item in the catalog,
Please contact the following, or return the information form below.

D. M. Shepherd
Bldg. 3022
Ext. 6686

To: Mechanical Department
Engineering and Mechanical Division
Building 3022, X-10

Date:

Subject: Remote Maintenance
Tools Catalog

From: _____

_____ Division
Bldg. _____
Tel. Ext. _____

Please contact me concerning:

- A suggestion on the catalog.
- A correction to the catalog.
- An item for inclusion in the catalog.
- Further information on a catalog item.
- Other (specify below)

INDEX

Introduction	ii
Suggestion Sheet	iii
<u>Handling Tools, General Purpose</u>	
(Manipulators, tongs and retriever tools)	
Ball Socket Manipulator	3
Cable Actuated Retriever Tool	5
Defilming Tongs	7
Extraman Manipulator, 1" Size	9
Extraman Manipulator, 2" Size	11
Handling Tongs for HRE	13
Hydraulic Retriever Tool	15
Magnetic Retriever Tool	17
Modified Wiggle Tong	19
Removable Tong Finger Pads for Manipulators	21
Ten Foot Tongs	23
Utility Tongs, 3 Ft.	25
Utility Tongs, 6 Ft.	27
<u>Handling Tools, Special Purpose</u>	
(Operator tools, locating tools, and tools requiring special adapters to receive them)	
Air Line "Snap-Tite" Disconnect Tool	29
Feed and Purge Pump Mover Tool	31
Fuel Handling Tool	33
Low-Pressure Valve Flange Spreader	35

INDEX

ORR Access Cover Lifting Hook	37
ORR Fuel Element and Reflector Handling Tool	39
ORR Reflector Plug Handling Tool	41
ORR Shim Rod Handling Tool	43
Power Lead Disconnect Tool	45
Small Handling Tool	47
Thermocouple Disconnect Tool	49
Utility Handling Tool	51
<u>Torque Tools, Wrenches</u>	
Chain Drive, Offset Socket Wrench	53
Flange Cover Wrench	55
Hydraulic Torque Wrench	57
Impact Wrench, Chicago Pneumatic	59
ORR Cover Plate Lug Wrench	61
Retrieving Socket Torque Wrench	63
Right Angle Drive Socket Wrench	65
Right Angle Starting Wrench	67
Torque Multiplier Wrench	69
29 Ft. Retrieving Socket Wrench	71
Universal Extension Wrench	73
<u>Cutting Tools and Crimping Tools</u>	
Crimping Tool	75
Cut-Off Saw for MTR Assemblies	77

INDEX

Remote Band Saw	79
Remote Portable Band Saw	81
Remote Power Hack Saw	83
Saw Attachment for Extension Arm	85
Thermocouple Wire Cut-Off Tool	87
Tube Crimping Tool	89
Tube Shearing Tool	91
Wire Cutting Tongs	93
<u>Viewing Equipment</u>	
Underwater Light and Plexiglass Viewing Box	95
Underwater Television Camera	97
<u>Miscellaneous Tools</u>	
HRT Maintenance Tools	99
HRT Maintenance Tools	101
Thermocouple and Power Lead	
Disconnect Board and Bolt Rack	103
Tool Float Assembly	105
Tube Cutter, Wire Cutter, Remote Wrench,	
Special Soldering Gun	107
<u>Specialized Hot Cell Equipment</u>	
Bakelite Dispenser	109
Cut-Off Wheel	111
Dymo Dispenser	113

INDEX

Intercell Transfer Unit	115
Lapping Machine	117
Metallographic Polishing Wheel	119
Mounting Press	121
Remote Controlled Lathe	123
Remote Controlled Milling Machine	125
Remote Metallograph	127
Ultrasonic Specimen Cleaner	129

Name of Tool: Ball Socket Manipulator

Description: This tool is designed to operate through a 10 in. square opening in an 8 in. thick shielding wall. The body of the tool is 5/8 in. O.D. tubing. Overall length is approximately 4 ft. The pincer type tongs are actuated by a pull rod by means of a lever type handle at the operating end. Tong finger spacing is adjustable by means of a thumb nut. The lead shielded ball joint permits location of the tong axis at any angle included in a cone of approximately 70° included angle. The tong may be slid axially through the ball for coverage of an area inside the shielding.

Location: Manipulators of this type are in use in the Corrosion Examination Facility, Building 4501.

Reference: Designed 1-13-55 by Engineering and Mechanical Division for G. Jenks, Reactor Experimental Engineering Division.
Drawings D-19637, D-19638, D-19639 and D-19640

Name of Tool: Extraman Manipulator, Size 2"

Description: This tool is designed for medium duty general manipulation in a hot cell. The maximum O.D. of this tool is 2" except the handle, which permits use of the tool through a 2" cell wall penetration. Wrist motions are available at master and slave ends with motion of the slave end being reversed. Motion is transmitted by means of steel cables. Tongs at the slave end have parallel jaws opening from 0 to $4\frac{1}{2}$ inches. The jaws are spring loaded open and are closed by a hydraulic cylinder actuated by a lead screw and knob at the master end. The overall tool length is approximately 9 ft.

Location: This tool is located in the HRE In-Pile-Loop Dismantling Cell, Building 4501.

Reference: Designed 2-10-54 by Engineering and Mechanical Division for G. Jenks, Reactor Experimental Engineering Division.
Drawings E-17284, D-17285, D-17286, D-17287, D-17288, D-17289,
D-17290 and D-17291

Name of Tool: Handling Tongs for H.R.E.

Description: This tool was designed for general handling in the H.R.E. The body of the tools is $1\frac{1}{2}$ in. O.D. aluminum tubing. Overall length is approximately 21 ft. Wrist motions are provided at each end, with the motion being transmitted by steel cables strung through spherical segments. The parallel jaw tongs open from 0 to $2\frac{1}{4}$ in. They are spring loaded open, and are closed by means of a hydraulic pumping system built into the operating end. With the tongs closed, the tool can be inserted through an opening slightly over $1\frac{1}{2}$ in. diameter.

Location: This tool is now used at the HRT, Building 7500.

Reference: Designed 3-23-54 by Engineering and Mechanical Division for REED Division.

Drawings E-18482, D-18483, D-18484, D-18485, D-18486, D-18487 and D-18488.

Name of Tool: Hydraulic Retriever Tool

Description: This tool is used for the handling or manipulation of a variety of objects in the HRT cells. The handle consists of standard pipe, adjustable to various lengths. The tongs at the lower end are operated by a small hydraulic cylinder, with the hydraulic pressure being supplied from above by a portable pump. The tong assembly can be rotated about a horizontal centerline by means of angle gearing, from a "T" handle at the upper end of the tool.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed by Vitro Corp. for the Homogeneous Reactor Project.
Drawings 1171-L-18 and 1171-L-19

UNCLASSIFIED
PHOTO 43931

Name of Tool: Modified Wiggle Tong

Description: 3/4" O.D. stainless steel barrel has finger tongs on one end and operating handle on the other. The tool is designed to be used through a ball joint or rotating cylinder shielding penetration. Motion of the operating handle is transmitted to the tong end by means of tension on 1/16" diameter stainless steel cables. Motion of the tong end is opposite to motion of the operating end. Grip of tongs is controlled by a lever at the operating end, with spacing of the tong fingers adjustable by means of a knurled nut.

Overall length as designed is approximately 5 ft., but tongs could be built any length from about 2 ft. up, by modifying the length only of the barrel and the parts contained therein. A variety of fingers could be applied to the tongs.

Location: Tongs of this type are in use in the Corrosion Examination Facility, Building 4501, Reactor Experimental Engineering Division.

Reference: Designed 6-10-56 by Engineering and Mechanical Division for G. H. Jenks.

Drawings D-19692, D-19693, D-19694 and D-19695

Name of Tool: Utility Tongs

Description: This tool is designed for general handling of small articles within a shielded enclosure, by use through a ball-socket manipulator. The body of the tool is 5/8 inch O.D. stainless steel tubing. The curved pincer type tongs are actuated by a push rod from a lever handle at the operating end. Overall length of the tool is approximately 6 ft. 6 in. Reference drawings are listed below for the ball-socket manipulator as well as the tongs.

Location: These tongs are in use in the Corrosion Examination Facility, Building 4501.

Reference: Designed 5-9-55 by Engineering and Mechanical Division for G. Jenks, Reactor Experimental Engineering Division.

Drawings: Utility Tongs D-21086, D-10192 and D-10198

Ball Socket Manipulator E-10191, D-10193,
D-10194, D-10195, D-10196 and D-10197 also.

UNCLASSIFIED
PHOTO 43932

925 035

Name of Tool: Air Line "Snap-Tite" Disconnect Tool

Description: The body of this tool is 1" O.D. aluminum tubing, 9 ft. 6 in. long. Two "U" shaped jaws at the lower end are given a push pull motion by the lever handle at the top. This action serves to make or break "Snap-Tite" quick disconnect couplings in the HRT pool. All connections are vertical.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 6-20-56 by Engineering and Mechanical Division for W. R. Gall, Reactor Experimental Engineering Division.
Drawings D-25337 and D-25338

UNCLASSIFIED
PHOTO 19473

Name of Tool: Fuel Handling Tool

Description: This tool is designed to handle the fuel elements for the Geneva Conference Reactor. The $1\frac{1}{2}$ " O.D. aluminum body is approximately 25 ft. long. A grip hand is provided on the lower end with a locking pin to prevent dropping of an element. The locking pin is released by a pull rod from the operating end.

Reference: Designed 3-15-55 by Engineering and Mechanical Division for L. B. Holland, Applied Nuclear Physics Division.
Drawings D-22063, D-22064 and D-22065

UNCLASSIFIED
PHOTO 43933

Name of Tool: ORR Shim Rod Handling Tool

Description: This tool is designed to handle the ORR shim rods. The main body of the tool is $1\frac{1}{4}$ ", 347 stainless steel pipe, 28 ft. long. Two dogs at the lower end of the tool, which engage the shim rod, are opened or closed by a double acting cam. The cam is driven by a lead screw which is operated by a crank at the upper end. A "T" handle is provided at the top for two man operation, and a crane bail is provided for assistance. Floats have been designed to facilitate handling the tool in the ORR pool.

Location: This tool is located in the ORR, Building 3042.

Reference: Designed 5-2-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.
Drawings D-25344, D-25345, D-25346, D-26278 and D-23424

UNCLASSIFIED
PHOTO 43934

925 051

Name of Tool: Small Handling Tool

Description: This simple tool was designed for use in underwater disassembly of components of the Geneva Conference Reactor. It consists of a tubular handle approximately 16 ft. long which can be fitted with a $\frac{1}{4}$ " male hex tip or a $\frac{3}{8}$ " -16NC-2 male threaded tip. Other sizes or types of tips could be easily adapted.

Reference: Designed 4-26-55 by Engineering and Mechanical Division for L. B. Holland.
Drawing D-22077

Name of Tool: Utility Handling Tool

Description: This tool is designed to handle fuel elements or core pieces in the Pool Type Critical Assembly at the Bulk Shielding Facility. The body of the tool consists of $1\frac{1}{2}$ " O.D. aluminum tubing. It contains a smaller diameter actuating tube. The lower end of this underwater tool is designed to adapt to handling of Bulk Shielding Facility or ORR type end boxes. When tool is inserted in an end box, the actuator rod is pushed downward to extend holding lugs and it locks with a bayonet type lock. To retract holding lugs, bayonet lock is released and actuator is moved upward. Overall length is approximately 22 feet. A lifting bail is provided at the top for crane assistance in handling.

Reference: Designed 3-19-58 by Engineering and Mechanical Division for F. Maienschein, Applied Nuclear Physics Division for use in Building 3010.

Drawings D-32296, D-32297, D-32298, D-32299

Name of Tool: Flange Cover Wrench

Description: This tool is used to remove and replace 1-1/8 inch hex nuts on the ORR flange cover studs. The body of the tool is 1 1/2", Schedule 10, 347 stainless steel pipe 20 ft. long. The lower end is a commercial collet for 1-1/8 hex stock. The collet is tightened by wedging action when it is pulled up into a sleeve by a lead screw. This permits retention of the nut in the tool. A ratchet handle is provided at the top to operate the lead screw. A "T" handle for two man handling and a lifting bail for crane assistance are provided at the top. Floats have been designed for easier handling in the ORR pool.

Location: This tool is located in the ORR, Building 3042.

Reference: Designed 4-24-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.

Drawings D-25341, D-25342, D-25343 and D-23424

Name of Tool: Retrieving Socket Torque Wrench

Description: The body is of $1\frac{1}{2}$ " O.D. aluminum tubing, adaptable in 4 ft. lengths from 6 ft. to 30 ft. Various modified commercial sockets are provided, $\frac{3}{4}$ inch drive, from $\frac{7}{8}$ inch to $1\frac{1}{2}$ inch. A torque wrench applied at the top turns the entire body and socket. A ratchet adaptor is provided for easier operation. Bolts or nuts are retained in the sockets by a clamp actuated by an auxiliary lever which turns a lead screw.

The wrench is used under water for removing or tightening vertically positioned bolts in the HRT piping system.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 6-1-56 by Engineering and Mechanical Division for R. H. Winget, Chemical Technology Division.
Drawings D-27200, D-27201, D-27202, D-27203, D-27204, D-27205, D-27206, D-27209 and D-27210

925 071

Name of Tool: ORR Cover Plate Lug Wrench

Description: This tool is designed to manipulate and tighten the cover plate lugs on the ORR reactor tank access flange. The hold-down lugs are an inverted "L" shape, spring loaded upward so that when a stud nut is loosened, the lugs can be rotated 90° to permit removal of the cover plates. Two legs are provided at the bottom of the tool to rotate the hold-down lugs. A socket at the lower end of a 1 inch torque tube is used to tighten or loosen the stud nuts. A ratchet wrench at the operating end turns the torque tube. The body of the tool is 1½ inch pipe 20 ft. long provided with a "T" handle for operation and a lifting bail for crane assistance. Floats have been designed for attaching to the tool to permit easier handling in the ORR pool.

Location: This tool is located in the ORR, Building 3042.

Reference: Designed 4-24-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.

Drawings D-25339, D-25340 and D-23424

Name of Tool: Right Angle Starting Wrench

Description: This tool uses the same $1\frac{1}{2}$ " O.D. aluminum tubing body as the Retrieving Socket Torque Wrench. An aircraft type right angle gear box at the lower end is driven by a knurled hand wheel thru a torque tube. A socket adapter on the output shaft of the gear box permits use of modified commercial sockets. $1/2$ inch drive sockets are provided from $15/16$ inch to $1\frac{1}{4}$ inch. Bolts are retained in sockets by jamming with rubber bands.

This wrench is used to start and run up horizontal bolts in the HRT, prior to tightening with other tools.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 10-18-56 by Engineering and Mechanical Division for R. H. Winget, Chemical Technology Division.

Drawings D-27200, D-22434 and D-22435

Name of Tool: Cut-Off Saw for MTR Assemblies

Description: This saw is designed to operate underwater, slitting the side plates of MTR type fuel elements, thus separating the fuel plates. Elements to be cut are held in place by a clamp actuated by a knurled knob at the operating end. Two air motors, rotating in opposite directions at the lower end, power three slitting blades each, making three saw cuts along each side of the element simultaneously. The saw traverses along the element by means of a lead screw turned by a hand wheel from above.

The saw can also be used to cut end boxes off the elements.

Location: Undetermined

Reference: Designed 5-19-54 by Engineering and Mechanical Division for J. T. Howe, Solid States Division.

Drawings E-19925, D-19926, D-19927, D-19928 and D-19929

925 085

Name of Tool: Remote Band Saw

Description: This small band saw was designed for use in dismantling reactor experiments not over 4 inches in diameter. Raising and lowering the saw is done by turning a rod extending out of the hot cell. The same rod is used to roll the saw toward or away from the operator. A self-centering vise is used. Blades can be changed quite readily by using master-slave manipulators.

Location: This saw is located in the Solid States Division hot cells, Building 3025.

Name of Tool: Remote Portable Band Saw

Description: This recently developed tool has been tested in hot cell operation and appears to be very satisfactory. It consists of a commercially available portable electric band saw, to which a hexagonal handle has been added to permit its use with a General Mills Manipulator. The blades can be changed remotely by means of a special jig.

Location: One tool of this type is in use in the Solid States Division hot cells, Building 3025.

Reference: Saw by Wallace Supplies Mfg. Company. Modification designed by Reactor Projects Division. See CF-58-2-110 for more complete description.

Name of Tool: Saw Attachment for Extension Arm

Description: This tool was designed to cut pipe and tubing in a Chemical Pilot Plant. The tool attaches to the 2 inch diameter tubing body of the Universal Extension Wrench. It consists of three functional parts; a hydraulic vise, a hydraulic powered saw blade and a positioning mechanism. The positioning mechanism operates through gearing from two hand wheels at the top, to permit universal positioning of the saw-vise assembly. The piece to be cut is then clamped in the hydraulic vise and a hydraulic reciprocating mechanism drives the saber type saw blade to make the cut.

Location: Unknown

Reference: Designed September 25, 1951 by Engineering and Mechanical Division for C. D. Hylton, Chemical Technology Division. Drawings E-9828, D-9829, D-9830, D-9831, D-9832, D-9833, D-9834, D-9835, D-9836, D-9837 and D-9838

Name of Tool: Wire Cutting Tongs

Description: This tool is designed to cut wires remotely by pinching them between a stationary knife blade and a moving anvil. Motion is transmitted to the anvil from the operating lever by means of a 3/32" diameter stainless steel cable. The 3/4" O.D. tubular handle has a 90° bend to facilitate operation over a barricade. The tool is 3'-0" from the cutting end to the bend, and 4'-0" from the bend to the operating handle. The cutting mechanism could easily be adapted to a straight handle for underwater use.

Reference: Designed 10-13-50 by Engineering and Mechanical Division for J. C. Pigg, Solid States Division.

Drawing D-8370

UNCLASSIFIED
PHOTO 43941

Name of Tool: Underwater Light and Plexiglass Viewing Box

Description: These tools or equipment items are used to view underwater maintenance operations in the HRT. At the top is an underwater light, 1000 watt, of commercial design used to provide illumination for operations. The light is attached to a rigid pipe extension handle for raising lowering or rotating. A swivel joint between the light and the handle permits the light to be tilted by a hand line for universal coverage.

At the bottom is a plexiglass bottom viewing box. This box floating on the water surface cuts down surface reflection and ripples to permit better visibility of underwater operations. The long handled tools required are used through the notched out section, giving the operator good visibility on three sides of the area being viewed.

Location: These tools are located at the HRT, Building 7500

Reference: The lights are commercial items. The viewing box was developed by HRT field personnel. No drawings are available.

UNCLASSIFIED
PHOTO 41488

Name of Tool: Underwater Television Camera

Description: This television camera is used to view underwater maintenance operations at the HRT, to provide greater detail than can be detected by direct viewing through the water shielding. The camera itself is commercially available. The enclosure for underwater use was developed at ORNL. The assembly is held by a rigid pipe handle at the front for raising, lowering and rotation, and can be tilted by means of the hand line at the rear. Camera leads are brought to the surface through tygon tubing, which also serves as a means to circulate air through the enclosure for cooling the camera.

Location: This tool is used at the HRT, Building 7500.

Reference: Camera by Dage TV Division of Thompson Products, Inc.

Enclosure developed by HRT Field Forces.

Drawings are not available.

Name of Tool: HRT Maintenance Tools

Description: These tools are used in underwater maintenance of the

HRT. Their uses are as follows, from left to right.

Drift pin, used in aligning bolt holes of mating flanges.

Right angle socket drive, used for running up horizontal bolts.

Lifting hook, used for various lifting or grappling operations.

Mechanical retriever tool, used for picking up small objects.

Location: These tools are located at the HRT, Building 7500.

Reference: These tools were developed by Reactor Experimental Engineering
Division field forces.

No drawings are available.

Name of Tool: HRT Maintenance Tools

Description: These tools are all used in underwater maintenance of

the HRT. Their uses are, from left to right:

Gasket removal pick, used to free gaskets from flanges.

Right angle knife blade, used to cut insulation or other soft material.

Wedge knife blade, used for various cutting operations.

Mirror, has a ball socket joint for viewing from various angles.

Thread tap, to clean up threaded holes damaged by corrosion or cross threading.

All these tools have handles which are adjustable in length to suit the depth at which work is being performed.

Location: These tools are located at the HRT, Building 7500.

Reference: These tools were developed by the field forces responsible for HRT Maintenance, Reactor Experimental Engineering Division.

Drawings HRT Sketch 362 Gasket Removal Pick

HRT Sketch 366 Mirror

No drawings available on other tools.

Names of Tools: Tube Cutter
Wire Cutter
Remote Wrench
Special Soldering Gun

Description: These tools are all designed with offset handles so that they may be used through a hole in a lead shield without exposure to the radiation beam.

The tube cutter is a chisel shaped tool which is struck with a hammer. The tube to be cut is supported on an anvil in a special connecting device which joins an in-pile-loop to its shielding plug.

The wire cutter is a tubular type chisel tool which is used to cut wires threaded through a perforated tube in the same special connector.

The remote wrench is an adapted standard ratchet, with an auxiliary handle for manipulation, used to disconnect a locking screw in the special connector to permit separation of the loop from the shielding plug.

The soldering gun is used to sever 1/4" tubing connections made with a solder sleeve.

Location: These tools are used in in-pile-loop removal operations at the LITR, Building 3005.

Reference: Designed 10-1-53 by Engineering and Mechanical Division for G. H. Jenks, Reactor Experimental Engineering Division.
Drawing D-11444

UNCLASSIFIED
PHOTO 43616

Name of Tool: Bakelite Dispenser

Description: This tool is used to charge the Mounting Press with the bakelite powder in which specimens are mounted under heat and pressure. It consists of a vibrating tube supported by two leaf springs at about 60° to the axis of the tube. It is hand driven by a sprocket pushing against a small plate. The tube penetrates the cell wall through a pipe sleeve. Powder charged at the outer end is fed through the vibrating tube into the funnel on the mounting press.

Location: This tool is located in the Solid States Division Hot Cells, Building 3025.

Name of Tool: Cut-Off Wheel

Description: This tool is used in a hot cell for cutting up various irradiated materials, primarily in preparation for metallographic examination. The machine is loaded in the position shown and then is remotely pivoted so that the abrasive cut off wheel and vise are lowered into the tank. The cutting is done under water, by rotating the work into the wheel with the swiveling vise. Power and control leads can be remotely disconnected with a manipulator at the connector unit. The power unit can then be removed and the fiberglass tank can be disposed of for contamination control. Abrasive wheels can be changed with manipulators.

Location: This tool is located in the Solid States Division Hot Cells, Building 3025.

Reference: This is a newly re-designed machine, drawings for which are not yet available.

Name of Tool: Dymo Dispenser

Description: This apparatus is used to dispense diamond dust used in the polishing of metallographic specimens. The diamond dust, dispersed in a sticky material which will adhere to the specimens is dispensed from standard containers by an air operated ratchet mechanism below. The diamond dust clinging to the specimen is transferred to the polishing wheel, charging the wheel with abrasive.

Location: This unit is located in the Solid States Division Hot Cells, Building 3025.

Name of Tool: InterCell Transfer Unit

Description: Small objects are placed in the basket of this unit to be transported from cell to cell. The carriage runs on unistrut tracks mounted high in the cell, passing through openings in the walls between cells. Because of a set back in the back wall of the cells, the basket must be cantilevered out to the position shown for lowering. Upon raising, the slotted extensions on the basket engage the cantilever arms, raising them to the transporting position directly under the carriage.

Location: This unit is installed in the Solid States Division Hot Cells, Building 3025.

Name of Tool: Lapping Machine

Description: This machine is used in the polishing of mounted specimens, preparatory to metallographic examination. The lapping unit is a slightly modified Crane Packing Company "Lapmaster No. 12". The control unit, starting switch and timer are moved out of the cell. Recent changes consist of a splash pan around the lapping wheel to prevent slinging of grinding compound, turrets mounted on the conditioning rings for holding specimens, and separation of the grinding compound agitator from the tank so that it could be removed or replaced remotely. The last change mentioned was necessitated by frequent clogging of the valve that allowed the grinding compound to flow onto the lapping surface.

Location: This machine is installed in the Solid States Division hot cells, Building 3025.

0 1 2 3 4 5 6 7 8 9 10 11 12
INCHES

Name of Tool: Metallographic Polishing Wheel

Description: The polishing units are standard Buehler units that have been reworked; specimens and weights are held in a turret which is driven by a small motor. The turret is mounted on a plate that covers the entire polishing wheel, protecting it from foreign particles that could ruin the polishing action. These units are among the most successful that have been developed at ORNL. They are rugged, dependable and relatively easy to maintain. Recently another unit, the "Synthron" has become available and holds promise of being a valuable adjunct to the present units. At present they are more versatile but are not as rugged and are subject to greater cloth contamination troubles.

Location: These units are located in the Solid States Division hot cells, Building 3025.

925 127

Name of Tool: Mounting Press

Description: This unit is used for the mounting of metallographic specimens, within a hot cell. The out-of-cell control panel is shown alongside. Specimens are placed on bottom piston rod and lowered into mold. The funnel spout is rotated over mold and bakelite powder added. Upper cylinder rod, which is magnetized to hold identification and handling disk, is lowered into mold. The unit has functioned quite well for several years. The only objection is some difficulty in removing and replacing heater units.

Location: This machine is located in the Solid States Division hot cells, Building 3025.

Name of Tool: Remote Controlled Lathe

Description: This is a commercial machine tool, modified for installation in a hot cell. Direct mechanical linkages permit control of all major tool motions from outside the cell. Chuck, collet, and motion locks are operated by air or hydraulic cylinders. The headstock is driven by a hydraulic motor driven by a variable displacement pump mounted outside the cell, giving a simple variable speed control.

Location: This tool is located in the Solid States Division Hot Cells, Building 3025.

Name of Tool: Remote Controlled Milling Machine

Description: This is a commercial machine tool, modified for installation in a hot cell. Direct mechanical linkages permit control of all major tool motions from outside the cell. Vises and motion locks are operated by air or hydraulic cylinders. Spindle power is provided by a hydraulic motor driven by a variable displacement pump mounted outside the cell, giving a simple variable spindle speed control.

Location: This tool is located in the Solid States Division Hot Cells, Building 3025.

Name of Tool: Remote Metallograph

Description: The remote metallograph is a slightly modified Bausch and Lomb research metallograph. The stage is surrounded with six inches of lead and is accessible from inside the cell. The light source and camera are outside the cell. Microscope controls that have been brought out are: The coarse and fine focusing (a standard feature) and the stage motions, rotation, in and out, back and forth. An extension eyepiece has been brought out for initial examination. The lead shield has a door placed so that objectives, filters and other adjustments may be made by hand.

Location: This unit is located in the Solid States Division hot cells, Building 3025.

UNCLASSIFIED
PHOTO 13730

Name of Tool: Ultrasonic Specimen Cleaner

Description: This tool is used in cleaning specimens in preparation for metallographic examination. A wide variety of approaches to this operation has been tried. The use of ultrasonics has been by far the simplest and best approach that has been tried so far. In this unit the dirty specimen mount is placed in the right hand jaw, which turns it over and places it so that the handling disk of the mount is held against a magnet. The specimen is then rotated on its own axis and the arm is rotated into a perchlorethylene solution that is agitated by two cylindrical barium titanate transducers placed at right angles to each other. The specimen then is rotated out of the solution through a fresh perchlorethylene rinse, then into position for the clean right hand jaw that in turn rotates the specimen so that it can be transferred to the next operation. This unit, along with a still for cleaning the perchlorethylene solution, does a good job of cleaning, except on specimens with iron dust on them as from the lapping unit; the magnet collects the iron dust and the cleaner does not knock it off. Also the crystals have a short lifetime of only a few months the reason for which has not yet been found.

Location: This unit is located in the Solid States Division hot cells, Building 3025.

DISTRIBUTION LIST

1. A. A. Abbatiello
2. G. M. Adamson
3. C. W. Angel
4. S. E. Beall
5. D. S. Billington
6. R. E. Blanco
7. E. P. Blizzard
8. A. L. Boch
9. E. G. Bohlmann
10. E. S. Bomar
11. J. C. Bresee
12. R. B. Briggs
13. K. B. Brown
14. F. R. Bruce
15. D. W. Cardwell
16. W. R. Casto
17. R. H. Chapman
18. J. A. Cox
19. F. L. Culler
20. J. S. Culver
21. S. E. Dismuke
22. H. G. Duggan
23. W. K. Eister
24. D. E. Ferguson
25. E. A. Franco-Ferreira
26. J. H. Frye, Jr.
27. W. R. Gall
28. H. E. Goeller
29. T. E. Haynes
30. F. A. Heddleson
31. W. S. Hornbaker
32. K. E. Jamison
33. J. P. Jarvis
34. G. H. Jenks
35. W. H. Jordan
36. R. B. Korsmeyer

37. W. H. Lewis
38. R. B. Lindauer
39. H. G. MacPherson
40. W. D. Manly
41. R. V. McCord
42. W. B. McDonald
43. R. L. Moore
44. G. Morris
45. F. J. Muckenthaler
46. F. C. Maienschein
47. E. W. Parrish
48. W. A. Pate
49. P. Patriarca
50. E. E. Pierce
51. M. E. Ramsey
52. F. Ring
53. A. F. Rupp
54. H. W. Savage
55. W. F. Schaffer
56. H. E. Seagren
57. D. M. Shepherd
58. O. Sisman
59. I. Spiewak
60. E. Storto
61. W. H. Tabor
62. D. S. Toomb
63. T. L. Trent
64. A. M. Tripp
65. W. E. Unger
66. R. N. Winget
67. C. E. Winters
68. F. W. Wuest
69. ORNL-RC
- 70-71. Laboratory Records
72. M. J. Skinner
- 73-74. Central Research Library
75. Document Reference Section

REMOTE MAINTENANCE TOOLS

CATALOG

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
V-1	D-19638	4	Jaw	1/2 x 1/2 x 1/2	SST 304
V-2	Stock	4	Rollpin (79-022-094-0250)	.094 dia x 1/2 lg.	SST 420
V-3	D-19638	4	Link	1/2 x 1/2 x 1/2	SST 304
V-4	Stock	4	Rollpin (79-022-094-0375)	.094 dia x 3/8 lg.	SST 420
V-5	D-19638	2	Connector	3/8 x 5/8 x 1/2	SST 304
V-6	Stock	2	Rollpin (79-012-062-0375)	.062 dia x 3/8 lg.	SST 420
V-7	Stock	4	Rollpin (79-028-125-0562)	.125 dia x 3/8 lg.	SST 420
V-8	D-19638	2	Head	5/16 x 1-3/8 x 1/2	SST 347
V-9	Stock	2	Hose Clamp (Worm Drive)	Breeze Corp #05200-465	SST
V-10	D-19640	2	Boot (Koroseal Unichrome Coating 218 X As shown)		
V-11	Stock	32	Flat Hd. Mech. Screw	6-32NC-2 x 3/8 lg.	SST
V-12	D-19639	2	Flange	1/8 thk x 103 dia	SST 304
V-13	D-19639	2	Shielding Segment	1-13/32 x 8-25/32 x 8-3/4	Lead
V-14	D-19639	2	Bearing Segment	1-8 x 13/16 x 8-13/16	Mild Steel
V-15	D-19639	2	Shielding Segment	1-5/8 x 8-25/32 x 8-3/4	Lead
V-16	D-19639	2	Shielding Segment	1-3/8 x 8-25/32 x 9-3/4	Lead
V-17	D-19639	2	Bearing Segment	1-9 x 13/16 x 8-13/16	Mild Steel
V-18	D-19639	2	Shielding Segment	1-11/16 x 8-25/32 x 9-3/4	Lead
V-19	D-19640	2	Housing	As shown	Mild Steel
V-20	Stock	40	Sp. Hd. Cap Screw	10-24NC-2 x 3/8 lg.	Steel
V-21	D-19639	2	Flange	As shown	Mild Steel
V-22	D-19639	2	Ball	As shown	As noted
V-23	D-19638	1	Support Tube	As shown	SST 347
V-24	D-19638	1	Actuator Rod	As shown	SST 347
V-25	D-19638	2	Collar	1/2 dia x 1/4 lg.	SST 304
V-26	D-19638	2	Thumb Screw	3/8 dia x 3/16 lg.	SST 304
V-27	D-19638	2	Spring	.041 dia Wire	Muscle Wire
V-28	Stock	2	Hex. Soc. Set Screw (Flat Pt)	#8-40NC-2 x 3/16 long	SST
V-29	D-19640	2	Handle	As shown	SST 304
V-30	Stock	2	Pin	3/8 dia x 1 1/2 long	SST 304
V-31	D-19638	2	Retaining Nut	As shown	SST 304
V-32	D-19638	1	Actuator Rod	As shown	SST 347
V-33	D-19638	1	Support Tube	As shown	SST 347

NOTE: Quantities shown in Materials List are for two Manipulators. One req'd using Items V-23 & V-24 and one req'd using Items V-32 & V-33

A Redesigned Handle		5-24-55	WJK	6/2
NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-19637				
DRAWN	DATE	CHECKED	DATE	APPROVED
R. Lando	12-29-54	C.H. Buggins	1-12-55	WJK
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
				WJK
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

- MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
 2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
 3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED
AS _____
PER _____
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED
FRACTIONS: $\pm$ _____
DECIMALS: $\pm$ _____
ANGLES: $\pm$ _____
SCALE: 1" = 1"

Details of Ball Socket Manipulator - Sh. 1 D-19638	
Details of Ball Socket Manipulator - Sh. 2 D-19639	
Details of Ball Socket Manipulator - Sh. 3 D-19640	
REFERENCE DRAWINGS	DWG. NO.
CORROSION TEST FACILITY FOR LITR HB-5-BLDG. 3006	
BOMB DISMANTLING EQUIPMENT	
SUB-ASSY. OF BALL SOCKET MANIPULATOR	
OAK RIDGE NATIONAL LABORATORY	
OPERATED BY	
CARBIDE AND CARBON CHEMICALS COMPANY	
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION	
OAK RIDGE, TENNESSEE	
SUBMITTED	ACCEPTED
B. Rung	B. Rung
APPROVED	APPROVED
D-19637A	

APPROVED FOR CONSTRUCTION

925 009

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

Name of Tool: Cable Actuated Retriever Tool

Description: This tool is used for handling flange bolts or other objects in the HRT cells. The handle is of standard pipe, adjustable in length. The pincer type tongs are actuated by a cable from the operating lever handle. Tong spacing can be adjusted by one thumb screw on the operating handle, and the tongs can be locked in gripping position by means of another thumb screw and yoke. Rounded finger pads for gripping both horizontal and vertical bolts are provided.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed by Reactor Experimental Engineering Division.

Drawings C-27789 and C-27799

NOT CLASSIFIED

PARTS LIST

PART NO.	DWG. NO.	NO. REQD	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	Stock	1	Pin #32 Ga x 1/4 lg.	Music Wire
2	D-25044	1	Spring As shown	Music Wire
3	"	2	Spring Pin 3/16 dia x 1/8	347-55T
4	"	1	Handle As shown	" "
5	Stock	1	Pin #38 Ga x 3/8 lg	Music Wire
6	D-25044	1	Body As shown	347-55T
7	"	1	Push Rod As shown	" "
8	Stock	1	Pin #32 Ga x 1/4 lg.	Music Wire
9	D-25044	1	Arm As shown	347-55T
10	"	1	Cap 1 dia x 1/4 lg.	" "
11	"	1	Arm As shown	" "
12	Stock	1	Pin #32 Ga x 3/8 lg	Music Wire

- GENERAL SPECIFICATIONS:
1. Break all sharp edges 1/64 max., unless otherwise specified.
 2. The fabricator may choose the type, grade or finish of material unless otherwise specified.
- MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
 2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
 3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING
CLASSIFIED
AS **NOT CLASSIFIED**
PER *[Signature]*

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED

FRACTIONS: $\pm$

DECIMALS: $\pm$

ANGLES: $\pm$

SCALE: 2" = 1"

Detail Sheet #1		D-25045
REFERENCE DRAWINGS		DWG. NO.
Specimen Scrubber Holder & Defilming Tongs BLDG. NO. 4501		
ASSEMBLY		
DEFILMING TONGS #1		
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE NUCLEAR COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE		
SUBMITTED <i>[Signature]</i>	ACCEPTED <i>[Signature]</i>	APPROVED <i>[Signature]</i>
		D-25044
		REV

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25044				
DRAWN J.E. Corum	DATE 2-3-55	CHECKED A.M. Tripp	DATE 2-6-55	APPROVED DATE
DESIGNED	DATE	SUBMITTED A.M. Tripp	DATE 2-7-55	APPROVED H. S. [Signature]

925 013

APPROVED FOR CONSTRUCTION

Name of Tool: Defilming Tongs

Description: This tool is designed to handle very small specimens, with a minimum of contact between the specimen and tongs. The pincer type tongs are actuated by a push rod, with a scissors type handle at the operating end. The body of the tool is 3/4 in. O.D. tubing. Length of the tool overall is approximately 12 in.

Location: This tool is located in the Corrosion Examination Facility, Building 4501.

Reference: Designed 2-7-56 by Engineering and Mechanical Division for G. Jenks, Reactor Experimental Engineering Division.
Drawings D-25044 and D-25045

MATERIALS LIST

ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-17293	2	Pin	1/8 Dia. x .1875	St. Stl.
2	D-17293	2	Pin	1/8 Dia. x .250	St. Stl.
3	D-17293	2	Pin	1/8 Dia. x .125	St. Stl.
4	D-17293	2	Pin	1/8 Dia. x .156	St. Stl.
5	D-17293	2	Frame	1/16 x 15/16 x 2 1/2	St. Stl.
6	Stock	1	Rollpin	1/8 Dia. x 1 1/4	Stl.
7	Stock	4	Socket Head Cap Screw	#8-32NC-2 x 1/2	Stl.
8	Stock	4	Hex. Nut	#8-32	Stl.
9	D-17293	1	Swage Fitting	1/2 x 1/2 x 1 1/2	St. Stl.
10	Stock	As Req.	Cable (S.S. White)	130 R 36	
11	Stock	As Req.	Cable Casing (S.S. White)	155 D 1	
12	D-17293	1	Pin	1/8 Dia. x .375	St. Stl.
13	D-17293	2	Link	As Shown	St. Stl.
14	D-17293	2	Jaw	As Shown	St. Stl.
15	Stock	34	Snap Ring Waltes Truarc	5100-12	Standard
16	D-17293	2	Heel	1/8 x 1/2 x 9/16	St. Stl.
17	D-17293	4	Pin	1/8 Dia. x .3125	St. Stl.
18	D-17293	2	Link	As Shown	St. Stl.
19	D-17293	2	Pin	1/8 Dia. x .218	St. Stl.
20	D-17293	2	Link	1/16 x 9/16 x 1 1/2	St. Stl.
21	D-17294	1	Adapter	1.031 Dia. x 1 1/2	St. Stl.
22	Stock	1	Socket Head Set Screw	#5-40NC-2 x 1/2	Stl.
23	D-17293	36	Segment	1.031 Dia. x 1 1/2	
24	Stock	As Req.	Cable, ORNL Cat. No. 241-1611	1/16 Dia. x 1g. as required	St. Stl.
25	D-17294	1	Plug	1" Dia. x 1 1/2	Nylon
26	Stock	2	Pin	3/32 Dia. x 3/16	Steel
27	D-17294	1	Tube	1" O.D. x .032 wall x 48"	Brass
28	Stock	1	Tube	3/4 O.D. x .125 wall x 46 11/32	2S Al.
29	D-17294	3	Spacer	15/16 Dia. x 1	Brass
30	D-17294	1	Plug	1" Dia. x 1 1/8	Nylon
31	D-17294	18	Segment	1.031 Dia. x 1 1/2	Nylon
32	D-17294	1	Adapter	1 1/2 Dia. x 1 9/16	24 St. M
33	Stock	8	Round Head Mach. Screw	#4-40NC-2 x 3/16	Stl.
34	D-17294	6	Screw	5/16 Dia. x 1 1/2	Wild Stl
35	D-17294	6	Swage Fitting	3/16 Dia. x 3/8	St. Stl.
36	D-17295	1	Handle Housing	As Shown	St. Stl.
37	D-17295	1	Lever	As Shown	St. Stl.
38	D-17295	1	Swage Fitting	7/16 Dia. x 2 5/16	St. Stl.
39	Stock	1	Jam Nut	1/4-20	Stl.
40	D-17295	1	Fork	3/8 x 3/8 x 2 1/2	Stl.
41	D-17293	1	Pin	1/8 Dia. x .562	St. Stl.
42	D-17293	1	Pin	1/8 Dia. x .451	St. Stl.
43	D-17295	1	Cover	4 x 1 1/2 x 3	24St. Al.
44	D-17294	1	Spacer	5/16 Dia. x .250	St. Stl.
45	Stock	3	Staple .020 Wire 3/16 BC x 3/16 LG.	.020 Dia. x 9/16	St. Stl.

Handle shown for jaws in closed position

Match drill item 28 with item 29, & install item 45.

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-17292				
DRAWN	DATE	CHECKED	DATE	APPROVED
M. Kropff	2-1-54			
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED
AS NOT CLASSIFIED
PER <i>[Signature]</i>
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED
FRACTIONS: $\pm$
DECIMALS: $\pm$
ANGLES: $\pm$
SCALE: 1" = 1"

DETAILS SHEET # 3	D-17295
DETAILS SHEET # 2	D-17294
DETAILS SHEET # 1	D-17293
REFERENCE DRAWINGS	DWG. NO.
IN FILE LOOP BLDG. 4501	
DISMANTLING EQUIPMENT	
1" EXTRAMAN MANIPULATOR	
OAK RIDGE NATIONAL LABORATORY	
OPERATED BY	
CARBIDE AND CARBON CHEMICALS COMPANY	
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION	
OAK RIDGE, TENNESSEE	
SUPPLIED	ACCEPTED
<i>[Signature]</i>	<i>[Signature]</i>
APPROVED	
<i>[Signature]</i>	
REV	D-17292

Name of Tool: Extraman Manipulator, 1" Size

Description: This tool is designed for light duty general manipulation in hot cells. The maximum O.D. of the tool is 1", with the exception of an operating handle, which permits insertion of the manipulator through a 1" opening in the cell. Wrist motions are available on master and slave ends, with the slave motion being reversed. Motion is transmitted by steel cables. Tongs on the slave end have parallel jaws which may be opened from 0 to $2\frac{1}{2}$ in. by means of a grip handle at the master end. The overall tool length is approximately 7 ft.

Location: This tool is in use in the HRE In-Pile-Loop Dismantling Cell, Building 4501.

Reference: Designed 2-12-54 by Engineering and Mechanical Division for G. Jenks, Reactor Experimental Engineering Division.
Drawings D-17292, D-17293, D-17294 and D-17295

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1.	D-17285	1	Pin	9/16 Dia x .728	S. ST.
2	D-17285	2	Jaw	As shown	S. ST.
3	D-17285	2	Link	As shown	S. ST.
4	D-17285	2	Pin	5/16 Dia x .397	S. ST.
5	D-17285	2	Pin	5/16 Dia x .672	S. ST.
6	Stock	30	Snap Ring Waldee Truarc	# 5100 - 18	STD.
7	D-17285	4	Pin	3/16 Dia x .597	S. ST.
8	D-17285	2	Head	1/4 x 9/8 x 15/16	S. ST.
9	D-17285	2	Link	As shown	S. ST.
10	D-17285	2	Pin	9/16 Dia x .285	S. ST.
11	D-17285	2	Frame	1/8 x 1-7/8 x 5	S. ST.
12	D-17285	2	Link	1/8 x 1-1/8 x 5	S. ST.
13	Stock	1	Rollpin	1/8 Dia x 8/8	Steel
14	D-17286	1	Spring	As shown	ST. Wire
15	D-17286	1	Rod	1 Dia x 4 - 1/16	S. ST.
16	Stock	4	Soc. Head Cap Screw	#10-24UNC-2 x 1	S. ST.
17	Stock	1	*O* Ring #6227-12	3/8 10 x 13/16 OD x 7/32	NBR/EPDM
18	Stock	1	*O* Ring #6227-11	9/16 10 x 1 00 x 5/32	NBR/EPDM
19	Stock	1	*O* Ring #6227-17	7/8 10 x 1 1/8 OD x 1/16	NBR/EPDM
20	Stock	1	Snap Ring	Waldee Truarc #5100-18	STD.
21	Stock	3	*O* Ring #6227-8	1 10 x 3/8 OD x 1/16	NBR/EPDM
22	D-17286	1	Headle	3/8 Dia x 1-7/16	S. ST.
23	Stock	6	Socket Head Cap Screw	#8-32UNC-2 x 1	S. ST.
24	D-17287	1	Split Collar	1-7/8 Dia x 1/16	S. ST.
25	D-17287	1	Socket	1-7/8 Dia x 1/16	24 ST AL.
26	Stock	as req'd	Bushing	1/8 x .063 wall x 19, as req'd	Bar/rod
27	D-17287	30	Segment	As shown	As noted
28	Stock	as req'd	Cable ORNL Cat. No. 24-16/16	1/8 Dia	S. ST.
29	Stock	2	Socket Head Cap Screw	#8-32UNC-2 x 1/16	Steel
30	D-17287	1	Head	1-1/8 Dia x 7/16	S. ST.
31	D-17287	1	Cylinder	1-7/8 Dia x 5	S. ST.
32	Stock	1	Snap Ring Waldee Truarc	#5000-75	STD.
33	D-17286	12	Swage Fitting	1/4 Dia x 3/8	S. ST.
34	D-17286	1	Ferrule	3/8 Dia x 3/16	Copper
35	D-17286	1	Nut	1/2 Dia x 5/16	S. ST.
36	D-17286	1	Sleeve	1/4 Dia x 7/8	S. ST.
37	Stock	4	Hex Nut	9-10-24	S. ST.
38	D-17287	1	Spacer	3/8 Dia x .500	S. ST.
39	D-17284	1	Tube ORNL Cat. 243-3025	2"OD x .063 wall x 40"	S. ST.
40	D-17288	1	Rod	1-7/8 Dia x 28-7/8	24 ST AL.
41	D-17288	1	Rod	1-7/8 Dia x 1-7/8	24 ST AL.
42	Stock	1	Soc. Hd. Set Screw	#8-32UNC-2 x 5/16	Steel
43	D-17289	1	Handle	As shown	As noted
44	Stock	2	Soc. Hd. Cap Screw	#8-32UNC-2 x 1/2	Steel
45	Stock	2	Hex Nut	1/4 - 20	Steel
46	D-17290	2	End Flange	1/2 Dia x 3/8	Steel
47	Stock	24	Rollpin	1/8 Dia x 3/8	Steel
48	D-17289	24	Rollpin	1.250 Dia x .375	Bronze
49	D-17289	24	Plate	3/32 x 1.406 x 11/32	Steel
50	Stock	1	Soc. Head Set Screw	3/8-16UNC-2 x 1 1/2	Steel
51	Stock	1	Key	1/4 x 1/4 x 1	Keystock
52	D-17290	1	Adapter	5/8 Dia x 9	24 ST AL.
53	D-17289	1	Handle	As shown	As noted
54	D-17290	5	Segment	As shown	As noted
55	D-17290	1	Sleeve	1/4 Dia x 1-3/4	Brass
56	D-17291	1	Adapter	5 Dia x 4	24 ST AL.
57	C-17290	12	Bushing	3/4 Hex x 2-8	Steel
58	D-17290	12	Swage Fitting	1/2 Hex x 1-3/4	S. ST.
59	C-17291	1	Headle	1-1/2 Dia x 24	H. Steel
60	Stock	1	Snap Ring Waldee Truarc	#5100-37	STD.
61	D-17291	2	Washer	1/2 Dia x 1/16	H. Steel
62	Stock	1	*O* Ring #6227-10	1 19 x 11/16 OD x 7/32	NBR/EPDM
63	Stock	1	*O* Ring #6227-8	3/8 10 x 3/8 OD x 7/32	NBR/EPDM
64	D-17291	1	Flange Head	.063 Dia x 3/4	Brass
65	D-17291	1	Cap	1-1/2 Dia x 1/2	Brass
66	Stock	4	Soc. Hd. Cap Screw	1/4-20UNC-2 x 5/8	Steel
67	D-17291	1	Screw	1-3/8 Dia x 5-11/16	H. Steel
68	C-17289	24	Spacer	1/4 Dia x 3/16	H. Steel
69	D-17285	2	Pin	9/16 Dia x .222	S. ST.
70	D-17285	2	Pin	9/16 Dia x .408	S. ST.

NOTE:
Prior to assembly of cable, item 28, in manipulator, swage item 38 to one end of cable. Assemble flexible section of manipulator from tong head end and swage item 58 in place.

DETAILS	SHEET # 7	D-17291
DETAILS	SHEET # 6	D-17290
DETAILS	SHEET # 5	D-17289
DETAILS	SHEET # 4	D-17288
DETAILS	SHEET # 3	D-17287
DETAILS	SHEET # 2	D-17286
DETAILS	SHEET # 1	D-17285
REFERENCE DRAWINGS		DWG. NO.

IN FILE LOOP BLDG. 4501

DISMANTLING EQUIPMENT
2' EXTRAMANE MANIPULATOROAK RIDGE NATIONAL LABORATORY
OPERATED BY
CARBIDE AND CARBON CHEMICALS COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEESUBMITTED BY: *[Signature]* APPROVED BY: *[Signature]*

E-17284

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED
AS SECRET (U.S. GOVERNMENT PROPERTY)
PER 101-10

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED

FRACTIONS: $\frac{\quad}{\quad}$

DECIMALS: $\pm \quad$

ANGLES: $\pm \quad$

SCALE: 1" = 1'

NO.		REVISIONS				DATE		APPR.		APPR.	
DRAWING NO. E-17284											
DRAWN		DATE		CHECKED		DATE		APPROVED		DATE	
66 Kroff		1-4-56		Howell		1-7-56					
DESIGNED		DATE		SUBMITTED		DATE		APPROVED		DATE	
								3/10/56		3-10-56	
HEALTH PHYSICS			MEDICAL			OPERATIONS			SAFETY		
FIRE PROTECTION			RESEARCH SHOP			MAINTENANCE					

Name of Tool: Magnetic Retriever Tool

Description: This tool uses the $1\frac{1}{2}$ " O.D. aluminum tubing handle originally designed for Retrieving Socket Torque wrench. Length is adjustable from 6 ft. to 30 ft. in 4 ft. increments. The tool consists of a strong bar magnet fixed in a hinged adapter to permit its entry in confined places. It is used to retrieve parts or tools dropped into the HRT pool, as well as to handle bolts in removing them from or replacing them in flanges.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 6-20-56 by Engineering and Mechanical Division, for R. H. Winget, Chemical Technology Division.
Drawings D-27207, D-27208 and D-27200

MATERIALS LIST						MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL	ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-19693	1	Finger With Fork	As Shown	SST	20	D-19694	1	Spring	7/16 O.D. x 3 Lg	SST, Spring Wire
2	"	1	Finger With Tongue	As Shown	SST	21	D-19695	1	Nut	As Shown	SST
3	"	4	Link	As Shown	SST	22	"	1	Arm	3/8 x 2 3/8 x 12 Ga.	SST
4	"	2	Link Head Assy	As Shown	SST	23	"	1	Nut	As Shown	SST
5	"	2	Spring	.057 O.D. x .250 Lg	Music Wire	24	D-19693	2	Finger Operator	As Shown	SST
6	"	2	Ball	3/32 Dia	SST	25	Stock	4	Corrosion Resistant Roll-Pin	1/8 Dia x 9/16	SST
7	"	2	Pin	As Shown	SST	26	"	8	Corrosion Resistant Roll-Pin	1/8 Dia x 5/8	SST
8	"	2	Fitting	7/8 Dia x 3/8 Lg	SST	27	D-19694	2	Bracket	1/2 x 5/8 x 1 1/2	SST
9	D-19694	10	Ball	3/4 Dia	Brass	28	D-19693	1	Adapter	3/4 O.D. x 9/16	SST
10	"	8	Collar	3/4 Dia x 1/2	SST	29	"	2	Lock Ring	As Shown	SST
11	"	1	Fitting	1 Dia x 1 1/16	SST	30	Stock	2	Cone Point Set Screw	5-40NC-2 x 1/8	SST
12	Stock	1	Full Dog Set Screw	8-32NC-2 x 3/8 Lg	SST	31	D-19693	20	Insert	3/4 Dia x 3/16	Nylon
13	D-19694	1	Support Tube	3/4 O.D. x .065 Wall x 39 1/8	SST	32	D-19694	4	Support Cable Assy	As Shown	As Shown
14	D-19695	1	Push-Pull Cable Assy	As Shown	SST	33	D-19695	1	Handle	5/8 O.D. x .065 Wall x 6 3/8	SST
15	D-19694	1	Guide Tube	3/8 O.D. x .035 Wall x 39 3/8	SST	34	"	1	Handle Bracket	As Shown	SST
16	Stock	1	Nut - Hex	3/4-16 NF-2	SST	35	"	2	Side Plate	As Shown	SST
17	D-19694	1	Spring	13/16 I.D. x 1 1/2 Lg	SST Spring Wire	36	Stock	1	Rivet	3/16 Dia x 1 1/8 Grip	SST
18	D-19695	1	Adjustment Fitting	1 Dia x 1 1/8 Lg	SST	37	"	1	Socket Hd Cone Pt Set Screw	#10-24NC-2 x 1/4	SST
19	Stock	1	Pipe	1/2 Nom Sch 40 IPS	SST	38	D-19693	2	Finger Operator	As Shown	SST
						39	"	2	Finger	As Shown	SST

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-19692				
DRAWN	DATE	CHECKED	DATE	APPROVED
Hoyle	22 Apr 55	S.O. Lewis	6-7-55	H. Duggan
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		AMT/10/10	6-10-55	
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

Detail Sheet #3	D-19695
Detail Sheet #2	D-19694
Detail Sheet #1	D-19693
REFERENCE DRAWINGS	DWG. NO.
AUXILIARY EQUIPMENT CORROSION EXAMINATION FACILITY BLDG 4501	
MODIFIED WIGGLE TONG ASSEMBLY	
OAK RIDGE NATIONAL LABORATORY	
OPERATED BY	
CARBIDE AND CARBON CHEMICALS COMPANY	
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION	
OAK RIDGE, TENNESSEE	
SUBMITTED	APPROVED
PER <i>[Signature]</i>	PER <i>[Signature]</i>
SCALE: 1 = 1	D-19692

APPROVED FOR CONSTRUCTION

925 025

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

Name of Tool: Removable Tong Finger Pads for Manipulators

Description: This tool is a modified tong finger, to replace the standard type on master slave manipulators. When the tong fingers (upper left and center) are installed on the manipulator, the finger pads (upper right and lower left) can be changed remotely by means of the changing jig (bottom center). These finger pads can have a variety of facings, or can be attached to various small tools for better tool handling.

Location: The master-slave manipulators in the Solid States Division Hot Cells, Building 3025 will be equipped with these fingers and pads.

SECTION A-A

MATERIALS LIST				
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE MATERIAL
1	This Dwg.	2	Tong Finger	As Shown SST-347
2	Stock	3	Hex Jam Nut	#10-32 SST
3	Stock	4	Rivet (Headless)	1/16 Dia. x 3/16 long Steel
4	Stock	2	Rivet (Headless)	1/16 Dia. x 3/16 long Steel
5	This Dwg.	1	Actuator	1/4 x 1/2 x 1/4 Brass
6	This Dwg.	2	Finger Link	1/8 x 1/2 x 1/8 SST-347
7	This Dwg.	1	Tong Head	As Shown Brass
8	Stock	1	Stop Pin	1/16 Dia. x 1/2 Steel
9	This Dwg.	1	Rod (Short)	As Shown Brass
10	D-6943	1	Housing (Short)	As Shown Al-24 ST
11	Stock	6	Round Hd. Mach. Screw	#6-32 x 3/8 long SST
12	This Dwg.	2	Spacer	3/16 Dia. x 3/8 Brass
13	Stock	12	Round Hd. Mach. Screw	#4-40 x 1/4 long SST
14	D-6943	1	Cover Plate (Top)	1/8 x 1 3/8 x Lgh to suit Al-24 ST
15	This Dwg.	2	Pin	1/4 Dia. x 1/2 SST-316
16	This Dwg.	1	Bell-crank	1/4 x 3/8 x 3/8 SST-316
17	Stock	2	Cotter Pin	1/16 Dia. x 1/16 Steel
18	Stock	2	Plain Washer	#4 Steel
19	This Dwg.	1	Cover Plate (Bottom)	1/8 x 1 3/8 x 1 1/8 Al-24 ST
20	D-6943	1	Pivot Shaft	3/16 Dia. x 1 1/8 Brass
21	D-6943	1	Rod (Long)	As Shown Brass
22	D-6943	1	Housing (Long)	As Shown Al-24 ST
23	D-6943	3	Spacer	1/8 Dia. x 1/2 Bakelite
24	Stock	3	Headless Set Screw	#4-40 x 3/16 Steel
25	Stock	1	Rivet (Headless)	1/8 Dia. x 1/16 Steel
26	D-6943	1	Clamping Lever	As Shown Al-24 ST
27	Stock	1	Headless Set Screw	#10-32 x 3/4 Steel
28	Stock	2	Rivet (Headless)	3/32 Dia. x 1/8 Steel
29	D-6943	1	Clamping Link	3/16 x 3/16 x 2 3/16 Al-24 ST
30	D-6943	1	Thrust Collar	1/4 x 1/2 x 1 1/8 Al-24 ST
31	D-6943	1	Spring	As Shown Spring Wire
32	Stock	3	Round Hd. Mach. Screw	#4-40 x 3/8 long Steel
33	Stock	1	Fillister Hd. Mach. Screw	#6-32 x 3/8 long Steel
34	Stock	1	Shake Proof Washer	For #6 Screw Steel

NOTE
All dimensions shown in inches
Do not scale drawing
Break all sharp edges & remove all burrs
All riveted joints to allow smooth easy operation of component parts
Space item #23 on 2" centers along item #21 starting at bell-crank end, 2" from center of eye.
It is expected that all linkage fit snugly yet be free to move without binding.

APPROVED FOR CONSTRUCTION

NO.	REVISIONS	DATE	APPR.	APPR.
1	DESIGNED	10-10-50	W. Wallace	Robertson
2	CHECKED	10-10-50	W. Wallace	Robertson
3	APPROVED	10-10-50	W. Wallace	Robertson
4	DESIGNED	10-10-50	W. Wallace	Robertson
5	CHECKED	10-10-50	W. Wallace	Robertson
6	APPROVED	10-10-50	W. Wallace	Robertson
7	DESIGNED	10-10-50	W. Wallace	Robertson
8	CHECKED	10-10-50	W. Wallace	Robertson
9	APPROVED	10-10-50	W. Wallace	Robertson

THIS DRAWING NOT CLASSIFIED		DETAIL SHEET #1		D-6943
BY: W. Wallace		REFERENCE DRAWINGS		DWG. NO.
CHECKED: W. Wallace		DEVICES FOR HANDLING RADIOACTIVE MATERIALS		
APPROVED: W. Wallace		Bldg 706A TEN FOOT TONGS ASSEMBLY & DETAILS		
OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS DIVISION UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENN.		SUBMITTED: W. Wallace		APPROVED: W. Wallace
372374		D-6942		

Name of Tool: Ten Foot Tongs

Description: This tool is designed to handle small radioactive samples over or through a sleeve in a shielding barricade. The body of the tool is 3/4 inch O.D. aluminum tubing. Length of the arm from the operating handle to the fixed 90° joint is approximately 10 ft. The distance from the 90° joint to the end of the tongs is approximately 2 ft. The tong fingers are actuated by means of a hand lever and push rod operating through a 90° bell crank. Tong finger spacing can be adjusted by means of double nuts on the push rod at the operating handle.

Location: Unknown

Reference: Designed 3-7-50 by Engineering and Mechanical Division for Chemistry Division.

Drawings D-6942 and D-6943

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-9533	1	Handle (Movable)	See Detail	Brass
2	Stock	2	Cotter Pin	1/8 x 3/16"	Steel
3	D-9533	1	Pivot Pin	3/16 Diam. x 1" Lg.	Drill Rod
4	D-9533	1	Rod Connector	See Detail	Brass
5	Stock	2	Allen Skt Hd. Cap Scr.	#10-32-N.F. x 1/2 Lg.	Steel
6	D-9533	1	Handle (Fixed)	See Detail	Brass
7	D-9533	1	Spring	See Detail	311 Spring Wire
8	D-9533	1	Tube & Bushing	See Detail	Brass
9	D-9533	1	Jaw & Bushing	See Detail	See Detail
10	D-9533	1	Jaw & Rod	See Detail	See Detail
11	D-9533	1	Tube	1/2" I.D. x 20" Lg.	Steel

APPROVED FOR CONSTRUCTION

Utility Tongs- Details	D-9533
Manipulator Assembly	E-9529
Dolly Assembly	E-9526
REFERENCE DRAWINGS	DWG. NO.

THIS DRAWING
CLASSIFIED
AS OFFICIAL USE ONLY
PER 2.5.4.11

LIMITS OF DIMENSIONS UNLESS
OTHERWISE SPECIFIED

FRACTIONS: ± _____

DECIMALS: ± _____

ANGLES: ± _____

SCALE: 1" = 1"

BARRICADE & HANDLING EQUIPMENT - BLDG. 3026

UTILITY TONGS
ASSEMBLY

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
CARBIDE AND CARBON CHEMICALS DIVISION
UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

SUBMITTED: [Signature] NO. 439698

ACCEPTED: [Signature]

APPROVED: [Signature]

D-9532

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-9532				
DRAWN	DATE	CHECKED	DATE	APPROVED
C. J. PUGH	6-1-51	[Signature]	6/22/51	[Signature]
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
C. J. PUGH	6-1-51	C. ANGEL	6-23-51	[Signature]
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

925 031

Name of Tool: Utility Tongs

Description: This tong is designed to hold objects behind a barricade.

Tongs slide in and out through a fixed sleeve. Tong fingers have rubber pads and are actuated by a plier grip handle through a pull rod. Overall length is approximately 3 ft.

Location: Undetermined

Reference: Designed 6-25-51 by Engineering and Mechanical Division for

E. S. Wyatt, Chemistry Division.

Drawings D-9532 and D-9533

DETAIL SHEET NO. 7 " " " "		REFERENCE DRAWINGS	
D-10198 D-10192		DWG. NO.	
AUXILIARY EQUIPMENT CORROSION EXAMINATION FACILITY - Bldg. - 4501			
UTILITY TONGS - ASSY			
OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE			
SUBMITTED 12/10/48		ACCEPTED 12/10/48	
APPROVED 12/10/48		REV D-21086

Name of Tool: Feed and Purge Pump Mover Tool

Description: This tool is used to move the feed and purge pumps into or out of position in the HRT system for removal or replacement. The pumps are mounted on rolling supports. Special pockets are provided to receive the mover tool. The fingers of the tool are spread or closed to move the pump by a scissors jack action actuated by a lead screw turned by a "T" handle at the upper end.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed by Vitro Corp. for the Homogeneous Reactor Project.
Drawings 1171-L-16 and 1171-L-17

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-22063				
DRAWN	DATE	CHECKED	DATE	APPROVED
Oliver	3-2-55	Volante	3-9-55	
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		C. Angel	3-14-55	
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

925 039

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-22064	1	Nose	1 1/2 x 1 1/2 x 3/8	AL 24 ST
2	Stock	6	Oval Hd. Mech. Screw	#8-32NC-2 x 3/8	SST
3	Stock	1	Soc. Hd. Set Scr (Cup Pt)	#6-32NC-2 x 1/2	SST
4	Stock	1	Lower Actuating Pin	1/2" dia x 1-7/8" lg.	SST 304
5	D-22064	1	Lower Actuating Sleeve	1-7/8 dia x 2" lg.	AL 24 ST
6	D-22064	1	Locking Pin Assembly	See Detail	SST 304
7	D-22064	1	Lower Tube	1 1/2 OD x 120 wall	AL 2 S
8	D-22065	1	Lower Tube Adapter	See Detail	As noted
9	D-22065	1	Locking Sleeve	2 1/2 dia x 5-3/16 lg.	AL-24 ST
10	Stock	1	Soc. Hd. Set Scr (cup pt)	#6-32NC-2 x 1/2	SST
11	D-22066	1	Locking Pin Coupling	1 1/2 dia x 1-5/8 lg.	SST 304
12	D-22065	1	Spring	See Detail	SST 302
13	D-22065	1	Upper Tube Adapter	2.094 dia x 6-1/8	AL 2 S
14	Stock	3	Oval Hd. Mech. Screw	#4-40NC-2 x 1" lg.	SST
15	D-22065	1	Locking Sleeve Retainer	2.125 dia x 1/4 thk.	AL 24 ST
16	D-22066	1	Upper Tube	1 1/2 OD x 120 wall	AL 2 S
17	D-22066	1	Trigger Rod	See Detail	SST 304
18	Stock	3	Oval Hd. Mech. Screw	#8-32NC-2 x 3/8	SST
19	D-22066	1	Handle Adapter	1 1/2" dia x 1 1/2" lg.	SST 347
20	D-22066	1	Handle	See Detail	SST 347
21	Stock	1	Soc. Hd. Set Screw (cup pt)	#5-40NC-2 x 1/8" lg.	Steel
22	D-22066	1	Trigger	See Detail	AL 2 S
23	D-22065	2	Key	1/2" Sq. x 1 1/2"	SST 304
24	Stock	4	Flat Hd. Mech. Screw	#4-40NC-2 x 3/8	SST

This drawing contains information which is the property of the Oak Ridge National Laboratory. It is submitted in confidence and does not convey a license or permission to manufacture the equipment or parts shown for others. It must not be used, disclosed or copied without permission from Oak Ridge National Laboratory except in connection with our work. All rights of design and invention are reserved.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\dots}$

THIS DRAWING CLASSIFIED	
AS NOT CLASSIFIED	
PER <i>Life Holland</i>	
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED	
FRACTIONS: $\pm$	
DECIMALS: $\pm$	
ANGLES: $\pm$	
SCALE: 1" = 1"	

Detail Sheet # 3	D-22064
Detail Sheet # 2	D-22064
Detail Sheet # 1	D-22064
Reactor Installation Drawing	E-22050
REFERENCE DRAWINGS	DWG. NO.

GENEVA CONFERENCE REACTOR		
FUEL HANDLING TOOL ASSEMBLY		
OAK RIDGE NATIONAL LABORATORY		
OPERATED BY		
CARBIDE AND CARBON CHEMICALS COMPANY		
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION		
OAK RIDGE, TENNESSEE		
SUBMITTED	ACCEPTED	APPROVED
<i>F. R. King</i>	<i>A. B. H. H. H.</i>	<i>A. B. H. H. H.</i>
		D-22063

APPROVED FOR CONSTRUCTION

Name of Tool: Low Pressure Valve Flange Spreader

Description: This tool is used on the HRT piping system to spread valve flanges apart so that the O-ring seals will not be damaged during valve removal. The body of the tool is $1\frac{1}{2}$ inch O.D. aluminum tubing adjustable in 4 ft. steps from 4 ft. to 28 ft. The lower end has one fixed and one movable jaw. Each jaw has a locating pin which engages one of the bolt holes in the flange. Rotating the T-bar handle at the top then jacks the flanges apart by means of a lead screw.

Location: This tool is located at the HRT, Building 7500.

Reference: Field developed by HRT personnel. As built drawings made by Engineering and Mechanical Division for W. R. Gall, Reactor Experimental Engineering Division.
Drawings D-25349, D-26275 and D-26276

PARTS LIST				
PART NO.	DWG. NO.	NO. REQD.	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-2533G	1	Lifting Arm As Shown	S. St. #347
2	D-2533G	4	Special Washer $\frac{1}{8} \times 1\frac{1}{2} \times 1\frac{1}{2}$	S. St. #347
3	Stock	4	Hex. Nut $\frac{3}{4}$ -10NC-2	S. St.
4	D-2533G	4	Hook $\frac{3}{4}$ Dia. X 13	S. St. #347

NOTE:-
Hooks must be located & orientated to engage 4 eye bolts on Access Cover Plate, part #5, Dwg. D-19602

- GENERAL SPECIFICATIONS:
1. Break all sharp edges $\frac{1}{64}$ max., unless otherwise specified.
 2. The fabricator may choose the type, grade or finish of material unless otherwise specified.
- MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
 2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
 3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED NOT CLASSIFIED	
AS: <i>(Signature)</i>	PER: <i>(Signature)</i>
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED	
FRACTIONS: $\pm$	DECIMALS: $\pm$
ANGLES: $\pm$	SCALE: $\frac{1}{2}'' = 1''$

Tool Float Assy. & Details		D-23424
Detail Sheet No. 1		E-25336
REFERENCE DRAWINGS		DWG. NO.
TOOLS & BRIDGE FOR O.R.P. BLDG. NO. 3042		
ACCESS COVER LIFTING HOOK ASSEMBLY		
OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE		
SUBMITTED <i>(Signature)</i>	ACCEPTED <i>(Signature)</i>	APPROVED <i>(Signature)</i>
		D-25335

LTR	REVISIONS	DATE	APPD.	APPD.
DRAWING NO. D-25335				
DRAWN <i>H. Mirade</i>	DATE 2-6-56	CHECKED <i>M. Kropff</i>	DATE 2-22-56	APPROVED <i>(Signature)</i>
DESIGNED	DATE 3-21-56	SUBMITTED <i>S. O. Lewis</i>	DATE 4-24-56	APPROVED <i>(Signature)</i>

925 043

Name of Tool: ORR Access Cover Lifting Hook

Description: This tool is designed to handle the reactor tank access cover of the ORR. The body is $1\frac{1}{4}$ " Schedule 5 aluminum pipe, 20 ft. long. Four rigid hooks on cross pieces at the bottom are arranged to engage eye-bolts in the cover for lifting. A T-bar handle at the top permits two man operation. A lifting bail is provided for crane assistance. Floats have been designed for attaching to the tool to make it easier to handle in the ORR pool.

Location: This tool is located at the ORR, Building 3042.

Reference: Designed 4-24-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.
Drawings D-25335, E-25336 and D-23424

NOT CLASSIFIED

PARTS LIST

PART NO.	DWG. NO.	NO. REQD.	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-25327	1	Operating Handle As Shown	S.St. #347
2	This Dwg	1	Roll Pin $\frac{3}{16}$ Dia. x 1" Lg.	S.St.
3	"	2	Roll Pin $\frac{3}{16}$ Dia. x $1\frac{3}{4}$ " Lg.	S.St.
4	D-25327	1	Lifting Bail As Shown	S.St. #347
5	D-25328	2	Handle $\frac{3}{4}$ I.P.S. Sch. #10 pipe	S.St. #316
6	This Dwg	2	Flat Washer For $\frac{3}{8}$ Screw	S.St.
7	"	2	Hex. Hd. Mach. Screw $\frac{3}{8}$ -16NC-2 x $1\frac{3}{8}$ Lg.	S.St.
8	D-25328	1	Extension Arm As Shown	S.St. #347
9	"	1	Operating Rod $\frac{3}{8}$ Dia. x $34\frac{1}{2}$ "	S.St. #347
10	This Dwg	4	Hex. Socket Hd. Cap. Screw 10-24NC-2 x $\frac{1}{2}$ Lg.	S.St.
11	D-25327	1	Cam $\frac{3}{32}$ Dia. x $\frac{1}{16}$ "	S.St. #316
12	"	4	Lifting Dog As Shown	S.St. #316
13	"	1	Guide Housing As Shown	S.St. #347
14	This Dwg	1	Roll pin $\frac{1}{16}$ Dia. x $1\frac{5}{16}$ Lg.	S.St.
15	D-25327	2	Dowel Pin $\frac{3}{16}$ Dia. x $1\frac{1}{8}$ Lg.	S.St.
16	"	2	Dowel Pin $\frac{3}{16}$ Dia. x $1\frac{1}{8}$ Lg.	S.St.
18	D-26277	1	Spring As Shown	1047 S.St. Spring Wire
19	"	1	Spring Barrel $\frac{7}{8}$ Dia. x $\frac{1}{4}$ "	S.St.
20	"	1	Lock Rod $\frac{3}{8}$ Dia. x $2\frac{3}{16}$ "	S.St.
21	"	1	Knob 1" Dia. x $\frac{3}{16}$ "	S.St.
22	"	1	Hex. Jam Nut $\frac{1}{4}$ -20NC-2	S.St.

SECTION "A-A"

SECTION "B-B"

GENERAL SPECIFICATIONS:

1. Break all sharp edges $\frac{1}{64}$ max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED NOT CLASSIFIED	
AS PER	<i>G. R. King</i>
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED	
FRACTIONS:	$\pm \frac{1}{64}$
DECIMALS:	$\pm .005$
ANGLES:	$\pm 0^{\circ}-30'$
SCALE: 1" = 1"	

Guide Housing Adapter Assy & Detail	D-29288
Tool Float Assy. & Details	D-23424
Detail Sheet No. 3	D-26277
Detail Sheet No. 2	D-25328
Detail Sheet No. 1	D-25327
REFERENCE DRAWINGS	DWG. NO.

TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3042

FUEL ELEMENT & REFLECTOR HANDLING TOOL-ASSEMBLY

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
CARBIDE AND CARBON CHEMICALS COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

SUBMITTED <i>G. R. King</i>	ACCEPTED <i>J. H. Lee</i>	APPROVED <i>R. W. West</i>
		D-25326

APPROVED FOR CONSTRUCTION

A	Reference DWG D-29288 Added	5-20-57	W.A.	W.D.
LT	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25326				
DRAWN	DATE	CHECKED	DATE	APPROVED
V. Miracle	2-2-56	S.O. Lewis	3-12-56	<i>[Signature]</i>
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		S.O. Lewis	3-21-56	W. Huggan

925 045

Name of Tool: ORR Fuel Element and Reflector Handling Tool

Description: This tool is designed to handle fuel elements and reflector pieces in the ORR lattice. The body is $1\frac{1}{4}$ " pipe, 29 ft. long. The lower end has four cam operated lugs which engage an internal groove in the end boxes of the elements and reflectors. The push-pull cam is spring locked either open or closed. A "T" handle at the top permits two man operation. A bail is provided for crane assistance. Floats are designed for attaching to the tool body for easier handling in the ORR pool.

Location: This tool is located in the ORR, Building 3042.

Reference: Designed 3-30-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.
Drawings D-25326, D-25327, D-25328, D-26277, D-23424 and D-29288

SECTION "A-A"

SECTION "B-B"

GENERAL SPECIFICATIONS:

1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\text{ }}$.

PARTS LIST				
PART NO.	DWG. NO.	NO. REQD.	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-25331	1	Lifting Bail As Shown	S.ST. #347
2	" "	1	operating Handle As Shown	S.ST. #347
3	Stock	1	Hex. Socket Hd. Cap Screw #10-24NC-2 x 1 1/2 Lg.	S.ST.
4	" "	2	Hex. Hd. Cap Screws #8-16NC-2 x 1 3/4 Lg.	S.ST.
5	" "	2	Flat Washer For #8 screw	S.ST.
6	D-25330	2	Handle 3/4 I.P.S. Sch. #10 pipe x 16 Lg.	S.ST. #316
7	Stock	2	Roll Pin 3/16 Dia. x 1 3/4 Lg.	S.ST.
8	D-25330	1	Extension Arm As Shown	S.ST. #347
9	D-25331	1	Operating Rod 1/2 O.D. x .049 Wall Tubing x 33 1/2 Lg.	S.ST. #347
10	Stock	2	C5% Hd. Rivets 5/32 Dia. x 5/8 Lg.	S.ST.
11	D-25331	1	Cam 9/16 Dia. x 5 1/16 Lg.	S.ST. #316
12	" "	3	Pin 1/8 Dia. x 1 Lg.	S.ST.
13	" "	1	Pin Retainer 1/2 I.P.S. Sch. #10 pipe x 3/4 Lg.	S.ST. #316
14	" "	3	Lifting Dogs 3/64 x 2 3/8 x 3/16	S.ST. #316
15	" "	2	Lug 5/16 Dia. x 3/4 Lg.	S.ST. #316
16	Stock	3	Hex. Socket Hd. Cap Screws #10-24NC-2 x 1/2 Lg.	S.ST.
17	Stock	1	Hex. Nut. #10-24NC-2	S.ST.
18	D-26277	1	Spring As Shown	S.S. #302
19	" "	1	Spring Barrel 7/8 Dia. x 1 1/4	S.S.
20	" "	1	Lock Rod 9/16 Dia. x 2 3/16	S.ST.
21	" "	1	Knob 1- Dia. x 3/16	S.ST.
22	Stock	1	Hex. Jam Nut 1/2-20NC-2	S.ST.

Detail Sheet No. 3	D-26277
Tool Float Assembly	D-23424
Detail Sheet No. 2	D-25331
Detail Sheet No. 1	D-25330
REFERENCE DRAWINGS	DWG. NO.

TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3042

REFLECTOR PLUG HANDLING TOOL - ASSEMBLY

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
UNION CARBIDE NUCLEAR COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

SUBMITTED	ACCEPTED	APPROVED
P. King	J. H. H.	T. W. W.
D-25329		REV

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25329				
DRAWN	DATE	CHECKED	DATE	APPROVED
V. Mirade	2-3-56	S.O. Lewis	3-14-56	W. H. H.
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		S.O. Lewis	3-27-56	W. H. H.

Name of Tool: ORR Reflector Plug Handling Tool

Description: This tool is designed to handle reflector plugs in the ORR. The main body is $1\frac{1}{4}$ ", 347 stainless steel pipe, 30 ft. long. The lower end of the tool fits into the end box of the plug and has three cam operated lugs on 120° spacing which engage an internal groove in the plug. The cam is push pull operated through a tube from the top end and is held in either open or closed positions by a spring lock. A "T" handle at the top permits two man operation. A lifting bail is provided for crane assistance. Floats have been designed to permit easier handling in the ORR pool.

Location: This tool is located in the ORR, Building 3042.

Reference: Designed 4-24-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations Division.
Drawings D-25329, D-25330, D-25331, D-26277 and D-23424

PARTS LIST

PART NO.	DWG. NO.	NO. REQD.	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-25346	1	Crank Handle $\frac{7}{8}$ Dia. x $3\frac{1}{2}$	S.S.T. #347
2	D-25346	1	Crank Arm $\frac{3}{4}$ Dia. x $3\frac{1}{2}$	S.S.T. #347
3	Stock	1	Hex. Socket Set screw - Flat. Pt. #10-24UNC x $\frac{1}{4}$	S.S.T.
4	D-25345	1	Crank Hub $1\frac{1}{2}$ Dia. x $1\frac{3}{4}$	S.S.T. #316
5	D-25345	1	Top Bushing $1\frac{1}{2}$ Dia. x $\frac{1}{2}$	Monel
6	D-26278	1	Lifting Bail As Shown	S.S.T. #347
7	Stock	2	Roll Pin $\frac{3}{16}$ Dia. x $1\frac{1}{2}$	S.S.T.
8	D-25345	1	Extension Arm As Shown	S.S.T. #347
9	D-25346	1	Operating Shaft As Shown	S.S.T. #347
10	Stock	6	Flat Hd. Mach. Screw #8-20UNC-2 x $\frac{3}{4}$ Lg.	S.S.T.
11	D-25345	1	Bottom Bushing $1\frac{1}{2}$ Dia. x $\frac{1}{2}$	Monel
12	D-25346	1	Cam $1\frac{1}{16}$ x $1\frac{1}{16}$ x $7\frac{1}{2}$	Monel
13	D-26278	1	Housing As Shown	S.S.T. #347
14	D-25346	2	Pin $\frac{3}{8}$ Dia. x $2\frac{1}{8}$	S.S.T. #316
15	D-25346	2	Lifting Arm 1 x $2\frac{1}{4}$ x $6\frac{3}{4}$	S.S.T. #316
16	D-26278	2	Retaining Screw .125 Dia. x $1\frac{1}{8}$	S.S.T. #316
17	Stock	1	Lock Washer For $\frac{1}{4}$ Dia. Screw	S.S.T.
18	"	1	Hex. Nut $\frac{1}{4}$ -20NC-2	S.S.T.
19	"	1	Socket Hd. Cap Screw $\frac{1}{4}$ -20NC-2 x $1\frac{5}{8}$ Lg.	S.S.T.

SECTION "A-A"

- GENERAL SPECIFICATIONS:
1. Break all sharp edges $1/64$ max., unless otherwise specified.
 2. The fabricator may choose the type, grade or finish of material unless otherwise specified.
- MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
 2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
 3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING
CLASSIFIED
NOT CLASSIFIED
AS
PER *JAL*

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED

FRACTIONS: $\pm$ _____

DECIMALS: $\pm$ _____

ANGLES: $\pm$ _____

SCALE: 1" = 1"

Tool Float Assembly & Details	D-23424
Detail Sheet No. 3	D-26278
Detail Sheet No. 2	D-25346
Detail Sheet No. 1	D-25345
REFERENCE DRAWINGS	DWG. NO.
TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3044	
SHIM ROD HANDLING TOOL ASSEMBLY	
OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE	
SUBMITTED <i>G. King</i>	ACCEPTED <i>JAL</i>
APPROVED <i>F. W. W. W.</i>	
D-25344	

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25344				
DESIGNED V. Miracle	CHECKED J.A.K.	DATE 4-19-56	DATE 5-1-56	DATE 5-1-56
DATE 5-1-56	SUBMITTED A.M. Tripp	DATE 5-1-56	DATE 5-1-56	DATE 5-1-56

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

Name of Tool: Power Lead Disconnect Tool

Description: The body of this tool is $1\frac{1}{2}$ " O.D. aluminum tubing approximately 9 ft. long. A pair of jaws at the lower end grip the cylindrical power lead connectors and either pull or twist it as required. Grip force is provided by a lever at the operating handle. Used to make or break power lead connections in the HRT pool.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 6-18-56 by Engineering and Mechanical Division for W. R. Gall, Reactor Experimental Engineering Division.
Drawings D-27213, D-27214 and D-27215

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1		1	Threaded Tip	See Detail	304 SST
2		1	Hex Tip	See Detail	
3	Stock	1	Roll Pin	$\frac{3}{8} \times \frac{1}{2}$ lg	
4		1	Body	See Detail	347 SST
5		1	Pin Handle	See Detail	304 SST
6	Stock	1	Socket Set Screw	#10-24 NC-2 $\times \frac{1}{2}$ lg	SST
7		1	Extension Handle	See Detail	2s Alum

ASSEMBLY
Scale 1"=1"

① THREADED TIP
Mat'l - 304 SST $\frac{3}{8}$ Hex.
1 Req'd
Scale 1"=1"

② HEX TIP
Mat'l - As noted
1 Req'd
Scale 1"=1"

④ BODY
Mat'l - 347 SST
1 Req'd
Scale 1"=1"

⑤ PIN HANDLE
Mat'l - 304 SST
1 Req'd
Scale 1"=1"

⑦ EXTENSION HANDLE
Mat'l - 2s Aluminum
1 Req'd
Scale 1"=1"

For surfaces not otherwise indicated, roughness height shall not exceed .63

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-22077				
DESIGNED	DATE	CHECKED	DATE	APPROVED
DATE	DATE	DATE	DATE	DATE
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
PIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED	REFERENCE DRAWINGS	DWG. NO.
FRACTIONS: $\pm \frac{1}{16}$	GENEVA CONFERENCE REACTOR	
DECIMALS: $\pm .005$	SMALL HANDLING TOOL	
ANGLES: $\pm 0^{\circ}30'$		
THIS DRAWING CLASSIFIED		
AS NOT CLASSIFIED		
PER: [Signature]	SUBMITTED: [Signature]	ACCEPTED: [Signature]
SCALE: As Noted		APPROVED: [Signature]

OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE	
D-22077	REV

Name of Tool: Thermocouple Disconnect Tool

Description: This tool uses the same body originally designed for the Retrieving Socket Torque wrench, $1\frac{1}{2}$ " O.D. aluminum tubing adaptable in 4 ft. lengths from 6 ft. to 30 ft. The tool is designed to make and break thermocouple pairs in the HRT cell. Standard quick disconnect thermocouple connectors are used.

The lower end consists of two rectangular sections one within the other, which slip over the movable portion of the connector. The connector is seized by two dogs actuated by a sliding wedge which is driven by a lead screw. An "L" handle at the top end is used to rotate the lead screw.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 7-31-56 by the Engineering and Mechanical Division for W. R. Gall, Reactor Experimental Engineering Division. Drawings D-27200, D-27211 and D-27212

PARTS LIST				
PART NO.	DWG. NO.	NO. REQD	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-32298	4	Screw #10-24NC-2 x 3" Lg (See Detail)	55T-303
2	D-32297	1	ORB End Box Adapter - 2 1/8" Dia x 2 1/2" Lg	6061-AI
3	Stock	4	Roll Pin - 3/16 x 2 1/2" Lg	55T
4	D-32297	2	Lug - .860 x .937 x 1.360	55T-303
5	D-32297	1	Lug Actuator - 1.610 Dia. x 4" Lg	55T-303
6	D-32298	1	Spring - See Detail	55T
7	Stock	4	Flat Hd. Mach. Screw - #6-32NC-2 x 1/2	55T
8	D-32297	1	Actuator Cap - 1.610 Dia x 1/2"	55T-303
9	D-32297	1	B.S.F. Grid Plate Adapter - 2 1/8" Dia. x 4 1/2" Lg	6061-AI
10	D-32298	1	Actuator Tube - See Detail	6061-AI
11	D-32297	1	Operating Sleeve - 2" O.D. x 1.515 I.D. x 3" Lg	6061-AI
12	D-32298	1	Lock Pin - .250 Dia x 2" Lg	55T-303
13	D-32298	1	Lower Tube Section - 1 1/2" O.D. x .083 wall x 10' 0" Lg	6061-AI
14	D-32298	1	Actuator Tube Guide - 1.500 O.D. x 2"	6061-AI
15	D-32298	1	Upper Tube Section - 1 1/2" O.D. x .083 wall x 10' 0" Lg	6061-AI
16	D-32298	2	Grid Plate Adapter Lug (See Detail)	55T-303
17	Stock	1	O'Ring - Parker # 5427-21	Neoprene
18	Stock	3	Flat Hd. Mach. Screw #10-24NC-2 x 5/8 Lg	55T
19	D-32299	1	Crane Hook Adapter - 2 3/8" Dia. x 2 1/2" Lg	55T-347
20	Stock	1	O'Ring - Parker # 5427-21	Neoprene
21	Stock	1	Roll Pin - 1/8" Dia. x 1/2" Lg	55T
22	D-32298	1	Actuator Knob - 2 1/8" Dia x 1 1/4" Lg	6061-AI
23	D-32299	1	Crane Hook - 3/8" (See Detail)	55T-347
24	Stock	2	Handle Bar - 3/4" O.D. x .065 wall x 4 3/4"	55T-347
25	Stock	2	Flat Hd. Mach. Screw #6-32NC-2 x 3/8 Lg	55T

DETAIL SHEET #3	D-32299
DETAIL SHEET #2	D-32298
DETAIL SHEET #1	D-32297
REFERENCE DRAWINGS	DWG. NO.
POOL TYPE CRITICAL ASSEMBLY SUB. 3010	

UTILITY HANDLING TOOL ASSEMBLY	
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE NUCLEAR COMPANY A DIVISION OF UNION CARBIDE CORPORATION OAK RIDGE, TENNESSEE	
SUBMITTED F. Ring Jr.	ACCEPTED F. Maierstein
APPROVED F. W. West	REV D-32296

GENERAL SPECIFICATIONS:
1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1-1955.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed .

CLASSIFICATION
UNCLASSIFIED
F. Maierstein

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED
FRACTIONS: ±
DECIMALS: ±
ANGLES: ±
SCALE: 1" = 1"

APPROVED FOR CONSTRUCTION

LTR	DATE	CHECKED	DATE	APPROVED	DATE
DESIGNED	3-12-58	C. Ancel	3-11-58	H. G. DeLong	3-15-58
DATE	3-17-58	C. Ancel	3-17-58	APPROVED	DATE

925 057

Name of Tool: Chain Drive Offset Socket Wrench

Description: This tool is used to tighten or loosen bolts which are located so that an extension handle directly above the socket would meet with obstructions. The body of the wrench is of standard pipe making the length adjustable. The socket is chain driven from a torque tube turned from above through two sprockets. Lugs are provided to resist the socket torque and prevent its transmission through the handle.

Location: This tool is located at the HRT, Building 7500.

Reference: Developed by HRT Field Forces.

No drawings are available.

PARTS LIST

PART NO.	DWG. NO.	NO. REQD	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-25343	1	Lifting Bail As Shown	SST 347
2	"	1	Socket Drive Stud. 1/8" Socket hd. Cap Screw	SST
3	Stock	1	Reversible Ratchet (16" Lg.) ORNL Cat #	298-640
4	"	1	Socket Hd. Cap Screw #10-24NC-2 x 3/8 Lg.	SST
5	D-25343	1	Socket Wrench As Shown	Stl.
6	Stock	2	Roll Pin 3/16 Dia. x 1 3/4 Lg.	SST
7	D-25342	1	Operating Handle As Shown	SST 347
8	D-25343	1	Torque Tube 3/8 O.D. x .065 Wall Tubing x 23 1/2 Lg.	SST
9	Stock	4	Csk Hd. Rivet 1/4 Dia. x 3/4 Lg.	SST
10	D-25342	1	Operating Shaft. 3/4 Dia. x 5	SST 316
11	Stock	1	Socket Hd. Cap Screw #10-32NF-2 x 3/32 Lg.	SST
12	"	1	Collet - Hardinge - 2J - for 1/8 Hex. stock.	
13	D-25342	1	Key .240 x .156 x 1 1/2	SST 316
14	D-25342	1	Adapter 1 3/4 Dia x 1 1/8	SST 316

REMARKS:
1. Collet, (item #12) Purchased item to be altered as follows:
Chrome plate .002 to .003 thk. Heat for 4 hours @ 400°F. To prevent hydrogen embrittlement.

GENERAL SPECIFICATIONS:
1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed ✓.

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25341				
DESIGNED	DATE	CHECKED	DATE	APPROVED
W. H. H. H.	2-27-56	S. O. Lewis	3-15-56	W. H. H. H.
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
W. H. H. H.	3-21-56	S. O. Lewis	4-24-56	W. H. H. H.

Tool Float Assy. & Details	D-23424
Detail Sheet No. 2	D-25343
Detail Sheet No. 1	D-25342
REFERENCE DRAWINGS	DWG. NO.

TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3042

FLANGE COVER WRENCH ASSEMBLY

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
UNION CARBIDE NUCLEAR COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

SUBMITTED	ACCEPTED	APPROVED
G. H. H. H.	W. H. H. H.	W. H. H. H.
		D-25341
		REV

Name of Tool: Hydraulic Torque Wrench

Description: This tool is used to tighten large bolts in the HRT system.

A hydraulic cylinder actuates a ratchet wrench and socket to turn the bolts. The torque applied is controlled by varying the pressure of the hydraulic fluid at the pump, which is located above. Various handles and attachments are provided to increase the versatility of the tool by permitting its use on vertical or horizontal bolts. Restraining lugs are provided to prevent the torque applied to the bolts from being transmitted to the handle.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed by Vitro Corporation for the HRP and improved by HRT field forces.

Drawings 1171-L-4, 1171-L-13 and 1171-L-14 HRT Sketches
No. 600 and 732

PARTS LIST				
PART NO.	DWG. NO.	NO REQ	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	Stock	1	Utility Valve - Schrader Cat. No. 8936W	
2 ₁	Stock	1	Schrader Industrial Cat. No. 25 - Page 6. Adapter - 3/8 IPS Male - 1/4 IPS Female - Schrader Cat. No. 8206	
3 ₂	Stock	1	Air Regulator - See Note #2	
4 ₁	Stock	2	Hose Coupling - 1/4 Male - Schrader Cat. No. 9634	Brass
5 ₁	Stock	2	Universal Clamp - ORNL Cat. No. 291-1476	SST
6	Stock	As Req'd	Tubing - 3/8 I.D. x 1/8 Wall - ORNL Cat. No. 15-291-6277	Rubber
7	Stock	As Req'd	Air Hose - 3/8 I.D. x 47/64 O.D. Schrader Cat. No. 9617	Rubber
8	Stock	1	Schrader Industrial Cat. No. 25 Page 12	
9 ₁	Stock	1	Universal Clamp - ORNL Cat. No. 291-1477	SST
9	Stock	1	Hose Coupling - 3/4 RPT Female - Schrader Cat. No. 1699	
10	This Dwg.	1	Elbow - 1/8 x 1/8 x 2 7/8	316 SST
11	This Dwg.	1	Bracket - 1/2" x 1/2" x 1/2"	Al-SST
12 ₃	Stock	3	Soc Hd Cap Screw 1/4 - 20NC - 2 x 2	T6
13 ₄₋₅	Stock	1	Auto Impact Wrench - Furnished by requester	SST
14 ₆	Stock	1	Angle Head - Furnished by requester	

REMARKS:

1. All Schrader Industrial Products may be purchased from Tennessee Mill & Mine Supply Co., 404-412 State Street, Knoxville 60, Tennessee.

NOTES:

1. All hose couplings and adaptors - See Schrader Industrial Cat. No. 25, page 13.
2. Remove existing air regulator from (Part No. 13) auto impact wrench and install as shown.
3. Use existing lock washers under soc hd cap screws.
4. Remove existing air deflector from auto impact wrench (Part No. 13) - Ream air outlet to 3/4" dia x 1/2" dp for force fit into elbow (Part No. 10).
5. Order No. 13 Auto Impact - Model CP-10 with an hose (Part No. 14) manufactured by Chicago Pneumatic Tool Company, 6 East 44th Street, New York 17, New York.

⑩ ELBOW
Matl - 3/16 SST
1-Peep
Scale $1/2 = 1$

⑪ BRACKET
Matl- Aluminum 6061-T6
1- Reqd
Scale 1:1

GENERAL SPECIFICATIONS:

1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\frac{1}{8}$.

SECTION A-A
Scale 1 = 1

29' Retrieving Socket Wrench	D-25292
REFERENCE DRAWINGS	DWG. NO.
Tools & Adapters For HRT-CP	
BLOG. NO. 7500	
IMPACT WRENCH ASSEMBLY & DETAILS	
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE NUCLEAR COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE	
SUBMITTED G. King	APPROVED R. H. Winget
	APPROVED J. W. Wier
	D-28975
	REV

Name of Tool: Impact Wrench, Chicago Pneumatic

Description: This tool consists of a modified commercially available pneumatic impact wrench which is used to tighten or loosen bolts under water in the HRT piping system. It is particularly intended to loosen bolts that have corroded. The body of the tool is $1\frac{1}{2}$ inch O.D. aluminum tubing adjustable in 4 ft. steps from 4 ft. to 28 ft. An adapter bracket at the lower end secures the wrench to the extension handle. The wrench throttle is taped shut and the tool is controlled by a small hand valve from above. The regulator which controls the tool impact is also relocated to the operator end. Exhaust air is brought to the surface to permit visibility while wrench is being used.

A right angle drive extension is provided so that the tool can be used on either vertical or horizontal bolts.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 10-22-56 by Engineering and Mechanical Division for R. H. Winget, Chemical Technology Division.

Drawings D-25292 and D-28975

NOT CLASSIFIED

PARTS LIST

PART NO.	DWG. NO.	NO. REQD.	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-25340	1	Lifting Ball As Shown	SST 347
2	Stock	1	Reversible Ratchet (16" Lg.) ORNL CAT.	298-6410
3	D-25340	1	Socket Wrench As Shown	STL
4	Stock	1	Socket Hd. Cap Screw 3/16-18NC-2 1/2 Lg.	SST
5	"	1	Shake-proof Washer For 3/16 Screw	SST
6	"	1	Hex. Nut 3/16-18NC-2 1/2 Lg.	SST
7	Stock	2	Roll Pin 3/16 Dia. x 1 1/2 Lg.	SST
8	D-25340	1	Operating Arm As Shown	SST 347
9	"	1	Torque Tube As Shown	SST 347
10	Stock	2	Dowel Pin 1/4 Dia. x 1.305 Lg.	SST
11	"	4	Socket Hd. Cap Screw 3/8-16NC-2 x 1 Lg.	SST
12	"	4	Lock Washer - Med. For 3/8 Screw	SST
13	"	1	Pan Hd. Rivet 3/16 Dia. x 1 3/4 Lg.	SST
14	D-25340	1	Socket Wrench As Shown	STL
15	"	2	Positioning Lugs As Shown	SST 347

GENERAL SPECIFICATIONS:

1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING CLASSIFIED AS NOT CLASSIFIED PER <i>G. R. R. 4</i>
LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED
FRACTIONS: $\pm$
DECIMALS: $\pm$
ANGLES: $\pm$
SCALE:

Tool Float Assy. & Details		D-23424
Detail Sheet No. 1		D-25340
REFERENCE DRAWINGS	DWG. NO.	
TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3042		
COVER PLATE LUG WRENCH ASSEMBLY		
OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE		
SUBMITTED <i>G. R. R. 4</i>	ACCEPTED <i>[Signature]</i>	APPROVED <i>[Signature]</i>
		D-25339

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-25339				
DRAWN V. Miracle	DATE 2-17-56	CHECKED M. KROFF	DATE 2-23-56	APPROVED [Signature]
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		S. J. Lewis	3-21-56	[Signature]

925 007

Name of Tool: Right Angle Drive Socket Wrench

Description: The body of this tool is 2 inch O.D. aluminum tubing, adjustable in 4 ft. lengths from 6 ft. to 30 ft. The lower end has an offset ratchet wrench, which is given reciprocal motion by a Bellows air motor mounted on the upper end. The socket drive shaft extends on both sides of the ratchet, permitting reversal of motion by changing ends.

A bolt retaining device is provided in the sockets which is actuated from the operating end by a torque applied to the ratchet pull rod driving a worm and gear mechanism. 3/4 inch drive sockets are provided from 3/4 inch to 2-3/16 inches. A socket extension is also provided to increase the versatility of the wrench.

This wrench is used to remove or replace horizontally positioned bolts in the HRT.

Location: This wrench is used at the HRT, Building 7500.

Reference: Designed 8-3-56 by Engineering and Mechanical Division for R. H. Winget, Chemical Technology Division.

Drawings D-26317, D-26318, D-26319, D-26320, D-26321, D-26322, D-26323, D-26324, D-23419, D-27224, D-27642 and D-27643

EXISTING WRENCH EXTENSION
SEE DWG D-27200

To retain bolts, cross rubber bands
as shown and insert bolt head
in socket.

- GENERAL SPECIFICATIONS:
1. Break all sharp edges 1/64 max., unless otherwise specified.
 2. The fabricator may choose the type, grade or finish of material unless otherwise specified.
- MACHINE FINISH SPECIFICATIONS:
1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
 2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
 3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{}$.

PARTS LIST

PART NO.	DWG. NO.	NO REQD	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
1	D-22435	1	KNOB 2 1/2 DIA x 1 3/8	52S AL
2	Stock	1	DOWEL 1/8 DIA x 7/8	STEEL
3	D-22435	1	BEARING 1 DIA x 1 5/16	BRONZE
4	D-22435	1	ADAPTER 1 1/4 HEX x 6 1/16	52S AL
5	D-22435	1	STEM 3/8 HEX x 5 1/2	61S AL
6	D-22435	1	DRIVE ADAPTER 1 1/4 x 1 3/16 x 19	52S AL
7	D-22435	1	STEM 5/8 DIA x 17 3/16	SST 316
8	Stock	4	SOC HD CAP SCREW No. 8-32NC-2 x 1/2	STEEL
9	Stock	4	HEX NUT - FIBER SELF LOCKING No. 8-32	STEEL
10	Stock	1	RIGHT ANGLE GEAR DRIVE	
11	Stock	2	SOC HD SET SCREW, FULL DOG PT, No. 10-24NC-2 x 3/8	STEEL
12	D-22435	1	SOCKET ADAPTER 1/2 x 1/2 x 5/8	SST 316
13	D-22435	1 EA	SOCKET, SNAP-ON, 1/2 DRIVE, 12 POINT, 1 5/16, 1 1/2, 1 3/4, 1 7/8	

REMARKS:

1. Airborne Model R-300-AS-BS, Type 2 way, Ratio 1:1, Both shafts involute spline, Static Torque in pounds 250
Airborne Accessories Corporation
1414 Chestnut Ave.
Hillside 5, New Jersey
To be furnished by requester.
2. Snap-On Cat. No. SW-301, 1 5/16
Snap-On Cat. No. SW-341, 1 1/4
Snap-On Cat. No. SW-361, 1 1/8
Snap-On Cat. No. SW-401, 1 1/4
Catalog "V" page 26
Snap-On Tools Corporation
380 Techwood Drive
Atlanta 13, Ga.
To be furnished by requester.

LTR	REVISIONS	DATE	APPD	APPD
DRAWING NO. D-22434				
DRAWN	DATE	CHECKED	DATE	APPROVED
M. KROPP	9-24-56	S. Lewis	10-17-56	
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		M. Kropf	10-18-56	N. Guffey

THIS DRAWING
CLASSIFIED
AS **NOT CLASSIFIED**
PER *[Signature]*

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED

FRACTIONS: ±

DECIMALS: ±

ANGLES: ±

SCALE: 1" = 1"

WRENCH FOR HRT ASSEMBLY		D-27200
RIGHT ANGLE STARTING WRENCH DETAILS		D-22435
REFERENCE DRAWINGS	DWG. NO.	
TOOLS & ADAPTERS FOR HRT - CP BLDG. NO. 7500		
RIGHT ANGLE STARTING WRENCH ASSEMBLY		
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE NUCLEAR COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE		
SUBMITTED <i>[Signature]</i>	ACCEPTED <i>[Signature]</i>	APPROVED <i>[Signature]</i>
		D-22434
REV		

APPROVED FOR CONSTRUCTION

Name of Tool: Torque Multiplier Wrench

Description: This tool is used in tightening 2500 lb. flanges in the HRT Piping System. The body of the tool is $1\frac{1}{4}$ inch, Schedule 40 steel pipe, 30 ft. long. A welded assembly at the lower end fits over three bolts on the flange being assembled, with the torque being applied to the center bolt. A torque wrench at the top supplies the needed leverage, and a commercial torque multiplier has been incorporated into the lower end. A lifting bail is provided for crane assistance. This tool has been built in four sizes to fit $2\frac{1}{2}$ inch, 3 inch, $3\frac{1}{2}$ inch and 4 inch flanges respectively.

Location: This tool is in use at the HRT, Building 7500.

Reference: Designed December 1956 by Reactor Experimental Engineering Division.

Drawings D-25646, D-25647, D-27780, D-27781, D-27730, D-27731, D-27776, and D-27777

MATERIALS LIST

ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-25293	3	Extension - 1 1/2 O.D. x 1/2 Wall Tubing		Al.
2	"	1	Extension - 1/2 O.D. x .063 Wall Tubing		Al.
3	"	1	Nut - 1/2-20 As Shown		Brass
4	D-25295	1	Locking Nut - 3/8 Hex x 1 1/2 Lg - As Shown		"
5	"	1	Centering Washer - 3/8 x 1/2 Dia		Stl.
6	"	21	Screw Retaining Spring - As Shown		"
7	D-25293	1	Socket Adaptor - As Shown		"
8	D-25295	1	Actuating Rod - 3/8 O.D. x 10 3/4 Lg		Drill Rod
9	Stock	1	Cone Pt Set Screw - 1/2-20NC-2 x 1/2 Lg		Stl.
10	"	1	Pin - 3/32 Dia x 1/2 Lg		Stl-1020
11	D-25295	1	Clamp Jaw - As Shown		Vege
12	"	2	Nut - 3/8-16 Hex		Stl
13	"	1	Socket - ORNL Cat. No. 298-8535		"
14	Stock	1	Rollpin - 1/8 Dia x 1/2 Lg		"
15	"	2	Rollpin - 1/8 Dia x 1/2 Lg		"
16	"	21	Rd Hd Mach Screw - 8-32NC-2 x 1/2 Lg		"
17	D-25294	42	Soc Hd Cap Screw - 1/2-20NC-2 x 1/2 Lg		"
18	Stock	4	Cone Pt Set Screw - 10-32NF-2 x 1/2 Lg		"
19	"	8	Soc Set Screw - Flat Pt - 10-32NF-2 x 1/2 Lg		"
20	"	6	Soc Set Screw - Flat Pt - 8-32NC-2 x 1/2 Lg		"
21	"	3	Soc Set Screw - Flat Pt - 4-40NC-2 x 1/2 Lg		"
22	D-25294	1	Modified Ratchet - ORNL Cat. No. 298-6410		"
23	"	1	Soc Set Screw - Flat Pt - 1/2-20 x 1/2 Lg		Stl
24	"	1	Hex Adaptor - 1 1/2 Hex x 4 Lg		"
25	"	1	Extension - 1 1/2 O.D. x 1/2 Wall x 96 Lg Tubing		Al
26	"	3	Extension Connector - 1/2 Hex x 6 3/8 Lg		"
27	"	8	Spacer - 3/8 x 1 1/8 Dia		"
28	D-25295	4	Guide - 1/2 x 1 1/8 Dia		"
29	"	3	Connector - 3/8 Hex x 3 3/8 Lg		"

AS BUILT

PROTOTYPE

Detail Sheet #3	D-25295
Detail Sheet #2	D-25294
Detail Sheet #1	D-25293
REFERENCE DRAWINGS	DWG. NO.

HRT - TOOLS & REMOTE MAINTENANCE DEVICES Bids 1999

29' RETRIEVING SOCKET WRENCH

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
UNION CARBIDE NUCLEAR COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

THIS DRAWING
CLASSIFIED
AS NOT CLASSIFIED
PER [Signature]
SCALE: 1 = 1

SUBMITTED [Signature] APPROVED [Signature]
D-25292

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-25292				
DRAWN	DATE	CHECKED	DATE	APPROVED
W. Boyle	4-2-54	M. Koepff	2-20-54	
DESIGNED	DATE	SUBMITTED	DATE	APPROVED
		A.M. Tapp	4-25-54	H. Duggan
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

Name of Tool: 29' Retrieving Socket Wrench

Description: This tool is used to remove and replace vertically positioned bolts in the HRT piping system. The body of the tool is $1\frac{1}{2}$ inch O.D. aluminum tubing adjustable in length in 4 ft. steps from 4 ft. to 28 ft. The lower end will receive various modified $3/4$ inch drive sockets. The sockets are provided with a finger, actuated by a screw from the top, to retain bolt heads in the socket. A ratchet handle at the top provides wrenching torque.

Location: This tool is located at the HRT, Building 7500.

Reference: Field developed by HRT personnel. As built drawings prepared by Engineering and Mechanical Division for W. R. Gall, Reactor Experimental Engineering Division.

Drawings D-25292, D-25293, D-25294 and D-25295

Lubricate with
Liqui-Moly Grease

Scale: 1/8"=1"

Clean surface of stationary parts.
Prime with Zink-Chrome Primer
Finish with DuPont #353-775
Gray Paint, Acid and Alkali
Resistant, Phenolic Resin Type,
or equivalent.

When desired or necessary
use standard 1/2 drive
extension between Items
57 & 50 or between Item 50
& standard 12 point socket or crow foot.

Alternate method
of attachment

Standard 12 point
socket or crow foot
to fit hex nut.

Lubricate with Sinclair
Shamrock, Grade F,
Aluminum Stearate Base
or equivalent

Lubricate with
Liqui-Moly Grease

When desired or necessary
use standard 1/2 drive
extension between Items
50 & 50 or between Item 50
and standard 12 point socket.

Standard 12 point
socket to fit
hex nut

Scale: 1"=1"

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	E-8678	2	Taper Pin	22 x 1 1/2 lg.	Steel
2	D-8679	2	Tube	1" OD x .125 wall x 12	24 St.
3	D-8679	1	Hub	3" x 6"	24 St.
4	E-8678	4	Soc. Hd. Cap Screw	1/2-20 NF-2 x 7/8	24 St.
5	D-8679	4	Washer	1/2-20 NF-2 x 7/8	24 St.
6	E-8678	4	Soc. Mach. Screw Nut	1/2-20 NF-2	24 St.
7	D-8679	1	Tube	2" OD x .065 wall x 9 ft.	24 St.
8	E-8678	8	Dowel Pin	1/16 OD x 1/2 lg.	24 St.
9	D-8680	2	Spring	.020 x 1/2 x 1/2	Phos. Brs.
10	E-8678	8	Fillister Hd. Mach. Screw	1/4-20 NC-2 x 3/8	24 St.
11	E-8678	4	Dowel Pin	1/16 Dia. x 3/8 lg.	24 St.
12	D-8680	1	Sleeve Half	24 OD x 10 lg.	24 St.
13	D-8681	2	Plug	1.870 OD x 10" lg.	24 St.
14	D-8680	9	Set Screw	5/16-24 NC-2 x 3/8 lg.	24 St.
15	E-8678	18	Fl. Hd. Mach. Screw	1/4-20 NC-2 x 5/16 lg.	24 St.
16	D-8679	1	Tube	2 OD x .065 Wall x 11 ft.	24 St.
17	D-8679	1	Tube	2 OD x .065 Wall x 12 ft.	24 St.
18	D-8680	1	Key	3/16 x 3/16 x 1	Key Stock
19	E-8678	1	Full Dog Point	1/2-20 NC-2 x 5/8 lg.	24 St.
20	D-8681	1	Housing	1 15/16 x 2 3/16 x 5	24 St.
21	D-8681	1	Gear	See Note 1	---
22	D-8681	1	Gear	See Note 1	---
23	E-8678	1	Pin	See Note 1	---
24	E-8678	1	Screw	See Note 1	---
25	E-8678	4	Screw	See Note 1	---
26	D-8682	1	Housing	2 3/8 x 2 3/16 x 2.026	24 St.
27	E-8678	2	Collar	See Note 1	---
28	D-8682	1	Shaft	5/8 OD x 3 lg.	587
29	E-8678	1	Soc. Hd. Set Screw	1/2-20 NC-2 x 1/2 lg.	24 St.
30	D-8682	1	"Snap-On" Extension Socket	Drive x 2" lg.	24 St.
31	D-8681	1	Plug	2" OD x 5 1/16 lg.	24 St.
32	D-8681	1	Shaft	1/2 OD x 38 lg.	587
33	E-8678	1	Soc. Hd. Set Screw	1/2-20 NF-2 x 1/2 lg.	24 St.
34	D-8681	1	Block	3/16 Dia. x 1/8 lg.	Oilite Brs.
35	D-8681	1	Bushing	1/2 x 5/8 OD x 3/16	Oilite Brs.
36	D-8682	1	Pin	3/8 Dia. x 1 1/16 lg.	24 St.
37	E-8678	1	Hex Mach. Screw Nut	1/2-20 NF-2	24 St.
38	D-8682	1	Washer	1/2-20 NF-2 x 1/16 thk.	24 St.
39	E-8678	40	Hex Nut	1/2-20 NC-2	24 St.
40	E-8678	1	Taper Pin	3/16 x 7/8 lg.	24 St.
41	D-8682	1	Axis	8 OD x 8 lg.	Drill Rod
42	D-8682	1	Wheel	84 Dia. x 5	Wood & Stl.
43	E-8678	2	Hex Nut	1/2-20 NC-2	24 St.
44	D-8683	2	Hand Railing	As Shown-Iron Pipe	24 St.
45	D-8683	1	Platform Floor	12 x 60 x 4-Bolter	1/2 Angle
46	D-8683	1	As Shown	As Shown	1/2 Angle
47	E-8678	4	125 Cast Iron Flange	For 1 1/2 IPS	Cast Iron
48	E-8678	24	Hex Hd. Bolt	1/2-20 NC-2 x 1 1/2 lg.	24 St.
49	D-8683	1	Channel	4" x 3 1/2 ft. 8.25 #1 ft.	24 St.
50	E-8678	1	Universal	Std. 1" Sq. Dr. or Equiv.	24 St.
51	D-8680	1	Sleeve Half	24 OD x 10 lg.	24 St.
52	E-8678	2	Screw	See Note 1	---
53	D-8679	2	Plug	1" Dia. x 1 lg.	24 St.
54	D-8680	2	Spring	1.000 x 1/2 x 1/2	Phos. Brs.
55	D-8680	4	Stiffener	1.000 x 1/2 x 1	Phos. Brs.
56	D-8680	2	Disk	1/2 OD x 1 1/8 lg.	24 St.
57	D-8682	1	Adapter	See Note 2	---

NOTE 1.
Items 21, 22, 23, 24, 25, 27 & 52 to be taken from "Pizzo"
Universal Gear Joint No. 50 (Furnished)

NOTE 2.
Make Item 57 from "Snap-On" 1/2 sq. drive
extension or equivalent. Use shortest
available length that will give Item 57 a
length of 3" over all.

E-8678

APPROVED FOR CONSTRUCTION

DET. SH. # 5	D-8683
DET. SH. # 4	D-8682
DET. SH. # 3	D-8681
DET. SH. # 2	D-8680
DET. SH. # 1	D-8679

THIS DRAWING HAS BEEN CLASSIFIED AS NOT CLASSIFIED		BUILDING 205 UNIVERSAL EXTENSION WRENCH	
THIS TRACING HAS BEEN CHECKED BY:		OAK RIDGE NATIONAL LABORATORY OPERATED BY CARBIDE AND CARBON CHEMICALS DIVISION UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE	
Health Physics	_____	DECIMALS	_____
Operations	_____	ANGLES	_____
Refuge	_____	SCALE: AS NOTED	_____
Fire Protection	_____		
Maintenance	_____		
Research Shop	_____		

REV.	DATE	REVISIONS	APPD.	DATE
1	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
2	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
3	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
4	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
5	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
6	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
7	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
8	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
9	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
10	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
11	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
12	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
13	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
14	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
15	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
16	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
17	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
18	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
19	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
20	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
21	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
22	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
23	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
24	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
25	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
26	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
27	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
28	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
29	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
30	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
31	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
32	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
33	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
34	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
35	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
36	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
37	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
38	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
39	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
40	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
41	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
42	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
43	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
44	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
45	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
46	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
47	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
48	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
49	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
50	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
51	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
52	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
53	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
54	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
55	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
56	10-1-57	AS SHOWN	W. J. H. H.	10-1-57
57	10-1-57	AS SHOWN	W. J. H. H.	10-1-57

925 079

Name of Tool: Universal Extension Wrench

Description: This tool was designed to operate piping flange bolts at distances up to 27 ft. The tool may be made up in lengths of 9, 18 and 27 ft. by joining 9 ft. sections of 2 inch diameter aluminum tubing. Torque is applied to the wrench with a "T" handle at the top. A 1/2 inch square drive at the lower end will receive commercial sockets of various sizes. Universal joints permit driving of the sockets at any desired angle through a Piezo gear unit located at the lower end.

Location: Unknown

Reference: Designed 12-13-50 by Engineering and Mechanical Division for C. D. Hylton, Chemical Technology Division.

Drawings E-8678, D-8679, D-8680, D-8681, D-8682 and D-8683

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D27788	1	Yoke	See Detail	Mild Stl.
2	"	1	Bottom Die	See Detail	Tool Stl.
3	"	1	Top Die	" "	" "
4	Purchase	4	Spring Eye Bolt	1/4" x 1 1/2" 120 NC	Mild Stl.
5	Purchase	2	Spring	To Suit	Spring Stl.
6	D27788	2	"U" Bolts	See Detail	Mild Stl.
7	Purchase	1	Porto-Power Hydraulic	Blackhawk # P76	"
8	D27788	1	Handle	See Detail	Alum.
9	Purchase	2	Toggle Pin	3/8" x 3 1/2"	Mild Stl.
10	D27788	2	Sliding Bracket	See Detail	" "
11	Purchase	4	Bolts Hex. Hd.	1/2" 20NC 1 1/2"	" "
12	"	4	Nuts	1/2" 20NC	" "
13	"	4	Nuts	3/8" 16NC	" "
14	D27788	1	"V" Block	See Detail	" "
15	Purchase	2	Socket Hd Screw	3/8" 16NC 1 1/2"	" "
16	D27788	1	Handle Adapter	See Detail	" "
17	Purchase	4	Hex Hd Bolts	3/8" 16NC 2 1/2"	" "
18	"	8	Plain Washers	1/2" ID x 1 1/2" OD	" "
19	"	4	Nuts	3/8" 16NC	" "

APPROVED
FOR
CONSTRUCTION

R. B. BRIGGS DEC 18 1956

Crimping Tool - Details		D27787
REFERENCE DRAWINGS		DWG. NO.
H.R.T.		BLDG. 7500
CRIMPING TOOL FOR LEAK DETECTOR LINES ASSY.		
OAK RIDGE NATIONAL LABORATORY OPERATED BY UNION CARBIDE NUCLEAR COMPANY A DIVISION OF UNION CARBIDE AND CARBON CORPORATION OAK RIDGE, TENNESSEE		
SUBMITTED	ACCEPTED	APPROVED
	4/17/54 J.H.T.	W.B. D-17-56
		D-27787

NO.	REVISIONS	DATE	APPR.	APPR.
DRAWING NO. D-27787				
DESIGNED	DATE	CHECKED	DATE	APPROVED
R. Hale	12/15/56	Thomas	12-18-56	M. L. Landon
DATE	SUBMITTED	DATE	APPROVED	DATE
HEALTH PHYSICS	MEDICAL	OPERATIONS	SAFETY	
FIRE PROTECTION	RESEARCH SHOP	MAINTENANCE		

Name of Tool: Crimping Tool

Description: The handle of this tool is a 30 ft. section of $1\frac{1}{4}$ " aluminum pipe. A "C" shaped yoke at the lower end contains a fixed bottom die and movable upper die. The tube is crimped between the dies by force exerted by a hydraulic cylinder. The cylinder is powered by a commercial hydraulic hand pump which can be located at one foot intervals along the handle to facilitate using the tool at various depths. This tool was designed to crimp leak detector lines to approximately 1/2 inch O.D. tube size in the HRT cells.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 12-15-56 by Reactor Experimental Engineering Division.

Drawings D-27787 and D-27788

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	D-19927	1	Special Nut	1/2 x 1/2	Bronze
2	Stock	2	Male Elbow - 1/2 Flare Tube	1/2 x 1/2	6-40275-5-8
3	Stock	1	Rotary Air Motor		
4	Stock	1	Rotary Air Motor		
5	Stock	2	Male Connector 1/2 Flare Tube	1/2 x 1/2	6-40275-5-8
6	Stock	4	Soc. Hd. Cap Screw	5/16-18NC-2 1/2 x 1/8	3. Steel
7	Stock	1	Roll Pin	3/16 dia. x 7/8 lg.	3. Steel
8	Stock	4	Soc. Hd. Cap Screw	1/4-20NC-2 x 5/8 lg.	3. Steel
9	D-19926	1	Pad	.240 x 2 1/2 x 1/4	3. S. 347
10	Stock	6	Flat Hd. Mach. Screw	1/4-20NC-2 x 1/2 lg.	3. Steel
11	D-19926	1	Removable Clamp	1/2 x 1/2 x 1/4	3. S. 347
12	Stock	1	Retaining Ring	"Truarc" #5100-25	3. Steel
13	Stock	2	Soc. Hd. Cap Screw	1/4-20NC-2 x 1/2 lg.	3. Steel
14	D-19927	1	Screw	3/8 dia x 5-1/2	3. Steel
15	D-19926	1	Upper Guide Bracket	5/8 x 1 1/2 x 1/4	3. S. 347
16	Stock	4	Roll Pin	3/32 dia x 3/8 lg.	3. S. 347
17	D-19926	1	Feed Tube (Welded Const)	As shown	3. Steel
18	D-19926	1	Feed Screw	5/8 dia x 38-5/8 lg.	Bronze
19	Stock	2	Roll Pin	1/8 dia x 1/2 lg.	3. Steel
20	D-19926	1	Extension Tube	1/2 x .005 wall x 18-1/2 lg.	3. Steel
21	Stock	1	Bearing	"New Departure 7MM-8	3. Steel
22	Stock	1	Roll Pin	1/8 dia x 1-5/8 lg.	3. Steel
23	D-19926	1	Motor Mount (Welded Const)	As shown	3. S. 347
24	D-19927	1	Long Support (Welded Const)	As shown	Steel
25	D-19927	1	Short Support (Welded Const)	As shown	Steel
26	D-19926	1	Lower Guide Bracket	5/8 x 1 1/2 x 1/4	3. S. 347
27	Stock	2	Soc. Set Screw (Cup Point)	#6-32NC-2 x 5/8 lg.	3. Steel
28	D-19926	1	Fixed Clamp	.397 x 1 1/2 x 1/4	3. S. 347
29	D-19926	2	Key	1/2 x 1/2 x 1/2	3. Steel
30	Stock	2	Woodruff Key	1/2 x 1/2 x 1/2	Steel
31	Stock	2	Soc. Set Screw (Cup Point)	#6-32NC-2 x 1/2 lg.	3. Steel
32	D-19926	1	Key	1-5/8 hex dia lg.	3. S. 347
33	Stock	6	Saw Blade	2 1/2 dia x 3/64 thk.	Steel
34	D-19926	4	Spacer	1-3/4 dia x 1/8 thk.	3. S. 347
35	D-19926	2	Pressure Disk	1 1/2 dia x 3/16 thk.	3. S. 347
36	D-19926	2	Special Nut	1 1/2 hex x 3/8 thk.	Bronze
37	Stock	5	Hex Hd. Mach. Screw	1/4-20NC-2 x 1 lg.	3. Steel
38	Stock	2	Hex Nut	1/4-20NC-2	3. Steel
39	Stock	2	Cotter Pin	1/16 x 1-1/2	Steel
40	D-19926	1	Pressure Foot	2 x 2 x 1/2 angle x 8 lg.	Steel
41	D-19926	1	Guide Bar	1 dia x 37-3/8 lg.	3. S. 347
42	D-19926	1	Extension Tube	1/2 x .005 wall x 17-1/2 lg.	3. Steel
43	D-19926	1	Alteration to Hand Wheel	6" O.D. 1/2-1/4-1/2	3. Steel
44	D-19926	1	Extension Rod	1/2 dia x 17-3/4 lg.	3. Steel
45	D-19926	1	Knob	1 dia x 1/2 thick	25 Alum.
46	Stock	1	Roll Pin	3/32 dia x 1 lg.	3. Steel
47	Stock	1	Roll Pin	1/8 dia x 3/4 lg.	3. Steel
48	D-19926	1	Lever	1/2 x 1-5/8 x 1/8	3. S. 347
49	Stock	1	Hex Hd. Cap Screw	3/8-24NF-3 x 5 lg.	Steel
50	Stock	1	Elastic Stop Nut	"Estop" #78C-004	Steel
51	D-19926	1	Yoke	1 1/2 x 3 x 1-1/2	3. S. 347
52	Stock	1	Hex Hd. Mach. Screw	1/4-20NC-2 x 1 lg.	3. Steel
53	Stock	1	Hex Nut	1/4-20NC-2	3. Steel
54	Stock	1	Washer	1/2 Standard	3. Steel
55	Stock	1	Lock Washer	As shown (Welded Const)	Steel
56	D-19926	1	Support Bracket	As shown (Welded Const)	Steel
57	D-19926	1	Spacer	5/8 dia x 3/82 thk.	Steel
58	D-19926	1	Screw	3/8 dia x 6 lg.	3. Steel

REMARKS:

1. Rotary Air Motors (Items 3 & 4) are Gast Manufacturing Corporation, Model 444 with 1-3/4" hub mounting, 1-1/8" long shaft, for horizontal operation. Item 3 has clockwise rotation with shaft extended toward you. Item 4 has counter-clockwise rotation.

2. Saw Blade (Item 33) is to be 2 1/2" OD, 3/64" thick, 7/8" bore, with 1/8" x 1/16" keyway, suitable for cutting 25 Aluminum.

NOTES:

1. The points of screws (Items 6, 8, 10 & 13) are to be ground flush with surface of parts they are threaded into.

2. Paint Items 24, 25, 40, 43 & 56 except Bearing Surfaces as follows:
A. Remove all rust and scale by sandblasting.
B. Apply 3 coats of Gray Amercoat #23. Bare metal surface must not be left overnight before applying first coat.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.

2. Roughness height values are the maximum with mathematical average deviation from the mean surface, expressed in microinches.

3. For surfaces not otherwise indicated, roughness height shall not exceed .005.

Cut-Off Saw - Detail Sheet #1	D-19926
Cut-Off Saw - Detail Sheet #2	D-19926
Cut-Off Saw - Detail Sheet #3	D-19926
Cut-Off Saw - Detail Sheet #4	D-19926
REFERENCE DRAWINGS	DWG. NO.
CUT-OFF SAW FOR MTR ASSYS. - BLDG. 302B	
CUT-OFF SAW ASSEMBLY	
OAK RIDGE NATIONAL LABORATORY	
OPERATED BY	
CARBIDE AND CARBON CHEMICALS COMPANY	
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION	
OAK RIDGE, TENNESSEE	
SUBMITTED	APPROVED
<i>[Signature]</i>	<i>[Signature]</i>
E-19926	

Name of Tool: Remote Power Hack Saw

Description: This remote hack saw has been found to be very useful and serviceable in dismantling of reactor experiments. The unit is a commercially available saw to which a hydraulic vise that can move in or out for precise positioning has been added. Motor controls have been put on to adjust the back stroke lift and for lifting the blade after a cut. Blades can be changed remotely.

Location: This unit is installed in the Solid States Division hot cells, Building 3025.

NOT CLASSIFIED

MATERIALS LIST					
ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
1	Stock	20	Fillister Hd. Scr.	#8-32 x 1/2 Lp.	Steel
2	D-9832	21	Gasket (Make 50)	1/16" ID x 1/2 OD x 1/32	Neoprene
3	Stock	6	Soc. Hd. Cap Scr.	#10-24 x 3/8 Lp.	Steel
4	D-9831	1	Guide	3/8 x 1 1/16 x 2	Al-24 St.
5	D-9832	2	Rivet (Make 12)	1/8 OD x 1/32 Lp.	Al-23
6	D-9832	1	Blade (Make 2)	1/4 Lp.	As Shown
7	D-9838	3	Set Screw	5/16-24 x 3/8 Lp.	Steel
8	D-9838	1	Plug	As Shown	Al-24 St.
9	Stock	16	Roll Pin	.078 Dia. x 3/8 Lp.	Steel
10	D-9837	6	Sleeve	1/8 x 3/8 OD x 1/2 Lp.	Mild Stl.
11	D-9835	2	Worm Gear	Boston D-1029	Bronze
12	D-9835	1	Worm	1/8-24 x 1 1/2 Lp.	Steel
13	Stock	3	Hex. Nut	#10-24	Steel
14	D-9835	3	Gasket	3/16 ID x 3/8 OD x 1/32	Neoprene
15	D-9835 As Req'd.	Shim	1/8 - 1" OD x .002		Steel
16	D-9835	1	Fork	As Shown	Al-24 St.
17	Stock	3	Snap Ring	Truarc 5100-50	Steel
18	D-9838	5	Shaft	As Specified	Al-25 h
19	D-9837	1	Clamp	Make from	Item 20
20	D-9837	1	Hard Wheel	1 OD x 1 Lp.	Mild Stl.
21	D-9837	1	Hard Wheel	1 OD x 1 1/8 Lp.	Mild Stl.
22	D-9838	1	Plug	2 OD x 5/8 Lp.	Al-24 St.
23	D-9837	1	Shaft	.625 OD x 2 Lp.	Drill Rod
24	Stock	1	Snap Ring	Truarc 5100-48	Steel
25	D-9837	1	Gear	Boston D-1031	Brass
26	D-9835 As Req'd.	Shim	5/8 x 1" OD x .002		Steel
27	D-9837	4	Key	.0625 x .125 x .203	Blue Spr. St.
28	D-9837	1	Bearing	.625 OD x .501 ID x .07/64	Gilite Brz.
29	Stock	3	Roll Pin	.187 Dia. x 1 Lp.	Steel
30	D-9836	6	Link	1/16 x .250 x 2	Blue Spr. St.
31	Stock	6	Snap Ring	Truarc 5100-28	Steel
32	D-9836	1	Bearing	.376 OD x .252 ID x .750	Gilite Brz.
33	D-9836	4	Washer	1/8 OD x 17/64 ID x 1/16	Mild Stl.
34	D-9837	1	Shaft	.250 OD x 2.625 Lp.	Drill Rod
35	Stock	2	Worm	Boston HLTN	Steel
36	D-9836	1	Bearing	.376 OD x .220 ID x .187	Gilite Brz.
37	Stock	4	Fl. Hd. Scr.	#8-32 x 1 Lp.	Steel
38	D-9835	1	Delvial Plate	1 x 2 x 1 7/8	Mild Stl.
39	D-9836	1	Arm	.388 x 2.437 x 2 9/16	Al-24 St.
40	D-9836	1	Bearing	.376 OD x .252 ID x .897	Gilite Brz.
41	D-9836	1	Shaft	.250 Dia. x 2.687	Drill Rod
42	D-9836	2	Pinion	Boston GNSI	Brass
43	D-9836	1	Shaft	.250 Dia. x 1.625	Drill Rod
44	D-9836	1	Bearing	.376 OD x .252 ID x .506	Gilite Brz.
45	D-9833	1	Housing	1.600 ID x 3 x 7/16	Al-24 St.
46	Stock	2	Soc. Hd. Cap Scr.	#10-24 x 1 Lp.	Steel
47	D-9834	1	Jer	.500 x 1.500 x 1.500	S.D.S.
48	D-9834	1	Jer	.800 x 1.500 x 2.000	S.D.S.
49	Stock	1	"O" Ring	AM-62278-12	Neoprene
50	D-9834	1	Bearing	.034 Dia. x .750	Gilite Brz.
51	Stock	1	Soc. Hd. Cap Scr.	#10-24 x 7/16 Lp.	Steel
52	D-9833	3	Washer	18/64 ID x 3/8 OD x 1/16	Mild Stl.
53	D-9830	3	Seal	1 OD x 1/8 ID	Neoprene
54	D-9834	2	Spacer	.437 Dia. x .187	Mild Stl.
55	Stock	2	Snap Ring	Truarc 5100-41	Steel
56	D-9834	1	Seal	1/16 Dia. x .093	Neoprene
57	D-9834	1	Bearing	.750 Dia. x .188	Gilite Brz.
58	D-9834	1	Shaft	.400 Dia. x 1.650	S.D.S.
59	Stock	1	Snap Ring	Truarc 5100-78	Steel
60	D-9833	1	Link	15/16 x .0635	Blue Spr. St.
61	Stock	1	Fl. Hd. Scr.	#8-32 x 1 Lp.	Steel
62	Stock	1	Fl. Hd. Scr.	#8-32 x 3/8 Lp.	Steel
63	Stock	2	Snap Ring	Truarc 5100-112	Steel
64	D-9832	1	Plug	1.118 Dia. x .378	Al-24 St.
65	Stock	1	"O" Ring	AM-62279-15	Neoprene
66	Stock	1	Shoulder Scr.	- Allen Mfg. Co.	Steel
67	D-9832	1	Washer	.750 Dia. x .063	Mild Stl.
68	D-9832	1	Washer	.990 Dia. x .125	S.D.S.
69	D-9832	2	Seal	1.000 OD x .187	Neoprene
70	D-9832	1	Spacer	.750 OD x .187	S.D.S.
71	D-9839	1	Shift	1.000 OD x 8.250	S.D.S.
72	D-9831	1	Bushing	.750 OD x .250	Gilite Brz.
73	D-9831	3	Seal	1.000 OD x .187	Neoprene
74	D-9831	1	Spacer	.038 OD x .187	Mild Stl.
75	Stock	1	Snap Ring	Truarc 5100-100	Steel
76	D-9831	2	Spacer	12/16 OD x .848	Mild Stl.
77	D-9831	1	Seal	.887 OD x .088	Neoprene
78	D-9831	1	Washer	.687 OD x .083 THK.	Gilite Brz.
79	D-9831	1	Washer	.687 OD x .083 THK.	Neoprene
80	D-9830	1	Plug	.750 OD x 1.214	Al-24 St.
81	D-9830	1	Arm	1/2 x .800 x 1.214	Al-24 St.
82	D-9829	1	Spool	6.000 Dia. x 4.187	S.D.S.
83	D-9830	2	Soc. Hd. Cap Scr.	#10-24 x 2 Lp.	Steel
84	D-9829	1	Housing	8.000 x 2.000 x 3.750	Al-24 St.
85	Stock	2	Soc. Hd. Cap Scr.	#10-24 x 3/8 Lp.	Steel
86	D-9829	1	Spool	.500 OD x 1.625	S.D.S.
87	D-9829	1	Seal	1.125 OD x .190	Neoprene
88	D-9829	1	Bearing	.750 OD x .187 Lp.	Gilite Brz.
89	Stock	1	"O" Ring	AM-62278-10	Neoprene
90	D-9830	1	Plug	1/2 x 1 1/16 Lp.	Al-24 St.
91	D-9830	1	Washer	1.125 OD x .187 Lp.	Drill Rod
92	Stock	1	Soc. Hd. Cap Scr.	1/2-20 x 1 Lp.	Steel
93	D-9835	1	Shaft	.625 OD x 2.000 Lp.	S.D.S.
94	D-9834	1	Seal	.500 Dia. x .053	Neoprene
95	Stock	1	Roll Pin	.125 Dia. x 5/16 Lp.	Steel
96	Stock	2	Soc. Hd. Cap Scr.	#5-40 SC-2 x 3/8 Lp.	Steel
97	D-9837	1	Clamp	Make from	Item 20
98	D-9834	1	Bearing	.510 OD x .220 ID x .187	Gilite Brz.

APPROVED FOR CONSTRUCTION

THIS DRAWING
AS NOT CLASSIFIED
PER 24K.100.100
LIMITS ON DIMENSIONS UNLESS
OTHERWISE SPECIFIED
FRACTIONS: 1/16
DECIMALS: 1/100
ANGLES: 1/16
SCALE: 1" = 1"

DET. SH #10	D-9830
DET. SH #9	D-9837
DET. SH #8	D-9836
DET. SH #7	D-9835
DET. SH #6	D-9834
DET. SH #5	D-9833
DET. SH #4	D-9832
DET. SH #3	D-9831
DET. SH #2	D-9830
DET. SH #1	D-9829
REFERENCE DRAWINGS	DWG. NO.
BLDG. 3019	
ASSEMBLY of SAW ATTACHMENT for EXTENSION ARM	
OAK RIDGE NATIONAL LABORATORY	
OPERATED BY CARBIDE AND CARBON CHEMICALS DIVISION	
UNION CARBIDE AND CARBON CORPORATION	
OAK RIDGE, TENNESSEE	
APPROVED	APPROVED
NO 340399	E-9828

Name of Tool: Thermocouple Wire Cut-Off Tool

Description: This tool is used to cut thermocouple wires and other miscellaneous small wires or tubes in the HRT pool. The body of the tool is the same as the Retrieving Socket Torque Wrench, 1½" O.D. aluminum tubing adjustable from 6 ft. to 30 ft. in 4 ft. steps. The lower end has two concentric tool steel cylinders with matching slots at one end. They are rotated with respect to one another for the cut. A lead screw and link mechanism provides the rotary motion. The lead screw is rotated by a handle at the top.

Location: This tool is located at the HRT, Building 7500.

Reference: Designed 7-31-58 by Engineering and Mechanical Division for R. H. Winget, Chemical Technology Division.
Drawings D-27200, D-27216, D-27217, D-27218

Technical drawing of a crimping rod. The drawing shows a cross-section of the rod with a diameter of $\frac{1}{16}$ inch. The rod is shown in two views: a side view and a cross-sectional view. The side view shows a length of $3\frac{1}{2}$ inches, with a maximum length of $3\frac{1}{2}$ inches. The cross-sectional view shows a diameter of $\frac{1}{16}$ inch. The rod is labeled "Med Fit to Item 6" and "Dia. Snug Fit with Item 7". The rod is also labeled "90° ± 0.15° Typical".

⑧ CRIMPING ROD
 Mat'l. - Carpenter Vega Tool SH
 No Req'd - 36
 Note Heat Treat for Max. Toughness

1/4 So Med Fit
To Item 9

22 1/2

1 1/8

1 5/8

1/4

1/4 So

1/4 Dia Max

1/4 Dia Max
To Item 10

1/2 R Typical
.975 Dia Max

1/2 R
Both Ends

10 WRENCH
Mat'l Carpenter Vega Tool Stl
2 Req'd.

Note Heat Treat for Max Toughness

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microlinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{}$.

Assem Shearing Tool	D-1151
Equipment Plan	D-1103
Assembly of Loop Carrier	R-103
REFERENCE DRAWINGS	DWG. NO.

LTR IN PILE LOOP BLDG 3005

ASSEMBLY & DETAILS
TUBE CRIMPING TOOL

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
CARBIDE AND CARBON CHEMICALS COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION
OAK RIDGE, TENNESSEE

SUBMITTED <i>F. Kuyk</i>	ACCEPTED <i>E. J. [unclear]</i>	APPROVED <i>W. W. [unclear]</i>
WO A-1030 Chg 3908-1736-1		D-11443

Name of Tool: Tube Crimping Tool

Description: This tool is used through a lead shield to crimp stainless steel tubing up to .090" diameter preparatory to shearing the tubing with a tube shearing tool (Dwg. D-15510). The tool has two barrels, each of which holds a hardened steel clamp. The tool is slipped over the tubing and the clamps are tightened by means of a ratchet wrench operating a set screw in the clamp. The clamps are detached from the tool by means of locking levers and remain in place on the tubing. The tubing can then be cut between the two clamps, reducing spillage to a minimum. Centerline spacing between the two clamps is 1-5/16".

Location: This tool is used in In-Pile-Loop removal operations at the LITR, Building 3005.

Reference: Designed 9-28-53 by Engineering and Mechanical Division for G. H. Jenks, Reactor Experimental Engineering Division.
Drawing D-11443

Name of Tool: Tube Shearing Tool

Description: This tool is designed to shear tubing up to 1/8" O.D.

while operating through a hole in a lead carrier. The guillotine type cutter is actuated by a lead screw which is manually operated with a ratchet wrench. Length is approximately 12", but could be modified for greater reach. A right angle handle 12" long is provided to resist the torque applied with the operating wrench.

Location: This tool is used at the LITR, Building 3005, for cutting tubing during removal of in-pile-loops from the reactor.

Reference: Designed 9-24-53 by Engineering and Mechanical Division for G. H. Jenks, Reactor Experimental Engineering Division.
Drawing D-15510

Name of Tool: Thermocouple and Power Lead Disconnect Board and
Bolt Rack

Description: These tools are used in HRT maintenance primarily to eliminate the necessity to withdraw other long handled tools during repetitive operations. In the removal or replacement of a piece of apparatus, the power and thermocouple leads are plugged into the disconnect board. This prevents leads from becoming tangled among themselves or on obstructions, and also holds them in position so that the power lead and thermocouple disconnect tools can grasp them. The bolt rack holds all the bolts from a flange or group of flanges so they are more easily accessible to an operator using a handling tool.

Location: These tools are used in the HRT, Building 7500.

Reference: These tools were developed by Reactor Experimental Engineering Division field forces.
No drawings are available.

PARTS LIST

PART NO.	DWG. NO.	NO REQD	DESCRIPTION (NAME, SIZE, ETC.)	MATERIAL
----------	----------	---------	--------------------------------	----------

TYPICAL TOOL ASSEMBLY
WITH FLOATS ATTACHED

3/8-16 NC-2 x 2 3/4 SST. Soc. Hd. Cap Screw 2 Req'd. Per float
 3/8-16 SST. Hex Nut 2 Req'd. Per float
 Lock Washer for 3/8 Screw SST. 2 Req'd. Per float

FLOAT DETAILS

Continuous Weld Typ.
 All welds must be
 water tight and
 ground smooth

SECTION "A-A"
Full Scale

Fillet Weld
 Typ Both Ends

ASSEMBLY	Body Size	LARGE FLOAT		No. Req'd.	SMALL FLOAT		No. Req'd.
		A	C		B	D	
D-25344, D-25326, D-25329, D-25335	1 1/4 I.P.S.	6" O.D. x .065 wall	1 3/4" O.D. x .035 wall	8	4 1/2" O.D. x .065 wall	1 3/4" O.D. x .035 wall	8
D-25339, D-25341,	1 1/2 I.P.S.	6" O.D. x .065 wall	2" O.D. x .035 wall	4	4 1/2" O.D. x .065 wall	2" O.D. x .035 wall	4

Material: 2S Aluminum & As Noted

GENERAL SPECIFICATIONS:

1. Break all sharp edges 1/64 max., unless otherwise specified.
2. The fabricator may choose the type, grade or finish of material unless otherwise specified.

MACHINE FINISH SPECIFICATIONS:

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed 63.

THIS DRAWING
 CLASSIFIED
 AS NOT CLASSIFIED
 PER G. King

LIMITS ON DIMENSIONS UNLESS OTHERWISE SPECIFIED

FRACTIONS: $\pm \frac{1}{64}$

DECIMALS: $\pm$ _____

ANGLES: $\pm$ _____

SCALE: 1/2" = 1"

SHIM ROD HANDLING TOOL	D-25344
FLANGE COVER WRENCH	D-25341
COVER PLATE LUG WRENCH	D-25339
ACCESS COVER LIFTING HOOK	D-25335
REFLECTOR PLUG HANDLING TOOL	D-25329
FUEL ELEMENT & REFLECTOR HANDLING TOOL	D-25326
REFERENCE DRAWINGS	DWG. NO.

TOOLS & BRIDGE FOR O.R.R. BLDG. NO. 3042

TOOL FLOAT ASSEMBLY
& DETAILS

OAK RIDGE NATIONAL LABORATORY

OPERATED BY

UNION CARBIDE NUCLEAR COMPANY

A DIVISION OF UNION CARBIDE AND CARBON CORPORATION

OAK RIDGE, TENNESSEE

DESIGNED	DATE	CHECKED	DATE	APPROVED	DATE
M. Kroppf	4-2-56	S. Lewis	4-3-56		
DESIGNED	DATE	SUBMITTED	DATE	APPROVED	DATE
		A. M. Thayer	4-11-56	H. S. Gamm	4-24-56

D-23424

REV

Name of Tool: Tool Float Assembly

Description: These assemblies are hollow semi-cylinders of aluminum, which clamp around tool bodies to support the weight of the tools used in underwater operations at the ORR. Each section is 6'-3" long and sections of two different outside diameters are used to provide better tool balance.

Location: These floats will be used in the pool of the ORR, Building 3042.

Reference: Designed 7 6-56 by Engineering and Mechanical Division for J. A. Cox, Reactor Operations.
Drawing D-23424

ITEM NO.	DWG. NO.	QTY.	NAME	SIZE	MATERIAL
----------	----------	------	------	------	----------

ITEM	OPERATION	NO OF OPERATIONS	LOCATION	REQ'D TOOLS	REMARKS
1	Crimping .062, .080, & .090 Dia Tubes - 2 Places each Tube	10	at Front of Shield Plug	Tube Crimping Tool Dwg. D-11443	
2	Cutting Tubes	5	"	Tube Shearing Tool Dwg. D-15510	
3	Cutting $\frac{1}{8}$ " Dia Tubes	9	"	Standard Bolt Clippers	
4	Cutting Wires	24	"	Standard Wire Cutters	
5	Crimping .062, .080, & .090 Dia Tubes - 2 Places each Tube	10	at Connector in Loop Carrier	Remote Wrench with Attachments "A" & "B"	
6	Cutting Tubes	5	"	Tube Cutter & Ball Peen Hammer	
7	Cutting $\frac{1}{8}$ " Solder Sleeve	7	"	Special Solder Gun	
8	Wire Cutting (All)	1	"	Wire Cutter & Ball Peen Hammer	
9	Disconnecting Bayonet Locking Screw	1	"	Remote Wrench with Attachments "A" & "B"	
10	Attaching Cable Shoulder Screw	1	"	Remote Wrench with Attachment "C"	Be sure Shield Plug is Weld with Direction only before installing shoulder screw

1. Finish symbols are in accordance with ASA Standard B46.1 - 1947.
2. Roughness height values are the maximum arithmetical average deviation from the mean surface, expressed in microinches.
3. For surfaces not otherwise indicated, roughness height shall not exceed $\sqrt{\quad}$.

THIS DRAWING
CLASSIFIED
~~NOT CLASSIFIED~~
PER S. J. [Signature]
LIMIT ON DIMENSIONS UNLESS
OTHERWISE SPECIFIED
FRACTIONS: $\pm$ $\frac{1}{64}$
DECIMALS: $\pm$.005
ANGLES: $\pm$ 2°
SCALE: FULL

Connector for Loop Container & Shield Plug	D-11448
Equipment Plan	D-11436
Assembly of Loop Carrier	E-16390
Tube Crimping Tool	D-11443
Tube Shearing Tool	D-15510
REFERENCE DRAWINGS	DWG. NO.

LITR IN FILE LOOP BLDG 3005
MISCELLANEOUS DISASSEMBLY TOOLS

OAK RIDGE NATIONAL LABORATORY
OPERATED BY
CARBIDE AND CARBON CHEMICALS COMPANY
A DIVISION OF UNION CARBIDE AND CARBON CORPORATION

OAK RIDGE, TENNESSEE			
SUBMITTED	ACCEPTED	APPROVED	
<i>B. King</i>	<i>E. J. ...</i>	<i>R. W. Wuest</i>	
WO A. 8050.		P-11444	REV A

UNCLASSIFIED MASTER

X-822

OAK RIDGE NATIONAL LABORATORY
Operated By
UNION CARBIDE NUCLEAR COMPANY

POST OFFICE BOX P
OAK RIDGE, TENNESSEE

ORNL
CENTRAL FILES NUMBER

58-5-110

External Transmittal Authorized

COPY NO. 116

HRP-MET-26

DATE: May 28, 1958
SUBJECT: Metallurgical Examination of Valve
Trim From HRP Dump Valve Test Loop
TO: A. M. Billings
FROM: F. W. Cooke

SUMMARY

An investigation of trim from the HRP Dump Valve Test Loop revealed that performance improved with increasing poppet hardness. From this it was hypothesized that deformation of softer poppets increased the poppet-seat contact area, thus reducing the closing pressure. The deformation areas of a number of poppets were measured and the closing pressures calculated. A plot of closing pressure against leak rate showed a fair correlation and tends to support the hypothesis.

NOTICE

This document contains information of a preliminary nature and was prepared primarily for internal use at the Oak Ridge National Laboratory. It is subject to revision or correction and therefore does not represent a final report.

UNCLASSIFIED

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.

On 9-19-57, A. M. Billings submitted for examination five sets of trim from the HRP dump valve test loop. The purpose of the examination was to determine the effect, if any, of metallurgical variables on service performance.

These and the trim subsequently examined were of the design shown in Fig. 1, consisting of 347 type stainless steel seats and various poppet materials. They were tested at temperatures of 250 to 300°C in uranyl sulfate solutions for approximately 400 dumps.¹

The various sets of trim were distinguished according to the poppet material. For the conditions and results of each test, as well as a description of the various poppet materials, see Table 1. Service performance was equated to the increase in leak rate due to being tested. Small leaks were measured by the rise in pressure (microns/minute) in a vacuum system attached to one side of the valve, the other side being at atmospheric pressure. When the rigors of the test caused a valve to leak at a rate in excess of 50 microns/minute, the rate of leakage of high pressure water, or nitrogen, was used to determine the leak rate. It is not possible to convert these rates into microns/minute, but any leak rate expressed in terms of mL/min., or cc/min., is in excess of 50 µ/min. Service performance (microns/min.) equals the leak rate after testing minus the leak rate before testing.

Initially, five sets of trim were examined under the low power microscope. The amount of misalignment, discoloration, type and degree of deformation, and evidence of galling and scoring were all observed. None of these seemed correlated with performance. It was observed, however, that the harder poppets seemed to perform better. Because of the geometry involved, the hardness was measured on the ends of the poppets and not at the actual seating areas. The poppet hardness of eleven more sets of trim was determined. Some sets of trim were not examined, as explained in the Appendix. The rough correlation which exists between this parameter and performance may be seen in Fig. 2. The Rockwell "A" scale was used, as it alone covered the range of hardness encountered.

This correlation may be explained in part by the fact that annealed, or partially annealed, 347 stainless steel, of which all the seats were made, work hardens rapidly and to high hardnesses, due to martensite formation during deformation. The seat, initially softer than the poppet, must be deformed at the point of contact and is thus hardened. With repeated closings the seat hardness approaches that of the poppet, and the hardness differential between them is eliminated. It is reported by A. M. Billings that such a hardness differential is considered desirable.

That the area of contact of the seat is highly deformed to a shallow depth is shown in Fig. 8 and 9. (These photomicrographs are of area "A" in Fig. 1.)

1. A. M. Billings, "Valve Test Loop Operation, November 23, 1955 thru October 18, 1957," ORNL CF-57-12-57.

It is of interest that the hardness of the poppets which gave the best performance (that is the hardest poppets), is about the same as the maximum hardness which 347 stainless steel can attain by work hardening (Fig. 2).

It is further hypothesized by Dr. M. L. Picklesimer of the HRP Metallurgy Group that as the seat hardness approached that of the poppet, the poppet would begin to be deformed. This would cause an increase in the contact area and a decrease in the closing pressure at the poppet-seat interface. The softest poppets might be expected to deform most.

In order to check this idea, a jig was made to hold the poppets. It was mounted on the Bausch and Lomb Metallograph in the Y-12 Metallography Laboratory. In this way the conical surface of the poppet could be viewed at 100X magnification. The maximum and minimum widths of the deformation area were measured in mils. From this the area of the deformed band could be calculated. (See Appendix for details of calculations.) This was assumed to be the same as the area of contact, or bearing area, between poppet and seat. This area is plotted against service performance in Fig. 3. Again the correlation is in the expected direction but is rough.

From a knowledge of the actuating air pressures and the 86 sq. in. area of the actuation diaphragm, the closing pressure on the bearing areas was calculated. (See Appendix for details of calculations.) The plot of closing pressure against performance showed the strongest correlation of all the variables considered (Fig. 4).

Fig. 5 is a plot of the maximum width of the deformed area against performance. This showed some correlation. Fig. 6 is a similar plot using the minimum widths and there is no real correlation. Since the area is related to performance and is a direct function of the widths, it is obvious that at least one of the two widths must also be related to performance. The significance of the fact that the related width was the maximum rather than the minimum is not known.

The plot of the difference of the maximum and minimum widths against performance shows the effect of misalignment of poppet and seat. As suspected, misalignment plays a minor roll (Fig. 7).

Fig. 10 is a photomicrograph of a section through the deformation band on a Zircaloy-2 poppet the hardness of which was Ra 46. The deformation is severe and the band wide. However, it should be noted that a shoulder has been formed such that its surface is at right angles to the closing force. This shoulder presumably supported most of the closing force during the bulk of the test.

Other points which serve to cloud the results are: 1) the variations in conditions from one test to another; 2) the error involved in measuring deformation band width; 3) the assumption that the deformation band area equals the bearing area; 4) the existence of what appeared to be channels across the deformation bands of poppets with good performance records; 5) the unconsidered fact that the valves close at high speeds; and 6) the fact that statistical confidence is low due to the fewness of the sets of trim observed.

It is not felt that these data are a corroboration of the hypothesis expressed, though they do tend in this direction. Probably this line of reasoning would be invalid for designs which required small closing forces and for such designs as that using a gold insert for one of the contact members. In the light of these results, however, the following recommendations for materials to be tested seem in order.

<u>Poppet</u>	<u>Seat</u>
AM355 (Rc 46) vs.	311 SS (Rc 33 Max)
AM355 (Rc 46) vs.	347 SS (Rc 41 Max)
17-4PH (Rc37) vs.	311 SS (Rc 33 Max)

Though the corrosion resistance of AM355 in uranyl sulfate solutions is doubtful, the extremely poor performance of AM355 poppets tested since this investigation was begun, is due to lack of composition control by the supplier and to improper heat treatment. The material tested was double aged, which is known to have very poor corrosion resistance. It should be used in the sub-zero cooled and tempered (S.C.T.) condition. Stainless steel type 311 may be expected to have corrosion resistance similar to 304 stainless steel. The combinations suggested above are such that at least some hardness differential between poppet and seat would be maintained for the duration of the test.

The metallographic studies were performed by the Y-12 Metallography Group.

Table 1

Trim No.	Material Plug	Number Dumps	Leak Rate/Min.		Air Pressure	Remarks
			Before	After		
S-1	#347SS	100	6 μ	14 μ	50#	Old design
S-2	#347SS	224	6 μ	50 ML	40#	Plug & seat scored
S-3	#347SS	404	3 μ	30 μ	50#	O.K.
S-4	#347SS	408	5 μ	50 μ	40#	O.K.
S-5	#347SS	440	3 μ	20 μ	45#	O.K.
ST-1	Stel.#6	300	16 μ	Too great	50#	Too much lapping
ST-2	Stel.#6	100	7 μ	Too great	50#	Unsatisfactory
ST-3	Stel.#6	400	6 μ	30 μ	50#	O.K. OK
ST-7	Stel.#6	400	3 μ	50 μ	45#	O.K. Cleveland
TL10-1	Titanium	326	7 μ	500 ML	50#	Not so good
TL30-1	Titanium	404	6 μ	16 μ	50#	O.K.
TL30-4	Titanium	402	10 μ	Too great	45#	No good--Mat'l fused
TM-1	Titanium	75	5 μ	Too great	45#	No good--Mat'l fused
G-1	Gold ring	203	7 μ	16 μ	50#	O.K.
G-2	Gold ring	356	3 μ	Too great	40#	Not so good. Bad alignment
G-3	Gold ring	404	3 μ	10 μ	40#	O.K.
G-4	Gold ring	496	5 μ	50 μ	40#	O.K.
HRT 1/2"	#347SS	440	1 μ	20 μ	45#	O.K.
HRT 1"	#347SS	440	3 μ	30 μ	45#	O.K.
PH-2	17-4 PH	402	6 μ	50 μ	40#	O.K.
PH-3	17-4 PH	442	5 μ	30 μ	40#	O.K.
PH-4	17-4 PH	438	8 μ	20 μ	40#	O.K.
PH-5	17-4 PH	404	6 μ	50 μ	40#	O.K.
PH-6	17-4 PH	440	6 μ	7 μ	40#	Excellent
PT-1	347SS w. 80% Pt. 20% IR.	444	10 μ	50 μ	45#	O.K.
PT-2	"	408	10 μ	15 ML	45#	O.K.
PT-E1	#347SS 80% Pt. 10% AU (E-872)	456	10 μ	67 ML	45#	Fair. Cap worked loose
PT-E2	"	420	10 μ	1.5 ML	45#	O.K.
PT-E3	#347SS 70% Pt. 20% AU (E-130)	448	10 μ	1.5 ML	45#	O.K.
PT-E4	"	448	10 μ	165 cc	45#	O.K.
AL-1	#347SS w. AL.OX	46	10 μ	Too great	45#	Failed after 46 dumps
HRT 1/2"	17-4 PH	412	10 μ	50 μ	45#	O.K.
TC-1	#347SS w. Tung.C Pt. Binder	424	10 μ	100 cc	45#	O.K.
K501-1	Kenna #501	3	10 μ	Too great	45#	Plug fractured after 3 dumps
TC-2	#347SS w. Tung.C Pt. Binder	420	10 μ	30 μ	40#	O.K.

(Cont'd)

Table 1 (Cont'd)

Trim No.	Material Plug	Number Dumps	Leak Rate/Min.		Air Pressure	Remarks
			Before	After		
K96-1	Kenna #96	60	Too great	Too great	40#	Fractured after 60 dumps
S-6	#347SS	1476	10 μ	20 ML	40#	O.K.
ZR-1	Zirc. #2	400	10 μ	27 ML	40#	O.K. Valve slightly out of line
ZR-2	Zirc. #2	440	12 μ	10 ML	40#	O.K.

Table 2

	Trim	Max. Width (Mils)	Min. Width (Mils)	Max-Min Widths (Mils)	Bearing Area (sq.in.)	Closing Pressure on Bear- ing Area psi	Poppet Hardness Ra	Leak Rate Microns/ Minute
1	PH-6	--	--	--	--	--	67	1
2	S-1	34	10	24	0.0690	23,800	46*	8 (100 Dumps)
3	PH-4	12	8	4	0.0314	38,400	67.5	12
4	S-5	--	--	--	--	--	66*	17
5	Tc-2	22	14	8	0.0565	21,400	68*	20
6	ST-3	26	12	14	0.0597	27,200	--	24
7	PH-3	16	10	6	0.0408	29,400	67.5	25
8	S-3	58	19	39	0.120	13,600	46*	27
9	PT-1	26	24	2	0.0785	18,100	61	40
10	PH-5	--	--	--	--	--	64	44
11	PH-2	26	12	14	0.0597	20,100	62	40
								<u>ml/min.</u>
13	PT-E3	48	20	28	0.107	13,200	5.9	1.5
14	PT-E2	44	22	22	0.112	12,600	56	1.5
15	PT-2	--	--	--	--	--	50	15
16	Zr-1	--	--	--	--	--	46	27
								<u>cc/min.</u>
17	PT-E4	40	19	21	0.0926	15,200	57	165

* Doubtful results, See Appendix.

Fig 1. VALVE POPPET AND SEAT

FIGURE 2

Refer to TABLE 2 for values

Fig. 3. Leak Rate vs. Bearing Area

Fig. 4. Leak Rate vs. Closing Pressure .