Phil
280
5/26/67

ORNL-NSIC-34
UC-80 — Reactor Technology

OAK RIDGE NATIONAL LABORATORY

operated by
UNION CARBIDE CORPORATION

for the
U.S. ATOMIC ENERGY COMMISSION

MASTER

INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 9

NSIC STAFF

NUCLEAR SAFETY INFORMATION CENTER

NSIC

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

THIS DOCUMENT HAS BEEN REVIEWED,
NO INVENTIONS OF PATENT INTEREST
TO THE A.E.C. ARE DISCLOSED THEREIN.

2886-1-67

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NUCLEAR SAFETY

A QUARTERLY REVIEW JOURNAL PREPARED BY NSIC

Nuclear Safety covers significant developments in the field of nuclear safety.

The scope is limited to topics relevant to the analysis and control of hazards associated with nuclear reactors, operations involving fissionable materials, and the products of nuclear fission.

Primary emphasis is on safety in reactor design, construction, and operation; however, safety considerations in reactor fuel fabrication, spent-fuel processing, nuclear waste disposal, handling of radioisotopes, and related operations are also treated.

Qualified authors are invited to submit interpretive articles, which will be reviewed for technical accuracy and pertinency. Authors will be advised as soon as possible of acceptance or suggested changes. Send inquiries or 3 copies of manuscripts (with the draftsman's original line drawings plus 2 copies, and with continuous-tone glossy prints of photographs plus 2 copies) to J. P. Blakely, Oak Ridge National Laboratory, P. O. Box Y, Oak Ridge, Tennessee 37830.

Nuclear Safety is prepared by the Nuclear Safety Information Center at Oak Ridge National Laboratory for the U.S. Atomic Energy Commission, Division of Technical Information. For subscriptions, address Superintendent of Documents, U.S. Government Printing Office, Washington, D. C. 20402. The subscription rate is \$3.00 per year. Below is an order blank for your convenience.

U.S. GOVERNMENT PRINTING OFFICE
DIVISION OF PUBLIC DOCUMENTS
WASHINGTON, D.C. 20402

POSTAGE AND FEES PAID
U.S. GOVERNMENT PRINTING OFFICE

OFFICIAL BUSINESS

RETURN AFTER 5 DAYS

Name _____
Address _____
City _____ State _____ Zip _____

----- TO INSURE PROMPT, ACCURATE SHIPMENT, PLEASE PRINT OR TYPE CORRECT ADDRESS ON MAILING LABEL ABOVE -----

MAIL ORDER FORM To:

Superintendent of Documents, Government Printing Office, Washington, D.C., 20402

Enclosed find \$ _____ (check, money order, or Supt. of Documents coupons).

Please send me _____ annual subscriptions to Nuclear Safety
at \$3.00 per subscription.

Name _____
Address _____
City _____ State _____ Zip _____

Please charge these
publications to my Deposit
Account No. _____

FOR USE OF SUPT. DOCS.

Enclosed _____
To be mailed _____
later _____
Subscription _____
Refund _____
Coupon refund _____
Postage _____

USAE Division of Technical Information Extension, Oak Ridge, Tennessee

CONTRACT NO. W-7405-ENG-26

CESI PRICES

NUCLEAR SAFETY INFORMATION CENTER

H.C. \$ 3.00; MN 65

INDEXED BIBLIOGRAPHY OF CURRENT
NUCLEAR SAFETY LITERATURE - 9

NSIC STAFF

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

MAY 1967

OAK RIDGE NATIONAL LABORATORY
OAK RIDGE, TENNESSEE
OPERATED BY
UNION CARBIDE CORPORATION
FOR THE
U.S. ATOMIC ENERGY COMMISSION

Printed in the United States of America. Available from Clearinghouse for Federal
Scientific and Technical Information, National Bureau of Standards,
U.S. Department of Commerce, Springfield, Virginia 22151
Price: Printed Copy \$3.00; Microfiche \$0.65

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

FOREWORD

THE INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE IS PUBLISHED FOUR TIMES ANNUALLY UNDER THE AUSPICES OF THE NUCLEAR SAFETY INFORMATION CENTER. THE CENTER WAS ESTABLISHED IN MARCH 1963 AT THE OAK RIDGE NATIONAL LABORATORY UNDER THE SPONSORSHIP OF THE U. S. ATOMIC ENERGY COMMISSION AND SERVES AS A FOCAL POINT FOR THE COLLECTION, STORAGE, EVALUATION, AND DISSEMINATION OF NUCLEAR SAFETY INFORMATION. IT CONTAINS AN EXTENSIVE COLLECTION OF MATERIAL FILED IN A MANUAL RAPID-ACCESS SYSTEM TO PROVIDE READY ANSWERS TO QUESTIONS ARISING IN THE FIELD OF NUCLEAR SAFETY.

BIBLIOGRAPHIC DATA AND ABSTRACTS HAVE BEEN STORED IN BOTH A COMPUTER AND A MANUAL FILE SINCE SEPTEMBER 1964. THE PRODUCTION OF THIS BIBLIOGRAPHY WAS MADE POSSIBLE THROUGH IBM-7090 COMPUTER PROGRAMS DEVELOPED BY THE INFORMATION SYSTEMS DEPARTMENT OF THE COMPUTER SCIENCES CENTER AT OAK RIDGE.

BIBLIOGRAPHIC ITEMS HAVE BEEN SORTED INTO 19 CATEGORIES OF NUCLEAR SAFETY INFORMATION. ITEMS MAY APPEAR IN AS MANY AS THREE CATEGORIES. A SELECTOR INDEX AND AN AUTHOR INDEX ARE PROVIDED FOR THE CONVENIENCE OF THE USER.

EACH BIBLIOGRAPHIC ITEM CONSISTS OF AUTHOR(S), TITLE, CORPORATE AUTHOR(S), NUMBER OF PAGES, TABLES, FIGURES, REFERENCES, DATE, DOCUMENT NUMBER(S), AVAILABILITY (IF NOT OBVIOUS), AN INFORMATIVE ABSTRACT OF LESS THAN 100 WORDS, AND SEVERAL SELECTOR TERMS. THE SELECTOR TERMS OR KEYWORDS ARE ASSIGNED BY NSIC PERSONNEL TO SERVE AS COORDINATE INDEXING TERMS FOR STORAGE AND FUTURE RETRIEVAL OF INFORMATION. THE MOST SIGNIFICANT SELECTOR TERMS FOR EACH BIBLIOGRAPHIC ENTRY ARE ASTERISKED AS WEIGHTING FACTORS. SELECTOR TERMS ARE INCLUDED WITH THIS BIBLIOGRAPHY SINCE THEY CAN, THROUGH THE SELECTOR INDEX, BE OF AID TO THE READER IN LOCATING ITEMS OF INTEREST. MANY READERS, HOWEVER, WILL PREFER TO SCAN THE CATEGORIES MOST RELATED TO THEIR FIELD OF INTEREST.

NSIC STAFF MEMBERS SELECTED, EXTRACTED, AND KEYWORDED THE VARIOUS ENTRIES IN THE BIBLIOGRAPHY. THE ASSIGNMENTS OF THE STAFF MEMBERS, MOST OF WHOM WORK HALF TIME FOR THE CENTER, ARE AS FOLLOWS

WM. B. COTTRELL - DIRECTOR
J. R. BUCHANAN - ASST. DIRECTOR AND CONTAINMENT OF NUCLEAR FACILITIES
J. P. BLAKELY - GENERAL SAFETY CRITERIA AND SOURCES OF ENERGY RELEASE
UNDER ACCIDENT CONDITIONS
E. N. CRAMER - OPERATIONAL SAFETY AND EXPERIENCE
W. K. ERGEN - REACTOR TRANSIENTS, KINETICS, AND STABILITY
M. H. FONTANA - HEAT TRANSFER AND FLUID DYNAMICS
D. G. JACOBS - RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT
G. W. KEILHOLTZ - FISSION-PRODUCT RELEASE, TRANSPORT, AND REMOVAL
T. F. LOMENICK - ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION
EXPOSURE OF MAN
W. C. MCCLAIN - EARTHQUAKE CONSIDERATIONS IN NUCLEAR PLANT DESIGN
T. L. MCLEAN - NUCLEAR INSTRUMENTATION, CONTROL AND SAFETY SYSTEMS
J. G. MERKLE - STRUCTURAL INTEGRITY
C. M. MURPHY - INFORMATION SPECIALIST
H. G. OBRIEN - NUCLEAR INSTRUMENTATION, CONTROL AND SAFETY SYSTEMS
J. B. PUCH - RADIOCHEMICAL PLANT SAFETY AND PLANT SAFETY FEATURES
R. L. SCOTT - OPERATIONAL SAFETY AND EXPERIENCE
L. B. SHAPPERT - TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS
C. S. WALKER - NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS
H. B. WHETSEL - TECHNICAL EDITING
M. L. WINTON - SDI PROGRAM
S. P. HENDRIX - INFORMATION SPECIALIST
R. G. WALLACE - INFORMATION SPECIALIST

THE SERVICES OF THE CENTER INCLUDE PRINCIPALLY (1) PREPARATION OF STATE-OF-THE-ART REPORTS (ISSUED WITH ORNL-NSIC REPORT NUMBERS) IN THE SUBJECT AREAS LISTED ABOVE WITH STAFF ASSIGNMENTS, (2) PREPARATION OF THE QUARTERLY TECHNICAL PROGRESS REVIEW, NUCLEAR SAFETY, (3) ANSWERING TECHNICAL INQUIRIES AS TIME IS AVAILABLE, AND (4) COUNSEL AND GUIDANCE ON NUCLEAR SAFETY PROBLEMS IN THE ABOVE SUBJECT AREAS. THE COMPUTER CODE USED IN THE PREPARATION OF THIS BIBLIOGRAPHY IS ALSO USED FOR SELECTIVE DISSEMINATION OF INFORMATION AND SPECIAL LITERATURE SEARCHES.

SERVICES OF THE NSIC ARE AVAILABLE WITHOUT CHARGE TO GOVERNMENT AGENCIES, RESEARCH AND EDUCATIONAL INSTITUTIONS, AND THE NUCLEAR INDUSTRY. THE NSIC SERVICES ARE AS LISTED ABOVE BUT UNDER NO CIRCUMSTANCES DO THEY INCLUDE FURNISHING COPIES OF ANY DOCUMENTS (EXCEPT NSIC REPORTS) ALTHOUGH ALL DOCUMENTS MAY BE EXAMINED AT THE CENTER BY QUALIFIED PERSONNEL. INQUIRIES CONCERNING THE CAPABILITIES AND OPERATION OF THE CENTER MAY BE ADDRESSED TO

J. R. BUCHANAN, ASSISTANT DIRECTOR
(PHONE 615-483-8611 EXT. 3-7253)
NUCLEAR SAFETY INFORMATION CENTER
OAK RIDGE NATIONAL LABORATORY
POST OFFICE BOX Y
OAK RIDGE, TENNESSEE 37830

THE PUBLICATIONS CONTAINED IN THIS REPORT WERE PROCESSED BY THE NSIC STAFF DURING THE PERIOD ENDING IN JANUARY 1967.

PREVIOUS NUCLEAR SAFETY INFORMATION CENTER BIBLIOGRAPHIC REPORTS ARE AS FOLLOWS

ORNL-NSIC-8	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 1	APRIL, 1965
ORNL-NSIC-9	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 2	AUGUST, 1965
ORNL-NSIC-12	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 3	NOVEMBER, 1965
ORNL-NSIC-14	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 4	MARCH, 1966
ORNL-NSIC-16	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 5	JUNE, 1966
ORNL-NSIC-19	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 6	SEPTEMBER, 1966
ORNL-NSIC-20	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 7	NOVEMBER, 1966
ORNL-NSIC-32	INDEXED BIBLIOGRAPHY OF CURRENT NUCLEAR SAFETY LITERATURE - 8	MARCH 1967

TABLE OF CONTENTS

	PAGE
FOREWORD	III
CATEGORY SCOPE NOTES	1
BIBLIOGRAPHY	
CATEGORY 1, GENERAL SAFETY CRITERIA	3
CATEGORY 2, SITING OF NUCLEAR FACILITIES	14
CATEGORY 3, TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS	15
CATEGORY 4, AEROSPACE SAFETY	18
CATEGORY 5, ACCIDENT ANALYSIS	24
CATEGORY 6, REACTOR TRANSIENTS, KINETICS, AND STABILITY	50
CATEGORY 7, FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL	73
CATEGORY 8, SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS	87
CATEGORY 9, NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS	93
CATEGORY 10, ELECTRICAL POWER SYSTEMS	110
CATEGORY 11, CONTAINMENT OF NUCLEAR FACILITIES	111
CATEGORY 12, PLANT SAFETY FEATURES	130
CATEGORY 13, RADIOCHEMICAL PLANT SAFETY	135
CATEGORY 14, RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT	139
CATEGORY 15, ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN	150
CATEGORY 16, METEOROLOGICAL CONSIDERATIONS	173
CATEGORY 17, OPERATIONAL SAFETY AND EXPERIENCE	178
CATEGORY 18, SAFETY ANALYSIS AND DESIGN REPORTS	218
CATEGORY 19, BIBLIOGRAPHIES	240
SELECTOR INDEX	241
PERSONAL AUTHOR INDEX	260
APPENDIX	
REFERENCE SOURCES	275

CATEGORY SCOPE NOTES

A BRIEF EXPLANATION OF THE COMPOSITION OF EACH CATEGORY WITHIN THE SCOPE OF THE NUCLEAR SAFETY INFORMATION CENTER FOLLOWS

1. GENERAL SAFETY CRITERIA

THIS CATEGORY ENCOMPASSES ALL SAFETY ASPECTS OF RADIATION PHILOSOPHY, STANDARDS, CODES, COST, FINANCIAL LIABILITY AND INSURANCE. OTHER ITEMS OF INTEREST ARE CRITICALITY SAFETY AND THE COMPARATIVE RISK TO THE PUBLIC HEALTH AND SAFETY FROM NUCLEAR AND NONNUCLEAR HAZARDS.

2. SITING OF NUCLEAR FACILITIES

THIS CATEGORY DEALS WITH DOCUMENTS RELATED TO THE FACTORS USED IN EVALUATING SITES SUCH AS CHARACTERISTICS OF THE FACILITY DESIGN, PROPOSED OPERATION, POPULATION DENSITY, USE CHARACTERISTICS OF THE SITE ENVIRONS, PHYSICAL CHARACTERISTICS OF THE SITE, AND THE RELATIONSHIP OF ENGINEERED SAFEGUARDS TO NUCLEAR FACILITY SITING.

3. TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS

THIS CATEGORY CONTAINS ARTICLES DEALING WITH SHIPPING CONTAINERS, SHIPPING REGULATIONS, CRITICALITY SAFETY AS RELATED TO SHIPPING AND HANDLING, TRANSPORTATION ACCIDENTS, AND ALL OTHER ITEMS DEALING WITH SAFETY DURING THE TRANSPORTATION AND/OR HANDLING OF RADIOACTIVE MATERIALS.

4. AEROSPACE SAFETY

THIS CATEGORY COVERS SAFETY CONSIDERATIONS SUCH AS LAUNCH AND REENTRY PROBLEMS THAT ARE UNIQUE TO NUCLEAR SYSTEMS USED IN AEROSPACE VEHICLES.

5. ACCIDENT ANALYSIS

ALL FACETS OF THE ANALYSIS OF POSTULATED ACCIDENTS ARE CONSIDERED IN THIS CATEGORY. INCLUDED ARE BURNOUT HEAT FLUX, CRITICAL HEAT TRANSFER, RELIABILITY ANALYSIS, IN PILE EXPERIMENTS, COOLANT ACTIVITY BUILDUP, PIPE RUPTURE, AND EXPERIMENTS, I.E. LOFT. EXPERIMENTS RELATED TO REACTOR KINETICS ARE CATALOGED IN CATEGORY 6.

6. REACTOR TRANSIENTS, KINETICS, AND STABILITY

THIS CATEGORY INCLUDES THE VARIOUS STUDIES, BOTH ANALYTICAL AND EXPERIMENTAL, SUCH AS TREAT AND SPERT IN WHICH THE TRANSIENT BEHAVIOR OF REACTORS AND CRITICALITY ACCIDENTS ARE EXAMINED.

7. FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

THE RELEASE OF FISSION PRODUCTS FROM VARIOUS MATERIALS AND THEIR MOVEMENT WITHIN A NUCLEAR FACILITY CONTAINMENT SYSTEM ARE INCLUDED IN THIS CATEGORY. TRANSPORT OF THE FISSION PRODUCT INVOLVES THE PHYSICAL AND CHEMICAL CHARACTERIZATION OF THE RELEASED RADIOACTIVE MATERIALS, AS WELL AS THE VARIOUS MECHANISMS SUCH AS DEPOSITION, ADSORPTION, FILTRATION, FALLOUT, ETC., THAT WOULD ATTENUATE THEIR CONCENTRATION WITHIN THE CONTAINMENT SYSTEM.

8. SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

SOURCES OF ENERGY CONSIDERED IN THIS CATEGORY INCLUDE NUCLEAR, WIGNER, AND GAMMA ENERGIES, AS WELL AS CHEMICAL REACTIONS, METAL-WATER REACTIONS, AND ANY OTHER TYPES OF ENERGY THAT MIGHT BE RELEASED AS THE RESULT OF A NUCLEAR ACCIDENT.

9. NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

THE DESIGN OF CONTROL AND SAFETY SYSTEMS FOR VARIOUS NUCLEAR PROCESSES, AS WELL AS THE REQUIRED INSTRUMENTATION AND HARDWARE, ARE INCLUDED IN THIS CATEGORY. THE PROBLEMS INVOLVED ARE THE PERFORMANCE REQUIRED OF SAFETY SYSTEMS THE SPECIFICATION OF INSTRUMENTATION THE CONCEPTS OF COINCIDENCE, REDUNDANCE, FAILURE MODES, AND RELIABILITY THE ADEQUACY OF SHUTDOWN MARGINS THE DESIGN FEATURES OF DIFFERENT MECHANICAL DEVICES AND RELATED SUBJECTS.

10. ELECTRICAL POWER SYSTEMS

INFORMATION RELATED TO ROUTINE AND EMERGENCY MEANS OF SUPPLYING ELECTRICAL POWER TO NUCLEAR FACILITIES IS COVERED IN THIS CATEGORY.

11. CONTAINMENT OF NUCLEAR FACILITIES

THIS CATEGORY ENCOMPASSES ALL ASPECTS OF PRESSURE CONTAINMENT, PRESSURE RELEASE CONTAINMENT, AND MULTIPLE BARRIER CONTAINMENT FOR REACTORS, RADIOCHEMICAL PLANTS, HOT CELLS, SOURCES, ETC., AND WILL INCLUDE SUCH ASPECTS AS DESIGN CONSIDERATIONS, LEAKAGE, PENETRATIONS, STRUCTURAL INTEGRITY, AND TEST TESTING.

12. PLANT SAFETY FEATURES

THE SAFETY ASPECTS OF MAINTENANCE, DECONTAMINATION, REACTOR SYSTEMS, URANIUM MINING AND MILLING, AND FUEL FABRICATION AND STORAGE ARE COVERED IN THIS CATEGORY. ENGINEERING DEVICES SUCH AS PRESSURE AND TEMPERATURE REDUCING SYSTEMS, AIR CLEANING SYSTEMS, AND CORE SPRAY AND SAFETY INJECTION SYSTEMS THAT ARE DESIGNED TO MINIMIZE THE CONSEQUENCES OF NUCLEAR ACCIDENTS ARE INCLUDED.

13. RADIOCHEMICAL PLANT SAFETY

NUCLEAR SAFETY INFORMATION RELATED SPECIFICALLY TO RADIOCHEMICAL PLANTS IS COVERED IN THIS CATEGORY.

14. RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

ALL ASPECTS OF THE INTENTIONAL OR ACCIDENTAL RELEASE OF RADIOACTIVITY TO THE ENVIRONMENT ARE INCLUDED IN THIS CATEGORY. RADIOACTIVE WASTE MANAGEMENT, INCLUDING WASTE TRANSPORTATION, TREATMENT, DISPOSAL AND EFFLUENT CONTROL IS OF PRIMARY IMPORTANCE AS IS RADIONUCLIDE OCCURRENCE AND MOVEMENT. THE LATTER INCLUDES FALLOUT, GEOLOGICAL CONSIDERATIONS, COUNTERMEASURES, ANALYTICAL TECHNIQUES, HYDROLOGIC CONSIDERATIONS, AND RADIONUCLIDE MOVEMENT IN SOIL AND WATER.

15. ENVIRONMENTAL SURVEYS, MONITORING, AND RADIATION EXPOSURE OF MAN

THIS CATEGORY INCLUDES ITEMS RELATED TO (1) ENVIRONMENTAL AND PERSONNEL MONITORING DURING ROUTINE AND ACCIDENTAL RADIONUCLIDE RELEASE, (2) MONITORING METHODS AND TECHNIQUES, (3) DOSE MEASUREMENT AND CALCULATION, (4) DETERMINATION OF MAXIMUM PERMISSIBLE DOSE AND CONCENTRATION, AND (5) INTERNAL AND EXTERNAL EXPOSURE TO RADIONUCLIDES.

16. METEOROLOGICAL CONSIDERATIONS

THIS CATEGORY CONSIDERS NOT ONLY DIFFUSION AND DEPOSITION OF RADIOACTIVE MATERIAL NEAR THE EARTH'S SURFACE IN CONNECTION WITH REACTOR OPERATIONS BUT ALSO THE ATMOSPHERIC TRANSPORT AND FALLOUT IN THE TROPOSPHERE AND STRATOSPHERE AS A RESULT OF NUCLEAR WEAPONS TESTS.

17. OPERATIONAL SAFETY AND EXPERIENCE

THIS CATEGORY INCLUDES COVERAGE OF THE SAFETY ASPECTS OF ROUTINE REACTOR OPERATION AND OF INCIDENTS OR UNUSUAL OPERATING OCCURRENCES, LARGE OR SMALL. POWER, RESEARCH, AND TEST REACTORS AND FUEL REPROCESSING PLANTS WILL BE COVERED. ALL AVAILABLE OPERATING, INCIDENTS, SAFEGUARDS, AND INSPECTION REPORTS WILL BE COLLECTED AND INDEXED.

18. SAFETY ANALYSIS AND DESIGN REPORTS

ROUTINE LISTINGS OF THE LATEST NUCLEAR FACILITY SAFETY ANALYSIS AND DESIGN REPORTS ARE TO BE FOUND IN THIS CATEGORY. INCLUDED ARE BOTH ANALYSES AND REPORTS BY FACILITY DESIGNERS AND BY THE AEC REGULATORY STAFF.

19. BIBLIOGRAPHIES

THIS CATEGORY CATALOGUES DOCUMENTS ON NUCLEAR SAFETY TOPICS THAT ARE EXCLUSIVELY BIBLIOGRAPHIES AS WELL AS THOSE THAT INCLUDE EXTENSIVE BIBLIOGRAPHIES WITH OTHER MATERIAL.

CATEGORY 1
GENERAL SAFETY CRITERIA

1-07715 LARSON HJ
REACTOR SAFETY REVIEW ORGANIZATION
VALLECITOS ATOMIC POWER LABORATORY, GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
20 PAGES, 5 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 16-17

A MULTI-LEVEL REVIEW ORGANIZATION RESULTED IN A MANAGEMENT--STAFF-LEVEL PERMANENT UNIT DEALING WITH VARIOUS OPERATING GROUPS AND EXTRA-COMPANY REGULATORY BODIES. THIS HAS ADVANTAGES (SIMPLIFIES COMMUNICATION, PROVIDES INDEPENDENT REVIEW, INFORMATION IS CENTRALIZED, REGULATIONS AWARENESS) AND DISADVANTAGES (FACILITY MANAGEMENT MINIMIZES LICENSING EFFORT, OPERATING GROUPS DO NOT CHALLENGE TECHNICALLY STRONGER REVIEW GROUP AND PERFUNCTIONARILY PERFORMS THEIR OWN REVIEW/AUDIT). CONCLUSION - NOTHING CAN REPLACE COMPETENT OPERATORS, BUT REVIEW IS NECESSARY WHERE HIGH RELIANCE MUST BE PLACED ON PROCEDURAL SAFEGUARDS.

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + ADMINISTRATIVE CONTROLS AND PRACTICES + REACTOR, TEST

1-07716 ABLITT JF
THE CONTRIBUTION OF SYSTEMATIC INCIDENT EVALUATION TO THE ACHIEVEMENT OF REACTOR SAFETY
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
17 PAGES, 10 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 17-19

SINCE 1961, A UK SAFETY GROUP HAS BEEN ANALYZING REPORTED FAULTS FOR (A) TRENDS AT LOCAL SITES, (B) SPECIFIC COMPONENT MALFUNCTION, AND (C) COMPONENT-FAILURE-RATE EXPERIENCE. SEVERAL TYPICAL RELAY MALFUNCTIONS DESCRIBED, AND INCIDENT STATISTICS FOR A CHOSEN PERIOD REVIEWED.

*RELIABILITY ANALYSIS + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + INCIDENT, ACTUAL, GENERAL + UNITED KINGDOM

1-07717 MCCOOL WJ
REACTOR SAFETY AT AEC-OWNED FACILITIES
U. S. ATOMIC ENERGY COMMISSION, REACTOR SAFETY BRANCH
14 PAGES, 1 TABLE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 19

AEC OWNS 151 REACTORS OF VARIOUS TYPES, OPERATED BY 26 CONTRACTORS. DESPITE THIS COMPLEXITY, GENERALLY UNIFORM STANDARDS ARE TO BE APPLIED, CONSISTENT WITH AEC-LICENSED REACTORS. THE AEC MANUAL ESTABLISHES THAT (A) CONTRACTORS OPERATE WITH CARE COMMENSURATE WITH RISK, CARRY MAJOR BURDEN OF SAFETY, (B) FIELD OFFICES REVIEW PROPOSED AND CURRENT OPERATIONS, AUDIT OPERATIONS, (C) DIVISION OF OPERATIONAL SAFETY DEVELOPS POLICY AND EVALUATES PERFORMANCE. VARIOUS GUIDES HAVE BEEN PUBLISHED.

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + ADMINISTRATIVE CONTROLS AND PRACTICES + REACTOR, AEC OWNED

1-07718 CORLETT RF
CONTROL OF REACTOR MODIFICATIONS FOLLOWING COMMISSIONING
BATTELLE-NORTHWEST
2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 19-20

EARLY IN THE LIFE OF A REACTOR, STAFF IS WELL DISCIPLINED IN CAREFUL FORMAL REVIEW OF MODIFICATIONS TO CRUCIAL EQUIPMENT. LATER, PERSONNEL WILL LEAVE, CLIMATE WILL CHANGE, NATURAL DESIRE TO STRETCH PLANT, ALL WILL REQUIRE A SYSTEM TO CONTROL MODIFICATIONS. CRITERIA - (1) BALANCE BETWEEN SAFETY AND ECONOMICS IN GRAY AREAS, (2) BALANCE BETWEEN SPEEDY JOB AND AGONIZINGLY SLOW REVIEW, (3) CLEARLY DEFINED REVIEW RESPONSIBILITIES. THE EXACT CONTENT OF THE SYSTEM IS LESS IMPORTANT THAN THE FACT THAT A REFLECTIVE PAUSE IS MANDATORY BEFORE CRUCIAL SYSTEMS ARE CHANGED.

*MODIFICATION, SYSTEM OR EQUIPMENT + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + HANFORD SITE

1-08441 FOX TA + MUELLER RA + FORD CH + ALGER DL
CRITICAL MASS STUDIES WITH NASA ZERO POWER REACTOR II. I - CLEAN HOMOGENEOUS CONFIGURATIONS
LEWIS RESEARCH CENTER, NATIONAL AERONAUTICS AND SPACE ADMINISTRATION, CLEVELAND, OHIO
NASA-TN-D-3097 +. 19 PAGES, 6 FIGURES, 2 TABLES, 6 REFERENCES- NOVEMBER 1965, CFSTI \$1.00 CY, \$0.50 MN

THE NASA ZERO POWER REACTOR II (ZPR-II) HAS BEEN USED TO DETERMINE EXPERIMENTALLY THE CRITICAL MASSES FOR MORE THAN A TENFOLD RANGE OF HIGHLY ENRICHED (93.2 PERCENT U-235) AQUEOUS URANYL FLUORIDE FUEL CONCENTRATIONS IN CLEAN CYLINDRICAL GEOMETRIES. IN ADDITION TO THE CRITICAL MASSES, DATA ARE PRESENTED ON THE TEMPERATURE COEFFICIENT OF REACTIVITY WORTH AT CRITICALITY FOR A SIMILAR RANGE OF CONCENTRATIONS. A BRIEF DESCRIPTION OF THE ZPR-II AND THE EXPERIMENTAL PROCEDURES USED ARE ALSO INCLUDED.

CRITICALITY EXPERIMENT + CRITICALITY SAFETY + REACTIVITY COEFFICIENT + TEMPERATURE COEFFICIENT + URANIUM

1-08785 LEVERETT MC
THE HANFORD N-REACTOR
HANFORD ATOMIC PRODUCTS OPERATION
HW-SA-3470 +. 18 PAGES, 5 FIGURES, APRIL 1964, PAPER PRESENTED AT THE AMERICAN SOCIETY FOR TESTING AND MATERIALS MEETING, DAVENPORT HOTEL, SPokane, WASHINGTON, APRIL 22, 1964, SOURCE

ACCESSION NUMBER 1-07715 TO 1-08785

CATEGORY 1
GENERAL SAFETY CRITERIA

1-08785 *CONTINUED*

SOME EXAMPLES OF THE TECHNOLOGY AND WORK WHICH HAVE GONE INTO THE N REACTOR AT HANFORD ARE DESCRIBED. THE NEW TECHNOLOGY IS APPLICABLE TO REACTORS OTHER THAN THOSE AT HANFORD AND WILL FIND ITS WAY INTO COMMERCIAL USE. THE CONTAINMENT SYSTEM, PIPING, CARBON-STEEL, GRAPHITE, PROBLEMS AND FUEL-ELEMENT EXPERIENCE ARE NOTED.

*REACTOR DESCRIPTION + HANFORD PRODUCTION REACTOR

1-09576 THOMAS JT

EXPERIMENTAL AND CALCULATED SYSTEM CRITICALITY
OAK RIDGE NATIONAL LABORATORY

SM-70/29 +. 37 PAGES, 15 TABLES, 8 FIGURES, 11 REFERENCES, SYMPOSIUM ON CRITICALITY CONTROL OF FISSILE MATERIALS, STOCKHOLM, NOVEMBER 1-5, 1965, SOURCE

SPECIFIC DETAILS NECESSARY TO CHARACTERIZE CRITICALITY ARE GIVEN WITH EXPERIMENTAL DATA. THE PRINCIPAL MODE OF ASSEMBLY AND CONTROL IS STATED. THE FISSILE MATERIALS USED WERE EITHER METAL OR AQUEOUS SALT SOLUTIONS. HYDROGENOUS MATERIALS WERE USED AS REFLECTORS AND MODERATORS IN THE ARRAYS. A NUMBER OF EXPERIMENTS WITH METAL UNITS WERE PERFORMED WITH THE UNITS IN IRON CONTAINERS. THE METHOD OF ASSEMBLY FOR SOLUTION UNITS WAS TO SPACE THE PROPOSED SYSTEM OF UNITS BY HAND. REACTIVITY CONTROL AND CRITICALITY WERE ACHIEVED BY VARYING THE COMMON SOLUTION HEIGHT IN THESE CENTRAL UNITS. THE SPACING WAS ADJUSTED TO ATTAIN CRITICALITY WHEN THE CONTROL CONTAINERS WERE INDISTINGUISHABLE FROM THE HAND-PLACED UNITS. THE TWO COMPONENT METAL ASSEMBLIES WERE CONTROLLED BY UNIT SEPARATION. THE MULTIPLE-COMPONENT METAL SYSTEMS WERE CONDUCTED ON THE SPLIT-TABLE APPARATUS, AND CONTROL WAS ACHIEVED BY TABLE SEPARATION.

COMPUTER PROGRAM + COMPUTER, DIGITAL + CRITICALITY SAFETY + FUEL HANDLING + MODERATOR + MONTE CARLO + REFLECTOR

1-09592 QUESTIONS AND ANSWERS ON THE PROPOSED MALIBU NUCLEAR POWER STATION OF THE LOS ANGELES DEPARTMENT OF WATER AND POWER
LOS ANGELES DEPARTMENT OF WATER AND POWER
6 PAGES, 1965, SOURCE

SERIES OF QUESTIONS AND ANSWERS INDICATING THE GENERAL SAFETY OF POWER REACTORS AND SPECIFIC FEATURES OF MALIBU, AND THE DESIRABILITY OF THE MALIBU STATION (NO AIR POLLUTION, ATTRACT VISITORS, PUBLIC PARK, CHEAPER ELECTRICITY).

*MALIBU + *RADIATION IN PERSPECTIVE + *RADIATION, PUBLIC EDUCATION/ACCEPTANCE + REACTOR, PRESSURIZED WATER

1-09686 WOOD RE

THE 630A HIGH PERFORMANCE MERCHANT SHIP NUCLEAR STEAM GENERATOR
GENERAL ELECTRIC COMPANY, ADVANCED TECHNOLOGY SERVICE

TM-64-8-14 + CONF-640810-1 +. 43 PAGES, CONFERENCE ON NUCLEAR MARINE PROPULSION, VIRGINIA POLYTECHNIC INSTITUTE, BLACKSBURG, VIRGINIA, AUGUST 10-13, 1964, CFSTI, \$2.00 CY

THE SAFETY ASPECTS OF A GAS-COOLED SYSTEM, SUCH AS THE 630A, ARE INHERENTLY DIFFERENT IN MANY RESPECTS FROM THOSE OF THE MORE FAMILIAR WATER-COOLED SYSTEMS. THE BASIC 630A DESIGN PROVIDES A NUMBER OF UNIQUE SAFETY-RELATED FEATURES. IN THE PRESENT RESEARCH AND DEVELOPMENT PHASE, A CONCERTED EFFORT IS BEING MADE TO ACHIEVE A FINAL DESIGN FEATURING MAXIMUM SAFETY AND RELIABILITY WHILE RETAINING THE OPTIMUM BALANCE BETWEEN PERFORMANCE, OPERABILITY, WEIGHT, AND ECONOMICS. THE APPROACH COMBINES CAREFUL CONSIDERATION OF CURRENT INDUSTRY PRACTICE AND DESIGN STANDARDS, WHEREVER THE MORE CONVENTIONAL SAFETY ASPECTS ARE CONCERNED, WITH EXPLOITATION OF THE TYPICAL INHERENT AND CONFIGURATIONAL FEATURES. RESULTS TO DATE ARE HIGHLY PROMISING, ALL INDICATIONS BEING THAT AN UNPRECEDENTED DEGREE OF BUILT-IN SAFETY CAN BE REALIZED IN THE FINAL 630A DESIGN.

*ACCIDENT ANALYSIS + *REACTOR, GAS COOLED + *REACTOR, MARITIME + *630 A (MARITIME REACTOR) + DECAY HEAT + ECONOMICS + REACTIVITY EFFECT + REACTOR DESCRIPTION + REACTOR TRANSIENT

1-09703 KIER PH

THE EBWR PLUTONIUM RECYCLE EXPERIMENTAL PROGRAM. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 1 PAGE, DECEMBER 1965, SECTION II-17, P. 92, CFSTI, \$7.22 CY, \$2.00 CY

THIS PROGRAM FOR SAFETY-RELATED MEASUREMENTS IN THE PLUTONIUM-LOADED EBWR INCLUDES CONTROL ROD WORTHS, BORIC ACID WORTHS, TEMPERATURE COEFFICIENT, SHUTDOWN MARGIN, TRANSFER FUNCTIONS, AND STABILITY. A PROGRAM FOR EXPERIMENTS IN A CRITICAL SYSTEM CONTAINING PLUTONIUM WITH SIGNIFICANT PU-240 INCLUDES CRITICAL MASS, BORIC ACID WORTH, AND TEMPERATURE-COEFFICIENT MEASUREMENTS.

*EBWR (EXPERIMENTAL BOILING WATER REACTOR) + *PLUTONIUM + CHEMICAL SHIM + CONTROL ROD WORTH + CRITICALITY EXPERIMENT + EXPERIMENT, GENERAL + POISON, SOLUBLE + REACTOR STABILITY + REACTOR, BOILING WATER + SHUTDOWN MARGIN + TEMPERATURE COEFFICIENT + TRANSFER FUNCTION

1-09968 REPROCESSING TECHNIQUES AND PROGRESS

2 PAGES, EURONUCLEAR 2(12), PAGES 604-605 (DECEMBER, 1965)

THE INCREASINGLY IMPORTANT PROBLEMS ASSOCIATED WITH THE REPROCESSING OF IRRADIATED NUCLEAR

CATEGORY 1
GENERAL SAFETY CRITERIA

1-09968 *CONTINUED*

FUELS ARE NOW ACHIEVING PRIORITY IN ALL COUNTRIES WHERE NUCLEAR POWER IS BEING, OR IS EXPECTED TO BE, UTILIZED. THE EUROCHEMIC PLANT AT MOI IN BELGIUM IS EXPECTED TO PROVIDE A LARGE PERCENTAGE OF THE REPROCESSING CAPACITY REQUIRED DURING THE NEXT FEW YEARS, BUT SEVERAL OTHER NUCLEAR-DEVELOPED COUNTRIES HAVE THEIR OWN SMALLER PLANTS WHICH MAY ALSO CONTRIBUTE TO THE TOTAL EUROPEAN REQUIREMENT.

*CONTAINMENT, FUEL REPROCESSING + *EUROCHEMIC + *RADIOCHEMICAL PROCESSING + BELGIUM + ITALY + NETHERLANDS + TRANSPORTATION AND HANDLING + UNITED KINGDOM

1-09969 ORGANIC-COOLED REACTOR GOES CRITICAL

1 PAGE, 2 FIGURES, EURONUCLEAR, 2(12), PAGE 606 (DECEMBER, 1965)

THE ONLY OPERATING REACTOR USING AN ORGANIC LIQUID AS THE HEAT-TRANSFER MATERIAL AND HEAVY WATER AS THE MODERATOR, THE WR-1 REACTOR AT THE WHITESHELL NUCLEAR RESEARCH ESTABLISHMENT OF ATOMIC ENERGY OF CANADA LIMITED, WENT INTO OPERATION DURING THE EVENING OF MONDAY, NOVEMBER 1, 1965. THE WR-1 IS THE FIRST MAJOR NUCLEAR FACILITY TO GO INTO SERVICE AT THE WHITESHELL CENTRE, WHERE SEVERAL LABORATORIES HAVE BEEN IN OPERATION SINCE JULY 1963.

*CANADA + *REACTOR, HEAVY WATER + *REACTOR, ORGANIC COOLED + *WR1 (WHITESHELL REACTOR NO. 1, CANADA)

1-09992 LLOYD RC + RICHIEY CR + CLAYTON ED + SKEEN DR

CRITICALITY STUDIES WITH PLUTONIUM SOLUTIONS

BATTELLE MEMORIAL INSTITUTE, RICHLAND, WASHINGTON

8 PAGES, 8 FIGURES, 6 TABLES, NUCLEAR SCIENCE AND ENGINEERING, 25(2), PAGES 165-173 (JUNE, 1966)

CRITICALITY EXPERIMENTS WITH PLUTONIUM (4.6 PERCENT PU-240) NITRATE SOLUTION (AQUEOUS) IN STAINLESS-STEEL SPHERES 11.5, 14, AND 15.2 IN. IN DIAMETER. REFLECTORS - WATER, CONCRETE, PARAFFIN, STAINLESS STEEL. LARGEST SPHERE WAS ALSO USED WITHOUT REFLECTOR. CRITICALITY WAS REACHED WITH PLUTONIUM CONCENTRATIONS THAT VARIED FROM 24 TO 435 G PU PER LITER. MINIMUM CRITICAL VOLUMES WERE ABOUT 22 AND 11 LITERS, RESPECTIVELY, FOR BARE AND REFLECTED SPHERES AT A PU CONCENTRATION OF 175 G/LITER. ACTUAL RESULTS WERE COMPARED WITH THOSE PREDICTED BY MULTIGROUP DIFFUSION THEORY.

*CRITICALITY EXPERIMENT + COMPUTER, DIGITAL + CRITICALITY SAFETY + PLUTONIUM + REFLECTOR + WATER, GENERAL

1-09995 MOUNIOT JC

THEORETICAL AND EXPERIMENTAL ASPECTS OF NEUTRONIC INTERACTION OF MULTIPLYING MEDIA

COMMISSARIAT A L ENERGIE ATOMIQUE, FRANCE, CENTRE D ETUDES NUCLEAIRES, SACLAY

CEA-R-2849 +. 93 PAGES, OCTOBER, 1965, CEA, DEP/MN

A THEORETICAL STUDY OF NEUTRONIC INTERACTION OF MULTIPLYING MEDIA IS PRESENTED. THE USE OF THE SURFACE MULTIPLICATION CONSTANT AND OF THE EFFECTIVE MULTIPLICATION CONSTANT IS CONSIDERED. THREE CLASSICAL METHODS OF INTERACTION CALCULATIONS ARE STUDIED IN PARALLEL, AND THE APPLICATION OF THE EFFECTIVE-MULTIPLICATION-CONSTANT METHOD TO PROBLEMS OF NUCLEAR SAFETY IS DISCUSSED.

*EQUATION, GENERAL + *MONTE CARLO + *NEUTRON INTERACTION + STATISTICAL CORRELATION

1-09997 RESEARCH CENTRES IN EUROPE - NO. 10.-RISO

THE DANISH ATOMIC ENERGY COMMISSION RESEARCH ESTABLISHMENT

8 PAGES, FIGURES, EURONUCLEAR, 2(10), PP. 497-504 (OCTOBER 1965)

FROM A LATE BEGINNING IN 1955 THE DANISH AEC, UNDER THE ORIGINAL CHAIRMANSHIP OF NIELS FOHR, HAS BUILT UP AN EFFECTIVE RESEARCH ESTABLISHMENT AT RISØ. THE CENTRE HAS THREE REACTORS, OPERATING SINCE 1960 - AQUEOUS HOMOGENEOUS, LIGHT-WATER MODERATED, AND HIGH FLUX OF THE PLUTO TYPE. IN ADDITION, THERE ARE HOT-CELLS, A WASTE-TREATMENT PLANT (EVAPORATION AND INCINERATION), METALLURGICAL LABORATORIES, LABORATORIES FOR THE STUDY OF CHEMISTRY AND PLASMA PHYSICS, AN AGRICULTURAL RESEARCH DEPARTMENT, A LINEAR ACCELERATOR, AND AN ISOTOPES CENTER.

*REACTOR, RESEARCH + *RISO (RESEARCH LABORATORY, DENMARK) + DENMARK + REACTOR, HIGH FLUX + REACTOR, HOMOGENEOUS + REACTOR, WATER

1-10107 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, FEBRUARY 1966

ARGONNE NATIONAL LABORATORY

ANL-7176 +. 95 PAGES, 28 FIGURES, 20 TABLES, REFERENCES, MARCH 23, 1966, CFSTI, \$4.00 CY, \$0.75 MN

THIS MONTHLY PROGRESS REPORT (FEBRUARY 1966) CONTAINS SECTIONS ON LIQUID-METAL-COOLED REACTORS, GENERAL REACTOR TECHNOLOGY, ADVANCED SYSTEMS R AND D, NUCLEAR SAFETY, AND PUBLICATIONS. THE SAFETY SECTION DEALS WITH REACTOR KINETICS, TREAT, CHEMICAL ENERGY PROBLEMS IN REACTOR SAFETY, AND PLUTONIUM VOLATILITY SAFETY.

*ANL (ARGONNE NATIONAL LABORATORY) + CHEMICAL REACTION + PLUTONIUM + REACTOR KINETICS + REACTOR, LIQUID METAL COOLED

1-10109 REGULATIONS ON RADIATION SAFETY DURING GAMMA-RAY DEFECTOSCOPY

JPRS-33502 + TT-65-34076 +. 24 PAGES, TRANSLATED FROM DURZHAVEN VESTN, (95), PP. 1-7 (1965), CFSTI, \$1.00 CY, \$0.50 MN

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10109 *CONTINUED*

THESE REGULATIONS ARE OBLIGATORY IN THE DESIGNING, OPERATING, AND USE OF LABORATORIES FOR GAMMA DEFECTOSCOPY, REGARDLESS OF THEIR PURPOSE, LOCATION, UTILIZED TYPE OF GAMMA DEFECTOSCOPE, ETC. THEY ARE OBLIGATORY IN THE DESIGNING, PRODUCTION, AND USE OF ALL TYPES OF GAMMA DEFECTOSCOPES IN BULGARIA.

*BULGARIA + *GAMMA + *INSTRUMENTATION, RADIATION MONITORING + *REGULATION, GENERAL

1-10114 BYRNE JT

PLUTONIUM MANAGEMENT AT ROCKY FLATS

DOW CHEMICAL COMPANY, ROCKY FLATS DIVISION

RFP-720 + CONF-660308-1 +. 21 PAGES, FEBRUARY 11, 1966, AMERICAN NUCLEAR SOCIETY, PLUTONIUM INFORMATION MEETING, WASHINGTON, D. C., CFSTI, \$1.00 CY, \$0.50 MN

SOME MAJOR TECHNICAL CONSIDERATIONS IN PLUTONIUM MATERIALS MANAGEMENT ARE DISCUSSED. THIS REPORT IS BASED UPON PRACTICES DEVELOPED AND EVALUATED DURING NEARLY 15 YEARS OF EXPERIENCE IN LARGE-SCALE CHEMICAL, METALLURGICAL, AND FABRICATION OPERATIONS AT THE USAEC'S ROCKY FLATS PLANT. PARTICULAR EMPHASIS IS PLACED UPON THE PROBLEM OF CONTAINMENT AND ON MEANS OF COPING WITH LOSS-OF-CONTAINMENT SITUATIONS. RECENT WORK ON HANDLING AND MEASURING PLUTONIUM SHIPMENTS IS SUMMARIZED. EFFECTIVE METHODS FOR PLUTONIUM HANDLING AND CONTROL DURING PROCESSING ARE DESCRIBED. CURRENT PROBLEMS IN PLUTONIUM MATERIALS MANAGEMENT ARE IDENTIFIED.

*CONTAINMENT SYSTEM, OPERATION OF + *PLUTONIUM + *RADIOCHEMICAL PROCESSING + *ROCKY FLATS + TRANSPORTATION AND HANDLING

1-10115 PFANN J + MARKVART J + SULC P

DETERMINATION OF CRITICAL SIZE AND EFFECTIVE FUEL CHARGE OF HEAVY WATER NATURAL URANIUM REACTOR WITH MULTIZONE ACTIVE CORE. CALCULATION METHOD AND DESCRIPTION OF PROGRAMMING

USTAV JADERNEHO VYZKUMU, CESKOSLOVENSKA AKADEMIE VED, REZ

UJV-1046 +. 34 PAGES, 1966, DEP.MN, ENGLISH ABSTRACT

THIS PAPER OUTLINES ALGORITHMS FOR DETERMINING CRITICAL PARAMETERS AND NEUTRON-DENSITY DISTRIBUTION IN TWO-GROUP DIFFUSION APPROXIMATION APPLIED TO HETEROGENEOUS HEAVY-WATER GAS-COOLED POWER REACTOR WITH MULTIZONE ACTIVE CORE AND MULTIREGION REFLECTOR. IN ADDITION, EFFECTIVE FUEL CHARGE AND OTHER NECESSARY FACTORS SUCH AS NEUTRON-FLUX FLATTENING, ETC., ARE PRESENTED. IN THE PAPER IS DESCRIBED AUTOCODE PROGRAM DESIGNED FOR NUMERICAL SOLUTION OF INTRODUCED ALGORITHMS. THE METHOD IS DESIGNED FOR ACTIVE-CORE OPTIMIZATION.

*COMPUTER PROGRAM + *CRITICALITY SAFETY + CZECHOSLOVAKIA + REACTOR; HEAVY WATER

1-10122 CRITICALITY CONTROL OF FISSILE MATERIALS. IAEA SYMPOSIUM, STOCKHOLM, NOVEMBER 1 TO 5

1 PAGE, NUCLEAR ENGINEERING, 10(115), PP. 453 (DECEMBER 1965)

A SYMPOSIUM ON THE CRITICALITY CONTROL OF FISSILE MATERIALS WAS HELD BY THE INTERNATIONAL ATOMIC ENERGY AGENCY IN STOCKHOLM FROM NOVEMBER 1 TO 5. THE SUBJECTS TREATED (1) BASIC CRITICALITY OR THE ASSESSMENT OF REACTIVITIES AND (2) CRITICALITY CONTROL OR THE METHODS OF MAINTAINING SUBCRITICALITY IN OPERATIONS. BASIC CRITICALITY INCLUDED BOTH COMPUTATIONAL TECHNIQUES FOR THE CALCULATIONS OF CRITICAL PARAMETERS AS WELL AS EXPERIMENTAL TECHNIQUES AND DETERMINATION OF CRITICALITY PARAMETERS. THE PAPERS ON CRITICALITY CONTROL DEALT WITH THE ADMINISTRATIVE AND MANAGERIAL ASPECTS OF ENSURING SUBCRITICALITY IN PROCESSES INVOLVING FISSILE MATERIALS.

*CRITICALITY SAFETY + *IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY) + ADMINISTRATIVE CONTROLS AND PRACTICES + COMPUTER PROGRAM + CRITICALITY EXPERIMENT

1-10130 CHEMICAL AND ASSOCIATED ENERGY-TRANSFER PROBLEMS IN REACTOR SAFETY

ARGONNE NATIONAL LABORATORY

ANL-7132 +. 2 PAGES, 1 TABLE, JANUARY 25, 1966, PP. 80-81 OF ANL REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, DECEMBER 1965, CFSTI, \$3.00 CY

DATA ON THE EXTENT OF URANIUM-WATER REACTION FOR THE UNCLAD URANIUM ALLOY (5 PERCENT ZR, 1.5 PERCENT NB) PINS HAVE BECOME AVAILABLE FOR THE METAL-WATER EXPERIMENTS THAT WERE CONDUCTED DURING THE KIWI-TNT DESTRUCTIVE TEST IN JANUARY 1965 IN NEVADA. THIS TEST AFFORDED AN OPPORTUNITY TO OBTAIN METAL-WATER REACTION DATA DURING A SHORT-PERIOD (0.6-MSEC) TRANSIENT. THE EXTENT OF REACTION OF URANIUM WITH WATER WAS DETERMINED BY ANALYZING THE MELTDOWN RESIDUES, RATHER THAN BY DIRECT HYDROGEN MEASUREMENT, THE METHOD USED IN ALL PREVIOUS IN-PILE METAL-WATER REACTION EXPERIMENTS. THE DATA SHOW A CLEAR INCREASE IN THE AMOUNT OF CHEMICAL REACTION WITH PEAK URANIUM TEMPERATURES.

*METAL WATER REACTION + *URANIUM + ALLOY + ANL (ARGONNE NATIONAL LABORATORY) + KIWI TNT (TRANSIENT NUCLEAR TEST) + NIOBIUM + ZIRCONIUM

1-10152 PFR RESULT - SCOTLAND 2, ENGLAND O

2 PAGES, 1 FIGURE, NUCLEAR ENGINEERING, 11(118), PP. 182-183 (MARCH 1966)

THE NEW UNITED KINGDOM 250-MWE PROTOTYPE FAST REACTOR WILL BE BUILT AT THE DOUNREAY SITE IN SCOTLAND. SAFETY AND STABILITY ARE VESTED IN INTEGRAL DESIGN AND THE THERMAL CAPACITY OF A 300,000-GAL SODIUM TANK. FLOW THROUGH THE CORE IS UPWARDS, AND THE ENTIRE PRIMARY CIRCUIT IS IMMERSSED IN THE REACTOR VESSEL, INCLUDING IMPELLER PUMPS AND VALVES, WITH DRIVES MOUNTED ABOVE THE TOP SHIELD. THE FUEL IS CURRENTLY THOUGHT OF AS PLUTONIUM/NATURAL URANIUM OXIDE

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10152 *CONTINUED*

CLAD IN 316 TYPE STAINLESS STEEL PINS ARRANGED IN HEXAGONAL BUNDLES.

*DESIGN STUDY + *DOUNREAY (UK) + *REACTOR, FAST + *UNITED KINGDOM

1-10162 AEC PUBLISHES AGREEMENT PROPOSED BY ALABAMA
U. S. ATOMIC ENERGY COMMISSION
PRESS REL. J-140 +. 15 PAGES, JUNE 2, 1966, DPI

THE AEC PUBLISHED AN AGREEMENT (FOR PUBLIC COMMENT) PROPOSED BY ALABAMA UNDER WHICH THE STATE WOULD ASSUME PART OF AEC'S REGULATORY AUTHORITY OVER THE USE OF RADIOACTIVE MATERIALS IN ALABAMA. THE COMMISSION WOULD TRANSFER TO ALABAMA REGULATORY RESPONSIBILITY OVER THE USE OF RADIOISOTOPES, THE SOURCE MATERIALS URANIUM AND THORIUM, AND SMALL QUANTITIES OF FISSIONABLE MATERIALS. THE ALABAMA STATE BOARD OF HEALTH WAS DESIGNATED THE STATE RADIATION CONTROL AGENCY RESPONSIBLE FOR LICENSING, RULE MAKING, AND ENFORCEMENT IN THE USES OF RADIOACTIVE MATERIALS IN THE STATE. THE DIVISION OF RADIOLOGICAL HEALTH WOULD CONDUCT THE RADIATION CONTROL PROGRAM FOR THE AGENCY. A RADIATION ADVISORY BOARD OF HEALTH WAS ESTABLISHED TO ADVISE THE AGENCY IN CARRYING OUT THE REGULATORY PROGRAM.

*REGULATION, AEC + *REGULATION, STATE + RADIOISOTOPE + THORIUM + URANIUM

1-10250 CIBOIS M + LEMAIRE J + WEISZ M
REACTOR TANKS STEELS. IRRADIATION OF TENSILE-TEST PIECES IN EL.3 AT DIFFERENT TEMPERATURES AND POST-IRRADIATION TESTS
COMMISSARIAT A L ENERGIE ATOMIQUE, PARIS, FRANCE
EURAF-1502 + EUR-2660 +. 64 PAGES, 1964, CFSTI, \$3.00 CY, \$0.75 MN

THE EFFECT OF TEMPERATURE ON IRRADIATION DAMAGE TO VARIOUS STEELS HAS BEEN STUDIED IN A SERIES OF SIX SUCCESSIVE ASSEMBLIES FROM 100 TO 400 C AT DOSES OF SOME 3×10 TO THE 19 FAST NEUTRONS. HARDENING MAXIMIZES AT 100 TO 200 C FOR ALL STEELS CONSIDERED, THEN DROPS TO VIRTUALLY 0 AT 30 C. FOR HIGH ELASTIC LIMIT WELDABLE STEELS, HOWEVER, RESIDUAL HARDENING REMAINS EVEN AT 400 C. THE STRAIN-HARDENING CURVE SHOWS A REDUCTION OF THE PETCH EQUATION PARAMETER K_1 , ESPECIALLY FOR LOW CARBON STEELS. A SECONDARY HARDENING WAS NOTED IN MN-MO STEELS.

*EMBRITTEMENT + *RADIATION EFFECT + *STEEL + FAST NEUTRON + THERMAL ANALYSIS + THERMAL EXPERIMENT

1-10251 DIXON FE
EXTENDED FIRE TESTS ON TINPLATE CANS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-M-1664 +. 13 PAGES, 12 FIGURES, REFERENCES, NOVEMBER, 1965, BIS, \$1.40, HMSO

IAEA REGULATIONS REQUIRE THAT SOURCES OF GAMMA-EMITTING MATERIALS WITH A STRENGTH BETWEEN 3 AND 20 CURIES SHALL HAVE AN OUTER STEEL CONTAINMENT VESSEL OF 2 MM THICKNESS. IT IS VERY DIFFICULT TO OBTAIN SMALL STANDARD CANS IN THIS THICKNESS. TO PROVE THAT TINPLATE CONTAINERS WOULD WITHSTAND EXTENDED FIRE TESTS, SAMPLES WERE SUBJECTED TO A TORCH TEST (TO SIMULATE A JET OF FLAME) ON A CONTAINER FOR FOUR HOURS, AND A FOUR-HOUR FIRE TEST IN A COMPLETELY OXIDIZING ATMOSPHERE IN AN ELECTRIC FURNACE. A TORCHING FLAME OF 800 C FOR FOUR HOURS HAD NO SIGNIFICANT EFFECT ON THE STRENGTH OF THE CAN OR ON ITS ABILITY TO CONTAIN THE ISOTOPE SPECIFIED. AFTER THE OXIDIZING TEST AT 300 C, THE CAN, ALTHOUGH HEAVILY OXIDIZED, WAS STILL CAPABLE OF RETAINING THE ISOTOPE AS SPECIFIED.

*PIPE + *SHIPPING CONTAINER + *TEST, PROOF + CONTAINMENT INTEGRITY + HIGH TEMPERATURE + STEEL + THERMAL EXPERIMENT

1-10252 WHITEHOUSE WJ + DYSON ED
THE ADVANCED COURSE IN THE PRINCIPLES OF RADIATION PROTECTION. PART I
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-5084 +. 23 PAGES, 6 TABLES, 1 FIGURE, REFERENCES, NOVEMBER, 1965, BIS, \$0.70, HMSO

NINE ADVANCED COURSES IN THE PRINCIPLES OF RADIATION PROTECTION WERE HELD AT HARWELL FROM 1959 TO 1964. EACH COURSE LASTED ABOUT THREE MONTHS. THIS REPORT REVIEWS THE BACKGROUND, HISTORY, AND INITIAL ORGANIZATION OF THE COURSES, AND SUMMARIZES THEIR SUBJECT MATTER, INCLUDING LECTURES, PRACTICAL WORK, VISITS, AND FILMS. THE REASONS FOR ARRANGING AND PRESENTING THE COURSES, IN THE WAY THAT WAS ADOPTED, ARE DISCUSSED.

*HARWELL (UK) + *RADIATION PROTECTION, ORGANIZATION + *SAFETY PRINCIPLES AND PHILOSOPHY

1-10254 STEIN RM
DEVELOPMENT OF THE LAW OF NUCLEAR ENERGY IN EUROPE
EUROPEAN NUCLEAR ENERGY AGENCY
4 PAGES, NUCLEAR ENGINEERING, 11(119), PP. 299-302 (APRIL, 1966)

THIS ARTICLE VERY EFFECTIVELY TRACES THE HISTORY OF NUCLEAR-RELATED LAW IN EUROPE FROM ITS BEGINNING IN THE MIDDLE 1950S. THE ROLES OF NATIONAL AND INTERNATIONAL ORGANIZATIONS ARE OUTLINED, TOGETHER WITH THE LEGAL RELEVANCE OF INTERNATIONAL JOINT UNDERTAKINGS, SUPPLY OF NUCLEAR MATERIALS, SECURITY CONTROL, HEALTH AND SAFETY, THIRD PARTY LIABILITY, AND TRANSPORT. SOME FORECASTING OF FUTURE NEEDS FOR INTERNATIONAL NUCLEAR LAW IS ATTEMPTED.

*ENEA (EUROPEAN NUCLEAR ENERGY AGENCY) + *EURATOM + *IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY) + *LAW +

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10254 *CONTINUED*
LIABILITY

1-10255 DANISH LAWS AND REGULATIONS RELATING TO RADIATION HYGIENE
NATIONAL HEALTH SERVICE, COPENHAGEN
NP-15571 +. 42 PAGES, 1965, DEP/MN

DANISH LAWS AND REGULATIONS DEALING WITH RADIATION SAFETY ARE LISTED.

*DENMARK + *RADIATION SAFETY AND CONTROL + LAW + REGULATION, GENERAL

1-10257 FULLAM HT
A CRITICALLY SAFE FLAT BED CONTACTOR FOR PROCESSING SOLID FISSILE MATERIALS
HANFORD ATOMIC PRODUCTS OPERATION
RL-SA-52 + CONF-651010-2 +. 12 PAGES, ELECTROCHEMICAL SOCIETY 6TH REGIONAL AICHE MEETING, UNION,
WASHINGTON, CFSTI, \$1.00 CY, \$0.50 MN

A FLAT-BED REACTOR WAS DEVELOPED FOR PROCESSING SOLID FISSILE MATERIALS WHICH IS (1) CRITICALLY SAFE BY GEOMETRICAL DESIGN, (2) MECHANICALLY SIMPLE, (3) VERSATILE, (4) CAPABLE OF EFFICIENT HANDLING OF A WIDE RANGE OF PARTICLE SIZES AND GAS FLOWS. THE BODY OF THE CONTACTOR CONSISTS OF A HOLLOW CYLINDRICAL SLAB DIVIDED BY A POROUS PLATE INTO AN UPPER AND LOWER SECTION. THE SOLIDS TO BE REACTED ENTER THE UPPER SECTION OF THE REACTOR AT THE PERIPHERY AND ARE MOVED TO THE CENTER BY A RABBLE ARM. THE POROUS PLATE SERVES AS THE BED SUPPORT FOR THE SOLIDS. THE REACTING GAS IS PREHEATED AS IT ENTERS THE LOWER SECTION OF THE REACTOR, THEN PASSES UP THROUGH THE POROUS PLATE AND THROUGH THE BED OF SLOWLY MOVING SOLIDS. THE GASEOUS PRODUCTS LEAVE THE CONTACTOR THROUGH A VENT LINE IN THE COVER PLATE.

*CRITICALITY SAFETY + *RADIOCHEMICAL PLANT SAFETY + *RADIOCHEMICAL PROCESSING + CHEMICAL REACTION + DESIGN CRITERIA + DESIGN STUDY

1-10258 SALLERON C
INTERNATIONAL REGULATION OF TRANSPORT OF RADIOACTIVE MATERIALS. PRESENT TRENDS
PARIS UNIVERSITY, FRANCE
NP-15620 +. 45 PAGES, 1964, IN FRENCH, DEP. MN

THE MODIFICATIONS AND ALTERATIONS MADE IN 1963 BY THE INTERNATIONAL AGENCY FOR ATOMIC ENERGY TO THE REGULATIONS FOR TRANSPORTING RADIOACTIVE MATERIALS ARE SUMMARIZED. THE DEFINITIONS OF TERMS ARE GIVEN, AND THE MATERIALS EXEMPT FROM INTERNATIONAL REGULATION ARE DESCRIBED. THE CONDITIONS FOR PACKAGING AND PERMISSION FOR TRANSPORTATION ARE OUTLINED, AND THE REGULATIONS CONCERNING STORAGE AND TRANSPORTATION ARE INDICATED.

*IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY) + *REGULATION, IAEA + *TRANSPORTATION AND HANDLING

1-10305 AEC APPOINTS PANEL TO STUDY WAYS TO IMPROVE HANDLING OF CONTESTED REACTOR LICENSING CASES
UNITED STATES ATOMIC ENERGY COMMISSION
AEC PRESS REL. J-86 +. 1 PAGE, APRIL 4, 1966, DPI

THE AEC APPOINTED A THREE-MEMBER PANEL FROM OUTSIDE THE GOVERNMENT TO MAKE AN IN-DEPTH STUDY OF CONTESTED CASES INVOLVING APPLICATIONS TO BUILD AND OPERATE NUCLEAR FACILITIES. THE REVIEW PANEL WILL SEEK TO DETERMINE IF IMPROVEMENTS CAN BE MADE IN AEC PROCEDURES FOR HANDLING SUCH CASES. CONTESTED CASES ARE ONE IN WHICH THERE IS A CONTROVERSY BETWEEN THE AEC REGULATORY STAFF AND THE APPLICANT CONCERNING THE ISSUANCE OF THE LICENSE OR ANY OF ITS TERMS OR CONDITIONS, OR IN WHICH THE APPLICATION IS OPPOSED BY ANY OTHER PARTY TO THE PROCEEDING.

*LICENSING STATUS OF NUCLEAR PROJECTS + PROCEDURES AND MANUALS + REGULATION, AEC

1-10404 ANDREWS JS
THE WINDSCALE ADVANCED GAS-COOLED REACTOR
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
8 PAGES, 6 TABLES, ENERGIE NUCLEAIRE, 7(7), PP. 410-417 (NOVEMBER 1965)

THIS ARTICLE DISCUSSES THE DESIGN OF THE WINDSCALE AGR AND ITS AUXILIARY EQUIPMENT AND GIVES AN ACCOUNT OF THE COMMISSIONING OF THE REACTOR AND OF ITS OPERATION OVER TWO-AND-A-HALF YEARS TO THE AUTUMN OF 1965. IT OUTLINES THE EXPERIMENTAL WORK CARRIED OUT, WITH SPECIAL REFERENCE TO THE SATISFACTORY BEHAVIOR OF THE FUEL. FINALLY AN INDICATION IS GIVEN OF POSSIBLE FUTURE DEVELOPMENTS IN GAS-COOLED-REACTOR TECHNOLOGY ARISING FROM THIS WORK.

*AGR (ADVANCED GASCOOLED REACTOR, WINDSCALE, UK) + DESIGN STUDY + OPERATING EXPERIENCE + REACTOR, GAS COOLED + UNITED KINGDOM

1-10405 DAVIS K + MCCULLOUGH CR
SAFETY IN THE NUCLEAR POWER INDUSTRY
4 PAGES, NUCLEAR NEWS-ANS, 7(10), PP. 98-101 (OCTOBER 1964)

ABOUT 10 PERCENT OF THE THIRD GENEVA CONFERENCE (1964) WAS DEVOTED TO NUCLEAR SAFETY. SAFETY WAS TREATED AS AN IMPORTANT BUT NORMAL ENGINEERING PROBLEM, AND WITH GROWING CONFIDENCE. THIS CONTRASTED WITH THE ATTITUDE AT THE FIRST CONFERENCE, WHERE SAFETY HAD RECEIVED MAJOR ATTENTION AND VERY CAUTIOUS ATTITUDES HAD BEEN EXPRESSED. IT WAS CONCLUDED THAT THERE HAS

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10405 *CONTINUED*

NOT BEEN ANY DETERRENT TO THE GROWTH OF NUCLEAR POWER BY THE SAFETY PROBLEMS OF GOVERNMENT REGULATIONS. THERE IS STILL NEED FOR ADDITIONAL STUDY AND EXPERIMENT, AND FOR CRITERIA WHICH WILL LEAD TO MORE ECONOMICAL AND SAFER DESIGN.

*SAFETY PRINCIPLES AND PHILOSOPHY + ATMOSPHERIC DIFFUSION + CONCRETE, PRESTRESSED + CONTAINMENT, GENERAL + ENGINEERED SAFEGUARD + RADIOCHEMICAL PROCESSING + REACTOR SAFETY SYSTEM + REACTOR, MARITIME + SITING, GENERAL + TRANSPORTATION AND HANDLING

1-10409 PETRENKO LI + SAVITSKII PS + SINITSIN VI + KOLCTYRKIN YM + SYRKUS NP + ROMM RF
THE USES OF RADIOACTIVE ISOTOPES AND NUCLEAR RADIATION IN THE U.S.S.R. PROCEEDINGS OF THE ALL-UNION CONFERENCE HELD IN RIGA, 12-16 APRIL 1960. VOLUME ONE. GENERAL PROBLEMS CONNECTED WITH THE USE OF ISOTOPES. DEVICES INCORPORATING RADIOACTIVE OIL INDUSTRIES
AEC-TR-6466-1 + CONF-600 402 (VOL I) +. 339 PAGES, FIGURES, TABLES, 1961, CFSTI, \$7.00 CY

AN ALL-UNION CONFERENCE WAS HELD IN RIGA IN 1960 ON THE USES OF RADIOACTIVE ISOTOPES AND NUCLEAR RADIATION IN THE U.S.S.R. PROCEEDINGS WERE REPORTED IN FOUR VOLUMES. THIS ONE (VOL. I) INCLUDES GENERAL PROBLEMS CONNECTED WITH THE USE OF ISOTOPES (6 PAPERS), DEVICES INCORPORATING RADIOACTIVE SOURCES (17 PAPERS), RADIATION CHEMISTRY (13 PAPERS), AND CHEMICAL AND OIL INDUSTRIES (14 PAPERS). NO BIBLIOGRAPHY OR REFERENCES ARE GIVEN.

*RADIOISOTOPE + ECONOMIC STUDY + INSTRUMENTATION, GENERAL + RADIOCHEMICAL PROCESSING + SOURCE, RADIATION + UNION OF SOVIET SOCIALIST REPUBLICS

1-10411 KOUTS HJ
RESEARCH FOR REACTOR SAFETY IN THE UNITED STATES
BROOKHAVEN NATIONAL LABORATORY
BNL-10138 + CONF-660312-4 +. 17 PAGES, APRIL, 1966, NEDERLANDS ATOOMFORUM, UTRECHT, CFSTI, \$1.00 CY, \$0.50 MN

THE ASSESSMENT OF THE SAFETY OF NUCLEAR REACTORS IN THE UNITED STATES IS A COMBINATION OF MANY JUDGMENTS. THE STUDIES TO IMPROVE SAFETY AND ITS ANALYSIS IS DONE PARTLY BY MANUFACTURERS AND PARTLY THROUGH THE REACTOR DEVELOPMENT PROGRAM OF THE USAEC. THE NUMBER OF PROBLEMS BEING STUDIED IS VERY LARGE. THE PROGRAM WILL BE DESCRIBED, WITH EMPHASIS ON ITS MAJOR ASPECTS. PERSONAL VIEWS ABOUT WHAT IS TO BE ACCOMPLISHED ARE GIVEN.

*REVIEW + *SAFETY PRINCIPLES AND PHILOSOPHY + ACCIDENT ANALYSIS + ACCIDENT, HYPOTHETICAL

1-10412 BENNELICK EJ
A REVIEW OF THE TOXICOLOGY AND POTENTIAL HAZARDS OF NATURAL, DEPLETED AND ENRICHED URANIUM
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AHSB(RP)-R-5P +. 44 PAGES, MARCH, 1966, HMSO, BIS, \$1.20 CY

THIS REPORT IS BASED ON A SELECTION OF PUBLISHED AND UNPUBLISHED DATA ON URANIUM, ITS COMPOUNDS AND ALLOYS. IT REVIEWS FROM THE STANDPOINT OF POTENTIAL HAZARDS, THE MAIN PHYSICAL, CHEMICAL, AND NUCLEAR PROPERTIES AND BIOLOGICAL BEHAVIOR OF URANIUM. IT DISCUSSES THE TOXICOLOGY OF URANIUM AND ALSO REPRODUCES THE DERIVED WORKING LIMITS FOR EXPOSURE TO THE MATERIAL FORMULATED BY THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY. DATA IS GIVEN ON EXTERNAL RADIATION DOSE RATES, INCLUDING THAT FROM PROCESSED IRRADIATED URANIUM. FINALLY A REVIEW IS GIVEN OF FIRE AND EXPLOSION HAZARDS AND CRITICALITY ASPECTS.

*CHEMICAL TOXICITY + *HAZARD, RELATIVE + *URANIUM + BIOMEDICAL + CRITICALITY SAFETY + EXPLOSION + FIRE + PERSONNEL EXPOSURE, RADIATION + REVIEW + UNITED KINGDOM

1-10618 CHALMERS JH + WALKER G + PUGH J
HANDBOOK OF CRITICALITY DATA. VOLUME 1
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
AHSB(S)-HANDBK-1(1ST. REV)+. 142 PAGES, 3 REFERENCES, 1965, BIS \$8.40

COLLECTION OF CRITICALITY DATA ON URANIUM SYSTEMS, PLUTONIUM SYSTEMS, MIXED PLUTONIUM SYSTEMS, AND MISCELLANEOUS DATA.

*CRITICALITY SAFETY + CRITICALITY EXPERIMENT + PLUTONIUM + URANIUM

1-10619 BRUNA JG + BRUNET JP + CAIZERGUES R + CLOUET D ORVAL C + KREMSER J + TELLIER H + VERKIEKE P
ALECTO - RESULTS OBTAINED WITH HOMOGENEOUS CRITICAL EXPERIMENTS ON PLUTONIUM 239, URANIUM 235 AND URANIUM 233
COMMISSARIAT A L ENERGIE ATOMIQUE, FRANCE, CENTRE D ETUDES NUCLEAIRES, SACLAY
CEA-R-2814 +. 130 PAGES, 37 FIGURES, 24 TABLES, OCTOBER 1965, DEP. MN

IN THIS REPORT ARE GIVEN THE RESULTS OF THE HOMOGENEOUS CRITICALITY EXPERIMENTS ALECTO, MADE ON PLUTONIUM-239, URANIUM-235 AND URANIUM-233. AFTER A BRIEF DESCRIPTION OF THE EQUIPMENT, THE CRITICAL MASSES FOR CYLINDERS OF DIAMETERS VARYING FROM 25 TO 42 CM ARE GIVEN AND COMPARED WITH OTHER VALUES (FOREIGN RESULTS, CRITICALITY GUIDE). EXPERIMENTS RELATING TO CROSS SECTIONS AND CONSTANTS TO BE USED ON THESE MATERIALS ARE PRESENTED. LASTLY, KINETIC EXPERIMENTS ALLOW ONE TO COMPARE PULSED-NEUTRON METHODS WITH FLUCTUATION METHODS.

*CRITICALITY EXPERIMENT + CRITICALITY SAFETY + NOISE ANALYSIS + PLUTONIUM + PULSED NEUTRON TECHNIQUE + URANIUM

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10656 MALAKHOF V + SIMON W
CRITICALITY OF FUEL REPROCESSING EQUIPMENT
GENERAL ATOMIC
GAMD-6623 +. 20 PAGES, AUGUST 17, 1965, CFSTI, \$1.00 CY, \$0.50 MN

A STUDY OF THE CRITICALITY OF FUEL-PARTICLE STORAGE CONTAINERS AND OF ARRAYS OF SUCH CONTAINERS WAS CARRIED OUT. THE OBJECTIVE WAS TO COMPUTE THE MULTIPLICATION FACTOR AS A FUNCTION OF LENGTH AND DIAMETER FOR CYLINDRICAL CONTAINERS AND TO COMPUTE MASS LIMITS FOR VARIOUS KINDS OF FUEL PARTICLES THAT HAVE BEEN COATED WITH PYROLYTIC CARBON.

*CARBON + *CRITICALITY SAFETY + *PYROLYTIC + *URANIUM + COMPUTER, DIGITAL + THORIUM

1-10695 LONG JK + MCVEAM RL + REYNOLDS AB + STEWART SL + WEITZBERG A + LERIDON A
CRITICAL MASS OF SEFOR MOCKUP IN ZPR-III
ARGONNE NATIONAL LABORATORY, IDAHO FALLS, IDAHO + GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA + CENTRE
D ETUDES NUCLEAIRES DE CADARACHE, FRANCE
2 PAGES, 1 FIGURE, 1 TABLE, 12 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING 25 (4)- 442-443 (1966)

CRITICALITY OF THE MOCKUP OF THE SOUTHWEST EXPERIMENTAL FAST OXIDE REACTOR (SEFOR) IN THE ZPR-III FACILITY WAS ACHIEVED NOVEMBER 17, 1965. THE NEUTRON SPECTRUM AND URANIUM-TO-PLUTONIUM RATIO OF THIS ALL-PLUTONIUM CRITICAL IS CHARACTERISTIC OF LARGE, FAST, CERAMIC POWER REACTORS. THE CRITICAL LOADING WAS THE FIRST IN A SERIES OF EXPERIMENTS.

*SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR) + CRITICAL ASSEMBLY FACILITY + CRITICALITY EXPERIMENT + REACTOR, BREEDER + REACTOR, FAST + ZPR III (ANL ZERO POWER REACTOR)

1-10718 BROWN CL
CRITICALITY SAFETY OF PUO₂-SS DRIVER FUEL IN THE FFTF
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-222 +. PAGES 10-11 OF PHYSICS RESEARCH QUARTERLY REPORT - OCTOBER, NOVEMBER, DECEMBER 1965. JANUARY 14, 1966, CFSTI, \$2.00 CY, \$0.50 MN

UPDATES, IN THE LIGHT OF SLIGHT DESIGN CHANGES, THE REACTIVITY SAFETY CALCULATIONS OF THE PLUTONIUM OXIDE-STAINLESS STEEL DRIVER IN THE FFTF.

*FAST NEUTRON + *HANFORD SITE + CRITICALITY SAFETY + REACTIVITY, EXCESS + REACTOR, TEST

1-10805 BIERMAN SR
PULSED NEUTRON SOURCE MEASUREMENTS OF THE Z-9 CRIB
HANFORD ATOMIC PRODUCTS OPERATION
HW-80913 +. 9 PAGES, MARCH 16, 1964, CFSTI, \$1.00 CY

THE PULSED-NEUTRON TECHNIQUE IS THOUGHT OF AS A DEVICE TO MEASURE THE SUBCRITICALITY OF COMPONENTS OF PLANTS WHICH HANDLE FISSIONABLE MATERIAL. THE ACTUAL EXPERIMENTS IN THE HANFORD CRITICAL MASS LABORATORY WERE DONE IN CONJUNCTION WITH MEASUREMENTS OF CRITICAL MASS, CONTROL AND SAFETY ROD WORTH, AND NEUTRON LIFETIMES. INCLUDES ANALYSIS OF THE EXPERIMENTS.

*FUEL HANDLING + *PULSED NEUTRON TECHNIQUE + *SHUTDOWN MARGIN + CONTROL ROD WORTH + CRITICALITY SAFETY + PROMPT NEUTRON LIFETIME + RADIOCHEMICAL PROCESSING

1-10824 CUPINI E + DE MATTEIS A
RAM--AN IBM-7094 MONTE CARLO CODE FOR CRITICALITY CALCULATIONS
COMITATO NAZIONALE PER L ENERGIA NUCLEARE, ROME, ITALY
RT/FIMA (65)5 +. 29 PAGES, NOVEMBER, 1965, DEP/MN

THE TECHNIQUE APPLIED HERE IS ESSENTIALLY THAT DESCRIBED BY GOERTZEL AND KALOS. STARTING FROM AN ARBITRARY SPATIAL DISTRIBUTION OF PRIMARY NEUTRONS, SEVERAL NEUTRON GENERATIONS ARE FOLLOWED UNTIL AN EQUILIBRIUM FORM OF THIS SPATIAL DISTRIBUTION IS SETTLED DOWN. THE MULTIPLICATION CONSTANT, K-SUB-EFF, IS THEN COMPUTED AS THE RATIO BETWEEN THE NUMBER OF PRIMARY NEUTRONS BELONGING TO TWO SUCCESSIVE GENERATIONS.

*COMPUTER, DIGITAL + *CRITICALITY SAFETY

1-10825 CLAYTON ED + RICHEY CR + LLOYD RC + BIERMAN SR + CARTER LL
CRITICALITY RESEARCH ON PLUTONIUM
BATTELLE-NORTHWEST, RICHLAND, WASHINGTON
BNWL-SA-214 + CONF-651103-10 +. 26 PAGES, AUGUST 12, 1965, IAEA SYMPOSIUM ON CRITICALITY CONTROL OF FISSIONABLE MATERIALS, STOCKHOLM, CFSTI, \$2.00 CY, \$0.50 MN

RESULTS FROM CRITICALITY EXPERIMENTS WITH PLUTONIUM SOLUTIONS AND COMPOUNDS, PLUS ANALYSES OF DATA THEREFROM. PREVIOUSLY ESTIMATED CURVES FOR CRITICAL DIMENSIONS OF HOMOGENEOUS, WATER-MODERATED PLUTONIUM-239 IN THE UNDERMODERATED RANGE HAVE BEEN REVISED. CURVES ON PU-240. EFFECT OF NITRATE ON CRITICALITY FOR REFLECTED SPHERES. INTERACTION EXPERIMENT WITH DRY PUO₂ POWDER IN A LOW-DENSITY REFLECTED CUBIC ARRAY. PLANNED EXPERIMENTS.

*CRITICALITY EXPERIMENT + *CRITICALITY SAFETY + HANFORD SITE + PLUTONIUM

1-10838 A NEW WAY TO TRIM ACCIDENT COSTS

ACCESSION NUMBER 1-10656 TO 1-10838

CATEGORY 1
GENERAL SAFETY CRITERIA

1-10838 *CONTINUED*
2 PAGES, FACTORY, PAGES 76-79 (JULY, 1966), MCGRAW-HILL PUBLICATION, \$1.00 CY

UNEXPECTED SUPPORT FOR THE MCA APPROACH TO REACTOR SAFETY MAY BE INFERRED FROM THIS DISCUSSION OF CONVENTIONAL INDUSTRIAL SAFETY. A LARGE INSURANCE COMPANY RECOMMENDS REPORTING INDUSTRIAL ACCIDENTS ON THE BASIS OF COST AND CAUSE, THEN WORKING ON THE EXPENSIVE ACCIDENTS WHERE PAYOFF IS BIG, FAST, AND CERTAIN. CASE STUDIES SHOW THAT HUMAN ERRORS FALL INTO A FEW MAIN-ISSUE CAUSES AND THAT WHEN LOCAL SAFETY PROGRAMS ARE CONCENTRATED ON CERTAIN POOR WORKING HABITS, RESULTS ARE BETTER THAN GENERALIZED BE-SAFE PROGRAMS.

*ADMINISTRATIVE CONTROLS AND PRACTICES + *OPERATING EXPERIENCE + *SAFETY PRINCIPLES AND PHILOSOPHY

1-10932 WHITESIDES GE + MORRISON GW + CPUME EC
FEW-GROUP MONTE CARLO CRITICALITY CALCULATIONS
UNION CARBIDE CORPORATION, OAK RIDGE, TENNESSEE
2 PAGES, 1 TABLE, 10 REFERENCES, AND TRANSACTIONS 9(1), PAGES 133-134 (JUNE, 1966), AMERICAN NUCLEAR SOCIETY ANNUAL MEETING, DENVER, COLORADO, JUNE 20-23, 1966

A GENERAL-PURPOSE MONTE CARLO NEUTRON-TRANSPORT CODE WAS ALTERED TO ACCEPT THE 16-GROUP ENERGY STRUCTURE OF HANSEN AND ROACH. THE TRANSPORT, SCATTERING, AND FISSION CROSS SECTIONS FOR THE GROUPS ARE INPUT FOR EACH ELEMENT IN A MEDIUM. NEUTRON SLOWING DOWN IS TREATED BY SAMPLING FROM THE TRANSFER MATRIX CROSS SECTIONS.

*COMPUTER, DIGITAL + *CRITICALITY SAFETY + MONTE CARLO

1-11160 ANNUAL REPORT, 1965-66
CHALK RIVER, AECL
AECL-2407 +. 48 PAGES, FIGURES, 1966, DEP. MN

STATUS REPORT (A BROCHURE) OF ATOMIC ENERGY OF CANADA LIMITED, INCLUDING NONTECHNICAL DESCRIPTIONS OF CANADIAN AND INDIAN REACTORS, BUT WITHOUT SPECIFIC REFERENCE TO SAFETY.

*CANADA + *INDIA + HEAVY WATER + URANIUM, NATURAL

1-11161 TUTTLE RJ
A SUMMARY OF THE CALCULATED CHARACTERISTICS OF THE EPITHERMAL CRITICAL ASSEMBLIES 1 THROUGH 13
ATOMIC INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11799 +. 92 PAGES, JANUARY 12, 1966, CFSTI \$3.00 CY, \$0.75 MN

PROBLEM - SUMMARIZE THE RESULTS OF CALCULATIONS PERFORMED FOR THE CRITICAL ASSEMBLIES AT THE EPITHERMAL CRITICAL EXPERIMENT LABORATORY TO FACILITATE ANALYSIS OF THE EXPERIMENTAL RESULTS AND AID FUTURE EXPERIMENTAL PLANNING. RESULTS - CRITICALITY CALCULATIONS AND PERTURBATION THEORY CALCULATIONS OF THE PROMPT-NEUTRON LIFETIME, EFFECTIVE DELAYED-NEUTRON FRACTION AND AVERAGE FISSION IMPORTANCE ARE TABULATED FOR THE ECEL CORES 1-13. THE FLUX AND ADJOINT SPECTRA ARE TABULATED AND PRESENTED IN GRAPHICAL FORM. MATERIAL SPECIFICATIONS AND THE CROSS-SECTION LIBRARY USED IN THE CALCULATIONS ARE ALSO RECORDED. A BIBLIOGRAPHY OF THE EXPERIMENTAL PROGRAM IS PROVIDED.

*CRITICALITY EXPERIMENT + DELAYED NEUTRON + PROMPT NEUTRON LIFETIME + ROSSI ALPHA

1-11398 SMIDT D + FRISCH W + GIORDANO P + HEUSENER G + KESSLER G + KREWER KH + MERK W + MALMBERG T + SCHONFELD E
SAFETY AND COST ANALYSIS OF A 1000-MWE SODIUM-COOLED FAST POWER REACTOR
INSTITUTE FOR REACTOR DEVELOPMENT, KERNFORSCHUNGSZENTRUM, KARLSRUHE, GERMANY
ANL-7120 +. 13 PAGES, 6 TABLES, 14 FIGURES, OCTOBER 11-14, 1965, PAGES 33-45, PROCEEDINGS OF THE CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

THE MAIN FEATURES INCLUDE A CYLINDRICALLY SHAPED, OXIDE FUEL (87 PERCENT THEORETICAL DENSITY), NO MODERATOR, SUCH AS BEO, AND A MODERATE FLATTENING WITH A HEIGHT-TO-DIAMETER RATIO OF 1 TO 3. THIS RESULTS IN A RELATIVELY LARGE NEGATIVE DOPPLER COEFFICIENT AND AN INTERNAL BREEDING RATIO CLOSE TO UNITY. THE VOID COEFFICIENT WILL THEN BE SOMEWHAT LARGER THAN THAT IN SEVERAL OTHER DESIGNS. ITS EFFECT ON OVERALL SAFETY IS ONE OF THE TOPICS OF THIS PAPER. THE CAPITAL COSTS, BASED ON STUDIES FROM INDUSTRY, WERE CALCULATED TO BE \$115/KW.

*ECONOMIC STUDY + *GERMANY + *REACTOR, BREEDER + *SAFETY STUDY + DESIGN STUDY + REACTOR, LIQUID METAL COOLED

1-11399 DENIELOU G + ABOON R + FOURNIER J + LADET J + PUIG I + ROBIN M + ZALESKI CP
CONTRIBUTION TO SAFETY PROBLEMS RELATED TO A 1000-MWE FAST POWER REACTOR PROJECT
EURATOM CEA, (CADARACHE), FRANCE
ANL-7120 +. 5 PAGES, 3 TABLES, 3 FIGURES, 1 REFERENCE, OCTOBER 11-14, 1965, PAGES 157-161, PROCEEDINGS OF THE CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

THE FRENCH APPROACH TO REACTOR SAFETY IS RATHER EMPIRICAL, BEING LARGELY BASED ON PAST EXPERIENCE. THOUGH ACCEPTED SAFETY CRITERIA ARE WIDELY USED, THEY REMAIN VERY OFTEN UNWRITTEN. DESIGNERS ARE GIVEN MUCH FREEDOM- THEY KNOW ONLY THAT THEY MUST BE ABLE TO CONVINCE EVERY SCIENTIFICALLY AND TECHNICALLY COMPETENT NON-EXPERT OF THE VALIDITY OF THEIR HYPOTHESES. IT COULD BE SAID THAT SAFETY IS ACHIEVED BY THE GENERAL AGREEMENT OF LEARNED PEOPLE. THE REACTOR SAFETY SUB-COMMITTEE, WHOSE AUTHORITY IS ABSOLUTELY UNDISPUTED, EMBODIES THIS AGREEMENT. THE EXAMPLE OF THE 1000-MWE REACTOR PROJECT IS A GOOD ILLUSTRATION. THE

CATEGORY 1
GENERAL SAFETY CRITERIA

1-11399 *CONTINUED*

AUTHORS ARE CONFIDENT THAT THEY WILL BE ABLE TO CONVINCE ANYBODY OF ITS GOOD SAFETY FEATURES. ACTUALLY, ON A GOOD MANY POINTS THEY HAVE ALREADY SUCCEEDED, BUT ON OTHERS MUCH RESEARCH AND DEVELOPMENT MUST BE DONE.

*FRANCE + *REACTOR, FAST + *SAFETY STUDY + REACTOR, POWER + SAFETY PRINCIPLES AND PHILOSOPHY

1-11404 ROM FE

FAST AND MODERATED LOW-POWER, LIGHTWEIGHT REACTORS FOR NUCLEAR ROCKET PROPULSION
NASA, LEWIS RESEARCH CENTER, CLEVELAND, OHIO

N-65-29480 + NASA-TM-X-52047 +. 75 PAGES, REFERENCES, 1964, CFSTI \$3.00 CY, \$0.75 MN

THE NUCLEAR PROPULSION SCHEME CONSIDERED IS THE DIRECT-HEATING SYSTEM WHERE HYDROGEN, THE PROPELLANT, IS HEATED BY PASSING IT THROUGH A REACTOR CORE MADE OF HIGH-TEMPERATURE MATERIALS. IT IS USED TO COOL THE NOZZLE, REFLECTOR, PRESSURE SHELL, OR ANY OTHER PARTS THAT REQUIRE COOLING BEFORE IT PASSES THROUGH THE REACTOR CORE. THE CORE IS COMPOSED OF AN ARRAY OF FUEL-BEARING HEAT-TRANSFER PASSAGES THAT PERMIT REMOVAL OF THE FISSION ENERGY GENERATED WITHIN THE CORE MATERIALS. THRUST IS PRODUCED BY EXPANDING THE HEATED HYDROGEN THROUGH A CONVERGENT-DIVERGENT NOZZLE. A CONTROL SYSTEM IS PROVIDED TO START, OPERATE, AND SHUT DOWN THE REACTOR.

*NUCLEAR ROCKET + *REACTOR DESCRIPTION + *REACTOR, SPACE

1-11407 LEVENSON M + ADAMS RM

ADMINISTRATION OF NUCLEAR SAFETY AT ANL
ARGONNE NATIONAL LABORATORY, ARGONNE

6 PAGES, NUCLEAR SAFETY 7(1), PAGES 1-6, (FALL 1965)

THE SAFETY PROGRAM OF ARGONNE NATIONAL LABORATORY, CONCERNED SPECIFICALLY WITH RADIOACTIVE AND FISSIONABLE MATERIALS AND WITH REACTORS, MAY BE CONSIDERED TO CONSIST OF TWO BROAD AREAS INVOLVING RADIATION SAFETY AND NUCLEAR SAFETY. AN ATTEMPT HAS BEEN MADE TO ESTABLISH A SYSTEM OF CHECKS AND BALANCES WHICH WILL ENSURE THAT NO SIGNIFICANT FACTS HAVE BEEN OVERLOOKED IN ANALYZING THE SAFETY OF PROPOSED OPERATIONS BY REQUIRING REVIEW BY EXPERIENCED BUT DISINTERESTED EXPERTS. TO ASSIST IN DISCHARGING NUCLEAR-SAFETY RESPONSIBILITIES, TWO ADVISORY COMMITTEES WERE CONSTITUTED - THE REACTOR SAFETY REVIEW COMMITTEE AND THE CRITICALITY HAZARDS CONTROL COMMITTEE.

*ADMINISTRATIVE CONTROLS AND PRACTICES + *ANL (ARGONNE NATIONAL LABORATORY) +
*SAFETY PRINCIPLES AND PHILOSOPHY + CRITICALITY SAFETY + RADIOCHEMICAL PLANT SAFETY + REACTOR, RESEARCH

1-11408 SMITH JL

LEGAL ASPECTS OF A RADIATION-SAFETY PROGRAM

6 PAGES, REFERENCES, NUCLEAR SAFETY 7(1), PAGES 6-11, (FALL 1965)

THE RADIATION-SAFETY PROGRAM OF AN INDUSTRIAL CONCERN OR LABORATORY SHOULD HAVE AS ITS PRIMARY PURPOSE THE PROTECTION AND SAFETY EDUCATION OF ITS EMPLOYEES. FURTHER, THE PROGRAM, ALTHOUGH NOT ESTABLISHED TO PROVIDE EVIDENCE IN AN INJURY CLAIM OR A LAWSUIT, SHOULD ALSO PROVIDE ADEQUATE RECORDS THAT CAN BE USED IF A RADIATION INJURY OR DAMAGE CLAIM IS MADE OR A LAWSUIT IS FILED. THREE LAWSUITS ARE REFERENCED AND DISCUSSED IN WHICH SUCH RECORDS WERE INVALUABLE.

*LAW + *PERSONNEL EXPOSURE, RADIATION + *RADIATION DAMAGE + RADIATION IN PERSPECTIVE +
RADIATION, PUBLIC EDUCATION/ACCEPTANCE

1-11410 STERNER JH

ATOMIC ENERGY FOR SOCIETY AND THE BALANCE BETWEEN HAZARD AND GAIN
EASTMAN KODAK COMPANY, ROCHESTER, N. Y.

5 PAGES, REFERENCES, NUCLEAR SAFETY 7(1), PAGES 14-18, (FALL 1965)

HEALTH PROBLEMS CREATED BY THE PEACEFUL USES OF ATOMIC ENERGY ARE NOT SIGNIFICANTLY DIFFERENT, QUANTITATIVELY OR QUALITATIVELY, FROM MANY OF THE OTHER ENVIRONMENTAL HEALTH PROBLEMS CONFRONTING SOCIETY. IT IS ONLY THAT INORDINATE CONCERN BY THE GENERAL PUBLIC TENDS TO OVEREMPHASIZE THE HIGHLY PUBLICIZED HAZARDS INHERENT IN THE USE OF ATOMIC ENERGY, WITHOUT APPROPRIATE CONSIDERATION FOR THE GAINS WHICH MAY BE DERIVED. SOCIETY MAY THUS BE DEPRIVED OF THE SUBSTANTIAL PROFITS THAT CAN ACCRUE FROM ORDERLY DEVELOPMENT OF THE INDUSTRY. THE EXPERIENCE OF ABOUT A THOUSAND NUCLEAR REACTOR YEARS HAS DEVELOPED A PERFORMANCE RECORD FOR THE INDUSTRY WHICH IS EXCELLENT IN COMPARISON WITH THAT OF OTHER MAJOR INDUSTRIES. NO INJURY HAS BEEN IDENTIFIED IN INDIVIDUALS OR GROUPS EXPOSED TO ALLOWABLE OPERATIONAL LEVELS OF RADIATION, BASED ON THE SAME KIND OF RISK ASSESSMENT AS HAS BEEN APPLIED IN THE EVALUATION OF OTHER OCCUPATIONAL AND ENVIRONMENTAL HEALTH HAZARDS.

*COMPARISON, THEORY AND EXPERIENCE + *RADIATION IN PERSPECTIVE + *REACTOR, GENERAL + HAZARD, RELATIVE +
POPULATION EXPOSURE + RADIATION, PUBLIC EDUCATION/ACCEPTANCE

1-11443 THE ATOM - FRIEND OR FOE (PARTS I - IV)

10 PAGES, UNITED MINE WORKERS JOURNAL, SEPTEMBER 15, 1965

SERIES OF ARTICLES STRINGING TOGETHER QUOTATIONS FROM 1957 BROOKHAVEN REPORT, TESTIMONY BEFORE JCAE, AND VARIOUS MAGAZINE ARTICLES TO SHOW THAT NUCLEAR REACTORS CAN LEAVE ACCIDENTS ENDANGERING 750,000 SQUARE MILES OR MORE. NOT BLATANTLY PREJUDICED OR SCARE TYPE OF ARTICLE, BUT DEFINITELY A ONE-SIDED VIEW.

CATEGORY 1
GENERAL SAFETY CRITERIA

1-1144? *CONTINUED*

*RADIATION, PUBLIC EDUCATION/ACCEPTANCE + INCIDENT, ACTUAL, GENERAL + RADIATION IN PERSPECTIVE + WASTE DISPOSAL, GENFRAI

1-12019 BUCHANAN JR + CROSS NF
CURRENT NUCLEAR SAFETY RESEARCH AND DEVELOPMENT PROJECTS
OAK RIDGE NATIONAL LABORATORY
535 PAGES, JUNE 1966, CFSTI \$6.50 CY, \$2.25 MN

THIS SECOND ISSUE OF THE NUCLEAR SAFETY RESEARCH AND DEVELOPMENT CONTRACT REPORT SERVES AS A GUIDE TO THE NATIONS ACTIVITIES IN THE FIELD OF NUCLEAR SAFETY FOR THE SPECIALISTS AND SCIENTISTS ASSOCIATED WITH NSIC. SUFFICIENT INFORMATION IS GIVEN TO ENABLE INTERESTED PERSONS TO DETERMINE WHO IS DOING THE WORK, WHERE IT IS BEING DONE, THE SIZE OF THE PROGRAM, WHO IS SPONSORING THE WORK, AND THE APPROXIMATE FUNDING LEVEL. A BRIEF SUMMARY IS GIVEN TO DESCRIBE THE PURPOSE, NEED, AND SCOPE OF EACH PROGRAM. AN ATTEMPT WAS MADE TO INCLUDE ALL PUBLICATIONS ISSUED UNDER EACH CONTRACT.

*NSIC (NUCLEAR SAFETY INFORMATION CENTER) + *RESEARCH CONTRACT + *REVIEW

1-12022 HAFELE W
THE FAST BREEDER PROJECT KARLSRUHE
10 PAGES, 8 FIGURES, 1 TABLE, 42 REFERENCES, ATOMWIRTSCHAFT 11(6), PAGES 293-302, (JUNE 1966) IN GERMAN

THE TIME SCALE OF THE PROJECT ENVISAGES THE START OF THE CONSTRUCTION OF A 300-MW(E) PROTOTYPE REACTOR IN 1969 AND ITS COMPLETION BY 1973. SUBSEQUENTLY LARGE 1,000-MW (E) REACTORS SHOULD THEN FOLLOW BY 1978.

*KARLSRUHE + *REACTOR, BREEDER + *REACTOR, FAST + EURATOM + GERMANY + SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR)

1-12038 BAIL S.I
SIMULATORS FOR TRAINING MOLTEN-SALT REACTOR EXPERIMENT OPERATORS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
ORNL-TM-1445 +. 24 PAGES, 11 FIGURES, 2 TABLES, APRIL 5, 1966, CFSTI \$1.00 CY, \$0.50 MN

TWO ON-SITE REACTOR KINETICS SIMULATORS WERE DEVELOPED FOR TRAINING OPERATORS OF THE MOLTEN-SALT REACTOR EXPERIMENT (MSRE) IN NUCLEAR STARTUP AND POWER-LEVEL OPERATING PROCEDURES. BOTH SIMULATORS WERE SET UP ON GENERAL PURPOSE, PORTABLE ELECTRONIC ASSOCIATES, INC., TR-10 ANALOG COMPUTERS AND WERE CONNECTED TO THE REACTOR CONTROL AND INSTRUMENTATION SYSTEM. THE TRAINING PROGRAM WAS SUCCESSFULLY COMPLETED. ALSO, THE REACTOR CONTROL AND INSTRUMENTATION SYSTEM, THE OPERATING PROCEDURES, AND THE ROD AND RADIATOR-DOOR DRIVES WERE CHECKED OUT. SOME MINOR MODIFICATIONS WERE MADE TO THE SYSTEM AS A RESULT OF THE EXPERIENCE WITH THESE SIMULATORS.

*COMPUTER PROGRAM + *MSRE (MOLTEN SALT REACTOR EXPERIMENT) + *REACTOR KINETICS + *STAFFING, TRAINING, QUALIFICATION + COMPUTER, ANALOG

1-12041 BORNAND B
LISTING OF NUCLEAR CODES FOR IBM-704, 709, AND -7090
COMMISSARIAT A L'ENERGIE ATOMIQUE, SACLAY, FRANCE
CEA-BIB-17 (II) +. 143 PAGES, JANUARY 1966, CEA, IN FRENCH AND ENGLISH

THE DIGITAL COMPUTER CODES LISTED IN PARTS I AND II OF THIS BIBLIOGRAPHY WERE SELECTED ON THE BASIS OF THE MOST USEFUL CODES FOR REACTOR COMPUTATIONS. IN THE LISTING, THE CODES ARE ARRANGED CHRONOLOGICALLY IN EIGHT CATEGORIES - BURN-UP, ENGINEERING, GROUP DIFFUSION, KINETICS, TRANSPORT, PHYSICS, MONTE-CARLO, MISCELLANEOUS. BURN-UP, ENGINEERING, AND GROUP DIFFUSION ARE ISSUED IN PART I. MACHINE, FAST MEMORY, AND LANGUAGE ARE INDICATED. THE NUMBER OF THE REPORT THAT GIVES THE DETAILS OF THE CODE IS LISTED. INDEXES OF CODE NAMES, AUTHORS, AND OF QUOTED REPORTS ARE GIVEN. THIS BIBLIOGRAPHY HAS BEEN REVIEWED FROM 1957 TO MARCH 1964, FOR SECTION I, FROM 1957 TO MARCH 1965 FOR SECTION II.

*BIBLIOGRAPHY + *COMPUTER PROGRAM + *FRANCE

CATEGORY 2
SITING OF NUCLEAR FACILITIES

2-09544 SOME NON-TECHNICAL ASPECTS OF NUCLEAR POWER. PART I - CRITERIA AND SITING OF REACTORS
3 PAGES, EURONUCLEAR, 3(2), PP. 77-79 (FEBRUARY 1966)

THE VARIOUS CRITERIA FOR THE SITING OF REACTORS IN MANY COUNTRIES ARE DISCUSSED IN GENERAL TERMS. THE ASSUMPTIONS USED IN CALCULATING TYPICAL REACTOR SITING DISTANCES ARE DISCUSSED IN MORE DETAIL.

*SITING, REACTOR + DOSE + ENGINEERED SAFEGUARD + FISSION PRODUCT RELEASE, GENERAL + JAPAN + UNITED KINGDOM + UNITED STATES

2-09851 COUSINS N
REMARKS BY NORMAN COUSINS EDITOR, SATURDAY REVIEW AT THE SYMPOSIUM ON LOCATING NUCLEAR POWER PLANTS IN CITIES.
5 PAGES, PRESENTED AT THE ANS SYMPOSIUM ON LOCATING NUCLEAR POWER PLANTS IN CITIES, MARCH 22, 1966, NEW YORK CITY

LAYMANS VIEW AT THE SAFETY OF NUCLEAR PLANTS (AUTHOR IS EDITOR OF SATURDAY REVIEW). THE PAPER IS VERY GENERAL.

*SITING, REACTOR

2-10600 APPLICATION FOR LICENSES FPCE PLANT
ISOICHEM INC.
750 PAGES APPROX., 83 FIGURES, 71 TABLES, REFERENCES, JUNE 1966, DOCKET NO. 50-258, PDR

REPORT GIVES ALL THE GENERAL AND DETAILED TECHNICAL INFORMATION REQUIRED FOR AEC LICENSING OF A RADIOCHEMICAL PLANT. INCLUDED ARE SECTIONS ON - SITE DESCRIPTION, PLANT DESCRIPTION, PROCESS DESCRIPTION, EQUIPMENT DESCRIPTION, SYSTEMS ANALYSIS, PUBLIC PROTECTION, PERSONNEL PROTECTION, SAFETY, PLANT ORGANIZATION, AND STARTUP PLANS.

*APPLICATION FOR AEC LICENSE + *CERIUM + *CESIUM + *FPCE PLANT + *PROMETHIUM + *RADIOCHEMICAL PROCESSING + *SAFEGUARDS REPORT, GENERAL + *STRONTIUM + FISSION PRODUCT, SEPARATION FROM WASTE + FISSION PRODUCT, USE OF IN WASTES + HAZARDS ANALYSIS + ISOICHEM, INC. + RADIOCHEMICAL PLANT SAFETY

2-11805 CHANGE 22, ADDENDUM A. - FULL-TIME AVAILABILITY OF EMERGENCY CONDENSER (DURING REACTOR OPERATION) IN THE EVENT OF A TSUNAMI (TIDAL WAVE).
PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
4 PAGES, OCTOBER 3, 1966, DOCKET NO. 50-133, PDR

FURTHER REVIEW OF PROTECTION AGAINST TIDAL WAVES INDICATES THAT THE EMERGENCY CONDENSER SHOULD BE IN SERVICE ANYTIME THE REACTOR OPERATES.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + EMERGENCY COOLING + HUMBOLDT BAY + REACTOR, BOILING WATER + SEISMOLOGY

CATEGORY 3
TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS

3-09526 BELLET J + CHOUARD P + TALON R
HANDLING OF SUBASSEMBLIES AND LOADING OF SLEEVES OF THE HEATED CORE WITH THE HELP OF AN AUXILIARY GRIPPER
ON THE RAPSDIE ENGINEERING MOCK-UP
COMMISSARIAT A L ENERGIE ATOMIQUE, CADARACHE, FRANCE, CENTRE D ETUDES NUCLEAIRES
ORNL-TR-985 +. PNR/SEPR-65-004 +. 100 PAGES, FEBRUARY 26, 1965, JCL, \$8.60 FS, \$3.20 MF

REPORT DEALS WITH THE LOADING AND UNLOADING CAMPAIGNS CARRIED OUT WITH THE HELP OF AN
AUXILIARY GRIPPER ON THE RAPSDIE ENGINEERING MOCKUP, JULY-NOVEMBER, 1964. ON THE WHOLE, THE
UNLOADING OPERATIONS ENTAILED ONLY MINOR DETAIL MODIFICATIONS. AFTER THE ENCOURAGING RESULTS
OBTAINED WITH THE AUXILIARY GRIPPER WHICH CAN OPERATE EVEN IN ABNORMAL CASES OF UNLOADING,
WHICH IS IMPOSSIBLE WITH THE PRIMARY UNLOADING CASK CAR, IT SEEMS DESIRABLE THAT A GRIPPER
SPECIALLY ADAPTED TO WORKING CONDITIONS BE DESIGNED IN ORDER TO ALLOW SOME SPECIAL UNLOADINGS.

*FUEL HANDLING + *FUEL HANDLING MACHINE + COOLANT SYSTEM + SODIUM

3-09528 IMPROVEMENTS IN OR RELATING TO CONTAINERS FOR TRANSPORTING RADIOACTIVE MATERIALS
BRITISH PAT. 973,448 +. 3 PAGES, 1 FIGURE, OCTOBER 28, 1964, PATENT (BRITISH)

PATENT DESCRIBES IMPROVEMENTS IN OR RELATING TO CONTAINERS FOR TRANSPORTING RADIOACTIVE
MATERIALS, SPECIFICALLY ISOTOPES. THE UNIQUE FEATURE IS AN INNER, HERMETICALLY SEALED VESSEL
OF DENSE RADIATION-RESISTING MATERIAL INSIDE A THERMAL INSULATING CASING COMPOSED OF A HARD
WOOD. THESE CONTAINERS ARE THEN ENCLOSED IN A THIRD CONTAINER, WITH SPACING PROVIDED BETWEEN
THE OUTER TWO.

*SHIPPING CONTAINER + *THERMAL INSULATION + *TRANSPORTATION AND HANDLING

3-09564 WILKINS BW
FREEZING PRECAUTIONS IN SHIPPING SPENT FUEL, FEBRUARY 1966
GENERAL ELECTRIC COMPANY, SYRACUSE, N.Y.
2 PAGES, MARCH 18, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 17-18 (MAY 2, 1966)

SEVERAL INDIAN POINT CORE A SHIPMENTS WERE MADE WITH ALCOHOL ADDED TO THE CASK COOLANT. AFTER
THE 16-HR JOURNEY TO NFS, CASK PRESSURES WERE 19-34 PSI DUE TO VAPORIZATION CAUSED BY
FUEL-SURFACE TEMPERATURES AS HIGH AS 180 F. WOODEN ENCLOSURES WERE THEN TRIED, AND LOUVERS
ADJUSTED ACCORDING TO CASK SURFACE TEMPERATURE AND MANUFACTURERS CALCULATIONS. RUPTURE DISK
DISCHARGE LINE WAS CONNECTED TO 55-GAL DRUM TO MONITOR FOR LEAKAGE.

*OPERATING EXPERIENCE + *SHIPPING CONTAINER + FUEL ELEMENT + NFS (NUCLEAR FUEL SERVICES)

3-09850 DUHAMEL F + LAVIE JM
THE LIMITATION OF THE QUANTITIES OF RADIOACTIVE SUBSTANCES MANIPULATED OR TRANSPORTED. EVALUATION OF
ACCIDENTAL EXPOSURES TO RADIATION
ATOMIC ENERGY COMMISSION, NUCLEAR RESEARCH CENTER, SACLAY, FRANCE
AEC-TR-6525 +. 35 PAGES, TRANSLATED FROM HEALTH PHYSICS 10, PP. 453-468 (1964), JCL \$3.60 FS, \$1.25 MF

VARIOUS NATIONAL AND INTERNATIONAL GROUPS HAVE STUDIED THE PROBLEM OF LIMITING THE QUANTITIES
OF RADIOACTIVE SUBSTANCES THAT MAY BE MANIPULATED UNDER CERTAIN OPERATING CONDITIONS. THE
MOST VALUABLE STUDIES HAVE BEEN ACHIEVED ON THE BASIS OF RADIOBIOLOGY. NOW, IT IS CLEAR THAT
THE RESULTS FROM RADIOBIOLOGY DO NOT SUFFICE TO ESTABLISH A COMPLETE AND SCIENTIFIC BASIS.
FOR PRACTICAL APPLICATION, NUMEROUS COMPLEMENTARY HYPOTHESES MUST BE MADE. IN ATTEMPTING TO
INTERRELATE OPERATIONS THAT ARE VERY DIFFERENT, THE AUTHORS PROPOSE A PROCEDURE WHICH,
ALTHOUGH NOT SCIENTIFICALLY RIGOROUS, MAKES APPARENT THE RELATIONSHIPS BEING HYPOTHECATED
BETWEEN THE FUNDAMENTAL THEORETICAL ASSUMPTIONS AND THE PRACTICAL VALUE TO BE OBSERVED. THIS
PROCEDURE PERMITS ONE TO EVALUATE, UNAMBIGUOUSLY, THE MAXIMUM QUANTITIES TO BE MANIPULATED IN
THE CASE OF ANY RADIONUCLIDE, CHEMICAL FORM, PHYSICAL STATE, DEGREE OF CONTAINMENT, TYPE OF
OPERATION, KIND OF FACILITY AND TECHNICAL SKILL OF THE OPERATORS. THUS THIS PROCEDURE
POSSESSES GREAT FLEXIBILITY AND PERMITS ONE TO DETERMINE THESE QUANTITIES ON A SCALE
EXTENDING OVER A RANGE OF 10 TO THE 14.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + ACCIDENT, EXPOSURE + ADMINISTRATIVE CONTROLS AND PRACTICES +
TRANSPORTATION AND HANDLING

3-09968 REPROCESSING TECHNIQUES AND PROGRESS
2 PAGES, EURONUCLEAP 2(12), PAGES 604-605 (DECEMBER, 1965)

THE INCREASINGLY IMPORTANT PROBLEMS ASSOCIATED WITH THE REPROCESSING OF IRRADIATED NUCLEAR
FUELS ARE NOW ACHIEVING PRIORITY IN ALL COUNTRIES WHERE NUCLEAR POWER IS BEING, OR IS
EXPECTED TO BE, UTILIZED. THE EUROCHEMIC PLANT AT MOL IN BELGIUM IS EXPECTED TO PROVIDE A
LARGE PERCENTAGE OF THE REPROCESSING CAPACITY REQUIRED DURING THE NEXT FEW YEARS, BUT SEVERAL
OTHER NUCLEAR-DEVELOPED COUNTRIES HAVE THEIR OWN SMALLER PLANTS WHICH MAY ALSO CONTRIBUTE TO
THE TOTAL EUROPEAN REQUIREMENT.

*CONTAINMENT, FUEL REPROCESSING + *EUROCHEMIC + *RADIOCHEMICAL PROCESSING + BELGIUM + ITALY + NETHERLANDS +
TRANSPORTATION AND HANDLING + UNITED KINGDOM

3-10251 DIXON FE
EXTENDED FIRE TESTS ON TINPLATE CANS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARKWELL
AERE-M-1664 +. 13 PAGES, 12 FIGURES, REFERENCES, NOVEMBER, 1965, BIS, \$1.40, HMSO

CATEGORY 3
TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS

3-10251 *CONTINUED*

IAEA REGULATIONS REQUIRE THAT SOURCES OF GAMMA-EMITTING MATERIALS WITH A STRENGTH BETWEEN 3 AND 20 CURIES SHALL HAVE AN OUTER STEEL CONTAINMENT VESSEL OF 2 MM THICKNESS. IT IS VERY DIFFICULT TO OBTAIN SMALL STANDARD DRUMS IN THIS THICKNESS. TO PROVE THAT TINPLATE CONTAINERS WOULD WITHSTAND EXTENDED FIRE TESTS, SAMPLES WERE SUBJECTED TO A TORCH TEST (TO SIMULATE A JET OF FLAME) ON A CONTAINER FOR FOUR HOURS, AND A FOUR-HOUR FIRE TEST IN A COMPLETELY OXIDIZING ATMOSPHERE IN AN ELECTRIC FURNACE. A TORCHING FLAME OF 800 C FOR FOUR HOURS HAD NO SIGNIFICANT EFFECT ON THE STRENGTH OF THE CAN OR ON ITS ABILITY TO CONTAIN THE ISOTOPE SPECIFIED. AFTER THE OXIDIZING TEST AT 800 C, THE CAN, ALTHOUGH HEAVILY OXIDIZED, WAS STILL CAPABLE OF RETAINING THE ISOTOPE AS SPECIFIED.

*FIRE + *SHIPPING CONTAINER + *TEST, PROOF + CONTAINMENT INTEGRITY + HIGH TEMPERATURE + STEEL + THERMAL EXPERIMENT

3-10258 SALLERON C
INTERNATIONAL REGULATION OF TRANSPORT OF RADIOACTIVE MATERIALS. PRESENT TRENDS
PARIS UNIVERSITY, FRANCE
NP-15620 +. 45 PAGES, 1964, IN FRENCH, DEP. MN

THE MODIFICATIONS AND ALTERATIONS MADE IN 1963 BY THE INTERNATIONAL AGENCY FOR ATOMIC ENERGY TO THE REGULATIONS FOR TRANSPORTING RADIOACTIVE MATERIALS ARE SUMMARIZED. THE DEFINITIONS OF TERMS ARE GIVEN, AND THE MATERIALS EXEMPT FROM INTERNATIONAL REGULATION ARE DESCRIBED. THE CONDITIONS FOR PACKAGING AND PERMISSION FOR TRANSPORTATION ARE OUTLINED, AND THE REGULATIONS CONCERNING STORAGE AND TRANSPORTATION ARE INDICATED.

*IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY) + *REGULATION, IAEA + *TRANSPORTATION AND HANDLING

3-11301 SISLER JA + GAUERKE RC
NEW DEVELOPMENTS IN CONTAINERS FOR SHIPPING RADIOACTIVE MATERIALS
SANDIA CORPORATION, ALBUQUERQUE, NEW MEXICO
64-WA/NE-6 +. 7 PAGES, 7 FIGURES, 1964, FOR PRESENTATION AT THE ASME WINTER ANNUAL MEETING, NOVEMBER 29 - DECEMBER 4, 1964, NEW YORK, NEW YORK, ASME \$1.00 CY

NEW DEVELOPMENTS IN CONTAINERS FOR RADIOACTIVE MATERIALS, BASED ON THE RESULTS OF AN EXTENSIVE TESTING PROGRAM AT SANDIA CORPORATION, ARE DISCUSSED. THE ENTIRE TEST PROGRAM, INCLUDING FIRE, DROP, AND WATER-SUBMERGENCE TESTS, IS REPORTED. THE PRIMARY DEVELOPMENT IS THE INDICATION OF SAFETY OBTAINED BY SURROUNDING A HEAVY (4000-LB) CASK WITH A 6-IN. WALL OF DOUGLAS-FIR PLYWOOD. ADEQUATE PROTECTION FROM FIRE, IMPACT, AND SUBMERGENCE WAS ACHIEVED.

*STRUCTURAL INTEGRITY + *TEST, DESTRUCTIVE + SHIPPING CONTAINER + TRANSPORTATION AND HANDLING

3-11302 THOMPSON JT + MORGAN JM
NUCLEAR TRANSPORTATION. PART I. RESEARCH AND ITS COORDINATION. PART II. PROBLEMS ASSOCIATED WITH RESEARCH
JOHNS HOPKINS UNIVERSITY
82 PAGES, 1 FIGURE, 1 TABLE, 60 REFERENCES, DECEMBER 1965, SOURCE

A STUDY WAS MADE OF RESEARCH AND ITS COORDINATION AND OF PROBLEMS ASSOCIATED WITH RESEARCH IN THE INCREASINGLY IMPORTANT FIELD OF NUCLEAR TRANSPORTATION. THE PURPOSE OF THE STUDY WAS TO- (1) ASCERTAIN WHAT HAS BEEN COMPLETED, WHAT IS IN PROGRESS, AND WHAT LIES AHEAD- (2) JUDGE WHETHER OR NOT DUPLICATION IS PRESENT, IF THERE EXISTS GAPS IN THE PROGRAM UNDERWAY, OR IF NEEDED AREAS ARE BEING NEGLECTED- AND (3) DETERMINE IF THE EFFORT IS PROPERLY COORDINATED AND IF NOT RECOMMEND STEPS TO IMPROVE THE SITUATION. RECOMMENDATIONS AND CONCLUSIONS ARE MADE.

*OPERATIONS REPORTS, ANALYSIS + CRITICALITY SAFETY + ECONOMIC STUDY + INSURANCE + REGULATION, GENERAL + SAFETY STUDY + TRANSPORTATION AND HANDLING

3-11381 SHAPPERT LB + SALMON R
SHIPPING COST COMPARISONS FOR LEAD-, STEEL-, AND URANIUM-SHIELDED CASKS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE
ORNL-P-2161 + CONF-660532-1 +. 8 PAGES, FROM ATOMIC ENERGY COMMISSION TRAFFIC MANAGEMENT CONFERENCE, LAS VEGAS, NEV., 1966, CFSTI \$1.00 CY, \$0.60 MN

THIS REPORT DEALS MAINLY WITH A COST COMPARISON AMONG LEAD-, STEEL-, AND URANIUM-SHIELDED CASKS (25 TONS) THAT CAN BE SHIPPED BY MOTOR FREIGHT (25 TON WEIGHT). ECONOMICS OF THE TRANSPORTATION OF THESE CASKS ARE A FUNCTION OF HANDLING, TRANSPORTATION, INSURANCE, AND AMORTIZATION COSTS. THESE COSTS AND HOW THEY ARE AFFECTED BY CASK WEIGHT, ROUND-TRIP TIME, ETC., ARE DISCUSSED.

*ECONOMIC STUDY + *SHIELDING + LEAD + SHIPPING CONTAINER + URANIUM

3-11382 ANDELIN RL
HIGH-TEMPERATURE COMPATIBILITY TESTING OF MOLTEN PLUTONIUM FUEL-CONTAINER SYSTEMS
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-DC-7315 + CONF-651101-28 +. 5 PAGES, FOR PRESENTATION AT THE 13TH CONFERENCE ON REMOTE SYSTEMS TECHNOLOGY, WASHINGTON, D. C., 1965, CFSTI \$1.00 CY, \$0.50 MN

TO DETERMINE THE COMPATIBILITY OF MOLTEN PLUTONIUM AND ITS CONTAINER FOR THE FAST-BREEDER PROGRAM, FUEL-CONTAINER SYSTEMS AT RELATIVELY HIGH TEMPERATURES (900 TO 1150 C) WERE TESTED TO REDUCE THE TIME REQUIRED TO OBTAIN CORROSION DATA, AND THIS INFORMATION WAS EXTRAPOLATED

ACCESSION NUMBER 3-10251 TO 3-11382

CATEGORY 3
TRANSPORTATION AND HANDLING OF RADIOACTIVE MATERIALS

3-11382 *CONTINUED*

TO LOWER TEMPERATURES (600 TO 700 C), MORE PRACTICAL FOR REACTOR OPERATION. THIS REPORT DESCRIBES THE RESULTS OF SUCH TESTS ON TWO FUEL SYSTEMS - PLUTONIUM CONTAINED IN TANTALUM, AND 97.5 PERCENT PLUTONIUM PLUS 2.5 PERCENT IRON-GALLIUM STABILIZED FUEL ALLOY CONTAINED IN TANTALUM. THE TESTS WERE CONDUCTED IN A VACUUM.

*HIGH TEMPERATURE + *PLUTONIUM + REACTOR, BREEDER + REACTOR, FAST + TEST, PROOF

3-11423 MARRIOTT AJ + HOWDEN JL

TRANSPORT OF NON-IRRADIATED FISSILE MATERIAL UNDER THE INTERNATIONAL ATOMIC ENERGY AGENCY REVISED TRANSPORT REGULATIONS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, ALDERMASTON

9 PAGES, 1 TABLE, 4 FIGURES, JOURNAL OF BRITISH NUCLEAR ENERGY SOCIETY 5(2), PAGES 137-145, APRIL 1966

THE PAPER CHIEFLY RECOUNTS THOSE PARTS OF THE IAEA REGULATIONS THAT DEAL WITH THE TRANSPORT OF NONIRRADIATED FISSILE MATERIALS AND REVIEWS UKAEA ATOMIC WEAPONS RESEARCH ESTABLISHMENT EXPERIENCE WITH RELATED RECOMMENDATIONS ON THE DESIGN, MANUFACTURE, AND MAINTENANCE OF PACKINGS.

*EQUIPMENT DESIGN + *REGULATION, IAEA + CODES AND STANDARDS + CRITICALITY SAFETY + LIQUID FUEL + OPERATING EXPERIENCE + PLUTONIUM + SHIPPING CONTAINER + TEST, PROOF + TRANSPORTATION AND HANDLING + UNITED KINGDOM

3-11847 WHITTLE D + ANDERSON C

INVESTIGATION OF FUEL ELEMENT TEMPERATURES IN CHAPELCROSS DISCHARGE VESSELS AND TRANSPORT FLASKS DOMINION TAR AND CHEMICAL CO., LTD., CANADA + UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CHAPELCROSS PRODUCTION GROUP

8 PAGES, 8 FIGURES, 2 TABLES, 5 REFERENCES, BRITISH NUCLEAR ENERGY SOCIETY 5(2), PAGES 156-164, (APRIL 1966)

STEADY-STATE TEMPERATURE MEASUREMENTS HAVE BEEN MADE IN THE VESSELS USED AT THE UKAEA CHAPELCROSS WORKS FOR THE DISCHARGE AND TRANSPORT OF FUEL ELEMENTS. THESE MEASUREMENTS HAVE BEEN USED TO CALCULATE THE MAXIMUM TEMPERATURE TO WHICH AN IRRADIATED FUEL ELEMENT IS HEATED WHEN PLACED IN A DISCHARGE VESSEL AND TO CALCULATE THE MAXIMUM TEMPERATURE TO WHICH THE INTERIOR OF A WATER-FILLED TRANSPORT FLASK WOULD BE HEATED WHEN USED DURING HOT SUMMER WEATHER. EXPERIMENTAL AND DATA ANALYSIS TECHNIQUES WHICH CAN HAVE GENERAL APPLICATION TO SIMILAR PROBLEMS ARE ILLUSTRATED. MODELS FOR THE WET AND DRY TRANSPORT FLASKS ARE DESCRIBED, PERMITTING PREDICTIONS TO BE MADE OF SPECIFIC TEMPERATURE CONDITIONS WHICH WERE IN EXCELLENT AGREEMENT WITH MEASURED TEMPERATURES.

*HEAT TRANSFER EXPERIMENT + HEAT TRANSFER ANALYSIS + SHIPPING CONTAINER + TRANSPORTATION AND HANDLING

CATEGORY 4
AEROSPACE SAFETY

4-09577 MURRAY HS
THE STABILITY OF COUPLED-CORE NUCLEAR REACTOR SYSTEMS BY THE SECOND METHOD OF LIAPUNOV
UNIVERSITY OF ARIZONA
2 PAGES, 1965, DISSERTATION ABSTRACTS, 26(4), PP. 2089-2090 (1965), ORDER NO. 65-11,558, 105 PAGES,
XEROGRAPHY \$5.20, MICROFILM \$3.00

IN CONNECTION WITH THE USE OF MULTIPLE REACTORS FOR NUCLEAR ROCKETS, THE NEUTRONIC STABILITY OF THE ARRAY IS STUDIED, TAKING INTO ACCOUNT THE DELAY TERMS CAUSED BY THE TRANSIT TIME OF NEUTRONS FROM ONE CORE TO THE OTHER. A LIAPUNOV FUNCTION (V) IS CONSTRUCTED, BUT ITS DERIVATIVE IS NEGATIVE -- DEFINITE IF (V) IS SMALLER THAN A CERTAIN FUNCTION OF V. THIS CONDITION IS SAID TO BE SUFFICIENT FOR STABILITY.

*COUPLED CORES + *ROVER PROGRAM + LIAPUNOV'S FUNCTION + MATHEMATICAL STUDY + REACTOR DYNAMICS + REACTOR STABILITY

4-09600 BAZYKIN V
RADIATION HAZARDS IN OUTER SPACE
USSR ACADEMY OF SCIENCES, ASTRONOMY AND GEODESY SOCIETY
2 PAGES, 1 TABLE, AEROSPACE MEDICINE, 36(12), PP. 1194-1195 (DECEMBER 1965)

HAZARDS TO ASTRONAUTS FROM COSMIC RAYS AND RADIATION BELTS, PROBABLE DOSES (IN AND OUT OF CAPSULE), SOLAR ERUPTIONS AND DIFFICULTY IN FORECASTING THEM, AND EFFECT OF DIFFERENT RADIATIONS ARE DISCUSSED, WITH PARTICULAR REFERENCE TO SOVIET SPACE EFFORTS.

*AEROSPACE SAFETY + *COSMIC RADIATION + *HAZARDS ANALYSIS + *UNION OF SOVIET SOCIALIST REPUBLICS + DOSE + PERSONNEL EXPOSURE, RADIATION + RADIATION EFFECT

4-09608 GOOD RC
SOLAR FLARE HAZARDS - PREDICTABILITY
GENERAL ELECTRIC COMPANY, SPACE SCIENCES LABORATORY
AD-618905 + R65SD31 +. 45 PAGES, FIGURES, JULY, 1965, CFSTI, \$2.00 CY, \$0.50 MN

THE HAZARDS OF SOLAR FLARES ARE DISCUSSED IN SOME DETAIL TO SHOW THE NEED FOR PREDICTION. HAZARDS ARE NOTED AS PROTONS, X RAYS, ULTRAVIOLET, AND RADIO INTERFERENCE. SINCE THE FIRST IS POTENTIALLY THE MOST DANGEROUS, SOME DATA ON DOSAGE DURING FLARES IS PRESENTED TO EVALUATE THE HAZARDS. SINCE FLARES OCCUR AT OR NEAR SUNSPOTS, AND SINCE THERE SEEMS TO BE A DIRECT CORRELATION WITH THE CHARACTERISTICS OF SUNSPOTS, SOME DISCUSSION IS GIVEN OF THE DIMENSIONS AND CHARACTERISTICS OF SUNSPOTS. ONE PREDICTION SCHEME IS PRESENTED WHICH INVOLVES THE STATISTICS OF FLARES, AND A SCHEME IS DESCRIBED THAT IS PRESENTLY BEING USED FOR FLARE STUDIES AT THE SPACE SCIENCES LABORATORY.

*AEROSPACE SAFETY + *COSMIC RADIATION + *HAZARDS ANALYSIS + *SURVEY, RADIATION, ENVIRONMENTAL + DOSE + STATISTICAL ANALYSIS

4-09679 BEAL JL + BROWN WR + PLEUTHNER RL + NEWTON JF
AEROSPACE NUCLEAR SAFETY INVESTIGATIONS OF REENTRY ABLATION PHENOMENA. QUARTERLY REPORT, AUGUST 1-OCTOBER 31, 1965
CORNELL AERONAUTICAL LABORATORY, INC., BUFFALO, N. Y.
SC-DC-65-1893 +. 58 PAGES, REFERENCES, OCTOBER 1965, CFSTI, \$3.00 CY, \$0.75 MN

THE SIZE DISTRIBUTION AS DETERMINED BY TARGET IMPACT IS GIVEN FOR DEBRIS PARTICLES FORMED IN A SHOCK-TUNNEL TEST FROM EXCESSIVE-SIZE DROPS OF LIQUID ZIRCONIUM. TESTS OF ZIRCONIUM HYDRIDE UNDER REENTRY CONDITIONS SIMULATED IN THE MACH-6 SECTION OF THE WAVE SUPERHEATER HYPERSONIC TUNNEL ARE DESCRIBED. THE DETERMINATION OF EMISSIVITY DURING AN ABLATION TEST IS REPORTED.

*AEROSPACE SAFETY + *HYDRIDE + *PARTICLE SIZE DISTRIBUTION + *ZIRCONIUM

4-09681 BLUMENTHAL JL + SANTY MJ
AN EXPERIMENTAL INVESTIGATION OF THE BEHAVIOR OF BERYLLIUM IN SIMULATED LAUNCH PAD ABORT ENVIRONMENTS.
FINAL REPORT
TRW SYSTEMS
SC-DC-65-1637 + 213 PAGES, REFERENCES, JULY 30, 1965, CFSTI, \$6.00 CY, \$1.25 MN

THIS REPORT IS THE FINAL PROGRAM REPORT DESCRIBING THE WORK PERFORMED BY TRW SYSTEMS (FORMERLY TRW/SPACE TECHNOLOGY LABORATORIES) FOR THE SANDIA CORPORATION UNDER CONTRACT 62-6211. THE INVESTIGATION WAS STARTED IN ORDER TO ANSWER CRITICAL QUESTIONS CONCERNING THE CHEMICAL BEHAVIOR OF BERYLLIUM METAL EXPOSED TO A LAUNCH PAD ABORT FIRE ENVIRONMENT. IN PARTICULAR, THE TOXIC NATURE OF AIRBORNE BERYLLIUM COMPOUND PARTICLES OR SMOKE MAKES IT ESSENTIAL FROM A SAFETY POINT OF VIEW TO KNOW UNDER WHAT CONDITIONS, IF ANY, IN A LAUNCH-PAD ABORT FIRE, BULK BERYLLIUM METAL COMPONENTS ARE LIKELY TO IGNITE AND BURN TO FORM SMOKE. IN THIS PROGRAM, A COMPREHENSIVE LABORATORY INVESTIGATION OF THE CHEMICAL BEHAVIOR OF BERYLLIUM METAL IN A WIDE RANGE OF SIMULATED LAUNCH ABORT ENVIRONMENTS WAS COMPLETED. EXPERIMENTS WERE CONDUCTED OVER THE SPECTRUM OF POSSIBLE ENVIRONMENTAL CONDITIONS (TEMPERATURE, AND CHEMICAL COMPOSITION OF THE COMBUSTION GASES) WHICH IT WAS BELIEVED COULD OCCUR IN THE EVENT OF A LAUNCH PAD ABORT ACCIDENT INVOLVING PRESENTLY USED PROPELLANT COMBINATIONS.

*AEROSPACE SAFETY + *BERYLLIUM + *CHEMICAL TOXICITY + *FIRE + ACCIDENT ANALYSIS + EXPERIMENT, GENERAL + PYROPHORIC REACTION

4-09682 BEAL JL + BROWN WR + PLEUTHNER RL

ACCESSION NUMBER 4-09577 TO 4-09682

CATEGORY 4
AEROSPACE SAFETY

4-09682 *CONTINUED*
DISPERSAL OF REACTOR CORE MATERIALS BY REENTRY PROCESSES. QUARTERLY REPORT
CORNFIL AERONAUTICAL LABORATORY, INC.
SC-DC-65-1520 +. 45 PAGES, APRIL 1965 (INCLUDES OCTOBER 1964), CFSTI, \$2.00 CY, \$0.50 MN

ZIRCONIUM RODS WERE TESTED UNDER SIMULATED REENTRY CONDITIONS. MELTING PHENOMENA WERE OBSERVED AND DEBRIS FROM RAPIDLY ABLATING RODS WAS COLLECTED. TEMPERATURE RISE RATES OF THE RODS WERE DETERMINED BY SEVERAL METHODS AND COMPARED WITH RATES CALCULATED FOR DIFFERENT INTENSITIES OF OXIDATION HEATING. BASED ON THE TESTS, A METHOD FOR COMPUTING THE OXIDATION HEATING EFFECT IS SUGGESTED.

*AEROSPACE SAFETY + *OXIDATION + *ZIRCONIUM + EXPERIMENT, GENERAL + TEST, DESTRUCTIVE

4-09685 DIECKAMP FM
NUCLEAR SPACE POWER SYSTEMS
ATOMICS INTERNATIONAL
AI-MEMO-7585 (REV. 2) +. 193 PAGES, SEPTEMBER 1964, CFSTI, \$5.00 CY

THE STATE OF THE ART OF NUCLEAR-REACTOR SPACE POWER PLANTS IS REVIEWED. AN INVESTIGATION AND SURVEY IS THEN PRESENTED OF THE REACTOR HEAT SOURCE DESIGN, HEAT REJECTION ASPECTS, SYSTEM DESIGN, AND VEHICLE INTEGRATION. AS EXAMPLES, SNAP 2, 8, AND 10A ARE DISCUSSED IN DETAIL. PRESENTED ALSO ARE GENERAL SAFETY DESIGN CRITERIA THAT HAVE BEEN USED FOR THE SNAP SPACE REACTOR SYSTEMS - (A) SAFETY AND CASE OF HANDLING, (B) PREVENTION OF ACCIDENTAL CRITICALITY, (C) INHERENT SHUTDOWN, (D) ORBITAL STARTUP, (E) ORBITAL SHUTDOWN, AND (F) REENTRY BURNUP. VARIOUS PERIODS (E.G., SHIPMENT, LAUNCH PAD OPERATIONS) DURING WHICH AN ACCIDENT COULD OCCUR AND STEPS TAKEN TO PREVENT THEM ARE DISCUSSED.

*AEROSPACE SAFETY + *SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) +
*SNAP 2 (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *SNAP 8 (SYSTEMS FOR NUCLEAR AUXILIARY POWER) +
ACCIDENT ANALYSIS + DESIGN CRITERIA + REACTOR, SPACE

4-09688 BERRY RE
AEROSPACE SAFETY RESULTS FROM A ROVER/NERVA POST-OPERATIONAL DESTRUCT TEST
SANDIA CORPORATION
SC-R-65-1017 + CONF-651101-54 +. 17 PAGES, AMERICAN NUCLEAR SOCIETY WINTER MEETING, 13TH CONFERENCE ON
REMOTE SYSTEMS TECHNOLOGY, WASHINGTON, D.C., NOVEMBER 15-18, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE DESTRUCTION OF A FULL-SCALE MOCKUP ROVER/NERVA PROPULSION ENGINE WAS PERFORMED UNDER THE DIRECTION OF THE JOINT AEC/NASA SPACE NUCLEAR PROPULSION OFFICE. THE INSTRUMENTATION WAS DEVELOPED AND INSTALLED BY ABERDEEN PROVING GROUND AND SANDIA CORPORATION. THE DATA COLLECTED INCLUDED INFORMATION ABOUT THE DESTRUCT DEBRIS VELOCITY, SIZE, WEIGHT, AND SPATIAL DISTRIBUTION. THESE DATA ARE A SATISFACTORY SOURCE TERM FOR THE COMPUTER ANALYSIS OF THE ROVER/NERVA PROGRAM SAFETY.

*AEROSPACE SAFETY + *NUCLEAR EXPLOSION DEBRIS + *ROVER PROGRAM + *TEST, DESTRUCTIVE + COMPUTER PROGRAM

4-09690 BERRY RE + MARTIN JP
ROVER/NERVA DESTRUCT SYSTEM TEST RESULTS, ABERDEEN PROVING GROUND - 3, FINAL REPORT
SANDIA LABORATORY, ALBUQUERQUE
SC-RR-65-620 +. 258 PAGES, TABLES, DECEMBER, 1965, CFSTI, \$6.00 CY, \$1.25 MN

THE ROVER/NERVA NUCLEAR PROPULSION ENGINE DESTRUCT TEST WAS PERFORMED TO DETERMINE THE DISTRIBUTION, PARTICLE SIZE AND MASS, AND PARTICLE VELOCITY OF THE DEBRIS. THESE DEBRIS DATA ARE THE INPUT DATA FOR A COMPUTER ANALYSIS OF THE SAFETY ASPECTS OF USING THE NERVA REACTOR FOR SPACE FLIGHT. REPORTED IN THIS DOCUMENT ARE THE DEBRIS DISTRIBUTION, SIZE, MASS, AND VELOCITY MEASURED DURING THE TEST. DATA ARE PRESENTED IN TABLES AND GRAPHS.

*AEROSPACE SAFETY + *NUCLEAR EXPLOSION DEBRIS + *ROVER PROGRAM + *TEST, DESTRUCTIVE + PARTICLE SIZE

4-09726 UPTON AC
RADIOBIOLOGICAL ASPECTS OF THE SUPERSONIC TRANSPORT
OAK RIDGE NATIONAL LABORATORY
ORNL-P-1333 + ICRP/65-C1-2/7 +. 59 PAGES, 11 FIGURES, HEALTH PHYSICS, 12(2), PP. 209-226 (FEBRUARY 1966)

THE HIGH CRUISING ALTITUDE OF THE SUPERSONIC TRANSPORT (SST) WILL SUBJECT ITS OCCUPANTS TO LARGER AMOUNTS OF COSMIC RADIATION THAN ARE PRESENT AT SEA LEVEL OR AT ALTITUDES ATTAINED BY ORDINARY COMMERCIAL JET AIRCRAFT. THE PASSENGERS AND CREW OF THE SST WILL BE EXPOSED NOT ONLY TO INCREASED AMOUNTS OF GAMMA RAYS BUT ALSO TO PARTICULATE RADIATIONS. ASSESSMENT OF THE HEALTH IMPLICATIONS OF THE SST MUST, CONSEQUENTLY, TAKE INTO ACCOUNT THE AMOUNT, RELATIVE BIOLOGICAL EFFECTIVENESS, AND PROBABLE EFFECT OF THESE RADIATIONS, AND THE FACTORS AFFECTING THE CUMULATIVE EXPOSURE AND RADIOSENSITIVITY OF THE EXPOSED POPULATION. THE TASK GROUPS APPRAISAL OF THESE QUESTIONS IS SUMMARIZED IN THE FOLLOWING. RADIATION DOSES WHICH MAY BE RECEIVED BY PASSENGERS AND CREW OF THE SST ARE COMPARED WITH THE MAXIMUM PERMISSIBLE DOSES RECOMMENDED BY THE ICRP FOR RADIATION WORKERS AND THE PUBLIC. ALTHOUGH NO ATTEMPT IS MADE IN THIS REPORT TO WEIGH THE POSSIBLE MAGNITUDE OF THE RESULTING RISKS FROM RADIATION IN COMPARISON WITH RISKS OF OTHER TYPES TO OCCUPANTS OF THE SST, THIS IS AN ASPECT OF THE PROBLEM WHICH MAY DESERVE CONSIDERATION IN EVALUATING THE PRACTICAL IMPLICATIONS OF THIS REPORT.

*AEROSPACE SAFETY + *BIOMEDICAL + *DOSE CALCULATION, INTERNAL + DOSE +
ICRP (INT. COMM. ON RADIOLOGICAL PROTECTION) + MAXIMUM PERMISSIBLE DOSE (MPD) + POPULATION EXPOSURE

CATEGORY 4
AEROSPACE SAFETY

4-10261 BLAKE VE
AEROSPACE NUCLEAR SAFETY
SANDIA CORPORATION.

SC-DC-66-1369 + CONF-660305-15 +. 11 PAGES, AMERICAN NUCLEAR SOCIETY TOPICAL MEETING, AUGUSTA, GEORGIA, MARCH 18, 1966, CFSTI, \$1.00 CY, \$0.50 MN

ONE IS CONFRONTED WITH THE VERY DIFFICULT PROBLEM OF TRYING TO COMPARE THE ACCEPTABILITY OF A LOW PROBABILITY OF EXPOSING A SMALL NUMBER OF PEOPLE TO A HIGH LEVEL OF HAZARD, WITH A HIGHER PROBABILITY OF EXPOSING A LARGE NUMBER OF PEOPLE TO A LOW LEVEL OF HAZARD. FROM CURVES, AND THE POPULATION DISTRIBUTION ON THE EARTH, THE CURVE SHOWN IN FIG. 6 WAS DERIVED. IT SHOWS THE RELATION BETWEEN THE NUMBER OF PEOPLE THAT COULD BE KILLED FROM A GIVEN SIZE METEORITE STRIKING THE EARTH, AND THE PROBABILITY OF THAT EVENT HAPPENING. IT SHOWS, FOR EXAMPLE, THAT THE PROBABILITY OF ONE DEATH PER YEAR IS ABOUT ONE IN 300, WHILE THE PROBABILITY OF AS MANY AS EIGHT MILLION PEOPLE BEING KILLED IS ABOUT ONE IN ONE BILLION. IN SPITE OF THE FACT THAT ABOUT TEN METEORITES STRIKE THE EARTH EACH DAY, THERE APPARENTLY HAS NEVER BEEN A DEATH ATTRIBUTED TO A METEORITE. INDIVIDUAL HAZARD IS REMOTE, BEING ABOUT ONE CHANCE IN 10 TO MINUS 11 OF BEING STRUCK IN ANY GIVEN YEAR.

*AEROSPACE SAFETY + POPULATION EXPOSURE

4-11159 LITTLE WW + HARDIE RW
NEUTRONICS CHARACTERISTICS OF SELECTED COMPACT FAST REACTORS
PACIFIC NORTHWEST LABORATORY, BATTELLE NORTHWEST, RICHLAND

BNWL-283 +. 22 PAGES, 14 FIGURES, 6 TABLES, 7 REFERENCES, JULY 1966, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT DESCRIBES THE NEUTRONICS CHARACTERISTICS OF FAST, COMPACT REACTORS FUELED BY TUNGSTEN-CONTAINING CERMETS CONTAINING EITHER U-235 DIOXIDE OR PU-239 MONONITRIDE. THE PRINCIPAL ITEMS STUDIED ARE REACTOR CRITICALITY AND FUEL BURNUP. FOR THE FUEL COMPOSITIONS AND VOID FRACTIONS CONSIDERED, REACTORS FUELED WITH U-233 OR PU-239 REQUIRE CONSIDERABLY LESS FUEL THAN REACTORS FUELED WITH U-235. ALL REACTORS CONSIDERED ARE RATHER INSENSITIVE TO CHANGES IN THE INVENTORY OF REFRACTORY METAL. OF SAFETY INTEREST ARE CHAPTER 3 (REACTIVITY-COEFFICIENT CALCULATIONS) AND CHAPTER 5 (KINETICS CHARACTERISTICS).

*REACTOR, FAST + NITRIDE + PLUTONIUM OXIDE + REACTIVITY COEFFICIENT + REACTOR KINETICS + TUNGSTEN + URANIUM DIOXIDE

4-11404 ROM FE
FAST AND MODERATED LOW-POWER, LIGHTWEIGHT REACTORS FOR NUCLEAR ROCKET PROPULSION
NASA, LEWIS RESEARCH CENTER, CLEVELAND, OHIO

N-65-29480 + NASA-TM-X-52047 +. 75 PAGES, REFERENCES, 1964, CFSTI \$3.00 CY, \$0.75 MN

THE NUCLEAR PROPULSION SCHEME CONSIDERED IS THE DIRECT-HEATING SYSTEM WHERE HYDROGEN, THE PROPELLANT, IS HEATED BY PASSING IT THROUGH A REACTOR CORE MADE OF HIGH-TEMPERATURE MATERIALS. IT IS USED TO COOL THE NOZZLE, REFLECTOR, PRESSURE SHELL, OR ANY OTHER PARTS THAT REQUIRE COOLING BEFORE IT PASSES THROUGH THE REACTOR CORE. THE CORE IS COMPOSED OF AN ARRAY OF FUEL-BEARING HEAT-TRANSFER PASSAGES THAT PERMIT REMOVAL OF THE FISSION ENERGY GENERATED WITHIN THE CORE MATERIALS. THRUST IS PRODUCED BY EXPANDING THE HEATED HYDROGEN THROUGH A CONVERGENT-DIVERGENT NOZZLE. A CONTROL SYSTEM IS PROVIDED TO START, OPERATE, AND SHUT DOWN THE REACTOR.

*NUCLEAR ROCKET + *REACTOR DESCRIPTION + *REACTOR, SPACE

4-11491 SULLIVAN L + BURGIO R + CLEMENZ B
RE-ENTRY ABLATION EVALUATION OF SMALL MOLTEN DROPLETS OF STRONTIUM-90 SPACE FUEL
MARTIN-MARIETTA CORPORATION, BALTIMORE
MND-3062-5 +. 141 PAGES, MAY 1964, CFSTI, \$5.00 CY

THIS IS A STUDY OF THE EFFECTS OF PHYSICAL PROPERTIES OF POSSIBLE NUCLEAR SPACE FUELS ON THE ABLATION OF SMALL MOLTEN DROPLETS OF FUEL ENTERING THE ATMOSPHERE AT HYPERSONIC SPEEDS. THE OBJECTIVE IS TO IDENTIFY THE PHYSICAL PROPERTIES THAT CONTROL THE RATE OF BURNUP OF SMALL MOLTEN DROPLETS AND TO SPECIFY THE APPROXIMATE VALUES OF THESE PHYSICAL PROPERTIES NECESSARY TO PRODUCE A PRESCRIBED TOTAL BURNUP. ABLATION MECHANISMS WERE POSTULATED AND PROGRAMMED FOR THE IBM 7094 COMPUTER. PRELIMINARY RESULTS INDICATE THAT VISCOSITY, SURFACE TENSION, HEAT OF VAPORIZATION, AND BOILING POINT ARE THE DOMINANT PHYSICAL PROPERTIES.

*AEROSPACE SAFETY + *REENTRY, ATMOSPHERIC + *STRONTIUM

4-11492 DAILEY A
ONE-HUNDRED-FOOT DROP TESTS ON SIMULATED SNAP-10A REACTOR VESSELS
ATOMICS INTERNATIONAL, CANOGA PARK, CALIFORNIA
NAA-SR-MEMO-10165 +. 20 PAGES, JULY 9, 1964, CFSTI, \$1.00 CY

THE OBJECTIVE OF THIS TEST WAS TO DETERMINE THE STRUCTURAL DISASSEMBLY CHARACTERISTICS OF THIN-WALL, GROOVED, AND UNGROOVED CYLINDERS UPON IMPACT ON CONCRETE FROM 100 FT. ON MAY 20, 1964, 100-FT DROP TESTS WERE CONDUCTED ON REACTOR-VESSEL TEST SPECIMENS TO DETERMINE G LEVELS EXPERIENCED BY THE UNITS AT CONTACT BUT MORE IMPORTANTLY TO ASCERTAIN THE CHARACTERISTIC AND EXTENT OF STRUCTURAL DAMAGE SUSTAINED.

*SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *TEST, COMPONENT + *TEST, DESTRUCTIVE + REACTOR, SPACE

CATEGORY 4
AEROSPACE SAFETY

4-11493 HANSEL JG + ZWILLENBERG M + MELLOR AM + SULLIVAN HF + GLASSMAN I
FIRST ANNUAL PROGRESS REPORT ON THE COMBUSTION OF METALS, JULY 1, 1964 - JUNE 30, 1965
PRINCETON UNIVERSITY
SC-DC-65-1691 +. 38 PAGES, AUGUST 1965, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT SUMMARIZES RESEARCH CONCERNING METAL COMBUSTION PERFORMED FOR SANDIA CORPORATION IN THE DEPARTMENT OF AEROSPACE AND MECHANICAL SCIENCES AT PRINCETON UNIVERSITY DURING THE PERIOD JULY 1964 THROUGH JUNE 1965. THE COMBUSTION OF RESISTIVELY HEATED METAL WIRES OR STRIPS WAS EXAMINED IN A CONTROLLED-ATMOSPHERE CHAMBER CAPABLE OF OPERATING AT ELEVATED OR REDUCED PRESSURES. METALS THAT BURN PRIMARILY AT THE SURFACE, SUCH AS TANTALUM, MOLYBDENUM, AND ZIRCONIUM, AND METALS THAT BURN PRIMARILY IN THE VAPOR PHASE, SUCH AS CALCIUM AND MAGNESIUM, WERE STUDIED. VARIOUS GASEOUS ATMOSPHERES WERE USED, THE COMPONENTS OF WHICH WERE OXYGEN, NITROGEN, CARBON DIOXIDE, WATER VAPOR, AND ARGON. RESULTS ARE INTERPRETED IN TERMS OF THE GLASSMAN HYPOTHESIS FOR METAL BURNING. PRELIMINARY EXPERIMENTATION ON THE DETERMINATION OF METAL FLAME TEMPERATURES AND OF IGNITION PROCESSES ON A FLAT-FLAME BURNER IS DISCUSSED.

*COMBUSTION + *METAL + AEROSPACE SAFETY + IGNITION

4-11494 BOYLE TJ + PARKER GH + SHAW HK
ANALYSIS OF THE SNAP-10A FSM-4 PRESTARTUP TESTS
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11921 +. 26 PAGES, APRIL 20, 1966, CFSTI \$2.00 CY, \$0.50 MN

THE SNAP 10A FSM-4 PRESTARTUP ORBITAL TESTS WERE EVALUATED BY THERMAL ANALYSIS OF THE DATA. THE EFFECTS OF GRAVITATIONAL FORCES ON THE SIMULATED SPACE CONDITIONS WERE ASSESSED. THE THERMAL PERFORMANCE OF THE EJECTABLE HEAT SHIELD AND ITS THERMAL COUPLING TO THE NAK SYSTEM IS DISCUSSED.

*SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *TEST, PREOPERATIONAL + AEROSPACE SAFETY + NAK (SODIUM POTASSIUM ALLOY) + REACTOR, SPACE

4-11495 OHLENKAMP RM + WADE BR + SEXTON IB
SNAP-10A COMPONENT QUALIFICATION PROGRAM FINAL REPORT
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11914 +. 108 PAGES, REFERENCES, MAY 6, 1966, CFSTI \$4.00 CY, \$0.75 MN

THE SNAP 10A COMPONENT QUALIFICATION TEST PROGRAM WAS SUCCESSFULLY CONDUCTED OVER A THREE-YEAR PERIOD IN CONJUNCTION WITH EXTENSIVE DEVELOPMENT TESTING, PLUS THE QUALIFICATION AND DEMONSTRATION TESTING OF FLIGHT SYSTEMS. DURING THE PAST 1-1/2 YEARS, SUFFICIENT ENDURANCE TESTING HAS BEEN ACCUMULATED TO ENABLE AUTHORITATIVE RELIABILITY PREDICTIONS FOR OPERATING PERIODS OF UP TO 1 YEAR IN ORBIT.

*SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *TEST, COMPONENT + CONTROL SYSTEM + HEAT TRANSFER + REACTOR, SPACE

4-11496 STONE LR
SNAP 10A EXPANSION COMPENSATOR TESTS SIMULATING FS-3 SYSTEM CONDITIONS
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11865 +. 41 PAGES, FIGURES, REFERENCES, MARCH 1, 1966, CFSTI \$2.00 CY, \$0.50 MN

TWO SNAP 10A SECONDARY CONTAINMENT EXPANSION COMPENSATOR UNITS (ECU), S/N 022 AND 023, WERE SUBJECTED TO TEN TEMPERATURE-DEFLECTION CYCLES AND UP TO 100 HOURS OF STEADY-STATE OPERATION AT 775 F TO DETERMINE IF ECUS WHICH HAVE BEEN ON LONG-TERM ENDURANCE OPERATION WOULD WITHSTAND ADDITIONAL OPERATION AT INCREASED TEMPERATURES AND BELLWS DEFLECTIONS.

*SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *TEST, COMPONENT + AEROSPACE SAFETY + REACTOR, SPACE

4-11497 KRANZ IH + ADAMS RJ + PROWETT RH
SNAP-10A ELECTRICALLY ACTUATED BAND RELEASE DEVICE (EABRD) DEVELOPMENT
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11454 +. 67 PAGES, FIGURES, TABLES, REFERENCES, NOVEMBER 24, 1965, CFSTI \$3.00 CY, \$0.75 M

PROBLEM - DEVELOP A COMPACT ELECTRICAL RELEASE ACTUATOR TO PROVIDE FOR POSITIVE SHUTDOWN OF THE SNAP 10A REACTOR BY INITIATING EJECTION OF THE REFLECTORS. DEMONSTRATE THAT THE COMPONENT WILL FUNCTION SATISFACTORILY AFTER EXPOSURE TO CONDITIONS WHICH SIMULATE THE SNAP 10A SPACE MISSION. THIS REPORT DISCUSSES THE CONFIGURATION STUDIES AND MATERIALS EVALUATIONS WHICH LED TO THE FINAL DESIGN. DESIGN-VERIFICATION TESTS WERE PERFORMED TO ESTABLISH CONFIDENCE THAT THE REFERENCE DESIGN EABRD WOULD SUCCESSFULLY MEET THE SNAP 10A QUALIFICATION-TEST REQUIREMENTS. THESE TESTS INCLUDE THE FOLLOWING - (1) FIRING TESTS, (2) TENSILE TESTS, (3) DYNAMIC-LOAD TESTS, (4) THERMAL-VACUUM ENDURANCE TESTS, (5) MAXIMUM NO-FIRE CURRENT TESTS, AND (6) IRRADIATION TESTS. BASED ON THE RESULTS, THE REFERENCE DESIGN EABRD APPEARS TO SATISFY THE SNAP 10A SYSTEM REQUIREMENTS.

*AEROSPACE SAFETY + *SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + REACTOR, SPACE + TESTING

4-11498 POUCHER FW + CRESHO PM + WIMBERLY FC
MERCURY RANKINE PROGRAM SYSTEM TEST EXPERIENCE
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11747 + CONF-651026-8 +. 74 PAGES, FROM 1ST AIAA RANKINE CIRCLE SPACE POWER SYSTEM

ACCESSION NUMBER 4-11493 TO 4-11498

CATEGORY 4
AEROSPACE SAFETY

4-11498 *CONTINUED*
SPECIALISTS CONFERENCE, CLEVELAND, JANUARY 25, 1966, CFSTI \$3.00 CY, \$0.75 MN

CONSIDERABLE TEST EXPERIENCE (OVER 2300 HR) HAS BEEN ACCUMULATED AT ATOMICS INTERNATIONAL IN THE AREA OF COMPLETE MERCURY RANKINE SYSTEMS. THIS TESTING INCLUDED A SPACE-CONFIGURED SYSTEM OPERATING IN A VACUUM CHAMBER, A STRUCTURAL MOCKUP SYSTEM FOR VIBRATION TESTING, AND A SYSTEM DESIGNED TO SIMULATE THE EFFECTS OF ZERO-GRAVITY CONDENSING. EACH OF THESE SYSTEM TESTS HAS CONTRIBUTED SIGNIFICANTLY TOWARD A BETTER UNDERSTANDING OF THE OPERATION OF A MERCURY RANKINE SYSTEM, AND THE COMBINATION OF SYSTEMS DEMONSTRATED THE FEASIBILITY OF GROUND STARTUP, LAUNCH SURVIVAL, SIMULATED ORBITAL STARTUP, AND SIMULATED STEADY-STATE OPERATION IN SPACE. IN THIS PAPER THE BASIC OBJECTIVES AND OVERALL ACCOMPLISHMENTS OF THESE SYSTEMS ARE DISCUSSED, THE EXPERIENCE GAINED IN TEST OPERATIONS IS PRESENTED, AND THE SIGNIFICANT RESULTS ARE SUMMARIZED AND DISCUSSED.

*TEST, SYSTEM OPERABILITY + AEROSPACE SAFETY + TESTING

4-11499 GRAHN D + WRIGHT HL
METHODS IN THE EVALUATION OF RADIATION HAZARDS IN MANNED SPACE FLIGHT
ARGONNE NATIONAL LABORATORY, ARGONNE + LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-DC-6681 + CONF-720-2 +. 14 PAGES, FROM 2ND SYMPOSIUM ON PROTECTION AGAINST RADIATION HAZARDS IN SPACE, GATLINBURG, TENN., OCTOBER 1964, CFSTI \$1.00 CY

HAZARDS IN MANNED SPACE FLIGHT ARE REVIEWED WITH A VIEW TOWARD SETTING NEW STANDARDS IF NECESSARY.

*AEROSPACE SAFETY

4-11500 PERRY JE
ANALOG SIMULATION OF KIWI REACTOR CONTROLS
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-DC-6652 + CONF-797-1 +. 21 PAGES, FROM AMERICAN SOCIETY OF MECHANICAL ENGINEERS, ALBUQUERQUE, NEW MEXICO, OCTOBER 1964, CFSTI \$1.00 CY

THIS PAPER PRESENTS SOME OF THE WAYS IN WHICH AN ANALOG COMPUTER WAS USED IN THE MATHEMATICAL DESIGN OF THE CONTROL SYSTEMS USED TO OPERATE THE KIWI REACTORS OF THE ROVER PROGRAM. THE BASIC VARIABLES TO BE CONTROLLED ARE (1) THE FLOW OF LIQUID HYDROGEN, WHICH IS THE COOLANT AND PROPELLANT OF THE ROCKET ENGINE, AND (2) THE TEMPERATURE TO WHICH THE HYDROGEN IS HEATED BY THE REACTOR POWER. A BRIEF QUALITATIVE DESCRIPTION OF SOME ASPECTS OF THE CONTROL DESIGN PROCESS IS GIVEN, PLUS THE ANALYTICAL DEVELOPMENT OF THE CONTROL SYSTEM RATHER THAN THE PHYSICAL DEVELOPMENT OF THE NEVADA CONTROL APPARATUS ITSELF.

*AEROSPACE SAFETY + *COMPUTER, ANALOG + *CONTROL SYSTEM + *KIWI

4-11501 STUDY OF A NUCLEAR ELECTRIC GENERATOR FOR SPACE
COMMISSARIAT A L ENERGIE ATOMIQUE, PARIS
N-66-14377 + NASA-TT-F-9806 +. 46 PAGES, FIGURES, REFERENCES, FEBRUARY 1965, CFSTI \$2.00 CY, \$0.50 MN

THE POSSIBILITY OF USING NUCLEAR ENERGY TO SUPPLY ELECTRIC POWER TO SPACE VEHICLES LED THE FRENCH ATOMIC ENERGY COMMISSION TO UNDERTAKE A SERIES OF STUDIES. THE PRESENT REPORT IS A SUMMARY OF AN EXPLORATORY STUDY DONE IN 1964.

*AEROSPACE SAFETY + RADIATION PROTECTION, CHEMICAL + REACTOR, SPACE

4-11502 VESELSKY JC
NUCLEAR ENERGY FOR SPACE IN THE USSR
1 PAGE, ATOMWIRTSCHAFT 11(8/9), PAGE 454, AUGUST, SEPTEMBER 1966

IN COMPARING THE ROMASHKA REACTOR WITH THE AMERICAN SNAP-10A SYSTEM, THE MOST STRIKING FACT IS THE LARGE DIFFERENCE IN THE OPERATING TEMPERATURES, WHICH INDICATES THAT THE ROMASHKA REACTOR IS CAPABLE OF DEVELOPMENT IN RESPECT OF ENERGY OUTPUT. WHILE SNAP-10A HAS ALREADY BEEN TESTED ON BOARD A SATELLITE, THE SOVIET ROMASHKA REACTOR WAS BUILT FOR PARAMETER STUDIES IN THE LABORATORY AND IS NOT CAPABLE OF BEING FLOWN.

*REACTOR, SPACE + *SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *UNION OF SOVIET SOCIALIST REPUBLICS

4-11503 REIDER R
KIWI - TNT EXPLOSION
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-3351 +. 11 PAGES, JULY 14, 1965, CFSTI \$1.00 CY, \$0.50 MN

THE EFFECTS OF THE KIWI-TNT EXPLOSION (SO-CALLED) ARE COMPARED WITH THE EFFECTS OF VARIOUS TYPES OF EXPLOSIONS AND APPEAR TO BE MOST SIMILAR TO THOSE OF BLACK POWDER.

*AEROSPACE SAFETY + *EXPLOSION + *KIWI TNT (TRANSIENT NUCLEAR TEST) + ACCIDENT ANALYSIS + ACCIDENT, CONSEQUENCES

4-11504 COX AL + BLANTON RW
STUDY OF RANKINE-CYCLE

CATEGORY 4
AEROSPACE SAFETY

4-11504 *CONTINUED*
BROWN ENGINEERING CO., INC.
N65-16315 + NASA-CR 60553 +. 230 PAGES, REFERENCES, AUGUST 1964, CFSTI \$6.00 CY, \$1.25 MN

THIS REPORT PRESENTS THE RESULTS OF A GENERALIZED STUDY OF RANKINE-CYCLE NUCLEAR POWER SYSTEMS FOR USE IN SPACE VEHICLES. FACTORS ON THE SPECIFIC WEIGHT ARE PRESENTED FOR A NUMBER OF CONFIGURATIONS AND OPERATING FLUIDS. IT IS SHOWN THAT WHEN SHIELDING FOR MANNED VEHICLES IS REQUIRED, THE MINIMUM SPECIFIC WEIGHTS OCCUR AT TEMPERATURE RATIO ACROSS THE TURBINE MUCH LOWER THAN THE 0.75 GENERALLY FOUND FOR UNMANNED SYSTEMS. SUGGESTIONS FOR IMPROVED POWER SYSTEMS ARE INCLUDED.

*AEROSPACE SAFETY

CATEGORY 5
ACCIDENT ANALYSIS

5-08969 HELM JW
EFFECT OF NEUTRON IRRADIATION ON UHTREX GRAPHITE AND CARBON
BATTELLE-NORTHWEST, RICHLAND
BNWL-191 +. 17 PAGES, 3 FIGURES, 5 TABLES, 7 REFERENCES, FEBRUARY 1966, CFSTI, \$1.00 CY, \$0.50 MN

THE DIMENSIONAL STABILITY OF THE GRAPHITE AND CARBON MATERIALS USED IN UHTREX WAS DETERMINED TO NEUTRON EXPOSURES EQUAL TO EXPECTED LIFETIME EXPOSURES, AND THE BEHAVIOR OF THESE MATERIALS WAS COMPARED WITH A CONVENTIONAL NUCLEAR GRAPHITE. IRRADIATIONS WERE CONDUCTED IN THE ETR TO MAXIMUM NEUTRON EXPOSURES OF 7×10 TO THE 20 NV T, E GREATER THAN 0.18 MEV AT SAMPLE TEMPERATURES BETWEEN 900 AND 1800 DEGREES C. AT IRRADIATION TEMPERATURES OF 1000 AND 1800 DEGREES C, CGL GRAPHITE BEHAVES ABOUT THE SAME AS CSF, AND THE LENGTH CHANGES ARE LESS THAN -0.06 PERCENT IN BOTH ORIENTATIONS AT THE MAXIMUM EXPOSURES.

*GRAPHITE + *RADIATION DAMAGE + *RADIATION EFFECT + CARBON + IN PILE LOOP + PROPERTY, PHYSICAL

5-09549 COUGHLIN RW + VON BERG RL
MASS AND HEAT TRANSFER TO DROPS IN A MIXER-SETTLER
CORNELL UNIVERSITY
16 PAGES, 12 FIGURES, 4 TABLES, 26 REFERENCES, CHEMICAL ENGINEERING SCIENCE, 21(1), PP. 3-18 (1966)

REPORTS AN EXPERIMENTAL STUDY OF HEAT AND MASS TRANSFER IN A MIXER-SETTLER. TRANSPORT TOOK PLACE FROM A CONTINUOUS PHASE OF HIGHLY REFINED KEROSENE TO WATER DROPS DISPERSED THEREIN BY A PUMP-MIX IMPELLER. IN THE CASE OF MASS TRANSFER, THE WATER DROPS EXTRACTED 2-ETHYLBUTYRIC ACID FROM THE ORGANIC PHASE. FILM COEFFICIENTS FOR HEAT AND MASS TRANSFER WERE DEVELOPED FROM THE EXPERIMENTAL INFORMATION AND ESTIMATED DROP-LIFETIME AND VELOCITY. THE EXPERIMENTAL VALUES WERE COMPARED WITH THE PREDICTIONS OF SEVERAL THEORIES. IN GENERAL, EXPERIMENTAL RESULTS AGREE BETTER WITH THE MODELS BASED ON EDDY DIFFUSION IN A VIBRATING DROP THAN WITH THOSE MODELS THAT POSTULATE A STAGNANT OR CIRCULATING DROP.

*COMPARISON, THEORY AND EXPERIENCE + *DROPLET + *HEAT TRANSFER CORRELATION + *HEAT TRANSFER EXPERIMENT + *MASS TRANSFER + HEAT TRANSFER

5-09550 SWENSON HS + CARVER JR + KAKARALA CR
HEAT TRANSFER TO SUPERCRITICAL WATER IN SMOOTH-BORE TUBES
THE BABCOCK AND WILCOX COMPANY, ALLIANCE, OHIO
8 PAGES, 10 FIGURES, 22 REFERENCES, JOURNAL OF HEAT TRANSFER, 84(4), PP. 477-484, SERIES C (NOVEMBER 1965), TRANSACTIONS OF THE ASME

LOCAL FORCED CONVECTION HEAT-TRANSFER COEFFICIENTS FOR SUPERCRITICAL WATER FLOWING INSIDE SMOOTH-BORE TUBES WERE OBTAINED EXPERIMENTALLY OVER A RANGE OF PRESSURES (3300 TO 6000 PSIA) AND BULK TEMPERATURES (167 TO 1068 F). BECAUSE THE THERMOPHYSICAL PROPERTIES OF SUPERCRITICAL FLUIDS CHANGE RAPIDLY WITH TEMPERATURE IN THE PSEUDOCRITICAL RANGE, CONVENTIONAL FORCED-CONVECTION CORRELATIONS WERE UNABLE TO FIT THE DATA. HOWEVER, A SATISFACTORY CORRELATION FOR FULLY DEVELOPED TURBULENT FLOW WAS OBTAINED BY PROPERLY MODIFYING THE CONVENTIONAL NONDIMENSIONAL MODEL TO ACCOUNT FOR THE PHYSICAL-PROPERTY VARIATION ACROSS THE BOUNDARY LAYER. OUT OF 2951 DATA POINTS, 95 PERCENT LIE WITHIN PLUS OR MINUS 15 PERCENT OF THE CORRELATION.

*HEAT TRANSFER + *HEAT TRANSFER CORRELATION + *HEAT TRANSFER EXPERIMENT + *HEAT TRANSFER, CONVECTION + FLOW, TUBE + HEAT TRANSFER ANALYSIS

5-09551 JACKSON TW + PURDY KR
RESONANT PULSATING FLOW AND CONVECTIVE HEAT TRANSFER
GEORGIA INSTITUTE OF TECHNOLOGY + PURDUE UNIVERSITY
6 PAGES, 6 FIGURES, 17 REFERENCES, JOURNAL OF HEAT TRANSFER, 84(4), PP. 507-512, SERIES C (NOVEMBER 1965), TRANSACTIONS OF THE ASME

THE RESULTS OF EXPERIMENTS ON THE BEHAVIOR OF A SIMPLE CONVECTIVE HEAT EXCHANGER SUBJECTED TO A RESONANT PULSATING FLOW ARE DESCRIBED. A 3.86-IN.-ID , HORIZONTAL, ISOTHERMAL TUBE, 10 FT LONG, THROUGH WHICH AIR WAS BLOWN AT REYNOLDS NUMBERS RANGING FROM 2000 TO $200,000$, WAS USED AS THE HEAT EXCHANGER. BOTH THE THERMAL AND THE HYDRODYNAMIC BOUNDARY LAYERS STARTED AT THE SAME POSITION IN THE APPARATUS. LOCAL HEAT-TRANSFER COEFFICIENTS WERE OBTAINED EXPERIMENTALLY AND COMPARED WITH EQUATIONS DERIVED, USING A SUPERPOSITION TECHNIQUE, FOR BOTH THE LAMINAR AND TURBULENT REGIMES.

*FLOW, PULSATING + *FLOW, TUBE + *HEAT TRANSFER + *HEAT TRANSFER AUGMENTATION + *HEAT TRANSFER, CONVECTION + FLOW, AXIAL + HEAT TRANSFER ANALYSIS + HEAT TRANSFER EXPERIMENT

5-09552 DE BRUIN C + DE HEER CD + DEKKER NH
METHOD TO PREDICT THE MASS FLOW DENSITY DISTRIBUTION THROUGH A WATER-COOLED REACTOR CORE
REACTOR CENTRUM NEDERLAND, THE HAGUE
EUR-2547.E +. 56 PAGES, REFERENCES, 1965, DEP. MN

REPORT PRESENTS A METHOD FOR PREDICTING THE MASS FLOW DENSITY DISTRIBUTION THROUGH A WATER-COOLED REACTOR CORE. THE METHOD BASICALLY DEPENDS ON TWO ASSUMPTIONS. NO INTERACTION BETWEEN THE VARIOUS CHANNELS IN THE REACTOR CORE, THEREFORE CROSS-MIXING IS NEGLECTED. EACH CHANNEL HAS THE SAME AXIAL POWER DISTRIBUTION.

*FLOW THEORY AND EXPERIMENTS + *FLOW, TUBE + *HYDRODYNAMIC ANALYSIS + FLOW STABILITY + FLOW, AXIAL +

CATEGORY 5
ACCIDENT ANALYSIS

5-09552 *CONTINUED*
FUEL ELEMENT + HEAT TRANSFER

5-09553 BHATTACHARYYA A
HEAT TRANSFER ANALOGIES
AKTIEBOLAGET ATOMENERGI, STOCKHOLM, SWEDEN
AE-201 + 66 PAGES, NOVEMBER, 1965, DEP. MN

THIS REPORT CONTAINS DESCRIPTIONS OF VARIOUS ANALOGUES USED TO STUDY STEADY-STATE AND UNSTEADY-STATE HEAT TRANSFER PROBLEMS. THE ANALOGUES COVERED ARE AS FOLLOWS - 1. HYDRAULIC. (A) WATER FLOW, (B) AIR FLOW. 2. MEMBRANE. 3. GEOMETRIC ELECTRICAL. (A) ELECTROLYTIC-TANK, (B) CONDUCTING SHEET. 4. NETWORK. (A) RESISTANCE, (B) R-C. A COMPARISON OF THE ANALOGUES IS PRESENTED IN THE FORM OF A TABLE. THE BIBLIOGRAPHY CONTAINS 81 REFERENCES.

*HEAT TRANSFER + *HEAT TRANSFER CORRELATION + FLOW THEORY AND EXPERIMENTS + HEAT TRANSFER ANALYSIS + HYDRODYNAMIC ANALYSIS

5-09554 GINIER R + LEDUC J
INTERPRETATION OF THERMAL SHOCK TESTS ON THE RAPSDIE ENGINEERING MOCK-UP
COMMISSARIAT A L ENERGIE ATOMIQUE, CADARACHE, FRANCE + CENTRE D ETUDES NUCLEAIRES, SACLAY
ORNI-TR-986 + PNR/SEPR/65.013 +. 91 PAGES, MARCH 29, 1965, JCL, \$8.60 FS, \$2.93 MF

CONTAINS RESULTS OBTAINED BY SODIUM THERMAL-SHOCK TESTS, DONE ON THE ENGINEERING MOCKUP OF RAPSDIE. THE ANALYSIS OF THE THERMOCOUPLES AND THE STRAIN GAGES ALLOWED US TO CHECK THE VALIDITY OF THE THERMAL SHIELDING ADOPTED FOR THE REACTOR, TO DETERMINE THE NA BEHAVIOR AS REGARDS ITS FLOW AND SHOCK ABSORBING PROPERTIES, TO DETERMINE, AT LEAST APPROXIMATELY, THE OVERALL STRESSES WHICH THE VESSEL AND THE TUBES ARE SUBJECTED TO DURING A THERMAL SHOCK, THE ORIGIN OF THESE STRESSES, AND THE APPROPRIATE MODIFICATIONS OF THE REACTOR DESIGN.

*STRESS + *THERMAL MECHANICAL EFFECT + SHIELDING + SODIUM + STRESS ANALYSIS + THERMAL EXPERIMENT

5-09555 GOUSE SW + COUMOU KC
HEAT TRANSFER AND FLUID FLOW INSIDE A HORIZONTAL TUBE EVAPORATOR - PHASE I
MASSACHUSETTS INSTITUTE OF TECHNOLOGY + GENERAL ATOMIC, DIVISION OF GENERAL DYNAMICS CORP.
9 PAGES, 9 FIGURES, 1 TABLE, 18 REFERENCES, ASHRAE TRANSACTIONS, AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR CONDITIONING ENGINEERS, INC., PORTLAND MEETING, JULY 5-7, 1965, SOURCE, \$1.00

IT IS RECOGNIZED THAT AN EXPRESSION FOR THE LOCAL HEAT-TRANSFER COEFFICIENT ALONG AN EVAPORATOR TUBE SHOULD INCLUDE THE LOCAL MIXTURE QUALITY, OR, WHAT IS MORE SIGNIFICANT AT LOW QUALITIES FROM A HYDRODYNAMIC POINT OF VIEW, THE LOCAL VOID FRACTION. THE LOCAL VOID FRACTION IS ESPECIALLY SIGNIFICANT IF NONEQUILIBRIUM FLOW CONDITIONS ARE INVOLVED. THE CHOICE OF AN ANALYTICAL MODEL UPON WHICH TO BASE A HEAT-TRANSFER CORRELATION IS SERIOUSLY COMPLICATED BY THE PRESENCE OF VARIOUS TWO-PHASE FLOW PATTERNS, EACH OF WHICH SUGGESTS A DIFFERENT MODEL.

*FLOW THEORY AND EXPERIMENTS + *FLOW, TUBE + *FLOW, TWO PHASE + *HEAT TRANSFER + *HEAT TRANSFER, BOILING + HEAT TRANSFER ANALYSIS + HEAT TRANSFER EXPERIMENT

5-09556 COLLICOTT HE + FONTAINE WE + GROSH RJ
FREE CONVECTION AND RADIATION HEAT TRANSFER FROM CYLINDRICAL FINNS
BENDIX SYSTEMS DIVISION, ANN ARBOR, MICHIGAN + THE RAY W. HERRICK LABORATORIES + PURDUE UNIVERSITY
4 PAGES, 7 FIGURES, 5 REFERENCES, ASHRAE TRANSACTIONS, AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR CONDITIONING ENGINEERS, INC., PORTLAND MEETING, JULY 5-7, 1965, SOURCE, \$1.00

THIS INVESTIGATION CONCERNS A CYLINDRICAL FIN PROTRUDING FROM A CONSTANT-TEMPERATURE SOURCE INTO A CONSTANT-TEMPERATURE ENVIRONMENT. THIS ENVIRONMENT MAY BE EITHER THE AIR FOR CONVECTION PURPOSES, OR SURROUNDING SURFACES FOR RADIATION. THE CYLINDER HAS NO HEAT TRANSFER FROM ITS FREE END. A THERMALLY SIMILAR ARRANGEMENT IS A CYLINDER OF TWICE THE LENGTH SUSPENDED BETWEEN TWO EQUAL SOURCES. THE PURPOSE OF THIS STUDY IS TO EXTEND THE THEORETICAL EQUATIONS TO ACCOUNT FOR A VARIABLE HEAT-TRANSFER COEFFICIENT, AS WELL AS TO INCLUDE THE PRESENCE OF RADIATION HEAT TRANSFER FROM THE CYLINDER.

*HEAT TRANSFER + *HEAT TRANSFER AUGMENTATION + *HEAT TRANSFER, CONVECTION + *HEAT TRANSFER, NATURAL CONVECTION + *HEAT TRANSFER, RADIANT + HEAT TRANSFER ANALYSIS

5-09557 BANCROFT AR + CHARLESWORTH DH + DUERKSEN JH
IMPURITY EFFECTS IN THE FOULING OF HEAT TRANSFER SURFACES BY ORGANIC COOLANTS
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO
AECL-1913 +. 1964, AECL, \$1.50

RESULTS OF SMALL LOOP TESTS SHOWED THAT CHLORINE IS BY FAR THE STRONGEST FACTOR IN FOULING, ALTHOUGH SMALL EFFECTS WERE OBSERVED DUE TO RADIOLYSIS PRODUCTS, WATER, AND OXYGEN. A 1000-HOUR OUT-OF-PILE TEST SHOWED THAT A DEPOSITION RATE OF 0.2 MICROGRAM PER CU. CM PER HR CAUSED AN INCREASE OF 25 C/YEAR IN THE SHEATH TEMPERATURE OF ELEMENTS RATED AT 100 W/SQ.CM. IN-PILE TESTS SHOWED THAT, WITH CONTINUOUS COOLANT PURIFICATION AND EXCLUSION OF CHLORINE, ETC., FOULING UNDER POWER-REACTOR CONDITIONS CAN BE RESTRICTED TO ACCEPTABLE RATES.

*COOLANT CHEMISTRY + *FILM, GENERAL + *FUEL ELEMENT + *HEAT TRANSFER + *SURFACE, GENERAL + CHLORINE + OMRE (ORGANIC MODERATED REACTOR EXPERIMENT) + REACTOR, ORGANIC COOLED

CATEGORY 5
ACCIDENT ANALYSIS

5-09589 HEAT TRANSFER DEVICE
BELGIAN PAT. 656,515 +. ABSTRACT ONLY, DECEMBER 2, 1964, PATENT (FOREIGN)

THIS IS A DEVICE ALLOWING LARGE AMOUNTS OF HEAT TRANSFER OVER LONG DISTANCES WITH A VERY SMALL TEMPERATURE DROP ALONG ITS LENGTH, THE DEVICE BEING A CONTAINER ENCLOSING A CONDENSABLE VAPOR AND CAPILLARY MEANS ON THE INNER SURFACE OF THE CONTAINER, SAID CAPILLARY MEANS CAPABLE OF CAUSING THE TRANSPORT OF THE CONDENSED VAPOR FROM A COOLER AREA OF THE CONTAINER TO A HOTTER AREA.

*HEAT TRANSFER + *HEAT TRANSFER AUGMENTATION + HEAT EXCHANGER + HEAT TRANSFER, BOILING + THERMODYNAMICS

5-09626 PEI DC
HEAT TRANSFER FROM SPHERES UNDER COMBINED FORCED AND NATURAL CONVECTION
UNIVERSITY OF WATERLOO
7 PAGES, 10 FIGURES, 13 REFERENCES, PP 57-63 OF HEAT TRANSFER - CLEVELAND, (CHEMICAL ENGINEERING PROGRESS SYMPOSIUM SERIES 59(61) 1965), AMERICAN INSTITUTE OF CHEMICAL ENGINEERS, SOURCE, \$15.00 CY

HEAT TRANSFER FROM SPHERES UNDER COMBINED FORCED AND NATURAL CONVECTION WAS STUDIED. THE RESULTS WERE CORRELATED AND COMPARED FAVORABLY WITH THE THEORETICAL PREDICTIONS. THE PARAMETER Gr/Re^2 WAS FOUND TO BE OF FUNDAMENTAL IMPORTANCE, AND THE TRANSITION FROM PREDOMINANTLY FORCED TO PREDOMINANTLY NATURAL CONVECTION WAS GRADUAL.

*HEAT TRANSFER ANALYSIS + *HEAT TRANSFER EXPERIMENT + *HEAT TRANSFER, CONVECTION + *SPHERE + COMPARISON, THEORY AND EXPERIENCE + HEAT TRANSFER

5-09627 STEIN RP
HEAT TRANSFER COEFFICIENTS IN LIQUID METAL CONCURRENT FLOW DOUBLE PIPE HEAT EXCHANGERS
ARGONNE NATIONAL LABORATORY
12 PAGES, 8 FIGURES, 9 REFERENCES, PP 64-75 OF HEAT TRANSFER - CLEVELAND, (CHEMICAL ENGINEERING PROGRESS SYMPOSIUM SERIES 59(61) 1965), AMERICAN INSTITUTE OF CHEMICAL ENGINEERS, SOURCE, \$15.00 CY

AN ANALYTICAL STUDY OF LIQUID-METAL HEAT TRANSFER IN CONCURRENT-FLOW HEAT EXCHANGERS IS DESCRIBED. THE ANALYSIS IS BASED ON PLUG-FLOW MODELS OF THE FLUIDS, WITH AN APPROXIMATION METHOD ALLOWING APPLICATION TO TURBULENT FLOWS AND IS APPLIED TO THE PREDICTION OF FULLY DEVELOPED LIQUID-METAL HEAT-TRANSFER COEFFICIENTS. THE RESULTS SUGGEST THE POSSIBILITY THAT INCONSISTENT VALUES OF HEAT-TRANSFER COEFFICIENTS FREQUENTLY OBTAINED FROM EXPERIMENTS WITH DOUBLE-PIPE HEAT EXCHANGERS ARE ACTUALLY A PREDICTABLE EFFECT OF OPERATING CONDITIONS.

*HEAT TRANSFER ANALYSIS + *METAL, LIQUID + ANNULUS + HEAT EXCHANGER + HEAT TRANSFER + HEAT TRANSFER CORRELATION + HEAT TRANSFER, CONVECTION

5-09639 FAUSKE HK
THE DISCHARGE OF SATURATED WATER THROUGH TUBES
ARGONNE NATIONAL LABORATORY, ARGONNE
7 PAGES, 2 FIGURES, 2 TABLES, PP 210-216 OF HEAT TRANSFER - CLEVELAND (CHEMICAL ENGINEERING PROGRESS SYMPOSIUM SERIES 59(61) 1965), AMERICAN INSTITUTE OF CHEMICAL ENGINEERING, SOURCE

A NEW HIGH-PRESSURE FACILITY DESIGNED FOR MEASURING DISCHARGE RATES OF WATER FROM VARIOUS TUBE CONFIGURATIONS UP TO 2000 LB/SQ. IN. IS BRIEFLY DESCRIBED. DATA ARE REPORTED ON DISCHARGE RATES OF SATURATED WATER FROM TUBES OF LENGTH-TO-DIAMETER (L/D) RATIO FROM 0 TO 40, WITH INITIAL PRESSURE UP TO 2000 LB/SQ. IN. PRESSURE PROFILES IN THE TUBES WERE MEASURED FOR VARIOUS UPSTREAM CONDITIONS, AND THE CRITICAL PRESSURE RATIO WAS DETERMINED AS A FUNCTION OF L/D RATIO AND FOUND INDEPENDENT OF INITIAL CONDITIONS.

*FLOW, TUBE + *FLOW, TWO PHASE + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + LOSS OF FLOW

5-09686 WOOD RE
THE 630A HIGH PERFORMANCE MERCHANT SHIP NUCLEAR STEAM GENERATOR
GENERAL ELECTRIC COMPANY, ADVANCED TECHNOLOGY SERVICE
TM-64-8-14 + CONF-640810-1 +. 43 PAGES, CONFERENCE ON NUCLEAR MARINE PROPULSION, VIRGINIA POLYTECHNIC INSTITUTE, BLACKSBURG, VIRGINIA, AUGUST 10-13, 1964, CFSTI, \$2.00 CY

THE SAFETY ASPECTS OF A GAS-COOLED SYSTEM, SUCH AS THE 630A, ARE INHERENTLY DIFFERENT IN MANY RESPECTS FROM THOSE OF THE MORE FAMILIAR WATER-COOLED SYSTEMS. THE BASIC 630A DESIGN PROVIDES A NUMBER OF UNIQUE SAFETY-RELATED FEATURES. IN THE PRESENT RESEARCH AND DEVELOPMENT PHASE, A CONCERTED EFFORT IS BEING MADE TO ACHIEVE A FINAL DESIGN FEATURING MAXIMUM SAFETY AND RELIABILITY WHILE RETAINING THE OPTIMUM BALANCE BETWEEN PERFORMANCE, OPERABILITY, WEIGHT, AND ECONOMICS. THE APPROACH COMBINES CAREFUL CONSIDERATION OF CURRENT INDUSTRY PRACTICE AND DESIGN STANDARDS, WHEREVER THE MORE CONVENTIONAL SAFETY ASPECTS ARE CONCERNED, WITH EXPLOITATION OF THE TYPICAL INHERENT AND CONFIGURATIONAL FEATURES. RESULTS TO DATE ARE HIGHLY PROMISING, ALL INDICATIONS BEING THAT AN UNPRECEDENTED DEGREE OF BUILT-IN SAFETY CAN BE REALIZED IN THE FINAL 630A DESIGN.

*ACCIDENT ANALYSIS + *REACTOR, GAS COOLED + *REACTOR, MARITIME + *630 A (MARITIME REACTOR) + DECAY HEAT + ECONOMICS + REACTIVITY EFFECT + REACTOR DESCRIPTION + REACTOR TRANSIENT

5-09687 630A MARK V MARITIME NUCLEAR STEAM GENERATOR STATUS REPORT. ROUGH DRAFT
GENERAL ELECTRIC, ADVANCED TECHNOLOGY SERVICES
GEMP-342 +. 231 PAGES, FEBRUARY 26, 1965, CFSTI, \$6.00 CY

CATEGORY 5
ACCIDENT ANALYSIS

5-09687 *CONTINUED*

INCLUDED IN THIS REPORT ARE DETAILED DESCRIPTIONS OF 630A, PRESSURE VESSEL, CONTAINMENT, ACCESSORIES, AND A SAFETY ANALYSIS INCLUDING THE REFERENCE ACCIDENT AND A REFUELING ACCIDENT. APPENDED ARE SPECIFICATIONS AND OPERATING CONDITIONS, AND OPERATING AND SAFETY PARAMETERS AND ACTIONS.

*ACCIDENT ANALYSIS + *ACCIDENT, REFUELING + *CONTAINMENT, GENERAL + *MAINTENANCE AND REPAIR + *REACTOR, MARITIME + *WASTE HANDLING + *630 A (MARITIME REACTOR) + ACCIDENT, CONSEQUENCES + ACCIDENT, CONTROL ROD WITHDRAWAL + CONTAINMENT LEAKAGE CONTROL + CONTAINMENT, PRESSURE VESSEL + EXCURSION, LARGE + LOSS OF COOLANT + LOSS OF FLOW + OPERATIONS REPORTS, GENERAL + REACTOR DESCRIPTION + REACTOR, GAS COOLED

5-09778 HEAT TRANSFER AND FLUID FLOW CHARACTERISTICS IN A PRESSURIZED WATER REACTOR. QUARTERLY PROGRESS REPORT NO. 5, JANUARY 1-APRIL 1, 1965
TECHNISCHE HOGESCHOOL, EINDHOVEN, NETHERLANDS
EURAC-1487 + EUR-2654 + WW-015 R67 +. 20 PAGES, SEPTEMBER, 1965, CFSTI, \$1.00 CY, \$0.50 MN

IN THIS QUARTER, THE FIRST EXPERIMENTS WERE STARTED IN THE 140-ATMOSPHERES PRESSURIZED WATER LOOP. THESE EXPERIMENTS ARE THE FIRST OF AN INTRODUCTORY PROGRAM ON MIXING. THE INFLUENCE OF A COLD WALL AND OF MIXING BETWEEN THE FUEL CHANNEL AND A SURROUNDING CHANNEL ON THE BURN-OUT POWER WILL BE MEASURED. A PROPOSAL IS BEING MADE FOR OTHER TEST SECTIONS FOR ESTABLISHING THE MIXING EFFECTS BETWEEN SUBCHANNELS IN A MORE FUNDAMENTAL WAY BY MAKING MASS AND HEAT BALANCES IN SEPARATE CHANNELS.

*HEAT TRANSFER, CONVECTION + FLOW, AXIAL + FUEL ELEMENT + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + PRESSURIZER + WATER, GENERAL

5-09779 TRANSITION BOILING HEAT TRANSFER PROGRAM. ELEVENTH QUARTERLY PROGRESS REPORT, JULY-SEPTEMBER 1965
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
GEAP-4963 + EURAC-1525 +. 29 PAGES, OCTOBER 1, 1965, CFSTI, \$2.00 CY, \$0.75 MN

HEAT TRANSFER DATA HAVE BEEN OBTAINED WITH THE NEW THREE-ROD ASSEMBLY AT 60 TEST CONDITIONS. TWO DIFFERENT SMOOTH ROD GEOMETRIES WERE TESTED. RESULTS WERE OBTAINED WITH ONE GEOMETRY AT THREE PRESSURES AND THREE MASS VELOCITIES. THE CRITICAL HEAT FLUX WAS FOUND TO OCCUR ON THE PART OF THE HEATED RODS FACING OTHER HEATED SURFACES BEFORE SPREADING TO AREAS FACING THE UNHEATED CHANNEL. PARTIAL HEAT TRANSFER RESULTS ARE PRESENTED WHICH SHOW TRENDS SIMILAR TO THE ONE-ROD DATA. FULLY DEVELOPED FILM BOILING COEFFICIENTS FOR SEVERAL FLOW CONDITIONS ARE PRESENTED. THE DESIGN OF A THREE-ROD OBSERVATIONAL TEST SECTION HAS BEEN COMPLETED AND FABRICATION IS UNDERWAY.

*HEAT TRANSFER, BOILING + CONVECTIVE BOILING + FLOW, AXIAL + FUEL ELEMENT + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT

5-09814 REACTOR VESSEL CLAD PENETRATION AND HYDROGEN EMBRITTLEMENT
DIVISION OF REACTOR LICENSING, USAEC
2 PAGES, APRIL 18, 1966, DOCKET 50-29, ATOMIC ENERGY CLEARING HOUSE, 12(17), PP. 19-20 (APRIL 25, 1966)

DRL (IN REPLY TO YANKEE EVALUATION OF CLAD PENETRATION) BELIEVES THAT EVIDENCE NOT SUFFICIENT TO ESTABLISH THAT A302B VESSEL IS NOT SUSCEPTIBLE TO HYDROGEN EMBRITTLEMENT IN CONTACT WITH WATER, AND REQUESTS ADDITIONAL INFORMATION. ALSO REQUESTS VESSEL NDT PREDICTIONS BASED ON RECENT SURVEILLANCE-SPECIMEN MEASUREMENTS. ENCLOSURE PROVIDES JUSTIFICATION FOR CONCERN.

*BRITTLE FRACTURE + *CONTAINMENT, PRESSURE VESSEL + *HYDROGEN + OPERATING EXPERIENCE + REACTOR, PRESSURIZED WATER + YANKEE

5-09843 ROGERS JT + BARNS GM
DNB HEAT FLUXES IN AN ANNULAR TEST SECTION FOR A TERPHENYL COOLANT CONTAINING 30 PERCENT HIGH BOILERS
CANADIAN GENERAL ELECTRIC COMPANY, LTD.
R63CAP6/ +. 62 PAGES, JUNE 1965, DEP.MN

DNB HEAT FLUXES UNDER FORCED-CONVECTION, SUBCOOLED BOILING CONDITIONS HAVE BEEN MEASURED IN VERTICAL ANNULI FOR A COOLANT CONSISTING ESSENTIALLY OF A TERPHENYL MIXTURE WITH ABOUT 30 PERCENT HIGH BOILERS. A SUMMARY OF OTHER DATA ON SUBCOOLED, FORCED-CONVECTION DNB HEAT FLUXES FOR TERPHENYL COOLANTS IS GIVEN, AND A COMPARISON MADE WITH THE RESULTS OBTAINED IN THIS INVESTIGATION. A RECOMMENDED CORRELATION, FOR USE IN SIMPLE FLOW GEOMETRIES ONLY, IS PRESENTED.

*CONVECTIVE BOILING + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *HEAT TRANSFER, BOILING + *ORGANIC COOLANT + HEAT TRANSFER + HEAT TRANSFER CORRELATION + HEAT TRANSFER EXPERIMENT

5-09917 GROZIN BD + CHEPNEKOV VS
POSSIBILITY OF STRENGTHENING STEEL BY ELECTRON BOMBARDMENT
JPRS-32107 + TT-65-32600 +. 7 PAGES, SEPTEMBER 22, 1965, TRANSLATED FROM DOPOVIDI AKADEMIYI NAUK UKRAYINSKOYI RSR, (2), PAGES 202-5 (1963), CFSTI, \$1.00 CY, \$0.50 MN

THEORETICAL CONSIDERATIONS PERMIT THE POSSIBILITY OF STRENGTHENING STEEL BY ELECTRON BOMBARDMENT. EXPERIMENTS HAVE CONFIRMED THE CORRECTNESS OF THIS PREMISE. THE HARDNESS OF STEEL IS RAISED TO 900-950 KG/MM SQUARED BY ELECTRON BOMBARDMENT. THE IRRADIATED ZONE HAS A SPECIFIC MICROSTRUCTURE.

ACCESSION NUMBER 5-09687 TO 5-09917

CATEGORY 5
ACCIDENT ANALYSIS

5-09917 *CONTINUED*

*RADIATION EFFECT + *STEEL + *TENSILE PROPERTY + ALLOY + CREEP PROPERTY + RADIATION DAMAGE + X-RAY

5-09918 SMITH BE

AN X-RAY STUDY OF FISSION FRAGMENT DAMAGE IN STEELS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

5 PAGES, 4 TABLES, 1 FIGURE, 11 REFERENCES, JOURNAL OF NUCLEAR MATERIALS, 17(1), PAGES 167-171 (1965)

LATTICE-PARAMETER MEASUREMENTS WERE MADE ON STEELS BOMBARDED WITH FISSION FRAGMENTS AT ABOUT 60 C. THE RESULTS FOR ONE AUSTENITIC STEEL (CR, 20 WT PERCENT, NI, 20 WT PERCENT, NB, 0.44 WT PERCENT) ARE DISCUSSED IN CONJUNCTION WITH PUBLISHED RESULTS OBTAINED BY ELECTRON MICROSCOPY AND ARE CONSIDERED CONSISTENT WITH THE HYPOTHESIS THAT THE PROPORTION OF SMALL DEFECTS IN THIS STEEL IS GREATEST WHEN IRRADIATION DOSE RATES ARE HIGH. IN TWO OTHER AUSTENITIC STEELS (CR, 18 WT PERCENT, NI, 37 WT PERCENT) AND (CR, 18 WT PERCENT, NI, 12 WT PERCENT) AND A FERRITIC STEEL (CR, 15 WT PERCENT, NI, 5 WT PERCENT), A MEASURABLE PROPORTION OF SMALL DEFECTS WAS PRESENT AFTER IRRADIATION AT A DOSE RATE INTERMEDIATE BETWEEN THE TWO USED FOR THE 20/20 AUSTENITE.

*ALLOY + *RADIATION DAMAGE + *STEEL + ELECTRON MICROSCOPY + RADIATION EFFECT + X-RAY

5-09919 BROTHERS AJ + NEWHOUSE DL + WUNDT BM

RESULTS OF BURSTING TESTS OF ALLOY STEEL DISKS AND THEIR APPLICATION TO DESIGN AGAINST BRITTLE FRACTURE

GENERAL ELECTRIC COMPANY, SCHENECTADY, NEW YORK

18 PAGES, 11 FIGURES, 3 TABLES, 13 REFERENCES, ASTM 68TH ANNUAL MEETING, LAFAYETTE, INDIANA, JUNE 13-18, 1965, SOURCE

REPORT PRESENTS THE RESULTS OF BURST TESTS OF NOTCHED AND NITRIDED ALLOY STEEL DISKS AND PROPOSES A DESIGN PROCEDURE AGAINST BRITTLE FRACTURE, USING THE RESULTS OF THESE TESTS.

*ALLOY + *BRITTLE FRACTURE + *NITRIDE + *STEEL + *TESTING + PROCEDURES AND MANUALS + TEST, DESTRUCTIVE

5-09920 COWAN A

METALLURGICAL TESTING AT CULCHETH

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, REACTOR MATERIALS LABORATORY, CULCHETH

4 PAGES, 3 FIGURES, ATOM(112), PAGES 33-36 (FEBRUARY, 1966)

A LARGE PROPORTION OF THE WORK AT THE REACTOR MATERIALS LABORATORY IS METALLURGICAL, AND EXTENSIVE FACILITIES HAVE BEEN DEVELOPED TO ALLOW FULL-SCALE INVESTIGATIONS OF THE BEHAVIOUR OF METALS RANGING IN SECTION FROM THIN FOIL TO THICK STEEL PLATES. IN ADDITION TO CONVENTIONAL TESTS, EQUIPMENT HAS BEEN DEvised TO GIVE BETTER SIMULATION OF ACTUAL SERVICE CONDITIONS, ESPECIALLY WHERE APPLICATION OF NORMAL TEST DATA IS INADEQUATE OR EVEN UNREALISTIC. IN SEVERAL CASES THIS INCLUDED TESTS ON EITHER THE FULL-SIZE COMPONENT OR LARGE SAMPLES, NECESSARY TO BE REASONABLY REPRESENTATIVE OF THE FINAL PRODUCT. CREEP TESTING. BRITTLE FRACTURE TESTS. TESTS ON MODEL VESSELS. POSTIRRADIATION TESTING FACILITIES. OTHER FACILITIES.

*EQUIPMENT DESIGN + *METAL + *TESTING + BRITTLE FRACTURE + CORROSION + CREEP PROPERTY + IMPACT PROPERTY + RADIATION EFFECT + TENSILE PROPERTY + TEST, PRESSURE VESSEL

5-09921 JABLONOWSKI EJ + RITZMAN RL + DEMAISTRY JA

FISSION-FRAGMENT EFFECTS IN STRUCTURAL MATERIALS. QUARTERLY PROGRESS REPORT, JULY-SEPTEMBER 1965

BATTELLE MEMORIAL INSTITUTE

BMI-X-10146 + EURAEC-1527 +. 7 PAGES, OCTOBER 1, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE OBJECTIVE OF THIS PROGRAM IS TO DETERMINE THE TYPE AND MAGNITUDE OF MECHANICAL-PROPERTY CHANGES PRODUCED ANNEALED AISI TYPE 304 STAINLESS STEEL AND ANNEALED ZIRCALOY-2 BY FISSION-FRAGMENT IRRADIATIONS. TESTING OF TUBE-BURST AND BEND SPECIMENS OF RECOIL-IMPREGNATED ZIRCALOY-2 AND TYPE 304 STAINLESS STEEL WAS COMPLETED. NOMINAL INCREASES OF 8 TO 10 PERCENT IN AVERAGE PROPORTIONAL LIMIT AND YIELD-STRENGTH VALUES OF FISSION-FRAGMENT-DAMAGED OVER NEUTRON-DAMAGED MATERIALS WERE NOTED FROM BOTH THE BEND AND TUBE-BURST DATA. LIGHT AND ELECTRON METALLOGRAPHIC ANALYSES OF THE RECOIL-IMPREGNATED MATERIALS WERE COMPLETED. NO STRUCTURAL CHANGES WERE NOTED AS THE RESULT OF FISSION-FRAGMENT OR NEUTRON DAMAGE. FRACTURE ANALYSIS OF RUPTURES PRODUCED IN THE TUBE-BURST EXPERIMENTS INDICATED NO CHANGE IN FRACTURE MODE (DUCTILE) AS A RESULT OF FISSION-FRAGMENT IRRADIATION. THE MAXIMUM RADIATION-INDUCED TENSILE AND COMPRESSIVE STRESSES IN ZIRCALOY-2 AND TYPE 304 STAINLESS STEEL WERE CALCULATED ON THE BASIS OF EXPERIMENTALLY DETERMINED VALUES OF RADIATION EXPANSION COEFFICIENTS AND FISSION-FRAGMENT CONCENTRATIONS. ALTHOUGH CALCULATED TENSILE STRESSES WERE NOMINAL, COMPRESSIVE STRESSES OF 14,300 PSI (STAINLESS STEEL) AND 42,400 PSI (ZIRCALOY-2) WERE OBTAINED.

*RADIATION DAMAGE + *STEEL, STAINLESS + *TENSILE PROPERTY + ALLOY + ELECTRON MICROSCOPY + FAILURE, PIPE + TESTING + ZIRCONIUM

5-09952 RABENAU A

CHEMICAL TRANSPORT REACTIONS

AACHEN LABORATORY OF PHILIPS ZENTRALLABORATORIUM GMBH.

3 PAGES, 4 FIGURES, PHILLIPS TECHNICAL REVIEW, 26(4-6), PAGES 117-119 (1965)

THIS PAPER IS A DISCUSSION OF THE CHEMICAL-TRANSPORT REACTIONS BY WHICH A CONDENSED PHASE MAY BE TRANSFERRED THROUGH A GAS PHASE BY MEANS OF A CHEMICAL REACTION IN WHICH GASES OR VAPORS

ACCESSION NUMBER 5-09917 TO 5-09952

CATEGORY 5
ACCIDENT ANALYSIS

5-09952 *CONTINUED*
ARE INVOLVED.

*CHEMICAL REACTION + *MASS TRANSFER + CHEMICAL EQUILIBRIUM + CHEMICAL KINETICS + METAL

5-09959 ALBAUGH FW
BATTELLE-NORTHWEST STUDIES EXECUTED FOR THE USAEC-AECL COOPERATIVE PROGRAM. MONTHLY PROGRESS REPORT,
NOVEMBER 1965
BATTELLE-NORTHWEST
TID-22426 +. 7 PAGES, DECEMBER 6, 1965, CFSTI, \$1.00 CY, \$0.50 MN

BATTELLE-NORTHWEST PROGRESS REPORT, NOVEMBER, 1965. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. NO FURTHER REPORTS ON THE SERIES WILL BE SUMMARIZED UNLESS A SIGNIFICANT CHANGE ON THE PROGRAM OR A SIGNIFICANT ITEM OF INTEREST TO NSIC IS REPORTED. TOPICS COVERED IN THIS REPORT ARE (1) CROSS-FLOW MIXING BETWEEN PARALLEL FLOW CHANNELS DURING BOILING, (2) PARALLEL-CHANNEL REACTOR, (3) BOILING-STABILITY STUDY, (4) IN-REACTOR MEASUREMENT OF CREEP IN ZR-NB ALLOY, (5) ZR-NB PRESSURE TUBING, (6) EVALUATION OF CORROSION OF ZIRCONIUM ALLOYS IN THE REACTOR.

*CORROSION + *CREEP BEHAVIOR + *FLOW DISTRIBUTION + *FLOW, TWO PHASE + FLOW THEORY AND EXPERIMENTS + HEAT TRANSFER, BOILING + NIOBIUM + ZIRCONIUM

5-09965 CASTAGNA M + COLOMBO RL + FERRO A + ROSSI FS + SZABO G
ON THE EFFECT OF NITROGEN INTERSTITIALS ON THE RADIATION EMBRITTLEMENT OF PURE IRON. TECHNICAL REPORT NO. 3
SORIN - CENTRO RICERCHE NUCLEARI, SALUGGIA (VERCELLI) + FIAT - SEZIONE ENERGIA NUCLEARE, TORINO + ISTITUTO ELETTROTECNICO NAZIONALE GALILEO FERRARIS, TORINO
EURAE-1347 + EUR-2322 +. 37 PAGES, 1965, CFSTI, \$2.00 CY, \$1.00 MN

IN VIEW OF THE PRESENT INTEREST ON THE RADIATION EMBRITTLEMENT OF STEELS, SOME PRELIMINARY EXPERIMENTS WERE PERFORMED TO IMPROVE THE KNOWLEDGE OF THE INFLUENCE OF NITROGEN PRESENT IN COMBINED OR FREE SOLUTION IN THE FERRITIC STEELS USED FOR NUCLEAR PRESSURE VESSELS. EXPERIMENTS WERE PERFORMED ON TWO IRON MATERIALS. ONE WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED NITRIDED IRON IN A NITROGEN ATMOSPHERE AND SILICON AS A DEOXIDIZER, SO THAT THE FINAL NITROGEN CONTENT WAS ABOUT 0.02 PERCENT. THE OTHER, USED FOR REFERENCE, WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED 0.25 PERCENT TITANIUM, WITH THE PURPOSE, BESIDES DEOXIDATION, OF REMOVING ALL THE NITROGEN AND CARBON INTERSTITIALS, WHICH PRECIPITATE AS TITANIUM NITRIDES AND CARBIDES. THIS MATERIAL SHOWS NO ACENIC AT ALL AND HAS NO SHARP YIELD POINT. THE TRANSITION TEMPERATURE FOR NITROGEN-CONTAINING IRON WAS ABOUT 0 DEGREE C PRIOR TO IRRADIATION AND ABOUT 160 DEGREES C AFTER IRRADIATION, WHILE IN INTERSTITIAL-FREE IRON IT SHIFTED FROM MINUS 60 DEGREES TO 0 DEGREE C.

*EMBRITTLEMENT + *IMPACT PROPERTY + *IRON + *NITROGEN + *RADIATION DAMAGE + BRITTLE FRACTURE + NITRIDE + TESTING

5-09966 RUBEL H + DEBRAY W + ROSLER U
HYDROGEN PICK-UP AND EMBRITTLEMENT OF ZIRCALOY-2 ZRNB 1 AND ZRNB 2.5
SIEMENS-SCHUCKERTWERKE AG, ERLANGEN, GERMANY
EURAE-901 + EUR-1501.0 +. 33 PAGES, 1965, REPRINT FROM NUKLEONIK 6(4), (1964), CFSTI, \$3.60 FS, \$1.19 MF

NEXT TO THE BEHAVIOR TOWARD OXIDATION, IT IS MAINLY THE EMBRITTLEMENT SUBSEQUENT TO HYDROGEN PICKUP THAT SETS A LIMIT TO THE SUITABILITY AND LIFETIME OF ZIRCONIUM ALLOYS IN WATER-COOLED OR STEAM-COOLED NUCLEAR REACTORS. WITH THE ZIRCALOY-2 AND ZIRCALOY-4 AMERICAN STANDARD ZIRCONIUM ALLOYS FOR WATER-COOLED REACTORS, THE MAXIMUM OPERATING TEMPERATURE IS TO BE TAKEN AS ABOUT 350 C. THE OBJECT OF THE PRESENT INVESTIGATION IS TO CONTRIBUTE TO KNOWLEDGE ABOUT THE HYDROGEN PICKUP AND THE CONSEQUENT CHANGES IN THE MECHANICAL PROPERTIES IN CONNECTION WITH THE ZR-NB 1 AND ZR-NB 2.5 ALLOYS WITH RESPECT TO ZIRCALOY-2 TAKEN AS STANDARD OF COMPARISON.

*ALLOY + *EMBRITTLEMENT + *HYDROGEN + *NIOBIUM + *ZIRCALOY + *ZIRCONIUM + BRITTLE FRACTURE

5-09996 MERRIAM RL
AN INVESTIGATION OF LIQUID-METAL HEAT TRANSFER IN A COCURRENT-FLOW, DOUBLE-PIPE, HEAT EXCHANGER
ARGONNE NATIONAL LABORATORY
ANL-7056 +. 121 PAGES, 16 TABLES, 57 FIGURES, 69 REFERENCES, JUNE, 1965, CFSTI, \$4.00 CY, \$0.75 MN

THE CONSTRUCTION OF A MERCURY HEAT-TRANSFER LOOP AND EXPERIMENTS WITH COCURRENT-FLOW, DOUBLE-PIPE, HEAT-EXCHANGER TEST SECTIONS IS DESCRIBED, INCLUDING APPLICATION OF A NEW EXPERIMENTAL TECHNIQUE TO OBTAIN VALUES OF FULLY-DEVELOPED HEAT-TRANSFER COEFFICIENTS. THE EXPERIMENTAL RESULTS SHOWED AGREEMENT WITH THE ANALYSIS. IT IS SHOWN THAT - (1) HEAT-TRANSFER COEFFICIENTS DEPEND UPON THE OPERATING CONDITIONS OF THE HEAT EXCHANGER, AND THEIR VALUES CAN BE SIGNIFICANTLY LOWER THAN THOSE CORRESPONDING TO A UNIFORM-SURFACE-TEMPERATURE BOUNDARY CONDITION, (2) USE OF THE CUSTOMARY DESIGN EQUATION TO PREDICT HEAT-EXCHANGER PERFORMANCE CAN LEAD TO SIGNIFICANT ERRORS.

*ANNULUS + *HEAT EXCHANGER + *HEAT TRANSFER CORRELATION + *METAL, LIQUID + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER EXPERIMENT

5-10005 BAILEY RE
THE EFFECTS OF THE MOLECULAR DIFFUSION OF HEAT ON FLUID VELOCITY MEASUREMENTS ACCOMPLISHED BY THERMOCOUPLE

CATEGORY 5
ACCIDENT ANALYSIS

5-10005 *CONTINUED*

CROSS-CORRELATION
ATOMICS INTERNATIONAL

NAA-SR-MEMO-10848 +. 25 PAGES, FIGURES, MARCH 28, 1965, CFSTI \$2.00 CY, \$0.50 MN

AN ATTEMPT HAS BEEN MADE TO FIND A MINIMUM VELOCITY FOR FLUIDS, WITH LOW PRANDTL NUMBER, ABOVE WHICH CROSS CORRELATION TECHNIQUES BETWEEN THERMOCOUPLES, ONE DOWNSTREAM FROM THE OTHER, CAN BE USED TO MEASURE THE TRANSIT TIME OF AN EDDY OF FLUID BETWEEN THE TWO THERMOCOUPLES. IN THIS STUDY, A POINT SOURCE OF HEAT IN AN INFINITE MEDIUM WAS USED TO REPRESENT AN EDDY OF FLUID. THE CRITERIA USED TO FIND THE MINIMUM VELOCITY WAS THAT THE EDDY OF FLUID MUST PASS BETWEEN THE THERMOCOUPLES MUCH MORE QUICKLY THAN THE MAXIMUM OF A THERMAL WAVE GENERATED BY A POINT SOURCE LOCATED AT THE UPSTREAM THERMOCOUPLE.

HEAT CONDUCTION + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER, CONVECTION +
INSTRUMENTATION, GENERAL + INSTRUMENTATION, TEMPERATURE

5-10174 COTTRELL WB

ORNL NUCLEAR SAFETY RESEARCH AND DEVELOPMENT PROGRAM BIMONTHLY REPORT FOR MARCH - APRIL 1966
OAK RIDGE NATIONAL LABORATORY
ORNL-CF-66-5-20 +. 45 PAGES, MAY 2, 1966, SOURCE

ORNL PROGRESS IN THE USAEC REACTOR SAFETY PROGRAM DURING THE MONTHS OF MARCH AND APRIL ARE SUMMARIZED. INCLUDED IS WORK ON VARIOUS CHEMICAL REACTIONS, THE RELEASE, CHARACTERIZATION, AND TRANSPORT OF FISSION PRODUCTS IN CONTAINMENT SYSTEMS UNDER VARIOUS ACCIDENT CONDITIONS, AND PROBLEMS ASSOCIATED WITH THE REMOVAL OF THESE FISSION PRODUCTS FROM GAS STREAMS. WHILE THESE STUDIES PROVIDE INFORMATION ON THE CONSEQUENCE OF POTENTIAL REACTOR ACCIDENTS AND THUS HAVE DIRECT RELEVANCE TO THE EVALUATION OF REACTOR SITES, A SEPARATE STUDY IS BEING UNDERTAKEN ON THE SAFETY AND FEASIBILITY OF THE OFF-SHORE SITING OF POWER REACTORS. ALTHOUGH MOST OF THE WORK HAS BEEN AND CONTINUES TO BE IN GENERAL SUPPORT OF WATER POWER REACTOR TECHNOLOGY, INCLUDING SOME IN DIRECT SUPPORT OF THE LOFT AND CSE PROGRAMS, SEVERAL NEW PROJECTS WERE INITIATED THE FIRST OF THE YEAR IN SUPPORT OF THE HIGH-TEMPERATURE GAS-COOLED REACTOR (HTGR) PROGRAM. THESE NEW PROJECTS INCLUDE BOTH IN-PILE AND OUT-PILE STUDIES OF REACTION RATES AND FISSION-PRODUCT RELEASE AND TRANSPORT PHENOMENA RELEVANT TO POTENTIAL HTGR ACCIDENT SITUATIONS. TWO NEW PROJECTS, INITIATED DURING THE REPORT PERIOD, INCLUDE STUDIES ON PRESSURE-VESSEL TECHNOLOGY AND THE INITIATION OF A SERIES OF DISCUSSION PAPERS ON VARIOUS ASPECTS OF WATER REACTOR TECHNOLOGY. RECENT ACTIVITIES OF THE NSIC AND THE NUCLEAR SAFETY JOURNAL IN BEHALF OF THE NUCLEAR COMMUNITY ARE ALSO DISCUSSED.

*FISSION PRODUCT RELEASE, GENERAL + *FISSION PRODUCT TRANSPORT + *FISSION PRODUCT, IODINE +
*LOFT (LOSS OF FLUID TEST) + *NSIC (NUCLEAR SAFETY INFORMATION CENTER) +
*NSPP (NUCLEAR SAFETY PILOT PLANT) + *TREAT (TRANSIENT TEST REACTOR FACILITY) + CHARCOAL +
CHEMICAL KINETICS + CONTAINMENT, PRESSURE VESSEL + FILTER + FILTER, COMBINATION + FILTER, MAY PACK +
GRAPHITE + IN PILE EXPERIMENT + IN PILE LOOP + ORGANIC IODIDE + OUT OF PILE LOOPS AND EXPERIMENTS +
PARTICULATE + REACTOR, GRAPHITE MODERATED + REACTOR, PRESSURIZED WATER + REACTOR, TEST + STEAM +
STRESS ANALYSIS

5-10207 HOLTZ RE

HEATING TECHNIQUES FOR LIQUID METAL LOOPS
ARGONNE NATIONAL LABORATORYANL-7100 + CONF 650946 +. 23 PAGES, 8 FIGURES, 6 REFERENCES, PP. 9-22 OF PROCEEDINGS OF THE CONFERENCE ON
APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965,
CFSTI, \$6.75 CY \$2.75 MN

PROBLEM - HOW TO HEAT LIQUID-METAL LOOPS AT HIGH TEMPERATURES (2100 F) AND HIGH HEAT FLUXES (1,000,000 BTU/HR-FT²). METHODS OF APPROACH - A VARIETY OF POSSIBLE METHODS WERE EXAMINED, AND THERMAL-RADIATION HEATING AND ELECTRON BOMBARDMENT APPEAR MOST PROMISING. CONCLUSION - USE (1) TANTALUM ELEMENTS FOR THERMAL RADIATION HEATING, (2) TUNGSTEN AND THORIATED TUNGSTEN ELECTRODES FOR ELECTRON-BOMBARDMENT HEATING.

*HEAT TRANSFER EXPERIMENT + *METAL, LIQUID + HEAT EXCHANGER + HEAT TRANSFER + HEAT TRANSFER, RADIANT

5-10208 BOND JA + PETERSON JR + TIPPETS FE

HEAT TRANSFER AND PRESSURE DROP MEASUREMENTS FOR HIGH TEMPERATURE BOILING POTASSIUM IN FORCED CONVECTION
GENERAL ELECTRIC COMPANY, CINCINNATI, OHIO
ANL-7100 + CONF-650946 +. 43 PAGES, 17 FIGURES, 19 REFERENCES, PP. 53-96 OF PROCEEDINGS OF THE CONFERENCE
ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965,
CFSTI, \$6.75 CY, \$2.75 MN

INSTRUMENTATION AND MEASUREMENT TECHNIQUES USED FOR EXPERIMENTS WITH FORCED-CONVECTION BOILING POTASSIUM IN A SODIUM-HEATED HAYNES-25 ALLOY-TEST FACILITY AT POTASSIUM TEMPERATURES TO 1750 F AND IN A RADIANT-HEATED CB-12R FACILITY AT TEMPERATURES TO 2100 F ARE DESCRIBED. SOME OF THE HEAT-TRANSFER AND PRESSURE-DROP RESULTS OBTAINED ARE PRESENTED. THE HEAT-TRANSFER DATA PRESENTED INCLUDE MEASUREMENTS OF HEAT TRANSFER COEFFICIENTS IN THE NUCLEATE-BOILING AND TRANSITION-BOILING REGIMES, AND MEASUREMENTS OF ONSET OF CRITICAL-HEAT-FLUX CONDITIONS.

*HEAT TRANSFER, BOILING + *INSTRUMENTATION, GENERAL + *METAL, LIQUID + *POTASSIUM + HEAT TRANSFER +
HEAT TRANSFER CORRELATION + HEAT TRANSFER EXPERIMENT + HYDRAULIC EXPERIMENT

5-10209 SAWOCHKA SG

MEASUREMENTS OF FORCED CONVECTION CONDENSING POTASSIUM HEAT TRANSFER
GENERAL ELECTRIC COMPANY, CINCINNATI, OHIO

ANL-7100 + CONF-650946 +. 30 PAGES, 13 FIGURES, 25 REFERENCES, PP. 97-126 OF PROCEEDINGS OF THE CONFERENCE

CATEGORY 5
ACCIDENT ANALYSIS

5-10209 *CONTINUED*
ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965,
CFSTI, \$6.75 CY, \$2.75 MN

A DISCUSSION OF TEMPERATURE AND FLOW RATE MEASURING TECHNIQUES, WHICH HAVE ALLOWED THE DETERMINATION OF HEAT TRANSFER AND PRESSURE CHANGE DATA FOR THE FORCED CONVECTION CONDENSATION OF POTASSIUM, IS PRESENTED. INTERCALIBRATION OF THE CONDENSING TEST SECTION THERMOCOUPLES IS DISCUSSED, AND REPRESENTATIVE TUBE WALL RADIAL TEMPERATURE PROFILES AND POTASSIUM AXIAL TEMPERATURE PROFILES ARE PRESENTED. THE HEAT TRANSFER RESULTS FOR THE 5/8-IN. ID TUBE WITH HELICAL AND TUBULAR INSTRUMENTED INSERTS ARE PRESENTED. THESE DATA ARE CONSIDERED THE MOST RELIABLE OF THE DATA OBTAINED FOR THE FIVE TEST-SECTION CONFIGURATIONS SINCE THE INSTRUMENTED INSERTS PROVIDED A MEANS OF MEASURING THE LOCAL POTASSIUM-SATURATION TEMPERATURES. THE DATA ARE GENERALLY LOWER THAN THOSE PREDICTED BY THE NUSSELT THEORY. THIS IS THOUGHT TO BE DUE TO THE PRESENCE OF A THERMAL RESISTANCE BETWEEN THE VAPOR AND LIQUID PHASES. THESE DATA WERE OBTAINED AT INLET VELOCITIES FROM 100 TO 1700 FT/SEC, AT TEMPERATURES FROM 900 TO 1400 F, HEAT FLUXES FROM 30,000 TO 300,000 BTU/HR-FT², AND CONDENSER LOADS FROM 5 TO 35 KW THERMAL.

*CONDENSATION + *HEAT TRANSFER, BOILING + *INSTRUMENTATION, GENERAL + *METAL, LIQUID + *POTASSIUM + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + HEAT TRANSFER, CONVECTION

5-10210 CASSANO AJ + ENGDAHL RE
PRESSURE TRANSDUCER FOR LIQUID METAL APPLICATIONS
CONSOLIDATED CONTROLS CORPORATION, BETHEL, CONNECTICUT
ANL-7100 + CONF-650946 +. 21 PAGES, 6 FIGURES, 7 REFERENCES, PP. 165-186 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN.

DEVELOPMENT OF A PRESSURE TRANSDUCER FOR USE IN FLOW LOOPS FOR LIQUID-METALS LOOPS POSES MANY DESIGN PROBLEMS DEMANDING THE BEST FROM MATERIALS. THE PROGRAM TO BE DISCUSSED INCLUDES THE DEVELOPMENT OF A PRESSURE TRANSDUCER PROVIDING ACCURATE MEASUREMENTS IN THE LIQUID, VAPOR, AND TWO-PHASE STREAMS OF A POTASSIUM LOOP OPERATING UP TO 1800 F. IN ADDITION TO POTASSIUM, THE TRANSDUCER MAY ALSO FIND USE IN LOOPS CONTAINING SODIUM, LITHIUM, CESIUM OR RUBIDIUM. THE TRANSDUCER EMPLOYS A THERMIONIC DIODE SENSOR TO CONVERT THE MOTION OF A PRESSURE-ACTUATED REFRACTORY-ALLOY CAPSULE INTO A SUITABLE ELECTRICAL OUTPUT.

*INSTRUMENTATION, GENERAL + *METAL, LIQUID + *POTASSIUM + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + PRESSURE, INTERNAL

5-10211 WENTZ LB + NEAL LG + WRIGHI RW
X-RAY MEASUREMENT OF VOID DYNAMICS IN BOILING LIQUID METALS
TRW SYSTEMS, REDONDO BEACH, CALIFORNIA
ANL-7100 + CONF-650946 +. 20 PAGES, 6 FIGURES, 10 REFERENCES, PP. 195-215 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

PROBLEM - TO OBTAIN A MEASUREMENT SYSTEM CAPABLE OF PREASSURING VOID BEHAVIOUR OF BOILING LIQUID METAL, WITH RESPONSE TIME OF ONE MILLISECOND WITHOUT AFFECTING THE BOILING BEHAVIOUR. SOLUTION - X-RAY ATTENUATION. RESULTS - AN EXPERIMENT WITH BOILING POTASSIUM DEMONSTRATED THE TECHNIQUE. VOIDING TIMES OF A FEW MILLISECONDS WERE OBSERVED. CONCLUSIONS - WITH GOOD EQUIPMENT AND FREQUENT CALIBRATION, MEASUREMENTS IN ONE MILLISECOND WITH 3 PERCENT UNCERTAINTY ARE POSSIBLE. SPACE AND TIME RESOLUTION ARE LIMITED BY THE X-RAY INTENSITY AVAILABLE.

*HEAT TRANSFER, BOILING + *INSTRUMENTATION, GENERAL + *METAL, LIQUID + *POTASSIUM + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT

5-10212 BALZHISER RE + SMITH LR
INSTRUMENTATION FOR TWO PHASE METALLIC FLOWS
UNIVERSITY OF MICHIGAN
ANL-7100 + CONF-650946 +. 28 PAGES, 10 FIGURES, 2 TABLES, 15 REFERENCES, PP. 217-245 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

INSTRUMENTATION FOR MEASURING PRESSURE DROP AND VOID FRACTIONS IN TWO-PHASE METALLIC FLOWS IS DISCUSSED. A TAYLOR DIFFERENTIAL PRESSURE GAGE MEASURED PRESSURE DROP OVER A 36-IN. LENGTH OF HORIZONTAL 0.495-IN. TUBING. VOID FRACTIONS WERE DETERMINED AT THE CENTER OF THIS SECTION BY USING RADIATION-ATTENUATION TECHNIQUES. A THULIUM-170 SOURCE WAS USED TO PROVIDE A 0.084-MEV GAMMA RAY FOR MEASUREMENT PURPOSES. A THALLIUM-ACTIVATED NaI CRYSTAL WAS USED TO DETECT THE VERY NEARLY MONOENERGETIC BEAM. PROBLEMS IN ALIGNMENT AT LOOP TEMPERATURES ARE CITED AS WELL AS THE IMPORTANCE OF TEMPERATURE CONTROL OF THE SCINTILLATOR. THE RANGE OF APPLICABILITY FOR SUCH MEASUREMENTS AND RESULTS OBTAINED WILL BE DISCUSSED.

*FLOW, TWO PHASE + *METAL, LIQUID + *POTASSIUM + HYDRAULIC EXPERIMENT + INSTRUMENTATION, GENERAL + PRESSURE, INTERNAL

5-10213 FERRELL JK + MCGEE JW
AN ACCURATE ONE-SHOT GAMMA ATTENUATION TECHNIQUE FOR MEASURING VOID FRACTIONS
NORTH CAROLINA STATE UNIVERSITY
ANL-7100 + CONF-650946 +. 22 PAGES, 5 TABLES, 9 FIGURES, PP. 247-269 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

CATEGORY 5
ACCIDENT ANALYSIS

5-10213 *CONTINUED*

THE OBJECTIVE OF THE INVESTIGATION REPORTED UPON HERE WAS TO IMPROVE THE ACCURACY OF THE ONE-SHOT TECHNIQUE FOR MEASURING LOCAL VOID VOLUME FRACTIONS OF TWO-PHASE FLUIDS IN SMALL FLOW CHANNELS BY ELIMINATING THE DEPENDENCE OF THE MEASUREMENTS ON THE VOID DISTRIBUTION IN THE FLOW CHANNEL. THE ACCURATE DETERMINATION OF THE LOCAL VOLUMETRIC VAPOR FRACTION OF VAPOR-LIQUID MIXTURES IS ESSENTIAL TO AN UNDERSTANDING OF THE FLUID MECHANICS OF TWO-PHASE FLOW. TWO TECHNIQUES EMPLOYING GAMMA-RAY ATTENUATION ARE FREQUENTLY USED. ONE TECHNIQUE IS TO TRAVERSE THE FLOW CHANNEL WITH A THINLY COLLIMATED GAMMA BEAM. WITH THE OTHER, THE ONE-SHOT METHOD, THE GAMMA RAYS ARE COLLIMATED SO THAT THE ENTIRE CROSS SECTION OF THE FLOW CHANNEL IS VIEWED BY THE GAMMA BEAM AT ONE TIME. THE ONE-SHOT METHOD IS SIMPLE AND FAST, BUT THE VOID FRACTIONS DETERMINED MAY BE A FUNCTION OF THE VOID DISTRIBUTION.

*FLOW, TWO PHASE + *HEAT TRANSFER, BOILING + *INSTRUMENTATION, GENERAL + *METAL, LIQUID +
HEAT TRANSFER EXPERIMENT + HYDRAULIC EXPERIMENT

5-10214 TAUSON P + AMMON RL
DEVELOPMENT OF ALKALI METAL QUALITY METER
ASTRONUCLEAR LABORATORY, WESTINGHOUSE RESEARCH CORPORATION
ANL-7100 + CONF-650946 +. 15 PAGES, 5 FIGURES, PP. 272-287 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

THE MEASUREMENT OF THE QUALITY OF ALKALI METAL VAPOR INVOLVES TWO MAJOR GOALS - (1) COLLECTION OF A REPRESENTATIVE SAMPLE, AND (2) MEASUREMENT OF THE SAMPLE QUALITY. THE FIRST IS A STUDY IN ITSELF BECAUSE OF THE TENDENCY OF ALKALI-METAL LIQUIDS TO ADHERE TO THE WALLS. THE SECOND IS THE ANALYSIS OF THE QUALITY OF VAPOR OF A COLLECTED SAMPLE. THIS PAPER WILL DEAL PRIMARILY WITH THE SECOND GOAL. THE METHOD USED IS TO MEASURE THE AMOUNT OF ENERGY REQUIRED TO DRY THE SAMPLE AND COMPARE IT WITH THE AMOUNT OF ENERGY REQUIRED TO SUPERHEAT IT TO A PRESET AMOUNT OF SUPERHEAT ΔT . THE ACTUAL FORM OF THE EQUATION IS SOMEWHAT COMPLEX DUE TO THERMAL AND FLOW CHARACTERISTICS, HOWEVER, AN INSTRUMENT CAN BE CONSTRUCTED TO PROVIDE THE MEASUREMENTS OF QUALITY. THIS TECHNIQUE IS NOW BEING DEVELOPED BY WESTINGHOUSE ASTRONUCLEAR LABORATORY.

*FLOW, TWO PHASE + *HEAT TRANSFER, BOILING + *INSTRUMENTATION, GENERAL + *METAL, LIQUID + *POTASSIUM +
HEAT TRANSFER + HEAT TRANSFER EXPERIMENT

5-10215 EDWARDS JA + HOFFMAN HW
SUPERHEAT WITH BOILING ALKALI METALS
OAK RIDGE NATIONAL LABORATORY
ANL-7100 + CONF 650946 +. 20 PAGES, 9 FIGURES, 6 REFERENCES, PP. 515-534 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

RESULTS OF EXPERIMENTS IN A NATURAL-CIRCULATION LOOP TO ESTABLISH THE MAGNITUDE OF THE SUPERHEAT ASSOCIATED WITH ALKALI-METAL BOILING SHOW THAT POTASSIUM BOILING ON AN AS-RECEIVED (COMMERCIALY SMOOTH) SURFACE, THE SUPERHEAT MEASURED RANGED FROM 500 F AT A SATURATION TEMPERATURE OF 1500 F DOWN TO 230 F AT T-SUB-SAT EQUALS 1770 F. WALL-TEMPERATURE OSCILLATIONS, WHICH OCCUR IN THE PRESENCE OF THESE LARGE SUPERHEATS BECAUSE OF THE UNUSUAL THERMAL PROPERTIES OF THE LIQUID METALS, WERE IN THE RANGE OF 170 TO 300 F AT A FREQUENCY OF 1.5 CPM. BECAUSE OF MAXIMUM SURFACE-TEMPERATURE LIMITATIONS, SODIUM COULD NOT BE BOILED ON THIS SURFACE. SIGNIFICANT REDUCTIONS IN THE MAGNITUDE OF THE SUPERHEAT FOR K AND NA AND HENCE IN THE AMPLITUDE OF THE WALL TEMPERATURE OSCILLATIONS WERE EFFECTED BY MODIFYING THE SURFACE OF THE BOILER. OVER THE LIMITED RANGE OF THESE EXPERIMENTS, THE SUPERHEAT DATA FOR POTASSIUM AND SODIUM CORRELATE REASONABLY WITH PREDICTIONS BASED ON A MODEL FEATURING A SPHERICAL VAPOR BUBBLE IN THERMAL EQUILIBRIUM WITHIN A LIQUID POOL OF UNIFORM TEMPERATURE.

*COMPARISON, THEORY AND EXPERIENCE + *HEAT TRANSFER, BOILING + *METAL, ALKALI + *METAL, LIQUID +
HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + SURFACE, GENERAL

5-10216 WICHNER RP + HOFFMAN HW
PRESSURE DROP WITH FORCED-CONVECTION BOILING OF POTASSIUM
OAK RIDGE NATIONAL LABORATORY
ANL-7100 + CONF-650946 +. 12 PAGES, 4 FIGURES, 1 TABLE, 7 REFERENCES, PP. 535-547 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

THE RESULTS ARE GIVEN FOR THE PRESSURE DROP WITH BOILING POTASSIUM IN FORCED-CONVECTION FLOW THROUGH A VERTICAL, CIRCULAR TUBE. THE DATA, WHICH COMPRISE A SINGLE SERIES OF MEASUREMENTS (SERIES D), WERE OBTAINED IN A 6-FT-LONG BY 0.270-IN.-ID TUBE HAVING PRESSURE TAPS AT 1-FT SPACINGS OVER THE FINAL 4 FT OF THE CHANNEL. THE PRESSURE-MEASUREMENT SYSTEM AND ITS DEFICIENCIES ARE DISCUSSED. THE PRIMARY DIFFICULTY APPEARS TO BE AGING OF THE DIAPHRAGMS IN THE PRESSURE TRANSMITTERS OVER LONG EXPOSURE TIMES AT HIGH TEMPERATURES. THE PRESSURE DISTRIBUTION ALONG THE BOILER WAS ESTIMATED BY USING BOTH HOMOGENEOUS AND LOCKHART-MARTINELLI DESCRIPTIONS OF THE FLOW. THE CALCULATED EXIT PRESSURES COMPARED FAVORABLY WITH THE MEASURED VALUES.

*COMPARISON, THEORY AND EXPERIENCE + *FLOW, TUBE + *HEAT TRANSFER, BOILING + *INSTRUMENTATION, FLOW +
*POTASSIUM + HEAT TRANSFER CORRELATION + HEAT TRANSFER EXPERIMENT + HYDRAULIC EXPERIMENT +
INSTRUMENTATION, GENERAL + PRESSURE DROP

5-10217 LURIE H
SODIUM BOILING HEAT TRANSFER AND HYDRODYNAMICS

CATEGORY 5
ACCIDENT ANALYSIS

5-10217 *CONTINUED*

ATOMICS INTERNATIONAL

ANL-7100 + CONF-650946 +. 22 PAGES, 10 FIGURES, 13 REFERENCES, PP. 549-571 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

PRESENTED ARE THE RESULTS OF EXPERIMENTS ON THE STEADY-STATE POOL-BOILING CRITICAL HEAT FLUX OF SATURATED SODIUM AS A FUNCTION OF PRESSURE, AND ON THE FORCED-CONVECTION BOILING-HEAT-TRANSFER CHARACTERISTICS AND THE CRITICAL HEAT FLUX OF SODIUM AS FUNCTIONS OF PRESSURE, FLOW RATE, AND SUBCOOLING OR QUALITY. ALSO PRESENTED ARE THE STEADY-STATE TWO-PHASE PRESSURE-DROP AND VOID-FRACTION RESULTS FOR THE UPFLOW OF SODIUM IN AN UNHEATED ANNULUS.

*CONVECTIVE BOILING + *FLOW, TUBE + *HEAT TRANSFER, BOILING + *METAL, ALKALI + *METAL, LIQUID + *POOL BOILING + *SODIUM + HEAT TRANSFER EXPERIMENT

5-10218 SELLERS AJ + THUR GM + WONG MK

RECENT DEVELOPMENTS IN HEAT TRANSFER AND DEVELOPMENT OF THE MERCURY BOILER FOR THE SNAP-8 SYSTEM AEROJET-GENERAL CORPORATION + NATIONAL AERONAUTICS AND SPACE ADMINISTRATION

ANL-7100 + CONF-650946 +. 59 PAGES, 36 FIGURES, 2 TABLES, 5 REFERENCES, PP. 573-632 OF PROCEEDINGS OF THE CONFERENCE ON APPLICATION OF HIGH TEMPERATURE INSTRUMENTATION TO LIQUID-METAL EXPERIMENTS, SEPTEMBER 28-29, 1965, CFSTI, \$6.75 CY, \$2.75 MN

THE MAJOR REQUIREMENTS ASSOCIATED WITH MERCURY ONCE-THROUGH BOILERS FOR SPACE POWER-PLANTS ARE REPEATABLE STARTUP AND RELIABLE LONG-TERM HEAT-TRANSFER PERFORMANCE WITHOUT DELETERIOUS EFFECTS ON OTHER SYSTEM COMPONENTS SUCH AS TURBINES, PUMPS, AND CONDENSERS. DURING THE PAST FEW YEARS THERE HAVE BEEN A NUMBER OF INSTANCES WHERE MERCURY BOILERS WERE KNOWN TO DECONDITION (LOSE HEAT-TRANSFER CAPABILITY) EITHER DURING STARTUP OR AFTER SOME PERIOD OF OPERATION. THIS CONDITION OF PERFORMANCE UNCERTAINTY DURING SYSTEM STARTUP AND ENDURANCE OPERATION CAN CAUSE PERFORMANCE REDUCTION, PREVENT ADEQUATE STARTUP, AND PRECIPITATE TURBINE CORROSION/EROSION. DURING THE DEVELOPMENT OF THE BOILERS FOR THE SNAP-8 NUCLEAR-ELECTRIC RANKINE-CYCLE SYSTEM, A NUMBER OF SINGLE-TUBE AND FULL-SCALE BOILER TESTS WERE PERFORMED. THE DATA WERE EVALUATED TO DETERMINE THE VALIDITY OF PROPOSED SEMIEMPIRICAL BOILING HEAT-TRANSFER AND TWO-PHASE-FLOW PRESSURE-DROP CORRELATIONS, AND BOILING CONDITIONING EFFECTS.

*HEAT EXCHANGER + *HEAT TRANSFER EXPERIMENT + *METAL, LIQUID + *SNAP 8 (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + *SURFACE, GENERAL + HEAT TRANSFER + HEAT TRANSFER CORRELATION + MERCURY + REACTOR, SPACE

5-10269 ORGANIC COOLANTS AND MODERATORS. BIBLIOGRAPHICAL SERIES NO. 17

INTERNATIONAL ATOMIC ENERGY AGENCY, VIENNA, AUSTRIA
STI/PUB/21/17 +. 176 PAGES, 1965, IAEA, \$4.00

THIS BIBLIOGRAPHY, WHICH ATTEMPTS TO REVIEW THE INFORMATION ON THE PRODUCTION, USE, PROPERTIES, PURIFICATION, ETC., OF ORGANIC MODERATORS AND COOLANTS, COVERS THE PERIOD FROM 1960 TO 1964 INCLUSIVE. NUCLEAR SCIENCE ABSTRACTS WAS USED AS THE MAIN BIBLIOGRAPHICAL SOURCE, AND THE PROCEEDINGS OF SPECIALIZED CONFERENCES WERE SCANNED. THE RELEVANT PAPERS OF THE 3RD INTERNATIONAL CONFERENCE ON THE PEACEFUL USES OF ATOMIC ENERGY, GIVING THE MOST RECENT INFORMATION, HAVE ALSO BEEN INCLUDED. THE BIBLIOGRAPHY CONTAINS 546 REFERENCES, MOSTLY WITH ABSTRACTS IN THE ENGLISH LANGUAGE. THE TITLES WITH THEIR REFERENCES AND ABSTRACTS ARE LISTED CHRONOLOGICALLY. AN AUTHOR INDEX, INCLUDING CORPORATE AUTHORS IN ABBREVIATED FORM, AND A SUBJECT INDEX ARE GIVEN AT THE END OF THE BIBLIOGRAPHY.

*BIBLIOGRAPHY + *MODERATOR + *ORGANIC COOLANT + CHEMICAL ANALYSIS + HEAT TRANSFER

5-10271 CHI JW

FORCED CONVECTIVE BOILING HEAT TRANSFER TO HYDROGEN
WESTINGHOUSE ELECTRIC CORPORATION

3 PAGES, 4 FIGURES, 10 REFERENCES, JOURNAL SPACECRAFT AND ROCKETS, 3(1), PP. 150-152 (JANUARY, 1966)

PROBLEM - ATTEMPT TO DEVELOP A GENERAL CORRELATION FOR FILM AND NUCLEATE BOILING OF HYDROGEN IN TUBES. SOLUTION - AN ANNULAR FLOW MODEL IS POSTULATED WITH A LIQUID CORE. IN FILM BOILING, HEAT MUST FIRST BE TRANSFERRED THROUGH THE VAPOR. TRANSITION BOILING IS TREATED BY PARAMETERS GIVING THE FRACTION OF TIME LIQUID OR VAPOR ARE IN CONTACT WITH THE WALL. RESULTS - CORRELATIONS SHOW SIMILARITY WITH POOL-BOILING CURVES, DIFFERENCES EXPLAINABLE BY TUBE-FLOW EFFECTS. CONCLUSION - ANNULAR FLOW MODEL APPEARS REASONABLE FOR THE SHORT (6 IN.) TEST SECTION USED, BUT MAY BREAK DOWN IN LONGER TUBES. MORE RESEARCH IS NEEDED TO ESTABLISH CONDITIONS UNDER WHICH ANNULAR FLOW PREVAILS.

*CONVECTIVE BOILING + *HEAT TRANSFER + *HEAT TRANSFER ANALYSIS + *HEAT TRANSFER CORRELATION + *HEAT TRANSFER, BOILING + FLOW, TUBE + HYDROGEN

5-10320 VOIGT O

POST-ACCIDENT PRESSURE AND TEMPERATURE TRANSIENTS IN A DRY CONTAINMENT - A PARAMETRIC STUDY
ALLGEMEINE ELEKTRICITÄTS-GESELLSCHAFT (AEG), FRANKFURT/MAIN, GERMANY

15 PAGES, 4 TABLES, 17 FIGURES, 10 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(3) PP. 451-466 (APRIL 1966)

DRY CONTAINMENT IS WIDELY USED FOR SAFETY ENCLOSURE OF NUCLEAR POWER PLANTS. TO DETERMINE THE CONTAINMENT DESIGN PRESSURE, IT IS REQUIRED TO CALCULATE THE MAXIMUM PRESSURE FOLLOWING THE POSTULATED MOST SEVERE ACCIDENT AND ESTIMATE THE UNCERTAINTIES OF THE CALCULATION. THE RELEASE OF FISSION PRODUCTS FOLLOWING THE ACCIDENT HAS TO BE DETERMINED ON THE EVALUATION OF

CATEGORY 5
ACCIDENT ANALYSIS

5-10320 *CONTINUED*

THE LONG-TIME TRANSIENT PRESSURES AND TEMPERATURES. THE FOLLOWING WORK DESCRIBES A METHOD OF PERFORMING THESE CALCULATIONS, BASED ON WORK DONE FOR THE 520-MW(TH) BOILING WATER REACTOR AT LINGEN, GERMANY. IT DEMONSTRATES THE INFLUENCE OF DEVIATIONS OF BASIC DATA ON THE CALCULATED TRANSIENTS AND PROVIDES A BASIS FOR ENGINEERING JUDGEMENT ON THE RELATIVE IMPORTANCE OF THE DIFFERENT INPUT DATA. THE COMPUTER PROGRAM IS DESCRIBED.

*COMPUTER PROGRAM + *CONTAINMENT ANALYSIS + *CONTAINMENT, HIGH PRESSURE + GERMANY + LOSS OF COOLANT + PRESSURE, INTERNAL + REACTOR, BOILING WATER + THERMAL ANALYSIS

5-10407 MORRISON DL + GIESEKE JA + RITZMAN RL + WALTERS CT + GENCO JM + SUNDERMAN DN
AN EVALUATION OF THE APPLICABILITY OF EXISTING DATA TO THE ANALYTICAL DESCRIPTION OF A NUCLEAR-REACTOR ACCIDENT. QUARTERLY PROGRESS REPORT FOR JANUARY-MARCH, 1966
BATTELLE MEMORIAL INSTITUTE
BMI-X-10163 + EURAEC-1641 +. 44 PAGES, 9 FIGURES, 2 TABLES, 55 REFERENCES, APRIL 1, 1966, CFSTI, \$2.00 CY, \$0.50 MN

THIS IS A PROGRESS REPORT ON THE FOLLOWING AREAS - HEAT TRANSFER AND THERMODYNAMICS, METAL-WATER REACTIONS, HYDROGEN COMBUSTION, LOSS-OF-COOLANT ACCIDENT, MELTDOWN, FISSION-PRODUCT CHEMISTRY, FISSION-PRODUCT TRANSPORT AND DEPOSITION, DEPOSITION ON SURFACES, PARTICLE DYNAMICS, AND PARTICLE-SIZE ANALYSIS ON DEPOSITION TUBES WITH POLYDISPERSE PARTICLES.

*ACCIDENT MODEL + *AEROSOL + *AEROSOL PROPERTIES + ACCIDENT ANALYSIS + CHEMICAL REACTION + CORE MELTDOWN + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT + HEAT TRANSFER + LOSS OF COOLANT + SURFACE, GENERAL + THERMODYNAMICS

5-10430 ARGONNE NATIONAL LABORATORY PUBLICATIONS, JULY 1, 1964 - JUNE 30, 1965
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7087 +. 328 PAGES, AUGUST 1965 CFSTI, \$7.00 CY, \$1.50 MN

THIS PUBLICATION LIST IS A BIBLIOGRAPHY OF SCIENTIFIC AND TECHNICAL ACCOUNTS ORIGINATED AT ARGONNE AND PUBLISHED DURING FISCAL YEAR 1965. IT INCLUDES ITEMS PUBLISHED AS JOURNAL ARTICLES, TECHNICAL REPORTS, BOOKS, ETC., ALL OF WHICH HAVE BEEN MADE AVAILABLE TO THE PUBLIC. THE LIST IS DIVIDED INTO THREE PARTS - THE FIRST A LIST DIVISION, THE SECOND AN ALPHABETICAL AUTHOR INDEX, AND THE THIRD PART A KWIC SUBJECT INDEX. INCLUDED ARE SECTIONS ON RADIOLOGICAL PHYSICS, REACTOR PHYSICS, REACTOR ENGINEERING, INDUSTRIAL HYGIENE AND SAFETY, FIRE PROTECTION, AND CHEMICAL ENGINEERING.

*BIBLIOGRAPHY + *BURNOUT HEAT FLUX + *CHEMICAL REACTION + *DOSE MEASUREMENT, EXTERNAL + *HEAT TRANSFER + *REACTOR DYNAMICS + *REACTOR STABILITY + ACCIDENT ANALYSIS + FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) + METAL WATER REACTION + NOISE + REACTIVITY COEFFICIENT + REACTOR KINETICS + REACTOR TRANSIENT + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED + SPACE DEPENDENT DYNAMICS + VOID COEFFICIENT

5-10454 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 7 PAGES, 2 FIGURES, 1 TABLE, JUNE 1966, DOCKET 115-5, PP. II-5-1 THROUGH II-5-7, AMENDMENT NO. 25, PDR

QUESTION II-5. DISCUSSION OF THE LIMITING HEAT FLUX OF 109 BTU/SEC-FT SQ SHOWS THAT TWO DESIGN CRITERIA WERE USED TO DETERMINE LOWER LIMITS OF CIRCULATING FLOW - (1) BURNOUT RATIO 1.5, (2) STEAM-VOLUME FRACTION LESS THAN 0.7. FOUR STANDARD POWER LEVELS WERE EVALUATED AT VARIOUS REACTOR LIFETIMES AND ROD POSITIONS TO DETERMINE THE LIMITING FLOWS. WORST CASE WAS INITIAL STARTUP, AS ZIRCALOY SHROUDS DO NOT RAISE PEAK-TO-AVERAGE POWER TO INITIAL CONDITIONS.

*BURNOUT HEAT FLUX + *LACROSSE BOILING WATER REACTOR + *POWER DISTRIBUTION + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FLOW, TWO PHASE + FUEL BURNUP + REACTOR, BOILING WATER

5-10475 COATES RL + HORTON NR
RSAC--A RADIOLOGICAL SAFETY ANALYSIS COMPUTER PROGRAM
PHILLIPS PETROLEUM COMPANY, IDAHO
ID0-17151 +. 208 PAGES, 3 TABLES, 7 REFERENCES, MAY 1966, CFSTI, \$6.00 CY, \$1.25 MN

AN IBM 7040 PROGRAM WHICH COMPUTES THE POTENTIAL RADIOLOGICAL DOSES RESULTING FROM A CONTINUOUS OR INSTANTANEOUS RELEASE OF FISSION PRODUCTS TO THE ATMOSPHERE. DEVELOPED AS PART OF LOFT AND GENERAL NUCLEAR SAFETY PROGRAMS TO PROVIDE A GENERALIZED COMPUTER PROGRAM FOR A COMPLETE PARAMETRIC INVESTIGATION OF RADIOLOGICAL HAZARDS. DOSES CONSIDERED ARE CLOUD GAMMA, DEPOSITION GAMMA, INGESTION, AND INHALATION, AND ARE BASED UPON THE RELEASE OF UP TO 200 ISOTOPES, THE RELATIVE ABUNDANCE OF EACH ISOTOPE BEING DEPENDENT UPON THE OPERATING HISTORY OF THE NUCLEAR REACTOR UNDER CONSIDERATION. INCLUDED ARE THE MATHEMATICAL MODELS, CONVERSION FACTORS, ASSUMPTIONS, FLOW CHARTS, PROGRAM LISTINGS, AND OTHER DATA PERTINENT TO THE OVERALL DEVELOPMENT OF THIS PROGRAM.

*COMPUTER PROGRAM + *DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL + *FISSION PRODUCT RELEASE, GENERAL + SUTTON DIFFUSION FORMULA

5-10553 MILLER D
A CRITICAL REVIEW OF THE PROPERTIES OF MATERIALS AT THE HIGH TEMPERATURES AND PRESSURES SIGNIFICANT FOR FAST REACTOR SAFETY

CATEGORY 5
ACCIDENT ANALYSIS

5-10553 *CONTINUED*
ARGONNE NATIONAL LABORATORY, ARGONNE
ANL-7120 +. 13 PAGES, 17 FIGURES, 5 TABLES, PP. 641-653 OF PROCEEDINGS OF THE CONFERENCE ON SAFETY,
FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, OCTOBER 11-14, 1965, CFSTI, \$9.25 CY

THE EQUATION OF STATE PLAYS AN IMPORTANT ROLE IN CALCULATIONS OF THE COURSE OF A HYPOTHETICAL FAST-REACTOR EXCURSION, FOR IT SERVES AS THE LINK BETWEEN THE NEUTRONIC REACTIONS AND THE DYNAMIC BEHAVIOR OF A CORE WHICH LEADS TO ULTIMATE SHUTDOWN. DETERMINATION OF THE ENERGY APPEARING AS KINETIC ENERGY PROVIDES INSIGHT INTO THE POTENTIAL DAMAGE THAT MIGHT RESULT FROM SUCH AN EXCURSION. THE PRINCIPAL RELATIONS NECESSARY FOR SUCH CALCULATIONS ARE THE PRESSURE AS A FUNCTION OF ENERGY AND VOLUME FOR HYDRODYNAMICS CALCULATIONS, WHICH GIVE THE TIME VARIATION OF GEOMETRY (INCLUDING PURELY ELASTIC DEFORMATIONS SUCH AS THERMAL EXPANSION), AND THE TEMPERATURE AS A FUNCTION OF ENERGY AND VOLUME, TO GIVE THE PROPER TEMPERATURE DEPENDENCE OF NUCLEAR CROSS SECTIONS (WITH SPECIAL EMPHASIS ON THE DOPPLER COEFFICIENT). SEVERAL TECHNIQUES FOR DETERMINING THESE RELATIONS HAVE BEEN USED AND WILL BE CRITICALLY REVIEWED AND COMPARED. IN ADDITION, SOME FUTURE DIRECTIONS WILL BE INDICATED.

*EQUATION OF STATE + *REACTOR, FAST + *SAFETY PRINCIPLES AND PHILOSOPHY + *THERMODYNAMICS +
CHEMICAL KINETICS + OXIDE + REACTOR KINETICS + URANIUM + VAPOR, VAPOR PRESSURE

5-10572 POPPENDIEK HF + GREENE ND + SABIN CM + FEIGENBUTZ LV + MOURITZEN G + MACDONALD FR + LIVETT RK +
CHAMBERS JE + SCHWARTZ PE + CONNELLY DJ + MORTON WA
HIGH ACCELERATION FIELD HEAT TRANSFER FOR AUXILIARY SPACE NUCLEAR POWER SYSTEMS. SUMMARY REPORT
GEOSCIENCE LTD., SOLANA BEACH, CALIFORNIA
SAN-409-29 +. 125 PAGES, REFRANCFS, JANUARY, 1966, CFSTI, \$4.00 CY, \$0.75 MN

THIS REPORT SUMMARIZES THE PRINCIPAL RESULTS OF THE GEOSCIENCE, LTD., RESEARCH PROJECT IN BOILING HEAT TRANSFER IN HIGH-ACCELERATION FIELDS FOR THE PERIOD SEPTEMBER 1, 1961, TO AUGUST 31, 1965. THE ANALYTICAL AND EXPERIMENTAL WORK WAS DIRECTED TOWARD THE STUDY OF THE MECHANISMS WHICH CONTROL BOILING HEAT TRANSFER, BOTH IN LINEAR AND HELICAL FORCED FLOW BOILING. THE SUMMARY MATERIAL WAS ABSTRACTED FROM PREVIOUS GEOSCIENCE ANNUAL REPORTS. THE PHASE DISTRIBUTION HAS A LARGE EFFECT UPON MOMENTUM AND HEAT-TRANSFER PROCESSES IN FORCED-FLOW BOILING. IT IS ALSO CLEAR THAT THE PHASE DISTRIBUTION IS AFFECTED BY THE HEAT FLUX ITSELF. THE ANALYTICAL RESULTS PRESENTED CONSIST OF STUDIES OF IDEALIZED MOMENTUM- AND HEAT-TRANSFER MODELS. THE PRINCIPAL DIFFERENCE BETWEEN THE MODELS RELATES TO THE POSTULATED PHASE DISTRIBUTION. THE PARTICULAR PHASE DISTRIBUTIONS STUDIED ARE REPRESENTATIVE OF LINEAR AND HELICAL FLOW SYSTEMS. THE ANALYTICAL RESULTS FOR THE MODEL INVESTIGATED WERE COMPARED WITH EXPERIMENTAL DATA WHERE SUCH DATA EXIST. IN THE EXPERIMENTAL WORK REPORTED HERE, EMPHASIS WAS PLACED ON HIGH-ACCELERATION-FIELD HELICAL-FLOW BOILING, WITH MERCURY AND POTASSIUM AS THE WORKING FLUIDS.

*HEAT TRANSFER AUGMENTATION + *HEAT TRANSFER, BOILING + *METAL, LIQUID + FLOW THEORY AND EXPERIMENTS +
FLOW, TUBE + HEAT TRANSFER + HEAT TRANSFER ANALYSIS

5-10578 DIETZ KA
QUARTERLY TECHNICAL REPORT - STEP PROJECT, APRIL 1965-JUNE 1965
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
ID0-17145 +. 104 PAGES, 69 FIGURES, 14 TABLES, 30 REFERENCES, MAY 1966, CFSTI, \$4.00 CY, \$0.75 MN

QUARTERLY PROGRESS REPORT ON SNAPTRAN-1 TEST PROGRAM, LOFT CORE DESIGN, LOFT FACILITY AND EXPERIMENTAL DESIGN, LOFT RADIOLICAL STUDIES, AND INSTRUMENTATION STUDIES.

*LOFT (LOSS OF FLUID TEST) + *SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES) +
*STEP (SAFETY TEST ENGINEERING PROGRAM) + ANALYTICAL MODEL + CONTAINMENT DESIGN +
CONTAINMENT FILTERING SYSTEM + CONTAINMENT INSTRUMENTATION + FISSION PRODUCT TRANSPORT +
INSTRUMENTATION, GENERAL + IODINE + REACTOR KINETICS + REACTOR, PRESSURIZED WATER + SAMPLING

5-10750 THOMAS DG
FORCED CONVECTION MASS TRANSFER. PART I. EFFECT OF TURBULENCE LEVEL ON MASS TRANSFER THROUGH BOUNDARY LAYERS WITH A SMALL FAVORABLE PRESSURE GRADIENT
OAK RIDGE NATIONAL LABORATORY
6 PAGES, 6 FIGURES, 1 TABLE, 34 REFERENCES, A. I. CH. E. JOURNAL, 11(3), PAGES 520-525 (MAY, 1965)

THE EFFECT OF FREE-STREAM TURBULENCE LEVEL ON FORCED CONVECTION THROUGH LAMINAR AND TURBULENT BOUNDARY LAYERS ON A FLAT PLATE WAS STUDIED IN A WIND TUNNEL WITH A SMALL BUT NONZERO FAVORABLE PRESSURE GRADIENT BY MEANS OF THE NAPHTHALENE-SUBLIMATION TECHNIQUE. WITH THE SMALL FAVORABLE PRESSURE GRADIENT USED, THE RATE OF FORCED CONVECTION THROUGH LAMINAR BOUNDARY LAYERS AGREED WITH POLHAUSEN THEORETICAL EQUATION FOR TURBULENCE LEVELS LESS THAN 2.8 PERCENT BUT INCREASED IN A REGULAR FASHION FOR TURBULENCE LEVELS GREATER THAN 2.8 PERCENT AND WAS ALMOST TRIPLED AT A FREE STREAM TURBULENCE LEVEL OF 11 PERCENT. THERE WAS NO EVIDENCE OF AN INTERACTION BETWEEN PRESSURE GRADIENT AND TURBULENCE LEVEL WHICH WOULD PRODUCE DISPROPORTIONATE EFFECTS ON THE RATE OF FORCED CONVECTION THROUGH LAMINAR BOUNDARY LAYERS. SUBSTANTIALLY NO EFFECT OF TURBULENCE LEVEL ON FORCED CONVECTION THROUGH TURBULENT BOUNDARY LAYERS WAS OBSERVED FOR TURBULENCE LEVELS UP TO 7 PERCENT.

*BOUNDARY LAYER + *FLOW, TURBULENT + *MASS TRANSFER + FLOW THEORY AND EXPERIMENTS + FLUCTUATION +
HEAT TRANSFER

5-10751 THOMAS DG
FORCED CONVECTION MASS TRANSFER. PART II. EFFECT OF WIRES LOCATED NEAR THE EDGE OF THE LAMINAR BOUNDARY LAYER ON THE RATE OF FORCED CONVECTION FROM A FLAT PLATE

CATEGORY - 5
ACCIDENT ANALYSIS

5-10751 *CONTINUED*

OAK RIDGE NATIONAL LABORATORY

5 PAGES, 5 FIGURES, 1 TABLE, 18 REFERENCES, A. I. CH. E. JOURNAL, 11(5), PAGES 848-852 (SEPTEMBER, 1965)

THE LOCAL AND THE AVERAGE RATES OF FORCED CONVECTION THROUGH LAMINAR BOUNDARY LAYERS ON A FLAT PLATE WERE SHOWN TO BE MARKEDLY INCREASED BY LOCATING SMALL CYLINDERS NEAR THE OUTER EDGE OF THE BOUNDARY LAYER. THE LOCAL RATE OF FORCED CONVECTION WAS STRONGLY PEAKED DIRECTLY BENEATH EACH CYLINDER. THE MAGNITUDE OF THE EFFECT DEPENDED UPON THE FREE STREAM VELOCITY, THE SPACING BETWEEN CYLINDERS, AND THE GAP BETWEEN THE CYLINDERS AND THE PLATE. UNDER OPTIMUM CONDITIONS, LOCAL VALUES OF THE RATE OF FORCED CONVECTION WERE INCREASED AS MUCH AS 340 PERCENT WHILE THE AVERAGE VALUES WERE INCREASED BY OVER 190 PERCENT.

*BOUNDARY LAYER + *HEAT TRANSFER + *MASS TRANSFER + FLOW THEORY AND EXPERIMENTS + FLOW, LAMINAR + HEAT TRANSFER AUGMENTATION

5-10752 THOMAS DG

FORCED CONVECTION MASS TRANSFER. PART III. INCREASED MASS TRANSFER FROM A FLAT PLATE CAUSED BY THE WAKE FROM CYLINDERS LOCATED NEAR THE EDGE OF THE BOUNDARY LAYER

OAK RIDGE NATIONAL LABORATORY

7 PAGES, 6 FIGURES, 1 TABLE, 25 REFERENCES, A. I. CH. E. JOURNAL, 12(1), PAGES 124-130 (JANUARY, 1966)

ENHANCED RATES OF MASS TRANSFER IN THE WAKE REGION BEHIND DETACHED CYLINDRICAL TURBULENCE PROMOTERS WERE INVESTIGATED WITH THE USE OF THE NAPHTHALENE SUBLIMATION TECHNIQUE. THE MAXIMUM INCREASE IN THE AVERAGE RATE OF MASS TRANSFER THROUGH LAMINAR BOUNDARY LAYERS WAS OVER 170 PERCENT. THE REMARKABLE FEATURE OF THESE RESULTS WAS THAT THE ENHANCED RATES OF MASS TRANSFER PERSISTED OVER ONE HUNDRED AND THIRTY CYLINDER DIAMETERS DOWNSTREAM FROM THE CYLINDER GENERATING THE WAKE. THE OBSERVED EFFECT WAS NOT ONLY STRONGLY DEPENDENT ON THE FREE STREAM VELOCITY AND THE LOCATION OF THE CYLINDERS RELATIVE TO THE MASS TRANSFER SURFACE, BUT THERE WERE MARKED DIFFERENCES OBSERVED BETWEEN THE RATE OF MASS TRANSFER IN THE WAKE REGION BEHIND ONE AND BEHIND TWO CYLINDERS. THESE RESULTS RESEMBLE A TUNING PHENOMENON AND ARE BELIEVED TO BE DUE TO TOLLMEIN-SCHLICHTING INSTABILITIES AND PREMATURE TRANSITION.

*BOUNDARY LAYER + *HEAT TRANSFER + *HEAT TRANSFER AUGMENTATION + *MASS TRANSFER + FLOW THEORY AND EXPERIMENTS + HEAT TRANSFER, CONVECTION

5-10753 THOMAS DG + KRAUS KA

INTERACTION OF VORTEX STREETS

OAK RIDGE NATIONAL LABORATORY

2 PAGES, 1 FIGURE, 8 REFERENCES, JOURNAL OF APPLIED PHYSICS, 35(12), PAGES 3458-3549 (DECEMBER, 1964)

PROBLEM - STUDY THE EFFECTS OF VORTEX STREET FORMATION AND INTERACTION FROM MULTIPLE CYLINDERS ARRANGED PARALLEL TO THE FLOW. SOLUTION - TITANIUM TETRACHLORIDE SMOKE WITH HIGH-SPEED PHOTOGRAPHY IN A WIND TUNNEL WAS USED TO OBSERVE THE DEVELOPMENT IN THE WAKE OF THE RODS. RESULTS - PHOTOGRAPHS OF WAKE PATTERNS ARE SHOWN. CONCLUSION - (A) MULTIPLE CYLINDERS IN A FLOWING STREAM DO NOT PRODUCE CHAOTIC TURBULENCE BUT A SERIES OF PERIODIC PHENOMENA. (B) INTERFERENCE EFFECTS WERE MORE PRONOUNCED WHEN THE CYLINDERS WERE IN THE PLANE OF THE FLOW THAN WHEN THEY WERE PERPENDICULAR TO THE FLOW, AS ORIGINALLY SUGGESTED BY TAYLOR. (C) EXPANSION OF THE VORTEX STREET AND COALESCENCE OF VORTICES CAN OCCUR AWAY FROM THE SURFACE OF THE CYLINDER. USUALLY THIS OCCURS WITHIN A DISTANCE OF 20 TO 30 DIAMETERS DOWNSTREAM. (D) BEATS CAN OCCUR, CHARACTERIZED BY FREQUENCIES MUCH SMALLER THAN THE PRIMARY FREQUENCY OF VORTEX SHEDDING AND BY MARKEDLY DIFFERENT WAKE PATTERNS FOR CERTAIN COMBINATIONS OF CYLINDER SPACING AND AIR VELOCITY. (E) CONTRACTIONS OR CANCELLATION OF THE VORTEX STREETS SEEMED TO BE MAXIMAL WHEN THE CYLINDER SPACING WAS AN ODD MULTIPLE OF 1/2 OF THE LONGITUDINAL SPACING OF THE VORTICES OF THE STREET FROM A SINGLE CYLINDER.

*FLOW STABILITY + *FLOW THEORY AND EXPERIMENTS + *HEAT TRANSFER AUGMENTATION + *HYDRAULIC EXPERIMENT + FLOW, CROSS + FLUCTUATION + HEAT TRANSFER + MASS TRANSFER

5-10754 HSU CJ + HUANG CJ

HEAT OR MASS TRANSFER IN LAMINAR FLOW THROUGH A CONCENTRIC ANNULUS WITH CONVECTIVE FLUX AT WALLS UNIVERSITY OF HOUSTON, TEXAS

12 PAGES, 8 FIGURES, 1 TABLE, 3 REFERENCES, CHEMICAL ENGINEERING SCIENCE, 21(3), PAGES 209-221 (1966)

THEORETICAL EQUATIONS DESCRIBING THE TEMPERATURE FIELDS AND NUSSELT NUMBERS HAVE BEEN OBTAINED FOR A FULLY DEVELOPED LAMINAR FLOW THROUGH AN ANNULAR PASSAGE WHERE THERMAL RADIATION FROM THE WALL TO THE SURROUNDING MEDIUM TAKES PLACE ACCORDING TO NEWTON'S LAW OF COOLING. THE ANALYTICAL SOLUTIONS WERE OBTAINED BY REDUCING THE GOVERNING ENERGY EQUATION TO A PAIR OF ORDINARY DIFFERENTIAL EQUATIONS. ONE OF THESE EQUATIONS CONSTITUTES AN EIGENVALUE PROBLEM OF THE STURM-LIOUVILLE SYSTEM. EIGENVALUES AND EIGENFUNCTIONS SATISFYING THE CHARACTERISTIC EQUATION AND THE APPROPRIATE RADIATIVE BOUNDARY CONDITIONS ARE DETERMINED AND TABULATED. VARIATIONS OF THE LOCAL NUSSELT NUMBER ARE ILLUSTRATED FOR THE RESPECTIVE CASES OF UNILATERAL (OUTER WALL INSULATED) AND BILATERAL RADIATIVE TRANSFER. FOR THE LATTER CASE, THE EFFECTS OF VARYING THE RELATIVE MAGNITUDE OF THE RADIATION COEFFICIENTS AT THE INNER AND THE OUTER WALLS OF THE ANNULUS ARE ALSO INVESTIGATED AND DISCUSSED. SOLUTIONS ARE ALSO OBTAINED FOR THE CASE WHERE RADIATIVE HEAT TRANSFER AT THE WALL AND UNIFORM INTERNAL HEAT GENERATION TAKE PLACE SIMULTANEOUSLY.

*ANNULUS + *FLOW, AXIAL + *FLOW, LAMINAR + *HEAT TRANSFER + *HYDRODYNAMIC ANALYSIS + *MASS TRANSFER + FLOW THEORY AND EXPERIMENTS

5-10755 NIJSING R

TEMPERATURE AND HEAT FLUX DISTRIBUTION IN NUCLEAR FUEL ELEMENT RODS

ACCESSION NUMBER 5-10751 TO 5-10755

CATEGORY 5
ACCIDENT ANALYSIS

5-10755 *CONTINUED*

JOINT RESEARCH CENTRE OF THE EUROPEAN COMMUNITY FOR ATOMIC ENERGY, EURATOM, ISPRA, ITALY
21 PAGES, 19 FIGURES, 5 TABLES, 4 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4, PAGES 1-20 (1966)

THE ANALYTIC METHODS PRESENTED IN THIS PAPER MAY BE USED TO SOLVE COMPLEX HEAT-CONDUCTION PROBLEMS ASSOCIATED WITH THE DESIGN OF ROD-TYPE FUEL ELEMENTS. THE MAIN ADVANTAGE OF THE APPROACH ADOPTED IS THAT WITHOUT THE NECESSITY OF AN ITERATIVE PROCEDURE A SOLUTION IS OBTAINED THAT DESCRIBES THE TEMPERATURE FIELD IN THE FUEL AS WELL AS IN THE CLADDING. THE INFLUENCES OF ASYMMETRIC HEAT GENERATION AND PERIPHERAL VARIATIONS OF CONTACT RESISTANCE AND HEAT-TRANSFER COEFFICIENTS WERE INVESTIGATED INDEPENDENTLY FROM EACH OTHER. IF NECESSARY THE SAME METHODS CAN BE USED TO DESCRIBE ANALYTICALLY THE COMBINED INFLUENCE OF SUCH NONUNIFORMITIES. AS TO THE PERIPHERAL VARIATIONS OF THE CONTACT RESISTANCE, ONLY THE CASE WAS CONSIDERED OF A ONE-POINT CONTACT BETWEEN FUEL AND CLADDING. EXPRESSIONS DESCRIBING THE EFFECT OF A MORE-POINT CONTACT CAN BE DERIVED IN EXACTLY THE SAME MANNER. FROM THE NUMERICAL RESULTS PRESENTED, A NUMBER OF GENERAL CONCLUSIONS CAN BE DRAWN. FOR HIGH-CONDUCTIVITY FUELS, THE PRESENCE OF A LARGE CONTACT RESISTANCE HAS TWO UNFAVOURABLE INFLUENCES. IT ENTAILS AN IMPORTANT INCREASE IN FUEL TEMPERATURE, THUS IMPAIRING THE ADVANTAGES INHERENT TO SUCH FUELS, AND IT GIVES RISE TO HOT SPOTS IN THE CLADDING IN CASE THE CONTACT RESISTANCE VARIES PERIPHERALLY DUE TO POOR MECHANICAL TOLERANCES. THE USE OF A HIGH-CONDUCTIVITY CLADDING PRESENTS A CONSIDERABLE ADVANTAGE SINCE IT ATTENUATES TEMPERATURE DIFFERENCES DUE TO VARIATION IN HEAT GENERATION, CONTACT RESISTANCE, AND HEAT-TRANSFER COEFFICIENTS. THE ATTENUATING EFFECT IS RELATIVELY LESS IMPORTANT THE GREATER THE DISTANCES OVER WHICH THESE VARIATIONS EXTEND.

*FUEL ELEMENT + *HEAT CONDUCTION + *HEAT GENERATION, INTERNAL + *HEAT TRANSFER ANALYSIS +
HEAT GENERATION, NONUNIFORM + HEAT TRANSFER

5-10756 PAVLICA RT + MARSHALL RC
AN EXPERIMENTAL STUDY OF FUEL ASSEMBLY VIBRATIONS INDUCED BY COOLANT FLOW
COMBUSTION ENGINEERING, INC.
7 PAGES, 7 FIGURES, 2 TABLES, 5 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4, PAGES 54-60 (1966)

PROBLEM - DETERMINE EXPERIMENTALLY AND ATTEMPT CORRELATIONS OF FUEL-ASSEMBLY VIBRATIONS INDUCED BY COOLANT FLOW. ALTHOUGH CONSIDERABLE WORK HAS BEEN DONE ON PERPENDICULAR FLOW, RELATIVELY LITTLE INFORMATION IS AVAILABLE FOR PARALLEL FLOW. SOLUTION - A SERIES OF EXPERIMENTS WERE RUN, USING A BUNDLE OF RODS OF 0.4375 INCH OUTER DIAMETER, SIX FEET LONG, IN A 4 X 4 ARRAY, WITH A FLOW AREA OF 4.68 SQ. IN. INSIDE THE SHROUD. THE NUMBER OF SPACERS WERE VARIED TO AFFECT BUNDLE RIGIDITY. RESULTS - THE PAIDOUSSIS CORRELATION IN SINGLE RODS WAS EXTENDED TO ROD BUNDLES AND WAS SHOWN TO AGREE FAIRLY WELL WITH THE DATA. CONCLUSIONS - VIBRATION OF A FUEL ASSEMBLY TREATED AS A COMPOSITE STRUCTURE IS QUITE SIMILAR TO INDIVIDUAL ROD VIBRATION IN PARALLEL FLOW. IT TENDS TO VIBRATE NEAR ITS NATURAL FREQUENCY, AND THE AMPLITUDE INCREASES PROPORTIONAL TO THE FLOW VELOCITY TO THE SECOND OR THIRD POWER. FOR THE NARROW TEMPERATURE RANGE INVESTIGATED, THE VISCOSITY EFFECT IS NOT AS STRONG AS PREDICTED BY BURGHEEN AND PAIDOUSSIS. THIS IS ALSO CONFIRMED BY THE DATA OF QUINN. THE CORRELATION DUE TO PAIDOUSSIS FITS THE DATA FAIRLY WELL, EXCEPT FOR THE VISCOSITY EFFECT, PROVIDING THE MEASURED DYNAMIC STIFFNESS IS USED TO ACCOUNT FOR THE STIFFENING EFFECT OF INTERMEDIATE SPACERS. FURTHER WORK IS REQUIRED, USING DIFFERENT SIZE BUNDLES AND WIDER TEMPERATURE RANGES, TO CONFIRM THE APPLICABILITY OF THE PAIDOUSSIS CORRELATION TO COMPOSITE FUEL-BUNDLE VIBRATION.

*FLOW, AXIAL + *FUEL ELEMENT + *VIBRATION + FAILURE, FATIGUE + FLOW STABILITY +
FLOW THEORY AND EXPERIMENTS + FLUCTUATION

5-10900 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
13 PAGES, 4 FIGURES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING
UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 5 IS REALLY FIVE QUESTIONS ABOUT OPERATION WITH MAXIMUM SPECIFIC POWER HIGHER THAN THAT OF ANY CURRENTLY LICENSED REACTOR - (A) PEAK HEAT-FLUX FACTORS IN VARIOUS CONDITIONS, (B) PERCENTAGE OF FUEL RODS AT VARIOUS POWERS, REACTOR AT 100 PERCENT POWER, (C) SAME AS B, INCLUDING INSTRUMENT ERROR, (D) REPEAT OF B AND C, REACTOR AT 112 PERCENT POWER, (E) AT 125 PERCENT POWER, 37 FUEL RODS MIGHT REACH DNB, (F) DNB RATIO, FUEL CENTERLINE TEMPERATURE, AND EXIT QUALITY GIVEN FOR VARIOUS DEGREES OF OVERPOWER WITH HOT-CHANNEL FACTORS RAISED 10 PERCENT, (G) STATISTICAL VARIANCES OF ENGINEERING HOT-CHANNEL FACTORS GIVEN.

*CENTERLINE MELTING + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *HOT SPOT +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER

5-10906 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
6 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 11 ASKS FOR DETAILS OF STARTUP STEAM-LINE RUPTURE, REFUELING, AND
CONTROL-ROD-EJECTION ACCIDENTS. ANSWER DESCRIBES GENERALIZED COURSE OF ONOFRE RESULTS AS NOT
SIGNIFICANTLY DIFFERENT FOR ROD EJECTION.

*ACCIDENT, CONTROL ROD EJECTION + *ACCIDENT, CONTROL ROD WITHDRAWAL + *ACCIDENT, REFUELING +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *STEAM LINE RUPTURE + INDIAN POINT II +
REACTOR, PRESSURIZED WATER

CATEGORY 5
ACCIDENT ANALYSIS

5-10908 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 13 -- DESCRIBES WATER SUPPLY AND PUMPING TO STEAM GENERATOR UPON A COMPLETE LOSS OF
POWER. STORAGE FOR 24 HR AT LEAST WILL BE MAINTAINED IN THE CONDENSATE STORAGE TANK, WITH
CONNECTIONS TO MAKEUP OR CITY-WATER STORAGE. BACKUP CAN BE POWERED FROM DIESELS. AN
EMERGENCY, TURBINE-DRIVEN FEED PUMP IS PROVIDED (STARTED ON LOSS OF FLOW) AND SIZED SO THE
TUBES WILL NOT BE UNCOVERED. STEAM FROM THE STEAM GENERATOR RUNS TURBINE.

*DECAY HEAT + *EMERGENCY POWER, NONELECTRIC + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + LOSS OF POWER + REACTOR, PRESSURIZED WATER

5-10917 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 17 -- ALL EQUIPMENT ASSOCIATED WITH NUCLEAR SAFETY IS COMPLETELY SEPARATE FROM UNIT
1. AN MCA DOSE (INFINITE AND 8-HR, THYROID AND WHOLE BODY) RECEIVED IN THE CONTROL ROOM OF
THE OTHER UNIT IS LESS THAN 3 REMS. VARIOUS CONSERVATIVE ASSUMPTIONS WERE MADE.

*ACCIDENT, MAXIMUM CREDIBLE (MCA) + *DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + BUILDING + INDIAN POINT II + REACTOR, PRESSURIZED WATER

5-10919 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19A - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- MISSILE
PROTECTION SHALL BE PROVIDED FOR CONTAINMENT LINER AND ENGINEERED SAFEGUARDS. VARIOUS DESIGN
CONSIDERATIONS AND TYPES OF MISSILES ARE DESCRIBED.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
CONTAINMENT, MISSILE GENERATION AND PROTECTION + ENGINEERED SAFEGUARD + INDIAN POINT II +
REACTOR, PRESSURIZED WATER

5-10920 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19B - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STEAM
GENERATION WILL BE SUPPORTED TO PREVENT SECONDARY-SYSTEM DAMAGE FROM PRIMARY-PIPING RUPTURE.
AUXILIARY PIPING WILL NOT BE SPECIALLY SUPPORTED. REACTOR VESSEL, MAIN COOLANT PIPING, AND
SAFETY INJECTION PIPING WILL BE BRACED TO PREVENT CONTAINMENT DAMAGE AT THE CONTAINMENT
PENETRATION FOLLOWING A REACTOR COOLANT-PIPE BREAK.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SUPPORT STRUCTURE + FAILURE, PIPE +
INDIAN POINT II + REACTOR, PRESSURIZED WATER

5-10921 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19C - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STEAM
GENERATORS WILL BE PROTECTED AGAINST INCONEL TUBE OR TUBE-SHEET RUPTURE FOLLOWING PRIMARY OR
SECONDARY LINE BREAK, BY ASSUMING THAT FULL PRESSURE DIFFERENTIAL IS APPLIED AND BY LIMITING
STRESS TO 90 PERCENT OF YIELD STRESS.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FAILURE, PIPE + HEAT EXCHANGER +
INDIAN POINT II + REACTOR, PRESSURIZED WATER + STRESS ANALYSIS + SUPPORT STRUCTURE

5-10922 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19D - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- PRIMARY
AND SECONDARY COOLANT ALLOWABLE FISSION PRODUCT CONTENT WERE CALCULATED (BASED ON RELEASE OF
EITHER COOLANT IN A MINOR ACCIDENT) TO BE MUCH HIGHER THAN EXPECTED IN NORMAL OPERATION.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + DOSE CALCULATION, EXTERNAL +
INDIAN POINT II + REACTOR, PRESSURIZED WATER + STEAM LINE RUPTURE

CATEGORY 5
ACCIDENT ANALYSIS

5-10926 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19H - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STATES
THAT HYDRAULIC EFFECTS ON CORE INTERNALS DURING LOSS OF COOLANT ACCIDENT WILL BE CONSIDERED.

*CONTROL ROD, SHIM SAFETY + *DESIGN CRITERIA + *HYDRAULIC EFFECT +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FUEL ELEMENT + INDIAN POINT II + LOSS OF COOLANT +
REACTOR, PRESSURIZED WATER

5-11108 LAWRENCE RA + PANCOAST JT
ASTR LOSS OF FLUID COOLANT TEST
SOUTHERN METHODIST UNIVERSITY + GENERAL ATOMIC DIVISION, GENERAL DYNAMICS CORP.
23 PAGES, 11 FIGURES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966,
ANS TRANS. 9(11), PAGE 298

ASTR IS A 10-MW(TH) TANK-TYPE REACTOR WITH MTR-TYPE ELEMENTS WHICH CAN BE OPERATED IN A WATER
POOL OR IN AIR, WITH CORE ORIENTED IN ANY DIRECTION. THIRTEEN RUNS WERE MADE WITH COOLANT
WATER BLOWN OUT AND FUEL-ELEMENT TEMPERATURE MONITORED. A DETERMINATION OF OPERATING TIME VS
POWER LEVEL FOR FUEL MELTING WAS MADE, AND A TIME-TO-REACH-MELTING CURVE SHOWED 1000 SEC TO
TAKE ACTION FOR MOST SITUATIONS. A HEAT-TRANSFER MODEL WAS CHECKED, AND APPROPRIATE
COEFFICIENTS DERIVED.

*LOSS OF COOLANT + *TEST, PROOF + ACCIDENT ANALYSIS + REACTOR, TEST

5-11151 ANDERSEN P + ANDERSEN R + PEITRSEN VS + GRENNES M
DESIGN STUDY OF AN EXPERIMENTAL LOOP WITH A MODEL OF A DOR COOLANT CHANNEL IN FULL SIZE
SCANPROCESS A/S, CHEMICAL AND MECHANICAL ENGINEERS, COPENHAGEN + THE ELSINORE SHIPBUILDING AND ENGINEERING
CO., LTD., ELSINORE
RISO-REPORT-123 +. 180 PAGES, 20 FIGURES, 6 TABLES, 30 REFERENCES, MARCH 1965, DEP. MN

DESIGN CALCULATIONS AND DRAWINGS FOR A MECHANICAL-DESIGN TEST FOR FUEL ELEMENTS OF DOR,
(DANISH REACTOR, HEAVY-WATER ORGANIC-COOLED, 700 THERMAL MEGAWATTS). THE LOOP WAS NOT
COMPLETED BECAUSE THE DOR PROJECT WAS TERMINATED.

*HYDRAULIC EXPERIMENT + DENMARK + FUEL ELEMENT + OUT OF PILE LOOPS AND EXPERIMENTS + REACTOR, HEAVY WATER +
REACTOR, ORGANIC COOLED

5-11171 YANG WJ + CLARK JA
INFLUENCE OF FLOW AND ROTATIONAL OSCILLATIONS ON THE MECHANICS OF TWO-DIMENSIONAL LAMINAR BOUNDARY-LAYER
FLOW PAST CYLINDERS, INCLUDING UNIFORM SUCTION OR BLOWING
UNIVERSITY OF MICHIGAN, ANN ARBOR
ARL-66-0010, PART V +. 89 PAGES, 24 FIGURES, 6 TABLES, 43 REFERENCES, JANUARY 1966, DOD

A THEORETICAL INVESTIGATION OF THE INFLUENCE OF FLOW OSCILLATION, FLUCTUATING CIRCULATION AND
ROTATIONAL OSCILLATION UPON THE TRANSFER OF MOMENTUM, WITH OR WITHOUT UNIFORM SUCTION. THE
BOUNDARY-LAYER EQUATIONS FOR FLOW, TEMPERATURE AND CONCENTRATION ARE LINEARIZED BY MEANS OF A
PERTURBATION PROCEDURE AND THE FIRST THREE TERMS RETAINED. THE SOLUTIONS OF THE VELOCITY,
ORDINARY BLASIUS SERIES FOR A SYMMETRICAL BLUNT BODY, AND A GENERALIZED BLASIUS SERIES FOR A
SHARP-EDGED BODY. THEORETICAL RESULTS INCLUDE THE FREQUENCY RESPONSE OF FLUID VELOCITY,
TEMPERATURE AND CONCENTRATION, THE STREAMLINE PATTERNS OF THE STREAMING, THE DISTRIBUTION OF
THE STEADY SECOND-ORDER TEMPERATURE AND CONCENTRATION, AND THE ALTERNATIONS IN THE SHEAR
STRESS, RATES OF HEAT AND MASS TRANSFER. FOR FLOW AROUND A CIRCULAR CYLINDER NUMERICAL
RESULTS SHOW THAT THE PERMANENT ALTERATIONS IN THE SKIN FRICTION AND HEAT-TRANSFER RATE
INDUCED BY THE FLOW OSCILLATION, FLUCTUATING CIRCULATION AND ROTATIONAL OSCILLATION ARE VERY
SMALL IN THE RANGE OF SMALL AMPLITUDE AND LOW FREQUENCY.

*BOUNDARY LAYER + *FLOW STABILITY + *FLOW, PULSATING + FLUCTUATION + HEAT TRANSFER ANALYSIS +
HYDRODYNAMIC ANALYSIS + MASS TRANSFER

5-11172 SHOTKIN LM
A SPACE-INDEPENDENT MODEL OF TWO-PHASE FLOW AND ITS APPLICATION TO EXPERIMENT
BROOKHAVEN NATIONAL LABORATORY
BNL-963 +. 25 PAGES, 11 FIGURES, 3 TABLES, 34 REFERENCES, JANUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

A SPACE-INDEPENDENT MODEL OF A BOILING HYDRAULIC CHANNEL IS PRESENTED. THE MODEL INCLUDES TWO
EMPIRICAL CONSTANTS - THE SINGLE-PHASE FRICTION COEFFICIENT AND THE K-FACTOR IN BANKOFFS SLIP
RATIO RELATION - AND REQUIRES A KNOWLEDGE OF THE STEADY-STATE RELATION BETWEEN HEAT INPUT AND
FLOW RATE. LINEARIZED ANALYTICAL RESULTS ARE COMPARED, WITH REASONABLY GOOD AGREEMENT, WITH
SEVERAL TRANSFER FUNCTIONS MEASURED BY ZIVI, WRIGHT ET AL., IN A BOILING LOOP AT ATMOSPHERIC
PRESSURE USING BOTH NATURAL AND FORCED CIRCULATION. THE EXPERIMENTALLY OBSERVED INCREASE IN
UNSTABLE OSCILLATION FREQUENCY WITH INVERSE BOILING LENGTH IS ALSO SHOWN ANALYTICALLY. THE
POSITION OF THE BOILING BOUNDARY IN THE CHANNEL IS SHOWN TO BE IMPORTANT IN STABILITY
CONSIDERATIONS. BY COMPARING ANALYTICAL RESULTS WITH EXPERIMENTAL DATA OF WISSLER ET AL.,
AND BECKER ET AL., IT IS CONCLUDED THAT THE LEAST STABLE SITUATION RESULTS WHEN THE BOILING
BOUNDARY IS PART-WAY UP THE CHANNEL. SINCE THE POSITION OF THE BOILING BOUNDARY IS DIRECTLY
RELATED TO THE DEGREE OF SUBCOOLING, THE EXISTENCE OF THIS CRUCIAL POSITION IS USED TO
EXPLAIN THE INFLUENCE OF SUBCOOLING ON STABILITY.

*FLOW STABILITY + FLOW THEORY AND EXPERIMENTS + FLOW, TWO PHASE + HEAT TRANSFER, BOILING +

CATEGORY 5
ACCIDENT ANALYSIS

5-11172 *CONTINUED*
HYDRODYNAMIC ANALYSIS

5-11226 FERRELL JK
A STUDY OF CONVECTION BOILING INSIDE CHANNELS. PROGRESS REPORT
NORTH CAROLINA STATE UNIVERSITY, RALEIGH
TID-22967 +. 34 PAGES, DECEMBER 31, 1964, CFSTI \$2.00 CY, \$0.50 MN

PROGRESS REPORT (NORTH CAROLINA STATE UNIVERSITY, RALEIGH) ON CONVECTION BOILING INSIDE CHANNELS. THE PURPOSE OF THE PROJECT IS TO MAKE EXPERIMENTAL AND THEORETICAL STUDIES TO DETERMINE THE EFFECTS OF THE PERTINENT VARIABLES UPON TWO-PHASE, SINGLE-COMPONENT, FRICTIONAL AND CONTRACTION-EXPANSION PRESSURE LOSSES. THE FRICTIONAL PRESSURE-DROP RELATIONSHIPS ARE TO BE DETERMINED FOR HORIZONTAL AND VERTICAL, HEATED AND UNHEATED CHANNEL SURFACES.

*FLOW, TWO PHASE + *HEAT TRANSFER, BOILING + *PRESSURE DROP + CONVECTIVE BOILING +
FLOW THEORY AND EXPERIMENTS + FLOW, TUBE

5-11233 NICHOLS RW + WATKINS B
IMPLICATIONS OF EMBRITTLEMENT DURING THE LIFE OF A ZIRCONIUM PRESSURE TUBE REACTOR
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH
TRG REPORT 1252 (C) +. 21 PAGES, 9 FIGURES, 27 REFERENCES, JUNE 1966, UKAEA

REVIEW OF EFFECTS OF HYDROGEN AND RADIATION ON ZIRCALOY 2 SHOWS THAT ONLY HYDROGEN EMBRITTLEMENT IS OF IMPORTANCE. STEAM-GENERATING, HEAVY-WATER, PRESSURE-TUBE OUT-OF-PILE TESTS WITH 400 PPM OF HYDROGEN SHOW THAT DEFECTS SEVERAL INCHES LONG CAN BE TOLERATED. PRELIMINARY RESULTS INDICATE THAT CRACK-OPENING DISPLACEMENT PROVIDES A CORRELATION BETWEEN SMALL-SPECIMEN TESTS AND ACTUAL TUBE TESTS. NOTCH SPECIMENS IRRADIATED IN THE DFR TO 10 TO THE 21 NEUTRONS/SQ. CM SUGGEST THAT THE EMBRITTLEMENT EFFECT SATURATES AT LOW DOSES.

*EMBRITTLEMENT + *HYDROGEN + *ZIRCALOY + REACTOR, PRESSURE TUBE

5-11234 COWAN A + FEARNEHOUGH AC + GILLIES J + LEES GM
IRRADIATION DAMAGE IN MILD STEEL. A COMPARISON OF CRACK ARREST TEST AND OF NEUTRON SPECTRUM
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH
TRG REPORT 1069 (C) +. 29 PAGES, 15 FIGURES, 8 TABLES, 19 REFERENCES, MAY 1966, UKAEA

IRRADIATION OF CRACK-ARREST SPECIMENS AND CHARPY-V-NOTCH SPECIMENS UNDER IDENTICAL CONDITIONS SHOWED GOOD CORRESPONDENCE IN EVALUATION OF IRRADIATION-EMBRITTLEMENT EFFECTS. THUS CHANGES IN CHARPY-V-NOTCH MONITORING OR SURVEILLANCE SPECIMENS CAN BE USED WHEN REACTOR PRESSURE-VESSEL OPERATING LIMITS ARE BASED ON CRACK-ARREST CRITERIA. CHARPY SPECIMENS OF THE SAME STEEL, IRRADIATED IN THREE DIFFERENT REACTORS, SHOW THAT, WHEN DAMAGE IS EXPRESSED IN TERMS DERIVED FROM ACTIVATION OF NICKEL MONITORS, MEASURED CHANGES FOR A GIVEN DOSE CAN VARY BY A FACTOR OF TWO. HOWEVER, WHEN THE DAMAGE INDEX IS TAKEN AS THE TOTAL NUMBER OF ATOMS DISPLACED IN EACH REACTOR FACILITY, THE AGREEMENT WITH MEASURED DAMAGE IMPROVED TO BETTER THAN PLUS-OR-MINUS 15 PERCENT. THUS, WITH A KNOWLEDGE OF NEUTRON SPECTRA, IT IS POSSIBLE FOR A GIVEN STEEL SAMPLE TO GIVE A RELIABLE PREDICTION OF DAMAGE FROM ONE REACTOR TO ANOTHER.

*CONTAINMENT, PRESSURE VESSEL + *EMBRITTLEMENT + TEST, DROP

5-11297 KUMAR R
HEAT TRANSFER IN LAMINAR FLOW OF BINGHAM MATERIAL THROUGH AN ANNULUS
INDIAN INSTITUTE OF TECHNOLOGY, NEW DELHI, INDIA
5 PAGES, 2 FIGURES, 1 TABLE, 11 REFERENCES, JOURNAL OF THE PHYSICAL SOCIETY OF JAPAN 21(3), MARCH 1966

THE HEAT TRANSFER IN FULLY DEVELOPED LAMINAR FLOW OF BINGHAM MATERIAL IN AN ANNULUS BETWEEN TWO COAXIAL PIPES IS DISCUSSED. THE INNER PIPE MOVES PARALLEL TO ITSELF AND THE OUTER PIPE IS AT REST. EQUATIONS FOR TEMPERATURE DISTRIBUTION, INCLUDING THE EFFECT OF DISSIPATION AND INTERNAL HEAT GENERATION, WERE SET UP, AND A DISCUSSION OF THE SOLUTION IS GIVEN FOR THE CASE OF SMALL-GAP APPROXIMATION. THE TEMPERATURE DISTRIBUTIONS DEPEND ON BINGHAM NUMBER (OR THE POSITION OF YIELD SURFACE), BRINKMAN NUMBER, AND THE RATE OF HEAT TRANSFER AT THE WALL. THE EFFECT OF DISSIPATION IS TO INCREASE THE TEMPERATURE AT A PLACE, AND THIS EFFECT BECOMES GREATER AS THE REGION OF FLOW BECOMES NARROWER. THERE IS A CRITICAL VALUE OF THE BRINKMAN NUMBER ABOVE OR BELOW WHICH THE COOLING OR HEATING OF THE OUTER PIPE TAKES PLACE.

*ANNULUS + *FLOW, LAMINAR + *FLOW, NONNEWTONIAN + *HEAT TRANSFER ANALYSIS + FLOW, AXIAL + HEAT TRANSFER

5-11299 WOHLBERG C
ESTIMATES OF THE POSSIBILITY OF HYDROGEN EMBRITTLEMENT OF TANTALUM IN THE FRCTF
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-3508-MS +. 50 PAGES, 11 FIGURES, 12 TABLES, 44 REFERENCES, AUGUST 18, 1965, CFSTI \$3.00 CY

SINCE NAH IS NOT REMOVED BY TRAPPING ON HOT ZIRCONIUM, AN EVALUATION WAS MADE OF THE EXTENT TO WHICH THE CLADDING MIGHT BE HYDRIDED. COLD TRAPPING GIVES A 40-PPM EQUILIBRIUM VALUE IN THE TANTALUM, WELL BELOW THE 800-PPM ROOM-TEMPERATURE EMBRITTLEMENT VALUE. LITTLE IS KNOWN OF EMBRITTLEMENT EFFECTS AT 500 TO 600 C. EXTREME EXTRAPOLATIONS HAD TO BE MADE OF PARTIAL PRESSURES OF HYDROGEN OVER UNSATURATED SODIUM.

*EMBRITTLEMENT + *HYDROGEN + CLAD + COOLANT CHEMISTRY + FRCTF (FAST REACTOR CORE TEST FACILITY) +
REACTOR, LIQUID METAL COOLED + TANTALUM

CATEGORY 5
ACCIDENT ANALYSIS

5-11376 LOFT ANALYSIS--HYDRODYNAMICS DESCRIBING ACOUSTIC PHENOMENA DURING BLOWDOWN
PHILLIPS PETROLEUM COMPANY
100-17165 +. 28 PAGES, 4 FIGURES, REFERENCES, PAGES 45-72 OF QUARTERLY TECHNICAL REPORT, STEP PROJECT,
JULY 1965, SEPTEMBER 1965, CFSTI \$3.00 CY, \$0.75 MN

A METHOD IS BEING DEVELOPED FOR CALCULATING THE SPATIAL DISTRIBUTION OF PRESSURE WITHIN THE LOFT PRIMARY-COOLANT SYSTEM AS A FUNCTION OF TIME DURING THE FIRST HUNDRED MILLISECONDS AFTER BLOWDOWN. A CHEMICAL METHOD WAS DEVELOPED FOR THE RAPID SEPARATION OF TELLURIUM AND IODINE FROM OTHER FISSION PRODUCTS AND FROM EACH OTHER. MAXIMUM EXPECTED CONCENTRATIONS OF VARIOUS FISSION PRODUCTS WERE CALCULATED FOR THE CDE AND LOFT ATMOSPHERES AFTER 1.16 DAYS OF COOLING. STANDARD SURFACES WERE SELECTED FOR PLATEOUT STUDIES. SIMULATED IRRADIATION TESTS WERE CONDUCTED IN A STEAM-AIR ATMOSPHERE. COATED AND STAINLESS STEEL SURFACES WERE CONTAMINATED WITH MOLECULAR IODINE IN AN AUTOCLAVE TO DETERMINE THE INFLUENCE OF STEAM PRESSURE ON CONTAMINATION. A DESIGN STUDY WAS MADE TO DETERMINE THE FEASIBILITY OF A REACTIVITY ACCIDENT TEST USING A SMALL BOILING-WATER-REACTOR CORE.

*LOFT (LOSS OF FLUID TEST) + DEPOSITION + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT + PRESSURE, INTERNAL

5-11383 PIERCE BL
MODIFIED TRANSIENT AND/OR STEADY-STATE (TOSS) DIGITAL HEAT TRANSFER CODE
WESTINGHOUSE ELECTRIC CORP., PITTSBURGH, PA.
WANL-TME-1108 +. 53 PAGES, APRIL 1964, CFSTI \$3.00 CY, \$0.50 MN

THE TRANSIENT OR STEADY-STATE (TOSS) HEAT-TRANSFER CODE WAS MODIFIED TO INCLUDE TEMPERATURE-DEPENDENT SPECIFIC HEAT AND THERMAL CONDUCTIVITY AND TIME-DEPENDENT FORCED FILM CONVECTION COEFFICIENTS. THE SOLUTION OF THE GENERAL HEAT-CONDUCTION EQUATION WAS CHANGED FROM THE EXPLICIT TO IMPLICIT METHOD, THEREBY ALLOWING A LARGER TIME STEP AND THE USE OF LESS COMPUTER TIME. THE METHOD OF HANDLING HEAT TRANSFER BETWEEN CONTACTING BODIES WAS MODIFIED SO THAT IT IS NO LONGER NECESSARY TO USE SURFACE NODES. PROBLEMS THAT PREVIOUSLY WERE LIMITED BY SURFACE-NODE DIMENSIONS MAY NOW BE MANAGED.

*COMPUTER PROGRAM + *COMPUTER, DIGITAL + HEAT CONDUCTION + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + THERMAL PROPERTY

5-11384 CULVER HN + KEETON DC
ACCIDENT CONSEQUENCES FOLLOWING THE EJECTION OF A CONTROL ROD FROM THE EGCR CORE
TENNESSEE VALLEY AUTHORITY, OAK RIDGE
TID-22743 +. 69 PAGES, APRIL 26, 1965, CFSTI \$3.00 CY, \$0.75 MN

AS A SUPPLEMENT TO MCA STUDIES, AN ACCIDENT CONDITION INVOLVING THE FAILURE OF A CONTROL-ROD NOZZLE WAS INVESTIGATED TO DETERMINE THE CONSEQUENCES OF A NUMBER OF ASSUMED CONDITIONS OF FAILURE. THE CONSEQUENCES OF THE FAILURE OF A CONTROL-ROD NOZZLE ARE IN MANY RESPECTS SIMILAR TO THOSE THAT COULD BE ASSOCIATED WITH A DEPRESSURIZATION ACCIDENT RESULTING FROM THE FAILURE OF THE TOP NOZZLE OF A COOLING SYSTEM OR FROM A LIMITED FAILURE IN THE HOT-LEG PIPING OF A REACTOR COOLANT SYSTEM. HOWEVER, IN THE CASE OF THE CONTROL-ROD-NOZZLE FAILURE, THERE EXISTS THE POSSIBILITY, FOR CERTAIN POSTULATED FAILURES, OF INSERTING LARGE AMOUNTS OF REACTIVITY IN A RELATIVELY SHORT TIME IF THE POSTULATED FAILURE CAUSES THE RAPID EJECTION OF A CONTROL ROD. THIS STUDY INVESTIGATES THE CONSEQUENCES OF AN ASSUMED FAILURE IN A CONTROL-ROD NOZZLE THAT HAS CAUSED THE RAPID EJECTION OF A CONTROL ROD, AND COMPARES THESE CONSEQUENCES WITH THOSE ASSOCIATED WITH THE MCA. OXIDE TEMPERATURE REACHES ITS MAXIMUM TEMPERATURE IN ABOUT 1.2 SEC, AND CLAD TEMPERATURES REACH THEIR MAXIMUM IN ABOUT 2.0 SEC. WITH THE EXCEPTION OF THE FUEL-TEMPERATURE TRANSIENT AND ITS EFFECT ON FUEL-ELEMENT FAILURES, THE CONSEQUENCES ARE LESS SEVERE THAN THOSE THAT HAVE BEEN DESCRIBED FOR OTHER ACCIDENTS.

*ACCIDENT ANALYSIS + *EGCR (EXPERIMENTAL GAS COOLED REACTOR) + CONTROL ROD + HEAT TRANSFER ANALYSIS + LOSS OF COOLANT

5-11385 JORDAN EC + STEFFINS J
AN INVESTIGATION OF THE EFFECT OF MECHANICALLY INDUCED VIBRATIONS ON HEAT TRANSFER RATES IN A PRESSURIZED WATER SYSTEM
CATHOLIC UNIVERSITY OF AMERICA
NYO-2655-1 +. 105 PAGES, JULY 1965, CFSTI \$4.00 CY, \$0.75 MN

THIS EXPERIMENTAL INVESTIGATION WAS UNDERTAKEN TO DETERMINE VIBRATIONAL HEAT-TRANSFER RATES IN AN AREA PREVIOUSLY UNEXPLORED - VIBRATION OF SOLIDS AT HIGH TEMPERATURE IN HIGH-PRESSURE WATER. A CONSTANT EXPERIMENTAL GEOMETRY WAS INVESTIGATED WITH CONVECTIVE HEAT-TRANSFER RATES INVESTIGATED IN THE REGION OF HEAT FLUXES FROM 50,000 TO 80,000 BTU/HR/SQ. FT, REYNOLDS NUMBERS FROM 7000 TO 8500, AND DELTA T (DIFFERENCE BETWEEN HEATER SURFACE TEMPERATURE AND AVERAGE WATER TEMPERATURE) FROM 90 TO 210 F. A DECREASE IN HEATER SURFACE TEMPERATURE, WITH VIBRATIONS, QUALITATIVELY INDICATED AN INCREASE IN THE HEAT TRANSFER COEFFICIENT. THERE WAS LITTLE EFFECT ON HEAT-TRANSFER RATES WITH FREQUENCIES BELOW 75 CPS. THE MAXIMUM INCREASE IN THE TRANSFER RATE IN THE REGION INVESTIGATED WAS ABOUT 50 PERCENT. PLOTS OF THE RATIO OF THE VIBRATIONAL HEAT-TRANSFER COEFFICIENT TO THE AVERAGE OF THE NONVIBRATIONAL COEFFICIENT AS A FUNCTION OF DISPLACEMENT, WITH FREQUENCY AS A FACTOR, YIELDED A STRAIGHT-LINE APPROXIMATION. MEASUREMENTS MADE AT CONSTANT AMPLITUDE AND VARIABLE FREQUENCIES INDICATED OPTIMUM FREQUENCIES WHICH WERE A FUNCTION OF DISPLACEMENT. THESE COULD BE EXPLAINED BY AN ANALYSIS BASED ON CAVITATION THEORY IN WHICH IT WAS ASSUMED THAT THE INSTANTANEOUS LOCAL PRESSURE AT THE SURFACE OF THE HEATER ROD IS EQUAL TO THE VAPOR PRESSURE. THE LOCAL PRESSURE IS THE DIFFERENCE BETWEEN THE ABSOLUTE WATER PRESSURE AND THE PRESSURE INDUCED BY VIBRATIONS.

*HEAT TRANSFER CORRELATION + *VIBRATION + FLUCTUATION + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + WATER, GENERAL

CATEGORY 5
ACCIDENT ANALYSIS

5-11386 CORNWELL RS
EFFECTIVENESS NTU RELATIONS FOR ONE-, TWO-, AND THREE-PASS CROSS COUNTER FLOW HEAT EXCHANGERS TO NTU OF 40
LAWRENCE RADIATION LABORATORY
UCRL-14620 +. 14 PAGES, FEBRUARY 2, 1966, CFSTI \$1.00 CY, \$0.50 MN

CALCULATIONS OF EFFECTIVENESS FOR ONE-, TWO-, AND THREE-PASS CROSS COUNTERFLOW HEAT EXCHANGERS HAVE BEEN MADE FOR NTU (NUMBER OF TRANSFER UNITS) UP TO 40, AND CAPACITY RATE RATIOS OF 0.1 TO 1.0. NTU IS DEFINED AS THE RATIO OF THE OVERALL CONDUCTANCE FOR HEAT TRANSFER (BTU PER HOUR PER DEGREE F) DIVIDED BY THE MINIMUM FLUID HEAT-CAPACITY RATE (BTU PER HOUR PER DEGREE F). A 20 X 20 MATRIX IS USED IN EACH CROSSFLOW CELL, AND THE RESULTS ARE FED INTO THE NEXT CELL OR ARE MIXED TO GET A FINAL TEMPERATURE. A FORTRAN CODE FOR THE CDC 3600 IS ALSO INCLUDED.

*FLOW, CROSS + *HEAT EXCHANGER + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER CORRELATION

5-11387 MAHAFFEY MK
A VELOCITY TRANSFER FUNCTION ANALYSIS OF FORCED CONVECTION HEAT TRANSFER
KANSAS STATE UNIVERSITY
TID-22663 +. 87 PAGES, 1966, CFSTI \$3.00 CY, \$0.75 MN

IN THIS STUDY, DIGITAL-COMPUTER METHODS ARE USED IN CONJUNCTION WITH A PERTURBATION TECHNIQUE TO PREDICT THE RESPONSE TO CHANGES IN COOLANT VELOCITY OF A STAINLESS-STEEL TEST SECTION CONTAINED IN A PRESSURIZED-WATER HEAT-TRANSFER LOOP. THE TRANSFER FUNCTION OF OUTLET TEMPERATURE-COOLANT VELOCITY IS FORMULATED AND UTILIZED IN PREDICTING TEMPERATURE RESPONSES TO STEP CHANGES IN VELOCITY. SELECTED RESULTS ARE COMPARED WITH EXPERIMENTAL DATA GATHERED FROM THE HEAT-TRANSFER LOOP OPERATED BY THE NUCLEAR ENGINEERING DEPARTMENT OF KANSAS STATE UNIVERSITY.

*FLUCTUATION + *FUEL ELEMENT + *HEAT TRANSFER ANALYSIS + *TEMPERATURE TRANSIENT + COMPUTER, DIGITAL + FLOW THEORY AND EXPERIMENTS + FLOW, AXIAL + HEAT TRANSFER + HEAT TRANSFER CORRELATION + WATER, GENERAL

5-11388 MCFADDEN PW + SCHOENHALS RJ
HIGH FLUX HEAT TRANSFER TO SUB- AND SUPERCRITICAL WATER
PURDUE RESEARCH FOUNDATION, LAFAYETTE
COO-1177-19 + 23 PAGES, JANUARY 1966, CFSTI \$1.00 CY, \$0.50 MN

THIS FINAL REPORT DESCRIBES RESEARCH ACCOMPLISHED UNDER ATOMIC ENERGY COMMISSION CONTRACT NO. AT (11-1) - 1177 FOR THE PERIOD FROM JUNE 1, 1962, TO JANUARY 31, 1966. RESULTS OBTAINED DURING THIS PERIOD IN FIVE AREAS OF INVESTIGATION ARE BRIEFLY OUTLINED, AND APPROPRIATE REFERENCES ARE GIVEN AS A SOURCE OF FURTHER DETAIL.

*HEAT TRANSFER, SUPERCRITICAL + FLOW, TUBE + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER, BOILING

5-11389 CREVELING HF + SCHOENHALS RJ
STEADY FLOW CHARACTERISTICS OF A SINGLE-PHASE NATURAL CIRCULATION LOOP
PURDUE UNIVERSITY
COO-1177-15 +. 50 PAGES, JANUARY 1965, CFSTI \$2.00 CY, \$0.50 MN

ONE-DIMENSIONAL, STEADY-STATE, SINGLE-PHASE NATURAL-CIRCULATION FLOW IN A CIRCULAR LOOP WAS ANALYZED. THE RESULTING CORRELATIONS ARE PRESENTED FOR BOTH LAMINAR AND TURBULENT FLOWS FOR WIDE RANGES OF THE DIMENSIONLESS PARAMETERS INVOLVED. IN APPLYING THESE CORRELATIONS TO A PARTICULAR CASE IT IS NECESSARY TO CARRY OUT ITERATIVE CALCULATIONS. SAMPLE CALCULATIONS ARE GIVEN. EXPERIMENTS WERE MADE WITH WATER, AND DATA WERE COMPARED WITH THE ANALYTICAL PREDICTIONS.

*FLOW, TUBE + FLOW THEORY AND EXPERIMENTS + FLOW, LAMINAR + FLOW, TURBULENT + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER EXPERIMENT + HEAT TRANSFER, NATURAL CONVECTION + HYDRODYNAMIC ANALYSIS

5-11390 SHIMAZAKI TT
EFFECTS OF SOME SURFACE AND SYSTEM CONTAMINANTS ON MERCURY POOL BOILING HEAT TRANSFER
ATOMICS INTERNATIONAL, CANOGA PARK, CALIFORNIA
NAA-SR-11949 +. 62 PAGES, JULY 16, 1966, CFSTI, \$3.00 CY, \$0.75 MN

WITH RESPECT TO THE MERCURY RANKINE PROGRAM, THE EFFECTS OF SOME SURFACE AND SYSTEM CONTAMINANTS ON POOL-BOILING HEAT TRANSFER WERE INVESTIGATED TO (1) EXPLORE THE VALIDITY OF THE LOSS-OF-ADEQUATE-WETTING HYPOTHESIS PROPOSED AS AN EXPLANATION FOR BOILER DECONDITIONING, AND (2) DETERMINE TO WHICH CONTAMINANTS THE LOSS OF WETTING IS ATTRIBUTABLE. THE RESULTS INDICATE THAT LOSS OF ADEQUATE WETTING IS THE MOST LIKELY CAUSE OF DECONDITIONING, AND THAT THE EFFECT OF OIL CONTAMINATION ON LOSS OF WETTING IS MUCH MORE SEVERE AND PERMANENT THAN AIR OR WATER CONTAMINATION.

*HEAT EXCHANGER + *HEAT TRANSFER, BOILING + *METAL, LIQUID + *SURFACE CONTAMINATION + *SURFACE, GENERAL + HEAT TRANSFER + HEAT TRANSFER CORRELATION + HEAT TRANSFER EXPERIMENT + MERCURY

5-11391 OMBERG RP
EFFECT OF NATURAL CONVECTION UPON THE TEMPERATURE TRANSIENT FOLLOWING A LOSS-OF-COOLANT ACCIDENT IN A NUCLEAR POWER REACTOR
LAWRENCE RADIATION LABORATORY

CATEGORY 5
ACCIDENT ANALYSIS

5-11391 *CONTINUED*
UCRL-16394 +. 118 PAGES, FIGURES, REFERENCES, SEPTEMBER 1965, CFSTI \$4.00 CY, \$0.75 MN

THE EFFECT OF NATURAL CONVECTION UPON THE TEMPERATURE TRANSIENT FOLLOWING A LOSS-OF-COOLANT ACCIDENT WAS ANALYZED FOR A TYPICAL POWER-REACTOR CONFIGURATION. THE SYSTEM OF EQUATIONS DEVELOPED WAS THEN SOLVED BY USING THE DESIGN SPECIFICATIONS OF THE LOSS-OF-FLUID TEST REACTOR (LOFT). IT WAS FOUND THAT NATURAL CONVECTION WILL PREVENT MELTING OF EITHER THE FUEL OR CLADDING AT LOW POWER LEVELS. AT THE MAXIMUM POWER DENSITY ALLOWABLE IN THE LOFT, THE TIME TO FUEL MELTING WAS NEARLY TWICE THAT FOR AN ADIABATIC TRANSIENT.

*ACCIDENT, MAXIMUM CREDIBLE (MCA) + *LOFT (LOSS OF FLUID TEST) + *LOSS OF COOLANT + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER, NATURAL CONVECTION

5-11392 SEMENOV PA + SOLOVEV AV
FLOW OF THIN LIQUID FILMS
ANL-1KANS-319 +. 7 PAGES, 3 REFERENCES, MAY 1966, CFSTI \$1.00 CY, \$0.50 MN

IN THE PAPER THE AUTHORS CONSIDER A FLOW OF A THIN LIQUID FILM PAST A VERTICAL WALL, THE FREE SURFACE OF THE FILM BEING AFFECTED BY FRICTION FORCE OF GAS MOVING WITH HIGH VELOCITY. IF THE GAS MOVES UPWARD, THEN IN THE CASE OF AN INCREASE OF THE GAS VELOCITY, THE DOWNFLOW OF THE LIQUID IS AT FIRST DECELERATED BY THE FRICTION FORCE. IT STOPS THEREAFTER ENTIRELY, AND FINALLY THE LIQUID IS CARRIED AWAY BY THE FORCE OF FRICTION AND BEGINS TO FLOW UPWARD AND THE COUNTERCURRENT MOTION IS REPLACED BY THE ASCENDING DIRECT-FLOW MOTION. THE SURFACE OF THE LIQUID FILM IN THE UPWARD FLOW IS NOT PLANE BUT IS COVERED WITH WAVES. IF THE LIQUID FLOWS ALONG THE INTERNAL SURFACE OF A CIRCULAR TUBE IN WHOSE CENTRAL PART A GAS FLOW OCCURS, THEN THE WAVES POSSESS THE FORM OF RINGS WHICH ARE LOCATED REGULARLY AND WHICH MOVE UPWARD WITH A CONSTANT VELOCITY WHICH PERMITS ANALYSIS OF A REGULAR WAVE MODE OF FLOW. AT HIGH GAS VELOCITIES, THE CIRCULAR WAVE MODE IS REPLACED BY THE MODE OF CRESCENT-SHAPED WAVES, WHICH DO NOT COVER THE TOTAL TUBE PERIMETER. AT VERY HIGH GAS VELOCITIES, THE WAVES BECOME TRIDIMENSIONAL, SIMILAR TO RIPPLES ON THE SURFACE OF A POND. ANALYTICAL SOLUTIONS WERE OBTAINED FOR THE WAVE VELOCITY AND WAVELENGTH IN TERMS OF THE PRESSURE GRADIENT, RADIUS OF THE TUBE, SURFACE TENSION, AND OTHER PROPERTIES OF THE GAS AND LIQUID.

*FILM, LIQUID + *FLOW THEORY AND EXPERIMENTS + HEAT TRANSFER + HYDRODYNAMIC ANALYSIS + PRESSURE DROP

5-11393 BENTLEY PG + CAWSON DG
FLUID FLOW MEASUREMENT BY TRANSIT TIME ANALYSIS OF TEMPERATURE FLUCTUATIONS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
TRG-1155 (R) +. 24 PAGES, 15 FIGURES, 7 REFERENCES, FEBRUARY 15, 1966, UKAEA

THIS REPORT DESCRIBES INVESTIGATIONS INTO A METHOD OF FLOW MEASUREMENT BASED ON THE TRANSPORT OF NATURALLY OCCURRING TEMPERATURE PATTERNS IN A FLUID STREAM (AS IN THE CORE OF A NUCLEAR REACTOR). TEMPERATURE FLUCTUATIONS ARE DETECTED BY TWO THERMOCOUPLES SPACED ALONG THE FLOW DIRECTION AND ARE ANALYSED EITHER BY A CROSS-SPECTRUM ANALYSER WHICH GIVES THE PHASE ANGLE SEPARATION AS A FUNCTION OF FREQUENCY OR BY A METHOD OF ANALYSIS WHICH MEASURES THE TIME INTERVAL BETWEEN ZERO CROSSINGS DIRECTLY. LABORATORY MEASUREMENTS SHOW THAT THE METHOD MEASURES THE MEAN FLUID VELOCITY OR TOTAL FLOW AND IS LARGELY INDEPENDENT OF THE PIPE GEOMETRY. RIG MEASUREMENTS SHOW THAT SUFFICIENTLY LARGE TEMPERATURE FLUCTUATIONS OCCUR NATURALLY AND THAT MEASUREMENTS ARE POSSIBLE IN PRACTICE. THE ACCURACY IS ESTIMATED TO BE A FEW PERCENT FOR A MEASUREMENT TAKING 10 MIN OR LONGER.

*FLOW THEORY AND EXPERIMENTS + *INSTRUMENTATION, FLOW + FLUCTUATION + TEMPERATURE TRANSIENT + TRANSFER FUNCTION

5-11395 FORGAN R + WHITTLE RH
PRESSURE-DROP CHARACTERISTICS FOR THE FLOW OF SUBCOOLED WATER AT ATMOSPHERIC PRESSURE IN NARROW HEATED CHANNELS, PART I
ATOMIC ENERGY RESEARCH ESTABLISHMENT, HARWELL
AERE-M-1739 +. 83 PAGES, 2 TABLES, 33 FIGURES, 7 REFERENCES, MAY 1966, BIS, \$2.60

MEASUREMENTS HAVE BEEN MADE OF THE PRESSURE-DROP FLOW CHARACTERISTICS FOR SUBCOOLED WATER IN NARROW HEATED CHANNELS, TO PROVIDE DATA ON SUBCOOLED-BOILING PRESSURE DROP AND IN PARTICULAR TO LOCATE THE MINIMUM IN THE CHARACTERISTIC CURVES. ON THIS KNOWLEDGE ASSESSMENTS OF THE ONSET OF EXCURSIVE TYPE FLOW INSTABILITY CAN BE MADE. THE EXPERIMENTS WERE DONE ON A SINGLE CHANNEL 24 IN. LONG X 1.0 IN. X 0.127 IN. COOLANT VELOCITIES RANGED FROM 6-FT-S TO 24-FT-S AND HEAT FLUXES FROM 82 WATTS/CM² TO 250 WATTS/CM². FOR THIS LIMITED RANGE OF PARAMETERS, IT WAS FOUND THAT THE MINIMUM IN THE PRESSURE-DROP/FLOW CURVES ALWAYS OCCURRED WHEN THE TEMPERATURE RISE OF THE COOLANT IN THE CHANNEL WAS 0.8 (SATURATION TEMPERATURE AT OUTLET - INLET TEMPERATURE).

*BURNOUT HEAT FLUX + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *HEAT TRANSFER, BOILING + *PRESSURE DROP + FLOW STABILITY

5-11396 LEMCOE M
STUDY OF INSTANTANEOUS COLLAPSE AND CREEP BUCKLING CHARACTERISTICS OF LARGE SGR PROCESS TUBES
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-11323 +. 47 PAGES, 4 TABLES, REFERENCES, JULY 25, 1965, CFSTI \$3.00 CY, \$0.50 MN

THE INSTANTANEOUS COLLAPSE (LESS THAN 0.2 HR) AND CREEP-BUCKLING CHARACTERISTICS (UP TO 5000 HR) OF TYPE 304 STAINLESS STEEL TUBES (4.00 IN. IN OD, WITH 0.025-IN. WALL), UNDER EXTERNAL RADIAL PRESSURE AND VARYING AXIAL LOAD, WERE DETERMINED AT TEMPERATURES UP TO 1200 F IN AN ARGON ENVIRONMENT. THE LENGTH OF EACH TUBE WAS 6 FT, WHICH IS ESSENTIALLY INFINITE IN TERMS

CATEGORY 5
ACCIDENT ANALYSIS

5-11396 *CONTINUED*

OF BUCKLING. IN ADDITION, TUBES IN COMBINATION WITH FUEL-ELEMENT BUNDLES CORRESPONDING TO THOSE PROPOSED FOR A LARGE SODIUM GRAPHITE REACTOR (LSGR) WERE ALSO INVESTIGATED TO DETERMINE THE EXTENT TO WHICH THE FUEL-ELEMENT BUNDLE INCREASED THE RESISTANCE TO COLLAPSE OF THE PROCESS TUBE. THE RESULTS OF THE STUDY INDICATED THAT STIFFENER RINGS OR THICKER-WALLED TUBES SHOULD NOT BE NECESSARY UNDER NORMAL OPERATING CONDITIONS.

*PIPING + *STEEL, STAINLESS + BUCKLING + REACTOR, LIQUID METAL COOLED

5-11405 JENSEN SE

THE EFFECTS OF METAL WATER REACTIONS ON THE LOSS OF COOLANT ACCIDENT
PHILLIPS PETROLEUM COMPANY

IDO-17168 +. 99 PAGES, 35 FIGURES, 3 TABLES, 36 REFERENCES, AUGUST 1966, CFSTI \$4.00 CY

PHILLIPS UNDERTOOK AN ANALYSIS OF THE POTENTIAL EFFECTS OF ZIRCALOY-4-WATER REACTIONS ON THE LOSS-OF-COOLANT TEST, BASED ON THE RATE-LIMITING MECHANISMS WHICH CONTROL THE REACTION AND THE CALCULATION OF THE RATE AND EXTENT OF THE REACTION AS FUNCTIONS OF SPACE AND TIME. THE RATE-LIMITING PHENOMENA, PARTICULARLY STEAM AVAILABILITY, TEND TO REDUCE THE RATE AT WHICH THE REACTION CAN OCCUR, THUS SPREADING THE REACTION AND ITS ASSOCIATED ENERGY RELEASE OVER A LONGER TIME. BECAUSE OF ITS FUNDAMENTAL BASIS, THE DISCUSSIONS HAVE BEEN KEPT GENERAL IN NATURE, AND VARIOUS SITUATIONS NOT DIRECTLY RELATED TO LOFT ARE EXAMINED.

*ACCIDENT ANALYSIS + *LOSS OF COOLANT + *METAL WATER REACTION + LOFT (LOSS OF FLUID TEST) +
NRTS (NATIONAL REACTOR TEST STATION) + ZIRCALOY

5-11411 PASCOUET A

NUCLEAR-POWER-EXCURSION SIMULATION IN FRANCE

COMMISSARAT A L ENERGIE ATOMIQUE

6 PAGES, 9 FIGURES, 1 TABLE, NUCLEAR SAFETY 7(1), PAGES 20-25 (FALL 1965)

AN INVESTIGATION AT THE FRENCH ATOMIC ENERGY COMMISSION OF MEANS FOR SIMULATING NUCLEAR POWER EXCURSIONS LED TO THE DEVELOPMENT OF EXPLOSIVE SIMULATION CHARGES WITH TIME-DEPENDENT POWER RELEASES. RELEASE COMPARABLE WITH THE MAXIMUM BORAX-I POWER RELEASE IS OBTAINED WITHIN A GIVEN VOLUME. THE DATA ARE IN GOOD AGREEMENT WITH THOSE DEDUCTED FROM EXPERIMENTS PERFORMED IN THE UNITED STATES ON VARIOUS REACTORS AND HAVE BEEN USED TO ESTABLISH LIKELY ORDERS OF MAGNITUDE FOR THE MECHANICAL STRUCTURAL RESPONSE. THE SIMULATION PROVIDES FOR THE EXPERIMENTAL INVESTIGATION OF BOILING PHENOMENA NEAR FUEL PLATES, AND CLADDING BEHAVIOR DURING REACTOR TRANSIENTS.

*DESTRUCTIVE TRANSIENT + *FRANCE + *SIMULATION + REACTOR KINETICS + REACTOR, WATER

5-11455 FAUSKE HK

FLUID AND THERMAL TECHNOLOGY - COMPRESSIBILITY AFFECTS FLOW INSTABILITY AND BURNOUT
ARGONNE NATIONAL LABORATORY, ARGONNE

4 PAGES, 7 FIGURES, 11 REFERENCES, POWER REACTOR TECHNOLOGY, 9(2), PAGES 65-68, SPRING 1966

THE PROBLEM OF EVALUATING ACCURATELY THE BURNOUT HEAT FLUX (MAXIMUM OR CRITICAL) AND FLOW INSTABILITIES IN FORCED-CONVECTION BOILING SYSTEMS HAS RECEIVED A GREAT DEAL OF ATTENTION IN THE LAST 10 YEARS, PRIMARILY BECAUSE OF THE NEED FOR BETTER CORRELATIONS IN REACTOR DESIGN. HOWEVER, THE RESULTS OBTAINED TO DATE FORM A SOMEWHAT CONFUSED PICTURE. THERE ARE NUMEROUS WIDELY DIFFERING CORRELATIONS AND CONTRADICTORY CONCLUSIONS. THIS IS LARGELY BECAUSE UNSTABLE BEHAVIOR AND PREMATURE BURNOUT CAN BE CAUSED BY A NUMBER OF MECHANISMS THAT ARE NOT ALWAYS PROPERLY ACCOUNTED FOR. THIS ARTICLE DEALS WITH THE IMPORTANCE OF INCLUDING COMPRESSIBILITY EFFECTS WHEN TWO-PHASE FLOW DATA ARE BEING INTERPRETED.

*BURNOUT HEAT FLUX + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *FLOW STABILITY + *HEAT TRANSFER, BOILING +
HEAT TRANSFER + PRESSURE, INTERNAL

5-11456 SMITH FA

COMPONENTS - INTERPRETING THE FRENCH LIQUID-METAL-HEATED STEAM-GENERATOR PROGRAM

ARGONNE NATIONAL LABORATORY, ARGONNE

5 PAGES, 3 FIGURES, 16 REFERENCES, POWER REACTOR TECHNOLOGY, 9(2), PAGES 69-73, SPRING 1966

DEVELOPMENT OF RELIABLE AND ECONOMICAL SODIUM-HEATED STEAM GENERATORS IS CONSIDERED A MAJOR PROBLEM OF SODIUM (FAST REACTOR) TECHNOLOGY IN THE UNITED STATES AND FRANCE. BRIEFLY, THE FRENCH AND U. S. LIQUID-METAL STEAM-GENERATOR PROGRAMS ARE SIMILAR IN THAT BOTH USE ONCE-THROUGH UNITS AT COMPARABLE TEMPERATURE AND PRESSURE RANGES. FURTHER, BOTH PROGRAMS EMPLOY NONNUCLEAR TEST FACILITIES FOR DETAILED ENGINEERING EVALUATIONS OF POSSIBLE LEAKAGE. ESSENTIAL DIFFERENCES ARE IN THE DESIGN APPROACH (THE FRENCH USE A CONFIGURATION OF PIPE HEADERS AND TUBES RATHER THAN TUBES AND TUBE SHEETS IN A SHELL DESIGN) AND IN THE CONSTRUCTION MATERIALS FOR BOTH WATER AND SODIUM SIDES. ANOTHER DIFFERENCE IS IN THE SIZE OF TEST INSTALLATIONS, 5 MW(T) FOR FRENCH TESTS AND 35 FOR U. S. TESTS.

*HEAT EXCHANGER + *METAL, LIQUID + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + SODIUM

5-11466 STEVENS GF + WOOD RW

A COMPARISON BETWEEN BURN-OUT DATA FOR 19-ROD CLUSTER TEST-SECTIONS COOLED BY FREON-12 AT 155 POUNDS PER SQUARE INCH (ABS) AND BY WATER AT 1000 PER SQUARE INCH IN VERTICAL UPFLOW
UNITED KINGDOM ATOMIC ENERGY ASSOCIATION, WINFRITH

AEW-R-468 +. 61 PAGES, 6 TABLES, REFERENCES, JANUARY 1966, BIS \$2.00 CY

ACCESSION NUMBER 5-11396 TO 5-11466

CATEGORY 5
ACCIDENT ANALYSIS

5-11466 *CONTINUED*

THE SCALING FACTORS OBTAINED FROM THE WINFRITH FREON RIG WERE TESTED AGAINST DATA FOR 19-ROD CLUSTERS THAT HAD PREVIOUSLY BEEN TESTED AT COLUMBIA UNIVERSITY. THIS REPORT PRESENTS THE RESULTS OF THE ROD-CLUSTER TESTS IN WHICH COMPARISON IS MADE BETWEEN FREON-12 AND WATER FOR THREE TEST-SECTIONS THAT DIFFER IN THE MEANS OF SPACING THE INDIVIDUAL RODS. ALL THE TEST SECTIONS WERE HEATED UNIFORMLY WITH RESPECT TO LENGTH, BUT HAD A RADIAL FLUX DEPRESSION OF NOMINALLY 0.70/1.0. THE RESULTS PROVIDE STRONG EVIDENCE THAT THE SCALING-FACTOR METHOD USING FREON-12 AT 155 PER SQ. IN. (ABS) IS USEFUL FOR PREDICTING THE BEHAVIOUR AT BURNOUT OF COMPLICATED TEST SECTIONS COOLED BY BOILING WATER AT 1000 LB PER SQ. IN. WITH ONLY ONE-EIGHTEENTH OF THE POWER REQUIRED FOR THE WATER EXPERIMENT. IN PARTICULAR, THE FREON TESTS REPRODUCE CLOSELY THE RELATIVE BURNOUT POWERS PREVIOUSLY MEASURED FOR WATER.

*BURNOUT HEAT FLUX + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *HEAT TRANSFER, BOILING + FUEL ELEMENT + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT

5-11469 BURKOVIC ES + MIKHAILOV IF + KOSIK NA
INVESTIGATION OF THE PROCESS OF HEAT TRANSFER AND PRESSURE DROP IN COIL-PIPE COUNTERFLOW HEAT EXCHANGERS
LA-TR-66-25 +. 20 PAGES, 4 FIGURES, 3 TABLES, 7 REFERENCES, TRANSLATED FROM UKRAINS KYI FIZYCHNYI ZHURNAL
9(7) PP 749-58 (1964), CFSTI \$1.00 CY, \$0.50 MN

DISCUSSES THE RESULTS OF EXPERIMENTS ON HEAT TRANSFER AND PRESSURE DROP IN COUNTER-FLOW HEAT EXCHANGERS CONSISTING OF PIPES OF VARIOUS DIAMETERS SOLDERED TOGETHER AT THE THERMAL CONTACT AND COILED. PROVIDES SIMPLIFIED EQUATIONS AND SOME DATA FOR THE DESIGN OF SUCH HEAT EXCHANGERS.

*FLOW, TUBE + *HEAT EXCHANGER + *HEAT TRANSFER, CONVECTION + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER CORRELATION + HEAT TRANSFER EXPERIMENT

5-11474 NA TY + ARPACI VS + CLARK JA
THE INFLUENCE OF LOCALIZED, NORMAL SURFACE OSCILLATIONS OF THE STEADY LAMINAR FLOW OVER A FLAT PLATE
UNIVERSITY OF MICHIGAN, ANN ARBOR
ARL-66-0010, PART II +. 123 PAGES, 36 FIGURES, 32 REFERENCES, JANUARY 1966, DDC

THE STEADY, LAMINAR FLOW OF AN INCOMPRESSIBLE FLUID OVER A LOCALLY VIBRATING SEMI-INFINITE FLAT PLATE WAS ANALYZED. THE PROBLEM WAS FORMULATED IN THE CO-ORDINATE SYSTEM FIXED TO THE PLATE. THE FORMULATION WAS SIMPLIFIED BY CONSIDERING THE UNSTEADY FLOW TO BE OF THE BOUNDARY-LAYER TYPE. THE RESULTING EQUATIONS FOR THE UNSTEADY BOUNDARY LAYER WERE LINEARIZED BY MEANS OF A PERTURBATION PROCEDURE. THE FIRST THREE APPROXIMATIONS WERE SOLVED BY THE INTEGRAL METHOD. IT WAS FOUND THAT THE PHASE OF SKIN FRICTION IN RELATION TO THE INPUT DISTURBANCE IS APPROXIMATELY ZERO, WHILE THAT OF HEAT TRANSFER LAGS APPROXIMATELY $\pi/2$ RADIANS. THE TIME-AVERAGED VALUE OF THE SKIN FRICTION IS SLIGHTLY GREATER THAN ITS STEADY VALUE IN THE ABSENCE OF OSCILLATIONS. THE TIME-AVERAGED HEAT TRANSFER, HOWEVER, IS SLIGHTLY LESS THAN ITS CORRESPONDING STEADY VALUE. IT WAS ALSO FOUND THAT THE LOCALIZED OSCILLATIONS INCREASES THE FLOW INSTABILITY LOCALLY. THE PHYSICAL INTERPRETATION OF THE RESTRAINTS ON THE ANALYSIS ARE DISCUSSED IN APPENDIX IV.

*FLOW, LAMINAR + *VIBRATION + FLOW THEORY AND EXPERIMENTS + HEAT TRANSFER + HEAT TRANSFER ANALYSIS + HEAT TRANSFER EXPERIMENT + HEAT TRANSFER, CONVECTION

5-11475 FRIND G
ELECTRIC ARCS IN TURBULENT FLOWS, II
GENERAL ELECTRIC COMPANY, PHILADELPHIA
ARL-66-0073 +. 46 PAGES, 24 FIGURES, 13 REFERENCES, APRIL 1966, DDC

TURBULENT HEAT TRANSFER IN AXIAL FLOW ELECTRICAL ARCS WAS EXPERIMENTALLY STUDIED. THE ARCS WERE OPERATED WITH ARGON IN THE CURRENT RANGE OF 10 TO 100 AMP, WITH PRESSURES OF 1 TO 10 ATM, AND WITH FLOW RATES OF 0.02 TO 35 GRAMS/SEC. THE FLOW TUBES WERE 75 CM LONG AND HAD INNER DIAMETERS OF 0.5 AND 1.0 CM. IT WAS FOUND THAT THE ARC POTENTIAL INCREASED LINEARLY ALONG MOST OF THE TUBE LENGTH FOR ALL FLOW RATES. ALSO, CALORIMETRIC MEASUREMENTS AT THE END OF A FLOW TUBE WITH 0.5-CM DIAMETER SHOWED CLOSE AGREEMENT BETWEEN WALL HEAT FLUX AND ELECTRICAL INPUT PER CM FOR ALL FLOW RATES. THIS, TOGETHER WITH A CAREFUL ESTIMATE OF THE REMAINING FLOW TERMS, SHOWED THAT A FULLY DEVELOPED TEMPERATURE PROFILE HAD BEEN ACHIEVED. THE ARCS AT HIGH FLOW RATES SHOWED CONSIDERABLY LARGER ELECTRICAL GRADIENTS THAN THE ARCS AT LOW FLOW RATES. IN ADDITION, HIGH-SPEED PHOTOGRAPHS REVEALED THAT INCREASED ELECTRICAL GRADIENTS WERE ACCOMPANIED BY THE ONSET OF DISTURBANCES OF THE PLASMA COLUMN. AT CONDITIONS OF THE HIGHEST FLOW RATES AND ELECTRICAL GRADIENTS ACHIEVED, THE ARCS APPEARED TO BE STRONGLY TURBULENT, WITH THE ARC COLUMN BROKEN UP INTO PLASMA GLOBULES OF IRREGULAR SIZES.

*FLOW, TUBE + *FLOW, TURBULENT + FLOW THEORY AND EXPERIMENTS + FLOW, LAMINAR + HEAT TRANSFER

5-11539 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 7 PAGES, PAGES A.1 TO A.7, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

APPENDIX A - FUEL TEMPERATURE DURING PRIMARY SYSTEM BLOWDOWN. RECIRCULATION LINE BREAK IS SHOWN TO LAST 13 SEC UNTIL A PRESSURE OF 63 PSIA IS REACHED. THE K WAS ASSUMED TO BE 100 BTU/HR-DEG F-SQ. FT UNTIL SUPERHEAT WAS REACHED, AND THEN K WAS ASSUMED EQUAL TO 10.

*LOSS OF COOLANT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + HYDRODYNAMIC ANALYSIS + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

CATEGORY 5
ACCIDENT ANALYSIS

5-11670 AULETA JJ
PIQUA MAIN HEAT TRANSFER SYSTEM COMPONENT ANALYSIS PROGRAM
ATOMICS INTERNATIONAL, CANOGA PARK, CALIFORNIA
39 PAGES, JANUARY 28, 1964, DOCKET 115-2 CFSTI \$4.60 FS, \$1.46 MF

STANDARD EVALUATION METHODS, USING A FORTRAN PROGRAM, ARE PRESENTED FOR THE ROUTINE PERFORMANCE CHECKING OF THE MAIN HEAT-TRANSFER PUMPS AND THE STEAM GENERATOR. A ROUTINE SURVEILLANCE OF THE PERFORMANCE OF THE MAIN HEAT-TRANSFER SYSTEM AND ITS COMPONENTS IS A MEANS OF OBTAINING WARNING OF ANOMALIES OR MALFUNCTIONS OF THIS SYSTEM.

*HEAT TRANSFER ANALYSIS + HEAT EXCHANGER + PIQUA + PUMP + REACTOR, ORGANIC COOLED

5-11739 H B ROBINSON UNIT NO. 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT - VOL. III. PLANT DESIGN DESCRIPTION AND SAFETY ANALYSIS
CAROLINA POWER AND LIGHT COMPANY
240 PAGES, 110 FIGURES, 34 TABLES, JULY 1966, DOCKET NO. 50-261, PDR

(1) IN-CORE INSTRUMENTATION WILL CONSIST OF CHROMEL-ALUMEL OUTLET-TEMPERATURE SENSORS AND MOVABLE MINIATURE FISSION CHAMBERS. REACTOR WILL BE CONNECTED TO SYSTEM LOAD DISPATCH. LOSS OF LOAD WILL NOT CAUSE TURBINE TRIP BECAUSE OF CONTROLLED STEAM DUMP. (2) A DOUBLE-ENDED PIPE RUPTURE WAS SHOWN TO RESULT IN 1 REM THYROID DOSE IN 2 HOURS AT THE SITE BOUNDARY WHERE ABOUT 10 PERCENT OF THE CORE INVENTORY EXCEEDS 2500 F AND RELEASES THE ISOTOPIC FRACTIONS NOTED IN TID-14844 AND WHERE THE 0.1 PERCENT PER DAY LEAKAGE EXISTS FOR ONLY 1 MIN UNTIL ISOLATION AND SEAL-WATER ARE EFFECTIVE. AS TO THE COMPLETE CORE MELTDOWN AND CONTINUED CONTAINMENT LEAK OF 0.1 PERCENT PER DAY, THIS WOULD YIELD 23 REMS OF IODINE DOSE AT THE SITE BOUNDARY WITH TWO CONTAINMENT SPRAYS SPRAYING NA2S2O3, OR 53 REMS WITH ONLY ONE SPRAY. ALSO, THE 2-HR THYROID DOSE IS LESS THAN 300 REMS IF A SPRAY PUMP IS STARTED 30 MIN AFTER THE ACCIDENT OR IF THE CONTAINMENT IS SEALED AFTER 40 MIN.

*CONTAINMENT PENETRATION, CLOSURE OF + *CONTAINMENT SPRAY + *SAFEGUARDS REPORT, PRELIMINARY + INSTRUMENTATION, IN CORE + LOSS OF COOLANT + REACTOR, PRESSURIZED WATER + ROBINSON

5-11748 LIEBENBERG OH
MEASUREMENT OF AN ENHANCED HE II FILM FLOW RATE FROM A TURBULENT BATH
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-3492 +. 11 PAGES, 2 FIGURES, 1 TABLE, 10 REFERENCES, DECEMBER 5, 1965, CFSTI, \$1.00 CY, \$0.50 MN

OBSERVATIONS ARE REPORTED OF THE THICKNESS OF THE SUPERFLUID HELIUM FILM ON A METAL SURFACE VS HEIGHT ABOVE THE BATH. THE MEASUREMENTS ARE MADE BY RECORDING THE TIME THAT HELIUM TAKES TO FLOW ONTO A KNOWN SURFACE AREA WHEN SUPPLIED BY A LIMITING PERIMETER. THE FLOW OF THE FILM IS MARKEDLY DIFFERENT, DEPENDING ON THE HISTORY OF THE HELIUM. WE SPECULATE ON THE INTERPRETATION OF THESE DATA BASED ON THE PHASE-COHERENCE PROPERTIES BETWEEN TWO FILM-CONNECTED BATHS OF SUPERFLUID HELIUM.

*FLOW THEORY AND EXPERIMENTS + FILM, LIQUID + FLOW, TURBULENT + HEAT TRANSFER + HELIUM + SURFACE, GENERAL

5-11749 ST. PIERRE CC
FREQUENCY-RESPONSE ANALYSIS OF STEAM VOIDS TO SINUSOIDAL POWER MODULATION IN A THIN-WALLED BOILING WATER COOLANT CHANNEL
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
ANL-7041 +. 148 PAGES, 32 FIGURES, 7 TABLES, MAY 1965, CFSTI \$5.00 CY, \$1.00 MN

THE PRINCIPAL OBJECTIVE OF THIS STUDY WAS TO ACQUIRE EXPERIMENTAL DATA ON POWER-TO-VOID TRANSFER FUNCTIONS FOR A SINGLE RECTANGULAR FLOW-CHANNEL AT ELEVATED PRESSURES. AN OUT-OF-PILE OR BOILING LOOP WAS OPERATED IN FORCED CIRCULATION FOR VARIOUS FIXED PRESSURES, INLET FLOW RATES, AND TEMPERATURES, AND THE POWER WAS MODULATED SINUSOIDALLY AROUND A STEADY-STATE POWER LEVEL. THEN THE AMPLITUDE AND PHASE OF THE VOID RESPONSE WERE MEASURED AT VARIOUS AXIAL AND TRANSVERSE POSITIONS OF THE CHANNEL, EMPLOYING A CROSS-CORRELATION TECHNIQUE OVER THE FREQUENCY RANGE FROM 0.01 TO 5 CPS. THROUGH AN ANALYSIS OF THE DATA PLOTTED IN BODE DIAGRAM FORM, INFORMATION WAS OBTAINED AS TO THE PROPAGATION VELOCITY OF VOID PERTURBATIONS, THE RANGE OF LINEARITY OF THE VOID RESPONSE TO POWER MODULATION, THE SHAPE OF THE AXIAL VARIATION OF TRANSIENT VOID AMPLITUDES, AND THE BREAK FREQUENCY OF THE TRANSFER FUNCTION. MEASUREMENTS OF POWER-TO-VOID TRANSFER FUNCTIONS WERE MADE IN A VERTICAL, RECTANGULAR, ELECTRICALLY HEATED TEST SECTION IN WHICH FOUR MAIN CONDITIONS WERE VARIED - PRESSURE (200-800 PSIA), INLET FLOW RATES (2.52-3.78 FT/SEC) HEAT FLUXES (22,800 TO 91,200 BTU/HR-FT SQUARED, AND INLET SUBCOOLINGS (0.8 TO 12.4 F). DATA WERE OBTAINED AT THREE AXIAL POSITIONS AND ALSO AT VARIOUS TRANSVERSE POSITIONS ACROSS THE WIDTH OF THE CHANNEL FOR A FIXED AXIAL HEIGHT.

*FLOW, TWO PHASE + FLOW STABILITY + FLUCTUATION + HEAT TRANSFER + HEAT TRANSFER, BOILING + STEAM + TRANSFER FUNCTION + VOID COEFFICIENT

5-11755 VAN GASSELT ML + VAN MEEL DA
RESEARCH ON THE INFLUENCE ON THE CONDITIONS OF FLOW, SUBCOOLING AND COMPOSITION, ON THE BURN-OUT HEAT FLUX OF POLYPHENYL REACTOR COOLING AGENTS
CENTRAL TECHNICAL INSTITUTE T.N.O., NETHERLANDS
EUR-2299.E +. 23 PAGES, 1965, DEP. MN

THIS REPORT PRESENTS AN EXPERIMENTAL INVESTIGATION ON THE EFFECTS OF FLOW, SUBCOOLING, AND COMPOSITION ON THE BURNOUT HEAT FLUX OF POLYPHENYL REACTOR COOLANTS.

*BURNOUT HEAT FLUX + *ORGANIC COOLANT + CHEMICAL ANALYSIS + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT

CATEGORY 5
ACCIDENT ANALYSIS

5-11756 UCHIDA H
EXPERIMENTAL INVESTIGATION OF CORE SPRAY
UNIVERSITY OF TOKYO
6 PAGES, 7 FIGURES, 1 TABLE, 1 REFERENCE, NUCLEAR SAFETY 7(3), PAGES 330 342, (SPRING 1966)

EXPERIMENTAL INVESTIGATIONS OF CORE-SPRAY COOLING FOR ELECTRICALLY HEATED SIMULATED FUEL-ELEMENT ASSEMBLIES ARE DISCUSSED. THE PURPOSE OF A CORE SPRAY IS TO PREVENT A SUDDEN TEMPERATURE RISE OF THE FUEL ELEMENTS IN A LIGHT-WATER-MODERATED REACTOR FOLLOWING A LOSS-OF-COOLANT ACCIDENT. THE SPRAY COOLS THE HEATED RODS BY EVAPORATION OF A WATER FILM FLOWING DOWN ACROSS THE SURFACE. AS THE HEAT INCREASES BEYOND A CERTAIN POINT, THE LOWER PARTS OF THE RODS DRY OWING TO COMPLETE EVAPORATION AND TO THE FACT THAT FURTHER DOWNWARD FLOW OF WATER THROUGH THE CHANNELS IS PREVENTED BY THE UPWARD FLOW OF STEAM.

*CORE SPRAY + CORE MELTDOWN + DROPLET + HEAT TRANSFER + HEAT TRANSFER EXPERIMENT + SPRAY, GENERAL

5-11757 WIERELT JA
ENGINEERING RADIATION HEAT TRANSFER
OKLAHOMA STATE UNIVERSITY
278 PAGES, 1966 HOLT, RINEHART AND WINSTON INC., NEW YORK, CHICAGO, SAN FRANCISCO, TORONTO, LONDON, \$9.50 CY

THIS BOOK IS AN ATTEMPT TO ASSEMBLE AND CLASSIFY A PORTION OF THE LITERATURE, PAST AND PRESENT, OF IN-PAKED ENERGY TRANSMISSION. INFRARED OR THERMAL RADIATION ACTIVITIES HAVE BEEN SO STIMULATED BY SPACE APPLICATIONS THAT THE LITERATURE IS GROWING VERY RAPIDLY. FOR THIS REASON THE BOOK ATTEMPTS TO LAY A FOUNDATION FOR FURTHER STUDY, RATHER THAN TO TREAT COMPREHENSIVELY MORE COMPLICATED DESIGN CHARACTERISTICS. TOPICS COVERED INCLUDE THE FOLLOWING - BASIC OPTICS, ELECTROMAGNETIC WAVE THEORY, BASIC DEFINITIONS, THERMODYNAMIC RADIATION LAWS, CHARACTERISTICS OF BLACK AND REAL SYSTEMS, ENERGY EXCHANGE CONCEPTS AND GEOMETRIC FACTORS, FLUX ALGEBRA, ENERGY EXCHANGE IN GRAY ENCLOSURES WITHOUT GASES, METHOD OF SOLVING INTEGRAL EQUATIONS, FINITE-DIFFERENCE APPROXIMATIONS FOR INTEGRAL EQUATIONS, NONGRAY SYSTEMS OR NONDIFFUSE SYSTEM ANALYSIS, ENERGY TRANSFER IN ABSORBING AND EMITTING MEDIA, AND RADIATION EQUIPMENT, SUCH AS DETECTORS, SOURCES, PYROMETERS, AND PROPERTY-MEASUREMENT APPARATUS.

*HEAT TRANSFER + *HEAT TRANSFER, RADIANT

5-11758 QUINN EP
TRANSITION BOILING HEAT TRANSFER PROGRAM. QUARTERLY PROGRESS REPORT, JANUARY - MARCH 1965
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
GEAP-4843 + EURAEC-1372 +. 15 PAGES, APRIL 1, 1965, CFSTI \$1.00 CY

THIS REPORT IS ONE OF A SERIES OF REPORTS ON THE FOLLOWING SUBJECTS - SIMULATED FUEL-GEOMETRY TESTS, EFFECT OF LOOP CHARACTERISTICS ON TRANSITION BOILING, OBSERVATIONAL STUDY OF TRANSITION BOILING, REACTOR-TRANSIENT THERMAL PROPERTIES SIMULATION, MULTI-ROD TESTS.

*CONVECTIVE BOILING + *HEAT TRANSFER, BOILING + FLOW THEORY AND EXPERIMENTS + FLOW, TWO PHASE + FUEL ELEMENT + HEAT TRANSFER

5-11759 TWO-PHASE FLOW AND HEAT TRANSFER IN MULTIROD GEOMETRIES. FOURTH AND FIFTH QUARTERLY PROGRESS REPORTS. JULY 26, 1965-JANUARY 25, 1966.
GENERAL ELECTRIC COMPANY, ATOMIC POWER EQUIPMENT DEPARTMENT, SAN JOSE, CALIFORNIA
GEAP-5056 +. 35 PAGES, FEBRUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

GENERAL ELECTRIC ATOMIC POWER EQUIPMENT DEPARTMENT, PROGRESS REPORT, JULY 1965 TO JANUARY 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE FOLLOWING SUBJECTS - MEASUREMENTS OF THE STRUCTURE OF TWO-PHASE FLOW, AIR-WATER MIXTURES IN VERTICAL ANNULI, AIR-WATER MIXTURE IS A VERTICAL NINE-ROD ASSEMBLY, AND STEAM-WATER MIXTURES AT HIGH PRESSURES (600 TO 1400 PSIA) IN A VERTICAL NINE-ROD ASSEMBLY.

*FLOW, TWO PHASE + *HEAT TRANSFER, BOILING + ANNULUS + FUEL ELEMENT + HEAT TRANSFER + PRESSURE DROP

5-11760 HESSON GM
DETERMINATION OF MAXIMUM NUCLEAR TUBE POWERS BASED ON BOILING BURNOUT
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-176 +. 17 PAGES, 5 FIGURES, DECEMBER 1965, CFSTI \$1.00 CY

THIS REPORT PROPOSES A PROCEDURE FOR CALCULATING THE MAXIMUM TUBE POWER OF A PRESSURE-TUBE REACTOR, BASED ON BOILING BURNOUT. A PRIMARY PURPOSE OF DEVELOPING THIS PROCEDURE IS TO PROVIDE A METHOD FOR CALCULATING MAXIMUM TUBE POWERS FOR THE PLUTONIUM RECYCLE TEST REACTOR (PRTR) WHICH IS FLEXIBLE ENOUGH TO EASILY ACCOMMODATE CHANGES IN REACTOR CONDITIONS AND TO INCORPORATE NEW KNOWLEDGE AS IT BECOME AVAILABLE.

*PRTR (PLUTONIUM RECYCLE TEST REACTOR) + BURNOUT HEAT FLUX + DNB (DEPARTURE FROM NUCLEATE BOILING) + HEAT TRANSFER + HEAT TRANSFER, BOILING + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

5-11761 KEETON DC + SMITH D
TRANSIENT CALCULATIONS FOR THE EGCR BASE CASE ACCIDENT
TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE
TID-22755 +. 25 PAGES, NOVEMBER 13, 1964, CFSTI \$1.00 CY, \$0.50 MN

CATEGORY 5
ACCIDENT ANALYSIS

5-11761 *CONTINUED*

THIS REPORT DESCRIBES RESULTS OF CALCULATIONS MADE TO DETERMINE THE RESULTING TRANSIENT POWER GENERATION AND CORE TEMPERATURES FOLLOWING THE REATTAINMENT OF CRITICALITY AFTER THE MAXIMUM CREDIBLE ACCIDENT (MCA). SEVERAL PHYSICAL PARAMETERS OF THE CORE, ALONG WITH VARIOUS REACTIVITY RELEASE RATES, WERE EXAMINED TO DETERMINE THEIR EFFECT ON THE TRANSIENT. IT WAS CONCLUDED THAT IT IS POSSIBLE TO REGAIN CRITICALITY AFTER THE EGCR MCA. IMMEDIATELY AFTER THE DEPRESSURIZATION ACCIDENT, CONTROL RODS ARE INSERTED IN THE CORE, AND THE REACTOR IS SUBCRITICAL. THERE ARE THREE POSSIBLE WAYS TO ADD REACTIVITY TO THE CORE TO CAUSE THE REATTAINMENT OF CRITICALITY. THESE ARE (1) FUEL-CLAD MELTING RESULTING IN LOSS OF STAINLESS-STEEL POISON, (2) HEATING OF THE LOWER CORE-SUPPORT STRUCTURE SO THAT THE CORE SAGS AWAY FROM THE SUSPENDED CONTROL RODS, AND (3) LOSING CONTROL-ROD POISON BY OXIDATION OR MELTING OF THE BORON CARBIDE.

*ACCIDENT, CRITICALITY + *CORE MELTDOWN + *EGCR (EXPERIMENTAL GAS COOLED REACTOR) +
ACCIDENT, MAXIMUM CREDIBLE (MCA) + HEAT TRANSFER + LOSS OF COOLANT

5-11805 CHANGE 22, ADDENDUM A. - FULL-TIME AVAILABILITY OF EMERGENCY CONDENSER (DURING REACTOR OPERATION) IN THE EVENT OF A TSUNAMI (TIDAL WAVE).
PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
4 PAGES, OCTOBER 3, 1966, DOCKET NO. 50-133, PDR

FURTHER REVIEW OF PROTECTION AGAINST TIDAL WAVES INDICATES THAT THE EMERGENCY CONDENSER SHOULD BE IN SERVICE ANYTIME THE REACTOR OPERATES.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + EMERGENCY COOLING + HUMBOLDT BAY + REACTOR, BOILING WATER + SEISMOLOGY

5-11820 TAYLOR AF
THE INVESTIGATION OF REACTOR FLOW PROBLEMS USING MODELLING TECHNIQUES
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
4 PAGES, ATOM NUMBER 119, PAGES 195-197 + 212 (SEPTEMBER 1966)

BRIEFLY DESCRIBES THE USE OF AIR AND WATER IN FULL-SCALE MODELS TO STUDY FLOW PROBLEMS.

*HYDRODYNAMIC ANALYSIS + MOCKUP + REACTOR, POWER + TESTING + UNITED KINGDOM

5-11990 PRTR ELEMENT HYDRIDING FROM FINGERPRINTS
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY
BNWL-269 +. 2 PAGES OF CERAMICS RESEARCH AND DEVELOPMENT QUARTERLY REPORT. OCTOBER-DECEMBER 1965, PAGE 3.26, PAGE 4.8, AUGUST 12, 1966, CFSTI

PAGE 3.26.-- TWO ZIRCALOY RODS FROM THE PRTR WHICH LEAKED FISSION PRODUCTS IN 1965 WERE EXAMINED. THE DEFECTS WERE LOCATED IN A DISCOLORED AREA OF THE CLADDING. AN AREA ON ONE ELEMENT SHOWED MASSIVE HYDRIDING AND THE OTHER ELEMENT BROKE IN SUCH AN AREA DURING HOT-CELL HANDLING. ALL ACTIVE PRTR ELEMENTS WERE EXAMINED IN STORAGE, SEVEN HAVING SUSPECTED HYDRIDE AREAS. THE SHAPE OF SOME OF THE AREAS IS THAT OF A FINGERPRINT. PLASTIC BAGS ARE NOW USED TO PREVENT GREASE DEPOSITION DURING HANDLING. PAGE 4.8.- REJECTED SAXTON TUBING WAS THERMAL-CYCLED IN A PROGRAM TO EVALUATE MANUFACTURING DEFECTS ON FUEL-ROD PERFORMANCE. MANY ULTRASONIC DEFECTS WERE NOT DETECTED DURING SECTIONING.

*FAILURE, CLADDING + ADMINISTRATIVE CONTROLS AND PRACTICES + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, PRESSURE TUBE + REACTOR, PRESSURIZED WATER + TEST, NONDESTRUCTIVE

5-11992 FRESHLEY MD + WHEELER RG + BATCH JM + HESSON GM
INVESTIGATION OF THE COMBINED FAILURE OF A PRESSURE TUBE AND DEFECTED FUEL ROD IN PRTR
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-272 +. 151 PAGES, 3 TABLES, 57 FIGURES, 27 REFERENCES, MAY 13, 1966, CFSTI \$5.00 CY, \$1.00 MN

ON SEPTEMBER 29, 1965, A FUEL MELTDOWN AND PRESSURE-TUBE RUPTURE RELEASED FISSION GAS INTO THE PRTR BUILDING THROUGH COVER-GAS-SYSTEM LEAKS, CAUSING EXTENSIVE CONTAMINATION. THIS REPORT REVIEWS THE FUEL-ELEMENT FAILURE. VIBRATORY-COMPACTED FUEL ROD FR4 WAS IRRADIATED TO APPROXIMATELY 900 MWD/TON U, THEN A HOLE WAS DRILLED THROUGH THE CLADDING AND IT WAS REPLACED IN THE SEPARATE LOOP FOR IRRADIATION AT 27 KW/FT WITH CENTERLINE MELTING. THREE DAYS AFTER REPLACEMENT, THE INCIDENT OCCURRED DURING SCHEDULED LOOP-FLOW REDUCTIONS. WATER ENTERED THE FUEL REGION AND LOCALLY OXIDIZED THE (U,Pu) OXIDE TO AN O/U RATIO OF 2.1. THE REDUCED THERMAL CONDUCTIVITY AND LOWERED MELTING POINT INCREASED THE MOLTEN ZONE, ALREADY 3/4 OF THE FUEL RADIUS. EXPANSION BLOCKED OFF COOLANT FLOW AND WITHIN 24 SEC THE PRESSURE TUBE RUPTURED BECAUSE OF OVERHEATING. THE RESULTANT LOCALLY INCREASED PRESSURE BLEW MOLTEN FUEL FROM THE FUEL ROD THROUGH THE PRESSURE-TUBE RUPTURE HOLE INTO THE MODERATOR. BEHAVIORAL DIFFERENCES WERE FOUND AMONG INTACT VIBRATORILY PACKED FUEL RODS AND BETWEEN DEFECTIVE AND INTACT MIXED-OXIDE RODS.

*FUEL MELTDOWN + *INCIDENT, ACTUAL, GENERAL + CENTERLINE MELTING + FAILURE, CLADDING + IN PILE LOOP + PLUTONIUM OXIDE + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST + STOICHIOMETRY + URANIUM OXIDE

5-12041 BORNAND B
LISTING OF NUCLEAR CODES FOR IBM-704, 709, AND -7090
COMMISSARIAT A L'ENERGIE ATOMIQUE, SACLAY, FRANCE
CEA-BIB-17 (III) +. 143 PAGES, JANUARY 1966, CEA, IN FRENCH AND ENGLISH

ACCESSION NUMBER 5-11761 TO 5-12041

CATEGORY 5
ACCIDENT ANALYSIS

5-12041 *CONTINUED*

THE DIGITAL COMPUTER CODES LISTED IN PARTS I AND II OF THIS BIBLIOGRAPHY WERE SELECTED ON THE BASIS OF THE MOST USEFUL CODES FOR REACTOR COMPUTATIONS. IN THE LISTING, THE CODES ARE ARRANGED CHRONOLOGICALLY IN EIGHT CATEGORIES - BURN-UP, ENGINEERING, GROUP DIFFUSION, KINETICS, TRANSPORT, PHYSICS, MONTE-CARLO, MISCELLANEOUS. BURN-UP, ENGINEERING, AND GROUP DIFFUSION ARE ISSUED IN PART I. MACHINE, FAST MEMORY, AND LANGUAGE ARE INDICATED. THE NUMBER OF THE REPORT THAT GIVES THE DETAILS OF THE CODE IS LISTED. INDEXES OF CODE NAMES, AUTHORS, AND OF QUOTED REPORTS ARE GIVEN. THIS BIBLIOGRAPHY HAS BEEN REVIEWED FROM 1957 TO MARCH 1964, FOR SECTION I, FROM 1957 TO MARCH 1965 FOR SECTION II.

*BIBLIOGRAPHY + *COMPUTER PROGRAM + *FRANCE

5-12073 HELM JW
RADIATION EFFECTS IN GRAPHITE AT HIGH TEMPERATURE
BATTELLE-NORTHWEST, RICHLAND
BNWL-SA-67 +. 25 PAGES, FIGURES, 2 TABLES, 12 REFERENCES, JUNE 4, 1965, CFSTI \$1.00 CY, \$0.50 MN

ONE OF THE PROBLEMS IN THE USE OF GRAPHITE AS A MODERATOR IS THE RADIATION-INDUCED DIMENSIONAL CHANGES WHICH OCCUR IN THE REACTOR. THERE ARE CONSIDERABLE DATA AVAILABLE ON THE DIMENSIONAL STABILITY OF GRAPHITE IN THE IRRADIATION TEMPERATURE RANGE OF 450 TO 800 C. CONSIDERABLE MORE DATA HAVE BEEN OBTAINED IN THIS TEMPERATURE RANGE SINCE DATA WERE PRESENTED PREVIOUSLY AND NEUTRON EXPOSURES HAVE BEEN EXTENDED 80 PERCENT TO A MAXIMUM OF 16×10 TO THE 21 NVT. DATA IN THE TEMPERATURE RANGE OF 800-1200 C ARE LIMITED EVEN THOUGH THIS RANGE IS OF PARTICULAR INTEREST TO OPERATORS AND DESIGNERS OF GRAPHITE-MODERATED REACTORS. IRRADIATIONS ARE BEING CONDUCTED IN THIS TEMPERATURE RANGE AND DATA ARE AVAILABLE TO A MAXIMUM EXPOSURE OF 4.5×10 TO THE 21 NVT. DATA ARE ALSO AVAILABLE FOR SEVERAL TYPES OF RAW-COKE AND ISOTROPIC GRAPHITES OVER THE TEMPERATURE RANGE OF 500-1150 C.

*GRAPHITE + *PROPERTY, PHYSICAL + *RADIATION DAMAGE + *RADIATION EFFECT + MODERATOR

5-12076 BARNES RH + KIRCHER JF + TOWNLEY CW
CHEMICAL EQUILIBRIUM STUDIES OF ORGANIC-IODIDE FORMATION UNDER NUCLEAR REACTOR ACCIDENT CONDITIONS
BATTELLE MEMORIAL INSTITUTE
BMI-1781 +. 32 PAGES, 15 FIGURES, 19 REFERENCES, AUGUST 15, 1966, CFSTI \$2.00 CY, \$0.50 MN.

THE PRESENCE OF CH₃I IN NUCLEAR-REACTOR ENVIRONMENTS POSSES A POTENTIAL HAZARD BECAUSE OF THE DIFFICULTIES INVOLVED IN REMOVING THIS COMPOUND FROM GASES USING CONVENTIONAL TRAPPING TECHNIQUES. TO GAIN INSIGHT INTO THE CHEMICAL PROCESSES LEADING TO CH₃I FORMATION, A STUDY WAS PERFORMED OF CALCULATED EQUILIBRIUM CONCENTRATIONS OF CH₃I AND OTHER IMPORTANT SPECIES FOR A RANGE OF CONDITIONS TYPICAL OF REACTOR-ACCIDENT SYSTEMS. THE RESULTS OF THIS STUDY INDICATED THAT CHEMICAL SYSTEMS CONTAINING SIMPLE COMPOUNDS SUCH AS CO₂, H₂O, CH₄, AND IODINE WOULD BE EXPECTED TO GENERATE CH₃I. THE CALCULATED EQUILIBRIUM CONCENTRATIONS OF CH₃I WERE FOUND TO BE SEVERAL ORDERS OF MAGNITUDE LOWER THAN THOSE OBSERVED IN COMPARABLE EXPERIMENTAL SYSTEMS, INDICATING THAT CHEMICAL-KINETIC FACTORS ARE IMPORTANT. A PRELIMINARY STUDY OF THE PRACTICALITY OF SOLVING THE KINETIC PROBLEM WAS MADE.

*CHEMICAL EQUILIBRIUM + *CHEMICAL KINETICS + *FISSION PRODUCT, IODINE + *ORGANIC IODIDE + ACCIDENT MODEL + ANALYTICAL MODEL + CHEMICAL REACTION

5-12237 JUDD DF + WILSON RH + SWENSON HS + LEE RA + ACKERMAN JW
NONUNIFORM HEAT GENERATION EXPERIMENTAL PROGRAM. QUARTERLY PROGRESS REPORT NO. 6, OCTOBER - DECEMBER 1964
BABCOCK AND WILCOX COMPANY, LYNCHBURG, VA. AND ALLIANCE, OHIO
BAW-3238-6 + EURAEC-1327 +. 43 PAGES, CFSTI, \$2.00 CY

THE BABCOCK AND WILCOX COMPANY, AS PART OF THE JOINT U.S.-EURATOM RESEARCH AND DEVELOPMENT PROGRAM, IS CONDUCTING EXPERIMENTAL AND ANALYTICAL INVESTIGATIONS TO DETERMINE THE EFFECTS OF IRREGULAR HEAT FLOW THROUGH REACTOR CHANNELS ON THE OPERATING CONDITIONS THAT CAUSE BURNOUT (DEPARTURE FROM NUCLEATE BOILING). THIS PROGRAM SEEKS TO IMPROVE DESIGN CORRELATIONS THAT WILL BE SUITABLE FOR DIRECT USE BY REACTOR DESIGNERS. TUBULAR SPECIMENS WITH FOUR AXIAL POWER SHAPES, AND ANNULAR SPECIMENS WITH FIVE POWER SHAPES, ARE BEING USED, AND AN EFFORT TO CORRELATE THE EXPERIMENTAL DATA WITH EMPIRICAL AND ANALYTICAL MODELS WILL BE MADE.

*BURNOUT HEAT FLUX + *DN3 (DEPARTURE FROM NUCLEATE BOILING) + *HEAT TRANSFER EXPERIMENT + FLOW, TWO PHASE + FUEL ELEMENT + HEAT TRANSFER

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-07756 HAMILTON GN + TAYLOR EG + HANLEN OF
DESIGN CONSIDERATIONS IN SAFETY ANALYSIS OF PARTIAL MODERATOR-LEVEL CONTROLLED REACTORS
WESTINGHOUSE ATOMIC POWER DIVISION, MADISON, PA.
1 PAGE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING,
JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 49

VARIABLE MODERATOR-LEVEL CONTROL (INSTEAD OF CONTROL RODS) PRESENTS MANY PHYSICS ADVANTAGES
FOR CRITICAL ASSEMBLIES. IN ADDITION, IT HAS SAFETY ADVANTAGES. NO CORE PLATE PENETRATIONS
FOR ABSORBERS TO FALL THROUGH, NO PROBLEMS COUPLING CONTROL MATERIAL AND FUEL, REACTIVITY
DOES NOT VARY WITH RADIAL POSITION, ONLY ONE WAY OF ADDING REACTIVITY, RAMP RATE IS A
CONTINUOUS VARIABLE, NO STEP-INCREASE ACCIDENTS. SYSTEM HAS OPERATED EFFECTIVELY 5 YEARS AT
WREC.

*CONTROL ROD + *MODERATOR + *REFLECTOR + ACCIDENT, REACTIVITY + CRITICAL ASSEMBLY FACILITY

6-08441 FOX TA + MUELLER RA + FORD CH + ALGER DL
CRITICAL MASS STUDIES WITH NASA ZERO POWER REACTOR II. 1 - CLEAN HOMOGENEOUS CONFIGURATIONS
LEWIS RESEARCH CENTER, NATIONAL AERONAUTICS AND SPACE ADMINISTRATION, CLEVELAND, OHIO
NASA-TN-D-3097 +. 19 PAGES, 6 FIGURES, 2 TABLES, 6 REFERENCES- NOVEMBER 1965, CFSTI \$1.00 CY, \$0.50 MN

THE NASA ZERO POWER REACTOR II (ZPR-II) HAS BEEN USED TO DETERMINE EXPERIMENTALLY THE CRITICAL
MASSES FOR MORE THAN A TENFOLD RANGE OF HIGHLY ENRICHED (93.2 PERCENT U-235) AQUEOUS URANYL
FLUORIDE FUEL CONCENTRATIONS IN CLEAN CYLINDRICAL GEOMETRIES. IN ADDITION TO THE CRITICAL
MASSES, DATA ARE PRESENTED ON THE TEMPERATURE COEFFICIENT OF REACTIVITY WORTH AT CRITICALITY
FOR A SIMILAR RANGE OF CONCENTRATIONS. A BRIEF DESCRIPTION OF THE ZPR-II AND THE
EXPERIMENTAL PROCEDURES USED ARE ALSO INCLUDED.

CRITICALITY EXPERIMENT + CRITICALITY SAFETY + REACTIVITY COEFFICIENT + TEMPERATURE COEFFICIENT + URANIUM

6-08781 ALLAN DL
NUCLEAR PHYSICS DIVISION PROGRESS REPORT FOR PERIOD JANUARY 1, 1964 TO JUNE 30, 1964
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-PR/NP-7 +. 51 PAGES, 11 TABLES, 34 FIGURES, 114 REFERENCES, NOVEMBER 1964, UK-AEA

THE ONLY ITEM RELATED TO REACTOR SAFETY IS THE MEASUREMENT OF THE TIME-DEPENDENT SPECTRUM OF
NEUTRONS IN HEAVY WATER.

*REACTOR DYNAMICS

6-09358 ERGEN WK
SELF-LIMITING POWER EXCURSIONS IN LARGE REACTORS
OAK RIDGE NATIONAL LABORATORY
2 PAGES, TRANSACTIONS ANS, 8(1), PAGES 221-222 (JUNE, 1965), AMERICAN NUCLEAR SOCIETY MEETING, GATLINBURG,
TENNESSEE, MAY, 1965

A POWER EXCURSION IS ASSUMED TO BE INITIATED BY AN INSTANTANEOUS REACTIVITY INSERTION INTO A
LIMITED REGION OF A LARGE REACTOR. AS THE POWER INCREASES IN THAT REGION AND ITS
SURROUNDINGS, A PROMPT-ACTING REACTIVITY-COMPENSATING MECHANISM, SUCH AS THE DOPPLER EFFECT,
TERMINATES THE EXCURSION. THIS MECHANISM IS ASSUMED TO DEPEND ON THE ENERGY-DENSITY
DEPOSITED. HENCE, IT IS SPACE- AND TIME-DEPENDENT. THIS PAPER TREATS THE PROBLEM FOR THE
ONE-GROUP CASE BY ANALYTICAL METHODS. ATTENTION IS CONFINED TO THE ENERGY DENSITY ATTAINED
AT THE END OF THE EXCURSION. IN 1966, A MORE DETAILED PAPER IS TO APPEAR IN NUCLEAR SAFETY
JOURNAL.

DOPPLER EFFECT + REACTOR, LARGE + SPACE DEPENDENT DYNAMICS

6-09399 CHOCK KJ + KAPLAN S + MARGOLIS SG
ANALOG STUDIES OF XENON OSCILLATIONS - THE EFFECT OF COOLANT RECIRCULATION ON SPATIAL STABILITY.
WESTINGHOUSE ELECTRIC CORPORATION, BETTIS ATOMIC POWER LABORATORY
CONF-650602 +. 1 PAGE, 2 FIGURES, AMERICAN NUCLEAR SOCIETY MEETING, GATLINBURG, TENNESSEE, JUNE 21-24,
1965, ANS TRANSACTIONS, 8(1) PAGE 237

IN REACTORS WITH NEGATIVE TEMPERATURE COEFFICIENT OF REACTIVITY, THE RECIRCULATION OF THE
COOLANT FROM HEAT EXCHANGER TO CORE CONSTITUTES A FEEDBACK LOOP, WHICH CAN BE USED TO
STABILIZE THE REACTOR AGAINST XENON OSCILLATIONS IN THE FUNDAMENTAL MODE AND IN HIGHER
SPATIAL MODES.

*XENON + *XENON OSCILLATION + SPACE DEPENDENT DYNAMICS

6-09541 BARAN W + MEYER K
EFFECT OF DELAYED NEUTRONS ON THE STABILITY OF A NUCLEAR POWER REACTOR
RESEARCH INSTITUTE FOR ADVANCED STUDIES, BALTIMORE, MARYLAND
6 PAGES, 1 FIGURE, NUCLEAR SCIENCE AND ENGINEERING, 24(4), PP. 356-361 (APRIL 1966)

AN EXAMPLE IS GIVEN TO SHOW THAT STABILITY WITHOUT DELAYED NEUTRONS DOES NOT IMPLY STABILITY
WITH DELAYED NEUTRONS. A NEW CRITERION FOR STABILITY IN THE LARGE IS DERIVED. AN EXAMPLE IS
GIVEN THAT SHOWS THAT THE NEW CRITERION PREDICTS STABILITY IN SOME CASES WHEN THE OLDER ONE
FAILS.

*DELAYED NEUTRON + *REACTOR STABILITY + *THEORETICAL INVESTIGATION + REACTOR, POWER

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09542 ISHIGURO Y
A RIGOROUS EXPRESSION FOR SHAPE OF A DOPPLER-BROADENED RESONANCE
JAPAN ATOMIC ENERGY RESEARCH INSTITUTE
6 PAGES, 4 FIGURES, 2 TABLES, NUCLEAR SCIENCE AND ENGINEERING 24(4), PP. 375-380 (APRIL 1966)

A RIGOROUS EXPRESSION IS DERIVED FOR THE SHAPE OF A DOPPLER-BROADENED ABSORPTION CROSS SECTION. WHEN THE WIDTH IS ASSUMED TO BE CONSTANT, THE EXPRESSION, WHICH IS RIGOROUS FOR A MAXWELLIAN GAS OF RESONANCE-ABSORBER ATOMS, IS WRITTEN AS THE DIFFERENCE BETWEEN THE TWO PSI FUNCTIONS. COMPARISONS WITH THE USUAL PSI FUNCTION APPROXIMATION AND THE LOW-LYING RESONANCES OF URANIUM-235, PLUTONIUM-239, ETC., ARE MADE. FOR THE LOW-LYING RESONANCES, THE DOPPLER-BROADENED ABSORPTION CROSS-SECTION IS EASILY COMPUTED BY THE ASYMPTOTIC EXPANSION OF THE PSI FUNCTION.

*DOPPLER EFFECT + *THEORETICAL INVESTIGATION + PLUTONIUM + URANIUM

6-09543 OTSUKA M + SAITO K
NEUTRON FLUCTUATIONS IN A MULTIPLYING MEDIUM
JAPAN ATOMIC ENERGY RESEARCH INSTITUTE
3 PAGES, NUCLEAR SCIENCE AND ENGINEERING, 24(4), PP. 412-414 (APRIL 1966)

ATTEMPT TO UNRAVEL THE CONNECTIONS OF THE APPROACHES OF THE FOLLOWING AUTHORS TO THE PROBLEM OF NEUTRON FLUCTUATIONS IN A MULTIPLYING MEDIUM - G. I. BELL, L. PAL, R. K. OSBORN, E. S. YIP, M. OTSUKA AND K. SAITO.

*NOISE ANALYSIS + THEORETICAL INVESTIGATION

6-09577 MURRAY HS
THE STABILITY OF COUPLED-CORE NUCLEAR REACTOR SYSTEMS BY THE SECOND METHOD OF LIAPUNOV
UNIVERSITY OF ARIZONA
2 PAGES, 1965, DISSERTATION ABSTRACTS, 26(4), PP. 2089-2090 (1965), ORDER NO. 65-11,558, 105 PAGES, XEROGRAPHY \$5.20, MICROFILM \$3.00

IN CONNECTION WITH THE USE OF MULTIPLE REACTORS FOR NUCLEAR ROCKETS, THE NEUTRONIC STABILITY OF THE ARRAY IS STUDIED, TAKING INTO ACCOUNT THE DELAY TERMS CAUSED BY THE TRANSIT TIME OF NEUTRONS FROM ONE CORE TO THE OTHER. A LIAPUNOV FUNCTION (V) IS CONSTRUCTED, BUT ITS DERIVATIVE IS NEGATIVE -- DEFINITE IF (V) IS SMALLER THAN A CERTAIN FUNCTION OF V. THIS CONDITION IS SAID TO BE SUFFICIENT FOR STABILITY.

*COUPLED CORES + *ROVER PROGRAM + LIAPUNOV'S FUNCTION + MATHEMATICAL STUDY + REACTOR DYNAMICS + REACTOR STABILITY

6-09699 BENTLEY PG + BURTON EJ
THE MEASUREMENT AND ANALYSIS OF CAN TEMPERATURE FLUCTUATIONS IN CHAPELCROSS REACTORS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
12 PAGES, 5 FIGURES, 1 TABLE, REFERENCES, JOURNAL OF NUCLEAR ENERGY PARTS A/B, 19(5), PP. 313-324 (MAY 1965)

FLUCTUATING SIGNALS FROM CAN-TEMPERATURE THERMOCOUPLES IN CHAPELCROSS REACTORS HAVE BEEN ANALYSED BY ANALOGUE AND BY DIGITAL METHODS. MEASURED SIGNALS ARE FOUND TO BE ALMOST STATIONARY OVER PERIODS OF SEVERAL DAYS AND ARE BELIEVED TO BE MADE UP OF THREE DISTINCT COMPONENTS. AT FREQUENCIES BELOW 0.001 C/S THERE IS A COMPONENT WHICH MAY BE DUE TO DRIFT IN THE CONTROL OF THE REACTOR AND WHICH IS COMMON TO ALL FUEL ELEMENTS. AT HIGHER FREQUENCIES (0.001-0.01 C/S) A COMPONENT OF UNKNOWN SOURCE IS INFERRED FROM ITS LACK OF CORRELATION WITH OTHER CAN TEMPERATURES. THE THIRD COMPONENT HAS THE CHARACTERISTICS OF WHITE NOISE SMOOTHED BY THE TIME CONSTANT OF THE MEASURING THERMOCOUPLE IN THE FREQUENCY RANGE 0.1-10 C/S AND IS BELIEVED TO BE CAUSED BY RANDOM HEAT TRANSFER IN THE TURBULENT COOLANT GAS.

*NOISE ANALYSIS + CLAD + FUEL ELEMENT + REACTOR, GAS COOLED + TEMPERATURE TRANSIENT + THERMAL CONSIDERATION + UNITED KINGDOM

6-09701 SHAFTMAN DH + KELBER CN + KRISTIANSON BN + REED HF + SAVIO RP + STEPHANY WP + DAUGHTRY J + JOHNSON T + KOCRICK F + PLUMLEE K + ROBINSON W + STANFORD G
REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 34 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS II-4 THROUGH II-11, PP. 42-76, CFSTI, \$7.22 CY, \$2.00 MN.

THE FOLLOWING TOPICS ARE DISCUSSED FOR THE AARR - (1) RADIATION DOSES FOLLOWING A POSTULATED MCA, HEATING RATES FOR MATERIALS IN THE INTERNAL THERMAL COLUMN AND THE REFLECTOR, BOTH DURING OPERATION AND AFTER SHUTDOWN, MULTIPLICATION OF PHOTONEUTRONS IN SUBCRITICAL AARR, EFFECTS ON REACTOR POWER AND LOCATION OF STARTUP DETECTOR, ANALYSIS OF CRITICAL-FACILITY LOADING, TRANSIENT TEMPERATURE CALCULATIONS, CRITICAL EXPERIMENTS, GAMMA HEATING.

*AARR (ARGONNE ADVANCED RESEARCH REACTOR) + ACCIDENT, MAXIMUM CREDIBLE (MCA) + COMPUTER PROGRAM + CRITICALITY EXPERIMENT + DECAY HEAT + DELAYED NEUTRON + DOSE CALCULATION, EXTERNAL + ENERGY SOURCE + INSTRUMENTATION, NUCLEAR + PROMPT NEUTRON LIFETIME + ROSSI ALPHA + TEMPERATURE COEFFICIENT + TEMPERATURE TRANSIENT + THERMAL ANALYSIS + VOID COEFFICIENT

6-09702 MILLER D + JAIN KC + PETRICK M + BANKOFF SG + SANATHANAN CK
REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ACCESSION NUMBER 6-09542 TO 6-09702

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09702 *CONTINUED*

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 7 PAGES, 1 FIGURE, 16 REFERENCES, DECEMBER 1965, SECTIONS II-12 AND II-13, PP. 76-82, CFSTI, \$7.22 CY, \$2.00 MN

REGARDING OSCILLATION IN A NATURAL-CIRCULATION BOILING SYSTEM, IT MAY BE NECESSARY TO CONSIDER THE PERIODIC VAPORIZATION OF SUPERHEATED LIQUID NEAR THE LEADING EDGE OF THE TWO-PHASE FLOW (FOR DETAILS SEE ANL-7073). AN ANALYTICAL STUDY OF SPACE-DEPENDENT DYNAMICS OF BOILING REACTORS USING LINEAR TRANSFER FUNCTION IN TIME AND THE COORDINATE ALONG THE CORE AXIS IS ALSO DISCUSSED.

*REACTOR, BOILING WATER + CIRCULATION, NATURAL (LOOPS AND REACTORS) + CONVECTIVE BOILING + DYNAMICS, NONLINEAR + FLOW, PULSATING + HEAT TRANSFER, NATURAL CONVECTION + SPACE DEPENDENT DYNAMICS + TRANSFER FUNCTION

6-09703 KIER PH

THE EBWR PLUTONIUM RECYCLE EXPERIMENTAL PROGRAM. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 1 PAGE, DECEMBER 1965, SECTION II-17, P. 92, CFSTI, \$7.22 CY, \$2.00 CY

THIS PROGRAM FOR SAFETY-RELATED MEASUREMENTS IN THE PLUTONIUM-LOADED EBWR INCLUDES CONTROL ROD WORTHS, BORIC ACID WORTHS, TEMPERATURE COEFFICIENT, SHUTDOWN MARGIN, TRANSFER FUNCTIONS, AND STABILITY. A PROGRAM FOR EXPERIMENTS IN A CRITICAL SYSTEM CONTAINING PLUTONIUM WITH SIGNIFICANT PU-240 INCLUDES CRITICAL MASS, BORIC ACID WORTH, AND TEMPERATURE-COEFFICIENT MEASUREMENTS.

*EBWR (EXPERIMENTAL BOILING WATER REACTOR) + *PLUTONIUM + CHEMICAL SHIM + CONTROL ROD WORTH + CRITICALITY EXPERIMENT + EXPERIMENT, GENERAL + POISON, SOLUBLE + REACTOR STABILITY + REACTOR, BOILING WATER + SHUTDOWN MARGIN + TEMPERATURE COEFFICIENT + TRANSFER FUNCTION

6-09704 HELM FH + KATO WY + MAIN G + RUSCH GK

PHYSICS PARAMETERS AND SODIUM VOID COEFFICIENTS IN A 950-LITER PANCAKE CORE. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 13 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTION III-1, PP. 101-113, CFSTI, \$7.22 CY, \$2.00 MN.

THE SODIUM VOID EFFECT WAS MEASURED ON ASSEMBLY NO. 3 OF ZPR-6, WHICH HAS A PANCAKE-SHAPED CORE. SOME OF THE RESULTS ARE COMPARED WITH IDENTICAL MEASUREMENTS IN ASSEMBLY NO. 2, WHICH HAD THE SAME COMPOSITION BUT A LENGTH-TO-DIAMETER RATIO OF ABOUT 1 TO 1. THE ASSEMBLY IS DESCRIBED, AND THE EXPERIMENTAL METHOD OF VOID MEASUREMENT AND HETEROGENEITY-EFFECT MEASUREMENTS ARE DISCUSSED. THE SODIUM-VOID COEFFICIENT WAS MEASURED FOR A NUMBER OF REGIONS, AND RESULTS ARE GIVEN. MEASUREMENTS WERE ALSO MADE WITH A LOW-DENSITY BLANKET ZONE REPLACING THE AXIAL U-238 BLANKET. MOST OF THE SODIUM-VOID CALCULATIONS UTILIZED THE ONE-DIMENSIONAL CODE MACH 1. CENTRAL REACTIVITY COEFFICIENTS AND FISSION RATIO WERE ALSO MEASURED.

COMPARISON, THEORY AND EXPERIENCE + COMPUTER, DIGITAL + CRITICAL ASSEMBLY FACILITY + MEASUREMENT, GENERAL + PROMPT NEUTRON LIFETIME + REACTOR, FAST + ROSSI ALPHA + SODIUM COEFFICIENT + VOID COEFFICIENT + ZPR VI (ANL ZERO POWER REACTOR)

6-09705 KARAM RA + ANCARANI A + HELM F + KATO WY + RUSCH GK + BENNETT EF

REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 7 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-2 AND III-3, PP. 114-120, CFSTI, \$7.22 CY, \$2.00 MN

THE ZPR VI ASSEMBLY 4Z HAS FOUR ZONES - CENTRAL, BUFFER, DRIVER AND REFLECTOR. TOPICS OF DISCUSSION INCLUDE (1) THE COMPOSITION AND CRITICAL MASS, (2) SPECTRAL MATCHING, (3) FATMAN EFFECT, (4) MEASUREMENT OF SPECTRUM AND DOPPLER EFFECT, AND (5) CONTROL ROD CALIBRATION. THE EXPERIMENTAL TECHNIQUE FOR MEASUREMENT OF THE NEUTRON SPECTRUM IS DESCRIBED AND RESULTS ARE GIVEN.

*ZPR VI (ANL ZERO POWER REACTOR) + CONTROL ROD WORTH + CRITICAL ASSEMBLY FACILITY + CRITICALITY EXPERIMENT + DOPPLER EFFECT + FLUX DISTRIBUTION + HYDROGEN + NEUTRON + REACTOR, FAST + REFLECTOR

6-09706 FISCHER GJ + MENELEY DA + HWANG RN + GROH EF + TILL CE

DOPPLER EFFECT MEASUREMENTS IN PLUTONIUM-FUELED FAST POWER BREEDER REACTOR SPECTRA. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 5 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTION III-4, PP. 120-124, CFSTI, \$7.22 CY, \$2.00 MN.

MEASUREMENT OF THE DOPPLER EFFECT IN THE ZPR-III WAS MADE BY MEANS OF A DOPPLER ELEMENT OF VARIABLE TEMPERATURE. EQUIPMENT AND PROCEDURES ARE DESCRIBED. RESULTS AND CONCLUSIONS ARE GIVEN. EXPERIMENTAL AND THEORETICAL UNCERTAINTIES ARE DISCUSSED.

*DOPPLER EFFECT + COMPARISON, THEORY AND EXPERIENCE + CRITICAL ASSEMBLY FACILITY + MEASUREMENT, GENERAL + PLUTONIUM + REACTOR, FAST + ZPR III (ANL ZERO POWER REACTOR)

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09707 HWANG RN
REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 4 PAGES, 3 TABLES, 1 FIGURE, 1 REFERENCE, DECEMBER 1965, SECTIONS III-5 AND III-6, PP. 124-127, CFSTI, \$7.22 CY, \$2.00 MN

THE CALCULATION OF DOPPLER EFFECTS IN THE SEFOR MOCKUP (THE ZPR-III) SHOWS THAT DOPPLER COEFFICIENTS WILL BE SUBSTANTIALLY NEGATIVE AS LONG AS THE OUTER RADIUS OF THE OUTER CORE DOES NOT EXCEED 39 CM. THE INNER CORE IS FUELED WITH U-238-PU-MO PLATES AND GIVES A NEGATIVE DOPPLER EFFECT. THE OUTER CORE, FUELED WITH PURE PU, GIVES A POSITIVE COEFFICIENT. RESONANCE INTERFERENCE IS CONSIDERED ACCORDING TO R. N. HWANG, NUCLEAR SCIENCE AND ENGINEERING, 21, P. 523, (1965).

*DOPPLER EFFECT + CRITICAL ASSEMBLY FACILITY + DOPPLER COEFFICIENT + PLUTONIUM + REACTOR, BREEDER + REACTOR, FAST + SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR) + URANIUM + ZPR III (ANL ZERO POWER REACTOR)

6-09708 MENEGHETTI D
THEORETICAL STUDIES OF THIN SLAB HETEROGENEITY EFFECTS UPON THE SPECTRAL REACTIVITY COMPONENT OF SODIUM VOIDING. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 3 PAGES, 2 TABLES, 4 REFERENCES, DECEMBER 1965, SECTION III-11, PP. 148-150, CFSTI, \$7.22 CY, \$2.00 MN.

TWENTY-TWO GROUP CALCULATIONS OF ASSUMED CELL COMPOSITIONS AND CONFIGURATIONS HAVE BEEN MADE USING THE SNARG CODE UTILIZING 12 OR 14 DISCRETE ANGLES IN A MODIFIED SINGLE-GAUSSIAN QUADRATURE. RESULTS OF THE ANALYSES FOR TWO ASSUMED CORE COMPOSITIONS ARE GIVEN.

*REACTOR, FAST + SLAB + SODIUM COEFFICIENT + THEORETICAL INVESTIGATION

6-09709 LOEWENSTEIN WB + KIRN F + SMITH RR
EBR-II PHYSICS. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 2 PAGES, 7 REFERENCES, DECEMBER 1965, SECTION III-12, PP. 151-152, CFSTI, \$7.22 CY, \$2.00 MN.

THE REACTOR IS STABLE AT ALL POWER LEVELS OF OPERATION. THE POWER COEFFICIENT IS ESSENTIALLY CONSTANT. AN UNEXPECTED OBSERVATION PERTAINS TO SMALL 10-CPS OSCILLATIONS. THE REACTIVITY OSCILLATOR ROD FAILED.

*EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + FAILURE, COMPONENT + OSCILLATOR, REACTIVITY + POWER COEFFICIENT + REACTOR STABILITY + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

6-09710 MADELL JT
PHYSICS ANALYSIS OF TREAT WITH AN EBR-II SUBASSEMBLY. REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 4 PAGES, 2 TABLES, 2 FIGURES, 5 REFERENCES, DECEMBER 1965, SECTION III-14, PP. 154-157, CFSTI, \$7.22 CY, \$2.00 MN.

THE OBJECTIVES OF THE PHYSICS ANALYSIS WERE TO DETERMINE THE REACTIVITY EFFECT OF THE SUBASSEMBLY AND ITS COMPONENTS, THE POWER DISTRIBUTION IN THE SUBASSEMBLY AND IN TREAT, AND THE KINETIC PARAMETERS OF TREAT WITH THE SUBASSEMBLY PRESENT.

ANALYTICAL MODEL + COMPUTER PROGRAM + REACTIVITY EFFECT + REACTOR KINETICS + REACTOR, GRAPHITE MODERATED + REACTOR, TEST + TREAT (TRANSIENT TEST REACTOR FACILITY)

6-09711 DICKERMAN CE + ROBINSON LE + AUGUST C + STEWART R + STEPHANY W + WILLIS L + CARLANDER R + MUELLER M
PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 4 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-15 THROUGH III-19, PP. 157-165, CFSTI, \$7.22 CY, \$2.00 MN.

IN TREAT TRANSPARENT MELTDOWN CAPSULES, THE FOLLOWING SAMPLES WERE SUBJECTED TO TRANSIENTS FOR THE PURPOSES INDICATED - U-5 W/O FISSION ALLOY SAMPLES PREIRRADIATED TO 1.3 AT. PERCENT BURNUP, MEASUREMENT OF EXPANSION. EBR-II FUEL PIN PREIRRADIATED TO 0.6 AT. PERCENT, STUDY OF FAILURE MECHANISM. TH-U METALLIC FUEL ELEMENTS OF THE EBR-II MARK I TYPE, STUDY OF FAILURE MECHANISM (SEE ALSO TRANS. AMERICAN NUCLEAR SOCIETY, 6(1), P. 302 (1965)). EBR-II TYPE US FUELED, W-RE ALLOY CLAD ELEMENTS, STUDY OF FAILURE, IF ANY (SEE ALSO NUCLEAR APP. 1, P. 168 (1965)). IN THE INTEGRAL SODIUM LOOP EBR-II PINS WERE SUBJECTED TO 3 TRANSIENTS WITH SODIUM FLOW AND THREE TRANSIENTS WITHOUT FLOW. FUEL-CLADDING EUTECTIC WAS FORMED BY MOLTEN FUEL PENETRATING FROM THE CENTER OF THE ROD TO THE SURFACE.

*TREAT (TRANSIENT TEST REACTOR FACILITY) + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + FAILURE, CLADDING + FAILURE, FUEL ELEMENT + FUEL MELTDOWN + HIGH TEMPERATURE + IN PILE LOOP + IRRADIATION TESTING + PRESSURE, INTERNAL + REACTOR, BREEDER + REACTOR, FAST + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + REACTOR, TEST + THORIUM + URANIUM + URANIUM SULFIDE

6-09712 KARAM RA
NOTE ON ROSSI-ALPHA IN REFLECTED FAST REACTORS. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30,

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09712 *CONTINUED*
1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 2 PAGES, 8 REFERENCES, DECEMBER 1965, SECTION III-23, PP. 172-173, CFSTI, \$7.22 CY, \$2.00 MN.

IN REFLECTED FAST REACTORS, THE PROMPT NEUTRON LIFETIME, AS OBTAINED FOR ROSSI-ALPHA AND DELAYED-NEUTRON FRACTION MEASUREMENTS, DEVIATES CONSIDERABLY FROM CALCULATION BECAUSE, IN THE CALCULATION, NEUTRONS OF ALL MODES ARE TAKEN INTO CONSIDERATION, WHEREAS MEASUREMENTS ARE BASED ON THE ASYMPTOTIC MODE.

*REACTOR, FAST + *REFLECTOR + DELAYED NEUTRON + PROMPT NEUTRON LIFETIME + ROSSI ALPHA

6-09713 BUTLER DK + LOEWENSTEIN WB + MENEGHETTI D + PHILLIPS KE + HUMMEL HH + WHITE J

PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 12 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-24 THROUGH III-26, PP. 173-184, CFSTI, \$7.22 CY, \$2.00 MN

AMONG MANY OTHER THINGS, THE SODIUM AND DOPPLER COEFFICIENTS AND THE DYNAMIC BEHAVIOR ARE COMPUTED.

*REACTOR, FAST + COMPUTER PROGRAM + DESIGN STUDY + DOPPLER EFFECT + PLUTONIUM + REACTIVITY COEFFICIENT + REACTOR, BREEDER + REACTOR, LARGE + SODIUM COEFFICIENT + VOID COEFFICIENT

6-09714 HWANG RN + LOEWENSTEIN WB + ALMENAS KK + KNAPP WG + DOERNER RC + BUTLER DK + COHN C +

KARAM RA + KATO WY + DYER HL + SPINRAD BI + CROKE EJ + STEPHENSON, M + ULRICH AJ + MADELL JT

PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 23 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-32 THROUGH III-39, PP. 207-229, CFSTI, \$7.22 CY, \$2.00 MN

WITH RESPECT TO TUNGSTEN-BASED, FAST, BE- OR AL-REFLECTED ROCKET REACTORS - TEMPERATURE-DEPENDENT CROSS-SECTIONS OF W IN DOPPLER REGIONS, REACTIVITY COEFFICIENTS OF FUEL EXPANSION INTO REFLECTORS, EXPERIMENTS ON ZPR IX, REFLECTOR-BASED CONTROL.

*REACTOR, FAST + *SPACECRAFT + CONTROL ROD WORTH + CRITICAL ASSEMBLY FACILITY + DOPPLER EFFECT + EXPANSION REACTIVITY EFFECT + EXPERIMENT, GENERAL + FUEL EXPANSION COEFFICIENT + REACTOR DYNAMICS + REFLECTOR + ZPR IX (ANL ZERO POWER REACTOR)

6-09715 COHN CE + REDMAN WC + BRETSCHER MM + PLUMLEE KE

PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 9 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS IV-11 THROUGH IV-13, PP. 259-267, CFSTI, \$7.22 CY, \$2.00 CY

SPACE DEPENDENT TRANSFER FUNCTION FROM ONE-GROUP DIFFUSION EQUATIONS, USING STATICS TECHNIQUES AND OSCILLATION MEASUREMENT IN CRITICALITY EXPERIMENTS ARE DISCUSSED.

*SPACE DEPENDENT DYNAMICS + CRITICALITY EXPERIMENT + TRANSFER FUNCTION

6-09716 ROBINSON LE + PURVIANCE RT + WILLIS FL + SCHILTZ RJ + MONAWECK JH + DE VOLPI A + FREESE CH

PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 22 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS IV-14 THROUGH IV-18, PP. 268-290, CFSTI, \$7.22 CY, \$2.00 MN

MODIFICATION OF THE TREAT SMALL INTEGRAL SODIUM LOOPS, THEIR LOADING AND REMOTE HANDLING, PRESSURE TRANSDUCERS, REMOTE ENCAPSULATION OF PREIRRADIATED FUEL ELEMENTS FOR EXPOSURE IN TREAT, AND FAST-NEUTRON TRANSIENT DETECTION HODOSCOPE FOR MELTDOWN STUDIES ARE DISCUSSED IN THESE ARTICLES.

*IN PILE LOOP + *TREAT (TRANSIENT TEST REACTOR FACILITY) + FAILURE, FUEL ELEMENT + IN PILE EXPERIMENT + REACTOR, GRAPHITE MODERATED + REACTOR, TEST + REMOTE MANIPULATING AND VIEWING + SODIUM

6-09718 ADKINS CR

EFFECTS OF CHEMICAL BINDING ON THE DOPPLER BROADENED CROSS SECTION OF URANIUM IN A UO₂ LATTICE. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965

ARGONNE NATIONAL LABORATORY

ANL-7110 +. 4 PAGES, 8 REFERENCES, DECEMBER 1965, SECTION V-9, PP. 327-330, CFSTI, \$7.22 CY, \$2.00 MN

TO CALCULATE A PHONON FREQUENCY DISTRIBUTION, A COMPUTER SOLUTION WAS OBTAINED TO MAP, POINT BY POINT, THE IRREDUCIBLE ELEMENT OF THE BRILLOUIN ZONE AND PROVIDE THE WEIGHTS FOR EACH POINT. OTHER PROGRAMS HAVE BEEN WRITTEN TO CALCULATE THE DYNAMICAL MATRIX ELEMENTS AND TO DIAGONALIZE THE MATRIX TO DETERMINE THE FREQUENCY EIGENVALUES.

*DOPPLER EFFECT + *URANIUM OXIDE + COMPUTER PROGRAM

6-09719 KARAM RA

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09719 *CONTINUED*
SPATIAL DEPENDENCE OF PROMPT-NEUTRON CHAINS. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 3 PAGES, 1 TABLE, 5 REFERENCES, 1 FIGURE, DECEMBER 1965, SECTION V-10, PP. 330-332, CFSTI,
\$7.22 CY, \$2.00 MN.

IT WAS REPORTED THAT THE PROMPT-NEUTRON CHAINS IN REACTORS WITH REFLECTORS CONSTRUCTED OF LOW-ATOMIC-WEIGHT MATERIAL DIE OUT WITH MODES BESIDES THE ASYMPTOTIC MODE. IN THIS PAPER, THE RESULTS OF A STUDY OF THE SPATIAL DEPENDENCE OF THE DECAY RATES OF THE ASYMPTOTIC MODE AND OTHER MODES (APPROXIMATED BY A SINGLE MODE) ARE REPORTED FOR ASSEMBLIES NGS. 4B AND 6 OF ZERO POWER REACTOR-9 (ZPR-9). APPEARED ALSO IN TRANS. AMERICAN NUCLEAR SOCIETY, 8(1), P. 224 (1965).

*REFLECTOR + *SPACE DEPENDENT DYNAMICS + PROMPT NEUTRON + ROSSI ALPHA

6-09720 SANATHANAN CK
ON THE SYNTHESIS OF SPACE DEPENDENT TRANSFER FUNCTIONS. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 4 PAGES, 1 FIGURE, 12 REFERENCES, DECEMBER 1965, SECTION V-11, PP. 332-335, CFSTI, \$7.22 CY, \$2.00 MN

A PROCEDURE HAS BEEN DEVELOPED TO SYNTHESIZE THE SPACE DEPENDENT TRANSFER FUNCTION OF A LINEAR DYNAMIC SYSTEM USING FREQUENCY RESPONSE DATA.

*SPACE DEPENDENT DYNAMICS + *TRANSFER FUNCTION

6-09721 MACFARLANE DR
VAPORIZATION OF SODIUM IN REACTOR COOLANT CHANNELS. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 6 PAGES, 6 FIGURES, 8 REFERENCES, DECEMBER 1965, SECTION V-29, PP. 380-385, CFSTI, \$7.22 CY, \$2.00 MN.

THE WORK DESCRIBED HEREIN IS PART OF A CONTINUING PROGRAM TO OBTAIN A BETTER UNDERSTANDING OF COOLANT VAPORIZATION EFFECTS IN LARGE, FAST POWER REACTORS. ALTHOUGH ALL THE WORK PERFORMED SO FAR IS ANALYTIC IN NATURE, IT IS LIKELY THAT THE RESULTS WILL BE USEFUL IN LAYING GUIDELINES FOR FUTURE PLANNED TRANSIENT BOILING EXPERIMENTS WITH SODIUM. WHILE THE PROBLEM FORMULATION IS QUITE GENERAL, THE WORK IS ORIENTED TOWARD THE LARGE (1000 MWE) FAST BREEDER REACTOR HAVING URANIUM OXIDE OR URANIUM CARBIDE FUEL RODS.

*REACTOR, FAST + ANALYTICAL MODEL + COMPUTER PROGRAM + FLOW, TWO PHASE + HYDRAULIC ANALYSIS + SODIUM + THERMAL ANALYSIS

6-09722 DICKERMAN C + STEPHANY W + WRIGHT A
PARAMETRIC STUDIES USING A COOLANT EXPULSION MODEL. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 6 PAGES, 3 TABLES, 2 FIGURES, 6 REFERENCES, DECEMBER 1965, SECTION V-30, PP. 385-390, CFSTI, \$7.22 CY, \$2.00 MN

BECAUSE OF THE LACK OF EXPERIMENTAL DATA ON TRANSIENT BOILING OF LIQUID METALS, AND THE ABSENCE OF AN ADEQUATE THEORETICAL DESCRIPTION FOR SUCH SYSTEMS (OR, INDEED EVEN FOR THE COMPARATIVELY WELL-INVESTIGATED CASE OF WATER), A THEORETICAL PARAMETER STUDY HAS BEEN PERFORMED USING REPRESENTATIONS IN WHICH DETAILED HEAT TRANSFER PHENOMENA DO NOT ENTER EXPLICITLY. EMPHASIS WAS PLACED ON THE STUDY OF THE EFFECTS FACTORS SUCH AS COOLANT CHANNEL CROSS SECTIONAL AREA, CHANNEL LENGTH, MASS LOADING, AND POWER. IN PRINCIPLE, AT LEAST, THE MODEL IS SUFFICIENTLY GENERAL THAT HEAT-TRANSFER DATA COULD BE COMBINED WITH IT, WHEN THOSE DATA BECOME AVAILABLE. THIS STUDY REPRESENTS AN EXTENSION OF THE EARLIER, DETAILED CALCULATIONS BY R. BRITTON.

HYDRAULIC ANALYSIS + POOL BOILING + REACTOR, FAST + THEORETICAL INVESTIGATION + THERMAL ANALYSIS

6-09723 CARPENTER SG + OTTER JM + PASCHALL RK + ROYDEN HM
TUNGSTEN RESONANCE INTEGRALS AND DOPPLER COEFFICIENTS. QUARTERLY PROGRESS REPORT NO. 1, JULY-SEPTEMBER 1965
ATOMICS INTERNATIONAL
AI-65-225 + NASA-CR-54769 +. 21 PAGES, OCTOBER 29, 1965, CFSTI, \$1.00 CY, \$0.50 MF

REACTIVITY WORTHS OF SAMPLES OF TUNGSTEN, U-238, AND CARBON.

*DOPPLER EFFECT + COMPARISON, THEORY AND EXPERIENCE + COMPUTER PROGRAM + EXPERIMENT, GENERAL + MEASUREMENT, GENERAL + TUNGSTEN + URANIUM

6-09738 SHEFF JR + ALBRECHT KW
THE SPACE DEPENDENCE OF REACTOR NOISE. I - THEORY
UNIVERSITY OF WASHINGTON, SEATTLE, WASHINGTON
13 PAGES, 3 TABLES, 26 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING, 24(3), PAGES 246-259 (MARCH, 1966)

THE THEORY OF SPACE-DEPENDENT STOCHASTIC FLUCTUATIONS IS DEVELOPED IN SUFFICIENT GENERALITY

ACCESSION NUMBER 6-09719 TO 6-09738

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09738 *CONTINUED*

THAT ANY SPECIALIZATION CAN BE MADE TO A PARTICULAR REACTOR MODEL BY THE APPROPRIATE GREENS FUNCTION. THE CROSS-CORRELATION FUNCTION IS A DOUBLE CONVOLUTION OVER TWO GREENS FUNCTIONS AND THE CORRELATION FUNCTION OF EQUIVALENT NOISE SOURCES. A CLEAR DISTINCTION IS MADE BETWEEN FLUCTUATIONS IN THE NEUTRON DENSITY AND THE FLUCTUATIONS OBSERVED WITH A DETECTOR.

*NOISE ANALYSIS + FLUCTUATION + THEORETICAL INVESTIGATION

6-09739 NEAL LG + ZIVI SM
HYDRODYNAMIC STABILITY OF NATURAL CIRCULATION BOILING SYSTEMS. VOLUME I. A COMPARATIVE STUDY OF ANALYTICAL MODELS AND EXPERIMENTAL DATA
TRW SYSTEMS, REDONDO BEACH, CALIFORNIA
STL-372-14(1) +. 185 PAGES, JUNE 30, 1965, CFSTI, \$5.00 CY, \$1.00 MN

MECHANISMS OF HYDRODYNAMIC INSTABILITY, (BASIC TYPES OF HYDRODYNAMIC INSTABILITY, LUMPED PARAMETER APPROXIMATION OF VOID-FLOW FEEDBACK MECHANISM, EFFECTS OF HEAT CAPACITY AND THERMAL CONDUCTIVITY OF THE CHANNEL WALLS, TRANSPORTATION TIME DELAYS). OBSERVED EFFECT OF OPERATING PARAMETERS ON LOOP STABILITY, (EFFECT OF SYSTEM PRESSURE EFFECT OF SUBCOOLING, EFFECT OF FRICTIONAL DISTRIBUTION). THE DYNAMIC EQUATIONS FOR STABILITY MODELS (CONSERVATION EQUATIONS, SLIP, FRICTION AND HEAT TRANSFER EQUATIONS, METHODS OF SOLUTION). STABILITY MODELS (NON-LINEAR MODELS, LINEARIZED MODELS, OTHER MODELS). APPLICATION OF JONES MODEL TO THE EBWR INSTABILITY, CONCLUSIONS. EXPERIMENTAL DATA AND TEST LOOP DESCRIPTIONS.

ANALYTICAL MODEL + CIRCULATION, NATURAL (LOOPS AND REACTORS) + COMPARISON, THEORY AND EXPERIENCE + COMPUTER PROGRAM + DYNAMICS, NONLINEAR + EBWR (EXPERIMENTAL BOILING WATER REACTOR) + HYDRAULIC ANALYSIS + REACTOR STABILITY + REACTOR, BOILING WATER + THERMAL ANALYSIS

6-09741 SWIFT D + KRAUSE P
FUEL-COOLANT AND CLADDING-COOLANT INTERACTION STUDIES
ARGONNE NATIONAL LABORATORY
ANL-7055 +. 8 PAGES, 8 FIGURES, SECTION V.B.1, PP. 199-206 OF CHEMICAL ENGINEERING DIVISION SEMIANNUAL REPORT, JANUARY-JUNE 1965, OCTOBER, 1965, CFSTI, \$6.00 CY, \$1.25 MN

IN AN ARGON ATMOSPHERE, 0.300-G SAMPLES OF VARIOUS METALS WERE INDUCTIVELY HEATED AND DROPPED INTO A POOL OF LIQUID SODIUM. VARIOUS DEGREES OF DISPERSION OCCURRED, DEPENDING ON TEMPERATURE AND THE MATERIAL USED. METALS INVESTIGATED WERE CB, MC, TA, CB-1 PERCENT ZR ALLOY, NI, ZR, V, MILD STEEL, 304 SS, U, ARMCO IRON. NO CHEMICAL REACTION WAS OBSERVED.

*FAILURE, CLADDING + EXPERIMENT, GENERAL + MOLYBDENUM + NICKEL + NIOBIUM + SODIUM + STEEL, STAINLESS + TANTALUM + VANADIUM

6-09742 IVINS RO + BAKER L
TRANSIENT HEAT TRANSFER STUDIES - MEASUREMENT OF HEAT FLUX FROM A HEATED METAL SPHERE MOVING THROUGH WATER
ARGONNE NATIONAL LABORATORY
ANL-7055 +. 3 PAGES, 3 FIGURES, OCTOBER, 1965, SECTION V.B.2, PP. 206-208 OF CHEMICAL ENGINEERING DIVISION SEMIANNUAL REPORT, JANUARY-JUNE 1965, CFSTI, \$6.00 CY, \$1.25 MN

QUARTER-INCH NICKEL SPHERES WERE HEATED IN A FURNACE AND THEN CARRIED THROUGH WATER AT ABOUT 10 FT/SEC ON A SWINGING ARM. HEAT TRANSFER RATES OF A MILLION AND 3 MILLION BTU/HR/SQ.FT WERE MEASURED AT BALL TEMPERATURES OF 300 AND 1000 C.

HEAT TRANSFER EXPERIMENT + SPHERE + TEMPERATURE TRANSIENT + THERMAL ANALYSIS

6-09743 BAKER L + TEVEBAUGH AD + LEIBOWITZ L + CHASANOV M + FISCHER DF + MISHLER LW
SODIUM-AIR REACTION CALCULATIONS AND OTHER FAST REACTOR SAFETY STUDIES
ARGONNE NATIONAL LABORATORY
ANL-7055 +. 7 PAGES, 5 FIGURES, 1 TABLE, OCTOBER, 1965, SECTIONS V.B.3 AND 4, PP. 206-212 OF CHEMICAL ENGINEERING DIVISION SEMIANNUAL REPORT, JANUARY-JUNE 1965, CFSTI, \$6.00 CY \$1.25 MN.

CALCULATION OF THE MAXIMUM PRESSURE AND TEMPERATURE OBTAINABLE BY THE SODIUM-AIR REACTION, TAKING INTO ACCOUNT THERMAL DECOMPOSITION OF THE OXIDE, SHOW MAXIMUM VALUES OF ABOUT 100 PSIG AND 2000 C. HIGHER PRESSURE SEEMS ATTAINABLE WITH HIGHER STARTING PRESSURES. EXPERIMENTS ON FUEL SEGREGATION AND ON SPECIFIC HEAT OF MOLTEN UO₂ ARE BEING STARTED.

*FIRE + *SODIUM + FUEL SEGREGATION + HIGH TEMPERATURE + PRESSURE, INTERNAL + URANIUM OXIDE

6-09766 CARMICHAEL BM
EFFECT OF FISSION GAS BUBBLES ON THE RESPONSE OF MOLTEN FUEL REACTORS TO FAST TRANSIENTS
LOS ALAMOS SCIENTIFIC LABORATORY, NEW MEXICO
LA-DC-7476 + CONF-651009-7 +. 12 PAGES, 1965, CONFERENCE ON SAFETY, FUELS AND CORE DESIGN IN LARGE FAST POWER REACTORS, ARGONNE, ILLINOIS, CFSTI, \$1.00 CY, \$0.50 MN

INTEREST IN MOLTEN FUELS HAS, IN PART, BEEN STIMULATED BY THE SAFETY ADVANTAGES OFFERED BY THESE FUELS IN FAST REACTOR APPLICATIONS. THESE ADVANTAGES DERIVE FROM THE LARGE THERMAL EXPANSION COEFFICIENTS AVAILABLE IN LIQUID METALS. THE AIM IN THE ANALYSIS OF THE CLEAN FUEL TRANSIENTS WAS TO INVESTIGATE WHAT RANGE OF REACTIVITY INSERTION RATES MIGHT LEAD TO FUEL CAPSULE DAMAGE. HOWEVER, THE THRESHOLD FOR CAPSULE DAMAGE DUE TO THE PRESSURE RISE MIGHT BE EXPECTED TO LIE IN THE VICINITY OF THE PRESSURE OF 7500 PSI ASSOCIATED WITH THE 100/SEC RAMP.

*IN PILE-LOOP + *MOLTEN FUEL + *PLUTONIUM + IN PILE EXPERIMENT + METAL, LIQUID + REACTOR CONTROL +

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09766 *CONTINUED*
REACTOR KINETICS + REACTOR STABILITY + REACTOR TRANSIENT

6-09781 RINALDINI C + COEN V + FOGGI C + GALLI DE PARATESI S + LANZA F + RICCHENA R + RIEBOLD W + VOLTA G
TESI - AN ADVANCED POWER EXCURSION REACTOR FOR RESEARCH IN REACTOR SAFETY PRELIMINARY STUDIOS
EUROPEAN ATOMIC ENERGY COMMUNITY, BELGIUM
EUR-2433.E +. 196 PAGES 1965, DEP/MN

TESI (POWER EXCURSION REACTOR FOR SAFETY TESTS) IS A TREAT-TYPE REACTOR IMPROVED IN TWO WAYS, EITHER BY INCREASING THE MAXIMUM FINAL OPERATING TEMPERATURE OR BY REDUCING, BY A FACTOR OF TWO, THE FISSION CONCENTRATION IN THE REACTOR CORE. TWO VERSIONS OF TESI HAVE BEEN STUDIED - THE MEAN-TEMPERATURE (MT) VERSION, IN WHICH A ZIRCONIUM ALLOY CLADDING ENSURES FISSION PRODUCT RETENTION, AND THE HIGH-TEMPERATURE (HT) VERSION, IN WHICH NO METALLIC CANNING IS PRESENT. THE CHARACTERISTICS OF TREAT AND THE TWO VERSIONS OF TESI ARE SHOWN IN TABLE FORM.

*REACTOR, FAST BURST + *REACTOR, PULSED + DESTRUCTIVE TRANSIENT + GRAPHITE + ITALY + REACTOR, TEST

6-09822 AKCASU AZ + NOBLE LD
A NONLINEAR STUDY OF REACTORS WITH A LINEAR FEEDBACK
UNIVERSITY OF MICHIGAN
11 PAGES, 4 FIGURES, 1 TABLE, NUCLEAR SCIENCE AND ENGINEERING, 25(1), PP. 47-57 (MAY 1966)

SOLUTIONS OF THE POINT KINETIC EQUATIONS WITH DELAYED NEUTRONS FOR REACTOR SYSTEMS WITH ARBITRARY LINEAR FEEDBACK ARE INVESTIGATED. SOLUTIONS THAT ARE LAPLACE-TRANSFORMABLE ARE BOUNDED FOR ALL INITIAL PERTURBATIONS REGARDLESS OF WHETHER THE SYSTEM IS LINEARLY STABLE, PROVIDED THE LAPLACE TRANSFORM OF THE FEEDBACK KERNEL HAS NO ZEROS ON THE POSITIVE REAL AXIS. THERE ARE ALSO NONTRANSFORMABLE SOLUTIONS THAT POSSESS A FINITE ESCAPE TIME. THE GENERAL CONCLUSIONS ARE VERIFIED BY CONSIDERING SOME SPECIFIC FEEDBACK MODELS FOR WHICH EXACT SOLUTIONS ARE AVAILABLE. NUMERICAL SOLUTIONS FOR REACTOR SYSTEMS WITH MORE REALISTIC FEEDBACK MODELS, SUCH AS ONE USED TO DESCRIBE EBR-I, ARE OBTAINED BY A DIGITAL COMPUTER.

*DYNAMICS, NONLINEAR + COMPUTER, DIGITAL + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + EQUATION, NONLINEAR + REACTOR STABILITY + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED + THEORETICAL INVESTIGATION + TRANSFER FUNCTION

6-09823 HFJTMANK H
RIGOROUS SOLUTION OF THE INITIAL VALUE PROBLEM OF THE TIME-DEPENDENT REACTOR TRANSPORT
ATOMINSTITUT DER OESTERREICHISCHEN, VIENNA, AUSTRIA
2 PAGES, NUCLEAR SCIENCE AND ENGINEERING, 25(1), PP. 94-95 (MAY 1966)

WING WRITES THE SOLUTION OF AN INITIAL-VALUE PROBLEM OF THE TIME-DEPENDENT REACTOR EQUATION IN THE FORM OF A SEMIGROUP OF OPERATORS. THIS TECHNICAL NOTE GIVES A REPRESENTATION OF THIS SEMIGROUP FOR AN UNBOUNDED REACTOR.

*REACTOR DYNAMICS + REACTOR KINETICS + TRANSPORT THEORY

6-09824 KASTEN PR
SPACE-DEPENDENT REACTOR KINETICS
OAK RIDGE NATIONAL LABORATORY
4 PAGES, NUCLEAR SAFETY, 7(2), PP. 162-165 (WINTER 1965-1966)

RESULTS OF RECENT SPACE-TIME REACTOR KINETICS CALCULATIONS INDICATE THAT, IN GENERAL, SPATIAL EFFECTS ARE SIGNIFICANT AND CANNOT BE NEGLECTED IN STUDYING REACTOR BEHAVIOR OR IN DETERMINING REACTOR PARAMETERS. UNDER CERTAIN CIRCUMSTANCES THE SPACE-INDEPENDENT KINETICS MAY GIVE USEFUL INFORMATION, BUT THESE CONDITIONS ARE AT PRESENT POORLY DEFINED. IT IS NOT CLEAR WHAT INFLUENCE SPATIAL EFFECTS HAVE ON THE GENERAL SAFETY AND STABILITY CRITERIA DEVELOPED BY USING THE SPACE-INDEPENDENT MODEL. MUCH WORK STILL REMAINS TO BE DONE IN THIS AREA.

SPACE DEPENDENT DYNAMICS

6-09825 CHAUMONT JM + MARTIN J
STUDY OF THE TEMPERATURE SODIUM REACTIVITY COEFFICIENT IN LARGE FAST REACTORS
EURATOM + COMMISSARIAT A L ENERGIE ATOMIQUE, FRANCE
EUR-2230F + CEA-R-2555 +. 33 PAGES, 12 FIGURES, 1965, DEP/MN, IN FRENCH

AMONG THE THREE COMPONENTS OF THE SODIUM TEMPERATURE-REACTIVITY COEFFICIENT, THE FIRST ONE, ASSOCIATED NEUTRON CAPTURE IN SODIUM, IS SMALL AND ALWAYS POSITIVE. THE SECOND, ASSOCIATED WITH NEUTRON DEGRADATION BY ELASTIC OR INELASTIC SCATTERING OF SODIUM, IS INDEPENDENT OF GEOMETRY AND IS A FUNCTION OF FUEL ENRICHMENT. THE THIRD, ASSOCIATED WITH NEUTRON LEAKAGE, IS ALWAYS NEGATIVE AND VARIES WITH THE GEOMETRY IN A WAY THAT LIMITS THE POSSIBILITY OF REDUCING A POSITIVE SODIUM COEFFICIENT BY CORE-FLATTENING. EXPERIMENTAL AND THEORETICAL SODIUM REACTIVITY COEFFICIENTS ARE COMPARED.

*REACTOR, FAST + *REACTOR, LARGE + *SODIUM COEFFICIENT + COMPARISON, THEORY AND EXPERIENCE

6-09915 PERSIANI PJ + BUMP TR + KANN WJ

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09915 *CONTINUED*
FARET CORE 1 FUEL IRRADIATION PROGRAM AND REFERENCE DESIGN
ARGONNE NATIONAL LABORATORY
ANL-7106 +. 22 PAGES, 5 FIGURES, 9 TABLES, 6 REFERENCES, OCTOBER, 1965, CFSTI, \$2.00 CY, \$0.50 MN

A SERIES OF CRITICAL EXPERIMENTS WAS MADE TO CONFIRM THE PHYSICS ANALYSIS OF MULTIFUELED, NONUNIFORM CORE LOADINGS. MEASUREMENTS OF THE REACTIVITY OF 12 CONTROL RODS WERE COMPARED WITH CALCULATED VALUES FOR TWO BORON-10 ENRICHMENTS IN THE BORON CARBIDE CONTROL RODS.

*CONTROL ROD WORTH + *CRITICALITY EXPERIMENT + FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) + MEASUREMENT, REACTIVITY + REACTOR, FAST

6-09941 REACTIVITY MEASUREMENTS
ARGONNE NATIONAL LABORATORY
ANL-6849 +. 20 PAGES, 16 FIGURES, 1 TABLE, NOVEMBER, 1964, PAGES 15-35 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

CONTROL-ROD WORTHS, EXCESS REACTIVITY, TEMPERATURE COEFFICIENT, REACTIVITY EFFECT OF BORIC ACID, POWER COEFFICIENT, XENON AND SAMARIUM POISONING.

*BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + BORON + CONTROL ROD WORTH + POISON, SOLUBLE + POWER COEFFICIENT + REACTIVITY, EXCESS + TEMPERATURE COEFFICIENT + XENON

6-09944 POWER-DISTRIBUTION MEASUREMENTS. TRANSFER-FUNCTION MEASUREMENTS AND STABILITY ANALYSIS
ARGONNE NATIONAL LABORATORY
ANL-6849 +. 39 PAGES, 28 FIGURES, 1 TABLE, NOVEMBER, 1964, PAGES 35-50, 66-90 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

A VERY EXTENSIVE SET OF EXPERIMENTS WERE PERFORMED ON THE B-2 CORE FOR BORAX-V. POWER MAPPING WITH REMOVABLE FUEL RODS, AGREED WITH FLUX-SCANNING WIRE METHODS. A ROD OSCILLATOR AND ANALOG CROSS-CORRELATION EQUIPMENT WERE USED TO MEASURE THE REACTOR TRANSFER FUNCTIONS FOR POWERS UP TO 16 MW. THE MEASUREMENTS AGREED WITH THE THEORETICAL MODEL AND WERE USED IN STABILITY STUDIES THAT INDICATED THAT THE REACTOR WAS VERY STABLE UP TO 16 MW, AND THE TRENDS SUGGESTED A POWER-LEVEL INSTABILITY IN THE REGION OF 30 TO 40 MW. MEASUREMENTS AND DESCRIBING FUNCTION CALCULATIONS INDICATED THAT THE TRANSFER FUNCTIONS WERE NOT DISTORTED SIGNIFICANTLY BY THE NONLINEARITIES CAUSED BY LARGE REACTIVITY DISTURBANCES OR CHANGES IN POWER LEVEL. NOISE-ANALYSIS EXPERIMENTS WERE NOT CONCLUSIVE.

*ANALYTICAL MODEL + *COMPARISON, THEORY AND EXPERIENCE + *REACTOR STABILITY + *TEST, PLANT RESPONSE + *TRANSFER FUNCTION + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + COMPUTER, DIGITAL + MEASUREMENT, GENERAL + NOISE ANALYSIS + OPERATING EXPERIENCE + REACTOR, BOILING WATER

6-09985 GYFTOPOULOS EP
THEORETICAL AND EXPERIMENTAL CRITERIA FOR NONLINEAR REACTOR STABILITY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY
26 PAGES, 4 FIGURES, 1965, SOURCE

CRITERIA FOR NONLINEAR ASYMPTOTIC STABILITY OF NUCLEAR REACTOR SYSTEMS REPRESENTABLE BY POINT REACTOR KINETICS ARE DERIVED. THE REACTOR-SYSTEM MODEL INCLUDES ALL DELAYED NEUTRON PRECURSORS AND LINEAR FEEDBACK. THE RESULTS ARE ALSO EXTENDED TO SYSTEMS WHERE THE FEEDBACK IS NOT LINEAR. A PROCEDURE IS OUTLINED FOR INTERPRETING THE CRITERIA BY MEANS OF SMALL-AMPLITUDE PERTURBATION TESTS. THE PROCEDURE IS ILLUSTRATED BY USING EXPERIMENTAL TRANSFER-FUNCTION MEASUREMENTS FROM EBWR.

*DYNAMICS, NONLINEAR + *REACTOR STABILITY + DELAYED NEUTRON + EBWR (EXPERIMENTAL BOILING WATER REACTOR) + REACTOR, BOILING WATER + TRANSFER FUNCTION

6-09993 PORSCHING TA
NUMERICAL SOLUTION OF THE REACTOR KINETICS EQUATIONS BY APPROXIMATE EXPONENTIALS
BETTIS ATOMIC POWER LABORATORY, WEST MIFFLIN, PENNSYLVANIA
5 PAGES, 2 FIGURES, 12 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING, 25(2), PAGES 183-188 (JUNE, 1966)

A NUMERICAL SOLUTION OF THE REACTOR KINETICS EQUATIONS IS GIVEN IN TERMS OF A DIFFERENCE EQUATION INVOLVING AN EXPONENTIAL MATRIX. IT IS SHOWN THAT THIS EQUATION YIELDS A LOCAL ERROR OF THE ORDER OF THE TIME STEP-SIZE CUBED. THE EXPONENTIAL OF THE ORIGINAL EQUATION IS APPROXIMATED BY RATIONAL MATRIX FUNCTIONS, AND A BOUND FOR THE ERROR RESULTING FROM SUCH APPROXIMATIONS IS ESTABLISHED. THREE PARTICULAR RATIONAL MATRIX FUNCTIONS ARE PROPOSED, AND THE TWO PROBLEMS INVOLVING RAMP CHANGES IN REACTIVITY ARE SOLVED USING THEM.

*REACTOR KINETICS

6-09994 CHWASZCZEWSKI S + SZECHTER A + DYBOWSKI K
IMPROVED METHOD FOR THE PROMPT-NEUTRON-PERIOD MEASUREMENTS
INSTITUTE OF NUCLEAR RESEARCH, WARSAW-SWIERK, POLAND
2 PAGES, 2 FIGURES, 4 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING, 25(2), PAGES 201-202 (JUNE, 1966)

MODIFIED ROSSI-ALPHA METHOD APPLICABLE TO THERMAL REACTORS THAT HAVE LONG PROMPT-NEUTRON LIFETIMES.

*REACTOR DYNAMICS + *ROSSI ALPHA + THERMAL NEUTRON

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-09995 MOUGNIOT JC
THEORETICAL AND EXPERIMENTAL ASPECTS OF NEUTRONIC INTERACTION OF MULTIPLYING MEDIA
COMMISSARIAT A L'ENERGIE ATOMIQUE, FRANCE, CENTRE D'ETUDES NUCLEAIRES, SACLAY
CEA-R-2849 +. 93 PAGES, OCTOBER, 1965, CEA, DEP/MN

A THEORETICAL STUDY OF NEUTRONIC INTERACTION OF MULTIPLYING MEDIA IS PRESENTED. THE USE OF THE SURFACE MULTIPLICATION CONSTANT AND OF THE EFFECTIVE MULTIPLICATION CONSTANT IS CONSIDERED. THREE CLASSICAL METHODS OF INTERACTION CALCULATIONS ARE STUDIED IN PARALLEL, AND THE APPLICATION OF THE EFFECTIVE-MULTIPLICATION-CONSTANT METHOD TO PROBLEMS OF NUCLEAR SAFETY IS DISCUSSED.

*EQUATION, GENERAL + *MONTE CARLO + *NEUTRON INTERACTION + STATISTICAL CORRELATION

6-10057 FAST REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 2 PAGES, JANUARY 25, 1966, PAGES 75-76 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, DECEMBER, 1965, CFSTI, \$3.00

COOLANT (WATER) EXPULSION STUDIES SHOW WATER-HAMMER PRESSURE GREATER THAN INITIAL PRESSURE PULSES, WHICH INCREASE WITH INCREASING TEMPERATURE. CONSTRUCTION PROGRESS ON SODIUM SUPERHEAT EXPERIMENT. CRITICAL FLOW STUDIES SHOWED THAT (1) THE FLOWRATES WERE CONSIDERABLY HIGHER THAN THOSE PREDICTED ON THE BASIS OF PREVIOUS WORK, (2) THE CRITICAL FLOWRATE DID NOT EXHIBIT A MAXIMUM AS A FUNCTION OF QUALITY, AS PREDICTED BY LEVY AND MOODY MODELS, (3) THE ASSUMPTION OF THERMAL EQUILIBRIUM DOES NOT SEEM VALID.

*HYDRAULIC ANALYSIS + *REACTOR, LIQUID METAL COOLED + *THERMAL ANALYSIS + FLOW, TWO PHASE + SODIUM

6-10058 EQUATION OF STATE FOR FAST REACTOR ACCIDENTS. TRANSIENT-PRESSURE RESPONSE OF TRANSDUCERS AND MARK-I INTEGRAL LOOPS
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 4 PAGES, JANUARY 25, 1966, PAGES 76-79 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, DECEMBER, 1965, CFSTI, \$3.00

EFFECT OF POROSITY OF FUEL ELEMENTS ON THEIR EQUATION OF STATE IS OF INTEREST FOR FAST-REACTOR SAFETY STUDIES AS IT REDUCES THE PRESSURE AND INITIAL DISASSEMBLY RATE. THIS EFFECT IS DISCUSSED. TRANSIENT PRESSURE RESPONSE AND OSCILLATIONS OBSERVED IN MARK-I INTEGRAL LOOPS. THEORETICAL ANALYSIS OF TEMPERATURE DISTRIBUTION IN A SEVEN-PIN EBR-II FUEL SUBASSEMBLY FOR TREAT TESTS.

*EQUATION OF STATE + *IN PILE LOOP + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + IN PILE EXPERIMENT + REACTOR, BREEDER + REACTOR, FAST + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + REACTOR, TEST + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM

6-10059 TREAT
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 2 PAGES, JANUARY 25, 1966, PAGES 79-80 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, DECEMBER, 1965, CFSTI, \$3.00

TREAT IRRADIATION OF ZIRCALOY CLAD URANIUM DIOXIDE FUEL RODS SUSPENDED ABOVE WATER, AND OF HFIR FUEL, PROGRESS ON LARGE TREAT LOOP. KIWI-TNT TESTS ON URANIUM-WATER REACTION SHOWED THAT IT WENT TO 77 PERCENT COMPLETION IN SOME CASES WHEN TEMPERATURE REACHED THE BOILING POINT OF URANIUM.

*TREAT (TRANSIENT TEST REACTOR FACILITY) + HFIR (HIGH FLUX ISOTOPE REACTOR) + KIWI TNT (TRANSIENT NUCLEAR TEST) + METAL WATER REACTION + REACTOR, GRAPHITE MODERATED + REACTOR, RESEARCH + REACTOR, TEST + URANIUM DIOXIDE + ZIRCALOY

6-10060 ANALYSIS OF MELTDOWN EXPERIMENTS
ARGONNE NATIONAL LABORATORY
ANL-7152 +. 3 PAGES, FEBRUARY 24, 1966, PAGES 87-89 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, JANUARY, 1966, CFSTI, \$4.00

DISCUSSION OF TREAT MELTDOWN EXPERIMENTS, PARTICULARLY OF FLUX DEPRESSION IN HIGHLY ENRICHED SAMPLES. COVERS TREAT IRRADIATION OF SPERT, HFIR, PBF SAMPLES, CONSTRUCTION OF LARGE TREAT LOOP, INCLUDING A CONSTRUCTION ACCIDENT.

*FLUX DISTRIBUTION + *FUEL MELTDOWN + *HFIR (HIGH FLUX ISOTOPE REACTOR) + *PBF (POWER BURST FACILITY) + *SPERT, ALL (SPECIAL POWER EXCURSION REACTOR TEST) + *TREAT (TRANSIENT TEST REACTOR FACILITY) + REACTOR, GRAPHITE MODERATED + REACTOR, PRESSURIZED WATER + REACTOR, RESEARCH + REACTOR, TEST

6-10061 FAST REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7152 +. 1 PAGE, FEBRUARY 24, 1966, PAGE 87 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, JANUARY, 1966, CFSTI, \$4.00

IN COOLANT (WATER) EXPULSION STUDIES, THE PRESSURE PULSE INCREASES WITH INPUT POWER, INITIAL TEMPERATURE OF THE WATER, AND DENSITY OF THE LIQUID. WATER HAMMER IN A STEAM-WATER MIXTURE DOES NOT OCCUR NEAR THE SATURATION POINT. EXPERIMENTS ON TWO-PHASE FLOW SHOWED HIGHER FLOW RATES AND MUCH SMALLER SLIP THAN PREDICTED BY FAUSKE, LEVY, OR MOODY MODELS. METASTABLE EFFECTS FROM CHOKED FLOW.

ACCESSION NUMBER 6-09995 TO 6-10061

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10061 *CONTINUED*
*HYDRAULIC ANALYSIS + *THERMAL ANALYSIS + REACTOR, FAST

6-10062 CHEMICAL AND ASSOCIATED ENERGY-TRANSFER PROBLEMS IN REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7152 +. 7 PAGES, 2 TABLES, 3 FIGURES, FEBRUARY 24, 1966, PAGES 90-96 OF REACTOR DEVELOPMENT PROGRAM
PROGRESS REPORT, JANUARY, 1966, CFSTI, \$4.00

ABNORMALLY HOT CLADDING METAL AND URANIUM OXIDE WERE DROPPED INTO LIQUID SODIUM, LITHIUM,
POTASSIUM, WATER, AND NITROGEN. FRAGMENTATION OCCURS, IF AND ONLY IF THE DROPPED SAMPLE IS
MOLTEN AND IF THERE IS VIOLENT SUBCOOLED BOILING IN THE TRANSITION AND NUCLEATE REGIMES. THE
LATTER DOES NOT OCCUR ABOVE THE CRITICAL POINT.

*FAILURE, CLADDING + METAL, LIQUID + URANIUM DIOXIDE

6-10063 FAST REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7176 +. 2 PAGES, MARCH 23, 1966, PAGES 88-89 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT,
FEBRUARY, 1966, CFSTI, \$4.00

COOLANT (WATER) EXPULSION STUDIES REACHED MAXIMUM POWER (110 KW), RESULTING IN EXPULSION
VELOCITIES UP TO 5 M/SEC. PLANS FOR EXPERIMENTS ON LIQUID SUPERHEAT BEING MADE TO START
NUCLEATE BOILING FOR SODIUM-EXPULSION STUDIES, AND FOR CRITICAL FLOW STUDIES.

*HYDRAULIC ANALYSIS + *THERMAL ANALYSIS + NUCLEATE BOILING

6-10064 IRRADIATED FAST REACTOR OXIDE FUEL PINS
ARGONNE NATIONAL LABORATORY
ANL-7176 +. 2 PAGES, MARCH 23, 1966, PAGES 86-87 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT,
FEBRUARY, 1966, CFSTI, \$4.00

MTR IRRADIATION AND EXAMINATION OF EBR-2 TYPE OF URANIUM DIOXIDE FUEL PINS PRELIMINARY TO
TREAT EXPOSURE. SEVEN TREAT TRANSIENT IRRADIATIONS OF PROTOTYPE SEFOR FUEL.
ZIRCALOY-2-CLAD, VIBRATORILY PACKED URANIUM DIOXIDE SUBJECTED TO TRANSIENTS IN
ROOM-TEMPERATURE WATER. SPERT 1-D TYPE AND HFIR-TYPE FUEL PLATES HEATED ABOVE MELTING POINT
OF ALUMINUM BEFORE BEING COOLED WITH WATER. ZIRCALOY-2-CLAD URANIUM DIOXIDE FUEL PINS WERE
MELTED IN TREAT WHILE SUSPENDED ABOVE A POOL OF WATER (DETAILS GIVEN).

*TREAT (TRANSIENT TEST REACTOR FACILITY) + ALUMINUM + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) +
HFIR (HIGH FLUX ISOTOPE REACTOR) + METAL WATER REACTION + REACTOR, FAST +
SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR) + SPERT, ALL (SPECIAL POWER EXCURSION RCTR. TEST) +
URANIUM DIOXIDE + ZIRCALOY

6-10065 CONTAINMENT PROGRAM
ARGONNE NATIONAL LABORATORY
ANL-7176 +. 1 PAGE, MARCH 23, 1966, PAGE 89 OF REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, FEBRUARY,
1966, CFSTI, \$4.00

COMPUTER PROGRAMS, MOSTLY FROM PLOWSHARE, CAPABLE OF HANDLING THE BEHAVIOR OF MATERIAL IN THE
ELASTIC TO THE HIGH-PRESSURE HYDRODYNAMIC REGION. INCLUDES MECHANISMS SUCH AS CRUSHING,
COMPACTION, AND CRACK PROPAGATION. SOLUTION OF CERTAIN PROBLEMS IN SHELL VIBRATION.

*CONTAINMENT ANALYSIS + COMPUTER, DIGITAL + EQUATION OF STATE + STRESS ANALYSIS

6-10126 TREAT
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 3 PAGES, 1 TABLE, REFERENCES, JANUARY 25, 1966, PP. 79-81 OF ANL REACTOR DEVELOPMENT PROGRAM
PROGRESS REPORT, DECEMBER 1965, CFSTI, \$3.00 CY

OPERATIONS REPORT ON TREAT AND CONSTRUCTION OF LARGE TREAT LOOP.

HFIR (HIGH FLUX ISOTOPE REACTOR) + REACTOR, GRAPHITE MODERATED + REACTOR, RESEARCH + REACTOR, TEST +
TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM DIOXIDE + ZIRCONIUM

6-10127 MELTDOWN EXPERIMENTS WITH EBR-II PIN CLUSTERS
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 2 PAGES, JANUARY 25, 1966, PP. 78-79 OF ANL REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT,
DECEMBER 1965, CFSTI, \$3.00 CY

THEORY AND EXPERIMENTS ON LOOP MELTDOWN EXPERIMENTS IN TREAT WITH SEVEN-PIN EBR-II TYPE OF
FUEL CLUSTERS.

*EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + *FUEL ELEMENT + *THERMAL ANALYSIS + REACTOR, BREEDER +
REACTOR, FAST + REACTOR, LIQUID METAL COOLED

6-10128 EQUATION OF STATE FOR FAST REACTOR ACCIDENTS. TRANSIENT-PRESSURE RESPONSE OF TRANSDUCERS AND

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10128 *CONTINUED*
MARK-I INTEGRAL LOOPS
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 3 PAGES, JANUARY 25, 1966, PP. 76-78 OF ANL REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT,
DECEMBER 1965, CFSTI, \$3.00 CY

(1) EFFECT OF POROSITY ON EQUATION OF STATE. (2) EFFECT OF PRESSURE ON ELASTIC AND PLASTIC COOLANTS. (3) TRANSIENT PRESSURE RESPONSE OF TRANSDUCERS AND MARK I INTEGRAL LOOPS.

*EQUATION OF STATE + *HIGH TEMPERATURE + *POROUS MEDIA + INSTRUMENTATION, GENERAL + PRESSURE, EXTERNAL

6-10129 FAST REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 2 PAGES, JANUARY 25, 1966, PP. 75-76 OF ANL REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT,
DECEMBER 1965, CFSTI, \$3.00 CY

1. PRELIMINARY RESULTS OF COOLANT (WATER) EXPULSION STUDIES. 2. APPARATUS FOR SODIUM SUPERHEAT EXPERIMENTS. 3. CRITICAL-FLOW STUDIES SHOW THAT (1) THE OBTAINED FLOWRATES APPEAR CONSIDERABLY HIGHER THAN THOSE PREDICTED ON THE BASIS OF PREVIOUS INVESTIGATIONS, (2) THE CRITICAL FLOWRATE IS NOT FOUND TO EXHIBIT A MAXIMUM AS A FUNCTION OF QUALITY AS PREDICTED BY THE LEVY AND MOODY MODELS, (3) THE ASSUMPTION OF THERMAL EQUILIBRIUM APPEARS NOT TO BE VALID.

*HYDRAULIC ANALYSIS + *REACTOR, FAST + *THERMAL ANALYSIS

6-10133 FAST NEUTRONS. REPORT OF ACTIVITIES OF 2ND QUARTER 1965
COMMISSARIAT A L ENERGIE ATOMIQUE, CADARACHE, FRANCE. CENTRE D ETUDES NUCLEAIRES
ORNL-TR-900 +. 106 PAGES, 1965, JCL, \$9.10 FS, \$3.30 MF

RAPSODIE CONTROL-ROD-MECHANISM AND SAFETY REPORT, SODIUM-WATER REACTION IN EVAPORATOR. HARMONIE SAFETY REPORT, DOPPLER EFFECT AND PULSED OR MODULATED EXPERIMENTS. PIRANA TESTS, IN PARTICULAR, EXPLOSION IN SODIUM AND WATER, MELTING OF IRRADIATED URANIUM IN SODIUM. (NOT MUCH DATA).

*DOPPLER EFFECT + *FRANCE + *REACTOR, FAST + CONTROL ROD SCRAM MECHANISM + FUEL MELTDOWN + METAL WATER REACTION + REACTOR, PULSED + SAFEGUARDS REPORT, GENERAL + SODIUM + URANIUM

6-10139 KIRN FS + LOEWENSTEIN WB
EBR-II WET CRITICAL EXPERIMENTS
ARGONNE NATIONAL LABORATORY
ANL-6864 +. 46 PAGES, 15 TABLES, 25 FIGURES, OCTOBER 1964, CFSTI, \$2.00 CY

WET-CRITICAL EXPERIMENTS WERE PERFORMED IN THE EBR-II WITH SODIUM COOLANT IN THE REACTOR SYSTEM. MEASUREMENTS INCLUDED CONTROL-ROD WORTH, NEUTRON-SOURCE STRENGTH, NUCLEAR-INSTRUMENT RESPONSE, CRITICAL SIZE, ISOTHEMAL TEMPERATURE COEFFICIENT, AND REACTIVITY WORTH OF THE SODIUM COOLANT. THE MEASUREMENTS AGREED WELL WITH CALCULATED VALUES AND WITH VALUES EXTRAPOLATED FROM THE DRY CRITICAL EXPERIMENTS AND THE ZERO-POWER MOCKUP.

*CONTROL ROD CALIBRATION + *CRITICALITY EXPERIMENT + *EBR I AND II (EXPERIMENTAL REFFER REACTORS) + CONTROL ROD WORTH + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY + REACTOR STARTUP EXPERIENCE, INITIAL + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED + SOURCE, NEUTRON + TEMPERATURE COEFFICIENT

6-10143 BLUESTEIN I + MATTY TC + SCHULTZ MA
SHUTDOWN REACTIVITY METER DEVELOPMENT. PHASE II. OPERATION IN HIGH GAMMA FIELDS
MILLETRON, INC., IRWIN, PA.
NYO-3122-35 +. 109 PAGES, DECEMBER 31, 1965, CFSTI, \$4.00 CY, \$0.75 MN

TWO APPROACHES FOR USING CONVENTIONAL NEUTRON DETECTORS AND ELECTRONIC APPARATUS FOR SHUTDOWN-REACTIVITY MEASUREMENTS ON POWER REACTORS, USING NOISE-MEASUREMENT TECHNIQUES, ARE OUTLINED. A NARROW-BAND SYSTEM HAVING THE ADVANTAGE OF SIMPLICITY BUT ONLY MODERATE GAMMA REJECTION IS DESCRIBED, AS IS A COMPLEX WIDE-BAND MULTIPLE DETECTOR SYSTEM HAVING EXCELLENT THEORETICAL NEUTRON-TO-GAMMA DISCRIMINATION. THE APPROACH FINALLY USED IS A NARROW BAND, ONE THAT EMPLOYS A NEW MULTIPLE ELEMENT DETECTOR. A COMPLETE SHUTDOWN-REACTIVITY-MONITORING SYSTEM IS PRESENTED, AND THE RESULTS OF PRELIMINARY TESTS WITH THE SYSTEM AT THE B AND W TEST REACTOR ARE GIVEN. THE TESTS PROVE THE GENERAL FEASIBILITY OF THE PRINCIPLE AND EQUIPMENT, BUT BECAUSE OF AN UNTIMELY FAILURE IN THE NEW DETECTOR, ULTIMATE APPLICATION TO ACTUAL REACTOR PROBLEMS HAS NOT YET BEEN DEMONSTRATED.

*COMPARISON, THEORY AND EXPERIENCE + *MEASUREMENT, REACTIVITY + *NOISE ANALYSIS + *REACTOR, TEST + *TEST, SYSTEM OPERABILITY + INSTRUMENTATION, NUCLEAR + MEASUREMENT, SUBCRITICALITY + TRANSFER FUNCTION

6-10144 FRY DN + ROUX DP + RICKER CW + STEPHENSON SE + HANAUER SH + TRINKO JR
NEUTRON FLUCTUATION MEASUREMENTS AT OAK RIDGE NATIONAL LABORATORY
OAK RIDGE NATIONAL LABORATORY
ORNL-P-1967 + CONF-660206-2 +. 18 PAGES, 1966, SYMPOSIUM ON NEUTRON NOISE, WAVES, AND PULSE PROPAGATION,
GAINESVILLE, FLORIDA, CFSTI, \$1.00 CY, \$0.50 MN

REVIEW OF NEUTRON POWER SPECTRAL-DENSITY MEASUREMENTS AT ORNL. NOISE-SPECTRA MEASUREMENTS IN THE MOLTEN-SALT REACTOR EXPERIMENT WERE USED TO DETERMINE THE CHANGE IN THE DELAYED-NEUTRON FRACTION FOR CIRCULATING AND NONCIRCULATING FUEL. NOISE-SPECTRA MEASUREMENTS OF THE FIRST

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10144 *CONTINUED*

HIGH FLUX ISOTOPE REACTOR CORE WERE USED TO DETERMINE ITS REACTIVITY. THE METHOD GAVE GOOD RESOLUTION AND WILL BE USED TO DETECT CHANGES IN WORTH OF SUCCESSIVE CORES. EXPERIMENTS IN THE OAK RIDGE RESEARCH REACTOR INDICATED THAT NOISE-SPECTRA MEASUREMENTS WOULD NOT BE USEFUL TO DETECT THE ONSET OF NUCLEATE BOILING. PULSE-TYPE DETECTORS WERE USED IN MEASUREMENTS AT THE POOL CRITICAL ASSEMBLY AS THE FIRST STEP IN A PROGRAM TO MEASURE SHUTDOWN REACTIVITY IN THE PRESENCE OF GAMMA RADIATION.

*HFIR (HIGH FLUX ISOTOPE REACTOR) + *MEASUREMENT, NOISE + *MSRE (MOLTEN SALT REACTOR EXPERIMENT) + *ORR (OAK RIDGE RESEARCH REACTOR) + *REACTOR, HIGH FLUX + *REACTOR, MOLTEN SALT + *REACTOR, RESEARCH + *REACTOR, TEST + DELAYED NEUTRON + MEASUREMENT, REACTIVITY + MEASUREMENT, SUBCRITICALITY + NOISE ANALYSIS + NUCLEATE BOILING + TRANSFER FUNCTION

6-10287 GIORDANO P + MATHIS A + MELUCCI G
DYNAMICS AND CONTROL STUDIES FOR A STEAM-GENERATING PRESSURE-TUBE REACTOR
COMITATO NAZIONALE PER L'ENERGIA NUCLEARE, ROME, ITALY
RT/ING(65)13 +. 37 PAGES, SEPTEMBER, 1965, DEP/MN

DYNAMIC STUDIES OF THE CIRENE REACTOR ARE DESCRIBED. AN ANALOG COMPUTER SIMULATION WAS USED DURING THE EARLY DESIGN TO HELP ESTABLISH MANY OF THE PLANT PARAMETERS. THE COMPUTER MODEL WAS REFINED DURING THE DESIGN OF THE PLANT AND USED IN CONTROL-SYSTEM STUDIES. A DIGITAL COMPUTER MODEL WAS USED FOR STABILITY STUDIES. THE DYNAMIC STUDIES INDICATED THAT THE REACTOR WAS BASICALLY UNSTABLE AND COULD NOT BE CONTROLLED MANUALLY, SO A FLUX CONTROLLER WOULD BE REQUIRED. THE PLANT BEHAVED SMOOTHLY WITH THE FLUX CONTROLLER AND COULD EASILY BE MADE TO BE LOAD-FOLLOWING.

*COMPUTER, ANALOG + *CONTROL SYSTEM + *MATHEMATICAL STUDY + *REACTOR DYNAMICS + *REACTOR STABILITY + *ANALYTICAL MODEL + *COMPUTER PROGRAM + *COMPUTER, DIGITAL + DESIGN STUDY + ITALY + REACTOR CONTROL + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + TRANSFER FUNCTION

6-10389 CALIGIURI GP + WUNDT H
DYNAMICS AND CONTROL OF THE FAST PULSED REACTOR SORA
EUROPEAN ATOMIC ENERGY COMMUNITY, ISPRA, ITALY
EUR-2553.E +. 102 PAGES, AUGUST 13, 1965, DEP.MN

A DETAILED DESCRIPTION OF THE DYNAMIC BEHAVIOR OF THE REACTIVITY-PULSED RESEARCH REACTOR SORA IS PRESENTED, BASED ON RESULTS OF A SIMULATION ON AN ANALOG COMPUTER. THE PERIODICALLY PULSED STATE IS TREATED, AS WELL AS DISTURBANCES FROM IT. TEMPERATURE FEEDBACK IS CONSIDERED. A SUITABLE CONTROL IS DESIGNED TO KEEP THE REACTOR STABLE EVEN THOUGH IT BECOMES PROMPT-SUPERCRITICAL FIFTY TIMES A SECOND. THE SIMULATION ITSELF REQUIRED NEW, COMBINED, DIGITAL-ANALOG TECHNIQUES, WHICH ARE EQUALLY DESCRIBED.

COMPUTER PROGRAM + COMPUTER, ANALOG + COMPUTER, DIGITAL + CONTROL SYSTEM + DESIGN STUDY + ITALY + MATHEMATICAL STUDY + REACTOR DYNAMICS + REACTOR KINETICS + REACTOR SAFETY SYSTEM + REACTOR, FAST BURST + REACTOR, PULSED

6-10430 ARGONNE NATIONAL LABORATORY PUBLICATIONS, JULY 1, 1964 - JUNE 30, 1965
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7087 +. 328 PAGES, AUGUST 1965 CFSTI, \$7.00 CY, \$1.50 MN

THIS PUBLICATION LIST IS A BIBLIOGRAPHY OF SCIENTIFIC AND TECHNICAL ACCOUNTS ORIGINATED AT ARGONNE AND PUBLISHED DURING FISCAL YEAR 1965. IT INCLUDES ITEMS PUBLISHED AS JOURNAL ARTICLES, TECHNICAL REPORTS, BOOKS, ETC., ALL OF WHICH HAVE BEEN MADE AVAILABLE TO THE PUBLIC. THE LIST IS DIVIDED INTO THREE PARTS - THE FIRST A LIST DIVISION, THE SECOND AN ALPHABETICAL AUTHOR INDEX, AND THE THIRD PART A KWIC SUBJECT INDEX. INCLUDED ARE SECTIONS ON RADIOLOGICAL PHYSICS, REACTOR PHYSICS, REACTOR ENGINEERING, INDUSTRIAL HYGIENE AND SAFETY, FIRE PROTECTION, AND CHEMICAL ENGINEERING.

*BIBLIOGRAPHY + *BURNOUT HEAT FLUX + *CHEMICAL REACTION + *DOSE MEASUREMENT, EXTERNAL + *HEAT TRANSFER + *REACTOR DYNAMICS + *REACTOR STABILITY + ACCIDENT ANALYSIS + FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) + METAL WATER REACTION + NOISE + REACTIVITY COEFFICIENT + REACTOR KINETICS + REACTOR TRANSIENT + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED + SPACE DEPENDENT DYNAMICS + VOID COEFFICIENT

6-10578 DIETZ KA
QUARTERLY TECHNICAL REPORT - STEP PROJECT, APRIL 1965-JUNE 1965
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
IDO-17145 +. 104 PAGES, 69 FIGURES, 14 TABLES, 30 REFERENCES, MAY 1966, CFSTI, \$4.00 CY, \$0.75 MN

QUARTERLY PROGRESS REPORT ON SNAPTRAN-1 TEST PROGRAM, LOFT CORE DESIGN, LOFT FACILITY AND EXPERIMENTAL DESIGN, LOFT ANALYSIS, LOFT RADIOLOGICAL STUDIES, AND INSTRUMENTATION STUDIES.

*LOFT (LOSS OF FLUID TEST) + *SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES) + *STEP (SAFETY TEST ENGINEERING PROGRAM) + ANALYTICAL MODEL + CONTAINMENT DESIGN + CONTAINMENT FILTERING SYSTEM + CONTAINMENT INSTRUMENTATION + FISSION PRODUCT TRANSPORT + INSTRUMENTATION, GENERAL + IODINE + REACTOR KINETICS + REACTOR, PRESSURIZED WATER + SAMPLING

6-10619 BRUNA JG + BRUNET JP + CAIZERGUES R + CLOUET D ORVAL C + KREMSEY J + TELLIER H + VERRIERE P
ALECTO - RESULTS OBTAINED WITH HOMOGENEOUS CRITICAL EXPERIMENTS ON PLUTONIUM 239, URANIUM 235 AND URANIUM

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10619 *CONTINUED*
233

COMMISSARIAT A L ENERGIE ATOMIQUE, FRANCE, CENTRE D ETUDES NUCLEAIRES, SACLAY
CEA-R-2814 +. 130 PAGES, 37 FIGURES, 24 TABLES, OCTOBER 1965, DEP. MN

IN THIS REPORT ARE GIVEN THE RESULTS OF THE HOMOGENEOUS CRITICALITY EXPERIMENTS ALECTO, MADE ON PLUTONIUM-239, URANIUM-235 AND URANIUM-233. AFTER A BRIEF DESCRIPTION OF THE EQUIPMENT, THE CRITICAL MASSES FOR CYLINDERS OF DIAMETERS VARYING FROM 25 TO 42 CM ARE GIVEN AND COMPARED WITH OTHER VALUES (FOREIGN RESULTS, CRITICALITY GUIDE). EXPERIMENTS RELATING TO CROSS SECTIONS AND CONSTANTS TO BE USED ON THESE MATERIALS ARE PRESENTED. LASTLY, KINETIC EXPERIMENTS ALLOW ONE TO COMPARE PULSED-NEUTRON METHODS WITH FLUCTUATION METHODS.

*CRITICALITY EXPERIMENT + CRITICALITY SAFETY + NOISE ANALYSIS + PLUTONIUM + PULSED NEUTRON TECHNIQUE + URANIUM

6-10695 LONG JK + MCVEAM RL + REYNOLDS AB + STEWART SL + WEITZBERG A + LERIDON A
CRITICAL MASS OF SEFOR MOCKUP IN ZPR-III
ARGONNE NATIONAL LABORATORY, IDAHO FALLS, IDAHO + GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA + CENTRE
D ETUDES NUCLEAIRES DE CADARACHE, FRANCE
2 PAGES, 1 FIGURE, 1 TABLE, 12 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING 25 (4)- 442-443 (1966)

CRITICALITY OF THE MOCKUP OF THE SOUTHWEST EXPERIMENTAL FAST OXIDE REACTOR (SEFOR) IN THE ZPR III FACILITY WAS ACHIEVED NOVEMBER 17, 1965. THE NEUTRON SPECTRUM AND URANIUM-TO-PLUTONIUM RATIO OF THIS ALL-PLUTONIUM CRITICAL IS CHARACTERISTIC OF LARGE, FAST, CERAMIC POWER REACTORS. THE CRITICAL LOADING WAS THE FIRST IN A SERIES OF EXPERIMENTS.

*SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR) + CRITICAL ASSEMBLY FACILITY + CRITICALITY EXPERIMENT + REACTOR, BREEDER + REACTOR, FAST + ZPR III (ANL ZERO POWER REACTOR)

6-10761 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MARCH, 1966
ARGONNE NATIONAL LABORATORY
ANL-7193 +. 102 PAGES, 26 FIGURES, 25 TABLES, REFERENCES, APRIL 22, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT, MARCH, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TESTS, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM + REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

6-10763 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MAY, 1966
ARGONNE NATIONAL LABORATORY
ANL-7219 +. 92 PAGES, 27 FIGURES, 31 TABLES, REFERENCES, JUNE 30, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR MAY, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM + REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

6-10764 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, JUNE, 1966
ARGONNE NATIONAL LABORATORY
ANL-7230 +. 80 PAGES, 17 FIGURES, 26 TABLES, REFERENCES, JULY 27, 1966, CFSTI, \$3.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR JUNE, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM + REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

6-10805 BIERMAN SR
PULSED NEUTRON SOURCE MEASUREMENTS OF THE Z-9 CRIB
HANFORD ATOMIC PRODUCTS OPERATION
HW-80913 +. 9 PAGES, MARCH 16, 1964, CFSTI, \$1.00 CY

THE PULSED-NEUTRON TECHNIQUE IS THOUGHT OF AS A DEVICE TO MEASURE THE SUBCRITICALITY OF COMPONENTS OF PLANTS WHICH HANDLE FISSIONABLE MATERIAL. THE ACTUAL EXPERIMENTS IN THE HANFORD CRITICAL MASS LABORATORY WERE DONE IN CONJUNCTION WITH MEASUREMENTS OF CRITICAL MASS, CONTROL AND SAFETY ROD WORTH, AND NEUTRON LIFETIMES. INCLUDES ANALYSIS OF THE EXPERIMENTS.

*FUEL HANDLING + *PULSED NEUTRON TECHNIQUE + *SHUTDOWN MARGIN + CONTROL ROD WORTH + CRITICALITY SAFETY + PROMPT NEUTRON LIFETIME + RADIOCHEMICAL PROCESSING

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10820 BUFFONI G + GALATI A
EVALUATION OF THE TEMPERATURE DISTRIBUTION IN THE FUEL UNDER TRANSIENT CONDITIONS OF POWER
COMITATO NAZIONALE PER L'ENERGIA NUCLEARE, ROME, ITALY
RT/FI-(65)52 +. 18 PAGES, NOVEMBER, 1965, DEP/MN

TEMPERATURE DISTRIBUTION IN A FUEL ROD OF A BOILING-WATER REACTOR DURING A TRANSIENT.

*REACTOR, BOILING WATER + *THERMAL ANALYSIS + FUEL ELEMENT

6-10821 HUERLIMANN T + SCHMID P
DETERMINATION OF THE STABLE REACTOR PERIOD IN THE PRESENCE OF A NEUTRON SOURCE
SWISS FEDERAL INSTITUTE FOR REACTOR RESEARCH, WURELINGEN, SWITZERLAND
ANL-TRANS-282 +. 6 PAGES, TRANSLATED FROM NUKLEONIK 5(6), PAGES 236-239 (1963), JCL, \$1.10 FS, \$0.80 MN

THE EFFECT OF AN EXTERNAL NEUTRON SOURCE UPON THE REACTOR PERIOD WAS STUDIED. IT WAS FOUND THAT THE STABLE PERIOD CAN BE DETERMINED BY MEANS OF A SIMPLE EXTRAPOLATION METHOD. IT CONSISTS IN PLOTTING THE RECIPROCAL VALUES OF THE INSTANTANEOUS PERIOD AGAINST THE RATIO OF THE SOURCE CAPACITY TO THE OBSERVED CAPACITY. THE MEASURING POINTS LIE ON A STRAIGHT LINE WHICH MEETS THE ORDINATE AT THE RECIPROCAL STABLE PERIOD. THE METHOD IS DEMONSTRATED ON THE BASIS OF MEASUREMENTS CARRIED OUT ON THE SAPHIR.

*REACTOR DYNAMICS

6-10822 TURNER SE
NUCLEAR ANALYSIS OF THE ELK RIVER REACTOR
COMBUSTION ENGINEERING, INC., DUNEDIN, FLORIDA
CEND-507 +. 69 PAGES, TABLES, FIGURES, OCTOBER, 1964, CFSTI, \$3.00 CY, \$0.75 MN

OF SAFETY INTEREST IS MAINLY SECTION IV ON REACTIVITY EFFECTS, SPECIFICALLY TEMPERATURE COEFFICIENT, VOID COEFFICIENT, XENON, SAMARIUM, AND PROTACTINIUM REACTIVITY EFFECTS, PLUS DOPPLER EFFECT.

*ELK RIVER + DOPPLER EFFECT + PROTACTINIUM + REACTOR, BOILING WATER + SAMARIUM + TEMPERATURE COEFFICIENT + VOID COEFFICIENT + XENON

6-10823 SMITH RI + MARYOTT JL
CALCULATED REACTOR PARAMETERS FOR THE HIGH POWER DENSITY CORE IN PRTR
HANFORD ATOMIC PRODUCTS OPERATION
HW-84544 (APP. 5) +. 9 PAGES, 1 TABLE, 2 REFERENCES, DECEMBER 3, 1964, CFSTI, \$1.00

UNDER CERTAIN OFF-STANDARD OPERATING CONDITIONS, BUBBLES OF HELIUM CAN BE INJECTED INTO THE MODERATOR IN THE CALANDRIA OF PRTR. THESE BUBBLES PRODUCE A REDUCTION IN THE DENSITY OF THE MODERATOR AND SIMULTANEOUSLY INCREASE THE HEIGHT OF THE MODERATOR. THESE TWO EFFECTS PRODUCE CHANGES IN K-EFFECTIVE FOR THE REACTOR WHICH ARE OPPOSITE IN SIGN. THE SUM OF THESE TWO EFFECTS IS THE NET CHANGE IN K-EFFECTIVE FOR THE REACTOR, AND THE VARIATION OF THIS SUM AS A FUNCTION OF THE PERCENTAGE VOID INJECTION AND INITIAL MODERATOR HEIGHT FOR THE HIGH POWER DENSITY CORE IN PRTR IS THE SUBJECT OF THIS REPORT.

*PRTR (PLUTONIUM RECYCLE TEST REACTOR) + *VOID COEFFICIENT + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

6-10828 NATELSON M + OSBORN RK + SHURE F
SPACE AND ENERGY EFFECTS IN REACTOR FLUCTUATION EXPERIMENTS
UNIVERSITY OF MICHIGAN, ANN ARBOR, MICHIGAN
28 PAGES, 5 FIGURES, REFERENCES, JOURNAL OF NUCLEAR ENERGY PARTS A/B, 20(7), PP. 557-585 (JULY 1966)

AN ANALYSIS OF THE SPACE AND ENERGY DEPENDENCE OF NEUTRON FLUCTUATIONS IS PRESENTED, AND APPLIED TO REACTOR FLUCTUATION EXPERIMENTS, ESPECIALLY ON SPECTRAL DENSITY AND VARIANCE TO MEAN. INFINITE AND FINITE-GEOMETRY-REACTOR MODELS. CALCULATIONS ON EFFECTS OF DETECTOR SIZE, SHAPE AND LOCATION, AND DELAYED NEUTRONS. TWO-ENERGY GROUP MODEL.

*NOISE ANALYSIS + *SPACE DEPENDENT DYNAMICS + DELAYED NEUTRON + REACTOR, LARGE

6-10906 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
6 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 11 ASKS FOR DETAILS OF STARTUP STEAM-LINE RUPTURE, REFUELING, AND CONTROL-ROD-EJECTION ACCIDENTS. ANSWER DESCRIBES GENERALIZED COURSE OF ONOFRE RESULTS AS NOT SIGNIFICANTLY DIFFERENT FOR ROD EJECTION.

*ACCIDENT, CONTROL ROD EJECTION + *ACCIDENT, CONTROL ROD WITHDRAWAL + *ACCIDENT, REFUELING +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *STEAM LINE RUPTURE + INDIAN POINT II +
REACTOR, PRESSURIZED WATER

6-10907 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-10907 *CONTINUED*
MARCH 31, 1966, DOCKET NO. 5G-247, PDR

QUESTION 12. BORATED SAFETY-INJECTION WATER WILL BE DILUTED BY SPILLED COOLANT, BUT SIMULTANEOUS DILUTION BY SPILLED SECONDARY WATER IS CONSIDERED INCREDIBLE BECAUSE OF PRECAUTIONS TAKEN. THIS DILUTION TAKES PLACE ONLY DURING THE RECIRCULATION OF CONTAINMENT SUMP WATER AND LASTS ONLY 10 MIN. EVEN THEN, RESIDUAL CORE HEAT PROVIDES ENOUGH STEAM VOID TO SHUT DOWN THE CORE AND KEEP SUBCRITICAL, REGARDLESS OF CONTROL RODS OR FISSION PRODUCT POISONING. IN ANY CASE, POWER GENERATION WOULD BE RESTRICTED TO 4 PERCENT - THE RESIDUAL HEAT-EXCHANGER CAPACITY.

*DILUTION + *POISON, SOLUBLE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SAFETY INJECTION + INDIAN POINT II + REACTOR, PRESSURIZED WATER + SHUTDOWN MARGIN

6-11006 JAKEMAN D
PHYSICS OF NUCLEAR REACTORS. CHAPTER 9 - REACTIVITY CHANGES AND CONTROL
356 PAGES, THE ENGLISH UNIVERSITIES PRESS LTD (1966)

CHAPTER 9 CONTAINS A FEW TOPICS OF SAFETY INTEREST. THESE INCLUDE REACTIVITY EFFECTS OF TEMPERATURE IN THERMAL REACTORS, REACTIVITY EFFECTS IN FAST REACTORS DUE TO FUEL EXPANSION, SODIUM VOIDS AND DOPPLER EFFECT, CONTROL METHODS, THEORY OF CONTROL RODS, AND REACTOR KINETICS.

CONTROL ROD + CONTROL, GENERAL + DOPPLER EFFECT + FUEL EXPANSION COEFFICIENT + REACTOR DYNAMICS + REACTOR, FAST + REACTOR, THERMAL + SODIUM COEFFICIENT + TEMPERATURE COEFFICIENT

6-11023 EICH WJ + WILLIAMS HI + AISU H + MINION GH
CALCULATION OF REACTIVITY WORTH OF ROD-CLUSTER CONTROL ELEMENTS AND CORRELATION OF THEORY WITH EXPERIMENT
WESTINGHOUSE ATOMIC POWER DIVISION, PITTSBURGH, PA.
11 PAGES, 8 FIGURES, 2 TABLES, 18 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING, 24(3), PAGES 272-283, (MARCH, 1966)

ANALYTICAL PROCEDURES FOR THE REPRESENTATION OF ROD-CLUSTER CONTROL ELEMENTS IN NUCLEAR DESIGN CALCULATIONS ARE DEVELOPED AND EVALUATED BY APPLICATION TO A VARIETY OF CRITICAL EXPERIMENTS. METHODS SUITABLE FOR USE IN FEW-GROUP DIFFUSION THEORY STUDIES ARE UTILIZED IN PREDICTING CRITICAL WATER HEIGHTS AND INTEGRAL WORTH MEASUREMENTS FOR REACTORS CONTAINING ARRAYS OF CYLINDRICAL ABSORBERS. RESULTS INDICATE THAT WORTH CAN BE CALCULATED TO WITHIN PLUS OR MINUS 3 PERCENT FOR A WIDE RANGE OF CONFIGURATIONS INVOLVING CLAD AND UNCLAD ABSORBERS OF 0.260, 0.330, AND 0.403 IN. DIAMETER.

*CONTROL ROD WORTH + ANALYTICAL MODEL + COMPARISON, THEORY AND EXPERIENCE + EXPERIMENT, GENERAL

6-11106 GASEOUS-FUELED CAVITY REACTORS - CRITICALITY CALCULATIONS AND ANALYSIS
GENERAL MOTORS CORPORATION, INDIANAPOLIS
NASA-CR-487 +. 156 PAGES, FIGURES, TABLES, 11 REFERENCES, JULY 1966, CFSTI \$5.00 CY, \$1.00 MF

REPORT INCLUDES, AMONG OTHER SUBJECTS, A CALCULATION OF THE TEMPERATURE COEFFICIENT OF GASEOUS-FUELED CAVITY REACTORS.

*AEROSPACE SAFETY + *TEMPERATURE COEFFICIENT

6-11139 GRONROOS H
ANALOG COMPUTER STUDY OF THERMIONIC-REACTOR POWER-PLANT TRANSIENTS
CALIFORNIA INST. OF TECH., PASADENA
2 PAGES, 1 FIGURE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 165-166.

THE MODELS AND EQUATIONS USED IN A COMPUTER STUDY OF A 50-KW ELECTRICAL POWER REACTOR (FAST, LIQUID-METAL COOLED) ARE BRIEFLY DISCUSSED.

*SNAP, GENERAL (SYSTEMS FOR NUCLEAR AUX. POWER) + REACTOR TRANSIENT

6-11157 GELINAS RJ + OSBORN RK
REACTOR NOISE ANALYSIS FROM OBSERVATIONS ON THE HIGH-ENERGY RADIATION FROM THE REACTOR CORE
LAWRENCE RADIATION LABORATORY + MICHIGAN UNIVERSITY, ANN ARBOR
UCRL-14719-T + CONF-660206-18 +. 26 PAGES, FROM SYMPOSIUM ON NEUTRON NOISE, WAVES, AND PULSE PROPAGATION, GAINESVILLE, FLORIDA, 1966, CFSTI \$2.00 CY, \$0.50 MN

PAPER PRESENTS A THEORY FOR INTERPRETING A NOISE EXPERIMENT PERFORMED BY USING A PHOTON DETECTOR TO MEASURE THE FLUCTUATIONS IN THE HIGH ENERGY RADIATION DISTRIBUTION FROM THE REACTOR CORE. A PHOTON DETECTOR IS PLACED OUTSIDE A REACTOR CORE. THEORETICAL DESCRIPTION OF THE OBSERVABLES OF AN EXPERIMENT. UPON COMPARISON WITH THE CORRESPONDING EXPRESSIONS FROM A CONVENTIONAL NEUTRON-NOISE ANALYSIS, IT IS FOUND THAT THE SAME NEUTRON-CORRELATION INFORMATION IS OBTAINABLE IN PRINCIPLE BY A PHOTON-DETECTING NOISE ANALYSIS AS BY CONVENTIONAL TECHNIQUES.

*GAMMA + *NOISE ANALYSIS

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11159 LITTLE WW + HARDIE RW
NEUTRONICS CHARACTERISTICS OF SELECTED COMPACT FAST REACTORS
PACIFIC NORTHWEST LABORATORY, BATTELLE NORTHWEST, RICHLAND
BNWL-283 +. 22 PAGES, 14 FIGURES, 6 TABLES, 7 REFERENCES, JULY 1966, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT DESCRIBES THE NEUTRONICS CHARACTERISTICS OF FAST, COMPACT REACTORS FUELED BY TUNGSTEN-CONTAINING CERMETS CONTAINING EITHER U-235 DIOXIDE OR PU-239 MONONITRIDE. THE PRINCIPAL ITEMS STUDIED ARE REACTOR CRITICALITY AND FUEL BURNUP. FOR THE FUEL COMPOSITIONS AND VOID FRACTIONS CONSIDERED, REACTORS FUELED WITH U-233 OR PU-239 REQUIRE CONSIDERABLY LESS FUEL THAN REACTORS FUELED WITH U-235. ALL REACTORS CONSIDERED ARE RATHER INSENSITIVE TO CHANGES IN THE INVENTORY OF REFRACTORY METAL. OF SAFETY INTEREST ARE CHAPTER 3 (REACTIVITY-COEFFICIENT CALCULATIONS) AND CHAPTER 5 (KINETICS CHARACTERISTICS).

*REACTOR, FAST + NITRIDE + PLUTONIUM OXIDE + REACTIVITY COEFFICIENT + REACTOR KINETICS + TUNGSTEN + URANIUM DIOXIDE

6-11161 TUTTLE RJ
A SUMMARY OF THE CALCULATED CHARACTERISTICS OF THE EPITHERMAL CRITICAL ASSEMBLIES 1 THROUGH 13
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-MEMO-11799 +. 92 PAGES, JANUARY 12, 1966, CFSTI \$3.00 CY, \$0.75 MN

PROBLEM - SUMMARIZE THE RESULTS OF CALCULATIONS PERFORMED FOR THE CRITICAL ASSEMBLIES AT THE EPITHERMAL CRITICAL EXPERIMENT LABORATORY TO FACILITATE ANALYSIS OF THE EXPERIMENTAL RESULTS AND AID FUTURE EXPERIMENTAL PLANNING. RESULTS - CRITICALITY CALCULATIONS AND PERTURBATION THEORY CALCULATIONS OF THE PROMPT-NEUTRON LIFETIME, EFFECTIVE DELAYED-NEUTRON FRACTION AND AVERAGE FISSION IMPORTANCE ARE TABULATED FOR THE ECEL CORES 1-13. THE FLUX AND ADJOINT SPECTRA ARE TABULATED AND PRESENTED IN GRAPHICAL FORM. MATERIAL SPECIFICATIONS AND THE CROSS-SECTION LIBRARY USED IN THE CALCULATIONS ARE ALSO RECORDED. A BIBLIOGRAPHY OF THE EXPERIMENTAL PROGRAM IS PROVIDED.

*CRITICALITY EXPERIMENT + DELAYED NEUTRON + PROMPT NEUTRON LIFETIME + ROSSI ALPHA

6-11162 HALFEN FJ
SRE-PEP TRANSIENT EXCURSION ANALYSIS
ATOMICS INTERNATIONAL, DIVISION OF NORTH AMERICAN AVIATION, INC., CANOGA PARK, CALIFORNIA
NAA-SR-MEMO-9741 +. 35 PAGES, MARCH 30, 1964, CFSTI, \$2.00 CY

PROBLEM - PREPARE A MATHEMATICAL MODEL FOR THE SRE-PEP CORE NEUTRON AND THERMAL KINETICS, LOOP HYDRAULICS, AND PROTECTIVE SYSTEM. USE THIS MODEL TO INVESTIGATE THE TRANSIENT BEHAVIOR OF THIS SYSTEM DURING VARIOUS INCIDENTS FOR INCLUSION IN THE SAFEGUARDS REPORT. SPECIFICALLY, ANALYZE THE SRE CORE III (PEP) CONFIGURATION FOR THE FOLLOWING INCIDENTS - (1) UNCONTROLLED ROD WITHDRAWAL FROM SHUTDOWN, (2) UNCONTROLLED ROD WITHDRAWAL FROM FULL POWER, (3) LOSS OF MAIN COOLANT FLOW AT FULL POWER. RESULTS - THE ANALYSIS SHOWED THAT THE POSTULATED PROTECTIVE SYSTEM WILL PROVIDE BOTH PRIMARY AND BACKUP PROTECTION AGAINST EXCESSIVELY HIGH TEMPERATURES RESULTING FROM THE INCIDENTS STUDIED.

*SRE (SODIUM REACTOR EXPERIMENT) + ACCIDENT ANALYSIS + ACCIDENT, CONTROL ROD WITHDRAWAL + LOSS OF FLOW + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED

6-11267 SMITH D + KEETON DC
KINETICS OF POSITIVE AND NEGATIVE PERIOD MEASUREMENTS IN THE EGCR
TENNESSEE VALLEY AUTHORITY, OAK RIDGE
TID-22768 +. 36 PAGES, MAY 5, 1965, CFSTI, \$2.00 CY, \$0.50 MN

REPORT CONCERNS PLANS WHICH NEVER MATERIALIZED FOR MEASURING THE REACTIVITY OF THE EGCR BY POSITIVE AND NEGATIVE REACTOR-PERIOD EXPERIMENTS.

*EGCR (EXPERIMENTAL GAS COOLED REACTOR) + REACTIVITY, EXCESS + REACTOR TRANSIENT + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED + SHUTDOWN MARGIN

6-11268 HARDE R + STOHR KW
THE COMPACT SODIUM-COOLED NUCLEAR REACTOR KARLSRUHE KNK - PART II
KARLSRUHE NUCLEAR RESEARCH CENTER
6 PAGES, 12 FIGURES, 13 REFERENCES, ATOMWIRTSCHAFT 11(8/9) 448-453, AUGUST, SEPTEMBER 1966, IN GERMAN

REGARDING THE ZIRCONIUM-HYDRIDE-MODERATED, SODIUM-COOLED KNK REACTOR, POSITIVE POWER COEFFICIENT AT LOW POWER AND HIGH BURNUP ARE EXPLAINED, PLUS REQUIREMENTS FOR THE CONTROL SYSTEM. ACTIVATION OF PRIMARY SODIUM. COMPLETE SHEAR OF MASS PIPING OF PRIMARY SYSTEM REGARDED AS INCREDIBLE. BUDGET FOR EXPERIMENTS, INCLUDING SAFETY RESEARCH. REACTOR PHYSICS INCLUDING CONTROL-ROD WORTH AND DANGER COEFFICIENTS. EXPERIMENTS ON SMALL AND LARGE LEAKS IN THE SODIUM SYSTEM AND IN THE STEAM GENERATOR.

*GERMANY + *SODIUM + ACCIDENT, MAXIMUM CREDIBLE (MCA) + ACTIVATION + CONTROL ROD WORTH + CONTROL SYSTEM + COOLANT SYSTEM + DANGER-COEFFICIENT + FIRE + POWER COEFFICIENT + PRESSURE, INTERNAL + SAFETY STUDY

6-11281 BRICKSTOCK A + DAVIES AR + SMITH IC
SWANTIME. A TIME-DEPENDENT MULTI-GROUP DIFFUSION CODE FOR THE IBM-7030
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, ALDERMASTON
AWRE-O-3/66 +. 41 PAGES, MAY 1966, DEP.MN

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11281 *CONTINUED*

SWANTIME IS A CODE FOR THE TIME-DEPENDENT MULTI-GROUP DIFFUSION EQUATIONS IN SPHERICAL GEOMETRY. IT IS INTENDED PRIMARILY TO FOLLOW THE RESPONSE TO A NEUTRON PULSE INJECTED INTO A SYSTEM WITH SHORT PROMPT-NEUTRON LIFETIME MICROSECOND OR SUBMICROSECOND REGION.

*COMPUTER, DIGITAL + *PULSED NEUTRON TECHNIQUE + REACTOR, FAST

6-11282 HAUGSET K
A STUDY OF SPACE-DEPENDENT TRANSFER FUNCTIONS
INSTITUTT FOR ATOMENERGI, KJELLER, NORWAY

CONF-660624-1 + KR-107 +. 30 PAGES, MAY 1966, FROM EAES SYMPOSIUM ON ADVANCES IN REACTOR THEORY, KARLSRUHE, GERMANY, CFSTI, \$2.00 CY, \$0.50 MN

MEASUREMENT OF THE SPACE-DEPENDENT TRANSFER FUNCTION WAS PERFORMED IN THE ZERO-POWER REACTOR NORA, USING THE OSCILLATOR-ROD METHOD. FREQUENCY RANGE WAS FROM 0.03 TO 120 CPS, AND LARGE SPATIAL EFFECTS WERE DETECTED AT HIGH FREQUENCIES. THE EXPERIMENTAL RESULTS ARE COMPARED WITH A THEORETICAL MODEL OF THE SPACE-DEPENDENT TRANSFER FUNCTION. THIS MODEL IS BASED ON SPATIAL EIGENFUNCTION EXPANSION. TWO-GROUP DIFFUSION THEORY GIVES GOOD AGREEMENT WITH EXPERIMENT IN THE WHOLE FREQUENCY RANGE.

NORWAY + SPACE DEPENDENT DYNAMICS + TRANSFER FUNCTION

6-11283 WASSERMAN AA + BALCOMB JD + BODENSCHATZ CA + JOHNSON JA + STEINER GH + SPRINGER TE + JAMES LR + HONKA EK

REVIEW OF TRANSFER FUNCTION MEASUREMENTS IN THE NUCLEAR ROCKET PROGRAM USING NOISE TECHNIQUES
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA
LA-DC-7781 + CONF-660608-9 +. 18 PAGES, 1966, FROM SECOND AIAA PROPULSION JOINT SPECIALIST CONFERENCE, COLORADO SPRINGS, CFSTI, \$1.00 CY, \$0.50 MN

SUMMARIZES EXPERIENCE IN TRANSFER-FUNCTION MEASUREMENTS (BY USE OF NOISE TECHNIQUES) ACQUIRED DURING NUCLEAR-ROCKET REACTOR TESTS AT THE NUCLEAR ROCKET DEVELOPMENT STATION (NRDS). SUCH MEASUREMENTS, USING RANDOM OR PSEUDO-RANDOM INPUT SIGNALS AND CROSS-CORRELATION DATA-PROCESSING TECHNIQUES, WERE PERFORMED ON KIWI-A3, KIWI-B-4D, KIWI-B-4E, PHOEBUS-1A, NRX-A2, NRX-A3, AND NRX/EST. THE PURPOSES OF THESE MEASUREMENTS WERE TO AID IN VALIDATION OF DYNAMIC COMPUTER MODELS USED TO PREDICT OVERALL SYSTEM PERFORMANCE.

*NOISE ANALYSIS + *NUCLEAR ROCKET + *TRANSFER FUNCTION

6-11284 HAGEN JI + GOIN RW
BORAX-V NEUTRONICS
ARGONNE NATIONAL LABORATORY, ARGONNE

ANL-6904 +. 110 PAGES, 41 FIGURES, TABLES, 44 REFERENCES, DECEMBER 1965, CFSTI \$4.00 CY, \$0.75 MN

ITEMS OF SAFETY APPLICATION INCLUDE - CALCULATION OF REACTIVITY WORTH OF BORON-STEEL (STAINLESS) RODS AND OF THE CONTROL RODS. CONTROL-ROD CALIBRATION AND AVAILABLE EXCESS REACTIVITY. DISCUSSES BORIC ACID EFFECT, FLOODING, TEMPERATURE AND POWER COEFFICIENT, AND COUPLING OF SUPERHEATER AND ROILER.

*BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRDS) + *CONTROL ROD CALIBRATION + CONTROL ROD WORTH + FLOODING COEFFICIENT + POISON, SOLUBLE + POWER COEFFICIENT + REACTOR, BOILING WATER + REACTOR, SUPERHEAT + TEMPERATURE COEFFICIENT

6-11374 SNAPTRAN-1 TEST PROGRAM
PHILLIPS PETROLEUM COMPANY

100-17165 +. 9 PAGES, 3 FIGURES, 2 TABLES, REFERENCES, PAGES 1-9 OF QUARTERLY TECHNICAL REPORT, STEP PROJECT, JULY 1965, SEPTEMBER 1965, CFSTI \$3.00 CY, \$0.75 MN

IN SNAPTRAN-1 THE STEADY-STATE POWER TEST DETERMINED THE ISOTHERMAL TEMPERATURE COEFFICIENT OF -0.11 CENT PER DEGREE F. THE IMPULSE TRANSIENT TESTS INDICATED A SLIGHTLY HIGHER FEEDBACK COEFFICIENT THAN OBSERVED IN PREVIOUS TESTS. THE STEP TRANSIENT TESTS DETERMINED THE FEEDBACK COEFFICIENT UP TO AVERAGE CORE TEMPERATURE OF 1355 F. MEASURABLE HYDROGEN RELEASE OCCURRED ONLY WHEN THE AVERAGE FUEL TEMPERATURE EXCEEDED 1200 F, AND THE AMOUNT OF RELEASE DEPENDED ON THE FINAL TEMPERATURE REACHED IN THE FUEL.

*SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES) + HYDRIDE + TEMPERATURE COEFFICIENT + TRANSFER FUNCTION + ZIRCONIUM

6-11375 SNAPTRAN-2 TEST PROGRAM
PHILLIPS PETROLEUM COMPANY

100-17165 +. 35 PAGES, 8 FIGURES, 3 TABLES, REFERENCES, PAGES 10-44 OF QUARTERLY TECHNICAL REPORT, STEP PROJECT, JULY 1965, SEPTEMBER 1965, CFSTI \$3.00 CY

CONTROL AND INSTRUMENTATION FOR SNAPTRAN-2 PLANNED, MODIFIED, AND EVALUATED.

*SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES) + CONTROL SYSTEM + INSTRUMENTATION, CONTROL

6-11378 COHN CE + JOHNSON RJ + MACDONALD RN

CALCULATING SPACE-DEPENDENT REACTOR TRANSFER FUNCTIONS USING STATICS TECHNIQUES

ACCESSION NUMBER 6-11281 TO 6-11378

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11378 *CONTINUED*
ARGONNE NATIONAL LABORATORY, ARGONNE + GEORGIA INSTITUTE OF TECHNOLOGY, GEORGIA
9 PAGES, 6 FIGURES, NUCLEAR SCIENCE AND ENGINEERING, 26(2), PAGES 198-206, (OCTOBER 1966)

ASSUMING THAT THE EXTERNAL SOURCE AND THE FLUX RESPONSE ARE SINUSOIDAL, THE ORIGINAL TIME-DEPENDENT EQUATIONS TRANSFORM INTO A SET OF COMPLEX EQUATIONS DEPENDENT ON SPACE AND FREQUENCY BUT INDEPENDENT OF TIME. SEPARATING THE EQUATIONS INTO REAL AND IMAGINARY PARTS YIELDS COUPLED, INHOMOGENEOUS DIFFERENTIAL EQUATIONS (TWO FOR EACH GROUP). THESE CAN BE SOLVED BY WELL-KNOWN STATICS TECHNIQUES FOR THE REAL AND IMAGINARY COMPONENTS OF THE COMPLEX AMPLITUDES OF THE FLUXES. THIS METHOD WAS APPLIED TO THE NORA REACTOR. RESULTS OF THE CALCULATIONS CLOSELY REPRODUCE THE EXPERIMENTAL RESULTS FOR GAIN AND PHASE SHIFT.

*SPACE DEPENDENT DYNAMICS + *TRANSFER FUNCTION + NORWAY

6-11379 SHEFF JR + ALBRECHT RW
THE SPACE DEPENDENCE OF REACTOR NOISE-II CALCULATIONS
UNIVERSITY OF WASHINGTON, SEATTLE
15 PAGES, 11 FIGURES, NUCLEAR SCIENCE AND ENGINEERING, 26(2), PAGES 207-221, (OCTOBER 1966)

THE THEORY OF SPACE-DEPENDENT STOCHASTIC FLUCTUATIONS IS APPLIED TO THE INFINITE MEDIUM. THE RESULTING CROSS-CORRELATION AND CROSS-SPECTRAL-DENSITY FUNCTIONS YIELD AUTO-CORRELATION AND SPECTRAL-DENSITY FUNCTIONS WHICH DIFFER STRIKINGLY FROM THE USUAL POINT-REACTOR RESULT. IT IS SHOWN, HOWEVER, THAT THE POINT-REACTOR RESULT IS IDENTICAL TO THE RESULT OBTAINED IN AN INFINITE REACTOR WITH A UNIFORMLY DISTRIBUTED DETECTOR.

*NOISE ANALYSIS + *SPACE DEPENDENT DYNAMICS

6-11380 CANOSA J + BROOKS H
XENON-INDUCED OSCILLATIONS
GENERAL ELECTRIC COMPANY, PLEASANTON, CALIF. + HARVARD UNIVERSITY, CAMBRIDGE
17 PAGES, 9 FIGURES, 7 TABLES, NUCLEAR SCIENCE AND ENGINEERING, 26(2), PAGES 237-253, (OCTOBER 1966)

THE XENON-INDUCED OSCILLATIONS IN THE POWER LEVEL (FUNDAMENTAL MODE) AND IN THE POWER DISTRIBUTION (FIRST HARMONIC) HAVE BEEN STUDIED FOR A SLAB REACTOR WITH PROMPT POWER REACTIVITY FEEDBACK. ONE-GROUP SPACE-DEPENDENT KINETICS EQUATIONS AND LINEARIZED THEORY ARE USED THROUGHOUT. EXPLICIT FORMULAS GIVING THE EFFECTS OF THE COUPLING OF REACTOR MODES WITH THE FUNDAMENTAL MODE AND FIRST HARMONIC ARE OBTAINED. AT HIGHER NEUTRON FLUXES (10 TO THE 15), MODE COUPLING IS DESTABILIZING AND MIGHT BE SIGNIFICANT. DEPENDING ON FLUX LEVEL, A REFLECTED REACTOR MAY BE MORE STABLE THAN A BARE REACTOR AGAINST FUNDAMENTAL MODE OSCILLATIONS.

*REACTOR STABILITY + *XENON

6-11400 LOEWENSTEIN WB + BLUMENTHAL B
MIXED FUEL-CYCLE FAST BREEDER REACTORS NUCLEAR, SAFETY, AND MATERIALS CONSIDERATIONS
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7120 +. 8 PAGES, 3 FIGURES, 3 TABLES, 17 REFERENCES, OCTOBER 11-14, 1965, PAGES 751-758, PROCEEDINGS OF THE CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

TO MINIMIZE THE POSITIVE SODIUM VOID COEFFICIENT IN A FAST REACTOR WITHOUT COMPROMISING THE CONVERSION RATIO, POSSIBLE LOADING, AND SPECIFIC POWER, IT IS SUGGESTED THAT THE CENTER OF THE REACTOR BE LOADED WITH U-233 AND THORIUM.

*REACTOR, FAST + *SODIUM COEFFICIENT + *THORIUM

6-11401 KIEFHABER E + OTT K
SURVEY PARAMETER STUDY OF LARGE STEAM-COOLED FAST POWER REACTORS
KERNFORSCHUNGSZENTRUM, KARLSRUHE, GERMANY
ANL-7120 +. 11 PAGES, 10 FIGURES, 1 TABLE, 3 REFERENCES, OCTOBER 11-14, 1965, PAGES 815-825, PROCEEDINGS OF THE CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

EXPERIMENTS AND CALCULATIONS SHOW THAT FLOOD SAFETY CAN BE ACHIEVED IN A SMALL U-235 FUELED STEAM-COOLED FAST REACTOR BY USE OF SELECTED RESONANCE POISONS. UNTIL DATA ARE OBTAINED AND EVALUATED FOR SOFTER SPECTRA AND FOR PLUTONIUM FUEL, IT IS NOT POSSIBLE TO GUARANTEE THE VALIDITY OF THE MODEL FOR ALL REGIMES OF FLOODING WHICH CAN BE ENCOUNTERED IN PRACTICAL SYSTEMS.

*REACTOR, FAST + *REACTOR, GAS COOLED + *STEAM + FLOODING COEFFICIENT +
MSSR (MIXED SPECTRUM SUPERHEAT REACTOR)

6-11434 KLINE KH
ANALOG COMPUTER FOR THE ARGON FLUX MONITOR
ATOMICS INTERNATIONAL
NAA-SR-11355 +. 21 PAGES, 11 FIGURES, 3 REFERENCES, MAY 25, 1966, CFSTI \$1.00 CY, \$0.50 MN

AN ANALOG COMPUTER WAS DESIGNED AND BUILT TO SOLVE ANY ONE OF SEVERAL EQUATIONS TO DETERMINE NEUTRON FLUX BY THE ACTIVATION OF ARGON FLOWING THROUGH A PIPING SYSTEM IN A NUCLEAR REACTOR. INPUTS TO THE COMPUTER ARE FROM TRANSDUCERS THAT MEASURE COUNTING RATES, PRESSURES, MASS

ACCESSION NUMBER 6-11378 TO 6-11434

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11434 *CONTINUED*
FLOW, AND TEMPERATURES. THE OVERALL SYSTEM ACCURACY WAS 100 PERCENT, PLUS OR MINUS 1 PERCENT.

*INSTRUMENTATION, NUCLEAR + *NEUTRON + IN CORE MEASUREMENT + MEASUREMENT, REACTIVITY

6-11438 MOHLER RR
OPTIMAL NUCLEAR ROCKET ENGINE CONTROL
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-DC-6837 + CONF-650413-2 +. 35 PAGES, 5 FIGURES, 2 TABLES, 3 REFERENCES, FROM SYMPOSIUM ON NEUTRON
DYNAMICS AND CONTROL, TUCSON, ARIZONA, MARCH 12, 1965, CFSTI \$2.00 CY

THE PROBLEM OF CONTROLLING A NUCLEAR-ROCKET ENGINE SO AS TO MINIMIZE PROPELLANT CONSUMPTION IS ANALYZED. THE REQUIRED CONTROL CONSISTS OF A MAXIMUM-ALLOWABLE-EFFORT PROCESS. IN ADDITION TO CONSTRAINTS IN REACTIVITY AND FLOW RATE, THE FOLLOWING FACTORS WERE CONSIDERED - REACTOR POWER, RATE OF CHANGE, CORE TEMPERATURE, AND PUMP PERFORMANCE. THE ANALYSIS IS MADE BY USE OF THE MAXIMUM PRINCIPLE (PONTYAGIN) AND PHYSICAL ARGUMENTS.

*NUCLEAR ROCKET + *PONTYAGIN'S PRINCIPLE + MATHEMATICAL STUDY + REACTOR KINETICS + REACTOR, AIRCRAFT

6-11439 DEBACKER W
REACTOR POWER REDUCTION IN MINIMUM TIME INCLUDING RESTRICTION OF XENON POISONING
EUROPEAN ATOMIC ENERGY COMMUNITY, EURATOM
EUR-2506.E + CONF-650564-1 +. 24 PAGES, 6 FIGURES, FROM THEORETICAL AUTOMATICS CONGRESS, SACLAY, FRANCE,
JUNE 18, 1965, DEP. MN.

A GENERAL EQUATION FOR REACTOR OPERATION IS PRESENTED. THE MAXIMUM PRINCIPLE (PONTYAGIN) IS APPLIED TO THE GENERAL PROBLEM. THE HAMILTONIAN EQUATION AND RESULTING CURVES ARE GENERATED. THESE ARE THEN INSPECTED FOR THE OPTIMAL CONTROL.

*PONTYAGIN'S PRINCIPLE + MATHEMATICAL STUDY + REACTOR KINETICS + XENON

6-11440 BALL RM + BATCH ML + PITTS TG + BARRINGER HS + HOSTETLER DR + WOLFE GE
INDIAN POINT REACTOR NUCLEAR INSTRUMENTATION ASYMMETRY RESPONSE VERIFICATION
DABCOCK AND WILCOX CO., LYNCHBURG
BAW-1302 +. 80 PAGES, 15 FIGURES, 6 TABLES, JANUARY 1966, CFSTI

IN CORE A OF THE INDIAN POINT REACTOR, A DELIBERATE ASYMMETRIC POWER DISTRIBUTION WAS INDUCED AT LOW POWER, AND THE INDICATED NEUTRON FLUX ON EACH OF 18 POWER-RANGE CHAMBERS OUTSIDE THE PRESSURE VESSEL WAS COMPARED WITH VALUES DETERMINED ANALYTICALLY FOR THE SAME CONFIGURATION. THE RESULTS SHOWED THAT THE EXTERNAL POWER-RANGE DETECTORS RESPOND CORRECTLY TO AN ASYMMETRIC POWER DISTRIBUTION AND ARE CAPABLE OF INDICATING SUCH A DISTRIBUTION. THE RESPONSE OF THE CORE-POWER DISTRIBUTION AND NUCLEAR-INSTRUMENT READINGS AS XENON REDISTRIBUTED INDICATES THE DEGREE OF POWER ASYMMETRY. ANALYTIC CALCULATIONS WERE WITHIN 10 PERCENT OF MEASURED VALUES.

*FLUX DISTRIBUTION + *INSTRUMENTATION, NUCLEAR + DYNAMICS, NONLINEAR + IN CORE MEASUREMENT + INDIAN POINT I + REGULATING SYSTEM

6-11472 MUNNS JM
REACTOR COOLANT SYSTEM RATE-OF-CHANGE-OF-PRESSURE (DP/DT) TRIP
TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE
TID-22760 +. 9 PAGES, AUGUST 12, 1964, CFSTI, \$1.00 CY, \$0.50 MN

TWO METHODS WERE INVESTIGATED FOR POSSIBLE USE IN ACTUATING A REACTOR-COOLANT-SYSTEM DP/DT TRIP. THE IDEA WAS TO PROVIDE A SIMPLE YET RELIABLE TRIP WHILE REQUIRING A MINIMUM NUMBER OF CHANGES TO THE EXISTING SAFETY SYSTEM. THE METHODS ARE DEPICTED BY ONE-LINE DIAGRAMS.

*CONTAINMENT INSTRUMENTATION + *LOSS OF PRESSURE + EGCR (EXPERIMENTAL GAS COOLED REACTOR) + INSTRUMENTATION, PROCESS + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

6-11473 WILLIS WL + TAYLOR JF
TIME DOMAIN REFLECTOMETRY FOR LIQUID HYDROGEN LEVEL DETECTION
LOS ALAMOS SCIENTIFIC LABORATORY
LA-3474 +. 9 PAGES, 3 FIGURES, FEBRUARY 1, 1966, CFSTI \$1.00 CY, \$0.50 MN

A COMMERCIAL-TRANSMISSION-LINE IMPEDANCE-MEASURING SYSTEM WAS ADAPTED TO A CAPACITANCE LIQUID-LEVEL GAGE. THE LOW IMPEDANCE OF THE SYSTEM MAKES IT RADIATION-RESISTANT. THE SYSTEM IS ADAPTABLE TO DIGITAL OR ANALOG READOUT.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + HYDROGEN + NUCLEAR ROCKET

6-11483 GAGNE GA + WIERWILLE WW
CHARACTERIZATION OF TIME-VARYING HUMAN OPERATOR DYNAMICS (PROJECT ICARUS)
CORNELL AERONAUTICAL LABORATORY, INC., BUFFALO, NEW YORK
NASA-CR-539 +. 82 PAGES, 7 TABLES, 29 FIGURES, 11 REFERENCES, AUGUST 1966, CFSTI, \$3.00 CY

A STUDY WAS CONDUCTED TO DETERMINE THE PERFORMANCE OF PILOTS IN SINGLE-AXIS AND TWO-AXIS COMPENSATORY TRACKING TASKS WITH A VARIETY OF DISPLAYS. THE EXPERIMENTAL AND THEORETICAL INVESTIGATIONS USED TO APPLY AND EXTEND THE DETERMINISTIC THEORY OF TIME-VARYING

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11483 *CONTINUED*

HUMAN-OPERATOR CHARACTERIZATION ARE PRESENTED. THE AUTHORS CONCLUDE THAT THE NONLINEARITY AND TIME VARIATION OF THE HUMAN OPERATOR MADE THE USE OF A MODEL OF THE HUMAN OPERATOR IN A COMPLEX SITUATION DIFFICULT.

*ANALYTICAL MODEL + COMPUTER, ANALOG + CONTROL SYSTEM + INSTRUMENTATION, GENERAL

6-11484 PHYSICS RESEARCH QUARTERLY REPORT, JANUARY-MARCH 1966

BATTTELLE-NORTHWEST, RICHLAND, WASHINGTON

BNWL-284 +. 26 PAGES, 7 TABLES, 43 REFERENCES, 5 FIGURES, APRIL 15, 1966, CFSTI, \$2.00 CY, \$0.50 MN

OF POSSIBLE SAFETY INTEREST ARE THE FOLLOWING ITEMS - COMPUTER ANALYSIS OF REACTOR NOISE DATA. PARAMETERS ARE OBTAINED FROM THE EXPERIMENTAL DATA BY FITTING THE THEORETICAL FUNCTIONS TO THE DATA USING IMPROVED LEAST-SQUARES-FITTING TECHNIQUES, AND REACTIVITY WORTH OF NEUTRON-ABSORBING RODS IN PLUTONIUM-FUELED WATER-MODERATED SYSTEMS. HF AND B USED AS POISON. RESULTS IN TABULAR FORM. WORTH DEPENDS ON PU-240 AND MODERATOR-OXIDE RATIO.

BORON + COMPUTER, DIGITAL + CONTROL ROD WORTH + CRITICALITY EXPERIMENT + HAFNIUM + NOISE ANALYSIS + PLUTONIUM

6-11486 WINSON RW

THERMAL MODEL FOR USE IN SNAP SYSTEM SIMULATION

ATOMICS INTERNATIONAL, CANOGA PARK

NAA-SR-MEMO-10961 +. 22 PAGES, MARCH 2, 1966, CFSTI \$1.00 CY, \$0.50 MN

A THERMAL MODEL IN TRANSFER-FUNCTION FORM WAS DEVELOPED TO DESCRIBE THE HEAT TRANSFER WITHIN EITHER A FLUID-TO-FLUID OR FLUID-TO-SOLID HEAT EXCHANGE. THE MODEL IS INTENDED FOR USE AS A FOUR-TERMINAL NETWORK. THE MODEL IS AN ACCURATE THERMAL REPRESENTATION OF THE EXCHANGER, USING A MINIMAL MATHEMATICAL REPRESENTATION. AN APPROXIMATION OF THE MODEL IS PRESENTED WHICH SIMPLIFIES THE EQUATIONS TO BE USED ON AN ANALOG COMPUTER. TWO DIGITAL SUBROUTINES ARE ALSO GIVEN.

*ANALYTICAL MODEL + HEAT EXCHANGER + REACTOR, SPACE + SNAP, GENERAL (SYSTEMS FOR NUCLEAR AUX. POWER)

6-11598 LITTLE WW

K-III. A THREE-REGION KINETICS CODE IN FORTRAN-IV

BATTTELLE-NORTHWEST, RICHLAND

BNWL-252 +. 40 PAGES, FIGURES, 2 REFERENCES, JUNE 1966, CFSTI \$2.00 CY, \$0.50 MN

THIS PAPER DESCRIBES A COUPLED NEUTRONICS-HEAT-TRANSFER-KINETICS CODE IN FORTRAN-IV. POWER VARIATION IS COMPUTED BY USING A LUMPED-PARAMETER MODEL WITH UP TO SIX PRECURSOR GROUPS. SPATIAL TEMPERATURE DISTRIBUTION IN THREE REGIONS IS COMPUTED IN PLANE, CYLINDRICAL, OR SPHERICAL GEOMETRY. UP TO 30 SPATIAL NODES CAN BE EMPLOYED. BOTH LINEAR AND DOPPLER (1/T) REACTIVITY-FEEDBACK MECHANISMS ARE AVAILABLE. A TYPICAL CASE REQUIRES ABOUT 2 MIN OF UNIVAC-1107 TIME. INPUT INFORMATION, A SAMPLE CASE, AND A FORTRAN-IV SOURCE DECK LISTING ARE GIVEN.

*COMPUTER, DIGITAL + *SPACE DEPENDENT DYNAMICS + THERMAL ANALYSIS

6-11638 HAEFELE W

PROMPT SUPERCRITICAL POWER EXCURSIONS IN FAST REACTORS

KERNFORSCHUNGSZENTRUM, KARLSRUHE, INSTITUT FUER ANGEWANDTE REAKTORPHYSIK

EURFNR-68F + KFK-175 +. 31 PAGES, AUGUST 1963, JCL \$3.60 FS, \$1.13 MF

IN PREPARATION FOR DOPPLER COEFFICIENT MEASUREMENTS IN THE SEFOR, A METHOD WAS DEVELOPED FOR READING OFF THE PROMPT COEFFICIENT FROM THE CURVE OF THE PROMPT-SUPERCRITICAL POWER EXCURSION CAUSED BY RAMP-REACTIVITY ADDITION. INCLUDES CORRECTION FOR DELAYED NEUTRONS.

*DOPPLER COEFFICIENT + *SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR) + DELAYED NEUTRON + DYNAMICS, NONLINEAR + REACTOR, BREEDER + REACTOR, FAST

6-11639 GERTZ D + LEVINE J

FINAL REPORT FROM APRIL 1961 TO JUNE 1965. FEASIBILITY STUDY OF A UNIFIED DIGITAL INSTRUMENTATION AND

CONTROL SYSTEM FOR NUCLEAR POWER PLANTS

SPERRY RAND CORPORATION

NYO-2764-2 +. 320 PAGES, 180 FIGURES, JUNE 30, 1965, CFSTI \$7.00 CY

AFTER REVIEWING THE BASIC CONCEPTS OF INSTRUMENTATION, THE AUTHORS CONCLUDE THAT AN ALL-DIGITAL INSTRUMENT SYSTEM FOR NUCLEAR REACTORS IS DESIRABLE. A SYSTEM IS DESCRIBED WHICH USES ULTRASONIC TRANSDUCERS FOR DIGITAL MEASUREMENT OF TEMPERATURE, PRESSURE, AND LEVEL. THE ASSOCIATED ELECTRONICS TO HANDLE AND PROCESS THE DIGITAL SIGNALS FROM THESE TRANSDUCERS IS ALSO GIVEN.

*INSTRUMENTATION, GENERAL + INSTRUMENTATION, LIQUID LEVEL DETECTION + INSTRUMENTATION, PROCESS + INSTRUMENTATION, TEMPERATURE

6-11797 GALL DA + DOYLE EF + BOURNE JG

AN AUTOMATIC FLOW BALANCING DEVICE FOR BOILING WATER REACTORS

ACCESSION NUMBER 6-11483 TO 6-11797

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-11797 *CONTINUED*
DYNATECH CORPORATION, CAMBRIDGE, MASSACHUSETTS
5 PAGES, 3 FIGURES, 7 REFERENCES, NUCLEAR APPLICATIONS 2(3), PAGES 226-230, JUNE 1966

DESCRIBES A DEVICE TO CONTROL THE FRACTION OF VAPOR IN THE EXIT STEAM OF INDIVIDUAL FUEL-ELEMENT ASSEMBLIES FOR BOILING-WATER REACTORS. THE DEVICE CONSISTS OF TWO VENTURIS AND A PRESSURE-SIGNAL COMPARISON DEVICE WHICH CONTROLS THE FLOW BY MEANS OF A HYDRAULICALLY OPERATED VALVE. RESULTS INDICATED THAT THE DISCHARGE QUALITY WAS HELD TO PLUS OR MINUS 6 PERCENT OF THE DESIGN VALUE DURING TRANSIENTS IN THE HEAT TRANSFER RATE OF UP TO 25 PERCENT.

*CONTROL, GENERAL + *STEAM + REACTOR, BOILING WATER + VAPOR, VAPOR PRESSURE

6-11808 SMALLEY WR + PAXSON E
ENGINEERING AND METALLURGICAL EVALUATION OF AN IRRADIATED YANKEE CORE I CONTROL ROD
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, ATOMIC POWER DIVISION
WCAP-6074 +. 58 PAGES, 26 FIGURES, 8 TABLES, 8 REFERENCES, DOCKET NO. 50-29, JULY 1966, CFSTI \$3.00 CY, \$0.50 MN

NICKEL-PLATED SILVER-INDIUM-CADMIUM CONTROL RODS FROM YANKEE CORE I WERE EXAMINED TO DETERMINE THE EFFECTS OF REACTOR EXPOSURE ON THEIR IRRADIATION STABILITY. THE SAMPLES WERE EVALUATED FOR CHANGES IN SURFACE CONDITION, DIMENSIONS, MICROSTRUCTURE, AND TENSILE PROPERTIES. LARGE AREAS OF THE CONTROL-RODS ABSORBERS WERE DEVOID OF NICKEL PLATE, AND THE REMAINING PLATING HAD BEEN ATTACKED BY THE REACTOR COOLANT. ALSO, INTERNAL OXIDATION OF THE BASE METAL OCCURRED. THE AG-IN-CD ALLOY ITSELF DISPLAYED GOOD DIMENSIONAL AND IRRADIATION STABILITY DURING REACTOR OPERATION. THE MICROSTRUCTURE OF THE ALLOY WAS ALMOST UNCHANGED, WITH NO EVIDENCE OF NEW PHASES OR SIGNIFICANT PRECIPITATION. SIMILARLY, THE HARDNESS AND TENSILE PROPERTIES OF IRRADIATED ABSORBER SAMPLES SHOWED NO APPRECIABLE CHANGES. NO HYDROGEN PICKUP OCCURRED.

*CONTROL ROD, SHIM SAFETY + *EXAMINATION + REACTOR, PRESSURIZED WATER + YANKEE

6-11843 HANNAFORD J
SECTION 15 - TIME RESPONSES FROM POWER TO VARIOUS TEMPERATURES IN INSTRUMENTED FUEL ASSEMBLIES
HPR-35 VOL. 11 +. 32 PAGES, 12 FIGURES, 2 TABLES, AUGUST 1964, PAGES 1-32, SECTION 15 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME 11, DEP MN.

MEASUREMENTS HAVE BEEN MADE TO DETERMINE THE TIME CONSTANTS OF THE FUEL, BURNOUT DETECTOR AND GAMMA THERMOMETERS OF TWO INSTRUMENTED FUEL ASSEMBLIES. THE FUEL TIME CONSTANTS HAVE BEEN DETERMINED AT VARIOUS ELEMENT POWER LEVELS USING CAN AND CENTRAL OXIDE THERMOCOUPLES. DIFFERENCES BETWEEN RESULTS ARE CONSIDERED TO BE DUE TO THE FLUX DEPRESSION AND TEMPERATURE PROFILE DISTORTION WITHIN A FUEL PIN. THIS MAY NECESSITATE, IN SOME DYNAMIC MODELS, THE USE OF TWO DIFFERENT TIME CONSTANTS FOR THE DOPPLER REACTIVITY COEFFICIENT AND HEAT TRANSFER BLOCKS.

*IN CORE MEASUREMENT + *RESPONSE TIME + BURNOUT HEAT FLUX + DOPPLER COEFFICIENT + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + MATHEMATICAL STUDY + OSCILLATOR, REACTIVITY + REACTOR STABILITY + REACTOR, BOILING WATER

6-11849 JAMES PR + TAIT D
USE OF A SMALL ANALOGUE COMPUTER IN THE INVESTIGATION OF THE KINETIC BEHAVIOR OF THE D.F.R.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
TR6-REPORT-1179 +. 20 PAGES, 6 FIGURES, 7 REFERENCES, JANUARY 20, 1966, UKAEA

AN EXISTING SMALL ANALOGUE COMPUTER AT DOUNREAY MADE POSSIBLE THE DETECTION OF NON-LINEARITY IN THE FAST COMPONENT OF THE REACTOR REACTIVITY FEEDBACK AND HAS REDUCED CONSIDERABLY THE EXPERIMENTAL TIME REQUIRED ON THE REACTOR TO MEASURE CONTROL ROD WORTHS AND THE DEGREE OF FLOW DEPENDENCE OF THE REACTIVITY FEEDBACK. THE COMPUTER ALSO SIMULATES THE EFFECTS OF ACTUAL OR PROJECTED CHANGES IN THE REACTOR OPERATING CONDITIONS AND DETERMINES THEIR IMPLICATIONS FOR THE REACTOR SAFETY.

*COMPUTER, ANALOG + *DOUNREAY (UK) + CONTROL ROD WORTH + REACTOR, BREEDER + TRANSFER FUNCTION

6-12035 SAFETY EVALUATION REPORT MH-1A (STURGIS) FLOPING NUCLEAR POWER PLANT CONTROL ROD EJECTION ACCIDENT
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-67-1 +. 16 PAGES, 1 TABLE, JULY 1966, OCE

THE ANALYSIS OF A 2.8 PERCENT INJECTION IN 88 MILLISEC, WITH A NEGATIVE C.COC03 PER DEG C DOPPLER COEFFICIENT AND THE TEMPERATURE CHANGE OF AN AVERAGE ELEMENT, GAVE TWO POWER PEAKS OF 520 AND 180 MW-SEC RESPECTIVELY. A HIGHLY CONSERVATIVE MODEL YIELDED 23 PERCENT MELTDOWN, WHILE COMPARISON WITH SPERT GAVE A WORST CASE OF 10 OR A BEST ESTIMATE OF 1 PERCENT MELTDOWN. EVALUATION OF REACTOR VESSEL BY NOLTR 63-140 GAVE 415 MW-SEC AS CAPABILITY OF VESSEL, AND 310 WAS ASSIGNED TO THERMAL SHIELDS. A 40 PERCENT REDUCTION IN DOPPLER EFFECT WOULD NOT CHANGE CORE MELTDOWN. ARCHS CONCLUDED THAT FURTHER REFINED CALCULATIONS ARE NOT NEEDED, RECOMMENDED MODIFICATION TO ROD DRIVES, AND ALLOWED INITIAL OPERATION (WITH LOW FISSION PRODUCT) UNTIL THE FIRST REFUELING, WHICH MAY AGAIN BRING THE CENTRAL RODS BACK UP TO 2.8 PERCENT REACTIVITY.

*SAFETY EVALUATION + ACCIDENT, CONTROL ROD EJECTION + CONTAINMENT, PRESSURE VESSEL + CONTAINMENT, SHOCK GENERATION AND PROTECTION + FUEL MELTDOWN + REACTOR, ARMY + REACTOR, PRESSURIZED WATER

CATEGORY 6
REACTOR TRANSIENTS, KINETICS, AND STABILITY

6-12037 INTERIM REPORT. HEALTH AND SAFETY REVIEW OF MH-1S (STURGIS) FLOATING NUCLEAR POWER PLANT
FINAL SAFEGUARDS REPORT
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-66-4 +. 25 PAGES, 5 REFERENCES, MARCH 1, 1966, OCE

THE REVIEW, BASED ON FINAL SAFEGUARDS REPORTS AND ADDENDA, IS INTENDED ONLY FOR FT. BELVOIR OPERATION. A PREVIOUS REVIEW SHOWED THE UNIQUE SAFETY FEATURE OF MH1A TO BE SATISFACTORY BUT INDICATED 8(OUT OF 27) AEC CONSTRUCTION-PERMIT CRITERIA WERE NOT FULFILLED, PRIMARILY BECAUSE OF LACK OF DETAILED INFORMATION. THIS REPORT CONSIDERS ONLY THOSE 8 CRITERIA (CRITERIA 3, 6, 7, 13, 15, 16, 19, AND 20). ALL ITEMS WERE SATISFACTORY EXCEPT 7, 19 AND 20. ITEM 7 CONSIDERED A ROD EJECTION OF THE CENTER ROD (2.8 PERCENT REACTIVITY) AS GIVING ONLY MINOR FUEL MELTING. HOWEVER, THE MOST CONSERVATIVE DOPPLER COEFFICIENT WAS NOT USED. ITEMS 19 AND 20 - THE CONTAINMENT IS SCHEDULED TO BE LEAK-RATE TESTED AT 50 PSIG RATHER THAN AT THE 140.3-PSI DESIGN PRESSURE. THUS THERE MAY BE UNKNOWN LEAKAGE PATHS EVIDENT ONLY AT HIGH PRESSURE.

*SAFETY EVALUATION + ACCIDENT, CONTROL ROD EJECTION + CONTAINMENT, HIGH PRESSURE +
MH 1A (MOBILE HIGH POWER PLANT 1A) + REACTOR, ARMY + REACTOR, PRESSURIZED WATER + TEST, LEAK RATE

6-12091 CARMICHAEL BM + LABAUVE RJ
CONTROL ROD CALCULATION TECHNIQUES WITH APPLICATIONS TO THE UHTREX REACTOR
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
LA-3194 +. 93 PAGES, 19 FIGURES, 13 TABLES, 14 REFERENCES, JUNE 7, 1965, CFSTI \$4.00 CY

TWO-GROUP, MULTIREGION, ANALYTIC CALCULATIONS OF CONTROL ROD WORTHS IN UHTREX ARE COMPARED WITH RESULTS FROM TWO-DIMENSIONAL, DIFFUSION THEORY (CRAM CODE), AND TWO-DIMENSIONAL, S-SUB-N TRANSPORT THEORY (DDK CODE).

*CONTROL ROD WORTH + *UHTREX (ULTRA HIGH TEMP. REACTOR EXPERIMENT) + COMPUTER PROGRAM + MATHEMATICAL STUDY

6-12092 HEARN TO
NRDS ANALYSIS OF THE KIWI 8-4D-202 NUCLEAR REACTOR CONTROL SYSTEM
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
LA-3301-MS +. 107 PAGES, 47 FIGURES, 12 REFERENCES, SEPTEMBER 20, 1965, CFSTI \$4.00 CY, \$0.75 MN

THE CONTROL SYSTEMS USED WITH THE KIWI 8-4D-202 REACTOR SERIES ARE EVALUATED THROUGH THE USE OF AN ANALOG COMPUTER SIMULATION. MODEL CHARACTERISTICS USED WERE, BY AND LARGE, OBTAINED FROM B. G. STRAIT OF N-4. THE THREE MODES OF CONTROL DISCUSSED ARE - AUTOMATIC REACTOR STARTUP, POWER CONTROL, AND POWER-TEMPERATURE CONTROL. A BRIEF ANALYSIS OF THE 8-4E-301 TEMPERATURE-CONTROL SYSTEM IS ALSO INCLUDED.

*ANALOG SIMULATION + *CONTROL SYSTEM + *KIWI + INSTRUMENTATION, NUCLEAR + NUCLEAR ROCKET +
REACTOR DYNAMICS + REACTOR KINETICS + SERVOMECHANISM

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-07739 CUTFORTH DC + MILES CC + VILLARREAL R
DEFECTIVE FUEL TESTS IN THE NUCLEAR SUPERHEATING REACTOR BORAX-V
ARGONNE NATIONAL LABORATORY, IDAHO
2 PAGES, 1 TABLE, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 9, PAGES 35-36

PRELIMINARY DATA FROM VBWR LOOP INDICATED A MILLION TIMES MORE IODINE CARRYOVER FROM SUPERHEAT FAILURE THAN FROM BOILER-ELEMENT FAILURE. BORAX V OPERATED WITH PURPOSELY DAMAGED BOILER AND SH FUEL TO TEST THIS (0.5 SQ. IN. OF CLADDING REMOVED TO WITHIN 2 MILS OF FUEL). ACTIVITIES IN SYSTEM FROM 1 DEFECTIVE SH FUEL SAMPLE WERE ABOUT THE SAME AS FROM 10 DEFECTIVE BOILER RODS, ALTHOUGH SH FUEL GAVE MORE SYSTEM CONTAMINATION. THIS SHOWS THAT UO₂-SS CERMET SH FUEL DOES NOT PRESENT A SUBSTANTIALLY GREATER HAZARD THAN UO₂-SS-CLAD BOILER FUEL. THE CERMET FUEL RUNS COOLER, AND SS MATRIX AIDS IN TRAPPING OF FISSION PRODUCTS.

*FAILURE, FUEL ELEMENT + *OPERATING EXPERIENCE + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) +
IN CORE MEASUREMENT + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

7-07742 BATTIST L + SMITH ER + LOWE SD + DELAPAZ A
FUEL-ELEMENT DEFECTS IN CERMET-TYPE FUELS IN THE SM-1 AND PM-3A REACTORS, AND CONSEQUENT PM-3A CONTAINMENT AIR ACTIVITY
NUCLEAR UTILITY SERVICES, INC. + U. S. NAVY CEC (NNPU), NUCLEAR UTILITY SERVICES, INC., WASHINGTON, D. C.
1 PAGE, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 9, PAGE 38

ANALYZING WATER ACTIVITY SHOWED THAT A CLADDING DEFECT HAD OCCURRED AND GAVE SIZE. AT PM3A, CONTAINMENT AIR WAS FILTERED, USING LOCAL EQUIPMENT.

*CONTAINMENT FILTERING SYSTEM + *FAILURE, CLADDING + *OPERATING EXPERIENCE + REACTOR, ARMY

7-08811 SHERWOOD RJ + STEVENS DC
SOME OBSERVATIONS ON NATURE AND PARTICLE SIZE OF AIRBORNE PLUTONIUM IN THE RADIO-CHEMICAL LABORATORIES, HARWELL
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-4672 +. 38 PAGES, 9 PLATES, 8 FIGURES, 11 TABLES, 9 REFERENCES, JUNE 1964, UKAEA

A NUMBER OF SAMPLES OF AIRBORNE DUST TAKEN IN AREAS IN WHICH PLUTONIUM IS PROCESSED HAVE BEEN AUTORADIOGRAPHED AND EXAMINED MICROSCOPICALLY TO DETERMINE THE SIZE AND ACTIVITY DISTRIBUTIONS OF THE ACTIVE DUST. ALTHOUGH THE MEDIAN PARTICLE ACTIVITY WAS OFTEN AS LITTLE AS 0.01 DPM, THE SPREAD OF ACTIVITY OBSERVED WAS ENORMOUS. IN ABOUT HALF THE SAMPLES, THE GREATER PART OF THE SAMPLE ACTIVITY COULD BE ATTRIBUTED TO A SINGLE PARTICLE WHOSE ACTIVITY WAS AS MUCH AS 10,000 OR 100,000 TIMES THE MEAN.

*AIRBORNE RELEASE + *PARTICLE SIZE + FILTER + FILTER, FIBERGLASS + FILTER, HIGH EFFICIENCY + GLOVE BOX + PARTICULATE + PLUTONIUM + PLUTONIUM + SAMPLING

7-09229 KRESS TS + NEILL FH
A MODEL FOR FISSION PRODUCT TRANSPORT AND DEPOSITION UNDER ISOTHERMAL CONDITIONS
OAK RIDGE NATIONAL LABORATORY
24 PAGES, 11 FIGURES, 13 REFERENCES- PAPER PRESENTED AT THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS NUCLEAR ENGINEERING DIVISION WINTER ANNUAL MEETING, NOVEMBER 7-11, 1965, CHICAGO, ILLINOIS- SOURCE

THE TRANSPORT OF FISSION PRODUCTS THROUGH A CARRIER COOLANT STREAM AND THEIR DEPOSITION ONTO THE CONDUIT SURFACES HAVE BEEN STUDIED ANALYTICALLY AND EXPERIMENTALLY. THE MODEL DEVELOPED ASSUMES VALIDITY OF THE HEAT-MASS ANALOGY UNDER CONDITIONS OF RADIOACTIVE DECAY AND AN IMPERFECT SINK THAT MAY SATURATE AND POSTULATES A CLASSICAL ADSORPTION-DESORPTION INTERACTION AT THE CONDUIT SURFACE. MASS BALANCES IN THE CARRIER STREAM AND ON THE CONDUIT SURFACE RESULT IN A SET OF TIME DEPENDENT, NONDIMENSIONAL DIFFERENTIAL EQUATIONS. THESE EQUATIONS EXPRESS THE CONCENTRATION IN THE GAS STREAM AND ON THE CONDUIT SURFACE AS FUNCTIONS OF TIME, AXIAL POSITION, AND THE IDENTIFIED FISSION PRODUCT DEPOSITION PARAMETERS. EQUILIBRIUM SOLUTIONS ARE PRESENTED ALONG WITH TRANSIENT SOLUTIONS OF A LIMITING CONDITION OF THE EQUATIONS SHOWN TO BE EQUIVALENT TO A SET IN THE LITERATURE.

*ANALYTICAL MODEL + *DEPOSITION + *FISSION PRODUCT TRANSPORT + *OUT OF PILE LOOPS AND EXPERIMENTS + HELIUM + IODINE + STEEL + SURFACE CONTAMINATION

7-09361 WHITBY KT + LUNDGREN DA + PETERSON CM
HOMOGENEOUS AEROSOL GENERATORS
UNIVERSITY OF MINNESOTA
15 PAGES, INT. J. AIR WATER POLLUTION, 9, PP. 263-277 (1965)

THREE AEROSOL GENERATORS CAPABLE OF GENERATING ESSENTIALLY HOMOGENEOUS, MONODISPERSE, SPHERICAL, AND ELECTRICALLY NEUTRAL SOLID PARTICLES OF FLUORESCENT DYE ARE DESCRIBED. THESE ARE AN ATOMIZER-IMPACTOR COMBINATION AND TWO SPINNING-DISK AEROSOL GENERATORS. THE ATOMIZER-IMPACTOR COMBINATION IS CAPABLE OF GENERATING PARTICLES HAVING GEOMETRIC STANDARD DEVIATIONS BETWEEN 1.3 AND 1.5 WITH AN MMD FROM 0.02 TO 0.5 MICRON. THIS GENERATOR UTILIZES THE ALL-METAL COLLISION ATOMIZER IN SERIES WITH A SPECIAL IMPACTOR DESIGNED SO THAT THE DROPLET CUTOFF CAN BE VARIED. HIGH QUALITY AEROSOLS, HAVING GEOMETRIC STANDARD DEVIATIONS LESS THAN 1.1, WITHIN THE SIZE RANGING FROM 0.5 TO 3 MICRON, ARE GENERATED BY A 1.63-IN.-DIAM STAINLESS STEEL SPINNING DISK SPUN BY AN AIR MOTOR FROM 20,000 TO 70,000 REV/MIN. THE SECOND SPINNING-DISK GENERATOR PRODUCES AEROSOLS FROM 4 TO 30 MICRON BY MEANS OF A SYNCHRONOUS MOTOR AND A GEARED PULLEY DRIVING A 3.23-IN. DISK AT A SPEED OF 7200 REV/MIN. DURING THE DEVELOPMENT OF THESE GENERATORS IT WAS FOUND THAT THE PARTICLES WERE ELECTRICALLY CHARGED TO

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09361 *CONTINUED*

SUBSTANTIAL FRACTION OF THEIR MAXIMUM EQUILIBRIUM CHARGE. ALL THREE GENERATORS INCORPORATE A NOVEL ION GENERATOR AND NEUTRALIZATION SYSTEM WHICH REDUCES THE CHARGE TO A NEGLIGIBLE LEVEL. A SUMMARY OF THE PHYSICS OF AEROSOL CHARGE NEUTRALIZATION IS GIVEN. ESSENTIAL OPERATIONAL VARIABLES, AEROSOL PROPERTIES, AND CERTAIN APPLICATION PROBLEMS ARE ALSO DISCUSSED.

*AEROSOL PRODUCTION + *AEROSOL PROPERTIES + *PARTICLE SIZE + AEROSOL + ELECTROSTATIC CHARGE

7-09362 WHITBY KT

CALCULATION OF THE CLEAN FRACTIONAL EFFICIENCY OF LOW MEDIA DENSITY FILTERS
UNIVERSITY OF MINNESOTA

10 PAGES, 5 TABLES, 7 FIGURES, 19 REFERENCES, ASHRAE JOURNAL, PP. 56-65, (SEPTEMBER, 1965)

ALTHOUGH CALCULATED VALUES OF FILTER EFFICIENCY WILL NEVER REPLACE ACTUAL MEASUREMENTS, THERE ARE TIMES WHEN THE CALCULATED FRACTIONAL EFFICIENCY CURVE OF THE CLEAN FILTER PROVIDES SUFFICIENT INFORMATION FOR FILTER SELECTION OR DESIGN. THIS PAPER DESCRIBES A PROCEDURE FOR OBTAINING THE ESSENTIAL FILTER MAT PARAMETERS USED IN COMPUTING A FRACTIONAL EFFICIENCY CURVE. THE FILTER MAT PARAMETERS, OBTAINED FOR ANY OPERATING REYNOLDS NUMBER, ARE COMPUTED FROM PRESSURE DROP VS VELOCITY DATA. IN ADDITION, THE PAPER CONTAINS THE BEST COMBINATION OF DIFFUSION, INTERCEPTION AND INERTIAL IMPACTION THEORY, THAT WAS SELECTED FROM A COMPARISON OF EXPERIMENTAL FRACTIONAL EFFICIENCY CURVES WITH VARIOUS FILTRATION THEORIES.

*FILTER THEORY, DIFFUSION + *FILTER THEORY, IMPACTION + *FILTER THEORY, INTERCEPTION +
*FILTER, EFFICIENCY OF + AIR CLEANING + DIFFUSION + FILTER + FILTER CHARACTERISTICS + FILTER DESIGN +
FILTER, FIBER + PARTICULATE

7-09363 WHITBY KT + LIU BY + PETERSON CM

CHARGING AND DECAY OF MONODISPERSED AEROSOLS IN THE PRESENCE OF UNIPOLAR ION SOURCES
UNIVERSITY OF MINNESOTA

17 PAGES, JOURNAL OF COLLOID SCIENCE, 20, PP. 585-601, (1965)

THE EFFECTS OF AIRBORNE ELECTRIC CHARGE CARRIED ON EITHER SMALL IONS OR ON AEROSOL PARTICLES HAS BEEN OF INTEREST TO METEOROLOGISTS FOR A LONG TIME. MORE RECENTLY THIS SUBJECT HAS INTERESTED THE MEDICAL PROFESSION BECAUSE OF THE POSSIBLE HEALTH EFFECTS OF AIRBORNE CHARGE. AEROSOL TECHNOLOGISTS ALSO HAVE AN INTEREST IN AEROSOL CHARGE BECAUSE OF ITS EFFECT ON AEROSOL DEPOSITION, ON AIR CLEANER EFFICIENCY, AND ON THE GENERAL BEHAVIOR OF AEROSOLS. NATURAL CONCENTRATIONS OF IONS AND CHARGED AEROSOL PARTICLES ARE ON THE ORDER OF A FEW HUNDRED TO A FEW THOUSAND PER CUBIC CENTIMETER. AT THESE LOW CONCENTRATIONS, THE EFFECTS OF THE ELECTRICAL CHARGE ARE USUALLY NEGLIGIBLE, BUT AT THE HIGHER CONCENTRATIONS ENCOUNTERED WHEN GENERATING ARTIFICIAL AEROSOLS OR DOWNSTREAM OF ELECTRICAL AIR-CLEANING SYSTEMS, THE NET SPACE CHARGE MAY CAUSE HIGH CHARGE-CONCENTRATION GRADIENTS, STRONG ELECTRIC FIELDS, AND SIGNIFICANT PRECIPITATION OF IONS AND AEROSOLS.

*AEROSOL + *ELECTROSTATIC CHARGE + AEROSOL PRODUCTION + AEROSOL PROPERTIES + AIR CLEANING + PARTICLE SIZE

7-09364 WHITBY KT + LUNDGREN DA

MECHANICS OF AIR CLEANING
UNIVERSITY OF MINNESOTA

4 PAGES, ASAE TRANSACTIONS, 8(3), PP. 342-44, 351-352 (1965)

ENOUGH RELIABLE EXPERIMENTAL DATA HAVE NOW BEEN ACCUMULATED TO ALLOW THE SELECTION, FROM THE AVAILABLE THEORIES, OF SOME THAT ARE QUITE USEFUL FOR OBTAINING A CORRECT INSIGHT INTO THE OPERATION OF MOST KINDS OF AIR-CLEANING DEVICES AND FOR THE PRELIMINARY DESIGN AND SELECTION OF A DEVICE TO MEET A GIVEN REQUIREMENT. THIS PAPER REVIEWS THE PRINCIPAL AIR-CLEANING MECHANISMS AND PRESENTS WHAT IS BELIEVED TO BE THE BEST WORKING EQUATIONS FOR CALCULATING THE CONTRIBUTIONS OF THE VARIOUS MECHANISMS. RESULTS OF CALCULATIONS OF THE CONTRIBUTION OF EACH OF THE IMPORTANT MECHANISMS TO THE COLLECTION OF AIR-BORNE DUST ARE PRESENTED FOR FOUR FILTERS OF DIFFERENT PERFORMANCE RANGES.

AIR CLEANING + ELECTROSTATIC CHARGE + FILTER + FILTER THEORY, DIFFUSION + FILTER THEORY, IMPACTION +
FILTER THEORY, INTERCEPTION + FILTER, FIBER + PARTICULATE

7-09367 ENGINEERING ASPECTS

25 PAGES, ENCYCLOPEDIA OF CHEMICAL TECHNOLOGY, 7, PAGES 429-451, (1965)

THIS ARTICLE DEALS WITH THE SOURCES, PHYSICAL PROPERTIES, SAMPLING, AND MEASUREMENT OF SOLID AND LIQUID PARTICLES SUSPENDED IN A GAS.

AEROSOL + AEROSOL PROPERTIES + AIR CLEANING + FILTER + FILTER CHARACTERISTICS + FILTER DESIGN +
FILTER OPERATION + FILTER, EFFICIENCY OF + FILTER, FIBER + MATERIAL + PARTICLE SIZE + PARTICULATE +
SAMPLING

7-09372 CARROLL RM

THE BEHAVIOR OF FISSION-GAS IN FUELS
OAK RIDGE NATIONAL LABORATORY

33 PAGES, 7 FIGURES, 21 REFERENCES, AIME CONFERENCE ON RADIATION EFFECTS, ASHVILLE, NORTH CAROLINA, SEPTEMBER, 1965, SOURCE

IN THIS PAPER, THE BEHAVIOR OF FISSION GAS IN UO₂ IS USED TO ILLUSTRATE THE EFFECTS OF IRRADIATION ON FISSION-PRODUCT MIGRATION IN FUEL MATERIALS. FISSION-GAS IS RELEASED FROM UO₂

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09372 *CONTINUED*

BY A TEMPERATURE-DEPENDENT PROCESS, USUALLY ASSUMED TO BE DIFFUSION. THEREFORE, A GREAT MANY MEASUREMENTS OF DIFFUSION COEFFICIENTS (D) WERE OBTAINED FOR PREDICTING FISSION-GAS RELEASES DURING IRRADIATION. MORE RECENTLY, IT WAS DISCOVERED THAT BURNUP AND FISSION RATE HAVE LARGE EFFECTS ON A MEASURED DIFFUSION COEFFICIENT. THE EARLIER DIFFUSION COEFFICIENT VALUES WERE OBTAINED BY USING A MODEL THAT ASSUMED THAT IRRADIATION WOULD NOT AFFECT THE DIFFUSION COEFFICIENT. THUS, THESE VALUES SHOULD NOT BE USED FOR CALCULATIONS. THESE OBSERVATIONS HAVE RESULTED IN THE FORMATION OF A DEFECT-TRAP MODEL FOR FISSION-GAS RELEASE.

*ANALYTICAL MODEL + *FISSION GAS RELEASE + *RADIATION DAMAGE + DIFFUSION + DIFFUSION COEFFICIENT + FISSION RECOIL + FUEL BURNUP + URANIUM OXIDE

7-09519 BLOOD CM + OVERHOLSER LG
COMPATIBILITY OF PYROLYTIC-CARBON COATED FUEL PARTICLES WITH WATER VAPOR
OAK RIDGE NATIONAL LABORATORY
17 PAGES, 6 FIGURES, 2 TABLES, LIBBY-COCKCROFT GRAPHITE CHEMISTRY MEETING, HARWELL, ENGLAND, APRIL 25-27, 1966, SOURCE

FUEL PARTICLES WITH VARIOUS TYPES OF COATINGS WERE EXAMINED TO ASCERTAIN WHAT (1) EFFECT THE COATING STRUCTURE MIGHT HAVE ON THE REACTIVITY OF THE CARBON COATINGS WITH WATER VAPOR AND (2) THE INCIDENCE OF FAILURE OF THE COATINGS UPON EXPOSURE TO WATER VAPOR. URANIUM AND THORIUM WERE PRESENT AS DICARBIDES. THESE STUDIES WERE MADE AT 1000 C, USING HELIUM-WATER VAPOR MIXTURES HAVING PARTIAL PRESSURES OF WATER VAPOR OF 4.6, 46, AND 567 TORR. REACTION RATES FOR DIFFERENT BATCHES OF PARTICLES INDICATE THAT NO SIMPLE RELATIONSHIP EXISTS BETWEEN REACTIVITY AND PARTIAL PRESSURE OF WATER VAPOR. THE APPARENT ORDER OF THE REACTION BETWEEN STEAM AND THE COATING APPEARS TO HAVE INCREASED WITH INCREASING PARTIAL PRESSURE OF STEAM IN NEARLY ALL CASES.

*COATED PARTICLE + *PYROLYTIC + CARBON + FUEL INTEGRITY + GRAPHITE + STEAM + URANIUM CARBIDE

7-09521 DIFFUSION OF RARE GASES IN SOLIDS. QUARTERLY REPORT NO. 21, JULY-SEPTEMBER 1965
HAHN-MEITNER-INSTITUT FUER KERNFORSCHUNG, BERLIN, WEST GERMANY
EURAC-1489 + EUR-2656 +. 25 PAGES, OCTOBER, 1965, CFSTI, \$1.00 CY, \$0.50 MN

A UNIFORM ACTIVATION ENERGY WAS FOUND BETWEEN 850 AND 1250 C FOR THE SIMULTANEOUS DIFFUSION OF ARGON-37 AND XENON-133 IN CAF₂ SINGLE CRYSTALS DOPED WITH 1 MOLE PERCENT U. D-SUB-AR EQUALS 1.4 TIMES 10 TO THE 10 EXP - 97300/RT. D-SUB-XE EQUALS 7.1 TIMES 10 TO THE 7 EXP - 97300/RT. THE FOLLOWING RESULTS WERE OBTAINED FOR ARGON DIFFUSION IN KI SINGLE CRYSTALS AFTER LOW-LEVEL NEUTRON IRRADIATION - ABOVE 450 C D EQUALS 3 TIMES 10 TO MINUS 3 EXP - 6800/RT, BELOW 450 C D EQUALS 1 TIMES 10 TO MINUS 2 EXP - 22400/RT. ALL THE ACTIVATION ENERGIES MEASURED HITHERTO FOR THE DIFFUSION OF ARGON IN K-HALIDES ARE TABULATED. AN INTERSTITIAL MECHANISM FOR THE DIFFUSION IS SUGGESTED IN THE CASE OF KF AND THE HIGH-TEMPERATURE VALUES FOR KCl TO KI.

*DIFFUSION + *NOBLE GAS + ARGON + DIFFUSION COEFFICIENT + URANIUM CARBIDE + URANIUM OXIDE + XENON

7-09536 ADAMS RE + BROWNING WE
EVALUATION OF OFF-GAS SYSTEM FOR THE CP-ORR CAPSULE EXPERIMENT
OAK RIDGE NATIONAL LABORATORY
ORNL-1M-1328 +. 14 PAGES, NOVEMBER 12, 1965, CFSII, \$1.00 CY, \$0.50 MN

THE PERFORMANCE OF THE OFF-GAS SYSTEM OF THE CP-ORR (COATED PARTICLE-OAK RIDGE RESEARCH REACTOR) CAPSULE EXPERIMENT IS EVALUATED BOTH WITH AND WITHOUT AN ACTIVATED CHARCOAL TRAP BY COMPUTING THE POSSIBLE ATMOSPHERIC RADIATION DOSES THAT WOULD RESULT FROM A FISSION-PRODUCT RELEASE AND COMPARING THESE DOSES WITH PERMISSIBLE ATMOSPHERIC DOSES. CONTINUOUS RELEASE AND INSTANTANEOUS RELEASE OF ACCUMULATED FISSION PRODUCTS FROM THE UC2 FUEL PARTICLES WERE CONSIDERED. BY ADDING THE CHARCOAL TRAP, IT WAS SHOWN THAT A POSSIBLE TOTAL BODY RADIATION DOSE OF 273 MR MAY BE REDUCED TO 3 MR, WHICH IS 30 PERCENT OF THE PERMISSIBLE ORNL ATMOSPHERIC DOSE. IT IS CONCLUDED THAT THE ACTIVATED-CHARCOAL TRAP WILL TRAP FISSION PRODUCTS SATISFACTORILY AND THAT NO UNDUE ATMOSPHERIC RADIATION HAZARD WILL FOLLOW.

*CHARCOAL + AIR CLEANING + AIRBORNE RELEASE + COATED PARTICLE + FILTER + FISSION PRODUCT TRANSPORT + FISSION PRODUCT, IODINE + URANIUM CARBIDE

7-09537 SUNDERMAN DN + MORRISON DL + HOWES JE + JABLONOWSKI EJ
FISSION-PRODUCT REACTIONS WITH AND RELEASE FROM FUEL-ELEMENT CLADDINGS. QUARTERLY PROGRESS REPORT FOR JULY-SEPTEMBER 1965
BATTTELLE MEMORIAL INSTITUTE
BMI-X-10143 + EURAC-1496 +. 8 PAGES, OCTOBER 1, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE OBJECTIVE OF THE RESEARCH IS TO STUDY THE RATE OF MIGRATION OF FISSION PRODUCTS THROUGH CLADDING MATERIALS AND TO PROVIDE DATA ON THE SIZE OF RELEASE, TO DEFINE THE INFLUENCE OF MATERIAL CHARACTERISTICS, TEMPERATURE, AND RADIATION ON FISSION-PRODUCT DIFFUSIVITY AND INTERNAL PRECIPITATION IN CLADDING. STUDY TO INCLUDE NOT ONLY MATERIALS OF ENGINEERING INTEREST BUT TO DETERMINE IF VARIATIONS IN FISSION-PRODUCT DIFFUSIVITY CAN BE CORRELATED WITH BASIC PHYSICAL PROPERTIES WHICH WILL PERMIT EXTRAPOLATION OF THE DATA TO OTHER CLADDING SYSTEMS. BOTH IN-PILE AND OUT-OF-PILE DIFFUSION AND SUPPORTING EXPERIMENTS WILL BE MADE TO INVESTIGATE THE RELEASE AND MIGRATION OF FISSION PRODUCTS THROUGH THE VARIOUS MATERIALS. PROGRESS ON THE PROGRAM DURING THE QUARTERLY PERIOD ENDING SEPTEMBER 30, 1965, IS DISCUSSED.

*CLAD + *DIFFUSION + *STEEL, STAINLESS + *ZIRCONIUM + ACTIVATION + ALLOY + DIFFUSION COEFFICIENT + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT + FUEL ELEMENT + IN PILE EXPERIMENT + IN PILE LOOP + OUT OF PILE LOOPS AND EXPERIMENTS

ACCESSION NUMBER 7-C9372 TO 7-09537

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09545 GINNA RE
APPLICATION FOR LICENSES
ROCHESTER GAS AND ELECTRIC CORPORATION
22 PAGES, OCTOBER 28, 1965, DCKET 50-244, PDR

APPLICANT DISCUSSES FINANCIAL AND TECHNICAL QUALIFICATIONS, GIVES DESCRIPTION OF FACILITY, AND DISCUSSES NUCLEAR SAFETY (PROTECTION AGAINST CONSEQUENCES OF ACCIDENTS, CONTROL OF CORE REACTIVITY DURING OPERATION, EFFLUENTS, WASTE DISPOSAL, OPERATING PROCEDURES).

*LICENSING STATUS OF NUCLEAR PROJECTS + ACCIDENT, CONSEQUENCES + ADMINISTRATIVE CONTROLS AND PRACTICES + EFFLUENT + WASTE DISPOSAL, GENERAL

7-09582 VENERUS ER + OZISIK MN
THEORETICAL INVESTIGATIONS OF FISSION PRODUCT DEPOSITION FROM FLOWING GAS STREAMS
NORTH CAROLINA STATE UNIVERSITY, RALEIGH
CONF-651101-44 +. 26 PAGES, 1965, 13TH CONFERENCE ON REMOTE SYSTEMS TECHNOLOGY, WASHINGTON, D.C., CFSTI, \$2.00 CY, \$0.50 MN

THIS PAPER CONSIDERS SUITABLE MODELS THAT WOULD GOVERN THE DISTRIBUTION OF FISSION PRODUCTS IN A COOLANT STREAM AND THE DEPOSITION OF FISSION PRODUCTS ON THE SURFACES OF A CONDUIT. THE SOLUTION OF THE BOUNDARY-VALUE PROBLEM BASED ON THE RESISTANCE MODEL INDICATES THAT THE BULK NUSSELT NUMBER IS A FUNCTION OF THE WALL NUSSELT NUMBER. THIS IMPLIES THAT THE HEAT-MASS ANALOGY WOULD BE IN ERROR, SINCE THE RESULTS OF THIS ANALOGY ARE EITHER BASED ON A CONSTANT WALL TEMPERATURE (NU-SUB-W EQUALS INFINITY) OR A CONSTANT WALL HEAT FLUX EQUALS ZERO. FOR ZERO LESS THAN NU-SUB-W LESS THAN INFINITY, THE HEATMASS ANALOGY SHOULD NOT BE USED. THE ADSORPTION ENERGIES OF FISSION PRODUCTS ON VARIOUS SURFACE MATERIALS ARE NOT WELL KNOWN. THE TRANSPORT MODEL PROVIDES A USEFUL MEANS OF OBTAINING THE ADSORPTION ENERGIES OF VARIOUS ISOTOPE-SURFACE-MATERIAL COMBINATIONS.

*ANALYTICAL MODEL + *DEPOSITION + *FISSION PRODUCT TRANSPORT + REACTOR, GAS COOLED

7-09595 FLETCHER RD
POST-TEST PHYSICAL, CHEMICAL AND METALLURGICAL ANALYSIS OF SNAPTRAN-3 FUEL
PHILLIPS PETROLEUM COMPANY, ICAHO
1D0-17065 +. 72 PAGES, JUNE 1965, CFSTI, \$3.00

THE FUEL-ELEMENT DAMAGE THAT OCCURRED DURING THE SNAPTRAN-3 DESTRUCTIVE TEST OF A SNAP 10A/2 REACTOR IS DESCRIBED. CHEMICAL ANALYSIS OF THE FUEL INDICATED THAT ABOUT 15 PERCENT OF THE HYDROGEN WAS RELEASED AND THAT THE CORE FLUX WAS HIGHER TOWARD THE CENTER, BOTH RADially AND AXIALLY. METALLURGICAL ANALYSIS DETERMINED THE PRESENCE OF THE EPSILON, DELTA, AND GAMMA PHASES IN THE GRAIN STRUCTURE, AND EVIDENCE OF A POSSIBLE ALPHA OR BETA PHASE. THE PHASE CHANGES INDICATED A MINIMUM PEAK FUEL TEMPERATURE OF 1290 F, WHILE CRACKING AT THE GRAIN BOUNDARIES INDICATED A PEAK FUEL TEMPERATURE IN EXCESS OF 1740 F. THE FAILED EDGES OF THE FUEL CLADDING SUGGESTED A PEAK CLAD TEMPERATURE IN EXCESS OF 1000 F.

*FUEL MELTDOWN + *SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + CHEMICAL ANALYSIS + FAILURE, FUEL ELEMENT + FUEL INTEGRITY + HYDROGEN

7-09596 DEMMITT TF
AUTOMATED PROCEDURE FOR ZIRCONIUM ANALYSIS IN WATER
BATTELLE NORTHWEST, RICHLAND, WASH.
BNWL-SA-166 +. 11 PAGES, REFERENCES, AUGUST 2, 1965, CFSTI, \$1.00 CY, \$0.50 MF

A SIMPLE AND EFFECTIVE METHOD FOR AUTOMATING DIFFERENTIAL FLUORESCENCE ANALYSES WAS DEVELOPED. IT WAS USED TO ADAPT AN EXISTING MANUAL PROCEDURE FOR ZIRCONIUM ANALYSIS IN WATER FOR CONTINUOUS OPERATION. ALTHOUGH THE PROCEDURE HAS NOT BEEN OPTIMIZED AND THE ULTIMATE SENSITIVITY AND REPRODUCIBILITY HAVE NOT BEEN DETERMINED YET, IT IS APPARENT THAT IT CAN BE USED TO MONITOR ZIRCONIUM CONCENTRATIONS IN THE PPB RANGE. THE PROCEDURE MAY EVENTUALLY BE SUITABLE FOR DETECTING ACCELERATED CORROSION OF ZIRCONIUM AND ZIRCONIUM ALLOYS IN WATER.

*CHEMICAL ANALYSIS + *CORROSION + *ZIRCONIUM + WATER, GENERAL

7-09597 SUNDERMAN DN + MORRISON DL + HOWES JE + JACLONOWSKI EJ
FISSION-PRODUCT REACTIONS WITH AND RELEASE FROM FUEL-ELEMENT CLADDINGS. QUARTERLY PROGRESS REPORT FOR APRIL-JUNE 1965
BATTELLE MEMORIAL INSTITUTE
BMI-X-10132 + EURAEC-1427 +. 14 PAGES, JULY 1, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE DIFFUSION OF FISSION PRODUCTS IN ALPHA-ZIRCONIUM WAS STUDIED IN POSTIRRADIATION EXPERIMENTS AT TEMPERATURES BETWEEN 600 AND 800 C. THE ACTIVATION ENERGIES AND FREQUENCY FACTORS (D SUB ZERO) FOR DIFFUSION OF ZR-95 AND TE-132 WERE DETERMINED.

CERIUM + CORROSION + DIFFUSION + FISSION PRODUCT TRANSPORT + RADIATION DAMAGE + RUTHENIUM + TELLURIUM + ZIRCONIUM

7-09598 DEVELOPMENT PROGRAM ON THE APPLICATION OF STEAM-WATER SPRAY TO REACTOR COOLING. CAN 3, FINAL REPORT COVERING THE PERIOD DECEMBER 15, 1961 - AUGUST 31, 1964
CENTRO INFORMAZIONI STUDI ESPERIENZ, SEGRATE, MILANO
CISE-R-136 + EURAEC-1382 + EUR-2345 +. 52 PAGES, TABLES, OCTOBER, 1964, CFSTI, \$3.00 CY, \$0.50 MN

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09598 *CONTINUED*

THE CAN-3 RESEARCH PROGRAM CONCERNED DEVELOPMENT WORK LINKED WITH FEATURES OF A POSSIBLE REACTOR DESIGN AND WITH REACTOR CONDITIONS MORE CLOSELY THAN HAD BEEN PREVIOUS CAN-1 AND CAN-2 PROGRAMS. EXPERIMENTAL WORK WAS MAINLY DEVOTED TO THE FIELD OF HEAT TRANSFER, HYDRODYNAMICS, AND IN-PILE EXPERIMENTS FOR CORROSION OF STRUCTURAL MATERIALS AND FOR WATER CHEMISTRY. THE PRESENT FINAL REPORT COLLECTS FUNDAMENTAL ASPECTS AND RESULTS.

*CORE SPRAY + *CORROSION + *IN PILE EXPERIMENT + *IN PILE LOOP + COOLANT CHEMISTRY + SPRAY, GENERAL

7-09677 DELORENZO JT
HFIR CLADDING-FAILURE DETECTOR
OAK RIDGE NATIONAL LABORATORY

ORNL-TM-1388 +. 9 PAGES, 3 FIGURES, DECEMBER 8, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE HFIR CLADDING-FAILURE DETECTOR MONITORS A SAMPLE STREAM OF PRIMARY COOLANT WATER FROM THE EXIT OF THE REACTOR TO DETECT THE RELEASE OF FISSION-PRODUCT ACTIVITY FROM SMALL DEFECTS, SUCH AS BLISTERS, IN THE FULL CLADDING. THE OPERATION OF THE SYSTEM IS BRIEFLY DESCRIBED, AND A PROCEDURE FOR DETERMINING THE SETTINGS FOR THE PULSE AMPLIFIER, PULSE-HEIGHT DISCRIMINATOR, AND HIGH-VOLTAGE SUPPLY IS GIVEN.

*FAILURE, CLADDING + *FAILURE, FUEL ELEMENT + *FISSION PRODUCT, IODINE +
*INSTRUMENTATION, RADIATION MONITORING + *INSTRUMENTATION, SURVEILLANCE + *MONITOR, RADIATION, LIQUID +
INSTRUMENTATION, NUCLEAR + MONITOR, RADIATION, EMERGENCY

7-09711 DICKERMAN CE + ROBINSON LE + AUGUST C + STEWART K + STEPHANY W + WILLIS L + CARLANDER R +
MUELLER M
PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 9 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-15 THROUGH III-19, PP.
157-165, CFSTI, \$7.22 CY, \$2.00 MN.

IN TREAT TRANSPARENT MELTDOWN CAPSULES, THE FOLLOWING SAMPLES WERE SUBJECTED TO TRANSIENTS FOR THE PURPOSES INDICATED - U-5 W/O FISSION ALLOY SAMPLES PREIRRADIATED TO 1.3 AT. PERCENT BURNUP, MEASUREMENT OF EXPANSION. EBR-II FUEL PIN PREIRRADIATED TO 0.6 AT. PERCENT, STUDY OF FAILURE MECHANISM. TH-U METALLIC FUEL ELEMENTS OF THE EBR-II MARK I TYPE, STUDY OF FAILURE MECHANISM (SEE ALSO TRANS. AMERICAN NUCLEAR SOCIETY, 8(1), P. 309 (1965). EBR-II TYPE US FUELED, W-RE ALLOY CLAD ELEMENTS, STUDY OF FAILURE, IF ANY (SEE ALSO NUCLEAR APP. 1, P. 168 (1965)). IN THE INTEGRAL SODIUM LOOP EBR-II PINS WERE SUBJECTED TO 3 TRANSIENTS WITH SODIUM FLOW AND THREE TRANSIENTS WITHOUT FLOW. FUEL-CLADDING EUTECTIC WAS FORMED BY MOLTEN FUEL PENETRATING FROM THE CENTER OF THE ROD TO THE SURFACE.

*TREAT (TRANSIENT TEST REACTOR FACILITY) + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) +
FAILURE, CLADDING + FAILURE, FUEL ELEMENT + FUEL MELTDOWN + HIGH TEMPERATURE + IN PILE LOOP +
IRRADIATION TESTING + PRESSURE, INTERNAL + REACTOR, BREEDER + REACTOR, FAST +
REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + REACTOR, TEST + THORIUM + URANIUM +
URANIUM SULFIDE

7-09752 ETTINGER IJ + MOSS WD + BUSEY HM
AEROSOL CHARACTERISTICS OF BURNING SODIUM AND PLUTONIUM
LOS ALAMOS SCIENTIFIC LABORATORY
1 PAGE, AMERICAN NUCLEAR SOCIETY TRANSACTIONS, 8(1), PP. 143 (1965)

AEROSOL-COUNT MEDIAN DIAMETERS AND AEROSOL-MASS MEDIAN DIAMETERS WERE DETERMINED FOR BURNING SODIUM, PLUTONIUM AND PU-CO-CE ALLOY, UNDER CONDITIONS OF CONTROLLED TEMPERATURE, RELATIVE HUMIDITY, AND OXYGEN CONCENTRATION IN THE VICINITY OF THE BURNING MATERIAL. THE AEROSOL CHARACTERISTICS INDICATE THAT CAREFUL CONSIDERATION MUST BE GIVEN TO THE DESIGN OF FILTRATION SYSTEMS TO BE USED WITH THESE MATERIALS BECAUSE OF THE SMALL PLUTONIUM PARTICLES PRODUCED. SODIUM PARTICLES ARE MORE THAN TEN TIMES LARGER AND WILL CONSTITUTE A SIGNIFICANT PROBLEM OF FILTER CLOGGING.

*AEROSOL PROPERTIES + *OXIDATION + *PARTICLE SIZE + *PLUTONIUM + *SODIUM + AEROSOL + AEROSOL PRODUCTION

7-09753 OI N + TAKAGI J
DISTRIBUTION OF FISSION PRODUCTS IN IRRADIATED UO2
TOKYO SHIBAURA ELECTRIC CO., LTD. + NAIG NUCLEAR RESEARCH LABORATORY
5 PAGES, JOURNAL OF NUCLEAR SCIENCE AND TECHNOLOGY, 2(4), PP. 127-131 (APRIL 1965)

INHOMOGENEITIES OF FISSION PRODUCTS AND PLUTONIUM DISTRIBUTION IN IRRADIATED UO2 WERE EXAMINED. UO2 PELLETS WERE GROUND SO AS TO LET THEM FRACTURE ALONG THE GRAIN BOUNDARIES, AND THE FRAGMENTS WERE THEN DISSOLVED SUCCESSIVELY INTO SEVERAL FRACTIONS. THE SPECIFIC ACTIVITIES OF THESE FRACTIONS WERE COMPARED, AND THE DISTRIBUTION OF FISSION PRODUCTS IN THE GRAIN AND GRAIN BOUNDARIES WERE STUDIED. IT WAS FOUND THAT AT LOWER TEMPERATURES OF IRRADIATION (ABOUT 1400 C), THE FISSION PRODUCTS, EXCEPT CS, WERE DISTRIBUTED FAIRLY UNIFORMLY OVER THE GRAIN, WHILE CS HAD ACCUMULATED AT THE GRAIN BOUNDARIES. AT HIGHER TEMPERATURES (NEAR OR ABOVE THE MELTING POINT OF UO2), INHOMOGENEITY WAS NOTICED IN THE AR-NB AND CS DISTRIBUTION. THE CONCENTRATION OF THESE ELEMENTS VARIED ALONG THE TEMPERATURE GRADIENT OF THE FUEL ROD THAN WITHIN THE GRAINS. ZR-NB WAS CONCENTRATED IN THE HIGHER TEMPERATURE AREAS OF THE FUEL ROD, WHILE CONVERSELY, THE CONCENTRATION OF CS WAS SMALLER IN THE SAME AREAS. DISTRIBUTION OF CE, RU, AND PU WAS FAIRLY UNIFORM THROUGHOUT THE GRAINS. THE PROCESS OF FISSION PRODUCT MIGRATION IN UO2 IS ALSO DISCUSSED IN THE PAPER.

*FISSION PRODUCT TRANSPORT + *PLUTONIUM + *URANIUM + CERIUM + CESIUM + DIFFUSION + OXIDE + RUTHENIUM +

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09753 *CONTINUED*
ZIRCONIUM

7-09757 BLICK EF
CAPILLARY-ORIFICE MODEL FOR HIGH-SPEED FLOW THROUGH POROUS MEDIA
UNIVERSITY OF OKLAHOMA, NORMAN, OKLAHOMA
5 PAGES, 2 TABLES, 2 FIGURES, 19 REFERENCES, I AND EC PROCESS DESIGN AND DEVELOPMENT, 5(1), PP. 90-94
(JANUARY 1966)

THE CAPILLARY-ORIFICE MODEL IS PROPOSED TO PREDICT THE FLOW BEHAVIOR IN POROUS MEDIA. THIS MODEL ASSUMES POROUS MEDIA TO BE MADE UP OF BUNDLES OF CAPILLARY TUBES WITH ORIFICE PLATES SPACED THROUGHOUT THE TUBES AT A DISTANCE EQUAL TO THE TUBE DIAMETER. THE PRESSURE DROP FOR FLUID FLOWING THROUGH A POROUS MEDIUM IS OBTAINED BY APPLYING THE LAWS OF CONSERVATION OF MASS AND MOMENTUM. THIS PROCEDURE PRODUCES THEORETICAL EXPRESSIONS FOR THE VISCOUS RESISTANCE COEFFICIENT (RECIPROCAL OF THE PERMEABILITY) AND THE INERTIAL RESISTANCE COEFFICIENT. THIS IS BELIEVED TO BE THE FIRST THEORETICALLY DERIVED EQUATION FOR THE INERTIAL RESISTANCE COEFFICIENT. THE THEORETICAL VALUES OF PRESSURE DROP, INERTIAL RESISTANCE COEFFICIENTS, AND VISCOUS RESISTANCE COEFFICIENTS COMPARE FAVORABLY WITH EXPERIMENTAL VALUES.

*ANALYTICAL MODEL + *DIFFUSION CHANNEL + *POROUS MEDIA + DIFFUSION + POROUS DIFFUSION

7-09758 BARTON CJ + COTTRELL WB
FISSION-PRODUCT RELEASE AND TRANSPORT UNDER ACCIDENT CONDITIONS
OAK RIDGE NATIONAL LABORATORY
2 PAGES, NUCLEAR SAFETY, 7(2), PP. 203-204 (WINTER 1965-1966)

USAEC REPORT CONF-650407, VOLS. I AND II, INTERNATIONAL SYMPOSIUM ON FISSION-PRODUCT RELEASE AND TRANSPORT UNDER ACCIDENT CONDITIONS, APRIL 5-7, 1965, OAK RIDGE, TENNESSEE. THE PURPOSE AND PRINCIPAL OBJECTIVES OF RESEARCH ON THE RELEASE AND TRANSPORT OF FISSION PRODUCTS ARE (A) TO STUDY THE CHEMICAL, PHYSICAL, AND TIME BEHAVIOR OF FISSION PRODUCTS RELEASED INTO A CONTAINED VOLUME. (B) TO STUDY THE NATURAL PROCESSES WHICH GOVERN THE REDUCTION OF THE AIRBORNE FRACTIONS BY AEROSOL COALESCENCE, GAS CONDENSATION, IODINE ABSORPTION BY SURFACES AND STEAM CONDENSATES. (C) TO DETERMINE AND DEVELOP SUITABLE AND ADEQUATE MEANS OF COLLECTING AND TRAPPING THE RELEASED FISSION PRODUCTS SO THAT THEY ARE UNAVAILABLE FOR LEAKAGE TO THE ENVIRONMENT BEYOND THE CONTAINMENT BARRIER. ALL SUCH STUDIES SHOULD BE DIRECTED TOWARD AIDING THE CALCULATION OF FISSION-PRODUCT BEHAVIOR FOR DIFFERENT REACTOR SYSTEMS UNDER CONDITIONS WHERE COUNTERMEASURES ARE ASSUMED TO WORK OR TO FAIL. THE MAIN ISOTOPES OF INTEREST FOR THE RELEASE AND TRANSPORT STUDIES ARE THOSE OF IODINE DUE TO THEIR YIELD AND TOXICOLOGICAL IMPORTANCE.

*AEROSOL + *FISSION PRODUCT RELEASE, GENERAL + *FISSION PRODUCT TRANSPORT + *FISSION PRODUCT, IODINE + *LOFT (LOSS OF FLUID TEST) + ACCIDENT ANALYSIS + ACCIDENT MODEL + ACCIDENT, GENERAL + AEROSOL PRODUCTION + AEROSOL PROPERTIES + AEROSPACE SAFETY + AIR CLEANING + AIRBORNE RELEASE + ANALYTICAL MODEL + ANALYTICAL TECHNIQUE, GENERAL + CHARCOAL + CONTAINMENT, GENERAL + DECONTAMINATION + FAILURE, GENERAL + FILTER + FILTER, COMBINATION + FISSION PRODUCT, NONVOLATILE + FISSION PRODUCT, VOLATILE + MONITOR, RADIATION, GENERAL + REACTOR, PRESSURIZED WATER

7-09764 FIOCCHI R
EFFECT OF THE SURFACE DIFFUSION ON THE SEPARATION EFFICIENCY IN BRETON-MASSIGNONS THEORY
CNEN - ISTITUTO DI FISICA DELL'UNIVERSITA, MILANO
8 PAGES, 4 FIGURES, 9 REFERENCES, ENERGIA NUCLEARE, 13(1), PP. 24-31 (JANUARY 1966)

CURRENT THEORIES OF ISOTOPE SEPARATION BY GASEOUS DIFFUSION THROUGH POROUS BARRIERS ARE ALMOST ALL BASED ON THE MODEL OF STRONGLY ELONGATED CYLINDRICAL CAPILLARY PORES. RECENTLY BRETON AND MASSIGNON HAVE ESTABLISHED A CONSISTENT SEPARATION THEORY BASED ON THE MODEL OF DISORDERED AND ISOTROPIC PACK OF IDENTICAL SPHERES, WHICH DESCRIBES MORE EXACTLY MOST OF THE POROUS BARRIERS. SINCE THE SURFACE MIGRATION OF ADSORBED MOLECULES MAY PLAY AN IMPORTANT ROLE IN THE SEPARATION PROCESS, IN THIS PAPER THE EFFECT OF THE SURFACE DIFFUSION ON THE SEPARATION EFFICIENCY DERIVED FROM BRETON-MASSIGNONS THEORY IS INVESTIGATED. THIS ANALYSIS IS ESSENTIALLY DEVOTED TO THE URANIUM ISOTOPE SEPARATION. THE RESULTS ARE COMPARED WITH THOSE OBTAINED FROM PREVIOUS THEORIES.

*ANALYTICAL MODEL + *DIFFUSION + *DIFFUSION CHANNEL + *POROUS DIFFUSION + *POROUS MEDIA + *URANIUM HEXAFLUORIDE

7-09765 KEILLY JJ + WACHTEL SJ + JOHNSON R + WIRSING E + HATCH LP
FLUIDIZED BED REPROCESSING OF GRAPHITE MATRIX NUCLEAR FUEL
BROOKHAVEN NATIONAL LABORATORY
9 PAGES, 11 FIGURES, 3 TABLES, 19 REFERENCES, I AND EC PROCESS DESIGN AND DEVELOPMENT, 5(1), PP. 51-59
(JANUARY 1966)

AN OXIDATION-FLUORINATION PROCESS FOR RECOVERING URANIUM FROM GRAPHITE-BASE NUCLEAR REACTOR FUELS HAS BEEN STUDIED ON A PILOT-PLANT SCALE. THE GRAPHITE FUEL WAS BURNED WITH OXYGEN, AND, THE RESIDUE, CONTAINING U₃O₈, WAS MADE TO REACT WITH FLUORINE TO FORM VOLATILE UF₆. THESE EXOTHERMIC REACTIONS WERE CARRIED OUT WITHIN A FLUIDIZED BED OF REFRACTORY ALUMINA PARTICLES, WHICH SERVED AS AN INERT HEAT-TRANSFER MEDIUM FOR CONTROL OF TEMPERATURE. IN THE OXIDATION STEP, THE OXYGEN WAS FED CONTINUOUSLY TO THE REACTOR, WHILE THE GRAPHITE FUEL WAS ADDED INTERMITTENTLY AT INTERVALS OF ABOUT 1 HR. UNDER THESE CONDITIONS AND AT 700 TO 750 C, AN OXIDATION RATE EQUIVALENT TO 13.6 KG OF CARBON PER HOUR PER SQUARE FOOT OF REACTOR CROSS SECTION COULD BE READILY MAINTAINED. IN THE FLUORINATION STEP, THE BED MATERIAL CONTAINING THE NONVOLATILE OXIDATION PRODUCTS WAS INTRODUCED AS A SINGLE CHARGE INTO A SEPARATE REACTOR

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09765 *CONTINUED*
AND BROUGHT IN CONTACT WITH FLUORINE AT 450 TO 550 C. OVERALL URANIUM RECOVERIES OF MORE THAN 99 PERCENT WERE OBTAINED.

*FLUORINE + *OXIDATION + *RADIOCHEMICAL PROCESSING + CHEMICAL KINETICS + GRAPHITE + OXIDE + PLUTONIUM + ROVER PROGRAM + THORIUM + URANIUM

7-09766 CARMICHAEL BM
EFFECT OF FISSION GAS BUBBLES ON THE RESPONSE OF MOLTEN FUEL REACTORS TO FAST TRANSIENTS
LOS ALAMOS SCIENTIFIC LABORATORY, NEW MEXICO
LA-DC-7476 + CONF-651009-7 +. 12 PAGES, 1965, CONFERENCE ON SAFETY, FUELS AND CORE DESIGN IN LARGE FAST POWER REACTORS, ARGONNE, ILLINOIS, CFSTI, \$1.00 CY, \$0.50 MN

INTEREST IN MOLTEN FUELS HAS, IN PART, BEEN STIMULATED BY THE SAFETY ADVANTAGES OFFERED BY THESE FUELS IN FAST REACTOR APPLICATIONS. THESE ADVANTAGES DERIVE FROM THE LARGE THERMAL EXPANSION COEFFICIENTS AVAILABLE IN LIQUID METALS. THE AIM IN THE ANALYSIS OF THE CLEAN FUEL TRANSIENTS WAS TO INVESTIGATE WHAT RANGE OF REACTIVITY INSERTION RATES MIGHT LEAD TO FUEL CAPSULE DAMAGE. HOWEVER, THE THRESHOLD FOR CAPSULE DAMAGE DUE TO THE PRESSURE RISE MIGHT BE EXPECTED TO LIE IN THE VICINITY OF THE PRESSURE OF 7500 PSI ASSOCIATED WITH THE \$100/SEC RAMP.

*IN PILE LOOP + *MOLTEN FUEL + *PLUTONIUM + IN PILE EXPERIMENT + METAL, LIQUID + REACTOR CONTROL + REACTOR KINETICS + REACTOR STABILITY + REACTOR TRANSIENT

7-09781 RINALDINI C + COEN V + FOGGI C + GALLI DE PARATESI S + LANZA F + RICCHENA R + RIEBOLD W + VOLTA G
TFST - AN ADVANCED POWER EXCURSION REACTOR FOR RESEARCH IN REACTOR SAFETY PRELIMINARY STUDIOS
EUROPEAN ATOMIC ENERGY COMMUNITY, BELGIUM
EUR-2433.E +. 196 PAGES 1965, DEP/MN

TESI (POWER EXCURSION REACTOR FOR SAFETY TESTS) IS A TREAT-TYPE REACTOR IMPROVED IN TWO WAYS, EITHER BY INCREASING THE MAXIMUM FINAL OPERATING TEMPERATURE OR BY REDUCING, BY A FACTOR OF TWO, THE FISSILE CONCENTRATION IN THE REACTOR CORE. TWO VERSIONS OF TESI HAVE BEEN STUDIED - THE MEAN-TEMPERATURE (MT) VERSION, IN WHICH A ZIRCONIUM ALLOY CLADDING ENSURES FISSION PRODUCT RETENTION, AND THE HIGH-TEMPERATURE (HT) VERSION, IN WHICH NO METALLIC CANNING IS PRESENT. THE CHARACTERISTICS OF TREAT AND THE TWO VERSIONS OF TESI ARE SHOWN IN TABLE FORM.

*REACTOR, FAST BURST + *REACTOR, PULSED + DESTRUCTIVE TRANSIENT + GRAPHITE + ITALY + REACTOR, TEST

7-09782 JOHNSTON K
A CALORIMETRIC DETERMINATION OF FISSION PRODUCT HEATING IN FAST REACTOR PLUTONIUM FUEL
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, ATOMIC WEAPONS RESEARCH ESTABLISHMENT, ALDERMASTON
13 PAGES, JOURNAL OF NUCLEAR ENERGY PARTS A/B, 19(7), PP. 527-539 (JULY 1965)

FISSION-PRODUCT HEATING IN PLUTONIUM IRRADIATED IN THE DOUNREAY FAST REACTOR WAS MEASURED BY USING A CALVET MICROCALORIMETER. BY USE OF SMALL, LIGHTLY CANNED SAMPLES AND A GAMMA ABSORBER, THE BETA- AND GAMMA-POWER CONTRIBUTIONS WERE MEASURED SEPARATELY OVER A RANGE OF DECAY TIMES BETWEEN 40 AND 150 DAYS AFTER SHUTDOWN.

*PLUTONIUM + *THERMAL PROPERTY + DOUNREAY (UK) + REACTOR, BREEDER + REACTOR, FAST

7-09832 KRESS TS
PARAMETERS OF ISOTHERMAL FISSION-PRODUCT DEPOSITION
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1330, REVISED +. 93 PAGES, 5 TABLES, 22 FIGURES, APRIL 1966, CFSTI, \$3.00 FS, \$0.75 MN

AN ANALYTICAL MODEL WAS DEVELOPED AND GIVEN EXPERIMENTAL VERIFICATION, USING STABLE IODINE TAGGED WITH I-131 DISSOCIATED FROM A PALLADIUM DIOXIDE SOURCE. THE DEPOSITION SURFACES WERE STAINLESS STEEL AND MILD STEEL HELD VERY CLOSE TO 500 F IN A TURBULENTLY FLOWING STREAM OF HELIUM. THE DISTRIBUTION OF THE DEPOSITED IODINE WAS DETERMINED BY COUNTING THE SURFACE ACTIVITY WITH AN NAI CRYSTAL CONNECTED TO A SINGLE-CHANNEL SCINTILLATION COUNTER. THE MEASUREMENTS WERE CALIBRATED BY RADIO-CHEMICAL ANALYSES OF THE SURFACES AND FURTHER VERIFIED BY NEUTRON ACTIVATION OF SOLUTIONS LEACHED FROM THE SURFACES.

*ANALYTICAL MODEL + *FISSION PRODUCT TRANSPORT + *IODINE + COMPUTER PROGRAM + DEPOSITION + DESORPTION + STEEL, STAINLESS + SURFACE CONTAMINATION + TRACER, RADIOACTIVE

7-09919 BROTHERS AJ + NEWHOUSE DL + WUNDT BM
RESULTS OF BURSTING TESTS OF ALLOY STEEL DISKS AND THEIR APPLICATION TO DESIGN AGAINST BRITTLE FRACTURE
GENERAL ELECTRIC COMPANY, SCHENECTADY, NEW YORK
18 PAGES, 11 FIGURES, 3 TABLES, 13 REFERENCES, ASTM 68TH ANNUAL MEETING, LAFAYETTE, INDIANA, JUNE 13-18, 1965, SOURCE

REPORT PRESENTS THE RESULTS OF BURST TESTS OF NOTCHED AND NITRIDED ALLOY STEEL DISKS AND PROPOSES A DESIGN PROCEDURE AGAINST BRITTLE FRACTURE, USING THE RESULTS OF THESE TESTS.

*ALLOY + *BRITTLE FRACTURE + *NITRIDE + *STEEL + *TESTING + PROCEDURES AND MANUALS + TEST, DESTRUCTIVE

7-09952 RARFNAU A

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-09952 *CONTINUED*
CHEMICAL TRANSPORT REACTIONS
AACHEN LABORATORY OF PHILIPS ZENTRALLABORATORIUM GMBH.
3 PAGES, 4 FIGURES, PHILLIPS TECHNICAL REVIEW, 26(4-6), PAGES 117-119 (1965)

THIS PAPER IS A DISCUSSION OF THE CHEMICAL-TRANSPORT REACTIONS BY WHICH A CONDENSED PHASE MAY BE TRANSFERRED THROUGH A GAS PHASE BY MEANS OF A CHEMICAL REACTION IN WHICH GASES OR VAPORS ARE INVOLVED.

*CHEMICAL REACTION + *MASS TRANSFER + CHEMICAL EQUILIBRIUM + CHEMICAL KINETICS + METAL

7-09965 CASTAGNA M + CULOMBO RL + FERRO A + ROSSI FS + SZABO G
ON THE EFFECT OF NITROGEN INTERSTITIALS ON THE RADIATION EMBRITTLEMENT OF PURE IRON. TECHNICAL REPORT NO. 3
SORIN - CENTRO RICERCHE NUCLEARI, SALUGGIA (VERCELLI) + FIAT - SEZIONE ENERGIA NUCLEARE, TORINO + ISTITUTO ELETTROTECNICO NAZIONALE GALILEO FERRARIS, TORINO
EURAE-1347 + EUR-2322 +. 37 PAGES, 1965, CFSTI, \$2.00 CY, \$1.00 MN

IN VIEW OF THE PRESENT INTEREST ON THE RADIATION EMBRITTLEMENT OF STEELS, SOME PRELIMINARY EXPERIMENTS WERE PERFORMED TO IMPROVE THE KNOWLEDGE OF THE INFLUENCE OF NITROGEN PRESENT IN COMBINED OR FREE CONDITION IN THE FERRITIC STEELS USED FOR NUCLEAR PRESSURE VESSELS. EXPERIMENTS WERE PERFORMED ON TWO IRON MATERIALS. ONE WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED NITRIDED IRON IN A NITROGEN ATMOSPHERE AND SILICON AS A DEOXIDIZER, SO THAT THE FINAL NITROGEN CONTENT WAS ABOUT 0.02 PERCENT. THE OTHER, USED FOR REFERENCE, WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED 0.25 PERCENT TITANIUM, WITH THE PURPOSE, BESIDES DEOXIDATION, OF REMOVING ALL THE NITROGEN AND CARBON INTERSTITIALS, WHICH PRECIPITATE AS TITANIUM NITRIDES AND CARBIDES. THIS MATERIAL SHOWS NO AGEING AT ALL AND HAS NO SHARP YIELD POINT. THE TRANSITION TEMPERATURE FOR NITROGEN-CONTAINING IRON WAS ABOUT 0 DEGREE C PRIOR TO IRRADIATION AND ABOUT 160 DEGREES C AFTER IRRADIATION, WHILE IN INTERSTITIAL-FREE IRON IT SHIFTED FROM MINUS 60 DEGREES TO 0 DEGREE C.

*EMBRITTLEMENT + *IMPACT PROPERTY + *IRON + *NITROGEN + *RADIATION DAMAGE + BRITTLE FRACTURE + NITRIDE + TESTING

7-09966 RUBEL H + DEBRAY W + ROSLER U
HYDROGEN PICK-UP AND EMBRITTLEMENT OF ZIRCALOY-2 ZRNB 1 AND ZRNB 2.5
SIEMENS-SCHUCKERTWERKE AG, ERLANGEN, GERMANY
EURAE-901 + EUR-1501.0 +. 33 PAGES, 1965, REPRINT FROM NUKLEONIK 6(4), (1964), CFSTI, \$3.60 FS, \$1.19 MF

NEXT TO THE BEHAVIOR TOWARD OXIDATION, IT IS MAINLY THE EMBRITTLEMENT SUBSEQUENT TO HYDROGEN PICKUP THAT SETS A LIMIT TO THE SUITABILITY AND LIFETIME OF ZIRCONIUM ALLOYS IN WATER-COOLED OR STEAM-COOLED NUCLEAR REACTORS. WITH THE ZIRCALOY-2 AND ZIRCALOY-4 AMERICAN STANDARD ZIRCONIUM ALLOYS FOR WATER-COOLED REACTORS, THE MAXIMUM OPERATING TEMPERATURE IS TO BE TAKEN AS ABOUT 350 C. THE OBJECT OF THE PRESENT INVESTIGATION IS TO CONTRIBUTE TO KNOWLEDGE ABOUT THE HYDROGEN PICKUP AND THE CONSEQUENT CHANGES IN THE MECHANICAL PROPERTIES IN CONNECTION WITH THE ZR-NB 1 AND ZR-NB 2.5 ALLOYS WITH RESPECT TO ZIRCALOY-2 TAKEN AS STANDARD OF COMPARISON.

*ALLOY + *EMBRITTLEMENT + *HYDROGEN + *NIOBIUM + *ZIRCALOY + *ZIRCONIUM + BRITTLE FRACTURE

7-10174 COTTRELL WB
ORNL NUCLEAR SAFETY RESEARCH AND DEVELOPMENT PROGRAM BIMONTHLY REPORT FOR MARCH - APRIL 1966
OAK RIDGE NATIONAL LABORATORY
ORNL-CF-66-5-20 +. 45 PAGES, MAY 2, 1966, SOURCE

ORNL PROGRESS IN THE USAEC REACTOR SAFETY PROGRAM DURING THE MONTHS OF MARCH AND APRIL ARE SUMMARIZED. INCLUDED IS WORK ON VARIOUS CHEMICAL REACTIONS, THE RELEASE, CHARACTERIZATION, AND TRANSPORT OF FISSION PRODUCTS IN CONTAINMENT SYSTEMS UNDER VARIOUS ACCIDENT CONDITIONS, AND PROBLEMS ASSOCIATED WITH THE REMOVAL OF THESE FISSION PRODUCTS FROM GAS STREAMS. WHILE THESE STUDIES PROVIDE INFORMATION ON THE CONSEQUENCE OF POTENTIAL REACTOR ACCIDENTS AND THUS HAVE DIRECT RELEVANCE TO THE EVALUATION OF REACTOR SITES, A SEPARATE STUDY IS BEING UNDERTAKEN ON THE SAFETY AND FEASIBILITY OF THE OFF-SHORE SITING OF POWER REACTORS. ALTHOUGH MOST OF THE WORK HAS BEEN AND CONTINUES TO BE IN GENERAL SUPPORT OF WATER POWER REACTOR TECHNOLOGY, INCLUDING SOME IN DIRECT SUPPORT OF THE LOFT AND CSE PROGRAMS, SEVERAL NEW PROJECTS WERE INITIATED THE FIRST OF THE YEAR IN SUPPORT OF THE HIGH-TEMPERATURE GAS-COOLED REACTOR (HTGR) PROGRAM. THESE NEW PROJECTS INCLUDE BOTH IN-PILE AND OUT-PILE STUDIES OF REACTION RATES AND FISSION-PRODUCT RELEASE AND TRANSPORT PHENOMENA RELEVANT TO POTENTIAL HTGR ACCIDENT SITUATIONS. TWO NEW PROJECTS, INITIATED DURING THE REPORT PERIOD, INCLUDE STUDIES ON PRESSURE-VESSEL TECHNOLOGY AND THE INITIATION OF A SERIES OF DISCUSSION PAPERS ON VARIOUS ASPECTS OF WATER REACTOR TECHNOLOGY. RECENT ACTIVITIES OF THE NSIC AND THE NUCLEAR SAFETY JOURNAL IN BEHALF OF THE NUCLEAR COMMUNITY ARE ALSO DISCUSSED.

*FISSION PRODUCT RELEASE, GENERAL + *FISSION PRODUCT TRANSPORT + *FISSION PRODUCT, IODINE + *LOFT (LOSS OF FLUID TEST) + *NSIC (NUCLEAR SAFETY INFORMATION CENTER) + *NSPP (NUCLEAR SAFETY PILOT PLANT) + *TREAT (TRANSIENT TEST REACTOR FACILITY) + CHARCOAL + CHEMICAL KINETICS + CONTAINMENT, PRESSURE VESSEL + FILTER + FILTER, COMBINATION + FILTER, MAY PACK + GRAPHITE + IN PILE EXPERIMENT + IN PILE LOOP + ORGANIC IODIDE + OUT OF PILE LOOPS AND EXPERIMENTS + PARTICULATE + REACTOR, GRAPHITE MODERATED + REACTOR, PRESSURIZED WATER + REACTOR, TEST + STEAM + STRESS ANALYSIS

7-10175 BENSON SW + KING JW
ELECTROSTATIC ASPECTS OF PHYSICAL ADSORPTION - IMPLICATIONS FOR MOLECULAR SIEVES AND GASEOUS ANESTHESIA

ACCESSION NUMBER 7-09952 TO 7-10175

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-10175 *CONTINUED*
STANFORD RESEARCH INSTITUTE + JET PROPULSION LABORATORY, CALIFORNIA INSTITUTE OF TECHNOLOGY, PASADENA
4 PAGES, 22 FIGURES, SCIENCE, 150(3704), PP. 1710-1713 (DECEMBER 24, 1965)

STATE-OF-THE-SCIENCE REVIEW. THE EQUATIONS OF ELECTROSTATICS ARE APPLIED TO THE ADSORPTION OF GASES ON MOLECULAR SIEVES. SEPARATIONS ON SIEVES ARE CAUSED NOT BY THE SIZE OF MOLECULES BUT BY ELECTROSTATIC FORCES BETWEEN THE GASES AND THE STRONG ELECTRIC FIELDS OF THE SIEVES. ELECTROSTATIC INTERACTIONS CAN ALSO EXPLAIN THE PHENOMENON OF GENERAL ANESTHESIA.

*ADSORPTION + *CHROMATOGRAPHY + *ELECTROSTATIC CHARGE + *MOLECULAR SIEVE + ADSORPTION SURFACE + ANALYTICAL TECHNIQUE, GAS + CHEMISORPTION + SURFACE TO VOLUME RATIO

7-10177 BOLOTIN VF + NEMIOV NF
IDENTIFICATION AND MEASUREMENT OF THE ACTIVITY OF LONG-LIVED BETA-ACTIVE ISOTOPE FISSION FRAGMENTS IN THE DISPERSION PHASE OF AEROSOLS. REPORT NO. 118
GOSUDARSTVENNYI KOMITET PO ISPOLZOVANIYU ATOMNOI ENERGII SSSR
NP-15102 +. 13 PAGES, 1964, DEP/MN, IN RUSSIAN

RADIOMETRIC ANALYSIS WAS MADE OF BETA ACTIVE FRAGMENTS (CS-137, SR-90, Y-90, RH-106, CE-144, PR-144, ZR-NB-95) SIMULTANEOUSLY PRESENT IN THE AIR OF RADIOCHEMICAL PLANTS. THE IDENTIFICATION AND MEASUREMENTS WERE CARRIED OUT WITH AN AIR-COLLECTOR WITH FILTER BELT AND BETA- AND GAMMA-SPECTROMETER TRANSDUCERS ERECTED ON ONE STAND, AND AN ELECTRON-MEASURING EQUIPMENT CONSISTING OF SEVEN IDENTICAL DIFFERENTIAL DISCRIMINATORS REGULATED BY THE CHANNEL WIDTH, PLUS SEVEN IDENTICAL NUMERICAL COUNTERS, ON ANOTHER STAND. THE SENSITIVITY OF THE INSTALLATION IS ABOUT 1 TIMES 10 TO 13 COUNTS/LITER IN CASES IN WHICH THE CONTENT OF ALL ISOTOPES IS IDENTICAL.

*AEROSOL + *ANALYTICAL TECHNIQUE, GENERAL + *BETA EMITTER + *FISSION PRODUCT, AIRBORNE + *RADIOCHEMICAL ANALYSIS + *RADIOCHEMICAL PROCESSING + CERIUM + CESIUM + NIOBIUM + PRASEODYMIUM + RHODIUM + RUTHENIUM + STRONTIUM + YTTRIUM + ZIRCONIUM

7-10178 ARTEMENKOVA LV
RADIOMETRY OF IODINE. REPORT NO. 109
GOSUDARSTVENNYI KOMITET PO ISPOLZOVANIYU ATOMNOI ENERGII SSSR
NP-15104 +. 8 PAGES, 1964, DEP/MN. IN RUSSIAN

BRIEF REVIEW OF THE METHODS AND EQUIPMENT USED IN RADIOMETRY OF RADIOACTIVE IODINE RELEASED DURING TREATMENT OF NUCLEAR FUEL AND IN LABORATORIES PRODUCING RADIOACTIVE ISOTOPES.

*FISSION PRODUCT, IODINE + *IODINE + *RADIOCHEMICAL PROCESSING + ANALYTICAL TECHNIQUE, GENERAL + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT

7-10179 VANSLAGER FE
RAD 2 - A COMPUTER PROGRAM FOR CALCULATING FISSION PRODUCT RADIOACTIVITIES
GENERAL ATOMIC, SAN DIEGO, CALIFORNIA
GAMD-6519 +. 33 PAGES, JULY 23, 1965, CFSTI, \$2.00 CY, \$0.50 MN

RAD 2 IS A FORTRAN IV COMPUTER PROGRAM DESIGNED FOR CALCULATING FISSION-PRODUCT-ACTIVITY DISTRIBUTIONS IN A HIGH-TEMPERATURE GAS-COOLED REACTOR SYSTEM. THE PROGRAM REQUIRES INPUT INFORMATION CONCERNING THE RELEASE OF EACH FISSION PRODUCT FROM THE FUEL MATERIAL OR, ALTERNATIVELY, A DIFFUSION PARAMETER FROM WHICH THE PROGRAM CALCULATES THESE RELEASE FRACTIONS, ASSUMING DIFFUSIVE RELEASE. THE PROGRAM WILL PERFORM A VARIETY OF SIMPLE BOOKKEEPING CALCULATIONS FOR FISSION-PRODUCT DECAY CHAINS OF ANY DESIRED LENGTH.

*ANALYTICAL MODEL + *COMPUTER PROGRAM + *FISSION PRODUCT RELEASE, GENERAL + *FISSION PRODUCT TRANSPORT + DIFFUSION

7-10270 ARNETT LM + ROSS CP + RUSCHE BC + TAYLOR CD
FINAL SAFETY ANALYSIS OF THE MAXIMUM CREDIBLE ACCIDENT IN THE HEAVY WATER COMPONENTS TEST REACTOR SAVANNAH RIVER LABORATORY, DUPONT
DP-1037 +. 30 PAGES, 4 FIGURES, 7 TABLES, REFERENCES, DECEMBER 1965, CFSTI \$2.00 CY, \$0.50 MN

THE MAXIMUM CREDIBLE ACCIDENT IN THE HWCTR IS ANALYZED FOR THE CONDITIONS THAT EXIST SINCE IODINE ABSORBERS WERE INSTALLED IN THE CONTAINMENT BUILDING. THE ABSORBERS REMOVE RADIOIODINE ISOTOPES TO THE EXTENT THAT THE THYROID AND WHOLE-BODY DOSES AT THE SAVANNAH RIVER PLANT BOUNDARY WOULD BE LESS BY FACTORS OF SIX AND TWENTY-FIVE, RESPECTIVELY, THAN THE ALLOWABLE LIMITS SET FORTH IN THE CODE OF FEDERAL REGULATIONS (10 CFR 100).

*ACCIDENT, MAXIMUM CREDIBLE (MCA) + *HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + FILTER + IODINE + SAFEGUARDS REPORT, GENERAL

7-10296 MICHELSON C + SCOTT JL + LONG EL
AN EVALUATION OF UO2 IRRADIATED AT 1600 TO 2400 DEGREES C
OAK RIDGE NATIONAL LABORATORY
ORNL-3930 +. 70 PAGES, 27 FIGURES, 15 TABLES, REFERENCES, MAY, 1966, CFSTI, \$3.00 CY

FOUR HEAVY-WALL INCONEL CAPSULES WERE PREPARED FOR IRRADIATION IN AN AIR-COOLED LOOP IN THE LOW INTENSITY TEST REACTOR AT OAK RIDGE. EACH CAPSULE WAS CLOSED AT MIDLENGTH TO FORM TWO GAS-TIGHT COMPARTMENTS, WHICH WERE FILLED WITH ARGON. EACH COMPARTMENT CONTAINED THREE 20-PERCENT-ENRICHED UO2 FUEL BUSHINGS 0.2 CM ID, 0.4 CM OD, AND 0.6 CM LONG. EACH FUEL

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-10296 *CONTINUED*

BUSHING WAS SURROUNDED BY A DEPLETED UO₂ INSULATING BUSHING 0.4 CM ID, 0.7 CM OD, AND 0.6 CM LONG. MOST COMPARTMENTS CONTAINED TANTALUM-SHEATHED CENTRAL THERMOCOUPLES, AND EACH CAPSULE HAD THREE THERMOCOUPLES ATTACHED TO THE INCONEL CLADDING. THE BASIC PLAN WAS TO IRRADIATE THESE CAPSULES AT FUEL TEMPERATURES EXCEEDING 1900 C AND BURNUPS RANGING FROM 0.01 TO 1.0 AT. PERCENT. THE OBJECTIVE WAS TO DETERMINE FISSION-GAS RELEASE AND EVALUATE MICROSTRUCTURAL CHANGES AS A FUNCTION OF BURNUP. THE THERMAL NEUTRON FLUX WAS ABOUT 1.7 TIMES 10 TO THE 13.

*FUEL ELEMENT + *IN PILE LOOP + *REACTOR, GAS COOLED + *URANIUM OXIDE + CLAD + FISSION GAS RELEASE + FUEL INTEGRITY + IN PILE EXPERIMENT + IRRADIATION TESTING + RADIATION DAMAGE

7-10407 MORRISON DL + GIESEKE JA + RITZMAN RL + WALTERS CT + GENCO JM + SUNDERMAN DN
AN EVALUATION OF THE APPLICABILITY OF EXISTING DATA TO THE ANALYTICAL DESCRIPTION OF A NUCLEAR-REACTOR ACCIDENT. QUARTERLY PROGRESS REPORT FOR JANUARY-MARCH, 1966
BATTELLE MEMORIAL INSTITUTE
BMI-X-10163 + EURAEC-1641 +. 44 PAGES, 9 FIGURES, 2 TABLES, 55 REFERENCES, APRIL 1, 1966, CFSTI, \$2.00 CY, \$0.50 MN

THIS IS A PROGRESS REPORT ON THE FOLLOWING AREAS - HEAT TRANSFER AND THERMODYNAMICS, METAL-WATER REACTIONS, HYDROGEN COMBUSTION, LOSS-OF-COOLANT ACCIDENT, MELTDOWN, FISSION-PRODUCT CHEMISTRY, FISSION-PRODUCT TRANSPORT AND DEPOSITION, DEPOSITION ON SURFACES, PARTICLE DYNAMICS, AND PARTICLE-SIZE ANALYSIS ON DEPOSITION TUBES WITH POLYDISPERSE PARTICLES.

*ACCIDENT MODEL + *AEROSOL + *AEROSOL PROPERTIES + ACCIDENT ANALYSIS + CHEMICAL REACTION + CORE MELTDOWN + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT + HEAT TRANSFER + LOSS OF COOLANT + SURFACE, GENERAL + THERMODYNAMICS

7-10578 DIETZ KA
QUARTERLY TECHNICAL REPORT - STEP PROJECT, APRIL 1965-JUNE 1965
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
100-17145 +. 104 PAGES, 69 FIGURES, 14 TABLES, 30 REFERENCES, MAY 1966, CFSTI, \$4.00 CY, \$0.75 MN

QUARTERLY PROGRESS REPORT ON SNAPTRAN-1 TEST PROGRAM, LOFT CORE DESIGN, LOFT FACILITY AND EXPERIMENTAL DESIGN, LOFT ANALYSIS, LOFT RADIOLOGICAL STUDIES, AND INSTRUMENTATION STUDIES.

*LOFT (LOSS OF FLUID TEST) + *SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES) + *STEP (SAFETY TEST ENGINEERING PROGRAM) + ANALYTICAL MODEL + CONTAINMENT DESIGN + CONTAINMENT FILTERING SYSTEM + CONTAINMENT INSTRUMENTATION + FISSION PRODUCT TRANSPORT + INSTRUMENTATION, GENERAL + IODINE + REACTOR KINETICS + REACTOR, PRESSURIZED WATER + SAMPLING

7-10580 QUON JE + MOCKROS LF
THE EQUILIBRIUM SIZE DISTRIBUTION OF AN AEROSOL CONTINUALLY REINFORCED WITH PARTICLES
NORTHWESTERN UNIVERSITY, THE TECHNOLOGICAL INSTITUTE, EVANSTON, ILLINOIS
11 PAGES, 4 TABLES, 4 FIGURES, 7 REFERENCES, INT. J. AIR WATER POLLUTION, 9, PP. 279-290 (1965)

AN AEROSOL CONTINUALLY REINFORCED BY A CONSTANT RATE OF INPUT OF PARTICLES EVENTUALLY REACHES AN EQUILIBRIUM DISTRIBUTION OF PARTICLE SIZES. THE CHARACTERISTICS OF THE EQUILIBRIUM DISTRIBUTION DEPEND ON THE COAGULATION PROCESS AND ON THE CHARACTERISTICS OF THE INPUT DISTRIBUTION. USING A MODIFICATION OF SMOLUCHOWSKIS THEORY (1918), EQUILIBRIUM SIZE DISTRIBUTIONS ARE NUMERICALLY COMPUTED FOR INPUTS OF (1) PARTICLES OF UNIFORM SIZE, AND (2) PARTICLES WHOSE CONCENTRATION SIZE CURVE IS A SKEWED DISTRIBUTION. FOR PARTICLE SIZES GREATER THAN THE MODAL INPUT SIZE, THE EQUILIBRIUM SIZE DISTRIBUTION IS CHARACTERIZED BY A POWER LAW. WHEN PLOTTED ON LCG-LOG PAPER THE POWER LAW IS CHARACTERIZED BY A SLOPE, S-SUB-M OF 1.5 FOR AN INPUT OF UNIFORM SIZE PARTICLES. FOR DISTRIBUTED INPUTS WHOSE GEOMETRIC STANDARD DEVIATION VARIES FROM 1.2 TO 2.0, THE CHARACTERISTIC SLOPE S-SUB-M VARIES FROM 1.5 TO 0.35. THE CONCENTRATIONS MAY BE SCALED FOR ARBITRARY VALUES OF THE COAGULATION RATE CONSTANT K AND INPUT RATE, I-SUB-M. USING A MODEL FOR THE PACKING OF AGGLOMERATES (VOLD, 1963), THE RESULTS MAY BE SCALED FOR ANY ASSUMED DEGREE OF PACKING.

*AEROSOL + *AEROSOL PROPERTIES + *AGGLOMERATE + *PARTICLE SIZE + COALESCENCE + PARTICLE SIZE DISTRIBUTION + PARTICULATE

7-10581 KOLTZ RJ
ANALYSIS OF FISSION PRODUCT ACTIVITY EFFECTS FOR THE ELK RIVER REACTOR
COMBUSTION ENGINEERING, INC.
CEND-512 +. 56 PAGES, TABLES, FIGURES, OCTOBER, 1964, CFSTI, \$3.00 CY, \$0.50 MN

THE PURPOSE OF THIS REPORT IS TO RECORD A COMPLETE ANALYSIS OF THE FISSION-PRODUCT ACTIVITIES EXPECTED FROM THE ELK RIVER REACTOR AND THEIR EFFECTS ON ITS SAFE OPERATION. INCLUDED IN THE STUDY ARE THE EXPECTED DOSE RATES AND DOSAGES, INSIDE AND OUTSIDE THE CONTAINMENT BUILDING. THE PURPOSE OF THE ANALYSIS WAS TO PROVIDE INFORMATION NEEDED FOR THE ANTICIPATION OF EFFECTS BEARING ON RADIATION CONTROL IN AND AROUND THE PLANT, IN ORDER TO FACILITATE PLANNING FOR SAFE AND EFFICIENT RADIATION CONTROL. OBVIOUSLY THE PREDICTIONS, WHICH INVOLVE LARGE INHERENT UNCERTAINTIES, SHOULD NOT IN ANY WAY BE CONSIDERED AS SUBSTITUTES FOR EFFECTIVE MONITORING IN THE RADIATION CONTROL PROGRAM.

*SAFETY STUDY + BUILDING + CONTAINMENT, GENERAL + MONITOR, RADIATION, GENERAL + RADIOCHEMICAL PLANT SAFETY + SOURCE, CONTINUOUS + STACK

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-10582 LEDWIDGE TJ + MAIDMENT L
IN SITU MEASUREMENT OF F.P. GAS DENSITY
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, DOUNREAY
2 PAGES, 3 FIGURES, NUCLEAR ENGINEERING 11(120), PP. 380-381 (MAY, 1966)

A METHOD OF MEASURING THE INTERNAL GAS PRESSURE IN IRRADIATED FUEL TUBES HAS BEEN EVOLVED BY THE AEA. IT DOES NOT REQUIRE ORTHODOX PRESSURE TRANSDUCERS AND WAS DEVELOPED PARTICULARLY FOR FAST REACTOR FUEL CAPSULES BUT IS CONSIDERED SUITABLE FOR ANY CAPSULE OR VESSEL WHERE THE ENVIRONMENT MAKES NORMAL PRESSURE-SENSING IMPOSSIBLE. IT IS BASED ON THE FACT THAT RESISTANCE TO MOTION OF A FALLING BODY IS PROPORTIONAL TO THE DENSITY OF THE MEDIUM THROUGH WHICH THE BODY IS FALLING FOR REYNOLDS NOS. GREATER THAN 100. CONSEQUENTLY, THE TIME TAKEN FOR A BODY TO FALL A GIVEN DISTANCE THROUGH THE MEDIUM IS A FUNCTION OF THE MEDIUM DENSITY, AND, IF THE MEDIUM TEMPERATURE IS CONSTANT, IS A FUNCTION OF THE MEDIUM PRESSURE.

*FISSION PRODUCT RELEASE, GENERAL + *INSTRUMENTATION, SURVEILLANCE + *VAPOR, VAPOR PRESSURE + INSTRUMENTATION CALIBRATION

7-10583 SUNDERMAN DN + MORRISON DL + HOWES JE + JABLONOWSKI EJ
FISSION-PRODUCT REACTIONS WITH AND RELEASE FROM FUEL-ELEMENT CLADDINGS. QUARTERLY PROGRESS REPORT, JANUARY - MARCH, 1965
BATTELLE MEMORIAL INSTITUTE
BMI-X-10118 + EURAEC-1364 +. 7 PAGES, APRIL 1, 1965, CFSTI, \$1.00 CY

THE DIFFUSION COEFFICIENTS OF NONGASEOUS FISSION PRODUCTS IN ZIRCONIUM HAVE BEEN MEASURED IN POSTIRRADIATION EXPERIMENTS AT TEMPERATURES OF 650 AND 750 C. ZIRCONIUM PLATES WERE IMPREGNATED WITH FISSION PRODUCTS BY FISSION RECOIL FROM AN ADJACENT URANIUM FOIL DURING NEUTRON IRRADIATION. FOLLOWING DIFFUSION ANNEALING OF THE SPECIMENS IN A HELIUM ATMOSPHERE, LAYERS WERE REMOVED FROM THE SPECIMEN BY CHEMICAL POLISHING. THE INDIVIDUAL FISSION-PRODUCT CONCENTRATIONS IN THE POLISH SOLUTIONS WERE DETERMINED BY COMPUTER RESOLUTION OF THE GROSS-GAMMA SPECTRA. THE DIFFUSION COEFFICIENTS WERE CALCULATED FROM THE FISSION-PRODUCT-DISTRIBUTION PROFILES.

*DIFFUSION COEFFICIENT + *FISSION PRODUCT TRANSPORT + *ZIRCONIUM + CERIUM + CLAD + RUTHENIUM + TELLURIUM

7-10584 TAIT JH
A COMPARISON OF GAS PHASE REACTION CALCULATIONS CARRIED OUT ON THE RADIATION-INDUCED REACTION BETWEEN CARBON DIOXIDE AND GRAPHITE
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-5181 +. 14 PAGES, MARCH, 1966, BIS, \$0.50, HMSO

THE THEORETICAL WORK OF JONES ON THE DIFFUSION OF SPECIES PRODUCED BY THE IRRADIATION OF CARBON DIOXIDE AND THEIR ATTACK ON GRAPHITE IS COMPARED WITH THE TREATMENT GIVEN IN AERE-R-5087. THE FORMER DEALT WITH THE ATTACK ON THE OUTER SURFACE OF THE GRAPHITE, WHILE THE LATTER WAS CONCERNED MAINLY WITH THE IN-PORE ATTACK. THE TWO TREATMENTS ARE BASICALLY THE SAME, STARTING WITH THE ONE-VELOCITY GROUP-DIFFUSION EQUATION. IT IS SHOWN THAT IT IS JUST POSSIBLE TO ACCOUNT FOR THE OBSERVED INHIBITION OF THE IN-PORE ATTACK BY THE ADDITION OF A FEW PERCENT OF CARBON MONOXIDE TO THE CARBON DIOXIDE ON AN OXYGEN ATOM MECHANISM.

*CARBON DIOXIDE + *CARBON MONOXIDE + *GRAPHITE + *OXIDATION + CHEMICAL REACTION + DIFFUSION + RADIATION EFFECT

7-10590 HIOY GM
ON THE THEORY OF THE COAGULATION OF NONINTERACTING PARTICLES IN BROWNIAN MOTION
NATIONAL CENTER FOR ATMOSPHERIC RESEARCH, BOULDER, COLORADO
22 PAGES, 12 FIGURES, 3 TABLES, 21 REFERENCES, JOURNAL OF COLLOID SCIENCE, 20(2), PP. 123-144 (FEBRUARY, 1965)

THE THEORY FOR COAGULATION OF PARTICLES IN BROWNIAN MOTION IS REVIEWED. THE EFFECTS OF HETEROGENEITY IN PARTICLE SIZE AND OF PARTICLE MOTION IN A RAREFIED MEDIUM ARE EXAMINED, USING NUMERICAL SOLUTIONS OF THE COAGULATION EQUATIONS. HETEROGENEITY AND INCREASED VALUES OF THE RATIO OF THE MEAN FREE PATH OF THE MEDIUM TO THE PARTICLE RADIUS (THE KNUDSEN NUMBER FOR PARTICLES) INCREASED THE RATE OF COAGULATION. ACCORDING TO THE RESULTS OF THE NUMERICAL EXPERIMENTS, A SELF-PRESERVING FUNCTION FOR THE SIZE DISTRIBUTION DEVELOPS AFTER DIMENSIONLESS COAGULATION TIMES OF ABOUT 3. THE SELF-PRESERVING SPECTRUM WAS FOUND TO BE INDEPENDENT OF THE INITIAL DISTRIBUTION AFTER A SUFFICIENTLY LONG TIME. THE SHAPE OF THE ASYMPTOTIC DISTRIBUTION VARIED WITH THE RATIO OF THE MEAN FREE PATH OF THE MEDIUM TO THE PARTICLE RADIUS $\lambda/R - SUB-1$. A CUMULATIVE DISTRIBUTION RAPIDLY FORMED WHICH WAS INSENSITIVE TO TIME, TO INITIAL CONDITIONS, AND TO VARIATIONS IN $\lambda/R - SUB-1$ UP TO ONE. THE AVERAGE CUMULATIVE DISTRIBUTION COMPARED FAIRLY WELL WITH AN EXPERIMENTALLY DETERMINED DISTRIBUTION.

*AEROSOL PROPERTIES + *AGGLOMERATE + *DIFFUSION + AEROSOL + ANALYTICAL MODEL + PARTICLE SIZE + PARTICLE SIZE DISTRIBUTION

7-10761 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MARCH, 1966
ARGONNE NATIONAL LABORATORY
ANL 7173 +. 102 PAGES, 26 FIGURES, 25 TABLES, REFERENCES, APRIL 22, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT, MARCH, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TESTS, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, PLUTONIUM VOLATILITY

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-10761 *CONTINUED*
SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

7-10763 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MAY, 1966
ARGONNE NATIONAL LABORATORY

ANL-7219 +. 92 PAGES, 27 FIGURES, 31 TABLES, REFERENCES, JUNE 30, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR MAY, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

7-10764 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, JUNE, 1966
ARGONNE NATIONAL LABORATORY

ANL-7230 +. 80 PAGES, 17 FIGURES, 26 TABLES, REFERENCES, JULY 27, 1966, CFSTI, \$3.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR JUNE, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO-2, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

7-11270 ETTINGER HJ + MOSS WD + BUSEY H
CHARACTERISTICS OF THE AEROSOL PRODUCED FROM BURNING SODIUM AND PLUTONIUM
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS

LA-3491 +. 51 PAGES, 28 FIGURES, 7 TABLES, 12 REFERENCES, FEBRUARY, 1966, CFSTI \$3.00 CY, \$0.50 MN

SIZE CHARACTERISTICS OF THE AEROSOL PRODUCED DURING SODIUM AND PLUTONIUM FIRES WERE DETERMINED FOR DIFFERENT ATMOSPHERES RANGING FROM AIR TO 100 PERCENT NITROGEN. GRAM QUANTITIES OF SODIUM, PLUTONIUM-COBALT-CERIUM ALLOY, AND ALPHA- AND DELTA-PHASE PLUTONIUM WERE BURNED SEPARATELY. THE AEROSOL PRODUCED BY BURNING GRAM QUANTITIES OF SODIUM WAS COMPARED WITH THAT PRODUCED BY A FIRE INVOLVING 600 POUNDS OF SODIUM. DATA WERE OBTAINED REGARDING THE FRACTION OF PLUTONIUM ALLOY AIRBORNE DURING A PLUTONIUM FIRE. FIRES SIMULATING A REACTOR ACCIDENT INVOLVING BOTH FUEL AND COOLANT DEFINED THE RELATIVE AIRBORNE CONCENTRATIONS OF PLUTONIUM AND SODIUM. SODIUM AEROSOLS PRODUCED FROM SMALL- AND LARGE-SCALE FIRES HAVE COMPARABLE SIZE CHARACTERISTICS. AEROSOL PARAMETERS CAN BE DETERMINED FOR ANY SPECIAL CONDITIONS WITHOUT BUILDING A LARGE SYSTEM FOR SUCH TESTS. OXYGEN CONCENTRATION OF THE BURNING ATMOSPHERE DOES NOT AFFECT THE PARTICLE SIZE OF THE AEROSOL PRODUCED FROM BURNING PLUTONIUM METAL OR ALLOY. FIRES INVOLVING PLUTONIUM ALLOY AND SODIUM PRODUCE AIRBORNE PARTICLES THAT HAVE A PLUTONIUM-SODIUM RATIO RANGING FROM 0.34 TO LESS THAN 0.008 PERCENT. THE HIGH INITIAL RATIO IS RAPIDLY REDUCED AS THE MOLTEN SODIUM BLANKETS THE RELEASE OF PLUTONIUM.

*PARTICLE SIZE + *PLUTONIUM + *SODIUM + AEROSOL PRODUCTION + AEROSOL PROPERTIES + AEROSOL, RADIOACTIVE +
AIR CLEANING + AIRBORNE RELEASE + ALLOY + FIRE + INCINERATION + OXIDATION

7-11376 LOFT ANALYSIS--HYDRODYNAMICS DESCRIBING ACOUSTIC PHENOMENA DURING BLOWDOWN
PHILLIPS PETROLEUM COMPANY

IDO-17165 +. 28 PAGES, 4 FIGURES, REFERENCES, PAGES 45-72 OF QUARTERLY TECHNICAL REPORT, STEP PROJECT, JULY 1965, SEPTEMBER 1965, CFSTI \$3.00 CY, \$0.75 MN

A METHOD IS BEING DEVELOPED FOR CALCULATING THE SPATIAL DISTRIBUTION OF PRESSURE WITHIN THE LOFT PRIMARY-COOLANT SYSTEM AS A FUNCTION OF TIME DURING THE FIRST HUNDRED MILLISECONDS AFTER BLOWDOWN. A CHEMICAL METHOD WAS DEVELOPED FOR THE RAPID SEPARATION OF TELLURIUM AND IODINE FROM OTHER FISSION PRODUCTS AND FROM EACH OTHER. MAXIMUM EXPECTED CONCENTRATIONS OF VARIOUS FISSION PRODUCTS WERE CALCULATED FOR THE COE AND LOFT ATMOSPHERES AFTER 1.16 DAYS OF COOLING. STANDARD SURFACES WERE SELECTED FOR PLATEOUT STUDIES. SIMULATED IRRADIATION TESTS WERE CONDUCTED IN A STEAM-AIR ATMOSPHERE. COATED AND STAINLESS STEEL SURFACES WERE CONTAMINATED WITH MOLECULAR IODINE IN AN AUTOCLAVE TO DETERMINE THE INFLUENCE OF STEAM PRESSURE ON CONTAMINATION. A DESIGN STUDY WAS MADE TO DETERMINE THE FEASIBILITY OF A REACTIVITY ACCIDENT TEST USING A SMALL BOILING-WATER-REACTOR CORE.

*LOFT (LOSS OF FLUID TEST) + DEPOSITION + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT TRANSPORT +
PRESSURE, INTERNAL

7-11382 ANDELIN RL
HIGH-TEMPERATURE COMPATIBILITY TESTING OF MOLTEN PLUTONIUM FUEL-CONTAINER SYSTEMS
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS

LA-DC-7315 + CONF-651101-28 +. 5 PAGES, FOR PRESENTATION AT THE 13TH CONFERENCE ON REMOTE SYSTEMS TECHNOLOGY, WASHINGTON, D. C., 1965, CFSTI \$1.00 CY, \$0.50 MN

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-11382 *CONTINUED*

TO DETERMINE THE COMPATIBILITY OF MOLTEN PLUTONIUM AND ITS CONTAINER FOR THE FAST-BREEDER PROGRAM, FUEL-CONTAINER SYSTEMS AT RELATIVELY HIGH TEMPERATURES (900 TO 1150 C) WERE TESTED TO REDUCE THE TIME REQUIRED TO OBTAIN CORROSION DATA, AND THIS INFORMATION WAS EXTRAPOLATED TO LOWER TEMPERATURES (600 TO 700 C), MORE PRACTICAL FOR REACTOR OPERATION. THIS REPORT DESCRIBES THE RESULTS OF SUCH TESTS ON TWO FUEL SYSTEMS - PLUTONIUM CONTAINED IN TANTALUM, AND 97.5 PERCENT PLUTONIUM PLUS 2.5 PERCENT IRON-GALLIUM STABILIZED FUEL ALLOY CONTAINED IN TANTALUM. THE TESTS WERE CONDUCTED IN A VACUUM.

*HIGH TEMPERATURE + *PLUTONIUM + REACTOR, BREEDER + REACTOR, FAST + TEST, PROOF

7-11945 MCCARTHY WJ

FERMI FUEL DAMAGE PRELIMINARY REPORT, OCTOBER 10, 1966
POWER REACTOR DEVELOPMENT COMPANY, DETROIT, MICHIGAN

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGES 9-10 (OCTOBER 17, 1966) DOCKET NO. 50-16

BRIEF REVIEW OF AN INCIDENT ON OCTOBER 5, 1966. ON RAISING THE POWER LEVEL TO 34 MW(TH), A REGULATING ROD SEEMED FARTHER OUT THAN NORMAL, ALSO TWO FUEL-OUTLET TEMPERATURES WERE ABOVE NORMAL. COVER-GAS ACTIVITY HAD INCREASED. SOME FUEL DAMAGE AND REDISTRIBUTION RESULTED, AND INVESTIGATIONS ARE CONTINUING.

*FAILURE, FUEL ELEMENT + FERMI + REACTOR, FAST BREEDER + REACTOR, LIQUID METAL COOLED

7-12072 RIVERS RD + TRINKLE JL

MOISTURE SEPARATOR STUDY

AMERICAN AIR FILTER COMPANY, INC., LOUISVILLE

NYO-3250-6 +. 50 PAGES, 25 FIGURES, 8 TABLES, JUNE 1966, CF3T1

IN THE EVENT OF AN INCIDENT AT THE CONNECTICUT YANKEE ATOMIC POWER PLANT WATER SPRAYS WILL BE ACTIVATED INSIDE THE REACTOR CONTAINMENT. FOUR RECIRCULATING FILTER SYSTEMS OF 40,000 CFM CAPACITY EACH WILL BE ACTIVATED TO REDUCE THE CONCENTRATION OF RADIOIODINE, ITS COMPOUNDS AND OTHER FISSION PRODUCTS. THESE SYSTEMS INCLUDE CHARCOAL FILTERS (FOR REMOVAL OF GASEOUS FISSION PRODUCTS) WHICH ARE PROTECTED BY HIGH-EFFICIENCY PARTICULATE FILTERS. WATER DROPLETS MUST NOT BE ALLOWED TO REACH THESE PARTICULATE FILTERS, FOR WATER WILL BLOCK THE FILTER MEDIA, CAUSING A REDUCTION IN AIR FLOW AND POSSIBLE MEDIA RUPTURE. A MOISTURE SEPARATOR TO REMOVE WATER DROPLETS MUST BE PROVIDED UPSTREAM OF THE PARTICULATE FILTER. THE MOISTURE SEPARATOR REMOVED ESSENTIALLY ALL DROPLETS FROM THE AIR STREAM UNDER SIX TEST CONDITIONS WITH PRESSURES RANGING FROM 10 TO 40 PSI. HIGH EFFICIENCY PARTICULATE FILTERS DOWNSTREAM OF THE SEPARATOR WITHSTOOD TEST PERIODS UP TO 24 HOURS AT PREDICTED MAXIMUM CONDITIONS WITHOUT MEASURABLE LOSS OF PERFORMANCE.

*CONNECTICUT YANKEE + *FILTER SAFETY EVALUATION + *FILTER SPRAY + *SEPARATOR + *STEAM +
*TEST, FILTER SYSTEM + CONTAINMENT FILTERING SYSTEM + FILTER SYSTEM + REACTOR, PRESSURIZED WATER +
WATER VAPOR

7-12074 MOHNNEN V

INVESTIGATIONS INTO ATTACHMENT PROPERTIES OF RADIOACTIVE AEROSOLS

MUNICH UNIVERSITY, WEST GERMANY

BMWF-FBK-66-11 +. 58 PAGES, 10 FIGURES, 33 REFERENCES, MAY 1966, DEP. MN, IN GERMAN

THE ATTACHMENT OF SMALL IONS AND RADIOACTIVE DECAY PRODUCTS (FROM RADON OR THORON) TO AEROSOLS WAS STUDIED, STARTING WITH THE EXACT SOLUTION OF THE DIFFUSION EQUATION. FOR THE FIRST TIME, ALL PARAMETERS IN THIS EQUATION WERE DISCUSSED, AND ALL POSSIBILITIES TO SIMPLIFY THE RESULTING EQUATION WERE THEORETICALLY EXAMINED FOR DEVIATIONS FROM THE EXACT VALUE. ALSO A STRONG DIFFERENTIATION WAS MADE BETWEEN THE ATTACHMENT OF NEUTRAL AND ELECTRICALLY LOADED, RADIOACTIVE DECAY PRODUCTS. THE TIME FOR ION CAPTURE AND NEUTRAL DECAY PRODUCT CAPTURE TO A GIVEN AEROSOL MIXTURE WAS CALCULATED. A METHOD TO DETERMINE THE TOTAL NUMBER OF PARTICLES AND THEIR SIZE SPECTRUM (USING A CYLINDRICAL CONDENSOR AS PARTICLE DISCRIMINATOR) WERE THEORETICALLY ESTABLISHED.

*AEROSOL + *MATHEMATICAL STUDY + *PARTICLE SIZE DISTRIBUTION + *PARTICLE, RADIOACTIVE + ADSORPTION +
ANALYTICAL MODEL + ELECTROSTATIC CHARGE + THEORETICAL INVESTIGATION

7-12075 SHAPIRO NZ + SHAPLEY LS

ON MEMBRANE EQUILIBRIA

RAND CORPORATION, SANTA MONICA

RM-4464-PK +. 51 PAGES, 2 FIGURES, 1 TABLE, 24 REFERENCES, JULY 1966, SOURCE

THIS MEMORANDUM REPORTS RECENT RESULTS OF CONTINUING RAND RESEARCH ON THE THEORETICAL AND COMPUTATIONAL ASPECTS OF IDEAL CHEMICAL SYSTEMS. THIS RESEARCH IS COMPANION TO STUDIES ON THE USE OF MATHEMATICAL MODELS TO INVESTIGATE THE CHEMISTRY OF PHYSIOLOGICAL SUBSYSTEMS. SPECIFICALLY, THE MEMORANDUM DEALS WITH THEORETICAL PROPERTIES OF THE TYPE OF IDEAL CHEMICAL SYSTEM SUGGESTED BY PROBLEMS INVOLVING SEMIPERMEABLE MEMBRANES IN BIOLOGICAL SYSTEMS. THE DISCUSSIONS, RESULTS, AND INFORMAL PROOFS SHOULD BE INTELLIGIBLE TO MATHEMATICALLY LITERATE BIOCHEMISTS, PHYSIOLOGISTS, RESEARCH PHYSICIANS, ETC. SOME OF THE FORMAL PROOFS, HOWEVER, REQUIRE MORE MATHEMATICAL BACKGROUND.

*BIOMEDICAL + *CHEMICAL EQUILIBRIUM + *MATHEMATICAL STUDY + ANALYTICAL MODEL + EQUATION, GENERAL +
THEORETICAL INVESTIGATION

CATEGORY 7
FISSION PRODUCT RELEASE, TRANSPORT, AND REMOVAL

7-12076 BARNES RH + KIRCHER JF + TOWNLEY CW
CHEMICAL EQUILIBRIUM STUDIES OF ORGANIC-IODIDE FORMATION UNDER NUCLEAR REACTOR ACCIDENT CONDITIONS
BATTELLE MEMORIAL INSTITUTE
BMI-1781 +. 32 PAGES, 15 FIGURES, 19 REFERENCES, AUGUST 15, 1966, CFSTI \$2.00 CY, \$0.50 MN.

THE PRESENCE OF CH₃I IN NUCLEAR-REACTOR ENVIRONMENTS POSES A POTENTIAL HAZARD BECAUSE OF THE DIFFICULTIES INVOLVED IN REMOVING THIS COMPOUND FROM GASES USING CONVENTIONAL TRAPPING TECHNIQUES. TO GAIN INSIGHT INTO THE CHEMICAL PROCESSES LEADING TO CH₃I FORMATION, A STUDY WAS PERFORMED OF CALCULATED EQUILIBRIUM CONCENTRATIONS OF CH₃I AND OTHER IMPORTANT SPECIES FOR A RANGE OF CONDITIONS TYPICAL OF REACTOR-ACCIDENT SYSTEMS. THE RESULTS OF THIS STUDY INDICATED THAT CHEMICAL SYSTEMS CONTAINING SIMPLE COMPOUNDS SUCH AS CO₂, H₂O, CH₄, AND IODINE WOULD BE EXPECTED TO GENERATE CH₃I. THE CALCULATED EQUILIBRIUM CONCENTRATIONS OF CH₃I WERE FOUND TO BE SEVERAL ORDERS OF MAGNITUDE LOWER THAN THOSE OBSERVED IN COMPARABLE EXPERIMENTAL SYSTEMS, INDICATING THAT CHEMICAL-KINETIC FACTORS ARE IMPORTANT. A PRELIMINARY STUDY OF THE PRACTICALITY OF SOLVING THE KINETIC PROBLEM WAS MADE.

*CHEMICAL EQUILIBRIUM + *CHEMICAL KINETICS + *FISSION PRODUCT, IODINE + *ORGANIC IODIDE + ACCIDENT MODEL + ANALYTICAL MODEL + CHEMICAL REACTION

7-12077 KEILHOLTZ GW
FILTERS, SORBENTS, AND AIR CLEANING SYSTEMS AS ENGINEERED SAFEGUARDS IN NUCLEAR INSTALLATIONS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE
ORNL-NSIC-13 +. 143 PAGES, FIGURES, TABLES, REFERENCES, OCTOBER 1966, CFSTI \$5.00 CY

THE PURPOSE OF THIS REVIEW IS FIRST, TO PRESENT BRIEFLY SOME OF THE GAS CLEANING METHODS USED AT NUCLEAR REACTOR PLANTS AND OTHER PLACES WHERE RADIOACTIVE SUBSTANCES MUST BE REMOVED FROM AIR BEFORE IT IS RELEASED TO THE ATMOSPHERE, SECOND, TO PRESENT PERTINENT INFORMATION ABOUT THE PHYSICAL AND CHEMICAL PROPERTIES OF FISSION PRODUCTS AS THEY RELATE TO TRAPPING, THIRD, TO INDICATE RECENT ADVANCES IN THE TRAPPING (FILTRATION AND SORPTION) OF THESE RADIATION EMITTERS. HIGH-EFFICIENCY PARTICULATE AIR FILTERS, SORBENTS, AND AIR CLEANING SYSTEMS ARE DESCRIBED, AND THEIR USES AS ENGINEERED SAFEGUARDS FOR TRAPPING RADIOACTIVE AEROSOLS AND GASES GENERATED IN NUCLEAR INSTALLATIONS ARE EVALUATED.

*AIR CLEANING + *ENGINEERED SAFEGUARD + *FILTER SYSTEM + *FISSION PRODUCT, IODINE + *ORGANIC IODIDE + *SORPTION + CONTAINMENT FILTERING SYSTEM + FILTER SAFETY EVALUATION + FISSION PRODUCT RETENTION + NSIC (NUCLEAR SAFETY INFORMATION CENTER) + RADIOCHEMICAL PLANT SAFETY + REACTOR SAFETY SYSTEM

7-12078 CELLFRINO A + CAVALCANTI RC
USE OF RADIOACTIVE KRYPTON 85KR IN THE STUDY OF VENTILATION UNIFORMITY AND DISTRIBUTION OF PERFUSION IN SEPARATE LUNGS. 1. PRESENTATION OF THE METHOD
NP-TR-1382 39 PAGES, 1965, MINERVA NUCLEARE 9(3), PAGES 160-71, JCL \$3.60 FS, \$1.37 MF

ON THE BASIS OF A NEW CONCEPT IN THE USE OF RADIOACTIVE GASES FOR THE STUDY OF REGIONAL PULMONARY VENTILATION AND PERFUSION, AN ORIGINAL APPARATUS IS DESCRIBED WHICH PERMITS A CONTINUOUS BREATH-BY-BREATH MEASUREMENT OF RADIOACTIVITY ON THE EXPIRATORY FLOW OF THE LUNGS TOGETHER OR INDIVIDUALLY. SOME PATTERNS OF THE WASH-OUT CURVES OBTAINED AFTER INTRAVENOUS INJECTION OF SMALL AMOUNTS OF KR-85 IN AQUEOUS SOLUTIONS ARE PRESENTED.

*INHALATION + *KRYPTON + TESTING + TRACER, RADIOACTIVE

7-12079 MILLER NE + MARTIN RL + ROSENBERG HS + PRICE RB + TOWNLEY CW
ETR IRRADIATIONS OF PYROLYTIC-CARBON-COATED FUEL PARTICLES
BATTELLE MEMORIAL INSTITUTE, COLUMBUS
BMI-1772 +. 35 PAGES, 20 FIGURES, 4 TABLES, 5 REFERENCES, MAY 11, 1966, CFSTI \$2.00 CY, \$0.50 MN

TRIPPLICATE SPECIMENS OF EACH OF 25 LOTS OF PYC-COATED FUEL PARTICLES WERE IRRADIATED IN THE ETR AT TEMPERATURES OF NOMINALLY 550, 1100, AND 1300 C TO BURNUPS ON THE ORDER OF 2 TIMES 10(21ST) FISSIONS PER CC. THE SAMPLES INCLUDED COATINGS OF MONOLITHIC LAMINAR PYROLYTIC CARBON, DUPLEX PYROLYTIC CARBON (LAMINARY OVER POROUS), AND COMPOSITE PYROLYTIC CARBON (PYC OVER BEO OR SIC) APPLIED TO URANIUM- OR (THORIUM-URANIUM) - BASE FUEL PARTICLES. POSTIRRADIATION FISSION-GAS-RELEASE MEASUREMENTS AND METALLOGRAPHIC EXAMINATIONS WERE USED TO STUDY THE EFFECTS OF COATING COMPOSITION AND THICKNESS, FUEL COMPOSITION AND DENSITY, AND IRRADIATION TEMPERATURE. NO DEFINITE EFFECTS OF FUEL COMPOSITION AND IRRADIATION TEMPERATURE WERE OBSERVED. DUPLEX AND COMPOSITE COATINGS SHOWED THE BEST PERFORMANCE WITH SOME ADDITIONAL IMPROVEMENT NOTED WHEN USED ON FUEL CORES OF LOWER DENSITY. OF THE MONOLITHIC COATINGS, ONLY THE THICK COATING SHOWED NO FAILURE. RESULTS OF FOUR IRRADIATIONS AT THE BRRR SHOWED NO FAILURE OF MONOLITHIC PYC COATINGS ON LARGE, POROUS UO₂ PARTICLES IRRADIATED TO HIGH BURNUP.

*COATED PARTICLE + *FAILURE, COATED PARTICLE + *FUEL INTEGRITY + *PYROLYTIC + CARBIDE + CARBON + FISSION PRODUCT RELEASE, GENERAL + FISSION PRODUCT RETENTION + FUEL BURNUP + RADIATION DAMAGE

7-12080 SCHWARTZBERG FR + OSGOOD SH + KEYS PD + KIEFER TF
CRYOGENIC-MATERIALS DATA HANDBOOK
THE MARTIN COMPANY, DENVER
AD-609,562 + PB-171,809, REV. +. 200 PAGES, AUGUST 1964, CFSTI

THE COMPLETELY REVISED CRYOGENIC MATERIALS DATA HANDBOOK PRESENTLY CONTAINS MECHANICAL AND PHYSICAL PROPERTY DATA ON 62 METALLIC AND NONMETALLIC MATERIALS ORGANIZED IN EIGHT SECTIONS. THE HANDBOOK ALSO CONTAINS MATERIAL, PROPERTY, AND ACCUMULATIVE INDICES AND REFERENCE LIST.

*MATERIAL + *PROPERTY, PHYSICAL + ALLOY + ALUMINUM + PLASTICITY + STEEL, STAINLESS + TITANIUM

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-09701 SHAFTMAN DH + KELBER CN + KRISTIANSON BN + REED HF + SAVIO RP + STEPHANY WP + DAUGHTRY J + JOHNSON T + KOCHICK F + PLUMLEE K + ROBINSON W + STANFORD G
REACTOR PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 34 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS II-4 THROUGH II-11, PP. 42-76, CFSTI, \$7.22 CY, \$2.00 MN.

THE FOLLOWING TOPICS ARE DISCUSSED FOR THE AARR - (1) RADIATION DOSES FOLLOWING A POSTULATED MCA, HEATING RATES FOR MATERIALS IN THE INTERNAL THERMAL COLUMN AND THE REFLECTOR, BOTH DURING OPERATION AND AFTER SHUTDOWN, MULTIPLICATION OF PHOTONEUTRONS IN SUBCRITICAL AARR, EFFECTS ON REACTOR POWER AND LOCATION OF STARTUP DETECTOR, ANALYSIS OF CRITICAL-FACILITY LOADING, TRANSIENT TEMPERATURE CALCULATIONS, CRITICAL EXPERIMENTS, GAMMA HEATING.

*AARR (ARGONNE ADVANCED RESEARCH REACTOR) + ACCIDENT, MAXIMUM CREDIBLE (MCA) + COMPUTER PROGRAM + CRITICALITY EXPERIMENT + DECAY HEAT + DELAYED NEUTRON + DOSE CALCULATION, EXTERNAL + ENERGY SOURCE + INSTRUMENTATION, NUCLEAR + PROMPT NEUTRON LIFETIME + ROSSI ALPHA + TEMPERATURE COEFFICIENT + TEMPERATURE TRANSIENT + THERMAL ANALYSIS + VOID COEFFICIENT

8-09714 HWANG RN + LOEWENSTEIN WB + ALMENAS KK + KNAPP WG + DOERNER RC + BUTLER DK + COHN C + KARAM RA + KATO WY + DYER HL + SPINKAU BI + CROKE EJ + STEPHENSON M + ULRICH AJ + MADILL JT
PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 23 PAGES, FIGURES, TABLES, REFERENCES, DECEMBER 1965, SECTIONS III-32 THROUGH III-39, PP. 207-229, CFSTI, \$7.22 CY, \$2.00 MN

WITH RESPECT TO TUNGSTEN-BASED, FAST, BE- OR AL-REFLECTED ROCKET REACTIONS -
TEMPERATURE-DEPENDENT CROSS-SECTIONS OF W IN DOPPLER REGIONS, REACTIVITY COEFFICIENTS OF FUEL EXPANSION INTO REFLECTORS, EXPERIMENTS ON ZPR IX, REFLECTOR-BASED CONTROL.

*REACTOR, FAST + *SPACECRAFT + CONTROL ROD WORTH + CRITICAL ASSEMBLY FACILITY + DOPPLER EFFECT + EXPANSION REACTIVITY EFFECT + EXPERIMENT, GENERAL + FUEL EXPANSION COEFFICIENT + REACTOR DYNAMICS + REFLECTOR + ZPR IX (ANL ZERO POWER REACTOR)

8-09743 BAKER L + TEVEBAUGH AD + LEIBOWITZ L + CHASANOV M + FISCHER OF + MISHLER LW
SODIUM-AIR REACTION CALCULATIONS AND OTHER FAST REACTOR SAFETY STUDIES
ARGONNE NATIONAL LABORATORY
ANL-7055 +. 7 PAGES, 5 FIGURES, 1 TABLE, OCTOBER, 1965, SECTIONS V.B.3 AND 4, PP. 206-212 OF CHEMICAL ENGINEERING DIVISION SEMIANNUAL REPORT, JANUARY-JUNE 1965, CFSTI, \$6.00 CY \$1.25 MN.

CALCULATION OF THE MAXIMUM PRESSURE AND TEMPERATURE OBTAINABLE BY THE SODIUM-AIR REACTION, TAKING INTO ACCOUNT THERMAL DECOMPOSITION OF THE OXIDE, SHOW MAXIMUM VALUES OF ABOUT 100 PSIG AND 2000 C. HIGHER PRESSURE SEEMS ATTAINABLE WITH HIGHER STARTING PRESSURES. EXPERIMENTS ON FUEL SEGREGATION AND ON SPECIFIC HEAT OF MOLTEN UO₂ ARE BEING STARTED.

*FIRE + *SODIUM + FUEL SEGREGATION + HIGH TEMPERATURE + PRESSURE, INTERNAL + URANIUM OXIDE

8-09817 ADDITIONAL INFORMATION REQUESTED ON HUMBOLDT BAY ZIRCONIUM-WATER REACTION ANALYSIS
DIVISION OF REACTOR LICENSING, USAEC
1 PAGE, APRIL 15, 1966, DOCKET 50-133, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 44 (MAY 9, 1966)

PLANS TO REFUEL WITH A HALF CORE OF ZIRCONIUM-CLAD ELEMENTS ARE APPROVED, BUT DRL REQUESTS FURTHER ANALYSIS PRIOR TO FINAL QUARTER-CORE LOADING. DRL REQUESTS ANALYSIS (TO INCLUDE CONTAINMENT PRESSURE) ASSUMING TERMINATION TEMPERATURE TO BE MELTING POINT OF THE OXIDE.

*METAL WATER REACTION + HUMBOLDT BAY + REACTOR, BOILING WATER + ZIRCONIUM

8-09952 RABENAU A
CHEMICAL TRANSPORT REACTIONS
AACHEN LABORATORY OF PHILLIPS TECHNICAL LABORATORIES GMBH.
3 PAGES, 4 FIGURES, PHILLIPS TECHNICAL REVIEW, 26(4-6), PAGES 117-119 (1965)

THIS PAPER IS A DISCUSSION OF THE CHEMICAL-TRANSPORT REACTIONS BY WHICH A CONDENSED PHASE MAY BE TRANSFERRED THROUGH A GAS PHASE BY MEANS OF A CHEMICAL REACTION IN WHICH GASES OR VAPORS ARE INVOLVED.

*CHEMICAL REACTION + *MASS TRANSFER + CHEMICAL EQUILIBRIUM + CHEMICAL KINETICS + METAL

8-10108 CHASE WL + FORD JA + FRIEDLAND AJ + GREEN DM + KOVAC LR + MEYERS JE
ANALYSIS OF THE BABCOCK AND WILCOX FULL-SIZE STEAM GENERATOR FOR A SODIUM-WATER REACTION
ATOMIC POWER DEVELOPMENT ASSOCIATES, INC.
APDA-176 +. 188 PAGES, TABLES, FIGURES, NOVEMBER 30, 1965, CFSTI, \$5.00 CY, \$1.00 MN

AN ANALYSIS OF THE EFFECTS OF A SODIUM-WATER REACTION IN THE BABCOCK AND WILCOX FULL-SIZE STEAM GENERATOR WAS CONDUCTED. A LEAK IN A TUBE OF THE UNIT WOULD CAUSE A SODIUM-WATER REACTION WHICH WOULD RESULT IN THE RAPID GENERATION OF QUANTITIES OF REACTION PRODUCTS, INCLUDING HYDROGEN AND HIGH TEMPERATURES. THE COMPREHENSIVE MATHEMATICAL MODELS AND SUPPORTING EXPERIMENTAL TESTS DEVELOPED TO ANALYZE A SODIUM-WATER REACTION ARE DISCUSSED, AND DATA ARE PRESENTED ON THE EFFECT OF (1) LEAK SIZE, (2) PATHS FOR REACTION RELIEF, AND (3) LEAK LOCATION ON HYDROGEN PRESSURE. THE LOCATION AND OPERATING CONDITIONS FOR THE REACTION THAT WOULD RESULT IN THE MOST SEVERE PRESSURE TRANSIENT FROM THE COMPLETE SEVERANCE OF ONE

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-10108 *CONTINUED*

TUBE IS DISCUSSED AND ILLUSTRATED IN DETAIL WITH CURVES OF THE REACTION DATA. RECOMMENDATIONS ARE PRESENTED FOR (1) IMPROVING THE METHOD OF ANALYSIS OF A SODIUM-WATER REACTION IN THE FULL-SIZE STEAM GENERATOR AND (2) CHANGING THE DESIGN TO IMPROVE THE ABILITY OF THE UNIT TO WITHSTAND SUCH A REACTION.

*ACCIDENT ANALYSIS + *MATHEMATICAL STUDY + *METAL WATER REACTION + *SODIUM + ANALYTICAL MODEL

8-10110 HELMS RE + MACPHERSON RE

SUMMARY REPORT OF THE REACTION OF STEAM WITH LARGE SPECIMENS OF GRAPHITE FOR THE EXPERIMENTAL GAS-COOLED REACTOR

OAK RIDGE NATIONAL LABORATORY

ORNL-TM-1430 +. 41 PAGES, 12 FIGURES, 10 REFERENCES, MARCH, 1966, CFSTI, \$2.00 CY, \$0.50 MN

GRAPHITE REACTION RATES AND HYDROGEN GENERATION RATES HAVE BEEN DETERMINED FOR HIGH-PRESSURE HIGH-TEMPERATURE STEAM FLOWING THROUGH A FULL-SCALE EGCR FUEL-ELEMENT GRAPHITE SLEEVE (SPEER 901-RYL), AND A GEOMETRICALLY IDENTICAL SLEEVE MACHINED FROM EGCR MODERATOR GRAPHITE (NATIONAL CARBON COMPANY). GRAPHITE REACTION RATES WERE MEASURED AS A FUNCTION OF GRAPHITE BURNOFF IN THE TEMPERATURE RANGE OF 1300 TO 1600 F WITH BOTH TYPES OF GRAPHITE. EXPOSURE OF THE GRAPHITE TO STEAM OVER A PERIOD OF TIME INCREASES THE REACTIVE SURFACE AREA. THIS BURNOFF OF GRAPHITE RESULTS IN AN INCREASE IN THE NOMINAL REACTION RATE. TO DETERMINE THE EFFECT OF PRESSURE FROM 50 TO 300 PSIG, TEST DATA WERE OBTAINED BY USING AN EGCR FUEL-ELEMENT GRAPHITE SLEEVE. NO SIGNIFICANT EFFECT OF STEAM PRESSURE ON REACTION RATES WAS NOTED.

*CHEMICAL REACTION + *EGCR (EXPERIMENTAL GAS COOLED REACTOR) + *GRAPHITE + *STEAM + HIGH TEMPERATURE + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

8-10111 SODIUM-HEATED STEAM GENERATOR DEVELOPMENT. ADDENDUM TO PRELIMINARY DESIGN REPORT FULL SIZE STEAM GENERATOR SODIUM WATER REACTION

BABCOCK AND WILCOX COMPANY, BARBERTON, OHIO

BW-67-2(A) +. 160 PAGES, SEPTEMBER 15, 1965, CFSTI, \$5.00 CY, \$1.50 MN

THE STEAM GENERATOR UNDER THIS CONTRACT IS BEING DESIGNED WITH A SINGLE TUBE WALL SEPARATING THE SODIUM AND WATER. THE DESIGN OF THE FULL-SIZE AND PROTOTYPE STEAM GENERATOR IS SUCH THAT THE STEAM-GENERATOR SHELL IN EACH CASE IS PROTECTED BY A LINER SEPARATED FROM THE SHELL BY AN INERT-GAS ANNULUS. A GAS CUSHION IS PROVIDED OVER THE SODIUM IN EACH STEAM GENERATOR, AND RELIEF VALVES AND RUPTURE DISKS ARE PROVIDED FOR THE SAFE RELIEF OF THE PRODUCTS OF A SODIUM-WATER REACTION. AS A RESULT OF THIS STUDY IT IS CONCLUDED THAT THE FULL-SIZE STEAM GENERATOR WILL WITHSTAND A CREDIBLE NUMBER OF TUBES FAILING SIMULTANEOUSLY WITHOUT BECOMING A HAZARD TO NEARBY PERSONNEL AND EQUIPMENT.

*ACCIDENT ANALYSIS + *DESIGN STUDY + *METAL WATER REACTION + *SODIUM

8-10112 LIIMATAINEN RC

NUCLEAR REACTOR SAFETY - THE MELTDOWN OF METALS AT HIGH TEMPERATURES AND METAL-WATER REACTIONS

ARGONNE NATIONAL LABORATORY

ORNL-TR-694 +. 14 PAGES, TABLES, FIGURES, REFERENCES, TRANSLATED FROM ARKHIMEDES, J. FINNISH PHYSICAL SOC. (1), PP. 27-36 (1964), JCL, \$1.60 FS, \$0.80 MF

THE SIGNIFICANCE OF CHEMICAL ENERGY IS EVALUATED IN RELATION TO A WATER-COOLED REACTOR WHEREIN THE NUCLEAR ENERGY RELEASE DURING A POWER EXCURSION OR LOSS OF COOLANT INCIDENT IS SUFFICIENT TO MELT THE FUEL ELEMENTS WHICH MAY THEN REACT EXOTHERMICALLY WITH THE WATER. EXPERIMENTAL RESULTS ARE SUMMARIZED FROM BOTH LABORATORY AND TREAT IN-PILE STUDIES ON REACTION OF MOLTEN ALUMINUM, MAGNESIUM, STAINLESS STEEL, URANIUM, AND ZIRCONIUM WITH WATER. THE DATA SHOW THAT THERE ARE THREE INTERRELATED PARAMETERS PERTINENT TO THE METAL-WATER HAZARDS ANALYSIS PROBLEMS FOR A GIVEN CORE MATERIAL. THEY ARE - THE ENERGY INPUT AS DETERMINED BY THE INTEGRATED POWER OF THE REACTOR PULSE, THE REACTOR PERIOD, AND THE PARTICLE SIZE INTO WHICH THE FRAGMENTED CORE MATERIAL IS DISPERSED. FINALLY, RATE LIMITING MECHANISMS AND APPROACHES TO CORRELATING AND PREDICTING METAL-WATER REACTIONS ARE PRESENTED.

*FUEL MELTDOWN + *METAL WATER REACTION + *REACTOR, WATER + ACCIDENT ANALYSIS + ACCIDENT, REACTIVITY + IN PILE EXPERIMENT + LOSS OF COOLANT + REACTOR, GRAPHITE MODERATED + REACTOR, TEST + TREAT (TRANSIENT TEST REACTOR FACILITY)

8-10113 FORD JA

LITERATURE REVIEW OF SODIUM-WATER REACTIONS

ATOMIC POWER DEVELOPMENT ASSOCIATES, INC.

APDA-167 +. 46 PAGES, REFERENCES, MARCH 15, 1965, CFSTI

A REVIEW WAS MADE OF THE LITERATURE PERTAINING TO THE INTERACTION OF SODIUM AND WATER, WITH PARTICULAR EMPHASIS ON REACTION DATA AND INFORMATION APPLICABLE TO THE DESIGN AND ANALYSIS OF SODIUM-HEATED STEAM GENERATORS. THE FIRST FOUR SECTIONS OF THE REVIEW ARE A GENERAL DISCUSSION OF THE MORE IMPORTANT ASPECTS OF THE REACTION, WHILE THE FIFTH SECTION SUMMARIZES THE INFORMATION ON TESTS AND ANALYSES PERTINENT TO REACTIONS OCCURRING IN ALKALI-METAL-HEATED STEAM GENERATORS. IN ADDITION TO A DOCUMENTATION OF THE REACTIONS WHICH HAVE OCCURRED IN OPERATING MODEL AND PLANT-SIZED STEAM GENERATORS, TABULATIONS OF THE EXPERIMENTAL DATA FROM MOST OF THE ALKALI-METAL-WATER REACTION TESTS THAT HAVE BEEN CONDUCTED ARE PRESENTED.

*BIBLIOGRAPHY + *METAL WATER REACTION + *REVIEW + *SODIUM + DESIGN STUDY

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-10130 CHEMICAL AND ASSOCIATED ENERGY-TRANSFER PROBLEMS IN REACTOR SAFETY
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 2 PAGES, 1 TABLE, JANUARY 25, 1966, PP. 80-81 OF ANL REACTOR DEVELOPMENT PROGRAM PROGRESS
REPORT, DECEMBER 1965, CFSTI, \$3.00 CY

DATA ON THE EXTENT OF URANIUM-WATER REACTION FOR THE UNCLAD URANIUM ALLOY (5 PERCENT ZR, 1.5 PERCENT NB) PINS HAVE BECOME AVAILABLE FOR THE METAL-WATER EXPERIMENTS THAT WERE CONDUCTED DURING THE KIWI-TNT DESTRUCTIVE TEST IN JANUARY 1965 IN NEVADA. THIS TEST AFFORDED AN OPPORTUNITY TO OBTAIN METAL-WATER REACTION DATA DURING A SHORT-PERIOD (0.6-MSEC) TRANSIENT. THE EXTENT OF REACTION OF URANIUM WITH WATER WAS DETERMINED BY ANALYZING THE MELTDOWN RESIDUES, RATHER THAN BY DIRECT HYDROGEN MEASUREMENT; THE METHOD USED IN ALL PREVIOUS IN-PILE METAL-WATER REACTION EXPERIMENTS. THE DATA SHOW A CLEAR INCREASE IN THE AMOUNT OF CHEMICAL REACTION WITH PEAK URANIUM TEMPERATURES.

*METAL WATER REACTION + *URANIUM + ALLOY + ANL (ARGONNE NATIONAL LABORATORY) +
KIWI TNT (TRANSIENT NUCLEAR TEST) + NIOBIUM + ZIRCONIUM

8-10133 FAST NEUTRONS. REPORT OF ACTIVITIES OF 2ND QUARTER 1965
COMMISSARIAT A L ENERGIE ATOMIQUE, CADARACHE, FRANCE. CENTRE D ETUDES NUCLEAIRES
ORNL-TR-900 +. 106 PAGES, 1965, JCL, \$9.10 FS, \$3.38 MF

RAPSODIE CONTROL-ROD-MECHANISM AND SAFETY REPORT, SODIUM-WATER REACTION IN EVAPORATOR.
HARMONIE SAFETY REPORT, DOPPLER EFFECT AND PULSED OR MODULATED EXPERIMENTS. PIRANA TESTS, IN
PARTICULAR, EXPLOSION IN SODIUM AND WATER, MELTING OF IRRADIATED URANIUM IN SODIUM. (NOT
MUCH DATA).

*DOPPLER EFFECT + *FRANCE + *REACTOR, FAST + CONTROL ROD SCRAM MECHANISM + FUEL MELTDOWN +
METAL WATER REACTION + REACTOR, PULSED + SAFEGUARDS REPORT, GENERAL + SODIUM + URANIUM

8-10256 NELSON LS
THE COMBUSTION AND EXPLOSION OF ZIRCONIUM DROPLETS IGNITED BY FLASH HEATING
SANDIA CORPORATION
SC-RR-65-569 +. 58 PAGES, JANUARY, 1966, CFSTI, \$3.00 CY, \$0.75 MN

FLASH HEATING WITH A CAPACITOR DISCHARGE LAMP WAS USED TO STUDY THE COMBUSTION OF SINGLE
DROPLETS OF ZIRCONIUM (49 TO 525 MICRONS DIAMETER) IN AIR, OXYGEN, AND VARIOUS MIXTURES OF
OXYGEN WITH ARGON AND NITROGEN. THE BRIGHTLY BURNING DROPLETS WERE STUDIED DURING FREE FALL
AND BY QUENCHING IN LIQUID ARGON AT VARIOUS STAGES IN THE COMBUSTION. CHEMICAL AND PHYSICAL
CHANGES WERE DETERMINED, AND PARTICULAR EMPHASIS WAS PLACED ON UNDERSTANDING EXPLOSIONS OF
SOME DROPLETS A FEW HUNDRED MILLISECONDS AFTER IGNITION.

*COMBUSTION + *EXPLOSION + *ZIRCONIUM + AEROSPACE SAFETY + AIR + ARGON + CHEMICAL REACTION + NITROGEN +
OXYGEN

8-10304 PETERSON S
IGNITION AND COMBUSTION OF REACTOR MATERIALS UNDER ACCIDENT CONDITIONS
OAK RIDGE NATIONAL LABORATORY
4 PAGES, 1 TABLE, REFERENCES, NUCLEAR SAFETY, 7(2), PP. 169-173 (WINTER 1965-1966)

NEW INFORMATION IS SUMMARIZED ON THE OXIDATION REACTIONS PERTINENT TO SAFETY IN THE NUCLEAR
INDUSTRY. SUBJECTS TREATED INCLUDE THE IGNITION BEHAVIOR OF URANIUM ALLOYS (INCLUDING THOSE
WITH PLUTONIUM), THE PARTICLE SIZE OF URANIUM COMBUSTION PRODUCTS, THE OXIDATION OF URANIUM
MONONITRIDE IN VARIOUS FORMS, GRAPHITE OXIDATION BY VARIOUS GASES, THE IGNITION BEHAVIOR OF
MAGNESIUM AND ITS ALLOYS IN CARBON DIOXIDE AND MIXTURES CONTAINING CARBON DIOXIDE,
IMPROVEMENT BY ALUMINUM OF THE OXIDATION RESISTANCE OF ZIRCONIUM AND NIOBIUM BERYLLIDES, THE
IGNITION OF METAL POWDERS IN VARIOUS GASES, AND THE NATURE AND COMBATING OF FIRES.

*COMBUSTION + *IGNITION + *MATERIAL + *REACTOR, GENERAL + BERYLLIUM + CHEMICAL REACTION + FIRE + GRAPHITE +
MAGNESIUM + NIOBIUM + NITRIDE + OXIDE + URANIUM + ZIRCONIUM

8-10397 IVINS RO + LIIMATAINEN RC + TESTA FJ
REACTION OF URANIUM WITH WATER AS INITIATED BY A POWER EXCURSION IN A NUCLEAR REACTOR (TREAT)
ARGONNE NATIONAL LABORATORY
9 PAGES, 2 TABLES, 8 FIGURES, NUCLEAR SCIENCE AND ENGINEERING, 25(2), PP. 131-140 (JUNE 1966)

THE EXTENT OF REACTION WITH WATER OF FUEL MATERIALS HAVING URANIUM METAL AS THE MAJOR
CONSTITUENT WAS DETERMINED FOR ENERGIES RANGING FROM 37 TO 394 CAL/G AND REACTOR PERIODS FROM
63 TO 515 MSEC. WITH PERIODS OF ABOUT 100 MSEC, MELTING OF FUEL SAMPLES BEGAN AT A FISSION
ENERGY INPUT OF 40 CAL/G, WITH COMPLETE MELTING AT 95 CAL/G. THE EXTENT OF REACTION VARIED
FROM A FEW TENTHS OF A PERCENT FOR THOSE SAMPLES THAT HAD NOT MELTED APPRECIABLY, TO 4
PERCENT FOR THOSE THAT COMPLETELY MELTED IN THE EXPERIMENTS CONDUCTED IN 25 C WATER (20 PSIA
HELIUM OVERPRESSURE). ABOVE 95 CAL/G, THE SAMPLES FRAGMENTED, AND THE EXTENT OF REACTION
INCREASED WITH INCREASING FISSION ENERGY TO 50 PERCENT AT THE HIGHEST ENERGY, 394 CAL/G.
THREE EXPERIMENTS WERE PERFORMED IN 285 C WATER (1000-PSI STEAM OVERPRESSURE). THE THREE
SAMPLES IN 285 C WATER REACTED 2 TO 3 TIMES AS MUCH AS THOSE IN THE 25 C WATER AT THE SAME
ENERGIES.

*METAL WATER REACTION + *TREAT (TRANSIENT TEST REACTOR FACILITY) + *URANIUM + ACCIDENT ANALYSIS +
CHEMICAL REACTION + FUEL MELTDOWN + REACTOR TRANSIENT

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-10399 BAQUE P + DARRAS R
A SAFETY STUDY OF MAGNESIUM ALLOY FUEL SLEEVES IN CO₂-COOLED REACTION
COMMISSARIAT A L ENERGIE ATOMIQUE, CEN, SACLAY, FRANCE
11 PAGES, 9 FIGURES, 9 TABLES, 17 REFERENCES, JOURNAL OF NUCLEAR MATERIALS, 17(4), PP. 283-293 (DECEMBER 1965)

AN ANALYSIS WAS MADE OF THE INFLUENCE OF VARIOUS FACTORS ON THE SAFETY OF USE OF MAGNESIUM ALLOYS IN NUCLEAR REACTORS IN THE PRESENCE OF CARBON DIOXIDE, THE USUAL COOLANT. WHILE SMALL METALLIC ADDITIONS HAVE LITTLE EFFECT ON THE IGNITION TEMPERATURE OF MAGNESIUM IN CARBON DIOXIDE, AN INCREASE IN SPECIFIC SURFACE AREA OF THE SAMPLES MAY INCREASE IT CONSIDERABLY, AND SELF-HEATING THEN BECOMES SERIOUS. THE IGNITION TEMPERATURE RISES WITH THE PRESSURE OF CARBON DIOXIDE, DIMINISHES VERY RAPIDLY WHEN THE WATER VAPOUR CONTENT RISES TO 3000 VPM, AND DIMINISHES STEADILY AS THE PARTIAL PRESSURE OF AIR OR OXYGEN INCREASES.

*ALLOY + *IGNITION + *MAGNESIUM + CARBON DIOXIDE + CHEMICAL REACTION + CLAD + REACTOR, GAS COOLED

8-10454 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 7 PAGES, 2 FIGURES, 1 TABLE, JUNE 1966, DOCKET 115-5, PP. II-5-1 THROUGH II-5-7, AMENDMENT NO. 25, PDR

QUESTION II-5. DISCUSSION OF THE LIMITING HEAT FLUX OF 109 BTU/SEC-FT SQ SHOWS THAT TWO DESIGN CRITERIA WERE USED TO DETERMINE LOWER LIMITS OF CIRCULATING FLOW - (1) BURNOUT RATIO 1.5, (2) STEAM-VOLUME FRACTION LESS THAN 0.7. FOUR STANDARD POWER LEVELS WERE EVALUATED AT VARIOUS REACTOR LIFETIMES AND ROD POSITIONS TO DETERMINE THE LIMITING FLOWS. WORST CASE WAS INITIAL STARTUP, AS ZIRCALOY SHROUDS DO NOT RAISE PEAK-TO-AVERAGE POWER TO INITIAL CONDITIONS.

*BURNOUT HEAT FLUX + *LACROSSE BOILING WATER REACTOR + *POWER DISTRIBUTION +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FLOW, TWO PHASE + FUEL BURNUP + REACTOR, BOILING WATER

8-10761 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MARCH, 1966
ARGONNE NATIONAL LABORATORY
ANL-7193 +. 102 PAGES, 26 FIGURES, 25 TABLES, REFERENCES, APRIL 22, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT, MARCH, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TESTS, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO₂, METAL-WATER REACTIONS, PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

8-10763 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, MAY, 1966
ARGONNE NATIONAL LABORATORY
ANL-7219 +. 92 PAGES, 27 FIGURES, 31 TABLES, REFERENCES, JUNE 30, 1966, CFSTI, \$4.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR MAY, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO₂, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

8-10764 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, JUNE, 1966
ARGONNE NATIONAL LABORATORY
ANL-7230 +. 80 PAGES, 17 FIGURES, 26 TABLES, REFERENCES, JULY 27, 1966, CFSTI, \$3.00 CY, \$0.75 MN

ARGONNE NATIONAL LABORATORY PROGRESS REPORT FOR JUNE, 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE IRRADIATION OF FUEL PINS, TREAT MELTDOWN TEST, INTEGRAL SODIUM LOOP, FAST REACTOR SAFETY CONTAINMENT, EQUATION OF STATE OF REFRACTORIES SUCH AS UO₂, METAL-WATER REACTIONS, AND PLUTONIUM VOLATILITY SAFETY.

CONTAINMENT DESIGN + EQUATION OF STATE + FUEL MELTDOWN + METAL WATER REACTION + PLUTONIUM +
REACTOR DYNAMICS + REACTOR, FAST + SODIUM + TREAT (TRANSIENT TEST REACTOR FACILITY) + URANIUM OXIDE

8-10910 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14B -- INSTRUMENTATION SYSTEM -- THE EFFECT OF HYDRAULIC FORCES ON ROD-CLUSTER
INSERTION TIME DURING A LOSS OF COOLANT ACCIDENT WILL BE CONSIDERED IN CALCULATING ENERGY
RELEASES.

*CONTROL ROD + *HYDRODYNAMIC ANALYSIS + *LOSS OF COOLANT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-10910 *CONTINUED*
ENERGY SOURCE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

8-11402 SWIFT DL + BAKER L
EXPERIMENTAL STUDIES OF THE HIGH-TEMPERATURE INTERACTION OF FUEL AND CLADDING MATERIALS WITH LIQUID SODIUM
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7120 +. 9 PAGES, 11 FIGURES, OCTOBER 11-14, 1965, PAGES 839-847, PROCEEDINGS OF THE CONFERENCE ON
SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

A SERIES OF EXPERIMENTS WERE PERFORMED TO DETERMINE WHAT INTERACTIONS OCCUR WHEN ABNORMALLY
HOT FAST-REACTOR MATERIALS CONTACT LIQUID SODIUM. SMALL SAMPLES OF REACTOR MATERIAL WERE
HEATED TO TEMPERATURES AS HIGH AS 2400 C AND DROPPED INTO A POOL OF LIQUID SODIUM. THE
REACTOR MATERIALS STUDIED HAVE BEEN METALS AND UO2 PELLETS. THE METALS STUDIED WERE V-20 W/O
TI, NB, NB-1 W/O ZR, V, ZR, AND STAINLESS STEEL.

*HIGH TEMPERATURE + *METAL + *PYROPHORIC REACTION + *SODIUM + NIOBIUM + STEEL, STAINLESS + TITANIUM +
URANIUM DIOXIDE + ZIRCONIUM

8-11403 CHARAK I + SMITH FA
PRELIMINARY EVALUATION OF A TECHNIQUE TO STUDY EXPULSION OF SODIUM INTO AIR
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7120 +. 5 PAGES, 6 FIGURES, 1 REFERENCE, OCTOBER 11-14, 1965, PAGES 868-872, PROCEEDINGS OF THE
CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN LARGE FAST POWER REACTORS, CFSTI, \$9.25 CY, \$3.75 MN

A TECHNIQUE HAS BEEN DEVELOPED TO STUDY THE EXPULSION OF MOLTEN SODIUM INTO AIR. IT FEATURES
AN IMPACT MECHANISM USING A TEFLON PELLET FIRED FROM A REVOLVER. IF THE SMALL-SCALE
EXPERIMENTS DEFINE THE PHYSICAL NATURE OF THE SODIUM-AIR REACTION, THEN EXPERIMENTS ON A
LARGER SCALE MAY BE AVOIDED. THE NEED FOR THESE TESTS IS RELATED TO THE FARET CONTAINMENT
DESIGN, WHICH SHOULD ACCOMMODATE A MAXIMUM PRESSURE ASSOCIATED WITH THE SODIUM-AIR REACTION
FOLLOWING EXPLOSIVE EJECTION OF SODIUM INTO THE AIR-FILLED CONTAINMENT. PRELIMINARY
EXPERIMENTS INDICATED THAT HIGH-SPEED PHOTOGRAPHY WAS VERY USEFUL IN OBSERVING THE NATURE OF
THE SODIUM-AIR REACTIONS. EARLY ATTEMPTS AT PRESSURE MEASUREMENT INDICATED A RAPIDLY
OCCURRING PEAK PRESSURE SUFFICIENTLY HIGH TO CAUSE LEAKAGE AT THE GASKETS. STEPS WERE TAKEN
TO PROVIDE A MORE POSITIVE SEAL OF THE AIR CHAMBER.

*AIR + *CHEMICAL REACTION + *SODIUM + *TEST, BENCH + ANL (ARGONNE NATIONAL LABORATORY) +
FARET (FAST ARGONNE REACTOR EXPERIMENT TEST)

8-11405 JENSEN SE
THE EFFECTS OF METAL WATER REACTIONS ON THE LOSS OF COOLANT ACCIDENT
PHILLIPS PETROLEUM COMPANY
IDO-17168 +. 99 PAGES, 35 FIGURES, 3 TABLES, 36 REFERENCES, AUGUST 1966, CFSTI \$4.00 CY

PHILLIPS UNDERTOOK AN ANALYSIS OF THE POTENTIAL EFFECTS OF ZIRCALOY-4-WATER REACTIONS ON THE
LOSS-OF-COOLANT TEST, BASED ON THE RATE-LIMITING MECHANISMS WHICH CONTROL THE REACTION AND
THE CALCULATION OF THE RATE AND EXTENT OF THE REACTION AS FUNCTIONS OF SPACE AND TIME. THE
RATE-LIMITING PHENOMENA, PARTICULARLY STEAM AVAILABILITY, TEND TO REDUCE THE RATE AT WHICH
THE REACTION CAN OCCUR, THUS SPREADING THE REACTION AND ITS ASSOCIATED ENERGY RELEASE OVER A
LONGER TIME. BECAUSE OF ITS FUNDAMENTAL BASIS, THE DISCUSSIONS HAVE BEEN KEPT GENERAL IN
NATURE, AND VARIOUS SITUATIONS NOT DIRECTLY RELATED TO LOFT ARE EXAMINED.

*ACCIDENT ANALYSIS + *LOSS OF COOLANT + *METAL WATER REACTION + LOFT (LOSS OF FLUID TEST) +
NRTS (NATIONAL REACTOR TEST STATION) + ZIRCALOY

8-11412 BAKER L
METAL-WATER REACTIONS
ARGONNE NATIONAL LABORATORY, ARGONNE
10 PAGES, 3 FIGURES, 1 TABLE, NUCLEAR SAFETY 7(1), PAGES 25-34, (FALL 1965)

RECENT ADVANCES IN STUDIES OF REACTION BETWEEN METALS AND WATER ARE REPORTED FOR THE FOLLOWING
REACTOR METALS - URANIUM, ZIRCONIUM, STAINLESS STEEL, AND ALUMINUM. THE INFORMATION GATHERED
FROM THESE STUDIES IS USED FOR ANALYSES OF TWO PRINCIPAL TYPES OF MAXIMUM ACCIDENTS THAT
COULD POSSIBLY OCCUR IN WATER-COOLED REACTORS. FOR REACTOR-EXCURSION ACCIDENTS, THERE IS
GOOD AGREEMENT BETWEEN THE THEORETICAL AND OBSERVED REACTION ENERGIES FOR BOTH THE SL-1
ACCIDENT AND THE FINAL DESTRUCTIVE TEST OF THE SPERT-ID CORE. FOR LOSS-OF-COOLANT ACCIDENTS,
DETAILED CALCULATIONS PREDICT THE NATURE AND TIMING OF FAILURE OF ZIRCALOY-CLAD FUEL ELEMENTS
IN THE PROPOSED LOFT REACTOR FOLLOWING BLOWDOWN.

*ACCIDENT ANALYSIS + *ACCIDENT, REACTIVITY + *LOSS OF COOLANT + *METAL WATER REACTION + ALUMINUM +
INCIDENT, SL-1 + SPERT 1 (SPECIAL POWER EXCURSION REACTOR TEST) + STEEL, STAINLESS + URANIUM + ZIRCONIUM

8-11413 SKARPELOS JM
CHEMISTRY OF ESADE-VBWR NUCLEAR SUPERHEAT LOOP
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
GEAP-4813 +. 38 PAGES, FEBRUARY 1964, CFSTI, \$2.00 CY, \$0.50 MN

THE CHEMISTRY PROGRAM ASSOCIATED WITH THE ESADE-VBWR NUCLEAR SUPER
HEAT LOOP WAS CARRIED ON WITH THE PRIMARY PURPOSE OF DETECTING THE
FAILURE OF FUEL CLADDING AND MEASURING THE FISSION-PRODUCT RELEASE
RATE. TO ACCOMPLISH THIS OBJECTIVE, NOBLE-GAS FISSION PRODUCTS

CATEGORY 8
SOURCES OF ENERGY RELEASE UNDER ACCIDENT CONDITIONS

8-11413 *CONTINUED*

AND RADIOIODINES WERE MONITORED IN THE LOOP INLET AND OUTLET STEAM RADIOCHEMISTRY MEASUREMENTS MADE DURING IRRADIATION GAVE NO INDICATION OF DEFECTIVE FUEL. RESULTS AFTER SIPPING THE FUEL BUNDLE AT THE COMPLETION OF THE IRRADIATION INDICATED THAT A FUEL ELEMENT MIGHT HAVE BEEN DEFECTIVE. HOWEVER, THE SIGNAL WAS SUFFICIENTLY WEAK THAT IF A DEFECT WERE PRESENT IT WAS VERY SMALL. PROBLEMS ASSOCIATED WITH STEAM SAMPLING DID NOT DETRACT FROM THE MAJOR OBJECTIVE, WHICH WAS TO DETERMINE OPERATING LIMITS FOR SUPERHEAT FUEL ELEMENTS OF INTEREST.

*CHEMICAL REACTION + *FAILURE, FUEL ELEMENT + *VBWR (VALLECITOS BOILING WATER REACTOR) + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

8-11493 HANSEL JG + ZWILLENBERG M + MELLOR AM + SULLIVAN HF + GLASSMAN I
FIRST ANNUAL PROGRESS REPORT ON THE COMBUSTION OF METALS, JULY 1, 1964 - JUNE 30, 1965
PRINCETON UNIVERSITY
SC-DC-65-1691 +. 38 PAGES, AUGUST 1965, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT SUMMARIZES RESEARCH CONCERNING METAL COMBUSTION PERFORMED FOR SANDIA CORPORATION IN THE DEPARTMENT OF AEROSPACE AND MECHANICAL SCIENCES AT PRINCETON UNIVERSITY DURING THE PERIOD JULY 1964 THROUGH JUNE 1965. THE COMBUSTION OF RESISTIVELY HEATED METAL WIRES OR STRIPS WAS EXAMINED IN A CONTROLLED-ATMOSPHERE CHAMBER CAPABLE OF OPERATING AT ELEVATED OR REDUCED PRESSURES. METALS THAT BURN PRIMARILY AT THE SURFACE, SUCH AS TANTALUM, MOLYBDENUM, AND ZIRCONIUM, AND METALS THAT BURN PRIMARILY IN THE VAPOR PHASE, SUCH AS CALCIUM AND MAGNESIUM, WERE STUDIED. VARIOUS GASEOUS ATMOSPHERES WERE USED, THE COMPONENTS OF WHICH WERE OXYGEN, NITROGEN, CARBON DIOXIDE, WATER VAPOR, AND ARGON. RESULTS ARE INTERPRETED IN TERMS OF THE GLASSMAN HYPOTHESIS FOR METAL BURNING. PRELIMINARY EXPERIMENTATION ON THE DETERMINATION OF METAL FLAME TEMPERATURES AND OF IGNITION PROCESSES ON A FLAT-FLAME BURNER IS DISCUSSED.

*COMBUSTION + *METAL + AEROSPACE SAFETY + IGNITION

8-12020 TREIMAN M
BIBLIOGRAPHY ON KINETICS OF THE OXIDATION-REDUCTION REACTIONS OF URANIUM, NEPTUNIUM, PLUTONIUM, AND AMERICIUM IN SOLUTION
LOS ALAMOS SCIENTIFIC LABORATORY, UNIVERSITY OF CALIFORNIA, LOS ALAMOS, NEW MEXICO
LA-3507-MS +. 12 PAGES, MARCH 9, 1966, CFSTI \$1.00 CY, \$0.50 MN

THIS BIBLIOGRAPHY CONSISTS OF JOURNAL ARTICLES AND UNCLASSIFIED REPORTS WHICH WERE ABSTRACTED IN NUCLEAR SCIENCE ABSTRACTS FROM 1958 TO 1966. THE REFERENCES ARE LISTED NUMERICALLY BY NSA ABSTRACT NUMBER, WITH THE EARLIEST WORK APPEARING FIRST.

*AMERICIUM + *BIBLIOGRAPHY + *CHEMICAL KINETICS + *OXIDATION + *PLUTONIUM + *REDUCTION + *URANIUM + *WATER, GENERAL + NEPTUNIUM

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-07749 BRINKMAN DS + PEKRUL PJ
AUTOMATIC STARTUP AND OPERATION OF SNAP-10A FLIGHT SYSTEM IN A SIMULATED SPACE ENVIRONMENT
ATOMICS INTERNATIONAL
2 PAGES, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 43-44

SNAP 10A HAS OPERATED ON THE GROUND FOR SEVERAL MONTHS, SELF-CONTROLLED, AFTER AN AUTOMATIC
STARTUP.

OPERATING EXPERIENCE + REACTOR, SPACE + SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER)

9-07757 EPLER EP
SAFETY SYSTEM PERFORMANCE FAILURES
OAK RIDGE NATIONAL LABORATORY
2 PAGES, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 49-50

IN 20 YEARS, ABOUT 20 MAJOR INCIDENTS HAVE OCCURRED, TEN WHICH WOULD NOT HAVE OCCURRED HAD
SAFETY SYSTEM OPERATED CORRECTLY. THESE FAILURES WERE DUE TO DESIGN ERRORS IN WHICH DELAY,
LACK OF INPUT INFORMATION, OR PARALYZED SYSTEM PREVENTED SCRAM. DESPITE THE FACT THAT NO
SAFETY-SYSTEM-COMPONENT FAILURE RESULTED IN AN EXCURSION, SYSTEMS ARE BEING BUILT WITH
AUTOMATIC TESTING TO DETERMINE (AMPLIFIER) COMPONENT FAILURE. IF SAFETY SYSTEMS HAD BEEN
TESTED JUST ONCE UNDER ACCIDENT CONDITIONS, PROBABLY ALL UNCONTROLLED EXCURSIONS TO DATE
COULD HAVE BEEN PREVENTED.

*FAILURE, SCRAM MECHANISM + *OPERATING EXPERIENCE + *REACTOR SAFETY SYSTEM + EXCURSION, LARGE

9-07758 ROSS CP
PERFORMANCE OF HWCTR SAFETY SYSTEMS
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
25 PAGES, 10 FIGURES, 7 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 50

FOUR OF THE SIX ZIRCALOY ROD GUIDES FAILED AFTER 3 YEARS OF SERVICE, BY LONGITUDINAL SPLITS IN
THE SHOCK-ABSORBER SECTION. FAILURE WAS DETECTED BY SHORTER ROD-DROP TIMES. IT MIGHT HAVE
BEEN POSSIBLE TO DROP ROD ON A SPLIT, NOT ALL INTO CORE. TWICE A ROD FAILED TO DROP, DUE TO
A CRACKED OVERRUNNING CAM CLUTCH. BORON INJECTION (BY SEPARATE HELIUM SUPPLY) WOULD NOT WORK
IN CERTAIN PRESSURE AND FLOW SITUATIONS, SOLVED BY USING REACTOR COVER-GAS TO PRESSURIZE
SYSTEM. GAS-RELIEF VALVES WERE CHANGED TO LIQUID-RELIEF VALVES, AS CODE CHANGED, TO PREVENT
A VALVE FAILURE FROM RAPIDLY DEPRESSURIZING REACTOR. STEEL-DOME CONTAINMENT ON CONCRETE
BELOW COULD NOT ACHIEVE LEAKAGE LESS THAN 2-3 PERCENT PFR DAY AT 24 PSIG.

*FAILURE, SCRAM MECHANISM + *MODIFICATION, SYSTEM OR EQUIPMENT + *OPERATING EXPERIENCE +
*SAFETY INJECTION + *TEST, LEAK RATE + *VALVE + CONTAINMENT, LOW PRESSURE +
HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER +
REACTOR, TEST + STRESS

9-07760 PANCOAST JT
A GRAVITY INDEPENDENT REACTOR CONTROL SYSTEM
GENERAL DYNAMICS, FORT WORTH, TEXAS
3 PAGES, 3 FIGURES, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 51-53

REFLECTOR-POISON CYLINDERS ARE ROTATED BY RACK AND PINION DRIVES, OPERATED BY ELECTRIC MOTORS,
REGARDLESS OF REACTOR ORIENTATION.

*CONTROL ROD DRIVE + *REFLECTOR + REACTOR, RESEARCH

9-07761 EDWARDS DR
EXPERIENCE WITH ROD DROP TIMES AT THE UMRR
UNIVERSITY OF MISSOURI, ROLLA, MISSOURI
1 PAGE, 1 TABLE, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 53

ROD-DROP-TIME MEASUREMENTS TAKEN AT SIX-MONTH INTERVALS FAILED TO SHOW INCIPIENT FAILURE.
WATER LEAKED INTO THE 304 STAINLESS-STEEL ROD FILLED WITH B4C AND CADMIUM THROUGH THE SEAL
PLUG, AND DECOMPOSED. A ROD, SWOLLEN BY 8.6 PERCENT, JAMMED ON STARTUP AND FAILED TO DROP.
THE OTHER TWO RODS ALSO HAD SWOLLEN. BORON-STAINLESS-STEEL RODS, HAVING 80 PERCENT
EFFECTIVENESS OF OLD RODS, ARE REPLACEMENTS.

*CONTROL ROD + *FAILURE, SCRAM MECHANISM + *RADIOLYTIC GAS + INCIDENT, ACTUAL, GENERAL + REACTOR, POOL TYPE

9-07762 GIMMY KL + FIELD FR
ON-LINE COMPUTER ASSISTS REACTOR OPERATION AT SAVANNAH RIVER PLANT
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
2 PAGES, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 53-54

AT K REACTOR, SIGNALS FROM 3200 FLOW, PRESSURE, FLUX MONITORS, AND THERMOCOUPLES PROVIDE POWER
AND FLUX INFORMATION. USES ARE - DIRECT SURVEILLANCE OF INDIVIDUAL OPERATING LIMITS,

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-07762 *CONTINUED*

CALCULATION OF DERIVED LIMITS (SUCH AS BURNOUT SAFETY FACTOR) ON DEMAND, PREPARING HISTOGRAMS FOR OPERATORS TO ADJUST RADIAL POWER, ROUTINE DATA COLLECTION.

*COMPUTER, DIGITAL + *CONTROL, COMPUTER + OPERATING EXPERIENCE + REACTOR, HEAVY WATER + SAVANNAH RIVER PLANT

9-07763 OCCHIPINTI ES + MIX PE + STUTHEIT JS + FIELD FR
ANALOG COMPUTER SIMPLIFIES OPERATION OF SAVANNAH RIVER HIGH FLUX CHARGE
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
2 PAGES, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 54-55

DURING A RECENT SPECIAL HIGH-FLUX RUN, THE POWER DENSITY WAS CONTROLLED BY USING A DIRECT READOUT DISPLAY OF THE BURNOUT SAFETY FACTOR. GAMMA THERMOMETERS YIELDED THE FLUX DISTRIBUTION, WHILE COOLANT-FLOW CONDITIONS WERE MANUALLY ADJUSTABLE INPUTS. THIS CONSIDERABLY SHORTENS HAND COMPUTATIONS.

*COMPUTER, ANALOG + *CONTROL, COMPUTER + BURNOUT HEAT FLUX + REACTOR, HEAVY WATER + SAVANNAH RIVER PLANT

9-09578 ROHRBACHER RA
SAMPLE AND CONTROL FOR FAST DETECTION OF FUEL FAILURE IN A PRESSURIZED WATER REACTOR
HANFORD ATOMIC PRODUCTS OPERATION
CONF-701-3 +. 12 PAGES, 5 FIGURES, INSTRUMENT SOCIETY OF AMERICA 19TH ANNUAL INSTRUMENT AUTOMATION CONFERENCE AND EXHIBIT, NEW YORK, OCTOBER 12-15, 1964, SOURCE

DETECTION AND LOCATION OF FUEL ELEMENT FAILURES IN 1004 PROCESS TUBES OF THE NEW PRODUCTION REACTOR AT HANFORD REQUIRE A UNIQUE SAMPLING SYSTEM. THE SYSTEM CONTINUOUSLY DELIVERS AND CONTROLS THE TRANSIT TIME OF REACTOR COOLANT SAMPLES FROM EACH PROCESS TUBE. THE SAMPLES ARE MONITORED CONTINUOUSLY BY G-M TUBES AND PERIODICALLY BY SCINTILLATION COUNTERS. FAILURES MUST BE DETECTED PROMPTLY TO PREVENT POSSIBLE UNSAFE OPERATION OF THE REACTOR AND GROSS CONTAMINATION OF THE COOLANT. THE SYSTEM AUTOMATICALLY COMPENSATES FOR CHANGES IN REACTOR POWER LEVEL AND COOLANT PRESSURE, AND FOR RADIOACTIVE CRUD BURSTS. SAMPLE TRANSIT TIME (RADIOACTIVE DECAY TIME) IS ADJUSTABLE AND CAN BE PRESET TO THE OPTIMUM VALUE.

*FAILURE, FUEL ELEMENT + *HANFORD SITE + *INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + *MONITOR, RADIATION, SAMPLING + *SAMPLING

9-09716 ROBINSON LE + PURVANCE RT + WILLIS FL + SCHILTZ RJ + MONAWECK JH + DE VOLPI A + FREESE CH
PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 22 PAGES, TABLES, FIGURES, REFERENCES, DECEMBER 1965, SECTIONS IV-14 THROUGH IV-18, PP. 268-290, CFSTI, \$7.22 CY, \$2.00 MN

MODIFICATION OF THE TREAT SMALL INTEGRAL SODIUM LOOPS, THEIR LOADING AND REMOTE HANDLING, PRESSURE TRANSDUCERS, REMOTE ENCAPSULATION OF PREIRRADIATED FUEL ELEMENTS FOR EXPOSURE IN TREAT, AND FAST-NEUTRON TRANSIENT DETECTION MODOSCOPE FOR MELTDOWN STUDIES ARE DISCUSSED IN THESE ARTICLES.

*IN PILE LOOP + *TREAT (TRANSIENT TEST REACTOR FACILITY) + FAILURE, FUEL ELEMENT + IN PILE EXPERIMENT + REACTOR, GRAPHITE MODERATED + REACTOR, TEST + REMOTE MANIPULATING AND VIEWING + SODIUM

9-09717 PORGES KG
DESIGN IMPROVEMENTS AND SENSITIVITY TESTS OF THE FERD SYSTEM FOR EBR-II. PHYSICS DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965
ARGONNE NATIONAL LABORATORY
ANL-7110 +. 2 PAGES, 1 FIGURE, 2 REFERENCES, DECEMBER 1965, SECTION IV-22, PP. 294-295, CFSTI, \$7.22 CY, \$2.00 MN.

THE FUEL ELEMENT RUPTURE DETECTOR (FERD), NOW INSTALLED IN EBR-II, HAS ALREADY BEEN DESCRIBED IN GENERAL OUTLINE. IN THIS REPORT, A BRIEF ACCOUNT IS GIVEN OF THE ACCRUED MAINTENANCE EXPERIENCE WHICH LED TO CERTAIN IMPROVEMENTS AS WELL AS OF A RECENT TEST TO WHICH THE FERD SYSTEM AND CONFIRMING CHARGED-WIRE DETECTOR WERE SUBJECTED. (K. G. PORGES, EBR-II FUEL ELEMENT FAILURE DETECTOR, REACTOR PHYSICS DIVISION ANNUAL REPORT JULY 1, 1963 TO JUNE 30, 1964, ANL-7010 (1965), P. 231).

*EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + *INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

9-09801 BRIGGS NH + MCELROY DL
HIGH-TEMPERATURE THERMOMETRY WORK AT THE OAK RIDGE NATIONAL LABORATORY
OAK RIDGE NATIONAL LABORATORY
122 PAGES, 54 FIGURES, 22 TABLES, 20 REFERENCES, HIGH-TEMPERATURE THERMOMETRY MEETING, AEC HEADQUARTERS, WASHINGTON, D.C., FEBRUARY 24-26, 1965

A COLLECTION OF OAK RIDGE NATIONAL LABORATORY PAPERS PRESENTED AT THE AEC HIGH-TEMPERATURE THERMOMETRY MEETING, FEBRUARY 24-26, 1965. THE PAPERS INCLUDE - SUMMARY OF EXPERIENCE WITH HIGH-TEMPERATURE THERMOCOUPLES USED IN ORNL-GCR PROGRAM FUEL-IRRADIATION EXPERIMENTS, TEMPERATURE REFERENCE STANDARD FOR THE OAK RIDGE NATIONAL LABORATORY, THERMAL EMF DRIFT OF HIGH-TEMPERATURE THERMOCOUPLES IN HELIUM AND ARGON, THERMAL EMF DRIFT OF REFRACTORY METAL

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-09801 *CONTINUED*

THERMOCOUPLES IN PURE AND SLIGHTLY CONTAMINATED HELIUM ATMOSPHERES, HIGH-TEMPERATURE HIGH-VACUUM THERMOCOUPLE-DRIFT TESTS, INFLUENCE OF CO-CO₂ ENVIRONMENTS ON THE CALIBRATION OF CHROMEL-P/ALUMEL THERMOCOUPLES, CONTAMINATION OF PLATINUM-RHODIUM TRANSDUCERS, EFFECT OF COLD WORKING ON PT 90-RH 10 THERMOCOUPLES, A CONSTANT-POWER ANNEALING FURNACE, SPECIFICATIONS FOR SHEATHED HIGH-TEMPERATURE THERMOCOUPLES, DYNAMIC GAS THERMOMETRY.

*HIGH TEMPERATURE + *INSTRUMENTATION, TEMPERATURE + *MEASUREMENT, TEMPERATURE +
*ORNL (OAK RIDGE NATIONAL LABORATORY) + ARGON + CARBON DIOXIDE + CARBON MONOXIDE + HELIUM

9-09865 NUCLEAR INSTRUMENTATION - A GENERAL SURVEY
5 PAGES, FIGURES, EURONUCLEAR, 2(10), PP. 481-485 (OCTOBER 1965)

GENERAL SURVEY OF TRENDS IN NUCLEAR INSTRUMENTATION. CONTROLS AND INSTRUMENTATION MAKE UP ABOUT 5 PERCENT OF THE COST OF NUCLEAR POWER PLANTS. NEUTRON-FLUX INSTRUMENTATION IS RATHER STANDARDIZED EXCEPT FOR THE MOVING DETECTOR SYSTEM. ANALYSIS OF THE GAS IS IMPORTANT IN GAS-COOLED REACTORS. A HEALTH-PHYSICS MONITORING INSTRUMENT SENSITIVE TO X- OR GAMMA-RAYS AND/OR TO SLOW AND FAST NEUTRONS HAS BEEN DEVELOPED IN GERMANY. IT HAS NO BATTERIES OR POWER SUPPLY. OTHER SELECTED TOPICS ARE DISCUSSED, INCLUDING A MENTION OF A CERAMIC END-WINDOW IN BF₃ DETECTOR, THE USE OF SOLID-STATE DEVICES IN LOW-LEVEL AMPLIFIERS, THE ADVANTAGES OF MODULAR CONSTRUCTION OF ELECTRONICS, THE ADVANTAGES OF AUTOMATION IN EXPERIMENTS, AND THE USE OF RADIOISOTOPES IN MEASURING AND DETECTING INSTRUMENTS.

*INSTRUMENTATION, GENERAL + INSTRUMENTATION, AMPLIFIER + INSTRUMENTATION, NUCLEAR +
INSTRUMENTATION, PROCESS + INSTRUMENTATION, RADIATION MONITORING

9-09866 WESTHEAD JM
THE COMPUTER ALARM, MONITORING, LOGGING AND ANALYSIS SYSTEM FOR OLDBURY NUCLEAR POWER STATION
AEI AUTOMATION LIMITED
4 PAGES, 7 FIGURES, EURONUCLEAR, 2(10), PP. 489-492 (OCTOBER 1965)

THE COMPUTER ELIMINATES THE NEED FOR CONVENTIONAL ANNUNCIATORS ON 2700 ALARM CONTACTS. IT SCANS THE CONTACTS FOUR TIMES A SECOND, ANALYZING ANY ALARMING SITUATION ACCORDING TO PROGRAMMED ALARM INTERACTIONS, AND DISPLAYS THE ANALYSIS ON CATHODE-RAY TUBES. THE DISPLAY CONTAINS WORDS AND DIGITS DESCRIBING THE CAUSE OF THE TROUBLE. UNINFORMATIVE DEPENDENT ALARMS ARE NOT DISPLAYED. SIGNALS ARE TAKEN FROM THE TEMPERATURE-MONITORING THERMOCOUPLES, THE BURST-CARTRIDGE-DETECTION EQUIPMENT, AND FROM STATION EQUIPMENT.

*COMPUTER, DIGITAL + *INSTRUMENTATION, SURVEILLANCE + *MONITORING SYSTEM

9-09915 PERSIANI PJ + BUMP TR + KANN WJ
FARET CORE 1 FUEL IRRADIATION PROGRAM AND REFERENCE DESIGN
ARGONNE NATIONAL LABORATORY
ANL-7106 +. 22 PAGES, 5 FIGURES, 9 TABLES, 6 REFERENCES, OCTOBER, 1965, CFSTI, \$2.00 CY, \$0.50 MN

A SERIES OF CRITICAL EXPERIMENTS WAS MADE TO CONFIRM THE PHYSICS ANALYSIS OF MULTIFUELED, NONUNIFORM CORE LOADINGS. MEASUREMENTS OF THE REACTIVITY OF 12 CONTROL RODS WERE COMPARED WITH CALCULATED VALUES FOR TWO BORON-10 ENRICHMENTS IN THE BORON CARBIDE CONTROL RODS.

*CONTROL ROD WORTH + *CRITICALITY EXPERIMENT + FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) +
MEASUREMENT, REACTIVITY + REACTOR, FAST

9-09943 INSTRUMENT FAILURES
ARGONNE NATIONAL LABORATORY
ANL-6849 +. 11 PAGES, NOVEMBER, 1964, PAGES 91-101 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

SEVERAL FAILURES OCCURRED DURING THE EXPERIMENTS WITH CORE B-2 FOR BORAX-V. THE LOW-STEAM-FLOW SCRAM CIRCUIT FAILED TO OPERATE DURING A TEST BECAUSE OF DIRT IN THE STEAM LINES AND UNSATISFACTORY VENTING OF THE DIFFERENTIAL-PRESSURE CELL. PERIOD CIRCUITS WERE MODIFIED AFTER AN EXCESSIVE NUMBER OF SPURIOUS SCRAMS. THE IN-REACTOR-VESSEL INSTRUMENTATION FAILED TO OPERATE. THE BORON POISONING SYSTEM HAD TROUBLE WITH PIPE-LINE PLUGGING, AND PRECIPITATION AND PLATEOUT OF BORIC ACID.

*FAILURE, GENERAL + *FAILURE, INSTRUMENT + *SAFETY INJECTION +
BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + INSTRUMENTATION, IN CORE + INSTRUMENTATION, PROTECTIVE +
PERIOD METER + POISON, SOLUBLE + REACTOR, BOILING WATER

9-09944 POWER-DISTRIBUTION MEASUREMENTS. TRANSFER-FUNCTION MEASUREMENTS AND STABILITY ANALYSIS
ARGONNE NATIONAL LABORATORY
ANL-6849 +. 39 PAGES, 28 FIGURES, 1 TABLE, NOVEMBER, 1964, PAGES 35-50, 66-90 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

A VERY EXTENSIVE SET OF EXPERIMENTS WERE PERFORMED ON THE B-2 CORE FOR BORAX-V. POWER MAPPING WITH REMOVABLE FUEL RODS, AGREED WITH FLUX-SCANNING WIRE METHODS. A ROD OSCILLATOR AND ANALOG CROSS-CORRELATION EQUIPMENT WERE USED TO MEASURE THE REACTOR TRANSFER FUNCTIONS FOR POWERS UP TO 16 MW. THE MEASUREMENTS AGREED WITH THE THEORETICAL MODEL AND WERE USED IN STABILITY STUDIES THAT INDICATED THAT THE REACTOR WAS VERY STABLE UP TO 16 MW, AND THE TRENDS SUGGESTED A POWER-LEVEL INSTABILITY IN THE REGION OF 30 TO 40 MW. MEASUREMENTS AND DESCRIBING FUNCTION CALCULATIONS INDICATED THAT THE TRANSFER FUNCTIONS WERE NOT DISTORTED

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-09944 *CONTINUED*

SIGNIFICANTLY BY THE NONLINEARITIES CAUSED BY LARGE REACTIVITY DISTURBANCES OR CHANGES IN POWER LEVEL. NOISE-ANALYSIS EXPERIMENTS WERE NOT CONCLUSIVE.

*ANALYTICAL MODEL + *COMPARISON, THEORY AND EXPERIENCE + *REACTOR STABILITY + *TEST, PLANT RESPONSE + *TRANSFER FUNCTION + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + COMPUTER, DIGITAL + MEASUREMENT, GENERAL + NOISE ANALYSIS + OPERATING EXPERIENCE + REACTOR, BOILING WATER

9-10014 KEIL RW + SHEINBER H

FABRICATION AND PROPERTIES OF COPPER - BORON CARBIDE CONTROL MATERIAL FOR PHOEBUS II REACTOR
LOS ALAMOS SCIENTIFIC LABORATORY, NEW MEXICO
LA-DC-7745 +. 10 PAGES, 1 TABLE, 4 FIGURES, MARCH 17, 1966, CFSTI \$1.00 CY, \$0.50 MN

THE FABRICATION AND TESTING OF THE MECHANICAL, CHEMICAL, METALLURGICAL, THERMAL, AND NUCLEAR PROPERTIES OF THE CONTROL RODS FOR THE PHOEBUS II REACTOR ARE DESCRIBED. THE RODS ARE BORON CARBIDE IN A COPPER MATRIX.

*CONTROL ROD FABRICATION + BORON + CARBIDE + COPPER + REACTOR, SPACE + TESTING

9-10136 LENK PA + MCCREARY JC

RECOMMENDATIONS FOR IMPROVEMENT OF THE PM-TYPE REACTOR INSTRUMENTATION. FINAL REPORT
BAILEY METER COMPANY, WICKLIFFE, OHIO
NYO-3379-3 +. 199 PAGES, FEBRUARY 28, 1966, CFSTI, \$5.00 CY, \$1.25 MN

TWO PROPOSALS ARE PRESENTED FOR IMPROVING THE INSTRUMENTATION SYSTEMS FOR THE PM-TYPE POWER PLANTS. THE FIRST PROPOSAL IS A COMPLETE REDESIGN OF THE SYSTEM TO MEET THE REQUIREMENTS DEVELOPED IN AN EARLIER REPORT (NYO-3379-1). THE SECOND APPROACH IS TO MODIFY EXISTING EQUIPMENT IN AREAS THAT HAVE GIVEN DIFFICULTY, AS OUTLINED IN AN EARLIER REPORT ON OPERATING EXPERIENCE (NYO-3379-2). THE SECOND APPROACH IS RECOMMENDED FOR THE PM-1 AND PM-3A PLANTS. COST ESTIMATES ARE MADE FOR THE TWO APPROACHES.

*DESIGN CRITERIA + *MODIFICATION, SYSTEM OR EQUIPMENT + *PM 3A (PORTABLE MEDIUM NUCLEAR POWER PLANT) + *REACTOR, ARMY + INSTRUMENTATION, CONTROL + INSTRUMENTATION, NUCLEAR + INSTRUMENTATION, PROTECTIVE + INSTRUMENTATION, TESTING + PLANT PROTECTIVE SYSTEM + PM 1 (PORTABLE MEDIUM NUCLEAR POWER PLANT) + REACTOR, PRESSURIZED WATER

9-10139 KIRN FS + LOEWENSTEIN WB

EBR-II WET CRITICAL EXPERIMENTS
ARGONNE NATIONAL LABORATORY
ANL-6864 +. 46 PAGES, 15 TABLES, 25 FIGURES, OCTOBER 1964, CFSTI, \$2.00 CY

WET-CRITICAL EXPERIMENTS WERE PERFORMED IN THE EBR-II WITH SODIUM COOLANT IN THE REACTOR SYSTEM. MEASUREMENTS INCLUDED CONTROL-ROD WORTH, NEUTRON-SOURCE STRENGTH, NUCLEAR-INSTRUMENT RESPONSE, CRITICAL SIZE, ISOTHERMAL TEMPERATURE COEFFICIENT, AND REACTIVITY WORTH OF THE SODIUM COOLANT. THE MEASUREMENTS AGREED WELL WITH CALCULATED VALUES AND WITH VALUES EXTRAPOLATED FROM THE DRY CRITICAL EXPERIMENTS AND THE ZERO-POWER MOCKUP.

*CONTROL ROD CALIBRATION + *CRITICALITY EXPERIMENT + *EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + CONTROL ROD WORTH + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY + REACTOR STARTUP EXPERIENCE, INITIAL + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED + SOURCE, NEUTRON + TEMPERATURE COEFFICIENT

9-10143 BLUESTEIN I + MATTY TC + SCHULTZ MA

SHUTDOWN REACTIVITY METER DEVELOPMENT. PHASE II. OPERATION IN HIGH GAMMA FIELDS
MILLETRON, INC., IRWIN, PA.
NYO-3122-35 +. 109 PAGES, DECEMBER 31, 1965, CFSTI, \$4.00 CY, \$0.75 MN

TWO APPROACHES FOR USING CONVENTIONAL NEUTRON DETECTORS AND ELECTRONIC APPARATUS FOR SHUTDOWN-REACTIVITY MEASUREMENTS ON POWER REACTORS, USING NOISE-MEASUREMENT TECHNIQUES, ARE OUTLINED. A NARROW-BAND SYSTEM HAVING THE ADVANTAGE OF SIMPLICITY BUT ONLY MODERATE GAMMA REJECTION IS DESCRIBED, AS IS A COMPLEX WIDE-BAND MULTIPLE DETECTOR SYSTEM HAVING EXCELLENT THEORETICAL NEUTRON-TO-GAMMA DISCRIMINATION. THE APPROACH FINALLY USED IS A NARROW BAND, ONE THAT EMPLOYS A NEW MULTIPLE ELEMENT DETECTOR. A COMPLETE SHUTDOWN-REACTIVITY-MONITORING SYSTEM IS PRESENTED, AND THE RESULTS OF PRELIMINARY TESTS WITH THE SYSTEM AT THE B AND W TEST REACTOR ARE GIVEN. THE TESTS PROVE THE GENERAL FEASIBILITY OF THE PRINCIPLE AND EQUIPMENT, BUT BECAUSE OF AN UNTIMELY FAILURE IN THE NEW DETECTOR, ULTIMATE APPLICATION TO ACTUAL REACTOR PROBLEMS HAS NOT YET BEEN DEMONSTRATED.

*COMPARISON, THEORY AND EXPERIENCE + *MEASUREMENT, REACTIVITY + *NOISE ANALYSIS + *REACTOR, TEST + *TEST, SYSTEM OPERABILITY + INSTRUMENTATION, NUCLEAR + MEASUREMENT, SUBCRITICALITY + TRANSFER FUNCTION

9-10144 FRY DN + ROUX DP + RICKER CW + STEPHENSON SE + HANAUER SH + TRINKO JR

NEUTRON FLUCTUATION MEASUREMENTS AT OAK RIDGE NATIONAL LABORATORY
OAK RIDGE NATIONAL LABORATORY
ORNL-P-1967 + CONF-660206-2 +. 18 PAGES, 1966, SYMPOSIUM ON NEUTRON NOISE, WAVES, AND PULSE PROPAGATION, GAINESVILLE, FLORIDA, CFSTI, \$1.00 CY, \$0.50 MN

REVIEW OF NEUTRON POWER SPECTRAL-DENSITY MEASUREMENTS AT ORNL. NOISE-SPECTRA MEASUREMENTS IN THE MOLTEN-SALT REACTOR EXPERIMENT WERE USED TO DETERMINE THE CHANGE IN THE DELAYED-NEUTRON FRACTION FOR CIRCULATING AND NONCIRCULATING FUEL. NOISE-SPECTRA MEASUREMENTS OF THE FIRST

ACCESSION NUMBER 9-09944 TO 9-10144

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10144 *CONTINUED*

HIGH FLUX ISOTOPE REACTOR CORE WERE USED TO DETERMINE ITS REACTIVITY. THE METHOD GAVE GOOD RESOLUTION AND WILL BE USED TO DETECT CHANGES IN WORTH OF SUCCESSIVE CORES. EXPERIMENTS IN THE OAK RIDGE RESEARCH REACTOR INDICATED THAT NOISE-SPECTRA MEASUREMENTS WOULD NOT BE USEFUL TO DETECT THE ONSET OF NUCLEATE BOILING. PULSE-TYPE DETECTORS WERE USED IN MEASUREMENTS AT THE POOL CRITICAL ASSEMBLY AS THE FIRST STEP IN A PROGRAM TO MEASURE SHUTDOWN REACTIVITY IN THE PRESENCE OF GAMMA RADIATION.

*HFIR (HIGH FLUX ISOTOPE REACTOR) + *MEASUREMENT, NOISE + *MSRE (MOLTEN SALT REACTOR EXPERIMENT) + *ORR (OAK RIDGE RESEARCH REACTOR) + *REACTOR, HIGH FLUX + *REACTOR, MOLTEN SALT + *REACTOR, RESEARCH + *REACTOR, TEST + DELAYED NEUTRON + MEASUREMENT, REACTIVITY + MEASUREMENT, SUBCRITICALITY + NOISE ANALYSIS + NUCLEATE BOILING + TRANSFER FUNCTION

9-10146 EASTMAN R + GALLAGHER JM
RADIATION MONITORING--AN INSTRUMENTATION SYSTEM FOR CONTROL OF RADIATION HAZARDS
WESTINGHOUSE ATOMIC POWER DIVISION, PITTSBURGH, PA.
7 PAGES, 1 FIGURE, 9 REFERENCES, IEEE TRANS. ON NUCLEAR SCIENCE, 12(6), PP. 15-21 (DECEMBER, 1965)

A BRIEF AND SOMEWHAT ELEMENTARY REVIEW OF THE REQUIREMENTS FOR RADIATION-MONITORING SYSTEMS USED IN NUCLEAR POWER PLANTS.

*INSTRUMENTATION, RADIATION MONITORING + *RADIATION SAFETY AND CONTROL + MEASUREMENT, GENERAL + RADIATION UNIT

9-10147 FORSTER JJ
IN-CORE NEUTRON FLUX INSTRUMENTATION
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
7 PAGES, 8 FIGURES, 3 TABLES, 11 REFERENCES, IEEE TRANSACTIONS ON NUCLEAR SCIENCE, 12(6), PP. 8-14 (DECEMBER 1965)

SURVEY OF GENERAL ELECTRIC WORK ON IN-CORE NEUTRON MONITORING. MINIATURE MONITORS OF POWER-RANGE FLUX ARE IN ROUTINE USE IN FIVE WATER REACTORS WITH UP TO TWO AND ONE-HALF YEARS OF SERVICE. PRELIMINARY EXPERIMENTS ARE BEING CONDUCTED WITH STARTUP-RANGE AND INTERMEDIATE-RANGE FLUX MONITORS. THE STARTUP-RANGE CHANNELS USE RETRACTABLE FISSION COUNTERS. THE INTERMEDIATE-RANGE CHANNELS USE THE CAMPBELL METHOD OF RELATING FLUX TO THE VARIATION IN CURRENT FROM A FISSION CHAMBER. TRAVERSING IN-CORE PROBES ARE USED TO MEASURE FLUX PROFILES.

*INSTRUMENTATION, IN CORE + CHAMBER, FISSION + CHAMBER, ION + CHAMBER, NEUTRON + INSTRUMENTATION, NUCLEAR

9-10148 HARRER JM
REACTOR CONTROL EXPERIENCE
COMBUSTION ENGINEERING, INC.
7 PAGES, 2 FIGURES, 1 TABLE, 9 REFERENCES, POWER REACTOR TECHNOLOGY, 8(4), PP. 221-227 (FALL 1965)

REVIEW OF PAPERS ON EXPERIENCE WITH CONTROL AND SAFETY SYSTEMS (ANS CONFERENCE ON REACTOR OPERATING EXPERIENCE). NONE OF THE 20 REACTOR ACCIDENTS OR INCIDENTS HAVE RESULTED FROM FAILURE OF SAFETY COMPONENTS BUT RATHER FROM THE SAFETY SYSTEM BEING INHERENTLY UNABLE TO PERFORM CORRECTLY UNDER ACCIDENT CONDITIONS. ROD-DROP-TIME TESTS DID NOT GIVE ANY INDICATION OF SWELLING RODS. A LIQUID-POISON-INJECTION SYSTEM DID NOT FUNCTION UNDER TEST AND HAD TO BE REDESIGNED. OTHER TOPICS - SPRINGS VS PNEUMATIC SYSTEMS FOR ROD DRIVES, MODERATOR CONTROL OF CRITICAL FACILITIES, SUBCRITICAL REACTIVITY MEASUREMENTS, AND ON-LINE DIGITAL COMPUTERS.

*CONTROL SYSTEM + *FAILURE, DESIGN ERROR + *FAILURE, SCRAM MECHANISM + *OPERATING EXPERIENCE + *POISON, SOLUBLE + *REACTOR SAFETY SYSTEM + *REVIEW + *TEST, CONTROL ROD DRIVE + PLANT PROTECTIVE SYSTEM + SAFETY INJECTION + TEST, SYSTEM OPERABILITY

9-10149 GARRICK BJ + GEKLER WC + POMREHN HP
SOME ASPECT OF PROTECTIVE SYSTEMS IN NUCLEAR POWER PLANTS
HOLMES AND NARVER, INC.
9 PAGES, 3 FIGURES, 10 REFERENCES, IEEE TRANSACTIONS ON NUCLEAR SCIENCE, 12(6), PP. 22-30 (DECEMBER, 1965)

A BRIEF REVIEW OF THE HISTORICAL DEVELOPMENT AND THE STATE OF THE ART OF REACTOR PROTECTIVE SYSTEMS IS PRESENTED. TOPICS INCLUDE REASONS FOR REDUNDANCY AND COINCIDENCE, DIFFICULTY IN OBTAINING CHANNEL INDEPENDENCE, COMPONENT RELIABILITY VERSUS SYSTEM DESIGN, SYSTEM TESTING, NEED FOR MORE TESTING WITH TRANSISTORIZED CIRCUITRY, USE OF NOISE MEASUREMENTS, COMPUTER CONTROL, DIFFICULTY IN MEASURING RELIABILITY IN PROTECTIVE SYSTEMS, AND THE DIFFICULTY IN OBTAINING FAILURE-RATE INFORMATION.

*PLANT PROTECTIVE SYSTEM + *REACTOR SAFETY SYSTEM + *RELIABILITY ANALYSIS + *REVIEW + *SAFETY PRINCIPLES AND PHILOSOPHY + INSTRUMENTATION, COINCIDENT + INSTRUMENTATION, REDUNDANT + INSTRUMENTATION, TESTING + OPERATING EXPERIENCE + RELIABILITY, COMPONENT + RELIABILITY, SYSTEM

9-10150 BONYHADY KA
ANALYSIS OF PROCESS CONTROL IN AN SGR 200 MWE PROTOTYPE PLANT
ATOMICS INTERNATIONAL
NAA-SR-MEMO-11339 +. 23 PAGES, JUNE 26, 1965, CFSTI, \$1.00 CY, \$0.50 MN

A STUDY WAS MADE OF METHODS FOR CONTROLLING THE TEMPERATURE OF THE STEAM ENTERING THE TURBINE IN A 200-MWE SGR PLANT USING A ONCE-THROUGH STEAM GENERATOR. THE STEAM TEMPERATURE COULD NOT

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10150 *CONTINUED*

BE CONTROLLED WITH CONTROLLERS BY USING THE UNBALANCE BETWEEN THE TWO SODIUM FLOWS IN THE INTERMEDIATE HEAT EXCHANGER. DESUPERHEATING BETWEEN THE EVAPORATOR AND SUPERHEATER GAVE SATISFACTORY CONTROL. HOWEVER, DESUPERHEATING AT THE SUPERHEATER OUTLET DID NOT. A CONSTANT-TEMPERATURE FEEDWATER PREHEATER IMPROVED THE CONTROL PERFORMANCE.

*CONTROL SYSTEM + *REACTOR, GRAPHITE MODERATED + *REACTOR, LIQUID METAL COOLED + *STEAM + ANALYTICAL MODEL + MATHEMATICAL STUDY

9-10151 WILCOX GE

SOLID STATE NUCLEAR DETECTOR. FINAL REPORT
NAVAL AIR DEVELOPMENT CENTER, JOHNSVILLE, PA.

AD-614432 + NADC-EL-6504 +. 18 PAGES, MARCH 23, 1965, CFSTI, \$1.00 CY, \$0.50 MN

A STUDY WAS UNDERTAKEN TO DETERMINE THE APPLICABILITY OF PHOTOCONDUCTIVE (PC) AND ELECTROLUMINESCENT (EL) MATERIALS TO A SCINTILLATION SYSTEM FOR THE DETECTION AND MEASUREMENT OF NUCLEAR RADIATION. EFFORTS TO AMPLIFY INDIVIDUAL LIGHT FLASHES FROM SCINTILLATION PHOSPHORS BY USING ELPC SANDWICHES AS LIGHT AMPLIFIERS MET WITH LITTLE SUCCESS BECAUSE OF THE SLOW RESPONSE TIME CHARACTERISTIC OF THE PHOTOCONDUCTOR. THIS CHARACTERISTIC, HOWEVER, MADE THE PC ELEMENT A VALUABLE INTEGRATING DEVICE, AND A SIMPLE, RELIABLE, AND ECONOMICAL RATEMETER WAS DEVELOPED AND EVALUATED FOR THE MEASUREMENT OF ALPHA, BETA, GAMMA, AND NEUTRON DOSE RATES OVER A WIDE RANGE OF OPERATION.

*ALPHA EMITTER + *BETA EMITTER + *GAMMA EMITTER + *INSTRUMENTATION, NUCLEAR + *SOLID STATE DEVICE

9-10153 ASPINALL KJ

CRITICALITY DETECTION AND ALARM SYSTEMS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HEALTH AND SAFETY BRANCH

5 PAGES, 1 FIGURE, 5 REFERENCES, NUCLEAR ENGINEERING, 11(118), PP. 184-188 (MARCH, 1966)

A SET OF DESIGN SPECIFICATIONS FOR CRITICALITY DETECTION AND ALARM SYSTEMS IS DEVELOPED. TOPICS INCLUDE THE EFFECT OF EVACUATION ON DOSES RECEIVED, DETECTION THRESHOLDS, RELIABILITY, ALARM SOUND, AND EVACUATION AREAS.

*ACCIDENT, CRITICALITY + *DESIGN CRITERIA + *MONITOR, RADIATION, EMERGENCY + *RADIATION SAFETY AND CONTROL + *RADIOCHEMICAL PLANT SAFETY + MONITOR, RADIATION, PERSONNEL + UNITED KINGDOM

9-10154 EAMES AR

RELIABILITY ASSESSMENT OF PROTECTIVE SYSTEMS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HEALTH AND SAFETY BRANCH, RISLEY

5 PAGES, 5 TABLES, 3 FIGURES, 8 REFERENCES, NUCLEAR ENGINEERING, 11(118), PP. 188-192 (MARCH, 1966)

TWO METHODS ARE DEVELOPED TO NUMERICALLY EVALUATE THE RELIABILITY OF THE COMPONENTS IN A PROTECTIVE SYSTEM. IN THE FIRST A TOTAL FAILURE AND A FAIL-DANGEROUS FAILURE RATE ARE ESTIMATED. IN THE SECOND METHOD, THE FAILURE RATES ARE ESTIMATED FOR SEVERAL CATEGORIES OF FAILURES. AVERAGE FAILURE RATES BASED ON RECORDED DATA ARE TABULATED FOR ELECTRONIC, MECHANICAL, HYDRAULIC, AND PNEUMATIC COMPONENTS. EXAMPLES OF DETAILED ASSESSMENTS ARE GIVEN. SEVERAL COMPARISONS OF PREDICTED FAILURE RATES WITH ACTUAL EXPERIENCE SHOW AGREEMENT WITHIN A FACTOR OF TWO.

*COMPARISON, THEORY AND EXPERIENCE + *PLANT PROTECTIVE SYSTEM + *REACTOR SAFETY SYSTEM + *RELIABILITY ANALYSIS + FAILURE, COMPONENT + RELIABILITY, COMPONENT + RELIABILITY, SYSTEM + UNITED KINGDOM

9-10155 MOORE JC

RESEARCH REACTOR FAULT ANALYSIS - PART 1

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

6 PAGES, 1 TABLE, 6 FIGURES, NUCLEAR ENGINEERING, 11(118), PP. 195-202 (MARCH, 1966)

A FAULT-REPORTING AND ANALYSIS SCHEME ESTABLISHED IN 1960 AT HARWELL IS REVIEWED. ARTICLE DESCRIBES THE MATHEMATICAL TREATMENT OF DATA, USING LIDO AS AN EXAMPLE. IN GENERAL, (1) EXAMINATION OF MINOR FAULTS (NUISANCE) COULD OFTEN BE USED TO ASSESS THE LIKELIHOOD OF MAJOR FAULTS (POTENTIALLY UNSAFE) ARISING, (2) MORE-EFFECTIVE PREVENTIVE MAINTENANCE OBTAINS IF BASED ON FAULT-REPORTING DATA TO DETERMINE WHERE TO CONCENTRATE EFFORT, (3) A PRECURSOR RELATIONSHIP BETWEEN MINOR FAULTS AND VARIOUS MAJOR FAULTS SHOULD NOT BE IGNORED.

*FAILURE, GENERAL + *INCIDENT, ACTUAL, GENERAL + *OPERATING EXPERIENCE + *RELIABILITY ANALYSIS + REACTOR, RESEARCH + UNITED KINGDOM

9-10280 FAILURE OF OSCILLATOR DRIVE MECHANISM

ARGONNE NATIONAL LABORATORY

ANL-7190 +. 6 PAGES, 2 FIGURES, MARCH, 1966, PAGES 21-26 OF REACTOR ENGINEERING DIVISION ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965, CFSTI, \$5.00 CY, \$1.25 MN

TWO CONTROL RODS FAILED TO DROP AFTER A SPURIOUS SCRAM. THE STICKING OF THESE RODS WAS CAUSED BY STEEL BALLS LODGED BETWEEN THE ROD SHAFT AND THE REACTOR-VESSEL-COVER PENETRATION. THE BALLS CAME OUT OF DAMAGED LINEAR BALL BUSHINGS IN THE ROD-OSCILLATOR DRIVE MECHANISM ATTACHED TO AN ADJACENT ROD. THE ROD OSCILLATOR IS BEING REDESIGNED.

*CONTROL ROD DRIVE + *CONTROL ROD SCRAM MECHANISM + *FAILURE, SCRAM MECHANISM +

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10280 *CONTINUED*
EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + OPERATING EXPERIENCE + OSCILLATOR, REACTIVITY + REACTOR, BREEDER

9-10285 EDLUND MC + RHODE GK
SPECTRAL SHIFT CONTROL OF PRESSURIZED WATER REACTORS
BABCOCK AND WILCOX COMPANY
BAW-66 +. 12 PAGES, 1964, CFSTI

THE SPECTRAL-SHIFT METHOD FOR REACTIVITY CONTROL FOR A PWR IS DESCRIBED. THE EXCESS REACTIVITY IS CONTROLLED BY CHANGING THE RATIO OF HEAVY WATER TO LIGHT WATER IN THE MODERATOR. THIS ELIMINATES THE NEED OF USING CONTROL RODS OR POISON SOLUTIONS IN HOLDING DOWN THE INITIAL EXCESS REACTIVITY. THE SPECTRAL-SHIFT METHOD ALLOWS FUEL LOADINGS WITH THE HIGH EXCESS REACTIVITIES NECESSARY FOR LONGER CORE LIFETIMES WITHOUT DECREASING THE CONVERSION RATIO AS DO THE CONVENTIONAL REACTIVITY CONTROL METHODS.

*MODERATOR + *REACTIVITY, EXCESS + *REACTOR CONTROL + *REACTOR, SPECTRAL SHIFT + DEUTERIUM + HEAVY WATER + NEUTRON + REACTOR; HEAVY WATER + REACTOR, PRESSURIZED WATER

9-10286 RADEKA V + CHASE RL
A PARAMETRIC RADIATION DETECTOR PREAMPLIFIER
BROOKHAVEN NATIONAL LABORATORY
BNL-9980 + CONF-660304-2 +. 21 PAGES, INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS, SCINTILLATION AND SEMICONDUCTOR COUNTER SYMPOSIUM, WASHINGTON, D.C., 1965, CFSTI, \$1.00 CY, \$0.50 MN

A CHARGE-SENSITIVE PREAMPLIFIER WAS BUILT EMPLOYING A PAIR OF VARACTOR DIODES IN A NOVEL PARAMETRIC AMPLIFIER CONFIGURATION AS THE FIRST AMPLIFYING ELEMENT. THE CIRCUIT CONSISTS OF A PARAMETRIC SUBHARMONIC OSCILLATOR, PUMPED AT ABOUT 130 MC INCLUDED IN A NEGATIVE FEEDBACK LOOP. INPUT CHARGE SIGNALS PERTURB THE OSCILLATOR TUNING. THE FEEDBACK CIRCUIT PREVENTS SIGNIFICANT CHANGE IN THE OSCILLATOR AMPLITUDE BY SUPPLYING AN APPROXIMATELY EQUAL, OPPOSITE CHARGE TO THE INPUT CIRCUIT THROUGH A SMALL FEEDBACK CAPACITOR.

*INSTRUMENTATION, AMPLIFIER + *INSTRUMENTATION, NUCLEAR + EQUIPMENT DESIGN

9-10287 GIORDANO P + MATHIS A + MELUCCI G
DYNAMICS AND CONTROL STUDIES FOR A STEAM-GENERATING PRESSURE-TUBE REACTOR
COMITATO NAZIONALE PER L'ENERGIA NUCLEARE, ROME, ITALY
RT/ING165113 +. 37 PAGES, SEPTEMBER, 1965, DEP/MN

DYNAMIC STUDIES OF THE CIRENE REACTOR ARE DESCRIBED. AN ANALOG COMPUTER SIMULATION WAS USED DURING THE EARLY DESIGN TO HELP ESTABLISH MANY OF THE PLANT PARAMETERS. THE COMPUTER MODEL WAS REFINED DURING THE DESIGN OF THE PLANT AND USED IN CONTROL-SYSTEM STUDIES. A DIGITAL COMPUTER MODEL WAS USED FOR STABILITY STUDIES. THE DYNAMIC STUDIES INDICATED THAT THE REACTOR WAS BASICALLY UNSTABLE AND COULD NOT BE CONTROLLED MANUALLY, SO A FLUX CONTROLLER WOULD BE REQUIRED. THE PLANT BEHAVED SMOOTHLY WITH THE FLUX CONTROLLER AND COULD EASILY BE MADE TO BE LOAD-FOLLOWING.

*COMPUTER, ANALOG + *CONTROL SYSTEM + *MATHEMATICAL STUDY + *REACTOR DYNAMICS + *REACTOR STABILITY + ANALYTICAL MODEL + COMPUTER PROGRAM + COMPUTER, DIGITAL + DESIGN STUDY + ITALY + REACTOR CONTROL + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + TRANSFER FUNCTION

9-10383 OBRIEN HG + DITTO SJ
A CONTROL SYSTEM FOR A GAS-COOLED NUCLEAR POWER PLANT
OAK RIDGE NATIONAL LABORATORY
16 PAGES, 4 FIGURES, 3 REFERENCES, IEEE TRANSACTIONS ON NUCLEAR SCIENCE, NS-13(1), PP. 443-447 (FEBRUARY 1966), 12TH NUCLEAR SCIENCE SYMPOSIUM, INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS, SAN FRANCISCO, CALIFORNIA, OCTOBER 18-20, 1965

A MAJOR CONSIDERATION IN THE CONTROL OF A NUCLEAR POWER PLANT SUCH AS THE EXPERIMENTAL GAS-COOLED REACTOR IS THE REGULATION OF BOTH THE TEMPERATURE AND PRESSURE OF THE STEAM ENTERING THE TURBINE. THIS PAPER DESCRIBES A CONTROL SYSTEM THAT VARIES THE PRIMARY-COOLANT FLOW AND REACTOR POWER TO MAKE THE PLANT PRODUCE STEAM AT THE REQUIRED CONDITIONS OF TEMPERATURE AND PRESSURE OVER A WIDE RANGE OF STEAM FLOWS. ANALOG COMPUTER STUDIES SHOWED THAT THE CONTROL SYSTEM WAS ABLE TO MAKE THE SIMULATED PLANT SMOOTHLY FOLLOW BOTH LARGE CHANGES OF TURBINE LOAD (CHANGING AT A RATE OF 10 PERCENT PER MINUTE) AND SMALL RAPID CHANGES OF LOAD (1 PERCENT PER SECOND) WHILE LIMITING THE TRANSIENT VARIATIONS IN STEAM CONDITIONS TO ACCEPTABLE VALUES.

*CONTROL SYSTEM + *DESIGN STUDY + COMPUTER, ANALOG + EGCR (EXPERIMENTAL GAS COOLED REACTOR) + REACTOR, GAS COOLED

9-10386 SCHLOSSER W + NEWBERG J + KEY JA
PULSED NUCLEAR RADIATION INDUCED TRANSIENTS IN ELECTRICAL CABLES (DRF NO. 1)
U. S. ARMY ELECTRONICS COMMAND, ELECTRONICS LABORATORIES, FORT MONMOUTH, N.J.
ECUM-2415 +. 32 PAGES, JULY 1964, TECHNICAL REPORT, CFSTI

THE PULSED NUCLEAR-RADIATION-INDUCED TRANSIENTS IN THE INDIVIDUAL CONDUCTORS OF RG-62A/U AND RG-59B/U COAXIAL CABLES AND A MULTICONDUCTOR RIBBON CABLE DUE TO EXPOSURE TO THE DRF-MARK F TRIGA REACTOR WERE STUDIED AS A FUNCTION OF APPLIED VOLTAGE AND REPETITIVE EXPOSURE.

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10386 *CONTINUED*
*INSTRUMENTATION, COMPONENT + *RADIATION EFFECT + *REACTOR, PULSED + *TEST, COMPONENT +
TRIGA (TRAINING REACTOR, ISOTOPES, G.A.)

9-10387 OAKES LC
A SECOND GENERATION OF REACTOR CONTROL SYSTEMS AS APPLIED TO THE HIGH FLUX ISOTOPE REACTOR
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1259 +. 31 PAGES, 9 FIGURES, SEPTEMBER 1, 1965, CFSTI, \$2.00 CY, \$0.50 MN

PURPOSE - DESIGN CONTROL AND SAFETY SYSTEMS FOR THE HFIR. APPROACH - DEVELOP AN ORNL SECOND GENERATION OF TRANSISTORIZED AND MODULARLY CONSTRUCTED INSTRUMENTS. THE SAFETY SYSTEM EMPLOYS COMPUTER ELEMENTS FOR COMPUTATIONS SUCH AS HEAT POWER AND FLUX/FLOW RATIO. A MAGNET HAVING THREE COILS, ANY TWO OF WHICH CAN SUPPORT ITS ASSOCIATED ROD, IS THE COINCIDENCE ELEMENT THAT PERMITS EACH CHANNEL TO BE TESTED INDEPENDENTLY. THE WIDE-RANGE COUNTING CHANNEL EMPLOYING A SERVO-POSITIONED COUNTER COVERS STARTUP THROUGH FULL POWER. THREE SERVO CHANNELS DRIVE A SINGLE ROD THROUGH A DIFFERENTIAL GEAR. FAILURE OF A SINGLE SERVO CHANNEL, AND, IN SPECIAL CASES, TWO CHANNELS, WILL NOT CAUSE LOSS OF CONTROL. A MULTISECTION IONIZATION CHAMBER HAS UP TO THREE DETECTORS IN A SINGLE CAN. A CLADDING-FAILURE DETECTOR AND A FLUX-ASYMMETRY DETECTOR ARE ALSO DESCRIBED.

*CONTROL SYSTEM + *HFIR (HIGH FLUX ISOTOPE REACTOR) + *REACTOR SAFETY SYSTEM + *REACTOR, HIGH FLUX +
INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + INSTRUMENTATION, GENERAL + SERVOMECHANISM +
SYSTEM DESCRIPTION

9-10389 CALIGIURI GP + WUNDT F.
DYNAMICS AND CONTROL OF THE FAST PULSED REACTOR SORA
EUROPEAN ATOMIC ENERGY COMMUNITY, ISPRA, ITALY
EUR-2553.E +. 102 PAGES, AUGUST 13, 1965, DEP.MN

A DETAILED DESCRIPTION OF THE DYNAMIC BEHAVIOR OF THE REACTIVITY-PULSED RESEARCH REACTOR SORA IS PRESENTED, BASED ON RESULTS OF A SIMULATION ON AN ANALOG COMPUTER. THE PERIODICALLY PULSED STATE IS TREATED, AS WELL AS DISTURBANCES FROM IT. TEMPERATURE FEEDBACK IS CONSIDERED. A SUITABLE CONTROL IS DESIGNED TO KEEP THE REACTOR STABLE EVEN THOUGH IT BECOMES PROMPT-SUPERCritical FIFTY TIMES A SECOND. THE SIMULATION ITSELF REQUIRED NEW, COMBINED, DIGITAL-ANALOG TECHNIQUES, WHICH ARE EQUALLY DESCRIBED.

COMPUTER PROGRAM + COMPUTER, ANALOG + COMPUTER, DIGITAL + CONTROL SYSTEM + DESIGN STUDY + ITALY +
MATHEMATICAL STUDY + REACTOR DYNAMICS + REACTOR KINETICS + REACTOR SAFETY SYSTEM + REACTOR, FAST BURST +
REACTOR, PULSED

9-10439 BUMP TR + SIMMONS WR
HOLD-DOWN REQUIREMENTS FOR POISON CONTROL RODS
ARGONNE NATIONAL LABORATORY, ARGONNE
3 PAGES, 3 REFERENCES, PRESENTED AT ANS ANNUAL MEETING, JUNE 20-23, 1966, DENVER, COLORADO

PROBLEM--IN REACTORS WITH LIQUID-METAL COOLANTS, THE VESSEL OR CLOSURE DESIGN MAY BE DICTATED BY THE ROD HOLD-DOWN REQUIREMENTS, RATHER THAN BY COOLANT PRESSURE. IT IS NECESSARY TO ENSURE THAT A MINOR ACCIDENT CANNOT FORCE THE RODS OUT OF THE REACTOR CORE AND CAUSE A MORE SERIOUS ACCIDENT. APPROACH--FOUR POSSIBLE MECHANISMS THAT MIGHT FORCE THE RODS FROM THE CORE WERE EXAMINED FOR THE FAST DESIGN.

ACCIDENT, REACTIVITY + CONTROL ROD DRIVE + DESIGN CRITERIA + EXCURSION, LARGE +
REACTOR, LIQUID METAL COOLED

9-10466 LAWRENCE LA
DEVELOPMENT OF REDUNDANCY TECHNIQUES FOR THE ACHIEVEMENT OF HIGHLY RELIABLE AUTOCONTROL FOR NUCLEAR REACTORS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, WINFRITH
1 PAGE, NUCLEAR ENGINEERING, 11(117), P. 126 (FEBRUARY 1966), ABSTRACT ONLY

PROBLEM - DEVELOP A HIGHLY RELIABLE REACTOR ROD CONTROL SYSTEM. APPROACH - (1) COMPARE THE REDUNDANCY TECHNIQUES OF A RAPID SWITCHOVER BETWEEN TWO INDEPENDENT SYSTEMS WITH A TWO-OUT-OF-THREE SYSTEM, (2) EXAMINE FAILURE-MONITORING TECHNIQUES. RESULTS - ROD-CONTROL SYSTEM WAS DEVELOPED THAT USES THREE INDEPENDENT CHANNELS, WITH THE OUTPUT SHAFTS OF THE MOTORS COMBINED IN DIFFERENTIAL GEARBOXES SO THE ROD MOVEMENT IS PROPORTIONAL TO THE SUM OF THE ROTATIONS OF THE INDIVIDUAL SHAFTS.

*CONTROL SYSTEM + *RELIABILITY ANALYSIS + *RELIABILITY, SYSTEM + EQUIPMENT DESIGN +
INSTRUMENTATION, CONTROL + INSTRUMENTATION, REDUNDANT + REACTOR, RESEARCH + SERVOMECHANISM +
UNITED KINGDOM

9-10500 TOLSON GM
THE MANUFACTURE OF THE CONTROL RODS FOR THE EXPERIMENTAL GAS-COOLED REACTOR
OAK RIDGE NATIONAL LABORATORY
ORNL-3932 +. 22 PAGES, 14 FIGURES, 1 TABLE, REFERENCES, APRIL, 1966, CFSTI, \$2.00 CY, \$0.50 MN

PROBLEM - DESIGN AND MANUFACTURE CONTROL RODS FOR THE EGCR. APPROACH - RODS ARE MADE OF BORON CARBIDE BUSHINGS ENCASED IN STAINLESS STEEL TUBES. TO ALLOW MOVEMENT IN A DISTORTED CHANNEL,

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10500 *CONTINUED*

THE RODS WERE MADE UP OF FOUR SEGMENTS HELD TOGETHER BY A SPRING-LOADED CENTRAL ROD.

*CONTROL ROD FABRICATION + CONTROL ROD + EGCR (EXPERIMENTAL GAS COOLED REACTOR) + REACTOR, GAS COOLED

9-10826 SKARDHAMAR T
COMPARISON OF CONTROL ROD CALCULATIONS USING HOMOGENEOUS AND HETEROGENEOUS METHODS
AKTIEBOLAGET ATOMENERGI, STOCKHOLM, SWEDEN
RFR-193 +. 11 PAGES, FIGURES, REFERENCES, MAY 17, 1962, DEP/MN

A COMPARISON WAS MADE OF THE HOMOGENEOUS AND HETEROGENEOUS METHODS IN DETERMINING THE REACTIVITY EQUIVALENCES OF FULLY INSERTED CONTROL RODS IN THE CORE OF THE R3 REACTOR. FOR CYLINDRICAL CORES WITH SYMMETRICALLY PLACED CONTROL RODS, AND USING THE PRESENT-DAY COMPILATION OF REACTOR PARAMETERS, THE RESULTS OBTAINED FROM THE TWO METHODS ARE IN VERY GOOD AGREEMENT. THIS TENDS TO CONFIRM THAT THESE TWO DISTINCT METHODS CAN BE WELL USED TO SUPPLEMENT EACH OTHER IN GENERAL CONTROL-ROD CALCULATIONS.

*CONTROL ROD WORTH + COMPUTER, DIGITAL + SWEDEN

9-10909 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14A - INSTRUMENTATION SYSTEM -- STEAM-GENERATOR WATER-LEVEL INSTRUMENTATION IS REDUNDANT. THERE ARE TWO LEVEL TRANSMITTERS FOR EACH OF FOUR STEAM GENERATORS. LOW AND LOW-LOW LEVEL ALARMS, FEED WATER FLOW VS STEAM FLOW MISMATCH IS ALARMED, AND REACTOR IS TRIPPED IF ANY SG HAS LOW WATER LEVEL (1 OF 2) IN COINCIDENCE WITH WATER-STEAM FLOW MISMATCH.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + *REDUNDANCE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER + STEAM

9-10910 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14B -- INSTRUMENTATION SYSTEM -- THE EFFECT OF HYDRAULIC FORCES ON ROD-CLUSTER INSERTION TIME DURING A LOSS OF COOLANT ACCIDENT WILL BE CONSIDERED IN CALCULATING ENERGY RELEASES.

*CONTROL ROD + *HYDRODYNAMIC ANALYSIS + *LOSS OF COOLANT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + ENERGY SOURCE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

9-10911 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14C - INSTRUMENTATION SYSTEM -- MANUAL ISOLATION VALVES MAY BE CHECKED AT THEIR LOCATION FOLLOWING THE HYPOTHETICAL ACCIDENT. REMOTELY CONTROLLED VALVES WILL HAVE INDICATOR LIGHTS IN THE MAIN CONTROL ROOM.

*CONTAINMENT PENETRATION, CLOSURE OF + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + INSTRUMENTATION, GENERAL + REACTOR, PRESSURIZED WATER

9-10912 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14D - INSTRUMENTATION SYSTEM -- THE THREE PRESSURIZER-LEVEL SENSORS WILL EACH HAVE A SEPARATE TAP TO ENSURE INDEPENDENCE IN CASE OF A RUPTURED TAP.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + *PRESSURIZER + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + INSTRUMENTATION, INDEPENDENT + REACTOR, PRESSURIZED WATER

9-10913 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14E - INSTRUMENTATION SYSTEMS -- POST MCA REACTIVITY STATUS AND CONTAINMENT CONDITION INSTRUMENTATION. THREE CONTAINMENT-PRESSURE INDICATORS ARE THE MAIN INDICATIONS OF THE CONTAINMENT TEMPERATURE AND THE EFFECTIVENESS OF THE CONTAINMENT COOLING SYSTEMS. OTHER INDICATIONS MUST BE CONSIDERED AS BONUS READINGS. THERE IS NO SPECIFIC INDICATION THAT EACH SAFEGUARD SYSTEM IS ACTING AS DESIGNED. HOWEVER, VARIOUS INDICATORS ARE LISTED (EG. PUMP DISCHARGE PRESSURE, VALVE POSITION, SUPPLY-WATER LEVEL).

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-10913 *CONTINUED*

*CONTAINMENT INSTRUMENTATION + *INSTRUMENTATION, GENERAL + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CONTROL ROD, SHIM SAFETY + ENGINEERED SAFEGUARD + INDIAN POINT II + REACTOR, PRESSURIZED WATER

9-10914 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14F- INSTRUMENTATION SYSTEM -- EXPERIENCE AT YANKEE, INDIAN POINT I, AND CVTR SHOWS THAT THE BEST EXTERNAL DETECTORS OF AVERAGE CORE POWER AND OF FLUX TILTS IS A SET OF FOUR LONG ION CHAMBERS (LENGTH EQUAL TO CORE HEIGHT) LOCATED SYMMETRICALLY. EACH CHAMBER HAS TWO SECTIONS OF EQUAL LENGTH, ONE SECTION COMPENSATED AND THE OTHER UNCOMPENSATED. THE TOTAL CURRENT IS USED IN AVERAGE POWER CIRCUITS, AND THE INDIVIDUAL CURRENTS ARE COMPARED TO DETECT FLUX TILTS.

*FLUX TILT + *INSTRUMENTATION, NUCLEAR + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + OPERATING EXPERIENCE + REACTOR, PRESSURIZED WATER

9-11006 JAKEMAN D
PHYSICS OF NUCLEAR REACTORS. CHAPTER 9 - REACTIVITY CHANGES AND CONTROL
356 PAGES, THE ENGLISH UNIVERSITIES PRESS LTD (1966)

CHAPTER 9 CONTAINS A FEW TOPICS OF SAFETY INTEREST. THESE INCLUDE REACTIVITY EFFECTS OF TEMPERATURE IN THERMAL REACTORS, REACTIVITY EFFECTS IN FAST REACTORS DUE TO FUEL EXPANSION, SODIUM VOIDS AND DOPPLER EFFECT, CONTROL METHODS, THEORY OF CONTROL RODS, AND REACTOR KINETICS.

CONTROL ROD + CONTROL, GENERAL + DOPPLER EFFECT + FUEL EXPANSION COEFFICIENT + REACTOR DYNAMICS + REACTOR, FAST + REACTOR, THERMAL + SODIUM COEFFICIENT + TEMPERATURE COEFFICIENT

9-11023 EICH WJ + WILLIAMS HT + AISU H + MINTON GH
CALCULATION OF REACTIVITY WORTH OF ROD-CLUSTER CONTROL ELEMENTS AND CORRELATION OF THEORY WITH EXPERIMENT
WESTINGHOUSE ATOMIC POWER DIVISION, PITTSBURGH, PA.
11 PAGES, 8 FIGURES, 2 TABLES, 18 REFERENCES, NUCLEAR SCIENCE AND ENGINEERING, 24(13), PAGES 272-283, (MARCH, 1966)

ANALYTICAL PROCEDURES FOR THE REPRESENTATION OF ROD-CLUSTER CONTROL ELEMENTS IN NUCLEAR DESIGN CALCULATIONS ARE DEVELOPED AND EVALUATED BY APPLICATION TO A VARIETY OF CRITICAL EXPERIMENTS. METHODS SUITABLE FOR USE IN FEW-GROUP DIFFUSION THEORY STUDIES ARE UTILIZED IN PREDICTING CRITICAL WATER HEIGHTS AND INTEGRAL WORTH MEASUREMENTS FOR REACTORS CONTAINING ARRAYS OF CYLINDRICAL ABSORBERS. RESULTS INDICATE THAT WORTH CAN BE CALCULATED TO WITHIN PLUS OR MINUS 3 PERCENT FOR A WIDE RANGE OF CONFIGURATIONS INVOLVING CLAD AND UNCLAD ABSORBERS OF 0.260, 0.330, AND 0.403 IN. DIAMETER.

*CONTROL ROD WORTH + ANALYTICAL MODEL + COMPARISON, THEORY AND EXPERIENCE + EXPERIMENT, GENERAL

9-11110 DARKE RS + STEVENS HH
APPLICATION OF FOSSIL PLANT EXPERIENCE WITH ON-LINE COMPUTERS TO NUCLEAR POWER PLANTS
BAILEY METER COMPANY, OHIO + BABCOCK AND WILCOX
8 PAGES, 1 TABLE, JUNE 20, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER COLORADO, JUNE 20-23, ANS TRANS. 9(1), PAGE 266

BRIEFLY CONSIDERS APPLICATION OF COMPUTERS TO NUCLEAR PLANTS AS CONTROLLERS AND, OR, MONITORS. SUGGESTS MORE ALARMS OF A SPECIFIC NATURE BECAUSE OF CALCULATIONAL AND MEMORY FEATURES OF COMPUTERS. FOR EXAMPLE, COMPUTERS COULD BOTH WARN OF XENON OSCILLATION AND PRESCRIBE PROPER CONTROL ACTION.

*CONTROL, COMPUTER + REACTOR, POWER + XENON OSCILLATION

9-11441 REICKS GH
SODIUM LEVEL DETECTORS IN THE ENRICO FERMI ATOMIC POWER PLANT
ATOMIC POWER DEVELOPMENT ASSOCIATES
APDA-300 +. 44 PAGES, NOVEMBER 30, 1966, CFSTI, \$2.00 CY, \$0.50 MN

ALL LEVEL DETECTORS FOR HIGH-TEMPERATURE OPERATION IN LIQUID METALS WERE EVALUATED. THE MOORE SPECIAL MODEL 15 AND, LATER THE TAYLOR NAK-FILLED DETECTOR WERE INSTALLED. RESULTS OF THE FERMI-PLANT EXPERIENCE LEADS TO THE CONCLUSION THAT A DESIGN AND DEVELOPMENT PROGRAM IS NEEDED FOR LIQUID-METAL PROBES.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + FERMI + INSTRUMENTATION, PROCESS + METAL, LIQUID + MOLTEN FUEL + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

9-11472 MUNNS JM
REACTOR COOLANT SYSTEM RATE-OF-CHANGE-OF-PRESSURE (DP/DT) TRIP
TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE
TID-22760 +. 9 PAGES, AUGUST 12, 1964, CFSTI, \$1.00 CY, \$0.50 MN

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11472 *CONTINUED*

TWO METHODS WERE INVESTIGATED FOR POSSIBLE USE IN ACTUATING A REACTOR-COOLANT-SYSTEM DP/DT TRIP. THE IDEA WAS TO PROVIDE A SIMPLE YET RELIABLE TRIP WHILE REQUIRING A MINIMUM NUMBER OF CHANGES TO THE EXISTING SAFETY SYSTEM. THE METHODS ARE DEPICTED BY ONE-LINE DIAGRAMS.

*CONTAINMENT INSTRUMENTATION + *LOSS OF PRESSURE + EGCR (EXPERIMENTAL GAS COOLED REACTOR) + INSTRUMENTATION, PROCESS + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

9-11485 MUNNS JM

DESIGN PROPOSAL FOR A RATE-OF-CHANGE-OF-PRESSURE SCRAM SAFETY CHANNEL FOR THE EGCR
TENNESSEE VALLEY AUTHORITY, OAK RIDGE
TID-22759 +. 10 PAGES, APRIL 9, 1965, CFSTI \$1.00 CY, \$0.50 MN

THIS REPORT PRESENTS A DESIGN PROPOSAL FOR A TWO-OUT-OF-THREE RATE-OF-CHANGE-OF-PRESSURE SCRAM SYSTEM FOR USE DURING NITROGEN PRESSURIZATION OF THE EGCR CORE. THE DP-DT SCRAM INSTRUMENTATION, IN CONJUNCTION WITH THE PROPOSED PERIOD SCRAM, SHOULD LIMIT THE CONSEQUENCE TO REACTIVITY ACCIDENTS DURING THE EGCR PHYSICS TESTS (PHASE IVA) TO ACCEPTABLE LEVELS.

*CONTAINMENT INSTRUMENTATION + *EGCR (EXPERIMENTAL GAS COOLED REACTOR)

9-11487 BYRD JS

SOLID-STATE LOGARITHMIC CONVERTER

SAVANNAH RIVER LABORATORY

DP-MS-66-5 + CONF-660-408-4 +. 13 PAGES, FROM INSTRUMENT SOCIETY OF AMERICA, SOUTHEASTERN CONFERENCE AND EXHIBIT, AUGUSTA, GA., APRIL 19, 1966, CFSTI \$1.00, \$0.50 MN

A METHOD OF LOGARITHMIC CONVERSION OF CURRENT TO VOLTAGE, USING THE SHORT-CIRCUIT COLLECTOR CURRENT AND THE EMITTER-BASE VOLTAGE CHARACTERISTICS OF A SILICON TRANSISTOR, IS DESCRIBED. CIRCUITS DESIGNED TO MEASURE PICOAMPERES FOR NUCLEAR INSTRUMENTS ARE ANALYZED, AND GENERAL DESIGN CONSIDERATIONS FOR THE CONVERTER CIRCUIT ARE DISCUSSED

*INSTRUMENTATION, NUCLEAR + DATA PROCESSING + MEASUREMENT, REACTIVITY

9-11488 RUBEL P

VITAL POWER SUPPLIES FOR NUCLEAR FACILITIES

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

4 PAGES, 1 FIGURE, 1 TABLE, 5 REFERENCES NUCLEAR SAFETY 7(3), PAGES 324-328 (SPRING 1966)

MEANS FOR EVALUATING POWER SUPPLIES FOR VITAL FUNCTIONS IN NUCLEAR FACILITIES ARE DISCUSSED. THE OVERALL SYSTEM FOR SUPPLYING POWER FOR VITAL FUNCTIONS MUST BE EXAMINED SO THAT THE POWER-SUPPLY RELIABILITY CAN BE EVALUATED ACCORDING TO REQUIREMENTS CONSISTENT WITH THOSE OF THE VITAL FUNCTIONS SERVED. THE APPLICATION OF THE GENERAL SYSTEM-RELIABILITY CRITERIA (REDUNDANCE, INDEPENDENCE, ISOLATION, AND TESTING) IS SUGGESTED. OTHER DESIGN, MAINTENANCE, AND ADMINISTRATIVE ASPECTS OF POWER SYSTEMS ARE CORRELATED.

*ELECTRIC POWER, VITAL + *INSTRUMENTATION, INDEPENDENT + *REDUNDANCE + ELECTRIC POWER, AUXILIARY + EMERGENCY POWER, ELECTRIC + GENERATOR, DIESEL

9-11489 GREEN AE + BOURNE AJ

RELIABILITY CONSIDERATIONS FOR AUTOMATIC PROTECTIVE SYSTEMS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HEALTH AND SAFETY BRANCH

AHSB(S)-R-91 +. 15 PAGES, 2 TABLES, 2 FIGURES, 31 REFERENCES, 1965, UKAEA

PROBLEM - ESTIMATE THE RELIABILITY OF A REACTOR PROTECTIVE SYSTEM. APPROACH - (1) DEFINE RELIABILITY, (2) DEVELOP A METHOD FOR DERIVING A RELIABILITY MODEL, (3) GIVE APPLICATIONS OF USES OF THIS MODEL, (4) DISCUSS LIMITATIONS OF METHOD. RESULTS - PREDICTED OVERALL EQUIPMENT-FAILURE RATES CALCULATED FROM COMPONENT-FAILURE RATES AGREED WITHIN A FACTOR OF 2 OF ACTUAL EQUIPMENT-FAILURE RATES. CONCLUSIONS - THE LIMITATIONS REQUIRE THAT THE ABSOLUTE VALUES OF RELIABILITY BE USED WITH CAUTION - HOWEVER, THEY ARE USED WITH MORE CERTAINTY IN COMPARING DIFFERENT EQUIPMENT DESIGNS.

*REACTOR SAFETY SYSTEM + *RELIABILITY ANALYSIS + *RELIABILITY, COMPONENT + *RELIABILITY, SYSTEM + COMPARISON, THEORY AND EXPERIENCE

9-11597 MARKOV KP + RYABOV NV + STAS KN

METHOD FOR A CONTINUOUS CONTROL OF THE QUANTITY OF LATENT ENERGY

GOSUDARSTVENNYI KOMITET PO ISPOL ZOVANIYU ATOMNOI ENERGII SSSR

ANL-TRANS-277 + NP-15105 +. 13 PAGES, 1964, CFSTI, \$1.00 CY, \$0.50 MN

THIS ARTICLE DEALS WITH METHODOLOGICAL PROBLEMS CONCERNING THE FEASIBILITY AND THE CONSTRUCTION OF AN INSTRUMENT FOR CONTINUOUS RECORDING OF THE TOTAL REACTIVITY PRODUCED BY DAUGHTER PRODUCTS OF RADON IN THE ATMOSPHERE. THE ARTICLE GENERATES A MATHEMATICAL MODEL FOR A CONSTANT AIR MONITOR TYPE OF INSTRUMENT USING CONTINUOUS-BELT FILTERING. ONLY THE DAUGHTER PRODUCTS OF RADON ARE CONSIDERED.

*MATHEMATICAL STUDY + *MONITOR, RADIATION, AIR + INSTRUMENTATION, RADIATION MONITORING + MEASUREMENT, REACTIVITY

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11628 FIELD FR + BUTTERWORTH RR + GIMMY KL + HURLEY TJ + HATSHORN WR + PYDER FD
SRP REACTOR ON-LINE COMPUTER-PROCESS
SAVANNAH RIVER PLANT
DPSU-65-30-27 + CONF-650917-1 +. 6 PAGES, FROM INTERNATIONAL CONFERENCE ON INDUSTRIAL ELECTRONICS AND
CONTROL INSTRUMENTATION, PHILADELPHIA, JULY 1965, CFSTI \$1.00 CY, \$0.50 MN

A GE-412 ON-LINE COMPUTER WAS VALUABLE IN INCREASING SAFETY AND ASSISTING OPERATION OF A LARGE
HEAVY-WATER-MODERATED REACTOR AT THE SAVANNAH RIVER PLANT. COMPUTED PERFORMANCE DATA CLOSE
TO OPERATING CONTROL LIMITS ARE DISPLAYED FREQUENTLY FOR THE OPERATOR. 3250 SENSOR READINGS
ARE MADE EVERY 4-1/2 MIN. COMPUTER OUTPUT GIVES, WITH THE EXISTING SYSTEM OF COMPREHENSIVE
WRITTEN PROCEDURES, IMPROVED REACTOR CONTROL.

*CONTROL, COMPUTER + *SAVANNAH RIVER PRODUCTION REACTORS + INSTRUMENTATION, GENERAL

9-11629 BRACKENBUSH LW + BAUMGARTNER WV
NEUTRON DOSIMETRY USING THE FISSION FRAGMENT DAMAGE PRINCIPLE
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY
BNWL-SA-516 + CONF-660621-2 +. 17 PAGES, FROM HEALTH PHYSICS SOCIETY, 11TH ANNUAL MEETING, HOUSTON,
TEXAS, JUNE 9, 1966, CFSTI \$1.00 CY, \$0.50 MN

PLASTICS, GLASSES, AND MINERALS USED IN CONJUNCTION WITH FISSIONABLE FOILS PROVIDE THE BASIS
FOR A FULL-ENERGY-SPECTRUM NEUTRON DOSIMETER. STUDIES INDICATE THAT FAST NEUTRON DOSES AS
LOW AS 100 MILLIREMS, AND THERMAL NEUTRON DOSES OF 1 MILLIREM CAN BE MEASURED. NUCLEAR-TRACK
DETECTORS WERE MADE WITH FISSION FOILS OF METALLIC U235 AND DEPLETED U238. NEPTUNIUM OXIDE
FOILS WERE ALSO TESTED. EXPOSURE STUDIES OF RA-BE, PU-BE AND PUF4 NEUTRON SOURCES AND
MONOENERGETIC FAST NEUTRONS OBTAINED FROM A 2-MEV POSITIVE-ION ACCELERATOR CHARACTERIZE THE
ENERGY AND DOSE RESPONSE OF THIS DEVICE.

*DOSIMETRY, RADIOPHOTOLUMINESCENCE + *INSTRUMENTATION, NUCLEAR + INSTRUMENTATION CALIBRATION + NEUTRON +
NEUTRON INTERACTION

9-11639 GERTZ D + LEVINE J
FINAL REPORT FROM APRIL 1961 TO JUNE 1965. FEASIBILITY STUDY OF A UNIFIED DIGITAL INSTRUMENTATION AND
CONTROL SYSTEM FOR NUCLEAR POWER PLANTS
SPERRY RAND CORPORATION
NYO-2764-2 +. 320 PAGES, 180 FIGURES, JUNE 30, 1965, CFSTI \$7.00 CY

AFTER REVIEWING THE BASIC CONCEPTS OF INSTRUMENTATION, THE AUTHORS CONCLUDE THAT AN
ALL-DIGITAL INSTRUMENT SYSTEM FOR NUCLEAR REACTORS IS DESIRABLE. A SYSTEM IS DESCRIBED WHICH
USES ULTRASONIC TRANSDUCERS FOR DIGITAL MEASUREMENT OF TEMPERATURE, PRESSURE, AND LEVEL. THE
ASSOCIATED ELECTRONICS TO HANDLE AND PROCESS THE DIGITAL SIGNALS FROM THESE TRANSDUCERS IS
ALSO GIVEN.

*INSTRUMENTATION, GENERAL + INSTRUMENTATION, LIQUID LEVEL DETECTION + INSTRUMENTATION, PROCESS +
INSTRUMENTATION, TEMPERATURE

9-11640 PLISSON J
CAN RUPTURE DETECTION IN G3 - OPERATIONAL EXPERIENCE
CENTRE DE PRODUCTION DE PLUTONIUM DE MARCOULE, FRANCE
CEA-R-2710 +. 24 PAGES, 12 FIGURES, 5 REFERENCES, DECEMBER 1964, DEP. MN, IN FRENCH

A SUMMARY OF THE PRINCIPLES OF CAN-RUPTURE DETECTION IS GIVEN, PLUS A DESCRIPTION OF THE
CONCLUSION REACHED AFTER 4 YEARS OF OPERATION ON THE G3 REACTOR. A DAUGHTER-ION COLLECTOR IS
DESCRIBED, AND DETAILS OF THE INSTRUMENT PRESENTED.

*INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY

9-11762 LEAKE JW
NEW METHODS OF MEASURING NEUTRON DOSE EQUIVALENT RATE AROUND PULSED NEUTRON GENERATORS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-4883 +. 11 PAGES, 7 FIGURES, 9 REFERENCES, JUNE 1965, HMSO

TWO METHODS OF MEASURING THE NEUTRON DOSE EQUIVALENT AROUND PULSED MACHINES ARE DESCRIBED.
BOTH METHODS USE THE MODERATOR SYSTEM OF THE NEUTRON COUNTER ASSEMBLY T1940A (BASED ON THE
ANERSSON-BRAUN COUNTER), WITH EITHER THE STANDARD T1940A BF3 PULSE COUNTER OR A BF3 ION
CHAMBER MOUNTED AT THE CENTER. THE LIMITATIONS OF THE T1940A WITH THE PULSE-TYPE COUNTER,
AND THE ADVANTAGES OF THE ION CHAMBER VERSION, ARE DISCUSSED. UNDER FAVORABLE CONDITIONS,
THE T1940A WITH A PULSE-TYPE COUNTER IS ABLE TO MEASURE PULSED RADIATION, WITH LESS THAN 2
PERCENT LOSS, UP TO A MEAN DE RATE OF 1 REM/HR. THE RESPONSE OF BOTH SYSTEMS IS PROPORTIONAL
TO THE DE RATE (AS RECOMMENDED BY THE INTERNATIONAL COMMISSION ON RADIOLOGICAL PROTECTION,
1963) WITHIN PLUS OR MINUS 50 PERCENT FOR NEUTRONS OF ALL ENERGIES FROM THERMAL TO 12 MEV.

*DOSE MEASUREMENT, EXTERNAL + *INSTRUMENTATION, RADIATION MONITORING + *MONITOR, RADIATION, AIR +
CHAMBER, ION + ICRU (INT. COMM., RAD. UNITS AND MEASUREMENTS) + PULSED NEUTRON TECHNIQUE

9-11764 ABSON W + LOOSEMORE WR
REPORT ON DEVELOPMENTS IN HEALTH PHYSICS INSTRUMENTS IN ELECTRONICS DIVISION, A.E.R.E.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-4552 + CONF-640304-1 +. 49 PAGES, 18 FIGURES, 23 REFERENCES, 1965, HMSO

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11764 *CONTINUED*

THE REPORT PROVIDES A GENERAL SUMMARY AND REVIEW OF RESEARCH AND DEVELOPMENT WORK DURING THE LAST 3 YEARS IN THE ELECTRONICS DIVISION, ATOMIC ENERGY RESEARCH ESTABLISHMENT (UK), ON TOPICS RELATED TO RADIOLOGICAL PROTECTION AND HEALTH PHYSICS INSTRUMENTATION. THE REPORT COVERS EXTERNAL BETA-GAMMA MONITORING INSTRUMENTS, NEUTRON MONITORING INSTRUMENTS, MONITORING INSTRUMENTS FOR SURFACE CONTAMINATION, PERSONAL BETA-GAMMA DOSE AND DOSE-RATE INSTRUMENTS, GAMMA SPECTROMETERS FOR DISTRICT SURVEYS AND FOR AIRBORNE PARTICLES, PLUS OTHER INSTRUMENTATION TOPICS.

*DOSIMETRY, GENERAL + *MONITOR, RADIATION, GENERAL + CHAMBER, ION + DOSE MEASUREMENT, EXTERNAL + DOSIMETRY, THERMOLUMINESCENCE + MONITOR, RADIATION, AIR + MONITOR, RADIATION, PERSONNEL + MONITOR, RADIATION, SURFACE + UNITED KINGDOM

9-11765 REINKE CF + BECK WN
MEASUREMENT OF WATER-CHANNEL GAPS IN EBWR CORE-I FUEL ELEMENTS
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-6772 +. 15 PAGES, 6 FIGURES, 7 TABLES, 4 REFERENCES, MARCH 1964, CFSTI \$0.50

AN EDDY-CURRENT TECHNIQUE WAS DEVELOPED FOR MEASURING WATER-CHANNEL GAPS ON EBWR CORE-I FUEL ELEMENTS UNDER WATER IN THE EBWR REACTOR VESSEL. ACTUAL MEASUREMENTS WERE MADE WITH A MODIFIED COMMERCIAL EDDY-CURRENT-DETECTION DEVICE BEFORE AND AFTER 100-MW OPERATION OF THE EBWR. BEFORE HIGH-POWER OPERATION, THE CHANNELS RANGED FROM 8.4 MM TO GREATER THAN THE REFERENCE VALUE OF 11.1. AFTER 100-MW OPERATION, THE MINIMUM WATER GAP WAS ABOUT 10.2 MM. THE DATA INDICATE THAT SWELLING (IF ANY OCCURRED) WAS NEGLIGIBLE AND MASKED BY A LOSS OF OXIDE FROM THE FUEL-PLATE SURFACES.

*FUEL ELEMENT + *IN CORE MEASUREMENT + EBWR (EXPERIMENTAL BOILING WATER REACTOR) + TEST, NONDESTRUCTIVE

9-11770 RISING FL
A SYSTEM FOR CRITICALITY VERIFICATION
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-SA-31 +. 10 PAGES, JUNE 7, 1965, CFSTI \$1.00 CY, \$0.50 MN

A FAST-NEUTRON DETECTOR IS USED TO VERIFY A CRITICALITY INCIDENT AFTER A CRITICALITY ALARM. THIS TYPE OF DETECTOR WAS CHOSEN TO ELIMINATE THE ALARMS CAUSED BY CHANGES IN GAMMA BACKGROUND. THE SYSTEM IS CAPABLE OF DETECTING 10(15TH) FISSIONS, SHIELDED BY 8 IN. OF LEAD, AT A DISTANCE OF 700 FT. IT IS USED ONLY TO VERIFY AN OCCURRENCE. THE BASIC ELECTRONICS DESIGN WAS ADAPTED FROM RESEARCH WORK COMPLETED BY THE HANFORD NUCLEONICS INSTRUMENTATION GROUP AND IS USED WITH A SCINTILLATION DETECTOR AS AERIAL SURVEY EQUIPMENT.

*MONITOR, RADIATION, ENVIRONMENTAL + *MONITORING SYSTEM + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY

9-11771 MUSTARD GL
RADIATION ALARM INSTRUMENT INSTRUCTION MANUAL
GOODYEAR ATOMIC CORPORATION, PIKETON, OHIO
GAT-T-1222 +. 36 PAGES, OCTOBER 13, 1965, CFSTI \$2.00 CY, \$0.50 MN

THE THEORY OF OPERATION AND THE SPECIFICATIONS ARE PRESENTED FOR THE INTEGRATING-TYPE CRITICALITY ALARM INSTRUMENT USED AT THE PORTSMOUTH GASEOUS DIFFUSION PLANT. THE ADVANTAGES OF THE GAMMA-PLUS-NEUTRON-SENSITIVE ION CHAMBER WITH SHORT-TERM INTEGRATION ARE DISCUSSED. THE MAJOR DESIGN FEATURES - FEWER FALSE ALARMS, RELIABILITY, FAILSAFE, SELF-CONTAINED POWER FROM CONTINUOUSLY CHARGED ALKALINE BATTERIES, AND SELF-MONITORING ARE DESCRIBED IN DETAIL.

*CHAMBER, ION + *MONITOR, RADIATION, EMERGENCY + INSTRUMENTATION, NUCLEAR + MONITOR, RADIATION, ENVIRONMENTAL + PORTSMOUTH PLANT

9-11772 ROUX DP
NUCLEAR TRANSDUCERS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
6 PAGES, 1 TABLES, 2 FIGURES, 21 REFERENCES, NUCLEAR SAFETY 7(2), PAGES 179-184 (WINTER 1965-1966)

TWO TECHNIQUES DEVELOPED TO AVOID THE EFFECTS OF GAMMA RADIATION IN IONIZATION CHAMBERS INTENDED FOR NEUTRON-FLUX MEASUREMENT ARE DISCUSSED. SOME MAJOR LIMITATIONS OF FISSION COUNTERS IN REACTOR APPLICATIONS ARE THE COUNTING-RATE RANGE, THE GAMMA PILEUP, AND THE ELECTRICAL NOISE PICKUP. SEVERAL REPORTS DISCUSSING THESE PROBLEMS AND PROPOSING SOME REMEDIES ARE REVIEWED. SUBMINIATURE IN-CORE IONIZATION CHAMBERS, SELFPOWERED NEUTRON DETECTORS AND SELF-REGENERATING-NEUTRON-SENSITIVE DETECTORS ARE DESCRIBED AND EVALUATED AS IN-CORE NEUTRON MONITORS.

*CHAMBER, COMPENSATED + *CHAMBER, ION + *COUNTER + *NEUTRON + *SELF POWERED FLUX DETECTOR + INSTRUMENTATION, IN CORE + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY

9-11773 HEINRICH LA
GADOLINIUM NITRATE INJECTION AS AN AUXILIARY SHUTDOWN SYSTEM FOR SAVANNAH RIVER REACTORS
SAVANNAH RIVER LABORATORY
5 PAGES, 5 FIGURES, 1 TABLE, NUCLEAR SAFETY 7(2), PP. 175-179 (WINTER 1965-1966)

AUXILIARY SHUTDOWN SYSTEMS ON THE PRODUCTION REACTORS AT SAVANNAH RIVER FUNCTION BY INJECTING A GD(NO3)3-O2O SOLUTION INTO THE MODERATOR. CALCULATIONS SHOW THIS SYSTEM TO BE EFFECTIVE IN

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11773 *CONTINUED*

SHUTTING DOWN THE REACTOR AND KEEPING IT SUBCRITICAL. IN A SPECIAL TEST, A REACTOR WAS SHUT DOWN USING THIS SYSTEM. THE RESPONSE TIME WAS 3.5 SEC. POISON WAS SUBSEQUENTLY REMOVED FROM THE MODERATOR BY ION EXCHANGE.

*SHUTDOWN SYSTEM, SECONDARY + POISON, SOLUBLE + SAFETY INJECTION + SAVANNAH RIVER PRODUCTION REACTORS

9-11838 ROLSTAD E

SECTION 10 - THERMOCOUPLES, CABLES AND TUBES FOR IN-CORE INSTRUMENTS AT HBWR
HPR-35 VOL. II +. 32 PAGES, 26 FIGURES, AUGUST 1964, PAGES 1-32 SECTION 10 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR, VOLUME II, DEP. MN

THE INSTALLATION AND CALIBRATION OF 1 MM OUTSIDE DIAMETER INCONEL SHEATH THERMOCOUPLES IS GIVEN. THE PROCEDURE FOR CALIBRATING THE THERMOCOUPLES WHILE IN-CORE TO PLUS-0.1-MINUS-0.1 C IS GIVEN. CORROSION PROBLEMS ENCOUNTERED WITH 304 SS SHEATHS ARE DISCUSSED. A SPECIFICATION FOR AN EARLY TYPE OF THERMOCOUPLE IS GIVEN.

*INSTRUMENTATION CALIBRATION + *INSTRUMENTATION, IN CORE + *MEASUREMENT, TEMPERATURE + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + INSTRUMENTATION, GENERAL + REACTOR, BOILING WATER

9-11839 ENGEVIK R

SECTION 11 - PRESSURE VESSEL AND IN-PILE PENETRATION SEALS FOR HBWR
HPR-35 VOL. II +. 42 PAGES, 32 FIGURES, 6 TABLES, AUGUST 1964, PAGES 1-42, SECTION 11 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOL. II, DEP. MN

THE PAPER DEALS WITH VARIOUS PRESSURE VESSEL PENETRATION SEALS AS WELL AS SEALS FOR SIGNAL LEADS FROM THE IN-PILE INSTRUMENTS AT HBWR. IN MOST CASES MECHANICAL SEALS PROVIDE A SUCCESSFUL SOLUTION FOR INSTRUMENTATION IN A HEAVY WATER BOILING REACTOR.

*INSTRUMENTATION, IN CORE + CONTAINMENT PENETRATION + HALDEN + INSTRUMENTATION, GENERAL + REACTOR, BOILING WATER

9-11840 OLSON HP

SECTION 12 - IN-PILE BURNOUT PROTECTION AT HBWR
HPR-35 VOL. II +. 35 PAGES, 8 FIGURES, 3 TABLES, AUGUST 1964, PAGES 1-35 SECTION 12 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP. MN

A THERMOCOUPLE INSTALLED IN THE FUEL PELLET CANNING WAS USED TO PROTECT THE FOURTH INSTRUMENTED FUEL ASSEMBLY AT HBWR AGAINST FUEL SURFACE BURNOUT WHEN THE FUEL ASSEMBLY WAS OPERATED AT DOUBLE THE PREVIOUSLY LIMITING SPECIFIC POWER. A DESCRIPTION OF THE DESIGN AND SUPPORTING CALCULATIONS IS GIVEN. THE IN-PILE PERFORMANCE IS REPORTED AND THE APPLICATION OF THIS DEVICE TO SAFELY ATTAIN HIGH CORE POWER IS DISCUSSED.

*BURNOUT HEAT FLUX + *INSTRUMENTATION, PROTECTIVE + ANALYTICAL MODEL + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + HEAT TRANSFER, CONVECTION + INSTRUMENTATION, TEMPERATURE + REACTOR, BOILING WATER

9-11841 KJAERHEIM G

SECTION 13 - CENTRAL OXIDE TEMPERATURE MEASUREMENT AT HBWR
HPR-35 VOL. II +. 34 PAGES, 10 FIGURES, 4 TABLES, AUGUST 1964, PAGES 1-35, SECTION 13 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP. MN

AT 250 KW CHANNEL POWER THE MEASURED IFA-3 CENTRAL OXIDE TEMPERATURE WAS 970 C, AND THE MEASURED IFA-4 TEMPERATURE WAS 1275. THE IFA-4 TEMPERATURE ROSE TO 1900 C WHEN POWER WAS INCREASED TO 490 KW. THE ORIGINAL SAFETY CALCULATIONS UPON WHICH OPERATING LIMITS WERE BASED, GAVE A POSSIBLE CENTRAL TEMPERATURE OF 2900 C (UO₂ MELTING POINT IS 2760 C) IN THE HOTTEST FUEL ELEMENT (ABOUT 250 KW) WITH THE REACTOR OPERATING AT 20 MW. DIRECT GRAPHICAL EXTRAPOLATION OF IFA-4 DATA WOULD INDICATE THAT THE REACTOR COULD OPERATE AT MORE THAN 80 MW WITHOUT MELTING THE HOTTEST PIECE OF UO₂ IN THE REACTOR.

*HEAT CONDUCTION + *INSTRUMENTATION, TEMPERATURE + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + INSTRUMENTATION, IN CORE + REACTOR, BOILING WATER

9-11842 BRUUN A

SECTION 14 - FISSION GAS PRESSURE MEASUREMENT
HPR-35 VOL. II +. 29 PAGES, 11 FIGURES, 2 TABLES, AUGUST 1964, PAGES 1-29, SECTION 14 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP. MN

THE PURPOSES OF THIS PAPER ARE TO REPORT THE DEVELOPMENT OF A FISSION GAS PRESSURE TRANSDUCER INSTALLED IN THE FOURTH INSTRUMENTED FUEL ASSEMBLY, AND TO SUMMARIZE THE RESULTS FROM THE FIRST IN-PILE MEASUREMENTS. MOST OF THE UNSTABLE FISSION GASES PRODUCED IN UO₂ FUEL DECAY SO FAST THAT THEIR MIGRATION OUTSIDE THE FUEL PELLETS IS NOT OFTEN PREDICTED. SOME FRACTION OF THE STABLE FISSION GASES, HOWEVER, WILL PROBABLY DIFFUSE THROUGH THE UO₂, OUT INTO THE SPACE BETWEEN THE FUEL AND CLADDING, AND COULD BUILD UP PRESSURE IN THIS SPACE. IN NEW FUEL ELEMENT DESIGN, EFFORTS ARE BEING MADE TO REDUCE THE NONPRODUCTIVE CAPTURE OF NEUTRONS TO A MINIMUM BY REDUCING THE CLADDING THICKNESS. THE UNIT INSTALLED TO MEASURE THE GAS PRESSURE INSIDE ONE STRINGER OF IFA-4 FUEL HAS RESPONDED IN ACCORDANCE WITH PREDICTIONS OF PRESSURE CHANGES IN THE ABSENCE OF FISSION GASES (NEARLY ZERO EXPOSURE), ALTHOUGH PRESSURE CHANGES WITH POWER ARE GREATER THAN WAS EXPECTED.

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11842 *CONTINUED*
*FISSION GAS RELEASE + *IN CORE MEASUREMENT + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + REACTOR, BOILING WATER

9-11843 HANNAFORD J
SECTION 15 - TIME RESPONSES FROM POWER TO VARIOUS TEMPERATURES IN INSTRUMENTED FUEL ASSEMBLIES
HPR-35 VOL. II +. 32 PAGES, 12 FIGURES, 2 TABLES, AUGUST 1964, PAGES 1-32, SECTION 15 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP MN.

MEASUREMENTS HAVE BEEN MADE TO DETERMINE THE TIME CONSTANTS OF THE FUEL, BURNOUT DETECTOR AND GAMMA THERMOMETERS OF TWO INSTRUMENTED FUEL ASSEMBLIES. THE FUEL TIME CONSTANTS HAVE BEEN DETERMINED AT VARIOUS ELEMENT POWER LEVELS USING CAN AND CENTRAL OXIDE THERMOCOUPLES. DIFFERENCES BETWEEN RESULTS ARE CONSIDERED TO BE DUE TO THE FLUX DEPRESSION AND TEMPERATURE PROFILE DISTORTION WITHIN A FUEL PIN. THIS MAY NECESSITATE, IN SOME DYNAMIC MODELS, THE USE OF TWO DIFFERENT TIME CONSTANTS FOR THE DOPPLER REACTIVITY COEFFICIENT AND HEAT TRANSFER BLOCKS.

*IN CORE MEASUREMENT + *RESPONSE TIME + BURNOUT HEAT FLUX + DOPPLER COEFFICIENT + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + MATHEMATICAL STUDY + OSCILLATOR, REACTIVITY + REACTOR STABILITY + REACTOR, BOILING WATER

9-11844 SIVERTS JG
SECTION 16 - FUEL FAILURE LOCATION IN NATURAL-CIRCULATION BWR BY LOCAL FLUX DEPRESSION AND BY STEAM SAMPLING FROM SEPARATE FUEL ELEMENTS
HPR-35 VOL. II +. 32 PAGES, 12 FIGURES, 2 TABLES, AUGUST 1964, PAGES 1-32, SECTION 16 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP MN

THREE METHODS OF IDENTIFYING OR LOCATING A FAILED FUEL ELEMENT WERE EXPERIMENTALLY INVESTIGATED AT THE HBWR DURING THE PERIOD FROM OCTOBER 1963 TO APRIL 1964 - (1) LOCAL FLUX DEPRESSION COUPLED WITH MONITORING OF THE BULK COOLANT ACTIVITY, (2) SAMPLING AND MONITORING OF THE COOLANT FROM INDIVIDUAL FUEL ELEMENTS, AND (3) INSERTING A SUSPECT FUEL ELEMENT IN A VACUUM FLASK AND SUBSEQUENTLY MONITORING THE EXHAUST AIR FROM THE FLASK. ALL THE METHODS HAD PRACTICAL VALUE, EVEN THOUGH RELATIVELY SIMPLE MONITORING TECHNIQUES WERE APPLIED AS A FIRST STEP.

*INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + INSTRUMENTATION, IN CORE + MEASUREMENT, REACTIVITY + REACTOR, BOILING WATER

9-11845 SVANHOLM K
SECTION 17 - POST SHUTDOWN TEMPERATURE MEASUREMENT ON IFA-4
HPR-35 VOL. II +. 14 PAGES, 11 FIGURES, AUGUST 1964, PAGES 1-14, SECTION 17 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR, VOLUME II, DEP MN

FOR THE FUTURE TEST FUEL ASSEMBLIES THERE WILL BE A TEMPERATURE LIMIT NOT TO BE EXCEEDED IN THE POST SHUTDOWN PERIOD. TO AVOID POSSIBLE CONFUSION OF POST IRRADIATION METALLURGICAL EXAMINATION RESULTS, THIS TEMPERATURE LIMIT CAN BE AS LOW AS 150 C. THE TEMPERATURE WILL DEPEND UPON DECAY POWER OF THE PARTICULAR TEST ELEMENT AND THE COOLING SITUATION. THE DECAY POWER, CAUSING HEATING OF THE FUEL, DEPENDS UPON FUEL ELEMENT GEOMETRY, IN-PILE POWER PRE-HISTORY, AND TIME AFTER SHUTDOWN.

*DECAY HEAT + *INSTRUMENTATION, IN CORE + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + IN CORE MEASUREMENT + REACTOR, BOILING WATER

9-11991 OPERATIONS EXPERIENCE
RURAL COOPERATIVE POWER ASSOCIATION, ELK RIVER, MINNESOTA
COO-651-35 +. 6 PAGES, RURAL COOPERATIVE POWER ASSOCIATION ELK RIVER REACTOR, 46TH MONTHLY OPERATING REPORT, PAGES 9-15, SECTION III, AUGUST 1966, DOCKET NO. 115-1, PDR

SECT. III.- FIVE LEAKY TUBES WERE PLUGGED IN EVAPORATOR 1. (PART E)- CENTER (REGULATING) ROD POSITION AND LINEAR POWER-RANGE INSTRUMENT WAS CALIBRATED AGAINST POWER. AT 14.1 IN., 0.89 MW/IN. (AT 1723 MWD ON CORE II) OBSERVED GREATER THAN THE 0.78 MW/IN. (AT 19,800 MWD ON CORE I). NEAR FULL POWER, A 1 PERCENT CHANGE IN POWER CAUSES A 2 PERCENT CHANGE IN READING BECAUSE OF VARIABLE LEAKAGE-NEUTRON ATTENUATION AS THE PRIMARY PRESSURE VARIES WITH POWER. THE INSTRUMENT ACTS AS A SQUARE-ROOT FLOWMETER DOES (F)-HIGH CHLORIDE CONTENT IN PRIMARY SYSTEM TRACED TO LONG-TERM CHLORIDE FILM BUILDUP IN A COLLECTION TANK, WHICH INCIDENTALLY HAD NO ACCESS PORTS. (G)-STACK MONITOR ALARM SETTING DRIFTED OFFSCALE, DESPITE INSTALLING AIR CONDITIONER FOR BETTER TEMPERATURE CONTROL OF THE CIRCUITS. A BETTER CONTROLLER FOR THE CONTROL ROOM INSTRUMENT AIR CONDITIONER WILL BE INSTALLED, ALONG WITH ALARMS.

CHLORINE + CONTROL ROD CALIBRATION + COOLANT CHEMISTRY + ELK RIVER + INSTRUMENTATION, ABNORMAL INDICATION + INSTRUMENTATION, POWER RANGE + MONITOR, RADIATION, STACK + REACTOR, AEC OWNED + REACTOR, BOILING WATER

9-11993 FRESHLEY MD + WHEELER RG + BATCH JM + HESSON GM
REACTOR-POWER FLUCTUATIONS AT PRTR
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-272 +. 1 PAGE, INVESTIGATION OF THE COMBINED FAILURE OF A PRESSURE TUBE AND DEFECTED FUEL ROD IN PRTR, PAGE 9, MAY 13, 1966, CFSTI \$5.00 CY, \$1.00 MN

TWO REACTOR-POWER FLUCTUATIONS ARE MENTIONED. (1) ANOMALOUS POWER FLUCTUATIONS INCLUDED A 20 PERCENT OVERPOWER TRANSIENT THAT OCCURRED IN 11 SEC DURING INTENDED STEADY-STATE OPERATION.

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-11993 *CONTINUED*

(2) A REACTOR INSTABILITY WAS TRACED TO MECHANICAL PROBLEMS IN THE CONTROL SYSTEM AND ELIMINATED. NUCLEATE BOILING IN THE IN-PILE LOOP MAY HAVE AGGRAVATED THE PROBLEM.

*CONTROL SYSTEM + *REACTOR STABILITY + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST

9-11999 HBWR QUARTERLY PROGRESS REPORT, APRIL TO JUNE 1966
INSTITUTT FOR ATOMENERGI, HALDEN, NORWAY
HPR-68 +. 105 PAGES, 5 REFERENCES, 40 FIGURES, 5 TABLES, AUGUST 1966, CFSTI

THE THICKNESS OF TWO ALUMINUM GASKETS, (SEALING BETWEEN THE VESSEL LID AND FLANGE) HAS BEEN MONITORED SINCE 1958 AND A CONTINUING DECREASE NOTED. THE INCREASE IN GASKET WIDTH INDICATES THAT THE YIELDING MUST BE CAUSED BY A RELATIVE MOVEMENT BETWEEN THE FLANGE AND LID DUE TO THERMAL CYCLING, RESULTING IN A KNEADING EFFECT. GAMMA THERMOMETERS ARE USED TO MEASURE POWER OF INDIVIDUAL FUEL CHANNELS. HOWEVER, THE SIGNAL IS INFLUENCED BY SEVERAL FACTORS REQUIRING CALIBRATION AGAINST FLOW AND TEMPERATURE USE. IN AN EFFORT TO ELIMINATE THE CALIBRATION, A THEORETICAL ANALYSIS OF THE SIGNAL IS GENERATED IN THE ASSEMBLY. INDICATES THAT 50 TO 70 PERCENT IS FROM THE ASSEMBLY CONTAINING THE THERMOMETER.

*OPERATING EXPERIENCE + ALUMINUM + CONTAINMENT, PRESSURE VESSEL + GAMMA + HALDEN + INSTRUMENTATION, IN CORE + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + SEAL

9-12081 JOYCE DE
CAPACITANCE TEMPERATURE SENSOR, FINAL REPORT
GENERAL ELECTRIC, NUCLEAR MATERIALS AND PROPULSION OPERATION, CINCINNATI
GEMP-89 +. 57 PAGES, 56 FIGURES, JUNE 25, 1965, CFSTI \$3.00

THIS REPORT DESCRIBES AN INVESTIGATION OF THE USE OF THE CHANGE OF DIELECTRIC CONSTANT OF CERAMIC CAPACITANCE ELEMENTS AS A MEANS OF MEASURING TEMPERATURE, AND THE INCORPORATION OF SUCH CERAMIC ELEMENTS INTO TWO COMPLETE TEMPERATURE MEASURING SYSTEMS WHICH WERE DEVELOPED FOR SERVICE IN BOTH OXIDIZING AND NONOXIDIZING ATMOSPHERES.

*CERAMICS + *INSTRUMENTATION, TEMPERATURE + *MEASUREMENT, TEMPERATURE + HIGH TEMPERATURE + OXIDATION

9-12082 SWANSON CD + COUGHREN KD + DIONNE PJ + THIEME GG
ANALOG SIMULATION OF THE HANFORD N-REACTOR PLANT PART 1 - DESCRIPTION OF THE OVERALL SIMULATION MODEL
HANFORD ATOMIC PRODUCTS OPERATION, RICHLAND, WASHINGTON
HW-82589 +. 179 PAGES, 79 FIGURES, SEPTEMBER 1, 1964, CFSTI \$4.00 CY

ANALYSES OF THE HANFORD N-REACTOR PLANT-DYNAMIC EQUATIONS INCLUDED ANALOG SIMULATION STUDIES. THE SIMULATIONS, IN GENERAL, REPRESENTED VARIOUS PLANT SUBSYSTEMS OF INTEREST. SIMULATION OF THE REACTOR AND ITS PRINCIPAL COOLANT SYSTEMS AS AN INTEGRATED WHOLE COULD NOT SENSIBLY BE DONE BECAUSE OF THE LIMITED AMOUNT OF COMPUTING EQUIPMENT AVAILABLE. THE PURPOSE OF PART 1 IS TO DESCRIBE THE OVERALL N-REACTOR PLANT-SIMULATION MODEL, WHICH HAS BEEN DESIGNED TO UTILIZE THE CAPABILITIES OF THE PRESENT EXPANDED COMPUTER FACILITY.

*ANALYTICAL MODEL + *REACTOR, GRAPHITE MODERATED + CONTROL SYSTEM + COOLANT SYSTEM + PUMP

9-12086 CARLSON WJ + GUNBY AL
ANALYSIS OF POWER RAMPS WITH AN ANALOG COMPUTER
ATOMICS INTERNATIONAL, CANOGA PARK
NAA-SR-7929 +. 39 PAGES, 11 FIGURES, 2 TABLES, 7 REFERENCES, JUNE 15, 1964, CFSTI \$0.75 CY

ANALYSIS OF POWER RAMPS ON THE SODIUM REACTOR EXPERIMENT BY USE OF THE ANALOG COMPUTER IS A FAST, ACCURATE, AND SIMPLE METHOD FOR DETERMINING THE HEAT TRANSFER PARAMETERS. THIS METHOD REQUIRES A MINIMUM OF REACTOR TIME. RESULTS ON THE SRE CORE II ARE REPRODUCIBLE TO PLUS OR MINUS 5 PERCENT, SHOWING A PROMPT POWER COEFFICIENT OF REACTIVITY OF MINUS 2.05 CENTS/MWT AT 1000 GAL/MIN MAIN PRIMARY FLOW. THE SINGLE-LAG TEMPERATURE FEEDBACK APPROXIMATION IS ADEQUATE FOR MOST OPERATING CONDITIONS OF THE REACTOR.

*ANALYTICAL MODEL + *REACTOR DYNAMICS + *SRE (SODIUM REACTOR EXPERIMENT) + COMPUTER, ANALOG + MEASUREMENT, REACTIVITY + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED

9-12087 THORNGATE JH
AN INTERVAL TIMER DESIGNED FOR USE DURING IRRADIATION AT THE HEALTH PHYSICS RESEARCH REACTOR
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE
ORNL-TM-1559 +. 25 PAGES, 10 FIGURES, 1 TABLE, 3 REFERENCES, AUGUST 1966, CFSTI \$2.00, \$0.50 MF

AN INEXPENSIVE, RELIABLE TIMER HAS BEEN DESIGNED AND CONSTRUCTED THAT ALLOWS REACTOR RUNS TO BE TIMED FROM AN ARBITRARY STARTING POINT FOR PERIODS UP TO 27 HOURS. TIMING PRECISION TO 2.7 HOURS IS 1 SECOND AND IS 10 SECONDS UP TO 27 HOURS. ACCURACY DEPENDS UPON THE CONSTANCY OF THE 60-HERTZ LINE FREQUENCY BUT IS WITHIN ONE CYCLE OF THIS FREQUENCY. MANUAL TIMING OF ARBITRARY REACTOR RUNS IS ALSO POSSIBLE WITH THIS DEVICE AS THE TIMER WILL ALWAYS STOP WHEN A REACTOR SHUTDOWN OCCURS WHETHER OR NOT THE TIMER IS CONTROLLING THE REACTOR.

*INSTRUMENTATION, GENERAL + *MEASUREMENT, GENERAL + HPRR (HEALTH PHYSICS RESEARCH REACTOR) + INSTRUMENTATION, PROTECTIVE + REACTOR, TEST

CATEGORY 9
NUCLEAR INSTRUMENTATION, CONTROL, AND SAFETY SYSTEMS

9-12088 STENTZ RH + TREINEN RL
FINAL REPORT - DEVELOPMENT OF NUCLEAR SENSORS
GENERAL ELECTRIC, NUCLEAR MATERIALS AND PROPULSION OPERATION, CINCINNATI
GEMP-90 +. 50 PAGES, 41 FIGURES, 3 TABLES, JUNE 25, 1965, CFSTI \$3.00 CY

THIS REPORT CONTAINS THE RESULTS OF A PROGRAM TO DEVELOP ADVANCED NUCLEAR SENSORS FOR GENERAL USE IN THE NUCLEAR INDUSTRY FOR MONITORING AND CONTROLLING HIGH TEMPERATURE, HIGH PERFORMANCE REACTORS. MOST OF THE EFFORT CENTERED ON THE DEVELOPMENT OF TWO NEW TYPES OF SENSORS, THE A-C IONIZATION CHAMBER AND THE CHARGED-FRAGMENT DETECTOR.

*INSTRUMENTATION, RADIATION MONITORING + CHAMBER, COMPENSATED + CHAMBER, NEUTRON

9-12091 CARMICHAEL BM + LABAUVE RJ
CONTROL ROD CALCULATION TECHNIQUES WITH APPLICATIONS TO THE UHTREX REACTOR
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
LA-3194 +. 93 PAGES, 19 FIGURES, 13 TABLES, 14 REFERENCES, JUNE 7, 1965, CFSTI \$4.00 CY

TWO-GROUP, MULTIREGION, ANALYTIC CALCULATIONS OF CONTROL ROD WORTHS IN UHTREX ARE COMPARED WITH RESULTS FROM TWO-DIMENSIONAL, DIFFUSION THEORY (GRAM CODE), AND TWO-DIMENSIONAL, S-SUB-N TRANSPORT THEORY (DDK CODE).

*CONTROL ROD WORTH + *UHTREX (ULTRA HIGH TEMP. REACTOR EXPERIMENT) + COMPUTER PROGRAM + MATHEMATICAL STUDY

9-12092 HEARN TO
NRDS ANALYSIS OF THE KIWI B-4D-2C2 NUCLEAR REACTOR CONTROL SYSTEM
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
LA-3301-MS +. 107 PAGES, 47 FIGURES, 12 REFERENCES, SEPTEMBER 20, 1965, CFSTI \$4.00 CY, \$0.75 MN

THE CONTROL SYSTEMS USED WITH THE KIWI B-4D-202 REACTOR SERIES ARE EVALUATED THROUGH THE USE OF AN ANALOG COMPUTER SIMULATION. MODEL CHARACTERISTICS USED WERE, BY AND LARGE, OBTAINED FROM B. G. STRAIT OF N-4. THE THREE MODES OF CONTROL DISCUSSED ARE - AUTOMATIC REACTOR STARTUP, POWER CONTROL, AND POWER-TEMPERATURE CONTROL. A BRIEF ANALYSIS OF THE B-4E-301 TEMPERATURE-CONTROL SYSTEM IS ALSO INCLUDED.

*ANALOG SIMULATION + *CONTROL SYSTEM + *KIWI + INSTRUMENTATION, NUCLEAR + NUCLEAR ROCKET + REACTOR DYNAMICS + REACTOR KINETICS + SERVOMECHANISM

9-12093 HOHMANN GL + STRAIT BG
AUTOMATIC STARTUP FOR NUCLEAR REACTORS
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
LA(MS)-3111 +. 45 PAGES, 18 FIGURES, 2 TABLES, 7 REFERENCES, AUGUST 27, 1964, CFSTI \$4.00 CY

AN AUTOMATIC STARTUP TECHNIQUE FOR NUCLEAR REACTORS WAS SUCCESSFULLY TESTED AND SUBSEQUENTLY USED ON THE KIWI B-4D-202 REACTOR IN MAY 1964. THE STARTUP WAS ACHIEVED AUTOMATICALLY BY PROGRAMMING THE CONTROL RODS OUT RAPIDLY TO THE APPROXIMATE DELAYED-CRITICAL POSITION AND THEN CONTINUING TO MOVE THEM SLOWLY UNTIL THE POWER REACHED A PRESELECTED LEVEL. AT THIS TIME THE POWER CONTROL SYSTEM WAS SWITCHED INTO OPERATION. THUS, THE REACTOR, WAS AUTOMATICALLY BROUGHT FROM A SOURCE POWER LEVEL (ABOUT 4 DOLLARS SUBCRITICAL) THROUGH APPROXIMATELY 6 DECADES OF POWER TO A LEVEL SLIGHTLY ABOVE THE LOW END OF THE OPERATING RANGE OF THE LOGARITHMIC NEUTRON DETECTOR USED FOR FULL-POWER OPERATION.

*CONTROL SYSTEM + *KIWI + ANALOG SIMULATION + REACTOR STARTUP EXPERIENCE, INITIAL + REACTOR, SPACE + ROVER PROGRAM + SERVOMECHANISM

CATEGORY 10
ELECTRICAL POWER SYSTEMS

10-10283. AUSTIN HC
POWER COORDINATION AND RECOVERY
EDISON ELECTRIC INSTITUTE
6 PAGES, AMERICAN POWER CONFERENCE, APRIL 26-28, 1966, CHICAGO, ILLINOIS, APC, \$0.25

FOLLOWING THE POWER INTERRUPTION OF NOVEMBER 9, 1965, THE EDISON ELECTRIC INSTITUTE INITIATED A STUDY OF THE INCIDENT. THE NUMEROUS FACTORS OF SYSTEM AND INTERCONNECTION DESIGN AND OPERATION WHICH RELATED TO THE OUTAGE AND RECOVERY OF SERVICE WERE ASSESSED, AND LESSONS TO BE LEARNED FROM THE WIDESPREAD INTERRUPTION WERE CONSIDERED. THESE FINDINGS WERE THEN USED IN A REEVALUATION OF THE BASIC PRINCIPLES AND PRACTICES FOLLOWED IN THE COORDINATION OF ELECTRIC UTILITY SYSTEMS.

*ELECTRIC POWER, AUXILIARY + *ELECTRIC POWER, GENERAL + *ELECTRIC POWER, SHUTDOWN +
*EMERGENCY POWER, ELECTRIC + *RELIABILITY, SYSTEM + DESIGN CRITERIA

10-10457 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 2 PAGES, DOCKET 115-5, JUNE 1966, PP. V-11-1 THROUGH V-11-2, AMENDMENT NO. 25, PDR

QUESTION V-11. DISCUSSES SUPPLYING VITAL BUS FROM RESERVE AUXILIARY TRANSFORMER FOLLOWING TURBINE GENERATOR LOSS, USING AN AUTO TRANSFER SWITCH. SUGGESTS ALTERNATE SPLITTING OF LOADS IF DRL DESIRES ESSENTIAL BUS ALWAYS BE FED FROM RESERVE AUXILIARY TRANSFORMER, BUT PREFERS REDUNDANCY AND SWITCHOVER.

*ELECTRIC POWER, VITAL + *INSTRUMENTATION, SWITCH + *LACROSSE BOILING WATER REACTOR +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + LOSS OF POWER + REACTOR, BOILING WATER

10-10905 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES, 1 FIGURE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 10. ON LOSS OF POWER, 3 HALF-CAPACITY DIESELS WILL START. ON COMING TO SPEED, REQUIREMENT FOR SAFEGUARD SYSTEM OPERATION WILL CLOSE BREAKERS CONNECTING DIESELS TO FOUR 480-V BUSES, STARTING EQUIPMENT ON THAT BUS. TYPICAL EXPERIMENT - CONTAINMENT VENT FANS (5), SAFETY INJECTION PUMPS (3), SERVICE WATER PUMPS (3), CONTAINMENT SPRAY PUMPS (2), RESIDUAL-HEAT-REMOVAL PUMPS (2), AND TWO MOTOR-CONTROL CENTERS FOR VALVES.

*EMERGENCY POWER, ELECTRIC + *ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + REACTOR, PRESSURIZED WATER

10-10908 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 13 -- DESCRIBES WATER SUPPLY AND PUMPING TO STEAM GENERATOR UPON A COMPLETE LOSS OF POWER. STORAGE FOR 24 HP AT LEAST WILL BE MAINTAINED IN THE CONDENSATE STORAGE TANK, WITH CONNECTIONS TO MAKEUP OR CITY-WATER STORAGE. BACKUP CAN BE POWERED FROM DIESELS. AN EMERGENCY, TURBINE-DRIVEN FEED PUMP IS PROVIDED (STARTED ON LOSS OF FLOW) AND SIZED SO THE TUBES WILL NOT BE UNCOVERED. STEAM FROM THE STEAM GENERATOR RUNS TURBINE.

*DECAY HEAT + *EMERGENCY POWER, NONELECTRIC + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + LOSS OF POWER + REACTOR, PRESSURIZED WATER

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-07744 REYER RJ
CONTAINMENT TESTING IN HIGH FLUX BEAM REACTOR
BROOKHAVEN NATIONAL LABORATORY
2 PAGES, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 39-40

A STEEL-DOME SYSTEM IS DESIGNED FOR LESS THAN 5 PERCENT LEAKAGE PER DAY AT 2 PSIG. VARIOUS LEAKS WERE FOUND BY SIMPLE LISTENING AND WITH SONIC DETECTORS. SMOKE WAS USELESS. LEAKS WERE FOUND AT DOOR FRAMES, CONCRETE JOINTS, UNPAINTED CONCRETE, UNWELDED PIPE PENETRATIONS.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + HFBR (HIGH FLUX BEAM REACTOR) + REACTOR, RESEARCH

11-07745 ERION TL + ROTH JM
CONTAINMENT VESSEL INTEGRATED LEAK-TEST EXPERIENCE AT THE SAXTON NUCLEAR EXPERIMENTAL REACTOR
WESTINGHOUSE ATOMIC POWER DIVISION, MADISON, PA. + SAXTON NUCLEAR EXPERIMENTAL CORP.
1 PAGE, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 40

TESTED IN APRIL 1964 AS LESS THAN 0.4 PERCENT/24 HR AT 30 PSIG, BY RATIOING THE TEST AT 24.7 PSIA. A CONTROLLED LEAK WAS ALSO INTRODUCED. VARIOUS TEMPERATURE GRADIENTS OCCURRED. ALSO, AMBIENT TEMPERATURES CHANGED.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + REACTOR, PRESSURIZED WATER + SAXTON

11-07746 WHITHAM GK + TEBO FJ + MCGINNIS FD
FRR-II REACTOR BUILDING LEAK TESTING
ARGONNE NATIONAL LABORATORY, IDAHO
2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 40-41

A 3-DAY LEAK TEST SHOWED LESS THAN 100 CU FT/DAY AT 36.2 PSIA, AFTER ALL OPERATIONAL DOORS INSTALLED. SINCE THEN, YEARLY TESTS HAVE BEEN ON MAJOR PENETRATIONS AND RANDOMLY CHOSEN ELECTRICAL PENETRATIONS. THEY PROPOSE TO ADOPT 8 OF 24 ELECTRICAL PENETRATIONS FOR TESTING, INSTEAD OF RANDOM TESTING, WHICH DISRUPTS OPERATIONS.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

11-09307 INTERIM ANALYSIS OF NFS STACK CRACK AND VIBRATION PROBLEMS, MARCH 25, 1966
NUCLEAR FUEL SERVICES, INC.
3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 35-37, APRIL 11, 1966, DOCKET NO. 50-201

NFS STEEL STACK WAS PROTECTED AGAINST VORTEX-INDUCED VIBRATIONS BY SMALL RADIAL FINS. IN NOVEMBER 1964, SUSTAINED GUSTS VIBRATED STACK, AND METAL YIELDED. SPOILERS COULD NOT PROTECT AGAINST GUSTS, SO CONCRETE SHEATH ADDED AFTER STACK EXAMINED AND FOUR BASE LUGS REPAIRED. LATER, A CIRCUMFERENTIAL CRACK DEVELOPED AT THE CYLINDRICAL/CONICAL JUNCTION DUE TO FATIGUE, POOR WELDING, AND STRESS CONCENTRATION. THIS WELD WAS NOT GIVEN A THOROUGH INSPECTION PRIOR TO CONCRETE SHEATH. NOW ALL CIRCUMFERENTIAL WELDS ARE BEING TESTED WITH DYES AND ULTRASONIC DEVICES.

*FAILURE, FATIGUE + *STACK + *WELDING + FAILURE, ADMINISTRATIVE CONTROL + FAILURE, DESIGN ERROR + NUCLEAR FUEL SERVICES (NFS) + OPERATING EXPERIENCE + RADIOCHEMICAL PROCESSING + WIND STATISTICS

11-09604 HALFORD GR
THE ENERGY REQUIRED FOR FATIGUE
UNIVERSITY OF ILLINOIS
16 PAGES, 4 TABLES, 3 FIGURES, JOURNAL OF MATERIALS, 1(1), PP. 3-18 (MARCH, 1966)

PLASTIC STRAIN HYSTERESIS ENERGY (FATIGUE TOUGHNESS) WAS PLOTTED VERSUS NUMBER OF CYCLES TO FAILURE FOR 36 PREVIOUS INVESTIGATIONS. THE FATIGUE TOUGHNESS OF ALL METALS INCREASES APPROXIMATELY AS THE 1/3 POWER OF FATIGUE LIFE. FATIGUE TOUGHNESS VALUES ARE LOW FOR METALS THAT (1) ARE CAST, (2) HAVE A LOW MODULUS OF ELASTICITY, (3) ARE THERMALLY CYCLED, OR (4) ARE STRAIN CYCLED ABOUT A RELATIVELY LARGE TENSILE MEAN STRAIN. A BRIEF REVIEW IS PRESENTED OF THE UNIFYING RELATIONSHIPS BETWEEN STRESS RANGE, PLASTIC STRAIN RANGE, PLASTIC STRAIN HYSTERESIS ENERGY, AND FATIGUE LIFE.

*FAILURE, FATIGUE + *METAL + CONTAINMENT INTEGRITY + PLASTICITY + STRESS

11-09687 630A MARK V MARITIME NUCLEAR STEAM GENERATOR STATUS REPORT. ROUGH DRAFT
GENERAL ELECTRIC, ADVANCED TECHNOLOGY SERVICES
GEMP-342 +. 231 PAGES, FEBRUARY 26, 1965, CFSTI, \$6.00 CY

INCLUDED IN THIS REPORT ARE DETAILED DESCRIPTIONS OF 630A, PRESSURE VESSEL, CONTAINMENT, ACCESSORIES, AND A SAFETY ANALYSIS INCLUDING THE REFUELING ACCIDENT AND A REFUELING ACCIDENT. APPENDED ARE SPECIFICATIONS AND OPERATING CONDITIONS, AND OPERATING AND SAFETY PARAMETERS AND ACTIONS.

*ACCIDENT ANALYSIS + *ACCIDENT, REFUELING + *CONTAINMENT, GENERAL + *MAINTENANCE AND REPAIR + *REACTOR, MARITIME + *WASTE HANDLING + *630A (MARITIME REACTOR) + ACCIDENT, CONSEQUENCES + ACCIDENT, CONTROL ROD WITHDRAWAL + CONTAINMENT LEAKAGE CONTROL + CONTAINMENT, PRESSURE VESSEL +

ACCESSION NUMBER 11-07744 TO 11-09687

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-09687 *CONTINUED*
EXCURSION; LARGE + LOSS OF COOLANT + LOSS OF FLOW + OPERATIONS REPORTS, GENERAL + REACTOR DESCRIPTION + REACTOR, GAS COOLED

11-09750 ROBINSON GC + HORTON TR
LEAK TESTING OF REACTOR CONTAINMENT SYSTEMS
OAK RIDGE NATIONAL LABORATORY + UNIVERSITY OF NORTH CAROLINA
10 PAGES, 3 TABLES, REFERENCES, NUCLEAR SAFETY, 7(2), PP. 194-203 (WINTER 1965-1966)

THE ARTICLE COMPILES AND DISCUSSES DATA ON DESIGN, LEAK TESTING, AND LEAK-RATE TESTING OF PRESSURE-TIGHT CONTAINMENT SYSTEMS. EMPHASIS IS PLACED ON COMPARISON OF THE VARIOUS CONTAINMENT DESIGNS AND HISTORY OF LEAK-RATE TESTING. METHODS OF ANALYSIS OF LEAK-RATE TESTING BY THE VARIOUS CONTAINMENT OPERATORS ARE PRESENTED. CURRENT RETESTING SCHEDULES ARE ALSO PRESENTED AND DISCUSSED.

*CONTAINMENT ABSOLUTE MEASURING SYSTEM + *CONTAINMENT LEAKAGE CONTROL +
*CONTAINMENT REFERENCE MEASURING SYSTEM + *CONTAINMENT STRUCTURE + *TEST, LEAK LOCATION +
*TEST, LEAK RATE + CONTAINMENT, HIGH PRESSURE + CONTAINMENT, LOW PRESSURE +
CONTAINMENT, PRESSURE SUPPRESSION + CONTAINMENT, PRESSURE VENTING + REACTOR, ARMY +
REACTOR, BOILING WATER + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED + REACTOR, HEAVY WATER +
REACTOR, LIQUID METAL COOLED + REACTOR, ORGANIC COOLED + REACTOR, PRESSURE TUBE +
REACTOR, PRESSURIZED WATER + REACTOR, SUPERHEAT + REACTOR, TEST

11-09756 CROWTHER H
IMPROVEMENTS IN OR RELATING TO PRESSURE VESSELS
ATOMIC POWER CONSTRUCTIONS LTD.
BRITISH PAT. 1,022,447 +. 4 PAGES, MARCH 1966 (FILED OCTOBER 5, 1961), PATENT (BRITISH)

A FLANGED JOINT IS PROVIDED THAT IS PARTICULARLY SUITABLE FOR REACTOR PRESSURE AND IS SUBSTANTIALLY FREE FROM STRESSING CAUSED BY EITHER THE FORCES KEEPING THE PARTS OF THE JOINT TOGETHER OR BY THE LARGE INTERNAL PRESSURE OR TEMPERATURE DIFFERENCES THAT MAY OCCUR BETWEEN THE DIFFERENT PARTS OF THE JOINTS AND THE PRESSURE VESSEL. EACH PART OF THE FLANGED JOINT HAS A FLANGE WITH A CONTACT SURFACE FOR EFFECTING AN AREA OF SEALING CONTACT WITH EACH OTHER. EACH FLANGE IS PROVIDED WITH A SET OF THRUST MEMBERS ABUTTING ON THE PERIPHERY OF THE FLANGES. A FIRST SET OF TENSION MEMBERS EXTEND OBLIQUELY FROM THE FIRST FLANGE TO THE SECOND SET OF THRUST MEMBERS, AND A SECOND SET OF TENSION MEMBERS EXTEND OBLIQUELY FROM THE SECOND FLANGE TO THE FIRST SET OF THRUST MEMBERS. SPACING MEMBERS ARE PROVIDED BETWEEN THE THRUST MEMBERS OF EACH SET.

*FLANGE + *STRESS + CONTAINMENT, PRESSURE VESSEL + SEAL + STEEL

11-09759 IRVINE WH + BEVITT E + QUIRK A
SAFETY OF PRESSURE VESSELS AGAINST FAST FRACTURE
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
AHSB(S)-R-107 +. 13 PAGES, 1966, BIS \$0.60

THE HISTORICAL BACKGROUND OF THE U.K.A.E.A. PRESENT RESEARCH PROGRAM ON CYCLIC CRACK GROWTH AND FAST FRACTURE IN PRESSURE VESSELS IS GIVEN, AND THE SIGNIFICANCE AND APPLICATION OF THE EXPERIMENTAL RESULTS FROM THIS PROGRAM IN RELATION TO REACTOR SAFETY DISCUSSED.

*CONTAINMENT, PRESSURE VESSEL + *FAILURE, PRESSURE VESSEL + BRITTLE FRACTURE + STEEL

11-09772 IMPROVEMENTS IN OR RELATING TO BUILDINGS SUITABLE FOR HOUSING NUCLEAR REACTOR INSTALLATIONS
SIEMENS-SCHUCKERTWERKE AKTIENGESellschaft, GERMANY
BRITISH PAT. 1,010,180 +. 6 PAGES, 4 FIGURES, NOVEMBER 17, 1965, PATENT (FOREIGN)

THE INVENTION IS A BUILDING SUITABLE FOR HOUSING A NUCLEAR REACTOR AND COMPRISING A HOLLOW, ROTATIONALLY SYMMETRICAL BODY HAVING A HORIZONTAL OR SUBSTANTIALLY HORIZONTAL AXIS OF REVOLUTION, AND AN ACCURATE GENERATRIX WHICH DOES NOT CUT THE SAID AXIS, THE BODY BEING OF GREATER EXTENT, AT RIGHT ANGLES TO THE SAID AXIS, BETWEEN THOSE OPPOSED ENDS OF THE BODY THAT ARE ON THE SAID AXIS THAN IT IS AT THE SAID ENDS. A BUILDING OF THIS FORM CAN BE GIVEN AN ADEQUATE HEIGHT AND A GROUND PLAN WHICH CAN BE COVERED BY A NORMAL GENTRY CRANE. IT CAN ALSO BE RESISTANT TO EXTERNAL POSITIVE PRESSURE. A VERY ADVANTAGEOUS RATIO OF GROUND PLAN TO TOTAL VOLUME CAN BE OBTAINED. THE LARGE VOLUME IN THE EVENT OF AN ACCIDENT YIELDS A LOWER RISE IN PRESSURE THAN IN CONVENTIONAL REACTOR BUILDINGS.

*CONTAINMENT DESIGN + *CONTAINMENT, HIGH PRESSURE + CONCRETE, PRESTRESSED + STEEL + STRESS

11-09773 KNIGHTS HC
INTEGRAL NUCLEAR REACTOR
UNITED KINGDOM ATOMIC ENERGY AUTHORITY
BRITISH PAT. 1,011,639 +. 3 PAGES, 1 FIGURE, DECEMBER 1, 1965, PATENT (FOREIGN)

THE INVENTION IS AN INTEGRAL NUCLEAR REACTOR HAVING A CONTAINMENT VESSEL ENCLOSING THE PRESSURE VESSEL AND HAVING A SEALABLE OPENING IN THE CONTAINMENT VESSEL THROUGH WHICH THE PRESSURE VESSEL CAN BE WITHDRAWN AS A UNIT CHARACTERISED BY INLET AND OUTLET MANIFOLDS OUTSIDE THE PRESSURE VESSEL TO WHICH THE HEAT EXCHANGER WITHIN THE PRESSURE VESSEL IS CONNECTED, INLET AND OUTLET PIPES PENETRATING THE CONTAINMENT VESSEL, AND BREAKABLE CONNECTIONS BETWEEN THE INLET AND OUTLET MANIFOLDS AND INLET AND OUTLET PIPES RESPECTIVELY, THE BREAKABLE CONNECTIONS BEING SO POSITIONED THAT, AFTER BREAKING THE BREAKABLE CONNECTIONS,

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-09773 *CONTINUED*

THE MANIFOLDS CAN BE WITHDRAWN THROUGH THE SEALABLE OPENING WITH THE PRESSURE VESSEL.

*CONTAINMENT, HIGH PRESSURE + *CONTAINMENT, PRESSURE VESSEL + FLANGE + METAL + SEAL

11-09774 BUSSI J

DEFORMABLE SEALING JOINT BETWEEN THE CYLINDRICAL PART AND AN END OF THE CAISSON OF A NUCLEAR REACTOR
COMMISSARIAT A L ENERGIE ATOMIQUE, FRANCE
BRITISH PAT. 1,012,263 +. 6 PAGES, 2 FIGURES, DECEMBER 8, 1965, PATENT (FOREIGN)

THE INVENTION RELATES TO A SEALING JOINT WHICH IS PARTICULARLY ALTHOUGH NOT EXCLUSIVELY USEFUL FOR PROVIDING A SEAL BETWEEN THE INTERIOR AND THE EXTERIOR OF A PRESSURE VESSEL, SUCH AS A PRESSURE VESSEL IN A NUCLEAR REACTOR. SINCE THE PRESSURE FORCES AND TEMPERATURE EXPANSION FORCES INSIDE THE REACTOR ARE NOT THE SAME FOR THE CYLINDER AND FOR THE ENDS, IT HAS HERETOFORE BEEN NECESSARY TO PROVIDE A FLOW OF COOLING FLUID ON THE INSIDE SURFACE OF THE SEALING SKIN IN ORDER TO LIMIT THE TEMPERATURE OF THE CONCRETE AND REDUCE DIFFERENTIAL EXPANSIONS. IT IS AN OBJECT OF THIS INVENTION TO OBLIATE THESE DISADVANTAGES AND PROVIDE A DEFORMABLE SEALING JOINT.

*CONTAINMENT, PRESSURE VESSEL + *FLANGE + *SEAL

11-09821 SPRUCE TW

CONCRETE PRESSURE VESSEL
NUCLEAR POWER PLANT COMPANY LTD. + A.E.I. - JOHN THOMPSON NUCLEAR ENERGY
BRITISH PAT. 1,014,872 +. 3 PAGES, 4 FIGURES, DECEMBER 1965 (FILED JUNE 8, 1962), PATENT (BRITISH)

THIS CONCRETE PRESSURE VESSEL FOR A NUCLEAR REACTOR INCLUDES A LINER ON ITS INNER SURFACE THAT IS KEVED TO THE CONCRETE BY KEYS IN THE FORM OF RIBS PROJECTING FROM AND EXTENDING OVER THE OUTER SURFACE OF THE LINER SO THAT THE LINER AND CONCRETE ARE RIGIDLY SECURED TOGETHER, AT LEAST OVER CERTAIN REGIONS OF THE VESSEL. VARIOUS ARRANGEMENTS FOR THE KEYS ARE DESCRIBED IN DETAIL. COOLING PIPES FOR COOLING THE LINER ARE SECURED TO THE KEYS. THE PRESSURE VESSEL IS PARTICULARLY SUITABLE FOR USE WITH A GAS-COOLED GRAPHITE-MODERATED REACTOR.

*CONTAINMENT, PRESSURE VESSEL + *STEEL LINER + AUXILIARY COOLING SYSTEM + CONCRETE, PRESTRESSED + DESIGN CRITERIA

11-09860 ENGLAND GL

STEADY-STATE STRESSES IN CONCRETE STRUCTURES SUBJECTED TO SUSTAINED TEMPERATURES AND LOADS. PART II. CASES OF THREE DIMENSIONAL STRESS - HOLLOW CYLINDER AND HOLLOW SPHERE
KINGS COLLEGE, LONDON, ENGLAND
10 PAGES, 3 FIGURES, NUCLEAR ENGINEERING AND DESIGN, 3(2), PP. 246-255 (FEBRUARY/MARCH 1966)

THE STRESSES IN A THICK-WALLED HOLLOW CYLINDER AND IN A THICK-WALLED HOLLOW SPHERE ARE ANALYZED UNDER CONDITIONS OF INTERNAL AND EXTERNAL PRESSURE, TEMPERATURE GRADIENT, AND THERMAL CREEP. THESE MODELS REPRESENT PRESTRESSED CONCRETE PRESSURE VESSELS FOR REACTORS. THE TIME-DEPENDENT STRESS-STRAIN EQUATIONS ARE SO FORMULATED THAT CREEP STRAIN RATES ARE EXPRESSED BY EQUATIONS OF THE SAME FORM AS HOOKE'S LAW, WITH ϵ BEING REPLACED BY THE RECIPROCAL OF TEMPERATURE. ONLY SMALL ERRORS ARE BELIEVED TO RESULT IF POISSON'S RATIO IS GIVEN ITS INITIAL ELASTIC VALUE. ELASTIC UNLOADING DUE TO COOLING IS SHOWN TO CAUSE TENSILE STRESSES AT THE INSIDE SURFACES, WHICH INITIALLY CARRIED THE HIGHEST COMPRESSIVE STRESSES. A GENERALIZATION OF THE STRESS-STRAIN EQUATIONS TO THREE DIMENSIONS SEEMS POSSIBLE.

*CONCRETE + *CONCRETE, PRESTRESSED + *CREEP BEHAVIOR + *TEMPERATURE GRADIENT + COMPUTER PROGRAM + CONTAINMENT STRUCTURE + HIGH TEMPERATURE + STRESS + STRESS ANALYSIS

11-09861 CORUM JM

A THEORETICAL AND EXPERIMENTAL INVESTIGATION OF THE STRESSES IN A CIRCULAR CYLINDRICAL SHELL WITH AN OBLIQUE EDGE
OAK RIDGE NATIONAL LABORATORY
25 PAGES, 28 FIGURES, 9 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(2), PP. 256-280 (FEBRUARY/MARCH 1966)

A BASIC PROBLEM IN PRESSURE-VESSEL DESIGN IS THE ANALYSIS OF A NONRADIALLY ATTACHED NOZZLE. AN APPROXIMATE MEANS OF EXAMINING THE STRESSES IN THE NOZZLE PORTION OF A NONRADIAL ATTACHMENT IS TO USE A CYLINDRICAL SHELL ATTACHED OBLIQUELY TO A THICK PLATE. THIS CONFIGURATION HAS BEEN INVESTIGATED ANALYTICALLY AND EXPERIMENTALLY. THE ANALYSIS ASSUMES THAT THE TOTAL STRESS STATE IS APPROXIMATELY THE SUM OF A MEMBRANE STRESS STATE, A PURE BENDING STRESS STATE, AND AN EDGE EFFECT. EXPERIMENTS WERE PERFORMED ON AN EPOXY RESIN MODEL. AGREEMENT BETWEEN THEORY AND EXPERIMENT WAS GOOD. DIFFERENCES ARE IDENTIFIED AND DISCUSSED.

*CONTAINMENT, PRESSURE VESSEL + *MEASUREMENT, STRAIN GAGE + *SHELL + CONTAINMENT STRUCTURE + ELASTICITY + PIPING + STRESS + STRESS ANALYSIS + TEST, PRESSURE VESSEL

11-09862 FISTEDIS SH

A NEW REACTOR CONTAINMENT CONCEPT BY ENERGY ABSORPTION
ARGONNE NATIONAL LABORATORY
6 PAGES, 2 FIGURES, 4 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(2), PP. 281-286 (FEBRUARY/MARCH 1966)

IT IS SUGGESTED THAT THE CONVENTIONAL CONCRETE BIOLOGICAL SHIELD OF A POWER REACTOR CAN FUNCTION ALSO AS A BLAST SHIELD IF IT IS PRESTRESSED WITH HIGH-STRENGTH STEEL STRANDS. A

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-09862 *CONTINUED*

SECONDARY CONTAINMENT SHELL WOULD STILL BE PART OF THE CONTAINMENT SYSTEM. AFTER DEDUCTING ENERGY LOSSES DUE TO HEAT TRANSFER AND DISTORTION OF THE PRIMARY SYSTEM, THE ACCIDENT ENERGY IS EQUATED TO A CERTAIN FRACTION OF THE ULTIMATE STRAIN ENERGY OF THE PRESTRESSING SYSTEM. THE CONCRETE SERVES THE FUNCTION OF HOLDING THE STEEL IN PLACE. PRELIMINARY DESIGN WORK BASED ON THIS CONCEPT HAS BEEN DONE.

*CONCRETE, PRESTRESSED + *PLASTICITY + CONCRETE + CONTAINMENT DESIGN + SHOCK ABSORBER

11-09863 HOUSNER GW + HUDSON DE

EARTHQUAKE RESEARCH PROBLEMS OF NUCLEAR POWER PLANTS
CALIFORNIA INSTITUTE OF TECHNOLOGY, PASADENA

12 PAGES, 4 FIGURES, 28 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(2), PP. 308-319 (FEBRUARY/MARCH 1966)

CONSIDERING THE PROJECTED GROWTH OF NUCLEAR POWER, THE COST OF REDUCING THE MAJOR UNCERTAINTIES ASSOCIATED WITH THE EARTHQUAKE-RESISTANT DESIGN OF NUCLEAR STRUCTURES WILL BE LESS THAN THE COST OF OVERDESIGNING THESE STRUCTURES TO COMPENSATE FOR PRESENT UNCERTAINTIES. SPECIFIC PROBLEMS REQUIRING RESEARCH ARE - (1) PREDICTION OF GROUND MOTION, (2) DESCRIPTION OF GROUND MOTION, (3) CALCULATION OF STRUCTURAL RESPONSE, (4) DETERMINATION OF ACTUAL DYNAMIC PROPERTIES OF STRUCTURES, AND (5) DESIGN. GROUND MOTION MAY BE MODIFIED BY LOCAL GEOLOGY. MANY NUCLEAR PLANTS WILL BE BUILT AT LESS THAN IDEAL SITES. FULL-SCALE RESONANCE TESTS ARE RECOMMENDED. SOME LARGE SHAKER TABLES HAVE BEEN BUILT. BASIC STUDIES OF SOIL DYNAMICS ARE ALSO RECOMMENDED.

*CONTAINMENT, PRESSURE VESSEL + *EARTHQUAKE + *GEOLOGICAL CONSIDERATION, GENERAL + CONTAINMENT, GENERAL + SHOCK WAVE

11-09864 BAKER AL

PRESTRESSED CONCRETE REACTOR PRESSURE VESSEL MODEL TESTS
UNIVERSITY OF LONDON, IMPERIAL COLLEGE OF SCIENCE AND TECHNOLOGY

2 PAGES, 1 FIGURE, NUCLEAR ENGINEERING AND DESIGN, 3(2), PP. 363-364 (FEBRUARY/MARCH 1966)

A MODEL PRESTRESSED CONCRETE PRESSURE VESSEL TEST IS DESCRIBED. BOTH PRESSURE AND THERMAL LOADING WERE APPLIED. THE MODEL SCALE WAS 11.5 TO 1. HYDRAULIC PRESSURE WAS APPLIED THROUGH A RUBBER MEMBRANE. THERMAL LOADING WAS APPLIED BY MEANS OF EMBEDDED RESISTANCE-HEATED WIRES. THE MAXIMUM TEMPERATURE DIFFERENCE APPLIED WAS 85 DEGREES C.

*CONCRETE, PRESTRESSED + *CONTAINMENT, PRESSURE VESSEL + *TEST, PRESSURE VESSEL + CONCRETE + CONTAINMENT, GENERAL + CREEP BEHAVIOR + HIGH TEMPERATURE + MEASUREMENT, STRAIN GAGE + PRESSURE, INTERNAL + TEMPERATURE GRADIENT

11-09917 GROZIN BD + CHERNENKO VS

POSSIBILITY OF STRENGTHENING STEEL BY ELECTRON BOMBARDMENT

JPRS-32107 + TT-65-32600 +. 7 PAGES, SEPTEMBER 22, 1965, TRANSLATED FROM DOPOVIDI AKADEMIYI NAUK UKRAYINSKOYI RSR, (2), PAGES 202-5 (1963), CFSTI, \$1.00 CY, \$0.50 MN

THEORETICAL CONSIDERATIONS PERMIT THE POSSIBILITY OF STRENGTHENING STEEL BY ELECTRON BOMBARDMENT. EXPERIMENTS HAVE CONFIRMED THE CORRECTNESS OF THIS PREMISE. THE HARDNESS OF STEEL IS RAISED TO 900-950 KG/MM SQUARED BY ELECTRON BOMBARDMENT. THE IRRADIATED ZONE HAS A SPECIFIC MICROSTRUCTURE.

*RADIATION EFFECT + *STEEL + *TENSILE PROPERTY + ALLOY + CREEP PROPERTY + RADIATION DAMAGE + X-RAY

11-09918 SMITH BE

AN X-RAY STUDY OF FISSION FRAGMENT DAMAGE IN STEELS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

5 PAGES, 4 TABLES, 1 FIGURE, 11 REFERENCES, JOURNAL OF NUCLEAR MATERIALS, 17(1), PAGES 167-171 (1965)

LATTICE-PARAMETER MEASUREMENTS WERE MADE ON STEELS BOMBARDED WITH FISSION FRAGMENTS AT ABOUT 60 C. THE RESULTS FOR ONE AUSTENITIC STEEL (CR, 20 WT PERCENT, NI, 20 WT PERCENT, NB, 0.44 WT PERCENT) ARE DISCUSSED IN CONJUNCTION WITH PUBLISHED RESULTS OBTAINED BY ELECTRON MICROSCOPY AND ARE CONSIDERED CONSISTENT WITH THE HYPOTHESIS THAT THE PROPORTION OF SMALL DEFECTS IN THIS STEEL IS GREATEST WHEN IRRADIATION DOSE RATES ARE HIGH. IN TWO OTHER AUSTENITIC STEELS (CR, 18 WT PERCENT, NI, 37 WT PERCENT) AND (CR, 18 WT PERCENT, NI, 12 WT PERCENT) AND A FERRITIC STEEL (CR, 15 WT PERCENT, NI, 5 WT PERCENT), A MEASURABLE PROPORTION OF SMALL DEFECTS WAS PRESENT AFTER IRRADIATION AT A DOSE RATE INTERMEDIATE BETWEEN THE TWO USED FOR THE 20/20 AUSTENITE.

*ALLOY + *RADIATION DAMAGE + *STEEL + ELECTRON MICROSCOPY + RADIATION EFFECT + X-RAY

11-09919 BROTHERS AJ + NEWHOUSE DL + WUNDT BM

RESULTS OF BURSTING TESTS OF ALLOY STEEL DISKS AND THEIR APPLICATION TO DESIGN AGAINST BRITTLE FRACTURE
GENERAL ELECTRIC COMPANY, SCHENECTADY, NEW YORK

18 PAGES, 11 FIGURES, 3 TABLES, 13 REFERENCES, ASTM 68TH ANNUAL MEETING, LAFAYETTE, INDIANA, JUNE 13-18, 1965, SOURCE

REPORT PRESENTS THE RESULTS OF BURST TESTS OF NOTCHED AND NITRIDED ALLOY STEEL DISKS AND PROPOSES A DESIGN PROCEDURE AGAINST BRITTLE FRACTURE, USING THE RESULTS OF THESE TESTS.

*ALLOY + *BRITTLE FRACTURE + *NITRIDE + *STEEL + *TESTING + PROCEDURES AND MANUALS + TEST, DESTRUCTIVE

ACCESSION NUMBER 11-09862 TO 11-09919

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-09920 COWAN A
METALLURGICAL TESTING AT CULCHETH
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, REACTOR MATERIALS LABORATORY, CULCHETH
4 PAGES, 3 FIGURES, ATOM(112), PAGES 33-36 (FEBRUARY, 1966)

A LARGE PROPORTION OF THE WORK AT THE REACTOR MATERIALS LABORATORY IS METALLURGICAL, AND EXTENSIVE FACILITIES HAVE BEEN DEVELOPED TO ALLOW FULL-SCALE INVESTIGATIONS OF THE BEHAVIOUR OF METALS RANGING IN SECTION FROM THIN FOIL TO THICK STEEL PLATES. IN ADDITION TO CONVENTIONAL TESTS, EQUIPMENT HAS BEEN DEvised TO GIVE BETTER SIMULATION OF ACTUAL SERVICE CONDITIONS, ESPECIALLY WHERE APPLICATION OF NORMAL TEST DATA IS INADEQUATE OR EVEN UNREALISTIC. IN SEVERAL CASES THIS INCLUDED TESTS ON EITHER THE FULL-SIZE COMPONENT OR LARGE SAMPLES, NECESSARY TO BE REASONABLY REPRESENTATIVE OF THE FINAL PRODUCT. CREEP TESTING. BRITTLE FRACTURE TESTS. TESTS ON MODEL VESSELS. POSTIRRADIATION TESTING FACILITIES. OTHER FACILITIES.

*EQUIPMENT DESIGN + *METAL + *TESTING + BRITTLE FRACTURE + CORROSION + CREEP PROPERTY + IMPACT PROPERTY + RADIATION EFFECT + TENSILE PROPERTY + TEST, PRESSURE VESSEL

11-09921 JABLONOWSKI EJ + RITZMAN RL + DEMASTRY JA
FISSION-FRAGMENT EFFECTS IN STRUCTURAL MATERIALS. QUARTERLY PROGRESS REPORT, JULY-SEPTEMBER 1965
HAYELLE MEMORIAL INSTITUTE
BMI-X-10146 + EURAEC-1527 +. 7 PAGES, OCTOBER 1, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE OBJECTIVE OF THIS PROGRAM IS TO DETERMINE THE TYPE AND MAGNITUDE OF MECHANICAL-PROPERTY CHANGES PRODUCED ANNEALED AISI TYPE 304 STAINLESS STEEL AND ANNEALED ZIRCALOY-2 BY FISSION-FRAGMENT IRRADIATIONS. TESTING OF TUBE-BURST AND BEND SPECIMENS OF RECOIL-IMPREGNATED ZIRCALOY-2 AND TYPE 304 STAINLESS STEEL WAS COMPLETED. NOMINAL INCREASES OF 8 TO 10 PERCENT IN AVERAGE PROPORTIONAL LIMIT AND YIELD-STRENGTH VALUES OF FISSION-FRAGMENT-DAMAGED OVER NEUTRON-DAMAGED MATERIALS WERE NOTED FROM BOTH THE BEND AND TUBE-BURST DATA. LIGHT AND ELECTRON METALLOGRAPHIC ANALYSES OF THE RECOIL-IMPREGNATED MATERIALS WERE COMPLETED. NO STRUCTURAL CHANGES WERE NOTED AS THE RESULT OF FISSION-FRAGMENT OR NEUTRON DAMAGE. FRACTURE ANALYSIS OF RUPTURES PRODUCED IN THE TUBE-BURST EXPERIMENTS INDICATED NO CHANGE IN FRACTURE MODE (DUCTILE) AS A RESULT OF FISSION-FRAGMENT IRRADIATION. THE MAXIMUM RADIATION-INDUCED TENSILE AND COMPRESSIVE STRESSES IN ZIRCALOY-2 AND TYPE 304 STAINLESS STEEL WERE CALCULATED ON THE BASIS OF EXPERIMENTALLY DETERMINED VALUES OF RADIATION EXPANSION COEFFICIENTS AND FISSION-FRAGMENT CONCENTRATIONS. ALTHOUGH CALCULATED TENSILE STRESSES WERE NOMINAL, COMPRESSIVE STRESSES OF 14,300 PSI (STAINLESS STEEL) AND 42,400 PSI (ZIRCALOY-2) WERE OBTAINED.

*RADIATION DAMAGE + *STEEL, STAINLESS + *TENSILE PROPERTY + ALLOY + ELECTRON MICROSCOPY + FAILURE, PIPE + TESTING + ZIRCONIUM

11-09965 CASTAGNA M + COLOMBO RL + FERRO A + ROSSI FS + SZABO G
ON THE EFFECT OF NITROGEN INTERSTITIALS ON THE RADIATION EMBRITTLEMENT OF PURE IRON. TECHNICAL REPORT NO. 3
SORIN - CENTRO RICERCHE NUCLEARI, SALUGGIA (VERCELLI) + FIAT - SEZIONE ENERGIA NUCLEARE, TORINO + ISTITUTO ELETTROTECNICO NAZIONALE GALILEO FERRARIS, TORINO
EURAEC-1347 + EUR-2322 +. 37 PAGES, 1965, CFSTI, \$2.00 CY, \$1.00 MN

IN VIEW OF THE PRESENT INTEREST ON THE RADIATION EMBRITTLEMENT OF STEELS, SOME PRELIMINARY EXPERIMENTS WERE PERFORMED TO IMPROVE THE KNOWLEDGE OF THE INFLUENCE OF NITROGEN PRESENT IN COMBINED OR FREE CONDITION IN THE FERRITIC STEELS USED FOR NUCLEAR PRESSURE VESSELS. EXPERIMENTS WERE PERFORMED ON TWO IRON MATERIALS. ONE WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED NITRIDED IRON IN A NITROGEN ATMOSPHERE AND SILICON AS A DEOXIDIZER, SO THAT THE FINAL NITROGEN CONTENT WAS ABOUT 0.02 PERCENT. THE OTHER, USED FOR REFERENCE, WAS ARMCO IRON REMELTED IN A VACUUM, TO WHICH WAS ADDED 0.25 PERCENT TITANIUM, WITH THE PURPOSE, BESIDES DEOXIDATION, OF REMOVING ALL THE NITROGEN AND CARBON INTERSTITIALS, WHICH PRECIPITATE AS TITANIUM NITRIDES AND CARBIDES. THIS MATERIAL SHOWS NO AGEING AT ALL AND HAS NO SHARP YIELD POINT. THE TRANSITION TEMPERATURE FOR NITROGEN-CONTAINING IRON WAS ABOUT 0 DEGREE C PRIOR TO IRRADIATION AND ABOUT 160 DEGREES C AFTER IRRADIATION, WHILE IN INTERSTITIAL-FREE IRON IT SHIFTED FROM MINUS 60 DEGREES TO 0 DEGREE C.

*EMBRITTLEMENT + *IMPACT PROPERTY + *IRON + *NITROGEN + *RADIATION DAMAGE + BRITTLE FRACTURE + NITRIDE + TESTING

11-09966 RUBEL H + DEBRAY W + ROSLER U
HYDROGEN PICK-UP AND EMBRITTLEMENT OF ZIRCALOY-2 ZRNB 1 AND ZRNB 2.5
SIEMENS-SCHUCKERTWERKE AG, ERLANGEN, GERMANY
EURAEC-901 + EUR-1501.D +. 33 PAGES, 1965, REPRINT FROM NUKLEONIK 6(4), (1964), CFSTI, \$3.60 FS, \$1.19 MF

NEXT TO THE BEHAVIOR TOWARD OXIDATION, IT IS MAINLY THE EMBRITTLEMENT SUBSEQUENT TO HYDROGEN PICKUP THAT SETS A LIMIT TO THE SUITABILITY AND LIFETIME OF ZIRCONIUM ALLOYS IN WATER-COOLED OR STEAM-COOLED NUCLEAR REACTORS. WITH THE ZIRCALOY-2 AND ZIRCALOY-4 AMERICAN STANDARD ZIRCONIUM ALLOYS FOR WATER-COOLED REACTORS, THE MAXIMUM OPERATING TEMPERATURE IS TO BE TAKEN AS ABOUT 350 C. THE OBJECT OF THE PRESENT INVESTIGATION IS TO CONTRIBUTE TO KNOWLEDGE ABOUT THE HYDROGEN PICKUP AND THE CONSEQUENT CHANGES IN THE MECHANICAL PROPERTIES IN CONNECTION WITH THE ZR-NB 1 AND ZR-NB 2.5 ALLOYS WITH RESPECT TO ZIRCALOY-2 TAKEN AS STANDARD OF COMPARISON.

*ALLOY + *EMBRITTLEMENT + *HYDROGEN + *NITROGEN + *ZIRCALOY + *ZIRCONIUM + BRITTLE FRACTURE

11-09974 PRELIMINARY SAFETY ANALYSIS REPORT. TURKEY POINT NUCLEAR GENERATING UNITS NO. 3 AND NO. 4.

ACCESSION NUMBER 11-09920 TO 11-09974

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-09974 *CONTINUED*

SUPPLEMENT NO. 1

FLORIDA POWER AND LIGHT COMPANY

68 PAGES, FIGURES, TABLES, REFERENCES, DOCKET 50-250 AND DOCKET 50-251, MAY 12, 1966, PDR

ADDITIONAL INFORMATION ON PRESTRESSED CONCRETE CONTAINMENT VESSEL AND ON OCEANOGRAPHY. TIDAL CIRCULATION FLOW THROUGH BISCAYNE BAY MAJOR INLET MEASURED USING MEASURED FLOW THROUGH THREE MINOR INLETS AND TIDAL VOLUME CHANGE. STUDY CONTINUES. CONTAINMENT DESIGN CRITERIA PRESENTED. DESIGN PRESSURE IS 55 PSIG. ONE-FOURTH-INCH STEEL LINER USED TO MINIMIZE LEAKAGE. SEISMIC DESIGN WITH ASSUMED 0.05 G HORIZONTAL AND 0.033 G.

*CONCRETE, PRESTRESSED + *CONTAINMENT, HIGH PRESSURE + *OCEAN AND SEA + DESIGN CRITERIA + REACTOR, PRESSURIZED WATER + SAFEGUARDS REPORT, GENERAL + SEISMOLOGY + TURKEY POINT 3 + TURKEY POINT 4

11-10114 BYRNE JT

PLUTONIUM MANAGEMENT AT ROCKY FLATS

DOW CHEMICAL COMPANY, ROCKY FLATS DIVISION

RFP-720 + CONF-660308-1 +. 21 PAGES, FEBRUARY 11, 1966, AMERICAN NUCLEAR SOCIETY, PLUTONIUM INFORMATION MEETING, WASHINGTON, D. C., CFSTI, \$1.00 CY, \$0.50 MN

SOME MAJOR TECHNICAL CONSIDERATIONS IN PLUTONIUM MATERIALS MANAGEMENT ARE DISCUSSED. THIS REPORT IS BASED UPON PRACTICES DEVELOPED AND EVALUATED DURING NEARLY 15 YEARS OF EXPERIENCE IN LARGE-SCALE CHEMICAL, METALLURGICAL, AND FABRICATION OPERATIONS AT THE USAEC'S ROCKY FLATS PLANT. PARTICULAR EMPHASIS IS PLACED UPON THE PROBLEM OF CONTAINMENT AND ON MEANS OF COPING WITH LOSS-OF-CONTAINMENT SITUATIONS. RECENT WORK ON HANDLING AND MEASURING PLUTONIUM SHIPMENTS IS SUMMARIZED. EFFECTIVE METHODS FOR PLUTONIUM HANDLING AND CONTROL DURING PROCESSING ARE DESCRIBED. CURRENT PROBLEMS IN PLUTONIUM MATERIALS MANAGEMENT ARE IDENTIFIED.

*CONTAINMENT SYSTEM, OPERATION OF + *PLUTONIUM + *RADIOCHEMICAL PROCESSING + *ROCKY FLATS + TRANSPORTATION AND HANDLING

11-10165 IYENGAR KT + CHANDRASHEKHARA K

THERMAL STRESSES IN A FINITE SOLID CYLINDER DUE TO AN AXISYMMETRIC TEMPERATURE FIELD AT THE END SURFACE INDIAN INSTITUTE OF SCIENCE, BANGALORE, INDIA

11 PAGES, 7 FIGURES, 1 TABLE, 6 REFERENCES, NUCLEAR ENGINEERING AND DESIGN 3(1), PP. 21-31 (JANUARY 1966)

THE PROBLEM IS TO DETERMINE THE THERMAL STRESSES IN A SOLID CYLINDER OF FINITE LENGTH DUE TO A STEADY-STATE TEMPERATURE DISTRIBUTION WHICH IS A FUNCTION OF RADIUS AND AXIAL DISTANCE, BUT SYMMETRICAL ABOUT THE LONG AXIS OF THE CYLINDER. THE TEMPERATURE DISTRIBUTION IS EXPRESSED AS THE SUM OF TWO FUNCTIONS, ONE OF WHICH IS SYMMETRIC ABOUT THE MIDPLANE OF THE CYLINDER, AND ONE OF WHICH IS ANTISYMMETRIC. THE THERMAL STRESSES ARE ALSO OBTAINED AS THE SUM OF TWO SOLUTIONS. THE FIRST SOLUTION SATISFIES THE GOVERNING DIFFERENTIAL EQUATION BUT DOES NOT SATISFY THE BOUNDARY STRESS CONDITIONS. THE SECOND SOLUTION NULLIFIES THE INCORRECT BOUNDARY STRESSES PRODUCED BY THE FIRST SOLUTION.

*ELASTICITY + *STRESS + *STRESS ANALYSIS + *TEMPERATURE GRADIENT + FUEL ELEMENT + HIGH TEMPERATURE + HOT SPOT + RADIATION DAMAGE

11-10166 STOWELL EZ

A STUDY OF THE ENERGY CRITERION FOR FATIGUE

SOUTHWEST RESEARCH INSTITUTE

9 PAGES, 15 FIGURES, 3 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 32-40 (JANUARY 1966)

A STUDY WAS MADE TO TEST THE HYPOTHESIS THAT FATIGUE FAILURE OCCURS WHEN THE CUMULATIVE HYSTERESIS ENERGY REACHES THE ENERGY REQUIRED FOR STATIC FRACTURE. THE DATA WERE OBTAINED BY STRAIN-CYCLING ABOUT ZERO MEAN STRAIN. COMPARISON OF THEORY WITH DATA SHOWS THAT THE THEORY IS FAIRLY ACCURATE, PROVIDED THAT THE MATERIAL IS NOT IN AN ANNEALED CONDITION. THIS RESTRICTION IS NECESSARY BECAUSE THE MATERIAL HARDENS DURING CYCLING AND SO THE STRESS-STRAIN CURVE OBTAINED FROM THE ORIGINAL MATERIAL IS NOT REPRESENTATIVE OF THE MATERIAL DURING CYCLING.

*FAILURE, FATIGUE + CONTAINMENT INTEGRITY + CONTAINMENT, PRESSURE VESSEL + FAILURE, PIPE + FAILURE, PRESSURE VESSEL + METAL + PIPING + PLASTICITY + STRESS + TENSILE PROPERTY

11-10167 BAILEY RW + FIDLER R

STRESS ANALYSIS OF PLATES AND SHELLS CONTAINING PATTERNS OF REINFORCED HOLES

CENTRAL ELECTRICITY RESEARCH LABORATORIES, ENGLAND

13 PAGES, 13 FIGURES, 9 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 41-53 (JANUARY 1966)

THIS ANALYSIS IS APPLICABLE TO TUBE PLATES AND STANDPIPE ENTRIES IN CONCRETE PRESSURE VESSELS. EQUI-BIAxIAL STRESS IS ASSUMED. THE ANALYSIS DERIVES THE MAXIMUM STRESS CONCENTRATION AND EFFECTIVE ELASTIC MODULUS OF THE PLATE, AND THESE TWO QUANTITIES ARE PRESENTED IN THE FORM OF CURVES SHOWING VARIATION WITH THE PITCH-TO-DIAMETER RATIO AND DEGREE OF REINFORCING. THE ACCURACY OF THE PRESENTLY USED LIGAMENT THEORY IS DISCUSSED. EXPERIMENTAL VERIFICATION OF THE ANALYSIS IS OBTAINED WITH THE AID OF A PHOTOELASTIC MODEL.

*CONCRETE + *CONCRETE, PRESTRESSED + *CONTAINMENT STRUCTURE + *ELASTICITY + CONTAINMENT, PRESSURE VESSEL + STRESS + STRESS ANALYSIS

11-10168 ENGLAND GL

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-10168 *CONTINUED*

STEADY-STATE STRESSES IN CONCRETE STRUCTURES SUBJECTED TO SUSTAINED TEMPERATURES AND LOADS. PART I.
CASES OF UNIAXIAL STRESS
KINGS COLLEGE, LONDON, ENGLAND
13 PAGES, 11 FIGURES, 5 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 54-65 (JANUARY 1966)

BASED ON THE ASSUMPTION THAT THE CREEP RATE OF CONCRETE IS LINEARLY PROPORTIONAL TO BOTH STRESS AND TEMPERATURE, THE TIME VARIATION OF THE BENDING STRESSES IN BEAMS UNDER THERMAL AND MECHANICAL LOADING IS DISCUSSED. IT IS ASSERTED THAT STRESSES WILL LIE BETWEEN THEIR INITIAL ELASTIC VALUES AND AN ASYMPTOTIC DISTRIBUTION DETERMINED BY CREEP. COMPLETE DERIVATIONS ARE NOT GIVEN, AND THE READER MUST REFER TO THE REFERENCES FOR A COMPLETE EXPLANATION.

*CONCRETE + *CONCRETE, PRESTRESSED + *CREEP BEHAVIOR + *TEMPERATURE GRADIENT + CONTAINMENT STRUCTURE + CONTAINMENT, PRESSURE VESSEL + HIGH TEMPERATURE + STRESS + STRESS ANALYSIS

11-10169 CHAN HC + MCMINN SJ

THE STABILIZATION OF THE STEEL LINER OF A PRESTRESSED CONCRETE PRESSURE VESSEL
THE MANCHESTER COLLEGE OF SCIENCE AND TECHNOLOGY, MANCHESTER, ENGLAND
8 PAGES, 9 FIGURES, 2 TABLES, 5 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 66-73 (JANUARY 1966)

AN ANALYTICAL SOLUTION IS PRESENTED FOR THE BUCKLING BEHAVIOR OF THE LINER OF A PRESTRESSED CONCRETE PRESSURE VESSEL. RESULTS ARE PRESENTED AS CURVES SHOWING THE MAXIMUM LATERAL DEFLECTION AND THE CENTRAL ANGLE OF THE BUCKLED CHORD AS A FUNCTION OF THE UNBUCKLED COMPRESSIVE STRAIN. THERE IS A SMALL VALUE OF INITIAL COMPRESSIVE STRAIN BELOW WHICH BUCKLING WILL NOT OCCUR. ABOVE THIS STRAIN, THERE ARE TWO POSSIBLE POSTBUCKLING CONFIGURATIONS. THE FIRST PRODUCES ONLY SMALL DEFLECTIONS AND IS UNSTABLE. THE SECOND PRODUCES LARGE DEFLECTIONS AND IS STABLE. BUCKLING CAN BE PREVENTED BY SPACING ANCHORS CLOSER TOGETHER THAN THE ARC LENGTH OF THE UNSTABLE BUCKLED CONFIGURATION.

*BUCKLING + *CONCRETE, PRESTRESSED + *CONTAINMENT STRUCTURE + *INSTABILITY + COMPUTER PROGRAM + CONCRETE + CONTAINMENT, PRESSURE VESSEL + ELASTICITY + SHELL + STRESS + STRESS ANALYSIS + TEST, PRESSURE VESSEL

11-10170 ZUDANS Z

DYNAMIC RESPONSE OF SHELL TYPE STRUCTURES SUBJECTED TO IMPULSIVE MECHANICAL AND THERMAL LOADINGS
THE FRANKLIN INSTITUTE RESEARCH LABORATORIES, PHILADELPHIA, PA.
20 PAGES, 23 FIGURES, 25 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 117-137 (JANUARY 1966)

AN ORIGINAL METHOD OF DYNAMIC SHELL ANALYSIS, CAPABLE OF HANDLING LARGE NUMBERS OF BRANCHED SHELLS, IS PRESENTED. THE METHOD IS APPLICABLE TO RESTRAINED OR UNRESTRAINED SHELL STRUCTURES AND ALLOWS THE INCORPORATION OF ELASTIC RINGS OF ARBITRARY CROSS-SECTIONAL SHAPE. THE ANALYSIS IS BASED ON THE MODAL APPROACH, AND IN ITS PRESENT FORM IS LIMITED TO LINEAR ELASTIC EFFECTS. THE METHOD IS BEING USED FOR THE DYNAMIC RESPONSE ANALYSIS OF THE LOFT REACTOR VESSEL.

*COMPUTER PROGRAM + *SHELL + CONTAINMENT STRUCTURE + ELASTICITY + IMPACT SHOCK + SHOCK WAVE + STRESS + STRESS ANALYSIS + TEMPERATURE GRADIENT

11-10171 RASHID YK

ANALYSIS OF AXISYMMETRIC COMPOSITE STRUCTURES BY THE FINITE ELEMENT METHOD
GENERAL DYNAMICS CORPORATION, GENERAL ATOMIC DIVISION, SAN DIEGO, CALIFORNIA
20 PAGES, 20 FIGURES, 20 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 163-182 (JANUARY 1966)

A GENERAL DESCRIPTION OF THE FINITE-ELEMENT METHOD OF ANALYSIS IS GIVEN. THE METHOD UTILIZES THE PRINCIPLE OF STATIONARY POTENTIAL ENERGY, AND A MODIFIED RITZ PROCEDURE APPLIED TO EACH ELEMENT SEPARATELY. BY REPRESENTING A CONTINUOUS STRUCTURE AS AN ASSEMBLAGE OF DISCRETE ELEMENTS, THE EQUILIBRIUM CONDITIONS ARE REPRESENTED IN ALGEBRAIC RATHER THAN IN DIFFERENTIAL FORM. THUS MATRIX ALGEBRA BECOMES APPLICABLE TO THE PROBLEM. STRESS PLOTS FROM SOME EXAMPLE CALCULATIONS ARE GIVEN.

*COMPUTER PROGRAM + *CONCRETE, PRESTRESSED + *ELASTICITY + CONCRETE + CONTAINMENT STRUCTURE + CONTAINMENT, PRESSURE VESSEL + STRESS + STRESS ANALYSIS

11-10174 COTTRELL WB

ORNL NUCLEAR SAFETY RESEARCH AND DEVELOPMENT PROGRAM BIMONTHLY REPORT FOR MARCH - APRIL 1966
OAK RIDGE NATIONAL LABORATORY
ORNL-CF-66-5-20 +. 45 PAGES, MAY 2, 1966, SOURCE

ORNL PROGRESS IN THE USAEC REACTOR SAFETY PROGRAM DURING THE MONTHS OF MARCH AND APRIL ARE SUMMARIZED. INCLUDED IS WORK ON VARIOUS CHEMICAL REACTIONS, THE RELEASE, CHARACTERIZATION, AND TRANSPORT OF FISSION PRODUCTS IN CONTAINMENT SYSTEMS UNDER VARIOUS ACCIDENT CONDITIONS, AND PROBLEMS ASSOCIATED WITH THE REMOVAL OF THESE FISSION PRODUCTS FROM GAS STREAMS. WHILE THESE STUDIES PROVIDE INFORMATION ON THE CONSEQUENCE OF POTENTIAL REACTOR ACCIDENTS AND THUS HAVE DIRECT RELEVANCE TO THE EVALUATION OF REACTOR SITES, A SEPARATE STUDY IS BEING UNDERTAKEN ON THE SAFETY AND FEASIBILITY OF THE OFF-SHORE SITING OF POWER REACTORS. ALTHOUGH MOST OF THE WORK HAS BEEN AND CONTINUES TO BE IN GENERAL SUPPORT OF WATER POWER REACTOR TECHNOLOGY, INCLUDING SOME IN DIRECT SUPPORT OF THE LOFT AND CSE PROGRAMS, SEVERAL NEW PROJECTS WERE INITIATED THE FIRST OF THE YEAR IN SUPPORT OF THE HIGH-TEMPERATURE GAS-COOLED REACTOR (HTR) PROGRAM. THESE NEW PROJECTS INCLUDE BOTH IN-PILE AND OUT-PILE STUDIES OF REACTION RATES AND FISSION-PRODUCT RELEASE AND TRANSPORT PHENOMENA RELEVANT TO POTENTIAL HTR ACCIDENT SITUATIONS. TWO NEW PROJECTS, INITIATED DURING THE REPORT PERIOD, INCLUDE STUDIES ON PRESSURE-VESSEL TECHNOLOGY AND THE INITIATION OF A SERIES OF DISCUSSION PAPERS ON VARIOUS ASPECTS OF WATER REACTOR TECHNOLOGY. RECENT ACTIVITIES OF THE NSIC AND THE NUCLEAR SAFETY

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-10174 *CONTINUED*
JOURNAL IN BEHALF OF THE NUCLEAR COMMUNITY ARE ALSO DISCUSSED.

*FISSION PRODUCT RELEASE, GENERAL + *FISSION PRODUCT TRANSPORT + *FISSION PRODUCT, IODINE +
*LOFT (LOSS OF FLUID TEST) + *NSIC (NUCLEAR SAFETY INFORMATION CENTER) +
*NSPP (NUCLEAR SAFETY PILOT PLANT) + *TREAT (TRANSIENT TEST REACTOR FACILITY) + CHARCOAL +
CHEMICAL KINETICS + CONTAINMENT, PRESSURE VESSEL + FILTER + FILTER, COMBINATION + FILTER, MAY PACK +
GRAPHITE + IN PILE EXPERIMENT + IN PILE LOOP + ORGANIC IODIDE + OUT OF PILE LOOPS AND EXPERIMENTS +
PARTICULATE + REACTOR, GRAPHITE MODERATED + REACTOR, PRESSURIZED WATER + REACTOR, TEST + STEAM +
STRESS ANALYSIS

11-10185 MERKLE JG
THE STRENGTH OF STEEL CONTAINMENT SHELLS
OAK RIDGE NATIONAL LABORATORY
9 PAGES, 3 FIGURES, NUCLEAR SAFETY, 7(2), PP. 204-212 (WINTER 1965-1966)

PART ONE OF TWO PARTS. TWO IMPORTANT REPORTS CONCERNING REACTOR CONTAINMENT TECHNOLOGY WERE
RECENTLY ISSUED. A PORTION OF EACH REPORT CONCERNS THE BURSTING STRENGTH OF
THIN-WALLED-STEEL CONTAINMENT SHELLS. THESE SHELLS MAY BE CAPABLE OF UNDERGOING A LARGE
AMOUNT OF PLASTIC DEFORMATION PRIOR TO BURSTING. EXPERIMENTAL AND ANALYTICAL RESEARCH ON THE
BURSTING STRENGTH OF THIN-WALLED CYLINDERS WITH FLAT ENDS IS SUMMARIZED. DEFINITIONS OF
FAILURE AND STRENGTH ARE PRESENTED, AND THE BASIC EQUATIONS OF PLASTICITY ARE DERIVED.
INCLUDED ARE A TABULATED SUMMARY OF ANALYTICAL SOLUTIONS FOR THIN-WALLED CYLINDERS WITH RIGID
ENDS. EXTENSIVE BIBLIOGRAPHY.

*BIBLIOGRAPHY + *BURST PRESSURE + *CONTAINMENT STRUCTURE + *PLASTICITY + BRITTLE FRACTURE + BUCKLING +
CYLINDER + DEFORMATION + FAILURE, GENERAL + INSTABILITY + PRESSURE, INTERNAL + SHELL + STEEL + STRESS +
STRESS ANALYSIS + TENSILE PROPERTY

11-10186 BLOCK DL + CARD MF + MIKULAS MM
BUCKLING OF ECCENTRICALLY STIFFENED ORTHOTROPIC CYLINDERS
LANGLEY RESEARCH CENTER, NATIONAL AERONAUTICS AND SPACE ADMINISTRATION
NASA-TN-D-2960 +. 31 PAGES, 5 FIGURES, 1 TABLE, 13 REFERENCES, AUGUST, 1965, TECHNICAL NOTE, CFSTI, \$2.00
CY

A SMALL-DEFLECTION THEORY FOR BUCKLING OF STIFFENED ORTHOTROPIC CYLINDERS WHICH INCLUDES
ECCENTRICITY (ONE-SIDED EFFECTS) IN THE STIFFNESS IS DERIVED FROM ENERGY PRINCIPLES.
COMPARABLE SOLUTIONS FOR STIFFENED FLAT PLATES ARE ALSO GIVEN. CALCULATIONS DEMONSTRATE THAT
ECCENTRICITY EFFECTS ARE LARGE, EVEN WITH VERY-LARGE-DIAMETER CYLINDERS OF PRACTICAL
PROPORTIONS AND SHOULD BE ACCOUNTED FOR IN ANY BUCKLING ANALYSIS.

*BUCKLING + CONTAINMENT STRUCTURE + CYLINDER + DEFORMATION + ELASTICITY + INSTABILITY +
MATHEMATICAL STUDY + PRESSURE, EXTERNAL + SHELL + STRESS

11-10187 MOWBRAY DF + SOKOL GJ + SAVIDGE RE
FATIGUE CHARACTERISTICS OF NI-CR-FE ALLOYS WITH EMPHASIS ON PRESSURE-VESSEL CLADDING
KNOLLS ATOMIC POWER LABORATORY
KAPL-3108 +. 88 PAGES, JULY 1, 1965, CFSTI, \$3.00 CY, \$0.75 MN

NI-CR-FE ALLOYS IN THE FORM OF WELD OVERLAY ARE USED AS CLADDING FOR PROTECTION FROM CORROSION
IN NUCLEAR PRESSURE VESSELS. LOW FATIGUE STRENGTH COULD BE CAUSED BY LACK OF FUSION, GROSS
DEFECTS, OR POROSITY. FATIGUE DATA WERE OBTAINED ON THE ALLOYS AS A FUNCTION OF TEMPERATURE,
MEAN STRESS, AND SIZE. THE MATERIAL HAS MORE FATIGUE STRENGTH IN THE WROUGHT FORM THAN IN
THE FORM OF CLADDING. NEITHER DEFECTS OF THE ORDINARY SIZE AND NUMBER, TEMPERATURE, OR MEAN
STRESS APPEAR TO HAVE ANY SIGNIFICANT EFFECT ON FATIGUE STRENGTH.

*FAILURE, CLADDING + *FAILURE, FATIGUE + *FAILURE, PRESSURE VESSEL + *METAL + *WELDS + BRITTLE FRACTURE +
CONTAINMENT, PRESSURE VESSEL + EMBRITTLEMENT + FLAW + PLASTICITY + STRESS + TEST, DESTRUCTIVE + THICKNESS

11-10188 TENNYSON RC
AN EXPERIMENTAL INVESTIGATION OF THE BUCKLING OF CIRCULAR CYLINDRICAL SHELLS IN AXIAL COMPRESSION USING
THE PHOTOELASTIC TECHNIQUE
UNIVERSITY OF TORONTO
1 PAGE, DISSERTATION ABSTRACTS, 26(5), PP. 2622 (NOVEMBER 1965), ORDER NO. 65-12,457, 172 PAGES,
XEROGRAPHY \$8.00, MICROFILM \$3.00

FIVE ACCURATELY MADE, HOMOGENEOUS, ISOTROPIC CYLINDRICAL SHELLS OF CIRCULAR CROSS-SECTION WERE
TESTED IN AXIAL COMPRESSION AND BUCKLED COMPLETELY ELASTICALLY WITHIN TEN PERCENT OF THE
CLASSICALLY PREDICTED VALUES. THIS REPRESENTS AN INCREASE (IN CORRESPONDENCE WITH THEORY)
OVER PREVIOUS EXPERIMENTAL DATA. ANALYSIS OF THE PHOTOELASTICITY DATA INDICATES THAT THE
SHELL INITIALLY BUCKLES WITH A WAVE-SHAPE SIMILAR TO THE CLASSICAL WAVE FORM, WHICH RAPIDLY
DEGENERATES INTO THE DIAMOND-SHAPED BUCKLE IN ABOUT 0.005 SEC.

*BUCKLING + *COMPARISON, THEORY AND EXPERIENCE + *CYLINDER + *SHELL + DEFORMATION + ELASTICITY +
INSTABILITY + STRESS + STRESS ANALYSIS + TEST, DESTRUCTIVE

11-10189 ROBINSON CW
DYNAMIC RESPONSE OF A LONG CYLINDRICAL SHELL TO THERMAL LOADING
SANDIA CORPORATION
SCL-DR-65-144 +. 41 PAGES, FEBRUARY, 1966, CFSTI, \$2.00 CY, \$0.50 MN

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-10189 *CONTINUED*

THE EQUATIONS OF MOTION FOR A LONG CYLINDRICAL SHELL ARE SOLVED FOR THE CASE OF A TEMPERATURE DISTRIBUTION IN THE SHELL WHICH VARIES INDEPENDENTLY WITH ANGLE, TIME, AND DEPTH THROUGH THE SHELL. THE SOLUTIONS ARE OBTAINED BY SUPERIMPOSING TWO APPROXIMATE SOLUTIONS. EXPRESSIONS FOR THE STRESS AND DISPLACEMENTS ARE DERIVED IN SERIES FORM. THE APPENDICES CONTAIN THE INFORMATION NECESSARY TO USE THE COMPUTER PROGRAM OVALT, WRITTEN TO SOLVE THE DIFFERENTIAL EQUATIONS.

*COMPUTER PROGRAM + *CYLINDER + *SHELL + *TEMPERATURE GRADIENT + DEFORMATION + ELASTICITY + HIGH TEMPERATURE + MATHEMATICAL STUDY + STRESS

11-10220 DAVIES DK

MODERN TECHNIQUES IN DESIGN AND ANALYSIS OF NUCLEAR PRESSURE VESSELS
THE BABCOCK AND WILCOX COMPANY

13 PAGES, 6 FIGURES, AMERICAN NUCLEAR SOCIETY MEETING, JUNE, 1966, DENVER, COLORADO, ANS TRANSACTIONS, 9(1), PAGE 223

THIS IS A NONMATHEMATICAL DISCUSSION OF CURRENT PRESSURE-VESSEL TECHNOLOGY. DESIGN PROCEDURE IS OUTLINED. THE STEPS IN DESIGN ARE - GENERAL CONFIGURATION AND SIZING, PRELIMINARY STRESS ANALYSIS, DESCRIPTION OF PRESSURE AND TEMPERATURE TRANSIENTS, FREE-BODY ANALYSIS OF VESSEL SECTIONS, DISCONTINUITY STRESS ANALYSIS, AND STRESS EVALUATION. STRESSES ARE CLASSIFIED ACCORDING TO THEIR ORIGIN AND ACCORDING TO WHETHER THEY ARE LIMITED AND REDISTRIBUTED BY PLASTIC DEFORMATION. EXPERIMENTS SHOW THAT THE EQUATIONS OF ELASTIC PLATES AND SHELLS ARE ACCURATE FOR THE VESSELS NOW BEING BUILT. FATIGUE IS MENTIONED, BUT RADIATION EMBRITTLEMENT AND FRACTURE ARE NOT DISCUSSED.

*CONTAINMENT, PRESSURE VESSEL + *DESIGN CRITERIA + CODES AND STANDARDS + COMPUTER PROGRAM + ELASTICITY + FAILURE, FATIGUE + FAILURE, PRESSURE VESSEL + HIGH TEMPERATURE + MEASUREMENT, STRAIN GAGE + METAL + NOZZLE + PLASTICITY + SAFETY PRINCIPLES AND PHILOSOPHY + SHELL + STEEL + STRESS + STRESS ANALYSIS + TEMPERATURE GRADIENT + TEST, PRESSURE VESSEL

11-10259 KILSBY ER

REACTOR PRIMARY-PIPING-SYSTEM RUPTURE STUDIES
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA

10 PAGES, 5 FIGURES, 5 TABLES, NUCLEAR SAFETY, 7(2), PP. 185-194 (DECEMBER, 1965)

CURRENT STUDIES OF THE STRENGTH AND RELIABILITY OF REACTOR PRIMARY PIPING SYSTEMS ARE DISCUSSED. PIPING FAILURE MODES INCLUDE FRACTURE, FATIGUE, LOCAL CORROSION CRACKING, AND CREEP RUPTURE. PHASE ONE OF THIS PROJECT INCLUDED (1) A SURVEY OF INDUSTRY TO DEFINE CURRENT TECHNOLOGY AND PINPOINT EXISTING PROBLEMS, (2) COLLECTION OF FAILURE DATA, (3) ANALYSIS OF FAILURE DATA, AND (4) EVALUATION OF PRESENT DESIGN CODES. ONLY GROSS DESIGN ERRORS APPEAR CAPABLE OF CAUSING COMPLETE SEVERANCE FAILURES. BETTER METHODS OF ESTIMATING LOCAL STRESSES ARE NEEDED FOR IMPROVING FATIGUE ANALYSIS. FURTHER RESEARCH IS NEEDED IN THE AREAS OF FRACTURE MECHANICS, FATIGUE, LOCALIZED CORROSION, AND CREEP RUPTURE.

*BRITTLE FRACTURE + *FAILURE, FATIGUE + *FAILURE, PIPE + *PIPING + *RELIABILITY ANALYSIS + ACCIDENT, PROBABILITY OF + CODES AND STANDARDS + COMPARISON, THEORY AND EXPERIENCE + CONTAINMENT INTEGRITY + CREEP BEHAVIOR + LOSS OF COOLANT + STRESS + STRESS RUPTURE

11-10260 SACKMAN JL

CREEP IN CONCRETE AND CONCRETE STRUCTURES
UNIVERSITY OF CALIFORNIA, BERKELEY

33 PAGES, 35 FIGURES, 79 REFERENCES, PROCEEDINGS OF THE CONFERENCE ON SOLID MECHANICS, PRINCETON UNIVERSITY, CONFERENCE PUBLICATION NO. 40, 1965, PP. 15-48

THIS IS A REVIEW PAPER. THE CREEP OF CONCRETE DEPENDS ON MANY FACTORS, INCLUDING CEMENT QUALITY, WATER-CEMENT RATIO, MIX PROPORTIONS, AGGREGATE PROPERTIES, ADMIXTURES, CURING CONDITIONS, AGE AT LOADING, RELATIVE HUMIDITY, AND TEMPERATURE. THE LONGEST CREEP TESTS ON RECORD COVERED A PERIOD OF 30 YEARS. CONCRETE IS A TIME-VARIABLE LINEAR VISCOELASTIC MATERIAL FOR STRESS LEVELS BELOW ABOUT 35 PERCENT OF ULTIMATE STRENGTH. POISSON'S RATIO APPEARS TO REMAIN CONSTANT DURING CREEP. WHEN STRESS DISTRIBUTIONS ARE UNCHANGED BY CREEP, SOLUTIONS MAY BE OBTAINED BY THE REDUCED-MODULUS METHOD. LINEAR VISCOELASTIC ANALYSIS IS DISCUSSED. THE EFFECTS OF TEMPERATURE, HUMIDITY, CRACKING, AND HIGH STRESS LEVELS ARE ALSO DISCUSSED. AN EXTENSIVE BIBLIOGRAPHY IS INCLUDED.

*BIBLIOGRAPHY + *CONCRETE + *CREEP BEHAVIOR + *CREEP PROPERTY + CONTAINMENT STRUCTURE + CONTAINMENT, PRESSURE VESSEL + DEFORMATION + ELASTICITY + HIGH TEMPERATURE + STRESS + STRESS ANALYSIS

11-10288 YOUNG AG

PRESSURE VESSELS

ENGLISH ELECTRIC CO. LTD.

BRITISH PAT. 1,019,282 +. 8 PAGES, 4 FIGURES, FEBRUARY 2, 1966, PATENT (BRITISH)

THE INVENTION RELATES TO A CONCRETE PRESSURE VESSEL WHICH HAS AN INTERNAL SURFACE, PART OF WHICH IS SPHERICAL, WITH A FLUID-TIGHT LINER. THE LINER HAS A RIGID FRAME PORTION THAT IS EMBEDDED IN THE CONCRETE. THE FRAME PORTION HAS MANY MEMBERS ARRANGED TO DEFINE AT LEAST A PORTION OF THE SPHERE, WITH SOME MEMBERS ARRANGED TO DEFINE GEODETIC LINES ON THE SURFACE OF THE SPHERE. THESE LINES FORM A NUMBER OF SUBSTANTIALLY CONGRUENT SPHERICAL TRIANGLES OR APPROXIMATELY TRIANGULAR FIGURES.

*CONCRETE + *CONTAINMENT, PRESSURE VESSEL + CONTAINMENT DESIGN + SPHERE + STEEL LINER

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-10289 INTERIM REPORT ON THE NUCLEAR TEST FACILITY DESIGN
PRATT AND WHITNEY AIRCRAFT
CNLM-5983 +. 30 PAGES, NOVEMBER 30, 1964, CFSTI, \$2.00

THIS REPORT PRESENTS COMMENTS AND RECOMMENDATIONS ON THE PRELIMINARY TITLE I DESIGN REPORT, SNAP-50/SPUR NUCLEAR TEST FACILITY, SET FORTH IN CNLM-5931. IT ALSO PROVIDES AN INTERIM REPORT OF WORK WHICH WAS PERFORMED IN SUPPORT OF THE NUCLEAR TEST FACILITY DESIGN. THE SNAP-50 PROJECT HAS BEEN DEACTIVATED.

*CONTAINMENT ANALYSIS + *SNAP 50 (SYSTEMS FOR NUCLEAR AUXILIARY POWER) + CONTAINMENT DESIGN + ENERGY SOURCE + INSTRUMENTATION, GENERAL

11-10319 WAHL HW
FOUNDATION CAISSON PROVIDES UNDERGROUND CONTAINMENT FOR NUCLEAR POWER PLANT
BECHTEL CORPORATION
16 PAGES, 10 FIGURES, 2 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(3) PP. 478-494 (APRIL 1966)

A REINFORCED-CONCRETE CAISSON PROVIDES AN ECONOMICAL UNDERGROUND STRUCTURE FOR HOUSING A PORTION OF THE HUMBOLDT BAY NUCLEAR PLANT. IN ADDITION TO HOUSING THE NUCLEAR STEAM-SUPPLY SYSTEM, THE CAISSON ALSO SERVES AS PART OF THE PRESSURE-SUPPRESSION CONTAINMENT. THE UNIQUE DIFFERENCES BETWEEN THIS CAISSON AND THE CONVENTIONAL MARINE CAISSONS ARE POINTED OUT. THE CAISSON WAS SUNK IMMEDIATELY ADJACENT TO A STEAM POWER PLANT. SPECIAL SINKING TECHNIQUES WERE USED TO REDUCE THE SURFACE FRICTION, SOIL SUBSIDENCE, AND SINKING WEIGHT. UPON COMPLETION, THE UNDERGROUND STRUCTURE SERVED AS A FOUNDATION FOR THE PLANT-REFUELING BUILDING AND 250-FT-HIGH VENTILATION STACK. THE USE OF A CAISSON STRUCTURE PROVED TO BE A SOUND SOLUTION TO THE VARIED REQUIREMENTS OF PLANT LAYOUT, CONTAINMENT, CONSTRUCTION, ADJACENT FOUNDATIONS, AND BUDGET.

*CONTAINMENT CONSTRUCTION + *CONTAINMENT, UNDERGROUND + *HUMBOLDT BAY + CONTAINMENT, PRESSURE SUPPRESSION + REACTOR, BOILING WATER

11-10320 VOIGT O
POST-ACCIDENT PRESSURE AND TEMPERATURE TRANSIENTS IN A DRY CONTAINMENT - A PARAMETRIC STUDY
ALLGEMEINE ELEKTRICITÄTS-GESELLSCHAFT (AEG), FRANKFURT/MAIN, GERMANY
15 PAGES, 4 TABLES, 17 FIGURES, 10 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(3) PP. 451-466 (APRIL 1966)

DRY CONTAINMENT IS WIDELY USED FOR SAFETY ENCLOSURE OF NUCLEAR POWER PLANTS. TO DETERMINE THE CONTAINMENT DESIGN PRESSURE, IT IS REQUIRED TO CALCULATE THE MAXIMUM PRESSURE FOLLOWING THE POSTULATED MOST SEVERE ACCIDENT AND ESTIMATE THE UNCERTAINTIES OF THE CALCULATION. THE RELEASE OF FISSION PRODUCTS FOLLOWING THE ACCIDENT HAS TO BE DETERMINED ON THE EVALUATION OF THE LONG-TIME TRANSIENT PRESSURES AND TEMPERATURES. THE FOLLOWING WORK DESCRIBES A METHOD OF PERFORMING THESE CALCULATIONS, BASED ON WORK DONE FOR THE 520-MW(TH) BOILING WATER REACTOR AT LINGEN, GERMANY. IT DEMONSTRATES THE INFLUENCE OF DEVIATIONS OF BASIC DATA ON THE CALCULATED TRANSIENTS AND PROVIDES A BASIS FOR ENGINEERING JUDGEMENT ON THE RELATIVE IMPORTANCE OF THE DIFFERENT INPUT DATA. THE COMPUTER PROGRAM IS DESCRIBED.

*COMPUTER PROGRAM + *CONTAINMENT ANALYSIS + *CONTAINMENT, HIGH PRESSURE + GERMANY + LOSS OF COOLANT + PRESSURE, INTERNAL + REACTOR, BOILING WATER + THERMAL ANALYSIS

11-10744 LITTING BG
THE ROLE OF NON-DESTRUCTIVE TESTING IN THE MANUFACTURE OF WELDED AND CLAD PRESSURE VESSELS
INTERNATIONAL COMBUSTION LTD., DERBY, ENGLAND
7 PAGES, 7 FIGURES, BRITISH JOURNAL OF NON-DESTRUCTIVE TESTING, 7, PAGES 83-89 (DECEMBER, 1965)

THE ROLE OF NONDESTRUCTIVE TESTING AND PROBLEMS ENCOUNTERED IN THE MANUFACTURE OF PRESSURE VESSELS CLAD WITH STAINLESS STEEL ARE DESCRIBED. SPECIAL TECHNIQUES OF NONDESTRUCTIVE EXAMINATION WERE DEVELOPED TO MEET THE STRINGENT SPECIFICATION REQUIREMENTS WITH REGARD TO BONDING, AND, IN CARRYING OUT THIS WORK, THE NON-DESTRUCTIVE TESTING DEPARTMENT WAS ABLE TO MATERIALLY ASSIST IN ESTABLISHING A SATISFACTORY WELDING TECHNIQUE FOR THE M.I.G. CLADDING OF NOZZLE BORES.

*CONTAINMENT, PRESSURE VESSEL + *TEST, PRESSURE VESSEL + FLAW + METAL + STEEL + TEST, NONDESTRUCTIVE

11-10745 RODABAUGH EC + ATTERBURY TJ
ANALYSIS OF INFORMATION ON REINFORCED OPENINGS IN PRESSURE VESSELS. PHASE REPORT, FEBRUARY 12, 1963 - FEBRUARY 11, 1964
BATTTELLE MEMORIAL INSTITUTE
BMI-X-276 +. 79 PAGES, FEBRUARY 22, 1964, CFSTI, \$3.00 CY, \$0.75 MN

A COMPREHENSIVE STUDY IS BEING MADE OF THE ANALYTICAL AND EXPERIMENTAL INFORMATION ON STRESS DISTRIBUTIONS NEAR REINFORCED OPENINGS IN PRESSURE VESSELS. THEORY AND EXPERIMENT ARE BEING COMPARED, NECESSARY RESEARCH IS BEING IDENTIFIED, AND DESIGN METHODS ARE BEING DEVELOPED FOR A CYLINDER JOINED TO A SPHERE UNDER INTERNAL PRESSURE LOADING. THE ANALYSIS BY WATERS IS FAIRLY ACCURATE EXCEPT FOR CASES OF SIGNIFICANT LOCAL REINFORCING. THE SEAL-SHELL-2 CODE CAN BE USED FOR LOCAL REINFORCING PROBLEMS, PROVIDED THAT THICKNESS CHANGES ARE NOT TOO ABRUPT. PRESENT DESIGN CODE RULES MAY BE UNCONSERVATIVE FOR SOME CASES.

*COMPARISON, THEORY AND EXPERIENCE + *CONTAINMENT, PRESSURE VESSEL + *NOZZLE + *SHELL + *STRESS ANALYSIS + CODES AND STANDARDS + COMPUTER PROGRAM + CYLINDER + DESIGN CRITERIA + ELASTICITY + MATHEMATICAL STUDY + MEASUREMENT, STRAIN GAGE + PRESSURE, INTERNAL + SPHERE + STRESS

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-10901 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
13 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 6 DESCRIBES CONTAINMENT-AIR FILTERING SYSTEM AND EFFECTIVENESS. CHARCOAL TEMPERATURE MONITORED AND HAS A WATER-DOUSING SYSTEM. COMBUSTION OF ONE COMPLETE CHARCOAL BED WOULD INCREASE THE 45-PSIG MCA PEAK PRESSURE TO 60.

*CONTAINMENT FILTERING SYSTEM + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CHARCOAL + FIRE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

11-10902 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY
7 PAGES, 1 FIGURE, OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 7 DESCRIBES FUNCTIONING OF CONTAINMENT-PENETRATION PRESSURIZATION SYSTEM UNDER ACCIDENT CONDITIONS.

*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CONTAINMENT LEAKAGE CONTROL + INDIAN POINT II + REACTOR, PRESSURIZED WATER

11-10903 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 8 DISCUSSES MODEL (AND EXPERIMENTS) FOR REMOVING IODINE BY A SODIUM THIOSULPHATE CONTAINMENT-SPRAY SYSTEM.

*CONTAINMENT SPRAY + *FISSION PRODUCT, IODINE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + PRESSURE, INTERNAL + REACTOR, PRESSURIZED WATER

11-10904 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
9 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 9 CONCLUDES THAT ONLY CERTAIN PORTIONS OF THE SAFETY INJECTION SYSTEM HANDLE LARGE PORTIONS OF POST-MCA WATER, THAT MAXIMUM LEAKAGE OUTSIDE CONTAINMENT IS 88 CC/HR FROM THIS SYSTEM, AND THAT IODINE DOSE (24 HR IS 0.24 REM) FROM THIS IS WELL WITHIN 10-CFR-100.

*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + AIRBORNE RELEASE + DOSE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

11-10911 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14C - INSTRUMENTATION SYSTEM -- MANUAL ISOLATION VALVES MAY BE CHECKED AT THEIR LOCATION FOLLOWING THE HYPOTHETICAL ACCIDENT. REMOTELY CONTROLLED VALVES WILL HAVE INDICATOR LIGHTS IN THE MAIN CONTROL ROOM.

*CONTAINMENT PENETRATION, CLOSURE OF + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + INSTRUMENTATION, GENERAL + REACTOR, PRESSURIZED WATER

11-10923 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES, 1 FIGURE, 2 TABLES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS, INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19E - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- CONTAINS A LIST OF 58 CONTAINMENT PENETRATIONS AND TYPES OF CLOSURES.

*CONTAINMENT PENETRATION, CLOSURE OF + *DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER

11-11234 COWAN A + FEARNEHOUGH AC + GILLIES J + LEES GM
IRRADIATION DAMAGE IN MILD STEEL. A COMPARISON OF CRACK ARREST TEST AND OF NEUTRON SPECTRUM UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH
TRG REPORT 1069 (C) +. 29 PAGES, 15 FIGURES, 8 TABLES, 19 REFERENCES, MAY 1966, UKAEA

IRRADIATION OF CRACK-ARREST SPECIMENS AND CHARPY-V-NOTCH SPECIMENS UNDER IDENTICAL CONDITIONS SHOWED GOOD CORRESPONDENCE IN EVALUATION OF IRRADIATION-EMBRITTLEMENT EFFECTS. THUS CHANGES IN CHARPY-V-NOTCH MONITORING OR SURVEILLANCE SPECIMENS CAN BE USED WHEN REACTOR PRESSURE-VESSEL OPERATING LIMITS ARE BASED ON CRACK-ARREST CRITERIA. CHARPY SPECIMENS OF THE

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11234 *CONTINUED*

SAME STEEL, IRRADIATED IN THREE DIFFERENT REACTORS, SHOW THAT, WHEN DAMAGE IS EXPRESSED IN TERMS DERIVED FROM ACTIVATION OF NICKEL MONITORS, MEASURED CHANGES FOR A GIVEN DOSE CAN VARY BY A FACTOR OF TWO. HOWEVER, WHEN THE DAMAGE INDEX IS TAKEN AS THE TOTAL NUMBER OF ATOMS DISPLACED IN EACH REACTOR FACILITY, THE AGREEMENT WITH MEASURED DAMAGE IMPROVED TO BETTER THAN PLUS-OR-MINUS 15 PERCENT. THUS, WITH A KNOWLEDGE OF NEUTRON SPECTRA, IT IS POSSIBLE FOR A GIVEN STEEL SAMPLE TO GIVE A RELIABLE PREDICTION OF DAMAGE FROM ONE REACTOR TO ANOTHER.

*CONTAINMENT, PRESSURE VESSEL + *EMBRITTEMENT + TEST, DROP

11-11310 FLANGED JOINT

AKTIEBOLAGET ATOMENERGI, SWEDEN

BRITISH PAT. 1,024,767 +. 4 PAGES, 4 FIGURES, FEBRUARY 1, 1962, PATENT (BRITISH)

THE INVENTION IS CONCERNED WITH FLANGED JOINTS WHERE THE JOINT IS BEING SUBJECTED TO HIGH STRESSING, AS FOR INSTANCE IN THE CASE OF PRESSURE-VESSELS USED IN ATOMIC REACTORS. SUCH VESSELS ARE SUBJECTED TO HIGH INTERNAL WORKING PRESSURES, OF THE ORDER OF 50 ATMOSPHERES, AND ALSO TO CONSIDERABLE TEMPERATURE DIFFERENCES BETWEEN THE DIFFERENT PARTS OF THE FLANGED JOINT DURING PERIODS OF START-UP AND CLOSE-DOWN. THE PURPOSE OF THE INVENTION IS THEREFORE TO PROVIDE A TYPE OF FLANGED JOINT WHICH IS SUBSTANTIALLY FREE FROM STRESSING CAUSED EITHER BY THE FORCES KEEPING THE PARTS OF THE JOINT TOGETHER OR BY THE LARGE INTERNAL PRESSURE OR TEMPERATURE DIFFERENCES THAT MAY OCCUR BETWEEN THE DIFFERENT PARTS OF THE JOINT AND THE PRESSURE VESSEL.

*FLANGE + *SEAL + CONTAINMENT, PRESSURE VESSEL + STEEL + STRESS

11-11377 A STUDY ON PLASTIC FATIGUE EMBRITTEMENT OF REACTOR VESSEL

CENTRE NATIONAL DE RECHERCHES METALLURGIQUES, LIEGE

EURAE-1475 + EUR-2396 +. 49 PAGES, OCTOBER 1965, CFSTI \$3.00, \$0.50 MN

THE WORK DONE DURING THIS QUARTER WAS PRIMARILY DEVOTED TO THE STUDY OF THE CHARPY-V-NOTCH IMPACT STRENGTH PROPERTIES OF THE THREE GRADES OF STEEL USED IN STUDIES OF VARIOUS TYPES OF DAMAGE BY PLASTIC FATIGUE UNDER COMPRESSION-TENSION. THE RESULTS CONFIRM SOME OF THE OBSERVATIONS MADE PREVIOUSLY, NAMELY, THAT THE IMPACT STRENGTH, AFTER PLASTIC FATIGUE AT 20 C, SEEMS TO INCREASE IN THE LOW-TEMPERATURE REGION. ON THE OTHER HAND, PLASTIC FATIGUE AT 300 C SEEMS TO CAUSE A NOTICEABLE EMBRITTEMENT, WHICH IS EVIDENCED BY A SLIP IN THE TRANSITION CURVE. SUCH A SLIP IS OF THE SAME ORDER OF MAGNITUDE AS THAT PRODUCED BY STRAIN-HARDENING AND AGING, THOUGH SLIGHTLY ABOVE IT FOR TWO OF THE STEELS STUDIED.

*EMBRITTEMENT + *STEEL + CREEP BEHAVIOR + FAILURE, FATIGUE + STRESS

11-11397 TULIS RC

CONTAINMENT VESSEL ELECTRICAL PENETRATIONS-A STUDY OF PERIODIC TEST METHODS

TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE

TID-22770 +. 18 PAGES, JUNE 1, 1965, CFSTI, \$1.00 CY, \$0.50 MN

THIS REPORT VIEWS EGCR ELECTRICAL PENETRATIONS WHICH LEAVE THE CONTAINMENT VESSEL THROUGH 21 PENETRATION PIPES OF 2-FOOT DIAMETER. THERE ARE 24 SUCH PIPES, BUT THREE ARE BLANKED OFF. THIS INVESTIGATION ATTEMPTED TO SEEK MEANS WHEREBY PRESSURE COULD BE PERIODICALLY AND LOCALLY APPLIED TO THESE PENETRATIONS TO DETERMINE THEIR TIGHTNESS. THE AEC, THROUGH ITS DIVISION OF REACTOR LICENSING (DRL), IS FORMULATING PROCEDURES FOR CONTAINMENT VESSEL TESTING. MORE FREQUENT LEAKAGE CHECKS ARE INDICATED FOR THOSE LOCATIONS WHERE TIME-DEPENDENT DETEIORATION IS MOST LIKELY TO OCCUR. HOWEVER, THE EGCR CONTAINMENT WAS DESIGNED PRIOR TO 1960. NO PROVISION WAS MADE IN CONTAINMENT DESIGN FOR LOCAL, PERIODIC TESTING OF ELECTRICAL PENETRATIONS.

*CONTAINMENT PENETRATION + *EGCR (EXPERIMENTAL GAS COOLED REACTOR) + *TEST, LEAK LOCATION + CONTAINMENT, HIGH PRESSURE + PROCEDURES AND MANUALS + REACTOR, GAS COOLED

11-11445 NASSER KW + NEVILLE AM

CREEP OF CONCRETE AT TEMPERATURES ABOVE NORMAL

UNIVERSITY OF SASKATCHEWAN + UNIVERSITY OF CALGARY

7 PAGES, 6 FIGURES, 1 TABLE, 15 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4(1), PAGES 90-96, MAY/JUNE 1966

CREEP DATA ARE REPORTED FOR TYPE-III-CEMENT TEST CYLINDERS. NO SHRINKAGE WAS PERMITTED. CREEP STRAINS WERE MEASURED WITH EMBEDDED GAGES. CREEP RATES WERE LINEARLY PROPORTIONAL TO STRESS UP TO 70 PERCENT OF ULTIMATE STRENGTH, AND INCREASED WITH TEMPERATURE UP TO 16 F, DECREASING THEREAFTER. CREEP WAS INDEPENDENT OF RELATIVE HUMIDITY FOR CONCRETE IN HYGRAL EQUILIBRIUM WITH ITS SURROUNDINGS. THE DECREASE OF CREEP RATE WITH INCREASING TEMPERATURE ABOVE 160 F MAY BE DUE TO THE VAPORIZATION OF ADSORBED WATER, WHICH MAY OCCUR AT A TEMPERATURE BELOW 180 F. CREEP RECOVERY IS INDEPENDENT OF STRESS AND TEMPERATURE.

*CONCRETE + *CREEP BEHAVIOR + *CREEP PROPERTY + *MEASUREMENT, STRAIN GAGE + CONTAINMENT, PRESSURE VESSEL + DEFORMATION + HIGH TEMPERATURE + STRESS + STRESS STRAIN DATA

11-11446 HORVAY G

BLOWOUT OF THE FLAT END OF A HYDRAULICALLY PRESSURIZED CYLINDRICAL PRESSURE VESSEL

GENERAL ELECTRIC RESEARCH AND DEVELOPMENT CENTER, SCHENECTADY

22 PAGES, 15 FIGURES, 2 TABLES, 11 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4(1), PAGES 61-82, MAY/JUNE

ACCESSION NUMBER 11-11234 TO 11-11446

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11446 *CONTINUED*
1966

AN ANALYSIS WAS PERFORMED TO DETERMINE THE MOTION OF THE BLOWN-OUT END OF AN EXPERIMENTAL PRESSURE VESSEL CONTAINING WATER UNDER A PRESSURE OF 100,000 PSI. THE SHAPE OF THE EMERGING WATER JET IS ESTIMATED. THE END-PLATE VELOCITY REMAINS SUBSTANTIALLY BELOW THE WATER-JET VELOCITY DURING THE MAJOR PART OF THE IMPACT. A 4-TON CANOPY COVERING THE VESSEL END IS UTILIZED TO ABSORB MUCH OF THE MOMENTUM OF THE END PLATE. FOR THE PROPOSED DESIGN, THE END FRAGMENT AND CANOPY ACQUIRE A VELOCITY OF 22.6 FT PER SEC AND RISE ABOUT 1.0 FT. THE CASE OF LATERAL MOTION OF THE END-PLUG REQUIRES ADDITIONAL STUDY.

*ACCIDENT, EXPLOSION + *CONTAINMENT, HIGH PRESSURE + *CONTAINMENT, MISSILE GENERATION AND PROTECTION + *FAILURE, PRESSURE VESSEL + BRITTLE FRACTURE + CONTAINMENT ANALYSIS + CONTAINMENT PENETRATION + CONTAINMENT VESSEL LOADING + CONTAINMENT, PRESSURE VESSEL + CONTAINMENT, WATER FILLED + CYLINDER + EXCURSION, LARGE + EXPLOSION + IMPACT SHOCK + PRESSURE, INTERNAL

11-11447 QUIRK A + FINNEAR TC + FEARNEHOUGH GD + NICHOLS RW
AN EXPERIMENTAL STUDY OF THE FAILURE STRENGTH OF FLAWED STEEL PLATES
UKAEA, RISLEY + ENGLISH ELECTRIC CO., LTD, WHETSTONE + UKAEA REACTOR MATERIALS LABORATORY, CULCHETH, LANCASHIRE
15 PAGES, 16 FIGURES, 8 TABLES, 2 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4(1), PAGES 39-53, MAY/JUNE 1966

THE RESULTS OF TENSILE TESTS ON CENTRALLY FLAWED WIDE STEEL PLATES ARE REPORTED. THESE TESTS WERE PERFORMED TO TEST THE HYPOTHESIS THAT PLASTIC BULGING OF THE CRACKED ZONE INFLUENCES THE FRACTURE STRESS OF MODEL CYLINDRICAL PRESSURE VESSELS. TEST DATA DISPROVE THE HYPOTHESIS, INDICATING THAT THERE IS LITTLE DIFFERENCE BETWEEN THE FRACTURE STRESS OF 5-FT.-DIAMETER CYLINDERS, LARGER DIAMETER CYLINDERS, AND FLAT PLATES FOR CLEAVAGE FRACTURE.

*BRITTLE FRACTURE + *CONTAINMENT, PRESSURE VESSEL + *FAILURE, PRESSURE VESSEL + *FLAW + CONTAINMENT INTEGRITY + CYLINDER + EMBRITTLEMENT + MEASUREMENT, STRAIN GAGE + PLASTICITY + STEEL + STRESS + TENSILE PROPERTY

11-11448 LEPIK U
LARGE DEFLECTIONS OF RIGID-PLASTIC CYLINDRICAL SHELLS UNDER AXIAL TENSION AND EXTERNAL PRESSURE
UNIVERSITY OF TARTU, ESTONIAN
10 PAGES, 5 FIGURES, 2 TABLES, 14 REFERENCES, NUCLEAR ENGINEERING AND DESIGN 4(1), PAGES 29-38, MAY/JUNE, 1966

THE PROBLEM ANALYZED IS A RIGID-PLASTIC CYLINDRICAL SANDWICH SHELL LOADED BY A CONSTANT AXIAL TENSION AND AN INCREASING EXTERNAL PRESSURE. LOAD-DEFLECTION RELATIONS ONLY ARE OBTAINED. RUCKLING IS NOT CONSIDERED. THE SHELL ENDS ARE CONSIDERED SUPPLY SUPPORTED. ALL MEMBRANE FORCES ARE CARRIED BY THE THIN INNER AND OUTER LAYERS OF THE SHELL. ALL SHEAR IS CARRIED BY THE THICKER CORE. TRESCAS YIELD FUNCTION IS USED. IDEAL PLASTICITY IS ASSUMED. SOLUTIONS ARE OBTAINED IN CLOSED FORM. LOAD-DEFLECTION CURVES ARE PLOTTED GRAPHICALLY AND COMPARISONS ARE MADE WITH THE WORK OF OTHERS.

*CYLINDER + *PLASTICITY + *SHELL + DEFORMATION + PRESSURE, EXTERNAL + STRESS + STRESS ANALYSIS

11-11449 TAYLOR RL + CHANG TY
AN APPROXIMATE METHOD FOR THERMOVISCOELASTIC STRESS ANALYSIS
UNIVERSITY OF CALIFORNIA, BERKELEY
8 PAGES, 5 FIGURES, 12 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 4(1), PAGES 21-28, MAY/JUNE 1966

THE FINITE ELEMENT METHOD OF ANALYSIS IS APPLIED TO A THICK-WALLED HOLLOW CYLINDER OF LINEAR VISCOELASTIC MATERIAL. SOLUTIONS FOR COMBINED THERMAL AND PRESSURE LOADING ARE OBTAINED BY SUPERPOSITION OF THE SEPARATE SOLUTIONS. CREEP AND RELAXATION RATES ARE CONSIDERED TO BE TEMPERATURE-DEPENDENT. VOLUME CHANGES ARE ASSUMED TO BE ELASTIC. THE APPLICATION OF THIS TYPE OF ANALYSIS TO CONCRETE REACTOR STRUCTURES IS CONSIDERED.

*CONCRETE + *CREEP BEHAVIOR + COMPUTER PROGRAM + CONCRETE, PRESTRESSED + CYLINDER + HIGH TEMPERATURE + MATHEMATICAL STUDY + PRESSURE, INTERNAL + STRESS + STRESS ANALYSIS + TEMPERATURE GRADIENT

11-11458 STUDY ON SLIGHT LEAKAGE FROM A REACTOR CONTAINMENT VESSEL
3 PAGES, NIPP. KIKAI GAKKAI SHI 68, PAGES 1321-1323 (SEPTEMBER 1965)

THE ARTICLE DISCUSSED THE USE OF TECHNIQUES SUCH AS HELIUM LEAK DETECTION FOR FINDING VERY SMALL LEAKS. IF THE LEAKAGE PROBLEM IS TREATED IN TERMS OF THE MINIMUM LEAKAGE THAT CAN BE DETECTED, IT BECOMES NECESSARY FIRST OF ALL TO RELATE THE HELIUM LEAKAGE WITH THE LEAKAGE OF ACTUAL FLUIDS, TOGETHER WITH THE EFFECTS OF TEMPERATURE AND PRESSURE ON THE PROCESS. CALCULATIONS AND TESTS WERE PERFORMED TO AID IN DEVELOPING MODELS FOR CALCULATING ACTUAL LEAKAGE.

*TEST, LEAK RATE + ANALYTICAL MODEL + CONTAINMENT STRUCTURE + HELIUM

11-11508 UEBING O
REQUIREMENTS REGARDING THE PROPERTIES OF MATERIALS FOR REACTOR PRESSURE VESSELS WITH RESPECT TO OPERATING LOADS AND DISTURBANCES -- A SUMMARY
TECHNISCHER UBERWACHUNGS - VEREIN RHEINLAND E.V., COLOGNE, GERMANY
ORNL-TR-1308 +. 11 PAGES, 14 FIGURES, 17 REFERENCES, TABLES, NUCLEAR STRUCTURAL ENGINEERING 3, PAGES

ACCESSION NUMBER 11-11446 TO 11-11508

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11508 *CONTINUED*
421-431, (1966), JCL

THE STRENGTH OF PRESSURE VESSELS IN THE PLASTIC RANGE IS DISCUSSED. ULTIMATE TENSILE STRENGTH AND DUCTILITY ARE IMPORTANT, AS WELL AS YIELD STRENGTH. THE RATIO OF BURST PRESSURE TO YIELD PRESSURE DECREASES AS THE RATIO OF YIELD STRENGTH TO ULTIMATE STRENGTH OF THE MATERIAL INCREASES. NOTCH-IMPACT STRENGTH INCREASES AS DUCTILITY INCREASES. FATIGUE STRENGTH IS STRONGLY INFLUENCED BY THE FREQUENCY OF STRAIN FLUCTUATION.

*BURST PRESSURE + *CONTAINMENT, PRESSURE VESSEL + *FAILURE, PRESSURE VESSEL + BRITTLE FRACTURE + CONTAINMENT, WATER FILLED + CYLINDER + IMPACT PROPERTY + PLASTICITY + PRESSURE, INTERNAL + STEEL + STRESS + STRESS ANALYSIS

11-11509 WEISS V + GREWAL KS + SESSLER J
THE EFFECT OF TESTING SYSTEM STIFFNESS ON FRACTURE
SYRACUSE UNIVERSITY
ML-TDR-64-150 +. 28 PAGES, 10 FIGURES, 4 TABLES, APRIL 1964, CFSTI

THE ELASTIC ENERGY RELEASE RATE OF A NOTCH-BEND SPECIMEN ORDINARILY DECREASES WITH INCREASE IN CRACK LENGTH. HOWEVER, THE INCLUSION OF A SOFT SPRING IN SERIES WITH THE SPECIMEN CAUSES THE ENERGY RELEASE RATE TO INCREASE INSTEAD OF DECREASE WITH INCREASING CRACK LENGTH. EQUATIONS FOR THE ELASTIC ENERGY RELEASE RATES FOR FIXED GRIPS AND FIXED LOADS ARE PRESENTED. TESTING-SYSTEM STIFFNESS WAS VARIED BY USING SPRINGS AND LINKAGES. A SPECIAL COMPLIANCE GAGE WAS USED. FAILURE STRESS WAS NOT APPRECIABLY AFFECTED BY TESTING-SYSTEM STIFFNESS, BUT FAILURE MODE WAS. FRACTURE STRENGTH DECREASED WITH DECREASING LENGTH-TO-WIDTH RATIO.

*BRITTLE FRACTURE + *FLAW + *MEASUREMENT, STRAIN GAGE + CONTAINMENT, PRESSURE VESSEL + ELASTICITY + EMBRITTLEMENT + FAILURE, PRESSURE VESSEL + PLASTICITY + STRESS + TENSILE PROPERTY

11-11532 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 60 PAGES, 7 TABLES, 6 FIGURES, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

ACRS (AUGUST 19, 1966) REQUESTED INFORMATION ON THE RELIABILITY OF CERTAIN SYSTEMS UNDER MCA CONDITIONS, SPECIFICALLY THE RECIRCULATION-SPRAY SYSTEM, THE CORE-SPRAY SYSTEM, AND THE EFFECT OF CONTAINMENT FLOODING. AFTER ANALYSIS, THE FOLLOWING ITEMS ARE PROPOSED - (A) ELIMINATION OF THE RECIRCULATION-SPRAY COOLANT SYSTEM, (B) ADDITION OF A CORE WATER INJECTION SYSTEM, (C) PLANNED FLOODING OF THE REACTOR BUILDING AFTER A RUPTURE BELOW THE CORE, (D) PLANNED STRIPPING OF THE EXTERNAL INSULATION FROM THE BUILDING FOR HEAT DISSIPATION AFTER A STEAM-LINE BREAK, AND (E) MODIFICATION OF PLANT INSTRUMENTATION FOR RELIABILITY UNDER FLOODED CONDITIONS.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + EMERGENCY COOLING + LACROSSE BOILING WATER REACTOR + MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

11-11537 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 8 PAGES, PAGES 4.1-4.8, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

CONTAINMENT FLOODING - ENVIRONMENTAL EFFECTS ON ESSENTIAL SYSTEMS AND PLANT MODIFICATIONS.
(A) ELECTRICAL CABLES AND PENETRATIONS ARE MOISTURE PROOF. CONTROL SOLENOIDS ARE DE-ENERGIZED TO GIVE SAFETY ACTION. HOWEVER, HIGH-TEMPERATURE COIL SHORTING COULD HOLD SOLENOIDS OPEN IF THE CURRENT DOES NOT BLOW THE FUSES. CALCULATIONS SHOW THAT THE COIL ITSELF WOULD BURN OUT TO GIVE SAFETY ACTION. MOISTURE-GENERATED SHORTS WOULD BLOW FUSES.
(B) MODIFICATIONS INCLUDE A BUILDING DRAIN PIPE, REVISIONS TO CRITICAL BUILDING PRESSURE, TEMPERATURE, AND WATER-LEVEL INSTRUMENTATION, AND CHANGE OF THE FAILURE MODE OF THE WATER-SUPPLY VALVE TO SHUT DOWN THE CONDENSER.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + CONTAINMENT INSTRUMENTATION + EMERGENCY COOLING + LACROSSE BOILING WATER REACTOR + MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

11-11583 FLOWERS CD
STRUCTURAL ANALYSIS OF A HEXAGONAL TUBE OR RING UNDER INTERNAL PRESSURE
BATTELLE-NORTHWEST, RICHLAND
BNWL-263 +. 51 PAGES, 8 FIGURES, 6 REFERENCES, JUNE 1966, CFSTI \$3.00 CY, \$0.50 MN

A HEXAGONAL RING IS SYMMETRIC ABOUT THE LINES THROUGH ITS OPPOSITE CORNER POINTS AND THE LINES THROUGH THE MIDPOINTS OF ITS OPPOSITE SIDES. THEREFORE, UNDER INTERNAL PRESSURE LOADING, THERE ARE NO SHEAR FORCES AT THE CORNERS OR AT THE MIDPOINTS OF THE SIDES. CONSEQUENTLY, A HEXAGONAL RING UNDER INTERNAL PRESSURE CAN BE ANALYZED BY CONSIDERING A SECTION BETWEEN ONE CORNER AND THE MIDPOINT OF ONE ADJOINING SIDE. AN ANALYSIS OF THIS MODEL WAS PERFORMED, CONSIDERING BOTH BENDING AND DIRECT TENSION. THE FLAT SIDES WERE CONSIDERED AS FLAT PLATES, AND THE CORNERS WERE CONSIDERED AS CURVED PLATES. RESULTS ARE PRESENTED GRAPHICALLY AS WELL AS ANALYTICALLY.

*ELASTICITY + *PRESSURE, INTERNAL + *STRESS ANALYSIS + CONTAINMENT ANALYSIS + DESIGN STUDY

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11584 HAMADA K
THERMAL STRESS ANALYSIS FOR REACTOR PRESSURE VESSEL NOZZLES
HITACHI LTD., JAPAN
NSJ-TR-52 +. 11 PAGES, TRANSLATED FROM HITACHI HYORON 45(12), PAGES 91-4, DECEMBER 1963, JCL, \$1.60 FS,
\$0.80 MF

THIS IS A TRANSLATION OF A JAPANESE PAPER. A PRESSURE-VESSEL NOZZLE IS REPRESENTED BY A MODEL CONSISTING OF A SPHERICAL SHELL, A RING, AND A CYLINDRICAL SHELL. FOR A TRANSIENT CONDITION, A THREE-DIMENSIONAL TEMPERATURE DISTRIBUTION IS DETERMINED BY COMPUTER. FOR THE JPDR REACTOR, IT WAS CONCLUDED THAT 60,000 CYCLES OF NORMAL STARTUPS AND SHUTDOWNS, OR 2400 CYCLES OF EMERGENCY COOLING, WOULD BE PERMISSIBLE DURING THE LIFE OF THE VESSEL.

*CONTAINMENT, PRESSURE VESSEL + *HIGH TEMPERATURE + *NOZZLE + *STRESS ANALYSIS + COMPUTER PROGRAM + CONTAINMENT VESSEL LOADING + ELASTICITY + FAILURE, FATIGUE + FAILURE, PRESSURE VESSEL + SHELL + SPHERE

11-11585 GIBB M
PRESTRESSED CONCRETE IN REACTOR TECHNOLOGY
6 PAGES, 8 FIGURES, EURATOM BULLETIN 5(9), PAGES 56-61, JUNE 1966

CONSTRUCTION OF THE FIRST PRESTRESSED-CONCRETE REACTOR VESSEL BEGAN IN 1954. SUCH VESSELS ARE EASIER TO CONSTRUCT THAN STEEL ONES, ALTHOUGH IT IS BY NO MEANS SIMPLE. GAS-COOLED REACTORS MAY EVENTUALLY OPERATE AT TEMPERATURES UP TO 100 C. RECENT RESEARCH INDICATED THAT CONCRETE RETAINS CONSIDERABLE STRENGTH UP TO 400 C. THERMAL INSULATION MAY COST 40 PERCENT OF THE TOTAL COST, SO WAYS ARE BEING SOUGHT TO ELIMINATE INSULATION. ONE WAY IS TO USE A WATER-TUBE SCREEN. DOUBLE VESSEL DESIGNS ARE BEING STUDIED. THE INNER VESSEL IS A THERMAL AND RADIATION SHIELD, AND THE OUTER CARRIES MECHANICAL LOADS.

*CONCRETE + *CONCRETE, PRESTRESSED + *THERMAL INSULATION + CONTAINMENT DESIGN + CONTAINMENT RESEARCH AND DEVELOPMENT + CONTAINMENT, PRESSURE VESSEL + TEMPERATURE GRADIENT

11-11586 COWELL W
DYNAMIC PROPERTIES OF PLAIN PORTLAND CEMENT CONCRETE
NAVAL CIVIL ENGINEERING LABORATORY, CALIFORNIA
NCEL-TR-447 + DASA-13,0181 +. 56 PAGES, 23 FIGURES, 6 TABLES, 15 REFERENCES, JUNE 1966, CFSTI \$3.00 CY

TWO CONCRETE MIXES WERE TESTED TO DETERMINE THE EFFECT OF MOISTURE CONTENT AND RATE OF LOADING ON COMPRESSIVE AND TENSILE STRENGTH. STRENGTH INCREASED AS RATE OF LOADING INCREASED. ALLOWING THE CONCRETE TO DRY REDUCED THE RATE OF INCREASE IN STRENGTH AT LOW AND INTERMEDIATE STRESS RATES.

*CONCRETE + CONTAINMENT, SHOCK GENERATION AND PROTECTION + IMPACT PROPERTY + SHOCK WAVE + STRESS STRAIN DATA

11-11587 LARKE EC + PARKER RJ
CIRCUMFERENTIAL CREEP STRAIN OF CYLINDERS SUBJECTED TO INTERNAL PRESSURE. A COMPARISON OF THE THEORIES OF JOHNSON AND BAILEY
IMPERIAL CHEMICAL INDUSTRIES LTD.
5 PAGES, 4 REFERENCES, JOURNAL MECHANICAL ENGINEERING SCIENCE 8(1), PAGES 22-26, 1966

A COMPARISON WAS MADE BETWEEN TWO METHODS OF ANALYZING THE CREEP STRAINS OF THICK WALLED CYLINDERS UNDER INTERNAL PRESSURE LOADING. IT WAS SHOWN THAT THE EQUATIONS OF BAILEY, WHICH NEGLECT STRESS CHANGES WITH TIME, GIVE THE SAME INSIDE AND OUTSIDE DIAMETER CHANGES AS THE GRAPHICAL METHOD OF JOHNSON ET AL., WHICH CONSIDERS STRESS CHANGES WITH TIME.

*CREEP BEHAVIOR + *CYLINDER + *PRESSURE, INTERNAL + CONCRETE, PRESTRESSED + CONTAINMENT, PRESSURE VESSEL + DEFORMATION + MATHEMATICAL STUDY + STRESS + STRESS ANALYSIS

11-11588 WEIL NA + DANIEL IM
ANALYSIS OF FRACTURE PROBABILITIES IN NON-UNIFORMLY STRESSED BRITTLE MATERIALS
IIT RESEARCH INSTITUTE, CHICAGO
AD-437,664 +. 34 PAGES, 9 FIGURES, 9 REFERENCES, MAY 1964, SOURCE

EQUATIONS WERE DERIVED FOR CALCULATING THE STRENGTH OF BRITTLE BEAMS IN BENDING ACCORDING TO THE WEIBULL THEORY OF FAILURE. THE EFFECTS OF STRESS GRADIENT ARE CONSIDERED. FLAWS MAY BE DISTRIBUTED THROUGHOUT THE VOLUME OR ONLY ON THE SURFACE. RESULTS ARE PRESENTED GRAPHICALLY, AND AN EXPERIMENTAL PROGRAM IS BRIEFLY DESCRIBED.

*BRITTLE FRACTURE + *FLAW + *THICKNESS + ELASTICITY + FAILURE, FUEL ELEMENT + FUEL ELEMENT + GRAPHITE + MATHEMATICAL STUDY + RELIABILITY ANALYSIS + STRESS + TENSILE PROPERTY

11-11589 CALLADINE CR
ON THE DESIGN OF REINFORCEMENT FOR OPENINGS AND NOZZLES IN THIN SPHERICAL PRESSURE VESSELS
UNIVERSITY OF CAMBRIDGE
14 PAGES, 16 REFERENCES, JOURNAL MECHANICAL ENGINEERING SCIENCE 8(1), PAGES 1-14, 1966

ANALYTICAL STUDIES SHOW THAT IF A NOZZLE-REINFORCEMENT DESIGN IS GOOD FROM THE PLASTIC POINT OF VIEW, IT IS ALSO GOOD FROM THE ELASTIC, AND PROBABLY ALSO THE CREEP, POINTS OF VIEW. A CONICAL-PAD NOZZLE-REINFORCEMENT DESIGN IS PROPOSED. THE MAJOR ADVANTAGE OF THIS DESIGN OVER OTHERS IS THAT THE INTERNAL PRESSURE LOADING IS CARRIED ALMOST COMPLETELY BY MEMBRANE STRESS, WITH VERY LITTLE BENDING. THEREFORE, STRESS CONCENTRATIONS AT THE NOZZLE TO SHELL JUNCTURE

ACCESSION NUMBER 11-11584 TO 11-11589

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11589 *CONTINUED*

ARE VERY LOW. EQUATIONS OF PLASTIC ANALYSIS, BASED ON THE TRESCA YIELD CRITERION, ARE DERIVED TO DEMONSTRATE THE VALIDITY OF THE PROPOSED DESIGN.

*CONTAINMENT PENETRATION + *NOZZLE + *PLASTICITY + *SHELL + CONTAINMENT DESIGN +
- CONTAINMENT, PRESSURE VESSEL + CREEP BEHAVIOR + DEFORMATION + ELASTICITY + PRESSURE, INTERNAL + SPHERE +
STRESS ANALYSIS

11-11590 NELSON LL

IMPROVED SERVICE LIFE OF 15-KG REDUCTION REACTOR VESSELS

DOW CHEMICAL COMPANY

RFP-741 +. 19 PAGES, 11 FIGURES, 1 TABLE, JUNE 6, 1966, CFSTI \$2.00 CY, \$0.50 MN

REDUCTION VESSELS USED FOR BOMB-REDUCING BATCHES OF UF₄ TO URANIUM WERE FAILING AFTER ABOUT TWENTY-FIVE RUNS. THE FAILURES WERE CAUSED BY PROGRESSIVE CRACKING AROUND THE INSIDE OF THE TOP OF THE VESSEL. (THE VESSELS HAD BEEN CENTRIFUGALLY CAST FROM TYPE-310 STAINLESS STEEL.) IT WAS DETERMINED THAT THE CRACKING WAS CAUSED BY SENSITIZATION FROM THE THERMAL CYCLING TO WHICH THESE VESSELS WERE SUBJECTED. SENSITIZATION-RESISTANT TYPE-347 STAINLESS STEEL IS NOW USED FOR THE REACTORS, AND NO CRACKING HAS BEEN DETECTED BY FLUORESCENT-PENETRANT INSPECTION.

*CONTAINMENT, PRESSURE VESSEL + *FAILURE, FATIGUE + *METAL + BRITTLE FRACTURE + CONTAINMENT INTEGRITY +
CONTAINMENT, HIGH PRESSURE + EMBRITTLEMENT + EXPLOSION + FAILURE, PRESSURE VESSEL + IMPACT SHOCK +
PRESSURE, INTERNAL + SHELL + STEEL

11-11591 SAGET P

CONTAINMENT OF THE EDF 1 POWER PLANT OF CHINON

ORNL-TR-1202 +. 13 PAGES, 6 FIGURES, CONSTRUCTION 19(11), 325-29, (1964) JCL

A GENERAL DESCRIPTION OF THE DESIGN CRITERIA AND METHODS OF CONSTRUCTION FOR THE SPHERICAL STEEL CONTAINMENT SHELL OF THE EDF-1 POWER REACTOR ARE GIVEN. SOME DIFFERENCES BETWEEN FRENCH AND U.S. CONTAINMENT DESIGNS ARE POINTED OUT.

*CONTAINMENT CONSTRUCTION + *CONTAINMENT DESIGN + *DESIGN CRITERIA + *SHELL + *SPHERE + BRITTLE FRACTURE +
CONTAINMENT STRUCTURE + CONTAINMENT VESSEL LOADING + STEEL

11-11592 STUDY OF A PRESTRESSED CONCRETE TANK FOR A 1000 MWE BOILING WATER REACTOR. QUARTERLY REPORT NO. 2. OCTOBER-DECEMBER 1965.

SOCIETE DETUDES INDUSTRIELLES, VILLEJUIF, FRANCE

EURAEC-1577 + EUR-2808 +. 62 PAGES, JANUARY 1966, CFSTI, \$3.00 CY, \$0.75 MN

PRELIMINARY DESIGN AND COST ESTIMATES FOR A SPHERICAL PRESTRESSED CONCRETE REACTOR VESSEL ARE DISCUSSED. MODEL TESTS ARE SUGGESTED.

*CONCRETE + *CONCRETE, PRESTRESSED + *CONTAINMENT RESEARCH AND DEVELOPMENT +
*CONTAINMENT, PRESSURE VESSEL + *SHELL + *SPHERE + CONTAINMENT DESIGN + HIGH TEMPERATURE +
PRESSURE, INTERNAL

11-11622 KRAMEROV AY + SHEVELEV YV

ENGINEERING CALCULATIONS OF NUCLEAR REACTORS

ANL-TRANS-270 +. 101 PAGES, FROM INZHENERNGE RASCHETY REAKTOROV, ATOMIZDAT, MOSCOW, PAGES 234-97 (1964), CFSTI \$4.00 CY, \$0.75 MN

THIS IS A TRANSLATION OF A RUSSIAN DOCUMENT. GENERAL CONCEPTS OF STRENGTH AND STRESS ANALYSIS ARE PRESENTED. PARTICULAR PROBLEMS RELATED TO NUCLEAR REACTOR STRUCTURES ARE DISCUSSED, MOST HAVING TO DO WITH THERMAL STRESSES. ELASTIC, PLASTIC, AND CREEP BEHAVIOR ARE CONSIDERED.

*CREEP BEHAVIOR + *ELASTICITY + *HIGH TEMPERATURE + *PLASTICITY + *STRESS ANALYSIS + CONTAINMENT ANALYSIS +
DEFORMATION + FAILURE, GENERAL + FUEL ELEMENT + FUEL INTEGRITY + STRESS

11-11630 REACTOR PRIMARY COOLANT SYSTEM RUPTURE STUDY. QUARTERLY PROGRESS REPORT NO. 3. OCTOBER - DECEMBER 1965

GENERAL ELECTRIC, SAN JOSE, ATOMIC POWER EQUIPMENT DEPT.

GEAP-5082 +. 43 PAGES, 22 FIGURES, 10 TABLES, 8 REFERENCES, DECEMBER 1965, CFSTI \$3.00 CY, \$0.75 MN.

GEAP-5082, JANUARY 1966, IS PROGRESS REPORT NO. 3 IN A SERIES. PROGRESS REPORT NO. 2 WAS GEAP-4964, OCTOBER, 1965, (NSIC 9925). FOUR ASPECTS OF THE STRUCTURAL PERFORMANCE OF REACTOR PRIMARY PIPING SYSTEMS ARE BEING STUDIED. THESE ASPECTS ARE (1) RELIABILITY, (2) STRESS ANALYSIS, (3) FRACTURE MECHANICS, AND (4) FATIGUE.

*BRITTLE FRACTURE + *FAILURE, FATIGUE + *FAILURE, PIPE + *PIPING + *RELIABILITY ANALYSIS + BIBLIOGRAPHY +
COMPUTER PROGRAM + CONTAINMENT RESEARCH AND DEVELOPMENT + ELASTICITY + LOSS OF COOLANT + METAL + STRESS +
STRESS ANALYSIS

11-11631 REACTOR PRIMARY COOLANT SYSTEM RUPTURE STUDY. QUARTERLY PROGRESS REPORT NO. 4 JANUARY - MARCH 1966

GENERAL ELECTRIC, SAN JOSE, ATOMIC POWER EQUIPMENT DEPT.

GEAP-5147 +. 66 PAGES, 69 FIGURES, 13 TABLES, 13 REFERENCES, MARCH 1966, CFSTI \$4.00 CY, \$0.50 MF

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11631 *CONTINUED*

GEAP-5147 IS PROGRESS REPORT NUMBER 4 IN A SERIES. FOUR ASPECTS OF THE STRUCTURAL PERFORMANCE OF REACTOR PRIMARY PIPING SYSTEMS ARE BEING STUDIED. THESE ASPECTS ARE (1) RELIABILITY, (2) STRESS ANALYSIS, (3) FRACTURE MECHANICS, AND (4) FATIGUE.

*BRITTLE FRACTURE + *FAILURE, FATIGUE + *FAILURE, PIPE + *PIPING + *RELIABILITY ANALYSIS + BIBLIOGRAPHY + COMPUTER PROGRAM + CONTAINMENT RESEARCH AND DEVELOPMENT + ELASTICITY + LOSS OF COOLANT + METAL + STRESS + STRESS ANALYSIS

11-11632 LAUTZENHEISER CE + WHITING AR
NONDESTRUCTIVE TESTING OF PLASTIC FATIGUE PRESSURE VESSELS. FINAL REPORT
SOUTHWEST RESEARCH INSTITUTE, SAN ANTONIO, TEXAS
SWRI-1228-3-3 +. 112 PAGES, NOVEMBER 5, 1965, CFSTI \$4.00 CY, \$1.00 MN

THIS IS THE FINAL TOPICAL REPORT ON A PROGRAM TO PROVIDE INFORMATION ON THE PROBABLE NUMBER OF PRESSURE CYCLES TO INITIATE A FATIGUE CRACK AND TO ESTIMATE THE PROPAGATION RATE OF A FATIGUE CRACK IN THE ELK RIVER REACTOR VESSEL DURING OPERATION. PRESSURE VESSELS SUBJECTED TO CYCLIC PRESSURE LOADING WERE INSPECTED NONDESTRUCTIVELY DURING TESTING, AND PLOTS WERE MADE OF DEFECT SIZE VS NUMBER OF CYCLES. THESE CURVES CAN BE USED TO INDICATE POSSIBLE LIFE EXPECTANCY, ON A FATIGUE BASIS, FOR PRESSURE VESSELS IN SERVICE UNDER SIMILAR CONDITIONS.

*FAILURE, FATIGUE + *FAILURE, PRESSURE VESSEL + *FLAW + *TEST, NONDESTRUCTIVE + BRITTLE FRACTURE + CONTAINMENT RESEARCH AND DEVELOPMENT + CONTAINMENT, PRESSURE VESSEL + STRESS

11-11766 YOSHIKI M + KANAZAWA T + ITAGAKI H
AN ANALYSIS OF BRITTLE-FRACTURE PROPAGATION
TOKYO UNIVERSITY, TOKYO, JAPAN
5 PAGES, 2 TABLES, 8 FIGURES, 8 REFERENCES, EXPERIMENTAL MECHANICS 6(9), PAGES 458-462 (SEPTEMBER 1966)

EXPERIMENTS WERE PERFORMED TO STUDY THE RELATIONSHIPS BETWEEN THE SPEED OF BRITTLE CRACK PROPAGATION AND STRESS, STRESS DISTRIBUTION, AND TEMPERATURE. THE STRESS DISTRIBUTION AROUND A PROPAGATION CRACK IS DIFFERENT FROM THAT AROUND A STATIONARY CRACK. THERE IS A POINT AHEAD OF A RUNNING CRACK AT WHICH THE NORMAL STRESS IS LESS THAN THE NOMINAL STRESS. CRACK SPEED INCREASES WITH STRESS AND DECREASES WITH TEMPERATURE. THESE TENDENCIES CAN BE EXPLAINED FROM THE TEMPERATURE DEPENDENCE OF THE SURFACE PLASTIC WORK AND THE ENERGY CONDITION OF CRACK PROPAGATION.

*BRITTLE FRACTURE + CONTAINMENT, PRESSURE VESSEL + ELASTICITY + FAILURE, PRESSURE VESSEL + FLAW + MEASUREMENT, STRAIN GAGE + STRESS ANALYSIS

11-11767 AWOJORI AO
HARMONIC ROCKING OF A RIGID RECTANGULAR BODY ON A SEMI-INFINITE ELASTIC MEDIUM
C. A. V. LTD., LONDON, ENGLAND
6 PAGES, 4 FIGURES, 5 REFERENCES, JOURNAL OF APPLIED MECHANICS 33(3), PAGES 547-552 (SEPTEMBER 1966)

THE PROBLEM OF THE ROCKING OF AN INFINITELY LONG, RIGID RECTANGULAR BODY ON THE FREE SURFACE OF A SEMI-INFINITE ELASTIC MEDIUM IS HERE SOLVED. DYNAMIC STRESS DISTRIBUTIONS UNDER THE RIGID BODY AND RESONANCE CURVES FOR MOTION OF THE BODY ARE DERIVED FROM THE SOLUTION OF THESE EQUATIONS. A GRAPHICAL REPRESENTATION OF THE THEORETICAL RESULTS PROVIDES A NOVEL METHOD FOR ESTIMATING POISSON'S RATIO OF SOIL FROM A KNOWLEDGE OF THE ROCKING FREQUENCY OF A BUILDING. SUITABLE PUBLISHED RESULTS OF TESTS ON ACTUAL BUILDINGS WERE USED TO INDICATE THE APPLICATION OF THIS METHOD.

*EARTHQUAKE + CONTAINMENT, SHOCK GENERATION AND PROTECTION + ELASTICITY + GEOLOGICAL CONSIDERATION, GENERAL + IMPACT SHOCK + MATHEMATICAL STUDY + SEISMOLOGY

11-11768 WEISS V + SCHAEFFER G + FEHLING J
EFFECT OF SECTION SIZE ON NOTCH STRENGTH
SYRACUSE UNIVERSITY + SYLVANIA ELECTRIC PRODUCTS, INC. + UNIVERSITY OF ALBERTA
5 PAGES, 3 FIGURES, 3 TABLES, 34 REFERENCES, JOURNAL OF BASIC ENGINEERING 88(3), PAGES 675-681 (SEPTEMBER 1966)

DATA ARE REPORTED FOR NOTCHED CYLINDRICAL TENSILE SPECIMENS AND NOTCHED RECTANGULAR BEND SPECIMENS OF H-11 STEEL, 2014-T6 AND 7075-T6 ALUMINUM, AND PLEXIGLASS. THE NOTCH STRENGTH DECREASES WITH INCREASING SIZE FOR ALL SERIES INVESTIGATED. THE LOSS IN STRENGTH WITH DECREASING SIZES IS DUE AT LEAST TO TWO FACTORS - AN INCREASE IN STRESS CONCENTRATION FACTOR AND AN INCREASE IN CRITICALLY STRESSED VOLUME WITH INCREASING SIZE. A LOSS IN STRENGTH WITH INCREASING SIZE GREATER THAN THAT PREDICTED BY FRACTURE MECHANICS WAS OBSERVED FOR SOME OF THE H-11 STEEL SPECIMENS. INSIGHT INTO THE PROBLEM IS GAINED BY CONSIDERING A MODEL OF AN INHOMOGENEOUS MATERIAL CONTAINING EXTERNAL NOTCHES.

*BRITTLE FRACTURE + *FLAW + *STEEL + *TENSILE PROPERTY + ALUMINUM + CONTAINMENT, PRESSURE VESSEL + FAILURE, PRESSURE VESSEL + METAL

11-11769 REYNOLDS MB
FRACTURE TOUGHNESS OF SOME ENGINEERING ALLOYS
GENERAL ELECTRIC COMPANY, VALLECITOS ATOMIC POWER LABORATORY
GEAP-5014 +. 14 PAGES, 1 FIGURE, 5 TABLES, 15 REFERENCES, MARCH 1966, CFSTI \$1.00 CY

THIS REPORT CONTAINS A BRIEF SUMMARY OF THE PRINCIPLES GOVERNING FRACTURE MECHANICS, AND A

ACCESSION NUMBER 11-11631 TO 11-11769

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11769 *CONTINUED*

TABULAR SUMMARY OF FRACTURE-TOUGHNESS DATA FOR A302B PRESSURE VESSEL STEEL, SOME NI-CR-MO-Y STEELS, ZIRCALOY, SOME 7000-SERIES ALUMINUM ALLOYS, AND 4340 STEEL.

*ALUMINUM + *BRITTLE FRACTURE + *FLAW + *STEEL + *TENSILE PROPERTY + CONTAINMENT, PRESSURE VESSEL + ELASTICITY + FAILURE, PIPE + FAILURE, PRESSURE VESSEL + METAL + THICKNESS

11-11953 MEHANN RO

VENTILATION-FILTER CHANGE AT NS SAVANNAH, SEPTEMBER 20, 1966

FIRST ATOMIC SHIP TRANSPORT, INC., NEW YORK, NEW YORK

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(41), PAGES 14-15 (OCTOBER 10, 1966) DOCKET NO. 5G-238

A QUARTERLY TEST OF THE IODINE-REMOVAL EFFICIENCY OF BOTH VENTILATION FILTERS (SEPTEMBER 19, 1966) SHOWED REMOVAL FACTORS OF 504 AND 806. THE FILTERS WERE REPLACED AND CHECKED AS 11,681 AND 1,980. NO KNOWN REASON EXISTS FOR THIS APPARENT SIMULTANEOUS FAILURE. THE GASKET-SEALING METHODS WILL BE REEXAMINED.

*FAILURE, EQUIPMENT + *FAILURE, SIMULTANEOUS + *FILTER EFFICIENCY + *VENTILATION SYSTEM + N S SAVANNAH + REACTOR, MARITIME + REACTOR, PRESSURIZED WATER

11-11976 GALLAGHER EV + WIEDERMANN AH

STUDIES OF REACTOR CONTAINMENT. BIMONTHLY PROGRESS REPORT, APRIL-MAY 1966

ILLINOIS INSTITUTE OF TECHNOLOGY RESEARCH INSTITUTE

IITRI-T6042-20 + IITRI-578P21-20 +. 26 PAGES, 24 FIGURES, APRIL-MAY 1966, CFSTI \$2.00 CY, \$0.50 MN

THIS RESEARCH PROGRAM PERTAINS TO THE GENERATION, TRANSMISSION, AND ATTENUATION OF SHOCK WAVES IN CONTAINMENT STRUCTURES CAUSED BY REACTOR EXCURSIONS OR LOSS-OF-COOLANT ACCIDENTS. PHASE 1, CRUSHABLE-SHIELD ANALYSIS AND DESIGN, AND PHASE 2, SHOCK-IMPINGEMENT EXPERIMENTS ON CRUSHABLE SHIELDS, ARE COMPLETE. PHASE 3, COOLANT-DECOMPRESSION EXPERIMENTS AND ANALYSIS, IS STILL IN PROGRESS. A COMPUTER PROGRAM, SWIMM, HAS BEEN WRITTEN TO SOLVE COMPLEX ONE-DIMENSIONAL STRESS WAVE PROBLEMS.

*CONTAINMENT ANALYSIS + *CONTAINMENT, SHOCK GENERATION AND PROTECTION + COMPUTER PROGRAM + CSE (CONTAINMENT SYSTEMS EXPERIMENT) + REACTOR, PRESSURIZED WATER

11-11977 SALMON MA

STUDIES OF REACTOR CONTAINMENT STRUCTURES

ILLINOIS INSTITUTE OF TECHNOLOGY RESEARCH INSTITUTE

IITRI-578P22-11 +. 122 PAGES, 61 FIGURES, 2 TABLES, 14 REFERENCES, JUNE 1966, CFSTI \$4.00 CY

THIS IS THE FINAL SUMMARY REPORT ON THE IITRI CONTAINMENT-STRUCTURES RESEARCH PROGRAM. PLASTIC ANALYSIS HAS BEEN USED EXTENSIVELY. THE STATIC AND DYNAMIC RESPONSES OF MEMBRANE SHELLS HAVE BEEN STUDIED. THE PRESSURE REQUIRED TO CAUSE FAILURE OF A MEMBRANE SHELL WITHOUT PENETRATIONS MAY GREATLY EXCEED THE YIELD PRESSURE. A METHOD FOR ANALYZING A SPHERICAL SHELL WITH A RIGIDLY REINFORCED OPENING WAS DEVELOPED. THEORY PREDICTS AND TEST RESULTS CONFIRM THAT RIGIDLY REINFORCED OPENINGS SUBSTANTIALLY REDUCE THE BURST STRENGTH OF CIRCULAR PLATES. THE IMPLICATION IS THAT THE SAME IS TRUE FOR PRESSURE VESSELS AND CONTAINMENT STRUCTURES. AN ELASTIC-PLASTIC FINITE-ELEMENT METHOD OF ANALYSIS IS DESCRIBED.

*BURST PRESSURE + *CONTAINMENT PENETRATION + *CONTAINMENT STRUCTURE + *PLASTICITY + *SHELL + COMPARISON, THEORY AND EXPERIENCE + COMPUTER PROGRAM + CONTAINMENT INTEGRITY + CONTAINMENT RESEARCH AND DEVELOPMENT + CYLINDER + FAILURE, GENERAL + INSTABILITY + MEASUREMENT, STRAIN GAGE + NOZZLE + PRESSURE, INTERNAL + SPHERE + STEEL + STRESS ANALYSIS + TEST, DESTRUCTIVE

11-11978 SAMUELS DE

DESIGN FACTORS INFLUENCING THE CONTAINMENT OF INTERNAL EXPLOSION IN FAST REACTORS

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, A.W.R.E.

GMELIN-AEC-CONF-65-307-18 + CONF-651,009-17 +. 14 PAGES, OCTOBER 1965, PRESENTED AT CONFERENCE ON SAFETY, FUELS, AND CORE DESIGN IN FAST POWER REACTORS, ARGONNE, ILLINOIS, OCTOBER 11-14, 1965, CFSTI

THIS DISCUSSION RELATES TO THE SAFETY OF LIQUID-COOLED FAST REACTORS. CORE MELTDOWN MAY EVENTUALLY BE MADE IMPOSSIBLE, BUT AT PRESENT IT CANNOT BE DECLARED INCREDIBLE. THE SEQUENCE OF EVENTS FOLLOWING A CORE EXPLOSION IS DESCRIBED. STRUCTURAL LOADING AND RESPONSE MECHANISMS ARE IDENTIFIED. A CONTAINMENT DESIGN WHICH IS BALANCED FOR NORMAL OPERATING LOADS IS UNLIKELY TO BE PROPERLY BALANCED FOR THE CONTAINMENT OF EXPLOSIONS. MODEL STUDIES HAVE BEEN PERFORMED.

*ACCIDENT, EXPLOSION + *CONTAINMENT, SHOCK GENERATION AND PROTECTION + *EXCURSION, LARGE + *EXPLOSION + *REACTOR, FAST + CONTAINMENT INTEGRITY + CONTAINMENT, MISSILE GENERATION AND PROTECTION + DESIGN CRITERIA + FAILURE, GENERAL + IMPACT SHOCK + PRESSURE, INTERNAL + SHOCK WAVE

11-11979 MACKENZIE A + DALRYMPLE EW + SCHWARTZ F

DESIGN OF PRESSURE VESSELS FOR CONFINING EXPLOSIVES

PICATINNY ARSENAL, DOVER, NEW JERSEY

AD-467730 + TM-1643 +. 5 REFERENCES, 25 PAGES, 10 FIGURES, JULY 1965

FACTORS WHICH MUST BE CONSIDERED IN DESIGNING PRESSURE VESSELS TO WITHSTAND, IN A RADIATION ENVIRONMENT, HIGH, RAPIDLY APPLIED DYNAMIC IMPULSES (SUCH AS EXPLOSIONS) ARE DEFINED AND DISCUSSED. OF VARIOUS METALS TESTED FOR USE IN THE WALLS OF SUCH VESSELS, SEVERAL ALUMINUM

CATEGORY 11
CONTAINMENT OF NUCLEAR FACILITIES

11-11979 *CONTINUED*

ALLOYS WERE FOUND MOST PROMISING. THE REPORT CONTAINS SPECIAL SECTIONS ON THE DESIGN OF END CLOSURES, SHOCK ATTENUATION, PROVIDING FOR ELECTRICAL LEAD-THROUGHS NEEDED FOR INSTRUMENTATION, AND THE USE OF A THIN WINDOW IN THE VESSEL (NEEDED FOR IRRADIATION EXPERIMENTS). FROM THIS INFORMATION A PRESSURE VESSEL FOR A PARTICULAR APPLICATION CAN BE DESIGNED.

*ACCIDENT, EXPLOSION + *CONTAINMENT, MISSILE GENERATION AND PROTECTION +
*CONTAINMENT, SHOCK GENERATION AND PROTECTION + *EXCURSION, LARGE + *EXPLOSION + CONTAINMENT INTEGRITY +
CONTAINMENT, PRESSURE VESSEL + IMPACT SHOCK + PRESSURE, INTERNAL + SHOCK WAVE

11-12037 INTERIM REPORT. HEALTH AND SAFETY REVIEW OF MH-1S (STURGIS) FLOATING NUCLEAR POWER PLANT
FINAL SAFEGUARDS REPORT
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-66-4 +. 25 PAGES, 5 REFERENCES, MARCH 1, 1966, OCE

THE REVIEW, BASED ON FINAL SAFEGUARDS REPORTS AND ADDENDA, IS INTENDED ONLY FOR FT. BELVOIR OPERATION. A PREVIOUS REVIEW SHOWED THE UNIQUE SAFETY FEATURE OF MH1A TO BE SATISFACTORY BUT INDICATED 8 (OUT OF 27) AEC CONSTRUCTION-PERMIT CRITERIA WERE NOT FULFILLED, PRIMARILY BECAUSE OF LACK OF DETAILED INFORMATION. THIS REPORT CONSIDERS ONLY THOSE 8 CRITERIA (CRITERIA 3, 6, 7, 13, 15, 16, 19, AND 20). ALL ITEMS WERE SATISFACTORY EXCEPT 7, 19 AND 20. ITEM 7 CONSIDERED A ROD EJECTION OF THE CENTER ROD (2.8 PERCENT REACTIVITY) AS GIVING ONLY MINOR FUEL MELTING. HOWEVER, THE MOST CONSERVATIVE DOPPLER COEFFICIENT WAS NOT USED. ITEMS 19 AND 20 - THE CONTAINMENT IS SCHEDULED TO BE LEAK-RATE TESTED AT 50 PSIG RATHER THAN AT THE 140.3-PSI DESIGN PRESSURE. THUS THERE MAY BE UNKNOWN LEAKAGE PATHS EVIDENT ONLY AT HIGH PRESSURE.

*SAFETY EVALUATION + ACCIDENT, CONTROL ROD EJECTION + CONTAINMENT, HIGH PRESSURE +
MH 1A (MOBILE HIGH POWER PLANT 1A) + REACTOR, ARMY + REACTOR, PRESSURIZED WATER + TEST, LEAK RATE

11-12039 CORNELL DC + RIPARBELLI C
TARGET - AN IBM COMPUTER CODE FOR THE STRESS ANALYSIS OF BODIES OF REVOLUTION - INPUT INSTRUCTIONS (1964)
GENERAL ATOMIC
GAMD-5001 (REV.2) + EUR-2925.E +. 93 PAGES, 1964, CFSTI \$3.00 CY

THE IBM CODE TARGET, WRITTEN IN THE FORTRAN IV LANGUAGE AND COMPILED FOR THE 7044 DIGITAL COMPUTER, IS DESCRIBED AND DISCUSSED. THE TARGET PROGRAM IS A NUMERICAL METHOD FOR CALCULATING THE DEFORMATION OF BODIES OF REVOLUTION AND THE CONSEQUENT STRESS DISTRIBUTION. THE METHOD EMPLOYS THE CONCEPT STIFFNESS COEFFICIENTS. EXAMPLE PROBLEMS OF A THICK PLATE IN PURE BENDING AND A REINFORCED CONCRETE PRESSURE VESSEL ARE TREATED.

*COMPUTER PROGRAM + *CONTAINMENT, PRESSURE VESSEL + *STRESS ANALYSIS + COMPUTER, DIGITAL +
CONCRETE, PRESTRESSED + STEEL + TARGET (THRL ADV RCTR GASCOOLED EXPLOITING TH)

11-12040 CAVALLARO L
THERMAL PROTECTION OF CONCRETE PRESSURE VESSEL BY LAMINATED INSULATION AND INTERNAL COOLING (1964)
GENERAL ATOMIC
GAMD-5432 + EUR-2915 E +. 44 PAGES, JUNE 1964, CFSTI \$1.00 CY

TO PRESERVE THE INTEGRITY OF A CONCRETE PRESSURE VESSEL, THE TEMPERATURE MUST BE KEPT WITHIN THE LIMIT OF 150 F. WATER COOLING OF THE LINER IS PROVIDED FOR THIS PURPOSE. HOWEVER, TO MAKE THE COOLING PRACTICAL, IT IS IMPERATIVE THAT THE QUANTITY OF HEAT TRANSMITTED TO THE LINER BE KEPT AT A LOW LEVEL. TWO MEANS TO ACHIEVE THIS LIMITATION ARE CONSIDERED - (1) APPLYING A LAMINATED INSULATION TO THE LINER, AND (2) COOLING THE SPACE BETWEEN THE PRIMARY LOOP OF THE PRESSURE VESSEL. USING THE TARGET DESIGN AS A REFERENCE, AN APPROXIMATED EVALUATION OF THE ECONOMICS OF THE TWO SYSTEMS IS CARRIED OUT, AND THE AREAS REQUIRING FURTHER, MORE DETAILED INVESTIGATION ARE OUTLINED.

*CONTAINMENT, PRESSURE VESSEL + *THERMAL INSULATION + CONCRETE, PRESTRESSED +
TARGET (THRL ADV RCTR GASCOOLED EXPLOITING TH)

11-12042 HOWL DA
INSTANTANEOUS COLLAPSE PRESSURES OF GROOVED FUEL ELEMENT CLADDING FOR PRESSURIZED WATER REACTORS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, SPRINGFIELD
5 PAGES, 7 FIGURES, 3 REFERENCES, JOURNAL BRITISH NUCLEAR ENGINEERING SOCIETY 5(2), PAGES 148-152 (APRIL 1966)

CLADDING WITH A THERMOCOUPLE PEENED INTO A GROOVE HAS AN INSTANTANEOUS COLLAPSE PRESSURE EQUAL TO THAT OF THE PLAIN UNGROOVED CLADDING. IF THE THERMOCOUPLE IS DISPLACED OR OMITTED, THE SMALL PORTION, 1/4 IN LONG, WHERE THE GROOVE IS DEEPEMED IS NOT LONG ENOUGH TO HAVE AN EFFECT. SHALLOW GROOVES DO NOT REDUCE THE COLLAPSE PRESSURE VERY MUCH, BUT AS THE GROOVE DEPTH INCREASES, A DISCONTINUITY IS REACHED AND DEEPER GROOVES PRODUCE A STEEP DROP IN COLLAPSE PRESSURE. INCREASING THE NUMBER OF GROOVES AND VARYING THEIR ANGULAR SEPARATION HAS LITTLE OR NO EFFECT, AND TAKING THE GROOVES THROUGH AN END WELD IN THE CLADDING HAS NO EFFECT.

*FAILURE, CLADDING + *FUEL ELEMENT + REACTOR, PRESSURIZED WATER

CATEGORY 12
PLANT SAFETY FEATURES

12-07702 BENNETT EC
INSPECTION OF CRITICAL PROCESS-TUBE COMPONENTS AT HANFORD
HANFORD ATOMIC PRODUCTS OPERATION, GENERAL ELECTRIC CO.
RL-SA-44 +. 5 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 2-3

THE ALUMINUM PROCESS TUBES (18,000 AT ONE TIME) ARE SUBJECT TO EROSION AND CORROSION,
EXPENSIVE TO REPLACE EITHER EARLY OR TOO LATE. EDDY-CURRENT PROBES ARE USED IN PLACE TO
DETERMINE WALL THICKNESS (AND CORROSION RATE). INTERPRETATION OF THE DATA REMAINS AN ART,
AND TUBES ARE CHECKED IN A HOT CELL. NOZZLES AND FITTINGS ARE SUBJECT TO DAMAGE AND ARE
INSPECTED ROUTINELY. PRESSURE GAGES ARE GIVEN VARIOUS ROUTINE MAINTENANCE, WHICH HAS CUT THE
MALFUNCTION RATE TO A FOURTH.

*MAINTENANCE AND REPAIR + *TEST, NONDESTRUCTIVE + CORROSION + HANFORD SITE + INSTRUMENTATION, PROCESS +
OPERATING EXPERIENCE + REACTOR, PRESSURE TUBE

12-09303 LAMBERTUS H
KERR-MCGEE EMPLOYEES EXAMINED IN Y-12 WHOLE-BODY COUNTER
KERR-MCGEE OIL INDUSTRIES, OKLAHOMA CITY, OKLAHOMA
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 46, APRIL 11, 1966

EMPLOYEES INVOLVED IN AN INCIDENT AT CRUSHING PLANT, JUNE 23, 1964, SHOWED NO SIGNIFICANT
THORIUM CONTAMINATION WHEN EXAMINED IN Y-12 WHOLE-BODY COUNTER.

*INGESTION + *THORIUM + INCIDENT, ACTUAL, GENERAL

12-09307 INTERIM ANALYSIS OF NFS STACK CRACK AND VIBRATION PROBLEMS, MARCH 25, 1966
NUCLEAR FUEL SERVICES, INC.
3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 35-37, APRIL 11, 1966, DOCKET NO. 50-201

NFS STEEL STACK WAS PROTECTED AGAINST VORTEX-INDUCED VIBRATIONS BY SMALL RADIAL FINS. IN
NOVEMBER 1964, SUSTAINED GUSTS VIBRATED STACK, AND METAL YIELDED. SPOILERS COULD NOT PROTECT
AGAINST GUSTS, SO CONCRETE SHEATH ADDED AFTER STACK EXAMINED AND FOUR BASE LUGS REPAIRED.
LATER, A CIRCUMFERENTIAL CRACK DEVELOPED AT THE CYLINDRICAL/CONICAL JUNCTION DUE TO FATIGUE,
POOR WELDING, AND STRESS CONCENTRATION. THIS WELD WAS NOT GIVEN A THOROUGH INSPECTION PRIOR
TO CONCRETE SHEATH. NOW ALL CIRCUMFERENTIAL WELDS ARE BEING TESTED WITH DYES AND ULTRASONIC
DEVICES.

*FAILURE, FATIGUE + *STACK + *WELDING + FAILURE, ADMINISTRATIVE CONTROL + FAILURE, DESIGN ERROR +
NUCLEAR FUEL SERVICES (NFS) + OPERATING EXPERIENCE + RADIOCHEMICAL PROCESSING + WIND STATISTICS

12-09534 MOORE JC
RESEARCH REACTOR FAULT ANALYSIS - PART 2 -
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
1 PAGE, NUCLEAR ENGINEERING, 11(119), PP. 306 (APRIL 1966)

PART 1 DETAILED THE METHODS OF CLASSIFYING AND PRESENTING DATA ON FAULT INCIDENCE, THE
THEORETICAL BASIS FOR CORRELATING CALCULATIONS, AND OPENED THE DISCUSSION ON TECHNIQUES USED
FOR MAJOR AND MINOR FAULT ANALYSIS. PART 2 CONTINUES WITH A STUDY OF TIME INCIDENCE AND THEN
INVESTIGATES THE VALIDITY OF COMPUTING PLANT AVAILABILITY AND RELIABILITY AND EXAMINES THEIR
RELEVANCE TO MAINTENANCE PRACTICE.

*MAINTENANCE AND REPAIR + FAILURE, COMPONENT + FAILURE, EQUIPMENT + RELIABILITY, SYSTEM

12-09548 SELF-CHECKING IONIZATION RADIATION DETECTOR
PRESS REL. IN-680 + FRENCH PAT. 1,390,550 +. MARCH 10, 1964, ABSTRACT ONLY, PATENT (FOREIGN)

INVENTION RELATES TO AN IONIZATION CHAMBER RADIATION DETECTOR IN WHICH A CONTROLLABLE SOURCE
OF ELECTRONS IS DISPOSED SO AS TO PROVIDE FOR THE CHECKING OR CALIBRATION OF THE DETECTOR
AND/OR ITS INSTRUMENTATION. THE SOURCE, WHEN ENERGIZED, EMITS ELECTRONS IONIZING THE
SURROUNDING GAS AND THEREBY PROVIDING A CURRENT IN THE MEASURING AND UTILIZATION CIRCUITRY.

*FRANCE + *PERSONNEL PROTECTIVE DEVICE

12-09557 BANCROFT AR + CHARLESWORTH DH + DUERKSEN JH
IMPURITY EFFECTS IN THE FOULING OF HEAT TRANSFER SURFACES BY ORGANIC COOLANTS
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO
AECL-1913 +. 1964, AECL, \$1.50

RESULTS OF SMALL LOOP TESTS SHOWED THAT CHLORINE IS BY FAR THE STRONGEST FACTOR IN FOULING,
ALTHOUGH SMALL EFFECTS WERE OBSERVED DUE TO RADIOLYSIS PRODUCTS, WATER, AND OXYGEN. A
1000-HOUR OUT-OF-PILE TEST SHOWED THAT A DEPOSITION RATE OF 0.2 MICROGRAM PER CU. CM PER HR
CAUSED AN INCREASE OF 25 C/YEAR IN THE SHEATH TEMPERATURE OF ELEMENTS RATED AT 100 W/SQ.CM.
IN-PILE TESTS SHOWED THAT, WITH CONTINUOUS COOLANT PURIFICATION AND EXCLUSION OF CHLORINE,
ETC., FOULING UNDER POWER-REACTOR CONDITIONS CAN BE RESTRICTED TO ACCEPTABLE RATES.

*COOLANT CHEMISTRY + *FILM, GENERAL + *FUEL ELEMENT + *HEAT TRANSFER + *SURFACE, GENERAL + CHLORINE +
OMRE (ORGANIC MODERATED REACTOR EXPERIMENT) + REACTOR, ORGANIC COOLED

CATEGORY 12
PLANT SAFETY FEATURES

12-09791 CARR WH
POLICIES AND PROCEDURES USED IN THE UNITED STATES FOR DECONTAMINATING HOT CELLS
OAK RIDGE NATIONAL LABORATORY
3 PAGES, REFERENCES, NUCLEAR SAFETY, 7(2), PP. 212-214 (WINTER 1965-1966)

BOTH CONTAMINATION AND DECONTAMINATION INCLUDE CHEMICAL AND PHYSICAL MECHANISMS. CHEMICAL METHODS FOR DECONTAMINATION INCLUDE THE USE OF SOLUTIONS, SUCH AS FORMULATIONS BASED ON OXALIC ACID, THAT ARE SUPERIOR TO NITRIC ACID AND SODIUM HYDROXIDE. PHYSICAL METHODS INCLUDE VACUUM CLEANING, STEAM CLEANING, SANDBLASTING, SCRAPING, ULTRASONIC CLEANING, ETC.

*DECONTAMINATION + *HOT CELL

12-09831 BECKERS RM + DENKINS RF + GLEN HM + GOLSON TJ + KAHN JE + RENFRO GW + STEED JA
ENGINEERING DESIGN PRACTICES AT ORNL FOR FACILITIES CONTAINING RADIOACTIVE MATERIALS
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1459 +. 85 PAGES, 43 FIGURES, APRIL 1966, CFSTI, \$3.00 FS, \$0.75 MN

THIS REPORT IS A COMPILATION OF SEVEN PAPERS BY MEMBERS OF THE GENERAL ENGINEERING AND CONSTRUCTION DIVISION OF OAK RIDGE NATIONAL LABORATORY AS PART OF THE APPLIED HEALTH PHYSICS COURSE FOR STATE HEALTH DEPARTMENT PERSONNEL CONDUCTED BY THE OAK RIDGE INSTITUTE OF NUCLEAR STUDIES IN SEPTEMBER AND OCTOBER OF 1965. THE INTENT OF THE PAPERS IS TO CALL ATTENTION TO DESIGN PROBLEMS FOR LABORATORIES AND OTHER FACILITIES HANDLING RADIOACTIVE MATERIALS. THE INFORMATION SHOULD BE HELPFUL IN GUIDING ENGINEERS IN DESIGNING OR SPECIFYING THE SPECIAL TOOLS AND EQUIPMENT REQUIRED FOR HANDLING RADIOACTIVE MATERIALS.

*DESIGN CRITERIA + *GLOVE BOX + *HOT CELL + AIR CLEANING + CONTAINMENT STRUCTURE + CONTAINMENT, GENERAL + DECONTAMINATION + ORNL (OAK RIDGE NATIONAL LABORATORY) + SHIELDING + WASTE HANDLING

12-09850 DUHAMEL F + LAVIE JM
THE LIMITATION OF THE QUANTITIES OF RADIOACTIVE SUBSTANCES MANIPULATED OR TRANSPORTED. EVALUATION OF ACCIDENTAL EXPOSURES TO RADIATION
ATOMIC ENERGY COMMISSION, NUCLEAR RESEARCH CENTER, SACLAY, FRANCE
AEC-TR-6525 +. 35 PAGES, TRANSLATED FROM HEALTH PHYSICS 10, PP. 453-468 (1964), JCL \$3.60 FS, \$1.25 MF

VARIOUS NATIONAL AND INTERNATIONAL GROUPS HAVE STUDIED THE PROBLEM OF LIMITING THE QUANTITIES OF RADIOACTIVE SUBSTANCES THAT MAY BE MANIPULATED UNDER CERTAIN OPERATING CONDITIONS. THE MOST VALUABLE STUDIES HAVE BEEN ACHIEVED ON THE BASIS OF RADIOBIOLOGY. NOW, IT IS CLEAR THAT THE RESULTS FROM RADIOBIOLOGY DO NOT SUFFICE TO ESTABLISH A COMPLETE AND SCIENTIFIC BASIS. FOR PRACTICAL APPLICATION, NUMEROUS COMPLEMENTARY HYPOTHESES MUST BE MADE. IN ATTEMPTING TO INTERRELATE OPERATIONS THAT ARE VERY DIFFERENT, THE AUTHORS PROPOSE A PROCEDURE WHICH, ALTHOUGH NOT SCIENTIFICALLY RIGOROUS, MAKES APPARENT THE RELATIONSHIPS BEING HYPOTHECATED BETWEEN THE FUNDAMENTAL THEORETICAL ASSUMPTIONS AND THE PRACTICAL VALUE TO BE OBSERVED. THIS PROCEDURE PERMITS ONE TO EVALUATE, UNAMBIGUOUSLY, THE MAXIMUM QUANTITIES TO BE MANIPULATED IN THE CASE OF ANY RADIONUCLIDE, CHEMICAL FORM, PHYSICAL STATE, DEGREE OF CONTAINMENT, TYPE OF OPERATION, KIND OF FACILITY AND TECHNICAL SKILL OF THE OPERATORS. THUS THIS PROCEDURE POSSESSES GREAT FLEXIBILITY AND PERMITS ONE TO DETERMINE THESE QUANTITIES ON A SCALE EXTENDING OVER A RANGE OF 10 TO THE 14.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + ACCIDENT, EXPOSURE + ADMINISTRATIVE CONTROLS AND PRACTICES + TRANSPORTATION AND HANDLING

12-10111 SODIUM-HEATED STEAM GENERATOR DEVELOPMENT. ADDENDUM TO PRELIMINARY DESIGN REPORT FULL SIZE STEAM GENERATOR SODIUM WATER REACTION
RABCOCK AND WILCOX COMPANY, BARBERTON, OHIO
BW-67-2(A) +. 160 PAGES, SEPTEMBER 15, 1965, CFSTI, \$5.00 CY, \$1.50 MN

THE STEAM GENERATOR UNDER THIS CONTRACT IS BEING DESIGNED WITH A SINGLE TUBE WALL SEPARATING THE SODIUM AND WATER. THE DESIGN OF THE FULL-SIZE AND PROTOTYPE STEAM GENERATOR IS SUCH THAT THE STEAM-GENERATOR SHELL IN EACH CASE IS PROTECTED BY A LINER SEPARATED FROM THE SHELL BY AN INERT-GAS ANNULUS. A GAS CUSHION IS PROVIDED OVER THE SODIUM IN EACH STEAM GENERATOR, AND RELIEF VALVES AND RUPTURE DISKS ARE PROVIDED FOR THE SAFE RELIEF OF THE PRODUCTS OF A SODIUM-WATER REACTION. AS A RESULT OF THIS STUDY IT IS CONCLUDED THAT THE FULL-SIZE STEAM GENERATOR WILL WITHSTAND A CREDIBLE NUMBER OF TUBES FAILING SIMULTANEOUSLY WITHOUT BECOMING A HAZARD TO NEARBY PERSONNEL AND EQUIPMENT.

*ACCIDENT ANALYSIS + *DESIGN STUDY + *METAL WATER REACTION + *SODIUM

12-10262 CHASSANY JP + COHENDEY G + RODIER J
RADIOPROTECTION AND DECONTAMINATION OPERATION ON THE CENTRAL VIBRATING CHANNELS OF THE REACTOR G.3
COMMISSARIAT A L ENERGIE ATOMIQUE, CHUSCLAN, FRANCE
CEA-R-2781 +. 19 PAGES, 3 FIGURES, MAY, 1965, DEP. MN, IN FRENCH

THE DOSE RATE IN THE VIBRATING CHANNELS ROOM OF THE DISCHARGE SYSTEM, WHICH IS DUE TO THE CONTAMINATION OF ONE OF THE CHANNELS BY A RUPTURED CAN, WAS HIGH. IT WAS NECESSARY TO INTERVENE IN ORDER THAT NORMAL MAINTENANCE COULD BE CARRIED OUT ON THIS EQUIPMENT. THE OPERATION WAS CARRIED OUT FROM A NEIGHBOURING ROOM, USING CLEANING TUBES, AND THEN DIRECTLY, AFTER NUMEROUS PRECAUTIONS HAD BEEN TAKEN. RADIO-PROTECTION WAS MADE VERY DIFFICULT BECAUSE OF THE IRRADIATION AND OF THE POWDERY STATE OF THE CONTAMINATION. THE AVERAGE INDIVIDUAL INTEGRATED DOSE FOR THE 122 PERSONS HAVING TAKEN PART IN THIS 2-MONTH OPERATION WAS 362 MREM. THANKS TO THE CLOSE COLLABORATION BETWEEN THE OPERATIONAL, EMERGENCY AND RADIO-PROTECTION PERSONNEL, THIS OPERATION WAS EXECUTED SMOOTHLY AND RAPIDLY.

CATEGORY 12
PLANT SAFETY FEATURES

12-10262 *CONTINUED*

*DECONTAMINATION + *MAINTENANCE AND REPAIR + *PERSONNEL EXPOSURE, RADIATION + CONTAMINATION

12-10312 AYRES JA

DECONTAMINATION OF NUCLEAR REACTOR SYSTEMS

BATTTELLE-NORTHWEST

5 PAGES, 4 REFERENCES, MATERIALS PROTECTION, 5(1), PP. 11-15 (JANUARY 1966)

MOST CHEMICAL CLEANING PROBLEMS OF NUCLEAR REACTOR SYSTEMS ARE IDENTICAL. FILMS AND SCALES CAN FORM ON VESSEL OR PIPE WALLS USED TO STORE OR TRANSPORT CHEMICAL SOLUTIONS, RAW WATER, OR OTHER LIQUIDS. THESE SCALES AND FILMS CAUSE PROBLEMS OF HEAT TRANSFER, FLOW BLOCKAGE, OR SLUDGE FORMATION. THIS ARTICLE DISCUSSES ONE CHEMICAL CLEANING PROBLEM UNIQUE TO A NUCLEAR REACTOR SITE - THE CLEANING OF THE PRIMARY SYSTEM OF THE REACTOR. SO FAR DECONTAMINATION HAS BEEN USED SPARINGLY AND MANY OPERATORS CONSIDER IT A LAST RESORT. THIS THINKING IS BASED PRIMARILY ON LACK OF EXPERIENCE. VERY FEW REACTORS HAVE BEEN DECONTAMINATED AND VERY LITTLE LITERATURE IS AVAILABLE ON THE SUBJECT. AS MORE EXPERIENCE IS GAINED, DECONTAMINATION WILL BE CONSIDERED A VALUABLE ROUTINE PROCEDURE TO INCREASE EFFICIENCY AND A METHOD FOR RETURNING CONTAMINATED REACTORS TO OPERATION.

*DECONTAMINATION + CHEMICAL REACTION + CONTAMINATION + CORROSION + FAILURE, FUEL ELEMENT

12-10456 NICKEL HC

ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING

ALLIS-CHALMERS

ACNP-66546 +. 3 PAGES, 1 FIGURE, JUNE 1966, DOCKET 115-5, PP. V-3-1 THROUGH V-3-3, AMENDMENT NO. 25, PDR

QUESTION V-3. VARIOUS REDUNDANT VALVES ARE BEING ADDED TO THE BORON-INJECTION CORE-SPRAY SYSTEM TO MEET AEC SPECIFICATIONS FOR REDUNDANCY. ONE SET OF VALVES WILL BE NITROGEN-OPERATED AND THE OTHER AIR-OPERATED.

*LACROSSE BOILING WATER REACTOR + *REDUNDANCE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SHUTDOWN SYSTEM, SECONDARY + *VALVE + REACTOR, BOILING WATER

12-10600 APPLICATION FOR LICENSES FPCE PLANT

ISOICHEM INC.

750 PAGES APPROX., 83 FIGURES, 71 TABLES, REFERENCES, JUNE 1966, DOCKET NO. 50-258, PDR

REPORT GIVES ALL THE GENERAL AND DETAILED TECHNICAL INFORMATION REQUIRED FOR AEC LICENSING OF A RADIOCHEMICAL PLANT. INCLUDED ARE SECTIONS ON - SITE DESCRIPTION, PLANT DESCRIPTION, PROCESS DESCRIPTION, EQUIPMENT DESCRIPTION, SYSTEMS ANALYSIS, PUBLIC PROTECTION, PERSONNEL PROTECTION, SAFETY, PLANT ORGANIZATION, AND STARTUP PLANS.

*APPLICATION FOR AEC LICENSE + *CERIUM + *CESIUM + *FPCE PLANT + *PROMETHIUM + *RADIOCHEMICAL PROCESSING + *SAFEGUARDS REPORT, GENERAL + *STRONTIUM + FISSION PRODUCT, SEPARATION FROM WASTE + FISSION PRODUCT, USE OF IN WASTES + HAZARDS ANALYSIS + ISOICHEM, INC. + RADIOCHEMICAL PLANT SAFETY

12-10718 BROWN CL

CRITICALITY SAFETY OF PUO₂-SS DRIVER FUEL IN THE FFTF

BATTTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON

BNWL-222 +. PAGES 10-11 OF PHYSICS RESEARCH QUARTERLY REPORT - OCTOBER, NOVEMBER, DECEMBER 1965. JANUARY 14, 1966, CFSTI, \$2.00 CY, \$0.50 MN

UPDATES, IN THE LIGHT OF SLIGHT DESIGN CHANGES, THE REACTIVITY SAFETY CALCULATIONS OF THE PLUTONIUM OXIDE-STAINLESS STEEL DRIVER IN THE FFTF.

*FAST NEUTRON + *HANFORD SITE + CRITICALITY SAFETY + REACTIVITY, EXCESS + REACTOR, TEST

12-11396 LEMCOE M

STUDY OF INSTANTANEOUS COLLAPSE AND CREEP BUCKLING CHARACTERISTICS OF LARGE SGR PROCESS TUBES

ATOMICS INTERNATIONAL, CANOGA PARK

NAA-SR-11323 +. 47 PAGES, 4 TABLES, REFERENCES, JULY 25, 1965, CFSTI \$3.00 CY, \$0.50 MN

THE INSTANTANEOUS COLLAPSE (LESS THAN 0.2 HR) AND CREEP-BUCKLING CHARACTERISTICS (UP TO 5000 HR) OF TYPE 304 STAINLESS STEEL TUBES (4.00 IN. IN OD, WITH 0.025-IN. WALL), UNDER EXTERNAL RADIAL PRESSURE AND VARYING AXIAL LOAD, WERE DETERMINED AT TEMPERATURES UP TO 1200 F IN AN ARGON ENVIRONMENT. THE LENGTH OF EACH TUBE WAS 6 FT, WHICH IS ESSENTIALLY INFINITE IN TERMS OF BUCKLING. IN ADDITION, TUBES IN COMBINATION WITH FUEL-ELEMENT BUNDLES CORRESPONDING TO THOSE PROPOSED FOR A LARGE SODIUM GRAPHITE REACTOR (LSGR) WERE ALSO INVESTIGATED TO DETERMINE THE EXTENT TO WHICH THE FUEL-ELEMENT BUNDLE INCREASED THE RESISTANCE TO COLLAPSE OF THE PROCESS TUBE. THE RESULTS OF THE STUDY INDICATED THAT STIFFENER RINGS OR THICKER-WALLED TUBES SHOULD NOT BE NECESSARY UNDER NORMAL OPERATING CONDITIONS.

*PIPING + *STEEL, STAINLESS + BUCKLING + REACTOR, LIQUID METAL COOLED

12-11532 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29

ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND

ACNP-66564 +. 60 PAGES, 7 TABLES, 6 FIGURES, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

ACCESSION NUMBER 12-10262 TO 12-11532

CATEGORY 12
PLANT SAFETY FEATURES

12-11532 *CONTINUED*

ACRS (AUGUST 19, 1966) REQUESTED INFORMATION ON THE RELIABILITY OF CERTAIN SYSTEMS UNDER MCA CONDITIONS, SPECIFICALLY THE RECIRCULATION-SPRAY SYSTEM, THE CORE-SPRAY SYSTEM, AND THE EFFECT OF CONTAINMENT FLOODING. AFTER ANALYSIS, THE FOLLOWING ITEMS ARE PROPOSED - (A) ELIMINATION OF THE RECIRCULATION-SPRAY COOLANT SYSTEM, (B) ADDITION OF A CORE WATER INJECTION SYSTEM, (C) PLANNED FLOODING OF THE REACTOR BUILDING AFTER A RUPTURE BELOW THE CORE, (D) PLANNED STRIPPING OF THE EXTERNAL INSULATION FROM THE BUILDING FOR HEAT DISSIPATION AFTER A STEAM-LINE BREAK, AND (E) MODIFICATION OF PLANT INSTRUMENTATION FOR RELIABILITY UNDER FLOODED CONDITIONS.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
*SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + EMERGENCY COOLING + LACROSSE BOILING WATER REACTOR +
MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

12-11533 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. PAGE 2.1, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

ANSWER V-1 DESCRIBED A RECIRCULATING SPRAY SYSTEM THAT WOULD TAKE WATER FROM THE BUILDING SUMP (PREVIOUSLY CHARGED TO BUILDING), COOL IT, AND RETURN IT TO THE CORE-SPRAY SYSTEM. NOTE - A NEW APPROACH TO THIS PROBLEM MAKES THIS SYSTEM INAPPLICABLE.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CONTAINMENT SPRAY +
COOLANT SYSTEM + CORE SPRAY + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

12-11534 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 8 PAGES, PAGES 3.1-3.8, SEPTEMBER 1966, DOCKET NO. 115-5 PDR

CORE SPRAY SYSTEM - SYSTEM OPERABILITY UNDER ACCIDENT CONDITIONS. A REVIEW OF REACTION FORCES, MECHANICAL DESIGN, AND CORE WATER LEVEL INSTRUMENTATION SHOWED NO UNSOLVABLE PROBLEMS. DESIGN OF THE VESSEL MGDOWN STRUCTURE WILL NOT ALLOW VERTICAL OR RADIAL MOVEMENT FROM PIPE RUPTURE. EIGHTY-THREE PERCENT OF THE CORE-SPRAY NOZZLES WOULD HAVE TO BE BLOCKED TO RAISE THE PRESSURE ABOVE THE WEAKEST-FITTING-TEST PRESSURE. THERMAL SLEEVES AND FLEXIBLE HOSES ARE USED AS BLOWDOWN PROTECTION. PIPE WHIP DOES NOT AFFECT THE SPRAY LINES BECAUSE THEY ARE IN A DIFFERENT PIPE CHASE. PHASE REVERSAL OF THE POSITIVE-DISPLACEMENT PUMPS WILL NOT AFFECT THEIR PERFORMANCE. DURING BLOWDOWN, THE WATER LEVEL WILL READ IMPROPERLY. HOWEVER, AFTER BLOWDOWN, IT WILL RECOVER.

*CORE SPRAY + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM OPERABILITY IN ACCIDENT CONDITIONS +
INSTRUMENTATION, LIQUID LEVEL DETECTION + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

12-11535 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 13 PAGES, PAGES 3.9-3.21, SEPTEMBER 1966, DOCKET NO. 115-5 PDR

CORE SPRAY SYSTEM - COOLING EFFECTIVENESS. JAPANESE AND DRESDEN 3 TESTS WERE USED TO SHOW THAT THE ORIGINAL ASSUMPTION (RADIATIVE-COOLING ONLY) WAS TOO CONSERVATIVE. TO HELP IN THE FORMULATION OF A NEW MODEL, INCLUDING CONVECTIVE AND ADDITIONAL RADIATIVE HEAT TRANSFER EFFECTS, AN EFFECTIVE K WAS ADDED TO THE ORIGINAL MODEL. THE CALCULATED NUMBER OF FUEL RODS (35 PERCENT) EXCEEDING 2500 F WAS REDUCED TO ZERO PERCENT OF THE CLADDING REACHING 2500 F IF THE EFFECTIVE K EXCEEDS 3. TESTS ARE USED TO INDICATE THAT THE LACROSSE K IS GREATER THAN 2.

*CORE SPRAY + *HEAT TRANSFER ANALYSIS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
HEAT TRANSFER EXPERIMENT + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

12-11537 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR.
AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 8 PAGES, PAGES 4.1-4.8, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

CONTAINMENT FLOODING - ENVIRONMENTAL EFFECTS ON ESSENTIAL SYSTEMS AND PLANT MODIFICATIONS.
(A) ELECTRICAL CABLES AND PENETRATIONS ARE MOISTURE PROOF. CONTROL SOLENOIDS ARE DE-ENERGIZED TO GIVE SAFETY ACTION. HOWEVER, HIGH-TEMPERATURE COIL SHORTING COULD HOLD SOLENOIDS OPEN IF THE CURRENT DOES NOT BLOW THE FUSES. CALCULATIONS SHOW THAT THE COIL ITSELF WOULD BURN OUT TO GIVE SAFETY ACTION. MOISTURE-GENERATED SHORTS WOULD BLOW FUSES.
(B) MODIFICATIONS INCLUDE A BUILDING DRAIN PIPE, REVISIONS TO CRITICAL BUILDING PRESSURE, TEMPERATURE, AND WATER-LEVEL INSTRUMENTATION, AND CHANGE OF THE FAILURE MODE OF THE WATER-SUPPLY VALVE TO SHUT DOWN THE CONDENSER.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
*SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + CONTAINMENT INSTRUMENTATION + EMERGENCY COOLING +
LACROSSE BOILING WATER REACTOR + MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

12-11581 HUMBOLDT BAY REQUESTS DELAY TIL SCHEDULE SHUTDOWN FOR YEARLY TESTS
PACIFIC GAS AND ELECTRIC COMPANY
2 PAGES, SEPTEMBER 1966, DOCKET NO. 50-133, PDR

ACCESSION NUMBER 12-11532 TO 12-11581

CATEGORY 12
PLANT SAFETY FEATURES

12-11581 *CONTINUED*

TECHNICAL SPECIFICATIONS REQUIRE CERTAIN TESTS FOR EACH SCHEDULED REFUELING, BUT NOT LESS FREQUENTLY THAN YEARLY. THE 1966 TESTS WOULD BECOME DUE BEFORE THE NOVEMBER 1966 REFUELING, SO A TWX REQUEST WAS MADE TO EXTEND THE TEST REQUIREMENTS TO DECEMBER 31, 1966. (TESTS INCLUDE SCRAM, CONTAINMENT ISOLATION, CORE SPRAY, RELIEF VALVE, AND EMERGENCY CONDENSER SYSTEMS.)

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *TEST, SYSTEM OPERABILITY + CONTAINMENT PENETRATION, CLOSURE OF + CONTROL ROD SCRAM MECHANISM + EMERGENCY COOLING + HUMBOLDT BAY + REACTOR, BOILING WATER

12-11733 BEASLEY EG + LENCE JT
AREAS OF HIGH RADIATION DURING PHASE IVA PHYSICS EXPERIMENTS
TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE
65-66-EAS + TID-22800 +. 4 PAGES, JULY 9, 1965, CFSTI

IN THE EGCR, DURING PHASE IVA THE REACTOR WILL BE OPERATED AT LOW POWER FOR TESTS. DURING THESE TESTS THE PERMANENT BIOLOGICAL SHIELD WILL HAVE SEVERAL OPENINGS, AND A NUMBER OF SHIELD PLUGS WILL BE REMOVED FOR VARIOUS REASONS. THE PURPOSE OF THIS PAPER IS TO ESTABLISH THESE POINTS AND HIGH DOSE RATE AREAS SO THAT A MONITORING PROGRAM CAN BE ESTABLISHED AND TEMPORARY EXCLUSION AREAS DEFINED.

*EGCR (EXPERIMENTAL GAS COOLED REACTOR) + MONITOR, RADIATION, SURFACE + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED + SHIELDING

CATEGORY 13
RADIOCHEMICAL PLANT SAFETY

13-09304 CREUTZ E
GENERAL ATOMIC HIGH AIRBORNE ACTIVITY DUE TO CLOGGED FILTER, JANUARY 17, 1966
GENERAL ATOMIC DIVISION, GENERAL DYNAMICS CORPORATION, SAN DIEGO, CALIFORNIA
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 45, APRIL 11, 1966

INSOLUBLE U-235 WAS BEING PROCESSED IN A HOOD. THE EXHAUST FILTER CLOGGED, AND AN EMPLOYEE WAS EXPOSED TO 1.6 MPC (AIR). AN ADDITIONAL, INDEPENDENT SYSTEM WAS INSTALLED FOR THE ROOM, AND HOODS HAVE TELLTALE INDICATORS TO SHOW ADEQUACY OF THE FLOW.

*PERSONNEL EXPOSURE, RADIATION + FAILURE, ADMINISTRATIVE CONTROL + GLOVE BOX

13-09305 NURMI EO
B AND W RECOVERY FACILITY FIRE, FEBRUARY 22, 1966
BABCOCK AND WILCOX COMPANY, LYNCHBURG, VIRGINIA
3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 43-45, APRIL 11, 1966

LOW-URANIUM-CONTENT ZIRCONIUM-URANIUM ALLOY CHIPS BEING DISSOLVED IGNITED AND BURNED THROUGH THE DISSOLVER. STEAM PROPELLED BURNING CHIPS AGAINST NEARBY GLASS COLUMNS, WHICH OVERHEATED AND BROKE. SPIFFED KEROSENE CAUGHT FIRE. NO CONTAMINATION RESULTED, BUT ONE PERSON WAS BURNED. ALTHOUGH THIS DISSOLVER HAS OPERATED FOR 2 YEARS WITHOUT INCIDENT, AND HAD BEEN CHECKED 2 HR EARLIER, A GAS POCKET MIGHT HAVE FORMED IN THE CHIPS, SO A TRAY-TYPE DISSOLVER IS BEING DESIGNED.

*CHEMICAL REACTION + *FIRE + INCIDENT, ACTUAL, GENERAL + RADIOCHEMICAL PROCESSING

13-09308 RUNION TC
AEC REPLY TO NFS LETTER ON FIRST EXAMINATIONS TO LICENSE CHEMICAL OPERATORS
NUCLEAR FUEL SERVICES, INC., BALTIMORE, MARYLAND
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 34-35, APRIL 11, 1966, DOCKET NO. 50-201

NFS STAFF KEPT INFORMED OF CANDIDATES WHO PASSED, AND DENIAL LETTERS SENT PROMPTLY. FAILURES WERE NOT DUE PRIMARILY TO LACK OF GENERAL TECHNICAL KNOWLEDGE (ONLY 10 PERCENT OF EXAM) BUT DUE TO LACK OF BASIC KNOWLEDGE OF NFS SAFETY MANUAL AND INSTRUMENTATION. MENTAL FATIGUE NOT A LARGE FACTOR, AS MAJORITY OF FAILURES WERE IN FIRST TWO EXAMS GIVEN, WHICH AVERAGED ONLY 4 HOURS EACH. OPERATING TEST GIVEN ON DIFFERENT DAYS. NFS STAFF REVIEWED EXAMS WHILE IN PROGRESS, BUT WERE NOT GIVEN EXAMS IN ADVANCE, AS HAD BEEN REQUESTED

*STAFFING, TRAINING, QUALIFICATION + NUCLEAR FUEL SERVICES (NFS) + RADIOCHEMICAL PROCESSING

13-09368 ZIRCONIUM FINES FLASH FIRE
DIVISION OF OPERATIONAL SAFETY USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 274, 3 PAGES, 2 FIGURES, OCTOBER 7, 1966, DPI

USE OF A CENTERLESS GRINDER THREE WEEKS BEFORE THE INCIDENT PUT ZIRCONIUM FINES IN THE ENCLOSURE. DRY GRINDING OF A STAINLESS-STEEL ROD PROVIDED SPARKS TO START THE FIRE. THE HOUSEKEEPING TEAM THAT MORNING HAD FOUND NO EVIDENCE OF FINES, INDICATING A SUPERFICIAL EXAMINATION. PROTECTIVE GOGGLES PREVENTED SERIOUS EYE INJURY.

*FIRE + *ZIRCONIUM + INCIDENT, ACTUAL, NONREALISM

13-09576 THOMAS JT
EXPERIMENTAL AND CALCULATED SYSTEM CRITICALITY
OAK RIDGE NATIONAL LABORATORY
SM-70/29 +. 37 PAGES, 15 TABLES, 8 FIGURES, 11 REFERENCES, SYMPOSIUM ON CRITICALITY CONTROL OF FISSION MATERIALS, STOCKHOLM, NOVEMBER 1-5, 1965, SOURCE

SPECIFIC DETAILS NECESSARY TO CHARACTERIZE CRITICALITY ARE GIVEN WITH EXPERIMENTAL DATA. THE PRINCIPAL MODE OF ASSEMBLY AND CONTROL IS STATED. THE FISSION MATERIALS USED WERE EITHER METAL OR AQUEOUS SALT SOLUTIONS. HYDROGENOUS MATERIALS WERE USED AS REFLECTORS AND MODERATORS IN THE ARRAYS. A NUMBER OF EXPERIMENTS WITH METAL UNITS WERE PERFORMED WITH THE UNITS IN IRON CONTAINERS. THE METHOD OF ASSEMBLY FOR SOLUTION UNITS WAS TO SPACE THE PROPOSED SYSTEM OF UNITS BY HAND. REACTIVITY CONTROL AND CRITICALITY WERE ACHIEVED BY VARYING THE COMMON SOLUTION HEIGHT IN THESE CENTRAL UNITS. THE SPACING WAS ADJUSTED TO ATTAIN CRITICALITY WHEN THE CONTROL CONTAINERS WERE INDISTINGUISHABLE FROM THE HAND-PLACED UNITS. THE TWO COMPONENT METAL ASSEMBLIES WERE CONTROLLED BY UNIT SEPARATION. THE MULTIPLE-COMPONENT METAL SYSTEMS WERE CONDUCTED ON THE SPLIT-TABLE APPARATUS, AND CONTROL WAS ACHIEVED BY TABLE SEPARATION.

COMPUTER PROGRAM + COMPUTER, DIGITAL + CRITICALITY SAFETY + FUEL HANDLING + MODERATOR + MONTE CARLO + REFLECTOR

13-09791 CARR WH
POLICIES AND PROCEDURES USED IN THE UNITED STATES FOR DECONTAMINATING HOT CELLS
OAK RIDGE NATIONAL LABORATORY
3 PAGES, REFERENCES, NUCLEAR SAFETY, 7(2), PP. 212-214 (WINTER 1965-1966)

BOTH CONTAMINATION AND DECONTAMINATION INCLUDE CHEMICAL AND PHYSICAL MECHANISMS. CHEMICAL METHODS FOR DECONTAMINATION INCLUDE THE USE OF SOLUTIONS, SUCH AS FORMULATIONS BASED ON OXALIC ACID, THAT ARE SUPERIOR TO NITRIC ACID AND SODIUM HYDROXIDE. PHYSICAL METHODS INCLUDE VACUUM CLEANING, STEAM CLEANING, SANDBLASTING, SCRAPING, ULTRASONIC CLEANING, ETC.

ACCESSION NUMBER 13-09304 TO 13-09791

CATEGORY 13
RADIOCHEMICAL PLANT SAFETY

13-09791 *CONTINUED*
*DECONTAMINATION + *HOT CELL

13-09831 BECKERS RM + DENKINS RF + GLEN HM + GOLSON TJ + KAHN JE + RENFRO GW + STEED JA
ENGINEERING DESIGN PRACTICES AT ORNL FOR FACILITIES CONTAINING RADIOACTIVE MATERIALS
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1459 +. 85 PAGES, 43 FIGURES, APRIL 1966, CFSTI, \$3.00 FS, \$0.75 MN

THIS REPORT IS A COMPILATION OF SEVEN PAPERS BY MEMBERS OF THE GENERAL ENGINEERING AND CONSTRUCTION DIVISION OF OAK RIDGE NATIONAL LABORATORY AS PART OF THE APPLIED HEALTH PHYSICS COURSE FOR STATE HEALTH DEPARTMENT PERSONNEL CONDUCTED BY THE OAK RIDGE INSTITUTE OF NUCLEAR STUDIES IN SEPTEMBER AND OCTOBER OF 1965. THE INTENT OF THE PAPERS IS TO CALL ATTENTION TO DESIGN PROBLEMS FOR LABORATORIES AND OTHER FACILITIES HANDLING RADIOACTIVE MATERIALS. THE INFORMATION SHOULD BE HELPFUL IN GUIDING ENGINEERS IN DESIGNING OR SPECIFYING THE SPECIAL TOOLS AND EQUIPMENT REQUIRED FOR HANDLING RADIOACTIVE MATERIALS.

*DESIGN CRITERIA + *GLOVE BOX + *HOT CELL + AIR CLEANING + CONTAINMENT STRUCTURE + CONTAINMENT, GENERAL + DECONTAMINATION + ORNL (OAK RIDGE NATIONAL LABORATORY) + SHIELDING + WASTE HANDLING

13-09968 REPROCESSING TECHNIQUES AND PROGRESS
2 PAGES, EURONUCLEAR 2(12), PAGES 604-605 (DECEMBER, 1965)

THE INCREASINGLY IMPORTANT PROBLEMS ASSOCIATED WITH THE REPROCESSING OF IRRADIATED NUCLEAR FUELS ARE NOW ACHIEVING PRIORITY IN ALL COUNTRIES WHERE NUCLEAR POWER IS BEING, OR IS EXPECTED TO BE, UTILIZED. THE EUROCHEMIC PLANT AT MOL IN BELGIUM IS EXPECTED TO PROVIDE A LARGE PERCENTAGE OF THE REPROCESSING CAPACITY REQUIRED DURING THE NEXT FEW YEARS, BUT SEVERAL OTHER NUCLEAR-DEVELOPED COUNTRIES HAVE THEIR OWN SMALLER PLANTS WHICH MAY ALSO CONTRIBUTE TO THE TOTAL EUROPEAN REQUIREMENT.

*CONTAINMENT, FUEL REPROCESSING + *EUROCHEMIC + *RADIOCHEMICAL PROCESSING + BELGIUM + ITALY + NETHERLANDS + TRANSPORTATION AND HANDLING + UNITED KINGDOM

13-09992 LLOYD RC + RICHEY CR + CLAYTON ED + SKEEN DR
CRITICALITY STUDIES WITH PLUTONIUM SOLUTIONS
BATTELLE MEMORIAL INSTITUTE, RICHLAND, WASHINGTON
8 PAGES, 8 FIGURES, 6 TABLES, NUCLEAR SCIENCE AND ENGINEERING, 25(2), PAGES 165-173 (JUNE, 1966)

CRITICALITY EXPERIMENTS WITH PLUTONIUM (4.6 PERCENT PU-240) NITRATE SOLUTION (AQUEOUS) IN STAINLESS-STEEL SPHERES 11.5, 14, AND 15.2 IN. IN DIAMETER. REFLECTORS - WATER, CONCRETE, PARAFFIN, STAINLESS STEEL. LARGEST SPHERE WAS ALSO USED WITHOUT REFLECTOR. CRITICALITY WAS REACHED WITH PLUTONIUM CONCENTRATIONS THAT VARIED FROM 24 TO 435 G PU PER LITER. MINIMUM CRITICAL VOLUMES WERE ABOUT 22 AND 11 LITERS, RESPECTIVELY, FOR BARE AND REFLECTED SPHERES AT A PU CONCENTRATION OF 175 G/LITER. ACTUAL RESULTS WERE COMPARED WITH THOSE PREDICTED BY MULTIGROUP DIFFUSION THEORY.

*CRITICALITY EXPERIMENT + COMPUTER, DIGITAL + CRITICALITY SAFETY + PLUTONIUM + REFLECTOR + WATER, GENERAL

13-10109 REGULATIONS ON RADIATION SAFETY DURING GAMMA-RAY DEFECTOSCOPY
JPRS-33502 + TT-65-34076 +. 24 PAGES, TRANSLATED FROM DURZHAVEN VESTN, (95), PP. 1-7 (1965), CFSTI, \$1.00 CY, \$0.50 MN

THESE REGULATIONS ARE OBLIGATORY IN THE DESIGNING, OPERATING, AND USE OF LABORATORIES FOR GAMMA DEFECTOSCOPY, REGARDLESS OF THEIR PURPOSE, LOCATION, UTILIZED TYPE OF GAMMA DEFECTOSCOPE, ETC. THEY ARE OBLIGATORY IN THE DESIGNING, PRODUCTION, AND USE OF ALL TYPES OF GAMMA DEFECTOSCOPES IN BULGARIA.

*BULGARIA + *GAMMA + *INSTRUMENTATION, RADIATION MONITORING + *REGULATION, GENERAL

13-10114 BYRNE JT
PLUTONIUM MANAGEMENT AT ROCKY FLATS
DOW CHEMICAL COMPANY, ROCKY FLATS DIVISION
RFP-720 + CONF-660308-1 +. 21 PAGES, FEBRUARY 11, 1966, AMERICAN NUCLEAR SOCIETY, PLUTONIUM INFORMATION MEETING, WASHINGTON, D. C., CFSTI, \$1.00 CY, \$0.50 MN

SOME MAJOR TECHNICAL CONSIDERATIONS IN PLUTONIUM MATERIALS MANAGEMENT ARE DISCUSSED. THIS REPORT IS BASED UPON PRACTICES DEVELOPED AND EVALUATED DURING NEARLY 15 YEARS OF EXPERIENCE IN LARGE-SCALE CHEMICAL, METALLURGICAL, AND FABRICATION OPERATIONS AT THE USAECS ROCKY FLATS PLANT. PARTICULAR EMPHASIS IS PLACED UPON THE PROBLEM OF CONTAINMENT AND ON MEANS OF COPING WITH LOSS-OF-CONTAINMENT SITUATIONS. RECENT WORK ON HANDLING AND MEASURING PLUTONIUM SHIPMENTS IS SUMMARIZED. EFFECTIVE METHODS FOR PLUTONIUM HANDLING AND CONTROL DURING PROCESSING ARE DESCRIBED. CURRENT PROBLEMS IN PLUTONIUM MATERIALS MANAGEMENT ARE IDENTIFIED.

*CONTAINMENT SYSTEM, OPERATION OF + *PLUTONIUM + *RADIOCHEMICAL PROCESSING + *ROCKY FLATS + TRANSPORTATION AND HANDLING

13-10257 FULLAM HT
A CRITICALLY SAFE FLAT BED CONTACTOR FOR PROCESSING SOLID FISSILE MATERIALS
HANFORD ATOMIC PRODUCTS OPERATION

CATEGORY 13
RADIOCHEMICAL PLANT SAFETY

13-10257 *CONTINUED*

RL-SA-52 + CONF-651010-2 +. 12 PAGES, ELECTROCHEMICAL SOCIETY 6TH REGIONAL AICHE MEETING, UNION, WASHINGTON, CFSTI, \$1.00 CY, \$0.50 MN

A FLAT-BED REACTOR WAS DEVELOPED FOR PROCESSING SOLID FISSIONABLE MATERIALS WHICH IS (1) CRITICALLY SAFE BY GEOMETRICAL DESIGN, (2) MECHANICALLY SIMPLE, (3) VERSATILE, (4) CAPABLE OF EFFICIENT HANDLING OF A WIDE RANGE OF PARTICLE SIZES AND GAS FLOWS. THE BODY OF THE CONTACTOR CONSISTS OF A HOLLOW CYLINDRICAL SLAB DIVIDED BY A POROUS PLATE INTO AN UPPER AND LOWER SECTION. THE SOLIDS TO BE REACTED ENTER THE UPPER SECTION OF THE REACTOR AT THE PERIPHERY AND ARE MOVED TO THE CENTER BY A RABBLE ARM. THE POROUS PLATE SERVES AS THE BED SUPPORT FOR THE SOLIDS. THE REACTING GAS IS PREHEATED AS IT ENTERS THE LOWER SECTION OF THE REACTOR, THEN PASSES UP THROUGH THE POROUS PLATE AND THROUGH THE BED OF SLOWLY MOVING SOLIDS. THE GASEOUS PRODUCTS LEAVE THE CONTACTOR THROUGH A VENT LINE IN THE COVER PLATE.

*CRITICALITY SAFETY + *RADIOCHEMICAL PLANT SAFETY + *RADIOCHEMICAL PROCESSING + CHEMICAL REACTION + DESIGN CRITERIA + DESIGN STUDY

13-10600 APPLICATION FOR LICENSES FPCF PLANT
ISOICHEM INC.

750 PAGES APPROX., 83 FIGURES, 71 TABLES, REFERENCES, JUNE 1966, DOCKET NO. 50-258, PDR

REPORT GIVES ALL THE GENERAL AND DETAILED TECHNICAL INFORMATION REQUIRED FOR AEC LICENSING OF A RADIOCHEMICAL PLANT. INCLUDED ARE SECTIONS ON -- SITE DESCRIPTION, PLANT DESCRIPTION, PROCESS DESCRIPTION, EQUIPMENT DESCRIPTION, SYSTEMS ANALYSIS, PUBLIC PROTECTION, PERSONNEL PROTECTION, SAFETY, PLANT ORGANIZATION, AND STARTUP PLANS.

*APPLICATION FOR AEC LICENSE + *CERIUM + *CESIUM + *FPCF PLANT + *PROMETHIUM + *RADIOCHEMICAL PROCESSING + *SAFEGUARDS REPORT, GENERAL + *STRONTIUM + FISSION PRODUCT, SEPARATION FROM WASTE + FISSION PRODUCT, USE OF IN WASTES + HAZARDS ANALYSIS + ISOICHEM, INC. + RADIOCHEMICAL PLANT SAFETY

13-10656 MALAKHOFF V + SIMON W
CRITICALITY OF FUEL REPROCESSING EQUIPMENT
GENERAL ATOMIC

GAMD-6623 +. 20 PAGES, AUGUST 17, 1965, CFSTI, \$1.00 CY, \$0.50 MN

A STUDY OF THE CRITICALITY OF FUEL-PARTICLE STORAGE CONTAINERS AND OF ARRAYS OF SUCH CONTAINERS WAS CARRIED OUT. THE OBJECTIVE WAS TO COMPUTE THE MULTIPLICATION FACTOR AS A FUNCTION OF LENGTH AND DIAMETER FOR CYLINDRICAL CONTAINERS AND TO COMPUTE MASS LIMITS FOR VARIOUS KINDS OF FUEL PARTICLES THAT HAVE BEEN COATED WITH PYROLYTIC CARBON.

*CARBON + *CRITICALITY SAFETY + *PYROLYTIC + *URANIUM + COMPUTER, DIGITAL + THORIUM

13-10825 CLAYTON ED + RICHEY CR + LLOYD RC + BIERMAN SR + CARTER LL
CRITICALITY RESEARCH ON PLUTONIUM
BATTELLE-NORTHWEST, RICHLAND, WASHINGTON

BNWL-SA-214 + CONF-651103-10 +. 26 PAGES, AUGUST 12, 1965, IAEA SYMPOSIUM ON CRITICALITY CONTROL OF FISSIONABLE MATERIALS, STOCKHOLM, CFSTI, \$2.00 CY, \$0.50 MN

RESULTS FROM CRITICALITY EXPERIMENTS WITH PLUTONIUM SOLUTIONS AND COMPOUNDS, PLUS ANALYSES OF DATA THEREFROM. PREVIOUSLY ESTIMATED CURVES FOR CRITICAL DIMENSIONS OF HOMOGENEOUS, WATER-MODERATED PLUTONIUM-239 IN THE UNDERMODERATED RANGE HAVE BEEN REVISED. CURVES ON PU-240. EFFECT OF NITRATE ON CRITICALITY FOR REFLECTED SPHERES. INTERACTION EXPERIMENT WITH DRY PUO2 POWDER IN A LOW-DENSITY REFLECTED CUBIC ARRAY. PLANNED EXPERIMENTS.

*CRITICALITY EXPERIMENT + *CRITICALITY SAFETY + HANFORD SITE + PLUTONIUM

13-11484 PHYSICS RESEARCH QUARTERLY REPORT, JANUARY-MARCH 1966
BATTELLE-NORTHWEST, RICHLAND, WASHINGTON

BNWL-284 +. 26 PAGES, 7 TABLES, 43 REFERENCES, 5 FIGURES, APRIL 15, 1966, CFSTI, \$2.00 CY, \$0.50 MN

OF POSSIBLE SAFETY INTEREST ARE THE FOLLOWING ITEMS - COMPUTER ANALYSIS OF REACTOR NOISE DATA. PARAMETERS ARE OBTAINED FROM THE EXPERIMENTAL DATA BY FITTING THE THEORETICAL FUNCTIONS TO THE DATA USING IMPROVED LEAST-SQUARES-FITTING TECHNIQUES, AND REACTIVITY WORTH OF NEUTRON-ABSORBING RODS IN PLUTONIUM-FUELED WATER-MODERATED SYSTEMS. HF AND B USED AS POISON. RESULTS IN TABULAR FORM. WORTH DEPENDS ON PU-240 AND MODERATOR-OXIDE RATIO.

BORON + COMPUTER, DIGITAL + CONTROL ROD WORTH + CRITICALITY EXPERIMENT + HAFNIUM + NOISE ANALYSIS + PLUTONIUM

13-11704 MANNESCHMIDT JF
RECENT ADVANCES IN MONITORING OF RADIOACTIVE GASEOUS WASTES AT ORNL
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE

CONF-660904 +. 27 PAGES, 17 FIGURES, 6 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON, MASS., SEPTEMBER 13-16, 1966, SOURCE

MANY ACTIVITIES AT THE OAK RIDGE NATIONAL LABORATORY ARE CONCERNED WITH THE CHEMICAL PROCESSING OF RADIOACTIVE MATERIALS. GASEOUS EFFLUENTS FROM THESE OPERATIONS ARE TREATED TO REMOVE DANGEROUS CONTAMINANTS BEFORE RELEASE TO THE ATMOSPHERE. ROUTINE MONITORING OF SUCH EMISSIONS WAS STARTED IN 1966 WHEN MANUALLY OPERATED PARTICULATE MONITORS WERE INSTALLED AT EACH OF THREE PROCESS STACKS. SINCE THAT DATE, COVERAGE HAS BEEN EXTENDED TO SIX STACKS, THE

CATEGORY 13
RADIOCHEMICAL PLANT SAFETY

13-11704 *CONTINUED*

SAMPLE WITHDRAWAL SYSTEM HAS BEEN REBUILT, AND THE DETECTION EQUIPMENT HAS BEEN ADDED TO AND MODERNIZED. THE INTENSIVE MONITORING HAS LEAD TO PROCESS IMPROVEMENTS THAT HAVE REDUCED THE ENVIRONMENTAL RELEASES OF RADIOACTIVITY IN THE GASEOUS WASTE EFFLUENTS BY A FACTOR OF 3 SINCE 1962.

*MONITOR, RADIATION, EMERGENCY + *MONITOR, RADIATION, GAS + *MONITOR, RADIATION, GENERAL PRACTICE +
*MONITOR, RADIATION, SAMPLING + *MONITOR, RADIATION, STACK + MONITOR, RADIATION, AIR +
MONITOR, RADIATION, BACKGROUND + MONITOR, RADIATION, ENVIRONMENTAL + MONITOR, RADIATION, GENERAL

13-11942 LEWIS WH

NFS PLANT SHUTDOWN BECAUSE OF FP CONTAMINATION OF ACID RECOVERY SYSTEM, SEPTEMBER 2, 1966
NUCLEAR FUEL SERVICES, WEST VALLEY, NEW YORK
1 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(39), PAGE 45 (SEPTEMBER 26, 1966) DOCKET NO. 50-201

LOW WATER LEVEL IN EVAPORATOR 7C-2 CAUSED BURPING, AND ENTRAINED FISSION PRODUCTS WERE CARRIED OVER INTO THE ACID-RECOVERY SYSTEM. THE EVAPORATOR WILL BE SHUT-DOWN, THE ACID RECYCLED, AND THE EQUIPMENT FLUSHED.

*OPERATING EXPERIENCE + EVAPORATION + FAILURE, OPERATOR ERROR + NFS (NUCLEAR FUEL SERVICES) +
RADIOCHEMICAL PROCESSING

13-12036 REPORT SPECIAL HEALTH AND SAFETY REVIEW. ARMY MATERIALS RESEARCH AGENCY. NUCLEAR REACTOR FACILITY ADDITIONAL SPENT FUEL STORAGE
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-67-2 +. 22 PAGES, 1 FIGURE, 7 REFERENCES, JULY 1966, DOCKET NO. 50-47, OCE

WATERTOWN ARSENAL REACTOR POWER RAISED FROM 1 TO 2 MW(TH) IN JUNE 1966, AN INTERIM STEP TOWARD 5-MW OPERATION. THE 10-FT-ID CONCRETE TANK WILL BE STEEL-LINED (TO REDUCE WATER LEAKAGE AND MINIMIZE A LOSS-OF-COOLANT ACCIDENT), NECESSITATING TEMPORARY STORAGE OF IRRADIATED FUEL ELSEWHERE. FORTY-NINE ELEMENTS WILL BE STORED AROUND THE PERIPHERY OF AN UNUSED GAMMA-FACILITY TANK, 6 FT IN ID. REPORT ORNL-2609 WAS CITED TO SHOW THAT AN INFINITELY LONG PLANE, ONE ELEMENT HIGH, WOULD BE SUBCRITICAL. ARCHS CONCLUDED THAT FUEL MAY BE SAFELY STORED AS DESCRIBED BUT REQUESTED AN ANALYSIS OF THE DEGREE OF SUBCRITICALITY (IN THE CYLINDRICAL ARRAY).

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + CRITICALITY SAFETY + FUEL STORAGE + REACTOR, ARMY +
REACTOR, POOL TYPE + REACTOR, RESEARCH

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-08809 ELLIOT MN + GROVER JR
THE MEASUREMENT AND CONTROL OF GAS TEMPERATURE IN THE FINGAL PROCESS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HAPWELL
AERE-R-4512 +. 12 PAGES, 4 TABLES, 9 FIGURES, 7 REFERENCES, DECEMBER 1964, UKAEA

DURING DEVELOPMENT OF THE FINGAL PROCESS (FOR INCORPORATING HIGHLY RADIOACTIVE FISSION PRODUCT WASTE INTO GLASS) IT HAS BEEN FOUND IMPORTANT TO MAINTAIN THE TEMPERATURE OF THE GAS WITHIN THE PROCESS BETWEEN CERTAIN LIMITS. THIS REPORT DESCRIBES METHODS FOR MEASURING THESE TEMPERATURE LIMITS AND EXAMINES POSSIBLE METHODS OF CONTROLLING GAS TEMPERATURE IN THE PROCESS.

*THERMAL CONSIDERATION + *WASTE TREATMENT, FIXATION

14-09539 NELSON DJ
THE PREDICTION OF SR-90 UPTAKE IN FISH USING DATA ON SPECIFIC ACTIVITIES AND BIOLOGICAL HALF-LIVES
OAK RIDGE NATIONAL LABORATORY
21 PAGES, 4 TABLES, REFERENCES, INTERNATIONAL SYMPOSIUM ON RADIOECOLOGICAL CONCENTRATION PROCESSES, STOKHOLM, APRIL 29, 1966

WHITE CRAPPIES (POMOXIS ANNULARIS) WERE COLLECTED MONTHLY FROM THE CLINCH RIVER, AND FLESH AND BONE SAMPLES WERE ANALYZED FOR CA AND SR. BONE SAMPLES WERE ANALYZED FOR SR-90. FOUR OTHER SPECIES WERE SAMPLED ON A LIMITED BASIS FOR COMPARISON. THE OBJECTIVE WAS TO DETERMINE WHETHER THE UPTAKE OF SR-90 BY FISH COULD BE PREDICTED ON THE BASIS OF STABLE SR CONCENTRATIONS IN RIVER WATER AND FISH TISSUE. GOOD AGREEMENT WAS OBSERVED BETWEEN THE SPECIFIC ACTIVITY OF SR-90 IN WATER AND WHITE CRAPPIE BONE, INDICATING THAT IT IS POSSIBLE TO PREDICT SR-90 CONCENTRATIONS IN FISH WHEN THE SPECIFIC ACTIVITY OF THE WATER IS KNOWN. THE SPECIFIC ACTIVITY APPROACH WITH SR-90 IS CONSIDERED SUPERIOR TO THE USE OF SR-90-CA RATIOS.

*BIOLOGICAL CONCENTRATION, AQUATIC ORGANISMS + *ECOLOGICAL CONSIDERATION + CALCIUM + CESIUM + RIVER, CLINCH + STRONTIUM

14-09877 FOSTER RF + WILSON RF
EVALUATION OF EXPOSURE FROM MULTIPLE ENVIRONMENTAL SOURCES IN THE ENVIRONS OF THE HANFORD PLANTS
BATTELLE-NORTHWEST
BNWL-SA-53 + CONF-650616-4 +. 21 PAGES, JUNE 8, 1965, HEALTH PHYSICS SOCIETY, ANNUAL MEETING, LOS ANGELES, CFSTI, \$1.00 CY

THOSE WHO LIVE NEAR THE HANFORD ATOMIC ENERGY SITE CAN ACQUIRE RADIOACTIVE MATERIALS BY SEVERAL DIFFERENT PATHWAYS THAT BEGIN WITH THE RELEASE OF REACTOR EFFLUENT TO THE COLUMBIA RIVER, THE RELEASE OF STACK GASES TO THE ATMOSPHERE, AND WORLD-WIDE FALLOUT. IN 1964 THE RADIATION DOSE RECEIVED BY THE VAST MAJORITY OF THE RESIDENTS, FROM ALL SOURCES COMBINED, DID NOT EXCEED TEN PERCENT OF THE APPROPRIATE LIMITS. FOR THE RELATIVELY FEW WHO EAT LARGE NUMBERS OF FISH CAUGHT FROM THE COLUMBIA RIVER IMMEDIATELY BELOW THE HANFORD RESERVATION, P-32 IS AN IMPORTANT SOURCE OF EXPOSURE. IN 1964 THE HYPOTHETICAL INDIVIDUAL WHO HAD THE MAXIMUM CREDIBLE INTAKE OF P-32 AND OTHER NUCLIDES OF HANFORD ORIGIN COULD HAVE TAKEN IN ABOUT 25 PERCENT OF THE PERMISSIBLE ANNUAL INTAKE OF BONE SEEKERS.

*DOSE + *POPULATION EXPOSURE + *RIVER, COLUMBIA + CODES AND STANDARDS

14-10915 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 15 DISCUSSES THE UPRIVER TRANSPORT 22 MILES TO NEW YORK CITY WATER INTAKE AT CHELSEA, DUE TO TIDAL BACKFLOW AND TO THE SALT-WATER GRADIENT. SEVERAL TIDAL CYCLES ARE NECESSARY TO MOVE THE WATER UPRIVER, AND ACCORDING TO MEASURED DISPERSION COEFFICIENTS, WITH MINIMUM DOWNFLOW, A CONTINUOUS RELEASE OF 550 CURIES/DAY OF CS-137 OR 87 CURIES/DAY OF I-131 WOULD GIVE MPC AT THE INTAKE. INDIAN POINT I EXPERIENCE IS THAT ALL DISCHARGES ARE BELOW DRINKING-WATER MPC. AN INSTANTANEOUS RELEASE OF 5750 CURIES OF I-131 WOULD NEED BE RELEASED FOR THE PEAK CONCENTRATION AT CHELSEA TO REACH DRINKING-WATER MPC.

*HYDRAULIC ANALYSIS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE DISPOSAL, RIVER + DIFFUSION COEFFICIENT + INDIAN POINT II + REACTOR, PRESSURIZED WATER

14-10924 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19F - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- WASTE-GAS DECAY TANKS VOLUME IS PROVIDED TO STORE GASES EVOLVED DURING A SHUTDOWN. STORAGE FOR 45 DAYS. MAXIMUM QUANTITY EXPECTED IN ANY ONE TANK IS 13,500 CURIES OF XE-133, WHICH IF RELEASED WOULD GIVE 0.5 REM EXPOSURE AT SITE BOUNDARY DURING CLOUD PASSAGE.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE STORAGE + DOSE CALCULATION, EXTERNAL + FISSION GAS RELEASE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

14-10925 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK

ACCESSION NUMBER 14-08809 TO 14-10925

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-10925 *CONTINUED*

1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19C - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- THREE
LIQUID-WASTE TANKS ARE PROVIDED, EACH WILL HOLD 2/3 OF THE PRIMARY COOLANT. TANK PIT WILL
HOLD CONTENTS OF ONE TANK WITHOUT SPILLOVER. NORMAL DISCHARGE WILL BE THROUGH THE LIQUID
PROCESSING TRAIN.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE STORAGE + INDIAN POINT II +
REACTOR, PRESSURIZED WATER + WASTE TREATMENT, LIQUID

14-11086 DRL REFUSES INCREASED STACK RELEASE RATES AS OBSERVED DOSES EXCEED PREDICTED DOSES
PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
10 PAGES, DOCKET NO. 50-133, AUGUST 19, 1966, PDR

HUMBOLDT BAY REQUESTED AN INCREASE IN ALLOWABLE RELEASE RATES BECAUSE, FOR THREE MONTHS IN
1965, POWER WAS LIMITED BY STACK RELEASE RATE DUE TO DAMAGED FUEL. DRL REFUSED THE INCREASE,
NOTING BETTER FUEL THAT WILL BE PROCURED, THAT EVEN UNDER GOOD METEOROLOGICAL CONDITIONS A
POPULATED AREA WAS IN A FUMIGATION CONDITION, THAT SMOKE TESTS DO NOT SUPPORT METEOROLOGICAL
CONDITIONS, AND THAT SOME SITE-MONITORING STATIONS SHOW DOUBLE THE YEARLY DOSE PREDICTED.
DRL BELIEVES THAT REDUCED POWER OPERATION OR JUDICIOUS FUEL REPLACEMENT IS PREFERABLE TO
INCREASING STACK-RELEASE LIMITS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *RELEASE RATE + FAILURE, FUEL ELEMENT + HUMBOLDT BAY +
LAPSE RATE, STABLE + REACTOR, BOILING WATER

14-11135 ARTHUR CE + ARMSTRONG FE
A STUDY OF RADIOACTIVE CONTAMINATION RESULTING FROM THE USE OF NUCLEAR EXPLOSIVES FOR STIMULATING
PETROLEUM PRODUCTION
BUREAU OF MINES, WASHINGTON, D. C.
BM-RI-6684 +. 13 PAGES, MARCH 1965, CFSTI, \$1.00 CY, \$0.50 MN

THE BUREAU OF MINES INVESTIGATED THE PROBLEM OF RADIOACTIVE CONTAMINATION THROUGH THE USE OF
NUCLEAR EXPLOSIVES TO FRACTURE PETROLEUM RESERVOIRS IN AN ATTEMPT TO STIMULATE PRODUCTION.
IT WAS CONCLUDED THAT SOME CONTAMINATION OF PETROLEUM PRODUCTS WILL ALMOST CERTAINLY OCCUR.
HOWEVER, THE DEGREE OF CONTAMINATION CANNOT BE PREDICTED EXCEPT BY A FULL-SCALE EXPERIMENT,
SINCE SIMULATING THE PROBLEM IN THE LABORATORY IS ECONOMICALLY IMPOSSIBLE BECAUSE OF THE
EXTREMELY HIGH TEMPERATURES AND PRESSURES THAT MUST BE REACHED IN EXTREMELY SHORT TIMES IF A
REASONABLY ANALOGOUS MODEL IS TO RESULT.

*CONTAMINATION + *PLOWSHARE PROGRAM + GEOLOGICAL CONSIDERATION, GENERAL + NUCLEAR DETONATION

14-11268 HARDE R + STOHR KW
THE COMPACT SODIUM-COOLED NUCLEAR REACTOR KARLSRUHE KNK - PART II
KARLSRUHE NUCLEAR RESEARCH CENTER
6 PAGES, 12 FIGURES, 13 REFERENCES, ATOMWIRTSCHAFT 11(8/9) 448-453, AUGUST, SEPTEMBER 1966, IN GERMAN

REGARDING THE ZIRCONIUM-HYDRIDE-MODERATED, SODIUM-COOLED KNK REACTOR, POSITIVE POWER
COEFFICIENT AT LOW POWER AND HIGH BURNUP ARE EXPLAINED, PLUS REQUIREMENTS FOR THE CONTROL
SYSTEM. ACTIVATION OF PRIMARY SODIUM. COMPLETE SHEAR OF MASS PIPING OF PRIMARY SYSTEM
REGARDED AS INCREDIBLE. BUDGET FOR EXPERIMENTS, INCLUDING SAFETY RESEARCH. REACTOR PHYSICS
INCLUDING CONTROL-ROD WORTH AND DANGER COEFFICIENTS. EXPERIMENTS ON SMALL AND LARGE LEAKS IN
THE SODIUM SYSTEM AND IN THE STEAM GENERATOR.

*GERMANY + *SODIUM + ACCIDENT, MAXIMUM CREDIBLE (MCA) + ACTIVATION + CONTROL ROD WORTH + CONTROL SYSTEM +
COOLANT SYSTEM + DANGER COEFFICIENT + FIRE + POWER COEFFICIENT + PRESSURE, INTERNAL + SAFETY STUDY

14-11305 BARRY PJ
THE USE OF RADIOACTIVE TRACER GASES TO STUDY THE RATE OF EXCHANGE OF WATER VAPOR BETWEEN AIR AND NATURAL
SURFACES
ATOMIC ENERGY OF CANADA LTD., CHALK RIVER, ONTARIO
AECL-2576 + CONF-651108-7 +. 8 PAGES, 3 FIGURES, 3 TABLES, JUNE 1966, SYMPOSIUM ON ISOTOPE TECHNIQUES IN
THE HYDROLOGIC CYCLE, NOVEMBER 10-12, 1965, ILLINOIS, AECL \$0.50

RADIOACTIVE TRACERS WERE USED TO MEASURE THE FLUX OF MATTER AT THE SURFACE OF SNOW. BY THE
USE OF TWO TRACERS HAVING MARKEDLY DIFFERENT MOLECULAR DIFFUSIVITIES IT IS POSSIBLE TO STUDY
TURBULENT AND MOLECULAR TRANSPORTS SEPARATELY. THE RESULTS ARE COMPARED WITH EXISTING
EVAPORATION EQUATIONS FOR SURFACE-TO-AIR CONCENTRATION GRADIENTS, AND NONE OF THOSE EQUATIONS
PREDICTED RATES OF EVAPORATION SATISFACTORILY.

*MASS TRANSFER + *TRACER, RADIOACTIVE + DIFFUSION + SURFACE CONTAMINATION

14-11319 ENVIRONMENTAL RADIATION
UNIVERSITY OF CALIFORNIA, LOS ANGELES
UCLA-12-576 +. 111 PAGES, 4 TABLES, PP 91-111 OF SEMIANNUAL PROGRESS REPORT FOR THE PERIOD ENDING
DECEMBER 31, 1965, CFSTI \$4.00 CY, \$0.75 MN

SHORT PROGRESS SUMMARIES ARE GIVEN FOR VARIOUS PROJECTS IN THE UCLA PROGRAM IN ENVIRONMENTAL
RADIATION. SUBJECTS INCLUDE ECOLOGICAL CONSIDERATIONS, BEHAVIOR OF RADIONUCLIDES IN THE

ACCESSION NUMBER 14-10925 TO 14-11319

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11319 *CONTINUED*
SOIL, AND THE DETERMINATION OF RADIONUCLIDES IN ENVIRONMENTAL SAMPLES.

*ECOLOGICAL CONSIDERATION + *SOIL, NUCLIDE OCCURRENCE + ACTIVATION PRODUCT + ANALYTICAL TECHNIQUE, SOLID + BERYLLIUM + BIOLOGICAL CONCENTRATION, GENERAL + CESIUM + RADIATION EFFECT + RADIOCHEMICAL ANALYSIS + SOIL, RADIONUCLIDE MOVEMENT THROUGH + SPECTROMETRY, GAMMA

14-11341 SZEPEKE R + GRZYBOWSKA D
STRONTIUM-90 IN TAP WATER AND IN SOME RIVERS IN POLAND IN 1962 YEAR
CENTRAL LABORATORY FOR RADIOLOGICAL PROTECTION, WARSAW
AEC-TR-6487 +. 4 PAGES, 2 TABLES, 8 REFERENCES, NUKLEONIKA 10(1), PAGES 47-50, (1965), CFSTI \$3.00 CY, \$0.75 MN

IN 1962 THE STRONTIUM-90 CONTENT IN TAP-WATER IN WARSAW WAS ESTIMATED AT 0.69 PLUS OR MINUS 0.08 PC/LITER. IN THE FALL OF 1962 THE CONCENTRATION OF STRONTIUM-90 IN SOME RIVERS WAS 0.88 PLUS OR MINUS 0.15 PC/LITER. THE DATA OBTAINED ARE TABULATED.

*POLAND + *STRONTIUM + *SURFACE WATER, NUCLIDE OCCURRENCE + *WATER, DRINKING

14-11343 BOROWCZYK M + GRABEZAK J + ZUBER A
RADIOISOTOPES MEASUREMENTS OF THE GROUND-WATER FLOW DIRECTION BY THE SINGLE-WELL METHOD
GEOLOGICAL INSTITUTE, WARSAW + INSTITUTE OF NUCLEAR RESEARCH, WARSAW-SWIERK POLAND
AEC-TR-6468 +. 15 PAGES, 13 FIGURES, 2 TABLES, 11 REFERENCES, NUKLEONIKA 10(1), PAGES 17-31, (1965), CFSTI \$3.00 CY

THE PAPER CONTAINS A DISCUSSION OF FUNDAMENTAL PROBLEMS CONCERNING THE DETERMINATION OF THE DIRECTION OF GROUND-WATER FLOW BY MEANS OF A SINGLE-WELL METHOD, I.E., THE CHOICE OF THE RADIOISOTOPE, THE INJECTION PROCEDURE, AND THE PROCEDURE FOR PLACING THE PROBE IN THE BORE-HOLE. A GRAPH FOR THE DETERMINATION OF THE MINIMUM PERIOD BETWEEN THE INJECTION AND THE START OF MEASUREMENT IS ALSO GIVEN. THE RESULTS OF EXPERIMENTS ON A MODEL AND IN FIELD CONDITIONS ARE PRESENTED. THE RESULTS OF FIELD MEASUREMENTS ARE IN GOOD AGREEMENT WITH THOSE OBTAINED BY OTHER METHODS. IT SEEMS THAT THE FLOW-DIRECTION MEASUREMENTS BY MEANS OF THE SINGLE-WELL METHOD FOR ANY AQUIFERS WILL BE MORE CONVENIENT THAN THOSE OBTAINED BY OTHER METHODS. WE CAN ALSO EXPECT THAT FOR A COMPLICATED SYSTEM OF AQUIFERS, MORE INFORMATION CAN BE OBTAINED IN THIS WAY THAN HAS BEEN POSSIBLE UP TO NOW.

*GROUND WATER, TRACER + *TRACER, RADIOACTIVE + BROMINE + CADMIUM + CERIUM + CHROMIUM + DISPERSION + GOLD + GROUND WATER, PROPERTY + HAFNIUM + HYDROLOGICAL CONSIDERATION, RATE OF MOVEMENT + INDIUM + IODINE + IRIIDIUM + MERCURY + MOLYBDENUM + NIOBIUM + RUTHENIUM + SCANDIUM + SELENIUM + SILVER + SODIUM + TECHNETIUM + ZINC + ZIRCONIUM

14-11344 HERCZYNSKA E + PROSZYNSKA K
ADSORPTION OF TRACE AMOUNTS OF RADIOACTIVE ANIONS AND CATIONS ON AL SURFACES
INSTITUTE OF NUCLEAR RESEARCH, WARSAW
AEC-TR-6488 +. 12 PAGES, 4 FIGURES, 26 REFERENCES, NUKLEONIKA 10(1), PAGES 23-33, (1965), CFSTI \$3.00 CY, \$0.75 MN

THE ADSORPTION OF TRACE AMOUNTS OF RADIOACTIVE CATIONS AND ANIONS ON ALUMINUM POWDERS WAS MEASURED. THE RESULTS ARE QUALITATIVELY INTERPRETED ON THE BASIS OF THE ELECTRIC-DOUBLE-LAYER THEORY, CONSIDERING HYDROGEN AND HYDROXYL IONS TO DETERMINE THE POTENTIAL. THE RESULTS ARE CONSISTENT WITH THE THEORY BUT ARE LIMITED IN SCOPE.

ADSORPTION + CALCIUM + CESIUM + HYDROGEN + IODINE + ION EXCHANGE + MINERAL EXCHANGE + PHOSPHORUS + SULFUR

14-11345 RADWAN M + GOLINCZAK H + STASIUR J + KRZYSIAK B
INDIRECT METHOD FOR DETERMINING FALL-OUT CONTAMINATION OF A REGION
MILITARY TECHNICAL ACADEMY, WARSAW
AEC-TR-6488 +. 7 PAGES, 1 FIGURE, 2 TABLES, 4 REFERENCES, NUKLEONIKA 10(1), PAGES 49-55, (1965), CFSTI \$3.00 CY, \$0.75 MN

AN ATTEMPT IS MADE TO ESTABLISH THE DEGREE OF RADIOCONTAMINATION OF AN AREA BY FALLOUT BY DETERMINING THE STRONTIUM-90 CONTENT OF DEER ANTLERS. THE DATA SHOW AN INCREASE IN STRONTIUM-90 ACTIVITY IN TIME, WHICH AGREES WITH THE PREDICTED 13 YEAR SPAN OF INCREASING FALLOUT FROM NUCLEAR DETONATIONS.

*BIOLOGICAL CONCENTRATION, ANIMAL + ANALYTICAL TECHNIQUE, SOLID + FALLOUT + STRONTIUM

14-11347 LOCKHART LB + PATTERSON RL
THE EXTENT OF RADIOACTIVE EQUILIBRIUM BETWEEN RADON AND ITS SHORT LIVED DAUGHTER PRODUCTS IN THE ATMOSPHERE
U.S. NAVAL RESEARCH LABORATORY
NRL-REPORT-6374 +. 18 PAGES, 12 FIGURES, 5 TABLES, 3 REFERENCES, APRIL 5, 1966, CFSTI \$1.00 CY, \$0.50 MN

A SET OF EXPERIMENTAL CONDITIONS WERE DERIVED TO OPTIMIZE THE ACCURACY WITH WHICH THE RADON CONTENT OF THE ATMOSPHERE AND ITS APPARENT RESIDENCE TIME THERE CAN BE DETERMINED FROM MEASUREMENT OF THE FILTERABLE GROSS BETA ACTIVITY DURING TWO SEPARATE 10-MIN PERIODS FOLLOWING THE END OF A 20-MIN COLLECTION PERIOD. THE RATIO OF MEASURED COUNTS DURING THE 61-THROUGH-71-MIN DECAY PERIOD TO THAT DURING THE 1-THROUGH-11-MIN PERIOD IS EMPLOYED TO OBTAIN THE ATOMIC RATIO OF RAC TO RAB IN THE AIR SAMPLED, THE APPARENT AGE OF THE CONGLOMERATE OF RADON AND ITS DAUGHTERS, AND THE TOTAL COUNTS TO BE EXPECTED FROM ANY GIVEN RADON CONCENTRATION IN THE AIR. EXTENSIVE EXAMPLES OF ATMOSPHERIC MEASUREMENTS ARE GIVEN AND

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11347 *CONTINUED*

SUGGEST THAT UNDER MOST CONDITIONS IN THE FREE ATMOSPHERE RADON IS ESSENTIALLY AT SECULAR EQUILIBRIUM WITH ITS DAUGHTER PRODUCTS.

*RADON + AIR + GROSS BETA + RADIOCHEMICAL ANALYSIS + SAMPLING

14-11353 MARTIN WE + TURNER FB

TRANSFER OF SR-89 FROM PLANTS TO RABBITS IN A FALLOUT FIELD .
UNIVERSITY OF CALIFORNIA, LABORATORY OF NUCLEAR MEDICINE AND RADIATION BIOLOGY, LOS ANGELES, CALIFORNIA
11 PAGES, 2 FIGURES, 3 TABLES, 27 REFERENCES, HEALTH PHYSICS 12(5), PAGES 621-631, MAY 1966

THE OBJECTIVE OF THIS STUDY, WHICH WAS CONDUCTED IN THE FALLOUT FIELD PRODUCED ON 6 JULY 1962 BY PROJECT SEDAN, A NUCLEAR CRATERING EXPERIMENT AT THE NEVADA TEST SITE, WAS TO FORMULATE A MATHEMATICAL MODEL TO REPRESENT THE RELATIONSHIP BETWEEN GAMMA DOSE RATES AND INITIAL SR-89 CONCENTRATIONS ON FALLOUT-CONTAMINATED PLANTS AND THE TIME-SPECIFIC RELATIONSHIP BETWEEN CONCENTRATIONS ON PLANTS AND IN THE BONE ASH OF RABBITS COLLECTED AT THE SAME TIMES AND LOCATIONS IN THE FALLOUT FIELD. AN EXPONENTIAL MODEL WAS TESTED AND FOUND TO PROVIDE A REASONABLE REPRESENTATION OF THE TIME-SPECIFIC RELATIONSHIP BETWEEN SR-89 CONCENTRATIONS ON FALLOUT-CONTAMINATED PLANTS AND IN RABBIT BONE ASH. USE OF THE SAME MODEL TO ESTIMATE THE INFINITY DOSES DELIVERED BY SR-89 TO RABBIT BONE INDICATED A RANGE FROM ABOUT 0.1 TO 9.5 RADS AND AN AVERAGE OF 1.12 PLUS OR MINUS 0.36 RAD IN AREAS 12-110 MILES FROM GROUND ZERO. ESTIMATES OF INTEGRATED DOSES INDICATED THAT 93 PERCENT OF THE INFINITY DOSE WAS DELIVERED DURING THE FIRST 120 DAYS AFTER THE DETONATION.

*BIOLOGICAL CONCENTRATION, ANIMAL + *DOSE CALCULATION, INTERNAL + *DOSE MEASUREMENT, EXTERNAL + *PLOWSHARE PROGRAM + BIOLOGICAL CONCENTRATION, VEGETATION + DOSE + DOSE CALCULATION, EXTERNAL + FALLOUT + STRONTIUM

14-11354 NISHITA H + HAUG RM + STEEN AJ

SOLUBILITY AND PLANT AVAILABILITY OF RADIONUCLIDES IN REACTOR ACTIVATED SOILS
UNIVERSITY OF CALIFORNIA, LABORATORY OF NUCLEAR MEDICINE AND RADIATION BIOLOGY, LOS ANGELES, CALIFORNIA
6 PAGES, 3 TABLES, 1 FIGURE, 2 REFERENCES, HEALTH PHYSICS 12(5), PAGES 615-620, MAY 1966

THE SOLUBILITIES OF RADIONUCLIDES FORMED IN REACTOR-ACTIVATED SOILS WERE DETERMINED BY EQUILIBRIUM BATCH AND LEACHING METHODS, AND THE ECOLOGICAL IMPLICATIONS WERE DETERMINED BY A MODIFIED NEUBAUER TECHNIQUE. THE GAMMA ACTIVITY OF THE EQUILIBRIUM EXTRACTS OF ACTIVATED SOILS VARIED FROM 0.17 TO 20.22, 0.36 TO 25.09 AND 0.20 TO 28.76 PERCENT OF TOTAL ACTIVITY IN DEIONIZED H₂O, 0.1 N HCl AND 1 N NH₄AC, RESPECTIVELY, ABOUT 22 HR AFTER IRRADIATION. IN EVERY INSTANCE, THE PERCENTAGE OF LEACHABLE BETA ACTIVITY WAS GREATER THAN THAT OF THE LEACHABLE GAMMA ACTIVITY OF THE CORRESPONDING SOIL. THE DOMINANT GAMMA EMITTER IN THE PLANTS WAS RB-86, ALTHOUGH SC-46 WAS THE DOMINANT RADIO-NUCLIDE IN THE SOIL AT THE TIME OF HARVEST.

*ACTIVATION PRODUCT + *DESORPTION + *SOIL, NUCLIDE OCCURRENCE + ECOLOGICAL CONSIDERATION + GROSS BETA + GROSS GAMMA + MINERAL EXCHANGE + RUBIDIUM + SCANDIUM

14-11355 SHLEIEN B + GAETA NA + FRIEND AG

DETERMINATION OF PARTICLE SIZE CHARACTERISTICS OF OLD AND FRESH AIRBORNE FALLOUT BY GRADED FILTRATION
DIVISION OF RADIOLOGICAL HEALTH, PUBLIC HEALTH SERVICE, WINCHESTER, MASSACHUSETTS
7 PAGES, 3 TABLES, 2 FIGURES, 12 REFERENCES, HEALTH PHYSICS 12(5), PAGES 633-639, MAY 1966

BY USE OF A COLLECTION SYSTEM CONSISTING OF THREE GRADED FILTERS PLACED IN SERIES, A STUDY WAS CONDUCTED DURING THE PAST YEAR ON THE PARTICLE-SIZE CHARACTERISTICS OF AIR-BORNE FALLOUT. EITHER GAMMA SPECTROMETRY OR RADIOCHEMISTRY WAS USED FOR QUANTITATIVE ESTIMATIONS OF FISSION PRODUCTS. DURING THE LATTER PART OF OCTOBER AND THROUGHOUT NOVEMBER 1964, A SECOND SERIES OF COLLECTIONS WAS MADE AND INCLUDED FRESH FISSION-PRODUCT MATERIAL PRESUMABLY RESULTING FROM THE ATMOSPHERIC NUCLEAR DETONATION IN MAINLAND CHINA. DIFFERENCES IN THE PARTICLE-SIZE DISTRIBUTION OF MATERIAL ON EACH FILTER WERE DETERMINED BY OPTICAL MICROSCOPY. FOR OLDER DEBRIS, AT LEAST 88 PERCENT OF THE TOTAL ACTIVITY WAS ASSOCIATED WITH PARTICLES HAVING DIAMETERS OF LESS THAN APPROXIMATELY 1.75 MICRONS. IN FRESH FALLOUT, CERTAIN RADIONUCLIDES WERE INITIALLY ASSOCIATED WITH LARGER PARTICLES. WITH TIME, THIS DISTRIBUTION GRADUALLY DECREASED DUE TO SETTLING OUT OF LARGER ACTIVE PARTICLES. DATA ARE PRESENTED ON THE DEGREE OF RADIONUCLIDE FRACTIONATION IN EACH SIZE GROUP.

*FALLOUT + *PARTICLE SIZE DISTRIBUTION + PARTICLE, RADIOACTIVE + RADIOCHEMICAL ANALYSIS

14-11356 BOEGLY WJ + BRADSHAW RL + EMPSON FM + SCHAFER WF + PARKER FL + BLOMEKE JO

PROJECT SALT VAULT - A DEMONSTRATION DISPOSAL OF HIGH-LEVEL RADIOACTIVE SOLIDS IN LYONS, KANSAS, SALT MINE
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
8 PAGES, 5 FIGURES, 8 REFERENCES, HEALTH PHYSICS 12(3), PAGES 417-424, (MARCH 1966)

THE DEMONSTRATION OF THE DISPOSAL OF HIGHLY RADIOACTIVE SOLID WASTE HAS AS ITS OBJECTIVES THE DEMONSTRATION OF REQUIRED WASTE-HANDLING EQUIPMENT AND TECHNIQUES, THE DETERMINATION OF THE STABILITY OF SALT UNDER THE INFLUENCE OF HEAT AND RADIATION, AND THE COLLECTION OF INFORMATION ON CREEP AND PLASTIC FLOW OF SALT NEEDED FOR THE DESIGN OF AN ACTUAL DISPOSAL FACILITY. FOURTEEN IRRADIATED FUEL ASSEMBLIES FROM THE ENGINEERING TEST REACTOR WILL SERVE AS A SOURCE OF RADIATION. DURING THE COURSE OF THE 2-YEAR TEST, FOUR SETS OF ASSEMBLIES WILL BE USED TO ACHIEVE A PEAK DOSE IN THE SALT OF ABOUT 8 TIMES 10 TO THE 8TH RADS, AND THE TEMPERATURE OF THE SALT ADJACENT TO THE CENTER HOLE WILL BE MAINTAINED AT 200 C WITH SUPPLEMENTARY ELECTRICAL HEATERS. A SECOND RADIOACTIVE ARRAY, LOCATED IN THE EXISTING MINE FLOOR, WILL RECEIVE THE FUEL CANISTERS WHICH ARE REMOVED FROM THE MAIN ARRAY AT THE END OF EACH 6-MONTH PERIOD. A THIRD ARRAY, CONSISTING ONLY OF HEATERS, WILL BE OPERATED AS A CONTROL TO DETERMINE THOSE EFFECTS DUE SOLELY TO HEAT. IN ADDITION TO THE RADIOACTIVE AND

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11356 *CONTINUED*

CONTROL ARRAYS, A RIB-PILLAR LOCATED BETWEEN THE MAIN RADIOACTIVE ARRAY AND THE CONTROL ARRAY WILL BE LOCATED ELECTRICALLY AROUND ITS BASE TO PRODUCE SIGNIFICANT INFORMATION ON SALT FLOW CHARACTERISTICS AND MINE STABILITY AT ELEVATED TEMPERATURES.

*HEAT CONDUCTION + *WASTE DISPOSAL, SALT + DESIGN CRITERIA + DESIGN STUDY + DOSE + RADIATION EFFECT + TEMPERATURE GRADIENT + THERMAL CONSIDERATION

14-11357 SCHONFELD E + DAVIS W

SOFTENING AND DECONTAMINATING WASTE WATER BY CAUSTIC-CARBONATE PRECIPITANTS IN A SLOWLY-STIRRED SLUDGE-BLANKET COLUMN

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

10 PAGES, 5 TABLES, 3 FIGURES, 19 REFERENCES, HEALTH PHYSICS 12(3), PAGES 407-415, MARCH 1966

TO REDUCE THE CONCENTRATION OF CALCIUM IN LOW-RADIOACTIVITY-LEVEL PROCESS WASTE WATER AND THEREBY MAKE THE WATER MORE SUITABLE AS A FEED TO A COUNTERCURRENT FOAM COLUMN IN WHICH STRONTIUM AND OTHER RADIOACTIVE NUCLIDES CAN BE REMOVED, A MODIFIED LIME-SODA PRECIPITATION PROCESS WAS DEVELOPED. THE PROCESS CONSISTS IN ADDING SODIUM CARBONATE AND SODIUM HYDROXIDE TO THE WATER TO A CONCENTRATION OF 0.005 M EACH (CALCULATED BEFORE CHEMICAL REACTION) AND USING A SLOWLY STIRRED, SUSPENDED-BED SLUDGE COLUMN TO REMOVE (BY A FILTERING ACTION) THE RESULTING CALCIUM CARBONATE AND MAGNESIUM HYDROXIDE. WITH THIS PROCEDURE, AND WITH FERRIC IRON (A FEW PPM) AS A COAGULANT, THE RESIDUAL HARDNESS OF THE WATER WAS REDUCED AT 5 PPM (AS CaCO₃) OR LESS. WITH ORNL LOW-RADIOACTIVITY-LEVEL PROCESS WASTE WATER AS FEED, THE DECONTAMINATION FACTORS ACROSS THE SLUDGE COLUMN WERE AS FOLLOWS - 10 TO 15 FOR SR-90, 30 TO 40 FOR CE-144 ETC. THE CALCIUM CONCENTRATION CAN BE REDUCED TO A POINT SUCH THAT IT WILL NOT SIGNIFICANTLY INTERFERE WITH SUBSEQUENT REMOVAL OF STRONTIUM IN A FOAM SEPARATION COLUMN. THE DEGREES OF SOFTENING AND DECONTAMINATION ARE SIGNIFICANTLY BETTER THAN CAN BE ACHIEVED IN THE ORNL LIME-SODA PLANT. THE PROCESS IS BEING EVALUATED ON A 15,000 GAL/DAY BASIS.

*WASTE TREATMENT, LIQUID + *WATER TREATMENT + CALCIUM + CERIUM + CESIUM + COBALT + EFFLUENT + RUTHENIUM + STRONTIUM

14-11479 BRYANT PM

COMPUTED DEPOSITION RATES PER UNIT RELEASE RATE OF WINDBORNE MATERIAL

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL, ENGLAND

AHSB(RP)M-40 +. 34 PAGES, 13 TABLES, 3 REFERENCES, SEPTEMBER 1965, DEP.

THIS MEMORANDUM BRIEFLY DESCRIBES METHODS FOR CALCULATING DRY DEPOSITION RATES, WASHOUT BY RAIN, AND COMBINED (WET AND DRY) DEPOSITION RATES, ALL WITH RESPECT TO UNIT RATE OF RELEASE TO ATMOSPHERE. COMPUTED VALUES OF THESE RATES CORRESPONDING TO SEVERAL ALTERNATIVE VALUES OF DEPOSITION VELOCITY AND OF THE WASHOUT COEFFICIENT OVER A RANGE OF STACK HEIGHTS AND DISTANCES ARE GIVEN IN TABULAR FORM FOR USE AS READY-RECKONERS. THE COMPUTER PROGRAM, GIVEN IN THE APPENDIX, INCLUDES CALCULATION OF DERIVED WORKING LIMITS FOR CONTINUOUS RELEASE RATES OF SR-90 AND CS-137 TO THE ATMOSPHERE IN A MILK-PRODUCING AREA IN GREAT BRITAIN, AND THESE VALUES ARE INCLUDED.

*COMPUTER PROGRAM + *DEPOSITION + *FALLOUT + *RAINOUT + CESIUM + FISSION PRODUCT, AIRBORNE + STRONTIUM

14-11522 BLANCO RE + ALKIRE GJ + DAVIS W + GODBEE HW + IRISH ER + KING LJ + MERCER BW + ROBERTS JT + YEE WC

RECENT DEVELOPMENTS IN TREATING LOW AND INTERMEDIATE LEVEL RADIOACTIVE WASTE IN THE UNITED STATES

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

ORNL-TM-1289 + CONF-651202-11 +. 51 PAGES, 17 FIGURES, 13 TABLES, 28 REFERENCES, DECEMBER 1965, CFS11 \$3.00

RECENT RESEARCH AND DEVELOPMENT WORK IN THE TREATMENT OF LOW- AND INTERMEDIATE- LEVEL RADIOACTIVE WASTES IS SURVEYED, AND BRIEF ECONOMIC EVALUATIONS OF NEW TREATMENT METHODS ARE INCLUDED. THE METHODS INCLUDE (1) SCAVENGING-PRECIPITATION ION-EXCHANGE PROCESS FOR LOW-LEVEL WASTE, (2) A SCAVENGING-PRECIPITATION FOAM-SEPARATION PROCESS, (3) A METHOD FOR TREATING PROCESS CONDENSATE WASTES CONTAINING AMMONIA AND ORGANIC MATERIALS BY USE OF A STEAM-STRIPPING COLUMN (STEAM STRIPPING, FILTRATION, AND SEQUENTIAL SORPTION ON ANION AND CATION EXCHANGE RESINS), AND (4) A METHOD FOR INCORPORATING INTERMEDIATE-LEVEL WASTES IN ASPHALT.

*ION EXCHANGE + *WASTE TREATMENT, ECONOMICS + *WASTE TREATMENT, FIXATION + *WASTE TREATMENT, LIQUID + CERIUM + CESIUM + COBALT + FILTRATION + FOAM + MINERAL EXCHANGE + PRECIPITATION + RUTHENIUM + STRONTIUM

14-11524 STOREBO PB

PREDICTION OF MASSIVE WASH-OUT OF NUCLEAR BOMB DEBRIS

NORWEGIAN DEFENCE RESEARCH ESTABLISHMENT, KJELLER, NORWAY

2 PAGES, 5 FIGURES, HEALTH PHYSICS 11(11), PAGES 1203-1211, (NOVEMBER 1965)

PROBLEMS CONCERNING WASHOUT OF NUCLEAR BOMB DEBRIS ARE DISCUSSED IN CONNECTION WITH PREDICTION OF CLOSE-IN FALLOUT AREAS. WITH ADEQUATE WEATHER FORECASTS IT SHOULD BE POSSIBLE TO ADD WASHOUT FROM EXTENDED PRECIPITATION SYSTEMS TO PREDICTIONS OF DRY FALLOUT, FOR WHICH WIND INFORMATION ONLY IS NECESSARY. A DIAGRAM BASED ON COMPUTATION IS PRESENTED, FROM WHICH A QUANTITATIVE ESTIMATE OF WASHOUT MAY BE MADE FOR LOCATIONS WITHIN THE FALLOUT SECTOR WHEN BOMB SIZE, WIND SPEED, DISTANCE FROM GROUND ZERO, AMOUNT OF RAIN, AND TOP HEIGHT OF RAIN-PRODUCING LAYERS ARE KNOWN OR INDEPENDENTLY PREDICTED.

*WASHOUT + ATMOSPHERIC DIFFUSION + FALLOUT + NUCLEAR DETONATION + PARTICLE SIZE DISTRIBUTION + RAINOUT

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11531 COMAR CL + WASSERMAN RH + LENGEMANN FW
EFFECT OF DIETARY CALCIUM ON SECRETION OF STRONTIUM INTO MILK
CORNELL UNIVERSITY, NEW YORK STATE VETERINARY COLLEGE
6 PAGES, 4 TABLES, 16 REFERENCES, HEALTH PHYSICS 12(1), PAGES 1-6 (JANUARY 1966)

DAIRY COWS WERE RAISED FROM 5 MONTHS TO 2-1/2 YEARS OF AGE ON EITHER (A) A BASAL RATION THAT SUPPLIED 54 G OF CALCIUM PER DAY OR (B) THE SAME BASAL RATION BUT SUPPLEMENTED WITH INORGANIC SR-90-FREE CALCIUM TO SUPPLY 121 G OF CALCIUM DAILY. ANIMALS IN BOTH GROUPS CONSUMED ESSENTIALLY THE SAME AMOUNT OF SR-90 AND PRODUCED THE SAME AMOUNT OF MILK. THE MILK FROM ANIMALS ON THE BASAL RATION CONTAINED 8.4 PC OF SR-90 PER LITER, COMPARED WITH 4.4 IN MILK FROM ANIMALS ON THE SUPPLEMENTED RATION. THEREFORE THE SR-90 SECRETION INTO MILK WAS APPROXIMATELY INVERSELY PROPORTIONAL TO THE CALCIUM INTAKE, AS WAS PREDICTED FROM EARLIER EXPERIMENTS. THIS RELATIONSHIP WAS CONFIRMED BY A DOUBLE-TRACER STUDY USING SR-85 AND CA-47. THE EXTENT TO WHICH THE SAME RELATIONSHIP WOULD HOLD OUTSIDE THE RANGE OF CALCIUM INTAKES AND DIETARY CONDITIONS USED IN THE PRESENT STUDY IS NOT KNOWN. ABOUT 50 PERCENT OF THE SR-90 AND CALCIUM IN THE MILK ORIGINATED FROM THE DIET, AND ABOUT 50 PERCENT FROM THE BODY OF THE COW.

*BIOLOGICAL CONCENTRATION, MILK + *ECOLOGICAL CONSIDERATION + *STRONTIUM +
BIOLOGICAL CONCENTRATION, ANIMAL FEED + CALCIUM

14-11633 HAWLEY CA
CONTROLLED ENVIRONMENTAL RADIOIODINE TESTS AT THE NATIONAL REACTOR TESTING STATION, 1965 PROGRESS REPORT
USAEC, IDAHO OPERATIONS OFFICE
100-12047 +. 41 PAGES, 17 FIGURES, 10 TABLES, 15 REFERENCES, FEBRUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

THE CERT PROJECT CONSISTS OF A SERIES OF RELEASES OF RADIOIODINE OVER DIFFERENT VEGETATION AND DURING VARIOUS METEOROLOGICAL CONDITIONS, WITH THE PRIME OBJECTIVE BEING TO MEASURE THE RELATIONSHIPS INVOLVED IN THE PASSAGE OF RADIOIODINE THROUGH THE AIR-VEGETATION-COW-MILK-HUMAN CHAIN. THIS REPORT DEALS WITH THE RESULTS OF THE FIRST FIVE TESTS IN THE SERIES, WHICH STARTED IN THE SPRING OF 1963 AND IS CONTINUING. EACH TEST WAS CONDUCTED UNDER MEASURED METEOROLOGICAL CONDITIONS AND OVER PREPARED SAMPLING AND GRAZING COURSES. TWO TESTS WERE MADE OVER OPEN-RANGE TYPE VEGETATION, TWO OVER IRRIGATED PASTURES, AND ONE OVER SNOW-COVERED GROUND. TWO TESTS WERE CONDUCTED UNDER LAPSE CONDITIONS, TWO UNDER INVERSION CONDITIONS, AND ONE UNDER NEUTRAL CONDITIONS. DATA, DESCRIPTIONS OF METHODS, AND CALCULATIONS ARE REPORTED. DISCUSSIONS OF RESUSPENSION FACTORS AND PARTICLE SIZES AND BEHAVIOR ARE ALSO INCLUDED.

*FISSION PRODUCT, IODINE + *IODINE + BIOLOGICAL CONCENTRATION, MAN + BIOLOGICAL CONCENTRATION, MILK +
BIOLOGICAL CONCENTRATION, VEGETATION + DEPOSITION + DOSE CALCULATION, INTERNAL +
ECOLOGICAL CONSIDERATION + FISSION PRODUCT RELEASE, GENERAL + INGESTION + INHALATION +
METEOROLOGICAL SUPPORT + METEOROLOGY + PARTICLE SIZE + RESUSPENSION

14-11634 VORTMAN LJ
PROJECT SULKY. CLOSE-IN AIR BLAST FROM A RELATIVELY DEEP LOW-YIELD NUCLEAR DETONATION IN BASALT
SANDIA CORPORATION, ALBUQUERQUE, NEW MEXICO
PNE-711F +. 28 PAGES, 2 TABLES, 12 FIGURES, 6 REFERENCES, MAY 31, 1966, CFSTI \$1.50 CY, \$0.50 MN

CLOSE-IN AIR-BLAST MEASUREMENTS WERE MADE ON THE SULKY SHOT (AN 85-TON NUCLEAR DETONATION BURIED 90 FEET BELOW THE SURFACE IN BASALT). THE DOMINANT OVERPRESSURE WAS THAT RESULTING FROM A GROUND SHOCK WHICH TRANSMITTED PRESSURE TO THE AIR AT THE EPICENTER. THE PRESSURE WAVE THEN PROPAGATED AWAY FROM THE EPICENTER AT SONIC VELOCITY IN AIR. AN EARLIER WAVE OF 1/7 THE AMPLITUDE OF THE GROUND-SHOCK-INDUCED PEAK PROPAGATED AT THE VELOCITY OF A SEISMIC SURFACE WAVE. IT MAY HAVE BEEN DUE TO GAGE SENSITIVITY TO GROUND-SURFACE MOTION, OR IT MAY HAVE BEEN MEASUREMENT OF OVERPRESSURE RESULTING AT THE GAGE FROM SUCH GROUND MOTION. THE PULSE FROM VENTING GASES WAS WEAK BECAUSE OF THE RELATIVELY GREAT BURIAL DEPTH. IT WAS SUPER-IMPOSED ON THE NEGATIVE WAVE FOLLOWING THE GROUND-SHOCK-INDUCED PULSE AND GAVE PEAK VALUES EQUAL TO OR LESS THAN AMBIENT PRESSURE. IN ONE SENSE, THE GAS-VENTING PRESSURES WERE IN AGREEMENT WITH THOSE OF DANNY BOY, WHICH ALSO WERE SUPERIMPOSED ON A NEGATIVE WAVE BUT WHICH WERE STRONG ENOUGH TO HAVE POSITIVE VALUES BECAUSE OF THE RELATIVELY SHALLOWER BURIAL DEPTH. GROUND-SHOCK-INDUCED PEAKS FROM BOTH SULKY AND DANNY BOY ARE IN AGREEMENT WITH THOSE FROM HIGH-EXPLOSIVE SHOTS AT COMPARABLE BURIAL DEPTHS.

*NUCLEAR DETONATION + *PLOWSHARE PROGRAM + GEOLOGICAL CONSIDERATION, GEOPHYSICAL

14-11641 JORDAAN JM
LABORATORY SIMULATION OF WAVES GENERATED BY UNDERWATER NUCLEAR EXPLOSIONS
NAVAL CIVIL ENGINEERING LABORATORY, PORT HUENEME, CALIFORNIA
NCEL-TR-424 +. 37 PAGES, 5 TABLES, 16 FIGURES, JUNE 1966, DOD

THE KINEMATICS OF SURFACE GRAVITY WAVES PRODUCED IN WATER 2.5 FEET DEEP IN A BASIN 90 FEET SQUARE BY A SUDDEN, LOCALIZED DISTURBANCE WAS STUDIED THROUGH MEASUREMENTS OF HEIGHT AND PERIOD. THE WAVES WERE GENERATED BY THE QUICK WITHDRAWAL OR IMMERSION, OR COMBINATIONS OF THESE ACTIONS, OF A 14-FOOT-DIAMETER HALF-PARABOLOID PLUNGER LOCATED NEAR THE MID-POINT OF ONE WALL OF THE BASIN. SMALLER PLUNGERS OF DIVERSE SHAPES WERE ALSO USED. MEASUREMENTS WERE MADE BOTH IN THE CONSTANT-DEPTH PORTION OF THE BASIN AND OVER A BEACH WITH A UNIFORM SLOPE OF 1-13.6, WHICH WAS DIRECTLY OPPOSITE THE PLUNGER. AT THE SHORELINE ABOUT 80 FEET FROM THE PLUNGER, WAVES PRODUCED BY A SUDDEN WITHDRAWAL, FOR EXAMPLE, WERE 3 INCHES HIGH, WITH A MAXIMUM PERIOD OF 3 SECONDS. THE WAVES COMPARE ADEQUATELY WITH THOSE PREDICTED BY THE THEORY OF KRANZER AND KELLER, ALTHOUGH THEY WERE 40 PERCENT SMALLER AND 20 PERCENT SHORTER. BY EXTRAPOLATION, IT WAS FOUND THAT WAVES WERE PRODUCED WHICH ADEQUATELY SIMULATED THOSE FROM THE ACTUAL UNDERWATER DETONATION OF A HIGH-ENERGY EXPLOSIVE (5 TONS TNT) AND A NUCLEAR DEVICE (20 KT EQUIVALENT). IT IS CONCLUDED THAT WITH PROPER SCALING THE PLUNGER CAN BE USED TO SIMULATE WAVES FROM SUCH CAUSES.

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11641 *CONTINUED*
*NUCLEAR DETONATION + OCEAN AND SEA

14-11661 PAIGE BE
LEACHABILITY OF GLASS PREPARED FROM HIGHLY RADIOACTIVE CALCINED ALUMINA WASTE
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
IDO-14672 +. 32 PAGES, 12 FIGURES, 6 TABLES, FEBRUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

ALUMINA-PHOSPHATE GLASS WAS PREPARED FROM FULL-LEVEL RADIOACTIVE CALCINE PRODUCED IN THE WASTE CALCINING FACILITY AT THE IDAHO CHEMICAL PROCESSING PLANT. THE GLASS WAS PREPARED FROM 25 WEIGHT PERCENT ALUMINA CALCINE, 40.5 PERCENT P2O5 AND 18.6 PERCENT NA2O ADDED AS NAH2PO4-H2O, AND 15.9 PERCENT PBO. THE DETAILS OF PREPARATION AND THE EFFECT OF RADIATION AND HEAT TREATMENT ON THE GLASS ARE REPORTED. LEACHING DATA OBTAINED FOR FISSION PRODUCTS AND THE GLASS COMPONENTS ARE COMPARED FOR THE GLASS IN DISTILLED WATER AT 25 AND 94 C. A SPECIALLY DESIGNED APPARATUS WHICH CIRCULATED THE WATER CONTINUOUSLY WAS USED. THE HIGH LEVEL OF ACTIVITY MADE IT FEASIBLE TO USE A SINGLE MOLDED PIECE, PERMITTING THE SURFACE AREA AND OTHER EXPERIMENTAL CONDITIONS TO BE DEFINED TO A FAR GREATER DEGREE THAN IS FEASIBLE WITH THE CRUSHED GLASS REQUIRED FOR LOW LEVELS OF ACTIVITY. DEVITRIFICATION BY HEATING FOR 30 DAYS AT 450 C HAD NO EFFECT ON THE LEACHING RATE.

*CALCINATION + *GLASS + *WASTE TREATMENT, FIXATION + RADIATION EFFECT

14-11662 JANSEN G + WILLINGHAM WE + DEMIER WV
RIPIED RADIOACTIVE WASTE STORAGE TANK TEMPERATURES AND SOIL TEMPERATURES NEAR LEAKS
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL 101 +. 40 PAGES, 11 FIGURES, 7 TABLES, 7 REFERENCES, MARCH 1966, CFSTI \$3.00 CY, \$0.75 MN

THE TEMPERATURES AND HEAT LOSSES AROUND WASTE TANKS CONTAINING BOILING SOLUTIONS AND HEAT-GENERATING SLUDGE LAYERS ARE COMPARED FOR DRY AND WET SOILS. IN ALL CASES MOST OF THE CONDUCTED HEAT FLOWS FROM THE TOP OF THE TANK, THROUGH THE SOIL LAYER ABOVE THE TANK, AND TO THE ATMOSPHERE. THE TEMPERATURE DISTRIBUTION THROUGHOUT THE SOIL-TANK SYSTEM IS NEARLY INDEPENDENT OF THE MOISTURE CONTENT OF THE SOIL IF ALL THE SOIL IN THE SYSTEM HAS THE SAME THERMAL CONDUCTIVITY. HOWEVER, IF A LOCALIZED WET REGION APPEARS ONLY ADJACENT TO THE TANK WALL, HIGHER TEMPERATURES WILL BE FOUND IN THIS REGION OF THE SOIL THAN IN NEARBY DRY AREAS. REMOVAL OF ALL LIQUID FROM WASTE TANKS WITHOUT REMOVING THE SLUDGE CAN RESULT IN EXTREMELY HIGH TEMPERATURES. LEAKS OF ALKALINE SUPERNATE CONTAINING ONLY CESIUM AND SMALL AMOUNTS OF RUTHENIUM CANNOT CAUSE DANGEROUSLY HIGH SOIL TEMPERATURES. TEMPERATURE-RISE MAPS ARE PROVIDED FOR HEMISPHERICAL LEAKS, VARYING FROM 100 TO 100,000 GAL, FOR WET AND DRY SOIL AND FOR VARIOUS TYPES OF FISSION PRODUCTS. THESE MAPS MAY PROVE USEFUL IN ANALYZING TEMPERATURE RECORDS TO DETERMINE THE SIZE AND LOCATION OF A LEAK. A COMPUTER PROGRAM IS PROVIDED FOR CALCULATING TEMPERATURE RISE MAPS AROUND HEMISPHERICAL LEAKS AND HEMISPHEROIDAL LEAKS OF VARYING SHAPES. HIGHER TEMPERATURES ARE REACHED IN PROLATE HEMISPHEROIDAL LEAKS THAN IN HEMISPHERICAL LEAKS OF EQUAL VOLUME.

*THERMAL CONSIDERATION + *WASTE STORAGE + CESIUM + COMPUTER PROGRAM + HEAT CONDUCTION + HEAT TRANSFER + RUTHENIUM + SOIL, NUCLIDE OCCURRENCE + SOIL, RADIONUCLIDE MOVEMENT THROUGH

14-11663 BRAY LA + ROBERTS FP
PURIFICATION OF RARE EARTHS FROM HANFORD WASTES BY SOLVENT EXTRACTION
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-187 +. 31 PAGES, 9 FIGURES, 14 REFERENCES, FEBRUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

THE CO-EXTRACTION OF CERIUM AND RARE EARTHS INTO 0.4 M DI(2-ETHYLHEXYL) PHOSPHORIC ACID (D2EHPA) PLUS 0.2M TRI-N-BUTYL PHOSPHATE (TBP) IS COMPLICATED IF LARGE QUANTITIES OF MANGANESE ARE PRESENT. ALTHOUGH THIS SITUATION MAY NOT OCCUR IN FUTURE RARE-EARTH PROCESSING, A SEPARATION SCHEME HAD TO BE FOUND FOR PROCESSING A LARGE BATCH OF CURRENT FEED MATERIAL. BOTH LABORATORY AND HOT-CELL EXPERIMENTS SHOWED THAT A GOOD SEPARATION OF MANGANESE AND THE RARE EARTHS IS POSSIBLE BY CONTROLLED-PH SOLVENT EXTRACTION. BECAUSE PH CONTROL IS VERY DIFFICULT IN THE PLANT, UNRELIABLE RESULTS AND HIGH PRODUCT LOSSES OCCURRED IN THE FULL-SCALE TESTS. THE D2EHPA SOLVENT EXTRACTION SCHEME FOR MANGANESE REMOVAL PROVED IMPRACTICAL. ANOTHER SCHEME, BASED ON SULFATE PRECIPITATION WAS DEVELOPED. THIS PROCESS, ALTHOUGH COMPLICATED BY THE LACK OF A CENTRIFUGE IN THE PLANT, DOES NOT REQUIRE PH CONTROL. PRELIMINARY SEMIWORKS RESULTS INDICATE 85 TO 95 PERCENT RARE-EARTH RECOVERY, AND AN ADEQUATE MANGANESE DECONTAMINATION FACTOR OF 50 TO 100.

*RARE EARTH + *WASTE TREATMENT, LIQUID + CERIUM + MANGANESE

14-11702 LACHAPPELLE DG
AN ENGINEERING EVALUATION OF A RADIOACTIVE-WASTE INCINERATOR
U. S. ARMY NUCLEAR DEFENSE LABORATORY, EDGEWOOD ARSENAL, MARYLAND
CONF-660904 +. 67 PAGES, 32 FIGURES, TABLES, 4 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON, MASS., SEPTEMBER 13-16, 1966, SOURCE

A 50-LB/HR INCINERATOR AND ASSOCIATED GAS-CLEANING EQUIPMENT FOR THE CONCENTRATION OF LOW-LEVEL RADIOACTIVE WASTE WERE EVALUATED BY USE OF NONRADIOACTIVE MATERIAL, AND OPTIMUM OPERATING CONDITIONS FOR THE INCINERATOR AND THE GAS CLEANING EQUIPMENT RESULTED. THESE CONDITIONS WERE USED DURING THE RADIOLOGICAL EVALUATION. TESTS WITH SAWDUST CHARGES CONTAINING UP TO 200 MICROCURIES PER KG OF CHARGE WERE SUCCESSFULLY INCINERATED. ACTIVITY CONCENTRATION OF THE SR-89 DISCHARGED TO ATMOSPHERE WAS ALWAYS BELOW MPC LIMITS. TESTS ARE PRESENTLY BEING CONDUCTED IN WHICH ANIMALS INJECTED INTRAVENOUSLY WITH SR-89 ARE BEING INCINERATED TO DETERMINE IF THIS TYPE CHARGE CAN BE SAFELY HANDLED BY THE FACILITY. THE MAXIMUM AMOUNT OF SR INJECTED CORRESPONDS TO 200 MICROCURIES PER KG OF BODY WEIGHT.

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11702 *CONTINUED*

*INCINERATION + *STRONTIUM + *WASTE DISPOSAL, GENERAL + *WASTE TREATMENT, EQUIPMENT +
*WASTE TREATMENT, SOLID + AIR CLEANING + FISSION PRODUCT TRANSPORT + WASTE DISPOSAL, SOLID +
WASTE HANDLING

14-11703 FIRST MW + ZILLES P + WALKLEY J

DISPOSAL OF LOW LEVEL RADIOACTIVE WASTE IN COMMERCIAL INCINERATORS

HARVARD UNIVERSITY

CONF-660904 +. 12 PAGES, 5 FIGURES, 7 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON,
MASS., SEPTEMBER 13-16, 1966, SOURCE

THE HARVARD BOILER-INCINERATOR, HANDLING PACKAGED WASTES IN MECHANICAL SYSTEMS, IS A SANITARY
WAY OF HANDLING AND BURNING ESPECIALLY TROUBLESOME LABORATORY WASTES EFFICIENTLY AND FAST.
THE CYCLONE PRECOLLECTOR IS SUPERFLUOUS WITH GAS OR OIL FUELS AND CAN BE ELIMINATED WITHOUT
DECREASING OVERALL COLLECTION EFFICIENCY BY THE ELECTROSTATIC PRECIPITATOR THAT FOLLOWS IT.
THE REASONS FOR THE POOR EFFICIENCY OF THE ELECTROSTATIC PRECIPITATOR IN THIS TYPE OF SERVICE
REQUIRE ADDITIONAL STUDY.

*INCINERATION + *WASTE DISPOSAL, GENERAL + *WASTE TREATMENT, EQUIPMENT + *WASTE TREATMENT, SOLID +
AIR CLEANING + WASTE DISPOSAL, SOLID + WASTE HANDLING

14-11704 MANNESCHMIDT JF

RECENT ADVANCES IN MONITORING OF RADIOACTIVE GASEOUS WASTES AT ORNL

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE

CONF-660904 +. 27 PAGES, 17 FIGURES, 6 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON,
MASS., SEPTEMBER 13-16, 1966, SOURCE

MANY ACTIVITIES AT THE OAK RIDGE NATIONAL LABORATORY ARE CONCERNED WITH THE CHEMICAL
PROCESSING OF RADIOACTIVE MATERIALS. GASEOUS EFFLUENTS FROM THESE OPERATIONS ARE TREATED TO
REMOVE DANGEROUS CONTAMINANTS BEFORE RELEASE TO THE ATMOSPHERE. ROUTINE MONITORING OF SUCH
EMISSIONS WAS STARTED IN 1966 WHEN MANUALLY OPERATED PARTICULATE MONITORS WERE INSTALLED AT
EACH OF THREE PROCESS STACKS. SINCE THAT DATE, COVERAGE HAS BEEN EXTENDED TO SIX STACKS, THE
SAMPLE WITHDRAWAL SYSTEM HAS BEEN REBUILT, AND THE DETECTION EQUIPMENT HAS BEEN ADDED TO AND
MODERNIZED. THE INTENSIVE MONITORING HAS LEAD TO PROCESS IMPROVEMENTS THAT HAVE REDUCED THE
ENVIRONMENTAL RELEASES OF RADIOACTIVITY IN THE GASEOUS WASTE EFFLUENTS BY A FACTOR OF 3 SINCE
1962.

*MONITOR, RADIATION, EMERGENCY + *MONITOR, RADIATION, GAS + *MONITOR, RADIATION, GENERAL PRACTICE +
*MONITOR, RADIATION, SAMPLING + *MONITOR, RADIATION, STACK + MONITOR, RADIATION, AIR +
MONITOR, RADIATION, BACKGROUND + MONITOR, RADIATION, ENVIRONMENTAL + MONITOR, RADIATION, GENERAL

14-11774 SHIH CS + GLOYNA EF

RADIOACTIVITY TRANSPORT IN WATER - TRANSPORT OF SR85 AND CS137 IN AN AQUATIC ENVIRONMENT

UNIVERSITY OF TEXAS, ENVIRONMENTAL HEALTH ENGINEERING RESEARCH LABORATORY

EHE-01-6602 + CRWR-10 +. 97 PAGES, 24 TABLES, 39 FIGURES, JANUARY 20, 1966, SOURCE

THE TRANSPORT OF SR-85 AND CS-137 WAS OBSERVED IN A MODEL RIVER CONTAINING LAKE SEDIMENTS,
TYPICAL ROOTED PLANTS, AND SUSPENDED PLANKTON. MEASUREMENTS OF THE UPTAKE AND RELEASE IN
AQUATIC SYSTEMS AFTER A SINGLE RELEASE WERE MADE FOR VARIOUS LOCATIONS AND TIMES DURING 120
DAYS. MEASUREMENTS WERE ALSO MADE OF PH, OXIDATION-REDUCTION POTENTIAL, DISSOLVED OXYGEN,
TEMPERATURE, TOTAL AND FILTERED LIGHT INTENSITY, CARBON DIOXIDE, BIOMASS GEOCHEMICAL
ANALYSES, AND FLOW. THE RESULTS DESCRIBE THE RELATIVE UPTAKE AND TRANSPORT BY THE COMPONENTS
OF THE FLUME SYSTEM. GRAPHICAL TECHNIQUES WERE DEVELOPED TO DESCRIBE THE DISTRIBUTION OF
RADIO-NUCLIDES IN THE LIQUID PHASE, AND ANALYTICAL EXPRESSIONS WERE OBTAINED TO RELATE THE
MEASURED DETENTION TO THE AMOUNTS OF PLANTS, SEDIMENTS, AND SUSPENDED SOLIDS.

*CESIUM + *ECOLOGICAL CONSIDERATION + *STRONTIUM + *SURFACE WATER, DISPOSAL MEDIA +
BIOLOGICAL CONCENTRATION, AQUATIC ORGANISMS + ION EXCHANGE + MINERAL EXCHANGE + RIVER, GENERAL +
SAMPLING + SPECTROMETRY, GAMMA + SURFACE WATER, NUCLIDE OCCURRENCE + SURFACE WATER, PROPERTY +
SURFACE WATER, SEDIMENT + SURFACE WATER, TRACER

14-11777 SHIPMAN WH

CONCENTRATION OF STRONTIUM FROM SEAWATER BY MANGANESE DIOXIDE. DETERMINATION OF SR-90 IN LARGE VOLUMES OF
SEAWATER

NAVAL RADIOLOGICAL DEFENSE LABORATORY, SAN FRANCISCO

USNRDL-TR-995 + AD-635528 +. 14 PAGES, 3 FIGURES, 4 TABLES, 5 REFERENCES, FEBRUARY 27, 1966, DDC

THE ADSORPTION OF STRONTIUM BY HYDROUS MANGANESE DIOXIDE WAS USED TO CONCENTRATE STRONTIUM IN
SEAWATER. THE IMPORTANT FACTORS IN THIS CONCENTRATION PROCESS WERE STUDIED. A COMPLETE
RADIOCHEMICAL PROCEDURE IS PRESENTED.

*ANALYTICAL TECHNIQUE, WATER + *STRONTIUM + FALLOUT + OCEAN AND SEA + SURFACE WATER, NUCLIDE OCCURRENCE

14-11786 RASTOGI RC + SEHGAL JDD + THOMAS KJ

INVESTIGATION OF MATERIALS FOR FIXATION OF LOW AND MEDIUM LEVEL RADIOACTIVE WASTE IN STABLE SOLID MEDIA
ATOMIC ENERGY ESTABLISHMENT, TROMBAY

AEET-250 +. 64 PAGES, 24 FIGURES, 16 TABLES, 1966, DEP. MN.

THIS REPORT DESCRIBES A PROPOSAL FOR THE FIXATION (INTO VITREOUS PRODUCTS) OF SPENT
VERMICULITE AND SYNTHETIC CHEMICAL-TREATMENT-PLANT SLUDGE OBTAINED AS SECONDARY WASTES IN THE

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11786 *CONTINUED*

TREATMENT OF RADIOACTIVE LIQUID EFFLUENTS AND ASHES OBTAINED BY BURNING CONTAMINATED WASTES IN A PILOT INCINERATOR. RESULTS OF THE FISSION STUDIES (VERMICULITE, SYNTHETIC SLUDGE, AND INCINERATOR ASHES) AND OF THE LEACHING CHARACTERISTICS OF THE FUSED MASS AND THE VOLUME REDUCTION OBTAINABLE ARE PRESENTED. AN APPARATUS ASSEMBLED FOR STUDYING VOLATILIZATION LOSS OF CS BY USING ITS STABLE SALT, AND AN APPLICATION OF FLAME PHOTOMETRY TO ESTIMATE VOLATILIZED CS ARE DESCRIBED. RESULTS ON THE LOSS OF CS BY VOLATILIZATION DURING FIRING ARE PRESENTED. THE EFFECT OF SELF-ABSORPTION OF RADIATION DURING FINAL STORAGE ON CORROSION RESISTANCE OF GLASS HAS BEEN STUDIED.

*WASTE TREATMENT, FIXATION + CESIUM + DOSE + INCINERATION + RUTHENIUM + STRONTIUM + WASTE DISPOSAL, GENERAL + WASTE DISPOSAL, LIQUID + WASTE STORAGE + WASTE TREATMENT, EQUIPMENT + WASTE TREATMENT, LIQUID + WASTE TREATMENT, SOLID

14-11805 LEE, PK + FULTYN RV

KIWI TRANSIENT NUCLEAR TEST DOSE RATE SURVEY

LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO

LA-3519 +. 51 PAGES, 2 TABLES, 24 FIGURES, MARCH 1966, CFSTI \$3.00 CY, \$0.50 MN

FOLLOWING THE KIWI TNT EVENT, INTENSIVE, ACCURATE DOSE-RATE SURVEYS WERE TAKEN OF THE CONTAMINATED AREAS SURROUNDING THE TEST POINT. THE DATA COLLECTED DURING THESE SURVEYS, AND DECAY RELATIONSHIPS DERIVED THEREFROM, ARE PRESENTED.

*DOSE MEASUREMENT, EXTERNAL + *SURVEY, RADIATION, ENVIRONMENTAL + KIWI TNT (TRANSIENT NUCLEAR TEST) + NUCLEAR ROCKET + REACTOR, SAFETY RESEARCH + REACTOR, SPACE + ROVER PROGRAM

14-11816 RAWSON D + RANDOLPH P + BOARDMAN C + WHEELER V

POST-EXPLOSION ENVIRONMENT RESULTING FROM THE SALMON EVENT

UNIVERSITY OF CALIFORNIA, LAWRENCE RADIATION LABORATORY, LIVERMORE

UCRL-14,280, REV. II +. 41 PAGES, 11 REFERENCES, 4 TABLES, JUNE 1966, PREPARED FOR SUBMITTAL TO THE JOURNAL OF GEOPHYSICAL RESEARCH, CFSTI

THE SALMON EVENT WAS A 4.8- TO 5.8-KT NUCLEAR DETONATION AT A DEPTH OF 827.8 M IN THE TATUM SALT DOME IN MISSISSIPPI. THE EXPLOSION CREATED A NEARLY SPHERICAL CAVITY OF A RADIUS 16.8 TO 18 M, AND VAPORIZED AND MELTED APPROXIMATELY 5,400,000 KG OF ROCK WHICH FORMED A PUDDLE OF RECRYSTALLIZED SALT. RADIOACTIVE MELT INJECTED INTO CRACKS WAS OBSERVED AS FAR AS 37 M FROM THE SHOT POINT, AND RADIOACTIVITY INCREASED ABOVE BACKGROUND AS FAR AS 64 M. THE WALL ROCK WAS HIGHLY MICROFRACTURED AND CONTAINED SOME MACROFRACTURES. THE MOST BROKEN PORTION OF THE ROCK SURROUNDING THE CAVITY WAS OBSERVED IN THE REGION 39 TO 50 M BELOW SHOT POINT. IT IS CONCLUDED THAT THE RESULTING CAVITY IS STABLE AND CAN BE USED FOR A DECOUPLED OR PARTLY DECOUPLED EXPERIMENT. HOWEVER, THE MATERIAL SURROUNDING THE CAVITY IS LESS COMPETENT THAN THE PRESLOT CONDITION, AND THE STRENGTH PROPERTIES AND STRESS DISTRIBUTION OF THAT ROCK ARE NOT KNOWN.

*PLOWSHARE PROGRAM + *SALMON EVENT + GEOLOGICAL CONSIDERATION, GEOPHYSICAL + HYDROLOGICAL CONSIDERATION, GENERAL + NUCLEAR DETONATION

14-11817 COMMANDER RE + LOHSE GE + BLACK DE + COOPER ED

OPERATION OF THE WASTE CALCINING FACILITY WITH HIGHLY RADIOACTIVE AQUEOUS WASTE. REPORT OF THE FIRST PROCESSING CAMPAIGN

PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO

IDO-14662 +. 70 PAGES, 13 FIGURES, 9 TABLES, 15 REFERENCES, JUNE 1966, CFSTI \$3.00 CY, \$0.75 MN

THE WORLD'S FIRST MAJOR BREAKTHROUGH IN TREATING HIGH-LEVEL RADIOACTIVE AQUEOUS WASTE HAS BEEN ACHIEVED AT THE IDAHO CHEMICAL PROCESSING PLANT WHERE THE WASTE CALCINING FACILITY CONVERTS RADIOACTIVE WASTE SOLUTIONS TO SOLIDS. FROM DECEMBER 1963 TO OCTOBER 1964, ABOUT 512,000 GALLONS OF WASTE CONTAINING UP TO 40 CURIES OF VARIOUS RADIONUCLIDES PER GALLON WERE CALCINED IN AN AIR-FLUIDIZED BED HEATED TO 400 C BY MEANS OF A LIQUID-METAL HEAT-TRANSFER SYSTEM. AN OPERATING FACTOR OF 99.2 PERCENT WAS ACHIEVED, AND DECONTAMINATION OF THE OFF-GAS FROM THE FLUIDIZED BED WAS EXCELLENT.

*CALCINATION + *WASTE TREATMENT, FIXATION + DECONTAMINATION + HEAT GENERATION, INTERNAL + HEAT TRANSFER + INSTRUMENTATION, GENERAL + INSTRUMENTATION, LIQUID LEVEL DETECTION + INSTRUMENTATION, TEMPERATURE + MONITOR, RADIATION, GAS + WASTE DISPOSAL, SOLID + WASTE TREATMENT, EQUIPMENT + WASTE TREATMENT, LIQUID

14-11819 HARDY EP + RIVERA J

FALLOUT PROGRAM QUARTERLY SUMMARY REPORT. DECEMBER 1, 1965-MARCH 1, 1966

NEW YORK OPERATIONS OFFICE USAEC, HEALTH AND SAFETY LABORATORY

HASL-171 +. 430 PAGES, 22 TABLES, 8 FIGURES, 9 REFERENCES, APRIL 1, 1966, CFSTI \$7.30 CY, \$2.00 MN

THIS REPORT PRESENTS CURRENT DATA FROM THE HASL FALLOUT PROGRAM, THE NEW ZEALAND DEPARTMENT OF SCIENTIFIC AND INDUSTRIAL RESEARCH, THE NEW ZEALAND NATIONAL RADIATION LABORATORY, ARGONNE NATIONAL LABORATORY, U. S. NAVAL RADIOLOGICAL DEFENSE LABORATORY AND THE USDA SOIL CONSERVATION SERVICE. RADIONUCLIDE LEVELS IN FALLOUT, MILK, TAP WATER, DIET, SURFACE AND HIGH ALTITUDE AIR, ARE GIVEN IN TABULAR FORM. ALSO INCLUDED ARE INTERPRETIVE REPORTS AND NOTES DEALING WITH FALLOUT IN THE PACIFIC OCEAN, DEPTH DISTRIBUTION OF STRONTIUM-90 IN SOIL, DEVELOPMENT OF A SOIL STRONTIUM-90 METHOD, STRONTIUM-90 CONTAMINATION OF REAGENTS USED IN SEA-WATER ANALYSES, AND THE TRANSFER OF FALLOUT STRONTIUM-90 TO COWS MILK. A BIBLIOGRAPHY OF RECENT PUBLICATIONS RELATED TO NUCLEAR DEBRIS STUDIES IS PRESENTED.

*FALLOUT + *SURVEY, RADIATION, ENVIRONMENTAL + AIR + BIOLOGICAL CONCENTRATION, FOOD + BIOLOGICAL CONCENTRATION, GENERAL + BIOLOGICAL CONCENTRATION, MILK + CADMIUM + NEW ZEALAND +

ACCESSION NUMBER 14-11786 TO 14-11819

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11819 *CONTINUED*
NUCLEAR EXPLOSION DEBRIS + OCEAN AND SEA + RAINOUT + SAMPLING + SOIL, NUCLIDE OCCURRENCE + STRATOSPHERE + STRONTIUM + SURFACE WATER, NUCLIDE OCCURRENCE

14-11821 PAUL RA + DAY WC
TRACE ELEMENTS IN COMMON ROCK TYPES AND THEIR RELATIVE IMPORTANCE IN NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS
ARMY ENGINEER NUCLEAR CRATERING GROUP, LIVERMORE, CALIFORNIA
PNE-5006 +. 31 PAGES, 9 TABLES, 6 FIGURES, 61 REFERENCES, JUNE 1966, CFSTI \$1.50 CY, \$0.50 MN

A LITERATURE SEARCH WAS UNDERTAKEN TO DETERMINE THE AVERAGE AND RANGE OF CONTENT OF TRACE ELEMENTS IN COMMON ROCK TYPES TO PERMIT AN EVALUATION OF THEIR RELATIVE IMPORTANCE IN NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS. THE ELEMENTS CONSIDERED IN THE STUDY WERE DY, GD, EU, SM, ND, CD, AG, CO, CR, V, SC, CL, S, B, AND LI. DATA ARE REPORTED GIVING CONTENT OF THESE ELEMENTS IN TEN IGNEOUS ROCK TYPES AND THREE SEDIMENTARY ROCK TYPES. THE FIVE ELEMENTS GD, EU, SM, B, AND CL WERE FOUND TO OCCUR IN MOST ROCK TYPES IN QUANTITIES WHICH WOULD SIGNIFICANTLY AFFECT NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS. CALCULATIONS OF INDUCED RADIOACTIVITY WERE PERFORMED FOR GRANITE USING MAXIMUM, AVERAGE, AND MINIMUM TRACE ELEMENT VALUES OBTAINED FROM THE LITERATURE SEARCH. CALCULATIONS WERE ALSO PERFORMED USING AVERAGE TRACE ELEMENT VALUES FOR FOUR OTHER IGNEOUS ROCKS AND TWO SEDIMENTARY ROCKS. IT IS CONCLUDED THAT, IN GENERAL, USE OF THE AVERAGE VALUES FOR TRACE ELEMENTS PRESENTED IN THIS REPORT IS ADEQUATE FOR ASSESSING THE PRODUCTION QUANTITIES OF RADIONUCLIDES INDUCED EXTERNAL TO THE DEVICE FOR USE IN FEASIBILITY STUDIES FOR LARGE SCALE EXCAVATION PROJECTS AND OTHER UNDERGROUND NUCLEAR DETONATIONS WHEN DETAILED CHEMICAL ANALYSES OF EMPLACEMENT MEDIA ARE NOT AVAILABLE.

*ACTIVATION PRODUCT + *PLOWSHARE PROGRAM + GEOLOGICAL CONSIDERATION, GEOCHEMICAL + NEUTRON + NUCLEAR DETONATION

14-11822 BACKGROUND FOR MILK RADIOACTIVITY REPORTS
U.S. DEPT. OF HEALTH, EDUCATION, AND WELFARE
PRESS REL. HEW-K50 +. 5 PAGES, 1 TABLE, APRIL 1966, DPI

THIS PUBLICATION PROVIDES THE MOST RECENT INFORMATION AVAILABLE CONCERNING CONCENTRATIONS OF RADIOACTIVITY IN MILK SAMPLES COLLECTED AT THE STATIONS OF THE NATIONAL PASTEURIZED MILK NETWORK OPERATED BY THE PUBLIC HEALTH SERVICE IN COOPERATION WITH STATE AND LOCAL GOVERNMENT AGENCIES. EVERY STATE IS REPRESENTED IN THE NETWORK.

*BIOLOGICAL CONCENTRATION, MILK + *SURVEY, RADIATION, USPHS + FALLOUT + IODINE + RADIATION SAFETY AND CONTROL + STRONTIUM

14-11823 ZIPPRICH F + CONDES S + HARTECK P
DECONTAMINATION OF PRODUCTS FROM CHEMONUCLEAR REACTIONS
RENSSELAER POLYTECHNIC INSTITUTE, TROY, NEW YORK
RPI-321-6 +. 130 PAGES, 10 TABLES, 28 FIGURES, 72 REFERENCES, JULY 1966, SOURCE

INVESTIGATIONS WERE MADE TO DETERMINE THE EXTENT OF CONTAMINATION AND METHODS OF DECONTAMINATION OF PRODUCTS MADE BY CHEMONUCLEAR REACTIONS. PREVIOUS WORK BY OTHERS IN THIS LABORATORY SHOWED THAT THE RADIOLYSIS OF CO AND MIXTURES OF N₂ AND O₂ WITH FISSION FRAGMENTS PRODUCES SOLID CARBON SUBOXIDE POLYMER AND NITROGEN DIOXIDE RESPECTIVELY. ENRICHED URANIUM INCORPORATED IN THE STRUCTURE OF THIN FIBERS PROVIDED THE SOURCE OF FISSION FRAGMENTS AND THE MEANS FOR THEIR ESCAPE INTO THE IRRADIATED PHASE.

*DECONTAMINATION + *NUCLEAR EXPLOSION DEBRIS + *PLOWSHARE PROGRAM + CHEMICAL ANALYSIS + CHEMICAL REACTION + CONTAMINATION + COUNTER + ION EXCHANGE + NUCLEAR DETONATION

14-11824 LUST LF + VAN DER COOK BP
SULFUR DETERMINATION SUPPORTING THE WASTE SOLIDIFICATION PROGRAM
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-265 +. 9 PAGES, 2 FIGURES, 3 TABLES, 3 REFERENCES, JULY 1966, CFSTI \$1.00 CY, \$0.50 MN

COMBUSTION WITH VANADIUM PENTOXIDE WAS EFFECTIVE METHOD IN SEPARATING SULFUR FROM THE SOLID PRODUCT PRODUCED BY THE SOLIDIFICATION OF FISSION-PRODUCT WASTES. AFTER THE SULFUR WAS VOLATILIZED FROM THE SAMPLE, THE SO₃ WAS REDUCED TO SULFUR DIOXIDE BY HOT COPPER TURNINGS, REMOVED FROM THE OFF-GAS STREAM, AND QUANTITATIVELY DETERMINED BY TITRATION OR BY COLORIMETRY.

*ANALYTICAL TECHNIQUE, SOLID + *WASTE TREATMENT, FIXATION + SULFUR + WASTE DISPOSAL, GENERAL

14-11829 FINAL REPORT OF OFF-SITE SURVEILLANCE FOR PROJECT SULKY
PUBLIC HEALTH SERVICE, LAS VEGAS
PNE-715F +. 14 PAGES, 1 FIGURE, 2 TABLES, MARCH 9, 1965, CFSTI \$1.00 CY, \$0.50 MN

THE U.S. PUBLIC HEALTH SERVICE PROVIDED OFF-SITE MONITORING FOR PROJECT SULKY, WHICH WAS CONDUCTED AT 1135 HOURS ON DECEMBER 18, 1964. THE HIGHEST GAMMA DOSE RATE RECORDED OFF-SITE WAS 0.06 MR/HR, AND NO FRESH FISSION PRODUCTS WERE DETECTED IN AIR, WATER, OR MILK SAMPLES COLLECTED AFTER THE EXPERIMENT. NO EXPOSURES EXCEEDED THOSE LISTED IN THE RADIOLOGICAL SAFETY GUIDES OF CHAPTER 0524 IN THE AEC MANUAL.

*MONITOR, RADIATION, NUCLEAR DETONATION + *PLOWSHARE PROGRAM + DOSE MEASUREMENT, EXTERNAL + FALLOUT + MONITOR, RADIATION, AIR + MONITOR, RADIATION, ENVIRONMENTAL + MONITOR, RADIATION, PERSONNEL +

CATEGORY 14
RADIONUCLIDE RELEASE AND MOVEMENT IN THE ENVIRONMENT

14-11829 *CONTINUED*
NUCLEAR DETONATION + SAMPLING + SURVEY, RADIATION, USPHS

14-11905 ACRS SUGGESTIONS ON AEC REACTOR SAFETY RESEARCH PROGRAM, OCTOBER 12, 1966
U. S. ATOMIC ENERGY COMMISSION
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 32-33 (OCTOBER 31, 1966)

(A) ACRS ATTACHES SPECIAL IMPORTANCE TO (1) STUDIES OF MOLTEN MASSES OF FUEL AND STRUCTURAL MATERIAL, (2) STUDIES OF EMERGENCY CORE COOLING PROCESSES, (3) PERIODIC PRESSURE-VESSEL INSPECTION, (4) PROPERTIES OF THICK STEEL PRESSURE-VESSEL SECTIONS, (5) PRESTRESSED CONCRETE PRESSURE VESSELS, AND (6) ADVANCED METHODS OF CALCULATING DESTRUCTIVE REACTIVITY TRANSIENTS IN WATER-COOLED REACTORS. (B) ACRS VIEWS AS OF CURRENT AND INCREASING SIGNIFICANCE (1) PRESSURE-VESSEL STEEL OTHER THAN A302B, (2) FRACTURE MECHANICS OF PRESSURE VESSELS, (3) REVIEW OF NONNUCLEAR EXPERIENCE ON PRIMARY COOLANT SYSTEM COMPONENTS, (4) STANDARD METHODS OF CALCULATING STANDARD ACCIDENTS, (5) RECYCLED PLUTONIUM FUEL, (6) EARLY DETECTION OF SMALL LEAKS IN PRIMARY COOLANT SYSTEMS, AND (7) WASTE DISPOSAL INTO SURFACE WATER, INCLUDING BIOLOGICAL CONCENTRATION, AS IN THE GREAT LAKES.

*ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + *RESEARCH CONTRACT + *SAFETY STUDY + ACCIDENT, REACTIVITY + BIOLOGICAL CONCENTRATION, GENERAL + CONTAINMENT, PRESSURE VESSEL + EMERGENCY COOLING + PLUTONIUM + WASTE DISPOSAL, RIVER

14-11959 JENSON DK
SAMPLING CALCINER OFF-GAS FOR RADIOACTIVE RUTHENIUM USING A POLYETHYLENE ABSORBER
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
4 PAGES, 8 FIGURES, 11 REFERENCES, HEALTH PHYSICS 12(7), PAGES 923-926 (JULY 1966)

AN ABSORBER FOR SAMPLING GASEOUS RADIOACTIVE RUTHENIUM IN THE OFF-GAS WAS DEVELOPED. THIS ABSORBER SAMPLER CONSISTED OF A GLASS CARTRIDGE PACKED WITH ASTM TYPE II POLYETHYLENE PELLETS. THE AMOUNT OF RUTHENIUM ON THE SAMPLE WAS DETERMINED BY GAMMA COUNTING. CONTINUOUS RADIATION FIELD MEASUREMENTS PROVIDED CONSTANT MONITORING OF THE OFF-GAS RADIOACTIVITY LEVEL. PERFORMANCE OF THE ABSORBER SAMPLER WAS EVALUATED THROUGHOUT 10 MONTHS OF OPERATION. NO SPECIES OF RUTHENIUM WERE FOUND TO PASS THROUGH THE ABSORBER WITHOUT BEING COLLECTED. TEMPERATURE WAS FOUND TO HAVE A DEFINITE EFFECT ON ABSORBER EFFICIENCY. RU-106 LEVELS MEASURED IN THE OFF-GAS CAN BE CORRELATED WITH OPERATING DATA. THE MEASUREMENT OF RUTHENIUM DISCHARGED WAS SUPPORTED BY ANALYSES OF ENVIRONMENTAL AIRBORNE PARTICULATE AND VEGETATION SAMPLES. IT IS CONCLUDED THAT THE SYSTEM IS SATISFACTORY AND ADEQUATE FOR OFF-GAS RUTHENIUM SAMPLING.

*RUTHENIUM + *SAMPLING + ANALYTICAL TECHNIQUE, GAS + CALCINATION + EFFLUENT + IDAHO FALLS + MONITOR, RADIATION, GAS + MONITOR, RADIATION, SAMPLING + MONITOR, RADIATION, STACK

CATEGORY 15
ENVIRONMENTAL, SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-08806 DOLPHIN GW + JACKSON S + LISTER BA
INTERPRETATION OF BIO-ASSAY DATA
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AHSB(RP)R-41 +. 21 PAGES, 8 FIGURES, 49 REFERENCES, APRIL 1964, UKAEA

IN THIS REVIEW THREE BROAD CATEGORIES HAVE BEEN USED IN CLASSIFYING THE DIFFERENT MODES OF METABOLISM OF VARIOUS RADIONUCLIDES. THE FIRST GROUP INCLUDES THOSE RADIO-NUCLIDES WHICH ARE RATHER UNIFORMLY DISTRIBUTED THROUGHOUT THE BODY. THE SECOND GROUP INCLUDES THOSE WHICH ARE CONCENTRATED PARTICULARLY IN ONE OR MORE ORGANS OF THE BODY. THE THIRD GROUP, REALLY A SPECIALLY IMPORTANT SUB-GROUP OF THE SECOND, COMPRISES THE BONE SEEKERS. THE PATTERN OF URINARY EXCRETION AND PARTICULARLY ITS RELATIONSHIP TO THE RADIATION DOSE DELIVERED TO THE CRITICAL TISSUES, ARE DISTINCTLY DIFFERENT FOR THESE DIFFERENT GROUPS. A SUMMARY IS PRESENTED OF THE HUMAN DATA AVAILABLE ON METABOLISM AND URINARY EXCRETION OF TRITIUM, CESIUM, URANIUM, STRONTIUM, RADIUM AND PLUTONIUM. THE SMALL AMOUNT OF REFERENCE DATA AVAILABLE ABOUT THE METABOLISM OF RADIONUCLIDES IS STILL, HOWEVER, A VERY SERIOUS WEAKNESS AND A GREAT DEAL MORE RESEARCH IS URGENTLY NECESSARY.

*DOSE CALCULATION, INTERNAL + BIOLOGICAL CONCENTRATION, MAN + CESIUM + COUNTER, WHOLE BODY + DOSE MEASUREMENT, INTERNAL + INGESTION + INHALATION + MAXIMUM PERMISSIBLE DOSE (MPD) + MONITOR, RADIATION, PERSONNEL + PLUTONIUM + SODIUM + STRONTIUM + TRITIUM + URANIUM

15-08810 VANDERVELL HD + MORGAN A
THE DETERMINATION CESIUM-137 IN ROOT MAT, HERBAGE AND MILK
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AERE-R-4522 +. 12 PAGES, 2 FIGURES, 1 TABLE, 9 REFERENCES, JUNE 1964, UKAEA

RADIOCHEMICAL METHODS FOR THE DETERMINATION OF CS-137 IN MILK, HERBAGE AND ROOT-MAT SAMPLES ARE DESCRIBED. THESE METHODS ARE ALL BASED ON THE SAME PRINCIPLE. THE SAMPLE, WITH ADDED CESIUM CARRIER, IS BROUGHT INTO SOLUTION, WHICH, AFTER ACIDIFICATION IS PASSED THROUGH A COLUMN, CONTAINING A MIXTURE OF AMMONIUM 12-MOLYBDOPHOSPHATE (AMP) AND ASBESTOS. CESIUM IS RETAINED ON THE COLUMN, FROM WHICH THE POTASSIUM MAY BE SUBSEQUENTLY REMOVED BY SELECTIVE ELUTION. WITH MILK AND HERBAGE SAMPLES, THE AMP IS DISSOLVED AND AFTER FILTERING OFF THE ASBESTOS, CESIUM IS PRECIPITATED FROM THE FILTRATE AS THE CHLOROPLATINATE WHICH IS MOUNTED AND BETA COUNTED. ADDITIONAL PURIFICATION STAGES ARE INTRODUCED IN THE CASE OF ROOT-MAT SAMPLES, TO ENSURE THAT ADEQUATE DECONTAMINATION FROM ARTIFICIAL AND NATURAL RADIONUCLIDES IS OBTAINED.

*ANALYTICAL TECHNIQUE, MILK + *ANALYTICAL TECHNIQUE, VEGETATION + *CESIUM + ANALYTICAL TECHNIQUE, GENERAL + BIOLOGICAL CONCENTRATION, MILK + BIOLOGICAL CONCENTRATION, VEGETATION + CHEMICAL ANALYSIS + SOIL, NUCLIDE OCCURRENCE + UNITED KINGDOM

15-09402 AIR COOLING UNIT FOR PROTECTIVE CLOTHING AND THE LIKE
SO. AF. PATENT 1822/64 +. APRIL 20, 1964, PATENT (FOREIGN)

THIS INVENTION PROVIDES A DEVICE FOR COOLING GAS SUPPLIED TO A PERSON WEARING PROTECTIVE CLOTHING AND COMPRISES A SOURCE OF PRESSURIZED GAS, A CONDUIT FOR CONDUCTING SAID GAS TO SAID PERSON, AND A VORTEX TUBE ATTACHABLE TO THE BODY OF SAID PERSON. THE CONDUIT IS ATTACHED TO THE INLET OF THE VORTEX TUBE. DISTRIBUTION CONDUITS CONNECTED TO THE COLD OUTLET OF THE VORTEX TUBE ARE PROVIDED FOR CONDUCTING THE COOLED GAS EITHER TO A FACE MASK ONLY OR TO VARIOUS POSITIONS WITHIN A PROTECTIVE SUIT PARTIALLY OR WHOLLY COVERING THE PERSON. A NOISE MUFFLER IS ALSO PROVIDED WHERE NECESSARY IN THE COLD OUTLET LINE OF THE VORTEX TUBE.

*PERSONNEL PROTECTIVE DEVICE

15-09499 EVANS HD
SURVEY OF HEALTH PHYSICS INSTRUMENTS
IMPERIAL COLLEGE, LONDON
6 PAGES, 12 FIGURES, NUCLEAR ENGINEERING, 10(115), PP. 459-464 (DECEMBER, 1965)

A SURVEY OF THE PRESENT FIELD OF PORTABLE HEALTH PHYSICS INSTRUMENTS WAS MADE AND INCLUDES PERSONAL-DOSE MEASURING DEVICES, DOSE-RATE METERS, CONTAMINATION METERS, NEUTRON MONITORING, AIR MONITORING, EFFLUENT MONITORING, AND HAND-AND-CLOTHING MONITORS. AUTHOR CONCLUDES THAT THERE IS A DANGER THAT INSTRUMENTS ARE BECOMING TOO VERSATILE.

*MONITOR, RADIATION, AIR + *MONITOR, RADIATION, GENERAL + *MONITOR, RADIATION, LIQUID + *MONITOR, RADIATION, PERSONNEL + AIR + DOSE + DOSIMETRY, GENERAL + DOSIMETRY, PHOTOGRAPHIC + DOSIMETRY, THERMOLUMINESCENCE + FAST NEUTRON + UNITED KINGDOM

15-09510 MCCASLIN JB
SOME USES AND CHARACTERISTICS OF MOS TRANSISTORS FOR HEALTH PHYSICS APPLICATIONS
LAWRENCE RADIATION LABORATORY, BERKELEY, CALIFORNIA
UCRL-16446 + CONF-651109-6 +. 31 PAGES, JULY 1965, FIRST SYMPOSIUM ON ACCELERATOR RADIATION DOSIMETRY AND EXPERIENCE, UPTON, N.Y., CFSTI, \$2.00 FS, \$0.50 MF

MOS (METAL-OXIDE SEMICONDUCTOR) ELECTROMETERS HAVE MANY ADVANTAGES TO RECOMMEND THEM OVER VACUUM-TUBE TYPES. AMONG THESE ARE HIGHER G-SUB-M, LOWER I-SUB-G, LESS DRIFT, LOW CURRENT DRAIN, AND NO FILAMENTS. THEY ARE MORE RUGGED AND FREE FROM RF INTERFERENCE. ON THE OTHER HAND, THEY ARE NOT NEARLY AS RADIATION-RESISTANT AS VACUUM TUBES AND MUST BE WELL SHIELDED IF THEY ARE TO BE USED IN HIGH-LEVEL RADIATION AREAS. A MODERATED FAST BF3 COUNTER CAPABLE OF PRODUCING 30 TO 50 NS PULSE-WIDTHS HAS BEEN DESCRIBED. THIS ALLOWS SENSITIVE OF3 NEUTRON DETECTORS TO BE USED WHERE THE NEUTRON FLUX DENSITY IS EXTREMELY HIGH. THE 4-PI COINCIDENCE-ANTICOINCIDENCE G-M UNIT DESCRIBED IS EXTREMELY SIMPLE AND VERSATILE. EITHER G-M

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-09510 *CONTINUED*
UNIT MAY BE READ OUT INDIVIDUALLY, OR THE COINCIDENCE AND ANTICOINCIDENCE PULSES MAY BE COUNTED.

*INSTRUMENTATION, RADIATION MONITORING + COUNTER + DOSE + RADIATION DAMAGE

15-09562 MULLIKIN MS
RADIOGRAPHY OVEREXPOSURE, UNIVERSAL TESTING COMPANY, MARCH 10, 1966
UNIVERSAL TESTING COMPANY
2 PAGES, APRIL 8, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 27-28 (MAY 2, 1966)

A TRAINEE FAILED TO CONNECT THE CONTROL CABLE TO THE SOURCE CABLE, SO THE SOURCE REMAINED OUT OF THE SHIELDING AFTER THE FIRST WELD RADIOGRAPH. AFTER FIVE EXPOSURE SETUPS, THE SURVEY METER WAS BROUGHT OUT OF THE TRUCK, AND CONDITION FOUND. RADIOGRAPHER SHOOK SOURCE OUT OF TUBE AND RETURNED TO SHIELD. RADIOGRAPHERS FILM BADGE READ 0.935 REM, ESTIMATED WHOLE BODY DOSE 3 REMS, AND RIGHT HAND 26 REM. TRAINEE ADJUSTED SOURCE TUBE FOR EACH SETUP, FILM BADGE READ 4.27 REMS, ESTIMATED 176 REMS TO KNEES, AND 40 TO GONADS.

*INCIDENT, ACTUAL, HUMAN ERROR + *PERSONNEL EXPOSURE, RADIATION + *RADIOGRAPHY + FAILURE, DESIGN ERROR + FAILURE, OPERATOR ERROR

15-09563 MCCORMACK JE
COBALT-60 INHALATION DURING INSPECTION OF INDIAN POINT I PRESSURIZER, JANUARY 25, 1966
CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES, APRIL 19, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 22-25 (MAY 2, 1966)

THREE MEN ENTERED THE PRESSURIZER (APPARENTLY UNMASKED) FOR 39 MIN TO INSPECT THE LINING AND WERE FOUND LIGHTLY CONTAMINATED. ALTHOUGH AN AIR MONITOR HAD SHOWN AIR BELOW MPC, THEY WERE TAKEN TO A WHOLE-BODY COUNTER 3 HR LATER. COBALT-60 AND POSSIBLY MN-54 WERE FOUND. HIGHEST DOSE WAS 0.14 REM, AND BODY BURDENS 1.5-2.5 MICROCUPIES. DEPENDING ON WHETHER TOTAL BURDEN OR RESPIRATORY BURDEN USED, AIR SAMPLER UNDERESTIMATED (BY FACTOR OF 210) OR OVERESTIMATED (BY 12) THE ACTUAL CONCENTRATION. AIR WAS DILUTED BY LONG HOSE NECESSARY TO MOVE MONITOR OUT OF HIGH BACKGROUND. PARTICLES MAY HAVE BEEN TOO LARGE AND SETTLED TOO RAPIDLY TO ENTER HOSE.

*DOSE MEASUREMENT, INTERNAL + *INCIDENT, ACTUAL, GENERAL + *INDIAN POINT I + *INHALATION + *MONITOR, RADIATION, AIR + *PRESSURIZER + COBALT + MAINTENANCE AND REPAIR + REACTOR, PRESSURIZED WATER

15-09569 SNYDER WS
THE VARIATION OF DOSE IN MAN FROM UNILATERAL EXPOSURE TO GAMMA RAYS
OAK RIDGE NATIONAL LABORATORY
9 PAGES, 4 FIGURES, 2 REFERENCES, TENNESSEE VALLEY INDUSTRIAL HEALTH CONFERENCE, GATLINBURG, TENNESSEE, SEPTEMBER 30-OCTOBER 1, 1965, SOURCE

A MONTE-CARLO-TYPE CODE WAS DEVELOPED AT ORNL TO PERMIT ONE TO ESTIMATE DOSE IN TISSUE PHANTOMS FOR A WIDE VARIETY OF EXPOSURE SITUATIONS. IN THIS PAPER, THE CODE WAS USED TO STUDY THE DISTRIBUTION OF DOSE IN A MAN-SIZED HOMOGENEOUS PHANTOM THAT CORRESPONDS TO THE TRUNK OF AN ADULT MAN WHEN THE PHANTOM IS EXPOSED TO A BROAD-BEAM SOURCE OF MONOENERGETIC PHANTOMS.

*DOSE + GROSS GAMMA + MONTE CARLO + PHANTOM, HUMAN BODY

15-09584 NEUTRON DOSIMETER
CANADIAN PAT. 709,053 +. ABSTRACT ONLY, MAY 4, 1965, PATENT (FOREIGN)

PATENT RELATES TO A MEANS FOR MEASURING FAST-NEUTRON SPECTRA AND EXPRESSING THIS MEASUREMENT DIRECTLY IN TERMS OF DOSE, BY IN-SITU COUNTING WITH A FISSION DETECTOR OF THE FISSION FRAGMENTS FROM A COMPOSITE FOIL. THE FOIL COMPRISES A NICKEL DISK, WHICH MAY BE ELECTROPLATED WITH A MIXTURE OF URANIUM-235, NEPTUNIUM-237, AND URANIUM-238. THE DETECTOR MAY BE A SOLID-STATE SURFACE-BARRIER DEVICE. THE DETECTOR AND FOIL ARE ENCLOSED WITHIN SUITABLE THERMAL NEUTRON SHIELDING FOR ELIMINATING THERMAL NEUTRONS. THE DETECTOR IS CONNECTED TO SUITABLE INSTRUMENTS FOR PROVIDING A DIRECT INDICATION OF THE FAST-NEUTRON SPECTRUM IN TERMS OF DOSE.

*DOSIMETRY, GENERAL + DOSE MEASUREMENT, EXTERNAL + FAST NEUTRON + INSTRUMENTATION, NUCLEAR + INSTRUMENTATION, RADIATION MONITORING

15-09726 UPTON AC
RADIOBIOLOGICAL ASPECTS OF THE SUPERSONIC TRANSPORT
OAK RIDGE NATIONAL LABORATORY
ORNL-P-1333 + ICRP/65-C1-2// +. 59 PAGES, 11 FIGURES, HEALTH PHYSICS, 12(2), PP. 209-226 (FEBRUARY 1966)

THE HIGH CRUISING ALTITUDE OF THE SUPERSONIC TRANSPORT (SST) WILL SUBJECT ITS OCCUPANTS TO LARGER AMOUNTS OF COSMIC RADIATION THAN ARE PRESENT AT SEA LEVEL OR AT ALTITUDES ATTAINED BY ORDINARY COMMERCIAL JET AIRCRAFT. THE PASSENGERS AND CREW OF THE SST WILL BE EXPOSED NOT ONLY TO INCREASED AMOUNTS OF GAMMA RAYS BUT ALSO TO PARTICULATE RADIATIONS. ASSESSMENT OF THE HEALTH IMPLICATIONS OF THE SST MUST, CONSEQUENTLY, TAKE INTO ACCOUNT THE AMOUNT, RELATIVE BIOLOGICAL EFFECTIVENESS, AND PROBABLE EFFECT OF THESE RADIATIONS, AND THE FACTORS AFFECTING THE CUMULATIVE EXPOSURE AND RADIOSENSITIVITY OF THE EXPOSED POPULATION. THE TASK GROUPS APPRAISAL OF THESE QUESTIONS IS SUMMARIZED IN THE FOLLOWING. RADIATION DOSES WHICH MAY BE RECEIVED BY PASSENGERS AND CREW OF THE SST ARE COMPARED WITH THE MAXIMUM PERMISSIBLE DOSES

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-09726 *CONTINUED*

RECOMMENDED BY THE ICRP FOR RADIATION WORKERS AND THE PUBLIC. ALTHOUGH NO ATTEMPT IS MADE IN THIS REPORT TO WEIGH THE POSSIBLE MAGNITUDE OF THE RESULTING RISKS FROM RADIATION IN COMPARISON WITH RISKS OF OTHER TYPES TO OCCUPANTS OF THE SST, THIS IS AN ASPECT OF THE PROBLEM WHICH MAY DESERVE CONSIDERATION IN EVALUATING THE PRACTICAL IMPLICATIONS OF THIS REPORT.

*AEROSPACE SAFETY + *BIOMEDICAL + *DOSE CALCULATION, INTERNAL + DOSE +
ICRP (INT. COMM. ON RADIOLOGICAL PROTECTION) + MAXIMUM PERMISSIBLE DOSE (MPD) + POPULATION EXPOSURE

15-09755 MEDICAL TREATMENT FOR REACTOR TECHNICIAN IRRADIATED IN MANUAL ROD WITHDRAWAL ACCIDENT IN BELGIUM

1 PAGE, 1 FIGURE, NUCLEONICS WEEK 7(39), PAGE 6 (SEPTEMBER 29, 1966)

MEDICAL DETAILS WERE REVEALED AT THE FIRST CONFERENCE OF THE INTERNATIONAL RADIATION PROTECTION ASSOCIATION. VICTIM WAS KEPT IN A STERILE ENVIRONMENT AND GIVEN BLOOD TREATMENT, BONE GRAFTS WERE NOT NECESSARY. THE ACCIDENT WAS RECONSTRUCTED SO DOSE MEASUREMENTS COULD BE MADE TO HELP DETERMINE TREATMENT. TECHNICIAN FAILED TO COMPLY WITH WRITTEN INSTRUCTION FOR CHANGING ABSORBER RODS. SYNCHRONIZATION OF CONTROL RODS WAS DONE IN ADVANCE, AND AN ERROR WAS MADE IN HANDLING FUEL. CONFERENCE PAPERS FOCUSED ON ACCIDENTS, SHOWING HOW THEY HAPPENED AND COULD BE AVOIDED.

*ACCIDENT, CRITICALITY + *DOSE MEASUREMENT, EXTERNAL + *FAILURE, OPERATOR ERROR +
*INCIDENT, ACTUAL, HUMAN ERROR + *RADIATION INJURY, TREATMENT OF + BELGIUM

15-09850 DUHAMEL F + LAVIE JM

THE LIMITATION OF THE QUANTITIES OF RADIOACTIVE SUBSTANCES MANIPULATED OR TRANSPORTED. EVALUATION OF ACCIDENTAL EXPOSURES TO RADIATION

ATOMIC ENERGY COMMISSION, NUCLEAR RESEARCH CENTER, SACLAY, FRANCE

AEC-TR-6525 +. 35 PAGES, TRANSLATED FROM HEALTH PHYSICS 10, PP. 453-468 (1964), JCL \$3.60 FS, \$1.25 MF

VARIOUS NATIONAL AND INTERNATIONAL GROUPS HAVE STUDIED THE PROBLEM OF LIMITING THE QUANTITIES OF RADIOACTIVE SUBSTANCES THAT MAY BE MANIPULATED UNDER CERTAIN OPERATING CONDITIONS. THE MOST VALUABLE STUDIES HAVE BEEN ACHIEVED ON THE BASIS OF RADIOBIOLOGY. NOW, IT IS CLEAR THAT THE RESULTS FROM RADIOBIOLOGY DO NOT SUFFICE TO ESTABLISH A COMPLETE AND SCIENTIFIC BASIS. FOR PRACTICAL APPLICATION, NUMEROUS COMPLEMENTARY HYPOTHESES MUST BE MADE. IN ATTEMPTING TO INTERRELATE OPERATIONS THAT ARE VERY DIFFERENT, THE AUTHORS PROPOSE A PROCEDURE WHICH, ALTHOUGH NOT SCIENTIFICALLY RIGOROUS, MAKES APPARENT THE RELATIONSHIPS BEING HYPOTHECATED BETWEEN THE FUNDAMENTAL THEORETICAL ASSUMPTIONS AND THE PRACTICAL VALUE TO BE OBSERVED. THIS PROCEDURE PERMITS ONE TO EVALUATE, UNAMBIGUOUSLY, THE MAXIMUM QUANTITIES TO BE MANIPULATED IN THE CASE OF ANY RADIONUCLIDE, CHEMICAL FORM, PHYSICAL STATE, DEGREE OF CONTAINMENT, TYPE OF OPERATION, KIND OF FACILITY AND TECHNICAL SKILL OF THE OPERATORS. THUS THIS PROCEDURE POSSESSES GREAT FLEXIBILITY AND PERMITS ONE TO DETERMINE THESE QUANTITIES ON A SCALE EXTENDING OVER A RANGE OF 10 TO THE 14.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + ACCIDENT, EXPOSURE + ADMINISTRATIVE CONTROLS AND PRACTICES +
TRANSPORTATION AND HANDLING

15-09875 NENTWIG G

SOME REMARKS ABOUT SCINTILLATION COUNTERS WITH THIN PLASTIC SCINTILLATORS FOR BETA DOSIMETRY

WALTER ULBRICHT PLANT, VEB, DRESDEN

ORNL-TR-1093 +. 7 PAGES, TRANSLATED FROM KERNENERGIE, 8, PP. 481-4 (AUGUST 1965), JCL, \$1.10 FS, \$0.80 MF

BY USING A PLASTIC SCINTILLATOR, 10 MC/SQ CM, IN COMBINATION WITH A DISCRIMINATOR ENERGY OF ABOUT 50 KEV, THE MEASUREMENT OF THE BETA DOSE OR DOSE RATE IS ALMOST INDEPENDENT OF THE MAXIMUM ENERGY OF CONVENTIONAL BETA RADIATORS IN THE RANGE FROM ABOUT 150 KEV TO AT LEAST 2.5 MEV.

*COUNTER + *DOSE + DOSIMETRY, GENERAL + GROSS BETA + INSTRUMENTATION, RADIATION MONITORING

15-09876 SANDERS M

DIAGNOSTIC AIR MONITORING AND RELATED SAMPLING EQUIPMENT FOR RADIOACTIVE AND TOXIC PARTICULATES

Y-12 PLANT, UNION CARBIDE CORPORATION, OAK RIDGE

Y-KB-64 + CONF-650963-1 +. 15 PAGES, SEPTEMBER 15, 1965, HEALTH PHYSICS SOCIETY, FALL SYMPOSIUM, GAITHERSBURG, MD., CFSTI, \$1.00 CY, \$0.50 MN

THIS PAPER DISCUSSES THE GENERAL AIR-MONITORING PROGRAM AND THE DIAGNOSTIC AIR-MONITORING PROGRAM USED AT THE Y-12 PLANT.

*MONITOR, RADIATION, AIR + COMPUTER PROGRAM + INSTRUMENTATION, RADIATION MONITORING +
RADIATION SAFETY AND CONTROL + SAMPLING

15-10076 FRANK M + HERFORTH L

THERMOLUMINESCENCE DOSIMETRY WITH CAF2/MN

TECHNICAL UNIVERSITY OF DRESDEN, INSTITUTE FOR THE APPLICATION OF RADIOACTIVE ISOTOPES

UCRL-TRANS-1208(L) +. 14 PAGES, MARCH 1965, TRANSLATED FROM KERNENERGIE, 5, PAGES 173-176 (1962), JCL, \$1.60 FS, \$0.80 MF

DOSES OF BETA AND GAMMA RADIATION IN THE RANGE FROM 1 TO 10,000 RADS OR ROENTGENS CAN BE MEASURED BY THE THERMAL LIGHT EMISSION OF CAF2/MN. THIS PHOSPHOR SHOWS DOSE PROPORTIONALITY

ACCESSION NUMBER 15-09726 TO 15-10076

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-10076 *CONTINUED*
AND SUFFICIENT STORAGE CAPACITY FOR PRACTICAL USE. A SIMPLE DOSIMETER-EVALUATION APPARATUS IS DESCRIBED. THE PROCESS FOR MAKING THE PHOSPHOR IS GIVEN.

*DOSE MEASUREMENT, EXTERNAL + *DOSIMETRY, THERMOLUMINESCENCE + INSTRUMENTATION, RADIATION MONITORING

15-10084 HERFORTH L + FRANK M
THERMOLUMINESCENCE DOSIMETRY WITH LIF FOR RADIATION THERAPY AND PROTECTIVE RADIATION MONITORING
DRESDEN TECHNICAL UNIVERSITY, INSTITUTE FOR THE APPLICATION OF RADIOACTIVE ISOTOPES, GERMANY
UCRL-TRANS-1207(1) +. 9 PAGES, TRANSLATED FROM CZECHOSLOVAK JOURNAL OF PHYSICS, 13B, PAGES 219-221
(1963); JCL, \$1.10 FS, \$0.80 MN

THE PREPARATION OF LIF FOR THERMOLUMINESCENT DOSIMETRY IS REPORTED. THE DOSIMETRIC PROPERTIES OF LIF ARE GIVEN, AND THE FUTURE APPLICATION OF THIS PROCEDURE IS DISCUSSED.

*DOSE MEASUREMENT, EXTERNAL + *DOSIMETRY, THERMOLUMINESCENCE + MONITOR, RADIATION, PERSONNEL

15-10092 ABEE HH + DAVIS DM
RADIATION DOSE RECEIVED BY PASSENGERS AND CREW ON PLANES CARRYING RADIOISOTOPE SHIPMENTS
OAK RIDGE NATIONAL LABORATORY
11 PAGES, 4 FIGURES, 2 TABLES, INTERNATIONAL SYMPOSIUM ON THE DOSIMETRY OF IRRADIATIONS FROM EXTERNAL SOURCES, PARIS, FRANCE, NOVEMBER 23-27, 1964, SOURCE

IF ADVANTAGE COULD BE TAKEN OF LOAD-SPACING DISTANCE BETWEEN PACKAGES AS WELL AS THE CURRENT SEPARATION DISTANCE BETWEEN PASSENGERS OR CREW AND THE NEAREST PACKAGE, SOME PLANES WHICH NOW CANNOT CARRY THE MAXIMUM NUMBER OF UNITS ACCORDING TO CURRENT REGULATIONS COULD DO SO. IN ADDITION, MOST OF THE MODERN AIRCRAFT COULD CARRY MORE THAN THE SPECIFIED MAXIMUM OF FORTY UNITS WITHOUT EXPOSING PASSENGERS OR CREW TO DOSE RATES ABOVE THOSE INTENDED BY THE CURRENT REGULATIONS. A NEW TABLE OF SEPARATION DISTANCES COULD BE DEVELOPED WHICH NOT ONLY SPECIFIES THE DISTANCE BETWEEN THE PASSENGERS OR CREW AND THE NEAREST PACKAGE BUT ALSO SPECIFIES A MINIMUM SEPARATION DISTANCE BETWEEN PACKAGES OR GROUPS OF PACKAGES.

*AIRCRAFT + *DOSE MEASUREMENT, EXTERNAL + GCBALT + DOSE CALCULATION, EXTERNAL

15-10100 ROYETT RH + CLARK TG + FISH BR
BETA-DOSIMETRY APPLICATIONS FOR DISCRETE SOURCES. I. PRELIMINARY REVIEW
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-802 +. 21 PAGES, 8 FIGURES, 2 TABLES, 16 REFERENCES, FEBRUARY 26, 1964

A PRELIMINARY STUDY OF THE PROBLEM OF MEASURING THE BETA DOSE FROM DISCRETE RADIOACTIVE SOURCES WAS APPROACHED WITH SEVERAL PROPOSED METHODS OF EXPERIMENTAL DOSIMETRY. DATA FROM THE MEASUREMENTS ON ONE DISCRETE BETA SOURCE INDICATES THE VALIDITY OF THEORETICAL CALCULATIONS AND OFFERS SOME RELIABILITY OF CHOOSING A DOSIMETRY METHOD BASED ON PRESENT KNOWLEDGE.

*DOSE MEASUREMENT, EXTERNAL + *DOSIMETRY, GENERAL + *GROSS BETA + ANALYTICAL TECHNIQUE, CALIBRATION + DOSE CALCULATION, EXTERNAL + DOSIMETRY, THERMOLUMINESCENCE + ORNL (OAK RIDGE NATIONAL LABORATORY) + SOURCE, RADIATION + STRONTIUM + YTTRIUM

15-10109 REGULATIONS ON RADIATION SAFETY DURING GAMMA-RAY DEFECTOSCOPY
JPRS-33502 + TT-65-34076 +. 24 PAGES, TRANSLATED FROM DURZHAVEN VESTN, (95), PP. 1-7 (1965), CFSTI, \$1.00 CY, \$0.50 MN

THESE REGULATIONS ARE OBLIGATORY IN THE DESIGNING, OPERATING, AND USE OF LABORATORIES FOR GAMMA DEFECTOSCOPY, REGARDLESS OF THEIR PURPOSE, LOCATION, UTILIZED TYPE OF GAMMA DEFECTOSCOPE, ETC. THEY ARE OBLIGATORY IN THE DESIGNING, PRODUCTION, AND USE OF ALL TYPES OF GAMMA DEFECTOSCOPES IN BULGARIA.

*BULGARIA + *GAMMA + *INSTRUMENTATION, RADIATION MONITORING + *REGULATION, GENERAL

15-10134 AVAILABLE WHOLE-BODY COUNTING SERVICES
U. S. ATOMIC ENERGY COMMISSION, DIVISION OF OPERATIONAL SAFETY
HEALTH AND SAFETY INFORMATION BULLETIN NO. 233, 1 PAGE, MAY 9, 1966

AEC CONTRACTORS MAY USE ON-SITE WHOLE-BODY-COUNTING FACILITIES, USING TRAILER-MOUNTED EQUIPMENT SUPPLIED BY AEC FIELD OFFICES. THIS CAN TAKE THE PLACE OF THE ANALYSIS OF EXCRETA IN UNIQUE OR TROUBLESOME PROBLEMS, OR FOR DETERMINING POSTINCIDENT BODY BURDEN.

*INSTRUMENTATION, RADIATION MONITORING + *MAXIMUM PERMISSIBLE BODY BURDEN + INGESTION

15-10153 ASPINALL KJ
CRITICALITY DETECTION AND ALARM SYSTEMS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HEALTH AND SAFETY BRANCH
5 PAGES, 1 FIGURE, 5 REFERENCES, NUCLEAR ENGINEERING, 11(110), PP. 184-188 (MARCH, 1966)

A SET OF DESIGN SPECIFICATIONS FOR CRITICALITY DETECTION AND ALARM SYSTEMS IS DEVELOPED. TOPICS INCLUDE THE EFFECT OF EVACUATION ON DOSES RECEIVED, DETECTION THRESHOLDS, RELIABILITY, ALARM SOUND, AND EVACUATION AREAS.

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-10153 *CONTINUED*

*ACCIDENT, CRITICALITY + *DESIGN CRITERIA + *MONITOR, RADIATION, EMERGENCY +
*RADIATION SAFETY AND CONTROL + *RADIOCHEMICAL PLANT SAFETY + MONITOR, RADIATION, PERSONNEL +
UNITED KINGDOM

15-10252 WHITEHOUSE WJ + DYSON ED

THE ADVANCED COURSE IN THE PRINCIPLES OF RADIATION PROTECTION. PART I

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AERE-R-5084 +. 23 PAGES, 6 TABLES, 1 FIGURE, REFERENCES, NOVEMBER, 1965, BIS, \$0.70, HMSO

NINE ADVANCED COURSES IN THE PRINCIPLES OF RADIATION PROTECTION WERE HELD AT HARWELL FROM 1959 TO 1964. EACH COURSE LASTED ABOUT THREE MONTHS. THIS REPORT REVIEWS THE BACKGROUND, HISTORY, AND INITIAL ORGANIZATION OF THE COURSES, AND SUMMARIZES THEIR SUBJECT MATTER, INCLUDING LECTURES, PRACTICAL WORK, VISITS, AND FILMS. THE REASONS FOR ARRANGING AND PRESENTING THE COURSES, IN THE WAY THAT WAS ADOPTED, ARE DISCUSSED.

*HARWELL (UK) + *RADIATION PROTECTION, ORGANIZATION + *SAFETY PRINCIPLES AND PHILOSOPHY

15-10253 BRASACK G + KRAUS W

PROFESSIONAL RADIATION PROTECTION IN THE GERMAN DEMOCRATIC REPUBLIC, 1964

STAATLICHE ZENTRALE FUER STRAHLENSCHUTZ, BERLIN, EAST GERMANY

SZS-8(1965) +. 20 PAGES, AUGUST, 1965, IN GERMAN, DEP. MN.

THE 1964 RESULTS ARE REPORTED FOR PERSONNEL DOSIMETRY OF THE 16,762 PEOPLE UNDER THE JURISDICTION OF THE GERMAN STATE RADIATION PROTECTION OFFICES. A SURVEY ON MONTHLY OVEREXPOSURES (MORE THAN C.4 RAD) AS WELL AS ON THE DISTRIBUTION OF ANNUAL EXPOSURES IS GIVEN. THE RESULTS OF PERSONNEL DOSIMETRY IN 1963 AND 1964 ARE COMPARED. THE STATISTICAL TREATMENT OF THE ANNUAL EXPOSURES IS PERFORMED AS FOR 1963. SUGGESTIONS FOR IMPROVEMENTS IN RADIATION PROTECTION ARE GIVEN. THE TOTAL SITUATION OF OCCUPATIONAL EXPOSURES IN GERMANY IS ESTIMATED AS SATISFACTORY.

*DOSIMETRY, GENERAL + *GERMANY + *PERSONNEL EXPOSURE, RADIATION + *RADIATION PROTECTION, ORGANIZATION +
STATE PROGRAM + STATISTICAL CORRELATION

15-10475 COATES RL + HORTON NR

RSAC--A RADIOLOGICAL SAFETY ANALYSIS COMPUTER PROGRAM

PHILLIPS PETROLEUM COMPANY, IDAHO

IDO-17151 +. 208 PAGES, 3 TABLES, 7 REFERENCES, MAY 1966, CFSTI, \$6.00 CY, \$1.25 MN

AN IBM 7040 PROGRAM WHICH COMPUTES THE POTENTIAL RADIOLOGICAL DOSES RESULTING FROM A CONTINUOUS OR INSTANTANEOUS RELEASE OF FISSION PRODUCTS TO THE ATMOSPHERE. DEVELOPED AS PART OF LOFT AND GENERAL NUCLEAR SAFETY PROGRAMS TO PROVIDE A GENERALIZED COMPUTER PROGRAM FOR A COMPLETE PARAMETRIC INVESTIGATION OF RADIOLOGICAL HAZARDS. DOSES CONSIDERED ARE CLOUD GAMMA, DEPOSITION GAMMA, INGESTION, AND INHALATION, AND ARE BASED UPON THE RELEASE OF UP TO 200 ISOTOPES, THE RELATIVE ABUNDANCE OF EACH ISOTOPE BEING DEPENDENT UPON THE OPERATING HISTORY OF THE NUCLEAR REACTOR UNDER CONSIDERATION. INCLUDED ARE THE MATHEMATICAL MODELS, CONVERSION FACTORS, ASSUMPTIONS, FLOW CHARTS, PROGRAM LISTINGS, AND OTHER DATA PERTINENT TO THE OVERALL DEVELOPMENT OF THIS PROGRAM.

*COMPUTER PROGRAM + *DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL +
*FISSION PRODUCT RELEASE, GENERAL + SUTTON DIFFUSION FORMULA

15-11134 CAMBRAY RS + FISHER EM + BROOKS WL + HUGHES A + SPICER GS

RADIOACTIVE FALLOUT IN AIR AND RAIN - RESULTS TO THE MIDDLE OF 1965

UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AERE-R-4997 +. 42 PAGES, 6 FIGURES, 17 TABLES, 26 REFERENCES, NOVEMBER 1965, HMSO, BIS \$1.40 CY

SAMPLES OF ATMOSPHERIC DUST AND RAINWATER WERE COLLECTED FROM THE UNITED KINGDOM AND OVERSEAS. THE CONCENTRATIONS OF CS-137 AND SR-90 IN AIR AND RAIN OVER THE UNITED KINGDOM ARE, IN 1965, ABOUT ONE THIRD OF THOSE FOR 1964. THE AVERAGE DEPOSITION OF CS-137 AND SR-90 IN THE UNITED KINGDOM FOR THE FIRST SIX MONTHS OF 1965 IS ABOUT 40 PERCENT OF THAT FOR THE CORRESPONDING PERIOD OF 1964. THE LOW-YIELD CHINESE EXPLOSIONS OF OCTOBER 1964 AND MAY 1965 TEMPORARILY CONTRIBUTED ABOUT 3 PERCENT TO THE LONG-LIVING RADIATION EMITTERS. A COLLECTION OF TABULAR AND GRAPHICAL DATA.

*FALLOUT + AIR + ATMOSPHERIC CIRCULATION, GLOBAL + CERIUM + CESIUM + NUCLEAR EXPLOSION DEBRIS + PLUTONIUM +
RAINOUT + SAMPLING + STRONTIUM + SURVEY, RADIATION, ENVIRONMENTAL + UNITED KINGDOM

15-11298 EUROPE

EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH LABORATION, GENEVA, SWITZERLAND

NP-16226 +. 183 PAGES, 86 FIGURES, TABLES, PP. 148-154 OF EUROPEAN ORGANIZATION FOR NUCLEAR RESEARCH ANNUAL REPORT, 1965

REVIEWS ROUTINE SURVEYS, FILM BADGE PROGRAM, SHIELDING, ETC., ASSOCIATED WITH THE CERN PROTON SYNCHROTRON AND SYNCHRO-CYCLOTRON. A GATED OPERATION CONNECTED TO THE PS ACCELERATOR REDUCED THE BACKGROUND OF THE COUNTING EQUIPMENT. THE 600-MEV PROTON BEAM DOSIMETRY AND MOUSE EXPERIMENTS WERE BEGUN. THE GENERAL SAFETY GROUP STUDIED INFLAMMABLE GAS PROBLEM.

*ACCELERATOR + *RADIATION SAFETY AND CONTROL + HYDROGEN

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11306 FERRI E + MAGNO PJ + SETTER LR
RADIONUCLIDE ANALYSIS OF LARGE NUMBERS OF FOOD AND WATER SAMPLES
U. S. PUBLIC HEALTH SERVICE, DIVISION OF RADIOLOGICAL HEALTH
PHS PUBL 999-RH-17 +. 23 PAGES, 6 TABLES, 6 FIGURES, 8 REFERENCES, DECEMBER 1965, GPO, FREE

AS PART OF THE RESPONSIBILITIES OF THE DIVISION OF RADIOLOGICAL HEALTH FOR ENVIRONMENTAL SURVEILLANCE, LARGE NUMBERS OF SAMPLES ARE ANALYZED FOR GROSS AND SPECIFIC RADIOACTIVITY. THE PROCESSING OF FOOD AND WATER SAMPLES, AS CONDUCTED AT THE NORTHEASTERN RADIOLOGICAL HEALTH LABORATORY, IS DESCRIBED IN THIS REPORT. INCLUDED ARE MANPOWER AND EQUIPMENT REQUIREMENTS, AND TECHNICAL PROCEDURES FOR MEASUREMENTS OF APPROPRIATE RADIOACTIVITIES. PROCEDURES DESCRIBED INCLUDE TECHNIQUES FOR A SERIES OF RADIONUCLIDES, AS WELL AS CERTAIN STABLE ELEMENTS IN FOOD, AND FOR GROSS ALPHA AND BETA DETERMINATIONS, GAMMA SPECTRAL ANALYSES, AND RADIUM 226 AND STRONTIUM 90 IN WATER.

*ANALYTICAL TECHNIQUE, FOOD + *ANALYTICAL TECHNIQUE, WATER + *RADIOCHEMICAL ANALYSIS + BARIUM + CERIUM + CESIUM + GROSS ALPHA + GROSS BETA + GROSS GAMMA + IODINE + POTASSIUM + RADIUM + RUTHENIUM + STRONTIUM + YTTRIUM + ZINC + ZIRCONIUM

15-11307 DELAGUNA W
DISPOSAL OF RADIOACTIVE WASTES BY HYDRAULIC FRACTURING - PART II MECHANICS OF FRACTURE FORMATION AND DESIGN OF OBSERVATION AND MONITORING WELLS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
7 PAGES, 4 FIGURES, 1 REFERENCE, NUCLEAR ENGINEERING AND DESIGN 3 (1966) PP 432-438

ONE OF THE PROBLEMS ASSOCIATED WITH DISPOSAL BY HYDRAULIC FRACTURING CONCERNS METHODS OF MONITORING AT THE SURFACE FOR EVIDENCE OF FRACTURE ORIENTATION UNDERGROUND. MONITORING AND OBSERVATION WELLS HAD TO BE DESIGNED AND TESTED TO ENSURE THAT, AS FRACTURE AFTER FRACTURE WAS FILLED WITH WASTE, NO CHANGE IN THE FRACTURE PATTERN OR FAILURE IN THE PERMEABILITY OF THE COVER ROCK WOULD RESULT. PROTOTYPES OF TWO KINDS OF WELLS DESIGNED TO PROVIDE SUCH ASSURANCE HAVE BEEN TESTED WITH SUFFICIENT SUCCESS TO SHOW THAT THE BASIC DESIGNS ARE SOUND, ALTHOUGH CERTAIN IMPROVEMENTS WILL BE REQUIRED. IN PARTICULAR, A BETTER UNDERSTANDING OF THE COMPLEX ROCK MECHANICS OF THE OPERATION IS NEEDED TO MAKE BEST USE OF SEVERAL MONITORING TECHNIQUES AVAILABLE.

*GEOLOGICAL CONSIDERATION, GEOPHYSICAL + *WASTE DISPOSAL, HYDRAULIC FRACTURING + WASTE DISPOSAL, TERRESTRIAL

15-11319 ENVIRONMENTAL RADIATION
UNIVERSITY OF CALIFORNIA, LOS ANGELES
UCLA-12-576 +. 111 PAGES, 4 TABLES, PP 91-111 OF SEMIANNUAL PROGRESS REPORT FOR THE PERIOD ENDING DECEMBER 31, 1965, CFSTI \$4.00 CY, \$0.75 MN

SHORT PROGRESS SUMMARIES ARE GIVEN FOR VARIOUS PROJECTS IN THE UCLA PROGRAM IN ENVIRONMENTAL RADIATION. SUBJECTS INCLUDE ECOLOGICAL CONSIDERATIONS, BEHAVIOR OF RADIONUCLIDES IN THE SOIL, AND THE DETERMINATION OF RADIONUCLIDES IN ENVIRONMENTAL SAMPLES.

*ECOLOGICAL CONSIDERATION + *SOIL, NUCLIDE OCCURRENCE + ACTIVATION PRODUCT + ANALYTICAL TECHNIQUE, SOLID + BERYLLIUM + BIOLOGICAL CONCENTRATION, GENERAL + CESIUM + RADIATION EFFECT + RADIOCHEMICAL ANALYSIS + SOIL, RADIONUCLIDE MOVEMENT THROUGH + SPECTROMETRY, GAMMA

15-11340 GORBERG Z + ZARNOWICKI K
ESTIMATE OF FALL-OUT SAMPLING METHODS
INSTITUTE OF NUCLEAR RESEARCH, WARSAW-SWIERK
AEC-TR-6487 +. 2 PAGES, 2 FIGURES, 2 REFERENCES, NUKLEONIKA 10(1), PAGES 54-55, (1965), CFSTI \$3.00 CY, \$0.75 MN

AN EVALUATION WAS MADE OF WET AND DRY CONTAINERS FOR SAMPLING FALLOUT. THEY CONCLUDE THAT A LARGE DRY CONTAINER IS PREFERABLE BECAUSE IT CONSUMES LESS LABOR AND COLLECTS ON ITS LARGE SURFACE A MORE REPRESENTATIVE FALLOUT SAMPLE.

*SAMPLING + FALLOUT

15-11342 KARNIEWICZ W + LINIECKI J + KOSTERKIEWICZ A
CAESIUM-137 IN POPULATION OF LODZ (POLAND) IN 1963 AND 1964
INSTITUTE OF OCCUPATIONAL MEDICINE, LODZ
AEC-TR-6468 +. 15 PAGES, 10 FIGURES, 7 TABLES, 32 REFERENCES, NUKLEONIKA 10(1), PAGES 32-46, (1965), CFSTI \$3.00 CY, \$0.75 MN

THE WHOLE BODY COUNTER AT THE INSTITUTE OF OCCUPATIONAL MEDICINE IN LODZ IS DESCRIBED IN DETAIL. THE IN VIVO CALIBRATION FOR CS-137 AND FOR POTASSIUM WAS PERFORMED USING CS-132 AND K-42 AS WELL AS POTASSIUM CHLORIDE. DETAILS OF CALIBRATION PROCEDURE ARE GIVEN. CS-137 BODY LEVEL OF ADULT, PROFESSIONALLY NON-EXPOSED SUBJECTS OF BOTH SEXES, INHABITANTS OF LODZ WERE MEASURED FOUR TIMES. IN THE SPRING AND FALL OF 1963 AND 1964 THE CS-137- POTASSIUM RATIO WAS 133, 181, 178, AND 200 PC/G K RESPECTIVELY.

*CFSTIUM + *COUNTER, WHOLE BODY + *POPULATION EXPOSURE + FALLOUT + INSTRUMENTATION CALIBRATION + POLAND + POTASSIUM

15-11345 RADWAN M + GOLINCZAK H + STASIUR J + KRZYSIAK B
INDIRECT METHOD FOR DETERMINING FALL-OUT CONTAMINATION OF A REGION

ACCESSION NUMBER 15-11306 TO 15-11345

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11345 *CONTINUED*

MILITARY TECHNICAL ACADEMY, WARSAW

AEC-TR-6488 +. 7 PAGES, 1 FIGURE, 2 TABLES, 4 REFERENCES, NUKLEONIKA 10(1), PAGES 49-55, (1965), CFSTI \$3.00 CY, \$0.75 MN

AN ATTEMPT IS MADE TO ESTABLISH THE DEGREE OF RADIOCONTAMINATION OF AN AREA BY FALLOUT BY DETERMINING THE STRONTIUM-90 CONTENT OF DEER ANTLERS. THE DATA SHOW AN INCREASE IN STRONTIUM-90 ACTIVITY IN TIME, WHICH AGREES WITH THE PREDICTED 13 YEAR SPAN OF INCREASING FALLOUT FROM NUCLEAR DETONATIONS.

*BIOLOGICAL CONCENTRATION, ANIMAL + ANALYTICAL TECHNIQUE, SOLID + FALLOUT + STRONTIUM

15-11353 MARTIN WE + TURNER FB

TRANSFER OF SR-89 FROM PLANTS TO RABBITS IN A FALLOUT FIELD

UNIVERSITY OF CALIFORNIA, LABORATORY OF NUCLEAR MEDICINE AND RADIATION BIOLOGY, LOS ANGELES, CALIFORNIA 11 PAGES, 2 FIGURES, 3 TABLES, 27 REFERENCES, HEALTH PHYSICS 12(5), PAGES 621-631, MAY 1966

THE OBJECTIVE OF THIS STUDY, WHICH WAS CONDUCTED IN THE FALLOUT FIELD PRODUCED ON 6 JULY 1962 BY PROJECT SEDAN, A NUCLEAR CRATERING EXPERIMENT AT THE NEVADA TEST SITE, WAS TO FORMULATE A MATHEMATICAL MODEL TO REPRESENT THE RELATIONSHIP BETWEEN GAMMA DOSE RATES AND INITIAL SR-89 CONCENTRATIONS ON FALLOUT-CONTAMINATED PLANTS AND THE TIME-SPECIFIC RELATIONSHIP BETWEEN CONCENTRATIONS ON PLANTS AND IN THE BONE ASH OF RABBITS COLLECTED AT THE SAME TIMES AND LOCATIONS IN THE FALLOUT FIELD. AN EXPONENTIAL MODEL WAS TESTED AND FOUND TO PROVIDE A REASONABLE REPRESENTATION OF THE TIME-SPECIFIC RELATIONSHIP BETWEEN SR-89 CONCENTRATIONS ON FALLOUT-CONTAMINATED PLANTS AND IN RABBIT BONE ASH. USE OF THE SAME MODEL TO ESTIMATE THE INFINITY DOSES DELIVERED BY SR-89 TO RABBIT BONE INDICATED A RANGE FROM ABOUT 0.1 TO 9.5 RADS AND AN AVERAGE OF 1.12 PLUS OR MINUS 0.36 RAD IN AREAS 12-110 MILES FROM GROUND ZERO. ESTIMATES OF INTEGRATED DOSES INDICATED THAT 93 PERCENT OF THE INFINITY DOSE WAS DELIVERED DURING THE FIRST 120 DAYS AFTER THE DETONATION.

*BIOLOGICAL CONCENTRATION, ANIMAL + *DOSE CALCULATION, INTERNAL + *DOSE MEASUREMENT, EXTERNAL + *PLOWSHARE PROGRAM + BIOLOGICAL CONCENTRATION, VEGETATION + DOSE + DOSE CALCULATION, EXTERNAL + FALLOUT + STRONTIUM

15-11354 NISHITA H + HAUG RM + STEEN AJ

SOLUBILITY AND PLANT AVAILABILITY OF RADIONUCLIDES IN REACTOR ACTIVATED SOILS

UNIVERSITY OF CALIFORNIA, LABORATORY OF NUCLEAR MEDICINE AND RADIATION BIOLOGY, LOS ANGELES, CALIFORNIA 6 PAGES, 3 TABLES, 1 FIGURE, 2 REFERENCES, HEALTH PHYSICS 12(5), PAGES 615-620, MAY 1966

THE SOLUBILITIES OF RADIONUCLIDES FORMED IN REACTOR-ACTIVATED SOILS WERE DETERMINED BY EQUILIBRIUM BATCH AND LEACHING METHODS, AND THE ECOLOGICAL IMPLICATIONS WERE DETERMINED BY A MODIFIED NEUBAUER TECHNIQUE. THE GAMMA ACTIVITY OF THE EQUILIBRIUM EXTRACTS OF ACTIVATED SOILS VARIED FROM 0.17 TO 20.22, 0.36 TO 25.09 AND 0.20 TO 28.76 PERCENT OF TOTAL ACTIVITY IN DEIONIZED H₂O, 0.1 N HCl AND 1 N NH₄AC, RESPECTIVELY, ABOUT 22 HR AFTER IRRADIATION. IN EVERY INSTANCE, THE PERCENTAGE OF LEACHABLE BETA ACTIVITY WAS GREATER THAN THAT OF THE LEACHABLE GAMMA ACTIVITY OF THE CORRESPONDING SOIL. THE DOMINANT GAMMA EMITTER IN THE PLANTS WAS RB-86, ALTHOUGH SC-46 WAS THE DOMINANT RADIO-NUCLIDE IN THE SOIL AT THE TIME OF HARVEST.

*ACTIVATION PRODUCT + *DESORPTION + *SOIL, NUCLIDE OCCURRENCE + ECOLOGICAL CONSIDERATION + GROSS BETA + GROSS GAMMA + MINERAL EXCHANGE + RUBIDIUM + SCANDIUM

15-11355 SHLEIEN B + GAETA NA + FRIEND AG

DETERMINATION OF PARTICLE SIZE CHARACTERISTICS OF OLD AND FRESH AIRBORNE FALLOUT BY GRADED FILTRATION DIVISION OF RADIOLOGICAL HEALTH, PUBLIC HEALTH SERVICE, WINCHESTER, MASSACHUSETTS

7 PAGES, 3 TABLES, 2 FIGURES, 12 REFERENCES, HEALTH PHYSICS 12(5), PAGES 633-639, MAY 1966

BY USE OF A COLLECTION SYSTEM CONSISTING OF THREE GRADED FILTERS PLACED IN SERIES, A STUDY WAS CONDUCTED DURING THE PAST YEAR ON THE PARTICLE-SIZE CHARACTERISTICS OF AIR-BORNE FALLOUT. EITHER GAMMA SPECTROMETRY OR RADIOCHEMISTRY WAS USED FOR QUANTITATIVE ESTIMATIONS OF FISSION PRODUCTS. DURING THE LATTER PART OF OCTOBER AND THROUGHOUT NOVEMBER 1964, A SECOND SERIES OF COLLECTIONS WAS MADE AND INCLUDED FRESH FISSION-PRODUCT MATERIAL PRESUMABLY RESULTING FROM THE ATMOSPHERIC NUCLEAR DETONATION IN MAINLAND CHINA. DIFFERENCES IN THE PARTICLE-SIZE DISTRIBUTION OF MATERIAL ON EACH FILTER WERE DETERMINED BY OPTICAL MICROSCOPY. FOR OLDER DEBRIS, AT LEAST 88 PERCENT OF THE TOTAL ACTIVITY WAS ASSOCIATED WITH PARTICLES HAVING DIAMETERS OF LESS THAN APPROXIMATELY 1.75 MICRONS. IN FRESH FALLOUT, CERTAIN RADIONUCLIDES WERE INITIALLY ASSOCIATED WITH LARGER PARTICLES. WITH TIME, THIS DISTRIBUTION GRADUALLY DECREASED DUE TO SETTLING OUT OF LARGER ACTIVE PARTICLES. DATA ARE PRESENTED ON THE DEGREE OF RADIONUCLIDE FRACTIONATION IN EACH SIZE GROUP.

*FALLOUT + *PARTICLE SIZE DISTRIBUTION + PARTICLE, RADIOACTIVE + RADIOCHEMICAL ANALYSIS

15-11358 BORTOLI M + GAGLIONE P + MALVICINI A

SOME DATA AND COMMENTS ON SODIUM-22 IN FOOD CHAINS

EUROPEAN ATOMIC ENERGY COMMUNITY, ISPRA, ITALY

7 PAGES, 5 FIGURES, 3 TABLES, 5 REFERENCES, HEALTH PHYSICS 12(3), PAGES 353-359, MARCH 1966

MEASUREMENTS OF NA-22 CONCENTRATION IN FALLOUT, HERBAGE, AND MILK SAMPLES ARE DESCRIBED, TOGETHER WITH THE METHOD EMPLOYED, WHICH CONSISTS OF GAMMA SPECTROMETRY IN COINCIDENCE WITH THE SUM PULSES OF THE GAMMA RAYS IN CASCADE. FROM THE DATA OBTAINED, THE RATIO OF NA-22 TO CS-137 IN FALLOUT APPEARS TO BE LESS THAN THAT IN MILK, WHICH IS PROBABLY DUE TO GREATER UPTAKE FROM SOIL OF THE FORMER ISOTOPE THAN OF THE LATTER. THERE ARE DIFFICULTIES IN CALCULATING THE ENHANCEMENT FACTORS, BUT THEY MAY BE ESTIMATED TO BE ABOUT 4 IN THE

ACCESSION NUMBER 15-11345 TO 15-11358

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11358 *CONTINUED*
HERBAGE-MILK, AND 10 OR MORE IN THE COMPLETE STEP, FALLOUT-MILK.

*ECOLOGICAL CONSIDERATION + *FALLOUT + *SODIUM + BIOLOGICAL CONCENTRATION, ANIMAL FEED + BIOLOGICAL CONCENTRATION, FOOD + BIOLOGICAL CONCENTRATION, GENERAL + BIOLOGICAL CONCENTRATION, MILK + BIOLOGICAL CONCENTRATION, VEGETATION + CESIUM + SPECTROMETRY, GAMMA

15-11359 BECK HL
ENVIRONMENTAL GAMMA RADIATION FROM DEPOSITED FISSION PRODUCTS, 1960-1964
HEALTH AND SAFETY LABORATORY, USAEC, NEW YORK
10 PAGES, 2 TABLES, 4 FIGURES, 29 REFERENCES, HEALTH PHYSICS 12(3), PAGES 313-322, MARCH 1966

DOSE RATES IN AIR FROM EACH IMPORTANT DEPOSITED FISSION PRODUCT WERE CALCULATED FOR THE PERIOD 1 JULY 1960 TO 1 JANUARY 1965 FROM MEASURED DEPOSITION IN RAINFALL AT WESTWOOD, N.J. A REALISTIC MODEL WAS ADOPTED TO ACCOUNT FOR THE DISTRIBUTION WITH DEPTH OF THE RADIONUCLIDES IN THE SOIL. THESE CALCULATED DOSE RATES ARE CONSISTENT WITH IN SITU GAMMA-SPECTROMETRIC MEASUREMENTS, INDICATING THAT A DETAILED AND REASONABLY ACCURATE HISTORY HAS BEEN OBTAINED OF THE EFFECT OF FALLOUT ON EXTERNAL GAMMA RADIATION LEVELS.

*DOSE CALCULATION, EXTERNAL + *RAINOUT + DOSE MEASUREMENT, EXTERNAL + FALLOUT + POPULATION EXPOSURE + SOIL, NUCLIDE OCCURRENCE

15-11360 ETTINGER HJ
IODINE SAMPLING WITH SILVER NITRATE-IMPREGNATED FILTER PAPER
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO
8 PAGES, 4 FIGURES, 6 TABLES, 18 REFERENCES, HEALTH PHYSICS 12(3), PAGES 305-311, MARCH 1966

THE USE OF SILVER NITRATE-IMPREGNATED RADIOIODINE FILTERS WAS EVALUATED UNDER LABORATORY AND FIELD CONDITIONS. PRELIMINARY LABORATORY TESTS INDICATED EFFICIENCIES OF 91-96 PERCENT. WHEN SAMPLING A STACK EFFLUENT CONTAINING A VARIETY OF REACTOR WASTE PRODUCTS, EFFICIENCIES OF LESS THAN 8 PERCENT WERE OBTAINED. SAMPLING EFFLUENT GASES FROM HOT CELLS WHERE REACTOR FUEL ELEMENTS ARE HANDLED RESULTED IN A MEDIAN EFFICIENCY OF 20 PERCENT, WITH EFFICIENCIES AS HIGH AS 96-100 PERCENT UNDER CERTAIN OPERATING CONDITIONS. TEST RESULTS SHOW THAT FILTERS IMPREGNATED WITH SILVER NITRATE ARE NOT A RELIABLE METHOD FOR MONITORING THE RELEASE OF IODINE TO THE ATMOSPHERE.

*IODINE + *SAMPLING + FILTRATION

15-11409 JANKOWSKI FJ
EFFECT OF LOW-INTENSITY RADIATION ON MAN
RUTGERS UNIVERSITY
3 PAGES, 1 FIGURE, 1 TABLE, NUCLEAR SAFETY 7(1), PAGES 12-14, (FALL 1965)

THE RATIO OF RADIATION-DOSE-RATE THRESHOLD FOR SOMATIC DAMAGE TO THE NORMAL BACKGROUND DOSE RATE IS OF THE ORDER OF A FEW HUNDRED (100 TO 500). THIS IS IN THE RANGE OF THE RATIO OF HARMFUL CONCENTRATION OF SEVERAL CHEMICALS TO THE AMOUNT NEEDED OR BELIEVED TO BE NEEDED FOR HEALTH. THIS OBSERVATION RAISES THE QUESTION AS TO WHETHER ALL RADIATION IS HARMFUL, A QUESTION WHICH HAS BEEN RAISED BEFORE AND WHICH IS UNDER INVESTIGATION. IT ALSO SUGGESTS FURTHER EXPERIMENTS AT LOW OR VERY LOW (BELOW BACKGROUND) DOSE RATES.

*DOSE + *PERSONNEL EXPOSURE, RADIATION + *RADIATION EFFECT + RADIATION DAMAGE + RADIATION IN PERSPECTIVE + RADIATION, PUBLIC EDUCATION/ACCEPTANCE

15-11421 RYAN JT + JOHNSON T
RADIOLOGICAL RECOVERY REQUIREMENTS, STRUCTURES, AND OPERATIONS RESEARCH. VOLUME II, DEVELOPMENT OF ANALYTICAL, COMPUTER, AND SYSTEMS MODELS IN SUPPORT OF DECONTAMINATION ANALYSES. FINAL REPORT U. S. NAVAL RADIOLOGICAL DEFENSE LABORATORY
RTI-R-OU-214 (VOL. III) +. 228 PAGES, JUNE 6, 1966, SOURCE

OTHER VOLUMES CONTAIN SUMMARY AND COST/EFFECTIVENESS DATA FOR DECONTAMINATING TWO REAL CITIES. THE REPORT PRESENTS MODELS FOR COMPUTING DOSE INTENSITY AT A SPECIFIC LOCATION INSIDE A BUILDING FROM BOMB FALLOUT ON ADJACENT BUILDINGS, ROOFS, AND STREETS. ALSO, A STUDY OF CODING THE EFFORT-VS-EFFECTIVENESS DECISION FOR A COMPUTER PROGRAM WAS MADE.

*DECONTAMINATION + *DESIGN STUDY + *FALLOUT + INCIDENT, ACTUAL, RECOVERY FROM

15-11470 GIBSON JA + BURT AK
A METHOD FOR CONTINUOUS MEASUREMENT OF TRITIATED WATER IN AIR
ATOMIC ENERGY RESEARCH ESTABLISHMENT, HARWELL, ENGLAND
AERE-R-4967 +. 10 PAGES, JUNE 1965, UKAEA

AN INSTRUMENT WAS DEVELOPED FOR CONTINUOUSLY MEASURING TRITIUM (HTO) IN AIR IN THE VICINITY OF A HEAVY-WATER-MODERATED REACTOR. WATER IS CONDENSED CONTINUOUSLY FROM THE AIR AT THE RATE OF 10 G/HR, AND THE TRITIUM ACTIVITY IS MEASURED IN A FLOW CELL FILLED WITH ANTHRACENE CRYSTALS. THE METHOD WAS DEVELOPED TO IMPROVE THE SENSITIVITY OF DETECTION FROM 2.5 PC/CC FOR AN ION CHAMBER SYSTEM TO ENABLE THE CHRONIC LEVEL OF 0.4 PC/CC (0.08 OF THE MPC FOR AIR) TO BE CONTINUOUSLY MEASURED. THE RANGE OF THE INSTRUMENT, USING A LOGARITHMIC RATEMETER, IS FROM THE BACKGROUND SENSITIVITY OF C.1 PC/CC TO 1000 MPC. THE INSTRUMENT CAN BE OPERATED IN A HIGH GAMMA-RAY BACKGROUND AND DOES NOT DETECT RADIOACTIVE GASES SUCH AS AR-41. CONTAMINATION OF THE CELL IS RAPIDLY REMOVED AFTER A LARGE RELEASE OF TRITIUM.

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11470 *CONTINUED*

*INSTRUMENTATION, AIR SAMPLING + *TRITIUM + COUNTER + MONITOR, RADIATION, AIR +
MONITOR, RADIATION, SAMPLING + WATER, GENERAL

15-11471 TURCK B

DETECTION OF HARD BETA RADIATION IN WATER USING THE CHERENKOV EFFECT
COMMISSARIAT A L'ENERGIE ATOMIQUE, CENTRE ETUDES NUCLEAIRES, SACLAY
CEA-R-2915 +. 70 PAGES, 54 FIGURES, 1966, DEP. MN, IN FRENCH

THE LIGHT EMITTED FROM A LIQUID DURING THE PASSAGE OF A PARTICLE OF SUFFICIENTLY HIGH ENERGY CAN BE USED TO DETERMINE THE CONTAMINATION OF WATER BY BETA EMITTERS. THE DETECTOR BASED ON THIS PRINCIPLE REQUIRES NO SPECIAL TREATMENT OF THE WATER. THE SYSTEM EMPLOYING THE DETECTOR IS CAPABLE OF DETECTING A CONTAMINATION OF 8 TIMES 10(MINUS 8TH) MICROCURIES/CC OF SR-90 IN WATER. THE APPARATUS PRESENTS THE DOUBLE ADVANTAGE OF HAVING A HIGH SENSITIVITY AND OF BEING EASY TO USE. THE CHARACTERISTICS MAKE IT ADAPTABLE TO THE CONTINUOUS MONITORING OF WATER.

*MONITOR, RADIATION, ENVIRONMENTAL + *MONITOR, RADIATION, LIQUID + BETA EMITTER + MEASUREMENT, REACTIVITY

15-11476 HOUNAM RF

AN APPLICATION OF THE LOG-NORMAL DISTRIBUTION TO SOME AIR SAMPLING RESULTS AND RECOMMENDATIONS ON THE INTERPRETATION OF AIR SAMPLING DATA
ATOMIC ENERGY RESEARCH ESTABLISHMENT, HARWELL, ENGLAND
AERE-M-1469(REV.)+. 21 PAGES, 12 FIGURES, 9 REFERENCES, MARCH 1965, BIS \$0.70

THREE RECENT SERIES OF AIR SAMPLING RESULTS WERE SEPARATELY ANALYSED AND SHOWN TO CONFORM APPROXIMATELY TO A LOG-NORMAL DISTRIBUTION. THIS FINDING IS FOLLOWED BY A SUGGESTION OF HOW THE LOG-NORMAL DISTRIBUTION MAY BE APPLIED TO A SERIES OF CONFORMING AIR SAMPLING RESULTS TO ESTIMATE THE HAZARD TO INDIVIDUALS EXPOSED TO THE SAME ENVIRONMENT.

*AIR + *SAMPLING + CONTAMINATION + DOSE CALCULATION, EXTERNAL + HAZARDS ANALYSIS + POPULATION EXPOSURE

15-11477 NEWTON D

A CASE OF ACCIDENTAL INHALATION OF ACTINIUM-227
ATOMIC ENERGY RESEARCH ESTABLISHMENT, HARWELL, ENGLAND
AERE-R-4955 +. 23 PAGES, 2 TABLES, 5 FIGURES, 13 REFERENCES, JUNE 1965, UKAEA

THE RETENTION OF AC-227 AFTER ACCIDENTAL INHALATION WAS STUDIED FOR MORE THAN 800 DAYS. WHOLE-BODY MEASUREMENTS (GAMMA SPECTROMETRY) DURING THIS PERIOD SHOWED THAT THE ACTINIUM WAS LARGELY CONFINED TO THE CHEST, AND IT WAS CONCLUDED THAT THE BIOLOGICAL HALF-LIFE FOR CLEARANCE FROM THE THORAX IS AT LEAST 10 YEARS.

*BIOLOGICAL CONCENTRATION, MAN + *INHALATION + DOSE CALCULATION, INTERNAL + SPECTROMETRY, GAMMA

15-11480 LEAKE JW

CALIBRATION OF THE NEUTRON SURVEY PROBE 95/0054
ATOMIC ENERGY RESEARCH ESTABLISHMENT, HARWELL, ENGLAND
AERE-M-1564 +. 11 PAGES, 3 FIGURES, 1 TABLE, 4 REFERENCES, JULY 1965, BIS, \$0.50

THE NEUTRON ENERGY RESPONSE OF THE SURVEY PROBE 95/0054-1/6 WAS MEASURED OVER A RANGE OF ENERGIES FROM THERMAL TO 15 MEV. THE RESPONSE WAS SUBSTANTIALLY CONSTANT FROM THERMAL TO 5 MEV, GIVING A NEUTRON SENSITIVITY OF 0.6 (PLUS OR MINUS 60 PERCENT) COUNT PER SEC PER NEUTRON PER SQ. CM. OVER THIS REGION.

*INSTRUMENTATION CALIBRATION + INSTRUMENTATION, NUCLEAR + INSTRUMENTATION, RADIATION MONITORING + NEUTRON + SOURCE, NEUTRON

15-11481 ROTHWELL E + WASSELL LL

PRELIMINARY OBSERVATIONS OF THE RELEASE OF TRITIUM FROM IRRADIATED BERYLLIA
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL, ENGLAND
AERE-R-4691 +. 12 PAGES, 3 FIGURES, DECEMBER 1964, UKAEA

POSTIRRADIATION ANNEALING EXPERIMENTS ARE REPORTED FOR NEUTRON-IRRADIATED BERYLLIA COMPACTS AND FOR POWDER OBTAINED FROM AN IRRADIATED COMPACT. RELEASE RATES WERE MEASURED IN THE TEMPERATURE RANGE 200 TO 1650 C. AN INITIAL BURST OF TRITIUM WAS OBSERVED ON ATTAINING TEMPERATURE IN EACH CASE, AND PROLONGED ANNEALING WAS NECESSARY AT MOST TEMPERATURES BEFORE TRUE BULK DIFFUSION RELEASE CONDITIONS WERE ESTABLISHED.

*BERYLLIUM + *TRITIUM + ACTIVATION + DIFFUSION COEFFICIENT

15-11482 EAKINS JD + GOMM PJ

THE DETERMINATION OF PHOSPHORUS-32 IN URINE AND THE EVALUATION OF THE FINDINGS FOR THE ASSESSMENT OF INTERNAL CONTAMINATION
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL, ENGLAND
AERE-R-4860 + AHSB(RP)-R-44 +. 23 PAGES, 8 TABLES, 2 FIGURES, 22 REFERENCES, MARCH 1965, UKAEA

FOR THE RADIOLOGICAL PROTECTION OF PERSONS WORKING WITH COMPOUNDS OF P-32, IT IS DESIRABLE TO MAKE ROUTINE MEASUREMENTS OF THE LEVEL THEIR INTERNAL CONTAMINATION. THE MOST PRECISE METHOD IS BY DIRECT MEASUREMENT OF BREMSSTRAHLUNG EMITTED FROM THE PERSON, USING WHOLE-BODY

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11482 *CONTINUED*

MONITORING EQUIPMENT. AN ALTERNATIVE IS TO DETERMINE THE AMOUNT OF P-32 IN URINE TO ESTIMATE THE BODY CONTENT. AFTER INTAKE OF P-32 AS INORGANIC PHOSPHATE, THE CRITICAL ORGAN IS BONE. HOWEVER, IN THE CASE OF THE ORGANIC COMPOUND DI-ISOPROPYL-FLUOROPHOSPHONATE THE CRITICAL ORGAN IS THE TOTAL BODY. A METHOD FOR DETERMINING TOTAL P-32 BY DIRECT BETA-COUNTING OF URINE IS DESCRIBED, TOGETHER WITH MORE-SENSITIVE RADIOCHEMICAL PROCEDURES FOR TOTAL P-32 AND FOR P-32 AS INORGANIC PHOSPHATE.

*ANALYTICAL TECHNIQUE, URINE + *BIOLOGICAL CONCENTRATION, MAN + *PHOSPHORUS + *RADIOCHEMICAL ANALYSIS + DOSE CALCULATION, INTERNAL + INGESTION + MAXIMUM PERMISSIBLE BODY BURDEN + MAXIMUM PERMISSIBLE DOSE (MPD) + PHOSPHATE

15-11521 HANDLEY TP

RELEASE OF TRITIUM FROM TRITIUM-LABELED LUMINOUS PAINTS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

ORNL-TM-1478 +. 11 PAGES, 3 FIGURES, 6 TABLES, JUNE 1966, CFSTI \$1.00 CY, \$0.50 MN

SAMPLES OF COMMERCIAL TRITIATED ORGANIC POLYMERS USED IN LUMINOUS PAINTS WERE TESTED FOR RELEASE OF TRITIUM. DURING THE DRYING PERIOD AFTER APPLICATION, TRITIUM RELEASE DECREASED ONLY SLIGHTLY WITH TIME. LOSS OF TRITIUM BY THE DRIED PAINT WAS ROUGHLY EXPONENTIAL WITH RESPECT TO TEMPERATURE FOR CERTAIN PAINTS, AND FOR OTHERS A STEPWISE CHANGE WAS NOTED. THE TRITIUM WAS RELEASED CHIEFLY AS TRITIATED WATER.

*TRITIUM + THERMAL CONSIDERATION

15-11523 COWSER KE + SNYDER WS

SAFETY ANALYSIS OF RADIONUCLIDE RELEASE TO THE CLINCH RIVER
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

ORNL-3721 (SUPPL. 3) +. 115 PAGES, 16 FIGURES, 35 TABLES, 71 REFERENCES, MAY 1966, CFSTI \$4.00 CY, \$0.75 MN

ONE OF THE PRINCIPAL OBJECTIVES OF THE CLINCH RIVER STUDY IS THE EVALUATION OF RADIATION DOSE EQUIVALENTS TO POPULATIONS DOWNSTREAM FROM OPERATIONS AT THE OAK RIDGE NATIONAL LABORATORY. THE EVALUATION IS BASED ON LONG-TERM MONITORING DATA (1944-1963) AND THE IDENTIFICATION OF CRITICAL EXPOSURE PATHWAYS AND POPULATION GROUPS. THE IMPORTANT AVENUES OF EXPOSURE FROM THE DISCHARGE OF SLIGHTLY CONTAMINATED WASTE WATER TO THE CLINCH RIVER INCLUDE - (1) CONSUMPTION OF CONTAMINATED WATER AND FISH, (2) CONSUMPTION OF AGRICULTURAL PRODUCE THAT MAY BE IRRIGATED WITH RIVER WATER, (3) EXPOSURE TO CONTAMINATED WATER AND BOTTOM SEDIMENTS DURING RECREATIONAL AND INDUSTRIAL USE OF WATER, AND (4) EXPOSURE TO BUILDUP OF SLUDGE AND DEPOSITS IN WATER SYSTEMS UTILIZING RIVER WATER. THE MAJOR SOURCES OF EXPOSURE ARE CURRENTLY THE INGESTION OF CONTAMINATED WATER AND FISH. MATHEMATICAL MODELS WERE DEVELOPED FOR CALCULATING INTERNAL DOSES AND INCLUDED THE DIFFERENCES IN INTAKE AND IN SIZE OF THE CRITICAL ORGAN AS A FUNCTION OF THE AGE OF THE INDIVIDUAL. THE ESTIMATED TOTAL DOSES FROM INTERNAL AND EXTERNAL SOURCES (20-YEAR PERIOD) RECEIVED BY THE SKELETON OF CRITICAL POPULATION GROUPS - THE 18-YEAR-OLD INDIVIDUALS (IN 1944) USING THE CLINCH RIVER, AND THE 14-YEAR-OLD INDIVIDUALS (IN 1944) USING THE TENNESSEE RIVER - WERE 3.2 REMS AND 0.45 REM, RESPECTIVELY. THESE VALUES REPRESENT ABOUT A TENTH OF THE PERMISSIBLE LIMITS ESTABLISHED BY ICRP AND FRC. CALCULATIONAL METHODS ARE PRESENTED, AND EXAMPLES ARE GIVEN FOR THE TRANSFER OF SR-90 AND CS-137 TO MAN BY IRRIGATION WATER.

*DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL + *HAZARDS ANALYSIS + *RIVER, CLINCH + BIOLOGICAL CONCENTRATION, AQUATIC ORGANISMS + BIOLOGICAL CONCENTRATION, FOOD + BIOLOGICAL CONCENTRATION, MILK + CESIUM + COBALT + ECOLOGICAL CONSIDERATION + EFFLUENT + INGESTION + MAXIMUM PERMISSIBLE DOSE (MPD) + MINERAL EXCHANGE + ORNL (OAK RIDGE NATIONAL LABORATORY) + RIVER, TENNESSEE + SOIL, NUCLIDE OCCURRENCE + STRONTIUM + SURFACE WATER, NUCLIDE OCCURRENCE + SURFACE WATER, SEDIMENT + WASTE DISPOSAL, RIVER + WATER TREATMENT + WATER, DRINKING + WATER, IRRIGATION

15-11525 PALMER HE

SIMPLIFIED WHOLE-BODY COUNTING

BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON

2 PAGES, 1 FIGURE, 2 REFERENCES, HEALTH PHYSICS 12(1), PAGES 95-96 (JANUARY 1966)

STUDIES OF THE CS-137 CONTENT OF ALASKAN NATIVES PROVIDED THE OPPORTUNITY TO STUDY THE WHOLE-BODY COUNTING OF PEOPLE WHO CONTAIN SUFFICIENT ACTIVITY TO MAKE SHIELDING UNNECESSARY. WITH THIS SIMPLIFIED METHOD IT WAS POSSIBLE TO REACH A VILLAGE, COUNT ABOUT 20 PEOPLE AND THEN RETURN TO A CENTRAL POINT, ALL WITHIN A FEW HOURS, COMPARED WITH ABOUT A WEEK WHEN OLDER METHODS WERE USED.

*COUNTER, WHOLE BODY + BIOLOGICAL CONCENTRATION, MAN + CESIUM

15-11526 DUNSTER HJ

SOME PROBLEMS IN THE APPLICATION OF ICRP MAXIMUM PERMISSIBLE LEVELS FOR OCCUPATIONAL EXPOSURE
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

6 PAGES, 4 REFERENCES, HEALTH PHYSICS 12(1), PAGES 77-82, (JANUARY 1966)

THE PROBLEMS ARE DISCUSSED FROM THE STANDPOINT OF THE INTERPRETATION RATHER THAN THE IMPLEMENTATION OF ICRP RECOMMENDATIONS. THE RECOMMENDATIONS MAY BE SEPARABLE INTO TWO GROUPS. THE FIRST WOULD COMPRISE RECOMMENDATIONS DEALING WITH FUNDAMENTAL MATTERS DIRECTLY AFFECTING PEOPLE, E.G., MAXIMUM PERMISSIBLE DOSES TO ORGANS. THESE WOULD BE REGARDED AS MANDATORY. THE SECOND GROUP WOULD CONTAIN THE MORE GENERAL RECOMMENDATIONS DEALING WITH THE WORK AREAS AND WITH THE ORGANIZATION OF PROTECTIVE MEASURES. THESE COULD BE TREATED AS GENERAL GUIDES AND INTERPRETED WITH FLEXIBILITY. SUGGESTIONS ARE MADE FOR CHANGES IN THE

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11526 *CONTINUED*

FUNDAMENTAL RECOMMENDATIONS TO SIMPLIFY THEIR PRACTICAL USE. EMPHASIS IS PLACED ON THE NEED TO DEPEND MORE ON THE PROFESSIONAL JUDGMENT OF THE HEALTH PHYSICIST AND MEDICAL OFFICER AND LESS ON A RIGID FORM OF RECOMMENDATION THAT CAN BE INTERPRETED LEGALISTICALLY.

*ICRP (INT. COMM. ON RADIOLOGICAL PROTECTION) + *MAXIMUM PERMISSIBLE DOSE (MPD) + DOSE + PERSONNEL EXPOSURE, RADIATION

15-11527 RECHT P

REGULATIONS GOVERNING IONIZING RADIATIONS
EURATOM, BRUSSELS, BELGIUM

11 PAGES, HEALTH PHYSICS 12(1), PAGES 65-75, (JANUARY, 1966)

THE GENERAL PRINCIPLES UNDERLYING A RADIOACTIVE SAFEGUARDS POLICY ARE DOMINATED BY PREVENTION, WHICH RELATES TO BOTH NUCLEAR ACCIDENTS AND CHRONIC EXPOSURE. THE NOTION OF CALCULATED RISK IS DISCUSSED. THE PRACTICAL MEASURES AS EMBODIED IN REGULATIONS ARE BASED ON THE DEFINITION OF THE ACTIVITY, NOTIFICATION OR AUTHORIZATION OF SUCH ACTIVITIES, THE ESTABLISHMENT OF MAXIMUM LEVELS, THE ORGANIZATION OF SAFEGUARDS PROCEDURES, AND THE OBLIGATION TO PROMOTE TRAINING AND INFORMATION WITH REGARD TO THE RADIOACTIVE HAZARD. THE EUROPEAN ATOMIC ENERGY COMMUNITY (EURATOM) WAS SET UP IN 1958. IT IS PARTICULARLY ACTIVE IN THE FIELD OF REGULATIONS WITH RESPECT TO SIX EUROPEAN COUNTRIES, AND THE AUTHOR GIVES A MORE EXPLICIT ACCOUNT OF THE GENERAL PRINCIPLES AND THE MANNER IN WHICH THEY ARE NOW IMPLEMENTED UNDER LAWS WHICH HAVE BEEN ENACTED IN LINE WITH THE BASIC STANDARDS PROMULGATED BY EURATOM IN 1959.

*EURATOM + *RADIATION SAFETY AND CONTROL + MAXIMUM PERMISSIBLE DOSE (MPD) + RADIATION PROTECTION, ORGANIZATION + REGULATION, GENERAL + WASTE DISPOSAL, GENERAL

15-11528 SOLANAS J + DARDER A + BERTOU P

ENVIRONMENTAL RADIOACTIVITY IN VENEZUELA FROM JANUARY 1960 TO DECEMBER 1962

INSTITUTO VENEZOLANO DE INVESTIGACIONES CIENTIFICAS, CARACAS, VENEZUELA

9 PAGES, 9 FIGURES, 5 REFERENCES, HEALTH PHYSICS 12(1), PAGES 43-48, (JANUARY 1966)

MEASUREMENTS OF GROSS RADIOACTIVITY IN THE AIR, OF DEPOSITION OF SR-90 ON THE EARTH, AND OF PRECIPITATION HAVE BEEN MADE IN VENEZUELA SINCE JANUARY 1960. THE RESULTS SHOW AN INCREASE OF FISSION-PRODUCT ACTIVITY IN THE ENVIRONMENT AS WELL AS AN INCREASE IN THE DEPOSITION OF SR-90. THERE IS A LINEAR RELATION BETWEEN CUMULATIVE DEPOSITION OF SR-90 AND CUMULATIVE RAINFALL. CORRELATIONS BETWEEN BETA ACTIVITY IN THE AIR AND PRECIPITATION SHOW A COMPLEX INVERSE RELATION. VENEZUELA IS AFFECTED SOONER BY FRENCH NUCLEAR EXPLOSIONS BECAUSE, AMONG OTHER FACTORS, THE TESTS HAVE TAKEN PLACE IN THE EQUATORIAL ZONE.

*FALLOUT + *MONITOR, RADIATION, ENVIRONMENTAL + DEPOSITION + POPULATION EXPOSURE + RAINOUT + STRONTIUM

15-11529 JOHNSON JE + WARD GM + STEWART HF

INTERPRETATION OF GAMMA-RAY SPECTRA OF ENVIRONMENTAL FORAGE SAMPLES

COLORADO STATE UNIVERSITY, FORT COLLINS, COLORADO

6 PAGES, 5 FIGURES, 2 REFERENCES, HEALTH PHYSICS 12(1), PAGES 37-42, (JANUARY 1966)

IN STUDIES TO DETERMINE THE FALLOUT DEPOSITION OF CS-137, PASTURE FORAGE SAMPLES WERE COLLECTED AND ANALYZED BY GAMMA-RAY SPECTROMETRY. IN DETERMINING THE CONCENTRATION OF CESIUM THERE WAS OPPORTUNITY TO OBSERVE THE EFFECTS OF INTERFERING GAMMA-RAY EMITTERS DUE TO FALLOUT FISSION PRODUCT AND ACTIVATION PRODUCT ACTIVITY AS WELL AS GAMMA-RAY EMITTERS FROM THE NATURAL OCCURRING SERIES.

*BIOLOGICAL CONCENTRATION, VEGETATION + *CESIUM + BIOLOGICAL CONCENTRATION, ANIMAL FEED + FALLOUT + SPECTROMETRY, GAMMA

15-11530 MECHALI D + DOUSSET M + PARDO G + PENOTET M

DOSE DELIVREE A LA GLANDE THYROIDE APRES INHALATION DE PRODUITS DE FISSION

COMMISSARIAT A L ENERGIE ATOMIQUE

13 PAGES, 5 FIGURES, 6 TABLES, HEALTH PHYSICS 12(1), PAGES 15-27, (JANUARY 1966) IN FRENCH

AMONG THE VARIOUS HAZARDS ARISING FROM THE INHALATION OF FRESH FISSION PRODUCTS, IRRADIATION OF THE THYROID IS IMPORTANT. THIS PAPER IS CONCERNED WITH PU-239 FAST-NEUTRON FISSION PRODUCTS, AND IT BEARS ONLY ON THE CASE OF A CRITICALITY ACCIDENT WHEN ALL THE FISSIONS OCCUR WITHIN A VERY SHORT TIME. THE DOSE DELIVERED TO THE THYROID BY THE SEVERAL IODINE ISOTOPES AFTER THE INHALATION OF 1 MILLICURIE OF FISSION PRODUCTS WAS CALCULATED AS A FUNCTION OF THE TIME ELAPSED BETWEEN PLUTONIUM FISSION AND INHALATION. THE PRESENCE OF THE PARENTS OF THE IODINE ISOTOPES IN THE MIXTURE OF FISSION PRODUCTS WAS TAKEN INTO ACCOUNT.

*DOSE CALCULATION, INTERNAL + *INHALATION + IODINE

15-11531 COMAR CL + WASSERMAN RH + LENGEMANN FW

EFFECT OF DIETARY CALCIUM ON SECRETION OF STRONTIUM INTO MILK

CORNELL UNIVERSITY, NEW YORK STATE VETERINARY COLLEGE

6 PAGES, 4 TABLES, 16 REFERENCES, HEALTH PHYSICS 12(1), PAGES 1-6 (JANUARY 1966)

DAIRY COWS WERE RAISED FROM 5 MONTHS TO 2-1/2 YEARS OF AGE ON EITHER (A) A BASAL RATION THAT SUPPLIED 54 G OF CALCIUM PER DAY OR (B) THE SAME BASAL RATION BUT SUPPLEMENTED WITH INORGANIC SR-90-FREE CALCIUM TO SUPPLY 121 G OF CALCIUM DAILY. ANIMALS IN BOTH GROUPS CONSUMED ESSENTIALLY THE SAME AMOUNT OF SR-90 AND PRODUCED THE SAME AMOUNT OF MILK. THE MILK FROM

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11531 *CONTINUED*

ANIMALS ON THE BASAL RATION CONTAINED 8.4 PC OF SR-90 PER LITER, COMPARED WITH 4.4 IN MILK FROM ANIMALS ON THE SUPPLEMENTED RATION. THEREFORE THE SR-90 SECRETION INTO MILK WAS APPROXIMATELY INVERSELY PROPORTIONAL TO THE CALCIUM INTAKE, AS WAS PREDICTED FROM EARLIER EXPERIMENTS. THIS RELATIONSHIP WAS CONFIRMED BY A DOUBLE-TRACER STUDY USING SR-85 AND CA-47. THE EXTENT TO WHICH THE SAME RELATIONSHIP WOULD HOLD OUTSIDE THE RANGE OF CALCIUM INTAKES AND DIETARY CONDITIONS USED IN THE PRESENT STUDY IS NOT KNOWN. ABOUT 50 PERCENT OF THE SR-90 AND CALCIUM IN THE MILK ORIGINATED FROM THE DIET, AND ABOUT 50 PERCENT FROM THE BODY OF THE COW.

*BIOLOGICAL CONCENTRATION, MILK + *ECOLOGICAL CONSIDERATION + *STRONTIUM +
BIOLOGICAL CONCENTRATION, ANIMAL FEED + CALCIUM

15-11594 KLEMENT AW + SCHULTZ V
TERRESTRIAL AND FRESHWATER RADIOECOLOGY. A SELECTED BIBLIOGRAPHY
DIV. OF BIOLOGY AND MEDICINE, AEC
TID-3910 (SUPPL. 4) +. 130 PAGES, 1271 REFERENCES, JANUARY 1966, CFSTI \$1.50 CY, \$1.00 MN

A BIBLIOGRAPHY LISTING 1271 TITLES IN THE FIELD OF TERRESTRIAL AND FRESH-WATER ECOLOGY.

*ECOLOGICAL CONSIDERATION + BIOLOGICAL CONCENTRATION, GENERAL + RADIATION EFFECT

15-11595 HORWILZ EP + BLOOMQUIST CA + HARVEY HW + HOH JC
THE PROCESSING OF ROCK DEBRIS FOR TRANSPLUTONIUM ELEMENTS PRODUCED BY UNDERGROUND NUCLEAR DETONATIONS
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
ANL-7134 +. 24 PAGES, 9 FIGURES, 9 REFERENCES, FEBRUARY 1966, CFSTI \$2.00 CY

THE OVERALL RECOVERY OF PLUTONIUM AND THE TRANSPLUTONIUM ELEMENTS OBTAINED BY USING THE PROCEDURE DESCRIBED IN THIS REPORT IS DIFFICULT TO DETERMINE EXACTLY BECAUSE OF THE UNCERTAINTY IN THE INITIAL CONCENTRATIONS OF THESE ELEMENTS IN THE ROCK-DEBRIS SAMPLES. HOWEVER, SMALL-SCALE EXPERIMENTS, WHERE KNOWN QUANTITIES OF PU-239, CM-242, AND CF-252 WERE ADDED TO THE ROCK SAMPLES, PRODUCED RECOVERIES IN THE RANGE OF 90-95 PERCENT. RECOVERIES OF PLUTONIUM AND THE TRANSPLUTONIUM ELEMENTS OBTAINABLE ON A KILOGRAM SCALE ARE ESTIMATED TO BE AT LEAST THIS GOOD. PROCESSING TIMES ASSUME, OF COURSE, THAT ALL EQUIPMENT PERFORMS PROPERLY.

*NUCLEAR DETONATION + *PLOWSHARE PROGRAM + *PLUTONIUM + CALIFORNIUM + CURIUM + TRANSURANIUM ELEMENT

15-11596 INGRAHAM HS
ENVIRONMENTAL SAMPLING REPORT
BROOKHAVEN NATIONAL LABORATORY
13 PAGES, 6 TABLES, DECEMBER 1965

THE RESULTS INDICATE THAT THERE HAVE BEEN NO DETECTABLE INCREASES IN RADIOACTIVITY IN THE SAMPLES OF FALLOUT, MILK, VEGETATION, OR IN THE GAMMA-BACKGROUND MEASUREMENTS AROUND BROOKHAVEN NATIONAL LABORATORY DUE TO ITS OPERATIONS. THE RADIOACTIVITY DETECTED IN THE SAMPLES WAS CAUSED BY FALLOUT FROM NUCLEAR WEAPONS TESTING, AS EVIDENCED BY COMPARISON WITH SAMPLES TAKEN THROUGHOUT THE STATE.

*SURVEY, RADIATION, ENVIRONMENTAL + BARIUM + BIOLOGICAL CONCENTRATION, MILK +
BIOLOGICAL CONCENTRATION, VEGETATION + BNL (BROOKHAVEN NATIONAL LABORATORY) + CESIUM + FALLOUT +
GROSS GAMMA + IODINE + MANGANESE + POTASSIUM + STRONTIUM + ZIRCONIUM

15-11597 MARKOV KP + RYABOV NV + STAS KN
METHOD FOR A CONTINUOUS CONTROL OF THE QUANTITY OF LATENT ENERGY
GOSUDAKSIVENNIY KUMILEI PO ISPUL ZUVANIYU ATOMNOY ENERGII SSSR
ANL-TRANS-277 + NP-15105 +. 13 PAGES, 1964, CFSTI, \$1.00 CY, \$0.50 MN

THIS ARTICLE DEALS WITH METHODOLOGICAL PROBLEMS CONCERNING THE FEASIBILITY AND THE CONSTRUCTION OF AN INSTRUMENT FOR CONTINUOUS RECORDING OF THE TOTAL REACTIVITY PRODUCED BY DAUGHTER PRODUCTS OF RADON IN THE ATMOSPHERE. THE ARTICLE GENERATES A MATHEMATICAL MODEL FOR A CONSTANT AIR MONITOR TYPE OF INSTRUMENT USING CONTINUOUS-BELT FILTERING. ONLY THE DAUGHTER PRODUCTS OF RADON ARE CONSIDERED.

*MATHEMATICAL STUDY + *MONITOR, RADIATION, AIR + INSTRUMENTATION, RADIATION MONITORING +
MEASUREMENT, REACTIVITY

15-11623 CHANDRASEKARON VR + LALIT BY
RADIOCHEMICAL METHOD FOR THE DETERMINATION OF CESIUM, STRONTIUM AND RUTHENIUM IN AIRBORNE AND SURFACE FALLOUT
ATOMIC ENERGY ESTABLISHMENT, TROMBAY
5 PAGES, 1 FIGURE, 2 TABLES, 4 REFERENCES, PAGES 57-62 OF PROCEEDINGS OF THE NUCLEAR AND RADIATION CHEMISTRY SYMPOSIUM MARCH 16-MARCH 19, 1964, SOURCE

A SHORT RADIOCHEMICAL PROCEDURE WAS DEVELOPED FOR DETERMINING CS-137, SR-89, SR-90, AND RU-106 IN RADIOACTIVE FALLOUT. THE RESULTS OF A TRACER EXPERIMENT TO ESTABLISH THE PURITY AND QUANTITATIVE ASPECTS OF THE SEPARATION ARE GIVEN. SOME DATA ON THE LEVELS OF THESE ISOTOPES IN FALLOUT ARE INCLUDED, AND THE USE OF THE DATA ON THE RATIO SR-89/SR-90 IN FALLOUT IS DESCRIBED.

*ANALYTICAL TECHNIQUE, SOLID + *FALLOUT + *RADIOCHEMICAL ANALYSIS + CESIUM + RUTHENIUM + STRONTIUM

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11624 KHANDEKAR RN
SEPARATION OF RADIOZIRCONIUM FROM FALLOUT SAMPLES
ATOMIC ENERGY ESTABLISHMENT, TROMBAY
4 PAGES, 1 TABLE, 6 REFERENCES, PAGES 69-72 OF PROCEEDINGS OF THE NUCLEAR AND RADIATION CHEMISTRY SYMPOSIUM, MARCH 16 - MARCH 19, 1964, SOURCE

A METHOD IS PRESENTED FOR SEPARATING RADIOZIRCONIUM FROM FALLOUT SAMPLES. THE RECOVERY LIES BETWEEN 85.5 AND 96 PERCENT.

*ZIRCONIUM + FALLOUT + NIOBIUM

15-11633 HAWLEY CA
CONTROLLED ENVIRONMENTAL RADIOIODINE TESTS AT THE NATIONAL REACTOR TESTING STATION, 1965 PROGRESS REPORT
USAEC, IDAHO OPERATIONS OFFICE
IDO-12047 +. 41 PAGES, 17 FIGURES, 10 TABLES, 15 REFERENCES, FEBRUARY 1966, CFSTI \$2.00 CY, \$0.50 MN

THE CERT PROJECT CONSISTS OF A SERIES OF RELEASES OF RADIOIODINE OVER DIFFERENT VEGETATION AND DURING VARIOUS METEOROLOGICAL CONDITIONS, WITH THE PRIME OBJECTIVE BEING TO MEASURE THE RELATIONSHIPS INVOLVED IN THE PASSAGE OF RADIOIODINE THROUGH THE AIR-VEGETATION-COW-MILK-HUMAN CHAIN. THIS REPORT DEALS WITH THE RESULTS OF THE FIRST FIVE TESTS IN THE SERIES, WHICH STARTED IN THE SPRING OF 1963 AND IS CONTINUING. EACH TEST WAS CONDUCTED UNDER MEASURED METEOROLOGICAL CONDITIONS AND OVER PREPARED SAMPLING AND GRAZING COURSES. TWO TESTS WERE MADE OVER OPEN-RANGE TYPE VEGETATION, TWO OVER IRRIGATED PASTURES, AND ONE OVER SNOW-COVERED GROUND. TWO TESTS WERE CONDUCTED UNDER LAPSE CONDITIONS, TWO UNDER INVERSION CONDITIONS, AND ONE UNDER NEUTRAL CONDITIONS. DATA, DESCRIPTIONS OF METHODS, AND CALCULATIONS ARE REPORTED. DISCUSSIONS OF RESUSPENSION FACTORS AND PARTICLE SIZES AND BEHAVIOR ARE ALSO INCLUDED.

*FISSION PRODUCT, IODINE + *IODINE + BIOLOGICAL CONCENTRATION, MAN + BIOLOGICAL CONCENTRATION, MILK + BIOLOGICAL CONCENTRATION, VEGETATION + DEPOSITION + DOSE CALCULATION, INTERNAL + ECOLOGICAL CONSIDERATION + FISSION PRODUCT RELEASE, GENERAL + INGESTION + INHALATION + METEOROLOGICAL SUPPORT + METEOROLOGY + PARTICLE SIZE + RESUSPENSION

15-11634 VORTMAN LJ
PROJECT SULKY. CLOSE-IN AIR BLAST FROM A RELATIVELY DEEP LOW-YIELD NUCLEAR DETONATION IN BASALT
SANDIA CORPORATION, ALBUQUERQUE, NEW MEXICO
PNE-711F +. 28 PAGES, 2 TABLES, 12 FIGURES, 6 REFERENCES, MAY 31, 1966, CFSTI \$1.50 CY, \$0.50 MN

CLOSE-IN AIR-BLAST MEASUREMENTS WERE MADE ON THE SULKY SHOT (AN 85-TON NUCLEAR DETONATION BURIED 90 FEET BELOW THE SURFACE IN BASALT). THE DOMINANT OVERPRESSURE WAS THAT RESULTING FROM A GROUND SHOCK WHICH TRANSMITTED PRESSURE TO THE AIR AT THE EPICENTER. THE PRESSURE WAVE THEN PROPAGATED AWAY FROM THE EPICENTER AT SONIC VELOCITY IN AIR. AN EARLIER WAVE OF 1/7 THE AMPLITUDE OF THE GROUND-SHOCK-INDUCED PEAK PROPAGATED AT THE VELOCITY OF A SEISMIC SURFACE WAVE. IT MAY HAVE BEEN DUE TO GAGE SENSITIVITY TO GROUND-SURFACE MOTION, OR IT MAY HAVE BEEN MEASUREMENT OF OVERPRESSURE RESULTING AT THE GAGE FROM SUCH GROUND MOTION. THE PULSE FROM VENTING GASES WAS WEAK BECAUSE OF THE RELATIVELY GREAT BURIAL DEPTH. IT WAS SUPER-IMPOSED ON THE NEGATIVE WAVE FOLLOWING THE GROUND-SHOCK-INDUCED PULSE AND GAVE PEAK VALUES EQUAL TO OR LESS THAN AMBIENT PRESSURE. IN ONE SENSE, THE GAS-VENTING PRESSURES WERE IN AGREEMENT WITH THOSE OF DANNY BOY, WHICH ALSO WERE SUPERIMPOSED ON A NEGATIVE WAVE BUT WHICH WERE STRONG ENOUGH TO HAVE POSITIVE VALUES BECAUSE OF THE RELATIVELY SHALLOWER BURIAL DEPTH. GROUND-SHOCK-INDUCED PEAKS FROM BOTH SULKY AND DANNY BOY ARE IN AGREEMENT WITH THOSE FROM HIGH-EXPLOSIVE SHOTS AT COMPARABLE BURIAL DEPTHS.

*NUCLEAR DETONATION + *PLOWSHARE PROGRAM + GEOLOGICAL CONSIDERATION, GEOPHYSICAL

15-11653 GUILLOU RB
ARMS-II-CINCINNATI AREA AERORADIOACTIVITY SURVEY
EDGERTON, GERMESHAUSEN AND GRIER, INC., SANTA BARBARA, CALIFORNIA
CEX-62.6.5 +. 19 PAGES, 9 FIGURES, 1 TABLE, 5 REFERENCES, APRIL 1964, CFSTI \$1.00 CY

AN AERIAL RADIOLOGICAL MEASURING SURVEY (ARMS) OF THE CINCINNATI AREA WAS MADE BETWEEN NOVEMBER 3 AND NOVEMBER 24, 1962. THE SURVEY WAS PART OF A NATIONWIDE PROGRAM TO MEASURE THE PRESENT ENVIRONMENTAL LEVELS OF GAMMA RADIATION. APPROXIMATELY 7600 TRAVERSE MILES WERE FLOWN, AT AN ALTITUDE OF ABOUT 500 FT, IN THE AREA THAT CONSISTS OF A 100-MILE SQUARE CENTERED ON FERNALD, OHIO. THE NORTHEAST QUADRANT, PREVIOUSLY SURVEYED BY THE U. S. GEOLOGICAL SURVEY, WAS NOT RESURVEYED. EG AND G ARMS-II INSTRUMENTATION WAS USED IN THE SURVEY. THE DATA ARE PRESENTED AS AERORADIOACTIVITY UNITS, OR AREAS WITH SIMILAR GAMMA-RADIATION COUNTING RATES AT 500 FT, AT TWO MAP SCALES - (1) GENERALIZED AT ABOUT 1 TO 1,000,000 AND (2) DETAILED AT 1 TO 250,000. THE MAXIMUM AERORADIOACTIVITY IN MOST OF THE AREA IS LESS THAN 800 COUNTS/SEC. MAXIMUM COUNTING RATES OF MORE THAN 800 BUT LESS THAN 1200 COUNTS/SEC OCCUR IN ABOUT ONE-EIGHTH OF THE AREA. AERIAL MEASUREMENTS OF GROUND RADIOACTIVITY IN THE ARMS-II CINCINNATI AREA WERE CONSISTENT WITH WHAT WAS EXPECTED, CONSIDERING THE GEOLOGY OF THE AREA. THE GLACIATED PART OF THE AREA NORTH OF THE OHIO RIVER WAS GENERALLY LESS RADIOACTIVE THAN THE AREA SOUTH OF THE RIVER. ARTIFICIAL RADIONUCLIDES WERE PROBABLY PRESENT IN ONLY SMALL QUANTITIES BECAUSE BACKGROUND GAMMA RADIOACTIVITY WAS LESS THAN 200 COUNTS/SEC IN SEVERAL PLACES.

*SURVEY, RADIATION, AERIAL + CIVIL DEFENSE + GEOLOGICAL CONSIDERATION, GENERAL + POTASSIUM

15-11655 THORNGATE JH + LOY ET
POST PULSE GAMMA-RADIATION SPECTRUM--OPERATION BREN
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11655 *CONTINUED*
CEX-62.13 +. 118 PAGES, 19 FIGURES, 3 TABLES, 15 REFERENCES, DECEMBER 1965, CFSTI \$1.25 CY, \$0.75 MN

TO UNDERSTAND BETTER THE GAMMA-RAY FIELD EXISTING AFTER THE DETONATION OF A NUCLEAR WEAPON, A SERIES OF GAMMA-RAY SPECTRUM MEASUREMENTS WERE MADE AS A FUNCTION OF TIME AFTER A REACTOR PULSE DURING OPERATION BREN. MEASUREMENTS WERE MADE WITH A 3-IN.-BY-3-IN.-NAI(Tl) DETECTOR LOCATED IN A COLLIMATOR WHICH WAS AIMED ALTERNATELY AT THE REACTOR OR 60 DEG AWAY. ALTHOUGH ELABORATE REDUCTION OF THE DATA WAS NOT PERFORMED, THE RESULTS INDICATE THAT THE GAMMA FIELD WAS PRODUCED ABOUT EQUALLY BY THE FISSION PRODUCTS AND BY NUCLEAR INTERACTIONS BETWEEN THE DELAYED NEUTRONS AND AIR.

CESIUM + COBALT + COUNTER + NUCLEAR DETONATION + SPECTROMETRY, GAMMA

15-11656 POPENOE P
AERORADIOACTIVITY SURVEY AND AREAL GEOLOGY OF THE DENVER AREA, COLORADO. (ARMS-I)
U. S. GEOLOGICAL SURVEY + DIVISION OF BIOLOGY AND MEDICINE USAEC
CEX-59.4.26 +. 26 PAGES, 4 FIGURES, 3 TABLES, 23 REFERENCES, JULY 1966, CFSTI \$1.00 CY, \$0.50 MN

AN AIRBORNE GAMMA-RADIATION SURVEY OF 6500 SQUARE MILES NEAR DENVER, COLORADO, WAS MADE BY THE U. S. GEOLOGICAL SURVEY FOR THE USAEC. CONTINUOUS RADIOACTIVITY PROFILES WERE OBTAINED WITH SCINTILLATION DETECTION EQUIPMENT INSTALLED IN A TWIN-ENGINE AIRCRAFT. THE AREA WAS TRAVERSED WITH PARALLEL EAST-WEST FLIGHT LINES SPACED AT ONE-MILE INTERVALS AND FLOWN 500 FT ABOVE THE GROUND. A MAP OF RADIOACTIVITY UNITS WAS PREPARED FROM THE PROFILES. RESULTS OF THE SURVEY INDICATE THAT A WIDE RANGE OF NATURAL RADIOACTIVITY EXISTS AND THAT ITS GENERAL DISTRIBUTION CAN BE ATTRIBUTED TO THE GEOLOGY OF THE AREA. ALL THE AREA SURVEYED LIES IN THE COLORADO PIEDMONT SECTION OF THE GREAT PLAINS PHYSIOGRAPHIC PROVINCE, WHICH IS UNDERLAIN BY PALEOZOIC, MESOZOIC, AND CENOZOIC SEDIMENTARY ROCKS AND QUATERNARY SURFICIAL DEPOSITS. HIGH RADIOACTIVITY LEVELS ARE GENERALLY ASSOCIATED WITH ARKOSIC AND CONGLOMERATIC SEDIMENTARY ROCKS AND ALLUVIUM DERIVED FROM THE CRYSTALLINE ROCKS OF THE FRONT RANGE. LOWER LEVELS ARE ASSOCIATED WITH ARGILLACEOUS AND ARENACEOUS SEDIMENTARY ROCKS, AND EOLIAN SAND AND LOESS.

*SURVEY, RADIATION, AERIAL + CIVIL DEFENSE + GEOLOGICAL CONSIDERATION, GENERAL

15-11658 THORNGATE JH + JOHNSON DR + PERDUE PT
NEUTRON AND GAMMA RAY LEAKAGE FROM THE ICHIBAN CRITICAL ASSEMBLY
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
CEX-64.7 +. 60 PAGES, 22 FIGURES, 11 TABLES, 24 REFERENCES, JUNE 1966, CFSTI \$1.00 CY, \$0.50 MN

SINCE 1956, THE OAK RIDGE NATIONAL LABORATORY HEALTH PHYSICS DIVISION HAS CONDUCTED A STUDY TO DETERMINE THE NEUTRON AND GAMMA-RAY DOSES RECEIVED BY THE SURVIVORS OF THE HIROSHIMA AND NAGASAKI NUCLEAR DETONATIONS. STUDIES HAVE INCLUDED INVESTIGATIONS OF WEAPON FISSION YIELD AND RADIATION LEAKAGE, GEOMETRICAL FACTORS SUCH AS THE POSITION OF GROUND ZERO AND HEIGHT OF THE BURST, AND THE RADIATION ATTENUATION PROVIDED BY AIR AND BY TYPICAL JAPANESE STRUCTURES. THE PURPOSE OF THE PRESENT RESEARCH WAS TO DETERMINE ACCURATELY THE NEUTRON AND GAMMA-RAY LEAKAGE PER FISSION FROM THIS CRITICAL ASSEMBLY. COMPARISON OF THESE DATA WITH CALCULATIONS MADE AT LASL FOR THE SPHERICAL GEOMETRY OF ICHIBAN PROVIDES A TEST TO DETERMINE IF THE CALCULATIONS CAN BE EXTENDED TO THE WEAPON CONFIGURATION.

*DOSE CALCULATION, EXTERNAL + *POPULATION EXPOSURE + CIVIL DEFENSE + COUNTER + DOSE MEASUREMENT, EXTERNAL + NEUTRON + NUCLEAR DETONATION + SPECTROMETRY, NEUTRON

15-11659 MACKALLOR JA
AERORADIOACTIVITY SURVEY AND GEOLOGY OF PUERTO RICO (ARMS-I)
U. S. GEOLOGICAL SURVEY + DIVISION OF BIOLOGY AND MEDICINE, USAEC
CEX-61.7.2 +. 23 PAGES, 3 FIGURES, 33 REFERENCES, JUNE 1966, CFSTI \$1.00 CY, \$0.50 MN

AN AERORADIOACTIVITY SURVEY OF PUERTO RICO WAS MADE IN 1961 BY THE U. S. GEOLOGICAL SURVEY WITH SCINTILLATION-DETECTION EQUIPMENT INSTALLED IN A TWIN-ENGINE AIRCRAFT. THE ISLAND WAS TRAVERSED ON EAST-WEST FLIGHT LINES SPACED APPROXIMATELY ONE MILE APART, AND THE AIRCRAFT MAINTAINED AN ALTITUDE OF 500 FT ABOVE GROUND. THE RADIOACTIVITY DATA WERE CORRECTED FOR DEVIATIONS FROM THE SURVEYING ALTITUDE, AND A COSMIC COMPONENT WAS SUBTRACTED. RADIOACTIVITY OF MOST OF THE CENTRAL PART OF THE ISLAND IS 200 TO 300 CPS, AND AN AREA SEVERAL MILES WIDE THAT EXTENDS SOUTH-EASTWARD TO 25 MILES FROM SAN SEBASTIAN IS 300 TO 800 CPS. RADIOACTIVITY OF THE OUTER MARGINS OF THE ISLAND IS MOSTLY 100 TO 200 CPS, WITH SMALL AREAS OF CONSIDERABLY HIGHER RADIOACTIVITY. THE GENERALIZED GEOLOGIC MAP OF PUERTO RICO SHOWS 14 GEOLOGIC UNITS, AND THE GEOLOGY AND RADIOACTIVITY OF EACH UNIT IS DISCUSSED BRIEFLY.

*PUERTO RICO + *SURVEY, RADIATION, AERIAL + CIVIL DEFENSE + GEOLOGICAL CONSIDERATION, GENERAL + GEOLOGICAL CONSIDERATION, STRATIGRAPHY + GROSS GAMMA

15-11660 SMITH KF + SOMMERS JF
A PRACTICAL SIMULTANEOUS ALPHA-BETA COUNTER FOR APPLIED HEALTH PHYSICS
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
IDO-17122 +. 15 PAGES, 10 FIGURES, 3 TABLES, NOVEMBER 1965, CFSTI \$1.00 CY, \$0.50 MN

A NEW COUNTING SYSTEM TO SIMULTANEOUSLY COUNT ALPHA AND BETA RADIATION FROM A SINGLE SOURCE HAS BEEN DEVELOPED FOR APPLIED HEALTH PHYSICS WORK. THE SYSTEM USES A 2-1/4-IN.-DIAMETER PROPORTIONAL COUNTER WITH A 2-IN.-DIAMETER, 1 MG/CM² ALUMINIZED MYLAR WINDOW AS THE DETECTOR. THE COUNTER DRIVES AN AMPLIFIER-DISCRIMINATOR WHICH SEPARATES THE ALPHA AND BETA PULSES INTO TWO CHANNELS BY THE USE OF PULSE HEIGHT AND ANTICOINCIDENT CIRCUITRY. PREVIOUS SYSTEM DESIGNS USING WINDOW-TYPE COUNTERS HAVE RESULTED IN UNITS IN WHICH THE ALPHA AND BETA SENSITIVITIES DRIFT WITH TIME AND TEMPERATURE. IN ADDITION THERE HAS ALWAYS BEEN A SEVERE

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11660 *CONTINUED*

REDUCTION IN THE ALPHA SENSITIVITY WHEN OPERATING AT TYPICAL BETA-PLATEAU VOLTAGES. THESE TWO FAULTS HAVE BEEN LARGELY OVERCOME IN THE NEW SYSTEM THROUGH THE USE OF STABLE ELECTRONIC CIRCUITRY AND BY OPERATING THE COUNTER OFF THE PLATEAU. IN ADDITION TO OVERCOMING THESE TWO FAULTS, THE SYSTEM ALSO EXHIBITS A BETA-BACKGROUND RESPONSE WHICH IS AN ORDER OF MAGNITUDE LESS THAN THAT OBTAINED WITH PREVIOUS SYSTEMS.

*COUNTER + GROSS ALPHA + GROSS BETA + INSTRUMENTATION, NUCLEAR + INSTRUMENTATION, RADIATION MONITORING + SPECTROMETRY, ALPHA + SPECTROMETRY, BETA

15-11662 JANSSEN G + WILLINGHAM WE + DEMIER WV

BURIED RADIOACTIVE WASTE STORAGE TANK TEMPERATURES AND SOIL TEMPERATURES NEAR LEAKS
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON

BNWL-181 +. 69 PAGES, 11 FIGURES, 7 TABLES, 7 REFERENCES, MARCH 1966, CFSTI \$3.00 CY, \$0.75 MN

THE TEMPERATURES AND HEAT LOSSES AROUND WASTE TANKS CONTAINING BOILING SOLUTIONS AND HEAT-GENERATING SLUDGE LAYERS ARE COMPARED FOR DRY AND WET SOILS. IN ALL CASES MOST OF THE CONDUCTED HEAT FLOWS FROM THE TOP OF THE TANK, THROUGH THE SOIL LAYER ABOVE THE TANK, AND TO THE ATMOSPHERE. THE TEMPERATURE DISTRIBUTION THROUGHOUT THE SOIL-TANK SYSTEM IS NEARLY INDEPENDENT OF THE MOISTURE CONTENT OF THE SOIL IF ALL THE SOIL IN THE SYSTEM AS THE SAME THERMAL CONDUCTIVITY. HOWEVER, IF A LOCALIZED WET REGION APPEARS ONLY ADJACENT TO THE TANK WALL, HIGHER TEMPERATURES WILL BE FOUND IN THIS REGION OF THE SOIL THAN IN NEARBY DRY AREAS. REMOVAL OF ALL LIQUID FROM WASTE TANKS WITHOUT REMOVING THE SLUDGE CAN RESULT IN EXTREMELY HIGH TEMPERATURES. LEAKS OF ALKALINE SUPERNATE CONTAINING ONLY CESIUM AND SMALL AMOUNTS OF RUTHENIUM CANNOT CAUSE DANGEROUSLY HIGH SOIL TEMPERATURES. TEMPERATURE-RISE MAPS ARE PROVIDED FOR HEMISPHERICAL LEAKS, VARYING FROM 100 TO 100,000 GAL, FOR WET AND DRY SOIL AND FOR VARIOUS TYPES OF FISSION PRODUCTS. THESE MAPS MAY PROVE USEFUL IN ANALYZING TEMPERATURE RECORDS TO DETERMINE THE SIZE AND LOCATION OF A LEAK. A COMPUTER PROGRAM IS PROVIDED FOR CALCULATING TEMPERATURE RISE MAPS AROUND HEMISPHERICAL LEAKS AND HEMISPHEROIDAL LEAKS OF VARYING SHAPES. HIGHER TEMPERATURES ARE REACHED IN PROLATE HEMISPHEROIDAL LEAKS THAN IN HEMISPHERICAL LEAKS OF EQUAL VOLUME.

*THERMAL CONSIDERATION + *WASTE STORAGE + CESIUM + COMPUTER PROGRAM + HEAT CONDUCTION + HEAT TRANSFER + RUTHENIUM + SOIL, NUCLIDE OCCURRENCE + SOIL, RADIONUCLIDE MOVEMENT THROUGH

15-11704 MANNESCHMIDT JF

RECENT ADVANCES IN MONITORING OF RADIOACTIVE GASEOUS WASTES AT ORNL
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE

CONF-660904 +. 27 PAGES, 17 FIGURES, 6 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON, MASS., SEPTEMBER 13-16, 1966, SOURCE

MANY ACTIVITIES AT THE OAK RIDGE NATIONAL LABORATORY ARE CONCERNED WITH THE CHEMICAL PROCESSING OF RADIOACTIVE MATERIALS. GASEOUS EFFLUENTS FROM THESE OPERATIONS ARE TREATED TO REMOVE DANGEROUS CONTAMINANTS BEFORE RELEASE TO THE ATMOSPHERE. ROUTINE MONITORING OF SUCH EMISSIONS WAS STARTED IN 1966 WHEN MANUALLY OPERATED PARTICULATE MONITORS WERE INSTALLED AT EACH OF THREE PROCESS STACKS. SINCE THAT DATE, COVERAGE HAS BEEN EXTENDED TO SIX STACKS, THE SAMPLE WITHDRAWAL SYSTEM HAS BEEN REBUILT, AND THE DETECTION EQUIPMENT HAS BEEN ADDED TO AND MODERNIZED. THE INTENSIVE MONITORING HAS LEAD TO PROCESS IMPROVEMENTS THAT HAVE REDUCED THE ENVIRONMENTAL RELEASES OF RADIOACTIVITY IN THE GASEOUS WASTE EFFLUENTS BY A FACTOR OF 3 SINCE 1962.

*MONITOR, RADIATION, EMERGENCY + *MONITOR, RADIATION, GAS + *MONITOR, RADIATION, GENERAL PRACTICE + *MONITOR, RADIATION, SAMPLING + *MONITOR, RADIATION, STACK + MONITOR, RADIATION, AIR + MONITOR, RADIATION, BACKGROUND + MONITOR, RADIATION, ENVIRONMENTAL + MONITOR, RADIATION, GENERAL

15-11714 SMITH DG + REIST PC + SILVERMAN L
INCREASED DETECTION SENSITIVITY FOR KRYPTON-85
HARVARD UNIVERSITY

CONF-660904 +. 14 PAGES, 6 FIGURES, 1 TABLE, 4 REFERENCES, PRESENTED AT 9TH AEC AIR CLEANING CONFERENCE, BOSTON, MASS., SEPTEMBER 13-16, 1966, SOURCE

INCREASING THE FIELD DETECTION SENSITIVITY FOR KR-85 TO A LEVEL OF 3 (MINUS 8TH) MICROCURIE/CC BY USING A 2.8-LITER IONIZATION CHAMBER AND VIBRATING-REED-ELECTROMETER DETECTION SYSTEM, PLUS AN ADSORPTION-DESORPTION KR-85 CONCENTRATING SYSTEM, WAS INVESTIGATED. THE KR-85 IN THE SAMPLE STREAM WAS CONCENTRATED BY ADSORBING IT ON AN ACTIVATED CARBON BED AT -78.5 C AND DESORBING IT INTO THE IONIZATION CHAMBER AT 20 C. A CONCENTRATION FACTOR WAS DEFINED AND OBSERVED TO BE INDEPENDENT OF THE INLET CONCENTRATION OF KR-85.

*ANALYTICAL TECHNIQUE, AIR + *ANALYTICAL TECHNIQUE, GAS + *INSTRUMENTATION CALIBRATION + *KRYPTON + *NOBLE GAS + AIR CLEANING + RADIOACTIVITY, RELEASE + RADIOISOTOPE

15-11764 ABSON W + LOOSEMORE WR

REPORT ON DEVELOPMENTS IN HEALTH PHYSICS INSTRUMENTS IN ELECTRONICS DIVISION, A.E.R.E.
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AERE-R-4552 + CONF-640304-1 +. 49 PAGES, 18 FIGURES, 23 REFERENCES, 1965, HMSO

THE REPORT PROVIDES A GENERAL SUMMARY AND REVIEW OF RESEARCH AND DEVELOPMENT WORK DURING THE LAST 3 YEARS IN THE ELECTRONICS DIVISION, ATOMIC ENERGY RESEARCH ESTABLISHMENT (UK), ON TOPICS RELATED TO RADIOLOGICAL PROTECTION AND HEALTH PHYSICS INSTRUMENTATION. THE REPORT COVERS EXTERNAL BETA-GAMMA MONITORING INSTRUMENTS, NEUTRON MONITORING INSTRUMENTS, MONITORING INSTRUMENTS FOR SURFACE CONTAMINATION, PERSONAL BETA-GAMMA DOSE AND DOSE-RATE INSTRUMENTS, GAMMA SPECTROMETERS FOR DISTRICT SURVEYS AND FOR AIRBORNE PARTICLES, PLUS OTHER

ACCESSION NUMBER 15-11660 TO 15-11764

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11764 *CONTINUED*
INSTRUMENTATION TOPICS.

*DOSIMETRY, GENERAL + *MONITOR, RADIATION, GENERAL + CHAMBER, ION + DOSE MEASUREMENT, EXTERNAL +
DOSIMETRY, THERMOLUMINESCENCE + MONITOR, RADIATION, AIR + MONITOR, RADIATION, PERSONNEL +
MONITOR, RADIATION, SURFACE + UNITED KINGDOM

15-11770 RISING FL
A SYSTEM FOR CRITICALITY VERIFICATION
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-SA-31 +. 10 PAGES, JUNE 7, 1965, CFSTI \$1.00 CY, \$0.50 MN

A FAST-NEUTRON DETECTOR IS USED TO VERIFY A CRITICALITY INCIDENT AFTER A CRITICALITY ALARM.
THIS TYPE OF DETECTOR WAS CHOSEN TO ELIMINATE THE ALARMS CAUSED BY CHANGES IN GAMMA
BACKGROUND. THE SYSTEM IS CAPABLE OF DETECTING 10(15TH) FISSIONS, SHIELDED BY 8 IN. OF LEAD,
AT A DISTANCE OF 700 FT. IT IS USED ONLY TO VERIFY AN OCCURRENCE. THE BASIC ELECTRONICS
DESIGN WAS ADAPTED FROM RESEARCH WORK COMPLETED BY THE HANFORD NUCLEONICS INSTRUMENTATION
GROUP AND IS USED WITH A SCINTILLATION DETECTOR AS AERIAL SURVEY EQUIPMENT.

*MONITOR, RADIATION, ENVIRONMENTAL + *MONITORING SYSTEM + INSTRUMENTATION, NUCLEAR +
MEASUREMENT, REACTIVITY

15-11771 MUSTARD GL
RADIATION ALARM INSTRUMENT INSTRUCTION MANUAL
GOODYEAR ATOMIC CORPORATION, PIKETON, OHIO
GAT-T-1222 +. 36 PAGES, OCTOBER 13, 1965, CFSTI \$2.00 CY, \$0.50 MN

THE THEORY OF OPERATION AND THE SPECIFICATIONS ARE PRESENTED FOR THE INTEGRATING-TYPE
CRITICALITY ALARM INSTRUMENT USED AT THE PORTSMOUTH GASEOUS DIFFUSION PLANT. THE ADVANTAGES
OF THE GAMMA-PLUS-NEUTRON-SENSITIVE ION CHAMBER WITH SHORT-TERM INTEGRATION ARE DISCUSSED.
THE MAJOR DESIGN FEATURES - FEWER FALSE ALARMS, RELIABILITY, FAILSAFE, SELF-CONTAINED POWER
FROM CONTINUOUSLY CHARGED ALKALINE BATTERIES, AND SELF-MONITORING ARE DESCRIBED IN DETAIL.

*CHAMBER, ION + *MONITOR, RADIATION, EMERGENCY + INSTRUMENTATION, NUCLEAR +
MONITOR, RADIATION, ENVIRONMENTAL + PORTSMOUTH PLANT

15-11777 SHIPMAN WH
CONCENTRATION OF STRONTIUM FROM SEAWATER BY MANGANESE DIOXIDE. DETERMINATION OF SR-90 IN LARGE VOLUMES OF
SEAWATER
NAVAL RADIOLOGICAL DEFENSE LABORATORY, SAN FRANCISCO
USNRDL-TR-995 + AD-635528 +. 14 PAGES, 3 FIGURES, 4 TABLES, 5 REFERENCES, FEBRUARY 27, 1966, DDC

THE ADSORPTION OF STRONTIUM BY HYDROUS MANGANESE DIOXIDE WAS USED TO CONCENTRATE STRONTIUM IN
SEAWATER. THE IMPORTANT FACTORS IN THIS CONCENTRATION PROCESS WERE STUDIED. A COMPLETE
RADIOCHEMICAL PROCEDURE IS PRESENTED.

*ANALYTICAL TECHNIQUE, WATER + *STRONTIUM + FALLOUT + OCEAN AND SEA + SURFACE WATER, NUCLIDE OCCURRENCE

15-11779 BAIR WJ + PARK JF + CLARKE WJ
LONG-TERM STUDY OF INHALED PLUTONIUM IN DOGS
BATTELLE MEMORIAL INSTITUTE, RICHLAND
AFWL-TR-65-214 + AD-631690 +. 54 PAGES, 30 FIGURES, 4 TABLES, 22 REFERENCES, MARCH 1966, CFSTI \$3.00 CY,
\$0.50 MN

TO DETERMINE THE LONG-TERM TRANSLOCATION AND BIOLOGICAL EFFECTS OF INHALED PLUTONIUM, 40
BEAGLE DOGS WERE GIVEN A SINGLE 10- TO 30-MIN EXPOSURE TO PU(239)O2 AEROSOLS. THIRTEEN DOGS
DIED OR WERE SACRIFICED WHEN CLINICAL SIGNS INDICATED THAT DEATH WAS IMMINENT 29 TO 66 MONTHS
POSTEXPOSURE. THE BODY BURDENS AT DEATH RANGED FROM 0.5 TO 3 MICROCURIES WITH 40 TO 75
PERCENT OF THE BODY BURDEN IN THE LUNGS, AND 20 TO 50 PERCENT IN THE BRONCHIAL AND
MEDIASTINAL LYMPH NODES. THE LIVER CONTAINED 2 TO 21 PERCENT, AND THE SKELETON, 1 TO 7.

*BIOLOGICAL CONCENTRATION, ANIMAL + *BIOMEDICAL + *PLUTONIUM + AEROSOL + CHEMICAL TOXICITY + INHALATION +
PLUTONIUM DIOXIDE

15-11780 CROCKER GR
RADIOCHEMICAL DATA CORRELATIONS FOR SEAWATER AND CORAL-SURFACE BURSTS
NAVAL RADIOLOGICAL DEFENSE LABORATORY, SAN FRANCISCO
USNRDL-TR-991 +. 32 PAGES, 4 FIGURES, TABLES, 2 REFERENCES, JANUARY 22, 1966, CFSTI \$2.00 CY, \$0.50 MN

RADIOCHEMICAL DATA ON FALLOUT SAMPLES FROM THREE HIGH-YIELD SURFACE BURSTS HAVE BEEN
CORRELATED BY A METHOD OF LOG-LOG PLOTTING. THE CORRELATIONS WERE COMPARABLE WITH THOSE
AVAILABLE FOR SIMILAR BURST CONDITIONS. THE RESULTS PRESENTED IN THIS REPORT CONFIRM THE
UTILITY OF THE METHOD AND INDICATE THE STRONG EFFECTS OF FRACTIONATION ON THE RADIOCHEMICAL
COMPOSITION OF FALLOUT FROM SURFACE BURSTS.

*FALLOUT + *ISOTOPIC FRACTIONATION + *NUCLEAR DETONATION + *NUCLEAR EXPLOSION DEBRIS + OCEAN AND SEA

15-11782 LAUMETS E

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11782 *CONTINUED*

TIME HISTORY OF BIOLOGICAL RESPONSE TO IONIZING RADIATION
NAVAL RADIOLOGICAL DEFENSE LABORATORY, SAN FRANCISCO

AD-626996 + USNRDL-TR-905 +. 42 PAGES, 12 FIGURES, 6 TABLES, 4 REFERENCES, NOVEMBER 22, 1965, CFSTI \$2.00
CY, \$0.50 MN

EXPOSURE OF PERSONNEL TO INITIAL IONIZING RADIATION FROM A NUCLEAR AIR OR SURFACE BURST CAN CAUSE BOTH PROMPT AND DELAYED CASUALTIES. THEIR PERCENTAGES AND TIMES TO INCAPACITATION (OR COMBAT INEFFECTIVENESS, IN A MILITARY SENSE) AFTER EXPOSURE CAN BE OF MAJOR SIGNIFICANCE IN MILITARY OPERATIONS. AVAILABLE NUCLEAR-ACCIDENT DATA AND OTHER DATA ON HUMAN EXPOSURES ARE USED TO OBTAIN CURVES TO REPRESENT THE ESTIMATED TIME HISTORY OF THE ACUTE-RADIATION SYNDROME AS A FUNCTION OF DOSE RECEIVED IN A VERY SHORT TIME. EMPHASIS IS PUT ON THE TIME AFTER EXPOSURE OF THE ONSET OF THE INITIAL STAGE OF RADIATION SICKNESS (NAUSEA, VOMITING, MALAISE, ETC), DURATION OF THE INITIAL STAGE, START AND DURATION OF THE FOLLOWING ASYMPTOMATIC LATENT PERIOD, TIME OF ONSET OF THE SECOND (OR MANIFEST ILLNESS) STAGE, AND TIME OF EVENTUAL RECUPERATION OR DEATH. THE ESTIMATED TIME HISTORY IS DEPICTED GRAPHICALLY WITH TWO OTHER TIME HISTORIES FOR COMPARISON. ANALYTICAL EXPRESSIONS ARE DERIVED FOR THE THREE TIME HISTORIES FOR USE IN ESTIMATING ANY OF THESE SYNDROME TIMES OF PERIODS.

*DOSE + *PERSONNEL EXPOSURE, RADIATION + MATHEMATICAL STUDY + RADIATION EFFECT

15-11783 BUSH WR

HEALTH PHYSICS PLANNING FOR CHANGING THE NRU REACTOR VESSEL
ATOMIC ENERGY OF CANADA LTD., CHALK RIVER

AECL-2420 + CONF-660520-1 +. 35 PAGES, 2 FIGURES, 43 REFERENCES, FROM INTERNATIONAL SYMPOSIUM ON THE DECONTAMINATION OF NUCLEAR INSTALLATIONS, HARWELL, ENGLAND, MAY 4-6, 1966, AECL \$1.00 CY

THE NRU REACTOR VESSEL IS CORRODING SLOWLY AND EVENTUALLY MUST BE REPLACED. THE RADIATION HAZARDS EXPECTED DURING THE REPLACEMENT AND THE CORRESPONDING PRECAUTIONS THAT MUST BE TAKEN ARE DISCUSSED. DUMMY RUNS WILL BE MADE WITH A FULL-SIZE MODEL BEFORE THE RADIOACTIVE VESSEL IS HANDLED. A DIFFICULT PLANNING PROBLEM WILL BE THAT OF RECONCILING THE AVAILABLE MAN-REMS OF EXPOSURE WITH THE MAN-REMS OF EXPOSURE REQUIRED DURING THE SEVEN-MONTH VESSEL-CHANGE OPERATION. THE VESSEL CHANGE WILL PROVIDE AN OPPORTUNITY TO OBTAIN HEALTH-PHYSICS INFORMATION AND EXPERIENCE AND TO REAPPRAISE THE WORTH OF DEVICES SUCH AS ALARMS, DOSIMETERS, THE RESPIRATOR FIT-TEST APPARATUS, AND THE MOBILE CHANGE AND SHOWER ROOM.

*RADIATION SAFETY AND CONTROL + CANADA + DECONTAMINATION + DOSIMETRY, GENERAL +
NRU (CHALK RIVER NATURAL URANIUM REACTOR) + PERSONNEL EXPOSURE, RADIATION

15-11800 DUNSTER HJ + DUNCAN KP + DOLPHIN GW + LEGGE IK

ACCIDENTAL EXPOSURES TO IONISING RADIATIONS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AHSB(RP)R-71 +. 20 PAGES, 2 TABLES, 25 REFERENCES, PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, NICE, APRIL 26-29, 1966, UKAEA

THREE PAPERS PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, APRIL 26-29, 1966. TITLES - (1) LESSONS TO BE DRAWN FROM SOME IRRADIATION ACCIDENTS IN THE UNITED KINGDOM, (2) EARLY MEASURES IN THE CARE OF PERSONS ACCIDENTALLY OVEREXPOSED TO IONIZING RADIATION, (3) DOSE ASSESSMENT FOLLOWING ACCIDENTAL INTAKE OF RADIOACTIVE MATERIAL.

*INCIDENT, ACTUAL, GENERAL + *OPERATING EXPERIENCE + *SAFETY PRINCIPLES AND PHILOSOPHY +
DOSE CALCULATION, INTERNAL + DOSE MEASUREMENT, INTERNAL + RADIATION INJURY, TREATMENT OF + UNITED KINGDOM

15-11802 DUNCAN KP

PAPER NO. 2 - EARLY MEASURES IN THE CARE OF PERSONS ACCIDENTALLY OVEREXPOSED TO IONIZING RADIATIONS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AHSB(RP)R-71 +. 3 PAGES, 25 REFERENCES, 1966, PAGES 10-12 OF ACCIDENTAL EXPOSURES TO IONIZING RADIATIONS, PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, APRIL 26-29, 1966, UKAEA

BRIEF DISCUSSION OF EXTERNAL RADIATION AND INTERNAL CONTAMINATION PROBLEMS.

*RADIATION INJURY, TREATMENT OF + CONTAMINATION + UNITED KINGDOM

15-11803 DOLPHIN GW

PAPER NO. 3 - DOSE ASSESSMENT FOLLOWING ACCIDENTAL INTAKE OF RADIOACTIVE MATERIALS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AHSB(RP)R-71 +. 6 PAGES, 2 TABLES, 25 REFERENCES, 1966, PAGES 13-18 OF ACCIDENTAL EXPOSURES TO IONIZING RADIATIONS, PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, APRIL 26-29, 1966, UKAEA.

DISCUSSES PROBLEMS OF SOLUBLE AND INSOLUBLE MATERIAL ABSORBED BY WOUNDS OR INHALED, AND TWO NEW BIOLOGICAL INDICATORS OF EXPOSURE.

*DOSE CALCULATION, INTERNAL + *DOSE MEASUREMENT, INTERNAL + INCIDENT, ACTUAL, RECOVERY FROM +
UNITED KINGDOM

15-11809 LEE, PK + FULTYN RV

KIWI TRANSIENT NUCLEAR TEST DOSE RATE SURVEY
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO

LA-3519 +. 51 PAGES, 2 TABLES, 24 FIGURES, MARCH 1966, CFSTI \$3.00 CY, \$0.50 MN

ACCESSION NUMBER 15-11782 TO 15-11809

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11809 *CONTINUED*

FOLLOWING THE KIWI TNT EVENT, INTENSIVE, ACCURATE DOSE-RATE SURVEYS WERE TAKEN OF THE CONTAMINATED AREAS SURROUNDING THE TEST POINT. THE DATA COLLECTED DURING THESE SURVEYS, AND DECAY RELATIONSHIPS DERIVED THEREFROM, ARE PRESENTED.

*DOSE MEASUREMENT, EXTERNAL + *SURVEY, RADIATION, ENVIRONMENTAL + KIWI TNT (TRANSIENT NUCLEAR TEST) + NUCLEAR ROCKET + REACTOR, SAFETY RESEARCH + REACTOR, SPACE + ROVER PROGRAM

15-11810 BECK HL + LOWDER WM + BENNETT BG + CONDON WJ

FURTHER STUDIES OF EXTERNAL ENVIRONMENTAL RADIATION

NEW YORK OPERATIONS OFFICE AEC, HEALTH AND SAFETY LABORATORY

HASL-170 +. 53 PAGES, 4 FIGURES, 4 TABLES, 24 REFERENCES, MARCH 1966, CFSTI \$3.00 CY, \$0.50 MN.

SPECTROMETRIC TECHNIQUES FOR MEASURING TOTAL AND INDIVIDUAL COMPONENT GAMMA DOSE RATES FROM NATURALLY OCCURRING AND FALLOUT EMITTERS ARE ELABORATED UPON AND EXTENDED TO NEW APPLICATIONS. CALIBRATION OF HIGH-RESOLUTION 4- X 4-IN. NAI (TI) DETECTORS FOR SUCH MEASUREMENTS IS DESCRIBED. FIELD STUDIES UTILIZING THESE TECHNIQUES DURING 1965, INCLUDING MEASUREMENTS OF GAMMA DOSE RATES AT APPROXIMATELY 50 GROUND SITES SCATTERED AROUND THE UNITED STATES AS WELL AS ON HIGH ALTITUDE LAKES AND IN DEEP MINES, ARE SUMMARIZED AND THE DATA PRESENTED IN FULL. THESE RESULTS PROVIDE USEFUL INFORMATION RELEVANT TO CONTINUING STUDIES OF THE APPLICATION OF FIELD SPECTROMETRY TO THE RAPID ASSESSMENT OF FALLOUT DEPOSITION, PARTICULARLY CS-137, THE VARIATIONS OF NATURAL GAMMA DOSE RATE WITH TIME, AND THE CONTRIBUTIONS OF SOIL BETA ACTIVITY AND COSMIC RADIATION TO FREE-AIR IONIZATION NEAR THE AIR-GROUND INTERFACE. A DETAILED DESCRIPTION OF THE ARGON-FILLED HIGH PRESSURE IONIZATION CHAMBER USED FOR TOTAL DOSE RATE MEASUREMENTS IS PRESENTED.

*SPECTROMETRY, GAMMA + *SURVEY, RADIATION, ENVIRONMENTAL + CESIUM + DOSE MEASUREMENT, EXTERNAL + FALLOUT + GROSS BETA + INSTRUMENTATION CALIBRATION + SOIL, NUCLIDE OCCURRENCE

15-11811 FEASIBILITY STUDY FOR A MOBILE LABORATORY TO EVALUATE ENVIRONMENTAL RADIATION CONTAMINATION

EDGERTON, GERMESHAUSEN AND GRIER, INC., SANTA BARBARA, CALIFORNIA

AFRRI-CR-66-1 + AD-636571 +. 139 PAGES, JANUARY 1966 (REPORT ORIGINALLY ISSUED MAY 1964), CFSTI \$4.00 CY, \$1.00 CY

A STUDY OF THE LABORATORY REQUIREMENTS NECESSARY FOR EVALUATING RADIOACTIVE CONTAMINATION OF FOOD, WATER AND BIOLOGICAL SPECIMENS HAS BEEN COMPLETED. FROM THE INFORMATION OBTAINED, A MOBILE LABORATORY FACILITY WITH THE CAPABILITY OF QUALITATIVE AND QUANTITATIVE ANALYSES OF MILLIMICROCURIE AMOUNTS OF ALPHA, BETA AND GAMMA EMITTING RADIOISOTOPE CONTAMINANTS HAS BEEN DESIGNED. THE LABORATORY UTILIZES SUFFICIENT SHIELDING SO THAT ALL ANALYSES CAN BE PERFORMED IN A TWO-MILLIROENTGEN-PER-HOUR GAMMA RADIATION FIELD AND WHERE THE AVERAGE GAMMA ENERGY IS 1 MEV.

*SURVEY, RADIATION, ENVIRONMENTAL + ANALYTICAL TECHNIQUE, FOOD + ANALYTICAL TECHNIQUE, GENERAL + ANALYTICAL TECHNIQUE, GENERAL + ANALYTICAL TECHNIQUE, WATER + COUNTER + FALLOUT + GROSS ALPHA + GROSS BETA + GROSS GAMMA + MONITOR, RADIATION, GENERAL + SURVEY, RADIATION, EMERGENCY

15-11812 PERRY DR

NEUTRON DOSIMETRY METHODS AND EXPERIENCE ON THE 7 GEV PROTON SYNCHROTRON, NIMROD

RUTHERFORD HIGH ENERGY LABORATORY

RPP-R-2 + CONF-660,807-2 +. 22 PAGES, SEPTEMBER 1966, PRESENTED AT IAEA SYMPOSIUM ON NEUTRON MONITORING FOR RADIOLOGICAL PROTECTION, VIENNA, AUGUST 29-SEPTEMBER 2, 1966, DEP. MN

THIS PAPER DESCRIBES AND DISCUSSES THE METHODS WHICH HAVE BEEN USED, AND THE RESULTS OBTAINED, IN MEASUREMENTS OF NEUTRON FLUX, DOSE EQUIVALENT, DOSE RATE, AND ENERGY SPECTRUM. THESE METHODS INCLUDE THRESHOLD ACTIVATION DETECTORS, MODERATED FOILS, PHOTOGRAPHIC FILMS, NUCLEAR TRACK EMULSION, THERMOLUMINESCENT DETECTORS, PROTON RECOIL COUNTERS, BF3 COUNTERS, AND LII SCINTILLATORS IN VARIOUS MODERATING ASSEMBLIES, AND IONIZATION CHAMBERS. THE SUITABILITY OF DIFFERENT DETECTORS FOR FIXED-POINT MEASUREMENTS, ROUTINE SURVEYS, PERSONAL DOSIMETRY, AND SPECIAL INVESTIGATIONS HAS BEEN ASSESSED BY TRIALS AND INTERCOMPARISONS IN TYPICAL NIMROD FIELDS AND WITH STANDARD SOURCES.

*ACCELERATOR + *DOSE + DOSIMETRY, GENERAL + DOSIMETRY, PHOTOGRAPHIC + DOSIMETRY, THERMOLUMINESCENCE + NEUTRON + RADIATION SAFETY AND CONTROL + SHIELDING

15-11813 BRAMSON PE

A SYSTEM FOR CONTINUOUS MONITORING OF DOSE RATE TO THE G. I. TRACT FROM DRINKING WATER

BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON

BNWL-SA-212 +. 11 PAGES, JUNE 7, 1965, CFSTI \$1.00 CY, \$0.50 MN

DRINKING WATER SUPPLIES MAY BE CONTINUOUSLY MONITORED FOR GASTROINTESTINAL-TRACT DOSE DUE TO RADIONUCLIDES BY APPROPRIATELY DESIGNED RADIATION DETECTION EQUIPMENT. THE EQUIPMENT CONSISTS OF A HOLLOW CYLINDRICAL PLASTIC SCINTILLATOR COUPLED TO A PHOTOMULTIPLIER TUBE, PULSE-HEIGHT DISCRIMINATOR, SOLID-STATE AMPLIFIER, AND COUNTER. A 0.5-LITER-PER-MINUTE CONTINUOUS SAMPLE OF THE DRINKING WATER IS CIRCULATED THROUGH THE SCINTILLATOR CAVITY. THE COUNT RATE OUTPUT IS PROPORTIONAL TO THE DOSE RATE FOR AS-76, CR51, CU64, NA24, NP239, P32, SC46 AND ZN65. THIS PROPORTIONALITY IS ACHIEVED BY A PROPERLY CHOSEN SCINTILLATOR SHAPE, SCINTILLATOR SURFACE-TO-VOLUME RATIO, AND PULSE-HEIGHT-DISCRIMINATION LEVEL.

*DOSE MEASUREMENT, INTERNAL + *MONITOR, RADIATION, LIQUID + *WATER, DRINKING + DOSE + INSTRUMENTATION, RADIATION MONITORING

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11814 RAHM G
MEDICAL EXPERIENCE FOLLOWING THE GERMAN FIRST RADIATION PROTECTION REGULATION
1 PAGE, ATOMWIRTSCHAFT 11(3), PAGE 124, MARCH 1966, IN GERMAN

A MEDICAL-FITNESS EXAMINATION AND SUBSEQUENT EXAMINATION AT SPECIFIED INTERVALS PRESCRIBED IN THE GERMAN FEDERAL REPUBLIC BY THE 1ST RADIATION PROTECTION REGULATION (1ST SSVG) OF 1960 FOR THOSE DEALING WITH OPEN RADIOACTIVE SOURCES OR WORKING IN CONTROLLED AREAS. EXPERIENCE GAINED FROM THESE EXAMINATIONS AND THE IMPLICATIONS FOR RADIATION PROTECTION ARE DESCRIBED IN THE LIGHT OF THE RESULTS OBTAINED DURING 1964 IN NORTH-RHINE WESTPHALIA.

*BIOMEDICAL + *RADIATION SAFETY AND CONTROL + GERMANY + PERSONNEL EXPOSURE, RADIATION + RADIATION PROTECTION, ORGANIZATION

15-11818 ASSAY OF 90SR IN HUMAN BONE IN THE UNITED KINGDOM
MEDICAL RESEARCH COUNCIL, LONDON
NP-16050 (PT. 1) +. 19 PAGES, 2 FIGURES, 8 TABLES, 7 REFERENCES, MEDICAL RESEARCH COUNCIL, MONITORING REPORT NO. 12, FEBRUARY 1966, BIS \$0.60 CY

THIS REPORT PRESENTS RESULTS OF ASSAYS OF STRONTIUM-90 IN SAMPLES OF HUMAN BONE OBTAINED MAINLY FROM SUBJECTS WHO DIED IN THE FIRST HALF OF 1965. THE WORK CARRIED OUT BY THE UNITED KINGDOM ATOMIC ENERGY AUTHORITY IN THE COURSE OF THE NATIONAL SURVEY OF THE EFFECTS OF RADIOACTIVE FALLOUT IS REPORTED. THIS IS FOLLOWED BY SOME ADDITIONAL RESULTS FOR 1963 AND 1964, OBTAINED BY THE UKAEA FROM BONE SAMPLES FROM INDIVIDUALS WHO HAD BEEN RESIDENT IN LONDON OR ITS ENVIRONS.

*BIOLOGICAL CONCENTRATION, MAN + *STRONTIUM + BIOMEDICAL + FALLOUT + UNITED KINGDOM

15-11819 HARDY EP + RIVERA J
FALLOUT PROGRAM QUARTERLY SUMMARY REPORT. DECEMBER 1, 1965-MARCH 1, 1966
NEW YORK OPERATIONS OFFICE USAEC, HEALTH AND SAFETY LABORATORY
HASL-171 +. 430 PAGES, 22 TABLES, 8 FIGURES, 9 REFERENCES; APRIL 1, 1966, CFSTI \$7.30 CY, \$2.00 MN

THIS REPORT PRESENTS CURRENT DATA FROM THE HASL FALLOUT PROGRAM, THE NEW ZEALAND DEPARTMENT OF SCIENTIFIC AND INDUSTRIAL RESEARCH, THE NEW ZEALAND NATIONAL RADIATION LABORATORY, ARGONNE NATIONAL LABORATORY, U. S. NAVAL RADIOLOGICAL DEFENSE LABORATORY AND THE USDA SOIL CONSERVATION SERVICE. RADIONUCLIDE LEVELS IN FALLOUT, MILK, TAP WATER, DIET, SURFACE AND HIGH ALTITUDE AIR, ARE GIVEN IN TABULAR FORM. ALSO INCLUDED ARE INTERPRETIVE REPORTS AND NOTES DEALING WITH FALLOUT IN THE PACIFIC OCEAN, DEPTH DISTRIBUTION OF STRONTIUM-90 IN SOIL, DEVELOPMENT OF A SOIL STRONTIUM-90 METHOD, STRONTIUM-90 CONTAMINATION OF REAGENTS USED IN SEA-WATER ANALYSES, AND THE TRANSFER OF FALLOUT STRONTIUM-90 TO COWS MILK. A BIBLIOGRAPHY OF RECENT PUBLICATIONS RELATED TO NUCLEAR DEBRIS STUDIES IS PRESENTED.

*FALLOUT + *SURVEY, RADIATION, ENVIRONMENTAL + AIR + BIOLOGICAL CONCENTRATION, FOOD + BIOLOGICAL CONCENTRATION, GENERAL + BIOLOGICAL CONCENTRATION, MILK + CADMIUM + NEW ZEALAND + NUCLEAR EXPLOSION DEBRIS + OCEAN AND SEA + RAINOUT + SAMPLING + SOIL, NUCLIDE OCCURRENCE + STRATOSPHERE + STRONTIUM + SURFACE WATER, NUCLIDE OCCURRENCE

15-11821 PAUL RA + DAY WC
TRACE ELEMENTS IN COMMON ROCK TYPES AND THEIR RELATIVE IMPORTANCE IN NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS
ARMY ENGINEER NUCLEAR CRATERING GROUP, LIVERMORE, CALIFORNIA
PNE-5006 +. 31 PAGES, 9 TABLES, 6 FIGURES, 61 REFERENCES, JUNE 1966, CFSTI \$1.50 CY, \$0.50 MN

A LITERATURE SEARCH WAS UNDERTAKEN TO DETERMINE THE AVERAGE AND RANGE OF CONTENT OF TRACE ELEMENTS IN COMMON ROCK TYPES TO PERMIT AN EVALUATION OF THEIR RELATIVE IMPORTANCE IN NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS. THE ELEMENTS CONSIDERED IN THE STUDY WERE DY, GD, EU, SM, ND, CD, AG, CO, CR, V, SC, CL, S, B, AND LI. DATA ARE REPORTED GIVING CONTENT OF THESE ELEMENTS IN TEN IGNEOUS ROCK TYPES AND THREE SEDIMENTARY ROCK TYPES. THE FIVE ELEMENTS GD, EU, SM, B, AND CL WERE FOUND TO OCCUR IN MOST ROCK TYPES IN QUANTITIES WHICH WOULD SIGNIFICANTLY AFFECT NEUTRON-INDUCED RADIOACTIVITY CALCULATIONS. CALCULATIONS OF INDUCED RADIOACTIVITY WERE PERFORMED FOR GRANITE USING MAXIMUM, AVERAGE, AND MINIMUM TRACE ELEMENT VALUES OBTAINED FROM THE LITERATURE SEARCH. CALCULATIONS WERE ALSO PERFORMED USING AVERAGE TRACE ELEMENT VALUES FOR FOUR OTHER IGNEOUS ROCKS AND TWO SEDIMENTARY ROCKS. IT IS CONCLUDED THAT, IN GENERAL, USE OF THE AVERAGE VALUES FOR TRACE ELEMENTS PRESENTED IN THIS REPORT IS ADEQUATE FOR ASSESSING THE PRODUCTION QUANTITIES OF RADIONUCLIDES INDUCED EXTERNAL TO THE DEVICE FOR USE IN FEASIBILITY STUDIES FOR LARGE SCALE EXCAVATION PROJECTS AND OTHER UNDERGROUND NUCLEAR DETONATIONS WHEN DETAILED CHEMICAL ANALYSES OF EMPLACEMENT MEDIA ARE NOT AVAILABLE.

*ACTIVATION PRODUCT + *PLOWSHARE PROGRAM + GEOLOGICAL CONSIDERATION, GEOCHEMICAL + NEUTRON + NUCLEAR DETONATION

15-11822 BACKGROUND FOR MILK RADIOACTIVITY REPORTS
U.S. DEPT. OF HEALTH, EDUCATION, AND WELFARE
PRESS REL. HEW-K50 +. 5 PAGES, 1 TABLE, APRIL 1966, DPI

THIS PUBLICATION PROVIDES THE MOST RECENT INFORMATION AVAILABLE CONCERNING CONCENTRATIONS OF RADIOACTIVITY IN MILK SAMPLES COLLECTED AT THE STATIONS OF THE NATIONAL PASTEURIZED MILK NETWORK OPERATED BY THE PUBLIC HEALTH SERVICE IN COOPERATION WITH STATE AND LOCAL GOVERNMENT AGENCIES. EVERY STATE IS REPRESENTED IN THE NETWORK.

*BIOLOGICAL CONCENTRATION, MILK + *SURVEY, RADIATION, USPHS + FALLOUT + IODINE +

ACCESSION NUMBER 15-11814 TO 15-11822

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11822 *CONTINUED*
RADIATION SAFETY AND CONTROL + STRONTIUM

15-11825 STROSCHEIN HW + MAESER PH
HEALTH PHYSICS TECHNICIAN TRAINING MANUAL
PHILLIPS PETROLEUM COMPANY, IDAHO
IDO-17182 +. 289 PAGES, 61 FIGURES, 12 TABLES, 16 REFERENCES, JUNE 1966, CFSTI \$7.00 CY

THIS MANUAL IS DESIGNED AS A TEXT FOR THE FORMAL TRAINING OF HEALTH PHYSICS TECHNICIANS AND SO ARRANGED THAT IT MAY BE SUPPLEMENTED WITH SPECIFIC COMPANY POLICY. THE GENERAL PRINCIPLES OF RADIATION SAFETY COVERED INCLUDE THE BASIC PRINCIPLES OF RADIATION, DOSE DETERMINATION AND LIMITS, BIOLOGICAL EFFECTS OF RADIATION, RADIATION DETECTION INSTRUMENTATION, CONTAMINATION CONTROL, DECONTAMINATION, AND EMERGENCY ACTIONS. GENERAL INFORMATION IS ALSO INCLUDED ON NONRADIOLOGICAL SAFETY OFTEN ASSOCIATED WITH HEALTH PHYSICS WORK.

*RADIATION PROTECTION, ORGANIZATION + *RADIATION SAFETY AND CONTROL + CONTAMINATION + DECONTAMINATION + DOSE + DOSIMETRY, GENERAL + INSTRUMENTATION, RADIATION MONITORING + MONITOR, RADIATION, GENERAL + RADIATION EFFECT + SAFETY PRINCIPLES AND PHILOSOPHY + SAFETY STUDY + SHIPPING CONTAINER + SURVEY, RADIATION, ENVIRONMENTAL + TRANSPORTATION AND HANDLING + WASTE DISPOSAL, GENERAL

15-11826 BENTON EV + COLLVER MM
CHARGED PARTICLE TRACKS IN POLYMERS. NUMBER 2. REGISTRATION OF HEAVY IONS DURING THE FLIGHT OF GEMINI VI
NAVAL RADIOLOGICAL DEFENSE LABORATORY, SAN FRANCISCO, CALIFORNIA
USNRDL-TR-1037 +. 26 PAGES, 5 FIGURES, 7 REFERENCES, JUNE 23, 1966, DDC, CFSTI

SEVERAL SMALL DISKS OF CELLULOSE NITRATE PLASTIC WERE INCLUDED AS A PART OF A DOSIMETRY PACKAGE ABOARD THE GEMINI VI SPACECRAFT TO RECORD THE HEAVY COMPONENT OF THE PRIMARY COSMIC RADIATION. AN AVERAGE OF 10 TRACKS PER SQ. CM PER DAY WAS FOUND IN THE PLASTIC DETECTORS. MOST WERE JUDGED TO BE TRACKS OF HEAVY RECOIL IONS - ABOUT 1 TRACK PER SQ. CM PER DAY WAS THOUGHT TO BE DUE TO THE PRIMARY COSMIC RAY PARTICLES.

*COSMIC RADIATION + *SPACECRAFT + DOSIMETRY, GENERAL

15-11827 MARCOWITZ SM + WHEELER RV + LUCKS H
MEASUREMENT OF BEAM PROFILES WITH THERMOLUMINESCENT DOSIMETERS
ARGONNE NATIONAL LABORATORY, ARGONNE, ILL.
ANL-7196 +. 9 PAGES, 7 FIGURES, 3 REFERENCES, APRIL 1966, CFSTI \$1.00 CY, \$0.50 MN

THERMOLUMINESCENT DOSIMETERS WERE USED TO DETERMINE THE PROFILE OF THE 12.5-BEV EXTERNAL BEAM OF THE ZERO GRADIENT SYNCHROTRON AT ARGONNE NATIONAL LABORATORY. THE NUMBER OF PARTICLES IN THE BEAM, THEIR DISTRIBUTION, AND THE SHAPE OF THE BEAM WERE DETERMINED. THE RESULTS WERE IN EXCELLENT AGREEMENT WITH THOSE OBTAINED BY OTHER METHODS USED FOR DETERMINATION OF BEAM PROFILES. WITH ONLY ONE ACCELERATOR PULSE, A BEAM OF COMPARABLE SIZE, WITH INTENSITY UP TO 10(12TH) PARTICLES PER PULSE AND AS LOW AS 10(6TH) COULD BE ANALYZED.

*ACCELERATOR + *DOSIMETRY, THERMOLUMINESCENCE + RADIATION SAFETY AND CONTROL

15-11828 MCCLENDON L
ON-SITE RADIOLOGICAL SAFETY REPORT. PROJECT SULKY
REYNOLDS ELECTRICAL AND ENGINEERING CO., INC., MERCURY, NEV.
PNE-7117F +. 59 PAGES, 17 FIGURES, 13 TABLES, JULY 1965, CFSTI \$2.00 CY, \$0.75 MN

THE SULKY EVENT WAS DETONATED AT THE NEVADA TEST SITE ON DECEMBER 1964. THE TEST WAS CONDUCTED BY THE LAWRENCE RADIATION LABORATORY TO EXPLORE PEACEFUL USES OF NUCLEAR EXPLOSIONS AS A PART OF THE PLOWSHARE PROGRAM. APPROPRIATE PRECAUTIONS WERE TAKEN TO PROTECT INDIVIDUALS FROM UNNECESSARY EXPOSURE TO RADIATION. REMOTE RADIATION MEASUREMENTS WERE TAKEN DURING AND AFTER THE EVENT BY A TELEMETRY SYSTEM, AND MONITORS WITH PORTABLE INSTRUMENTS SURVEYED THE ROUTE INTO GROUND ZERO BEFORE OTHER ENTRIES WERE MADE. CONTINUOUS MONITORING WAS PROVIDED WHILE PERSONS WERE IN THE AREA. NO ONE RECEIVED A RADIATION DOSE GREATER THAN 100 MR, AND MEASUREMENTS INDICATED THAT NO CONCENTRATIONS OF TOXIC GASES OR EXPLOSIVE MIXTURES EXISTED IN THE WORK AREA.

*PLOWSHARE PROGRAM + *RADIATION SAFETY AND CONTROL + DOSE MEASUREMENT, EXTERNAL + FALLOUT + MONITOR, RADIATION, AIR + MONITOR, RADIATION, NUCLEAR DETONATION + MONITOR, RADIATION, PERSONNEL + NUCLEAR DETONATION + SAMPLING

15-11829 FINAL REPORT OF OFF-SITE SURVEILLANCE FOR PROJECT SULKY
PUBLIC HEALTH SERVICE, LAS VEGAS
PNE-715F +. 14 PAGES, 1 FIGURE, 2 TABLES, MARCH 9, 1965, CFSTI \$1.00 CY, \$0.50 MN

THE U.S. PUBLIC HEALTH SERVICE PROVIDED OFF-SITE MONITORING FOR PROJECT SULKY, WHICH WAS CONDUCTED AT 1135 HOURS ON DECEMBER 18, 1964. THE HIGHEST GAMMA DOSE RATE RECORDED OFF-SITE WAS 0.06 MR/HR, AND NO FRESH FISSION PRODUCTS WERE DETECTED IN AIR, WATER, OR MILK SAMPLES COLLECTED AFTER THE EXPERIMENT. NO EXPOSURES EXCEEDED THOSE LISTED IN THE RADIOLOGICAL SAFETY GUIDES OF CHAPTER 0524 IN THE AEC MANUAL.

*MONITOR, RADIATION, NUCLEAR DETONATION + *PLOWSHARE PROGRAM + DOSE MEASUREMENT, EXTERNAL + FALLOUT + MONITOR, RADIATION, AIR + MONITOR, RADIATION, ENVIRONMENTAL + MONITOR, RADIATION, PERSONNEL + NUCLEAR DETONATION + SAMPLING + SURVEY, RADIATION, USPHS

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11831 PERTSOV LA
THE CONTENT OF NATURAL FISSION RADIOISOTOPES IN THE BIOSPHERE
AEC-TR-6408 +. 5 PAGES, 2 TABLES, 9 REFERENCES, RADIOBIOLOGY 4(4), PAGES 175-179, (1964), CFSTI \$6.00 CY, \$1.00 MN

CALCULATED RESULTS INDICATE VERY LOW LEVELS OF NATURAL SR-90 AND CS-137 IN VARIOUS CONSTITUENTS OF THE BIOSPHERE AND HENCE AN EXCEEDINGLY SLIGHT IRRADIATION EFFECT ON HUMAN TISSUES. HOWEVER, IT FOLLOWS THAT THE NATURAL RADIOACTIVITY OF THE BIOSPHERE INCLUDES A WHOLE GROUP OF FISSION RADIOISOTOPES WHICH WERE NOT FORMERLY TAKEN INTO ACCOUNT IN THE CLASSIFICATION OF NATURAL EMITTERS. IN ADDITION TO SR-90 AND CS-137, THIS GROUP PROBABLY INCLUDES RU-106, CE-144, AND PM-147, PLUS SEVERAL OTHER ISOTOPES WITH RELATIVELY LONG HALF-LIVES.

*BIOLOGICAL CONCENTRATION, GENERAL + CESIUM + PROMETHIUM + RUTHENIUM + SOIL, NUCLIDE OCCURRENCE + STRONTIUM + THORIUM + URANIUM

15-11832 TYREE WH
A COMPACT, LOW-COST ALPHA COUNTER
DOW CHEMICAL COMPANY, GOLDEN COLORADO
REP-777 +. 4 PAGES, 2 FIGURES, AUGUST 17, 1966, CFSTI \$1.00 CY, \$0.50 MN

AN ALPHA COUNTER WITH METER READOUT IS DESCRIBED. THE COST OF THE COUNTER, INCLUDING AN AIR PROPORTIONAL DETECTOR AND RECHARGEABLE BATTERIES, IS LESS THAN 65 DOLLARS.

*COUNTER + GROSS ALPHA

15-11905 ACRS SUGGESTIONS ON AEC REACTOR SAFETY RESEARCH PROGRAM, OCTOBER 12, 1966
U. S. ATOMIC ENERGY COMMISSION
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 32-33 (OCTOBER 31, 1966)

(A) ACRS ATTACHES SPECIAL IMPORTANCE TO (1) STUDIES OF MOLTEN MASSES OF FUEL AND STRUCTURAL MATERIAL, (2) STUDIES OF EMERGENCY CORE COOLING PROCESSES, (3) PERIODIC PRESSURE-VESSEL INSPECTION, (4) PROPERTIES OF THICK STEEL PRESSURE-VESSEL SECTIONS, (5) PRESTRESSED CONCRETE PRESSURE VESSELS, AND (6) ADVANCED METHODS OF CALCULATING DESTRUCTIVE REACTIVITY TRANSIENTS IN WATER-COOLED REACTORS. (B) ACRS VIEWS AS OF CURRENT AND INCREASING SIGNIFICANCE (1) PRESSURE-VESSEL STEEL OTHER THAN A302B, (2) FRACTURE MECHANICS OF PRESSURE VESSELS, (3) REVIEW OF NONNUCLEAR EXPERIENCE ON PRIMARY COOLANT SYSTEM COMPONENTS, (4) STANDARD METHODS OF CALCULATING STANDARD ACCIDENTS, (5) RECYCLED PLUTONIUM FUEL, (6) EARLY DETECTION OF SMALL LEAKS IN PRIMARY COOLANT SYSTEMS, AND (7) WASTE DISPOSAL INTO SURFACE WATER, INCLUDING BIOLOGICAL CONCENTRATION, AS IN THE GREAT LAKES.

*ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + *RESEARCH CONTRACT + *SAFETY STUDY + ACCIDENT, REACTIVITY + BIOLOGICAL CONCENTRATION, GENERAL + CONTAINMENT, PRESSURE VESSEL + EMERGENCY COOLING + PLUTONIUM + WASTE DISPOSAL, RIVER

15-11955 BALLOU JE + PALOTAY JL
ORAL THERAPY FOR DEPOSITED PLUTONIUM
PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
9 PAGES, 6 FIGURES, 1 TABLE, 9 REFERENCES, HEALTH PHYSICS 12(7), PAGES 895-899, (JULY 1966)

EFFECTIVE ORAL THERAPY FOR PLUTONIUM IN RATS WAS OBTAINED WITH A TTHA DOSE OF 3-M-MOLES/KG ADMINISTERED 1 HR AFTER PLUTONIUM CITRATE INJECTION. DAILY ORAL ADMINISTRATION OF A 1.5 M-MOLES/KG DOSE, INITIATED 1 HR AFTER PLUTONIUM INJECTION AND CONTINUED FOR 9 DAYS, WAS ONLY marginally effective. MEASUREMENT OF THE ENHANCED EXCRETION OF PLUTONIUM IN THE BILE DURING PERFUSION OF DIFFERENT INTESTINAL SEGMENTS WITH CHELATING AGENTS INDICATED THAT THE AGENTS ARE ABSORBED PRIMARILY IN THE JEJUNUM AND ILEUM. MEANS OF PROMOTING ABSORPTION AND LIMITATIONS ON ORAL THERAPY ARE DISCUSSED.

*BIOLOGICAL CONCENTRATION, GENERAL + *PLUTONIUM + BIOMEDICAL + RADIATION PROTECTION, CHEMICAL

15-11956 YAMAGATA N + IINUMA TA
TOTAL BODY BURDEN OF CESIUM-137 IN JAPANESE IN 1964 AS ASSESSED BY BLOOD ANALYSIS
INSTITUTE OF PUBLIC HEALTH, TOKYO + NATIONAL INSTITUTE OF RADIOLOGICAL SCIENCES, CHIBA, JAPAN
7 PAGES, 4 TABLES, 1 FIGURE, 8 REFERENCES, HEALTH PHYSICS 12(7), PAGES 901-907 (JULY 1966)

RADIOCHEMICAL DETERMINATION OF CESIUM-137 IN POOLED WHOLE-BLOOD SAMPLES OBTAINED FROM BLOOD BANKS THROUGHOUT JAPAN WAS MADE. THE AVERAGE BODY BURDEN FOR APRIL - DECEMBER 1964 IS APPROXIMATELY 200 PC/KG BODY WEIGHT AS ASSESSED ON THE BASIS OF PARALLEL DETERMINATION OF THE BLOOD CONCENTRATION AND THE BODY BURDEN BY USE OF A COUNTER ON LABORATORY PERSONNEL. IN A NEAR-EQUILIBRIUM CONDITION BETWEEN THE DIET AND THE BODY, 1.3 PER CENT OF THE TOTAL BODY CESIUM-137 IS ESTIMATED TO BE IN BLOOD.

*CESIUM + *JAPAN + *POPULATION EXPOSURE + BIOLOGICAL CONCENTRATION, MAN

15-11957 DERUYTER AW + ATEN AH
GAMMA-EMITTING FALL-OUT NUCLIDES IN THE NETHERLANDS DIET
INSTITUUT VOOR KERNFYSIECH ONDERZOEK, OOSTER RINGDIJK, AMSTERDAM
7 PAGES, 3 TABLES, 3 FIGURES, 17 REFERENCES, HEALTH PHYSICS 12(7), PAGES 909-915 (JULY 1966)

A LOW-BACKGROUND GAMMA-COUNTER HAS BEEN CONSTRUCTED FOR THE MEASUREMENT OF SOME RADIONUCLIDES

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11957 *CONTINUED*

IN THE HUMAN DIET IN THE NETHERLANDS. THE QUANTITIES OF THE NUCLIDES CONSUMED DAILY ARE DETERMINED FROM THEIR CONCENTRATION IN URINE AND FECES. IN URINE K AND CS-137 ARE MEASURED, IN FECES K, CS-137, MN-54 AND CE-144. TO EXPLAIN THE EXCRETION OF THESE NUCLIDES THE SAME ISOTOPES ARE DETERMINED IN A SERIES OF FOODSTUFFS. THE ACTIVITIES OCCURRING IN THESE FOODSTUFFS SEEM TO BE IN ROUGH AGREEMENT WITH THE QUANTITIES EXCRETED. APART FROM THE NUCLIDES MENTIONED VEGETABLES ALSO CONTAIN SOME OTHER ACTIVITIES TWO OF WHICH HAVE BEEN RECOGNIZED AS BE-7 AND SB-125.

*BIOLOGICAL CONCENTRATION, FOOD + *NETHERLANDS + ANTIMONY + BERYLLIUM + CERIUM + CESIUM + DIETARY HABIT + FALLOUT + MANGANESE + POTASSIUM

15-11958 KOLEHMAINEN S + HASANEN E + MIETTINEN JK
CS-137 LEVELS IN FISH OF DIFFERENT LIMNOLOGICAL TYPES OF LAKES IN FINLAND DURING 1963
UNIVERSITY OF HELSINKI, FINLAND
6 PAGES, 2 FIGURES, 5 TABLES, 4 REFERENCES, HEALTH PHYSICS 12(7), PAGES 917-922 (JULY 1966)

THE LIMNOLOGICAL CHARACTERIZATION OF TWELVE LAKES AND THREE RIVERS IN DIFFERENT PARTS OF FINLAND AND CS-137 ANALYSES OF SEVERAL SPECIES OF FISH IN THESE LAKES AND RIVERS WERE CARRIED OUT. THE LAKES VARY FROM OLIGOTROPHIC (LOW-NUTRIENT) LAKES THROUGH DYS-OLIGOTROPHIC AND DYSEUTROPHIC TO FULLY EUTROPHIC (HIGH-NUTRIENT) LAKES. CORRESPONDINGLY, THE CONDUCTIVITY VARIES FROM 11 TO 79 MHO UNITS, THE COLOUR FROM 5 TO 100 MG PT/L., THE KMNO₄ CONSUMPTION FROM 8 TO 144 MG/L., AND THE CS-137 CONTENT IN DIFFERENT FISH SPECIES IN MORE OR LESS DIRECT RELATIONSHIP WITH THE DIMINISHING CONDUCTIVITY, E.G. PERCH (PERCA FLUVIATILIS) 0.2-20 NC/KG, PIKE (ESOX LUCIUS) 0.15-16 NC/KG, ROACH (LEUCISCUS RUTILUS) 0.1-7.5 NC/KG FRESH WEIGHT, THE HIGHEST VALUES BEING IN THE FISH OF OLIGOTROPHIC LAKES, WHICH WATERS HAVE A LOW ELECTROLYTIC CONDUCTIVITY. OTHER FACTORS AFFECTING THE CS-137 CONTENT OF THE FISH ARE ITS FEEDING HABITS AND THE GENERAL LIMNOLOGICAL CHARACTER OF THE WATERS. THE TOTAL GAMMA-ACTIVITY OF THE WATER VARIES ONLY SLIGHTLY AND THIS VARIATION EVIDENTLY IS NOT AN IMPORTANT CAUSE OF THE DIFFERENCES FOUND IN THE CS-137 CONTENT OF THE FISH.

*BIOLOGICAL CONCENTRATION, AQUATIC ORGANISMS + *CESIUM + *FINLAND + ECOLOGICAL CONSIDERATION + SURFACE WATER, NUCLIDE OCCURRENCE

15-11959 JENSON DK
SAMPLING CALCINER OFF-GAS FOR RADIOACTIVE RUTHENIUM USING A POLYETHYLENE ABSORBER
PHILLIPS PETROLEUM COMPANY, IDAHO FALLS, IDAHO
4 PAGES, 8 FIGURES, 11 REFERENCES, HEALTH PHYSICS 12(7), PAGES 923-926 (JULY 1966)

AN ABSORBER FOR SAMPLING GASEOUS RADIOACTIVE RUTHENIUM IN THE OFF-GAS WAS DEVELOPED. THIS ABSORBER SAMPLER CONSISTED OF A GLASS CARTRIDGE PACKED WITH ASTM TYPE II POLYETHYLENE PELLETS. THE AMOUNT OF RUTHENIUM ON THE SAMPLE WAS DETERMINED BY GAMMA COUNTING. CONTINUOUS RADIATION FIELD MEASUREMENTS PROVIDED CONSTANT MONITORING OF THE OFF-GAS RADIOACTIVITY LEVEL. PERFORMANCE OF THE ABSORBER SAMPLER WAS EVALUATED THROUGHOUT 10 MONTHS OF OPERATION. NO SPECIES OF RUTHENIUM WERE FOUND TO PASS THROUGH THE ABSORBER WITHOUT BEING COLLECTED. TEMPERATURE WAS FOUND TO HAVE A DEFINITE EFFECT ON ABSORBER EFFICIENCY. RU-106 LEVELS MEASURED IN THE OFF-GAS CAN BE CORRELATED WITH OPERATING DATA. THE MEASUREMENT OF RUTHENIUM DISCHARGED WAS SUPPORTED BY ANALYSES OF ENVIRONMENTAL AIRBORNE PARTICULATE AND VEGETATION SAMPLES. IT IS CONCLUDED THAT THE SYSTEM IS SATISFACTORY AND ADEQUATE FOR OFF-GAS RUTHENIUM SAMPLING.

*RUTHENIUM + *SAMPLING + ANALYTICAL TECHNIQUE, GAS + CALCINATION + EFFLUENT + IDAHO FALLS + MONITOR, RADIATION, GAS + MONITOR, RADIATION, SAMPLING + MONITOR, RADIATION, STACK

15-11960 BUTLER FE + BOULOGNE AR + WHITLEY EA
BIOASSAY AND ENVIRONMENTAL ANALYSES BY LIQUID ION EXCHANGE
SAVANNAH RIVER PLANT, AIKEN, SOUTH CAROLINA
7 PAGES, 3 TABLES, 4 FIGURES, 6 REFERENCES, HEALTH PHYSICS 12(7), PAGES 927-933 (JULY 1966)

LIQUID ION EXCHANGE HAS REPLACED SEVERAL SOLID ION EXCHANGE AND EXTRACTION PROCEDURES AT THE SAVANNAH RIVER PLANT (SRP). THE PRINCIPAL ADVANTAGE OF THE METHOD IS RAPIDITY. SEPARATION PROCEDURES ARE RELATIVELY SIMPLE. THE CATION EXCHANGER IS DI-2-ETHYLHEXYL PHOSPHORIC ACID (HDEHP) AND THE ANION EXCHANGER IS TRI-ISOOCTYLAMINE (TIOA). THE ION EXCHANGE CHARACTERISTICS OF THIRTY-SEVEN ELEMENTS WERE DETERMINED. HDEHP AND TIOA ARE USED TO SEPARATE RADIONUCLIDES WITH SIMILAR GAMMA ENERGIES PRIOR TO SPECTROMETRIC ANALYSES.

*ANALYTICAL TECHNIQUE, GENERAL + *ION EXCHANGE + BARIUM + CERIUM + CHROMIUM + COBALT + IODINE + NEPTUNIUM + PLUTONIUM + SPECTROMETRY, GAMMA

15-11961 PATTERSON HW + WALLACE R
REPORT ON A RADIATION SURVEY MADE IN EGYPT, INDIA AND CEYLON IN JANUARY 1963
LAWRENCE RADIATION LABORATORY, UNIVERSITY OF CALIFORNIA, BERKELEY, CALIFORNIA
6 PAGES, 3 TABLES, 10 REFERENCES, HEALTH PHYSICS 12(7), PAGES 935-941 (JULY 1966)

A RADIATION SURVEY HAS BEEN MADE IN THREE MONAZITE SAND AREAS IN AFRICA AND SOUTHERN ASIA, WITH SODIUM IODIDE DETECTORS, WHICH WERE DESIGNED TO ELIMINATE TO A LARGE EXTENT THE EFFECT OF COSMIC RAYS AND TO EMPHASIZE THE GAMMA-RAYS OF THE NATURAL ENVIRONMENT. THIS REPORT DEALS ONLY WITH THE PHYSICAL MEASUREMENTS MADE DURING THESE THREE SURVEYS, AND EVALUATES THE DOSE LEVELS THAT WERE INSTANTANEOUSLY PRESENT IN THESE AREAS. OTHER IMPORTANT QUESTIONS, SUCH AS INDIVIDUAL WHOLE-BODY AND INTERNAL EXPOSURES, THE NUMBER OF PEOPLE AND THE AMOUNT OF TIME THEY SPEND IN THE AREAS WHERE THE RADIATION SURVEYS WERE MADE, THE INTERPRETATION OF THEIR BIOLOGICAL CONDITION, AND ANY EFFECTS THE RADIATION FIELDS MAY HAVE ON THE POPULACE AS A

CATEGORY 15
ENVIRONMENTAL SURVEYS, MONITORING AND RADIATION EXPOSURE OF MAN

15-11961 *CONTINUED*
WHOLE, ARE BEING CAREFULLY INVESTIGATED BY THE GOVERNMENTS INVOLVED AND SOME RESULTS OF THESE INVESTIGATIONS HAVE ALREADY BEEN REPORTED.

*CEYLON + *EGYPT + *INDIA + *SURVEY, RADIATION, ENVIRONMENTAL + DOSE MEASUREMENT, EXTERNAL + POPULATION EXPOSURE

15-11973 TARDIFF RG + DUBOIS KP
FURTHER STUDIES ON THE EFFECTS OF VARIOUS DRUGS ON THE ADENOSINE TRIPHOSPHATASE ACTIVITY OF THE HEMATOPOIETIC TISSUES OF RATS EXPOSED REPEATEDLY TO COBALT-60 GAMMA RADIATION
UNIVERSITY OF CHICAGO, AIR FORCE RADIATION LABORATORY
AD-629,311 +. 14 PAGES, 7 TABLES, 12 REFERENCES, FROM QUARTERLY PROGRESS REPORT NO. 58 -- PAGE 1-14, JANUARY 15, 1966, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT CONCERNS MEASUREMENTS OF THE INFLUENCE OF VARIOUS DRUGS ON THE RADIATION-INDUCED INCREASE IN THE ADENOSINE TRIPHOSPHATASE ACTIVITY OF THE HEMATOPOIETIC TISSUES OF RATS EXPOSED TO DAILY DOSES OF COBALT-60 GAMMA RADIATION GIVEN AT THE RATE OF 46 R TO 54 R PER DAY.

*BIOMEDICAL + *RADIATION DAMAGE + *RADIATION INJURY, TREATMENT OF + DOSE + GROSS GAMMA + RADIATION PROTECTION, CHEMICAL

15-11974 YAM KM + DUBOIS KP
STUDIES ON THE EFFECT OF X-RADIATION ON THE HEXOBARBITAL METABOLIZING SYSTEM OF LIVER MICROSOMES
UNIVERSITY OF CHICAGO, AIR FORCE RADIATION LABORATORY
AD-629,311 +. 11 PAGES, 1 TABLE, 2 FIGURES, 13 REFERENCES, FROM QUARTERLY PROGRESS REPORT NO. 58, PAGES 15-25, JANUARY 15, 1966, CFSTI \$2.00 CY, \$0.50 MN

RESULTS OF THE PRESENT INVESTIGATION SHOWED THAT X-RADIATION REVERSIBLY INHIBITS THE PROCESS OF RESYNTHESIS OF THE HEXOBARBITAL METABOLIZING ENZYME SYSTEM IN THE REGENERATING LIVERS OF HEPATECTOMIZED, MALE RATS.

*BIOMEDICAL + *RADIATION DAMAGE + DOSE + X-RAY

15-11975 DOULL J + PLZAK V
HYPOBARIC OXYGEN EXPOSURE AND ACUTE RADIATION LETHALITY IN MICE
UNIVERSITY OF CHICAGO, AIR FORCE RADIATION LABORATORY
AD-629,311 +. 7 PAGES, 2 FIGURES, 2 TABLES, 3 REFERENCES, FROM QUARTERLY PROGRESS REPORT NO. 58, PAGES 26-32, JANUARY 15, 1966, CFSTI \$2.00 CY, \$0.50 MN

THE RESULTS OF THE STUDIES PRESENTED IN THIS REPORT INDICATE THAT THE EXPOSURE OF MICE TO WHOLE-BODY X-RAY EXPOSURE WITHIN THE DOSAGE RANGE OF 400 R THROUGH 700 R IN AN ATMOSPHERE OF 100 PERCENT OXYGEN AT 5 PSIA (258 MM. HG) PRODUCES NO SIGNIFICANT CHANGE (3 PERCENT) IN THE 30-DAY LD-50 WHEN COMPARED WITH THAT OF MICE IRRADIATED IN AIR.

*BIOMEDICAL + *RADIATION DAMAGE + DOSE + OXYGEN + X-RAY

CATEGORY 16
METEOROLOGICAL CONSIDERATIONS

16-09568 HALVERSON SL + KASTNER J + MOSES H + BANFIELD TV + MUELLER EA + STOUT GE
A NEW TECHNIQUE FOR MEASURING WIND VELOCITY PROFILES IN THE ATMOSPHERE
ARGONNE NATIONAL LABORATORY + ILLINOIS STATE WATER SURVEY
27 PAGES, 3 FIGURES, 7 TABLES, 8 REFERENCES, JULY 15, 1965, SOURCE

REPORTS THE EXPERIMENT PERFORMED TO DETERMINE WHETHER A COLUMN OF AIR, IONIZED BY A REACTOR, CAN BE DETECTED BY RADAR AND AS SUCH BE USED TO DETERMINE THE WIND PROFILE IN THE LOWER FEW HUNDRED FEET OF THE ATMOSPHERE. THE SYSTEM WOULD HAVE APPLICATION TO FLIGHT SAFETY AS WELL AS FOR CONTROL OF AIR POLLUTION OVER CITIES BY DETECTING TURBULENCE AND VENTILATION RATES. RESULTS ARE SOMEWHAT OBSCURE.

AIR POLLUTION + AIRCRAFT + CP-5 (CHICAGO PILE NO. 5) + INSTRUMENTATION, METEOROLOGICAL + TURBULENCE, SHEAR (WIND) + WIND PROFILE

16-09574 MARQUARDT W
METEOROLOGICAL INFLUENCES ON LONG-LIVED ATMOSPHERIC RADIOACTIVITY CONCENTRATION AS ANALYZED IN STUDYING MEASURING DATA FROM SUMMER 1961 TO SUMMER 1963
METEOROLOGISCHE OBSERVATORIUM WAHNSDORF, RADEBEUL, GERMANY
4 PAGES, KERNENERGIE, 7, PP. 54-58 (JANUARY 1964) IN GERMAN

AFTER A SHORT DESCRIPTION OF METHODS OF MEASURING ATMOSPHERIC RADIOACTIVITY, THE VARIATION OF THE LONG-LIVED ACTIVITY IN THE AIR FROM THE SUMMER OF 1961 TO THE SUMMER OF 1963 IS DISCUSSED. IT WAS ASSUMED THAT THE RADIOACTIVE AEROSOLS CAST IN THE STRATOSPHERE BY NUCLEAR WEAPONS TESTS AT HIGH LATITUDES SANK RAPIDLY INTO THE TROPOSPHERE AND PRODUCED THE AUTUMN MAXIMA IN 1961 AND 1962, WHILE THE AEROSOLS FROM TESTS IN LOWER LATITUDES REACHED THE TROPOSPHERE ONLY IN THE NEXT SPRING. DIMINISHED RADIOACTIVE CONCENTRATION IN THE AIR DURING FOGS WAS STATISTICALLY ESTABLISHED BY COMPARISON OF VALUES ON DAYS WITH FOG AND DAYS WITHOUT FOG. HOT PARTICLES COULD BE DETERMINED AT THE MEASURING PLACE ONLY UP TO 4 MO AFTER SUSPENSION OF NUCLEAR WEAPONS TESTS. SHOWERS HAD A GREATER SPECIFIC ACTIVITY THAN WIDESPREAD RAIN.

FALLOUT + MEASUREMENT, GENERAL + NUCLEAR DETONATION + PARTICLE, RADIOACTIVE + RAINOUT + STRATOSPHERE

16-09651 HOLLAND JZ + KLEMENT AW
FALLOUT PREDICTION TECHNIQUES
DIVISION OF BIOLOGY AND MEDICINE, USAEC
SC-DC-3553 + CONF-311 +. 22 PAGES, 13 FIGURES, 1 TABLE, PP. 219-230 OF PROCEEDINGS AEROSPACE NUCLEAR SAFETY, TRINITY SECTION - AMERICAN NUCLEAR SOCIETY NATIONAL TOPICAL MEETING, ALBUQUERQUE, NEW MEXICO, OCTOBER 1-4, 1963, JANUARY 1964, CFSTI, \$4.50 CY

THREE PRINCIPAL METHODS ARE EMPLOYED IN PREDICTING FALLOUT FROM RELEASES. THEY ARE BASED ON (1) GRAVITATIONAL SETTLING AND TURBULENT DIFFUSION OF PARTICLES, (2) DISTRIBUTION OF THE TOTAL DEBRIS INTO A FINITE NUMBER OF ATMOSPHERIC RESERVOIRS, AND (3) ANALOGY WITH THE OBSERVED DISTRIBUTIONS FROM SPECIFIC NUCLEAR DETONATIONS OR GROUPS OF DETONATIONS. AFTER DEPOSITION ON THE SURFACE, ESTIMATES OF DIETARY AND HUMAN LEVELS MAY BE MADE ON THE BASIS OF A VARIETY OF EMPIRICAL MODELS EMBODYING THE AVAILABLE RESULTS.

*FALLOUT + *NUCLEAR EXPLOSION DEBRIS + ATMOSPHERIC CIRCULATION, GLOBAL + ATMOSPHERIC DIFFUSION + COMPUTER, ANALOG + SAMPLING, HIGH ALTITUDE

16-10768 HARDY EP + RIVERA J
FALLOUT PROGRAM QUARTERLY SUMMARY REPORT, MARCH 1, 1966 - JUNE 1, 1966
NEW YORK OPERATIONS OFFICE, USAEC
HASL-172 +. 300 PAGES, 6 FIGURES, 5 TABLES, JULY 1, 1966, CFSTI, \$8.00 CY, \$2.25 MN.

THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED IN THIS REPORT ARE - (1) AIR SAMPLING, (2) PRECIPITATION OF RADIOISOTOPES, NEW ZEALAND RADIOACTIVITY REPORT, ARGONNE, AND ISRA, (3) SR-90 CONCENTRATION, (4) BALLOON SAMPLING PROGRAM, (5) A LISTING OF RECENT PUBLICATIONS.

*ATMOSPHERIC DIFFUSION, GLOBAL + *BIBLIOGRAPHY + *FALLOUT + *SAMPLING, HIGH ALTITUDE + *STRONTIUM + ANL (ARGONNE NATIONAL LABORATORY) + EURATOM + FILTER + NEW ZEALAND + PRECIPITATION + SAMPLING + STRATOSPHERE

16-10771 SCHAEFFER JR
CLIMATOLOGY OF TONOPAH TEST RANGE, 1963
SANDIA LABORATORY
SC-TM-64-576 +. 61 PAGES, FIGURES, TABLES, MAY, 1964, CFSTI, \$3.60, \$1.94 MF

PART I OF THIS REPORT CONSISTS OF GENERAL INFORMATION ABOUT THE SITE. PART II IS A PRESENTATION OF TONOPAH TEST RANGE CLIMATIC SUMMARIES OF SKY CONDITION, PRECIPITATION, TEMPERATURE, RELATIVE HUMIDITY, STATION PRESSURE, AND SURFACE WINDS DURING 1963. PART III CONTAINS SUMMARIES OF THE SAME ELEMENTS BASED ON 3-YEAR AVERAGES COVERING THE YEARS 1961 TO 1963. PART IV CONTAINS SUMMARIES OF UPPER WINDS BASED ON THE YEARS 1961 TO 1963.

*METEOROLOGICAL SUPPORT + *METEOROLOGY + *SITE CLIMATOLOGY + HUMIDITY + PRECIPITATION + WIND STATISTICS

16-10772 RENTSCHLER W + HAUSSELMANN W + WIESER PH
STUDIES OF THE FALLOUT RADIOACTIVITY OF GROUND-LEVEL AIR, PRECIPITATION AND DUST AT STUTTGART-HOHNHEIM
PHYSICS AND METEOROLOGY INSTITUTE OF THE STUTTGART-HOHNHEIM COLLEGE OF AGRICULTURE

ACCESSION NUMBER 16-09568 TO 16-10772

CATEGORY 16
METEOROLOGICAL CONSIDERATIONS

16-10772 *CONTINUED*

ORNL-TR-339 +. 27 PAGES, 9 FIGURES, 4 TABLES, 26 REFERENCES, TRANSLATED FROM ATOMKERNENERGIE 9, PAGES 297-306 (1964), JCL \$2.60 FS, \$1.04 MF

THE RESULTS OF AN INVESTIGATION OF THE DEPOSITION OF RADIOACTIVE FALLOUT AT STUTTGART HOHENHEIM FROM APRIL 1961 TO DECEMBER 1963 ARE DISCUSSED. THE MEASUREMENTS OF THE TOTAL BETA ACTIVITY, OF THE GAMMA SPECTROMETRICALLY DETERMINED NUCLIDE COMPOSITION AND OF THE CHEMICALLY SEPARATED SR-90 NUCLIDES OF PRECIPITATION, DUST, AND GROUND-LEVEL AIR, RESULT IN DISCRIMINATION EFFECTS IN THE SEPARATION AND COLLECTING PROCESSES. PARTICLE SIZE IS ONE OF THE ESSENTIAL REASONS FOR THE DISCRIMINATION OF FISSION PRODUCTS IN TRANSPORT, DEPOSITION, AND COLLECTION. IT IS ALSO SUSPECTED THAT DISTRIBUTION OF INDIVIDUAL NUCLIDES INTO FILTERS IS INFLUENCED BY BOTH SOLUBILITY AND PARTICLE SIZE.

*FALLOUT + *GERMANY + *PARTICLE SIZE DISTRIBUTION + *STRONTIUM + AEROSOL + METEOROLOGY +
NUCLEAR DETONATION + PRECIPITATION + SAMPLING + STRATOSPHERE

16-10775 BRADBURY HG

ATMOSPHERIC DIFFUSION STUDIES AT THE NARF SITE. PERIOD COVERED - OCTOBER 1, 1963-SEPTEMBER 30, 1964
GENERAL DYNAMICS/FORT WORTH

AD-618101 + FZK-206 + WL-TR-64-156 +. 113 PAGES, TABLES, REFERENCES, JUNE, 1965, CFSTI, \$4.00 CY, \$0.75 MN

FOUR ATMOSPHERIC DIFFUSION EXPERIMENTS WERE CONDUCTED IN THE NUCLEAR AEROSPACE RESEARCH FACILITY AREA AT GENERAL DYNAMICS/FORT WORTH TO STUDY THE DISPERSAL AND DILUTION FACTORS OF THE ATMOSPHERE AS THEY PERTAIN TO THE RELEASE OF AIRBORNE RADIOACTIVITY IN THE NARF AREA. FLUORESCENT DYE WAS RELEASED TO THE ATMOSPHERE FROM A POINT NEAR THE REACTOR OPERATIONS BUILDING AND SAMPLED DOWNWIND TO MEASURE DEPLETION FACTORS UNDER VARYING METEOROLOGICAL CONDITIONS. THE TESTS WERE PERFORMED WITH AIR-TEMPERATURE GRADIENTS RANGING FROM SLIGHTLY UNSTABLE TO MILDLY STABLE (INVERSION) SITUATIONS. ALTHOUGH THE FOUR TESTS WERE TOO FEW TO PROVIDE SUBSTANTIAL STATISTICAL DATA, THE RESULTS SHOW THAT UNDER THE POOREST DIFFUSION CONDITIONS EXPERIENCED, THE EFFLUENT-DEPLETION FACTORS RANGED FROM APPROXIMATELY 10 TO THE MINUS 4 TO 10 TO THE MINUS 6 BETWEEN 88 AND 704 M FROM THE RELEASE POINT. THESE FACTORS ARE CONSIDERABLY LESS THAN THOSE ACTUALLY BEING APPLIED UNDER NUCLEAR-SAFETY CONSIDERATIONS WITHIN THE NARF REACTOR OPERATIONS AREA.

*ATMOSPHERIC DIFFUSION EXPERIMENT + *DILUTION + *DISPERSION + *TRACER, FLUORESCENT + AEROSOL, RADIOACTIVE +
SAMPLING

16-10916 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 16 JUSTIFIES THE INVERSION FREQUENCY ASSUMED FOR THE 30-DAY FORECAST, BASED ON JOINT ASSUMPTION OF 42-4 PERCENT INVERSION CONDITIONS PLUS PREVAILING WIND (35 PERCENT) IN A NARROW (20 DEG) SECTOR. A DETAILED STUDY SHOWED THAT THE WORST CONDITIONS WERE ASSOCIATED WITH NIGHTTIME DOWN-VALLEY FLOW, MOST FREQUENT DURING SEPTEMBER AND OCTOBER. FURTHER STUDY SHOWED THAT THE ASSUMED 30-DAY ACCIDENT ANALYSIS WAS REALISTIC IF THE ACCIDENT COINCIDED WITH A SEQUENCE OF WEATHER CONDITIONS CONSIDERED MOST UNFAVORABLE.

*FREQUENCY SPECTRA + *LAPSE RATE, STABLE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + REACTOR, PRESSURIZED WATER + WIND STATISTICS

16-11262 MAGATA M

A STUDY OF THE SEA BREEZE BY THE NUMERICAL EXPERIMENT
METEOROLOGICAL RESEARCH INSTITUTE, TOKYO

16 PAGES, 2 TABLES, 10 FIGURES, METEOROLOGICAL RESEARCH INSTITUTE 16(1), PAGES 23-37, JUNE 1965

THE EFFECT OF THE GENERAL CURRENT WITH VERTICAL SHEAR AND THE RELEASE OF LATENT HEAT BY CONDENSATION ON THE DEVELOPMENT OF SEA-BREEZE CIRCULATION IS STUDIED BY THE NUMERICAL EXPERIMENT. TO FIND THE REASONABLE DISTRIBUTION OF THE DIFFUSION COEFFICIENT WHICH DECIDES THE VERTICAL TRANSFER OF HEAT AND PLAYS AN IMPORTANT ROLE IN SUCH AN EXPERIMENT, THE CALCULATED TEMPERATURE DISTRIBUTIONS BY THE EQUATION OF DIFFUSION ARE COMPARED WITH THE OBSERVATION IN THE CASE OF AN INVERSION LAYER DUE TO NOCTURNAL RADIATION. A CONDITION OF HEAT BALANCE AT THE SURFACE OF THE EARTH IS GIVEN BY TAKING INTO ACCOUNT INSOLATION, NOCTURNAL RADIATION, CONDUCTION, AND EDDY TRANSFER OF HEAT.

*ATMOSPHERIC DIFFUSION + *BREEZE, SEA + EQUATION, GENERAL + OCEAN AND SEA

16-11263 ENGELMANN RJ

CONSEQUENCES OF ACTIVITY RELEASE. CALCULATION OF PRECIPITATION SCAVENGING OF PARTICULATES AND GASES FROM THE ATMOSPHERE

BATTELLE NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
7 PAGES, 11 FIGURES, 4 TABLES, NUCLEAR SAFETY 7(3), PAGES 354-364, SPRING 1966

A FIRM BASIS FOR CALCULATIONS OF PRECIPITATION SCAVENGING OF PARTICLES AND GASES FROM THE ATMOSPHERE AND A GUIDE TO QUANTITATIVE PREDICTIONS ARE PRESENTED. COLLECTION EFFICIENCIES, WASHOUT COEFFICIENTS FOR PARTICLES AND GASES, RAIN SPECTRA, AND WASHOUT BY SNOW ARE DISCUSSED, AND VALUES ARE GIVEN, INCLUDING SOME PREVIOUSLY UNPUBLISHED. EXTENSIVE AREA-WITHIN-A-WASHOUT-ISOPLETH CHARTS ARE SHOWN FOR THREE ATMOSPHERIC STABILITIES AND SEVERAL WASHOUT COEFFICIENTS.

*RAINCUT + *WASHOUT + EQUATION, GENERAL + PARTICLE, RADIOACTIVE

CATEGORY 16
METEOROLOGICAL CONSIDERATIONS

16-11264 CHARASH E
VALUES OF SUTTONS TURBULENCE INDEX AS CALCULATED FROM WIND PROFILES AT LUCAS HEIGHTS
AUSTRALIAN ATOMIC ENERGY COMMISSION
AAEC/TM-243 +. 13 PAGES, 2 FIGURES, 2 TABLES, REFERENCES, MAY 1964, DEP. MN

STATISTICAL SUMMARIES ARE PRESENTED OF VALUES OF THE SUTTON TURBULENCE INDEX N, CALCULATED FROM VERTICAL WIND PROFILES AT LUCAS HEIGHTS. IT WAS FOUND THAT A GREAT SCATTER OF N-VALUES IS ASSOCIATED WITH ANY TEMPERATURE GRADIENT, AND THAT STABILITY ALONE CANNOT SERVE AS A BASIS FOR DETERMINING THE N-PARAMETER. THIS IS INTERPRETED AS THE EFFECT OF TERRAIN AT LUCAS HEIGHTS, AND SOME EVIDENCE IS ADDUCED WHICH INDICATES THAT MOMENTUM TRANSFER IS CONTROLLED MORE BY MECHANICAL TURBULENCE CREATED BY RUGGED CONTOURS THAN BY BUOYANCY FORCES. IT IS SHOWN HOWEVER THAT THE SCATTER IN N-VALUES IS DEPENDENT IN NO SMALL MEASURE UPON THE HEIGHT AND DEPTH OF THE LAYER THROUGH WHICH THE WIND PROFILE IS MEASURED AND CAN BE SIGNIFICANTLY REDUCED BY A JUDICIOUS SELECTION OF THESE LEVELS.

*TURBULENCE, STATISTICS + *WIND PROFILE + *WIND STATISTICS + AUSTRALIA

16-11265 STOREBOE PB
PARTICULATE NUCLEAR BOMB DEBRIS AS A METEOROLOGICAL TRACER
FORSVARFETS FORSKNINGINSTITUTT, KJELLER
NDRE-51 + CONF-747-6 +. 92 PAGES, REFERENCES, FROM 4TH SYMPOSIUM ON RADIOACTIVITY IN SCANDINAVIA RISOE, DENMARK, OCTOBER 1964, DEP. MN

THE SUITABILITY OF PARTICULATE NUCLEAR-BOMB DEBRIS AS TRACER MATERIAL IN METEOROLOGICAL RESEARCH IS INVESTIGATED. PARTICLE SIZE IS A VERY IMPORTANT FACTOR, AND MUCH EMPHASIS IS LAID ON AN ATTEMPT TO ASSESS THE SIZE THROUGH INFERENCE FROM DIRECT AND INDIRECT OBSERVATIONS, AS WELL AS THROUGH COMPUTATIONS. EVEN FOR AIR BURSTS, A SIGNIFICANT PART OF THE DEBRIS MAY BE IN THE MICRON RANGE AT THE MOMENT OF CLOUD STABILIZATION. SOURCES OF SYSTEMATIC AND UNSYSTEMATIC ERRORS DURING SAMPLING ARE DISCUSSED. POTENTIALITIES AND LIMITATIONS OF PARTICULATE DEBRIS AS METEOROLOGICAL TRACER MATERIAL ARE THEN DISCUSSED IN CONNECTION WITH A CRITICAL SURVEY OVER APPLICATIONS MADE IN THE PAST.

*NUCLEAR EXPLOSION DEBRIS + *TRACER, RADIOACTIVE + METEOROLOGY + PARTICLE SIZE + SAMPLING

16-11279 DINGLE AN + GATZ OF
RAIN SCAVENGING STUDIES. DATA ANALYSIS, SYNTHESIS, AND INTERPRETATION. PROGRESS REPORT NO. 2
UNIVERSITY OF MICHIGAN, ANN ARBOR, MICHIGAN
COO-1407-10 +. 37 PAGES, MAY 1966, CFSTI \$2.00 CY, \$0.50 MN

MICHIGAN UNIVERSITY, DEPARTMENT OF METEOROLOGY AND OCEANOGRAPHY, MAY 1966. THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE TOPICS ENUMERATED BELOW. TOPICS COVERED INCLUDE CONTAMINATION CONCENTRATION VARIATIONS WITHIN RAINS, THE ROLE OF RAINDROP EVAPORATION IN CONCENTRATION FLUCTUATIONS, AND RAIN SAMPLING.

*RAINOUT + DEPOSITION + METEOROLOGY + NUCLEAR EXPLOSION DEBRIS + SAMPLING

16 11280 PEARCE DW + GREEN JK
PACIFIC NORTHWEST LABORATORY ANNUAL REPORT FOR 1965 IN THE PHYSICAL SCIENCES. VOLUME I. ATMOSPHERIC SCIENCES.
BATTELLE-NORTHWEST, RICHLAND
BNWL-235 +. 38 PAGES, 29 FIGURES, 29 REFERENCES, MAY 1966, CFSTI \$2.00 CY, \$0.50 MN

BATTELLE-NORTHWEST PROGRESS REPORT, MAY 1966. THIS REPORT IS ONE OF A SERIES OF REPORTS OF THE SUBJECTS ENUMERATED BELOW. TOPICS COVERED ARE - PRECIPITATION-SCAVENGING STUDIES, MIDAS COMPUTER PROGRAM FOR EVAPORATION OF FALLING DROPS AND FOR ISENTROPIC STEAM FUNCTIONS AND TRAJECTORIES, BATTELLE-NORTHWEST RADIOTELEMETERED METEOROLOGICAL AND RADIATION OBSERVATION NETWORK, INSTRUMENTING OF AIRCRAFT FOR SAMPLING OF A ZINC SULFIDE ATMOSPHERIC TRACER, PREDICTION OF EXPOSURES FROM AN ELEVATED SOURCE AND SPECTRAL DISTRIBUTION OF ATMOSPHERIC TURBULENCE.

COMPUTER PROGRAM, METEOROLOGICAL + INSTRUMENTATION, METEOROLOGICAL + METEOROLOGY + RAINOUT + SOURCE, ELEVATED + TRACER, FLUORESCENT + TURBULENCE, STATISTICS

16-11735 BATTAN LJ
THE UNCLEAN SKY - A METEOROLOGIST LOOKS AT AIR POLLUTION
UNIVERSITY OF ARIZONA
126 PAGES, 19 FIGURES, 1966, DOUBLEDAY AND COMPANY, INC., GARDEN CITY, NEW YORK

POPULAR-BUT-EDUCATED-LEVEL REVIEW OF AIR-POLLUTION PROBLEMS OF INDUSTRIALIZED CIVILIZATION. (PESTICIDES AND RADIOISOTOPES WILL BE DISCUSSED IN ANOTHER BOOK.) DESCRIBES DONORA, LONDON, AND MEUSE INVERSION INCIDENTS IN RECENT TIMES, AS WELL AS A FEW RELEASES OF INDUSTRIAL GASES BOTH ROUTINE AND ACCIDENTAL. BRIEFLY DISCUSSES FALLOUT, ATMOSPHERIC CHEMISTRY, EFFECTS OF POLLUTION ON PLANTS AND ANIMALS, AND METEOROLOGICAL DISPERSION. ADVOCATES ELECTRIC TRAINS (PASSENGER), WITH LIMITATION ON PRIVATE VEHICLES, AS A SOLUTION BECAUSE THE CONTROL OF AUTOMOBILE EXHAUST FUMES IS ONLY A STOPGAP. PUBLIC APATHY IS A MAJOR PROBLEM. YET, MORE PEOPLE MUST BE MOVED WITH THE ACCOMPANIMENT OF LESS SMOKE, OR THE INCREASING AMOUNTS OF SMOKE WILL SURELY LEAD TO FEWER PEOPLE.

*ATMOSPHERIC POLLUTION + *INCIDENT, ACTUAL, NONNUCLEAR + *SMOKE + METEOROLOGY

CATEGORY 16
METEOROLOGICAL CONSIDERATIONS

16-11981 MURPHY CH + BULL GV + EDWARDS HD
UPPER ATMOSPHERE WINDS MEASURED BY GUN-LAUNCHED PROJECTILES
BALLISTIC RESEARCH LABORATORIES, MARYLAND
BRL-MR-1747 +. 48 PAGES, 6 TABLES, 11 FIGURES, 15 REFERENCES, MAY 1966, SOURCE

THE HIGH ALTITUDE RESEARCH PROJECT (HARP) USES GUN-LAUNCHED PROJECTILES TO PROBE THE UPPER ATMOSPHERE. UNDER THIS PROJECT, 5-INCH PROJECTILES HAVE REACHED 70 KM, AND 16-INCH PROJECTILES HAVE ATTAINED AN ALTITUDE OF 143 KM OVER BARBADOS, WEST INDIES. THE FIRST EXPERIMENTAL PROGRAM FOR THE 16-INCH GUN HAS BEEN THE PRODUCTION OF LUMINOUS TRIMETHYL ALUMINUM (TMA) TRAILS FOR THE MEASUREMENT OF WINDS ABOVE 90 KM. THE SMOOTHBORE EXTENDED 16-INCH GUN TUBE IS 119 FT LONG, WEIGHS 200 TONS AND HAS LAUNCHED VEHICLES WHICH GENERATE TMA TRAILS FROM 90 KM TO 138 KM. IN THE PERIOD JULY 1964 TO FEBRUARY 1966, 49 SUCH NIGHTTIME TRAILS WERE PHOTOGRAPHED AND 29 OF THESE TRAILS HAVE BEEN ANALYZED. DURING 42 OF THESE FLIGHTS, CONCURRENT IONOSONDE RECORDS WERE TAKEN AND THE LOCATIONS OF SPORADIC E LAYERS HAVE BEEN DETERMINED FOR COMPARISON WITH THE WIND PROFILES.

*WIND PROFILE + *WIND STATISTICS

16-11982 BOWMAN GG + MAINSTONE JS
GEOMAGNETIC AND IONOSPHERIC EFFECTS AT BRISBANE FOLLOWING THE NUCLEAR EXPLOSION ON JULY 9, 1962
UNIVERSITY OF QUEENSLAND, BRISBANE, AUSTRALIA + DANISH ATOMIC ENERGY RESEARCH ESTABLISHMENT, DENMARK
9 PAGES, 9 FIGURES, 8 REFERENCES, AUSTRALIAN JOURNAL OF PHYSICS 17(3), PAGES 409-417 (1964)

IONOSPHERIC DATA AND GEOMAGNETIC MICROPULSATION RECORDS FROM BRISBANE HAVE REVEALED BOTH SHORT-TERM AND DELAYED EFFECTS ASSOCIATED WITH THE U.S. NUCLEAR EXPLOSION ON JULY 9, 1962 ABOVE JOHNSTON I. THE INITIAL IONOSPHERIC EFFECTS, LASTING ABOUT 30 S, APPEARED TO BE DUE TO SEVERE LOW-LEVEL (D-REGION) BLANKETING, PROBABLY ARISING FROM THE DUMPING OF NEUTRON DECAY PRODUCTS. THE MICROPULSATIONS INITIATED BY THE EXPLOSION WERE DETECTED FOR ABOUT 5 MIN. AFTER AN INITIAL TRANSIENT, THEY BECAME SUPPRESSED DURING THE TIME WHEN THE LOW-LEVEL BLANKETING IONIZATION WAS PRESENT.

IONOSPHERE + NUCLEAR DETONATION + NUCLEAR EXPLOSION DEBRIS + RADIATION EFFECT

16-11983 BOWEN PJ + BOYD RL + DAVIES MJ + DORLING EB + GROVES GV + STEBBINGS RF
UPPER ATMOSPHERE WIND AND TEMPERATURE STRUCTURE BY SKYLARK ROCKET-GRENADE EXPERIMENTS AT WOOMERA, AUSTRALIA, 1957-59
UNIVERSITY COLLEGE LONDON
16 PAGES, 9 FIGURES, 4 TABLES, 8 REFERENCES, PROCEEDINGS ROYAL SOCIETY, SERIES A, 280(1381), PAGES 170-184 (JULY 21, 1964)

AN ACCOUNT IS PRESENTED OF THE FIRST GRENADE EXPERIMENTS CARRIED OUT AT THE WOOMERA ROCKET RANGE DURING 1957-59. A DESCRIPTION IS GIVEN OF THE GRENADES AND THEIR ROCKET INSTALLATION, AND OF THE OPTICAL AND ACOUSTICAL INSTRUMENTATION REQUIRED TO DETERMINE THEIR BURST POSITIONS AND TO FIND THE TIMES OF TRAVEL OF THE SOUND WAVES TO THE GROUND. THE METHOD AND THEORY OF THE EXPERIMENT ARE OUTLINED, AND DETAILS OF THE FIRINGS AND RESULTS OBTAINED ARE PRESENTED. THE ACCURACY OF THE MEASUREMENTS IS DISCUSSED AND COMPARISONS MADE WITH SIMULTANEOUS MEASUREMENTS BY OTHER METHODS. DETERMINATIONS OF WIND SPEED AND TEMPERATURE (DERIVED FROM THE SPEED OF SOUND) HAVE BEEN EXTENDED FROM THE UPPER BALLOON LIMIT TO ABOUT 85 KM, AND A COMPARISON BETWEEN SUMMER AND WINTER CONDITIONS HAS BEEN POSSIBLE. WIND MEASUREMENTS HAVE BEEN EXTENDED TO GREATER HEIGHTS BY MEANS OF THE GLOW PHENOMENON. PRESSURE AND DENSITY PROFILES HAVE BEEN DETERMINED AND AGREE VERY CLOSELY WITH THE COSPAR INTERNATIONAL REFERENCE ATMOSPHERE, 1961.

INSTRUMENTATION, METEOROLOGICAL + MEASUREMENT, GENERAL + TEMPERATURE GRADIENT + WIND STATISTICS

16-11984 KANGOS JD + GERRITY JP
THE INFLUENCE OF LOCAL WINDS ON FALLOUT. SEMIANNUAL PROGRESS REPORT 1
THE TRAVELERS RESEARCH CENTER, INC., HARTFORD, CONNECTICUT
ECOM-00392-1 +. 75 PAGES, AUGUST 1965, CFSTI \$3.00 CY, \$0.75 MN

THE PURPOSE OF THE STUDY IS TO FORMULATE EXISTING INFORMATION ON THE STRUCTURE OF LOCAL WIND SYSTEMS AND LOCAL (CLOSE-IN) FALLOUT CHARACTERISTICS INTO A COMPUTERIZED COMPUTATIONAL MODEL FOR USE IN ESTIMATING THE INFLUENCE OF LOCAL WIND CIRCULATIONS ON THE DEPOSITION OF CLOSE-IN FALLOUT. INFORMATION ON THE STRUCTURE OF THE SEA BREEZE OBTAINED BY PREVIOUS OBSERVATIONAL AND THEORETICAL STUDIES HAS BEEN EMPLOYED TO FORMULATE A KINEMATIC MODEL OF THE WIND FIELD ASSOCIATED WITH SEA BREEZE. A PROGRAM WAS CONSTRUCTED FOR THE NUMERICAL COMPUTATION OF FALLOUT TRANSPORT THROUGH AN ANALYTICALLY PRESCRIBED TWO-DIMENSIONAL LOCAL WIND CIRCULATION. AND FOR THE COMPUTATION OF ITS GROUND DEPOSITION PATTERN. THE PLANNED DEVELOPMENT OF A THREE-DIMENSIONAL KINEMATIC MODEL OF THE SEA-BREEZE WIND FIELD AND OF A COMPUTER PROGRAM FOR THE COMPUTATION OF FALLOUT TRANSPORT THROUGH IT, IS DISCUSSED.

*BREEZE, SEA + *DEPOSITION + COMPUTER PROGRAM, METEOROLOGICAL + WIND PROFILE

16-11985 WARNKE DF
APPLICATION OF THE LOG-NORMAL FUNCTION TO THE MASS DENSITY AND NUMBER DENSITY DISTRIBUTION OF SPHERICAL PARTICLES
SANDIA CORPORATION, ALBUQUERQUE, NEW MEXICO
SC-TM-65-397 +. 27 PAGES, DECEMBER 1965, CFSTI \$2.00 CY, \$0.50 MN

THE LOG-NORMAL DISTRIBUTION IS DESCRIBED IN TERMS OF MASS AND NUMBER DISTRIBUTIONS OF PARTICLES. ALL THE ASSOCIATED MATHEMATICAL RELATIONS ARE FORMULATED. AN EXAMPLE ILLUSTRATES THE USE OF LOG-NORMAL DENSITY AND DISTRIBUTION FUNCTION, INCLUDING CURVES AND TABLES OF THESE

ACCESSION NUMBER 16-11981 TO 16-11985

CATEGORY 16
METEOROLOGICAL CONSIDERATIONS

16-11985 *CONTINUED*
FUNCTIONS. AN APPENDIX DESCRIBES A SHORT FORTRAN PROGRAM FOR CALCULATING THE PROBABILITY DENSITY FUNCTIONS.

COMPUTER PROGRAM, METEOROLOGICAL + EQUATION, GENERAL + FALLOUT + PARTICLE SIZE DISTRIBUTION

16-11986 YAMAOKA Y + UENO K
DETERMINATION OF RADIOACTIVE FALLOUT FROM NUCLEAR WEAPON TESTS DETECTION AND DETERMINATION OF RADIOACTIVE NUCLIDES IN RAIN WATER
JAPAN ATOMIC ENERGY RESEARCH INSTITUTE, TOKYO
JAERI-1083 +. 10 PAGES, JUNE 1965, DPE. MN, IN JAPANESE

RAIN WATER SAMPLES WERE COLLECTED FROM OCTOBER 1961 TO NOVEMBER 1962. THE RADIOACTIVITY DETECTED WAS ON THE INCREASE AFTER THE SERIES OF NUCLEAR DETONATIONS BY SOVIET RUSSIA. THE DETECTION AND DETERMINATION OF RADIOACTIVE NUCLIDES WERE CARRIED OUT BOTH BY ION EXCHANGE (DOWEX 1 OR 50 RESIN), AND GAMMA-RAY SPECTROMETRY. BY THE FORMER METHOD, GROUP ACTIVITIES OF RARE-EARTH AND ALKALI-EARTH ELEMENTS WERE DETERMINED, AND BY THE LATTER, ZR-NB, MO-TC, RU-RH, TE-I, I, BA-LA, ETC., WERE DETECTED, AND ZR-NB WERE DETERMINED. ALSO, THE DETERMINATION METHODS FOR SMALL AMOUNTS OF U-238 AND U-237 IN RAIN WATER WERE INVESTIGATED, USING FLUOROMETRY AND ISOTOPE DILUTION METHOD, RESPECTIVELY.

IODINE + JAPAN + LANTHANUM + MOLYBDENUM + NIOBIUM + NUCLEAR EXPLOSION DEBRIS + RAINOUT + RHODIUM + RUTHENIUM + SAMPLING + TECHNETIUM + TELLURIUM + UNION OF SOVIET SOCIALIST REPUBLICS + URANIUM + ZIRCONIUM

16-11987 ENGELMANN RJ + PERKINS RW
SNOW AND RAIN WASHOUT COEFFICIENTS FOR INORGANIC IODINE VAPOR
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-SA-155 +. 5 PAGES, APRIL 16, 1965, CFSTI \$1.00 CY, \$0.50 MN

WASHOUT COEFFICIENTS FOR GASEOUS IODINE IN SNOWFALL AND AN ESTIMATE OF THE COEFFICIENT FOR RAINFALL HAVE BEEN EXPERIMENTALLY DETERMINED FOR THE FIRST TIME. THE COEFFICIENT FOR RAIN IS IN AGREEMENT WITH THEORY. THE COEFFICIENT FOR SNOW APPEARS TO DEPEND UPON CRYSTAL TYPE AND SIZE AS WELL AS UPON SNOWFALL RATE.

IODINE + RAINOUT + SOURCE, CONTINUOUS + WASHOUT

16-12017 PENG L
STRATOSPHERIC WIND TEMPERATURE AND ISOBARIC HEIGHT CONDITIONS DURING THE IGY PERIOD PART III. REPORT NO. 15
MASSACHUSETTS INSTITUTE OF TECHNOLOGY
MIT-2241-14 +. 204 PAGES, SEPTEMBER 1, 1965, CFSTI \$6.00 CY, \$1.25 MF

THE STRATOSPHERIC WIND, TEMPERATURE, AND ISOBARIC HEIGHT CONDITIONS OF THE NORTHERN HEMISPHERE DURING THE PERIOD FROM JULY TO DECEMBER 1958 WERE STATISTICALLY STUDIED. THREE-MONTH SEASONAL AVERAGES OF THESE QUANTITIES AND OF THE COVARIANCES BETWEEN THEM WERE COMPUTED AND ARE PRESENTED IN THE FORM OF HEMISPHERIC MAPS. ZONAL AVERAGES OF VARIOUS IMPORTANT QUANTITIES ARE ALSO GIVEN IN TABLES. GENERAL DISCUSSIONS OF THE RESULTS ARE GIVEN BRIEFLY.

EQUATION, GENERAL + STATISTICAL ANALYSIS + STRATOSPHERE + WIND PROFILE + WIND STATISTICS

16-12018 VOLCHOK HL
STRONTIUM 90 - ESTIMATION OF WORLDWIDE DEPOSITION
NEW YORK OPERATIONS OFFICE, USAEC, HEALTH AND SAFETY LABORATORY
2 PAGES, 3 TABLES, 1 FIGURE, 15 REFERENCES, SCIENCE 145, (3639) PAGES 1451-1452 (SEPTEMBER 25, 1964)

THE RELATION BETWEEN THE WORLDWIDE DEPOSITION OF STRONTIUM-90, AS CALCULATED BY MANY INVESTIGATORS OVER THE LAST DECADE, AND THAT OBSERVED IN RAINFALL IN NEW YORK CITY HAS BEEN RELATIVELY CONSTANT. ON THE AVERAGE, FOR EACH MILLICURIE OF STRONTIUM-90 PER SQUARE MILE DEPOSITED IN NEW YORK CITY, 0.055 MEGACURIE HAS BEEN DEPOSITED ON THE TOTAL SURFACE OF THE EARTH. CUMULATIVE DEPOSITS OF STRONTIUM-90 ON THE SURFACE AT VARIOUS INTERVALS OVER THE LAST 10 YEARS HAVE BEEN COMPUTED FROM THIS RATIO. FROM THE MEAN QUARTERLY FRACTION OF THE ANNUAL STRONTIUM-90 FALLOUT IN NEW YORK CITY FOR THE LAST 9 YEARS, THE WORLDWIDE DEPOSITION OF THIS NUCLIDE, EQUAL TO 2.48 MEGACURIES, IS PREDICTED FOR 1964.

DEPOSITION + RAINOUT + STRONTIUM

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07700 DE SAINT MAURICE A + CANFIELD R
THERMAL-COLUMN PNEUMATIC FACILITY
COLUMBIA UNIVERSITY IRL, PLAINSBORO, NEW JERSEY
1 PAGE, 2 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 1

A THERMAL COLUMN PNEUMATIC RABBIT FACILITY WAS INSTALLED IN THE SMW IRL RESEARCH REACTOR. PREVIOUSLY, SAMPLES COULD BE INSERTED ONLY WHILE THE REACTOR WAS DOWN. THE TUBE IS BENT TO PREVENT STREAMING.

*IN PILE LOOP + IN PILE EXPERIMENT + REACTOR, RESEARCH

17-07701 DALKE CA
ELIMINATION OF HYDRAULICALLY INDUCED CORE VIBRATIONS IN THE GE TEST REACTOR
VALLECITOS ATOMIC LABORATORY, GENERAL ELECTRIC COMPANY
9 PAGES, 5 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 2

EXCESSIVE LOG N PERIOD ALARMS INDICATED REACTIVITY OSCILLATIONS, WHICH INCREASED AS CONTROL ROD BANK POSITION INCREASED. MOTION PICTURES SHOWED THE CONTROL ROD GUIDE TUBES VIBRATING BECAUSE OF WEAR ON THE CORE COMPONENT SPACER PADS. BERYLLIUM TOP PIECES WERE REDESIGNED, AS WERE GUIDE TUBE SPACER PADS AND HOLDDOWN BOLTS.

*NOISE + *OPERATING EXPERIENCE + CONTROL ROD + FAILURE, EQUIPMENT + GETR (GENERAL ELECTRIC TEST REACTOR) + REACTIVITY EFFECT + REACTOR, TEST

17-07702 BENNETT EC
INSPECTION OF CRITICAL PROCESS-TUBE COMPONENTS AT HANFORD
HANFORD ATOMIC PRODUCTS OPERATION, GENERAL ELECTRIC CO.
RL-SA-44 +. 5 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 2-3

THE ALUMINUM PROCESS TUBES (18,000 AT ONE TIME) ARE SUBJECT TO EROSION AND CORROSION, EXPENSIVE TO REPLACE EITHER EARLY OR TOO LATE. EDDY-CURRENT PROBES ARE USED IN PLACE TO DETERMINE WALL THICKNESS (AND CORROSION RATE). INTERPRETATION OF THE DATA REMAINS AN ART, AND TUBES ARE CHECKED IN A HOT CELL. NOZZLES AND FITTINGS ARE SUBJECT TO DAMAGE AND ARE INSPECTED ROUTINELY. PRESSURE GAGES ARE GIVEN VARIOUS ROUTINE MAINTENANCE, WHICH HAS CUT THE MALFUNCTION RATE TO A FOURTH.

*MAINTENANCE AND REPAIR + *TEST, NONDESTRUCTIVE + CORROSION + HANFORD SITE + INSTRUMENTATION, PROCESS + OPERATING EXPERIENCE + REACTOR, PRESSURE TUBE

17-07703 BECKETT EF
REFUELING AND REPAIRS OF THE PM-3A DURING THE 1964-65 AUSTRAL SUMMER
NEW YORK OPERATIONS OFFICE, U. S. ATOMIC ENERGY COMMISSION
NYO-10736 +. 49 PAGES, 19 FIGURES, 2 TABLES, 11 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 3

ONE HUNDRED AND FORTY DAYS WERE REQUIRED - 13 FOR REFUELING AND 127 FOR MAINTENANCE AND TESTING. WORKERS WERE ABLE TO USE STUD TENSIONERS DIRECTLY WITHOUT REMOTE MANIPULATION ON HEAD REMOVAL BUT WERE JAMMED DURING HEAT REPLACEMENT BECAUSE THE STUD-OPERATING NUT ROTATES OPPOSITE TO THE STUD NUT. CONTROL-ROD-DRIVE COLLETS HAD DEFORMED AND WERE REPLACED. ROD-DRIVE ACTUATORS FAILED (WHEN USED IN GROUPS) BECAUSE OF EXCESSIVE CURRENT DEMAND. THREE HAD INTERNAL SHORTS IN THE COILS BECAUSE OF INTERNAL WIRE MOVEMENT LOOSENING THE POTTING, AND MOISTURE INLEAKAGE THROUGH POOR CABLE BONDS AND CONNECTORS. ON STARTUP, A STEAM-GENERATOR WATER-LEVEL INDICATOR MALFUNCTIONED, AND THE SHELL WAS RUN DRY. MUCH TIME WAS LOST BECAUSE PROCUREMENT AND ENGINEERING EVALUATION WERE DONE OFF-SITE.

*MAINTENANCE AND REPAIR + *OPERATING EXPERIENCE + *REFUELING + FAILURE, EQUIPMENT + PM 3A (PORTABLE MEDIUM NUCLEAR POWER PLANT) + REACTOR, ARMY + REACTOR, PRESSURIZED WATER + TRITIUM

17-07704 HAUSLER LM + HAUETER RL + CHRISTIANSON RC
IN-VESEL MODIFICATION OF IRRADIATED REACTOR INTERNALS AT BIG ROCK POINT
CONSUMERS POWER COMPANY + GENERAL ELECTRIC COMPANY, APED, SAN JOSE, CALIFORNIA
39 PAGES, 25 FIGURES, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 3-5

A 6-MONTH SHUTDOWN BEGINNING OCTOBER, 1964, WAS NECESSARY TO REPAIR THE VESSEL THERMAL-SHIELD ATTACHMENTS. TWO HOLD-DOWN STUDS FAILED FROM FATIGUE, DUE TO SELF-EXCITED VIBRATION OR LARGE CLEARANCES IN THERMAL SHIELD. THE HOLD-DOWNS WERE REDESIGNED, AND A PNEUMATIC DRILL WAS LOWERED INTO THE VESSEL FOR MILLING AND DRILLING. UNDERWATER TV WAS USED INSTEAD OF DIVERS BECAUSE THE RADIATION LEVEL WAS 25-50 R/HR. A NYLON-NET CHIP-CATCHER WAS USED. CONCLUSION - SUCH REPAIR WORK IS TEDIOUS BUT CAN BE DONE. DESIGNERS SHOULD PAY MORE ATTENTION TO MECHANICAL DESIGN. NEEDED COMPLETE RECORD AND AS-BUILT DRAWINGS.

*CONTAINMENT, PRESSURE VESSEL + *MODIFICATION, SYSTEM OR EQUIPMENT + BIG ROCK POINT + FAILURE, FATIGUE + MAINTENANCE AND REPAIR + OPERATING EXPERIENCE + REACTOR, BOILING WATER

17-07705 RIESLAND JI + GUSTAFSON EA

ACCESSION NUMBER 17-07700 TO 17-07705

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07705 *CONTINUED*

WORK PERFORMED ON FUEL CHANNELS AND THE CORE SUPPORT PLATE AT BIG ROCK POINT NUCLEAR PLANT
GENERAL ELECTRIC COMPANY, SAN JOSE
30 PAGES, 26 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 5-9

EARLY 1963 OPERATION REVEALED CHANNEL-SUPPORT-TUBE VIBRATION WHICH DISLODGED SOME SCREWS,
PREVENTING CONTROL-ROD WITHDRAWAL. ALTHOUGH THE SCREWS WERE STAKED, A STUCK ROD AGAIN
OCCURRED IN MAY 1963. THE CHANNELS WERE REMOVED AND SCREWS WELDED IN PLACE. PC FLOW
DIFFUSERS WERE INSTALLED ON THE CORE-SUPPORT PLATE, WHICH HAD BEEN REMOVED. DRY-SUIT DIVERS
AIDED INSTALLATION.

*CONTROL ROD DRIVE + *FAILURE, EQUIPMENT + BIG ROCK POINT + CONTAINMENT, PRESSURE VESSEL +
FAILURE, FATIGUE + FLOW DISTRIBUTION + MAINTENANCE AND REPAIR + MODIFICATION, SYSTEM OR EQUIPMENT +
OPERATING EXPERIENCE + REACTOR, BOILING WATER

17-07706 GRAY PL

IN-SITU REPAIRS WITHIN THE HWCTR PRESSURE VESSEL
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
25 PAGES, 10 FIGURES, 1 TABLE, 4 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING
EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8,
PAGES 9-11

A GAS BAFFLE (WHICH REDUCED TURBULENCE AND VOIDS DUE TO HELIUM ENTRAINMENT AT GAS-D2O
INTERPHASE) WAS FOUND TO HAVE BROKEN BOLTS AFTER TWO YEARS OPERATION, PERHAPS BECAUSE OF
FLEXING OF THE FLOW BAFFLE, WHICH HAD NOT BEEN DESIGNED TO SUPPORT THE GAS BAFFLE. THE FLOW
AND GAS BAFFLES WERE REMOVED AND REPAIRED. IRRADIATED FUEL WAS LEFT IN CORE, SHIELDING
INSTALLED SO WORKERS COULD ENTER THE VESSEL IN FIELDS LESS THAN 150 MR/HR. VARIOUS OTHER
BOLTS WERE BROKEN OR CRACKED DUE TO OVER STRESSING, STRESS CORROSION BECAUSE OF IMPROPER HEAT
TREATMENT, ETC.

*MODIFICATION, SYSTEM OR EQUIPMENT + *SHIELDING + CONTAINMENT, PRESSURE VESSEL +
HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + MAINTENANCE AND REPAIR + OPERATING EXPERIENCE +
REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER + REACTOR, TEST

17-07707 MCKIBBEN JM

A THREE-YEAR EVALUATION OF MILD STEEL AT THE HEAVY WATER COMPONENTS TEST REACTOR
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
21 PAGES, 4 FIGURES, 3 TABLES, 7 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING
EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE
11

ALL THE PIPING OUTSIDE THE REACTOR VESSEL, INCLUDING SG TUBES, IS MILD STEEL. VESSEL IS MILD
STEEL CLAD WITH 304 STAINLESS STEEL. DEUTERIUM GAS WAS ADDED TO AID RECOMBINATION. ADHERENT
MAGNETITE FILM WAS PRODUCED DELIBERATELY IN INITIAL FUNCTIONAL TESTS. STEAM-GENERATOR TUBES
FAILED FROM OXYGEN ATTACK ON SECONDARY SIDE. RADIATION MEASUREMENTS SHOW MOST OF COOLANT
SYSTEM CONTAMINATION IS FROM CRUD, DESPITE TEN FUEL-ELEMENT FAILURES.

*COOLANT CHEMISTRY + *CORROSION + FAILURE, FUEL ELEMENT + HWCTR (HEAVY WATER COMPONENT TEST REACTOR) +
OPERATING EXPERIENCE + REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER + REACTOR, TEST + RECOMBINER

17-07708 WHITHAM GK + LEMAN JC

RECENT PROBLEMS WITH EBR-II COMPONENTS
ARGONNE NATIONAL LABORATORY, IDAHO
2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING,
JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 11-12

EBR II WAS SHUT DOWN FROM OCTOBER 1964 TO MARCH 1965 BECAUSE OF TWO FAILURES - STICKING OF
THREE CONTROL-ROD DRIVES AND A WATER-TO-AIR LEAK IN A STEAM GENERATOR. BALLS FROM A BALL
BEARING HAD COME LOOSE.

*FAILURE, EQUIPMENT + CONTROL ROD DRIVE + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + HEAT EXCHANGER +
REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

17-07709 WOODRUFF RW

SRE CORE REPLACEMENT
ATOMICS INTERNATIONAL
1 PAGE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 12

SPE WILL BE REVISSED AND UPGRATED FOR USE AS A FUEL-TEST FACILITY. SINCE CORE REPLACEMENT NOW
WOULD TAKE 40 DAYS, FUEL HANDLING IS BEING REVISED TO REDUCE FUTURE DOWNTIME.

*FUEL HANDLING + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + REACTOR, TEST +
SRE (SODIUM REACTOR EXPERIMENT)

17-07710 NICHOLSON JO

DEMOLITION OF THE HEAT-TRANSFER SYSTEMS AT THE SODIUM REACTOR EXPERIMENT (IN PREPARATION FOR THE POWER
EXPANSION PROGRAM)
ATOMICS INTERNATIONAL

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07710 *CONTINUED*

2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 12-13

BETA-GAMMA RATIO INCREASED FROM 8/1 TO 15/1 AFTER SODIUM REMOVED FROM PIPING. RADIOACTIVE COMPONENTS WERE GIVEN TREATMENT IN BUTYL-CELLOSOLVE, RATHER THAN BEING STEAM CLEANED FOLLOWING THE OIL BATH, THIS TO GIVE SLOW REACTION RATE. SEVEN WEEKS AND 16 MEN WERE USED- MAXIMUM EXPOSURE WAS 1.8 REMS.

*MODIFICATION, SYSTEM OR EQUIPMENT + *POWER UPRATING + REACTOR DECOMMISSIONING EXPERIENCE + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + SRE (SODIUM REACTOR EXPERIMENT)

17-07711 NELSON SL

EVALUATION OF THE HANFORD PERSONNEL CERTIFICATION PROGRAM
HANFORD ATOMIC PRODUCTS OPERATION

RL-SA-13 +. 13 PAGES, 1 TABLE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 14

AFTER 3 YEARS, THE RETRAINING PROGRAM IS COMPLETE, WITH MOST OF THE SUPERVISORS AND OVER HALF THE OPERATORS CERTIFIED. MANAGEMENT BELIEVES PROGRAM HAS AIDED SAFETY, HAS A GAIN DUE TO INCREASED EFFICIENCY. MUCH TEACHING MATERIAL, INCLUDING PROGRAMMED INSTRUCTION, WAS DEVELOPED. FLOW CHART OF PROGRAM PRESENTED. TEMPORARY PROBLEMS WERE DETERMINATION OF THE SCOPE AND DEPTH, SCHEDULING OF ENTIRE OPERATING FORCE FOR SIMILAR TRAINING, RESENTMENT OF OLDTIMERS, UNION PROBLEMS, FAILURE TO CERTIFY.

*STAFFING, TRAINING, QUALIFICATION + HANFORD SITE + OPERATING EXPERIENCE + REACTOR, AEC OWNED

17-07712 JOHNSON MT

SELECTION AND TRAINING OF THE TEST OPERATIONS STAFF FOR THE NERVA REACTOR DEVELOPMENT PROGRAM
WESTINGHOUSE ASTRONUCLEAR LABORATORY

5 PAGES, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 15

COOPERATIVE ATTITUDE AND SELECTION OF WORKERS WERE RECOGNIZED AS KEY FACTORS. MAINTAINING AND ACQUIRING PROFICIENCY WAS DIFFICULT SINCE POWER OPERATION IS FOR ONLY MINUTES AT A TIME- SIMULATION TRAINING AND ROTATION HELPS. A FORMAL PROGRAM WAS ESTABLISHED, PATTERNED AFTER THE NAVAL REACTOR PROGRAM EXPERIENCE.

REACTOR, AEC OWNED + REACTOR, SPACE + STAFFING, TRAINING, QUALIFICATION

17-07713 BRYANT H

IDAHO DIVISION REACTOR OPERATIONS PERSONNEL TRAINING PROGRAM
ARGONNE NATIONAL LABORATORY, IDAHO

2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 15-16

A TRAINING OFFICE WAS ESTABLISHED JUNE 1960 TO COORDINATE THE TRAINING OF PEOPLE WITH DIVERSE BACKGROUNDS. LOCAL HIGH SCHOOL GRADUATES WERE WEAK IN THEORY, TECHNICAL SCHOOL GRADUATES WERE WEAK IN SPECIALIZED AREAS, AND EX-SUBMARINERS WERE WELL QUALIFIED. A GENERAL NUCLEAR BACKGROUND COURSE IS TAUGHT BY THE CENTRAL OFFICE, AND SPECIFIC PLANT TRAINING BY EACH OPERATIONS GROUP.

*STAFFING, TRAINING, QUALIFICATION + ANL (ARGONNE NATIONAL LABORATORY) + REACTOR, AEC OWNED

17-07714 NELSON CL + WHITHAM GK + BRYANT H + LEMAN D + GREENE JK

PLANT SYSTEMS TRAINING OF PERSONNEL FOR EBR-II
ARGONNE NATIONAL LABORATORY, IDAHO

15 PAGES, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 16

TRAINING BEGAN 18 MONTHS BEFORE DRY CRITICAL, AND INCLUDED BOTH THEORY AND PRACTICE. LESSON PLANS WERE PREPARED TO COORDINATE TRAINING WHEN SHIFT CREWS WERE FORMED. AS STARTUP APPROACHED, TRAINING WAS DONE ON OVERTIME. THERE IS NOW A 40-MAN OPERATING CREW AND A 4-MAN TRAINING CREW, WHICH PREPARES LESSON PLANS. TWO SUPERVISORS SIGN EACH LESSON PLAN WHEN THEY BELIEVE THAT THE TRAINEE KNOWS THE MATERIAL. A FINAL ORAL AND WRITTEN EXAM IS ALSO USED. OPERATOR PERFORMANCE ON SHIFT CORRELATES WITH RESULTS OF THE EXAMINATION.

*STAFFING, TRAINING, QUALIFICATION + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + REACTOR, AEC OWNED + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

17-07715 LARSON HJ

REACTOR SAFETY REVIEW ORGANIZATION

VALLECITOS ATOMIC POWER LABORATORY, GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA

20 PAGES, 5 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 16-17

A MULTI-LEVEL REVIEW ORGANIZATION RESULTED IN A MANAGEMENT--STAFF-LEVEL PERMANENT UNIT DEALING WITH VARIOUS OPERATING GROUPS AND EXTRA-COMPANY REGULATORY BODIES. THIS HAS ADVANTAGES (SIMPLIFIES COMMUNICATION, PROVIDES INDEPENDENT REVIEW, INFORMATION IS CENTRALIZED, REGULATIONS AWARENESS) AND DISADVANTAGES (FACILITY MANAGEMENT MINIMIZES LICENSING EFFORT,

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07715 *CONTINUED*

OPERATING GROUPS DO NOT CHALLENGE TECHNICALLY STRONGER REVIEW GROUP AND PERFUNCTORILY PERFORMS THEIR OWN REVIEW/AUDIT). CONCLUSION - NOTHING CAN REPLACE COMPETENT OPERATORS, BUT REVIEW IS NECESSARY WHERE HIGH RELIANCE MUST BE PLACED ON PROCEDURAL SAFEGUARDS.

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + ADMINISTRATIVE CONTROLS AND PRACTICES + REACTOR, TEST

17-07716 ABLITT JF

THE CONTRIBUTION OF SYSTEMATIC INCIDENT EVALUATION TO THE ACHIEVEMENT OF REACTOR SAFETY
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
17 PAGES, 10 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 17-19

SINCE 1961, A UK SAFETY GROUP HAS BEEN ANALYZING REPORTED FAULTS FOR (A) TRENDS AT LOCAL SITES, (B) SPECIFIC COMPONENT MALFUNCTION, AND (C) COMPONENT-FAILURE-RATE EXPERIENCE. SEVERAL TYPICAL RELAY MALFUNCTIONS DESCRIBED, AND INCIDENT STATISTICS FOR A CHOSEN PERIOD REVIEWED.

*RELIABILITY ANALYSIS + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + INCIDENT, ACTUAL, GENERAL + UNITED KINGDOM

17-07717 MCCOOL WJ

REACTOR SAFETY AT AEC-OWNED FACILITIES
U. S. ATOMIC ENERGY COMMISSION, REACTOR SAFETY BRANCH
14 PAGES, 1 TABLE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 19

AEC OWNS 151 REACTORS OF VARIOUS TYPES, OPERATED BY 26 CONTRACTORS. DESPITE THIS COMPLEXITY, GENERALLY UNIFORM STANDARDS ARE TO BE APPLIED, CONSISTENT WITH AEC-LICENSED REACTORS. THE AEC MANUAL ESTABLISHES THAT (A) CONTRACTORS OPERATE WITH CARE COMMENSURATE WITH RISK, CARRY MAJOR BURDEN OF SAFETY, (B) FIELD OFFICES REVIEW PROPOSED AND CURRENT OPERATIONS, AUDIT OPERATIONS, (C) DIVISION OF OPERATIONAL SAFETY DEVELOPS POLICY AND EVALUATES PERFORMANCE. VARIOUS GUIDES HAVE BEEN PUBLISHED.

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + ADMINISTRATIVE CONTROLS AND PRACTICES + REACTOR, AEC OWNED

17-07718 CORLETT RF

CONTROL OF REACTOR MODIFICATIONS FOLLOWING COMMISSIONING
BATTELLE-NORTHWEST
2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 19-20

EARLY IN THE LIFE OF A REACTOR, STAFF IS WELL DISCIPLINED IN CAREFUL FORMAL REVIEW OF MODIFICATIONS TO CRUCIAL EQUIPMENT. LATER, PERSONNEL WILL LEAVE, CLIMATE WILL CHANGE, NATURAL DESIRE TO STRETCH PLANT, ALL WILL REQUIRE A SYSTEM TO CONTROL MODIFICATIONS. CRITERIA - (1) BALANCE BETWEEN SAFETY AND ECONOMICS IN GRAY AREAS, (2) BALANCE BETWEEN SPEEDY JOB AND AGONIZINGLY SLOW REVIEW, (3) CLEARLY DEFINED REVIEW RESPONSIBILITIES. THE EXACT CONTENT OF THE SYSTEM IS LESS IMPORTANT THAN THE FACT THAT A REFLECTIVE PAUSE IS MANDATORY BEFORE CRUCIAL SYSTEMS ARE CHANGED.

*MODIFICATION, SYSTEM OR EQUIPMENT + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + HANFORD SITE

17-07719 SOWARDS NK

OPERATING PROCEDURES FOR THE ML-1 (MOBILE LOW-POWER) NUCLEAR POWER PLANT
AEROJET-GENERAL NUCLEONICS, IDAHO
1 PAGE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 20

AUTHORITY TO FIELD CHANGE A PROCEDURE IS PLACED AT REACTOR SUPERVISOR LEVEL BECAUSE SUPPORT STAFF IS 600 MILES AWAY. REACTOR SUPERVISOR KNOWS EQUIPMENT AND PROBLEMS, ALSO MANAGEMENT PHILOSOPHY. HAS COMMUNICATION WITH OPERATORS, TEST GROUPS AND MANAGEMENT. MAJOR DISADVANTAGE OF REPEATED OPERATING-PROCEDURE REVISION (COST) IS MORE THAN OFFSET BY CLOSER CONTROL AND WELL-DOCUMENTED PROGRAM.

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + ADMINISTRATIVE CONTROLS AND PRACTICES + ML 1 (MOBILE LOW POWER PLANT NO. 1) + PROCEDURES AND MANUALS + REACTOR, ARMY + REACTOR, GAS COOLED

17-07738 DAVIDSON RH

MODERATOR ELEMENT FAILURES IN THE HALLAM NUCLEAR POWER FACILITY
CONSUMERS PUBLIC POWER DISTRICT, HALLAM, NEBRASKA
16 PAGES, 10 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 35

SEVEN MODERATOR-CAN FAILURES WERE RAPIDLY DETECTED BY INSTRUMENTATION SHOWING FLUX TILT, LOCAL POWER DEPRESSION, AND REACTIVITY LOSS. FOR M51 FAILURE, A DELTA T REDUCTION OF 70 DEGREES F AND A LOSS OF 20 CENTS REACTIVITY RESULTED WITHIN 3 HOURS. SUBSEQUENT HOT-CELL EVALUATION SHOWED A CHARACTERISTIC STRESS FAILURE ON ALL ELEMENTS, ALLOWING SODIUM TO SOAK THE GRAPHITE, CAUSING NEUTRON POISON ACCUMULATION AND SWELLING.

*MODERATOR + *REACTIVITY EFFECT, ANOMALOUS + FAILURE, COMPONENT + HALLAM + REACTOR, GRAPHITE MODERATED +

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07738 *CONTINUED*
REACTOR, LIQUID METAL COOLED + STRESS

17-07739 CUTFORTH DC + MILES CC + VILLARREAL R
DEFECTIVE FUEL TESTS IN THE NUCLEAR SUPERHEATING REACTOR BORAX-V
ARGONNE NATIONAL LABORATORY, IDAHO
2 PAGES, 1 TABLE, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 35-36

PRELIMINARY DATA FROM VBWR LOOP INDICATED A MILLION TIMES MORE IODINE CARRYOVER FROM SUPERHEAT FAILURE THAN FROM BOILER-ELEMENT FAILURE. BORAX V OPERATED WITH PURPOSELY DAMAGED BOILER AND SH FUEL TO TEST THIS (0.5 SQ. IN. OF CLADDING REMOVED TO WITHIN 2 MILS OF FUEL). ACTIVITIES IN SYSTEM FROM 1 DEFECTIVE SH FUEL SAMPLE WERE ABOUT THE SAME AS FROM 10 DEFECTIVE BOILER RODS, ALTHOUGH SH FUEL GAVE MORE SYSTEM CONTAMINATION. THIS SHOWS THAT UO₂-SS CERMET SH FUEL DOES NOT PRESENT A SUBSTANTIALLY GREATER HAZARD THAN UO₂-SS-CLAD BOILER FUEL. THE CERMET FUEL RUNS COOLER, AND SS MATRIX AIDS IN TRAPPING OF FISSION PRODUCTS.

*FAILURE, FUEL ELEMENT + *OPERATING EXPERIENCE + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + IN CORE MEASUREMENT + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

17-07740 TABOR WH
FUEL-PLATE MELTING AT THE OAK RIDGE RESEARCH REACTOR
OAK RIDGE NATIONAL LABORATORY
2 PAGES, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 36-37

FLOW BLOCKAGE BY A NEOPRENE GASKET CAUSED A PARTIAL MELTING OF ONE FUEL PLATE, RELEASING 0.9 G OF U-235 AND 1000 CURIES OF VOLATILES. BOILING NOISE WAS DETECTED. CLEANUP FROM DEMINERALIZERS WAS ADEQUATE TO BRING REACTOR UP TWO DAYS LATER. SEE ORNL-TM-627 FOR MORE COMPLETE REPORT.

*FAILURE, FUEL ELEMENT + *FLOW BLOCKAGE + ORR (OAK RIDGE RESEARCH REACTOR) + REACTOR, RESEARCH + REACTOR, TEST

17-07741 PERRIGO L
TRANSPORT AND BUILDUP OF RADIOACTIVE MATERIALS IN REACTOR SYSTEMS AS DETERMINED BY SHUTDOWN RADIATION MEASUREMENTS
BATTTELLE-NORTHWEST
2 PAGES, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 37-38

SYSTEMATIC MEASUREMENTS AT SPECIFIC POINTS SHOW DISTRIBUTION AND HALF-LIFE OF MATERIAL, AND AID IN SCHEDULING MAINTENANCE. DURING DECONTAMINATION AFTER A FUEL-ELEMENT RUPTURE, SUCH MEASUREMENTS SHOWED LOCAL INCREASES DUE TO SHIFTING OF PARTICLES.

*DECONTAMINATION + *OPERATING EXPERIENCE + *SURVEY, RADIATION, GENERAL + MAINTENANCE AND REPAIR + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST

17-07742 BATTIST L + SMITH ER + LOWE SD + DELAPAZ A
FUEL-ELEMENT DEFECTS IN CERMET-TYPE FUELS IN THE SM-1 AND PM-3A REACTORS, AND CONSEQUENT PM-3A CONTAINMENT AIR ACTIVITY
NUCLEAR UTILITY SERVICES, INC. + U. S. NAVY CEC (NNPU), NUCLEAR UTILITY SERVICES, INC., WASHINGTON, D. C.
1 PAGE, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 38

ANALYZING WATER ACTIVITY SHOWED THAT A CLADDING DEFECT HAD OCCURRED AND GAVE SIZE. AT PM3A, CONTAINMENT AIR WAS FILTERED, USING LOCAL EQUIPMENT.

*CONTAINMENT FILTERING SYSTEM + *FAILURE, CLADDING + *OPERATING EXPERIENCE + REACTOR, ARMY

17-07743 HANSEN AI + CARTER TJ
FISSION-PRODUCT AND CARBON RETENTION IN SRE COLD TRAPS
ATOMICS INTERNATIONAL
2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 38-39

EIGHT COLD TRAPS, WHICH HAD BEEN USED TO REMOVE IMPURITIES, WERE EXAMINED FOR DISTRIBUTION AND KINDS OF IMPURITIES. SEVERAL RETENTION METHODS WERE FOUND, SUCH AS GETTERING ACTION OF CARBON AND SODIUM OXIDE.

*COOLANT CHEMISTRY + OPERATING EXPERIENCE + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED + SRE (SODIUM REACTOR EXPERIMENT)

17-07744 REYER RJ
CONTAINMENT TESTING IN HIGH FLUX BEAM REACTOR
BROOKHAVEN NATIONAL LABORATORY
2 PAGES, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 39-40

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07744 *CONTINUED*

A STEEL-DOME SYSTEM IS DESIGNED FOR LESS THAN 5 PERCENT LEAKAGE PER DAY AT 2 PSIG. VARIOUS LEAKS WERE FOUND BY SIMPLE LISTENING AND WITH SONIC DETECTORS. SMOKE WAS USELESS. LEAKS WERE FOUND AT DOOR FRAMES, CONCRETE JOINTS, UNPAINTED CONCRETE, UNWELDED PIPE PENETRATIONS.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + HFBR (HIGH FLUX BEAM REACTOR) + REACTOR, RESEARCH

17-07745 ERION TL + ROTH JM

CONTAINMENT VESSEL INTEGRATED LEAK-TEST EXPERIENCE AT THE SAXTON NUCLEAR EXPERIMENTAL REACTOR WESTINGHOUSE ATOMIC POWER DIVISION, MADISON, PA. + SAXTON NUCLEAR EXPERIMENTAL CORP. 1 PAGE, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 40

TESTED IN APRIL 1964 AS LESS THAN 0.4 PERCENT/24 HR AT 30 PSIG, BY RATIOING THE TEST AT 24.7 PSIA. A CONTROLLED LEAK WAS ALSO INTRODUCED. VARIOUS TEMPERATURE GRADIENTS OCCURRED. ALSO, AMBIENT TEMPERATURES CHANGED.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + REACTOR, PRESSURIZED WATER + SAXTON

17-07746 WHITHAM GK + TEBB FJ + MCGINNIS FD

EBR-II REACTOR BUILDING LEAK TESTING
ARGONNE NATIONAL LABORATORY, IDAHO

2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 40-41

A 3-DAY LEAK TEST SHOWED LESS THAN 100 CU FT/DAY AT 36.2 PSIA, AFTER ALL OPERATIONAL DOORS INSTALLED. SINCE THEN, YEARLY TESTS HAVE BEEN ON MAJOR PENETRATIONS AND RANDOMLY CHOSEN ELECTRICAL PENETRATIONS. THEY PROPOSE TO ADAPT 8 OF 24 ELECTRICAL PENETRATIONS FOR TESTING, INSTEAD OF RANDOM TESTING, WHICH DISRUPTS OPERATIONS.

*CONTAINMENT LEAKAGE CONTROL + *TEST, LEAK RATE + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED

17-07747 KELLER FR

PRE-NEUTRON TESTING AND STARTUP EXPERIENCE - THE ADVANCED TEST REACTOR
PHILLIPS PETROLEUM COMPANY, IDAHO

17 PAGES, 4 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 42

USING PERT SCHEDULING, ACCEPTANCE TESTING OF INDIVIDUAL SYSTEM AND COMPONENTS SOON AFTER INSTALLATION SAVED TIME AND MONEY. DURING CLEANING OPERATIONS AFTER THE TESTS, THE FOUR HEAT EXCHANGERS WERE FOUND TO BE LEAKING DUE TO TUBE VIBRATION. PRIMARY PUMPS OVERHEATED BECAUSE THE VENTILATING SYSTEM WAS UNDERDESIGNED. CHEAP PUMPS HAVE BEEN MORE EXPENSIVE THAN COSTLY, WELL DESIGNED AND FABRICATED PUMPS. SECONDARY BUTTERFLY BYPASS VALVE DAMAGED BECAUSE NOT LOCATED IN STRAIGHT PIPING SECTIONS.

*FAILURE, COMPONENT + *MODIFICATION, SYSTEM OR EQUIPMENT + *REACTOR STARTUP TESTING + ATR (ADVANCED TEST REACTOR - NRTS) + REACTOR, TEST

17-07748 MCGRATH RG + BABB HT
CVTR STARTUP PROBLEMS

WESTINGHOUSE ELECTRIC CORP., APD, MADISON, PA. + CAROLINAS VIRGINIA NUCLEAR POWER ASSOCIATION, PARR, SOUTH CAROLINA

2 PAGES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 42-43

PRESSURE-TUBE PLUGS GALLED BECAUSE CHROME PLATING WAS TOO THIN, AND 410 STAINLESS-STEEL BASE METAL YIELDED LOCALLY. HELIUM LEAKED FROM HEADER CAVITY. CONDENSATION IN IMPERFECTLY SEALED HEADER-CAVITY INSULATION RELEASED HALOGENS TO WASTE TANKS. PRIMARY FLOW RATE GRADUALLY REDUCED 7 PERCENT.

*REACTOR STARTUP EXPERIENCE, INITIAL + CVTR (CAROLINAS VIRGINIA TUBE REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

17-07749 BRINKMAN DS + PEKRL PJ

AUTOMATIC STARTUP AND OPERATION OF SNAP-10A FLIGHT SYSTEM IN A SIMULATED SPACE ENVIRONMENT
ATOMICS INTERNATIONAL

2 PAGES, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 43-44

SNAP 10A HAS OPERATED ON THE GROUND FOR SEVERAL MONTHS, SELF-CONTROLLED, AFTER AN AUTOMATIC STARTUP.

OPERATING EXPERIENCE + REACTOR, SPACE + SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER)

17-07750 DIXON GJ

HFIR PRE-OPERATIONAL TEST PROGRAM
OAK RIDGE NATIONAL LABORATORY

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07750 *CONTINUED*

1 PAGE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 44

VARIOUS CAVITATION AND VIBRATION TESTS. PRESSURE AND FLOW TRANSIENTS CAUSED BY PUMP TRIP, FAILURES, ETC., STUDIED.

*HYDRAULIC EXPERIMENT + *REACTOR STARTUP TESTING + HFIR (HIGH FLUX ISOTOPE REACTOR) + REACTOR, HIGH FLUX + REACTOR, RESEARCH + REACTOR, TEST

17-07751 LEWIS VG + BUONI FB + FARY LB + VALLISH EJ
PRE-STARTUP HYDRAULIC TESTS AT THE AIR FORCE NUCLEAR ENGINEERING TEST FACILITY
WRIGHT PATTERSON AIR FORCE BASE, OHIO

11 PAGES, 1 TABLE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 44-45

LOW-BUDGET TESTS USING SALT-INJECTION TECHNIQUE FOR MEASURING FLOW VELOCITIES IN FUEL-ELEMENT CHANNELS OF PLATE-TYPE REACTOR. MEASUREMENTS IN GENERAL SHOWED ADEQUATE COOLING FLOW, INCLUDING THAT BETWEEN OUTER FUEL PLATE AND SOLID BERYLLIUM REFLECTOR.

*FLOW, HIGH SPEED + *REACTOR STARTUP TESTING + REACTOR, RESEARCH

17-07752 PANTER R
INTENSIVE USE OF DIDO TYPE MATERIALS-TESTING REACTORS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL

AERE-L-159 +. 11 PAGES, 6 FIGURES, 3 TABLES, JULY, 1965, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 45

THE ORIGINAL MTR FUEL ELEMENTS, DESIGNED FOR 9 MW, WERE REPLACED WITH INVOLUTE (MARK-3) TYPE ELEMENTS. FIFTEEN-MW OPERATION IS POSSIBLE BY CAREFUL CONTROL OF HEAT-EXCHANGER FOULING AND COOLING-TOWER IMPROVEMENTS. A NEW CONCENTRIC-PLATE ELEMENT (MARK-5) WITH A LARGER SURFACE AREA IS TO BE OPERATED AT HIGHER D2O INLET TEMPERATURES TO GIVE 25-30 MW WITHOUT ALTERING THE COOLING-TOWER CIRCUIT. THE SEMIPHASE CONTROL ARMS ARE BEING REPLACED WITH CYLINDERS OPERATING WITHIN FUEL ELEMENTS. THE POWER UPGRATING, PLUS CLOSER-WRAPPED FUEL, DOUBLES THE FAST FLUX IN EXPERIMENTS WITHIN THE FUEL ELEMENT.

*MODIFICATION, SYSTEM OR EQUIPMENT + *POWER UPGRATING + CONTROL ROD, SHIM SAFETY + COOLANT CHEMISTRY + FUEL ELEMENT + REACTOR, TEST

17-07753 MARTIN RC
OPERATING EXPERIENCE WITH A HEAVY-WATER-REFLECTOR TANK
UNIVERSITY OF MICHIGAN

44 PAGES, 16 FIGURES, 2 TABLES, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 46

REFLECTOR CONVERTED TWO BEAM HOLES TO TANGENTIAL OPERATION, ALMOST DOUBLING THERMAL NEUTRON FLUX, AND IMPROVING SIGNAL TO BACKGROUND BY FACTOR OF 3, EQUIVALENT TO OPERATING 8-12 MW INSTEAD OF 2. INFLATABLE BELLOWS KEEP LIGHT WATER OUT OF GAPS. TANK ADDS ONLY 0.2 PERCENT REACTIVITY INSTEAD OF THE 0.4 CALCULATED. D2O TANK REDUCES ROD WORTH LESS THAN 5 PERCENT, AND REDUCES INSTRUMENT VARIATION (DUE TO XENON FLUX SHIFT) FROM 1.16 TO 1.12. BEAM-HOLE MAINTENANCE IS EASIER BECAUSE GAMMA BACKGROUND IS REDUCED A FACTOR OF 10.

*HEAVY WATER + *OPERATING EXPERIENCE + *REFLECTOR + BEAM HOLE + FAILURE, EQUIPMENT + REACTOR, POOL TYPE + WELDING

17-07754 DULIN RV
CONTROL OF OXYGEN IN PRTR HELIUM SYSTEMS
BATTELLE-NORTHWEST

2 PAGES, 1 TABLE, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 46-47

PREVIOUSLY, HYDROGEN HAD BEEN ADDED TO THE HELIUM CORE-COVER GAS PERIODICALLY. THIS PARTIALLY REDUCED OXYGEN, BUT HYDROGEN WAS QUICKLY REDUCED. DEUTERIUM AND OXYGEN ALLOWED TO BUILD UP TO SATURATION, THEN HYDROGEN ADDED. ANALYSIS SHOWED HYDROGEN PREFERRED BY OXYGEN, SO THAT EXCESS HYDROGEN ACTED AS A CATALYST. A UNIFORM 1 PERCENT HYDROGEN IS NOW MAINTAINED, AND THERE HAS BEEN LITTLE PROBLEM WITH EXCESS OXYGEN.

*COOLANT CHEMISTRY + *OPERATING EXPERIENCE + *RADIOLYTIC GAS + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST

17-07755 COFFER CO + SHOPTHUGH JR + WHITTEMORE WL
STABILITY OF U-ZRH-SUB-1.7 STAINLESS-CLAD TRIGA FUEL ELEMENTS SUBJECTED TO LARGE REACTIVITY INSERTIONS AND LONG-TERM STEADY-STATE OPERATION
GENERAL ATOMIC, SAN DIEGO, CALIFORNIA

1 PAGE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 48

REACTOR HAS OPERATED 2100 MWHR, UP TO 1.5 MW STEADY STATE, AND WITH 651 PULSES (4 TO 4.6

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07755 *CONTINUED*

DOLLARS) WITH STAINLESS-STEEL-CLAD ELEMENTS. RFNDING OBSERVED AFTER 4.6-DOLLAR PULSES, ALSO 10-PSI INCREASE IN ELEMENTS (700 C) DUE TO HYDROGEN DISSOCIATION. ON COOLING, THE HYDROGEN RE-FORMS.

*FUEL ELEMENT + *OPERATING EXPERIENCE + REACTOR, PULSED + TEST, PHYSICS + TRIGA (TRAINING REACTOR, ISOTOPES, G.A.)

17-07756 HAMILTON GN + TAYLOR EG + HANLEN OF
DESIGN CONSIDERATIONS IN SAFETY ANALYSIS OF PARTIAL MODERATOR-LEVEL CONTROLLED REACTORS
WESTINGHOUSE ATOMIC POWER DIVISION, MADISON, PA.
1 PAGE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 49

VARIABLE MODERATOR-LEVEL CONTROL (INSTEAD OF CONTROL RODS) PRESENTS MANY PHYSICS ADVANTAGES FOR CRITICAL ASSEMBLIES. IN ADDITION, IT HAS SAFETY ADVANTAGES. NO CORE PLATE PENETRATIONS FOR ABSORBERS TO FALL THROUGH, NO PROBLEMS COUPLING CONTROL MATERIAL AND FUEL, REACTIVITY DOES NOT VARY WITH RADIAL POSITION, ONLY ONE WAY OF ADDING REACTIVITY, RAMP RATE IS A CONTINUOUS VARIABLE, NO STEP-INCREASE ACCIDENTS. SYSTEM HAS OPERATED EFFECTIVELY 5 YEARS AT WREC.

*CONTROL ROD + *MODERATOR + *REFLECTOR + ACCIDENT, REACTIVITY + CRITICAL ASSEMBLY FACILITY

17-07757 EPLER EP
SAFETY SYSTEM PERFORMANCE FAILURES
OAK RIDGE NATIONAL LABORATORY
2 PAGES, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 49-50

IN 20 YEARS, ABOUT 20 MAJOR INCIDENTS HAVE OCCURRED, TEN WHICH WOULD NOT HAVE OCCURRED HAD SAFETY SYSTEM OPERATED CORRECTLY. THESE FAILURES WERE DUE TO DESIGN ERRORS IN WHICH DELAY, LACK OF INPUT INFORMATION, OR PARALYZED SYSTEM PREVENTED SCRAM. DESPITE THE FACT THAT NO SAFETY-SYSTEM-COMPONENT FAILURE RESULTED IN AN EXCURSION, SYSTEMS ARE BEING BUILT WITH AUTOMATIC TESTING TO DETERMINE (AMPLIFIER) COMPONENT FAILURE. IF SAFETY SYSTEMS HAD BEEN TESTED JUST ONCE UNDER ACCIDENT CONDITIONS, PROBABLY ALL UNCONTROLLED EXCURSIONS TO DATE COULD HAVE BEEN PREVENTED.

*FAILURE, SCRAM MECHANISM + *OPERATING EXPERIENCE + *REACTOR SAFETY SYSTEM + EXCURSION, LARGE

17-07758 ROSS CP
PERFORMANCE OF HWCTR SAFETY SYSTEMS
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
25 PAGES, 10 FIGURES, 7 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 50

FOUR OF THE SIX ZIRCALOY ROD GUIDES FAILED AFTER 3 YEARS OF SERVICE, BY LONGITUDINAL SPLITS IN THE SHOCK-ABSORBER SECTION. FAILURE WAS DETECTED BY SHORTER ROD-DROP TIMES. IT MIGHT HAVE BEEN POSSIBLE TO DROP ROD ON A SPLIT, NOT ALL INTO CORE. TWICE A ROD FAILED TO DROP, DUE TO A CRACKED OVERRUNNING CAM CLUTCH. BORON INJECTION (BY SEPARATE HELIUM SUPPLY) WOULD NOT WORK IN CERTAIN PRESSURE AND FLOW SITUATIONS, SOLVED BY USING REACTOR COVER-GAS TO PRESSURIZE SYSTEM. GAS-RELIEF VALVES WERE CHANGED TO LIQUID-RELIEF VALVES, AS CODE CHANGED, TO PREVENT A VALVE FAILURE FROM RAPIDLY DEPRESSURIZING REACTOR. STEEL-DOME CONTAINMENT ON CONCRETE BELOW COULD NOT ACHIEVE LEAKAGE LESS THAN 2-3 PERCENT PER DAY AT 24 PSIG.

*FAILURE, SCRAM MECHANISM + *MODIFICATION, SYSTEM OR EQUIPMENT + *OPERATING EXPERIENCE + *SAFETY INJECTION + *TEST, LEAK RATE + *VALVE + CONTAINMENT, LOW PRESSURE + HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER + REACTOR, TEST + STRESS

17-07759 ELDER GE
DESIGN, OPERATION AND UTILIZATION OF THE WHITE SANDS MISSILE RANGE FAST BURST REACTOR
WHITE SANDS MISSILE RANGE HEADQUARTERS, NEW MEXICO
2 PAGES, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 50-51

DESCRIBES GENERAL DESIGN, OPERATING ORGANIZATION.

*ADMINISTRATIVE CONTROLS AND PRACTICES + *REACTOR DESCRIPTION + REACTOR, FAST BURST

17-07760 PANCOAST JT
A GRAVITY INDEPENDENT REACTOR CONTROL SYSTEM
GENERAL DYNAMICS, FORT WORTH, TEXAS
3 PAGES, 3 FIGURES, 2 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 51-53

REFLECTOR-POISON CYLINDERS ARE ROTATED BY RACK AND PINION DRIVES, OPERATED BY ELECTRIC MOTORS, REGARDLESS OF REACTOR ORIENTATION.

*CONTROL ROD DRIVE + *REFLECTOR + REACTOR, RESEARCH

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-07761 EDWARDS DR
EXPERIENCE WITH ROD DROP TIMES AT THE UMRR
UNIVERSITY OF MISSOURI, ROLLA, MISSOURI
1 PAGE, 1 TABLE, 3 REFERENCES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 53

ROD-DROP-TIME MEASUREMENTS TAKEN AT SIX-MONTH INTERVALS FAILED TO SHOW INCIPIENT FAILURE.
WATER LEAKED INTO THE 304 STAINLESS-STEEL ROD FILLED WITH B4C AND CADMIUM THROUGH THE SEAL
PLUG, AND DECOMPOSED. A ROD, SWOLLEN BY 8.6 PERCENT, JAMMED ON STARTUP AND FAILED TO DROP.
THE OTHER TWO RODS ALSO HAD SWOLLEN. BORON-STAINLESS-STEEL RODS, HAVING 80 PERCENT
EFFECTIVENESS OF OLD RODS, ARE REPLACEMENTS.

*CONTROL ROD + *FAILURE, SCRAM MECHANISM + *RADIOLYTIC GAS + INCIDENT, ACTUAL, GENERAL + REACTOR, POOL TYPE

17-07762 GIMMY KL + FIELD FR
ON-LINE COMPUTER ASSISTS REACTOR OPERATION AT SAVANNAH RIVER PLANT
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
2 PAGES, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE
LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 53-54

AT K REACTOR, SIGNALS FROM 3200 FLOW, PRESSURE, FLUX MONITORS, AND THERMOCOUPLES PROVIDE POWER
AND FLUX INFORMATION. USES ARE - DIRECT SURVEILLANCE OF INDIVIDUAL OPERATING LIMITS,
CALCULATION OF DERIVED LIMITS (SUCH AS BURNOUT SAFETY FACTOR) ON DEMAND, PREPARING HISTOGRAMS
FOR OPERATORS TO ADJUST RADIAL POWER, ROUTINE DATA COLLECTION.

*COMPUTER, DIGITAL + *CONTROL, COMPUTER + OPERATING EXPERIENCE + REACTOR, HEAVY WATER +
SAVANNAH RIVER PLANT

17-07763 OCCHIPINTI ES + MIX PE + STUTHEIT JS + FIELD FR
ANALOG COMPUTER SIMPLIFIES OPERATION OF SAVANNAH RIVER HIGH FLUX CHARGE
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
2 PAGES, 1 FIGURE, 1 REFERENCE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE,
JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGES 54-55

DURING A RECENT SPECIAL HIGH-FLUX RUN, THE POWER DENSITY WAS CONTROLLED BY USING A DIRECT
READOUT DISPLAY OF THE BURNOUT SAFETY FACTOR. GAMMA THERMOMETERS YIELDED THE FLUX
DISTRIBUTION, WHILE COOLANT-FLOW CONDITIONS WERE MANUALLY ADJUSTABLE INPUTS. THIS
CONSIDERABLY SHORTENS HAND COMPUTATIONS.

*COMPUTER, ANALOG + *CONTROL, COMPUTER + BURNOUT HEAT FLUX + REACTOR, HEAVY WATER + SAVANNAH RIVER PLANT

17-07764 HEINRICH LA
GADOLINIUM NITRATE INJECTION AS AN AUXILIARY SHUTDOWN SYSTEM FOR SAVANNAH RIVER REACTORS
SAVANNAH RIVER PLANT, E. I. DUPONT DE NEMOURS AND COMPANY
1 PAGE, 1 FIGURE, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE,
WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 56

INJECTION STARTS WITHIN 5 SEC AFTER INITIATION AND IS COMPLETE WITHIN 3 SEC. A SPECIAL TEST
WITH THE REACTOR OPERATING REDUCED POWER TO LESS THAN 5 PERCENT IN 15 SEC. ION EXCHANGERS
SUBSEQUENTLY REMOVE THE POISON.

*SHUTDOWN SYSTEM, SECONDARY + *TEST, SYSTEM OPERABILITY + REACTOR, HEAVY WATER

17-09277 MULLIKIN MS
OVEREXPOSURE AT UNIVERSAL TESTING COMPANY, MARCH 11, 1966
UNIVERSAL TESTING COMPANY, SALT LAKE CITY, UTAH
1 PAGE, ATOMIC ENERGY CLEARING HOUSE, 12(16) PAGE 30, APRIL 18, 1966

TWO PERSONS WERE EXPOSED WHEN THEY FAILED TO CONNECT CONTROL CABLE AND SOURCE CABLE, FORCING
THE SOURCE TO END OF THE CABLE UNTIL RECOVERED BY HAND.

*PERSONNEL EXPOSURE, RADIATION + *RADIOGRAPHY + FAILURE, OPERATOR ERROR

17-09278 WINTERS WR
OVEREXPOSURE AT MAGNAFLUX CORPORATION, MARCH 8, 1966
MAGNAFLUX CORPORATION, CHICAGO, ILLINOIS
2 PAGES, ATOMIC ENERGY CLEARING HOUSE, 12(16) PAGES 28-29, APRIL 18, 1966

A RADIOGRAPHER RECEIVED 3 REMS DURING A SETUP, WHILE HE WAS PLACING THE FILM. HIS ASSISTANT
SET UP THE GAMMA CAMERA BUT FAILED TO CONNECT THE SOURCE TO THE DRIVE CABLE. THE ASSISTANT
NOTICED THAT THE SOURCE LIGHTS WERE NOT INDICATING CORRECTLY, SO WORKED THE CONTROLS. THEN
THE RADIOGRAPHER FOUND OUT, GOT A SURVEY METER, AND FOUND HE HAD BEEN RECEIVING AN EXPOSURE.

*PERSONNEL EXPOSURE, RADIATION + *RADIOGRAPHY + FAILURE, OPERATOR ERROR

17-09279 HUSSEY FL
INCIDENT AT LUTHERAN GENERAL HOSPITAL, FEBRUARY 17, 1966
LUTHERAN GENERAL HOSPITAL, PARK RIDGE, ILLINOIS

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09279 *CONTINUED*

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(16), PAGES 27-28, APRIL 18, 1966

AS AN OLD TELETHERAPY SOURCE (CO-60) WAS BEING REPLACED, THE NEW 3000-CURIE SOURCE FELL FROM ITS SHIELD. THE AREA WAS CLEARED, AND AEC ASSISTANCE TEAM CALLED IN. AREA WAS ROPED OFF, AND REMOTE-HANDLING DEVICE AND STORAGE CONTAINER OBTAINED. SOURCE WAS RECOVERED WITHOUT FURTHER HARM.

*INCIDENT, ACTUAL, RECOVERY FROM + INCIDENT, ACTUAL, GENERAL + SOURCE, RADIATION

17-09280 MCCUE JK

EXPOSURE AT AVONDALE SHIPYARDS, MARCH 12, 1966

AVONDALE SHIPYARDS, INC., NEW ORLEANS, LOUISIANA

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(16) PAGE 27, APRIL 18, 1966

RADIOGRAPHER RECEIVED FILM-BADGE DOSE OF 5 REMS WHILE CLOSING STUCK DOOR OF IRIIDIUM-192 RADIOGRAPHY UNIT. ESTIMATE BASED ON TIME WAS 1.2 REMS. ADDITIONAL TRAINING BEING GIVEN ON NFFD FOR CAUTION, FOR EXAMPLE ROTATING CAMERA OPENING AGAINST WALL AND PLANNING NEXT MOVE.

*FAILURE, COMPONENT + *PERSONNEL EXPOSURE, RADIATION + FAILURE, OPERATOR ERROR + INCIDENT, ACTUAL, RECOVERY FROM + RADIOGRAPHY

17-09301 SNAP-8 ER HASTELLOY CLADDING CRACKS

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(16) PAGE 8, APRIL 18, 1966

SNAP PROGRAM FACT SHEET OF MARCH 1966 NOTES THAT 80 PERCENT OF THE S8ER HASTELLOY-CLAD FUEL ELEMENTS HAD CRACKS AFTER 500 DAYS OF OPERATION WITH 1300 F COOLANT-OUTLET TEMPERATURE. CAUSE AND SIGNIFICANCE NOT YET FULLY DETERMINED.

*FAILURE, CLADDING + REACTOR, SPACE + SNAP 8 (SYSTEMS FOR NUCLEAR AUXILIARY POWER)

17-09302 KILLIAN CB

TRITIUM EXPOSURE AT NEW ENGLAND NUCLEAR CORPORATION, FEBRUARY 16, 1966

NEW ENGLAND NUCLEAR CORPORATION, BOSTON, MASSACHUSETTS

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 46, APRIL 11, 1966

A CHEMIST OPENED AN EVACUATED SYSTEM SEVERAL TIMES IN A HOOD, TO ADD MATERIAL TO TRITIATED WATER. HIS CUMULATIVE INTERNAL EXPOSURE WAS 4.26 REMS DURING A THREE-WEEK PERIOD.

*FAILURE, OPERATOR ERROR + *PERSONNEL EXPOSURE, RADIATION + TRITIUM

17-09303 LAMBERTUS H

KERR-MCGEE EMPLOYEES EXAMINED IN Y-12 WHOLE-BODY COUNTER

KERR-MCGEE OIL INDUSTRIES, OKLAHOMA CITY, OKLAHOMA

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 46, APRIL 11, 1966

EMPLOYEES INVOLVED IN AN INCIDENT AT CRUSHING PLANT, JUNE 23, 1964, SHOWED NO SIGNIFICANT THORIUM CONTAMINATION WHEN EXAMINED IN Y-12 WHOLE-BODY COUNTER.

*INGESTION + *THORIUM + INCIDENT, ACTUAL, GENERAL

17-09304 CREUTZ E

GENERAL ATOMIC HIGH AIRBORNE ACTIVITY DUE TO CLOGGED FILTER, JANUARY 17, 1966

GENERAL ATOMIC DIVISION, GENERAL DYNAMICS CORPORATION, SAN DIEGO, CALIFORNIA

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 45, APRIL 11, 1966

INSOLUBLE U-235 WAS BEING PROCESSED IN A HOOD. THE EXHAUST FILTER CLOGGED, AND AN EMPLOYEE WAS EXPOSED TO 1.6 MPC (AIR). AN ADDITIONAL, INDEPENDENT SYSTEM WAS INSTALLED FOR THE ROOM, AND HOODS HAVE TELLTALE INDICATORS TO SHOW ADEQUACY OF THE FLOW.

*PERSONNEL EXPOSURE, RADIATION + FAILURE, ADMINISTRATIVE CONTROL + GLOVE BOX

17-09305 NURMI EO

B AND W RECOVERY FACILITY FIRE, FEBRUARY 22, 1966

BABCOCK AND WILCOX COMPANY, LYNCHBURG, VIRGINIA

3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 43-45, APRIL 11, 1966

LOW-URANIUM-CONTENT ZIRCONIUM-UPANIUM ALLOY CHIPS BEING DISSOLVED IGNITED AND BURNED THROUGH THE DISSOLVER. STEAM PROPELLED BURNING CHIPS AGAINST NEARBY GLASS COLUMNS, WHICH OVERHEATED AND BROKE. SPILLED KEROSENE CAUGHT FIRE. NO CONTAMINATION RESULTED, BUT ONE PERSON WAS BURNED. ALTHOUGH THIS DISSOLVER HAS OPERATED FOR 2 YEARS WITHOUT INCIDENT, AND HAD BEEN CHECKED 2 HR EARLIER, A GAS POCKET MIGHT HAVE FORMED IN THE CHIPS, SO A TRAY-TYPE DISSOLVER IS BEING DESIGNED.

*CHEMICAL REACTION + *FIRE + INCIDENT, ACTUAL, GENERAL + RADIOCHEMICAL PROCESSING

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09306 FREDERICK KJ
ABBOTT LABORATORIES REPORTS EXPOSURE, FEBRUARY 18, 1966
ABBOTT LABORATORIES, NORTH CHICAGO, ILLINOIS
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 42-43, APRIL 11, 1966

A TECHNICIAN BECAME CONTAMINATED WITH (30,000 COUNTS/MIN) AND INGESTED (3.9 TIMES THE THYROID BURDEN) I-131. THIS OCCURRED BECAUSE DEAERATION OF SAMPLE WAS NOT AS EFFECTIVE, APPARENTLY, AS A RESULT OF A MAJOR MOVE. CONTAMINATION WAS DISCOVERED WHEN TECHNICIAN TOUCHED NOSE WITH GLOVED HAND AND PROMPTLY REQUESTED AN HP CHECK.

*INCIDENT, ACTUAL, GENERAL + CONTAMINATION + FISSION PRODUCT, IODINE + PERSONNEL EXPOSURE, RADIATION + TRACER, RADIOACTIVE

17-09307 INTERIM ANALYSIS OF NFS STACK CRACK AND VIBRATION PROBLEMS, MARCH 25, 1966
NUCLEAR FUEL SERVICES, INC.
3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 35-37, APRIL 11, 1966, DOCKET NO. 50-201

NFS STEEL STACK WAS PROTECTED AGAINST VORTEX-INDUCED VIBRATIONS BY SMALL RADIAL FINS. IN NOVEMBER 1964, SUSTAINED GUSTS VIBRATED STACK, AND METAL YIELDED. SPOILERS COULD NOT PROTECT AGAINST GUSTS, SO CONCRETE SHEATH ADDED AFTER STACK EXAMINED AND FOUR BASE LUGS REPAIRED. LATER, A CIRCUMFERENTIAL CRACK DEVELOPED AT THE CYLINDRICAL/CONICAL JUNCTION DUE TO FATIGUE, POOR WELDING, AND STRESS CONCENTRATION. THIS WELD WAS NOT GIVEN A THOROUGH INSPECTION PRIOR TO CONCRETE SHEATH. NOW ALL CIRCUMFERENTIAL WELDS ARE BEING TESTED WITH DYES AND ULTRASONIC DEVICES.

*FAILURE, FATIGUE + *STACK + *WELDING + FAILURE, ADMINISTRATIVE CONTROL + FAILURE, DESIGN ERROR + NUCLEAR FUEL SERVICES (NFS) + OPERATING EXPERIENCE + RADIOCHEMICAL PROCESSING + WIND STATISTICS

17-09308 RUNION TC
AEC REPLY TO NFS LETTER ON FIRST EXAMINATIONS TO LICENSE CHEMICAL OPERATORS
NUCLEAR FUEL SERVICES, INC., BALTIMORE, MARYLAND
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 34-35, APRIL 11, 1966, DOCKET NO. 50-201

NFS STAFF KEPT INFORMED OF CANDIDATES WHO PASSED, AND DENIAL LETTERS SENT PROMPTLY. FAILURES WERE NOT DUE PRIMARILY TO LACK OF GENERAL TECHNICAL KNOWLEDGE (ONLY 10 PERCENT OF EXAM) BUT DUE TO LACK OF BASIC KNOWLEDGE OF NFS SAFETY MANUAL AND INSTRUMENTATION. MENTAL FATIGUE NOT A LARGE FACTOR, AS MAJORITY OF FAILURES WERE IN FIRST TWO EXAMS GIVEN, WHICH AVERAGED ONLY 4 HOURS EACH. OPERATING TEST GIVEN ON DIFFERENT DAYS. NFS STAFF REVIEWED EXAMS WHILE IN PROGRESS, BUT WERE NOT GIVEN EXAMS IN ADVANCE, AS HAD BEEN REQUESTED

*STAFFING, TRAINING, QUALIFICATION + NUCLEAR FUEL SERVICES (NFS) + RADIOCHEMICAL PROCESSING

17-09309 MCEWEN LH
AIRLOCK MECHANICAL INTERLOCK FAILED AT GETR, MARCH 1, 1966
GENERAL ELECTRIC COMPANY, PLEASANTON, CALIFORNIA
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGES 33-34, APRIL 11, 1966, DOCKET NO. 50-70

A FAULT IN THE MECHANICAL INTERLOCK ALLOWED BOTH DOORS TO BE OPEN ABOUT 5 SEC.

*FAILURE, COMPONENT + CONTAINMENT AIR LOCK + GETR (GENERAL ELECTRIC TEST REACTOR) + REACTOR, TEST

17-09310 STATE GEOLOGIST DISAGREES WITH CHOICE OF NFS BURIAL GROUND FOR HIGHLY RADIOACTIVE WASTE.
MARCH 23, 1966
NUCLEAR FUEL SERVICES
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(15) PAGE 38, APRIL 11, 1966

STATE GEOLOGIST, CONSULTING DRILL RECORDS, FINDS PROPOSED SITE HAS COARSE SAND AND STONE, INSTEAD OF LOW-PERMEABILITY CLAY TILL. GEOLOGIST BELIEVES SUCH A SITE WOULD ALLOW HORIZONTAL GROUNDWATER MOVEMENT (DUE TO UNSATURATED CONDITIONS), WHICH WOULD CARRY LEAKAGE TO LOCAL STREAMS.

*WASTE DISPOSAL, SOLID + GEOLOGICAL CONSIDERATION, GENERAL + NUCLEAR FUEL SERVICES (NFS) + RADIOCHEMICAL PROCESSING + SURFACE WATER, GENERAL

17-09368 ZIRCONIUM FINES FLASH FIRE
DIVISION OF OPERATIONAL SAFETY USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 274, 3 PAGES, 2 FIGURES, OCTOBER 7, 1966, DPI

USE OF A CENTERLESS GRINDER THREE WEEKS BEFORE THE INCIDENT PUT ZIRCONIUM FINES IN THE ENCLOSURE. DRY GRINDING OF A STAINLESS-STEEL ROD PROVIDED SPARKS TO START THE FIRE. THE HOUSEKEEPING TEAM THAT MORNING HAD FOUND NO EVIDENCE OF FINES, INDICATING A SUPERFICIAL EXAMINATION. PROTECTIVE GOGGLES PREVENTED SERIOUS EYE INJURY.

*FIRE + *ZIRCONIUM + INCIDENT, ACTUAL, NONREACTOR

17-09557 BANCROFT AR + CHARLESWORTH DH + DUERKSEN JH
IMPURITY EFFECTS IN THE FOULING OF HEAT TRANSFER SURFACES BY ORGANIC COOLANTS
ATOMIC ENERGY OF CANADA LIMITED, CHALK RIVER, ONTARIO

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09557 *CONTINUED*
AECL-1913 +. 1964, AECL, \$1.50

RESULTS OF SMALL LOOP TESTS SHOWED THAT CHLORINE IS BY FAR THE STRONGEST FACTOR IN FOULING, ALTHOUGH SMALL EFFECTS WERE OBSERVED DUE TO RADIOLYSIS PRODUCTS, WATER, AND OXYGEN. A 1000-HOUR OUT-OF-PILE TEST SHOWED THAT A DEPOSITION RATE OF 0.2 MICROGRAM PER CU. CM PER HR CAUSED AN INCREASE OF 25 C/YEAR IN THE SHEATH TEMPERATURE OF ELEMENTS RATED AT 100 W/SQ.CM. IN-PILE TESTS SHOWED THAT, WITH CONTINUOUS COOLANT PURIFICATION AND EXCLUSION OF CHLORINE, ETC., FOULING UNDER POWER-REACTOR CONDITIONS CAN BE RESTRICTED TO ACCEPTABLE RATES.

*COOLANT CHEMISTRY + *FILM, GENERAL + *FUEL ELEMENT + *HEAT TRANSFER + *SURFACE, GENERAL + CHLORINE + OMRE (ORGANIC MODERATED REACTOR EXPERIMENT) + REACTOR, ORGANIC COOLED

17-09562 MULLIKIN MS
RADIOGRAPHY OVEREXPOSURE, UNIVERSAL TESTING COMPANY, MARCH 10, 1966
UNIVERSAL TESTING COMPANY
2 PAGES, APRIL 8, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(16), PP. 27-28 (MAY 2, 1966)

A TRAINEE FAILED TO CONNECT THE CONTROL CABLE TO THE SOURCE CABLE, SO THE SOURCE REMAINED OUT OF THE SHIELDING AFTER THE FIRST WELD RADIOGRAPH. AFTER FIVE EXPOSURE SETUPS, THE SURVEY METER WAS BROUGHT OUT OF THE TRUCK, AND CONDITION FOUND. RADIOGRAPHER SHOOK SOURCE OUT OF TUBE AND RETURNED TO SHIELD. RADIOGRAPHERS FILM BADGE READ 0.935 REM, ESTIMATED WHOLE BODY DOSE 3 REMS, AND RIGHT HAND 20 REM. TRAINEE ADJUSTED SOURCE TUBE FOR EACH SETUP, FILM BADGE READ 4.27 REMS, ESTIMATED 176 REMS TO KNEES, AND 40 TO GONADS.

*INCIDENT, ACTUAL, HUMAN ERROR + *PERSONNEL EXPOSURE, RADIATION + *RADIOGRAPHY + FAILURE, DESIGN ERROR + FAILURE, OPERATOR ERROR

17-09563 MCCORMACK JE
COBALT-60 INHALATION DURING INSPECTION OF INDIAN POINT I PRESSURIZER, JANUARY 25, 1966
CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES, APRIL 19, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 22-25 (MAY 2, 1966)

THREE MEN ENTERED THE PRESSURIZER (APPARENTLY UNMASKED) FOR 39 MIN TO INSPECT THE LINING AND WERE FOUND LIGHTLY CONTAMINATED. ALTHOUGH AN AIR MONITOR HAD SHOWN AIR BELOW MPC, THEY WERE TAKEN TO A WHOLE-BODY COUNTER 3 HR LATER. COBALT-60 AND POSSIBLY MN-54 WERE FOUND. HIGHEST DOSE WAS 0.14 REM, AND BODY BURDENS 1.5-2.5 MICROCURIES. DEPENDING ON WHETHER TOTAL BURDEN OR RESPIRATORY BURDEN USED, AIR SAMPLER UNDERESTIMATED (BY FACTOR OF 210) OR OVERESTIMATED (BY 12) THE ACTUAL CONCENTRATION. AIR WAS DILUTED BY LONG HOSE NECESSARY TO MOVE MONITOR OUT OF HIGH BACKGROUND. PARTICLES MAY HAVE BEEN TOO LARGE AND SETTLED TOO RAPIDLY TO ENTER HOSE.

*DOSE MEASUREMENT, INTERNAL + *INCIDENT, ACTUAL, GENERAL + *INDIAN POINT I + *INHALATION + *MONITOR, RADIATION, AIR + *PRESSURIZER + COBALT + MAINTENANCE AND REPAIR + REACTOR, PRESSURIZED WATER

17-09564 WILKINS BW
FREEZING PRECAUTIONS IN SHIPPING SPENT FUEL, FEBRUARY 1966
GENERAL ELECTRIC COMPANY, SYRACUSE, N.Y.
2 PAGES, MARCH 18, 1966, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 17-18 (MAY 2, 1966)

SEVERAL INDIAN POINT CORE A SHIPMENTS WERE MADE WITH ALCOHOL ADDED TO THE CASK COOLANT. AFTER THE 16-HR JOURNEY TO NFS, CASK PRESSURES WERE 19-34 PSI DUE TO VAPORIZATION CAUSED BY FUEL-SURFACE TEMPERATURES AS HIGH AS 180 F. WOODEN ENCLOSURES WERE THEN TRIED, AND LOUVERS ADJUSTED ACCORDING TO CASK SURFACE TEMPERATURE AND MANUFACTURERS CALCULATIONS. RUPTURE DISK DISCHARGE LINE WAS CONNECTED TO 55-GAL DRUM TO MONITOR FOR LEAKAGE.

*OPERATING EXPERIENCE + *SHIPPING CONTAINER + FUEL ELEMENT + NFS (NUCLEAR FUEL SERVICES)

17-09565 PETERSON RH
AEC REVIEW OF DRY SHIPPING TECHNIQUE AND OF REDUCED COOLANT FLOW DUE TO BOILER SCALE
PACIFIC GAS AND ELECTRIC COMPANY + DIVISION OF REACTOR LICENSING, USAEC
2 PAGES, APRIL 19, 1966, DOCKET 50-133, ATOMIC ENERGY CLEARING HOUSE, 12(18), PP. 16-17 (MAY 2, 1966)

DRL RECOMMENDS PROVIDING AN AUTOMATIC REFLOODING VALVE OPENING ON HIGH CHAMBER TEMPERATURE OR ELAPSED TIME, AND SUGGESTS REEVALUATION IN LIGHT OF CURRENT REDUCTION-IN-FLOW PROBLEM. DRL SUGGESTS THAT POWER BE RESTRICTED TO PRESENT 175-MW(TH) LEVEL BECAUSE OF A SIGNIFICANT UNCERTAINTY IN APPLYING BURNOUT MARGIN (BASED ON TOTAL FUEL-ELEMENT-FLOW CONDITIONS) TO INDIVIDUAL FUEL PINS.

*INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + *OPERATING EXPERIENCE + *SURFACE FILM DEPOSIT + FLOW BLOCKAGE + HUMBOLDT BAY + REACTOR, BOILING WATER

17-09588 RIDER BF + RUIZ CP + PETERSON JP + JAECH JL + SEYMOUR RS
ACCURATE NUCLEAR FUEL BURNUP ANALYSES. SEVENTEENTH QUARTERLY PROGRESS REPORT-DECEMBER 1965-FEBRUARY 1966
GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA
GEAP-5124 +. 40 PAGES, 2 FIGURES, 2 REFERENCES, 1966, CFSTI \$2.00 CY

SEVERAL IMPROVEMENTS NOTED IN METHOD REPORTED IN GEAP 4817.

*FUEL BURNUP + ISOTOPIC FRACTIONATION + REACTOR, POWER

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09754 LARGE COOLING TOWER FIRE AGAIN AFFIRMS VALUE OF AUTOMATIC SPRINKLER PROTECTION
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 273, 3 PAGES, 3 FIGURES, SEPTEMBER 30, 1966, DPI

A MILLION-DOLLAR WOODEN COOLING TOWER CAUGHT FIRE WHEN NORMAL VIBRATIONAL FLEXING OF MOTOR LEADS WORE THROUGH THE INSULATION. MOLTEN COPPER IGNITED THE JUNCTION-BOX RUBBER GASKETS AND THEN THE UPPER DECK. EVENTUALLY, AUTOMATIC SPRINKLERS OPERATED TO LIMIT LOSS TO 500 DOLLARS. MAGNETIC OVERLOAD TRIPS DID NOT WORK ON THIS AND OVER HALF THE OTHER THIRTY-NINE FAN MOTORS BECAUSE NORMAL VIBRATION HAD CAUSED MECHANICAL WEAR OF MOVING PARTS. THIS FACILITY IS NOW ROUTINELY TESTING SIMILAR TRIP DEVICES IN VIBRATION SERVICE, PROVIDING A WIRE SEPARATING DEVICE OR JUNCTION-BOX INSULATING FILL AND USING FIRE-RESISTANT TEFLON FOR JUNCTION-BOX GASKETS.

*FIRE + *HEAT SINK + FAILURE, COMPONENT + INCIDENT, ACTUAL, NONREACTOR + OPERATING EXPERIENCE + REACTOR, AEC OWNED

17-09755 MEDICAL TREATMENT FOR REACTOR TECHNICIAN IRRADIATED IN MANUAL ROD WITHDRAWAL ACCIDENT IN BELGIUM
1 PAGE, 1 FIGURE, NUCLEONICS WEEK 7(39), PAGE 6 (SEPTEMBER 29, 1966)

MEDICAL DETAILS WERE REVEALED AT THE FIRST CONFERENCE OF THE INTERNATIONAL RADIATION PROTECTION ASSOCIATION. VICTIM WAS KEPT IN A STERILE ENVIRONMENT AND GIVEN BLOOD TREATMENT, BONE GRAFTS WERE NOT NECESSARY. THE ACCIDENT WAS RECONSTRUCTED SO DOSE MEASUREMENTS COULD BE MADE TO HELP DETERMINE TREATMENT. TECHNICIAN FAILED TO COMPLY WITH WRITTEN INSTRUCTION FOR CHANGING ABSORBER RODS. SYNCHRONIZATION OF CONTROL RODS WAS DONE IN ADVANCE, AND AN ERROR WAS MADE IN HANDLING FUEL. CONFERENCE PAPERS FOCUSED ON ACCIDENTS, SHOWING HOW THEY HAPPENED AND COULD BE AVOIDED.

*ACCIDENT, CRITICALITY + *DOSE MEASUREMENT, EXTERNAL + *FAILURE, OPERATOR ERROR + *INCIDENT, ACTUAL, HUMAN ERROR + *RADIATION INJURY, TREATMENT OF + BELGIUM

17-09786 TABOR WH. + HURT SS
OAK RIDGE RESEARCH REACTOR QUARTERLY REPORT, JULY, AUGUST, AND SEPTEMBER OF 1965
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1351 + 35 PAGES, 15 TABLES, 7 FIGURES, NOVEMBER 22, 1965, CFSTI, \$2.00 CY, \$0.50 MN

THE SERVO AMPLIFIER FAILED, RESULTING IN AN INCREASE TO THE 36-MW(TH) REVERSE LEVEL, BECAUSE OF AN APPARENT LOSS OF SIGNAL FROM THE CHAMBER.

*FAILURE, COMPONENT + *INSTRUMENTATION, REGULATING + *REGULATING SYSTEM + ORR (OAK RIDGE RESEARCH REACTOR) + REACTOR, RESEARCH + REACTOR, TEST

17-09797 CHRISTENSEN J + GLESEN CB
PREDICTING PERFORMANCE OF D2O STEAM TURBINES IN BOILING HEAVY-WATER REACTORS
AB ATOMENERGI, STOCKHOLM, SWEDEN + STAL-LAVAL TURBINE CO., STOCKHOLM, SWEDEN
3 PAGES, 3 FIGURES, 6 REFERENCES, NUCLEONICS, 24(5), PP. 66-68 (MAY 1966)

ESTIMATES OF HEAVY-WATER LEAKAGE AND LIGHT-WATER CONTAMINATION WOULD INCREASE COST LESS THAN 0.1 MILL/KWHR, BASED ON TESTS AND EXPERIENCE IN MODERN TURBINES. RADIOLYTIC GAS RECOVERY WOULD REQUIRE A RECOMBINER. TRITIUM IN TURBINE WOULD REQUIRE STEAM-CLEARING BEFORE MAINTENANCE.

*ECONOMICS + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + TRITIUM

17-09798 THERMAL SHIELD VIBRATION ELIMINATED AT BIG ROCK POINT
2 PAGES, 3 FIGURES, 3 REFERENCES, NUCLEONICS, 24(5), PP. 64-65 (MAY 1966)

HALF THE THERMAL-SHIELD HOLDDOWN STUDS FAILED BECAUSE OF FATIGUE FAILURE. FLOW EXCITATION CAUSED A SELF-SUSTAINED VIBRATION, AFTER WEAR BETWEEN THE ALIGNMENT PINS AND SHIELD OPENED CLEARANCES. THE TOP SEAL WAS REVISED AND THE BOTTOM SEAL WEDGED OPEN. BIG ROCK PROBLEMS HAVE BEEN CONVENTIONAL MECHANICAL PROBLEMS, MAYBE BECAUSE THE CHALLENGING R AND D EFFORT RECEIVED MORE ATTENTION.

*FAILURE, FATIGUE + *GAMMA + *HEAT GENERATION, INTERNAL + *SHIELDING + BIG ROCK POINT + MODIFICATION, SYSTEM OF EQUIPMENT + OPERATING EXPERIENCE + REACTOR, BOILING WATER

17-09799 PROSPECTS FOR PLUTONIUM RECYCLE
6 PAGES, 5 TABLES, 8 FIGURES, 9 REFERENCES, NUCLEONICS, 24(5), PP. 58-63 (MAY 1966)

STUDIES HAVE BEEN MADE OF PU-U MIXTURES IN WATER REACTORS. ALTHOUGH AT END OF CORE LIFE, HALF THE POWER COMES FROM FISSION OF INBRED PU, STARTING WITH PU FUEL MAY CAUSE SOME DESIGN CHANGES. SAXTON EXPERIENCE SHOWS (1) OPTIMAL FUEL-TO-MODERATOR RATIO SIGNIFICANTLY DIFFERENT, (2) ROD WORTH AND SOLUBLE POISON WORTH REDUCED, (3) LOCAL POWER-PEAKING INCREASED AT CONTROL-ROD SLOTS AND AT BOUNDARIES BETWEEN U AND PU-U REGIONS. BWR CALCULATIONS SHOW A NET REDUCTION (3 PERCENT) IN COLD EXCESS REACTIVITY, WHICH MUST BE CONTROLLED BY RODS AND BURNABLE POISON, LARGELY BECAUSE OF PU-240 ABSORPTIONS. REACTIVITY COEFFICIENTS ARE MADE MORE NEGATIVE.

*ECONOMICS + *FUEL ELEMENT + *PLUTONIUM + CONTROL ROD WORTH + HOT SPOT + OPERATING EXPERIENCE + REACTIVITY COEFFICIENT + REACTOR, BOILING WATER + REACTOR, PRESSURIZED WATER + SAXTON

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09811 COX JA REACTOR OPERATIONS
OAK RIDGE NATIONAL LABORATORY
2 PAGES, NUCLEAR NEWS, 9(5), PP. 35-36 (MAY 1966)

ANS REACTOR OPERATIONS DIVISION WILL PUBLISH REACTOR INCIDENTS (WITHOUT ATTRIBUTION) WHICH WOULD NOT ORDINARILY BE PUBLISHED. FIRST SUCH REPORT. HELIARC WELDING CABLES LYING NEAR INSTRUMENTATION CABLES CAUSED STARTUP COUNTING RATE TO INCREASE A HUNDREDFOLD. THIS OCCURRED IN A POWER REACTOR THAT HAD BEEN FUELED BUT HAD NOT YET BEEN MADE CRITICAL. WELDERS INSTRUCTIONS WERE IMPROVED.

INCIDENT, ACTUAL, GENERAL + INSTRUMENTATION, NUCLEAR + REACTOR, POWER

17-09812 BONUS RESPIRATORY PROTECTION
PUERTO RICO WATER RESOURCES AUTHORITY
2 PAGES, MARCH 17, 1966, DOCKET 115-4, ATOMIC ENERGY CLEARING HOUSE, 12(17), PP. 14-15 (APRIL 25, 1966)

APPLICATION WAS MADE TO (APPARENTLY) TAKE CREDIT FOR MASKS WORN ROUTINELY IN CERTAIN PLANT AREAS HAVING AIRBORNE CONTAMINATION GASES AND RADIOACTIVE PARTICLES. AN ASSAULT MASK WITH AN M-11 CANISTER, USEFUL FOR PARTICLES LARGER THAN 0.3 MICRON IN DIAMETER, IS USED IN AREAS THAT HAVE LESS THAN 50 TIMES THE MPC OF THE MIXTURE OF ISOTOPES INVOLVED. PORTABLE AIR TANK USED WHEN MPC IS EXCEEDED MORE THAN FIFTYFOLD. CLEAN-AIR BLOWER AND MASK (DRAWING AIR FROM AREA HAVING CONCENTRATIONS LESS THAN 100 TIMES THE MPC).

*PERSONNEL PROTECTIVE DEVICE + *RADIATION SAFETY AND CONTROL + AIRBORNE RELEASE + BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

17-09813 FISSION GAS RELEASES WITHIN BONUS CONTAINMENT SHELL FOLLOWING SCRAMS
DIVISION OF REACTOR LICENSING, USAEC
4 PAGES, APRIL 14, 1966, DOCKET 115-4, ATOMIC ENERGY CLEARING HOUSE, 12(17), PP. 15-18 (APRIL 25, 1966)

SEVERAL RELEASES TOOK PLACE EARLY IN 1966 AFTER SCRAMS AS STEAM-SAMPLING STATIONS WERE LEFT OPEN. MAIN STEAM-BYPASS VALVES AND EMERGENCY CONDENSOR VALVES LEAKED ON BEING OPENED, AND THE GLAND SEAL EXHAUSTER LOOP SEAL BEING DRY. ON THREE OCCASIONS, MASKS HAD TO BE WORN BY OPERATORS. ON NO OCCASION WAS DISCHARGE TO PUBLIC DANGEROUS. KRYPTON-88 WAS THE MAJOR ACTIVITY. NO REASON ADVANCED FOR ITS PRESENCE IN THE STEAM.

*AIRBORNE RELEASE + BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + FISSION GAS RELEASE + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

17-09814 REACTOR VESSEL CLAD PENETRATION AND HYDROGEN EMBRITTLEMENT
DIVISION OF REACTOR LICENSING, USAEC
2 PAGES, APRIL 18, 1966, DOCKET 50-29, ATOMIC ENERGY CLEARING HOUSE, 12(17), PP. 19-20 (APRIL 25, 1966)

DRL (IN REPLY TO YANKEE EVALUATION OF CLAD PENETRATION) BELIEVES THAT EVIDENCE NOT SUFFICIENT TO ESTABLISH THAT A302B VESSEL IS NOT SUSCEPTIBLE TO HYDROGEN EMBRITTLEMENT IN CONTACT WITH WATER, AND REQUESTS ADDITIONAL INFORMATION. ALSO REQUESTS VESSEL NDT PREDICTIONS BASED ON RECENT SURVEILLANCE-SPECIMEN MEASUREMENTS. ENCLOSURE PROVIDES JUSTIFICATION FOR CONCERN.

*BRITTLE FRACTURE + *CONTAINMENT, PRESSURE VESSEL + *HYDROGEN + OPERATING EXPERIENCE + REACTOR, PRESSURIZED WATER + YANKEE

17-09815 DRL REQUESTS YANKEE AMEND TECHNICAL SPECIFICATIONS ON BORON CONCENTRATION DURING STARTUP OR OTHERS NOT IMPORTANTLY RELATED TO SAFETY
DIVISION OF REACTOR LICENSING, USAEC
1 PAGE, APRIL 22, 1966, DOCKET 50-29, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 45 (MAY 9, 1966)

DRL NOTES THAT YANKEE OPERATED 36 HR ABOVE 15 MW DURING A STARTUP WITH HIGHER-THAN-SPECIFICATION LIMIT ON BORON, STATES THAT DRL ANALYSIS INDICATES NO SIGNIFICANT SAFETY PROBLEM INVOLVED AND SUGGESTS THAT THE SPECIFICATION BE REVISED. DRL ALSO INVITES YANKEE TO LOOK AT TECHNICAL SPECIFICATIONS AND REVISE AREAS NOT IMPORTANTLY RELATED TO SAFETY (BASED ON APPROPRIATE SAFETY ANALYSIS).

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *POISON, SOLUBLE + REACTOR, PRESSURIZED WATER + YANKEE

17-09816 URRUTIA RV
BONUS REQUESTS CHANGE IN HEAT RATING OF SUPERHEATER FUEL, SUPPLIES LIST OF INSTRUMENT NOT FAIL-SAFE
PUERTO RICO WATER RESOURCES AUTHORITY
1 PAGE, APRIL 20, 1966, DOCKET 115-4, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 44 (MAY 9, 1966)

DATA SUBMITTED TO ACRS LISTING ALL PLACES WHERE FAILURE OF A SINGLE COMPONENT CAN INHIBIT SAFETY ACTION OR CONTAINMENT ISOLATION. BONUS REQUESTS SUPERHEATER HEAT RATING BE INCREASED FROM 9 TO 12 KW/FT AT 50 MW(T). OTHERWISE, OPERATION WITH LOW FEEDWATER TEMPERATURE TO OBTAIN LOW PROPER STEAM FLOW (TO OBTAIN REQUIRED 900 F SUPERHEATER OUTLET TEMPERATURE) RESULTS IN LOSS OF ELECTRICAL GENERATION.

*SAFE FAILURE CRITERION + BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + HEAT TRANSFER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09818 MCEWEN LH
THREE CONTAINMENT ISOLATIONS AT GETR, MARCH 24, 1966
GENERAL ELECTRIC COMPANY, PLEASANTON, CALIFORNIA
1 PAGE, APRIL 25, 1966, DOCKET 50-70, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 43 (MAY 9, 1966)

DURING A PLANNED SHUTDOWN, A CAPSULE EXPERIMENT WAS DEPRESSURIZED. A SUPERFLUOUS VALVE IN THE SAMPLE SYSTEM OF THE CAPSULE HAD BEEN LEFT PARTIALLY OPEN AND LEAKED TO THE CONTAINMENT.

*AIRBORNE RELEASE + *FAILURE, OPERATOR ERROR + GETR (GENERAL ELECTRIC TEST REACTOR) + IN PILE LOOP + IRRADIATION TESTING + REACTOR, TEST

17-09819 ANDERSON AN
REVISION OF TECHNICAL SPECIFICATION LIMIT ON SHUTDOWN MARGIN
CONSOLIDATED EDISON COMPANY
1 PAGE, APRIL 20, 1966, DOCKET 50-3, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 43 (MAY 9, 1966)

MINIMUM WORTH OF CONTROL RODS (0.10) WAS CHANGED FROM COLD-CLEAN TO HOT-CLEAN ZERO-POWER CONDITION BECAUSE COLD SHUTDOWN IS ENSURED BY BORIC ACID SYSTEM. THE MINIMUM WORTH MEASURED FOR CORE B HAD BEEN 0.086, COLD CLEAN.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *SHUTDOWN MARGIN + INDIAN POINT I + REACTOR, PRESSURIZED WATER

17-09859 DOOSE C
BEAM TUBE EQUIPMENT FOR THE FRJ-2 (DIDO) COLD NEUTRON SOURCE
KERNFORSCHUNGSANLAGE JULICH
AERE-TRANS-1043 +. 21 PAGES, 6 FIGURES, 19 REFERENCES, AUGUST, 1965, HMSO

SUBTHERMAL NEUTRONS ARE PRODUCED IN A BEAM HOLE USING 20-DEGREES-K LIQUID HYDROGEN. RATHER THAN DESIGN AN EXPLOSION-PROOF SYSTEM, THEY PREVENT AIR (OXYGEN) ENTERING BY AN ELABORATE HELIUM BARRIER, WITH ICING-MIRROR SENSORS FOR AIR LEAKAGE.

*GERMANY + *HYDROGEN + *IN PILE EXPERIMENT + *IN PILE LOOP + *IRRADIATION TESTING + *REACTOR, RESEARCH + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + REACTOR, HEAVY WATER

17-09870 AUNGST RC
ADDITIONAL CRACK PROPAGATION TESTS ON ZIRCALOY-2 REACTOR PRESSURE TUBES
BATTELLE-NORTHWEST
BNWL-SA-179 + CONF-651017-3 +. 30 PAGES, FIGURES, SEPTEMBER 20, 1965, ELECTROCHEMICAL SOCIETY MEETING, BUFFALO, CFSTI, \$2.00 CY, \$0.50 MN

A REPRODUCIBLE DROP-WEIGHT TEST WAS DEVELOPED WITH A UNIQUE CRACK-STARTER IN THE FORM OF A SMALL PIECE OF ZIRCALOY WIRE EMBRITTLED BY HYDROGEN AND RESISTANCE WELDED TO THE TENSION SIDE OF THE SPECIMEN. RESULTS SHOW A DEPENDENCE OF THE NDT ON HYDROGEN CONTENT, CONSISTENT WITH ENGLISH DATA. RESULTS OF FRACTURE TESTS ON SLOTTED-TUBE SPECIMENS COVERING A WIDE RANGE OF TEMPERATURE HAVE BEEN USED TO CONSTRUCT A FRACTURE ANALYSIS DIAGRAM. FAILURE OCCURS FOR A GIVEN DEFECT SIZE AT THE SAME FRACTION OF YIELD STRENGTH FOR ALL TEMPERATURES FROM BELOW THE NDT TO ABOVE THE CRACK-ARREST TEMPERATURE. THIS BEHAVIOR DIFFERS FROM THAT OF STEEL PLATE IN THAT THE LATTER EXHIBITS A MARKED RISE IN FAILURE STRESS AT TEMPERATURES ABOVE THE NDT.

*ZIRCALOY + BRITTLE FRACTURE + NDT DATA (NIL DUCTILITY TRANSITION) + REACTOR, PRESSURE TUBE

17-09871 FRESHLEY MD + PANISKO FE
PRTR FUEL ELEMENT EXPERIENCE
BATTELLE-NORTHWEST
BNWL-SA-409 + CONF-651119-3 +. 12 PAGES, TABLES, OCTOBER 14, 1965, LIBBY COCKCROFT INFORMATION EXCHANGE MEETING, HARWELL, ENGLAND, CFSTI, \$1.00 CY, \$0.50 MN

BRIEF REVIEW OF PROGRAM WHERE UO₂-PUO₂ FUELS ARE OPERATED WITH MOLTEN CENTERS TO DETERMINE IF THERE ARE FACTORS THAT LIMIT MIXED-FUEL ELEMENTS TO POWERS LESS THAN THAT FOR UO₂ FUELS. FISSION-GAS MEASUREMENTS INDICATE 100 PERCENT RELEASE FROM FUEL ABOVE AND 10 PERCENT RELEASE BELOW 1800 C. MELTING BEGINS AT 655 W/CM. THERE IS EVIDENCE THAT LIQUID FUEL MAY FLOW INTO RADIAL CRACKS DURING OPERATION. A SLIT-CLAD ELEMENT DID NOT WATERLOG, BUT SLIT WIDENED. FISSION-PRODUCT RELEASE RATE IS GREATER FROM VIBRATIONALLY PACKED FUEL THAN FROM SWAGED ELEMENTS. SEVERE HYDRIDING OCCURRED IN ONE ZIRCALOY-2-CLAD ELEMENT.

*CENTERLINE MELTING + *HYDROGEN + *IN PILE LOOP + *IRRADIATION TESTING + *PRTR (PLUTONIUM RECYCLE TEST REACTOR) + *ZIRCALOY + FUEL MELTDOWN + OPERATING EXPERIENCE + PLUTONIUM + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST

17-09872 GARIGLIANO NUCLEAR POWER PLANT. OPERATION REPORT FOR THE 3RD QUARTER OF 1965. TECHNICAL REPORT
ENTE NAZIONALE PER L ENERGIA ELETTRICA, ROME, ITALY
TID-22434 +. 10 PAGES, SEPTEMBER 30, 1965, CFSTI, \$1.00 CY, \$0.50 MN

AT THE END OF AUGUST 1965, CORE PRESSURE DROP INCREASED SO ONE RECIRCULATION PUMP WAS SHUT DOWN AND POWER REDUCED TO 90 PERCENT. UNDERWATER TV INSPECTION REVEALED POROUS DEPOSITS ON BOTTOM OF CORE GRID PLATE. FUEL ELEMENTS WERE REMOVED FOR CLEANING.

*ITALY + *OPERATIONS REPORTS, GENERAL + *REACTOR, BOILING WATER + *SURFACE FILM DEPOSIT + FLOW BLOCKAGE + FLOW ORIFICE OR RESTRICTION

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-09942 ZERO-POWER REACTIVITY MEASUREMENTS

ARGONNE NATIONAL LABORATORY

ANL-6849 +. 6 PAGES, 4 FIGURES, 1 TABLE, NOVEMBER, 1964, PAGES 15-20 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

ZERO-POWER EXPERIMENTS SHOWED INSUFFICIENT EXCESS REACTIVITY TO ATTAIN FULL POWER. SPIKING WITH 9.9 WT PERCENT FUEL IN PERIPHERY GAVE ONLY MINOR REACTIVITY GAIN AND ENDANGERED STUCK ROD CRITERION. DUMMY FUEL TUBES WERE ADDED TO EACH FUEL ELEMENT TO DECREASE METAL-TO-WATER RATIO. POISON RODS WERE ADDED NEAR CONTROL RODS TO REDUCE THEIR WORTH. VARIOUS SAMPLE CONTROL MATERIALS WERE REACTIVITY-TESTED IN REACTOR IN CASE OF FAILURE OF STAINLESS-STEEL-CLAD BORAL PLATES.

*CONTROL ROD + *MATERIAL + *MODIFICATION, SYSTEM OR EQUIPMENT + *REACTIVITY, EXCESS +
*REACTOR STARTUP TESTING + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + DANGER COEFFICIENT +
REACTOR, BOILING WATER

17-09943 INSTRUMENT FAILURES

ARGONNE NATIONAL LABORATORY

ANL-6849 +. 11 PAGES, NOVEMBER, 1964, PAGES 91-101 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

SEVERAL FAILURES OCCURRED DURING THE EXPERIMENTS WITH CORE B-2 FOR BORAX-V. THE LOW-STEAM-FLOW SCRAM CIRCUIT FAILED TO OPERATE DURING A TEST BECAUSE OF DIRT IN THE STEAM LINES AND UNSATISFACTORY VENTING OF THE DIFFERENTIAL-PRESSURE CELL. PERIOD CIRCUITS WERE MODIFIED AFTER AN EXCESSIVE NUMBER OF SPURIOUS SCRAMS. THE IN-REACTOR-VESSEL INSTRUMENTATION FAILED TO OPERATE. THE BORON POISONING SYSTEM HAD TROUBLE WITH PIPE-LINE PLUGGING, AND PRECIPITATION AND PLATEOUT OF BORIC ACID.

*FAILURE, GENERAL + *FAILURE, INSTRUMENT + *SAFETY INJECTION +
BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + INSTRUMENTATION, IN CORE + INSTRUMENTATION, PROTECTIVE +
PERIOD METER + POISON, SOLUBLE + REACTOR, BOILING WATER

17-09944 POWER-DISTRIBUTION MEASUREMENTS. TRANSFER-FUNCTION MEASUREMENTS AND STABILITY ANALYSIS

ARGONNE NATIONAL LABORATORY

ANL-6849 +. 39 PAGES, 28 FIGURES, 1 TABLE, NOVEMBER, 1964, PAGES 35-50, 66-90 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

A VERY EXTENSIVE SET OF EXPERIMENTS WERE PERFORMED ON THE B-2 CORE FOR BORAX-V. POWER MAPPING WITH REMOVABLE FUEL RODS, AGREED WITH FLUX-SCANNING WIRE METHODS. A ROD OSCILLATOR AND ANALOG CROSS-CORRELATION EQUIPMENT WERE USED TO MEASURE THE REACTOR TRANSFER FUNCTIONS FOR POWERS UP TO 16 MW. THE MEASUREMENTS AGREED WITH THE THEORETICAL MODEL AND WERE USED IN STABILITY STUDIES THAT INDICATED THAT THE REACTOR WAS VERY STABLE UP TO 16 MW, AND THE TRENDS SUGGESTED A POWER-LEVEL INSTABILITY IN THE REGION OF 30 TO 40 MW. MEASUREMENTS AND DESCRIBING FUNCTION CALCULATIONS INDICATED THAT THE TRANSFER FUNCTIONS WERE NOT DISTORTED SIGNIFICANTLY BY THE NONLINEARITIES CAUSED BY LARGE REACTIVITY DISTURBANCES OR CHANGES IN POWER LEVEL. NOISE-ANALYSIS EXPERIMENTS WERE NOT CONCLUSIVE.

*ANALYTICAL MODEL + *COMPARISON, THEORY AND EXPERIENCE + *REACTOR STABILITY + *TEST, PLANT RESPONSE +
*TRANSFER FUNCTION + BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + COMPUTER, DIGITAL +
MEASUREMENT, GENERAL + NOISE ANALYSIS + OPERATING EXPERIENCE + REACTOR, BOILING WATER

17-09945 PLANT PERFORMANCE AND TESTS

ARGONNE NATIONAL LABORATORY

ANL-6849 +. 11 PAGES, NOVEMBER, 1964, PAGES 91-101 OF EXPERIMENTS ON BOILING CORE B-2, BORAX-V, CFSTI, \$4.00

REACTOR WATER LEVEL INSTRUMENTATION -- A COLD REFERENCE LEG WAS USED AFTER HOT LEG GAVE FALSE READINGS DURING BLOWDOWN. TRUE REACTOR WATER LEVEL WAS MEASURED AT VARIOUS POWERS BY INJECTING SODIUM NITRATE. NA24 STAYS IN WATER, OBSERVED WITH MOVABLE STEAM PROBE. TEE-SHAPED CONTROL-ROD SHROUDS BUCKLED (CRUCIFORMS RETAINED THEIR SHAPE). X8001 FUEL-BOX RIVETS FAILED BECAUSE OF LOW CREEP STRENGTH- REPLACED BY NICKEL. SPRING-LOADED RELIEF VALVES ON FEEDWATER PUMPS WERE REPLACED WITH ORIFICES. UNSHIELDED 5000-R/HR CORE COMPONENTS WERE MOVED FROM VESSEL TO STORAGE BY SHIELDING-CRANE OPERATOR, WHO USED A SYSTEM OF INDICES ON CRANE TO POSITION THE EQUIPMENT.

*FAILURE, GENERAL + *OPERATING EXPERIENCE + *REMOTE MANIPULATING AND VIEWING + *SHIELDING +
BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS) + CONTROL ROD + FUEL ELEMENT +
INSTRUMENTATION, LIQUID LEVEL DETECTION + REACTOR, BOILING WATER + VALVE

17-10095 CHEATHAM OC

RADIATION SOURCE LOST AUGUST 12, 1966

SCHLUMBERGER WELL SURVEYING CORPORATION, HOUSTON

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(40), PAGES 20-21 (OCTOBER 4, 1966)

A 1.5-CURIE SOURCE (CS-137) WAS LOST IN A GAS WELL AT DEPTH 8496 FT NEAR CANTON, OKLAHOMA, ON JULY 26, 1966. THE WELL WAS NOT CAPPED NOR WAS THE CAPSULE CEMENTED IN PLACE BECAUSE OF POSSIBLE LOSS OF PRODUCTION. THE SOURCE IS WELL PROTECTED IN MONEL AND STAINLESS STEEL HOUSINGS AND IS IN A CERAMIC-MICROSPHERE MATRIX. THE WELL WILL BE ABANDONED WITHIN 20 YEARS, WELL BEFORE ANY PREDICTED FAILURE.

*SOURCE, RADIATION, LOST + CESIUM + CORROSION

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-10102 OBOYLE MJ
YANKEE CORE EVALUATION PROGRAM QUARTERLY PROGRESS REPORT FOR THE PERIOD ENDING JUNE 30, 1966
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA
WCAP-6081 +. 76 PAGES, 12 TABLES, 15 FIGURES, AUGUST 1966, DOCKET NO. 50-29 CFSTI \$3.00 CY, \$0.50 MN

A COMPUTATION IS BEING MADE TO SEE IF LOCAL BOILING EXISTED DURING CORE IV IN THE REGIONS WHERE LOOSE CRUD WAS FOUND. VARIOUS INVESTIGATION OF ISOTOPIC CONCENTRATIONS IN SPENT FUEL ARE REPORTED. STAINLESS-STEEL-CLADDING WAS SHIPPED TO GE FOR USE IN THEIR CLAC-TESTING PROGRAM.

*CLAD + *FUEL BURNUP + *SURFACE FILM DEPOSIT + REACTOR, PRESSURIZED WATER + YANKEE

17-10125 PLUTONIUM RECYCLE PROGRAM (EBWR)
ARGONNE NATIONAL LABORATORY
ANL-7132 +. 4 PAGES, 2 TABLES, 2 FIGURES, JANUARY 25, 1966, PP. 49-52 OF ANL REACTOR DEVELOPMENT PROGRAM
PROGRESS REPORT, DECEMBER 1965, CFSTI, \$3.00 CY

FOR CERTAIN CONTROL ROD CONFIGURATIONS AN INVERTED ROD-WORTH EFFECT WAS NOTED. WHEN THE CENTRAL ROD WAS PARTIALLY INSERTED AND THE EIGHT-ROD BANK WAS FULLY WITHDRAWN TO 48 IN., INSERTION OF THE BANK CAUSED A SLIGHT INCREASE IN REACTIVITY. THESE EFFECTS ARISE BECAUSE THE LOWER 13 IN. OF THE CONTROL ROD FOLLOWER IS STAINLESS STEEL, A MODERATELY STRONG NEUTRON ABSORBER, INSTEAD OF ZIRCALOY. IN ADDITION, THE ROD CROSS SECTION IN THE STAINLESS STEEL REGION IS SMALLER THAN IN THE ZIRCALOY FOLLOWER SECTION, SO THAT MORE BORIC ACID IN THE WATER IS PRESENT AT THIS REGION OF THE ROD. WITH THE EIGHT-ROD BANK OR THE CENTRAL ROD PARTIALLY INSERTED, THE FLUX IS PINCHED DOWN TO THE LOWER PART OF THE SYSTEM, CAUSING THE STAINLESS STEEL PORTION OF THE FOLLOWERS OF THE FULLY WITHDRAWN RODS TO BE IN A REGION OF GREATER IMPORTANCE. WHEN THE RODS ARE INSERTED, INITIALLY THE POSITIVE REACTIVITY EFFECT OF REMOVING STAINLESS STEEL AND BORIC ACID FROM A REGION OF HIGH IMPORTANCE IS GREATER THAN THE NEGATIVE REACTIVITY EFFECT OF INSERTING THE CONTROL RODS INTO A REGION OF SMALL IMPORTANCE.

*CONTROL ROD WORTH + *EBWR (EXPERIMENTAL BOILING WATER REACTOR) + *REACTIVITY EFFECT, ANOMALOUS + REACTOR, BOILING WATER

17-10134 AVAILABLE WHOLE-BODY COUNTING SERVICES
U. S. ATOMIC ENERGY COMMISSION, DIVISION OF OPERATIONAL SAFETY
HEALTH AND SAFETY INFORMATION BULLETIN NO. 233, 1 PAGE, MAY 9, 1966

AEC CONTRACTORS MAY USE ON-SITE WHOLE-BODY-COUNTING FACILITIES, USING TRAILER-MOUNTED EQUIPMENT SUPPLIED BY AEC FIELD OFFICES. THIS CAN TAKE THE PLACE OF THE ANALYSIS OF EXCRETA IN UNIQUE OR TROUBLESOME PROBLEMS, OR FOR DETERMINING POSTINCIDENT BODY BURDEN.

*INSTRUMENTATION, RADIATION MONITORING + *MAXIMUM PERMISSIBLE BODY BURDEN + INGESTION

17-10135 PLUTONIUM FIRE OUTSIDE OF GLOVEBOX LEADS TO \$30,000 CONTAMINATION CLEANUP COST
DIVISION OF OPERATIONAL SAFETY, U. S. ATOMIC ENERGY COMMISSION
SERIOUS ACCIDENTS ISSUE 264 +. 2 PAGES, MAY 13, 1966, DPI

A PLUTONIUM ROD AND SOME PLUTONIUM-PLATED PIECES WERE DOUBLE-BAGGED IN AN ARGON ATMOSPHERE AND REMOVED. APPARENTLY SOME AIR LEAKED IN AND REACTED WHILE THE MATERIAL WAS LEFT ON THE FLOOR OVER THE WEEKEND. WHEN IT WAS TOUCHED, IT BURST INTO FLAMES. THIS INCIDENT EMPHASIZES PROPER STORAGE IN APPROVED LOCATIONS. CLEANUP EXPENSES STILL CONTINUE, THREE MONTHS AFTER THE ACCIDENT.

*FIRE + *GLOVE BOX + *PLUTONIUM + INCIDENT, ACTUAL, HUMAN ERROR

17-10148 HARRER JM
REACTOR CONTROL EXPERIENCE
COMBUSTION ENGINEERING, INC.
7 PAGES, 2 FIGURES, 1 TABLE, 9 REFERENCES, POWER REACTOR TECHNOLOGY, 8(4), PP. 221-227 (FALL 1965)

REVIEW OF PAPERS ON EXPERIENCE WITH CONTROL AND SAFETY SYSTEMS (ANS CONFERENCE ON REACTOR OPERATING EXPERIENCE). NONE OF THE 20 REACTOR ACCIDENTS OR INCIDENTS HAVE RESULTED FROM FAILURE OF SAFETY COMPONENTS BUT RATHER FROM THE SAFETY SYSTEM BEING INHERENTLY UNABLE TO PERFORM CORRECTLY UNDER ACCIDENT CONDITIONS. ROD-DROP-TIME TESTS DID NOT GIVE ANY INDICATION OF SWELLING RODS. A LIQUID-POISON-INJECTION SYSTEM DID NOT FUNCTION UNDER TEST AND HAD TO BE REDESIGNED. OTHER TOPICS - SPRINGS VS PNEUMATIC SYSTEMS FOR ROD DRIVES, MODERATOR CONTROL OF CRITICAL FACILITIES, SUBCRITICAL REACTIVITY MEASUREMENTS, AND ON-LINE DIGITAL COMPUTERS.

*CONTROL SYSTEM + *FAILURE, DESIGN ERROR + *FAILURE, SCRAM MECHANISM + *OPERATING EXPERIENCE + *POISON, SOLUBLE + *REACTOR SAFETY SYSTEM + *REVIEW + *TEST, CONTROL ROD DRIVE + PLANT PROTECTIVE SYSTEM + SAFETY INJECTION + TEST, SYSTEM OPERABILITY

17-10155 MOORE JC
RESEARCH REACTOR FAULT ANALYSIS - PART 1
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
6 PAGES, 1 TABLE, 6 FIGURES, NUCLEAR ENGINEERING, 11(118), PP. 195-202 (MARCH, 1966)

A FAULT-REPORTING AND ANALYSIS SCHEME ESTABLISHED IN 1960 AT HARWELL IS REVIEWED. ARTICLE DESCRIBES THE MATHEMATICAL TREATMENT OF DATA, USING LIDO AS AN EXAMPLE. IN GENERAL, (1) EXAMINATION OF MINOR FAULTS (NUISANCE) COULD OFTEN BE USED TO ASSESS THE LIKELIHOOD OF MAJOR

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-10155 *CONTINUED*

FAULTS (POTENTIALLY UNSAFE) ARISING, (2) MORE-EFFECTIVE PREVENTIVE MAINTENANCE OBTAINS IF BASED ON FAULT-REPORTING DATA TO DETERMINE WHERE TO CONCENTRATE EFFORT, (3) A PRECURSOR RELATIONSHIP BETWEEN MINOR FAULTS AND VARIOUS MAJOR FAULTS SHOULD NOT BE IGNORED.

*FAILURE, GENERAL + *INCIDENT, ACTUAL, GENERAL + *OPERATING EXPERIENCE + *RELIABILITY ANALYSIS + REACTOR, RESEARCH + UNITED KINGDOM

17-10163 LESSONS LEARNED FROM INVESTIGATION OF A MINOR INCIDENT AT A SMALL PLUTONIUM LABORATORY DIVISION OF OPERATIONAL SAFETY, U. S. ATOMIC ENERGY COMMISSION
SERIOUS ACCIDENTS ISSUE 265 +. 2 PAGES, 1 FIGURE, MAY 27, 1966, DPI

A SPRINKLER HEAD OPENED (FALSE ALARM) IN A FANHOUSE ABOVE A MASS SPECTROGRAPH. ALTHOUGH THE INITIAL DAMAGE ESTIMATE WAS 50,000 DOLLARS, THE ACTUAL LOSS WAS ONLY 410 DOLLARS BECAUSE SPRAYING THE ELECTRONIC EQUIPMENT WITH A SOLUBLE DEHYDRATING AGENT AND HEATING REMOVED THE WATER. THE SPRINKLER HEAD WAS ACTIVATED BY FREEZING OF WATER TRAPPED IN A BRANCH CRY-PIPE LINE. THE BRANCH LINE HAD THE WRONG SLOPE, SO WATER USED IN SYSTEM TESTS DID NOT DRAIN.

*FAILURE, DESIGN ERROR + *FIRE + *SPRAY, GENERAL + INCIDENT, ACTUAL, RECOVERY FROM

17-10172 WEARNE SP + HUNT JA
LOGICAL DESIGN OF POWER REACTOR PLANT LAYOUT
UNIVERSITY OF MANCHESTER, INSTITUTE OF SCIENCE AND TECHNOLOGY + G.E.C. (PROCESS ENGINEERING) LTD., ERITH, KENT, ENGLAND
12 PAGES, 5 FIGURES, 9 REFERENCES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP 83-94 (JANUARY 1966)

BRIEF DISCUSSION OF LAYOUT OF A POWER REACTOR PLANT. EXAMPLE OF ACCESS AND CHANGE ROOM, WHEREIN A DOOR CAN BE LOCKED IN EITHER OF TWO POSITIONS TO GIVE ENTIRELY DIFFERENT TRAFFIC PATTERNS, DEPENDING ON CONTAMINATION CONTROL NECESSARY.

*RADIATION SAFETY AND CONTROL + DESIGN CRITERIA + REACTOR, GAS COOLED + UNITED KINGDOM

17-10204 TABOR WH + HURT SS
OAK RIDGE RESEARCH REACTOR QUARTERLY REPORT, OCTOBER, NOVEMBER, AND DECEMBER OF 1965
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1503 +. 35 PAGES, 16 TABLES, 4 FIGURES, APRIL 14, 1966, CFSTI, \$2.00 CY, \$0.50 MN

DIOCTYL PHOSPHATE CHECKS ON OFF-GAS FILTERS SHOWED ONE BANK ONLY 99.84 PERCENT EFFICIENT DUE TO DAMAGE BY RAIN WATER. EXCESSIVE NOISE WAS INDICATED ON NEUTRON-LEVEL INSTRUMENTS AFTER ROD MOVEMENTS TO OVERCOME XENON BURNUP CEASED. TESTS SHOWED THAT THE NOISE WAS NOT POWER-DEPENDENT. CONTROL RODS ON SOUTH SIDE APPEARED TO BE VIBRATING MORE. REPLACEMENT OF UPPER BEARING ASSEMBLIES REDUCED AMPLITUDE OF OSCILLATIONS.

*FILTER, DAMAGED + *NOISE ANALYSIS + *ORR (OAK RIDGE RESEARCH REACTOR) + INSTRUMENTATION, NUCLEAR + REACTOR, TEST

17-10205 CVTR CHANGE 11 - INCREASED PRESSURIZER LIQUID CONTENT AT POWER
CAROLINAS VIRGINIA NUCLEAR POWER ASSOCIATES, INC., PARR, SOUTH CAROLINA
2 PAGES, OCTOBER 4, 1966, DOCKET NO. 50-144, PDR

CVTR ALLOWED LIQUID VOLUME INCREASE FROM 40 TO 46 CUBIC FT TO ALLOW MORE MARGIN FROM WATER SHRINKAGE DURING OPERATIVE CHANGES WHICH COULD BARE THE HEATERS. PREVIOUS ANALYSIS (CVNA-47) SHOWED THE VAPOR VOLUME TO BE ACCEPTABLE AND THAT IT WILL NOT BE FILLED BY WATER IN REACTIVITY OR LOAD TRANSIENTS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *SAFETY EVALUATION + CVTR (CAROLINAS VIRGINIA TUBE REACTOR) + PRESSURIZER + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

17-10262 CHASSANY JP + COHENDY G + RODIER J
RADIOPROTECTION AND DECONTAMINATION OPERATION ON THE CENTRAL VIBRATING CHANNELS OF THE REACTOR G.3
COMMISSARIAT A L ENERGIE ATOMIQUE, CHUSCLAN, FRANCE
CEA-R-2781 +. 19 PAGES, 3 FIGURES, MAY, 1965, DEP. MN, IN FRENCH

THE DOSE RATE IN THE VIBRATING CHANNELS ROOM OF THE DISCHARGE SYSTEM, WHICH IS DUE TO THE CONTAMINATION OF ONE OF THE CHANNELS BY A RUPTURED CAN, WAS HIGH. IT WAS NECESSARY TO INTERVENE IN ORDER THAT NORMAL MAINTENANCE COULD BE CARRIED OUT ON THIS EQUIPMENT. THE OPERATION WAS CARRIED OUT FROM A NEIGHBOURING ROOM, USING CLEANING TUBES, AND THEN DIRECTLY, AFTER NUMEROUS PRECAUTIONS HAD BEEN TAKEN. RADIO-PROTECTION WAS MADE VERY DIFFICULT BECAUSE OF THE IRRADIATION AND OF THE POWDERY STATE OF THE CONTAMINATION. THE AVERAGE INDIVIDUAL INTEGRATED DOSE FOR THE 122 PERSONS HAVING TAKEN PART IN THIS 2-MONTH OPERATION WAS 362 MREM. THANKS TO THE CLOSE COLLABORATION BETWEEN THE OPERATIONAL, EMERGENCY AND RADIO-PROTECTION PERSONNEL, THIS OPERATION WAS EXECUTED SMOOTHLY AND RAPIDLY.

*DECONTAMINATION + *MAINTENANCE AND REPAIR + *PERSONNEL EXPOSURE, RADIATION + CONTAMINATION

17-10280 FAILURE OF OSCILLATOR DRIVE MECHANISM
ARGONNE NATIONAL LABORATORY
ANL-7190 +. 6 PAGES, 2 FIGURES, MARCH, 1966, PAGES 21-26 OF REACTOR ENGINEERING DIVISION ANNUAL REPORT,

ACCESSION NUMBER 17-10155 TO 17-10280

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-10280 *CONTINUED*

JULY 1, 1964 TO JUNE 30, 1965, CFSTI, \$6.00 CY, \$1.25 MN

TWO CONTROL RODS FAILED TO DROP AFTER A SPURIOUS SCRAM. THE STICKING OF THESE RODS WAS CAUSED BY STEEL BALLS LODGED BETWEEN THE ROD SHAFT AND THE REACTOR-VESSEL-COVER PENETRATION. THE BALLS CAME OUT OF DAMAGED LINEAR BALL BUSHINGS IN THE ROD-OSCILLATOR DRIVE MECHANISM ATTACHED TO AN ADJACENT ROD. THE ROD OSCILLATOR IS BEING REDESIGNED.

*CONTROL ROD DRIVE + *CONTROL ROD SCRAM MECHANISM + *FAILURE, SCRAM MECHANISM +
EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + OPERATING EXPERIENCE + OSCILLATOR, REACTIVITY +
REACTOR, BREEDER

17-10281 EXPERIMENTAL BREEDER REACTOR-II (EBR-II)

ARGONNE NATIONAL LABORATORY

ANL-7190 +. 29 PAGES, 13 FIGURES, 4 TABLES, MARCH, 1966, PAGES 11-39 OF REACTOR ENGINEERING DIVISION
ANNUAL REPORT, JULY 1, 1964 TO JUNE 30, 1965, CFSTI, \$6.00 CY, \$1.25 MN

BRIEF REVIEW OF EBR II OPERATING EXPERIENCE, INCLUDING STEAM-GENERATOR REPAIR, PLANT
IMPROVEMENTS, AND IRRADIATION-TEST-ASSEMBLY EXPERIENCE. TEN REGULAR FUEL ELEMENTS WERE
ACCURATELY MEASURED FOR BETTER POSTIRRADIATION MEASUREMENT OF FUEL SWELLING. FOR SOME
UNKNOWN REASON, THESE ELEMENTS ARE SWELLING FASTER THAN OTHER, SUPPOSEDLY IDENTICAL ELEMENTS.

*FUEL INTEGRITY + *OPERATING EXPERIENCE + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + REACTOR, BREEDER

17-10747 HINKLEY POINT-A WAS STRUCK BY FIRE

1 PAGE, NUCLEONICS WEEK 7(30), PAGE 7, JULY 28, 1966

FIRE AT HINKLEY POINT A-1, JULY 21, CAUSED WHEN LUBE OIL LEAK FROM A TURBINE STARTED A FIRE
THAT DAMAGED VARIOUS CONTROL CABLES, INCLUDING THOSE TO AN AUXILIARY TURBOGENERATOR THAT
POWERED THE MAIN COOLANT BLOWERS.

*FIRE + *INCIDENT, ACTUAL, EQUIPMENT + *LOSS OF FLOW + REACTOR, GAS COOLED + UNITED KINGDOM

17-10749 DOAN RL + LEVINE S

BABCOCK AND WILCOX TEST REACTOR BERYLLIUM EXAMINED ON BASIS OF EXPOSURE RATHER THAN ON CALENDAR TIME
DIVISION OF REACTOR LICENSING, USAEC

3 PAGES, DOCKET 50-200, JULY 25, 1966, PDR

BABCOCK AND WILCOX TEST REACTOR TECHNICAL SPECIFICATIONS CHANGED TO ALLOW CHECKING BERYLLIUM
REFLECTOR ELEMENTS (FOR IRRADIATION DAMAGE) EVERY 3500 MWD OF OPERATION, INSTEAD OF EVERY 2
YEARS.

*BERYLLIUM + *OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *RADIATION DAMAGE + REACTOR, TEST

17-10762 REACTOR DEVELOPMENT PROGRAM PROGRESS REPORT, APRIL, 1966

ARGONNE NATIONAL LABORATORY

ANL-7204 +. 89 PAGES, 25 FIGURES, 29 TABLES, REFERENCES, MAY 31, 1966, CFSTI, \$3.00 CY, \$0.75 MN

PG. 20 - FISSION GAS RELEASE FROM EBR II U-PU-FISSION FUELS BECOMES SUBSTANTIAL AFTER FUEL
VOLUME INCREASES OF 30 PERCENT. JACKETS CONTAINING 10 ATM OF PRESSURE REMAIN INTACT IF SIZED
FOR THIS EXPANSION. PG. 74 - USING A FREE SURFACE (INSTEAD OF A COMPLETELY CLOSED,
SOLID-WATER SYSTEM) REDUCES A PRESSURE PULSE TO 4 ATM FROM THE 17 ATM OBSERVED WITH A
CONFINED LIQUID. PG. 80 - ZIRCALOY CLAD, VIBRA-PACKED UO2 FUEL PINS IN A TREAT PULSE SHOWED
SIMILAR MELTDOWN RESULTS IN WATER, ALTHOUGH ONE SET WAS INTERNALLY PRESSURIZED TO 1500 PSIA
HELIUM AND THE OTHER SET WAS 15 PSIA. HOWEVER, THE UNPRESSURIZED PINS FAILED LATE IN THE
PULSE (BY CLAD MELTING), WHILE THE PRESSURIZED ONES FAILED BY CLAD OVERSTRESS AT A LOWER
TEMPERATURE EARLY IN THE PULSE. IN ADDITION, THE EXTENT OF METAL-WATER REACTION SEEMS TO BE
INDEPENDENT OF THE FORM OF UO2. VIBRA-PACKED UO2 DATA AGREES VERY WELL WITH PREVIOUS
SINTERED UO2 PELLET DATA.

*FAILURE, CLADDING + *FISSION GAS RELEASE + *FUEL BURNUP + *METAL WATER REACTION + *PRESSURE, EXTERNAL +
ANL (ARGONNE NATIONAL LABORATORY) + EBR I AND II (EXPERIMENTAL BREEDER REACTORS) + FUEL MELTDOWN +
PRESSURE, INTERNAL + REACTOR TRANSIENT

17-10838 A NEW WAY TO TRIM ACCIDENT COSTS

2 PAGES, FACTORY, PAGES 78-79 (JULY, 1966), MCGRAW-HILL PUBLICATION, \$1.00 CY

UNEXPECTED SUPPORT FOR THE MCA APPROACH TO REACTOR SAFETY MAY BE INFERRED FROM THIS DISCUSSION
OF CONVENTIONAL INDUSTRIAL SAFETY. A LARGE INSURANCE COMPANY RECOMMENDS REPORTING INDUSTRIAL
ACCIDENTS ON THE BASIS OF COST AND CAUSE, THEN WORKING ON THE EXPENSIVE ACCIDENTS WHERE
PAYOFF IS BIG, FAST, AND CERTAIN. CASE STUDIES SHOW THAT HUMAN ERRORS FALL INTO A FEW
MAIN-ISSUE CAUSES AND THAT WHEN LOCAL SAFETY PROGRAMS ARE CONCENTRATED ON CERTAIN POOR
WORKING HABITS, RESULTS ARE BETTER THAN GENERALIZED BE-SAFE PROGRAMS.

*ADMINISTRATIVE CONTROLS AND PRACTICES + *OPERATING EXPERIENCE + *SAFETY PRINCIPLES AND PHILOSOPHY

17-11087 WELSH EJ

FORTY-FOURTH MONTHLY OPERATING REPORT FOR JUNE 1966 FOR THE ELK RIVER REACTOR

ACCESSION NUMBER 17-10280 TO 17-11087

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11087 *CONTINUED*
RURAL COOPERATIVE POWER ASSOCIATION
C00-651-31 +. 21 PAGES, 3 FIGURES, DOCKET 115-1, JUNE, 1966, PDR

THE REACTOR WAS SHUT DOWN AS 64 NEW ELEMENTS WERE ADDED. BOWED TUBES WERE NOT FOUND IN SPIKED ELEMENTS, NOR WAS THERE A DIFFERENCE DUE TO CORE POSITION OR BURNUP. THREE BORON CARBIDE RODS REPLACED RODS MADE OF BORON-STAINLESS STEEL (B-SS) AND ARE WORTH 1.25 THE B-SS RODS IN SYMMETRIC POSITIONS. WELDS, REACTOR CLOSURE, AND HEAD-FLANGE STUDS WERE TESTED ULTRASONICALLY AND WERE IN GOOD CONDITION. FAILURE-FREE POWER SUPPLY CONVERTED FROM A GROUNDED CIRCUIT TO A FLOATING CIRCUIT.

*OPERATIONS REPORTS, GENERAL + BORON + CONTAINMENT, PRESSURE VESSEL + CONTROL ROD, SHIM SAFETY + ELECTRIC POWER, VITAL + ELK RIVER + FUEL ELEMENT + REACTOR, BOILING WATER + THERMAL MECHANICAL EFFECT

17-11092 ABNORMAL REACTOR OPERATING EXPERIENCES
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
ORNL-NSIC-17 +. 99 PAGES, 11 FIGURES, 28 REFERENCES, AUGUST 1966, CFSTI \$4.00 CY, \$0.75 MN

FIFTY INCIDENTS OF VARYING SAFETY SIGNIFICANCE OCCURRING DURING 1963-65 ARE REPORTED. BRIEF DESCRIPTIONS OF CAUSE, COURSE OF INCIDENT, AND CORRECTIVE ACTION INCLUDED.

*ACCIDENT COMPILATION + FAILURE, GENERAL + INCIDENT, ACTUAL, GENERAL + OPERATING EXPERIENCE + REACTOR, AEC OWNED

17-11101 MURPHY TL + SCHUYLER DR + CLARKE WL
FINAL DISASSEMBLY AND EXAMINATION OF THE ML-1 REACTOR CORE
PHILLIPS PETROLEUM COMPANY, IDAHO
IDO-17190 +. 150 PAGES, 60 FIGURES, 12 TABLES, JUNE 1966, CFSTI \$5.00 CY, \$1.00 MN

AREAS OF THE PRESSURE TUBES AND THE LOWER TUBE SHEET WERE IN A STATE OF INCREASING FAILURE, PROCEEDING BY GROSS PITTING AND STRESS-CORROSION CRACKING. BOTH MECHANISMS WERE WIDESPREAD IN EFFECT AND WERE PROPAGATING AT A SERIOUS RATE WHICH WOULD LEAD TO GROSS FAILURE OF THE LOWER PORTION OF THE CORE STRUCTURE. THE PENETRATION OF THE PRESSURE TUBE WALL AND THE CRACKING NEAR THE TREPAN WELD AREA PROVIDED THE PATHS TO ALLOW LEAKAGE OF THE GAS TO THE WATER MODERATOR. THE FUEL-ELEMENT OUTER LINERS WERE UNDERGOING GROSS CORROSION, PROMOTED BY INTERGRANULAR PRECIPITATION OF SECOND-PHASE MATERIAL. THE PRECIPITATING PHASE WAS BELIEVED TO BE A SIGMA TYPE RATHER THAN A CARBIDE FORMATION. THE LINER TEMPERATURE OF 1200 F FOR EXTENDED PERIODS MAY HAVE BEEN THE DRIVING MECHANISM FOR THE PRECIPITATING SECOND PHASE. CORROSION AND CRACKING OF THE NOSE GUIDES INDICATE THAT THE PROBLEMS WERE NOT LIMITED TO THE LINER. FAILURE AREAS WERE CONCENTRATED IN REGIONS WHERE THE EXIT GAS FROM THE FUEL ELEMENT HAD THE GREATEST TEMPERATURE EFFECT. THE CONCLUSION IS THAT THE MATERIALS, TYPES 304, 316, AND 321 STAINLESS STEELS, WERE UNSUITABLE FOR USE AT THE TEMPERATURES ACHIEVED IN THE REACTOR, WITH ITS MODE OF OPERATION EMPLOYING THE POSSIBLY CORROSIVE ENVIRONMENTS OF THE MODERATOR OR CANAL WATERS.

*CORE COMPONENTS, MISCELLANEOUS + *CORROSION + *FAILURE, GENERAL + *STRESS +
ML 1 (MOBILE LOW POWER PLANT NO. 1) + REACTOR, GAS COOLED + REACTOR, PRESSURE TUBE + STEEL, STAINLESS

17-11102 VAN HOWE KR + BROWN JR
PROGRESS OF ZERO POWER EXPERIMENTS IN THE PEACH BOTTOM HTGR
GENERAL ATOMIC
GA-7121 +. 27 PAGES, 15 FIGURES, APRIL 27, 1966, SOURCE

TESTS SHOW GOOD AGREEMENT WITH CALCULATIONS FOR COLD-CLEAN REACTOR. TESTS INCLUDED CONTROL-ROD WORTH, FLUX DISTRIBUTION, EXCESS REACTIVITY AND SHUTDOWN MARGIN, AND REACTIVITY WORTH OF POISONS AND FUELS. PULSED-NEUTRON TECHNIQUES WERE USED AT CRITICALITY AND SHUTDOWN. FINAL SHUTDOWN MARGIN (COLD) WAS 0.058. MAX K-EFFECTIVE WAS 1.201, COMPARED WITH PREDICTED 1.183 (PLUS OR MINUS 0.02). CONSIDERABLE EFFORT WAS NECESSARY TO CORRECTLY INTERPRET PULSED-NEUTRON DATA BECAUSE OF SPATIAL DIFFERENCES IN PROMPT- AND DELAYED-NEUTRON DISTRIBUTION.

*TEST, PHYSICS + PEACH BOTTOM + PULSED NEUTRON TECHNIQUE + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED + SHUTDOWN MARGIN

17-11108 LAWRENCE RA + PANCOAST JT
ASTR LOSS OF FLUID COOLANT TEST
SOUTHERN METHODIST UNIVERSITY + GENERAL ATOMIC DIVISION, GENERAL DYNAMICS CORP.
23 PAGES, 11 FIGURES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 298

ASTR IS A 10-MW(TH) TANK-TYPE REACTOR WITH MTR-TYPE ELEMENTS WHICH CAN BE OPERATED IN A WATER POOL OR IN AIR, WITH CORE ORIENTED IN ANY DIRECTION. THIRTEEN RUNS WERE MADE WITH COOLANT WATER BLOWN OUT AND FUEL-ELEMENT TEMPERATURE MONITORED. A DETERMINATION OF OPERATING TIME VS POWER LEVEL FOR FUEL MELTING WAS MADE, AND A TIME-TO-REACH-MELTING CURVE SHOWED 1000 SEC TO TAKE ACTION FOR MOST SITUATIONS. A HEAT-TRANSFER MODEL WAS CHECKED, AND APPROPRIATE COEFFICIENTS DERIVED.

*LOSS OF COOLANT + *TEST, PROOF + ACCIDENT ANALYSIS + REACTOR, TEST

17-11111 BIERMAN GF + MILLER WJ

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11111 *CONTINUED*

NUCLEAR REACTOR PLANT AVAILABILITY

METROPOLITAN EDISON COMPANY, READING, PENNSYLVANIA + YANKEE ATOMIC ELECTRIC COMPANY, BOSTON, MASSACHUSETTS
23 PAGES, 8 TABLES, 6 FIGURES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23,
1966, TRANSACTIONS OF AMERICAN NUCLEAR SOCIETY 9(1), PAGE 218

OPERATING EXPERIENCE OF SIX NUCLEAR POWER PLANTS, WHICH HAVE GENERATED MORE THAN 500,000 MW OF
ELECTRICITY, IS REVIEWED TO EVALUATE PLANT AVAILABILITY AND CHIEF FACTORS. THE MAJOR FACTORS
ARE REFUELING, MAINTENANCE, AND TESTING. AS PROCEDURES IMPROVE AND EXPERIENCE INCREASES,
AVAILABILITY OF NUCLEAR PLANTS WILL COMPARE WITH FOSSIL PLANTS. ELEVEN CONCLUSIONS ARE
DRAWN, FOR EXAMPLE - PROBABILITY STATISTICS CANNOT YET PREDICT FUTURE UNIT AVAILABILITY, TWO
CORE LIFETIMES ARE NECESSARY FOR FULL DEBUGGING.

*OPERATING EXPERIENCE + BIG ROCK POINT + DRESDEN I + HUMBOLDT BAY + INDIAN POINT I +
REACTOR, BOILING WATER + REACTOR, POWER + REACTOR, PRESSURIZED WATER + SHIPPINGPORT + YANKEE

17-11112 WOFFORD AW

ANTICIPATED PERFORMANCE OF THE NEW GENERATION OF WATER REACTORS

CONNECTICUT YANKEE ATOMIC POWER COMPANY, HADDAM

5 PAGES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS.,
9(1), PAGE 220

BRIEFLY CONSIDERS THE AVAILABILITY AND ECONOMICS OF NUCLEAR POWER PLANTS. CONSIDERATION OF
FUEL ECONOMY ONLY INDICATES THAT AVAILABILITY SHOULD BE GIVEN MORE CONSIDERATION THAN
INCREASED EFFICIENCY. SUGGESTS REACTOR HAS AN ADVANTAGE BECAUSE THE CRUCIAL COMPONENT (FUEL
ELEMENT) IS CONTINUALLY BEING IMPROVED AND REPLACED.

*ECONOMICS + FUEL ELEMENT + REACTOR, POWER

17-11136 LELLOUCHE GS + CHERNICK J

THE EFFECT OF XENON ON SAFETY OF THE HFBR

BROOKHAVEN NATIONAL LABORATORY, UPTON

BNL-10388 +. 9 PAGES, 5 FIGURES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE
20-23, 1966, ANS TRANS. 9(1), PAGE 300

THE IMPORTANT EFFECT IS A RAMP REACTIVITY ACCIDENT WHICH MAY BE TEMPORARILY ARRESTED BY THE
NEGATIVE TEMPERATURE COEFFICIENT BUT SPURTS UP AGAIN DUE TO INCREASED XENON BURNUP. A SECOND
EFFECT IS POWER OSCILLATION SHORTLY AFTER A SLOW POWER INCREASE IS MADE.

*XENON + ACCIDENT, REACTIVITY + HFBR (HIGH FLUX BEAM REACTOR) + REACTIVITY EFFECT + REACTOR TRANSIENT +
REACTOR, HEAVY WATER

17-11137 CUNNINGHAM JE + LONG EL

FAILURE OF BONUS REACTOR SUPERHEATER FUEL ASSEMBLY TRACED TO FAULTY WELD PRACTICE

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

4 PAGES, 1 FIGURE, 1 REFERENCE, FEBRUARY 22, 1966, ANS TRANSACTIONS 9(1) PAGE 65. SUMMARY FOR THE 12TH
ANNUAL AMERICAN NUCLEAR SOCIETY MEETING, DENVER, COLORADO, JUNE 19-23, 1966,

RESULTS OF EXAMINING SUPERHEATER ASSEMBLY INDICATED THAT THE FAILURE WAS CAUSED BY HOLES
RESULTING FROM HOT CRACKS IN THE WELD METAL DUE TO FAULTY WELDING. WATER LEAKED INTO THE
ELEMENT, SO THAT OVERHEATING INCREASED THE PRESSURE, RUPTURING THE CLADDING. RECOMMENDED (1)
ELIMINATION OF VENT HOLES, CHANGE FROM SOCKET-TYPE TO EDGE-TYPE JOINT FOR WELD CLOSURES, (2)
CONTROL OF GRAIN SIZE, (3) REVISION OF INSPECTION AND TESTING TECHNIQUES, AND (4) IMPROVEMENT
OF WELD QUALIFICATIONS AND QUALITY-CONTROL PROCEDURES.

*FAILURE, FUEL ELEMENT + BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + INCIDENT, ACTUAL, EQUIPMENT +
REACTOR, AEC OWNED + REACTOR, SUPERHEAT + WELDING

17-11138 PETERS NT + AMOROSI A

FEATURES OF SECOND GENERATION SODIUM-COOLED FAST REACTORS

ATOMIC POWER DEVELOPMENT ASSOCIATES, INC.

13 PAGES, 4 FIGURES, 2 TABLES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23,
1966, ANS TRANS. 9(1), PAGE 215

DISCUSSES FEATURES OF FERMI-I PLANT WHICH SHOULD BE RETAINED OR MODIFIED FOR THE DESIGN OF A
FERMI-II 500-MW(E) PLANT. BRIEFLY CONSIDERS DESIGN OF FUEL AND CORE, VESSEL, FUEL-HANDLING
SYSTEM, AND HEAT-TRANSPORT SYSTEM. POINTS OUT THAT THE INABILITY TO INSPECT PIPE HANGERS AND
THE POSSIBLE ADVERSE EFFECT OF THE SECONDARY CONTAINMENT OF THE PRIMARY PIPING ON THE PIPE
INTEGRITY LEADS TO CONSIDERATION OF AVOIDING THE NEED FOR SECONDARY CONTAINMENT.

FAILURE, PIPE + FERMI + OPERATING EXPERIENCE + REACTOR, BREEDER + REACTOR, FAST +
REACTOR, LIQUID METAL COOLED

17-11140 VASSELL GS + TIBBERTS N

A SYSTEM PLANNERS VIEW OF THE ECONOMIC SIGNIFICANCE OF PLANNED AND FORCED OUTAGES OF GENERATING CAPACITY

AMERICAN ELECTRIC POWER SERVICE CORPORATION

2 PAGES, 1 FIGURE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS
TRANS. 9(1), PAGE 217-218

AVAILABILITY IS IMPORTANT BECAUSE IT AFFECTS THE AMOUNT OF GENERATION RESERVE, WHICH IS OF

ACCESSION NUMBER 17-11111 TO 17-11140

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11140 *CONTINUED*
ECONOMIC SIGNIFICANCE. AVAILABILITY CAN BE INCREASED BY SCHEDULING PLANNED OUTAGES TO COINCIDE WITH LOW DEMANDS. AN INCREASE IN AVAILABILITY OF AN 800-MW UNIT IS SHOWN TO REDUCE THE BUS-BAR COST OF ENERGY 0.27 MIL/KWH.

*ECONOMICS + REACTOR, POWER + RELIABILITY ANALYSIS

17-11141 MURRAY WB
AVAILABILITY ASSURANCE FOR THE HEAVY-WATER ORGANIC-COOLED REACTOR
ATOMICS INTERNATIONAL
2 PAGES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGES 219-220

A MATHEMATICAL MODEL IS GIVEN WHICH EXPRESSES PLANT AVAILABILITY IN TERMS OF COMPONENT RELIABILITY. APPLICATION OF AN ANALYSIS DURING REACTOR DESIGN STAGE INDICATED KEY AREAS THAT AFFECT AVAILABILITY AND GUIDED THE DEVELOPMENT AND TESTING PROGRAMS.

*RELIABILITY ANALYSIS + ECONOMICS + REACTOR, HEAVY WATER + REACTOR, ORGANIC COOLED

17-11142 MCCONNELL LG
CANADIAN ON-POWER FUELING EXPERIENCE
HYDRO ELECTRIC POWER COMMISSION, TORONTO
1 PAGE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 220

CANADIAN EXPERIENCE AND ECONOMIC MOTIVATION FOR ON-POWER FUELING IS REVIEWED. AN ESTIMATE OF TOTAL ENERGY COST FOR SUCH FUELING IS 3.35 MILLS/KWH, COMPARED WITH 4.77 FOR OFF-POWER FUELING.

*ECONOMICS + CANADA + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REFUELING

17-11143 LEIBY DW + POOR CF
DATA PROCESSING APPLICATIONS TO A LARGE DUAL-PURPOSE NUCLEAR REACTOR
HANFORD ATOMIC PRODUCTS OPERATION
1 PAGE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 263

DISCUSSES APPLICATION OF DIGITAL COMPUTERS FOR HANDLING OPERATING, PRODUCTION, AND HISTORICAL DATA NEEDS AT THE 800 MW(E) NPR (HANFORD NEW PRODUCTION REACTOR).

*DATA PROCESSING + COMPUTER, DIGITAL + HANFORD SITE + REACTOR, GRAPHITE MODERATED + REACTOR, PRESSURE TUBE

17-11144 HOLLAND LK
ON-LINE COMPUTER EXPERIENCE WITH BOILING-WATER REACTORS
GENERAL ELECTRIC, SAN JOSE
1 PAGE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 264

BRIEFLY REVIEWS THE FEASIBILITY AND RELIABILITY OF DIGITAL COMPUTERS FOR CALCULATING AND INTERPRETING REACTOR VARIABLES, SUCH AS THREE-DIMENSIONAL POWER DISTRIBUTION, THERMAL POWER, HEAT-FLUX RATIO, FUEL TEMPERATURES, ETC. EMPHASIZES IMPROVED OPERATION OF THE REACTOR.

*COMPUTER, DIGITAL + BIG ROCK POINT + REACTOR, BOILING WATER

17-11145 NATH RJ + WYKE TF + LANGFORD FL + KORTHEUER JD
POWER-SHARING MEASUREMENTS ON THE CVTR
GE, ATOMIC POWER EQUIPMENT DEPT. + CAROLINAS-VIRGINIA NUCLEAR POWER ASSOCIATION
2 PAGES, 2 FIGURES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS 9(1), PAGES 277-278

A TWO-GROUP DIFFUSION THEORY TREATING PRESSURE TUBES, CONTROL ELEMENTS, AND HEAVY WATER AS DISTINCT REGIONS WAS USED TO PREDICT TUBE-POWER SHARING AS A FUNCTION OF CORE LIFE AND CONTROL-ROD POSITION. MEASUREMENTS WERE MADE USING WIRE IRRADIATION AND HEAT BALANCE AND RESULTED IN AGREEMENT TO WITHIN 5 PERCENT.

*FUEL BURNUP + *POWER DISTRIBUTION + CVTR (CAROLINAS VIRGINIA TUBE REACTOR) + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + TEST, PHYSICS

17-11146 MORGAN WR + BARTH NH
POWER-DISTRIBUTION MEASUREMENTS AT SENN
GENERAL ELECTRIC, SAN JOSE
1 PAGE, 1 FIGURE, 5 REFERENCES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1), PAGE 278

BRIEFLY DESCRIBES DETERMINATION OF POWER DISTRIBUTION BY MEASURING RELATIVE LA-140 GAMMA RADIATION OF FUEL ASSEMBLIES. THE PURPOSE WAS TO DEMONSTRATE THE CONFIDENCE OF COMPUTER-CALCULATED DISTRIBUTIONS.

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE17-11146 *CONTINUED*
*POWER DISTRIBUTION17-11147 ORR WL
A NUCLEAR DESIGN REVIEW OF THE SAXTON PARTIAL PLUTONIUM CORE
WESTINGHOUSE ELECTRIC CORP., ATOMIC POWER DIV.
1 PAGE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1),
PAGE 280OUTLINES PROGRAM FOR OBTAINING INFORMATION ON USE OF PLUTONIUM-ENRICHED FUEL IN PWR SYSTEMS.
PRIOR TO OPERATION, THE 23.5-MW SAXTON REACTOR IS PREDICTED TO HAVE A CAPABILITY OF 9300 MWd.

*FUEL BURNUP + PLUTONIUM OXIDE + REACTOR, PRESSURIZED WATER + SAXTON

17-11148 CHASTAIN RH + STERNBERG HI
PREDICTED AND OBSERVED PERFORMANCE OF THE SAXTON PARTIAL PLUTONIUM CORE DURING STARTUP TESTS
WESTINGHOUSE ELECTRIC CORP., ATOMIC POWER DIV.
2 PAGES, 1 FIGURE, 1 TABLE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23,
1966, ANS TRANS. 9(1), PAGES 280-281REACTIVITY CALCULATIONS AND EXPERIMENTAL RESULTS ARE COMPARED. RESULTS INDICATE THAT THE
NUCLEAR DESIGN PROCEDURES FOR SLIGHTLY ENRICHED URANIUM CORES YIELD GOOD ESTIMATES FOR
PLUTONIUM-FUELED CORES.

*MEASUREMENT, REACTIVITY + PLUTONIUM OXIDE + REACTOR, PRESSURIZED WATER + SAXTON

17-11149 HOLLAND LB + GILLEY LW + POSTON JW + WARD DR
OPERATIONAL PROBLEMS WITH THE HEALTH PHYSICS RESEARCH REACTOR
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE
1 PAGE, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23, 1966, ANS TRANS. 9(1),
PAGE 281INSTRUMENT NOISE RESULTED IN SHUTDOWNS. BETTER QUALITY CONTROL DURING ASSEMBLY OF IONIZATION
CHAMBERS RESULTED IN IMPROVEMENT. SCATTER IN THE BURST SIZE UP TO 40 PERCENT WAS REDUCED TO
4 PERCENT BY DAMPING THE IMPACT OF THE BURST ROD ON INSERTION AND BY INCREASING THE
ROD-INSERTION TIME.

*OPERATING EXPERIENCE + CONTROL ROD + REACTIVITY EFFECT, ANOMALOUS + REACTOR, FAST BURST + SCRAM, FALSE

17-11150 CROWLEY JH + VANN HE
ECONOMIC AND TECHNICAL FACTORS RELATING CURRENT WATER REACTOR TYPES TO ADVANCED CONCEPTS
JACKSON AND MORELAND, INC.
8 PAGES, 3 FIGURES, 4 TABLES, 1966 ANNUAL MEETING AMERICAN NUCLEAR SOCIETY, DENVER, COLORADO, JUNE 20-23,
1966, ANS TRANS. 9(1), PAGE 213DISCUSSES THE INEFFICIENCY OF PWR AND BWR REACTORS FOR UTILIZING THE URANIUM RESOURCES.
EMPHASIZES NECESSITY OF DEVELOPING BREEDER REACTORS TO MINIMIZE REQUIREMENTS FOR URANIUM
INPUT.

*ECONOMICS + REACTOR, BOILING WATER + REACTOR, BREEDER + REACTOR, PRESSURIZED WATER

17-11241 NORRIS EB
THE FIRST INSPECTION OF THE ELK RIVER REACTOR PRESSURE VESSEL AFTER OPERATION
SOUTHWEST RESEARCH INSTITUTE, SAN ANTONIO AND HOUSTON
SWRI-1228-9-8 +. 25 PAGES, 25 FIGURES, JUNE 10, 1966, DOCKET NO. 115-1, PDRAFTER ONE YEAR OF FULL-POWER OPERATION, BORESCOPING, VISUAL AND DYE PENETRANT TESTS WERE MADE
OF NOZZLES, HEAD, AND FLANGE. SURFACE CRACKS WERE FOUND BY DYE PENETRANT INCHES BELOW
SURFACE OF THE SHELL FLANGE, WHERE WELDING DILUTION HAD OCCURRED. THIS INSPECTION WAS DONE
IN A 150-MR/HR FIELD ON A LEAD-SHIELDED PLATFORM RESTING ON THE STEAM BAFFLE.*CONTAINMENT, PRESSURE VESSEL + *TEST, NONDESTRUCTIVE + ELK RIVER + MAINTENANCE AND REPAIR +
REACTOR, BOILING WATER + SHIELDING17-11242 SMALLEY WR
EVALUATION OF HIGHLY IRRADIATED YANKEE FUEL CLADDING
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA
6 PAGES, NUCLEAR APPLICATIONS, 1(5), PAGES 419-424, OCTOBER 1965TYPE-348 STAINLESS-STEEL CLADDING REMOVED FROM YANKEE CORES I AND II AFTER 6.0 X 10 TO 21
N-CM2 FAST NEUTRON EXPOSURE. VISUAL AND METALLOGRAPHIC EXAMINATION REVEALED THAT THE SURFACE
CONDITION WAS EXCELLENT, WITH NO EVIDENCE OF CORROSION, CRACKS, OR OTHER CLADDING DEFECTS.
THE MICROSTRUCTURE OF THE CLADDING WAS ESSENTIALLY UNCHANGED AS A RESULT OF REACTOR EXPOSURE.
ALTHOUGH THE CLADDING SHOWED MARKED INCREASES IN HARDNESS AND STRENGTH, THE REMAINING
DUCTILITY WAS DEMONSTRATED TO BE ADEQUATE. TYPE-348 CLADDING PERFORMED ACCEPTABLY DURING
OPERATION IN YANKEE CORES I AND II AND IS CAPABLE OF HIGHER IRRADIATION EXPOSURE.

*CLAD + *OPERATING EXPERIENCE + *STEEL, STAINLESS + REACTOR, PRESSURIZED WATER + YANKEE

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11243 JCHNSON CR
BORON STAINLESS-STEEL FUEL-FIFTH CLADDING IN THE INDIAN POINT REACTOR
BABCOCK AND WILCOX COMPANY, LYNCHBURG, VIRGINIA
7 PAGES, NUCLEAR APPLICATIONS 1(5), PAGES 432-438, OCTOBER 1965, DOCKET NO. 50-3

A PROGRAM TO CONFIRM THE USE OF BORON-STAINLESS STEEL CLADDING IN INDIAN POINT I. THE SPECIMENS WERE EXPOSED TO AN INTEGRATED THERMAL-NEUTRON FLUX OF 9.7 TIMES 10 TO THE 19 (LESS THAN 0.4 EV) AT AN IRRADIATION TEMPERATURE OF ABOUT 120 F, A BURNUP OF ABOUT 33 PPM OF B-10 IN THE 0.05 PERCENT BORON STEEL. EXPECTED BURNUP OF BORON IN THE CLADDING IS 43 PPM. TENSILE TESTS PERFORMED AT ROOM TEMPERATURE SHOW THAT BORON CONCENTRATIONS HAVE LITTLE EFFECT ON THE PROPERTIES OF IRRADIATED MATERIAL. THE EFFECT OF BORON ON YIELD STRENGTH IS MORE PRONOUNCED THAN ON ULTIMATE TENSILE STRENGTH. PRE- AND POSTIRRADIATION PHOTOMICROGRAPHS INDICATED THAT IRRADIATION CAUSED NO OBSERVABLE CHANGES IN GRAIN STRUCTURE.

*BORON + *CLAD + *DAMAGE + *STEEL, STAINLESS + INDIAN POINT I + REACTOR, PRESSURIZED WATER

17-11244 WYLIC RD
INSPECTION OF THE CONTROL ROD BLADES. ELK RIVER POWER PLANT
SOUTHWEST RESEARCH INSTITUTE, TEXAS
SWRI-1228-9-9 +. 26 PAGES, 17 FIGURES, 1 TABLE, 3 REFERENCES, JUNE 22, 1966, DOCKET NO. 115-1, PDR

BOREScope INSPECTION SHOWED THAT 11 OF 13 RODS HAD CRACKED GUSSET PLATES. THE REGULATING ROD HAD SEVERAL LONG CRACKS ACROSS THE FACE OF THE BORON-STAINLESS STEEL (B-SS) BLADES, AND ONE ROD HAD CRACKS AT RIVET HOLES IN THE B-SS JUNCTION WITH THE ZIRCALOY. B-SS IRRADIATION CAPSULES WERE REMOVED FOR TEST. ONE BROKE IN HANDLING, INDICATING AN ALMOST ZERO IMPACT STRENGTH. CONTROL RODS WERE LIFTED SO THE IN-CORE TIPS COULD BE TESTED WITH DYE.

*CONTROL ROD, SHIM SAFETY + *EMBRITTEMENT + *TEST, NONDESTRUCTIVE + BORON + DAMAGE + ELK RIVER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + STEEL, STAINLESS

17-11245 WYLIE RD
ULTRASONIC INSPECTION OF SELECTED WELDS IN STAINLESS STEEL PRIMARY STEAM PIPING IN ELK RIVER POWER PLANT
SOUTHWEST RESEARCH INSTITUTE, TEXAS
SWRI-1228-9-10 +. 9 PAGES, 8 FIGURES, JUNE 28, 1966, DOCKET NO. 115-1, PDR

STRESS-CORROSION CRACKING HAD BEEN OBSERVED IN STEEL SPECIMENS EXPOSED IN THE PRIMARY SIDE OF THE HEAT EXCHANGERS. TEN WELDS WERE SELECTED FOR ULTRASONIC TESTS, AND ALL PROVED SATISFACTORY.

*PIPING + *TEST, NONDESTRUCTIVE + *WELDS + CORROSION + ELK RIVER + REACTOR, BOILING WATER + STRESS

17-11332 SKREPPEN H
ORGANIC COOLED IRRADIATION LOOP IN THE HFR AT PETTEN
INSTITUTT FOR ATOMENERGI, KJELLER, NORWAY
KP-82 +. 22 PAGES, NOVEMBER 1965, DEP. MN

DESCRIBES AN ORGANIC-COOLED IRRADIATION LOOP USED FOR IRRADIATION STUDIES OF PRESSURE-VESSEL STEEL. THE COOLANT IS A EUTECTIC MIXTURE OF BIPHENYL, ORTHOPHENYL, AND META-TERPHENYL. THE OPERATING EXPERIENCE FOR 1965-66 IS REVIEWED. ONLY ONE SCRAM RESULTED FROM A REAL CAUSE DUE TO THE EXPERIMENT, WHEN NITROGEN WAS INJECTED FOR COOLANT MAKEUP INSTEAD OF LIQUID, AND THE PUMPS WOULD NOT PUMP THE MIXTURE. THE PLANNED PROGRAM IS GIVEN.

*CONTAINMENT, PRESSURE VESSEL + *IN PILE LOOP + *IRRADIATION TESTING + FAILURE, GENERAL + NETHERLANDS + ORGANIC COOLANT + REACTOR, TEST + STEEL

17-11334 CHEN JC
NUCLEAR POWER REACTOR TECHNOLOGY
BROOKHAVEN NATIONAL LABORATORY, UPTON, NEW YORK
BNL-10309 +. 86 PAGES, MAY 1966, CFSTI \$3.00 CY, \$0.75 MN

THE ENERGY-CONSUMPTION RATE BY THE WORLD, AND THE EXPECTED INCREASE IN DEMAND, ARE REVIEWED. IT IS PREDICTED THAT THE FOSSIL FUELS WILL BE DEPLETED IN 75 YEARS. CURRENT STATUS AND RECENT DEVELOPMENTS OF THE MAJOR TYPES OF POWER REACTORS ARE REVIEWED, AND THE CHARACTERISTICS OF EACH CLASS ARE GIVEN. IT IS STATED THAT WHEN CONVENTIONAL FUELS ARE DEPLETED, ENERGY WILL HAVE TO BE SUPPLIED BY NUCLEAR REACTORS - SPECIFICALLY, FAST BREEDERS.

*ECONOMICS + REACTOR, BREEDER + REACTOR, POWER + REVIEW

17-11338 PRESSURIZED WATER REACTOR (PWR) PROJECT.
WESTINGHOUSE ELECTRIC CORPORATION, BETTIS ATOMIC POWER LABORATORY, PITTSBURGH
WAPD-MRP-117 +. 126 PAGES, FIGURES, TABLES, JULY 22, 1966, CFSTI \$4.00 CY, \$1.00 MN

OPERATION WITH PH ABOVE 10.1 STOPPED CORE FLOW DECREASES, WHILE FLOW DECREASES RESUMED DURING PERIODS WHEN PH WAS REDUCED BELOW 10.1. OPERATING DATA SHOW THAT TRANSIENT XENON CAUSES POWER INSTRUMENTS TO VARY BY 17 PERCENT FROM A TRUE READING. ALSO, POWER PEAKING DUE TO XENON WAS CHECKED FOR VARIOUS REDUCED POWERS AT VARIOUS LIFETIMES, AND LIMITS SET ON POWER VS TIME BEFORE RETURNING TO FULL POWER. CORE 1 BARREL READ ABOUT 2000 REMS/HR (CONTACT) ON THE OUTSIDE AND ABOVE 6000 INSIDE. WITH 4 FT OF WATER SHIELDING, THE PEAK VALUE WAS 4.5 MILLIREMS/HR. PORTIONS OF A STEAM GENERATOR ARE BEING INSPECTED FOR CRACKING. ACCELERATED PICKUP OF HYDROGEN WAS NOTED ON WORN PARTS OF CONTROL ROD AND CORE COMPONENTS. ZIP

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11338 *CONTINUED*

AXIAL-DEPLETION MODEL WAS REVISED TO REDUCE THE YIELDS OF XENON AND SAMARIUM BY 30 PERCENT TO
FORCE AGREEMENT WITH PREDICTED AND OBSERVED CRITICAL POSITIONS OF THE RODS.

*OPERATIONS REPORTS, ANALYSIS + COOLANT CHEMISTRY + HEAT EXCHANGER + INSTRUMENTATION, ABNORMAL INDICATION +
REACTOR, PRESSURIZED WATER + SHIPPINGPORT + SURFACE FILM DEPOSIT + XENON

17-11339 POWER ESCALATION THROUGH FULL POWER OPERATION

ALLIS-CHALMERS, BETHESDA

ACNP-65524 REV. 1 +. 39 PAGES, 9 FIGURES, TABLES, 10 REFERENCES, FEBRUARY 1966, DOCKET NO. 115-1, CFSTI
\$2.00 CY, \$0.50 MN

DETAILED REPORTS ARE LISTED IN THE BIBLIOGRAPHY, WHILE THIS REPORT SUMMARIZES TESTS TO ENSURE
SAFE ESCALATION TO FULL POWER. UNEXPECTED FEED-WATER PULSING AT LOW POWER OCCURRED. FLOW
SEPARATORS THAT WORKED IN MODEL TESTS DID NOT WORK IN REACTOR. NITROGEN-16 IN THE EMERGENCY
CONDENSER CAUSED RADIOACTIVITY IN THE BUILDING EXHAUST TO RISE FALSELY UNTIL SHIELDED.
ALUMINUM CARRIAGE FOR THE START-UP CHANNEL WAS REPLACED BY MASONITE TO GAIN A FIVEFOLD
INCREASE IN COUNTING RATE.

*REACTOR STARTUP EXPERIENCE, INITIAL + ELK RIVER + MEASUREMENT, NOISE + REACTOR, BOILING WATER +
SOURCE, NEUTRON

17-11367 SMITH EH

ETR OPERATIONS BRANCH PROGRESS REPORT FOR CYCLE NO. 80 APRIL 7 - MAY 22, 1966

PHILLIPS PETROLEUM COMPANY, IDAHO

IDO-17197 +. 24 PAGES, FIGURES, TABLES, JULY 28, 1966, DTIE

THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS BELOW. TOPICS COVERED INCLUDE
- PLANT OPERATIONS, OPERATING SUMMARY, IRRADIATION PROGRAM, REACTOR IRRADIATION SUMMARY

*OPERATIONS REPORTS, GENERAL + ETR (ENGINEERING TEST REACTOR) + REACTOR, TEST

17-11368 FORD JD

MTR PROGRESS REPORT CYCLE NO. 244, JUNE 5 - JUNE 26, 1966

PHILLIPS PETROLEUM COMPANY, IDAHO

IDO-17200 +. 38 PAGES, FIGURES, TABLES, JULY 25, 1966, DTIE

THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON THE SUBJECTS BELOW. TOPICS COVERED INCLUDE
- PLANT OPERATIONS, OPERATING SUMMARY, IRRADIATION PROGRAM, AND REACTOR IRRADIATION SUMMARY.

*OPERATIONS REPORTS, GENERAL + MTR (MATERIAL TESTING REACTOR) + REACTOR, TEST

17-11369 FORD JD

MTR PROGRESS REPORT CYCLE NO. 244, JUNE 5 - JUNE 26, 1966

PHILLIPS PETROLEUM COMPANY, IDAHO

IDO-17200 +. 38 PAGES, FIGURES, TABLES, JULY 25, 1966, DTIE

REACTOR WAS SHUTDOWN SEVERAL TIMES TO REMOVE A BROWN FIBER, RESEMBLING HEMP ROPE, FROM THE
8-IN. BYPASS FILTER. A REFUELING WAS NECESSARY WHEN ONE FUEL-ELEMENT PRESSURE-DIFFERENTIAL
DROPPED BECAUSE OF SEVERAL SMALL PIECES OF A RUBBER-LIKE MATERIAL IN THE ELEMENT.

*INCIDENT, ACTUAL, GENERAL + FAILURE, OPERATOR ERROR + FLOW BLOCKAGE + MTR (MATERIAL TESTING REACTOR) +
REACTOR, TEST

17-11413 SKARPELOS JM

CHEMISTRY OF ESADE-VBWR NUCLEAR SUPERHEAT LOOP

GENERAL ELECTRIC COMPANY, SAN JOSE, CALIFORNIA

GEAP-4813 +. 38 PAGES, FEBRUARY 1964, CFSTI, \$2.00 CY, \$0.50 MN

THE CHEMISTRY PROGRAM ASSOCIATED WITH THE ESADE-VBWR NUCLEAR SUPER
HEAT LOOP WAS CARRIED ON WITH THE PRIMARY PURPOSE OF DETECTING THE
FAILURE OF FUEL CLADDING AND MEASURING THE FISSION-PRODUCT RELEAS
E RATE. TO ACCOMPLISH THIS OBJECTIVE, NOBLE-GAS FISSION PRODUCTS
AND RADIOIODINES WERE MONITORED IN THE LOOP INLET AND OUTLET STEAM
. RADIOCHEMISTRY MEASUREMENTS MADE DURING IRRADIATION GAVE NO IND
ICATION OF DEFECTIVE FUEL. RESULTS AFTER SIPPING THE FUEL BUNDLE
AT THE COMPLETION OF THE IRRADIATION INDICATED THAT A FUEL ELEMENT
MIGHT HAVE BEEN DEFECTIVE. HOWEVER, THE SIGNAL WAS SUFFICIENTLY
WEAK THAT IF A DEFECT WERE PRESENT IT WAS VERY SMALL. PROBLEMS AS
SOCIATED WITH STEAM SAMPLING DID NOT DETRACT FROM THE MAJOR OBJECT
IVE, WHICH WAS TO DETERMINE OPERATING LIMITS FOR SUPERHEAT FUEL EL
EMENTS OF INTEREST.

*CHEMICAL REACTION + *FAILURE, FUEL ELEMENT + *VBWR (VALLECITOS BOILING WATER REACTOR) +
REACTOR, BOILING WATER + REACTOR, SUPERHEAT

17-11425 ANNUAL REPORT, FISCAL YEAR, 1964-1965

PHILIPPINE ATOMIC ENERGY COMMISSION, MANILA

ACCESSION NUMBER 17-11338 TO 17-11425

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11425 *CONTINUED*
PAEC(A)AR-651 +. 188 PAGES, 1965, DEP.MN

DESCRIBES OPERATING EXPERIENCE GAINED IN UPRATING THE POWER FROM 100/KW TO 1 MW. DIFFICULTIES ENCOUNTERED INCLUDE THE REQUIRED MANUAL POWER CONTROL AS A RESULT OF THE LACK OF SPARE PARTS FOR THE SERVO AMPLIFIER, THE INSTRUMENT ABNORMALITIES, THE FLOATING OF CAPSULES AFTER IRRADIATION, AND THE INADEQUACY OF POLYETHYLENE CAPSULES AS SAMPLE HOLDERS. PARAFFIN THAT HAD BEEN USED AS SEALANT FOR IRRADIATION CAPSULES AT 100 KW MELTED AT THE 1-MW LEVEL SETTLED BELOW THE CORE AND SOLIDIFIED. PIECES OF THE PARAFFIN WERE LATER FOUND ON TOP OF THE ELEMENTS AND IN THE HEAT EXCHANGER. A MAJOR CLEANUP OF THE PRIMARY SYSTEM WAS REQUIRED.

*OPERATING EXPERIENCE + FAILURE, INSTRUMENT + INCIDENT, ACTUAL, GENERAL +
INSTRUMENTATION, ABNORMAL INDICATION + PHILIPPINES + REACTOR, RESEARCH

17-11431 ORSONI L + CUSTODERO S + WALTHER H
MODIFICATIONS OF SORINS POOL TYPE REACTOR AVOGADRO RSI FOR HIGHER POWER OPERATION
SORIN, CENTRO RICERCA NUCLEARE, ITALY
12 PAGES, 10 FIGURES, 5 TABLES, ENERGIA NUCLEARE 12(9), PAGES 459-470, (SEPTEMBER 1965)

THE INCREASE FROM 2 MW TO 10 WAS CHOSEN ON A COST BASIS, AS THE GRAVITY-FLOW-THROUGH REACTOR (ABOUT 5500 GPM) WOULD ALLOW 15 MW. ELEMENTS WERE CHANGED FROM 12-PLATE 20-PERCENT-ENRICHMENT TO 19-PLATE 90-PERCENT-ENRICHMENT. CONTROL ROD MAGNET WAS MOVED 1 FT AWAY FROM THE CORE (REDUCING RADIATION DAMAGE), THE PIVOTING SHOCK ABSORBER WAS FIXED (REDUCING VIBRATION), AND A PIVOTING JUNCTION AND GUIDE WERE PLACED 5 FT ABOVE THE CORE. TEMPERATURE AND VOID COEFFICIENT WERE REDUCED. THERMAL-COLUMN SHIELDING WAS INCREASED, AND A LIGHT SHIELD WAS ADDED TO PROTECT POOL WALLS. HEATED WATER IS LAYERED ON TOP OF POOL WATER TO AVOID BRINGING CONTAMINATED WATER TO THE SURFACE OF THE POOL.

*MODIFICATION, SYSTEM OR EQUIPMENT + *POWER UPRATING + ITALY + REACTOR, POOL TYPE

17-11442 KOSMATA HR
APPLICATIONS OF NPR TECHNOLOGY TO THE NATIONAL NUCLEAR PROGRAM
HANFORD ATOMIC PRODUCTS OPERATION
17 PAGES, 1 TABLE, 5 REFERENCES, PRESENTED AT THE ANS ELEVENTH ANNUAL MEETING, GATLINBURG, TENNESSEE, JUNE 21-24, 1965, SOURCE

BRIEFLY DESCRIBES THE 4000-MW(T) DUAL-PURPOSE REACTOR. THE ITEMS DISCUSSED OF VALUE TO THE NATIONAL PROGRAM INCLUDE (1) THE ACCELERATION OF THE ZIRCALOY PROCESS-TUBE TECHNOLOGY, (2) THE USE OF CARBON STEEL INSTEAD OF STAINLESS AS BASIC STRUCTURAL MATERIAL FOR THE PRIMARY LOOP, (3) THE USE OF METALLIC URANIUM AS A FUEL INEXPENSIVE TO FABRICATE AND CLAD, (4) THE OPTIMUM EQUIPMENT SIZE AND NUMBER OF PARALLEL SYSTEMS FOR LARGE REACTORS, AND (5) THE ADVANTAGES OF A TUBE REACTOR, WHICH PERMITS MODULAR DESIGN AND ALLOWS THE USE OF STOCK ITEMS.

*ECONOMICS + NPR (HANFORD NEW PRODUCTION REACTOR) + REACTOR, GRAPHITE MODERATED + STEEL + URANIUM + ZIRCALOY

17-11443 THE ATOM - FRIEND OR FOE (PARTS I - IV)
10 PAGES, UNITED MINE WORKERS JOURNAL, SEPTEMBER 15, 1965

SERIES OF ARTICLES STRINGING TOGETHER QUOTATIONS FROM 1957 BROOKHAVEN REPORT, TESTIMONY BEFORE JCAE, AND VARIOUS MAGAZINE ARTICLES TO SHOW THAT NUCLEAR REACTORS CAN LEAVE ACCIDENTS ENDANGERING 750,000 SQUARE MILES OR MORE. NOT BLATANTLY PREJUDICED OR SCARE TYPE OF ARTICLE, BUT DEFINITELY A ONE-SIDED VIEW.

*RADIATION, PUBLIC EDUCATION/ACCEPTANCE + INCIDENT, ACTUAL, GENERAL + RADIATION IN PERSPECTIVE + WASTE DISPOSAL, GENERAL

17-11582 TRAINING IAEA FELLOWS. SOLVING HUMAN AND TECHNICAL PROBLEMS
3 PAGES, INTERNATIONAL ATOMIC ENERGY AGENCY BULLETIN 8(2), PAGES 18-20, JUNE 1966

TRAINING IAEA FELLOWS. BRIEF ARTICLE DISCUSSES PROBLEMS OF ADAPTATION TO A NEW CULTURE, FOOD, CLIMATE, ETC. THE MAIN POINT IS THAT THE IAEA FELLOW NEEDS TRAINING, NOT EDUCATION. YET, TO THE FOREIGN UNIVERSITY, THE FELLOW IS NO DIFFERENT FROM ANY OTHER STUDENT, AND WHEN THE FELLOW FAILS TO PERFORM AS THE UNIVERSITY SEES FIT, HE IS DROPPED, AND THE TRAINING MISSION CANNOT BE FULFILLED. MAKING THE UNIVERSITY UNDERSTAND THAT THE TRAINING IS THE PRIMARY OBJECT (AND THAT DEGREE IS SECONDARY) SEEMS TO BE DIFFICULT IN MOST CASES.

*STAFFING, TRAINING, QUALIFICATION + IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY) + REACTOR, GENERAL

17-11599 EXPLOSION IN DRUM CONTAINING URANIUM EXTRACTION EXPERIMENT WASTES
DIVISION OF OPERATIONAL SAFETY U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
SERIOUS ACCIDENTS ISSUE NO. 257, 2 PAGES, DECEMBER 10, 1965, DPI

PRESENTS INFORMATION OBTAINED FROM AN ENGLISH TRANSLATION OF A COMMITTEE REPORT ON AN EXPLOSION THAT OCCURRED IN 1963 AT TOKAI RESEARCH INSTITUTE OF JAPAN. THE EXPLOSION WAS CAUSED BY THE MIXING OF 160 LITERS OF 30 PERCENT TBP/KEROSENE (CONTAINING 17 TO 20 PERCENT AROMATIC HYDROCARBON) WITH NITRIC ACID OF 77 PERCENT STRENGTH.

*CHEMICAL REACTION + *EXPLOSION + INCIDENT, ACTUAL, NONREACTOR + RADIOCHEMICAL PROCESSING

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11600 CRYOGENIC PURIFIER EXPLOSION
DIVISION OF OPERATIONAL SAFETY, U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
SERIOUS ACCIDENTS ISSUE NO. 255, 1 PAGE, NOVEMBER 12, 1965, DPI

AN EXPLOSION OCCURRED DURING THE STARTUP OF A CRYOGENIC PURIFIER-DRIER USED TO REMOVE TRACE AMOUNTS OF OIL, WATER, AND NITROGEN FROM HYDROGEN BEFORE ITS USE WITH A BUBBLE-CHAMBER. BEFORE STARTUP, MAINTENANCE HAD BEEN PERFORMED ON THE DRIER; ADMITTING AIR TO THE PURIFIER. A VALVE WAS THEN CLOSED, TRAPPING THE AIR WHICH WAS CONDENSED BY A LIQUID NITROGEN BATH. NO PURGE OCCURRED DURING STARTUP UNTIL THE VALVE WAS OPENED AND HYDROGEN ADMITTED TO THE SYSTEM. IT WAS THOUGHT THAT THE HYDROGEN FLOWING OVER THE CONDENSED AIR DETONATED.

*EXPLOSION + *HYDROGEN + INCIDENT, ACTUAL, HUMAN ERROR + INCIDENT, ACTUAL, NONNUCLEAR

17-11601 FIRE INVOLVING LIQUID HYDROGEN STORAGE TANK
DIVISION OF OPERATIONAL SAFETY, U.S. ATOMIC ENERGY COMMISSION, WASHINGTON, D.C.
SERIOUS ACCIDENT ISSUE NO. 272, 1 PAGE, AUGUST 26, 1966, DPI

DESCRIBES AN INCIDENT IN WHICH FIRE WAS DETECTED, DURING AN ELECTRICAL STORM, AT THE TERMINUS OF A 2-IN.-DIAM, 16-FT BOILOFF STACK FOR A 1500-GAL LIQUID-HYDROGEN STORAGE TANK. THE FLAME WAS EXTINGUISHED BY SPRAYING WATER ON THE STACK UNTIL IT FELT COOL AND THEN CLOSING A VALVE ON THE BOILOFF LINE TO CUT OFF THE GAS SUPPLY FEEDING THE FLAME. AFTER A 5-MIN WAIT, THE BOILOFF VALVE WAS REOPENED. NO REIGNITION OCCURRED. PROTECTION AGAINST FUTURE FIRES IS TO BE PROVIDED BY A NITROGEN-PRESSURIZED WATER TANK CONNECTED TO A SPRAY SYSTEM.

*FIRE + HYDROGEN + INCIDENT, ACTUAL, NONNUCLEAR

17-11602 BROMKAMP KH + CLEVE U + HANTKE HJ + SCHWEIGER F
REACTOR START-UP AND TESTS
1 PAGE, ATOMWIRTSCHAFT 11(5), PAGE 267, MARCH 1966, IN GERMAN

STRESSES THE NEED FOR CAREFULLY PREPARED PROCEDURES AND CONDITIONS FOR STARTUP AND TESTING OF REACTORS. AFTER THE INITIAL TESTS, THE INTERACTION OF THE SYSTEMS SHOULD BE STUDIED BEFORE THE PRODUCTION OF SIGNIFICANT RADIOACTIVITY. EMPHASIZES THE NEED FOR COORDINATION BETWEEN THE CONTRACTING, DESIGNING, AND CONSTRUCTION WORKERS.

*REACTOR STARTUP TESTING + GERMANY + REACTOR, GAS COOLED + TEST, PLANT RESPONSE + TEST, PREOPERATIONAL

17-11605 THOMPSON DH
VAPOR TRAPS PROTECT LIQUID-METAL SYSTEMS
COMBUSTION ENGINEERING INC.
12 PAGES, 11 FIGURES, 1 TABLE, 19 REFERENCES, POWER REACTOR TECHNOLOGY 8(4), PAGES 259-270, (FALL 1965)

DISCUSSED THE PRINCIPLES OF TRAPS FOR VAPORIZED METAL USED IN LIQUID-METAL SYSTEMS. DESCRIBED THE INERT-GAS BLANKET SYSTEMS AND VAPOR TRAPS USED AT SEVERAL REACTORS. DEVELOPMENT WORK ON A CONTINUOUS-HELICAL-FIN TYPE OF VAPOR TRAP APPEARED PROMISING BUT TERMINATION OF THE PROJECT PREVENTED COMPLETION OF THE EVALUATION TESTS. AN EFFICIENCY OF 99.8 PERCENT WAS ACHIEVED WITH A SODIUM-VAPOR TRAP RECENTLY DEVELOPED BY ARGONNE NATIONAL LABORATORY. RECOMMENDATIONS FOR DESIGN INCLUDE LOCATING THE TRAP NEAR THE VAPOR SOURCE OR ENSURING ADEQUATE HEAT CAPACITY FOR THE GAS PIPING, AND USING GRADUATED-DENSITY OR ZONE-DENSITY PACKINGS. A COMPREHENSIVE DEVELOPMENT PROGRAM WAS RECOMMENDED.

*CONDENSATION + *COOLANT PURIFICATION SYSTEM + *METAL, LIQUID + *VAPOR, VAPOR PRESSURE + NAK (SODIUM POTASSIUM ALLOY) + REACTOR, LIQUID METAL COOLED

17-11606 WE DONT WANT AUTOMATIC SPRINKLERS BECAUSE...
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D.C.
HEALTH AND SAFETY INFO. ISSUE NO. 242, 4 PAGES, 1 REFERENCE, AUGUST 29, 1966, DPI

OBJECTIONS TO INSTALLING AN AUTOMATIC SPRINKLER SYSTEM TO SAVE LIVES DURING A FIRE ARE DUE TO MISCONCEPTIONS. A MEMBER OF THE NATIONAL FIRE PROTECTION ASSOCIATION STAFF DISCUSSES THE COMMON OBJECTIONS WHICH ARE (1) EXCESSIVE WATER DAMAGE, (2) SMOKE GENERATED WILL SUFFOCATE, (3) THE WATER WILL DROWN PEOPLE, (4) THE STEAM GENERATED WILL SCALD THEM.

*FIRE + ACCIDENT, MONITOR + ACCIDENT, NONNUCLEAR

17-11607 SLAVE ALMOST A BRUTAL MASTER
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D.C.
HEALTH AND SAFETY INFO. ISSUE NO. 231, 3 PAGES, 2 FIGURES, APRIL 1, 1966, DPI

INCIDENT - A TECHNICIAN HAD ENTERED A SHIELDED ALPHA PLUTONIUM BOX TO OIL A LATHE AND CLEAN WINDOWS. HIS FEET WERE EXTENDING OUTSIDE THE CELL OPENING. THE CONTROLS TO CLOSE THE DOOR WERE ACCIDENTALLY ACTUATED, EXPOSING BOTH ANKLES TO THE SHEARING ACTION OF THE DOOR. FAST ACTION BY THE MONITOR AND SUPERVISOR PREVENTED SERIOUS INJURY. CORRECTIVE STEPS TO PREVENT A RECURRENCE ARE LISTED.

*INCIDENT, ACTUAL, EQUIPMENT + *INCIDENT, ACTUAL, NONREACTOR + HOT CELL

17-11608 LOSS OF A CESIUM-137 SOURCE

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11608 *CONTINUED*

DIVISION OF OPERATIONAL SAFETY, USAFC, WASHINGTON, D. C.
HEALTH AND SAFETY INFO. ISSUE NO. 232, 3 PAGES, 2 FIGURES, APRIL 5, 1966, DPI

THIS INCIDENT HIGHLIGHTS THE NEED FOR A GOOD ACCOUNTABILITY PROGRAM FOR RADIATION SOURCES. A 500-MC CESIUM-137 SOURCE USED IN WELL-LOGGING SURVEYS WAS LOST FROM A TRUCK WHILE IN TRANSIT BUT RECOVERED TWO MONTHS LATER. INVESTIGATORS CONCLUDED THAT NO SIGNIFICANT EXPOSURES HAD OCCURRED. THE LOSS OF THE SOURCE COULD BE ATTRIBUTED TO (1) THE LACK OF A SYSTEM FOR INVENTORY AND CONTROL, (2) THE SOURCE WAS NOT LOCKED IN ITS STORAGE PIG, (3) FAILURE TO SECURE THE SOURCE AND PIG TO THE TRUCK FOR TRANSPORT, AND (4) NO LABEL ON THE SOURCE, PLUS THE OBSCURED LABEL ON THE STORAGE PIG.

*INCIDENT, ACTUAL, HUMAN ERROR + *SOURCE, RADIATION, LOST + TRANSPORTATION AND HANDLING

17-11609 SHRAPNEL AT THE BURN PIT

DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 271, 1 PAGE, AUGUST 8, 1966, DPI

BRIEFLY DISCUSSES WASTE (DELIVERED TO BURN PITS) WHICH EXPLODES OR SHATTERS AND SENDS FRAGMENTS IN ALL DIRECTIONS. THIS WASTE CONSISTS OF BOTTLES, CANS, TANKS, BATTERIES, AND OTHER HARD RUBBISH. RECOMMENDS SEPARATION FROM ORDINARY COMBUSTIBLE MATERIAL AND PROVISION OF CONTAINERS FOR HAZARDOUS WASTE TO KEEP HARD TRASH OUT OF THE BURNABLE WASTE.

*INCINERATION + *WASTE DISPOSAL, GENERAL + EXPLOSION

17-11610 METALLIC URANIUM INCIDENT

DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 250, 2 PAGES, MAY 28, 1965, DPI

A TECHNICIAN RECEIVED THERMAL BURNS WHEN AN EXPLOSION OCCURRED DURING A URANIUM-PICKLING PROCESS. RECOMMENDATIONS FOR PROTECTION INCLUDE (1) INSTALLATION OF SAFETY SHOWER, (2) MINIMIZE HANDLING BY RELOCATING WATER LINES, (3) RESTRICTING MINIMUM SIZE OF CHIPS AND TURNINGS TO BE TREATED, (4) WEARING OF PROTECTIVE GLOVES, APRON, AND MASK, AND (5) THE USE OF AN EXPLOSION INHIBITOR IN THE SOLUTIONS.

*EXPLOSION + *URANIUM + INCIDENT, ACTUAL, GENERAL + INCIDENT, ACTUAL, NONREACTOR + METAL

17-11611 REPEAT PERFORMANCE OF PLASTIC FAN FAILURE

DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 240, 2 PAGES, DECEMBER 30, 1964, DPI

TWO INCIDENTS ARE DESCRIBED. ONE OCCURRED IN 1962 IN WHICH A PLASTIC IMPELLER ON ONE OF FOUR EXHAUST FANS FAILED, THROWING PIECES OUTWARD THROUGH THE PLASTIC FAN HOUSING WITH SUFFICIENT FORCE TO PENETRATE THE HOUSING OF AN ADJACENT FAN. THE IMPELLER OF THE SECOND FAN DISINTEGRATED, AND FRAGMENTS WERE EJECTED TO DAMAGE A THIRD FAN. THE INCIDENT WAS ATTRIBUTED TO AN UNDETECTED CRACK IN THE IMPELLER BLADE OF THE FIRST FAN. A SIMILAR INCIDENT OCCURRED IN 1964, ALSO RESULTING IN DAMAGE TO THREE FANS. CORRECTIVE ACTION INCLUDED MORE FREQUENT INSPECTIONS, PROTECTIVE MATS BETWEEN UNITS, AND INSTALLATION OF IMPELLERS MADE OF MATERIALS OTHER THAN PLASTIC.

*FAILURE, EQUIPMENT + FAILURE, SEQUENTIAL + INCIDENT, ACTUAL, EQUIPMENT + VENTILATION SYSTEM

17-11612 ACCIDENTAL X-RAY EXPOSURE

DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 251, 4 PAGES, 2 FIGURES, AUGUST 20, 1965, DPI

DESCRIBES OVEREXPOSURES TO X-RAYS. A SHORT DEVELOPED, PERMITTING CONTINUOUS BEAM PRODUCTION BY THE BYPASSING OF ALL INTERLOCKS AND CONTROLS. TWO OPERATORS RECEIVED CLASS-B SKIN EXPOSURES. NOTHING WAS FOUND EXCEPT FOR REDNESS ON THE END OF ONE MAN'S THUMB.

*INCIDENT, ACTUAL, EQUIPMENT + *X-RAY + CONTROL SYSTEM + FAILURE, EQUIPMENT + INCIDENT, ACTUAL, NONNUCLEAR + RADIOGRAPHY

17-11613 TWO MORE HAND EXPOSURES FROM X-RAY MACHINES

DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 259, 6 PAGES, 5 FIGURES, DECEMBER 30, 1965, DPI

TWO INCIDENTS RESULTING IN HAND EXPOSURES (X-RAY-MACHINE OPERATORS) ARE DESCRIBED. IN ONE, THE SAFETY SYSTEM HAD BEEN INCAPACITATED TO ALLOW THE ACCEPTANCE OF SAMPLES NOT COMPATIBLE WITH THE SIZE OF THE MACHINE. THE EXPOSURE WAS 1000 REMS, RESULTING IN SWELLING AND REDDENING OF THE FINGERS A WEEK LATER, AND BLISTERING OF THE AFFECTED AREAS AFTER THREE WEEKS. THE SECOND INCIDENT OCCURRED WHEN A CHEMIST REMOVED MOISTURE FROM A SAMPLE CHAMBER WITH THE TUBE ON AND THE SHUTTER STUCK OPEN. THIS EXPOSURE WAS 80,000 REMS TO THREE FINGERS, AFFECTING PRIMARILY THE SUPERFICIAL TISSUES.

*INCIDENT, ACTUAL, EQUIPMENT + *X-RAY + FAILURE, ADMINISTRATIVE CONTROL + FAILURE, EQUIPMENT + FAILURE, OPERATOR ERROR + INCIDENT, ACTUAL, NONNUCLEAR

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11614 EXPLOSION DURING ATTEMPTS TO FILL AN EMPTY TANK CAR
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 256, 2 PAGES, 1 FIGURE, NOVEMBER 26, 1965, DPI

DESCRIBES AN INCIDENT IN WHICH NITRIC ACID WAS ADDED TO ALCOHOL, CONVERTING IT TO ACETALDEHYDE. VAPOR WAS EVOLVED, AND THE REACTION INCREASED TO THE IGNITION TEMPERATURE OF THE ACETALDEHYDE-AIR MIXTURE, RESULTING IN AN EXPLOSION.

*CHEMICAL REACTION + *EXPLOSION + INCIDENT, ACTUAL, NONNUCLEAR + TRANSPORTATION AND HANDLING

17-11615 CUTTING WHEEL RESIDUES IN PLUTONIUM WASTE CAUSE EXPLOSION
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 258, 2 PAGES, DECEMBER 17, 1965, DPI

DESCRIBES AN INCIDENT IN WHICH AN EXPLOSION OCCURRED DURING THE OXIDATION OF WASTES FROM DRY CUTTING AND GRINDING OF METALLIC PLUTONIUM IN AN EVACUATED BELL JAR WITHIN A NITROGEN-FILLED GLOVEBOX. TESTS AFTER THE INCIDENT ESTABLISHED THAT EXPLOSIONS OCCURRED EACH TIME SUFFICIENT CUTTING-WHEEL DUST WAS PRESENT IN THE WASTE, THAT NO EXPLOSIONS OCCURRED WHEN THE DUST WAS ABSENT, THAT THE PRESENCE OF PYROPHORIC METAL REDUCED THE AMOUNT OF DUST REQUIRED FOR AN EXPLOSION, AND THAT FLAMMABLE GASES WERE EMITTED BY HEATING SYNTHETIC RUBBER BINDERS USED IN THE SILICON CARBIDE CUTTING WHEELS. NOW SUCH OXIDATIONS ARE DONE IN AN AIR-FILLED GLOVEBOX WITH EXHAUST FAST ENOUGH TO REMOVE EXPLOSIVE VAPOR.

*EXPLOSION + *WASTE HANDLING + GLOVE BOX + OXIDATION + PLUTONIUM

17-11616 COOLING TOWERS DO BURN
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 260, 2 PAGES, 2 FIGURES, JANUARY 18, 1966, DPI

A FIRE WAS STARTED IN ONE CELL OF A NEW COOLING TOWER BY A CUTTING TORCH WHILE INSTALLING A SPRINKLER SYSTEM. THE TOWER, STILL UNDER CONSTRUCTION, HAD THREE CELLS SEPARATED BY ASBESTOS-CEMENT PARTITIONS (15-MIN FIRE-RESISTANCE RATING). DUE TO THE ABSENCE OF ADEQUATE MANUAL FIREFIGHTING DEVICES AND TO DELAY IN SUMMONING HELP, THE BLAZE SPREAD TO A SECOND CELL BEFORE IT WAS BROUGHT UNDER CONTROL. RECOMMENDATIONS INCLUDED (1) CLOSER SUPERVISION OF WELDING AND CUTTING, (2) INSTALLATION OF AUTOMATIC FIRE PROTECTION AS EARLY IN CONSTRUCTION AS POSSIBLE, AND (3) THAT COOLING TOWER CELL-DIVISION WALLS SHOULD HAVE A 1-HR FIRE-RESISTANCE RATING.

*FIRE + COOLANT SYSTEM + HEAT SINK + INCIDENT, ACTUAL, HUMAN ERROR

17-11617 HAZARDOUS SOLVENT USE CAUSES EXPLOSION IN A GLOVEBOX
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 261, 2 PAGES, 2 FIGURES, FEBRUARY 25, 1966, DPI

DESCRIBES AN INCIDENT IN WHICH AN EXPLOSION OCCURRED IN A PLUTONIUM-FUELS-LABORATORY GLOVEBOX. A WAXLIKE SUBSTANCE WAS BEING CLEANED FROM ELECTRICAL WIRES. ACETONE WAS FOUND TO BE EFFECTIVE, AND TWO PARTLY FILLED QUART CANS OF ACETONE WERE PLACED IN THE GLOVEBOX. LOW AIRFLOW PERMITTED ACETONE VAPORS TO ACCUMULATE. THE PROBABLE IGNITION SOURCE WAS THOUGHT TO BE A STATIC DISCHARGE FROM THE GLOVES OR CLEANING RAGS. THE INCIDENT COULD HAVE BEEN PREVENTED BY USE OF A NONFLAMMABLE OR HIGH-FLASHPOINT SOLVENT OR BY DOING THE WORK IN AN INERT ATMOSPHERE.

*EXPLOSION + GLOVE BOX + INCIDENT, ACTUAL, NONREACTOR + PLUTONIUM

17-11618 NITRATED ANION EXCHANGE BED REACTS VIOLENTLY WITH NITRIC ACID
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
SERIOUS ACCIDENTS ISSUE NO. 266, 4 PAGES, 1 FIGURE, JUNE 3, 1966, DPI

DESCRIBES AN INCIDENT IN WHICH AN EXPLOSION OCCURS DURING THE TREATMENT OF AN ANION RESIN EXCHANGE BED WITH A SOLUTION OF NITRIC ACID. IT WAS CONCLUDED THAT THE EXPLOSION WAS CAUSED BY A CHEMICAL REACTION BETWEEN THE NITRIC ACID AND THE RESIN, APPARENTLY BECAUSE TOO STRONG AN ACID WAS USED.

*CHEMICAL REACTION + *EXPLOSION + FAILURE, OPERATOR ERROR + INCIDENT, ACTUAL, NONREACTOR + RESIN

17-11619 MASK EQUIPMENT FOR FIREFIGHTING
DIVISION OF OPERATIONAL SAFETY, USAEC, WASHINGTON, D. C.
HEALTH AND SAFETY INFO. ISSUE NO. 237, 1 PAGE, JUNE 13, 1966, DPI

A DEATH FROM SMOKE INHALATION POINTS OUT THAT FILTER-TYPE MASK USED FOR PROTECTION FROM RADIATION HAZARDS PROVIDE NO PROTECTION AGAINST CARBON MONOXIDE GAS THAT MAY BE GENERATED DURING A FIRE. WHERE MASKS ARE REQUIRED IN A FIRE, ONLY SELF-CONTAINED BREATHING APPARATUS SHOULD BE USED.

*FIRE + CARBON MONOXIDE + FILTER EFFICIENCY

17-11621 BEAN WC
IN-PLANT TEACHING OF NUCLEAR REACTOR PLANT KINETICS AND CONTROL TO GRADUATE ENGINEERS AND SCIENTISTS

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11621 *CONTINUED*

BETTIS ATOMIC POWER LABORATORY

WAPD-T-1832 + CONF-650917-3 +. 33 PAGES, JULY 1965, FROM INTERNATIONAL CONFERENCE ON INDUSTRIAL ELECTRONICS AND CONTROL INSTRUMENTATION, PHILADELPHIA, CFSTI \$2.00 CY, \$0.50 MN

APPROACHES TO TEACHING CONTROL ENGINEERING ARE - (1) THE SEPARATE TEACHING IN THE VARIOUS BRANCHES, SUCH AS MECHANICAL, ELECTRICAL, ETC., WHICH RESULTS IN DESCRIPTIVE LECTURES BECAUSE THE STUDENTS ARE UNPREPARED - AND (2) PRESENTATION OF A GENERAL COURSE TO COVER ALL RELATED DISCIPLINES, WHICH RESULTS IN LIMITED EFFORTS DEVOTED TO SPECIAL-APPLICATIONS PROBLEMS. THE SECOND APPROACH WAS ADOPTED. THE SOLUTION FOR SATISFYING THE NEEDS OF A MIXED CLASS WAS - (1) THE SELECTION OF FUNDAMENTAL TOPICS, (2) USE OF SIMPLE WIDE-RANGE EXAMPLES, AND (3) EMPHASIS ON THE INTERACTION OF PLANT SYSTEMS.

*STAFFING, TRAINING, QUALIFICATION + CONTROL, GENERAL + REACTOR KINETICS + REACTOR, PRESSURIZED WATER + SHIPPINGPORT

17-11625 OBOYLE MJ

YANKEE CORE EVALUATION PROGRAM. QUARTERLY PROGRESS REPORT ENDING MARCH 1966

WESTINGHOUSE ELECTRIC CORP., PITTSBURGH, ATOMIC POWER DIV.

WCAP-6080 +. 108 PAGES, 27 FIGURES, 25 TABLES, JUNE 1966, DOCKET NO. 50-29, CFSTI \$4.00 CY, \$0.75 MN

THIS REPORT IS ONE OF A SERIES OF SUCH REPORTS ON CORE EXAMINATION, EVALUATION OF CORE PERFORMANCE (PHYSICS AND HEAT TRANSFER), AND REVISION OF NUCLEAR DESIGN METHODS.

*COMPARISON, THEORY AND EXPERIENCE + *EXAMINATION + *FUEL ELEMENT + *IRRADIATION TESTING + CONTROL ROD, SHIM SAFETY + CORE COMPONENTS, MISCELLANEOUS + HEAT TRANSFER + POWER DISTRIBUTION + REACTIVITY FFFFT + REACTOR, PRESSURIZED WATER + YANKEE

17-11640 PLISSON J

CAN RUPTURE DETECTION IN G3 - OPERATIONAL EXPERIENCE

CENTRE DE PRODUCTION DE PLUTONIUM DE MARCOULE, FRANCE

CEA-R-2710 +. 24 PAGES, 12 FIGURES, 5 REFERENCES, DECEMBER 1964, DEP. MN, IN FRENCH

A SUMMARY OF THE PRINCIPLES OF CAN-RUPTURE DETECTION IS GIVEN, PLUS A DESCRIPTION OF THE CONCLUSION REACHED AFTER 4 YEARS OF OPERATION ON THE G3 REACTOR. A DAUGHTER-ION COLLECTOR IS DESCRIBED, AND DETAILS OF THE INSTRUMENT PRESENTED.

*INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + INSTRUMENTATION, NUCLEAR + MEASUREMENT, REACTIVITY

17-11667 REED G + TARNUZZER E

EXAMINING YANKEE PLANT PERFORMANCE IN 1965

YANKEE ATOMIC ELECTRIC COMPANY, BOSTON, MASSACHUSETTS

6 PAGES, NUCLEONICS 24(3), PAGES 42-47, MARCH, 1966, DOCKET NO. 50-29

CORE IV WAS REMOVED AUGUST 9-NOVEMBER 10. EARLY STARTUP HELPED ON THE POWER-BLACK-OUT RECOVERY. AMMONIUM HYDROXIDE INJECTION GAVE A 0.7 PERCENT DELTA K/K GAIN, ENOUGH FOR A MONTH AT FULL POWER. VARIOUS CORE COMPONENTS AND IRRADIATION SPECIMENS WERE FOUND LOOSE IN THE VESSEL BOTTOM HEAD WHEN THE CORE BARREL WAS REMOVED FOR VIBRATION INSPECTION. (VIBRATION DID NOT EXIST BECAUSE BARREL WAS TILTED AGAINST THE MECHANICAL STOP). LOOSE COMPONENTS HAD WORN THROUGH THE CLADDING AND CAUSED EXTENSIVE CORROSION INVESTIGATION. WELD-DEPOSIT CLAD IS PREFERRED, EVEN THOUGH PRESSURIZER CRACKING STOPPED AT THE INTERPHASE. THROWAWAY CRUD FILTERS ARE USED. COMMENTS ARE MADE ON PRACTICAL DESIGN OF VESSEL INTERVALS.

*CONTAINMENT, PRESSURE VESSEL + *DAMAGE + *OPERATING EXPERIENCE + *REACTIVITY EFFECT, ANOMALOUS + CORE COMPONENTS, MISCELLANEOUS + CRUD + REACTOR, PRESSURIZED WATER + SURFACE FILM DEPOSIT + YANKEE

17-11668 MAGNOX STATIONS LEAD IN ELECTRICITY PRODUCTION

3 PAGES, 1 TABLE, 1 FIGURE, 2 REFERENCES, NUCLEONICS 24(3), PAGES 48-50, MARCH 1966,

BRIEF DISCUSSION OF EXPERIENCES DURING 1965 AS VARIOUS POWER STATIONS. HINKLEY POINT HAD AN EXPLOSION IN THE HYDROGEN-COOLING SYSTEM.

*OPERATING EXPERIENCE + EXPLOSION + HYDROGEN + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED + UNITED KINGDOM

17-11669 JOSEPH L

PERFORMANCE OF FUEL ELEMENTS IN NUCLEAR POWER PLANTS

S. M. STOLLER ASSOCIATES, NEW YORK, NEW YORK

4 PAGES, 2 TABLES, 4 REFERENCES, NUCLEONICS 24(3), PAGES 51-54, MARCH 1966

BRIEF REVIEW OF DATA ON CLADDING FAILURES. ZIRCALOY CLADDING IS PREFERRED FOR A BWR BECAUSE OF INTERGRANULAR CRACKING OF FREE-STANDING STAINLESS-STEEL. A PWR APPARENTLY CAN USE EITHER ZIRCALOY OR STAINLESS STEEL.

*CLAD + *FAILURE, FUEL ELEMENT + *OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, PRESSURIZED WATER + STEEL, STAINLESS + ZIRCALOY

17-11670 AULETA JJ

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11670 *CONTINUED*
PIQUA MAIN HEAT TRANSFER SYSTEM COMPONENT ANALYSIS PROGRAM
ATOMIC INTERNATIONAL, CANOGA PARK, CALIFORNIA
39 PAGES, JANUARY 28, 1964, DOCKET 115-2 CFSTI \$4.60 FS, \$1.46 MF

STANDARD EVALUATION METHODS, USING A FORTRAN PROGRAM, ARE PRESENTED FOR THE ROUTINE PERFORMANCE CHECKING OF THE MAIN HEAT-TRANSFER PUMPS AND THE STEAM GENERATOR. A ROUTINE SURVEILLANCE OF THE PERFORMANCE OF THE MAIN HEAT-TRANSFER SYSTEM AND ITS COMPONENTS IS A MEANS OF OBTAINING WARNING OF ANOMALIES OR MALFUNCTIONS OF THIS SYSTEM.

*HEAT TRANSFER ANALYSIS + HEAT EXCHANGER + PIQUA + PUMP + REACTOR, ORGANIC COOLED

17-11676 LOW TEMPERATURE GRAPHITE RADIATION DAMAGE REMOVAL
U. S. ATOMIC ENERGY COMMISSION
CANADIAN PAT. 727,091 +. FEBRUARY 1, 1966, PATENT (FOREIGN)

PATENT FOR ANNEALING GRAPHITE BY DECREASING THE AIR FLOW TO INCREASE THE TEMPERATURE OF THE GRAPHITE TO 250 C.

*WIGNER ENERGY RELEASE + BNL (BROOKHAVEN NATIONAL LABORATORY) + GRAPHITE + REACTOR, GRAPHITE MODERATED

17-11677 DOME RG
DISTURBANCES IN THE EGCR CORE
TENNESSEE VALLEY AUTHORITY, OAK RIDGE, TENNESSEE
TID-22749 +. 31 PAGES, JUNE 3, 1965, CFSTI \$2.00 CY, \$0.50 MN

PRESENTS THE METHOD AND RESULTS OF DETERMINING THE CAUSE OF LOW-AMPLITUDE VIBRATIONS THAT HAVE OCCURRED IN THE CORE OF THE EGCR. STRAIN GAGES WERE MOUNTED IN THE CORE, AND MEASUREMENTS SHOWED THAT VIBRATIONS HAVING A FREQUENCY OF 4 CPS AND AN AMPLITUDE OF 0.001 IN. COULD BE ATTRIBUTED TO THE STARTING AND STOPPING OF THE BUILDING CRANES. ADDITIONAL STUDIES ARE RECOMMENDED.

*VIBRATION + EGCR (EXPERIMENTAL GAS COOLED REACTOR) + IN CORE MEASUREMENT + MEASUREMENT, STRAIN GAGE + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

17-11734 PIQUA NUCLEAR POWER FACILITY MONTHLY OPERATING REPORT NO. 33
PIQUA NUCLEAR POWER FACILITY, OHIO
COO-652-23 +. 23 PAGES, 2 FIGURES, JANUARY 1966, CFSTI

ON JANUARY 12, 1966, POWER AND TEMPERATURE OSCILLATIONS OCCURRED AT 27 MW(TH) STEADY STATE, CEASING AT 21 MW AND REAPPEARING WHEN POWER WAS RAISED THE NEXT DAY. A FALSE SCRAM FROM DEGASIFIER LOW LEVEL OCCURRED BECAUSE OVERHEATING EMBRITTLED INSULATION AND THE SWITCH SPRING STIFFENED. AN AIR LEAK ON THE PRESSURE-CONTROL VALVE WAS FOUND, AND WAS THOUGHT TO HAVE CAUSED THE POWER OSCILLATION. ROD-DROP TIMES INDICATED A JAMMED ROD 9. ROD EXCHANGES SHOWED THAT THE JAMMING WAS NOT CAUSED BY THE ROD. SEVERAL ELEMENTS WERE REMOVED BY USE OF LARGE FORCES BUT COULD NOT BE FULLY INSERTED. VARIOUS CONTROL-ROD-DRIVE LEADS WERE FOUND BURNED OUT. THE WASTE-FIRED BOILER WAS FOUND TO BE CONTAMINATED (1 RAD/HR).

*OPERATIONS REPORTS, GENERAL + COOLANT CHEMISTRY + FAILURE, FUEL ELEMENT + FAILURE, SCRAM MECHANISM + FUEL HANDLING + PIQUA + REACTIVITY EFFECT, ANOMALOUS + REACTOR, ORGANIC COOLED

17-11735 BATTAN LJ
THE UNCLEAR SKY - A METEOROLOGIST LOOKS AT AIR POLLUTION
UNIVERSITY OF ARIZONA
126 PAGES, 19 FIGURES, 1966, DOUBLEDAY AND COMPANY, INC., GARDEN CITY, NEW YORK

POPULAR-BUT-EDUCATED-LEVEL REVIEW OF AIR-POLLUTION PROBLEMS OF INDUSTRIALIZED CIVILIZATION. (PESTICIDES AND RADIOISOTOPES WILL BE DISCUSSED IN ANOTHER BOOK.) DESCRIBES DONORA, LONDON, AND MEUSE INVERSION INCIDENTS IN RECENT TIMES, AS WELL AS A FEW RELEASES OF INDUSTRIAL GASES BOTH ROUTINE AND ACCIDENTAL. BRIEFLY DISCUSSES FALLOUT, ATMOSPHERIC CHEMISTRY, EFFECTS OF POLLUTION ON PLANTS AND ANIMALS, AND METEOROLOGICAL DISPERSION. ADVOCATES ELECTRIC TRAINS (PASSENGER), WITH LIMITATION ON PRIVATE VEHICLES, AS A SOLUTION BECAUSE THE CONTROL OF AUTOMOBILE EXHAUST FUMES IS ONLY A STOPGAP. PUBLIC APATHY IS A MAJOR PROBLEM. YET, MORE PEOPLE MUST BE MOVED WITH THE ACCOMPANIMENT OF LESS SMOKE, OR THE INCREASING AMOUNTS OF SMOKE WILL SURELY LEAD TO FEWER PEOPLE.

*ATMOSPHERIC POLLUTION + *INCIDENT, ACTUAL, NONNUCLEAR + *SMOKE + METEOROLOGY

17-11787 KANSAS STATE UNIVERSITY CITED FOR NONCOMPLIANCE. APRIL 6-8, 1966
KANSAS STATE UNIVERSITY
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(40) PAGE 18 (OCTOBER 4, 1966), DOCKET NO. 50-188

VARIOUS ITEMS OF NONCOMPLIANCE INCLUDED INADEQUATE MONITORING OF AR-41, INADEQUATE SURVEYING OF PERSONNEL EXPOSURE AT BEAM-TUBE EXPERIMENTS, OPERATION AT 30 PERCENT OVERPOWER, FAILURE TO RAISE NEUTRON SOURCE TO TEST THE STARTUP CHANNEL, FAILURE TO TEST SCRAM SIGNALS CONSISTENTLY.

*FAILURE, ADMINISTRATIVE CONTROL + PERSONNEL EXPOSURE, RADIATION + REACTOR POWER + REACTOR SAFETY SYSTEM + REACTOR, PULSED + TRIGA (TRAINING REACTOR, ISOTOPES, G.A.)

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11788 JOHNSON RM
NORTHWESTERN UNIVERSITY TRITIUM SOURCE LOSS
NORTHWESTERN UNIVERSITY
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(40), PAGES 18-19 (OCTOBER 4, 1966)

A 2.6-CURIE TRITIUM SOURCE TO BE USED AS AN ACCELERATOR TARGET WAS DISCOVERED MISSING IN AUGUST 1966. IN MAY 1965, THE SOURCE HAD BEEN REMOVED FROM THE SHIPPING CONTAINER, USED IN A TRIAL RUN OF THE ACCELERATOR (BEFORE COMPLETION OF THE EXPERIMENT CHAMBER), AND STORED IN AN ORANGE-JUICE CAN IN A LEAD-LINED CONTAINER BEHIND A WORKBENCH. APPARENTLY, CONSTRUCTION WORKERS HAD THROWN IT OUT.

*SOURCE, RADIATION, LOST + ACCELERATOR + FAILURE, ADMINISTRATIVE CONTROL + FAILURE, OPERATOR ERROR + TRITIUM

17-11789 RICHARDSON X RAY SERVICE CITED FOR NONCOMPLIANCE
RICHARDSON X RAY SERVICE, ALHAMBRA, CALIFORNIA
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(40), PAGES 19-20 (OCTOBER 4, 1966)

A COMPLIANCE INSPECTION ON APRIL 14-16, 1966, INDICATED POOR WORKING HABITS ASSOCIATED WITH A 28-CURIE IR-192 SOURCE AT BOUNDARY DAM, WASHINGTON. RADIATION AREAS WERE NOT POSTED, SURVEYS WERE NOT MADE TO DETERMINE THAT THE SOURCE WAS SHIELDED, EXPOSURE METERS WERE NOT WORN, ETC. VARIOUS JOB REASSIGNMENTS AND SPECIAL TRAINING FOLLOWED.

*INCIDENT, ACTUAL, HUMAN ERROR + *RADIOGRAPHY + FAILURE, ADMINISTRATIVE CONTROL

17-11790 THOMAS JW
3 DRUMS OF WASTE MISPLACED, JULY 19, 1966
UNIVERSITY OF PENNSYLVANIA
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(40), PAGE 21, (OCTOBER 4, 1966)

THREE 55-GALLON DRUMS CONTAINING CALCIUM AND IODINE WERE MISTAKENLY TAKEN TO A COMMERCIAL LANDFILL BY THE PENNSYLVANIA STATE UNIVERSITY TRASH TRUCK. THE CANS WERE BURIED UNDER AT LEAST 30 FT OF FILL AND WILL BE LEFT.

*FAILURE, ADMINISTRATIVE CONTROL + *WASTE DISPOSAL, SOLID + WASTE DISPOSAL, TERRESTRIAL

17-11792 SMITH WR + THOMAS CE
A CONSOLIDATED NUCLEAR STEAM GENERATOR
BABCOCK AND WILCOX COMPANY
4 PAGES, NUCLEONICS 24(4), PAGES 39-42, (APRIL 1966)

DESCRIBES THE DESIGN OF A 200 MW(TH) PLANT TO BE USED FOR COMMERCIAL MARINE APPLICATION. THE DESIGN IS BASED ON THE EXPERIENCE GAINED FROM THE NS SAVANNAH PROGRAM. THE ENGINEERED SAFEGUARDS AND OPERATING EXPERIENCE OF THE SAVANNAH ARE REVIEWED. THE DESIGN OF THE CNSG REQUIRES HALF THE WEIGHT AND VOLUME OF THE SAVANNAH PLANT YET PROMISES REDUCED COSTS AND HIGHER RELIABILITY. THE CNSG PLANT HAS THE CORE, STEAM GENERATOR, AND PRESSURIZER WITHIN THE REACTOR VESSEL.

*N S SAVANNAH + *OPERATING EXPERIENCE + *REACTOR, MARITIME + REACTOR DESCRIPTION + REACTOR, PRESSURIZED WATER

17-11793 THOMAS RH
RADIATION HAZARDS OF THE NEW GENERATION OF ACCELERATORS
PUTHERFORD HIGH ENERGY LABORATORY, DIDCOT, ENGLAND
5 PAGES, NUCLEONICS 24(4), PAGES 64-69, (APRIL 1966)

REVIEWS THE SHIELDING, MAINTENANCE, AND INDUCED ACTIVITY PROBLEMS OF ACCELERATORS HAVING HIGH BEAM POWERS. IT IS INDICATED THAT FOR ACCELERATORS WITH HIGHER BEAM POWERS THE PROBLEMS OF ELECTRON AND PROTON MACHINES ARE SIMILAR. A BRIEF REVIEW IS ALSO GIVEN OF THE HAZARD OF OZONE. THE LONGER LIFETIME, THE UNAVAILABILITY OF MONITORING EQUIPMENT, AND THE UNCERTAINTY OF THE EFFECT OF OZONE ON MAN ARE DISCUSSED.

*ACCELERATOR + *RADIATION SAFETY AND CONTROL + *SHIELDING + MAINTENANCE AND REPAIR + OZONE

17-11794 EXPERIMENTAL BERYLLIUM OXIDE REACTOR PROGRAM. QUARTERLY PROGRESS REPORT FOR THE PERIOD ENDING MARCH 31, 1965.
GENERAL ATOMIC DIVISION OF GENERAL DYNAMICS
GA-6296 +. 33 PAGES, APRIL 28, 1965, CFSTI \$2.00 CY, \$0.50 MN

THIS REPORT IS ONE OF A SERIES OF REPORTS ON THE FOLLOWING TOPICS - (1) FUEL-PIN-CYCLING TESTS, (2) METALLOGRAPHIC EXAMINATION OF CLADDING SPECIMENS, (3) TESTING OF THE TIPPING REFLECTOR PNEUMATIC ACTUATOR, (4) SCRAM-MOTOR MALFUNCTION DUE TO IMPROPER FIT OF GEARS IN MOTOR HOUSING, (5) CHECKOUT OF FUEL-HANDLING TOOL, AND (6) STATUS OF CONSTRUCTION.

*EBOR (EXPERIMENTAL BERYLLIUM OXIDE REACTOR) + FAILURE, SCRAM MECHANISM + FUEL INTEGRITY + REACTOR, BEO MODERATED + REACTOR, GAS COOLED

17-11796 GRAY PL

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11796 *CONTINUED*

IN-SITU REPAIRS IN THE HEAVY WATER COMPONENTS TEST REACTOR
SAVANNAH RIVER LABORATORY E. I. DU PONT DE NEMOURS AND COMPANY, AIKEN, SOUTH CAROLINA
8 PAGES, 7 FIGURES, 4 REFERENCES, NUCLEAR APPLICATIONS 2(3), PAGES 213-220, JUNE 1966

BRIEFLY DESCRIBES THE PROCEDURE USED TO REPAIR AND MODIFY A GAS BAFFLE IN THE HWCTR. THE REPAIR WAS PERFORMED BY PLACING PERSONNEL, IN A SHIELDED BASKET, WITHIN 3-1/2 FT OF THE REACTOR CORE WHILE IRRADIATED FUEL REMAINED IN THE REACTOR. RADIATION DOSES TO PERSONNEL WAS HELD AT OR BELOW 140 MR. BY PROVIDING TWO-PIECE SUITS AND A SIMPLE VENTILATION SYSTEM, PROTECTION FROM INHALATION OF TRITIUM WAS PROVIDED. THE REPAIRS WERE COMPLETED IN 20 DAYS.

*MAINTENANCE AND REPAIR + FAILURE, COMPONENT + HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + INHALATION + RADIATION SAFETY AND CONTROL + REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER + TRITIUM

17-11797 GALL DA + DOYLE EF + BOURNE JG

AN AUTOMATIC FLOW BALANCING DEVICE FOR BOILING WATER REACTORS
DYNATECH CORPORATION, CAMBRIDGE, MASSACHUSETTS
5 PAGES, 3 FIGURES, 7 REFERENCES, NUCLEAR APPLICATIONS 2(3), PAGES 226-230, JUNE 1966

DESCRIBES A DEVICE TO CONTROL THE FRACTION OF VAPOR IN THE EXIT STEAM OF INDIVIDUAL FUEL-ELEMENT ASSEMBLIES FOR BOILING-WATER REACTORS. THE DEVICE CONSISTS OF TWO VENTURIS AND A PRESSURE-SIGNAL COMPARISON DEVICE WHICH CONTROLS THE FLOW BY MEANS OF A HYDRAULICALLY OPERATED VALVE. RESULTS INDICATED THAT THE DISCHARGE QUALITY WAS HELD TO PLUS OR MINUS 6 PERCENT OF THE DESIGN VALUE DURING TRANSIENTS IN THE HEAT TRANSFER RATE OF UP TO 25 PERCENT.

*CONTROL, GENERAL + *STEAM + REACTOR, BOILING WATER + VAPOR, VAPOR PRESSURE

17-11798 CHIRICO DI G + MERLI E

A PROTOTYPE MACHINE FOR HANDLING FUEL
COMITATO NAZIONALE ENERGIA NUCLEARE, ROME, ITALY
6 PAGES, 10 FIGURES, NUCLEAR APPLICATIONS 2(3), PAGES 231-236, JUNE 1966

DESCRIBES A FUEL- AND CONTROL-ROD-HANDLING MACHINE. THE DEVICE IS TO BE USED AT THE PROTOTIPO REATTORE ORGANICO, AN ORGANIC MODERATED AND COOLED REACTOR. A HOOKING DEVICE IS INSERTED INTO THE ELEMENT OR CONTROL ROD, AND THE ASSEMBLY IS THEN DRAWN UP INTO A GUIDE TUBE AND FINALLY INTO A CASK.

*FUEL HANDLING MACHINE + REACTOR, ORGANIC COOLED + REMOTE MANIPULATING AND VIEWING

17-11800 DUNSTER HJ + DUNCAN KP + DOLPHIN GW + LEGGE IK

ACCIDENTAL EXPOSURES TO IONISING RADIATIONS
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL
AHSB(RP)R-71 +. 20 PAGES, 2 TABLES, 25 REFERENCES, PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, NICE, APRIL 26-29, 1966, UKAEA

THREE PAPERS PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, APRIL 26-29, 1966. TITLES - (1) LESSONS TO BE DRAWN FROM SOME IRRADIATION ACCIDENTS IN THE UNITED KINGDOM, (2) EARLY MEASURES IN THE CARE OF PERSONS ACCIDENTALLY OVEREXPOSED TO IONIZING RADIATION, (3) DOSE ASSESSMENT FOLLOWING ACCIDENTAL INTAKE OF RADIOACTIVE MATERIAL.

*INCIDENT, ACTUAL, GENERAL + *OPERATING EXPERIENCE + *SAFETY PRINCIPLES AND PHILOSOPHY + DOSE CALCULATION, INTERNAL + DOSE MEASUREMENT, INTERNAL + RADIATION INJURY, TREATMENT OF + UNITED KINGDOM

17-11801 DUNSTER HJ + LEGGE IK

PAPER NO. 1 - LESSONS TO BE DERIVED FROM SOME IRRADIATION ACCIDENTS IN THE UNITED KINGDOM
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, HARWELL + MINISTRY OF LABOR
AHSB(RP)R-71 +. 9 PAGES, 1966, PAGES 1-9 OF ACCIDENTAL EXPOSURES TO IONIZING RADIATIONS, PRESENTED AT THE EURATOM SYMPOSIUM ON ACCIDENTAL IRRADIATION AT PLACE OF WORK, UKAEA

RATHER THAN MERELY DESCRIBE ACCIDENTS THAT HAVE HAPPENED, 27 LESSONS ON SAFETY PRINCIPLES ARE PRESENTED. THEY ARE ILLUSTRATED WITH BRIEF DESCRIPTIONS OF 20 INCIDENTS CAUSED BY EXPOSURES TO X-RAY EQUIPMENT, LARGE RADIOACTIVE SOURCES, CONTAMINATION, REMOVAL OF IRRADIATED MATERIAL FROM REACTORS, AND FIRES AND EXPLOSIONS.

*INCIDENT COMPILATION + *OPERATING EXPERIENCE + *SAFETY PRINCIPLES AND PHILOSOPHY + CONTAMINATION + FAILURE, OPERATOR ERROR + FIRE + GLOVE BOX + INCIDENT, ACTUAL, GENERAL + SOURCE, RADIATION + UNITED KINGDOM + X-RAY

17-11807 RULES AND REGULATION-MECHANICAL INSPECTION BUREAU-STATE OF NEW JERSEY

NEW JERSEY DEPARTMENT OF LABOR AND INDUSTRY
24 PAGES, SEPTEMBER 29, 1966, SOURCE

BRIEF SET OF RULES FOR PRESSURE-VESSEL CONSTRUCTION AND INSPECTION, AND FOR LICENSING OF BOILER ENGINEERS AND FIREMEN.

*REGULATION, STATE + CONTAINMENT, PRESSURE VESSEL + STAFFING, TRAINING, QUALIFICATION

17-11808 SMALLEY WR + PAXSON E

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11808 *CONTINUED*

ENGINEERING AND METALLURGICAL EVALUATION OF AN IRRADIATED YANKEE CORE 1 CONTROL ROD
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, ATOMIC POWER DIVISION

WCAP-6074 +. 58 PAGES, 26 FIGURES, 8 TABLES, 8 REFERENCES, DOCKET NO. 50-29, JULY 1966, CFSTI \$3.00 CY,
\$0.50 MN

NICKEL-PLATED SILVER-INDIUM-CADMIUM CONTROL RODS FROM YANKEE CORE 1 WERE EXAMINED TO DETERMINE THE EFFECTS OF REACTOR EXPOSURE ON THEIR IRRADIATION STABILITY. THE SAMPLES WERE EVALUATED FOR CHANGES IN SURFACE CONDITION, DIMENSIONS, MICROSTRUCTURE, AND TENSILE PROPERTIES. LARGE AREAS OF THE CONTROL-RODS ABSORBERS WERE DEVOID OF NICKEL PLATE, AND THE REMAINING PLATING HAD BEEN ATTACKED BY THE REACTOR COOLANT. ALSO, INTERNAL OXIDATION OF THE BASE METAL OCCURRED. THE AG-IN-CD ALLOY ITSELF DISPLAYED GOOD DIMENSIONAL AND IRRADIATION STABILITY DURING REACTOR OPERATION. THE MICROSTRUCTURE OF THE ALLOY WAS ALMOST UNCHANGED, WITH NO EVIDENCE OF NEW PHASES OR SIGNIFICANT PRECIPITATION. SIMILARLY, THE HARDNESS AND TENSILE PROPERTIES OF IRRADIATED ABSORBER SAMPLES SHOWED NO APPRECIABLE CHANGES. NO HYDROGEN PICKUP OCCURRED.

*CONTROL ROD, SHIM SAFETY + *EXAMINATION + REACTOR, PRESSURIZED WATER + YANKEE

17-11844 SIVERTS JG

SECTION 16 - FUEL FAILURE LOCATION IN NATURAL-CIRCULATION BWR BY LOCAL FLUX DEPRESSION AND BY STEAM SAMPLING FROM SEPARATE FUEL ELEMENTS

HPR-35 VOL. II +. 32 PAGES, 12 FIGURES, 7 TABLES, AUGUST 1964, PAGES 1-32, SECTION 16 FROM DEVELOPMENT AND APPLICATIONS OF IN-CORE INSTRUMENTATION AT HBWR VOLUME II, DEP MN

THREE METHODS OF IDENTIFYING OR LOCATING A FAILED FUEL ELEMENT WERE EXPERIMENTALLY INVESTIGATED AT THE HBWR DURING THE PERIOD FROM OCTOBER 1963 TO APRIL 1964 - (1) LOCAL FLUX DEPRESSION COUPLED WITH MONITORING OF THE BULK COOLANT ACTIVITY, (2) SAMPLING AND MONITORING OF THE COOLANT FROM INDIVIDUAL FUEL ELEMENTS, AND (3) INSERTING A SUSPECT FUEL ELEMENT IN A VACUUM FLASK AND SUBSEQUENTLY MONITORING THE EXHAUST AIR FROM THE FLASK. ALL THE METHODS HAD PRACTICAL VALUE, EVEN THOUGH RELATIVELY SIMPLE MONITORING TECHNIQUES WERE APPLIED AS A FIRST STEP.

*INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT + HALDEN + HBWR (HALDEN BOILING WATER REACTOR) + INSTRUMENTATION, IN CORE + MEASUREMENT, REACTIVITY + REACTOR, BOILING WATER

17-11941 HARRIS ER

INCIDENT AT GE PHILADELPHIA, PENNSYLVANIA PLANT, SEPTEMBER 7, 1966

GENERAL ELECTRIC COMPANY, PHILADELPHIA, PENNSYLVANIA

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(39), PAGE 45 (SEPTEMBER 26, 1966)

NO DETAILS ARE GIVEN OF CONTAMINATION INCIDENT INVOLVING BY-PRODUCT LICENSED ISOTOPES.

*INCIDENT, ACTUAL, GENERAL + CONTAMINATION + TRACER, RADIOACTIVE

17-11942 LEWIS WH

NFS PLANT SHUT DOWN BECAUSE OF FP CONTAMINATION OF ACID RECOVERY SYSTEM, SEPTEMBER 2, 1966

NUCLEAR FUEL SERVICES, WEST VALLEY, NEW YORK

1 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(39), PAGE 45 (SEPTEMBER 26, 1966) DOCKET NO. 50-201

LOW WATER LEVEL IN EVAPORATOR 7C-2 CAUSED BURPING, AND ENTRAINED FISSION PRODUCTS WERE CARRIED OVER INTO THE ACID-RECOVERY SYSTEM. THE EVAPORATOR WILL BE SHUT DOWN, THE ACID RECYCLED, AND THE EQUIPMENT FLUSHED.

*OPERATING EXPERIENCE + EVAPORATION + FAILURE, OPERATOR ERROR + NFS (NUCLEAR FUEL SERVICES) + RADIOCHEMICAL PROCESSING

17-11943 NFS CITED FOR ALLOWING AN UNLICENSED OPERATOR TO OPERATE, MAY 1966

NUCLEAR FUEL SERVICES, WEST VALLEY, NEW YORK

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(39), PAGE 45 (SEPTEMBER 26, 1966) DOCKET NO. 50-201

THE LICENSED OPERATOR HAD TO LEAVE FOR A SHORT TIME, AND AN UNLICENSED OPERATOR CONTINUED TO OPERATE AT THE GENERAL-PURPOSE CELL. ADMINISTRATIVE CHANGES WERE MADE.

*INSPECTION AND COMPLIANCE + ADMINISTRATIVE CONTROLS AND PRACTICES + NFS (NUCLEAR FUEL SERVICES) + RADIOCHEMICAL PROCESSING + STAFFING, TRAINING, QUALIFICATION

17-11945 MCCARTHY WJ

FERMI FUEL DAMAGE PRELIMINARY REPORT, OCTOBER 10, 1966

POWER REACTOR DEVELOPMENT COMPANY, DETROIT, MICHIGAN

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGES 9-10 (OCTOBER 17, 1966) DOCKET NO. 50-16

BRIEF REVIEW OF AN INCIDENT ON OCTOBER 5, 1966. ON RAISING THE POWER LEVEL TO 34 MW(TH), A REGULATING ROD SEEMED FARTHER OUT THAN NORMAL, ALSO TWO FUEL-OUTLET TEMPERATURES WERE ABOVE NORMAL. COVER-GAS ACTIVITY HAD INCREASED. SOME FUEL DAMAGE AND REDISTRIBUTION RESULTED, AND INVESTIGATIONS ARE CONTINUING.

*FAILURE, FUEL ELEMENT + FERMI + REACTOR, FAST BREEDER + REACTOR, LIQUID METAL COOLED

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11946 CLIFFORD FL
RADIOGRAPHY OVEREXPOSURE AT ELECTRIC BOAT, SEPTEMBER 12, 1966
GENERAL DYNAMICS CORPORATION, ELECTRIC BOAT DIV.
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGES 12-13 (OCTOBER 17, 1966)

A THREE-MAN TEAM HAD ARRANGED A SYSTEM OF CODED KNOCKS ON THE HULL, WHEREBY THE OUTSIDE MAN WOULD KNOCK WHEN THE FILM WAS IN PLACE AND HE WAS OUT OF THE WAY. HE RECEIVED 3.35 REMS (GAMMA) FROM AN IR-192 SOURCE WHEN THE INSIDE MAN THOUGHT HE HAD HEARD THE SIGNAL TO PROCEED. WORKERS WERE INSTRUCTED TO USE AUDIBLE MONITORS AND SOUND-POWERED TELEPHONES.

*FAILURE, ADMINISTRATIVE CONTROL + *FAILURE, OPERATOR ERROR + *INCIDENT, ACTUAL, HUMAN ERROR +
*RADIOGRAPHY + PERSONNEL EXPOSURE, RADIATION

17-11947 PUECHL KH
NUMEC, 3 AIRBORNE PLUTONIUM NITRATE INCIDENTS, JULY AND AUGUST 22, 1966
NUCLEAR MATERIALS AND EQUIPMENT CORPORATION, APOLLO, PENNSYLVANIA
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGES 13-14 (OCTOBER 17, 1966)

ON THREE OCCASIONS FOUR PERSONS RECEIVED OVER 40 TIMES THE MPC-EQUIVALENT HOURS EACH, BASED ON A BREATHING-ZONE ANALYSIS. MODIFICATIONS TO THE SCRAP-RECOVERY ROOM ELIMINATED STAGNANT AREAS. ONE MAN WAS EXPOSED WHEN REMOVING WASTE FROM AN OPEN-FRONT HOOD.

*PERSONNEL EXPOSURE, RADIATION + DOSE CALCULATION, INTERNAL + PLUTONIUM + WASTE HANDLING

17-11948 ALEXANDER RB
LOST RADIATION SOURCE, PHYLATRON CORPORATION, AUGUST 29, 1966
PHYLATRON CORPORATION, COLUMBUS, OHIO
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGES 14-15 (OCTOBER 17, 1966)

A 12-MILLICURIE CO-60 SOURCE WAS LOST EN ROUTE FROM COLUMBUS, OHIO, TO DES PLAINES, ILLINOIS. ATTEMPTS TO TRACE IT WERE UNSUCCESSFUL.

*SOURCE, RADIATION, LOST + TRANSPORTATION AND HANDLING

17-11949 NEW ENGLAND NUCLEAR CORPORATION CITED FOR NONCOMPLIANCE, AUGUST 8, 1966
NEW ENGLAND NUCLEAR CORPORATION, BOSTON, MASSACHUSETTS
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGE 15 (OCTOBER 17, 1966)

VARIOUS ADMINISTRATIVE FAILINGS DESCRIBED, INCLUDING FAILURE TO TRACE CAUSES OF HIGH TRITIUM CONTENT IN URINE, DISCHARGING 4.3 CURIES OF TRITIUM TO SEWER SYSTEM, AND CONSISTENTLY INADEQUATE EVALUATION OF AMOUNT OF RADIOACTIVE WASTE RELEASED TO SEWERS.

*INSPECTION AND COMPLIANCE + *TRITIUM + *WASTE DISPOSAL, LIQUID + SURVEY, RADIATION, GENERAL

17-11950 NUCLEAR SCIENCE AND ENGINEERING CORPORATION CITED FOR I-125 RELEASE, APRIL 14, 1966
NUCLEAR SCIENCE AND ENGINEERING CORPORATION, PITTSBURGH, PENNSYLVANIA
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGE 15-16 (OCTOBER 17, 1966)

NSEC REPLY (AUGUST 25, 1966) AGREES TO CITATION AND INDICATES RETRAINING AND INCREASED ADMINISTRATIVE, CONTROL MEASURES. CONTINUOUSLY MONITORING EQUIPMENT WAS PURCHASED.

*INCIDENT, ACTUAL, GENERAL + *IODINE + *RADIOCHEMICAL PROCESSING + FAILURE, ADMINISTRATIVE CONTROL

17-11951 WALSH JR
VA HOSPITAL REPORTS DOSES DUE TO BOTTLE MISLABELING, SEPTEMBER 12, 1966
VETERANS ADMINISTRATION HOSPITAL, PORTLAND, OREGON
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGE 16-17 (OCTOBER 17, 1966)

PORTLAND, OREGON, REPORTS THAT LABELS ON P-32 AND I-131 HIPURAN BOTTLES WERE SWITCHED AT THE FACTORY. TWO PATIENTS RECEIVED A DOSE OF 130 TO 160 RADS WHEN THEY MISTAKENLY GIVEN P-32. IODINE DOSES WERE NOT GIVEN. ASSERTS THAT THERE WERE NO HARMFUL EFFECTS.

*INCIDENT, ACTUAL, HUMAN ERROR + *PERSONNEL EXPOSURE, RADIATION + *TRACER, RADIOACTIVE + IODINE + PHOSPHORUS + RADIATION INJURY, TREATMENT OF

17-11953 MEHANN RO
VENTILATION-FILTER CHANGE AT NS SAVANNAH, SEPTEMBER 20, 1966
FIRST ATOMIC SHIP TRANSPORT, INC., NEW YORK, NEW YORK
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(41), PAGES 14-15 (OCTOBER 10, 1966) DOCKET NO. 50-238

A QUARTERLY TEST OF THE IODINE-REMOVAL EFFICIENCY OF BOTH VENTILATION FILTERS (SEPTEMBER 19, 1966) SHOWED REMOVAL FACTORS OF 504 AND 806. THE FILTERS WERE REPLACED AND CHECKED AS 11,681 AND 1,980. NO KNOWN REASON EXISTS FOR THIS APPARENT SIMULTANEOUS FAILURE. THE GASKET-SEALING METHODS WILL BE REEXAMINED.

*FAILURE, EQUIPMENT + *FAILURE, SIMULTANEOUS + *FILTER EFFICIENCY + *VENTILATION SYSTEM + N S SAVANNAH + REACTOR, MARITIME + REACTOR, PRESSURIZED WATER

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11954 WILL J
UKL CONCERNED ABOUT PERSONNEL WEAKENING AT FIRST ATOMIC SHIP TRANSPORT
FIRST ATOMIC SHIP TRANSPORT, INC, NEW YORK, NEW YORK
1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(41), PAGE 14 (OCTOBER 10, 1966) DOCKET NO. 50-238

DRL WROTE FAST ON SEPTEMBER 27, INDICATING CONCERN OVER THE SUDDEN TRANSFER OF TWO EXPERIENCED VICE PRESIDENTS. DRL VIEW WAS THAT A LARGE PART OF THE OPERATIONAL SAFETY OF THE NS SAVANNAH WAS VESTED IN THESE TWO INDIVIDUALS AND THAT THEY SHOULD BE REPLACED BY EQUALLY COMPETENT MEN. DRL ALSO EXPRESSED CONCERN OVER A POSSIBLE REDUCTION IN QUALIFICATION CRITERIA FOR THE CHIEF ENGINEER ON BOARD.

*STAFFING, TRAINING, QUALIFICATION + N S SAVANNAH + REACTOR, MARITIME + REACTOR, PRESSURIZED WATER

17-11962 GRONWALL B + LJUNGBERG L + HUBNER W + STUART W
INTERCRYSTALLINE STRESS CORROSION CRACKING OF INCONEL 600 INSPECTION TUBES IN THE AGESTA REACTOR
AKTIEBOLAGET ATOMENERGI, STOCKHOLM, SWEDEN
AE-245 +. 17 PAGES, 16 FIGURES, 9 TABLES, 10 REFERENCES, AUGUST 1966. DEP

INTERCRYSTALLINE STRESS-CORROSION CRACKING OCCURRED IN THREE INCONEL-600 INSPECTION TUBES, ON SURFACES EXPOSED TO H₂O AT 217 C (WITH 1-2 PPM LiOH), AND WITH TENSILE STRESS OF 0.2 PERCENT OFFSET YIELD STRESS (DUE TO SHOP WELDING). A RELATIVELY HIGH CARBON CONTENT (0.08 PERCENT) GAVE HEAVY PRECIPITATION. CRACKS WERE CIRCUMFERENTIAL. RECOMMENDATIONS - LOW CARBON CONTENT AND IMPURITIES (PREFERABLY BY USE OF VACUUM MELTING) AND SOLUTION ANNEALING AND QUENCHING. ALSO, AVOID THERMAL AND WELDING STRESS, OMIT CREVICES, AVOID GAS POCKETS AND BOILING, WHICH MAY ENRICH SOLUTES LOCALLY.

*CORROSION + *FAILURE, PIPE + *STRESS + CHLORINE + INCONEL + OPERATING EXPERIENCE + REACTOR, HEAVY WATER + REACTOR, PRESSURIZED WATER + SWEDEN

17-11963 POWER REACTOR STATUS
CONSOLIDATED EDISON COMPANY
1 PAGE, NUCLEAR INDUSTRY 13(10), PAGE 19 (OCTOBER 1966) DOCKET NO. 50-3

PAGE 19.- INDIAN POINT I, SHUTDOWN FROM SEPTEMBER 23 TO OCTOBER 8, 1966, TO PLUG LEAKS IN BOILER TUBES.

*FAILURE, PIPE + HEAT EXCHANGER + INDIAN POINT I + REACTOR, PRESSURIZED WATER

17-11964 POWER REACTOR STATUS
CONSUMERS POWER COMPANY
1 PAGE, NUCLEAR INDUSTRY 13(10), PAGE 19 (OCTOBER 1966) DOCKET NO. 50-155

PAGE 19.- BIG ROCK POINT WAS SHUT DOWN ON SEPTEMBER 17, 1966. LEAKING FUEL TUBES WERE FOUND IN FOUR STAINLESS-STEEL-CLAD FUEL ELEMENTS AND IN FOUR INCOLOY DEVELOPMENTAL ASSEMBLIES.

*FAILURE, CLADDING + BIG ROCK POINT + REACTOR, BOILING WATER

17-11965 CAMPBELL RJ + HALL D + KETTNER D
ELK RIVER REACTOR OPERATING EXPERIENCE
RURAL COOPERATIVE POWER ASSOCIATION
14 PAGES, 3 TABLES, 19 REFERENCES, NUCLEAR SAFETY 7(4), PAGES 482-495 (SUMMER 1966) DOCKET NO. 115-1

BRIEFLY DESCRIBES THE 50-MW(T) INDIRECT-CYCLE BOILING WATER REACTOR. PERFORMANCE DETAILS ARE GIVEN FOR THE REACTOR VESSEL, CONTROL RODS AND DRIVES, POISON-INJECTION SYSTEM, FUEL ELEMENTS, EVAPORATOR, CONTAINMENT VESSEL, AND FOSSIL-FUELED SUPERHEATER. OPERATION AND CONTROL OF THE PLANT ARE REVIEWED. CHANGES IN THE REACTOR INSTRUMENTATION ARE DISCUSSED. REVIEWS THE PLANT RADIATION LEVELS, WASTE-DISPOSAL OPERATIONS, PRIMARY-COOLANT ACTIVITY LFVFLS, AND PERSONNEL-MONITORING PROGRAM.

*OPERATING EXPERIENCE + CONTAINMENT, PRESSURE VESSEL + CONTROL ROD + CONTROL ROD DRIVE + ELK RIVER + FUEL ELEMENT BOWING + RADIATION SAFETY AND CONTROL + REACTOR, BOILING WATER + REACTOR, POWER + SHUTDOWN SYSTEM, SECONDARY + WASTE DISPOSAL, GENERAL

17-11966 CAMPBELL RJ + HALL D + KETTNER D
FUEL ELEMENT DISTORTION
RURAL COOPERATIVE POWER ASSOCIATION
1 PAGE, NUCLEAR SAFETY 7(4), PAGE 487 OF ELK RIVER REACTOR OPERATING EXPERIENCE, (SUMMER 1966) DOCKET NO. 115-1

PAGE 487.- IN 1964 TWO FUEL TUBES WERE OBSERVED TO BE BOWED OR DISTORTED. AGAIN IN 1966, 45 ELEMENTS HAD BOWED TUBES. THE BOWING OCCURRED IN THE OUTER TUBES ONLY. NO EXPLANATION HAS BEEN FOUND. TWO 17-4PH STEEL BOLTS USED ON THE SPRAY-RING FLANGES HAVE BEEN FOUND BROKEN. AN ANALYSIS SHOWED THAT THERMAL CYCLING COULD CAUSE FRACTURE. THE BOLTS WERE REPLACED WITH TYPE-316 STAINLESS-STEEL BOLTS. BECAUSE OF WEATHER, ELECTRIC HEATERS ARE USED AROUND PIPE PENETRATIONS IN THE CONTAINMENT SHELL TO ENSURE THAT THE STEEL IS KEPT ABOVE THE DUT OF 10 F.

*FAILURE, FATIGUE + *FUEL ELEMENT BOWING + CONTAINMENT STRUCTURE + CORE SPRAY + ELK RIVER + FAILURE, COMPONENT + NDT DATA (NIL DUCTILITY TRANSITION) + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, POWER

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11967 CAMPBELL RJ + HALL D + KETTNER D
EMERGENCY BORON-INJECTION SYSTEM
RURAL COOPERATIVE POWER ASSOCIATION
1 PAGE, NUCLEAR SAFETY 7(4), PAGE 486 OF ELK RIVER REACTOR OPERATING EXPERIENCE, (SUMMER 1966) DOCKET NO. 115-1

PAGE 486.- THE SOLUTION USED FOR THE SECONDARY SHUTDOWN SYSTEM WAS CHANGED FROM BORIC ACID TO SODIUM PENTABORATE. THE BORIC ACID SOLUTION HAD TO BE KEPT AT 200 F TO PREVENT CRYSTALLIZATION. THE SODIUM PENTABORATE SOLUTION IS MORE RELIABLE BECAUSE IT CAN BE STORED AT AMBIENT TEMPERATURES WITHOUT PRECIPITATION.

*POISON, SOLUBLE + *SHUTDOWN SYSTEM, SECONDARY + ELK RIVER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, POWER

17-11968 CAMPBELL RJ + HALL D + KETTNER D
PERFORMANCE OF CONTROL RODS AND CONTROL-ROD DRIVES
RURAL COOPERATIVE POWER ASSOCIATION
1 PAGE, NUCLEAR SAFETY 7(4), PAGE 485 OF ELK RIVER REACTOR OPERATING EXPERIENCE, (SUMMER 1966) DOCKET NO. 115-1

PAGE 485.- INFORMATION, OBTAINED IN 1962 AFTER FABRICATION OF THE CONTROL-ROD DRIVES INDICATED THAT SEVERAL PARTS SHOULD BE REPLACED. THE PARTS WERE MADE OF 17-4 PH STEEL, AND THE HEAT TREATMENT WAS SUCH THAT THE PARTS COULD CRACK IN HIGH-TEMPERATURE WATER. THE PARTS WERE REMOVED AND RETREATED OR REPLACED WITH THOSE OF THE H1100 CONDITION. TYPE-304 STAINLESS-STEEL RIVETS USED IN THE CONTROL RODS WERE THOUGHT TO BE SUBJECT TO STRESS CORROSION AND WERE REPLACED WITH INCONEL RIVETS. TENSILE SPECIMENS OF 2 PERCENT BORON-STAINLESS-STEEL INDICATED ELONGATION BELOW THE TECHNICAL-SPECIFICATION LIMIT, HOWEVER BORON CARBIDE RODS WILL BE USED FOR REPLACEMENT SINCE THEY ARE MORE DUCTILE AND WILL LAST LONGER.

*CONTROL ROD + *CONTROL ROD DRIVE + *FAILURE, COMPONENT + BORON + CORROSION + ELK RIVER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, POWER + STEEL, STAINLESS

17-11969 CAMPBELL RJ + HALL D + KETTNER D
CONTROL-ROD CALIBRATION
RURAL COOPERATIVE POWER ASSOCIATION
1 PAGE, NUCLEAR SAFETY 7(4), PAGE 484 OF ELK RIVER REACTOR OPERATING EXPERIENCE, (SUMMER 1966) DOCKET NO. 115-1

PAGE 484.- DURING ROD-CALIBRATION TESTS, SOME ROD CONFIGURATIONS RESULTED IN A REACTIVITY INCREASE OF 6 CENTS WITH INSERTION OF A ROD. THIS EFFECT WAS ATTRIBUTED TO THE FACT THAT THE ZIRCALOY FOLLOWER DOES NOT EXTEND THE FULL LENGTH OF THE CORE. WHEN THE ROD IS FULLY OUT, THERE IS 13 IN. OF WATER IN THE CORE BELOW THE FOLLOWER. THE CORE IS OVERMODERATED AT LOW TEMPERATURES, SO, WHEN THE ROD IS INSERTED, THE FOLLOWER DISPLACES WATER AND INCREASES REACTIVITY. THIS EFFECT IS NOT REALIZED DURING NORMAL OPERATIONS BECAUSE (1) IT OCCURS AT LOW TEMPERATURES, AND, BEFORE ROD REMOVAL CAN COMMENCE, THE WATER MUST BE AT 425 F, AND (2) WITH THE ROD BANK AT 32 IN., THE FLUX PEAKS AT THE INTERFACE OF THE FOLLOWER AND POISON SECTION.

*CONTROL ROD CALIBRATION + *REACTIVITY EFFECT, ANOMALOUS + ELK RIVER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, POWER

17-11970 CAMPBELL RJ + HALL D + KETTNER D
REACTOR VESSEL PERFORMANCE
RURAL COOPERATIVE POWER ASSOCIATION
1 PAGE, NUCLEAR SAFETY 7(4), PAGE 484 OF ELK RIVER REACTOR OPERATING EXPERIENCE, (SUMMER 1966) DOCKET NO. 115-1

PAGE 484.- THE PERFORMANCE OF THE REACTOR COMPONENTS IS REVIEWED. DEFECTS IN THE VESSEL CLADDING WERE DETECTED, RESULTING IN THE ACRS PERMITTING OPERATION OF THE VESSEL FOR FIVE EFFECTIVE FULL-POWER YEARS. EXTENSION OF THE OPERATING LIMIT IS SUBJECT TO NEW INFORMATION.

*CONTAINMENT, PRESSURE VESSEL + *FAILURE, PRESSURE VESSEL + ELK RIVER + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, POWER

17-11971 INCIDENTS RELATED TO NUCLEAR SAFETY IN AEC OPERATIONS
DIVISION OF OPERATIONAL SAFETY USAEC
4 PAGES, 1 TABLE, 6 REFERENCES, NUCLEAR SAFETY 7(4), PAGES 495-498 (SUMMER 1966)

INCIDENTS COMPILED FOR CALENDAR YEAR 1965. REPORTING CRITERIA ARE PERSONNEL DOSE GREATER THAN 1 QUARTER OR COST GREATER THAN 5000 DOLLARS. VARIOUS X RAY AND RADIOGRAPHY INCIDENTS DUE TO POOR TECHNIQUE AND COMPONENT FAILURE, AND VARIOUS CHEMICAL PROCESSING INCIDENTS RELEASED RADIOACTIVE MATERIALS IN THE WORKING AREA. SOME INCIDENTS HAVE BEEN REVIEWED IN DETAIL IN VARIOUS AEC BULLETINS.

*INCIDENT COMPILATION + PERSONNEL EXPOSURE, RADIATION + RADIOCHEMICAL PROCESSING + RADIOGRAPHY + REACTOR, AEC OWNED

17-11972 BLAKELY JP
FUEL-ASSEMBLY CLADDING-DEFECT DETERMINATIONS USING THE DRY SIPPING TECHNIQUE

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11972 *CONTINUED*

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

3 PAGES, 1 FIGURE, 2 REFERENCES, NUCLEAR SAFETY 7(4), PAGES 511-513 (SUMMER 1966) DOCKET NO. 50-133

WET SIPPING IS TIME-CONSUMING AND REQUIRES CAREFUL PROCESS CONTROL. DRY SIPPING WAS USED AT HUMBOLDT BAY TO SPOT 32 LEAKY FUEL ELEMENTS WHEN THE WHOLE CORE WAS CHECKED IN THE FALL OF 1965. A FUEL ELEMENT IS PLACED IN A SPECIAL UNDERWATER CAN, AND AIR IS USED TO FORCE THE WATER OUT FOR ABOUT 10 MIN. THE RESULTANT HEATUP TO A CLAD-SURFACE TEMPERATURE OF 300 F RELEASES RADIOACTIVE GAS THROUGH CLAD DEFECTS, AS DURING OPERATION, AND THIS IS EASILY MONITORED BY SAMPLING THE AIR IN THE CAN. USAEC DRL REQUESTED PROVISION OF A HIGH-TEMPERATURE ALARM AND AN AUTOMATIC REFLOODING CAPABILITY.

*FAILURE, CLADDING + FUEL INTEGRITY + HUMBOLDT BAY + REACTOR, BOILING WATER

17-11988 SCOTT RL

UNDERWATER HANDLING OF HFIR COMPONENTS

OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE

35 PAGES, 23 FIGURES, 1 REFERENCE AND TRANSACTIONS 9(2), PAGES 529-563, PRESENTED PITTSBURGH ANS MEETING, OCTOBER 31, 1966

BRIEFLY DESCRIBES THE HIGH FLUX ISOTOPE REACTOR COMPONENTS AND ASSEMBLY. PREREQUISITES FOR ADEQUATE TOOLING IS TREATED IN DETAIL ALONG WITH THE DESIGN TO MEET THE REQUISITES. METHODS FOR HANDLING THE COMPONENTS ARE DISCUSSED, WITH EMPHASIS ON THE MINIMUM CLEARANCES. TO PROVIDE REASONABLY TROUBLE-FREE OPERATION, THE OPERATORS SHOULD BE THOROUGHLY TRAINED, AND DETAILED PROCEDURES WITH DRAWINGS AND PICTURES SHOULD BE PROVIDED IN ADDITION TO EXCELLENT TOOLING.

*OPERATING EXPERIENCE + HFIR (HIGH FLUX ISOTOPE REACTOR) + MAINTENANCE AND REPAIR + REACTOR, RESEARCH + REACTOR, TEST + REMOTE MANIPULATING AND VIEWING

17-11990 PRTR ELEMENT HYDRIDING FROM FINGERPRINTS

BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY

BNWL-269 +. 2 PAGES OF CERAMICS RESEARCH AND DEVELOPMENT QUARTERLY REPORT. OCTOBER-DECEMBER 1965, PAGE 3.26, PAGE 4.8, AUGUST 12, 1966, CFSTI

PAGE 3.26.- TWO ZIRCALOY RODS FROM THE PRTR WHICH LEAKED FISSION PRODUCTS IN 1965 WERE EXAMINED. THE DEFECTS WERE LOCATED IN A DISCOLORED AREA OF THE CLADDING. AN AREA ON ONE ELEMENT SHOWED MASSIVE HYDRIDING AND THE OTHER ELEMENT BROKE IN SUCH AN AREA DURING HOT-CELL HANDLING. ALL ACTIVE PRTR ELEMENTS WERE EXAMINED IN STORAGE, SEVEN HAVING SUSPECTED HYDRIDE AREAS. THE SHAPE OF SOME OF THE AREAS IS THAT OF A FINGERPRINT. PLASTIC BAGS ARE NOW USED TO PREVENT GREASE DEPOSITION DURING HANDLING. PAGE 4.8.- REJECTED SEXTON TUBING WAS THERMAL-CYCLED IN A PROGRAM TO EVALUATE MANUFACTURING DEFECTS ON FUEL-ROD PERFORMANCE. MANY ULTRASONIC DEFECTS WERE NOT DETECTED DURING SECTIONING.

*FAILURE, CLADDING + ADMINISTRATIVE CONTROLS AND PRACTICES + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, PRESSURE TUBE + REACTOR, PRESSURIZED WATER + TEST, NONDESTRUCTIVE

17-11991 OPERATIONS EXPERIENCE

RURAL COOPERATIVE POWER ASSOCIATION, ELK RIVER, MINNESOTA

COO-651-35 +. 6 PAGES, RURAL COOPERATIVE POWER ASSOCIATION ELK RIVER REACTOR, 46TH MONTHLY OPERATING REPORT, PAGES 9-15, SECTION III, AUGUST 1966, DOCKET NO. 115-1, PDR

SECT. III.- FIVE LEAKY TUBES WERE PLUGGED IN EVAPORATOR 1. (PART E)- CENTER (REGULATING) ROD POSITION AND LINEAR POWER-RANGE INSTRUMENT WAS CALIBRATED AGAINST POWER. AT 14.1 IN., 0.89 MW/IN. (AT 1723 MWD ON CORE II) OBSERVED GREATER THAN THE 0.78 MW/IN. (AT 19,000 MWD ON CORE I). NEAR FULL POWER, A 1 PERCENT CHANGE IN POWER CAUSES A 2 PERCENT CHANGE IN READING BECAUSE OF VARIABLE LEAKAGE-NEUTRON ATTENUATION AS THE PRIMARY PRESSURE VARIES WITH POWER. THE INSTRUMENT ACTS AS A SQUARE-ROOT FLOWMETER DOES (F)-HIGH CHLORIDE CONTENT IN PRIMARY SYSTEM TRACED TO LONG-TERM CHLORIDE FILM BUILDUP IN A COLLECTION TANK, WHICH INCIDENTALLY HAD NO ACCESS PORTS. (G)-STACK MONITOR ALARM SETTING DRIFTED OFFSCALE, DESPITE INSTALLING AIR CONDITIONER FOR BETTER TEMPERATURE CONTROL OF THE CIRCUITS. A BETTER CONTROLLER FOR THE CONTROL ROOM INSTRUMENT AIR CONDITIONER WILL BE INSTALLED, ALONG WITH ALARMS.

CHLORINE + CONTROL ROD CALIBRATION + COOLANT CHEMISTRY + ELK RIVER + INSTRUMENTATION, ABNORMAL INDICATION + INSTRUMENTATION, POWER RANGE + MONITOR, RADIATION, STACK + REACTOR, AEC OWNED + REACTOR, BOILING WATER

17-11992 FRESHLEY MD + WHEELER RG + BATCH JM + HESSON GM

INVESTIGATION OF THE COMBINED FAILURE OF A PRESSURE TUBE AND DEFECTED FUEL ROD IN PRTR

BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON

BNWL-272 +. 151 PAGES, 3 TABLES, 57 FIGURES, 27 REFERENCES, MAY 13, 1966, CFSTI \$5.00 CY, \$1.00 MN

ON SEPTEMBER 29, 1965, A FUEL MELTDOWN AND PRESSURE-TUBE RUPTURE RELEASED FISSION GAS INTO THE PRTR BUILDING THROUGH COVER-GAS-SYSTEM LEAKS, CAUSING EXTENSIVE CONTAMINATION. THIS REPORT REVIEWS THE FUEL-ELEMENT FAILURE. VIBRATORY-COMPACTED FUEL ROD FR4 WAS IRRADIATED TO APPROXIMATELY 900 MWD/TON U, THEN A HOLE WAS DRILLED THROUGH THE CLADDING AND IT WAS REPLACED IN THE SEPARATE LOOP FOR IRRADIATION AT 27 KW/FT WITH CENTERLINE MELTING. THREE DAYS AFTER REPLACEMENT, THE INCIDENT OCCURRED DURING SCHEDULED LOOP-FLOW REDUCTIONS. WATER ENTERED THE FUEL REGION AND LOCALLY OXIDIZED THE (U,Pu) OXIDE TO AN O/U RATIO OF 2.1. THE REDUCED THERMAL CONDUCTIVITY AND LOWERED MELTING POINT INCREASED THE MOLTEN ZONE, ALREADY 3/4 OF THE FUEL RADIUS. EXPANSION BLOCKED OFF COOLANT FLOW AND WITHIN 24 SEC THE PRESSURE TUBE RUPTURED BECAUSE OF OVERHEATING. THE RESULTANT LOCALLY INCREASED PRESSURE BLEW MOLTEN FUEL FROM THE FUEL ROD THROUGH THE PRESSURE-TUBE RUPTURE HOLE INTO THE MODERATOR. BEHAVIORAL DIFFERENCES

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-11992 *CONTINUED*
WERE FOUND AMONG INTACT VIBRATORILY PACKED FUEL RODS AND BETWEEN DEFECTIVE AND INTACT MIXED-OXIDE RODS.

*FUEL MELTDOWN + *INCIDENT, ACTUAL, GENERAL + CENTERLINE MELTING + FAILURE, CLADDING + IN PILE LOOP + PLUTONIUM OXIDE + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST + STOICHIOMETRY + URANIUM OXIDE

17-11993 FRESHLEY MD + WHEELER RG + BATCH JM + HESSON GM
REACTOR-POWER FLUCTUATIONS AT PRTR
BATTELLE-NORTHWEST, PACIFIC NORTHWEST LABORATORY, RICHLAND, WASHINGTON
BNWL-272 +. 1 PAGE, INVESTIGATION OF THE COMBINED FAILURE OF A PRESSURE TUBE AND DEFECTED FUEL ROD IN PRTR, PAGE 9, MAY 13, 1966, CFSTI \$5.00 CY, \$1.00 MN

TWO REACTOR-POWER FLUCTUATIONS ARE MENTIONED. (1) ANOMALOUS POWER FLUCTUATIONS INCLUDED A 20 PERCENT OVERPOWER TRANSIENT THAT OCCURRED IN 11 SEC DURING INTENDED STEADY-STATE OPERATION. (2) A REACTOR INSTABILITY WAS TRACED TO MECHANICAL PROBLEMS IN THE CONTROL SYSTEM AND ELIMINATED. NUCLEATE BOILING IN THE IN-PILE LOOP MAY HAVE AGGRAVATED THE PROBLEM.

*CONTROL SYSTEM + *REACTOR STABILITY + PRTR (PLUTONIUM RECYCLE TEST REACTOR) + REACTOR, AEC OWNED + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE + REACTOR, TEST

17-11998 PICONE LF + TAYLOR GR
CHEMICAL EVALUATION OF YANKEE CORE I FUEL CLADDING CORROSION PRODUCTS
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA
WCAP-6072 +. 68 PAGES, 17 TABLES, 12 FIGURES, 12 REFERENCES, AUGUST 1966, CFSTI \$3.00 CY, \$0.75 MN, DOCKET NO. 50-29

EVALUATIONS ARE GIVEN OF THE DISTRIBUTION, COMPOSITION, AND ACTIVITY OF CORROSION PRODUCTS ON STAINLESS-STEEL FUEL-ROD CLADDING AFTER IRRADIATION. CONTROL-ROD POISONS WERE ALMOST UNDETECTED. BORON WAS DETECTED, BUT IT IS CONCLUDED THAT MOST OF IT WAS INTRODUCED AS A CONTAMINANT DURING THE ANALYTICAL PROCEDURE. THE TIGHTLY BOUND CORROSION FILM HAD NO EFFECT ON THE SYSTEM PRESSURE DROP, AND NO FLOW DECREASE WAS EXPERIENCED. THE CORROSION FILM RESULTED IN A NEGATIVE REACTIVITY OF 0.23 PERCENT FOR CORE I AND 0.060 PERCENT FOR CORE II. CHANGES OF 0.5 PERCENT WERE OBSERVED DURING PH CHANGES. THE CORROSION FILM APPEARS TO BE DEPOSITED RATHER THAN BASE-METAL CORROSION PRODUCTS. EXPERIMENTAL VERIFICATION HAS BEEN MADE FOR IRON, NICKEL, AND COBALT, BUT NOT FOR CHROMIUM.

*CORROSION + *SURFACE FILM DEPOSIT + COOLANT CHEMISTRY + CRUD + EXAMINATION + FUEL ELEMENT + REACTIVITY EFFECT, ANOMALOUS + REACTOR, PRESSURIZED WATER + STEEL, STAINLESS + YANKEE

17-11999 HBWR QUARTERLY PROGRESS REPORT, APRIL TO JUNE 1966
INSTITUTT FOR ATOMENERGI, HALDEN, NORWAY
HPR-68 +. 105 PAGES, 5 REFERENCES, 40 FIGURES, 5 TABLES, AUGUST 1966, CFSTI

THE THICKNESS OF TWO ALUMINUM GASKETS, (SEALING BETWEEN THE VESSEL LID AND FLANGE) HAS BEEN MONITORED SINCE 1958 AND A CONTINUING DECREASE NOTED. THE INCREASE IN GASKET WIDTH INDICATES THAT THE YIELDING MUST BE CAUSED BY A RELATIVE MOVEMENT BETWEEN THE FLANGE AND LID DUE TO THERMAL CYCLING, RESULTING IN A KNEADING EFFECT. GAMMA THERMOMETERS ARE USED TO MEASURE POWER OF INDIVIDUAL FUEL CHANNELS. HOWEVER, THE SIGNAL IS INFLUENCED BY SEVERAL FACTORS REQUIRING CALIBRATION AGAINST FLOW AND TEMPERATURE USE. IN AN EFFORT TO ELIMINATE THE CALIBRATION, A THEORETICAL ANALYSIS OF THE SIGNAL IS GENERATED IN THE ASSEMBLY. INDICATES THAT 50 TO 70 PERCENT IS FROM THE ASSEMBLY CONTAINING THE THERMOMETER.

*OPERATING EXPERIENCE + ALUMINUM + CONTAINMENT, PRESSURE VESSEL + GAMMA + HALDEN + INSTRUMENTATION, IN CORE + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + SEAL

17-12000 TARGET - A PROGRAM FOR A 1000-MW(E) HIGH-TEMPERATURE GAS-COOLED REACTOR. QUARTERLY PROGRESS REPORT FOR THE PERIOD ENDING MAY 31, 1964.
GENERAL DYNAMICS CORPORATION, GENERAL ATOMIC DIVISION, SAN DIEGO, CALIFORNIA
GA-5366 +. 149 PAGES, 27 REFERENCES, 46 FIGURES, 22 TABLES, JULY 1, 1964, CFSTI \$4.00 CY, \$1.00 MN

THE DEVELOPMENT EFFORT FOR THE PAST QUARTER IS REPORTED. TOPICS DISCUSSED ARE - (1) A DESIGN STUDY OF A 150- TO 300-MW(E) PROTOTYPE PLANT WHICH INCLUDES AN ANALYSIS OF A RUPTURE IN THE PRIMARY COOLANT SYSTEM, A TRANSIENT AND STEADY-STATE ANALYSIS, A VESSEL-DESIGN STUDY, AND SHIELDING STUDIES, (2) THE FUEL DEVELOPMENT PROGRAM, INCLUDING STUDIES OF THE PROPERTIES AND FEASIBILITY OF LOOSE COATED-PARTICLE FUEL SYSTEMS, (3) THE GRAPHITE DEVELOPMENT PROGRAM, IN WHICH EVALUATIONS OF VENDOR STOCKS AND IMPREGNATION STUDIES ARE REPORTED, (4) FISSION PRODUCT SORPTION AND DIFFUSION IN GRAPHITE, (5) FUEL-CYCLE STUDIES, (6) CONSTRUCTION-MATERIAL STUDIES, (7) HELIUM-PURIFICATION SYSTEMS, AND (8) DEVELOPMENT OF A MOISTURE-DETECTION SYSTEM AND ADAPTATION OF AN ACOUSTIC THERMOMETER TO MEASURE FUEL-ELEMENT TEMPERATURES.

*RESEARCH CONTRACT + COATED PARTICLE + FISSION PRODUCT TRANSPORT + GRAPHITE + HELIUM + INSTRUMENTATION, TEMPERATURE + MATERIAL + REACTOR, BREEDER + REACTOR, GAS COOLED + REACTOR, POWER

17-12038 BALL SJ
SIMULATORS FOR TRAINING MOLTEN-SALT REACTOR EXPERIMENT OPERATORS
OAK RIDGE NATIONAL LABORATORY, OAK RIDGE, TENNESSEE
ORNL-TM-1445 +. 24 PAGES, 11 FIGURES, 2 TABLES, APRIL 5, 1966, CFSTI \$1.00 CY, \$0.50 MN

CATEGORY 17
OPERATIONAL SAFETY AND EXPERIENCE

17-12038 *CONTINUED*

TWO ON-SITE REACTOR KINETICS SIMULATORS WERE DEVELOPED FOR TRAINING OPERATORS OF THE MOLTEN-SALT REACTOR EXPERIMENT (MSRE) IN NUCLEAR STARTUP AND POWER-LEVEL OPERATING PROCEDURES. BOTH SIMULATORS WERE SET UP ON GENERAL PURPOSE, PORTABLE ELECTRONIC ASSOCIATES, INC., TR-10 ANALOG COMPUTERS AND WERE CONNECTED TO THE REACTOR CONTROL AND INSTRUMENTATION SYSTEM. THE TRAINING PROGRAM WAS SUCCESSFULLY COMPLETED. ALSO, THE REACTOR CONTROL AND INSTRUMENTATION SYSTEM, THE OPERATING PROCEDURES, AND THE ROD AND RADIATOR-DOOR DRIVES WERE CHECKED OUT. SOME MINOR MODIFICATIONS WERE MADE TO THE SYSTEM AS A RESULT OF THE EXPERIENCE WITH THESE SIMULATORS.

*COMPUTER PROGRAM + *MSRE (MOLTEN SALT REACTOR EXPERIMENT) + *REACTOR KINETICS +
*STAFFING, TRAINING, QUALIFICATION + COMPUTER, ANALOG

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-07700 DE SAINT MAURICE A + CANFIELD R
THERMAL-COLUMN PNEUMATIC FACILITY
COLUMBIA UNIVERSITY IRL, PLAINSBORO, NEW JERSEY
1 PAGE, 2 FIGURES, AMERICAN NUCLEAR SOCIETY CONFERENCE ON REACTOR OPERATING EXPERIENCE, JACKSON LAKE LODGE, WYOMING, JULY 28-29, 1965, ANS TRANSACTIONS, SUPPLEMENT TO VOLUME 8, PAGE 1

A THERMAL COLUMN PNEUMATIC RABBIT FACILITY WAS INSTALLED IN THE SMW IRL RESEARCH REACTOR. PREVIOUSLY, SAMPLES COULD BE INSERTED ONLY WHILE THE REACTOR WAS DOWN. THE TUBE IS BENT TO PREVENT STREAMING.

*IN PILE LOOP + IN PILE EXPERIMENT + REACTOR, RESEARCH

18-09276 ENGINEERING MATERIALS LIST
DIVISION OF TECHNICAL INFORMATION
TID-4100 (SUPPL. 32) +. 60 PAGES, FEBRUARY 1966, DTIC, FREE

THE ENGINEERING MATERIALS LIST ANNOUNCES THE PUBLIC AVAILABILITY OF ENGINEERING DRAWINGS, SPECIFICATIONS, PARTS LISTS, AND RELATED MATERIALS OF INSTRUMENTS, REACTORS, DEVICES, ETC., DEVELOPED UNDER RESEARCH AND DEVELOPMENT PROGRAMS OF THE UNITED STATES ATOMIC ENERGY COMMISSION. PUBLICATIONS USED TO ANNOUNCE THESE MATERIALS ARE IDENTIFIED AS FOLLOWS - TID-4100 (1ST REV.), MAY 1958, TID-4100 (1ST REV.), SUPPLEMENT 1, JULY 1958, TID-4100, SUPPLEMENT 2, NOVEMBER 1958, THROUGH SUPPLEMENT 31, DECEMBER 1965.

*ENGINEERING DRAWING LIST

18-09453 OKRENT D
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS REPORT TO AEC ON PROPOSED ROCHESTER, N.Y., REACTOR U. S. ATOMIC ENERGY COMMISSION
PRESS RELEASE J-72 +. 4 PAGES, MARCH 25, 1966, DPI

ACRS BELIEVES THAT SEVERAL ACTIONS SHOULD BE TAKEN BEFORE SETTING DESIGN OF NOVEL CONCRETE CONTAINMENT BUILDING. APPLICANT HAS AGREED TO PROVIDE ADDITIONAL REDUNDANCY OR INDEPENDENCE IN EMERGENCY SAFEGUARDS, SERVICE WATER, AND CONTROL-ROOM SHIELDING. XENON OSCILLATION AND POD EJECTION WILL BE ANALYZED. ACRS SUGGESTS FURTHER CONSIDERATION FOR IN-SERVICE INSPECTION OF REACTOR VESSEL.

*ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + *BROOKWOOD + *CONCRETE, PRESTRESSED + CONTAINMENT, HIGH PRESSURE + ENGINEERED SAFEGUARD + REACTOR, PRESSURIZED WATER + XENON OSCILLATION

18-09687 630A MARK V MARITIME NUCLEAR STEAM GENERATOR STATUS REPORT. ROUGH DRAFT.
GENERAL ELECTRIC, ADVANCED TECHNOLOGY SERVICES
GEMP-342 +. 231 PAGES, FEBRUARY 26, 1965, CFSTI, \$6.00 CY

INCLUDED IN THIS REPORT ARE DETAILED DESCRIPTIONS OF 630A, PRESSURE VESSEL, CONTAINMENT, ACCESSORIES, AND A SAFETY ANALYSIS INCLUDING THE REFERENCE ACCIDENT AND A REFUELING ACCIDENT. APPENDED ARE SPECIFICATIONS AND OPERATING CONDITIONS, AND OPERATING AND SAFETY PARAMETERS AND ACTIONS.

*ACCIDENT ANALYSIS + *ACCIDENT, REFUELING + *CONTAINMENT, GENERAL + *MAINTENANCE AND REPAIR + *REACTOR, MARITIME + *WASTE HANDLING + *630 A (MARITIME REACTOR) + ACCIDENT, CONSEQUENCES + ACCIDENT, CONTROL ROD WITHDRAWAL + CONTAINMENT LEAKAGE CONTROL + CONTAINMENT, PRESSURE VESSEL + EXCURSION, LARGE + LOSS OF COOLANT + LOSS OF FLOW + OPERATIONS REPORTS, GENERAL + REACTOR DESCRIPTION + REACTOR, GAS COOLED

18-09770 LONG JK + KELMAN LR + MCVEAN RL + NOVICK M + SHUCK AB + THALGOTT FW
SAFETY ANALYSIS OF THE OPERATION OF ZPR-3 WITH FUEL LOADINGS UP TO PLUTONIUM LOADINGS IN ZPR-III
ARGONNE NATIONAL LABORATORY, IDAHO
ANL-7049 +. 22 PAGES, 8 TABLES, 1 FIGURE, 16 REFERENCES, DECEMBER 1965, CFSTI, \$1.00 CY, \$0.50 MN

IN ANL-6504, THE MAXIMUM CREDIBLE ACCIDENT IS A FIRE INVOLVING 230 KG OF PLUTONIUM AND RESULTING IN THE RELEASE OF NEARLY A THOUSANDTH OF THAT INVENTORY FROM THE BUILDING. SEFOR EXPERIMENTS ARE NOW ANTICIPATED, TO INCREASE THE INVENTORY TO ABOUT 430 KG. THIS REPORT EVALUATES THE HAZARDS OF ZPR-3 OPERATION AS AFFECTED BY THIS INCREASED INVENTORY AND CONCLUDES THAT THE HAZARD IS INCREASED ROUGHLY IN PROPORTION TO THE INVENTORY BUT THAT THERE IS NO REASON TO EXPECT ANY INCREASED PROBABILITY THAT A RELEASE WILL OCCUR. THE TOXICITY OF THE INCREASED MAXIMUM CREDIBLE RELEASE IS STILL AT A LEVEL WITH WHICH EXISTING PROCEDURES OF EVACUATION, DECONTAMINATION, AND MONITORING CAN FUNCTION SUCCESSFULLY.

CRITICAL ASSEMBLY FACILITY + CRITICALITY EXPERIMENT + PLUTONIUM + REACTOR, FAST + SAFEGUARDS REPORT, GENERAL + ZPR III (ANL ZERO POWER REACTOR)

18-09789 630A MARK III MARITIME NUCLEAR STEAM GENERATOR SUMMARY REPORT
GENERAL ELECTRIC COMPANY, CINCINNATI
GEMP-340 +. 11 PAGES, 1 FIGURE, FEBRUARY 26, 1965, CFSTI, \$1.00 CY

BRIEF DESCRIPTION OF ADAPTATION OF ANP REACTOR TO NUCLEAR MERCHANT SHIP USE. BIBLIOGRAPHY OF REPORTS INCLUDED.

*REACTOR DESCRIPTION + *630 A (MARITIME REACTOR) + REACTOR, MARITIME

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-09816 URRUTIA RV
BONUS REQUESTS CHANGE IN HEAT RATING OF SUPERHEATER FUEL, SUPPLIES LIST OF INSTRUMENT NOT FAIL-SAFE
PUERTO RICO WATER RESOURCES AUTHORITY
1 PAGE, APRIL 20, 1966, DOCKET 115-4, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 44 (MAY 9, 1966)

DATA SUBMITTED TO ACRS LISTING ALL PLACES WHERE FAILURE OF A SINGLE COMPONENT CAN INHIBIT
SAFETY ACTION OR CONTAINMENT ISOLATION. BONUS REQUESTS SUPERHEATER HEAT RATING BE INCREASED
FROM 9 TO 12 KW/FT AT 50 MW(T). OTHERWISE, OPERATION WITH LOW FEEDWATER TEMPERATURE TO
OBTAIN LOW PROPER STEAM FLOW (TO OBTAIN REQUIRED 900 F SUPERHEATER OUTLET TEMPERATURE)
RESULTS IN LOSS OF ELECTRICAL GENERATION.

*SAFE FAILURE CRITERION + BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + HEAT TRANSFER +
OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

18-09817 ADDITIONAL INFORMATION REQUESTED ON HUMBOLDT BAY ZIRCONIUM-WATER REACTION ANALYSIS
DIVISION OF REACTOR LICENSING, USAEC
1 PAGE, APRIL 15, 1966, DOCKET 50-133, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 44 (MAY 9, 1966)

PLANS TO REFUEL WITH A HALF CORE OF ZIRCONIUM-CLAD ELEMENTS ARE APPROVED, BUT DRL REQUESTS
FURTHER ANALYSIS PRIOR TO FINAL QUARTER-CORE LOADING. DRL REQUESTS ANALYSIS (TO INCLUDE
CONTAINMENT PRESSURE) ASSUMING TERMINATION TEMPERATURE TO BE MELTING POINT OF THE OXIDE.

*METAL WATER REACTION + HUMBOLDT BAY + REACTOR, BOILING WATER + ZIRCONIUM

18-09819 ANDERSON AN
REVISION OF TECHNICAL SPECIFICATION LIMIT ON SHUTDOWN MARGIN
CONSOLIDATED EDISON COMPANY
1 PAGE, APRIL 20, 1966, DOCKET 50-3, ATOMIC ENERGY CLEARING HOUSE, 12(19), PP. 43 (MAY 9, 1966)

MINIMUM WORTH OF CONTROL RODS (0.10) WAS CHANGED FROM COLD-CLEAN TO HOT-CLEAN ZERO-POWER
CONDITION BECAUSE COLD SHUTDOWN IS ENSURED BY BORIC ACID SYSTEM. THE MINIMUM WORTH MEASURED
FOR CORE B HAD BEEN 0.086, COLD CLEAN.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *SHUTDOWN MARGIN + INDIAN POINT I + REACTOR, PRESSURIZED WATER

18-09831 BECKERS RM + DENKINS RF + GLEN HM + GOLSON TJ + KAHN JE + RENFRO GW + STEED JA
ENGINEERING DESIGN PRACTICES AT ORNL FOR FACILITIES CONTAINING RADIOACTIVE MATERIALS
OAK RIDGE NATIONAL LABORATORY
ORNL-TM-1459 +. 85 PAGES, 43 FIGURES, APRIL 1966, CFSTI, \$3.00 FS, \$0.75 MN

THIS REPORT IS A COMPILATION OF SEVEN PAPERS BY MEMBERS OF THE GENERAL ENGINEERING AND
CONSTRUCTION DIVISION OF OAK RIDGE NATIONAL LABORATORY AS PART OF THE APPLIED HEALTH PHYSICS
COURSE FOR STATE HEALTH DEPARTMENT PERSONNEL CONDUCTED BY THE OAK RIDGE INSTITUTE OF NUCLEAR
STUDIES IN SEPTEMBER AND OCTOBER OF 1965. THE INTENT OF THE PAPERS IS TO CALL ATTENTION TO
DESIGN PROBLEMS FOR LABORATORIES AND OTHER FACILITIES HANDLING RADIOACTIVE MATERIALS. THE
INFORMATION SHOULD BE HELPFUL IN GUIDING ENGINEERS IN DESIGNING OR SPECIFYING THE SPECIAL
TOOLS AND EQUIPMENT REQUIRED FOR HANDLING RADIOACTIVE MATERIALS.

*DESIGN CRITERIA + *GLOVE BOX + *HOT CELL + AIR CLEANING + CONTAINMENT STRUCTURE + CONTAINMENT, GENERAL +
DECONTAMINATION + ORNL (OAK RIDGE NATIONAL LABORATORY) + SHIELDING + WASTE HANDLING

18-09868 MARK H
DISMANTLING AND SHIPPING OF AGN-201 REACTOR, SERIAL NUMBER 112
UNIVERSITY OF CALIFORNIA, BERKELEY
2 PAGES, APRIL 26, 1966, DOCKET 50-84, PDR

PROCEDURES FOR DISMANTLING, STORING AND TRANSFERRING AGN-201 (SERIAL NO. 112) FROM UNIVERSITY
OF CALIFORNIA, BERKELEY, TO UNIVERSITY OF NEW MEXICO.

*AGN (TRAINING REACTOR, AEROJET-GEN. NUCLEONICS) + *REACTOR DECOMMISSIONING EXPERIENCE + *REACTOR, TRAINING

18-09869 LEVINE S
HAZARDS ANALYSIS BY THE DIVISION OF REACTOR LICENSING IN THE MATTER OF PHILADELPHIA ELECTRIC COMPANY,
PEACH BOTTOM ATOMIC POWER STATION, OPERATIONS UP TO ONE MEGAWATT THERMAL
DIVISION OF REACTOR LICENSING, USAEC
49 PAGES, NOVEMBER 18, 1964, DOCKET 50-171, PDR

ACRS AND DRL APPROVAL EXPRESSED FOR INITIAL STARTUP TESTING, BASED ON CONSIDERATION OF
FULL-POWER OPERATION. DRL CALCULATIONS CHECK MCA HEATING AND DOSES RESULTING FROM RELEASES.

*PEACH BOTTOM + *REVIEW + *SAFEGUARDS REPORT, GENERAL + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

18-09914 PERSIANI PJ + BUMP TR + KANN WJ
FARET CORE I FUEL IRRADIATION PROGRAM AND REFERENCE DESIGN
ARGONNE NATIONAL LABORATORY
ANL-7106 +. 22 PAGES, 5 FIGURES, 9 TABLES, 6 REFERENCES, OCTOBER, 1965, CFSTI, \$2.00 CY, \$0.50 MN

SELECTION OF NUMBER AND KIND OF FUEL ELEMENTS (OXIDE, CARBIDE, ALLOY) AND OPERATING CONDITIONS

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-09914 *CONTINUED*

WAS MADE TO BRACKET CONDITIONS IN PROTOTYPE CORE. THREE YEARS OF OPERATION WILL ALLOW UP TO 15 PERCENT ATOMIC BURNUP. VARIOUS ASSEMBLIES WOULD BE REMOVED DURING THAT TIME TO EVALUATE CONDITIONS.

*FUEL ELEMENT + *IRRADIATION TESTING + FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) + REACTOR, FAST + SYSTEM DESCRIPTION

18-09974 PRELIMINARY SAFETY ANALYSIS REPORT. TURKEY POINT NUCLEAR GENERATING UNITS NO. 3 AND NO. 4. SUPPLEMENT NO. 1

FLORIDA POWER AND LIGHT COMPANY

68 PAGES, FIGURES, TABLES, REFERENCES, DOCKET 50-250 AND DOCKET 50-251, MAY 12, 1966, PDR

ADDITIONAL INFORMATION ON PRESTRESSED CONCRETE CONTAINMENT VESSEL AND ON OCEANOGRAPHY. TIDAL CIRCULATION FLOW THROUGH BISCAYNE BAY MAJOR INLET MEASURED USING MEASURED FLOW THROUGH THREE MINOR INLETS AND TIDAL VOLUME CHANGE. STUDY CONTINUES. CONTAINMENT DESIGN CRITERIA PRESENTED. DESIGN PRESSURE IS 55 PSIG. ONE-FOURTH-INCH STEEL LINER USED TO MINIMIZE LEAKAGE. SEISMIC DESIGN WITH ASSUMED 0.05 G HORIZONTAL AND 0.033 G.

*CONCRETE, PRESTRESSED + *CONTAINMENT, HIGH PRESSURE + *OCEAN AND SEA + DESIGN CRITERIA + REACTOR, PRESSURIZED WATER + SAFEGUARDS REPORT, GENERAL + SEISMOLOGY + TURKEY POINT 3 + TURKEY POINT 4

18-10116 OKRENT D

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS REPORTS TO AEC ON PUERTO RICO FACILITY

U. S. ATOMIC ENERGY COMMISSION

AEC PRESS REL. J-134 +. 4 PAGES, MAY 24, 1966, DPI

ACRS REVIEWED PROBLEMS OF BONUS CONTROL RODS, ENGINEERED SAFEGUARDS AND SCRAM SYSTEM, AND RECOMMENDS A REVIEW BY INDEPENDENT EXPERTS TO IDENTIFY SAFETY PROBLEMS AND RECOMMEND IMPROVEMENTS. ACRS APPROVES PUERTO RICO WATER RESOURCES AUTHORITY AS SOLE OPERATOR OF THE PLANT.

*ADMINISTRATIVE CONTROLS AND PRACTICES + *BONUS (BOILING NUCLEAR SUPERHEAT PROJECT) + *STAFFING, TRAINING, QUALIFICATION + ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + OPERATING EXPERIENCE + REACTOR, BOILING WATER + REACTOR, SUPERHEAT

18-10123 QUARTERLY STATUS REPORT ON ADVANCED REACTOR TECHNOLOGY(ART) FOR PERIOD ENDING JULY 30, 1966

LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS, NEW MEXICO

LA-3582-MS +. 72 PAGES, 9 TABLES, 31 FIGURES, 18 REFERENCES, AUGUST 1966, CFSTI \$3.00 CY, \$0.75 MN

THE LOS ALAMOS MOLTEN PLUTONIUM PROGRAM HAS BEEN TERMINATED. SOME R AND D WILL BE DIVERTED TO THE LIQUID-METAL (COOLED) FAST-BREEDER PROGRAM. OMEGA WEST REACTOR. PLUTONIUM CAPSULES SHOW AN 0.08 INCH DECREASE IN HEIGHT AFTER 2 DAYS OUT OF THE FLUX. UHTREX REFLECTOR IS COMPLETE, ACCIDENTS ARE BEING STUDIED FOR SAFETY ANALYSIS REPORT, AND A SECOND CORE LOADING WAS EXTRUDED.

*REACTOR, FAST BREEDER + *UHTREX (ULTRA HIGH TEMP. REACTOR EXPERIMENT) + LASL (LOS ALAMOS SCIENTIFIC LABORATORY) + PLUTONIUM + REACTOR, GAS COOLED

18-10133 FAST NEUTRONS. REPORT OF ACTIVITIES OF 2ND QUARTER 1965

COMMISSARIAT A L ENERGIE ATOMIQUE, CADARACHE, FRANCE. CENTRE D ETUDES NUCLEAIRES

ORNL-TR-900 +. 106 PAGES, 1965, JCL, \$9.10 FS, \$3.38 MF

RAPSODIE CONTROL-ROD-MECHANISM AND SAFETY REPORT, SODIUM-WATER REACTION IN EVAPORATOR. HARMONIE SAFETY REPORT, DOPPLER EFFECT AND PULSED OR MODULATED EXPERIMENTS. PIRANA TESTS, IN PARTICULAR, EXPLOSION IN SODIUM AND WATER, MELTING OF IRRADIATED URANIUM IN SODIUM. (NOT MUCH DATA).

*DOPPLER EFFECT + *FRANCE + *REACTOR, FAST + CONTROL ROD SCRAM MECHANISM + FUEL MELTDOWN + METAL WATER REACTION + REACTOR, PULSED + SAFEGUARDS REPORT, GENERAL + SODIUM + URANIUM

18-10152 PFR RESULT - SCOTLAND 2, ENGLAND D

2 PAGES, 1 FIGURE, NUCLEAR ENGINEERING, 11(118), PP. 182-183 (MARCH 1966)

THE NEW UNITED KINGDOM 250-MWE PROTOTYPE FAST REACTOR WILL BE BUILT AT THE DOUNREAY SITE IN SCOTLAND. SAFETY AND STABILITY ARE VESTED IN INTEGRAL DESIGN AND THE THERMAL CAPACITY OF A 300,000-GAL SODIUM TANK. FLOW THROUGH THE CORE IS UPWARDS, AND THE ENTIRE PRIMARY CIRCUIT IS IMMERSSED IN THE REACTOR VESSEL, INCLUDING IMPELLER PUMPS AND VALVES, WITH DRIVES MOUNTED ABOVE THE TOP SHIELD. THE FUEL IS CURRENTLY THOUGHT OF AS PLUTONIUM/NATURAL URANIUM OXIDE CLAD IN 316 TYPE STAINLESS STEEL PINS ARRANGED IN HEXAGONAL BUNDLES.

*DESIGN STUDY + *DOUNREAY (UK) + *REACTOR, FAST + *UNITED KINGDOM

18-10164 PON GA

CANDU-BLW-250 PROGRESS REPORT

ATOMIC ENERGY OF CANADA LIMITED, TORONTO, ONTARIO

AECL-2554 + 66-CNA-302 +. 12 PAGES, 1 TABLES, 3 FIGURES, PRESENTED AT THE INTERNATIONAL CONFERENCE AND EXHIBITION OF THE CANADIAN NUCLEAR ASSOCIATION, WINNIPEG, MAY 30-JUNE 1, 1966, AECL \$0.50 CY

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10164 *CONTINUED*

DESCRIPTION OF A 250-MW(E) HEAVY-WATER-MODERATED AND A BOILING-LIGHT-WATER-COOLED REACTOR. -
MAIN MECHANICAL DIFFERENCES FROM DOUGLAS POINT AND PICKERING WILL BE VERTICAL PRESSURE TUBES
AND SINGLE-END REFUELING. SCHEDULES GIVEN.

*REACTOR DESCRIPTION + CANADA + REACTOR, BOILING WATER + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

18-10173 ISO Y + SAKAKURA A

DESIGN AND EQUIPMENT OF THE JAERI POST IRRADIATION EXAMINATION FACILITY

JAPAN ATOMIC ENERGY RESEARCH INSTITUTE

12 PAGES, 14 FIGURES, NUCLEAR ENGINEERING AND DESIGN, 3(1), PP. 105-116 (JANUARY 1966)

THE HOT CELL OPERATIONAL SINCE 1958 WAS EXTENDED IN 1965 BY A SINGLE 35-METER CAVE WITH SHIELD
DOORS TO SEPARATE IT INTO STORAGE, MAINTENANCE, CLEAN AND DIRTY WORKING AREAS. THE DOORS AND
MATERIAL CONVEYOR MECHANISMS ARE DESCRIBED.

*DESIGN STUDY + *HOT CELL + JAPAN

18-10205 CVTR CHANGE 11 - INCREASED PRESSURIZER LIQUID CONTENT AT POWER

CAROLINAS VIRGINIA NUCLEAR POWER ASSOCIATES, INC., PARR, SOUTH CAROLINA

2 PAGES, OCTOBER 4, 1966, DOCKET NO. 50-144, PDR

CVTR ALLOWED LIQUID VOLUME INCREASE FROM 40 TO 46 CUBIC FT TO ALLOW MORE MARGIN FROM WATER
SHRINKAGE DURING OPERATIVE CHANGES WHICH COULD BARE THE HEATERS. PREVIOUS ANALYSIS (CVNA-47)
SHOWED THE VAPOR VOLUME TO BE ACCEPTABLE AND THAT IT WILL NOT BE FILLED BY WATER IN
REACTIVITY OR LOAD TRANSIENTS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *SAFETY EVALUATION + CVTR (CAROLINAS VIRGINIA TUBE REACTOR) +
PRESSURIZER + REACTOR, HEAVY WATER + REACTOR, PRESSURE TUBE

18-10257 FULLAM HT

A CRITICALLY SAFE FLAT BED CONTACTOR FOR PROCESSING SOLID FISSILE MATERIALS

HANFORD ATOMIC PRODUCTS OPERATION

RL-SA-52 + CONF-651010-2 +. 12 PAGES, ELECTROCHEMICAL SOCIETY 6TH REGIONAL AIChE MEETING, UNION,
WASHINGTON, CFSTI, \$1.00 CY, \$0.50 MN

A FLAT-BED REACTOR WAS DEVELOPED FOR PROCESSING SOLID FISSILE MATERIALS WHICH IS (1)
CRITICALLY SAFE BY GEOMETRICAL DESIGN, (2) MECHANICALLY SIMPLE, (3) VERSATILE, (4) CAPABLE OF
EFFICIENT HANDLING OF A WIDE RANGE OF PARTICLE SIZES AND GAS FLOWS. THE BODY OF THE
CONTACTOR CONSISTS OF A HOLLOW CYLINDRICAL SLAB DIVIDED BY A POROUS PLATE INTO AN UPPER AND
LOWER SECTION. THE SOLIDS TO BE REACTED ENTER THE UPPER SECTION OF THE REACTOR AT THE
PERIPHERY AND ARE MOVED TO THE CENTER BY A RABBLE ARM. THE POROUS PLATE SERVES AS THE BED
SUPPORT FOR THE SOLIDS. THE REACTING GAS IS PREHEATED AS IT ENTERS THE LOWER SECTION OF THE
REACTOR, THEN PASSES UP THROUGH THE POROUS PLATE AND THROUGH THE BED OF SLOWLY MOVING SOLIDS.
THE GASEOUS PRODUCTS LEAVE THE CONTACTOR THROUGH A VENT LINE IN THE COVER PLATE.

*CRITICALITY SAFETY + *RADIOCHEMICAL PLANT SAFETY + *RADIOCHEMICAL PROCESSING + CHEMICAL REACTION +
DESIGN CRITERIA + DESIGN STUDY

18-10270 ARNETT LM + ROSS CP + RUSCHE BC + TAYLOR CD

FINAL SAFETY ANALYSIS OF THE MAXIMUM CREDIBLE ACCIDENT IN THE HEAVY WATER COMPONENTS TEST REACTOR
SAVANNAH RIVER LABORATORY, DUPONT

DP-1037 +. 30 PAGES, 4 FIGURES, 7 TABLES, REFERENCES, DECEMBER 1965, CFSTI \$2.00 CY, \$0.50 MN

THE MAXIMUM CREDIBLE ACCIDENT IN THE HWCTR IS ANALYZED FOR THE CONDITIONS THAT EXIST SINCE
IODINE ABSORBERS WERE INSTALLED IN THE CONTAINMENT BUILDING. THE ABSORBERS REMOVE
RADIOIODINE ISOTOPES TO THE EXTENT THAT THE THYROID AND WHOLE-BODY DOSES AT THE SAVANNAH
RIVER PLANT BOUNDARY WOULD BE LESS BY FACTORS OF SIX AND TWENTY-FIVE, RESPECTIVELY, THAN THE
ALLOWABLE LIMITS SET FORTH IN THE CODE OF FEDERAL REGULATIONS (10-CFR 100).

*ACCIDENT, MAXIMUM CREDIBLE (MCA) + *HWCTR (HEAVY WATER COMPONENT TEST REACTOR) + FILTER + IODINE +
SAFEGUARDS REPORT, GENERAL

18-10340 DUNGENESS B AGR NUCLEAR POWER STATION

CENTRAL ELECTRICITY GENERATING BOARD

12 PAGES, FIGURES, JULY 1965, SOURCE

THE UK AGR AT DUNGENESS B WILL HAVE A NET OUTPUT OF 1200 MW(E). THE
COMPLETE REACTOR, INCLUDING CORE, GAS CIRCULATORS AND BOILERS,
IS HOUSED WITHIN A CONCRETE PRESSURE VESSEL. AN INNER PRESSURE CY-
LINDER IN THE FORM OF A BELL SEPARATES THE CORE FROM THE BOILERS.
THE INTERNAL WALLS OF THE CONCRETE PRESSURE VESSEL ARE CLAD WITH
STAINLESS STEEL THERMAL INSULATION. THE BOILERS ARE OF THE ONCE-T-
HROUGH TYPE WITH A SINGLE REHEATER STAGE. THE TUBE ENDS ARE LED O-
UT IN SUCH A WAY THAT ACCESS IS AVAILABLE FOR PLUGGING OR OTHER PU-
RPOSES WITHOUT ENTRY INTO THE PRESSURE VESSEL. THE URANIUM DIOXID-
E FUEL IS CONTAINED IN STAINLESS-STEEL CANS, ARRANGED IN THREE-RIN-
G CLUSTERS OF 36 PINS WITHIN GRAPHITE SLEEVES, TO FORM 40-INCH-LON-
G FUEL ELEMENTS. THE MEAN FUEL RATING IS SOME THREE TIMES GREATER
THAN FOR THE MAGNOX SYSTEM.

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10340 *CONTINUED*
*DUNGENESS B (UK) + *REACTOR DESCRIPTION + AGR (ADVANCED GASCOOLED REACTOR, WINDSCALE, UK) +
REACTOR SAFETY SYSTEM + REACTOR, GAS COOLED + UNITED KINGDOM

18-10404 ANDREWS JS
THE WINDSCALE ADVANCED GAS-COOLED REACTOR
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, RISLEY
8 PAGES, 6 TABLES, ENERGIE NUCLEAIRE, 7(7), PP. 410-417 (NOVEMBER 1965)

THIS ARTICLE DISCUSSES THE DESIGN OF THE WINDSCALE AGR AND ITS AUXILIARY EQUIPMENT AND GIVES AN ACCOUNT OF THE COMMISSIONING OF THE REACTOR AND OF ITS OPERATION OVER TWO-AND-A-HALF YEARS TO THE AUTUMN OF 1965. IT OUTLINES THE EXPERIMENTAL WORK CARRIED OUT, WITH SPECIAL REFERENCE TO THE SATISFACTORY BEHAVIOR OF THE FUEL. FINALLY AN INDICATION IS GIVEN OF POSSIBLE FUTURE DEVELOPMENTS IN GAS-COOLED-REACTOR TECHNOLOGY ARISING FROM THIS WORK.

*AGR (ADVANCED GASCOOLED REACTOR, WINDSCALE, UK) + DESIGN STUDY + OPERATING EXPERIENCE +
REACTOR, GAS COOLED + UNITED KINGDOM

18-10454 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 7 PAGES, 2 FIGURES, 1 TABLE, JUNE 1966, DOCKET 115-5, PP. II-5-1 THROUGH II-5-7, AMENDMENT NO. 25, PDR

QUESTION II-5. DISCUSSION OF THE LIMITING HEAT FLUX OF 109 BTU/SEC-FT SQ SHOWS THAT TWO DESIGN CRITERIA WERE USED TO DETERMINE LOWER LIMITS OF CIRCULATING FLOW - (1) BURNOUT RATIO 1.5, (2) STEAM-VOLUME FRACTION LESS THAN 0.7. FOUR STANDARD POWER LEVELS WERE EVALUATED AT VARIOUS REACTOR LIFETIMES AND ROD POSITIONS TO DETERMINE THE LIMITING FLOWS. WORST CASE WAS INITIAL STARTUP, AS ZIRCALOY SHROUDS DO NOT RAISE PEAK-TO-AVERAGE POWER TO INITIAL CONDITIONS.

*BURNOUT HEAT FLUX + *LACROSSE BOILING WATER REACTOR + *POWER DISTRIBUTION +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FLOW, TWO PHASE + FUEL BURNUP + REACTOR, BOILING WATER

18-10456 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 3 PAGES, 1 FIGURE, JUNE 1966, DOCKET 115-5, PP. V-3-1 THROUGH V-3-3, AMENDMENT NO. 25, PDR

QUESTION V-3. VARIOUS REDUNDANT VALVES ARE BEING ADDED TO THE BORON-INJECTION CORE-SPRAY SYSTEM TO MEET AEC SPECIFICATIONS FOR REDUNDANCY. ONE SET OF VALVES WILL BE NITROGEN-OPERATED AND THE OTHER AIR-OPERATED.

*LACROSSE BOILING WATER REACTOR + *REDUNDANCE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
*SHUTDOWN SYSTEM, SECONDARY + *VALVE + REACTOR, BOILING WATER

18-10457 NICKEL HC
ANSWERS TO QUESTIONS ABOUT LACBWR RECEIVED FROM THE DIVISION OF REACTOR LICENSING
ALLIS-CHALMERS
ACNP-66546 +. 2 PAGES, DOCKET 115-5, JUNE 1966, PP. V-11-1 THROUGH V-11-2, AMENDMENT NO. 25, PDR

QUESTION V-11. DISCUSSES SUPPLYING VITAL BUS FROM RESERVE AUXILIARY TRANSFORMER FOLLOWING TURBINE GENERATOR LOSS, USING AN AUTO TRANSFER SWITCH. SUGGESTS ALTERNATE SPLITTING OF LOADS IF DRL DESIRES ESSENTIAL BUS ALWAYS BE FED FROM RESERVE AUXILIARY TRANSFORMER, BUT PREFERENCES REDUNDANCY AND SWITCHOVER.

*ELECTRIC POWER, VITAL + *INSTRUMENTATION, SWITCH + *LACROSSE BOILING WATER REACTOR +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + LOSS OF POWER + REACTOR, BOILING WATER

18-10475 COATES RL + HORTON NR
RSAC--A RADIOLOGICAL SAFETY ANALYSIS COMPUTER PROGRAM
PHILLIPS PETROLEUM COMPANY, IDAHO
IDO-17151 +. 208 PAGES, 3 TABLES, 7 REFERENCES, MAY 1966, CFSTI, \$6.00 CY, \$1.25 MN

AN IBM 7040 PROGRAM WHICH COMPUTES THE POTENTIAL RADIOLOGICAL DOSES RESULTING FROM A CONTINUOUS OR INSTANTANEOUS RELEASE OF FISSION PRODUCTS TO THE ATMOSPHERE. DEVELOPED AS PART OF LOFT AND GENERAL NUCLEAR SAFETY PROGRAMS TO PROVIDE A GENERALIZED COMPUTER PROGRAM FOR A COMPLETE PARAMETRIC INVESTIGATION OF RADIOLOGICAL HAZARDS. DOSES CONSIDERED ARE CLOUD GAMMA, DEPOSITION GAMMA, INGESTION, AND INHALATION, AND ARE BASED UPON THE RELEASE OF UP TO 200 ISOTOPES, THE RELATIVE ABUNDANCE OF EACH ISOTOPE BEING DEPENDENT UPON THE OPERATING HISTORY OF THE NUCLEAR REACTOR UNDER CONSIDERATION. INCLUDED ARE THE MATHEMATICAL MODELS, CONVERSION FACTORS, ASSUMPTIONS, FLOW CHARTS, PROGRAM LISTINGS, AND OTHER DATA PERTINENT TO THE OVERALL DEVELOPMENT OF THIS PROGRAM.

*COMPUTER PROGRAM + *DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL +
*FISSION PRODUCT RELEASE, GENERAL + SUTTON DIFFUSION FORMULA

18-10832 COE RJ
AMENDMENT NO. 51 TO LICENSE APPLICATION DATED JUNE 29, 1956

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10832 *CONTINUED*
YANKEE ATOMIC ELECTRIC COMPANY
30 PAGES, FIGURES, JANUARY 28, 1966, DOCKET 50-29, PDR

YANKEE AMENDMENT 51 SUMMARIZES 11 APPROVED CHANGES, INCLUDING REPAIR OF PRESSURIZER SOLENOID RELIEF VALVE, RELOCATION OF SAFETY INJECTION TANK LEVEL SENSOR, PH CONTROL BY AMMONIA WITH BORON IN WATER, CAPACITY CHANGE OF LETDOWN ORIFICES, SAFETY INJECTION LIQUID HEATING AND PURIFICATION-LOOP OPERATION WITH TWO PROTOTYPE STAINLESS CLAD SILVER-INDIUM-CADMIUM CONTROL RODS, NEW PIPING IN LOW-PRESSURE SURGE-TANK SYSTEM, NEW SECONDARY CORE SUPPORTS ON THERMAL SHIELD, REMOVAL OF ONE SOURCE, REINFORCEMENT OF THERMAL SHIELD, AND FILTER FOR EVAPORATOR BOTTOMS.

*MODIFICATION, SYSTEM OR EQUIPMENT + *OPERATING LIMITS/TECHNICAL SPECIFICATIONS +
REACTOR, PRESSURIZED WATER + YANKEE

18-10900 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
13 PAGES, 4 FIGURES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING
UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 5 IS REALLY FIVE QUESTIONS ABOUT OPERATION WITH MAXIMUM SPECIFIC POWER HIGHER THAN THAT OF ANY CURRENTLY LICENSED REACTOR (A) PEAK HEAT-FLUX FACTORS IN VARIOUS CONDITIONS, (B) PERCENTAGE OF FUEL RODS AT VARIOUS POWERS, REACTOR AT 100 PERCENT POWER, (C) SAME AS B, INCLUDING INSTRUMENT ERROR, (D) REPEAT OF B AND C, REACTOR AT 112 PERCENT POWER, (E) AT 125 PERCENT POWER, 37 FUEL RODS MIGHT REACH DNB, (F) DNB RATIO, FUEL CENTERLINE TEMPERATURE, AND EXIT QUALITY GIVEN FOR VARIOUS DEGREES OF OVERPOWER WITH HOT-CHANNEL FACTORS RAISED 10 PERCENT, (G) STATISTICAL VARIANCES OF ENGINEERING HOT-CHANNEL FACTORS GIVEN.

*CENTERLINE MELTING + *DNB (DEPARTURE FROM NUCLEATE BOILING) + *HOT SPOT +
*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10901 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
13 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 6 DESCRIBES CONTAINMENT-AIR FILTERING SYSTEM AND EFFECTIVENESS. CHARCOAL TEMPERATURE MONITORED AND HAS A WATER-DOUSING SYSTEM. COMBUSTION OF ONE COMPLETE CHARCOAL BED WOULD INCREASE THE 45-PSIG MCA PEAK PRESSURE TO 60.

*CONTAINMENT FILTERING SYSTEM + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CHARCOAL + FIRE +
INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10902 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY
7 PAGES, 1 FIGURE, OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING
UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 7 DESCRIBES FUNCTIONING OF CONTAINMENT-PENETRATION PRESSURIZATION SYSTEM UNDER ACCIDENT CONDITIONS.

*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CONTAINMENT LEAKAGE CONTROL + INDIAN POINT II +
REACTOR, PRESSURIZED WATER

18-10903 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 8 DISCUSSES MODEL (AND EXPERIMENTS) FOR REMOVING IODINE BY A SODIUM THIOSULPHATE CONTAINMENT-SPRAY SYSTEM.

*CONTAINMENT SPRAY + *FISSION PRODUCT, IODINE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + PRESSURE, INTERNAL + REACTOR, PRESSURIZED WATER

18-10904 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
9 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 9 CONCLUDES THAT ONLY CERTAIN PORTIONS OF THE SAFETY INJECTION SYSTEM HANDLE LARGE PORTIONS OF POST-MCA WATER, THAT MAXIMUM LEAKAGE OUTSIDE CONTAINMENT IS 88 CC/HR FROM THIS SYSTEM, AND THAT IODINE DOSE (24 HR IS 0.24 REM) FROM THIS IS WELL WITHIN 10-CFR-100.

*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + AIRBORNE RELEASE + DOSE + INDIAN POINT II +
REACTOR, PRESSURIZED WATER

18-10905 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

ACCESSION NUMBER 18-10832 TO 18-10905

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10905 *CONTINUED*

CONSOLIDATED EDISON COMPANY OF NEW YORK

4 PAGES, 1 FIGURE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 10. ON LOSS OF POWER, 3 HALF-CAPACITY DIESELS WILL START. ON COMING TO SPEED, REQUIREMENT FOR SAFEGUARD SYSTEM OPERATION WILL CLOSE BREAKERS CONNECTING DIESELS TO FOUR 480-V BUSES, STARTING EQUIPMENT ON THAT BUS. TYPICAL EXPERIMENT - CONTAINMENT VENT FANS (5), SAFETY INJECTION PUMPS (3), SERVICE WATER PUMPS (3), CONTAINMENT SPRAY PUMPS (2), RESIDUAL-HEAT-REMOVAL PUMPS (2), AND TWO MOTOR-CONTROL CENTERS FOR VALVES.

*EMERGENCY POWER, ELECTRIC + *ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10906 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONSOLIDATED EDISON COMPANY OF NEW YORK

6 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 11 ASKS FOR DETAILS OF STARTUP STEAM-LINE RUPTURE, REFUELING, AND CONTROL-ROD-EJECTION ACCIDENTS. ANSWER DESCRIBES GENERALIZED COURSE OF ONOFRE RESULTS AS NOT SIGNIFICANTLY DIFFERENT FOR ROD EJECTION.

*ACCIDENT, CONTROL ROD EJECTION + *ACCIDENT, CONTROL ROD WITHDRAWAL + *ACCIDENT, REFUELING + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *STEAM LINE RUPTURE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10907 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONSOLIDATED EDISON COMPANY OF NEW YORK

2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 12. BORATED SAFETY-INJECTION WATER WILL BE DILUTED BY SPILLED COOLANT, BUT SIMULTANEOUS DILUTION BY SPILLED SECONDARY WATER IS CONSIDERED INCREDIBLE BECAUSE OF PRECAUTIONS TAKEN. THIS DILUTION TAKES PLACE ONLY DURING THE RECIRCULATION OF CONTAINMENT SUMP WATER AND LASTS ONLY 10 MIN. EVEN THEN, RESIDUAL CORE HEAT PROVIDES ENOUGH STEAM VOID TO SHUT DOWN THE CORE AND KEEP SUBCRITICAL, REGARDLESS OF CONTROL RODS OR FISSION PRODUCT POISONING. IN ANY CASE, POWER GENERATION WOULD BE RESTRICTED TO 4 PERCENT - THE RESIDUAL HEAT-EXCHANGER CAPACITY.

*DILUTION + *POISON, SOLUBLE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SAFETY INJECTION + INDIAN POINT II + REACTOR, PRESSURIZED WATER + SHUTDOWN MARGIN

18-10908 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONSOLIDATED EDISON COMPANY OF NEW YORK

2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 13 -- DESCRIBES WATER SUPPLY AND PUMPING TO STEAM GENERATOR UPON A COMPLETE LOSS OF POWER. STORAGE FOR 24 HR AT LEAST WILL BE MAINTAINED IN THE CONDENSATE STORAGE TANK, WITH CONNECTIONS TO MAKEUP OR CITY-WATER STORAGE. BACKUP CAN BE POWERED FROM DIESELS. AN EMERGENCY, TURBINE-DRIVEN FEED PUMP IS PROVIDED (STARTED ON LOSS OF FLOW) AND SIZED SO THE TUBES WILL NOT BE UNCOVERED. STEAM FROM THE STEAM GENERATOR RUNS TURBINE.

*DECAY HEAT + *EMERGENCY POWER, NONELECTRIC + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + LOSS OF POWER + REACTOR, PRESSURIZED WATER

18-10909 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONSOLIDATED EDISON COMPANY OF NEW YORK

1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14A - INSTRUMENTATION SYSTEM -- STEAM-GENERATOR WATER-LEVEL INSTRUMENTATION IS REDUNDANT. THERE ARE TWO LEVEL TRANSMITTERS FOR EACH OF FOUR STEAM GENERATORS. LOW AND LOW-LOW LEVEL ALARMS, FEED WATER FLOW VS STEAM FLOW MISMATCH IS ALARMED, AND REACTOR IS TRIPPED IF ANY SG HAS LOW WATER LEVEL (1 OF 2) IN COINCIDENCE WITH WATER-STEAM FLOW MISMATCH.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + *REDUNDANCE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER + STEAM

18-10910 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

CONSOLIDATED EDISON COMPANY OF NEW YORK

1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14B -- INSTRUMENTATION SYSTEM -- THE EFFECT OF HYDRAULIC FORCES ON ROD-CLUSTER INSERTION TIME DURING A LOSS OF COOLANT ACCIDENT WILL BE CONSIDERED IN CALCULATING ENERGY RELEASES.

*CONTROL ROD + *HYDRODYNAMIC ANALYSIS + *LOSS OF COOLANT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +

ACCESSION NUMBER 18-10905 TO 18-10910

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10910 *CONTINUED*
ENERGY SOURCE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10911 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14C - INSTRUMENTATION SYSTEM -- MANUAL ISOLATION VALVES MAY BE CHECKED AT THEIR
LOCATION FOLLOWING THE HYPOTHETICAL ACCIDENT. REMOTELY CONTROLLED VALVES WILL HAVE INDICATOR
LIGHTS IN THE MAIN CONTROL ROOM.

*CONTAINMENT PENETRATION, CLOSURE OF + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II +
INSTRUMENTATION, GENERAL + REACTOR, PRESSURIZED WATER

18-10912 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH
31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14D - INSTRUMENTATION SYSTEM -- THE THREE PRESSURIZER-LEVEL SENSORS WILL EACH HAVE A
SEPARATE TAP TO ENSURE INDEPENDENCE IN CASE OF A RUPTURED IAP.

*INSTRUMENTATION, LIQUID LEVEL DETECTION + *PRESSURIZER + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
INDIAN POINT II + INSTRUMENTATION, INDEPENDENT + REACTOR, PRESSURIZED WATER

18-10913 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14E - INSTRUMENTATION SYSTEMS -- POST MCA REACTIVITY STATUS AND CONTAINMENT CONDITION
INSTRUMENTATION. THREE CONTAINMENT-PRESSURE INDICATORS ARE THE MAIN INDICATIONS OF THE
CONTAINMENT TEMPERATURE AND THE EFFECTIVENESS OF THE CONTAINMENT COOLING SYSTEMS. OTHER
INDICATIONS MUST BE CONSIDERED AS BONUS READINGS. THERE IS NO SPECIFIC INDICATION THAT EACH
SAFEGUARD SYSTEM IS ACTING AS DESIGNED. HOWEVER, VARIOUS INDICATORS ARE LISTED (EG. PUMP
DISCHARGE PRESSURE, VALVE POSITION, SUPPLY-WATER LEVEL).

*CONTAINMENT INSTRUMENTATION + *INSTRUMENTATION, GENERAL + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
CONTROL ROD, SHIM SAFETY + ENGINEERED SAFEGUARD + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10914 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 14F - INSTRUMENTATION SYSTEM -- EXPERIENCE AT YANKEE, INDIAN POINT I, AND CVTR SHOWS
THAT THE BEST EXTERNAL DETECTORS OF AVERAGE CORE POWER AND OF FLUX TILTS IS A SET OF FOUR
LONG ION CHAMBERS (LENGTH EQUAL TO CORE HEIGHT) LOCATED SYMMETRICALLY. EACH CHAMBER HAS TWO
SECTIONS OF EQUAL LENGTH, ONE SECTION COMPENSATED AND THE OTHER UNCOMPENSATED. THE TOTAL
CURRENT IS USED IN AVERAGE POWER CIRCUITS, AND THE INDIVIDUAL CURRENTS ARE COMPARED TO DETECT
FLUX TILTS.

*FLUX TILT + *INSTRUMENTATION, NUCLEAR + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II +
OPERATING EXPERIENCE + REACTOR, PRESSURIZED WATER

18-10915 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 15 DISCUSSES THE UPRIVER TRANSPORT 22 MILES TO NEW YORK CITY WATER INTAKE AT CHELSEA,
DUE TO TIDAL BACKFLOW AND TO THE SALT-WATER GRADIENT. SEVERAL TIDAL CYCLES ARE NECESSARY TO
MOVE THE WATER UPRIVER, AND ACCORDING TO MEASURED DISPERSION COEFFICIENTS, WITH MINIMUM
DOWNFLOW, A CONTINUOUS RELEASE OF 550 CURIES/DAY OF CS-137 OR 87 CURIES/DAY OF I-131 WOULD
GIVE MPC AT THE INTAKE. INDIAN POINT I EXPERIENCE IS THAT ALL DISCHARGES ARE BELOW
DRINKING-WATER MPC. AN INSTANTANEOUS RELEASE OF 5750 CURIES OF I-131 WOULD NEED BE RELEASED
FOR THE PEAK CONCENTRATION AT CHELSEA TO REACH DRINKING-WATER MPC.

*HYDRAULIC ANALYSIS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE DISPOSAL, RIVER +
DIFFUSION COEFFICIENT + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10916 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2
CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2,
MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 16 JUSTIFIES THE INVERSION FREQUENCY ASSUMED FOR THE 30-DAY FORECAST, BASED ON JOINT

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10916 *CONTINUED*

ASSUMPTION OF 42-4 PERCENT INVERSION CONDITIONS PLUS PREVAILING WIND (35 PERCENT) IN A NARROW (20 DEG) SECTOR. A DETAILED STUDY SHOWED THAT THE WORST CONDITIONS WERE ASSOCIATED WITH NIGHTTIME DOWN-VALLEY FLOW, MOST FREQUENT DURING SEPTEMBER AND OCTOBER. FURTHER STUDY SHOWED THAT THE ASSUMED 30-DAY ACCIDENT ANALYSIS WAS REALISTIC IF THE ACCIDENT COINCIDED WITH A SEQUENCE OF WEATHER CONDITIONS CONSIDERED MOST UNFAVORABLE.

*FREQUENCY SPECTRA + *LAPSE RATE, STABLE + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER + WIND STATISTICS

18-10917 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 17 -- ALL EQUIPMENT ASSOCIATED WITH NUCLEAR SAFETY IS COMPLETELY SEPARATE FROM UNIT 1. AN MCA DOSE (INFINITE AND 8-HR, THYROID AND WHOLE BODY) RECEIVED IN THE CONTROL ROOM OF THE OTHER UNIT IS LESS THAN 3 REMS. VARIOUS CONSERVATIVE ASSUMPTIONS WERE MADE.

*ACCIDENT, MAXIMUM CREDIBLE (MCA) + *DOSE CALCULATION, EXTERNAL + *DOSE CALCULATION, INTERNAL + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + BUILDING + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10918 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 18 -- PRESSURE FLOW CHARACTERISTICS OF THE CENTRIFUGAL SAFETY INJECTION PUMPS (400 GPM AT A 2500-FT HEAD) AND THE POSITIVE DISPLACEMENT CHARGING PUMPS (125 GPM AT 2500 PSI) ARE GIVEN.

*SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SAFETY INJECTION + *SAFETY INJECTION + FLOW, HIGH SPEED + FLOW, HIGH SPEED + INDIAN POINT II + INDIAN POINT II + PRESSURE, INTERNAL + PRESSURE, INTERNAL + REACTOR, PRESSURIZED WATER + REACTOR, PRESSURIZED WATER
FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 18 -- PRESSURE FLOW CHARACTERISTICS OF THE CENTRIFUGAL SAFETY INJECTION PUMPS (400 GPM AT A 2500-FT HEAD) AND THE POSITIVE DISPLACEMENT CHARGING PUMPS (125 GPM AT 2500 PSI) ARE GIVEN.

18-10919 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19A - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- MISSILE PROTECTION SHALL BE PROVIDED FOR CONTAINMENT LINER AND ENGINEERED SAFEGUARDS. VARIOUS DESIGN CONSIDERATIONS AND TYPES OF MISSILES ARE DESCRIBED.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *CONTAINMENT, MISSILE GENERATION AND PROTECTION + ENGINEERED SAFEGUARD + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10920 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19B - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STEAM GENERATION WILL BE SUPPORTED TO PREVENT SECONDARY-SYSTEM DAMAGE FROM PRIMARY-PIPING RUPTURE. AUXILIARY PIPING WILL NOT BE SPECIALLY SUPPORTED. REACTOR VESSEL, MAIN COOLANT PIPING, AND SAFETY INJECTION PIPING WILL BE BRACED TO PREVENT CONTAINMENT DAMAGE AT THE CONTAINMENT PENETRATION FOLLOWING A REACTOR COOLANT-PIPE BREAK.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SUPPORT STRUCTURE + FAILURE, PIPE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10921 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19C - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STEAM GENERATORS WILL BE PROTECTED AGAINST INCONEL TUBE OR TUBE-SHEET RUPTURE FOLLOWING PRIMARY OR SECONDARY LINE BREAK, BY ASSUMING THAT FULL PRESSURE DIFFERENTIAL IS APPLIED AND BY LIMITING STRESS TO 90 PERCENT OF YIELD STRESS.

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-10921 *CONTINUED*

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FAILURE, PIPE + HEAT EXCHANGER + INDIAN POINT II + REACTOR, PRESSURIZED WATER + STRESS ANALYSIS + SUPPORT STRUCTURE

18-10922 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
3 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19D - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- PRIMARY AND SECONDARY COOLANT ALLOWABLE FISSION PRODUCT CONTENT WERE CALCULATED (BASED ON RELEASE OF EITHER COOLANT IN A MINOR ACCIDENT) TO BE MUCH HIGHER THAN EXPECTED IN NORMAL OPERATION.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + DOSE CALCULATION, EXTERNAL + INDIAN POINT II + REACTOR, PRESSURIZED WATER + STEAM LINE RUPTURE

18-10923 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
4 PAGES, 1 FIGURE, 2 TABLES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS, INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19E - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- CONTAINS A LIST OF 58 CONTAINMENT PENETRATIONS AND TYPES OF CLOSURES.

*CONTAINMENT PENETRATION, CLOSURE OF + *DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10924 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
2 PAGES OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19F - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- WASTE-GAS DECAY TANKS VOLUME IS PROVIDED TO STORE GASES EVOLVED DURING A SHUTDOWN. STORAGE FOR 45 DAYS. MAXIMUM QUANTITY EXPECTED IN ANY ONE TANK IS 13,500 CURIES OF XE-133, WHICH IF RELEASED WOULD GIVE 0.5 REM EXPOSURE AT SITE BOUNDARY DURING CLOUD PASSAGE.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE STORAGE + DOSE CALCULATION, EXTERNAL + FISSION GAS RELEASE + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-10925 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19G - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- THREE LIQUID-WASTE TANKS ARE PROVIDED, EACH WILL HOLD 2/3 OF THE PRIMARY COOLANT. TANK PIT WILL HOLD CONTENTS OF ONE TANK WITHOUT SPILLOVER. NORMAL DISCHARGE WILL BE THROUGH THE LIQUID PROCESSING TRAIN.

*DESIGN CRITERIA + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *WASTE STORAGE + INDIAN POINT II + REACTOR, PRESSURIZED WATER + WASTE TREATMENT, LIQUID

18-10926 FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 CONSOLIDATED EDISON COMPANY OF NEW YORK
1 PAGE OF FIRST SUPPLEMENT TO PRELIMINARY SAFETY ANALYSIS. INDIAN POINT NUCLEAR GENERATING UNIT NO. 2, MARCH 31, 1966, DOCKET NO. 50-247, PDR

QUESTION 19H - DESIGN CRITERIA AND JUSTIFICATION, HOW FULFILLED, AND TEST METHODS -- STATES THAT HYDRAULIC EFFECTS ON CORE INTERNALS DURING LOSS OF COOLANT ACCIDENT WILL BE CONSIDERED.

*CONTROL ROD, SHIM SAFETY + *DESIGN CRITERIA + *HYDRAULIC EFFECT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + FUEL ELEMENT + INDIAN POINT II + LOSS OF COOLANT + REACTOR, PRESSURIZED WATER

18-11086 DRL REFUSES INCREASED STACK RELEASE RATES AS OBSERVED DOSES EXCEED PREDICTED DOSES PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
10 PAGES, DOCKET NO. 50-133, AUGUST 19, 1966, PDR

HUMBOLDT BAY REQUESTED AN INCREASE IN ALLOWABLE RELEASE RATES BECAUSE, FOR THREE MONTHS IN 1965, POWER WAS LIMITED BY STACK RELEASE RATE DUE TO DAMAGED FUEL. DRL REFUSED THE INCREASE, NOTING BETTER FUEL THAT WILL BE PROCURED, THAT EVEN UNDER GOOD METEOROLOGICAL CONDITIONS A POPULATED AREA WAS IN A FUMIGATION CONDITION, THAT SMOKE TESTS DO NOT SUPPORT METEOROLOGICAL CONDITIONS, AND THAT SOME SITE-MONITORING STATIONS SHOW DOUBLE THE YEARLY DOSE PREDICTED. DRL BELIEVES THAT REDUCED POWER OPERATION OR JUDICIOUS FUEL REPLACEMENT IS PREFERABLE TO INCREASING STACK-RELEASE LIMITS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *RELEASE RATE + FAILURE, FUEL ELEMENT + HUMBOLDT BAY +

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11086 *CONTINUED*
LAPSE RATE, STABLE + REACTOR, BOILING WATER

18-11093 VER PLANCK DW
TUNGSTEN NUCLEAR ROCKET FACILITY TO BE DISMANTLED
GENERAL ATOMIC, SAN DIEGO, CALIFORNIA
3 PAGES, AUGUST 24, 1966, DOCKET 50-234, PDR

GENERAL ATOMIC WANTS LICENSE TERMINATED BECAUSE THE PROGRAM HAS BEEN COMPLETED. FUEL WILL BE REPROCESSED.

*REACTOR DECOMMISSIONING EXPERIENCE + CRITICAL ASSEMBLY FACILITY + REACTOR, SPACE

18-11094 LEVINE S
UNIVERSITY OF WASHINGTON RAISES POWER TO 100 KW FROM 10 KW. AMENDMENT NO. 7
DIVISION OF REACTOR LICENSING, USAEC
10 PAGES, AUGUST 30, 1966, DOCKET 50-139, PDR

UCLA AND THE UNIVERSITY OF FLORIDA HAVE INCREASED POWER WITHOUT HARM. UCLA EXPERIENCE SHOWS THAT MODERATOR DUMP DOES NOT CAUSE EXCESSIVE PLATE TEMPERATURES. LEAD BRICK WILL BE ADDED TO SHIELD TANK FOR BIOLOGICAL SHIELDING. NUCLEAR INSTRUMENTS WILL BE WRAPPED IN CADMIUM. THE PRIMARY CIRCUIT WILL HAVE SEPARATE REACTOR LOOP AND A HEAT-EXCHANGER LOOP TO PREVENT COOLANT OVERFLOW FROM THE FUEL ELEMENTS DUE TO INCREASED PUMP PRESSURE. NO INCREASE IN EXCESS REACTIVITY IS PLANNED.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *POWER UPGRATING +
ARGONAUT (ARGONNE NUC ASSEMBLY, UNIV TRAINING) + LOSS OF COOLANT + OPERATING EXPERIENCE +
REACTOR, TRAINING

18-11151 ANDERSEN P + ANDERSEN R + PEJTERSEN VS + GRENNESS M
DESIGN STUDY OF AN EXPERIMENTAL LOOP WITH A MODEL OF A DOR COOLANT CHANNEL IN FULL SIZE
SCANPROCESS A/S, CHEMICAL AND MECHANICAL ENGINEERS, COPENHAGEN + THE ELSINORE SHIPBUILDING AND ENGINEERING
CO., LTD., ELSINORE
RISO-REPORT-123 +. 180 PAGES, 20 FIGURES, 6 TABLES, 38 REFERENCES, MARCH 1965, DEP. MN

DESIGN CALCULATIONS AND DRAWINGS FOR A MECHANICAL-DESIGN TEST FOR FUEL ELEMENTS OF DOR,
(DANISH REACTOR, HEAVY-WATER ORGANIC-COOLED, 700 THERMAL MEGAWATTS). THE LOOP WAS NOT
COMPLETED BECAUSE THE DOR PROJECT WAS TERMINATED.

*HYDRAULIC EXPERIMENT + DENMARK + FUEL ELEMENT + OUT OF PILE LOOPS AND EXPERIMENTS + REACTOR, HEAVY WATER +
REACTOR, ORGANIC COOLED

18-11152 AEC UNCLASSIFIED PROGRAMS. QUARTERLY TECHNICAL PROGRESS REPORT, JANUARY - MARCH 1966
ATOMICS INTERNATIONAL
NAA-SR-11900+. 170 PAGES, FIGURES, TABLES, JUNE 1966, CFSTI \$5.00 CY, \$1.00 MN

A PRELIMINARY STUDY OF TRITIUM IN A 2117 MW(TH) FAST BREEDER INDICATE THAT 9200 CURIES PER
YEAR MAY BE PRODUCED AND MAY LEAK TO COOLANT. THIS WOULD PROBABLY BE MORE OF A NUISANCE THAN
A HAZARD. HYDRAULIC TESTS ON THE FUEL ELEMENTS (UO₂ CLAD IN SINTERED ALUMINUM POWDER) FOR
THE PIQUA CORE II WERE FOUND IN ERROR BECAUSE THE FLOWMETER READ ABOUT 40 PERCENT LOW.
VARIOUS TEMPERATURE AND FLOW CALCULATIONS ARE MADE.

*HYDRAULIC EXPERIMENT + *REACTOR, FAST + *TRITIUM + *URANIUM DIOXIDE + PIQUA +
REACTOR, LIQUID METAL COOLED + REACTOR, ORGANIC COOLED

18-11229 A GUIDE FOR THE ORGANIZATION AND CONTENTS OF SAFETY ANALYSIS REPORTS
DIVISION OF REACTOR LICENSING, USAEC
REG-1 +. 63 PAGES, 4 REFERENCES, JUNE 30, 1966, SOURCE

A GUIDE IN SATISFYING REQUIREMENTS OF 10 CFR 50, FOR POWER REACTORS, AND WRITTEN TO COORDINATE
WITH NEW TECHNICAL SPECIFICATIONS. BASICALLY AN OUTLINE (15 CHAPTERS) OF A SAFETY-ANALYSIS
REPORT, WITH DISCUSSIONS OF THE TYPE OF INFORMATION NEEDED IN EACH SUBSECTION. FOR EXAMPLE -
IIB METEOROLOGY - (1) IDENTIFY PREDOMINANT METEOROLOGICAL CONDITIONS, (2) EXPLAIN EFFECT ON
DESIGN BASES, (3) PROVIDE A BASIS FOR SELECTED DIFFUSION PARAMETERS. VI ENGINEERED
SAFEGUARDS - INFORMATION NEEDED TO SHOW (1) CONCEPT IS PROVEN, (2) SYSTEM WILL FUNCTION AND
ACCOMPLISH PURPOSE, (3) SYSTEM WILL FUNCTION WHEN REQUIRED, (4) TEST PROVISIONS HAVE BEEN
MADE.

*REGULATION, AEC + *SAFEGUARDS REPORT, GENERAL + *SAFETY PRINCIPLES AND PHILOSOPHY + DESIGN CRITERIA +
REACTOR POWER

18-11233 NICHOLS RW + WATKINS B
*IMPLICATIONS OF EMBRITTLEMENT DURING THE LIFE OF A ZIRCONIUM PRESSURE TUBE REACTOR
UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH
TRG REPORT 1252 (C) +. 21 PAGES, 9 FIGURES, 27 REFERENCES, JUNE 1966, UKAEA

REVIEW OF EFFECTS OF HYDROGEN AND RADIATION ON ZIRCALOY 2 SHOWS THAT ONLY HYDROGEN
EMBRITTLEMENT IS OF IMPORTANCE. STEAM-GENERATING, HEAVY-WATER, PRESSURE-TUBE OUT-OF-PILE

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11233 *CONTINUED*

TESTS WITH 400 PPM OF HYDROGEN SHOW THAT DEFECTS SEVERAL INCHES LONG CAN BE TOLERATED. PRELIMINARY RESULTS INDICATE THAT CRACK-OPENING DISPLACEMENT PROVIDES A CORRELATION BETWEEN SMALL-SPECIMEN TESTS AND ACTUAL TUBE TESTS. NOTCH SPECIMENS IRRADIATED IN THE DFR TO 10 TO THE 21 NEUTRONS/SQ. CM SUGGEST THAT THE EMBRITTLEMENT EFFECT SATURATES AT LOW DOSES.

*EMBRITTLEMENT + *HYDROGEN + *ZIRCALOY + REACTOR, PRESSURE TUBE

18-11234 COWAN A + FEARNEHOUGH AC + GILLIES J + LEES GM
IRRADIATION DAMAGE IN MILD STEEL. A COMPARISON OF CRACK ARREST TEST AND OF NEUTRON SPECTRUM UNITED KINGDOM ATOMIC ENERGY AUTHORITY, CULCHETH
TRG REPORT 1069 (C) +. 29 PAGES, 15 FIGURES, 8 TABLES, 19 REFERENCES, MAY 1966, UKAEA

IRRADIATION OF CRACK-ARREST SPECIMENS AND CHARPY-V-NOTCH SPECIMENS UNDER IDENTICAL CONDITIONS SHOWED GOOD CORRESPONDENCE IN EVALUATION OF IRRADIATION-EMBRITTLEMENT EFFECTS. THUS CHANGES IN CHARPY-V-NOTCH MONITORING OR SURVEILLANCE SPECIMENS CAN BE USED WHEN REACTOR PRESSURE-VESSEL OPERATING LIMITS ARE BASED ON CRACK-ARREST CRITERIA. CHARPY SPECIMENS OF THE SAME STEEL, IRRADIATED IN THREE DIFFERENT REACTORS, SHOW THAT, WHEN DAMAGE IS EXPRESSED IN TERMS DERIVED FROM ACTIVATION OF NICKEL MONITORS, MEASURED CHANGES FOR A GIVEN DOSE CAN VARY BY A FACTOR OF TWO. HOWEVER, WHEN THE DAMAGE INDEX IS TAKEN AS THE TOTAL NUMBER OF ATOMS DISPLACED IN EACH REACTOR FACILITY, THE AGREEMENT WITH MEASURED DAMAGE IMPROVED TO BETTER THAN PLUS-OR-MINUS 15 PERCENT. THUS, WITH A KNOWLEDGE OF NEUTRON SPECTRA, IT IS POSSIBLE FOR A GIVEN STEEL SAMPLE TO GIVE A RELIABLE PREDICTION OF DAMAGE FROM ONE REACTOR TO ANOTHER.

*CONTAINMENT, PRESSURE VESSEL + *EMBRITTLEMENT + TEST, DROP

18-11235 TURNER RA
ADVANCED TEST REACTOR TURBO REPORT
BABCOCK AND WILCOX, ATOMIC ENERGY DIV., LYNCHBURG
IDO-24459 +. 40 PAGES, 19 FIGURES, 8 TABLES, 5 REFERENCES, JANUARY 1964, CFSTI \$3.00 CY

SHOWS VARIATION OF POWER DISTRIBUTION WITH 17-DAY LIFETIME OF CORE. HOT-SPOT PEAK IS 2.52 AT ABOUT 1 DAY. A MAXWELLIAN SPECTRUM GAVE A BETTER POWER SHAPE, WHILE A WIGNER-WILKINS SPECTRUM GAVE A BETTER REACTIVITY MATCH WITH THE CRITICALITY EXPERIMENTS.

*FUEL BURNUP + *POWER DISTRIBUTION + ATR (ADVANCED TEST REACTOR - NRTS) + REACTOR, TEST

18-11236 INITIAL DECISION BY THE ATOMIC SAFETY AND LICENSING BOARD - MALIBU UNIT 1
ATOMIC ENERGY COMMISSION, DIVISION OF REACTOR LICENSING
48 PAGES, 28 REFERENCES, 7 FIGURES, JULY 14, 1966, DOCKET NO. 50-214, PDR

ALLOWS CONSTRUCTION PROVIDED THAT THE DESIGN CRITERIA INCLUDE PROVISION FOR PERMANENT GROUND DISPLACEMENT BY EARTHQUAKE. REVIEWS CONFLICTING TESTIMONY ON EARTHQUAKE FAULTS RUNNING THROUGH SITE.

*REGULATION, AEC + DESIGN STUDY + MALIBU + REACTOR, PRESSURIZED WATER + SEISMOLOGY

18-11237 MCGAUGH JD
THE EFFECT OF XENON SPATIAL VARIATIONS AND THE MODERATOR COEFFICIENT ON CORE STABILITY
WESTINGHOUSE ELECTRIC CORPORATION, PITTSBURGH, PENNSYLVANIA
WCAP-2983 +. 50 PAGES, 11 REFERENCES, 25 FIGURES, AUGUST 1966, DOCKET NOS. 50-250, 5C-251, 50-247, PDR

REPORT ASSERTS THAT IN THE 12-FT-LONG CORES BEING DESIGNED, XENON OSCILLATIONS CAN BE DETECTED AND CONTROLLED AND THAT POSITIVE MODERATOR COEFFICIENT ALLOW SUFFICIENT MARGIN TO INSTABILITY. THRESHOLD CALCULATIONS WERE DONE WITH DIFFUSION THEORY IN A NEUTRON-FLUX THRESHOLD PARAMETER STUDY. INDIAN POINT 2 CORE-DEPLETION STUDY DONE TO SHOW THAT FOUR LONG DETECTORS PLACED OUTSIDE THE CORE CAN SHOW INTERNAL CORE BEHAVIOR (BECAUSE OF CLOSE-COUPPING). A DIURNAL POWER CYCLE - OBTAINED WITH CONTROL ROD ADJUSTMENT - SHOWS DIVERGENT OSCILLATIONS (WITH END-OF-LIFE POWER FLATTENING) WHICH CAN BE CONTROLLED USING QUARTER-LENGTH CONTROL RODS TO SHAPE THE AXIAL FLUX. POSITIVE MODERATOR COEFFICIENT SHOWN BY ANALYSIS NOT TO EXCITE OSCILLATIONS. CRITICAL EXPERIMENTS SHOW VOIDS IN CENTRAL REGION CAUSE FLUX TO DROP (POWER TO REDISTRIBUTE), INCREASING POWER AT CORE PERIPHERY AND DECREASING IT AT THE CENTER.

*MODERATOR COEFFICIENT + *REACTOR STABILITY + *TURKEY POINT 3 + *TURKEY POINT 4 + *XENON OSCILLATION + INDIAN POINT II + INSTRUMENTATION, NUCLEAR

18-11270 ETTINGER HJ + MOSS WD + BUSEY H
CHARACTERISTICS OF THE AEROSOL PRODUCED FROM BURNING SODIUM AND PLUTONIUM
LOS ALAMOS SCIENTIFIC LABORATORY, LOS ALAMOS
LA-3491 +. 51 PAGES, 28 FIGURES, 7 TABLES, 12 REFERENCES, FEBRUARY, 1966, CFSTI \$3.00 CY, \$0.50 MN

SIZE CHARACTERISTICS OF THE AEROSOL PRODUCED DURING SODIUM AND PLUTONIUM FIRES WERE DETERMINED FOR DIFFERENT ATMOSPHERES RANGING FROM AIR TO 100 PERCENT NITROGEN. GRAM QUANTITIES OF SODIUM, PLUTONIUM-COBALT-CERIUM ALLOY, AND ALPHA- AND DELTA-PHASE PLUTONIUM WERE BURNED SEPARATELY. THE AEROSOL PRODUCED BY BURNING GRAM QUANTITIES OF SODIUM WAS COMPARED WITH THAT PRODUCED BY A FIRE INVOLVING 600 POUNDS OF SODIUM. DATA WERE OBTAINED REGARDING THE FRACTION OF PLUTONIUM ALLOY AIRBORNE DURING A PLUTONIUM FIRE. FIRES SIMULATING A REACTOR ACCIDENT INVOLVING BOTH FUEL AND COOLANT DEFINED THE RELATIVE AIRBORNE CONCENTRATIONS OF PLUTONIUM AND SODIUM. SODIUM AEROSOLS PRODUCED FROM SMALL- AND LARGE-SCALE FIRES HAVE COMPARABLE SIZE

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11270 *CONTINUED*

CHARACTERISTICS. AEROSOL PARAMETERS CAN BE DETERMINED FOR ANY SPECIAL CONDITIONS WITHOUT BUILDING A LARGE SYSTEM FOR SUCH TESTS. OXYGEN CONCENTRATION OF THE BURNING ATMOSPHERE DOES NOT AFFECT THE PARTICLE SIZE OF THE AEROSOL PRODUCED FROM BURNING PLUTONIUM METAL OR ALLOY. FIRES INVOLVING PLUTONIUM ALLOY AND SODIUM PRODUCE AIRBORNE PARTICLES THAT HAVE A PLUTONIUM-SODIUM RATIO RANGING FROM 0.34 TO LESS THAN 0.008 PERCENT. THE HIGH INITIAL RATIO IS RAPIDLY REDUCED AS THE MOLTEN SODIUM BLANKETS THE RELEASE OF PLUTONIUM.

*PARTICLE SIZE + *PLUTONIUM + *SODIUM + AEROSOL PRODUCTION + AEROSOL PROPERTIES + AEROSOL, RADIOACTIVE + AIR CLEANING + AIRBORNE RELEASE + ALLOY + FIRE + INCINERATION + OXIDATION

18-11288 POWER UPRATING OF WATERTOWN ARSENAL REACTOR TO 2 MWTH
ARMY MATERIALS RESEARCH AGENCY, WATERTOWN, MASSACHUSETTS
8 PAGES, JUNE 1966, DOCKET NO. 50-47, PDR

POWER WILL BE RAISED FROM 1 MW TO 2 AS AN INTERIM STEP TO 5. MCA IS FILLING OF BEAM TUBES, GIVING A 2 PERCENT STEP REACTIVITY. CONTAINMENT SHELL PROTECTS AGAINST 25 PERCENT FUEL MELTDOWN AND METAL-WATER REACTION. MAXIMUM HEAT FLUX WITH 21 ELEMENTS IS 32,000 BTU/HR-SQ FT, AND COOLANT FLOW IS 1000 GPM.

*POWER UPRATING + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + REACTOR, ARMY + REACTOR, POOL TYPE

18-11294 REVISIONS TO HTGR CRITICAL FACILITY
GENERAL ATOMIC, DIVISION OF GENERAL DYNAMICS, SAN DIEGO
11 PAGES, AUGUST 1966, DOCKET NO. 50-240, PDR

DRAINAGE WAS INCREASED TO PREVENT A WATER-FLOODING REACTIVITY INCREASE. A PULSED SOURCE WILL BE USED, REQUIRING BYPASSING PERIOD TRIPS. TWO NUCLEAR FUSES WILL BE USED. FUEL LOADING REQUIREMENTS WERE SET.

CRITICAL ASSEMBLY FACILITY + FUEL HANDLING + REACTOR FUSE + REACTOR, GRAPHITE MODERATED + SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + SOURCE, NEUTRON

18-11333 ARONSTEIN RE + CAMPISE AV + SPEIGLER P + VITTI J + PEARSON E + CASEY D + HOLZ HB + KEIM M
HNPF ALTERNATE CORE MODIFICATION STUDIES
ATOMICS INTERNATIONAL
NAA-SR-MEMO-11046 +. 23 PAGES, FEBRUARY 18, 1965, CFSTI, DOCKET NO. 115-3

DESCRIBES RESULTS OF A STUDY OF THE HNPF TO ACCOMMODATE TWO TYPES OF CORES - AN ADVANCED THERMAL REACTOR AND A PROTOTYPE OF A FAST REACTOR. THE REQUIRED MODIFICATIONS ARE LISTED.

*MODIFICATION, SYSTEM OR EQUIPMENT + HALLAM + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED

18-11335 ALEKSENKO YN
INVESTIGATIONS ON THE USES OF ORGANIC COOLANTS-MODERATORS IN NUCLEAR REACTORS
GOSUDARSTVENNYI KOMITET PO ISPOL ZOVANIYU ATOMNOI ENERGII, SSSR MOSCOW
IT-1248 +. 32 PAGES, 1966, JCL, \$3.60 FS, \$1.16 MF

RESULTS ARE GIVEN OF RADIATION-CHEMICAL, THERMOPHYSICAL, CORROSION, AND NEUTRON-PHYSICAL INVESTIGATIONS. THE USE OF DESTRUCTIVE HYDROGENATION FOR THE REGENERATION OF THE PRODUCTS OF RADIOLYSIS OF ORGANIC COOLANTS IS ALSO DISCUSSED.

*ORGANIC COOLANT + RADIATION EFFECT + REACTOR, ORGANIC COOLED + UNION OF SOVIET SOCIALIST REPUBLICS

18-11336 TAUBE M + POTURAJ-GUTNIAK S + KOWALEW A + MIELCARSKI M
MERCURY-BOILING FUSED-SALT FAST REACTOR WARS
INSTITUTE OF NUCLEAR RESEARCH, WARSAW, POLAND
INR-706/C +. 7 PAGES, APRIL 1966, DEP.

BRIEFLY DESCRIBES THE CONCEPT OF A 1000-MW(TH) REACTOR IN WHICH LIQUID MERCURY IS THE COOLANT, FUSED PLUTONIUM CHLORIDE THE FUEL, AND URANIUM-238 TRICHLORIDE AND NaCl OR KCl THE DILUENT.

*REACTOR DESCRIPTION + POLAND + REACTOR, HOMOGENEOUS + REACTOR, LIQUID METAL COOLED

18-11337 FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT. VOL II. APPENDIX G - SITE ASSEMBLY OF THE PRESSURE VESSEL
NORTHERN STATES POWER COMPANY
27 PAGES, SEPTEMBER 1966, 4 TABLES, 10 FIGURES, DOCKET NO. 50-263, PDR

THE SHELL RINGS WILL BE SHIPPED AS HALF RINGS WELDED TOGETHER AS FOUR FULL RINGS, AND WELDED ONE AT A TIME TO THE BOTTOM HEAD, WITH STRESS RELIEVING AFTER EACH SET OF WELDS. THE TOP-HEAD AND VESSEL-FLANGES WILL BE DRILLED IN THE FIELD. MACHINING WILL BE DONE BY BUILT UP BORING EQUIPMENT ATTACHED TO THE VESSEL. THE REPORT DESCRIBES FABRICATION AND ASSEMBLY, QUALITY CONTROL AND INSPECTION, AND LISTS CHICAGO BRIDGE AND IRON COMPANY FIELD-CONSTRUCTED HEAVY-WALL VESSELS.

*CONTAINMENT, PRESSURE VESSEL + *FABRICATION + MONTICELLO + REACTOR, BOILING WATER + WELDING

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11419 TECHNICAL SPECIFICATIONS FOR THE UNIVERSITY OF MISSOURI (AT ROLLA) REACTOR
UNIVERSITY OF MISSOURI AT ROLLA, ROLLA, MISSOURI
10 PAGES, 1 TABLE, JULY 1966, DOCKET NO. 50-123, PDR

THE REPORT PRESENTS TECHNICAL SPECIFICATIONS FOR 200-KW OPERATION, PATTERNED AFTER THE REACTOR AT OHIO STATE UNIVERSITY. DESCRIBES THE REACTOR BRIEFLY AND INCLUDES LIMITS FOR SAFETY-SYSTEM INSTRUMENTS, EXPERIMENT REACTIVITIES, MONITORING REQUIREMENTS, NEW-CORE STARTUPS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + POWER UPGRATING + REACTOR, POOL TYPE

18-11420 HAZARDS SUMMARY REPORT FOR THE UNIVERSITY OF MISSOURI (AT ROLLA) NUCLEAR REACTOR (200 KW REVISION)
UNIVERSITY OF MISSOURI AT ROLLA, ROLLA, MISSOURI
66 PAGES, 13 TABLES, 18 FIGURES, NOVEMBER 1965, REVISED JULY 1966, DOCKET NO. 50-123, PDR

THE REACTOR IS A CURTISS-WRIGHT POOL-TYPE REACTOR WITH ONE BEAM HOLE AND ONE THERMAL COLUMN. MAJOR REVISIONS IN THE HAZARDS SUMMARY APPEAR TO REPRESENT A TID-14844 MCA ANALYSIS BASED ON 4 PERCENT OF THE FUEL MELTING BECAUSE OF COOLANT-FLOW STOPPAGE. FIVE PERCENT OF THE FISSION PRODUCTS LEAVE THE POOL WATER, AND 20 PERCENT LEAVE THE BUILDING AT GROUND LEVEL.

*SAFEGUARDS REPORT, GENERAL + POWER UPGRATING + REACTOR, POOL TYPE

18-11426 TAUBE M + KOWALEW A + MIELCARSKI M + POTURAJ-GUTNIAK S
SAFETY-RATING FAST REACTOR, SAWA
INSTITUTE OF NUCLEAR RESEARCH, WARSAW, POLAND
INR-669/C +. 17 PAGES, DECEMBER 1965, DEP. MN

THE AUTHOR BRIEFLY PRESENTS THE SCHEME FOR A FAST BREEDER REACTOR FUELED WITH BOILING SALT CONTAINING FUSED PLUTONIUM CHLORIDE AS FUEL AND ALUMINUM CHLORIDE AS COOLANT.

*LIQUID FUEL + CHLORINE + PLUTONIUM + REACTOR, FAST BREEDER

18-11428 OPERATING AUTHORIZATION AND TECHNICAL SPECIFICATIONS FOR FULL POWER OPERATION OF HALLAM CONSUMERS PUBLIC POWER DISTRICT, LINCOLN, NEBRASKA
30 PAGES, FEBRUARY 5, 1964, DOCKET NO. 115-3, PDR

AUTHORIZATION REFERS TO OPERATION AT 756 MW(TH).

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + HALLAM + REACTOR, GRAPHITE MODERATED + REACTOR, LIQUID METAL COOLED

18-11430 HEAVY WATER ORGANIC COOLED REACTOR. 100-MWE NUCLEAR POWER PLANT PRELIMINARY CONCEPTUAL DESIGN. VOLUME II. PLANT DESCRIPTION
COMBUSTION ENGINEERING, INC.
AI-CE-MEMO-6 (VOL. 2) +. 294 PAGES, OCTOBER 1, 1965, CFSTI \$6.00 CY, \$1.50 MN

THE OUTPUT IS 3093 MW(TH), WITH 900-PSIG STEAM AT 725 F. THE UC FUEL IS IN SAP PROCESS TUBES. EIGHTY-FOUR HORIZONTAL SHUT-DOWN RODS AND 18 SHIM RODS SUPPORTED BY DRUM AND STEEL TAPES ARE USED.

*REACTOR DESCRIPTION + REACTOR, HEAVY WATER + REACTOR, ORGANIC COOLED

18-11532 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 60 PAGES, 7 TABLES, 6 FIGURES, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

ACRS (AUGUST 19, 1966) REQUESTED INFORMATION ON THE RELIABILITY OF CERTAIN SYSTEMS UNDER MCA CONDITIONS, SPECIFICALLY THE RECIRCULATION-SPRAY SYSTEM, THE CORE-SPRAY SYSTEM, AND THE EFFECT OF CONTAINMENT FLOODING. AFTER ANALYSIS, THE FOLLOWING ITEMS ARE PROPOSED - (A) ELIMINATION OF THE RECIRCULATION-SPRAY COOLANT SYSTEM, (B) ADDITION OF A CORE WATER INJECTION SYSTEM, (C) PLANNED FLOODING OF THE REACTOR BUILDING AFTER A RUPTURE BELOW THE CORE, (D) PLANNED STRIPPING OF THE EXTERNAL INSULATION FROM THE BUILDING FOR HEAT DISSIPATION AFTER A STEAM-LINE BREAK, AND (E) MODIFICATION OF PLANT INSTRUMENTATION FOR RELIABILITY UNDER FLOODED CONDITIONS.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS +
*SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + EMERGENCY COOLING + LACROSSE BOILING WATER REACTOR + MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

18-11533 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. PAGE 2.1, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

ANSWER V-1 DESCRIBED A RECIRCULATING SPRAY SYSTEM THAT WOULD TAKE WATER FROM THE BUILDING SUMP (PREVIOUSLY CHARGED TO BUILDING), COOL IT, AND RETURN IT TO THE CORE-SPRAY SYSTEM. NOTE - A

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11533 *CONTINUED*
NEW APPROACH TO THIS PROBLEM MAKES THIS SYSTEM INAPPLICABLE.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + CONTAINMENT SPRAY + COOLANT SYSTEM + CORE SPRAY + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

18-11534 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 8 PAGES, PAGES 3.1-3.8, SEPTEMBER 1966, DOCKET NO. 115-5 PDR

CORE SPRAY SYSTEM - SYSTEM OPERABILITY UNDER ACCIDENT CONDITIONS. A REVIEW OF REACTION FORCES, MECHANICAL DESIGN, AND CORE WATER LEVEL INSTRUMENTATION SHOWED NO UNSOLVABLE PROBLEMS. DESIGN OF THE VESSEL HOLDOWN STRUCTURE WILL NOT ALLOW VERTICAL OR RADIAL MOVEMENT FROM PIPE RUPTURE. EIGHTY-THREE PERCENT OF THE CORE-SPRAY NOZZLES WOULD HAVE TO BE BLOCKED TO RAISE THE PRESSURE ABOVE THE WEAKEST-FITTING-TEST PRESSURE. THERMAL SLEEVES AND FLEXIBLE HOSES ARE USED AS BLOWDOWN PROTECTION. PIPE WHIP DOES NOT AFFECT THE SPRAY LINES BECAUSE THEY ARE IN A DIFFERENT PIPE CHASE. PHASE REVERSAL OF THE POSITIVE-DISPLACEMENT PUMPS WILL NOT AFFECT THEIR PERFORMANCE. DURING BLOWDOWN, THE WATER LEVEL WILL READ IMPROPERLY. HOWEVER, AFTER BLOWDOWN, IT WILL RECOVER.

*CORE SPRAY + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + INSTRUMENTATION, LIQUID LEVEL DETECTION + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

18-11535 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 13 PAGES, PAGES 3.9-3.21, SEPTEMBER 1966, DOCKET NO. 115-5 PDR

CORE SPRAY SYSTEM - COOLING EFFECTIVENESS. JAPANESE AND DRESDEN 3 TESTS WERE USED TO SHOW THAT THE ORIGINAL ASSUMPTION (RADIATIVE-COOLING ONLY) WAS TOO CONSERVATIVE. TO HELP IN THE FORMULATION OF A NEW MODEL, INCLUDING CONVECTIVE AND ADDITIONAL RADIATIVE HEAT TRANSFER EFFECTS, AN EFFECTIVE K WAS ADDED TO THE ORIGINAL MODEL. THE CALCULATED NUMBER OF FUEL RODS (35 PERCENT) EXCEEDING 2500 F WAS REDUCED TO ZERO PERCENT OF THE CLADDING REACHING 2500 F IF THE EFFECTIVE K EXCEEDS 3. TESTS ARE USED TO INDICATE THAT THE LACROSSE K IS GREATER THAN 2.

*CORE SPRAY + *HEAT TRANSFER ANALYSIS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + HEAT TRANSFER EXPERIMENT + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

18-11536 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 4 PAGES, PAGES 3.22-3.25, SEPTEMBER 1966, DOCKET NO. 115-5, PRD

CORE SPRAY SYSTEM - ALTERNATE CORE SPRAY SYSTEM DESCRIPTION. A SECOND INDEPENDENT HIGH-FLOW (900 GPM) CORE-SPRAY SYSTEM WAS ADDED, USING RIVER WATER FROM THE DIESEL PUMP THROUGH PARALLEL SHUTOFF VALVES AND TWO SERIES CHECK VALVES DIRECTLY TO THE REACTOR ACCESS COVER. A SECOND DIESEL PUMP WILL BE ADDED. THE SYSTEM WILL BE STARTED ON CONTAINMENT PRESSURE ABOVE 5 PSIG, PLUS LOW REACTOR-WATER LEVEL, AND WILL INJECT WATER WHEN THE REACTOR PRESSURE DROPS TO 150 PSIG. THE BUILDING WILL BE FLOODED UNTIL THE CORE IS COVERED (10 HR LATER) IN CASE OF A BREAK IN THE MAJOR CIRCULATION LINE.

*CORE SPRAY + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM DESCRIPTION + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER + REDUNDANCE

18-11537 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 8 PAGES, PAGES 4.1-4.8, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

CONTAINMENT FLOODING - ENVIRONMENTAL EFFECTS ON ESSENTIAL SYSTEMS AND PLANT MODIFICATIONS. (A) ELECTRICAL CABLES AND PENETRATIONS ARE MOISTURE PROOF. CONTROL SOLENOIDS ARE DE-ENERGIZED TO GIVE SAFETY ACTION. HOWEVER, HIGH-TEMPERATURE COIL SHORTING COULD HOLD SOLENOIDS OPEN IF THE CURRENT DOES NOT BLOW THE FUSES. CALCULATIONS SHOW THAT THE COIL ITSELF WOULD BURN OUT TO GIVE SAFETY ACTION. MOISTURE-GENERATED SHORTS WOULD BLOW FUSES. (B) MODIFICATIONS INCLUDE A BUILDING DRAIN PIPE, REVISIONS TO CRITICAL BUILDING PRESSURE, TEMPERATURE, AND WATER-LEVEL INSTRUMENTATION, AND CHANGE OF THE FAILURE MODE OF THE WATER-SUPPLY VALVE TO SHUT DOWN THE CONDENSER.

*ENGINEERED SAFEGUARD + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + *SYSTEM OPERABILITY IN ACCIDENT CONDITIONS + CONTAINMENT INSTRUMENTATION + EMERGENCY COOLING + LACROSSE BOILING WATER REACTOR + MODIFICATION, SYSTEM OR EQUIPMENT + REACTOR, BOILING WATER

18-11538 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29
ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 4 PAGES, PAGES 5.1 TO 5.4, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

POSTACCIDENT PROCEDURES - REVIEWS OPERATION OF VARIOUS SYSTEMS. LONG-TERM DECAY-HEAT REMOVAL IS MORE DIFFICULT FOR THE SMALLER LEAK WHERE BUILDING FLOODING IS NOT FEASIBLE, OR FOR A

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11538 *CONTINUED*

STEAM-LINE BREAK WHERE THE SHUTDOWN CONDENSER IS NOT EFFECTIVE. CONTAINMENT PRESSURE AFTER A STEAM-LINE RUPTURE WAS SHOWN TO BE BELOW DESIGN PRESSURE FOR 5 DAYS, AND CONTAINMENT-INSULATION REMOVAL WAS SHOWN TO REDUCE THE BUILD UP OF PRESSURE. WHOLE-BODY RADIATION TO THE CONTROL-ROOM OPERATORS AFTER AN MCA IS 17.2 REMS FOR 200 HR.

*EMERGENCY COOLING + *PROCEDURES AND MANUALS + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + DOSE CALCULATION, EXTERNAL + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER + STEAM LINE RUPTURE

18-11539 DESCRIPTION OF POST-ACCIDENT SAFEGUARDS PROVISIONS FOR THE LACROSSE BOILING WATER REACTOR. AMENDMENT 29

ALLIS-CHALMERS MANUFACTURING COMPANY, BETHESDA, MARYLAND
ACNP-66564 +. 7 PAGES, PAGES A.1 TO A.7, SEPTEMBER 1966, DOCKET NO. 115-5, PDR

APPENDIX A - FUEL TEMPERATURE DURING PRIMARY SYSTEM BLOWDOWN. RECIRCULATION LINE BREAK IS SHOWN TO LAST 13 SEC UNTIL A PRESSURE OF 63 PSIA IS REACHED. THE K WAS ASSUMED TO BE 100 BTU/HR-DEG F-SQ. FT UNTIL SUPERHEAT WAS REACHED, AND THEN K WAS ASSUMED EQUAL TO 10.

*LOSS OF COOLANT + *SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS + HYDRODYNAMIC ANALYSIS + LACROSSE BOILING WATER REACTOR + REACTOR, BOILING WATER

18-11540 HUMBOLDT BAY TECHNICAL SPECIFICATION CHANGE 23 DUE TO ZIRCALOY CLAD FUEL
PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
11 PAGES, 1 FIGURE, 4 TABLES, SEPTEMBER 1966, DOCKET NO. 50-133, PDR

DUE TO STRESS-CORROSION-INDUCED FAILURE OF STAINLESS-STEEL-CLAD (TYPE I) FUEL, THE NOVEMBER 1966 RELOADING WILL DEVIATE FROM SPECIFICATIONS BY LOADING HALF THE CORE WITH NEW ZIRCALOY-CLAD FUEL (TYPE II) AND DIFFERENT POISON CURTAINS. ONE-QUARTER OF THE CORE WILL BE STEEL-CLAD FUEL, LOADED ON THE PERIPHERY, AND EACH ELEMENT WILL BE TESTED BY DRY SIPPING. THERMAL, HYDRAULIC, AND NUCLEAR CHARACTERISTICS OF THE CORE ARE GIVEN. A MORE DETAILED COMPUTER ANALYSIS WAS USED BECAUSE THE EXTENSIVE CHANGES WILL MAKE THE CORE LESS HOMOGENOUS.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *REFUELING + *ZIRCALOY + FAILURE, FUEL ELEMENT + HUMBOLDT BAY + REACTOR, BOILING WATER + SURFACE FILM DEPOSIT

18-11581 HUMBOLDT BAY REQUESTS DELAY TIL SCHEDULE SHUTDOWN FOR YEARLY TESTS
PACIFIC GAS AND ELECTRIC COMPANY
2 PAGES, SEPTEMBER 1966, DOCKET NO. 50-133, PDR

TECHNICAL SPECIFICATIONS REQUIRE CERTAIN TESTS FOR EACH SCHEDULED REFUELING, BUT NOT LESS FREQUENTLY THAN YEARLY. THE 1966 TESTS WOULD BECOME DUE BEFORE THE NOVEMBER 1966 REFUELING, SO A TWX REQUEST WAS MADE TO EXTEND THE TEST REQUIREMENTS TO DECEMBER 31, 1966. (TESTS INCLUDE SCRAM, CONTAINMENT ISOLATION, CORE SPRAY, RELIEF VALVE, AND EMERGENCY CONDENSER SYSTEMS.)

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *TEST, SYSTEM OPERABILITY + CONTAINMENT PENETRATION, CLOSURE OF + CONTROL ROD SCRAM MECHANISM + EMERGENCY COOLING + HUMBOLDT BAY + REACTOR, BOILING WATER

18-11603 GENERAL DYNAMICS CORPORATION DOCKET NO. 50-240 LICENSE
ATOMICS INTERNATIONAL
16 PAGES, 2 TABLES, SEPTEMBER 1966, DOCKET NO. 50-240, PDR

AUTHORIZES OPERATION OF THE HTGR CRITICAL FACILITY AT THERMAL POWER UP TO 100 W. THE TECHNICAL SPECIFICATIONS ARE INCLUDED AND PLACE RESTRICTIONS ON THE USE OF THE BUILDING, THE FUEL CONTENT OF THE ELEMENTS, THE OPERABILITY OF THE SAFETY AND CONTROL PLATES, TESTING AND REACTIVITY VALUE OF NUCLEAR FUSES, INSTRUMENTATION, RADIATION MONITORING, FUEL STORAGE, ASSEMBLY LOADING, AND THE EXPERIMENTAL PROGRAM. THE MAXIMUM TIME BETWEEN THE OPENING OF A SCRAM RELAY AND FULL INSERTION OF A SAFETY ROD IS 1.0 SEC. THE POSITIVE REACTIVITY OF ANY SAFETY OR CONTROL ROD IS LIMITED TO 3 CENTS/SEC. THE MINIMUM REACTIVITY AVAILABLE FROM NUCLEAR FUSES SHALL BE 1 DOLLAR, AND THE MINIMUM NUMBER OF FUSES IS TWO.

*CRITICAL ASSEMBLY FACILITY + *OPERATING LIMITS/TECHNICAL SPECIFICATIONS + PEACH BOTTOM + REACTOR FUSE + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

18-11675 HEAVY WATER MODERATED ORGANIC COOLED NUCLEAR FISSION REACTOR AND METHOD
U. S. ATOMIC ENERGY COMMISSION
CANADIAN PAT. 722,275 +. NOVEMBER 23, 1965, PATENT (FOREIGN)

PATENT FOR A REACTOR COOLED BY AN ORGANIC LIQUID AND MODERATED BY HEAVY WATER.

*REACTOR DESCRIPTION + REACTOR, HEAVY WATER + REACTOR, ORGANIC COOLED

18-11736 H. B. ROBINSON UNIT NO. 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT - AMENDMENT 1
CAROLINA POWER AND LIGHT COMPANY
78 PAGES, 23 FIGURES, OCTOBER 10, 1966, DOCKET NO. 50-261, PDR

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11736 *CONTINUED*

THE AMENDMENT REPRESENTS A COMPLETE REPLACEMENT OF CHAPTERS 5 (CONTAINMENT) AND 13 (ORGANIZATION AND TRAINING). A MAINTENANCE SUPERVISOR WAS ADDED TO THE TABLE OF ORGANIZATION. NINE NEW FIGURES WERE ADDED, MOSTLY CONTAINMENT-LOADING DIAGRAMS SHOWING THAT THE CONTAINMENT WILL WITHSTAND, WITHOUT LOSS OF FUNCTION, A LOSS-OF-COOLANT ACCIDENT COINCIDENT WITH A HYPOTHETICAL EARTHQUAKE. VERIFICATION OF COMPUTER PROGRAM USED WAS ASSERTED. INCREASED QUALITY CONTROL OF CONTAINMENT MATERIALS AND WELDING. RING-REINFORCING STEEL WAS ADDED TO THE CONTAINMENT DOME. STEEL-LINER STUD CONNECTIONS STUDIED. HINGE JOINT BETWEEN THE CONTAINMENT CYLINDER AND THE BASE SLAB WAS ELIMINATED IN FAVOR OF A CONCRETE MAT (WITH LEAK-TEST CONNECTIONS) ON TOP OF A LINER ON TOP OF THE SLAB. PENETRATION SEAL WATER IS NO LONGER INJECTED INTO A VERTICAL LENGTH OF PIPE BUT DIRECTLY INTO LARGE-VALVE BONNETS OR INTO THE LINE BETWEEN TWO SMALL VALVES.

*SAFEGUARDS REPORT, PRELIMINARY + CONTAINMENT LEAKAGE CONTROL + CONTAINMENT PENETRATION, CLOSURE OF + CONTAINMENT STRUCTURE + QUALITY CONTROL + REACTOR, PRESSURIZED WATER + ROBINSON + SEISMOLOGY + STRESS ANALYSIS

18-11737 H B ROBINSON UNIT 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT - VOL 1.
SUMMARY DESCRIPTION-SITE AND ENVIRONMENT
CAROLINA POWER AND LIGHT COMPANY
200 PAGES, 109 FIGURES, 33 TABLES, JULY 1966, DOCKET NO. 50-261, PDR

(1) INITIAL POWER 2094 MW(TH)/700 MW(E), EVENTUALLY 2300 MW(TH)/769 MW(E), SO ALL EVALUATION IS FOR HIGHER POWER. CORE IS IDENTICAL TO THAT OF TURKEY POINT, AS SHOWN BY COMPARISON TABLE. (2) ANSWERS TO AEC CONSTRUCTION PERMIT CRITERIA GIVEN. SITE. REACTOR LOCATED ABOVE AN EARTH DAM, ABOVE HIGH WATER LEVEL POSSIBLE. WATER RESIDENCE TIME IN LAKE IS 70 DAYS BECAUSE CONDENSER COOLING-WATER FLOW IS GREATER THAN RIVER FLOW. FIVE YEARS OF WEATHER DATA WERE ANALYZED ACCORDING TO TURNER-PASQUILL METHODS AND FORMULATED INTO A COMPUTER CODE (WINDIF) FOR DISPERSION CALCULATIONS. DESIGN EARTHQUAKE CHOSEN AS 0.1 G HORIZONTAL GROUND ACCELERATION, VERTICAL ACCELERATION IS 2/3 THE HORIZONTAL.

*SAFEGUARDS REPORT, PRELIMINARY + DESIGN CRITERIA + REACTOR, PRESSURIZED WATER + REGULATION, AEC + ROBINSON

18-11738 H B ROBINSON UNIT 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT VOL 2 -
PLANT DESIGN DESCRIPTION (AND SAFETY ANALYSIS)
CAROLINA POWER AND LIGHT COMPANY
240 PAGES, 110 FIGURES, 33 TABLES, JULY 1966, DOCKET NO. 50-261, PDR

CORE IS 3-REGION CYCLED CORE, 157 ZIRCALOY-CLAD FUEL ASSEMBLIES WITH 41-ROD-CLUSTER CONTROL ASSEMBLIES, SOLUBLE POISON CONTROLLED. THE DNB RATIO IS TO BE ABOVE 1.3 AT 12 PERCENT OVERPOWER. NO SELF-INDUCED AZIMUTHAL XENON OSCILLATIONS WILL EXIST, BUT SLOW FREE-RUNNING AXIAL OSCILLATIONS MAY OCCUR. DISCUSSION INCLUDED ON CONFIDENCE IN COMPUTER PROGRAMS FOR REACTOR PHYSICS AND HEAT TRANSFER. YANKEE EXPERIENCE WAS CITED. FUEL-ASSEMBLY SPACER GRIDS PROMOTE MIXING IN AND BETWEEN ASSEMBLIES TO REDUCE HOT-CHANNEL EFFECTS. W-3 DNB CORRELATION DISCUSSED. CORE-BARREL VIBRATION IS LIMITED BY SIX KEYS IN KEYWAYS ATTACHED TO THE REACTOR VESSEL. THE 42-PSIG CONTAINMENT VESSEL IS A STEEL-LINED PRESTRESSED-CONCRETE SHELL. PENETRATIONS HAVE AN OUTER SHELL, WHICH IS MONITORED FOR LEAKAGE. SOME PENETRATIONS PROVIDE FOR WATER INJECTION INTO A VERTICAL SECTION TO FORM A 2-FT-HIGH WATER SEAL OUTSIDE CONTAINMENT. CONTAINMENT SPRAY TAKES SUCTION FROM THE BORATED REFUELING STORAGE TANK, TO WHICH SODIUM THIOSULPHATE CAN BE ADDED FOR IODINE REMOVAL.

*CONTAINMENT, GENERAL + *FISSION PRODUCT RETENTION + *SAFEGUARDS REPORT, PRELIMINARY + COMPARISON, THEORY AND EXPERIENCE + CONTAINMENT PENETRATION, CLOSURE OF + CONTAINMENT SPRAY + ENGINEERED SAFEGUARD + HEAT TRANSFER CORRELATION + REACTOR, PRESSURIZED WATER + ROBINSON + XENON OSCILLATION

18-11739 H B ROBINSON UNIT NO. 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT - VOL. III. PLANT DESIGN DESCRIPTION AND SAFETY ANALYSIS
CAROLINA POWER AND LIGHT COMPANY
240 PAGES, 110 FIGURES, 34 TABLES, JULY 1966, DOCKET NO. 50-261, PDR

(1) IN-CORE INSTRUMENTATION WILL CONSIST OF CHROMEL-ALUMEL OUTLET-TEMPERATURE SENSORS AND MOVABLE MINIATURE FISSION CHAMBERS. REACTOR WILL BE CONNECTED TO SYSTEM LOAD DISPATCH. LOSS OF LOAD WILL NOT CAUSE TURBINE TRIP BECAUSE OF CONTROLLED STEAM DUMP. (2) A DOUBLE-ENDED PIPE RUPTURE WAS SHOWN TO RESULT IN 1 REM THYROID DOSE IN 2 HOURS AT THE SITE BOUNDARY WHERE ABOUT 10 PERCENT OF THE CORE INVENTORY EXCEEDS 2500 F AND RELEASES THE ISOTOPIC FRACTIONS NOTED IN TID-14844 AND WHERE THE 0.1 PERCENT PER DAY LEAKAGE EXISTS FOR ONLY 1 MIN UNTIL ISOLATION AND SEAL-WATER ARE EFFECTIVE. AS TO THE COMPLETE CORE MELTDOWN AND CONTINUED CONTAINMENT LEAK OF 0.1 PERCENT PER DAY, THIS WOULD YIELD 23 REMS OF IODINE DOSE AT THE SITE BOUNDARY WITH TWO CONTAINMENT SPRAYS SPRAYING NA2S2O3, OR 53 REMS WITH ONLY ONE SPRAY. ALSO, THE 2-HR THYROID DOSE IS LESS THAN 300 REMS IF A SPRAY PUMP IS STARTED 30 MIN AFTER THE ACCIDENT OR IF THE CONTAINMENT IS SEALED AFTER 40 MIN.

*CONTAINMENT PENETRATION, CLOSURE OF + *CONTAINMENT SPRAY + *SAFEGUARDS REPORT, PRELIMINARY + INSTRUMENTATION, IN CORE + LOSS OF COOLANT + REACTOR, PRESSURIZED WATER + ROBINSON

18-11740 H B ROBINSON UNIT NO. 2 - PRELIMINARY FACILITY DESCRIPTION AND SAFETY ANALYSIS REPORT-VOL. III. PLANT DESIGN DESCRIPTION AND SAFETY ANALYSIS
CAROLINA POWER AND LIGHT COMPANY
240 PAGES, 110 FIGURES, 34 TABLES, JULY 1966, DOCKET NO. 50-261, PDR

APPENDIXES - (A) SEISMIC-DESIGN CRITERIA - ACCELERATION CRITERIA WERE SET FOR VARIOUS CLASSES

ACCESSION NUMBER 18-11736 TO 18-11740

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11740 *CONTINUED*

OF ANALYSIS, AND VARIOUS EQUIPMENT SYSTEMS WERE ASSIGNED CLASSES. (B) EARTHQUAKE-DESIGN SPECTRUM RECOMMENDED BY HOUSNER IS THE AVERAGE GIVEN IN TID-7024. (C) SUMMARY OF WESTINGHOUSE EXPERIENCE WITH HIGH-POWER-LEVEL FUEL RODS IN VARIOUS TESTS. (D) CORE-SLUMP-ANALYSIS METHODS AND ASSUMPTIONS TO DETERMINE TEMPERATURES, TIMES, AND DEGREE OF MELTING.

*SAFEGUARDS REPORT, PRELIMINARY + DESIGN CRITERIA + FUEL BURNUP + OPERATING EXPERIENCE + REACTIVITY EFFECT, SLUMP + REACTOR, PRESSURIZED WATER + ROBINSON + SEISMOLOGY

18-11791 GENERAL ELECTRIC COMPANY AMENDED OPERATING LICENSE. AMENDMENT NO. 5
GENERAL ELECTRIC COMPANY, ATOMIC POWER DEPT.
27 PAGES, SEPTEMBER 1966 (MODIFIED OCTOBER 1966), DOCKET NO. 50-70, PDR

PRESENTS THE AMENDED LICENSE AND TECHNICAL SPECIFICATIONS FOR OPERATION OF THE GETR AT POWER LEVELS UP TO 50 MW(TH). THE MAXIMUM PERMISSIBLE SHORT-TERM ACTIVITY RELEASE RATES FOR THE STACK ARE NOT TO EXCEED 5 (19TH) THE MAXIMUM PERMISSIBLE CONCENTRATION (MPC), AND 5 (11TH) MPC FOR PARTICULATES. EACH LIMIT IS FOR HALF-LIVES GREATER THAN EIGHT DAYS. EXPERIMENTS CONTAINING EXPLOSIVE MATERIAL ARE LIMITED TO AMOUNTS YIELDING 2500 BTU. THE QUANTITY OF LIQUID METAL IN EACH EXPERIMENT IS LIMITED TO THAT WHICH WILL RELEASE 7500 BTU. NO CRYOGENICS OR LOOP EXPERIMENTS ARE PERMITTED.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + *POWER UPRATING + GETR (GENERAL ELECTRIC TEST REACTOR) + REACTOR, TEST

18-11804 STILLMAN DB + MEAC SW
THE FRAN PROMPT BURST REACTOR
LAWRENCE RADIATION LABORATORY, LIVERMORE
UCRL-14413 +. 37 PAGES, 20 FIGURES, 1 TABLE, SEPTEMBER 29, 1965, CFSTI \$2.00 CY, \$0.50 MN

FRAN IS A CYLINDRICAL FAST-BURST REACTOR, WITH A CENTRAL CAVITY FOR SAMPLE IRRADIATIONS. IT IS FUELED WITH U-235. FRAN OPERATED FOR 180 BURSTS FROM 1962 TO APRIL 1965.

*REACTOR DESCRIPTION + LRL (LAWRENCE RADIATION LABORATORY) + REACTOR, FAST BURST

18-11805 CHANGE 22, ADDENDUM A. - FULL-TIME AVAILABILITY OF EMERGENCY CONDENSER (DURING REACTOR OPERATION) IN THE EVENT OF A TSUNAMI (TIDAL WAVE).
PACIFIC GAS AND ELECTRIC COMPANY, SAN FRANCISCO, CALIFORNIA
4 PAGES, OCTOBER 3, 1966, DOCKET NO. 50-133, PDR

FURTHER REVIEW OF PROTECTION AGAINST TIDAL WAVES INDICATES THAT THE EMERGENCY CONDENSER SHOULD BE IN SERVICE ANYTIME THE REACTOR OPERATES.

*OPERATING LIMITS/TECHNICAL SPECIFICATIONS + EMERGENCY COOLING + HUMBOLDT BAY + REACTOR, BOILING WATER + SEISMOLOGY

18-11901 NC PUBLIC WORKS COMMISSION PROTESTS ROBINSON UNIT 2 ON ANTI-TRUST GROUNDS. OCTOBER 7, 1966
NORTH CAROLINA PUBLIC WORKS COMMISSION
3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 2-4 (OCTOBER 31, 1966) DOCKET NO. 50-261

PWC OF NORTH CAROLINA PROTESTS LICENSING OF ROBINSON UNIT 2 ON THE (ONLY) GROUNDS THAT CAROLINA POWER AND LIGHT COMPANY HAS ENTERED INTO POWER POOLING AGREEMENTS AMONG SEVERAL UTILITIES, AND ASSERTS THAT AEC POWERS SHOULD NOT BE USED IN AGREEMENTS WHICH DO NOT ALLOW SALE OF POWER TO INTERESTED NONMEMBERS AT PRICES NO HIGHER THAN TO MEMBERS. (NO TECHNICAL COMPLAINTS WERE LODGED AGAINST REACTOR DESIGN, OPERATION, OR SITE.)

*REGULATION, AEC + REACTOR, PRESSURIZED WATER + ROBINSON

18-11902 PATTERSON LR
FT. ST. VRAIN CONSTRUCTION PERMIT
PUBLIC SERVICE COMPANY OF COLORADO
9 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 4-12 (OCTOBER 31, 1966) DOCKET NO. 50-267

FT. ST. VRAIN WILL BE A LOAD-FOLLOWING REACTOR, SIMILAR TO PEACH BOTTOM HTGR, PRODUCING 837 MW(TH) AND 330 MW(E), LOCATED 35 MILES NORTH OF DENVER, COLORADO. AN 845-PSIG-DESIGN-PRESSURE PRESTRESSED CONCRETE REACTOR VESSEL WILL ENCLOSE THE PRIMARY AND PORTIONS OF THE SECONDARY SYSTEM. PRIMARY COOLANT CIRCULATORS ARE DRIVEN BY REHEAT-STEAM TURBINES, WITH AUXILIARY WATER-TURBINE DRIVES. (DETAILS GIVEN CONSISTENT WITH INTRODUCTION TO A PRELIMINARY SAFEGUARDS REPORT.)

*REACTOR DESCRIPTION + CONCRETE, PRESTRESSED + CONTAINMENT, PRESSURE VESSEL + EMERGENCY COOLING + FT. ST. VRAIN + REACTOR, GAS COOLED + REACTOR, GRAPHITE MODERATED

18-11903 JERSEY CENTRAL ADVISED TO CONSIDER DRESDEN 3 EMERGENCY COOLING PROVISIONS IN ANALYSIS OF OYSTER CREEK
JERSEY CENTRAL POWER AND LIGHT COMPANY
2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 25-26 (OCTOBER 31, 1966) DOCKET NO. 50-219

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11903 *CONTINUED*

ACRS LETTERS ON MILLSTONE POINT AND DRESDEN-2 AND -3 WERE SENT TOGETHER WITH THE SUGGESTION THAT THE DRESDEN-3 REVIEW SHOWED NECESSARY. ADDITIONAL EMERGENCY COOLING PROVISIONS (LOW-PRESSURE REFLOODING, HIGH-PRESSURE INJECTION PLUS AUTOMATIC DEPRESSURIZATION, SERVICE-WATER CONNECTION TO CONDENSER). JERSEY CENTRAL WAS ADVISED TO GIVE SPECIAL CONSIDERATION TO EMERGENCY CORE-COOLING, EVEN THOUGH FINAL SAFEGUARDS REPORT MAY HAVE GONE TO THE PRINTERS.

*CORE SPRAY + *EMERGENCY COOLING + ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + OYSTER CREEK + REACTOR, BOILING WATER

18-11904 JOHNSON JE

PYROTECHNICS SUGGESTS GENERAL LICENSING FOR AMERICIUM SMOKE DETECTORS

PYROTRONICS, INC., UNION NEW JERSEY

3 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 29-31 (OCTOBER 31, 1966)

IN SUPPORT OF A REQUEST FOR GENERAL LICENSING, PYROTECHNICS REPORTED ON CONTAMINATION TESTS OF 45,000 DETECTORS BETWEEN FALL 1963 AND JUNE 1966. ONLY 63 WERE CONTAMINATED ABOVE 0.0004 MICROCURIES. THIS TYPE OF DETECTOR HAD BEEN USED WITH RADIUM UNTIL THE FALL OF 1963, WHEN LESS THAN 130 MICROCURIES OF AM-241 WAS SUBSTITUTED. USA IS ONLY COUNTRY WHERE THESE DETECTORS MUST BE LEAK-TESTED AFTER FIELD INSTALLATION. FIELD TESTING IS A CONVENTIONAL HAZARD TO THE TESTER AND CONVINCES POTENTIAL USERS THAT THERE IS GRAVE POTENTIAL DANGER.

*FIRE + *INSTRUMENTATION, TEMPERATURE + REGULATION, AEC

18-11905 ACRS SUGGESTIONS ON AEC REACTOR SAFETY RESEARCH PROGRAM, OCTOBER 12, 1966

U. S. ATOMIC ENERGY COMMISSION

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(44), PAGES 32-33 (OCTOBER 31, 1966)

(A) ACRS ATTACHES SPECIAL IMPORTANCE TO (1) STUDIES OF MOLTEN MASSES OF FUEL AND STRUCTURAL MATERIAL, (2) STUDIES OF EMERGENCY CORE COOLING PROCESSES, (3) PERIODIC PRESSURE-VESSEL INSPECTION, (4) PROPERTIES OF THICK STEEL PRESSURE-VESSEL SECTIONS, (5) PRESTRESSED CONCRETE PRESSURE VESSELS, AND (6) ADVANCED METHODS OF CALCULATING DESTRUCTIVE REACTIVITY TRANSIENTS IN WATER-COOLED REACTORS. (B) ACRS VIEWS AS OF CURRENT AND INCREASING SIGNIFICANCE (1) PRESSURE-VESSEL STEEL OTHER THAN A302B, (2) FRACTURE MECHANICS OF PRESSURE VESSELS, (3) REVIEW OF NONNUCLEAR EXPERIENCE ON PRIMARY COOLANT SYSTEM COMPONENTS, (4) STANDARD METHODS OF CALCULATING STANDARD ACCIDENTS, (5) RECYCLED PLUTONIUM FUEL, (6) EARLY DETECTION OF SMALL LEAKS IN PRIMARY COOLANT SYSTEMS, AND (7) WASTE DISPOSAL INTO SURFACE WATER, INCLUDING BIOLOGICAL CONCENTRATION, AS IN THE GREAT LAKES.

*ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS) + *RESEARCH CONTRACT + *SAFETY STUDY + ACCIDENT, REACTIVITY + BIOLOGICAL CONCENTRATION, GENERAL + CONTAINMENT, PRESSURE VESSEL + EMERGENCY COOLING + PLUTONIUM + WASTE DISPOSAL, RIVER

18-11944 YOUNG JF

GE REQUESTS COOPERATIVE PREPARATION OF BWR SAFETY STANDARDS, SEPTEMBER 7, 1966

GENERAL ELECTRIC COMPANY

2 PAGES, ATOMIC ENERGY CLEARING HOUSE 12(42), PAGE 7-8 (OCTOBER 17, 1966) DOCKET NO. 50-249 AND 50-237

(1) JAMES F. YOUNG BRIEFLY REVIEWS RECENT ACRS-AEC REVIEWS OF DRESDEN 2 AND 3 REGARDING THE LOSS-OF-COOLANT ACCIDENT AND THE ENGINEERED SAFEGUARDS. DURING THESE ANALYSES, MORE CONSERVATIVE PREVENTIVE SAFEGUARDS WERE NOT FOLLOWED BY COMPENSATING ADJUSTMENTS IN THE CONSEQUENCE-LIMITING, SAFEGUARDS. (2) GE SUGGESTS A SERIES OF MEETINGS BETWEEN GE AND THE AEC, WITH EVENTUAL AEC ADOPTION OF BWR SAFETY CRITERIA.

*DESIGN CRITERIA + *SAFETY PRINCIPLES AND PHILOSOPHY + DRESDEN II + DRESDEN III + REACTOR, BOILING WATER

18-11952 HICOCK R

MILLSTONE POINT COMPANY ADVISED TO REVIEW THEIR DESIGN TO INCORPORATE DRESDEN 3 CHANGES, SEPTEMBER 27, 1966

MILLSTONE POINT COMPANY, HARTFORD, CONNECTICUT

1 PAGE, ATOMIC ENERGY CLEARING HOUSE 12(41), PAGE 15 (OCTOBER 10, 1966) DOCKET NO. 50-245

(1) DRL SUGGESTS THAT MILLSTONE POINT, WHICH IS ALMOST IDENTICAL TO DRESDEN 3, SHOULD BE REVIEWED IN LIGHT OF THE SIGNIFICANT CHANGES IN EFFECTIVENESS AND RELIABILITY OF CORE COOLING SYSTEM. (2) A LOW-PRESSURE, HIGH-CAPACITY, CORE-FLOODING SYSTEM WAS ADDED. ONE OF TWO EMERGENCY CONDENSERS WAS DELETED, AND A HIGH-PRESSURE, LOW-CAPACITY, COOLANT-INJECTION SYSTEM WAS ADDED FOR SMALL RUPTURES, WITH BACKUP TO COME FROM AUTOMATIC DEPRESSURIZATION. SERVICE-WATER CONNECTIONS WERE ADDED TO THE MAIN STEAM CONDENSER TO INCREASE THE WATER SUPPLY.

*CORE SPRAY + *EMERGENCY COOLING + MILLSTONE POINT + REACTOR, BOILING WATER

18-11991 OPERATIONS EXPERIENCE

RURAL COOPERATIVE POWER ASSOCIATION, ELK RIVER, MINNESOTA

COO-651-35 +. 6 PAGES, RURAL COOPERATIVE POWER ASSOCIATION ELK RIVER REACTOR, 46TH MONTHLY OPERATING REPORT, PAGES 9-15, SECTION III, AUGUST 1966, DOCKET NO. 115-1, PDR

SECT. III.- FIVE LEAKY TUBES WERE PLUGGED IN EVAPORATOR 1. (PART E)- CENTER (REGULATING) ROD POSITION AND LINEAR POWER-RANGE INSTRUMENT WAS CALIBRATED AGAINST POWER. AT 14.1 IN., 0.89 MW/IN. (AT 1723 MWD ON CORE II) OBSERVED GREATER THAN THE 0.78 MW/IN. (AT 19,800 MWD ON CORE I). NEAR FULL POWER, A 1 PERCENT CHANGE IN POWER CAUSES A 2 PERCENT CHANGE IN READING

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-11991 *CONTINUED*

BECAUSE OF VARIABLE LEAKAGE-NEUTRON ATTENUATION AS THE PRIMARY PRESSURE VARIES WITH POWER. THE INSTRUMENT ACTS AS A SQUARE-ROOT FLOWMETER DOES (F)-HIGH CHLORIDE CONTENT IN PRIMARY SYSTEM TRACED TO LONG-TERM CHLORIDE FILM BUILDUP IN A COLLECTION TANK, WHICH INCIDENTALLY HAD NO ACCESS PORTS. (G)-STACK MONITOR ALARM SETTING DRIFTED OFFSCALE, DESPITE INSTALLING AIR CONDITIONER FOR BETTER TEMPERATURE CONTROL OF THE CIRCUITS. A BETTER CONTROLLER FOR THE CONTROL ROOM INSTRUMENT AIR CONDITIONER WILL BE INSTALLED, ALONG WITH ALARMS.

CHLORINE + CONTROL ROD CALIBRATION + COOLANT CHEMISTRY + ELK RIVER + INSTRUMENTATION, ABNORMAL INDICATION + INSTRUMENTATION, POWER RANGE + MONITOR, RADIATION, STACK + REACTOR, AEC OWNED + REACTOR, BOILING WATER

18-12028 CONSERVATION CENTER APPEALS INDIAN POINT 2 CONSTRUCTION PERMIT, OCTOBER 3, 1966
CONSERVATION CENTER INC.
5 PAGES, ATOMIC ENERGY CLEARING HOUSE, 12(43), PAGES 9-13 (OCTOBER 24, 1966) DOCKET NC. 50-247

CONSERVATION CENTER, INC., APPEALED THE ISSUANCE OF A CONSTRUCTION PERMIT FOR INDIAN POINT II, TAKING SEVEN EXCEPTIONS TO THE ATOMIC SAFETY AND LICENSING BOARD ACTION. EXCEPTIONS 1-3, THAT CENTERS PETITION FOR INTERVENTION, WAS REJECTED. EXCEPTIONS 4-7, THAT CONSOLIDATED EDISON PRESENTED INSUFFICIENT EVIDENCE AND THAT ASLB ASSUMED THAT THE ACRS HAD CONCLUDED THAT INDIAN POINT II DEVELOPMENT WORK WOULD SHOW OPERATION WITHOUT UNDUE RISK. ARGUMENT WAS MADE THAT NO EXPERIENCE EXISTS FOR THIS CLASS OF REACTOR. CITES ACRS CONCERN FOR REACTOR-VESSEL FAILURE AND CONCERN FOR EMERGENCY CORE COOLING. SUGGESTS THAT DEVELOPMENT WORK BE DONE FIRST.

*CONSTRUCTION PERMIT PROCESS + BRITTLE FRACTURE + CONTAINMENT, PRESSURE VESSEL + EMERGENCY COOLING + INDIAN POINT II + REACTOR, PRESSURIZED WATER

18-12032 FINAL REPORT. HEALTH AND SAFETY REVIEW OF SM-1A CORE III
ARMY REACTOR SYSTEMS HEALTH AND SAFETY REVIEW COMMITTEE, CORPS OF ENGINEERS
ARCHS-66-3 +. 44 PAGES, 9 FIGURES, 3 TABLES, 7 REFERENCES, OCTOBER 1965, OCE

CORE III WILL HAVE 36 KG OF U-235 WITH A MEAT THICKNESS OF 0.30 IN. (INSTEAD OF 22 KG AND 0.20), DOUBLING THE CORE LIFETIME TO 32 MW-YEARS AND HAVING MORE BORON BURNABLE POISON (TO REDUCE INITIAL REACTIVITY). THE REVIEW CONSIDERED THE CHANGED CORE AND THE PROCEDURES FOR REFUELING. REFUELING AND PHYSICS-TEST PROCEDURES INCLUDED. NO SAFETY PROBLEMS WERE NOTED, INCLUDING PRESSURE-SUPPRESSION SYSTEM, EXCEPT THAT FLUX-WIRE DEBRIS CAUSED STICKING OF CONTROL RODS AND THAT A FUEL ELEMENT WAS DAMAGED IN HANDLING, BOTH PROBLEMS ARISING DURING A PREVIOUS RELOADING. OPERATION AT 400 KW(TH) IN NATURAL CONVECTION IS APPROVED WHEN ONE PUMP FAILS (AND OTHER ALREADY OUT OF SERVICE) TO AVOID A TOO RAPID COOLDOWN AND NDT PROBLEMS.

*FUEL HANDLING + *REFUELING + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + BRITTLE FRACTURE + FAILURE, SCRAM MECHANISM + OPERATING EXPERIENCE + REACTOR, ARMY + REACTOR, PRESSURIZED WATER

18-12033 REPORT. SPECIAL HEALTH AND SAFETY REVIEW OF DIAMOND ORDNANCE RADIATION FACILITY NUCLEAR REACTOR OPERATION WITH STAINLESS STEEL CLAD CORE
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-66-5 +. 9 PAGES, 3 TABLES, APRIL 1966, OCE

THE DIAMOND ORDNANCE RADIATION FACILITY (DORF) IS A WATER-REFLECTED MARK-F TRIGA REACTOR LOCATED IN WALTER REED ARMY MEDICAL CENTER, OPERATING STEADY-STATE AT 1.5 MW AND PULSING AT 4 DOLLARS. THE ALUMINUM-CLAD FUEL WAS RECENTLY CHANGED TO STAINLESS CLAD. REVIEW FOUND NO PERMANENT ELONGATION WITH THE NEW FUEL BUT RECOMMENDED CONTINUED DIMENSIONAL-ELONGATION AND BOWING SURVEILLANCE. SIGNIFICANT REACTIVITY DIFFERENCES WERE FOUND BETWEEN NEW AND OLD FUEL, AND ONE WAS LISTED. THE RECOMMENDATION WAS TO DEVELOP DIAMETRAL TESTS, CONTINUE TO MEASURE WATER CHEMISTRY AND RADIOACTIVITY, DEVELOP A TEST FOR CHLORIDE IN REACTOR WATER, AND DEVELOP A METHOD FOR THE DAILY ANALYSIS OF EXCESS REACTIVITY.

*CLAD + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + *STEEL, STAINLESS + REACTIVITY EFFECT, ANOMALOUS + REACTOR, ARMY + REACTOR, PULSED + REACTOR, RESEARCH + REFUELING + TRIGA (TRAINING REACTOR, ISOTOPES, G.A.)

18-12034 REPORT SPECIAL HEALTH AND SAFETY REVIEW OF ARMY MATERIALS RESEARCH AGENCY NUCLEAR REACTOR FACILITY OPERATION AT 2 MW POWER LEVEL
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-66-6 +. 10 PAGES, APRIL 1966, DOCKET NO. 50-47, OCE

THE WATERTOWN ARSENAL HAS OPERATED AT 1 MW(TH) SINCE JUNE 1960, AND RECENTLY REQUESTED AEC-DRL APPROVAL FOR 2-MW OPERATION. THE MCA WAS A 2 PERCENT REACTIVITY STEP FROM BEAM-HOLE FLOODING. CALCULATIONS SHOWED NO FUEL MELTING. MEASURED BEAM-HOLE REACTIVITY WAS ONLY 1.5 PERCENT. A HYPOTHETICAL ACCIDENT - WITH 25 PERCENT OF THE ALUMINUM REACTING WITH WATER - INDICATED ACCEPTABLE EXPOSURES AT SITE BOUNDARIES. ARCHS APPROVAL WAS GIVEN.

*POWER UPGRATING + *SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + BEAM HOLE + REACTOR, ARMY + REACTOR, POOL TYPE + REACTOR, RESEARCH

18-12035 SAFETY EVALUATION REPORT MH-1A (STURGIS) FLOATING NUCLEAR POWER PLANT CONTROL ROD EJECTION ACCIDENT
U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE
ARCHS-67-1 +. 16 PAGES, 1 TABLE, JULY 1966, OCE

THE ANALYSIS OF A 2.8 PERCENT INJECTION IN 88 MILLISEC, WITH A NEGATIVE 0.00003 PER DEG C DOPPLER COEFFICIENT AND THE TEMPERATURE CHANGE OF AN AVERAGE ELEMENT, GAVE TWO POWER PEAKS OF

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-12035 *CONTINUED*

520 AND 180 MW-SEC RESPECTIVELY. A HIGHLY CONSERVATIVE MODEL YIELDED 23 PERCENT MELTDOWN, WHILE COMPARISON WITH SPERT GAVE A WORST CASE OF 10 OR A BEST ESTIMATE OF 1 PERCENT MELTDOWN. EVALUATION OF REACTOR VESSEL BY NOLTR 63-140 GAVE 415 MW-SEC AS CAPABILITY OF VESSEL, AND 310 WAS ASSIGNED TO THERMAL SHIELDS. A 40 PERCENT REDUCTION IN DOPPLER EFFECT WOULD NOT CHANGE CORE MELTDOWN. ARCHS CONCLUDED THAT FURTHER REFINED CALCULATIONS ARE NOT NEEDED, RECOMMENDED MODIFICATION TO ROD DRIVES, AND ALLOWED INITIAL OPERATION (WITH LOW FISSION PRODUCT) UNTIL THE FIRST REFUELING, WHICH MAY AGAIN BRING THE CENTRAL RODS BACK UP TO 2.8 PERCENT REACTIVITY.

*SAFETY EVALUATION + ACCIDENT, CONTROL ROD EJECTION + CONTAINMENT, PRESSURE VESSEL + CONTAINMENT, SHOCK GENERATION AND PROTECTION + FUEL MELTDOWN + REACTOR, ARMY + REACTOR, PRESSURIZED WATER

18-12036 REPORT SPECIAL HEALTH AND SAFETY REVIEW. ARMY MATERIALS RESEARCH AGENCY. NUCLEAR REACTOR FACILITY ADDITIONAL SPENT FUEL STORAGE

U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE

ARCHS-67-2 +. 22 PAGES, 1 FIGURE, 7 REFERENCES, JULY 1966, DOCKET NO. 50-47, OCE

WATERTOWN ARSENAL REACTOR POWER RAISED FROM 1 TO 2 MW(TH) IN JUNE 1966, AN INTERIM STEP TOWARD 5-MW OPERATION. THE 10-FT-ID CONCRETE TANK WILL BE STEEL-LINED (TO REDUCE WATER LEAKAGE AND MINIMIZE A LOSS-OF-COOLANT ACCIDENT), NECESSITATING TEMPORARY STORAGE OF IRRADIATED FUEL ELSEWHERE. FORTY-NINE ELEMENTS WILL BE STORED AROUND THE PERIPHERY OF AN UNUSED GAMMA-FACILITY TANK, 6 FT IN ID. REPORT ORNL-2609 WAS CITED TO SHOW THAT AN INFINITELY LONG PLANE, ONE ELEMENT HIGH, WOULD BE SUBCRITICAL. ARCHS CONCLUDED THAT FUEL MAY BE SAFELY STORED AS DESCRIBED BUT REQUESTED AN ANALYSIS OF THE DEGREE OF SUBCRITICALITY (IN THE CYLINDRICAL ARRAY).

*SAFETY REVIEW (OPERATIONS, EXPERIMENTS) + CRITICALITY SAFETY + FUEL STORAGE + REACTOR, ARMY + REACTOR, POOL TYPE + REACTOR, RESEARCH

18-12037 INTERIM REPORT. HEALTH AND SAFETY REVIEW OF MH-1S (STURGIS) FLOATING NUCLEAR POWER PLANT FINAL SAFEGUARDS REPORT

U. S. ARMY, CORPS OF ENGINEERS, SAFETY OFFICE

ARCHS-66-4 +. 25 PAGES, 5 REFERENCES, MARCH 1, 1966, OCE

THE REVIEW, BASED ON FINAL SAFEGUARDS REPORTS AND ADDENDA, IS INTENDED ONLY FOR FT. BELVOIR OPERATION. A PREVIOUS REVIEW SHOWED THE UNIQUE SAFETY FEATURE OF MHIA TO BE SATISFACTORY BUT INDICATED 8 (OUT OF 27) AEC CONSTRUCTION-PERMIT CRITERIA WERE NOT FULFILLED; PRIMARILY BECAUSE OF LACK OF DETAILED INFORMATION. THIS REPORT CONSIDERS ONLY THOSE 8 CRITERIA (CRITERIA 3, 6, 7, 13, 15, 16, 19, AND 20). ALL ITEMS WERE SATISFACTORY EXCEPT 7, 19 AND 20. ITEM 7 CONSIDERED A ROD EJECTION OF THE CENTER ROD (2.8 PERCENT REACTIVITY) AS GIVING ONLY MINOR FUEL MELTING. HOWEVER, THE MOST CONSERVATIVE DOPPLER COEFFICIENT WAS NOT USED. ITEMS 19 AND 20 - THE CONTAINMENT IS SCHEDULED TO BE LEAK-RATE TESTED AT 50 PSIG RATHER THAN AT THE 140.3-PSI DESIGN PRESSURE. THUS THERE MAY BE UNKNOWN LEAKAGE PATHS EVIDENT ONLY AT HIGH PRESSURE.

*SAFETY EVALUATION + ACCIDENT, CONTROL ROD EJECTION + CONTAINMENT, HIGH PRESSURE + MH 1A (MOBILE HIGH POWER PLANT 1A) + REACTOR, ARMY + REACTOR, PRESSURIZED WATER + TEST, LEAK RATE

18-12043 BROWNS FERRY NUCLEAR POWER STATION - TVA - DESIGN AND ANALYSIS REPORT

TENNESSEE VALLEY AUTHORITY, KNOXVILLE, TENNESSEE

35 PAGES, JULY 1966, DOCKET NOS. 50-259 AND 50-260, PDR

CORPORATE INFORMATION PRIMARILY. - BROWNS FERRY WILL HAVE TWO IDENTICAL BWR UNITS, SHARING THE REFUELING BUILDING AND CERTAIN AUXILIARIES. EACH UNIT REFERENCE DESIGN IS 3293 MW(TH)/1098 MW(E) (GROSS), (ONE ON LINE OCTOBER 1970, THE OTHER IN OCTOBER 1971). HOWEVER, THE TURBINE IS SIZED FOR 1152 MW(E) (GROSS). LOCATED 10 MILES FROM ATHENS AND FROM DECATUR, ALABAMA. ZIRCALOY-2 CLAD UO2 IS IN A CORE 16-1/2 FT IN DIAMETER AND 12 FT TALL. CONTAINS 185 84C MOVABLE CONTROL RODS AND 356 TEMPORARY, FIXED CONTROL RODS, WITH VARIABLE CIRCULATION-FLOW POWER CONTROL WITH TWO LOOPS. PRESSURE-SUPPRESSION CONTAINMENT, WINDOWLESS CONCRETE REFUELING BUILDING, WITH A STANDBY GAS-TREATMENT SYSTEM PLACED IN SERVICE WHEN NEEDED.

*SAFEGUARDS REPORT, GENERAL + ADMINISTRATIVE CONTROLS AND PRACTICES + BROWNS FERRY + ECONOMICS + REACTOR, BOILING WATER

18-12044 BROWNS FERRY NUCLEAR POWER STATION - TVA - DESIGN AND ANALYSIS REPORT - VOL. I

TENNESSEE VALLEY AUTHORITY

360 PAGES, 46 TABLES, 150 FIGURES, JULY 7, 1966, DOCKET NOS. 50-259 AND 50-260, PDR

SITE. - NO SPECIAL GEOGRAPHICAL FEATURES, AND THE LAKE IS NOT LIKELY TO AFFECT BREEZES. CONTAINMENT. - DESIGN IS 62 PSIG, WHILE PIPING BLOWDOWN CALCULATION INDICATED 32. ANALYSIS SHOWS THAT CONTAINMENT CAN HANDLE PRESSURE FROM ANY CORE MELTDOWN LESS THAN 35 PERCENT. CONTAINMENT WILL HAVE AN INERT ATMOSPHERE. ENGINEERED SAFEGUARDS. - TWO CORE-SPRAY SYSTEMS PROVIDE A LOW-PRESSURE SPRAY, WHICH ALSO CAN REFLOOD THE CORE. EACH REACTOR HAS A SEPARATE CONTAINMENT SPRAY SYSTEM AND SHARES ONE SYSTEM. ACCIDENT ANALYSIS. - FOUR ACCIDENTS WERE ANALYZED IN DETAIL, AS WORST OF THAT TYPE. ROD EJECTION IN HOT STANDBY GAVE NO FUEL MELTDOWN, BUT CLAD PERFORATIONS RELEASED FISSION GAS WHICH PRODUCED A 0.1-REM CLOUD GAMMA DOSE, 2 HR. IN THE FUEL-HANDLING DROP (WORST RELEASE TO SECONDARY CONTAINMENT), REFUELING WATER RELEASES ALL RADIOGAS AND 1 PERCENT OF HALOGEN FROM 10 FUEL ELEMENTS, GIVING 0.66 REM CLOUD DOSE, 2 HR. STEAM-LINE BREAK GIVES NO MELTDOWN, HOT CLOUD RISES 212 FT IN A 50-MPH WIND, AND DOSES ARE IN THE MILLIREM REGION. PIPE RUPTURE IN DRY WELL GIVES DOSES IN MILLIREM REGION. SEVENTY-FIVE PERCENT OF RODS COULD HAVE CLADDING PERFORATIONS BUT NO FUEL WOULD MELT. LESS THAN 1 PERCENT OF THE INORGANIC IODIDES COULD LEAK FROM THE SUPPRESSION POOL AS

CATEGORY 18
SAFETY ANALYSIS AND DESIGN REPORTS

18-12044 *CONTINUED*

GAS AND WOULD BE FILTERED BY STANDBY GAS TREATMENT PLANT.

*SAFEGUARDS REPORT, GENERAL + BROWNS FERRY + CORE SPRAY + LOSS OF COOLANT + REACTOR, BOILING WATER

18-12045 BROWNS FERRY NUCLEAR POWER STATION - TVA - DESIGN AND ANALYSIS REPORT - VOL. II
TENNESSEE VALLEY AUTHORITY

360 PAGES, 157 FIGURES, 46 TABLES, JULY 7, 1966, DOCKET NOS. 50-259 AND 50-260, PDR

VOL. II CONTAINS ILLUSTRATIONS AND FIVE APPENDIXES. (A) GLOSSARY. (B) RELIABILITY ANALYSIS OF REACTOR PROTECTION SYSTEM. (C) CONTROL-ROD-DRIVE-SYSTEM DESCRIPTION AND ANALYSIS. REALLY STATEMENTS ON VARIOUS DESIGN ASPECTS AND FAILURES. (D) JET-PUMP DEVELOPMENT. REVIEW OF DESIGN AND OPERATIONAL ASPECTS. (E) CORE-SPRAY TEST. THIRTY-SIX ELECTRICALLY HEATED RODS WERE HEATED, AND 2-3 GPM WATER WAS SPRAYED ON TO GIVE SOME DESIGN NUMBERS. (F) CONTAINMENT FISSION-PRODUCT-RETENTION CAPABILITY.

*SAFEGUARDS REPORT, GENERAL + BROWNS FERRY + CONTAINMENT, GENERAL + CORE SPRAY + FISSION PRODUCT RETENTION + PUMP, JET + REACTOR, BOILING WATER

CATEGORY 19
BIBLIOGRAPHIES

19-09739 NEAL LG + ZIVI SM
HYDRODYNAMIC STABILITY OF NATURAL CIRCULATION BOILING SYSTEMS. VOLUME I. A COMPARATIVE STUDY OF
ANALYTICAL MODELS AND EXPERIMENTAL DATA
TRW SYSTEMS, REDONDO BEACH, CALIFORNIA
STL-372-14(1) +. 185 PAGES, JUNE 30, 1965, CFSTI, \$5.00 CY, \$1.00 MN

MECHANISMS OF HYDRODYNAMIC INSTABILITY, (BASIC TYPES OF HYDRODYNAMIC INSTABILITY, LUMPED
PARAMETER APPROXIMATION OF VOID-FLOW FEEDBACK MECHANISM, EFFECTS OF HEAT CAPACITY AND THERMAL
CONDUCTIVITY OF THE CHANNEL WALLS, TRANSPORTATION TIME DELAYS). OBSERVED EFFECT OF OPERATING
PARAMETERS ON LOOP STABILITY, (EFFECT OF SYSTEM PRESSURE EFFECT OF SUBCOOLING, EFFECT OF
FRICTIONAL DISTRIBUTION). THE DYNAMIC EQUATIONS FOR STABILITY MODELS (CONSERVATION
EQUATIONS, SLIP, FRICTION AND HEAT TRANSFER EQUATIONS, METHODS OF SOLUTION). STABILITY
MODELS (NON-LINEAR MODELS, LINEARIZED MODELS, OTHER MODELS). APPLICATION OF JONES MODEL TO
THE EBWR INSTABILITY, CONCLUSIONS. EXPERIMENTAL DATA AND TEST LOOP DESCRIPTIONS.

ANALYTICAL MODEL + CIRCULATION, NATURAL (LOOPS AND REACTORS) + COMPARISON, THEORY AND EXPERIENCE +
COMPUTER PROGRAM + DYNAMICS, NONLINEAR + EBWR (EXPERIMENTAL BOILING WATER REACTOR) + HYDRAULIC ANALYSIS +
REACTOR STABILITY + REACTOR, BOILING WATER + THERMAL ANALYSIS

19-10430 ARGONNE NATIONAL LABORATORY PUBLICATIONS, JULY 1, 1964 - JUNE 30, 1965
ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS
ANL-7087 +. 328 PAGES, AUGUST 1965 CFSTI, \$7.00 CY, \$1.50 MN

THIS PUBLICATION LIST IS A BIBLIOGRAPHY OF SCIENTIFIC AND TECHNICAL ACCOUNTS ORIGINATED AT
ARGONNE AND PUBLISHED DURING FISCAL YEAR 1965. IT INCLUDES ITEMS PUBLISHED AS JOURNAL
ARTICLES, TECHNICAL REPORTS, BOOKS, ETC., ALL OF WHICH HAVE BEEN MADE AVAILABLE TO THE
PUBLIC. THE LIST IS DIVIDED INTO THREE PARTS - THE FIRST A LIST DIVISION, THE SECOND AN
ALPHABETICAL AUTHOR INDEX, AND THE THIRD PART A KWIC SUBJECT INDEX. INCLUDED ARE SECTIONS ON
RADIOLOGICAL PHYSICS, REACTOR PHYSICS, REACTOR ENGINEERING, INDUSTRIAL HYGIENE AND SAFETY,
FIRE PROTECTION, AND CHEMICAL ENGINEERING.

*BIBLIOGRAPHY + *BURNOUT HEAT FLUX + *CHEMICAL REACTION + *DOSE MEASUREMENT, EXTERNAL + *HEAT TRANSFER +
*REACTOR DYNAMICS + *REACTOR STABILITY + ACCIDENT ANALYSIS +
FARET (FAST ARGONNE REACTOR EXPERIMENT TEST) + METAL WATER REACTION + NOISE + REACTIVITY COEFFICIENT +
REACTOR KINETICS + REACTOR TRANSIENT + REACTOR, BREEDER + REACTOR, FAST + REACTOR, LIQUID METAL COOLED +
SPACE DEPENDENT DYNAMICS + VOID COEFFICIENT

19-12041 BORNAND B
LISTING OF NUCLEAR CODES FOR IBM-704, 709, AND -7090
COMMISSARIAT A L'ENERGIE ATOMIQUE, SACLAY, FRANCE
CEA-BIB-17 (III) +. 143 PAGES, JANUARY 1966, CEA, IN FRENCH AND ENGLISH

THE DIGITAL COMPUTER CODES LISTED IN PARTS I AND II OF THIS BIBLIOGRAPHY WERE SELECTED ON THE
BASIS OF THE MOST USEFUL CODES FOR REACTOR COMPUTATIONS. IN THE LISTING, THE CODES ARE
ARRANGED CHRONOLOGICALLY IN EIGHT CATEGORIES - BURN-UP, ENGINEERING, GROUP DIFFUSION,
KINETICS, TRANSPORT, PHYSICS, MONTE-CARLO, MISCELLANEOUS. BURN-UP, ENGINEERING, AND GROUP
DIFFUSION ARE ISSUED IN PART I. MACHINE, FAST MEMORY, AND LANGUAGE ARE INDICATED. THE
NUMBER OF THE REPORT THAT GIVES THE DETAILS OF THE CODE IS LISTED. INDEXES OF CODE NAMES,
AUTHORS, AND OF QUOTED REPORTS ARE GIVEN. THIS BIBLIOGRAPHY HAS BEEN REVIEWED FROM 1957 TO
MARCH 1964, FOR SECTION I, FROM 1957 TO MARCH 1965 FOR SECTION II.

*BIBLIOGRAPHY + *COMPUTER PROGRAM + *FRANCE

INFORMATION AT NSIC IS DIVIDED INTO 19 CATEGORIES. AN ITEM OF INFORMATION MAY BE KEYED TO AS MANY AS THREE OF THESE. A COLLECTION OF SELECTORS OR KEY-WORDS IS USED TO DENOTE THE MAIN SAFETY RELATED POINTS COVERED IN AN ARTICLE. THE FOLLOWING INDEX IS AN ALPHABETICAL LISTING OF SELECTORS GIVING REFERENCES TO EACH ARTICLE WHICH WAS KEYED TO IT. THE CATEGORY NUMBER IS GIVEN FIRST, FOLLOWED BY THE ACCESSION NUMBER. THE ACCESSION NUMBERS ARE USED TO LOCATE BIBLIOGRAPHIC ITEMS WITHIN A CATEGORY.

AARR (ARGONNE ADVANCED RESEARCH REACTOR)				AEROSOL PROPERTIES			
6-09701	8-09701			5-10407	7-09361	7-09363	7-09367
ACCELERATOR				7-09752	7-09758	7-10407	7-10580
15-11298	15-11812	15-11827	17-11788	7-10590	7-11270	18-11270	
17-11793				AEROSOL, RADIOACTIVE			
ACCIDENT ANALYSIS				7-11270	16-10775	18-11270	
1-09686	1-10411	4-09681	4-09685	AEROSPACE SAFETY			
4-11503	5-09686	5-09687	5-10407	4-09600	4-09608	4-09679	4-09681
5-10430	5-11108	5-11384	5-11405	4-09682	4-09685	4-09688	4-09690
6-10430	6-11162	7-09758	7-10407	4-09726	4-10261	4-11491	4-11493
8-10108	8-10111	8-10112	8-10397	4-11494	4-11496	4-11497	4-11498
8-11405	8-11412	11-09687	12-10111	4-11499	4-11500	4-11501	4-11503
17-11108	18-09687	19-10430		4-11504	6-11106	7-09758	8-10256
ACCIDENT COMPILATION				8-11493	15-09726		
17-11092				AGGLOMERATE			
ACCIDENT MODEL				7-10580	7-10590		
5-10407	5-12076	7-09758	7-10407	AGN (TRAINING REACTOR, AERJET-GEN. NUCLEONICS)			
7-12076				18-09868			
ACCIDENT, CONSEQUENCES				AGR (ADVANCED GASCOOLED REACTOR, WINDSCALE, UK)			
4-11503	5-09687	7-09545	11-09687	1-10404	18-10340	18-10404	
18-09687				AIR			
ACCIDENT, CONTROL ROD EJECTION				8-10256	8-11403	14-11347	14-11819
5-10906	6-10906	6-12035	6-12037	15-09499	15-11134	15-11476	15-11819
11-12037	18-10906	18-12035	18-12037	AIR CLEANING			
ACCIDENT, CONTROL ROD WITHDRAWAL				7-09362	7-09363	7-09364	7-09367
5-09687	5-10906	6-10906	6-11142	7-09536	7-09758	7-11270	7-12077
11-09687	18-09687	18-10906		12-09831	13-09831	14-11702	14-11703
ACCIDENT, CRITICALITY				15-11714	18-09831	18-11270	
5-11761	9-10153	15-09755	15-10153	AIR POLLUTION			
17-09755				16-09568			
ACCIDENT, EXPLOSION				AIRBORNE RELEASE			
11-11446	11-11978	11-11979		7-08811	7-09536	7-09758	7-11270
ACCIDENT, EXPOSURE				11-10904	17-09812	17-09813	17-09818
3-09850	12-09850	15-09850		18-10904	18-11270		
ACCIDENT, GENERAL				AIRCRAFT			
7-09758				15-10092	16-09568		
ACCIDENT, HYPOTHETICAL				ALLOY			
1-10411				1-10130	5-09917	5-09918	5-09919
ACCIDENT, MAXIMUM CREDIBLE (MCA)				5-09921	5-09966	7-09537	7-09919
5-10917	5-11391	5-11761	6-09701	7-09966	7-11270	7-12080	8-10130
6-11268	7-10270	8-09701	14-11268	8-10399	11-09917	11-09918	11-09919
18-10270	18-10917			11-09921	11-09966	18-11270	
ACCIDENT, MONITOR				ALPHA EMITTER			
17-11606				9-10151			
ACCIDENT, NONNUCLEAR				ALUMINUM			
17-11606				6-10064	7-12080	8-11412	9-11999
ACCIDENT, PROBABILITY OF				11-11768	11-11769	17-11999	
11-10259				AMERICIUM			
ACCIDENT, REACTIVITY				8-12020			
6-07756	8-10112	8-11412	9-10439	ANALOG SIMULATION			
14-11905	15-11905	17-07756	17-11136	6-12092	9-12092	9-12093	
18-11905				ANALYTICAL MODEL			
ACCIDENT, REFUELING				5-10578	5-12076	6-09710	6-09721
5-09687	5-10906	6-10906	11-09687	6-09739	6-09944	6-10287	6-10578
18-09687	18-10906			6-11023	6-11483	6-11486	7-09229
ACRS (ADVISORY COMMITTEE ON REACTOR SAFEGUARDS)				7-09372	7-09582	7-09757	7-09758
14-11905	15-11905	18-09453	18-10116	7-09764	7-09832	7-10179	7-10578
18-11903	18-11905			7-10590	7-12074	7-12075	7-12076
ACTIVATION				8-10108	9-09944	9-10150	9-10287
6-11268	7-09537	14-11268	15-11481	9-11023	9-11840	9-12082	9-12086
ACTIVATION PRODUCT				11-11458	17-09944	19-09739	
14-11319	14-11354	14-11821	15-11319	ANALYTICAL TECHNIQUE, AIR			
15-11354	15-11821			15-11714			
ADMINISTRATIVE CONTROLS AND PRACTICES				ANALYTICAL TECHNIQUE, CALIBRATION			
1-07715	1-07717	1-10122	1-10838	15-10100			
1-11407	3-09850	5-11990	7-09545	ANALYTICAL TECHNIQUE, FOOD			
12-09850	15-09850	17-07715	17-07717	15-11306	15-11811		
17-07719	17-07759	17-10838	17-11943	ANALYTICAL TECHNIQUE, GAS			
17-11990	18-10116	18-12043		7-10175	14-11959	15-11714	15-11959
ADSORPTION				ANALYTICAL TECHNIQUE, GENERAL			
7-10175	7-12074	14-11344		7-09758	7-10177	7-10178	15-08810
ADSORPTION SURFACE				15-11811	15-11811	15-11960	
7-10175				ANALYTICAL TECHNIQUE, MILK			
AEROSOL				15-08810			
5-10407	7-09361	7-09363	7-09367	ANALYTICAL TECHNIQUE, SOLID			
7-09752	7-09758	7-10177	7-10407	14-11319	14-11345	14-11824	15-11319
7-10580	7-10590	7-12074	15-11779	15-11345	15-11623		
16-10772				ANALYTICAL TECHNIQUE, URINE			
AEROSOL PRODUCTION				15-11482			
7-09361	7-09363	7-09752	7-09758	ANALYTICAL TECHNIQUE, VEGETATION			
7-11270	18-11270			15-08810			

ANALYTICAL TECHNIQUE, WATER				17-11087	17-11243	17-11244	17-11968
14-11777	15-11306	15-11777	15-11811	BOUNDARY LAYER			
ANL (ARGONNE NATIONAL LABORATORY)				5-10750	5-10751	5-10752	5-11171
1-10107	1-10130	1-11407	8-10130	BREEZE, SEA			
8-11403	16-10768	17-07713	17-10762	16-11262	16-11984		
ANNULUS				BRITTLE FRACTURE			
5-09627	5-09996	5-10754	5-11297	5-09814	5-09919	5-09920	5-09965
5-11759				5-09966	7-09919	7-09965	7-09966
ANTIMONY				11-09759	11-09919	11-09920	11-09965
15-11957				11-09966	11-10185	11-10187	11-10259
APPLICATION FOR AEC LICENSE				11-11446	11-11447	11-11508	11-11509
2-10600	12-10600	13-10600		11-11588	11-11590	11-11591	11-11630
ARGON				11-11631	11-11632	11-11766	11-11768
7-09521	8-10256	9-09801		11-11769	17-09814	17-09870	18-12028
ARGONAUT (ARGONNE NUC ASSEMBLY, UNIV TRAINING)				18-12032			
18-11094				BROMINE			
ATMOSPHERIC CIRCULATION, GLOBAL				14-11343			
15-11134	16-09651			BROOKWOOD			
ATMOSPHERIC DIFFUSION				18-09453			
1-10405	14-11524	16-09651	16-11262	BROWNS FERRY			
ATMOSPHERIC DIFFUSION EXPERIMENT				18-12043	18-12044	18-12045	
16-10775				BUCKLING			
ATMOSPHERIC DIFFUSION, GLOBAL				5-11396	11-10169	11-10185	11-10186
16-10768				11-10188	12-11396		
ATMOSPHERIC POLLUTION				BUILDING			
16-11735	17-11735			5-10917	7-10581	18-10917	
ATR (ADVANCED TEST REACTOR - NRTS)				BULGARIA			
17-07747	18-11235			1-10109	13-10109	15-10109	
AUSTRALIA				BURNOUT HEAT FLUX			
16-11264				5-10430	5-10454	5-11395	5-11455
AUXILIARY COOLING SYSTEM				5-11466	5-11755	5-11760	5-12237
11-09821				6-10430	6-11843	8-10454	9-07763
BARIUM				9-11840	9-11843	17-07763	18-10454
15-11306	15-11596	15-11960		19-10430			
BEAM HOLE				BURST PRESSURE			
17-07753	18-12034			11-10185	11-11508	11-11977	
BELGIUM				CADMIUM			
1-09968	3-09968	13-09968	15-09755	14-11343	14-11819	15-11819	
17-09755				CALCINATION			
BERYLLIUM				14-11661	14-11817	14-11959	15-11959
4-09681	8-10304	14-11319	15-11319	CALCIUM			
15-11481	15-11957	17-10749		14-09539	14-11344	14-11357	14-11531
BETA EMITTER				15-11531			
7-10177	9-10151	15-11471		CALIFORNIUM			
BIBLIOGRAPHY				15-11595			
1-12041	5-10269	5-10430	5-12041	CANADA			
6-10430	8-10113	8-12020	11-10185	1-09969	1-11160	15-11783	17-11142
11-10260	11-11630	11-11631	16-10768	18-10164			
19-10430	19-12041			CARBIDE			
BIG ROCK POINT				7-12079	9-10014		
17-07704	17-07705	17-09798	17-11111	CARBON			
17-11144	17-11964			1-10656	5-08969	7-09519	7-12079
BIOLOGICAL CONCENTRATION, ANIMAL				13-10656			
14-11345	14-11353	15-11345	15-11353	CARBON DIOXIDE			
15-11779				7-10584	8-10399	9-09801	
BIOLOGICAL CONCENTRATION, ANIMAL FEED				CARBON MONOXIDE			
14-11531	15-11358	15-11529	15-11531	7-10584	9-09801	17-11619	
BIOLOGICAL CONCENTRATION, AQUATIC ORGANISMS				CENTERLINE MELTING			
14-09539	14-11774	15-11523	15-11958	5-10900	5-11992	17-09871	17-11992
BIOLOGICAL CONCENTRATION, FOOD				18-10900			
14-11819	15-11358	15-11523	15-11819	CERAMICS			
15-11957				9-12081			
BIOLOGICAL CONCENTRATION, GENERAL				CERIUM			
14-11319	14-11819	14-11905	15-11319	2-10600	7-09597	7-09753	7-10177
15-11358	15-11594	15-11819	15-11831	7-10583	12-10600	13-10600	14-11343
15-11905	15-11955	18-11905		14-11357	14-11522	14-11663	15-11134
BIOLOGICAL CONCENTRATION, MAN				15-11306	15-11957	15-11960	
14-11633	15-08806	15-11477	15-11482	CESIUM			
15-11525	15-11633	15-11818	15-11956	2-10600	7-09753	7-10177	12-10600
BIOLOGICAL CONCENTRATION, MILK				13-10600	14-09539	14-11319	14-11344
14-11531	14-11633	14-11819	14-11822	14-11357	14-11479	14-11522	14-11662
15-08810	15-11358	15-11523	15-11531	14-11774	14-11786	15-08806	15-08810
15-11596	15-11633	15-11819	15-11822	15-11134	15-11306	15-11319	15-11342
BIOLOGICAL CONCENTRATION, VEGETATION				15-11358	15-11523	15-11525	15-11529
14-11353	14-11633	15-08810	15-11353	15-11596	15-11623	15-11655	15-11662
15-11358	15-11529	15-11596	15-11633	15-11810	15-11831	15-11956	15-11957
BIOMEDICAL				15-11958	17-10095		
1-10412	4-09726	7-12075	15-09726	CEYLON			
15-11779	15-11814	15-11818	15-11955	15-11961			
15-11973	15-11974	15-11975		CHAMBER, COMPENSATED			
BNL (BROOKHAVEN NATIONAL LABORATORY)				9-11772	9-12088		
15-11596	17-11676			CHAMBER, FISSION			
BONUS (BOILING NUCLEAR SUPERHEAT PROJECT)				9-10147			
17-09812	17-09813	17-09816	17-11137	CHAMBER, ION			
18-09816	18-10116			9-10147	9-11762	9-11764	9-11771
BORAX, ALL (BOILING REACTOR EXPERIMENTS, NRTS)				9-11772	15-11764	15-11771	
6-09941	6-09944	6-11284	7-07739	CHAMBER, NEUTRON			
9-09943	9-09944	17-07739	17-09942	9-10147	9-12088		
17-09943	17-09944	17-09945		CHARCOAL			
BORON				5-10174	7-09536	7-09758	7-10174
6-09941	6-11484	9-10014	13-11484	11-10174	11-10901	18-10901	

CHEMICAL ANALYSIS				11-09860	11-09862	11-09864	11-10167
5-10269	5-11755	7-09595	7-09596	11-10168	11-10169	11-10171	11-10260
14-11823	15-08810			11-10288	11-11445	11-11449	11-11585
CHEMICAL EQUILIBRIUM				11-11586	11-11592		
5-09952	5-12076	7-09952	7-12075	CONCRETE, PRESTRESSED			
7-12076	8-09952			1-10405	11-09772	11-09821	11-09860
CHEMICAL KINETICS				11-09862	11-09864	11-09974	11-10167
5-09952	5-10174	5-10553	5-12076	11-10168	11-10169	11-10171	11-11449
7-09765	7-09952	7-10174	7-12076	11-11585	11-11587	11-11592	11-12039
8-09952	8-12020	11-10174		11-12040	18-09453	18-09974	18-11902
CHEMICAL REACTION				CONDENSATION			
1-10107	1-10257	5-09952	5-10407	5-10209	17-11605		
5-10430	5-12076	6-10430	7-09952	CONNECTICUT YANKEE			
7-10407	7-10584	7-12076	8-09952	7-12072			
8-10110	8-10256	8-10304	8-10397	CONSTRUCTION PERMIT PROCESS			
8-10399	8-11403	8-11413	12-10312	18-12028			
13-09305	13-10257	14-11823	17-09305	CONTAINMENT ABSOLUTE MEASURING SYSTEM			
17-11413	17-11599	17-11614	17-11618	11-09750			
18-10257	19-10430			CONTAINMENT AIR LOCK			
CHEMICAL SHIM				17-09309			
1-09703	6-09703			CONTAINMENT ANALYSIS			
CHEMICAL TOXICITY				5-10320	6-10065	11-10289	11-10320
1-10412	4-09681	15-11779		11-11446	11-11583	11-11622	11-11976
CHEMISORPTION				CONTAINMENT CONSTRUCTION			
7-10175				11-10319	11-11591		
CHLORINE				CONTAINMENT DESIGN			
5-09557	9-11991	12-09557	17-09557	5-10578	6-10578	6-10761	6-10763
17-11962	17-11991	18-11426	18-11991	6-10764	7-10578	7-10761	7-10763
CHROMATOGRAPHY				7-10764	8-10761	8-10763	8-10764
7-10175				11-09772	11-09862	11-10288	11-10289
CHROMIUM				11-11585	11-11509	11-11591	11-11592
14-11343	15-11960			CONTAINMENT FILTERING SYSTEM			
CIRCULATION, NATURAL (LOOPS AND REACTORS)				5-10578	6-10578	7-07742	7-10578
6-09702	6-09739	19-09739		7-12072	7-12077	11-10901	17-07742
CIVIL DEFENSE				18-10001			
15-11653	15-11656	15-11658	15-11659	CONTAINMENT INSTRUMENTATION			
CLAD				5-10578	6-10578	6-11472	7-10578
5-11299	6-09699	7-09537	7-10296	9-10913	9-11472	9-11485	11-11537
7-10583	8-10399	17-10102	17-11242	12-11537	18-10913	18-11537	
17-11243	17-11669	18-12033		CONTAINMENT INTEGRITY			
COALESCENCE				1-10251	3-10251	11-09604	11-10166
7-10580				11-10259	11-11447	11-11590	11-11977
COATED PARTICLE				11-11978	11-11979		
7-09519	7-09536	7-12079	17-12000	CONTAINMENT LEAKAGE CONTROL			
COBALT				5-09687	11-07744	11-07745	11-07746
14-11357	14-11522	15-09563	15-10092	11-09687	11-09750	11-10902	17-07744
15-11523	15-11655	15-11960	17-09563	17-07745	17-07746	18-09687	18-10902
CODES AND STANDARDS				18-11736			
3-11423	11-10220	11-10259	11-10745	CONTAINMENT PENETRATION			
14-09877				9-11839	11-11397	11-11446	11-11589
COMBUSTION				11-11977			
4-11493	8-10256	8-10304	8-11493	CONTAINMENT PENETRATION, CLOSURE OF			
COMPARISON, THEORY AND EXPERIENCE				5-11739	9-10911	11-10911	11-10923
1-11410	5-09549	5-09626	5-10215	12-11581	18-10911	18-10923	18-11581
5-10216	6-09704	6-09706	6-09723	18-11736	18-11738	18-11739	
6-09739	6-09825	6-09944	6-10143	CONTAINMENT REFERENCE MEASURING SYSTEM			
6-11023	9-09944	9-10143	9-10154	11-09750			
9-11023	9-11489	11-10188	11-10259	CONTAINMENT RESEARCH AND DEVELOPMENT			
11-10745	11-11977	17-09944	17-11625	11-11585	11-11592	11-11630	11-11631
18-11738	19-09739			11-11632	11-11977		
COMPUTER PROGRAM				CONTAINMENT SPRAY			
1-09576	1-10115	1-10122	1-12038	5-11739	11-10903	12-11533	18-10903
1-12041	4-05688	5-10320	5-10475	18-11533	18-11738	18-11739	
5-11383	5-12041	6-09701	6-09710	CONTAINMENT STRUCTURE			
6-09713	6-09718	6-09721	6-09723	11-09750	11-09860	11-09861	11-10167
6-09739	6-10287	6-10389	6-12091	11-10168	11-10169	11-10170	11-10171
7-09832	7-10179	8-09701	9-10287	11-10185	11-10186	11-10260	11-11458
9-10389	9-12091	11-09860	11-10169	11-11591	11-11977	12-09831	13-09831
11-10170	11-10171	11-10189	11-10220	17-11966	18-09831	18-11736	
11-10320	11-10745	11-11449	11-11584	CONTAINMENT SYSTEM, OPERATION OF			
11-11630	11-11631	11-11976	11-11977	1-10114	11-10114	13-10114	
11-12039	13-09576	14-11479	14-11662	CONTAINMENT VESSEL LOADING			
15-09876	15-10475	15-11662	17-12038	11-11446	11-11584	11-11591	
18-10475	19-09739	19-12041		CONTAINMENT, FUEL REPROCESSING			
COMPUTER PROGRAM, METEOROLOGICAL				1-09968	3-09968	13-09968	
16-11280	16-11984	16-11985		CONTAINMENT, GENERAL			
COMPUTER, ANALOG				1-10405	5-09687	7-09758	7-10581
1-12038	4-11500	6-10287	6-10389	11-09687	11-09863	11-09864	12-09831
6-11483	6-11049	7-07763	9-10287	13-09831	18-09687	18-09831	18-11738
9-10383	9-10389	9-12086	16-09651	18-12045			
17-07763	17-12038			CONTAINMENT, HIGH PRESSURE			
COMPUTER, DIGITAL				5-10320	6-12037	11-09750	11-09772
1-09576	1-09992	1-10656	1-10824	11-09773	11-09974	11-10320	11-11397
1-10932	5-11383	5-11387	6-09704	11-11446	11-11590	11-12037	18-09453
6-09822	6-09944	6-10065	6-10287	18-09974	18-12037		
6-10389	6-11281	6-11484	6-11598	CONTAINMENT, LOW PRESSURE			
9-07762	9-09866	9-09944	9-10287	9-07758	11-09750	17-07758	
9-10389	9-10826	11-12039	13-09576	CONTAINMENT, MISSILE GENERATION AND PROTECTION			
13-09992	13-10656	13-11484	17-07762	5-10919	11-11446	11-11978	11-11979
17-09944	17-11143	17-11144		18-10919			
CONCRETE				CONTAINMENT, PRESSURE SUPPRESSION			

11-09750	11-10319			CORE COMPONENTS, MISCELLANEOUS			
CONTAINMENT, PRESSURE VENTING				17-11101	17-11625	17-11667	
11-09750				CORE MELTDOWN			
CONTAINMENT, PRESSURE VESSEL				5-10407	5-11756	5-11761	7-10407
5-09687	5-09814	5-10174	5-11234	CORE SPRAY			
6-12035	7-10174	9-11999	11-09687	5-11756	7-09598	12-11533	12-11534
11-09756	11-09759	11-09773	11-09774	12-11535	17-11966	18-11533	18-11534
11-09821	11-09861	11-09863	11-09864	18-11535	18-11536	18-11903	18-11952
11-10166	11-10167	11-10168	11-10169	18-12044	18-12045		
11-10171	11-10174	11-10187	11-10220	CORROSION			
11-10260	11-10288	11-10744	11-10745	5-09920	5-09959	7-09596	7-09597
11-11234	11-11310	11-11445	11-11446	7-09598	11-09920	12-07702	12-10312
11-11447	11-11508	11-11509	11-11584	17-07702	17-07707	17-10095	17-11101
11-11585	11-11587	11-11589	11-11590	17-11245	17-11962	17-11968	17-11998
11-11592	11-11632	11-11766	11-11768	COSMIC RADIATION			
11-11769	11-11979	11-12039	11-12040	4-09600	4-09608	15-11826	
14-11905	15-11905	17-07704	17-07705	COUNTER			
17-07706	17-09814	17-11087	17-11241	9-11772	14-11823	15-09510	15-09875
17-11332	17-11667	17-11807	17-11965	15-11470	15-11655	15-11658	15-11660
17-11970	17-11999	18-09687	18-11234	15-11811	15-11832		
18-11337	18-11902	18-11905	18-12028	COUNTER, WHOLE BODY			
18-12035				15-08806	15-11342	15-11525	
CONTAINMENT, SHOCK GENERATION AND PROTECTION				COUPLED CORES			
6-12035	11-11586	11-11767	11-11976	4-09577	6-09577		
11-11978	11-11979	18-12035		CP-5 (CHICAGO PILE NO. 5)			
CONTAINMENT, UNDERGROUND				16-09568			
11-10319				CREEP BEHAVIOR			
CONTAINMENT, WATER FILLED				5-09959	11-09860	11-09864	11-10168
11-11446	11-11508			11-10259	11-10260	11-11377	11-11445
CONTAMINATION				11-11449	11-11587	11-11589	11-11622
12-10262	12-10312	14-11135	14-11823	CREEP PROPERTY			
15-11476	15-11802	15-11825	17-09306	5-09917	5-09920	11-09917	11-09920
17-10262	17-11801	17-11941		11-10260	11-11445		
CONTROL ROD				CRITICAL ASSEMBLY FACILITY			
5-11384	6-07756	6-11006	8-10910	1-10695	6-07756	6-09704	6-09705
9-07761	9-10500	9-10910	9-11006	6-09706	6-09707	6-09714	6-10695
17-07701	17-07756	17-07761	17-09942	8-09714	17-07756	18-09770	18-11093
17-09945	17-11149	17-11965	17-11968	18-11294	18-11603		
18-10910				CRITICALITY EXPERIMENT			
CONTROL ROD CALIBRATION				1-08441	1-09703	1-09992	1-10122
6-10139	6-11284	9-10139	9-11991	1-10618	1-10619	1-10695	1-10825
17-11969	17-11991	18-11991		1-11161	6-08441	6-09701	6-09703
CONTROL ROD DRIVE				6-09705	6-09715	6-09915	6-10139
9-07760	9-10280	9-10439	17-07705	6-10619	6-10695	6-11161	6-11484
17-07708	17-07760	17-10280	17-11965	8-09701	9-09915	9-10139	13-09992
17-11968				13-10825	13-11484	18-09770	
CONTROL ROD FABRICATION				CRITICALITY SAFETY			
9-10014	9-10500			1-08441	1-09576	1-09992	1-10115
CONTROL ROD SCRAM MECHANISM				1-10122	1-10257	1-10412	1-10618
6-10133	8-10133	9-10280	12-11581	1-10619	1-10656	1-10718	1-10805
17-10280	18-10133	18-11581		1-10824	1-10825	1-10932	1-11407
CONTROL ROD WORTH				3-11302	3-11423	6-08441	6-10619
1-09703	1-10805	6-09703	6-09705	6-10805	12-10718	13-09576	13-09992
6-09714	6-09915	6-09941	6-10139	13-10257	13-10656	13-10825	13-12036
6-10805	6-11023	6-11268	6-11284	18-10257	18-12036		
6-11484	6-11849	6-12091	8-09714	CRUD			
9-09915	9-10139	9-10826	9-11023	17-11667	17-11990		
9-12091	13-11484	14-11268	17-09799	CSE (CONTAINMENT SYSTEMS EXPERIMENT)			
17-10125				11-11976			
CONTROL ROD, SHIM SAFETY				CURIUM			
5-10926	6-11808	9-10913	17-07752	15-11595			
17-11087	17-11244	17-11625	17-11808	CVTR (CAROLINAS VIRGINIA TUBE REACTOR)			
18-10913	18-10926			17-07748	17-10205	17-11145	18-10205
CONTROL SYSTEM				CYLINDER			
4-11495	4-11500	6-10287	6-10389	11-10185	11-10186	11-10188	11-10189
6-11268	6-11375	6-11483	6-12092	11-10745	11-11446	11-11447	11-11448
9-10148	9-10150	9-10287	9-10383	11-11449	11-11508	11-11587	11-11977
9-10387	9-10389	9-10466	9-11993	CZECHOSLOVAKIA			
9-12082	9-12092	9-12093	14-11268	1-10115			
17-10148	17-11612	17-11993		DAMAGE			
CONTROL, COMPUTER				17-11243	17-11244	17-11667	
9-07762	9-07763	9-11110	9-11628	DANGER COEFFICIENT			
17-07762	17-07763			6-11268	14-11268	17-09942	
CONTROL, GENERAL				DATA PROCESSING			
6-11006	6-11797	9-11006	17-11621	9-11487	17-11143		
17-11797				DECAY HEAT			
CONVECTIVE BOILING				1-09686	5-09686	5-10908	6-09701
5-09779	5-09843	5-10217	5-10271	8-09701	9-11845	10-10908	18-10908
5-11226	5-11758	6-09702		DECONTAMINATION			
COOLANT CHEMISTRY				7-09758	12-09791	12-09831	12-10262
5-09557	5-11299	7-09598	9-11991	12-10312	13-09791	13-09831	14-11817
12-09557	17-07707	17-07743	17-07752	14-11823	15-11421	15-11783	15-11825
17-07754	17-09557	17-11338	17-11734	17-07741	17-10262	18-09831	
17-11991	17-11998	18-11991		DEFORMATION			
COOLANT PURIFICATION SYSTEM				11-10185	11-10186	11-10188	11-10189
17-11605				11-10260	11-11445	11-11448	11-11587
COOLANT SYSTEM				11-11589	11-11622		
3-09526	6-11268	9-12082	12-11533	DELAYED NEUTRON			
14-11268	17-11616	18-11533		1-11161	6-09541	6-09701	6-09712
COPPER				6-09985	6-10144	6-10828	6-11161
9-10014				6-11638	8-09701	9-10144	

DENMARK				15-09499	15-11812		
1-09997	1-10255	5-11151	18-11151	DOSIMETRY, RADIOPHOTOLUMINESCENCE			
DEPOSITION				9-11629			
5-11376	7-09229	7-09582	7-09832	DOSIMETRY, THERMOLUMINESCENCE			
7-11376	14-11479	14-11633	15-11528	9-11764	15-09499	15-10076	15-10084
15-11633	16-11279	16-11984	16-12018	15-10100	15-11764	15-11812	15-11827
DESIGN CRITERIA				DOUNREAY (UK)			
1-10257	4-09685	5-10919	5-10920	1-10152	6-11849	7-09702	18-10152
5-10921	5-10922	5-10926	9-10136	DRESDEN I			
9-10153	9-10439	10-10283	11-09821	17-11111			
11-09974	11-10220	11-10745	11-10923	DRESDEN II			
11-11591	11-11978	12-09831	13-09831	18-11944			
13-10257	14-10924	14-10925	14-11356	DRESDEN III			
15-10153	17-10172	18-09831	18-09974	18-11944			
18-10257	18-10919	18-10920	18-10921	DROPLET			
18-10922	18-10923	18-10924	18-10925	5-09549	5-11756		
18-10926	18-11229	18-11737	18-11740	DUNGENESS B (UK)			
18-11944				18-10340			
DESIGN STUDY				DYNAMICS, NONLINEAR			
1-10152	1-10257	1-10404	1-11398	6-09702	6-09739	6-09822	6-09985
6-09713	6-10287	6-10389	8-10111	6-11440	6-11638	19-09739	
8-10113	9-10287	9-10383	9-10389	EARTHQUAKE			
11-11583	12-10111	13-10257	14-11356	11-09863	11-11767		
15-11421	18-10152	18-10173	18-10257	EBOR (EXPERIMENTAL BERYLLIUM OXIDE REACTOR)			
18-10404	18-11236			17-11794			
DESORPTION				EBR I AND II (EXPERIMENTAL BREEDER REACTORS)			
7-09832	14-11354	15-11354		6-09709	6-09711	6-09822	6-10058
DESTRUCTIVE TRANSIENT				6-10064	6-10127	6-10139	7-09711
5-11411	6-09781	7-09781		9-09717	9-10139	9-10280	11-07746
DEUTERIUM				17-07708	17-07714	17-07746	17-10280
9-10285				17-10281	17-10762		
DIETARY HABIT				EBWR (EXPERIMENTAL BOILING WATER REACTOR)			
15-11957				1-09703	6-09703	6-09739	6-09985
DIFFUSION				9-11765	17-10125	19-09739	
7-09362	7-09372	7-09521	7-09537	ECOLOGICAL CONSIDERATION			
7-09597	7-09753	7-09757	7-09764	14-09539	14-11319	14-11354	14-11531
7-10179	7-10584	7-10590	14-11305	14-11633	14-11774	15-11319	15-11354
DIFFUSION CHANNEL				15-11358	15-11523	15-11531	15-11594
7-09757	7-09764			15-11633	15-11958		
DIFFUSION COEFFICIENT				ECONOMIC STUDY			
7-09372	7-09521	7-09537	7-10583	1-10409	1-11398	3-11302	3-11381
14-10915	15-11481	18-10915		ECONOMICS			
DILUTION				1-09686	5-09686	17-09797	17-09799
6-10907	16-10775	18-10907		17-11112	17-11140	17-11141	17-11142
DISPERSION				17-11150	17-11334	17-11442	18-12043
14-11343	16-10775			EFFLUENT			
DNB (DEPARTURE FROM NUCLEATE BOILING)				7-09545	14-11357	14-11959	15-11523
5-09843	5-10900	5-11395	5-11455	15-11959			
5-11466	5-11760	5-12237	18-10900	EGCR (EXPERIMENTAL GAS COOLED REACTOR)			
DOPPLER COEFFICIENT				5-11384	5-11761	6-11267	6-11472
6-09707	6-11638	6-11843	9-11843	8-10110	9-10383	9-10500	9-11472
DOPPLER EFFECT				9-11485	11-11397	12-11733	17-11677
6-09358	6-09542	6-09705	6-09706	EGYPT			
6-09707	6-09713	6-09714	6-09718	15-11961			
6-09723	6-10133	6-10822	6-11006	ELASTICITY			
8-09714	8-10133	9-11006	18-10133	11-09861	11-10165	11-10167	11-10169
DOSE				11-10170	11-10171	11-10186	11-10188
2-09544	4-09600	4-09608	4-09726	11-10189	11-10220	11-10260	11-10745
11-10904	14-09877	14-11353	14-11356	11-11509	11-11583	11-11584	11-11588
14-11786	15-09499	15-09510	15-09569	11-11589	11-11622	11-11630	11-11631
15-09726	15-09875	15-11353	15-11409	11-11766	11-11767	11-11769	
15-11526	15-11782	15-11812	15-11813	ELECTRIC POWER, AUXILIARY			
15-11825	15-11973	15-11974	15-11975	9-11488	10-10283		
18-10904				ELECTRIC POWER, GENERAL			
DOSE CALCULATION, EXTERNAL				10-10283			
5-10475	5-10917	5-10922	6-09701	ELECTRIC POWER, SHUTDOWN			
8-09701	14-10924	14-11353	15-10092	10-10283			
15-10100	15-10475	15-11353	15-11359	ELECTRIC POWER, VITAL			
15-11476	15-11523	15-11658	18-10475	9-11488	10-10457	17-11087	18-10457
18-10917	18-10922	18-10924	18-11538	ELECTRON MICROSCOPY			
DOSE CALCULATION, INTERNAL				5-09918	5-09921	11-09918	11-09921
4-09726	5-10475	5-10917	14-11353	ELECTROSTATIC CHARGE			
14-11633	15-08806	15-09726	15-10475	7-09361	7-09363	7-09364	7-10175
15-11353	15-11477	15-11482	15-11523	7-12074			
15-11530	15-11633	15-11800	15-11803	ELK RIVER			
17-11800	17-11947	18-10475	18-10917	6-10822	9-11991	17-11087	17-11241
DOSE MEASUREMENT, EXTERNAL				17-11244	17-11245	17-11339	17-11965
5-10430	6-10430	9-11762	9-11764	17-11966	17-11967	17-11968	17-11969
14-11353	14-11809	14-11829	15-09584	17-11970	17-11991	18-11991	
15-09755	15-10076	15-10084	15-10092	EMBRIEMENT			
15-10100	15-11353	15-11359	15-11658	1-10250	5-09965	5-09966	5-11233
15-11764	15-11809	15-11810	15-11828	5-11234	5-11299	7-09965	7-09966
15-11829	15-11961	17-09755	19-10430	11-09965	11-09966	11-10187	11-11234
DOSE MEASUREMENT, INTERNAL				11-11377	11-11447	11-11509	11-11590
15-08806	15-09563	15-11800	15-11803	17-11244	18-11233	18-11234	
15-11813	17-09563	17-11800		EMERGENCY COOLING			
DOSIMETRY, GENERAL				2-11805	5-11805	11-11532	11-11537
9-11764	15-09499	15-09584	15-09875	12-11532	12-11537	12-11581	14-11905
15-10100	15-10253	15-11764	15-11783	15-11905	18-11537	18-11537	18-11538
15-11812	15-11825	15-11826		18-11581	18-11805	18-11902	18-11903
DOSIMETRY, PHOTOGRAPHIC				18-11905	18-11952	18-12028	

EMERGENCY POWER, ELECTRIC	17-11137	17-11413	17-11669	17-11734
9-11488 10-10283 10-10905 18-10905	17-11945	18-11086	18-11540	
EMERGENCY POWER, NONELECTRIC	FAILURE, GENERAL			
5-10908 10-10908 18-10908	7-09758	9-09943	9-10155	11-10185
ENEA (EUROPEAN NUCLEAR ENERGY AGENCY)	11-11622	11-11977	11-11978	17-09943
1-10254	17-09945	17-10155	17-11092	17-11101
ENERGY SOURCE	17-11332			
6-09701 8-09701 8-10910 9-10910	FAILURE, INSTRUMENT			
11-10289 18-10910	9-09943 17-09943	17-11425		
ENGINEERED SAFEGUARD	FAILURE, OPERATOR ERROR			
1-10405 2-09544 5-10919 7-12077	13-11942 15-09562	15-09755	17-09277	
9-10913 10-10905 11-11532 11-11537	17-09278 17-09280	17-09302	17-09562	
12-11532 12-11533 12-11537 18-09453	17-09755 17-09818	17-11369	17-11613	
18-10905 18-10913 18-10919 18-11532	17-11618 17-11788	17-11801	17-11942	
18-11533 18-11537 18-11738	17-11946			
ENGINEERING DRAWING LIST	FAILURE, PIPE			
18-09276	5-09921 5-10920	5-10921	11-09921	
EQUATION OF STATE	11-10166 11-10259	11-11630	11-11631	
5-10553 6-10058 6-10065 6-10128	11-11769 17-11138	17-11962	17-11963	
6-10761 6-10763 6-10764 7-10761	18-10920 18-10921			
7-10763 7-10764 8-10761 8-10763	FAILURE, PRESSURE VESSEL			
8-10764	11-09759 11-10166	11-10187	11-10220	
EQUATION, GENERAL	11-11446 11-11447	11-11508	11-11509	
1-09995 6-09995 7-12075 16-11262	11-11584 11-11590	11-11632	11-11766	
16-11263 16-11985 16-12017	11-11768 11-11769	17-11970		
EQUATION, NONLINEAR	FAILURE, SCRAM MECHANISM			
6-09822	9-07757 9-07758	9-07761	9-10148	
EQUIPMENT DESIGN	9-10280 17-07757	17-07758	17-07761	
3-11423 5-09920 9-10286 9-10466	17-10148 17-10280	17-11734	17-11794	
11-09920	18-12032			
ETR (ENGINEERING TEST REACTOR)	FAILURE, SEQUENTIAL			
17-11367	17-11611			
EURATOM	FAILURE, SIMULTANEOUS			
1-10254 1-12022 15-11527 16-10768	11-11953 17-11953			
EUROCHEMIC	FALLOUT			
1-09968 3-09968 13-09968	14-11345 14-11353	14-11355	14-11479	
EVAPORATION	14-11524 14-11777	14-11819	14-11822	
13-11942 17-11942	14-11829 15-11134	15-11340	15-11342	
EXAMINATION	15-11345 15-11353	15-11355	15-11358	
6-11808 17-11625 17-11808 17-11998	15-11359 15-11421	15-11528	15-11529	
EXCURSION, LARGE	15-11596 15-11623	15-11624	15-11777	
5-09687 9-07757 9-10439 11-09687	15-11780 15-11810	15-11811	15-11818	
11-11446 11-11978 11-11979 17-07757	15-11819 15-11822	15-11828	15-11829	
18-09687	15-11957 16-09574	16-09651	16-10768	
EXPANSION REACTIVITY EFFECT	16-10772 16-11985			
6-09714 8-09714	FARET (FAST ARGONNE REACTOR EXPERIMENT TEST)			
EXPERIMENT, GENERAL	5-10430 6-09915	6-10430	8-11403	
1-09703 4-09681 4-09682 6-09703	9-09915 18-09914	19-10430		
6-09714 6-09723 6-09741 6-11023	FAST NEUTRON			
8-09714 9-11023	1-10250 1-10718	12-10718	15-09499	
EXPLOSION	15-09584			
1-10412 4-11503 8-10256 11-11446	FERMI			
11-11590 11-11978 11-11979 17-11599	7-11945 9-11441	17-11138	17-11945	
17-11600 17-11609 17-11610 17-11614	FILM, GENERAL			
17-11615 17-11617 17-11618 17-11668	5-09557 12-09557	17-09557		
FABRICATION	FILM, LIQUID			
18-11337	5-11392 5-11748			
FAILURE, ADMINISTRATIVE CONTROL	FILTER			
11-09307 12-09307 13-09304 17-09304	5-10174 7-08811	7-09362	7-09364	
17-09307 17-11613 17-11787 17-11788	7-09367 7-09536	7-09758	7-10174	
17-11789 17-11790 17-11946 17-11950	7-10270 11-10174	16-10768	18-10270	
FAILURE, CLADDING	FILTER CHARACTERISTICS			
5-11990 5-11992 6-09711 6-09741	7-09362 7-09367			
6-10062 7-07742 7-09677 7-09711	FILTER DESIGN			
11-10187 11-12042 17-07742 17-09301	7-09362 7-09367			
17-10762 17-11964 17-11972 17-11990	FILTER EFFICIENCY			
17-11992	11-11953 17-11619	17-11953		
FAILURE, COATED PARTICLE	FILTER OPERATION			
7-12079	7-09367			
FAILURE, COMPONENT	FILTER SAFETY EVALUATION			
6-09709 9-10154 12-09534 17-07738	7-12072 7-12077			
17-07747 17-09280 17-09309 17-09754	FILTER SPRAY			
17-09786 17-11796 17-11966 17-11968	7-12072			
FAILURE, DESIGN ERROR	FILTER SYSTEM			
9-10148 11-09307 12-09307 15-09562	7-12072 7-12077			
17-09307 17-09562 17-10148 17-10163	FILTER THEORY, DIFFUSION			
FAILURE, EQUIPMENT	7-09362 7-09364			
11-11953 12-09534 17-07701 17-07703	FILTER THEORY, IMPACTION			
17-07705 17-07708 17-07753 17-11611	7-09362 7-09364			
17-11612 17-11613 17-11953	FILTER THEORY, INTERCEPTION			
FAILURE, FATIGUE	7-09362 7-09364			
5-10756 11-09307 11-09604 11-10166	FILTER, COMBINATION			
11-10187 11-10220 11-10259 11-11377	5-10174 7-09758	7-10174	11-10174	
11-11584 11-11590 11-11630 11-11631	FILTER, DAMAGED			
11-11632 12-09307 17-07704 17-07705	17-10204			
17-09307 17-09798 17-11966	FILTER, EFFICIENCY OF			
FAILURE, FUEL ELEMENT	7-09362 7-09367			
6-09711 6-09716 7-07739 7-09595	FILTER, FIBER			
7-09677 7-09711 7-11945 8-11413	7-09362 7-09364	7-09367		
9-09578 9-09716 11-11588 12-10312	FILTER, FIBERGLASS			
14-11086 17-07707 17-07739 17-07740	7-08811			

FILTER, HIGH EFFICIENCY				5-09639	5-10216	5-10217	5-10271
7-08811				5-10572	5-11226	5-11388	5-11389
FILTER, MAY PACK				5-11469	5-11475		
5-10174	7-10174	11-10174		FLOW, TURBULENT			
FILTRATION				5-10750	5-11389	5-11475	5-11748
14-11522	15-11360			FLOW, TWO PHASE			
FINLAND				5-09555	5-09639	5-09959	5-10212
15-11958				5-10213	5-10214	5-10454	5-11172
FIRE				5-11226	5-11749	5-11758	5-11759
1-10251	1-10412	3-10251	4-09681	5-12237	6-09721	6-10057	8-10454
6-09743	6-11268	7-11270	8-09743	18-10454			
8-10304	11-10901	13-09305	13-09368	FLUCTUATION			
14-11268	17-09305	17-09368	17-09754	5-10750	5-10753	5-10756	5-11171
17-10135	17-10163	17-10747	17-11601	5-11385	5-11387	5-11393	5-11749
17-11606	17-11616	17-11619	17-11801	6-09738			
18-10901	18-11270	18-11904		FLUORINE			
FISSION GAS RELEASE				7-09765			
7-09372	7-10296	9-11842	14-10924	FLUX DISTRIBUTION			
17-09813	17-10762	18-10924		6-09705	6-10060	6-11440	
FISSION PRODUCT RELEASE, GENERAL				FLUX TILT			
2-09544	5-10174	5-10407	5-10475	9-10914	18-10914		
5-11376	7-09537	7-09758	7-10174	FOAM			
7-10178	7-10179	7-10407	7-10582	14-11522			
7-11376	7-12079	11-10174	14-11633	FPCE PLANT			
15-10475	15-11633	18-10475		2-10600	12-10600	13-10600	
FISSION PRODUCT RETENTION				FRANCE			
7-12077	7-12079	18-11738	18-12045	1-11399	1-12041	5-11411	5-12041
FISSION PRODUCT TRANSPORT				6-10133	8-10133	12-09548	18-10133
5-10174	5-10407	5-10578	5-11376	19-12041			
6-10578	7-09229	7-09536	7-09537	FRCTF (FAST REACTOR CORE TEST FACILITY)			
7-09582	7-09597	7-09753	7-09758	5-11299			
7-09832	7-10174	7-10178	7-10179	FREQUENCY SPECTRA			
7-10407	7-10578	7-10583	7-11376	16-10916	18-10916		
11-10174	14-11702	17-12000		FT. ST. VRAIN			
FISSION PRODUCT, AIRBORNE				18-11902			
7-10177	14-11479			FUEL BURNUP			
FISSION PRODUCT, IODINE				5-10454	7-09372	7-12079	8-10454
5-10174	5-12076	7-09536	7-09677	17-09588	17-10102	17-10762	17-11145
7-09758	7-10174	7-10178	7-12076	17-11147	18-10454	18-11235	18-11740
7-12077	11-10174	11-10903	14-11633	FUEL ELEMENT			
15-11633	17-09306	18-10903		3-09564	5-09552	5-09557	5-09778
FISSION PRODUCT, NONVOLATILE				5-09779	5-10755	5-10756	5-10926
7-09758				5-11151	5-11387	5-11466	5-11758
FISSION PRODUCT, SEPARATION FROM WASTE				5-11759	5-12237	6-09659	6-10127
2-10600	12-10600	13-10600		6-10820	7-09537	7-10296	9-11765
FISSION PRODUCT, USE OF IN WASTES				11-10165	11-11588	11-11622	11-12042
2-10600	12-10600	13-10600		12-09557	17-07752	17-07755	17-09557
FISSION PRODUCT, VOLATILE				17-09564	17-09799	17-09945	17-11087
7-09750				17-11112	17-11625	17-11998	18-09914
FISSION RECOIL				18-10926	18-11151		
7-09372				FUEL ELEMENT BOWING			
FLANGE				17-11965	17-11966		
11-09756	11-09773	11-09774	11-11310	FUEL EXPANSION COEFFICIENT			
FLAW				6-09714	6-11006	8-09714	9-11006
11-10187	11-10744	11-11447	11-11509	FUEL HANDLING			
11-11588	11-11632	11-11766	11-11768	1-09576	1-10805	3-09526	6-10805
11-11769				13-09576	17-07709	17-11734	18-11294
FLOODING COEFFICIENT				18-12032			
6-11284	6-11401			FUEL HANDLING MACHINE			
FLOW BLOCKAGE				3-09526	17-11798		
17-07740	17-09565	17-09872	17-11369	FUEL INTEGRITY			
FLOW DISTRIBUTION				7-09519	7-09595	7-10296	7-12079
5-09959	17-07705			11-11622	17-10281	17-11794	17-11972
FLOW ORIFICE OR RESTRICTION				FUEL MELTDOWN			
17-09872				5-11992	6-09711	6-10060	6-10133
FLOW STABILITY				6-10761	6-10763	6-10764	6-12035
5-09552	5-10753	5-10756	5-11171	7-09595	7-09711	7-10761	7-10763
5-11172	5-11395	5-11455	5-11749	7-10764	8-10112	8-10133	8-10397
FLOW THEORY AND EXPERIMENTS				8-10761	8-10763	8-10764	17-09871
5-09552	5-09553	5-09555	5-09959	17-10762	17-11992	18-10133	18-12035
5-10572	5-10750	5-10751	5-10752	FUEL SEGREGATION			
5-10753	5-10754	5-10756	5-11172	6-09743	8-09743		
5-11226	5-11387	5-11389	5-11392	FUEL STORAGE			
5-11393	5-11474	5-11475	5-11748	13-12036	18-12036		
5-11758				GAMMA			
FLOW, AXIAL				1-10109	6-11157	9-11999	13-10109
5-09551	5-09552	5-09778	5-09779	15-10109	17-09798	17-11999	
5-10754	5-10756	5-11297	5-11387	GAMMA EMITTER			
FLOW, CROSS				9-10151			
5-10753	5-11386			GENERATOR, DIESEL			
FLOW, HIGH SPEED				9-11488			
17-07751	18-10918	18-10918		GEOLOGICAL CONSIDERATION, GENERAL			
FLOW, LAMINAR				11-09863	11-11767	14-11135	15-11653
5-10751	5-10754	5-11297	5-11389	15-11656	15-11659	17-09310	
5-11474	5-11475			GEOLOGICAL CONSIDERATION, GEOCHEMICAL			
FLOW, NONNEWTONIAN				14-11821	15-11821		
5-11297				GEOLOGICAL CONSIDERATION, GEOPHYSICAL			
FLOW, PULSATING				14-11634	14-11816	15-11307	15-11634
5-09551	5-11171	6-09702		GEOLOGICAL CONSIDERATION, STRATIGRAPHY			
FLOW, TUBE				15-11659			
5-09550	5-09551	5-09552	5-09555	GERMANY			

1-11398	1-12022	5-10320	6-11268	HEAT TRANSFER ANALYSIS			
11-10320	14-11268	15-10253	15-11814	3-11847	5-09550	5-09551	5-09553
16-10772	17-09859	17-11602		5-09555	5-09556	5-09626	5-09627
GETR (GENERAL ELECTRIC TEST REACTOR)				5-09996	5-10005	5-10271	5-10572
17-07701	17-09309	17-09818	18-11791	5-10755	5-11171	5-11297	5-11383
GLASS				5-11384	5-11386	5-11387	5-11388
14-11661				5-11389	5-11391	5-11469	5-11474
GLOVE BOX				5-11670	12-11535	17-11670	18-11535
7-08811	12-09831	13-09304	13-09831	HEAT TRANSFER AUGMENTATION			
17-09304	17-10135	17-11615	17-11617	5-09551	5-09556	5-09589	5-10572
17-11801	18-09831			5-10751	5-10752	5-10753	
GOLD				HEAT TRANSFER CORRELATION			
14-11343				5-09549	5-09550	5-09553	5-09627
GRAPHITE				5-09843	5-09996	5-10208	5-10216
5-08969	5-10174	5-12073	6-09781	5-10218	5-10271	5-11385	5-11386
7-09519	7-09765	7-09781	7-10174	5-11387	5-11390	5-11469	18-11738
7-10584	8-10110	8-10304	11-10174	HEAT TRANSFER EXPERIMENT			
11-11588	17-11676	17-12000		3-11847	5-09549	5-09550	5-09551
GROSS ALPHA				5-09555	5-09626	5-09639	5-09778
15-11306	15-11660	15-11811	15-11832	5-09779	5-09843	5-09996	5-10207
GROSS BETA				5-10208	5-10209	5-10210	5-10211
14-11347	14-11354	15-09875	15-10100	5-10213	5-10214	5-10215	5-10216
15-11306	15-11354	15-11660	15-11810	5-10217	5-10218	5-11385	5-11389
15-11811				5-11390	5-11456	5-11466	5-11469
GROSS GAMMA				5-11474	5-11755	5-11756	5-12237
14-11354	15-09569	15-11306	15-11354	6-09742	12-11535	18-11535	
15-11596	15-11659	15-11811	15-11973	HEAT TRANSFER, BOILING			
GROUND WATER, PROPERTY				5-09555	5-09589	5-09779	5-09843
14-11343				5-09959	5-10208	5-10209	5-10211
GROUND WATER, TRACER				5-10213	5-10214	5-10215	5-10216
14-11343				5-10217	5-10271	5-10572	5-11172
HAFNIUM				5-11226	5-11388	5-11390	5-11395
6-11484	13-11484	14-11343		5-11455	5-11466	5-11749	5-11758
HALDEN				5-11759	5-11760		
6-11843	9-11838	9-11839	9-11840	HEAT TRANSFER, CONVECTION			
9-11841	9-11842	9-11843	9-11844	5-09550	5-09551	5-09556	5-09626
9-11845	9-11999	17-11844	17-11999	5-09627	5-09778	5-10005	5-10209
HALLAM				5-10752	5-11469	5-11474	9-11840
17-07738	18-11333	18-11428		HEAT TRANSFER, NATURAL CONVECTION			
HANFORD PRODUCTION REACTOR				5-09556	5-11389	5-11391	6-09702
1-08785				HEAT TRANSFER, RADIANT			
HANFORD SITE				5-09556	5-10207	5-11757	
1-07718	1-10718	1-10825	9-09578	HEAT TRANSFER, SUPERCRITICAL			
12-07702	12-10718	13-10825	17-07702	5-11388			
17-07711	17-07718	17-11143		HEAVY WATER			
HARWELL (UK)				1-11160	9-10285	17-07753	
1-10252	15-10252			HELIUM			
HAZARD, RELATIVE				5-11748	7-09229	9-09801	11-11458
1-10412	1-11410			17-12000			
HAZARDS ANALYSIS				HFBR (HIGH FLUX BEAM REACTOR)			
2-10600	4-09600	4-09608	12-10600	11-07744	17-07744	17-11136	
13-10600	15-11476	15-11523		HFIR (HIGH FLUX ISOTOPE REACTOR)			
HBWR (HALDEN BOILING WATER REACTOR)				6-10059	6-10060	6-10064	6-10126
6-11843	9-11838	9-11840	9-11841	6-10144	9-10144	9-10387	17-07750
9-11842	9-11843	9-11844	9-11845	17-11988			
17-11844				HIGH TEMPERATURE			
HEAT CONDUCTION				1-10251	3-10251	3-11382	6-09711
5-10005	5-10755	5-11383	9-11841	6-09743	6-10128	7-09711	7-11382
14-11356	14-11662	15-11662		8-09743	8-10110	8-11402	9-09801
HEAT EXCHANGER				9-12081	11-09860	11-09864	11-10165
5-09589	5-09627	5-09996	5-10207	11-10168	11-10189	11-10220	11-10260
5-10218	5-10921	5-11386	5-11390	11-11445	11-11449	11-11584	11-11592
5-11456	5-11469	5-11670	6-11486	11-11622			
17-07708	17-11338	17-11670	17-11963	HOT CELL			
18-10921				12-09791	12-09831	13-09791	13-09831
HEAT GENERATION, INTERNAL				17-11607	18-09831	18-10173	
5-10755	14-11817	17-09798		HOT SPOT			
HEAT GENERATION, NONUNIFORM				5-10900	11-10165	17-09799	18-10900
5-10755				HPRR (HEALTH PHYSICS RESEARCH REACTOR)			
HEAT SINK				9-12087			
17-09754	17-11616			HUMBOLDT BAY			
HEAT TRANSFER				2-11805	5-11805	8-09817	11-10319
4-11495	5-09549	5-09550	5-09551	12-11581	14-11086	17-09565	17-11111
5-09552	5-09553	5-09555	5-09556	17-11972	18-09817	18-11086	18-11540
5-09557	5-09589	5-09626	5-09627	18-11581	18-11805		
5-09639	5-09778	5-09779	5-09843	HUMIDITY			
5-09996	5-10005	5-10207	5-10208	16-10771			
5-10209	5-10210	5-10211	5-10214	HWCTR (HEAVY WATER COMPONENT TEST REACTOR)			
5-10215	5-10218	5-10269	5-10271	7-10270	9-07758	17-07706	17-07707
5-10407	5-10430	5-10572	5-10750	17-07758	17-11796	18-10270	
5-10751	5-10752	5-10753	5-10754	HYDRAULIC ANALYSIS			
5-10755	5-11297	5-11383	5-11385	6-09721	6-09722	6-09739	6-10057
5-11386	5-11387	5-11388	5-11389	6-10061	6-10063	6-10129	14-10915
5-11390	5-11391	5-11392	5-11455	18-10915	19-09739		
5-11456	5-11466	5-11469	5-11474	HYDRAULIC EFFECT			
5-11475	5-11748	5-11749	5-11755	5-10926	18-10926		
5-11756	5-11757	5-11758	5-11759	HYDRAULIC EXPERIMENT			
5-11760	5-11761	5-12237	6-10430	5-10208	5-10212	5-10213	5-10216
7-10407	12-09557	14-11662	14-11817	5-10753	5-11151	17-07750	18-11151
15-11662	17-09557	17-09816	17-11625	18-11152			
18-09816	19-10430			HYDRIDE			

4-09679	6-11374			9-10909	9-10910	9-10911	9-10912
HYDRODYNAMIC ANALYSIS				9-10913	9-10914	10-10905	10-10908
5-09552	5-09553	5-10754	5-11171	11-10901	11-10902	11-10903	11-10904
5-11172	5-11389	5-11392	5-11539	11-10911	11-10923	14-10915	14-10924
5-11820	8-10910	9-10910	18-10910	14-10925	16-10916	18-10900	18-10901
18-11539				18-10902	18-10903	18-10904	18-10905
HYDROGEN				18-10906	18-10907	18-10908	18-10909
5-09814	5-09966	5-10271	5-11233	18-10910	18-10911	18-10912	18-10913
5-11299	6-09705	6-11473	7-09595	18-10914	18-10915	18-10916	18-10917
7-09966	11-09966	14-11344	15-11298	18-10918	18-10918	18-10919	18-10920
17-09814	17-09859	17-09871	17-11600	18-10921	18-10922	18-10923	18-10924
17-11601	17-11668	18-11233		18-10925	18-10926	18-11237	18-12028
HYDROLOGICAL CONSIDERATION, GENERAL				INDIUM			
14-11816				14-11343			
HYDROLOGICAL CONSIDERATION, RATE OF MOVEMENT				INGESTION			
14-11343				12-09303	14-11633	15-08806	15-10134
IAEA (INTERNATIONAL ATOMIC ENERGY AGENCY)				15-11482	15-11523	15-11633	17-09303
1-10122	1-10254	1-10258	3-10258	17-10134			
17-11582				INHALATION			
ICRP (INT. COMM. ON RADIOLOGICAL PROTECTION)				7-12078	14-11633	15-08806	15-09563
4-09726	15-09776	15-11526		15-11477	15-11530	15-11633	15-11779
ICRU (INT. COMM., RAD. UNITS AND MEASUREMENTS)				17-09563	17-11796		
9-11762				INSPECTION AND COMPLIANCE			
IDAHO FALLS				17-11943	17-11949		
14-11959	15-11959			INSTABILITY			
IGNITION				11-10169	11-10185	11-10186	11-10188
4-11493	8-10304	8-10399	8-11493	11-11977			
IMPACT PROPERTY				INSTRUMENTATION CALIBRATION			
5-09920	5-09965	7-09965	11-09920	7-10582	9-11629	9-11838	15-11342
11-09965	11-11508	11-11586		15-11480	15-11714	15-11810	
IMPACT SHOCK				INSTRUMENTATION, ABNORMAL INDICATION			
11-10170	11-11446	11-11590	11-11767	9-11991	17-11338	17-11425	17-11991
11-11978	11-11979			18-11991			
IN CORE MEASUREMENT				INSTRUMENTATION, AIR SAMPLING			
8-11434	8-11440	8-11043	7-07739	15-11470			
9-11765	9-11842	9-11843	9-11845	INSTRUMENTATION, AMPLIFIER			
17-07739	17-11677			9-09865	9-10286		
IN PILE EXPERIMENT				INSTRUMENTATION, COINCIDENT			
5-10174	6-09716	6-09766	6-10058	9-10149			
7-09537	7-09598	7-09766	7-10174	INSTRUMENTATION, COMPONENT			
7-10296	8-10112	9-09716	11-10174	9-10386			
17-07700	17-09859	18-07700		INSTRUMENTATION, CONTROL			
IN PILE LOOP				6-11375	9-10136	9-10466	
5-08969	5-10174	5-11992	6-09711	INSTRUMENTATION, DETECTION FAILED FUEL ELEMENT			
6-09716	6-09766	6-10058	7-09537	9-09578	9-09717	9-10387	9-11440
7-09598	7-09711	7-09766	7-10174	9-11844	17-09565	17-11640	17-11844
7-10296	9-09716	11-10174	17-07700	INSTRUMENTATION, FLOW			
17-09818	17-09859	17-09871	17-11332	5-10216	5-11393		
17-11992	18-07700			INSTRUMENTATION, GENERAL			
INCIDENT COMPILATION				1-10409	5-10005	5-10208	5-10209
17-11801	17-11971			5-10210	5-10211	5-10212	5-10213
INCIDENT, ACTUAL, EQUIPMENT				5-10214	5-10216	5-10578	6-10128
17-10747	17-11137	17-11607	17-11611	6-10578	6-11483	6-11639	7-10578
17-11612	17-11613			9-09865	9-10387	9-10911	9-10913
INCIDENT, ACTUAL, GENERAL				9-11628	9-11639	9-11838	9-11839
1-07716	1-11443	5-11992	9-07761	9-12087	11-10289	11-10911	14-11817
9-10155	12-09303	13-09305	15-09563	18-10911	18-10913		
15-11800	17-07716	17-07761	17-09279	INSTRUMENTATION, IN CORE			
17-09303	17-09305	17-09306	17-09563	5-11739	9-09943	9-10147	9-11772
17-09811	17-10155	17-11092	17-11369	9-11838	9-11839	9-11841	9-11844
17-11425	17-11443	17-11610	17-11800	9-11845	9-11999	17-09943	17-11844
17-11801	17-11941	17-11950	17-11992	17-11999	18-11739		
INCIDENT, ACTUAL, HUMAN ERROR				INSTRUMENTATION, INDEPENDENT			
15-09562	15-09755	17-09562	17-09755	9-10912	9-11488	18-10912	
17-10135	17-11600	17-11608	17-11616	INSTRUMENTATION, LIQUID LEVEL DETECTION			
17-11789	17-11946	17-11951		6-11473	6-11639	9-10909	9-10912
INCIDENT, ACTUAL, NONNUCLEAR				9-11441	9-11639	12-11534	14-11817
16-11735	17-11600	17-11601	17-11612	17-09945	18-10909	18-10912	18-11534
17-11613	17-11614	17-11735		INSTRUMENTATION, METEOROLOGICAL			
INCIDENT, ACTUAL, NONREACTOR				16-09568	16-11280	16-11983	
13-09368	17-09368	17-09754	17-11599	INSTRUMENTATION, NUCLEAR			
17-11607	17-11610	17-11617	17-11618	6-09701	6-10139	6-10143	6-11434
INCIDENT, ACTUAL, RECOVERY FROM				6-11440	6-12092	7-09677	8-09701
15-11421	15-11803	17-09279	17-09280	9-09865	9-10136	9-10139	9-10143
17-10163				9-10147	9-10151	9-10286	9-10914
INCIDENT, SL-1				9-11487	9-11629	9-11640	9-11770
8-11412				9-11771	9-11772	9-12092	15-09584
INCINERATION				15-11480	15-11660	15-11770	15-11771
7-11270	14-11702	14-11703	14-11786	17-09811	17-10204	17-11640	18-10914
17-11609	18-11270			18-11237			
INCONEL				INSTRUMENTATION, POWER RANGE			
17-11962				9-11991	17-11991	18-11991	
INDIA				INSTRUMENTATION, PROCESS			
1-11160	15-11961			6-11472	6-11639	9-09865	9-11441
INDIAN POINT I				9-11472	9-11639	12-07702	17-07702
6-11440	15-09563	17-09563	17-09819	INSTRUMENTATION, PROTECTIVE			
17-11111	17-11243	17-11963	18-09819	9-09943	9-10136	9-11840	9-12087
INDIAN POINT II				17-09943			
5-10900	5-10906	5-10908	5-10917	INSTRUMENTATION, RADIATION MONITORING			
5-10919	5-10920	5-10921	5-10922	1-10109	7-09677	9-09865	9-10146
5-10926	6-10906	6-10907	8-10910	9-11597	9-11762	9-12088	13-10109

15-09510	15-09584	15-09875	15-09876	5-11539	5-11739	5-11761	7-10407
15-10076	15-10109	15-10134	15-11480	8-10112	8-10910	8-11405	8-11412
15-11597	15-11660	15-11813	15-11825	9-10910	11-09687	11-10259	11-10320
17-10134				11-11630	11-11631	17-11108	18-09687
INSTRUMENTATION, REDUNDANT				18-10910	18-10926	18-11094	18-11539
9-10149	9-10466			18-11739	18-12044		
INSTRUMENTATION, REGULATING				LOSS OF FLOW			
17-09786				5-09639	5-09687	6-11162	11-09687
INSTRUMENTATION, SURVEILLANCE				17-10747	18-09687		
7-09677	7-10582	9-09866		LOSS OF POWER			
INSTRUMENTATION, SWITCH				5-10908	10-10457	10-10908	18-10457
10-10457	18-10457			18-10908			
INSTRUMENTATION, TEMPERATURE				LOSS OF PRESSURE			
5-10005	6-11639	9-09801	9-11639	6-11472	9-11472		
9-11840	9-11841	9-12081	14-11817	LRL (LAWRENCE RADIATION LABORATORY)			
17-12000	18-11904			18-11804			
INSTRUMENTATION, TESTING				MAGNESIUM			
9-10136	9-10149			8-10304	8-10399		
INSURANCE				MAINTENANCE AND REPAIR			
3-11302				5-09687	11-09687	12-07702	12-09534
IODINE				12-10262	15-09563	17-07702	17-07703
5-10578	6-10578	7-09229	7-09832	17-07704	17-07705	17-07706	17-07741
7-10178	7-10270	7-10578	14-11343	17-09563	17-10262	17-11241	17-11793
14-11344	14-11633	14-11822	15-11306	17-11796	17-11988	18-09687	
15-11360	15-11530	15-11596	15-11633	MALIBU			
15-11822	15-11960	16-11986	16-11987	1-09592	18-11236		
17-11950	17-11951	18-10270		MANGANESE			
ION EXCHANGE				14-11663	15-11596	15-11957	
14-11344	14-11522	14-11774	14-11823	MASS TRANSFER			
15-11960				5-09549	5-09952	5-10750	5-10751
IONOSPHERE				5-10752	5-10753	5-10754	5-11171
16-11982				7-09952	8-09952	14-11305	
IRIDIUM				MATERIAL			
14-11343				7-09367	7-12080	8-10304	17-09942
IRON				17-12000			
5-09965	7-09965	11-09965		MATHEMATICAL STUDY			
IRRADIATION TESTING				4-09577	6-09577	6-10287	6-10389
6-09711	7-09711	7-10296	17-09818	6-11438	6-11439	6-11843	6-12091
17-09859	17-09871	17-11332	17-11625	7-12074	7-12075	8-10108	9-10150
18-09914				9-10287	9-10389	9-11597	9-11843
ISOCHEM, INC.				9-12091	11-10186	11-10189	11-10745
2-10600	12-10600	13-10600		11-11449	11-11587	11-11588	11-11767
ISOTOPIC FRACTIONATION				15-11597	15-11782		
15-11780	17-09588			MAXIMUM PERMISSIBLE BODY BURDEN			
ITALY				15-10134	15-11482	17-10134	
1-09968	3-09968	6-09781	6-10287	MAXIMUM PERMISSIBLE DOSE (MPDI)			
6-10389	7-09781	9-10287	9-10389	4-09726	15-08806	15-09726	15-11482
13-09968	17-09872	17-11431		15-11523	15-11526	15-11527	
JAPAN				MEASUREMENT, GENERAL			
2-09544	15-11956	16-11986	18-10173	6-09704	6-09706	6-09723	6-09944
KARLSRUHE				9-09944	9-10146	9-12087	16-09574
1-12022				16-11983	17-09944		
KIWI				MEASUREMENT, NOISE			
4-11500	6-12092	9-12092	9-12093	6-10144	9-10144	17-11339	
KIWI TNT (TRANSIENT NUCLEAR TEST)				MEASUREMENT, REACTIVITY			
1-10130	4-11503	6-10059	8-10130	6-09915	6-10139	6-10143	6-10144
14-11809	15-11809			6-11434	9-09915	9-10139	9-10143
KRYPTON				9-10144	9-11487	9-11597	9-11640
7-12078	15-11714			9-11770	9-11772	9-11844	9-12086
LACROSSE BOILING WATER REACTOR				15-11471	15-11597	15-11770	17-11148
5-10454	5-11539	8-10454	10-10457	17-11640	17-11844		
11-11532	11-11537	12-10456	12-11532	MEASUREMENT, STRAIN GAGE			
12-11533	12-11534	12-11535	12-11537	11-09861	11-09864	11-10220	11-10745
18-10454	18-10456	18-10457	18-11532	11-11445	11-11447	11-11509	11-11766
18-11533	18-11534	18-11535	18-11536	11-11977	17-11677		
18-11537	18-11538	18-11539		MEASUREMENT, SUBCRITICALITY			
LANTHANUM				6-10143	6-10144	9-10143	9-10144
16-11986				MEASUREMENT, TEMPERATURE			
LAPSE RATE, STABLE				9-09801	9-11838	9-12081	
14-11086	16-10916	18-10916	18-11086	MERCURY			
LASL (LOS ALAMOS SCIENTIFIC LABORATORY)				5-10218	5-11390	14-11343	
18-10123				METAL			
LAW				4-11493	5-09920	5-09952	7-09952
1-10254	1-10255	1-11408		8-09952	8-11402	8-11493	11-09604
LEAD				11-09773	11-09920	11-10166	11-10187
3-11381				11-10220	11-10744	11-11590	11-11630
LIABILITY				11-11631	11-11768	11-11769	17-11610
1-10254				METAL WATER REACTION			
LIAPUNOV'S FUNCTION				1-10130	5-10430	5-11405	6-10059
4-09577	6-09577			6-10064	6-10133	6-10430	6-10761
LICENSING STATUS OF NUCLEAR PROJECTS				6-10763	6-10764	7-10761	7-10763
1-10305	7-09545			7-10764	8-09817	8-10108	8-10111
LIQUID FUEL				8-10112	8-10113	8-10130	8-10133
3-11423	18-11426			8-10397	8-10761	8-10763	8-10764
LOFT (LOSS OF FLUID TEST)				8-11405	8-11412	12-10111	17-10762
5-10174	5-10578	5-11376	5-11391	18-09817	18-10133	19-10430	
5-11405	6-10578	7-09758	7-10174	METAL, ALKALI			
7-10578	7-11376	8-11405	11-10174	5-10215	5-10217		
LOSS OF COOLANT				METAL, LIQUID			
5-09687	5-10320	5-10407	5-10926	5-09627	5-09996	5-10207	5-10208
5-11108	5-11384	5-11391	5-11405	5-10209	5-10210	5-10211	5-10212

5-10213	5-10214	5-10215	5-10217	N S SAVANNAH			
5-10218	5-10572	5-11390	5-11456	11-11953	17-11792	17-11953	17-11954
6-09766	6-10062	7-09766	9-11441	NAK (SODIUM POTASSIUM ALLOY)			
17-11605				4-11494	17-11605		
METEOROLOGICAL SUPPORT				NDT DATA (NIL DUCTILITY TRANSITION)			
14-11633	15-11633	16-10771		17-09870	17-11966		
METEOROLOGY				NEPTUNIUM			
14-11633	15-11633	16-10771	16-10772	8-12020	15-11960		
16-11265	16-11279	16-11280	16-11735	NETHERLANDS			
17-11735				1-09968	3-09968	13-09968	15-11957
MH 1A (MOBILE HIGH POWER PLANT 1A)				17-11332			
6-12037	11-12037	18-12037		NEUTRON			
MILLSTONE POINT				6-09705	6-11434	9-10285	9-11629
18-11952				9-11772	14-11821	15-11480	15-11658
MINERAL EXCHANGE				15-11812	15-11821		
14-11344	14-11354	14-11522	14-11774	NEUTRON INTERACTION			
15-11354	15-11523			1-09995	6-09995	9-11629	
ML 1 (MOBILE LOW POWER PLANT NO. 1)				NEW ZEALAND			
17-07719	17-11101			14-11819	15-11819	16-10768	
MOCKUP				NFS (NUCLEAR FUEL SERVICES)			
5-11820				3-09564	13-11942	17-09564	17-11942
MODEPATOR				17-11943			
1-09576	5-10269	5-12073	6-07756	NICKEL			
9-10285	13-09576	17-07738	17-07756	6-09741			
MODERATOR COEFFICIENT				NIObIUM			
18-11237				1-10130	5-09959	5-09966	6-09741
MODIFICATION, SYSTEM OR EQUIPMENT				7-09966	7-10177	8-10130	8-10304
1-07718	9-07756	9-10136	11-11532	8-11402	11-09966	14-11343	15-11624
11-11537	12-11532	12-11537	17-07704	16-11986			
17-07705	17-07706	17-07710	17-07718	NITRIDE			
17-07747	17-07752	17-07758	17-09798	4-11159	5-09919	5-09965	6-11159
17-09942	17-11431	18-10832	18-11333	7-09919	7-09965	8-10304	11-09919
18-11532	18-11537			11-09965			
MOLECULAR SIEVE				NITROGEN			
7-10175				5-09965	7-09965	8-10256	11-09965
MOLTEN FUEL				NOBLE GAS			
6-09766	7-09766	9-11441		7-09521	15-11714		
MOLYBDENUM				NOISE			
6-09741	14-11343	16-11986		5-10430	6-10430	17-07701	19-10430
MONITOR, RADIATION, AIR				NOISE ANALYSIS			
9-11597	9-11762	9-11764	13-11704	1-10619	6-09543	6-09699	6-09738
14-11704	14-11829	15-09499	15-09563	6-09944	6-10143	6-10144	6-10619
15-09876	15-11470	15-11597	15-11704	6-10828	6-11157	6-11283	6-11379
15-11764	15-11828	15-11829	17-09563	6-11484	9-09944	9-10143	9-10144
MONITOR, RADIATION, BACKGROUND				13-11484	17-09944	17-10204	
13-11704	14-11704	15-11704		NORWAY			
MONITOR, RADIATION, EMERGENCY				6-11282	6-11378		
7-09677	9-10153	9-11771	13-11704	NOZZLE			
14-11704	15-10153	15-11704	15-11771	11-10220	11-10745	11-11584	11-11589
MONITOR, RADIATION, ENVIRONMENTAL				11-11977			
9-11770	9-11771	13-11704	14-11704	NPR (HANFORD NEW PRODUCTION REACTOR)			
14-11829	15-11471	15-11528	15-11704	17-11442			
15-11770	15-11771	15-11829		NRTS (NATIONAL REACTOR TEST STATION)			
MONITOR, RADIATION, GAS				5-11405	8-11405		
13-11704	14-11704	14-11817	14-11959	NRU (CHALK RIVER NATURAL URANIUM REACTOR)			
15-11704	15-11959			15-11783			
MONITOR, RADIATION, GENERAL				NSIC (NUCLEAR SAFETY INFORMATION CENTER)			
7-09758	7-10581	9-11764	13-11704	1-12019	5-10174	7-10174	7-12077
14-11704	15-09499	15-11704	15-11764	11-10174			
15-11811	15-11825			NSPP (NUCLEAR SAFETY PILOT PLANT)			
MONITOR, RADIATION, GENERAL PRACTICE				5-10174	7-10174	11-10174	
13-11704	14-11704	15-11704		NUCLEAR DETONATION			
MONITOR, RADIATION, LIQUID				14-11135	14-11524	14-11634	14-11641
7-09677	15-09499	15-11471	15-11813	14-11816	14-11821	14-11823	14-11829
MONITOR, RADIATION, NUCLEAR DETONATION				15-11595	15-11634	15-11655	15-11658
14-11829	15-11828	15-11829		15-11780	15-11821	15-11828	15-11829
MONITOR, RADIATION, PERSONNEL				16-09574	16-10772	16-11982	
9-10153	9-11764	14-11829	15-08806	NUCLEAR EXPLOSION DEBRIS			
15-09499	15-10084	15-10153	15-11764	4-09688	4-09690	14-11819	14-11823
15-11828	15-11829			15-11134	15-11780	15-11819	16-09651
MONITOR, RADIATION, SAMPLING				16-11265	16-11279	16-11982	16-11986
9-09578	13-11704	14-11704	14-11959	NUCLEAR FUEL SERVICES (NFS)			
15-11470	15-11704	15-11959		11-09307	12-09307	13-09308	17-09307
MONITOR, RADIATION, STACK				17-09308	17-09310		
9-11991	13-11704	14-11704	14-11959	NUCLEAR ROCKET			
15-11704	15-11959	17-11991	18-11991	1-11404	4-11404	6-11283	6-11438
MONITOR, RADIATION, SURFACE				6-11473	6-12092	9-12092	14-11809
9-11764	12-11733	15-11764		15-11809			
MONITORING SYSTEM				NUCLEATE BOTTLING			
9-09866	9-11770	15-11770		6-10063	6-10144	9-10144	
MONTE CARLO				OCEAN AND SEA			
1-09576	1-09995	1-10932	6-09995	11-09974	14-11641	14-11777	14-11819
13-09576	15-09569			15-11777	15-11780	15-11819	16-11262
MONTICELLO				18-09974			
18-11337				OMRE (ORGANIC MODERATED REACTOR EXPERIMENT)			
MSRE (MOLTEN SALT REACTOR EXPERIMENT)				5-09557	12-09557	17-09557	
1-12038	6-10144	9-10144	17-12038	OPERATING EXPERIENCE			
MSSR (MIXED SPECTRUM SUPERHEAT REACTOR)				1-10404	1-10838	3-09564	3-11423
6-11401				5-09814	6-09944	7-07739	7-07742
MTR (MATERIAL TESTING REACTOR)				9-07749	9-07757	9-07758	9-07762
17-11368	17-11369			9-09944	9-10148	9-10149	9-10155

9-10280	9-10914	9-11999	11-09307	12-09548	15-09402	17-09812
12-07702	12-09307	13-11942	15-11800	PHANTOM, HUMAN BODY		
17-07701	17-07702	17-07703	17-07704	15-09569		
17-07705	17-07706	17-07707	17-07711	PHILIPPINES		
17-07739	17-07741	17-07742	17-07743	17-11425		
17-07749	17-07753	17-07754	17-07755	PHOSPHATE		
17-07757	17-07758	17-07762	17-09307	15-11482		
17-09564	17-09565	17-09754	17-09798	PHOSPHORUS		
17-09799	17-09814	17-09816	17-09871	14-11344	15-11482	17-11951
17-09944	17-09945	17-10148	17-10155	PIPING		
17-10280	17-10281	17-10838	17-11092	5-11396	11-09861	11-10166
17-11111	17-11138	17-11149	17-11242	11-11630	11-11631	12-11396
17-11244	17-11425	17-11667	17-11668	PIQUA		
17-11669	17-11792	17-11800	17-11801	5-11670	17-11670	17-11734
17-11942	17-11962	17-11965	17-11966	PLANT PROTECTIVE SYSTEM		
17-11967	17-11968	17-11969	17-11970	9-10136	9-10148	9-10149
17-11988	17-11999	18-09816	18-10116	17-10148		9-10154
18-10404	18-10914	18-11094	18-11740	PLASTICITY		
18-12032				7-12080	11-09604	11-09862
OPERATING LIMITS/TECHNICAL SPECIFICATIONS				11-10185	11-10187	11-10220
2-11805	3-09850	5-11805	12-09850	11-11448	11-11508	11-11447
12-11581	14-11086	15-09850	17-09815	11-11622	11-11977	11-11509
17-09819	17-10205	17-10749	18-09819	PLOWSHARE PROGRAM		
18-10205	18-10832	18-11086	18-11094	14-11135	14-11353	14-11634
18-11419	18-11428	18-11540	18-11581	14-11821	14-11823	14-11829
18-11603	18-11791	18-11805		15-11595	15-11634	15-11821
OPERATIONS REPORTS, ANALYSIS				15-11829		15-11828
3-11302	17-11338			PLUTONIUM		
OPERATIONS REPORTS, GENERAL				1-09703	1-09992	1-10107
5-09687	11-09687	17-09872	17-11087	1-10618	1-10619	1-10825
17-11367	17-11368	17-11734	18-09687	3-11423	6-09542	3-11382
ORGANIC COOLANT				6-09707	6-09713	6-09703
5-09843	5-10269	5-11755	17-11332	6-10761	6-10763	6-09766
18-11335				7-08811	7-08811	6-10619
ORGANIC IODIDE				7-09765	7-09766	6-11484
5-10174	5-12076	7-10174	7-12076	7-10763	7-10764	7-09752
7-12077	11-10174			8-10761	8-10763	7-09782
ORNL (OAK RIDGE NATIONAL LABORATORY)				11-10114	13-09992	7-11270
9-09801	12-09831	13-09831	15-10100	13-11484	14-11905	7-11382
15-11523	18-09831			15-11595	15-11779	8-12020
ORR (OAK RIDGE RESEARCH REACTOR)				15-11960	17-09799	8-12025
6-10144	9-10144	17-07740	17-09786	17-11615	17-11617	15-08806
17-10204				18-10123	18-11270	15-11134
OSCILLATOR, REACTIVITY				PLUTONIUM DIOXIDE		15-11905
6-09709	6-11843	9-10280	9-11843	15-11779		
17-10280				PLUTONIUM OXIDE		
OUT OF PILE LOOPS AND EXPERIMENTS				4-11159	5-11992	6-11159
5-10174	5-11151	7-09229	7-09537	17-11148	17-11992	17-11147
7-10174	11-10174	18-11151		PM 1 (PORTABLE MEDIUM NUCLEAR POWER PLANT)		
OXIDATION				9-10136		
4-09682	7-09752	7-09765	7-10584	PM 3A (PORTABLE MEDIUM NUCLEAR POWER PLANT)		
7-11270	8-12020	9-12081	17-11615	9-10136	17-07703	
18-11270				POISON, SOLUBLE		
OXIDE				1-09703	6-09703	6-09941
5-10553	7-09753	7-09765	8-10304	6-11284	9-09943	6-10907
OXYGEN				17-09815	17-09943	9-10148
8-10256	15-11975			18-10907		9-11773
OYSTER CREEK				POLAND		17-11967
18-11903				14-11341	15-11342	
OZONE				PONTRYAGINS PRINCIPLE		18-11336
17-11793				6-11438	6-11439	
PARTICLE SIZE				POOL BOILING		
4-09690	7-08811	7-09361	7-09363	5-10217	6-09722	
7-09367	7-09752	7-10580	7-10590	POPULATION EXPOSURE		
7-11270	14-11633	15-11633	16-11265	1-11410	4-09726	4-10261
18-11270				15-09726	15-11342	14-09877
PARTICLE SIZE DISTRIBUTION				15-11528	15-11658	15-11359
4-09679	7-10580	7-10590	7-12074	POROUS DIFFUSION		15-11956
14-11355	14-11524	15-11355	16-10772	7-09757	7-09764	15-11961
16-11985				POROUS MEDIA		
PARTICLE, RADIOACTIVE				6-10128	7-09757	7-09764
7-12074	14-11355	15-11355	16-09574	PORTSMOUTH PLANT		
16-11263				9-11771	15-11771	
PARTICULATE				POTASSIUM		
5-10174	7-08811	7-09362	7-09364	5-10208	5-10209	5-10210
7-09367	7-10174	7-10580	11-10174	5-10212	5-10214	5-10216
PBF (POWER BURST FACILITY)				15-11342	15-11596	15-11653
6-10060				POWER COEFFICIENT		15-11957
PEACH BOTTOM				6-09709	6-09941	6-11268
17-11102	18-09869	18-11603		14-11268		6-11284
PERIOD METER				POWER DISTRIBUTION		
9-09943	17-09943			5-10454	8-10454	17-11145
PERSONNEL EXPOSURE, RADIATION				17-11625	18-10454	17-11146
1-10412	1-11408	4-09600	12-10262	POWER UPGRATING		
13-09304	15-09562	15-10253	15-11409	17-07710	17-07752	17-11431
15-11526	15-11782	15-11783	15-11814	18-11288	18-11419	18-11094
17-09277	17-09278	17-09280	17-09302	18-12034		18-11420
17-09304	17-09306	17-09562	17-10262	PRASEODYMIUM		18-11791
17-11787	17-11946	17-11947	17-11951	7-10177		
17-11971				PRECIPITATION		
PERSONNEL PROTECTIVE DEVICE				14-11522	16-10768	16-10771
						16-10772

PRESSURE DROP					15-11623			
5-10216	5-11226	5-11392	5-11395		RADIOCHEMICAL PLANT SAFETY			
5-11759					1-10257	1-11407	2-10600	7-10581
PRESSURE, EXTERNAL					7-12077	9-10153	12-10600	13-10257
6-10128	11-10186	11-11448	17-10762		13-10600	15-10153	18-10257	
PRFSSURE, INTERNAL					RADIOCHEMICAL PROCESSING			
5-10210	5-10212	5-10320	5-11376		1-09968	1-10114	1-10257	1-10405
5-11455	6-09711	6-09743	6-11268		1-10409	1-10805	2-10600	3-09968
7-09711	7-11376	8-09743	11-09864		6-10805	7-09765	7-10177	7-10178
11-10185	11-10320	11-10745	11-10903		11-09307	11-10114	12-09307	12-10600
11-11446	11-11449	11-11508	11-11583		13-09305	13-09308	13-09968	13-10114
11-11587	11-11589	11-11590	11-11592		13-10257	13-10600	13-11942	17-09305
11-11977	11-11978	11-11979	14-11268		17-09307	17-09308	17-09310	17-11599
17-10762	18-10903	18-10918	18-10918		17-11942	17-11943	17-11950	17-11971
PRESSURIZER					18-10257			
5-09778	9-10912	15-09563	17-09563		RADIOGRAPHY			
17-10205	18-10205	18-10912			15-09562	17-09277	17-09278	17-09280
PROCEDURES AND MANUALS					17-09562	17-11612	17-11789	17-11946
1-10305	5-09919	7-09919	11-09919		17-11971			
11-11397	17-07719	18-11538			RADIOISOTOPE			
PROMETHIUM					1-10162	1-10409	15-11714	
2-10600	12-10600	13-10600	15-11831		RADIOLYTIC GAS			
PROMPT NEUTRON					9-07761	17-07754	17-07761	
6-09719					RADIUM			
PROMPT NEUTRON LIFETIME					15-11306			
1-10805	1-11161	6-09701	6-09704		RADON			
6-09712	6-10805	6-11161	8-09701		14-11347			
PROPERTY, PHYSICAL					RAINOUT			
5-08969	5-12073	7-12080			14-11479	14-11524	14-11819	15-11134
PROTACTINIUM					15-11359	15-11528	15-11819	16-09574
6-10822					16-11263	16-11279	16-11280	16-11786
PRTR (PLUTONIUM RECYCLE TEST PEACTOR)					16-11987	16-12018		
5-11760	5-11990	5-11992	6-10823		RARE EARTH			
9-11993	17-07741	17-07754	17-09871		14-11663			
17-11990	17-11992	17-11993			REACTIVITY COEFFICIENT			
PUERTO RICO					1-08441	4-11159	5-10430	6-08441
15-11659					6-09713	6-10430	6-11159	17-09799
PULSED NEUTRON TECHNIQUE					19-10430			
1-10619	1-10805	6-10619	6-10805		REACTIVITY EFFECT			
6-11281	9-11762	17-11102			1-09686	5-09686	6-09710	17-07701
PUMP					17-11136	17-11625		
5-11670	9-12082	17-11670			REACTIVITY EFFECT, ANOMALOUS			
PUMP, JET					17-07738	17-10125	17-11149	17-11667
18-12045					17-11734	17-11969	17-11998	18-12033
PYROLYTIC					REACTIVITY EFFECT, SLUMP			
1-10656	7-09519	7-12079	13-10656		18-11740			
PYROPHORIC REACTION					REACTIVITY, EXCESS			
4-09681	8-11402				1-10718	6-09941	6-11267	9-10285
QUALITY CONTROL					12-10718	17-09942		
18-11736					REACTOR CONTROL			
RADIATION DAMAGE					6-09766	6-10287	7-09766	9-10285
1-11408	5-08969	5-09917	5-09918		9-10287			
5-09921	5-09965	5-12073	7-09372		REACTOR DECOMMISSIONING EXPERIENCE			
7-09597	7-09965	7-10296	7-12079		17-07710	18-09868	18-11093	
11-09917	11-09918	11-09921	11-09965		REACTOR DESCRIPTION			
11-10165	15-09510	15-11409	15-11973		1-08785	1-09686	1-11404	4-11404
15-11974	15-11975	17-10749			5-09686	5-09687	11-09687	17-07759
RADIATION EFFECT					17-11792	18-09687	18-09780	18-10164
1-10250	4-09600	5-08969	5-09917		18-10340	18-11336	18-11430	18-11675
5-09918	5-09920	5-12073	7-10584		18-11804	18-11902		
9-10386	11-09917	11-09918	11-09920		REACTOR DYNAMICS			
14-11319	14-11356	14-11661	15-11319		4-09577	5-10430	6-08761	6-09577
15-11409	15-11594	15-11782	15-11825		6-09714	6-09823	6-09994	6-10287
16-11982	18-11335				6-10389	6-10430	6-10761	6-10763
RADIATION IN PERSPECTIVE					6-10764	6-10821	6-11006	6-12092
1-09592	1-11408	1-11410	1-11443		7-10761	7-10763	7-10764	8-09714
15-11409	17-11443				8-10761	8-10763	8-10764	9-10287
RADIATION INJURY, TREATMENT OF					9-10389	9-11006	9-12086	9-12092
15-09755	15-11800	15-11802	15-11973		19-10430			
17-09755	17-11800	17-11951			REACTOR FUSE			
RADIATION PROTECTION, CHEMICAL					18-11294	18-11603		
4-11501	15-11955	15-11973			REACTOR KINETICS			
RADIATION PROTECTION, ORGANIZATION					1-10107	1-12038	4-11159	5-10430
1-10252	15-10252	15-10253	15-11527		5-10553	5-10578	5-11411	6-09710
15-11814	15-11825				6-09766	6-09823	6-09993	6-10389
RADIATION SAFETY AND CONTROL					6-10430	6-10578	6-11159	6-11438
1-10255	9-10146	9-10153	14-11822		6-11439	6-12092	7-09766	7-10578
15-09876	15-10153	15-11298	15-11527		9-10389	9-12092	17-11621	17-12038
15-11783	15-11812	15-11814	15-11822		19-10430			
15-11825	15-11827	15-11828	17-09812		REACTOR POWER			
17-10172	17-11793	17-11796	17-11965		17-11787	18-11229		
RADIATION UNIT					REACTOR SAFETY SYSTEM			
9-10146					1-10405	6-10389	7-12077	9-07757
RADIATION, PUBLIC EDUCATION/ACCEPTANCE					9-10148	9-10149	9-10154	9-10387
1-09592	1-11408	1-11410	1-11443		9-10389	9-11489	17-07757	17-10148
15-11409	17-11443				17-11787	18-10340		
RADIOACTIVITY, RELEASE					REACTOR STABILITY			
15-11714					1-09703	4-09577	5-10430	6-09541
RADIOCHEMICAL ANALYSIS					6-09577	6-09703	6-09709	6-09739
7-10177	14-11319	14-11347	14-11355		6-09766	6-09822	6-09944	6-09985
15-11306	15-11319	15-11355	15-11482		6-10287	6-10430	6-11380	6-11843

7-09766	9-09944	9-10287	9-11843	6-09781	6-10389	7-09781	9-10389
9-11993	17-09944	17-11993	18-11237	17-07759	17-11149	18-11804	
19-09739	19-10430			REACTOR, GAS COOLED			
REACTOR STARTUP EXPERIENCE, INITIAL				1-09686	1-10404	5-09686	5-09687
6-10139	9-10139	9-12093	17-07748	6-09699	6-11267	6-11401	6-11472
17-11339				7-09582	7-10296	8-10110	8-10399
REACTOR STARTUP TESTING				9-10383	9-10500	9-11472	11-09687
17-07747	17-07750	17-07751	17-09942	11-09750	11-11397	12-11733	17-07719
17-11602				17-10172	17-10747	17-11101	17-11102
REACTOR TRANSIENT				17-11602	17-11668	17-11677	17-11794
1-09686	5-09686	5-10430	6-09766	17-12000	18-09687	18-09869	18-10123
6-10430	6-11139	6-11267	7-09766	18-10340	18-10404	18-11603	18-11902
8-10397	17-10762	17-11136	19-10430	REACTOR, GENERAL			
REACTOR, AEC OWNED				1-11410	8-10304	17-11582	
1-07717	5-11990	5-11992	9-11991	REACTOR, GRAPHITE MODERATED			
9-11993	17-07711	17-07712	17-07713	5-10174	6-09710	6-09711	6-09716
17-07714	17-07717	17-09754	17-11092	6-10058	6-10059	6-10060	6-10126
17-11137	17-11971	17-11990	17-11991	6-11162	6-11267	6-11472	7-09711
17-11992	17-11993	18-11991		7-10174	8-10110	8-10112	9-09716
REACTOR, AIRCRAFT				9-10150	9-11472	9-12082	9-12086
6-11438				11-09750	11-10174	12-11733	17-07709
REACTOR, ARMY				17-07710	17-07738	17-07743	17-11102
6-12035	6-12037	7-07742	9-10136	17-11143	17-11442	17-11668	17-11676
11-09750	11-12037	13-12036	17-07703	17-11677	18-09869	18-11294	18-11333
17-07719	17-07742	18-11288	18-12032	18-11428	18-11603	18-11902	
18-12033	18-12034	18-12035	18-12036	REACTOR, HEAVY WATER			
18-12037				1-09969	1-10115	5-11151	5-11760
REACTOR, BEO MODERATED				5-11992	6-10287	6-10823	9-07758
17-11794				9-07762	9-07763	9-10285	9-10287
REACTOR, BOILING WATER				9-11993	9-11999	11-09750	17-07706
1-09703	2-11805	5-10320	5-10454	17-07707	17-07741	17-07748	17-07754
5-11539	5-11805	6-09702	6-09703	17-07758	17-07762	17-07763	17-07764
6-09739	6-09944	6-09985	6-10287	17-09797	17-09859	17-09871	17-10205
6-10820	6-10822	6-11284	6-11797	17-11136	17-11141	17-11142	17-11145
6-11843	7-07739	8-09817	8-10454	17-11796	17-11962	17-11992	17-11993
8-11413	9-09943	9-09944	9-10287	17-11999	18-10164	18-10205	18-11151
9-11838	9-11839	9-11840	9-11841	18-11430	18-11675		
9-11842	9-11843	9-11844	9-11845	REACTOR, HIGH FLUX			
9-11991	9-11999	10-10457	11-09750	1-09997	6-10144	9-10144	9-10387
11-10319	11-10320	11-11532	11-11537	17-07750			
12-10456	12-11532	12-11533	12-11534	REACTOR, HOMOGENEOUS			
12-11535	12-11537	12-11581	14-11086	1-09997	18-11336		
17-07704	17-07705	17-07739	17-09565	REACTOR, LARGE			
17-09797	17-09798	17-09799	17-09812	6-09358	6-09713	6-09825	6-10828
17-09813	17-09816	17-09872	17-09942	REACTOR, LIQUID METAL COOLED			
17-09943	17-09944	17-09945	17-10125	1-10107	1-11398	5-10430	5-11299
17-11087	17-11111	17-11144	17-11150	5-11396	6-09709	6-09711	6-09822
17-11241	17-11244	17-11245	17-11339	6-10057	6-10058	6-10127	6-10139
17-11413	17-11669	17-11797	17-11844	6-10430	6-11162	7-09711	7-11945
17-11964	17-11965	17-11966	17-11967	9-09717	9-10139	9-10150	9-10439
17-11968	17-11969	17-11970	17-11972	9-11441	9-12086	11-07746	11-09750
17-11991	17-11999	18-09816	18-09817	12-11396	17-07708	17-07709	17-07710
18-10116	18-10164	18-10454	18-10456	17-07714	17-07738	17-07743	17-07746
18-10457	18-11086	18-11337	18-11532	17-11138	17-11605	17-11945	18-11152
18-11533	18-11534	18-11535	18-11536	18-11333	18-11336	18-11428	19-10430
18-11537	18-11538	18-11539	18-11540	REACTOR, MARITIME			
18-11581	18-11805	18-11903	18-11944	1-09686	1-10405	5-09686	5-09687
18-11952	18-11991	18-12043	18-12044	11-09687	11-11953	17-11792	17-11953
18-12045	19-09739			17-11954	18-09687	18-09789	
REACTOR, BREEDER				REACTOR, MOLTEN SALT			
1-10695	1-11398	1-12022	3-11382	6-10144	9-10144		
5-10430	6-09707	6-09709	6-09711	REACTOR, ORGANIC COOLED			
6-09713	6-09822	6-10058	6-10127	1-09969	5-09557	5-11151	5-11670
6-10139	6-10430	6-10695	6-11638	11-09750	12-09557	17-09557	17-11141
6-11849	7-09711	7-09782	7-11382	17-11670	17-11734	17-11798	18-11151
9-09717	9-10139	9-10280	9-11441	18-11152	18-11335	18-11430	18-11675
11-07746	17-07708	17-07714	17-07746	REACTOR, POOL TYPE			
17-10280	17-10281	17-11138	17-11150	9-07761	13-12036	17-07753	17-07761
17-11334	17-12000	19-10430		17-11431	18-11288	18-11419	18-11420
REACTOR, FAST				18-12034	18-12036		
1-10152	1-10695	1-11399	1-12022	REACTOR, POWER			
3-11382	4-11159	5-10430	5-10553	1-11399	5-11820	6-09541	9-11110
6-09704	6-09705	6-09706	6-09707	17-09588	17-09811	17-11111	17-11112
6-09708	6-09709	6-09711	6-09712	17-11140	17-11334	17-11965	17-11966
6-09713	6-09714	6-09721	6-09722	17-11967	17-11968	17-11969	17-11970
6-09822	6-09825	6-09915	6-10058	17-12000			
6-10061	6-10064	6-10127	6-10129	REACTOR, PRESSURE TUBE			
6-10133	6-10139	6-10430	6-10695	5-11233	5-11760	5-11990	5-11992
6-10761	6-10763	6-10764	6-11006	6-10287	6-10823	9-10287	9-11993
6-11159	6-11281	6-11400	6-11401	11-09750	12-07702	17-07702	17-07741
6-11638	7-09711	7-09782	7-10761	17-07748	17-07754	17-09870	17-09871
7-10763	7-10764	7-11382	8-09714	17-10205	17-11101	17-11142	17-11143
8-10133	8-10761	8-10763	8-10764	17-11145	17-11990	17-11992	17-11993
9-09717	9-09915	9-10139	9-11006	18-10164	18-10205	18-11233	
9-11441	11-07746	11-11978	17-07708	REACTOR, PRESSURIZED WATER			
17-07714	17-07746	17-11138	18-09770	1-09592	5-09814	5-10174	5-10578
18-09914	18-10133	18-10152	18-11152	5-10900	5-10906	5-10908	5-10917
19-10430				5-10919	5-10920	5-10921	5-10922
REACTOR, FAST BREEDER				5-10926	5-11739	5-11990	6-10060
7-11945	17-11945	18-10123	18-11426	6-10578	6-10906	6-10907	6-11808
REACTOR, FAST BURST				6-12035	6-12037	7-09758	7-10174

7-10578	7-12072	8-10910	9-07758	18-12033			
9-10136	9-10285	9-10909	9-10910	REGULATING SYSTEM			
9-10911	9-10912	9-10913	9-10914	6-11440	17-09786		
10-10905	10-10908	11-07745	11-09750	REGULATION, AEC			
11-09974	11-10174	11-10901	11-10902	1-10162	1-10305	18-11229	18-11236
11-10903	11-10904	11-10911	11-10923	18-11737	18-11901	18-11904	
11-11953	11-11976	11-12037	11-12042	REGULATION, GENERAL			
14-10915	14-10924	14-10925	15-09563	1-10109	1-10255	3-11302	13-10109
16-10916	17-07703	17-07706	17-07707	15-10109	15-11527		
17-07745	17-07758	17-09563	17-09799	REGULATION, IAEA			
17-09814	17-09815	17-09819	17-10102	1-10258	3-10258	3-11423	
17-11111	17-11147	17-11148	17-11150	REGULATION, STATE			
17-11242	17-11243	17-11338	17-11621	1-10162	17-11807		
17-11625	17-11667	17-11669	17-11792	RELEASE RATE			
17-11796	17-11808	17-11953	17-11954	14-11086	18-11086		
17-11962	17-11963	17-11990	17-11998	RELIABILITY ANALYSIS			
18-09453	18-09819	18-09974	18-10832	1-07716	9-10149	9-10154	9-10155
18-10900	18-10901	18-10902	18-10903	9-10466	9-11489	11-10259	11-11588
18-10904	18-10905	18-10906	18-10907	11-11630	11-11631	17-07716	17-10155
18-10908	18-10909	18-10910	18-10911	17-11140	17-11141		
18-10912	18-10913	18-10914	18-10915	RELIABILITY, COMPONENT			
18-10916	18-10917	18-10918	18-10918	9-10149	9-10154	9-11489	
18-10919	18-10920	18-10921	18-10922	RELIABILITY, SYSTEM			
18-10923	18-10924	18-10925	18-10926	9-10149	9-10154	9-10466	9-11489
18-11236	18-11736	18-11737	18-11738	10-10283	12-09534		
18-11739	18-11740	18-11901	18-12028	REMOTE MANIPULATING AND VIEWING			
18-12032	18-12035	18-12037		6-09716	9-09716	17-09945	17-11798
REACTOR, PULSED				17-11988			
6-09781	6-10133	6-10389	7-09781	RESEARCH CONTRACT			
8-10133	9-10386	9-10389	17-07755	1-12019	14-11905	15-11905	17-12000
17-11787	18-10133	18-12033		18-11905			
REACTOR, RESEARCH				RESIN			
1-09997	1-11407	6-10059	6-10060	17-11618			
6-10126	6-10144	9-07760	9-10144	RESPONSE TIME			
9-10155	9-10466	11-07744	13-12036	6-11843	9-11843		
17-07700	17-07740	17-07744	17-07750	RESUSPENSION			
17-07751	17-07760	17-09786	17-09859	14-11633	15-11633		
17-10155	17-11425	17-11988	18-07700	REVIEW			
18-12033	18-12034	18-12036		1-10411	1-10412	1-12019	8-10113
REACTOR, SAFETY RESEARCH				9-10148	9-10149	17-10148	17-11334
14-11809	15-11809			18-09869			
REACTOR, SPACE				RHODIUM			
1-11404	4-09685	4-11404	4-11492	7-10177	16-11986		
4-11494	4-11495	4-11496	4-11497	RISO (RESEARCH LABORATORY, DENMARK)			
4-11501	4-11502	5-10218	6-11486	1-09997			
9-07749	9-10014	9-12093	14-11809	RIVER, CLINCH			
15-11809	17-07712	17-07749	17-09301	14-09539	15-11523		
18-11093				RIVER, COLUMBIA			
REACTOR, SPECTRAL SHIFT				14-09877			
9-10285				RIVER, GENERAL			
REACTOR, SUPERHEAT				14-11774			
6-11284	7-07739	8-11413	11-09750	RIVER, TENNESSEE			
17-07739	17-09812	17-09813	17-09816	15-11523			
17-11137	17-11413	18-09816	18-10116	ROBINSON			
REACTOR, TEST				5-11739	18-11736	18-11737	18-11738
1-07715	1-10718	5-10174	5-11108	18-11739	18-11740	18-11901	
5-11992	6-09710	6-09711	6-09716	ROCKY FLATS			
6-09781	6-10058	6-10059	6-10060	1-10114	11-10114	13-10114	
6-10126	6-10143	6-10144	7-09711	ROSSI ALPHA			
7-09781	7-10174	8-10112	9-07758	1-11161	6-09701	6-09704	6-09712
9-09716	9-10143	9-10144	9-11993	6-09719	6-09994	6-11161	8-09701
9-12087	11-09750	11-10174	12-10718	KOVER PROGRAM			
17-07701	17-07706	17-07707	17-07709	4-09577	4-09688	4-09690	6-09577
17-07715	17-07740	17-07741	17-07747	7-09765	9-12093	14-11809	15-11809
17-07750	17-07752	17-07754	17-07758	RUBIDIUM			
17-09309	17-09786	17-09818	17-09871	14-11354	15-11354		
17-10204	17-10749	17-11108	17-11332	RUTHENIUM			
17-11367	17-11368	17-11369	17-11988	7-09597	7-09753	7-10177	7-10583
17-11992	17-11993	18-11235	18-11791	14-11343	14-11357	14-11522	14-11662
REACTOR, THERMAL				14-11786	14-11959	15-11306	15-11623
6-11006	9-11006			15-11662	15-11831	15-11959	16-11986
REACTOR, TRAINING				SAFE FAILURE CRITERION			
18-09868	18-11094			17-09816	18-09816		
REACTOR, WATER				SAFEGUARDS REPORT, GENERAL			
1-09997	5-11411	8-10112		2-10600	6-10133	7-10270	8-10133
RECOMBINER				11-09974	12-10600	13-10600	18-09770
17-07707				18-09869	18-09974	18-10133	18-10270
REDUCTION				18-11229	18-11420	18-12043	18-12044
8-12020				18-12045			
REDUNDANCE				SAFEGUARDS REPORT, PRELIMINARY			
9-10909	9-11488	12-10456	18-10456	5-11739	18-11736	18-11737	18-11738
18-10909	18-11536			18-11739	18-11740		
REENTRY, ATMOSPHERIC				SAFEGUARDS REPORT, RESPONSE TO AEC QUESTIONS			
4-11491				5-10454	5-10900	5-10906	5-10908
REFLECTOR				5-10917	5-10919	5-10920	5-10921
1-09576	1-09992	6-07756	6-09705	5-10922	5-10926	5-11539	6-10906
6-09712	6-09714	6-09719	8-09714	6-10907	8-10454	8-10910	9-10909
9-07760	13-09576	13-09992	17-07753	9-10910	9-10911	9-10912	9-10913
17-07756	17-07760			9-10914	10-10457	10-10905	10-10908
REFUELING				11-10901	11-10902	11-10903	11-10904
17-07703	17-11142	18-11540	18-12032	11-10911	11-10923	11-11532	11-11537

12-10456	12-11532	12-11533	12-11534	3-11301	3-11381	3-11423	3-11847
12-11535	12-11537	14-10915	14-10924	15-11825	17-09564		
14-10925	16-10916	18-10454	18-10456	SHIPPINGPORT			
18-10457	18-10900	18-10901	18-10902	17-11111	17-11338	17-11621	
18-10903	18-10904	18-10905	18-10906	SHOCK ABSORBER			
18-10907	18-10908	18-10909	18-10910	11-09862			
18-10911	18-10912	18-10913	18-10914	SHOCK WAVE			
18-10915	18-10916	18-10917	18-10918	11-09863	11-10170	11-11586	11-11978
18-10918	18-10919	18-10920	18-10921	11-11979			
18-10922	18-10923	18-10924	18-10925	SHUTDOWN MARGIN			
18-10926	18-11532	18-11533	18-11534	1-09703	1-10805	6-09703	6-10805
18-11535	18-11536	18-11537	18-11538	6-10907	6-11267	17-09819	17-11102
18-11539				18-09819	18-10907		
SAFETY EVALUATION				SHUTDOWN SYSTEM, SECONDARY			
6-12035	6-12037	11-12037	17-10205	9-11773	12-10456	17-07764	17-11965
18-10205	18-12035	18-12037		17-11967	18-10456		
SAFETY INJECTION				SILVER			
6-10907	9-07758	9-09943	9-10148	14-11343			
9-11773	17-07758	17-09943	17-10148	SIMULATION			
18-10907	18-10918	18-10918		5-11411			
SAFETY PRINCIPLES AND PHILOSOPHY				SITE CLIMATOLOGY			
1-10252	1-10405	1-10411	1-10838	16-10771			
1-11399	1-11407	5-10553	9-10149	SITING, GENERAL			
11-10220	15-10252	15-11800	15-11825	1-10405			
17-10838	17-11800	17-11801	18-11229	SITING, REACTOR			
18-11944				2-09544	2-09851		
SAFETY REVIEW (OPERATIONS, EXPERIMENTS)				SLAB			
1-07715	1-07716	1-07717	1-07718	6-09708			
13-12036	17-07715	17-07716	17-07717	SMOKE			
17-07718	17-07719	17-09859	18-11288	16-11735	17-11735		
18-11294	18-12032	18-12033	18-12034	SNAP 10A (SYSTEMS FOR NUCLEAR AUXILIARY POWER)			
18-12036				4-09685	4-11492	4-11494	4-11495
SAFETY STUDY				4-11496	4-11497	4-11502	7-09595
1-11398	1-11399	3-11302	6-11268	9-07749	17-07749		
7-10581	14-11268	14-11905	15-11825	SNAP 2 (SYSTEMS FOR NUCLEAR AUXILIARY POWER)			
15-11905	18-11905			4-09685			
SALMON EVENT				SNAP 50 (SYSTEMS FOR NUCLEAR AUXILIARY POWER)			
14-11816				11-10289			
SAMARIUM				SNAP 8 (SYSTEMS FOR NUCLEAR AUXILIARY POWER)			
6-10822				4-09685	5-10218	17-09301	
SAMPLING				SNAP, GENERAL (SYSTEMS FOR NUCLEAR AUX. POWER)			
5-10578	6-10578	7-08811	7-09367	6-11139	6-11486		
7-10578	9-09578	14-11347	14-11774	SNAPTRAN (SNAP TRANSIENT REACTOR TEST SERIES)			
14-11819	14-11829	14-11959	15-09876	5-10578	6-10578	6-11374	6-11375
15-11134	15-11340	15-11360	15-11476	7-10578			
15-11819	15-11828	15-11829	15-11959	SODIUM			
16-10768	16-10772	16-10775	16-11265	3-09526	5-09554	5-10217	5-11456
16-11279	16-11986			6-09716	6-09721	6-09741	6-09743
SAMPLING, HIGH ALTITUDE				6-10057	6-10133	6-10761	6-10763
16-09651	16-10768			6-10764	6-11268	7-09752	7-10761
SAVANNAH RIVER PLANT				7-10763	7-10764	7-11270	8-09743
9-07762	9-07763	17-07762	17-07763	8-10108	8-10111	8-10113	8-10133
SAVANNAH RIVER PRODUCTION REACTORS				8-10761	8-10763	8-10764	8-11402
9-11628	9-11773			8-11403	9-09716	12-10111	14-11268
SAXTON				14-11343	15-08806	15-11358	18-10133
11-07745	17-07745	17-09799	17-11147	18-11270			
17-11148				SODIUM COEFFICIENT			
SCANDIUM				6-09704	6-09708	6-09713	6-09825
14-11343	14-11354	15-11354		6-11006	6-11400	9-11006	
SCRAM, FALSE				SOIL, NUCLIDE OCCURRENCE			
17-11149				14-11319	14-11354	14-11662	14-11819
SEAL				15-08810	15-11319	15-11354	15-11359
9-11999	11-09756	11-09773	11-09774	15-11523	15-11662	15-11810	15-11019
11-11310	17-11999			15-11831			
SEFOR (SOUTHWEST EXP. FAST OXIDE REACTOR)				SOIL, RADIONUCLIDE MOVEMENT THROUGH			
1-10695	1-12022	6-09707	6-10064	14-11319	14-11662	15-11319	15-11662
6-10695	6-11638			SOLID STATE DEVICE			
SEISMOLOGY				9-10151			
2-11805	5-11805	11-09974	11-11767	SORPTION			
18-09974	18-11236	18-11736	18-11740	7-12077			
18-11805				SOURCE, CONTINUOUS			
SELENIUM				7-10581	16-11987		
14-11343				SOURCE, ELEVATED			
SELF POWERED FLUX DETECTOR				16-11280			
9-11772				SOURCE, NEUTRON			
SEPARATOR				6-10139	9-10139	15-11480	17-11339
7-12072				18-11294			
SERVOMECHANISM				SOURCE, RADIATION			
6-12092	9-10387	9-10466	9-12092	1-10409	15-10100	17-09279	17-11801
9-12093				SOURCE, RADIATION, LOST			
SHELL				17-10095	17-11608	17-11788	17-11948
11-09861	11-10169	11-10170	11-10185	SPACE DEPENDENT DYNAMICS			
11-10186	11-10188	11-10189	11-10220	5-10430	6-09358	6-09399	6-09702
11-10745	11-11448	11-11584	11-11589	6-09715	6-09719	6-09720	6-09824
11-11590	11-11591	11-11592	11-11977	6-10430	6-10828	6-11282	6-11378
SHIELDING				6-11379	6-11598	19-10430	
3-11381	5-09554	12-09831	12-11733	SPACECRAFT			
13-09831	15-11812	17-07706	17-09798	6-09714	8-09714	15-11826	
17-09945	17-11241	17-11793	18-09831	SPECTROMETRY, ALPHA			
SHIPPING CONTAINER				15-11660			
1-10251	3-09528	3-09564	3-10251	SPECTROMETRY, BETA			

15-11660				STRONTIUM			
SPECTROMETRY, GAMMA				2-10600	4-11491	7-10177	12-10600
14-11319	14-11774	15-11319	15-11358	13-10600	14-09539	14-11341	14-11345
15-11477	15-11529	15-11655	15-11810	14-11353	14-11357	14-11479	14-11522
15-11960				14-11531	14-11702	14-11774	14-11777
SPECTROMETRY, NEUTRON				14-11786	14-11819	14-11822	15-08806
15-11658				15-10100	15-11134	15-11306	15-11345
SPERT 1 (SPECIAL POWER EXCURSION REACTOR TEST)				15-11353	15-11523	15-11528	15-11531
8-11412				15-11596	15-11623	15-11777	15-11818
SPERT, ALL (SPECIAL POWER EXCURSION RCTR. TEST)				15-11819	15-11822	15-11831	16-10768
6-10060	6-10064			16-10772	16-12018		
SPHERE				STRUCTURAL INTEGRITY			
5-09626	6-09742	11-10288	11-10745	3-11301			
11-11584	11-11589	11-11591	11-11592	SULFUR			
11-11977				14-11344	14-11824		
SPRAY, GENERAL				SUPPORT STRUCTURE			
5-11756	7-09598	17-10163		5-10920	5-10921	18-10920	18-10921
SRE (SODIUM REACTOR EXPERIMENT)				SURFACE CONTAMINATION			
6-11162	9-12086	17-07709	17-07710	5-11390	7-09229	7-09832	14-11305
17-07743				SURFACE FILM DEPOSIT			
STACK				17-09565	17-09872	17-10102	17-11338
7-10581	11-09307	12-09307	17-09307	17-11667	17-11998	18-11540	
STAFFING, TRAINING, QUALIFICATION				SURFACE TO VOLUME RATIO			
1-12038	13-09308	17-07711	17-07712	7-10175			
17-07713	17-07714	17-09308	17-11582	SURFACE WATER, DISPOSAL MEDIA			
17-11621	17-11807	17-11943	17-11954	14-11774			
17-12038	18-10116			SURFACE WATER, GENERAL			
STATE PROGRAM				17-09310			
15-10253				SURFACE WATER, NUCLIDE OCCURRENCE			
STATISTICAL ANALYSIS				14-11341	14-11774	14-11777	14-11819
4-09608	16-12017			15-11523	15-11777	15-11819	15-11958
STATISTICAL CORRELATION				SURFACE WATER, PROPERTY			
1-09995	6-09995	15-10253		14-11774			
STEAM				SURFACE WATER, SEDIMENT			
5-10174	5-11749	6-11401	8-11797	14-11774	16-11523		
7-09519	7-10174	7-12072	8-10110	SURFACE WATER, TRACER			
9-10150	9-10909	11-10174	17-11797	14-11774			
18-10909				SURFACE, GENERAL			
STEAM LINE RUPTURE				5-09557	5-10215	5-10218	5-10407
5-10906	5-10922	6-10906	18-10906	5-11390	5-11748	7-10407	12-09557
18-10922	18-11538			17-09557			
STEEL				SURVEY, RADIATION, AERIAL			
1-10250	1-10251	3-10251	5-09917	15-11653	15-11656	15-11659	
5-09918	5-09919	7-09229	7-09919	SURVEY, RADIATION, EMERGENCY			
11-09756	11-09759	11-09772	11-09917	15-11811			
11-09918	11-09919	11-10185	11-10220	SURVEY, RADIATION, ENVIRONMENTAL			
11-10744	11-11310	11-11377	11-11447	4-09608	14-11809	14-11819	15-11134
11-11508	11-11590	11-11591	11-11768	15-11596	15-11809	15-11810	15-11811
11-11769	11-11977	11-12039	17-11332	15-11819	15-11825	15-11961	
17-11442				SURVEY, RADIATION, GENERAL			
STEEL LINER				17-07741	17-11949		
11-09821	11-10288			SURVEY, RADIATION, USPHS			
STEEL, STAINLESS				14-11822	14-11829	15-11822	15-11829
5-09921	5-11396	6-09741	7-09537	SUTTON DIFFUSION FORMULA			
7-09832	7-12080	8-11402	8-11412	5-10475	15-10475	18-10475	
11-09921	12-11396	17-11101	17-11242	SWEDEN			
17-11243	17-11244	17-11669	17-11968	9-10826	17-11962		
17-11990	18-12033			SYSTEM DESCRIPTION			
STEP (SAFETY TEST ENGINEERING PROGRAM)				9-10387	18-09914	18-11536	
5-10578	6-10578	7-10578		SYSTEM OPERABILITY IN ACCIDENT CONDITIONS			
STOICHIOMETRY				11-11532	11-11537	12-11532	12-11534
5-11992	17-11992			12-11537	18-11532	18-11534	18-11537
STRATOSPHERE				TANTALUM			
14-11819	15-11819	16-09574	16-10768	5-11299	6-09741		
16-10772	16-12017			TARGET (THERMAL ADV RCTR GASCOOLED EXPLOITING TH)			
STRESS				11-12039	11-12040		
5-09554	9-07758	11-09604	11-09756	TECHNETIUM			
11-09772	11-09860	11-09861	11-10165	14-11343	16-11986		
11-10166	11-10167	11-10168	11-10169	TELLURIUM			
11-10170	11-10171	11-10185	11-10186	7-09597	7-10583	16-11986	
11-10187	11-10188	11-10189	11-10220	TEMPERATURE COEFFICIENT			
11-10259	11-10260	11-10745	11-11310	1-08441	1-09703	6-08441	6-09701
11-11377	11-11445	11-11447	11-11448	6-09703	6-09941	6-10139	6-10822
11-11449	11-11508	11-11509	11-11587	6-11006	6-11106	6-11284	6-11374
11-11588	11-11622	11-11630	11-11631	8-09701	9-10139	9-11006	
11-11632	17-07738	17-07758	17-11101	TEMPERATURE GRADIENT			
17-11245	17-11962			11-09860	11-09864	11-10165	11-10168
STRESS ANALYSIS				11-10170	11-10189	11-10220	11-11449
5-09554	5-10174	5-10921	6-10065	11-11585	14-11356	16-11983	
7-10174	11-09860	11-09861	11-10165	TEMPERATURE TRANSIENT			
11-10167	11-10168	11-10169	11-10170	5-11387	5-11393	6-09699	6-09701
11-10171	11-10174	11-10185	11-10188	6-09742	8-09701		
11-10220	11-10260	11-10745	11-11448	TENSILE PROPERTY			
11-11449	11-11508	11-11583	11-11584	5-09917	5-09920	5-09921	11-09917
11-11587	11-11589	11-11622	11-11630	11-09920	11-09921	11-10166	11-10185
11-11631	11-11766	11-11977	11-12039	11-11447	11-11509	11-11588	11-11768
18-10921	18-11736			11-11769			
STRESS RUPTURE				TEST, BENCH			
11-10259				8-11403			
STRESS STRAIN DATA				TEST, COMPONENT			
11-11445	11-11586			4-11492	4-11495	4-11496	9-10386

TEST, CONTROL ROD DRIVE	3-11301	3-11302	3-11423	3-11847
9-10148 17-10148	11-10114	12-09850	13-09968	13-10114
TEST, DESTRUCTIVE	15-09850	15-11825	17-11608	17-11614
3-11301 4-09682 4-09688 4-09690	17-11948			
4-11492 5-09919 11-10187 11-10188 11-11977	TRANSURANIUM ELEMENT			
TEST, DROP	15-11595			
5-11234 11-11234 18-11234	TREAT (TRANSIENT TEST REACTOR FACILITY)			
TEST, FILTER SYSTEM	5-10174 6-09710 6-09711 6-09716			
7-12072	6-10058 6-10059 6-10060 6-10064			
TEST, LEAK LOCATION	6-10126 6-10761 6-10763 6-10764			
11-09750 11-11397	7-09711 7-10174 7-10761 7-10763			
TEST, LEAK RATE	7-10764 8-10112 8-10397 8-10761			
6-12037 9-07758 11-07744 11-07745	8-10763 8-10764 9-09716 11-10174			
11-07746 11-09750 11-11458 11-12037	TRIGA (TRAINING REACTOR, ISOTOPIES, G.A.)			
17-07744 17-07745 17-07746 17-07758	9-10386 17-07755 17-11787 18-12033			
18-12037	TRITIUM			
TEST, NONDESTRUCTIVE	15-08806 15-11470 15-11481 15-11521			
5-11990 9-11765 11-10744 11-11632	17-07703 17-09302 17-09797 17-11788			
12-07702 17-07702 17-11241 17-11244	17-11796 17-11949 18-11152			
17-11245 17-11990	TUNGSTEN			
TEST, PHYSICS	4-11159 6-09723 6-11159			
17-07755 17-11102 17-11145	TURBULENCE, SHEAR (WIND)			
TEST, PLANT RESPONSE	16-09568			
6-09944 9-09944 17-09944 17-11602	TURBULENCE, STATISTICS			
TEST, PREOPERATIONAL	16-11264 16-11280			
4-11494 17-11602	TURKEY POINT 3			
TEST, PRESSURE VESSEL	11-09974 18-09974 18-11237			
5-09920 11-09861 11-09864 11-09920	TURKEY POINT 4			
11-10169 11-10220 11-10744	11-09974 18-09974 18-11237			
TEST, PROOF	UHTREX (ULTRA HIGH TEMP. REACTOR EXPERIMENT)			
1-10251 3-10251 3-11382 3-11423	6-12091 9-12091 18-10123			
5-11108 7-11382 17-11108	UNION OF SOVIET SOCIALIST REPUBLICS			
TEST, SYSTEM OPERABILITY	1-10409 4-09600 4-11502 16-11986			
4-11498 6-10143 9-10143 9-10148	18-11335			
12-11581 17-07764 17-10148 18-11581	UNITED KINGDOM			
TESTING	1-07716 1-09968 1-10152 1-10404			
4-11497 4-11498 5-09919 5-09920	1-10412 2-09544 3-09968 3-11423			
5-09921 5-09965 5-11820 7-09919	5-11820 6-09699 9-10153 9-10154			
7-09965 7-12078 9-10014 11-09919	9-10155 9-10466 9-11764 13-09968			
11-09920 11-09921 11-09965	15-08810 15-09499 15-10153 15-11134			
THEORETICAL INVESTIGATION	15-11764 15-11800 15-11802 15-11803			
6-09541 6-09542 6-09543 6-09708	15-11818 17-07716 17-10155 17-10172			
6-09722 6-09738 6-09822 7-12074	17-10747 17-11668 17-11800 17-11801			
7-12075	18-10152 18-10340 18-10404			
THERMAL ANALYSIS	UNITED STATES			
1-10250 5-10320 6-09701 6-09721	2-09544			
6-09722 6-09739 6-09742 6-10057	URANIUM			
6-10061 6-10063 6-10127 6-10129	1-08441 1-10130 1-10162 1-10412			
6-10820 6-11598 8-09701 11-10320	1-10618 1-10619 1-10656 3-11381			
19-09739	5-10553 6-08441 6-09542 6-09707			
THERMAL CONSIDERATION	6-09711 6-09723 6-10058 6-10133			
6-09699 14-08809 14-11356 14-11662	6-10619 7-09711 7-09753 7-09765			
15-11521 15-11662	8-10130 8-10133 8-10304 8-10397			
THERMAL EXPERIMENT	8-11412 8-12020 13-10656 15-08806			
1-10250 1-10251 3-10251 5-09554	15-11831 16-11986 17-11442 17-11610			
THERMAL INSULATION	18-10133			
3-09528 11-11585 11-12040	URANIUM CARBIDE			
THERMAL MECHANICAL EFFECT	7-09519 7-09521 7-09536			
5-09554 17-11087	URANIUM DIOXIDE			
THERMAL NEUTRON	4-11159 6-10059 6-10062 6-10064			
6-09994	6-10126 6-11159 8-11402 18-11152			
THERMAL PROPERTY	URANIUM HEXAFLUORIDE			
5-11383 7-09782	7-09764			
THERMODYNAMICS	URANIUM OXIDE			
5-09589 5-10407 5-10553 7-10407	5-11992 6-09718 6-09743 6-10761			
THICKNESS	6-10763 6-10764 7-09372 7-09521			
11-10187 11-11588 11-11769	7-10296 7-10761 7-10763 7-10764			
THORIUM	8-09743 8-10761 8-10763 8-10764			
1-10162 1-10656 6-09711 6-11400	17-11992			
7-09711 7-09765 12-09303 13-10656	URANIUM SULFIDE			
15-11831 17-09303	6-09711 7-09711			
TITANIUM	URANIUM, NATURAL			
7-12080 8-11402	1-11160			
TRACER, FLUORESCENT	VALVE			
16-10775 16-11280	9-07758 12-10456 17-07758 17-09945			
TRACER, RADIOACTIVE	18-10456			
7-09832 7-12078 14-11305 14-11343	VANADIUM			
16-11265 17-09306 17-11941 17-11951	6-09741			
TRANSFER FUNCTION	VAPOR, VAPOR PRESSURE			
1-09703 5-11393 5-11749 6-09702	5-10553 6-11797 7-10582 17-11605			
6-09703 6-09715 6-09720 6-09822	17-11797			
6-09944 6-09985 6-10143 6-10144	VBWR (VALLECITOS BOILING WATER REACTOR)			
6-10287 6-11282 6-11283 6-11374	8-11413 17-11413			
6-11378 6-11849 9-09944 9-10143	VENTILATION SYSTEM			
9-10144 9-10287 17-09944	11-11953 17-11611 17-11953			
TRANSPORT THEORY	VIBRATION			
6-09823	5-10756 5-11385 5-11474 17-11677			
TRANSPORTATION AND HANDLING	VOID COEFFICIENT			
1-09968 1-10114 1-10258 1-10405	5-10430 5-11749 6-09701 6-09704			
3-09528 3-09850 3-09968 3-10258	6-09713 6-10430 6-10822 6-10823			
	8-09701 19-10430			

WASHOUT					11-10187	17-11245		
14-11524	16-11263	16-11987			WIGNER ENERGY RELEASE			
WASTE DISPOSAL, GENERAL					17-11676			
1-11443	7-09545	14-11702	14-11703		WIND PROFILE			
14-11786	14-11824	15-11527	15-11825		16-09568	16-11264	16-11981	16-11984
17-11443	17-11609	17-11965			16-12017			
WASTE DISPOSAL, HYDRAULIC FRACTURING					WIND STATISTICS			
15-11307					11-09307	12-09307	16-10771	16-10916
WASTE DISPOSAL, LIQUID					16-11264	16-11981	16-11983	16-12017
14-11786	17-11949				17-09307	18-10916		
WASTE DISPOSAL, RIVER					WR1 (WHITESHELL REACTOR NO. 1, CANADA)			
14-10915	14-11905	15-11523	15-11905		1-09969			
18-10915	18-11905				X-RAY			
WASTE DISPOSAL, SALT					5-09917	5-09918	11-09917	11-09918
14-11356					15-11974	15-11975	17-11612	17-11613
WASTE DISPOSAL, SOLID					17-11801			
14-11702	14-11703	14-11817	17-09310		XENON			
17-11790					6-09399	6-09941	6-10822	6-11380
WASTE DISPOSAL, TERRESTRIAL					6-11439	7-09521	17-11136	17-11338
15-11307	17-11790				XENON OSCILLATION			
WASTE HANDLING					6-09399	9-11110	18-09453	18-11237
5-09687	11-09687	12-09831	13-09831		18-11738			
14-11702	14-11703	17-11615	17-11947		YANKEE			
18-09687	18-09831				5-09814	6-11808	17-09814	17-09815
WASTE STORAGE					17-10102	17-11111	17-11242	17-11625
14-10924	14-10925	14-11662	14-11786		17-11667	17-11608	17-11998	18-10832
15-11662	18-10924	10-10925			YTTRIUM			
WASTE TREATMENT, ECONOMICS					7-10177	15-10100	15-11306	
14-11522					ZINC			
WASTE TREATMENT, EQUIPMENT					14-11343	15-11306		
14-11702	14-11703	14-11786	14-11817		ZIRCALOY			
WASTE TREATMENT, FIXATION					5-09966	5-11233	5-11405	6-10059
14-08809	14-11522	14-11661	14-11786		6-10064	7-09966	8-11405	11-09966
14-11817	14-11824				17-09870	17-09871	17-11442	17-11669
WASTE TREATMENT, LIQUID					18-11233	18-11540		
14-10925	14-11357	14-11522	14-11663		ZIRCONIUM			
14-11786	14-11817	18-10925			1-10130	4-09679	4-09682	5-09921
WASTE TREATMENT, SOLID					5-09959	5-09966	6-10126	6-11374
14-11702	14-11703	14-11786			7-09537	7-09596	7-09597	7-09753
WATER TREATMENT					7-09966	7-10177	7-10583	8-09817
14-11357	15-11523				8-10130	8-10256	8-10304	8-11402
WATER VAPOR					8-11412	11-09921	11-09966	13-09368
7-12072					14-11343	15-11306	15-11596	15-11624
WATER, DRINKING					16-11986	17-09368	18-09817	
14-11341	15-11523	15-11813			ZPR III (ANL ZERO POWER REACTOR)			
WATER, GENERAL					1-10695	6-09706	6-09707	6-10695
1-09992	5-09778	5-11385	5-11387		18-09770			
7-09596	8-12020	13-09992	15-11470		ZPR IX (ANL ZERO POWER REACTOR)			
WATER, IRRIGATION					6-09714	8-09714		
15-11523					ZPR VI (ANL ZERO POWER REACTOR)			
WELDING					6-09704	6-09705		
11-09307	12-09307	17-07753	17-09307		630 A (MARITIME REACTOR)			
17-11137	18-11337				1-09686	5-09686	5-09687	11-09687
WELDS					18-09687	18-09789		

FOLLOWING IS A LIST OF AUTHORS WHOSE DOCUMENTS
HAVE BEEN ABSTRACTED IN THIS PUBLICATION

ABDON R		17-07748			
1-11399		BAILEY RE			
ABEE HH		5-10005			
15-10092		BAILEY RW			
ABLITT JF		11-10167			
1-07716	17-07716	BAIR WJ			
ABSON W		15-11779			
9-11764	15-11764	BAKER AL			
ACKERMAN JW		11-09864			
5-12237		BAKER L			
ADAMS RE		6-09742	6-09743	8-09743	8-11402
7-09536		8-11412			
ADAMS RJ		BALCOMB JD			
4-11497		6-11283			
ADAMS RM		BALL RM			
1-11407		6-11440			
ADKINS CR		BALL SJ			
6-09718		1-12038	17-12038		
AISU H		BALLOU JE			
6-11023	9-11023	15-11955			
AKCASU AZ		BALZHISER RE			
6-09822		5-10212			
ALBAUGH FW		BANCROFT AR			
5-09959		5-09557	12-09557	17-09557	
ALBRECHT RW		BANFIELD TV			
6-09738	6-11379	16-09568			
ALEKSENKO YN		BANKOFF SG			
18-11335		6-09702			
ALEXANDER RB		BAQUE P			
17-11948		8-10399			
ALGER DL		BARAN W			
1-08441	6-08441	6-09541			
ALKIRE GJ		BARNES RH			
14-11522		5-12076	7-12076		
ALLAN DL		BARNES GM			
6-08781		5-09843			
ALMENAS KK		BARRINGER HS			
6-09714	8-09714	6-11440			
AMMON RL		BARRY PJ			
5-10214		14-11305			
AMOROSI A		BARTH NH			
17-11138		17-11146			
ANCARANI A		BARTON CJ			
6-09705		7-09758			
ANDELIN RL		BATCH JM			
3-11382	7-11382	5-11992	9-11993	17-11992	17-11993
ANDERSEN P		BATCH ML			
5-11151	18-11151	6-11440			
ANDERSEN R		BATTAN LJ			
5-11151	18-11151	16-11735	17-11735		
ANDERSON AN		BATTIST L			
17-09819	18-09819	7-07742	17-07742		
ANDERSON D		BAUMGARTNER WV			
3-11847		9-11629			
ANDREWS JS		BAZYKIN V			
1-10404	18-10404	4-09600			
ARMSTRONG FE		BEAL JL			
14-11135		4-09679	4-09682		
ARNETT LM		BEAN WC			
7-10270	18-10270	17-11621			
ARONSTEIN RE		BEASLEY EG			
18-11333		12-11733			
ARPACI VS		BECK HL			
5-11474		15-11359	15-11810		
ARTEMENKOVA LV		BECK WN			
7-10178		9-11765			
ARTHUR CE		BECKERS RM			
14-11135		12-09831	13-09831	18-09831	
ASPINALL KJ		BECKETT EF			
9-10153	15-10153	17-07703			
ATEN AH		BELLET J			
15-11957		3-09526			
ATTERBURY TJ		BENNELICK EJ			
11-10745		1-10412			
AUGUST C		BENNETT BG			
6-09711	7-09711	15-11810			
AULETA JJ		BENNETT EC			
5-11670	17-11670	12-07702	17-07702		
AUNGST RC		BENNETT EF			
17-09870		6-09705			
AUSTIN HC		BENSON SW			
10-10283		7-10175			
AWOJOBI AO		BENTLEY PG			
11-11767		5-11393	6-09699		
AYRES JA		BENTON EV			
12-10312		15-11826			
BABB HT		BERRY RE			

4-09688	4-09690			BRINKMAN DS			
BERTOU P				9-07749	17-07749		
15-11528				BROMKAMP KH			
BEVITT E				17-11602			
11-09759				BROOKS H			
BHATTACHARYYA A				6-11380			
5-09553				BROOKS WL			
BIERMAN GF				15-11134			
17-11111				BROTHERS AJ			
BIERMAN SR				5-09919	7-09919	11-09919	
1-10805	1-10825	6-10805	13-10825	BROWN CL			
BLACK DE				1-10718	12-10718		
14-11817				BROWN JR			
BLAKE VE				17-11102			
4-10261				BROWN WR			
BLAKELY JP				4-09679	4-09682		
17-11972				BROWNING WE			
BLANCO RE				7-09536			
14-11522				BRUNA JG			
BLANTON RW				1-10619	6-10619		
4-11504				BRUNET JP			
BLICK EF				1-10619	6-10619		
7-09757				BRUUN A			
BLOCK DL				9-11842			
11-10186				BRYANT H			
BLOMEKE JO				17-07713	17-07714		
14-11356				BRYANT PM			
BLOOD CM				14-11479			
7-09519				BUCHANAN JR			
BLOOMQUIST CA				1-12019			
15-11595				BUFFONI G			
BLUESTEIN I				6-10820			
6-10143	9-10143			BULL GV			
BLUMENTHAL B				16-11981			
6-11400				BUMP TR			
BLUMENTHAL JL				6-09915	9-09915	9-10439	18-09914
4-09681				BUONI FB			
BOARDMAN C				17-07751			
14-11816				BURGIO R			
BODENSCHATZ CA				4-11491			
6-11283				BURT AK			
BOEGLY WJ				15-11470			
14-11356				BURTON EJ			
BOLOTIN VF				6-09699			
7-10177				BUSEY H			
BOND JA				7-11270	18-11270		
5-10208				BUSEY HM			
BONYHADY KA				7-09752			
9-10150				BUSH WR			
BORNAND B				15-11783			
1-12041	5-12041	19-12041		BUSSI J			
BOROVIK ES				11-09774			
5-11469				BUTLER DK			
BOROWCZYK M				6-09713	6-09714	8-09714	
14-11343				BUTLER FE			
BORTOLI M				15-11960			
15-11358				BUTTERWORTH RR			
BOULOGNE AR				9-11620			
15-11960				BYRD JS			
BOURNE AJ				9-11487			
9-11489				BYRNE JT			
BOURNE JG				1-10114	11-10114	13-10114	
6-11797	17-11797			CAIZERGUES R			
BOWEN PJ				1-10619	6-10619		
16-11983				CALIGIURI GP			
BOWMAN GG				6-10389	9-10389		
16-11982				CALLADINE CR			
BOYD RL				11-11589			
16-11983				CAMBRAY RS			
BOYETT RH				15-11134			
15-10100				CAMPBELL RJ			
BOYLE TJ				17-11965	17-11966	17-11967	17-11968
4-11494				17-11969	17-11970		
BRACKENBUSH LW				CAMPISE AV			
9-11629				18-11333			
BRADBURY HG				CANFIELD R			
16-10775				17-07700	18-07700		
BRADSHAW RL				CANOSA J			
14-11956				6-11380			
BRAMSON PE				CARD MF			
15-11813				11-10186			
BRASACK G				CARLANDER R			
15-10253				6-09711	7-09711		
BRAY LA				CARLSON WJ			
14-11663				9-12086			
BRETSCHER MM				CARMICHAEL BM			
6-09715				6-09766	6-12091	7-09766	9-12091
BRICKSTOCK A				CARPENTER SG			
6-11281				6-09723			
BRIGGS NH				CARR WH			
9-09801				12-09791	13-09791		

CARROLL RM			
7-09372			
CARTER LL			
1-10825	13-10825		
CARTER TJ			
17-07743			
CARVER JR			
5-09550			
CASEY D			
18-11333			
CASSANO AJ			
5-10210			
CASTAGNA M			
5-09965	7-09965	11-09965	
CAVALCANTI RC			
7-12078			
CAVALLARO L			
11-12040			
CELLERINO A			
7-12078			
CHALMERS JH			
1-10618			
CHAMBERS JE			
5-10572			
CHAN HC			
11-10169			
CHANDRASEKARON VR			
15-11623			
CHANDRASHEKHARA K			
11-10165			
CHANG TY			
11-11449			
CHARAK I			
8-11403			
CHARASH E			
16-11264			
CHARLESWORTH DH			
5-09557	12-09557	17-09557	
CHASANOV M			
6-09743	8-09743		
CHASE RL			
9-10286			
CHASE WL			
8-10108			
CHASSANY JP			
12-10262	17-10262		
CHASTAIN RH			
17-11148			
CHAUMONT JM			
6-09825			
CHEATHAM OC			
17-10095			
CHEN JC			
17-11334			
CHERNENKO VS			
5-09917	11-09917		
CHERNICK J			
17-11136			
CHI JW			
5-10271			
CHIRICO DI G			
17-11798			
CHOCK KJ			
6-09399			
CHOUDARD P			
3-09526			
CHRISTENSEN J			
17-09797			
CHRISTIANSON RC			
17-07704			
CHWASZCZEWSKI S			
6-09994			
CIBOIS M			
1-10250			
CLARK JA			
5-11171	5-11474		
CLARK TG			
15-10100			
CLARKE WJ			
15-11779			
CLARKE WL			
17-11101			
CLAYTON ED			
1-09992	1-10825	13-09992	13-10825
CLEMENZ B			
4-11491			
CLEVE U			
17-11602			
CLIFFORD FL			
17-11946			
CLOUET D ORVAL C			

1-10619	6-10619		
COATES RL			
5-10475	15-10475	18-10475	
COE RJ			
18-10832			
COEN V			
6-09781	7-09781		
COFFER CO			
17-07755			
COHENDY G			
12-10262	17-10262		
COHN C			
6-09714	8-09714		
COHN CE			
6-09715	6-11378		
COLLICOTT HE			
5-09556			
COLLVER MM			
15-11826			
COLOMBO RL			
5-09965	7-09965	11-09965	
COMAR CL			
14-11531	15-11531		
COMMANDER RE			
14-11817			
CONDON WJ			
15-11810			
CONNELLY DJ			
5-10572			
COOPER ED			
14-11817			
CORLETT RF			
1-07718	17-07718		
CORNELL DC			
11-12039			
CORNWELL RS			
5-11386			
CORUM JM			
11-09861			
COTTRELL WB			
5-10174	7-09758	7-10174	11-10174
COUGHLIN RW			
5-09549			
COUGHREN KD			
9-12082			
COUMOU KG			
5-09555			
COUSINS N			
2-09851			
COWAN A			
5-09920	5-11234	11-09920	11-11234
18-11234			
COWELL W			
11-11586			
COWSER KE			
15-11523			
COX AL			
4-11504			
CREUTZ E			
13-09304	17-09304		
CREVELING HF			
5-11389			
CROCKER GR			
15-11780			
CROKE EJ			
6-09714	8-09714		
CROSS NF			
1-12019			
CROWLEY JH			
17-11150			
CROWTHER H			
11-09756			
CRUME EC			
1-10932			
CULVER HN			
5-11384			
CUNNINGHAM JE			
17-11137			
CUPINI E			
1-10824			
CUSTODERO S			
17-11431			
CUTFORTH DC			
7-07739	17-07739		
DAILEY A			
4-11492			
DALKE CA			
17-07701			
DALRYMPLE EW			
11-11979			
DANIEL IM			

11-11588				DORLING EB			
CARDER A				16-11983			
15-11528				DOULL J			
DARKE RS				15-11975			
9-11110				DOUSSET M			
DARRAS R				15-11530			
8-10399				DOYLE EF			
DAUGHTRY J				6-11797	17-11797		
6-09701	8-09701			DUBOIS KP			
DAVIDSON RH				15-11973	15-11974		
17-07738				DUERKSEN JH			
DAVIES AR				5-09557	12-09557	17-09557	
6-11281				DUHAMEL F			
DAVIES DK				3-09850	12-09850	15-09850	
11-10220				DULIN RV			
DAVIES MJ				17-07754			
16-11983				DUNCAN KP			
DAVIS DM				15-11800	15-11802	17-11800	
15-10092				DUNSTER HJ			
DAVIS K				15-11526	15-11800	17-11800	17-11801
1-10405				DYBOWSKI K			
DAVIS W				6-09994			
14-11357	14-11522			DYER HL			
DAWSON DG				6-09714	8-09714		
5-11393				DYSON ED			
DAY WC				1-10257	15-10252		
14-11821	15-11821			EAKINS JD			
DE BRUIN C				15-11482			
5-09552				EAMES AR			
DE HEER CD				9-10154			
5-09552				EASTMAN R			
DE MATTEIS A				9-10146			
1-10824				EDLUND MC			
DE SAINT MAURICE A				9-10285			
17-07700	18-07700			EDWARDS DR			
DE VOLPI A				9-07761	17-07761		
6-09716	9-09716			EDWARDS HD			
DEBACKER W				16-11981			
6-11439				EDWARDS JA			
DEBRAY W				5-10215			
5-09966	7-09966	11-09966		EICH WJ			
DEKKER NH				6-11023	9-11023		
5-09552				ELDER GE			
DELAGUNA W				17-07759			
15-11307				ELLIOT MN			
DELAPAZ A				14-08809			
7-07742	17-07742			EMPSON FM			
DELORENZO JT				14-11356			
7-09677				ENGDAHL RE			
DEMASTRY JA				5-10210			
5-09921	11-09921			ENGELMANN RJ			
DEMIER WV				16-11263	16-11987		
14-11662	15-11662			ENGEVIK R			
DEMMITT TF				9-11839			
7-09596				ENGLAND GL			
DENIELOU G				11-09860	11-10168		
1-11399				EPLER EP			
DENKINS RF				9-07757	17-07757		
12-09831	13-09831	18-09831		ERGEN WK			
DERUYTER AW				6-09358			
15-11957				ERION TL			
DICKERMAN C				11-07745	17-07745		
6-09722				ETTINGER HJ			
DICKERMAN CE				7-09752	7-11270	15-11360	18-11270
6-09711	7-09711			EVANS HD			
DIECKAMP HM				15-09499			
4-09685				FAUSKE HK			
DIETZ KA				5-09639	5-11455		
5-10578	6-10578	7-10578		FEARNEHOUGH AC			
DINGLE AN				5-11234	11-11234	18-11234	
16-11279				FEARNEHOUGH GD			
DIONNE PJ				11-11447			
9-12082				FEHLING J			
DITTO SJ				11-11768			
9-10383				FEIGENBUTZ LV			
DIXON FE				5-10572			
1-10251	3-10251			FERRELL JK			
DIXON GJ				5-10213	5-11226		
17-07750				FERRI E			
DOAN RL				15-11306			
17-10749				FERRO A			
DOERNER RC				5-09965	7-09965	11-09965	
6-09714	8-09714			FIDLER R			
DOLPHIN GW				11-10167			
15-08806	15-11800	15-11803	17-11800	FIELU FR			
DOMER RG				9-07762	9-07763	9-11628	17-07762
17-11677				17-07763			
DONDES S				FINNEAR TC			
14-11823				11-11447			
DOGSE C				FIOCCHI R			
17-09859				7-09764			

FIRST MW				GIBB M			
14-11703				11-11585			
FISCHER DF				GIBSON JA			
6-09743	8-09743			15-11470			
FISCHER GJ				GIESEKE JA			
6-09706				5-10407	7-10407		
FISH BR				GILLEY LW			
15-10100				17-11149			
FISHER EM				GILLIES J			
15-11134				5-11234	11-11234	18-11234	
FISTEDIS SH				GIMMY KL			
11-09862				9-07762	9-11628	17-07762	
FLETCHER RD				GINIER R			
7-09595				5-09554			
FLOWERS CD				GINNA RE			
11-11583				7-09545			
FOGGI C				GIORDANO P			
6-09781	7-09781			1-11398	6-10287	9-10287	
FONTAINE WE				GLASSMAN I			
5-09556				4-11493	8-11493		
FORD CH				GLEN HM			
1-08441	6-08441			12-09831	13-09831	18-09831	
FORD JA				GLOYNA EF			
8-10108	8-10113			14-11774			
FORD JD				GODBEE HW			
17-11368	17-11369			14-11522			
FORGAN R				GOIN RW			
5-11395				6-11284			
FORSTER JJ				GOLINCZAK H			
9-10147				14-11345	15-11345		
FOSTER RF				GOLSON TJ			
14-09877				12-09831	13-09831	18-09831	
FOURNIER J				GOMM PJ			
1-11399				15-11482			
FOX TA				GOOD RC			
1-08441	6-08441			4-09608			
FRANK M				GORBERG Z			
15-10076	15-10084			15-11340			
FREDERICK KJ				GOUSE SW			
17-09306				5-09555			
FREESE CH				GRABEZAK J			
6-09716	9-09716			14-11343			
FRESHLEY MD				GRAHN D			
5-11992	9-11993	17-09871	17-11992	4-11499			
17-11993				GRAY PL			
FRIEDLAND AJ				17-07706	17-11796		
8-10108				GREEN AE			
FRIEND AG				9-11489			
14-11355	15-11355			GREEN DM			
FRIND G				8-10108			
5-11475				GREEN JK			
FRISCH W				16-11280			
1-11398				GREENE JK			
FRY DN				17-07714			
6-10144	9-10144			GREENE ND			
FULLAM HT				5-10572			
1-10257	13-10257	18-10257		GRENNESS M			
FULTYN RV				5-11151	18-11151		
14-11809	15-11809			GRESHO PM			
GAETA NA				4-11498			
14-11355	15-11355			GREWAL KS			
GAGLIONE P				11-11509			
15-11358				GROH EF			
GAGNE GA				6-09706			
6-11483				GRONROOS H			
GALATI A				6-11139			
6-10820				GRONWALL B			
GALL DA				17-11962			
6-11797	17-11797			GROSH RJ			
GALLAGHER EV				5-09556			
11-11976				GROVER JR			
GALLAGHER JM				14-08809			
9-10146				GROVES GV			
GALLI DE PARATESI S				16-11983			
6-09781	7-09781			GROZIN BD			
GARRICK BJ				5-09917	11-09917		
9-10149				GRZYBOWSKA D			
GATZ DF				14-11341			
16-11279				GUILLLOU RB			
GAUERKE RC				15-11653			
3-11301				GUNBY AL			
GEKLER WC				9-12086			
9-10149				GUSTAFSON EA			
GELINAS RJ				17-07705			
6-11157				GYFTOPOULOS EP			
GENCO JM				6-09985			
5-10407	7-10407			HAEFELE W			
GERRITY JP				6-11638			
16-11984				HAFELE W			
GERTZ D				1-12022			
6-11639	9-11639			HAGEN JI			

6-11284					HOH JC				
HALFEN FJ					15-11595				
6-11162					HOHMANN GL				
HALFORD GR					9-12093				
11-09604					HOLLAND JZ				
HALL D					16-09651				
17-11965	17-11966	17-11967	17-11968		HOLLAND LB				
17-11969	17-11970				17-11149				
HALVERSON SL					HOLLAND LK				
16-09568					17-11144				
HAMADA K					HOLTZ RE				
11-11584					5-10207				
HAMILTON GN					HOLZ HB				
6-07756	17-07756				18-11333				
HANAUER SH					HONKA EK				
6-10144	9-10144				6-11283				
HANDLEY TP					HORTON NR				
15-11521					5-10475	15-10475	18-10475		
HANLEN DF					HORTON TR				
6-07756	17-07756				11-09750				
HANNAFORD J					HORVAY G				
6-11843	9-11843				11-11446				
HANSEL JG					HORWILZ EP				
4-11493	8-11493				15-11595				
HANSEN AI					HÖSTETLER DR				
17-07743					6-11440				
HANTKE HJ					HOUINAM RF				
17-11602					15-11476				
HARDE R					HOUSNER GW				
6-11268	14-11268				11-09863				
HARDIE RW					HOWDEN JL				
4-11159	6-11159				3-11423				
HARDY EP					HOWES JE				
14-11819	15-11819	16-10768			7-09537	7-09597	7-10583		
HARRER JM					HOWL DA				
9-10148	17-10148				11-12042				
HAPRIS ER					HSU CJ				
17-11941					5-10754				
HARTECK P					HUANG CJ				
14-11823					5-10754				
HARVEY HW					HUBNER W				
15-11595					17-11962				
HARY LB					HUDSON DE				
17-07751					11-09863				
HASANEN E					HUERLIMANN T				
15-11958					6-10821				
HATCH LP					HUGHES A				
7-09765					15-11134				
HATSHORN WR					HUMMEL HH				
9-11628					6-09713				
HAUETER RL					HUNT JA				
17-07704					17-10172				
HAUG RM					HURLEY TJ				
14-11354	15-11354				9-11628				
HAUGSET K					HURT SS				
6-11282					17-09786	17-10204			
HAUSLER LM					HUSSEY FL				
17-07704					17-09279				
HAUSSERMANN W					HWANG RN				
16-10772					6-09706	6-09707	6-09714	8-09714	
HAWLEY CA					IINUMA TA				
14-11633	15-11633				15-11956				
HEARN TO					INGRAHAM HS				
6-12092	9-12092				15-11596				
HEINRICH LA					IRISH ER				
9-11773	17-07764				14-11522				
HEJTMANEK H					IRVINE WH				
6-09823					11-09759				
HELM F					ISHIGURO Y				
6-09705					6-09542				
HELM FH					ISO Y				
6-09704					18-10173				
HELM JW					ITAGAKI H				
5-08969	5-12073				11-11766				
HELMS RE					IVINS RO				
8-10110					6-09742	8-10397			
HERCZYNSKA E					IYENGAR KT				
14-11344					11-10165				
HERFORTH L					JABLONOWSKI EJ				
15-10076	15-10084				5-09921	7-09537	7-10583	11-09921	
HESSON GM					JACKSON S				
5-11760	5-11992	5-11993	17-11992		15-08806				
17-11993					JACKSON TW				
HEUSENER G					5-09551				
1-11398					JABLONOWSKI EJ				
HICOCK R					7-09597				
18-11952					JAECHE JL				
HIDY GM					17-09588				
7-10590					JAIN KC				
HOFFMAN HW					6-09702				
5-10215	5-10216				JAKEMAN U				

6-11006	9-11006			KIEFER TF	
JAMES LR				7-12080	
6-11283				KIEFHABER E	
JAMES PR				6-11401	
6-11849				KIER PH	
JANKOWSKI FJ				1-09703	6-09703
15-11409				KILLIAN CB	
JANSEN G				17-09302	
14-11662	15-11662			KILSBY ER	
JENSEN SE				11-10259	
5-11405	8-11405			KING JW	
JENSON DK				7-10175	
14-11959	15-11959			KING LJ	
JOHNSON CR				14-11522	
17-11243				KIRCHER JF	
JOHNSON DR				5-12076	7-12076
15-11658				KIRN F	
JOHNSON JA				6-09709	
6-11283				KIRN FS	
JOHNSON JE				6-10139	9-10139
15-11529	18-11904			KJAERHEIM G	
JOHNSON MT				9-11841	
17-07712				KLEMENT AW	
JOHNSON R				15-11594	16-09651
7-09765				KLINE KH	
JOHNSON RJ				6-11434	
6-11378				KNAPP WG	
JOHNSON RM				6-09714	8-09714
17-11788				KNIGHTS HC	
JOHNSON T				11-09773	
6-09701	8-09701	15-11421		KOCRICK F	
JOHNSTON K				6-09701	8-09701
7-09782				KOLEHMAINEN S	
JORDAAN JM				15-11958	
14-11641				KOLOTYRKIN YM	
JORDAN ED				1-10409	
5-11385				KOLTZ RJ	
JOSEPH L				7-10581	
17-11669				KORTHEUER JD	
JOYCE DE				17-11145	
9-12081				KOSIK NA	
JUDD DF				5-11469	
5-12237				KOSMATA HR	
KAHN JE				17-11442	
12-09831	13-09831	18-09831		KOSTERKIEWICZ A	
KAKARALA CR				15-11342	
5-09550				KOUTS HJ	
KANAZAWA T				1-10411	
11-11766				KOVAC LR	
KANGOS JD				8-10108	
16-11984				KOWALEW A	
KANN WJ				18-11336	18-11426
6-09915	9-09915	18-09914		KRAMEROV AY	
KAPLAN S				11-11622	
6-09399				KRANZ IH	
KARAM RA				4-11497	
6-09705	6-09712	6-09714	6-09719	KRAUS KA	
8-09714				5-10753	
KARNIEWICZ W				KRAUS W	
15-11342				15-10253	
KASTEN PR				KRAUSE P	
6-09824				6-09741	
KASTNER J				KREMSER J	
16-09568				1-10619	6-10619
KATO WY				KRESS TS	
6-09704	6-09705	6-09714	8-09714	7-09229	7-09832
KEETON DC				KREWER KH	
5-11384	5-11761	6-11267		1-11398	
KEIL RW				KRISTIANSON BN	
9-10014				6-09701	8-09701
KEILHOLTZ GW				KRZYSIAK B	
7-12077				14-11345	15-11345
KEIM M				KUMAR R	
18-11333				5-11297	
KELBER CN				LABAUVE RJ	
6-09701	8-09701			6-12091	9-12091
KELLER FR				LACHAPELLE DG	
17-07747				14-11702	
KELMAN LR				LADET J	
18-09770				1-11399	
KESSLER G				LALIT BY	
1-11398				15-11623	
KETTNER D				LAMBERTUS H	
17-11965	17-11966	17-11967	17-11968	12-09303	17-09303
17-11969	17-11970			LANGFORD FL	
KEY JA				17-11145	
9-10386				LANZA F	
KEYS RD				6-09781	7-09781
7-12080				LARKE EC	
KHANDEKAR RN				11-11587	
15-11624				LARSON HJ	

1-07715	17-07715			1-10695	6-10695	18-U9770
LAUMETS E				LOOSEMORE WR		
15-11792				9-11764	15-11764	
LAUTZENHEISER CE				LOWDER WM		
11-11632				15-11810		
LAVIE JM				LOWE SD		
3-09850	12-C9850	15-09850		7-07742	17-07742	
LAWRENCE LA				LOY ET		
9-10466				15-11655		
LAWRENCE RA				LUCKS H		
5-11108	17-11108			15-11827		
LEAKE JW				LUNDGREN DA		
9-11762	15-11480			7-09361	7-09364	
LEDUC J				LURIE H		
5-09554				5-10217		
LEDWIDGE TJ				LUST LF		
7-10582				14-11824		
LEE RA				MACDONALD FR		
5-12237				5-10572		
LEE, PK				MACDONALD RN		
14-11809	15-11809			6-11378		
LEES GM				MACFARLANE DR		
5-11234	11-11234	18-11234		6-09721		
LEGGE IK				MACKALLOR JA		
15-11800	17-11800	17-11801		15-11659		
LEIBOWITZ L				MACKENZIE A		
6-09743	8-U9743			11-11979		
LEIBY DW				MACPHERSON RE		
17-11143				8-10110		
LELLOUCHE GS				MADELL JT		
17-11136				6-09710	6-09714	8-09714
LEMAIRE J				MAESER PH		
1-10250				15-11825		
LEMAN D				MAGATA M		
17-07714				16-11262		
LEMAN JD				MAGNO PJ		
17-07708				15-11306		
LEMCOE M				MAHAFFEY MK		
5-11396	12-11396			5-11387		
LENCE JT				MAIDMENT L		
12-11733				7-10582		
LENGEMANN FW				MAIN G		
14-11531	15-11531			6-09704		
LENK PA				MAINSTONE JS		
9-10136				16-11082		
LEPIK U				MALAKHOF V		
11-11448				1-10656	13-10656	
LERIDON A				MALMBERG T		
1-10695	6-10695			1-11398		
LEVENSON M				MALVICINI A		
1-11407				15-11358		
LEVERETT MC				MANNESCHMIDT JF		
1-08785				13-11704	14-11704	15-11704
LEVINE J				MARCOWITZ SM		
6-11639	9-11639			15-11827		
LEVINE S				MARGOLIS SG		
17-10749	18-09869	18-11094		6-09399		
LEWIS VG				MARK II		
17-07751				18-09868		
LEWIS WH				MARKOV KP		
13-11942	17-11942			9-11597	15-11597	
LIEDENBERG DH				MARKVART J		
5-11748				1-10115		
LIIMATAINEN RC				MARQUARDT W		
8-10112	8-10397			16-09574		
LINIECKI J				MARRIOTT AJ		
15-11342				3-11423		
LISTER BA				MARSHALL RC		
15-08806				5-10756		
LITTING BG				MARTIN J		
11-10744				6-09825		
LITTLE WW				MARTIN JP		
4-11159	6-11159	6-11598		4-09690		
LIU BY				MARTIN RD		
7-09363				17-07753		
LIVETT RK				MARTIN RL		
5-10572				7-12079		
LJUNGBERG L				MARTIN WE		
17-11962				14-11353	15-11353	
LLÖYD RC				MARYOTT JL		
1-09992	1-10825	13-09992	13-10825	6-10823		
LOCKHART LB				MATHIS A		
14-11347				6-10287	9-10287	
LOEWENSTEIN WB				MATTY TC		
6-09709	6-09713	6-09714	6-10139	6-10143	9-10143	
6-11400	8-09714	9-10139		MCCARTHY WJ		
LOHSE GE				7-11945	17-11945	
14-11817				MCCASLIN JB		
LONG EL				15-09510		
7-10296	17-11137			MCCLENDON L		
LONG JK				15-11828		

MCCONNELL LG					7-12074			
17-11142					MONAWECK JH			
MCCOOL WJ					6-09716	9-09716		
1-07717	17-07717				MOORE JC			
MCCORMACK JE					9-10155	12-09534	17-10155	
15-09563	17-09563				MORGAN A			
MCCREARY JC					15-08810			
9-10136					MORGAN JM			
MCCUE JK					3-11302			
17-09280					MORGAN WR			
MCCULLOUGH CR					17-11146			
1-10405					MORRISON DL			
MCELROY DL					5-10407	7-09537	7-09597	7-10407
9-09801					7-10583			
MCEWEN LH					MORRISON GW			
17-09309	17-09818				1-10932			
MCFADDEN PW					MORTON WA			
5-11388					5-10572			
MCGAUGH JD					MOSES H			
18-11237					16-09568			
MCGEE JW					MOSS WD			
5-10213					7-09752	7-11270	18-11270	
MCGINNIS FD					MOUGNIOT JC			
11-07746	17-07746				1-09995	6-09995		
MCGRATH RG					MOURITZEN G			
17-07748					5-10572			
MCKIBBEN JM					MOWBRAY DF			
17-07707					11-10187			
MCMINN SJ					MUELLER EA			
11-10169					16-09568			
MCVEAM RL					MUELLER M			
1-10695	6-10695				6-09711	7-09711		
MCVEAN RL					MUELLER RA			
18-09770					1-08441	6-08441		
MEAD SW					MULLIKIN MS			
18-11804					15-09562	17-09277	17-09562	
MECHALI D					MUNNS JM			
15-11530					6-11472	9-11472	9-11485	
MEHANN RO					MURPHY CH			
11-11953	17-11953				16-11981			
MELLOR AM					MURPHY TL			
4-11493	8-11493				17-11101			
MELUCCI G					MURRAY HS			
6-10287	9-10287				4-09577	6-09577		
MENEGHETTI D					MURRAY WB			
6-09708	6-09713				17-11141			
MENELEY DA					MUSTARD GL			
6-09706					9-11771	15-11771		
MERCER BW					NA TY			
14-11522					5-11474			
MERK W					NASSER KW			
1-11398					11-11445			
MERKLE JG					NATELSON M			
11-10185					6-10828			
MERLI E					NATH RJ			
17-11798					17-11145			
MERRIAM RL					NEAL LG			
5-09996					5-10211	6-09739	19-09739	
MEYER K					NEILL FH			
6-09541					7-09229			
MEYERS JE					NELSON CL			
8-10108					17-07714			
MICHELSON C					NELSON DJ			
7-10296					14-09539			
MIELCARSKI M					NELSON LL			
18-11336	18-11426				11-11590			
MIETTINEN JK					NELSON LS			
15-11958					8-10256			
MIKHAILOV IF					NELSON SL			
5-11469					17-07711			
MIKULAS MM					NEMILOV NF			
11-10186					7-10177			
MILES CC								

NIJSING R				18-11333		
5-10755				PEI DC		
NISHITA H				5-09626		
14-11354	15-11354			PEJTERSEN VS		
NOBLE LO				5-11151	18-11151	
6-09822				PEKRUL PJ		
NORRIS ER				9-07749	17-07749	
17-11241				PCNG L		
NOVICK M				16-12017		
18-09770				PENOTET M		
NURMI FO				15-11530		
13-09305	17-09305			PERDUE PT		
OAKES LC				15-11658		
9-10387				PERKINS RW		
OBOYLE MJ				16-11987		
17-10102	17-11625			PERRIGO L		
OBRIEN HG				17-07741		
9-10383				PERRY DR		
OCCHIPINTI ES				15-11812		
9-07763	17-07763			PERRY JE		
OHLENKAMP RM				4-11500		
4-11495				PERSIANI PJ		
OI N				6-09915	9-09915	10-09914
7-09753				PERTSOV LA		
OKRENT D				15-11831		
18-09453	18-10116			PETERS NT		
OLESEN CB				17-11138		
17-09797				PETERSON CM		
OLSON HP				7-09361	7-09363	
9-11840				PETERSON JP		
OMBERG RP				17-09588		
5-11391				PETERSON JR		
ORR WL				5-10208		
17-11147				PETERSON RH		
ORSONI L				17-09565		
17-11431				PETERSON S		
OSBORN RK				8-10304		
6-10828	6-11157			PETRENKO LI		
OSGOOD SH				1-10409		
7-12080				PETRICK M		
OTSUKA M				6-U9702		
6-09543				PFANN J		
OTT K				1-10115		
6-11401				PHILLIPS KE		
OTTER JM				6-09713		
6-09723				PICONE LF		
OVERHOLSER LG				17-11998		
7-09519				PIERCE BL		
OZISIK MN				5-11383		
7-09582				PITTS TG		
PAIGE BE				6-11440		
14-11661				PLEUTHNER RL		
PALMER HE				4-09679	4-09682	
15-11525				PLISSON J		
PALOTAY JL				9-11640	17-11640	
15-11955				PLUMLEE K		
PANCOAST JT				6-09701	8-09701	
5-11108	9-07760	17-07760	17-11108	PLUMLEE KE		
PANISKO FE				6-09715		
17-09871				PLZAK V		
PANTER R				15-11975		
17-07752				POMREHN HP		
PARDO G				9-10149		
15-11530				PON GA		
PARK JF				18-10164		
15-11779				POOR CF		
PARKER FL				17-11143		
14-11356				POPENOE P		
PARKER GH				15-11656		
4-11494				POPPENDIEK HF		
PARKER RJ				5-10572		
11-11587				PORGES KG		
PASCHALL RK				9-09717		
6-09723				PORSCHING TA		
PASCOUET A				6-09993		
5-11411				POSTON JW		
PATTERSON HW				17-11149		
15-11961				POTURAJ-GUTNIAK S		
PATTERSON LR				18-11336	18-11426	
18-11902				POUCHER FW		
PATTERSON RL				4-11498		
14-11347				PRICE RB		
PAUL RA				7-12079		
14-11821	15-11821			PROSZYNSKA K		
PAVLICA RT				14-11344		
5-10756				PROWETT RH		
PAXSON E				4-11497		
6-11808	17-11808			PUECHL KH		
PEARCE DW				17-11947		
16-11200				PUGH J		
PEARSON E				1-10618		

PUIG I				11-10189			
1-11399				ROBINSON GC			
PURDY KR				11-09750			
5-09551				ROBINSON LE			
PURVANCE RT				6-09711	6-09716	7-09711	9-09716
6-09716	9-09716			ROBINSON W			
PYDER FD				6-09701	8-09701		
9-11628				RODABAUGH EC			
QUINN EP				11-10745			
5-11758				RODIER J			
QUIRK A				12-10262	17-10262		
11-09759	11-11447			ROGERS JT			
QUON JE				5-09843			
7-10580				ROHRBACHER RA			
RABENAU A				9-09578			
5-09952	7-09952	8-09952		ROLSTAD E			
RADEKA V				9-11838			
9-10286				ROM FE			
RADWAN M				1-11404	4-11404		
14-11345	15-11345			ROMM RF			
RAHM G				1-10409			
15-11814				ROSENBERG HS			
RANDOLPH P				7-12079			
14-11816				ROSLER U			
RASHID YR				5-09966	7-09966	11-09966	
11-10171				ROSS CP			
RASTOGI RC				7-10270	9-07758	17-07758	18-10270
14-11786				ROSSI FS			
RAWSON D				5-09965	7-09965	11-09965	
14-11816				ROTH JM			
RECHT P				11-07745	17-07745		
15-11527				ROTHWELL E			
REDMAN WC				15-11481			
6-09715				ROUX DP			
REED G				6-10144	9-10144	9-11772	
17-11667				ROYDEN HN			
REED HF				6-09723			
6-09701	8-09701			RUBEL H			
REICKS GH				5-09966	7-09966	11-09966	
9-11441				RUBEL P			
REIDER R				9-11488			
4-11503				RUIZ CP			
REILLY JJ				17-09588			
7-09765				RUNION TC			
REINKE CF				13-09308	17-09308		
9-11765				RUSCH GK			
REIST PC				6-09704	6-09705		
15-11714				RUSCHE BC			
RENFRO GW				7-10270	18-10270		
12-09831	13-09831	18-09831		RYABOV NV			
RENTSCHLER W				9-11597	15-11597		
16-10772				RYAN JT			
REYER RJ				15-11421			
11-07744	17-07744			SABIN CM			
REYNOLDS AB				5-10572			
1-10695	6-10695			SACKMAN JL			
REYNOLDS MB				11-10260			
11-11769				SAGET P			
RHODE GK				11-11591			
9-10285				SAITO K			
RICCHENA R				6-09543			
6-09781	7-09781			SAKAKURA A			
RICHEY CR				18-10173			
1-09992	1-10825	13-09992	13-10825	SALLERON C			
RICKER CW				1-10258	3-10258		
6-10144	9-10144			SALMON MA			
RIDER BF				11-11977			
17-09588				SALMON R			
RIEBOLD W				3-11381			
6-09781	7-09781			SAMUELS DE			
RIESLAND JI				11-11978			
17-07705				SANATHANAN CK			
RINALDINI C				6-09702	6-09720		
6-09781	7-09781			SANDERS M			
RIPARBELLI C				15-09876			
11-12039				SANTY MJ			
RISING FL				4-09681			
9-11770	15-11770			SAVIDGE RE			
RITZMAN RL				11-10187			
5-09921	5-10407	7-10407	11-09921	SAVIO RP			
RIVERA J				6-09701	8-09701		
14-11819	15-11819	16-10768		SAVITSKII PS			
RIVERS RD				1-10409			
7-12072				SAWOCHKA SG			
ROBERTS FP				5-10209			
14-11663				SCHAEFFER G			
ROBERTS JT				11-11768			
14-11522				SCHAEFFER JR			
ROBIN M				16-10771			
1-11399				SCHAEFFER WF			
ROBINSON CW				14-11356			

SCHILTZ RJ		9-10826		
6-09716	9-09716	SKARPELOS JM		
SCHLOSSER W		8-11413	17-11413	
9-10386		SKEEN DR		
SCHMID P		1-09992	13-09992	
6-10821		SKREPPEN H		
SCHOENHALS RJ		17-11332		
5-11388		SMALLEY WR		
SCHONFELD E		6-11808	17-11242	17-11808
1-11398	14-11357	SMIDT O		
SCHULTZ MA		1-11398		
6-10143	9-10143	SMITH BE		
SCHULTZ V		5-09918	11-09918	
15-11594		SMITH D		
SCHUYLER DR		5-11761	6-11267	
17-11101		SMITH DG		
SCHWARTZ F		15-11714		
11-11979		SMITH EH		
SCHWARTZ PE		17-11367		
5-10572		SMITH ER		
SCHWARTZBERG FR		7-07742	17-07742	
7-12080		SMITH FA		
SCHWEIGER F		5-11456	8-11403	
17-11602		SMITH IC		
SCOTT JL		6-11281		
7-10296		SMITH JL		
SCOTT RL		1-11408		
17-11988		SMITH KF		
SEHGAL JDU		15-11660		
14-11786		SMITH LR		
SELLERS AJ		5-10212		
5-10218		SMITH RI		
SEMENOV PA		6-10823		
5-11392		SMITH RR		
SESSLER J		6-09709		
11-11509		SMITH WR		
SETTER LR		17-11792		
15-11306		SNYDER WS		
SEXTON IB		15-09569	15-11523	
4-11495		SOKOL GJ		
SEYMOUR RS		11-10187		
17-09588		SOLANAS J		
SHAFTMAN DH		15-11528		
6-09701	8-09701	SOLOVEV AV		
SHAPIRO NZ		5-11392		
7-12075		SOMMERS JF		
SHAPLEY LS		15-11660		
7-12075		SOWARDS NK		
SHAPPERT LB		17-07719		
3-11381		SPEIGLER P		
SHAW HK		18-11333		
4-11494		SPICER GS		
SHEFF JR		15-11134		
6-09738	6-11379	SPINRAD BI		
SHEINBER H		6-09714	8-09714	
9-10014		SPRINGER TE		
SHERWOOD RJ		6-11283		
7-08811		SPRUCE TW		
SHEVELEV YV		11-09821		
11-11622		ST. PIERRE CC		
SHIH CS		5-11749		
14-11774		STANFORD G		
SHIMAZAKI TT		6-09701	8-09701	
5-11390		STAS KN		
SHIPMAN WH		9-11597	15-11597	
14-11777	15-11777	STASIUR J		
SHLEIEN B		14-11345	15-11345	
14-11355	15-11355	STEBBINGS RF		
SCHOENHALS RJ		16-11983		
5-11389		STEED JA		
SHOPTAUGH JR		12-09831	13-09831	18-09831
17-07755		STEEN AJ		
SHOTKIN LM		14-11354	15-11354	
5-11172		STEFFINS J		
SHUCK AB		5-11385		
18-09770		STEIN RM		
SHURE F		1-10254		
6-10828		STEIN RP		
SILVERMAN L		5-09627		
15-11714		STEINER GH		
SIMMONS WR		6-11283		
9-10439		STENTZ RH		
SIMON W		9-12088		
1-10656	13-10656	STEPHANY W		
SINIT SIN VI		6-09711	6-09722	7-09711
1-10409		STEPHANY WP		
SISLER JA		6-09701	8-09701	
3-11301		STEPHENSON M		
SIVERTS JG		6-09714	8-09714	
9-11844	17-11844	STEPHENSON SE		
SKARDHAMAR T		6-10144	9-10144	

STERNBERG HI					TAYLOR JF				
17-11148					6-11473				
STERNER JH					TAYLOR RL				
1-11410					11-11449				
STEVENS DC					TEBO FJ				
7-08811					11-07746	17-07746			
STEVENS GF					TELLIER H				
5-11466					1-10619	6-10619			
STEVENS HH					TENNYSON RC				
9-11110					11-10188				
STEWART HF					TESTA FJ				
15-11529					8-10397				
STEWART R					TEVEBAUGH AD				
6-09711	7-09711				6-09743	8-09743			
STEWART SL					THALGOTT FW				
1-10695	6-10695				18-09770				
STILLMAN DB					THIEME GG				
18-11804					9-12082				
STOHR KW					THOMAS CE				
6-11268	14-11268				17-11792				
STONE LR					THOMAS DG				
4-11496					5-10750	5-10751	5-10752	5-10753	
STOREBO PB					THOMAS JT				
14-11524					1-09576	13-09576			
STOREBOE PB					THOMAS JW				
16-11265					17-11790				
STOUT GE					THOMAS KJ				
16-09568					14-11786				
STOWELL EZ					THOMAS RH				
11-10166					17-11793				
STRAIT BG					THOMPSON DH				
9-12093					17-11605				
STROSCHEIN HW					THOMPSON JT				
15-11825					3-11302				
STUART W					THORNGATE JH				
17-11962					9-12087	15-11655	15-11658		
STUTHEIT JS					THUR GM				
9-07763	17-07763				5-10218				
SULC P					TIBBERTS N				
1-10115					17-11140				
SULLIVAN HF					TILL CE				
4-11493	8-11493				6-09706				
SULLIVAN L					TIPPETS FE				
4-11491					5-10208				
SUNDERMAN DN					TOLSON GH				
5-10407	7-09537	7-09597	7-10407		9-10500				
7-10583					TOWNLEY CW				
SVANHOLM K					5-12076	7-12076	7-12079		
9-11845					TREIMAN M				
SWANSON CD					8-12020				
9-12082					TREINEN RL				
SWENSON HS					9-12088				
5-09550	5-12237				TRINKLE JL				
SWIFT D					7-12072				
6-09741					TRINKO JR				
SWIFT DL					6-10144	9-10144			
8-11402					TULIS RC				
SYRKUS NP					11-11397				
1-10409					TURCK B				
SZABO G					15-11471				
5-09965	7-09965	11-09965			TURNER FB				
SZECHTER A					14-11353	15-11353			
6-09994					TURNER RA				
SZEPKE R					18-11235				
14-11341					TURNER SE				
TABOR WH					6-10822				
17-07740	17-09786	17-10204			TUTTLE RJ				
TAIT D					1-11161	6-			

5-11755				WHITESIDES GE			
VANDERVELL HD				1-10932			
15-08810				WHITHAM GK			
VANN HE				11-07746	17-07708	17-07714	17-07746
17-11150				WHITING AR			
VANSLAGER FE				11-11632			
7-10179				WHITLEY EA			
VASSELL GS				15-11960			
17-11140				WHITTEMORE WL			
VENERUS ER				17-07755			
7-09582				WHITTLE D			
VER PLANCK DW				3-11847			
18-11093				WHITTLE RH			
VERRIERE P				5-11395			
1-10619	6-10619			WICHNER RP			
VESELSKY JC				5-10216			
4-11502				WIEBELT JA			
VILLARREAL R				5-11757			
7-07739	17-07739			WIEDERMANN AH			
VITTI J				11-11976			
18-11333				WIERWILLE WW			
VOIGT O				6-11483			
5-10320	11-10320			WIESER PH			
VOLCHOK HL				16-10772			
1A-12010				WILCOX GE			
VOLTA G				9-10151			
6-09781	7-09781			WILKINS BW			
VON BERG RL				3-09564	17-09564		
5-09549				WILL J			
VORTMAN LJ				17-11954			
14-11634	15-11634			WILLIAMS HT			
WACHTEL SJ				6-11023	9-11023		
7-09765				WILLINGHAM WE			
WADE RR				14-11662	15-11662		
4-11495				WILLIS FL			
WAHL HW				6-09716	9-09716		
11-10319				WILLIS L			
WALKER G				6-09711	7-09711		
1-10618				WILLIS WL			
WALKLEY J				6-11473			
14-11703				WILSON RH			
WALLACE R				5-12237	14-09877		
15-11961				WIMBERLY FC			
WALSH JR				4-11498			
17-11951				WINSON RW			
WALTERS CT				6-11486			
5-10407	7-10407			WINTERS WR			
WALTHER H				17-09270			
17-11431				WIRSING E			
WARD DR				7-09765			
17-11149				WOFFORD AW			
WARD GM				17-11112			
15-11529				WOHLBERG C			
WARNKE DF				5-11299			
16-11985				WOLFE GE			
WASSELL LL				6-11440			
15-11481				WONG MK			
WASSERMAN AA				5-10218			
6-11283				WOOD RE			
WASSERMAN RH				1-09686	5-09686		
14-11531	15-11531			WOOD RW			
WATKINS B				5-11466			
5-11233	18-11233			WOODRUFF RW			
WEARNE SH				17-07709			
17-10177				WRIGHT A			
WEIL NA				6-09722			
11-11588				WRIGHT HL			
WEISS V				4-11499			
11-11509	11-11768			WRIGHT RW			
WEISZ M				5-10211			
1-10250				WUNDT BM			
WEITZBERG A				5-09919	7-09919	11-09919	
1-10695	6-10695			WUNDT H			
WELSH EJ				6-10389	9-10389		
17-11087				WYKE TF			
WENTZ LB				17-11145			
5-10211				WYLIE RD			
WESTHEAD JM				17-11244	17-11245		
9-09866				YAM KM			
WHEELER RG				15-11974			
5-11992	9-11993	17-11992	17-11993	YAMAGATA N			
WHEELER RV				15-11956			
15-11827				YAMAOKA Y			
WHEELER V				16-11986			
14-11816				YANG WJ			
WHITBY KT				5-11171			
7-09361	7-09362	7-09363	7-09364	YEE WC			
WHITE J				14-11522			
6-09713				YOSHIKI M			
WHITEHOUSE WJ				11-11766			
1-10252	15-10252			YOUNG AG			

11-10288
YOUNG JF
18-11944
ZALESKI CP
1-11399
ZARNOWIECKI K
15-11340
ZILLES P
14-11703
ZIPPRICH F

14-11823
ZIVI SM
6-09739 19-09739
ZUBER A
14-11343
ZUDANS Z
11-10170
ZWILLENBERG M
4-11493 8-11493

APPENDIX

REFERENCE SOURCES

THE ONLY REPORTS DISTRIBUTED BY NSIC ARE THOSE GENERATED BY THE CENTER, I.E., THOSE WITH ORNL-NSIC NUMBERS. UNDER NO CIRCUMSTANCES ARE COPIES OF THE OTHER REPORTS REFERENCED IN THIS BIBLIOGRAPHY FURNISHED, ALTHOUGH ALL AVAILABLE DOCUMENTS MAY BE EXAMINED AT THE CENTER BY QUALIFIED PERSONNEL.

NSIC HAS INITIATED A NEW FORMAT FOR DOCUMENT AVAILABILITY AND PRICE. THIS INFORMATION IS NOW PRESENTED, WHERE APPLICABLE AND AVAILABLE, IN A LINE TO ITSELF FOLLOWING THE DOCUMENT ABSTRACT. WHERE PREVIOUSLY THE NAME OF THE SOURCE ORGANIZATION APPEARED AT THE END OF THE LINE PRECEDING THE ABSTRACT AND WAS ABBREVIATED, IT IS NOW SPOelled OUT IN THE NEW LOCATION. SINCE IT WILL TAKE SOME TIME TO CONVERT COMPLETELY TO THE NEW SYSTEM, NSIC WILL CONTINUE TO FURNISH A KEY TO THE ABBREVIATIONS. THIS KEY ALONG WITH THE ADDRESSED OF THE SOURCE ORGANIZATIONS FOLLOWS.

AEC-DOS	*AEC, DIVISION OF OPERATIONAL SAFETY, WASHINGTON, D. C.
AEC-FL	AEC FILM LIBRARY, OAK RIDGE OPERATIONS OFFICE, OAK RIDGE, TENNESSEE
AECL	ATOMIC ENERGY OF CANADA, LTD., CHALK RIVER, ONTARIO, CANADA
AIF	ATOMIC INDUSTRIAL FORUM, 850 THIRD AVENUE, NEW YORK 22, N. Y.
APC	AMERICAN POWER CONFERENCE E.R. WHITEHEAD, SECRETARY, ILLINOIS INSTITUTE OF TECHNOLOGY, CHICAGO, ILLINOIS
ASME	(PREPRINTS) AMERICAN SOCIETY OF MECHANICAL ENGINEERS ORDER DEPARTMENT, 345 E. 47TH ST., NEW YORK, N. Y. 10017
BIS	BRITISH INFORMATION SERVICE, 845 THIRD AVE., NEW YORK, N. Y. 10022
CEA	DOCUMENTATION FRANCAISE, SECRETARIAT GENERAL DU GOVERNMENT, DIRECTION DE LA DOCUMENTATION 16, RUE LORD BYRON, PARIS VIIIEME
CFSTI	CLEARINGHOUSE FOR FEDERAL SCIENTIFIC AND TECHNICAL INFORMATION, NBS, USDC, SPRINGFIELD, VIRGINIA
CY	INDICATES THAT THE FORMAT OF THE ITEM SOLD MAY BE EITHER A PRINTED DOCUMENT OR A PHOTOGRAPHIC REPRODUCTION (TWO-THIRDS OF ORIGINAL SIZE) DEPENDING UPON THE AVAILABILITY OF PRINTED STOCK. THE INDICATED PRICE IS FOR EITHER FORMAT.
DDC	DEFENSE DOCUMENTATION CENTER, CAMERON STATION, ALEXANDRIA, VIRGINIA
DEP	AEC REPORTS - FULL-SIZE COPY IS ON DEPOSIT IN THE DEPOSITORY LIBRARIES BOTH INSIDE AND OUTSIDE THE UNITED STATES. THESE REPORTS ARE ALSO FOR SALE BY MICROCARD EDITIONS, INC., ACCOUNTING AND SHIPPING DEPARTMENT, WEST SALEM, WISCONSIN 54669
	NON-AEC REPORTS - FULL-SIZE COPY ON DEPOSIT IN THE DEPOSITORY LIBRARIES IN THE UNITED STATES ONLY.
DEP(MC)	SAME AS FOR DEP, EXCEPT COPY IS IN MICROCARD FORM.
DEP(MN)	SAME AS FOR DEP, EXCEPT COPY IS IN MICRONEGATIVE (MICROFICHE) FORM.
DPI	AEC, DIVISION OF PUBLIC INFORMATION, WASHINGTON, D. C. 20545
GI	GMELIN INSTITUTE, 40-42 VARRENTAPPSTRASSE, FRANKFURT (MAIN) WEST GERMANY
GIH	AMERICAN CONFERENCE OF GOVERNMENTAL HYGIENISTS, 1014 BROADWAY, CINCINNATI, OHIO
GPO	U. S. GOVERNMENT PRINTING OFFICE, WASHINGTON, D. C. 20402
HMSO	(HER) MAJESTY S STATIONERY OFFICE, LONDON
IAEA	INTERNATIONAL ATOMIC ENERGY AGENCY (NEW YORK OR GENEVA)
JCL	JOHN CRERAR LIBRARY, 35 WEST 33RD ST., CHICAGO, ILLINOIS 60616
JUL	JUL. GJELLERUP, 87, SOLVGAD, COPENHAGEN K, DENMARK
MN	USED TO INDICATE THAT COPY IS ALSO AVAILABLE IN THE FORM OF MICRONEGATIVES (MICROFICHE).
NRC	NATIONAL RESEARCH COUNCIL OF CANADA, OTTAWA, ONTARIO, CANADA
NSIC	NUCLEAR SAFETY INFORMATION CENTER, OAK RIDGE NATIONAL LABORATORY, P. O. BOX Y, OAK RIDGE, TENNESSEE 37831
OCE	SAFETY OFFICE, OFFICE OF THE CHIEF OF ENGINEERS, DEPARTMENT OF THE ARMY, WASHINGTON, D.C.
OEEC	O.E.E.C. MISSION, PUBLICATIONS OFFICE, SUITE 1223, 1346 CONNECTICUT, WASHINGTON, D.C.

ORAU	AVAILABLE ON INTERLIBRARY LOAN FROM THE LIBRARY, OAK RIDGE ASSOCIATED UNIVERSITIES, POST OFFICE BOX 117, OAK RIDGE, TENNESSEE 37830.
PATENTS (BRITISH)	THE PATENT OFFICE, 25 SOUTHAMPTON BUILDING, LONDON, W. C. 2, ENGLAND (49 CENTS PER COPY)
PATENTS (FOREIGN)	(OTHER THAN BRITISH) IT IS OUR UNDERSTANDING THAT FOREIGN PATENTS MAY BE OBTAINED IN PHOTOCOPY FROM THE U. S. PATENT OFFICE, DEPARTMENT OF COMMERCE, WASHINGTON, D. C. (30 CENTS PER PAGE)
PATENTS (U. S.)	THE U. S. PATENT OFFICE, DEPARTMENT OF COMMERCE, WASHINGTON, D. C. (25 CENTS PER COPY)
PDR	**USAEC PUBLIC DOCUMENT ROOM, WASHINGTON, D. C.
SOURCE	ORIGINATOR OF DOCUMENT (AUTHOR, CORPORATE AUTHOR, OR PUBLISHER)
UKAEA, (LONDON)	UNITED KINGDOM ATOMIC ENERGY AUTHORITY, 11 CHARLES II STREET, LONDON, S. W. 1
USGS	U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C. 20242

*PREPARED BY USAEC DIVISION OF OPERATIONAL SAFETY, AVAILABLE FROM DOS IF THE SUPPLY OF A PARTICULAR ISSUE IS NOT EXHAUSTED.

**USUALLY DOCUMENTS MAY BE EXAMINED ONLY AT THE PUBLIC DOCUMENT ROOM. OCCASIONALLY EXTRA COPIES ARE AVAILABLE FOR DISTRIBUTION.

DISTRIBUTION FOR ORNL-NSIC-34

INTERNAL

1. T. D. ANDERSON	26. J. G. MERKLE
2. S. E. BEALL	27. C. M. MURPHY
3. J. P. BLAKELY	28. H. G. OBRIEN
4. W. E. BROWNING	29. G. D. PARKER (K-25)
5. J. R. BUCHANAN	30. L. F. PARSLY, JR.
6. D. W. CARDWELL	31. T. H. ROW
7. W. B. COTTRELL	32. J. B. RUCH
8. K. E. COWSER	33. R. L. SCOTT
9. E. N. CRAMER	34. L. B. SHAPPERT
10. F. L. CULLER	35. B. H. STOUTT (K-25)
11. W. K. ERGEN	36. C. S. WALKER
12. M. H. FONTANA	37. J. L. WANTLAND
13. A. P. FRAAS	38. A. M. WEINBERG
14. W. R. GRIMES	39. H. B. WHETSEL
15. F. C. HUTTON (K-25)	40. M. L. WINTON
16. D. G. JACOBS	41. BIOLOGY
17. W. H. JORDAN	42-44. CENTRAL RESEARCH LIBRARY
18. G. W. KEILHOLTZ	45-46. ORNL- Y-12 TECHNICAL LIBRARY
19. F. KERTESZ	DOCUMENT REFERENCE SECTION
20. J. O. KOLB	47-596. LABORATORY RECORDS DEPARTMENT
21. T. F. LOMENICK	597. LABORATORY RECORDS, ORNL R.C.
22. H. G. MACPHERSON	598-747. NUCLEAR SAFETY INFORMATION CENTER
23. W. C. MCCLAIN	J. R. BUCHANAN, BUILDING 9711-1
24. H. C. MCCURDY	748-768. OTHER ORNL INFORMATION CENTERS
25. T. L. MCLEAN	

EXTERNAL

769. W. A. KEE AEC-DTI
 770. F. A. GIFFORD USWB-ORO
 771-774. A. J. PRESSESKY AEC-DRD
 775. J. A. LIEBERMAN AEC-DRD
 776-1054. GIVEN DISTRIBUTION AS SHOWN IN
 TID-4500 UNDER REACTOR TECHNOLOGY
 CATEGORY (25 COPIES - CFSTI)