MASTER

285
4/30

Argonne National Laboratory

REACTOR DEVELOPMENT PROGRAM

PROGRESS REPORT

March 1965

PATENT CLEARANCE OBTAINED. RELEASE TO
THE PUBLIC IS APPROVED. PROCEDURES
ARE ON FILE IN THE RECEIVING SECTION.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

Reactor Development Program
Highlights of Project Activities for March, 1965

EBR-II

Repair of the leaky evaporator was completed. Authorization for power operation was obtained from DRDT and by the end of the month the reactor was operating at 45 MW, the maximum power level planned at this stage. All systems were performing in a stable, satisfactory manner. The turbine generator was in operation and about 14 MW gross was being delivered to the NRTS grid.

FARET

The A-E Title II design of the plant is about 93% complete.

Another meeting was held with an ACRS subcommittee and DRL personnel on the FARET Preliminary Safety Analysis Report.

Bid invitations for the cell shielding windows were sent out.

We are awaiting AEC approval of the reactor vessel vendor selected by the Laboratory.

AARR

Problems continue to be encountered with the fuel being supplied for the AARR critical experiments. Because of these problems, completion of the criticals will probably be delayed.

Preliminary development work with brazed AARR fuel assemblies appears to be promising.

ZPPR

The Architect-Engineer reports Title II work (started in February) to be 29% complete at the end of March.

A two-week extension on the bid date (to March 31) for the bed and tables, was granted.

ARGONNE NATIONAL LABORATORY
9700 South Cass Avenue
Argonne, Illinois 60440

REACTOR DEVELOPMENT PROGRAM
PROGRESS REPORT

March 1965

Albert V. Crewe, Laboratory Director
Stephen Lawroski, Associate Laboratory Director

<u>Division</u>	<u>Director</u>
Chemical Engineering	R. C. Vogel
Idaho	M. Novick
Metallurgy	F. G. Foote
Reactor Engineering	L. J. Koch
Reactor Physics	R. Avery
Remote Control	R. C. Goertz

Report Coordinated by
R. M. Adams and A. Glassner

Issued April 20, 1965

Operated by The University of Chicago
under
Contract W-31-109-eng-38
with the
U. S. Atomic Energy Commission

FOREWORD

The Reactor Development Program Progress Report, issued monthly, is intended to be a means of reporting those items of significant technical progress which have occurred in both the specific reactor projects and the general engineering research and development programs. The report is organized in a way which, it is hoped, gives the clearest, most logical over-all view of progress. The budget classification is followed only in broad outline, and no attempt is made to report separately on each sub-activity number. Further, since the intent is to report only items of significant progress, not all activities are reported each month. In order to issue this report as soon as possible after the end of the month editorial work must necessarily be limited. Also, since this is an informal progress report, the results and data presented should be understood to be preliminary and subject to change unless otherwise stated.

The issuance of these reports is not intended to constitute publication in any sense of the word. Final results either will be submitted for publication in regular professional journals or will be published in the form of ANL topical reports.

The last six reports issued
in this series are:

September 1964	ANL-6944
October 1964	ANL-6965
November 1964	ANL-6977
December 1964	ANL-6997
January 1965	ANL-7003
February 1965	ANL-7017

TABLE OF CONTENTS

	<u>Page</u>
I. Liquid-metal-cooled Reactors	1
A. EBR-II	1
1. Operations	1
2. Reactor Testing	2
3. Maintenance and Modification	2
4. Fuel Cycle Facility	3
B. FARET	6
1. General	6
2. System for Removal of Reactor Vessel Cover	7
3. Static Vessel Tests	9
4. Core Instrumentation	11
5. Design of Core Support	12
6. Fuel Assembly Sodium Flow Test Loop	13
C. General Fast Reactor Physics	15
1. ZPR-3 (FARET Criticals)	15
2. ZPR-6	18
3. ZPR-9	19
4. ZPPR	21
D. General Fast Reactor Fuel Development	22
1. Metallic Fuels	22
2. Carbide Fuel Elements	24
3. Development of Jacket Materials	26
4. Examination of EBR-I Mark-IV Fuel	28
5. Alternative Fuel-element Geometries	28
6. Zero Power Reactor Fuel Development	30
E. General Fast Reactor Fuel Reprocessing Development	30
1. Skull Reclamation Process	30
2. Processes for Advanced Reactor Fuels	31
3. Materials and Equipment Evaluation	33

TABLE OF CONTENTS

	<u>Page</u>
II. General Reactor Technology	35
A. Experimental Reactor and Nuclear Physics	35
1. Prompt $\bar{\nu}$ of U^{235}	35
2. Elastic Scattering of Fast Neutrons	36
3. High Conversion Critical Experiment	38
4. Techniques for Foil-activation Measurements	40
5. Absolute Fission-rate Determination	40
B. Theoretical Reactor Physics	42
1. Equivalence between Homogeneous and Heterogeneous Systems	42
2. Total Neutron Cross Sections	43
C. High-temperature Materials	44
1. Ceramics	44
2. Irradiations of Refractory Ceramic Fuel Materials	48
3. Plated Coating as a Deterrent to Oxidation of Refractory Metal	49
D. Other Reactor Fuels and Materials Development	50
1. Nondestructive Testing	50
E. Engineering Development	54
1. Two-phase Flow	54
2. Boiling Liquid Metal Technology	54
3. General Heat Transfer	56
4. ANL-AMU Program	58
F. Chemical Separations	60
1. Fluidization and Volatility Processes	60
2. Chemical-Metallurgical Process Studies	65
G. Plutonium Recycle Reactors	66
1. EBWR Facility	66
2. Fuel Development and Fabrication	68

TABLE OF CONTENTS

	<u>Page</u>
III. Advanced Systems Research and Development	69
A. Argonne Advanced Research Reactor (AARR)	69
1. Core Physics	69
2. Fuel Material Development	71
3. Heat Transfer	71
4. Critical Experiment	73
B. Magnetohydrodynamics (MHD)	78
IV. Nuclear Safety	79
A. Reactor Kinetics	79
1. Fast Reactor Safety	79
B. TREAT	81
1. Operations	81
2. Large Sodium Loop	82
C. Chemical and Associated Energy-transfer Problems in Reactor Safety	82
1. Short-period Transient Irradiation	82
V. Publications	85

I. LIQUID-METAL-COOLED REACTORS

A. EBR-II

1. Operations

During the first half of the month, the reactor was operated at powers up to 100 kW for physics measurements and for a series of foil irradiations. Also, the control rods were calibrated by period measurements, and operators were requalified. Repair of the leaking evaporator was completed about March 15, and the secondary sodium system was filled, as described below. Permission to proceed to higher power was obtained, on March 26, and the reactor was brought to a power level of 10 MW. On March 27 a power level of 45 MW was attained and the reactor is operating steadily and without problems at this power level at the end of the month.

Prior to operation, ten materials surveillance subassemblies were loaded into the primary tank, eight into inner blanket positions, and two into the storage basket. Four core-type and two inner blanket-type flux-wire subassemblies also were loaded into the reactor grid and irradiated for 10 kWh to measure relative distributions of radial and axial fission rates, and plutonium production in the core and inner blanket. These subassemblies were then removed from the primary tank, cleaned, and the flux wires submitted for radiochemical analysis. One additional 6th row, core-type subassembly was loaded into the reactor to provide a total excess reactivity of 312 lh at 700°F and zero power.

Flux-wire irradiations were carried out at 650°F, after which the bulk sodium temperature was lowered to 365°F to allow filling the secondary sodium system. After filling, the primary system was heated to 700°F by a combination of electrical heating and reactor operation at a power level of 100 kW.

The composition of the blanket gas in the primary system remained relatively constant, showing about 2% nitrogen and 0.3% hydrogen. The composition of the blanket gas in the secondary system also remained relatively constant, at about 0.3% nitrogen and 10 ppm hydrogen.

After the secondary sodium system was filled, the plugging temperature slowly rose to 300°F. By operating the cold trap for two days, the plugging temperature was reduced to less than 250°F.

The plugging temperature of the primary system remained below 250°F, so its cold trap was not operated.

Power Plant operations were at first limited to those required to support low-power operation of the reactor. With the advent of higher power operation, it was operated in the normal manner. The bypass valves on the cooling tower were closed for the first time since October 1964, to allow full tower operation. This dislodged a considerable amount of dirt and debris which caused plugging of cooling-water strainers in various equipment. Raw water was supplied to the reactor auxiliaries for a period while the cooling-tower basins were cleaned up. Until the system has been completely cleaned, this situation is expected to reoccur.

Investigation of the failure of the 400-kW diesel-generator (see Progress Report for February 1965, ANL-7017, pp. 1-2) has indicated that this may not have been caused by loss of lube oil pressure, although this cannot be ruled out as a possibility. The control wiring and mechanical systems have been checked thoroughly without indication of the real cause of the failure. Several load tests have been performed since the incident, and the unit has performed perfectly each time. Investigation is continuing, and further loss-of-normal-power tests are contemplated.

2. Reactor Testing

a. Fission and Capture Rate Distribution Measurements. Measurements of the fission and capture rates were made at six radial positions in the core and inner blanket, by irradiating U^{235} and U^{238} wires in special subassemblies. The irradiated wires, which were as long as the length of core and blanket, were analyzed for relative fission and capture rate by means of a scintillation counter and pulse-height analyzer. A single portion

Table I. Worth of
Control Rods

Rod No.	Worth (Ih)
1	130
2	158
3	130
4	158
5	132
6	153
7	124
8	151
9	125
10	158
11	128
12	158
Total	1705

of each wire was analyzed radiochemically for fissions and captures on an absolute basis. This particular run included data from rows 1 through 6 only. The data are being processed for determination of total fission and total capture in core and inner blanket.

b. Control Rod Calibration. Control Rods No. 3 and No. 10 were calibrated by period measurements over their length of 14 in. The other ten rods were compared with these rods for overall worth. The worths of the control rods given in Table I are essentially the same as measured previously.

3. Maintenance and Modification

A redesigned control system for the secondary sodium pump was placed in operation to replace the amplidyne control. However, the operation of this motor-driven exciter control is not entirely

satisfactory at points near zero output. A solid-state, static type of control system has been designed and built, and will be installed and tested when plant conditions permit.

The inflatable seal for the inner door of the personnel air lock developed a small leak and was replaced. A leak-rate test performed on both air lock doors verified that the leak rate was within specifications. This will also satisfy the requirements of an annual leak-rate test for this air lock.

A defective bearing in the drive motor of the main-turbine turning-gear oil pump was replaced.

During plant standby, trouble was experienced with the startup feedwater pump. A solenoid on one of the unloading mechanisms burned out and was replaced. The main motor-driven feedwater pump was used while the startup pump was out of service.

The pressure-control valve associated with the motor-driven feedwater pump has not performed satisfactorily. It has been necessary to set the valve manually for a substantial pressure drop and to depend on the feedwater-regulating valve to control with a boiler water pressure differential higher than that for which it was specified. Oscillations due to the malfunctioning valve reflect into the steam system and affect the steam-generation rate. Steam pulses, in turn, affect the large back-pressure-regulator valve, which is also unstable and tends to oscillate before it finds a stable regulating point. Analysis to date indicates a new feedwater-pressure coated valve for low flow rates will be required.

4. Fuel Cycle Facility

a. Argon and Air Cell Systems and Auxiliary Equipment.

(i) Manipulators and Transfer Locks. One of the small transfer locks between the Air and Argon Cells failed to close properly on the Argon Cell side, apparently because the lifting bail caught on the lid gasket, which was slightly displaced. The drive-chain counterweight dropped and was caught behind the lid, causing the axle to come out of one of its bearings when the lid was raised. The axle was replaced remotely, using the wrist and arm manipulator attachment, and the lock was restored to operation. A storage rack was removed from between the locks to minimize the likelihood of a re-occurrence of this accident. In addition, a remote pushbutton station for lock operation has been provided in the central control room to improve ability to observe operation of the locks.

A manipulator carriage from the Argon Cell was removed to the Air Cell roof to replace down-motion limit switches which had failed because of grit in the plunger barrel. The work was done successfully with minimal contamination by three men in about 3 hr, with exposures not exceeding about 20 mR.

A bridge drive motor from an EBR-II Argon Cell crane was previously removed for maintenance purposes by means of a remote-handling bridge-drive lifting tool (see Progress Report for January 1965, ANL-7003, p. 28). The same lifting tool was successfully used to reinstall the drive motor. This was the first time that a bridge drive motor has been remotely installed.

(ii) Radioactive Waste Burial. Radiation levels expected during pit burial of 6-ft-tall cans of radioactive waste were checked by a simulating burial operation with an 80-R/hr source in a 5-gal can suspended on a rope at various levels in the cask and pit. The maximum level observed was 90 mR/hr when the source passed the open lower door of the cask. Normally the transit at this point will be very rapid, and personnel will be at some distance. Other levels were below this value by an order of magnitude or more.

b. Irradiated Fuel Processing

(i) Sodium Removal, Examination, and Dismantling. Four lightly irradiated core subassemblies containing flux wires and foils were processed to remove sodium; the wires and foils were removed for counting and analysis. An inner blanket assembly was dismantled, and a group of blanket rods was checked with "go-no go" gauges in an attempt to detect swelling; no evidence of swelling was found.

A group of fuel rods from each of three assemblies dismantled previously were gamma-scanned at 1.5-in. intervals along the length of the rods, using a small thallium-activated NaI crystal and a 256-channel analyzer. Because of the 4-mo cooling time, the $\text{Zr}^{95}\text{-Nb}^{95}$ peak was used. Typical data are shown in Table II.

Table II. Gamma Scans of Irradiated Fuel Rods

Assembly Type	Assembly Removed from Row No.	Position of Max Gamma Intensity, in. above Bottom Tip	Relative Intensity at Peak, Max/Min* Gamma Intensity			
			For Rod Nearest Reactor Center	For Rod Farthest from Reactor Center	For Rod Nearest Reactor Center	For Rod Farthest from Reactor Center
Core	2	7.5	2.81	2.61	1.53	1.59
Control	5	10.0	1.94	1.57	1.67	1.64
1B Core	6	7.5	1.80	1.35	1.49	1.41

*Extrapolated.

An attempt will be made to correlate the results of gamma-scanning with chemical analyses to provide a simple method for burnup estimation.

(ii) Decanning, Melt Refining, and Oxidation. A group of 135 irradiated fuel pins, principally from a Row 6 inner blanket core assembly, was decanned successfully without jams, using a heated scrap separator. The decanned rod, with recycled irradiated fuel to make a total charge of 11.6 kg, was melt refined to yield a 10.9-kg ingot (94.5% pouring yield). The skull from this run and that from the preceding melt-refining run with irradiated fuel were oxidized, and the oxides were placed in zinc cans for storage.

An increasing tendency for the drive chain of the decanner unit to release from its sprockets has been observed, presumably because of an increasing need for decanning power. The unit was removed from the Argon Cell and partially decontaminated to permit examination of bearings and replacement of the single drive chain with a double chain.

c. Fuel Fabrication and Surveillance

(i) Injection Casting and Pin Processing. Two injection-casting runs were carried out with 12-kg charges of irradiated fuel ingots and heels, and a third run (11-kg charge) was made with unirradiated fuel alloy. The average casting weight per mold ranged from 74 to 85 g (a 14.22-in. pin weighs 68 g). A total of 560 castings was demolded and inspected in the pin processor. The yield of acceptable castings was 263, or 47%. Principal causes for rejection were shortness or warp, areas of substandard diameter, and evidence of porosity by eddy current test. It is suspected that improper mold coating or rate-of-quench gas flow may be significant in producing these defects, and these factors are being evaluated.

A significant number of castings (12%) was also sheared too short; the shear blades were found to be chipped. Replacement with set-screw-retained inserts was not successful, and the poor shearing recurred after 6-10 operations. Successful operation was attained by replacement with welded-in-place shear inserts.

(ii) Rod Fabrication and Testing. A single-rod prototype welder, loaded and operated by master-slave manipulator, was used to weld 187 assembled unirradiated fuel rods. This group and 15 other rods were leak tested (32 rods were rejected). A total of 124 rods were bonded and bond tested to yield 81 ready for final assembly.

(iii) Fuel Surveillance. Six fuel elements from the Row 2 sub-assembly with 0.26% maximum burnup were decanned, washed to remove sodium, and passed through the pin-processing machine for measurement.

The lengths, diameters, and weights corresponded closely with measurements before irradiation, indicating the absence of significant fuel swelling.

d. Skull Reclamation Process. A skull reclamation process is being developed for the recovery and purification of the fissionable material that remains in the melt-refining crucible after a melt-refining operation. Work is continuing on the engineering development of plant-scale equipment¹ and process procedures for the retorting step of this process.

Preliminary retorting tests of the plant-scale retorting apparatus have been carried out (see Progress Report for January 1965, ANL-7003, p. 30). In these tests, charges of Zn-Mg (no uranium) were distilled from a graphite crucible at reduced pressures and at a temperature of about 750°C. The retorting apparatus was operated in air. The atmosphere within the apparatus was argon. Distillation rates as high as 97 g/min have been achieved in a run which was carried out with a 30-kg charge at a reduced pressure of 10 Torr. (A 100-g/min distillation rate has been tentatively selected for plant operation in the EBR-II Fuel Cycle Facility.) Following the completion of the preliminary tests, installation of the retorting apparatus in the Chemical Engineering Division large inert atmosphere enclosure (see Progress Report for November 1964, ANL-6977, p. 31) will be undertaken, after which plant-scale demonstrations of the skull reclamation process will be carried out.

B. FARET

1. General

Progress on the various design packages of Title II beyond that reported previously (see Progress Report for February, 1965, ANL-7017, pp. 10-12) is as follows:

Package III - Liquid Metal Heat Exchangers - Complete reproducible drawings and specifications have been received from the Architect-Engineer, and are ready for distribution to the AEC and United Engineers and Constructors (UE&C). UE&C is now able to use this material for initiation of procurement of liquid metal heat exchangers.

Package IV - Liquid Metal Pumps - The drawings and specifications have been reviewed, and the Laboratory will sign the tracings at the Architect-Engineer offices.

Package V - Control and Instrumentation - This package is being reviewed by the Laboratory. Comments have been returned to the Architect-Engineer. Review on a high-priority basis continues.

¹Apparatus sized for full-scale (~5 kg uranium oxide) operation in the EBR-II Fuel Cycle Facility.

Package VI - Special Piping Materials and Valves - Comments on this package have been returned to Bechtel. It is planned to sign the specifications at the Bechtel offices during the first week of April.

Package VII - Special Early Procurement Items - All comments have been returned to Bechtel. Signing of drawings and specifications will take place at the Bechtel offices in early April.

Package IX - General Design - This package contains the bulk of the Architect-Engineer Title II design work. Review is continuing on material which has been submitted recently. The late items of this package are scheduled for final issue by the middle of April. These include the liquid metal systems, the cell, and the argon-cooling system. This package is being reviewed on a high-priority basis.

The Architect-Engineer has reported Title II design as approximately 90% completed at the end of February. The remaining work is generally classified as cleanup. The major outstanding items are incorporation of ANL comments in Packages V and IX. This material is expected to be in Bechtel's hands by the first week of April so that they can proceed with completion of the Title II design.

2. System for Removal of Reactor Vessel Cover

a. Large Bellows. It is planned to employ a large, accordion-type, flexible bellows in the system to remove the FARET reactor vessel cover (see Progress Report for February 1956, ANL 7017, p. 13).

Bellows manufacturers have recommended an elastomer-coated fabric as the bellows material, preferably a hypolon coating calendered on one side and a neoprene coating calendered on the other side of a nylon fabric. As shown in Figure 1, the bellows will be made up of a double layer of the above-mentioned material with aluminum slats inserted and bonded between the two layers of hypolon-nylon-neoprene material. The aluminum slats provide rigidity to the bellows convolutions, yet permit the fabric to flex during the bellows movement. The slats will also reduce the effective leakage area and thus reduce the overall diffusion through the bellows. Nylon tapes will be fastened to the convolutions to support the weight of the extended convolutions and to limit travel.

The bellows is a large hollow octagon, 11 ft across the flats on the outside and 9 ft across the flats on the inside. The nylon tapes limit the travel of each convolution to 16 in. The maximum extended length of the bellows is 45 ft. The minimum retracted length of the bellows is approximately 4 ft. Both ends of the bellows are provided with 4-in. high collars for the attachment of large metal flanges.

Figure 1. Bellows for Removal of Reactor Vessel Cover

b. Bellows Test Program. Tests will be conducted with samples of material and with a complete subsection of the bellows to guide the design, to arrive at the selection of the materials, and to determine the integrity of the bellows. The samples and sections to be fabricated or furnished by the manufacturer for tests are as follows:

- a complete scaled subsection of the bellows;
- test sample of the vertical bonded lap seam;
- a test section duplicating a cross section through the bellows convolution, including the bonded aluminum slat;
- a test sample of the nylon support tape;
- a test section of the nylon support tape attached to the bellows convolution;
- a test sample of the bellows elastomer-calendered fabric;
- a test sample of the closed-cell sponge-rubber gasket material;
- a test section of the closed-cell sponge-rubber gasket bonded to the bellows material;
- test samples of the bonding and sealing materials used in the fabrication of the bellows.

Test equipment has been set up for conducting flexibility, water vapor permeability, and air permeability tests with materials being considered for the large bellows. The test conditions, which are based on the FARET cell operating conditions, are as follows: normal pressure differential across the bellows of 2 in. W.G., a normal operating temperature of 100°F, short-term exposure to 160°F, and a water vapor pressure differential across the bellows of 13-15 mm Hg. (This is equivalent to air at 100°F and 30% RH on one side of the bellows and "dry" argon at 100°F on the other.)

The test procedures have been chosen to conform to ASTM specifications wherever possible. ASTM designation E96-63T is being used for the water-vapor-transmission tests. The flex test, however, is designed to duplicate the flexing that each convolution of the bellows will experience when it is retracted or extended during vessel-cover removal and replacement.

Permeability rates are to be determined on the materials "as received" and after subjecting them to various periods of flexing. The materials which are found to have the necessary low water vapor and air permeability rates and good flex strength will be tested further for bond strength and capability of repair in the event of an accidental puncture.

3. Static Vessel Tests

Since the arrangement of the FARET subassemblies within the reactor vessel requires a knowledge of placement, handling, and instrumentation in the presence of sodium or a sodium atmosphere with an argon gas blanket, it has been considered essential that the fuel-assembly

Figure 2. FARET Static Test Vessel

arrangement be mocked up on a full scale. The test will utilize shortened subassemblies representing the upper portions of fuel-, reflector-, control-, source-, and instrumented subassemblies. The vessel will be filled with sodium, whose level may be changed in order to observe the effect of variation of the sodium level in the FARET vessel on the placement and handling of the subassemblies.

Figure 2 shows the test vessel. Four nozzles will be a part of the vessel representing the configuration of the upper spool section of the FARET vessel. Through these nozzles various experiments will be conducted for the installation of the in-core instrumentation. Four smaller nozzles will be used for test vessel instruments, such as thermocouples, heaters, liquid-level instrumentation, and sodium sampling. The physical arrangement of the core subassemblies at the upper region will be effective in establishing the principal dimensions of the actual components to be installed in FARET.

In the case of in-core loops the arrangement of the loops will also be tested by this actual mockup. The effect of temperature on the structural arrangement, the upper parts of the core subassemblies and the test loops will be studied, since it is planned to heat the test set-up by means of electrical heaters in the sodium. The cover of the test vessel will be as large as that of the FARET reactor vessel. Thus experiments involving the gasketed closure of the vessel may also be conducted.

4. Core Instrumentation

a. High-temperature Furnace Facility. The new high-temperature furnace (see Progress Report for April 1964, ANL-6885, p. 34) which is used to develop temperature sensors for fuel pins has been put into operation and is capable of producing temperatures between 800°C and 2800°C plus, with vacuum or with one atmosphere of helium or argon-10% helium. The tungsten-mesh heating element is 2 in. in diameter and 12 in. long. The operating temperature can be controlled automatically from either the power or temperature signal. The power to the heating element is measured by means of a thermal converter and the temperature of the hot zone is measured with an optical pyrometer permanently mounted on the furnace facility. Both variables are continuously recorded by a two-pen strip-chart instrument. A portable optical pyrometer is used as a standard for determining the actual hot zone temperature. The furnace facility includes a vacuum system capable of producing a vacuum better than 2×10^{-5} Torr in the furnace chamber at heat and a gas system providing inert atmospheres at a pressure of 1 psig. The pressure instrumentation of the facility can measure values over the range from 15 psig to 1×10^{-9} Torr.

Some of the first tests scheduled to be performed in the furnace include the determination of the resistivity of refractor oxide electrical insulators, especially thoria, and the proof testing and calibration of prototype fuel-pin thermocouple assemblies.

b. Thermocouple Analysis. Prototype fuel-pin thermocouples have been successfully used to measure the centerline temperature of the fuel pellets in the "Fuel Slip-fit Experiment" (see Progress Report for January 1965, ANL-7003, p. 37). The capsule fuel centerline thermocouples consisted of a tungsten-5% rhenium/tungsten-26% rhenium wire combination insulated by thoria inside the fuel region and alumina outside. The sheath was 0.062-in.-OD tantalum.

The first capsule was backfilled with argon. The fuel attained an average centerline temperature of 1050°C throughout the 810-operating-hour test. The thermocouple was exposed to a calculated fast integrated neutron flux of $\sim 2.9 \times 10^{19}$ nvt. Approximately 30 thermal cycles occurred during the test. Only a slight change in emf output ($\pm 20^\circ\text{C}$ equivalent) was observed. Some of this was due to a power increase in the capsule. The thermocouple performance was completely satisfactory.

The second capsule was backfilled with helium. An average fuel centerline temperature of only 750°C was achieved throughout the 940-operating-hour test. The thermocouple was exposed to a calculated fast integrated neutron flux of $\sim 3.4 \times 10^{19}$ nvt. Approximately 35 thermal cycles occurred during this test, and again only a slight change in emf output ($\pm 30^\circ\text{C}$ equivalent) was observed. Again an apparent increase of power to the capsule accounted for some of these variations. This thermocouple also performed satisfactorily throughout the life of the test.

c. Electrical Connectors. A second series of tests in the seal-evaluation program has been completed. As in the test at room temperature (see Progress Report for December 1964, ANL-6997, pp. 24-5), seals whose mating surfaces were plated with silver and gold were clamped into fixtures and the fixture cavity was evacuated. The test fixtures with the seals in place were placed in a furnace with an argon atmosphere on one side of the seal. While the clamping pressure was held constant, the furnace temperature was varied. Seal-tightness decreased upon heating, but improved as the sample was heated further. This applied particularly to the plated seals and, at the end of the experiment, examination of the mating surfaces revealed gold and silver on both the seal surface and the fixture surface. The transfer of silver was greater than for gold. This observation indicates good sealing qualities. The overall seal performance appears to be satisfactory in an argon atmosphere at 650°C and also in air at room temperature.

5. Design of Core Support

A centrally reinforced two-plate structure for core support is being structurally analyzed. The reinforcement consists of a central rod and a concentric row of tubes connecting the two plates.

Analysis conducted thus far consists of a plate acted upon by a uniformly distributed load where the reaction of the reinforcement has been represented by appropriate forces and moments. Provisions have also been made to treat the plates with variable edge restraints. Thus, the deformation and strength of the plate is now a function of the uniform load, edge rigidity, and the forces-moments of the reinforcing members. At this point the reactions of the reinforcing members are unknown. These will be determined, however, when the solutions of the upper and the lower plates are superimposed and their deformations made compatible.

6. Fuel Assembly Sodium Flow Test Loop

a. Construction. The system piping is being welded and radiographed. The 3-in. and 4-in. lines have passed radiographic inspection. The 5-in. pump suction line is now being welded.

The pressure vessel heaters are in place and the lagging is about 75% completed. The heaters on the expansion tank and interim pump have been installed.

The manufacturer has reported that the pump volute and impeller of the 800-gpm circulating sodium pump have been cast and passed radiographic inspection. The castings are enroute from the foundry to the manufacturing company.

b. Experimental. The preliminary test of the Baldwin-Lima-Hamilton high-temperature full-bridge gages is almost complete (see Progress Report for February 1965, ANL-7017, p. 17). The endurance test of the operating gages at 900°F is incomplete. All results, however, are based on the information supplied by only two strain gages exposed to temperatures not exceeding 900°F. No general conclusions can yet be drawn on the performance, but qualitative know-how for the installation and operation of this type of gage has been obtained.

The effect of mechanical load was tested at constant temperature and for a short duration of time. It was found that the repeatability of these gages for mechanical loads was very good as compared with that of the ordinary, room-temperature strain gages.

The effect of material expansion with temperature was also investigated. The test specimen was brought up to temperature under no mechanical load and the strain indication was recorded. The result of many runs was an average of 0.323×10^{-6} in./in./°F for one gage, and a very constant rate of 2.2×10^{-6} in./in./°F for the other. The first value is an expected average variation. The second variation, however, would be intolerable in strain measurements at variable temperature. There is no explanation for this at this time.

The drift of instrumentation has also been observed at various temperature levels. After 2 hr, the time it takes to reach a best equilibrium of the system, no appreciable drift could be recorded up to a temperature of 900°F.

The strain indication was observed at constant temperature by varying the gage factor setting on the instrument. An average reading of about 450 in./in. gage factor setting was shown by one gage and of 350 in./in. gage factor setting for the other. There is a slight indication that somewhat greater variation takes place at higher temperatures.

C. General Fast Reactor Physics

1. ZPR-3 (FARET Criticals)

Experiments continued on ZPR-3 with Core 46B (see Progress Report for February 1965, ANL-7017, p. 20) the simulation of a 68-liter, carbide-fueled FARET core. Measurements of fuel worth at the radial edge of the core indicated a value of about 0.9% $\Delta k/k$ (550 lh = 1% $\Delta k/k$) for a carbide-fuel subassembly replacing the radial reflector at the edge of the core in FARET.

Experiments with mockups of possible FARET control/safety rods evaluated the reactivity effects that could be expected by the various designs proposed. For these measurements, drawers loaded with the mock-up B_4C rods were substituted for a radial reflector drawer in one half of the reactor. Figure 3 shows the reactor configuration of Half No. 1 with the substitution drawer located in 1-P-12 to obtain the "rod channel" axis-to-reactor axis distance of 10.9 in., compared with the average radius of 11.2 in. for the eight rods in FARET. First, the normal composition in P-12 (fine radial reflector, as given in Table III of Progress Report for February 1965, ANL-7017, p. 19) was replaced with cans of sodium, giving the effect of "voiding" a reflector subassembly channel. Next, the sodium cans were replaced with a mockup rod containing about 31% natural B_4C , 39% sodium, and 26% steel by volume. This was then replaced with a rod mockup containing 16 v/o natural B_4C , 15 v/o enriched B_4C ($B = 90\% B^{10}$),

Figure 3. Configuration of ZPR-3 Assembly-46B Core for FARET Safety Rod Experiments

39 v/o sodium, and 26 v/o steel. Results are listed in Table III. For eight rods of similar composition in a 68-liter-core FARET, the data indicate available reactivity controls of approximately 2.7% $\Delta k/k$ for the natural B_4C type (19% B^{10} in B) and 4.7% $\Delta k/k$ for the 1/2-enriched B_4C type (about 53% B^{10} in B).

Table III. FARET Control/Safety Rod Mockup
Experiments in ZPR-3 Assembly 46B

Loading of Mockup Channel in 1-P-12;
Cross-section Area = 4.75 in.²

Case	Axial Extensions (in. from Midplane)	Composition, 10 ²² atoms/cc						Reactivity Worth Relative to Sodium-filled Channel (Th)*
		Steel	Na	Al	B ¹⁰	B ¹¹	C	
I Radial Reflector	0 to 21	6.638	0.212	0.306	-	-	-	+18
	21 to 31	7.722	-	-	-	-	-	
II "Voided" (sodium-filled)	0 to 32	1.835	1.692	-	-	-	-	0
III Natural B ₄ C Rod	0 to 18	2.163	0.846	-	0.562	2.366	0.790	-83
	18 to 32	4.955	0.846	-	-	-	-	
IV 1/2 Enriched 1/2 Natural B ₄ C Rod	0 to 18	2.163	0.846	-	1.439	1.303	0.869	-153
	18 to 32	4.955	0.846	-	-	-	-	

*Reactivity calibration not yet final; estimated uncertainty is $\pm 10\%$.

The distributed worths of materials throughout the 46B core were obtained from substitution experiments in a distribution of nine core drawers of Half No. 1, representing a core quadrant, and in the central drawers 1 and 2-P-17. Materials involved were sodium, steel, graphite, depleted uranium, and U₃O₈. The results of this work have not yet been fully analyzed.

Some core loadings of FARET might be composed of mixtures of carbide-fueled and oxide-fueled subassemblies. Consequently, substitutions of a simulated oxide fuel were made for the carbide type at a few locations in the carbide core to assess the reactivity difference. The composition of the oxide fuel drawers used was the same as that intended for the next core in the assembly, Core 46C, representing about 36 v/o PuO₂-UO₂, 38 v/o sodium, and 18 v/o steel, with a U:Pu ratio of 6 and the uranium enriched to 48%. An oxide-loaded core drawer was substituted in turn for the regular carbide drawer in each of S-17, R-17, Q-17, and P-17 in the core in Half No. 1 (see Figure 3). Next, the oxide-for-carbide fuel substitution was carried out in an annular sector composed of drawers R-18, R-17, R-16, one-half each in drawers Q-15 and Q-16, and P-15 of both reactor halves. This sector represents in geometry about five of the twelve subassemblies in the third ring of hexagonal elements in the FARET reactor. Results are given in Table IV. It was found that in the annular

sector experiment the worth per drawer exchanged was essentially the same as for the single drawer replacement in 1-R-17.

Table IV. Worths of Simulated FARET Oxide Fuel
in ZPR-3 Assembly 46 Carbide Core

A. <u>Compositions Involved:</u>							
Fuel Type	Composition, 10^{22} atoms/cc						
	Pu	U ²³⁵	U ²³⁸	C	O	Na	Steel
Carbide (46B)	0.170	0.338	0.568	1.114	-	0.846	1.481
Oxide (46C)	0.112	0.333	0.347	0.514	0.865	0.846	1.518

B. Worths of Oxide-simulation Core Drawers
Replacing Carbide-core Drawers
in Carbide Core of Assembly 46B:

Number of Drawers*	Location of Drawers	Substitution Worth, lh**
1	1-S-17	-43
1	1-R-17	-65
1	1-Q-17	-82
1	1-P-17	-88
10	Annulus:	-625
	1-R-16 2-R-16	
	1-R-17 2-R-17	
	1-R-18 2-R-18	
	1/2 of 1-Q-15	
	1/2 of 1-Q-16	
	1/2 of 2-Q-15	
	1/2 of 2-Q-16	
	1-P-15 2-P-15	

*Core section dimensions: 2.18 x 2.18 x 12.03 in.

**Uncertainty of calibration is $\pm 10\%$.

Axial traverse experiments through Core 46B were completed. A 1/2-in.-dia channel was constructed through drawers 1- and 2-P-17 by rearranging the fuel and excluding some graphite. Traverses of both reaction-rate counters and reactivity samples were made along the reactor axis, extending from outside the axial reflector in Half No. 2, through the core, and into the axial reflector in Half No. 1. The material worths measured were for plutonium, enriched uranium, and natural uranium.

Materials used in the counters to determine fission rates were Pu, U^{235} , U^{238} , U^{234} , and B^{10} (n, α). Results are being analyzed. Figure 4 shows a plot of the results of the B^{10} , Pu, and U^{234} measurements normalized to unity at the core center.

Figure 4. Axial Counter Transverses through ZPR-3 Assembly 46B

Traverse measurements of the reactivity samples and counters in the radial direction are under way.

2. ZPR-6

Work with ZPR-6 Assembly No. 3 was completed. The blanket was removed, and equipment modifications and routine maintenance were performed in preparation for Assembly No. 4, which will be used to study the properties of zoned cores, especially with regard to the Doppler effect and the sodium void coefficient.

The hardware associated with the Doppler measurements has been installed. The stationary half of the matrix was preloaded with the blanket and core materials (U^{238} was substituted for U^{235}) for Assembly No. 4,

and the resulting deflection of the matrix measured. About 53 metric tons of U^{238} were loaded into the movable and stationary matrix tubes, as well as preloading 350 core drawers and loading them into the stationary half of the matrix. Subsequently, the stationary half of the matrix was partially unloaded to permit alignment of the two halves.

A number of the instruments in the console were relocated to group the nuclear instrumentation together. The semi-annual checkout, including a complete interlock checkout, was made. Additional wiring and cables for the Doppler equipment were installed, as were control wires for the associated air compressors, cooling equipment, air valves, etc.

3. ZPR-9

The effect on reactivity of loading B^{10} into the aluminum reflector of the ZPR-9 Assembly No. 6 was studied. The enriched boron powders were loaded into aluminum cans, $2 \times 2 \times 1/8$ in. The amount of B^{10} in each can is taken to be 4.06 ± 0.11 g. There are also uncertainties of several percent with respect to chemical purity and isotopic composition of boron.

The boron was loaded into rows, in the reflector, 10 cans long with an effective radius ranging from 41.7 to 43.4 cm, the variation being due to the rectilinear matrix structure. Forty-four circumferential positions are the best approximation to complete encirclement of the core that can be attained, and this covers nearly 74.5% of the circumference. For each position, the angle subtended by the boron can at the centerline was calculated. Figure 5 shows the variation in reactivity caused by the boron at each stage of the loading when plotted against the total subtended angle. A differential plot is shown in Figure 6. For a complete loading (440 cans), the reactivity was reduced 289 lh, at a total subtended angle of 268° .

When an extra can was added to one-fourth of the positions on each assembly half, 8.8 lh of reactivity were removed. Extrapolation to a complete loading of twelve cans for every position (24 in. long, the same as the core length) indicates that the boron loading in the reflector would hold 324 lh of reactivity. Extrapolation of this result to a full 360° gives a total reactivity of 435 lh, and a total B^{10} weight of 2878 g. Extrapolation was necessary because there were insufficient cans to permit actual loadings.

The irregularities in the plot of Figure 6 go far beyond the expected errors in the reactivity measurements. It is suspected that they might be caused by the uncertainties in purity, weight, and boron enrichment in the cans. Four random samples of eight cans each were loaded into the sample changer and their central worths determined. The following values were obtained: 75.41, 76.44, 73.33, and 72.91 lh.

Figure 5. Variation in Reactivity as Size of Angle Subtended by Section of Boron Annulus in ZPR-9 Assembly No. 6 Reflector is Changed. Boron-10 is installed in the assembly in aluminum cans, $2 \times 2 \times 1/8$ in., filled with boron powder.

Figure 6. Differential Variation in Reactivity with Size of Boron-10 Loaded in Annular Section in Reflector of ZPR-9 Assembly No. 6

With use of the B^{10} weight given per can, the reactivity should be 67.2 Δk on the basis of the previous B^{10} measurements. Since the relative errors in the reactivity measurement are expected to be less than 0.1 Δk , these figures suggest the source of error.

In another measurement, 30 boron carbide blocks, in which B^{10} was enriched to 92%, having dimensions of $1/4 \times 2 \times 2$ in., were loaded into a section of the reflector and subtended a 20° angle. The section was 3 cans wide and 10 cans long (20 in.). This loading removed 79.2 Δk of reactivity. Then one block was added to each end of each row, making the rows twelve blocks (24 in.) long. This loading removed an additional 8.0 Δk .

Assembly No. 6 was unloaded to permit the performance of the routine annual maintenance and fuel inventory. In addition, a number of modifications were made to the system. Upon completion of the work, re-loading of Assembly No. 6 was started.

4. ZPPR

The architect-engineer firm for ZPPR, Mason-Hanger, Silas Mason Co., Inc., is continuing Title II work which was begun last month.

a. Reactor Bed and Tables. A two-week extension on the bid date for the bed and tables was granted, moving it to March 31.

b. Matrix Assembly. The technical specifications for the matrix tubes have been sent to prospective bidders. These bids are due back on April 16.

Technical specifications for the matrix drawers are complete, and a bid package is being prepared.

A prototype of the fuel-rod drives was received and is being checked. Preliminary tests indicate the new gear arrangement to improve readout is satisfactory. Operation of the rod has shown that revisions in the drive springs and motors will be necessary before the remainder of the rod drives are ordered.

Specifications for the nuclear instruments were completed and are now being reviewed.

The area gamma-monitoring instrument specifications were also completed.

D. General Fast Reactor Fuel Development

1. Metallic Fuels

a. Improved Uranium-Plutonium-based Fuels. Compressive tests of U_2Ti , U-15 w/o Pu-10 w/o Ti, and U-22.1 w/o Pu-11.8 w/o Ti were made in the as-cast and homogenized conditions, as shown in Table V. The strength decreased and the ductility increased with temperature.

Table V. Ultimate Compressive Strength of U-Ti-based Alloys

Alloy (w/o)	Heat Treatment	Temp (°C)	Ultimate Compressive Strength (kg/mm ²)	Mode of Failure
U_2Ti	As cast	615	66	Ductile
U_2Ti	As cast	709	41	Ductile
U_2Ti	1050°C, 1 wk	554	103	Ductile-Brittle
U_2Ti	1050°C, 1 wk	710	50	Ductile
U_2Ti	1050°C, 1 wk	758	36	Ductile
U-15 Pu-10 Ti	As cast	20	120	Brittle
U-15 Pu-10 Ti	As cast	409	44	Brittle
U-15 Pu-10 Ti	As cast	560	39	Ductile-Brittle
U-15 Pu-10 Ti	1050°C, 1 wk	560	35	Ductile-Brittle
U-15 Pu-10 Ti	1050°C, 1 wk	643	15	Ductile
U-15 Pu-10 Ti	1050°C, 1 wk	766	6.7	Ductile
U-22.1 Pu-11.8 Ti	As cast	25	141	Brittle
U-22.1 Pu-11.8 Ti	As cast	405	71	Brittle
U-22.1 Pu-11.8 Ti	As cast	516	48	Ductile-Brittle
U-22.1 Pu-11.8 Ti	As cast	618	34	Ductile
U-22.1 Pu-11.8 Ti	As cast	717	11	Ductile

Homogenization strengthened the U_2Ti alloy and did not significantly affect the U-15 w/o Pu-10 w/o Ti alloy at a given test temperature. The binary alloy is stronger than the ternary alloys.

b. Uranium-Plutonium-based Fuel Rods for Irradiation Testing.

Uranium-plutonium alloy fuel rods for irradiation testing in EBR-II are being fabricated. Some 400 alloy fuel pins have been previously cast under this program. The work presently under way includes the preparation of 80 metal-fueled, sodium-bonded rods. The fuel pins are of four compositions: U-10 w/o Pu-10 w/o Fz; U-15 w/o Pu-10 w/o Fz; U-15 w/o Pu-10 w/o Zr; and U-15 w/o Pu-10 w/o Ti, made with 90 to 93.5 w/o enriched uranium to compensate for an anticipated low power level in the outer rows of the EBR-II core. The effects of void and sodium volume are being studied by varying jacket volume, sodium volume, and fuel-pin and restrainer length.

The fission alloys were premelted in yttria-coated graphite molds by well established practices. Preliminary tests showed very poor dissolution of titanium and zirconium in uranium and plutonium at temperatures less than 1500°C. The alloy for the titanium-containing fuel rods was single-melted at 1700°C and furnace-cooled. The ingot was sampled top and bottom, and showed less than 0.6 w/o Ti variation. Single melting of the zirconium alloy at 1740°C resulted in a 5.9 w/o Zr variation between top and bottom of the casting. Multiple melting of this alloy was required to produce a homogeneous ingot. Because of the high temperature required, yttria-stabilized zirconia crucibles were used for alloy preparation. The titanium and zirconium alloys were remelted in the yttria-stabilized zirconia crucibles and injection cast at 1525°C. This high temperature was required to injection-cast the metal in the 3.7-mm-dia Vycor molds. The yttria-stabilized zirconia crucibles were cracked by the thermal shock during the pressurizing cycle. A total of twenty-nine titanium-alloy castings and twenty-eight zirconium-alloy castings were produced with lengths greater than 43 cm. The titanium alloy is slightly more brittle at room temperature than the zirconium alloy. Diametral shrinkage was 3.5% for the titanium alloy and 2.0% for the zirconium alloy.

The fuel pins are made by machining the injection castings to length. The diameter and length are measured, and an immersion technique is used to determine pin volume.

The following procedure has been established for jacketing and bonding these specimens. The V-20 w/o Ti fuel tubes are degreased, inspected, and every volume is determined by calculation from the weight of CCl_4 required to fill the tube. A V-20 w/o Ti bottom plug is made for each tube and is welded in place after the tubes are thoroughly cleaned and degassed. The wide variation in tube diameter requires that the bottom plug be match fit to the particular tube with which it is used. After leak detection, a calculated weight of sodium is added in the form of an extruded wire. The sodium is received in a 400-g-capacity tank from which the extrusion cannisters are filled. The sodium is extruded, cut to length, weighed, and placed in the appropriate jacket subassemblies. Small brass funnels are used to prevent contamination of the jacket top. Each sodium-containing jacket receives a fuel pin. The assembly is heated to 150°C to allow the sodium to melt, and is vibrated for about 10 sec to settle the fuel pins below the surface of the sodium. The restrainers are then added while the sodium is still hot.

Because of the shortage of V-20 w/o Ti rod stock, the restrainers are made from three separate pieces that have been drawn or swaged to the rough diameter. The pieces are joined by TIG welding. The assembly is then machined to the final length and to fit the particular jacket tube in which it will be used. The fuel rods are closed by welding the restrainers into the top of the jacket tube. The completed rod is surveyed,

decontaminated if necessary, and removed from the glovebox system. Each rod is leak tested; the sodium level is checked by X radiography; the rods are bonded in a helium atmosphere at 500°C by 2000 impacts. The bonded rods are tested by standard eddy-current techniques. The sodium level is measured by X radiography, and the finished rod is inspected. Of the eighty fuel pins made, seventy-two have been machined and inspected. Forty have been welded into the jackets with the sodium and are being bonded. The remaining pins await the fabrication of additional restrainers, which are scheduled for delivery before April 1.

2. Carbide Fuel Elements

a. Compatibility of (U,Pu)C with Potential Jacketing Materials.

For fast breeder reactors solid-solution uranium-plutonium monocarbide fuels have the advantage over solid metallic fuels of being usable at higher temperatures and over oxide fuels of having superior thermal conductivity.

Interest in (U,Pu)C as a fast reactor fuel in the temperature range from 650 to 1100°C has occasioned the initiation of a systematic study to determine the extent and mode of its interaction with potential jacketing materials. This study is necessary to ensure that extensive interaction will not rupture the jacket of the fuel element nor affect adversely such pertinent properties as mechanical strength and thermal conductivity.

The following qualitative results have been obtained with stoichiometric $(U_{0.8}Pu_{0.2})C$:

(1) At 1100°C

- (a) Cr for 7 days showed no reaction.
- (b) Mo, Nb, and Ta for seven days showed slight reaction.
- (c) V for 7, 17, and 42 days showed appreciable reaction.
- (d) V-20 w/o Ti for 42 days showed extensive reaction.
- (e) Hastelloy-X and 304 stainless steel at 42 days showed catastrophic melting.

(2) At 950°C

- (a) Nb for 7 days showed very slight reaction.
- (b) V for 42 days showed slight reaction.
- (c) 304 stainless steel for 7 days showed slight reaction.
- (d) Hastelloy-X for 42 days showed appreciable reaction.
- (e) V-20 w/o Ti for 42 days showed extensive reaction.

The specimens of the test assembly consist of a fuel pellet sandwiched between two plates of jacketing material. This "diffusion couple" is stacked in a rectangular holder, a "picture-frame" clamp with a compression screw at one end to force the members of the couple into tight contact.

If the diffusion couple does not fit snugly into the frame, the waste space is taken up by a so-called "bucking pellet" inserted between the diffusion couple and the end of the frame opposite the screw.

Experimental difficulties have been encountered with the original diffusion couples due to the differences in thermal expansion of the specimens and holder. Since the specimen must expand more than the holder to exert pressure on the interface at the annealing temperature, there is a tendency for the fuel-jacket interface to pull apart on subsequent cooling. We are, therefore, trying a minor modification of the present technique in order to lower the differential thermal expansion between the fuel-jacket composite and the surrounding picture frame. The pressure will be adjusted by the proper selection of materials for the picture frame and bucking pellet.

In an attempt to assure more intimate contact between the fuels and jacketing materials, a second type of compatibility sample is also being tried. This sample consists of a number of pieces of arc-melted carbides dispersed in and compacted with a powder of the jacketing material. A number of pellets are being made to investigate the feasibility of this method along with effects of pressure, carbide particle size, and carbide volume fraction.

b. Fabrication of PuC and (U,Pu)C Irradiation Elements: The loading of 15 mixed-carbide irradiation specimens into tubes is under way. Three tubes have been loaded and decontaminated, but not welded. All specimens must have a bulk density not less than 80% of theoretical and a plutonium content of 20 w/o. Ten of the specimens will be a physical mixture of two coarse sizes (62.5 w/o 12/14 mesh* and 17.5 w/o 30/35 mesh) of crushed UC which is 97.5% dense and 20 w/o -325 mesh PuC, also about 97.5% dense. Five of the specimens are being made up of a similar particle size distribution, but all fractions consist of arc-melted $U_{0.8}Pu_{0.2}C$ solid solution. All specimens are filled by vibratory compaction techniques developed from bench studies of spherical and angular iron shot.

The bench model developed for the above test specimens showed that a packing efficiency of about 86% could be attained by using angular, malleable iron shot. Feed batches for the first three specimens of UC + PuC loaded were based on this model, in theory giving an effective bulk density of 84% of theoretical (assuming the feed to be 97.5% dense).

In two of the three specimens the UC coarse fractions could not be compacted to fill the desired volume. A sieve analysis of the UC dumped from the tubes showed that about one-eighth of the 12/14 mesh fraction broke down to a 14/30 mesh fraction, and that about one-half of the original 30/35 fraction broke down to a -35 mesh size. The two samples were vibrated

*All mesh U. S. Standard Sieve.

10 and 70 min before they were dumped, and both exhibited a similar breakdown of the starting granular fractions. We conclude that, under the 15 G's of 60-cycle vibration used, the breakdown of the UC coarse fractions occurs in the first 10 min of vibration. This breakdown lowers the packing efficiency enough to prevent attaining the 86% level reached with the iron-shot model. The loading of all subsequent tubes was, therefore, reduced several percent to fit the 80% bulk density originally specified.

Five of the mixed-carbide tubes have been filled to 80% of theoretical density to date. The first of these was decontaminated while the second was vibrated and filled in the same glovebox. When the first tube was sufficiently decontaminated the restrainer plug was inserted, only to reveal that the unrestrained fuel column had risen 4.8 cm in the tube, presumably owing to the faint vibrations transmitted through the box from the securely anchored vibrator. The second tube was then decontaminated without the vibrator in operation. A similar fuel column rise, but of only 4.8 mm, was noted on the second specimen. Extreme care in handling and greater efficiency in the decontamination process, reduced from four to one hour, have reduced the fuel column rise in subsequent specimens to about 2.2 mm. It has been possible to drive down the fuel column with the restrainer plug and vibration such that a satisfactory fit of the top end cap is achieved.

One of the chief bottlenecks in the fabrication job is the time required to hand grind the coarse UC chunks (and later the arc-melted buttons) to achieve a maximum yield of the 12/14 and 30/35 mesh fractions desired. A miniature adjustable-gap hand-operated jaw crusher has been designed that should help the granulation process. Tests are presently under way to see if an expansion of the fractions to 10/16 and 30/50, respectively, are feasible in the attainment of 80% bulk density.

3. Development of Jacket Materials

a. Vanadium Alloys

(i) Extrusion of TV-20 Tube-blanks. Five additional billets machined from V-20 w/o Ti (TV-20) bar stock from Union Carbide (see Progress Report for February 1965, ANL-7017, p. 30) have been extruded satisfactorily to tube-blanks. Three were conditioned, swaged, annealed, and sent to the Superior Tube Co. for drawing to a final size of 0.65 cm ID x 0.05 cm wall (0.257 in. ID x 0.020 in. wall). Part of the remaining tube-blanks will be finished to the same size at ANL.

(ii) Corrosion in Low-oxygen Sodium. Samples of V-20 w/o Ti have been exposed to sodium at 650°C for periods of time up to 335 hr (14 days) with intermittent stirring. The oxygen concentration in the sodium is believed to be less than 10 ppm, but final confirmation awaits analysis of the sodium.

The samples showed small weight gains describable by the equation

$$w^2 = 2.7 \times 10^{-4}t,$$

where w is weight gain in mg/cm^2 and t is in hours. Metallography and chemical analysis of the samples are now in progress.

(iii) Development of Refractory Metal Alloys for Service in Oxygen-contaminated Sodium. A second group of refractory alloys has been tested in 650°C sodium containing about 40 ppm oxygen (start 42 ppm; finish 43 ppm) for 168 hr. This oxygen concentration is a result of maintaining the cold trap at 250°C in the small recirculating system described last month. Preliminary results are shown in Table VI.

Table VI. Corrosion of Refractory Metal Alloys in Sodium

Alloy (w/o)	Loss of Thickness, $\text{cm} \times 10^3$
V-20 Ti	8.4
V-20 Ti-2 Mo (#7)	3.3
V-20 Ti-2 Ta (#8)	6.9
V-20 Ti-2 Nb (#9)	6.9
V-5 Ti-15 Cr (#4A)	1.8
V-40 Ti	2.3

Alloys were tested as cold rolled about 50%.

The V-Ti-Cr system continues to show significantly better corrosion resistance for a given total alloying addition.

A third test in the same system is suspect since the V-20 w/o Ti control did not corrode as much as in the first two tests. Possible causes are being investigated.

b. Niobium Alloys. A creep test with a Nb-1 w/o Zr tubular specimen at 600°C has been extended to 1000 hr without failure. The total radial strain is approaching 2% without signs of impending failure as compared to the previously reported (see Progress Report for February 1965, ANL-7017, p. 31) value of 1.25% after 345 hr of testing.

Stressed and unstressed lengths of Nb-1 w/o Zr and V-20 w/o Ti tubes have been exposed to flowing sodium at 600°C for one week as a

pretreatment to creep testing under triaxial stress. The stressed specimens exhibited measurable longitudinal strain and all showed an oxide coating but no visible signs of cracking.

4. Examination of EBR-I Mark-IV Fuel

EBR-I Mark-IV fuel rods are undergoing postirradiation examination. Eleven rods were selected to provide a complete radial sample of the Mark-IV core. Each rod contains four Pu-1.25 w/o Al fuel slugs, approximately 5.4 cm long by 0.6 cm in diameter, with four equispaced, longitudinal ribs approximately 0.18 mm high. The ribs were upset in centrifugally cast pins of the alloy; a 3-hr anneal at 550°C followed the forming operation. The slugs were NaK-bonded in 0.53-mm-wall Zircaloy-2 tubes. The NaK annulus was 0.32 mm with approximately 0.14 mm clearance for the ribs.

The Mark-IV core operated at a power level of 978 kW to an estimated burnup of 0.07 a/o. Central fuel temperatures ranged from 370 to 435°C. Except for slug dimensions, which were recorded for each slug, postirradiation evaluations are to be compared with specifications for the fuel and cladding materials.

Gamma-activity measurements of the fuel rods identified the high- and low-burnup locations for chemical and metallographic analyses. Visual examination of the rods as-received revealed no indications of fuel swelling or distortion. After sectioning of each fuel rod in the vicinity of the NaK level spacer, the fuel slugs dropped freely out of the tubes. End-bonding of adjacent slugs occurred in two instances, thus reducing the total number of slugs for length measurements to 40. The nature of the bond between slugs has not yet been determined.

No indication of slumping was observed. On the contrary, slug length changes were characterized by growth (up to 0.18%), and diameter changes were characterized by shrinkage (up to 2.6%). Density measurements completed for about one-fourth of the slugs have indicated no significant changes.

5. Alternative Fuel-element Geometries

a. Development of Powder-loaded, Radiator-type Fuel Elements

(i) Radiator Development. The term "radiator fuel element" denotes an extended-surface heat-exchanger fuel element. Such elements may afford higher heat-exchange rates than plate- or rod-type elements. The complexity of solid shapes required to fill such elements has delayed the development of the radiator fuel element.

Two model radiators have now been constructed. Each has solid rods in a hexagonal array, one of 61 and one of 91 rods as stand-ins for tubes. The models will be used to determine the packing density of spherical and angular components within the triangular space between tubes. This information will be used to predict ultimate densities achievable in particulate systems as well as to dictate the design of the actual radiator shape.

(ii) Vibratory Compaction. Work on the compaction of irregular shaped particles has been completed. The relationship between the packing efficiency of a single component and the size of the particle has been found by computer to be

$$Pe_1 = 0.635 - (0.032/d_1) - 0.072 e^{-0.207D/d_1},$$

where Pe_1 is the packing efficiency, D is the diameter of the container, and d_1 is the diameter of the single component. The fit of the equation to the data points yields a standard deviation of packing efficiency of 0.009 for particle dimensions greater than 300 μ .

The packing efficiency of a second angular component in the matrix formed by the first component is expressible as

$$Pe_2 = 0.484 - 0.192 e^{-0.098d_1/d_2}.$$

The standard deviation is 0.026.

With the aid of the two above equations the total packing fraction of a binary system of angular materials reduces to

$$0.812 - (0.017/d_1) - 0.037 e^{-0.207D/d_1} - 0.070 e^{-0.098d_1/d_2}.$$

The value 0.812 is the limiting density of a binary system of angular (approximately tetragonal) grit. Efforts to produce uniform density by infiltration of a third component into a binary system were singularly unsuccessful.

The information gleaned from the above studies is now being put to practical use. The application of the results of these "bench studies" is discussed in Section I. D. 2. b, "Fabrication of PuC and (U,Pu)C Irradiation Elements."

6. Zero Power Reactor Fuel Development

a. Evaluation of ZPR-3 Elements for SEFOR Critical Experiment.

This program will evaluate preproduction specimens submitted by the manufacturer and inspect production specimens for conformity to specification. Evaluation of the preproduction will be by the laboratory inspection of 20 U-Pu-Mo alloy core plates of four typical sizes and the inspection of 70 jacket panels; 70 dummy wafers containing stainless steel core plates; five wafers containing U-Pu-Mo alloy plates; and ten weld strips and run-out rods.

Thirty-five stainless steel jacket panels were received from the fabricator and visually inspected. Numerous panels contained imbedded metal chips and other defects that made them unacceptable. All the panels had obviously not passed through the manufacturer's degreasing, cleaning, or quality-control inspection operations. Further inspection was discontinued, and the fabricator was requested to resubmit materials meeting the specification.

Three 4.51-cm x 7.06-cm core plates were received for preproduction qualification. These were rejected after visual inspection and measurement for cold shuts, cracks, deep shrinkage voids, and other defects, indicating the need for improved casting practices. The fabricator was requested to submit material of higher quality.

Five additional core plates of the same size were received. The surface of these was greatly improved and was considered acceptable pending the evaluation of surface cracks found on three of four core plates. The core plates were measured and the dimensions were found to be acceptable, with a few minor deviations. As part of the inspection, three of the core plates were scored and fractured. The surfaces of the fractures of two plates were without defects. The fracture surfaces of the third showed several small inclusions. Samples were submitted for chemical analysis and for metallographic examination of the surface cracking condition.

E. General Fast Reactor Fuel Reprocessing Development

1. Skull Reclamation Process

The skull reclamation process, being developed as an auxiliary process in the EBR-II fuel cycle to recover and purify uranium from skulls remaining in melt refining crucibles, is being studied on a pilot-plant scale of 1.5 kg of uranium. In the last few runs in the pilot-plant equipment, special attention has been given to achieving good uranium recoveries, i.e., recoveries of greater than 95% of the uranium in the crucible residues.

(Since only a small fraction of the total discharged EBR-II fuel, less than 10%, is processed by the skull reclamation process, a 95% recovery is adequate.) Excessive uranium losses occurred in earlier runs, principally by entrainment of uranium-zinc intermetallic precipitate in the waste magnesium-zinc supernatant solution which is transferred out of the crucible after the uranium-zinc intermetallic compound is precipitated and the solution is cooled (see Progress Report for December 1964, ANL-6997, p. 8).

Measures which have been taken in recent runs to produce a well-settled precipitate bed (mainly, longer settling of the precipitate under quiescent conditions) were effective in reducing entrainment losses to acceptable levels (1 to 2% uranium). However, transfer of the supernatant waste solution to a waste receiver (effected by pressuring the supernatant from beneath a frozen layer of salt through a transfer line) became slow and erratic. This difficulty resulted from the solidification of a small amount of salt in the transfer line, forming a plug or a restriction while the flux-metal system was being cooled to the metal transfer temperature. Since the melt is cooled below the freezing point of the flux for the transfer, a small amount of flux can restrict or plug the transfer line. This difficulty was overcome simply by increasing the furnace pressure sufficiently to raise the metal and any flux floating on the metal into the heated section of the transfer line before the melt cooled to the liquidus temperature of the flux. The metal was maintained at this height in the transfer line during the remaining cooling and settling period, and the flux in the heated portion of the transfer line remained molten. Three successive transfers of supernatant metal waste were made without difficulty by this technique, and the technique will be developed further for use in the skull-reclamation process.

2. Processes for Advanced Reactor Fuels

Compact pyrochemical processes are under development for processing fast breeder reactor fuels of the ceramic (e.g., oxide and carbide) or metallic types. In these processes, a solution of plutonium, uranium, and fission products in cadmium is first produced. Subsequently, uranium and plutonium are separated from the fission products by two major operations: (1) selective oxidation of uranium and plutonium (and the more easily oxidized fission products) to chlorides and their transfer to a molten halide salt phase, leaving in the metal phase the relatively noble fission products such as ruthenium, molybdenum, palladium, and technetium, and (2) selective reduction of uranium and plutonium to the metals and their transfer from the salt phase to a cadmium-magnesium-zinc metal phase, leaving in the salt phase the highly reactive fission products (rare earth and alkaline earths). Cadmium chloride is employed as the oxidizing agent, and a magnesium-sodium-potassium alloy is employed as the reducing agent.

Uranium and plutonium metals are recovered from the product solution by vaporizing the solvent metals. The uranium and plutonium may then be converted to the desired type of fuel by conventional procedures.

A laboratory-scale test was done with uranium alone to study the possibility of maintaining a constant salt composition by adding sodium, potassium, and magnesium, in the reduction step, in proportions to yield 30 m/o NaCl-20 m/o KCl-50 m/o MgCl_2 for use in the oxidation step. Results showed that in the step in which uranium and plutonium are to be selectively oxidized, the molten salt (30 m/o NaCl-20 m/o KCl-50 m/o MgCl_2) could accommodate UCl_3 concentrations up to 30-35 m/o at the proposed operating temperature of 600°C. Subsequently, the uranium was reduced by sodium-potassium-magnesium (in liquid cadmium) in the proper proportion to regenerate the 30 m/o NaCl-20 m/o KCl-50 m/o MgCl_2 salt. The reaction proceeded smoothly, and reduction of UCl_3 was essentially complete. Further work will be done on this system.

The cadmium chloride (oxidizing agent) can be regenerated from a portion of the recycled cadmium by chlorination in the presence of the molten salt (30 m/o NaCl-20 m/o KCl-50 m/o MgCl_2). Specifically, chlorination at about 500°C yielded CdCl_2 concentrations in the salt of up to 60 m/o. This chlorination can be easily performed and avoids the purchase of CdCl_2 which is expensive.

The noble metal waste solution and the rare earth waste solution containing the fission products are treated to permit recycle of the bulk of the salt and metal solvents to the oxidation and reduction steps. The cadmium is vaporized from the noble metal waste solution and collected for recycle; the salt solution is purified by extracting fission products into an aluminum-magnesium alloy, which is then discarded as a waste.

A program is under way to develop engineering technology applicable to the separation of plutonium from rare earth fission products by multistage extractions in molten metal-salt systems. The engineering developmental program is presently concentrated on studies of mass transfer rates between liquid metal and liquid salt phases at high temperatures. The objectives are to demonstrate the feasibility of metal-salt extractions, to determine optimum operating conditions, and to obtain a clearer understanding of the extraction processes.

Three mixing-settling runs were made to determine the mixing time and degree of agitation required for the extraction of cerium (a representative rare earth) from 5 kg of a Cd-11 w/o Zn-5 w/o Mg-3 w/o Ce alloy into 2 kg of a MgCl_2 -30 m/o NaCl-20 m/o KCl salt phase at 600°C. Complete transfer of cerium from the metal phase to the salt phase could be effected by a few minutes of moderate to vigorous agitation.

3. Materials and Equipment Evaluation

Two tungsten crucibles are being employed in the EBR-II skull reclamation process. One crucible, of relatively large size (15 in. ID by 30 in. high), is used for the steps between oxidation of melt refining crucible skulls and retorting of uranium-magnesium-zinc solution for recovery of uranium metal product; the other crucible, of smaller size ($7\frac{1}{2}$ in. ID by 17 in. high), is used for the retorting step. The tungsten crucibles used to date in the skull-reclamation process have been made by pressing and sintering, and have given good performance. However, because the method of their fabrication results in crucibles with thick walls, the crucibles are heavy, unwieldy, and expensive. Alternative methods of fabrication, which might overcome the disadvantages of pressed-and-sintered tungsten crucibles, are being examined.

Efforts to obtain satisfactory tungsten-lined silicon carbide crucibles have been discontinued since it has been found that the sprayed tungsten coatings can not be made sufficiently nonporous for process use. The silicon carbide substrate can not withstand the temperature (1350°C) required to close the pores by sintering.

A promising technique for fabrication of a free-standing tungsten crucible consists of plasma-spraying tungsten on a removable mandrel and subsequently sintering the crucible at a high temperature for densification. Such a crucible would have properties similar to the pressed-and-sintered crucibles now in use, but would have a thinner, more uniform wall and would probably cost less. A small plasma-sprayed crucible (4 in. OD by 6 in. high by $\frac{3}{16}$ -in.-thick wall) has performed very well in preliminary tests for flux and metal containment. In one test, the crucible was held at 800°C for 1 hr while containing equal weights of a Zn-Mg mixture and a MgCl_2 - CaCl_2 - CaF_2 mixture. No evidence of leakage was observed. In another test, the crucible was exposed to EBR-II process salts at 800°C for $4\frac{1}{2}$ hr, again with no evidence of leakage. Delivery of a second small crucible is expected soon. Several manufacturers have the capability to produce large tungsten crucibles by this technique.

A corrosion test was done as part of an investigation to determine the feasibility of removing uranium product as a powder from a tungsten retorting crucible after hydriding the uranium (and possibly later dehydriding it). A 2-in. by 0.3-in. by 0.02-in. tungsten coupon and an ingot charge were loaded into a crucible, and retorting and hydriding operations were then performed. The tungsten coupon did not suffer any detectable detrimental effects as a result of exposure in the retorting and hydriding steps.

A new crucible material, vitreous carbon, a product of Société le Carbone, France, has been tested for containment of molten metal and salt

systems. The material is similar to glass in that it is fragile, microscopically sealed, and impervious to gas. It has good thermal shock resistance. A small crucible ($1\frac{3}{8}$ in. OD by $1\frac{3}{8}$ in. high by 0.10-in.-thick wall) contained a Zn-12 w/o Mg-10 w/o U/flux solution, which is used in the skull-reclamation process, for 24 hr at 800°C. Neither the flux nor the metal wetted the crucible. The only size limitation that is known for this material is a maximum wall thickness of $1/8$ in. Because of its fragility, a full-size crucible for process use would have to be placed in a secondary container. This crucible material looks promising and will be investigated further.

II. GENERAL REACTOR TECHNOLOGY

A. Experimental Reactor and Nuclear Physics

1. Prompt $\bar{\nu}$ of U^{235}

Recent measurements^{2,3} of $\bar{\nu}_p$, the average number of prompt neutrons per fission for fast-neutron-induced fission of U^{235} , have indicated that at about 0.3 MeV there may be a departure from an approximately linear increase with energy. In an attempt to confirm this phenomenon, a series of measurements have been made over the energy range from 0.039 to 1.0 MeV, with the preliminary results shown in Table VII and Figure 7.

Table VII. Prompt $\bar{\nu}$ Values for U^{235}

E_n , MeV	ν_p	E_n , MeV	ν_p
0.039	2.401 ± 0.017	0.375	2.467 ± 0.022
0.046	2.403 ± 0.016	0.405	2.454 ± 0.022
0.150	2.449 ± 0.018	0.425	2.519 ± 0.017
0.225	2.466 ± 0.018	0.476	2.499 ± 0.019
0.265	2.455 ± 0.022	0.548	2.487 ± 0.017
0.298	2.458 ± 0.022	0.675	2.501 ± 0.017
0.325	2.496 ± 0.018	0.785	2.518 ± 0.014
0.358	2.422 ± 0.018	1.000	2.540 ± 0.016

Figure 7. Prompt $\bar{\nu}$ for U^{235} . The horizontal bars indicate the spread incident energy.

²Mather, D. S., Fieldhouse, P., and Moat, A., The Number of Prompt Neutrons and the Kinetic Energy of Fragments during Low Energy Fission of U^{235} , *Phys. Rev.* **133**, B1403 (1964).

³Blyumkina, Yu. A., Bondarenko, I. I., Kuznetsov, U. F., Nesterov, U. G., Okolovich, U. N., and Smirenkin, G. N., Average Number of Prompt Neutrons from U^{235} Fission Induced by Neutrons from Thermal to 8 MeV, *Atomnaya Energiya* **15**, 64 (1963); *Soviet Atomic Energy* **15**, 725 (1964).

All measurements were made relative to $\bar{\nu}_p$ for spontaneous fission of Cf^{252} . Absolute values are based on $\bar{\nu}_p(\text{Cf}^{252}) = 3.782$. Future refinements in the various corrections to the data may result in a shift in the absolute values by as much as 0.4%, but this should cause little if any change in the relative values.

2. Elastic Scattering of Fast Neutrons

A number of measurements of differential elastic-scattering cross sections have been completed recently.

a. Al and Na. Both the total cross section and the differential elastic-scattering cross sections of aluminum were determined from 0.3 to 1.5 MeV. Measurements of the total cross section were carried out with resolution of 0.1 nsec/m or 2 keV, whichever is smaller, in a given energy region. Gross resonance structure, indicated by the dotted curve of Figure 8, was observed. Multilevel resonance fits to these resonances are now in progress. The differential scattering cross sections measurements are indicated by the open circles of Figure 8. The resolution was about 20 keV. When this is taken into consideration, the agreement between the experimental high-resolution total cross sections and the measured scattering cross sections is good.

Figure 8. The Measured Total Neutron Cross Section of Aluminum (Dotted Line) and the Experimental Differential Elastic-scattering Cross Section Aisles Expressed in the Form

$$\frac{d\sigma}{d\Omega} = \frac{\sigma_{el}}{4\pi} \left(1 + \sum_{i=1}^4 \omega_i P_i \right).$$

The solid lines represent calculations based on the optical model.

The experimental results were compared with the results of calculations based on the optical model, indicated by the solid lines in Figure 8. Since the nuclear optical model is founded on average resonance effects, the experimental results must be averaged over a number of measurements before comparison with theory. When this is done the theory nicely predicts the experimental values, as indicated in the figure. This is remarkable, for aluminum is a very light nucleus not well described by the optical potential.

Scattering measurements were similarly made with sodium. Although sodium is characterized by a wider-spaced resonance structure than aluminum, the characteristics of the process and its interpretation are similar to those pertaining to aluminum.

b. In, Cd, and Ag. The elastic scattering of fast neutrons from the medium-weight nuclei In, Cd, and Ag has been experimentally examined in detail. Typical results for indium are given in Figure 9. In these nuclei,

Figure 9. The Measured and Calculated (Optical Model) Elastic-scattering Cross Sections of Indium

the experimental resolution of ~ 20 keV certainly averages over a number of resonances; thus the measurements can be compared directly with the theoretical optical-model calculations, indicated by the solid curves. Both the measured total scattering cross sections and the coefficients of the Legendre polynomial expansion of the differential distributions are well described by theory. These nuclei, In, Cd, and Ag, are of medium weight, spherical, and away from closed shells. They are, therefore, ideally suited to optical model interpretations.

3. High Conversion Critical Experiment

The thermal disadvantage factor ξ was measured in five High Conversion (Hi-C) cores. The experimental values indicate that ξ does not decrease monotonically with decreasing water-to-uranium oxide volume ratio as predicted by calculations. The ratios in these stainless steel-clad cores varied between 0.96 and 0.16.

The disadvantage factor was obtained by using the so-called integral technique. Foils of a 17.5 w/o uranium-aluminum alloy enriched to 92.75 w/o U^{235} were shaped to measure the U^{235} fission rate in representative portions of the fuel and moderator volumes of a unit cell. Cadmium ratios in both fuel and moderator sections were determined by using 0.051-cm cadmium covers over the foils. Various foil thicknesses (0.0051 to 0.066 cm) were used. The foil activities were corrected for thermal self-shielding. In the foil irradiation, various masses of cadmium were used; the cadmium ratios were corrected to zero cadmium mass.

The results are shown in Table VIII. The error limits on the U^{235} fission cadmium ratios reflect the uncertainty of the extrapolation to zero cadmium mass as well as the data scatter. The U^{235} fission disadvantage factors, ξ^{25} , are plotted versus water-to-oxide volume ratio in Figure 10.

Table VIII. Thermal Disadvantage Factors and U^{235} Fission Cadmium Ratios in Hi-C Lattices

Lattice		Experimental Results				Calculated ξ		
Pitch, cm	Water-to-Oxide Volume Ratio	Fuel Cadmium Ratio	Moderator Cadmium Ratio	Bare Moderator to Bare Fuel Ratios	ξ	THERMOS Number Density	THERMOS U^{235} Fission	B692/RP Flux
1.24 (square)	0.962	4.49 ± 0.11	5.19 ± 0.15	1.118 ± 0.009	1.160 ± 0.015	1.238	1.248	1.163
1.27 (triangular)	0.757	3.75 ± 0.08	4.14 ± 0.10	1.075 ± 0.009	1.112 ± 0.015	1.225	1.234	1.154
1.166 (triangular)	0.437	2.55 ± 0.06	2.72 ± 0.08	1.054 ± 0.004	1.096 ± 0.026	1.190	1.198	1.140
1.127 (triangular)	0.324	2.15 ± 0.05	2.33 ± 0.08	1.050 ± 0.008	1.120 ± 0.038	1.186	1.193	1.136
1.069 (triangular)	0.164	1.59 ± 0.03	1.69 ± 0.09	1.081 ± 0.041	1.189 ± 0.109	1.157	1.162	1.133

Figure 10

The variation of the thermal disadvantage factor with the water-to-uranium oxide volume ratio common to Hi-C cores is shown for both experimental and theoretical values. The theoretical values were calculated by three different methods.

Also given in Table VIII and Figure 10 are the results of three computations. An extra scattering region in the unit cells was used to approximate an isotropic return at the boundary. Values of ζ for both neutron density and U^{235} fission are given. The disadvantage factor was also calculated using a collision probability technique⁴ and the flat-flux approximation. The collision probabilities were computed by the B-692/RP code,⁵ which considered a three-region cell (fuel, clad, and moderator). The cross sections used for this one-group calculation were the averaged ones obtained from the THERMOS outputs. This computation results in flux ζ 's.

Two disagreements are noted in the comparison of the calculations with the experimental data. First, except for the tightest lattice, all calculated values are larger than experimental disadvantage factors. This is what Honeck⁶ observed when he found that theory predicted disadvantage factors that were 3 to 5% higher than measured, the 3% corresponding to the lowest W/U lattices (about 4) and the 5% to the highest W/U lattice (about 1.2) for which he had experimental data. This trend appears to continue through the lowest Hi-C lattices. For these lattices, the theory predicts disadvantage factors which are 6 to 10% larger than measured values.

The second difficulty is that while the experimental values increase at values of water-to-uranium oxide volume ratio lower than about 0.5, the calculations show the disadvantage factor to be monotonically decreasing with smaller lattice pitch. As is indicated by the error bars on the experimental points in Figure 10, ζ becomes increasingly difficult to measure as the lattice pitch decreases. Nevertheless, the experimental results do suggest the existence of a minimum value of ζ at a water-to-oxide volume ratio of about 0.5.

At this time it is not known whether the discrepancy in or between experiment and theory is due to experimental or computational error.

⁴Pennington, E. M., Collision Probabilities in Cylindrical Lattices, Nucl. Sci. Eng. 19, 215 (1964).

⁵Pennington, E. M., Cylindrical Lattice Collision Probability Codes, B-692/RP, ANL-6836 (1964).

⁶Honeck, H. C., The Calculation of the Thermal Utilization and Disadvantage Factor in Uranium/Water Lattices, Nucl. Sci. Eng. 18, 49 (1964).

4. Techniques for Foil-activation Measurements

A FORTRAN routine, Program DEADTIME (RP-362), has been written for the CDC-3600 computer in conjunction with the standard ANL foil-data-processing code RP-202. By use of the input and output cards from RP-202, the DEADTIME program uses successive counts from the decaying foils to determine an effective resolving time for each counting channel. The program is designed for use when the counting period extends over one or more half-lives. In practice, the program not only provides a calculation of true deadtime, but also provides a means of compensating for long-term gain in the circuitry, especially for those which are counting-rate dependent. A value of the deadtime plus up to five additional power series coefficients can be provided. Equation (1) is nominally used to correct the measured counting rate:

$$T = M + AM^2 + BM^3 + CM^4 + \dots, \quad (1)$$

where

T = time counting rate;

M = measured counting rate;

A = deadtime;

$B, C, \dots$ = higher-ordered coefficients.

The data, however, rarely justify the use of more than one additional coefficient.

Another program (FOILNORM) is also being prepared for use in conjunction with RP-202. This program is divided into two parts. The first part is intended to provide weighted averages when the same group of foils has been counted on more than one scaler, in more than one system, or at several different times. The second part is for use in internormalizing the data from a set of foils which is so large that it is separated into two or more groups, for counting on different channels or at different times. It is necessary that each group include one or more foils which are common to every other group.

5. Absolute Fission-rate Determination

In the past there has been disagreement between calculated and measured values of the ratio of U^{238} capture to U^{235} fission in fast spectra. A typical example of this is given by Avery et al.⁷

⁷Avery, R., Hummel, H. H., Hwang, R. N., Meneghetti, D., Moldauer, P. A., Smith, A. B., Greebler, P., and Nims, J. B., *Physics of Fast Reactors*, Third International Conference on the Peaceful Uses of Atomic Energy, Geneva, Switzerland, September, 1964, Paper No. P/259 (to be published).

The measurement is made radiochemically with two uranium foils: one highly enriched in U^{235} , the other of normal uranium or uranium slightly depleted in U^{235} . The number of fissions in each foil is determined by Mo^{99} analysis. The number of U^{238} neutron captures is determined in the normal or depleted foil by Np^{239} analysis. From these two analyses, the ratio of $\bar{\sigma}_c^{238}/\bar{\sigma}_f^{235}$ is calculated.⁸

The precision of the two above-mentioned measurements depends upon absolute beta-counting techniques. The equipment used in these measurements was calibrated several years ago. A systematic error was indicated, since the calculations were always 10 to 20% higher than the measured values. A deviation of 10 to 20% could indicate a possible error due to nonuniformity in the samples. Another possibility was that the calibration of the counting equipment was in error or an error existed in the U^{238} neutron capture value.

Since there are at least four laboratories other than ANL, Illinois, which have experience in making fission rate determinations by the Mo^{99} analysis, it was decided to have other laboratories measure comparable samples, compare results, and attempt to resolve the differences. Foils irradiated in the AFSR have been distributed to the four other laboratories for counting. A general agreement was obtained in the fission analysis to within $\pm 2\%$.⁹

Another method was used to check the fission-rate analysis. A thin, 93% enriched U^{235} foil, 0.010 in. (0.025 cm) thick, was taped on the outside of an absolute fission counter. Uranium-235 of identical composition was electroplated on a 0.005-in. (0.0125-cm) stainless steel plate, which acted as the one end of the fission counter. The uranium foil for radiochemical analysis was placed on the opposite side of the plate. The separation between the uranium foils was 0.005 in. (0.0125 cm); it was assumed that the fission rate per gram in both foils was the same. The weight of the fission counter foil was known to be better than 1%, so that the fission rate could be determined to approximately 1%.

In order to reduce flux depression in the foils, the entire counter-fission foil assembly was wrapped with 0.010 in. (0.025 cm) of 93% enriched U^{235} . This, in turn, was covered with 0.020 in. (0.050 cm) of cadmium, so that the thermal flux was filtered out and the uranium foils were exposed to a fairly hard neutron flux. The counter-fission foil assembly was irradiated in a thermal-neutron flux. The fission rate per gram was determined by the absolute fission counter. Radiochemical analysis of the fission foil yielded agreement with the fission counter data to within $\pm 2\%$.

⁸Armani, R. J., Bennett, E. F., Brenner, M. W., Bretcher, M. M., Cohn, C. E., Huber, R. J., Kaufmann, S. G., and Redman, W. C., Improved Techniques for Low-flux Measurement of Prompt Neutron Lifetime, Conversion Ratio, and Fast Spectra, Proc. IAEA Symposium on Exponential and Critical Experiments, Vienna (1964).

⁹Huber, R. J., private communication.

The results of these cross checks of the fission-rate determinations and the absolute fission counter measurements indicated that there was no substantial error in the original work. If any experimental error exists, it must lie in the U^{238} neutron capture measurement.

B. Theoretical Reactor Physics

1. Equivalence between Homogeneous and Heterogeneous Systems

In resonance-integral calculations, it is possible with certain assumptions to define, for heterogeneous systems, an equivalent scattering cross section per absorber atom, σ_p , such that a homogeneous resonance integral calculated with this σ_p has the same value as the heterogeneous one. The question of finding a relation of this type accurate enough for fast-reactor resonance-integral evaluation and simple enough for routine calculations has been studied.

The Bell Approximation^{10,11} appears adequate to calculate the Dancoff factor, $\gamma = 1 - C$, provided it is modified slightly to give higher values of γ at higher values of moderator optical chord length.¹² In the following, subscript 1 refers to fuel and 2 to moderator:

$$\gamma_B = \frac{1}{1 + \frac{\Sigma_{e2}}{\Sigma_2}} \quad (1)$$

where Σ_2 = moderator total cross section, and

$$\Sigma_{e2} = \frac{1}{\ell_2} = \frac{S_1}{4V_2} = \frac{R_1}{2(R_2^2 - R_1^2)}.$$

We propose the modification

$$\gamma = \gamma_B + \gamma_B^4 (1 - \gamma_B). \quad (2)$$

This value of γ is practically the same as γ_B for small values of γ_B , slightly larger for larger values of Σ_2 , and never exceeds unity as $\Sigma_2 \rightarrow \infty$.

For an isolated rod, the escape probability P_0 may be expressed in the form

¹⁰Bell, G. I., A Simple Treatment for Effective Resonance Absorption Cross Sections in Dense Lattices, Nucl. Sci. Eng. 5, 138 (1959).

¹¹Nordheim, L. W., The Theory of Resonance Absorption, Symp. Appl. Math., 11, 58 (1961).

¹²Leslie, D. C., Hill, J. G., and Jonsson, A., Improvements to the Theory of Resonance Escape and Heterogeneous Fuel. I. Regular Arrays of Fuel Rods, AEEW-R353 (Feb 1964).

$$P_0 = \frac{1}{1 + \frac{\Sigma_1}{\Sigma_{e_1} a}}; \quad \Sigma_{e_1} = \frac{S_1}{4V_1} = \frac{1}{2R_1}, \quad (3)$$

where a is a factor suggested by Levine¹³ which makes the rational approximation exact. This expression is then exact if a is regarded as a function of Σ_1 , but useful for obtaining an equivalence relation only if some mean value $\bar{a}$ is used. A value of 1.35 seems appropriate for an isolated rod.¹⁴

When Dancoff interaction must be considered, the escape probability for the rod in the lattice, P_0^* , must be cast again in the form of a rational approximation:

$$P_0^* = \frac{1}{1 + \frac{\Sigma_1}{\Sigma_{e_1}^*}} \quad (4)$$

to obtain an equivalence relationship. $\Sigma_{e_1}^*$ can be accurately approximated as a function of C and Σ_1 in a cylindrical lattice^{11, 15} by

$$\Sigma_{e_1}^* = \Sigma_{e_1} (1 - C) \left[\frac{a}{1 + (a - 1) C} \right]. \quad (5)$$

It is necessary in this case also to define a mean value of a which need not necessarily be the same as in the case of the isolated rod. The problem is the selection of what mean value of a to use. It would be possible to make $\bar{a}$ a function of C ; however, this does not at present seem worthwhile. When C is nearly 1, the expression in brackets in equation (5) is nearly 1 regardless of a ; and when C is small, the isolated rod condition is approached for which $\bar{a}$ is 1.35. Levine¹³ has recommended a value of 1.10. Preliminary investigation indicates that a value of 1.35 is more satisfactory. This point is being studied further. When more detailed information is available it may be desirable to consider $\bar{a}$ a function of C .

2. Total Neutron Cross Sections

A FORTRAN code, RESFIT, has been written for the CDC-3600 to fit cross sections, calculated by using multilevel formulae for purely scattering resonances without Doppler broadening, to experimental cross sections obtained from transmission measurements made by the Van de Graaff group. The code succeeds one which used single-level formulae written

¹³Levine, M. M., Resonance Integral Calculations for U²³⁸ Lattices, Nucl. Sci. Eng. 16, 271 (1963).

¹⁴Otter, J. M., Escape Probability Approximations in Lumped Resonance Absorbers, NAA-SR-9744 (Aug 1, 1964).

¹⁵Aisu, H. and Minton, G. H., Effective Surface in Lattices in the Calculation of Resonance Integrals, Nucl. Sci. Eng. 19, 470 (1964).

for the IBM-704. The input to RESFIT includes up to 300 pairs of experimental energies and total cross sections, values of known parameters, and initial guesses for the unknown parameters. Orbital angular momenta for $\ell = 0, 1$, and 2 are allowed. The code calculates the total cross section at each experimental energy and uses the method of least squares to yield new values for the unknown parameters. The total cross sections are then recalculated from the new parameters, and the least-squares procedure is repeated until convergence criteria are satisfied or until the maximum number of iterations allowed by the input is reached.

A study was made of the feasibility of determining α^{49} and α^{41} in the plutonium loading of EBWR, by irradiation of capsules and flux measurements with and without cadmium covers.

The measurements involve the preparation of test samples of Pu^{239} and Pu^{241} , about 1 mg in weight, to be mounted on fuel pins of fuel elements. Subsequent to irradiation (minimum of about 35 days for samples with cadmium covers), the samples would be removed and capture to fission ratios determined by mass-spectrographic measurements and cesium-disintegration rate analysis.¹⁶

For an irradiation exposure of about 35 days, α_{epi}^{41} could be determined with an accuracy of about 15%. This is based on an estimated impurity of Pu^{242} of 0.88% in Pu^{241} .

C. High-temperature Materials

1. Ceramics

a. Properties of (Th-U) Phosphides. An attempt to measure the melting point of stoichiometric UP in equilibrium with its own vapor was made. A pellet was placed in a full-density tungsten crucible, which was then sealed by electron-beam welding. The crucible was heated at roughly 25°C increments, starting at 2500°C. Gamma radiography was employed to detect when melting had occurred. The pellet showed signs of softening at 2580°C and had partially melted at 2610°C. Heating the crucible to 2620°C resulted in complete melting of the pellet. Gravimetric analysis showed that no material had been lost from the crucible during heating.

Studies of the system UP-UN continued. Solid solubility in this system is limited to about 0.6 w/o UN in UP. There was no solid solubility of UP in UN nor did any intermediate compounds exist. Vaporization studies in vacuum showed that UN vaporized faster than UP and that the intermediate compositions also exhibited greater weight losses than UP. Pellets rich in UN exhibited very large losses at 2000°C in vacuum due to vaporization and melting.

¹⁶Crouthamel, C. et al., Capture to Fission Ratios of U^{235} , U^{238} , and Pu^{239} in EBR-I, Mark III, J. Nucl. Sci. and Eng., 21 (Feb 1965).

b. Preparation and Properties of Plutonium Sulfide and Plutonium Phosphide. The phases present in various compositions near those of PuS and PuP are being studied to determine ranges of stoichiometry and oxygen solubility. These studies are being conducted by use of metallographic and X-ray diffraction techniques on samples with various composition and impurity contents. High-purity material is needed as a starting point. Previous work has shown that PuS with less than 0.05 w/o total nonmetal impurities could be prepared by the gas-metal reaction. Recently PuP was prepared by the same method, with a total nonmetal impurity content of about 0.08 w/o. Attempts are being made to fabricate this material into disc specimens for diffusivity and heat-capacity measurements.

The thermal expansion of PuP was measured from room temperature to 960°C. The linear thermal expansion coefficient for this temperature range was $11.9 \times 10^{-6}/^{\circ}\text{C}$. No discontinuities were found in the expansion curve.

c. Mechanical Properties of Uranium Compounds. Mechanical tests of UO_2 in a gas atmosphere at 1500°C were continued. Moisture in the helium cylinder was detected after specimens showed unusual plasticity (see Progress Report for February 1965, ANL-7017, p. 49). A drying tower in which molecular-sieve material was used proved somewhat effective as a dryer after activation, but did not lower the moisture content below 15 ppm, even after cold trapping in liquid nitrogen. The drying agent was unable to cope with a steady flow of moist gas once the cylinder became less than two-thirds full, and the capacity between activation periods was distinctly limited for the sensitive reaction of UO_2 to moisture.

The hydrogen-purification system in the laboratory was completed, leak tested, and commissioned to repeat the above tests in what should be a very pure gas. Initially, a stagnant atmosphere of hydrogen was employed, as with helium, at a pressure of 1 to 5 mm. Again, the plasticity of the specimen at 1500°C was increased, but inconsistently. The hydrogen atmosphere "cleaned up" the surface of the tungsten tools and heat shields, and this water-producing reaction could account for the moisture, which does not enter with the gas, but is produced in situ by reduction of metal oxides present in the hot zones. Employment of a dummy run in hydrogen as a cleanup procedure and insertion of the specimen with minimum exposure of the furnace to air before testing in hydrogen leads to excellent results. Although the strength of the uranium was little affected, the ductility was still higher than in similar tests in vacuo.

Runs were made in flowing hydrogen in an endeavor to sweep out the moisture before it could affect the specimen. Helium, dried as before, was used to purge and bring the furnace to slightly higher than

atmospheric pressure before admitting hydrogen. Again difficulty was experienced with moisture from the helium, moisture that could not be removed with certainty by the flow of hydrogen. Subsequently, the helium purge was discontinued and direct entry of hydrogen was made after evacuation. Cleanup procedures proved to be essential whenever exposure to moisture had occurred, even for minutes. The tests then became consistent and showed an embrittling effect of hydrogen on low-density samples in direct contrast to the increased plasticity introduced by the presence of moisture.

Additional samples of high density were tested in flowing hydrogen with no helium purge and with rigid precautions to avoid the ingress of moisture. This time a high rupture strength, reasonably high ductility, and the return of a yield point occurred in all samples under medium strain. The rupture strength was higher, the ductility slightly higher, than any values previously attained at 1500°C, even with fast strain. Results are summarized in Table IX.

Table IX. Deformation of UO_2 at 1500°C in Varying Atmospheres

Number of Samples	Density (g/cc)		Maximum Stress (kg/cm ²)		Mean Strain Rate (mm/sec x 10 ⁴)	Mean Total Strain (mm)	Mean Load Rate (g/sec)	Atmosphere
	Mean	Standard Deviation	Mean	Standard Deviation				
4	10.59	0.01	859	16.6	12.2	0.38	149.7	1 to 5 mm Helium
6	10.52	0.03	932	43.2	9.8	0.33	149.7	1 to 5 mm Hydrogen
5	10.47	0.004	793	48.7	12.0	0.18	303.9	Flowing Hydrogen
5	10.62	0.001	1568	88.9	7.5	0.43	145.2	Flowing Hydrogen

A possible explanation of the effect of atmosphere appears as follows. Water appears to lower the breaking strength, even at room temperature (see Progress Report for February 1965, ANL-7017, p. 49), but at higher temperature also increases ductility. Modification of the stress system around pores seems feasible, but some effect on crack propagation must also be involved. Hydrogen could conceivably enter the UO_2 lattice by dissociation (at the surface) of water vapor together with oxygen. The oxide would then become slightly nonstoichiometric at the surface involved, and therefore more plastic. The hydrogen, on the other hand, could diffuse more readily through the lattice, and either interfere with dislocation movements through the lattice by frictional stress against a U-O pair, or by occupying vacancies that normally assist movement of U-O pairs.

Hydrogen produced at the surface by dissociation of water should enter the lattice readily. Where the gas is present in molecular

form and moisture is absent, dissociation of hydrogen will be small unless the surface area is large. This may explain why low-density specimens are more affected by hydrogen than high-density ones. Confirmatory tests with one freshly ground face exposed to the gas will be attempted in an endeavor to check this.

d. Thermal Stability

(i) UO₂. Samples of uranium dioxide were prepared by sintering compacts in hydrogen at 1750°C for 4.5 hr. The apparent density of the sintered samples was 97.8% of theoretical as calculated from measurements made with CCl₄ as the suspending media. Oxygen-to-uranium ratios were determined from weight changes resulting from oxidation and reduction of randomly selected samples. The average oxygen-uranium ratio was determined to be 2.01.

Specimens of UO₂ were suspended from tungsten wire for the determination of the evaporation rate in vacuum. No reactions with tungsten were noted within the temperature range investigated.

Figure 11. Evaporation Rate of UO_{2,01}

Weight-loss-versus-time curves for UO₂ heated in vacuum showed that at the higher temperatures weight loss was linear with time, as was to be expected since the samples were designed to keep surface area change to a minimum. Some spread in data was experienced at lower temperatures, and this has been attributed to the magnitude of experimental errors relative to the very small weight changes involved. Samples of considerably larger surface areas have been prepared to check the lower temperature data.

A preliminary evaporation rate curve is shown in Figure 11. Additional samples are in process to fill in this curve more completely.

(ii) Plutonium Ceramics and US. A high-temperature vacuum microbalance apparatus is being constructed for evaporation experiments. Another apparatus is being set up for the determination of oxidation rates by gas-chromatographic analysis.

Preliminary oxidation experiments have begun with uranium monosulfide, however, rather than with a plutonium compound. The objective of these experiments is to fill the gaps in existing data and to check the performance of the oxidation apparatus before it is committed

to plutonium use. The present experimental runs are concerned with establishing suitable operating conditions, including the most desirable ranges of temperature and oxygen partial pressure.

A sintered US pellet of about 90% of theoretical density was oxidized for one hour at 700°C in an atmosphere of helium containing 0.1% oxygen. Inspection of the reacted specimen showed that a compact, adherent product layer had formed. Measurements of the reacted specimen indicated that a linear expansion of 1% and weight gain of 1.1% accompanied oxidation. Microscopic examination showed that the product layer consisted of several sublayers of distinctly different appearance. Work is in progress on the X-ray and microscopic identification of the various product phases.

e. Anelasticity of Some Uranium Compounds. Attempts to oxidize specimens of uranium dioxide have been continued. A sintered sample of UO_2 , weighing 5.3641 gm, and green pellets of U_3O_8 , weighing 2.4259 gm, were placed in a quartz tube and sealed in argon at a pressure of 500 mm Hg. The capsule was heated at 1150°C for 140 hr and cooled very slowly. Stoichiometric determination, performed with part of the sample, gave an O/U ratio of 2.07. Metallographic examination seems to indicate the presence of a second phase. X-ray results have not been analyzed yet.

The rest of the specimen was sealed again in argon at a pressure of 500 mm Hg and annealed at 1150°C for 60 hr in order to get a higher degree of homogeneity. The capsule was cooled from 1150°C to 550°C in 3 hr and then removed from the furnace. The O/U ratio was 2.04. Metallographic and X-ray studies will be performed.

The preparation of the samples for the study of the effect of grain size on Young's modulus and on internal friction has been continued. Repeated heat treatment of the samples has permitted the obtaining of a wide range of grain sizes without affecting the density. Metallographic examinations indicate that the heat treatment produced a migration of the pores from the center of a grain toward the grain boundary. The number of pores was reduced but, as they became larger, the total porosity remained the same.

2. Irradiations of Refractory Ceramic Fuel Materials

Various refractory ceramic compounds of uranium and plutonium are being irradiated to determine their feasibility as high-temperature reactor fuel materials. Jacketed specimens of the compounds are being irradiated over a range of burnups and temperatures to test their behavior with respect to swelling, fission-gas release, microstructural changes, and behavior with various jacketing materials.

Four instrumented, temperature-controlled capsules containing six specimens each have been under irradiation in the MTR. Capsule ANL-56-7 with four specimens of vibratorily compacted physically mixed powders of UC-20 w/o PuC and two specimens of vibratorily compacted PuC powder was removed from the reactor. The fuel is jacketed in 0.23-mm-thick Nb-1 w/o Zr or in Type 304 stainless steel. The fuel diameter is 3.9 mm. These specimens have operated at cladding surface temperatures from 510 to 650°C. The estimated burnup ranges from 1.4×10^{21} to 1.8×10^{21} fiss/cc (5.5 to 6.8 a/o) for all specimens. The postirradiation examination will begin in the near future.

Capsule ANL-56-8 contains four specimens of pressed and sintered US pellets and two specimens of vibratorily compacted physically mixed powders of UC-20 w/o PuC. The specimens are jacketed with 0.31-mm Nb-1 w/o Zr, and a helium annulus exists between the clad and the 6.4-mm-diameter fuel. The specimens have achieved an estimated maximum burnup of 7.2×10^{20} fiss/cc at jacket surface temperatures from 535 to 650°C. The capsule has been moved to a new reactor position to reach jacket temperatures of 750 to 800°C for the remainder of the irradiation period. Target burnup is 2.2×10^{21} fiss/cc in the sulfide specimens (10 a/o of the U), or 2.6×10^{21} fiss/cc in the carbide specimens.

Capsule ANL-56-9 contains an identical loading as capsule ANL-56-8. Present jacket surface temperatures range from 480 to 700°C. Loss of all but one thermocouple will necessitate the removal of this capsule at half its intended burnup of 2.2×10^{21} fiss/cc. The present maximum burnup is 5.4×10^{20} fiss/cc.

Capsule ANL-56-11 also contains a specimen loading identical to capsule ANL-56-8. The intended burnup is 2.2×10^{21} fiss/cc in the sulfide at cladding surface temperatures between 600-650°C. The specimens have achieved a maximum burnup of 4.1×10^{20} fiss/cc at temperatures within the desired range.

3. Plated Coating as a Deterrent to Oxidation of Refractory Metal

Testing of the six samples of nickel-plated refractory metal (see Progress Report for February 1965, ANL-7017, p. 55) was continued. After 14 cycles at 1500°F, only one sample, as-plated, negatively etched, showed flaking after the first cycle. The temperature of the furnace was then raised. Results so far are as follows:

Cycle 15, at 1700°F - 5 samples - intact

Cycle 16, at 1820°F - 5 samples - intact

Cycle 17, at 1920°F - 5 samples - intact

Cycle 18, at 1940°F - Samples 1, 3, and 5, which had been negatively etched, showed cracking and peeling of the outer (nickel) coat, but no apparent attack on the base metal in those areas made visible by flaking. Samples 2, 4, and 6 (positively etched) showed no flaking or peeling.

Cycle 19, at 2000°F - The remaining samples, 2, 4, and 6, started to peel.

Cycle 20, at 2000°F - All samples showed continued peeling of outside coat, but base metal appears intact.

D. Other Reactor Fuels and Materials Development

1. Nondestructive Testing

a. Determination of Elastic Moduli of High-temperature Materials by Ultrasonics. The object of this program is to measure the temperature dependence of the elastic moduli of materials that show promise in high-temperature reactor applications. To obtain these data a vacuum furnace has been constructed in which solid bar-shaped samples will be mounted. Pulsed ultrasonic waves will be propagated along the length of these samples, and the transit times of pulses passing a heated, indexed region in each bar will be measured. The indexing is done by machining one end to a smaller diameter than the rest of the bar.

The velocity of sound in the indexed region can be calculated from the length of this region and the transit time in it. Both shear-wave and longitudinal velocities are determined. Any of the elastic moduli, e.g., Young's modulus, Poisson's ratio, and shear modulus, can be determined if the sound velocities are known.

A new heating element was made for use in the furnace. The element is 6.3×10^{-3} -mm-thick tantalum foil and designed to surround the rod samples almost completely over a length of around 10 cm. It was hoped that the thermal gradient in the index region might be reduced by use of this sheet heater, but temperature differences as great as 13°C may still be found in the specimen under certain conditions. The new heating element is advantageous in that significantly higher temperatures may be reached with a given power input as compared with the old heater. Work on the gradient problem continues.

A tungsten bar has been machined to the proper dimensions for ultrasound measurements. After these are made, the bar will be put into a modified high-temperature furnace to see at how high a temperature measurements of this type can actually be made.

b. Ultrasonic Field Visualization. A final report on the imaging system is in preparation.

One of the more significant aspects of the report concerns the utility of the imaging system for inspecting flat fuel elements. The excellent sensitivity of the system for detecting variations in such objects was demonstrated. This capability, combined with the excellent resolution and speed of the television system, are very useful features which permit the system to be used for inspection of relatively thin, flat materials. These capabilities may be particularly useful for the inspection of the fuel plates now being considered for the AARR.

c. Development of a Neutron-image Intensification System. The video tape recorder used in the postirradiation annealing study (see Progress Report for February 1965, ANL-7017, pp. 57-58) was tested to ascertain the reason for recordings of fair to poor quality obtained during the annealing run. Manufacturer representatives determined that several internal settings on the recorder were not correct. This eliminated some speculation that the vidicon television camera in the neutron-imaging system was not compatible with the tape recorder. Arrangements were made to use a tape recorder again during a future annealing study.

The optical components needed to improve the speed of the optical system between the image intensifier and the vidicon television camera have been received and evaluated in an optical bench test. A magnification of about 1:1 will provide the best situation for the useful vidicon scanned area. The two lenses and mirror in the system will improve the speed of the optics over that of the present $f/1.4$ system and, in addition, will permit the television camera to be moved out of the neutron beam. The mechanical components needed for the optical system are now being assembled.

d. Suppression and Reduction of Noise in Electromagnetic Test Systems. The problem of noise in general is the chief factor limiting the application of electromagnetic test systems to many problems in non-destructive testing that a superficial consideration might indicate could best be solved by an electromagnetic method. Noise itself has been defined as "signals that are not coherent with any signals to which meaning is assigned in any transmission system."¹⁷ This noise can, for the purposes of this study, be divided into two broad classifications: (i) System noise, and (ii) Test specimen noise.

The term "system noise" is intended to cover all noise that arises within the test system, such as shot noise, Johnson noise, partition noise, and flicker (f^{-1}) noise. Most of these types of noise are wideband in nature. For this type of noise, the noise power output of the system, dP , referred to the input, is given by

$$dP = FkTp(f)df,$$

¹⁷Goldman, S., Information Theory, Prentice-Hall, Inc., New York (1953), p. 123.

where

F = the system noise figure;

k = Boltzmann's constant;

T = absolute temperature;

$p(f)$ = the Planck factor, which is equal to unity in the frequency and temperature ranges under consideration;

df = differential of frequency.

A pulse $G(t)$ which is zero everywhere except in the interval $T_1 < t < T_2$ possesses a frequency spectrum $\Omega(\omega)$ that is continuous:

$$\Omega(\omega) = \int_{-\infty}^{+\infty} G(t) e^{-j\omega t} dt.$$

In practice, a relatively wide bandwidth is required to transmit such a pulse with reasonable fidelity. Obviously, the narrow-band electromagnetic test systems possess a considerable advantage over the pulsed systems in freedom from the problems of wideband noise.

The second broad classification of noise in electromagnetic test systems has been termed test-specimen noise. This does not refer to the thermal noise reflected into the test system pickup by the apparent increase in resistance caused by the test specimen while it is in motion and under test. This noise is caused by a variety of effects, often poorly understood, but including variations in test specimen geometry, permeability, or resistivity which do not affect its serviceability, as well as vibration of and stray fields about the pickup. This noise is usually neither truly random nor ergodic.

It may seem that there exists superficially very little relationship between these two broad classifications of noise. Unfortunately, the measures taken to suppress the effects of the second type of noise often have the effect of increasing the effect of the first type of noise. For example, the wideband test systems developed at Argonne have been relatively successful in suppressing type-ii noise encountered in the testing of metallic tubing (actually this was accomplished by increasing the system signal-to-type-ii noise ratio), but type-i noise has increased in importance owing to the increased bandwidth. In these systems, further improvements could be expected in the suppression of type-ii noise if type-i noise could first be reduced. As another example, in narrow band systems, type-ii noise has often been suppressed by the use of another separate frequency channel, thus increasing the effect of type-i noise.

Since in any generalized transmission system the overall signal-to-noise ratio governs the ultimate sensitivity, both types of noise should be considered together, particularly in broadband systems. Most efforts to increase the S/N ratio in broadband systems have been directed toward increasing the signal rather than decreasing the noise. The approach to noise suppression has been very empirical and very pragmatic. A strong possibility exists that better performance and increased application can be obtained from existing electromagnetic test systems as a result of improvements suggested by the systematic study of the sources of type-i noise, and the characteristics of type-ii noise now in progress.

e. Infrared Imaging. A chopping mechanism for use with point detectors has been assembled and mounted, and provides a chopping rate of about 2400 cps. The tuned amplifier for use with the output from the detector assembly is under construction.

f. Thermal Conductivity of Irradiated Metallic Fuel as a Function of Burnup. The thermal-pulse method of measuring thermal diffusivity and conductivity is being utilized to determine the thermal properties of irradiated fuel pins as a function of burnup. This method will enable the diffusivity and conductivity to be measured in both the axial and radial directions at many points along the fuel pin, and thus will indicate any anisotropy in the thermal properties as well as any variation of these properties in the axial and radial directions along the length of the fuel pin.

A room-temperature setup suitable for remote operation has been completed, but has not as yet been installed in the cave. Transverse specimens (0.366 cm in diameter and 0.102 cm thick) for axial measurements and longitudinal sections (0.366 cm square and 0.102 cm thick) have been made from unirradiated fuel pins for the following alloys:

U-5 w/o Fs	(10% enriched)
U-10 w/o Fs	(10% enriched)
U-15 w/o Fe	(10% enriched)
U-5 w/o F	(20% enriched).

Room-temperature measurements on these alloys are now in progress. These measurements on the unirradiated fuel pins are necessary as the pins contain a larger percentage of zirconium, and consequently have higher conductivity values, than that given for the alloys.

g. Radiography of Irradiation Capsules and Fuel Plates. Gamma-ray radiography was employed in examining six TREAT irradiation capsules. Three capsules were radiographed after irradiation; the remaining capsules were radiographed prior to irradiation. Significant defects were noted in the fuel pins of the postirradiated capsules, including a ruptured fuel pin and an indication of voids. Radiographs of the preirradiated capsules revealed a slanted pin and a fuel pin void.

E. Engineering Development

1. Two-phase Flow

a. Void Fraction - Pressure-drop Facility. This experimental facility is designed to investigate the two-phase flow characteristics of boiling sodium. In particular, it is desired to obtain experimental information pertinent to the vapor volume fraction and two-phase frictional losses in an adiabatic test section.

After repairing the condenser (see Progress Report for February 1965, ANL-7017, pp. 58-9), the loop was heated to 1500°F under a pressure of one atmosphere. During heating two plugs occurred, one in the Venturi manometer line and one in the main loop, the latter stopping flow completely and allowing the maximum boiler temperature to reach 1700°F. Further heating dissolved the plug.

A boiling run was made at 1500°F by slowly decreasing loop pressure to approximately 7 psia. Following this, a failure occurred at the upper test-section pressure tap, most probably another thermal stress failure. The sodium was dumped and the loop shut down for repairs. The sodium was contaminated during condenser repair, and several flushing operations with clean sodium will be effected before the next series of tests.

Previously collected quantitative data is being evaluated.

2. Boiling Liquid Metal Technology

a. Niobium-1% Zirconium Loop. This facility is designed to investigate the heat transfer and two-phase flow characteristics of boiling sodium approaching a temperature of 2100°F, and a pressure of approximately 8 atmospheres. Among the variables to be investigated are boiling heat flux and temperature difference up to the critical heat flux occurrence, boiling and adiabatic two-phase pressure drop, vapor volume fraction, boiling stability parameters, and possibly flow pattern regimes.

The Nb-1% Zr loop design and construction procedure have been reviewed with members of Pratt & Whitney-CANEL staff. To date, no vendor has been willing to undertake fabrication of the boiler section.

Extrusion is still a possibility, but would prove to be very expensive. Some tentative design revisions have been proposed, and an alternate will be selected if the original design proves unfeasible. The remaining loop components are being procured, and the overall schedule is still in force.

The loop support structure, heater, and preheater units are 80% complete. Materials required for the experimental shutter assembly have been received, and the forming of the corrugated sections has begun. Nb-1% Zr insulating foil and heavier sections for instrumentation hook-up have been received.

The fabrication of the differential pressure transducers is nearly complete, and the electronic components will be received shortly. The 300°F transducer oven is being fabricated. Design of the flowmeter cooling system is complete; the system is being fabricated. Nb-1% Zr-sheathed, chromel-alumel thermocouple assemblies have been ordered, and the higher-temperature assemblies (W5Re-W26Re) will be ordered as soon as vendor information is complete; the selection of the latter has been delayed because of the stringent specifications required for successful 2500-hr operation and thermal cycling.

Investigation is underway to determine the applicability of an automatic data-collection and processing system, which would be purchased for initial use with the boiling sodium system and would be available for general application to experimental heat transfer and fluid flow facilities.

Installation of the vacuum chamber and associated equipment is continuing. The cooling water systems have been tied to the canal water line which has been thoroughly flushed. Water leaks in the supply manifold have been corrected and the cooling water flow switches have been checked out. A permanent vacuum line to the leak detector has been constructed and the detector is operational. Flange covers and gaskets on the chamber have been disassembled, cleaned and replaced in preparation for leak checking. The 110-V systems for receptacle power and control power have been brought into service and the rotary pump operated to evacuate the seal vacuum system. Leadwires for all the vacuum instrumentation have been prepared and installed. Several of liquid nitrogen storage tanks and some of the hardware for the associated supply manifold have been received. Design work for installation of the sodium pump is in progress. Properly sized switchgear and instrumentation for the pump and blower have been obtained, as has some of the supporting hardware for the pump stator.

b. Heater Experiments

(i) Thermal Radiation Heater Experiment. Experience derived from this study has determined the design to be used in the Nb-1% Zr facility. The facility fabrication is 80% complete.

(ii) Electron Bombardment Heater. This experiment is designed to investigate the use of electron bombardment as a means of supplying high uniform heat fluxes to high temperature liquid metal systems; this small facility will also supply basic information concerning pool boiling from a

cylindrical surface. All equipment has been received and installed, and the initial checkout of the system is underway.

c. Boiling Liquid Metal Research Survey. A study is currently underway to update background material necessary for the interpretation of data acquired from the Nb-1% Zr facility. An application of this information will be made to the design of the automatic data-recording and analyzing system.

3. General Heat Transfer

a. Heat Transfer in Double-pipe Heat Exchanger

(i) Liquid Metal Cocurrent Turbulent Flow. The long (length-to-diameter ratio of 20) test section has been installed in the loop after being reworked to reduce heat conduction across the endplates. The thermocouples used to measure the exit bulk fluid temperatures were relocated in order to obtain a more representative value of bulk temperatures. The relocation lowered average heat-balance errors in the test section from 8% to 4%. Recent replacement of an inlet end thermocouple is expected to lower the errors even further.

As mentioned previously (see Progress Report for February 1965, ANL-7017, p. 61), the heat-exchanger analysis suggests a procedure for determining the local overall heat transfer coefficient when the heat transfer is fully developed. The outside wall temperatures, expressed in suitable dimensionless form, are plotted versus heat exchanger length on semilog paper. When the heat transfer is fully developed, the plot becomes a straight line, the slope of which is proportional to the fully developed overall heat transfer coefficient. A plot of this kind is illustrated in Figure 12 for an actual experiment with Peclet numbers of about 100 in both

Figure 12

Outside Wall Temperature Distribution vs. Heat Exchanger Length from Actual Experiment (Peclet Numbers ≈ 100 for Both Sides of Exchanger)

channels. The local heat flux at the outlet of the exchanger can be calculated from the outlet bulk fluid temperatures after the local overall heat transfer coefficient is known.

A single thermocouple inbedded in the tube wall at the outlet is used to obtain a wall temperature at a known radial location. Since the nickel wall has a high thermal conductivity and is relatively thin, the temperature drop through the wall is small; hence, the location of the thermocouple need not be known very accurately. With the local heat flux known, the individual channel surface temperatures and local heat transfer coefficients are easily calculated. Operation at Peclet numbers of 100 in the annulus and low flow rates in the tube has yielded local heat transfer coefficients within 10% of those predicted by the detailed heat-exchanger analysis. In particular, coefficients for the annulus side have been obtained which are significantly lower than those obtained with boundary conditions involving constant surface temperature. Very recent tests with higher flow rates in the tube have not been as successful, however, and are being studied further.

After completion of tests with the long test section, the short test section, reworked to eliminate heat conduction along the end plates, will be installed for further tests.

(ii) Countercurrent Flow. It was reported previously (see Progress Report for October 1964, ANL-6965, p. 68) that researchers at Syracuse University had obtained formal analytical solutions for a special case of the countercurrent-flow heat exchanger, and that these solutions, although less general, are nearly equivalent to those obtained at Argonne. Both involve difficulties in theory and application which appear to be at least unusual, if not unique, in the field of applied mathematics.

Nunge and Gill of Syracuse University have published¹⁸ computations based on their solutions and have compared them with computations based on finite-difference techniques applied directly to the appropriate problem in differential-equation form. The results of these computations clearly indicate that applications of the formal analytical solutions are practical.

During the past few months collaboration between Nunge and Gill, and Stein of Argonne, has resulted in a very general formulation of appropriate analytical solutions to countercurrent-flow heat- and mass-transfer problems. Detailed computations have been performed at Syracuse for laminar flow in parallel plane exchangers, and have been reported in a joint paper recently submitted for publication.¹⁹ Computations at ANL related to turbulent liquid metal flow in concentric tube exchangers will begin shortly.

¹⁸Nunge, R. J., and Gill, W. N., Analysis of Heat and Mass Transfer in Some Countercurrent Flows, Paper submitted to Int. J. Heat and Mass Transfer, Sept 1964. Accepted for publication Dec 1964.

¹⁹Nunge, R. J., Gill, W. N., and Stein, R. P., Analysis of a Counterflow Parallel Plate Heat Exchanger, Paper submitted to Int. J. Heat and Mass Transfer, March 1965.

(iii) Cocurrent Laminar Flow. As reported previously (see Progress Report for August, 1964, ANL-6936, p. 61), a previous analysis of the cocurrent laminar flow in a concentric tube heat exchanger has been extended and formulated for solution by an analog computer. Results obtained previously by digital computation have now been satisfactorily reproduced by the analog, and the more extensive and general analog computations are about to begin.

A newly incorporated feature of the computations involves the simultaneous use of both the analog computer and a digital machine. The latter will perform most of the arithmetical operations and store pertinent results for later tabulation. The necessary hardware for successful operation of this type of so-called "hybrid" machine computation is relatively new at ANL, and the heat-exchanger problem will be one of the first detailed applications.

The results of these computations will consist of the information required for convenient and accurate predictions of overall heat transfer in cocurrent laminar-flow heat exchangers over wide ranges of operating conditions. This type of information does not appear to be presently available.

b. Selected Topics Related to Liquid Metal Heat Transfer. A draft of a chapter on Liquid Metal Heat Transfer has been completed for publication in "Advances in Heat Transfer," Vol. III, (T. F. Irvine and J. P. Hartnett, eds.), Academic Press, New York. The chapter covers such topics as Liquid Metal Heat Transfer-Research in General; Turbulent Convection-General Considerations; Convection in Ducts with Specified Heat Flux and concluding with Heat Exchangers.

4. ANL-AMU Program

Other heat engineering experiments, performed as part of a joint program (not supported by the Division of Reactor Development and Technology) between the Laboratory and the Associated Midwest Universities (AMU), are described below.

a. Two-phase Flow Characteristics during the Complete Vaporization of a Fluid. A series of tests being conducted in the Freon loop was interrupted by decomposition of the Freon which occurred during high-heat-flux operation when an air-pressure failure caused a closing of a valve at the exit of the test section. The heated section did not fracture, although the section underwent some bending and a resistance change was noted. This unit was replaced and tests have been continued after the system was cleaned. A further delay in testing occurred when the overpressure safety discs failed due to pitting, and subsequent pinhole fractures dumped the Freon charge. The destruction of these discs appears to have originated on the atmosphere side of the discs.

The tests have proceeded to the third test-pressure level. Evaluation of the void fraction and pressure-drop data has not been completed for the two lower test pressures. At the present time, a comparison with the results of Griffith²⁰ for two pressures of the transition from slug to annular flow, indicates that there is an apparent agreement between the demarcation of the two flow regions on the basis of superficial velocity of the liquid and vapor. However, it would appear that there is a difference in the quality at which this transition occurs.

The visual test section through which photographic views of the flow patterns are to be made has been nearly completed in the reassembly process. Color movies of the flow regimes will then be available for comparison with the visual results of the X-ray and fluoroscope examination.

b. Heat Transfer Instabilities near the Thermodynamic Critical Point. Heat transfer instabilities which occur during the transfer of heat to a fluid at a supercritical pressure have been investigated in a heat transfer loop designed to operate by either natural or forced convection. Dichlorotetrafluoroethane (critical temperature, 294.26°F; critical pressure, 473.18 psia) was employed as the coolant.

When the wall temperature exceeded 600-700°F, a chemical reaction was started or accelerated on the heater wall. If allowed to continue, a deposit would build up on the heater wall so that the outside wall temperatures would be 200°F higher than their former values. The deposit was of uneven thickness, resulting in unusual wall-temperature profiles. When the test section was thoroughly cleaned with a wire brush and alcohol, the loop reverted to its original behavior. The reaction limited the electrical heating power to about 9 kW.

An interesting result was obtained when this limit was exceeded briefly. A forced-convection run at 8-kW power and 5-gpm flow rate was started. This flow rate should have resulted in a lower wall temperature than during a similar natural convection run. With bulk temperatures less than 200°F (94°F below the critical) and wall temperatures of about 400°F, a hot spot developed at the test section exit. The wall temperature increased to greater than 600°F at the top thermocouple. As the bulk temperature was raised slowly, the hot spot moved down the section, affecting one thermocouple at a time. This experiment was repeated three times with similar results, although the wall-temperature level gradually rose as the tests progressed, indicating that the deposit was building up in the test section. This indicated that a chemical reaction was responsible for the anomalous behavior. Similar results were observed for oxygen at

²⁰Griffith, P., The Slug-Annular Flow Regime Transition at Elevated Pressure, ANL-6796 (Nov 1963)

supercritical pressures,²¹ for which a wall temperature increase from 400°R to 2000°R occurred over a small axial distance in the heated section.

F. Chemical Separations

1. Fluidization and Volatility Processes

a. Recovery of Uranium from Low-enrichment Ceramic Fuels

(i) Laboratory Support Work. An experimental program has been started to evaluate the use of bromine pentafluoride (BrF_5) as a selective fluorinating agent for uranium-plutonium fuel materials. It is expected that fluorination of uranium-plutonium oxide mixtures with BrF_5 will result in the conversion of uranium to volatile UF_6 with the concomitant reduction of BrF_5 to bromine trifluoride (BrF_3) while plutonium is converted to nonvolatile PuF_4 . Plutonium would be recovered as PuF_6 in a subsequent step by fluorination of PuF_4 with fluorine. Some potential advantages of the BrF_5 fluorination scheme over the procedure involving the direct fluorination of both uranium and plutonium compounds with fluorine are: (1) possibly shorter overall plutonium-fluorination time, if plutonium as PuF_4 can be allowed to accumulate in the fluid bed from several batches of feed before recovery by reaction with fluorine; (2) the conversion of PuF_6 to PuF_4 (by thermal decomposition of PuF_6 or by chemical reduction) could be performed in the absence of UF_6 ; (3) purification and decontamination of UF_6 would be simplified in the absence of PuF_6 ; and (4) collection of the UF_6 product in a liquid mixture of BrF_5 and BrF_3 may be more efficient than collection of the UF_6 by condensation as a solid from a gas phase of fluorine and nitrogen.

Preliminary data have been obtained on the rates of reaction of uranyl fluoride (UO_2F_2) and UF_4 with BrF_5 in the temperature range from 175 to 300°C. Experiments were performed in a horizontal tubular reactor with a gas containing 20 v/o BrF_5 in nitrogen at a linear velocity of 0.04 ft/sec. The fluorination rates ranged from 42 to 248 mg U/min for UO_2F_2 , and from 3 to 197 mg U/min for UF_4 . These rates, which are believed to be adequate for process application, will be compared with the rates for fluorine gas in later experiments. Apparent activation energies of 8 and 17 kcal/mole were calculated for UO_2F_2 and UF_4 , respectively.

Several tests were performed to evaluate suitable methods for disposal of excess BrF_5 from laboratory experiments. Tests with activated alumina as a disposal agent showed that, although BrF_5 reacted with the alumina, the bromine product was only absorbed by the alumina but did not react with it. This behavior suggests that activated alumina would not

²¹Powell, W. B., Heat Transfer to Fluids in the Region of the Critical Temperature, Jet Propulsion, 27, 776-783 (July 1957).

be a suitable disposal agent for BrF_5 . Soda lime appeared to be a satisfactory material for disposal of BrF_5 , since the material completely reacted with the soda lime. To assure complete reaction of the bromine, the bed of soda lime must be heated to a temperature above 100°C .

(ii) Decladding and Fluorination. Development studies on the decladding and fluorination of UO_2 fuels have continued in a $1\frac{1}{2}$ -in.-dia nickel fluid-bed reactor. Zircaloy-clad or stainless steel-clad UO_2 fuel elements may be chemically declad by the high-temperature reaction of the cladding with a gaseous mixture of HF-O_2 (see Progress Report for September 1964, ANL-6944, pp. 69-70). The cladding is converted primarily to nonvolatile oxides during this reaction. During the decladding step, the oxide fuel reacts with the decladding agent to form a powdered mixture of UO_2F_2 and UF_4 . This material is then fluorinated with fluorine gas to recover uranium as the volatile hexafluoride.

Decladding of stainless steel-clad fuel is carried out at 550°C with a gaseous mixture of 40 v/o HF , 40 v/o O_2 , and 20 v/o N_2 . During the decladding step, the stainless steel is converted to oxide, which appears in the form of a scaly material. No volatilization of iron and chromium has been observed during the decladding step.

The extent of chromium volatilization during the fluorination step was observed in a test involving the processing of uranium dioxide-stainless steel cermet fuel (see Progress Report for January 1965, ANL-7003, p. 60). In this test a three-step fluorination procedure was employed: 3.3 hr at 250°C while the fluorine concentration in the feed gas was increased from 5 to 90 v/o; 4 hr with 90 v/o F_2 in nitrogen while the bed temperature was increased from 250 to 550°C ; and 1.0 hr at 550°C using 95 v/o F_2 . Approximately 45% of the chromium in the cermet fuel volatilized during the fluorination, whereas the iron was totally retained in the fluid-bed reactor. The chromium that had not volatilized and the iron were converted to very fine particulate fluoride during the fluorination step. The course of uranium and chromium volatilization during the three-step fluorination procedure was followed by measuring the quantity of the volatile materials recovered in refrigerated condensers during each step. The data are shown in Table X.

Table X. Course of Uranium and Chromium Volatilization during Processing of UO_2 -Stainless Steel Cermet Fuel

Time (hr)	Temperature ($^\circ\text{C}$)	Fluorine Concentration (v/o)	Uranium Recovered (% of total recovered)	Chromium Recovered (% of total recovered)
3.3	250	5-90	89	21
4.0	250-550	90	10	52
1.0	550	95	1	27

During the fluorination, 99.4% of the uranium in the fuel charge was recovered as UF_6 in the condensers. It is expected that separation of chromium from the UF_6 product can be performed without difficulty.

Zircaloy-2 cladding can be destructively oxidized by contact with gaseous mixtures of HF and oxygen at a temperature of 550°C . To determine if selective volatilization of any of the constituents of Zircaloy-2 occurs during oxidation, the relative concentrations of zirconium, tin, iron, and chromium in the scaly oxide product and in the parent metal were measured by an electron probe microanalyzer. Since the relative concentrations of all constituents were the same in both the oxide product and the parent metal, no selective volatilization of any constituent occurs during the destructive oxidation of Zircaloy-2.

Preliminary data on the corrosion of nickel-200 (a proposed material of construction for fluid-bed reactors) in gaseous mixtures of HF, oxygen, and nitrogen have been obtained by measurement of weight gains of corrosion specimens suspended in the fluid-bed reactor. The specimens, 1-in.-long sections of 1/4-in.-dia nickel-200 tubing, were exposed to 40 v/o HF, 40 v/o O_2 , and 20 v/o N_2 for 21 hr at temperatures between 500 and 600°C . During the testing period the specimens were thermally cycled several times between room temperature and processing temperature. The average corrosion rates, based on weight gain, were 8.8 mils/year for specimens in the disengaging section of the fluid-bed reactor, and 17.5 mils/year for specimens immersed in the fluidized bed of alumina particles. These data indicate that nickel-200 is a likely candidate for use in HF-O_2 environments.

(iii) Engineering-scale Alpha Facility. An engineering-scale alpha facility (see Progress Report for January 1965, ANL-7003, p. 59) is being installed to permit demonstration of the major steps of the fluid-bed fluoride volatility process for the recovery of uranium and plutonium from ceramic oxide fuels. Equipment units for processing batches of $\text{UO}_2\text{-PuO}_2$ pellets to hexafluorides and for demonstrating the conversion of hexafluorides to oxides have been installed in the facility. Design work on a distillation unit for purifying and separating the UF_6 and $\text{UF}_6\text{-PuF}_6$ product streams is under way.

Preliminary testing of the equipment for the conversion of hexafluorides to oxides has commenced. The entire converter system was satisfactorily tested by processing a 1.6-kg batch of UF_6 to UO_2 in the 2-in.-dia fluid-bed converter.

A preliminary test of the hydrogen fluoride system (see ANL-7003, p. 59) for use with the 3-in.-dia fluorinator was completely satisfactory.

b. Recovery of Uranium from Highly Enriched Uranium Alloy Fuels

(i) Corrosion Studies in Pilot-plant Demonstration Runs. Final evaluation has been made of the corrosion specimens inserted in the pilot-plant equipment used to demonstrate the recovery of uranium from multiplate assemblies of uranium alloy fuels by means of the fluid-bed fluoride volatility process. During the pilot-plant program a total of 18 runs were made in which 24 multiplate fuel assemblies were processed. A description of the processing conditions and the results of recent runs were reported previously (see Progress Report for December 1964, ANL-6997, pp. 41-45). A summary of the recommended materials of construction based on pilot-plant corrosion data is presented in Table XI.

Table XI. Materials of Construction for the Processing of Uranium-Alloy Fuels

	Corrosive Environment	Suitable Materials
Halogenation Reactor and Packed-bed Filter	HCl, ZrCl ₄ , AlCl ₃ , H ₂ , HF, F ₂ , UF ₆	Nickel 200 or 201
Pyrohydrolyser	HCl, ZrCl ₄ , AlCl ₃ , H ₂ , H ₂ O	Stainless Steel or Inconel
Pyrohydrolyser Filters	HCl, H ₂ O, H ₂	Nickel or Inconel
Process Piping	Dry HCl	Stainless Steel
Process Piping	HF, F ₂	Monel or Nickel
Process Piping	HCl, ZrCl ₄ , AlCl ₃ , H ₂ , HF, F ₂ , UF ₆	Nickel 200 or 201
Process Piping	Wet HCl above condensation point	Stainless Steel or Inconel

Nickel-200 and nickel-201 welded and unwelded corrosion specimens in the primary fluid-bed reactor showed corrosion rates ranging from 0.08 to 0.12 mil/day (24 hr) in the fluidized bed and from 0.03 to 0.09 mil/day in the region above the fluidized bed. The higher corrosion rates observed on specimens in the fluidized bed are attributed to the removal of the protective fluoride film by the action of the fluid-bed particles.

Corrosion rates of less than 0.04 mil/day in the pyrohydrolysis reactor were exhibited by 304 and 347 stainless steel and Inconel-600. There was no marked difference in the corrosion behavior of these

materials whether immersed in the fluidized bed or suspended above the fluid bed. Both Inconel and nickel sintered metal filters were entirely satisfactory for use in the $\text{HCl-H}_2\text{O-H}_2$ off-gas from HCl pyrohydrolysis reactor; sintered stainless steel filters were not evaluated in this program.

(ii) Bench-scale Fluid-bed Studies of Irradiated Fuels. The fluid-bed hydrochlorination-fluorination process is being studied in a bench-scale high-activity-level facility with highly irradiated uranium-Zircaloy or uranium-aluminum alloy fuel materials. The facility consists of a $1\frac{1}{2}$ -in.-dia fluid-bed reactor and a packed-bed filter with associated equipment for the containment of volatile chlorides and uranium hexafluoride produced in the process (see Progress Report for May 1964, ANL-6904, pp. 89-90). Volatile zirconium tetrachloride or aluminum trichloride produced by reaction of the fuel alloy with hydrogen chloride is condensed to a solid chloride and disposed by dissolution in dilute hydrochloric acid. The uranium hexafluoride produced by reaction of uranium trichloride with fluorine is decontaminated by a sorption-desorption operation in a series of four sodium fluoride traps maintained at temperatures between 20 and 400°C . The hexafluoride product is subsequently collected in a series of refrigerated traps.

Data on uranium decontamination and fission product distribution have been obtained from two runs in which 269 g of long-cooled irradiated uranium-Zircaloy-2 alloy were processed in each run. The alloy used in these runs contained 4.92 g uranium and 3.28 g fission products (40% burnup), and was cooled for 5 yr. The original uranium enrichment was 93%.

Values of uranium recoveries and losses were compared with those obtained in runs with unirradiated alloy fuel. It appears that the behavior of uranium in both cases was essentially the same and that the presence of fission products had no marked effect on uranium recovery or loss.

Measurements of fission product activity after the hydrochlorination step indicate that cesium, cerium, ruthenium, and strontium are nonvolatile during hydrochlorination. A small amount of these activities, however, are entrained and deposited along with ZrCl_4 in the condenser.

An examination of the fission product distribution following the fluorination step shows that the bulk of the activities of cesium, cerium, ruthenium, and strontium remain in the reactor and packed-bed filter. Some entrainment of these materials had occurred, since cesium and strontium were found in all the sodium fluoride traps. Antimony was found in the 400°C sodium fluoride trap in quantities too large to be accounted for by an entrainment mechanism. Of the total amount of antimony found, about half

remained in the reactor and filter; the rest apparently volatilized and was sorbed by the first sodium fluoride trap. Molybdenum and technetium were nearly completely removed from the reactor and filter beds during the fluorination step. Both accompanied uranium and were collected with the uranium in the 100°C sodium fluoride trap.

The decontamination factor for uranium, from the principal fission product activities, calculated from activities in the 100°C sodium fluoride trap, was about 1×10^4 . Contamination of the product by gamma-active isotopes appears to have been mainly due to entrainment. Preliminary data indicate that higher decontamination can be obtained by incorporating a product desorption step in which the UF_6 is desorbed from the sodium fluoride traps and passed through a sintered metal filter prior to collection in refrigerated condensers.

Studies currently under way in this facility include experiments with irradiated uranium-aluminum alloy fuels and both unirradiated and irradiated uranium dioxide fuels.

2. Chemical-Metallurgical Process Studies

a. Chemistry of Liquid Metals

(i) Sodium Purification. Methods are being sought for the removal of carbon impurities present at the ppm level in sodium. At the same time, investigation of the nature of the carbon-containing species in sodium is under way.

An attempt to decarbonize sodium by vacuum distillation and passage of the vapor through a stainless steel frit (of 10- μ porosity and 3/32 in. thick) was unsuccessful in that not enough sodium passed through the frit to permit analysis of the condensate. This poor recovery is in contrast with a similar previous experiment (see Progress Report for February 1965, ANL-7017, p. 70) in which a glass frit (of 10- to 15- μ porosity) was used.

The efficacy of soluble and solid metal getters for removal of carbon from liquid sodium was tested in two preliminary experiments. Dissolution of calcium in liquid sodium was shown both experimentally and thermodynamically to be ineffective for removing carbon. Exposure of liquid sodium to a Zr-15 w/o Ti foil at 600°C gave results which were inconclusive. Further work with getter materials is planned.

Past studies have shown that vacuum distillation of nominally pure sodium does not completely eliminate carbon impurities (e.g., see Progress Reports for February 1965, ANL-7017, p. 70, and January 1965, ANL-7003, p. 24). The relatively small carbon separations achieved

have led to the suspicion that organic compounds are volatilized during sodium distillation. Preliminary information on this possibility has been obtained by mass-spectrometric analysis of vaporized sodium.

Baker and Adamson Reagent Grade sodium (75 to 150 ppm carbon) was volatilized at $\sim 400^{\circ}\text{C}$ and $\sim 5 \times 10^{-7}$ Torr from a tungsten Knudsen effusion cell into a Bendix time-of-flight mass spectrometer. Initially, a significant quantity of light hydrocarbons was released, together with hydrogen and several species with masses between 200 and 350. (An earlier, unreported gas-chromatographic analysis of the volatile products from dissolution of sodium in water also indicated minor amounts of light hydrocarbons in sodium.) On prolonged heating, evolution of the light hydrocarbons diminished, but evolution of the hydrogen and heavy-mass species continued. Similar results were obtained with a sample of distilled sodium except for the appearance of a few additional heavy-mass species whose presence was attributed to inadvertent contamination of the sample.

If it is assumed that the heavy-mass species present in Reagent Grade sodium are organic compounds of high molecular weight, a plausible explanation can be given for the inability to remove carbon by vacuum distillation. At the temperatures employed in vacuum distillation ($\sim 400^{\circ}\text{C}$), such compounds have appreciable vapor pressures and may distil with little or no decomposition. The origin of these compounds is possibly connected with the method of sodium manufacture. Sodium is made by high-temperature electrolysis of a NaCl-CaCl_2 mixture using graphite anodes and metal cathodes. The graphite anodes, which contain a pitch binder (condensed ring aromatic compounds), are gradually corroded by the hot chlorine gas evolved during electrolysis. The leads uncovered by the mass-spectrometric results will be explored further.

G. Plutonium Recycle Reactors

1. EBWR Facility

a. Inspection of Vessel Cladding (see Progress Report for February 1965, ANL 7017, pp. 73-4). Grinding explorations of cladding cracks revealed by the 800-psi, nitrogen-foam test were completed. The extent and nature of the vessel cladding failures are partially illustrated in Figure 13. Most of the cracking in the upper part of the shell followed either the longitudinal sealing welds between adjacent vertical panels, or followed the circumferential welds between the wrought cladding and submerged-arc cladding of the closure forging. Other cross- and X-shaped ruptures further removed from the seams are also present.

Figure 13. Cladding Cracks at Top of EBWR Vessel Shell

b. Primary System Piping. Work was started on the repair of the faulty welds in the 6-in. steam and safety valve piping.

Replacement springs for installation into the bodies of the two 80-MW safety valves were purchased. The valves will be set to open at 650 psi in accordance with the requirements of paragraph P-270 of the 1956 (and 1962) edition of the ASME Boiler and Pressure Vessel Code "Power Boilers."

c. Feedwater Filters. Filter No. 2 was removed from further service when radiographs revealed numerous cracked longitudinal and circumferential seams. Minor cracks in the upper circumferential welds of filters No. 3 and No. 7 were ground out and rewelded.

Detailed calculations of the strength of filters 1, 3, and 4 are in progress to clarify their design criterion, i.e., 900 psi at 500°F.

d. Containment Shell Doors. A structural design for the stiffening of the containment shell doors were selected and approved for fabrication. Parts are being prepared for installation.

2. Fuel Development and Fabrication

a. Loaded Zircaloy-2 Tubing. A total of 124 loaded Zircaloy-2 tubes (116 normal and 8 enriched) were tested ultrasonically. In two enriched tubes, indications of transverse defect were obtained. Since both defects were located above the spring on the tube ID, it was possible that the springs were in intimate contact with the tube at the positions where defect signals were produced. To check this, the tubes were placed upright (spring end up) and tapped. If the springs were touching the tube ID, such an operation should reposition the spring and thereby eliminate the indications or relocate them. Upon re-examination, the defect signals were gone.

A transverse defect was detected in the slug region of another fuel rod (loaded tube). Tapping of this rod in an upright position did not eliminate the defect indication. A gamma radiograph revealed that the slugs were aligned properly; apparently, they are not touching the tube ID.

III. ADVANCED SYSTEMS RESEARCH AND DEVELOPMENT

A. Argonne Advanced Research Reactor (AARR)

1. Core Physics

a. Multiplication of the Photoneutrons from the Beryllium Reflector after Shutdown from Power. The neutron-flux distribution arising from the subcritical multiplication of photoneutrons from the beryllium reflector has been calculated. The one-space-dimension program REX was used to perform a succession of one-shot problems (see Progress Report for February 1965, ANL-7017, pp. 45-47).

It was found that at the outer edge of the beryllium reflector, the level of the multiplied thermal-neutron flux is 2.2 times the level of the unmultiplied flux when the reactor is subcritical by \$10. At 14 cm from the beryllium, in the water, the multiplied flux is 1.6 times the unmultiplied flux. It is concluded that a startup detector placed in this region will exhibit a believable rise in count rate if the reactivity of the system is increased while the reactor is grossly subcritical.

The additional power generated by the subcritical multiplication is approximately 1% of the power due to decay of fission products when the reactor is subcritical by \$10. If the reactor were subcritical by only \$1, the additional power would contribute only 10% to the net decay power.

b. Differential Reactivity Worth for Peripheral Control Blades. The position-dependent reactivity worths of one in-core control blade and of one peripheral control blade have been measured (see Figures 14 and 15) in the critical facility with the 615-fuel-foil loading (see Progress Report for December 1964, ANL-6997, p. 51). The differential reactivity worth of a peripheral control blade is very small when the absorbing portion of the blade is above the top of the active core zone. At this position, the differential reactivity worth of an in-core control blade is much greater.

The present concept of control-blade scram is that the initial acceleration of the blade will be 4 g, and that this acceleration will be reduced linearly to 1 g within the first 6 in. of blade movement. If the effects of frictional drag, etc., of the blade in the control channel may be ignored, 26 msec are required for the blade to move the first 1/2 in. For fast-reactivity transients, for which the reactivity is introduced within 33 msec (the time required for coolant to flow from the top of the core to the bottom of the core), it is calculated that the reactivity transient would be ended long before the peripheral control blades would be of much effect, if the blade absorber started at the top of the active core. If it be assumed that the blade movement began 10 msec after a high-flux-level signal, a peripheral control blade would introduce negligible reactivity control before reactivity-feedback mechanisms limited the transient power. If the

Figure 14
Integral Reactivity Worth of Peripheral
Control Blade (615-foil Fuel Loading)

Figure 15
Integral Reactivity Worth of In-core
Control Blade (615-foil Fuel Loading)

peripheral control blade were withdrawn even farther, to enhance the peaking of the thermal-neutron flux near the tips of beam tubes at this vertical position, the blade would act even less like a "safety blade" for fast transients. Therefore, it is questionable whether a very rapid acceleration of peripheral control blades would be of much value in limiting short-period power transients. This is a mixed blessing, since a rapid acceleration of the large peripheral control blades might be very difficult to achieve if the coolant gaps are thin. This matter will require further study.

2. Fuel Material Development

Samples of fuel for irradiation were installed in ETR-G12 facility in late February and have been operating satisfactorily at a nominal average heat flux of approximately 700,000 Btu/hr-ft². Maximum heat flux in the samples exceeds 1.5×10^6 Btu/hr-ft².

Initial development work at the Pyromet Company with brazed assemblies has been completed. Flow-channel spacing along the 20-in.-long, 37-plate composite has been held to 0.040 ± 0.0015 in. Figure 16 shows one of the 37-plate rhomboidal subassemblies. Figure 17 is a photomicrograph of a typical edge spacer-to-plate brazed joint showing good bonding achieved in such developmental assemblies.

3. Heat Transfer

a. Analytical Studies. Further front-to-back analog studies of AARR fuel plates were conducted with regard to accuracy, channel size, and values of physical properties.

A seven-region analog model consisting of five fuel regions with a region of cladding on each side was compared with an eleven-region model having nine fuel regions and a region of cladding on each side. Maximum heat flux ratio was found to be 1.350 for the seven-region model and 1.370 for the eleven-region model. This difference of only 1% indicates that the seven-region model gives meaningful results.

A model was designed with a 0.050-in. coolant channel on the cold side and compared with a control model having 0.040-in. channels on each side of the cladding. The maximum heat flux ratio of the model with the enlarged channel was 1.254, or 2.6% less than that for the control model having a ratio of 1.288.

Conditions for the control model were varied to show the changes caused by varying physical property values. Variations of 10% in cladding conductivity, cladding thickness, fuel conductivity, film coefficient, and water temperature in the channels resulted in changes in maximum heat flux ratio ranging from negligible to 7.3%. Water temperature had the greatest effect on the results.

Figure 16. 37-plate Brazed Rhomboidal Fuel Assembly Model (Pyromet Corporation)

100X

Figure 17. Typical Edge Spacer-to-plate Joint from Assembly No. 1, Brazed with GE J8100 at 2135-2145F for 2 hr. (Etched with 50% HNO_3 at 1.8 V for 40 sec.)

b. Experimental Program. The experimental AARR steady-state heat transfer program is to determine the maximum power conditions for the AARR fuel assembly. Electrically heated nickel test sections are used to simulate the nuclear core coolant channels.

A new 22-in.-long, uniform test section with a 0.040-in.-thick, 1.25-in.-wide flow channel having a heated length of 18 in. was installed in the heat transfer loop, with appropriate thermocouples and pressure taps. The channel spacing did not vary more than ± 0.002 in. over the total length of the test section.

The burnout detector which had previously failed to function properly was modified and reinstalled. Burnout conditions were approached by maintaining constant flow rate, inlet temperature, and exit pressure, while raising the power by small increments. Power-to-pressure-drop measurements were made while approaching burnout. Again, destructive burnout of the test section was experienced. An evaluation of the rate of increase in wall temperature at the time of burnout indicates that the delay time in the circuit breaker and the response time of the power supply are too large and are the cause for failure of the system to prevent burnout of the test section.

Different methods for operating the power supply are being examined to decrease the delay times for shutdown of maximum power when burnout conditions are reached. If this problem is not resolved, only one true burnout point per test specimen can be expected. If this is the case, the steady-state heat transfer program for AARR will be changed accordingly to test only specific conditions applying to the design as time progresses, rather than a detailed parameter study as first anticipated.

The limited amount of burnout point and power-to-pressure-drop measurements obtained to date are being analyzed.

The feasibility of measuring void fractions within reasonable accuracies in the narrow flow channels is being investigated with an out-of-loop experiment. A gamma-ray-attenuation technique is being utilized. If the outcome is favorable, the installation of necessary void-measurement equipment will be initiated in the AARR heat transfer loop.

Four additional test sections have been ordered. The test sections are 22 in. long, with a flow channel 0.040 in. thick, 1.25 in. wide, and a heated length of 18 in. The first two of the four test specimens will be machined to represent linearly increasing heat flux; the last two will represent skewed flux distributions corresponding to presently anticipated flux distribution in the AARR core. An added feature to these test sections is the rounding off of corners to avoid peak heat fluxes which otherwise might result in premature burnouts.

4. Critical Experiment

a. Theoretical Analyses for the Minimum Critical Loading of 315 Fuel Foils. The 16-group cross-section set No. 206 has been modified. Group parameters for chromium, derived from GAM calculations, were substituted for the previous values. The parameters for groups 15 and 16, the two thermal groups, have been computed for the 315-fuel-foil averaged reactor core by means of digital-computer program TEMPEST. The microscopic capture and fission cross sections for U^{235} have been computed for the energy groups which include the region of resolved resonances of the U^{235} . To estimate these group-averaged cross sections, it was necessary

to compute an average value of the potential scattering per atom of U^{235} in the dilute slab lattice of fuel foils, stainless steel, and water. It was found that, to a good approximation for k_{eff} , the fuel foils in this loading could be treated as isolated slabs of U^{235} and Σ_s pot/atom U^{235} determined with the aid of a rational approximation formula involving the average chord length of the foil. The result was that for a homogeneous distribution of 16.1 kg U^{235} in the reactor core, and with an outer reflector consisting of a homogeneous mixture of beryllium and 10 v/o Plexiglas, the calculated value of k_{eff} is 1.039. For zero Plexiglas in the beryllium zone, $k_{eff} = 1.054$. On the basis of 16-group S_n calculations, it was estimated earlier that k_{eff} was reduced by ~3% because of the heterogeneous distribution of the fuel foils in the minimum critical loading. This estimate has been checked, on the basis of fewer-group S_n calculations, where the group parameters were determined by flux-weighting the multigroup parameters.

Consequently, it appears that the modified 16-group set yields a value of k_{eff} approximately 0.5% higher than the measured value, $k_{eff} = 1.004$, for the minimum critical loading of 315 fuel foils, when the calculation is corrected for the reactivity reduction due to the heterogeneous distribution of the fuel foils.

The mean prompt-neutron lifetime ℓ^* has been estimated by calculating the change in k_{eff} due to the addition of an α/v absorber uniformly throughout the reactor. Starting at criticality (for $\alpha = 0$),

$$\ell^* = \lim_{\alpha \rightarrow 0} \frac{1 - k_{eff}}{\alpha}.$$

For groups $j = 1$ to 14, $\bar{v}_j$ was assumed to be constant throughout the reactor. In the two thermal groups (15 and 16), the $\bar{v}_j$ were assumed to be region-dependent. For the reactor core, $\bar{v}_{15}$ and $\bar{v}_{16}$ were inferred from TEMPEST calculations for the homogeneous loading of 315 fuel foils. For the Internal Thermal Column (ITC) and for the beryllium outer reflector, $\bar{v}_{15}$ and $\bar{v}_{16}$ were computed for a spectrum representative of the average spectrum in the ITC.

The computed value of ℓ^* is 41.7 μsec . This is in fair agreement with the value of 38.8 μsec which was inferred from Rossi- α measurements with this core (see Progress Report for November 1964, ANL-6977, p. 78).

b. Measurements. Measurements completed with the 615 fuel-foil core included: measurement of the uniform temperature coefficient; substitution of one fully loaded fuel subassembly into the core; removal of Plexiglas from the original radial reflector and flux mappings in the new reflector arrangement for comparison with similar mappings made earlier in the original reflector.

The temperature coefficient was measured over a wider range than before, from 21°C to 72°C. Although data scatter prevented a precise determination, the results are consistent with earlier measurements. With all control blades withdrawn and reactivity compensation by water-level control, a uniform but small negative temperature coefficient of reactivity was measured to be $-2 \times 10^{-3}\%/^{\circ}\text{C}$. With control blades compensating for reactivity changes and water raised to provide full core moderation and an infinite top reflector, noticeably different results were obtained. Most of the reactivity loss occurred above 33°C. The average coefficient from 33 to 72°C was $-6 \times 10^{-3}\%/^{\circ}\text{C}$. It is not known whether the larger coefficient with control blades inserted is the result of a gain in control-blade worth as the temperature rises and moderator density decreases. As reported previously (see Progress Report for February 1965, ANL-7017, pp. 75-77), measurement of the reactivity effect of voids in the water indicated that variation in water density with temperature in the core and in the ITC should provide a contribution of $-7.5 \times 10^{-3}\%/^{\circ}\text{C}$ to the uniform temperature coefficient.

Radial manganese-foil-activation traverses taken before the removal of Plexiglas from the radial reflector are given in Figure 18 with foil locations being indicated in Figure 19. These traverses show the effect of loading-density changes when compared with similar traverses in the 315-foil loading (see Progress Report for November 1964, ANL-6977, Figure 18). The principal changes are: (a) a noticeably lessened thermal-neutron activation of foils in the more densely loaded fuel region with 615 fuel foils, relative to the activation of foils in the ITC and in the radial reflector; (b) a drop from 2.4 to 1.6 in the cadmium ratio of manganese in the fuel region, with the ratios in the ITC and in the radial reflector remaining unchanged; and (c) a readily apparent dip in the distribution of the activity of the manganese in the core, near the outer edge of the fuel region. A noticeable dip in the thermal-neutron-group fluxes was indicated by calculations for the fully loaded core (see Progress Report for January 1965, ANL-7003, Figure 16). This dip applies also to the activity of bare manganese foils in the calculated flux distribution.

The Plexiglas was removed from the 90% beryllium-10% Plexiglas (by volume) radial reflector. The resulting increase in reactivity was measured, by the change in position of the critical control blade, to be 1.2%. Activation plots of manganese foils were taken to permit a comparison between the two reflector compositions. The results will be reported if significant changes are indicated.

Figure 18. Manganese Radial Activation Traverses
(615-foil Core)

Figure 19. Foil Placement for Radial Activation
Mapping with Manganese Foils

Substitution of a fully loaded fuel subassembly into the core was done for two reasons. One was to provide a comparison between reloading one subassembly and the eventual reloading of the entire core. If reasonably consistent patterns develop, this will simplify future efforts to measure the reactivity effects of graduated loadings and burnout of the fuel and poison, which will vary from point to point about the fuel region. Another reason was to assure that the currently available fuel is sufficiently within the dimensional specifications to permit assembly of a fully loaded core. No difficulty was encountered on reassembling two different fuel subassemblies and substituting each into the core, replacing one subassembly at a time at several locations. (Only enough spare fuel was on hand to provide one fully loaded assembly by addition to one of the subassemblies already in use.)

The supply of fuel available to the critical experiment is expected to be adequate to achieve a two-thirds loading of 810 fuel foils in April 1965. As with earlier loadings, some of the bare uranium foil delivered by the fabricator failed to pass ANL inspection for dimensional tolerances. The consequences of using fuel which is noticeably out of specification include a risk of inability to load a fully loaded (1215-foil core) because of lack of space in the tightly loaded fuel region.

The contract for fuel foils requires the contractor to furnish a certified chemical analysis of samples from finished foils: (a) from each lot, or batch, of UF_6 converted to uranium metal; and (b) from each lot, or batch, of uranium metal produced by recycle of scrap or rejected foils. These data are to be submitted to Argonne National Laboratory with each lot of packaged fuel foils.

In early shipments, the analysis data were not submitted as specified, but in the interest of initiating the critical experiments as quickly as possible, Argonne proceeded with inspection of delivered fuel foils and checking to determine whether individual foils met the specifications on dimensions. Recently, the contractor supplied data for samples of as-cast ingots from recycled material, indicating that this material did not meet the specifications on impurity levels of carbon and/or iron. Fuel foils had been produced from these ingots and had been shipped to the Laboratory. Some of these foils have been used in criticality experiments. These foils will be retained by the Laboratory, but special attention will be required in selecting foils for certain reactor physics measurements, e.g., danger-coefficient measurements.

In the future, certified chemical analyses will be required as stipulated in the contract, namely, at the same time as the shipment of the packages of foils. It should be noted that the contract also requires that the contractor verify that the finished foils meet all of the specifications before shipping them. Every possible means is being exploited to encourage the fabricator to improve both delivery schedules and quality of material delivered.

B. Magnetohydrodynamics (MHD)

Extensive modifications of a NaK-N₂ loop have been initiated to accommodate a new series of experiments with a MHD generator to utilize a two-plane, highly dispersed inlet flow. The experiments are designed to demonstrate the feasibility of the film-generator concept and to provide data on generator efficiency and the relative importance of skin friction losses.

Extensive tests have been completed on the nozzle and generator geometries that will be used in this program. Tests were run on Lucite mockups in an air-water system. Based upon these tests, the final nozzle and generator configuration has been selected, and final drawings of the two components are being made. In addition, the design of all other loop components has been completed, and drawings are being made so that job construction can be started. The generator geometry selected will have a maximum output of $1\frac{1}{2}$ kW.

The major pieces of equipment, namely, the 16-in.-diameter magnet and the NaK pump have been received. The magnet has been installed in place and has been completely checked out. Difficulties encountered in testing out the pump have been traced to faulty mechanical seals. Arrangements have been made with the vendor to modify the pump to secure the desired performance.

IV. NUCLEAR SAFETY

A. Reactor Kinetics

1. Fast Reactor Safety

a. Coolant (Water) Expulsion Studies. A small-scale experiment has been planned to investigate the expulsion of sodium from a reactor channel during a power excursion. The first tests will use water as the fluid rather than sodium, due to ease in handling. Instrumentation and power supply problems will be greatly reduced.

The check-out and calibration of equipment and instruments for the water-expulsion tests is continuing. The twenty 12-V diesel truck batteries wired in series yielded a maximum current of approximately 10,000 Amp through the test section. The thin-wall (0.005-in.) section increased its temperature at a rate in excess of 10^6 °F/sec and partially vaporized in several milliseconds. A number of heavier-walled tubes are being investigated at the maximum current load.

The precalibrated pressure transducers were recalibrated to check accuracy by means of a dead-weight gauge. The factory-supplied calibration was found to agree within $\pm 1\%$ with the new data.

Circuitry is being developed to step-down the signal from the current shunt so the signal will be directly recordable.

b. Hydrodynamic Calculations. The sodium void coefficient, which may be positive or negative depending on where the voiding occurs in the core, greatly influences the behavior of a reactor especially during an excursion. A parametric study of the voiding behavior of sodium is in progress.

Basically, numerical solutions are being sought for coupled two-phase coolant-hydrodynamics equations, the fuel-element-heat-conduction equation, and reactor kinetics equations. The terms in the fluid dynamics equations, such as friction pressure gradient, are obtained empirically, and the heat transfer coefficient is deduced from the steady-state values given in the literature.

The following parametric conditions for a coolant channel were used:

Rod diameter	= 0.635 cm
Coolant fraction	= 0.50 cm
Core length	= 150 cm

Blanket thickness = 30 cm
 Blanket heat rate = 0.10 x core heat rate
 Coolant inlet temperature = 400°C

Initially, steady-state solutions for the two-phase conservation equations (mass, momentum, and energy) for boiling sodium in a single coolant channel were obtained. An ALGOL program was used to solve the steady-state equations for two-phase flow for sodium.

The effect of varying maximum channel heat flux as well as channel exit pressure was found. As expected, reducing the pressure at the exit of the channel increases the total pressure drop for a given flow rate and heat flux. Likewise, increasing the heat flux with a given flow rate and exit pressure increases the total pressure drop. The empirical Martinelli correlation (built into the ALGOL program), which relates void fraction to quality and fluid properties, gives a curve having an almost vertical slope for curves of void versus channel length, at the start of boiling. The steepness of the curve is probably due to the extremely high ratios of liquid to vapor density for sodium in the pressure range of interest.

In the cases of high heat flux and/or a low exit pressure, the pressure profile has a singularity in that the pressure gradient became exceedingly steep at the exit of the channel, and there is an apparent discontinuity just ahead of the exit. Halving of the space interval studied in these cases results in a steepened gradient, even though the calculated overall pressure drop across the channel does not change appreciably. These results have been interpreted in terms of the phenomenon of critical flow and agree surprisingly well with theoretical calculations by Fauske²² for limiting or critical two-phase flows with sodium. Fauske's theoretical treatment was derived from work with water in two-phase critical flow.

c. Calculations of Pressure Pulses. Mathematical difficulties were encountered in solving the equations originally coded for the calculation of transient pressures involving expulsion of vaporizing coolant from a heated channel, for certain parametric cases. The problem is reformulated in a finite-difference approximation by the following basic equations:

$$\dot{Z}\left(t + \frac{\Delta t}{2}\right) = \dot{Z}\left(t - \frac{\Delta t}{2}\right) + \frac{A[P(t) - P_0]}{M_L(t)} \Delta t - g\Delta t - M_L(t) \left[\dot{Z}\left(t - \frac{\Delta t}{2}\right) \right]^2 \quad (1)$$

and

²²Fauske, Hans K., Two-phase Critical Flow with Application to Liquid Metal Systems (Mercury, Cesium, Rubidium, Potassium, Sodium, and Lithium), ANL-6779 (Oct 1963).

$$Z(t + \Delta t) = Z(t) + \dot{Z} \left(t + \frac{\Delta t}{2} \right) \Delta t, \quad (2)$$

where

Z = distance;

t = time;

Δt = time increment for calculations;

A = channel cross-sectional area;

P = saturated vapor pressure;

P_0 = initial pressure;

g = acceleration due to gravity;

M_L = mass of liquid coolant being expelled;

γ = a friction factor.

Equations (1) and (2) are used to calculate transient pressure as follows. It is assumed that the coolant is at saturation conditions, so that pressure is given as a function of enthalpy of the saturated liquid. Enthalpy is calculated as a function of time by calculating the energy necessary to vaporize sufficient vapor to fill the volume $AZ(t)$, and subtracting that energy from the time-integral of power. Because of the unique relationship between temperature and pressure along the saturation curve, it is not necessary for temperature to appear explicitly in the calculations.

This problem has been coded for the 160A as an experimental code without the gravitational and frictional terms, and with material properties specified by simple analytic functions and constant power.

B. TREAT

1. Operations

Fast Ceramic Reactor fuel sample C-3-B was subjected to a low-energy transient to obtain data on the relationship between sample power and reactor power prior to a higher-power transient intended to yield central fuel temperatures near the melting point. This sample of mixed Pu-U oxide fuel was irradiated in GETR prior to shipment to TREAT. Transient irradiations of FCR fuel are being conducted for the General Electric Co.

Two capsules, containing prototype Power Burst Facility fuel samples, were irradiated for the Phillips Petroleum Co. One capsule that contained a three-rod cluster of fuel samples was subjected to ten transients

designed to produce fuel temperatures similar to those expected during normal operation of the Power Burst Facility. Objectives of the test were to verify cladding integrity and strain on the sheath in the design of this element. The other capsule that contained one fuel sample was subjected to one transient designed to produce 150% of design energy release in the fuel.

2. Large Sodium Loop

The compound bellows assemblies are now 95% complete. As soon as these units are finished they will be shipped to Idaho for incorporation into the loop structure. Single bellows which are used throughout the loop as expansion joints are also being assembled.

The fabrication of the leak-detection circuitry for the large TREAT loop is approximately 60% complete. The bid package for the construction of the test section has been prepared, and has been distributed to various vendors for price and delivery information.

Analog computations have been made to determine the influence of the generated pressure upon the flow rate of the loop sodium. Three regions of maximum transient pressure, i.e., 250, 500, and 750 psi, were explored. The results show that the upstream sodium will be stopped and reversed in direction without excessive reaction pressures being generated.

In preparation is an experiment in TREAT to determine the reactivity worth of a test-section mockup. Preliminary estimates show that the worth of the test section is expected to be $\sim -6.5\%$ Δk . With the addition of double-viewing shots and a stainless steel-slot liner, the total negative reactivity may exceed the total available reactivity for proper operation of the reactor; consequently, the slot liner will have to be constructed of Zircaloy. The mockup experiment will verify this need.

C. Chemical and Associated Energy-transfer Problems in Reactor Safety

1. Short-period Transient Irradiation

The recent destructive test of the Kiwi-TNT reactor (see Progress Report for January 1965, ANL-7003, p. 76) offered a unique opportunity to obtain data on metal-water reactions of typical reactor fuel-element materials during a short-period (0.5-msec) transient. (Previous experiments have been carried out during transients in TREAT with reactor periods ranging from about 50 to 500 msec.) The Kiwi-TNT transient allowed fission heating of the fuel material under conditions more closely approximating those achieved during a short-period nuclear-reactor excursion.

Prior to the test, twenty-four stainless steel autoclaves containing various fuel samples in water were placed at distances of from 8 in. to 12 ft from the Kiwi-TNT reactor vessel. The autoclaves in turn were contained within an outer stainless steel capsule (2-in. Schedule 40 pipe). Each autoclave contained a flux-monitor wire and a fuel pin immersed in water. Six samples of each of the following enriched fuel materials were used: (1) uranium alloy (5 w/o Zr, 1.5 w/o Nb) pin, unclad; (2) UO_2 core, Zircaloy-2-clad pin; (3) UO_2 core, 304 stainless steel-clad pin; and (4) aluminum alloy (17 w/o U, 2 w/o Ni) plate, unclad.

Twenty-three of the autoclaves were recovered following the transient of January 12, 1965 and returned to Argonne. All were intact, except one, which was almost completely crushed, most likely by impact with a portion of the reactor itself. However, the containment capsules all underwent various degrees of deformation except the one that was farthest (12 ft) from the reactor.

Postirradiation observations and analyses of the fuel samples are being made. The results available to date are summarized in Table XII. The condition of the fuel specimens after the transient was dependent on both the original distance of the specimen from the reactor and on the composition of the fuel. All of the uranium alloy pins and two of the aluminum alloy plates melted and apparently underwent substantial metal-water reaction. Only one of each type of metal-clad, UO_2 -core specimens (the one nearest the reactor) was fragmented.

Some additional background information concerning the transient itself is of interest, since the test is pertinent to our work in nuclear reactor safety. The total yield of the test was 3×10^{20} fissions, which corresponds to an integrated power of 10,000 MW-sec. The anticipated yield was 10^{21} fissions; thus the total energy of the excursion was somewhat less than that predicted. Since the capsules were placed in positions based on a yield of 10^{21} fissions, a few more of the fuel pins remained intact (i.e., the heating was not sufficient to melt them) than would have otherwise been the case. However, on the whole, the placement of the capsules was about optimum; if all had been close (within 3 ft of the reactor), they would have been severely distorted and dented. Also, very useful information should be obtained on the variation of neutron flux with distance so that, if another such test is conducted, then the capsules can be located with much more confidence.

The double-capsule assembly for this metal-water portion of the Kiwi-TNT test weighed 7.5 lb. For those autoclaves that flew 500 ft from the reactor, an initial velocity of 125 ft/sec (86 miles/hr) was computed, assuming that they left at a trajectory of 45° with respect to the horizontal.

Table XII. Observations and Data Currently Available^a from
Kiwi-TNT Short-period Test

No.	Autoclave		Fuel Sample			
	Distance, ^b ft	Condition of Outer Capsule after the Transient	Type of Fuel Specimen ^c	Condition of Fuel after the Transient	Metal-Water Reaction, %	d_{sv} , ^d mil
1	2/3	Completely crushed	U alloy	Fragments and fine particles		6
2	2	Dented severely	U alloy	Completely melted into fine particles		3
3	3	Distorted	U alloy	Particles		6
4	3.5	Dented	U alloy	Melted into globules and fines		21
5	5	Dented	U alloy	Globule and particles		19
6	6	Dented mildly	U alloy	Partially melted	3.4	98
7	2/3	Dented severely	SS clad UO ₂	Completely melted, globules and particles		32
8	2	Dented severely	SS clad UO ₂	Intact, slight swelling		-
9	3	Dented	SS clad UO ₂	Intact		-
10	3.5	Not recovered	SS clad UO ₂		-	-
11	5	Dented	SS clad UO ₂	Intact	0	-
12	6	Dented mildly	SS clad UO ₂	Intact	0	-
13	2/3	Distorted	Zr clad UO ₂	Cladding ruptured, core converted into particles		6
14	2	Dented severely	Zr clad UO ₂	Intact (swelled)		-
15	3	Dented severely	Zr clad UO ₂	Intact (slight oxidation)		-
16	3.5	Dented severely	Zr clad UO ₂	Intact (slight darkening)		-
17	5	Dented mildly	Zr clad UO ₂	Intact	0.03	-
18	6	Dented mildly	Zr clad UO ₂	Intact	0.03	-
19	3	Dented severely	Al alloy	Completely melted, particles and fines		150
20	3.5	Dented	Al alloy	1/3 melted, some particles		80
21	5	Dented	Al alloy	Intact (darkened)		-
22	6	Dented mildly	Al alloy	Intact	0.01	-
23	10	Dented mildly	Al alloy	Intact	0.01	-
24	12	No change	Al alloy	Intact	0.01	-

^aAs of March 25, 1965.

^bDistance between autoclave and reactor vessel.

^cU alloy: 93.5 w/o U, 5.0 w/o Zr, 1.5 w/o Nb, 20% enriched, 0.2 in. dia x 0.5 in. long.
SS-304 clad UO₂ core: single pellet of UO₂, 11.2% enriched, 0.375 in. dia x 0.5 in. long.
Zr-2 clad UO₂ core: single pellet of UO₂, 11.2% enriched, 0.375 in. dia x 0.5 in. long.
Al alloy: 81 w/o Al, 17 w/o U, 2 w/o Ni, 93% enriched, 0.5-in.-long plate sample.

^dMean volume-to-surface particle size of fragmented fuel sample.

V. PUBLICATIONS

PapersPHASE DIAGRAM CONSIDERATIONS FOR THE REGENERATIVE
BIMETALLIC CELL

A. K. Fischer

149th Mtg. Am. Chem. Soc., Detroit, April 4-9, 1965.

Abstracts of Papers: p. 13-L

THERMODYNAMICS AND THERMAL EFFICIENCIES OF THERMALLY
REGENERATIVE EMF CELL SYSTEMS

J. C. Hesson

149th Mtg. Am. Chem. Soc., Detroit, April 4-9, 1965.

Abstracts of Papers. p. 14-L

THERMODYNAMIC PROPERTIES OF LITHIUM HYDRIDE BY AN EMF
METHOD

C. E. Johnson, R. R. Heinrich, and C. E. Crouthamel

149th Mtg. Am. Chem. Soc., Detroit, April 4-9, 1965.

Abstracts of Papers. p. 37-S

THERMODYNAMIC DATA FOR THE LiH CELL

C. E. Johnson and R. R. Heinrich

149th Mtg. Am. Chem. Soc., Detroit, April 4-9, 1965.

Abstracts of Papers. p. 17-L

BORAX-V - A NUCLEAR SUPERHEAT REACTOR

R. E. Rice and W. R. Wallin

Proc. Am. Power Conf., Illinois Institute of Technology,
April 14-16, 1964. Vol. 26, pp. 191-200.

FAST REACTOR FUEL BURNUP

F. R. Channon, J. D. Luoma, and E. D. Frankhouser

Nucl. Applications 1(1), 55-61 (February 1965)

DRAWING OF TUBES FILLED WITH PARTICULATE SOLIDS

N. H. Polakowski and R. M. Mayfield

Trans. ASME 87, Series B (1), 80-84 (February 1965)STATISTICAL-ERROR ESTIMATION FOR THE TRANSFER-FUNCTION
MEASUREMENTS OF A NOISY REACTOR SYSTEM

C. Hsu and W. C. Lipinski

Nucl. Sci. Eng. 21(3), 407-408 (March 1965)

REFRACTORY OXIDE INSULATED THERMOCOUPLE ANALYSIS AND DESIGN

G. F. Popper and T. Z. Zeren

Presented at the High Temperature Thermometry Seminar,
February 24-26, 1965, Washington, D. C.

EBR-II SYSTEM AND COMPONENT EXPERIENCE

R. A. Jaross

Proc. Sodium Components Information Meeting held in Palo Alto,
California, August 20-21, 1963. SAN-8002 (May 1964). pp. 3-9

PERFORMANCE CHARACTERISTICS OF A LIQUID METAL MHD GENERATOR

Michael Petrick and Kung-You Lee

Magnetohydrodynamic Electrical Power Generation. Proc.
Intern. Symp., Paris, July 1964. European Nuclear Energy
Agency. p. 953

LIQUID-METAL MAGNETOHYDRODYNAMICS

Michael Petrick

IEEE Spectrum 2, 137-151 (March 1965)

THE CONTROL OF FAST REACTORS: CURRENT METHODS AND FUTURE PROSPECTS

W. B. Loewenstein

Proc. IAEA Symp. on Physics and Material Problems of
Reactor Control Rods, Vienna, November 11-15, 1963. Intern.
Atomic Energy Agency, Vienna, 1964. pp. 633-665

ANL Reports

- ANL-6829 ENGINEERING DEVELOPMENT OF FLUID-BED FLUORIDE
VOLATILITY PROCESSES. Part 1. Bench-scale Investiga-
tion of a Process for Zirconium-Uranium Alloy Fuel
D. Ramaswami, N. M. Levitz, J. T. Holmes, and
A. A. Jonke
- ANL-6849 EXPERIMENTS ON BOILING CORE B-2, BORAX-V
Borax-V Project Staff
- ANL-6866 EXPERIMENTAL INVESTIGATIONS OF SECONDARY
CRITICAL CONFIGURATIONS (ZPR-III Assemblies 27
and 28)
W. Gemmell, J. K. Long, and W. P. Keeney

- ANL-6937 A STUDY OF UNSTEADY MAGNETOHYDRODYNAMIC
FLOW AND HEAT TRANSFER
Ralph M. Singer
- ANL-6948 CONDENSATION OF METAL VAPORS: MERCURY AND
THE KINETIC THEORY OF CONDENSATION
Donald J. Wilhelm
- ANL-6978 NEARREX, A COMPUTER CODE FOR NUCLEAR RE-
ACTION CALCULATIONS
P. A. Moldauer, C. A. Engelbrecht, and G. J. Duffy
- ANL-6984 AN ITERATIVE UNFOLDING METHOD FOR RESPONSE
MATRICES
Raymond Gold