~~CONFIDENTIAL~~

UNCLASSIFIED

MAY 1 1964

CLASSIFICATION LEVEL

(S, C, OR U)

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

MASTER

NAA-SR-MEMO - 9108

This document contains 18 pages

This is copy 82 of series

Do not remove
this sheet

THIS MATERIAL CONTAINS INFORMATION AFFECTING THE
NATIONAL DEFENSE OF THE UNITED STATES WITHIN THE
MEANING OF THE ESPIONAGE LAW, TITLE 18, U.S.C., SECS
793 AND 794, THE TRANSMISSION OR REVELATION OF WHICH
IN ANY MANNER TO AN UNAUTHORIZED PERSON IS PRO-
HIBITED BY LAW.

CLASSIFICATION TYPE

(RD OR DI)

*NAA-SR-MEMOs are working papers and may be expanded,
modified, or withdrawn at any time,
and are intended for internal use only.*

GROUP 1

EXCLUDED FROM AUTOMATIC

DOWNGRADING & DECLASSIFICATION

This report may not be published without the approval of the Patent Branch, AEC.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.

1 4537

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

~~CONFIDENTIAL~~

UNCLASSIFIED

CLASSIFICATION LEVEL

(S, C, OR U)

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

~~CONFIDENTIAL~~ UNCLASSIFIED

ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.		NAA SR-MEMO CONF NO. 9108		APPROVALS	
TECHNICAL DATA RECORD		PAGE 1 OF 18		<i>S. S. Zeller</i>	
AUTHOR <i>P. B. Abramson</i> P. B. Abramson		DEPT. & GROUP NO. 726-62		DATE 10-14-63	
TITLE Mercury Pump Degradation		GO NO. 7562		S/A NO. 2239 TWR	
PROGRAM SNAP-2		SECURITY CLASSIFICATION			
		(CHECK ONE BOX ONLY)		(CHECK ONE BOX ONLY)	
		AEC DOD		RESTRICTED DATA ☐	
		UNCL. ☐ CONF. ☒ SECRET ☐		DEFENSE INFO. ☒	
DISTRIBUTION Entire copy to SNAP-2 Standard Distribution		AUTHORIZED CLASSIFIER SIGNATURE <i>S. S. Zeller</i> DATE 16 Oct 63			
		STATEMENT OF PROBLEM			
		To describe the mechanisms and evaluate the possibility of CRU mercury pump degradation.			
		ABSTRACT:			
		The object of this report is to describe CRU pump performance and to present an evaluation of how the pump system will (or will not) degrade under long term operation.			
		<div>CLASSIFICATION CONFIDENTIAL UNCLASSIFIED</div> <div>OR CHANGED TO <i>DOC</i></div> <div>BY <i>J. K. Kamen</i> DATE <i>4 Nov 71</i></div> <div>Exempt from CCRP Re-review Requirements (per 7/22/82 Duff/Caudle memorandum) <i>9/28/04 H.A.</i></div> <div><div>Confidential CLASSIFICATION</div><div><i>S. S. Zeller</i> SIGNATURE</div><div>RD ☒ <i>16 Oct 63</i> DATE</div><div>AUTHORIZED CLASSIFIER</div></div>			

~~CONFIDENTIAL~~ UNCLASSIFIED

~~CONFIDENTIAL~~

NAA-SR-MEMO 9108
DATE 10-14-63
PAGE 2 OF 18

ATOMICS INTERNATIONAL
A Division of North American Aviation, Inc.

INTRODUCTION

In this report, a review is presented of the characteristics of pump degradation. This review is then applied to the CRU mercury pump, to determine:

- a) If the pump will degrade, and
- b) How it will degrade

Cavitation erosion and crud in the system are the only mechanisms which can cause degradation. Both have occurred, but so far no degradation from the former has been observed on either SNAP-2 or Sunflower.

I. General Pump Performance

Pump performance is generally described by two curves. Pump ΔP vs flow and NPSH vs Pump ΔP (termed cavitation performance).

Centrifugal pumps of the same design all have basically the same performance characteristics (see Figure 1-A). Changes in performance are designated by application requirements and created by design changes. For example, see Figure 1-A.

II. Effect of Exit Portion of Blades

The sketch below demonstrates the effect of exit blade angle on the head vs flow curves.

UNCLASSIFIED

Figure 1

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 3 OF 18

ATOMICS INTERNATIONAL
A Division of North American Aviation, Inc.

36,000 RPM Cavitation Performance
CRU IV & CRU V Centrifugal Pump

~~CONFIDENTIAL~~

0711587030

NO. NAA-SR-MEMO 9108
DATE 10-14-63
PAGE 4 OF 18

ATOMICS INTERNATIONAL
A Division of North American Aviation, Inc.

The slope of curve (b) is determined by the exit angle. As the exit $\angle$ approaches 90° , ΔP becomes invariant with flow. For applications where it is critical to have constant ΔP regardless of Q , the exist $\angle$ is designed at or close to 90° . All of the CRU pumps are designed with a 90° exit angle.

Next examine the history of the SNAP-2 pump with respect to ΔP vs Q curves (Figure 2).

Figure 2

~~CONFIDENTIAL~~

0711587030

03.15.07.030

~~CONFIDENTIAL~~
 NO. NAA-SR-MEMO 9108
 DATE 10-14-63
 PAGE 5 OF 18
ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

Originally, the SNAP-2 pump was designed with 90° exit because it was felt necessary to have flat ΔP vs Q in the operating range. Some slight sacrifice in the flatness of this curve was permitted in the CRU V design in order to improve blade turning rate and cavitation performance. This resulted in the slight sloped ΔP vs Q curve for CRU V whose exit $\angle$ is 31°.

III Effect of Inlet Portion of Blade on Cavitation

Blade turning rate, and inlet angle and geometry have a controlling influence over cavitation performance. It is necessary to have proper design in order to avoid cavitation. Cavitation is minimized by eliminating dynamic depression in the impeller inlet. A typical static pressure curve for a centrifugal pump is shown below, illustrating presence and absence of dynamic depression:

Dynamic depression is caused by improper matching of fluid flow angle relative to the blade angle. The depression can be minimized by proper design methods, but normally cannot be completely eliminated. The effect of improper design is to cause shift in the cavitation performance as in the following illustration. Off design operation (running at design speed at off design flows or vice versa) causes mismatched flow to blade angle and increases dynamic depression.

~~CONFIDENTIAL~~

03.15.07.030

03115087030

~~CONFIDENTIAL~~**ATOMICS INTERNATIONAL**

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108DATE 10-14-63PAGE 6 OF 18

Figure 4

Normally, even at on design incidence and with proper blade design, some cavitation occurs. Raising inlet pressures one or two orders of magnitude above minimum estimated NPSH sometimes cannot suppress all cavitation. This is due to the fluid turning around the point of the leading edge. This point can be sharpened to a razor edge to reduce this effect but even a razor edge seems huge to a mercury molecule.

IV Expected Physical Damage From Cavitation - Erosion

Cavitation erosion is the most probable influence on performance of a given pump under long term operation. If performance of the pump is to degrade, its characteristics, and therefore its geometry, must be altered in some way. Assuming that heat and pressures will not cause yielding or deformation of the geometry, the only factor that can change the pump geometry is erosion. This erosion can be caused either by particles or by cavitation. Under design point operation, cavitation bubbles always collapse on the suction side of the blades or in the free stream. It is difficult to predict where particle erosion will occur but so far, this does not appear to ever have been a significant factor in CRU pump erosion.

In Figure 4A, typical CRU pump erosion is shown. The bubbles were created at the dynamic depression on the suction side and followed the stream line of flow until they reached a high pressure region, where they collapsed. Evidence of erosion in the picture is where it would be expected.

~~CONFIDENTIAL~~

03115087030

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

~~CONFIDENTIAL~~

NO. NA-1-SR-Memo 9108

DATE 10-14-63

PAGE 7 OF 18

SUNFLOWER Hg IMPELLER AFTER 2300 HR TEST

AREA I:
CAVITIES ON
HUB SURFACE

FIGURE 4A

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

0313587030

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 8 OF 18

The theoretical head of a centrifugal pump is predicted from principle of angular momentum.

Euler's Expression
$$H_i = \frac{C_2^2 - C_1^2}{2g} + \frac{U_2^2 - U_1^2}{2g} + \frac{W_1^2 - W_2^2}{2g}$$

Examine what happens to the theoretical head as erosion eats away the blades in various places.

U = Peripheral velocity of impeller

C = Absolute velocity of flow (Components C_m radial C_u tangent)

W = Relative velocity of flow (fluid relative to blade)

Assume W does not change significantly due to erosion.

Consider first 4 possible areas for erosion and its probable effect on performance.

Case 1)

Figure 5

erosion at outlet end of pump

$$H_{i_{\text{eroded}}} < H_{i_{\text{uneroded}}} \quad \text{for constant } Q$$

i.e.

Figure 6

~~CONFIDENTIAL~~

0313587030

0011507030

~~CONFIDENTIAL~~

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108
 DATE 10-14-63
 PAGE 9 OF 18

Cavitation Performance

Figure 7

Case 2)

Figure 8

This has no influence on the theoretical head but the pump capacity is decreased

Probable
effect
upon
performance

Figure 9

Figure 10

~~CONFIDENTIAL~~

0011507030

0315587030

~~CONFIDENTIAL~~

NO. NAA-SR-MEMO 9108
 DATE 10-14-63
 PAGE 10 OF 18

ATOMICS INTERNATIONAL
 A Division of North American Aviation, Inc.

Figure 11

This decreases the theoretical head for a given Q

Figure 12

and cuts considerably the cavitation performance.

Figure 13

Case 4) Erosion mid blade has little or no effect unless it creates a hole in the blade.

~~CONFIDENTIAL~~

0315587030

ATOMICS INTERNATIONAL
A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108
DATE 10-14-63
PAGE 11 OF 18

V) Actual Pump Cavitation Results

Experience shows* that cavitation damage reported in literature has occurred on the suction side at the leading edge as expected with the following results on performance:

Figure 14

Figure 15

Experience with pump inlet design and cavitation erosion has provided the following observations of cavitation in pumps and resultant conclusions for design.

Cavitation begins with formation of small bubbles at the leading edge.

Figure 16

As NPSH is further decreased, the phenomenon spreads until it forms a pattern as shown.

Figure 17

* See page 235, "Centrifugal and Axial Flow Pumps",
A. J. Stepanoff.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 12 OF 18

At this point in cavitation, there is no measurable degradation of pump performance.

From this point, further decrease in NPSH causes shedding of the pattern above and unstable cavitation patterns in the entire pump, blocking flow and creating measurable decay in pump performance. For this reason, the non-cavitating performance of the pump can be characterized by cavitation patterns anywhere between and including Figures 16 and 17. Since the cavitation renders the section of the blade covered by the pattern useless in turning the flow, it is reasonable to say that no obvious change in non-cavitating performance of a pump will be created by redesigning a pump blade whose leading edge takes the form of Figure 17, the critical cavitation pattern

Figure 18

This is verified by tests of Sunflower pump in which erosion ate away part of the blade which would have been covered by this critical pattern (see photograph) and the pump was tested parametrically and no measurable degradation was observed (Figure 19). In all CRU tests and Sunflower tests, the erosion has been less than Figure 17 and has not effected performance.

VI Jet Pump

So far we have discussed only centrifugal pump performance; our CRU, however, has a jet boost pump in series with the centrifugal pump and its influence is important to degradation. Of primary concern to the SNAP-2 is the jet pump which boosts the centrifugal pump inlet pressure (through momentum transfer from recirculated fluid from the centrifugal pump output) to reduce cavitation. The use of the boost pump is the primary factor which enables operation of a centrifugal pump, since the centrifugal pump would not operate at 6 psi NPSH (the condenser outlet pressure) due to cavitation. The use of a boost pump in a low NPSH system which requires high output pressures is common in industry. Axial flow inducer pumps are employed upstream of the main centrifugal pumps in liquid

~~CONFIDENTIAL~~

0371228030

~~CONFIDENTIAL~~

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 13 OF 18

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

rockets and jet pump boosters have been used for decades to help pump water from wells. The boost pump becomes the critical area for cavitation in most of these applications and has conformed to this trend in SNAP-2.

The performance of the SNAP-2 jet pump is described by M vs J cruves where

$$M = \frac{Q_{\text{pumped}}}{Q_{\text{driving}}} \quad J = \frac{\text{Head output}}{\text{Head input}} = \frac{H_n - H_s}{H_d - H_n}$$

The characteristic curve for the SNAP-2 jet pump is

Figure 20

Since Q_{driving} is only a nozzle loop

$$Q_{\text{driving}} = K C_n \sqrt{H_d - H_s}$$

where C_n = nozzle coefficient

~~CONFIDENTIAL~~

0313587030

~~CONFIDENTIAL~~

NAA-SR-MEMO 9108

10-14-63

Page 14 of 18

COMPONENT TEST CAVITATION PERFORMANCE JET-CENTRIFUGAL PUMPS

FIGURE 19

~~CONFIDENTIAL~~ 0313587030

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 15 OF 18

$$M = K (H_d - H_s)^{x-1/2}$$

Now examine (Figure 20) to see what effect change of H_d , the centrifugal pump output pressure, has upon the operation of the jet system.

We are looking for further changes in H_d (the centrifugal pump output pressure) which accompany small changes therein making the system unstable.

NOTE:

$$J = \frac{H_n - H_s}{H_d - H_n}$$

if $x > 1/2$, a small decrease in H_d decreases M and therefore increases H_n which is the inlet pressure to the pump

If $x < 1/2$, a small decrease in H_d increases M and therefore decreases H_n which further decreases H_d .

Since the slope of J vs M is very steep at the operating point, a small increase in M is self perpetuating and the system drives to $J = 0 = H_n$, i.e., the pump loses prime. We can see, therefore, that, if there is any degradation, for pump stability, the loop flows must vary more sensitively to the pressure than by the square root. Any component which tends to make PCS flows unaffected by pressures can only aggravate the problem.

One might ask why is not the CRU jet pump redesigned to avoid this characteristic. The answer, the pump was optimized to get the performance to be that good; i.e., that is just the best momentum transfer we can create.

~~CONFIDENTIAL~~

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO.

NA-ER-MEMO 9108

DATE 10-14-63

PAGE 16 OF 18

If jet pump degradation is to occur, it will probably be due to plugging. In fact, degradation has occurred on some instances due to clogging of the jet pump driving nozzle. As the jet nozzle clogs, the momentum transfer to the suction fluid decreases. As a result, the NPSH to the centrifugal pump is decreased and cavitation in the centrifugal pump increases causing the centrifugal pump to operate off design and worsening the effect.

The jet nozzle crudding was noticed as an instantaneous decrease in the pump output. This indicates a particle had clogged the nozzle. A thorough analysis of this phenomenon is available in an ASME Technical Paper to be presented to the ASME meeting in Philadelphia, Pennsylvania, in the Fall of 1963 by Messrs. C. W. Grennan and R. A. Lewis of TRW. It will suffice for this report to note that the particle of crud in the jet nozzle shifts the jet performance curve as:

This makes conditions worse at the jet pump and the previous analysis still holds.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

~~CONFIDENTIAL~~
UNCLASSIFIED

NO. ~~CONFIDENTIAL~~ NAA-SR-MEMO-9108

DATE 10-14-63

PAGE 17 OF 18

SUMMARY

- I. If the CRU mercury pump degrades, it will be caused by cavitation erosion or by plugging of the jet nozzle with crud.
- II. Cavitation erosion or jet plugging can increase substantially the NPSH required to prime but does not significantly effect the performance curves for our mercury pumps (i.e., ΔP vs flow) even for very severe erosion.
- III. Crudding of the jet pump nozzle results in less momentum transfer to the suction fluid, lower centrifugal pump NPSH, off design operation and hence erosion of the centrifugal pump, and loss of prime if the crudding is severe enough.
- IV. During two 90-day tests of CRU pumps, erosion was observed but when operated at on design flow, there was no significant blade erosion and when there was blade erosion, it was not sufficient to cause performance degradation.

~~CONFIDENTIAL~~

UNCLASSIFIED

0377281030

0315087030

~~CONFIDENTIAL~~

NO. NAA-SR-MEMO 9108

DATE 10-14-63

PAGE 18 OF 18

UNCLASSIFIED

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

VII Conclusions

From the previous brief presentation, it may be concluded that:

- 1) Centrifugal pump performance is not expected to degrade.
- 2) Jet pump performance could degrade by clogging of the driving nozzle if there is crud in the system.
- 3) If the centrifugal pump or the jet pump does degrade, any device which tends to keep system flows invariant to pump ΔP is harmful to the pump system and could cause complete loss of prime, dependent upon the operating point of the jet pump and the amount of degradation.

VIII List of Parameters

ΔP - Pressure gradient

NPSH - Net Positive Suction Head

Q - Flow rate

H_i - Head input theoretical

UNCLASSIFIED

~~CONFIDENTIAL~~

03170201030