23,226

HOME VENTILATION RATES: A LITERATURE SURVEY

T. H. Handley

C. J. Barton

MASTER

OAK RIDGE NATIONAL LABORATORY

OPERATED BY UNION CARBIDE CORPORATION • FOR THE U.S. ATOMIC ENERGY COMMISSION

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Contract No. W-7405-eng-26

ENVIRONMENTAL SCIENCES DIVISION

HOME VENTILATION RATES: A LITERATURE SURVEY

T. H. Handley and C. J. Barton

SEPTEMBER 1973

—NOTICE—

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
U.S. ATOMIC ENERGY COMMISSION

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

fig

.

.

.

.

.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	1
INTRODUCTION	1
MEASUREMENT OF EXCHANGE RATE	2
SUMMARIES OF IMPORTANT INVESTIGATIONS	3
Elkins and Wensman	3
Coblentz and Achenbach	4
Jordan, Erickson, and Leonard	5
Bahnfleth, Mosley, and Harris	6
Tamura and Wilson	6
ASHRAE Handbook Calculation	7
Laschober and Healy	7
Foreign Investigations.	8
Multiple Housing Units	8
CONCLUSIONS AND DISCUSSION	9
REFERENCES	12

HOME VENTILATION RATES: A LITERATURE SURVEY

T. H. Handley and C. J. Barton

ABSTRACT

A survey was made of published ventilation rates because this parameter has an important effect on doses to home occupants from airborne radionuclides. The survey was devoted primarily to information on ventilation of single housing units located in the United States including techniques used to measure the ventilation rate. Helium was found to be the most commonly used tracer gas. The available data suggest that the average annual ventilation rate of most occupied houses falls in the range 0.5 to 1.5 air changes per hour. We recommend that this range be adopted for calculations of doses resulting from home exposure to airborne radionuclides. Inclusion of apartments in modern high-rise buildings would raise the recommended upper limit to 2.0 air changes per hour if all ventilation air is from outside the building.

INTRODUCTION

Natural gas from wells stimulated by nuclear devices contains small amounts of ^3H (tritium) and ^{85}Kr .¹ Potential doses from tritium introduced hypothetically into the home with the natural gas have been calculated.¹⁻³ Since the annual doses usually calculated are a function of average air exchange rate, it is necessary to establish an annual average rate for homes under practical living conditions. Air exchange rate is defined as the hourly volumetric rate at which air enters (or leaves) the residence divided by the volume of the residence.⁴ In calculating potential yearly doses, we assumed that air in homes exchanged once every hour, but the validity of this assumption has been questioned.¹⁻³ In a study of doses in homes from radon in natural gas, we consider a range of exchange rates from 0.25 to 2.0 per hour.⁵

This literature survey was performed to determine whether data exists to justify a change in the rate presently used and to collect information on measurement methods.

Air is exchanged in residences either by natural infiltration or by ventilation. Natural infiltration results chiefly from leakage through cracks and interstices around doors and windows that normally is not controlled by residence occupants. Ventilation comprises the controlled displacement of air in the residence by either natural or mechanical means. Some of the variables affecting air exchange rate are inside-outside temperature differential, wind speed and direction, quality of residence construction and its design, topographical setting, and occupant activities.

MEASUREMENT OF EXCHANGE RATE

If the exchange rate is constant, the concentration of a tracer gas will decrease exponentially as indicated by the following equation:⁶

$$C = C_0 e^{-It}$$

where

C = concentration at time t ,

C_0 = concentration at $t = 0$,

t = time in hours,

I = air exchange rate per hour.

Various tracer gases, such as helium,^{4,10,11,18,19,21,27} ethane,⁶ sulfur hexafluoride,⁸ and inert radioactive gases,^{9,14,17} have been used to measure rates. Recently, sulfur hexafluoride has been the preferred

tracer gas because of the high sensitivity of detection of this nontoxic gas.⁸ In published work, helium is by far the most common tracer used. This choice probably resulted, at least in part, from development of a portable helium meter by the National Bureau of Standards.⁷ Helium is cheap, available, and nontoxic; however, the use of helium has been questioned, since it has a higher diffusion rate than air.¹⁰ One test was reported that compared exchange rates obtained with helium and ethane.²¹ Ethane has, for all practical purposes, the same density and diffusion rate as air. It was concluded that essentially the same rate was obtained with helium and ethane. The investigator stated that he was satisfied the rates obtained using helium were indicative of the actual air exchange rate and that no appreciable error was introduced by the use of helium. Other investigators have concluded that part of the exchange rate observed with no wind blowing and with no temperature differential, ranging from 0.05 to 0.19 per hour, may be due to the higher diffusion rate of helium as compared to air.¹¹ Helium does not stratify during determination of air exchange rates.¹⁰

SUMMARIES OF IMPORTANT INVESTIGATIONS

Elkins and Wensman⁶

Most measurements of air exchange rates of residences reported in the literature were not performed under practical living conditions. Elkins and Wensman measured air exchange rates in two identical modern residences in Canton, Ohio, occupied by families whose activities were not affected by the tests. One house is gas heated, while the other is all electric. All significant variables were monitored, including

weather conditions and occupant activities, such as door openings and appliance operation. Ethane tracer gas was used to measure the exchange rates. Tests were conducted during a period of approximately 10 months. The air exchange rate varied by a factor of about 3 from one day to the next. Observed exchange rates varied from 0.24 to 0.83 for the gas-fueled house, while the range was 0.13 to 0.42 for the all-electric house. Based on local weather data and American Society of Heating, Refrigerating, and Air-Conditioning Engineers' (ASHRAE) calculation methods,¹³ the estimated average rate for the gas-fueled house during a heating season was calculated to be 0.9 air exchange per hour.¹² This value was more or less confirmed by the fact that an exchange rate of 1.0 per hour was required for the ASHRAE¹³ calculation of the heat loss for the gas-heated house to be consistent with the measured heat losses over that period. Estimations of the average annual exchange rate for the two houses tested were made by assuming they were located in other cities with different annual average temperatures and wind speeds.¹² The investigator emphasized that these estimates are valid only for the test houses and are no better than the statistical limitations of the data. However, the estimates are internally consistent and reflect the difference in rates due to geographic location. Estimated rates for three of the cities are Chattanooga, 0.50; Spokane, 0.67; and Boston, 1.06 air exchanges per hour.¹²

Coblentz and Achenbach⁴

These investigators made field measurements in ten representative electrically heated houses in Indiana. The houses were described as one- and two-story brick and frame houses, built over basements, crawl

spaces, or concrete slabs on the ground. Five of the houses were practically new, while the ages of the others ranged from 20 to 46 years. The houses were unoccupied and outside openings were closed during the tests. Consequently, the measurements do not reflect a practical living situation. Two to four tests were made on each house over a 2-day period. The observed rates, adjusted to the design weather conditions, ranged from 0.54 to 1.45 air changes per hour. These values were in agreement with computed values based on the air change method described in the ASHRAE Guide¹³ which ranged from 0.6 to 1.5.

Jordan, Erickson, and Leonard¹⁹

An especially well-controlled and detailed study of air infiltration rates in two well-built research houses was reported by Jordan, Erickson, and Leonard. Heat was supplied by electricity, and heat contributed by a family and appliances was simulated by electrical heaters. Outer openings were kept closed during the measurements. The investigators concluded that, from a practical standpoint, the air infiltration rate can be taken as 0.33 per hour under almost all weather conditions for houses as well built as these and under conditions of no occupancy. However, during operation of appliances, the investigators reported an increase to values as high or higher than 1.5 air changes per hour. The investigators concluded that, within limitations of the tests, for tightly constructed and electrically heated houses, an air change rate of 0.75 per hour could be "safely" assumed for design purposes.

Bahnfleth, Mosley, and Harris¹⁰

Infiltration rates in two special research houses were measured and variables affecting infiltration were studied.²⁰ House 1 was a two-story structure with brick veneer and a basement, heated by a hot-water system; house 2 was a one-story frame building with full basement and a gas-fueled forced warm-air furnace. All outside doors and windows were closed during the tests. House 1 was occupied by 2 to 5 people, while house 2 was unoccupied. Measurements were made during an 8-month period. The observed infiltration for house 1 varied from 0.16 to 0.43 air change per hour, while house 2 ranged from 0.26 to 0.80 air change per hour. During discussions of an oral presentation of results of these studies at an ASHRAE²⁶ meeting, one of the investigators stated that tests on two additional houses resulted in infiltration rates of 1.5 to 3.0 changes per hour. The higher ventilation rates observed in these houses were attributed in part to poor quality of workmanship.

Tamura and Wilson¹¹

Tamura and Wilson measured the "air leakage" during all four seasons of two project-built houses located in Ottawa, Canada. Both are one-story five-room houses of insulated wood-frame construction with full basements. The houses are heated by a forced warm-air system with high-pressure gun-type oil burners. The houses were occupied, but occupant activities were not mentioned. All outside openings were kept closed during tests. During the winter, measured rates varied from 0.25 to 0.41 air change per hour in house 1 and 0.37 to 0.63 air change per

hour for house 2. During the summer, measured air change rates varied from 0.07 to 0.16 for house 1 and 0.11 to 0.23 for house 2.

ASHRAE Handbook Calculations¹³

Calculations of air exchange rate, using ASHRAE Handbook methods, have been made for a "characteristic" house located in the Baltimore-Washington area.²² By definition, the characteristic house has a gas-fired forced warm-air heating system and an air conditioning system. For houses of conventional construction, the air exchange rate was calculated to range from 1.3 to 1.7 per hour; industrial standard construction gave a calculated rate of 1.0 per hour. For houses built by controlled construction methods, the range was 0.33 to 0.67 per hour. Specific details of construction methods referred to were not defined.

Laschober and Healy²⁷

Laschober and Healy applied statistical analysis methods to measurements of infiltration rates made during a heating season in two split-level research houses. The average test period duration was 1.5 hr, and all windows and doors were closed during the tests. No ventilation or exhaust fans were used during the tests. The average air change rate in a house heated with a gas-fired hot-water system was 1.19 changes per hour (range, 0.32-2.67). The heating system of the other house is described as a full perimeter air distribution system used in conjunction with a gas-fired or electric furnace. Separate tests were made with each furnace. The average rate for electric heating was 0.61 (range, 0.20-1.60), while the average during heating with gas was 0.84 (range, 0.30-1.79). The difference in average values

(0.23) is very close to the calculated increase in air leakage (0.19) during operation of the gas furnace from air used to burn gas.

Foreign Investigations

Investigators in foreign countries have, in general, used the same techniques as those described in this survey.^{9,15-18} Their objectives are similar to ours: to optimize design of heating systems and to measure heat losses. Due to differences in house design and possible differences in occupant activities, results of studies in foreign countries are not considered in this survey.

Multiple Housing Units

This review is limited to the single family residential unit. It is not possible to cover every one of the many residential types, especially since some of them are not represented in the literature on ventilation rates. However, because increasing numbers of people are living in modern high-rise apartment complexes, this type of residence cannot be ignored. Air change in this type of residence is controlled mainly by mechanical means, and we did not find field test results of single units in a complex of units. Many communities rely on the Building Officials Conference of America (BOCA)'s Basic Building Code²⁵ to establish standards for regulation of high-rise apartment complexes. The BOCA Code requires a minimum fresh air supply for living rooms and bedrooms of 2 air changes per hour; 3 air changes per hour are required for kitchens and 5 air changes per hour are required for bathrooms. A more recent code²⁸ requires that air temperature control systems be capable of providing 2 air changes per hour and that at least one-fifth

of the air supply be taken from the outside. Jennings and Armstrong²⁹ discussed the importance of recirculated air in ventilation practice, but we have not considered this situation in our study. Our recommended value of two air changes per hour for apartments is based on the assumption that all ventilation air comes from outside the building.

CONCLUSIONS AND DISCUSSION

We suggest a range of 0.5 to 1.5 air changes per hour be used for calculation of dose from exposure to tritium and other radionuclides introduced into the home with natural gas. Available data are insufficient to assign a single value for an average or characteristic occupied house.

This conclusion is based on the following reasoning. An infiltration rate of about 0.3 per hour has been reported for well-built unoccupied research houses.^{10,19} This is more or less confirmed by calculated infiltration rates of 0.3 to 0.6 per hour, using ASHRAE methods, for a "characteristic" house, assuming controlled construction techniques.²² Further confirmation was obtained by private communication with professional investigators in this field who are presently involved in measuring exchange rates. They stated that a rate of 0.3 per hour would be very difficult to maintain under practical living conditions.²³ A statement was also made that an infiltration rate of 0.3 per hour could be assigned to the research house, but that this value would be valid only for low wind speed and a low temperature differential.²⁴ A practical living situation should result in an exchange rate higher than the infiltration rate observed for unoccupied research houses or

infiltration rates calculated from design considerations. This was confirmed by Elkins¹² who reported 0.5 to 1.0 air change per hour (adjusted to local wind speeds) for a modern well-built house that is occupied. Therefore, use of the lower limit of 0.5 air change per hour is suggested.

Assignment of 1.5 air changes per hour for the upper limit is made on the following basis. Infiltration rates for ten representative houses, adjusted to local wind speeds, ranged from 0.54 to 1.45.⁴ Ages of five houses in this group ranged from 20 to 46 years. Many houses are older and these cannot be ignored. The higher value of 1.45 air changes per hour probably means that the older houses have a higher rate as compared to modern well-built houses. Based on ASHRAE methods, calculated infiltration rates for a "characteristic" house (assuming conventional construction methods) are reported to range from 1.3 to 1.7 air changes per hour.²² The rate for a specific house will vary with location due to local wind speeds¹² and may vary as much as a factor of 2. For design purposes, a rate of 0.75 has been recommended for all-electric houses,¹⁹ while gas-fueled houses would have a higher rate.²¹ It has been suggested that a yearly average infiltration rate of 1.0 is reasonable from a practical standpoint.^{12,23,24} Because activities of house occupants cannot be regimented and builders may be careless in implementing designed characteristics of a house, it is the opinion of the reviewers that rates for occupied houses are likely to be higher than rates based on design. Therefore, 1.5 air changes per hour is suggested as a conservative upper limit for the annual average ventilation rate in individual United States homes. It should be recognized that, because pollutants introduced into home atmospheres

are removed by ventilation at an exponential rate, the average of doses calculated for the ends of the suggested air change range is not equal to the dose calculated using the mid-range value of 1.0 air change per hour.

Based on the design ventilation rates in the BOCA Building Code, 2.0 air changes per hour is suggested as an average rate for calculations of doses received by occupants of apartments in modern high-rise apartment complexes if all the ventilation air is from outside the building.

REFERENCES

1. C. J. Barton, D. G. Jacobs, M. J. Kelly, "Radiological Considerations in the Use of Natural Gas from Nuclearly Stimulated Wells," *Nuclear Technol.* 11, 335 (1971).
2. C. J. Barton, R. E. Moore, and S. H. Hanna, *Quarterly Progress Report on Radiological Safety of Peaceful Uses of Nuclear Explosions: Hypothetical Exposures to Radon Gas*, ORNL-TM-3601 (October 1971).
3. D. G. Jacobs, E. G. Struxness, M. J. Kelly, and C. R. Bowman, "Consideration of the Radiological Impact from the Hypothetical Use of Contaminated Natural Gas from Nuclearly Stimulated Reservoirs," *Health Physics* 22, 429 (1972).
4. C. W. Coblenz and P. R. Achenbach, "Field Measurements of Air Infiltration in Ten Electrically Heated Houses," *ASHRAE Journal* 5, 69 (1963).
5. C. J. Barton, R. E. Moore, and P. S. Rohwer, *Contribution of Radon in Natural Gas to the Natural Radioactivity Dose in Homes*, ORNL-TM-4154 (1973).
6. P. H. Elkins and C. E. Wensman, "Natural Ventilation of Modern Tightly Constructed Homes," Conference on Natural Gas Research and Technology, American Gas Association, Inc., and Institute of Gas Technology, Chicago, Illinois, February 28 - March 3, 1971.
7. C. W. Coblenz and P. R. Achenbach, "Design and Performance of a Portable Infiltration Meter," *Trans. ASHRAE* 63, 477 (1957).
8. F. J. Powell, Chief of Thermal Engineering Systems, National Bureau of Standards, Washington, D. C., private communication with T. H. Handley, Oak Ridge National Laboratory, January 3, 1973.

9. A. H. Howland, D. E. Kimber, and R. F. Littlejohn, "Measurements of Air Movements in a House Using a Radioactive Tracer Gas," *Institute of Heating and Ventilating Engineers Journal* 28, 57 (1960).
10. D. R. Bahnfleth, T. D. Mosley, and W. S. Harris, "Measurement of Infiltration in Two Residences, Part 1: Technique and Measured Infiltration," *Heating, Piping, and Air Conditioning* 29(6), 165 (1957).
11. G. T. Tamura and A. G. Wilson, "Air Leakage and Pressure Measurements on Two Occupied Houses," *ASHRAE Journal* 5, 65 (1963).
12. R. H. Elkins, Institute of Gas Technology, private communication with T. H. Handley, Oak Ridge National Laboratory, February 1, 1973.
13. *ASHRAE Handbook of Fundamentals*, American Society of Heating, Refrigerating, and Air Conditioning Engineers, New York, 1967.
14. Martha Gerrard, "Measurement of Ventilation Rates with Radioactive Tracers," *ASHRAE Journal* 10, 47 (1968).
15. J. B. Dick and D. A. Thomas, "Ventilation Research in Occupied Houses," *The Institute of Heating and Ventilating Engineers Journal* 19, 279-305 (1951).
16. J. B. Dick, "Experimental Studies in Natural Ventilation of House," Department of Scientific and Industrial Research, Building Research Station Note No. 180, Garston, Watford, England.
17. B. G. Collins and D. B. Smith, "The Measurement of Ventilation Rates Using a Radioactive Tracer," *The Institute of Heating and Ventilating Engineers Journal* 23, 270 (1955).

18. J. B. Dick, "Measurement of Ventilation Using Tracer Gas Technique," *Heating, Piping, and Air Conditioning* 22(5), 131 (1950).
19. R. C. Jordan, G. A. Erickson, and R. R. Leonard, "Infiltration Measurements in Two Research Homes," *ASHRAE Journal* 5, 71 (1963).
20. D. R. Bahnfleth, T. D. Mosely, and W. S. Harris, "Measurement of Infiltration in Two Residences, Part II: Comparison of Variables Affecting Infiltration," *Heating, Piping, and Air Conditioning* 29(7), 159 (1957).
21. C. W. Coblentz, discussion of the paper, "Field Measurement of Air Infiltration in Ten Electrically Heated Houses," *ASHRAE Transactions* 69, 358 (1963).
22. Department of Housing and Urban Development, Office of the Assistant Secretary for Research and Technology, *Residential Energy Consumption--Phase 1 Report*, Report No. HUD-HAI-1 (1972).
23. F. J. Powell, Chief of Thermal Engineering Systems, National Bureau of Standards, private communication with T. H. Handley, Oak Ridge National Laboratory, January 1973.
24. C. Hunt, Thermal Engineering Systems, National Bureau of Standards, private communications, with T. H. Handley, Oak Ridge National Laboratory, February 1973.
25. Building Officials Conference of America, Incorporated, *BOCA Basic Building Code*, "Article 5, Light and Ventilation," Fourth Edition, Owl Printing Company, Chicago, Illinois, 1970.
26. W. S. Harris, discussion of the paper, "Field Measurement of Air Infiltration in Ten Electrically Heated Houses," *ASHRAE Transactions* 69, 358 (1963).

27. R. R. Laschober and J. H. Healy, "Statistical Analyses of Air Leakage in Split-Level Residences," *ASHRAE Transactions* 70, 364 (1964).
28. International Conference of Building Officials, *Uniform Building Code*, Vol. 1, 1970 Edition, Pasadena, California.
29. B. H. Jennings and J. A. Armstrong, "Ventilation Theory and Practice," *ASHRAE Journal* 77, Part I (1971).

1

2

3

4

5

INTERNAL DISTRIBUTION

1. H. H. Abee	81. L. R. McKay
2. W. D. Arnold	82. D. J. Nelson
3-27. S. I. Auerbach	83. Carol Oen
28. J. A. Auxier	84. R. V. O'Neill
29. B. G. Blaylock	85. D. E. Reichle
30. F. T. Binford	86. P. S. Rohwer
31. Wm. J. Boegly	87. W. S. Snyder
32-56. C. J. Barton	88-112. E. G. Struxness
57. C. C. Coutant	113. F. G. Taylor
58. K. E. Cowser	114. J. R. Totter
59. D. J. Crouse	115. J. R. Trabalka
60. R. C. Dahlman	116. R. I. Van Hook
61. S. Draggan	117. W. Van Winkle
62. C. W. Francis	118. J. P. Witherspoon
63. D. M. Davis	119. A. D. Warden
64. F. L. Culler	120-121. Biology Library
65. D. E. Ferguson	122-123. Central Research Library
66. A. B. Fuller	124-126. Laboratory Records Dept.
67-71. T. H. Handley	127-128. Technical Information Center
72. J. W. Huckabee	129. ORNL Y-12 Technical Library
73. R. E. Moore	130. Document Reference Section
74-78. S. V. Kaye	131. Laboratory Records, ORNL, R.C.
79. J. E. Kahn	132. ORNL Patent Office
80. J. T. Kitchings	

EXTERNAL DISTRIBUTION

133. Charles Atkinson, U.S. Bureau of Mines, Bartlesville Petroleum Research Center, Bartlesville, Oklahoma 74004.
134. J. A. Blasy, Division of Applied Technology, U.S. Atomic Energy Commission, Washington, D.C. 20545.
135. Martin B. Biles, Director, Division of Operational Safety, U.S. Atomic Energy Commission, Washington, D.C. 20545.
- 136-140. Eddie W. Chew, El Paso Natural Gas Co., P. O. Box 1492, El Paso, Texas 79999.
141. Carter D. Broyles, Department Manager, Test Sciences (7110), Sandia Corp., P. O. Box 5800, Albuquerque, N.M. 87115.
142. D. S. Barth, National Environmental Research Center, EPA, P. O. Box 15027, Las Vegas, Nevada 89114.
143. C. D. Catt, El Paso Natural Gas Company, P. O. Box 1492, El Paso, Texas 79999.
144. George A. Cowan, Los Alamos Scientific Laboratory, P. O. Box 1663, Los Alamos, N.M. 87544.

145. Richard Cunningham, Division of Materials Licensing, U.S. Atomic Energy Commission, Bethesda, Md. 20014.
146. Harold J. Groh, Jr., Separations Chemistry, Savannah River Laboratory, E. I. duPont de Nemours and Company, P. O. Box "A", Aiken, South Carolina 29802.
147. K. Z. Morgan, School of Nuclear Engineering, Georgia Institute of Technology, Atlanta, Georgia 20332.
148. J. W. Healy, Health Physics Division, Los Alamos Scientific Laboratory, Box 1663, Los Alamos, N.M. 87544.
149. Bennie DiBona, Director, Division of Peaceful Applications, Nevada Operations Office, U.S. Atomic Energy Commission, P. O. Box 1676, Las Vegas, Nevada 89101.
150. John Heslep, Chief, Environmental Safety and Consumer Protection Program, State Department of Public Health, 2151 Berkeley Way, Berkely, Calif. 94704.
- 151- Gary H. Higgins, K. Division, Lawrence Livermore Laboratory, P. O.
152. Box 808 (L-41), Livermore, Calif. 94551.
153. George Hinman, Gulf General Atomic, Box 608, San Diego, Calif. 92112.
154. I. A. Hobbs, Director, Technical and Production Division, Savannah River Operations Office, P. O. Box "A", Aiken, South Carolina 29802.
155. John B. Hursh, Department of Radiation Biology and Biophysics, University of Rochester, Rochester, N.Y. 14620.
- 156- Edward H. Fleming, Assistant Director, Division of Applied
167. Technology, U.S. Atomic Energy Commission, Washington, D. C. 20545.
168. Paul Kruger, Professor of Nuclear Chemistry, Department of Civil Engineering, Stanford University, Stanford, Calif.
169. Dwight Lemmon, Assistant Chief Geologist for Economic Geology, U.S. Geological Survey, Department of the Interior, Washington,, D.C. 20240.
170. Dan Marostica, Pacific Lighting Service Company, 720 W. Eighth Street, Los Angeles, Calif. 90017.
171. Richard Grove, Materials Licensing, U.S. Atomic Energy Commission, Bethesda, Md. 20014.
172. M. L. Merritt, Underground Physics Division (5332), Sandia Corp., Albuquerque, N. M. 87115.
173. Mahlon Gates, Manager, Nevada Operations Office, U.S. Atomic Energy Commission, P. O. Box 1676, Las Vegas, Nevada 99101.
174. Neldon Jensen, Physical Science Administrator, Office of Assistant Director — Planning, U.S. Bureau of Mines, Dept. of Interior, Washington, D.C. 20240.
175. Director, Explosive Excavation Research Office, Corps of Engineers, Lawrence Livermore Laboratory, P. O. Box 808 (L-396), Livermore, California. 94551.
176. Lee Aamodt, Los Alamos Scientific Laboratory, P. O. Box 1663, Los Alamos, N. M. 87544.
177. C. C. Palmiter, Office of Radiation Programs, Environmental Protection Agency, Rockville, Md. 20852.

178. F. J. Parsons, Pacific Gas and Electric Company, 245 Market Street, San Francisco, Calif. 94106.
179. L. M. Muntzing, Director of Regulation, U.S. Atomic Energy Commission, Bethesda, Md. 20014
180. J. Ramsey, U.S. Bureau of Mines, Washington, D.C. 20240.
181. P. L. Randolph, El Paso Natural Gas Co., P. O. Box 1492, El Paso, Texas 79999.
182. Lester R. Rogers, Director of Regulatory Standards, U.S. Atomic Energy Commission, Bethesda, Md. 20014.
183. Paul Russell, Research Director, Denver Mining Research Center, U.S. Bureau of Mines, Denver Federal Building, Denver, Colorado 80225.
184. Lewis M. Schalit, Systems, Science and Software, P. O. Box 1620, La Jolla, Calif. 92037.
185. Clifford S. Selvage, Manager, Advance Systems Research Department 1, Sandia Corp., P. O. Box 969, Livermore, Calif. 94550.
186. Harold Sohns, U.S. Bureau of Mines, Laramie Petroleum Research Center, Laramie, Wyoming 82071.
187. R. H. Thalgott, Test Manager, Nevada Operations Office, U.S. Atomic Energy Commission, P. O. Box 1676, Las Vegas, Nevada 89101.
188. Donald Gilbert, Director, Arizona Atomic Energy Commission, 40 East Thomas Road, Suite 107, Pheonix, Arizona 85012.
189. William S. Twenhofel, U.S. Geological Survey, Federal Center, Denver, Colorado 80225.
190. B. H. Van Domelen, Governor's Science Adviser, Sandia Laboratory, 1820, Albuquerque, N. M. 87115.
191. J. Wade Watkins, Chief, Division of Petroleum and Natural Gas, U.S. Bureau of Mines, Department of the Interior, Washington, D.C. 20240.
- 192- Glenn C. Werth, Associate Director for Plowshare, Lawrence
195. Livermore Laboratory, P. O. Box 808 (L-13), Livermore, Calif. 94551.
196. Research and Technical Support Division, U.S. Atomic Energy Commission, Oak Ridge Operations.
197. Ronald A. Siddons, United Kingdom Atomic Energy Authority, Weapons Research Establishment, Berkshire, England.
198. C. F. Smith, Jr., Lawrence Livermore Laboratory, P. O. Box 808, Livermore, Calif. 94551.
199. Miles Reynolds, Austral Oil Company, 2700 Humble Bldg., Houston, Texas 77002.
200. Sam Ross, Public Service Co. of Colorado, Denver, Colo. 80220.
201. John Hassoldt, Public Service Co. of Colorado, Denver, Colorado 80220.
202. John Reed, Rocky Mountain Natural Gas Company, P. O. Box 700, Glenwood Springs, Colorado 81601.
203. Fred P. Wehrle, Colorado Interstate Gas Company, P. O. Box 1087, Colorado Springs, Colorado 80901.
204. Howard Tewes, Lawrence Livermore Laboratory, P. O. Box 808, Livermore, Calif. 94551.
205. G. W. Frank, Austral Oil Co., 2700 Humble Bldg., Houston, Texas 77002.

- 206- Howard Frederickson, Colorado Interstate Gas Co., Colorado Springs,
210. Colorado 80901.
- 211. G. Edwin Brown, Jr., Management Consultant, P. O. Box 253, New
Canaan, Conn. 06840.
- 212. Abraham S. Goldin, Kresge Center for Environmental Health, Harvard
University, School of Public Health, Boston, Mass. 02100.
- 213. Warren Donnelly, Library of Congress, Legislative Reference Service,
Washington, D.C. 20504.
- 214. R. D. Siek, Colorado Department of Health, 4210 East 11th Avenue,
Denver, Colorado 80220.
- 215. James E. Sohngen, Atomic Industrial Forum, Inc., 475 Park Avenue,
New York, N. Y. 10016.
- 216. W. H. Pennington, Division of Biomedical and Environmental Research,
U.S. Atomic Energy Commission, Washington, D.C. 20545.
- 217. Andre Bouville, United Nation, Scientific Committee on the Effects
of Atomic Radiation, New York, N.Y. 10016.
- 218. Paul J. Cory, Office of the Secretary of Transportation, Washington,
D.C. 20590.
- 219. James Yates Pauling, President, Anistics, Inc., 260 Madison Avenue,
New York, N.Y. 10016.
- 220. Seymour Shwiller, Staff Member, Joint Committee on Atomic Energy,
Congress of the United States, Washington, D.C. 20510.
- 221. D. C. Morse, Gulf General Atomic, P. O. Box 608, San Diego,
Calif. 92112.
- 222. David S. Smith, Office of Radiation Programs, Environmental
Protection Agency, Rockville, Md. 20852.
- 223. S. R. Hanna, Air Resources Atmospheric Turbulence and Diffusion
Laboratory, NOAA, Oak Ridge, Tennessee 37830.
- 224. F. A. Gifford, Jr., Air Resources Atmospheric Turbulence and
Diffusion Laboratory, NOAA, Oak Ridge, Tennessee 37830.
- 225. G. R. Luetkehans, CER-Geonuclear Corp., 120 East Flamingo Road,
Las Vegas, Nevada 89109.
- 226. Jack G. Christian, Office of Radiation Programs, Environmental
Protection Agency, Rockville, Md. 20852.
- 227. Murray Calkins, National Environmental Research Center, Environ-
mental Protection Agency, Cincinnati, Ohio.
- 228. David S. Ballantine, Division of Biological and Environmental
Research, U.S. Atomic Energy Commission, Washington, D.C. 20545.
- 229. Randolph R. Newton, Division of Biological and Environmental
Research, U.S. Atomic Energy Commission, Washington, D.C. 20545.
- 230. M. M. Williamson, Division of Applied Technology, U. S. Atomic
Energy Commission, Washington, D. C. 20545.

OAK RIDGE NATIONAL LABORATORY

OPERATED BY
UNION CARBIDE CORPORATION
NUCLEAR DIVISION

POST OFFICE BOX X
OAK RIDGE, TENNESSEE 37830

SPECIAL 4TH CLASS RATE BOOKS

If a change of address is needed, indicate the change, include the zip code, and identify the document; tear off this cover and return it to the above address.