50
st. Reeder
9/26
1

GEAP-5635
AEC RESEARCH AND
DEVELOPMENT REPORT
JUNE 1968

A Distr.
journal

162

244

MASTER

SIGNIFICANCE OF NEUTRON DATA UNCERTAINTIES TO FAST REACTOR ECONOMICS AND POWER PLANT DESIGN

P. GREEBLER
B.A. HUTCHINS
R.B. LINFORD
B. WOLFE

U.S. ATOMIC ENERGY COMMISSION
CONTRACT AT (04-3)-189
PROJECT AGREEMENT 10

ADVANCED PRODUCTS OPERATION

GENERAL ELECTRIC

SUNNYVALE, CALIFORNIA

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

SIGNIFICANCE OF NEUTRON DATA UNCERTAINTIES TO
FAST REACTOR ECONOMICS AND POWER PLANT DESIGN

P. Greebler
B. A. Hutchins
R. B. Linford
B. Wolfe

R. E. Skavdahl

R. E. Skavdahl, Project Engineer
Fast Ceramic Reactor Development Program

E. L. Zebroski

E. L. Zebroski, Manager
Sodium Reactor Technology

Prepared for the
U. S. Atomic Energy Commission
Under Contract AT(04-3)-189
Project Agreement 10

Printed in U.S.A. Available from the
Clearing House for Federal Scientific and Technical Information
National Bureau of Standards, U.S. Department of Commerce
Springfield, Virginia
Price: \$3.00 per copy

ADVANCED PRODUCTS OPERATION

GENERAL ELECTRIC

SUNNYVALE, CALIFORNIA

5636-APO-28
190-AT-6/68

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:
A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
B. Assumes any liability with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.
As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor, prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

- A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or*
- B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.*

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	v
1.0 INTRODUCTION	-1-
2.0 FAST REACTOR PARAMETERS CONSIDERED	-1-
3.0 MAJOR DATA UNCERTAINTIES	-2-
4.0 FUEL COST COMPONENTS—EXAMPLES OF SENSITIVITY TO SPECIFIC DATA UNCERTAINTIES	
5.0 SENSITIVITY RESULTS FOR LOW LEAKAGE REACTOR	-5-
6.0 SENSITIVITY RESULTS FOR HIGH LEAKAGE REACTOR	-6-
7.0 SUMMARY OF SPECIFIC DATA COST UNCERTAINTIES	-7-
8.0 ACCURACY GOALS FOR NUCLEAR DATA MEASUREMENTS	-9-
9.0 ENGINEERING DESIGN ALTERNATIVES TO COUNTERACT ADVERSE DATA	-11-
10.0 IMPLICATIONS OF FAST REACTOR UNCERTAINTIES ON THE REACTOR ECONOMY	-12-
APPENDIX	-14-
REFERENCES	-17-
DISTRIBUTION LIST	-20-

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1	1000 MWe, Sodium-Cooled, Fast Reactors	-2-
2	Main Uncertainties for Pu-239 and U-238	-3-
3	Component Fuel Costs (mills/kWh)	-4-
4	Cost and Doubling Time Uncertainty Ranges	-5-
5	Doppler and Total Sodium Void Uncertainty Ranges	-6-
6	Uncertainty Ranges (1.5-foot Core)	-7-
7	Fuel Cost Uncertainty Span (mills/kWh) for Pu-239 and U-238 Data	-8-
8	Fuel Cost Uncertainty Span (mills/kWh) for Higher Pu Isotopes and Fission Products	-8-
9	Fuel Cost Uncertainty Span (mills/kWh) for Sodium, Steel, and Tantalum	-9-
10	Targets for Data Accuracy	-10-
11	Core Design Changes to Counteract High Pu-239 Alphas	-12-
12	Data Uncertainties	-14-
13	Uncertainties for Pu-239 Alpha Values	-15-

ABSTRACT*

An evaluation of the sensitivity of physics parameters and fuel costs of fast power reactors indicates that combined current data uncertainties produce about a ± 0.15 mill/kWh uncertainty in fuel cost for a sodium-cooled, fast reactor whose design has not been severely limited by requirements on the sodium void and Doppler reactivity effects. For a reactor that must satisfy stringent sodium void and Doppler reactivity requirements, the combined data uncertainties produce about a ± 0.25 mill/kWh uncertainty in fuel cost. The current large uncertainty in the Pu-239 alpha value below 15 keV is the largest single contributor to the overall fuel cost uncertainty, with the uncertainties in U-238 radiative capture cross sections and Pu-239 $\bar{\nu}$ being next in importance. A set of targets for nuclear data accuracy is recommended, on the basis of the calculated sensitivity of fuel cost to specific data uncertainties, which would reduce the calculated fuel cost uncertainty to about ± 0.03 mill/kWh.

Design modifications and associated development programs to improve fuel and heat transfer-fluid flow performance will be required for sodium-cooled, fast reactors in the event of appreciably adverse nuclear data, if specific performance targets, such as low fissile doubling time (~ 10 years), are to be achieved. The uncertainties in performance, date of introduction, and need for additional development of fast reactors because of data uncertainties have large enough economic implications for the total reactor economy to justify an intensive effort to reduce these uncertainties.

* The results described in this report were presented in papers given at the 1967 Meeting of the American Nuclear Society, Chicago, Illinois, November 5-9, 1967; and at the Conference on Neutron Cross Sections and Technology, Washington, D.C., March 4-7, 1968.

1.0 INTRODUCTION

Fast reactor designers are concerned about nuclear data uncertainties for two reasons. One is the uncertainty that it produces in our projections of fast breeder reactor power costs, mainly in the plutonium credit and plutonium inventory components of the fuel cost. A large economic uncertainty results from these data uncertainties because they tend to obscure the role fast breeders will play in the future reactor economy. A second concern is for the design of the early-generation fast breeder power plants and the uncertainty in reactivity coefficients and other reactor performance characteristics associated with the data uncertainties.

A first step in the assessment of effects on fuel costs is the determination of the sensitivity of fast reactor parameters affecting fuel and capital costs to arbitrary changes in each of the neutron cross sections that are important for fast reactors. (For example, the change in fissile inventory, breeding ratio, safety characteristics, and other quantities that ultimately affect the power cost of a fast reactor can be determined for a 10% increase in each important cross section over some small lethargy interval.) Such information is useful for establishing accuracy requirements for cross section measurements. Studies of the sensitivity of physics parameters of fast reactors to such changes in cross sections have been described by Moorhead,⁽¹⁾ Greebler and Hutchins,⁽²⁾ and R. D. Smith.⁽³⁾

A second step involves the evaluation of the magnitude of the uncertainty in each of the cross sections and from this, the determination of the uncertainty range in presently predicted fast reactor physics parameters (and in the associated power costs) which is caused by the individual cross section data uncertainties, as well as their combined effect. Completion of these first two steps not only gives the uncertainty

in predicted power cost resulting from inadequate data accuracy, but also indicates to the cross section measurers what data most urgently need their attention.

The third step involves the consideration of core design alternatives that may be adopted to satisfy advanced performance targets in the event of adverse data, and to an assessment of the resulting uncertainties in the projected reactor economy.

2.0 FAST REACTOR PARAMETERS CONSIDERED

Table 1 shows parameters of two sodium-cooled, oxide-fueled, 1000 MWe fast reactors which were used as models for the determination of the sensitivity of the fuel cost to uncertainties in nuclear data.

The low leakage reactor has a 2.5-foot core height which was selected on the basis of thermal-hydraulics and economics considerations, and not because of the sodium void reactivity effect. It has very good neutron economy as indicated by the breeding ratio of almost 1.4 and the less than 10-year fissile doubling time. The fuel cost is calculated to be 0.5 mill/kWh. The cost components most sensitive to the nuclear data uncertainties are the plutonium credit and the plutonium inventory, and these are based on a fissile plutonium value of \$10/gm, a 10% per annum fuel use charge, and an 80% load factor. The Doppler coefficient ($-T dk/dT$) with coolant out of the reactor is just under 0.004, and total loss of sodium results in a 1.2% reactivity increment. Since the limitations on the design that may be imposed by the sodium voiding reactivity problem are not yet fully understood, the low leakage reactor of Table 1 has to be classified as an advanced reactor.

The second reactor in Table 1, having a 1.5-foot core height, is a more conservative safety design with regard to the sodium

TABLE 1

1000 MWe, SODIUM-COOLED, FAST REACTORS

	<u>Low Leakage</u>	<u>High Leakage</u>	<u>Comments</u>
Power (MWt)	2500	2500	
Core Height (ft)	2.5	1.5	Blankets—18-inch Axial; 12-inch Radial
Core Diameter (ft)	8.0	10.8	
In-Pile Fissile Pu (kg)	2360	2710	Add 30% out-of-pile
Breeding Ratio	1.38	1.28	
Doubling Time (year)	9.2	14.7	
Fuel Cost (mills/kWh)	0.50	0.70	\$10/gm fissile Pu*
Doppler—Sodium-Out ($-T dk/dT$)	0.0038	0.004	3.4 vol% BeO in high leakage reactor
Coolant Loss Reactivity (Δk)	+ 0.012	-0.001	
Core Volume Composition Fuel/Na/Steel/BeO/Ta)	42.4/39.2/ 17.7/0/0.7	36/40/20/3.4/0.6	

*Also 10% fuel inventory interest rate, 80% load factor, \$200/kg fabrication for 2.5-foot core and \$230/kg for 1.5-foot core, \$30/kg fabrication for axial blanket, and \$25/kg for radial blanket, \$55/kg for reprocessing, 1.15×10^5 MWd/Te fuel burnup.

voiding reactivity problem. It was required for this reactor that the reactivity from total sodium voiding be zero (or negative) and, further, that the negative Doppler coefficient with sodium-out be at least 0.004. This requires a core with a high neutron leakage, in this case produced by having a core of only 18-inch height. It also requires addition of a small amount of moderating material, 3.4 volume percent BeO, to degrade the neutron spectrum. The imposition of these stringent safety criteria penalizes the neutron economy, as noted from the higher fissile inventory, lower breeding ratio, longer doubling time, and higher fuel cost, compared with the low leakage reactor. Imposition of these requirements on the Doppler and sodium void coefficients also affects the sensitivity of the fuel cost to the nuclear data uncertainties; and that is why these two different sodium-cooled, fast reactor designs are considered here.

3.0 MAJOR DATA UNCERTAINTIES

Table 2 indicates data uncertainties for Pu-239 and U-238, the two isotopes which have the most significant uncertainties for the fast reactors whose properties are described in Table 1. The second column of Table 2 shows the energy region where each of these reaction type data uncertainties is greatest and has the largest effect on the calculated reactor parameters. The magnitude of the uncertainty is illustrated in the third column of Table 2 by the range of variation in the cross section value at some energy point within the specified energy range. The reference cross section value in each case is that recommended for the ENDF/B nuclear data files.⁽⁴⁾

One of the largest and most significant data uncertainties for a large, ceramic-fueled, fast power reactor is that of the

TABLE 2

MAIN UNCERTAINTIES FOR PU-239 AND U-238

<u>Data Type</u>	<u>Most Important Energy Interval</u>	<u>Example of Uncertainty</u>	<u>Correlation Intervals</u>
Pu-239 Alpha	0.2—15 keV	0.6 to 1.3 at 1 keV	2 ($\lesssim$ 15 keV)
Pu-239 σ_f	15—300 keV	1.5 to 1.8 at 50 keV	2 ($\lesssim$ 0.3 MeV)
Pu-239 $\bar{\nu}$	0—300 keV	2.8 to 2.92 at 1eV	1 ($<$ 10 MeV)
U-238 σ_c	10—100 keV	0.5 to 0.75 at 20 keV	2 ($\lesssim$ 0.1 MeV)
U-238 σ_{inel}	0.1—2 MeV	2.0 to 2.6 at 1 MeV	2 ($\lesssim$ 2 MeV)
U-238 σ_f	2—6 MeV	0.5 to 0.6 at 4 MeV	1 ($>$ 2 MeV)

Pu-239 alpha value below 15 keV. The Doppler effect is very sensitive to this uncertainty, and so the fuel cycle cost is especially sensitive to it in a reactor where the calculated Doppler coefficient only marginally exceeds a minimum value imposed by safety criteria, like the high leakage reactor of Table 1. Fissile inventory costs are very sensitive to the Pu-239 fission cross section values. The most significant uncertainty in $\bar{\nu}$ for Pu-239 is in the absolute normalization at low energy, with the uncertainty in the slope $d\bar{\nu}/dE$ being of lesser importance. The large uncertainties in U-238 capture cross sections have considerable significance for the sodium void reactivity effect and for the breeding ratio and other physics parameters that directly affect the fuel cycle cost.

Calculated uncertainties in physics parameters and costs are highly sensitive to the degree of correlation assumed in the data uncertainties. The right-hand column of Table 2 shows the number of energy intervals that were used for each reaction type, with data assumed to be correlated within each of the energy intervals listed. It was assumed that the data uncertainties are correlated for each type of data within rather wide energy intervals, as indicated in Table 2. For example, the high U-238 σ_c

data below 0.1 MeV use the highest reasonable data over this entire energy interval; but are not assumed to be correlated with the highest U-238 σ_c data in the interval above 0.1 MeV. (The energy intervals actually used for U-238 σ_c were 1 to 100 keV and 0.1 to 10 MeV.) The cross section uncertainties were assumed to be correlated within wide energy intervals because the disagreements between different cross section measurements appear to be mainly in the absolute normalization, which results in a consistent disagreement over a wide energy interval.

For the Pu-239 alpha below 15 keV, a correlation was assumed between the fission and radiative capture cross sections, consistent with the measurements and analyses used to arrive at the alpha values. The high Pu-239 alpha values below 15 keV use variations in the fission and capture cross sections that correspond to the pessimistic side of the error bars in $\alpha(E)$ obtained from recent measurements and evaluations made in Harwell. ⁽⁵⁾

Other data uncertainties not listed in Table 2, but considered in the sensitivity studies, include the important cross sections of the higher plutonium isotopes and of fission products, structural material, coolant,

and control rod material. Tables 12 and 13 in the Appendix give a more complete description of the data uncertainties used in this sensitivity study.

4.0 FUEL COST COMPONENTS— EXAMPLES OF SENSITIVITY TO SPECIFIC DATA UNCERTAINTIES

Table 3 shows the breakdown in fuel cost for the two reactors listed in Table 1. Note that for the advanced core—the one with the 2.5-foot height and with no BeO—the plutonium credit almost cancels the fissile inventory cost; whereas this is not the case for the less advanced reactor and, hence, accounts for most of the difference in total fuel cost. The three right-hand columns in Table 3 show the changes in the calculated fuel cost components for the advanced reactor when we use three different cross section variations which are the extreme highs

in their respective uncertainty ranges. The high Pu-239 alphas below 15 keV produce a very large reduction in the plutonium credit which is associated with the loss of breeding ratio. Most of the cross section uncertainties affect mainly the plutonium credit component of the fuel cost, with the variation in the plutonium inventory cost associated with the change in fissile "enrichment" being considerably smaller. An exception to this rule is the fission cross section of the dominant fissile isotope, Pu-239, whose variation affects mainly the inventory cost component as shown in the next-to-the-last column in Table 3. Variations in the radiative capture cross sections of the fertile isotopes produce opposing effects on the credit and inventory cost components. The right-hand column in Table 3 shows that using high U-238 capture cross sections between 1 and 100 keV improves the plutonium credit by an amount that substantially overrides the penalty in the plutonium inventory cost.

TABLE 3

COMPONENT FUEL COSTS (mills/kWh)

	<u>Base Values</u>		<u>2.5-foot Core</u>		
	<u>1.5-foot Core</u>	<u>2.5-foot Core</u>	<u>High Pu-239 σ 0.2 to 15 keV</u>	<u>High Pu-239 σ_f 15 to 300 keV</u>	<u>High U-238 σ_c 1 to 100 keV</u>
Pu Credit	-0.30	-0.40	-0.29	-0.41	-0.47
Pu Inventory	0.50	0.44	0.45	0.41	0.46
Fabrication	0.25	0.24	0.241	0.237	0.242
Recovery	0.19	0.17	0.171	0.168	0.171
Fabrication Cap.	0.06	0.05	0.05	0.05	0.05
Total	0.70	0.50	0.62	0.46	0.45

Note that the fabrication and recovery costs are changed only slightly (in the third significant decimal place). This is due mainly to small variations in the power

distributions that result in small changes in the ratio of blanket fuel to core fuel, in addition to changes in fissile material loss during processing.

5.0 SENSITIVITY RESULTS FOR LOW LEAKAGE REACTOR

Table 4 shows the sensitivity to data uncertainties of the advanced reactor—the one that does not have stringent limitations on its design imposed by the sodium void reactivity effect. The uncertainty range in total fuel cost (minimum and maximum values) is shown corresponding to each of several important nuclear data uncertainties, and for the combined effect of all of the data uncertainties. The right-hand column gives the uncertainty ranges in the fissile doubling time. The bottom row in Table 4 shows the base values calculated with the reference ENDF/B cross section data for comparison with the uncertainty ranges. Note that the reference cross section data do not, in general, give calculated parameters in the middle of the uncertainty range. This

is due mainly to the strong bias of the Pu-239 alpha uncertainty below 15 keV in the direction of higher fuel cost and longer doubling time.

To get the combined effect of the data uncertainties, the various uncorrelated contributions were combined by the common statistical procedure of adding the individual variances and taking the square root. The uncertainty in the fuel cycle cost from the base value is about 0.15 mill/kWh; 0.25 mill/kWh for the full uncertainty span. (See Table 1 for the main economic assumptions used in the fuel cost calculations.) The uncertainty span in doubling time is about a factor of two. The uncertainties in alpha and $\bar{\nu}$ of Pu-239 and in the U-238 capture cross section are the largest individual contributors, with fission product σ_c and Pu-239 σ_f uncertainties being next most significant.

TABLE 4
COST AND DOUBLING TIME UNCERTAINTY RANGES
(3.5-foot Core)

<u>Data Uncertainty</u>	<u>Fuel Cost (mills/kWh)</u>	<u>Doubling Time (year)</u>
Pu-239 Alpha (0.2 to 15 keV)	0.48 to 0.62	8.8 to 13.5
Pu-239 σ_f (15 to 300 keV)	0.46 to 0.50	8.4 to 9.2
Pu-239 $\bar{\nu}$ (0 to 10 MeV)	0.45 to 0.58	8.1 to 11.5
U-238 σ_c (1 to 100 keV)	0.45 to 0.55	8.0 to 10.9
U-238 σ_{inel} (0.1 to 2 MeV)	0.49 to 0.51	9.0 to 9.4
Fission Product σ_c (0 to 10 MeV)	0.48 to 0.54	8.7 to 10.1
All Data Uncertainties	0.41 to 0.66	7.2 to 14.2
Base Values (ENDF/B)	0.50	9.2

There is a need to clarify what is meant by an uncertainty range. To state a standard deviation implies a certain precision in the selection of the data uncertainties, which is not the case here. The general approach followed was to exercise judgment

on the basis of available data and evaluations that have been made and attempt to select the very highest and the very lowest reasonable values for each data parameter within an assumed correlated energy interval. Thus the uncertainty ranges here are

near maximum uncertainties—much nearer to two or three standard deviations than to one.

Table 5 shows the uncertainty ranges for the Doppler coefficient with sodium out of the reactor and for the total sodium

voiding reactivity effect, for the same reactor and the same data uncertainties as in Table 4. The high end of the Pu-239 alpha range produces a large reduction in the Doppler coefficient and a large increase in the sodium void reactivity, with the U-238 σ_c below 100 keV also having an appreciable influence on these reactivity coefficients.

TABLE 5
DOPPLER AND TOTAL SODIUM VOID UNCERTAINTY RANGES
(2.5-foot Core)

<u>Data Uncertainty</u>	<u>Doppler $-T \frac{dk}{dT} \times 10^3$</u>	<u>Sodium Void (% Δk)</u>
Pu-239 Alpha (0.2 to 15 keV)	3.1 to 4.0	1.1 to 1.8
Pu-239 σ_f (15 to 300 keV)	3.7 to 3.9	1.2 to 1.4
Pu-239 $\bar{\nu}$ (0 to 10 MeV)	3.8 to 3.8	1.2 to 1.2
U-238 σ_c (1 to 100 keV)	3.2 to 4.4	1.0 to 1.4
U-238 σ_{inel} (0.1 to 2 MeV)	3.7 to 3.9	1.2 to 1.2
Fission Product σ_c (0 to 10 MeV)	3.5 to 4.0	1.1 to 1.3
<hr/>		
All Data Uncertainties	2.8 to 4.6	0.9 to 1.9
Base Values (ENDF/B)	3.8	1.2

6.0 SENSITIVITY RESULTS FOR HIGH LEAKAGE REACTOR

Table 6 shows the sensitivity to data uncertainties of the high leakage sodium reactor having stringent requirements imposed on the sodium void reactivity effect and on the Doppler coefficient for a voided core. In this case, the BeO content must be adjusted to satisfy these requirements as the cross section data vary. The right-hand column in Table 6 lists the range of BeO content corresponding to the range of each listed type of data uncertainty in the left-hand column. In this case, the Pu-239 alpha uncertainty, with its large effect on the Doppler coefficient and also on the sodium voiding reactivity, gives a large uncertainty in the

required amount of BeO which, in turn, considerably enlarges the fuel cost uncertainty, and also that of the doubling time, relative to the advanced reactor.

The cost span on Pu-239 σ_f between 15 and 300 keV is lower than it was for the advanced reactor. The reason for this is that increasing this fission cross section hardens the neutron spectrum and reduces the Doppler coefficient, requiring the addition of more BeO in this reactor, whose cost effect tends to offset the benefit of the higher σ_f . The combined data uncertainties produce an uncertainty range in the fuel cycle cost which is about 30% higher than that for the advanced low leakage reactor which did not have such

TABLE 6

UNCERTAINTY RANGES (1.5-foot Core)

<u>Date Uncertainty</u>	<u>Fuel Cost (mills/kWh)</u>	<u>Doubling Time (year)</u>	<u>Volume Percent BeO</u>
Pu-239 Alpha (0.2 to 15 keV)	0.66 to 0.90	13.0 to 40.0	2.7 to 6.2
Pu-239 σ_f (15 to 300 keV)	0.68 to 0.70	14.4 to 14.7	3.1 to 3.6
Pu-239 $\bar{\nu}$ (0 to 10 MeV)	0.65 to 0.78	12.5 to 19.9	3.3 to 3.6
U-238 σ_c (1 to 100 keV)	0.65 to 0.75	12.0 to 19.3	3.0 to 3.8
U-238 σ_{inel} (0.1 to 2 MeV)	0.69 to 0.71	14.4 to 15.0	3.2 to 3.6
Fission Product σ_c (0 to 10 MeV)	0.66 to 0.76	13.2 to 18.3	2.9 to 4.3
<hr/>			
All Data Uncertainties	0.61 to 0.94	10.1 to 42.0	2.2 to 6.5
Base Values (ENDF/B)	0.70	14.7	3.4

stringent design requirements imposed by the sodium void problem.

The U-238 σ_c uncertainties between 1 and 100 keV produced a much smaller effect on the sodium-voided Doppler coefficient of the high leakage reactor than for the advanced low leakage reactor, whereas the fission product σ_c uncertainties produced a larger effect on the sodium-voided Doppler coefficient of the high leakage reactor. (Compare volume percent BeO ranges in Table 6 with Doppler ranges in Table 5.) This result is consistent with the softer spectrum and higher U-238 dilution of the high leakage reactor in the sodium-voided condition.

The Pu-239 $\bar{\nu}$ uncertainty produces the same fuel cost uncertainty range in the high leakage reactor as in the low leakage (advanced) reactor. The uncertainty in the fission product capture cross sections produces a larger cost uncertainty in the high leakage reactor because of the large uncertainty in BeO content associated with the significant influence of fission product capture at low energies on the Doppler coefficient.

7.0 SUMMARY OF SPECIFIC DATA
COST UNCERTAINTIES

Tables 7, 8, and 9 give the cost uncertainty spans—the full difference between the maximum and the minimum cost associated with each data uncertainty. The cost uncertainty span is listed for both the low leakage (2.5-foot) and the high leakage (1.5-foot) sodium-cooled reactors considered in this study. This comparison of the cost uncertainties provides a reasonable measure of the relative importance of the different data uncertainties.

Table 7 again shows the importance of the current Pu-239 alpha uncertainties below 15 keV, and also at higher energies where a correlated uncertainty of $\pm 20\%$ was assumed. The large cost uncertainty span for Pu-239 $\bar{\nu}$ and U-238 σ_c are also noted, with smaller but significant cost spans associated with Pu-239 σ_f and the fission neutron spectrum, U-238 σ_f , and U-238 σ_{inel} .

Table 8 shows the cost uncertainty spans for higher plutonium isotopes, fission products, and the Be (n,2n) reaction—the latter for only the high leakage reactor. The

TABLE 7

FUEL COST UNCERTAINTY SPAN (mills/kWh)
FOR PU-239 AND U-238 DATA

<u>Data</u>	<u>First Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>	<u>Second Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>
Pu-239 Alpha	0.2 to 15 keV	0.14	0.24	15 keV to 2 MeV	0.04	0.03
Pu-239 σ_f	15 to 300 keV	0.04	0.02	0.3 to 3 MeV	0.01	0.01
Pu-239 $\bar{\nu}$	0 to 10 MeV	0.13	0.13			
Pu-239 Temperature	Fission Spectrum	0.03	0.03			
Pu-239 σ_{inel}	0.1 to 10 MeV	0.005	0.002			
U-238 σ_c	1 to 100 keV	0.10	0.10	0.1 to 10 MeV	0.03	0.05
U-238 σ_f	2 to 6 MeV	0.03	0.02			
U-238 σ_{inel}	0.1 to 2 MeV	0.02	0.02	2 to 10 MeV	0.01	0.005

TABLE 8

FUEL COST UNCERTAINTY SPAN (mills/kWh)
FOR HIGHER PU ISOTOPES AND FISSION PRODUCTS

<u>Data</u>	<u>First Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>	<u>Second Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>
Pu-240 σ_c	0.1 to 50 keV	0.01	0.03	0.05 to 1 MeV	0.002	0.01
Pu-240 σ_f	1 keV to 10 MeV	0.02	0.02			
Pu-240 σ_{inel}	0.1 to 2 MeV	0.001	0.001	2 to 10 MeV	0	0.001
Pu-241 Alpha	0.1 to 200 keV	0.002	0.005	0.2 to 10 MeV	0	0.002
Pu-241 σ_f	0.1 to 200 keV	0.01	0.01	0.2 to 10 MeV	0.005	0.005
Pu-242 σ_c	0.1 to 50 keV	0	0	0.05 to 1 MeV	0	0.001
Pu-242 σ_f	1 keV to 10 MeV	0	0.001			
Fission Product σ_c	0.1 keV to 10 MeV	0.06	0.10			
Be (n, 2n)	2 to 10 MeV	---	0.005			

TABLE 9

FUEL COST UNCERTAINTY SPAN (mills/kWh)
FOR SODIUM, STEEL, AND TANTALUM

<u>Data</u>	<u>Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>	<u>Interval</u>	<u>2.5-foot</u>	<u>1.5-foot</u>
Sodium σ_c	0.1 to 10 keV	0.002	0.003	10 to 100 keV	0.001	0.002
Sodium σ_c	0.1 to 10 MeV	0.001	0.002			
Sodium σ_{elas}	0.1 to 10 keV	0.005	0.005	10 to 300 keV	0.02	0.01
Sodium σ_{elas}	0.3 to 10 MeV	0.003	0.004			
Steel σ_c	0.1 to 10 keV	0.01	0.02	10 to 100 keV	0.02	0.03
Steel σ_c	0.1 to 10 MeV	0.03	0.04			
Steel σ_{inel}	0.8 to 10 MeV	0.01	0.005			
Ta σ_c	0.1 keV to 10 MeV	0.02	0.03			

fission product σ_c uncertainty span is the largest of those listed in Table 8, with the Pu-240 and Pu-241 fission cross sections being significant. The Pu-240 σ_c cost uncertainty span is surprisingly small for the advanced reactor (2.5-foot core). This results from a near cancellation of the effects on the plutonium credit and the plutonium inventory. The Pu-240 σ_c cost span is somewhat larger for the 1.5-foot core because of the influence of this cross section on the Doppler coefficient and, hence, on the amount of BeO required.

Table 9 shows the fuel cost uncertainty spans for sodium, steel, and tantalum cross sections. The values for steel σ_c in each of the three energy intervals indicated are significant. The effect is due mainly to the iron in the steel, since the nickel and chromium are present in considerably smaller content. The fuel cost uncertainty span for tantalum data was estimated from the uncertainty in the volume required for tantalum control rods, which in turn affects the fuel volume fraction and, hence, the neutron economy and the fuel cycle cost.

8.0 ACCURACY GOALS FOR NUCLEAR DATA MEASUREMENTS

Table 10 lists important nuclear data measurements wanted by fast reactor designers. (The first four nuclear data parameters listed in Table 10 would probably appear on any fast power reactor designer's list of the most wanted neutron data measurements.) Accuracy is desired over the energy spectrum as indicated in Table 10, to reduce the fuel cost uncertainty associated with each kind of data to the amount listed in the right-hand column. These fuel cost uncertainties are for the low leakage advanced reactor, since we are considering here longer-term accuracy goals for cross section measurements. Note the very high precision required of $\bar{\nu}$ to get its fuel cost uncertainty to less than 0.02 mill/kWh. Pu-239 σ_f and U-238 σ_c are desired at the next higher precision. (The cost uncertainty range indicated in Table 10 has the same statistical significance as that of the corresponding data uncertainty range.) The Pu-239 alpha value below 15 keV should be given the highest priority (even though other data may

TARGETS FOR DATA ACCURACY

Energy (keV)		mills/kWh Uncertainty
Pu-239 Alpha	$\pm 5\%$ $\pm 3\%$ $\pm 5\%$ $\pm 10\%$	$\pm .01$
Pu-239 σ_f	$\pm 2\%$	$\pm .01$
Pu-239 $\bar{\nu}$	$\pm \frac{1}{2}\%$	$\pm .015$
U-238 σ_c	$\pm 5\%$ $\pm 2\%$ $\pm 10\%$	$\pm .01$
U-238 σ_f	$\pm 5\%$	$\pm .005$
U-238 σ_{inel}	$\pm 5\%$	$\pm .005$
Fission Product σ_c	$\pm 10\%$	$\pm .005$
σ_f Pu-240, 241	($\pm 5\%$)	$\pm .015$
σ_c Pu-240, Fe, Ni, Cr, Ta	($\pm 10\%$)	$\pm .03$
σ_{elas} Na, Fe, Ni, Cr	($\pm 10\%$)	

ultimately require higher accuracy) because it has such a large uncertainty at the present time. If the cross-section measurers can provide the data accuracy indicated in Table 10, it will be possible to design plutonium-fueled fast power reactors with only a ± 0.03 mill/kWh uncertainty in fuel cost from neutron data uncertainties.

9.0 ENGINEERING DESIGN ALTERNATIVES TO COUNTERACT ADVERSE DATA

If subsequent measurements of cross sections indicate that data are on the adverse side of the uncertainty range, a number of design modifications may be considered which would still satisfy certain performance targets. For illustration by a relatively simple example, the advanced sodium-cooled reactor concept (no severe limitations imposed by the sodium void reactivity effect) will be considered with alternatives in core and fuel design that would yield a doubling time of 10 years even if the very high Pu-239 alpha values considered in this sensitivity study turned out to be correct.*

As indicated in Table 4, the pessimistic Pu-239 alphas increase the doubling time to 13.5 years. Engineering design modifications that may be considered to counteract such adverse data and return the doubling time to 10 years include the following:

- a. Different fuel material (not oxide) such as carbide which (if developed to its full potential) could appreciably reduce fissile inventory because of its higher thermal conductivity and also increases the breeding ratio because

of its higher density of fertile and fissile atoms.

- b. Sodium-bonded fuel which would reduce fissile inventory because of improved heat transfer from fuel surface to coolant.
- c. Smaller fuel rod diameter to reduce fissile inventory and/or higher oxide density to increase breeding ratio.
- d. Higher fuel volume fraction to increase breeding ratio and reduce inventory. This can be achieved through advances in fuel spacer and subassembly enclosure design that result in lower fuel rod pitch-to-diameter ratio and in lower steel and sodium content.

These design modifications require advances in fuel technology and demand higher performance of the coolant in core heat removal (such as higher flow velocity and/or larger temperature rise across the core to accommodate an improved fuel heat transfer and/or a tighter fuel lattice) with consequent increased severity on material requirements to withstand larger coolant pressure differentials across the core and/or higher coolant outlet temperatures. Development programs in sodium technology must, correspondingly, be extended to insure that reactor operation under these more stringent requirements does not result in unacceptable risks to the potential utility reactor operators.

Table 11 shows core design parameters which would result from the high Pu-239 alpha values below 15 keV for the original low-leakage design and for two alternate designs which are chosen to yield 10-year doubling times with the high Pu-239 alpha values. To achieve this condition, the fuel was sodium-bonded to the cladding in one case, and the fuel rod diameter reduced from 0.25 to 0.225-inch for the other alternate. The fuel rod pitch-to-diameter ratio

* Other combinations of pessimistic data could be considered for this purpose. For example, a combination of lower U-238 capture cross sections and not quite so high Pu-239 alphas would produce about the same effect on breeding and economics as the very high Pu-239 alphas alone.

TABLE 11

CORE DESIGN CHANGES
TO COUNTERACT HIGH Pu-239 ALPHAS

	<u>Base Design</u>	<u>Sodium- Bonded</u>	<u>Small Rod Diameter</u>
Fuel Rod Diameter (inch)	0.25	0.25	0.225
Sodium-Bonded	No	Yes	No
Rod Pitch-to-Diameter	1.25	1.20	1.20
Fuel/Sodium/Steel vol %	42/39/18	44/37/18	44/37/18
Core Diameter (ft)	8.0	7.15	7.15
Pressure Drop (psi)	80	190	210
In-Pile Fissile Pu (kg)	2430	2020	2020
Breeding Ratio	1.28	1.31	1.31
Doubling Time (year)	13.5	10	10
Fuel Cost (mill/kWh)	0.62	0.51	0.54

was reduced for both alternates, permitting a slightly higher fuel volume fraction with a lower sodium content and no increase in the steel content. The alternate designs have the base design characteristics of 2.5-foot core height, 18-inch-thick blankets, oxide fuel density at 90% theoretical density, steel cladding thicknesses based on the gaseous fission-product vent-to-coolant approach, 300° F coolant temperature rise across the core, and a peak central fuel temperature slightly below the melting point.

Sodium-bonding or the smaller fuel rod diameter each permit an increase in fuel specific power leading to a reduction in the fissile inventory by about 20%; the higher fuel volume fraction and lower sodium fraction increase the breeding ratio from 1.28 to 1.31. The tighter lattice and higher heat transfer from fuel to coolant require about a 35 ft/sec sodium flow velocity for the alternate designs, compared with 28 ft/sec for the base design. This results in coolant core pressure drops of about 200 psi for the alternate designs.

10.0 IMPLICATIONS OF FAST REACTOR
UNCERTAINTIES ON THE REACTOR
ECONOMY

The previous sections have indicated that the uncertainty in power cost from nuclear data uncertainties amounts to approximately 0.25 mill/kWh. For calibration it is worth noting that this uncertainty represents about a \$2 million per year operating uncertainty for a 1000 MWe plant.* It also represents a total fuel cost differential of \$35 billion over a 35-year period between 1985 and 2020 using one projective buildup of fast

* The nuclear data uncertainties affect mainly the fuel cost, but they also produce a small uncertainty in capital cost because of resultant uncertainties in design requirements such as number of control rods, shielding thicknesses, and containment pressure in a Doppler-controlled design basis accident. These capital cost factors are estimated to add about another 0.03 mill/kWh to the power cost uncertainty span associated with the nuclear data uncertainties. The power cost uncertainty span arising from approximations in current neutronics computation methods—other than data—is estimated to be about 0.05 mill/kWh.

breeder electrical generating capacity.⁽⁶⁾ The total cost of power from mature fast breeder reactors has been generally estimated to be in the neighborhood of 3 to 4 mills/kWh⁽⁷⁾ so that the large dollar figures indicated above are due to the very large usage of electricity rather than to a large percentage increase in the cost of electricity.

The uncertainty span in doubling time translates into a difference of 1 million tons in cumulative ore requirements (natural U_3O_8 over the same 35-year period) which would lead to a potential additional cost differential of the order of \$30 billion.⁽⁸⁾

The previous discussion has indicated that specific goals such as low doubling time (which would alleviate the ore requirements mentioned above) can be achieved if one alters the design in the direction of requiring improved performance from the reactor fuel and system. This route of course entails added risk to the achievement of predicted reactor performance and/or requires additional development work prior to the commitment of the reactor. It may entail additional costs in power generation.

In their state of asymptotic development, it is predicted that the fast reactor may have an inherent cost advantage over competing reactor types of the order of 1/2 to 1 mill/kWh, or more, primarily because of its potential for very low fuel costs. However, because of first-of-a-kind fabrication costs and the need to develop a stable and large scale sodium components industry, the initial achievement of even

break-even economics, compared to other power sources, will be a challenge. The large-scale introduction of fast breeders depends upon their achieving this economic parity with competing forms of nuclear and fossil power sources. The uncertainty in economic performance clouds the target designs necessary to reach economic parity and obscures the need for the development programs which might hasten the economic introduction of fast reactors. The date of introduction of fast reactors is of some importance since fast reactors are expected to be the most economical users of plutonium, a by-product of all reactor operation. By 1980, it is estimated that there will be approximately 100 metric tons of plutonium recovered from civilian power reactors, by 1985 approximately 300 tons, and by 1990, 600 tons.⁽⁹⁾ The value of the plutonium used in a fast breeder has been estimated at approximately \$10/gram or more as compared to estimates closer to \$5/gram for the value of plutonium if it were used in a thermal reactor.⁽¹⁰⁾ Thus, a 5-year reduction in the date of introduction of breeders can result in significant cumulative savings to the economy.

In summary, it appears that uncertainties in economics and performance from present nuclear data uncertainties are not large enough to affect the ultimate development of economic fast breeders. They do produce significant uncertainties in the performance of the breeders, their date of introduction and the urgency and cost incentives for additional development work. The economic implications are large enough to justify an intensive effort to reduce these uncertainties.

APPENDIX

The nuclear data uncertainties listed in Tables 12 and 13 below are expressed in terms of percent change in the base values. The base calculations have been computed with values which were, with a few exceptions, derived from the pointwise data of

the ENDF/B⁽⁴⁾ files. In several cases, the uncertainties have relatively fine variations with energy. In these cases the changes shown below for specific energies are average values in the neighborhood of these energies.

TABLE 12

DATA UNCERTAINTIES

<u>Material</u>	<u>Data Type</u>	<u>Energy</u>	<u>Percent Change</u>	
			<u>High</u>	<u>Low</u>
1. Pu-239	α	See Table 13		
	σ_f	15 keV	+15.0	- 8.0
		50 keV	+25.0	0
		500 keV	+10.0	0
		2 MeV	+ 3.0	- 3.0
		4 MeV	0	- 6.0
		10 MeV	0	0
	$\bar{\nu}$	0 to 10 MeV	+ 1.6	- 2.5
	Nuclear Temperature	Fission Neutron Spectrum	+ 7.0	- 7.0
	σ_{inel}	0.1 to 10 MeV	+80.0	0
2. U-238	σ_c	1 keV	0	0
		4 keV	+20.0	-20.0
		10 keV	+25.0	-25.0
		100 keV	+20.0	-15.0
		1 MeV	+15.0	0
		4 MeV	+15.0	0
	σ_f	2 MeV	0	-15.0
		4 MeV	+ 8.0	- 8.0
		6 MeV	+ 2.0	0
		10 MeV	0	0
	σ_{inel}	100 keV	0	0
		500 keV	+15.0	-15.0
		1 MeV	+10.0	-10.0
	σ_{inel} , Nuclear Temperature	2 to 10 MeV	+25.0	-25.0
3. Pu-240	σ_c	100 eV	+20.0	-15.0
		10 KeV to 1 MeV	+40.0	-25.0
	σ_f	100 to 300 keV	+30.0	-30.0
		1 MeV	+10.0	-10.0
		10 MeV	+ 5.0	- 5.0
	σ_{inel}	(Same as for U-238)		

TABLE 12

DATA UNCERTAINTIES (Continued)

<u>Material</u>	<u>Data Type</u>	<u>Energy</u>	<u>Percent Change</u>	
			<u>High</u>	<u>Low</u>
4. Pu-241	α	100 eV to 10 MeV	+25.0	-25.0
	σ_f	100 eV to 10 MeV	+25.0	-25.0
5. Pu-242	σ_c	(Same as Pu-240)		
	σ_f	(Same as Pu-240)		
6. Fission Products	σ_c	100 eV to 10 MeV	+50.0	-30.0
7. Ta	σ_c	100 eV to 10 MeV	+30.0	-25.0
8. Fe, Cr, Ni	σ_c	100 eV to 10 MeV	+50.0	-30.0
	σ_{inel}	800 keV to 10 MeV	+15.0	-15.0
9. Na	σ_c	100 eV to 10 keV	+75.0	-30.0
		10 keV to 10 MeV	+30.0	-25.0
	σ_{elas}	100 eV to 10 MeV	+20.0	-20.0
10. Be	$\sigma_{n, 2n}$	2 to 10 MeV	+20.0	-20.0

TABLE 13

UNCERTAINTIES FOR Pu-239 ALPHA VALUES

<u>E</u>	<u>High Values^(a)</u>			<u>Low Values</u>		
	$\frac{\Delta\alpha}{\alpha} (\%)$	$\frac{\Delta\sigma_c}{\sigma_c} (\%)$	$\frac{\Delta\sigma_f}{\sigma_c} (\%)$	$\frac{\Delta\alpha}{\alpha} (\%)$	$\frac{\Delta\sigma_c}{\sigma_c} (\%)$	$\frac{\Delta\sigma_f}{\sigma_f} (\%)$
0.2 keV	0	0	0	-10	-10	0
0.6 keV	+ 50	+ 50	0	↑ ↓	↑ ↓	↑ ↓
1.0 keV	+100	+ 60	-20			
3.0 keV	+110	+ 90	-10			
5.0 keV	+140	+105	-15			
10.0 keV	+ 80	+ 60	-10			
15.0 keV	+ 20	+ 20	0	-20	-20	↓
2.0 MeV	+ 20	+ 20	0	-20	-20	0

(a) Because of the difference approach used in one of the methods for obtaining the high α values below 15 keV, ⁽⁵⁾ the σ_f values were lowered and σ_c values simultaneously raised to conform to those required to obtain high α values.

The data uncertainty ranges were principally determined from the spread of values and data error bars presented in BNL 325,⁽¹¹⁾ KFK-120,⁽¹²⁾ and the documentation of ENDF/B evaluations.⁽⁴⁾ For the data which are more important in fast reactor computations, a search for additional sources was made to ensure an up-to-date consideration of the uncertainties.

The base Pu-239 cross sections and reasons for choosing them are described in GEAP-5272.⁽¹³⁾ The high uncertainties in the α value of Pu-239 below 15 keV, as listed in Table 13 were taken from the high end of the error bars of recent evaluations in the U. K.,⁽⁵⁾ while the low side is according to Schmidt's February 1966 evaluation.⁽¹²⁾ Above 15 keV the range was estimated from the error bars of the measurements of Hopkins-Diven⁽¹⁴⁾ and Lottin, et al.⁽¹⁵⁾

The high Pu-239 σ_f values were chosen from the higher values of Dubrovina, et al.,⁽¹⁶⁾ below 1 MeV, and Smith, Henkel, and Nobles⁽¹⁷⁾ above 1 MeV, while the low values are a combination of James⁽⁵⁾ data at low energies, White⁽¹⁸⁾ data between 20 and 500 keV, and Henkel⁽¹⁹⁾ above 2 MeV. The range of Pu-239 $\bar{\nu}$ was determined from

the high thermal values of Mather, Fieldhouse, and Moat,⁽²⁰⁾ and the low values of Colvin and Sowerby.⁽²¹⁾

For U-238 σ_c , the ranges were determined from the high data of Macklin, Pasma, and Gibbons⁽²²⁾ and the low values of Moxon, et al.,⁽²³⁾ below 100 keV. Above 100 keV, the spread in data of Barry, Bunce, and White,⁽²⁴⁾ Leipunsky, et al.,⁽²⁵⁾ and Bercquist⁽²⁶⁾ was considered. The uncertainties in σ_{inel} level data for U-238 and for fuel isotopes in general, were estimated from the data of Batchelor, et al.,⁽²⁷⁾ and Barnard, et al.,⁽²⁸⁾ on the high side, and from Parker's recommended curve⁽²⁹⁾ on the low side.

Ranges in σ_c of Ta were obtained from the ENDF/B evaluation by Henderson, et al.,⁽³⁰⁾ The highly uncertain σ_c values of iron, the principal structural element, are indicated by the recent data of Moxon-Rae,⁽³¹⁾ and Macklin-Gibbons^(32,33) which indicate higher values than earlier measurements. For many of the remaining uncertainties, available data were so sparse that only crude estimates could be made of the uncertainty ranges.

REFERENCES

1. Moorhead, T. P., "The Effects of Errors in Cross-Section Data on Calculations for a Large Dilute Fast Reactor," Proceedings of the Seminar on Physics of Fast and Intermediate Reactors, SM-18/15, Vienna, II, 111, (1962).
2. Greebler, P., and Hutchins, B. A., "User Requirements for Cross Sections in the Energy Range from 100 eV to < 100 keV," GEAP-4472, (June 1966).
3. Smith, R. D., "Nuclear Data Requirements for Fast Reactor Design and Operation," Paper CN-23/52, Conference on Nuclear Data—Microscopic Cross Sections and Other Data Basic for Reactors, Paris, October 17—21, 1966. Also private communication from J. L. Rowlands for other sensitivity studies conducted in the U.K.
4. "ENDF/B Summary Documentation," ENDF Newsletter, Brookhaven National Laboratory, National Neutron Cross Section Center, 3, 2, (October 2, 1967).
5. Shomberg, M. G., Sowerby, M. G., and Evans, F. W., "A New Method of Measuring Alpha(E) for ^{239}Pu ," IAEA Symposium on Fast Reactor Physics and Related Safety Problems, SM-101/41, Karlsruhe, Germany, (October 30—November 3, 1967).
6. Dietrich, R. J., "Uranium Requirements for Nuclear Power," Nuclear News, 10, 9 (September 1967).
7. Cohen, K. P., and O'Neill, G. L., "Safety and Economic Characteristics of a 1000 MWe Fast Sodium-Cooled Reactor Design," Conference of Safety, Fuels and Core Design in Large, Fast Power Reactors, Argonne National Laboratory, ANL-7120, (October 11—14, 1965).
8. "World Uranium and Thorium Resources," Organization for Economic Cooperation and Development and European Nuclear Energy Agency (August 1965).
9. Beckman, M. C., and Wagner, H. A., "Plutonium Recycle in U. S. Thermal Reactors," Symposium on Plutonium Fuel Technology, Phoenix, Arizona, (October 1967).
10. Murphy, P. M., "The Influence of Plutonium on the Design of Advance Reactors," Twelfth Annual Meeting of American Nuclear Society, Denver, Colorado, (June 20—23 1966).
11. Stehn, J. R., Goldberg, M. D., Wiener-Chasman, R., Mughabghab, S. F., Magurno, B. A., and May, V. M., "Neutron Cross Sections," BWL 325 2nd ed., (Z = 00 to 90), Brookhaven National Laboratory, III, 2, (February 1965).
12. Schmidt, J. J., "Neutron Cross Sections for Fast Reactor Materials Part I: Evaluation," KFK 120, Kernforschungszentrum, Karlsruhe, (February 1966).
13. Greebler, P., Aline, P. G., and Hutchins, B. A., "Evaluation and Compilation of ^{239}Pu Cross-Section Data for the ENDF/B Files," GEAP-5272, (December 1966).

REFERENCES (Continued)

14. Hopkins, J. C., and Diven, B. C., "Neutron Capture to Fission Ratios in ^{233}U , ^{235}U , ^{239}Pu ," J. Nucl. Sci. Eng., 12, 169 (1962).
15. Lottin, A., Weston, L. W., deSaussure, G., and Todd, J. H., "Ratio of Capture to Fission in ^{239}Pu at keV Neutron Energies," Proceedings of the International Conference on Fast Critical Experiments and Their Analysis, ANL-7320, Argonne National Laboratory, 22 (1966).
16. Dubrovina, S. M., and Shigin, V. A., "Fission Cross-Sections of ^{231}Pu and ^{239}Pu in the 1.5 to 1500 keV Energy Range," Dokl. Akad. Nauk SSSR 157, 561 (1964).
17. Smith, R. K., Henkel, R. L., and Nobles, R. A., "Neutron-Induced Fission Cross-Sections for ^{233}U , ^{235}U , ^{238}U , and ^{239}Pu from 2 to 10 MeV," Bull. Am. Phys. Soc. 2, 196 (1957).
18. White, P. H., Hodgkinson, J. G., and Wall, G. J., "Measurement of Fission Cross-Sections for Neutrons of Energies in the Range 40-500 keV," Proc. Conf. on Physics and Chemistry of Fission, IAEA, Salzburg, Austria, EANDC(UK) 535 (1964).
19. Henkel, R. L., "Summary of Neutron-Induced Fission Cross-Sections," LA-2114, Los Alamos Scientific Laboratory, (1957).
20. Mather, D. S., Fieldhouse, P., and Moat, A., "Measurement of the Prompt $\bar{\nu}$ for the Neutron-Induced Fission of ^{232}Th , ^{233}U , ^{234}U , ^{238}U , and ^{239}Pu ," Nucl. Phys., 66, 149 (1965).
21. Colvin, D. W., and Sowerby, M. G., "Boron-Pile $\bar{\nu}$ Measurements," Proc. Conf. of Physics and Chemistry of Fission, IAEA, Salzburg, Austria, SM-60/44 (1964).
22. Macklin, R. L., Pasma, P. J., and Gibbons, J. H., "Neutron Capture," AEC Nuclear Cross-Section Advisory Group, WASH-1046, 88-90, (1964).
23. Moxon, M. C., Rae, E. R., Batchelor, R., Egelstaff, P. A., and Ferguson, A. T. G., "Neutron Interactions with Reactor Materials," Third Geneva Conf., A/CONF 28/P/167 (1964).
24. Barry, J. F., Bunce, J., and White, P. H., "Cross-Section for the Reaction $^{238}\text{U}(n, \gamma)^{239}\text{U}$ in the Energy Range 0.12-7.6 MeV," J. Nucl. Energy, 18, 481 (1964).
25. Leipunski, A. I., Kazachkovsky, O. D., Artyukhov, G. Y., Baryshnikou, A. I., Belanova, T. S., Galkou, V. N., Stavisky, Y. Y., Stumbur, E. A., and Sherman, L. E., "Measurements of Radiative Capture Cross-Sections for Fast Neutrons," Second Geneva Conf., A/CONF, 15/P/2219 (1958).
26. Bercqvist, I., "Fast Neutron Radiative Capture Cross-Sections in Ag, Ta, W, Au, Hg, and U," Arkiv Fysik, 23, 425 (1963).
27. Batchelor, R., Proc. Phys. Soc., London, A 69, 214 (1964).
28. Barnard, E., Ferguson, A. T. G., McMurray, W. R., vanHeerden, I. J., "Scattering of Fast Neutrons by ^{238}U ," International Conf. on Study of Nuclear Structure with Neutrons,

REFERENCES (Continued)

- Antwerp, Belgium, EANDC-50-S, P/26 (1965).
29. Parker, K., "Neutron Cross-Sections of ^{235}U and ^{238}U in the Energy Range 1 keV - 15 MeV. Part I, Best Cross-Sections for ^{238}U Based on Microscopic Experimental and Theoretical Data Available at December, 1961," AWRE-O-79/63 (1964).
30. Henderson, W. B., DeCorrevont, P. A., and Zwick, J. W., "Evaluation and Compilation of Ta-181, W-182, W-183, W-184, and W-186 Cross-Section Data for the ENDF/B File," GEMP-448, (November 11, 1966).
31. Moxon, M. C., "The Neutron Capture Cross-Section of Iron and Cobalt," International Conf. of Study of Nuclear Structure with Neutrons, Antwerp, Belgium, P/88 (1965).
32. Macklin, R. L., Pasma, P. J. and Gibbons, J. H., "Resonance Neutron Capture and Transmission in Sulfur, Iron, and Lead," Phys. Rev. 136, B 695 (1964).
33. Macklin, R. L., Gibbons, J. H., "Capture Cross-Section Studies for 30-220 keV Neutrons Using a New Technique," Phys. Rev. 159, 1007 (1967).

DISTRIBUTION LIST

Director, Contracts Division	2	Sunnyvale, California	
U. S. Atomic Energy Commission		Attn: J. V. Levy	
San Francisco Operations Office			
2111 Bancroft Way		LMFBR Program Office	
Berkeley, California 94704		Argonne National Laboratory	
		9800 South Cass Avenue	
Chief, California Patent Group	1	Argonne, Illinois 60439	
U. S. Atomic Energy Commission		Attn: A. Amorosi, Director	1
San Francisco Operations Office		L. R. Kelman	1
P. O. Box 808			
Livermore, California 94551		Atomics International	
		P. O. Box 309	
Division of Reactor Development	2	Canoga Park, California 91304	
and Technology		Attn: S. Golan	2
U. S. Atomic Energy Commission			
Washington, D. C. 20545		Director	2
Attn: Asst. Director for Reactor		Liquid Metals Information Center	
Engineering		P. O. Box 309	
		Canoga Park, California 91305	
M. J. Whitman	1		
Asst. Director for Program Analysis		The Babcock & Wilcox Company	
		Atomic Energy Division	
A. Giambusso	3	Lynchburg, Virginia 24501	
Asst. Director for Project Management		Attn: M. W. Croft	2
(Attn: R. Sweek, G. Wensch,			
J. Morabito)		Mr. L. W. Fromm, Manager	2
		1000 MWe LMFBR Follow-On Study	
J. A. Lieberman	1	Project, Building 208	
Asst. Director for Nuclear Safety		Argonne National Laboratory	
		9800 South Cass Avenue	
J. W. Crawford	1	Argonne, Illinois 60439	
Asst. Director for Plant Engineering			
		Mr. C. A. Anderson, Project Manager	2
R. H. Steel	1	1000 MWe LMFBR Follow-On Study	
Division of Naval Reactors		Westinghouse Electric Corporation	
		Advanced Reactors Division	
E. E. Sinclair	2	Waltz Mill Site	
Asst. Director for Reactor Technology		P. O. Box 158	
(Attn: J. M. Simmons and		Madison, Pennsylvania 15663	
I. Zartman)			
		FFTF Project	8
RDT Site Office	2	P. O. Box 220	
U. S. Atomic Energy Commission		Richland, Washington 99352	
c/o General Electric Company		Attn: Configuration and Data	
310 DeGuigne Drive		Management	

DISTRIBUTION LIST (Continued)

W. P. Staker, Project Manager 1000 MWe LMFBR Follow-On Study Combustion Engineering, Inc. P. O. Box 500 Windsor, Connecticut 06095	2	RDT Site Representative U. S. Atomic Energy Commission Post Office Box 2108 Idaho Falls, Idaho 83401	1
RDT Senior Site Representative U. S. Atomic Energy Commission P. O. Box 2325 San Diego, California 92112	1	RDT Site Representative U. S. Atomic Energy Commission United Nuclear Corporation Grasslands Road Elmsford, New York 10523	
RDT Senior Site Representative Canoga Park Area Office P. O. Box 591 Canoga Park, California 91305	1	Attn: M. Napack A. Strasser	1 1
RDT Senior Site Representative U. S. Atomic Energy Commission Argonne National Laboratory 9800 South Cass Avenue Argonne, Illinois 60439	1	Argonne National Laboratory 9800 South Cass Avenue Argonne, Illinois 60439 Attn: J. H. Kittel R. C. Vogel	3 1
RDT Site Office U. S. Atomic Energy Commission Atomic Power Development Associates, Inc. 1911 First Street Detroit, Michigan 48226	1	Pacific Northwest Laboratory P. O. Box 999 Richland, Washington 99352 Attn: E. A. Eschbach E. A. Evans	1 2
RDT Senior Site Representative Oak Ridge National Laboratory P. O. Box X Oak Ridge, Tennessee 37830	1	Knolls Atomic Power Laboratory P. O. Box 1072 Schenectady, New York 12301 Attn: W. Cashin	1
RDT Site Office U. S. Atomic Energy Commission Combustion Engineering, Inc. P. O. Box 500 Windsor, Connecticut 06095	1	University of California Lawrence Radiation Laboratory P. O. Box 808 Livermore, California 94551 Attn: A. Rothman	1
RDT Senior Site Representative U. S. Atomic Energy Commission P. O. Box 550 Richland, Washington 99352	1	Los Alamos Scientific Laboratory P. O. Box 1663 Los Alamos, New Mexico 87544 Attn: R. D. Baker D. B. Hall W. R. Wykoff Reports Librarian	1 1 1 1

DISTRIBUTION LIST (Continued)

Westinghouse Electric Corporation		United States Embassy	
Bettis Atomic Power Laboratory		Brussels, Belgium	
P. O. Box 79			
West Mifflin, Pennsylvania		Division of Technical Information	
Attn: E. J. Kreh	1	Extension	50
		U. S. Atomic Energy Commission	
Oak Ridge National Laboratory		P. O. Box 62	
P. O. Box X		Oak Ridge, Tennessee 37831	
Oak Ridge, Tennessee 37830			
Attn: J. E. Cunningham	1	Dr. John C. Woodhouse	1
		1 Guest Lane	
Brookhaven National Laboratory		Wilmington, Delaware 19809	
Upton, New York 11973			
Attn: O. E. Dwyer	1	Power Reactor Development Corp.	
		1911 First Street	
Battelle Memorial Institute		Detroit, Michigan 48226	
Columbus Laboratories		Attn: W. J. McCarthy	1
505 King Avenue			
Columbus, Ohio 43201			
Attn: D. Keller	1	Argonne National Laboratory	
		Idaho Division	
Atomics International		P. O. Box 1096	
P. O. Box 309		Idaho Falls, Idaho 83401	
Canoga Park, California 91304		Attn: F. A. Thalgott	1
Attn: H. Pearlman	1		
FBR Project Manager		Detroit Edison Company	
(R. J. Beeley)	1	1911 First Street	
		Detroit, Michigan 48226	
Dow Chemical Company		Attn: A. S. Griswold	1
Rock Flats Division			
P. O. Box 888		Atomic Power Development Associates	
Golden, Colorado 80401		1911 First Street	
Attn: R. D. Forest	1	Detroit, Michigan 48226	
		Attn: A. A. Shoudy	1
Scientific Representative	1		
U. S. Atomic Energy Commission		Combustion Engineering, Inc.	
American Embassy		Nuclear Division	
APO San Francisco 96503		Prospect Hill Road	
		Windsor, Connecticut 06095	
U. S. AEC Scientific Representative		Attn: W. P. Chernock	1
United States Embassy	1		
Paris, France, APO New York 09777		The Babcock & Wilcox Company	
		Atomic Energy Division	
Senior U. S. AEC Representative	1	Lynchburg, Virginia 24501	
U. S. Mission to the European		Attn: H. S. Barringer	1
Communities		S. H. Esleeck	1

DISTRIBUTION LIST (Continued)

General Atomic, A Division of General Dynamics Corporation P. O. Box 608 San Diego, California 92112 Attn: D. B. Coburn	1	Plutonium Laboratory Leechburg, Pennsylvania 15656 Attn: William J. Ross	1
The Babcock & Wilcox Company Alliance Research Center Alliance, Ohio 44601 Attn: D. Koch	1	U. S. AEC Scientific Representative United States Embassy London, England	1
Westinghouse Electric Corporation Advance Reactors Division P. O. Box 217 Cheswick, Pennsylvania 15024 Attn: W. E. Ray	1	S. F. Stachura Villa Plein Ail Quartier Roussier Aix-en-Provence 13 - France	1
Nuclear Materials & Equipment Corporation	1	S. Visner Nuclear Division Combustion Engineering, Inc. P. O. Box 500 Windsor, Connecticut 06095	2