NOV 13 1964

UCRL-7850 Rev. 1

MASTER

University of California Ernest O. Lawrence Radiation Laboratory

ECONOMICS OF GROUND WATER RECHARGE

~~NOT FOR PUBLIC RELEASE - OFFICIAL
DISTRIBUTION MAY BE MADE - OFFICIAL
REQUESTS MAY BE FILED - REPORT
CONTAINS NOTHING OF PATENT INTEREST
PROCEDURES ON FILE IN RECEIVING
SECTION~~

Livermore, California

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

UNIVERSITY OF CALIFORNIA
Lawrence Radiation Laboratory
Livermore, California

Contract No. W-7405-eng-48

ECONOMICS OF GROUND WATER RECHARGE

David K. Todd

September 28, 1964

This paper was submitted for publication in the open literature at least 9 months prior to the issuance date of this Microcard. Since the U.S.A.E.C. has no evidence that it has been published, the paper is being distributed in Microcard form as a preprint.

ECONOMICS OF GROUND WATER RECHARGE

by

David K. Todd,¹ M. ASCE

SUMMARY

Costs and benefits of artificially recharging ground water are reviewed to form a basis for economic evaluation of the technique. Alternative procedures, institutional and financial arrangements, and cost components are considered. Selected cost data, mostly from California projects, are summarized.

¹Prof. of Civil Engineering, Univ. of California, Berkeley.

ECONOMICS OF GROUND WATER RECHARGE

by

David K. Todd, M. ASCE

SYNOPSIS

Although artificial recharge of ground water is well known and widely practiced, little information on costs of the technique is available. This paper summarizes benefits and alternatives to artificial recharge, reviews cost components, and presents costs of selected projects. The value of water is reviewed followed by consideration of the direct and indirect benefits of recharging. Institutional and financial arrangements for artificial recharge projects are discussed. Particular attention is given to California's Water Replenishment District Act and the use of the replenishment assessment as a means for financing projects. A few data on costs of water wells and pumping ground water are presented because extraction of ground water is a part of the total recharge cost. Generalized cost estimates of various items involved in recharge projects are tabulated, followed by costs of actual projects in California and Illinois. Because of the variability of size, purpose, and method of operation, together with a wide range in land and water costs, no concise summary of recharge costs is possible. However, it is believed that the data assembled here will be useful to engineers planning and designing such projects.

INTRODUCTION

Today the purposes of artificial recharge of ground water in terms of conservation, storage, and purification are well known. Throughout the United States recharging is practiced wherever available ground water resources must be managed for maximum beneficial development.² In the Southwestern United States, where arid climates and concentrations of population are combined, the technique has found greatest application as evidenced by its rapid expansion in the region. California alone recharges more water underground than all other states combined.³

Although artificial recharge is widely practiced, little information has been assembled regarding its costs. Perhaps the reason lies in the fact that recharge projects vary greatly in size, purpose, and method of operation. Land and water costs are other significant variables. Yet, if engineers concerned with water resources management are to evaluate the economic feasibility of recharging, cost data must be collected and analyzed.

This paper attempts to summarize benefits and alternatives to artificial recharge, to review cost components of artificial recharge projects, and to summarize costs of selected artificial recharge projects.

METHODS OF ARTIFICIAL RECHARGE

Works for artificially recharging ground water are designed to increase infiltration rates, wetted area, and duration of infiltration over that occurring naturally. Most projects may be classified by method as follows: basins, modified stream beds, pits, ditches and furrows, flooding, and injection wells. Richter and Chun⁴ showed that a majority of projects in California were of the basin type, while the basin and modified stream bed types accounted for more than 80 per cent of all water recharged.

The various methods of artificial recharge have been extensively discussed in the literature^{5,6} so that further elaboration here is unnecessary.

VALUE OF WATER

In assessing the benefits of artificial recharge, consideration must be given to the importance of water to the total economy, to the value of water for various uses, as well as to the direct and intangible benefits which may accrue. Furthermore, because storage, underground distribution, and re-use of water are involved, the importance of the method as a technological necessity for water resources development needs to be assessed.

Water is an extremely low-cost item on a unit-cost basis, yet the large volumes consumed, together with the increasing costs of its production, make impressive totals in terms of expenditures involved. Recently, in a worldwide review by Scientific American of technology and economic development, Revelle⁷ analyzed the role of water. The following excerpt is an excellent statement of the economic significance of water.

"Although it is usually not reckoned as such in economic statistics, water can be considered a new material. In the U. S. the production of raw materials has a minor role in the total economy, and water costs are small even when compared with those of other raw materials. The cost of all the water used by U. S. householders, industry and agriculture is around \$5 billion a year: only 1 per cent of the gross national product. The less developed countries, where raw materials are a major component of the economy, cannot afford water prices that would be acceptable in the U. S.

"In the U. S. water costs \$10 to \$20 an acre-foot, compared with wholesale prices of \$22,000 an acre-foot for petroleum, \$100,000 an acre-foot for milk and \$1 million an acre-foot (not counting taxes) for bourbon

whiskey. The largest tanker ever built can hold less than \$1000 worth of water. Yet Americans use so much water — about 1700 gallons a day per capita — that capital costs for water development are comparable to other kinds of investment. Although the water diverted from streams and pumped from the ground is equivalent to only about 7 per cent of the rain and snow falling on the U. S., this is still an enormous quantity: 200 times more than the weight of any other material except air. The annual capital expenditure of water structures in the U. S. — dams, community and industrial water works, sewage-treatment plants, pipelines and drains, irrigation canals, river-control structures and hydroelectric works — is about \$10 billion.

"One of the most critical water problems in the U. S. is represented by the vast water-short region of the Southwest and the high Western plains. In some parts of the Southwest water stored underground is being mined at an alarmingly high rate, and new sources must soon be found to supply even the present population. The average annual supply of controllable water in the entire region is 76 million acre-feet. If agriculture continued to develop at the present rate, 98 to 131 million acre-feet would be required by the year 2000. Provided that the neighboring water-surplus regions could be persuaded to share their abundance, this deficit could be met by long-distance transportation of 22 to 55 million acre-feet per year. But the annual cost would be \$2 billion to \$4 billion, or \$60 to \$100 per acre-foot of water, including amortization of capital costs of \$30 billion to \$70 billion. The cost per acre-foot would be too high for most agriculture, although not too high for municipal, industrial and recreational needs.

"Nathaniel Wollman of the University of New Mexico and his colleagues have shown that the average value added to the economy of the Southwest through the use of water in irrigation is only \$44 to \$51 an acre-foot, whereas

the value gained from recreational uses could be about \$250 an acre-foot and from industrial uses \$3000 to \$4000 an acre-foot. Because the quantities of water consumed by city-dwellers and their industries are much less than those in agriculture, the arid Western states would not require such a vast increase in future supply if they shifted from a predominantly agricultural to a predominantly industrial economic base."

It is clear that analysis of the benefits of artificial recharging is dependent upon what value can be assigned to a unit volume of water. The price of water varies widely, being controlled by its source, use, quality, and the economic criteria of supply and demand. In general, water for municipal and industrial purposes is priced at many times that for agricultural purposes. It is also apparent that prices of water are rising rapidly with the possible exception of agricultural water provided under Federal subsidy.

Renshaw⁸ analyzed the value of water in terms of use. His data are summarized in Table 1. Because water can be used for several purposes simultaneously, the aggregate value of water at any point is the sum of individual use values. In addition, water returned to a stream or reservoir may be used to generate values at other points of use.

Values in Table 1 are gross values as other appurtenant costs are included. For municipal and industrial water, for example, costs of purification and distribution are included. Renshaw points out that the net worth of water is difficult to determine because there is not an active market in water rights; therefore, the best estimate of relative water values may be either distributions of market prices paid for water at points of use or distributions of actual costs incurred in putting water to work. Comparison of gross values is often inaccurate as an arbitrary decision to include or exclude a given cost element could have a significant effect. Although no attempt was

made to assign monetary values to recreational and aesthetic attributes of water, it is apparent that these factors could become quite important for some water bodies.

TABLE 1. VALUE OF WATER IN THE UNITED STATES
FOR VARIOUS PURPOSES, 1950⁸

Purpose	Maximum Value, dollars/acre-foot	Mean Value, dollars/acre-foot
Domestic Water Supply	\$235.66	\$100.19
Industrial Water Supply	163.35	40.73
Irrigation	27.04	1.67
Power	5.90	0.71
Waste Disposal	2.56	0.63
Inland Navigation	1.17	0.05
Commercial Fisheries	1.06	0.025

The largest wholesaler of water in Southern California is The Metropolitan Water District of Southern California. Its water is transported from the Colorado River by aqueducts to markets in the coastal area from Los Angeles to San Diego. A majority of the District's income comes from an advalorem tax assessment, while a minor portion comes from water sales. The price schedule for Metropolitan Water District water is shown in Table 2 from its first delivery in 1940 to 1966 together with proposed water prices from 1966 to 1990. In 1958 separate rates for domestic and municipal use and for agricultural use and ground water replenishment were established. The differential recognized the limited ability to pay of agricultural users. It was also designed to encourage agricultural use and artificial recharge of ground water reservoirs. This purpose has been served: in 1961-62 38.3 per cent of all imported Colorado River water was used for ground water replenishment.

TABLE 2.—PRICE OF COLORADO RIVER WATER SOLD BY THE METROPOLITAN WATER DISTRICT OF SOUTHERN CALIFORNIA, 1940-1990* (DOLLARS PER ACRE-FOOT)

Effective Date	Domestic and Municipal Use			Agricultural Use and Ground Water Replenishment		
	Softened and Filtered	Softened	Untreated	Softened and Filtered	Filtered	Untreated
12/20/40	\$15.00		\$ 8.00			
7/1/48	18.00		8.00			
7/1/50	20.00		10.00			
12/1/54	18.00		8.00			
5/1/55	22.00		10.00			
11/1/55	18.00		8.00			
12/1/55	20.00		10.00			
7/1/57	22.00		12.00			
7/1/58	25.00		15.00	\$22.00		\$12.00
7/1/60	23.00		15.00	20.00		12.00
1/1/61	25.00		17.00	20.75		12.75
1/1/62	27.00		19.00	21.50		13.50
1/1/63	29.00		21.00	22.25		14.25
1/1/64	32.00	\$29.00	24.00	23.00	\$20.00	15.00
7/1/64	34.00	30.00	25.00	24.25	20.25	15.25
7/1/65	37.00	33.00	28.00	25.00	21.00	16.00
7/1/66	40.00	36.00	31.00	26.00	22.00	17.00
7/1/67**				34.00		18.00
7/1/68				37.00		19.00
7/1/69				40.00		20.00
7/1/70				43.00		21.00
7/1/71				46.00		22.00
7/1/78				49.00		23.00
7/1/81				52.00		24.00
7/1/88				51.00		23.00

*Data from Miller⁹ (4) and data furnished by the District.

**Rates on and after July 1, 1967 are proposed and have not yet been acted upon by the MWD Board.

DIRECT BENEFITS OF ARTIFICIAL RECHARGE

Evaluation of benefits received from operation of a surface water system can be measured by estimates of the revenue which will accrue as a result of the project. However, artificial recharge projects are generally not so susceptible of expression in explicit form. Organizations conducting recharging may receive only partial benefit, identification of recharged water is often impossible, and quality differences may complicate monetary evaluations. The basic benefits of artificial recharge of ground water can be classified under two categories: (a) relief of overdraft, and (b) use of ground water basins as cyclic storage and distribution systems.

By counteracting overdraft of a ground water basin, artificial recharge may provide the following specific benefits:

- (a) Lower operating costs for ground water supplies by lessening pumping lifts.
- (b) Eliminate capital expenditures for purpose of deepening wells.
- (c) Increase farm income as a result of augmented and dependable water supplies.
- (d) Reduce incidence of premature abandonment of wells.
- (e) Increased municipal expansion resulting from augmented sub-surface water supplies.
- (f) Prevent sea water intrusion into coastal aquifers.
- (g) Prevent release of deep-seated connate brines into the aquifer.
- (h) Prevent dewatering of all or part of the underground reservoir.
- (i) Prevent land subsidence by sustaining ground water levels.

Use of underground reservoirs as storage and distribution systems is analogous to the operation of a surface reservoir and distribution system. The usable capacity of the ground water reservoir can be developed by

planned extractions of ground water during periods of low precipitation, while subsequent replenishment can be made during periods of surplus surface supply. Such a conjunctive operation with surface and subsurface water supplies presupposes that there is sufficient ground water storage to meet requirements for regulation of local and imported water supplies, and that the aquifers possess sufficient transmissibility to permit movement of recharged water to the area of extraction. The basic difference between the usual surface water development with its associated ground water development and conjunctive operation of surface and ground water reservoirs is that the separate firm yields of the former may be replaced by a more economic joint yield in the latter.³

The benefits of conjunctive operation of all water resources are several. These include:

- (a) Saving in cost of developing equivalent usable storage capacity in a surface storage reservoir.
- (b) Saving in cost of constructing an equivalent surface distribution system and with regard to peak requirements.
- (c) Increased total water supply available for use.
- (d) Small drainage system required in irrigated areas as wells aid in controlling the water table.
- (e) Reduced canal lining as seepage from canals becomes a benefit as artificial recharge.
- (f) Greater flood control as release of stored surface waters for artificial recharge reduces the flood control reservation.
- (g) Smaller evapotranspiration losses for water stored underground than above ground.

- (h) Improvement of power load and pumping plant use factors in areas served by either surface or ground water, as surface water can be released for irrigation during peak power demand periods to effect a saving in power costs.

INTANGIBLE BENEFITS OF ARTIFICIAL RECHARGE

Adequate storage of ground water supplies in a metropolitan area provides a high degree of protection of water supply and thus an important safety measure. Ground water supplies are much less susceptible to contamination as compared to surface reservoirs; similarly, their reduction from danger of destruction of reservoir structures and wide dispersion of outlet facilities make ground water basins of inestimable value as an emergency supply. Such considerations are of paramount importance in Los Angeles, for example, where widespread disasters such as dam failures, severed aqueducts, earthquakes, or atomic attacks could paralyze surface water facilities.

ALTERNATIVES TO ARTIFICIAL RECHARGE

Construction and operation of an artificial recharge project implies the desirability or necessity of either augmenting the existing water supply or utilizing the underground storage capacity for storage and distribution of local and imported water supplies. In order for a recharge project to be successful, field conditions must be such as to provide for appropriate storage, movement, and utilization of recharge water. The California Department of Water Resources has enumerated the following physical requirements on recharging. These are arranged in the probable order of their significance:

- (a) Geology — The basin must be suitable from the standpoint of storage capacity and transmissibility of aquifers.

(b) Water — Adequate water must be available for the purpose of controlled recharge.

(c) Infiltration — Recharge rates must be maintained at adequate levels in spreading areas.

(d) Drainage — Where a water table is near ground surface, adequate storage capacity in the basin for recharging must be provided.

(e) Water Quality — Recharged water must be chemically compatible with existing ground water.

(f) Recovery Efficiency — Pumping lifts must not be excessive, installed pumping capacity must be efficiently used, and quality of water recovered must be satisfactory.

If a limitation exists on one or more of the physical requirements for recharging, the only alternative is surface storage. Because the purpose of an artificial recharge project is to store and deliver an adequate water supply at a minimum cost, recharging must be considered in competition with the alternative of surface storage and distribution. Implied in this is that the cost of pumping recharged water must be included to deliver water to a point of use.

Although artificial recharge in particular situations may not be able to store and supply water at a lower cost than surface facilities, surface storage alone will be inadequate to meet ultimate water requirements of California. Furthermore, surface storage will become steadily more costly as the remaining combinations of good dam sites with surface reservoir sites of adequate storage capacity are exhausted. In general, capital expenditures for artificial recharge will be less than for equivalent surface storage facilities; however, the acquisition of land and rights of way in highly urbanized areas may present major economic problems.

INSTITUTIONAL AND FINANCIAL ARRANGEMENTS

In 1958 the 276 artificial recharge projects in California were operated by 54 agencies, most of which were various types of public water districts.⁴ Projects were financed by (a) sale of general obligation bonds, (b) revenues from sales of water, power, property, water rights, leases, etc., and (c) direct assessments.

In 1955 the California legislature enacted a Water Replenishment District Act specifically designed to meet the assessment problems attending artificial recharge projects. Districts organized under this act are authorized to levy assessments in proportion to the amount of water pumped from underground supplies. This is of particular importance in making equitable assessments of those holding appropriative and prescriptive rights to use water on non-overlying land. The organization of water replenishment districts is presently limited to the counties of Santa Barbara, Ventura, Los Angeles, San Bernadino, Orange, Riverside, and San Diego.

The powers of a water replenishment district are very broad, as indicated by the following sections of the California Water Code:

"60220. A district may do any act necessary to replenish the ground water of said district.

"60221. Without being limited to the following enumerations, a district may, among other things, but only for the purposes of replenishing the ground water supplies within the district:

- (a) Buy and sell water;
- (b) Exchange water;
- (c) Distribute water to persons in exchange for ceasing or reducing ground water extractions;

- (d) Spread, sink and inject water into the underground;
- (e) Store, transport, recapture, reclaim, purify, treat or otherwise manage and control water for the beneficial use of persons or property within the district;
- (f) Build the necessary works to achieve ground water replenishment.

"60222. A district may take any action necessary to protect or prevent interference with water, the quality thereof, or water rights of persons or property within the district, subject to the limitations contained in Section 60230.

"60223. For the purposes of replenishing the ground water supplies within the district, a district may do any act in order to put to beneficial use any water under its control or management."

The powers of a district further include the right of eminent domain, the right to cause assessments and/or charges to be levied, and the right to carry on technical and other investigations. A district may borrow money, incur indebtedness, issue bonds, cause taxes to be levied, fix rates for services, and fix rates at which water shall be sold for replenishment purposes. It may also act jointly or cooperate with any entity, public or private, to the end that purposes and activities may be fully and economically performed.¹⁰

Central and West Basin Replenishment District. The Central and West Basin Water Replenishment District was created by a favorable vote of the people in 1959. The district embraces the coastal plain of Los Angeles County south and west of the center of the City of Los Angeles. It has an area of 420 square miles and 29 incorporated cities are included in the area.

In its first year of operation the district levied a replenishment assessment, or pump tax, on all ground water pumped. The tax is revised

annually to fit costs of purchasing Colorado River water for ground water recharge. Following are the annual charges levied by the district:

<u>Year</u>	<u>Pump Tax, Dollars/acre-foot</u>
1960-61	\$3.19
1961-62	5.75
1962-63	6.63
1963-64	6.58

The district purchases water from Metropolitan Water District at the replenishment rates shown in Table 2. It also buys at the same prices 10,000 acre-feet per year of reclaimed waste water produced at Whittier Narrows by Los Angeles County Sanitation District No. 2. Revenues from sale of reclaimed water are expected to cover operating costs of the reclamation plant and to repay the loan for the plant to Los Angeles County in 30 years.

Orange County Water District. In recent years Orange County Water District has recharged the largest volume of imported Colorado River water in Southern California. The district obtained its funds for the first purchases of imported water in 1949 from an ad valorem tax on real property that was then restricted to 15 cents per \$100 of assessed value. The tax, however, did not provide enough money to buy imported water in the quantities needed to offset annual overdrafts. To meet the need to raise additional water on an equitable basis, the Orange County Water District Act was amended in 1953 by the California legislature. The changes provided for a new source of revenue in the form of a replenishment assessment, or pump tax, on the production of ground water.

The limit on the ad valorem tax was reduced from 15 cents to 8 cents per \$100 of assessed value, with funds from this source to be used to defray

the administrative costs of the District and to buy enough water to replace in a 10-20 year period the long-time accumulated overdraft.

The pump tax has increased from \$3.50 per acre-foot of water pumped in 1953 to \$6.00 in 1962. In the first seven years of operation the assessment raised \$5,400,000, while in addition the ad valorem tax raised \$3,555,000. The District's act was amended in 1961 to permit levying an additional pump tax on the production of water for non-irrigation use. Thus, a two-rate pump tax was created favoring agricultural interests using ground water. It also equalizes the purchase price of Colorado River water with the cost of ground water for cities connected to Metropolitan Water District lines and capable of securing imported water. Amendments also increased the ad valorem tax to purchase additional water to recharge the basin. The District expects to purchase and spread 210,000 acre-feet of water per year from the Metropolitan Water District as long as such water is available.

COST COMPONENTS OF ARTIFICIAL RECHARGE PROJECTS

Costs of proposed artificial recharge projects must be ascertained to determine economic justification and financial feasibility. ASCE Manual of Engineering Practice No. 40 (2) points out the variety and variability of costs associated with artificial recharge projects.

A convenient check list of costs for artificial recharge projects, prepared by the California Department of Water Resources, is shown in Table 3. Corrective actions for many of the operation and maintenance problems have been discussed in detail elsewhere.⁴

Direct comparison of costs of projects constructed at different times requires adjustment to a common base. The Engineering News-Record Construction Cost Index, defined in terms of basic construction materials

and common labor, serves as a valid basis for comparing artificial recharge project costs. The importance of this adjustment can be noted by observing that the Index has increased from 200 in 1930 to greater than 900 in 1963.

TABLE 3. -CHECK LIST OF OPERATION AND MAINTENANCE AND
CONSTRUCTION AND ENGINEERING COSTS FOR ARTIFICIAL
RECHARGE PROJECTS*

I. Operation and Maintenance

A. Field

1. Grading
2. Cleaning shoulders
3. Storm protection
4. Crushed rock or graveling (riprap)
5. Moving
6. Painting
7. Structure repair
8. Excavation (removing silt)
9. Miscellaneous
10. Equipment maintenance and fuels
11. Equipment rental
12. Spreading ground repairs - replacement
13. Discing
14. Weed control
15. Rodent control
16. Patrolling
17. Treatment of water
18. Injection well maintenance
19. Repair sides of basins due to washouts

B. Office

1. Supervision
2. Wages of personnel
3. Insurance liability (drowning)
4. Legal fees (Attorney)
5. Office expenses, such as stationery, telephone, etc.
6. Maintenance of office machines
7. Building expenses (rent, utilities, etc.)
8. Taxes
 - (a) Land
 - (b) Agency
9. Interest
10. Miscellaneous

II. Construction and Engineering

A. Structures

1. Conduit, closed-open, ditches
2. Recording devices
3. Control, structures
4. Operator's residence
5. Flood protection of grounds
6. Overflow drainline
7. Spreading ground
 - (a) Dikes
 - (b) Basins
 - (c) Roads
 - (d) Dams
 - (e) Diversion
 - (f) Equipment housing
 - (g) Pipe lines
 - (h) Intake structures
8. Fences
9. Trespassing signs
10. Lighting

B. Engineering

1. Surveys
2. Mapping
3. Design
4. Lab tests
5. Inspection
6. Consultation
7. Preliminary study

*Furnished by California Department of Water Resources

Water Wells and Ground Water Production. Although the costs of water wells and production of ground water are not direct artificial recharge costs, they nevertheless must be considered in the total analysis of an artificial recharge project compared to an alternative surface storage and distribution project. Extraction and delivery of recharged water to a surface distribution point becomes a part of the overall project cost.

Water well costs are a function of the size, depth, type, and location of wells. Heavy production wells for irrigation or municipal water supply represent a major capital investment. They are usually constructed with

large diameters, corrosion-resistant casings, and gravel packs around the casings to insure high yields over a long life. The following paragraphs, summarizing actual costs of irrigation and municipal wells, are indicative of the costs involved in producing ground water. Detailed cost breakdowns for these data are available.¹¹

An analysis of costs for producing ground water at one pumping plant was made by the City of Santa Ana, California, in 1960. The plant, containing two deep wells, produced water at a cost of \$13.53 per acre-foot. It should be noted that the cost of water produced included costs of wells, power, reservoir, booster station, and well buildings.

Cost of producing ground water supplies by the City of Anaheim, California, during 1960 ranged from \$10.43 to \$22.77 per acre-foot among seven wells studied. The weighted average cost was \$13.62 per acre-foot. These costs include the Orange County Water District pump tax; without it, the weighted average cost would have been reduced to \$8.65 per acre-foot of water pumped.

A detailed breakdown of costs for producing ground water for agricultural use in Orange County, California, was prepared in 1958 by the Orange County Water District. This analysis included capital, maintenance, and power costs for 11 irrigation wells located in representative agricultural areas of the District. The average cost per acre-foot of water pumped ranged from \$6.02 to \$25.95 among the 11 wells with a weighted average of \$9.21. All cost data were adjusted, as needed, to apply to the 1956-58 period. These data do not include any pump tax.

In 1957 a study was made of the cost of producing ground water for irrigation in Harmon County, Oklahoma.¹² Data were collected on some 25 wells irrigating about 100 acres each. It was found that capital costs (fixed

costs) varied from \$2.38 to \$25.66 per acre-foot pumped and averaged \$7.20. In addition, operating costs ranged from \$1.45 to \$6.42 per acre-foot pumped and averaged \$3.11. Thus, the average total cost of the water was \$10.31 per acre-foot.

Studies by agricultural economists at the University of California, Davis, have provided valuable information on costs of ground water production for irrigation in the San Joaquin Valley, California.¹³ Data were analyzed for some 11,000 wells; pumping plants ranged from 5-horsepower motors lifting less than 100 gal/min. to 300-horsepower units discharging more than 2000 gal/min. The distance ground water must be lifted proved to be the most important single factor in the cost. The investment and annual per acre-foot costs of pumping water at 1959 prices ranged from \$2.40 per acre-foot at the northern end of the valley to \$22.63 per acre-foot on the dry west side portion.

Dams. Where dams are built to store water for subsequent artificial recharge, the cost of the dam becomes part of the total cost of an artificial recharge project. Often, however, a reservoir serves other purposes as well — such as flood control, water supply, hydropower, and recreation. For multiple-purpose operation, costs must be prorated among the various benefits.

Information is available on costs of six rolled earth-fill dams constructed in 1935 and 1936 by Santa Clara Valley Water Conservation District. Details of the dams and their costs are listed in Table 4. In the same District it was reported that low sausage dams (consisting of Page wire fencing held in place by steel fence posts driven into the creek bed) for modified stream channel spreading cost \$7.00 per lineal foot in 1938.

TABLE 4. -DESCRIPTION AND COST OF SIX ROLLED EARTH-FILL DAMS CONSTRUCTED BY SANTA CLARA COUNTY WATER CONSERVATION DISTRICT^a

Dam	Year Constructed	Reservoir Capacity, (acre-feet)	Height of Crest above Stream bed (ft)	Fill (yd ³)	Cost
Almaden	1935	1972	105	250,000	\$446,924 ^b
Calero	1935	9213	90	550,000	440,726 ^b
Coyote	1936	24,560	120	1,060,000	915,218 ^c
Guadalupe	1935	3460	129	520,000	361,565 ^b
Stevens Creek	1935	3966	120	530,000	441,329 ^b
Vasona	1935	750	30	70,000	197,757 ^d

^aData furnished by the District.

^bIncluding spillway and road.

^cIncluding spillway.

^dIncluding an estimated \$30,000 for Vasona Canal.

COSTS OF EXISTING ARTIFICIAL RECHARGE PROJECTS

Generalized Cost Estimates. In Table 5 is a listing of items to be considered in artificial recharge projects, together with estimated costs or remarks. This information was furnished by the California Department of Water Resources and represents conditions as of 1957. The detailed check list of cost items shown as Table 3 should also be consulted in this connection.

TABLE 5.—ESTIMATED COSTS FOR COMPONENTS OF ARTIFICIAL
RECHARGE PROJECTS IN CALIFORNIA, 1957*

Capital Costs Item	Estimated Cost
Land acquisition	\$10-100/acre; may be donated or leased
Access rights-of-way	Generally same as land costs
Buildings	Office space, maintenance yard, and shops; may be constructed, rented, or shared
Reservoir site and clearing	\$50-250/acre
Leveling	\$30-100/acre
Dams	Cost may be shared by flood control
Canals	\$0.30-1.50/yd ³
Diversion structures	\$500. and up
Levees	\$0.35-1.50/yd ³
Roads	\$100 and up (should be gravel)
Measuring devices	Meters, weirs, Parshall flumes, \$50-500/unit
Control valves	\$10-100/unit
Conduit	Concrete, metal, wood, earth
Fences	\$0.25-1.50/ft
<u>Annual Costs</u>	
Water	0-\$20/acre-ft
Interest	0-6%
Loss of income from productive land	\$30-100/acre
Repayment	50-year period
Replacement	50-year period
Operation and maintenance	High variable: rodent control, flood damage, silt removal, vegetation control, algae control, wave action damage, structural repair
General expenses	Administration, personnel, equipment, legal, engineering, office expenses
Pumping costs to recover recharged water	\$2-8/acre/ft

*Data furnished by California Department of Water Resources

Table V. (Con't)

Capital Costs Item	Estimated Cost
<u>Life of Works</u>	
Levees	50 years
Wood structures **	10 years
Buildings	30 years
Permanent works	50 years

** Also including structures buried in the ground or exposed to water

Los Angeles County Flood Control District. Los Angeles County Flood Control District operates some 23 spreading grounds. Of these, four basin grounds and three pit grounds were selected for cost analysis. The selection was made with the help of District personnel in an effort to obtain representative cost data for large and small as well as old and new spreading grounds. Costs per acre-foot of water recharge are listed in Tables 6 and 7. The following subsections contain brief descriptions of the individual grounds, and the final one describes the basis for ascertaining some of the cost figures.

Wet and dry cycles will affect recharge costs, as well as whether the source of water for spreading originates from uncontrolled runoff or from controlled dam releases. If imported water must be purchased, an additional cost must be included.

A. Rio Hondo spreading grounds. This is a large water-spreading area consisting of shallow basins about 5 feet deep, occupying a gross area of 423 acres (in 1959-60), and having a wetted area of 370 acres. The basins are situated in a premium location, hydrologically speaking. The land was purchased by the District and purchase costs are regarded as average. About one-half of the water spread (88,000 AF) was storm water,

TABLE 6.—COSTS OF SELECTED SPREADING GROUNDS OPERATED BY LOS ANGELES
COUNTY FLOOD CONTROL DISTRICT^a

	Rio Hondo Spreading Grounds	Sawpit Spreading Grounds	Pacoima Spreading Grounds	Santa Fe Reservoir Spreading Grounds
Operation and Maintenance ^b	\$ 3.50	\$13.00	\$ 3.40	\$ 1.25
Supervision of O & M	1.00	1.00	0.80	1.00
Office Engineering	0.30	1.00	0.25	0.04
Rights-of-Way	3.25	4.00	0.75	0.00
Development ^{c, d}	7.00	22.00	4.40	0.85
Clearing and Scarifying	1.50	5.00	1.10	0.09
Repairs	1.50	2.50	0.60	0.05
Total Cost per Acre-Foot	\$18.05	\$48.50	\$11.30	\$ 3.28
Total Water Spread, AF	172,000	2100	62,600	16,500
Period of Operation	1937-60	1946-60	1932-60	1954-60

^a All cost figures are in dollars per acre-foot of water spread, and are actual unadjusted costs.

^b Total operation and maintenance cost includes operation and maintenance, supervision of operation and maintenance, and office engineering.

^c Total capital investment includes development, clearing, and repairs.

^d Development consists of District engineering and surveys, basins, structures, fences, and buildings.

TABLE 7.—COSTS OF SELECTED RECHARGE PITS OPERATED BY
LOS ANGELES COUNTY FLOOD CONTROL DISTRICT^a

	Peck Road Pit	Buena Vista Pit	Eaton Spreading Basin
Operation and Maintenance ^b	\$ 9.50	\$ 0.50	\$ 6.60
Supervision of O & M	8.00	0.80	0.80
Office Engineering	0.13	0.03	0.20
Rights-of-Way	7.90	0.00	4.90
Development ^{c, d}	15.00	0.70	3.70
Clearing and Scarifying	0.80	0.40	2.70
Repairs	3.70	1.25	0.60
Total Cost per Acre-Foot	\$45.03	\$3.68	\$19.50
Total Water Spread, AF	1000	6100	2500
Period of Operation	1959-60	1959-60	1956-60

^a All cost figures are in dollars per acre-foot of water, recharged, and are actual unadjusted costs.

^b Total operation and maintenance cost includes operation and maintenance, supervision of operation and maintenance, and office engineering.

^c Total capital investment includes development, clearing, and repairs.

^d Development consists of District engineering and surveys, basins and structures, and fences and buildings.

which was stored upstream by reservoirs and released as needed. There was no charge for this water. The remaining water (84,000 AF) was purchased from the Metropolitan Water District for \$20.00/acre-foot. Funds came from ad valorem taxes of \$0.04 per \$100 assessed valuation in a local conservation district (Zone I).

B. Sawpit Spreading Grounds. This is a small group of shallow basins about 3 feet deep, having a gross area of 11.6 acres, and a wetted area of 3.8 acres. This is regarded as an excellent location in terms of efficiency of water spreading, but costly in terms of land value. Only storm water is spread here. Costs tend to decrease with time as development is prorated over a longer period. Land costs are figured at 4 per cent of initial cost annually throughout period of use. Office engineering is figured at 5 per cent of development for an indefinite life. This project is considered to be a relatively expensive one for water spreading.

C. Pacoima Spreading Grounds. These are shallow spreading basins having a depth of 5 feet, occupying an area of 175 acres, and having a wetted area of 122 acres. The land was purchased by the District. Storm water is spread here; therefore, the degree of control depends upon the seasonal availability of water. This is the oldest spreading ground in the District and costs are stable.

D. Santa Fe Reservoir Spreading Grounds. As this land is part of the flood control basin of the Corps of Engineers, there is no land cost involved. These are shallow basins 3 to 5 feet deep, occupying a gross area of 193 acres, and having a wetted area of 133 acres. All water spread is storm water, part being stored and part being natural flood waters. Because of zero land and water costs, together with minimum operation and maintenance costs, this project gives the least cost for water spreading.

E. Peck Road Pit. This project consists of three pits approximately 60 feet deep excavated by a gravel company and subsequently condemned and purchased by the District. The gross area is 156 acres of which 85 acres are wetted. Only local storm water is spread. Part of the high cost of this project can be attributed to the fact that costs have been incurred since 1954, but no water was spread until 1959.

F. Buena Vista Pit. This is the smallest and least expensive pit operated by the District. The pit is an abandoned gravel pit purchased by the District. Its gross and wetted area is 10 acres. Storm water and excess irrigation water is recharged. There is no cost for land because the pit is figured as a flood control benefit. The actual purchase price of the land was \$4000 per acre.

G. Eaton Spreading Basin. This is a 60-foot-deep abandoned gravel pit purchased by the District from a gravel company. The pit has a gross

area of 16 acres and a wetted area of 10 acres. Only storm water is re-charged and the pit is self-operating. This is considered by the District to be a typical pit in terms of size and developmental costs.

H. Method for Computing Costs. The cost of water varies with the availability of water. During a dry cycle spreading costs will slowly increase, while during a wet cycle costs will rapidly decrease.

Table 8 contains a summary of assumptions made in determining costs by the District.

TABLE 8.—BASIS FOR COST EVALUATIONS OF ARTIFICIAL RECHARGE PROJECTS BY LOS ANGELES COUNTY FLOOD CONTROL DISTRICT

A. Life of Items

Land	Continuous at 4% interest
Land Acquired by Perpetual Easement	50 years
Permanent Structures and Basins	50 years
R/W, Surveying, Mapping	50 years
Recorders	50 years
Shelter Houses	30 years
Fences	30 years
Wood Structures	20 years
Temporary Structures	10 years
Maintenance and Operation	1 year
Clearing and Repairs	1 year

B. Annual Costs

Interest on purchase price of land at 4 per cent. (When an area is rented or leased by the District to some outside agency for use until development, the income is subtracted from the annual interest.)

Interest and sinking fund for depreciation at 4 per cent on all items with a limited life.

Cost per year charges are entered the first year chargeable and each succeeding year for the life of the item.

Orange County Water District. One of the largest water spreading projects in Southern California is conducted along the Santa Ana River in Orange County by the Orange County Water District. Costs of spreading for

the 9-year period 1953-1962 are summarized in Table 9. Note that the total cost, exclusive of water purchase and land acquisition, for spreading more than one million acre-feet of water amounted to \$449,000 or only \$0.43 per acre-foot of water. This was distributed as follows: \$0.22 for salaries and administrative costs; \$0.19 for equipment, including gas, oil, and repairs; and \$0.02 for the prorated cost of capital investment on fixed assets, excluding land.

The District owns approximately 800 acres of land both within and outside of the Santa Ana River. The total purchase price of the land approximates \$435,000; however, the district has received in excess of \$750,000 in royalties for sand and fill material which has been removed from these properties by permittees. For the 9-year period shown in Table 9, income from sale of sand and fill material totaled \$566,274, which considerably exceeds the sum of all operating costs. And, incidentally, removal of this material has greatly improved the lands for spreading operations. The astute management of recharging by this District could well be a model for others to follow.

Santa Clara Valley Water Conservation District. Since the 1930's local water has been recharged in Santa Clara County by the Santa Clara Valley Water Conservation District. Originally, spreading was by the modified stream channel method; more recently, basins, or percolation ponds, have been constructed. Table 10 shows the volume of water diverted to beneficial use (District personnel stated that more than 80 per cent was recharged underground while less than 20 per cent went for direct surface irrigation), total income, and cost per acre-foot (assuming all income was expended). Costs vary widely from year to year, primarily because of the variability of local water available for recharge. The average cost per acre-foot for the 10 years 1953-1963 amounts to \$17.60.

TABLE 9.—ORANGE COUNTY WATER DISTRICT WATER SPREADING
COSTS 7/1/53 THROUGH 6/30/62* (9-YEAR PERIOD)

Salaries & Administration			
Salaries, Including Administration	\$185,128		
Social Security	3,800		
Hospitalization	600		
Workmen's Compensation Insurance	4,680		
Mileage & Miscellaneous Expense	2,270		
Other Overhead Costs	37,026		
Sub-Total			\$233,504
Maintenance & Operation			
Utilities	1,974		
Gas, Oil, Repairs	37,332		
Field Operations Maintenance	20,240		
Equipment Rental	1,460		
Expendable Equipment:			
Small tools, pipe, etc.	30,481		
Tractors, autos, etc.	103,325		
Liability Insurance	9,240		
Sub-Total			204,052
Fixed Assets — Prorated for 9-Year Period			
Permanent Structures:	Total cost		
Atwood connector	20,895	418	
Crill delivery chute	43,898	878	
Crill diversion gates	9,295	186	
Fences	21,352	5,872	
Buildings	19,850	4,042	
Sub-Total			11,396
Grand Total all Costs			\$448,952
Total Water Spread: Colorado River (MWD)	865,020	acre feet	
Other non-local	182,655	" "	
Total	1,047,675	" "	
Cost of Spreading Per Acre Foot = $\frac{\$ 448,952}{1,047,675} = 42.9 \text{ cents}$			

* Data furnished by the District.

TABLE 10.—COST OF WATER DIVERTED TO BENEFICIAL USE BY
SANTA CLARA VALLEY WATER CONSERVATION DISTRICT, 1935-1963*

Year	Water Diverted to Beneficial Use (acre-feet)	Total Income
1935-36	36,150	\$ 179,796.70
1936-37	60,410	216,817.71
1937-38	61,170	208,668.96
1938-39	6,670	190,345.41
1939-40	39,990	190,193.81
1940-41	38,260	203,587.17
1941-42	36,340	217,988.29
1942-43	38,270	210,410.70
1943-44	38,680	169,325.71
1944-45	39,710	203,200.21
1945-46	41,000	192,337.53
1946-47	6,200	196,722.70
1947-48	6,340	217,170.86
1948-49	22,170	363,697.72
1949-50	13,440	599,107.34
1950-51	57,380	553,054.00
1951-52	49,630	566,411.31
1952-53	55,080	596,051.87
1953-54	52,580	716,153.30
1954-55	44,960	776,623.89
1955-56	65,110	909,202.29
1956-57	63,090	1,020,225.44
1957-58	61,770	1,310,430.45
1958-59	87,450	1,449,762.43
1959-60	72,410	1,139,428.63
1960-61	23,222	1,242,213.31
1961-62	80,000 (est.)	1,311,662.64
1962-63	90,000 (est.)	1,388,382.76

Average cost (assuming income equals costs)
for 1935-63 period amounts to
\$12.84 per acre-foot.

*Data furnished by the District.

Maintenance costs on an acre-foot basis for four selected percolation ponds are shown in Table 11.

During the period 1958-1960, the District purchased stream-bed land for \$1700 per acre, while off-stream land cost \$3575.

TABLE 11. -AVERAGE MAINTENANCE COSTS OF RECHARGE,
SANTA CLARA VALLEY WATER CONSERVATION DISTRICT

Area	Period	Maintenance Costs (dollars per acre-foot)
Coyote Percolation Ponds	1936-1961	\$0.13
Los Gatos Percolation Ponds	1959-1961	0.07
Penitencia Percolation Ponds	1938-1957	1.38
Penitencia Percolation Ponds	1957-1963	8.05
Main Avenue Percolation Ponds	1954-1962	1.37

With concrete gunning machines, 19.4 miles of canal were concrete-lined at a cost of \$0.42 per square foot. Hand clearing of aquatic weeds and algae in 20.5 miles of canals cost \$6820 in 1959. However, in 1960 using Aquilan, a new chemical herbicide from Shell Chemical Company, the cost was greatly reduced. It was estimated in 1961 that the cleaning with this chemical could be done for \$2180 on an annual basis.

Separan AP30, a new synthetic polymer designed as a flocculating chemical, was tested in 1959. Treatment consisted of adding the solution to a canal upstream from percolation ponds. With a concentration of 0.225 ppm of Separan in the water, turbidity was reduced from 618 ppm to 91 ppm on an 8-cfs flow for a cost of \$0.61 per acre-foot.

Peoria, Illinois, Recharge Pits. In the last 10 years recharge pits were constructed adjoining the Illinois River at Peoria, Illinois, in an effort to combat the overdraft resulting from heavy industrial pumping.¹⁴ River water, chlorinated but unfiltered, was released into the pits continuously, except in the summer months when river temperatures were high. The pits, located in highly permeable alluvium, accepted the water readily; cleaning was necessary only on an annual basis in most instances. The pits were constructed as an experiment by the Illinois State Water Survey, but their success has warranted their continued operation by the City of Peoria.

A summary of costs for one pit during 1954-56 and for two pits during 1956-1959 is presented in Table 12. Note that the unit operating cost drops significantly for two pits as compared with one pit.

Miscellaneous Cost Data. Construction and engineering cost data for several artificial recharge projects in these Southern California counties were assembled by the California Department of Water Resources and are reproduced as Table 13.

CONCLUSION

On the basis of economic data on projects to artificially recharge ground water presented in this paper, it is clear that the variables governing costs and benefits of artificial recharge preclude development of any concise summary. It is believed, however, that the data presented can be of assistance to engineers concerned with planning and designing such projects. Certainly, continued growth of the method requires that the economic feasibility of each new project can be demonstrated.

ACKNOWLEDGMENTS

The preparation of this report would not have been possible without the excellent cooperation of several agencies and organizations in California. Valuable cost data on artificial recharge were provided by the California Department of Water Resources, Los Angeles County Flood Control District, Orange County Water District, and Santa Clara Valley Water Conservation District. Costs of Colorado River water were furnished by the Metropolitan Water District of Southern California. This paper is abstracted from a report (Ref. 11) prepared under contract with the University of California Ernest O. Lawrence Radiation Laboratory, Livermore, California (work performed under the auspices of the U. S. Atomic Energy Commission).

TABLE 12.—COST OF ARTIFICIAL RECHARGE AT
PEORIA, ILLINOIS, PITS¹³

CAPITAL INVESTMENT					
Land and laboratory*	\$300,000				
Pit No. 1					
Observation wells		\$ 1,610			
Sheet piling and intake		14,350			
Control tower					
Structure	\$20,130				
Equipment	5,330				
Utilities	1,440				
	\$26,900	\$26,900			
Pipe lines, piping		8,610			
Pit excavation and sand		8,790			
Fencing		3,040			
Landscaping		100			
Total		\$63,400			
Pit No. 2					
Land**		\$15,000			
Pump, motor, flow meter, and other equipment		5,600			
Installation		4,730			
Pit excavation, gravel, pipe line		12,760			
Observation wells		4,460			
Fencing		2,050			
Miscellaneous		150			
Total		\$44,750			
OPERATING COSTS					
	One pit	Two pits			
	1954-55	1955-56	1956-57	1957-58	1958-59
Personal Services	\$ 6,600	\$ 7,500	\$ 9,920	\$ 9,425	\$ 8,705
Contractual Services					
Water	300	410	500	465	900
Electricity	185	250	1,900	1,775	1,450
Gas (for heat)	130	135	100	105	100
Pit Cleaning	1,600	1,765	1,500	---	---
Miscellaneous	15	110	535	905	895
Commodities					
Chlorine	975	1,580	2,800	2,770	2,550
Copper sulfate	---	---	45	50	50
Miscellaneous	60	415	85	30	90
Equipment	---	15	---	10	---
Totals	\$ 9,865	\$12,180	\$17,385	\$15,535	\$14,740
Unit Cost of Operation					
Recharge during season					
(acre-feet)	365.02	423.63	1,079.86	966.78	915.32
Unit cost, dollars/acre-foot	\$8.80	\$9.34	\$5.84	\$5.52	\$4.43

*Includes cost of land Pit No. 1

**Cost of a grant of easement and not outright purchase of land.

TABLE 13.—CONSTRUCTION AND ENGINEERING COST FOR ARTIFICIAL RECHARGE PROJECTS
IN SOUTHERN CALIFORNIA*

Project	Method of Recharge	Gross Area (acres)	Net Area (acres)	Years of Construction	Total Construction and Engineering Costs
Ventura County					
El Rio	Basin	125	111	1955	\$582,700.
Saticoy	Basin	Var.	Var.	Variable	310,805.
			39.8	1931-32	
Piru	Basin	63.9	43.2	1946-50	22,497.
Los Angeles County					
Rio Hondo Coastal	Basin	417	370	1937-52	282,442.
San Gabriel Coastal	Basin	127	96	1936-52	29,401.
Pacoima	Basin	179	122	1931-52	194,532.
Tujunga Wash	Basin &				
	Ditch	81	64.7	1931-32	68,526.
Sierra Madre	Basin	17	7	Var.	109,838.
San Bernardino County					
College Heights	Basin	28	21.3	1939-42	76,262.
				1939-42	
Eighth Street	Basin	32	20	1954-55	139,100.
Ely Street	Basin	32	20	1947-55	52,047.
Etiwanda	Basin	30	26	1954-57	9,705.
Twenty-Ninth Street	Basin	8.8	6.4	1951-55	127,741.
Devil Canyon	Basin &				
	Ditch	440	410	Var.	71,193.
Daley Canyon	Basin	30	21	1939-57	81,884.
Thirteenth Street	Basin	2.6	2.1	1946-55	25,184.
San Gorgonio	Basin &			1900-10	
	Ditch	1725	1300	1948-50	12,530.

*Data furnished by California Department of Water Resources.

REFERENCES

²Committee on Ground Water, Ground Water Basin Management, "Manual of Engineering Practice No. 40," ASCE, New York, 160 pp., 1961.

³Todd, D. K., Ground Water Hydrology, J. Wiley & Sons, New York, 336 pp., 1959.

⁴Richter, R. C., and R. Y. D. Chun, "Artificial Recharge of Ground Water Reservoirs in California," Proc. Amer. Soc. Civil Engrs., Vol. 85, No. IR-4, pp. 1-28, Dec. 1959.

⁵Muckel, D. C., "Replenishment of Ground Water Supplies by Artificial Means," Tech. Bull. No. 1195, U. S. Dept. of Agriculture, Washington, D. C., 51 pp., 1959.

⁶Todd, D. K., "Annotated Bibliography on Artificial Recharge of Ground Water through 1954," U. S. Geological Survey Water-Supply Paper 1477, Washington, D. C., 115 pp. 1959.

⁷Revelle, R., "Water," Scientific American, Vol. 209, No. 3, pp. 92-108, September 1963.

⁸Renshaw, E. F., "Value of an Acre-Foot of Water," Jour. Amer. Water Works Assoc., Vol. 50, pp. 303-309, 1958.

⁹Miller, D. T. (editor), "Report for the Fiscal Year July 1, 1961, to June 30, 1962, "The Metropolitan Water District of Southern California, Los Angeles, California, 165 pp., 1962.

¹⁰"Report on Proposed Central and West Basin Water Replenishment District," California Dept. of Water Resources, Sacramento, 76 pp. July 1959.

¹¹Todd, D. K., Economics of Ground Water Recharge by Nuclear and Conventional Means, UCRL-7850, Univ. of California Lawrence Radiation Lab., Livermore, California 135 pp., 1964.

¹²Davis, K. C. and J. F. Meek, "Economics of Ground Water Development on Farms in Southwestern Oklahoma," Oklahoma Agric. Exp. Sta. Bull. B-499, 30 pp., Nov. 1957.

¹³Moore, C. V., and T. R. Hedges, "Irrigation Costs of Pumping in the San Joaquin Valley," California Agriculture, pp. 3-4, October 1960.

¹⁴Suter, M., and R. H. Harmeson, "Artificial Ground-Water Recharge at Peoria, Illinois," Bull. 48, Illinois State Water Survey, Urbana, 48 pp., 1960.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.