382

568 pg
8/5

MASTER

UNIVERSITY of CALIFORNIA
LIVERMORE

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

TID-4500, UC-33
Propulsion Systems and
Energy Conversion

Lawrence Radiation Laboratory
UNIVERSITY OF CALIFORNIA
LIVERMORE

UCRL-50004-67-3 Part I

QUARTERLY REPORT
ADVANCED SPACE NUCLEAR POWER PROGRAM
July Through September 1967

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

24

Foreword

Starting with the 1967 third-quarter report, each quarterly report of the Advanced Space Nuclear Power Program is published in two parts. The first contains unclassified material only, the second contains classified material only. Hence the two volumes of this report, for example, are numbered UCRL-50004-67-3, Part I, and UCRL-50004-67-3, Part II.

Highlights and Summary

Highlights

MATERIALS

- Systematic studies of the physical and thermodynamic properties of uranium nitride have begun to yield meaningful data on its phase-equilibrium conditions and transition kinetics (p. 20), as well as on its compressive creep behavior (p. 29).

REFERENCE DESIGNS

- Studies of representative out-of-core thermionic power-conversion systems have been extended to power levels appropriate for auxiliary applications (about 100 kWe), and optimum configurations have been sought. The minimum system mass appears to be comparable to that promised by the Rankine cycle, and it is available at temperatures as low as 1800°K (p. 57).
- The near-final characteristics of the SPR-6 reference design are described (p. 88).

COMPONENT ENGINEERING

- The successful operation of an annular heat pipe coupled to an inert-gas plenum indicates that this device is useful as a remote-controlled isothermal heat sink for fuel-irradiation capsules (p. 107).

Summary

Good progress is being made toward assuring the feasibility of uranium nitride as the primary fuel choice. The techniques of manufacturing high-density UN are now well in hand, and most of the elements of a program for measuring the properties of UN are coming into active existence. The testing and exploratory fabrication of potential cladding and structural alloys is also well under way, but the results are quite diffuse because of the wide variety of alloys being considered. However, the alloy W-25%Re-30%Mo (at.%) is becoming a leading choice for comprehensive evaluation as a cladding material. Experimental work with alkali-metal coolants is still awaiting the availability of appropriate handling facilities and reliable sources of pure materials, but it is expected to begin during the coming quarter.

Our study of the SPR-6 reference design has been completed except for the final selection of a few alternative features and the publication of a final report. Design

attention is now turning strongly toward a lower power level suitable for the auxiliary power applications that early missions are expected to require, and toward the exploration of features that would enable a reactor to supply heat to both Rankine-cycle and other power-conversion systems. The out-of-core thermionic concept continues to show interesting characteristics in this respect.

Table of Conversions

Temperature conversion chart

Fahrenheit	0	500	1000	1500	2000	2500	3000	3500	4000
Rankine	500	1000	1500	2000	2500	3000	3500	4000	4500
Centigrade	0	500	1000	1500	2000	2500	3000	3500	4000
Kelvin	0	500	1000	1500	2000	2500	3000	3500	4000

Length

$$1 \text{ cm} = 0.394 \text{ in.}$$

$$1 \text{ m} = 3.28 \text{ ft}$$

Area

$$1 \text{ cm}^2 = 0.155 \text{ in.}^2$$

$$1 \text{ m}^2 = 10.8 \text{ ft}^2$$

Volume

$$1 \text{ cm}^3 = 6.10 \times 10^{-2} \text{ in.}^3$$

$$1 \text{ m}^3 = 35.3 \text{ ft}^3$$

Speed

$$1 \text{ m/sec} = 2.24 \text{ miles/hour}$$

$$= 3.28 \text{ ft/sec}$$

Mass

$$1 \text{ kg} = 2.20 \text{ lb}_m$$

Density

$$1 \text{ g/cm}^3 = 62.4 \text{ lb}_m/\text{ft}^3$$

$$= 3.61 \times 10^{-2} \text{ lb}_m/\text{in.}^3$$

Force

$$1 \text{ newton (N)} = 10^5 \text{ dynes}$$

$$= 0.225 \text{ lb}_f$$

Pressure

$$1 \text{ N/cm}^2 = 9.87 \times 10^{-2} \text{ atm}$$

$$= 1.45 \text{ lb}_f/\text{in.}^2$$

$$1 \text{ kg}_f/\text{cm}^2 = 0.968 \text{ atm}$$

$$= 14.2 \text{ lb}_f/\text{in.}^2$$

$$1 \text{ bar} = 0.987 \text{ atm}$$

$$= 10 \text{ N/cm}^2$$

$$1 \text{ torr} = 1 \text{ mm Hg (0°C)}$$

$$= 1.32 \times 10^{-3} \text{ atm}$$

Energy

$$1 \text{ joule} = 1 \text{ W-sec}$$

$$= 0.738 \text{ ft-lb}_f$$

$$= 9.48 \times 10^{-4} \text{ Btu}$$

$$= 0.239 \text{ cal}$$

Power

$$1 \text{ kW} = 1.34 \text{ hp}$$

$$= 3.41 \times 10^3 \text{ Btu/hour}$$

$$= 7.38 \times 10^2 \text{ ft-lb}_f/\text{sec}$$

Power density

$$1 \text{ kW/cm}^3 = 28.3 \text{ MW/ft}^3$$

Acceleration due to gravity (standard for units)

$$g = 980.7 \text{ cm/sec}^2$$

$$= 32.17 \text{ ft/sec}^2$$

Related Publications During the Quarter

1. E. Garelis, A Calculation of the Prompt Decay Constant for a Reflected Assembly, paper presented at the American Nuclear Society Winter Meeting, Chicago, Illinois, November 5-9, 1967 (UCRL-70563 Summary).
2. E. S. Peck, "Quantitative Spectrographic Determination of Hafnium in Tungsten by a Vacuum Cup Solution Method," Analytical Chemistry, vol. 40, p. 324 (1968).
3. R. R. Vandervoort, "Creep Correlations for Body-Centered Cubic Refractory Metals," Transactions of the AIME, vol. 240, p. 345 (1968).
4. R. W. Werner and G. A. Carlson, Heat Pipe Radiator for a 50-MWt Space Power Plant, UCRL-50294, Lawrence Radiation Laboratory, Livermore (1967).

Contents

HIGHLIGHTS AND SUMMARY	iii
TABLE OF CONVERSIONS	v
MATERIALS	1
Development of Refractory Metal Alloys	1
Dispersion Strengthening of Refractory Metals	1
Powder Metallurgy	1
Intermetallic Compounds	6
Internal Nitriding of Refractory Metal Alloys	6
Tungsten-Based Alloys	6
Molybdenum-Based Alloys	11
High-Temperature Creep Tests on Internally Nitrided TZM	11
Covapor Deposition of W-HfN	12
Fiber Reinforcement	14
Chemical Vapor Deposition of Tungsten and Tungsten-Rhenium Alloys	14
Tensile Properties	14
Deposition Rate	14
Fluorine Content	15
Weldability of Tungsten-Rhenium-Molybdenum Alloys	15
Fuel Studies	19
Synthesis and Fabrication of Uranium Nitride	19
UN Phase Equilibria and Vaporization Rates	20
Grain Growth in UN	22
Kinetics of Grain Growth	22
Anomalous Grain Growth	24
Crystal Growth in UN	25
Nitrogen Diffusion in UN	26
Bubble-Migration Studies	27
Compressive Creep of UN	29
Liquid-Metal Studies	32
Corrosion-Loop and Capsule Programs	32
Status of the Corrosion Loop	32
Status of the Pumped Capsules	32
Sampling and Handling Techniques	32
Analytical Studies	35
Determination of Rhenium and Molybdenum in Tungsten- Rhenium-Molybdenum Alloys	35
Analysis of Refractory Alloys for Titanium, Tungsten, Molybdenum, Niobium, and Tantalum	36

Analytical Studies (Continued)

Determination of Metallic Impurities in Tungsten, Molybdenum, and Tungsten-Rhenium-Molybdenum Alloys	36
NEUTRONIC CALCULATIONAL METHODS	37
Updating of Existing Codes and Cross-Section Compilations	37
R-Division MESNE Program	37
Neutronic Calculations for the SPR-4 Reactor	38
Fuel-Enrichment and Control Requirements	40
Radial Power Shaping	42
Effect of Lithium Loss	44
Neutronic Calculations for the SPR-6 Reactor	44
Power Flattening	44
Axial ZOOM Calculations	47
End-Reflection Worths	47
Redetermination of Fuel Enrichment	50
Reactivity Control with Liquids	54
Ground Safety	55
Selection of a Suitable Geometric Temperature Effect	57
Optimization Studies of Out-of-Core Thermionic Systems (SPR-5 and SPR-8)	57
Component Review	64
Neutronic Reflector and Control System	64
Heat Pipes	64
Diode Array	64
Materials	67
Radiator	69
Shield	70
Reactor Core	73
RADIATION EFFECTS AND SHIELDING	73
GEISHA Shielding Calculations	73
Geometry	74
Neutron-Flux Calculation	75
Core Gamma-Flux Calculation	77
Secondary-Gamma-Flux Calculation	78
Payload Dose Rate	80
Main-Shield Heating Rate	80
Maximum Main-Shield Temperature	80
SPR-6 Shielding Results	81
THERMODYNAMICS AND FLUID FLOW	82
Extrapolation of Fluid Saturation Conditions to the Critical Point	82
Saturation Enthalpy	83

Extrapolation of Fluid Saturation Conditions to the Critical Point (Continued)

Saturation Entropy	85
REACTOR SYSTEM AND COMPONENT ENGINEERING	88
SPR-6 Reference Design	88
Reactor System Analysis	89
Criticality-Limited Core: U ²³³	92
Heat-Pipe-Cooled Reactors	93
Spaced-Pin Geometry	96
Hybrid Geometry	98
Reactor Control	98
System Analysis	101
Heat-Pipe Radiator	103
Heat-Pipe Input Flux and Axial-Flux Safety Factor	103
Heat-Pipe Diameter	106
Heat-Pipe Survival Probability	106
Working-Fluid Pressure Drop	106
Radiator Survival Probability	106
Heat-Pipe Fluid	107
Annular-Heat-Pipe Experiment	107
Corrosion Loop	109
Loop Design	109
Induction Pump	112
Heat Rejection	114
Fill/Drain and Expansion Tanks	114
Containment Vessel	114
NaK Low-Temperature Test Loop	115
REFERENCES	118

QUARTERLY REPORT ADVANCED SPACE NUCLEAR POWER PROGRAM July Through September 1967

Materials

DEVELOPMENT OF REFRACTORY METAL ALLOYS

Dispersion Strengthening of Refractory Metals

Powder Metallurgy

It was suggested in the preceding quarterly report^{*} that the severe coarsening of the oxide dispersoid (HfO_2 , ZrO_2 , or ThO_2) observed in a fully densified tungsten matrix during a postconsolidation heat treatment was due to the formation of a liquid phase between the dispersoid and the WO_3 present as a residual impurity. Further, it was pointed out that oxygen content could be kept lower if larger tungsten particles were used or formed in the dispersing process in order to avoid the coarsening effects of the oxide eutectics. In the present work, a W- ThO_2 dispersion prepared and consolidated by the Westinghouse Electric Corporation with their recently announced process¹ was structurally evaluated for comparison with the wet-blended, hydrogen-purified, and sintered W- ThO_2 composites prepared at LRL. This comparison is important since the Westinghouse dispersing process results

in large (about $2\ \mu$ in diam) tungsten particles (with fine thoria trapped in them), whereas the blending process necessarily requires the use of fine powders (about $0.05\ \mu$). The wet-blending approach was intended to serve as a prototype for all other processes resulting in fine tungsten powder. To develop a better understanding of some unusual behavior observed in the course of the present work, a brief sintering study of pure tungsten and of W- ThO_2 was carried out.

Microscopic examination of the dispersions showed that the Westinghouse W- ThO_2 preparation retained, throughout the consolidation sequence, a dispersion that was a few orders of magnitude finer than that obtained with the wet-blending and hydrogen-sintering approach. Substantial coarsening, however, was noted in both structures.

The thoria coarsening that occurred during hydrogen-sintering of the wet-blended powders was found to be independent of the extent of the low-temperature ($<1000^\circ\text{C}$) hydrogen pretreatment given to the low-density green-pressed compacts. Also, the coarsening occurred in conjunction with rapid and virtually complete densification over the temperature range of 900 to 1100°C . This was about 250°C

^{*}See p. 2 of the 1967 second-quarter report, UCRL-50004-67-2.

lower than the temperature required to sinter the equivalent undoped tungsten powder. This behavior is ascribed to liquid-phase sintering caused by eutectic formation between the WO_3 impurity and the ThO_2 dispersed phase.

In view of the known difficulty with which adsorbed oxygen is removed from tungsten surfaces with hydrogen at temperatures as high as 1270°C ,² it is concluded that fine ThO_2 dispersions cannot be practically prepared in tungsten by simple blending and hydrogen-sintering procedures. On the other hand, the Westinghouse W- ThO_2 dispersion is in the size range of interest, so its high-temperature creep properties should be evaluated.

As experimental material for this work, a standard W-5 vol % ThO_2 wet-blended composite powder (hereafter referred to as wet-blended W- ThO_2) was prepared, using n-heptane as a carrier and oleic acid as a surfactant, according to procedures developed by Norris *et al.* for nickel-metal oxide blending.³ The tungsten in this mixture was prepared at the Ciba Company, Inc., by reducing the hexachloride with hydrogen in a plasma; its average diameter as measured by electron microscopy was $0.05\ \mu$. The ThO_2 was prepared by the Vitro Corporation with their vaporization technique, and its average diameter by surface-area measurement (Brunauer, Emmett, and Teller) was $0.011\ \mu$.

The tungsten powders used in the sintering studies include the Ciba product and a $0.5\text{-}\mu$ powder prepared at the General Electric Company by reducing WO_3 in hydrogen. Also used in the sintering studies was a Westinghouse-prepared W-3.8 vol % ThO_2 composite made by their process, which involves spraying an

aqueous solution of $\text{Th}(\text{NO}_3)_4$ into coarse WO_3 , then drying and hydrogen-reducing the resultant powder. This powder passes through a $2\text{-}\mu$ Fisher subsieve.

In addition, a $3/8\text{-in.}$ -diam bar of W- ThO_2 , conventionally sintered and swaged (at about 2000°C), was obtained for structural examination. The bar was prepared by Westinghouse from powder made in a manner similar to that just described.

The experiments involved the cleaning and sintering of low-density green-pressed compacts in hydrogen. Green-pressing was carried out in air at 90,000 psi in a segmented piston/cylinder die. The resulting compacts were $3/8\text{ in.}$ in diam and about 0.5 in. high. All hydrogen purification and sintering was performed in a 1-in.-diam molybdenum-wound alumina muffle with a hydrogen flow rate of 400 cc/min. The hydrogen had a dew point of $<20^\circ\text{C}$ and contained $<4\text{ ppm}$ of oxygen. Low-temperature purification was done by slowly heating the compacts in hydrogen to the sintering temperature. The weight loss and sintered density were found to be sensitive to the heating rate (see Table I). Both the weight loss and the sintered density increase significantly with reduced heating rates. This is expected since premature surface sintering retards purification and densification. An optical examination revealed no clear differences between the structures of the wet-blended W- ThO_2 specimens listed in Table I. The most dense (and most purified) wet-blended W- ThO_2 specimen was selected for structural analysis.

The structures of both the "as-received" Westinghouse bar and the wet-blended W- ThO_2 specimen were thoroughly

Table I. Effect of heating rate on weight loss and sintered density.

Heating rate	Sintered density (g/cc) and weight loss (%)		
	GE tungsten	Ciba tungsten	Wet-blended W-ThO ₂
About 2000°C/hour to 1400°C in H ₂ , held 1 hour in H ₂	13.79 g/cc 0.75%	11.80 g/cc 1.28%	11.48 g/cc 2.74%
About 280°C/hour to 1400°C in H ₂ , held 1 hour in H ₂	14.20 g/cc 0.75%	14.01 g/cc 1.27%	18.64 g/cc 2.90%
About 28°C/hour to 1400°C in H ₂ , held 1 hour in H ₂	14.69 g/cc 0.79%	16.80 g/cc 1.38%	18.65 g/cc 2.94%

examined by both light and electron microscopy. Optical micrographs (see Figs. 1a and 1b) indicated that substantial coarsening had occurred in both structures. Electron microscopy included both plastic and extraction replicas since they complement one another as evaluation techniques. The extraction replicas were made by heavily etching the specimen, depositing carbon onto the etched surface, and subsequently removing the film in a 3% H₂O₂ solution.

Figures 2a through 2c show the Westinghouse bar (longitudinal section), and Figs. 2d through 2f show the sintered wet-blended W-ThO₂ specimen. While substantial coarsening occurred in the Westinghouse bar, a high density of particles 200 to 400 Å in diam was retained. The banding visible in Fig. 2b is partly the result of directional working during swaging. The sintered wet-blended W-ThO₂ specimen shows substantially more

a

b

Fig. 1. Optical micrographs (both 1000X) of the polished and etched structures of the Westinghouse W-ThO₂ bar (a) and the sintered wet-blended W-ThO₂ (b).

a. Plastic replica (5000X)

d. Plastic replica (5000X)

b. Extraction replica (5000X)

e. Extraction replica (5000X)

c. Extraction replica (40,000X)

f. Extraction replica (80,000X)

Fig. 2. Electron micrographs of the Westinghouse W-ThO₂ bar (a through c) and the sintered wet-blended W-ThO₂ (d through f). The ThO₂ particles retained on the replicas in b, c, e, and f are opaque to the electron beam.

coarsening, with much less thoria being retained in fine distribution. It is interesting to note, however, that some fine

particles remained (Fig. 2f).

The basic difference in the two processes is the finer tungsten-particle size.

That is, the Westinghouse process involves spraying an aqueous solution of $\text{Th}(\text{NO}_3)_4$ onto a coarse WO_3 powder that, when hydrogen-reduced, results in a coarse tungsten powder (about $2\ \mu$ in diam) with thoria particles trapped in it. The wet-blended W-ThO_2 , however, involves $0.05\text{-}\mu$ tungsten with about 40 times the surface area and therefore 40 times the adsorbed oxygen content. This adsorbed oxygen may then have an opportunity during sintering to revert to WO_3 , which subsequently forms a eutectic with ThO_2 and promotes coarsening.

To develop a better understanding of the phenomenon that promotes coarsening, green-pressed compacts of Ciba tungsten, GE tungsten, wet-blended W-ThO_2 , and Westinghouse powder were sintered at 700, 900, 1100, 1335, 1500, and 1865°C in steps of 15 hours each. Density determinations were made between each step. The results are given in Fig. 3.

While the finer Ciba tungsten begins to sinter before the GE tungsten does, the curves approach each other above 1100°C, thus indicating that something may be "washing out" the difference in particle size. The maximum density is reached at about 1500°C. The wet-blended W-ThO_2 , on the other hand, sinters to nearly full density at about 1200°C. Further, the Westinghouse powder shows an inflection in sinterability above 1500°C. These observations can be explained simply if molten WO_3 is assumed to be promoting sintering in the pure tungsten and a lower melting $\text{WO}_3\text{-ThO}_2$ eutectic in the composite. It is interesting to note that the results from the Westinghouse powder reflect the fact that most of the ThO_2 is trapped in the particles. It should be

Fig. 3. Isochronal sintering curves.

pointed out that a low-melting eutectic has been found in both the $\text{WO}_3\text{-ZrO}_2$ and the $\text{WO}_3\text{-HfO}_2$ systems,⁴ and it is also expected that one exists in the $\text{WO}_3\text{-ThO}_2$ system.

On the basis of the liquid model of coarsening, it would be necessary for oxygen to be removed below about 900°C before a fine distribution of ThO_2 could be retained. Langmuir notes that absorbed oxygen is much more difficult to reduce with hydrogen than any of the tungsten oxides.² The difficulty is demonstrated by the fact that hydrogen will not, within a

reasonable time, remove adsorbed oxygen at 1275°C above a partial-pressure ratio (P_{O_2}/P_{H_2}) of about 2×10^{-4} . Removal would be considerably more difficult at 900°C. It is concluded, therefore, that fine ThO_2 (or HfO_2) dispersions cannot be prepared practically with simple blending and sintering operations.

Intermetallic Compounds

A preliminary series of creep tests has been run on pure tungsten, W-25%Re, W-28%Re, and W-30%Re (all wt %). The purpose of these tests was to study the effect of composition and thermal history on creep behavior. All of the tests were conducted at 1400°C in a vacuum of about 10^{-8} torr, and the applied stress was either 5,000 or 10,000 psi. The results are listed in Table II.

From these data the following tentative observations can be made. In the hot-rolled condition, pure tungsten creeps faster than W-25%Re, W-28%Re, and W-30%Re by a factor of about five (Test Nos. 1, 3, 9, and 10). The creep rates for the alloys at 10,000 psi are roughly the same for the thermomechanical histories examined to date.

Annealing pure tungsten at 1600°C for 1 hour caused recrystallization but did not significantly alter the creep strength as compared to the hot-rolled condition (Test Nos. 1 and 2). However, annealing W-25%Re at 1600°C or 1800°C or solution-annealing W-30%Re at 2250°C decreased the creep rate by a factor of three as compared to the hot-rolled state (Test Nos. 3, 6, 7, 10, and 12).

Aging the W-30%Re alloy at 1400 to 2000°C for 50 hours after solution-annealing did not reduce the creep rate

below that of the unaged solution-annealed specimen (Test Nos. 12 through 16). Examination of the aged specimens with a light microscope revealed that the sigma phase had precipitated in the grain boundaries, not in the grains. However, electron microscopy is being used to determine if the sigma phase precipitated on a finer scale in the grains. This seems unlikely since the creep strength did not vary with the aging treatment.

Creep tests were run on specimens of W-25%Re where the stress was either parallel or normal to the rolling direction. Specimens in both orientations had almost the same creep rate at 10,000 psi in the hot-rolled and recrystallized conditions (Test Nos. 3, 4, 7, and 8). Thus, the creep behavior of this alloy is not sensitive to preferred orientation.

Internal Nitriding of Refractory Metal Alloys

Tungsten-Based Alloys—The internal-nitriding kinetics of pure tungsten, W-25%Re, and W-25%Re-30%Mo (at. %) to which about 1 at. % of hafnium had been added were investigated at several temperatures between 1500 and 2000°C and at various pressures between 10 and 250 torr. At all temperatures and pressures, the nitriding kinetics were found to be controlled by the rate at which nitrogen diffused through the refractory-metal matrix. As a result, the nitriding rate at a given temperature and pressure is adequately represented by an equation of the form

$$x^2 = kt, \quad (1)$$

Table II. Creep of pure tungsten and tungsten-rhenium alloys at 1400°C.

Test No.	Alloy ^a	Condition	Stress (psi)	Total strain (%)	Time (hours)	Minimum creep rate (hour ⁻¹)
1	Tungsten	Hot-rolled at 1400°C	10,000	18	19	6.1×10^{-3}
2	Tungsten	Annealed for 1 hour at 1600°C	10,000	4	11	5.1×10^{-3}
			5,000	3	63	1.1×10^{-4}
3	W-25% Re	Hot-rolled at 1400°C	10,000	13	70	1.1×10^{-3}
			5,000	3	50	4.9×10^{-4b}
4	W-25% Re (transverse)	Hot-rolled at 1400°C	10,000	12	45	1.5×10^{-3}
			5,000	2	55	4.0×10^{-4b}
5	W-25% Re	Annealed for 50 hours at 1400°C	10,000	11	70	8.9×10^{-4}
			5,000	3	45	6.2×10^{-4b}
6	W-25% Re	Annealed for 50 hours at 1600°C	10,000	3	100	3.0×10^{-4}
			5,000	1	140	5.5×10^{-5}
7	W-25% Re	Annealed for 50 hours at 1800°C	10,000	6	115	3.0×10^{-4}
			5,000	1	50	1.1×10^{-4b}
8	W-25% Re (transverse)	Annealed for 50 hours at 1800°C	10,000	5	95	3.6×10^{-4}
			5,000	1	175	5.8×10^{-5}
9	W-28% Re	Hot-rolled at 1400°C	10,000	85	350	1.5×10^{-3}
				(fractured)		
10	W-30% Re	Hot-rolled at 1400°C	10,000	22	113	1.5×10^{-3}
			5,000	11	882	8.9×10^{-5}
11	W-30% Re	Aged for 50 hours at 1400°C	10,000	10	73	1.2×10^{-3}
			5,000	5	543	7.5×10^{-5}
12	W-30% Re	Solution-annealed for 2 hours at 2250°C	10,000	13	216	5.2×10^{-4}
13	W-30% Re	Solution-annealed for 2 hours at 2250°C; aged for 50 hours at 1400°C	10,000	11	216	5.1×10^{-4}
			5,000	3	374	4.5×10^{-5}
14	W-30% Re	Solution-annealed for 2 hours at 2250°C; aged for 50 hours at 1600°C	10,000	12	317	3.4×10^{-4}
			5,000	4	505	4.4×10^{-5}
15	W-30% Re	Solution-annealed for 2 hours at 2250°C; aged for 50 hours at 1800°C	10,000	8	168	5.9×10^{-4}
			5,000	2	241	5.2×10^{-5}
16	W-30% Re	Solution-annealed for 2 hours at 2250°C; aged for 50 hours at 2000°C	10,000	10	312	2.5×10^{-4}
			5,000	3	336	3.4×10^{-5}

^aAlloy compositions are given in terms of weight percent.^bSpecimen had entered tertiary creep.

where x is the thickness of the internally nitrided layer, t is the time, and k is the rate constant, which is given by

$$k = \frac{2N_n D_n}{vN_{Hf}} \quad (2)$$

where N_n is the atomic fraction of nitrogen at the surface of the metal, D_n is the diffusion coefficient of nitrogen in the metal, N_{Hf} is the atomic fraction of hafnium in the alloy, and v is the ratio of nitrogen to hafnium in the nitride phase.

The temperature dependence of k for the three tungsten-based alloys having the highest hafnium content is shown in Figs. 4 and 5. It can be seen that k increases by almost two orders of magnitude between 1500 and 2000°C for all three alloys. The activation energy derived from the slopes of the plots of $\log k$ versus $1/T$ represents the energy for the permeation of nitrogen

Fig. 4. Nitriding rate versus temperature for W-25%Re-1.74%Hf and W-1.84%Hf (at. %).

Fig. 5. Nitriding rate versus temperature for W-25%Re-30%Mo-1.43%Hf (at. %).

through the metal or alloy matrix. These values are summarized in Table III. Within the uncertainties in the experimental data, the activation energy for nitrogen permeation is shown to be essentially the same for all three alloys.

Table III. Activation energies for the permeation of nitrogen through various tungsten-based alloys as derived from internal-nitriding kinetics.

Alloy ^a	Activation energy for nitrogen permeation (kcal/mole)
Pure tungsten	65.7
W-25%Re	67.8
W-25%Re-30%Mo	68.8

^aAlloy compositions are given in terms of atomic percent.

For diatomic gases that dissociate upon entering into solution in a metal, the quantity (q) of gas that permeates through a membrane of thickness d and area A in time t when a pressure differential ($p_2 - p_1$) is maintained across the membrane is given by

$$q = PA t (p_2^{1/2} - p_1^{1/2}) / d, \quad (3)$$

where P is the permeation coefficient.

Nitrogen permeation coefficients calculated from the kinetic data shown in Figs. 4 and 5 are plotted as a function of temperature in Fig. 6 along with permeation-rate data for pure tungsten obtained by Conn et al.⁵ and Frauenfelder.⁶ The permeation coefficients are expressed as the number of cubic centimeters (STP) of nitrogen per minute passing through a membrane 1 mm thick and 1 cm² in area when a pressure differential of 1 atm is maintained across the membrane. It can be seen that the tungsten permeation coefficients derived from the internal-nitriding kinetics of tungsten-hafnium alloys agree with the values measured directly by Conn et al. within a factor of about 2.5. The temperature dependence of the nitrogen

Fig. 6. Nitrogen permeation coefficient versus temperature for pure tungsten and W-25%Re-30%Mo (at. %).

permeation coefficient is also in good agreement. Frauenfelder's results, although they also give a good order-of-magnitude agreement, indicate a considerably smaller activation energy for nitrogen permeation (52 kcal/mole).

From the data shown in Fig. 6, the total amount of nitrogen permeating through the wall of a tungsten fuel capsule in 10,000 hours can easily be calculated for any given wall thickness and any assumed pressure differential. At 1500°C, for example,

about 2 cc (STP)/cm² of nitrogen will permeate through a 0.020-in.-thick tungsten tube if a nitrogen pressure of 760 torr is maintained inside the tube while the outside is kept under vacuum. At 2000°C, the corresponding quantity is on the order of 100 cc (STP)/cm². It is also evident that the nitrogen permeation rate for W-25%Re-30%Mo is about a factor of three greater than that for pure tungsten under the same conditions.

When the diffusion of nitrogen in the metal is the rate-controlling step, which appears to be the case here, the permeation coefficient is the product of the solubility and the diffusivity of nitrogen in the metal. Consequently,

$$Q_p = Q_s + Q_D, \quad (4)$$

where Q_p is the activation energy for nitrogen permeation, Q_s is the heat of solution of nitrogen in the metal, and Q_D is the activation energy for self-diffusion. Independent measurements of the diffusion coefficients by Frauenfelder yield a value of 62 kcal/mole for Q_D . Since Q_p from the present measurements is about 66 kcal/mole, $Q_s \approx 4$ kcal/mole, which indicates that the solubility of nitrogen in tungsten is virtually independent of temperature between 1500 and 2000°C. Attempts are being made to confirm this by direct solubility measurements.

As noted previously, the hardening effects produced by internal nitriding at 1650°C are most pronounced in the binary tungsten-hafnium alloys. The same holds true at higher nitriding temperatures. In general, the higher the hafnium content and the lower the nitriding temperature, the greater the surface hardness after nitriding in any given alloy series. The

primary effect of increasing the hafnium content is to increase the volume fraction of the second-phase HfN particles, which leads to a higher hardness. Increasing the nitriding temperature leads to an increase in the average nitride-particle size (and a corresponding increase in the mean interparticle spacing), which results in a lower hardness.

The second-phase particles seen in the nitrided zones in the W-Re-Hf and W-25%Re-30%Mo-Hf alloys are most probably HfN. These particles have a plate-like morphology and are crystallographically aligned with respect to the metal matrix. At 1650°C, the particles are 10 to 15 μ wide and about 1 μ thick; at 2000°C, the particles still have plate-like shapes but on the average are considerably larger, being about 50 μ or more wide and several microns thick. Using replica techniques and the electron microscope, it has been established that the nitride particles formed in the binary W-Hf alloys, which are too small to be resolved in the optical microscope, also have plate-like shapes and are crystallographically aligned with respect to the metal matrix. In a W-1%Hf (at. %) alloy nitrided at 1750°C, the HfN particles are only 500 to 2000 Å wide at the most and are perhaps only 100 Å thick. The much smaller size of the nitride particles in the binary W-Hf alloys thus is consistent with the greater hardening effects observed in these alloys as compared to W-Re and W-Re-Mo alloys. It may be that the HfN particles grow to a larger size during nitriding in the W-Re and W-Re-Mo alloys because the diffusion coefficient of hafnium is greater in these alloys than in pure tungsten.

At sufficiently low nitriding temperatures, however, substantial hardening effects can be obtained with the W-Re-Hf and W-Re-Mo-Hf alloys. This is shown in Fig. 7, where the surface hardness after nitriding at 1500 and 1650°C is plotted as a function of hafnium content for W-25%Re-30%Mo-Hf. For comparison, the surface hardness of binary tungsten-hafnium alloys nitrided at 1650°C is also shown. It appears that the hafnium content can profitably be increased to achieve an even greater improvement in hardening.

The main reason for adding rhenium to tungsten is to achieve greater ductility and ease of fabrication. There is reason to believe, however, that this could be accomplished effectively by adding only about 5% of rhenium rather than 25%. If so, the diffusion coefficient of hafnium in the metal

Fig. 7. Surface hardness versus hafnium content for pure tungsten and W-25%Re-30%Mo (at. %).

matrix may not be raised significantly by the presence of rhenium, and hence the average nitride-particle size may not be much greater in, say, a W-5%Re-1%Hf alloy than in a pure binary W-1%Hf alloy. This means, in turn, that we could take advantage of the ductilizing effect of rhenium and still achieve high hardness levels after nitriding. This possibility is being investigated with a series of W-5%Re-Hf and W-10%Re-Hf alloys that are being prepared by arc-melting.

Molybdenum-Based Alloys—The internal-nitriding kinetics of Mo-1%Hf (at. %) are now being investigated. Typical results at 1350°C and 1 atm of nitrogen are shown in Fig. 8. The nitriding rate is diffusion-controlled like the tungsten-based alloys, and under these conditions it appears that a 0.050-in.-thick creep-test sample could be completely nitrided in about 100 hours.

High-Temperature Creep Tests on Internally Nitrided TZM—Creep measurements on internally nitrided TZM have been

Fig. 8. Thickness of nitrided layer versus time for Mo-1%Hf (at. %). Nitriding conditions: 1350°C and 1 atm of nitrogen.

concluded. The final tests were made on samples that were first nitrided, then tested in a vacuum. In this way the benefit obtained from the nitrogen atmosphere during testing was determined since previous samples had been both nitrided and tested in about 1 atm of nitrogen.*

The samples were tested under the same conditions as before—a temperature of $1450 \pm 10^\circ\text{C}$ and a stress of 285 kg/cm^2 (about 4000 psi)—except that the ambient pressure was less than 10^{-6} torr. In 50 hours the creep was about 3%. At the same temperature and stress, but in 1 atm of nitrogen, the same material took about 500 hours to creep 3%.

No further work will be done on this alloy since for several reasons it is far from optimum for dispersion strengthening: The concentration of the dispersoid is too low, the main dispersant constituent is titanium (which is inferior to hafnium), and it is likely that the titanium and zirconium are at least in part nonuniformly dispersed in the as-received alloy. Also, the temperature chosen (1450°C) is thought to be too high for optimum strengthening in the molybdenum-based system. The results of these preliminary measurements are sufficiently encouraging, however, to warrant further work on alloys that have compositions chosen for optimum strengthening. We are now procuring molybdenum-hafnium, tungsten-hafnium, and tungsten-rhenium-hafnium alloys for this purpose.

Covapor Deposition of W-HfN

Analytical determinations were continued during this reporting period in order

*See p. 19ff in the 1967 second-quarter report, UCRL-50004-67-2.

to provide results from Run Nos. 15 through 18. The same temperature profile (400 to $975 \pm 20^\circ\text{C}$) was maintained along the substrate tubes throughout these four runs. The tungsten-to-hafnium ratio in the feed gas was fairly constant during the runs (see the last column in Table IV). Table IV also indicates that more than enough hydrogen was available to reduce the WCl_6 and HfCl_4 introduced during each run. Only the NH_3 content (expressed as the nitrogen equivalent) was varied from a deficient amount (0.13 mole of nitrogen/mole of hafnium in Run No. 16) to an excess amount (0.56 mole of nitrogen/mole of hafnium in Run No. 18) in order to study the effect of nitrogen concentration on the hafnium deposition rate. No clear correlation can be made between the nitrogen concentration and the hafnium deposition rate (see the results listed in Table V). The results do indicate that oxygen has some effect on the hafnium deposition. The hafnium and oxygen contents in Run No. 15 were much higher than in the other runs due to a leak in a flowmeter connection.

In most cases, the as-deposited microhardness increased with increasing nitrogen content. The reduction in hardness after these coatings were heat-treated (at 1100°C for 111 hours in 1 atm of H_2 -50 mole % N_2) was due to the decomposition of W_2N (see Run Nos. 15 and 17 in Table V). The hardness of the heat-treated coatings increased with increasing oxygen content.

Before the effect of nitrogen on the deposition rate of hafnium can be studied, and before the properties of the resulting coating can be determined, the oxygen contamination must be reduced. An NH_3 purifier was designed and built to improve the purity of the NH_3 gas, and the vapor

Table IV. Mole ratios maintained during covapor-deposition runs.

Run No.	Mole ratio				Maximum possible HfN content (wt %)
	H ₂ /WCl ₆	N ₂ /W ^a	H ₂ /HfCl ₄	N ₂ /Hf ^a	
15	12.8	0.23	20.6	0.37	39.3
16	23.1	0.08	52.2	0.13	31.5
17	11.6	0.14	19.2	0.22	38.7
18	16.8	0.25	37.5	0.56	31.6
Stoichiometric ratio from reactions below					
	2.5	0.25	2.0	0.5	
$\text{WCl}_6 + 3 \text{H}_2 \longrightarrow \text{W} + 6 \text{HCl}$ $4 \text{W} + \text{N}_2 \longrightarrow 2 \text{W}_2\text{N}$ $\text{HfCl}_4 + 2 \text{H}_2 \longrightarrow \text{Hf} + 4 \text{HCl}$ $2 \text{Hf} + \text{N}_2 \longrightarrow 2 \text{HfN}$					

^aThe nitriding agent was NH₃.

Table V. Summary of results collected from covapor-deposition runs.

Run No.	Measured variable	Approximate distance along substrate tube from nozzle							
		8 in.	10 in.	12 in.	14 in.	16 in.	18 in.	20 in.	22 in.
15	Hafnium content (wt %)		3.81			29.33	34.71		40.91
	Nitrogen content (wt %)		5.38			3.39	3.25		1.68
	Oxygen content (wt %)		0.75			1.37	1.03		2.17
	AD DPH ^a (kg/mm ²)	1690	1870			1630	1770		1440
	HT DPH ^b (kg/mm ²)		820				1220		1660
16	Hafnium content (wt %)		0.10	0.13	0.94		2.47		3.16
	Nitrogen content (wt %)		0.372	1.69			0.180		
	Oxygen content (wt %)		0.024	0.010			0.531		
	AD DPH ^a (kg/mm ²)		1730	2180		1620			
	HT DPH ^b (kg/mm ²)		In progress						
17	Hafnium content (wt %)	0.01	0.015	0.02		0.49			
	Nitrogen content (wt %)	2.72	1.67	1.83		0.091			
	Oxygen content (wt %)	0.006	0.010	0.003		0.464			
	AD DPH ^a (kg/mm ²)	2390	1860	2120	2640				
	HT DPH ^b (kg/mm ²)	380		320		480			
18	Hafnium content (wt %)	0.19	0.04	0.11	0.42		0.75	0.64	
	Nitrogen content (wt %)	3.32	3.40	3.30			0.066	0.035	
	AD DPH ^a (kg/mm ²)	1930	2090	2000	2430				

^aAs-deposited diamond pyramid hardness.

^bDiamond pyramid hardness after heat treatment at 1100°C.

deposition equipment was modified to distill away the oxychlorides from the WCl_6 and $HfCl_4$ just before each deposition run.

Fiber Reinforcement

One section each from two W-8 vol % ZrN extrusions (No. 24 and 26) were sintered for 8.5 hours at 1700°C in H_2 -50 mole % N_2 . One section from a tungsten extrusion (No. 27) was also sintered. These sections were used to study the effect of the ZrN fibers on the grain growth and density of the tungsten. The porosity-size distribution and the density of these three sections were determined with a mercury porosimeter. The sintered densities were 72.6%, 79.7% and 85.7% of theoretical density for Extrusion Nos. 24, 26, and 27. A fine grain size (about 5 μ in diam) was observed for all three sections.

These sections are scheduled for zone-refining heat treatments near the melting point of ZrN to improve the density and grain structure of the ZrN.

Chemical Vapor Deposition of Tungsten and Tungsten-Rhenium Alloys

During this quarter, emphasis has been placed on completing a new chemical vapor deposition (CVD) apparatus for producing 1-ft lengths of 0.5-in.-diam tubing. Fabrication and installation of the equipment has

been completed, and shake-down testing is in progress.

Studies on the effects of deposition variables, evaluation of heat treatments, and testing of the mechanical properties of ring specimens have been continued in an effort to improve the tensile properties of CVD tungsten-rhenium alloys. The equipment and techniques used in this work are described in previous quarterly reports as well as in Ref. 7. The significant results obtained since these reports were published include the following.

Tensile Properties

The ultimate tensile strength of the strongest deposit produced to date (see Table VI) was increased by lowering the annealing temperature from 1400 to 1200°C and by increasing the annealing time from 1 to 18 hours. A maximum strength of nearly 250,000 psi was obtained. Maximum ductility (greater than 2% uniform elongation) was obtained with a lower rhenium concentration and a correspondingly lower strength deposit (see Table VI).

Deposition Rate

The results of a series of experiments on alloy deposition rates at temperatures below those previously investigated are given in Fig. 9, together with pure-tungsten data taken from the preceding quarterly

Table VI. Maximum tensile strength at room temperature of tungsten-rhenium deposits produced by hydrogen-reduction of the fluorides.

Experiment No.	Temperature (°C)	Pressure (torr)	Flow rate of input gases		Gas composition (% ReF_6)	Deposition rate (mils/min)	Deposited composition (% Re)	Heat treatment	Ultimate tensile strength (psi)	0.02% offset yield strength (psi)	Uniform elongation (%)
			H_2 (cc/min)	MF_6 (cc/min)							
545	600	10	1000	70	14.3	0.25	26.0	1 hour at 1400°C	201,500	191,000	0.06
545	600	10	1000	70	14.3	0.25	26.0	18 hours at 1200°C	247,500	246,000	0.05
656	600	10	500	140	6.8	0.25	24.0	1 hour at 1400°C	181,000	178,000	>2

Fig. 9. Deposition rate versus temperature for pure tungsten and tungsten-rhenium. Deposition conditions: 1500 cc/min of H_2 , 500 cc/min of MF_6 , and 10 torr.

report. It is apparent that the presence of rhenium greatly accelerates the deposition rate at the lower temperatures.

Fluorine Content

The fluorine contents of several series of pure tungsten deposits are given in Table VII along with the plating conditions employed and the plating rates obtained. No clear-cut trends with temperature, pressure, ratio of hydrogen to WF_6 , plating rate, or other variables are apparent, although the high-pressure (300-torr) deposit contained an unusually high fluo-

rine content. Rubbing had no apparent influence on the fluorine concentration.

Weldability of Tungsten-Rhenium-Molybdenum Alloys

Welding studies are required to successfully fabricate hardware for corrosion experiments with liquid metals in refractory metals. Corrosion experiments are of two general kinds: 1) a pumped capsule that consists of a 10-in. length of tubing (0.5-in. o.d. $\times$ 0.040-in.-thick wall) sealed at the ends with welded caps, and 2) a forced-convection (pumped) loop that consists of a D-shaped circuit of 0.5-in.-o.d. tubing with a varying inside diameter to simulate reactor flow conditions. The loop will have an all-welded construction and will contain various kinds of joints, including thin-section butt welds, standing-edge welds, and deep-penetration butt welds.

The alloys selected for the initial corrosion experiments are the two-phase W-30%Re-30%Mo (at.%) alloy and the single-phase W-25%Re-30%Mo (at.%) alloy. This selection is based on reports by General Electric⁸ and Wah Chang⁹ that indicate that these alloys are relatively fabricable and weldable and can be obtained in such forms as sheet, plate, rod, and tubing on a custom-order basis. Current plans are to construct pumped capsules from both alloys and to construct the loop from the single-phase alloy.

An investigation is being conducted to establish the parameters for making sound pore-free welds in the two alloys by electron-beam welding. Welds of the kinds to be used in the capsules and the loop are being made as described below and are

Table VII. Fluorine analyses for a variety of tungsten-rhenium reduction conditions.

Specimen No.	Temperature (°C)	Pressure (torr)	H ₂ , MF ₆ flow rates (cc/min)	Deposited thickness (mils)	Deposition rate (mils/min)	Fluorine concentration (ppm)
677	546	5	500, 70	3.0	0.04	67
688	535	20	500, 70	9.0	0.075	34
699	535	80	500, 70	10.0	0.165	29
720	700	5	500, 70	14.7	0.245	17
721	700	20	500, 70	16.6	0.415	24
719	700	80	500, 70	18.2	0.607	34
715	750	10	500, 70	9.7	0.485	18
680	900	5	500, 70	18.9	0.63	12
687	900	20	500, 70	18.0	0.60	33
701	900	80	500, 70	16.0	0.80	11
709	550	10	1500, 500	5.5	0.063	26
710	600	10	1500, 500	6.2	0.103	30
711	700	10	1500, 500	17.0	0.283	24
712	800	10	1500, 500	22.5	0.563	20
713	1000	10	1500, 500	32	1.60	13
679-4	535	300	740, 83	34.5	0.23	71 (rubbed section)
697-10	535	300	740, 83	34.5	0.23	70 (rubbed section)

being evaluated and qualified through room- and high-temperature mechanical-property tests. The information obtained from this program will be used for the fabrication of the corrosion-test assemblies and will provide the basis for fabrication of future engineering-test assemblies and reactor prototype components.

The welding tests were performed in a Hamilton Standard electron-beam welder on a W-30%Re-30%Mo tube (0.5-in. o.d. $\times$ 0.040-in.-thick wall). This alloy is quite fluid in the molten state, it fuses easily, and it is apparently not prone to cracking. Full-penetration welds can easily be made.

The welds are porous with a line of gas pockets at the interface of the fusion-heat-affected zone and with larger gas pockets in the fusion zone. The source of this porosity seems to be gases released from the base metal. Studies of ways to minimize the porosity are continuing.

A total of 10 butt welds have been made on one W-30%Re-30%Mo tube from General Electric by making a weld, cutting the weld out, and rewelding the cut ends. The first six welds were made to determine the welding parameters that would give full penetration without excessive drop-through. A high travel speed (40 in./min surface

speed) with a high welding power (1000 to 1500 W) was used in these runs. These parameters were chosen to minimize coring of the alloy and the width of the heat-affected zone. The six welds were made at the same speed with changes in power input to obtain full penetration. All welds showed varying amounts of porosity (a typical weld is shown in Fig. 10). Before welding, all weld areas were etched in lactic acid/ HNO_3 / HF and the tubes were given a 1000°C baking in a vacuum for one hour. The porosity did not decrease. The travel speed was then reduced to keep the weld molten for a longer time and to allow the gas to evolve. A travel speed of 10 in./min, a welding power of 600 W, and a total time of 45 sec on the weld with 20 sec at full power greatly reduced the gross porosity in the weld proper as shown in

Fig. 11. The lower speed, however, did not decrease the amount of fine porosity at the interface between the weld and the base metal or at the fusion line. In fact, it seemed to increase and concentrate it at the fusion line. This interfacial porosity seems to be caused by gases released from the base metal by the welding heat and then trapped during solidification of the melt.

Welding evaluations by the manufacturer consisted of a surface fusion of the tube (rather than a butt weld) as a process check. The increased surface area in such a joint could provide additional sources of gas. Therefore, a surface-melting pass was made on a tube that had been cut on the EDM (electrodischarge machining) cutter. The melting pass was made on the as-received end in the same

Fig. 10. Weld in W-30%Re-30%Mo (at. %) made at a surface speed of 40 in./min (50X).

Fig. 11. Weld in W-30%Re-30%Mo (at. %) made at a surface speed of 10 in./min (60X).

way that the manufacturer does it for quality inspection. This fusion pass also showed porosity at the fusion line. In addition, two sections of tubing remaining from this work were prepared for welding tests by grinding one end of each tube to remove all traces of an EDM cutting operation that had been used to prepare multiple weld specimens from the short lengths available. One of the ground ends and one of the EDM-cut ends were polished on the inside and outside to remove any surface contamination. The other two ends were not cleaned except for etching. Both tubes were then etched in lactic acid/ HNO_3 / HF to remove any soluble surface contaminants. The end of each tube was melted under the electron beam and examined. All sections showed about the same amount of fine porosity at the fusion line, with larger porosity in the molten metal. The surface condition had no appreciable effect on the amount of internal porosity.

A tube and an end cap were welded together to obtain parameters for the pumped-capsule assembly. The cap was machined from a solid bar, and a thin central tube was machined in it. The edges of the cap were welded to the main tube, and the central tube was sealed by melting the ends. All welds had porosity at the fusion line.

Two of the butt-weld samples welded at lower speeds had incomplete penetration and showed evidence of grain growth across the unmelted interface below the fusion zone (see Fig. 12). It is known that W-30%Re-30%Mo diffusion-bonds easily, so it may be possible to make a partial-penetration weld with a minimum of porosity and hence obtain, with the right combination of pressure and time, a strong

Fig. 12. Partial weld in W-30%Re-30%Mo (at. %) showing grain growth across the unmelted interface below the fusion zone (60X).

diffusion bond for the rest of the joint. The contact pressure is the result of solidification shrinkage in the fusion zone. This effect will be investigated further.

The tests to date show that the porosity is derived from contaminants in the base metal rather than from the cleaning or welding operations. The cause may be gases carried through from the powder stage, or it may be metal vapors formed by heating trace elements such as calcium and aluminum above their vaporization temperatures. Vacuum-arc-melted material will be tested for weldability because its interstitial and metallic-impurity concentrations will be lower than in the powder-metallurgy material.

FUEL STUDIES

Synthesis and Fabrication of Uranium Nitride

Uranium-mononitride powder is being synthesized by a sequence of reactions that can be summarized as follows:

The primary purpose of the runs to date has been to learn some of the effects of the many process-operating variables on the properties of UN powder. This study will continue toward optimum properties.

Hydride/dehydride conditions have been arbitrarily fixed. A hydriding temperature within the range of that used at CANEL¹⁰ (about 100 to 140°C) was chosen and has not been varied. Hydriding is carried out under 1 atm of hydrogen in Inconel vessels. The hydrogen is supplied by a palladium diffuser unit.

A dehydriding temperature higher than CANEL's has been selected (about 400 to 450°C) to permit dehydriding at atmospheric pressure rather than under a vacuum. The advantage of atmospheric dehydriding is that vacuum-pumping with its attendant potential for contamination can be avoided. In early runs, the dehydriding temperature was high enough to slightly reaggregate the uranium powder. Reagglomeration is entirely precluded by ending the powder-production process with a hydride step rather than a dehydride one. Later runs have been made with

seven hydride and six dehydride steps. Each step takes 35 to 45 min at temperature.

A more severe agglomeration problem is encountered in nitriding. The rate of nitriding must be carefully controlled not only to prevent "clinkering" (coarsening) of the uranium powder by the heat of the reaction, but also to avoid an attack on the reaction vessel by the hot uranium. Recent nitriding runs have been made at about 300°C (285 to 315°C) with a nitrogen pressure of about 100 μ as measured by a thermocouple gauge. Reaction times of 19 to 21 hours have been used. The result is a soft, finely divided, nonclinkered U_2N_3 powder. Some effort has been devoted to establishing denitriding conditions that will yield a pressable, sinterable UN powder having an N/U ratio close to unity. U_2N_3 has been denitrided at CANEL at 1000°C.¹⁰ Observations to date at LRL are that treatments at 1000°C result in substantial agglomeration or "presintering" in the UN powder. Therefore, the most recent efforts have been directed at denitriding at a modest temperature for extended times (e.g., 650°C for up to 64 hours). Pressures during denitriding are maintained by oil diffusion pumping between 10^{-5} and 10^{-4} torr as measured by a Bayard-Alpert ion gauge.

Limited impurity analyses indicate that the oxygen and carbon levels in these first UN batches are higher than desired. For example, the UN in LRL Batch No. 3 contained 454 ppm of oxygen and 470 ppm of carbon. The carbon content is expected to drop with the addition of improved baffles to the vacuum-pumping system. The principle source of oxygen contamination

is thought to be the synthesis nitrogen. Initially, pure uranium was to be nitrided in a closed vessel, with the gas being supplied only as it was consumed by the reaction. This would have added undetectable amounts of oxygen to the product. At present, however, the nitriding step is being started with uranium hydride. The hydrogen by-product must be constantly removed from the system and the nitrogen partial pressure must be regulated carefully to control the rate of the reaction. This is done by constantly pumping the system and maintaining the nitrogen pressure through a steady, controlled leak. Thus, more nitrogen flows through the system than is needed for the reaction, and the oxygen content of the gas stream reacts preferentially with the uranium. Steps are being taken to purify the nitrogen supply stream and to reduce the nitrogen flow with automatic pressure controls.

In addition to the synthesis problems just described, fabrication problems are also being investigated. Adiprene molds have been used to cold isostatically press UN powders at pressures as high as 150,000 psi. Sound compacts result. UN powder purchased from the Y-12 plant of the Union Carbide Corporation was cold isopressed to about 72% of theoretical density at 100,000 psi and to about 73% of theoretical density at 150,000 psi. When these pellets were fired under a vacuum (6×10^{-7} torr) for 2 hours at 1700°C, followed by 1 hour at 2250°C under 10 torr of nitrogen, they reached about 91% of theoretical density. The high-temperature vacuum treatment resulted in a weight loss of 1.8%, but no evidence was seen under

the microscope of either second-phase (U) or liquid-phase sintering.

The Stokes pellet press from CANEL is now operative. Pellets having 55% to 58% of theoretical density have been obtained with single pressings of CANEL, Y-12, and LRL UN powders at a nominal pressure of 60,000 to 65,000 psi. So far the use of binders and lubricants in the UN powder has been avoided to reduce contamination. Lubricants may be required, however, if die wear is excessive.

UN Phase Equilibria and Vaporization Rates

Phase equilibria in the U-N system should be known in order to predict which U-N species will be present at a given temperature and nitrogen pressure. Similarly, the vapor pressure of nitrogen and uranium should be known for each phase at a given temperature. For this purpose, vaporization rates were determined from the weight changes of a Knudsen cell set on a thermal balance.

Initial runs were made in a high-temperature vacuum thermal-balance system (see Fig. 13) with a 2.0705-g sample of powdered (-250 mesh) UN. Chemical analysis indicated a composition of $\text{UN}_{0.98 \pm 0.01}$ with 1280 ppm of oxygen and 560 ppm of carbon. Assuming that all oxygen exists as U_3O_8 and neglecting the carbon as insignificant, the composition becomes $\text{UN}_{0.99 \pm 0.01}$.

The balance was carefully calibrated for mass changes due to convection and buoyancy effects. It was found that at nitrogen pressures up to 130 torr, compositional changes from UN to U_2N_3 and back to UN could be followed with a

Fig. 13. High-temperature vacuum thermal-balance system.

precision of ± 0.002 in the N/U ratio. From 130 to 700 torr, the precision was ± 0.004 . The nitrogen pressure at 0.003 and 700 torr could be controlled with a precision of $\pm 5\%$ and $\pm 0.006\%$ respectively.

The following preliminary results have been obtained:

- The UN_{1+x} and U_2N_{3-y} phase boundaries were determined at 130 and 520 torr of nitrogen (see Fig. 14). These results confirm the work of Bugl and Bauer¹² and Lapat and Holden¹³ in regard to the decomposition temperature for U_2N_3 (see Table VIII).

Table VIII. Comparison of U_2N_3 decomposition temperatures.

Pressure (torr)	Decomposition temperature (°C)		
	Bugl and Bauer ¹²	Lapat and Holden ¹³	This study
130	1192	1207	1210 ± 5
520	1337	1357	1334 ± 10

- At 1334°C , the composition of the UN solid solution varied from $\text{UN}_{0.97 \pm 0.01}$ at 4×10^{-7} torr of nitrogen to $\text{UN}_{0.99 \pm 0.01}$ at 520 torr. The uncertainty of ± 0.01 is due to analytical error.
- At 130 torr of nitrogen, the UN_{1-x} composition was measured in the temperature range of 1210 to 2260°C . Extrapolation of this data to 2642°C , the decomposition temperature of UN at 130 torr,¹⁴ gives an estimated composition of $\text{UN}_{0.93}$ for the phase boundary in equilibrium with $\text{U}_{(\text{liquid})}$.
- The rate of weight loss of UN_{1-x} was measured in a Knudsen cell as a function of temperature at 0.1 and 130 torr of nitrogen (see Fig. 15).

In Fig. 15, the first series of points were taken with the nitrogen activity fixed by the 130-torr nitrogen atmosphere. While Point No. 4 (2413°C) was being taken, most of the oxygen and carbon were probably lost as impurities. At this pressure, gaseous diffusion most likely limits vaporization. Subsequent points taken at lower temperatures (Nos. 5 and 6) were consistent with the points measured before No. 4. A second series of points was taken at a pressure of 0.1 torr. The loss rates were measured and found to be linear with $1/T$ up to about 2300°K . Above this temperature, the sample either appears to be decomposing or there is a considerable evolution of impurities.

The equipment for *in situ* preparation of UN is now complete. After the residual-gas analyzer is installed, a more elaborate and thorough study of the kind reported here is planned. A UN sample having a higher purity and one for which the N/U

Fig. 14. U-N partial-phase diagram.¹¹ The points on the 130-torr and 520-torr isobars are taken from the present investigation.

ratio has been more accurately determined will be used.

Grain Growth in UN

Kinetics of Grain Growth

The kinetics of grain growth in high-density UN was investigated for tempera-

tures of 2000, 2100, and 2300°C under 1 atm of nitrogen. The specimens used consisted of small discs approximately 1/16 in. thick by 0.4 in. in diam. The discs were cut from a UN rod containing about 300 ppm of oxygen, 80 ppm of carbon, and less than 30 ppm of other elements. Measurements of the initial grain

Fig. 15. Rate of weight loss of UN_{1-x} versus reciprocal temperature. The tungsten effusion cell was loaded with 2.0705 g of powdered (-250 mesh) UN. Cell-orifice diameter = 0.252 cm at 2100°C; Clausing factor (W_o) = 0.782.

size and density were made on each disc. The initial grain sizes ranged from 43 to 50 μ , and the densities were within $99.4 \pm 0.1\%$ of theoretical.

For each grain-growth run, a series of seven specimens was inserted in a special holder positioned in a cold region ($<100^\circ\text{C}$) above the hot zone of a tungsten-element vacuum furnace. The entire system was evacuated, then filled with nitrogen to give 1 atm of pressure at temperature. At predetermined times, specimens were dropped from the holder onto a tungsten plate in the hot zone of the furnace.

After each run, the density and grain size were measured. No significant changes in density were detected. Grain growth at 2000 and 2100°C was generally observed to be uniform, and the grains were equiaxed with straight boundaries. Some of the grains in specimens heated at 2300°C for 32 and 64 hours exhibited abnormal growth. They were about five times the average grain size and had very irregular boundaries.

The results of the grain-growth studies are shown in Fig. 16, where the average

Fig. 16. Grain growth in UN. The starting grain size was about 45 μ .

grain diameter is plotted against time at temperature on a log-log scale. This figure shows the expected linear relationship, but the slopes of these curves are approximately 0.1, which is considerably lower than the theoretically predicted value of 0.5.¹⁵

Anomalous Grain Growth

The appearance of very large grains in annealed polycrystalline UN samples has suggested the possibility of growing single crystals of UN by mass transport in the solid state. The six samples in which this phenomenon occurred were cut from hot isostatically pressed UN rods (0.375 in. in diam $\times$ 0.625 in. long). The samples had an initial grain size of about 30 μ and a density 95% of theoretical. Before the samples were given a high-temperature treatment, they were sealed in a molybdenum capsule and heated for 4 hours in a vacuum (10^{-7} torr).

After vacuum heating (10^{-8} torr) at 1500°C for 2 hours, the bottom of the capsule was charged with 3.70 g of U_2N_3 powder that had lattice constants of $a_0 = 3.6895 \text{ \AA}$ and $c_0 = 5.863 \text{ \AA}$. The internal volume of the capsule prior to insertion of the samples was 16.3 cm³. The entire assembly, consisting of the U_2N_3 , the perforated molybdenum support pedestal, and the samples, was then sealed by electron-beam welding. The sealed capsule was then placed in a vacuum furnace and annealed for 24 hours at 1950°C and a pressure of 10^{-6} torr.

Metallographic analysis showed that the modal grain size of five of the annealed samples had grown to 150 μ . In contrast, the sixth sample showed exaggerated grain growth and became a tri-crystal. The

interfaces of the tri-crystal were curved, indicating that the boundaries were not in thermodynamic equilibrium. There was no apparent corrosion of the samples or the can, although the can had been bulged by a high nitrogen pressure (about 20 atm) due to the decomposition of the U_2N_3 . The U_2N_3 decomposed to UN with a lattice constant of $a_0 = 4.8943 \text{ \AA}$.

In a second, more controlled, experiment, two different samples were used. One was cut from the same batch of rods that had showed discontinuous grain growth in the previous experiment, the other from a different batch of 0.250-in.-diam rods. The samples were 0.0625-in.-thick discs with a density 95% of theoretical density. Analysis by emission spectography showed the major impurities to be essentially the same in each sample: 100 ppm of oxygen, 35 ppm of iron, and 8 ppm of nickel. The nitrogen content in both samples was 5.50%, and the modal grain size was 50 μ .

The two discs were supported on a perforated molybdenum stand in a molybdenum can. The bottom of the can below the stand was filled with a predetermined amount of U_2N_3 to generate 8 atm of nitrogen pressure in the sealed can at the annealing temperature. A molybdenum lid was fitted to the can and sealed by electron-beam welding. The annealing was carried out for 24 hours at 1950°C and 10^{-6} torr.

Visual postannealing examination disclosed that the ends of the molybdenum can had bulged to a spherical shape but had not ruptured. Metallographic analysis showed that the large-diameter disc contained only five grains, whereas the small-diameter disc increased in grain size to only 60 μ . Fig. 17 shows the large-diameter disc before and after annealing

(a)

(b)

Fig. 17. A polycrystalline UN disc before (a) and after (b) isothermal annealing at 1950°C and 8 atm of nitrogen for 24 hours (a, 50X; b, 3X). Recrystallization converted the original fine-grained material to five single crystals.

and illustrates the recrystallization phenomenon. As in the previous experiment, the large-grained sample contained non-equilibrium interfaces. Examination of the large-grained sample by electron microprobe and electron microscopy gave no evidence of an impurity concentration or precipitation in the boundaries.

No explanation can be offered at present for these anomalous results, although the possibility of strain-anneal recrystallization is being considered.

Crystal Growth in UN

Testing of recently installed ultra-high-vacuum melting equipment has been completed and initial solidification studies have begun. UN was successfully cast in

tungsten crucibles and melted in a water-cooled silver boat.

In the casting experiment, UN powder was cold-pressed (to 60% of theoretical density) in a tungsten crucible (0.250 in. i.d. $\times$ 1.00 in. long). The crucible was fitted with a cap having a blackbody hole for reading the temperature and was heated in a purified nitrogen atmosphere until liquid UN appeared in the crucible. The heating was by electrical induction (450 kc, 80 kW) with an eddy-current concentrator. The experimental conditions were 2850°C and 3 atm of nitrogen. After quenching, the melted specimens were sectioned along a midplane parallel to the longest dimension of the rod. These sections were then mounted, polished, and

subjected to chemical and metallographic examination and microprobe analysis.

Typically, the fused specimens showed a grain size of about 2 mm. Figure 18 shows that extensive tungsten precipitation (identified by electron-microprobe analysis) took place during the casting cycle.

In the melting experiment in the water-cooled silver boat, cold-pressed specimens (70% of theoretical density) were used that were 0.375 in. in diam $\times$ 1.00 in. long. These specimens were heated in a purified nitrogen environment by electrical induction (450 kc, 10 kW) with a 9-turn

Fig. 18. Microstructure of UN cast in a tungsten crucible (50X). The sample was etched in lactic acid/ HNO_3 /HF. Conditions: 2850°C and 3 atm of nitrogen, then quenched. The white dendrites are tungsten that precipitated during the casting cycle. Some UN has penetrated the walls of the crucible by intergranular diffusion. Differential expansion of the tungsten and the UN has cracked the rim of the crucible.

solenoid coil. The temperatures were read by sighting with a calibrated optical pyrometer on a blackbody hole drilled into the side of the specimen. Liquid was observed at 2850°C and 4 atm of nitrogen. After quenching, the melted specimens were sectioned and examined in the same manner as the cast material.

Emission-spectrography analysis showed the fused material to be more pure than the starting material. Iron, nickel, silicon, and boron in particular were removed beyond detectable limits. No silver contamination was detected. Typically, the fused specimens were badly distorted but showed a grain size of 4 mm. Some liquid-uranium precipitation occurred during cooling despite control of the nitrogen pressure. This effect has been reported previously.¹¹

Various methods are being explored to minimize nucleation in the melted specimens and to create single-phase, single-crystal UN having uniform dimensions.

Nitrogen Diffusion in UN

UN castings received from Battelle Memorial Institute last quarter have been cut into single-crystal samples and annealed. Analyses of these samples are given in Table IX. The diffusion coefficients for three of the samples are listed in Table X and plotted in Fig. 19 along with the results reported in earlier quarters. The temperature column marked "pyrometer" represents the optical-pyrometer reading that has been used to indicate the annealing temperature in all previous quarterly reports. Since the optical pyrometer has been calibrated, the corrected temperature of the sample

Table IX. Analysis of annealed single-crystal samples of UN.

Element	Heat No. 558		Heat No. 559		Heat No. 560		Heat No. 562		Heat No. 563	
	(wt %)	(at. %)	(wt %)	(at. %)	(wt %)	(at. %)	(wt %)	(at. %)	(wt %)	(at. %)
Carbon	20	209	20	211	10	105	10	104	10	105
Oxygen	179	1407	99	784	186	1464	93	729	206	1618
Hydrogen	<1	<126	<1	<127	<1	<126	<1	<125	<1	<126
Aluminum	<10	<47	<10	<47	<10	<47	<10	<46	<10	<47
Boron	0.3	4	0.7	8	0.5	6	0.6	7	1.9	22
Cadmium	<0.1	<1	<0.1	<1	<0.1	<1	<0.1	<1	0.9	1
Calcium	<1	<3	1	3	1	3	1	3	8	25
Copper	1	2	1	2	5	10	11	22	11	22
Iron	<10	<23	<10	<23	<10	<23	<10	<22	<10	<23
Lead	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Magnesium	<2	<10	<2	<10	<2	<10	<2	<10	<2	<10
Manganese	<1	<2	<1	<2	<1	<2	<1	<2	<1	<2
Molybdenum	2.5	3	3	4	4	5	2.5	3	2	3
Nickel	<2	<4	<2	<4	<2	<4	<2	<4	2	4
Silicon	12	54	6	27	6	27	<6	<27	12	54
Tin	<2	<2	<2	<2	<2	<2	<2	<2	<2	<2
Vanadium	<3	<7	<3	<7	<3	<7	<3	<7	<3	<7
Zinc	<20	<38	<20	<39	<20	<39	<20	<38	<20	<38
Nitrogen	5.56	499,233	5.48	495,701	5.55	498,788	5.61	501,971	5.57	499,634

is listed under the "true" temperature heading.

It is not possible with this data to arrive at a heat of activation for diffusion in a specified UN stoichiometry since the U/N ratios are not yet known as a function of temperature and nitrogen pressure.

The three single-crystal samples were annealed at 1946°C (true temperature) and 603 and 472 torr of nitrogen, and at 1957°C and 146 torr of nitrogen. The sample annealed at 603 torr appears to have formed a U_2N_3 surface coating that may void the analysis of this sample because a change in the boundary conditions would invalidate the model being used. The sample at 1957°C will be sectioned and analyzed with a mass spectrometer as a check on the

values for the coefficients of diffusion calculated by the activation method.

Bubble-Migration Studies

An attempt is being made to follow the migration of helium bubbles through MgO in order to gain basic information about the swelling of nuclear fuels. One problem is to get a uniform distribution of the gas in the solid. Experiments to achieve a uniform initial gas distribution were done by bombarding B_2O_3 in MgO with neutrons. An MgO melt was doped with 0.01% of B_2O_3 by W. and C. Spicer, Ltd. (London). The doped crystals were columnar in shape and had lengths as great as 2 cm. Spectrographic analysis showed a

Table X. Diffusion coefficients of nitrogen in UN.

Temperature		Nitrogen pressure (torr)	D ^a (cm ² /sec)
Pyrometer (°C)	True (°C)		
1970	2000	135	$3.9^{+1.8}_{-0.9} \times 10^{-10}$
1960 ^b	1989	132	$3.02^{+0.25}_{-0.16} \times 10^{-10}$
1940 ^b	1968	162	$2.1^{+0.9}_{-0.7} \times 10^{-10}$
1920 ^b	1946	7	$4.6^{+1.7}_{-1.2} \times 10^{-11}$
1910	1935	116	1.96×10^{-10}
1910	1935	14	1.07×10^{-10}
1850	1871	133	$1.7 \pm 0.6 \times 10^{-10}$
1800	1856	107	$9.57^{+0.6}_{-0.8} \times 10^{-11}$
1792	1848	129	1.3×10^{-10}
1730	1780	152	9.8×10^{-11}
1730	1780	152	8.8×10^{-11}
1730	1780	152	7.1×10^{-11}

^aArithmetic mean. The extreme range of values from a single microdensitometer trace is shown as D^{+x}_{-y}.

^bSingle crystal. All other samples consisted of coarse grains (several mm in size).

boron concentration of 0.001% in the transparent crystals, and a concentration of 0.03% in discrete yellow regions scattered throughout the melt. One of the doped MgO crystals was irradiated with a thermal-neutron flux of 4.4×10^{12} neutrons/cm²-sec for 12 hours in the Livermore Pool-Type Reactor. Helium is produced by the B¹⁰ (n, α) Li⁷ reaction in the irradiation.

The feasibility of producing uniformly distributed helium by irradiating boron-doped UN with neutrons was also considered. The major problem in this procedure is the production of radioactivity by

fission in the U²³⁵. The amount of activity produced was measured experimentally by irradiating a small sample of depleted uranium (0.163 % U²³⁵). The calculated and experimental values were in close agreement. The results permit the prediction that a 1-g sample of UN doped with 2% of B¹⁰ and containing 0.1 mole % of helium would have an activity of 100 mCi 30 days after neutron irradiation.

One sample of MgO, which had previously been irradiated with alpha particles, was annealed in a crude thermal-gradient furnace for 2 hours in a gradient estimated at 1000°C/cm and at a temperature of

Fig. 19. Diffusion of nitrogen into UN.

1800°C. The irradiated surface of the MgO sample was then beveled to a depth of about 150 μ . The beveled surface was polished and replicas of electron micrographs were prepared. A typical result is shown in Fig. 20. The surface appears to be covered with large numbers of irregularly shaped bumps varying in diameter from 500 to 5000 Å. A possible explanation is that these bumps are hardened regions surrounding gas bubbles. Such bumps have been observed by Weaver, who suggests that they are caused by localized stress concentrations around the helium bubbles in the UN.¹⁶ However, the bumps may only be artifacts introduced in the replication.

Compressive Creep of UN

The objective of this investigation was to determine the high-temperature plastic-

deformation behavior of stoichiometric UN as a function of stress and temperature. The creep of other refractory compounds containing uranium (e.g., UO_2 and UC) has been studied by various investigators.¹⁷⁻²⁰ Fassler *et al.*²⁰ have studied the creep of UN in a vacuum from 1100 to 1350°C at stresses of 6000 and 8000 psi. In the present work, the creep of UN in equilibrium with 200 torr of nitrogen was investigated from 1500 to 1800°C at stresses from 2000 to 5000 psi.

The specimens were prepared by hot isostatically pressing UN powder into cylinders 1/4 in. in diam and about 1 in. high. After pressing, the specimens were heat-treated in approximately 10 atm of nitrogen at 1900°C for 50 hours. The densities of the individual specimens were determined by the water-displacement method. All specimens had a density 100% of theoretical, based on a value of 14.32 g/cc.²¹ The principal metallic impurities were 50 ppm of calcium, 5 ppm of copper,

Fig. 20. Electron micrograph of a replica of a beveled MgO surface. The bumps may be hardened regions surrounding gas bubbles.

30 ppm of iron, 5 ppm of magnesium, 10 ppm of nickel, and 20 ppm of silicon. The oxygen content was 400 ± 50 ppm, and the carbon content was 100 ± 25 ppm. The nitrogen content was 5.56 ± 0.05 wt %. The average grain size for the five specimens, as determined by the intercept method, was 0.14 ± 0.01 mm. One specimen had a grain size of 2.0 mm. This large grain size is an anomaly (see p. 24) since all specimens had the same chemical and thermal histories.

Specimens 1/4 in. in diam and 1/2 in. high were creep-tested under compression in a clam-shell furnace heated by sheet elements of W-25%Re. The temperature was measured within $\pm 10^\circ\text{C}$ by an optical pyrometer that had been calibrated with a standard source. Before the specimen was heated to the test temperature, the furnace chamber was evacuated to 10^{-5} torr and then back-filled with nitrogen.

The compression load was applied and controlled by an Instron testing machine, and the stress was held constant to within $\pm 2\%$ of the selected value. The strain was determined by measuring, with an optical comparator, the distance between fiducial marks on the specimen before and after testing. The gauge length was 1/4 in. The strain rate was calculated from the strain and the time under load.

The creep of many crystalline materials can be described by

$$\dot{\epsilon} = f(s)\sigma^n \exp\left(-\frac{\Delta H}{RT}\right) \quad (5)$$

where $\dot{\epsilon}$ is the creep rate, $f(s)$ is a function involving structure, σ is the applied stress, n is a constant, ΔH is the apparent activation energy for creep, R is the gas constant, and T is the absolute temperature. The

change-of-stress technique was used to evaluate n . In this method, creep rates are measured at a constant temperature as the applied stress is varied incrementally. The n for UN was 6.0 ± 1.0 (see Fig. 21). The ΔH for UN was determined from creep rates at a selected stress at various temperatures; it was 75 ± 10 kcal/mole (see Fig. 22).

Also included in Fig. 22 are the data of Fassler *et al.* on the creep of UN.²⁰ Most of the tests conducted by these investigators were on specimens that had oxygen contents of about 2600 ppm (Curve Nos. 1 and 2 in Fig. 22), but a few tests were run on specimens in which the oxygen impurity level was comparable to that of the specimens tested in the present study (Curve No. 3 in Fig. 22). The latter data were then extrapolated to higher temperatures, using an activation energy of 62.0 kcal/mole. Although the two investigations obtained different activation energies for creep, the relative positions of the curves for specimens having equivalent oxygen contents are consistent if the data are corrected for the effect of stress on the creep rate. The data also indicate that the creep resistance of UN increases with increasing oxygen content.

The influence of stress on the strain rate can be described by the relation $\dot{\epsilon} \propto \sigma^6$ (see Fig. 21). This kind of stress law is typical of deformation that occurs by dislocation motion.²²⁻²⁴ None of the theoretical creep mechanisms involves a stress component of exactly 6, but the dislocation-climb model²² where $n = 4.5$ is closest to the experimental value of $n = 6$. Fassler and his co-workers obtained a stress exponent of 4.2 based on two stresses. In the present investigation, the creep rate

Fig. 21. Creep of UN: strain rate versus stress.

was based on strain that occurred during both primary and secondary creep, whereas Fassler *et al.* reported secondary

Fig. 22. Creep rate of UN versus temperature.

creep rates obtained by extensometry during testing. The apparent difference in stress laws may result from the inclusion of strain from primary creep in the calculation of the creep rates for the present data.

Above 1/2 of the melting temperature (in absolute units), the activation energy for creep is usually related to a volume-diffusion process. The activation energy for the diffusion of nitrogen in UN is 55 kcal/mole.²⁵ Since the activation

energy for creep found in the present investigation was 75 kcal/mole, diffusion of the uranium ion is apparently the rate-controlling diffusion process during creep. It is interesting to note that diffusion of the uranium ion is the rate-controlling diffusion process during creep in stoichiometric UO_2 .¹⁷

In some cases, the creep rate of polycrystalline materials depends on grain size. The curve for the 5000-psi stress in Fig. 22 was obtained from the specimen with a grain size of 2.0 mm. Nevertheless, the creep behavior of this specimen is consistent with the creep data from the other specimens in this work whose grain sizes were smaller by a factor of 15. In addition, extrapolated creep rates from the data of Fassler *et al.* for specimens having a grain size of 0.03 mm (Curve No. 3 in Fig. 22) were also consistent with the creep rates from the present study. Thus, $f(s)$ in Eq. (5) is probably not sensitive to grain size.

LIQUID-METAL STUDIES

Corrosion-Loop and Capsule Programs

Status of the Corrosion Loop

Enough W-25%Re-30%Mo (at. %) to make one corrosion loop should be available from the General Electric Company by November 1967. The first pieces of W-25%Re-30%Mo tubing have been received and are now undergoing nondestructive tests at LRL. These pieces will be used either for a weld-development study or for the first pumped capsule if their quality is high enough.

A program has been started to develop an in-house capability at LRL for assembling the first corrosion loop. Areas of

interest to the program include the development of adequate techniques for making butt, fillet, and edge welds in tungsten-rhenium-molybdenum alloys; the design and construction of apparatus to manipulate loop subassemblies during electron-beam welding; and the development of nondestructive test procedures to evaluate the integrity of weld joints. The program will include making simulated loop welds in tungsten-rhenium-molybdenum alloys and testing the mechanical properties of these welds; simulating the fabrication of critical subassemblies with alumina pieces; and fabricating a stainless-steel loop that is an exact copy of the W-25%Re-30%Mo loop.

One reason for this increased emphasis on welding development has been the recent discovery at LRL and General Electric that welds in 0.004-in.-thick W-25%Re-30%Mo sections are porous even though welds in similar 0.001 to 0.0015-in. material are not. Several welds of 0.004-in. sections will be needed in the corrosion loop.

Status of the Pumped Capsules

The first pumped-capsule test is intended to determine the ability of W-25%Re-30%Mo to withstand corrosion under loop conditions. Hence, the capsule test is a key item in the loop development program. All major components of the pumped capsule have been received and are being inspected and cleaned. This includes the vacuum bell jar, assembly spool, support brackets, heat shields, water-cooled walls and power leads, and other associated parts.

Sampling and Handling Techniques

As a quality-control measure, metallurgical and chemical analyses must be

performed on the materials used in the pumped capsules and the corrosion loop. Samples for these analyses must be cut from the capsules and the loop without introducing impurities into the samples.

The laser provides a feasible way to cut open capsule and loop tubing and to prepare samples for analysis. The speed at which the samples can be cut depends on the repetition rate and the power of the laser. With high repetition rates (15 pulses/min or more), the time required to cut tungsten is short enough to make this method competitive with more conventional ones.

The tests reported here were run with the samples in air. Future tests in argon are anticipated. The samples pierced in air showed a black discoloration (assumed to be an oxide) around the entrance point of the beam.

The laser head used in this study was a Brewster angle ruby rod (0.5 in. in diam and 6 in. long) pumped by two linear xenon flash lamps. One of the mirrors was 99% reflective and had a nitrobenzene cell in front of it to prevent burning of the mirror. The output mirror was 10% reflective. During operation, the head was cooled by an air stream that had been passed through an ice bath. The laser gave an average output of 15 J.

The capacitor bank used to fire the laser had a storage capacity of 17,300 J when charged to 6000 V, but all of the tests were run with the bank at 5900 J and 3500 V.

The double-convex lens used with the laser was 1.79 in. in diam and had a focal length of 44 mm; it was set 1 ft away from the output mirror. It was found that the samples had to be between 48 and 51 mm

from the center of the lens to get the best results.

Tungsten sheets having thicknesses of 0.040, 0.050, 0.060, and 0.125 in. were the first samples tested. The sheets were mounted on a micrometer table so that they could be moved parallel and perpendicular to the laser beam. The 0.040-in. sheet, when positioned with its front surface 48 mm from the center of the lens, was pierced completely with one pulse of the laser. The average diameter of the entrance holes was 0.020 in., and the exit holes varied from 0.002 to 0.009 in. in diam. The 0.050-in. sheet was pierced completely by two laser pulses, and the average diameters of the entrance and exit holes were 0.025 and 0.010 in. respectively. The 0.060-in. sheet was pierced by three laser pulses; it had average entrance-hole diameters of 0.020 in. and exit-hole diameters of 0.010 and 0.015 in. Figure 23

Fig. 23. Laser exits in 0.060-in.-thick tungsten sheet.

shows two exit holes in the 0.060-in. sheet; their appearance is typical of that for all sheets.

All of the above tests were made with the samples at the same distance from the center of the lens (48 mm) for all pulses. In the tests on the 0.125-in. sheet, however, the specimen was moved between pulses to keep the focal point of the beam in the metal. Two holes were drilled in the 0.125-in. material with this procedure. In the first test, the specimen was started at 48 mm from the center of the lens, and after each pulse it was moved 0.020-in. closer to the lens. Although the sheet had not been pierced after eight pulses, it was not shifted any more because the next change would have put the back surface of the specimen out of the focus of the beam. With four more pulses at the same distance as the eighth pulse, the sheet was pierced. In the second test, the same specimen was started as before, but after each pulse it was moved 0.015-in. closer to the lens. The eighth pulse pierced the sheet. Both tests on the 0.125-in. sheet gave an entrance-hole diameter of 0.030 in. and an exit-hole diameter of about 0.003 in. Figure 24 shows both entrance holes in the 0.125-in. sheet.

Fig. 24. Laser entrances in 0.125-in.-thick tungsten sheet.

Table XI summarizes the information on the tests with tungsten sheet.

A final test was performed on a piece of W-30%Re-30%Mo(at.%) tubing (0.5-in. o.d. and 0.040-in.-thick wall). This tube was mounted on a turntable with its front surface 48 mm from the center of the lens. Based on the assumption of an entrance-hole diameter of 0.020 in., it

Table XI. Results of laser experiments with tungsten sheet.

Thickness of sheet (in.)	Number of pulses to pierce	Hole diameters (in.)	
		Entrance	Exit
0.040	1	0.020	0.002 to 0.009
0.050	2	0.025	0.010
0.060	3	0.020	0.010 to 0.015
0.125 (Test No. 1)	12	0.030	0.003
0.125 (Test No. 2)	8	0.030	0.003

Specimen moved to
keep it in focus

was decided to rotate the tube 2 deg after each shot, thus ensuring that the holes would overlap.

With this procedure, the tube was completely cut around its circumference except for two or three points that broke easily under finger pressure to completely separate the tube into two parts. The inside of the tube contained a thin blue film (probably an oxide), which could be wiped off cleanly.

Figure 25 shows the edge of the laser cut on one-half of the tube. Figure 26 shows a polished and etched cross section of the tube, showing the edge of the laser cut and the microstructure around it. It appears that the heat-affected zone may be only a few thousandths of an inch deep,

but more work is being done to confirm this.

ANALYTICAL STUDIES

Determination of Rhenium and Molybdenum in Tungsten-Rhenium-Molybdenum Alloys

In determining rhenium and molybdenum in a tungsten-rhenium-molybdenum alloy, the alloy is first fused with potassium pyrosulfate in a platinum crucible at the minimum temperature necessary to sustain the reaction. The melt temperature is kept low because of the possibility of volatilizing the rhenium. After fusion, the melt is dissolved in dilute NH_4OH . The result of an experiment conducted with pure rhenium indicates that little

Fig. 25. Edge of laser cut in W-30%Re-30%Mo (at. %) tubing (10X).

Fig. 26. Microstructure of W-30%Re-30%Mo (at. %) tubing at laser cut (100X).

rhenum is lost during the fusion. A 418.2-mg sample of rhenum was dissolved by this method, and 417.6 mg was recovered in the melt solution.

Rhenum is determined by precipitation as the tetraphenylarsoniumperrrhenate^{26,27} from a 0.5-M NaCl solution. The precipitate is allowed to stand overnight. Then it is filtered through a fine-pore filtering crucible, washed with water that is saturated with tetraphenylarsoniumperrrhenate, dried at 150°C, and weighed. The results of analysis of rhenum in synthetic samples (see Table XII) indicate

Table XII. Determination of rhenum in synthetic tungsten-rhenum-molybdenum samples.

Amount of rhenum used (mg)	Amount of rhenum recovered (mg)
31.36	31.09 ^a
31.36	31.32 ^b
31.36	31.38 ^b

^aPrecipitate washed with cold water.

^bPrecipitate washed with water that is saturated with tetraphenylarsoniumperrrhenate.

that the method is applicable in the presence of tungsten and molybdenum.

Analysis of Refractory Alloys for Titanium, Tungsten, Molybdenum, Niobium, and Tantalum

An anion-exchange procedure employing fluoride media can apparently be used to separate and determine titanium, tungsten, molybdenum, niobium, and tantalum in a single sample of a refractory alloy.^{28,29} After the alloy is dissolved in appropriate

mixtures of HCl, HNO₃, and HF, the sample is taken to near dryness and redissolved in 1-M HF. This solution is passed through a Dowex-1 anion-exchange resin, and the five metals are adsorbed. Various mixtures of HF/HCl and NH₄F/NH₄Cl are then used as eluting solutions.

The titanium, tungsten, and molybdenum fractions are evaporated with sulfuric acid to remove the HF. Titanium is determined calorimetrically with H₂O₂; tungsten is precipitated with cinchonine, ignited to WO₃, and assayed gravimetrically; and molybdenum is precipitated with α -benzoinoxime, ignited to MoO₃, and determined gravimetrically. The niobium and tantalum fractions are precipitated with cupferron after complexing the fluoride with H₃BO₃. A gravimetric determination is again used after ignition to the oxides.³⁰

Work completed thus far indicates that the five metals can be individually adsorbed on Dowex-1 resin and then quantitatively eluted. Data are not yet complete on adsorbing mixtures of these elements on the resin and eluting them one at a time in the presence of each other.

There is provision in the procedure for the removal of aluminum, manganese, nickel, chromium, cobalt and iron, which are likely to be present in high-temperature alloys. The use of HF required the construction of all-plastic ion-exchange columns; disposable columns were developed from Tygon tubing.

Determination of Metallic Impurities in Tungsten, Molybdenum, and Tungsten-Rhenum-Molybdenum Alloys

The electrode configuration and conditions for exciting MoO₃ reported earlier³¹ have been revised. The revision is based

on recent studies of the processes that occur in the dc arc discharge for exciting the impurities in MoO_3 .^{*} It has been found that these conditions can also be applied to the excitation of impurities in WO_3 and mixtures of WO_3/MoO_3 .

In order to apply this method of excitation, metal samples are converted to the oxide either by direct oxidation or by acid

^{*}See p. 48ff in the 1967 second-quarter report, UCRL-50004-67-2.

Fig. 27. New electrode configuration.

dissolution and thermal conversion of the tungstic or molybdic acids to the oxide. In the case of tungsten-rhenium-molybdenum alloys, the metal is dissolved in concentrated HNO_3 containing a few drops of HF . The acid mixture is evaporated and the rhenium is separated by volatilizing Re_2O_7 (bp = 370°C). The remaining mixed oxide (WO_3/MoO_3) is then available for excitation.

The electrode configuration is shown in Fig. 27, and the excitation conditions are given in Table XIII.

Table XIII. Conditions for Exciting MoO_3 , WO_3 , and WO_3/MoO_3 .

Excitation	Direct-current arc programmed to give 5 A for 30 sec, 10 A for 30 sec, and 15 A for 30 sec
Electrodes	Cathode: UCP ^a 5001 Anode: UCP ^a 1998, UCP ^a 1964
Electrode gap	4 mm
Electrode charge	See Fig. 27
Atmosphere	Argon, 8 ft ³ /hour
Total exposure time	90 sec

^aUltra Carbon Products

Neutronic Calculational Methods

UPDATING OF EXISTING CODES AND CROSS-SECTION COMPILATIONS

R-Division MESNE Program

The cross-section library reported in the 1967 second-quarter report (UCRL-50004-67-2) has been expanded to

include the materials listed in Table XIV. In addition, the rhenium and silver cross sections have been more thoroughly evaluated and updated. Note that some of the materials listed in Table XIV are new by virtue of having been averaged over a

spatially dependent spectrum. That is, a typical SPR-6 design was chosen and the spectrum was calculated as a function of position in the system. The group cross sections were then obtained by averaging over the spectra at the locations indicated in Table XIV.

Processing of neutron cross sections has heretofore been accomplished by means of the R-Division MESNE program.* However, this processing is not feasible

*See p. 11ff in the 1966 first-quarter report, UCRL-50004-66-1.

Table XIV. New nuclides for which group cross sections are available.

Nuclide	Remarks
Barium	Spatially independent weighting spectrum
$1/v^a$	Spatially independent weighting spectrum
Silver	Newly evaluated and updated
Rhenium	Newly evaluated and updated
U^{235}	Weighting spectrum from SPR-6 core region
U^{238}	Weighting spectrum from SPR-6 core region
Nitrogen	Weighting spectrum from SPR-6 core region
Beryllium	Weighting spectrum from SPR-6 core region
Oxygen	Weighting spectrum from SPR-6 core region
Tungsten	Weighting spectrum from SPR-6 core region
Tungsten	Weighting spectrum from SPR-6 pressure-vessel region
Beryllium	Weighting spectrum from SPR-6 reflector region
Oxygen	Weighting spectrum from SPR-6 reflector region

^aIdealized material in which the capture cross section is inversely proportional to the neutron velocity.

for the first four nuclides listed in Table XIV because the data have been obtained from original sources rather than from the R. J. Howerton Evaluated Library.³² The input requirements for the R-Division MESNE program are peculiar to the format of the Howerton Library. Accordingly, the SOPHIST IIA,³³ SOPHIST-5,³⁴ and UTRANS³⁵ codes were used to process all the cross sections for the first four nuclides listed in Table XIV. The remainder of the nuclides listed in Table XIV were processed as before (i. e., with the R-Division MESNE code).

NEUTRONIC CALCULATIONS FOR THE SPR-4 REACTOR

The preliminary definition of the SPR-4 reference design is given in the 1966 second-quarter report (UCRL-50004-66-2). The current constraints are listed in Table XV. All calculations reported in this section are based directly upon these numbers. The calculations described here were performed with the ZOOM and DTF codes operating with the R-Division 16-group cross-section library as described in preceding quarterly reports. The ZOOM diffusion-theory code is used because of its short running time and convenience of use. The DTF code is used where necessary to normalize the ZOOM-computed results.

The operational changes in densities of U^{235} , U^{238} , U^{236} , and Pu^{239} are calculated with 1-group equations; no spatial dependence is involved. The flux is assumed to be constant for a specified time interval. In this particular study, the reactor lifetime is divided into 10 equal time intervals so that the changes

Table XV. Constraints on the SPR-4 reference design.

Neutronic constraints

Power	2 MW	
Lifetime	20,000 hours	
Fuel	UN	
Reactor coolant	Lithium	
Temperature of reactor-coolant outlet	1500°K	
Structural material	W-25%Re-30%Mo (at. %) ^a	
Length/diameter ratio	1.2	
Kind of fuel elements	<u>Spaced pin^b</u>	<u>Tube^b</u>
Burnup	1.2%	1.6%
Linear swelling	2.4%	3.2%
Material volume fractions		
Fuel	0.645	0.743
Cladding	0.165	0.035
Coolant	0.143	0.149
Swelling allowance	0.048	0.074
Core volume	17,500 cm ^{3c}	11,400 cm ^{3c}

Other constraints

Mission	Unmanned
Power-conversion system	Turbo-generator
Working fluid	Potassium
Radiator heat-pipe fluid	Potassium
Shielding	
Geometry	Circular
Shielded-cone half angle	14 deg
Neutron dose at 10 m	10 ¹³ neutrons/cm ²
Gamma dose at 10 m	10 ⁶ rad

^aUsed for both the cladding and the pressure vessel in the calculations.^bSee Fig. 28.^cAssumes 1.099 g of uranium fissioned per megawatt-day.

in flux and atomic density proceed in steps. The 1-group cross sections³² are weighted according to the SPR-3 flux. The thermal expansion of the reactor between 300 and 1500°K is assumed to be determined by the expansion coefficient for tungsten ($5.08 \times 10^{-6}/^{\circ}\text{C}$).

Material densities are given in Table XVI. These numbers are combined with the volume fractions from Table XV in the neutronics calculations.

Both the outer-annulus and the central-pipe coolant-return geometries are considered in this study. The reactor

Fig. 28. Two kinds of fuel-element geometry considered for the SPR-4 reactor.

Table XVI. Densities of reactor materials.

Material	Temperature (°K)	Density (g/cm ³)	Density (10 ²⁴ atoms/cm ³)
Li ⁷	300	0.534	0.04633
Li ⁷	1500	0.430	0.0373
UN	300	14.32	0.0342
Tungsten ^a	300	9.52	0.0312
Rhenium ^a	300	5.36	0.0173
Molybdenum ^a	300	3.31	0.0208

^aOccurs only in W-25%Re-30%Mo (at.%), whose density is 17.0 g/cm³.

dimensions for both geometries are shown in Fig. 30 for the two kinds of fuel elements listed in Table XV.

Operational shutdown	0.02
End reflection	0.03
Miscellaneous reflection	0.01

Fuel-Enrichment and Control Requirements

The proper fuel enrichment is taken to be that for which the DTF code calculates $k_{\text{eff}} = 0.94$ for the unreflected reactor. This implies a critical system when the following reactivity contributions are assumed:

The calculation of k_{eff} versus fuel enrichment is shown in Fig. 29 for the four systems described in Fig. 30

Control requirements, as calculated by the ZOOM code, are summarized in Table XVII. The required reflector thickness is found from the curves of k_{eff}

Fig. 29. DTF calculation of k_{eff} versus fuel enrichment. The curves are labeled for the fuel geometry and the geometry of the coolant-return passage.

Fig. 30. Dimensions of the SPR-4 reactor. The area of the coolant-return annulus is equal to the core-flow area, and the area of the central pipe is 0.3 of the core-flow area. The thickness of the pressure-vessel wall is 0.635 cm in all cases. In the length/diameter ratio, L is the reactor length and D is the inner diameter of the pressure vessel.

Table XVII. Summary of control requirements.

	Pin		Tube	
	Annulus	Central pipe	Annulus	Central pipe
Δk_{eff}				
Operational loss	0.0103	0.0100	0.0126	0.0126
Temperature	0.0156	0.0140	0.0166	0.0142
Fuel swelling	0.0029	0.0027	0.0046	0.0042
Operational shutdown	0.0200	0.0200	0.0200	0.0200
Operational reserve	0.0100	0.0100	0.0100	0.0100
Total adjustable reactivity required	0.0588	0.0567	0.0638	0.0610
Inverse reflector efficiency ^a	1.47	1.47	1.47	1.47
Reactivity worth required of reflector	0.0864	0.0833	0.0938	0.0897
Required thickness of BeO reflector	2.6 cm	1.9 cm	2.3 cm	1.7 cm

^aRatio of reactivity worth required of reflector to total adjustable reactivity required. The value given is based on the assumption that the side reflector consists of six adjustable vanes of 60 deg each. The value consists of three factors: Postulated failure of one vane is taken into approximate account by a factor of 6/5. A factor of 1/0.85 converts the adjustable reactivity worth of the side reflector to the total worth of the side reflector. The final factor of 1.04 accounts for a vane-shadowing effect observed in critical experiments at CANEL.

versus thickness calculated by DTF and shown in Fig. 31.

Radial Power Shaping

The fuel enrichment required for any of the four reactor models shown in Fig. 30 is so high that criticality limitations enter the picture if one attempts to flatten the radial power profile by nonuniform enrichment. The loss in reactivity due to the outward displacement of U^{235} may be compensated for by adding a certain thickness of fixed side reflector. Whatever this thickness may be, it is minimized by having a maximum fuel enrichment of 100% in the core.

Since the radial power profile is sensitive to changes in reflector thickness, the

ideally flat profile cannot be maintained throughout the operating lifetime where side-reflector movement is necessary for control. For this study, it is assumed that the radial power is optimal if it is flat at the halfway point of the operating lifetime. Therefore, it is desirable to know what the reflector thickness is at the halfway point so that the radial fuel enrichment can be adjusted for flat power at that thickness. The calculational procedure is illustrated by the following example.

Consider the case of an annulus coolant return and pin fuel element geometry. It is assumed that the effects on reactivity of temperature, operational loss, and fuel swelling are the same for the flat-power reactor as for the uniformly enriched

Fig. 31. DTF calculation of k_{eff} versus the thickness of the BeO side reflector. The curves are labeled for the fuel geometry and the geometry of the coolant-return passage.

reactor. The reactivity history is outlined in Table XVIII. The programmed reactivity [$\Delta k(PR)$] is the amount of positive reactivity that must be provided by the control system. Since the power-profile calculation is to be done by the ZOOM code, it is desirable to know the appropriate value of k_{eff} for the ZOOM calculation corresponding to the halfway point of operation.

Where DTF calculates $k_{eff} = 0.94$, ZOOM calculates 0.885. (Recall that for the unreflected reactor, $k_{eff} = 0.94$ when the effects of end reflection and miscellaneous reflection are subtracted.) In Table XVIII, $\Delta k(PR)$ is 0.042 at the halfway point. Then, for the ZOOM calculation at the halfway point, we should have $k_{eff} = 0.885 + 0.042 = 0.927$.

By a series of trial calculations, it is found that the reflector thickness must be about 2.3 cm in order to obtain a flat radial power profile with a maximum fuel enrichment of 100% and a $k_{eff} = 0.927$. Since the radial power has been flattened for each trial calculation, the appropriate initial radial fuel enrichment has thus been established.

A curve of k_{eff} versus reflector thickness can now be calculated to determine the thickness of the fixed reflector and the

Table XVIII. Reactivity history of the SPR-4 reactor with pin fuel element geometry (Fig. 28) and an annulus coolant return.

State	$\Delta k(T)$	$\Delta k(OL) + \Delta k(FS)$	$\Delta k(PR)$	k_{eff}
Initial; cold reactor, control elements fully out	—	—	—	0.9800
Full power	-0.016	0.0	0.036	1.0000
Full power; one-half of operating lifetime accrued	-0.016	-0.007	0.042	1.0000
Full power; full operating lifetime accrued	-0.016	-0.013	0.049	1.0000

maximum total reflector thickness necessary for operation. Such curves are shown in Fig. 32. For the case discussed above, the thickness of the fixed reflector (that for which $k_{\text{eff}} = 0.885$) is found to be 1.3 cm. The maximum total thickness can be found by referring back to Table XVII. The reactivity worth required of the side reflector is 0.0864; therefore, the total required thickness is that for which ZOOM calculates $k_{\text{eff}} = 0.885 + 0.086 = 0.971$.

Fig. 32. ZOOM calculation of k_{eff} versus the thickness of the BeO side reflector where the radial power density is flat at the halfway point of operation.

Fig. 32 shows that this thickness is 3.8 cm. The entire reflector will then consist of a fixed layer 1.3 cm thick and a movable layer 2.5 cm thick.

Effect of Lithium Loss

The dependence of k_{eff} on the Li^7 enrichment of both the stagnant and the coolant lithium is shown in Fig. 33. The calculations apply to the initial state of the unreflected reactor at 300°K. Note that at beginning-of-life, stagnant lithium fills the volume designated "swelling allowance" in Table XV. At end-of-life, the fuel is assumed to have expanded into this volume and displaced the stagnant lithium.

Figure 33 displays the values of k_{eff} calculated for a void in place of stagnant or coolant lithium. (This point is not indicated for the coolant lithium in the central-pipe geometry since the treatment of a central void region is not an option in either ZOOM or DTF.) The significance of the indicated intersection points is that the corresponding enrichment is the value that would yield a null effect on reactivity when the lithium (stagnant or coolant) is expelled from the core.

These results indicate the amount of control that can be achieved by varying the lithium enrichment in either of the two lithium components.

NEUTRONIC CALCULATIONS FOR THE SPR-6 REACTOR*

Power Flattening

The problem of power flattening has been studied for the SPR-6 reactor with a central coolant-return pipe and a fuel-burnup fraction of 0.02. The volume of

*See also p. 88.

Fig. 33. ZOOM calculation of k_{eff} versus Li^7 enrichment in stagnant lithium (Curve No. 1) and coolant lithium (Curve No. 2). Values of k_{eff} are indicated for replacement of the lithium by a void. Along Curve No. 1 in each case, only the stagnant-lithium enrichment is variable (the coolant lithium is 100% Li^7). Along Curve No. 2 in each case, only the coolant-lithium enrichment is variable (the stagnant lithium is 100% Li^7).

the central coolant-return pipe was 20% of the active core volume ($V_p/V_c = 0.2$). Power flattening was accomplished by radially varying the fuel enrichment. The criterion adopted was that the power be flat within $\pm 10\%$. The radial power profile is expected to vary over the reactor life-time due to side-reflector motion, so the power was flattened at midlife (5000 hours).

Table XIX presents the results of this study. Five regions (corresponding to five different fuel-enrichment values) were found to be adequate for satisfying the flatness criterion.

Table XIX. Fuel-enrichment profile required to produce a flat power distribution ($\pm 10\%$) at 5000 hours for the SPR-6 reactor (fuel burnup = 0.02, $V_p/V_c = 0.2$).

Region	Outer radius of region (cm)	Fuel enrichment
1	23.8	0.43
2	27.5	0.53
3	29.2	0.64
4	31.0	0.74
5	32.6	0.91

The operation history of the reactor is outlined in Table XX. The determination of the required reflector thickness is based on the reflector-worth curves of Fig. 34, which are calculated by ZOOM with a normalization to DTF. For comparison, the results for the reactor with unflattened power are also shown. Note the increase in reflector worth resulting from power flattening.

The radial power distribution of the reactor is shown in Figs. 35 through 37, which correspond to three times during the reactor operation: 0, 5000, and 10,000 hours. The corresponding reflector thicknesses are 1.1, 1.5, and 2.0 cm.

Since LRL's one-dimensional codes (including ZOOM) cannot exactly represent a realistic reflector configuration, it was necessary to use an equivalent uniform reflector thickness in this calculation. In reality, with a vane-control system, the power can be expected to vary azimuthally depending on vane position, or with an axially translating reflector, the radial power distribution can be expected to vary axially (i.e., fully reflected at some axial locations and unreflected at others).

Table XX. SPR-6 (flat-power) operation history (fuel burnup = 0.02, $V_p/V_c = 0.2$).

Time (hours)	Δk (required) ^a	Reflector worth required ^b	Reflector thickness required (cm)
0 (shutdown)	0.000	0.000	0.0
0 (cold critical)	0.020	0.026	0.5
0 (hot critical)	0.043	0.056	1.1
5,000	0.057	0.074	1.5
10,000	0.070	0.091	2.0

^aOperational losses and temperature effect.

^bBased on an inverse reflector-effectiveness factor of 1.3.

Axial Zoom Calculations

End-Reflection Worths

In the multigroup neutronic calculations to date, the SPR-6 reactor has been represented in a detailed manner in the radial direction, but only approximately in an axial direction. The procedure has been to represent end leakage by an absorption cross section equal to the diffusion coefficient (D) times the axial geometric buckling (B_g^2) that is determined for the reactor without end reflection. In computing the required fuel enrichment, the worth of the end reflection has been estimated as $\Delta k(ER) = 0.03$. The purpose of the present calculations was twofold—to make a better estimate of $\Delta k(ER)$ and to determine the axial power distribution of the reactor.

The SPR-6 reactor considered in this study* had fuel burnups of 0.01, 0.02, and 0.03 as described in the 1966 fourth-quarter report (UCRL-50004-66-4). The representation used in the axial ZOOM

*The cladding, structure, and pressure vessel were composed of W-25%Re(at.%).

Fig. 34. BeO side-reflector worth for the SPR-6 reactor with and without power flattening. In both cases, the fuel burnup is 0.02 and $V_p/V_c = 0.20$. The flat-power case was achieved by radially varying the fuel enrichment in the presence of 1.5 cm of BeO side reflector until the power was flat to within $\pm 10\%$.

Fig. 35. SPR-6 radial power distribution with flat ($\pm 10\%$) power. The reactor has a central coolant-return duct with $V_p/V_c = 0.20$. The fuel burnup is 0.02. The side-reflector thickness of 1.1 cm corresponds to the initial hot critical position.

Fig. 36. SPR-6 radial power distribution with flat ($\pm 10\%$) power. The reactor has a central coolant-return duct with $V_p/V_c = 0.20$. The fuel burnup is 0.02. The side-reflector thickness of 1.5 cm corresponds to the 5000-hour position.

Fig. 37. SPR-6 radial power distribution with flat ($\pm 10\%$) power. The reactor has a central coolant-return duct with $V_p/V_c = 0.20$. The fuel burnup is 0.02. The side-reflector thickness of 2.0 cm corresponds to the 10,000-hour position.

calculations is depicted in Fig. 38 and Tables XXI and XXII. This is certainly not an exact representation of the end regions, but it should be a better approximation than those made previously with $\Delta k(ER) = 0.03$. The radius used in the axial calculations was not the actual core radius, but an equivalent dimension selected to produce the same radial leakage

as calculated in the radial ZOOM calculations.

The plenum will probably be hemispherical in the final SPR-6 design. For the one-dimensional model used in the present study, however, this region was represented by a cylinder having a thickness selected to preserve the hemispherical plenum volume in a reactor with a fuel

burnup of 0.02. As a reasonable approximation, this thickness was also used for reactors with burnups of 0.01 and 0.03.

The ZOOM code was used in all calculations with modifications of $c = 1$ according to the 1966 second-quarter report

Fig. 38. SPR-6 representation in axial ZOOM calculations.

Table XXI. SPR-6 dimensions used in axial ZOOM calculations.

Fuel burnup	R^a (cm)	T_1 (cm)	T_2^b (cm)	T_3 (cm)	T_4 (cm)	T_5 (cm)	T_6 (cm)
0.01	33.24	0.635	26.0	1.75	115.08	0.5	30.0
0.02	26.28	0.635	26.0	1.75	91.28	0.5	30.0
0.03	22.84	0.635	26.0	1.75	79.80	0.5	30.0

^aThis is not the actual reactor radius, but an effective radius determined by axial ZOOM calculations to preserve the net radial leakage.

^bAn effective thickness that would preserve the volume of the hemispherical plenum of the reactor with a fuel burnup of 0.02.

Table XXII. Atom densities and volume fractions used in axial ZOOM calculations.

Material	Atom density (10^{24} atoms/cm ³)	Volume fraction by region					
		1	2	3	4	5	6
U^{235}	$(0.03421)e^a$	0.0	0.0	0.0	0.4	0.0	0.0
U^{238}	$(0.03421)(1-e)^a$	0.0	0.0	0.0	0.4	0.0	0.0
Nitrogen	0.03421	0.0	0.0	0.0	0.4	0.0	0.0
Li^7	0.04633	0.0	1.0	0.25	0.3	0.25	0.7
Tungsten	0.04820	1.0	0.0	0.75	0.2	0.75	0.3
Rhenium	0.01586	1.0	0.0	0.75	0.2	0.75	0.3
Void	0.0	0.0	0.0	0.0	0.1	0.0	0.0

^a e = fuel enrichments of 0.37, 0.49, and 0.59, corresponding to reactors with fuel burnups of 0.01, 0.02, and 0.03.

(UCRL-50004-66-2). The axial cylinder option was selected, permitting a detailed axial representation of the reactor (which must be homogeneous in the radial direction). The neutron cross-section set used in ZOOM was the interim R-Division 16-group set.

The axial version of ZOOM permits a detailed description of the reactor in the axial direction with a DB_g^2 term representing radial leakage.^g In the present calculations, an effective radius was chosen that would result in the same radial leakage as that calculated by the radial version of ZOOM for the unreflected reactor with a central coolant-return pipe. The procedure was to describe the reactor accurately in the axial direction, execute a few problems with varying radii, and from a plot of radial leakage versus radius determine the radius which would result in the same leakage as the one computed when the reactor was described radially. The results of this calculation are presented in Table XXIII.

The results of the calculations of end-reflector worth are presented in Table

Table XXIII. Determination of equivalent radii for use in axial ZOOM calculations for the SPR-6 reactor.

Fuel burnup	$R_0 + T_p^a$ (cm)	$L(R)^b$	R^c (cm)
0.01	41.73	0.761	31.67
0.02	33.23	0.894	25.86
0.03	29.13	0.904	23.82

^aRadius of core plus thickness of pressure vessel.

^bNet radial neutron leakage per fission.

^cRadius that, when used in axial ZOOM calculations, results in the leakage in Column No. 3.

XXIV. The effects of adding a 10-cm BeO front reflector were also calculated. No significant change in $\Delta k(ER)$ occurred ($\Delta k \leq 0.0001$), indicating that the end regions effectively decouple the reactor from external end reflection. Note that the worth of the end regions is less than the first estimate [$\Delta k(ER) = 0.03$]. This means that the initial enrichment estimate may have been incorrect.

In the next section, a fuel-enrichment redetermination incorporating the calculated end-reflector worth and a few other refinements is described.

Redetermination of Fuel Enrichment

As observed in the preceding section, the initial fuel-enrichment estimation was probably a little low due to overestimation of the worth of end reflection. In addition to overestimating end-region worth, the worth of the reflector in the open position

Table XXIV. Worth of SPR-6 end regions as determined by axial ZOOM calculations.

Fuel burnup	$\Delta k(ER)$
0.01	0.0055
0.02	0.0090
0.03	0.0101

Table XXV. Determination of approximate open-vane worth.

Fuel burnup	$\Delta k(SR)$	T_r	θ	$\theta \Delta k(SR)$
0.01	0.0882	4.4	0.1007	0.0089
0.02	0.1086	3.4	0.0977	0.0106
0.03	0.1245	3.3	0.1082	0.0135

$[\theta\Delta k(\text{SR})^*]$ was not included in the initial computations of fuel enrichment.

With the above-mentioned corrections, and representing the pressure vessel in the calculations, the fuel enrichment was redetermined with the $c = 1$ version of ZOOM. In this calculation, θ was assumed to be the fraction of the reactor-core surface area still covered by the reflectors when the six vanes were opened to their 90-deg position. Thus,

$$\theta = \frac{6T_r}{2\pi(R_0 + T_p)},$$

where T_r is the reflector thickness, R_0 is the core radius, and T_p is the pressure-vessel thickness.

The results of the determination of $\theta\Delta k(\text{SR})$ are presented in Table XXV. The side-reflector worth $[\Delta k(\text{SR})]$ was taken

*The term $\Delta k(\text{SR})$ is the total side-reflector worth, and θ is the fraction of side-reflector worth that remains when the side reflectors are turned to their fully open position.

from the 1966 fourth-quarter report (UCRL-50004-66-4).

To determine the required fuel enrichment, the desired multiplication constant for the unreflected reactor (k_B) was determined from

$$k_B = 1 - [\theta\Delta k(\text{SR}) + \Delta k(\text{OS}) + \Delta k(\text{ER}) + \Delta k(\text{MR}) + \Delta k(\text{DTF} - \text{ZOOM})],$$

where $\Delta k(\text{OS})$ is the operational-shutdown reactivity margin, $\Delta k(\text{ER})$ is the end-reflection reactivity worth, $\Delta k(\text{MR})$ is the reactivity worth of miscellaneous reflection (external to reactor reflector proper), and $\Delta k(\text{DTF} - \text{ZOOM})$ is the difference between DTF- and ZOOM-calculated reactivities (correction of diffusion theory to transport theory). Then the appropriate enrichment value was calculated. Table XXVI summarizes the enrichment determination.

The calculated axial power profiles given in Figs. 39 through 42 show that the peak-to-average fission density is about

Table XXVI. Redetermination of SPR-6 fuel enrichment.^a

	Fuel burnup		
	0.01	0.02	0.03
$\theta\Delta k(\text{SR})$	0.0089	0.0106	0.0135
$\Delta k(\text{OS})$	0.0200	0.0200	0.0200
$\Delta k(\text{ER})$	0.0055	0.0090	0.0101
$\Delta k(\text{MR})$	0.0100	0.0100	0.0100
$\Delta k(\text{DTF} - \text{ZOOM})$	0.0072	0.0119	0.0158
Total	0.0516	0.0615	0.0694
k_B	0.9484	0.9385	0.9306
e	0.38 (0.365 ^b)	0.50 (0.49 ^b)	0.60 (0.59 ^b)

^aCalculated with the radial $c = 1$ ZOOM code and with end leakage from axial ZOOM calculations. The reactor has a central coolant-return pipe with $V_p/V_c = 0.2$, nominal volume fractions, and a length/diameter ratio of 1.4.

^bValues reported in the 1966 fourth-quarter report (UCRL-50004-66-4).

Fig. 39. Axial power-density profile (fuel burnup = 0.01).

Fig. 40. Axial power-density profile (fuel burnup = 0.02).

Fig. 41. Axial power-density profile (fuel burnup = 0.03).

Fig. 42. Fraction of fissions integrated over neutron energy groups for the SPR-6 reactor with the indicated fuel burnups.

1.4 for all three burnup conditions. Since a flat radial power distribution ($\pm 10\%$) is expected, the peak burnup in the reactor will be greater than the average burnup by a factor of about 1.5.

The integrated fission fraction as a function of neutron energy for the SPR-6 reactor is plotted in Fig. 42. The median energies of neutrons causing fission are listed in Table XXVII. The results displayed in this table update those presented in Table XIX of the 1966 fourth-quarter report (UCRL-50004-66-4).

Table XXVII. Median energy of neutrons causing fission in the SPR-6 reactor with a central coolant-return pipe, nominal volume fractions, no reflectors, and a length/diameter ratio of 1.4.

Fuel burnup	Median fission energy (MeV)
0.01	0.20
0.02	0.27
0.03	0.31

Reactivity Control with Liquids

The concept of controlling reactor neutronics with liquid agents was discussed in the 1967 first-quarter report (UCRL-50004-67-1). Some further general discussion is given here along with calculational results for the SPR-6 reactor.

The uses to which liquid controls can be put consist of the following items:

- Ground safety can be assured by initially filling the primary coolant-loop section in the fueled core with Li^6 , and the remaining volume of the same loop with Li^7 . Prior to reactor startup, and upon heating

of the system by auxiliary means, mixing of the two lithium isotopes takes place and renders the reactor near-critical.

- Trimming reactivity to design conditions in the hot, near-critical state prior to the starting of the reactor can be accomplished, if required, by correcting the lithium enrichment in the primary-loop mixture.
- The magnitude of the geometric effect of temperature on reactivity can be selected, within limits, by a particular concentration of Li^7 in the stagnant lithium. Self-regulation can thus be achieved, and the effect is "near-prompt."
- Operational losses in reactivity due to fuel burnup and fuel swelling during the lifetime of the reactor can be partially compensated for by progressive corrections to the Li^7 concentration in the stagnant lithium and/or by vernier controls (see below).
- Operational shutdown of the reactor in space is readily accomplished by injecting Li^6 into tubular voids (i. e., liquid-control circuits) inside the fueled core. Removal of this lithium for restarting the reactor in space is achieved with compressed helium and evaporation.
- Vernier control of the reactor is needed in reactivity amounts of less than ± 1.00 for operational control of the power level. Several possibilities exist for providing this small amount of adjustable reactivity. A liquid vernier mechanism, for

example, might be similar to that for operational shutdown.

Liquid controls have a number of advantages and disadvantages.

- Advantages

1. No moving parts in or near the high-temperature core.
2. Simplicity of heat removal from liquid-control agents.
3. Remote control through valves and pumps at relatively low temperatures behind the radiation shield.
4. Substantial reduction in the shield mass because of the constant shape, and often smaller size, of liquid-controlled reactors.
5. Redundancy of controls through multiple independently controlled liquid-control circuits, which are analogous to solid control rods.
6. Double usage of coolant and liquid heat-transfer media as control agents.

- Disadvantages

1. The desirability of negative void coefficients for the coolant and some of the liquid heat-transfer media imposes constraints on the Li^7 concentration in the liquid-control circuits. The effect is dependent upon the neutron energy spectrum of each reactor.
2. Liquid controls require the reactor and some of its associated equipment to be above the freezing points of the liquid-control agents, which precludes self-heated reactor startup.

3. Leaks in the membranes separating liquid lithium of different enrichments could have serious reactivity consequences.

Ground Safety

The preflight safety of small, fast reactors to be used in space requires careful attention. In the absence of bulky side reflectors, the fueled core is quite sensitive to neutron return from the environment. Provision must therefore be made to render the reactor substantially subcritical during its assembly and preflight handling. Accidental immersion in water, with the possibility of internal flooding, must be considered.*

In the past, the reactivity reserve for ground safety has often been built into the range of a movable side reflector of beryllium or BeO . This in turn increased the thickness of the side reflector and consequently added considerable mass to the system, especially because of the increase in mass in the radiation shield. The size of the radiation shield is usually dictated by the effective radius of the reactor with the reflector vanes in their open position.

These disadvantages, as well as other related problems, can be eliminated with a novel approach: Preflight ground safety can be assured by initially filling the primary coolant-loop section in the fueled core with Li^6 , and the remaining volume of the same loop with Li^7 . This allocation can be sustained without valves since lithium is solid below 450°K . Prior to

*This safety aspect was discussed, and calculational results given, in the 1967 second-quarter report, UCRL-50004-67-2.

Fig. 43. k_{eff} as a function of Li^7 enrichment in the SPR-6 reactor.

reactor startup, and upon heating of the system by auxiliary means, a one-time irreversible mixing of the two lithium isotopes takes place. This in effect removes Li^6 from the fueled core, replaces it with the average resulting mixture of the two isotopes, and renders the reactor near-critical.

Calculations show that initially filling the primary coolant-loop section in the fueled core with Li^6 would suppress reactivity by about $\Delta k = 0.22$, which is far beyond the requirements of ground safety (see Fig. 43). This implies that other combinations of Li^6 and Li^7 could be used to initially fill the primary coolant-loop sections. A proper choice must be made in light of two constraints. First, the final enrichment of the lithium coolant is not arbitrary. Operational safety requires the reactor to become subcritical if the primary coolant loop ruptures and all fluids are lost. For the SPR-6 system under study, enrichment of the lithium coolant must be equal to or greater than 7% Li^6 . Second, the initial Li^7

concentration in the coolant loop outside the core should be such that an excessive positive reactivity change is prevented during the early stages of melting and mixing in the coolant. At that time, coolant with a high Li^7 enrichment could enter and temporarily occupy the whole fueled core. This in turn could cause a reactivity surge beyond the control capability of the operational shutdown reserves ($\Delta k = 0.02$) and the vernier controls ($\Delta k = 0.007$) (i. e., a surge in excess of $\Delta k = 0.027$).

Assuming that 10% of the primary coolant is contained in the fueled core at all times, it can be shown that initially filling the core with 75% Li^7 , and the remaining section of the coolant loop with 95% Li^7 , yields a final mixture of 93% Li^7 and produces the desired reactivity effect for ground safety. Likewise, the temporary surge in k_{eff} during melting does not exceed $\Delta k = 0.01$ and is well within the capability of the remaining controls.

Selection of a Suitable Geometric Temperature Effect

The SPR-6 design utilizes stagnant or near-stagnant lithium between the fuel and its cladding. When the reactor is heated to operating temperatures, two effects take place and govern the presence of stagnant lithium in the core. First, the density of the lithium changes from 0.52 to 0.42 g/cm³, and second, stagnant lithium is displaced from the fueled core because the thermal expansion coefficient of UN is nearly twice that of tungsten. The latter effect is "nearly prompt" because of the stiff coupling of the lithium to the fuel matrix.

It is easy to determine the particular mixture of Li⁶ and Li⁷ in the stagnant lithium that will yield a desired negative temperature effect for power stability. The noteworthy item here is not that the temperature effect of the system is an unchangeable de facto response of a particular reactor, but that it can be selected at will, within limits, with a proper isotopic mixture in the stagnant lithium.

Corrections to the Li⁷ concentration in the near-stagnant lithium can be made during the lifetime of the reactor to compensate for time-dependent changes in the dynamic response of the overall system. The quantities of Li⁶ and Li⁷ needed for this purpose are small.

OPTIMIZATION STUDIES OF OUT-OF-CORE THERMIONIC SYSTEMS (SPR-5 AND SPR-8)

A preliminary design of a heat-pipe-cooled, out-of-core thermionic system was discussed in the 1966 fourth-quarter report (UCRL-50004-66-4). As noted

there, all system parameters were assigned what were believed to be reasonable, near-optimum values but what were otherwise arbitrary (that is, the system was not optimized). In this report, the results of optimization studies are presented. A salient result of the optimization procedure is the indication of a solid heat-transfer medium (BeO) between the shield heat pipes and the diode emitter in place of the radiant heat-transfer mechanism employed previously. In the studies, simple but physically reasonable models were used to describe the essential components in the system. The elementary models were used to permit a computer to make rapid survey calculations of system configurations and specifications that yield minimum specific mass. The computer uses a Monte Carlo procedure to determine the optimum set of values for the following parameters:

- θ — the half angle of the shield /radiator flare,
- V_f — the core volume fraction occupied by fuel,
- T_c — the diode-collector temperature (assumed to be equal to the radiator temperature), and
- ΔT — the temperature drop sustained between the reactor core and the diode emitter.

The system specific mass is determined from these values and from specified values of electric power, reactor temperature, and shield attenuation. Also, a variety of constraints are imposed. Criticality, for instance, is an intrinsic condition throughout, and the fuel burnup is limited to 0.03. The configuration of the out-of-core thermionic

system consists, in linear succession, of the core, the shield, the heat exchanger (from the core heat pipes to the emitter heat pipes), the diode array, and the radiator. These components are cylindrically symmetric.

The system model and most of the calculations are based on the system and the equations developed for the SPR-5 and reported in the 1966 fourth-quarter report (UCRL-50004-66-4). The configuration of the SPR-5 is shown in Fig. 44, and

definitions of some of the basic geometric variables are given in Fig. 45.

The primary task performed by the optimization code is to determine, for a given set of input data (e. g., reactor temperature, desired output voltage, and electrical power output), the minimum specific mass consistent with internal and input constraints. A secondary task is to calculate the interesting parameters of the optimized system.

Fig. 44. SPR-5 system configuration.

Fig. 45. Definition of basic geometric variables for the SPR-5.

During the optimization studies, certain parameters were arbitrarily held constant. The fuel and core structure were always UN and tungsten. An output voltage of 400 V dc was required. The sensitivity of

the system specific mass (α^*) was evaluated for some model constants and should be

α^* = total system mass/electric power output.

evaluated for all input assumptions. However, it is thought that no significant changes in conclusions regarding desirable parameter regions are likely to result from reasonable variations in the model constants. The absolute changes in α are expected to be significant, though not major, and they can be deliberately ignored in keeping with the spirit of these optimization studies (*viz.*, the absolute magnitudes are approximate, but the trends and optima are generally reliable).

Figure 46 shows α as it depends on power output. The figure indicates that interesting values of α can be obtained from tens of kilowatts to 10 MW. Systems at two electrical power levels—a 300-kWe system designated SPR-8 and a 10-MWe system designated SPR-5—are considered below. The SPR-5 and SPR-8 systems have virtually the same values of α . The effect of three orders of magnitude of radiation attenuation is also shown in Fig. 46 as it corresponds to shields rated for manned or unmanned spacecraft.

Figures 47 and 48 show the variation of α with reactor temperature for the SPR-5 (man-rated) and the SPR-8 (unman-rated). For each of the two systems, four combinations of materials were considered. The use of either lithium or silver as the working fluid in the reactor-core heat pipes was treated as a possibility. It is clear that the temperature requirements placed on materials can be made hundreds of degrees less stringent by choosing lithium over silver. Furthermore, a heat exchanger that uses conduction through BeO is superior to a vacuum-gap radiant heat exchanger. This conduction heat exchanger is required to electrically insulate the diode-emitter heat pipes from each other in the out-of-core concept. Even when the electrical resistivity is assumed to be an order of magnitude poorer than the LRL-measured values used here, α is raised by only 10%. Radiation degradation should not be significant since these insulators are not in the core.

Fig. 46. System specific mass versus electric power level.

On the basis of the information shown in these figures, the SPR-5 and SPR-8 systems being studied are considered to use tungsten and lithium for the reactor-core heat pipes, to use BeO as the insulation between the diode-emitter heat pipes and shield heat pipes, and to operate in the vicinity of 1800°K. These materials and temperatures are fortunate choices from the viewpoint of technology readiness, for they make it possible to use the results of Rankine-cycle development work being performed at LRL.

Figure 49 shows that the maximum diode-array power density implicit in

Figs. 46, 47, and 48 was chosen at such a point that a further increase in its value does not significantly decrease α .

Tables XXVIII and XXIX show the specifications and the performance of the SPR-5 and the SPR-8. Both the radial and the axial heat fluxes in the reactor heat pipes are higher than the ones commonly encountered. Radial heat-flux limits are often estimated on the basis of the separation of a liquid film from a solid heat-source surface, for which the recognized values for sodium and potassium are in excess of 10^2 W/cm^2 . On the same basis, the properties of lithium indicate

Fig. 47. System specific mass versus reactor heat-pipe temperature for lithium and silver heat-pipe fluids in the man-rated SPR-5 (radiant or BeO conductive heat transfer).

Fig. 48. System specific mass versus reactor heat-pipe temperature for lithium and silver heat-pipe fluids in the unman-rated SPR-8 (radiant or BeO conductive heat transfer).

Fig. 49. System specific mass versus diode-array power density.

Table XXVIII. Specifications and performance.

	SPR-5	SPR-8
Fuel		
Composition	UN	UN
Enrichment	35%	100%
Burnup	3%	2.8%
Volume fraction	73%	76%
Core structure		
Composition	Tungsten	Tungsten
Volume fraction	5%	4%
Core coolant		
Composition	Lithium	Lithium
Temperature	1800°K	1800°K
Core geometry		
Radius	59 cm	12 cm
Length	20 cm	18 cm
Shield		
Composition	BeO	BeO
Length	149 cm	70 cm
Maximum radius	113 cm	20 cm
Flare half angle	15 deg	1.5 deg
Nonheat-pipe fraction	49%	80%
Emitter		
Insulation	BeO	BeO
Temperature	1790°K	1790°K
Collector temperature	1193°K	1275°K
Efficiency		
Diode	16%	13.8%
System	15.6%	13.4%
Heat pipe		
Core axial flux	26 kW/cm ²	26 kW/cm ²
Core radial flux	330 W/cm ²	366 W/cm ²
Shield axial flux	9 kW/cm ²	14 kW/cm ²
Diode-array power density	250 W/cm ²	250 W/cm ²

Table XXIX. Specific mass.

	SPR-5 (10 MWe) (kg/kWe)	SPR-8 (300 kWe) (kg/kWe)
Reactor	0.24	0.29
Reactor heat exchanger	0.01	0.02
Shield	1.31 (man-rated)	0.78 (unman-rated)
Shield heat exchanger	0.03	0.03
Diodes	1.14	1.14
Radiator	1.07	0.97
Total	3.8	3.2

that radial fluxes approaching 10^3 W/cm^2 can be attained. The axial heat flux quoted (26 kW/cm^2) is optimistic but is not unreasonable.

Component Review

Neutronic Reflector and Control System

Space has been left in the system geometry for side and end reflectors (and thus a reflector control system). Nominal thicknesses of 5 cm have been used for each of these regions. These thicknesses influence the shield flare angle and dependent system-mass values. However, in the system-optimization code, the mass of the reflector regions is ignored. The criticality condition is based on a bare core with $k_{\text{eff}} = 0.9$, and neutron leakage for adequate reflector control is not otherwise an explicit constraint.

Heat Pipes

Axial heat-pipe fluxes are computed in the system-optimization calculations from an expression derived at LRL and based on pressure-drop expressions from LASL.³⁶ This expression results from selecting an effective capillary radius and vapor-passage radius to yield a maximum axial flux, which is given as a function of such basic parameters as heat of vaporization and liquid and vapor density of the working fluid, heat-pipe radius and length, and wick dimensions. Heat pipes 1 cm in diam are used. Wall thickness is determined in terms of stress set by the creep strength of tungsten, except that a fabricability minimum of 0.5 mm is required. (Doubling this minimum thickness to 1 mm increases the system specific mass by about 6%.)

Diode Array

Figures 50 and 51 show a schematic representation of the proposed diode-array configuration. The heat-flow path starts where the heat passes from the shield heat exchanger through the BeO insulator into the emitter heat pipe. (The shield heat exchanger keeps all the diode emitters at the same temperature.) The heat flows axially down the emitter heat pipe and then passes radially through a gap. It enters the reentrant-cavity collector heat pipe and flows axially down this pipe. It then passes into a collector heat exchanger, and thence to the radiator. (The collector heat exchanger keeps all the diode collectors at the same temperature.)

Electrical power is removed from the diode along a continuous ribbon that connects the diodes in series. The ribbon is surrounded by insulating material (also Al_2O_3) as it passes through the collector heat pipe. The seal and support for this insulator are provided by an expandable connection to the collector heat pipe.

The factor limiting diode length in previously considered cases has been the electrical resistance along the diode emitter and collector. The ribbon-connection scheme eliminates axial current flow along the emitter and the collector, and the diode length is limited only by the heat-pipe capacity or by mechanical considerations. The questionable mechanical stability of this collector configuration must be studied.

Two annular insulators are shown in Fig. 50. The functions of the insulators have been separated in the hope that this would be a more realizable system. One of the insulators provides a vapor seal

Fig. 50. Proposed diode-array configuration.

Fig. 51. Details of the diode array.

for the cesium vapor, the other acts as a spacer to fix the interelectrode gap. There is an additional insulator at the end of the emitter heat pipe. This insulator centers the emitter pipe in the collector cavity; it is not a seal.

Also shown in Fig. 51 is a scheme to make parallel connections between the diodes. This is done with a ribbon that sections the collector heat pipe (which could represent redundancy) and passes into an adjacent collector.

The system-optimization code uses a parameter that measures the ratio of electrical power output to diode-array cross-sectional area. Figure 52 shows the end-on diode-array power density proposed with the following assumptions (λ is the axial heat transport per unit area):

Fig. 52. End-on power density versus diode length for two emitter radii.

- Emitter heat pipe $\lambda = 25 \text{ kW/cm}^2$ (this is not limiting).
- Collector heat pipe $\lambda = 5 \text{ kW/cm}^2$.
- Emitter temperature = 1800°K .
- Collector temperature = 1200°K .
- Maximum radial heat flow = 100 W/cm^2 .
- Emitter electric power density = 20 W/cm^2 .
- Geometric parameters
 - Wall thickness = 0.010 in.
 - Gap width = 0.010 in.
 - Wick thickness = 0.040 in.

Figure 52 shows the diode length required to obtain the desired power density for both hexagonal and square diode packing.

The emitter heat pipe can carry enough power for the diode length to be 100 times its radius. Therefore, these results show that the end-on power density of 250 W/cm^2 assumed in the system-optimization code can probably be attained. However, such a power density would

require the diodes either to be stacked in layers normal to the system axis or to be very long. The latter situation could cause problems with high electric current density.

The diode efficiency assumed for this work is the product of the value shown in Fig. 53 for a specified emitter temperature (T_E) times a modifying factor $[f(T_C)]$. The modifying factor is unity for $T_C \leq 2/3 T_E$, and it decreases linearly at higher values of T_C until it becomes zero when the collector and emitter temperatures are equal. This prescription for diode efficiency was adapted from a RAND study³⁷ and is consistent with state-of-the-art literature values.

The mass of the diode array is estimated as the sum of 1) the collector and emitter surface mass, which is dependent only on the surface thicknesses (established as heat-pipe thicknesses) and the emitter power density, and 2) a structure

Fig. 53. Maximum diode efficiency versus emitter temperature.

mass proportional to the total electric power output of the system (P_e). The diode power density is shown in Fig. 54 as a function of emitter temperature. The use of Fig. 54 with Fig. 53 introduces a degree of optimism because the efficiency and power-density values shown in the graphs are not actually obtained under the same conditions. The constant of proportionality between the structure mass and the electric power output of the diode array is 0.8 kg/kWe.

Materials

In these system-optimization studies, the creep strength of tungsten at various temperatures is based on the values for pure tungsten shown in Fig. 55. If the properties of the tungsten "goal" alloy* are used instead, the values of α are unchanged below about 1900°K but do not

*These properties are based on a 10-year projection of development status according to LRL's Rankine-cycle studies.

display the rapid rise with increasing temperature above 2000°K that appears in Figs. 47 and 48. In fact, α continues to fall during a temperature rise of several hundred degrees, which implies a considerable potential for upgrading performance in later generations.

The properties of BeO are of major importance in this system-optimization work. Its thermal conductivity has been fixed at a conservative value of 0.15 W/cm-°C. The electrical-conductivity data being used are LRL values³⁸ (see Fig. 56). The published data generally give too high an

Fig. 54. Diode electric power density versus emitter temperature at the optimum collector temperature.

Fig. 55. Strength representation for tungsten and the tungsten "goal" alloy. In this Larson-Miller plot of low-strain creep data, T is the test temperature ($^{\circ}\text{K}$), t is the test time (hours), and $C = 16.63$.

electrical conductivity at high temperatures (an impurity effect, not intrinsic conductivity). The LRL conductivities for pure BeO are more than an order of magnitude lower than those published in the literature or those obtained at LRL for less-pure BeO (about 200 ppm of metallic impurities). Furthermore, it is felt that the intrinsic conductivity of BeO is still not being measured. Further purification should

give even lower conductivities. Alternatively, doping BeO with lithium should reduce the cation vacancy concentration and thus reduce the electrical conductivity.

At the high temperatures and long life-time that are required, there is a tendency for the BeO insulation to vaporize and transport to a cooler region. It must be established that this loss does not impair

Fig. 56. BeO resistivity versus temperature.

performance. If BeO is used in a configuration like that shown in Fig. 57, vaporization will occur from the exposed face and the surface will recede. The upper limit at which this recession will take place can be established by means of the following equation, which relates matter loss to the vapor pressure, temperature, and molecular weight of the volatile gas species:

$$\text{flux (moles/cm}^2\text{-sec)} = \frac{44P}{\sqrt{MT}}, \quad (6)$$

where P is the vapor pressure in atmospheres, M is the molecular weight of the vaporizing species, and T is the temperature in $^{\circ}\text{K}$. This equation truly gives an upper limit to the loss since it assumes that every molecule leaving the surface is

lost and that there are no kinetic hindrances to the vaporization process.

If this expression is applied to BeO, using vapor-pressure data from the literature, a density of 3.00 g/cc, and $M = 75$ (Be_3O_3), the erosion after 10^4 hours at 1800 $^{\circ}\text{K}$ is

$$\begin{aligned} \text{erosion (cm)} &= \frac{(44)(2 \times 10^{-10})}{\sqrt{75 \times 1800}} \frac{(75)}{(3)} \\ &\times (3.6 \times 10^7) = 0.02 \text{ cm}, \quad (7) \end{aligned}$$

which would certainly seem to be tolerable. Since BeO vaporizes congruently (that is, the material remaining has the same composition as the original), the electrical resistance should not change as the material volatilizes.

The emitter/collector seal, operating near the collector temperature of 1200 $^{\circ}\text{K}$, is comparable to those being considered for in-core applications. At this relatively low temperature, the insulator need not be a pure, exceedingly refractory material, and thus it can be chosen for its electrical properties as well as its ability to bond to metals.

Radiator

In the system-optimization work, waste heat is dumped from a radiant surface

Fig. 57. Schematic location of BeO emitter-heat-pipe insulators.

operating at the diode-collector temperature (T_c). (The heat-pipe temperature drop is assumed to be negligible.) This surface has an unspecified configuration but is subject to containment within the cone defined by the shield flare half angle (θ). The radiator, then, appears in the system optimization only to the extent that it contributes a mass that is assumed to be proportional to the radiating surface, which in turn is proportional to the radiated power divided by the fourth power of the collector temperature (T_c^4). The constant of proportionality is such that at 1200°K, for example, the radiator weighs 0.2 kg/kWe. If the system is 15% efficient, the specific mass of that radiator (at 1200°K) is about 1 kg/kWe.

If very small values of θ are determined to be optimum by the system-optimization procedure, it may turn out that the radiator must be impractically long to provide sufficient radiating area for dumping the waste heat. The penalty incurred by forcing θ from 1.5 to 5 deg in order to alleviate this problem is a 10% increase in the total system specific mass in the case of the SPR-8.

A variety of heat-pipe-radiator configurations can be envisaged. One is an axially symmetric body of the cellular type suggested by LASL.³⁹ An armored radiator of this kind is discussed in the 1966 fourth-quarter report (UCRL-50004-66-4) and is estimated there at 0.5 kg/kWe for 1250°K. A flat, rather than axially symmetric, radiator is also a possibility.

For the SPR-5, sodium is presently believed to be superior to lithium as the working fluid in the radiator heat pipes because of its more appropriate vapor density at 1200°K (the pressure is 1.5 bars for sodium as opposed to 2×10^{-2} bar for lithium). The radiator can be protected

from meteoroids by beryllium or graphite armor bonded to niobium heat-pipe walls.

Shield

The shield length is calculated from a shield composition consisting of BeO homogenized with the tungsten and lithium heat-pipe materials. A simple exponential attenuation based on 1-group effective-removal cross sections for neutrons is used. A total attenuation of 10^7 is required for man-rated SPR-5 shields, which corresponds to a 20,000-hour dose of about 17 rem and leaves a margin for an additional natural dose (e.g., from solar flares).^{*} An attenuation of 10^4 is required for unman-rated SPR-5 shields. Due to the time scale under which the optimization work was carried out, the same attenuation requirements were imposed for all the power levels surveyed (including the SPR-8) instead of requiring the same dose at the payload at all power levels. This is progressively conservative as the power from the SPR-5 decreases since the attenuations mentioned yield the proper payload doses for the SPR-5. In fact, unreviewed data indicate that the SPR-8 has a value for α of about 10% less for the constant-dose cases than for the constant-attenuation cases. At 30 kWe, the same data indicate a reduction in α of roughly 25% for the unmanned system.

To test the adequacy of the shield-length calculations, in which a homogenized BeO heat-pipe/shield region was assumed, the SPR-5 system was computed explicitly by LRL's GEISHA shield code and included

^{*}For a further discussion of dosage limits, see p. 48ff in the 1966 third-quarter report, UCRL-50004-66-3.

gamma-ray attenuation (see p. 73). The results for shield mass agreed to within 10%.

In actuality, the heat-pipe/shield structure is not homogeneous. If the heat pipes traverse the shield in parallel straight-line paths, the SPR-5 shield provides at least four orders of magnitude less shielding than is required for man-rating. This is due to neutron streaming through the heat-pipe vapor passages. A rough estimate of the shielding required is given below, where the total attenuation demanded of the system is 2×10^{-10} , which is consistent with the GEISHA calculation and of which 10^{-7} is accomplished by the shield proper. If the shield at the reactor is eliminated and all shielding is accomplished at the payload, the shield mass rises by more than one order of magnitude. Therefore, some offsetting or helixing of the heat pipes that penetrate the shield appears to be a necessity. The number of offsets required is not susceptible to quick estimation, but it is believed to be reasonable (probably at least one order of magnitude of attenuation per offset).

Consider an infinitely broad slab shield having a thickness T , an attenuation coefficient μ , and an isotropic surface source

Fig. 58. Schematic of shield calculation (with hole).

on one side. In this shield, a small cylindrical hole having a radius a has been drilled (see Fig. 58). It is desired to find the flux at a distance D from the isotropic source in a direction through the shield. The flux can be represented as the sum of two terms:

$$\Phi(D, \mu, T, a, b) = \Phi_0(D, \mu, T) + \Delta\Phi(D, \mu, T, a, b), \quad (8)$$

where $\Phi_0(D, \mu, T)$ is the flux that would exist if no hole were present, and $\Delta\Phi(D, \mu, T, a, b)$ is the correction to the flux due to the presence of the hole.

For an infinite slab shield with an isotropic surface source of S_A ,

$$\Phi_0(D, \mu, T) = 2\pi \int_0^\infty r dr \frac{S_A e^{-\mu T(\rho/D)}}{4\pi\rho^2}, \quad (9)$$

where $\rho^2 = r^2 + D^2$.

This yields

$$\Phi_0(D, \mu, T) = \frac{S_A}{2} E_1(\mu T). \quad (10)$$

Using the same relationships,

$$\Delta\Phi = \int_0^{2\pi} d\theta \int_0^\infty r dr \frac{S_A}{4\pi\rho^2} \times [e^{-\mu\bar{\rho}} - e^{-\mu T(\rho/D)}], \quad (11)$$

where $\rho^2 = b^2 - 2br \cos \theta + r^2 + D^2$, and $\bar{\mu\rho} = \int_0^\rho \mu(S) dS$. Here S is a point along the line marked ρ in Fig. 58 at which μ is evaluated in the integration. Since μ is a constant value in the shield material and is zero in the hole or in the volume behind the shield, $\bar{\mu\rho}$ is really just μ times the

path length in the shield. Given the position of dA and the detector, this length can easily be found from geometrical considerations. The integral expression for $\Delta\Phi$ can then be evaluated by numerical methods.

It is convenient to represent $\Delta\Phi$ as the product of two terms:

$$\Delta\Phi(D, \mu, T, a, b) = f(D, \mu, T, a, b) \cdot \Delta\Phi(D, a), \quad (12)$$

where $\Delta\Phi(D, a)$ is the correction necessary for the case in which $b = 0$, and $f(D, \mu, T, a, b)$ provides the dependence upon b . For the case in which $a \ll D$ and $e^{-\mu T} \ll 1$, then

$$\Delta\Phi(D, a) = \frac{S_A}{4} (a/D)^2 \quad (13)$$

and

$$f(D, \mu, T, a, b) = \frac{\Delta\Phi(D, \mu, T, a, b)}{\frac{S_A}{4} (a/D)^2}. \quad (14)$$

Figure 59 presents values of f for the following parameters:

$\mu = 0.149 \text{ cm}^{-1}$ (BeO fast-neutron removal).

$T = a$ variable.

$a = 0.5 \text{ cm}$.

$D = 50 \text{ m}$.

The arrows on Fig. 59 indicate the value of b at which it is no longer possible to see directly through the hole.

So far, only one hole has been considered in the shield. The general SPR-5 system has many, many holes. If it is assumed that these holes do not interact with each other, then the flux can be written as

$$\Phi(D, \mu, T, a, N) = \Phi_0(D, \mu, T) + \sum_N \Delta\Phi(D, \mu, T, a, b_n), \quad (15)$$

where N is the number of holes and b_n is

the distance between the hole and the detector's projection on the shield surface. Using the relations above,

$$\Phi(D, \mu, T, a, N) = \Phi_0(D, \mu, T) + \frac{S_A}{4} (a/D)^2 \sum_N f(D, \mu, T, a, b_n). \quad (16)$$

For a large number of equally spaced holes, an average value of f can be defined as

$$\bar{f} = \frac{\int_0^R r dr f(D, \mu, T, a, r)}{\int_0^R r dr}, \quad (17)$$

where R is the shield's outer radius. Then,

$$\sum_N f(D, \mu, T, a, b_n) \approx N\bar{f}, \quad (18)$$

but

$$N = \frac{2 \int_0^R r dr}{a^2} V_h, \quad (19)$$

where V_h is the volume fraction of the holes in the shield. This gives

$$\Phi(D, \mu, T, a, N) = \frac{S_A}{2} E_1(\mu T) + \frac{S_A}{2} \frac{\int_0^R r dr f(D, \mu, T, a, r)}{D^2} V_h. \quad (20)$$

Figure 60 indicates the fluxes due to a solid shield and to a shield containing cylindrical holes with $V_h = 50\%$. The section of the shield containing the holes was assumed to have a radius of 1 m, although this value does not alter the results for shield thicknesses greater than five mean free paths. The parameters used to obtain Fig. 59 also apply here. The shield attenuation is approximately twice the value of the flux per unit source shown in Fig. 60.

Fig. 59. Single-hole flux-correction factor (f) as a function of detector distance (b) from the hole axis.

Reactor Core

The core cross-sectional area—and hence radius—is determined from the total required heat-pipe frontal area and the ratio of fuel to heat-pipe volume. The heat-pipe area is determined from considerations of electric power, system efficiency, and heat-pipe performance; the associated fuel volume fraction (V_f) is an optimizable parameter. It was found that the system specific mass is extremely insensitive to the fuel volume fraction in the

Fig. 60. Transmitted flux versus thickness.

SPR-5. The core length is then determined as required either from the maximum allowable burnup (arbitrarily fixed at 0.03) or from criticality requirements. The criticality is determined from 1-group calculations* developed for reactor surveys. A value of 0.9 is arbitrarily required for the start-of-life k_{eff} in the bare core in order to leave an adequate margin for control.

*See p. 17ff in the 1966 third-quarter report, UCRL-50004-66-3.

Radiation Effects and Shielding

GEISHA SHIELDING CALCULATIONS

The GEISHA-II computer code was written to perform parametric surveys that are useful in designing shields and

reactors for space-power systems. It uses a theory that is simple enough to hold the required calculation time down to a reasonably small time interval, but that is sufficiently rigorous for preliminary

designs. Neutron fluxes are calculated with 1-group removal theory modified by the Albert-Welton method for hydrogen.⁴⁰ Six gamma energy groups with the appropriate build-up factors are used to calculate the gamma dose and the heating rates. Secondary gamma production is included by relating the number of neutrons removed within a component to the number of capture gammas produced. The code is able to vary the thickness of the shield in order to achieve a desired dose rate at the payload, and to vary the shield position to ensure that its maximum temperature is below a specified value.

The code itself is composed of a series of subroutines, each of which performs a specific part of the shielding calculation. The code was constructed in this way not only for the sake of convenience, but also to allow future changes in the system geometry to be made easily. It is expected

that such changes will occur and that additional subroutines describing a more complete shielding model will be necessary. Allowances for coolant activation, the thickness of the shield's wings, and streaming paths through the shield are examples of possible additions. The following sections describe in detail the model now in use and the operations performed in the code.

Geometry

The geometry considered in the GEISHA-II code is shown in Fig. 61. Each of the eight parts of the assumed system is labeled in this figure. The main shield is considered to be a frustum of the cone that forms a perfect shadow between the entire reactor assembly and the payload. Its inside radius is given by

$$R_{\min} = R_r + (R_p - R_r) \left(\frac{L_s}{L} \right) \quad (21)$$

Fig. 61. Geometry of GEISHA calculations.

Fig. 62. Point flux calculation.

and its outside radius is given by

$$R_{\max} = R_r + (R_p - R_r) \left(\frac{L_s + T_s}{L} \right), \quad (22)$$

where R_r is the reactor radius (core plus side reflector), R_p is the radius of the payload, L is the total system length (i.e., the length from the outside edge of the forward end reflector to the payload), L_s is the length from the outside edge of the forward end reflector to the shield face closest to the reactor, and T_s is the thickness of the shield.

Neutron-Flux Calculation

The neutron flux at a point outside of the core but on the system's centerline is

calculated by assuming a uniform source throughout the core and making use of the usual point kernel:

$$\phi = \int_0^{2\pi} d\psi \int_0^L dz \int_0^R r dr \frac{S_v}{4\pi\rho^2} e^{-\bar{\mu}\rho} \quad (23)$$

where ϕ is the neutron flux,

$$\bar{\mu}\rho = \left(\sum_i t_i \mu_i + \mu_c z \right) \sec \theta = X \sec \theta, \quad \mu \text{ is}$$

the macroscopic neutron-removal cross section, $\rho = (D + z) \sec \theta$, $r = (D + z) \tan \theta$, and ψ is the azimuthal angle (not shown in Fig. 62, where the remaining quantities are defined). The value of the source per unit volume (S_v) is obtained from the

reactor's power (P) and the number of neutrons emitted per fission (ν):

$$S_v = \frac{(P)(3.12 \times 10^{16} \text{ fissions/sec-MW})(\nu)}{(\pi R^2 L)_{\text{core}}} \quad (24)$$

The ψ dependence can easily be eliminated and the r dependence removed by converting to θ as the independent variable, then substituting $q = X \sec \theta$ and integrating. The result is

$$\phi = \frac{S_v}{2} \int_0^L dz \left[E_1(X) - E_1(X \sec \theta_m) \right], \quad (25)$$

where $\sec \theta_m = \left[(D+z)^2 + R^2 \right]^{1/2} / (D+z)$

and $E_n(b) = b^{n-1} \int_b^\infty (e^{-t}/t^n) dt$. This

solution is obtained by numerically evaluating the integral by means of Simpson's rule.

Neutron currents throughout the system are desired in order to evaluate the

secondary gamma production. Two methods are used to obtain the currents. The first finds the current on the centerline of the system only, the second finds an average value across the face of a component.

The first method involves the integration of the expression

$$J = \int_0^{2\pi} d\psi \int_0^L dz \int_0^R r dr \frac{S_v}{4\pi\rho^2} \cos \theta e^{-\mu\rho}. \quad (26)$$

The terms in this equation are defined in Fig. 62. This results in a solution similar to that for the flux:

$$J = \frac{S_v}{2} \int_0^L dz \left[E_2(X) - \frac{E_2(X \sec \theta_m)}{\sec \theta_m} \right]. \quad (27)$$

As before, the integration is performed numerically.

The second method produces the integral of the current over the surface of a disk centered on the system's centerline

Fig. 63. Average current calculation.

(see Fig. 63). The current at any point on this disk is given by Eq. (26) with ρ redefined as

$$\rho = \sqrt{(D+z)^2 + a^2}. \quad (28)$$

Integrating over the entire surface of the disk gives

$$\begin{aligned} \bar{J}A_{\text{disk}} &= \int J dA_{\text{disk}} = \int_0^{2\pi} d\psi \int_0^L dz \\ &\times \int_0^R r dr \int_0^{2\pi} d\alpha \int_0^{a_{\text{max}}} da \\ &\times \left(\frac{S_v}{4\pi\rho^2} \cos \theta e^{-\mu\rho} \right). \end{aligned} \quad (29)$$

The quantity a_{max} defines the maximum value of a that can be taken without being off the disk:

$$a_{\text{max}} = -r \cos \alpha + \left[R_{\text{disk}}^2 - r^2(1 - \cos^2 \alpha) \right]^{1/2}. \quad (30)$$

The current expression can be reduced to

$$\begin{aligned} \bar{J}A_{\text{disk}} &= S_v \int_0^R r dr \int_0^L dz \int_0^\pi d\alpha \\ &\times \left[E_2(X) - \frac{E_2(X \sec \theta_m)}{\sec \theta_m} \right], \end{aligned} \quad (31)$$

where $X \equiv \sum_i \mu_i t_i + \mu_c z$ and

$$\sec \theta_m = \left[(D+z)^2 + a_{\text{max}}^2 \right]^{1/2} / (D+z).$$

This triple integration is again performed numerically within the GEISHA code. Due to the length of time required to perform this calculation, the average value of current is found only for the front and rear surfaces of the main shield.

At other points within the system, the calculated current is multiplied by the ratio of the average surface current to the centerline current on the main shield surface nearest to the points in order to obtain an average internal current.

The second method makes some generalizations in the geometry of the system by extending the centerline materials outward to (effectively) infinity. It therefore neglects the change of materials from the core to the side reflector and from the aft reflector to the side reflector. These errors should be very small for most realistic systems (see Fig. 64).

Fig. 64. Actual geometry contrasted with the model assumed for calculation purposes. The disc size is shown larger than normal to emphasize errors.

Core Gamma-Flux Calculation

In the neutron calculation, once a neutron is "removed" it is forgotten as far as flux and dose rates are concerned. This rather violent assumption does not really produce bad results since the biological effectiveness of neutrons decreases rapidly with decreases in energy. For gamma rays, however, this is not true. For this reason, simple point kernels are modified with a buildup factor:

$$\phi_{\text{pt}} = \frac{S}{4\pi\rho^2} e^{-\mu\rho} B(\mu\rho). \quad (32)$$

The buildup factor is generally obtained from exact calculations that include the down-scattering of gamma rays; it is a function of initial gamma energy as well as the material. In general, it is given only for an infinite homogeneous material. Many forms of the buildup factor have been given, but for convenience the Taylor form⁴¹ is used here:

$$B(\overline{\mu\rho}) = A e^{\overline{\alpha\mu\rho}} + (1 - A) e^{-\overline{\beta\mu\rho}}. \quad (33)$$

Substituting this into Eq. (32) gives

$$\phi_{pt} = \frac{S}{4\pi\rho^2} \left[A e^{-\overline{\mu\rho}(1-\alpha)} + (1 - A) e^{-\overline{\mu\rho}(1+\beta)} \right]. \quad (34)$$

This is simply the weighted sum of two normal kernels, each with slightly altered attenuation coefficients. Only one buildup factor is used for the system. Comparison with Monte Carlo calculations indicates that this factor should be the same as the one for the material immediately in front of the detector if there is a reasonable amount of that material present.⁴²

The solution for the gamma flux outside of the core but on its centerline is obtained in exactly the same way as the neutron flux except that the modified point kernel is included. The solution for the gamma flux on the system centerline, then, is given by

$$\begin{aligned} \phi = \frac{S_v}{2} & \left(A \int_0^L dz \left\{ E_1 \left[(1 - \alpha)X \right] \right. \right. \\ & - E_1 \left[(1 - \alpha)X \sec \theta_m \right] \left. \right\} + (1 - A) \\ & \times \int_0^L dz \left\{ E_1 \left[(1 + \beta)X \right] \right. \end{aligned}$$

$$\left. - E_1 \left[(1 + \beta)X \sec \theta_m \right] \right\} \right). \quad (35)$$

The value of X now represents the sum of the macroscopic gamma cross section and the shielding thickness. The source per unit volume is given by

$$S_v = \frac{(P)(3.12 \times 10^{16} \text{ fissions/sec-MW})(\Gamma)}{(\pi R^2 L)_{\text{core}}}, \quad (36)$$

where Γ is the gamma energy per fission in MeV. The resulting solution for the flux is therefore given in terms of MeV/cm²-sec.

In general, the gamma flux changes its energy spectrum considerably in passing from the core, through a thick shield, and thence to the payload. Therefore, no 1-group set of cross sections would be adequate to represent the spatial and energy dependence of the gamma flux. For this reason, it was decided to conduct the gamma calculations on a 6-group basis. Each group has its own cross sections and buildup factors, and each is a separate calculation. This involves using the flux equation six times instead of just once. It should be noted that since the buildup factor has the effect of increasing the calculated uncollided flux in order to include the effects of scattering and the subsequent loss of energy, the GEISHA-calculated 6-group gamma-flux spectrum is not really representative of the true flux spectrum.

Secondary-Gamma-Flux Calculation

Gamma rays emitted from neutron interactions (secondary gammas) can be very important in calculating both the payload dose rate and the shield heating

rate. The GEISHA code performs a simple but conservative calculation to evaluate their effect.

It is assumed that the total number of gammas (S) produced in one of the system's components has a direct relationship to the number of neutrons "removed" in that component. This number of neutrons is further taken to be the difference between the number of fast neutrons passing into the region and the number passing out:

$$S = C [(\bar{J}A)_{in} - (\bar{J}A)_{out}], \quad (37)$$

where C is a constant number that is the input for each region and also for each gamma energy group; it is given in terms of MeV of gamma energy per neutron removal. The average neutron currents are calculated by the methods already explained. This calculation neglects both the neutrons that exit from the region by passing out of the edges of the region rather than from the back face, and the neutrons that exit from the region after they have been slowed down. If it is possible to estimate what fraction of the incoming neutrons exit from a region's edge, or if it is possible to estimate the fraction of low-energy neutrons that escape from a region, this information can be included in the calculation by making appropriate adjustments in the value of C.

The second assumption made is that the gamma-production rate is constant in the radial direction and varies as $e^{-\Sigma z}$ in the axial direction (Σ is the macroscopic neutron-removal cross section in the given region). This gives a distribution of

$$S_v = S_0 e^{-\Sigma(L-z)}, \quad (38)$$

where S_0 is a normalization factor, L is the length of the region, and z is the axial position forward of the aft surface of the region. The factor S_0 can be evaluated by equating the total source in the region:

$$S = \int S_0 e^{-\Sigma(L-z)} dV = C [(\bar{J}A)_{in} - (\bar{J}A)_{out}], \quad (39)$$

which gives

$$S_0 = \frac{\Sigma C [(\bar{J}A)_{in} - (\bar{J}A)_{out}]}{\pi R^2 (1 - e^{-\Sigma L})}, \quad (40)$$

where R is the region's radius.

Calculation of the flux outside this region that results from the above source distribution within the region is a problem very similar to the core problem. The basic equation for the flux on the center-line can be rewritten by replacing the constant value of S_v with S_0 . For the simple point kernel, the result for points behind the aft surface of the region is

$$\phi = \frac{S_0}{2} \int_0^L e^{-\Sigma(L-z)} dz \left[E_1(X) - E_1(X \sec \theta_m) \right]. \quad (41)$$

For points in front of the forward surface of the region, the solution is similar to Eq. (41) except that the source has its maximum value when $z = 0$, and its minimum value when $z = L$. Making this change in the source description gives

$$\phi = \frac{S_0}{2} \int_0^L e^{-\Sigma z} dz \left[E_1(X) - E_1(X \sec \theta_m) \right]. \quad (42)$$

The proper calculation of gamma rays with buildup factors uses these solutions twice, as explained above.

Payload Dose Rate

The dose rate at the payload is assumed to have six contributors:

1. "Fast" neutrons from the core.
2. Gammas from the core.
3. Secondary gammas from the aft reflector.
4. Secondary gammas from the hot shield.
5. Secondary gammas from the main shield.
6. Secondary gammas from the rear shielding.

The flux from each of these contributors is calculated by the methods explained above. The dose rate is calculated by multiplying the flux times an input conversion factor. The units of the dose rate are determined from these conversion factors and may be chosen to fit the problem at hand. Integrated dose rates are calculated by multiplying the dose rates by the system-operation time.

Main-Shield Heating Rate

The heating rate on the surface of the main shield facing the reactor is also calculated. This is assumed to be the highest rate within the shield, although it may not be in certain special cases. Five items are summed to obtain this rate.

- Neutron heating. This quantity is calculated by multiplying the rate at which neutrons are removed ($\phi\Sigma$) times a factor specifying the energy released at a point due to such removal. This energy term can

represent the kinetic energy given up by a neutron due to its removal, or it can represent the energy of a secondary-particle emission (such as an (n, α) reaction).

- Heating by primary core gammas. This quantity is calculated by multiplying the energy-absorption coefficient times the gamma energy-absorption flux. It is summed over all six gamma groups.
- Heating by secondary gammas from the aft reflector. This is calculated as for the primary gammas.
- Heating by secondary gammas from the hot shield. This is calculated as for the primary gammas.
- Heating by secondary gammas from the main shield. This is calculated as for the primary gammas.

The input values are such that the heating rate is calculated in $\text{MeV}/\text{cm}^3\text{-sec}$. Before it appears in the final printout, this is converted to W/cm^3 .

Maximum Main-Shield Temperature

The temperature distribution throughout the shield is given by

$$k\nabla^2 T = -q(r), \quad (43)$$

where k is the thermal conductivity and $q(r)$ is the heat-production rate. This equation is assumed to have boundary conditions on the outer surface that are set by radiative heat transfer only:

$$\frac{\partial T}{\partial r} = -\frac{\epsilon\sigma}{k} (T^4 - T_0^4), \quad (44)$$

where T_0 is the temperature of free space (assumed to be zero), σ is the Boltzmann constant, and ϵ is the emissivity.

Assuming that there is no conduction in the axial direction and that there is a uniform source distribution in the radial direction, the solution is

$$T = \frac{q}{4k} [R^2 - r^2] + \left[\frac{q}{2\sigma\epsilon} R \right]^{1/4}. \quad (45)$$

The maximum value of this equation occurs at the centerline:

$$T_{\max} = \frac{q}{4k} R^2 + \left[\frac{q}{2\sigma\epsilon} R \right]^{1/4}. \quad (46)$$

This value is calculated for the shield with the maximum heating rate determined in the following section. It should be noted that the neutron and core-gamma contributions to this rate are calculated at the centerline of the shield and are then assumed to have the same value over the entire face of the shield. The secondary-gamma contributions are taken to be an average over the shield face. These assumptions tend to make the calculated maximum temperature higher than it really would be. Sample calculations indicate that this error is 5 to 10% in absolute temperature.

SPR-6 Shielding Results

A series of GEISHA problems were run to investigate the effects of the hot-shield and rear-shield thicknesses. Figure 65 presents the results of this work in the form of a "carpet plot" of total shielding mass (hot shield plus main shield plus rear shield) versus the hot-shield and rear-shield thicknesses. In all cases, the main-shield thickness was varied to achieve a total integrated dose at the payload of 13.3 rem (10,000 hours), and its position was varied to achieve a maximum temperature of less than 830°K.

The system parameters are given in Table XXX. While the results indicate a

Table XXX. SPR-6 shielding model.

<u>Core (including coolant-return and control regions)</u>		
Radius	31.1	cm
Length	87.1	cm
Power (thermal)	55.0	MW
<u>Composition</u>		
Li ⁷	0.183	g/cm ³
Tungsten	3.543	g/cm ³
Uranium	4.710	g/cm ³
Nitrogen	0.279	g/cm ³
<u>Tube sheet</u>		
Length	0.5	cm
<u>Composition</u>		
Li ⁷	0.11	g/cm ³
Tungsten	14.21	g/cm ³
<u>Hot Shield</u>		
<u>Composition</u>		
Li ⁷	0.294	g/cm ³
Tungsten	5.69	g/cm ³
<u>Main shield</u>		
<u>Composition</u>		
Li ⁷ H	0.74	g/cm ³
<u>Back shield</u>		
<u>Composition</u>		
Tungsten	19.3	g/cm ³
<u>Reactor package</u>		
Effective outer radius	43.0	cm

minimum weight at about 30 cm for the hot shield and 12 cm for the rear shield, it should be evident that 1) this is only a preliminary study, 2) structural components such as pipes have not been included, and 3) the use of other components (such as the boiler) in a dual capacity as shielding materials have not been included.

Fig. 65. Mass of shielding versus hot-shield and back-shield thicknesses for the SPR-6.

The SPR-6 model used in these calculations involved a 5-m-diam payload 100 m from the core. This is equivalent to a 1.2-deg half angle. Increasing the payload's diameter to 10 m increases the

half angle to 2.6 deg and increases the shielding masses by about 20%.

The masses indicated in Table XXX do not include the "wings" that shield the radiator and prevent scattering into the payload.

Thermodynamics and Fluid Flow

EXTRAPOLATION OF FLUID SATURATION CONDITIONS TO THE CRITICAL POINT

In the 1967 first-quarter report (UCRL-50004-67-1), a method was given for approximating the engineering thermodynamic properties of fluid metals in the

dry-gas region at temperatures substantially higher than measured values and in a pressure domain only a little larger than the measured one. Described below is a reasonably accurate method of extrapolating the enthalpy and entropy of a saturated gas or liquid to the critical

point, using experimental data for temperatures lower than about 75% of the critical value. For two well-documented materials (water⁴³ and ethane⁴⁴), good agreement is found between the extrapolated and the experimental data for temperatures above 75% of critical. (The larger the number of distinct well-documented materials to which the following scheme applies, the greater the confidence with which it can be used.) The data used here are for one reference material (water) and one calculated material (potassium).

Saturation Enthalpy

As explained in the 1967 first-quarter report, the mean value of the enthalpy of a saturated liquid or gas $[\bar{H}(T)]$ is fairly well represented as a linear function of T .^{*} However, in order to include water and ethane in these calculations, it is necessary to extend the function to a quadratic dependence:

$$\frac{1}{2} [H_l(T) + H_g(T)] = \bar{H}(T) \approx \alpha + \beta T + \gamma T^2. \quad (47)$$

This equation was subsequently applied to all of the materials studied.

Watson⁴⁵ has shown that the heat of vaporization of most materials is accurately represented by

$$H_g(T) - H_l(T) = \Delta H(T) = \kappa \left(1 - \frac{T}{T_c}\right)^{0.38}, \quad (48)$$

where T_c is the critical temperature and κ is a constant that depends on the material. From Eqs. (47) and (48),

Table XXXI. Nomenclature used in determining the enthalpy and entropy of saturated liquids or gases.

Term	Definition
C_j	Constants (Eq. (47), $j = 1, 2, 3$)
$\Delta H(T)$	Latent heat of vaporization at temperature T
$H_l(T)$	Saturated-liquid enthalpy at temperature T
$H_g(T)$	Saturated-gas enthalpy at temperature T
$S_l(T)$	Saturated-liquid entropy at temperature T
$S_g(T)$	Saturated-gas entropy at temperature T
T_r	Reduced temperature ($T_r = T/T_c$)
T_c	Critical temperature
q	Vapor quality ($q = 1$ for a saturated gas, $q = 0$ for a saturated liquid)

$$H_l(T) = \bar{H}(T) - \frac{1}{2} \Delta H(T) \quad (49)$$

and

$$H_g(T) = \bar{H}(T) + \frac{1}{2} \Delta H(T). \quad (50)$$

In using the data for water⁴³ to determine α , β , γ , and κ in the reduced temperature range of $0.48 \leq T_r \leq 0.74$ (the typical range of experimental data for the alkali metals), the saturation enthalpy predicted by Eq. (47) at the critical temperature (647.3°K) is found to be in error by 6%.^{*} Since the approximation fits the experimental range of data quite well (see Figs. 66 and 67), the extrapolation is expected to be accurate for some distance beyond the upper limit of the data. Indeed, for water we find the extrapolated values of the enthalpies of the saturated liquid and gas to vary from the values quoted in

^{*}The terms used in this and the following section are defined in Table XXXI.

^{*}Extension of the data to a range $0.48 \leq T_r \leq 0.98$ reduces the error to 3%.

Fig. 66. Enthalpy versus temperature for water.

Fig. 67. Enthalpy versus temperature for potassium.

Ref. 43 by 3.2% and 0.4% respectively at a temperature 90% of critical.

Saturation Entropy

As explained in the 1967 first-quarter report, the accuracy of extrapolating the mean value of the entropies of saturated liquids or gases was inadequate. Accordingly, the method described below was devised.

In generating values of $S_l(T)$ and $S_g(T)$, it is expedient to consider the behavior of the material in enthalpy-entropy (H - S) space. The intersection of an isobar and a saturated-liquid line ($q = 0$) is shown schematically in Fig. 68. From the notation of this figure,

$$f(T_0) = \frac{S_1 - S_0}{S_2 - S_0} = \left(\frac{H_2 - H_0}{S_2 - S_0} \right) / \left(\frac{H_2 - H_0}{S_1 - S_0} \right). \quad (51)$$

The limit of $H_2 \rightarrow H_0$ gives

$$f(T) = \frac{\left. \frac{\partial H}{\partial S} \right|_p}{\left. \frac{\partial H}{\partial S} \right|_{q=0}} = \frac{T}{\left. \frac{\partial H}{\partial S} \right|_{q=0}}, \quad (52)$$

and rearranging this gives

$$\left. \frac{\partial S}{\partial T} \right|_{q=0} = \frac{f(T)}{T} \left. \frac{\partial H}{\partial T} \right|_{q=0}. \quad (53)$$

Differentiating Eqs. (49) and (50) and integrating Eq. (53) gives

$$S_l(T) - S_l(T_0) = \int_{T_0}^T \frac{f(T')}{T'} \left[C_2 + 2C_3 T' + \frac{0.19K_0}{T_c} (1 - T'_r)^{-0.62} \right] dT'. \quad (54)$$

The saturated-gas entropy is, of course, given by

Fig. 68. Intersection of an isobar and the saturated-liquid line on a typical Mollier diagram.

$$S_g(T) = S_l(T) + \frac{\Delta H(T)}{T}. \quad (55)$$

In order to perform the integration indicated by Eq. (54), it is necessary to know $f(T)$. Let us first examine the limits of $f(T)$. From basic thermodynamics,

$$dH = TdS + \frac{dp}{\rho} \quad (56)$$

or

$$\left. \frac{\partial H}{\partial S} \right|_{q=0} = T + \frac{1}{\rho} \left. \frac{\partial p}{\partial S} \right|_{q=0}. \quad (57)$$

It is known that $\rho > 0$, and for most materials $(\partial S / \partial T)|_{q=0} > 0$ (certainly for $T_r < 1$). Further, it is also true that $(\partial p / \partial T)|_{q=0} > 0$. Thus, $(\partial p / \partial S)|_{q=0} > 0$. Secondly, from Eq. (56), $(\partial H / \partial S)|_p = T$. Thus, from Eq. (52),*

* Note that at the critical point, the isobar is tangent to the vapor dome. Thus, $f(T_c) = 1$.

Fig. 69. Entropy versus temperature (slope method) for water.

Fig. 70. Entropy versus temperature (slope method) for potassium.

Fig. 71. Enthalpy versus entropy (slope method) for potassium.

$$0 < f(T) \leq 1. \quad (58)$$

In the work reported here, $f(T)$ has been calculated for two materials for which the data are well established: water⁴³ and ethane.⁴⁴ It was found that $0.95 < f(T) < 1$ both for water in the reduced temperature range of $0.48 \leq T_r \leq 0.98$ and for ethane in the range $0.29 \leq T_r \leq 0.98$. It was therefore decided to use a constant value of $f = 0.98$ for all calculations. Figures 69 and 70 show the results of this extrapolation

technique for water and potassium. For completeness, the results of the extrapolations are included on a Mollier diagram for potassium (see Fig. 71). This is merely a "cross-plot" of Figs. 67 and 70.

To date only water, ethane, and the alkali metals potassium, sodium, and cesium have been treated by these methods. However, the saturation conditions of these materials are well represented, indicating that the above extrapolation techniques could be applied generally.

Reactor System and Component Engineering

SPR-6 REFERENCE DESIGN*

In July 1966, a design study of a 10-MWe reference power system operating on the Rankine cycle was begun. This system was designated SPR-6. Preliminary neutron calculations have been reported in the 1966 third- and fourth-quarter reports (UCRL-50004-66-3 and -4), and system characteristics and reactor design have been presented in the 1966 fourth-quarter report and the 1967 first-quarter report (UCRL-50004-67-1). During the present quarter, studies pertinent to the SPR-6 reference design were compiled in an internal topical memorandum. This memorandum is now being examined for design consistency, and it is expected that a formal report on the SPR-6 reference design will be published at the end of the next quarter. A brief summary of the design follows.

Important conclusions will be drawn from the SPR-6 reference design, so it must be based on realistic assumptions regarding material properties and component performance. Some optimism may be in order, however, since the design is not intended for use much sooner than 20 years from now. The approach used in the SPR-6 study was to take the available short-time data on refractory metals and to extrapolate them to long lifetimes and heavier sections. The reliability of the data extrapolation and the effect of radiation, welding, fatigue, thermal cycling,

etc., were generally neglected in the spirit of optimism.

The principal characteristics of the SPR-6 reference design are listed in Table XXXII. It is assumed that the system would be launched in a partially assembled condition and that some manual work would be required in a low earth orbit to prepare the system for operation and earth escape. An artist's sketch of the SPR-6 powerplant is shown in Fig. 72. Artistic license has been applied to emphasize the reactor and salient details of the design. A diagram of the thermodynamic cycle with a peak reactor-coolant temperature of 1650°K is shown in Fig. 73. The specific mass of the system is given in Table XXXIII. The low computed specific mass of 7 g/W is encouraging, for if the system is to be used for difficult electric-propulsion missions, its specific mass must be low.

The primary application of megawatt space-power systems appears at this time to be in providing propulsion energy for long-duration manned interplanetary missions. In the absence of a specific application for the SPR-6, a reference mission was selected to put the SPR-6 design in context. The characteristics of this mission—a manned Mars landing—are given in the 1966 fourth-quarter report. The power level, specific mass, and lifetime of the SPR-6 are consistent with the general requirements of this mission.

The SPR-6 reference design supports the basic material system chosen for the reactor: tungsten, uranium nitride, and

*See also p. 44.

Table XXXII. Selected characteristics of the SPR-6 reference design.

<u>General</u>	
Reactor power	55 MW ^a
Electric power	10 MW
Design life	10 ⁴ hours
Application	Electric propulsion
Payload	
Type	Manned
Diameter	10 m ^b
Distance from reactor	100 m
Design power on-off cycles	6
<u>Reactor core</u>	
Reactor coolant	Lithium
Reactor-outlet temperature	1650°K ^c
Coolant-temperature rise	70°K
Difference between fuel centerline temperature and local coolant temperature	49°K
Reactor-coolant inlet pressure	25 bars ^d
Reactor pressure drop	0.534 bar
Mean outer radius of active core	31.1 cm
Core length	87 cm
Coolant-return radius	7.7 cm
Coolant-channel radius	0.2245 cm
Volume of active core	2.3 × 10 ⁵ cm ³
Weight of fuel and cladding	2535 kg
Weight of uranium	1354 kg
Fluid velocity	7.4 m/sec
Number of coolant channels	3400
Inside radius of pressure vessel	32.1 cm
Pressure-vessel alloy	T-111
Fuel volume fraction	0.435
Cladding volume fraction	0.183
Primary-coolant volume fraction	0.234
Stagnant-coolant volume fraction	0.093
Swelling allowance	0.054
<u>Fuel elements</u>	
Fuel	UN
Cladding alloy on fuel elements	W-25% Re (at. %)
Burnup fraction	0.02
Kind of fuel element	Hybrid ^e
Fuel radius	0.2207 cm
Cladding outer radius	0.2551 cm
Number of fuel elements	7800
Fuel density (fraction of theoretical)	0.97
Fuel-enrichment fraction (estimate)	0.47
Average fuel power density	550 W/cm ³
<u>Shielding</u>	
Main shield material	LiH
Maximum temperature of main shield	800°K
Main-shield thickness	112 cm
Total dose at payload (reactor origin)	13.3 R
<u>Power-conversion system</u>	
Type	Turbo-generator
Working fluid	Potassium
Turbine-inlet temperature	1560°K
Main-radiator inlet temperature	1110°K
Projected area of main radiator	427 m ²
Radiator reliability	0.99

^aThe use of a heat-pipe radiator permits a more efficient cycle, hence a lower thermal power is required than has previously been indicated.

^bThe payload diameter has been increased from 5 m in order to accommodate larger payloads.

^cThe reactor-outlet temperature has been reduced from 1800°K as a result of using a heat-pipe radiator.

^dThe reactor-coolant inlet pressure is chosen to match the potassium working-fluid pressure in the boiler.

^eSee the description of fuel elements in Fig. 28, p. 40.

lithium. System studies leading up to this design did not uncover a better Rankine-cycle working fluid than potassium. The maximum beneficial turbine-inlet temperature appears to be about 1650°K. Unless a considerably stronger (by a factor of 10) tungsten alloy is postulated, the reactor pressure vessel must be cooled to allow the more fabricable tantalum alloy (T-111) to be used as the pressure-vessel material. The pressure vessel is internally clad with tungsten to prevent the reactor coolant from attacking the tantalum. A relatively thin pressure vessel is required so that the external side reflector does not decouple from the core.

REACTOR SYSTEM ANALYSIS

A reactor-design code has been developed that describes a reactor in sufficient detail for board layout. The calculations proceed in this manner:

- Assume a power level.
- Assume a burnup fraction.
- Assume a porosity parameter.
- Assume an operating time. (These four assumptions fix the fuel volume, the various volume fractions, the power density, and the core volume.)
- Assume an allowable fuel thermal stress. (This assumption fixes the heat-pipe radius.)
- Calculate the maximum length of the heat pipe that will transfer the (known) required power from one end. (This establishes the core length.)
- Calculate the core radius from the known core volume and length.
- Calculate k_{eff} for a bare core and adjust the burnup. Repeat until k_{eff} reaches a preset value.

Repeat until k_{eff} is correct.

Fig. 72. Artist's sketch of the SPR-6 system.

Table XXXIII. Mass analysis of the SPR-6 reference design.

Component	Mass (kg)	Specific mass (g/W)	Relative mass
Radiator	13,200	1.32	0.19
Alternator	8,400	0.84	0.12
Turbine	7,800	0.78	0.11
Shield	6,800	0.68	0.10
Boiler/preheater	5,000	0.50	0.07
Reactor	4,200	0.42	0.06
Primary piping	2,300	0.23	0.03
Power conditioning and distribution ^a	1,600	0.16	0.02
Structure	1,500	0.15	0.02
Lithium pump	800	-	-
Potassium working fluid	600	-	-
Potassium pump	500	-	-
Lithium coolant	400	-	-
Controls	300	-	-
Secondary piping	300	-	-
Miscellaneous	2,300	-	-
Contingency (25%)	<u>14,000</u>	<u>1.40</u>	<u>0.20</u>
Total	70,000	7.00	1.00

^aPower conditioning and distribution for powerplant use only.

Fig. 73. Schematic diagram of the SPR-6 Rankine-cycle components.

Further iteration of the calculations permits a reactor with a discrete number of fuel elements and a 12-sided outer circumferential boundary to be described.

Variations in the calculational procedure are easily accommodated. For example, at low power, the aspect ratio of the core can be fixed. In this regime, the heat pipes are not driven to their utmost capacity.

Assumed amounts of fuel swelling and thermal expansion are allowed for. Heat transfer, thermal stress, friction pressure drops, and other characteristics are computed for the fuel elements with temperature-dependent properties. Neutronic calculations based on transport theory are performed as desired to compute the required fuel enrichment, multiplication factor, side-reflector worth, temperature effect on reactivity, reactivity change due to dynamic temperature fluctuations in individual components such as the fuel, the cladding, and the coolant, and lifetime effects due to burnup, swelling, and transmutation.

Although the details of the computational model are fairly elaborate, the resulting reactor design is only approximate because:

1. The mathematical representation of fuel swelling is not based on experimental data.
2. Neutronic calculations are one-dimensional.
3. Doppler effects are neglected.
4. Uniform fuel enrichment and burnup are assumed.

The reactor-design code was used to survey the thermal power range from 0.1 to 100 MW. There are three identifiable

regions in this range: 1) a criticality-limited region extending up to 2 or 4 MW, 2) a burnup-limited region extending upward from 10 or 20 MW, and 3) an intermediate region between 2 and 20 MW.

In the criticality-limited range, the only means of significantly reducing the core size is the choice of fissile material. The merits of U^{233} and U^{235} in this context are discussed below. Over most of the criticality-limited region, the specific power density is low enough for heat pipes to be attractive for cooling. In the intermediate region, conventional cooling with liquids pumped between spaced pins (see Fig. 74a) begins to show superior performance. In the burnup-limited range, the increase of core size with increasing power results in a significantly increased pressure drop or coolant-temperature rise across the reactor. The more favorable flow configuration of the hybrid geometry proposed for the SPR-6 reactor (see Fig. 74b) shows up at 15 to 25 MWt.

Criticality-Limited Core: U^{233}

In the thermal power region below 1 MW, the fuel volume fraction is well above 60% even for fully enriched (about 90%) U^{235} cores. The upper limit of the fuel volume fraction is generally established by the geometry of the fuel elements and by fabrication considerations. While further size reduction can be anticipated from porosity changes, replacement of U^{235} by U^{233} can reduce the core volume by a factor of 3 and the core radius by a factor of about 1.5. The use of U^{233} instead of U^{235} thus might be somewhat attractive below 1 MWt. However, fuel processing and assembly of the core must

(a) Spaced-pin geometry

(b) Hybrid geometry

Fig. 74. Two fuel-element geometries being considered for the SPR-6.

take place within a short time^{*} after the uranium/thorium stripping process in order to avoid a difficult handling process made necessary by the hard beta and gamma spectra of the daughter products. Fewer (by a factor of 3) delayed neutrons from U^{233} may complicate reactor-control problems.

Heat-Pipe-Cooled Reactors

Heat-pipe-cooled reactors have been proposed previously^{**} for high-power out-of-pile thermionic systems. A great advantage of the heat-pipe-cooled reactor is that it eliminates the hot-loop pump. For very-high-temperature thermionic out-of-pile systems this is almost a necessity, and for lower temperature

applications it is desirable from a reliability standpoint since it avoids pump failure and attendant heating problems. Comparison of heat-pipe systems with pumped systems shows that the radius penalty involved in using heat pipes is low for thermal powers under 2 to 4 MW. Boiler designs that use the condensing section of the heat pipe extending out of the core are now in progress. The heat-pipe core design consists of a cylindrical bundle of heat pipes that are hexagonally spaced at intervals throughout the core by tube sheets normal to the core axis. The fuel elements consist of hexagonal fuel tubes slipped over the heat pipes. The fuel tubes are immersed in a bonding fluid, and space is allowed for fuel swelling and differential expansion between the fuel and the heat pipes.

Figures 75, 76, and 77 show the core mass, the aspect ratio (length/diameter), and the radius for a set of UN/lithium/tungsten heat-pipe cores operating at 1500°K and using both U^{233} and U^{235} as

^{*}This time is from one to two weeks for the handling of kilogram quantities without special shielding, or from three to four months for the handling of single fuel elements in a lightly shielded glove box.

^{**}See the 1966 second-quarter report, UCRL-50004-66-2.

the fissile material. The porosity is indicated by the porosity parameter (β), which is defined as the ratio of the inside radius of the fuel tube to the outer flat radius. The heat pipes in these cores are custom designed in each case according to the restrictions imposed by the core.

A heat pipe that is typical of the design used and the dimensions calculated has been fabricated but not yet operated.

In Fig. 75, the core mass for heat-pipe-cooled reactors is plotted against power with the porosity parameter β . The horizontal portion of the curves represents

Fig. 75. Core mass for heat-pipe-cooled reactors. The fuel enrichment is 90% U^{235} or U^{233} in U^{238} , the reactor temperature is 1500°K, and the bonding and heat-pipe fluid is Li^7 .

Fig. 76. Core aspect ratio (length/diameter) for heat-pipe-cooled reactors. The fuel enrichment is 90% U^{235} or U^{233} in U^{238} , the reactor temperature is 1500°K , and the bonding and heat-pipe fluid is Li^7 .

Fig. 77. Core radius for heat-pipe-cooled reactors. The fuel enrichment is 90% U^{235} or U^{233} in U^{238} , the reactor temperature is 1500°K , and the bonding and heat-pipe fluid is Li^7 .

cases that are not limited by the heat-pipe power. The core aspect ratio in this regime was set at $L/D = 1.2$. Parametric studies indicate that this is about the optimum aspect ratio for a minimum core mass with the particular heat pipes considered. The horizontal portion of the curves would have bent up at lower powers (indicating a higher core mass) if they had been continued.

Figure 76 shows the variation of core aspect ratio with power for heat-pipe-cooled reactors having several values of β . The core aspect ratio was arbitrarily limited to $L/D = 1.2$ for the reasons mentioned above. Figure 77 shows the variation of core radius with power, again with $L/D = 1.2$ at the lower powers.

The core radius is actually a more significant parameter than the core mass since the shield mass is a strong function of the core radius. Two core-radius curves are plotted as a function of β in Fig. 78. One curve (positive slope only shown) results if the core aspect ratio is held constant (the power is also held constant). The heat pipes in these cores are not limited by the power to the right of the transition point between the two curves. A second curve (negative slope only shown) is formed by considering only cores that are limited by the heat-pipe power. The intersection of these curves specifies the value of β for the minimum core radius at a given core aspect ratio. The porosity parameter obtained in this manner is given as a function of power in Fig. 79.

Figure 80 shows the corresponding core radii. It must be emphasized that these values are subject to uncertainty until more is known about the behavior of

heat pipes. Accordingly, a safety factor has been applied. The safety factor is the ratio of the energy that can be carried by a given heat pipe as indicated by present theory to that which is assumed to be carried. Figures 75, 76, 77, and 78 are based on a heat-pipe safety factor of 1.

Spaced-Pin Geometry

In the intermediate thermal power range (2 to 20 MW), circulating liquid-metal-cooled reactors with a spaced-pin

Fig. 78. Typical behavior of core radius with varying porosity for heat-pipe-cooled reactors. To the right of the transition point, the cores have a constant aspect ratio of $L/D = 1.2$. To the left, the aspect ratio decreases due to heat-pipe limitations.

Fig. 79. Optimum porosity parameter (β) for heat-pipe-cooled reactors having a 90% U^{235} enrichment, a 20,000-hour lifetime, a 1500°K operating temperature, and Li^7 as the coolant.

Fig. 80. Minimum core radius for heat-pipe-cooled reactors having a 90% U^{235} enrichment, a 20,000-hour lifetime, a 1500°K operating temperature, and Li^7 as the coolant.

fuel geometry (see Fig. 74a) require smaller core radii than heat-pipe-cooled reactors. The most significant design parameters in this power range appear to be the core pressure drop and the fuel burnup. As the power increases, the porosity must increase in order to maintain a constant pressure drop across the

core for a constant coolant-temperature rise. In Figs. 81, 82, and 83, the core mass, the spacing parameter (β), and the radius are shown for various friction pressure drops as a function of power.

Fig. 81. Minimum core mass for spaced-pin cores having a 90% U^{235} enrichment, a 1500°K operating temperature, and Li^7 as the coolant. The parameter is the friction pressure drop for a 70°K coolant-temperature rise in the core.

Fig. 82. Optimum spacing parameter (β) for spaced-pin cores having a 90% U^{235} enrichment, a 1500°K operating temperature, and Li^7 as the coolant. The parameter is the friction pressure drop for a 70°K coolant-temperature rise in the core.

Fig. 83. Minimum core radius for spaced-pin cores having a 90% U^{235} enrichment, a 1500°K operating temperature, and Li^7 as the coolant. The parameter is the friction pressure drop for a 70°K coolant-temperature rise in the core.

The spacing parameter in spaced-pin cores is defined as the ratio of the spacer radius to the pin radius. Since these cores do not show a significant advantage over heat-pipe-cooled cores below 1 MWt,

no comparison of the U^{235} and U^{233} systems was made.

Hybrid Geometry

Figure 84 shows the mass and radius distributions for cores with a hollow central-coolant-return hybrid geometry (see Fig. 74b) as a function of power. A comparison of this figure with the figures for the spaced-pin cores shows that the hybrid geometry begin to show superiority in the thermal power range of 10 to 25 MW. In this range, the advantages of the more optimum flow channel begin to outweigh the disadvantage of the limited and fixed volume fraction of the hybrid geometry.

REACTOR CONTROL

Power fluctuations cause the temperature in the core to fluctuate, and a change

Fig. 84. Core mass, radius, and friction pressure drop for cores having a hybrid fuel geometry and a central coolant-return duct.

in the core temperature produces a change in the reactivity, thus establishing a feedback loop on the power.

Newly available computer programs such as the Control Systems Analysis Program⁴⁷ have made it possible to utilize relatively complex models in performing reactor-stability analyses.

When the complexity of the model is increased, the transfer function remains valid to increasingly higher frequencies.

Storrer's two-node derivation⁴⁸ has been extended to a three-node representation in which the fuel, the cladding, and the coolant are individually lumped in the radial reactor direction. The equations are solved exactly in the axial reactor direction.

The thermal time constants (i.e., the time for the temperature difference to change by a factor of e) for typical 2-MWt and 55-MWt reactor designs are given in Table XXXIV and are defined in Fig. 85. The thermal capacitances (mass times heat capacity) have been evaluated at the average temperature of the region under consideration. The thermal resistances

(temperature difference divided by heat flow) have been evaluated between the average temperature radii of adjacent regions. The large difference between the time constants for the 2-MWt reactor indicates that a simpler model would be sufficient for this case. However, this is not the situation for the 55-MWt reactor.

Several reactivity changes resulting from changes in the temperature of the individual components (fuel, cladding, or coolant) or in the temperature of the inlet coolant were determined. Examination of the individual components is desirable since the time constants are generally different. The changes considered are:

- Fuel-temperature reactivity effect (ΔK_F): This is the change in the multiplication factor due to a temperature change in the fuel alone. The change results from the thermal expansion or contraction of the fuel, which displaces or replaces the bonding fluid in the core.
- Cladding-temperature reactivity effect (ΔK_{CL}): Three principal effects are included here: 1) The

Table XXXIV. Thermal time constants for 2-MWt and 55-MWt reactor designs.

Parameter	Time constants (in 10^{-3} sec) for:	
	2-MWt designs (spaced-pin geometry)	55-MWt designs (hybrid geometry)
Coolant (R_2C_3)	3	57
Cladding (to coolant) (R_2C_2)	7	50
Cladding (to fuel) (R_1C_2)	57	54
Fuel (R_1C_1)	264	110
Power in fuel/heat capacity of fuel	10° K/sec	300° K/sec
Coolant velocity	2.4 m/sec	7.4 m/sec

Fig. 85. Definition of the thermal capacitance and resistance used in this study.

core dimensions change with the expansion coefficient of the cladding (close-packed fuel elements); 2) the primary-coolant volume increases (with temperature) but the primary-coolant density does not, and 3) the volumes of the bonding and interstitial fluids increase (with temperature) and the densities of the fluids decrease since their temperatures are assumed to follow the cladding temperature.

- Primary-coolant reactivity effect (ΔK_C): This is the change in the multiplication factor due to a density change in the primary coolant.

- Bias-temperature reactivity effect (ΔK_B): This is the effect due to a change in the inlet-coolant temperature. This changes the mean temperature of the entire reactor, including the pressure vessel and the coolant annulus between the core and the pressure vessel.
- Liquid-control reactivity effect (ΔK_{LC}): This is the control swing available by substituting Li^6 for Li^7 in the internal liquid-control circuits.*

*For a description of the liquid-control concept, see the 1967 first-quarter report, UCRL-50004-67-1.

The magnitude of these reactivity changes were determined for the SPR-6 reactor in two studies: The first examined the effect of a uniform Li^6/Li^7 mixture throughout the core, and the second examined the effect of various lithium mixtures in the interstitial and bonding fluids, with near-natural lithium (6% Li^6) in the primary coolant.* The results are shown in Table XXXV.

SYSTEM ANALYSIS

The Rankine-cycle computer code has been revised to include the heat-pipe radiator described in the 1966 fourth-quarter report (UCRL-50004-66-4) and a more realistic turbine model. The resulting effect on optimum reactor-outlet

*Uniform fuel enrichment and burnup were assumed in both studies.

temperature is seen in Fig. 86. Both the initial and the revised curves contain a minimum that results from an interchange in mass between the system-containment vessels and the radiator. At the higher temperatures, the radiator is lighter due to an increase in radiating power per unit area. However, the higher temperatures also result in a lower material strength and in heavier containment vessels. Above a particular optimum temperature, the containment-vessel mass is dominant and the system specific mass increases with temperature. Below the optimum temperature, the radiator mass is dominant and the system specific mass increases as the temperature decreases. Since the heat-pipe radiator used in the revised code has about one-half of the mass of the original fin-and-tube radiator, the original curve and optimum temperature are translated to the left and downward.

Table XXXV. Reactivity changes in the SPR-6 reactor according to its lithium content.

Uniform Li^6/Li^7 mixture throughout the core	Reactivity change at an Li^6 fraction of:					
	0.0	0.03	0.06	0.09	0.12	0.15
$\Delta K_F/^\circ\text{K} \times 10^{-6}$	-0.87	-0.40	-0.03	+0.43	+0.81	+1.16
$\Delta K_{CL}/^\circ\text{K} \times 10^{-6}$	-7.4	-7.1	-6.9	-6.6	-6.4	-6.2
$\Delta K_C/^\circ\text{K} \times 10^{-6}$	-1.64	-0.75	-0.84	+0.84	+1.55	+2.21
$\Delta K_B/^\circ\text{K} \times 10^{-6}$	-10.01	-8.62	-6.55	-4.68	-2.97	-1.42
Various lithium mixtures in the interstitial and bonding fluids only	Reactivity change at an Li^6 fraction of:					
	0.0	0.10	0.20	0.30	0.40	
$\Delta K_F/^\circ\text{K} \times 10^{-6}$	-0.085	-0.534	+1.783	+2.95	+4.04	
$\Delta K_{CL}/^\circ\text{K} \times 10^{-6}$	-12.53	-3.50	+4.97	+12.92	+20.37	
$\Delta K_C/^\circ\text{K} \times 10^{-6}$	+0.032	+0.021	+0.013	+0.005	+0.0008	
$\Delta K_B/^\circ\text{K} \times 10^{-6}$	-5.24	-3.09	-1.07	+0.811	+2.57	
ΔK_{LC}	-0.056	-0.054	-0.052	-0.051	-0.050

Fig. 86. Variation of SPR-6 system specific mass with reactor-outlet temperature. The power level is 10 MWe, the working fluid is potassium, the boiler flow density is variable in the original model and is $10.2 \text{ g/cm}^2\text{-sec}$ in the revised model, the turbine temperature ratio is 0.75 in the original model and is 0.71 in the revised model, and the radiator uses a solid fin in the original model and heat pipes in the revised model.

In the original model of the turbine, it was assumed that the turbine blades were exposed to potassium vapor at the boiler-outlet temperature. This temperature is unrealistically high because a considerable fluid-temperature drop exists through the turbine nozzle just upstream of the turbine blades. Based on this fact, it was found that the turbines could be operated with reactor-outlet temperatures of up to 1750°K without being overstressed. This increase in the allowable reactor-outlet

temperature permits the revised system to be operated at its optimum temperature of 1650°K .

It should be noted that the system specific mass is sensitive to assumptions of material strength. Specifically, the following strength values were used in the revised system.

- Containment vessels (except radiator):

$$\sigma \text{ (psi)} = 10 \exp(-0.0502P + 5.99)$$

for the tungsten alloy [W-25%Re-30%Mo (at. %)], where

$$P = \left[T(^{\circ}\text{R})/1000 \right] \left[15 + \log_{10}(\text{hours}) \right]$$

- Turbine blades:

$$\sigma \text{ (psi)} = 10 \exp(-0.0336P + 5.88),$$

$$P < 49$$

and

$$\sigma \text{ (psi)} = 10 \exp(-0.1003P + 9.15),$$

$$49 < P < 54.7$$

for the molybdenum alloy (TZC).

$$\sigma \text{ (psi)} = 10 \exp(-0.0502P + 6.69),$$

$$P > 54.7$$

for the tungsten alloy (Sylvania A or equivalent).

- Radiator:

$$\sigma \text{ (psi)} = 5100 \text{ for the niobium alloy.}$$

A study has been completed to determine the effect of the reactor-to-payload distance on the system specific mass. The results, shown in Fig. 87, indicate that the specific mass is relatively insensitive to changes in the reactor-to-payload distance. The system specific mass was also found to be practically independent of the payload diameter. This is because the shadow cone angle is quite small. A value of 10 m was picked as the nominal condition.

A study of the effects of assumed fuel swelling on several reactor parameters

has been made for a typical SPR-6 reactor (2% fuel burnup). The linear swelling of the fuel was assumed to vary from 1 to 9% per 1% of fuel burnup, which resulted in a fuel volume swelling of 3 to 30%. With increased swelling, additional space was necessary for the fuel to swell into. As the swelling allowance increased, the reactor design showed increased length, radius, mass, and cladding thickness. The effective multiplication factor (equal enrichment in all cases), the lithium-coolant velocity, and the pressure drop all decreased. The variations were as shown in Fig. 88.

HEAT-PIPE RADIATOR

Additional analysis has been carried out on heat-pipe radiators, particularly as applied to the SPR-6 reference design.⁴⁹ The computer code developed during the course of these studies, HPRAD3, was used to investigate the effect of various parameters on the mass of the SPR-6 radiator. While the parameter variation was not exhaustive, enough was done to specify a "near-optimum" radiator design. The parameters investigated are described below.

Heat-Pipe Input Flux and Axial-Flux Safety Factor

The heat-pipe input flux and the axial-flux safety factor jointly determine the length of an individual heat pipe as well as its separation into evaporator and condenser sections. Higher input fluxes mean shorter evaporator sections and hence a smaller size and mass for the heat-pipe manifold. However, this advantage is eventually overtaken by a disadvantage, which is that small manifolds

require much segmentation and this in turn increases the amount of feed-line piping. Thus, there is an optimum value for the heat-pipe input flux.

It can also be argued that there should be an optimum value for the axial-flux safety factor. For any given ratio of condenser-section length to evaporator-section length, higher safety factors mean shorter heat pipes but more of them. The shorter pipes can be constructed with thinner walls because of their reduced vulnerability to meteoroids, but this mass reduction tends to be offset by the amount of manifolding required to accommodate the increased number of heat pipes. Thus, there is an optimum value for the axial-flux safety factor.

Figure 89a shows the effect of the heat-pipe input flux and the axial-flux safety

Fig. 87. Effect of reactor-to-payload distance on the SPR-6 power-plant specific mass. Nominally, the SPR-6 has a combined payload and powerplant weight of 3000 kg, a reactor-to-payload distance of 100 m, a powerplant specific mass of 4.54 g/W, and a payload diameter of 10 m.

Fig. 88. Variation of normalized reactor parameters with linear fuel swelling.

factor on the total radiator mass. The curves refer to radiators using 1.5-cm-diam heat pipes filled with potassium.

The piping is sized for a 5% drop in inlet pressure in the working fluid as it passes through the radiator. A "near-optimum"

Fig. 89. Effect of parameter variation on the mass of the SPR-6 heat-pipe radiator.

radiator results at an input flux of 50 W/cm^2 and an axial-flux safety factor of two. [The 75-W/cm^2 (safety-factor unity) case is not chosen because it is not considered desirable to operate the heat pipes at their maximum capacity.]

Heat-Pipe Diameter

The total radiator mass is a strong function of the heat-pipe diameter. As the heat-pipe diameter decreases, the required wall thickness decreases. This results in a reduction in heat-pipe mass, even though the number of heat pipes increases. At some point, however, this decrease in mass is negated by the increased amount of piping required to accommodate the large number of small heat pipes. Figure 89b shows the effect of heat-pipe diameter on total radiator mass. The results shown are for potassium-filled heat pipes with an input flux of 50 W/cm^2 and an axial-flux safety factor of 2. The optimum heat-pipe diameter is between 1.0 and 1.5 cm.

Heat-Pipe Survival Probability

There is a tradeoff between the protection (by increasing wall thickness) that can be given individual heat pipes and the amount of redundancy that can be obtained by using extra heat pipes. In Fig. 89c, it can be seen that for an optimum design the fraction of heat pipes that would not survive should be 0.10. That is, the optimum design calls for sufficient protection of individual heat pipes to assure that no more than 10% of them would sustain damaging hits. The results of Fig. 89c are for 1.5-cm-diam potassium-filled heat pipes with an input flux of

50 W/cm^2 and an axial-flux safety factor of 2.*

Working-Fluid Pressure Drop

Higher allowable pressure drops permit the use of lighter radiators because segmentation of the manifold decreases and because both the length and the diameter of the feed and return lines decrease. Figure 89d shows the effect of varying the allowable pressure drop from 5 to 20% of the inlet pressure to the radiator. The reduction in mass resulting from the increased allowable pressure drop is rather small, but this effect should be balanced by the increase in pump mass due to higher pressure drops. The results are for 1.5-cm-diam potassium-filled heat pipes with an input flux of 50 W/cm^2 and an axial-flux safety factor of 2.

Radiator Survival Probability

Since no punctures can be tolerated in the manifold and feed lines, armor must be provided for them. Figure 89e shows the effect of meteoroid armor on the probability of survival. The higher total mass at higher survival probabilities is due entirely to the increase in armor thickness. The armor thickness increases from 1.15 cm at $P(0) = 0.99$ to 4.0 cm at $P(0) = 0.9999$. The penalty for the added reliability afforded by the 0.9999 case as opposed to the 0.99 case would actually be less than the 2 g/W implied by Fig. 89e

*The calculations for Figs. 89c and 89d were done for a radiator having a nontapered feed line, and they do not agree absolutely with the results shown in Figs. 89a and 89b.

since the powerplant cycle could be re-optimized to decrease the fraction of total mass contributed by the radiator.

Heat-Pipe Fluid

Sodium is a better heat-pipe fluid with respect to its heat-transport properties. However, the use of sodium-filled heat pipes in the SPR-6 radiator does not necessarily result in a lighter radiator. Figure 89f presents the same parameter variation as Fig. 89a except that the heat pipes contain sodium rather than potassium. The minimum radiator mass with sodium (at an input flux of 75 W/cm^2 and an axial-flux safety factor of 2) is only 150 kg less than the minimum radiator mass with potassium. In one sense, the sodium heat-pipe radiator is "better" than the potassium one. The sodium design has the same minimum mass as the potassium design at an input flux of 50 W/cm^2 but at a higher axial-flux safety factor. Thus, the sodium pipes operate at a lower fraction of their capacity than do the potassium pipes. Unfortunately, this "advantage" does not appear as a reduction in radiator mass.

ANNULAR-HEAT-PIPE EXPERIMENT

Initial experiments with an isothermal annular heat pipe have been carried out. In this heat pipe, the working fluid is coupled to a large inert-gas plenum that is maintained at a constant temperature. The pressure and temperature of the working fluid thus remain nearly constant as the power to the heat pipe is varied over a wide range.

This arrangement is expected to present an ideal means of establishing and

automatically maintaining a desired temperature while irradiating fuel samples even though the power of the irradiation reactor might vary considerably during a cycle. An additional advantage is the ability to accurately infer the high temperature of the fuel with a low-temperature pressure gauge in the gas plenum.

An observation first reported by Cotter³⁶ lead to this concept of automatic temperature control. Cotter observed that the inadvertent inclusion of a low-solubility gas (hydrogen) in a heat pipe causes the normally isothermal pipe to have a temperature falloff at the condensing end. This falloff is ascribed to the hydrogen being pumped to the condensing end of the heat pipe along with the vaporized working fluid and, being noncondensable, remaining there while the condensed working fluid returns to the evaporator end via the wick. When the heat input is increased, the length of the temperature-falloff region decreases.

A heat pipe containing gas from a fixed-pressure reservoir will respond to changes in the input power by changing the volume of the hot vapor. This in turn results in a change in the surface area of the condenser to match the new heat load. The gas and vapor phases do not mix appreciably since essentially all of the vapor condenses on the pipe walls before it penetrates very far into the gas region. Figure 90 illustrates the principle of operation.

The experimental annular heat pipe (see Fig. 91) is designed to use potassium or sodium as the working fluid. A high surface heat flux (about 100 W/cm^2) is obtained with an electrical heater. The maximum design temperature is 1000°K .

Fig. 90. Operation of a heat pipe containing a low-solubility gas in addition to the working fluid.

Means for measuring and controlling the wick temperature, heater temperature, heat input and output, and pressure are provided. The model is made up of two concentric, cylindrical, stainless-steel tubes 45 cm long. The center tube (2.67-cm o.d. and 0.165-cm-thick wall) contains the electrical heater. The heater is thermally bonded to the tube with liquid potassium at a pressure higher than its vapor pressure. A stainless-steel screen (five layers thick) is wrapped around the outside diameter of the center tube and spot welded. This screen forms the capillary structure that supplies liquid metal to the evaporator (heat-source) region of the center tube. The liquid metal evaporates and flows radially and axially to the inside wall of the outer tube (condenser), where it condenses and returns by gravity to the evaporator. The condenser is also covered with a stainless-steel screen. The heat is removed from the condenser by conduction across a 0.075-cm helium gap to a water-cooled

jacket. A schematic of the system is shown in Fig. 92.

Initial tests with the annular heat pipe were conducted at 830, 920, and 970°K. Six independent test runs were made. Run No. 1 was a non-data-gathering run at low power (400 W) to "bake out" and check out the system. Data was obtained during Run Nos. 2, 4, 5, and 6 (Run No. 3 was for demonstration only). The total time with power on was about 6 hours.

Near the end of Run No. 6, the electrical heater supplying power to the heat pipe failed when one of its legs shorted out across the heater insulation, through the heater sheath, and into the heat-pipe wall to ground. The heat-pipe power at the time was 3 kW. The probable cause of failure was heat-pipe "burnout" (i. e., a local condition where the wick structure is starved for fluid). The local loss of ability to lose heat (no fluid, no vapor, no heat transfer) caused the heater temperature to rise until the insulation broke down. The maximum heater rating is

Fig. 91. Sketch of the experimental annular heat pipe. The circled numbers indicate thermocouple locations.

about 1075°K, and its life expectancy is 8 hours. The high-voltage arc that was produced burned a hole about 0.5 cm in

diam through the heat-pipe wall. Repairs are underway.

Figure 93 is a partial reproduction of the temperature traces recorded by Thermocouple Nos. 2 and 3 (see Fig. 91). Note that as the power was increased from 1500 to 3000 W, the temperature of both thermocouples remained substantially constant at 870°K, changing only about five or six degrees, or less than 1%. Figure 93 suggests that operation in the heat-pipe regime is not accomplished until the power input is at least 1500 W. This observation is substantiated in Fig. 94, where the temperatures of Thermocouple Nos. 8 and 9 did not agree with those of Thermocouple Nos. 2 and 3 until 1800 W of power were applied. Figure 94 shows how the vapor/gas interface moves up the heat pipe with increasing power. Figure 95 demonstrates the effect of power input on isothermal length and the ability to preserve constant operating temperatures. Figure 96 compares the pressures observed by a micromanometer connected to the heat pipe with the vapor-pressure curve for potassium. The implication in Fig. 96 is that the high temperature of the heat pipe can be inferred from a room-temperature measurement of the heat-pipe pressure. This ability would greatly simplify the instrumentation of fuel-irradiation capsules.

CORROSION LOOP

Loop Design

The design of the W-25%Re-30%Mo (at. %) corrosion loop* has been modified

*See also p. 32.

Fig. 93. Reproduced temperature traces of Thermocouple Nos. 2 (top) and 3 (bottom) during Run No. 4. The working fluid was potassium and the plenum gas was argon.

Fig. 94. Temperatures at thermocouple stations along the heat pipe as a function of power (Run No. 4).

Fig. 95. Effect of power input on isothermal length and the ability to preserve a constant operating temperature (Run No. 4).

Fig. 96. Comparison of experimental vapor pressures from micro-manometer readings with consolidated data from Refs. 46, 50, 51, and 52.

to reduce the total costs of material and fabrication. The major changes are the size and location of the fill/drain and expansion tanks. Minor redesigning of some of the components was necessary to accommodate the revised loop operating temperature (1800 to 1700°K) and minor fabrication problems. The new tank arrangement is shown in Fig. 97. The basic layout and design of the loop remain unchanged, and all components have been placed for manufacture. The minor design changes are described below.

Induction Pump

More detailed heat-balance calculations and the lowering of the loop temperature have eased the problem of thermal shielding for the induction pump. Adequate thermal isolation of the pump can be achieved by two sheets of corrugated

Fig. 97. Revised loop arrangement and tank detail.

tungsten foil plus a thin alumina slab to ensure electrical standoff from the vacuum vessel. A redesign of the external magnet now permits the vessel wall to be directly cooled next to the pump.

Heat Rejection

Control of heat rejection from the loop has been complicated by the reduction in the loop temperature. The loop now requires only a single surface shield everywhere but around the heater section and the pump. The bias-heater elements have been changed to a 20%-porosity mesh. At present the range of control is adequate, but another drop of 100°K in the average loop temperature will require the addition of more rejection surface.

Fill/Drain and Expansion Tanks

The fill/drain system has been extensively modified to eliminate one of the large (and expensive) ternary-alloy tanks and to shorten the total length of alloy tubing required. The fill/drain tank has been redesigned and relocated below the loop. Only a small blind expansion tank has been retained at the upper end of the loop. This tank acts as a gas trap and accumulator to force lithium out of the loop and into the drain tank. Lithium is held in the loop by balancing the pressure of the trapped gas against an external pressure source. A fluid indicator has been provided to give positive evidence of the presence or absence of fluid in the upper expansion tank.

The fill/drain tank has been redesigned to operate below the loop with dip legs for the loop connection and the external fill line. An inverted dip tube has been

provided to act as a fluid-level indicator. The tank is smaller than either of the two tanks it replaces because the total lithium volume in the loop has been reduced. The tank is big enough to contain two loop volumes (418 cm³).

The new tank position permits the lithium fill line and the gas-pressurization line to penetrate the wall of the vacuum vessel through a mechanical vacuum seal. The transition in the line from ternary alloy to stainless steel occurs outside the vacuum chamber in a sealed box kept at more than 1 atm of argon. Even though a mechanical transition was selected, various braze combinations are being tested as a back-up design.

The fill/drain tank is well shielded from the primary heat source and the main shield pack, which causes a problem in keeping the lithium fluid during the start-up phase. Auxiliary heat may be required, depending on the final start-up procedure selected. Provision for such auxiliary heat has been made.

Containment Vessel

The corrosion-loop containment vessel consists of three sections. The base section is a triode-ion-pump vacuum chamber that has provision both for rough pumping through two valved connections by means of cryogenic pumps, and for ion pumping down to 10⁻⁹ torr by means of six 1000-liter/sec ion pumps.

The center section is an instrumentation spool that supports and guides the loop, provides for positioning the electromagnetic pump magnet, and provides pass-throughs for electrical power leads, lithium and argon lines, and instrumentation leads. There are also two viewports

for observing critical portions of the loop, a port for a residual-gas analyzer, and another port for attaching a turbomolecular vacuum pump through a 6-in. bakeable valve.

The third section is a "bell-jar" cover for the instrumentation spool. This cover can be removed to work on the loop and its supports in the spool. The bell jar also has five viewports for loop observation.

NaK LOW-TEMPERATURE TEST LOOP

The NaK low-temperature test loop was modified this quarter, and the first tests were completed on the electro-magnetic pump and liquid-level detector. Figure 98 shows the modified NaK-loop assembly. The previous arrangement was described in the 1967 first-quarter report (UCRL-50004-67-1).

The NaK loop is modeled after the W-25%Re-30%Mo (at. %) high-temperature

Fig. 98. Schematic of the NaK low-temperature test loop.

Fig. 99. Measured NaK-loop operating characteristics and calculated NaK-loop and corrosion-loop operating characteristics.

corrosion loop, but differential pressure transducers, flow-measurement channels, and sight glasses for liquid-level indication have been added. The most serious operational difficulty to date has been electrical noise caused by the high electromagnetic-pump currents superimposed on transducer output signals (pressures and flow). This difficulty has been only partially rectified. Localized heating in the pump has also prevented high-current, long-term (10-min) operation.

The measured operating characteristics of the NaK loop are shown in Fig. 99. Electrical noise from the pump armature current caused erratic readings, and

heating of the NaK in the pump appeared to cause some drift in the pressure-transducer outputs. The pressures plotted in Fig. 99 represent the pressure rise in the pump and the pressure drop across the test section (0.343-cm i. d. and 60.8-cm length). Curves representing calculated pressure drops in the test section are also shown for reference.

The pump performance was much higher than that obtained with a similar pump in the original NaK loop. The difference is attributed to the much-improved differential pressure transducers in this loop. The new transducers are a diaphragm type that uses a variable-reluctance measuring technique. The first

NaK loop utilized absolute liquid-filled transducers (constructed at LRL), so small pressure differences between two transducers were often undetectable. The flow was measured with a Potter MF-150-4171 turbine flow meter that was calibrated by the manufacturer with water as the measured fluid. The system pressure drop was varied by means of a valve.

The calculated pressure/flow characteristics of the corrosion loop at 1800°K are also shown in Fig. 99. Pump

performance in the corrosion loop can be predicted from the NaK-loop data of Fig. 99 through some simplification. The wall current for both pumps is a small portion of the total current, and since the pumps are driven by a constant-current source, pump performance is almost independent of the fluid resistivity. Hence, the performance of the pump in the corrosion loop should be essentially the same as that of the NaK pump as shown in Fig. 99.

References

1. H. G. Sell, W. R. Morcum, G. W. King, and N. F. Cerulli, Development of Dispersion Strengthened Tungsten Base Alloys, AFML-TR-65-407, Part II, Westinghouse Electric Corporation, Bloomfield, New Jersey (1966).
2. I. Langmuir, Monolayers on Solids (Chemical Society, London, 1940), part I.
3. L. F. Norris, G. Reinhardt, and W. S. Cremens, Comparison of Selected Submicron Powder Blending Methods for Dispersion Alloys, NASA-TND-3834, National Aeronautics and Space Administration, Lewis Research Center, Cleveland (1967).
4. B. Phillips, L. L. Y. Chang, and M. G. Scroger, Research on Criteria for Selection of Alloys and Surface Treatments for Inhibition of Tungsten Oxidation, Part III, ML-TDR-64-230, Part III, Temp-Pres Research Associates, University Park, Pennsylvania (1966).
5. P. K. Conn, E. C. Duderstadt, and R. E. Fryxell, Measurement of the Permeability of Tungsten to Nitrogen, GE-NMPO-67-522, General Electric Company, Evendale, Ohio (1967).
6. R. Frauenfelder, "The Diffusion of Hydrogen and Nitrogen in Tungsten and Molybdenum," paper presented at the 13th National Vacuum Symposium, San Francisco, October 26-28, 1966.
7. W. R. Holman and F. J. Huegel, CVD Tungsten and Tungsten-Rhenium Alloys for Structural Applications, Part I: Process Development and Part II: Evaluation, UCRL-70340, Parts I and II, Lawrence Radiation Laboratory, Livermore (1967).
8. Fourth Annual Report, High Temperature Materials and Reactor Component Development Programs, Vol. I: Materials, GEMP-334A, General Electric Company, Evendale, Ohio (1965).
9. Private communication from C. T. Wang, Wah Chang Corporation, Albany, Oregon, July 1966.
10. M. A. DeCrescente, M. S. Freed, and S. D. Caplow, Uranium Nitride Fuel Development, SNAP-50, PWAC-488, Pratt and Whitney Company, Inc., Middletown, Connecticut (1965).
11. R. Benz and M. G. Bowman, J. Am. Chem. Soc. 88, 264 (1966).
12. J. Bugl and A. A. Bauer, "Thermodynamics of the U_2N_3 Phase Region," Nuclear Metallurgy, Vol. 10: Compounds of Interest in Nuclear Reactor Technology, ed. Waber, Chiotti, and Minor (AIME, New York, 1964), p. 215.
13. P. E. Lapat and R. B. Holden, "Thermodynamics of the Uranium-Nitrogen System," ibid., p. 225.
14. W. M. Olsen and R. N. R. Mulford, J. Phys. Chem. 67, 952 (1963).
15. D. McLean, Grain Boundaries in Metals (Clarendon Press, Oxford, 1957), p. 248.

16. Private communication from S. C. Weaver, Oak Ridge National Laboratory, July 15, 1967.
17. W. M. Armstrong, W. R. Irvine, and R. H. Martinson, *J. Nucl. Mater.* 7, 133 (1962).
18. J. J. Norreys, Carbides in Nuclear Energy (Macmillan & Company, Ltd., London, 1964), vol. I, p. 435.
19. R. Chang, G. G. Bentle, and F. E. Ekstrom, *Met. Eng. Quart.* 3, 36042 (1963).
20. M. H. Fassler, F. J. Huegel, and M. A. DeCrescente, Compressive Creep of UC and UN, PWAC-482, Pratt and Whitney Company, Inc., Middletown, Connecticut (1965).
21. C. P. Kempter, J. C. McGuire, and M. R. Nadler, *Anal. Chem.* 31, 156 (1959).
22. J. Weertman, *J. Appl. Phys.* 28, 362 (1957).
23. J. Weertman, *J. Appl. Phys.* 28, 1185 (1957).
24. C. R. Barrett and W. D. Nix, *Acta Met.* 13, 1247 (1965).
25. T. J. Sturiale and M. A. DeCrescente, Self Diffusion of Nitrogen in Uranium Mononitride, PWAC-477, Pratt and Whitney Company, Inc., Middletown, Connecticut (1965).
26. H. H. Willard and G. M. Smith, *Ind. Eng. Chem., Anal. Ed.* 11, 305 (1939).
27. W. T. Smith and S. H. Long, *J. Am. Chem. Soc.* 70, 354 (1948).
28. D. H. Wilkins, *Talanta* 2, 355 (1959).
29. E. J. Dixon and J. B. Headridge, *Analyst* 89, 185 (1964).
30. W. F. Hillebrand and G. E. F. Lundell, Applied Inorganic Analysis (John Wiley & Sons, Inc., New York, 1953), 2nd ed., pp. 310-311, 580-584, and 689-692.
31. E. E. Albin and W. F. Morris, Determination of Impurities in Molybdenum by Emission Spectroscopy, UCID-15039, Lawrence Radiation Laboratory, Livermore (1966).
32. R. J. Howerton, Semiempirical Neutron Cross Sections, Part II, Vol. I, UCRL-5351, Lawrence Radiation Laboratory, Livermore (1958). This is the most recently published report, but the data actually used in the studies reported here have been updated by Howerton.
33. E. H. Canfield and J. Pettibone, SOPHIST II, a Group Cross Section IBM 709/7090 Code, UCRL-6912, Lawrence Radiation Laboratory, Livermore (1962). SOPHIST IIA is essentially identical to SOPHIST II but has been coded for use with the CDC 3600 computer.
34. E. H. Canfield, SOPHIST-5 an IBM 7090/7094 FORTRAN II Code Which Calculates Multigroup Energy Transfer Matrices for Anisotropic Elastic Scattering of Neutrons, UCRL-7624, Lawrence Radiation Laboratory, Livermore (1963).
35. R. J. Doyas, and E. H. Canfield, A New Derivation of Multigroup Cross Sections for BeO- and Graphite-Moderated Systems, UCRL-7827, Lawrence Radiation Laboratory, Livermore (1964), p. 10.

36. T. P. Cotter, Theory of Heat Pipes, LA-3247-MS, Los Alamos Scientific Laboratory, Albuquerque (1965).
37. A. Leonard, Out-of-Pile Thermionic Space Power Systems Using a Gaseous Heat Transfer Fluid, RM-4469-PR, The RAND Corporation, Santa Monica (1965).
38. C. Cline, Electrical Transport Processes in BeO, UCRL-6513-T, Lawrence Radiation Laboratory, Livermore (to be published).
39. R. E. Schreiber and E. W. Salmi, "A Look at Nuclear Thermionic Systems," AIAA paper No. 67-498 (1967).
40. R. D. Albert and T. A. Welton, A Simplified Theory of Neutron Attenuation and Its Application to Reactor Shield Design, WAPD-15, Westinghouse Electric Corporation, Wilmington (1950).
41. D. K. Trubey, A Survey of Empirical Functions Used to Fit Gamma-Ray Buildup Factors, ORNL-RSEC-10, Oak Ridge National Laboratory (1966).
42. M. Soodak, Reactor Handbook (Interscience Publishers, Inc., New York, 1962), vol. III, part B, pp. 117-119.
43. J. H. Keenan and F. G. Keyes, Thermodynamic Properties of Steam (John Wiley & Sons, Inc., New York, 1936).
44. F. Din, Thermodynamic Functions of Gases (Butterworth & Company, London, 1961).
45. K. M. Watson, *Ind. Eng. Chem.* **35**, 398 (1943).
46. C. T. Ewing, J. P. Stone, J. R. Spann, E. W. Steinkuller, D. D. Williams, and R. R. Miller, High-Temperature Properties of Potassium, NRL-6233, Naval Research Laboratory, Washington, D. C. (1965).
47. M. E. Fowler, Control Systems Analysis Program II (CSAP II), 38004, IBM Corporation, Inc., Owego, New York (1965).
48. F. Storrer, Temperature Response to Power, Inlet Coolant Temperature and Flow Transients in Solid Fuel Reactors, APDA-132, Atomic Power Development Associates, Inc., Detroit (1959).
49. R. W. Werner and G. A. Carlson, Heat Pipe Radiator for a 50-MWt Space Power Plant, UCRL-50294, Lawrence Radiation Laboratory, Livermore (1967).
50. R. Hultgren, Selected Values of Thermodynamic Properties of Metals and Alloys (John Wiley & Sons, Inc., New York, 1963).
51. W. D. Weatherford, Jr., J. L. Tyler, and P. M. Ku, Properties of Inorganic Energy-Conversion and Heat-Transfer Fluids for Space Applications, WADD-TR-61-96, Southwest Research Institute, San Antonio (1961).
52. R. E. Hoenig, Vapor Pressure Data for the Solid and Liquid Elements, Radio Corporation of America, Princeton (1962).

Distribution

LRL Internal Distribution

D. Sewell	
B. J. Weis	
J. W. Hadley	4
R. E. Batzel	
A. T. Biehl	
E. Teller	
J. S. Kane	2
W. B. Myers	2
B. Rubin	
L. W. Roberts	
R. A. Heckman	
J. W. Kury	
P. C. Stevenson	
O. C. Kolar	
J. O. Cowles	
J. R. Long	
H. F. Finn	
W. C. Grayson, Jr.	
H. L. Reynolds	
G. Cummings	
TID Berkeley	
TID File	30

External Distribution

G. Newby
M. Klein
C. Johnson
U.S. Atomic Energy Commission
Space Nuclear Systems Division
Washington, D. C.

External Distribution (Continued)

R. L. Wessel
Defense Atomic Support Agency
Livermore, California

J. G. Whiteaker
Office of the Chief of Naval Operations
Washington, D. C.

W. O. Harms
Oak Ridge National Laboratory
Oak Ridge, Tennessee

F. W. Hunton
San Francisco Operations Office
Berkeley, California

J. P. Layton
Forrestal Research Center, Princeton University
Princeton, New Jersey

L. Humble
T. Moss
Lewis Research Center
Cleveland, Ohio

S. V. Manson
J. J. Lynch
National Aeronautics and Space Administration
Washington, D. C.

J. P. Davis
D. G. Elliott
Jet Propulsion Laboratory
Pasadena, California

L. Roberts
Ames Research Center
Moffett Field, Sunnyvale, California

R. J. Rosa
AVCO Everett Research Laboratory
Everett, Massachusetts

R. F. Cooper
Air Force Aero-Propulsion Laboratory
Wright-Patterson Air Force Base, Ohio

J. L. Kerrebrock
Massachusetts Institute of Technology
Cambridge, Massachusetts

S. Siegel
L. Prem
North American Aviation, Inc.
Atomics International Division
Canoga Park, California

External Distribution (Continued)

E. Pierson
University of Illinois
Chicago, Illinois

M. Petrick
Argonne National Laboratory
Argonne, Illinois

R. V. Mrozinski
National Aeronautics and Space Council
Washington, D. C.

TID-4500, UC-33, Propulsion Systems and Energy Conversion

264

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

Printed in USA. Available from the Clearinghouse for Federal
Scientific and Technical Information, National Bureau of Standards,
U. S. Department of Commerce, Springfield, Virginia 22151
Price: Printed Copy \$3.00; Microfiche \$0.65.

SN/rt