405-
10-1

135 Fast Reactor

A+B Fast Reactor Journal

1934

AI-AEC-13006

MASTER

CFH

ANNUAL TECHNICAL PROGRESS REPORT

LMFBR SAFETY PROGRAMS

GFY 1971

AEC Research and Development Report

Atoms International
North American Rockwell

P.O. Box 309
Canoga Park, California 91304

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

Printed in the United States of America
Available from

Clearinghouse for Federal Scientific and Technical Information
National Bureau of Standards, U.S. Department of Commerce
Springfield, Virginia 22151

Price: Printed Copy \$3.00; Microfiche \$0.65

ANNUAL TECHNICAL PROGRESS REPORT
LMFBR SAFETY PROGRAMS
GFY 1971

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Atoms International
North American Rockwell

P.O. Box 309
Canoga Park, California 91304

CONTRACT: AT(04-3)-701
ISSUED: SEPTEMBER 15, 1971

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

fy

DISTRIBUTION

This report has been distributed according to the category "Health and Safety," as given in the Standard Distribution for Unclassified Scientific and Technical Reports, TID-4500.

CONTENTS

<u>Program</u>	<u>AEC Task No.</u>	<u>Project Title</u>	<u>Page</u>
Reactor Development	6-D 6-E 6-F	Nuclear Safety, Gaseous Effluents, Sodium Fires	5
Fast-Reactor Development	6-G	Nuclear Safety (Kinetics), Boiling Studies for Sodium Reactor Safety	35

1. Spray-Burning Experiments	9
2. Sodium Jet Discharge Conditions	15
3. Results From LTV - Sodium Jet Discharge Tests	17
4. Summary of UO ₂ Aerosol Generator Test Data (LTC)	26
5. Summary of $\beta\alpha$ Values for Comparison of HAA-3 With Experiments	30

FIGURES

1. Pressure-Rise Comparison	12
2. LTV Sodium Jet Discharge Test	16
3. Burning Time of Sodium Droplets in an Air Environment	22
4. Burning Time of Sodium Droplets in a 5% Oxygen Environment	22
5. Wire-Wrapped, Tantalum-Sheathed, 3-Pin Heater	
a. Overall View	38
b. Closeup of Wire Wrap	38
c. Wire-Wrap Location at End of Heated Zone	38
6. Traces for 16-kw Total Power Boiling Run (3 wire-wrapped pins)	39
7. Bulk Fluid Temperature Traces for 16-kw Total Power Boiling Run (3 wire-wrapped pins)	40
8. 3-Pin Burnout Data	42
9. Dryout Heat Flux vs Static Pressure in Test Section	43
10. Subcooling vs Local Burnout Heat Flux	44

FIGURES

	Page
11. Traces for Burnout at 32.4-kw Total Power	45
12. Bulk Superheat vs Velocity for Small-Annulus, Single-Pin Test Section	46
13. Bulk Superheat vs Heat Flux for Two Test Sections With Different Annuli	48
14. Bulk Superheat vs Reynolds Number	50
15. Wall Superheat vs Velocity	52
16. Thermal to Mechanical Energy Conversion Efficiency vs Energy Density in UO_2	55
17. UO_2 Particle Size Distribution	55
18. Fine Particle Fraction vs Energy Density in UO_2	55

Program: Reactor Development		
AEC Task: 6-D, -E, and -F - Nuclear Safety, Gaseous Effluents, Sodium Fires		
Project Manager: H. A. Morewitz		
Reporting Period: Government Fiscal Year 1971	189A: 13242	
General Order: 07702	Subaccount: 31111	Category: 04-60-40-02.1

Principal Contributors: R. L. Koontz, R. P. Johnson, C. T. Nelson,
L. Baurmash, M. Silverberg, E. U. Vaughan, M. Heisler

I. PROJECT OBJECTIVES

The general objective of this project is to develop experimentally verified analytical models for postulated LMFBR accidents involving release and transport of energy and aerosols (sodium, PuO_2 , and fission products) in support of: (1) FFTF safety development needs, and (2) LMFBR Demonstration Plant safety analysis, engineered safeguards design, and siting. Postulated LMFBR accidents under consideration by this project include sodium pool and spray fires, core disassembly accidents, and fuel accidents. Information derived from this project is essential to the realistic assessment of FFTF-LMFBR accident consequences, required for placing meaningful limits upon the design pressure and leak rates of containment barrier, as well as the site boundary. The objectives of this project correspond to those of Tasks 10-2.6 and 2.7 of the "LMFBR Program Plan, Section 10, Safety" (WASH-1110).

II. TECHNICAL PROGRESS DURING FISCAL YEAR 1971

A. PUBLICATIONS

A topical report, AI-AEC-12977 (1970), "Aerosol Modeling of Hypothetical LMFBR Accidents," by R. L. Koontz, L. Baurmash, M. A. Greenfield, C. T. Nelson, D. F. Hausknecht, E. U. Vaughan, M. Silberberg, and H. A. Morewitz, was published.

Four papers were presented at the USAEC Air Cleaning Conference in Richland, Washington, August 31 to September 3, 1970. The papers were: (1) "Characterization of Energy Release and Aerosol Behavior of Sodium Spray Fires," J. Granger, C. Nelson, and M. Silberberg, (2) "Behavior of Iodine in the

Presence of Sodium Oxide Aerosols," L. Baurmash, C. Nelson, J. Granger, and R. Koontz, (3) "Measurements of Particulate Filtration Efficiencies of Building Materials," C. Nelson, J. Granger, R. Koontz, and L. Baurmash, and (4) "Comparison of Aerosol Experiments to Models Used in Reactor Siting Evaluation," M. Greenfield, R. Koontz, R. Johnson, and H. Morewitz.

A paper, "Effects of Aerosol Agglomeration on Reactor Dose Evaluations," by R. L. Koontz, L. Baurmash, and H. Morewitz, was presented at the Fifth Annual Health Physics Society Midyear Topical Symposium in Idaho Falls, Idaho, November 3-6, 1970.

A paper, "Comparison of Experiment and Theory for the Coagulation of Aerosols," by M. A. Greenfield, R. L. Koontz, and D. F. Hausknecht, was published in the Journal of Colloid and Interface Science, Volume 35, No. 1 (January 1971).

A paper entitled, "Approximation Solution of Equations for Aerosol Agglomeration," by E. Richard Cohen and Edward U. Vaughan, was published in the J. of Colloid and Interface Science, Volume 35, No. 4 (April 1971) pp 612-623.

B. SPRAY-BURNING EXPERIMENTS

1. STV Spray Fire Experiments

A series of spray-burning experiments were run in the Spray Test Vessel (STV), to determine the effects on sodium spray burning in controlled low-oxygen environments. During the test series, the following variables were held constant: (1) mass of sodium introduced, 71 gm, (2) sodium preheat, 1000°F, (3) nozzle size, 20-mil impinging jet, and (4) vessel geometry, 440ℓ, with nozzles directed vertically downward. Controlled variables included: (1) oxygen concentration, 5, 1, and 0%, and (2) initial humidity, 50 to 10⁴ wppm. Variables observed during each test included: (1) pressure rise, (2) gas temperature, (3) oxygen consumption, (4) combustion product species, (5) sodium burning efficiency, and, on specific tests, (6) resulting sodium droplet size and final humidity concentration. During the series, several tests resulted in either plugged nozzles which terminated the test, or partially plugged nozzles which produced intermittent sprays. Data of these tests are not reported.

The preheat and transfer subsystem of the STV was modified to allow rapid duplicate tests to be run. This modification consisted of replacing the previously used 1-l preheat and transfer tank with detachable 500-cc bombs, each of which was preloaded with a known quantity of sodium. This eliminated several steps in the pretest procedures, and permitted a more rapid sequence of tests to be run.

A free-oxygen analyzer was developed to perform rapid analysis of aerosol samples taken during a spray fire, to determine the amount of sodium peroxide present in a sample.

Observed and computed parameters are shown in Table 1. From the data in Table 1, it can be seen that the adiabatic pressure function, which includes the sensible heat of nonreacted sodium, is insensitive to the initial humidity in the range to be encountered in inerted LMFBR vaults.

The simplicity of these spray geometries has led to an improved understanding of the heat transfer mechanisms. Although a verified model for calculating spray-burning rate constants for sodium spray droplets is not presently available, a heat balance can be made on the results of a spray fire. This balance results from summation of heat source terms during a fire, which are: (1) heat due to combustion, (2) sensible heat, and (3) heat of reaction due to water vapor. The first term, combustion heat (Q_C), is based on the observed oxygen consumption, which reflects combustion product ratio:

$$Q_C (\text{Btu}) = M_{O_2} (6.5 f_p + 11.25 f_m) \times 10^3, \quad \dots (1)$$

where:

M_{O_2} = mass of oxygen used (lb)

f_p = fraction peroxide

f_m = fraction monoxide.

The sensible heat term is based upon heat transfer from the unburned sodium (M_{Na}) to the system:

$$Q_L (\text{Btu}) = M_{Na} C_p \Delta T, \quad \dots (2)$$

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

Test No.	Initial Conditions			Results					Calculations										
	Oxygen (%)	Humidity (ppm)	Sodium Released (gm)	Peak Pressure		Oxygen Consumed (%)	Sodium Reacted to Na ₂ O ₂ (%)	Sodium Consumed (gm)	Adiabatic ΔP (psig)			Adiabatic ΔP/gm Na (psig/gm)				Efficiency ($\frac{\text{Na Consumed}}{\text{Na Released}}$)	$\frac{\text{O}_2 \text{ Consumed}}{\text{Initial O}_2}$	Total ΔP from Computed Q _T (psig)	
				Time of (sec)	Observed Pressure Rise (psig)				From Oxygen Consumed	From Sensible Heat	Total	Released		Consumed					
												From Oxygen Consumed	Total	From Oxygen Consumed	Total				
S2TA	5.28	140	66.0	17.5	10.6	3.73	80	41	51	1.2	52.2	0.77	0.79	1.25	1.27	0.62	0.45	52.2	
S2TC	5.5	4400	74.8	12.5	13.2*	2.45	54	40.7	40	1.4	41.4	0.54	0.55	1.0	1.1	0.51	0.445	-	
S2TD	5.0	50	69.1	12.1	9.9	3.4	68	40.5	50	0.84	50.8	0.73	0.73	1.2	1.2	0.59	0.68	40.6	
S2TF	5.0	1500	70.1	12.4	6.6	2.1	51	28.5	33	1.9	34.9	0.47	0.49	1.15	1.22	0.41	0.42	38.2	
S2TH	1.1	420	69.4	9.1	2.2	0.15	14	2.52	2.7	4.8	7.5	0.039	0.107	1.07	3.0	0.036	0.136	3.8	
S2TI	1.0	10 ⁴	74.8	12.0	3.4	0.2	0	3.62	4.0	4.5	8.5	0.054	0.114	1.1	2.35	0.048	0.2	7.65	
S2TJ	1.1	290	72.7	6.8	5.3	0.15	5	2.64	3.0	4.0	7.0	0.042	0.096	1.15	2.65	0.036	0.136	10.8	
S2TK	1.0	740	74.4	9.1	3.9	0.1	9	1.7	2.0	5.3	7.3	0.027	0.098	1.17	4.3	0.023	0.1	7.49	
S2TL	1.0	170	69.6	11.6	3.8	0.1	9	1.7	2.0	4.4	6.4	0.029	0.092	1.17	3.8	0.025	0.1	8.6	
S2TM	<0.1	640	73.4	8.0	4.48	0	-	0	-	4.6	-	-	-	-	-	-	-	8.6	
S2TN	<0.1	480	71.4	6.0	2.58	0	-	0	-	3.9	-	-	-	-	-	-	-	6.4	

*Estimated

Table 1. Spray-Burning Experiments

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

where:

M_{Na} = mass of unburned sodium (lb)

C_p = specific heat of sodium

ΔT = initial temperature of sodium minus final temperature of gas in the vessel at the end of the spray period.

Heat due to the reaction of sodium with water vapor is found by

$$Q_{H_2O} \text{ (Btu)} = (\Delta \text{PPM-H}_2\text{O}) M_{\text{gas}} (6300 \text{ Btu/lb}) , \quad \dots (3)$$

where:

$\Delta \text{PPM-H}_2\text{O}$ = water vapor consumed (wppm)

M_{gas} = mass of gas in chamber (lb).

Q_L , Q_C , and Q_{H_2O} are compared to the total (Q_T) generated in the vessel by computations based on the pressure rise curve obtained during the spray. The following simple relation is adequate, if the mass of sprayed sodium enters linearly in a time (τ):

$$\Delta P = \frac{14.7 \Delta T}{540} = \frac{Q_T}{\tau} \frac{\theta_o}{\alpha_a} [1 - \exp(-t/\theta_o)] \times \frac{14.7}{540} , \quad \dots (4)$$

where:

$$t \leq \tau$$

t = time (hr)

θ_o = vessel time constant = α_a / Ah (hr^{-1})

h = overall heat transfer coefficient ($\text{Btu}/^\circ\text{F-hr-ft}^2$)

A = area of contact between gas and steel (ft^2)

$\alpha_a = M_{\text{gas}} C_{v_{\text{gas}}} \text{ (Btu}/^\circ\text{F)}$

$C_{v_{\text{gas}}}$ = specific heat of gas at constant volume ($\text{Btu/lb-}^\circ\text{F}$)

Q_T = heat released (Btu) due to spray in a time (τ).

7702-45278

Figure 1. Pressure-Rise Comparison

Equation 4 is particularly useful when $\tau \gg \theta_o$, for then the maximum pressure at τ is in equilibrium (saturated), allowing one to obtain θ_o at the time when the pressure is equal to $0.62 \times \Delta P_{\max}$. Thus, Q_T can be determined. If the spray terminates before saturation, one can use a value for Q_T based on the sum of the combustion, water, and sensible heat, together with τ , the time of input, to obtain a fit of the pressure data. The equation can also be solved simultaneously for $\Delta P_{\max}$ from the ΔP vs time data. There is only one combination of Q_T and θ_o which will fit the observed pressure data. Table 1 shows how the estimates of Q_T obtained from the pressure curves compare to those obtained by the summation method.

Figure 1 shows typical comparisons of Equation 1 and the test data.

The two spray tests in zero oxygen, shown in Table 1, gave pressure-rise curves whose computed time constants were 5.4 and 2.7 sec, indicating a gas-to-wall heat transfer coefficient of ~ 3.8 and $7.4 \text{ Btu}/^\circ\text{F}\text{-ft}^2\text{-hr}$ for the two tests, respectively.

It was determined, after some study, that the spray time, 7.5 and 5.5 sec, should not be used to compute the heat transfer from the sodium to the gas, nor should the fall time of the drops be used to estimate this value. Droplets which are 135μ in diameter lose 63% of their heat in ~ 0.04 sec, and 90% of their heat is lost, 0.08 sec after the spray enters the vessel, based on a theoretical heat transfer coefficient of 60 to $80 \text{ Btu/hr}\text{-ft}^2\text{-}^\circ\text{F}$, for heat transfer from a sphere to a gas in forced convection. If the spray time is used to estimate the heat transfer time, the heat transfer coefficient would be $\sim 1 \text{ Btu/hr}\text{-ft}^2\text{-}^\circ\text{F}$, which is almost two orders of magnitude lower than coefficients computed from theory.

By analyzing the pressure-time histories of the spray vessel, it has been possible to determine the total energy balance (heat in = heat loss + heat remaining in the gas). Previously, the energy release computations were based on the oxygen depletion and the ratio of peroxide and monoxide produced during the oxidation. This had been necessary, because the STV system is not adiabatic, especially for the long spray times which are used, and because the time constant of a pressure decay curve following the termination of the spray (θ_a) at τ differs from that during the spray (θ_x). This change in time constant (inverse of the heat transfer coefficient) must be due either to the increased movement of the gas relative to the walls during the spray, or to radiation losses contributed by

the high temperatures at the burning droplet surface. In the 5% O₂ spray fires, it can be assumed that the time constant during the spray is an effective one, which is related to the time constant after the spray (θ_a) by

$$\theta_o = \frac{\theta_x \theta_a}{\theta_x + \theta_a} \quad \dots (5)$$

Typical values are $\theta_o = 2.7$ sec, $\theta_a = 9$ sec, and $\theta_x = 3.8$ sec. The steel surface area is 37.5 ft² in the 5-ft test vessel, and the computed heat transfer coefficient from gas to wall is 2.3, 5.5, and 7.8 Btu/°F-hr-ft² for the time constants of 9, 3.8, and 2.7, respectively.

It should be noted in Table 1 that, over a wide of range of humidity contents (including FFTF HTS cell vault operating conditions), the effect of humidity on sodium spray-burning characteristics in low-oxygen environments does not appear to be significant.

C. SIMULATIONS OF SODIUM JET DISCHARGE

1. Inerted Primary Heat Transfer System Cells

Test planning was conducted for experimental studies to characterize the behavior of a sodium jet which discharges into an inerted (oxygen content up to ~2 vol %) LMFBR primary heat transfer system cell following a hypothetical pipe-rupture accident. This information will be used, in conjunction with appropriate analytical modeling, for realistic engineering analyses of pipe-rupture accident consequences for LMFBR primary cell design pressure criteria. Initial emphasis will be placed on obtaining sufficient information to confirm the preliminary evaluation⁽¹⁾ of the design pressure for the FFTF HTS cells, which indicates lower than upper-limit pressure rises for a particular jet discharge, and subsequent impingement configuration. The test program is designed to study jet breakup and droplet formation, as well as the heat transfer characteristics of the resulting breakup phase, for various rupture and jet impingement configurations. Information on breakup characteristics will be obtained from scaled water jet simulation tests, while scaled sodium jet simulations will provide modeling of integral effects of sodium droplet - gas heat transfer and bulk

gas mixing. Preparations for the water jet simulation tests were essentially complete at the close of the fiscal year.

2. Air Containment

Several preliminary experiments were conducted in the LTV to obtain initial information on the burning characteristics of a vertical sodium jet discharging into an air-filled enclosure, followed by jet impingement on a horizontal surface at some distance from the point of sodium injection. Such experiments are of interest to the assessment of the consequences of a sodium jet released into the FFTF outer containment following the hypothetical core disassembly accident (HCDA). In this case, it is postulated that the residual gas bubble from the HCDA lifts one of the reactor head access plugs which penetrates the operating deck, and is followed by a sodium jet discharging into the outer containment. These scoping experiments were directed toward a preliminary evaluation of the fraction of released sodium which could burn (burning efficiency) during the total time that the initial jet, and any subsequent droplet formation due to breakup, are airborne in the containment. Sodium jet discharge conditions supplied by WADCO for a 1-ft diameter plug opening, following a 600 Mw-sec (work) HCDA, are shown in Table 2.

TABLE 2
SODIUM JET DISCHARGE CONDITIONS

Time (sec)	Velocity (fps)	Cumulative Ejected Mass (lb)
0	1	0
0.2	161	1434
0.4	114	2530
0.6	80	3304
0.8	51	3825
1.0	26	4134

A jet injection system was assembled from high-pressure components. Figure 2 shows the system used. It consists of a heated pressure bomb (to contain the hot sodium) leading to a heated pipe which changes the direction of sodium flow, so that it is vertically upward. The other end of the sodium bomb is

LTV JET SPRAY
ORIENTATION

LTV JET SPRAY

7702-45279

Figure 2. LTV Sodium Jet Discharge Test

connected to a 14-l pressure reservoir which is connected to a nitrogen bottle through a regulator. Between the pressure reservoir and the sodium bomb is a solenoid charge valve, a solenoid vent valve, and a pressure transducer. The two solenoid valves are arranged so that the vent valve is normally open, and the charge valve closed. A timing signal closes the vent valve and opens the charge valve, allowing pressurized nitrogen gas to flow into the sodium bomb, driving liquid sodium ahead of it. At the end of the timing signal, the drive valve closes and the vent valve opens, allowing the gas pressure to decay and decrease the sodium outlet velocity. The pressure transducer records the gas pressure driving the sodium out of the bomb. On the outlet pipe, a calibrated EM flow-meter is installed to record the sodium velocity in the pipe. The completed system was tested, using water, to verify timing pulse duration and to calibrate the pressure transducer.

A 2-l pressure bomb, containing sodium, was mounted in the system and installed in LTV. An impact plate was mounted 23 ft directly above the exit tube. Two tests were performed, using a sodium charge of 5.6 lb. The results are shown in Table 3.

TABLE 3
RESULTS FROM LTV - SODIUM JET DISCHARGE TESTS

Parameter	Test 1	Test 2
Initial Humidity (ppm)	7400	8000
Final Humidity (ppm)	3500	85
Sodium Temperature (° F)	1000	1000-1100
Initial Sodium Drive Pressure (psig)	250	305
Weight of Sodium Injected (lb)	3.8	5.3-5.5
Estimated Peak Velocity (ft/sec)	50	100
Maximum Observed Chamber Pressure Rise (psi)	3.3	11.7
Reaction Products (% Na ₂ O)	100	91-96
Sodium Consumed During Spray (lb)	1.0	3.6
Time to Reach Peak Pressure (sec)	3.5	2.0
Burning Efficiency (lb burned/lb spray)	0.26	0.66
Peak Aerosol Concentration (μgm Na ₂ O/cc)	7.2	17.1
Theoretical Peak Chamber Pressure Rise (psi)	12.5	17.7

In Test 1, a large amount of the ejected sodium did not hit the impact plate. This was confirmed by photographic documentation of the sodium jet exiting from the pipe. The stream was continuous and nonluminous. When the drive valve was closed and the pressure allowed to decay, the column was observed to collapse on itself, and a large fraction of the sodium fell to the floor. There was no observed breakup of the jet as it exited the pipe during the test.

A larger fraction of the column in Test 2 hit the impact plate, as evidenced by a 4-ft diameter oxide deposit on the plate. The temperature reading of the top plate reached 2000°F in 1 sec, indicating that burning on the plate could have contributed to the peak pressure rise. Motion pictures of the sodium jet in this test show that some breakup of the jet did occur. Droplets which fell from the impact plate were as large as 1/2 in. As they fell, a visible oxide trail was observed. These droplets were large enough so that, when they hit the floor, they were not completely burned.

If all the released sodium in these tests had been oxidized in the jet, the upper-limit thermodynamic pressure rises would have been 12.5 and 17.7 psig respectively.

D. MODELS OF SODIUM SPRAY BURNING IN AIR

Methods for predicting realistic pressure rises in air-filled containment is required in test-of-containment analyses of the sodium releases resulting from hypothetical LMFBR accidents. Evaluation of such conditions are currently of interest to the FFTF for postulated releases from the reactor head. Once the degree of dispersion and the geometry of a given release configuration is specified, it is necessary to define the quantity of the released sodium which burns during its airborne history, in order to compute energy transfer to the gas, and hence pressure rise. Realistic estimates of sodium combustion must be based upon an appropriate general model for computing the burning rate of sodium droplets in air over a broad range of parameters. Extensions and appropriate modifications to such a model are also of interest to accident conditions involving containment spaces having a reduced-oxygen atmosphere.

Burning rates of nonstationary sodium droplets in air have been calculated, using the combustion theory proposed for liquid propellants by Lambiris et al.⁽²⁾ The approach proposed by Lambiris et al. is described in the following section.

1. Theory of Single-Droplet Combustion

a. Nonconvective Theory

It has been confirmed experimentally that a droplet's mass burning rate is directly proportional to its diameter. Analytically, this is expressed as follows:

Mass of the droplet (m),

$$m = \frac{\pi}{6} D^3 \rho_l \quad \dots (6)$$

Differentiating to get rate of change of mass,

$$\frac{dm}{dt} = -\frac{\pi}{2} D \rho_l \frac{dD^2}{dt} \quad \dots (7)$$

$$= \frac{\pi}{4} D \rho_l (2k')$$

$$= \frac{\pi}{4} D \rho_l k \quad \dots (8)$$

where:

$k' = -\frac{dD^2}{dt}$, is commonly referred to as the evaporation coefficient.

$$k = 2k'.$$

The linear regression rate implied by Equation 8 has been found to apply to a wide range of convective conditions, from no convection to forced convection at $Re \approx 2000$.

Droplet combustion theory is based on spherical symmetry which implies no convection. An expression for spherico-symmetric droplet combustion was derived by Spalding,⁽³⁾ through consideration of the molecular diffusion of reacting species into the flame front:

$$k = \frac{8\lambda}{\rho_l C_{p_l}} \ln(1 + B) \quad \dots (9)$$

where

$$B = \frac{\Delta H_c Y_o}{\Delta H_v r} + C_{p_g} \frac{(T_f - T_1)}{\Delta H_v} , \quad \dots (10)$$

C_{p_l} = specific heat of sodium

ΔH_c = heat of combustion

ΔH_v = heat of vaporization (ΔH also includes the heat required to heat the particle to the vaporization temperature)

Y_o = mass fraction of oxidant at infinite distance from the particle surface

r = stoichiometric mixture ratio

T_f = flame temperature

T_1 = vaporization temperature

λ_g = mean coefficient of thermal conductivity of gas in combustion zone

C_{p_g} = mean specific heat of gas in combustion zone

ρ_l = density of the droplet.

b. Forced Convection

The relationships between conditions of forced convection and no convection may be developed from a heat balance at the droplet surface, neglecting radiation.

$$\Delta H_v \frac{dm}{dt} = - \pi D^2 h \Delta T , \quad \dots (11)$$

where:

h = surface heat transfer coefficient

ΔH_v includes sensible heat, as well as latent heat of vaporization.

Recognizing that Nusselt number,

$$Nu = \frac{hD}{\lambda_g} , \quad \dots (12)$$

$$\frac{dm}{dt} = -\frac{\pi g D \Delta T}{\Delta H_v} \text{Nu} \quad \dots (13)$$

Written for no convection and incorporating Equation 8, Equation 13 gives

$$(\text{Nu})_s = \rho_l k \Delta H_v / 2 \lambda_g \Delta T, \quad \dots (14)$$

where $(\text{Nu})_s$ refers to the Nusselt number for stationary conditions. It can be related to the Nusselt number for forced convection by the following empirical argument. It has been found, by various investigators, that, on the basis of their experimental data, the Nusselt number for forced convection droplet combustion can be described by the equation

$$\text{Nu} = (\text{Nu})_s (2 + 0.6 \text{Pr}^{1/3} \text{Re}^{1/2}) \quad \dots (15)$$

Here the assumption has been made that the Schmidt number for mass transfer is equal to the Prandtl number (Pr) for heat transfer. It follows, from Equations 13, 14, and 15, that

$$\frac{dm}{dt} = \frac{-\pi \rho_l D k}{8} (2 + 0.6 \text{Pr}^{1/3} \text{Re}^{1/2}) \quad \dots (16)$$

This equation, with k determined by Equations 9 and 10, is useful for determining droplet combustion rates under widely different convective conditions.

2. Calculation of Single-Droplet Combustion Rates for Forced Convection

Combustion rates for various droplet diameters and various convective velocities in air were calculated for the set of conditions:

$$T_f = 3260^\circ \text{F}$$

$$T_l = 1660^\circ \text{F}$$

$$C_{P_l} = 0.296 \text{ Btu/lb-}^\circ \text{F}$$

Figure 3. Burning Time of Sodium Droplets in an Air Environment

7702-45280

Figure 4. Burning Time of Sodium Droplets in a 5% Oxygen Environment

7702-45281

$$\rho_l = 51 \text{ lb/ft}^3$$

$$\Delta H_c = 4000 \text{ Btu/lb Na}$$

$$\Delta H_v = 1650 + 0.3 (1650 - 1050) = 1830 \text{ Btu/lb Na}$$

$$r = \text{moles Na/moles O}_2 = 4.0$$

$$Y_o = 0.232 \text{ lb O}_2/\text{lb air}$$

$$\lambda_g = 0.064 \text{ Btu/ft-hr-}^\circ\text{F}$$

$$C_{p_g} = 0.293 \text{ Btu/lb-}^\circ\text{F}$$

The results of the burning rate calculations in an air environment are summarized in Figure 3.

Figure 4 shows the relation of particle lifetime, for multiples of the 135- μ droplets used in the STV spray fires studies in 5% O₂ environments, as a function of particle velocity. The terminal velocity is ~15, 6.6, and 3 ft/sec for the 540-, 270-, and 135- μ droplets respectively. As can be seen in the figures, the particle lifetime of the droplets used in the STV down spray tests (135 μ) is small, compared to the spray times (5 to 20 sec) and the time to fall the height of the chamber (5 ft at 3 ft/sec velocity = 1.6 sec).

The prime uncertainty in both Figures 3 and 4 is the flame temperature, for which a model exists, but remains unresolved at present. The model neglects mass transfer to the surface and assumes vaporization as the sole means of reaction. This is probably not correct for low oxygen environments.

E. MODELS OF SODIUM JET DISCHARGE

Consideration of realistic sodium release dispersions and geometrics, for estimating containment pressurization following certain hypothetical LMFBR accidents, requires appropriate models for characterizing the actual behavior of the discharge and subsequent breakup of sodium. Without such models, analyses must involve use of unrealistic conservative assumptions concerning the sodium release, such as exceptionally small droplet size and large effective containment gas mixing volumes, leading to upper-limit pressure rise estimates. Realistic descriptions of sodium jet discharge, over a range of initial conditions are of interest to hypothetical accident consequence analyses for inerted cells (pipe-rupture accident), as the input to the sodium-gas heat transfer model, and for air-filled containment (HCDA), as the input to the sodium droplet burning model.

A preliminary model of sodium jet discharge was formulated for a vertical jet-on-ceiling configuration, resulting from a hypothetical guillotine pipe rupture in the FFTF HTS cell.⁽¹⁾ Recent effort was initiated to evaluate possible improvements to the preliminary models utilized for jet hydrodynamics and sodium droplet-to-gas heat transfer, in conjunction with the planned test program.

In addition, other possible configuration of sodium pipe ruptures, and of the resulting sodium jets, have been reviewed, with respect to the rate at which they might transfer heat to the ambient gas. The case of a simple "guillotine" rupture, sending a large smooth jet against a wall or ceiling, was potentially the most severe, until it was realized that, at moderate velocities, the impinging jet does not splash, but forms a sheet, flowing smoothly over the surface. If the surface is a ceiling, the liquid will contact the gas by "raining" from the edge of the sheet, but this is a far less efficient contact than a volume-filling spray.

If the jet impinges instead on another pipe, it will again flow smoothly part of the way around the pipe, and then continue its flight. The process of separation of the flow from the pipe will probably produce some spray, and the distinction of the jet from a cylindrical to a more sheet-like configuration will reduce its stability. However, the resulting contact with the gas does not appear to be better than that of the rain from the edge of a sheet on a ceiling, since only part of the sodium is likely to spray, and the rest may reach walls, floor, or ceiling before its instability is effectively manifested.

Other types of rupture, such as longitudinal or transverse cracks, will no doubt emit sheet-like jets that break up at once into sprays. But, in such cases, the rate of flow of the sodium through the narrow apertures will be low, and again thermal contact with the gas will be low, relative to the total sodium flow in the pipe. An intermediate configuration arises, if a pipe is sheared through, but the sheared ends are only partly displaced. If the displacement (supposed entirely, or almost entirely, transverse) is small, there is a spray, but not much sodium; in the opposite case of large displacement, the "guillotine" configuration is approached, with much sodium, but no spray; in between, it is likely that the spraying is reduced more rapidly than the sodium release increases, and that the severity is thus reduced.

The order of decreasing thermal contact between sodium and gas appears to be:

- 1) Sheared pipe with large displacement ("guillotine" rupture), with jet impinging on ceiling.
- 2) Some rupture, with jet impinging on another pipe
- 3) Slits or cracks, emitting sheets that form sprays
- 4) Sheared pipe, with partial displacement.

F. LABORATORY TEST CHAMBER (LTC) AEROSOL EXPERIMENTS

1. UO₂ Vaporization Generator Tests

Performance evaluation of a technique for generating UO₂ aerosols at high rates by arc-vaporization continued with the testing of a number of designs and procedures in the 40-ft³, 6-ft high LTC. The most successful apparatus to date consisted of a steel pot containing a compressed mixture of UO₂ pellets and powder. In the center of this charge was a hollow steel tube containing UO₂ powder. The other electrode consisted of three tungsten electrodes connected to the power supply. The procedure was to advance the steel pot containing UO₂ until the center tube contacted the three tungsten electrodes. Then, the power supply was adjusted until 50 to 100 amp were flowing, and this condition was maintained for 2 min. The steel tube acted initially as a resistance heater, so that the temperature of the UO₂ charge was increased. Then, the current was increased to 150 amp at 40 v, and the steel pot was retracted from the tungsten electrodes until an arc was struck. As the UO₂ melted and flowed to the bottom of the pot, the pot was advanced to maintain a good arc. While the procedure appeared to be satisfactory, it was noted that a portion of the molten UO₂ was left behind in the pot. A new pot has been fabricated with a conical bottom, so that the molten UO₂ will flow to the center of the pot and reach the arc, where it can be vaporized. This pot has not yet been tested.

During these LTC tests, uranium oxide aerosol data for UO₂ charges of 200 to 250 gm in the steel pot were obtained, and the results are summarized in Table 4.

TABLE 4
SUMMARY OF UO_2 AEROSOL GENERATOR TEST DATA (LTC)

	Test No.			
	71-3	71-4	71-5	71-6
UO_2 Released as U_3O_8 (gm)	47.8	81.0	175.0	52.0
Arc Time (min)	2.0	2.0	11.0	12.0
Peak Air Concentration of U_3O_8 (gm/cm^3)	30.9	35.0	43.5	18.5
Time of Peak Concentration (min)	1.0	1.0	10.0	4.0
Weight of Fallout (gm)	41.1	78.0	87.0	47.0
Weight of Wall Plating (gm)	6.7	3.0	88.0	5.0
Initial T_{50} of Air Concentration (min)	5.0	3.5	3.0	7.0

The arc in Test 71-6 was unstable, and had to be restruck manually several times, which is the reason for the long arcing time, and the probable cause of the lower release fraction and air concentration.

2. Interaction of Molecular Iodine and Sodium Oxide Aerosols

Iodine vapor scavenging by sodium oxide particulates was shown^(4,5) to be strongly influenced by the presence of the normal dust concentration in air. The dust particles compete with the oxide for the iodine vapor. If the iodine is released into dusty air before the oxide, then agglomeration occurs mainly between the iodine and the dust-oxide mixture, rather than between the iodine and oxide. The interaction mechanisms of iodine vapor and sodium oxide aerosol are of importance in the analyses of a fuel handling accident, as well as for the analysis of the effect of iodine scavenging and transport following the HCDA, when sodium oxide is present in the aerosol phase.

3. Aerosol Leakage Through Containment Materials

One of the assumptions currently used in LMFBR safety analysis is that particulate aerosols, such as UO_2 - PuO_2 and sodium oxides, leak through concrete containment structure as though they were gases, without any attenuation by filtration within the leak path. Results from preliminary experiments^(4,6) indicate that this assumption is unrealistically conservative, by at least several orders of magnitude. A theoretical basis for such observations has recently been reported.⁽⁷⁾

G. LARGE TEST VESSEL (LTV) AEROSOL EXPERIMENTS

1. Sodium Oxide Aerosols

Two aerosol modeling experiments (AM-1, AM-2) were conducted in the 2200 ft³, 30 ft high LTV in which 15 lb of sodium were burned in 21% O₂. The conditions for both tests were identical, except for the initial humidity, which differed slightly. The results for both tests have been reported in detail.⁽⁸⁾

During these tests, fallout and cascade impactor samples were taken, specifically to evaluate the size and shape of the sodium oxide aerosol and to estimate the changes in density due to agglomeration. Estimates of the particle agglomerate volumes were made, using photographs of the deposits on each cascade impactor stage. From these volumes, and the calibrated aerodynamic diameter constant for each stage, the apparent density of the particle agglomerate was computed. It was found that a range of densities could be found for each stage; but a trend was indicated, that, as the aerodynamic diameter was increased, the apparent density decreased.⁽⁸⁾ These data indicate that Stoke's settling velocities calculated for agglomerates using the normal density would be erroneous, and such velocities should be corrected for density changes, as is presently attempted in the HAA-3A model.

Microscopic observations of the particle agglomerate which settles out from the aerosol phase show the presence of particles larger than 100 μ . The extent of particle growth observed for such agglomerates can only occur with mechanisms such as gravitational agglomeration with appreciable collision efficiencies, or collision radii.

2. Uranium Oxide Aerosols

Previous aerosol modeling experiments in LTV have used sodium oxide from sodium fires as the source of aerosol particles. In order to verify the acceptability of the HAA-3A model for reactor accident analyses, modeling experiments are being performed using UO₂ as the aerosol source. The first such modeling experiment in LTV, UAM-1, has been performed. In this experiment, arcs were struck in each of three UO₂-filled crucibles in sequential fashion, over a period of 7.5 min, for the three units. The power supply was programmed so that a current of 50 amp was flowing when the tungsten cathode was in contact with

the steel pin in the crucible. The pot contact was withdrawn until the arc was struck, at which time the current was increased to 150 amp at 40 v. (The future design of this system will utilize three separate power supplies, so that the three crucibles can be operated simultaneously, and release the vaporized UO_2 in shorter time periods at higher rates than this first attempt.)

Analysis of the data shows that a total of 240 gm of material was released, yielding a released concentration of $4 \mu\text{gm}/\text{cm}^3$. X-ray fluorescence analyses of air and fallout samples, taken at different times, indicated that the aerosol was composed of 25 wt % of uranium oxide, with the balance being iron oxide. The ideal density of this mixture is computed to be $5.8 \text{ gm}/\text{cm}^3$. A number of cascade impactor samples were taken. These samples indicated the growth of the aerosol due to the agglomeration of the initial particles. The measured aerodynamic diameter of the particle size sample taken at 3 min, together with the calculated ideal density of the mixture, gives a mass median diameter for the aerosol of 0.58μ . Examination of electrostatic precipitator samples show the aerosol to be in the typical chain structure, formed from small spheroids co-agglomerated with larger spheroids of iron oxide.

H. AEROSOL MODEL DEVELOPMENT

1. Two-Compartment Aerosol Transport Model HAA-3A

Many reactor accident analyses are concerned with the transport of aerosol particles from a compartment in which they are released to a second compartment, and finally to the outer environment. HAA-3A was modified for the solution of this problem. The original version of HAA-3A was not capable of handling a source term in which both source rate and size were time variants. Therefore, it was necessary to do the secondary containment calculations in a series of steps, each step requiring calculated input mass rate and calculated particle size parameters. This mode of operation produced acceptable calculations, but was tedious and inefficient.

The new program, HAA-3B, computes an average input rate into the secondary containment volume from the mass leakage from the primary over a time step, $t_i - t_{i-1}$. The program also computes an average mass median radius, and variance for a log-normal distribution, over this time step. These computed

values are provided on punch cards, which can be used as source descriptions for secondary containment calculations. In addition to eliminating the tedious manual calculations, HAA-3B provides the time-dependent behavior of the leaked aerosol. The size distribution of the leaked mass in several compartments is also readily obtained.

2. Comparison of HAA-3 Calculations and Experiments

Comparisons were made between various aerosol experiments and calculations, using the HAA-3A model to evaluate the effect on the agreement with experiment of the two basic parameters, α and β , in the general aerosol equation. The parameter β in the HAA-3A formulation is a mean effective gravitational collision efficiency, and α is the Stokes settling velocity correction factor. Both α and β are functions of aerosol geometry. Since aerosol geometry (shape and density) is a function of material and degree of agglomeration, one expects the product, $\beta\alpha$, to vary in a systematic way with experiments of differing initial concentration and degree of gravitational agglomeration (which is related to the height of the experimental vessel).

Table 5 presents a summary of the values of the product, $\beta\alpha$, which produce the best agreement between HAA-3A model computations and experimental data from the LTV and the smaller LTC. The product, $\beta\alpha$, is presented, because it has been found to be the more sensitive factor influencing calculations; rather than β and α separately.

For theoretical reasons, one expects low initial concentration experiments, dominated by Brownian agglomeration, to have $\beta\alpha$ near 1; whereas high initial concentration experiments, with strong gravitational agglomeration effects, are expected to have $\beta\alpha$ considerably <1 . As can be seen in Table 5, this expectation is confirmed. The values of $\beta\alpha$ near unity gave good agreement on the low-density sodium oxide tests in the LTV, whereas values of $\beta\alpha = 0.25$ (sodium oxide) to 0.33 (mixed oxide) were required to give good fits to the high-concentration tests. In the LTC, the values of $\beta\alpha$ of 0.75 (UO_2 aerosols) to 1 (sodium oxide aerosols) reflect the lower gravitational agglomeration present, because of the lower height.

It is of interest to obtain values for β and α separately, however, in order to understand more fully the physical phenomena occurring. Values of α as low

TABLE 5
SUMMARY OF $\vartheta\alpha$ VALUES FOR COMPARISON OF HAA-3
WITH EXPERIMENTS

Vessel	Test	Initial O ₂ Content (%)	Released Mass Concentra- tion (μ gm/cm ³)	Measured Peak Concentra- tion (μ gm/cm ³)	Initial Aerosol Density (gm/cm ³)	Fitting Parameters ($\vartheta\alpha$)
LTV	Pool Fire No. 3	21	135	42	2.27	0.25
	4	21	130	45	2.27	0.25
	5	9.2	64	27	2.27	0.25
	6	2.0	0.64	0.60	1.0	1.0
LTV	AM-1	21	30	20	2.27	0.33
	AM-2	21	22	15	2.27	0.33
LTV	UAM-1	21	4.0	4.0	5.78	0.33
LTC	Sodium Oxide Releases	21	2 - 130	1 - 60	2.27	1.0
LTC	Uranium Oxide Releases	21	1×10^{-2} to 50	9×10^{-3} to 30	4.8 to 7.6	1 to 0.75

as 0.25 have been considered for the high-initial-concentration LTV experiments (where $\vartheta\alpha \cong 0.25$) based on values inferred from the literature.^(9,10) However, inference of values this small for α , based on Reference 9, is faulty, because the values reported are not Stokes settling velocity correction factors, but rather the ratio of apparent density of the aerosol to the ideal density. Values approaching 0.25 for density⁽⁹⁾ ratios therefore should be correctly compared to values near 0.6 for α , since α is related to the cube root of the density, rather than linearly. Values from Reference 10 may, however, be compatible with $\alpha \cong 0.25$. This uncertainty in α , of course, does not alter the goodness of fit resulting from using the product $\vartheta\alpha = 0.25$ for high-density experiments, but merely alters the choice of values for ϑ and α , separately, taken to obtain the product 0.25. Instead of considering as one limit $\vartheta = 1$, $\alpha = 0.25$, one might prefer a limit closer to $\vartheta = 0.4$, $\alpha = 0.6$, if one assumes that Lane and Stone's⁽⁹⁾ low-density data are also applicable to sodium oxide aerosols. The choice of $\alpha = 0.25$ as a

lower limit would be acceptable, if sodium aerosols were described by the lowest density data in Reference 10 (equivalent to ρ/ρ_0 approaching 0.015).

Preliminary work to date suggests that one should also make a theoretical correction to values of α derived empirically from experiment, in order to compare such values with those estimated from theoretical models currently available. The gravitational collision rate based on the model of Saffman and Turner⁽¹¹⁾ contains a factor $(r_1 + r_2)^2$, where r_1 and r_2 are the radii of the colliding particles. These radii, as evaluated by HAA-3A, are those of spheres having the correct mass of the aerosol particles and the ideal density of the aerosol material. If the Stokes velocity correction factor (α) is interpreted as defining an equivalent sphere of correct mass and some effective radius and density, then the radius defined previously should be increased by a factor of $1/\alpha$, and thus the factor $(r_1 + r_2)^2$ by the factor $1/\alpha^2$. It has been convenient to include this correction factor in α , for lack of precise definition of the correct effective size. When this is done, it, of course, leads to higher numerical values for α (e.g., near 1). If the correction is made directly in the term $(r_1 + r_2)^2$, the value of α which gives agreement between model and experiment would be reduced by a factor of ~ 3 . The lower value of α which one would obtain by accounting for the departure from ideal, nonspherical particle shape, would result in some reduction of the difference between the theoretical and experimental estimates of α . These considerations are in the process of further investigation, along with other mechanisms that may give further clarification to differences between empirically determined mean parameter values and theoretical estimates.

3. Improvement of the Aerosol Agglomeration Code HAA-2

The HAA-2 code, which solves the aerosol agglomeration equation numerically, with no approximations other than those entailed by the need for discrete representations of continuous functions, has been largely superseded for the past year and a half by the faster HAA-3 code, which assumes a log-normal distribution, and computes it through its moments. The older code is still needed, however, both for use with unusual situations in which the distribution is manifestly not log-normal, and for verifying the validity of the log-normal assumption in more usual cases. This validity has, in fact, been verified by comparison of HAA-2 and HAA-3 for mass release concentrations up to $4 \mu\text{g}/\text{cm}^3$; but, for higher concentrations, the running time of HAA-2 becomes prohibitively long.

Since concentrations exceeding $10 \mu\text{g}/\text{cm}^3$ are important in practice, an effort was made to reduce the running time of HAA-2. Linear interpolation and Gaussian quadrature, employed in the evaluation of integrals of the integro-differential agglomeration equation, were replaced by cubic interpolation and Euler-Madaurin quadrature; and first-order Euler integration of the differential equations in time was replaced by the third-order Adams-Moulton method. These changes did not solve the problem, but they narrowed the range of search for the source of the remaining difficulty, which was found to be that the time increment was kept short by the requirement of accurately representing the rapid scavenging of a few very small particles by the rest of the aerosol. This requirement was relaxed by omitting these particles from the system, once this concentration has become negligible. Tests, though still at an early stage, indicate that this simple device has increased the time increment, and hence decreased the running time, by at least an order of magnitude.

The HAA-2 code is also being improved by increasing the number of input options (e.g., including agglomeration mechanisms depending on turbulence, and improving the representation of Brownian agglomeration, so as to extend its range of validity toward smaller particles) and by introducing the extensive output edits already employed in HAA-3.

I. FFTF-SAR REVIEW SUPPORT

Technology being developed under this project found considerable application during the year, in support of the review of the PSAR for the FFTF Project by the AEC regulatory groups. Support to HEDL by Task 6-D, -E, -F project personnel was provided in the following areas: (1) special calculations for extension of PSAR evaluations, (2) assistance in documenting PSAR items requiring clarification and/or additional detail by ACRS and DRL, and (3) attendance at ACRS review meetings for special presentations, and a meeting with DRL on aerosol behavior modeling.

III. EVALUATION OF EFFORT DURING FISCAL YEAR 1971

As a result of a comprehensive review and assessment,⁽¹²⁾ and subsequent evaluations during the FFTF-PSAR review, considerable progress has been made toward establishing the validity of the basic HAA-3 aerosol model as a realistic technique for describing the behavior of aerosols generated during hypothetical LMFBR accidents. Although substantial validation testing in LTV remains to be done for UO_2 aerosols and UO_2 - sodium oxide aerosol mixtures over a range of initial conditions inclusive of those for postulated accidents, the studies in LTV with sodium oxide over a wide range of mass concentrations has permitted the development of confidence in the application of the model to LMFBR inner containment. An important feature of the LTV, which minimizes the extrapolation of test results to inner containment (reactor cavity or HTS cells), is its height of 30 ft, since the key geometric parameter in the gravitational agglomeration process for aerosols is the height of the enclosed volume. Detailed comparison of the HAA-3A model with aerosol experiments over a range of conditions, including test vessel size, has empirically established the importance of the product of gravitational collision efficiency (ϵ) and Stokes settling correction factor (α). Some degree of uncertainty presently exists in defining the magnitude of each of the parameters, ϵ and α , taken separately, based upon information available in the literature. However, investigations aimed at defining the values these parameters have been started, and a number of promising mechanistic approaches have been identified for obtaining further resolution of their uncertainty. The present status concerning uncertainties in ϵ and α , however, does not detract from the good overall agreement being obtained between experiment and the basic aerosol behavior model.

The modification of the experimental geometry in the STV to a down-spray configuration has enhanced considerably the interpretation of the experimental data being generated, by eliminating indeterminate, nonsystematic effects. This will be extremely helpful, when comparing sodium spray burning and heat transfer models with spray data in this facility.

Detailed test planning and preparation for the sodium jet discharge characterization studies has developed to the point where the test program can proceed in a timely manner for FFTF HTS cell design pressure evaluation. The preliminary analytical model developed for the pipe-rupture accident represents a major

contribution toward establishing a realistic basis for LMFBR primary cell design pressure, provided experimental justification can be demonstrated.

The preliminary effort initiated on sodium jet discharge into air containment has not proceeded in sufficient depth to permit conclusions to be drawn, relative to interpretation for FFTF application. Improvement in jet velocity measurement techniques, currently underway, is required to properly evaluate the initial tests, as well as to ensure the utility of future tests needed in this area.

REFERENCES

1. "Quarterly Technical Progress Report, LMFBR Safety Programs, January-March 1971," AI-AEC-12992 (May 1971)
2. Lambiris et al., "Stable Combustion Processes in Liquid Propellant Rocket Engines," Fifth Award Colloquium on Combustion and Propulsion, Braunschweig, April 1962
3. D. B. Spaulding, "The Combustion of Liquid Fuels," Fourth International Symposium on Combustion, Cambridge, Mass., September 1952
4. "Quarterly Technical Progress Report, LMFBR Safety Programs, July-September 1970," AI-AEC-12979 (November 1970)
5. L. Baurmash et al., "Behavior of Iodine in the Presence of Sodium Oxide Aerosols," Proc. Eleventh AEC Air Cleaning Conference, Richland, Washington, August 31-September 3, 1970; CONF-700816, 1 (December 1970)
6. C. T. Nelson et al., "Measurements of Particulate Filtration Efficiencies of Building Materials," Proc. Eleventh AEC Air Cleaning Conference, Richland, Washington, August 31-September 3, 1970; CONF 700816, 1 (December 1970)
7. D. C. Hunt, "Restricted Release of Plutonium - Part 2. Theory," Nuclear Safety, 12, No. 3 (1971) p 203
8. "Quarterly Technical Progress Report, LMFBR Safety Programs, October-December 1970," AI-AEC-12986 (February 1971)
9. W. R. Lane and B. R. D. Stone, "Structure and Density of Particulate Aggregates," Int. Conf. Mechanisms of Corrosion by Fuel Impurities, Butterworths (1963)
10. K. Kay and H. F. Johnstone, "Factors of Agglomeration of Solid Aerosol Particles," COO-1019 (1962)
11. P. G. Saffman and J. S. Turner, J. Fluid Mech. 1, (1956) p 16
12. R. L. Koontz et al., "Aerosol Modeling of Hypothetical LMFBR Accidents," AI-AEC-12977 (August 31, 1970)

Program:	Fast-Reactor Development		
AEC Task:	6-G - Nuclear Safety (Kinetics), Boiling Studies for Sodium Reactor Safety		
Project Manager:	H. A. Morewitz		
Reporting Period:	Government Fiscal Year 1971		
General Order:	7702	Subaccount:	13410
		189A:	13243
		Category:	04-60-01-09.1

Principal Investigators: D. Logan, J. Landoni, and C. Baroczy

I. PROJECT OBJECTIVES

The general objective of this project is to develop basic information on two-phase flow and boiling, required in the safety evaluation of LMFBR designs. This information is important, because of the key role that sodium boiling plays in reactor dynamics, fuel meltdown accidents, and the ultimate shutdown mechanism of the reactor. Specific objectives of the experimental program include the development of reliable high-flux heaters, and the measurements of boiling heat-transfer characteristics, two-phase pressure drop, void fraction, liquid superheating, transient voiding rates and pressures, and hydrodynamic instabilities. Specific objectives of the theoretical study, in addition to any analyses required to support the experimental work, are the development of digital computer codes which will predict transient void fraction, flow rate, and heat transfer for single- and multichannel sodium flow.

II. TECHNICAL PROGRESS DURING FISCAL YEAR 1971

A. SUMMARY

Three-pin tantalum-clad heaters, both wire-wrapped and unwrapped, were developed and used successfully in an experimental two-phase thermal-hydraulic investigation which studied both stable boiling and burnout at 5 psia. Burnout heat flux increased with both subcooling and pressure; little velocity effect was found. At heat fluxes $< 200,000 \text{ Btu/hr-ft}^2$, it was possible to produce check curves extending well into the two-phase region with stable boiling. However, at heat fluxes greater than $\sim 400,000 \text{ Btu/hr-ft}^2$, subcooled boiling with negligible vapor generation occurred, and burnout followed shortly after the two-phase region was entered.

Studies conducted with SODIFAZE,⁽¹⁾ a steady-state, multi-channel boiling sodium code, predicted that, under nonuniform heat input conditions, the pressure drop-flow characteristic (check curve) for three geometrically identical channels could be markedly different from that for a single channel. This has been verified by comparison to an experimental⁽²⁾ check curve which displayed a pronounced looping characteristic, similar to that predicted by SODIFAZE. However, the check curve shape was very sensitive to small changes in flow-channel dimensions.

Incipient boiling was studied with a high-velocity single-channel test section. Commercial (high nitrogen) cladding produced the same superheating as the low-nitrogen FFTF cladding. Superheating was found to correlate with Reynolds number, as predicted by an analytical model which demonstrated the effect of turbulent eddies on boiling inceptions.

In a separate experiment, an electrically heated UO_2 fuel pin was overheated at the bottom of a static 20-ft sodium column. In this UO_2 explosion experiment, both the energy converted to work by vaporizing the sodium, and the UO_2 particle size distribution, were determined.

B. PUBLICATIONS

A topical report, AI-AEC-13010 (1971), "Forced Flow Sodium Boiling in Multiple Channels," D. Logen, C. J. Baroczy, and H. A. Morewitz, was prepared, and will be released during the first quarter of FY 1972.

A paper, "Exploding Fuel Pin Experiment," H. A. Morewitz, D. Logan, and L. Haba, was presented at the 1971 Annual Meeting of the ANS, Boston, Mass., June 13, 1971.

A paper, "Effects of Velocity, Oxide Level, and Flow Transients on Boiling Initiation in Sodium," D. Logan, C. J. Baroczy, J. A. Landoni, and H. A. Morewitz, was presented at the Winter Annual Meeting of the ASME, New York, New York, November 30, 1970.

A paper, "Incipient Superheat and Sodium Boiling Stability," H. A. Morewitz, was presented at the Second Meeting of the Technical Working Group on Liquid-Metal Thermal Science, ANL, May 19 and 20, 1971.

C. TWO-PHASE THERMAL-HYDRAULIC STUDIES*

1. Wire-Wrapped Tantalum-Sheathed 3-Pin Heater

A wire-wrapped, tantalum-sheathed, 3-pin heater was developed, and used in the last series of two-phase thermal-hydraulic tests. This heater had a 15-in.

*Full details of this work are reported in AI-AEC-13010, "Forced Flow Sodium Boiling in Multiple Channels," (to be published 1971)

heated section, followed by a 15-in. unheated section, to represent the downstream blanket in an LMFBR core. The heaters were 1/4 in. in diameter, and had the same pitch-to-diameter ratio as the FFTF fuel elements.

Temperature measurement was accomplished by thermocouples located in the wire wrap. Two 30-mil thermocouples were placed in each wire wrap, one located 1/4 in. into the heated zone, and the other 3/4 in. above the heated zone. The wire wrap was swaged from 62-mil OD tubing with a 10-mil wall and the two 20-mil Chromel-Alumel thermocouples inside. The final OD was 52 mils. Good response was obtained from the thermocouples, because of the extreme tight fit resulting from the swaging process. Additional thermocouples were brought through the Conoseal head to measure temperatures at the outlet of the unheated zone. Figure 5a shows an overall view of the heater and Figure 5b shows a closeup of the wire wrap. Extra spacers (which simulate adjacent wire wrap) are placed every 4 in., to provide centering support between the long contact spans of the wire wrap. The wire wrap was put on the heaters with a 12-in. pitch, and the wires were located so that the wrap location at the end of the heated zone corresponds to that in Figure 5c.

2. Boiling Behavior With Wire-Wrapped 3-Pin Heater

Boiling tests, utilizing three wire-wrapped heated pins, were conducted at total power inputs of 16, 25, and 32.4 kw;* additional tests, to burnout, were performed with two heated pins, and then with one heated pin.

Figure 6 shows representative traces for the 16-kw boiling run, in which flow was decreased and then increased. Shown are static pressure, pressure drops across the heated and unheated sections, flow rate, and accelerometer output. As flow decreases in the all-liquid region, the heated- and unheated-section pressure drops decrease, as the static pressure remains constant.

A flattening of the pressure drop (indicating two-phase flow) occurs first in the unheated section, and then in the heated section. As flow is further reduced, both the static pressure and the unheated-section pressure drop increase

*16-kw total power corresponds to an average (per pin) condition of 4.25 kw/ft and $Q/A = 222,000$ Btu/hr-ft²; 25-kw total power corresponds to an average (per pin) condition of 6.6 kw/ft and $Q/A = 346,000$ Btu/hr-ft²; 32-kw total power corresponds to an average (per pin) condition of 8.5 kw/ft and $Q/A = 444,000$ Btu/hr-ft²

7702-40234

a. Overall View

7702-40236

b. Closeup of Wire Wrap

c. Wire-Wrap Location at End of Heated Zone

7702-45282

Figure 5. Wire-Wrapped, Tantalum-Sheathed, 3-Pin Heater

7702-45283

Figure 6. Traces for 16-kw Total Power Boiling Run
(3 wire-wrapped pins)

AI-AEC-13006

7702-45284

Figure 7. Bulk Fluid Temperature Traces for 16-kw Total Power Boiling Run (3 wire-wrapped pins)

substantially, while the heated-section pressure drop remains essentially constant. As flow is then increased, the process is reversed, except for some hysteresis effect in the pressure drops and static pressure; that is, higher levels exist on the increasing-flow portion of the process.

Figure 7 shows bulk fluid temperature traces for the end of the heated section (upper trace) and the end of the unheated section (lower trace) for the same 16-kw run. It can be seen that the rising and falling pattern of the static pressure at the end of the heated section is duplicated by the temperature trace at the end of the heated section. In contrast, the temperature trace at the end of the unheated section is much flatter. For saturation conditions at both the end of the heated section and the end of the unheated section, the described pattern is as expected, if the downstream pressure remains essentially constant.

3. Boiling Burnout Investigations

During the course of the 3-pin boiling experiments, burnout conditions were achieved on seven occasions. As used here, "burnout" corresponds to the local occurrence of either melting of the heater cladding, or peripheral swelling of the cladding.

Figure 8 shows local burnout heat flux as a function of average liquid sodium velocity in the test section. Three burnout curves, each increasing with velocity, are evident; the upper curve corresponds to burnout under locally subcooled liquid conditions (320°F), the lowest curve corresponds to locally saturated liquid conditions, and the intermediate curve is for a small degree of local subcooling. However, the velocity dependence largely disappears when the data are corrected for differences in pressure by the data of Peppler and Schlectendal,⁽³⁾ shown in Figure 9. The increase of burnout heat flux with increasing subcooling, shown in Figure 10, is in accord with previous experimental results with water⁽⁴⁾ and sodium.⁽⁵⁾

The variation of bulk temperature in the tricuspid area located just above the end of the heated section, and the accelerometer output, are shown in Figure 11, as burnout was approached with a total input power of 32.4 kw. The temperature trace shows considerable variation ($\sim 100^\circ\text{F}$) on the left side. The tighter rising temperature pattern corresponded to a more uniform and greater vapor generation rate during the rising portion of the trace. An identical pattern of behavior

7702-45285

Figure 8. 3-Pin Burnout Data

Figure 9. Dryout Heat Flux vs Static Pressure in Test Section

7702-45287

Figure 10. Subcooling vs Local Burnout Heat Flux

7702-45288

Figure 11. Traces for Burnout at 32.4-kw Total Power

7702-45276A

Figure 12. Bulk Superheat vs Velocity for Small-Annulus, Single-Pin Test Section

is indicated by the accelerometer trace. This condition occurred after a small flow reduction, and lasted for ~20 sec before burnout took place. During this period, the bulk fluid temperature increased from a subcooled state to that approaching saturation. As the bulk temperature of the subcooled fluid increases, a greater fraction of the void generated at the wall continues to survive downstream, until the void fraction is great enough to permit a dryout to occur. Fiori and Bergles⁽⁶⁾ observed a trend identical to that shown here (increasing temperature) for wall temperature, as burnout for water was approached.

For a single annular channel, Peppler and Schlectendal⁽³⁾ have determined the region of sodium burnout in terms of pressure level only. The present saturated boiling data fall near the dryout zone described by these authors, while the slightly subcooled data are displaced toward higher burnout heat fluxes. Since, in a multichannel configuration, local conditions which affect burnout (mass velocity, quality, subcooling) can differ greatly from that of the average, or single-channel, conditions, the present favorable comparison with the single-channel results may be fortuitous. As a result, further multichannel burnout data at higher static pressures (i.e., 15 and 30 psia) are required for LMFBR accident analyses.

D. SODIUM SUPERHEAT

1. Boiling Initiation Tests

Sodium boiling initiation tests were performed, both with a small-annulus* (0.23 in. ID by 0.342 in. OD) coolant passage, and with a large annulus (0.25 in. ID by 0.5 in. OD) coolant passage. In Figure 12, the data from the small-annulus tests are shown in terms of bulk superheat vs velocity. Similar data were obtained for the large annulus. Bulk superheat decreases with increasing flow rate (velocity), even though the heat flux required to initiate boiling increases with flow rate. At a given flow rate (velocity), the vertical distribution of points is due to heat flux; that is, the highest superheat corresponds to the highest heat flux, and vice versa.

*It was shown, in these tests, that incipient boiling superheat obtained with FFTF cladding does not differ from the superheat obtained with commercial Type 304 stainless steel, which has a nitrogen content that is a factor of 10 larger.

Figure 13. Bulk Superheat vs Heat Flux for Two Test Sections With Different Annuli

For otherwise similar conditions (pressure, inlet subcooling, heat flux), the bulk superheat for two different flow area annuli will be the same at the same mass flow rate. The plot in Figure 13 (bulk superheat vs heat flux), using comparable data for the small annulus and the large annulus, shows that similar superheat occurs for similar mass flow rates, which correspond to different velocities. For example, 4 ft/sec in the large annulus corresponds to 744 lb/hr, whereas 10 ft/sec in the small annulus corresponds to 602 lb/hr. The observed result is in accordance with that expected from an all-liquid heat balance, since the small annulus superheats (lower mass flow rate) tend to group on a slightly higher curve than the large annulus (higher mass flow rate) data.

Figure 14 shows that superheat for the large and small annulus test section can be correlated to Reynolds number, for otherwise similar test conditions (pressure and inlet subcooling). Sodium superheat is seen to decrease with increasing Reynolds number.

2. Boiling Initiation Theory

At the high Reynolds numbers, turbulence penetrates the laminar sublayer, and another source of energy is available to supply the minimum work required to create the vapor phase. The connections between the turbulent process and incipient superheat is possible, if the energy possessed by the turbulent eddies contributes to the formation of incipient bubbles. It is well known that, for fully developed turbulent flow (i.e., large Reynolds numbers, Re), there is a universal pattern in which the transfer of a constant power density exists (i.e., the kinetic energy from the larger eddies is transferred to the smaller eddies, until it is finally dissipated by the eddies with the smallest size).

By using the Kolmogorov energy spectrum⁽⁷⁾ for large Reynolds numbers, it was demonstrated⁽⁸⁾ that

$$\epsilon \propto u^2, \quad \dots (17)$$

where:

ϵ = kinetic energy continued by eddies per unit mass

u = bulk velocity of the flow (a local channel velocity).

If it is assumed that this energy (ϵ) represents the kinetic energy part of the stream contributing to the energy ($W_{\min}$) required for the formation of a noncollapsing vapor bubble at the surface, or in the surface cavities of the heater, then it follows that

Figure 14. Bulk Superheat vs Reynolds Number

71-A1-23-6

$$\frac{16}{3} \pi \frac{\sigma_e^3}{(p' - p)^2} = W_{\min} \propto u^2, \quad \dots (18)$$

where

σ_e = effective surface tension

$(p' - p)$ = superheat pressure.

In order to facilitate the representation of this latter result, it is possible, in a first approximation, to express the factor $(p' - p)$ in Equation 18 by ΔT , the wall superheat, by using the Clapeyron-Clausius formula.* This leads to

$$\Delta T \propto u^{-1}, \quad \dots (19)$$

which is the trend shown in Figure 15. In this figure, the upper points, denoting the maximum wall superheat values, correspond to a minimal contribution from the kinetic energy contained by the eddies; while the lower points, denoting the minimum wall superheat values, correspond to a maximal contribution. The shadowed area in Figure 15 indicates the range of wall superheats and velocities covered by the present experimental runs. But this trend, as obtained by using the total kinetic energy contained by the eddies, may be misleading, because most of the energy is contained in the large-size eddies, whose penetration into the laminar sublayer zone is never completed. In consequence, it is worthwhile to examine the contribution for the kinetic energy of the eddies in the smallest size range, which leads to

$$W_{\min} \propto u^{3/2}, \quad \dots (20)$$

and therefore,

$$\Delta T \propto u^{-3/4}. \quad \dots (21)$$

This trend is also indicated in Figure 15, together with some representative data of Chen,⁽¹⁰⁾ for incipient boiling of potassium, whose trend seems to be in agreement with the derivations.

Neither the whole kinetic energy contained per unit mass of the eddies, nor the smallest size eddies (internal scale), precisely determines the trend of

*This is possible, because of the modest superheat detected in the velocity range under consideration.

7702-4749A

Figure 15. Wall Superheat vs Velocity

decreasing wall superheats with increasing velocities. But there is no question that, by taking these two extreme cases, definite trends are shown, indicating the link existing between incipient boiling and the propagation of turbulence into the laminar sublayer with increasing velocities. This decrease in incipient boiling superheat with increasing Reynolds number, as a result of increased turbulence in the boundary layer, has also been predicted by the CNEN group.⁽¹¹⁾

E. EXPLODING FUEL PIN EXPERIMENT

An unirradiated UO_2 fuel pin was exploded by direct electrical heating under a column of 1200°F sodium, ~ 20 ft in height. The mechanical energy conversion efficiency (ϵ), the size distribution of the dispersed UO_2 particles, and the velocity profile were obtained from this test.

The amount of thermal energy that was converted to mechanical energy during the test was computed from four contributions: (1) friction loss, (2) sudden expansion, (3) height change, and (4) compression work. The friction loss of the sodium column was calculated by utilizing the EM flowmeter data, which gave the velocity profile and the net distance moved due to the "explosion." The sudden expansion of the sodium, as it left the ~ 20 -ft-high, 0.46-in.-ID test section and entered the expansion tank at the top of the test section, the net height change in the ~ 20 -ft sodium column, and the compression work done on the gas in the expansion tank at the top of the test section, were also calculated from the flowmeter data. There is no contribution from acceleration of the sodium column, because the four energy contributions (friction, sudden expansion, height change, and compression work) were either summed to, or taken at, the point when the sodium column velocity was zero. In this experiment, a total of ~ 125 J of energy was converted to mechanical work, from an electrical input energy of $\sim 36,000$ J. This yields a conversion efficiency of $\epsilon = 3.5 \times 10^{-3}$ at an energy density of 4 kJ/gm UO_2 .

The present experiment can be compared with a conversion efficiency of $\epsilon = 2 \times 10^{-5}$, the results of a similar measurement performed in TREAT⁽¹²⁾ at 2.6 kJ/gm UO_2 . A recent series of SPERT⁽¹³⁾ measurements of single UO_2 pins exploded in water can also be used for comparison.

It can be seen (Figure 16) that, for a given energy density, ϵ is more than three orders of magnitude less in the sodium-cooled case than in the water-cooled

case. In both the TREAT nuclear heating experiment and the AI electrically heated experiment, the power was applied to the UO_2 pin for ~ 0.25 sec prior to the rupture.

In the present experiment, the entire mass of UO_2 was vented into the 1200°F sodium through an axial slit, ~ 1 in. long by ~ 75 mils wide, and from the downstream end, which was completely blown off. Photomicrographs of the fragments show mainly faceted (nonspherical) morphology. The UO_2 particle size distribution (see Figure 17), obtained by sieving, shows a mass median diameter of $400\ \mu\text{m}$. Of primary interest is the fact that only 7% of the mass of the particles had diameters smaller than $100\ \mu\text{m}$, and that only 1% of the mass of the particles had diameters smaller than $43\ \mu\text{m}$. This can be compared to the SPERT results (see Figure 18) for UO_2 -water explosions, where $\sim 2\ \text{kJ/gm}$ UO_2 produced approximately the same fragment size distribution, and where the amount of fine particles increased with energy density. This may explain, in part, the low efficiency (compared to water) of the sodium vapor explosion for overpowered UO_2 pins.

III. EVALUATION OF EFFORT DURING FISCAL YEAR 1971

A. TWO-PHASE THERMAL HYDRAULICS

Two-phase thermal-hydraulic tests in multichannel LMFBR geometry showed the existence of a looping check curve, in which pressure drop remained essentially constant until boiling was attained in all channels. This verified the prior predictions of a SODIFAZE, a multichannel boiling sodium code. The shape of the multichannel check curve was shown to be very sensitive to differences in channel heat input or dimensions. Boiling sodium pressure drop behavior in a multichannel test section with equal-length heated and unheated sections exhibited a pronounced hysteresis effect, when decreasing flow was followed by increasing flow.

At ~ 5 psia and heat fluxes of $\sim 200,000\ \text{Btu/hr-ft}^2$, it was possible to produce multichannel check curves extending well into the two-phase region. However, at heat fluxes $> 400,000\ \text{Btu/hr-ft}^2$, subcooled boiling, with negligible vapor generation, occurred, and burnout was observed shortly after the two-phase region was entered. It was shown that, at 5 psia, velocity effects on burnout heat flux were small, while the effects of subcooling on burnout heat flux were large.

Figure 16. Thermal to Mechanical Energy Conversion Efficiency vs Energy Density in UO_2

Figure 17. UO_2 Particle Size Distribution

Figure 18. Fine Particle Fraction vs Energy Density in UO_2

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

This type of information is required at higher local pressures, in order to assess the cladding behavior in the LMFBR "pipe rupture accident with scram."

B. AI-DEVELOPED HIGH FLUX GRAPHITE HEATERS

1. FFTF Cladding as Heater Sheath

A 0.230-in. OD heater was fabricated with FFTF fuel element cladding as the heater sheath. This was done without altering, in any manner, the cladding material. This design had previously been used to fabricate heaters of 0.250 in. diameter. The 0.230-in. OD heater was used successfully in a series of high-velocity boiling inception tests. This heater has the characteristics of the Type II heater required for advanced LMFBR thermal-hydraulic tests.

2. Wire-Wrapped 3-Pin Tantalum-Clad Heater

A 0.250-in. diameter, 3-pin, tantalum-sheathed heater was fabricated with wire wrapping. Each wire wrap contained two thermocouples. This heater was installed in a specially constructed test section, and used to perform the last series of two-phase thermal-hydraulic tests. The heater performed very successfully, under conditions of continuous boiling, for several tests, before failure was brought about by vapor blanketing at low flow. Its performance demonstrates it to be a useful research tool.

C. BOILING INITIATION SUPERHEAT

Theoretical investigation of sodium superheat for Reynolds numbers well into the turbulent-flow regime ($Re > 2 \times 10^4$) indicates that the turbulent eddies provide an additional energy source for nucleating the incipient boiling, so that the incipient boiling wall superheat decreases in correspondence with increasing the kinetic energy possessed by the eddies as the Reynolds number increases. This has been verified by correlation, on the basis of Reynolds number, of the single-channel superheat data obtained with the small-annulus test section with data previously obtained with the large-annulus test section. This indicates that superheating in LMFBR coolant channels is not important at velocities above ~ 6 ft/sec.

Superheat data obtained with FFTF-type heater cladding displayed no appreciable difference from data previously obtained with commercial Type 304 stainless steel heater cladding, indicating that nitrogen dissolved in the cladding played no role in the process.

D. EXPLODING FUEL PIN EXPERIMENT

A UO_2 fuel pin was exploded by direct electrical heating under an ~ 20 -ft column of 1200°F sodium. Mechanical energy conversion efficiency and UO_2 particle size distribution were obtained. Although additional experiments are needed to validate this test, and to scope the energy density range, this suggests, in combination with the TREAT experiments, that the available work energy from the sodium vapor explosion has been seriously overestimated in previous LMFBR safety analyses. For example, our results would indicate that the DBA energy available from the AI-GPU FBR or the FFTF central seven subassemblies would have an average efficiency of $\sim 10^{-3}\%$ for converting the hot UO_2 fragment - sodium interaction into work. This would lead to only a few megawatt seconds of work from the "sodium vapor explosion." Previously, using upper-limit thermodynamic processes (for the AI-GPU FBR), 400 Mw-sec had been estimated for the work from this process, and 100 Mw-sec of work for the "fuel vapor explosion."

In the actual DBA, because of the small mass of fine particles shown by this experiment, the presently assumed aerosol source term should be reduced by several orders of magnitude, as particles $> 43\ \mu\text{m}$ in diameter rapidly settle from the air.

A series of these experiments could provide the information necessary to model the LMFBR "sodium vapor explosion." Parameters such as mixing time, particle size distribution, and fuel motion caused by sodium drag, could be measured as a function of energy density, fuel density, cladding brittleness, and fuel pin gas pressure.

REFERENCES

1. C. J. Baroczy, "SODIFAZE, A Steady State Multi-channel Boiling Sodium Code," AI-AEC-12804 (February 15, 1970)
2. D. Logan, C. J. Baroczy, and H. A. Morewitz, "Forced Flow Sodium Boiling in Multiple Channels," AI-AEC-13010 (to be published)
3. W. Peppler and E. G. Schlectendahl, "Experimental and Analytical Investigations of Sodium Boiling Events in Narrow Channels," Liquid Metal Heat Transfer and Fluid Dynamics, ASME Symposium, New York, November 30, 1970
4. L. S. Tong, F. E. Motley, and J. O. Cermak, "Scaling Law of Flow-Boiling Crisis," Vol VI, Fourth International Heat Transfer Conference, Paris, 1970

5. R. C. Noyes and H. Lurie, "Boiling Sodium Heat Transfer," Vol V, Third International Heat Transfer Conference, Chicago, Illinois, August 7-12, 1966
6. M. P. Fiori and A. E. Bergles, "Model of Critical Heat Flux in Subcooled Flow Boiling," Vol VI, Fourth International Heat Transfer Conference, Paris, 1970
7. G. H. A. Cole, Fluid Dynamics (Methuen and Co. Ltd., London, 1962) p 201
8. "Quarterly Technical Progress Report, LMFBR Safety Programs, July-September 1970," AI-AEC-12979 (November 12, 1970)
9. "Annual Technical Progress Report, LMFBR Safety Programs, GFY 1970," AI-AEC-12970 (August 15, 1970)
10. J. S. Chen, "Effect of Turbulent Flow on Incipient Boiling Superheat," Technical Working Group on Liquid Metal Thermal Science, Brookhaven National Laboratory, May 22-23, 1969
11. M. Pezzilli et al., "The NEMI Model for Sodium Boiling and Its Experimental Basis," Symposium on Liquid-Metal Heat Transfer and Fluid Dynamics, ASME, New York, November 30, 1970
12. C. E. Dickerman et al., Trans. Am. Nucl. Soc., 13 (1970) p 370
13. "SPERT SPX-18 Tests," IDO-17287 (1968)