OCT 3 1966

UNCLASSIFIED

CERT PRICES

CLASSIFICATION LEVEL
(S, C OR U)

H.C. \$ 1.00; MN 50

ATOMICS INTERNATIONAL
A Division of North American Aviation Inc.

NAA-SR-MEMO COVER SHEET

MASTER

REPORT TITLE

AUTHOR

NAA-SR-MEMO 8324

RELEASED FOR ANNOUNCEMENT
IN NUCLEAR SCIENCE ABSTRACTS

(This Document Contains 13 Pages.)
(This is Copy of Series)

CLASSIFICATION TYPE
(RD OR DI)

*NAA-SR-MEMOs are working papers and may be expanded,
modified, or withdrawn at any time, and are intended for
internal use only.*

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, AEC.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

UNCLASSIFIED

CLASSIFICATION LEVEL
(S, C OR U)

DO NOT REMOVE THIS SHEET

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.		NAA-SR- TDR NO 8324	APPROVALS
TECHNICAL DATA RECORD		PAGE 1 OF 13	C.W. Griffin
AUTHOR N. K. Rumpf	DEPT & GROUP NO 717-71	DATE 3-18-63	J. J. ...
		GO NO 7578	A. ...
TITLE Pressure Buildup in the Cell and Primary Vault of the FARET from Sodium Fires or Spills		S A NO 8981	TWR 41893
		SECURITY CLASSIFICATION	
		(CHECK ONE BOX ONLY) UNCL. ☒ CONF. ☐ SECRET ☐	(CHECK ONE BOX ONLY) RESTRICTED DATA ☐ DEFENSE INFO. ☐
		AUTHORIZED CLASSIFIER SIGNATURE DATE	
PROGRAM FARET	SUBACCOUNT TITLE FARET Preliminary Hazards Evaluation		
DISTRIBUTION	STATEMENT OF PROBLEM		
W. O. Allen	Evaluate the pressure increase in the hot cell from a sodium fire and in the primary vault from a hot sodium spill. Determine if the design criteria are sufficient to safely contain these pressures, and if not suggest means to relieve the system.		
W. F. Anderson			
D. W. Beimler			
S. Berger			
F. B. Beyer			
C. H. Bridges			
A. V. Campise			
H. H. Cappel			
D. F. Casey			
H. O. Charnock	ABSTRACT		
C. C. Connors	Two different types of fires are analyzed which might result from the explosion of a supercritical mass in the core with the equivalent force of 300 lb TNT. If a fine sodium spray is expelled into an atmosphere of air, a pressure of 48 psig is possible. However, this accident is found to be incredible in the present physical surroundings. There is a remote possibility that the top shield plug could become dislodged by an explosion. In such an instance it is found that the pressure after 3 hours is 4.22 psig and the maximum possible pressure is 10 psig. This is well within the 30 psig design pressure. The primary vault, which has the largest floor area to over-all surface area ratio, is analyzed. The initial pressure increase for a spill of 1000 lb or more is such that gas must be removed at 1668 cfm. A relief valve has already been designed into the system. It is found that this valve must be in a 4 inch line in order to keep the pressure in the vault at less than 2 psig which is within the design limits.		
R. L. Cummings			
R. W. Dickinson			
W. L. Dixon			
C. L. Dunsmore			
R. C. Gerber			
C. W. Griffin			
J. F. Hagelston			
B. J. Halfon			
D. V. Hammond			
J. P. Hawley			
H. B. Hole (7)			
N. L. Kledzik			
G. Landler			
J. E. Mahlmeister			
J. Marvosh			
J. W. McCarty			
J. A. McEdwards			
C. Myhre			
P. Perlow			
V. R. Pool			
N. K. Rumpf			
N. K. Simon			
H. L. Sletten			
G. W. Spangler			
F. J. Waters			
A. G. Williams			
L. J. Zimmer			

INTRODUCTION

In the construction of the reactor building it is necessary to maintain structural integrity in the face of possible accident conditions. Two such possible accidents are a sodium fire or a spill of hot sodium into an enclosed region.

If it is assumed that the perfect gas law holds, then the pressure increase will be proportional to the temperature increase. It is necessary to find the magnitude of these pressure increases in order to determine some of the design criteria of the structural portions of the reactor complex.

Potential Sodium Fire Hazards in the FARET Cell

It is possible to define several different types and magnitudes of fires according to the assumptions made in determining the accidents which initiate these fires. Since the structural units associated with the reactor are designed to exclude oxygen from the vicinity of the primary sodium system, two consecutive accidents are required to cause a fire in the hot cell.

The worst conceivable accident is one in which a fine spray of sodium is expelled into the cell. It is assumed, in all further discussions, that, through some failure, the cell contains a normal atmosphere of air. The EBR II Hazards Summary⁽¹⁾ contains a discussion of the consequences of the expulsion of a fine sodium spray into a normal air atmosphere.

Using this report it was found that the maximum pressure which could be expected is 48 psig. This is 75 percent of the theoretical maximum in accordance with the findings of the above study. However, it has also been shown that a highly idealized set of conditions are necessary to attain 75% of the theoretical maximum pressure. Under less than ideal conditions it can be expected that the maximum pressure encountered will be reduced by some considerable amount.

The only conceivable accident which could lead to the above set of conditions is the formation of a supercritical mass which explodes with extreme violence, thus expelling the sodium spray. It has been postulated that the explosive force of such an accident in the FARET core might be the equivalent of 300 lb TNT. However, the design of the reactor structure is such that an accident of this nature would

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NL. 8324
DATE 3-18-63
PAGE 3 OF 13

first blow out the sides of the reactor. In order for a fire to ensue from a sodium spray, it is necessary that the spray be expelled from the top of the reactor into an oxygenated atmosphere. The above explosion would not be sufficient to both dislodge the top plug shield of the reactor and then also expel a fine sodium spray into the hot cell. Thus it is somewhat illogical for the sodium spray type fire to be of significant concern in considering the maximum pressure developed in the hot cell.

Some doubt has been raised as to whether the magnitude of the explosion postulated above would even be sufficient to raise the top shield plug because of the proposed structural design. However, if this should occur, a sodium fire of considerably lesser magnitude than the one discussed above would occur. Here there would be an exposed pool of sodium which would be free to burn only at the top. In order to calculate the maximum pressure in the cell it is necessary to set up a model for the temperature rise of the gaseous atmosphere. It is assumed that the perfect gas law holds and that the pressure rise is proportional to the temperature rise.

The differential equation describing the rate of temperature change in the sodium pool is

$$WC_p \dot{T}_s = -U_1 A_1 (T_s - T_G) \quad (1)$$

where

W_s = weight of sodium

C_p = heat capacity of sodium

$\dot{T}_s$ = rate of change of sodium temperature

U_1 = heat transfer coefficient from sodium to gas

A_1 = heat transfer area from sodium to gas

T_s = sodium temperature

T_G = gas temperature

The differential equation describing the rate of change of gas temperature is

$$WC_p)_G \dot{T}_G = - U_1 A_1 (T_G - T_s) - U_2 A_2 (T_G - T_o) + H$$

where

$W)_G$ = weight of gas

$C_p)_G$ = heat capacity of gas

$\dot{T}_G$ = rate of change of gas temperature

U_2 = over-all heat transfer coefficient from gas to surroundings

A_2 = heat transfer area from gas to surroundings

T_o = constant boundary temperature

H = rate of heat addition to gas from the fire

The constant temperature boundary position is not necessarily the same as that of the physical boundary. The temperature boundary is at a position in the wall which is the farthest point to which the heat has travelled at the time of interest. This boundary condition is then time dependent and, in being so, actually constantly changes the spatially dependent time constant associated with the resistance to heat flow through the wall.

To more accurately stipulate the position of this boundary a simple trial and error process is used. A wall thickness is first assumed. It is possible to calculate the heat given to the gas and also that given to the walls over a given period of time. The mean temperature of the gas and the section of wall under investigation can be found from a heat balance. A linear temperature distribution is assumed in the wall which stipulates the inner wall temperature. This in turn fixes the heat flow across the film from the gas to the wall. If the heat transfer coefficient is assumed constant, this heat flow may be readily compared with the true heat flow. If the assumed heat flow is less than the true heat flow the boundary has been assumed too far into the wall. If the assumed flow is too small the reverse is true.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

N. 8324
DATE 3-18-63
PAGE 5 OF 13

The model presented by Equations (1) and (2) gives a conservative picture since these equations do not account for the heat absorbed in the wall. If this heat were accounted for, the maximum pressure would be reduced from the presently predicted value. Although the reduction in the maximum pressure is not great, previous work⁽²⁾ has shown that the initial rate of pressure increase would be significantly reduced.

It can also be seen from the above system of equations, that all the heat from the fire is assumed to be lost to the gas and none is assumed absorbed by the sodium pool or sodium oxide crust atop the pool. This also will not significantly reduce the maximum pressure, but will reduce the rate of pressure rise. A final conservative factor is the assumption of no heat loss from the sodium pool except to the gas.

Equations (1) and (2) may be written in the form

$$\dot{T}_s = - \frac{(T_s - T_g)}{\lambda_1} \quad (3)$$

$$\dot{T}_g = - \frac{(T_g - T_s)}{\lambda_2} - \frac{(T_g - T_o)}{\lambda_3} + F \quad (4)$$

where

$$\lambda_1 = \frac{WC_p)_s}{U_1 A_1}$$

$$\lambda_2 = \frac{WC_p)_g}{U_1 A_1}$$

$$\lambda_3 = \frac{WC_p)_g}{U_2 A_2}$$

$$F = \frac{H}{WC_p)_g}$$

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. 8324
DATE 3-18-63
PAGE 6 OF 13

In order to find the transient gas temperature response, it is necessary to have a third equation. This is obtained by differentiating Equation (4) to yield

$$\ddot{T}_G = - \frac{(\dot{T}_G - \dot{T}_s)}{\tau_2} - \frac{\dot{T}_G}{\tau_3} \quad (5)$$

This system of equations evolves to

$$\ddot{T}_G + \dot{T}_G \left[\frac{\tau_1(\tau_2 + \tau_3) + \tau_2\tau_3}{\tau_1\tau_2\tau_3} \right] + \frac{1}{\tau_1} \left(\frac{1}{\tau_1\tau_3} \right) - \frac{F}{\tau_1} - \frac{\dot{T}_s}{\tau_1\tau_3} = 0 \quad (6)$$

The solution to Equation (6) is

$$T_G = Ae^{r_1 t} + Be^{r_2 t} + F\tau_3 + T_0 \quad (7)$$

where r_1 and r_2 are the two negative roots of the quadratic equation

$$r^2 + r \left(\frac{\tau_2 + \tau_3}{\tau_1\tau_2\tau_3} + \frac{1}{\tau_1} \right) + \frac{1}{\tau_1\tau_3} = 0 \quad (8)$$

and A and B are arbitrary constants determined by the initial conditions.

It has been found that the initial burning rate of sodium in air is 1.3 lb/min, $\text{ft}^2(3)$. Making the conservative assumption that this rate remains constant, the rate of heat release H , is found to be 26×10^4 Btu/hr. It has been assumed that the room is initially at 70°F and 30% relative humidity. All the water in the hot cell reacts within the first hour and then it is assumed that the sodium-water reaction rate remains at this constant rate of 5×10^4 Btu/hr. This number has been included in H above. It should also be noted that the oxidation to sodium peroxide has been assumed since this gives off the greatest amount of heat in the shortest time. The following numbers are assumed in finding a solution to the particular problem at hand.

26/4/63 - 1/2 - Later data w/ 1/2

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

8324
 DATE 3-18-63
 PAGE 7 OF 13

$$W)_S = 10,000 \text{ lb} \checkmark$$

$$C_p)_S = 0.326 \text{ Btu/hr, lb, } ^\circ\text{F}$$

$$U_1 = 2 \text{ Btu/hr, ft}^2, ^\circ\text{F}$$

$$A_1 = 33.18 \text{ ft}^2$$

$$W)_G = 2031 \text{ lb}$$

$$C_p)_G = 0.3$$

$$U_2 = \underline{0.1562} \quad ?$$

$$A_2 = 4644 \text{ ft}^2$$

$$T_o = 70^\circ\text{F}$$

Then

$$\frac{1}{t_1} = 49.1 \text{ hr}$$

$$\frac{1}{t_2} = 9.19 \text{ hr}$$

$$\frac{1}{t_3} = .840 \text{ hr}$$

$$F = 426 \text{ Btu/hr}$$

whence

$$r_1 = -1.304 \quad r_2 = -0.0175$$

To determine A and B, note that at $t = 0$,

$$T_G = 70^\circ\text{F}$$

$$\begin{aligned} \frac{\dot{T}_G}{t} &= - \frac{(T_G - T_S)}{\frac{1}{t_2}} - \frac{(T_G - T_o)}{\frac{1}{t_3}} + F = \frac{1080}{9.19} + 0 + 426 \quad (10) \\ &= 544^\circ\text{F/hr} \end{aligned}$$

from which

$$A = 144$$

$$B = -214$$

and the final equation is

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. 8324
DATE 3-18-63
PAGE 8 OF 13

$$T_G = 144e^{-1.304t} - 214e^{-0.0175t} + 428 \quad (11)$$

The pressure is given by

$$P = \left(\frac{T_G + 460}{530} - 1 \right) 14.7 \quad (12)$$

This response is shown in Figure 1 for a period of 3 hours. The amount of oxygen available within the cell is sufficient to sustain combustion for approximately the 3 hr period mentioned above. It has been assumed that the oxygen supply within the cell is not replenished and the sodium oxide crust formed atop the sodium pool will extinguish the fire when approximately 10% oxygen concentration remains in the cell. This number is below that found by experimental evidence. If replenishment of oxygen is assumed, then a pressure buildup may not be assumed. Obviously if oxygen has a means of entering the cell, pressure has a means of escaping.

After a 3 hr period, the pressure in the cell is 4.22 psig. The maximum pressure which can be attained under these circumstances is 10.0 psig. Both these numbers are well within the design pressure of 30 psig in the cell.

$$3318 \times 1.3 \times 10^{-4} \times 398 \times 3 \times 10^4 = 1 \times 10^4$$

FIG. 1. PRESSURE RISE IN THE FARET HOT CELL FROM A
SODIUM FIRE IN THE REACTOR WITH THE TOP
SHIELD PLUG REMOVED

Pressure Buildup in the FARET Primary Vault

In analyzing the possible pressure buildup in any of the primary vaults, a non-reactive atmosphere is assumed. Also, the primary concern is in ways and methods to release the pressure before it builds to levels which might cause some part of the structure or equipment to lose its integrity.

For this case, the equations used in determining the temperature response for a sodium spill are similar to those derived for the sodium fire accident. These have been previously derived and are

$$\dot{T}_s = - \frac{(T_s - T_o)}{t_1} - \frac{(T_s - T_g)}{t_2} \quad (13)$$

$$\dot{T}_g = - \frac{(T_g - T_s)}{t_3} - \frac{(T_g - T_o)}{t_4} \quad (14)$$

$$\ddot{T}_g = - \frac{(\dot{T}_g - \dot{T}_s)}{t_3} - \frac{\dot{T}_g}{t_4} \quad (15)$$

The extra term in Equation (13) is the loss of heat by conduction from the bottom of the vault. The over-all heat transfer coefficients are

U_1 = coefficient through the bottom of the vault to the surroundings

U_2 = coefficient from sodium to the gas

U_3 = coefficient from gas to the surroundings

The areas A_1 , A_2 , and A_3 are those appropriate to the above subscripted coefficients. Then for this case

$$t_1 = \frac{WC_p s}{U_1 A_1}$$

$$t_2 = \frac{WC_p s}{U_2 A_2}$$

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

8324
DATE 3-18-63
PAGE 11 OF 13

$$\tau_3 = \frac{WC_p G}{U_2 A_2}$$

$$\tau_4 = \frac{WC_p G}{U_3 A_3}$$

The final equation for the temperature response in the vault is

$$T_G = A e^{r_1 t} + B e^{r_2 t} + T_0 \quad (16)$$

where r_1 and r_2 are the two negative roots to the quadratic equation

$$r^2 + r \left[\frac{\tau_1 \tau_2 (\tau_3 + \tau_4) + \tau_3 \tau_4 (\tau_1 + \tau_2)}{\tau_1 \tau_2 \tau_3 \tau_4} \right] + \frac{(\tau_1 + \tau_2)(\tau_3 + \tau_4) - \tau_1 \tau_4}{\tau_1 \tau_2 \tau_3 \tau_4} = 0 \quad (17)$$

The largest spill considered was 35,000 lb sodium. Cases were also run for 10,000, 1,000 and 100 lb. These cases are labeled 1, 2, 3 and 4 respectively in Figure 2, which describes the pressure response for the first several minutes after the spill.

It can be seen that for all except case 4, the initial rate of pressure increase is almost identical. Thus, for any large spill of sodium into one of the primary vaults the requirements for relieving the pressure in that vault are nearly the same. The calculations were performed on the vault with the largest floor surface to over-all surface ratio since it has been shown⁽²⁾ that this would give the greatest maximum pressure if the heat transfer coefficients are assumed constant in each instance.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

N. 8324
DATE 3-18-63
PAGE 12 OF 13

The dimensions of the vault in these calculations are 27' x 42' x 16'.
Then

$$A_1 = A_2 = 1134 \text{ ft}^2$$

$$A_3 = 3342 \text{ ft}^2$$

$$U_1 = 1.08$$

$$U_2 = 2$$

$$U_3 = 0.1688$$

The response in case 1 shows the rate of pressure increase over the first five minutes to be 2.5 psi/min. For the volume in this vault the volumetric gas release which must be maintained over this period is 1668 cfm. This information was forwarded and it was determined that a 4" pipe was necessary to remove this volume of gas at 2 psi overpressure. The percentage volume occupied by the sodium increases the pressure somewhat, but this was found to be negligible.

References

1. Koch, L. J., et al, "Hazard Summary Report; Experimental Breeder Reactor II (EBR-II)", ANL-5719, May 1957.
2. Rumpf, N. K., "360 Mwe SGR Power Plant Hazards Analyses - Sodium Fires and Associated Accidents", NAA-SR-TDR-8153, December 1962.
3. Begley, R. J., Experimental evidence compiled during tests conducted under AEC contracts, results to be published (1962).

Fig. 2 PRESSURE RISE IN A FAREY PRIMARY VAULT
FROM SODIUM SPILLS OF VARIOUS MAGNITUDES