

390
12-5-80
[Signature]

2

19. 2116
SAN-1570-2/2

OCEAN THERMAL ENERGY CONVERSION (OTEC) POWER SYSTEM DEVELOPMENT

Preliminary Design Report—Appendices—Part 1 (Final)


MASTER

December 4, 1978

Work Performed Under Contract No. EG-77-C-03-1570

TRW Systems and Energy
Redondo Beach, California

DIST-328
NTIS-25



U.S. Department of Energy



Solar Energy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DISCLAIMER

"This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

This report has been printed directly from copy supplied by the originating organization. Although the copy supplied may not in part or whole meet the standards for acceptable reproducible copy, it has been used for reproduction to expedite distribution and availability of the information being reported.

Available from the National Technical Information Service, U. S. Department of Commerce, Springfield, Virginia 22161.

Price: Paper Copy \$38.00
Microfiche \$3.50

OCEAN THERMAL ENERGY CONVERSION (OTEC) POWER
SYSTEM DEVELOPMENT

Preliminary Design Report—Appendices—Part 1 (Final)

December 4, 1978

Contract No. EG-77-C-03-1570

TRW Systems and Energy
Redondo Beach, California

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDICES

CONTENTS

	Page
Part I	
A. DEVELOPED COMPUTER MODELS	A-1
A.1 SYSTEM DESIGN AND OPTIMIZATION MODEL UPDATE	A-3
A.2 SYSTEM PERFORMANCE MODEL	A-37
A.3 HYDRAULIC TRANSIENT MODEL	A-89
B. WATER SYSTEM DYNAMICS STUDIES	B-1
B.1 SUMMARY	B-2
B.1.1 Introduction	B-4
B.1.2 Conduit Distribution Systems	B-5
B.1.3 Dynamics of Flow in the Open Trough System	B-8
B.2 COMPLETELY CLOSED CONDUIT SYSTEM	B-13
B.2.1 Basic Features and Simplified Representation	B-14
B.2.2 Startup	B-18
B.2.3 Vertical Hull Motion	B-27
B.3 DECOUPLED CLOSED CONDUIT SYSTEM	B-37
B.3.1 Basic Features	B-38
B.3.2 Dynamics of Flow	B-38
B.4 OPEN TROUGH SYSTEM	B-41
B.4.1 Basic Features	B-42
B.4.2 Pump Startup	B-42
B.4.3 Standing Waves in the Trough	B-45
B.4.4 Vertical Motion of Water Surface	B-46
C. MISCELLANEOUS PERFORMANCE ANALYSIS	C-1
C.1 VARIABILITY OF AMMONIA LOOP PARAMETERS	C-3
C.2 OPTIMUM DESIGN ΔT	C-15
D. MATERIALS AND PROCESSES	D-1
D.1 TUBE MANUFACTURING	D-3
D.2 EROSION AND CORROSION CONTROL	D-47
D.3 MATERIALS COMPATIBILITY, RECOMMENDED MATERIALS	D-69

APPENDICES
CONTENTS (Continued)

	Page
E. DETAILED EQUIPMENT LISTS	E-1
E.1 SYSTEM EQUIPMENT LISTS	E-3
E.2 SPECIAL SUPPORT EQUIPMENT LIST	E-13
E.3 MACHINERY, TOOLS, AND SPARE PARTS LIST 10 MWe	E-17
E.4 LONG LEAD TIME PROCUREMENT LIST, 200 kWe and 10 MWe	E-19
F. TURBINE DESIGN STUDIES	F-1
F.1 TURBINE PRELIMINARY DESIGN ANALYSIS	F-3
F.2 ELLIOTT'S TURBINE STUDY	F-15
G. TUBE CLEANER DESIGN	G-1
G.1 HYDRAULIC TUBE CLEANER ANALYSIS	G-3
G.2 OTHER DESIGN CONSIDERATIONS WITH RESPECT TO THE HYDRAULIC TUBE CLEANER	G-13
G.3 MAINTENANCE AND OPERATING PLAN INPUTS FOR THE 10 MWe AND THE 0.2 MWe TUBE CLEANERS	G-27
G.4 TUBE CLEANER MEASUREMENTS AND CONTROLS	G-33
H. AMMONIA LEAK DETECTION	H-1
H.1 OTEC AMMONIA LEAK DETECTION SYSTEM	H-3
H.2 OTEC PSD-1, EFFECTS OF SEAWATER LEAKAGE INTO AMMONIA SYSTEM	H-37
I. HEAT EXCHANGER DESIGN SUPPORTING DATA	I-1
I.1 THERMAL/HYDRAULIC ANALYSIS	I-3
I.1.1 Tube Side Equations - Heat Transfer and Pressure Drop	I-4
I.1.2 Evaporation Heat Transfer Coefficient	I-5
I.1.3 Condensing Heat Transfer Coefficient	I-7
I.1.4 Metal Resistance	I-8
I.1.5 Shell Side Pressure Drop	I-10
I.1.6 Evaporator and Condenser Dimensions	I-12
I.1.7 Non-Condensibles	I-12
I.2 STRESS ANALYSIS	I-133
I.2.1 10 MWe Heat Exchanger	I-137
I.2.2 0.2 MWe Test Articles	I-201
I.2.3 Heat Exchangers Support	I-213
I.3 TUBE SELECTION/DESIGN DATA	I-231
I.4 0.2 MWe TEST ARTICLE LOOP	I-275

APPENDIX A
DEVELOPED COMPUTER MODELS

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX A.1

SYSTEM DESIGN AND OPTIMIZATION MODEL UPDATE

TRW

DEFENSE AND SPACE SYSTEMS GROUP
ONE SPACE PARK - REDONDO BEACH - CALIFORNIA 92278

INTEROFFICE CORRESPONDENCE

TO: Paul Bakstad

CC: Distribution
P. Fukunaga P.F.F.
R. Pearson

PSD-I-322
78.6852.4.7-05
DATE: 2 June 1978

SUBJECT: OTEC System Optimization Program Update

FROM: Gregory S. Gibson
BLDG. 81 MAIL STA. 1569 EXT. 63374

The OTEC-I system optimization computer model is described in reference 3, pages E-1 to E-37. The OTEC-II system optimization computer model has greater capabilities than the OTEC-I model. The areas of modification include:

- o Heat transfer coefficients
- o Programming inputs
- o Gross power iteration
- o Cost equations
- o Printout

These modifications were developed by myself and P. Bakstad. G. Kikin developed the enclosed heat exchanger cost equations. J. Kaellis developed the thermal thickness evaluation technique.

PROGRAM INPUTS

The OTEC-II optimization computer program has more flexibility and capability than the OTEC-I model. Inputs listed in Table 1 allow the programmer to change tube geometry and tube material with each computer run. Tube geometry of each heat exchanger is inputted by choosing the appropriate values of D_0 , D , D_w , A_r and $Thick$. Tube material is inputted by choosing the appropriate value of CON , the tube thermal conductivity. Tube cost parameters depend on both the tube geometry and tube material.

Table 1
OTEC OPTIMIZATION COMPUTER
PROGRAM INPUTS

C_1, C_2 and
 B_1, B_2

Tube Cost Parameters, \$/FT
 (see Tables 3 and 4)

$DO_C, D_C, D_{WC},$ Thick C and
 $DO_B, D_B, D_{WB},$ Thick B

Tube Geometry, Inches
 (see Figure 1)

A_r

Water Side Area Ratio

CON.


Tube Wall Thermal Conductivity, BTU/HR/FT/°F

Subscript C
 B

Symbolizes Condenser
 Symbolizes Boiler

A-5

Figure 1
Fluted Tube Geometry



The input parameter "Thick" is not the tube thickness. It is the tube thermal thickness. The thermal thickness is used to compute the wall heat transfer resistance using the following equation:

$$R = (\text{Thick}) (D) / (\text{CON}(D - \text{Thick}))$$

The thermal thickness is computed for each tube geometry using an isotherm analysis technique.

COST EQUATIONS

Our customer requested an itemized list of heat exchanger cost. Evaporator and condenser cost equations are listed in Tables 2 and 3. Heat exchanger cost depends on the number of tubes N, the tube total length, L, in feet and the tube outside diameter, D, in inches (this D is equal to the D0 in Table 1). In the evaporator the total tube length is greater than the tube heat transfer length by 3.5 feet. In the condenser, the difference is one foot. A clad or unclad tubesheet cost option is included. Input cost parameter B₁, B₂, C₁, and C₂ appear in the tube material cost equations.

The cost of space (cost of heat exchanger size) is no longer a part of the total system cost. Thus the penalty for large heat exchangers has been removed.

Figure 2 shows the insensitivity of evaporator length and hot water exit temperature with total system cost. Seawater entrance temperature is 80°F. The optimum length and exit temperatures are 34 feet, 73.8°F. At 26 feet, 74.7°F, the total system cost increases by \$0.15 million which is 0.93%. The differences between 40 feet, 73.2°F and 26 feet, 74.4°F is only 0.56%.

Table 2
EVAPORATOR Cost Equations

TUBES	MATERIAL	LABOR
	$N(B_1L+B_2)$	$28.10^{0.7}N$
Tubesheets Clad	$1.24D^{2.30}N^{1.15}$	$0.457N^{1.34}D^{0.68}(D-0.5) + 329(DN^{1/2}-148)^{1.5}^*$
Unclad	$0.105D^{2.5}N^{1.27}$	$0.307N^{1.33}D^{0.66}(D-0.5) + 221(DN^{1/2}-148)^{1.5}^*$
Tube Support Plates	$9.22(10^{-4})D^{3.046}N^{1.523}$	$0.124N^{1.295}D^{0.591}(D-0.5)$
Shell	$.012D^{2.29}N^{1.145}L$	$3.16D^{1.654}N^{0.827}L^{0.7}$
Water Boxes	$0.175D^{2.1}N^{1.05}$	$172.5D^{1.32}N^{0.66}$
Nozzles	$79.6D^{0.908}N^{0.454}$	$62.3D^{1.34}N^{0.67}$
Ammonia Distribution (Evaporator only)	$0.024D^{2.592}N^{1.296}$	$0.0962N^{1.38}D^{0.756}(D-0.5)$
Bustle (Evaporator only)	$0.0104D^{2.69}N^{1.345}$	$147.4D^{1.35}N^{0.675}$
Water Inlets	$12.0D^{1.28}N^{0.64}$	$92.3D^{1.27}N^{0.635}$
Supports	$0.053D^{2.090}N^{1.045}$	$27.1D^{1.33}N^{0.665}$

* If $(DN^{1/2}-148)$ is less than zero set $(DN^{1/2}-148)$ to zero.

B_1 and B_2 are tube cost inputs

Table 3
CONDENSER Cost Equations

TUBES	MATERIAL	LABOR
	$N(C_1L+C_2)$	$28.1D^{0.7}N$
Tubesheets Clad	$1.24D^{2.30}N^{1.15}$	$0.457N^{1.34}D^{0.68}(D-0.5) + 329(DN^{1/2}-148)^{1.5}$ *
Unclad	$0.105D^{2.5}N^{1.27}$	$0.307N^{1.33}D^{0.66}(D-0.5) + 221(DN^{1/2}-148)^{1.5}$ *
Tube Support Plates	$9.22(10^{-4})D^{3.046}N^{1.523}$	$0.124N^{1.295}D^{0.591}(D-0.5)$
Shell	$.012D^{2.29}N^{1.145}L$	$3.16D^{1.654}N^{0.827}L^{0.7}$
Water Boxes	$0.175D^{2.1}N^{1.05}$	$172.5D^{1.32}N^{0.66}$
Nozzles	$79.6D^{0.908}N^{0.454}$	$62.3D^{1.34}N^{0.67}$
Ammonia Distribution (Evaporator only)	Zero	Zero
Bustle (Evaporator only)	Zero	Zero
Water Inlets	$12.0D^{1.28}N^{0.64}$	$92.3D^{1.27}N^{0.635}$
Supports	$0.053D^{2.090}N^{1.045}$	$27.1D^{1.33}N^{0.665}$

* If $(DN^{1/2}-148)$ is less than zero set $(DN^{1/2}-148)$ to zero.

C_1 and C_2 are tube cost inputs

Figure 2

SENSITIVITY OF PROTOTYPE MODULE COST TO EVAPORATOR LENGTH (BTL) AND TO CHANGE IN WARM WATER TEMPERATURE (DTH). OTHER PROGRAM PARAMETERS ARE FIXED (CONDENSER LENGTH 35 FT. CHANGE IN COLD WATER TEMPERATURE 6.2°F).




Figure 2 also illustrates the computer sequential search optimization method described in reference 3, page E-2. Starting at BTL = 40 feet, DTH is varied in the direction of decreasing cost until a local minimum is reached at DTH = 6.8°F. The process is repeated with a new value of BTL, until a global minimum is found.

GROSS POWER ITERATION

Table 4 illustrates the updated gross power iteration method used in OTEC-II. This iteration finds the value of P_G (gross power) which solves


$$P_G = P_p + P_N$$

P_p (total parasitic power loss) is a function of P_G . P_N (net power, i.e. 10.5 MWe) is constant. The iteration usually requires 2 or 3 steps because the initial guess is very good. This method is much simpler, more accurate, and more reliable than the method in OTEC-I.

PRINTOUT

Table 5 shows the OTEC-II printout.

Table 4
Gross Power Iteration



P_G = Gross Power
 P_N = Net Power
 P_p = Total Parasitic Power

CASE NO 17

	W WATER PIPE	C WATER PIPE
LENGTH FEET	300	2900.0000
DIAMETER FT	15.8975	15.2525
NUMBER OF PIPES	1	1
H2O VEL FT/S	6.0000	6.0000
WATER FLOW LB/HR	2.7348E+08	2.5262E+08
PRESSURE DPOP PSI	.5577	3.0504
	EVAPORATOR	CONDENSER
BOTTOM REYNOLDS NUM	2.0403E+03	2.7510E+03
TOP REYNOLDS NUM	5.2243E+03	0.0
HEAT TRAN LENGTH FT	26.5000	29.0000
TOTAL LENGTH FT	30.0000	30.0000
SHELL DIAM FT	24.9483	25.2422
TUBE DIAMETER IN	.9900	.9900
NUMBER TUBES	42667	43678
TUBE MAT COST \$/FOOT	1.6500	1.3100
WATER TUBE VEL FT/SEC	6.6140	5.8228
NH3 ENT FLOW CFS		2.5943E+03
NH3 EXIT FLOW CFS	1.8666E+03	2.0691E+01
HEAT TRAN AREA SQ. FT.	2.6039E+05	2.9481E+05
HEAT TRANSFERED	1.5431E+09	1.4950E+09
OVERALL BTU/HR/F/FT**2	895.5240	796.0179
NH3 HTC BTU/HR/F/FT**2	11915.3145	15421.6060
WALL HTC BTU/HR/F/FT**2	2302.5576	2774.5603
WATER HTC BTU/HR/F/FT**2	1939.0474	1349.8842
H2O AREA RATIO	1.4600	1.4600
FOULING (FT**2 HR F/BTU)	1.0000E-04	1.0000E-04
H2O ENTRANCE TEMP F	80.0000	40.0000
CHANGE IN WATER TEMP	5.9000	6.2000
PRESSURE DROP PSID	4.1150	3.6098
NH3 OUTLET TEMP F	70.0000	50.0000
NH3 OUTLET PRES PSIA	128.7997	89.1924

CYCLE DATA

GROSS POWER MW	1.4032E+01	NET POWER MW	1.0500E+01
WW PUMPS MW	1.3514E+00	CW PUMPS MW	1.7731E+00
NH3 PUMPS MW	4.0766E-01	EVAPOR LB/SEC	8.0715E+02
TUR ENTHAL BTU	1.6813E+01	TUR EX QUALITY	2.4553E-02
PLANT EFF	2.3217E-02		

COST BREAKDOWN (\$)

EVAP HE COST	4.8252E+06	CON HE COST	4.1391E+06
WW PUMP COST	4.5070E+05	CW PUMP COST	4.1885E+05
NH3 R PUMP	1.0394E+05	NH3 F PUMP	8.0886E+04
GEN COST	6.2274E+05	TURBINE COST	8.2473E+05
CW PIPE	1.4591E+06	MISCEL	1.5000E+06
TOTAL SYSTEM	1.4425E+07	TOTAL BOTH HE	8.9643E+06

EVAPORATOR

CONDENSER

PART	MATERIAL	LABOR	MATERIAL	LABOR
TUBES	2.1120E+06	1.1905E+06	1.7165E+06	1.2187E+06
CLAD	0.	0.	0.	0.
UNCLAD	7.7713E+04	3.0886E+05	8.0059E+04	3.2173E+05
PLATES	1.0071E+04	5.9842E+04	1.0437E+04	6.1685E+04
SHELL	7.0431E+04	2.2675E+05	7.2345E+04	2.3118E+05
BOXES	1.2459E+04	1.9359E+05	1.2769E+04	1.9661E+05
NOZZLES	9.9773E+03	7.7768E+04	1.0084E+04	7.8998E+04
DIST	2.3415E+04	1.1471E+05	0.	0.
BUSTLE	1.7091E+04	1.9405E+05	0.	0.
INLETS	1.0886E+04	7.9390E+04	1.1050E+04	8.0580E+04
SUPPORT	3.5777E+03	3.2076E+04	3.6663E+03	3.2579E+04
EACH TOTAL	2.3476E+06	2.4776E+06	1.9170E+06	2.2221E+06

Correlations for the ammonia side heat transfer coefficients are usually given on a per tube basis. It was therefore decided to improve the OTEC computer model so that it could accept heat transfer correlations that are given on a per tube basis.

The overall heat transfer coefficient is given by:

$$\frac{1}{U} = \frac{D_w}{D H_w^C} + \frac{1}{H_{sw}} + F F_{sw} \quad (1)$$

The sea water heat transfer coefficient is given by:

$$H_{sw} = C_2 V^{0.8}$$

Where $C_2 = 0.027 \text{ K Pr}^{1/3} \frac{Ar}{D_w} \left[\frac{D_w \rho}{\mu} \right]^{0.8}$ (2)

The working fluid (ammonia) heat transfer coefficient (H_w^C) is a composite heat transfer coefficient. It is computed in the OTEC computer model in subroutine NH3 HTC as a function of the number of tubes.

$$H_w^C = H_w^C(N) \quad (3)$$

The seawater side fouling factor ($F F_{sw}$) is input to the program.

$$F F_{sw} = 0.0001 \text{ hr ft}^2 \text{ }^\circ\text{F/BTU} \quad (4)$$

The seawater velocity V is given by the volumetric flow per tube ($\frac{Q}{N}$) divided by the cross sectional area. This gives another equation for H_{sw} .

$$H_{sw} = C_2 \left(\frac{4Q}{D_w^2 \pi} \right)^{0.8} N^{-0.8} \quad (5)$$

Substitution of equation (5) into (1) and rearranging gives

$$U = \left[\frac{D_w}{D H_w^C} + \frac{N^{0.8}}{C_2 X_2} + F F_{sw} \right]^{-1} \quad (6)$$

Where $X_2 = \left(\frac{4Q}{D_w^2 \pi} \right)^{0.8}$

The total seawater side heat transfer area is given by

$$A = \pi D_w L N \quad (7)$$

Multiplying equations (6) by A and rearranging gives

$$N - X_3 N^{0.8} - \frac{X_4}{\frac{C}{HWf}} - X_5 = 0 \quad (8)$$

Where $X_1 = \pi D_w L$

$$X_3 = \frac{(UA)}{X_1 X_2 C_2}$$

$$X_4 = \frac{D_w (UA)}{D X_1}$$

$$X_5 = \frac{(UA) F F_{sw}}{X_1}$$

Equation (8) can be solved by Newton-Raphson iteration for N.

This iteration also requires knowledge of $\frac{C}{HWf}$ and $\frac{\partial HWf}{\partial N}$ which are computed for each heat exchanger in subroutine NH3 HTC. Equations (9), (10) and (11) demonstrate the Newton-Raphson method.

$$F = N - X_3 N^{0.8} - \frac{X_4}{\frac{C}{HWf}} - X_5 \quad (9)$$

$$\frac{\partial F}{\partial N} = 1 - 0.8 X_3 N^{-0.2} + \frac{X_4}{(\frac{C}{HWf})^2} \frac{\partial HWf}{\partial N} \quad (10)$$

$$N_{New} = N_{old} - \frac{F}{\left(\frac{\partial F}{\partial N}\right)} \quad (11)$$

EVAPORATOR

The evaporator heat transfer coefficient model is taken from Carnegie-Mellon data (see reference 1 and Figure 3). Since these coefficients are believed to be high, they were reduced by 20%. Equation (12) is the reduced correlation.

$$H^C = \frac{(2.939 Re_T^{.4151} - 63.217) 8 \times 10^5 - 5.633 Re_B^{1.8452}}{Re_T - Re_B} \quad (12)$$

This is a composite correlation for fluted tubes. We estimated the experimental wall resistance in this correlation to be R_o . Therefore the ammonia heat transfer coefficient (H_{wfb}) is:

$$H_{wfb} = 1 / \left(\frac{1}{H^C} - R_o \right) \quad (13)$$

We estimated the wall resistance in our system to be R . Therefore the composite coefficient for our system is:

$$H_{wf}^C = 1 / \left(\frac{1}{H_{wfb}} + R \right) \quad (14)$$

The value of H_{wf}^C used in the Newton-Raphson iteration on the number of tubes is computed from equations (14), (13) and (12). The Reynolds number at the top (Re_T) and the Reynolds number at the bottom (Re_B) of the evaporator are computed separately as explained later.

The derivative of equations (14), (13) and (12) with respect to the number of tubes gives the value of $\frac{\partial H_{wf}^C}{\partial N}$ used in the Newton-Raphson iteration on the number of tubes (equations (8), (9), (10) and (11)).

$$\frac{\partial H_{wf}^C}{\partial N} = \frac{1}{(1 + R H_{wfb})^2} \frac{\partial H_{wfb}}{\partial N} \quad (15)$$

$$\frac{\partial H_{wfb}}{\partial N} = \frac{1}{(1 - R_o H^C)^2} \frac{\partial H^C}{\partial N} \quad (16)$$

$$\frac{\partial H^C}{\partial N} = \frac{F_2 \frac{\partial F_1}{\partial N} - F_1 \frac{\partial F_2}{\partial N}}{F_2^2} \quad (17)$$

Where

$$H^c = F_1/F_2$$

$$F_1 = (2.939 Re_T^{0.4151} - 63.217) 8 \times 10^5 - 5.633 Re_B^{1.8452}$$

$$\frac{\partial F_1}{\partial N} = (-2.939)(0.415) 8 \times 10^5 \left(\frac{Re_T^{0.4151}}{N} \right) + 5.633(1.8452) \frac{Re_B^{1.8452}}{N}$$

$$F_2 = Re_T - Re_B$$

$$\frac{\partial F_2}{\partial N} = \frac{-Re_T}{N} + \frac{Re_B}{N}$$

With these values of H^c and $\frac{\partial H^c}{\partial N}$ the Newton-Raphson iterations can now be used to find the number of tubes. The Reynolds number at the top (Re_T) and at the bottom (Re_B) of the evaporator are computed using:

$$Re_T = \frac{3.17508 \times 10^8}{Re_B^{1.44537}} \quad (18)$$

$$WWF_T = WWF_B + WWF_e \quad (19)$$

$$Re_i = \frac{4 WWF_i}{\mu \pi DN} \quad (20)$$

Equation (18) is the relationship that gives the optimum recirculation ratio. WWF_e is known. Equations (18), (19) and (20) imply:

$$Re_B + C - \frac{A}{(Re_B)^B} = 0 \quad (21)$$

Where

$$C = \frac{4 WWF_e}{\pi \mu DN} = 3.546628 \frac{WWF_e}{DN}$$

$$A = 3.17508 \times 10^8$$

$$B = 1.44537$$

Equations (21) can be used to find Re_B by Newton-Raphson iteration.

This Newton-Raphson iteration goes as follows:

$$X = Re_B$$


$$F = X + C - AX^{-B}$$

$$\frac{\partial F}{\partial X} = 1 + BAX^{-B-1}$$

$$X_{\text{new}} = X_{\text{old}} \frac{F}{\left(\frac{\partial F}{\partial X}\right)}$$

Figure 3

EVAPORATOR AMMONIA HEAT TRANSFER MODEL



BASIS:

EXPERIMENTAL DATA ON FLUTED TUBES OBTAINED BY CMU. EQUIVALENT SMOOTH AREA BASED ON RILL-TO-RILL DIAMETER IS THE REFERENCE AREA.

CORRELATION RELATING Re_T AND Re_B :

$$Re_T = \frac{3.1751 \times 10^8}{Re_B^{1.4454}}$$

COMPOSITE COEFFICIENT:

$$h^c = \frac{[2.939 Re_T^{0.4151} - 63.22] 0.8 \times 10^6 - 5.633 Re_B^{1.8452}}{Re_T - Re_B}$$

SINCE h^c INCLUDES EFFECT OF 65 MILS WALL (ALUMINUM, $k = 116$):

$$\frac{1}{h_{NH3}} = \frac{1}{h^c} - \left(\frac{\Delta X}{k}\right)_{Al}$$

CONDENSER

The condenser heat transfer coefficient model is computed from a curve fit of Oak Ridge data for fluted tubes (see reference 2 and figure 4). Equation

(22) is the composite Oak Ridge coefficient (h_{OR}^C) curve fit.

$$h_{OR}^C = K_1 + \frac{K_2}{\frac{Q}{A_{OR}} + K_3} \quad (22)$$

$$= K_1 + \frac{K_2 \frac{P_{OR}}{P_{TRW}}}{\frac{Q}{A_{OR}} \frac{P_{OR}}{P_{TRW}} + K_3 \frac{P_{OR}}{P_{TRW}}} \quad (23)$$

Equation (22) was multiplied by the ratio P_{OR}/P_{TRW} to convert the Oak Ridge reference area to the TRW reference area. Equation (24) gives the relationship between the Oak Ridge coefficient and the TRW coefficient. Equation (25) is the condenser coefficient relation used in the OTEC computer model.

$$h_{TRW}^C = h_{OR}^C \frac{P_{OR}}{P_{TRW}} \quad (24)$$

$$h_{TRW}^C = C_1 + \frac{C_2}{\left(\frac{Q}{A}\right)_{TRW} + C_3} \quad (25)$$

Where K_1, K_2, K_3 are curve fit constants

P_{OR} = Oak Ridge outside tube perimeter for Tube E = 0.41667 FT.

P_{TRW} = TRW reference perimeter for Tube E = (.078125) = 0.2454

$\frac{Q}{A_{OR}}$ = Oak Ridge Heat Flux (Figure 2)

$$\frac{Q}{A_{TRW}} = \frac{Q}{A_{OR}} \frac{P_{OR}}{P_{TRW}}$$

$$C_1 = K_1 \frac{P_{OR}}{P_{TRW}} = -3231.62$$

$$C_2 = K_2 \left(\frac{P_{OR}}{P_{TRW}} \right)^2 = 3.684 \times 10^8$$

$$C_3 = K_3 \left(\frac{P_{OR}}{P_{TRW}} \right) = 20129.28$$


$$A = \pi DLN$$

To find the number of tubes in the condenser using Newton-Raphson iteration (equation (8), (9), (10) and (11)), h_w^c and $\frac{\partial h_w^c}{\partial N}$ must be known. As in the evaporator, the resistance R_0 and R in the condenser give the corresponding equations (13), (14), (15) and (16) for the condenser. The final equation is equation 17 which for the condenser comes from equation (25).

$$\frac{\partial h_{TRW}^c}{\partial N} = \frac{C_2 A}{NQ \left(1 + \frac{C_3 A}{Q} \right)^2}$$

(26)

Figure 4
 CONDENSER HEAT TRANSFER MODEL



BASIS:

EXPERIMENTAL DATA ON FLUTED TUBES OBTAINED BY ORNL (TUBE "E"). EQUIVALENT SMOOTH AREA BASED ON RILL-TO-RILL DIAMETER IS THE REFERENCE AREA.

$$h_{TRW}^o = -3231.62 + \frac{3.684 \times 10^8}{(\frac{q}{A})_{TRW} + 20,129.3}$$

THIS COMPOSITE h INCLUDES THE EFFECT OF THE ALUMINUM WALL IN THE OAK RIDGE EXPERIMENT, THEREFORE $(\Delta X \approx 0.031", k = 116)$

$$\left(\frac{1}{h}\right)_{NH_3} = \frac{1}{h_c} - \left(\frac{\Delta X}{k}\right)_{Al}$$

LIST OF SYMBOLS

A_r	Seawater side area ratio.
D	Ammonia side diameter measured to the flute root, FT
D_w	Seawater side (inside) diameter, FT
K	Thermal conductivity, BTU/HR/FT/°F
L	Tube length, FT
N	Number of tubes.
P_G	Gross power, MWe
Pr	Prandtl number.
Re_B	Bottom reynolds number.
Re_T	Top reynolds number.
WWF_B	Mass flow rate of ammonia at the bottom of the evaporator, LB/HR
WWF_e	Mass flow rate of ammonia evaporated, LB/HR
WWF_T	Mass flow rate of ammonia at the top of the evaporator, LB/HR
ρ	Density of ammonia, LB/FT ³
μ	Viscosity of ammonia, LB/HR/FT

REFERENCES

1. Sallie Ann Ward, "Analytical Models for Vertical Fluted Tube Heat Exchangers in Solar Sea Power Plants", Carnegie-Mellon University, (April, 1977).
2. S. K. Combs, An Experimental Study of Heat Transfer Enhancement for Ammonia Condensing on Vertical Fluted Tubes, ORNL-5356 (January, 1978).
3. TRW, "Ocean Thermal Energy Conversion Power System Utilizing Advanced, High-Performance Heat Transfer Techniques, Volume II", TRW SAN/1570-1 (January, 1978).

PROGRAM LISTING

```

00100 PROGRAM DTECI(INPUT,OUTPUT,TAPES=INPUT,TAPE6=OUTPUT)
00110 C
00120 C MAIN PROGRAM - INITIALIZES PARAMETERS,INPUTS DATA
00130 C AND CALLS OPTIMIZATION SUBROUTINE.
00140 C
00150 COMMON/REN/REDB,RETB,REBC,RRATIO
00160 COMMON/TIAL/THICKC,THICKB,CON
00170 COMMON/NH3D/HB(4),HF(4),SB(4),SF(4),VB(4),VF(4),PZ(4),X(4)
00180 COMMON/COBT/C,CBXT,CCXT,CCMT,CCUPT,CWUPT,CNOOR,
00190 + CTURBT,CSPT,CFPT,CRPT,CBENT
00200 COMMON/POWER/PN,PG,CUP,UWP
00210 COMMON/TEMP/TH,TC,BTH,DTC,T1,T2
00220 COMMON/DIH/H,DC,DH,NH,NC,MTB,NTC,CTL,BTL,
00230 IRKC,RKH,RKBX,RKCX,CL,PI,NCP
00240 COMMON/DIA/DWB,DUC,DB,BDC,DOB,DOC
00250 COMMON/PAR/PKU1,PKU2,PKU3,PKU4,BP1,DP2,DP3,BP4
00260 + ,PKU2T,PKU4T,PKU1T,PKU3T
00270 COMMON/EVAL/PAR(6),DPA(6),MMAX,NPB
00280 COMMON/ARRR/ARR
00290 COMMON/FAB/C11,C22,B11,B22
00300 COMMON/PRH/A(210),IUF
00310 COMMON/EFF/ETAP,ETAT,ETAB,XU
00320 COMMON/MXI/QAS,QRS,UB,UC,DT1,BT2
00330 COMMON/RAH/P1,P2,TA,EPSR,PUF,WUF,VA1,
00340 + VA2,VA3,DHI,DNA,PWFT
00350 COMMON/MXO/VAH,VAC,AB,AC,MTUB,MTUC,EP6B,EP6
00360 + C,UAB,UAC
00370 COMMON/HTC/FFB,FFC,HUFB,HUFC,HUALLC,HUALLB,HSUB,HSUC
00380 COMMON/OPTIONS/NMOD,NOP,NXH,NXUP,NAFP,NARP,NAT
00390 COMMON/NEXT/NEXT
00400 COMMON/AA/A11(14)
00410 COMMON/NAT/EM(12),CH(12)
00420 COMMON/LAB/EL(12),CL11(12)
00430 DIMENSION NA(36)
00440 REAL NTUB,NTUC
00450 DATA NOP,FAB/1,1./
00460 DATA NA/1,1,1,2,2,1,
00470 + 2,2,1,2,2,1,
00480 + 4,2,1,2,2,1,
00490 + 1,1,2,3,3,2,
00500 + 2,1,2,3,3,1,
00510 + 4,1,1,2,2,1/
00520 DATA RKC,RKCX,RKH,RKBX/3.1,0.70,1.85,0.70/
00530 DATA ETAP,ETAT,ETAB/0.804,0.85,0.98/
00540 DATA H,NH,NC,DH,DC,NCP/3000.,1,1,20.,50.,4/
00550 DATA BTL,CTL/26.5,29.0/
00560 DATA DWB,DUC1,DB1,DC1,DOB1,DOC1/.87963,.889,.91,.91,
00561 + .99,.99/
00570 DATA DTH,DTC/5.9,6.2/
00580 DATA CON,THICKC,THICKB/11.5,.04716,.05623/
00590 DATA C11,B11,C22,B22/1.31,1.65,2*0.0/
00600 DATA DPAR/2.,100.,2*0.1,2*1./
00610 DATA VDC,VCL,VDTH,VDTC,VBTL,VCTL/2.,200.,2*0.1,2*1./
00620 DATA PI,IUF,PMI,MMAX/3.14159265,1,10.5,10/
00630 DATA FFB,FFC/0.0001,0.0001/
00640 DATA ARR,DT1,DT2,XU/1.46,0.0,0.1,1./
00650 A11(14)=10HCASE NO 17
00660 C
00670 NAMELIST INPUT
00680 + NAMELIST/INPUT/H,DC,DTH,DTC,PMI,IUF,NH,NC,CTL,BTL,
00690 + RKC,RKH,RKBX,RKCX,ETAP,ETAB,DPA,NCP,FFB,FFC,
00700 + DWB,DUC1,DB1,DC1,DOB1,DOC1,NOP,A11,ETAT,
00710 + XU,ARR,DT1,DT2,C11,C22,B11,B22,CON,THICKC,THICKB
00720 + NAMELIST/PARA/DC,CL,DTH,DTC,BTL,CTL,VDC,VCL,VDTH,VDTC,VBTL,
00730 + VCTL,NEXT
00740 10 READ(5,INPUT)
00750 DOB=DOB1/12.
00760 DOC=DOC1/12.
00770 DWB=DWB1/12.
00780 DUC=DUC1/12.
00790 DB=DB1/12.
00800 DDC=DC1/12.
00810 C
00820 FOR OPTIONS A,B,C,D,E,F NOP IS EQUAL TO
00830 1, 2, 3, 4, 5, 6, RESPECTFULLY
00840 I=(NOP-1)*6
00850 NMOD=NA(I+1)
00860 NXH=NA(I+2)
00870 NXUP=NA(I+3)
00880 NAFP=NA(I+4)
00890 NARP=NA(I+5)
00900 NAT=NA(I+6)
00910 15 CALL BT(H,TH,TC)
00920 PAR(1)=DC
00930 PAR(2)=H-100.
00940 PAR(3)=DTH

```

```

00920      PAR(4)=DTC
00930      PAR(5)=BTL
00940      PAR(6)=CTL
00950      T1=TH-(TH-TC)/4.
00960      T2=TC+(TH-TC)/4.
00970      CALL RANKINE
00980      PN=PM1/RHOD
00990      PB=1.4*PN
01000      DISPLAY*      BTH      DTC      BTL      CTL      COST*
01010 20      CALL OPTIMIZ
01020 C      DISPLAY* *
01030 C      DISPLAY* *
01040 C      ENTER THE VALUE OF NEXT
01050      READ(5,PARA)
01060      IF(NEXT.EQ.10)GO TO 10
01070      IF(NEXT.EQ.1) GO TO 20
01080      IF(NEXT.EQ.3) GO TO 30
01100      PAR(1)=DC
01110      PAR(2)=CL
01120      DPAR(1)=VDC
01130      DPAR(2)=VCL
01140      PAR(3)=BTH
01150      PAR(4)=DTC
01160      PAR(5)=BTL
01170      PAR(6)=CTL
01180      DPAR(3)=VDBTH
01190      DPAR(4)=VDTC
01200      DPAR(5)=VDBTL
01210      DPAR(6)=VDBCTL
01220      GO TO 20
01230 30      CONTINUE
01240      CALL PRINT1
01250      GO TO 10
01260      END
01270      SUBROUTINE EVAL(J)
01280 C
01290 C      EVAL IS A "MASTER" SUBROUTINE WHICH EVALUATES OPERATING
01300 C      PARAMETERS AND COST OF A SPECIFIED DESIGN.
01310 C
01320      COMMON/OPTIONS/RHOD,NOP,NXH,NXUP,NAFP,NARP,NAT
01330      COMMON/REN/REDB,RETB,REBC,RRATIO
01340      COMMON/COST/C.CBXT,CCXT,CCUT,CCUPT,CUPT,CHOOR,
01350 +      CTURBT,CSPT,CFPT,CRPT,CGENT
01360      COMMON/POWER/PM,PB,CUP,HWP
01370      COMMON/CHOH/RHOC,RHOB,PHUC,PHUB,CPB,
01380 +      CPC,TKB,TKC
01390      COMMON/TEMP/TH,TC,BTH,DTC,T1,T2
01400      COMMON/DIM/H,DC,DH,NH,NC,NTB,NTC,CTL,BTL,
01410      IRKC,RKH,RKDX,RKCY,CL,P1,MCP
01420      COMMON/DIA/DUB,DUC,DB,DBC,DBB,BOC
01430      COMMON/PAR/PK1,P2,P3,P4,P5,P6,P7,P8,P9,P10,P11,P12,P13,P14,P15,P16,P17,P18,P19,P20,P21,P22,P23,P24,P25,P26,P27,P28,P29,P30,P31,P32,P33,P34,P35,P36,P37,P38,P39,P40,P41,P42,P43,P44,P45,P46,P47,P48,P49,P50,P51,P52,P53,P54,P55,P56,P57,P58,P59,P60,P61,P62,P63,P64,P65,P66,P67,P68,P69,P70,P71,P72,P73,P74,P75,P76,P77,P78,P79,P80,P81,P82,P83,P84,P85,P86,P87,P88,P89,P90,P91,P92,P93,P94,P95,P96,P97,P98,P99,P100,P101,P102,P103,P104,P105,P106,P107,P108,P109,P110,P111,P112,P113,P114,P115,P116,P117,P118,P119,P120,P121,P122,P123,P124,P125,P126,P127,P128,P129,P130,P131,P132,P133,P134,P135,P136,P137,P138,P139,P140,P141,P142,P143,P144,P145,P146,P147,P148,P149,P150,P151,P152,P153,P154,P155,P156,P157,P158,P159,P160,P161,P162,P163,P164,P165,P166,P167,P168,P169,P170,P171,P172,P173,P174,P175,P176,P177,P178,P179,P180,P181,P182,P183,P184,P185,P186,P187,P188,P189,P190,P191,P192,P193,P194,P195,P196,P197,P198,P199,P200,P201,P202,P203,P204,P205,P206,P207,P208,P209,P210,P211,P212,P213,P214,P215,P216,P217,P218,P219,P220,P221,P222,P223,P224,P225,P226,P227,P228,P229,P230,P231,P232,P233,P234,P235,P236,P237,P238,P239,P240,P241,P242,P243,P244,P245,P246,P247,P248,P249,P250,P251,P252,P253,P254,P255,P256,P257,P258,P259,P260,P261,P262,P263,P264,P265,P266,P267,P268,P269,P270,P271,P272,P273,P274,P275,P276,P277,P278,P279,P280,P281,P282,P283,P284,P285,P286,P287,P288,P289,P290,P291,P292,P293,P294,P295,P296,P297,P298,P299,P300,P301,P302,P303,P304,P305,P306,P307,P308,P309,P310,P311,P312,P313,P314,P315,P316,P317,P318,P319,P320,P321,P322,P323,P324,P325,P326,P327,P328,P329,P330,P331,P332,P333,P334,P335,P336,P337,P338,P339,P340,P341,P342,P343,P344,P345,P346,P347,P348,P349,P350,P351,P352,P353,P354,P355,P356,P357,P358,P359,P360,P361,P362,P363,P364,P365,P366,P367,P368,P369,P370,P371,P372,P373,P374,P375,P376,P377,P378,P379,P380,P381,P382,P383,P384,P385,P386,P387,P388,P389,P390,P391,P392,P393,P394,P395,P396,P397,P398,P399,P400,P401,P402,P403,P404,P405,P406,P407,P408,P409,P410,P411,P412,P413,P414,P415,P416,P417,P418,P419,P420,P421,P422,P423,P424,P425,P426,P427,P428,P429,P430,P431,P432,P433,P434,P435,P436,P437,P438,P439,P440,P441,P442,P443,P444,P445,P446,P447,P448,P449,P450,P451,P452,P453,P454,P455,P456,P457,P458,P459,P460,P461,P462,P463,P464,P465,P466,P467,P468,P469,P470,P471,P472,P473,P474,P475,P476,P477,P478,P479,P480,P481,P482,P483,P484,P485,P486,P487,P488,P489,P490,P491,P492,P493,P494,P495,P496,P497,P498,P499,P500,P501,P502,P503,P504,P505,P506,P507,P508,P509,P510,P511,P512,P513,P514,P515,P516,P517,P518,P519,P520,P521,P522,P523,P524,P525,P526,P527,P528,P529,P530,P531,P532,P533,P534,P535,P536,P537,P538,P539,P540,P541,P542,P543,P544,P545,P546,P547,P548,P549,P550,P551,P552,P553,P554,P555,P556,P557,P558,P559,P560,P561,P562,P563,P564,P565,P566,P567,P568,P569,P570,P571,P572,P573,P574,P575,P576,P577,P578,P579,P580,P581,P582,P583,P584,P585,P586,P587,P588,P589,P590,P591,P592,P593,P594,P595,P596,P597,P598,P599,P600,P601,P602,P603,P604,P605,P606,P607,P608,P609,P610,P611,P612,P613,P614,P615,P616,P617,P618,P619,P620,P621,P622,P623,P624,P625,P626,P627,P628,P629,P630,P631,P632,P633,P634,P635,P636,P637,P638,P639,P640,P641,P642,P643,P644,P645,P646,P647,P648,P649,P650,P651,P652,P653,P654,P655,P656,P657,P658,P659,P660,P661,P662,P663,P664,P665,P666,P667,P668,P669,P670,P671,P672,P673,P674,P675,P676,P677,P678,P679,P680,P681,P682,P683,P684,P685,P686,P687,P688,P689,P690,P691,P692,P693,P694,P695,P696,P697,P698,P699,P700,P701,P702,P703,P704,P705,P706,P707,P708,P709,P710,P711,P712,P713,P714,P715,P716,P717,P718,P719,P720,P721,P722,P723,P724,P725,P726,P727,P728,P729,P730,P731,P732,P733,P734,P735,P736,P737,P738,P739,P740,P741,P742,P743,P744,P745,P746,P747,P748,P749,P750,P751,P752,P753,P754,P755,P756,P757,P758,P759,P760,P761,P762,P763,P764,P765,P766,P767,P768,P769,P770,P771,P772,P773,P774,P775,P776,P777,P778,P779,P780,P781,P782,P783,P784,P785,P786,P787,P788,P789,P790,P791,P792,P793,P794,P795,P796,P797,P798,P799,P800,P801,P802,P803,P804,P805,P806,P807,P808,P809,P810,P811,P812,P813,P814,P815,P816,P817,P818,P819,P820,P821,P822,P823,P824,P825,P826,P827,P828,P829,P830,P831,P832,P833,P834,P835,P836,P837,P838,P839,P840,P841,P842,P843,P844,P845,P846,P847,P848,P849,P850,P851,P852,P853,P854,P855,P856,P857,P858,P859,P860,P861,P862,P863,P864,P865,P866,P867,P868,P869,P870,P871,P872,P873,P874,P875,P876,P877,P878,P879,P880,P881,P882,P883,P884,P885,P886,P887,P888,P889,P890,P891,P892,P893,P894,P895,P896,P897,P898,P899,P900,P901,P902,P903,P904,P905,P906,P907,P908,P909,P910,P911,P912,P913,P914,P915,P916,P917,P918,P919,P920,P921,P922,P923,P924,P925,P926,P927,P928,P929,P930,P931,P932,P933,P934,P935,P936,P937,P938,P939,P940,P941,P942,P943,P944,P945,P946,P947,P948,P949,P950,P951,P952,P953,P954,P955,P956,P957,P958,P959,P960,P961,P962,P963,P964,P965,P966,P967,P968,P969,P970,P971,P972,P973,P974,P975,P976,P977,P978,P979,P980,P981,P982,P983,P984,P985,P986,P987,P988,P989,P990,P991,P992,P993,P994,P995,P996,P997,P998,P999,P1000,P1001,P1002,P1003,P1004,P1005,P1006,P1007,P1008,P1009,P1010,P1011,P1012,P1013,P1014,P1015,P1016,P1017,P1018,P1019,P1020,P1021,P1022,P1023,P1024,P1025,P1026,P1027,P1028,P1029,P1030,P1031,P1032,P1033,P1034,P1035,P1036,P1037,P1038,P1039,P1040,P1041,P1042,P1043,P1044,P1045,P1046,P1047,P1048,P1049,P1050,P1051,P1052,P1053,P1054,P1055,P1056,P1057,P1058,P1059,P1060,P1061,P1062,P1063,P1064,P1065,P1066,P1067,P1068,P1069,P1070,P1071,P1072,P1073,P1074,P1075,P1076,P1077,P1078,P1079,P1080,P1081,P1082,P1083,P1084,P1085,P1086,P1087,P1088,P1089,P1090,P1091,P1092,P1093,P1094,P1095,P1096,P1097,P1098,P1099,P1100,P1101,P1102,P1103,P1104,P1105,P1106,P1107,P1108,P1109,P1110,P1111,P1112,P1113,P1114,P1115,P1116,P1117,P1118,P1119,P1120,P1121,P1122,P1123,P1124,P1125,P1126,P1127,P1128,P1129,P1130,P1131,P1132,P1133,P1134,P1135,P1136,P1137,P1138,P1139,P1140,P1141,P1142,P1143,P1144,P1145,P1146,P1147,P1148,P1149,P1150,P1151,P1152,P1153,P1154,P1155,P1156,P1157,P1158,P1159,P1160,P1161,P1162,P1163,P1164,P1165,P1166,P1167,P1168,P1169,P1170,P1171,P1172,P1173,P1174,P1175,P1176,P1177,P1178,P1179,P1180,P1181,P1182,P1183,P1184,P1185,P1186,P1187,P1188,P1189,P1190,P1191,P1192,P1193,P1194,P1195,P1196,P1197,P1198,P1199,P1200,P1201,P1202,P1203,P1204,P1205,P1206,P1207,P1208,P1209,P1210,P1211,P1212,P1213,P1214,P1215,P1216,P1217,P1218,P1219,P1220,P1221,P1222,P1223,P1224,P1225,P1226,P1227,P1228,P1229,P1230,P1231,P1232,P1233,P1234,P1235,P1236,P1237,P1238,P1239,P1240,P1241,P1242,P1243,P1244,P1245,P1246,P1247,P1248,P1249,P1250,P1251,P1252,P1253,P1254,P1255,P1256,P1257,P1258,P1259,P1260,P1261,P1262,P1263,P1264,P1265,P1266,P1267,P1268,P1269,P1270,P1271,P1272,P1273,P1274,P1275,P1276,P1277,P1278,P1279,P1280,P1281,P1282,P1283,P1284,P1285,P1286,P1287,P1288,P1289,P1290,P1291,P1292,P1293,P1294,P1295,P1296,P1297,P1298,P1299,P1300,P1301,P1302,P1303,P1304,P1305,P1306,P1307,P1308,P1309,P1310,P1311,P1312,P1313,P1314,P1315,P1316,P1317,P1318,P1319,P1320,P1321,P1322,P1323,P1324,P1325,P1326,P1327,P1328,P1329,P1330,P1331,P1332,P1333,P1334,P1335,P1336,P1337,P1338,P1339,P1340,P1341,P1342,P1343,P1344,P1345,P1346,P1347,P1348,P1349,P1350,P1351,P1352,P1353,P1354,P1355,P1356,P1357,P1358,P1359,P1360,P1361,P1362,P1363,P1364,P1365,P1366,P1367,P1368,P1369,P1370,P1371,P1372,P1373,P1374,P1375,P1376,P1377,P1378,P1379,P1380,P1381,P1382,P1383,P1384,P1385,P1386,P1387,P1388,P1389,P1390,P1391,P1392,P1393,P1394,P1395,P1396,P1397,P1398,P1399,P1400,P1401,P1402,P1403,P1404,P1405,P1406,P1407,P1408,P1409,P1410,P1411,P1412,P1413,P1414,P1415,P1416,P1417,P1418,P1419,P1420,P1421,P1422,P1423,P1424,P1425,P1426,P1427,P1428,P1429,P1430,P1431,P1432,P1433,P1434,P1435,P1436,P1437,P1438,P1439,P1440,P1441,P1442,P1443,P1444,P1445,P1446,P1447,P1448,P1449,P1450,P1451,P1452,P1453,P1454,P1455,P1456,P1457,P1458,P1459,P1460,P1461,P1462,P1463,P1464,P1465,P1466,P1467,P1468,P1469,P1470,P1471,P1472,P1473,P1474,P1475,P1476,P1477,P1478,P1479,P1480,P1481,P1482,P1483,P1484,P1485,P1486,P1487,P1488,P1489,P1490,P1491,P1492,P1493,P1494,P1495,P1496,P1497,P1498,P1499,P1500,P1501,P1502,P1503,P1504,P1505,P1506,P1507,P1508,P1509,P1510,P1511,P1512,P1513,P1514,P1515,P1516,P1517,P1518,P1519,P1520,P1521,P1522,P1523,P1524,P1525,P1526,P1527,P1528,P1529,P1530,P1531,P1532,P1533,P1534,P1535,P1536,P1537,P1538,P1539,P1540,P1541,P1542,P1543,P1544,P1545,P1546,P1547,P1548,P1549,P1550,P1551,P1552,P1553,P1554,P1555,P1556,P1557,P1558,P1559,P1560,P1561,P1562,P1563,P1564,P1565,P1566,P1567,P1568,P1569,P1570,P1571,P1572,P1573,P1574,P1575,P1576,P1577,P1578,P1579,P1580,P1581,P1582,P1583,P1584,P1585,P1586,P1587,P1588,P1589,P1590,P1591,P1592,P1593,P1594,P1595,P1596,P1597,P1598,P1599,P1600,P1601,P1602,P1603,P1604,P1605,P1606,P1607,P1608,P1609,P1610,P1611,P1612,P1613,P1614,P1615,P1616,P1617,P1618,P1619,P1620,P1621,P1622,P1623,P1624,P1625,P1626,P1627,P1628,P1629,P1630,P1631,P1632,P1633,P1634,P1635,P1636,P1637,P1638,P1639,P1640,P1641,P1642,P1643,P1644,P1645,P1646,P1647,P1648,P1649,P1650,P1651,P1652,P1653,P1654,P1655,P1656,P1657,P1658,P1659,P1660,P1661,P1662,P1663,P1664,P1665,P1666,P1667,P1668,P1669,P1670,P1671,P1672,P1673,P1674,P1675,P1676,P1677,P1678,P1679,P1680,P1681,P1682,P1683,P1684,P1685,P1686,P1687,P1688,P1689,P1690,P1691,P1692,P1693,P1694,P1695,P1696,P1697,P1698,P1699,P1700,P1701,P1702,P1703,P1704,P1705,P1706,P1707,P1708,P1709,P1710,P1711,P1712,P1713,P1714,P1715,P1716,P1717,P1718,P1719,P1720,P1721,P1722,P1723,P1724,P1725,P1726,P1727,P1728,P1729,P1730,P1731,P1732,P1733,P1734,P1735,P1736,P1737,P1738,P1739,P1740,P1741,P1742,P1743,P1744,P1745,P1746,P1747,P1748,P1749,P1750,P1751,P1752,P1753,P1754,P1755,P1756,P1757,P1758,P1759,P1760,P1761,P1762,P1763,P1764,P1765,P1766,P1767,P1768,P1769,P1770,P1771,P1772,P1773,P1774,P1775,P1776,P1777,P1778,P1779,P1780,P1781,P1782,P1783,P1784,P1785,P1786,P1787,P1788,P1789,P1790,P1791,P1792,P1793,P1794,P1795,P1796,P1797,P1798,P1799,P1800,P1801,P1802,P1803,P1804,P1805,P1806,P1807,P1808,P1809,P1810,P1811,P1812,P1813,P1814,P1815,P1816,P1817,P1818,P1819,P1820,P1821,P1822,P1823,P1824,P1825,P1826,P1827,P1828,P1829,P1830,P1831,P1832,P1833,P1834,P1835,P1836,P1837,P1838,P1839,P1840,P1841,P1842,P1843,P1844,P1845,P1846,P1847,P1848,P1849,P1850,P1851,P1852,P1853,P1854,P1855,P1856,P1857,P1858,P1859,P1860,P1861,P1862,P1863,P1864,P1865,P1866,P1867,P1868,P1869,P1870,P1871,P1872,P1873,P1874,P1875,P1876,P1877,P1878,P1879,P1880,P1881,P1882,P1883,P1884,P1885,P1886,P1887,P1888,P1889,P1890,P1891,P1892,P1893,P1894,P1895,P1896,P1897,P1898,P1899,P1900,P1901,P1902,P1903,P1904,P1905,P1906,P1907,P1908,P1909,P1910,P1911,P1912,P1913,P1914,P1915,P1916,P1917,P1918,P1919,P1920,P1921,P1922,P1923,P1924,P1925,P1926,P1927,P1928,P1929,P1930,P1931,P1932,P1933,P1934,P1935,P1936,P1937,P1938,P1939,P1940,P1941,P1942,P1943,P1944,P1945,P1946,P1947,P1948,P1949,P1950,P1951,P1952,P1953,P1954,P1955,P1956,P1957,P1958,P1959,P1960,P1961,P1962,P1963,P1964,P1965,P1966,P1967,P1968,P1969,P1970,P1971,P1972,P1973,P1974,P1975,P1976,P1977,P1978,P1979,P1980,P1981,P1982,P1983,P1984,P1985,P1986,P1987,P1988,P1989,P1990,P1991,P1992,P1993,P1994,P1995,P1996,P1997,P1998,P1999,P2000,P2001,P2002,P2003,P2004,P2005,P2006,P2007,P2008,P2009,P2010,P2011,P2012,P2013,P2014,P2015,P2016,P2017,P2018,P2019,P2020,P2021,P2022,P2023,P2024,P2025,P2026,P2027,P2028,P2029,P2030,P2031,P2032,P2033,P2034,P2035,P2036,P2037,P2038,P2039,P2040,P2041,P2042,P2043,P2044,P2045,P2046,P2047,P2048,P2049,P2050,P2051,P2052,P2053,P2054,P2055,P2056,P2057,P2058,P2059,P2060,P2061,P2062,P2063,P2064,P2065,P2066,P2067,P2068,P2069,P2070,P2071,P2072,P2073,P2074,P2075,P2076,P2077,P2078,P2079,P2080,P2081,P2082,P2083,P2084,P2085,P2086,P2087,P2088,P2089,P2090,P2091,P2092,P2093,P2094,P2095,P2096,P2097,P2098,P2099,P2100,P2101,P2102,P2103,P2104,P2105,P2106,P2107,P2108,P2109,P2110,P2111,P2112,P2113,P2114,P2115,P2116,P2117,P2118,P2119,P2120,P2121,P2122,P2123,P2124,P2125,P2126,P2127,P2128,P2129,P2130,P2131,P2132,P2133,P2134,P2135,P2136,P2137,P2138,P2139,P2140,P2141,P2142,P2143,P2144,P2145,P2146,P2147,P2148,P2149,P2150,P2151,P2152,P2153,P2154,P2155,P2156,P2157,P2158,P2159,P2160,P2161,P2162,P2163,P2164,P2165,P2166,P2167,P2168,P2169,P2170,P2171,P2172,P2173,P2174,P2175,P2176,P2177,P2178,P2179,P2180,P2181,P2182,P2183,P2184,P2185,P2186,P2187,P2188,P2189,P2190,P2191,P2192,P2193,P2194,P2195,P2196,P2197,P2198,P2199,P2200,P2201,P2202,P2203,P2204,P2205,P2206,P2207,P2208,P2209,P2210,P2211,P2212,P2213,P2214,P2215,P2216,P2217,P2218,P2219,P2220,P2221,P2222,P2223,P2224,P2225,P2226,P2227,P2228,P2229,P2230,P2231,P2232,P2233,P2234,P2235,P2236,P2237,P2238,P2239,P2240,P2241,P2242,P2243,P2244,P2245,P2246,P2247,P2248,P2249,P2250,P2251,P2252,P2253,P2254,P2255,P2256,P2257,P2258,P2259,P2260,P2261,P2262,P2263,P2264,P2265,P2266,P2267,P2268,P2269,P2270,P2271,P2272,P2273,P2274,P2275,P2276,P2277,P2278,P2279,P2280,P2281,P2282,P2283,P2284,P2285,P2286,P2287,P2288,P2289,P2290,P2291,P2292,P2293,P2294,P2295,P2296,P2297,P2298,P2299,P2300,P2301,P2302,P2303,P2304,P2305,P2306,P2307,P2308,P2309,P2310,P2311,P2312,P2313,P2314,P2315,P2316,P2317,P2318,P2319,P2320,P2321,P2322,P2323,P2324,P2325,P2326,P2327,P2328,P2329,P2330,P2331,P2332,P2333,P2334,P2335,P2336,P2337,P2338,P2339,P2340,P2341,P2342,P2343,P2344,P2345,P2346,P2347,P2348,P2349,P2350,P2351,P2352,P2353,P2354,P2355,P2356,P2357,P2358,P2359,P2360,P2361,P2362,P2363,P2364,P2365,P2366,P2367,P2368,P2369,P2370,P2371,P2372,P2373,P2374,P2375,P2376,P2377,P2378,P2379,P2380,P2381,P2382,P2383,P2384,P2385,P2386,P2387,P2388,P2389,P2390,P2391,P2392,P2393,P2394,P2395,P2396,P2397,P2398,P2399,P2400,P2401,P2402,P2403,P2404,P2405,P2406,P2407,P2408,P2409,P2410,P2411,P2412,P2413,P2414,P2415,P2416,P2417,P2418,P2419,P2420,P2421,P2422,P2423,P2424,P2425,P2426,P2427,P2428,P2429,P2430,P2431,P2432,P2433,P2434,P2435,P2436,P2437,P2438,P2439,P2440,P2441,P2442,P2443,P2444,P2445,P2446,P2447,P2448,P2449,P2450,P2451,P2452,P2453,P2454,P2455,P2456,P2457,P2458,P2459,P2460,P2461,P2462,P2463,P2464,P2465,P2466,P2467,P2468,P2469,P2470,P2471,P2472,P2473,P2474,P2475,P2476,P2477,P2478,P2479,P2480,P2481,P2482,P2483,P2484,P2485,P2486,P2487,P2488,P2489,P2490,P2491,P2492,P2493,P2494,P2495,P2496,P2497,P2498,P2499,P2500,P2501,P2502,P2503,P2504,P2505,P2506,P2507,P2508,P2509,P2510,P2511,P2512,P2513,P2514,P2515,P2516,P2517,P2518,P2519,P2520,P2521,P2522,P2523,P2524,P2525,P2526,P2527,P2528,P25
```

```

01770 + RHOB,DUB,DB,DOB,FFB,VAH/NXH,2,BTL,UB,
01780 +XN,PB,QRS,WUF)
01790 NTB=XN
01800 CALL UCALC(UAC/NXH,AC,CPC,PNUC,TKC,
01810 + RHOC,DUC,DDC,DCC,FFC,VAC/NXH,1,CTL,UC,
01820 +XN,PB,QRS,WUF)
01830 NTC=XN
01840 15 CALL PDROP(NC,VAC*NMOD,BC,CL*300.,0.01,RKC,DP1,PKU1,VELCP,RH
01850 + OC,PNUC,1)
01860 PKU1T=PKU1/(NMOD)
01870 CALL PDROP(NTC,VAC/NXH,DUC,CTL*1.,0.0001,RKCK,DP2
01880 + ,PKU2,VELC,RHOC,PNUC,2)
01890 PKU2T=PKU2/NXH
01900 CALL PDROP(NH,VAH/NXH,BH,300.,0.02,RKH,DP3,PKU3,VELHP,
01910 + RHOB,PNUB,3)
01920 PKU3T=PKU3/NXH
01930 CALL PDROP(NTB,VAH/NXH,DUB,BTL*3.5,0.0001,RKDX,DP4
01940 + ,PKU4,VELB,RHOB,PNUB,4)
01950 PKU4T=PKU4/NXH
01960 PP1=(PKU1T+PKU2T+PKU3T+PKU4T)/1000
01970 RRATIO=RETB/(RETB-REDB)
01980 PP22=PWFT*RRATIO*((BTL*20.)/(144*VF(3))+5.)/(PZ(1)-PZ(3))
01990 PP2=(PWFT*1.1*PB+PP22*PB+PKU1T*1.33/DP1)/1000.
02000 PP=PP1+PP2
02010 IF(ABS((PG-PP-PN)/PN).LT.0.001)GO TO 100
02020 PB=PG-1.3*(PG-PP-PN)
02030 IF(PG.GT.2.*PN)GO TO 110
02040 IF(NPB.EQ.100)GO TO 110
02050 GO TO 10
02060 100 CONTINUE
02070 CALL COST
02080 RETURN
02090 110 C=1.E10
02100 RETURN
02110 END
02120 SUBROUTINE RANKINE
02130 C
02140 C RANKINE COMPUTES RANKINE CYCLE PARAMETERS,GIVEN
02150 C WORKING FLUID AND OPERATING TEMPERATURES.
02160 C
02170 COMMON/OPTIONS/NMOD,NOP,NXH,NXUP,NAFP,NARP,MAT
02180 COMMON/TEMP/TH,TC,DTH,DTC,T1,T2
02190 COMMON/HX/QAS,QRS,UB,UC,DT1,DT2
02200 COMMON/EFF/ETAP,ETAT,ETAQ,XU
02210 COMMON/RAN/P1,P2,YA,EPSR,PUF,WUF,VA1,
02220 + VA2,VA3,DHI,DHA,PUFT
02230 COMMON/DTDP/DTDP(2,3)
02240 COMMON/PRN/A(210),IUF
02250 COMMON/NH3D/HG(4),HF(4),SG(4),SF(4),VG(4),VF(4),PZ(4),X(4)
02260 DATA DTDP/0.44,0.58,0.74,0.95,0.55,0.69/
02270 333 X(1)=T1
02280 X(2)=T1+DT1
02290 X(3)=T2
02300 X(4)=T2-DT2
02310 DO 11 I=1,4
02320 CALL THERMO(X(I),VF(I),VG(I),HF(I),HG(I),SG(I),SF(I),PZ(I))
02330 11 CONTINUE
02340 P1=PZ(1)
02350 P2=PZ(3)
02360 UPI=144./778.16*(P1-P2)*VF(4)
02370 WPA=WPI/0.72
02380 QA=HG(1)-HF(4)-WPA
02390 YI=(SG(3)-SG(1))/(SG(3)-SF(3))
02400 DHI=(HG(1)-(HG(3)-YI*(HG(3)-HF(3))))*(P1-
02410 + P2-0.1)/(P1-P2)
02420 EPSR=(DHI-WPA)/(QA)
02430 DHA=ETAT*DHI
02440 YA=(DHA+HG(3)-HG(1))/(HG(3)-HF(3))
02450 DHB=ETAQ*DHA
02460 PWF=WPA*1000./DHB
02470 PUFT=PWF
02480 WUF=3412.+1000./60./DHB
02490 VA1=WUF*VG(1)
02500 VA2=WUF*(YA*VF(3)+(1.-YA)*VF(3))
02510 QAS=QA+WUF*60.
02520 QRS=(HG(1)-HF(4)-DHA)*WUF*60.
02530 VA3=WUF*VF(4)
02540 RETURN
02550 END
02560 SUBROUTINE THERMO(X1,VF1,VG1,HF1,HG1,SG1,SF1,P1)
02570 C
02580 COMMON/PRN/A(210),IUF
02590 P11 =FX(1,X1)
02600 VF1=FX(2,X1)

```

```

02610      V81=FX(3,X1)
02620      HF1=FX(4,X1)
02630      HG1=FX(5,X1)
02640      SF1=FX(6,X1)
02650      SG1=FX(7,X1)
02660      RETURN
02670      END
02680      SUBROUTINE CUATER(X,TK,CP,PNH,RHD)
02690 C
02700 C
02710 C
02720      DATA CO,C1,RO,R1,R2,TO,T1,P0,P1,P2/.95213,5.4727E-3,
02730 +      6.4131E+1,-6.8811E-4,-4.9417E-5,3.1043E-1,5.2E-4,
02740 +      7.218,-1.0139E-1,4.903E-4/
02750      TK=(TO+T1*X)/3600.
02760      CP=CO+C1*X
02770      RHD=RO+R1*X+R2*X**2
02780      PNH=(P0+P1*X+P2*X**2)/3600.
02790 C
02800 C
02810 C
02820      RETURN
02830      END
02840      SUBROUTINE HX(PB)
02850 C
02860 C      THIS IS A HEAT EXCHANGER SIZING (UA) ROUTINE.
02870 C
02880      REAL NTUB,NTUC
02890      COMMON/TEMP/TH,TC,DTH,DTC,T1,T2
02900      COMMON/HX1/QAS,QRS,UB,UC,DT1,DT2
02910      COMMON/OPTIONS/MNOD,NOP,NXM,NXWP,NAFP,NARP,NAT
02920      COMMON/HX0/VAH,VAC,AB,AC,NTUB,NTUC,EP5B,EP5
02930 +      C,UAB,UAC
02940      COMMON/CHOH/RHOC,RHOB,PHUC,PNUB,CPB,
02950 +      CPC,TKB,TKC
02960      CUH=PB+QAS/DTH
02970      VAH=CUH/(CPB+RHOB*3600.)
02980      IF((TH-DTH).LT.(T1-DT1+0.001)) GO TO 10
02990      UAB=CUH*ALOG((TH-T1)/(TH-DTH-DT1-T1
03000 +      ))*DTH/(DTH+DT1)
03010      GO TO 11
03020 10      UAB=1.E20
03030      RETURN
03040 11      CONTINUE
03050      NTUB=UAB/CUH
03060      EP5B=1.-EXP(-NTUB)
03070 30      CONTINUE
03080      CUC=PB+QRS/DTC
03090      VAC=CUC/(CPC+RHOC*3600.)
03100      IF((TC+DTC).GT.(T2-0.001)) GO TO 20
03110      IF((TC+0.001).GT.(T2-DT2)) GO TO 20
03120      UAC=CUC*ALOG((T2-TC-DT2)/(T2-TC-DT
03130 +      ))*DTC/(DTC-DT2)
03140      GO TO 41
03150 20      UAC=1.E20
03160      RETURN
03170 41      CONTINUE
03180      NTUC=UAC/CUC
03190      EP5C=1.-EXP(-NTUC)
03200 40      CONTINUE
03210      RETURN
03220      END
03230      FUNCTION FX(N,X)
03240 C
03250 C      COMPUTE THERMODYNAMIC PARAMETERS BY POLYNOMIAL APPROX.
03260 C
03270      COMMON /PRM/ A(10,7,3), M
03280      FX = A(8,M,N)
03290      DO 5 I=1,7
03300 5      FX = A(I-1,M,N) + X*FX
03310      RETURN
03320      END
03330      BLOCK DATA
03340 C
03350 C      THERMODYNAMIC DATA CORRELATIONS FOR THREE WORKING FLUIDS.
03360 C
03370      DIMENSION A(210)
03380      COMMON /PRM/ AN(10,7,3), M
03390      EQUIVALENCE (A,AN)
03400 C          NH3, M=1
03410 C          R12/31, M=2
03420 C          C3H8, M=3
03430      DATA (A(I),I=1,70)/84.133493,-3.9453629,.15738164,-.1913845E-2,
03440      9.1422349E-3,.18339454E-6,-.11582025E-8,3*0.,

```

```

03450      B.024006455,.31671989E-4,.19186155E-7,7*0.,
03460      D8.5193668,-.15928666,1.3131055E-3,-4.3466241E-6,6*0.,
03470      D43.487815,1.0582983,6.0084034E-4,7*0.,
03480      D611.76387,.32369748,-1.0868347E-3,7*0.,
03490      D.097824697,.23223434E-2,-.13707722E-5,7*0.,
03500      D1.3331697,-.18926911E-2,.27186791E-5,7*0./
03510      DATA (A(I),I=141,210)/38.230987,.7607506,.0053448139,.20438083E-4,
03520      D6*0.,.0285395,.49614286E-4,8*0.,
03530      D2.599814,-.042940313,.33701757E-3,-.11431079E-5,6*0.,
03540      D22.295251,.57566684,.2100919E-3,.17800981E-5,6*0.,
03550      D192.37849,.24008893,.6844913E-3,-.1036914E-4,.40020469E-7,5*0.,
03560      D.051873571,.0011781429,8*0.,.41891072,-.18447649E-3,.69524078E-6,
03570      D7*0./
03580      DATA (A(I),I=71,140)/23.525983,.51905623,3.9539428E-3,
03590      D1.8760553E-5,6*0.,.011383466,1.1766036E-5,4.3291317E-8,7*0.,
03600      D1.8709644,-.035334956,3.5435288E-4,-2.0419788E-6,5.2201533E-9,
03610      D5*0.,8.9574725,.23667748,-3.4996582E-6,6.8474216E-7,6*0.,
03620      D90.829294,.11175462,-1.4016807E-4,7*0.,
03630      D.02036797,5.0953434E-4,-5.0909091E-7,1.4141414E-9,6*0.,
03640      D,19859993,-1.5477577E-4,6.6334017E-7,-1.8607124E-9,6*0./
03650      END
03660      SUBROUTINE FRICFAC(RE,EOD,FD)
03670 C
03680 C      COMPUTES FRICTION FACTORS USING COLEBROOKS CORRELATION.
03690 C
03700      COMMON/ARRR/ARR
03710      INTEGER E
03720      IF(RE.LT.500000.) GO TO 11
03730      FD = .316/SQRT(SQRT(RE))
03740      X = 1./SQRT(FD)
03750      A = EOD/3.7
03760      B = 2.51/RE
03770      DX = 0.
03780      N = -1
03790 2   X = X + DX
03800      U = A + B*X
03810      IF(U.LE.0.0)GO TO 12
03820      DYDX = 1. + .86*B/U
03830      DX = -(X + .86*ALOG(U))/DYDX
03840      N = N + 1
03850      IF(ABS(DX/X).GT..001) GO TO 5
03860      FD = 1./(X*X)
03870      RETURN
03880 12   FD=.316/SQRT(SQRT(RE))
03890      RETURN
03900 11   CONTINUE
03910      DATA C1,C2,C3/0.025,-0.7534,1.386/
03920      REL=ALOG(RE)
03930      FDL=C1*(REL**2)+C2*REL+C3
03940      FD=EXP(FDL)
03950      FD=FD*ARR
03960 10   CONTINUE
03970      RETURN
03980      END
03990      SUBROUTINE PDROP(N,B,D,EL,EPS,RK,DP,PKU,VEL,RHO,PMU,I)
04000 C
04010 C      COMPUTES PRESSURE DROP AND PUMPING POWER
04020 C      FOR A GIVEN PIPE OR TUBE ARRANGEMENT.
04030      COMMON/EFF/ETAP,ETAT,ETAG,XU
04040      VEL = 4.*B/(D**3.14159*N)
04050      IF(I.EQ.2.OR.I.EQ.4)GO TO 10
04060      VEL=6.
04070      D=SQRT(4*B/(N*3.14159*VEL))
04080 10   CONTINUE
04090      RE = RHO*VEL*D/PMU
04100      CALL FRICFAC(RE,EPS/D,FD)
04110      DP = (FD*EL/D + RK)*RHO*VEL*VEL/(2.*144.*32.174)
04120      PKU = 144.*DP*B/(550.*1.341*ETAP)
04130      RETURN
04140      END
04150      SUBROUTINE BT(H,TH1,TC1)
04160 C
04170 C      TEMPERATURE-DEPTH PROFILE.
04180 C
04190      TH1=.79.
04200      TC1=39.+39.4*EXP(-(H-100.)/977.)
04210      TH1=80.
04220      TC1=40.
04230      RETURN
04240      END
04250      SUBROUTINE OPTIMIZ
04260 C
04270 C      OPTIMIZATION (COST MINIMIZATION) ROUTINE
04280 C      SEQUENTIAL DIRECT SEARCH.

```

```

04290 C
04300 COMMON/OPTIONS/NMOD,NOP,NXM,NXUP,NAFP,NARP,NAT
04310 COMMON/EVAL/PAR(6),DPAR(6),NMAX,NPG
04320 COMMON/COST/C,CBXT,CCXT,CCUT,CCUPT,CUOPT,CMOOR,
04330 + CTURBT,CBPT,CFPT,CRPT,CGENT
04340 COMMON/NEXT/NEXT
04350 IF(NEXT.EQ.4) GO TO 110
04360 C DISPLAY* J PAR(J) COST*
04370 DO 100 J=3,6
04380 N=1
04390 10 CALL EVAL(J)
04400 C WRITE(6,25) J,PAR(J),C,NPG
04410 25 FORMAT(12,2X,F10.3,2X,E10.3,I6)
04420 IF(N.NE.1) GO TO 40
04430 20 CO=C
04440 30 N=N+1
04450 PAR(J)=PAR(J)+DPAR(J)
04460 GO TO 10
04470 40 IF(C.GE.CO) GO TO 50
04480 IF(N.GT.NMAX) GO TO 60
04490 GO TO 20
04500 50 DPAR(J)=-DPAR(J)
04510 PAR(J)=PAR(J)+DPAR(J)
04520 IF(N.EQ.2) GO TO 30
04530 60 CONTINUE
04540 100 CONTINUE
04550 110 CALL EVAL(6)
04560 82 PRINT 80,(PAR(J),J=3,6),C,NPG
04570 80 FORMAT(5F9.2,I6)
04580 RETURN
04590 END
04600 SUBROUTINE COST
04610 C
04620 C COMPUTES DIRECT COST OF TRADE OFF SENSITIVE COST ELEMENTS.
04630 C
04640 COMMON/COST/C,CBXT,CCXT,CCUT,CCUPT,CUOPT,CMOOR,
04650 + CTURBT,CBPT,CFPT,CRPT,CGENT
04660 COMMON/OPTIONS/NMOD,NOP,NXM,NXUP,NAFP,NARP,NAT
04670 COMMON/POWER/PN,PB,CUP,UUP
04680 COMMON/TEMP/TH,TC,DTH,DTC,T1,T2
04690 COMMON/DIM/H,DC,DH,NH,NC,NTB,NTC,CTL,BTL,
04700 + RKC,RKH,RKBX,RKCX,CL,PI,NCP
04710 COMMON/DIA/DWB,DWC,DB,DDC,DOB,DOC
04720 COMMON/PAR/PKU1,PKU2,PKU3,PKU4,DP1,DP2,DP3,DP4
04730 + ,PKU2T,PKU4T,PKU1T,PKU3T
04740 COMMON/EVAL/PAR(6),DPAR(6),NMAX,NPG
04750 COMMON/PRM/A(210),IUF
04760 COMMON/EFF/ETAP,ETAT,ETAB,XU
04770 COMMON/MXI/QAS,GRS,UB,UC,DT1,DT2
04780 COMMON/RAN/P1,P2,PA,EPSR,PVF,UWF,VA1,
04790 + VA2,VA3,BH1,DHA,PUFT
04800 COMMON/HXO/VAH,VAC,AB,AC,NTUB,NTUC,EP6B,EP6
04810 + C,HAB,UAC
04820 COMMON/VEL/VELCP,VELC,VELHP,VELB
04830 COMMON/TURB/W3,W3
04840 COMMON/AA/A11(14)
04850 COMMON/MAT/EN(12),CH(12)
04860 COMMON/LAB/EL(12),CL1(112)
04870 COMMON/PAB/C11,C22,D11,D22
04880 COMMON/REN/REBB,RETB,REBC,RRATIO
04890 REAL NTUB,NTUC
04900 C IF IC=1 TUBESHEETS CLAD WHICH IMPLIES EN3=EL3=0.0
04910 IC=2
04920 L2=0.0
04930 D=DOB*12.
04940 XN=NTB
04950 XL=DTL*3.5
04960 EN(1)=XN*(B11*XL+B22)
04970 EN(2)=1.24*D+2.300*XN+1.150
04980 EN(3)=.105*D+2.500*XN+1.27
04990 IF(IC.EQ.1)EN(3)=0.0
05000 IF(IC.NE.1)EN(2)=0.0
05010 EN(4)=(9.22*D+3.046*XN+1.523)/10000.
05020 EN(5)=.012*D+2.290*XN+1.145*XL
05030 EN(6)=.175*D+2.100*XN+1.05
05040 EN(7)=79.6*D+0.908*XN+0.454
05050 EN(8)=.024*D+2.592*XN+1.296
05060 EN(9)=0.0104*D+2.690*XN+1.345
05070 EN(10)=12.0*D+1.280*XN+0.64
05080 EN(11)=0.053*D+2.090*XN+1.045
05090 EL(1)=28.10*D+0.700*XN+1.0
05100 F=D*XN+0.5-148.
05110 IF(F.LT.0.0)F=0.0
05120 EL(2)=0.457*D+0.680*XN+1.34*(D-0.5)+329.*F+1.5

```

```

05130 EL(3)=0.307*D+0.660*XN+1.33*(D-0.5)+221.*F+0.5
05140 IF(IC.EB.1)EL(3)=0.0
05150 IF(IC.NE.1)EL(2)=0.0
05160 EL(4)=0.124*D+0.591*XN+1.295*(D-0.5)
05170 EL(5)=3.160*D+1.654*XN+0.827*XL+0.7
05180 EL(6)=172.5*D+1.320*XN+0.66
05190 EL(7)=62.30*D+1.340*XN+0.67
05200 EL(8)=.0962*D+0.756*XN+1.38*(D-0.5)
05210 EL(9)=147.4*D+1.350*XN+0.675
05220 EL(10)=92.30*D+1.270*XN+0.635
05230 EL(11)=27.10*D+1.33*XN+0.665
05240 EL(12)=0.0
05250 EM(12)=0.0
05260 DO 50 I=1,11
05270 EL(12)=EL(12)+EL(I)
05280 EM(12)=EM(12)+EM(I)
05290 50 CONTINUE
05300 CBX=EL(12)+EM(12)
05310 CBXT=CBX*NXN*NM0D
05320 SP1=1.6833*XL*XN+D0B+D0B
05330 C CONDENSER
05340 D=D0C+12.
05350 XN=NTC
05360 XL=CTL+1.0
05370 CM(1)=XN*(C11*XL+C22)
05380 CM(2)=1.24*D+2.300*XN+1.150
05390 CM(3)=-.105*D+2.500*XN+1.27
05400 IF(IC.EQ.1)CM(3)=0.0
05410 IF(IC.NE.1)CM(2)=0.0
05420 CM(4)=(9.22*D+3.046*XN+1.523)/10000.
05430 CM(5)=-.012*D+2.290*XN+1.145*XL
05440 CM(6)=-.175*D+2.100*XN+1.05
05450 CM(7)=79.6*D+0.908*XN+0.454
05460 CM(8)=0.0
05470 CM(9)=0.0
05480 CM(10)=12.0*D+1.280*XN+0.64
05490 CM(11)=0.053*D+2.090*XN+1.045
05500 CL11(1)=28.10*D+0.700*XN+1.0
05510 F=D*XN+0.5-148.
05520 IF(F.LT.0.0)F=0.0
05530 CL11(2)=0.457*D+0.680*XN+1.34*(D-0.5)+329.*F+0.5
05540 CL11(3)=0.307*D+0.660*XN+1.33*(D-0.5)+221.*F+0.5
05550 IF(IC.EB.1)CL11(3)=0.0
05560 IF(IC.NE.1)CL11(2)=0.0
05570 CL11(4)=0.124*D+0.591*XN+1.295*(D-0.5)
05580 CL11(5)=3.160*D+1.654*XN+0.827*XL+0.7
05590 CL11(6)=172.5*D+1.320*XN+0.66
05600 CL11(7)=62.30*D+1.340*XN+0.67
05610 CL11(8)=0.0
05620 CL11(9)=0.0
05630 CL11(10)=92.30*D+1.270*XN+0.635
05640 CL11(11)=27.10*D+1.33*XN+0.665
05650 CL11(12)=0.0
05660 CM(12)=0.0
05670 DO 60 I=1,11
05680 CL11(12)=CL11(12)+CL11(I)
05690 CM(12)=CM(12)+CM(I)
05700 60 CONTINUE
05710 CCX=CL11(12)+CM(12)
05720 CCXT=CCX*NXN*NM0D
05730 SP2=1.6833*XL*XN+D0C+D0C
05740 CCWT=42.*CL*PI+DC*NC/4.
05750 CWP=PKU1T*(1.+1.33/DP1)+PKU2T
05760 CCUP=VAC/(NXN*NXUP)+448.6+0.75+50000.
05770 CCWPT=CCUP*NXUP*NM0D+NXH
05780 WWP=PKU3T+PKU4T
05790 CUWP=VAH/(NXN*NXUP)+448.6+0.75+50000.
05800 CUWPT=CUWP*NXUP*NM0D+NXH
05810 K3=1
05820 30 XX=VA3+PG+448.6/(60.*1000.)/NXN/K3
05830 CFP=(7.64*XX-0.304*XX*XX-4.28)*1000.
05840 CFFT=CFP*NAFP*NM0D+NXH
05850 XX=XX*RRATIO
05860 CRP1=(-.045*XX*XX+3.26*XX+12.76)*1000.
05870 CRP2=(-0.6*XX*XX+13.26*XX-27.3)*1000.
05880 CRP=ANAX1(CRP1,CRP2)
05890 CRPT=CRP*NAFP*NM0D+NXH
05900 Y=PG/(NXH*NAT)
05910 CTURB=(-0.001*Y+Y+0.082*Y-0.129)*1.E6
05920 CTURBT=CTURB*NM0D+NXH*NAT
05930 CGEN=(0.023*PG+0.3)*1.E6
05940 CGENT=CGEN*NM0D
05950 CM00R=1.5E6
05960 CSP=(SP1+SP2)*2.*20.

```

```

05970      CSPT=0.0
05980 40    C=(CBXT+CCXT+CSPT+CCWT+CCUPT+CUUPT+CMOOR+CTURBT+CGENT+
05990 +     CFPT+CRPT)/1.E6
06000      RETURN
06010      END
06020      SUBROUTINE UCALC(UA,A,CP,PMU,TK,RHO,DU,B,DO,FF,G,I,TL,U,
06030 +     *XN,PG,GRS,HUF)
06040      COMMON/ARRR/ARR
06050      COMMON/HTC/FFB,FFC,HUFB,HUFC,HVALLC,HVALLB,HSUB,HSUC
06060 C
06070 C      COMPUTES OVERALL "U" BY NEWTON-RHAPSON ITERATION.
06080      PI=3.1415927
06090      PR=CP*PMU/TK
06100      PR1=(PR**0.33333)*(RHO*DU/PMU)**0.8
06110      C1=4.*G*TL/DU
06120      C2=0.027*TK*PR1*3600.*ARR/DM
06130      X2=(4*G/(PI*DU*DU))**0.8
06140      X1=PI*DU*TL
06150      X3=UA/(X1*X2*C2)
06160      X4=DU*UA/D/X1
06170      X5=UA*FF/X1
06180 C      DISPLAY=C1,C2,X1,X2,X3,X4,X5*
06190 C      DISPLAY C1,C2,X1,X2,X3,X4,X5
06200 C      INITIAL GUESS
06210      XN=4.*G/(PI*DU*DU*.6)
06220 10     CALL NH3HTC(I,TL,XN,D,PG,GRS,HUF,DO,HUF,DHUF)
06230      F1=XN-X3*XN**0.8-X4/HUF-X5
06240      DF1=1-.8*X3/(XN**.2)+X4*DHUF/(HUF*HUF)
06250      XN1=XN-F1/DF1
06260 C      DISPLAY=XN,XN1,F1,DF1,HUF,DHUF*
06270 C      DISPLAY XN,XN1,F1,DF1,HUF,DHUF
06280      IF(ABS((XN-XN1)/XN1).LT.0.001) GO TO 20
06290      XN=XN1
06300      GO TO 10
06310 20    XN=XN1
06320      V=4.*G/(DU*DU*PI*XN)
06330      H=C2*V**0.8
06340      IF(1.EQ.1)HSUC=H
06350      IF(1.EQ.2)HSUB=H
06360      A=X1*XN
06370      U=UA/A
06380 C      DISPLAY=U*,U,*A*,A,*V*,V,*XN*,XN
06390 C      DISPLAY=N*,XN,C1,C2,X1,X2,X3,X4,X5
06400 C      DISPLAY=PG,UA,G,HUF*
06410 C      DISPLAY PG,UA,G,HUF
06420 C      DISPLAY *
06430      IF(U.LT.100.) U=100.
06440      RETURN
06450      END
06460      SUBROUTINE NH3HTC(I,TL,XN,D,PG,GRS,HUF,DO,HUF,DHUF)
06470 C      I=1 IS FOR THE CONDENSER
06480      COMMON/REN/REDB,RETB,REBC,RRATIO
06490      COMMON/TIAL/THICK,THICKB,CUM
06500      COMMON/HTC/FFB,FFC,HUFB,HUFC,HVALLC,HVALLB,HSUB,HSUC
06510      PI=3.14159
06520      IF(1.EQ.1) GO TO 10
06530 C      EVAPORATOR
06540      GO TO 20
06550 C      F1=7200.+6600.*DO-1600*DO*DO
06560 C      F2=0.097-0.233*DO+0.058*DO*DO
06570 C      H=F1*TL**F2
06580 C      RETURN
06590 20     WUF1=WUF+PD*.60
06600 C      INITIAL GUESS
06610      X0=2000.
06620      A=3.17508EB
06630      B=1.44537
06640      C=3.5446282*WUF1/(XN*D)
06650      N=1
06660 100    F5=X0-A*X0**(-B)+C
06670      DF5=1.+A*B*X0**(-B-1)
06680      X1=X0-F5/DF5
06690      IF(ABS((X1-X0)/X1).LT.0.001)GO TO 200
06700      X0=X1
06710      N=N+1
06720      GO TO 100
06730 200    REDB=X1
06740      RETB=A/(X1**B)
06750 C      DISPLAY=NO OF ITERATIONS FOR E HTC**,N
06760 C      DISPLAY=REDB**,REDB,*RETB**,RETB
06770      C1=2.939
06780      C2=0.4151
06790      C3=63.217
06800      C4=1.E6*0.8

```



```

06810 C5=7.04096*0.8
06820 C6=1.8452
06830 F1=((C1*(RETB**C2)-C3)*C4-C5*(REBB**C6))
06840 F2=RETB-REBB
06850 R0=.065/(12.*116.)
06860 H=F1/F2
06870 TH=THICKB/12.
06880 R=TH*D/(CON*(D-TH))
06890 HUALLB=1/R
06900 C H IS FROM A COMPOSITE CORRELATION
06910 C THEREFORE R0 MUST BE TAKEN OUT TO GET HUFB
06920 HUFB=1./((1/H-R0)
06930 HUF=1/(1/HUFB*R)
06940 C HUF IS THE COMPOSITE MTC FOR THIS SYSTEM
06950 DF1=(-C1*C2*C4*RETB**C2+C5*C6*REBB**C6)/XM
06960 DF2=-F2/XM
06970 DH=(F2*DF1-F1*DF2)/(F2+F2)
06980 DHUFB=DH/(1.-R0*H)**2.
06990 DHUF=DHUFB/(HUFB*R+1.)**2.
07000 RETURN
07010 C CONDENSER
07020 10 C1=-3231.62
07030 C2=3.684E8
07040 C3=20129.28
07050 R0=.03125/(12.*116.)
07060 Q=QRS*PG
07070 A=TL*D*PI*XN
07080 DA=A/XN
07090 TH=THICKC/12.
07100 R=TH*D/(CON*(D-TH))
07110 H=C1+C2/(Q/A+C3)
07120 HUFC=1/(1/H-R0)
07130 HUF=1/(1/HUFC*R)
07140 DH=C2*Q/DA/(Q/DA+C3*XN)**2.
07150 DHUFC=DH/(1.-R0*H)**2.
07160 DHUF=DHUFC/(1+R*HUFC)**2.
07170 REBC=3.13606*UUF*PG*60./((XN*D)
07180 HUALLC=1/R
07190 RETURN
07200 END
07210 SUBROUTINE PRINT1
07220 C
07230 C PRINT RESULTS
07240 C
07250 COMMON/REN/REBB,RETB,REBC,RRATIO
07260 COMMON/COST/C,CBXT,CCXT,CCUT,CCUPT,CUWPT,CNOOR,
07270 C CTURBT,CSPT,CFPT,CRPT,CBENT
07280 COMMON/OPTIONS/NMOD,NOP,NXM,NXUP,NAFP,MAPP,NAT
07290 COMMON/POWER/PN,PG,CUP,UUP
07300 COMMON/TEMP/TH,TC,DTH,DTC,T1,T2
07310 COMMON/DIM/H,DC,DH,NH,NC,NTB,NTC,CTL,BTL,
07320 C IRKC,RKH,RKX,RKCX,CL,P1,NCP
07330 COMMON/DIA/DUB,DUC,DB,DDC,DOB,DOC
07340 COMMON/PAR/PKU1,PKU2,PKU3,PKU4,DP1,DP2,DP3,DP4
07350 C ,PKU2T,PKU4T,PKU1T,PKU3T
07360 COMMON/EVAL/PAR(6),DPAR(6),NMAX,NPG
07370 COMMON/PRM/A(210),IUF
07380 COMMON/EFF/ETAP,ETAT,ETAG,XU
07390 COMMON/HXI/QAS,QRS,IR,UC,DT1,DT2
07400 COMMON/RAN/P1,P2,PA,EPSR,PUF,UUF,VA1,
07410 C VA2,VA3,DHI,DHA,PUFT
07420 COMMON/HXD/VAN,VAC,AB,AC,NTUB,NTUC,EPSB,EPS
07430 C ,UAB,UAC
07440 COMMON/TURB/K3,V3
07450 COMMON/MTC/FFB,FFC,HUFB,HUFC,HUALLC,HUALLB,HSUB,HSUC
07460 COMMON/CHDH/RHOC,RHOB,PHUC,PHUB,CPB,
07470 C CPC,TKB,TKC
07480 COMMON /VEL/ VELCP,VELC,VELMP,VELD
07490 COMMON/AA/A11(14)
07500 COMMON/HAT/EM(12),CH(12)
07510 COMMON/LAB/EL(12),CL11(12)
07520 COMMON/ARRR/ARR
07530 COMMON/FAB/C11,C22,B11,B22
07540 REAL NTUB,NTUC
07550 DISPLAY* =
07560 PRINT 133,A11(14)
07570 133 FORMAT(25X,A10)
07580 XNTB=NTB
07590 XNTC=NTC
07600 DSC=0.122*DOC*12.*SQRT(XNTC)
07610 DOCC=DOC*12.
07620 U2=VA2*PG/60./NXM
07630 U3=VA3*PG/60./NXM
07640 QC=QRS*PG

```

```

07660      QB=QAS*PG
07670      U1=VA1*PG/60./NXH
07680      BDB=DDB*12.
07690      DDB=0.122*DDB*12.*SQRT(XNTB)
07700      BTL=BTL+3.5
07710      CTL=CTL+1.
07720      VAH1=VAH*3600.*RHOD
07730      VAC1=VAC*3600.*RHOC
07740      DP11=DP1+1.33
07745      T22=T2-DT2
07750      PRINT 9
07760      PRINT 11,CL
07770      PRINT 12,DH,BC
07780      PRINT 13,NH,MC
07790      PRINT 14,VELHP,VELCP
07800      PRINT 38,VAH1,VAC1
07810      PRINT 16,DP3,DP11
07820      PRINT 15
07830      PRINT 17,REDB,REDC
07840      PRINT 18,RETB
07850      PRINT 19,BTL,CTL
07860      PRINT 20,BTL,CTLY
07870      PRINT 21,DGB,DGC
07880      PRINT 22,DGB,DGC
07890      PRINT 23,NTB,HTC
07900      PRINT 41,B11,C11
07910      PRINT 24,VELB,VELC
07920      PRINT 25,U2
07930      PRINT 26,U1,U3
07940      PRINT 27,AB,AC
07950      PRINT 28,OB,OC
07960      PRINT 29,UB,UC
07970      PRINT 30,HUFB,HUFC
07980      PRINT 31,HUALLB,HUALLC
07990      PRINT 32,HSUB,HSUC
08000      PRINT 40,ARR,ARR
08010      PRINT 33,FFB,FFC
08020      PRINT 39,TH,TC
08030      PRINT 34,DTH,DTC
08040      PRINT 35,DP4,DP2
08050      PRINT 36,T1,T22
08060      PRINT 37,P1,P2
08070 9:   FORMAT(12BX,12HU WATER PIPE,3X,12MC WATER PIPE)
08080 11   FORMAT(25HLENGTH FEET ,12X,3H300,F15.4)
08090 12   FORMAT(25HDIAMETER FT ,2F15.4)
08100 13   FORMAT(25HNUMBER OF PIPES ,2I15)
08110 14   FORMAT(25HH2O VEL FT/S ,2F15.4)
08120 38   FORMAT(25HWATER FLOW LB/HR ,2E15.4)
08130 14   FORMAT(25HPRESSURE DROP PSI ,2F15.4)
08140 15   FORMAT(28X,10HEVAPORATOR,5X,9NCONDENSER)
08150 17   FORMAT(25HBOTTOM REYNOLDS NUM ,2E15.4)
08160 18   FORMAT(25HTOP REYNOLDS NUM ,E15.4,12X,3H0.0)
08170 19   FORMAT(25HHEAT TRAN LENGTH FT ,2F15.4)
08180 20   FORMAT(25HTOTAL LENGTH FT ,2F15.4)
08190 21   FORMAT(25HSHELL DIAH FT ,2F15.4)
08200 22   FORMAT(25HTUBE DIAMETER IN. ,2F15.4)
08210 23   FORMAT(25HNUMBER TUBES ,2I15)
08220 24   FORMAT(25HWATER TUBE VEL FT/SEC ,2F15.4)
08230 25   FORMAT(25HIN3 ENT FLOW CFS ,15X,E15.4)
08240 26   FORMAT(25HIN3 EXIT FLOW CFS ,2E15.4)
08250 27   FORMAT(25HHEAT TRAN AREA SQ. FT. ,2E15.4)
08260 28   FORMAT(25HHEAT TRANSFERED BTU/HR ,2E15.4)
08270 29   FORMAT(25HOVERALL BTU/HR/F/FT**2 ,2F15.4)
08280 30   FORMAT(25HIN3 HTC BTU/HR/F/FT**2 ,2F15.4)
08290 31   FORMAT(25HUALL HTC BTU/HR/F/FT**2 ,2F15.4)
08300 32   FORMAT(25HWATER HTC BTU/HR/F/FT**2 ,2F15.4)
08310 33   FORMAT(25HFLOULING (FT**2 HR F/BTU) ,2E15.4)
08320 34   FORMAT(25HCHANGE IN WATER TEMP ,2F15.4)
08330 35   FORMAT(25HPRESSURE DROP PSID ,2F15.4)
08340 36   FORMAT(25HIN3 OUTLET TEMP F ,2F15.4)
08350 37   FORMAT(25HIN3 OUTLET PRES PSIA ,2F15.4)
08360      C1=CUP*NMDD/1000.
08370      C2=UUP*NMDD/1000.
08380      PNM=NMDD*PN
08390      PGG=PG*NMDD
08400      C3=PGG*PNM-C1-C2
00410      CHXT=CBXT*CCXT
08420      U4=UUF*PG/60./NXH
08430      U5=PUF*PG
08440      Z1=CPB*RHDB*DTH*VAN*3600.
08450      PEFF=PN*3412*1.E3/Z1
08455      C=C*1.E6
08460      PRINT 42
08470      PRINT 43,PGG,PNM
08480      PRINT 44,C2,C1

```

```

08490 PRINT 45,C3,U4
08495 YAI=1.-YA
08500 PRINT 46,DNA,YAI
08510 PRINT 47,PEFF,ETAT
08520 PRINT 48
08530 PRINT 49,CBXT,CCXT
08540 PRINT 51,CUPT,CCUPT
08550 PRINT 52,CRPT,CFPT
08560 PRINT 53,CBENT,CTURBT
08570 PRINT 54,CCUT,CNOOR
08580 PRINT 55,C,CNXT
08590 39 FORMAT(25HH20 ENTRANCE TEMP F ,2F15.4)
08600 40 FORMAT(25HH20 AREA RATIO ,2F15.4)
08610 41 FORMAT(25HTUBE MAT COST $/FOOT ,2F15.4)
08620 42 FORMAT(20X,10HCYCLE DATA)
08630 43 FORMAT(15HGROSS POWER MW ,E10.4,15X,
08640 + 15HNET POWER MW ,E10.4)
08650 44 FORMAT(15HMU PUMPS MW ,E10.4,15X,
08660 + 15MCU PUMPS MW ,E10.4)
08670 45 FORMAT(15HMH3 PUMPS MW ,E10.4,15X,
08680 + 15HEVAPOR LB/SEC ,E10.4)
08690 46 FORMAT(15HTURBINE BTU/LB ,E10.4,15X,
08700 + 15TUR EX. QUALITY ,E10.4)
08710 47 FORMAT(15HPLANT EFF ,E10.4,15X,
08711 + 15HTURBINE EFF ,E10.4)
08720 48 FORMAT(20X,10HCOST BREAKDOWN (0))
08730 49 FORMAT(15HEVAP HE COST ,E10.4,15X,
08740 + 15HCON HE COST ,E10.4)
08750 51 FORMAT(15HMU PUMP COST ,E10.4,15X,
08760 + 15MCU PUMP COST ,E10.4)
08770 52 FORMAT(15HMH3 R PUMP ,E10.4,15X,
08780 + 15HMH3 F PUMP ,E10.4)
08790 53 FORMAT(15HGEN COST ,E10.4,15X,
08800 + 15HTURBINE COST ,E10.4)
08810 54 FORMAT(15HCMU PIPE ,E10.4,15X,
08820 + 15HMISCEL ,E10.4)
08830 55 FORMAT(15HTOTAL SYSTEM ,E10.4,15X,
08840 + 15HTOTAL BOTH HE ,E10.4)
08850 A11(1)=10HTUBES
08860 A11(2)=10HCLAD
08870 A11(3)=10HUNCLAD
08880 A11(4)=10HPLATES
08890 A11(5)=10HSHELL
08900 A11(6)=10HBOXES
08910 A11(7)=10HNOZZLES
08920 A11(8)=10HDIST
08930 A11(9)=10HBUSTLE
08940 A11(10)=10HINLETS
08950 A11(11)=10HSUPPORT
08960 A11(12)=10HEACH TOTAL
08980 DISPLAY* EVAPORATOR*,
08990 + * CONDENSER*
09000 DISPLAY*PART MATERIAL LABOR*
09010 + * MATERIAL LABOR*
09020 DO 10 I=1,12
09030 PRINT 50,A11(I),EN(I),EL(I),CH(I),CL1(I)
09040 50 FORMAT(A10,4E15.4)
09050 10 CONTINUE
09060 PRINT 1111
09070 1111 FORMAT(////////)
09080 RETURN
09090 END

```

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX A.2
SYSTEM PERFORMANCE MODEL

TABLE OF CONTENTS

1. INTRODUCTION AND OVERVIEW
 2. PROGRAM DESCRIPTION
 - 2.1 Introduction
 - 2.2 The Basic Flow of the Program
 - 2.3 Subroutines and Functions referenced by Main Subroutines Vapor and Liquid
 - 2.3.1 Subroutines and Functions Used in Main Subroutine Vapor
 - 2.3.2 Subroutines and Functions Used in Liquid Side Calculations
 - 2.3.3 Hierarchical Structure of the Program
 - 2.4 Program Flow Charts
 - 2.4.1 Flow Chart of Main Program
 - 2.4.2 Flow Chart of Subroutines Vapor and Liquid
 3. INPUT
 4. OUTPUT
 5. OPERATING PROCEDURES
- ATTACHMENT I: SAMPLE CASE
- A.1 Standard Output
 - A.2 TAPE6 (Debug) Output
- ATTACHMENT II: DESCRIPTION OF FUNCTIONS AND SUBROUTINES
- FIGURES:
- 2.1 Flow Diagram of Configuration 1
 - 2.2 Flow Diagram of Configuration 2a and 2b
 - 3.1 NAMELIST DATA (\$DATAIN) Variables
 - 3.2 NAMELIST DATA (\$GEODATA) Variables
 - 4.1 Standard Output

1.0 Introduction and Overview

The Ocean Thermal Energy Conversion Steady State Simulation (OTECSS) computer program was developed to provide an accurate performance model of TRW's PSDI OTEC design's steady state performance. With this simulation as a tool, the performance (power) and, functional parameters (temperatures, pressures, pump suction heads, flow rates etc.) of the plant may be investigated over a wide range of operation conditions.

The OTECSS program was designed to provide the next level of detail beyond the OTEC-II Computer Program in the analysis of OTEC performance. The OTEC-II Program is a design optimization program designed to optimize OTEC cost performance using somewhat simplified models of plant performance consistent with the optimization process. The OTECSS program provides a detailed model of an OTEC design as developed from OTEC-II and other analyses. The OTECSS contains detailed models of the various elements of the OTEC power cycle: Evaporator, condenser, turbine, bypass, pumps, pipes, valves, and bends. The program was developed by TRW and Carnegie Mellon University Consultants. The program is modular in construction and has all important plant parameters as input variables so that present and future designs can be easily studied.

The heat exchangers modeled are of the fluted tube falling film design. The program segments the tubes into a number (nominally 10) of elements and determines the heat transfer for each of the elements. The sum of the evaporation/condensation flow for each element is the total for a single tube. This multiplied by the number of tubes to get the total evaporation or condensation rate. The model assumes that there is no pressure drop in the heat exchanger caused by vapor flow. The ammonia entering the evaporator is assumed to be raised to saturation temperature in the header and the water temperature is adjusted for this. Super heat of the liquid in the evaporator header and super cooling in the condenser well is not modeled but should be negligible. Likewise heat transfer through the heat exchanger shells and the various pipes in the system is also not modeled. The water flow through the heat exchangers is constant for this steady state model.

The model for the turbine was developed by Professor Larry Amb's of the University of Massachusetts based on their ammonia turbine simulation programs. An optimized single stage turbine was defined for the baseline OTEC conditions using their turbine optimization program. The off design performance was then investigated and the results were curve fit to provide power, outlet pressure, and outlet enthalpy as a function of inlet flow and temperature. Generator efficiency is assumed to be 98% and a 1% turbine bearing loss is allowed for in the program. While the turbine model is felt to be accurate over a wide range, output at less than half or more than 50% greater than nominal may be in error. Variable turbine nozzles are not modeled.

The ammonia reflux and condensate pumps are modeled with curve fits to the pump curves shown in Figures 1-1 and 1-2. The curves are valid at the indicated RPM. The head and flow as a function of RPM was developed using the relationship:

$$\frac{n}{n_0} = \frac{Q}{Q_0} = \sqrt{\frac{H}{H_0}}$$

where n_0 , Q_0 , and H_0 are the RPM, flow, and head at the design RPM.

The various control valves are modeled simply with a k factor with which the pressure drop across them is determined. The capability exists to model the k vs angle relationship but this is not used at this time.

The parasitic power required to provide the nominal water flow rates (as input) is an input variable. If different rates are input a new parasitic pumping power is computed as:

$$\text{Power} = \text{Nominal Power} \left(\frac{\text{Flow}}{\text{Flow Nominal}} \right)^{2.8}$$

The OTECSS program selects the proper valve or motor RPM settings on the condensate and reflux (recirculation) lines to achieve equilibrium. Thus, it is not possible to select these valve or RPM settings to observe what will happen to plant performance; they are the dependent variables. Feed rate to the evaporator is an independent variable and the valve or pump setting necessary to achieve a specified flow can be determined.

Program flow in the OTECSS is fairly straightforward. The vapor and liquid portions of the simulation are performed in sequence. First the vapor calculation is performed using the input values of ammonia flow, and warm cold water flow. An iterative solution is used in which the evaporation rate and pressure, turbine pressure, enthalpy and quality drops, and condensation rate and pressure are adjusted to reach equilibrium. This is accomplished by adjusting the evaporator pressure until the evaporation rate and the condensation rate (adjusted for turbine outlet quality) are equal to within 1 lb/sec ($\approx .1\%$). The condenser flow and evaporator reflux along with the respective pressures are then input to the liquid side. Pump speeds or valve settings are iteratively adjusted, taking into account the pressure drops associated with the fluid flows, to achieve pressure equilibrium.

The following sections of this report describe the program in greater detail, define the input, outputs, and operating procedures and provide a sample case.

Fig. 1-1 EVAPORATOR PUMP & SYSTEM HEAD VS. FLOW





Fig. 1-2 CONDENSATE PUMP & SYSTEM HEAD VS FLOW



2. PROGRAM DESCRIPTION

2.1 INTRODUCTION

The OTEC Steady State Simulation program is coded in FORTRAN IV, and compiled on the CDC 6600. The program is organized modularly into main subroutines VAPOR and LIQUID, and into two output subroutines BUDGET and MATRIX. Subroutine VAPOR includes all the vapor side calculations of the program and subroutine LIQUID includes all liquid side calculations of the program. Section 2.2 describes the basic flow of the program from the top level flow view. Section 2.3 displays the hierarchical structure of the program and describes the functions and subroutines involved. Section 2.4 contains a detailed functional flow chart of the main program and the subroutines VAPOR and LIQUID.

Input data are supplied through two Namelists, \$DATAIN and \$GEODATA. Default values of all input data are provided in the BLOCKDATA subprogram. The program is designed to run nominally in a perturbation mode allowing the user to specify just the input quantity to be perturbed. A maximum of nine perturbations is allowed. In addition, the program permits the stacking of input data for multiple cases.

2.2 THE BASIC FLOW OF THE PROGRAM

1. Reads in NAMELIST data \$DATAIN for input of frequently changed variables and next reads NAMELIST data \$GEODATA for the optional input of other less frequently changed variables.
2. Initiates major DO loop that includes main subroutines VAPOR and LIQUID, and subroutine BUDGET. The loop runs from one to the number of cases (NCASE), perturbing one of seven acceptable input variables repeatedly by a user specified increment.
 - a. Subroutine VAPOR
 - 1) Estimates the ammonia saturation pressures in the evaporator and condenser.
 - 2) Adjusts the saturation pressure until the ammonia saturation pressure in the condenser equals to the turbine output pressure and the condensation rate in the condenser equals to the turbine output flow plus the bypass flow rate (if not closed).
 - 3) Prints out saturated pressures, temperatures, the reflux and condensate flow rates, and the turbine power output on TAPE6.
 - b. Subroutine LIQUID
 - 1) Couples the VAPOR results to the subroutine LIQUID, primarily through COMMON/SEAWTR/(liquid flow rates of feed, reflux, and condensate line).

- 2) Calculates the pump speeds/control valve settings to produce a pressure balance among points P8, P12, and P18 (see Figure 1.1).
- 3) Calculates the remaining pressures at LIQUID side points.
- 4) Prints out the pressure profile around the system, the values of the control parameters, the pump powers and NPSH values on TAPE6.

c. Subroutine BUDGET

- 1) Transmits some of the subroutine LIQUID results to the BUDGET routine through COMMON/PARA/.
 - 2) Prints out the final gross and net power budget on TAPE6.
3. After completion of the DO loop statement, subroutine MATRIX is called in the main program. It displays the output variables of interest:
4. The calculational flow then returns to the start and looks for the next stacked case, or terminates if so instructed.





Figure 2.1 Flow Diagram of Configuration 1

configuration 2a



Configuration 2b




Figure 2.2 Flow Diagram of Configuration 2a and 2b

2.3. SUBROUTINES AND FUNCTIONS REFERENCED BY MAIN SUBROUTINES VAPOR AND LIQUID

2.3.1. Subroutines and Functions Used in Main Subroutine VAPOR

<u>FUNCTIONS</u>	<u>DESCRIPTION</u>
TSAT (P_{sat})	Calculates saturation temperature ($^{\circ}F$).
PSAT (T_{sat})	Calculates saturation pressure (PSIA).
VOLUME (P_{sat})	Calculates specific volume of saturated vapor (cu.ft/lb).
HEVAP ($M_{WW}, M_{NH3}, T_{WW}, T_{NH3}$)	Calculates overall local heat transfer coefficient for a segment of an evaporator tube (Btu/ $^{\circ}F$.sec).
HCOND ($M_{CW}, M_{NH3}, T_{CW}, T_{NH3}$)	Calculates overall local heat transfer coefficient for a segment of a condensate tube (Btu/ $^{\circ}F$.sec).
<u>SUBROUTINE</u>	<u>DESCRIPTION</u>
EVAP	Calculates the evaporation rate and $\partial ER / \partial P_{sat}$ in the evaporator for specified warm sea water conditions and a specified ammonia feed rate and saturation temperature.
COND	Calculates the condensation rate and $\partial CR / \partial p_{sat}$ in the condenser for specified cold sea water conditions and a specified saturation temperature.
TURBINN	Calculates the output conditions for the turbine and the work done in the turbine for specified inlet conditions and inlet flow rate.


2.3.2 Subroutines and Functions Used in Liquid Side Calculations


FUNCTIONS

<u>FUNCTIONS</u>		<u>DESCRIPTION</u>
PSAT (T_{sat})	} Ammonia Table	Calculates saturation pressure (PSIA).
GAMMA (T_{sat})		Calculates density of saturated liquid (lbs/ft ³).
P18C1	} Calculates pressure drop at control valve V_{7a}	These functions calculate the pressure at points 18, 12, and 8 for the three configurations (see Figure 1.1).
P18C2A		
P18C2B		
P12C1	} Calculates pressure drop at control valve V_{6a}	
P12C2A		
P12C2B		
P8C1	} Calculates pressure drop at control valve V_{6a}	
P8C2A		
P8C2B		


SUBROUTINES

<u>SUBROUTINES</u>	<u>DESCRIPTION</u>
VALV7A	Calculates K factor of feed flow control valve.
PUMPRF	Calculates head of reflux pump (ft) and power (KW).
VALV6A	Calculates K factor of condensate flow control valve .
PUMPC	Calculates head of condensate pump (ft) and power (KW).
HEADER	Calculates ΔP in ammonia feed header (ft ³ /sec).
SEARCH	Search subroutine to determine the required valve K factors or pump speeds to secure pressure balances in the several legs of the liquid ammonia system.







A-50




A-51







A-53



A-54

2.4 PROGRAM FLOW CHARTS

2.4.1 Flow Chart of Main Program



15

Sub. VAPOR
Includes all VAPOR
side calculation.
Detail Flowchart is
described at 2.4.2

Sub. LIQUID
Includes all LIQUID
side calculation.
Detail Flow Chart is
described at 2.4.2

Sub. BUDGET
Calculates and Prints all
POWER information on TAPES
(Gross, net, turbine, pumps,
miscellaneous, and parasitic)

MAT(Z,NC)
=SEA(IC)


SEA(IC) =
SEA(IC) + DELT



Sub. MATRIX
Prints the output
variables of interest.

SEA(IC)
= SAVE

90

2.4.2 Flow Chart of Subroutines VAPOR and LIQUID





Sub.
LIQUID

$$ORFSC = \sqrt{C_d A^2}$$

$$C_1 = 1/18/\pi^2/32.16$$

$$C_2 = 1/288/32.16$$

ICONF

CONFIGURATION 1

100

$$FEDDSC = (f \frac{L}{D} + K_{bends} + K_{filter}) \text{ feed line}$$

$$RFLSCN = (f \frac{L}{D} + K_{bends} + K_{V2a}) \text{ reflux suction line}$$

$$RFLDSC = (f \frac{L}{D} + K_{bends} + K_{V2b} + K_{V3a}) \text{ reflux discharge line}$$

$$CONSCN = (f \frac{L}{D} + K_{bends} + K_{V4a}) \text{ condensate suction line}$$

$$CONDSC = (f \frac{L}{D} + K_{bends} + K_{V4b} + K_{V5a}) \text{ condensate discharge line}$$

CONFIGURATION 2a

200

$$FEDSCN = (f \frac{L}{D} + K_{bends} + K_{V2a}) \text{ feed suction line}$$

$$FEDDSC = (f \frac{L}{D} + K_{bends} + K_{filter} + K_{V3a} + K_{V2b}) \text{ feed discharge line}$$

$$CONSCN = (f \frac{L}{D} + K_{bends} + K_{V4a}) \text{ condensate suction line}$$

$$CONDSC = (f \frac{L}{D} + K_{bends} + K_{V4b} + K_{V5a}) \text{ condensate discharge line}$$

CONFIGURATION 2b

300

$$FEDSCN = (f \frac{L}{D} + K_{bends} + K_{V2a}) \text{ feed suction line}$$

$$FEDDSC = (f \frac{L}{D} + K_{bends} + K_{filter} + K_{V3a} + K_{V2a}) \text{ feed discharge line}$$

$$RFLSCN = (f \frac{L}{D} + K_{bends}) \text{ reflux suction line}$$

$$CONSCN = (f \frac{L}{D} + K_{bends} + K_{V4a}) \text{ condensate suction line}$$



$$CONDSC = (f \frac{L}{D} + K_{bends} + K_{V4b} + K_{V5a}) \text{ condensate discharge line}$$



400


Func. PSAT
Calculate saturated
evaporator pressure.
INPUT: T_{sat}^e



Func. PSAT
Calculate saturated
condenser pressure.
INPUT: T_{sat}^c

(P5)









3. INPUT

Input data are supplied through two NAMELISTS labeled \$DATAIN and \$GEODATA. \$DATAIN comprises twenty input variables which it is anticipated will be altered for various test runs: e.g., seawater temperatures, fouling factors, mass flow rates, and so on. \$GEODATA comprises forty-eight parameters which it is anticipated will be altered only infrequently between runs; e.g., tube dimensions, pipe elevations, valve K-factors, and so on.

Default values of all input data are provided in the BLOCKDATA sub-program. These values specify the 10 MW "baseline case" for power module steady-state operation. To run the baseline case, input:

```
P$DATAIN
$END
```

\$GEODATA need not be specified. The simulation program permits the stacking of namelist data sets for multiple cases. See variable IEND below.

The program has been designed to run nominally in a parameter perturbation mode. The user specifies only one of 7 acceptable input variables to be perturbed (see M PARA below), the amount of the perturbation (see DELT below) and the number of cases to be run (see NCASE below). The program then executes a nominal case followed by NCASE-1 successive perturbation cases and formats the results of all cases in an easy to read columnar format. Note that in this mode namelist \$DATAIN is input once only.

Figures 3.1 and 3.2 following define all input variables.

FORTRAN SYMBOL	ENGINEERING SYMBOL	DEFAULT VALUE	DEFINITION
TWARM	T_{warm}	80.	Temperature of warm sea water (°F).
MWARM	\dot{M}_{warm}	75967.	Warm sea water flow rate to evaporator (lbs/sec)
FFWARM	ff_{warm}	.0001	Fouling factor on input diameter of evaporator tubes (ft ² hr °F/Btu).
TCOLD	T_{cold}	40.	Temperature of cold sea water (°F).
MCOLD	\dot{M}_{cold}	70172.2	Cold sea water flow rate to condenser (lbs/sec).
FFCOLD	ff_{cold}	.0001	Fouling factor on input diameter of condenser tubes (ft ² hr °F/Btu).
ICONF		2	Liquid side configuration selector. 1 = configuration 1 2 = configuration 2a 3 = configuration 2b
MFEED	\dot{M}_{feed}	1324.4	Ammonia feed rate to the evaporator header (lbs/sec).
KV1B	K_{v1b}	2000.	Bypass valve K factor. If KV1B > 1999. or < .05 the valve is closed.
REFRFL	rpm/r_{fl}	585.	Specified/initial estimate of reflux/feed pump rotational speed (rpm).
REFCON	$rpm/cond$	880.	Specified/initial estimate of condensate pump rotational speed (rpm).
REFV7A	V_{7a}	.2	Specified/initial estimate of ammonia feed flow control valve (V_{7a}).
REFV6A	V_{6a}	.2	Specified/initial estimate of ammonia condensate flow control valve (V_{6a}).
JMPRF		0	Feed flow control selector. (0 = V_{7a} control valve) (1 = reflux/feed pump)

Figure 3.1 NAMELIST DATAIN (\$DATAIN) Variables

FORTRAN SYMBOL	ENGINEERING SYMBOL	DEFAULT VALUE	DEFINITION
JPMPC		1	Condensate flow control selector. (0 = V _{6a} control valve) (1 = condensate pump)
IEND		-2 (on the first case)	Run termination and namelist control flag.
		-1 (subsequent case)	1 Terminates run 0 Requests namelist GEODATA be read and written -1 Suppresses reading and writing of GEODATA -2 Requests GEODATA be written only
MPARA		'MCOLD'	Hollerith name of input variable to be perturbed. Acceptable names are 'TWARM', 'MWARM', 'FWARM', 'TCOLD', 'MCOLD', 'FFCOLD', 'MFEED'.
DELT		100.	Amount by which MPARA variable is perturbed.
NCASE		1	Number of cases to be run by perturbing variable defined by MPARA: (10 ≤ offline) (5 ≤ terminal)

FORTRAN SYMBOL	ENGINEERING SYMBOL	DEFAULT VALUE	DEFINITION
DIAI	D_{inlet}	5.9	Inside diameter of vapor duct from evaporator to turbine (ft).
FLDI	$f \frac{L}{D}$.1	The product of the friction factor by the length over diameter ratio of vapor duct from evaporator to turbine.
BENDSI	$K_{bend, etc.}$.9	K factor of vapor duct from evaporator to turbine (includes exit orifice losses in evaporator).
DIAO	D_{outlet}	8.0	Inside diameter of vapor duct from turbine to condenser (average value) (ft).
FLDØ	$f \frac{L}{D}$.1	The product of the friction factor by the length over diameter ratio of vapor duct from turbine to condenser.
BENDSØ	$K_{bend, etc.}$.3	K factor of vapor duct from turbine to condenser.
DIAB	D_{bypass}	5.5	Inside diameter of vapor bypass duct around turbine (ft).
FLDB	$f \frac{L}{D}$.45	The product of the friction factor by the length over diameter ratio of vapor bypass duct.
BENDSB	$K_{bend, etc.}$.45	K factor of vapor bypass duct.
DIAFED	D_{feed}	3.0	Inside diameter of liquid ammonia feed line (ft.)
FLDFS	$f \frac{L}{D}$.1	The product of the friction factor by the length over diameter ratio of feed suction line.
BENDFS	K_{bends}	.45	K factor of feed suction line.
FLDFD	$f \frac{L}{D}$.3	The product of the friction factor by the length over diameter ratio of feed discharge line.
BENDFD	K_{bends}	1.35	K factor of feed discharge line.
HFEED	h_{feed}	54.	Elevation of evaporator orifice plate above pump centerline (ft).
DIARFL	D_{reflux}	3.0	Diameter of liquid ammonia reflux line (ft).
FLDRS	$f \frac{L}{D}$	0.	The product of the friction factor by the length over diameter ratio of reflux suction line.

Figure 3.2 NAMELIST GEODATA (\$GEØDATA) Variables

FORTTRAN SYMBOL	ENGINEERING SYMBOL	DEFAULT VALUE	DEFINITION
BENDRS	K_{bends}	0.	K factor of reflux suction line.
FLDRD	$f \frac{L}{D}$	0.	The product of the friction factor by the length over diameter of ratio of reflux discharge line.
BENDRD	K_{bends}	0.	K factor of reflux discharge line.
HSUMP	h_{sump}	21.	Elevation of liquid surface in evaporator sump above pump center line (ft).
DIACØN	D_{cond}	2.0	Diameter of liquid ammonia condensate line (ft).
FLDCS	$f \frac{L}{D}$.3	The product of the friction factor by the length over diameter ratio of condensate suction line.
BENDCS	K_{bends}	.45	K factor of condensate suction line.
FLDCD	$f \frac{L}{D}$.3	The product of the friction factor by the length over diameter ratio of condensate discharge line.
BENDCD	K_{bends}	1.35	K factor of condensate discharge line.
HWELL	h_{well}	21.	Elevation of liquid surface in condenser hot well above pump centerline (ft).
FILTER	K_{filter}	6.4	K factor of the liquid ammonia feed filter.
CDA	$C_d A$	1.16	The product of the discharge coefficient and the area of the composite of all of the film forming orifices in the evaporator (ft ²).
KV1A	K_{V1a}	.2	K factor of the valve which is between the outlet of evaporator and inlet of turbine.
KV2A	K_{V2a}	.2	K factor of the valve which is between the sump and reflux/feed pump.
KV2B	K_{V2b}	.2	K factor of the valve which is between the reflux/feed pump and the valve V_{3a} .
KV3A	K_{V3a}	0.	K factor of the valve which is between the valve V_{2b} and screen filter.
KV4A	K_{V4a}	.2	K factor of the valve which is between the hot well and the condensate pump.
KV4B	K_{V4b}	.2	K factor of the valve which is between the condensate pump and control valve V_{6a} .

FORTTRAN SYMBOL	ENGINEERING SYMBOL	DEFAULT VALUE	DEFINITION
KV5A	k_{v5a}	0.	K factor of the valve which is between the control valve V_{6a} and sump.
ETUBID	D_{ID}^e	.0733	Evaporator tube effective inside diameter (ft).
ETUBØD	D_{OD}^e	.07583	Evaporator tube effective outside diameter (ft).
ELNGTH	l^e	26.5	Evaporator tube active length (ft).
ENMBR	n^e	42667	Total number of evaporator tubes.
ENSEG	$NSEG^e$	10	Number of length segments into which the evaporator tubes are divided for computational purposes (≤ 20).
CTUBID	D_{ID}^c	.07408	Condenser tube effective inside diameter (ft).
CTUBØD	D_{OD}^c	.07583	Condenser tube effective outside diameter (ft).
CLNGTH	l^c	29.	Condenser tube active length (ft).
CNMBR	n^c	43678	Total number of condenser tubes.
CNSEG	$NSEG^c$	10	Number of segments of length into which the condenser tubes are to be divided for computational purposes (≤ 20).
ARE	AR^e	1.46	Area ratio of evaporator.
ARC	AR^c	1.46	Area ratio of condenser.
THET	t^e	.00469	Thermal thickness of evaporator tube (ft).
THCT	t^c	.00393	Thermal thickness of condenser tube (ft).
CONCT	k^c	11.5	Thermal conductivity of condenser tube (Btu/hr/ft/°F).
CONET	k^e	11.5	Thermal conductivity of evaporator tube (Btu/hr/ft/°F).

4. OUTPUT

The output consists of a printout of the input data sets \$DATA and optionally \$GEODATA, and a display of the simulation results. The printing of the \$GEODATA set is controlled by input IEND in the \$DATAIN set. If the name of the variable to be perturbed is input to MPAPA, it is displayed in hollerith representation. If not input, its default value 'MCOLD' is displayed in integer format.

The output is formatted and printed in subroutine MATRIX. The output format has been designed to display 33 variables for up to ten cases for offline print and for up to five cases for remote terminal display. One example of this format appears in Figure 4.1. For debug purposes, Dr. Impink's output is displayed on TAPE6. The variables are self-identified by text. The procedure for obtaining this output is given in Section 5.

The following is a list, with definitions, of the standard output variables displayed in the order of appearance so shown in Figure 4.1.

<u>FORTRAN SYMBOL</u>	<u>ENGINEERING SYMBOL</u>	<u>DEFINITION</u>
POWER AND EFFICIENCY		
QNET	P_{net}	Net power of the system (MegaWatts).
POWER	$P_{turbine}$	Turbine power (MegaWatts).
QCOLD	$P_{cold\ water}$	Cold sea water pumping power (MegaWatts).
QWARM	$P_{warm\ water}$	Warm sea water pumping power (MegaWatts).
QCOND	P_{pump}^c	Ammonia condensate pumping power (MegaWatts).
QRFLX	P_{pump}^e	Ammonia feed pumping power (MegaWatts).
QMISC	P_{mis}	Miscellaneous power requirements (MegaWatts).
FFFIC	η	Turbine efficiency (%).
QUAL	X	Ammonia turbine exit quality.

FORTTRAN
SYMBOL

ENGINEERING
SYMBOL

DEFINITION

FLOW RATES

M_{feed}

M_{feed}

Ammonia feed rate to the evaporator header (lbs/sec).

ER

Evaporation rate (lbs/sec).

CR

Condensate rate (lbs/sec).

MRFL

M_{reflux}

The evaporator reflux flow rate (lbs/sec).

FLOWIN

TF

Turbine inlet flow rate (lbs/sec).

BYPASS

BP

The resulting bypass flow rate (lbs/sec).

TEMPERATURES

TOUTW

$T_{\text{warm water}}$

The warm water discharge temperature ($^{\circ}\text{F}$).

TOUTC

$T_{\text{cold water}}$

The cold water discharge temperature ($^{\circ}\text{F}$).

TSATE

T_{evap}

Temperature of evaporator ($^{\circ}\text{F}$).

TSATC

T_{cold}

Temperature of condensor ($^{\circ}\text{F}$).

PRESSURES

PSATE

P_{evap}

Pressure of evaporator (PSIA).

PSATC

P_{cond}

Pressure of condensor (PSIA).

PTHRTL

$P_{\text{turb throttle}}$

Turbine throttle pressure (PSIA).

RPMRFL

$\text{rpm}_{\text{reflux pump}}$

Reflux feed pump speed (RPM).

ANGV7A

$\angle V_{7A}$

Feed flow valve angles ($^{\circ}$).

NPSHRF

$\text{NPSH}_{\text{reflux}}$

Reflux feed pump NPSH (feet).

DPV7A

ΔP_{V7A}

The pressure drop across the feed control valve (PSI).

RPMCON

$\text{rpm}_{\text{cond pump}}$

Condensate pump speed (RPM).

ANGV6A

$\angle V_{6A}$

Condensate flow valve angle ($^{\circ}$).

NPSHC

$\text{NPSH}_{\text{cond}}$

Condensate pump NPSH (feet).

DPV6A

ΔP_{V6A}

The pressure drop across (feet) the the condensate flow control valve (PSI).

FORTTRAN
SYMBOL

ENGINEERING
SYMBOL

DEFINITION

PRESSURES (continued)

HEU

Heat transfer coefficient of
evaporator (Btu/ F/ft²/sec).

HCU

Heat transfer coefficient of
condenser
(Btu/ F/ft²/sec).

CASE	1	2
VARIABLE MFEED	1324.40	1224.40
POWER & EFFICIENCY (MEGAWATTS)		
NET POWER	10.33	10.34
TURBINE POWER	14.73	14.73
COLD WATER PUMP	1.77	1.77
WARM WATER PUMP	1.35	1.35
CONDENSATE PUMP	.32	.32
FEED PUMP	.16	.15
MISCELLANEOUS	.50	.50
TURBINE EFFICIENCY%	87.67	87.67
AMMONIA QUALITY %	97.44	97.44
FLOW RATES (LBS/SEC)		
FEED TO EVAPORATOR	1324.40	1224.40
EVAPORATION FLOW	808.43	808.28
CONDENSATION FLOW	787.47	787.26
REFLUX FLOW	515.97	416.12
TURB INLET FLOW	808.43	808.28
BYPASS FLOW	0.00	0.00
TEMPERATURES (DEG F)		
WARM WATER DISCHG	74.02	74.05
COLD WATER DISCHG	46.21	46.21
EVAPORATOR	70.20	70.19
CONDENSER	50.31	50.31
PRESSURES (PSIA)		
EVAPORATOR	129.25	129.23
CONDENSER	89.19	89.19
TURB THROTTLE	129.04	129.02
PUMPS AND VALVES		
FEED PUMP SPEED, RPM	596.56	576.99
FEED ANGLE, DEGREE	.20	.20
FEED NPSH, FEET	123.52	130.44
DF PR FEED VALV, PSI	.02	.02
COND PUMP SPEED, RPM	779.60	779.65
COND ANGLE, DEGREE	.20	.20
COND NPSH, FEET	26.36	26.36
DF PR COND VALV, PSI	0.00	0.00
HEAT TRS COEFF EVAP	905.04	887.93
HEAT TRS COEFF COND	726.81	726.82

A-73

Figure 4.1 Standard Output

5. OPERATING PROCEDURES

Approximately 34200 (octal) words of core are needed for loading, and 24400 (octal) words of core are needed for execution on the CDC 6600 at TRW. To run the default case with no variable perturbations takes about one second of central processor time. A typical control file for timeshare execution is:

```
GET,OTEB5,Input file
OTEB5,INPUT=Input file,OUTPUT=PR1
PRINTF,PR1,bldg,room (or courier)
(PPRINTF,TAPE6) if debug output is desired
```

A control file for remote batch execution is:

```
ACCOUNT,username,password
NAME,CCCOO,badge,last name,first initial
PROBLEM,job number
FLENGTH,34200
PRIORITY,E
BANNER,OUTPUT,bldg.room (or courier)
GET,OTEB5,input file
OTEB5,INPUT=input file
(PPRINTF,TAPE6) if debug output is desired
```

ATTACHMENT I

SAMPLE CASE

A.1 STANDARD OUTPUT

DTEC STATIC SIMULATION MODEL

DATAIN
END

A 77

SDATA IN

TWARM = 8.0E+01,
MWARM = 7.59667E+04,
FFWARM = 1.0E-04,
TCOLD = 4.0E+01,
HCOLD = 7.01722E+04,
FCOLD = 1.0E-04,
MFEE0 = 1.3244E+03,
CONF = 2,
AREA = 2.36,
KV18 = 2.0E+03,
REFRFL = 5.85E+02,
REFCON = 8.8E+02,
REFV7A = 2.0E-01,
REFV6A = 2.0E-01,
JPMPRF = 0,
JPMPC = 1,
IGND = -2,
SPARA = 235098405946710893,
DELT = 1.0E+02,
BASE = 1,
END

A-78

SGEODATA

DIAI = 5.5,
 FLDI = 3.0E-01,
 BENDSI = 4.5E-01,
 DIAO = 7.0,
 FLDO = 3.0E-01,
 BENDSO = 4.5E-01,
 DIAB = 5.5,
 FLOB = 4.5E-01,
 BENDSB = 4.5E-01,
 DIAFEO = 3.0,
 FLOFS = 3.0E-01,
 BENDFS = 4.5E-01,
 FLDFO = 3.0E-01,
 BENDFO = 9.0E-01,
 HFEEED = 7.0E+01,
 DIARFL = 2.5,
 FLDRS = 0.,
 BENDRS = 0.,
 FLDRD = 0.,
 BENDRD = 0.,
 HSUMP = 2.9E+01,
 DIACON = 2.0,
 FLOCS = 3.0E-01,
 BENDCS = 4.5E-01,
 FLDCD = 3.0E-01,
 BENDCD = 9.0E-01,
 HWELL = 2.7E+01,
 FILTER = 4.0E-01,
 CDA = 1.16,
 KV1A = 2.0E-01,
 KV2A = 2.0E-01,
 KV2B = 2.0E-01,
 KV3A = 0.,
 KV4A = 2.0E-01,
 KV4B = 2.0E-01,
 KV5A = 0.,
 ETUBID = 7.33E-02,
 ETUBOD = 8.25E-02,
 ELNGTH = 2.65E+01,
 ENMBR = 42667,
 ENSEG = 10,

A-79

CTUBID = 7.408E-07,
CTUBOD = 8.25E-02,
CLNGTH = 2.9E+01,
CNMBR = 43678,
CNSEG = 10,
ARE = 1.46,
ARC = 1.46,
THET = 4.60E-03,
THCT = 3.93E-03,
CONET = 1.15E+01,
CONCT = 1.15E+01,
SEND

CASE	1
VARIABLE MCOLD	70172.20
POWER & EFFICIENCY	(MEGAWATTS)
NET POWER	10.33
TURBINE POWER	14.73
COLD WATER PUMP	1.77
WARM WATER PUMP	1.35
CONDENSATE PUMP	.32
FEED PUMP	.16
MISCELLANEOUS	.50
TURBINE EFFICIENCY%	87.67
AMMONIA QUALITY %	97.44
FLOW RATES	(LBS/SEC)
FEED TO EVAPORATOR	1324.40
EVAPORATION FLOW	808.43
CONDENSATION FLOW	787.47
REFLUX FLOW	515.97
TURB INLET FLOW	808.43
BYPASS FLOW	0.00
TEMPERATURES	(DEG F)
WARM WATER DISCHG	74.02
COLD WATER DISCHG	46.21
EVAPORATOR	70.20
CONDENSER	50.31
PRESSURES	(PSIA)
EVAPORATOR	129.25
CONDENSER	89.19
TURB THROTTLE	129.04
PUMPS AND VALVES	
FEED PUMP SPEED, RPM	596.58
FEED ANGLE, DEGREE	.20
FEED NPSH, FEET	123.52
DF PR FEED VALV, PSI	.02
COND PUMP SPEED, RPM	779.80
COND ANGLE, DEGREE	.20
COND NPSH, FEET	26.36
DF PR COND VALV, PSI	0.00
HEAT TRS COEFF EVAP	905.04
HEAT TRS COEFF COND	726.81

A-81

A.2 TAPE6 DEBUG OUTPUT

THE BYPASS VALVE IS CLOSED

A-83

LIQUID SIDE CHARACTERISTICS

CONFIGURATION 2A

	REFLUX/FEED PUMP SPEED	CONDENSATE PUMP SPEED	FEED FLOW VALVE ANGLE	COND.FLOW VALVE ANGLE
INPUT	585.00	880.00	.20	.20
ACTUAL	596.58	779.80	.20	.20

	PUMP PARAMETERS	
	POWER	NPSH
REFLUX/FEED	.16	123.52
CONDENSATE	.32	26.36

PRESSURES	
A-84	P 7 = 89.73
	P 8 = 129.24
	P 9 = 96.86
	P10 = 137.35
	P11 = 129.24
	P12 = 129.24
	P13 = 136.02
	P14 = 153.85
	P15 = 134.89
	P16 = 129.24
	P17 = 89.73
	P18 = 129.24

THE PRESSURE DROP ACROSS THE CONDENSATE FLOW CONTROL VALVE (V6A) IS 0.0 PSI
 THE PRESSURE DROP ACROSS THE FEED FLOW CONTROL VALVE IS .0 PSI

OVERALL POWER BALANCE

TURBINE THERMAL POWER IS 14.73 MEGAWATTS

GROSS ELECTRICAL POWER IS 14.44 MEGAWATTS

TOTAL PARASITIC LOSSES ARE 4.11 MEGAWATTS, APPORTIONED AS FOLLOWS

COLD SEAWATER PUMPING POWER	1.77 MEGAWATTS
WARM SEAWATER PUMPING POWER	1.35 MEGAWATTS

AMMONIA CONDENSATE PUMPING POWER	.32 MEGAWATTS
----------------------------------	---------------

AMMONIA FEED PUMPING POWER	.16 MEGAWATTS
----------------------------	---------------

MISCELLANEOUS POWER REQUIREMENTS	.50 MEGAWATTS
----------------------------------	---------------

NET ELECTRICAL POWER IS 10.33 MEGAWATTS

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

ATTACHMENT II

DESCRIPTION OF FUNCTIONS AND SUBROUTINES

PROGRAM LISTING

These will be furnished at customer's request.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX A.3
HYDRAULIC TRANSIENT MODEL

A.3. HYDRAULIC TRANSIENT MODEL

The vertical motion of the hull causes flow transients in the cold and warm water systems, which cause unsteady flow on the waterside of the heat exchangers. In order to examine the nature of the unsteady flow and to determine its effect, a dynamic mathematical model of the water flow was set up and was solved numerically by computer. In the model, the hydraulic features of a 40 MW platform are represented by three subsystems. The cold water pipe and open trough are represented as a single subsystem as shown in Figure 1. The second subsystem consists of a condenser, an evaporator, and their common effluent discharge pipe as shown in Figure 2. The third subsystem includes all of the seawater pumps and is represented by a dimensionless pump characteristic curve as shown in Figure 3. The symbols used to represent these subsystems are defined in Tables 1, 2, and 3, respectively.

Table 1. Symbols Used for Representation of Cold Water Pipe and Open Trough

a_1	= area of horizontal water surface in the trough (constant)
A_1	= cross section area of cold water pipe (constant)
D_r	= draft (constant) = depth from mean sea level to floor of open trough in calm sea with no pumping
D_1	= internal diameter of cold water pipe (constant)
h_1	= elevation of water surface in trough with respect to datum elevation (function of time, positive up from datum)
h_{MSL}	= elevation of mean sea level with respect to datum elevation (constant, positive up from datum)
V_1	= absolute velocity of flow in cold water pipe (function of time, positive up pipe into trough)
z_1	= elevation of floor of trough with respect to datum elevation (function of time, positive up from datum)
z_0	= half amplitude of heave of platform
z_1'	= value of z_1 in calm sea




Fig. 1. Cold-Water Pipe and Open Trough




Fig. 2. Evaporator, Condenser, and Effluent Discharge Pipe

FIGURE 3
DIMENSIONLESS PUMP CHARACTERISTIC CURVE




Table 1. Symbols Used for Representation of Cold Water Pipe and Open Trough (Continued)

Z_1 = depth of water in trough (function of time)

ΣQ_p = total rate of flow out of trough through all cold water pumps (function of time)

L_1 = length of cold water pipe from bottom end to floor of trough (constant)

MSL = mean sea level

g = acceleration due to gravity

t = time

$\Delta h_{s,1}$ = difference in static head due to difference between water temperatures inside and outside of cold water pipe

f_1 = Darcy friction factor for cold water pipe

ω = frequency of heave of platform

Table 2. Symbols Used for Representation of Heat Exchangers and Effluent Discharge Pipe

a_2 = area of horizontal water surface in top water box of evaporator (constant)

a_3 = area of horizontal water surface in top water box of condenser (constant)

A_2' = total cross section area of all tubes in evaporator (constant)

A_3' = total cross section area of all tubes in condenser (constant)

A_2 = cross section area of evaporator branch of discharge pipe (constant)

A_3 = Cross section area of condenser branch of discharge pipe (constant)

A_4 = cross section area of combined effluent discharge pipe (constant)

D_2 = diameter of evaporator branch of discharge pipe (constant)

D_3 = diameter of condenser branch of discharge pipe (constant)

D_4 = diameter of combined effluent discharge pipe (constant)

Table 2. Symbols Used for Representation of Heat Exchangers and Effluent Discharge Pipe (Continued)

h_2	= elevation of water surface in top water box in evaporator with respect to datum elevation (function of time, positive up from datum)
h_3	= elevation of water surface in top water box in condenser with respect to datum elevation (function of time, positive up from datum)
$\Delta H'_{e,2}$	= energy loss during flow from top water box into tubes in evaporator (function of velocity V'_2)
$\Delta H'_{e,3}$	= energy loss during flow from top water box into tubes in condenser (function of V'_3)
$\Delta H_{e,2}$	= energy loss during flow from evaporator bottom water box to branch discharge pipe (function of V_2)
$\Delta H_{e,3}$	= energy loss during flow from condenser water box to branch discharge pipe (function of V_3)
L'_2	= length of flow path through evaporator tubes and bottom water box (constant)
L'_3	= length of flow path through condenser tubes and bottom water box (constant)
L_2	= length of evaporator branch discharge pipe (constant)
L_3	= length of condenser branch discharge pipe (constant)
L_4	= length of combined discharge pipe (constant)
p_1	= pressure at bottom tubesheet of evaporator (function of time)
p_3	= pressure at bottom tubesheet of condenser (function of time)
p_2	= pressure at junction of branch discharge pipes (function of time)
$Q_{p,2}$	= rate of flow pumped into top water box of evaporator (function of time)
$Q_{p,3}$	= rate of flow pumped into top water box of condenser (function of time)
V'_2	= absolute velocity of flow in evaporator tubes (function of time, positive toward discharge outlet)
V'_3	= absolute velocity of flow in condenser tubes (function of time, positive toward discharge outlet)

Table 2. Symbols Used for Representation of Heat Exchangers and Effluent Discharge Pipe (Continued)

V_2 = absolute velocity of flow in evaporator branch discharge pipe (function of time, positive toward discharge outlet)

V_3 = absolute velocity of flow in condenser branch discharge pipe (function of time, positive toward discharge outlet)

V_4 = absolute velocity of flow in combined discharge pipe (function of time, positive toward discharge outlet)

$V_{e,4}$ = absolute velocity at outlet end of combined discharge pipe (function of time, positive out of pipe)

z_2 = elevation of evaporator top tubesheet with respect to datum (function of time, positive up from datum)

z_3 = elevation of condenser top tubesheet with respect to datum (function of time, positive up from datum)

z_4 = elevation of junction of branch interceptors with respect to datum (function of time, positive up from datum)

Z_2 = depth of water in top water box of evaporator (function of time)

Z_3 = depth of water in top water box of condenser (function of time)

α = coefficient (constant)

β = coefficient (constant)

θ = angle between vertical and branch discharge conduit (constant)

γ = unit weight of water (constant)

$\Delta H'_{f,2}$ = friction losses in evaporator tubes (function of V'_2 and time)

$\Delta H'_{f,3}$ = friction losses in condenser tubes (function of V'_3 and time)

$\Delta H_{f,2}$ = friction losses in evaporator branch discharge pipe (function of V_2 and time)

$\Delta H_{f,3}$ = friction losses in condenser branch discharge pipe (function of V_3 and time)

$\Delta H_{f,4}$ = friction losses in combined discharge pipe (function of V_4 and time)

Table 3. Symbols Used for Representation of Pumps

H = head delivered by pump (function of time)

H_0 = head delivered by pump at steady state in calm sea (constant)

Q = rate of flow pumped (function of time)

Q_0 = rate of flow pumped at head H_0 with steady state and calm sea (constant)

z_0' = half amplitude of wave motion driving the heave of the platform (constant)

For each subsystem, the flow in each component is described by equation of continuity and momentum. The former are written in terms of velocities relative to the hull, pipes, tubesheets, etc. The momentum equations are written in terms of absolute velocities relative to fixed space, except for the terms that determine entrance and friction losses. These terms are written with the same relative velocities used in the continuity equations. The absolute velocities are needed for terms involving momentum and acceleration.

For the cold water pipe and open trough, the continuity equation is concerned primarily with the trough while the momentum equation is concerned primarily with the pipe. The continuity equation is

$$A_1 \left(V_1 - \frac{dz_1}{dt} \right) - \Sigma Q_p = a_1 \frac{dZ_1}{dt} \quad (1)$$

while the momentum equation is

$$-\frac{L_1}{g} \frac{dV_1}{dt} = z_1 + Z_1 - h_{MSL} + \Delta h_{s,1} + \frac{V_1^2}{2g} + \frac{f_1 L_1}{2gD_1} \left(V_1 - \frac{dz_1}{dt} \right)^2 \quad (2)$$

In order to guarantee that the friction force always acts in the correct direction, the square of the relative velocity in equation (2) can be replaced by $\left| \left(V_1 - \frac{dz_1}{dt} \right) \right| \left(V_1 - \frac{dz_1}{dt} \right)$. However, since no reversal of flow in the pipe was anticipated this elaboration was not used.

The elevation, z_1 , can be divided into a static term, z_1' , and an oscillating term, $z_0 \sin \omega t$. The first gives the value of z_1 in a calm sea, while the second is a sinusoidal representation of the heave of the platform. With this division the values of z_1 and Z_1 always satisfy the equation

$$z_1 + Z_1 - h_{MSL} = Z_1 - D_r + z_0 \sin \omega t \quad (3)$$

Substitution of equation (3) in equation (2) leads to

$$-\frac{L_1}{g} \frac{dV_1}{dt} = Z_1 - D_r + z_0 \sin \omega t + \Delta h_{s,1} + \frac{V_1^2}{2g} + \frac{f_1 L_1}{2gD_1} (V_1 - \frac{dz_1}{dt})^2 \quad (4)$$

Continuity equations for the heat exchangers are similar to those for the trough. The equations for the evaporator and condenser are respectively

$$Q_{p,2} - A_2' (V_2' + \frac{dz_2}{dt}) = a_2 \frac{dZ_2}{dt} \quad (5)$$

$$Q_{p,3} - A_3' (V_3' + \frac{dz_3}{dt}) = a_3 \frac{dZ_3}{dt} \quad (6)$$

The velocities in the tubesheet can be eliminated using the continuity equations between heat exchanger and branch discharge pipe. That is

$$A_2' (V_2' + \frac{dz_2}{dt}) = A_2 \left[(V_2 \cos \theta + \frac{dz_2}{dt})^2 + (V_2 \sin \theta)^2 \right]^{1/2} \quad (7)$$

and

$$A_3' (V_3' + \frac{dz_3}{dt}) = A_3 \left[(V_3 \cos \theta + \frac{dz_3}{dt})^2 + (V_3 \sin \theta)^2 \right]^{1/2} \quad (8)$$

Substitution of equations (7) and (8) into equations (5) and (6), respectively, leads to the following overall equations for each interceptor and branch discharge pipe.

$$Q_{p,2} - A_2 \left[(V_2 \cos \theta + \frac{dz_2}{dt})^2 + (V_2 \sin \theta)^2 \right]^{1/2} = a_2 \frac{dZ_2}{dt} \quad (9)$$

$$Q_{p,3} - A_3 \left[(V_3 \cos \theta + \frac{dz_3}{dt})^2 + (V_3 \sin \theta)^2 \right]^{1/2} = a_3 \frac{dZ_3}{dt} \quad (10)$$

Finally flow in the branches is related to flow in the combined discharge pipe by the following continuity equation

$$A_2 \left[\left(V_2 \cos \theta + \frac{dz_2}{dt} \right)^2 + (V_2 \sin \theta)^2 \right]^{1/2} + A_3 \left[\left(V_3 \cos \theta + \frac{dz_3}{dt} \right)^2 + (V_3 \sin \theta)^2 \right]^{1/2} = A_4 \left(V_4 + \frac{dz_4}{dt} \right) \quad (11)$$

The momentum equations for the heat exchangers and discharge pipes are similar to those for the trough and cold water pipe. However, the equations for the individual components must be written in terms of intermediate pressures p_1 , p_2 , and p_3 . For the heat exchangers, the equations become:

$$- \frac{L'_2}{g} \frac{dV'_2}{dt} = -L'_2 + \frac{V_2'^2}{2g} + \frac{p_1}{\gamma} - \alpha_2 \frac{V_1'^2}{2g} - Z_2 + \Delta H'_{e,2} + \Delta H'_{f,2} \quad (12)$$

$$- \frac{L'_3}{g} \frac{dV'_3}{dt} = -L'_3 + \frac{V_3'^2}{2g} + \frac{p_3}{\gamma} - \alpha_3 \frac{V_3'^2}{2g} - Z_3 + \Delta H'_{e,3} + \Delta H'_{f,e} \quad (13)$$

In these equations α_i and β_i are defined by

$$\alpha_i = \frac{A_i'}{A_B} \left(1 - \frac{A_i'}{A_B} \right) \quad \beta_i = \left(\frac{A_i'}{A_B} \right)^2 \quad (14)$$

in which A_B is the cross section area of the bottom water box of the heat exchanger. The equations for the branch discharge pipes become

$$\begin{aligned} \frac{p_2}{\gamma} - \frac{p_3}{\gamma} + (1 - \beta_2) \frac{V_2^2}{2g} - L_2 \cos \theta + \Delta H_{e,2} + \Delta H_{f,2} \\ = - \frac{L_2}{g} \frac{dV_2}{dt} - \frac{V_2^2}{g} (1 - \sqrt{\beta_2} \cos \theta) \end{aligned} \quad (15)$$

and

$$\begin{aligned} \frac{p_1}{\gamma} - \frac{p_3}{\gamma} + (1 - \beta_3) \frac{V_3^2}{2g} - L_3 \cos \theta + \Delta H_{e,3} + \Delta H_{f,3} = \\ - \frac{L_3}{g} \frac{dV_3}{dt} - \frac{V_3^2}{g} (1 - \sqrt{\beta_3} \cos \theta) \end{aligned} \quad (16)$$

Equations 12 and 13 can be combined with 15 and 16 respectively to yield the following overall equation from the top water boxes to the junction of the branch discharge pipes.

$$\begin{aligned} - \frac{L'_2}{g} \frac{dV'_2}{dt} - \frac{L_2}{g} \frac{dV_2}{dt} = \frac{p_2}{\gamma} - L_2 \cos \theta - Z_2 + \frac{V_2^2}{g} (1 - \sqrt{\beta_2} \cos \theta) \\ + (1 - \alpha_2) \frac{V'^2_2}{2g} + (1 - \beta_2) \frac{V_2^2}{2g} + \Delta H'_{e,2} + \Delta H'_{f,2} + \Delta H_{f,2} + \Delta H_{e,2} \end{aligned} \quad (17)$$

$$\begin{aligned} - \frac{L'_3}{g} \frac{dV'_3}{dt} - \frac{L_3}{g} \frac{dV_3}{dt} = \frac{p_2}{\gamma} - L'_3 - L_3 \cos \theta - Z_3 + \frac{V_3^2}{g} (1 - \sqrt{\beta_3} \cos \theta) \end{aligned} \quad (18)$$

$$+ (1 - \alpha_3) \frac{V'^2_3}{2g} + (1 - \beta_3) \frac{V_3^2}{2g} + \Delta H'_{e,3} + \Delta H_{e,3} + \Delta H'_{f,3} + \Delta H_{f,3}$$

The momentum equation for the combined discharge pipe also requires the intermediate pressure p_2 at the junction. The equation is:

$$\begin{aligned} - \frac{L_4}{g} \frac{dV_4}{dt} = h_{MSL} - z_4 - \frac{p_2}{\gamma} + \frac{V_{e,4}^2}{2g} \\ + \frac{V_4^2}{2g} + \Delta H_{f,4} - \frac{1}{g} \left(\frac{A_2}{A_4} \right) V_2^2 \cos \theta - \frac{1}{g} \left(\frac{A_3}{A_4} \right) V_3^2 \cos \theta \end{aligned} \quad (19)$$

In the current form of the dynamic model, the momentum and dynamics of the seawater pumps and their motors are not considered. Each pump is represented by an approximate characteristic curve that gives delivered head as a function of discharge. For the cold water pump, the delivered head H_3 is the difference $h_3 - h_1$ between water surface elevations in the open trough and the top water box of the condenser. This difference is given by

$$H_3 = h_3 - h_1 = Z_3 - Z_1 + D_r \quad (20)$$

For the warm water pump, the delivered head H_2 is equal to the difference between h_2 and the sea outside the hull. If the wave motion that drives the heave of the platform is represented by $z_0' \sin \omega t$, the delivered head on the warm water pump is given by

$$H_2 = h_2 - z_0' \sin \omega t = Z_2 + (z_0 - z_0') \sin \omega t \quad (21)$$

At any time the delivered head is determined from the values of Z_1 , Z_2 , and Z_3 and Equation 20 or 21. The value of flow is then obtained from the characteristic curve for the pump.

The use of only one curve for each pump is equivalent to the assumption that the pump operates at constant speed as the head changes. The change in pump torque and pump speed due to variation in head has been ignored.

As already shown in Figure 3, a dimensionless pump curve is used. The same curve is used for cold and warm water. For each pump, the values of H_0 and Q_0 are the delivered head and discharge, respectively, for steady state in a calm sea.

In addition to the pump curve, there is a relationship between flow rates $Q_{p,3}$ and ΣQ_p . Since all of the flow is pumped to the condensers from the trough

$$\Sigma Q_p = 4 Q_{p,3} \quad (22)$$

Equations 1, 4, 7, 8, 9, 10, 11, 17, 18, 19, 20, 21, 22, and the two pump characteristic curves for cold and warm water form a set of 15 equations with 15 variables $V_1, V_2', V_2, V_3', V_3, V_4, Z_1, Z_2, Z_3, Q_{p,2}, Q_{p,3}, \Sigma Q_p, P_2, H_2$ and H_3 . By differentiation and substitution, Equation 7, 8, 11, 17, 18 and 19 are reduced to two equations in V_3 and V_2 , and the variables V_2', V_3', V_4 and p_2 are eliminated. The result is two equations with the functional form

$$C_{1,1} \frac{dV_3}{dt} + C_{1,2} \frac{dV_2}{dt} = C_{1,0} \quad (23)$$

$$C_{2,1} \frac{dV_3}{dt} + C_{2,2} \frac{dV_2}{dt} = C_{2,0} \quad (24)$$

In addition, Equation 22 is used to eliminate $Q_{p,3}$. The set is reduced to 10 equations, 1, 4, 9, 10, 20, 21, 23, 24 and two pump curves. The 10 variables are $V_1, V_2, V_3, Z_1, Z_2, Z_3, Q_{p,2}, Q_{p,3}, H_2$ and H_3 . This set of 10 equations and variables is solved numerically by computer. Values of the variables at time t are used in the equations to calculate the values after an increment Δt of time.

In 8 of the equations and variables, an explicit method of solution is used. In each equation only one variable is allowed to change during Δt . The other variables are treated as constants with values that they have at time t . The equation is then solved independently for the value of the one variable that changes. In Equation 1, for example, all variables except Z_1 , are treated as constants with values from time t . The equation is solved independently for the change in Z_1 , during Δt . Similarly, Equation 4 is solved independently for the change in V_1 . The changes during Δt are added to the values of the variables at t to obtain values at $t + \Delta t$. For a pump curve, the value of H at t is used to determine Q_p at t . The value of Q_p then remains constant until $t + \Delta t$.

Equation 23 and 24 are solved implicitly, that is V_3 and V_2 both change during Δt , and the equations are solved simultaneously for the changes. The changes are then added to values at t to obtain values at $t + \Delta t$. Since Equation 23 and 24 represent the 6 original equations 7, 8, 11, 17, 18 and 19, all 6 equations are essentially solved simultaneously.

PREPARED _____

CHECKED _____

MODEL _____

VARIABLE NAME	FORTRAN NAME	VARIABLE NAME	FORTRAN NAME	VARIABLE NAME	FORTRAN NAME
a_1	A	L_4	LY	Z_2	GZ2
a_2	AWB2	L_2	LE	Z_3	GZ3
a_3	AWB3	L_3	LC	Z_4	GZ4
A_1	A1	P_1	P1	Z_1	Z1
A_2	A2	P_2	P2	Z_2	Z2
A_3	A3	P_3	P3	Z_3	Z3
A_4	A4	ΣQ_p	QP	$\Delta H_{e,2}$	HE2
A'_2	AE	$Q_{p,2}$	QP2	$\Delta H_{e,3}$	HE3
A'_3	AC	$Q_{p,3}$	QP3	$\Delta H_{e',2}$	HEE
D_1	D1	t	T	$\Delta H_{e',3}$	HEC
D_2	D2	V_1	V1	$\Delta H_{f,2}$	HF2
D_3	D3	V_2	V2	$\Delta H_{f,3}$	HF3
D_4	D4	V_3	V3	$\Delta H_{f,4}$	HF4
D_r	DR	V_4	V4	$\Delta H'_{f,2}$	HFE
f_1	F1	V'_2	VE	$\Delta H'_{f,3}$	HEC
g	G	V'_3	VC	$\Delta h_{s,1}$	DHS
h_{msl}	HMSL	$V_{e,4}$	VED	Δt	DT
H_0	HO	Z_0	ZHI		
L_1	L1	Z_1	GZ1		
L_2	L2				
L_3	L3				

PREPARED _____

CHECKED _____

MODEL _____

VARIABLE NAME	FORTRAN NAME	VARIABLE NAME	FORTRAN NAME	VARIABLE NAME	FORTRAN NAME
β	BETA	$\frac{dz_y}{dt}$	DG2y		
θ	THETA				
ω	W	$\frac{dz_1}{dt}$	DZ1		
α	ALPHA				
$\frac{dv_1}{dt}$	DV1	$\frac{dz_2}{dt}$	DZ2		
$\frac{dv_2}{dt}$	DV2				
$\frac{dv_3}{dt}$	DV3	$\frac{dz_3}{dt}$	DZ3		
$\frac{dv_4}{dt}$	DV4				
$\frac{dv'_2}{dt}$	DVE				
$\frac{dv'_3}{dt}$	DVC				
$\frac{dz_1}{dt}$	DGZ1				
$\frac{dz_2}{dt}$	DGZ2				
$\frac{dz_3}{dt}$	DGZ3				

A-104

PROGRAM LISTING

```

00100 PROGRAM ENWAT(INPUT,OUTPUT,TAPE5=INPUT,TAPE6)
00110 COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
00120 COMMON/COM2/D4,D3,D2,D1,DE,DC
00130 COMMON/COM3/L4,L3,L2,L1,LE,LC
00140 COMMON/COM4/A4,A3,A2,A1,AE,AC,A
00150 COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
00160 COMMON/COM6/DWB2T,DWB3T,AWB2T,AWB3T,THETA
00170 COMMON/COM7/Z,V1,Z2,V2,Z3,V3,V4,VE,VC,VED
00180 COMMON/COM8/DZ,DV1,DZ2,DV2,DZ3,DV3,DV4,
00190 + DVE,DVC
00200 COMMON/COM9/HEE,HFE,HE2,HF2,HEC,HFC,HE3,HF3,HF4
00210 COMMON/COM10/DT1,CFLOW,NMAX
00220 EQUIVALENCE (D2GZ,D2GZ2,D2GZ3,D2GZ4)
00230 EQUIVALENCE (DGZ,DGZ2,DGZ3,DGZ4)
00240 DATA L,DR/5,63./
00250 DATA PI,ZH0,TH,TMAX/
00260 +3.1415927,10.7,16.19,100./
00270 DATA D1,A,L1,G,DHS,DT1,EPS/
00280 +30.505,5893.,2950,32.174,3.,.2,.02/
00290 DATA HMSL,D4,D3,D2,DE1,DC1/0.0,22.03,15.2525,15.8975,
00300 + .87965,0.889/
00310 DATA L4,L3,L2,LE,LC/270,2*40,2*30/
00320 DATA DWB2T,DWB3T,QP20,QP30/2*27.,1191.0,1096.3/
00330 DATA DWB2B,DWB3B/2*27./
00340 DATA CFLOW,NMAX,NPRINT/0.0,62,0/
00350 NAMELIST/INPUT/PI,ZH0,TH,Z0,V10,TMAX,
00360 + D1,A,L1,G,DHS,DT1,EPS,L,DR,D4,D3,D2,DE1,DC1,
00370 + L4,L3,L2,Z20,Z30,V20,V30,CFLOW,DWB2T,DWB3T,NMAX,
00380 + NPRINT
00390 17 READ(5,INPUT)
00400 IF(L.EQ.65)GO TO 65
00410 IF(L.EQ.64)GO TO 18
00420 DE=DE1/12.
00430 DC=DC1/12.
00440 CALL CAL10(A1,D1,A4,D4,1)
00450 CALL CAL10(A2,D2,AE,DE,42667)
00460 CALL CAL10(AWB2T,DWB2T,AWB3T,DWB3T,1)
00470 CALL CAL10(AWB2B,DWB2B,AWB3B,DWB3B,1)
00480 CALL CAL10(A3,D3,AC,DC,43678)
00490 CALL CAL11(BETA2,A2,AWB2B,ALPHA2,AE)
00500 CALL CAL11(BETA3,A3,AWB3B,ALPHA3,AC)
00510 DT=DT1
00520 QP3=QP30
00530 QP2=QP20
00540 QP=4.*QP3
00550 Z2=0.0
00560 Z3=0.0
00570 V1=QP/A1
00580 V2=QP2/A2
00590 V3=QP3/A3
00600 THETA=PI/6.
00610 N=1
00620 NN=1
00630 T=-1.0
00640 16 CONTINUE
00650 C IF(T.EQ.2.0.OR.T.EQ.4.0)DT=2.*DT
00660 IF(T.NE.-1.0.AND.T.LT.0.0)T=0.0
00670 CALL HEAVE(T)
00680 IF(T.EQ.-1.0)GO TO 20

```

```

00690      CALL FLOW(Z3-Z+DR,QP3,H30,QP30)
00700      CALL FLOW(Z2-CFLOW+DGZ,QP2,H20,QP20)
00710      QP=4.+QP3
00720 20    CONTINUE
00730      CALL FRICFAC(V1-DGZ,EPS/D1,F1,D1,1.70906E-5)
00740      CALL CAL1(F22,THETA,V2,DGZ2)
00750      CALL CAL2(DZ2,F22+A2,QP2,AWB2T)
00760      CALL CAL1(F33,THETA,V3,DGZ3)
00770      CALL CAL2(DZ3,F33+A3,QP3,AWB3T)
00780      CALL CAL3(VE,F22+A2,0.0,DGZ2,AE)
00790      CALL CAL3(VC,F33+A3,0.0,DGZ3,AC)
00800      CALL CAL3(V4,F22+A2,F33+A3,DGZ4,A4)
00810      VED=V4/2.
00820      CALL FRICFAC(V4+DGZ,0.01/D4,F4,D4,1.26150E-5)
00830      CALL FRICFAC(V3+DGZ,0.01/D3,F3,D3,1.70906E-5)
00840      CALL FRICFAC(V2+DGZ,0.01/D2,F2,D2,0.97915E-5)
00850      CALL FRICFAC(VE+DGZ,0.0001/DE,FE,DE,0.97915E-5)
00860      CALL FRICFAC(VC+DGZ,0.0001/DC,FC,DC,1.70906E-5)
00870      CALL PDROP(HEE,VE+DGZ,0.3,HE2,V2+DGZ,0.25)
00880      CALL PDROP(HEC,VC+DGZ,0.3,HE3,V3+DGZ,0.25)
00890      CALL PDROP(HFE,VE+DGZ,FE+LE/DE,HFC,VC+DGZ,FC+LC/DC)
00900      CALL PDROP(HF2,V2+DGZ,F2+L2/D2,HF3,V3+DGZ,F3+L3/D3)
00910      CALL PDROP(HF4,V4+DGZ,F4+L4/D4,XXX,0.0,0.0)
00920      CALL CAL5(CC1,CC2,CC3,D2GZ2,D2GZ3,D2GZ4,
00930 +      AE,AC,A4)
00940      CALL CAL6(CF4,CF3,CF2,CF1,LE,L2,Z2,
00950 +      VE,V2,ALPHA2,BETA2,HEE,HFE,HE2,HF2)
00960      CALL CAL6(CG4,CG3,CG2,CG1,LC,L3,Z3,
00970 +      VC,V3,ALPHA3,BETA3,HEC,HFC,HE3,HF3)
00980      IF(T.GT.-1.0) GO TO 14
00990      Z=- (GZ+DHS-DR+V1*ABS(V1))/(2.*G)+
01000 +      (F1+L1/2./G/D1)*(V1)*ABS(V1))
01010      Z2=CF4
01020      Z3=CG4
01030      CF4=0.0
01040      CG4=0.0
01050      H30=Z3-Z+DR
01060      H20=Z2
01070 14    CONTINUE
01080      CALL CAL4(CA1,CA2,A2,AE,F22,V2,THETA,DGZ2,D2GZ2)
01090      CALL CAL4(CB1,CB2,A3,AC,F33,V3,THETA,DGZ3,D2GZ3)
01100      CALL CAL7(CH1,CH2,CH3,CH4,CF1,CF2,
01110 +      CF3,CF4,CC1,CC2,CC3)
01120      CALL CAL7(CI1,CI2,CI3,CI4,CG1,CG2,
01130 +      CG3,CG4,CC2,CC1,CC3)
01140      CALL CAL8(CX1,CX2,CX3,CH1,CH2,CH3,CH4,
01150 +      CA1,CA2,CB1,CB2)
01160      CALL CAL8(CY1,CY3,CY2,CI1,CI2,CI3,CI4,
01170 +      CB1,CB2,CA1,CA2)
01180      CALL CAL9(DV2,DV3,CX1,CX2,CX3,CY1,CY2,CY3)
01190      CALL DIFF(T)
01200      IF(T.EQ.0.0.OR.T.EQ.-1.)GO TO 13
01210      IF(N.EQ.L)GO TO 13
01220      N=N+1
01230      T=T+DT
01240      CALL INT(DT,T)
01250      GO TO 16
01260 13    N=1
01270      CALL PLOT(T,NN)
01280      NN=NN+1
01290 15    T=T+DT
01300      CALL INT(DT,T)
01310      IF(NN.LE.NMAX)GO TO 16
01320      IF(NPRINT.NE.0)GO TO 18
01330      GO TO 17
01340 18    CALL PRINT(T,NPRINT)

```

```

01350      GO TO 17
01360 65    CONTINUE
01370      END
01380      SUBROUTINE INT(DT,T)
01390      COMMON/COM7/Y(10)
01400      COMMON/COM8/F(9)
01410      DO 10 I=1,6
01420 10    Y(I)=Y(I)+DT*F(I)
01430      RETURN
01440      END
01450      SUBROUTINE HEAVE(T)
01460      COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
01470      COMMON/COM3/L4,L3,L2,L1,LE,LC
01480      COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
01490      COMMON/COM6/DWB2T,DWB3T,AWB2T,AWB3T,THETA
01500      IF(T.EQ.-1.0)GO TO 10
01510      IF(T.LE.10.0)ZH1=ZH0*T/10.
01520      W=2.*PI/TH
01530      GZ=ZH1*SIN(W*T)
01540      GZ4=GZ-(LE+L2*CDS(THETA))
01550      DGZ=W*ZH1*CDS(W*T)
01560      D2GZ=-W*W*ZH1*SIN(W*T)
01570      RETURN
01580 10    GZ=0.0
01590      DGZ=0.0
01600      D2GZ=0.0
01610      GZ4=-(LE+L2*CDS(THETA))
01620      RETURN
01630      END
01640      SUBROUTINE DIFF(T)
01650      COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
01660      COMMON/COM2/D4,D3,D2,D1,DE,DC
01670      COMMON/COM3/L4,L3,L2,L1,LE,LC
01680      COMMON/COM4/A4,A3,A2,A1,AE,AC,A
01690      COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
01700      COMMON/COM7/Z,V1,Z2,V2,Z3,V3,V4,VE,VC,VED
01710      COMMON/COM8/F(9)
01720      F(1)=(A1/A)*(V1-DGZ)-QP/A
01730      F(2)=-(G/L1)*(GZ+Z+DHS-DR+V1*ABS(V1))/(2.*6)+
01740 +      (F1*L1/2./G/D1)*(V1-DGZ)*ABS(V1-DGZ)
01750      RETURN
01760      END
01770      SUBROUTINE FRICFAC(V1,EDD,FD,D1,XNU)
01780 C
01790 C      COMPUTES FRICTION FACTORS USING COLEBROOKS CORRELATION.
01800      RE=ABS(V1)*D1/XNU
01810      IF(RE.LT.500000.) GO TO 11
01820      FD = .316/SQRT(SQRT(RE))
01830      X = 1./SQRT(FD)
01840      A = EDD/3.7
01850      B = 2.51/RE
01860      DX = 0.
01870      N = -1
01880 2      X = X + DX
01890      U = A + B*X
01900      IF(U.LE.0.0)GO TO 12
01910      DYDX = 1. + .86*B/U
01920      DX = -(X + .86*ALOG(U))/DYDX
01930      N = N + 1
01940      IF(ABS(DX/X).GT..001) GO TO 2
01950      FD = 1./(X*X)
01960      RETURN
01970 12    FD=.316/SQRT(SQRT(RE))
01980      RETURN
01990 11    CONTINUE
02000      DATA C1,C2,C3/0.025,-0.7534,1.386/

```

```

02010      REL=ALDG(RE)
02020      FDL=C1*(REL**2)+C2*REL+C3
02030      FD=EXP(FDL)
02040      FD=FD*1.46
02050 10    CONTINUE
02060      RETURN
02070      END
02080      SUBROUTINE CAL1(F3,THETA,V,DGZ)
02090 C      THIS COMPUTES MAGNITUDE OF HX VELOCITY
02100      F1=V*COS(THETA)+DGZ
02110      F2=V*SIN(THETA)
02120      F3=SQRT(F1**2+F2**2)
02130      RETURN
02140      END
02150      SUBROUTINE CAL2(DX,F,QP,AWB)
02160 C      COMPUTES EQUATIONS NO. 1 AND 2.
02170      DX=(QP-F)/AWB
02180      RETURN
02190      END
02200      SUBROUTINE CAL3(V,F3,F2,DGZ,A)
02210 C      COMPUTES EQUATIONS 6,7, AND 8.
02220      V=(F3+F2)/A -DGZ
02230      RETURN
02240      END
02250      SUBROUTINE CAL4(C1,C2,A2,AE,F2,V2,THETA,DGZ,D2GZ)
02260 C      COMPUTES COEFFICIENTS FOR EQUATIONS 9 AND 10 IN
02270 C      THE FORM OF EQUATIONS 14 AND 15.
02280      X1=A2/AE/F2
02290      C2=X1*(V2+DGZ*COS(THETA))
02300      C1=X1*(V2+D2GZ*COS(THETA)+DGZ*D2GZ)-D2GZ
02310      RETURN
02320      END
02330      SUBROUTINE CAL5(CC1,CC2,CC3,D2GZ2,D2GZ3,D2GZ4,
02340 +      AE,AC,A4)
02350 C      COMPUTES COEFFICIENTS OF EQUATION NO. 11
02360 C      IN THE FORM OF EQUATION 11B
02370      CC1=AE/A4
02380      CC2=AC/A4
02390      CC3=CC1*D2GZ2+CC2*D2GZ3-D2GZ4
02400      RETURN
02410      END
02420      SUBROUTINE CAL6(CF4,CF3,CF2,CF1,LEX,L2X,Z2X,
02430 +      VEX,V2X,ALPHA,BETA,HFEX,HFFX,HF2X,HF2X)
02440 C      COMPUTES COEFFICIENTS OF EQUATIONS 12 AND 13
02450 C      IN THE FORM OF EQUATION 12B
02460      COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
02470      COMMON/COM2/D4,D3,D2,D1,DE,DC
02480      COMMON/COM3/L4,L3,L2,L1,LE,LC
02490      COMMON/COM4/A4,A3,A2,A1,AE,AC,A
02500      COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
02510      COMMON/COM6/DWB2T,DWB3T,AWB2T,AWB3T,THETA
02520      COMMON/COM7/Z,V1,Z2,V2,Z3,V3,V4,VE,VC,VED
02530      COMMON/COM8/DZ,DV1,DZ2,DV2,DZ3,DV3,DV4,
02540 +      DVE,DVC
02550      COMMON/COM9/HEE,HFE,HE2,HF2,HEC,HFC,HE3,HF3,HF4
02560      HT=HEEX+HFEX+HE2X+HF2X
02570      C1=HMSL-GZ4+HF4-Z2X
02580      C2=(VED*VED/2.-V4*V4/2.+V4*V4)/G
02590      C3=-(A2*V2+V2+A3*V3*V3)*COS(THETA)/G/A4
02600      C4=V2X*V2X*(1.-SQRT(BETA)*COS(THETA))/G
02610      C5=((1.-ALPHA)*VEX*VEX+(1.-BETA)*V2X*V2X)/2./G
02620      CF4=C1+C2+C3+C4+C5+HT-LEX-L2X*COS(THETA)
02630      CF3=-L4/G
02640      CF2=-L2X/G
02650      CF1=-LEX/G

```

```

02660 RETURN
02670 END
02680 SUBROUTINE CAL7(CH1,CH2,CH3,CH4,CF1,CF2,
02690 + CF3,CF4,CC1,CC2,CC3)
02700 C COMPUTES COEFFICIENTS OF EQUATIONS NO. 16 AND 17.
02710 CH1=CF1+CF3+CC1
02720 CH2=CF2
02730 CH3=CF3+CC2
02740 CH4=CF4-CF3+CC3
02750 RETURN
02760 END
02770 SUBROUTINE CAL8(CX1,CX2,CX3,CH1,CH2,CH3,CH4,
02780 + CA1,CA2,CB1,CB2)
02790 C COMPUTES COEFFICIENTS OF EQUATIONS 18 AND 19.
02800 CX1=CH1+CA1+CH3+CB1-CH4
02810 CX2=CH1+CA2+CH2
02820 CX3=CH3+CB2
02830 RETURN
02840 END
02850 SUBROUTINE CAL9(DV2,DV3,X1,X2,X3,Y1,Y2,Y3)
02860 C SOLVES EQUATIONS 20 AND 21.
02870 X6=Y2-Y3+X2/X3
02880 X7=Y3+X1/X3-Y1
02890 DV2=X7/X6
02900 DV3=(X1+X2+DV2)/(-X3)
02910 RETURN
02920 END
02930 SUBROUTINE PDROP(H1,V1,X1,H2,V2,X2)
02940 G=32.174
02950 H1=X1+V1+ABS(V1)/G/2.
02960 H2=X2+V2+ABS(V2)/G/2.
02970 RETURN
02980 END
02990 SUBROUTINE CAL10(A1,D1,A2,D2,N)
03000 PI=3.1415927
03010 A1=PI+D1+D1/4.
03020 A2=PI+D2+D2/N/4.
03030 RETURN
03040 END
03050 SUBROUTINE CAL11(BETA,A,AB,ALPHA,AX)
03060 BETA=(A/AB)+2.
03070 ALPHA=(AX/AB)+(1.-AX/AB)
03080 RETURN
03090 END
03100 SUBROUTINE PLOT(T,I)
03110 COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
03120 COMMON/COM2/D4,D3,D2,D1,DE,DC
03130 COMMON/COM3/L4,L3,L2,L1,LE,LC
03140 COMMON/COM4/A4,A3,A2,A1,AE,AC,A
03150 COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
03160 COMMON/COM6/DWB2T,DWB3T,AWB2T,AWB3T,THETA
03170 COMMON/COM7/Z,V1,Z2,V2,Z3,V3,V4,VE,VC,VED
03180 COMMON/COM8/DZ,DV1,DZ2,DV2,DZ3,DV3,DV4,
03190 + DVE,DVC
03200 COMMON/COM9/HEE,HFE,HE2,HF2,HEC,HFC,HE3,HF3,HF4
03210 COMMON/COM10/DT1,CFLOW,NMAX
03220 COMMON/COM11/X(100),YV11(100),YV22(100),YV33(100)
03230 COMMON/COM12/YDD(100),YZ2(100),YZ3(100),YD6Z(100)
03240 COMMON/COM13/YVCC(100),YVEE(100),YV44(100)
03250 YD6Z(I)=DGZ
03260 X(I)=T
03270 YV11(I)=V1-DGZ
03280 YV22(I)=V2+DGZ
03290 YV33(I)=V3+DGZ
03300 YV44(I)=V4+DGZ
03310 YDD(I)=Z-IR

```

```

03320      YZ2(I)=Z2
03330      YZ3(I)=Z3
03340      YVCC(I)=VC+DGZ
03350      YVEE(I)=VE+DGZ
03360      IF(I.EQ.NMAX)GO TO 20
03370      RETURN
03380 20    CONTINUE
03390      WRITE(6,36)CFLW,DT1
03400 36    FORMAT(/5X,6HCFLW=,F12.9,5X,4HDT1=,F12.9)
03410      WRITE(6,37)
03420      WRITE(6,34)(X(J),YV11(J),YVEE(J),YVCC(J),J=1,NMAX)
03430      WRITE(6,35)
03440      WRITE(6,34)(X(J),YDD(J),YZ2(J),YZ3(J),J=1,NMAX)
03450 34    FORMAT(4F15.9)
03460 35    FORMAT(/5X,4HTIME,11X,9HDRAW DOWN,6X,10HEVAP DEPTH,5X,
03470 +      10HCOND DEPTH)
03480 37    FORMAT(/5X,4HTIME,11X,8HV1-DZ/DT,7X,8HVE+DZ/DT,
03490 +      7X,8HVC+DZ/DT)
03500      RETURN
03510      END
03520      SUBROUTINE FLOW(H,QP,H0,QP0)
03530      DATA A,B,C/-1.82E-01,-5.5E-02,1.237/
03540      X=H/H0
03550      QP=(C+B*X+A*X*X)*QP0
03560      RETURN
03570      END
03580      SUBROUTINE PRINT(T,NPRINT)
03590      COMMON/COM1/ZH0,TH,PI,TMAX,G,DHS,HMSL,DR,F1
03600      COMMON/COM2/D4,D3,D2,D1,DE,DC
03610      COMMON/COM3/L4,L3,L2,L1,LE,LC
03620      COMMON/COM4/A4,A3,A2,A1,AE,AC,A
03630      COMMON/COM5/QP,QP2,QP3,GZ,DGZ,D2GZ,GZ4
03640      COMMON/COM6/DWB2T,DWB3T,AWB2T,AWB3T,THETA
03650      COMMON/COM7/Z,V1,Z2,V2,Z3,V3,V4,VE,VC,VED
03660      COMMON/COM8/DZ,DV1,DZ2,DV2,DZ3,DV3,DV4,
03670 +      DVE,DVC
03680      COMMON/COM9/HEE,HFE,HE2,HF2,HEC,HFC,HE3,HF3,HF4
03690      COMMON/COM10/DT1,CFLW,NMAX
03700      COMMON/COM11/X(100),YV11(100),YV22(100),YV33(100)
03710      COMMON/COM12/YDD(100),YZ2(100),YZ3(100),YDGZ(100)
03720      COMMON/COM13/YVCC(100),YVEE(100),YV44(100)
03730      PRINT 10
03740      DO 100 I=1,NPRINT
03750      V1=YV11(I)+YDGZ(I)
03760      VE=YVEE(I)-YDGZ(I)
03770      VC=YVCC(I)-YDGZ(I)
03780      V4=YV44(I)-YDGZ(I)
03790      Z=YDD(I)+DR
03800      QP4=A4*YV44(I)
03810      QPC=AC*YVCC(I)
03820      QPE=AE*YV22(I)
03830      QP=4.*QPC
03840 12    PRINT 11,X(I)
03850      PRINT 13,V1,VE,VC,V4
03860      PRINT 14,YV11(I),YVEE(I),YVCC(I),YV44(I)
03870      PRINT 15,Z,YZ2(I),YZ3(I)
03880      PRINT 17,QP,QPE,QPC,QP4
03890      PRINT 16,YDD(I)
03900 100  CONTINUE
03910 11    FORMAT(20HTIME,SECONDS           ,F13.4)
03920 13    FORMAT(20HSTATIONARY VEL,FT/S   ,4E13.4)
03930 14    FORMAT(20HRELATIVE VEL FT/S     ,4E13.4)
03940 15    FORMAT(20HWATER DEPTH FT        ,3E13.4)
03950 17    FORMAT(20HFLOW RATE CFS         ,4E13.4)
03960 16    FORMAT(20HDRAW DOWN FT          ,E13.4,/)
03970 10    FORMAT(///20X,3X,10HCW PIPE     ,3X,10HEVAPORATOR,3X,
03980 +      10HCONDENSER ,3X,9HEXIT PIPE)
03990      RETURN
04000      END

```

APPENDIX B

WATER SYSTEM DYNAMICS STUDIES

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX B .1

SUMMARY

B.1. SUMMARY

B.1.1 INTRODUCTION, PURPOSE, AND SCOPE

B.1.1.1 Introduction

The work described below is a study of the dynamics of the flow in the cold and warm water system, and it is part of Tasks b and c in the Statement of Work Number 1981-LB-7.088. The work is concerned primarily with transients and oscillations in flow caused by:

1. Operation including startup, shutdown, load rejection, and equipment failure.
2. Hull motion due to the sea state including vertical motion (heave), horizontal motion (surge and sway), and rotation about horizontal axes (roll and pitch).

B.1.1.2 Purpose

The purposes of the work described are:

1. To determine the nature and approximate magnitude of transients and oscillations in pressures, velocities, and water surfaces in the distribution system.
2. To interpret the significance of the transients and oscillations in the system design.
3. To recommend design features to reduce or modify the transients and oscillations in instances where they are unacceptable.

B.1.1.3 Scope

Three types of water distribution systems were considered. They are:

1. A completely closed conduit distribution system.
2. A decoupled conduit distribution system.
3. An open trough distribution system.

Not all of the items of operation and hull motion mentioned above were considered for each type of system. Some were not appropriate for some systems and some were beyond the scope of work at this time. Even for those considered, the nature of the flow was determined qualitatively and the magnitude approximated roughly.

A much more accurate determination of the nature and magnitude of the dynamic effects is possible, but it requires the simultaneous solution of systems of nonlinear equations. Such solutions would have to be obtained numerically by computer and are beyond the scope of work at this time. In some cases, the distribution system was represented by simpler systems in order to obtain approximate solutions. In other cases, the nonlinear terms were linearized. When absolutely necessary, a small amount of numerical solution was done by hand calculator.

B.1.2 CONDUIT DISTRIBUTION SYSTEMS

B.1.2.1 Completely Closed Conduit System

In the completely closed conduit water system, the total path from intake to discharge is a closed conduit with no openings to the atmosphere. This alternative was examined for both the cold and warm water systems, but most attention was given to the former. The long vertical cold water supply conduit makes the cold water system more crucial.

The cold water system examined first corresponds to one of the early design options in which the modules are laid out in a single line and the hull is long and narrow. When the system was reexamined later in the work, the length of horizontal pipe, from the vertical supply conduit to the pumps, was changed to correspond more closely to a later option such as Option A with a square hull. The results obtained and the conclusions reached will be similar for either configuration.

The dynamics of flow in the completely closed cold water system were examined for the following situations:

1. Pump startup
2. Vertical hull motion in Sea State 6.

The major problem in pump startup in this type of system is the maximum drop in suction head at the starting pump before sufficient water arrives from the vertical supply conduit. If the suction head falls too low, it will cause cavitation of the pump. The cavitation could continue for several minutes after starting. For feasible configuration

and geometry of the cold water system, the only parameter that can be adjusted to avoid the problem is the rate of increase of the pump speed and rate of flow for the starting pump. The slower the increase, the less the drop in suction head. For a configuration with 16 cold water pumps and a linear rate of increase in flow rate, cavitation might occur if the starting pump reaches full speed in less than 15 seconds. In starting the pumps sequentially, the suction head decreases at the pumps already running, as well as at the starting pump. Therefore, cavitation can be caused at the pumps already running, as well as the one starting.

The decrease in suction head at the pumps already running means a decrease in flow rate. This decrease in flow also means a decrease in flow at the heat exchangers already operating. Therefore, rapid starting of pumps in the completely-closed system can interfere with power generation in units already running.

To examine the dynamic effect of vertical hull motion on the flow in the completely-closed conduit system, the system was approximated by an inverted U-tube with both legs down in the water and a pump in the upper end of one leg. One leg represented the vertical cold water supply column. The other leg represented the hydraulic equivalent of the heat exchangers and vertical discharge pipes in parallel. The horizontal section between the two legs represented the hydraulic equivalent of the pipes from the supply conduit to the heat exchangers in parallel.

The heave and vertical accelerations for Sea State 6 were incorporated into a sinusoidal variation of hull elevation with time. This variation in elevation was applied to the inverted U-tube representing the system. The nonlinear equations for the fluid motion in the tube with the pump operating were linearized and solved.

The pressures and velocities resulting from Sea State 6 were estimated. At certain times in the hull motion, pressures in conduits can have a maximum value from 16 to 60 psi. Pressures of this magnitude occurred in the top of the condenser on the cold water side. For a mean velocity of 7 fps, at steady state, the mean velocity at Sea State 6 is reduced by about 4 percent to 6.7 fps. The variation in velocity at this sea state is from 6.0 to 7.4 or +10 percent.

B.1.2.2 Decoupled Closed Conduit System

In one early design, the closed conduit system for cold water is decoupled by disconnecting the conduits at the pumps. Instead of a vertical conduit connected to the pump intake, the vertical conduit is larger than the pump and extends up around it to form an open standpipe. The pump is located inside the standpipe, which serves as the forebay or suction well for the pump. The dynamics of flow in this system were examined for the following situations:

1. Pump startup
2. Vertical hull motion in Sea State 6.

The dynamics of startup in the decoupled system are the same as in the completely-closed system if water-surface elevation in the standpipe is substituted for suction head at the pump. The fall in the water level in the standpipe is equivalent to the decrease in suction head. The occurrence of cavitation and the variation of flow in the heat exchangers are similar for both systems. The problems are avoided in both systems by limiting the rate of increase in pump speed during pump starting. However, the limit is not quite the same for both. The standpipe in the decoupled system holds a larger volume of water than the pump conduit in the completely-closed system. Because of the storage, the drop in water level in the uncoupled system is less than the decrease in suction head in the completely-closed system for the same rate of increase in pump speed. A pump starting the decoupled system can be brought up to full speed in about 10 seconds.

In the decoupled system, the vertical hull motion does not produce the high pressures produced in the completely-closed system. However, the variation in flow through the heat exchanger is much larger. The rise and fall of water surface in the standpipe around the pump is of the same order as the heave of the hull. That is, ± 8 to 10 feet from the mean elevation at Sea State 6. This variation causes a similar variation in head on the pumps. This amount of change in head will change the flow rate pumped by ± 33 percent.

B.1.3 DYNAMICS OF FLOW IN THE OPEN TROUGH SYSTEM

B.1.3.1 Problems Considered

For examination of the dynamics of flow in the open trough system, Design Option A was used. The dynamics were examined for the following items:

1. Pump startup
2. Vertical hull motion (heave)
3. Horizontal hull motion (surge)
4. Rotation about horizontal axes (pitch and roll).

The problems identified in this examination were:

1. Standing waves in the open trough
2. Vertical motion of water surfaces in the trough and on top of the heat exchangers
3. Variation in pump head and rate of flow through heat exchanger.

All of the problems identified were less severe or more easily avoided than the problems associated with the two alternative systems. For this reason, among several others, the open trough system is the alternative selected. The dynamics of this alternative are discussed more fully in the next section.

B.1.3.2 Startup

In the open trough of the cold water system, the dynamic response to pump startup has two aspects analogous to aspects of the two alternative systems. These are the motion of fluid at the vicinity of the starting pump and the effect on other pumps.

In the open trough, the water surface does not drop in the same manner as water level in the standpipe or suction head in the pump conduit. As soon as the water falls at one location in the trough, water from other locations rushes to the first forming a surface wave. Because the depth

and the area of the vertical cross section of the trough are so large, the waves formed by starting one pump are small. If the largest pump anticipated in the design were brought up to speed instantaneously, the resulting surface wave in the trough would have a height of less than 1 foot. Thus, there is no limit on how fast the pumps are brought up to speed.

However, if several pumps were started at the same time and each one brought up to full speed instantaneously, difficulties could occur. Depending on the location of the pumps in the trough, the surface wave formed could be significant. Furthermore, the inertia of the vertical supply conduit limits the rate at which the flow in that conduit can increase. Therefore, instantaneous startup of several pumps simultaneously would remove a significant amount of water from the trough and lower the water level in the trough by 10 feet or more before the inflow from the supply conduit could catch up. Therefore, pumps should be started sequentially with at least 100 seconds between starting successive pumps, but each pump can be started instantaneously.

The startup of the warm water pumps presents no difficulties. The warm water troughs are connected to the open sea through openings in the hull. If these openings are large enough, water rushes into the trough quickly enough to prevent significant fall in water level in the trough. However, the pumps in one trough should be started sequentially.

B.1.3.3 Standing Waves in the Trough

The surge and pitch of the hull can produce standing shallow water waves in the trough. At certain frequencies, the waves are in resonance with the hull motion, and the amplitude increases without limit until the waves break. For the length of trough in Design Option A, the fundamental resonant frequency is about 14 seconds, while it is about 17 seconds for the longer trough in Option B. Without hydraulic model tests or detailed numerical computations, it is difficult to predict the maximum amplitude of the waves in resonance before they break. Based on values of wave steepness, the amplitude of the standing waves could be as great as 7 feet. These amplitudes can occur in relatively calm sea when the frequency of the surge and pitch are suitable for resonance.

The amplitude of the standing waves in resonance can be reduced and controlled by gated walls or bulkheads across the trough. The gates in the walls would be adjustable and controlled as part of operation. Whether two or four walls are required would have to be determined by hydraulic model studies along with other aspects of operation. By opening various gates in the walls, the trough can be detuned and the resonant waves broken up. It is estimated that gated walls can reduce the maximum amplitude of the standing waves to 2 feet.

B.1.3.4 Vertical Motion of Water Surface

The heave of the hull and vertical movement of the open trough cold water system produces vertical motion of the water in the trough relative to the hull. It also produces vertical motion of the water in the top water box of the heat exchanger relative to the top tube sheet. If there were no friction losses in the vertical supply conduit, and the horizontal area of the trough were the same as the cross section area of the conduit, the water column in the conduit would not move in space due to its inertia. The motion of the water relative to the conduit and trough would be exactly equal and opposite to the vertical hull motion. The same would be true in the heat exchangers if the horizontal area of the top water box equalled the cross-sectional area of the discharge conduit and there were no friction losses. Relative to the trough or water box the vertical motion of the water in them would have an amplitude of 21 feet in Sea State 6.

The area ratios and friction losses that actually occur reduce this amplitude significantly. In order to estimate the reduced amplitude, the equations of motion were set up for vertical flow in the supply conduit and trough and in the heat exchanger and discharge conduit. Design Option A and a constant rate of pumping were assumed, and other simplifying assumptions were made. The equations were solved numerically for a limited number of time increments using a hand calculator. From these calculations it was estimated that the amplitude of vertical motion of the water surface in the trough relative to the trough in Sea State 6 is 6 feet. That is, the water surface stays within +3 feet of the steady level for a calm sea. For Design Option B, the amplitude would be a little less. In the heat exchanger, the motion of the water surface relative to the tube sheet stays within +1 foot of the steady level for a calm sea.

If it is desired to reduce the vertical motion in the trough even further the adjustments of gates in the walls across the trough can be used. More detailed computation or hydraulic model studies would be necessary to determine how much additional reduction is possible.

In the warm water trough the heave doesn't cause vertical motion of the water in the trough relative to the trough. At the surface of the sea, the water surface goes up and down with the hull. However, there is similar motion due to roll. When one side of the hull goes up or down due to roll, the sea goes down or up with respect to the trough. The depth of water in the warm water trough decreases or increases accordingly. For Design Option A, the magnitude of the change is +3 feet, which is similar to the motion in the cold water trough. In Design Option B, the change is a little less.

B.1.3.5 Variation in Pump Head and Heat Exchanger Flow

The combination of the vertical motion in the trough and heat exchanger can change the head on the cold water pumps by +4 feet in either the cold or warm water system. This change of head causes a change in flow rate of +10 to 12 percent.

Since a constant rate of flow was assumed for the computation of vertical motion, the results are in error, but the error is conservative. When the pump head increases, the flow rate decreases, the water level on the heat exchanger falls, and the pump head starts to decrease again. The opposite happens when the pump rate decreases. Therefore, the variation in pump head will tend to decrease the vertical motion that causes the variation.

The variation in pump flow rate and the vertical motion of water in the heat exchanger and discharge conduit produce a total variation in flow rate through the heat exchanger. The conservative assumption is that the maximum change due to pump flow rate occurs with the maximum due to vertical motion. This would cause the flow rate to vary by 20 to 30 percent.

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX B .2
COMPLETELY CLOSED CONDUIT SYSTEMS

B.2. COMPLETELY CLOSED CONDUIT SYSTEMS

B.2.1 BASIC FEATURES AND SIMPLIFIED REPRESENTATION

B.2.1.1 Design Features Considered

Figure 1 shows an elevation and side view of the design of a cold water distribution system used as an example of a completely closed conduit system. Cold water passes through the vertical supply conduit and the lateral conduit to the pump conduit where the pump causes an increase in pressure. The motion through these three conduits is caused by the total head at the suction side of the pump being below mean sea level. The total head at the discharge side of the pump is above sea level and forces the flow through the pump discharge conduit, heat exchanger, and vertical discharge conduit. The complete path from cold water intake to discharge is closed conduit with no openings to the atmosphere.

Figure 2 shows the warm water system used as an example of a completely closed system. Warm water passes from the trough through the pump conduit, pump discharge conduit, heat exchanger and vertical discharge conduit. Although the conduit system is simpler, it is still completely closed from intake to discharge.

B.2.1.2 Simplified Representation

For analysis of certain problems, the completely closed conduit system can be approximated by an inverted U-tube as shown in Figure 3 for the cold water system. The longer vertical leg, 1, represents the vertical cold water supply column. The horizontal section, 2, represents the hydraulic equivalent of most of the conduits between the supply conduit and the heat exchanger, while the shorter vertical leg, 3, represents the hydraulic equivalent of all of the heat exchangers and vertical discharge columns. For convenience, the equivalent of the pumps is placed near the top of the longer leg, but it could be placed almost anywhere in the U-tube. The length of a leg is represented by L and the cross-section area by A as shown.




Fig. 1 Cold Water Distribution, Completely Closed Conduit

BY _____ DATE 26 Jul 77 SUBJECT _____
 CHKD. BY _____ DATE _____
 SHEET NO. 2-2 OF _____
 JOB NO. _____




Fig 2 Warm Water Distribution

Scale 1"=30'

BY _____ DATE 22 XII 77 SUBJECT _____
 CHKD. BY _____ DATE _____
 SHEET NO. 2-4 OF _____
 JOB NO. _____

B-16




Fig. 3 Inverted U-tube as
 B-17 Approximation of
 Completely Closed
 Condensate System

B.2.2 STARTUP

B.2.2.1 General

In startup, the system with completely closed conduits is similar to one with decoupled conduits. Before a unit is started up the surface of the water in the pump conduits and heat exchanger must be at or near mean sea level, and there must be empty space in the top of the pump discharge conduit and the heat exchanger. The unit is not closed until the space is filled with water.

B.2.2.2 Starting One Cold Water Pump With All Units Off

When all units are off, water is standing in the pump conduits with the water surface near mean sea level as just described. In the heat exchanger there is little or no water above the top tube sheet. When the pump starts, therefore, it will be pumping against less head than at normal operation. As a result, the flow rate will be greater than normal operation.

On the suction side of the starting pump the piezometric head is below mean sea level. A pressure gradient is created in the lateral conduit because the water level in other pump conduits is still at or near sea level. Therefore, water in the lateral conduit begins to flow toward the pump conduit where the pump is being started. Because of the inertia of the water in the long vertical supply conduit, that conduit does not supply water to flow in the lateral conduit. As a result, water flows from other pump conduits to the conduit of the pump being started. This causes the water in all pump conduits to be drawn down.

Figure 4 shows the pattern of water surface elevations in pump conduits and flow in the lateral conduit a short time after starting the first pump with all others off. The line drawn through water surfaces in the pump conduits is the hydraulic grade line along the lateral conduit. Where the hydraulic grade line passes over the top of the vertical supply column, the difference between the line and mean sea level is the head available to accelerate flow in the column. Therefore, the acceleration in the column cannot be significant until the water surfaces in all the

B-19




Fig. 4 Hydraulic Grade Line and Flow Shortly After Starting First Pump

BY _____ DATE _____
CHKD. BY _____ DATE _____
SUBJECT _____
SHEET NO. 2-11 OF _____
JOB NO. _____

pump conduits are low enough to have a low hydraulic grade line. By then the suction head in the conduit of the pump being started will be low enough for the pump to cavitate.

The drop in suction head and hydraulic grade line is part transient and part steady state. Right after the pump starts, most of the difference between mean sea level and the hydraulic grade line corresponds to acceleration of flow. This part is the transient. At steady state, the flow rate in the vertical column is equal to the rate of pumping, and the difference between mean sea level and the hydraulic grade line corresponds to friction losses. At some time during the transient, the hydraulic grade line drops to a level much lower than that corresponding to steady state. It is at these greatest values of draw down that cavitation is most likely. The cavitation could last several minutes.

B.2.2.3 Approximate Analysis for Starting First Pump

If the shape of the hydraulic grade line in Figure 4 can be assumed, it is possible to develop an approximate analysis of the flow resulting from starting the first pump. With such an assumption, the volume of water withdrawn from the pump columns can be related to the elevation of the hydraulic grade line above the top of the cold water supply conduit. A possible assumption is shown in Figure 5. The example represented is for the pump that experiences the greatest drop in suction head. It was selected because it is conservative and because the analysis will serve for startup of other pumps as well as the first.

The pump shown is the one furthest from the vertical supply conduit. Because it is the first pump, the friction losses in the lateral supply conduit are low enough to cause negligible slope in the hydraulic grade line even when the rate of flow at the pump is up to full value. The slope of the hydraulic grade line is caused primarily by acceleration of flow in the lateral supply conduit. Between the vertical supply conduit and the starting pump the grade line is linear with a constant slope. Rough estimates can be made for the drop in the grade line between vertical conduit and the starting pump. Based on the diameters and length of the vertical and horizontal conduits, it is estimated that the drop in the




FIG. 5. HYDRAULIC GRADE LINE FIRST PUMP STARTING IN THE COMPLETELY CLOSED SYSTEM

grade line is about 40 percent of the difference between mean sea level and the hydraulic grade line above the vertical conduit. Letting the difference be h , the drop is $0.4h$. On the opposite side of the vertical conduit, the acceleration in the lateral conduit is assumed to be negligible, and the hydraulic grade is assumed to be straight and horizontal.

With this assumed grade line, the change in average water-surface elevation in the pump conduits is $1.1dh$ when the change in h is dh . The corresponding change in total volume in the pump conduits is the product of the average change and the total horizontal area of water surface in these conduits. The water surface moves in 15 of the 16 pumps. Only the suction head changes in the starting pump. For 15 conduits, each with a diameter of 10 feet, the change in volume is $1.1(15)25\pi dh$ or $412.5\pi dh \text{ ft}^3$.

The rate of change in h is equal to the difference between the rate of flow into the pump conduits and the rate of flow out of them. The former is equal to the rate of flow, Q_1 , in the pump conduit while the latter is equal to the rate of pumped flow, Q_p . Thus the continuity equation for the sum of the pump conduits is

$$Q_1 - Q_p = 412.5\pi \frac{dh}{dt} \quad (1)$$

in which t is the time in seconds.

The difference, h , is the head available to change the flow rate, Q_1 , in the vertical conduit. Let h be positive when the hydraulic grade line is above mean sea level and Q_1 be positive when the flow in the conduit is up. For this convention, the momentum equation for flow in the conduit is

$$-h - \Delta h_s - \frac{V_1 |V_1|}{2g} - \Delta H_f = \frac{L_1}{g} \frac{dV_1}{dt} = \frac{L_1}{gA_1} \frac{dQ_1}{dt} \quad (2)$$

in which

Δh_s = static head due to difference between the water temperature inside the conduit and in the surrounding water outside

V_1 = flow velocity in the vertical supply conduit

ΔH_f = head losses due to friction

L_1 = length of vertical supply conduit

A_1 = cross section area of vertical supply conduit

g = acceleration due to gravity.

Some terms in the equation can be dropped. For the first pump starting, the flow is a small percentage of the total flow for all pumps. In addition, the water inside the vertical conduit has not been displaced by colder water. Therefore, the terms Δh_s , ΔH_f , and $V_1|V_1|/2g$ are negligible. The equation becomes

$$-h = \frac{L_1}{gA_1} \frac{dQ_1}{dt} \quad (3)$$

The continuity equation can be differentiated and substituted into the momentum equation to give

$$-h = \frac{L_1}{gA_1} \left(412.5\pi \frac{d^2h}{dt^2} + \frac{dQ_p}{dt} \right) \quad (4)$$

The derivative, dQ_p/dt , indicates the effect of the rate of starting the pump. For simplicity assume that the method of starting the pump produces a linear rate of increase in Q_p . That is

$$Q_p = qt \quad (5)$$

The differential equation then becomes

$$\frac{L_1}{gA_1} 412.5\pi \frac{d^2h}{dt^2} + h = -\frac{L_1}{gA_1} q \quad (6)$$

The coefficients in this equation can be evaluated from the following data

$$L_1 = 3000 \text{ feet}$$

$$A_1 = (50)^2\pi/4 = 625\pi \text{ft}^2$$

The equation becomes

$$61.49 \frac{d^2h}{dt^2} + h = -0.0474q \quad (7)$$

For the initial conditions

$$h = dh/dt = 0 \quad @ \quad t = 0$$

the solution is

$$h = -0.0474q(1 - \cos\frac{t}{7.842}) \quad (8)$$

The fundamental period of the motion is 49.27 seconds. If the linear increase in Q_p continues long enough the minimum value of h occurs at 24.64 seconds.

This solution is valid until the pump reaches full speed. The following table shows the values of h and dh/dt when the pump reaches full flow rate in various times.

Startup Time In Seconds	q Ft ³ /Sec ²	h (Feet)	dh/dt
1	860.000	-0.331	-0.661
5	172.000	-1.602	-0.619
10	86.000	-2.889	-0.497
15	57.330	-3.629	-0.326
20	43.000	-3.730	-0.141
25	34.400	-3.261*	
30	28.667	-2.718*	

As a first approximation, assume that Q_p is constant after the pump reaches full speed. The differential equation of h becomes

$$61.49 \frac{d^2h}{dt^2} + h = 0 \quad (9)$$

The initial conditions for this equation are the values, h_0 and dh_0/dt , at the time, t_0 , when the pump reaches full flow rate. These conditions are the values in the above table. The solution of the equation is

* Minimum h occurs when $t/7.842 = \pi$ or $t = 24.64$ seconds.

$$h = 7.842 \frac{dh_0}{dt} \sin \frac{(t-t_0)}{7.842} + h_0 \cos \frac{(t-t_0)}{7.842} \quad (10)$$

The lowest point occurs when dh/dt is zero, that is

$$\frac{dh}{dt} = \frac{dh_0}{dt} \cos \frac{(t-t_0)}{7.842} - \frac{h_0}{7.842} \sin \frac{(t-t_0)}{7.842} = 0 \quad (11)$$

$$\tan \frac{(t-t_0)}{7.842} = \frac{7.842}{h_0} \frac{dh_0}{dt} \quad (12)$$

The following table gives the minimum values of h based on h_0 and dh_0/dt from the table above.

Startup Time t_0 (seconds)	$\frac{7.842}{h_0} \frac{dh_0}{dt}$	Time to Minimum h		Minimum h (feet)
		$t-t_0$ (seconds)	t (seconds)	
1	15.684	11.819	12.82	-5.190
5	3.030	9.818	14.82	-5.110
10	1.349	7.316	17.32	-4.851
15	0.704	4.813	19.81	-4.439
20	0.296	2.260	22.26	-3.890
25			24.64	-3.261
30			24.64	-2.781

The minimum h is the maximum drop in suction head at the starting pump. This approximate analysis shows that the maximum does not decrease significantly until the startup time, t_0 , approaches half of the fundamental period of the motion. The fundamental period decreases with the cross section area of the pump conduits. Thus, the pumps can be started faster with smaller conduits than with larger ones.

This result is true only for the first one or two pumps. For these, the value of V_1 is small and the terms $V_1^2/2g$ and $\Delta H_{f,1}$ are negligible. Without these terms in the equation, the amplitude of the motion is independent of the horizontal cross section area of storage. A larger area slows down the response of the flow in the vertical conduit without any decrease of the amplitude.

If the diameter of the pump conduits is reduced from 10 feet to 8 feet the fundamental period is reduced to 39.4 seconds. A startup time of 20 seconds would produce the minimum values of maximum drop in suction. Since there is a limit to how small the column can be made, it is unlikely that the startup time can be less than 15 seconds for safe values of minimum h . However, smaller conduits are not beneficial for starting other pumps after the first one or two. As the values of $V_1^2/2g$ and $\Delta H_{f,1}$ become significant, larger conduits reduce the minimum value of h . Therefore, it is better to plan to start the first pump or two more slowly and let them take 25 or 30 seconds to reach full flow rate.

B.2.2.4 Starting One Cold Water Pump With Other Units On

Starting a pump with others already running is similar to starting the first pump. Just before this latest pump starts the water levels or suction heads in the pump conduits all lie on some hydraulic grade line corresponding to flow to the pumps already running. If only one pump is already running, the grade line would look something like that in Figure 4 or 5. When the latest pump starts, its suction head is lowered until the hydraulic grade line is altered enough to cause water to flow to the pump. The inertia of the flow in the vertical cold water conduit causes the flow to respond slowly to the increase corresponding to the latest pump. Therefore, flow to the latest pump comes from reduction in flow to the pumps already running until the flow in the vertical column increases.

As was shown in Figure 4, the whole grade line must be lowered to accelerate flow in the vertical conduit. Thus startup of the latest pump lowers its own suction head and the suction head at all pumps already running. Cavitation can be caused at the latest pump and may be caused at some of the running pumps. Also, the flow rate of all of the running pumps is affected.

The situation changes as the number of pumps already running is increased. The location of the grade line before the latest pump starts is lower when more pumps are running. Therefore, the suction head is already lower at the beginning of the transient caused by starting the latest pump. On the other hand, the terms, $V_1^2/2g$ and $\Delta H_{f,1}$, in the

momentum are significant and reduce the amplitude of the transient. The suction head at the lowest point in the transient is not as far below the value at the beginning of the transient. Also, with less storage effects in the pump conduits, the period of the transient is shorter.

For this stage of the work, it is not feasible to obtain numerical estimates of these changes. The analysis of starting pumps after the first cannot be approximated as easily as for the first pumps. The pump conduits with pumps already running do not provide simple storage. The analysis of the change in flow at these pumps involves the characteristic curves of the pump and the inertia of the pump and motor as well as the momentum of flow in the conduits.

Short of adequate computation, it appears that the reduction in amplitude and period of the transient is a larger effect than the lower hydraulic grade line at the beginning of the transient. After the first one or two pumps, therefore, the time for each pump to reach full flow rate can probably be reduced to 15 seconds. At most, it will be 25 or 30 seconds.

B.2.3 VERTICAL HULL MOTION

B.2.3.1 Sinusoidal Approximation of Hull Motion

Assume that the elevation, z , of the hull above mean sea level can be represented by

$$z = z^* \sin \Omega t \quad (13)$$

in which

z^* = maximum value of z

Ω = frequency in radians per second

By differentiation the acceleration of the hull is

$$\frac{d^2 z}{dt^2} = -\Omega^2 z^* \sin \Omega t \quad (14)$$

The values of Ω and z^* can be estimated for Sea State 6. The heave of 21.4 feet can be represented by $2z^*$. That is

$$z^* = 10.7 \text{ feet}$$

The maximum acceleration is 0.05g. Therefore

$$\Omega^2 z^* = 0.05g$$

$$\Omega = \left[\frac{0.05(32.2)}{10.7} \right]^{1/2} = 0.388 \text{ radians/sec}$$

The frequency in cycles per second is $0.39/2\pi$ or 0.062 and the period is 16.11 seconds. The equation for z is

$$z = 10.7 \sin 0.388 t$$

B.2.3.2 Equations for Simplified Representation

The simplified representation of the completely closed system as an inverted U-tube is described in Article 2.1b. This simplification is used to estimate the effect of vertical hull motion on the flow in the completely closed cold water system.

To set up the equations of motion for the flow the following variables and terms are needed:

h_0 = hydraulic or piezometric head just outside of entrance to the vertical cold water supply conduit

= depth of entrance of column below mean sea level (negative value because below mean sea level)

$\Delta H_{u,1}$ = head loss at entrance to vertical supply conduit

γ = unit weight of water in the conduits

$\Delta H_{f,1}$ = friction loss in vertical supply conduit

Δp = increase in pressure from suction to discharge side of pump

$\Delta H_{f,2}$ = friction loss in lateral supply and pump conduits

V_2 = velocity in the equivalent to lateral supply and pump conduits

L_2 = length of the equivalent to lateral

V_3 = velocity in the equivalent of condenser and cold water discharge

L_3 = length of condenser and cold water discharge

$\Delta H_{f,3}$ = friction loss in condenser and cold water discharge

$\Delta H_{d,3}$ = head loss and exit loss at outlet of cold water discharge

$\Delta h_{s,2}$ = static head in vertical cold water discharge conduit

Other variables have already been defined in preceding articles.

The momentum equation for the equivalent U-tube is

$$\begin{aligned} \Delta H_{u,1} + \Delta H_{f,1} - \frac{\Delta P}{\gamma} + \Delta h_{s,1} + \frac{L_1}{g} \frac{dV_1}{dt} + \Delta H_{f,2} \\ + \frac{L_2}{g} \frac{dV_2}{dt} + \Delta H_{f,3} - \Delta h_{s,3} + \Delta H_{d,3} + \frac{L_3}{g} \frac{dV_3}{dt} = 0 \end{aligned} \quad (15)$$

The losses are given by

$$\begin{aligned} \Delta H_{u,1} &= C_1 V_1^2 / 2g \\ \Delta H_{d,3} &= (1+C_3) V_3^2 / 2g \\ \Delta H_{f,1} &= \frac{f_1 L_1}{2gD_1} (V_1 - \frac{dz}{dt})^2 \\ \Delta H_{f,2} &= \frac{f_2 L_2}{2gD_2} V_2^2 \\ \Delta H_{f,3} &= \frac{f_3 L_3}{2gD_3} (V_3 + \frac{dz}{dt})^2 \end{aligned} \quad (16)$$

In the expressions for friction loss, f is the friction factor. In the expressions for entrance and exit losses, assume

$$C_1 = C_2 = 0$$

For the given design, the static heads are approximated by

$$\Delta h_{s,1} = 3.0$$

$$\Delta h_{s,2} = 0$$

The continuity equations for the equivalent U-tube are:

$$(V_1 - \frac{dz}{dt})A_1 = V_2 A_2 = (V_3 + \frac{dz}{dt})A_3 \quad (17)$$

These lead to

$$V_2 = \frac{A_1}{A_2} V_1 - \frac{A_1}{A_2} \frac{dz}{dt} \quad (18)$$

$$V_3 = \frac{A_1}{A_3} V_1 - \left(\frac{A_1 + A_3}{A_3} \right) \frac{dz}{dt} \quad (19)$$

Substitution of the continuity equation into the momentum equation leads to

$$\begin{aligned}
 & \Delta H_{f,1} + \Delta H_{f,2} + \Delta H_{f,3} + 3 - \Delta p/\gamma \\
 & + \left(\frac{A_1}{A_3}\right)^2 \frac{V_1^2}{2g} + \left(\frac{L_1}{g} + \frac{A_1}{A_2} \frac{L_2}{g} + \frac{A_1}{A_3} \frac{L_2}{g}\right) \frac{dV_1}{dt} \\
 & = \left[\frac{A_1}{A_2} \frac{L_2}{g} + \left(\frac{A_1 + A_3}{A_3}\right) \frac{L_3}{g}\right] \frac{d^2z}{dt^2} + \frac{1}{g} \frac{A_1}{A_3} \left(\frac{A_1 + A_3}{A_3}\right) V_1 \frac{dz}{dt} \\
 & \quad - \frac{1}{2g} \left(\frac{A_1 + A_3}{A_3}\right)^2 \left(\frac{dz}{dt}\right)^2 \tag{20}
 \end{aligned}$$

The friction losses are given by

$$\Delta H_{f,1} + \Delta H_{f,2} + \Delta H_{f,3} = \left[\frac{f_1 L_1}{2gD_1} + \left(\frac{A_1}{A_2}\right)^2 \frac{f_2 L_2}{2gD_2} + \left(\frac{A_1}{A_3}\right)^2 \frac{f_3 L_3}{2gD_3} \right] \left(V_1 - \frac{dz}{dt}\right) \tag{21}$$

In order to provide a simple approximation, assume that the total area of conduits in parallel, equivalent to conduits 2 and 3 of the U-tube, is each equal to the area of conduit 1. That is

$$A_1 = A_2 = A_3 \tag{22}$$

With this approximation the equation is simplified to

$$\begin{aligned}
 (1 + \Sigma \frac{fL}{D}) \frac{V_1^2}{2g} + 3 + \frac{1}{g} \Sigma L \frac{dV_1}{dt} &= \frac{\Delta p}{\gamma} + \frac{V_1}{g} (2 + \Sigma \frac{fL}{D}) \frac{dz}{dt} - \frac{1}{2g} (4 + \Sigma \frac{fL}{D}) \left(\frac{dz}{dt}\right)^2 \\
 &+ \frac{1}{g} (L_2 + 2L_3) \frac{d^2z}{dt^2} \tag{23}
 \end{aligned}$$

in which

$$\Sigma \frac{fL}{D} = \frac{f_1 L_1}{D_1} + \frac{f_2 L_2}{D_2} + \frac{f_3 L_3}{D_3} \tag{24}$$

and

$$\Sigma L = L_1 + L_2 + L_3 \tag{25}$$

To linearize the equation, the term V_1^2 is replaced by $|V_1|V_1$ with $|V_1|$ equal to a constant. The constant absolute value was made equal to 7 ft/sec which is the steady value for no vertical hull motion. This value is also used in the coefficient of dz/dt .

The friction losses are based on the average diameters and lengths of the conduits. The data used are given in the following table.

Conduit	L Feet	D Feet	f
1	3000	50	0.010
2	150	20	0.013
3	200	20	

In order to make the head loss through the heat exchanger and discharge tube equal to the design value for no vertical hull motion, it is necessary to have

$$\frac{f_3 L_3}{D_3} = 10.803$$

With these values

$$\Sigma \frac{fL}{D} = 11.5$$

Additional friction loss was added to this value to allow for bends and changes in diameter not included in the value of $f_3 L_3 / D_3$. With the additional losses

$$\Sigma \frac{fL}{D} = 13.6$$

The value of ΣL is obtained from the lengths in the table for friction factors. That is

$$\Sigma L = 3350 \text{ feet}$$

The derivatives of hull motion are given by

$$\frac{dz}{dt} = 4.152 \cos 0.388t \quad (26)$$

$$\frac{d^2z}{dt^2} = -1.61 \sin 0.388t$$

$$\left(\frac{dz}{dt}\right)^2 = 8.62 (1 + \cos 0.776t)$$

With the preceding numerical values and assumptions, the final linearized equation becomes

$$104.04 \frac{dV_1}{dt} + 1.59 V_1 = \frac{\Delta p}{62.4} - 27.50 \sin 0.388t + 14.08 \cos 0.388t - 2.36 \cos 0.776t - 5.36 \quad (27)$$

2.3.3 Linear Approximation For Pump Curve

To obtain an expression for $\Delta p/\gamma$, it is assumed that the pump curve is linear in the range of values of Q_1 anticipated in the vertical motion. The linear expression for the curve is

$$\frac{\Delta p}{\gamma} = h_0 - (Q_1 - \bar{Q}_1) \frac{dh}{dQ_1} \quad (28)$$

The value of \bar{Q}_1 corresponds to a value of 7 ft/sec for $|V_1|$. This expression can also be written

$$\frac{\Delta p}{\gamma} = h_0 - (V_1 - 7) \frac{dh}{dV_1} \quad (29)$$

From the pump curves supplied by TRW

$$\frac{\Delta p}{\gamma} = 14.11 - 7.42 (V_1 - 7) \quad (30)$$

When this expression is substituted in the momentum equation, the resulting equation is

$$104.04 \frac{dV_1}{dt} + 9.01 V_1 = 60.69 - 27.50 \sin 0.388t + 14.08 \cos 0.388t - 2.36 \cos 0.776t \quad (31)$$

or

$$\begin{aligned} \frac{dV_1}{dt} + 0.0866 V_1 &= 0.584 - 0.264 \sin 0.388t \\ &+ 0.135 \cos 0.388t \\ &- 0.0227 \cos 0.776t \end{aligned} \quad (32)$$

B.2.3.4 Variation in Flow Rate

This equation can be solved directly for V_1 . It is in the form

$$\frac{dV_1}{dt} + PV_1 = Q(t) \quad (33)$$

The solution

$$V_1(t) = Ce^{-\int P dt} + e^{-\int P dt} \int e^{\int P dt} Q(t) dt \quad (34)$$

To evaluate the solution

$$\int P dt = 0.866t$$

$$\int e^{0.866t} Q(t) dt = 6.738 e^{0.866t} \quad (35)$$

$$- 0.639 e^{0.866t} (0.2232 \sin 0.388t - \cos 0.388t)$$

$$+ 0.332 e^{0.0866t} (\sin 0.388t + 0.2232 \cos 0.388t)$$

$$- 0.0289 e^{0.866t} (0.112 \cos 0.776t + \sin 0.776t)$$

$$V_1(t) = Ce^{-0.0866t} + 6.738 + 0.189 \sin 0.388t$$

$$+ 0.713 \cos 0.388t - 0.0289 \sin 0.776t \quad (36)$$

$$- 0.00324 \cos 0.776t$$

If

$$V_1 = 7 @ t = 0$$

then

$$7 = C + 6.738 + 0.713 - 0.00324$$

$$C = 7 - 7.448 = -0.448$$

Therefore,

$$V_1(t) = -0.448 e^{-0.0866t} + 6.738$$

$$+ 0.189 \sin 0.388t + 0.713 \cos 0.388t \quad (37)$$

$$- 0.0289 \sin 0.776t - 0.00324 \cos 0.776t$$

To find the range of velocity variation at steady state, try various points in the cycle of hull motion for $t = \infty$.

$$\sin 0.388t = 1:$$

$$V_1 = 6.738 + 0.189 + 0.00324 = 6.93 \text{ ft/sec}$$

$$\cos 0.388t = -1:$$

$$V_1 = 6.738 - 0.713 + 0.00324 = 6.03 \text{ ft/sec}$$

$$\sin 0.388t = -1:$$

$$V_1 = 6.738 - 0.189 + 0.00324 = 6.55 \text{ ft/sec}$$

$$\cos 0.388t = 1:$$

$$V = 6.738 + 0.713 + 0.00324 = 7.454 \text{ ft/sec}$$

The range of velocity is approximately $7.454 - 6.03 = 1.42 \text{ ft/sec}$ with a mean value of 6.74 ft/sec . This variation is $+0.71/6.74 = +10.5 \text{ percent}$. It is also the variation in flow rate.

B.2.3.5 Maximum Pressures

The pressure at the top of the longer leg of the inverted U-tube corresponds to the pressure at the top of the vertical supply conduit, while the pressure at the top of the shorter leg corresponds to the pressure in the top water box of the heat exchanger. These pressures vary during the cycle of vertical hull motion as required to accelerate or decelerate the flow in the conduits. They are related to dV_1/dt by the momentum equation.

From the solution $V(t)$ in the preceding section,

$$\begin{aligned} \frac{dV_1}{dt} = & 0.040 e^{-0.0866t} + 0.073\cos 0.388t \\ & - 0.277\sin 0.388t - 0.022\cos 0.776t \\ & + 0.00251\sin 0.776t \end{aligned} \quad (38)$$

The range of values of this derivation can be determined by evaluating it for different times during the cycle of hull motion. For steady state the exponential term is zero.

$$\cos 0.388t = 1:$$

$$\frac{dV_1}{dt} = 0.073 - 0.022 = 0.051$$

$$\sin 0.388t = 1:$$

$$\frac{dV_1}{dt} = -0.277 - 0.022 = -0.299$$

$$\cos 0.388t = -1$$

$$\frac{dV_1}{dt} = -0.073 - 0.022 = -0.095$$

$$\sin 0.388t = -1$$

$$\frac{dV_1}{dt} = 0.277 + 0.022 = 0.299$$

At the top of the vertical supply conduit, the head associated with the acceleration is given by

$$h + z = - \frac{3000}{32.2} \frac{dV_1}{dt}$$

At the maximum values of acceleration

$$z = 10.7 \text{ ft};$$

$$h = 27.86 - 10.7 = 17.16 \text{ ft}$$

$$p = 7.44 \text{ psi}$$

$$z = -10.7 \text{ ft}$$

$$h = -27.86 + 10.7 = -17.16 \text{ ft}$$

$$p = -7.44 \text{ psi}$$

These accelerations and associated pressures are based on the assumption that

$$A_1 = A_2 = A_3$$

If A_2 and A_3 are smaller than A_1 , the accelerations and pressures are increased in magnitude. The pressures could be as high as 10 psi or as low as -10 psi.

The pressures due to acceleration, must be added to the pressure created by the pumps for overcoming friction. At some locations between the pump discharge and the heat exchanger, this pressure is 4 to 6 psi. At the top of the vertical hull motion the pressures from acceleration and pumping add total from 14 to 16 psi. At the bottom of the motion, the sum of the two is negative with values between -6 and -4 psi.

These pressures all assume no malfunction of the pumps or closure of valves that might restrict the flow in conduits. Suppose that it is attempted to operate valves and pump speed to maintain a constant flow rate with respect to the conduits. The acceleration of the flow would equal the acceleration of the hull. The pressures associated with these accelerations would be of the order of 60 psi.

The actual pressures lie somewhere between the ultimate value of 60 psi and the value of 14 to 16 psi given above. To estimate them more accurately, it is necessary to consider the control and inertia of the pump and motor.

APPENDIX B.3
DECOUPLED CLOSED CONDUIT SYSTEM

B.3. DECOUPLED CLOSED CONDUIT SYSTEM

B.3.1 BASIC FEATURES

In one early design, the closed conduit system for cold water supply is decoupled by disconnecting the conduits at the pumps. The design is shown in Figure 6. Instead of a vertical conduit connected to the pump intake the vertical conduit is larger than the pump and extends up around it to form an open standpipe. The pump is located inside the standpipe, which serves as the forebay or suction well for the pump. All design features except for the open standpipe are the same as shown in Figure 1 for the completely closed system.

B.3.2 DYNAMICS OF FLOW


B.3.2.1 Pump Startup

The dynamics of conduit flow resulting from starting pumps is similar to that described in Subsection 2.2 for the completely closed system. For the decoupled system, the hydraulic grade line in Figure 4 is always defined by the water surface in the standpipes instead of a combination of pump suction head at the pumps running and water surface at those not running. The flow to the latest starting pump comes from storage in the standpipes until the flow rate in the vertical supply column is increased to provide for the latest pump.

The approximations and equations used for the completely closed system in Subsection 2.2 can be used for very rough estimates. As shown in that subsection, the drawdown for starting the first one or two pumps is not decreased significantly unless the time for the pump to reach full flow rate is approximately $1/2$ the fundamental period of the motion.

In that subsection it was also shown that the fundamental period depends upon the horizontal cross-section area of the water stored in the pump conduits. For the decoupled system, the period depends upon the horizontal cross-section of the annular space between the pump casing and the standpipe.

Mean Sea Level and Elevation
of Top Tube Sheet



Note: Design similar to Fig. 1 except for
pump conduits replaced by open
standpipes

Elevation

Side
View

Fig. 6 Cold Water Distribution
Decoupled Conduit

Scale 1"=50'

B-39

Depending upon the design, the area of the annular space can be less or greater than the cross-section area of the pump conduits in the completely closed system. If the diameters of the pump casing and standpipe are 9 and 13 feet, respectively, the horizontal area of 15 annular spaces is 330π feet. This is less than the total horizontal cross-section area pump conduits used for the computations in Article 2.2c. Therefore, the fundamental period is shorter for the decoupled system and the first pump can be started more quickly.

For pumps after the first one or two, larger standpipes permit more rapid pump start up. If the diameters of the pump casing and standpipe are 9 and 15 feet, respectively, the horizontal area of 15 annular spaces is $540 \pi \text{ ft}^2$. This is significantly more than the total horizontal cross-sectional area of pump conduits in the computations for the completely closed system. Furthermore, there is a storage effect in all 15 stand pipes, regardless of how many pumps are running. Without detailed computations, it appears that most of the pumps in the decoupled system can be brought up to full flow rate in about 10 seconds.

B.3.2.2 Vertical Hull Motion

In the decoupled system, the vertical hull motion does not produce the high pressures produced in the completely closed system. Instead, the motion causes movement of the water surface in the stand pipes around the pumps. The rise and fall of the water surface is of the same order as the motion of the hull. At sea state 6 the change is ± 8 to 10 feet from the mean elevation.

This variation in elevation of the water surface is a change in the head on the pumps. A change of this magnitude will cause the rate of flow pumped to change by $\pm 33\%$.

APPENDIX B.4
OPEN TROUGH SYSTEM

B.4. OPEN TROUGH SYSTEM

B.4.1 BASIC FEATURES

The open trough system for supply and distribution of cold water is shown in Figure 7. The dimensions shown there are the ones used for preliminary estimates. The system has free water surface at two locations. One is the open trough, and the other is the water box at the top of the condenser.

The warm-water system is similar to that shown in Figure 2 with one difference; the water box at the top of the evaporator has a free surface.

B.4.2 PUMP STARTUP

B.4.2.1 Cold Water System

When a pump is started in the open trough, there is a tendency for the water surface to have the same shape as the hydraulic grade line in Figure 4 for roughly similar reasons. As soon as the water surface falls at the starting pump, however, water from the rest of the trough rushes toward the pump forming a surface wave. The height and speed of the wave can be estimated.


The estimate was made for a case of starting one large pump or several small pumps located near enough to each other to be considered a single point. The flow rate at the starting pumps increased to 3700 ft³/sec instantaneously. The flow resulting from starting the pumps was treated as a shallow water wave.

For water starting with no velocity and a depth of 80 feet, the wave celerity w corresponding to 3700 ft³/sec is given by

$$-2(80g)^{1/2} = V + 2w \quad (40)$$

The velocity V and depth Z at the wave are related by

$$60VZ = 3700 \quad (41)$$



PLAN

Note

Pumps, Heat Exchanger
and Discharge Conduit
Similar to Fig. 1 & 6

Water Surface for
Calm Sea, No Pumping




Fig. 7. Open Trough Cold Water Distribution

The depth Z is related to the wave celerity w by

$$w = \sqrt{gZ} \quad (42)$$

These 3 equations are combined to form the following equation

$$\frac{1824.67}{w^2} + 2w = 101.51 \quad (43)$$

By trial and error the solution is

$$w = 50.4 \text{ ft/sec}$$

$$Z = 78.87 \text{ ft}$$

$$V = 0.782 \text{ ft/sec}$$

Therefore the wave is a drawdown or decrease in depth equal to 1.13 feet moving away from the pump at a speed of 49.6 ft/sec.

This case is more extreme than any start up anticipated in an actual design. The flow rate for a single pump will be less than 3700 ft/sec. For a pump that will be selected for design, the wave height will be less than 1 foot.

In addition to surface waves, pump start up can also cause a drop in the water surface in the whole trough. As described for the previous system, the inertia of the water in the vertical supply conduit prevents the flow rate in that conduit from responding immediately to the starting pump. The water for the starting pump comes from the trough, and the whole water surface in the trough falls below the elevation at which it was located before the pump started. Because of the large horizontal area of the trough, the response of the flow in the conduit is slow. The period of the transient motion in the conduit is 204 seconds.

If more than one pump is started within $1/2$ of the period, the effect will be the same as one pump with a flow rate equal to the sum of flow rates of all of the pumps started. After starting one pump, the

next should not be started until at least 100 seconds later. However, the time between successive pump starts should not be multiples of the period of 204 seconds. Although there should be sufficient time between successive pump starts, it is not necessary to start up each individual pump slowly. Each pump can be brought up to full flow rate as quickly as desired.

B.4.2.2 Warm Water System

Start-up of the warm water trough presents no difficulties. The warm-water troughs are connected to the open sea through openings in the hull. If these openings are large enough, water enters the trough quickly enough to prevent significant fall in water level in the trough. However, the pumps in any single trough should be started sequentially.

B.4.3 STANDING WAVES IN THE TROUGH

The surge and pitch of the hull can produce standing shallow water waves in the trough. The period of these waves can be determined from the wave celerity given in Article 4.2.1. The period of the shallow water trough is twice the length of time required for the wave to travel the length of the trough. With a length of 370 feet and a celerity of 50.4 ft/sec., the period is 14.7 seconds.

This period is in the range of periods that can be expected for rotation and horizontal motion of the hull. For these periods, the standing waves are in resonance with the hull motion. Even though the sea which is creating the hull motion is relatively calm, the standing waves in the hull at resonance will increase in height until they break. Without hydraulic model tests or detailed numerical computations, it is difficult to predict the maximum height of the waves before they break. Based on values of wave steepness at breaking, the height could be as great as 7 feet.

The amplitude of the standing waves can be reduced by building walls or bulkheads across the trough. The walls would have openings covered by gates so that the total area of opening in each wall can be controlled.

By varying the opening according to the sea state, the natural frequency of the waves in the trough can be kept different from the hull motion and resonance can be avoided. Essentially the trough is detuned.

The design and operation of the gated walls would have to be determined from hydraulic model studies. It is estimated that such walls could limit the maximum amplitude of the standing waves to 2 feet.

B.4.4 VERTICAL MOTION OF WATER SURFACE

B.4.4.1 Equations of Motion

The vertical motion of the hull causes unsteady flow on the cold and warm water systems. This unsteady flow causes the water surfaces in the troughs and in the top water boxes of the heat exchangers to move relative to the troughs and boxes. If the horizontal area of the cold water trough were equal to the cross-section area of the vertical cold water conduit, and if there were no friction losses, the water column in the conduit would not move relative to fixed space because of the inertia of the column. The same could be said of the water columns in the vertical discharge conduits for the heat exchangers. For such a situation, the water surface in the cold water trough and water boxes would remain at mean sea level and appear to move up and down in the trough and boxes. The amplitude of this relative motion would equal the heave of the hull.

The relative motion affects the flow ratio pumped through the heat exchangers. Since the pumps are fixed with respect to the hull, the water surfaces move relative to the pumps and changes the head on the pumps. As a result, the rate of flow pumped to the heat exchangers changes.

The equations for the relative motion are similar to the momentum and continuity equations used in previous sections. The continuity equation for the vertical conduit and open trough or vertical conduit and heat exchanger is

$$A\left(V - \frac{dz}{dt}\right) - \sum Q_p = a \frac{dZ}{dt} \quad (44)$$

Most of the symbols of this equation have been defined previously. The variable a is now the horizontal area of the water surface in the open trough or in the water box at the top of the heat exchanger. The sum of flow for all pumps operating is $\sum Q_p$. The velocity V is the value for the vertical column being considered. The momentum equation is

$$-\frac{L}{g} \frac{dV}{dt} = z + Z + \Delta h_s + \frac{V^2}{2g} + \frac{fL}{2gD} \left(V - \frac{dz}{dt} \right)^2 \quad (45)$$

In this equation the V^2 is replaced by $|V|V$ and $(V - dz/dt)^2$ by $|V - dz/dt| (V - dz/dt)$ as was done previously.

B.4.4.2 Numerical Solution

In previous sections, similar equations were linearized by assuming that the absolute values in the momentum equation are constant and equal to average values. A similar approach was used for the open trough system, but the results were not reassuring. Therefore, it was decided to do a limited amount of numerical computation.

The equations of motion were written in terms of increments ΔV , ΔZ , and Δt . They become

$$\Delta Z = \left[\frac{A}{a} \left(V - \frac{dz}{dt} \right) - \frac{\sum Q_p}{a} \right] \Delta t \quad (46)$$

$$\Delta V = -\frac{g}{L} \left[z + (Z + \Delta h_s) + \frac{V|V|}{2g} + \frac{fL}{2gD} \left(V - \frac{dz}{dt} \right) |V - \frac{dz}{dt}| \right] \Delta t \quad (47)$$

The values of ΔZ and ΔV were computed for a Δt of 2 seconds using the values of V and dz/dt at the beginning of the increment Δt . The computations began with initial values of V and Z , and the values of ΔV and ΔZ were added at the end of each time increment. In the continuity equation, the value of Q_p remained constant. The computation was

carried out in a combination of manual calculations and automatic data processing with a programmable hand calculator.

For the open trough, the initial value of V and Z were 7 fps and 77 feet, respectively. The hull motion was represented by the sine wave derived above for Sea State 6. The values of f , L and D for the vertical cold water conduit are the same as those used in Subsection 2.3.

For the heat exchanger and vertical discharge column, the initial value of V was -5.41 ft/sec. The initial surface elevation h of the water above the top tube sheet was 8.22 feet above mean sea level. This elevation is equal to the head losses for steady flow through the heat exchanger when there is no hull motion and the velocity in the discharge column is -5.41 ft/sec. The value of $fL/2gD$ was 0.265 which corresponds to a head loss of 8.22 feet.

The results of the computations are listed in the following tables. For the open trough the values of V and Z are given, while the values of V and h are given for the heat exchanger. In order to indicate the water velocity relative to the heat exchanger tubes, the values of $V - dz/dt$ are also given for the heat exchanger.

B.4.4.3 Results

The values of h and Z are plotted in Figure 8. Also shown in the figure are the values of Δh_s in the trough, ΔH_f in the vertical cold-water supply conduit; and the elevation h of the water surface in the top of the heat exchanger when there is no vertical hull motion.


The computations could not be carried far enough to show a complete cycle of the depth in the trough. The fundamental period of the transient motion in the vertical supply conduit is 204 seconds. The computation might have to be continued for 612 seconds or more before the curve for Z begins to repeat. However, it can be assumed that in the first three quarters of a period, the maximum difference between the depth in the trough and the depth that would occur in a calm sea is an indication of one half of the maximum amplitude of the change in depth.


VELOCITY IN VERTICAL SUPPLY CONDUIT AND DEPTH
IN OPEN TROUGH BY NUMERICAL COMPUTATION


t sec	V ft/sec	Z-77 ft	t sec	V ft/sec	Z-77 ft	t sec	V ft/sec	Z-77 ft
0	7.0	0	56	6.08	-2.53	112	7.53	-2.29
2	6.98	-0.72	58	6.07	-1.95	114	7.63	-2.89
4	6.82	-1.24	60	6.21	-1.50	116	7.56	-3.42
6	6.59	-1.27	62	6.45	-1.51	118	7.39	-3.54
8	6.42	-0.82	64	6.65	-2.02	120	7.23	-3.12
10	6.40	-0.17	66	6.72	-2.80	122	7.18	-2.37
12	6.53	0.27	68	6.63	-3.44	124	7.29	-1.66
14	6.64	0.74	70	6.46	-3.63	126	7.51	-1.36
16	6.78	0.78	72	6.32	-3.30	128	7.72	-1.57
18	6.77	0.60	74	6.31	-2.68	130	7.81	-2.13
20	6.61	-0.12	76	6.46	-2.18	132	7.73	-2.64
22	6.38	-1.25	78	6.71	-2.11	134	7.55	-2.76
24	6.21	-0.86	80	6.92	-2.55	136	7.36	-2.34
26	6.18	-0.25	82	7.01	-3.27	138	7.29	-1.58
28	6.30	0.17	84	6.94	-3.88	140	7.37	-0.84
30	6.51	0.12	86	6.78	-4.05	142	7.57	-0.49
32	6.66	-0.43	88	6.64	-3.69	144	7.76	-0.67
34	6.51	-1.05	90	6.62	-3.02	146	7.84	-1.20
36	6.37	-1.69	92	6.77	-2.44	148	7.76	-1.72
38	6.15	-1.86	94	7.02	-2.29	150	7.55	-1.86
40	5.99	-1.53	96	7.25	-2.65	152	7.35	-1.48
42	5.96	-0.97	98	7.34	-3.31	154	7.24	-0.73
44	6.10	-0.56	100	7.28	-3.87	156	7.30	0.02
46	6.32	-0.67	102	7.11	-4.01	158	7.19	-0.60
48	6.49	-1.18	104	6.97	-3.62	160	6.97	-0.84
50	6.53	-1.99	106	6.94	-2.90	162	7.06	-1.50
52	6.42	-2.65	108	7.07	-2.25	164	7.00	-2.17
54	6.23	-2.84	110	7.31	-2.01	166	6.82	-2.48

VELOCITY IN VERTICAL DISCHARGE CONDUIT AND WATER
SURFACE ELEVATION IN HEAT EXCHANGER

t sec	V ft/sec	$V - \frac{dz}{dt}$ ft/sec	h ft	t sec	V ft/sec	$V - \frac{dz}{dt}$ ft/sec	h ft
0	-5.41	-9.58	8.22	28	-5.59	-5.28	7.61
1	-2.74	-6.60	6.86	29	-3.83	-5.12	7.65
2	-2.62	-5.59	6.47	30	-2.27	-4.97	7.74
3	-3.52	-5.15	6.41	31	-1.13	-4.84	7.89
4	-4.98	-5.02	6.50	32	-0.61	-4.77	8.07
5	-6.61	-5.06	6.62	33	-0.79	-4.77	8.28
6	-8.07	-5.17	6.74	34	-1.67	-4.87	8.49
7	-9.09	-5.27	6.82	35	-3.11	-5.07	8.67
8	-9.49	-5.31	6.87	36	-4.91	-5.32	8.78
9	-9.20	-5.31	6.90	37	-6.77	-5.57	8.81
10	-8.28	-5.25	6.93	38	-8.40	-5.77	8.76
11	-6.86	-5.15	6.99	39	-9.55	-5.89	8.65
12	-5.16	-5.03	7.07	40	-10.06	-5.91	8.49
13	-3.43	-4.89	7.20	41	-9.87	-5.86	8.33
14	-1.93	-4.76	7.37	42	-9.02	-5.75	8.18
15	-0.87	-4.66	7.58	43	-7.65	-5.61	8.07
16	-0.44	-4.61	7.82	44	-5.95	-5.46	8.00
17	-0.72	-4.64	8.09	45	-4.17	-5.29	7.99
18	-1.68	-4.77	8.34	46	-2.56	-5.12	8.03
19	-3.20	-5.00	8.54	47	-1.36	-4.98	8.12
20	-5.04	-5.27	8.68	48	-0.75	-4.88	8.27
21	-6.91	-5.54	8.73	49	-0.83	-4.87	8.44
22	-8.52	-7.14	8.69	50	-1.62	-4.94	8.62
23	-9.18	-6.41	8.12	51	-3.00	-5.11	8.77
24	-9.81	-5.65	7.80	52	-4.76	-5.35	8.87
25	-9.58	-5.62	7.72	53	-6.62	-5.59	8.89
26	-8.69	-5.54	7.65	54	-8.28	-5.79	8.83
27	-7.29	-5.42	7.61	55	-9.48		8.71







APPENDIX C
MISCELLANEOUS PERFORMANCE ANALYSIS

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX C.1
VARIABILITY OF AMMONIA LOOP PARAMETERS

INTEROFFICE CORRESPONDENCE

78.6806-PJB-253
PSD-I-262

TO: Distribution

CC:

DATE: 5 May 1978

SUBJECT: Preliminary Analysis of Variability of
Ammonia Loop Parameters Due to Annual
Overall Temperature Difference Variations

PJB
FROM: P. J. Bakstad
BLDG. MAIL STA. EXT.
81 1538 51554

The analysis included in the attached technical note has been prepared to support preliminary design activities. More detailed analyses will be available later during the July-August timeframe, but these will come too late to impact early design decisions. These latter detailed performance models are presently being formulated by Dr. Impink, et al, at CMU under the direction of Dr. Kayton and myself.

The analysis presented gives estimates of the annual variations in ammonia flow, pressure and temperature. These results should be useful in the preliminary design of the instrumentation and control systems, the specifications of ammonia pumps, valves and turbogenerator (these must be sized for maximum flow and power conditions), for the definition of design pressures (e.g., 10% over maximum operating pressure) and pipe sizing.

The analysis indicates that evaporator and condenser operating conditions are set by energy balances and heat transfer rates considering the effect of the turbine representing a flow impedance between the ammonia vapor source (evaporator) and sink (condenser). The analysis shows that the system is stable in the sense that the evaporator and condenser pressures and temperatures will adjust itself to match the turbine impedance (which depends on parameters such as vane position and power demand) to satisfy energy and mass balances.

We are presently assuming that nominal design ΔT is 40°F with annual variations of $\pm 4^\circ\text{F}$ ($T_H = 80 \pm 4^\circ\text{F}$, $T_C = 40^\circ\text{F}$ constant). Expected variations are shown in a table. Note that the presently ongoing re-optimization will define nominal flow and power for the 10 MWe, net loop. Preliminary results indicate that the gross power at nominal conditions (P_G°) will be about 14.4 MWe, the corresponding nominal ammonia flow rate will be about 825 lb/sec. Table 2 and Eq (10) may then be used to estimate variations.

1. PURPOSE AND SCOPE

THE PURPOSE OF THIS NOTE IS TO PRESENT A SIMPLIFIED ANALYSIS OF THE VARIABILITY OF THE POWER LOOP PARAMETERS WITH SEASONAL VARIATIONS IN SEAWATER TEMPERATURES. THE ANALYSIS WILL BE SUFFICIENTLY DETAILED TO SUPPORT INITIAL SPECIFICATIONS OF TURBINES AND PUMPS, AND SIZING OF PIPES. (NOTE THAT MAX. FLOW/POWER CONDITIONS MUST BE USED TO SPECIFY THESE ITEMS)

MORE ACCURATE ANALYSES WILL BE AVAILABLE LATER WHEN THE DETAILED STEADY STATE PERFORMANCE AND DYNAMIC MODELS ARE DEVELOPED

2. MODEL AND ASSUMPTIONS





FIG. 1. SIMPLIFIED LOOP SCHEMATIC

THE FOLLOWING EQUATIONS DESCRIBE THE MODEL USED.
 HEAT TRANSFER RATE :

PREPARED _____
 CHECKED _____
 MODEL _____



$$Q_E = (UA)_E \frac{(T_E - T_1) - (T_E - \Delta T_E - T_1)}{\ln\left(\frac{T_E - T_1}{T_E - \Delta T_E - T_1}\right)} \quad (1)$$



$$Q_C = (UA)_C \frac{(T_2 - T_C) - (T_2 - T_C - \Delta T_C)}{\ln\left(\frac{T_2 - T_C}{T_2 - T_C - \Delta T_C}\right)} \quad (2)$$




FIG. 2. TEMP. PROFILES

U - OVERALL HEAT TRANSFER COEFF.
 A - HEAT TRANSFER AREA
 T - TEMPERATURES DEFINED IN FIG. 2

ENERGY BALANCE, WATER SIDE :

$$Q_E = (W_g C_p)_E \Delta T_E \quad (3)$$

$$Q_C = (W_g C_p)_C \Delta T_C \quad (4)$$

$W_g C_p$ - HEAT CAPACITY (BTU/HR-°F)
 IN ABOVE EQUATIONS: E - EVAPORATOR
 C - CONDENSER

THE HEAT RATES ARE RELATED BY A LOOP
 POWER CONVERSION EFFICIENCY η :

$$Q_C = (1 - \eta) Q_E \quad (5)$$

AMMONIA FLOW RATE, w IS GIVEN BY :

$$w = \frac{Q_E}{h_g(T_1) - h_f(T_2)} \quad (6)$$

$h_g(T_1)$ = SPECIFIC ENTHALPY OF SATURATED VAPOR AT T_1
 $h_f(T_2)$ = SPECIFIC ENTHALPY OF SATURATED LIQUID AT T_2

PREPARED _____
 CHECKED _____
 MODEL _____

THE TURBINE REPRESENTS AN IMPEDANCE TO VAPOR FLOW FROM EVAPORATOR TO CONDENSER. WE ASSUME FOR THIS ANALYSIS TWO MODELS FOR THIS IMPEDANCE :

$$a) \quad W = C_1 \sqrt{\rho_{g1} (P_1 - P_2)} \quad (7a)$$

$$b) \quad W = C_2 P_1 / \sqrt{T_1 + 460} \approx C_2' P_1 \quad (7b)$$

a) IS AN APPROXIMATE RELATIONSHIP FOR A SUBSONIC NOZZLE

b) IS AN APPROXIMATE RELATIONSHIP FOR A SONIC NOZZLE (CHOKED NOZZLE)

A REFERENCE FOR THESE FORMULAS IS AEROSPACE FLUID COMPONENT DESIGNER'S HANDBOOK VOL 1, 1967 (TRW REPORT AD-809182) . SEE ALSO "CRANE, FLOW OF FLUIDS" .

ASSUMPTIONS IMPLICIT IN THESE EQUATIONS (1)---(7) INCLUDE :

1. PREHEATING LOAD IS SMALL AND NOT ACCOUNTED FOR IN LOG MEAN ΔT CALCULATION, EQS (1) & (2).
2. THE ENERGY ADDED BY THE REFLUX AND FEED PUMPS AND WORK TO OVERCOME ELEVATION AND FRICTION IS IGNORED IN EQ (6).
3. THE REPRESENTATION OF THE TURBINE IMPEDANCE AS CHOKED OR SUBSONIC NOZZLE IS APPROXIMATE, AT BEST. IT IS OUR CONJECTURE THAT THESE TWO MODELS WILL BRACKET ACTUAL TURBINE CHARACTERISTIC.
4. THE EFFECTS OF VARIABLE INLET VANES HAS NOT BEEN CONSIDERED.

3. DETERMINATION OF $T_1, T_2, \Delta T_E, \Delta T_C$ FOR VARIATIONS IN T_E AND T_C

PREPARED _____
CHECKED _____
MODEL _____

TO PROCEED THE FOLLOWING ADDITIONAL ASSUMPTIONS WILL BE MADE :

1. $(UA)_E$ AND $(UA)_C$ ARE CONSTANT INDEPENDENT OF SEAWATER TEMPERATURE VARIATIONS. THESE ARE VALID ASSUMPTIONS CONSIDERING 2) BELOW.
2. THE SEAWATER FLOW RATES ARE CONSTANT, THEREFORE $(W\dot{Q}C_p)_E$ AND $(W\dot{Q}C_p)_C$ ARE ESSENTIALLY CONSTANTS.
3. THE POWER CONVERSION EFFICIENCY η IS CONSTANT SUCH THAT

$$\frac{Q_E}{Q_C} = \text{CONSTANT} \quad (8)$$

BY EQUATING EQS (1) AND (3) AND EQS (2) AND (4) RESPECTIVELY WE OBTAIN :

$$\Delta T_E = (T_E - T_1) \left[1 - \exp\left(-\frac{UA}{(W\dot{Q}C_p)_E}\right) \right] \quad (9)$$

$$\Delta T_C = (T_2 - T_C) \left[1 - \exp\left(-\frac{UA}{(W\dot{Q}C_p)_C}\right) \right] \quad (10)$$

THEREFORE, DENOTING FROM NOW ON NOMINAL, OR DESIGN, CONDITIONS WITH A SUPERSCRIPT "0" :

$$\frac{\Delta T_E}{\Delta T_E^0} = \frac{T_E - T_1}{T_E^0 - T_1^0} \quad (11)$$

$$\frac{\Delta T_C}{\Delta T_C^0} = \frac{T_2 - T_C}{T_2^0 - T_C^0} \quad , \quad (12)$$

AND USING EQ(8) AND ASSUMPTION 2) ABOVE :

$$\frac{\Delta T_E}{\Delta T_C} = \frac{\Delta T_E^0}{\Delta T_C^0} \Rightarrow T_2 = T_C + (T_E - T_1) \frac{T_2^0 - T_C^0}{T_E^0 - T_1^0} \quad (13)$$

FINALLY, BY EQUATING EQS (6) AND (7a,b) AND USING NOMINAL CONDITIONS TO ELIMINATE C_1 RESP. C_2 (WHICH

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

PAGE 5/10

WE ASSUME ARE CONSTANTS) WE OBTAIN

a) FOR THE SUBSONIC NOZZLE ASSUMPTION :

$$\frac{\frac{T_E - T_1}{T_E^\circ - T_1^\circ}}{\frac{h_g(T_1) - h_f(T_2)}{h_g(T_1^\circ) - h_f(T_2^\circ)}} = \sqrt{\left(\frac{S_{g1}}{S_{g1^\circ}}\right) \left(\frac{p_1 - p_2}{p_1^\circ - p_2^\circ}\right)} \quad (14a)$$

b) FOR THE SONIC NOZZLE ASSUMPTION :

$$\frac{\frac{T_E - T_1}{T_E^\circ - T_1^\circ}}{\frac{h_g(T_1) - h_f(T_2)}{h_g(T_1^\circ) - h_f(T_2^\circ)}} = \frac{p_1}{p_1^\circ} \quad (14b)$$

EQS (13) AND (14), REPRESENTING TWO EQUATIONS IN TWO UNKNOWN T_1 AND T_2 , HAVE BEEN SOLVED NUMERICALLY FOR DIFFERENT VALUES OF T_E AND T_C USING THE FOLLOWING APPROXIMATIONS FOR THE THERMODYNAMIC RELATIONSHIPS FOR SATURATED AMMONIA :

$$p_1 = p_1^\circ + \Delta T_1 \left(\frac{\partial p}{\partial T}\right)_{1,s} = 128.8 + 2.27 \Delta T_1 \quad (\text{PSIA}) \quad \text{AT } 70^\circ\text{F}$$

$$p_2 = p_2^\circ + \Delta T_2 \left(\frac{\partial p}{\partial T}\right)_{2,s} = 89.2 + 1.71 \Delta T_2 \quad (\text{PSIA}) \quad \text{AT } 50^\circ\text{F}$$

$$h_g = h_g^\circ + \Delta T_1 \left(\frac{\partial h_g}{\partial T}\right)_{1,s} = 629.1 + 0.17 \Delta T_1 \quad (\text{BTU/LB}) \quad \text{AT } 70^\circ\text{F}$$

$$h_f = h_f^\circ + \Delta T_2 \left(\frac{\partial h_f}{\partial T}\right)_{2,s} = 97.9 + 1.12 \Delta T_2 \quad (\text{BTU/LB}) \quad \text{AT } 50^\circ\text{F}$$

$$S_{g1} = S_{g1}^\circ + \Delta T_1 \left(\frac{\partial S_g}{\partial T}\right)_{1,s} = 0.4325 + 0.0074 \Delta T_1 \quad (\text{LB/CUFT}) \quad \text{AT } 70^\circ\text{F}$$

AND

$$\Delta T_1 = T_1 - T_1^\circ$$

$$\Delta T_2 = T_2 - T_2^\circ$$

C-9

(15)



PREPARED _____
 CHECKED _____
 MODEL _____

A LISTING OF A FORTRAN PROGRAM ACCOMPLISHING THIS (SUBSONIC NOZZLE CASE) IS GIVEN BELOW:

```

00100      PROGRAM SENS(INPUT,OUTPUT)
00110      T10=70.
00120      T20=50.
00130      TE0=80.
00140      TC0=40.
00150      RG10=0.4325
00160      DRG1=0.0074
00170      HG10=629.1
00180      DHG=0.17
00190      HF20=97.9
00200      DHF2=1.12
00210      P10=128.8
00220      DP1=2.27
00230      P20=89.2
00240      DP2=1.71
00250 5     ACCEPT TE,TC
00260      T1=TE-0.25*(TE-TC)
00270 10    T2=TC+(TE-T1)*(T20-TC0)/(TE0-T10)
00280      DT1=T1-T10
00285      DT2=T2-T20
00290      HG1=HG10+DT1*DHG1
00300      HF2=HF20+DT2*DHF2
00310      RG1=RG10+DT1*DRG1
00320      P1=P10+DT1*DP1
00330      P2=P20+DT2*DP2
00340      A=SQRT(RG1*(P1-P2)/(RG10*(P10-P20)))
00350      B=(HG1-HF2)/(HG10-HF20)
00360      T11=TE-(TE0-T10)*A*B
00370      IF(ABS(T11-T1).LT.0.01) GO TO 20
00380      T1=T11
00390      GO TO 10
00400 20    DISPLAY T1,T2
00410      GO TO 5
00420      END
  
```

4 RESULTS AND DISCUSSION

THE FORTRAN PROGRAM SHOWN ABOVE AND ITS EQUIVALENT FOR THE SONIC NOZZLE CASE (STATEMENT 00340 CHANGED TO $A = P1/P10$) WERE USE TO GENERATE THE RESULTS IN TABLE 1 (NEXT PAGE) AND FIGURES 1 AND 2.

THE NOMINAL ("0") VALUES ARE $T^0 = 80^{\circ}F$, $T_1^0 = 70^{\circ}F$, $T_2^0 = 50^{\circ}F$ AND $T_C^0 = 40^{\circ}F$ WHICH IS OUR BASELINE DESIGN. THE TABLE AND FIGURES ALSO SHOW AS A REFERENCE THE RESULT OF THE (1/4, 1/2, 1/4) "RULE", NAMELY (TEXT CONT. ON PAGE 8) C-10

PREPARED _____
 CHECKED _____
 MODEL _____

T_E (°F)	T_C (°F)	SONIC N.		SUBSONIC N.		$(\frac{1}{4}, \frac{1}{2}, \frac{1}{4})$	
		T_1 (°F)	T_2 (°F)	T_1 (°F)	T_2 (°F)	T_1 (°F)	T_2 (°F)
70.	40.	61.47	48.53	62.37	47.63	62.5	47.5
72.	↓	63.17	48.83	63.67	48.13	64.0	48.0
74.	↓	64.88	49.12	65.40	48.60	65.5	48.5
76.	↓	66.59	49.41	66.94	49.06	67.0	49.0
78.	↓	68.30	49.70	68.47	49.53	68.5	49.5
80.	↓	70.-	50.-	70.-	50.-	70.-	50.-
82.	↓	71.70	50.30	71.53	50.47	71.5	50.5
84.	↓	73.42	50.58	73.09	50.91	73.0	51.0
86.	40.	75.12	50.88	74.62	51.38	74.5	51.5
80.	36.	69.94	46.06	69.41	46.59	69.0	47.0
↓	38.	69.97	48.03	69.71	48.29	69.5	48.5
↓	40.	70.-	50.-	70.-	50.-	70.-	50.-
80.	42.	70.03	51.97	70.30	51.70	70.5	51.5
82.	38.	71.67	48.33	71.25	48.75	71.0	49.0
84.	36.	73.34	46.66	72.51	47.49	72.0	48.0

TABLE 1, NUMERICAL RESULTS




FIG. 2. T_1 AND T_2 FOR VARIATIONS IN T_E , CONSTANT $T_C = 40^\circ\text{F}$

PREPARED _____
 CHECKED _____
 MODEL _____

REPORT NO. _____
 PAGE 8/10




FIG. 3. T_1 AND T_2 FOR VARIATIONS IN T_c , CONST. $T_E = 80^\circ\text{F}$

THAT, APPROXIMATELY, OPTIMUM DESIGN CORRESPONDS TO

$$\left. \begin{aligned} T_E - T_1 &= \frac{1}{4} (T_E - T_c) \\ T_1 - T_2 &= \frac{1}{2} (T_E - T_c) \\ T_2 - T_c &= \frac{1}{4} (T_E - T_c) \end{aligned} \right\} \quad (16)$$

IF WE MAKE THE ASSUMPTION THAT THE SONIC AND SUBSONIC NOZZLE APPROXIMATIONS BRACKET THE ACTUAL TURBINE, THE RESULTS ABOVE CAN BE USED TO ESTIMATE OFF-DESIGN CONDITIONS OF TEMPERATURES AND FLOW. NOTE THAT THE (1/4, 1/2, 1/4) RULE ALMOST COINCIDES WITH THE SUBSONIC NOZZLE APPROXIMATION.

IF WE ASSUME THAT ANNUAL VARIATIONS IN WARM WATER TEMPERATURE T_E IS $\pm 4^\circ\text{F}$ WITH COLD WATER TEMPERATURE ESSENTIALLY CONSTANT, THEN WE CAN ESTIMATE THE VARIATION IN AMMONIA FLOW, PRESSURE AND TEMPERATURE CONDITIONS USING THE VAPOR TABLES AND THE RESULTS SHOWN ABOVE. TABLE 2 SHOWS THE RESULTS.



PREPARED _____
 CHECKED _____
 MODEL _____

SEASONAL VARIATIONS IN WARM WATER TEMP. 80 ± 4 °F. CONSTANT COLD WATER TEMP. 40°F	MIN. FLOW CONDITIONS "WINTER" T _E = 76°F	NOM. FLOW CONDITIONS T _E = 80°F	MAX. FLOW CONDITIONS "SUMMER" T _E = 84°F	VAR- IABILITY (APPROX.) %
<u>EVAPORATOR OUTLET (STATIC)</u>				
NH ₃ TEMPERATURE, °F	66.5	70.0	73.5	± 5
" PRESSURE, PSIA	121.1	128.8	136.9	± 6
" QUALITY, %	> 99	> 99	> 99	
" MASS FLOW, LB/SEC	0.90 w°	w°	1.10 w°	± 10
" VOL. FLOW, ACFS	0.95 V°	V°	1.05 V°	± 5
<u>CONDENSER INLET (STATIC)</u>				
" TEMPERATURE, °F	49.0	50.0	51.0	± 2
" PRESSURE, PSIA	87.5	89.2	90.9	± 2

TABLE 2. VARIABILITY OF AMMONIA CONDITIONS

NOTE THAT THE PRESSURE AND TEMPERATURE VARIATIONS ARE BASED ON THE SONIC NOZZLE APPROXIMATION TO THE TURBINE, AND THE MASS AND VOLUMETRIC FLOW RATES ARE BASED ON THE SUB-SONIC APPROXIMATION. THESE CHOICES MAXIMIZE (OR "WORST-CASE") THESE VARIATIONS.

THE VARIATIONS IN MASS FLOW RATE IS COMPUTED FROM:

$$\left(\frac{w}{w^0}\right) = \left(\frac{Q}{Q_0}\right) \left(\frac{h_g^0 - h_f^0}{h_g - h_f}\right) = \left(\frac{T_E - T_1}{T_E^0 - T_1^0}\right) \left(\frac{h_g^0 - h_f^0}{h_g - h_f}\right) \quad (9)$$

THE VARIATION IN GROSS TURBINE POWER HAS BEEN CALCULATED BASED ON CONSTANT TURBINE EFFICIENCY. FROM THE THERMODYNAMIC TABLES IT FOLLOWS THAT:

(T ₁ , T ₂)	73, 51	70, 50	67, 49	(°F)
(Δh) _{s=c}	21.56	19.85	17.99	(BTU/LB)

PREPARED _____

CHECKED _____

MODEL _____

USING EQ(9) IT FOLLOWS THAT :

$$\left. \begin{aligned} \left(\frac{P_G}{P_G^0}\right)_{\text{MAX}} &= 1.196 \\ \left(\frac{P_G}{P_G^0}\right)_{\text{MIN}} &= 0.815 \end{aligned} \right\} \quad (10)$$

NOTE :

- THE TURBO-GENERATOR MUST BE SIZED FOR MAX. POWER.
- AMMONIA PUMPS, PIPES AND VALVES MUST BE SIZED FOR MAX. FLOW.
- THE CONTROL SYSTEMS MUST HANDLE VARIATIONS BETWEEN MIN. AND MAX. THE RFP REQUIREMENTS INCLUDE CONSIDERATION OF ΔT VARIATIONS OF $+4^\circ\text{F}$ AND -11°F . THEREFORE, OPERATION AT CONSIDERABLY REDUCED FLOWS, AND EVAPORATOR PRESSURE MUST BE ADDRESSED.

APPENDIX C.2
OPTIMUM DESIGN ΔT

TRW

DEFENSE AND SPACE SYSTEMS GROUP

ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278

INTEROFFICE CORRESPONDENCE

78.6806-PJB-254
PSD-I-263

TO: Distribution

CC:

DATE: 5 May 1978

SUBJECT: Optimum Design ΔT^*
For OTEC Plants

PJB
FROM: P. J. Bakstad

BLDG. 81 MAIL STA. 1538 EXT. 51554

Dr. Abe Lav[†]* called my attention to an unpublished paper where he showed that the optimum design ΔT^* for an OTEC plant may be less than the annual average ΔT_0 . The purpose of the enclosed note is to analyze this conjecture using our own cost and performance models. The result indicates that for an average annual ΔT of 40°F varying sinusoidally with + 4°F amplitude, the optimum design ΔT^* is 38.1°F. This result is based on the assumption that the warm and cold water flow rates are constant, and that the ammonia pumps, valves, pipes and turbine-generator are sufficiently oversized to handle maximum ΔT ("summer") conditions. However, the sensitivity to $|\Delta T^* - \Delta T_0|$ is so small that the result is of theoretical interest only. Furthermore, we show that the optimum ΔT^* is sensitive to the details of the cost model used.

It is concluded that, at the present state-of-the-art, the design ΔT^* should be selected equal to the annual average ΔT_0 . This is the approach we are taking in the PSD-I design. It must be emphasized again that ammonia pumps, valves, pipes and turbogenerator must be sized for maximum ΔT ("summer") conditions.

* I believe during the February Miami Conference

PREPARED P. BAKSTAD 4/30/78

REPORT NO.

PAGE 1/5

CHECKED _____

MODEL _____

**OPTIMUM DESIGN ΔT
FOR OTEC PLANTS**

LAVI (UNPUBLISHED PAPER) HAS SUGGESTED THAT, CONSIDERING ANNUAL VARIATIONS IN THE AVAILABLE $\Delta T = T_{WARM} - T_{COLD}$, THE OPTIMUM DESIGN $\Delta T = \Delta T^*$ MAY BE LESS THAN THE AVERAGE $\Delta T = \Delta T_0$. THIS NOTE INVESTIGATES THIS CONJECTURE, FOLLOWING LAVI'S ANALYSIS USING OUR OWN RECOMMENDED PERFORMANCE AND COST RELATIONSHIPS.

LET ΔT^* BE THE DESIGN ΔT , THEN, AS SUGGESTED BY J. HILBERT ANDERSON, THE PLANT CAPITAL COST IS APPROXIMATED BY

$$C_c = \frac{a}{\Delta T^* - b}, \$ \quad (1)$$

WHERE $b \approx 23^\circ F$, AS SHOWN IN THE PSD CD. REPORT.

THE VARIATION IN PLANT OUTPUT WITH ΔT IS APPROXIMATELY GIVEN BY

$$P_N = P_G \left(\frac{\Delta T}{\Delta T^*} \right)^2 - P_L \quad (2)$$

WHERE

P_N = NET POWER, MW

P_G^* = GROSS POWER AT DESIGN $\Delta T = \Delta T^*$, MW

P_L^* = LOSSES, MOST OF WHICH ARE WATER PUMPING WHICH ARE ASSUMED CONSTANT (NO FLOW RATE VARIATION), MW

THE POWER DEPENDENCY IS APPROXIMATELY TRUE, SINCE TO A FIRST APPROXIMATION GROSS POWER IS PROPORTIONAL TO CARNOT EFFICIENCY ($\sim \Delta T$) TIMES HEAT TRANSFERRED ($\sim \Delta T$).

ASSUME FURTHER THAT THE ΔT VARIATION WITH TIME IS SINUSOIDAL:

$$\Delta T(t) = \Delta T_0 + \epsilon \cdot \sin\left(\frac{2\pi t}{12}\right) \quad t \text{ IN MONTHS} \quad (3)$$

PREPARED _____
 CHECKED _____
 MODEL _____

THE TIME VARIATION OF NET PLANT OUTPUT IS THEN :

$$P_N(t) = P_G^* \left(\frac{\Delta T(t)}{\Delta T^*} \right)^2 - P_L^* \quad (4)$$

THE ANNUAL AVERAGE IS THEREFORE :

$$\langle P_N \rangle = P_G^* \frac{\Delta T_0^2 + \frac{1}{2} \epsilon^2}{(\Delta T^*)^2} - P_L^* \quad (5)$$

NOTE THAT THESE DERIVATIONS ASSUME THAT THE TURBOGENERATOR IS OVERSIZED TO HANDLE MAX. POWER OUTPUT AND ALSO THAT TURBINE EFFICIENCY IS ESSENTIALLY CONSTANT.

THE BUSBAR ENERGY COST C_{BB} (\$/KWH) IS NOW, ASSUMING A CONSTANT AVAILABILITY FACTOR :

$$C_{BB} \sim \left[\frac{a}{\Delta T^* - b} \right] \left[\frac{1}{P_G^* \frac{\Delta T_0^2 + \frac{1}{2} \epsilon^2}{(\Delta T^*)^2} - P_L^*} \right]$$

IF C_{BB} HAS A MINIMUM FOR SOME ΔT^* THE DERIVATIVE MUST BE ZERO:

$$\frac{\partial C_{BB}}{\partial \Delta T^*} = 0$$

OR EQUIVALENTLY

$$\frac{\partial \left(\frac{1}{C_{BB}} \right)}{\partial \Delta T^*} = 0$$

THEREFORE :

$$\left[P_G^* \frac{\Delta T_0^2 + \frac{1}{2} \epsilon^2}{(\Delta T^*)^2} - P_L^* \right] + [\Delta T^* - b] \left[P_G^* (\Delta T_0^2 + \frac{1}{2} \epsilon^2) (-2) (\Delta T^*)^{-3} \right] = 0$$

PREPARED _____
 CHECKED _____
 MODEL _____

REPORT NO. _____

PAGE 3/5

DIVIDE BY P_G^* , MULTIPLY WITH $(\Delta T^*)^3$ AND COLLECT TERMS:

$$\frac{P_L^*}{P_G^*} (\Delta T^*)^3 + \Delta T^* [\Delta T_0^2 + \frac{1}{2} \epsilon^2] - 2b [\Delta T_0^2 + \frac{1}{2} \epsilon^2] = 0 \quad (6)$$

THIS EQUATION CAN BE SOLVED ANALYTICALLY, BUT TRIAL-AND-ERROR SOLUTION IN THE FORM

$$\Delta T^* = \frac{2b [\Delta T_0^2 + \frac{1}{2} \epsilon^2] (P_G^*/P_L^*)}{[\Delta T_0^2 + \frac{1}{2} \epsilon^2] (P_G^*/P_L^*) + (\Delta T^*)^2} \quad (7)$$

IS EASIER.

EXAMPLE :

$$\frac{P_G^*}{P_L^*} = \frac{1.3}{0.3} = 4.333$$

$$b = 23^\circ \text{F}$$

$$\Delta T_0 = 40^\circ \text{F}$$

$$\epsilon = 4^\circ \text{F}$$

$$\Delta T_{opt}^* = \frac{320528}{6968 + (\Delta T_{opt}^*)^2} \Rightarrow \Delta T^* = 38.1^\circ \text{F}$$

THIS SUGGEST THAT THE OPTIMUM DESIGN ΔT^* IS 38.1°F WHICH IS 1.9°F LESS THAN THE AVERAGE SITE ΔT_0 . TO INVESTIGATE SENSITIVITY CALCULATE :

$$\frac{C_{BB}(\Delta T^*)}{C_{BB}(\Delta T_0)} = \left[\frac{\Delta T_0 - b}{\Delta T^* - b} \right] \left[\frac{\frac{P_G^*}{P_L^*} (\Delta T_0^2 + \frac{1}{2} \epsilon^2) - \Delta T_0^2}{\frac{P_G^*}{P_L^*} (\Delta T_0^2 + \frac{1}{2} \epsilon^2) \left(\frac{\Delta T_0}{\Delta T^*} \right)^2 - \Delta T_0^2} \right]$$


WHICH IS THE RATIO OF ENERGY COST FOR DESIGN ΔT^* VERSUS AVERAGE ΔT_0 . FOR THE SAMPLE VALUES:

PREPARED _____
 CHECKED _____
 MODEL _____

WE COMPUTE :

ΔT^*	$\frac{C_{PB}(\Delta T^*)}{C_{PB}(\Delta T_0)}$
34	1.0313
36	1.0025
38	0.9940
40	1.0000
42	1.0175
44	1.0449
38.1	0.9939

$(\frac{C_{PB}^*}{C_{PB}})$



IT FOLLOWS FROM THIS NUMERICAL EXAMPLE THAT ALTHOUGH A THEORETICAL MINIMUM ENERGY COST OCCURS FOR 38.1 °F FOR AN AVERAGE ΔT OF 40 °F, THE SENSITIVITY IS SMALL. THE ENERGY COST AT 40 °F IS HIGHER BY ONLY 0.6 PERCENT. (WHICH IS WITHIN THE UNCERTAINTY OF THE MODEL !)

CONCLUSION

DR. LAVI'S CONJECTURE APPEARS MATHEMATICALLY CORRECT. HOWEVER, THE ENERGY COST IS VERY INSENSITIVE TO DESIGN TEMPERATURE AND FOR DESIGN OTHER CONSIDERATIONS OF OFF-DESIGN PERFORMANCE (SUCH AS TURBINE EFFICIENCY) ARE MORE IMPORTANT.

APRIL 30, 78
 P.J. Bahstad

ADDENDUM

THE CONCLUSION ABOVE APPEARS SENSITIVE TO THE EXACT COST MODEL. LAVI ASSUMED THAT

PREPARED _____
 CHECKED _____
 MODEL _____

$$C \sim (\Delta T^*)^{-k}$$

WHERE $2. \leq k \leq 3.$
 (LAVI SUGGESTS THAT $k=2.5$)

FOR THIS CASE:

$$\Delta T^* \Big|_{\substack{\text{MIN} \\ \text{COST LAVI}}} = \sqrt{\left(\frac{P_G^*}{P_L^*}\right) \left(\frac{k-2}{k}\right) \left[(\Delta T_0)^2 + \frac{1}{2}\epsilon^2\right]}$$

IN OUR EXAMPLE :

$$\Delta T^* \Big|_{\substack{\text{MIN} \\ \text{COST, LAVI}}} = \sqrt{\left(\frac{1.3}{0.3}\right) \left(\frac{0.5}{2.5}\right) (1600+8)} = 37.3 \quad \text{FOR } k=2.5$$


= 0. (!) FOR $k=2.$

= 48.2 (!) FOR $k=3.$

THE EXPRESSION FOR $C_{BB}(\Delta T^*) / C_{BB}(\Delta T_0)$ BECOMES:

$$\frac{C_{BB}(\Delta T^*)}{C_{BB}(\Delta T_0)} = \left(\frac{\Delta T_0}{\Delta T^*}\right)^k \left[\frac{P_G^* (\Delta T_0^2 + \frac{1}{2}\epsilon^2) - \Delta T_0^2}{P_L^* (\Delta T_0^2 + \frac{1}{2}\epsilon^2) \left(\frac{\Delta T_0}{\Delta T^*}\right)^2 - \Delta T_0^2} \right]$$

ΔT^*	C_{BB}^* / C_{BB}^0		
	$k=2$	$k=2.5$	$k=3$
32	0.903	1.010	1.129
36	0.946	0.998	1.052
40	1.000	1.000	1.000
44	1.067	1.017	0.970
48	1.151	1.051	0.959



THIS SHOWS:

- 1) THE LAVI COST ALG.'S WEAKNESS IN ITS SENSITIVITY TO k
- 2) THE IDEA OF OPTIMIZING DESIGN ΔT^* SHOULD NOT BE PURSUED AT PRESENT, USE $\Delta T^* = \Delta T_0$

APPENDIX D
MATERIALS AND PROCESSES

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX D.1
TUBE MANUFACTURING



DEFENSE AND SPACE SYSTEMS GROUP

ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278

PSD-1-546
5515.2.78-433

INTEROFFICE CORRESPONDENCE

TO: C. Williamson	CC: P. Edris C. Feddersen ✓ J. Hsu F. Jackson G. Porter L. Rosales W. Talon S. Vincent	DATE: 7 September 1978		
SUBJECT: OTEC Tube to Tubesheet Joints — Rubber Expanding Method		FROM: J. Hicks	BLDG. MAIL STA.	EXT.
			01 2080	61486

- Reference: (1) IOC PCS-1-488 (same subject) from C. Williamson to J. Hsu, 14 August 1978.
- (2) Letter from Hitachi America, Ltd. (same subject) to J. Hicks, 25 August 1978.
- (3) Letter from J. Hicks to Hitachi America, Ltd., 7 September 1978.

1. In response to your Reference (1) recommendations, representatives of Materials Engineering met with Mr. K. Ichibashi from Hitachi America (Houston, Texas), who has since supplied the Reference (2) information (copy attached).
2. To facilitate an in-house evaluation of the rubber expanding method, the Reference (3) "cost and delivery" inquiry has been made to Hitachi to supply TRW with twelve sample specimens for testing in our laboratories. Their reply will be forwarded upon receipt.



7 September 1978

Mr. K. Ichihashi
Hitachi America, Ltd.
3800 Buffalo Speedway, Suite 318
Greenway Plaza
Houston, Texas 77098

Dear Mr. Ichihashi:

This letter is to acknowledge receipt of the proposed licensing agreement for use of the Hitachi Expanding Machine (Rubber Expansion Unit), and the copy of the United States patent for same. This information has been forwarded to our Ocean and Energy Systems Department for their consideration.

We would appreciate further information from your home office relative to having Hitachi provide TRW with twelve single tube models, as illustrated in Figure 9 of the Hitachi "Technical Report of Uniform Tube Expansion (Rubber Expansion)", except the titanium tube wall thickness should be 0.71 mm (0.028 inch) instead of the 1.75 mm (0.069 inch) shown. These twelve specimens would be tested in TRW laboratories relative to retaining force and watertightness. The planning information required is:

- o Total cost, including air freight delivery to Los Angeles International Airport
- o Estimated delivery schedule (TRW desires delivery by mid-November 1978).

Thank you for your assistance in obtaining the above information.

Sincerely yours,


John S. Hicks

D-5

 **Hitachi America, Ltd.**

HOUSTON OFFICE
3800 BUFFALO SPEEDWAY, SUITE 318
GREENWAY PLAZA
HOUSTON, TEXAS 77098

TELEX
77-8985

August 25, 1978
HOU-025-S

Mr. John Hicks
TRW, Inc., Systems Group
Building No. 01, Room 2220
One Space Park
Redondo Beach, California 90278

Dear Mr. Hicks:

I am enclosing our proposal regarding Hitachi Expanding machine (Rubber Expansion Unit) sales, and also the patent copy registered in the United States, for your reference.

The unit is ready for shipment within four (4) months after our receipt of contract.

We would appreciate your comment on this matter. Thank you for your kind attention.

Very truly yours,

HITACHI, AMERICA, LTD.

K. Ichihashi

K. Ichihashi

KI:sp
Enclosures

LICENSE AGREEMENT

1. Grant of License

HITACHI, LTD. grants to Licensee:

1. A nonexclusive and nontransferrable license to use technical information disclosed to licensee by Hitachi, Ltd., in the manufacture and sale of Heat Exchangers throughout the world.

2. A nonexclusive and nontransferrable license under Hitachi, Ltd. patent right throughout the world to manufacture and sell Heat Exchangers.

2. Royalty

1. An initial payment of five million yen (¥ 5,000,000), which shall be applicable to the running royalties specified in No. 2, below.

2. Running royalties in the amount of 1.5 per cent of the net sales price of Heat Exchanger manufactured by Rubber Expanding Unit and sold by licensee during the term of this Agreement.

3. Royalty shall be paid to Hitachi, Ltd. every six months.

3. Hitachi, Ltd. Services

Hitachi, Ltd. furnishes to Licensee:

1. Information helpful to licensee in the manufacture of Heat Exchangers applying Rubber Expansion Unit.

2. Design Method of tube-to-tubesheet construction.

3. Operation manual and explanation sheet of Rubber Expansion Unit.

4. Rubber Expansion Unit

FOB Japan Port Price: ¥ 5,000,000 (five million yen) per one unit.

Q. 1st

4068372




NOTICE TO ALL TO WHOM THESE PRESENTS SHALL COME:

TO ALL TO WHOM THESE PRESENTS SHALL COME:

**Whereas, THERE HAS BEEN PRESENTED TO THE
Commissioner of Patents and Trademarks**

A PETITION PRAYING FOR THE GRANT OF LETTERS PATENT FOR AN ALLEGED NEW AND USEFUL INVENTION THE TITLE AND DESCRIPTION OF WHICH ARE CONTAINED IN THE SPECIFICATIONS OF WHICH A COPY IS HEREUNTO ANNEXED AND MADE A PART HEREOF, AND THE VARIOUS REQUIREMENTS OF LAW IN SUCH CASES MADE AND PROVIDED HAVE BEEN COMPLIED WITH, AND THE TITLE THERETO IS, FROM THE RECORDS OF THE PATENT AND TRADEMARK OFFICE IN THE CLAIMANT(S) INDICATED IN THE SAID COPY, AND WHEREAS, UPON DUE EXAMINATION MADE, THE SAID CLAIMANT(S) IS (ARE) ADJUDGED TO BE ENTITLED TO A PATENT UNDER THE LAW.

NOW, THEREFORE, THESE Letters Patent ARE TO GRANT UNTO THE SAID CLAIMANT(S) AND THE SUCCESSORS, HEIRS OR ASSIGNS OF THE SAID CLAIMANT(S) FOR THE TERM OF SEVENTEEN YEARS FROM THE DATE OF THIS GRANT, SUBJECT TO THE PAYMENT OF ISSUE FEES AS PROVIDED BY LAW, THE RIGHT TO EXCLUDE OTHERS FROM MAKING, USING OR SELLING THE SAID INVENTION THROUGHOUT THE UNITED STATES.



In testimony whereof I have hereunto set my hand and caused the seal of the Patent and Trademark Office to be affixed at the City of Washington this seventeenth day of January in the year of our Lord one thousand nine hundred and seventy-eight, and of the Independence of the United States of America the two hundredth and second.

*Attest:
Wm. G. M. [Signature]
Attending Officer.*

D-8
[Signature]
Acting Commissioner of Patents and Trademarks.

[54] TUBE EXPANDER

[75] Inventors: Hidesaki Kamohara, Kudamatsu; Toji Nakatani, Hikari; Yuji Yoshitomi, Kudamatsu; Iwao Sasaki, Kudamatsu; Kenji Shimada, Kudamatsu, all of Japan

[73] Assignee: Hitachi, Ltd., Tokyo, Japan

[21] Appl. No.: 768,198

[22] Filed: Feb. 14, 1977

[30] Foreign Application Priority Data

Feb. 18, 1976 Japan 51-15879

[51] Int. Cl.² B23P 17/00

[52] U.S. Cl. 29/727; 29/282; 29/283.5; 72/58; 72/DIG. 14

[58] Field of Search 72/58, 59, 61, 62, DIG. 14; 29/421 R, 523, 727, 283.5, 282, 157.4

[56] References Cited

U.S. PATENT DOCUMENTS

3,152,630 10/1964 Nilsson 72/58 X
 3,595,047 7/1971 Fenning 72/58

3,977,068 8/1976 Krips 29/727 X
 4,006,619 2/1977 Anderson 72/58 X

Primary Examiner—Leon Gilden
 Attorney, Agent, or Firm—Beall & Jeffery

[57] ABSTRACT

Disclosed is a tube expander adapted for use in fixing tubes to a tube plate of a boiler or a multitubular heat exchanger. The expander incorporates an elastic expanding medium adapted to be inserted into a tube to be expanded radially against a wall of a tube-receiving bore of the tube plate. The expander further includes a pressurizing rod passing through the expanding medium, a pressurizing rod head provided at one end of the pressurizing rod, a back-up ring adapted to be supported straddling said tube receiving bore and slidably passed by the pressurizing rod, and seal rings disposed at both sides of the pressurizing rod. The seal rings are made of a hard elastic material of a hardness greater than that of the expanding medium, and each of them is provided with at its portion confronting the end of the expanding medium with a conical recess.

10 Claims, 7 Drawing Figures




FIG. 1




FIG. 2




FIG. 3




FIG. 4




FIG. 5




FIG. 6





FIG. 7



TUBE EXPANDER

BACKGROUND OF THE INVENTION

The present invention relates to a tube expander for fixing tubes to a tube plate of a boiler or multitubular heat exchanger and, more particularly, to a tube expander relying upon a radial expansion of a cylindrical elastic expanding medium inserted into a tube caused by an axial compression of the medium for expanding and fixing the tube to the tube-receiving bore of the tube plate.

In manufacturing boilers and multitubular heat exchanger or the like, such a method of fixing tubes to a tube plate is getting popular as consisted in inserting a cylindrical elastic expanding medium and compressing the medium in the axial direction to cause the later to exert a radial expanding force which in turn acts on the inner peripheral wall of the tube to radially expand and tightly fix the tube to the tube plate.

Conventionally, tube expanders for carrying out the above explained method incorporates a cylindrical elastic expanding medium, a pressurizing rod passing through the medium and a back-up ring adapted to be secured straddling a tube-receiving bore of the tube plate. The pressurizing rod is connected to a piston rod in a hydraulic cylinder. In operation, the hydraulic cylinder exerts a force on a rod-head of the pressurizing rod so that the rod effects an axial compression and a consequent radial expansion of the expanding medium. The radial expansion of the medium in turn expands the tube radially and tightly fits it to the tube-receiving bore of the tube plate.

In those conventional tube expanders, as the tube is radially expanding, a gap left between the inner surface of the tube and a central boss of the back-up ring is also enlarged. Thus, part of the expanding medium inconveniently invades this enlarged gap causing a collapse or deformation of the expanding medium. This unfavorable invasion of the expanding medium takes place also at the end of the pressurizing rod opposite to the back-up ring, where a gap is formed between the rod-head of the pressurizing rod and the tube.

In order to prevent this undesirable collapse of the expanding medium, it has been proposed to put a cylindrical seal ring having parallel end surfaces between the expanding medium and the tube. This seal ring is adapted to expand radially, when compressed axially, to increase its diameter thereby to prevent the collapse of the expanding medium.

The radial deformation or displacement of the seal ring depends on the hardness of the material of the seal ring. A soft seal ring would be collapsed as it is pressed onto the back-up ring, although it may exhibit a large radial displacement to ensure a larger sealing effect. Therefore, the material of the seal ring is selected to have a larger hardness than the expanding medium.

The seal ring is, however, not effective when the expanding pressure reaches 3000 to 4000 kg/cm² as is the case where a large airtightness and a large fixing force is required between the tube and the tube plate, although it can do pretty well for thin tubes. Namely, the larger radial displacement of the seal ring for ensuring the larger sealing effect and the prevention of the collapse of the seal ring are incompatible with each other, since the collapse prevention is ensured only through an enhanced hardness which provides a poor radial displacement.

Under these circumstances, the invention is aiming at overcoming the drawbacks of the prior art by providing an improved tube expander which is free from the collapse of the expanding medium even at a large expanding pressure.

According to the invention, there is provided a tube expander comprising an elastic expanding medium adapted to be received by a tube to be expanded, a pressurizing rod passing through the expanding medium, a rod-head provided at one end of the pressurizing rod, a back-up ring slidably passed by the pressurizing rod and seal rings made of an elastic material of a hardness greater than that of the expanding medium disposed close to both ends of the expanding medium and slidably passed by the pressurizing rod, characterized in that a conical recess is formed in at least one seal ring at a portion thereof facing one end surface of the expanding medium.

The described and other objects, as well as the advantageous features of the invention will become clear from the following description of preferred embodiments taken in conjunction with the attached drawings in which:

BRIEF DESCRIPTION OF THE DRAWINGS

FIG. 1 shows a tube expander embodying the present invention received by a tube to be expanded, particularly a cross-section thereof before the expansion,

FIG. 2 is a cross-sectional illustration explaining a deflection of a seal ring incorporated in the tube expander of the invention, when the ring is axially compressed,

FIG. 3 is a cross-sectional illustration explaining the dynamic behavior of the seal ring when it is deflected,

FIG. 4 is a cross-sectional view of another tube expander received by a tube to be expanded, before the expansion,

FIG. 5 is a cross-sectional view of a seal ring incorporated in the tube expander of the invention,

FIG. 6 is a cross-sectional view of the seal ring of FIG. 5 in a deflected state, and

FIG. 7 is a sectional view of another example of the tube plate to which a tube is fixed by means of a tube expander of the invention, after the expansion.

DETAILED DESCRIPTION OF PREFERRED EMBODIMENTS

Referring at first to FIG. 1 which shows a cross-section of a tube expander embodying the invention received by a tube 1 to be expanded before the expansion, the tube expander includes a cylindrical expanding medium 5 made of an elastic material such as silicon rubber or natural rubber, a pressurizing rod 3 passing through the expanding medium 5, seal rings 7 disposed close to the end faces of the expanding medium and slidably passed by the pressurizing rod 3, the seal rings 7 having conical recesses 7d confronting the ends of the expanding medium and being made of urethane rubber, TEF-LON, epoxy or the like material, and a back-up ring 4 adapted to be secured to the end face of the tube plate 2 by straddling the tube receiving bore.

The pressurizing rod 3 is connected to a piston housed by a hydraulic cylinder which are not shown in the drawings.

The arrangement is such that an axial force F exerted by the hydraulic cylinder on a rod-head 3a of the pressurizing rod 3 compresses the expanding medium 5 axially, whereby a resulting radial expansion of the

medium 5 expands the tube radially to tightly fit it against the tube plate 2.

As mentioned above, the seal rings 7 incorporated in the expander of the invention are provided at their portions confronting the end surfaces of the expanding medium with conical recesses 7d. These recesses are intended for causing a larger radial displacement of the seal rings 7 at portions 7a thereof contacting the expanding medium than at opposite portions 7b, 7c, when the seal rings are subjected to axial compression. The seal rings 7 are adapted to assume their original form when relieved from axial load, and are made of an elastic material for an easy insertion and withdrawal to and from the tube 1, and have a hardness larger than that of the expanding medium 5 so as not to be collapsed by the expanding pressure.

In the embodiment of FIG. 1, a seal ring having conical recess 7d is provided at each side or end of the expanding medium 5. However, alternatively, the seal ring having conical recess may be situated at only one side of the expanding medium, preferably at the side closer to the pressurizing rod head 3a where a comparatively greater load is imparted so as to shift axially, although it is preferable to use the conically recessed seal ring 7 at both sides of the expanding medium, in order to ensure the prevention of the collapse of the expanding medium 5.

Referring next to FIGS. 2 and 3 showing the manner of deflection of the seal rings, as an axial force F is applied to the pressurizing rod 3, as shown in FIG. 1, the force is transmitted through the seal ring 7 to the expanding medium 5. The axial compression exerted on the seal ring 7 appears uniformly on the surface of the seal ring 7 abutting the back-up ring 4 as substantially equally distributed surface pressure p, while, on the surface confronting the expanding medium 5, the pressure increases as it radiates from the center of the seal ring, due to the presence of the conical recess 7d.

Thus, the seal ring 7 is subjected not only to the compression load but also to a bending moment M, so that the seal ring 7 is deflected to have a profile shown by a broken line.

The maximum radial displacement δ of the seal ring is the sum of a radial displacement δ_p caused by the surface pressure p and that δ_θ caused by the bending moment M, as shown in the following equation 1.

$$\delta = \delta_p + \delta_\theta \quad (1)$$

The radial displacements δ_p and δ_θ caused by the surface pressure p and the bending moment M are given by the following equations 2 and 3, respectively.

$$\delta_p = (Pd_1/E) \mu \quad (2)$$

$$\delta_\theta = 2Sg\theta = 2Sg(MR^2g/El) \quad (3)$$

where,

P: surface pressure on the seal ring kg/cm²

Rg: centroidal radius of the cross-sectional of the seal ring mm

E: Young's modulus of the seal ring kg/mm²

Sg: distance of the seal ring from the centroid mm

θ : angular displacement of the seal ring

M: bending moment applied to the seal ring kg-mm/mm

I: moment of inertia of area around an axis I—I

d_1 : the outer diameter of the ring 7 in the relaxed condition

As will be seen from the equations 2 and 3, the surface pressure p and the bending moment M becomes larger as the compression load on the seal ring increases. Therefore, the radial displacement of the seal ring at the portion in contact with the expanding medium gets larger as the compression load increases, thereby to ensure a larger sealing effect and to prevent the fluidizing of the seal ring which would cause the collapse of the expanding medium.

A multitubular heat exchanger was produced employing a tube expander of the invention. No collapsing phenomena of the expanding medium (this medium was a soft rubber having a hardness of 65HSa) was observed even by a surface pressure of 3870 kg/cm², and a uniform expansion of the tube was obtained. The inner diameter of the tube was found to have been increased by about 0.5 mm, as a result of the expansion, and the gap between the outer diameter of the expanding medium and the inner diameter of the tube was 1.1 mm at the maximum.

As have been explained, thanks to the adoption of seal rings having conical recesses, a deflection of the seal ring is effected at its portion confronting the expanding medium, not only by a surface pressure but by a bending moment as well, so that a larger sealing effect is obtained promising a larger effect of preventing the collapsing phenomena of the expanding medium.

The maximum allowable radial displacement of the seal ring can optionally determined, as far as it falls within an acceptable range for the tube-expanding, by suitably selecting the material, shape and dimension of the seal ring.

Therefore, the allowable gap between the wall of the tube-receiving bore of the tube plate and the outer surface of the tube can be made larger as compared with the tube-expansion relying upon conventional seal rings, which contributes to facilitate the insertion of the tube, resulting in a lowered cost of manufacture of the heat exchanger. In addition, the sealing mechanism for the expanding medium is considerably simplified to much facilitate maintenance and inspection of the tube expander.

FIG. 4 shows another embodiment of the invention. A tube expander is shown in section, received by a tube 1 destined to be fitted to a tube plate 2, at a state before the expansion.

The tube expander of this embodiment comprises a pressurizing rod 3 having a head 3a, a cylindrical expanding medium 5, a back-up ring 4 and seal rings 7 (hereinafter called conical seal rings 7) having respective conical recesses 7d, similarly to the first mentioned embodiment.

The tube expander of this embodiment is characterized by an additional provision of an auxiliary conical seal ring 8 disposed in the conical recess of the seal ring, the auxiliary seal ring having a shape similar to that of the conical recess and being made of the same material as the seal ring.

As will be seen from an enlarged view of FIG. 5, the auxiliary seal ring 8 has an outer peripheral edge 8a in contact with the tapered wall of the recess 7d. The auxiliary seal ring 8 further has a tapered surface 8b confronting the wall of the recess 7d of the conical seal ring 7. The tapered surface 8b is inclined with respect to a plane normal to the axis of the ring at an angle smaller than that at which the wall of the 7d is inclined, so that a slight gap 9 is formed between the two seal rings 7 and 8.

In use, subsequent to an insertion of the tube 1 to the tube-receiving bore of the tube plate 2, the conical seal ring 7, auxiliary seal ring 8, expanding medium 5, another auxiliary seal ring 8 and another conical seal ring 7 are fitted on the pressurizing rod 7 in the mentioned sequence.

The pressurizing rod 3 thus carrying these members is then inserted into the tube 1. A back-up ring 4 for supporting the axial compression during the expansion is then attached.

An axial force F is applied in the same manner as the first mentioned embodiment to cause the radial expansion of the expansion medium and, accordingly, of the tube.

During this operation of expanding, the conical seal ring 7 and the auxiliary seal ring 8 play respective roles as mentioned below. The conical seal ring 7 assumes a shape as shown in FIG. 5, before the expansion, while, during the expansion the conical seal ring 7 is deformed to assume a shape as shown in FIG. 6 by the axial compression force. Thus, the peripheral edge 7a of the conical recess 7d exhibits a larger radial deformation than the opposite peripheral edge 7b of the conical seal ring 7, so as to be strongly pressed against the inner surface of the tube 1, thereby to prevent the collapse of the expanding medium 5.

As a result of a repeated use of the conical seal ring 7, the inner peripheral edge 7e of the peripheral edge of the recess 7d is deformed radially outwardly, causing a slight gap δ , between itself 7e and the pressurizing rod 3. However, this gap is conveniently covered by the auxiliary seal ring 8 which has been axially moved without being deformed substantially.

In general, as the conical seal ring 7 is used for repeated continuous operations, the gap between the peripheral edge 7e of the ring and the pressurizing rod 3 is increased considerably, so as to allow the invasion of the fluidized expanding medium. It is remarkable that this plastic flow of the expanding medium 5 is prevented by the provision of the auxiliary seal ring.

Referring to a practical example of the tube expander of the second embodiment, the expanding medium was made from a soft rubber having a hardness of 65 HsA, while the conical seal rings are formed with a hard rubber having a hardness exceeding 95 HsA. These expanding medium and the seal rings are used for expanding tubes having a diameter of 25.4 mm and a thickness of 1.7 mm. Unfavorable plastic flow of the expanding medium was not observed, and efficient and good tube-expanding was confirmed even after 1000 times of operation.

In order to obtain an increased fixing force and watertightness between the tube and the tube plate, the wall of the tube-receiving bore of the tube plate can have a plurality of grooves 10, as shown in FIG. 7. The tube will then firmly gnaw into the grooves to provide an increased force of fixing and enhanced watertightness.

It will be seen from the foregoing description that the tube expander of the present invention incorporates seal rings disposed at both ends of the expanding medium, at least one of the seal rings having a conical recess at a portion thereof confronting a cylindrical recess. The conical recess causes an additional bending moment on the seal ring, when the latter is compressed even by a strong expanding pressure, which in combination with the surface pressure resulted by the compression provides a larger radial deflection of the seal ring, thereby

to ensure against plastic flow and a consequent collapse of the expanding medium.

What is claimed is:

1. A tube expander having a tubular, elastic expansion medium having axially opposite end surfaces and adapted to be inserted into a tube which, through a radial expansion thereof, is adapted to be fixed to a tube plate; a pressurizing rod passing through said expansion medium; a pressurizing rod head provided at one end of said pressurizing rod; a back-up ring adapted to be supported by an end of said tube plate straddling a tube-receiving bore of said tube plate, said back-up ring being telescopically received by said pressurizing rod; and seal rings each disposed to abut respective ones of said end surfaces of said expansion medium, said seal rings being of an elastic material having a hardness greater than that of said expansion medium and telescopically received by said pressurizing rod, and at least one of said seal rings having a conical recess at its portion confronting the end surface of said expansion medium.

2. A tube expander as claimed in claim 1, wherein said seal ring closest to said pressurizing rod head has said conical recess.

3. A tube expander as claimed in claim 1, wherein seal rings at both sides of said expansion medium have said conical recess.

4. A tube expander as claimed in claim 3, wherein an auxiliary seal ring is disposed in said conical recess of said seal ring.

5. A tube expander as claimed in claim 4, wherein said auxiliary seal ring has a conical shape similar to that of said conical recess of said seal ring.

6. A tube expander as claimed in claim 1, wherein said conical recess increases in axial width radially inwardly from the outermost peripheral edge of each seal ring that provides the sole engagement between the sealing rings and expansion medium prior to expansion and further provides means for exerting a bending moment on said sealing ring so as to radially expand said peripheral edge to a greater extent than the remaining portions of said sealing rings, upon expansion of said expansion ring to effectively seal the annular gap between the sealing ring and the inner diameter of the tube during expansion of the tube against axial flow of the expansion medium between the sealing rings and the tube during expansion.

7. A tube expander as claimed in claim 6, further including an auxiliary ring telescopically received on said pressurizing rod with the inner diameter of said auxiliary ring being close to the outer diameter of said pressurizing rod, said auxiliary ring having a hardness greater than that of said expansion medium, having an outer diameter substantially less than the outer diameter of each of said sealing rings, and constituting means to seal the gap between the pressurizing rod and the adjacent sealing ring as the sealing ring expands outwardly to prevent flow of the expansion medium between the pressurizing rod and the seal ring during expansion.

8. A tube expander as claimed in claim 7, wherein said auxiliary seal ring has one axial face of complimentary shape to the adjacent face of said expansion medium, and an opposite axial face that is conical at an angle with respect to a plane perpendicular to said pressurizing rod to a lesser extent than the adjacent conical face of its seal ring.

9. A tube expander as claimed in claim 1, further including an auxiliary ring telescopically received on

7

said pressurizing rod with the inner diameter of said auxiliary ring being close to the outer diameter of said pressurizing rod, said auxiliary ring having a hardness greater than that of said expansion medium, having an outer diameter substantially less than the outer diameter of each of said sealing rings, and constituting means to seal the gap between the pressurizing rod and the adjacent sealing ring as the sealing ring expands outwardly

8

to prevent flow of the expansion medium between the pressurizing rod and the seal ring during expansion.
10. A tube expander as claimed in claim 9, wherein said auxiliary seal ring has one axial face of complementary shape to the adjacent face of said expansion medium, and an opposite axial face that is conical at an angle with respect to a plane perpendicular to said pressurizing rod to a lesser extent than the adjacent conical face of its seal ring.

15

20

25

30

35

40

45

50

55

60

65

Tube Enhancement Development

Several alternate processes are being evaluated in an effort to reduce the cost of enhanced tubing for heat exchangers.

During the course of the tube enhancement development program it was decided to investigate processes that required one piece tooling (i.e., male or female). This decision was reached due to the large number of corrugations required (36) and the apparent lack of available space for two piece tooling. As such, isostatic pressing was evaluated.

A male tool was made to the reverse geometry (i.e., desired contour of 36 flutes for production parts on I.D.) because of ease of fabricability (Figure A). A 5052-0 aluminum alloy tube was placed over the die and the ends sealed. The tube was then placed in an isostatic press and pressurized to 60,000 psi. The I.D. of the tube conformed to the outermost contour of the die but not the innermost portion. A cross-section of the resulting shape is shown in Figure B and an overall view shown in Figure C. It was concluded that higher pressures were required. The same procedure was repeated with commercially pure titanium. Very little forming was achieved, as anticipated, due to the higher strength of the titanium. Inasmuch as significantly higher pressures could not be achieved with commercially available isostatic presses, hot pressing was considered. By heating the material to 1500°F to 1800°F it was possible that, due to the lower strength of the material at temperature, the pressures available with existing facilities could be utilized to produce satisfactory results. To this end, superplastic forming (SPF) was evaluated.

The SPF process consisted of heating a die with the desired profile machined into one surface to approximately 1650°F and applying 600 psi pressure (the limit of the equipment). Using this technique the geometry produced is shown in Figures D and E. It was concluded from these efforts that still higher pressures were required to achieve total conformity to the die.

To obtain higher pressures, hot isostatic pressing (HIP) was evaluated. A die with the desired contour machined into one surface was completely encased in a titanium case, evacuated, and sealed. The encased die was then placed

in an isostatic press, the temperature raised to 1650°F and the pressure raised to 15,000 psi. The results are TBD (hopefully by Tuesday 10/19/78).

The production application of this process is envisioned as a multi-cavity heated die into which tubing is placed. The tube(s) will then be internally pressurized with argon gas thereby forcing the tube to conform to the die.

One of the methods employing two piece tooling that was evaluated was roll forming. This process utilizes opposed rolls which roll the corrugated contour into the sheet material. The formed sheet will then be rolled into a tubular shape and fusion welded. Figure F shows a cross-section of corrugated sheet with a 0.132 inch pitch which has been partially formed into a circular cross-section. To date, a pitch of 0.100 inches has been produced which results in 31 corrugations. Figure G shows a cross-section of the corrugations.




Figure A. Photograph of male die (Mag. 3x)




Figure B. Cross-section of 5052-0 Aluminum Tube After Isostatic Pressing at 60,000 psi (Mag. 3x)




Figure C. View of 5052-0 Tube Formed by Isostatic Pressing at 60,000 psi (Mag. 1-1/4x)




Figure D. View of the Contour Produced by SPF.




Figure E. Cross-section of Part Shown in Figure D (Mag. 10x)




Figure F. Flat Pattern With 0.132 Pitch Rolled Into a Tubular Cross-section (Mag. 5x)




Figure G. Cross-section of Corrugated Sheet With a Pitch of 0.100 Inches (Mag. 5x)

Toshiba High Heat Flux Titanium Tube

Toshiba Research and Development Center

Toshiba Metal Products Division

The generation of power from heat sources with low enthalpy, such as geothermal resources, sea water, low temperature water which is rejected from power stations and factories is becoming increasingly important.

As the energy extraction system mentioned above, fluid from geothermal wells, power stations and factories exchanges heat through a series of heat exchangers to a secondary fluid. For example, freon or isobutane is used. The fluid is evaporated and expanded to turn a turbine to generate electricity. The fluid is then cooled in a condenser using cooling water and then returned to the heat exchanger system.

In this system, the heat exchanger requires ten times more surface area than that of a thermal power plant, because of the low temperature difference between the heat source fluid and a secondary fluid, as well as because of the low heat conducting coefficient of the secondary fluid. According to a trial calculation of the system, the cost of the heat exchangers for 10-MW plant represents approximately 30 percent of the total plant equipment cost. Decreasing the heat exchanger cost is an important factor in the system development.

Toshiba high heat flux tube, introduced in the catalog has been developed for a binary cycle power generation system using hot geothermal water, sea water and so on. The developed process enables fabricating the tube surface in a contoured shape which consists of ridges and valleys for enhancement of heat transfer coefficient. For an example of condensing heat transfer, the appropriate contoured

surfaces utilize surface tension to push the condensate in the drainage channels, as was first pointed out by Gregorig, resulting in enhancing tube heat transfer coefficients. Tube characteristics are as follows:

High heat transfer coefficient

As the condensed film on the tube is pulled into the channels and becomes thinner due to spreading over the contoured surface, condensing heat transfer coefficient of the tube is 8 - 15 times higher than that of a flat tube.

No limitation to tube materials in fabricating the contoured surface

Not only aluminum, copper and their alloys, but also titanium and its alloys and stainless steels, which have superior corrosion resistance to geothermal hot water and sea water, which contains many of corrosive elements, such as Cl^- , SO_4^{--} , NH_4^+ and H_2S gas, can be fabricated into the contoured surface that enhances heat transfer coefficient. Especially, the latter two metals entail difficult fabrication properties.

Economy superiority

Plant cost and space are saved by making the heat exchanger compact.

1. Toshiba high flux tube production method

1.1 Toshiba's fabrication process

The process is illustrated in Fig. 1. First, the plate is cold rolled and the appropriate contoured surface is fabricated. Then,

the plate with the contoured surface is run out in a tubular shape by roll forming and welding.

A precise contoured surface with 1.0 mm pitch, suitable for enhancing heat transfer is obtained by the process. This precision manufacturing is difficult by ordinary fabrication process, such as machining, extrusion and drawing. The process is especially suitable for fabricating the contoured surface on titanium and its alloys and stainless steels.

1.2 Tube materials

Due to adoption of Toshiba's process, there is no limitation as to tube materials which can be used in fabrication of the contoured surface. The process is applied economically to titanium and its alloys and stainless steels.

1.3 Contoured surface

The contoured surface is decided by pitch, radius of curvature and depth, as shown in Fig. 2. Contoured surfaces, which are possible to fabricate on titanium and its alloy and stainless steels, are shown in the following.

Pitch	: 0.5 ~ 5 mm
Radius of curvature	: 0.1 ~ 3 mm
Depth	: > 0.3 mm

1.4 Tube types

Tubes with the contoured surfaces outside, inside (shown in Fig. 3A or B), or both sides (the so called doubly fluted tube), can be produced by the process.

2. Toshiba high heat flux titanium tube specifications

An example of the specification is shown in Table 1. The outer diameter of the tube produced in Toshiba is 8 mm to 50 mm.

3. Toshiba high heat flux titanium tube external appearance

Tubes are shown in Figs. 4A and B.

4. Toshiba high heat flux titanium tube contoured surface

The cross section of Toshiba high flux titanium tube with 1.0 mm and 1.5 mm in pitch, and 0.5 mm in depth are shown in Fig. 5A and B.

5. Toshiba high heat flux titanium tube heat transfer coefficient measurement results

Condensing heat transfer coefficients for tubes which have the same contoured surface as that shown in Figs. 5A and B, are shown in Fig. 6. Compared with a flat titanium tube, the condensing heat transfer coefficient for Toshiba high flux titanium tube is 8 to 15 times higher than that of a flat tube. Heat transfer coefficients were measured in Toshiba Research and Development Center in a vertical state.

6. Toshiba high heat flux titanium tube heat transfer enhancement mechanism

Condensed fluids flow on the contoured surface due to a combination of gravity and surface tension forces, as shown in Fig. 7. In an actual case, as the surface tension force in the horizontal direction is ten times larger than the gravity force in the vertical direction, the condensed fluids on the surface are pulled from the ridges to the valleys and flow in channels in the vertical direction.

For this reason, the condensed films become thinner, resulting in enhancing condensing heat transfer coefficients.

7. Applications

Home electric appliances

Condenser, evaporator for air conditioner

Heat pipes

Heavy electric appliances

Binary cycle power generation and solar sea power plant heat exchanger tube.

Vertical-multi-effect type desalination plant.




Fig. 1 Toshiba High Heat Flux Titanium Tube Fabrication Process.




Fig. 2 Contoured Shape






Fig. 3 Tube Types




(A) External Appearance




(B) Cross Section

Fig. 4 Toshiba High Heat Flux Titanium Tube




(A) Pitch .04 in., Depth: 0.2 in. x 25



(B) Pitch .06 in., Depth: .02 in. x 25


Fig. 5 Toshiba High Heat Flux Titanium Tube
Contoured Surface

Condensing Heat Transfer Coef. [kcal/m².h.°C]



Heat Flux [kcal/m².h]

(A)




(B)

(Temperature Difference Between Tube Surface and Saturated Freon 11 Fluid)

Fig. 6 Measurement Results of Heat Transfer Coefficients of Toshiba High Heat Flux Titanium Tube.


Condensed Film Thickness



Condensed Fluid Moving Direction

Flat Surface

Horizontal Direction Force due to Surface Tension Force



Condensed Fluid Moving Direction

Vertical Direction Force by Gravity Force

Contoured Surface

Fig. 7 Toshiba High Heat Flux Titanium Tube Heat Transfer Enhancement Mechanism

Table 1 Toshiba High Heat Fluex Titanium Tube Specifications.

Types	Dimension	Pitch (p)	Thickness (t)		Outer Diameter (D)	
			Max.	Min.	Max.	Min.
Types A and B	$1p \times 0.5t \times 25.4D$	1 ± 0.1	1 ± 0.06	0.5 ± 0.08	25.4	24.9
	$1.5p \times 0.5t \times 25.4D$	1.5 ± 0.1	1 ± 0.06	0.5 ± 0.08		
Type C	$1p \times 0.5t \times 25.4D$	1 ± 0.1				

Dimensions : mm

from
VGB KRAFTWERKSTECHNIK
Volume 56, No. 7

**Hydraulic Expansion
— a new method for
the anchoring of tubes**

H. Krips und M. Podhorsky

Production Programme

Steam Generators	for all capacities, pressures and temperatures to be installed in power stations for fossile fuels, in nuclear power plants, and for waste heat recuperation in industrial plants.
Firing Systems	for all fuels.
Heat Exchangers	to be installed in power stations as well as in chemical and petrochemical industries, for air conditioning and refrigerating systems.
Water Recooling Systems	designed as natural or mechanical draught wet or dry or combined (hybride) cooling towers, package cooling towers, industrial air coolers, complete cooling water supply systems.
Condensers	air-cooled or water-cooled.
Feedwater Tanks	and deaeration plants.
Air Heaters	fluo-gas-heated or steam-heated.
Sanitary and Domestic Equipment	heating systems, ventilation and air conditioning plants, pipework.
Pumps and Compressors	
Conveyor Systems	for furnace residues and bulk materials.
Low Pressure Fans	with low noise level, impeller dia. up to 26m.
Fin Tubes	made of steel or nonferrous metals.

Hydraulic Expansion — a new method for the anchoring of tubes

By H. Krips and M. Podhorsky*

The conventional method of mechanical rolling for expanding tubes into the tube plates of heat exchangers has for some time been the target of justified criticism both from engineers supplying the chemical industry and from those supplying equipment for nuclear plants. The joint between tube and tube plate is an important consideration, both from safety and from process engineering aspects. Pressure-tightness, shaping in the transition area between the anchoring zone and the unstressed tube, and proper sealing of the gap are all essential requirements for the reliability and life of valuable plant components. The conventional method of mechanical rolling expansion does not adequately meet these requirements.

INTRODUCTION

The mechanical deformation produced by rolling the tube walls results in stresses which cannot be accurately determined because of the inherent irregularities of the method. Such stresses make the tube susceptible to, or increase the risk of, corrosion. The end gap cannot be closed by rolling without risking shearing of the tube. Any improvement to this mechanical method can only be partially successful and thus one is compelled to look for a different method.

The hydraulic expansion method described below eliminates the inadequacies encountered in the past. The advantage of a hydraulic method rests in the fact that the working pressure of the liquid can be accurately determined. This affords the necessary consistency of a repetitive process, and thus allows tube anchorage calculations to be performed. Only a method whose results can be calculated beforehand will ensure adequate reliability of the equipment.

In almost all fields, development work leads to equipment of ever increasing unit size, with the number of heat exchanger tubes increasing as the square of the heat exchanger diameter. In view of the great number of tube anchorages, which may total several thousand in a single item of equipment, the reliability of this joint is of decisive importance. The bigger the item of equipment, the more important is its degree of availability, and this depends largely on the pressure-tightness of the individual tubes. Sufficient reliability of the equipment under all operating conditions can only be assured by tube joints meeting superior quality standards. Efforts to improve the quality of conventional mechanically rolled tube joints encounter limits due to physical factors. It is unlikely that substantial further progress will be made in this field in the foreseeable future.

Hydraulic expansion of tubes is a method which, although in its early days, has already yielded good results. Predictability, accurate consistency, ease of handling and the associated economy are major advantages of the hydraulic method. Like rolling, it can be combined with a welding operation. A combination of the hydraulic and mechanical methods might be an interesting proposition for certain designs.




Fig. 1. Diagram of the tube-expansion installation.

- Sekundärbereich = Secondary section
- Primärbereich = Primary section
- Füllen = Fill
- (Sekundärraum) = (secondary space)
- Aufweiten = Expand
- Entlasten = Relieve
- (Druckausgleich) = (pressure equalization)

DESCRIPTION OF THE METHOD

Hydraulic expansion differs from all other known anchoring methods in that the tube is plastically deformed simply by means of a pressurized liquid. Under the pressure exerted by this liquid, the tube material flows until it reaches the wall of the bore. By increasing the pressure further, the tube is pressed against the wall of the receiving bore. The pressure is increased until the bore has been so deformed that the tube disc will lock permanently around the tube as a result of the elastic recovery of the disc when the pressure is removed. The tube expander is simple and neatly arranged as can be seen from Figure 1. It consists of probe 1, pump 2, booster 3, pressure gauge 4, overflow valve 5, hydraulic fluid tank 6 and control valve 7. A mobile tube expander is shown in Figure 2.




Fig. 2. Mobile tube expander.

* Oberingenieur H. Krips and Dr.-Ing. M. Podhorsky, Balcke-Dürr AG, Bochum..




Fig. 3. Deformation during the expansion operation.
 Flüssigkeitsdruck = Liquid pressure
 Flüssigkeitsvolumen = Liquid volume

The probe 1 inserted in the tube is provided with two sealing elements which limit the range of expansion. Before expansion can commence, the secondary section must be filled with liquid and the booster 3 pushed into its initial position. This is achieved by actuating the control valve 7. The high-pressure pump 2 generates the primary pressure required to operate the equipment. The booster 3 intensifies this pressure to the secondary pressure level required for the tube expansion operation. Since the pressure intensification ratio of the booster is constant, the final pressure in the secondary section must be set by limiting the pressure in the primary section.

The operating pressure in the secondary section is checked by means of pressure gauge 4, which is connected to the primary section. The primary pressure is set by means of overflow valve 5. As soon as the desired maximum pressure has been reached, the overflow valve 5 discharges liquid from the primary section into tank 6. To enable the probe to be withdrawn from the expanded tube, control valve 7 must be operated in order to equalize the pressure between the secondary space and the tank 6.

Figure 3 illustrates the deformation of the tube and tube disc during the expansion operation. The amount of pressurized liquid introduced is a function of the proportions of elastic and plastic expansion occurring in the tube and tube disc. In zone a), the tube is stressed elastically until the yield point is reached. In zone b), the tube material flows until it has bridged the gap between the outside diameter of the tube and the wall of the receiving bore. This plastic flow is usually accompanied by a strain-hardening effect and is reflected in the upward slope of the pressure curves. On reaching zone c), the tube bears against the wall of the receiving bore. From this point onwards, the tube undergoes further plastic deformation, and the tube plate now deforms elastically. The final pressure of zone c) is calculated on the basis of the material selected, the tube disc geometry and the desired adhesion pressure, and it is set on overflow valve 5.

Figure 4 a shows the zone of contact between an expanded tube and the wall of the receiving bore. The roughness of the bore wall and that of the tube surface determine the extraction force. Where a greater extraction force is required, the wall of the hole is provided with a shallow circular recess. The depth of this groove is no more than a few tenths of a millimetre. A tube expanded into a recessed hole is shown in Figure 4 b. This shows clearly how accurately the tube has been formed to the shape of the receiving bore under the high hydraulic pressure applied. The recess is pro-




Fig. 4. Expanded tube.
 a) in a straight-walled bore
 b) in a recessed bore

duced in a manner similar to that employed for rolled grooves except that the cutting tool used has very mild contours.

ADVANTAGE OF THE EXPANSION DEVICE

The pressure probe can be inserted into the tubes without damaging them. The device is easy to handle and move (Figure 5). The insertion depth can be accurately fixed. Operation is by means of a simple lever (Figure 6).

The expansion operation as such does not take more than a few seconds. The probe can be pulled out with ease after the pressure has been removed. The useful life of the sealing elements is, of course, limited.




Fig. 5. Hydraulic expansion device.




Fig. 6. Handling of the expansion plant.

Replacing these elements is, however, neither difficult nor time-consuming. Each expansion operation verifies at the same time the existence of proper adhesion in the respective tube joint, because adhesion between the tube and the receiving bore is determined exclusively by the selected pressure, which can be checked on the pressure gauge. Check measurements of the diameter of the expanded tube are not only superfluous, but might even lead to wrong conclusions. Thus, with a wall thickness of 2.9 mm, a spacing of 30 mm and a calculated adhesion pressure of 728 bar (see numerical example), an inaccuracy of no more than 0.002 mm in the measurement of the inside diameter would result in an error of 10%.

Since no mechanical tool is involved in deforming the tube, the material will naturally adopt the shape having least internal stress. Bores with adhering revolving shafts are no exception to this rule. This property is of great importance for all materials susceptible to stress corrosion cracking.

The expansion zones can be accurately defined. This permits the gap between tube and tube plate to be avoided, even at the end of the receiving bore on the inner side of the tube plate, the expansion zone being located at the end of the bore. In conventional roll-expanded tube joints the tubes could not be expanded to the end of the bore without risking damage, and thus gaps were left as potential nests of corrosion.

No additional tools are required in cases where contact between tube and tube plate is to extend over great lengths in order to preclude the formation of a heat-insulating gap or to assure continuous adhesion. The difference in time required for expanding a short or long section is negligible.

In tubes which are anchored in two fixed tube plates, axial stresses are produced both in the case of hydraulic expansion and in the case of mechanical roll expansion. These in-

cluded stresses produce a load on the tube disc. However, the axial stresses produced by hydraulic expansion and those produced by mechanical roll expansion act in opposite directions. Consequently, if hydraulic expansion and mechanical roll expansion are employed in an appropriately matched combination, it is now possible to anchor tubes in apparatus having two fixed tube plates with balanced stress or a predetermined amount of prestress.

The economy of the new method can only be assessed by comparing it with the conventional roll-expansion method, although the two methods and the different results achieved by them can hardly be compared.

Assuming, for the sake of comparison, that the two methods produce the same effect, the costs of hydraulic tube expansion are slightly lower than those of rolling in two steps, because a comparison clearly favours the hydraulic method as soon as the length to be rolled exceeds 30 mm.

TUBE ANCHORAGE CALCULATION

The hydraulic method provides a clear basis for calculating the expansion pressure required to achieve a desired adhesion pressure.

The adhesion pressure is a measure of the force preventing the tube plate from being extracted from the bore. For the purposes of the following calculation, adhesion pressure will be substituted for the previously used criterion of adhesive expansion.

The thick-walled tube under conditions of dynamically balanced surface loading

Hydraulic expansion produces a dynamically balanced stress field first in the tube and later, approximately, in the tube plate also.

Assume that the longitudinal stress is equal to zero (plane stress). The equilibrium equations for the element are thus considerably simplified. Taking advantage of the convenience afforded by polar coordinates, we have:

$$\frac{d}{dr} (r \cdot \sigma_r) - \sigma_\theta = 0 \quad (1)$$

The stress-strain relationships are:

$$\epsilon_r = \frac{dw}{dr} = \frac{1}{E} (\sigma_r - \mu \cdot \sigma_\theta) \quad (2)$$

With the stress function F and the stresses

$$\begin{aligned} \epsilon_\theta &= \frac{w}{r} = \frac{1}{E} (\sigma_\theta - \mu \cdot \sigma_r), \\ \sigma_r &= \frac{1}{r} \frac{dF}{dr} \\ \sigma_\theta &= \frac{d^2 F}{dr^2} \end{aligned} \quad (3)$$

the equilibrium condition (1) is fully satisfied. We must therefore apply the compatibility condition

$$\frac{d}{dr} (r \cdot \epsilon_\theta) - \epsilon_r = 0 \quad (4)$$

With (2) and (3), we obtain the homogenous differential equation

$$\frac{d^2 F}{d r^2} + \frac{1}{r} \frac{d F}{d r} - \frac{1}{r^2} \frac{d F}{d r} = 0 \quad (5)$$

the solution of which can be written as follows:

$$F = A \cdot \lg r + C r^2 \quad (6)$$

The constants A and C are determined from the limiting conditions in accordance with Figure 7. The following applies:

$$\sigma_{r_i} = -p_i \quad \sigma_{r_a} = -p_a \quad (7)$$




Fig. 7. Loads acting on a tube.

Using (3) and (6) the constants can be expressed as:

$$A = \frac{r_i^2 \cdot r_a^2 (p_a - p_i)}{r_a^2 - r_i^2}; \quad C = \frac{1}{2} \frac{p_i r_i^2 - p_a r_a^2}{r_a^2 - r_i^2} \quad (8)$$

The stresses can then be expressed as follows:

$$\begin{aligned} \sigma_r &= \frac{r_i^2 \cdot r_a^2 (p_a - p_i)}{r_a^2 - r_i^2} \frac{1}{r^2} + \frac{p_i r_i^2 - p_a r_a^2}{r_a^2 - r_i^2} \\ \sigma_\phi &= -\frac{r_i^2 \cdot r_a^2 (p_a - p_i)}{r_a^2 - r_i^2} \frac{1}{r^2} + \frac{p_i r_i^2 - p_a r_a^2}{r_a^2 - r_i^2} \end{aligned} \quad (9)$$

The stresses are simplified for $p_a = 0$:

$$\begin{aligned} \sigma_r &= \frac{r_i^2 \cdot p_i}{r_a^2 - r_i^2} \left(1 - \frac{r_a^2}{r^2}\right) \\ \sigma_\phi &= \frac{r_i^2 \cdot p_i}{r_a^2 - r_i^2} \left(1 + \frac{r_a^2}{r^2}\right) \end{aligned} \quad (10)$$

and for $p_i = 0$:

$$\begin{aligned} \sigma_r &= -\frac{r_a^2 \cdot p_a}{r_a^2 - r_i^2} \left(\frac{r_i^2}{r^2} - 1\right) \\ \sigma_\phi &= -\frac{r_a^2 \cdot p_a}{r_a^2 - r_i^2} \left(\frac{r_i^2}{r^2} + 1\right) \end{aligned} \quad (11)$$

Up to this point, we have only considered the behaviour of the tube within the elastic range. Hydraulically expanded tubes

are, however, deliberately deformed plastically. To calculate the load-bearing capacity and behaviour of the tube in the elastic-plastic and plastic ranges, we need a formula for plastic flow. For the purposes of the following calculations, we will use the formula developed by Mises which expresses plastic flow as follows:

$$\sigma_F = \sqrt{3} \cdot \sqrt{I_2(\sigma)} \quad (12)$$

For the plane stress condition assumed, we can express the load due to internal pressure as follows:

$$\begin{aligned} \sigma_F &= \sqrt{\sigma_r^2 - \sigma_r \cdot \sigma_\phi + \sigma_\phi^2} = \\ &= \frac{p_i r_i^2}{r_a^2 - r_i^2} \sqrt{3 \left(\frac{r_a}{r}\right)^4 + 1} \end{aligned} \quad (13)$$

The internal pressure at which the inner fibre of the tube yields can be calculated from (13):

$$p_i^i = \frac{\sigma_F (u^2 - 1)}{\sqrt{3 \cdot u^4 + 1}} \quad (14)$$

A further increase in the internal pressure will cause the plastic zone to extend outwards. The outer fibre is reached as a pressure of:

$$p_i^a = \frac{\sigma_F}{2} (u^2 - 1) \quad (15)$$

The radial shift in the elastic range is calculated from (2) for the load due to p_i :

$$w = \frac{p_i \cdot r}{E} \cdot \frac{1 + \mu}{u^2 - 1} \cdot \left[\left(\frac{r_a}{r}\right)^2 + \frac{1 - \mu}{1 + \mu} \right] \quad (16)$$

and for p_a :

$$w = -\frac{p_a \cdot r}{E} \cdot \frac{1 + \mu}{1 - \frac{1}{u^2}} \cdot \left[\left(\frac{r_i}{r}\right)^2 + \frac{1 - \mu}{1 + \mu} \right]$$

For further considerations, the shift of the outer fibre of the tube significant. If $r = r_a$, then

$$(w)_{r=r_a} = \frac{2 \cdot p_i \cdot r_a}{E \cdot (u^2 - 1)} \quad (17)$$

$$(w)_{r=r_a} = -\frac{p_a \cdot r_a}{E} \left(\frac{u^2 + 1}{u^2 - 1} - \mu\right)$$

and for $p_i = p_i$ we have:

$$(w)_{r=r_a} = \frac{2 \cdot \sigma_F \cdot r_a}{E \cdot \sqrt{3 \cdot u^4 + 1}} \quad (18)$$

Thus for $p_i = p_i^a$:

$$(w)_{r=r_a} = \frac{\sigma_F \cdot r_a}{E} \quad (19)$$

Sample calculation for a tube plate

To obtain a simple analytical solution, we simplify the tube plate geometry as shown in Figure 8. We assume that deformation is limited to that part of the plate which is located within the inscribed circle R_a . Strain measurements performed on a test block have confirmed that this assumption




Fig. 8. Simplified tube plate geometry.

yields useful results (Figure 9). Since the aim of the expanding operation is to achieve a permanent contact pressure between the tube and the receiving bore in the tube plate, the following requirement must be satisfied when the pressure has ceased to rise:

$$[(w)_r=r_b] p_i \leq [(w)_{R=R_i}] (p_i - p_i^*) \quad (20)$$

After applying the formula derived above, this inequality yields:

$$p_i > \frac{2 \cdot \sigma_{FR}}{\sqrt{3 \cdot u_R^4 + 1}} \cdot \frac{u_p^2 - 1}{u_p^2 (1 + \mu) + 1 - \mu} + \frac{\sigma_{FR} (u_R^2 - 1)}{2} \quad (21)$$

The right-hand side of equation (21) is called the limiting pressure p_o . It represents the pressure p_i at which the recovery of the tube sheet is equal to the recovery of the tube. In Figure 10, the limiting pressure referred to the yield point of the tube is plotted as a function of the radii. The curve $u_p = 1.0$ shows the specific expansion pressure (p_i^*/σ_{FR}) of the tube, and the curve $u_p = \infty$ shows the relationships in an infinite plate with a single bore.

The following requirement must be satisfied if we wish to avoid plastic deformation of the material between the bores in the tube plate:

$$\left[p_i - \frac{\sigma_{FR} \cdot (u_R^2 - 1)}{2} \right] \cdot \frac{u_p^2 + 1}{u_p - 1} \leq \sigma_{FP} \quad (22)$$

With $p_i = p_o$ and appropriate transformation, we obtain:

$$\frac{p_o}{\sigma_{FR}} \leq \frac{\sigma_{FP}}{\sigma_{FR}} \cdot \frac{u_p^2 - 1}{u_p^2 + 1} + \frac{u_R^2 - 1}{2} \quad (23)$$




Fig. 9. Stress variation in the bore.




Fig. 10. Specific limiting pressure plotted against tube and tube plate geometry.

$\frac{\delta_{FP}}{\sigma_{FR}} = 0.8$ and 0.6 is shown in Figure 10.

With a yield limit condition of $\delta_{FP} - \delta_{FR} < 1$, there are geometries which are so unfavourable that the limiting pressure cannot be reached without the yield point in the tube plate being exceeded.

This limitation of the geometry for

$$\frac{\delta_{FP}}{\delta_{FR}} = 0.8 \text{ and } 0.6$$

is shown in Figure 10.

A very important question which we will now attempt to answer is that of the adhesion pressure persisting between tube and receiving bore under no-load conditions.

According to (16), the expansion of the tube due to the adhesion pressure p_H is

$$w_R = - \frac{p_H \cdot r_b}{E} \cdot \frac{1 + \mu}{1 - \frac{1}{u_R^2}} \left(\frac{1}{u_R^2} + \frac{1 - \mu}{1 + \mu} \right) \quad (24)$$

and that of the tube plate

$$w_P = \frac{p_H \cdot R_i}{E} \cdot \frac{1 + \mu}{u_p^2 - 1} \left(u_p^2 + \frac{1 - \mu}{1 + \mu} \right) \quad (25)$$

The expansion of the tube plate model due to the pressure component ($p_i - p_o$) is:

$$w_P^* = \frac{(p_i - p_o) \cdot R_i}{E} \cdot \frac{1 + \mu}{u_p^2 - 1} \cdot \left(u_p^2 + \frac{1 - \mu}{1 + \mu} \right) \quad (26)$$

for $R_i = r_b$, the contact formula

$$w_P^* = w_P - w_R \quad (27)$$

after substitution of the terms (24), (25) and (26) and brief transformation, yields:

$$\frac{p_H}{p_i - p_o} = \frac{1}{1 + \frac{(u_p^2 - 1)}{(u_R^2 - 1)} \cdot \left[\frac{u_R^2 (1 - \mu) + 1 + \mu}{u_p^2 (1 + \mu) + 1 - \mu} \right]} \quad (28)$$




Fig. 11. Specific adhesion pressure plotted against tube and tube plate geometry.

In this calculation, the modulus of elasticity of the tube plate has been equated to that of the tube. The formula (28) is graphically represented in Figure 11 for $\mu = 0.3$. The extraction force for the tube can then be theoretically calculated as

$$P_R = 2 \cdot \pi \cdot r_s \cdot L \cdot p_H \cdot \bar{f} \quad (29)$$

Critical comments on the term "adhesive expansion"

In conjunction with the common method of anchoring tubes in a tube plate or similar bodies by mechanical roll-expansion, adhesive expansion is presented as the one and only criterion for the quality of the rolled joint. The approximate values specified for different tube materials in the tube rolling manufacturers' catalogues disregard tube geometry and the clearance between tube and receiving bore. Adhesive expansion is expressed as

$$H = \frac{d_{iA} - D + 2s}{s} \cdot 100 \quad (30)$$

By substituting $(D - d_{iA}) = 2s_A$, we have

$$H = 2 \cdot \left(1 - \frac{s_A}{s}\right) \cdot 100. \quad (31)$$

We shall now examine the behaviour of the tube during the rolling process (Figure 12). The tube expands nonuniformly and contacts the wall of the receiving bore. At this stage, it is not yet possible to create a permanent joint between tube and tube plate. Since the volumes are equal before and after contact, it follows that




Fig. 12. The tube before and after the rolling operation.

$$\frac{d_i + d_e}{2} \cdot s \cdot L = (d_e + \delta - s_A) \cdot s_A \cdot L - \Delta \cdot s \cdot \frac{d_i + d_e}{2} \quad (32)$$

which leads to the quadratic equation

$$s_A^2 - s_A (d_e + \delta) + s \cdot \frac{d_i + d_e}{2} \left(1 + \frac{\Delta}{L}\right) = 0 \quad (33)$$

and the solution to this is:

$$s_A = \frac{d_e + \delta - \sqrt{(d_e + \delta)^2 - 4(d_e - s) \cdot \left(1 + \frac{\Delta}{L}\right) \cdot s}}{2} \quad (34)$$

Substitution of this term in (31) yields an apparent adhesive expansion of

$$H^* = \left\{ 2 - \left[\frac{d_e + \delta}{s} - \sqrt{\left(\frac{d_e}{s}\right)^2 + 2 \frac{d_e}{s} \cdot \frac{\delta}{s} - 4 \left(\frac{d_e}{s} - 1\right) \left(1 + \frac{\Delta}{L}\right)} \right] \right\} \cdot 100 \quad (35)$$

Owing to the elongation of the tube during rolling, Δ is negative. The change in tube length depends on several parameters and is unknown for most practical applications. If Δ/L as to 1 in (35) is ignored, the apparent adhesive expansion can be represented graphically. As can be seen from Figure 13, this apparent adhesive expansion depends on the tube geometry and clearance. The value of H^* as the clearance increases. The clearance will, however, usually differ from one tube - bore pair to another, which explains the variations of adhesive expansion. The definition of adhesive expansion is obviously unsatisfactory and unreliable. Instead of adhesive expansion, which depends on geometry and clearance, the hydraulic tube expansion method relies on an accurately measurable parameter, namely internal pressure which guarantees uniform tube anchoring for all tubes.

Numerical example

Tube of Incoloy 800, tube plate of 22 NiMoCr 37, triangular spacing 30 mm.

$$\sigma_{FR} = 475 \text{ N / mm}^2$$

$$\begin{aligned} d_i &= 16.2 \text{ mm} \\ d_e &= 22 \text{ mm} \\ D_i &= 23.1 \text{ mm} \\ D_e &= 36.9 \text{ mm} \\ U_R &= 1.358 \\ U_P &= 1.5974 \end{aligned}$$




Fig. 13. Apparent adhesive expansion.

From Figure 10, we have for $u_p = 1.0$:

$$\frac{P_o}{\sigma_{FR}} = 0.42$$

Accordingly, the pressure at which the plastic zone has reached the outer fibre of the tube is

$$p_i^0 = 0.42 \cdot 475 \cdot 10 = 1995 \text{ bar.}$$

From Figure 10, we find for the actual tube sheet geometry

$$u_p = 1,5974$$

$$\frac{P_o}{\sigma_{FR}} = 0,654$$

The limiting pressure is then

$$p_o = 0.654 \cdot 475 \cdot 10 = 3106 \text{ bar.}$$

From Figure 11, we read off the adhesion pressure which persists after the load has been removed:

$$\frac{P_R}{P_i - p_o} = 0.457$$

For example, for $p_i = 4700 \text{ bar}$:

$$p_H = 0.457 (4700 - 3106) = 728 \text{ bar.}$$

EXPERIMENT

A number of experiments have been performed to support the theory presented above. One of these experiments will be described and discussed below.

Ten 420 mm long tubes of 22 mm dia \times 2.9 mm, made of Incoloy 800, were inserted in a 320 mm thick test block of 22 NiMoCr 37 material. The geometry of the holes and tubes was recorded in three planes.

The pressure applied to expand the tubes ranged between 1950 and 2050 bar. The expansion zone started at a distance of 25 mm from the face of the test block and ended 2 mm behind the rear edge of the test block.

Different final pressures were applied to bring the tubes into contact with the walls of the receiving bores. The change in tube geometry, the reduction in tube length, pressure-tightness and the force required to pull the tube from its receiving bore (extraction force) were measured on completion of the test.

A leak rate of less than $1 \cdot 10^{-7} [\text{torr} \cdot 1 \cdot \text{s}^{-1}]$ was verified by a leak test with helium. All of the measured values are plotted graphically in Figure 14. The interdependence of certain parameters is clearly apparent from the graph.

Of particular interest is the relationship between the extraction force, the adhesive expansion and the adhesion pressure P_H calculated in accordance with equation (28). The extraction force P , as well as the positive difference between the adhesive expansion H defined in (30) and the apparent adhesive expansion H^* increase with increasing adhesion pressure. This confirms the theory developed above and proves its usefulness in practice. The small extraction forces for tubes 1 and 3 which, according to the theory, ought to be zero are due to inaccuracies of the hole geometry in the longitudinal direction of the hole. Figure 14 proves the justification of the term "apparent adhesive expansion" and shows




Fig. 14. Test results. Relationship between the actual adhesive expansion and the hydraulic pressure applied.
 Rohr-Nr. = Tube No.

how unreliable a check of the joint between tube and tube sheet based on "adhesive expansion" actually is. The strong influence of clearance on apparent adhesive expansion agrees with (35).

PROBLEMS INVOLVED IN STRESS-FREE TUBE ANCHORING IN STRAIGHT-TUBE HEAT EXCHANGERS OR SIMILAR EQUIPMENT WITH TWO FIXED TUBE PLATES

As already mentioned, tubes can be anchored stress-free in tube plates if the hydraulic expansion method is combined with a suitable rolling method, taking advantage of the relationships existing between tube length reduction and clearance in the case of hydraulic expansion and between tube elongation and roller setting in the subsequent rolling operation. These two characteristics can be easily determined by means of a simple pilot test, as shown in Figure 15. It is logical that we shall always endeavour to exactly balance out the reduction in tube length by tube elongation.




Fig. 15. Change in tube length as a function of roller setting and clearance between tube and tube plate.

- | | |
|-------------------------------------|---------------------------------|
| Rohre \varnothing 23 \times 1,5 | = Tubes 23 mm dia. \times 1.5 |
| Werkstoff: 1.4523 | = Material: 1.4523 |
| Teilung: 30 mm | = Spacing: 30 mm |
| Aufweitstrecke: 239 mm | = Hydr. expanded length: 239 mm |
| Walzstrecke: 70 mm | = Rolled length: 70 mm |
| Walzen | = Rolling |
| Aufweiten | = Hydr. expanding |
| Walzeinstellung | = Roller setting |
| Spiel | = Clearance |
| Seite I | = Side I |
| Seite II | = Side II |




Fig. 16. Test apparatus with two fixed tube plates. Tube 290 dia./230; EF 18 material Tube 280 dia./200; 17 MnMoV 64 material.
 Dehnmeßstreifen 3/120 LY in Längsricht. a.d. Röhren Nr. 1-6 mittig zw. Block u. Leitblech
 = Strain gauges 3/120 LY, longitudinally applied to Tubes Nos. 1-6 centrally between block and fin.
 6 Röhre Ø 23 x 15 mm
 = 6 tubes 23 dia. x 1.5 mm
 Werkst.: 1.4523 = Material 1.4523
 Teilung: 30mm = Spacing: 30 mm
 Ansicht „x“ = View "X"
 vpr dem Aufweiten = Prior to hydraulic expansion
 Aufweitstrecke = Expanded lengths
 nach dem Aufweiten = after hydraulic expansion
 nach dem Walzen = after rolling




Fig. 17. Results of the extension measurement.
 Seite I = Side I
 Seite II = Side II
 Aufweiten = Expansion
 Walzen = Rolling
 Endzustand = Final condition
 Rohr-Nr. = Tube No.
 Meßstellen an Seite I = Measuring points on side I
 Meßstellen an Seite II = Measuring points on side II
 Spiel = Clearance (mm).

We cannot influence the reduction in tube lengths, because it depends exclusively on the clearance. However, the roll setting of the rolling controller and the rolled lengths are variables which, if appropriately selected, will enable us to achieve any desired prestress of the tube, including the special case of stress-free anchorage. Of course, certain tolerances of hole and tube diameter must be expected even in one and the same heat exchanger or similar equipment. It is impossible to measure all bores and associated tubes and then select the required roll setting or rolled length to suit the actual clearance. What we can do, however, is select a statistically representative number of bores and tubes, measure these and then calculate the representative bore diameter, outside diameter of tube and the clearance between tube plate and tubes on the basis of simple drillmatic averages. According to the law of probability, the sum of the tube forces divided by the number of tubes can be expected to yield the desired prestress in the tube, or zero in the case of stress-free anchorage.

To support this theory, a test was performed in which the axial stresses existing in the tubes were measured by means of strain gauges. The test apparatus is shown in Figure 16; the stresses measured after each operation are plotted in Figure 17. It was endeavoured to anchor the tubes in a balanced stress configuration. The expansion zone started at a distance of 30 mm from the face of the tube sheet and ended at the end of the tube emerging from the tube plate. The hydraulic pressure to be applied to expand the tubes was fixed

at 2500 bar. After hydraulically expanding Side I the same side was rolled in three steps, employing the step rolling method (see Figure 16). During this process, the tube was pushed out and a joint was obtained between tube and plate with no gap and balanced stresses. The tubes were then also anchored in the same sequence in Side II.

In the final state (figure 17), the tubes 2 and 5 are subjected to a slight tensile stress while the tubes 1,3,4 and 6 are then subjected to compressive stress. It can be seen that the result is very close to the zero limit which we desired. We can safely assume that with a greater number of tubes the deviation would have been even less.

CONCLUSION

Compared with the conventional method of mechanical roll expansion, the hydraulic method of expanding tubes in tube plates offers numerous advantages which have been discussed in this article. The method is particularly suitable for heat exchangers or similar equipment and tube joints which must satisfy exacting requirements in terms of quality and uniformity of the joint, such as steam generators for nuclear power stations, high and low-pressure feed water heaters for conventional power stations and equipment for the chemical industry. The method presented in this article will enable designers of such equipment to calculate the required expansion pressure in a simple manner. By combining the hydraulic method with mechanical roll expansion for heat exchangers or similar equipment with two fixed tube plates, we can now influence the prestress in straight tubes, although this was previously not possible. This aspect will be found particularly interesting in connection with heat exchangers or other equipment subject to thermal stresses in operation.

SYMBOLS AND ABBREVIATIONS

- σ = stress
- ϵ = strain
- r = radial coordinate of the tube
- R = radial coordinate of the tube plate model
- d = tube diameter
- D = hole diameter
- s = tube wall thickness
- E = modulus of elasticity
- μ = Poisson' ratio
- w = radial displacement
- F = stress function
- p = pressure
- I_2 = second invariant of stress condition
- $D\sigma$ = stress deviator
- u = ratio of radii (outside/inside)
- Δ = reduction in tube length

- L = expanded length
- f = coefficient of friction
- δ = clearance between tube and bore
- H = adhesive expansion

INDICES

- r = radial direction
- \emptyset = peripheral direction
- i = inside
- a = outside
- F = yield limit
- H = adhesion pressure
- P = tube plate
- R = tube
- A = after rolling or hydraulic expansion

LITERATURE

- [1] Lehmann, T.: Elemente der Mechanik, Bertelsmann Universitätsverlag, Düsseldorf 1974.
- [2] Timoshenko, S.P.: J.N. Goodier: Theory of Elasticity, Mc Graw-Hill Book Company 1970.
- [3] Strohmaier, K.: Beitrag zur Berechnung zylindrischer Mehr-lagenbehälter für statische Innendruckbelastung, Konstruktion 1974, pages 187-191 and 217-223.
- [4] Schweigener, S.: Festigkeitsberechnung von Bauelementen des Dampfkessel-, Behälter- und Rohrleitungsbaues. Springer 1970, Berlin-Heidelberg-New York.
- [5] Dunker, H.W.: Festigkeit von Rohreinwalzungen in Rohrböden. Chem.-Ing.-Technik 1951, Nr. 17/18.
- [6] Güllich, J.F.: Bedeutung der thermohydraulischen Verhältnisse für die Korrosionssicherheit von DWE-Dampferzeugern. Atomwirtschaft, February 1975.
- [7] Spähn, Wagner, and Steinhoff: Formen, Bedeutung und Erscheinungsbild der Spannungsrißkorrosion. TÜ 14 (1973).
- [8] Söhngen, and Faulstich: Festigkeitsuntersuchungen von eingeschweißten Rohren in Rohrböden und Wärmeaustauschern. Schweißen und Schneiden, H. 9, 1964.
- [9] Stückrad, J.: Zur Rohr/Rohrboden-Verbindung an Wärmeaustauschern. Chemiker-Ztg./Chem. Apparatur, 90, Volume 1966, No. 17.
- [10] Krägeloh, E.: Die Beanspruchung von Lochreihen und die Auswirkung eingewalzter Rohre. Konstruktion 18 (1966), H. 5.
- [11] Siebel, E.: Walzverbindungen. Stahl und Eisen, H. 47 (1933).
- [12] Class, I.: Überblick über das Gebiet der Spannungsrißkorrosion. Werkstoffe und Korrosion, H. 4, 1965.
- [13] Class, I.: Spannungskorrosionsartige Erscheinungen an mechanisch-beanspruchtem Stahl durch diffundierenden Wasserstoff. Werkstoffe und Korrosion, H. 5, 1955.
- [14] Möller, W., and Wenzel, H.: Werkstoff- und Fertigungsfragen bei der Herstellung von Geradrohrdampferzeugern. VGB KRAFTWERKSTECHNIK 56 (1976), H. 4.
- [15] Schopf, A.: Dampferzeuger in U-Rohr-Bauweise für Kernkraftwerke und ihre Fertigung. VGB KRAFTWERKSTECHNIK 56 (1976), H. 3, p. 137-143.

R. L. BEYNON & ASSOCIATES

166 Santa Clara Avenue
Oakland, California 94610
Telephone (415) 444-7795

**BALCKE-DÜRR
AKTIENGESELLSCHAFT**

D-4030 Ratingen 1
Postfach 1240
Telefon (02102) 2001
Telex 08585113

D-4630 Bochum 1
Postfach 100210
Telefon (0234) 6171
Telex 0825808

D-6710 Frankenthal
Postfach 227
Telefon (06233) 6011
Telex 0465228

With effect from end of 1977 please contact our Ratingen office.

D-46

APPENDIX D.2
EROSION AND CORROSION CONTROL

INTEROFFICE CORRESPONDENCE

TO: L. A. Rosales

CC: T. C. Dvorak
J. S. Hicks
M. Kwan5515.2.78-416
DATE: August 24, 1978

SUBJECT: Tube Sheet Coating and Corrosion Allowance

M.P. Bianchi
FROM: M. P. Bianchi
BLDG. 01 MAIL STA. 2230 EXT. 52303

In answer to your request to obtain more information on the neoprene coating used to protect the British Power generating station's condenser tubeplates and waterboxes from saltwater corrosion and silt erosion shown in the April 1978 issue of DuPont's "Elastomers Notebook", I have obtained the following:

1. The manufacturer of the coating is:

Protective Rubber Coatings (Bristol), Ltd
Payne's Shipyard, Coronation Rd
Bristol, England BS 31RP

2. The coating is called "Limpetite" and it is a neoprene coating.

3. The manufacturer has found that at the saltwater-cooled Portishead installation a 1/16-inch coating on the tubeplates, waterboxes, valves, etc. has shown an indefinite life; that is, no degradation other than mechanical damage (the coating is repairable) from maintenance work over the 32 years it has been in service.

4. On that basis, no corrosion allowance is needed and in the U.K. all present power stations under construction will use "Limpetite".

5. Tube entries were also coated for an initial length of three inches with the coating thickness tapering from 0.20 inch to 0 inch. The life of the entry coating at Portishead has been seven years and is extended for one inch every recoat to a maximum of six inches from the end of the tubes.

6. Impressed current cathode protection is not and should not be used with the coating.

August 24, 1978

Page two

7. The surface preparation is by grit-blasting to white metal followed by a brush application of the primer. The coating is then applied with brush or roller in 22 coats to a nominal 1/16-inch final thickness. The process is continuous and the curing time a minimum of ten days.
8. According to their Managing Director, Mr. J. H. Payne, "Limpetite" is not available in the U.S. and, as far as they are concerned, there are no comparable coatings both in the U.S. and the U.K.

Mr. Payne made reference in his Telex of the Central Electricity Generating Board Construction Division in Barnwood, Gloucester, and I am writing them for any further information they may have on this coating.

MPB:cd

Tel. 861344
S.T.D. Code 0272

Telegrams:
Limpetite, Bristol



Directors
W. H. Payne, F.W.I. (Chairman)
J. H. Payne, M.W.I. (Managing)
B. C. Payne
C. R. Tottle

PROTECTIVE RUBBER COATINGS (BRISTOL) LTD

PAYNE'S SHIPYARD CORONATION ROAD
BRISTOL BS3 1RP

Your Ref.

Our Ref. JHP/PAH

4th September, 1978.

M.P. Bianchi Esq.,
TRW Defense & Space Systems Group,
Building 01,
Room 2230,
One Space Park,
Redondo Beach,
California 90278,
U.S.A.

★

*Liquid applied, Air
cured Synthetic Rubber
Coatings*

for protection of all metals
against corrosion, erosion
and electrolytic action. Ap-
plied in liquid, putty or
sheet form.

★

Electricity Generating

Coatings for main condens-
er and ancillary cooler wat-
er boxes, tube plates and
tube entries, water mani-
folds, valves, coal and ash
handling plant. Sea water
pumps, strainers and weed-
grids.

★

*General and Chemical
Engineering*

Coatings for fume ducts,
fan casings and impellers,
acid vats, storage pressure
and vacuum vessels, struc-
tures etc.

★

Marine

main condenser tube plates,
waterboxes, intake and dis-
charge valves, pump casings
and impellers. Stern frames,
rudder nosings, intake and
discharge grills, propeller
shafts, diesel engine wet
liners, cooling water sys-
tems.

★

Hull Sheathing

Liquid applied, flexible hull
sheathing for steel or woo-
den boats is completely re-
sistant to marine borers and
prevents corrosion. Keeps
hull, decks and superstruc-
ture watertight

★

*Nylon, P.V.C. Epoxy
Phenolic, and Polyure-
thane Coatings*

for bumps, storage vessels,
road and rail tankers, fume
ducts, structures, etc.

Dear Mr Bianchi,

We comment upon your letter of August 23rd, 1978.

Limpetite has additionally been used quite widely in
Central Electricity Generating Board in the last few years
where titanium tubes are fitted to existing "Naval Brass"
tube plates. The electro-potential difference between the
titanium and the "Naval Brass" is so high that Limpetite
is an absolute must. Even new stations under construction
were fitted with new brass tube plates until the problem
was discovered in some of the older stations where
titanium tubes had been fitted on trial. Subsequent new
condensers fitted aluminium bronze or aluminium brass tube
plates thus reducing the electro-potential difference.

Under specific conditions of aluminium brass tube
plates it should be noted no service experience is available
as far as we are aware. It is anticipated that Limpetite
coatings for the protection of the tube plates will not be
necessary. Service conditions may dictate otherwise.

Your specific problem is akin to the first mentioned
above where there is a large electro-potential difference
between the tubes and the tube plate. We would expect that
if it is successful between titanium and "Naval Brass" tube
plates it would be equally successful between steel tube
plates and presumably titanium or brass tubes.

Cont'd 2/....

M.O.D. QUALITY ASSURANCE APPROVAL 09604/1/01



M.P. Bianchi Esq.,
TRW Defense & Space Systems Group.

4th September, 1978.

Consideration must be given to the design of the tube to tube plate junction at both ends of the tubes. In the case of a floating tube-plate to accommodate the expansion of tubes this presents no problem, but it could present a slightly more difficult problem in the case of fixed tube plates.

In the case of floating tube plates the present practice here is for the entry end either to have expanded, bellmouthed, flush tubes with the tube plate coating taken down into the tube entry; or the tubes standing out about 1/4" and the coating finished around the outside diameter of the tube. This latter method is that used for the outlet ends where water flow direction would preclude the use of a coating within the tube bore.

In the case of rigid tube plates then presumably the outlet end would be packed in some way allowing the tube to slide through packing on expansion and contraction. In these cases you would use two methods, The simplest seems to be quite effective, namely to coat the tube standing out in exactly the same way as the standout inlet. That is to say, coat around the outside diameter of the tube for a distance of say between 1/4" and 1". In some cases tubes have pulled through the coating sleeve, yet, under the difference in pressure between the steam side and the cooling water side this has maintained an effective seal. In other cases where the total expansion has remained small the coating has either stretched as necessary or has lifted slightly from the tube plate.

Another method has been used where Neoprene sponge washers have been fitted and a coating applied on the tube plate over the square section washer close fitting to the outside diameter of the tube and on to the outside diameter of the tube thus providing a bellows to accommodate greater movement. The success of this latter method depends to some extent upon the pitch of the tube and the physical accessibility for brushing the coating around the tubes and the washers.

With reference to the second paragraph of your letter Limpetite could be made available in the United States unless there is some Customs ban on its import. In the past we have found the United States Customs requirements to be singularly complicated and we would probably find every component of the three or four components required would have to be submitted for examination and test to U.S. customs Laboratory for classification. It seems to us from our experiences of some time ago that they will not take classifications commonly used throughout Europe and the rest of the world and translate them into their own standard grouping. Your organisation concerned with defence may be able to employ some influence in this respect.

The only literature we have we enclose, which is a general brochure giving illustrations of various applications and a leaflet describing Limpetite A/B; two of the three types of synthetic rubber liquid applied, air cured coatings that we manufacture.

We would imagine that if in the event that you wish to apply materials in the United States it would be best for us to send over a representative who will advise upon initial application. Normally in this country we seldom supply the Limpetite for application by others, except in small private applications, because of the failure so often of professional contractors to appreciate the requirements of Limpetite and to treat it simply as an ordinary paint.

Cont'd 3/....

M.P. Bianchi Esq.,
TRW Defence & Space Systems Group.

4th September, 1978.

It is not untrue to say that the success of Limpetite stems almost as much from our appreciation of the engineering requirements of its application as from the material itself.

We shall be happy to liaise with you on this matter.

Yours truly,

A handwritten signature in black ink, appearing to read 'J.H. Payne', with a stylized flourish at the end.

J.H. Payne,
Managing Director.

INTEROFFICE CORRESPONDENCE

5515.2.78-269

TO: J. W. Denton

CC:

P. Edris
E. L. Leventhal
R. O. Pearson
W. I. Rogers
L. A. Rosales
W. J. Tallon, Jr.

DATE: 19 May 1978

SUBJECT: Cathodic Protection of Submerged
Heat Exchanger.

FROM: T. C. Dvorak

BLDG.
01

MAIL STA.
2220

EXT.
51900

T. C. Dvorak

The customer request to evaluate the impact of submerging the 25 MWe heat exchanger has required that active corrosion preventive measures (i.e. cathodic protection) in addition to the planned passive measures (i.e. coatings) be considered. To this end, the Harco Corporation was contacted and a meeting was arranged.

On May 15, the writer, L. Rosales and L. Leventhal of TRW met with Mr. Robert Deskins, V.P. and Western Region Manager and Steve Jones, Manager of Engineering, Western Region Office of the Harco Corporation. Our design concept was shown to them and the following points were made.

Harco is in the business of providing corrosion engineering services during the design phase of a program. They will review the design, recommend the type of cathodic protection required, prepare plans and specifications for the installation and monitoring of the system after installation.

The method of attachment of the heat exchanger to the hull is very critical. If the joint is electrically conductive and the hull is more noble than the heat exchanger, as would be the case if the hull were concrete, then the exchanger would corrode at a very rapid rate due to the large area ratio of the hull to the heat exchanger. To resolve this issue we must have a better understanding of the hull design, materials of construction, etc.

It was Harco's opinion that the sacrificial anode type of cathodic protection as opposed to induced current was the best method for our application. A cost for this type of system could only be obtained after a detailed design study. The approximate cost for anodes would be one dollar per pound with installation also costing about one dollar per pound (based on off-shore oil platform costs-may be higher for OTEC installations). For an idea of cost, the Exxon oil platform Hondo required 750,000 pounds of sacrificial anodes to provide protection for 10-15 years.

Page 2

5515.2.78-269

Cathodic Protection of Submerged Heat Exchanger

In summary, due to the complex nature of designing an adequate protection system and our lack of experience in this area, we strongly recommend that a company such as Harco, be contracted to provide this service. Our role would be that of technical monitor and point of information exchange. As of this point in time we plan no further activity in this area. Task I, Subtask 5 is now considered complete.

TCD:dj

TRW

DEFENSE AND SPACE SYSTEMS GROUP
ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 92770

INTEROFFICE CORRESPONDENCE

TO: Paul Edris

cc: Distribution

PSD-1-373
5515.2.78-329
DATE: 7 July 1978

SUBJECT: Corrosion Allowance for Carbon Steel in Design of OTEC/PSD-1 Heat Exchanger Shell, Tube Sheets and Water Boxes. FROM: J. Hicks
BLDG. 01 MAIL STA. 2080 EXT. 61486

- References:
- (1) TRW Conceptual Design Report SAN/1570-1, Volume II, Dated 30 January 1978. (Appendix A - "Heat Exchangers Mechanical Design and Producibility", prepared by C. F. Braun & Co., 10 January 1978.)
 - (2) DOT/USCG Document CG-116 "Marine Engineering Regulations," dated 1 August 1977.
 - (3) INCO "Guidelines for Selection of Marine Materials," May 1971.

The following comments are in response to yesterday's inquiry from C. F. Braun & Co. relative to the subject.

1. The corrosion allowance of 1/8-inch for carbon steel as stipulated by C. F. Braun (see Reference 1, pages A-48 and A49) appears sufficient and proper for the subject heat exchanger components, IF the heat exchanger is not totally immersed in sea water, (see SUMMARY). This conclusion is based on a review of the regulatory requirements, the C. F. Braun proposed design, and general industry guidelines for the selection of marine materials, as outlined below.
2. Code Provisions - Part 54 (Pressure Vessels) of the Reference 2 regulations establishes the requirements for the design, construction and inspection of seaborne heat exchangers. Paragraph 54.01-35 specifically addresses the corrosion allowance to be applied in the design of the pressure portions of pressure vessels. This paragraph is reproduced below; note particularly subparagraphs (b)(1), (b)(4), (d)(1), and (d)(2).

(b) The following information shall be submitted:

(1) Calculations for all pressure containment components including the maximum allowable working pressure, the hydrostatic or pneumatic test pressure, and the intended safety device setting.

(2) Joint design and methods of attachment of all pressure containment components.

(3) Foundations and supports (design and attachment).

(4) Pertinent calculations for pressure vessel foundations and/or supports.

(5) A bill of material meeting the requirements of section VIII of the ASME Code, as modified by this part.

(6) A diagrammatic arrangement drawing of the assembled unit indicating location of internal and external components.

§ 54.01-25 Miscellaneous pressure components (modifies UG-11).

(a) Pressure components for pressure vessels shall be as required by UG-11 of the ASME Code except as noted otherwise in this section.

(b) All pressure components conforming to an accepted ANSI (American National Standards Institute) Standard referred to in an adopted code, specification or standard or in this subchapter shall also be marked in accordance with MSS (Manufacturers' Standardization Society) Standard SF-25.

[COFR 68-87, 33 F.R. 18828, Dec. 18, 1968, as amended by COFR 69-127, 35 F.R. 9977, June 17, 1970]

§ 54.01-30 Loadings (modifies UG-22).

(a) The loadings for pressure vessels shall be as required by UG-22 of the ASME Code except as noted otherwise in this section.

(b) In evaluating loadings for certain pressure vessel applications, the Commandant may require consideration of the following loads in addition to those listed in UG-22 of the ASME Code:

(1) Loading imposed by vessel's attitude in roll, list, pitch and trim.

(2) Dynamic forces due to ship motions.

§ 54.01-35 Corrosion (modifies UG-23).

(a) Vessels or portions of vessels subject to corrosion shall be as required by UG-23 of the ASME Code except as noted otherwise in this section.

(b) The pressure portions of pressure vessels shall:

(1) Normally have a corrosion allowance of one-sixth of the calculated thickness, or one-sixteenth inch, whichever is smaller, added to the calculated thickness as determined by the applicable design formula.

(2) Be specifically evaluated in cases where unusually corrosive cargoes will be involved, for the possible increase of this corrosion allowance.

(3) Have no additional thickness required when acceptable corrosion resistant materials are used.

(4) Not normally need additional thickness allowance when the effective stress (either S or SE depending on the design formula used) is 80 percent or less of the allowable stress listed in section VIII of the ASME Code for calculating thickness.

(c) Teflate holes shall not be permitted in pressure vessels containing dangerous fluids, such as acid, poison, corrosives, etc.

(d) Exemption from these corrosion allowance requirements will be granted by the Commandant in those cases where:

(1) The contents of the pressure vessel is judged to be sufficiently noncorrosive; and,

(2) Where the external surface is also protected from corrosion. A suitable vapor barrier is adequate protection, while paint or other thin coatings exposed to weather or mechanical damage are not acceptable.

Note: No applied linings except as provided in Part UCL of the ASME Code shall be acceptable.

[COFR 68-82, 33 F.R. 18828, Dec. 18, 1968, as amended by COFR 72-69B, 37 F.R. 6169, Mar. 25, 1972]

§ 54.01-40 External pressure (modifies UG-28).

(a) The exemption from external pressure consideration provided by the note under UG-28(f) does not apply.


(b) Vessels which may at times be subjected to partial vacuum due to nature of the contents, temperature, unloading operations, or other facet of employment shall either have vacuum breaker protection or be designed for not less than one-half atmosphere of external pressure.

[COFR 70-143, 35 F.R. 19609, Dec. 30, 1970]

3. C. F. Braun Proposed Design - Attachment Pages 1 and 2 (from Reference 1) show tube and tubesheet-to-shell details of the C. F. Braun proposed design. It appears that this design complies with the provisions of all four subparagraphs of the Code noted above, IF the heat exchanger is not immersed.

4. Corrosion in Sea Water - Charts from Reference 3 relative to general corrosion rates of unprotected carbon steel in seawater, the galvanic potential of titanium coupled with carbon steel, and other galvanic considerations in the design of tube sheets and water boxes are reproduced below. They are essentially self-explanatory.

Figure 8 - SEAWATER VELOCITY (PIPE AND TUBE RANGES)



Note, in Figure 8 above, that the general wasting corrosion rate of unprotected carbon steel in seawater can vary from 5 mils/year to 30 mils/years depending on the velocity of the seawater.

Table IV
GALVANIC POTENTIALS IN FLOWING SEAWATER
 (VELOCITY = 13 ft. per sec. except where noted)

METAL OR ALLOY	TEMPERATURE, °C			VOLT ³ VS. SATURATED CALOMEL		
Zinc	26			-1.03		
Mild steel	24			.61		
Gray cast iron	24			.61		
Austenitic cast iron ²		14			.47	
Copper	24			.36		
Admiralty brass	24.6			.36		
Gunmetal	24			.31		
Aluminum brass	24.6			.29		
Admiralty brass		11.9			.30 ¹	
Lead-Tin Solder (50-50)		17			.28	
90/10 copper-nickel alloy (1.4 Fe)			6			.24
90/10 copper-nickel alloy (1.4 Fe)		17			.29	
90/10 copper-nickel alloy (1.5 Fe)	24			.22		
70/30 copper-nickel alloy (0.51 Fe)			6			.22
70/30 copper-nickel alloy (0.51 Fe)		17			.24	
70/30 copper-nickel alloy (0.51 Fe)	26.7			.20		
Nickel-copper alloy 400	22			.11		
Nickel	25			.10 ¹		
Titanium	27			-.10		
Graphite	24			+.25		
Platinum		18			+.25 ¹	

- Notes: 1. Seawater velocity = 7.8 ft. per sec.
 2. Austenitic nickel ductile cast iron Type D-2 (3.0 C, 1.5-3 Si, 0.7-1.25 Mn, 18-22 Ni, 1.75-2.75 Cr).
 3. All values negative vs. saturated calomel reference electrode except those for graphite and platinum.

Note, in Table IV above, that the galvanic couple of titanium with carbon steel in seawater generates approximately 1/2 volt, with the carbon steel being anodic (sacrificial).

TUBE SHEET

The present trend towards welding tubes to tube sheet and galvanic considerations tend very strongly towards use of the same alloy in the

tube sheet as in tubes. This is preferred. Older practice was to use muntz metal or naval brass tube sheets.

Applicable Data

Table V, Selective Corrosion

WATER BOXES

Key Consideration

(1) The water box should not be more noble than the tubing.

Materials Used	Comments
Carbon steel and cast iron	Heavy corrosion of steel provides substantial cathodic protection to copper alloy tube ends and tube sheet.
Carbon steel and cast iron lined with organic lining	Reduces cathodic protection of tube ends. Also forces steel exposed at pinholes and scratches to furnish the full amount of the current required by the galvanic couple with the copper alloy tube sheet and tube ends. Maintenance can be high.
Austenitic nickel cast iron	Good selection. Low corrosion but still protective to copper alloy tube ends and tube sheet.
90/10 copper-nickel alloy (1.5 Fe)	Good selection, when using 90/10 copper-nickel alloy (1.5 Fe) tubes, 70/30 copper-nickel alloy (0.5 Fe) tubes or nickel-copper alloy 400 tubes.
70/30 copper-nickel alloy (0.5 Fe)	Good selection, when using 70/30 copper-nickel alloy (0.5 Fe) tubes and nickel-copper alloy 400 tubes.
Nickel-copper alloy 400	Good selection, when using nickel-copper alloy 400 tubes. Solder wipe when using 70/30 copper-nickel alloy (0.5 Fe) tubes.

Applicable Data

Fig. 10, Galvanic Series
Table IV, Galvanic Series
Fig. 3, Effect of Velocity — Steel
Fig. 4, Effect of Velocity — Zinc


Fig. 5, General Wasting
Fig. 6, Pitting Rates
Fig. 8, Velocity: Pipe and Tube
Table V, Selective Corrosion

5. SUMMARY -


- 5.1 A corrosion allowance of 1/8-inch for carbon steel in design of the subject components is adequate, if the heat exchanger is not submerged.
- 5.2 If the OTEC system design requires submergence of the heat exchangers, the corrosion allowance for the pressure vessel components must be increased to a minimum of 1/2-inch, even when protected with an approved marine coating system. (see Code provision 54.01-35 (d)(2), above.)
- 5.3 Waterbox Coating - It will be noted in the C. F. Braun design (see Figure 6, attached) that a coal tar epoxy coating is proposed for the waterbox coating. Although this coating may be adequate, TRW Materials Engineering suggests that C. F. Braun designers consider another more resilient Neoprene coating system which appears outstanding for this application, and which has a proven 32 year service life. (See attachment pages 3 and 4.)

TRW
SYSTEMS GROUP
KROONDD BEILII, CA

OTEC HEAT EXCHANGERS



ALUMINUM TUBES



TITANIUM TUBES


TUBE DETAILS

D-60


TRW
SYSTEMS GROUP
REDONDO BEACH, CA

OTEC HEAT EXCHANGERS

D-61



TUBESHEET TO SHELL ATTACHMENT DETAILS



7 July 1978

Neoprene Waterbox Coating System


1. Reference: DuPont Elastomers Notebook - Volume 201, April 1978.
Neoprene Coating by Protective Rubber Coatings (Bristol) Ltd., England.
2. Application: Portishead "A" Power Station - Bristol, England.
Condenser tube plates and waterboxes, coated with Neoprene coating of 60 mils total thickness, exposed to high velocity silted salt water for 32 years. Still in service during March 1978, (See Attachment-4).
3. Coating System Details:
 - Surface Preparation - Sandblast to NACE No. 1 white metal blast cleaned surface. (See, SSPC-SP5-63 white metal blast cleaning)
 - Prime Coat* - GACO Primer N-11R (inhibitive primer)
 - Top Coat* - GACO Neoprene Liquid Lining N-200-1 unit coating thickness = 5 mils Total coating thickness = 60 mils
 - Inspection - Electrical continuity test (wet or dry)
 - Supplier - GACO Western, Inc.
8023 E. Slauson Ave.
Montebello, Calif. 90640
(213) 254-0536
 - Applicator - Parker Brothers
7044 Bandini
Los Angeles, Calif.
(213) 723-8701

* These coating comply with specification MIL-R-15058F, type IV.

RELIABLE PROTECTION FOR 16 YEARS

Neoprene coating, applied in 1946 to condenser water box in English power station,
is still successfully combatting corrosion-erosion from tidewater

(Originally published in 1963)



Electrostatic tests and close visual inspection proves Neoprene coating is still firmly attached after years of service.

Sea water is an inexpensive coolant to obtain but engineers at the Portishead "A" Power Station, about 10 miles from Bristol on the Severn Estuary, were painfully aware of how expensive it is to control. Pumped directly from the estuary, millions of gallons of sea water were used per day as the cooling medium in the station's main steam condensers. The supply was convenient and inexhaustible. However, its salt content made it corrosive to metal and the presence of sand and silt intensified this attack by their scouring effect. Condenser tube plates suffered heavy pitting from the cooling water's corrosive-erosive action.

This double-edged hazard to equipment was effectively blunted in 1946 when a protective coating based on Du Pont Neoprene was brush-applied to the condenser tube plates. It was put on the bare metal, to a thickness of about one-sixteenth inch (1.6 mm), after careful surface preparation. Neoprene was chosen for this job because of its well-known resistance to salt water, abrasion, oil and chemicals plus its excellent adhesion to metals and reputation for long life.

The choice has not been regretted. Apart from normal cleaning, the water boxes of the condensers have not been opened up at all for anticorrosion maintenance in the sixteen plus years since the Neoprene coating was put on. This is an important economic advantage because of the considerable expense in-

olved each day a generator is shut down for condenser repairs.

Following the success of this initial coating at Portishead, other stations of the Central Electricity Generating Board in Great Britain have specified the same Neoprene formulation for similar purposes. These include three nuclear power stations as well as a number of conventional facilities.

Equally long life is expected of these installations. When recently inspected, the 1946 Neoprene coating was still resilient and unimpaired. It had every appearance of lasting another sixteen years!

1978 UPDATE

Protective Rubber Coatings (Bristol) Ltd. confirmed, in March, 1978, that the original Neoprene coating indeed was still in service. Occasional repairs to portions mechanically damaged by maintenance workers have been necessary but the major portion of the 1946 coating job is intact after 32 years.

Neoprene coating by
Protective Rubber Coatings (Bristol) Ltd., England Circle Code No. 7

Amercoat

DIMETCOTE® 6

MARINE COATING

Types: S, M, L and Inorganic Zinc
 Applications: Hulls, Decks, Buoys, Booms,
 Superstructures, Holds

AVAILABLE FOR: Ships, Workboats, Barges,
 Offshore Structures

- A SUPERIOR MARINE "PERMANENT" PRIMER
- CAN BE APPLIED AT TEMPERATURES DOWN TO 0°F
- WITHSTANDS WATER CONTACT 15 MINUTES AFTER APPLICATION
- RAPID-CURES AT HUMIDITIES UP TO 99% AND VERY LOW TEMPERATURES
- A SELF-CURING, ALKYL SILICATE-BASED INORGANIC ZINC

■ Best inorganic zinc coating for applications in low temperatures, high humidities ■ Extremely resistant to severe marine environments ■ Withstands intermittent contact with water, rain or condensation 15 minutes after application ■ Develops a tough, abrasion-resistant film in approximately 2 hours ■ Cures to permit topcoating after 24 hours ■ High metallic zinc content... provides cathodic protection to steel surfaces, including sharp edges, nuts and bolts.

Included in: U.S. Navy Chapter 9190 as a self-curing inorganic zinc silicate coating approved for application to hulls above water line, decks and superstructures of U.S. Navy vessels.

PRINCIPAL AREAS OF USE:

- Barges
 - Sides and Rakes ■ Decks ■ Deck Piping up to 150°F ■ Deck Machinery
 - Cargo Holds ■ Cargo Tanks ■ Void Spaces
- Ships, Workboats
 - Keel to Light Load Line ■ Boottopping ■ Deep Load Line to Rail ■ Weather Decks ■ Superstructures ■ Boms, Masts, King Posts ■ Deck Piping (Up to 150°F) ■ Deck Machinery ■ Cargo Holds ■ Cargo/Ballast Tanks ■ Fuel Oil Tanks ■ Void Spaces and Cofferdams
- Offshore Platforms
 - Splash Zone and Submersible Areas ■ Drilling Areas Subjected to Splash and Spillage of Drilling Muds ■ Rig Jackets (Including Legs and Columns In and Above Tidal Zone) ■ Deck Sections

Apply Dimetcote 6 in a single coat, at 2½ mils dry film thickness; badly pitted surfaces may require up to 5 mils, but never apply more than 6 mils. As a permanent primer, Dimetcote 6 will reduce maintenance and eliminate future need for extensive surface preparation when used under recommended Amercoat topcoat systems; obtain specific recommendations, based on service requirements, from the Ameron representative.

RESISTANCE—When Used Without A Topcoat

This chart is only a guide. For specific recommendations, see the Amercoat Coatings Tank Lining Chart.

WEATHER: Outstanding resistance. No loss of protective qualities even after prolonged exposure. Unharmful by ultraviolet light.

TEMPERATURE: Withstands heat up to 600°F (dry).

PETROLEUM: Ideally suited for fumes, splash, spillage or immersion in petroleum hydrocarbons, such as:

Aviation Gasoline	Fuel Oil
Jet Fuel	Motor Gasoline
Kerosene	

SALTS: Prolongs life of topcoat when suitably topcoated and subjected to splash and spillage of neutral salt solutions.

SOLVENTS: Resistant to fumes, splash, spillage or immersion in ke-

tones, aromatic and aliphatic hydrocarbons, chlorinated hydrocarbons (water-free), alcohols, including:

Acetone	Carbon Tetrachloride
Xylene	Isopropyl Alcohol
Toluene	Ether Alcohols
Hexane	

ANIMAL AND VEGETABLE OILS: Suitable for immersion in animal and vegetable oils of free acid content below 2½%.

WATER: Ideally suited for atmospheric exposure to, and (with suitable topcoat) splash or spillage of fresh or salt water.

NOTE: As is true with all inorganic zinc silicate coatings, Dimetcote 6 is not recommended for immersion in, or spillage of, acid or alkali solutions.

FINISH	Matte
COLOR	Reddish Gray to Gray
RECOMMENDED DRY FILM THICKNESS PER COAT	2½ mils
NO. OF COATS REQUIRED	1
TOTAL DRY FILM THICKNESS	
DIMETCOTE 6	2½ mils
TOTAL VOLUME SOLIDS†	43.7%
THEORETICAL COVERAGE* @ 1 MIL	700 sq. ft. per gal.
THEORETICAL COVERAGE* PER COAT @ 2½ MILS	280 sq. ft. per gal.
*See Amercoat Technical Report on Coverage of Inorganic Zinc Coatings. When computing working coverage, allow for application losses, surface irregularities, etc.	
NO. OF COMPONENTS	2
MIXING RATIO	15 lbs. Powder to 3/4 gal. Liquid
POT LIFE	24 hrs. minimum @ 70°F
APPLY OVER	Dry-abrasive blasted steel
APPLY BY	Conventional spray
DRYING TIME	Water-insoluble: 15 min. above 32°F; 15-30 min. @ 0-32°F Abrasion-resistant: 2 hrs. @ 70°F
CURING TIME	To Topcoat: 24 hrs. @ 70°F
TOPCOAT REQUIRED	For specific services
THINNER	Amercoat No. 65 Thinner (70°F or below), No. 101 Thinner (above 70°F). Order 1 gal. per 8 gals. Dimetcote 6
CLEANER	Amercoat No. 65 or No. 101 Thinner. Order 1 gal. per 10 gals. Dimetcote 6
MISCELLANEOUS	Moisture aids in achieving maximum film hardness
TEMPERATURE RESISTANCE	Up to 600°F (dry)
FLASH POINT	70°F Mixed (Tag Open Cup)
COMBUSTIBILITY	Flammable during application; cured film not combustible
WT. PER MIL-SQ. FT. OF DRY FILM	0.4 oz.
ELECTRICAL CONDUCTIVITY	Weak conductor
PACKAGING	Separate containers make 1 gal. mixture
SHIPPING WEIGHT	Powder—16 lbs. Liquid—7.5 lbs.
GUARANTEED SHELF LIFE FROM SHIPMENT DATE	1 year

DIMETCOTE® 6 APPLICATION INSTRUCTIONS

SURFACE PREPARATION

STEEL

Round off all rough welds and sharp edges. Remove weld spatter.

Dry-abrasive blast, including all pits and depressions; remove all mill scale, rust, rust scale, grease, paint or foreign matter. Surface profile from abrasive blasting should be similar to that obtained with fresh steel grit (G-40 size), steel shot (S-230 size), graded flint or silica sand (30-60 mesh), under nozzle pressure of 100 psi. If reusing blasting abrasives, clean them of contamination before reusing; do not reuse sand or flint abrasives.

Where an automatic blasting unit is used, its manufacturer should be consulted for "working" abrasive mixtures and line speeds.

OLD OR NEW GALVANIZING

Sweep-blast surface lightly to remove dirt, etc.

Apply Dimetcote 6 as soon as possible to prevent blasted surfaces from rusting. Keep surfaces moisture-free until coated. Keep oil, grease or other organic matter off surface before coating. Spot reblast to remove any contamination; solvent-wiping is not satisfactory.

EQUIPMENT REQUIRED

- Pressure material pot with mechanical agitator.
- Separate atomizing air and fluid pressure regulators.
- Air Supply: Compressor capable of continuous volume of 20 CFM at 80 psi minimum to each nozzle. For a moisture-free air supply, a moisture trap (such as DeVilbiss HRE-501 Oil and Moisture Separator) must be in the line between compressor and pressure spray pot and spray gun.
- Air hose for gun, 5/16" I.D.
- Material hose, 1/2" I.D.
- Industrial spray gun, such as DeVilbiss MBC 2E or 24E with graphite or Teflon needle packing and heavy "mastic" spring; or Binks No. 18 with 66X66P nozzle setup with No. 54-764 graphite or 2-28 Teflon needle packing and No. 54-839 heavy mastic spring.
- 30-60 mesh metal screen.

SAFETY EQUIPMENT REQUIRED

(In Tanks or Confined Areas Only)

- Explosion-proof lights and electrical equipment.
- Fresh air mask, such as DeVilbiss P-MPH 527 and MPH 529, connected by 1/4" I.D. hose directly to air source.
- Nonsparking shoes or tools for workers in area.
- Exhaust fan of sufficient capacity to keep solvent vapors below 20% of the explosive limit or 1/4% by volume of solvent vapor in air.

Volume of Tank (Gallons)	Required Blower Size* (Cu. Ft./Min.)
500 - 5,000	1,000
5,000 - 20,000	2,000
20,000 - 100,000	5,000
100,000 - 250,000	10,000
500,000	15,000
1,000,000 - 2,000,000	20,000

*All blowers to be suction type.

APPLICATION PROCEDURE

1. Flush equipment with Amercoat No. 12 Cleaner to remove moisture from all application equipment; moisture can harden Dimetcote 6 in spray equipment.
2. Discard desiccant bag from Powder can.
3. Stir total contents of each Powder can slowly into total contents of each Liquid can until well dispersed. Do not reverse order. Do not vary proportions.
4. Do not thin except for workability in conditions such as hot, windy weather, and then with no more than 1 pint of No. 65 or No. 101 Thinner per gallon of mixed Dimetcote 6.
5. Strain mixture through 30-60 mesh screen to remove large particles.
6. Keep mixture in closed container until ready to use. Dimetcote 6 is sensitive to moisture in the atmosphere. If skinning occurs, remove skin by filtering through cheese cloth or fine mesh screen. Agitate slowly throughout application to maintain uniform suspension.
7. Remove all dust from surface to be coated.
8. Regulate air pressure: 40-60 psi to gun (with DeVilbiss equipment and 25-ft. hose); 10 psi to pot. Note: Required pressures may vary with temperature and hose length.
9. Keep pressure pot at approximately same elevation as spray gun.
10. Make even, parallel passes. Overlap each pass 50%.
11. Apply a heavy, wet coat to obtain proper thickness with no bare areas, pinholes or holidays.
12. Double-lap spray all welds, corners, edges, etc.
13. Clean all spray equipment immediately after use with Amercoat No. 65 or No. 101 Thinner (not water).
14. If humidity is extremely low, spray a water mist to effect rapid curing.
15. If greater thickness is desired, recoat when first coat is dry to touch.
16. Random pinholes and holidays should be touched up by brush when film is dry to touch. Bare areas should be resprayed.
17. If damage occurs, recoat with Dimetcote 6 when film is dry to touch.
18. If topcoating is required, allow to dry at least 24 hours.

WARNING: Dimetcote 6 Liquid is flammable and causes skin and eye irritation. Keep away from heat and open flame. Keep container closed. Use with adequate ventilation. Avoid prolonged breathing of vapor. Avoid contact with skin or eyes. Do not take internally. In case of contact, immediately flush skin with plenty of water; for eyes, flush with plenty of water for at least 15 minutes and get medical attention. If used in confined areas, observe the following precautions to prevent hazards of fire or explosion or damage to the health: (1) circulate adequate fresh air continuously during application and drying, (2) use fresh air masks and explosion-proof equipment, (3) prohibit all flames, sparks, welding and smoking.

WARNING: Dimetcote 6 Powder is a harmful dust. Avoid breathing dust. Wash thoroughly before eating or smoking. Keep away from feed or food products.

If welding is to be performed in confined spaces on steel coated with Dimetcote 6, do so in accordance with instructions in U.S.A. Standard Z 49.1-1967, "Safety in Welding and Cutting."



CORROSION CONTROL DIVISION

Home Office BREA, CALIFORNIA 92621

Amercoat

AMERCOAT® 83/84

MARINE COATING

Types: Physical-cured

100%

Use: Keel to Light Load Line, Topsides

Ships, Workboats, Submarines

- A HIGHLY PROTECTIVE MARINE EPOXY COATING SYSTEM
- PROVIDES FULL PROTECTION IN ONLY TWO COATS
- FORMULATED FOR EXTERIOR HULL PROTECTION
- MEETS U.S. NAVY REQUIREMENTS FOR SUBMARINE HULLS, TOPSIDES AND BOTTOM AREAS
- FULLY COMPATIBLE WITH VINYL ANTI-FOULING TOPCOATS

- Specially formulated for maximum protection of steel in salt water
- Ready for immersion in 24 hrs.
- Cures at temperatures of 35°F and above
- Available in six standard Navy colors and specified camouflage colors

Conforms to: U.S. Navy Chapter 9190; approved for coating submarine hulls, topsides and bottoms. Also acceptable for bottoms of surface vessels. Proprietary approval for application over post-cured inorganic zinc approved under MIL-P-23236.

PRINCIPAL AREAS OF USE:

- Ships, Workboats**
 - Keel to Light Load Line — 1 coat of No. 83 Primer, at 2 mils dry film thickness, over Dimetcote 3 or Dimetcote 6. Topcoat with 1 coat of No. 84, at 6 mils dry and 2 coats of Amercoat No. 67 Anti-Fouling, at 3 mils each. Alternate: the same system except without Dimetcote 3 or 6 as permanent primer.
- Submarines**
 - Keel to Waterline — 1 coat of No. 83 Primer, at 2 mils dry, topcoated with 1 coat of No. 84, at 6 mils and 1-2 coats of a Navy-approved antifouling.
 - Topsides — 1 coat of No. 83 Primer, at 2 mils dry, topcoated with 1 coat of No. 84, at 6 mils.

Where required, U.S. Navy Antifouling Formulas 121/63 or 129/63 or Amercoat No. 67 or No. 70 Anti-Fouling may be applied.

	No. 83 Prime	No. 84 Topcoat
FINISH	Matte	
COLORS	No. 83: Oxide Red. No. 84: Black Navy 3, Gray Navy 7, Gray Navy 11, Ocean Gray Navy 17, Haze Gray Navy 27, White Navy 82 and specified camouflage colors	
RECOMMENDED DRY FILM THICKNESS PER COAT	2 Mil	6 Mil
NO. OF COATS REQUIRED	1	1
TOTAL DRY FILM THICKNESS	2 Mil	6 Mil
THEORETICAL COVERAGE* PER COAT @ 1 MIL	690 Sq. Ft. per Gal.	690 Sq. Ft. per Gal.
THEORETICAL COVERAGE* PER COAT (Sq. Ft./Gal.)	345 @ 2 Mil	115 @ 6 Mil
<small>*When computing working coverage, allow for application losses, surface irregularities, etc.</small>		
NO. OF COMPONENTS	2	2
MIXING RATIO	1 cure: (Parts by Volume) 2 resin	1 cure: 2 resin
MINIMUM POT LIFE	24 hrs. @ 70°F	
APPLY BY	Airless, Conventional Spray; Brush Touchup	
APPLY NO. 83/84 OVER	Blasted Steel; Clean Dimetcote (See other side for repair)	
DRYING TIME	See Application Instructions	
TOPCOATS COMPATIBLE	Vinyl antifouling (Navy Formula 121/ 63 or 129/63), Amercoat No. 67 or 70 Anti-Fouling	
THINNER AND CLEANER	Amercoat No. 9 HF Thinner—Order 1 gal. per 10 gals. No. 83 and 84	
COMBUSTIBILITY	Chars	
WT. PER SQ. FT. OF TOTAL DRY SYSTEM	Approx. 1.25 oz. @ 8 Mil	
ELECTRICAL CONDUCTIVITY	Nonconductor	
PACKAGING	1's and 5's (Unitized)	
SHIPPING WEIGHT	1's — 13 lbs. 5's — 65 lbs.	1's — 12 lbs. 5's — 59 lbs.
GUARANTEED SHELF LIFE FROM SHIPMENT DATE	1 Year	1 Year

SURFACE PREPARATION

- Immersion — Bare Steel**
 1. Round off all rough welds and sharp steel edges. Remove weld spatter.
 2. Dry-abrasive blast, including all pits and depressions; remove all mill scale, rust, rust scale, grease, paint or foreign matter. Blast only with steel grit (G-40 size), steel shot (S-230 size) or graded flint or silica sand (30-60 mesh). If reusing steel grit or shot, clean them of contamination before reusing. Do not reuse sand or flint abrasives. Use air of 100 psi at 200 CFM per blast nozzle.
 3. Apply No. 83 Primer as soon as possible to prevent blasted surfaces from rusting. Keep moisture, oil, grease or other organic matter off surface before coating. If surface is dry, clean by vacuum brushing or air blow down. If greasy, use solvent or oil cleaner followed by fresh water rinse, then dry thoroughly.
- Immersion — Dimetecote Surfaces**
 1. Be certain surface is fully cured, dry and clean.
 2. Wash off any cure crystals; scrub with water and stiff bristle brush to remove heavy deposits.
- Repair — No. 83/84 Abraded to Bare Steel**

Remove all rust, growth, peeling paint, etc. by spot reblasting, if possible. Otherwise, disc-sand with No. 16 open-coat sandpaper, feathering edges of intact coating.
- Repair — Abraded No. 84 Topcoat; No. 83 Prime Intact**

Scrape and/or lightly sand intact Prime to remove any loosely-adhering coating; feather surrounding edges. Solvent-wipe damaged area.

EQUIPMENT REQUIRED

- For Airless Spray —**
 - Standard airless spray equipment, such as Gray, DeVilbiss or any others using a 28:1 pump ratio; .015" or .017" tip (for No. 83); .017" or .021" tip (for No. 84). 80-100 psi inbound
- For Conventional Spray —**
 - Pressure material pot
 - Separate atomizing air and fluid pressure regulators
 - Air supply: compressor capable of supplying a continuous volume of air at 80 psi to nozzle of each gun
 - Air hose for gun, 3/8" or 1/2" I.D.
 - Material hose, 1/2" I.D.
 - Industrial spray gun, such as DeVilbiss MBC or JGA with 78 or 765 Air Cap, and "E" Fluid Tip

SAFETY EQUIPMENT REQUIRED

(In Confined Areas Only)

- Explosion-proof lights and electrical equipment.
- Fresh air mask, such as DeVilbiss P-MPH 527 and MPH 529, connected by 1/4" I.D. hose directly to air source
- Exhaust fan of sufficient capacity to keep solvent vapors below 20% of the explosive limit or 1/4% by volume of solvent vapor in air

APPLICATION PROCEDURE

1. Clean all equipment with No. 9 HF Thinner.
2. Stir resin and cure for No. 83 separately. Then mix one part cure into two parts resin (by volume). Stir for about 5 minutes with hand or power mixer. When ready to apply No. 84, follow this same mixing procedure.
 - If Using Airless Spray Equipment**
 - a. At temperatures above 50°F, thinning is not normally required. At temperatures of 35-50°F, thinning may be needed for workability; if so, thin with no more than 1 pint No. 9 HF Thinner per gallon No. 83 or No. 84.
 - If Using Conventional Spray Equipment**
 - a. At temperatures above 35°F, thin only for workability, and then with no more than 1 pint No. 9 HF per gallon No. 83 or No. 84.
 - b. Regulate air pressure: 20-25 psi to pot; 60-75 psi to spray gun (with DeVilbiss). NOTE: pressure requirements may vary with hose length and temperature.
3. Apply in even, wet coats, overlapping each pass 50%. Give special attention to corners, welds, rough areas, edges, etc. Leave no pinholes, bare areas or holidays.
4. **Applying No. 83 Prime — Above 35°F**
 - a. Spray one coat at 2 mils dry film thickness.
 - b. Allow No. 83 to dry at least 2 hrs. @ 70°F (4 hrs. @ 35-50°F) before applying No. 84. No. 83 may be allowed to dry up to 180 days above 35°F before topcoating. If more than 180 days elapse, apply a "mist" coat of No. 83 before topcoating.
5. **Applying No. 84 Topcoat At 35-50°F —**
 - a. Spray on 2 coats, each at 3 mils dry film thickness. Let dry 4 hrs. between coats.
 - b. Allow No. 84 to dry at least 4 hrs. before applying antifouling. No. 84 may be allowed to dry up to 48 hrs. before applying antifouling.

Above 50°F —

 - a. Apply No. 84 in a single coat at 6 mils dry film thickness.
 - b. Allow No. 84 to dry at least 4 hrs. before topcoating with antifouling. No. 84 may dry up to 24 hrs. before applying antifouling.
6. Clean equipment immediately after application with No. 9 HF Thinner.
 - Curing No. 83/84 System**
 1. Before walking on No. 83/84, allow system to dry 24 hrs. @ 70°F, 5 days @ 50°F or one week @ 35°F.
 2. Before immersion, No. 83/84 system must dry at least 24 hrs. above 35°F.
 - Touchup or Repair**

Consult with Amercoat Representative on procedures for touchup or repairing No. 83/84 system.

CAUTION: No. 83/84 Resin and Cure are combustible. Keep away from heat and open flame. Keep containers closed. Use with adequate ventilation. Avoid prolonged breathing of vapor. Avoid prolonged and repeated contact with skin. In confined areas, observe the following precautions to prevent hazards of fire or explosion or damage to the health: (1) circulate adequate fresh air continuously during application and drying; (2) use fresh air masks and explosion-proof equipment; (3) prohibit all flames, sparks, welding and smoking.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX D.3
MATERIALS COMPATIBILITY, RECOMMENDED MATERIALS

TRW

DEFENSE AND SPACE SYSTEMS GROUP
ONE SPACE PARK - REDONDO BEACH - CALIFORNIA 90770

INTEROFFICE CORRESPONDENCE

TO: L. A. Rosales

CC: Distribution

5515.2.78-421
DATE: August 28, 1978

SUBJECT: Ammonia Metering Device Flow Tests

M. P. Bianchi
FROM: M. P. Bianchi
BLDG. 01 MAIL STA. 2230 EXT. 52303

INTRODUCTION

A series of flow tests have been run to determine a rough order of magnitude flow rate from the polyethylene metering device proposed for the OTEC falling film heat exchanger tubes. Because of the difficulties in using liquid ammonia for this test, it was decided to use a modeling fluid; that is, one with physical properties similar to liquid ammonia but with a high enough boiling point so that the experiment could be run at room temperature and ambient pressures. Those properties it was desired to simulate were surface tension, density, and viscosity. Ideally, the liquid was to be non-toxic, non-flammable, and was to possess a boiling point as high above room temperature as possible. As will be shown, the latter property had a pronounced effect on the reproducibility of the test. Table I contains a list of some of the candidate fluids, and their properties, proposed for this test. Some candidates, not shown, were rejected since they were not readily available in quantities sufficient for the test. Originally, a water/surfactant solution was developed for heat exchanger tube bundle wetting and distribution tests. The initial requirements for this fluid was that it should possess a contact angle to acrylic (the tube bundle model material) similar to that of liquid ammonia to titanium. The properties of that solution are also shown in Table I. However, as will be discussed later, this fluid does not behave completely like liquid ammonia and the reasons for that will be discussed. Along with the flow rate measurements, the original tests attempted to establish the wetting and distribution of the fluid over the fluted titanium tubes after leaving the metering device. This was unsuccessful largely because the surfactant water mixture was used. Again, the reasons for this will be discussed. Subsequently, isopropyl alcohol was tried and this resulted in complete wetting of the tube which then led us to use it in the metering device tests.

TESTS

A simple flow-rate test set-up was assembled as shown in the sketch of Figure 1. The working principle is as follows:

1. A constant "head" is kept on the metering orifices (see Figures 2 and 3 for details of orifices) by pouring liquid at a rate sufficient to maintain a continuous overflow into the reservoir (Figure 1).
2. After a constant flow down the tube was achieved, a quantity of the fluid was collected over a specified time by means of a beaker held under the tube.
3. The flow-rate was then calculated as the weight of the fluid divided by time taken to collect it.
4. Acetone, isopropyl alcohol and water were the fluids used to measure the flow-rate from the metering device.

RESULTS

The results of the flow-rate measurements from the metering device with the three test fluids are shown in Table II. As can be seen from the results with acetone and isopropyl alcohol, the tests were less than successful. The measurements with water, however, were consistent and showed as good a reproducibility as could be expected from the test set-up. The reason for the decreasing flow rate exhibited by acetone and isopropyl alcohol was temperature. The high evaporation rates, especially of the acetone, caused the device to cool steadily when these fluids were flowing. For example, the temperature during seven consecutive one-minute flow measurements with acetone dropped from 70°F to 50°F. The isopropyl alcohol showed a somewhat slower fall with the temperature dropping from 70°F down to 65°F over the same number of one-minute flow measurements. Since polyethylene has a large coefficient of expansion (83 to 167×10^{-6} in/in/°F), the effect was to cause the orifices in the metering device to shrink a significant amount thus resulting in a steady constriction of these openings. The viscosity also decreased as the temperature dropped, but the change was small and the effect on the flow was probably insignificant.

August 28, 1978

Page three

Both the acetone and the isopropyl alcohol (IPA) completely wet the titanium tube after leaving the orifices in the metering device. Water did not. This was not only because of its higher surface tension, hence poor wettability, but also because the higher density of the water results in a higher momentum when flowing down the tube than that for acetone and IPA. This was the reason for the channeling of the water/surfactant solution even though the surface tension of this fluid is much lower than that of water.

DISCUSSION

The implications of these results to the metering of liquid ammonia with the polyethylene device are difficult to assess. If the device operates at a temperature equal to the installation temperature with little or no variation, the device should work providing, of course, the tube tolerances can be somehow accommodated. Aside from the serious problem of the orifice size change with temperature encountered in our test, we also found that because of the large expansion coefficient differences between the aluminum tube plate (11.7 to 13.7×10^{-6} in/in/ $^{\circ}$ F) and the polyethylene metering device, cooling (because of test liquid evaporation) caused a gap to steadily open between the plate and the device which allowed liquid to flow out. The low surface tension of acetone and isopropyl alcohol caused them to wet and spread across the horizontal surface of the tube plate bottom resulting in random dripping from various areas of the plate. In the beginning, this resulted in somewhat erratic measurements if the drops happened to land in our collection beaker. Later we were able to guard against this in our experiment; however, the implications for the OTEC falling film evaporation if cooling occurs, I believe, will have to be looked at. The steel tube sheet proposed for OTEC has an even lower coefficient of expansion than aluminum (approximately 6 to 8×10^{-6} in/in/ $^{\circ}$ F) which will result in the same or an even worse gap forming tendency if cooling occurs during operation of the evaporator.

August 28, 1978

Page four

Although not an objective of this test, it was noted that the tube flute ridges were wet by both the acetone and the isopropyl alcohol. However, it was found that the wetting occurred for a greater length with the isopropyl, which we attributed to its higher boiling point hence slower evaporation rate. We did not observe wavefronts in the liquids flowing down the tube which theoretically are supposed to occur on fluted tubes.

CONCLUSIONS

I would like to reiterate that the results of these flow tests on the polyethylene metering device should be considered rough order of magnitude measurements. The difficulties in measurements encountered with the test fluids, as well as problems of fitting the machined metering device without distortion, preclude labeling these tests as definitive.

MPB:cd

- Attachments:
- (1) Table I - Room Temperature Physical Properties
 - (2) Table II - Flow Rate Measurements
 - (3) Figure 1 - Cross Sectional Sketch of Flow Rate Measurement Test Set-up
 - (4) Figure 2 - Polyethylene Metering Device
 - (5) Figure 3 - Polyethylene Metering Device

TABLE I
ROOM TEMPERATURE PHYSICAL PROPERTIES

FLUID	DENSITY (GMS/CM ³)	VISCOSITY (CENTIPOISE)	SURFACE TENSION (DINES/CM)	BOILING POINT (°C)
Acetone	0.79	0.34	23.7	56
Isopropyl Alcohol	0.79	2.20	21.7	82
Ethyl Alcohol	0.79	1.20	21.4	78
Hexane	0.66	0.34	18.4	69
Octane	0.70	0.55	21.8	126
Ammonia (Liquid)	0.62	0.16	20	N/A
Water	1.00	1.00	72.8	100
0.1%/Wt QS10/H ₂ O (Surfactant Solution)	≅ 1.0	TBD	27.1	≅ 100

TABLE II
FLOW RATE MEASUREMENTS

FLUID COLUMN HEIGHT: 10 inches

ORIFICE DIMENSIONS: See Figures 2 and 3

FLUID	TEST	TIME (SEC)	WEIGHT (GMS)	FLOW (GMS/SEC)	TEMP. (°F)	
Acetone	1	60	300.2	5.0	70	
"	2	"	276.5	4.6	↓	
"	3	"	264.7	4.4		
"	4	"	260.7	4.3		
"	5	"	241.0	4.0		
"	6	"	237.0	4.0		
"	7	"	229.1	3.8		50
Isopropyl Alcohol	1	60	145.4	2.4		70
"	2	"	137.5	2.3	↓	
"	3	"	130.4	2.2		
"	4	"	118.5	2.0		
"	5	"	113.8	1.9		
"	6	"	106.7	1.8		
"	7	"	98.8	1.7		64
Water	1	60	260.0	4.3		70
"	2	"	265.0	4.4	↓	
"	3	"	264.0	4.4		
"	4	"	266.0	4.4		
"	5	"	265.0	4.4		
"						70




FIGURE 1

CROSS SECTIONAL SKETCH
OF
FLOW RATE MEASUREMENT TEST SET-UP




FIGURE 2

POLYETHYLENE METERING DEVICE
DIMENSIONS AND ORIFICE ARRANGEMENT







FIGURE 3

**POLYETHYLENE METERING DEVICE
ORIFICE DIMENSIONS**



DISTRIBUTION

F. T. Brewen	01/2230
T. C. Dvorak	01/2220
J. S. Hicks	01/2080
M. Kwan	01/2220
W. I. Rogers	01/2230
L. V. Warner	01/2111

MATERIAL SELECTION FOR AMMONIA SERVICE COMPONENTS
 PIPING CLASSIFICATION A
 CARBON STEEL (AMMONIA SERVICE)

GENERAL	Maximum pressure rating: Minimum temperature:	150 psig at 100°F Minus 28°F
PIPE	1/2 inch through 20 inches: Wall thickness for larger diameters: 24-36 inches 60-72 inches	ASTM A106, Grade B, or API-5L BRG or ASTM A333 GR6 standard weight, seamless or electric- resistance welded. 3/8 (.375) wall thickness. 9/16 (.5625) wall thickness.
FITTINGS	2" and smaller: 2-1/2" and larger:	ASTM A420, WPL6 or ASTM A105, Grade II, ANSI B16.11, 2000#, socket weld, carbon steel. ASTM A420, WPL6 or ASTM A234, Grade WPB, ANSI B16.9, same schedule as pipe, butt weld, carbon steel (long radius elbows).
FLANGES		ASTM A350-LF2 or ASTM A181, Grade II, ANSI B16.5, 300#, weld neck or slip on, raised face. Bore to match pipe I.D. Sealing surface finish 500 AARH or less.
GASKETS		Flexitallic Spiral wound type CG.
BOLTS		ASTM A193, Grade B8, ANSI B18.2.
NUTS		ASTM A194, Grade 4, ANSI B18.2 Heavy, semi-finished, hexagonal.

Note: Material for pipe, fittings and flanges shall match.

MATERIAL SELECTION FOR AMMONIA SERVICE COMPONENTS
 PIPING CLASSIFICATION B
 CARBON STEEL (WELDED) (NITROGEN GAS)

GENERAL	Maximum pressure rating:	275 psig at 100°F
	Minimum temperature:	Minus 20°F
PIPE	1/2 inch through 180 inches:	ASTM A53, Grade B, or ASTM A106 GRB standard weight, seamless or electric- resistance welded.
FITTINGS	2 inches and smaller:	ASTM A420, WPL6 or ASTM A105, Grade II, ANSI B16.11, 2000#, socket weld.
	2-1/2 inches and larger:	ASTM A420, WPL6 or ASTM B16.9, same schedule as pipe, black, but weld (long radius elbows).
FLANGES		ASTM A350-LF2 or ASTM A181, Grade II, ANSI B16.5, 150#, weld neck, raised face with concentric serrations. Bore to match pipe I.D.
GASKETS		Johns-Manville No. 76, 1/8 inch thick ring.
BOLTS		ASTM A193, Grade B7, ANSI B18.2.
NUTS		ASTM A195, Grade 4, ANSI B18.2 heavy, semi- finished, hexagonal.


MATERIAL SELECTION FOR AMMONIA SERVICE COMPONENTS
PIPING CLASSIFICATION C
CARBON STEEL (AMMONIA SERVICE)

GENERAL	Maximum pressure rating: Minimum temperature:	86 psig at 100°F Minus 28°F.
PIPE	1/2 inch through 20 inches: Wall thickness for larger diameters: 94-120 inches	ASTM A106, Grade B, or API-5L GRB or ASTM A333 GR6 standard weight, seamless or electric-resistance welded. 9/16 (.5625) wall thickness.
FITTINGS	2" and smaller: 2-1/2" and larger:	ASTM A420, WPL6 or ASTM A105, Grade II, ANSI B16.11, 2000#, socket weld, carbon steel. ASTM A420, WPL6 or ASTM A234, Grade WPB, ANSI B16.9, same schedule as pipe, butt weld, carbon steel (long radius elbows).
FLANGES		ASTM A350-LF2 or ASTM A181, Grade II, ANSI B16.5, 300#, weld neck or slip on, raised face. Bore to match pipe I.D. Sealing surface finish 500 AARH or less.
GASKETS		Flexitalllic Spiral wound type CG.
BOLTS		ASTM A193, Grade B7, ANSI B18.2.
NUTS		ASTM A194, Grade 4, ANSI B18.2 Heavy, semi-finished, hexagonal.

Note: Material for pipe, fittings and flanges shall match.


OTEC PSD I AMMONIA CONDENSER SUMP T-2

1	Service	LIQUID AMMONIA		Item	T-2	
2	Quantity	ONE (1)	Dia 120	in ID	Length between tangents	26'-6" horiz YES
3	DESIGN CONDITIONS			OPERATING CONDITIONS		
4	Code	ASME SECT. VIII DIV I		Operating pressure	psig	
5				Operating temp	50 °F	Liquid sp gravity .625
6	Design pressure, internal	150	psig	Liquid level for mechanical design is above the bottom TL 9'-0"		
7	At design temperature	-28 TO +120	°F			
8	Design pressure, external	7.5	psig			
9	At design temperature	-28 TO +120	°F			
10	Corrosion allow	1/8	in			
11	Joint eff, shell	85%	heads 100%			
12	Wind pressure	—				
13	Earthquake	— G				
14	Postweld heat treat	NO				
15	Radiograph	SPOT				
16	Insulation	YES	thk. 3	in		
17						
18	MATERIAL					
19	Heads	SA-516-60 (OR APPROV)				
20	Shell	SA-516-60 EQUAL				
21	Support	CARBON STEEL				
22	Nozzle necks	SA-106				
23	Flanges	SA-105				
24	Couplings	—				
25	Gaskets	FLEXITALLIC TYPE CG				
26	Fixed internals	—				
27	Removable internals	—				
28						
29	SUPPLIED BY SELLER					
30	Type support	SADDLES				
31	Manhole cover, hinged	YES	, w/davit —			
32	Insulation/fireproofing support	YES				
33	Clips for ladders and platforms	YES				
34	Clips for pipe supts and pipe guides	NO				
35	Lifting lugs	NO				
36	Surface preparation and paint	BLAST				
37		CLEAN PER SSPC SP6				
38		PRIME ORGANIC ZINC				
39	NOZZLES					
40	Mark	No	Size	Rtg Facing	Service	
41	N-1	1	6"	300#	RELIEF	
42	N-2	1	6"	300#	L.L. GUAGE	
43	N-3	1	24"	BW	PUMP	
44	N-4	1	6"	BW	MAKE-UP	
45	N-5	1	24"	BW	PUMP	
46	N-6	1	30"	BW	INLET	
47	M-1	1	18"	300#	MAN WAY	
48						
49						
50						
51						
52						
53						
54						
55						
56						
57						



OTEC PSD I AMMONIA EVAPORATOR SUMP T-1

1	Service LIQUID AMMONIA		Item T-1		
2	Quantity ONE (1) Dia 120 in ID	Length between tangents 28'-6"	horiz YES		
3	DESIGN CONDITIONS		OPERATING CONDITIONS		
4	Code ASME SECT VIII DIV 2	Operating pressure	psig		
5		Operating temp 60 °F	Liquid sp gravity .609		
6	Design pressure, internal 150 psig	Liquid level for mechanical design is above the bottom TL 9'-0"			
7	At design temperature -28 TO +120 °F				
8	Design pressure, external 7.5 psig				
9	At design temperature -28 TO +120 °F				
10	Corrosion allow 1/8 in				
11	Joint eff, shell 85% , heads 100%				
12	Wind pressure —				
13	Earthquake — G				
14	Postweld heat treat NO				
15	Radiograph SPOT				
16	Insulation YES thk. 3" in				
17					
18	MATERIAL				
19	Heads SA-516-60 (OR APP'VD)				
20	Shell SA-516-60 EQUAL				
21	Support CARBON STEEL				
22	Nozzle necks SA-106				
23	Flanges SA-105				
24	Couplings —				
25	Gaskets FLEXITALIC TYPE CG				
26	Fixed internals —				
27	Removable internals —				
28					
29	SUPPLIED BY SEALER				
30	Type support SADDLES				
31	Manhole cover, hinged YES , w/davit YES				
32	Insulation/fireproofing support YES				
33	Clips for ladders and platforms YES				
34	Clips for pipe supts and pipe guides NO				
35	Lifting lugs NO				
36	Surface preparation and paint BLAST CLEAN				
37	PER SSPC SP6, PRIME ORGANIC				
38	ZINC				
39	NOZZLES				
40	Mark	No	Size	Rtg Facing	Service
41	N-1	1	6"	300#	RELIEF
42	N-2	1	6"	BW	VENT
43	N-3	1	6"	300#	L.L. GAUGE
44	N-4	1	36"	BW	TO PUMP
45	N-5	1	36"	BW	TO PUMP
46	N-6	1	24"	BW	INLET
47	N-7	1	24"	BW	INLET
48	M-1	1	18"	300#	MANWAY
49					
50					
51					
52					
53					
54					
55					
56					
57					



INTEROFFICE CORRESPONDENCE

TO: L. A. Rosales

CC: T. C. Dvorak
J. Hicks

DATE: 29 August 1978

SUBJECT: NH₃ Compatibility of Steel

FROM: M. Kwan *mk*

BLDG.	MAIL STA.	EXT.
01	2220	51901

A literature search was conducted on ammonia compatibility of steels considered for OTEC application. Most of the available experimental data (1-4) on stress-corrosion cracking (SCC) in anhydrous ammonia has been performed on high strength, quenched and tempered steels (such as ASTM A517) used to construct ammonia cargo tanks. These steels, having yield strengths of approximately 100 ksi, have demonstrated their susceptibility to SCC in air contaminated liquid ammonia. Susceptibility to SCC is dependent on a number of factors including the operating temperature, strength of the steel, post-weld heat treatment, and purity of ammonia. Experimental and service experience have shown that the addition of 0.2% water in ammonia inhibits the SCC of these high strength steels.

With respect to the OTEC unit, the addition of 0.2% water to the ammonia may mean a 1 to 2 percent degradation in performance. In addition, the candidate steels being considered for OTEC application have significantly lower yield strengths (Table I). Kawamoto and Kenjo (5) conducted tests on three steels of different strengths where specimens were subjected to 4-point fulcra bending at applied stresses of 40%, 60%, 80% and 100% of their respective yield strengths and immersed in ammonia tanks at three plants. Test results show that those steels with tensile strengths below about 85 ksi can be considered insusceptible to SCC in liquid ammonia when residual stresses due to welding is on the order of the yield strength of the material. Figure 1 summarizes the SCC susceptibility of several steels as a function of tensile strength and applied stress (5). Furthermore, guidelines established for avoiding SCC in ammonia plants indicate that stress relief heat treatment is preferred, but not required, for steels with less than 50 ksi yield strength and operating at -5°C and above (6). Kawamoto (5) also conducted in-plant immersion tests on slit-type welded specimens of steel at three strength levels (75 ksi, 81 ksi, and 109 ksi yield strengths) which showed little difference in SCC susceptibility between exposures in gas phase

and liquid phase ammonia. Tests on welded specimens showed cracks beyond the heat-affected zone perpendicular to the weld line; these results indicate that as-quenched metal such as heat-affected zones may have lower susceptibility to SCC compared to the base metal in spite of the higher tensile strength.

It can be concluded that the steels for OTEC are sufficiently low strength that they can be considered insusceptible to SCC in liquid and vapor phase ammonia.

MK:dk


Table I. MECHANICAL PROPERTIES OF STEELS FOR OTEC

Type of Steel	Ultimate Tensile Strength (ksi)	Minimum Yield Strength (ksi)	% Elongation in 2"
SA516, GR70	70 - 90	38	21
SA515, GR70	70 - 90	38	21
SA283, GRD	60 - 72	33	23
SA285, GRB	50 - 70	27	28

REFERENCES

1. Phelps, E.H., "Causes of Stress-Corrosion Cracking of Steel in Ammonia," Ammonia Plant Safety, Vol. 16, pp 32-38.
2. Loginow, A.W. and E.H. Phelps, "Stress-Corrosion Cracking of Steels in Agricultural Ammonia," Corrosion, Vol. 18, No. 8, pp 299t - 309t (1962) August.
3. Deegan, D.C. and B.E. Wilde, "Stress Corrosion Cracking Behavior of ASTM A517 Grade F Steel in Liquid Ammonia Environments," Corrosion, Vol. 29, No. 8, pp 310 - 315 (1973) August.
4. Tones, D.A., C.D. Kim, and B.D. Wilde, "The Electrochemistry and Mechanism of Stress Corrosion Cracking of Constructional Steel in Liquid Ammonia," Corrosion, Vol. 33, No. 2, pp 50 -55 (1977) February.
5. Kawamoto, T., T. Kenjo and Y. Imasaka, "Study on Stress Corrosion Cracking of Liquid Ammonia Spherical Storage Tank", IHI Engineering Review, Vol. 10, No. 4, October 1977.
6. Clark, W.D. and A. Cracknell, "Safety in Ammonia Plants and Related Facilities Atlantic City: 30 August - 1 September 1976," AIChE Symposium.

Figure 1. SCC susceptibility of high strength steels in liquid ammonia (5)



APPENDIX E
DETAILED EQUIPMENT LISTS

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX E.1
SYSTEM EQUIPMENT LISTS

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

OTEC EQUIPMENT SUMMARY LIST 10 MWe

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
E-1	Evaporator	CP-SS14-51 and CFB Spec. No. 5304-100-117 5304-100-117-1	Nooter	451 Ton	26'3"Dia,54'7"H	(L.L.)*
C-1	Condenser	Same	Nooter	430 Ton	27'1"Dia,58'7"H	(L.L.)
TG-1	Turbine/Generator	CFB Spec. No. 5304-100-135-1	Elliot	100 Ton		Axial turbine, 4-4 1800 RPM, Variable inlet stators (L.L.) <hr/> 18 MW Generator, 13.8 KV
* (L.L.) = Long Lead						

S-3

POWER LOOP AMMONIA SUBSYSTEM

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTARY INFORMATION
V-1	Flow Control Valve	CP-EQ2-546		5,200	36" B.W.	Remote (L.L.)
V-2	Turbine Trip Valve	CP-EQ2-547		8,000	60" B.W.	Remote (L.L.)
V-3	Turbine By-Pass	CP-EQ2-547		3,600	30" B.W.	Remote (L.L.)
V-4	Evap. Drain Shut-Off	6850.7E-05		2,200	24" B.W.	Remote (L.L.)
V-5	Cond. Drain Shut-Off	6850.7E-05		3,700	30" B.W.	Remote (L.L.)
V-6	Ammonia Supply	CP-EQ2-544		125	6"-300# ANSI	Remote
V-7	Ammonia Return	CP-EQ2-544		125	6"-300# ANSI	Remote
V-8	Ammonia Return	CP-EQ2-544		125	6"-300# ANSI	Remote
V-9	Recirc. Pump Shut-Off	6850.78-05		4,500	36" B.W.	Manual (L.L.)
V-10	Recirc. Pump Shut-Off	6850.78-05		5,000	36" B.W.	Remote (L.L.)
V-11	Feed Pump Shut-Off	6850.78-05		1,900	24" B.W.	Manual (L.L.)
V-12	Feed Pump Shut-Off	6850.78-05		2,200	24" B.W.	Remote (L.L.)
V-13	Recirc. Pump Shut-Off	6850.78-05		4,500	36" B.W.	Manual (L.L.)
V-14	Recirc. Pump Shut-Off	6850.78-05		5,000	36" B.W.	Remote (L.L.)
V-15	Feed Pump Shut-Off	6850.78-05		1,900	24" B.W.	Manual (L.L.)
V-16	Feed Pump Shut-Off	6850.78-05		2,200	24" B.W.	Remote (L.L.)
V-17	Purge and Blowdown	6850.73-05		440	12"-300# ANSI	Remote
V-18	Non-Cond. Purge	6850.73-05		210	8"-300# ANSI	Remote
V-19	Purge and Blowdown	6850.73-05		440	12"-300# ANSI	Remote
V-20	Nitrogen Purge	6850.73-05		10	2"-300# ANSI	Remote
V-21	Nitrogen Purge	6850.73-05		10	2"-300# ANSI	Remote
V-22	Cond. Sump Shut-Off	6850.73-05		125	6"-300# ANSI	Remote
V-23	Evap. Sump Shut-Off	6850.73-05		125	1"-300# ANSI	Remote
V-24	Ammonia Purification	6850.73-05		8	1"-300# ANSI	Remote
V-25	Loop Shut-Off Valves	6850.73-05		10	1½"-300# ANSI	Remote

E-6

OTEC EQUIPMENT SUMMARY LIST 10 MWe
POWER LOOP AMMONIA SUBSYSTEM (CONT)

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTARY INFORMATION
P-3	Ammonia Recirc. Pump	CP-EQ2-545	Worthington	10,000	41 X 132	250 HP (L.L.)
P-4	Ammonia Recirc. Pump	CP-EQ2-545	20 LNS-28	10,000	41 X 132	250 HP (L.L.)
P-5	Ammonia Feed Pump	CP-EQ2-543	14 LNS-32	6,000		500 HP (L.L.)
P-6	Ammonia Feed Pump	CP-EQ2-543		6,000		500 HP (L.L.)
CV-1	Check Valve	6850.78-05		2,210	24" B.W.	(L.L.)
CV-2	Check Valve	6850.78-05		125	6"-300# ANSI	
PSV-1	Relief Valve	6850.78-05		440	12"-300# ANSI	Set 86 PSIG
PSV-2	Relief Valve	6850.78-05		440	12"-300# ANSI	Set 136 PSIG
PSV-3	Relief Valve	6850.78-05		200	6"-300# ANSI	Set 150 PSIG
PSV-4	Relief Valve	6850.78-05		200	6"-300# ANSI	Set 150 PSIG
PSV-5	Relief Valve	6850.78-05			1"-300# ANSI	Set 150 PSIG
PSV-6	Relief Valve	6850.78-05			1"-300# ANSI	Set 150 PSIG
PSV-7	Relief Valve	6850.78-05			1"-300# ANSI	Set 150 PSIG
PSV-8	Relief Valve	6850.78-05			1"-300# ANSI	Set 150 PSIG
PSV-9	Relief Valve	6850.78-05			1"-300# ANSI	Set 150 PSIG
T-1	Evap. Sump	CP-EQ2-541		52,000	See Spec.	(L.L.)
T-2	Cond. Sump	CP-EQ2-541		52,000	See Spec.	(L.L.)
F-1	Ammonia Filter	6850.78-05		5,000	36" B.W.	W/FLG FOR (L.L.)
F-2	Ammonia Filter	6850.78-05		5,000	36" B.W.	SERVICING (L.L.)
	MISCELLANEOUS CATEGORIES	FOR WEIGHT ESTIMATION				
	Piping, Fittings, Other Piping Loop Materials	6850.78-05		108,000	See Drawing	Field Assembled

E-7

OTEC EQUIPMENT SUMMARY LIST 10 MWe
AMMONIA STORAGE, CONDITIONING & SUPPLY SUBSYSTEM

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
T-101	NH ₃ Purification Column	6850.78-06	Riley-Beaird	8,100	Dia = 12", L=324"	Packed with 3/4" Ceramic Saddles(L.L.)
D-100	NH ₃ Heel Storage Drum	6850.78-06	Riley-Beaird	135,000	Dia = 168", L=300"	(L.L.)
D-101	Wet NH ₃ Storage Drum	6850.78-06	Riley-Beaird	135,000	Dia = 168", L=300"	(L.L.)
D102	Dry NH ₃ Storage Drum	6850.78-06	Riley-Beaird	135,000	Dia = 168", L=300"	(L.L.)
D103	NH ₃ Reflux Accumulator	6850.78-06	Riley-Beaird	1,100	Dia = 24", L= 36"	(L.L.)
D-104	NH ₃ Blowdown Drum	6850.78-06	Riley-Beaird	7,900	Dia = 72", L=120"	(L.L.)
D-105	Recovered NH ₃ Drum	6850.78-06	Riley-Beaird	1,000	Dia = 24", L= 36"	(L.L.)
E-100	NH ₃ Overhead Condenser	6850.78-06	Hughes-Anderson	2,100	Dia = 13 1/4", L = 168"	238 Ft ² (L.L.)
E-101	NH ₃ Compressor Condenser	6850.78-06	Hughes-Anderson	1,800	Dia = 12", L=168"	210 Ft ² (L.L.)
E-102	NH ₃ Column Reboiler	6850.78-06	Hughes-Anderson	-	Dia = 19"/36", L = 96"	Part of NH ₃ Purification Column 350 Ft ² (L.L.)
P-100	Evaporator Blowdown Pump	6850.78-06	Sundyne	610		10 GPM - 103 psi - 7.6 HP Motor
P-101	NH ₃ Transfer Pump	6850.78-06	Bingham	2,017		500 GPM - 153 psi - 100 HP Motor (L.L.)
P-102	NH ₃ Column Feed Pump	6850.78-06	Sundyne	562		10 GPM - 62 psi - 3 HP Motor
P-103	Reflux Pump	6850.78-06	Sundyne	705		10 GPM - 152 psi - 20 HP Motor
P-104	Recovered NH ₃ Pump	6850.78-06	Sundyne	332		10 GPM - 45 psi - 3 HP Motor
P-105	NH ₃ Blowdown Drum Pump	6850.78-06	Sundyne	585		15 GPM - 216 psi 20 HP Motor

MISCELLANEOUS CATEGORIES - FOR WEIGHT ESTIMATION

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
	Piping, Fittings & Other Pipe Loop Materials (Ammonia Support)	6850.78-06		38,000		

E-9

OTE EQUIPMENT SUMMARY LIST 10 MWe
 NITROGEN STORAGE, CONDITIONING & SUPPLY SUBSYSTEM

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
P-106	Liquid Nitrogen Transfer Pump	685C.78-07	Airco Cryogenics Duplex	985	1 1/2" - 300# Discharge 3" - 300# Suction	100 GFM, 255 psi (L.L.) 50 HP Motor
P-107	N ₂ - Heater Seawater Return Pump	6850.78-07	Bingham 3"x4"x11 1/2"	964	3" - 300# Discharge 4" - 300# Suction	250 GPM, 50 psi 15 HP Motor
P-108	Cold Seawater Pump	685C.78-07	Peerless 8 lb	2,350	6" - 125# ANSI FF Fig	350 GPM, 50 psi 15 HP Motor
P-109	Warm Seawater Pump	6850.78-07 3	Bingham	2,150	6" - 300# ANSI Discharge 8" - 300# ANSI Suction	1200 GPM, 50 psi 60 HP Motor
E-103	Nitrogen Vaporizer	6850.78-07	TBD	4,300	2" - 2" x 5' x 192" Long Tubes	To be Designed During Final Design (L.L.)
D-106	Liquid Nitrogen Storage Dewar	6850.78-07	TBD	47,000	Dia-122", L-384"	To be Designed and Built (L.L.)
D-107	Liquid Nitrogen Shipping Dewar	6850.78-07	TBD	88,000	Dia- 96",L-396"	To be Designed and Built (L.L.)
	Piping, Fittings and Other Pipe Loop Materials	6850.78-07		12,000		

E-10

ELECTRICAL SUBSYSTEM

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
E-11	ELECTRICAL POWER DISTRIBUTION AND CONTROL CP-SS14-53					
	15 KV Switchgear	CP-E 2-548	GE/WH	38,000	90"Hx244"Wx78"D	(L.L.)
	480 V Power Transformer	CP-EQ2-551	GE/WH	5,000	90"Hx64"Wx60"D	1500 KVA (L.L.)
	480 V Motor Control Center	CP-EQ2-553	GE/WH	4,800	90"Hx144"Wx20"D	
	480 V Auto Transfer Switch	CP-EQ2-555	GE/WH	650	69"Hx40"Wx16"D	Conduits
	Wiring & Conduit	CP-SS14-53	GE/WH	10,000	NA	Conduits, Condulets, J Boxes, Cables Signal Wire, Misc. Hardware, Etc.
	Local Control Station	CP-SS14-53	GE/WH	1	6"H x 4"W x 2"D	1 Unit per Drive
	INSTRUMENTATION AND CONTROL SUBSYSTEM CP-SS14-3					
		C F Braun Project Report No. 5304-P Instrument List		25,000	Refer to Spec	Ammonia Power Loop Ammonia Storage Subsystem Nitrogen Storage Subsystem

OTEC EQUIPMENT SUMMARY LIST 10 MWe
 BIOFOULING CONTROL AND AMMONIA LEAK DETECTION SUBSYSTEM

E-12

REFERENCE DESIGNATOR	DESCRIPTION	SPEC OR DWG NO.	MFG & PART NO.	EST WT. (LB)	DIMENSIONS	SUPPLEMENTAL INFORMATION
	BIOFOULING CONTROL SUBSYSTEM	CP-SS14-47				
	Tube Cleaning Subsystem	CP-SS14-45	TBD	10,000		(L.L.)
	Positioner	CP-EQ2-556	TBD	4,000	13'5"H, 33'L, 27'W	
	Tube Cleaning Head	CP-EQ2-557	TBD	1,000	32'H, 1.5'D	(L.L.)
	Controller/Recorder	CP-EQ2-558	TBD	50		
	Electrolytic Seawater Chlorinator	CP-EQ2-542		4,300		
	AMMONIA LEAK DETECTION SUBSYSTEM	CP-SS14-48	TBD	4,500		Many Small Packages
Air Monitor, (Ammonia Detector) Infrared Analyzer		Beckman Model Set	750	3'W x 3'D x 2'5"H	Includes Remote Sensing Equipment	

APPENDIX E.2

SPECIAL SUPPORT EQUIPMENT LIST

E.2. SPECIAL SUPPORT EQUIPMENT LIST

Following is a preliminary list of identified special support equipment. The list does not necessarily represent the total items of this nature required and is expected to change during final design. Some of the equipment required to support the operation of an OTEC Modular Application Power System (MAPS) were considered important enough to be treated as separate subsystems because of their specific interface requirements with components of the MAPS.

Equipment required for operational support activities are as follows:

- Tube Cleaner

Described in Appendix C

- Leak Detection Equipment

Described in Appendix H

- Ammonia Resupply System

A ship, barge, or work boat mounted tank for transporting ammonia to an OTEC platform.(not part of this contract).

- Nitrogen Resupply System

A vacuum jacketed tank capable of being transported by ship, barge or work boat to an OTEC platform. Approximate capacity - 8,000 gallons.

- Startup Power Unit

An 11.5 MVA power source is required for initial startup of a 10 MWe MAPS module. The requirements for this are described in Section 2.10 of the PDR. This unit is not part of this contract.

- Standby Power

A 563 KVA power source is required to permit orderly shutdown at the 10 MWe MAPS module during system shutdowns. This requirement is described in Section 2.10 of this PDR. This unit is not part of this contract. It is anticipated that this power will be available from the platform's main power source.

- Primary Crane for Installation of Heat Exchangers, Turbine Generator and Other Heavy Components

A 150 ton crane is required for installation of Heat Exchangers as described in Section 2.1.1 of this PDR. This crane may be part of the OTEC platform or it may be provided by a separate service and installation ship. It is not part of this contract.

- Material Handling Equipment for Other Components of the MAPS Module

Various on-board hoists, cranes, and monorails may be required for installation, servicing and replacement of MAPS major components, such as pump, valves and filters. These items have not been defined but will be in the final design. (TBD)

- Heat Exchanger Shipping Fixtures

Special shipping fixtures will be required for transporting of the heat exchangers from the point of manufacture to the final place of installation. These fixtures are TBD. They will be defined and designed as part of the heat exchangers final design.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX E.3
MACHINERY TOOLS AND SPARE PARTS LIST, 10 MWe

E.3. MACHINERY TOOLS AND SPARE PARTS LIST, 10 MWe

The special machinery equipment will consist of handling equipment for the evaporator, condenser, and tube cleaner (slings, etc.) and hydraulic tube expanding equipment for the initial fabrication and subsequent repairing of tube-to-tube sheet joints. Special tools for maintenance of the turbine generator are listed below. They will be shipped with the unit and are priced as part of the turbine-generator unit.

The machinery and equipment, to be fabricated separately from equipment list items, are listed below

<u>Component Supported</u>	<u>Support Equipment</u>	<u>No. Required</u>	<u>Weight</u>
1. Evaporator and Condenser	Lifting and Positioning Fixture	1	
2. Tube Cleaning Positioner	Lifting Fixture	1	
3. Tube Cleaning Head	Lifting Fixture	1	
4. Evaporator and Condenser	Hydro Expanding Tool	2	
5. Turbine Generator	Inner Casing Removal Rails Centering Rings Endwall Counterweight		

Other items may be identified during final design. Conventional tools required for normal maintenance are not included as they are expected to be the standard commercially available tools carried as workman's tools.

Spare parts will be defined during the final design and will consist of such things as circuit breakers, motors, tubing plugs, pump and valve seals, stem and shaft packing, tube cleaner brushes, instrumentation sensors and the like.

APPENDIX E.4

LONG LEAD TIME PROCUREMENT, 200 kWe AND 10 MWe

E.4 LONG LEAD TIME PROCUREMENT LIST, 200 kWe AND 10 MWe

The Phase II, master milestone schedule, Task 1.1.8 places DOE procurement and fabrication authorization at Phase II go-ahead plus 5 months. Long lead items are defined as those items which must be purchased in advance of the fifth month milestone to guarantee integration into the deliverable hardware package prior to scheduled hardware delivery, Task 1.1.11 on the fourteenth month.

The identifiable long lead items, requiring procurement authorization prior to the scheduled authorization date (Phase II go-ahead plus 5 months) are listed below.

Long Lead Item	Expected Procurement or Fabrication Time (Month)	Need Date Based on Phase II Go-Ahead (Month)
Heat Exchanger Test Article Condenser	12	14
Heat Exchanger Test Article Evaporator	12	14
Heat Exchanger Tubes, 0.2 MWe	TBD	8
Evaporator Recirculation Pump	12	14
Evaporator Sump	14	14
Flow Control Valve	10	14
Filter Unit	8	14

Remaining deliverable items are currently available within 9 months after award of contract (Task 1.1.8).

The Phase II, master milestone schedule, Task 2.1.7 places DOE procurement and fabrication authorization at the end of the sixth month of Phase II activity. This master milestone schedule is used to define long lead items as those items which must be purchased in advance of the sixth month milestone to guarantee integration into the deliverable hardware package prior to scheduled hardware delivery, Task 2.1.10, on the twenty-fourth month.

The identifiable long lead items, requiring procurement authorization prior to the scheduled authorization date (Phase II go-ahead plus 6 months) are indicated on the OTEC Equipment Summary List, 10 MWe, of this Appendix Section E-1, by the symbol L.L. in the supplemental information column.

Remaining deliverable items are currently available within 18 months after award of contract (Task 2.1.7).

APPENDIX F
TURBINE DESIGN STUDIES

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX F.1
TURBINE PRELIMINARY DESIGN ANALYSIS

F.1 TURBINE PRELIMINARY DESIGN ANALYSIS

Contained herein are the results of an unconstrained analysis of the optimum geometry for ammonia turbines operating between 70°F inlet state and 50°F outlet state. For multistage turbines, only the first stage analysis is given based on equal loading for each stage. Power output is 14 MWe overall with 1% bearing losses and a generator efficiency of 98%. This analysis was performed by Dr. Ambs of University of Massachusetts, consultant to TRW.

Single Stage Single Flow

T TURBINE TB=70.,TC=50.,GP=14.,RND=3600.,DELD=.04,SH=.04,TBH=.04 SEND

TURBINE DESIGN FOR 14.00 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(Psia),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	50.0000	62.9488	68.4022	70.0000
STATIC PRESSURE	89.3447	113.7277	125.4049	128.9944
TOTAL PRESSURE	89.9809	125.4078	126.2579	
STATIC ENTHALPY	611.8146	623.6296	628.8471	629.1218
TOTAL ENTHALPY	612.1920	629.2218	629.2218	
SP. VOLUME	3.2053	2.5867	2.3728	
ENTROPY	1.2188	1.2165	1.2163	1.2139
QUALITY	.9745	.9918	1.0000	
VISCOSITY	.232E-01	.238E-01	.240E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	113.0038	118.3674		
TOTAL ENTHALPY	612.5784	612.5784		
PRESSURE RATIO	1.4132			

SPECIFIC SPEED	137.9737				
SPECIFIC DIAMETER	1.1984				
EFFICIENCIES	.8842	TURBOGENERATOR	.9800	GENERATOR	.0100 BEARING LOSS
ROTATIONAL SPEED RPM	3600				
MASS FLOW LBM/SEC	803.2858				
MACHINE REYNOLDS NO.	.2803E+09				
DISK RE. NO.	.3076E+08				
STATOR BLADE RE. NO.	.2364E+08				
ROTOR BLADE RE. NO.	.4487E+08				
STATOR THETA RE. NO.	.3305E+05				
ROTOR THETA RE. NO.	.5838E+05				
REACTION	.6933				

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	5.5381	4.9751	4.7649
B. HEIGHT	1.4718	1.3222	1.2663
	ROTOR		STATOR
PITCH	1.3586		.7548
AXIAL WIDTH	.2569		.4193
CAMBER LINE LENGTH	1.4138		.9772
CHORD LENGTH	1.4138		.8877
TRAILING EDGE THICKNESS	.0589		.0529
STAGGER ANGLE	10.4678		28.1868
INLET ANGLE	24.2459		90.0000
OUTLET ANGLE	6.6289		15.0000
NO. BLADES	10.0000		18.0000

RATIOS

ASPECT		.9606	.6714
SOLIDITY		.9610	.8502
RADIUS		.4685	
BL. HEIGHT/DIAM.		.2658	
GAS FLOW ANGLES	EXIT	85.0489	UNDER TURNING 2.7733
CLEARANCE	TIP	.0589	ROTOR HOUSING .2215

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 4.3245 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	137.4569	529.1111	136.9440
AXIAL COMP.	136.9440	136.9440	
TANGENTIAL COMP.	11.8634	511.0821	
RELATIVE	838.2693	333.4779	
TANGENTIAL COMP.	827.0077	-304.0622	
PERIPHERAL	815.1443		

DIMENSIONLESS DESIGN RATIOS

BLADE JET SPEED RATIO	.842782	FLOW COEF	.168000
BLADE LOADING COEF	.703946	SPEED WORK COEF	1.420564
SPECIFIC SPEED	1.069563	SPECIFIC DIAM	2.853484
EXIT VELOCITY/SPOUTING	.020197		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK

TOTAL TO TOTAL	.920882	TOTAL TO STATIC	.902282
CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES			
TOTAL TO TOTAL	.920788	TOTAL TO STATIC	.902190

Single Stage Double Flow

7 TURBINE TB=70.,TC=50.,GP=7.,RND=3600. *END

TURBINE DESIGN FOR 7.00 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(P(SIA),H(BTU/LBM),V(CUVT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	50.0000	62.0012	69.5016	70.0000
STATIC PRESSURE	89.3447	111.7869	127.8664	128.9944
TOTAL PRESSURE	90.1708	126.7407	128.9944	128.9944
STATIC ENTHALPY	610.8638	621.8647	629.0368	629.1218
TOTAL ENTHALPY	611.3530	629.1218	629.1218	629.1218
SP. VOLUME	3.1994	2.6220	2.3285	
ENTROPY	1.2169	1.2150	1.2146	1.2139
QUALITY	.9727	.9887	1.0000	1.0000
VELOCITY	156.0035	156.0035	156.0035	0.0000
VISCOSITY	.232E-01	.237E-01	.241E-01	

RELATIVE STATE PROPERTIES

TOTAL PRESSURE	110.5454	114.1622		
TOTAL ENTHALPY	611.7320	611.7320		
PRESSURE RATIO	1.4438			

SPECIFIC SPEED 92.7090
 SPECIFIC DIAMETER 1.4642
 EFFICIENCIES .8858 TURBOGENERATOR .9800 GENERATOR .0100 BEARING LOSS

ROTATIONAL SPEED RPM 3600.
 MASS FLOW LBM/SEC 385.4524
 MACHINE REYNOLDS NO. .1969E+09
 DISK RE. NO. .5235E+08
 STATOR BLADE RE. NO. .1527E+08
 ROTOR BLADE RE. NO. .2449E+08
 STATOR THETA RE. NO. .2037E+05
 ROTOR THETA RE. NO. .2987E+05
 REACTION .6174

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	4.6367	4.1975	3.9556
B. HEIGHT	.6277	.5682	.5355
	ROTOR	STATOR	
PITCH	.6710	.3863	
AXIAL WIDTH	.1884	.2146	
CAMBER LINE LENGTH	.7266	.5001	
CHORD LENGTH	.7266	.4544	
TRAILING EDGE THICKNESS	.0251	.0227	
STAGGER ANGLE	15.0250	28.1868	
INLET ANGLE	40.4967	90.0000	
OUTLET ANGLE	9.0474	15.0000	
NO. BLADES	19.0000	33.0000	

RATIOS

ASPECT	1.1577	.7997	
SOLIDITY	.9234	.8502	
RADIUS	.7293		
BL. HEIGHT/DIAM.	.1354		
GAS FLOW ANGLES	EXIT 85.4542	UNDER TURNING	2.3011
CLEARANCE	TIP .0251	ROTOR HOUSING	.1855

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 4.0579 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	156.4958	602.7511	156.0035
AXIAL COMP. ,	156.0035	156.0035	
TANGENTIAL COMP.	12.4032	582.2129	
RELATIVE	792.7941	240.2253	
TANGENTIAL COMP.	777.2937	-182.6776	
PERIPHERAL	764.8905		

DIMENSIONLESS DESIGN RATIOS

BLADE JET SPEED RATIO	.775408	FLOW COEF	.203955
BLADE LOADING COEF	.831591	SPEED WORK COEF	1.202514
SPECIFIC SPEED	.718674	SPECIFIC DIAM	3.486152
EXIT VELOCITY/SPOUTING	.025169		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK

TOTAL TO TOTAL .927222 TOTAL TO STATIC .903884

CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES

TOTAL TO TOTAL .927244 TOTAL TO STATIC .903906

TWO STAGE SINGLE FLOW

T TURBINE TB=70.,TC=60.,GP=7.,RND=1800. SEND

TURBINE DESIGN FOR 7.00 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	60.0000	66.2448	69.7664	70.0000
STATIC PRESSURE	107.7721	120.6804	128.4648	128.9944
TOTAL PRESSURE	108.2306	128.1615	128.9944	128.9944
STATIC ENTHALPY	620.0880	625.7298	629.0820	629.1218
TOTAL ENTHALPY	620.3178	629.1218	629.1218	629.1218
SP. VOLUME	2.7088	2.4496	2.3180	
ENTROPY	1.2153	1.2144	1.2142	1.2139
QUALITY	.9861	.9947	1.0000	1.0000
VELOCITY	106.6541	106.6541	106.6541	0.0000
VISCOSITY	.236E-01	.239E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	120.7656	122.1919		
TOTAL ENTHALPY	620.5716	620.5716		
PRESSURE RATIO	1.1969			

SPECIFIC SPEED	102.6137			
SPECIFIC DIAMETER	1.3831			
EFFICIENCIES	.8866	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	1800.			
MASS FLOW LBM/SEC	777.5841			
MACHINE REYNOLDS NO.	.2468E+09			
DISK RE. NO.	.5675E+08			
STATOR BLADE RE. NO.	.1899E+08			
ROTOR BLADE RE. NO.	.3362E+08			
STATOR THETA RE. NO.	.2510E+05			
ROTOR THETA RE. NO.	.4050E+05			
REACTION	.6390			

GEOMETRY SPECIFICATION-LENGTH IN FEET	ROTOR EXIT	ROTOR INLET	STATOR INLET.
DIAMETER	6.8237	6.4890	6.3123
B. HEIGHT	1.0979	1.0441	1.0156
	ROTOR	STATOR	
PITCH	1.1447	.6784	
AXIAL WIDTH	.2900	.3769	
CAMBER LINE LENGTH	1.2253	.8782	
CHORD LENGTH	1.2253	.7979	
TRAILING EDGE THICKNESS	.0439	.0418	
STAGGER ANGLE	13.6891	28.1868	
INLET ANGLE	35.1557	90.0000	
OUTLET ANGLE	8.3766	15.0000	
NO. BLADES	16.0000	27.0000	
RATIOS			
ASPECT	1.1160	.7642	
SOLIDITY	.9342	.8502	
RADIUS	.6782		
BL. HEIGHT/DIAM.	.1609		
GAS FLOW ANGLES	EXIT 83.8138	UNDER TURNING	2.3870
CLEARANCE	TIP .0439	ROTOR HOUSING	.2729

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 5.830. FEET	STATION 3	STATION 2	STATION 1
ABSOLUTE	107.2788	412.0797	106.6541
AXIAL COMP.	106.6541	106.6541	
TANGENTIAL COMP.	11.5604	398.0384	
RELATIVE	571.0868	0 185.2277	
TANGENTIAL COMP.	561.0392	-151.4405	
PERIPHERAL	549.4788		
DIMENSIONLESS DESIGN RATIOS			
BLADE JET SPEED RATIO	.791516	FLOW COEF	.194100
BLADE LOADING COEF	.798088	SPEED WORK COEF	1.252994
SPECIFIC SPEED	.795455	SPECIFIC DIAM	3.293264
EXIT VELOCITY/SPOUTING	.023881		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .926803 TOTAL TO STATIC .904670
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .926859 TOTAL TO STATIC .904725

Two Stage Double Flow

? \$TURBINE TB=70.,TC=60.,BP=3.5,RND=3600.,SH=.04,DELD=.04,TBH=.04 \$END

TURBINE DESIGN FOR 3.50 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	60.0000	66.7442	69.4912	70.0000
STATIC PRESSURE	107.7721	121.7616	127.8429	128.9944
TOTAL PRESSURE	108.1445	127.9572	128.2762	
STATIC ENTHALPY	620.4691	626.4335	629.0350	629.1218
TOTAL ENTHALPY	620.6560	629.2218	629.2218	
SP. VOLUME	2.7108	2.4315	2.3290	
ENTROPY	1.2161	1.2148	1.2146	1.2139
QUALITY	.9868	.9959	1.0000	
VISCOSITY	.236E-01	.240E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	122.1416	124.5291		
TOTAL ENTHALPY	620.6996	620.6996		
PRESSURE RATIO	1.1903			

SPECIFIC SPEED	140.4547			
SPECIFIC DIAMETER	1.1610			
EFFICIENCIES	.8740	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	3600			
MASS FLOW LBM/SEC	399.2135			
MACHINE REYNOLDS NO.	.1796E+09			
DISK RE. NO.	.1435E+08			
STATOR BLADE RE. NO.	.1320E+08			
ROTOR BLADE RE. NO.	.2642E+08			
STATOR THETA RE. NO.	.2070E+05			
ROTOR THETA RE. NO.	.3779E+05			
REACTION	.6985			

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	4.1181	3.9001	3.8170
B. HEIGHT	1.2361	1.1707	1.1457
	ROTOR	STATOR	
PITCH	.9852	.5795	
AXIAL WIDTH	.1717	.3219	
CAMBER LINE LENGTH	1.0278	.7503	
CHORD LENGTH	1.0278	.6816	
TRAILING EDGE THICKNESS	.0494	.0468	
STAGGER ANGLE	9.6174	28.1868	
INLET ANGLE	22.7836	90.0000	
OUTLET ANGLE	6.0583	15.0000	
NO. BLADES	10.0000	17.0000	
RATIOS			
ASPECT	.8315	.5822	
SOLIDITY	.9585	.8502	
RADIUS	.3997		
BL. HEIGHT/DIAM.	.3002		
GAS FLOW ANGLES	EXIT 88.9047	UNDER TURNING	3.2039
CLEARANCE	TIP .0494	ROTOR HOUSING	.1647

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 3.1359 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	96.7163	373.6149	96.6987
AXIAL COMP.	96.6987	96.6987	
TANGENTIAL COMP.	1.8489	360.8843	
RELATIVE	600.7871	249.7045	
TANGENTIAL COMP.	592.9541	-230.2210	
PERIPHERAL	591.1052		

DIMENSIONLESS DESIGN RATIOS

BLADE JET SPEED RATIO	.856681	FLOW COEF	.163590
BLADE LOADING COEF	.681289	SPEED WORK COEF	1.467806
SPECIFIC SPEED	1.150812	SPECIFIC DIAM	2.764315
EXIT VELOCITY/SPOUTING	.019648		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .909729 TOTAL TO STATIC .891855
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .909762 TOTAL TO STATIC .891888

THREE STAGE SINGLE FLOW

RNH

T TURBINE TB=70.,TC=63.3,GP=4.67,RND=1800. @END

TURBINE DESIGN FOR 4.67 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PNSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	63.3000	67.8387	69.8659	70.0000
STATIC PRESSURE	114.4535	124.1576	128.6902	128.9944
TOTAL PRESSURE	114.7337	128.5564	128.9944	128.9944
STATIC ENTHALPY	623.1281	627.1770	629.0989	629.1218
TOTAL ENTHALPY	623.2613	629.1218	629.1218	629.1218
SP. VOLUME	2.5680	2.3886	2.3141	
ENTROPY	1.2149	1.2142	1.2141	1.2139
QUALITY	.9907	.9969	1.0000	1.0000
VELOCITY	80.7574	80.7574	80.7574	0.0000
VISCOSITY	.238E-01	.240E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	124.7612	125.8381		
TOTAL ENTHALPY	623.4917	623.4916		
PRESSURE RATIO	1.1270			

SPECIFIC SPEED	135.0860				
SPECIFIC DIAMETER	1.2097				
EFFICIENCIES	.8822	TURBOGENERATOR	.9800	GENERATOR	.0100 BEARING LOSS
ROTATIONAL SPEED RPM	1800.				
MASS FLOW LBM/SEC	778.6768				
MACHINE REYNOLDS NO.	.2295E+09				
DISK RE. NO.	.2722E+08				
STATOR BLADE RE. NO.	.1668E+08				
ROTOR BLADE RE. NO.	.3799E+08				
STATOR THETA RE. NO.	.2443E+05				
ROTOR THETA RE. NO.	.5023E+05				
REACTION	.6902				

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	6.4287	6.2000	6.1026
B. HEIGHT	1.6490	1.5904	1.5654
	ROTOR	STATOR	
PITCH	1.5884	.8360	
AXIAL WIDTH	.3057	.4645	
CAMBER LINE LENGTH	1.6551	1.0824	
CHORD LENGTH	1.6551	.9833	
TRAILING EDGE THICKNESS	.0660	.0636	
STAGGER ANGLE	10.6434	28.1868	
INLET ANGLE	24.7551	90.0000	
OUTLET ANGLE	6.7305	15.0000	
NO. BLADES	10.0000	19.0000	
RATIOS			
ASPECT	1.0037	.6183	
SOLIDITY	.9597	.8502	
RADIUS	.4870		
BL. HEIGHT/DIAM.	.2565		
GAS FLOW ANGLES	EXIT 81.4767	UNDER TURNING	2.6542
CLEARANCE	TIP .0660	ROTOR HOUSING	.2571

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 5.0561 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	81.6593	312.0226	80.7574
AXIAL COMP.	80.7574	80.7574	
TANGENTIAL COMP.	12.1029	301.3907	
RELATIVE	495.2575	192.8578	
TANGENTIAL COMP.	488.6290	-175.1353	
PERIPHERAL	476.5261		
DIMENSIONLESS DESIGN RATIOS			
BLADE JET SPEED RATIO	.838932	FLOW COEF	.169471
BLADE LOADING COEF	.710422	SPEED WORK COEF	1.407613
SPECIFIC SPEED	1.047178	SPECIFIC DIAM	2.880375
EXIT VELOCITY/SPOUTING	.020668		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .919247 TOTAL TO STATIC .900248
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .919161 TOTAL TO STATIC .900164

*TURBINE TB=70.,TC=63.3,GP=2.33,RND=1800.,DELD=.04,TBM=.04,SH=.04 SEND

TURBINE DESIGN FOR 2.33 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	63.3000	67.3680	69.6678	70.0000
STATIC PRESSURE	114.4535	123.1229	128.2417	128.9944
TOTAL PRESSURE	114.7829	128.3690	128.6060	
STATIC ENTHALPY	623.2172	626.8845	629.0652	629.1218
TOTAL ENTHALPY	623.3738	629.2218	629.2218	
SP. VOLUME	2.5685	2.4070	2.3219	
ENTROPY	1.2151	1.2145	1.2144	1.2130
QUALITY	.9908	.9965	1.0000	
VISCOSITY	.238E-01	.240E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	123.0178	124.0301		
TOTAL ENTHALPY	623.3907	623.3907		
PRESSURE RATIO	1.1237			

SPECIFIC SPEED	96.2231			
SPECIFIC DIAMETER	1.4331			
EFFICIENCIES	.8872	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	1800			
MASS FLOW LBM/SEC	389.7925			
MACHINE REYNOLDS NO.	.1620E+09			
DISK RE. NO.	.4101E+08			
STATOR BLADE RE. NO.	.1139E+08			
ROTOR BLADE RE. NO.	.2034E+08			
STATOR THETA RE. NO.	.1605E+05			
ROTOR THETA RE. NO.	.2594E+05			
REACTION	.6246			

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	5.4007	5.2283	5.1350
B. HEIGHT	.7788	.7539	.7405
	ROTOR	STATOR	
PITCH	.8181	.4750	
AXIAL WIDTH	.2241	.2639	
CAMBER LINE LENGTH	.8811	.6150	
CHORD LENGTH	.8811	.5587	
TRAILING EDGE THICKNESS	.0312	.0302	
STAGGER ANGLE	14.7356	28.1868	
INLET ANGLE	38.4902	90.0000	
OUTLET ANGLE	8.9541	15.0000	
NO. BLADES	18.0000	31.0000	
RATIOS			
ASPECT	1.1313	.7410	
SOLIDITY	.9285	.8502	
RADIUS	.7116		
BL. HEIGHT/DIAM.	.1442		
GAS FLOW ANGLES	EXIT 89.3805	UNDER TURNING	2.3548
CLEARANCE	TIP .0312	ROTOR HOUSING	.2160

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 4.6871 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	88.5382	342.9655	88.5331
AXIAL COMP.	88.5331	88.5331	
TANGENTIAL COMP.	.9573	330.4099	
RELATIVE	451.4732	142.2490	
TANGENTIAL COMP.	442.7075	-111.3403	
PERIPHERAL	441.7502		
DIMENSIONLESS DESIGN RATIOS			
BLADE JET SPEED RATIO	.781163	FLOW COEF	.200414
BLADE LOADING COEF	.819382	SPEED WORK COEF	1.220431
SPECIFIC SPEED	.745916	SPECIFIC DIAM	3.412251
EXIT VELOCITY/SPOUTING	.024513		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .928011 TOTAL TO STATIC .905263
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .928032 TOTAL TO STATIC .905283

FOUR STAGE SINGLE FLOW

7 TURBINE TB=70.,TC=65.,GP=3.5,RND=1800. \$END

TURBINE DESIGN FOR 3.50 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	65.0000	68.3314	69.8970	70.0000
STATIC PRESSURE	118.0173	125.2477	128.7605	128.9944
TOTAL PRESSURE	118.2482	128.6543	128.9944	128.9944
STATIC ENTHALPY	624.7809	627.6273	629.1042	629.1218
TOTAL ENTHALPY	624.8877	629.1218	629.1218	629.1218
SP. VOLUME	2.4996	2.3701	2.3129	
ENTROPY	1.2149	1.2141	1.2140	1.2139
QUALITY	.9933	.9976	1.0000	1.0000
VELOCITY	70.7927	70.7927	70.7927	0.0000
VISCOSITY	.239E-01	.240E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	125.8908	126.8743		
TOTAL ENTHALPY	624.5660	624.5660		
PRESSURE RATIO	1.0930			

SPECIFIC SPEED	169.3222			
SPECIFIC DIAMETER	1.0989			
EFFICIENCIES	.8563	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	1800.			
MASS FLOW LBM/SEC	807.5588			
MACHINE REYNOLDS NO.	.2269E+09			
DISK RE. NO.	.1021E+08			
STATOR BLADE RE. NO.	.1513E+08			
ROTOR BLADE RE. NO.	.2915E+08			
STATOR THETA RE. NO.	.2397E+05			
ROTOR THETA RE. NO.	.4205E+05			
REACTION	.6789			

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	6.3162	6.1505	6.0758
B. HEIGHT	2.2107	2.1527	2.1265
	ROTOR	STATOR	
PITCH	1.4649	.9156	
AXIAL WIDTH	.2422	.5086	
CAMBER LINE LENGTH	1.5325	1.1853	
CHORD LENGTH	1.5325	1.0768	
TRAILING EDGE THICKNESS	.0884	.0861	
STAGGER ANGLE	9.0937	28.1868	
INLET ANGLE	21.9965	90.0000	
OUTLET ANGLE	5.6994	15.0000	
NO. BLADES	10.0000	16.0000	
RATIOS			
ASPECT	.6932	.5002	
SOLIDITY	.9559	.8502	
RADIUS	.300C		
BL. HEIGHT/DIAM.	.3500		
GAS FLOW ANGLES EXIT	104.5116	UNDER TURNING	3.8429
CLEARANCE TIP	.0884	ROTOR HOUSING	.2526

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 4.6629 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	73.1256	273.5220	70.7927
AXIAL COMP.	70.7927	70.7927	
TANGENTIAL COMP.	-18.3235	264.2019	
RELATIVE	427.0361	189.0073	
TANGENTIAL COMP.	421.1273	-175.2489	
PERIPHERAL	439.4508		
DIMENSIONLESS DESIGN RATIOS			
BLADE JET SPEED RATIO	.896609	FLOW COEF	.161094
BLADE LOADING COEF	.621962	SPEED WORK COEF	1.607816
SPECIFIC SPEED	1.312575	SPECIFIC DIAM	2.616492
EXIT VELOCITY/SPOUTING	.022260		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .893674 TOTAL TO STATIC .873781
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .893719 TOTAL TO STATIC .873825

FOUR STAGE DOUBLE FLOW

? TURBINE TB=70.,TC=65.,GP=1.75,RND=1800.,SH=.04,DELD=.04,TBM=.04 SEND

TURBINE DESIGN FOR 1.75 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	65.0000	68.3332	69.9443	70.0000
STATIC PRESSURE	118.0173	125.2518	128.8680	128.9944
TOTAL PRESSURE	118.2550	128.9773	129.1239	
STATIC ENTHALPY	624.5992	627.5876	629.1123	629.1218
TOTAL ENTHALPY	624.7091	629.2218	629.2218	
SP. VOLUME	2.4987	2.3699	2.3110	
ENTROPY	1.2145	1.2140	1.2139	1.2139
QUALITY	.9929	.9976	1.0000	
VISCOSITY	.239E-01	.240E-01	.241E-01	

RELATIVE STATE PROPERTIES

TOTAL PRESSURE	125.3978	126.2203		
TOTAL ENTHALPY	624.7855	624.7854		
PRESSURE RATIO	1.0941			

SPECIFIC SPEED 113.5684
 SPECIFIC DIAMETER 1.3125
 EFFICIENCIES .8865 TURBOGENERATOR .9800 GENERATOR .0100 BEARING LOSS

ROTATIONAL SPEED RPM 1800
 MASS FLOW LBM/SEC 379.1503
 MACHINE REYNOLDS NO. .1498E+09
 DISK RE. NO. .2856E+08
 STATOR BLADE RE. NO. .1133E+08
 ROTOR BLADE RE. NO. .2255E+08
 STATOR THETA RE. NO. .1669E+05
 ROTOR THETA RE. NO. .3023E+05
 REACTION .6603

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	5.1318	4.9977	4.9353 (30.6" Base Diameter)
B. HEIGHT	.9815	.9539	.9439
	ROTOR	STATOR	
PITCH	1.0306	.5825	
AXIAL WIDTH	.2386	.3236	
CAMBER LINE LENGTH	1.0874	.7542	
CHORD LENGTH	1.0874	.6851	
TRAILING EDGE THICKNESS	.0393	.0382	
STAGGER ANGLE	12.6747	28.1868	
INLET ANGLE	30.8042	90.0000	
OUTLET ANGLE	7.9119	15.0000	
NO. BLADES	13.0000	23.0000	

RATIOS

ASPECT	1.1079	.7168	
SOLIDITY	.9478	.8502	
RADIUS	.6175		
BL. HEIGHT/DIAM.	.1913		
GAS FLOW ANGLES	EXIT 86.3239	UNDER TURNING 2.4045	
CLEARANCE	TIP .0393	ROTOR HOUSING .2053	

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 4.2647 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	74.1818	286.0268	74.0292
AXIAL COMP.	74.0292	74.0292	
TANGENTIAL COMP.	4.7563	276.2807	
RELATIVE	413.3752	145.8411	
TANGENTIAL COMP.	406.6924	-125.6554	
PERIPHERAL	401.9361		

DIMENSIONLESS DESIGN RATIOS

BLADE JET SPEED RATIO	.808555	FLOW COEF	.184181
BLADE LOADING COEF	.764804	SPEED WORK COEF	1.307524
SPECIFIC SPEED	.880375	SPECIFIC DIAM	3.125036
EXIT VELOCITY/SPOUTING	.022269		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .925198 TOTAL TO STATIC .904594
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .925184 TOTAL TO STATIC .904581

FIVE STAGE SINGLE FLOW

KNN

7 TURBINE TB=70.,TC=66.,GP=2.8,RND=1200.,END

TURBINE DESIGN FOR 2.80 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(PSIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	66.0000	68.6927	69.9189	70.0000
STATIC PRESSURE	120.1531	126.0519	128.8103	128.9944
TOTAL PRESSURE	120.3304	128.7471	128.9944	128.9944
STATIC ENTHALPY	625.5472	627.9461	629.1080	629.1218
TOTAL ENTHALPY	625.6279	629.1218	629.1218	629.1218
SP. VOLUME	2.4594	2.3567	2.3120	
ENTROPY	1.2145	1.2140	1.2140	1.2139
QUALITY	.9944	.9981	1.0000	1.0000
VELOCITY	62.7898	62.7898	62.7898	0.0000
VISCOSITY	.239E-01	.240E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	126.4867	127.0128		
TOTAL ENTHALPY	625.7709	625.7708		
PRESSURE RATIO	1.0736			

SPECIFIC SPEED	130.4387			
SPECIFIC DIAMETER	1.2289			
EFFICIENCIES	.8836	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	1200.			
MASS FLOW LBM/SEC	783.1835			
MACHINE REYNOLDS NO.	.2048E+09			
DISK RE. NO.	.2729E+08			
STATOR BLADE RE. NO.	.1525E+08			
ROTOR BLADE RE. NO.	.3517E+08			
STATOR THETA RE. NO.	.2238E+05			
ROTOR THETA RE. NO.	.4662E+05			
REACTION	.6855			

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	7.2974	7.1434	7.0754
B. HEIGHT	1.7649	1.7277	1.7112
	ROTOR	STATOR	
PITCH	1.8244	.9602	
AXIAL WIDTH	.3665	.5334	
CAMBER LINE LENGTH	1.9007	1.2431	
CHORD LENGTH	1.9007	1.1294	
TRAILING EDGE THICKNESS	.0706	.0691	
STAGGER ANGLE	11.1179	28.1868	
INLET ANGLE	25.6867	90.0000	
OUTLET ANGLE	7.0395	15.0000	
NO. BLADES	10.0000	19.0000	
RATIOS			
ASPECT	1.0769	.6537	
SOLIDITY	.9598	.8502	
RADIUS	.5163		
BL. HEIGHT/DIAM.	.2419		
GAS FLOW ANGLES	EXIT 81.1215	UNDER TURNING	2.4737
CLEARANCE	TIP .0706	ROTOR HOUSING	.2919

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 5.8072 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	63.5512	242.6010	62.7898
AXIAL COMP.	62.7898	62.7898	
TANGENTIAL COMP.	9.8085	234.3346	
RELATIVE	379.9127	144.8604	
TANGENTIAL COMP.	374.6880	-130.5449	
PERIPHERAL	364.8796		
DIMENSIONLESS DESIGN RATIOS			
BLADE JET SPEED RATIO	.832660	FLOW COEF	.172084
BLADE LOADING COEF	.721166	SPEED WORK COEF	1.386644
SPECIFIC SPEED	1.011153	SPECIFIC DIAM	2.926124
EXIT VELOCITY/SPOUTING	.021032		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK
 TOTAL TO TOTAL .921053 TOTAL TO STATIC .901681
 CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES
 TOTAL TO TOTAL .921001 TOTAL TO STATIC .901630

FIVE STAGE DOUBLE FLOW

*TURBINE TB=70.,TC=66.,GP=1.4,RND=1800.,TBH=.04,SH=.04,DELD=.04 @END

TURBINE DESIGN FOR 1.40 MEGAWATTS AMMONIA WORKING FLUID

STATE POINTS-----T(F),P(P(SIA),H(BTU/LBM),V(CUFT/LBM),S(BTU/LBM-F)

	STATION 3	STATION 2	STATION 1	EVAPORATOR
TEMPERATURE	66.0000	68.8482	70.0922	70.0000
STATIC PRESSURE	120.1531	126.3990	129.2039	128.9944
TOTAL PRESSURE	120.3399	129.2931	129.4016	
STATIC ENTHALPY	625.4209	627.9628	629.1374	629.1218
TOTAL ENTHALPY	625.5059	629.2218	629.2218	
SP. VOLUME	2.4588	2.3503	2.3052	
ENTROPY	1.2142	1.2138	1.2137	1.2139
QUALITY	.9941	.9981	1.0000	
VISCOSITY	.239E-01	.241E-01	.241E-01	
RELATIVE STATE PROPERTIES				
TOTAL PRESSURE	126.6905	127.3948		
TOTAL ENTHALPY	625.5922	625.5922		
PRESSURE RATIO	1.0770			

SPECIFIC SPEED	128.2254			
SPECIFIC DIAMETER	1.2386			
EFFICIENCIES	.8849	TURBOGENERATOR	.9800	GENERATOR .0100 BEARING LOSS
ROTATIONAL SPEED RPM	1800			
MASS FLOW LBM/SEC	368.2197			
MACHINE REYNOLDS NO.	.1424E+09			
DISK RE. NO.	.2000E+08			
STATOR BLADE RE. NO.	.1034E+08			
ROTOR BLADE RE. NO.	.2455E+08			
STATOR THETA RE. NO.	.1605E+05			
ROTOR THETA RE. NO.	.3435E+05			
REACTION	.6825			

GEOMETRY SPECIFICATION-LENGTH IN FEET

	ROTOR EXIT	ROTOR INLET	STATOR INLET
DIAMETER	4.9671	4.8563	4.8095
B. HEIGHT	1.1672	1.1411	1.1301
	ROTOR	STATOR	
PITCH	1.2488	.6244	
AXIAL WIDTH	.2586	.3469	
CAMBER LINE LENGTH	1.2986	.8084	
CHORD LENGTH	1.2986	.7344	
TRAILING EDGE THICKNESS	.0467	.0456	
STAGGER ANGLE	11.4871	28.1868	
INLET ANGLE	26.1833	90.0000	
OUTLET ANGLE	7.2985	15.0000	
NO. BLADES	10.0000	20.0000	
RATIOS			
ASPECT	1.1126	.6436	
SOLIDITY	.9617	.8502	
RADIUS	.5300		
BL. HEIGHT/DIAM.	.2350		
GAS FLOW ANGLES	EXIT 84.9251	UNDER TURNING	2.3944
CLEARANCE	TIP .0467	ROTOR HOUSING	.1987

VELOCITIES IN FT/SEC AT MEAN SQUARE DIAMETER OF 3.9751 FEET

	STATION 3	STATION 2	STATION 1
ABSOLUTE	65.2336	251.0551	64.9778
AXIAL COMP.	64.9778	64.9778	
TANGENTIAL COMP.	5.7704	242.5006	
RELATIVE	385.9302	147.2606	
TANGENTIAL COMP.	380.4208	-132.1498	
PERIPHERAL	374.6504		

DIMENSIONLESS DESIGN RATIOS

BLADE JET SPEED RATIO	.829629	FLOW COEF	.173434
BLADE LOADING COEF	.726444	SPEED WORK COEF	1.376568
SPECIFIC SPEED	.993996	SPECIFIC DIAM	2.949089
EXIT VELOCITY/SPOUTING	.020867		

CALCULATED EFFICIENCY BASED ON THEORETICAL WORK

TOTAL TO TOTAL .922178 TOTAL TO STATIC .902935

CALCULATED EFFICIENCY BASED ON SUMMATION OF LOSSES

TOTAL TO TOTAL .922142 TOTAL TO STATIC .902900

APPENDIX F.2
ELLIOTT'S TURBINE STUDY

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

DESIGN STUDY OF AN AMMONIA
EXPANDER/GENERATOR SET FOR
OCEAN THERMAL ENERGY CONVERSION APPLICATION

TRW ORDER NO. G27617LNEE
TRW PROJECT NO. 1981-LN-8.190

AUGUST 25, 1978

FINAL REPORT

Elliott Company - Division of Carrier Corporation
900 North Fourth Street
Jeannette, Pennsylvania 15644

Principal Investigator

Charles H. Kostors
Arthur J. Miller
John E. Claydon
Thomas J. Elliott

Prepared For
TRW Defense and Space Systems Group
One Space Park
Redondo Beach, California 90278

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

CONTENTS

	<u>PAGE</u>	
Tables	F-22	
Figures	F-23	
 <u>SECTION</u>		
1	SUMMARY	F-27
2	INTRODUCTION	F-29
3	GAS PROPERTIES AND CALCULATION METHOD	F-30
	Gas Properties	F-30
	Calculation Method	F-31
4	EXPANDER AERODYNAMIC DESIGN	F-37
	Design Optimization	F-40
	Performance Maps	F-49
	Blade Path Design	F-52
	Variable Nozzle	F-53
	Diffuser Design	F-55
	Moisture Loss	F-57

<u>SECTION</u>		<u>PAGE</u>
5	EXPANDER MECHANICAL DESIGN	F-87
	Rotor	F-89
	Bearings	F-90
	Seals	F-91
	Casing and Maintenance	F-92
	Moisture Erosion	F-96
	Rotor Blades	F-98
6	GENERATOR DESIGN AND ANALYSIS	F-106
	Generator Design	F-106
	Coupling Design	F-107
7	CONTROLS	F-112
	Valve Sizing	F-112
	Valve Characteristics	F-113
	Control Scheme	F-114
	Future Work	F-118
8	LUBE AND SEAL SYSTEM	F-121
	Flow Requirements	F-121
	Components	F-122
	Auxiliary Requirements	F-127
	Degasifier System	F-128
9	SUBSYSTEM DESIGN	F-129
	Cross Section Layout	F-129
	String Arrangement	F-130
	Lube and Seal Oil Schematic	F-131

<u>SECTION</u>		<u>PAGE</u>
10	MISCELLANEOUS	F-138
	Protection Equipment	F-138
	Instrumentation	F-139
	Materials	F-142
	Codes	F-143
	Scalability	F-144
ATTACHMENT 1	REFERENCES	F-155
ATTACHMENT 2	NOMENCLATURE & DEFINITIONS	F-157

TABLES

<u>TABLE</u>		<u>PAGE</u>
2-1	Turbine Inlet and Outlet Conditions	F-28
3-1	Comparison of NBS Circular 142 to B-W-R	F-35
3-2	Expander Thermodynamic Conditions	F-36
6-1	Generator Data	F-109
8-1	Oil Requirements	F-121
8-2	Auxiliary Services	F-127
9-1	Expander Blade Geometry	F-132
9-2	Expander/Generator Component Weights	F-133
10-1	Thermodynamic Instrumentation Requirements	F-149
10-2	Instrumentation	F-150
10-3	Materials of Construction	F-152
10-4	Scaled Expanders	F-153

FIGURES

<u>FIGURES</u>		<u>PAGE</u>
4-1	Normalized Efficiency for Single Stage - Idealized	F-58
4-2	Normalized Efficiency for Two Stage - Idealized	F-59
4-3	Normalized Efficiency for Three Stage - Idealized	F-60
4-4	Normalized Efficiency for Four Stage - Idealized	F-61
4-5	Normalized Efficiency for Five Stage - Idealized	F-62
4-6	L/D versus Base Diameter - Idealized Blades	F-63
4-7	Normalized Efficiency for Three Stage - Real Blades	F-64
4-8	Normalized Efficiency for Four Stage - Real Blades	F-65
4-9	Normalized Efficiency for Five Stage - Real Blades	F-66
4-10	Normalized Efficiency for 31 Base Diameter - Real Blades	F-67
4-11	L/D versus Base Diameter - Real Blades	F-68
4-12	Normalized Efficiency for Single and Double Flow Design - Real Blades	F-69
4-13	Normalized Efficiency for Single Stage, Single Flow Design - Idealized Blades	F-70
4-14	Normalized Efficiency for Radial Inflow Design	F-71
4-15	Flow Correction	F-72
4-16	Generator Output for 89.2 psia Exhaust	F-73
4-17	Generator Output Correction versus Exhaust Pressure	F-74

FIGURESPAGE

4-18	Generator Output Correction versus Generator Output	F-75
4-19	Generator Output Expanded Plot	F-76
4-20	Generator Output Expanded Plot	F-77
4-21	Generator Output Expanded Plot	F-78
4-22	Generator Output Expanded Plot	F-79
4-23	Seasonal Variation in Expander Efficiency	F-80
4-24	Velocity Triangles First Stage	F-81
4-25	Velocity Triangles Second Stage	F-82
4-26	Velocity Triangles Third Stage	F-83
4-27	Velocity Triangles Fourth Stage	F-84
4-28	Effect of Exhaust Diffuser Recovery Factor	F-85
4-29	Effect of Moisture Loss Factor	F-86
5-1	Labyrinth Seal	F-100
5-2	Dry Carbon Seal	F-101
5-3	Bushing Seal	F-102
5-4	Face Seal with Shutdown Features	F-103
5-5	Variable Nozzle Linkage	F-104
5-6	Goodman Diagram	F-105
6-1	Generator Efficiency	F-111
7-1	Control Schematic	F-120
9-1	Expander Cross Section Layout	F-134
9-2	Expander Blade Path	F-135

FIGURES

		<u>PAGE</u>
9-3	String Arrangement	F-136
9-4	Oil Schematic	F-137
10-1	Normalized Efficiency 10, 22.5, and 40 MW(e)	F-154
B-1	Blade Terminology	F-161
B-2	Turbine Stage Diameters	F-162

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

SECTION 1

SUMMARY

A design and optimization study for a 14.4 MWe gross expander/generator set operating with ammonia gas as the motive fluid for an ocean thermal energy conversion process (OTEC) has been completed. The prime consideration in this design study dictated that the hardware remain within the state-of-the-art.

A barrel type axial flow expander (See Figure 9-1) was designed to operate on saturated ammonia vapor at inlet conditions of 128.8 psia/70°F to an exhaust pressure of 89.2 psia with a weight flow of 825 pounds mass per second.* Variable parameters included the number of stages, the operating speed, the disc base diameter and the type of expander. The gas properties as used for this expander design were qualified by comparison to NBS circular 142 and making minor corrections to the final results as indicated.

The expander, which resulted in an optimized expander/generator set, was a four stage double flow axial flow machine direct connected to a four-pole synchronous generator developing 15040 KW at 13.8 KV for the above conditions. The 640 KW increase in power output is due to an

*TRW presented new mass flow data, which is 2.8 percent less, at an August 14, 1978 meeting at Elliott Company. No revisions have been made to this report as a result of this new data.

expander efficiency of 89.6 percent compared to a minimum efficiency of 85 percent projected by TRW.

The blading used for the expander is proprietary state-of-the-art high performance blading. Blade stresses and frequencies were checked to verify the mechanical integrity before a final decision could be made on the staging.

The proposed control system includes variable nozzles for the first expander stage; the variable nozzles provide for increased power developed at off-design conditions compared to fixed nozzles.

The safe handling and containing of ammonia vapor was critically important in determining the mechanical design. Special attention was given to joint leakage and shaft seals to provide positive sealing.

Operation with ammonia vapor as the motive fluid requires that materials which are not susceptible to stress corrosion cracking be used in the expander construction.

SECTION 2

INTRODUCTION

The purpose of this study is to present a manufacturable ammonia expander/generator set with optimized performance based on nominal conditions provided by TRW, Inc. These and the maximum and minimum extremes to be accommodated by the expander are shown in Table 2 - 1.

TABLE 2 - 1

TURBINE - INLET AND OUTLET CONDITIONS***

	Minimum Flow ("Winter")	Nominal Flow	Maximum Flow ("Summer")
<u>Inlet Conditions (Total)</u>			
Ammonia Mass Flow, lb/sec	742	825	908
Ammonia Temperature, °F	67.0	70.0	73.0
Ammonia Pressure, psia	122.1	128.8	135.7
Ammonia Quality, %*	99.0	99.0	99.0
Ammonia Vol. Flow, acfs **	1,838	1,907	1,995
<u>Outlet Conditions (Total)</u>			
Ammonia Temperature, °F	49.0	50.0	51.0
Ammonia Pressure, psia	87.5	89.2	90.9

* Saturated Conditions

** Estimated Assuming 100% Vapor

*** TRW presented new mass flow data, which is 2.8 percent less, at an August 14, 1978 meeting at Elliott Company. No revisions have been made to this report as a result of this new data.

The approval to proceed with the study was given by TRW on June 12, 1978 and the work was completed on the designated date of August 25, 1978. Included in the study were five main areas of concern, namely; expander aerodynamic analysis, mechanical analysis, generator design, controls and the lube system.

The properties of the motive fluid, anhydrous ammonia vapor, were specified to be per National Bureau of Standards Circular No. 142, Tables of Thermodynamic Properties of Ammonia (1942); the ammonia is to be continuously filtered through a 40 micron filter and have the water content maintained below 10 parts per million.

Sea state six and sea state nine (non-operational at this condition) were considered for the design of the equipment as specified for this marine application.

The generator design information was supplied by Brown Boveri Corporation, North Brunswick, New Jersey.

Definitions of various symbols and terms used in this report can be found in Appendix B.

SECTION 3

GAS PROPERTIES AND CALCULATION METHOD

GAS PROPERTIES

The Elliott Company uses a modified Benedict-Webb-Rubin (BWR) equation of state for real gas calculations. The requirements for this project specified the gas properties to be used as those defined by NBS circular 142. Therefore, a comparison of the two sources of gas properties must be made to insure the accuracy of our thermodynamic calculations. Table 3 - 1 shows three upstream thermodynamic state points, which were chosen from NBS circular 142 to be as close to the actual performance points as possible without requiring any interpolation. The table also includes for each upstream point an isentropic downstream point, which was selected from circular 142 for the same reasons as were the upstream points. The comparison at these upstream and downstream conditions includes specific volume, quality, and available energy.

For the upstream points saturation values of temperature and volume are given for each pressure. No appreciable difference exists between the BWR and circular 142 values of saturation temperature. The downstream points give values for quality and volume. Notice that the difference in quality is practically zero. The absolute levels of enthalpy are not

particularly important here, but the available energy or isentropic heat drop is important. Table 3 - 1 contains a comparison of the available energy for each of the three points considered, with the difference being on the order of one percent. The BWR equation calculates the higher available energy values as well as higher specific volumes, by about one and one half percent. We have adjusted all of our calculations to conform to NBS circular 142.

CALCULATION METHOD

The design point performance and performance maps were calculated on Elliott Company's Multistage Performance Program, which has been developed during the past five years. The program is a modified pitch line analysis based on the Ainley and Mathieson (1)* loss method with many of the improvements as proposed by Dunham and Came (2). In addition, a number of proprietary improvements have been incorporated by Elliott Company.

The Multistage Performance Program calculates the turbine thermodynamic conditions at specific stations within the turbine for a given geometry on the basis of mass flow continuity. The thermodynamic analysis uses only pressure, enthalpy, and specific volume

*Numbers in parentheses refer to references listed in Appendix A.

at each station. The calculations between stations are made from calculated efficiencies and enthalpy differences. The method of calculation requires more computer time than the conventional pressure temperature ideal gas law type performance calculation. However, it has the advantage of being completely independent of gas moisture level, utilizing an equilibrium gas property calculation. The gas properties are calculated with a modified Benedict-Webb-Rubin equation of state.

The Ainley and Mathieson loss method develops the losses on the basis of a pressure loss coefficient, Y , which is defined as the loss of total head pressure divided by the blade exit velocity pressure head. The blade row pressure loss coefficient is the sum of profile, secondary and blade leakage pressure loss coefficients. In addition, if the rotating blades are not shrouded it is typical turbine practice to lash the blades together with either zigzag lashing pins or lashing wires, which present a flow path restriction and, therefore, a performance loss. The lashing pressure loss coefficient is calculated for unshrouded rotating blade rows and then added to the total pressure loss coefficient for that row. The profile loss is due to skin friction over the blade surface and blade incidence angle at blade inlet. The incidence loss used in the calculation of profile loss is the average incidence loss considering the base, mean, and tip incidence. The secondary loss includes both the annulus endwall friction losses and losses due to turning of the flow within the blade passage. The

calculation of both profile and secondary losses closely follow the procedures as outlined in references 1 and 2. Blade leakage loss is the loss associated with flow through the diaphragm shaft packing in the case of a stationary blade or over the rotating shroud or blade tips for a rotating blade row. The calculation of blade leakage loss closely follows the method outlined in reference 2. In addition, the rotating blade tip leakage loss has been modified to account for the blade tip static pressure drop.

After the above losses are calculated, the total pressure loss coefficient is converted to a blade efficiency. The blade efficiency is corrected for moisture loss depending on the mean moisture content of the blade row. The actual moisture loss factor is an input and is considered to be the percent decrease in efficiency per percent of mean blade row moisture as suggested in reference 3. The inlet conditions ahead of each blade row are then calculated from the final blade row efficiency and stage mass flow.

The disc friction and shroud friction losses are calculated with standard Elliott equations, and these losses are added to the stage exit enthalpy. This final stage exit enthalpy is used in the calculation of stage work output.

The pressure carryover between stages is calculated according to the method as suggested in reference 3.

Turbine inlet losses are input as a fraction of turbine inlet pressure. The turbine exhaust losses and the effect of the diffuser on exhaust losses are input as a fraction of last stage rotor blade exit velocity heads. The overall turbine efficiency includes inlet, exhaust, bearing and seal losses.

TABLE 3 - 1

COMPARISON OF NBS CIRCULAR AND BENEDICT-WEBB-RUBIN
EQUATION OF STATE FOR AMMONIA

SOURCE	UPSTREAM CONDITION			ISENTROPIC DOWNSTREAM CONDITION			AVAILABLE ENERGY
	P PSIA	T °F	V ft ³ /lbm	P PSIA	QUALITY	V ft ³ /lbm	ΔH_g BTU/lbm
POINT 1 (Nominal)							
NBS CIRCULAR 142	128.0	69.65	2.326	89.0	.9701	3.203	19.6
BWR			2.365		.9703	3.248	19.8
DIFFERENCE (%)			1.68		.03	1.41	1.02
POINT 2 (Max.)							
NBS CIRCULAR 142	136.0	73.11	2.193	91.0	.9667	3.134	21.6
BWR			2.231		.9670	3.170	21.89
DIFFERENCE (%)			1.74		.03	1.14	1.36
POINT 3 (Min.)							
NBS CIRCULAR 142	122.0	66.94	2.437	88.0	.9731	3.248	17.7
BWR			2.477		.9735	3.294	17.8
DIFFERENCE (%)			1.64		.04	1.42	.59

TABLE 3 - 2
EXPANDER THERMODYNAMIC CONDITIONS

	<u>Minimum Flow (Winter)</u>	<u>Nominal Flow</u>	<u>Maximum Flow (Summer)</u>
<u>Inlet Conditions (Total)</u>			
Pressure, psia	122.1	128.8	135.7
Enthalpy, BTU/lb	628.54	629.04	629.56
Temperature, °F	67.0	70.0	73.0
Quality, %	0.9999	0.9999	0.9999
 <u>Outlet Conditions (Total)</u>			
Pressure, psia	87.50	89.30	90.90
Enthalpy, BTU/lb	612.372	611.233	610.203
Temperature, °F	49.0	50.0	51.0
Quality, %	0.9761	0.9735	0.9711
 Expander Mass Flow, lb/sec.			
	742.	825.	908.
 Isentropic Heat Drop, BTU/lb			
	18.069	19.874	21.637
 Total To Static Efficiency, %			
	89.48	89.60	89.46

SECTION 4

EXPANDER AERODYNAMIC DESIGN

The purpose of the aerodynamic design study is to define the optimum expander design for the specified nominal conditions, and then to determine the expander performance characteristics over the entire seasonal operating range.

The primary consideration in the aerodynamic design of the expander was to achieve an optimum performance level with manufacturable state-of-the-art technology. Therefore, the aerodynamic design and the mechanical design cannot be separated. The first step in the design optimization process involves special blades, hereafter referred to as idealized blades, which do not take into account manufacturability. The second step in the optimization process incorporates proven airfoil designs. In this way, a manufacturable state-of-the-art design is assured, while still being optimized on the basis of idealized blades. Finally, the resulting real blade design is compared to several special cases, including single flow and radial inflow designs.

The use of the idealized blades will give the optimum theoretical design possible. These idealized blades consist of stator blades with 12° blade exit angles at their mean diameters and rotor blades with 15° blade exit angles at their mean diameters. These are considered the minimum possible angles for axial flow turbine blades using state-of-the-art technology. They are also predominantly found on blades having much lower L/D ratios than those examined in this study. These low angles, however unrealistic for the long blade lengths required, will give a high theoretical performance. These small angles will compel the use of longer blades, thereby maximizing L/D ratios. This will have the tendency to raise the stage velocity ratios by raising the mean blade speed, U, in the term U/C_o . For a design having fewer stages than the optimum number, this has a tendency to increase the stage velocity ratio toward the value where maximum efficiency occurs (in our case, approximately 0.65). The purpose of using the idealized blades is clearly seen in this light, that is, to create an optimum theoretical design with the fewest number of stages.

As mentioned before, however, the desired end result is a manufacturable aerodynamic design. The above analysis will not supply that, since its aerodynamics have been idealized and removed from real world considerations. To alleviate this problem, the design optimization analysis includes a more limited, but similar study involving actual turbine blades of the type envisioned for the final expander. The most promising designs obtained from the ideal blade study have been

reanalyzed on the basis of actual blades. For the actual blade study the base diameters were chosen to provide optimum performance at a synchronous speed. This is in contrast to the idealized blade optimization study, in which the base diameters were chosen to provide a wide enough range to produce a clear favorite. From this study, an optimum design can be chosen which gives the best choice for base diameter and number of stages.

The idealized and real blade designs have been analyzed at the nominal design point conditions, and the results have been presented in the form of normalized efficiency versus velocity ratio curves. Since the overall isentropic heat drop is fixed by the design point, as is the mass flow, the velocity ratio was varied by changing the shaft speed of the design. Constant speed lines are shown on the figures. In the course of changing speeds with a constant mass flow and isentropic heat drop, blade heights also vary along these velocity ratio curves.

Several restrictions have been set on the analyses described previously. Among these is the condition that only double flow axial designs be considered. Radial inflow expanders will be discussed after the double flow axial units have been analyzed, as will single flow designs. The rationale for initially excluding single flow designs is based on fact that such designs are hampered by high thrust bearing losses. Two single flow designs are included in this study,

so as not to rule them out on the basis of high thrust loads alone. It was felt that this disadvantage would limit the possibilities enough to enable a shorter discussion to suffice.

After the optimized design is achieved, it is analyzed over the entire range of operating conditions given, so that a detailed performance map can be made. This map encompasses the effects of variable nozzles over the entire seasonal range. Variable nozzles, diffuser design, and moisture loss are all discussed in later parts of Section 4.

DESIGN OPTIMIZATION

To optimize the final design, two types of blading are analyzed. The first type is an idealized selection, based on what is considered state-of-the-art minimum gauging angles possible for any blades; 12° for the stator blades and 15° for the rotor blades. These extremely low gauging angles are predominantly used in constant section blading. The second type of blading represents the actual blading chosen for this machine, a modified free-vortex design with stator mean gauging angles of 17 to 19 degrees and rotating blade mean gauging angles of 18 to 20 degrees. Limitations placed on the idealized blades included a maximum L/D ratio of 0.33, which has been shown from experience to be a practical limit. An L/D ratio of 0.290 is the limit for the actual blades chosen, which represents the practical twist limit for this modified free vortex design. Higher L/D ratios are possible at the expense of

increasing pitch line gauging angles. All calculations were made using nominal design point data.

Figures 4 - 1 through 4 - 5 show normalized efficiencies versus velocity ratio for the idealized blades. Each plot was drawn for a specific number of stages, with base diameter and speed being varied on each plot. Also shown is a line representing constant machine speed which indicates the peak base diameter for the shaft speed. The constant speed lines shown correspond to synchronous generator speeds. Predictably, overall peak performance increases with the number of stages and with decreasing base diameters. The latter phenomenon is caused by increasing L/D ratios, which are given in Figure 4 - 6 for the designs represented by the first five figures. The efficiencies were calculated regardless of L/D ratio, so that the curve of maximum L/D ratios must be checked for each of the first five figures. Some or most of those designs shown may violate L/D restrictions.

Figure 4 - 1 shows all one stage designs using the idealized blades. Four base diameters are included on the plot. Figure 4 - 6 shows that for one stage designs, the minimum base diameter that allows a reasonable L/D ratio is 22 inches. The constant speed line of 3600 RPM shows the best base diameter is 31 inches with a normalized efficiency of .955. The next, Figure 4 - 2, shows the two stage designs peaking at or below a 24 inch base diameter for 3600 RPM. However, this point represents an L/D ratio over 0.45. For L/D ratios below

the 0.33 limit, either the 31 inch base diameter design running at 3600 RPM or the 38 inch base diameter design running at 1800 RPM are the best. If gears are considered, the 31 inch base diameter design yields the highest normalized efficiency.

Three stage designs are limited to a minimum base diameter of 29 inches by L/D ratios which, in turn, means that the best efficiency for a three stage design is between a 31 inch or a 38 inch base diameter, running at 1800 RPM. The peak efficiency will be about 99% of the four stage efficiency. The four stage designs shown in Figure 4 - 4 are limited to a 31 inch base diameter by L/D ratio. Any higher efficiency in a four stage design must be obtained with an L/D ratio higher than 0.33. Five stage designs are limited to the two largest base diameters, with the 31 inch base diameter producing an L/D ratio of just over .35. With either of the 38 or 47.5 inch base diameter designs, peak efficiencies at synchronous speed are slightly less than the peak four stage efficiency.

In most of these cases either 1800 RPM or 3600 RPM give the best results, since gears are required otherwise, and gears usually mean a two percent efficiency penalty. The first five figures show that with these idealized blades, the highest efficiency can be obtained with a four stage design. The optimum base diameter appears to be near 31 inches, but this finding must be verified by generating efficiency curves of the actual blades under consideration. Figures 4 - 7 thru 4 - 11 are normalized efficiency versus velocity ratio curves for the

actual blades. Only three, four, and five stages have been considered on more than one base diameter, while one through five stages have been analyzed on a 31 inch base diameter. A plot of maximum L/D ratio versus base diameter is shown on Figure 4 - 11, with the .290 L/D limit previously discussed.

The question naturally arises as to why the idealized blades with their small gauging angles are not used instead of the modified free-vortex blades chosen. The answer lies in the nature of the free-vortex tapered and twisted idealized blade. This type of blading produces a nearly uniform radial distribution of mass flow with the stage reaction increasing from base to tip. Therefore, with increasing L/D ratio and constant mean reaction (constant mean exit angle), the reaction at the base of the vane will decrease and become negative, resulting in severe degradation of blade row efficiency. In addition, mechanical considerations dictate the use of zigzag lashing for very high L/D ratio blades rather than shrouds, resulting in additional degradation of performance. The above problems may be avoided by untwisting the blade sections, but this leads to other performance problems, such as mass flow imbalances in the radial direction. These idealized blades are in reality not desirable, but the point of including them in the optimization study was to favor the highest possible L/D ratios with the lowest possible gauging angles. In this way, an idealized design with the fewest number of stages is found and is then used as a starting point for a real blade study.

The general trend of the idealized blade study is that efficiency increases with increasing number of stages.

Figure 4 - 7 shows three stage designs using real blades. The three base diameters are 27 inches, 31 inches, and 40 inches. The latter base diameter maximizes the three stage design efficiency at 1800 RPM. Higher peak efficiencies can be obtained by going to higher shaft speeds and smaller base diameters. In this event, a gear would be used and a two percent loss would be incurred. Since the improvement is not two percent, the best performance can be obtained from the 40 inch base diameter design. This particular design has much lower efficiency compared to the four and five stage designs because of decreasing L/D ratios. This peak normalized efficiency is .978, which means this design will produce 2.2 percent less power than the four stage design. This works out to be approximately 330 Kilowatts. The 330 KW, valued at \$330,000*, can be obtained by adding a fourth stage at the cost of approximately \$100,000. For this reason, the three stage design can be discounted. The analysis with the idealized blades agrees with the analysis of the actual blades, in that both show that four stages are the minimum number necessary for peak operation.

*Power is evaluated at \$1000 per KW as per TRW on July 7, 1978, Equipment prices are based on current cost levels.

The next Figure 4 - 8 shows four stage, double flow designs on three different base diameters. The smallest base diameter peaks at the highest efficiency, but at a speed other than 1800 RPM or 3600 RPM. The 31 inch base diameter design is at the peak efficiency for 1800 RPM operation. No other synchronous speeds are in the proper range to appear on these velocity ratio curves. Figure 4 - 9 presents similar information for five stage designs, with the 27 inch base diameter giving the highest efficiency for 1800 RPM operation although it exceeds the L/D limits. Figure 4 - 10 is a plot of normalized efficiency versus velocity ratio for all of the 31 inch base diameter designs.

A five stage, double flow design does offer better performance than a four stage design, but caution must be exercised about the value of this small improvement. The 27 inch base diameter design peaks at nearly one percent better in performance, at the same shaft speed as the four stage design. But from our L/D curve, we can see that this design has blades that violate L/D limits, making this design unfeasible. The 31 inch base diameter design is also better than the four stage design, but there are two problems here, the first concerning L/D ratios. The maximum L/D ratio for the five stage design on a 31 inch base diameter is slightly higher than the accepted limit for this blade. This would necessitate a redesign of the blade to be used in this application. The second problem concerns practicality. The five stage design is about three-tenths of

one percent better in efficiency, amounting to about 50 KW. If the price of this power is \$1000 per KW, then \$50,000 could be saved by going to five stages. But the cost of adding a fifth stage to both ends of the double flow design would cost approximately \$100,000, making the five stage design cost inefficient. Critical speed problems can also be avoided by keeping bearing spans to a minimum, which also favors a four stage over a five stage design.

As a result of the first eleven figures in this section, several conclusions can be made. First, four stages are the minimum number of stages to provide peak efficiency. Second, a 31 inch base diameter provides the best efficiency for a four stage, double flow design when operating at 1800 RPM and when limited to the blade profile L/D limit shown on Figure 4 - 11. Another conclusion is that a five stage design yields better efficiency, but when the constraints of this system are applied (L/D ratios, 1800 RPM speed, using a gear for nonsynchronous operation) the gain is marginal. The gain is so small that the cost of adding the fifth stage would be higher than the benefit of the additional power. Critical speed problems will be created by stretching the shaft to accommodate the fifth stage.

So far we have only considered double flow designs, since they eliminate any high thrust bearing losses. Bearings for single flow designs can be quite large since it is accepted practice not to load thrust bearings over 250 psi, and preferably to keep the loading below 200 psi.

Figure 4 - 12 compares a double flow and a single flow design for the 10 MW net system. The single flow design is under some system constraints which limit its efficiency to 1.6 percent less than the double flow. The thrust bearing produces a large loss, but another loss is introduced by having to run at a synchronous speed of 1200 RPM. In peaking the velocity ratio of the single flow design for 1200 RPM operation, the base diameter has been increased and L/D ratios have gone down. This also contributes to the lower efficiency. Measures could be taken to reduce the thrust loading, such as balance holes, but an added performance penalty would result.

Also considered is a single stage, single flow design, the results being shown on Figure 4 - 13. This design concept uses the idealized blades previously discussed for comparative purposes. An important part of a single stage, single flow design is the diffuser, which is the only means of recovering some of the substantial amount of exhaust kinetic energy that would otherwise be wasted. For this reason, efficiency curves for a range of diffuser pressure recovery factors have been included in Figure 4 - 13. The highest value for the pressure recovery factor, 0.7, is based on the maximum area ratio possible, that is, the diffuser exit area is identical to the 126 inch diameter condenser inlet flange area. This area ratio produces a diffuser length well over 40 feet for the optimum recovery factor (11). With this type of diffuser, an overhung design would be necessary, with the bearing compartment being designed into the inlet side of the expander. The

probability of obtaining a pressure recovery factor of 0.7 is considered to be very small, even with such a design.

As noted on Figure 4 - 13, the base diameter is 31 inches, which produces an L/D ratio of 0.33. Since it is considered impossible to successfully use a shroud with the L/D ratio being so high, these efficiency curves reflect this difference between the four-stage, double flow and the one-stage, single flow designs. The normalized efficiency of the one-stage, single flow design is more than two percent lower than preferred design, indicating that additional stages do a better job of converting energy to power than a diffuser. Other disadvantages of the one one-stage, single-flow design include the difficult inlet case design and the requirement of more exotic blade materials to handle the higher stresses.

The final topic under consideration in the optimization study is that of using radial inflow expanders. Many different types of systems for radial inflow expanders are possible, but state-of-the-art technology limits the choices to one. No wheel diameter over 52 inches was chosen, since this is approximately the largest radial inflow wheel size now being considered. Because of the low available heat energy, only single stage designs were chosen. For the nominal conditions given, a synchronous speed of 3600 RPM gives the best range of velocity ratios for the wheel diameters studied. The only design choice left undecided at this point is the number of ways the flow must be divided.

46 inch wheel running at 3600 RPM may be designed for one-fourth of the total mass flow. For one-half the total mass flow, the inlet blade heights get large, and the exducer outside diameter approaches the wheel tip diameter. This results in an impractical design for high efficiency. Considering these facts, four-flow, single stage radial inflow expanders of various wheel diameters and running at various speeds were analyzed. Minimum angles were assumed at stator and rotor exits to maximize efficiency. The results are shown in Figure 4 - 14. Notice that the 46 inch wheel produces the peak efficiency for synchronous operation, and that this point is less than 2 percent lower than the peak efficiency for nonsynchronous operation, making a gear-driven generator unattractive. All performance levels are considerably lower than those obtained with the optimum axial flow designs. Therefore, a radial-inflow design is undesirable for this application.

PERFORMANCE MAPS

The TRW/OTEC ammonia expander performance maps were developed in the form of a four step nomograph of a type agreed to by both TRW and Elliott Company. These performance maps will give the generator output in megawatts (MW) from the following three known quantities: expander inlet pressure, exhaust pressure, and mass flow. The expander inlet conditions are fixed at the saturation line in all cases. In addition, the performance maps incorporate the effects of variable first stage stator blades.

The performance maps consist of Figures 4 - 15 through 4 - 18; in addition, Figures 4 - 19 through 4 - 22 represent Figure 4 - 16 on an expanded scale to facilitate greater accuracy.

The purpose of Figure 4 - 15 is to correct the actual expander mass flow to a flow with an exhaust pressure of 89.2 psia.

Figure 4 - 16 is a plot of corrected output in MW for an expander with an exhaust pressure of 89.2 psia plotted against mass flow.

The output found from Figure 4 - 16 can be corrected to any exhaust pressure using Figure 4 - 17. This figure corrects output for exhaust pressure, and includes the effect of expander efficiency, and generator efficiency.

A generator with improved performance was located at the time of final writing of this report and after the performance maps were developed. Therefore, Figure 4 - 18 has been added to correct to the new generator efficiency level.

The procedure for finding the generator output from the expander mass flow, inlet pressure, and exhaust pressure is as follows:

- 1) Enter Figure 4 - 15 at the actual exhaust pressure and inlet pressure to determine the flow correction factor.

- 2) Divide the actual flow by the flow correction factor found in step 1.
- 3) Using the corrected mass flow found in step 2, determine the corrected output for the exhaust pressure of 89.2 psia from Figure 4 - 16.
- 4) Enter Figure 4 - 17 at the actual exhaust pressure and inlet pressure to determine the generator output correction factor.
- 5) Multiply the generator output found in step 3 by the correction factor found in step 4 to determine the corrected output.
- 6) Enter Figure 4 - 18 at the corrected output found in step 5 to determine the generator efficiency correction factor.
- 7) Multiply the generator output found in step 5 by the generator efficiency correction factor found in step 6 to determine the net generator output for the actual operating conditions.

The performance levels obtained from these maps include the following losses:

- 1) An inlet loss of 1.4 inlet flange velocity heads. The nominal inlet flange velocity is 103 feet per second.
- 2) An exhaust loss of 0.8 last stage blade exit velocity heads. The nominal exhaust flange velocity is 55 feet per second.

3) Expander bearing and seal losses of 55.2 KW.

BLADE PATH DESIGN

The four stage double flow TRW/OTEC ammonia expander was designed for optimum performance at the specified nominal conditions, which insures the maximum expander performance over the entire operating range. The maximum performance change of 0.16 percent occurs between nominal (spring, fall) and summer conditions as shown in Figure 4 - 23. The final expander design has shrouded rotor blades for optimum performance resulting in an expander design point flange-to-flange efficiency of 89.60 percent. The generator efficiency at the design point conditions is 97.03 percent, resulting in an overall expander/generator efficiency of 86.94 percent with a generator output of 15040 KW.

The proposed expander utilizes modified free-vortex blading on a 31 inch base diameter. Both stator blades and rotor blades are a tapered and twisted design so that they are properly optimized along the entire blade height. The blade heights ranges from 10.2 inches for the first row stator to 12.3 inches for the fourth row rotor blade. The blading is a reaction type where the average reaction ranges from 3 percent at the base to 63 percent at the tip. A blade path cross section is shown in Figure 9 - 2. The diameters, axial widths, and gauging angles for each stage are given in Table 9 - 1. Velocity triangles, shown on Figures 4 - 24 through 4 - 27, are presented for the nominal conditions at the base, mean, and tip sections for each of the four stages.

It is preferred to use shrouded rotor blades with two 0.03 inch radial clearance tip seals to minimize rotor blade tip leakage and maximize performance. However, the use of shrouded blades in an ammonia atmosphere is still under investigation. If the use of shrouds are ruled out due to material problems, then zigzag lashing pins must be used to lash the blades, reducing the performance by 1.4 percent.

Stator blade leakage along the shaft will be minimized with labyrinth diaphragm seals. Each diaphragm seal will contain eight straight teeth with 0.03 radial clearance.

VARIABLE NOZZLE

As mentioned earlier, the performance map calculations have been made with the assumption that variable first stage nozzles would be incorporated into the final design. In this section the net power gain from the variable nozzles will be compared to their additional cost. To determine the net power gained, the machine design with the nominal point first stage nozzle angle was analyzed at the minimum and maximum flow points. Without variable nozzles, an inlet pressure lower than 122.1 psia is necessary to maintain the mass flow for the minimum condition, resulting in a lower value of pressure energy available to the expander. At the maximum condition, however, a nonvariable nozzle means that a small percentage of the mass flow must be bypassed which, in turn, means that less mass flow is available to produce power. In both cases in which nonvariable nozzles

are used, less power is produced than a comparable case in which variable nozzles are used. In neither case, however, is the change in power directly attributable to a significant change in expander efficiency. The net power gained by using variable nozzles is 150 KW at the minimum point and 252 KW at the maximum point.

The variation from maximum to nominal to minimum flow conditions is essentially a 360 degree sine wave. To determine the average values of net power gained, the sine wave must be integrated and then substituted by a rectangle of equal area. This rectangle will have a height of .637 relative to a sine wave height of 1.0. The average value of net power gained for each part of the sine wave variation in conditions (each 180 degrees) is obtained by multiplying the maximum and minimum flow condition values of net power gained by .637. This yields average values of 96 KW for the minimum part of the cycle and 160 KW for the maximum part of the cycle. The arithmetic average gives the overall cycle average value of net power gained by using variable nozzles. This value is 128 KW. At \$1000 per KW, this gives a savings of \$128,000 gained by using variable nozzles. Since the cost is roughly \$55,000 for both sides of the double flow machine, the variable nozzles will save money over the life of the machine, in addition to providing better control over the unit as outlined in Section 7.

Variable nozzles also provide for better matching of the ammonia expander cycle to particular site conditions, as well as enable one

expander design to be employed at a variety of locations.

Since efficiency is almost constant over the entire range of operating conditions with one set of variable nozzles, the use of variable nozzles in more than one stage will not increase efficiency. Additional complexity of construction and cost are not considered worthwhile.

DIFFUSER DESIGN

The expander last stage exhaust diffuser is designed for an exit to inlet area ratio of 1.61, and has an exit pressure recovery factor of 0.315. Combining both pressure loss in the exhaust diffuser and pressure loss between diffuser exit and the turbine exhaust flange, an estimated 0.8 fourth stage blade exit velocity heads are lost within the expander exhaust hood. Figure 4 - 28 shows a plot of normalized expander efficiency versus exhaust diffuser pressure recovery factor.

The exhaust diffuser design is optimum from a standpoint of its aerodynamic performance versus its effects on expander costs. Increasing the diffuser from the present mean radius of 24 inches to 36 inches will improve nominal expander output by 0.075 percent yielding an additional 11.3 KW. To obtain the additional output, the bearing span and casing diameter will have to be increased approximately 24 inches at an estimated increase in expander cost of \$115,000. The increase in expander output is only worth \$11,300.

evaluated at \$1000 per KW. Therefore, use of an improved exhaust diffuser is not cost effective.

The exhaust flange velocity, averaging 55 feet per second, will not have a uniform velocity profile at the exhaust flange. Some of the pressure calculated to be lost within the exhaust hood, in our performance studies, may be recovered by development of a uniform velocity profile. In addition, a uniform velocity profile is necessary to insure minimum loss in downstream elbows or transitions. It should be emphasized that the performance levels quoted in this report are without pressure recovery, and that pressure recovery may slightly improve performance levels.

To develop a uniform exhaust velocity profile it is recommended that a minimum of six expander flange pipe diameters of straight pipe be utilized between exhaust flange and the first pipe elbow or transition. This will insure maximum expander exhaust pressure recovery, in addition to minimizing pressure loss in downstream elbows or transitions. If it is necessary to elbow the exhaust pipe before the development of a uniform velocity head then corner vanes should be used in the pipe.

None of the velocity head lost within the exhaust hood will be recovered by the transition from the 94 inch inside diameter exhaust flange to the 126 inch inside diameter plant condensate pipe. In

addition, care should be exercised in the design of the transition so that a minimum pressure loss occurs. The pressure loss can be kept to a reasonable value by having a smooth transition which is a minimum of five pipe diameters in length (11).

MOISTURE LOSS

A moisture loss factor of one percent for each percent of mean blade row moisture was used in this performance analysis. This is a value which is normally used in high pressure steam turbines. Therefore, this level seems reasonable for the four stage high pressure high reaction design proposed. This moisture loss factor may even be conservative when ammonia drop sizes are compared with those of steam. The maximum stable drop size in ammonia, at 90 psia pressure, calculated on the basis of Weber number, is less than one third (0.199 microns) the size occurring in steam (0.609 microns) for the same conditions.

The effect of moisture loss factor on normalized turbine efficiency is shown in Figure 4 - 29. It should be noted that the aerodynamic loss is greater than that given by the moisture loss factor since the moisture loss is applied to each blade row during the calculation. The moisture loss is applied before the completion of the calculation of each blade row thermodynamic conditions.

FIGURE 4-1

TRW-OTEC OPTIMIZATION STUDY,
SINGLE STAGE DOUBLE FLOW DESIGNS,
IDEALIZED BLADES




FIGURE 4-2

TRW-OTEC OPTIMIZATION STUDY
TWO STAGE DOUBLE FLOW DESIGNS,
IDEALIZED BLADES




FIGURE 4-3

TRW-OTEC OPTIMIZATION STUDY,
THREE STAGE DOUBLE FLOW DESIGNS,
IDEALIZED BLADES




FIGURE 4-4

TRW-OTEC OPTIMIZATION STUDY,
FOUR STAGE DOUBLE FLOW DESIGNS,
IDEALIZED BLADES

$P_{IN} = 128.8$ PSIA

$T_{IN} = 70^{\circ}$ F

$P_{EX} = 89.2$ PSIA




FIGURE 4-5

TRW-OTEC OPTIMIZATION STUDY,
FIVE STAGE DOUBLE FLOW DESIGNS,
IDEALIZED BLADES




FIGURE 4-6

TRW-OTEC OPTIMIZATION STUDY,
MAXIMUM L/D VS BASE DIAMETER,
IDEALIZED BLADES




FIGURE 4-7

TRW-OTEC OPTIMIZATION STUDY, THREE STAGE
DOUBLE FLOW DESIGNS
REAL BLADES




FIGURE 4-8

TRW-OTEC OPTIMIZATION STUDY, FOUR STAGE
DOUBLE FLOW DESIGNS
REAL BLADES

$P_{IN} = 128.8$ PSIA
 $T_{IN} = 70^{\circ}$ F
 $P_{EX} = 89.2$ PSIA




FIGURE 4-9

TRW-OTEC OPTIMIZATION STUDY, FIVE STAGE
DOUBLE FLOW DESIGNS
REAL BLADES




FIGURE 4-10

TRW-OTEC OPTIMIZATION STUDY, DOUBLE FLOW
DESIGNS, 31 IN. BASE DIA.

REAL BLADES

$P_{IN} = 128.8$ PSIA

$T_{IN} = 70^{\circ}$ F

$P_{EX} = 89.2$ PSIA




FIGURE 4-11

TRW-OTEC OPTIMIZATION STUDY, MAXIMUM L/D
VS. BASE DIA.
REAL BLADES




FIGURE 4-12

TRW-OTEC OPTIMIZATION STUDY, FOUR STAGE
10MW NET DESIGNS
REAL BLADES

$P_{IN} = 128.8$ PSIA
 $T_{IN} = 70^{\circ}$ F
 $P_{EX} = 89.2$ PSIA




FIGURE 4-13

TRW/OTEC OPTIMIZATION STUDY
SINGLE STAGE, SINGLE FLOW DESIGNS
IDEALIZED BLADES
BASE DIAMETER = 31 IN.




FIGURE 4-14

TRW-OTEC OPTIMIZATION STUDY,
FOUR-FLOW, RADIAL INFLOW DESIGNS




FIGURE 4-15

TRW-OTEC AMMONIA EXPANDER
VARIATION OF FLOW WITH EXHAUST
PRESSURE




FIGURE 4-16

TRW-OTEC AMMONIA EXPANDER NET OUTPUT
AT AN EXPANDER EXHAUST PRESSURE
OF 89.2 PSIA




FIGURE 4-17

TRW-OTEC AMMONIA EXPANDER VARIATION OF NET OUTPUT VS EXHAUST PRESSURE




FIGURE 4-18

TRW-O TEC AMMONIA EXPANDER
CORRECTION FOR GENERATOR EFFICIENCY




FIGURE 4-19

TRW-OTEC AMMONIA EXPANDER NET OUTPUT
AT AN EXPANDER EXHAUST PRESSURE OF
89.2 PSIA




FIGURE 4-20

TRW-OTEC AMMONIA EXPANDER NET OUTPUT
AT AN EXPANDER EXHAUST PRESSURE
OF 89.2 PSIA




FIGURE 4-21

TRW-OTEC AMMONIA EXPANDER NET
OUTPUT AT AN EXPANDER EXHAUST
PRESSURE OF 89.2 PSIA




FIGURE 4-22

TRW-OTEC AMMONIA EXPANDER NET OUTPUT
AT AN EXPANDER EXHAUST PRESSURE OF
89.2 PSIA




FIGURE 4-23

TRW-OTEC AMMONIA EXPANDER
SEASONAL VARIATION IN EXPANDER
EFFICIENCY WITH VARIABLE FIRST
STAGE STATOR ANGLE






FIGURE 4-24


TRW-OTEC FIRST STAGE VELOCITY TRIANGLES
AT DESIGN CONDITIONS



BASE




MEAN




TIP

FIGURE 4-25


TRW-OTEC SECOND STAGE VELOCITY TRIANGLES
AT DESIGN CONDITIONS



BASE



MEAN



TIP

FIGURE 4-26

TRW-OTEC THIRD STAGE VELOCITY TRIANGLES
AT DESIGN CONDITIONS






FIGURE 4-27

TRW-OTEC FOURTH STAGE VELOCITY TRIANGLES
AT DESIGN CONDITIONS




FIGURE 4-28

EFFECT OF EXHAUST DIFFUSER PRESSURE RECOVERY ON EFFICIENCY OF THE TRW-OTEC AMMONIA EXPANDER





FIGURE 4-29

EFFECT OF MOISTURE LOSS FACTOR
ON THE EFFICIENCY OF THE TRW-O TEC
AMMONIA EXPANDER



SECTION 5

EXPANDER MECHANICAL DESIGN

Prior to the start of any design effort, design objectives must be established. The following objectives were established for the mechanical design of the ammonia expander:

- Expander is to drive a synchronous generator and operate at a speed consistent with the aerodynamic design.
- Positive casing sealing is required to contain the toxic ammonia gas.
- The shaft end seals should not leak the ammonia gas to the atmosphere in the event of loss of pressurized seal oil.
- Assembly and disassembly of the expander internals should not disturb the generator, nor the inlet and exhaust gas piping.

--- Bearings and seals shall be inspected or replaced without disturbing the main casing.

--- Blading shall be suitable for the required loadings.

The above objectives can be attained by the following:

--- Design the rotor bearing system such that no harmful or objectionable frequencies are within ± 20 percent of the operating speed.

--- Utilize barrel construction on the expander casing to provide full continuous sealing at the joints.

--- Utilize a contact type seal with shutdown features for virtual leakproof condition with zero sealing oil pressure.

--- Design the barrel-type expander such that the internal parts are removable from one end utilizing simple assembly and disassembly fixtures.

--- Utilize acceptable stress analysis techniques to qualify the blading.

The results of the conceptual design effort are shown in the cross-section layout of the expander, Figure 9 - 1.

ROTOR

Construction

The rotor construction shown on the layout utilizes separate disc assemblies shrunk onto the shaft to maintain concentricity and keyed to transmit the torque. An alternate method is to make the discs integral with shaft. Preliminary investigation indicates that the key disc shrink area may be conducive to stress corrosion cracking in the atmosphere. Further investigation of the stress corrosion potential is required before a final determination of the rotor construction can be made.

Critical Speed

The initial design objective was to make a stiff shaft design where the operating speed is below the first critical speed. Due to the desire to optimize thermodynamic performance, however, the mechanical design gave way. The result is a flexible shaft design with the operating speed between the first and second critical speeds, which are approximately 1300 rpm and 2700 rpm, respectively. The flexible shaft design allows for:

--- Better axial spacing for the inlet channel and for the diffuser at the blade path exhaust.

--- Better placement of the seals and bearings for maintenance accessibility.

--- Smaller bearings and seals requiring less oil flow and power loss.

There are no anticipated difficulties in running the expander between its first and second critical speeds. This is common practice for turbine/generator applications.

BEARINGS

Journal Bearings

The journal bearings should be 10-1/2 inch diameter by 7 inch wide cylindrical bearings and provide a stiffness of approximately 5×10^5 pounds per inch. These journal bearings are adequate considering loading, sea state conditions and critical speed. The bearing retainers are spherically seated to facilitate alignment of the bearings to the shaft. An alternate bearing configuration would be a five shoe tilt pad type, but for this rotor at 1800 rpm the better choice would be cylindrical bearings.

Thrust Bearing

A 55.1 square inch thrust bearing is recommended to accommodate the generator thrust loading due to magnetic misalignment and the thrust due to manufacturing tolerances on the blade rows on either side of the double flow unit. The thrust bearing is a self-equalizing Kingsbury type that is double acting to provide positive positioning of the rotor. The thrust collar is removable from the shaft for ease of maintenance, but does not require removal to change the seal for this particular design size.

SEALS

Four basic types of rotor-casing seals, shown in Figure 5 - 1 through 5 - 4, are used in turbines and compressors for minimizing the amount of motive fluid leaking out along the shaft. These are:

- Labyrinth Seals
- Dry Carbon Ring Seals
- Bushing Seals
- Face Seals

For this unit the labyrinth type seal was ruled out because it permits leakage of large quantities of the motive fluid. The dry carbon ring type seal has a lower leakage rate than the labyrinth type, but it will also permit leakage of the motive fluid to the atmosphere upon shutdown. The bushing type seal is used predominantly for very high

pressures and would have a large amount of seal oil leakage compared to the face seal. Looking at all factors for this ammonia expander application, the face type seal is recommended for use in this design.

For applications where no gas leakage to the atmosphere can be tolerated, a highly refined contact type face seal with shutdown features and a proven record of performance in process gas compressor installations should be used. During idle periods, shutdown pistons automatically lock the face seal ring. This permits the seal oil system to be shutdown with no ammonia gas leakage even though the expander is still pressurized.

CASING AND MAINTENANCE

The ammonia expander has five major components, namely; the outer casing barrel, the endwalls, inner casing assembly, the rotor assembly, and the two bearing cases. The inner casing assembly can be further broken down to include a stator housing, three diaphragm assemblies for each direction of flow, a diaphragm seal assembly for each diaphragm, a set of variable nozzles for each direction of flow, an inner guide ring for each set of variable nozzles, and variable nozzle linkage. A cross-section layout of the ammonia expander is shown in Figure 9 - 1.

The outer casing, which is of the barrel-type construction to provide full continuous sealing at the joints, has an outside diameter of 120 inches and an overall length of 181-1/2 inches. The 60 inch Class 175 flat faced inlet flange is fabricated to the outer casing thru a transition section and is located on the top vertical centerline 94 inches above the horizontal centerline of the machine. Note that the transition from the round inlet to the obround intersection with the outer barrel provides for the required flow area to maintain low fluid velocities and at the same time minimizes the bearing centerline distance. In a similar fashion there is a transition from the barrel section to the 96 inch Class 175 flat faced exhaust flanged 94 inches below the expander horizontal centerline.

The entire expander is provided with true centerline support by four support feet and keys to maintain the axial centerline. Once aligned at the site, the outer casing will not need to be removed from its foundation; thus the inlet and exhaust joints would not normally be broken.

The endwalls are bolted to the outer casing to provide sealing at the vertical joint. The endwall at the coupling end will not need to be removed once it is aligned to the outer casing. The endwall at the thrust end will require removal for assembly/disassembly purposes when any internal maintenance is desired. In addition to containing the motive fluid in the axial direction, the endwalls also accept

the stationary parts of the face seal that keeps the ammonia from escaping along the shaft to the atmosphere.

The function of the stator housing is to support and position the stationary diaphragms and to direct the flow from the inlet through the rotor to the exhaust. This casing is horizontally split and is fabricated from two half castings, which are welded to the inlet guide vanes to form the top and bottom halves.

The variable nozzles are connected through linkage to a common ring. Therefore, only a single rod penetrates the outer casing for each of the two rows of variable nozzles. The rod will be surrounded by a bushing and O-rings to prevent leakage of any ammonia to the atmosphere. Variable nozzles for axial flow steam turbines are not generally used because control valves have been historically used for part load conditions and high temperatures can create serious deformation problems at the operating pressures. Variable stators have been used very successfully throughout the industry on axial flow compressors for decades. Typical control linkage for an axial flow compressor is shown in Figure 5 - 5. This type of control has exhibited a high level of reliability with a minimum of maintenance.

The rotor assembly is positioned in the casing and provides the means of efficiently converting the energy of the ammonia motive fluid to usable power.

The two bearing cases, which are attached to the endwalls, provide a means of supporting and positioning the rotor.

Normal maintenance turnaround for the ammonia expander would be expected to be:

--- Twelve months for the first turnaround.

--- Twenty-four to thirty-six for subsequent turnarounds.

The first turnaround will require approximately three men for six shifts to make a complete inspection of bearings, seals, rotating element and stationary parts. Subsequent turnarounds of approximately four men for two shifts will involve inspection of only the bearing and seals. Full turnaround including the rotor inspection, similar to the first turnaround, should be conducted every five or six years. Service life of the expander can be expected to be similar to steam turbine generator drives.

The expander should be designed for minimum disassembly for maintenance on the bearings and seals. The bearings can easily be inspected by the removal of the top half bearing cases without disturbing the alignment. The face seals with shutdown features require the disassembly of the bearing cases and on the drive end the coupling must also be removed.

Special tools and fixtures should be provided for the disassembly of the complete expander. These fixtures would include rails to remove the inner casing, a centering ring to maintain concentricity between the rotor and inner casing during insertion, an endwall counterweight for stabilization during disassembly and provisions for eyebolts to remove the bearing cases. Also, a complete instruction book containing a detailed description of assembly and disassembly procedures should be supplied. Normally, the instruction book will include data on trouble shooting as well as alignment methods and spare parts lists.

The lube oil console maintenance and inspection should follow vendor recommendations. Components such as pumps and coolers should be inspected at each turnaround. Filters, reservoir tank oil level, oil pressures, and the temperatures should be checked on a daily basis to insure proper operation. The instrumentation gages, thermocouples, readouts, etc., should be inspected and calibrated at six month intervals.

Maintenance procedures for the synchronous generator should follow the manufacturer's recommendations.

MOISTURE EROSION

The proposed four stage ammonia expander should suffer no significant moisture erosion damage at the specified operating conditions. Consequently, protection of the leading edges of the rotating

blades with the use of stellite strips is not required. Also, due to the low levels of moisture and low velocities encountered in this design, stationary moisture collectors are unnecessary.

The above conclusions are based on calculations of surface tension, maximum stable droplet size, and the erosion coefficient for the ammonia expander as compared to steam turbine experience. At 90 psia pressure, the surface tension of water (.0032 LBF/FT) is 2.0 times greater than it is for ammonia (.0016 LBF/FT); therefore, the apparent hardness exhibited on impact of an ammonia droplet is much less than a water droplet at similar conditions. Similarly, the maximum stable droplet size on the basis of a Weber number calculation is more than three times larger in steam (.609 micron) than it is in ammonia vapor (.199 micron), therefore, the smaller ammonia drops will cause less erosion damage than the larger water drops would cause at similar conditions. The erosion coefficient from the equation

$$E = 4.1072 \times 10^{-6} \frac{K Y_0 U_{TIP}^3}{P_0}$$

was calculated for each rotating blade of the ammonia expander at nominal conditions. In the above equation K is a constant, which depends on the distance from the stator blade trailing edge to the rotor blade leading edge and on the thickness of the stator blade trailing edge. The value Y_0 is the fraction moisture level ahead of the stage, and U_{TIP} is the speed at the tip of the rotating blade in feet per second.

P_0 is the stage inlet static pressure in pounds per square inch absolute. The maximum erosion coefficient, which occurs on the fourth stage with 2 percent moisture ahead of the stage, was calculated to be .003. The threshold of significant erosion danger is at a coefficient of 8 or greater based on steam turbine experience. For example, a typical last stage of a large steam turbine with a moisture of 8 percent has an erosion coefficient of 30 or more.

ROTOR BLADES

The rotating element is the critical item in any piece of rotating equipment. Consequently, Elliott is compelled to insure that the design of the blading is both adequate and practical from a mechanical viewpoint and at the same time keep a watchful eye on optimizing the aerodynamic performance. The proposed expander design has attained these objectives.

Although all four rotor blades have been analyzed only the results for the fourth row, which has the highest stresses and lowest frequency, are presented in this report.

The direct tensile stress at the base of the vane of the last rotor blade row for the nominal operating conditions is 3255 psi and the gas bending stress, which is a maximum at the leading edge, is 5566 psi. Therefore, the maximum total steady state stress is 8821 psi. With these values and properties of annealed AISI Type 403 material,

a Goodman Diagram can be constructed. The Goodman Diagram provides a means of qualifying rotating parts and is an accepted standard in the industry. Figure 5 - 6 is the Goodman Diagram for the fourth row rotor blade. The diagonal solid line represents the failure line for annealed AISI Type 403 material at the blade temperature with a 1.667 stress concentration factor applied to the alternating stress. Actual stress values to the right of this line indicate the blade will fail. As you can see, the combination of stresses for the blade in question is well to the left of this diagonal line, and therefore, there is a certain amount of margin in the design. To determine the amount of margin in a design Elliott calculates a ratio termed the Goodman Factor. The Goodman Factor is just the allowable alternating stress at the blade total steady state stress divided by the actual blade bending stress. For this particular blade the Goodman Factor is 3.3. From historical data, Elliott has found the blades with Goodman Factors of 2.5 and larger will not experience failures due to these stresses for this type of staging.

The rotating blades should be designed so that its natural frequency exceeds the low multiples of the operating speed and does coincide with the nozzle passing frequency. Since the fundamental material frequencies of the rotating blades range from 8 to 11 times the operating speed, no blade vibratory problems are anticipated.

FIGURE 5-1

LABYRINTH SEAL




FIGURE 5-2

DRY CARBON RING SEAL





FIGURE 5-3

BUSHING SEAL




- 1. STATIONARY SEAL SLEEVE
- 2. ROTATING SHAFT SLEEVE
- 3. SPRING
- 4. SEAL CASING PARTITION
- 5. BEARING OIL DRAIN LINE

- 6. GAS AND CONTAMINATED OIL DRAIN
- 7. FLOATING BABBITT-FACED STEEL RING
- 8. SEAL OIL DRAIN LINE
- 9. WIPER RING
- 10. BEARING WIPER RING

FIGURE 5-4

FACE SEAL WITH SHUTDOWN FEATURES



- | | |
|-----------------------------------|--------------------------------------|
| 1. ROTATING CARBON RING | 8. FLOATING BABBITT-FACED STEEL RING |
| 2. ROTATING SEAL RING | 9. SEAL WIPER RING |
| 3. STATIONARY SLEEVE | 10. SEAL OIL DRAIN LINE |
| 4. SPRING RETAINER | 11. SECONDARY WIPER RING LABYRINTH |
| 5. SPRING | 12. BEARING OIL DRAIN LINE |
| 6. SHUTDOWN SEAL PISTON | 13. BEARING WIPER RING |
| 7. GAS AND CONTAMINATED OIL DRAIN | |

FIGURE 5-5

VARIABLE NOZZLE LINKAGE





FIGURE 5-6

TRW-OTEC AMMONIA EXPANDER
GOODMAN DIAGRAM



SECTION 6

GENERATOR DESIGN AND ANALYSIS

GENERATOR DESIGN

The Brown Boveri Model WG1000 db 4L generator presented is a 4-pole synchronous generator with a TEWAC (total enclosed water to air cooled) enclosure. Data for this generator is presented in Table 6 - 1. Generator overall efficiency versus load is shown in Figure 6 - 1.

The generator design is such that the service factor is 1.00 at full load of 18.0 MW. A load limiter should be included in the control scheme to prevent a generator overload condition.

Since this generator is only 97.2 percent efficient at full load, inquiries were made for a hydrogen cooled synchronous generator for this service. It was anticipated that efficiencies of 98 percent, or slightly higher, could be obtained. Both Brown Boveri and Westinghouse, however, have responded that they do not offer hydrogen cooled 2, 4 or 6-pole synchronous generators below the 25 to 35 MW range.

Generator vendors were not requested to design a hydrogen cooled

synchronous generator for this particular application. If all development costs for a hydrogen cooled generator were to be absorbed by one unit, the development costs should not exceed the value of the additional power produced. Thus, if a generator manufacturer would be amenable to expend the required design effort, the cost of the hydrogen cooled unit should not exceed the TEWAC generator by more than \$150,000.

COUPLING DESIGN

Three types of couplings have been considered for the ammonia expander/generator string, namely; a solid coupling, a gear type coupling and a diaphragm type coupling.

The solid coupling would be the least expensive type. It has the disadvantage, however, that there are no provisions in the design to accommodate offset or misalignment between the expander and generator. Precise alignment requiring many additional man-hours of time would be necessary and any initial cost advantage would quickly disappear. In addition, the barrel construction of the expander dictates that the coupling hub on the expander shaft must be removed to disassemble the expander. The possibility of getting the coupling hub back on the shaft exactly as it was before removal is highly improbable. Therefore, the solid coupling is not recommended.

A gear type coupling would provide for limited end float, and

could accommodate reasonable offset and misalignment between the two units. A verbal quote has been obtained for a number 9 Koppers gear type coupling at \$7500.

A diaphragm type coupling would also be acceptable because it can provide for limited end float, offset and misalignment. A verbal quote of \$8000 has been obtained from Bendix for their model 67E516.

Although both the gear and diaphragm type couplings are suitable for this design application, the diaphragm coupling is recommended because it does not require lubrication and allows for bearing case and seal removal.

T A B L E 6 - 1

GENERATOR DATA

Type	Synchronous
Manufacturer	Brown Boveri Corp.
Rated (KW)	18,000
Synchronous Speed (RPM)	1,800
Rated Voltage	13,800
No. of Phases/Frequency	3/60
Power Factor	0.8 Lagging
Service Factor	1.00
Efficiency % (at 4/4, 3/4, 1/2 Load)	97.2, 96.9, 96.2
Insulation Class	F
Max. Temp. Rise (Winding, over 40°C)	80°C
Excitation Type	Brushless
Excitation DC Voltage (at F.L.)	112
Excitation Response	2.0
Short Circuit Ratio	0.55
Short Term Thermal Capability (balance current)	100 Sec.
Short Term Thermal Capability (short current at machine terminals)	
Unbalanced (Line to Neutral)	30 Sec.


T A B L E 6 - 1 (cont...)

GENERATOR DATA

Wave Form Deviation, Max. %	0.8
Calculated Transient and Subtransient Reactance	27% 21%
Enclosure	TEWAC-Weatherproof
Cooling Water Inlet temp. (Max.), °F	85
Cooling Water Outlet Temp. °F	95
Cooling Water Requirements (GPM)	295
Lube Oil Pressure (PSIG)	15 - 18
Lube Oil Requirements (GPM)	8
WK ² of Machine (LB-FT ²)	24620 generator/exciter
Permissive Overspeed (RPM)	2250
Vibration Max., (MILS) peak-to-peak	1.5 approx.
Noise Level, dB (A)	84 + 3 dB (A) tol.
Weight (lbs.) net/shipping	86640/100500
Overall Dimensions	
Reactive Power Capacity	
20 40 60 80 100 % of Load	
14.4 14 13.3 12.4 11.2 MVA	

FIGURE 6-1

TRW-OTEC GENERATOR OVERALL
EFFICIENCY VS. PERCENT LOAD



SECTION 7

CONTROLS

VALVE SIZING

Two ammonia gas control valves have been investigated and sized for the expander operation, namely the emergency trip valve ahead of the expander and a bypass valve around the expander. The trip valve will be the equivalent of a 60 inch diameter to match the expander inlet size and should be as close to the inlet flange as possible so that the maximum overspeed of the string can be minimized. The bypass valve need only be the equivalent of a 30 inch diameter because the full pressure drop can be taken across it during start-up, shutdown or during an emergency trip out.

Governor valve requirements for speed control using fixed inlet nozzles in place of speed and load controlled variable inlet nozzles have not been investigated due to the limited time frame for this study. However, no difficulties are anticipated if this arrangement should be preferred. As discussed in Section 4, load controlled variable inlet nozzles are justified for maximizing seasonal output. Speed controlled variable nozzles can also satisfy synchronizing and grid

isolation requirements assuming that the variable nozzles can be designed to control the flow from no load to maximum power conditions.

VALVE CHARACTERISTICS

It is desirable to have a single 60 inch butterfly type trip valve close as quickly as possible. But if it were to slam shut, the valve seat would be damaged and eventually not perform its function. One approach to solve the quick trip problem is to have the valve close quickly to the point where it is only 5 percent open, and ease it closed for the remaining portion. Typical closing times of commercially available hydraulic operated 60 inch diameter butterfly valves are of the order of 3 to 5 seconds. This is not fast enough to prevent overspeeding of the expander/generator on an electrical full load dump. The preferred choice is a swing through type valve designed with a 0.5 second response time to close the valve. This valve would cost about \$75,000 and should have hydraulic actuation. Although a detailed calculation of the system was not possible with the information available, it is estimated that the above response times are adequate.

The bypass valve is a 30 inch butterfly valve with 0 to 70 degrees travel and a cost of \$31,900. Since tight shutoff and not fast closing is a requirement for this duty, the valve has a 5 second stroking speed from full open to full closed. The important characteristic of this valve is that it can fully open at the time of an emergency tripout in one second or less. This action will divert the motive fluid around the expander.

CONTROL SCHEME

Control of the expander/generator string covers the three basic phases of start-up/shutdown, steady state, and emergency trip. This system is rather unique due to the characteristics of this process, the requirement to limit the generator output, and the requirement to maximize expander output at any steady state condition. A simplified block schematic of the proposed control system is shown in Figure 7 - 1.

The basic elements of the OTEC ammonia cycle are: 1) the condenser for taking the ammonia vapor and converting it into liquid; 2) the ammonia pump for adding pressure head to the liquid; 3) the vapor generator which extracts heat from the warm sea water and transfers it to the ammonia for vaporization; 4) the expander which expands the ammonia vapor to extract energy and convert it to mechanical power; and, 5) the generator which converts the mechanical power to electrical power.

The control system requires a storage and makeup system so that the closed loop can be supplied with the desired amount of motive fluid as operating conditions vary.

The ammonia pump takes liquid from the condenser and pumps it to the vapor generator. Liquid ammonia is converted to a gas in the vapor generator as it passes through. Ammonia vapor passes through

the emergency trip valve and on to the expander variable nozzles, which are tied to the load-speed control. The exhaust flow from the expander goes to the condenser. The level control will maintain level in the condenser pump by bleeding fluid from the makeup system as needed. A bypass valve in a loop around the expander enables the entire loop to operate as a closed system during start-up without the expander rotating.

On start-up the expander trip valve would be closed. The cold sea water pump and warm sea water pump would then be activated.

Activation of the ammonia pump would raise the liquid level in the vapor generator to the desired level with the excess being diverted to the makeup system. Vapor would start to be generated and the system pressure would increase to the saturation pressure attainable with the warm sea water. Eventually, the steady state quantity of ammonia vapor would be generated.

Next, the variable nozzles are set to minimum setting and the trip valve is opened to admit a nominal amount of vapor through the expander.

When enough torque is developed to overcome frictional forces, the expander/generator string will come up to some minimum speed. The variable nozzles will be gradually opened and the bypass valve partially

closed until synchronous speed is attained. The variable nozzles will be used to synchronize the generator.

After synchronization load will gradually be applied to the string by opening the variable nozzles the required amount; the expander bypass valve will gradually be closed until it is completely shut.

Normal shutdown would basically be the reverse of the start-up procedure. Shutdown of the warm sea water pump would remove the heat source and vaporization would cease.

The requirement to maximize power at any steady state condition dictates a unique type of control, which is only possible if variable nozzles are provided and the generator is base loaded. The control would be as follows:

The generator is loaded to the desired capacity with the speed control. The load control is then transferred from manual to automatic operation. In the automatic mode, the load control actuates the variable nozzles a predetermined amount at preset time intervals. Initially, there is no movement of the variable nozzles until the dead band of the controls is exceeded. When the variable nozzle position exceeds this dead band, the load control will sense the increase (or decrease) in power output and will increase (or decrease) the speed set point of

the speed control. The load controller, however, is "smart" in that if power output drops instead of increasing it will reverse operation to decrease (or increase) the speed set point. This is a slow response activity compared to the speed control.

The dead band, proportional band and reset on the speed setting must be adjusted and tuned on site to match the response of the system.

For nonbase loaded operations the control would be as follows:

The generator produces the power required by the load. If the generator load drops below the set point, speed control will want the speed returned to 1800 rpm. Therefore, it will cause the variable nozzles to quickly close and provide less power. If the load is increased, the speed will drop below 1800 rpm and the nozzles will be quickly opened to return the speed to the set point.

The above control scheme has been reviewed with Woodward Governor Company and it seems practical, although there are no known applications of this kind. If the generator output exceeds its rating, a load limiter will decrease the variable nozzle setting, thereby reducing the mass flow to the expander based on the heat source characteristics. Thus, the power input to the generator will be reduced. The load limiter signal could be a part of the load control and will override the maximization of power signal to the variable nozzles.

For the safety of personnel and equipment redundancy has been included in the overspeed trip devices.

If there is a loss of generator load while it is on the line a signal will cause the emergency trip valve to close, the variable nozzles to go to minimum setting, and the expander bypass valve to completely open. This type of emergency is most serious, and thus, safety measures should be instituted at the earliest possible time.

The speed signal from the expander electronic speed counter provides back-up by initiating the above three actions at 3% (1854 rpm) overspeed.

The mechanical overspeed trip on the expander shaft, set at 10% (1980 rpm) overspeed, provides another means to initiate the above sequence of events.

FUTURE WORK

Several facets of the control area are recommended for future analysis.

The speed and load control is believed to be reasonable and feasible but a more detailed investigation is in order.

The variable nozzle minimum setting has to be studied along with

the expander bypass valve area to determine the minimum idle speed after breakaway.


The maximum overspeed of the string with maximum load dump needs to be studied for the actual valve response times, taking into account stored energies and system characteristics assuming the emergency signal occurs at 1800 rpm, at 1854 rpm, and at 1980 rpm.

The variable nozzle requires study to determine if it can provide tight shutoff in the required time, thus eliminating the emergency trip valve. While this is appealing, Elliott does not feel that this can be accomplished without compromising performance. This compromise, however, is minimized with a multistage design.

Also, it might be possible to eliminate the expander bypass valve. This evaluation would require an extensive study of the cycle dynamics. It may not be possible to synchronize the generator at system part load. In addition, the process upsets on the trip out of the string may be intolerable.

OTEC PROPOSED CONTROL SCHEMATIC

FIGURE 7-1



SECTION 8

LUBE AND SEAL SYSTEM

FLOW REQUIREMENTS

Lube and seal oil flow requirements are as follows in Table

8 - 1.

T A B L E 8 - 1

	GPM MAX/NORMAL	PRESSURE PSIG
Expander		
Journal Bearings	12.5	15 - 18
Thrust Bearing	11	15 - 18
Iso-Carbon Seals	<u>12.5</u>	125 MAX
Expander Total	36	
Generator Journals Total	8	15 - 18
Controls (Estimated)		
Variable Nozzles	15/10	125
Trip Valve	15/10	125
Bypass Valve	15/10	125
Total Controls	45/30	
Total String Requirements	89/74	

Lubricants utilized in ammonia expanding equipment have a unique requirement for chemical compatibility. Undesirable reactions such as congealing or formation of deposits should not occur. Ordinarily this need can be met by a choice of a straight uninhibited mineral oil. Either a straight naphthenic or a pour point depressed paraffinic oil would be suitable for the subject service; the oil should be of a good quality, and pass the oxidation test ASTM D943 for 3000 hours minimum. For the design of this lube console ARCO Ideal Oil S-150, which has an oxidation life of 4000 hours, has been used.

COMPONENTS

API 614, with some Elliott exceptions, was used throughout for the design of the lube system. Due to the ammonia atmosphere and salt water cooling water, no copper or copper bearing alloys will be in contact with the oil or atmosphere. The coolers and filters are ASME Code design and the coolers are TEMA "C" design. Electrical components will be good for NEMA Class 1, Group D, Division 2 areas. All switches are single-pole, double-throw type.

The schematic for this console is shown in Figure 9 - 4. The components in the lube system are reviewed below.

The oil reservoir is designed to insure an undisturbed positive suction for the oil pumps. The reservoir capacity, based on normal flow, is determined through API 614 requirements of a 5 minute working capacity

between minimum operating level and suction-loss level and an 8 minute retention capacity below the minimum operating level. A rundown capacity, capable of holding the total volume of oil in the piping and components, is provided above the maximum operating level. Free board is provided above rundown level. The reservoir is equipped with an internal baffle separating the return lines from the pump suction lines to help prevent vortexing at the pump suction. Each pump suction nozzle is equipped with an antiwhirl plate as well. A dessicant-type breather vented through a stack is provided to protect the tank from overpressure. Purge connections are also provided. A level indicator and a level alarm switch are provided to warn the operator of an accidental loss of oil.

The A.C. motor driven main and auxiliary oil pumps are horizontally mounted screw type positive displacement pumps in order to provide essentially pulsation-free oil to the equipment. The drivers are sized to permit the pumps to start up with 1000 SSU oil (40°F) and reach the relief valve set point without burning out the drivers. The pumps are sized to individually supply the necessary oil flows at the required pressures so that if one pump becomes inoperative, the other pump will supply the equipment requirements. Relief valves are provided on each pump discharge line to protect the oil console against overpressure. A D.C. motor driven centrifugal oil pump acts as a back-up for the bearing oil supply for emergency coastdown.

Twin shell and tube type oil coolers are provided to remove the

friction generated heat from the oil and maintain acceptable oil temperatures at the unit. The oil is maintained at a pressure higher than the cooling water to prevent water leaking into the oil. Twin oil filters of a nominal 10 micron rating are provided downstream of the coolers to insure a clean oil supply to the bearings and seals. The filter media is replaceable cotton-cotton matrix cartridges.

A transfer valve is located between the cooler-filter sets. This 6-ported valve permits a change over from one cooler-filter set to the other without bypassing any oil or interrupting the delivery of oil to the seals and bearings. This permits maintenance on the idle cooler-filter set.

A differential pressure indicating switch is provided across the cooler-filter-transfer valve package to indicate the dirty-filter cartridge condition.

A separate single oil filter is provided in the emergency oil supply to the bearings. A differential indicator is provided to indicate the dirty-filter cartridge condition.

Temperature and differential pressure switches notify the operator of a filter or cooler problem.

A pressure switch is located in the main oil header to automatically

start the auxiliary oil pump motor upon loss of header pressure.

A pneumatically controlled back-pressure regulator maintains a constant header pressure downstream of the coolers and filters by dumping the excess oil to the reservoir. This valve is selected to control the header pressure with either one or two of the oil pumps running.

Self-operated pressure regulating valves pass the required flow at the required pressure to the expander bearings and to the generator bearings. A pneumatic operated regulator is provided to pass the required flow and to follow the required differential pressure across the expander shaft seals. A pneumatic operated regulator is also provided to pass the desired flow to the control accumulators. Each regulator station is complete with isolating gate valves and bypass and vent globe valves to provide for maintenance of the valves without disturbing the unit.

Redundant pressure switches and differential pressure switches are installed in the bearing oil feed lines and seal oil feed lines, respectively, to protect the unit on loss of oil. They operate on a "majority rules" basis to eliminate accidental trip out of the string. Alarm switches are also connected to these lines to prompt for operator attention. An alarm switch is connected to the control oil feed line to indicate loss of pressure.

A contaminated seal oil drainer is provided for each of the flat face seals. These drainers permit the separation of free ammonia vapors from the oil and venting of the ammonia vapors to a collector system. The contaminated oil is discharged to the degassing tank.

A degassing tank equipped with an electrical heater separates the entrained ammonia from the oil and vents it to a collector system.

Thermometers are locally mounted at normal points of interest. Thermocouples may be used in lieu of thermometers or in parallel with them for remote read-out stations.

Pressure gages are also locally mounted at normal points of interest, as shown on the schematic, with pressure transducers in lieu of, or in parallel with the pressure gages. Pressure switches are mounted locally.

Sight flow indicators are normally provided in each lube oil drain to provide visual verification of oil flow.

Drain lines from the units should have a minimum slope of 1/4 inch per foot of pipe length to satisfy land-based installations plus an additional amount of slope required to drain the oil during sea state 6 conditions. If the lube console is located about 20 feet below the expander/generator string level, there should be ample slope for these

adverse conditions. Additional pump head capability will be required if the pump discharge is more than 25 feet below the bearing feed elevation.

AUXILIARY REQUIREMENTS

Requirements for auxiliary services are outlined in Table 8 - 2.

T A B L E 8 - 2

AUXILIARY SERVICES

Lube Console

Cooling Water	100 gpm @ 85°F
Control Air	15 psig
Pump Power	20 HP normal/30HP max.
Emergency DC Power	8 HP normal/15HP max.
Instrumentation	120 V 1 ϕ 60Hz 2KW

Expander

Instrumentation	120 V 1 ϕ 60Hz 2KW
Controls	120 V 1 ϕ 60Hz 1 KW

Generator

Cooling Water	295 gpm @ 85°F
---------------	----------------

DEGASSIFICATION.

A degasifying system for the lube and seal oil is recommended to minimize contamination of the oil with ammonia. The system consists of a small degassing tank, usually located on top of the oil reservoir equipped with an electrical heater, to separate the entrained ammonia from the oil and pass it to the collector system or vented to a stack above deck level.

SECTION 9

SUBSYSTEM DESIGN

CROSS-SECTION LAYOUT

Figure 9 - 1 shows the cross-section layout of the four stage double flow ammonia expander for 14.4 MWe at the nominal conditions. The expander is a flexible shaft design with a 151 inch bearing span. Flow enters at the top center of the expander and is distributed circumferentially before it turns axially to feed both sets of blading of the double flow design. After passing through the four stages the ammonia is efficiently diffused to exhaust pressure where the two flows are joined before exiting thru the common exhaust flange on the bottom vertical centerline. The overall shaft-end to shaft-end length is 197 inches with a 120 inch diameter of the outer casing. The casing and shaft lengths are nearly equal. The 60 inch diameter inlet is 94 inches from the horizontal centerline and the 96 inch exhaust flange is also 94 inches from the horizontal centerline.

The stages are located between the journal bearings and flat face shaft seals with the thrust bearing, and speed control devices, located outboard of the journal bearing on the nondrive end.

In Figure 9 - 2 data pertaining to the blade path is shown. This layout contains blade data such as number of blades and diameters. Table 9 - 1 contains additional data such as blade axial widths and gauging angles. Any and all blade data not shown in Figure 9 - 2 or in Table 9 - 1 is proprietary to Elliott Company.

STRING ARRANGEMENT

Arrangement of the expander, generator and coupling are shown in Figure 9 - 3 with appropriate overall dimensions. Pertinent details of each component can be found elsewhere in this report. Weights of major parts are in Table 9 - 2. If the components are shipped separately, a 50 ton crane will be required to lift the expander outer casing. If everything is mounted on a baseplate and lifted at the same time, a 150 ton crane will be required; since the baseplate is not included in any of these weights, it is assumed that it will not weigh more than 33000 pounds.

Straight removal of the generator rotor from the exciter end will require 13 more feet of space assuming the exciter portion of the rotor is not removed from the generator shaft. Sixteen and one half feet are needed to remove the expander rotor from the thrust end of the expander casing. The above procedure permits removal of either rotor without disturbing the other unit. It is recommended that a set down work area of 38 feet wide by 24 feet long be provided at the thrust end of the expander. This same area can be used for generator repairs, if desired,

provided the generator parts can be moved past the expander casing. Otherwise, an area 20 feet wide by 20 feet long will be needed for set down and work space for generator parts. Head room under the crane hook to the top of the generator sole plates of 17-1/2 feet is needed for 18.0 MWe TEWAC generator with cooler mounted on top of the generator.

LUBE AND SEAL OIL SCHEMATIC

Figure 9 - 4 shows the lube and seal oil system schematic. The major components include the reservoir, pumps, filters, coolers, regulators, relief valves, pressure switches, receivers and vacuum degassing tank. A more detailed description of the lube and seal system can be found in Section 8.

TABLE 9 - 1

TRW - OTEC DOUBLE FLOW AMMONIA
EXPANDER BLADE GEOMETRY FOR 1800 RPM


<u>STAGE</u>	<u>TYPE</u>	<u>BLADES PER ROW</u>	<u>BASE DIA. IN.</u>	<u>MEAN DIA. IN.</u>	<u>TIP DIA. IN.</u>	<u>BASE GAUGING ANGLE</u>	<u>MEAN GAUGING ANGLE</u>	<u>TIP GAUGING ANGLE</u>	<u>BASE AXIAL WIDTH</u>	<u>MEAN AXIAL WIDTH</u>	<u>TIP AXIAL WIDTH</u>
1	ROTOR	68	31.0	41.40	51.8	25.51	19.47	15.46	2.45	1.49	.97
	STATOR	38	31.0	41.20	51.4	14.57	17.57	20.42	3.05	3.60	4.15
2	ROTOR	68	31.0	41.90	52.8	25.51	19.23	15.18	2.45	1.46	.94
	STATOR	38	31.0	41.70	52.4	14.57	17.72	20.68	3.05	3.63	4.20
3	ROTOR	68	31.0	42.50	54.0	25.51	18.96	14.85	2.45	1.41	.91
	STATOR	38	31.0	42.30	53.6	14.57	17.88	20.95	3.05	3.66	4.26
4	ROTOR	68	31.0	43.30	55.6	25.51	18.58	14.43	2.45	1.35	.87
	STATOR	38	31.0	43.10	55.2	14.57	18.12	21.25	3.05	3.70	4.35


F-133

T A B L E 9 - 2

EXPANDER GENERATOR COMPONENT WEIGHTS


	Weight - Pounds
Expander	
Outer Casing	99,400
Endwalls (2)	31,380
Inner Casing Assembly	36,950
Rotor Assembly	<u>12,870</u>
Total Expander Weights	180,600
Generator including Exciter	
Stator	49,400
Rotor	24,250
Cooler	<u>12,990</u>
Total Generator Weights	86,640
Total String Weights	267,240






REV	DATE	BY	CHKD
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			
56			
57			
58			
59			
60			
61			
62			
63			
64			
65			
66			
67			
68			
69			
70			
71			
72			
73			
74			
75			
76			
77			
78			
79			
80			
81			
82			
83			
84			
85			
86			
87			
88			
89			
90			
91			
92			
93			
94			
95			
96			
97			
98			
99			
100			

TRW-OTEC DOUBLE FLOW AMMONIA EXPANDER BLADE PATH



F-137


FIGURE 9-2



- LEGEND**
- COMBINED OIL DRAIN
 - BEARING OIL SUPPLY
 - BEARING OIL DRAIN
 - PUMP DISCHARGE
 - PURCHASER'S PIPING
 - PUMP SUCTION
 - TURBINE RELEASE LINE
 - TURBINE - LS
 - AIR PIPING
 - TURBINE STEAM IMBET
 - GAS BEARING LINE
 - ISO-SEAL OIL SUPPLY
 - ISO-SEAL OIL DRAIN
 - CONTAMINATED OIL DRAIN

- KEY**
- INSTRUMENT - LOCAL WFL
 - INSTRUMENT - REMOTE WFL
 - PRESSURE INDICATOR
 - TEMPERATURE INDICATOR
 - SUPPLY OF DIFFERENTIAL PRESSURE INDICATOR
 - THERMOCOUPLE
 - PRESSURE SWITCH
 - TEMPERATURE SWITCH
 - DIFFERENTIAL PRESS. SWITCH
 - CHECK VALVE
 - GLOBE VALVE
 - BUTT VALVE
 - PLUG VALVE
 - VALVE - NORMALLY CLOSED
 - EXTENSION RELIEF VALVE
 - SOLENT - IN RELIEF VALVE
 - HOLDING CLAP VALVE
 - TRICK - MET VALVE
 - TRIMMER VALVE (A PORTED)
 - PRESSURE CONTROL VALVE
 - DIFFERENTIAL PRESS. CONTROL VALVE
 - SHIRT PUMP INDICATOR
 - GYFFICE
 - TIE - PLUMED
 - TRAP & TRAPBLE VALVE
 - BORE MINORING
 - BORELINE
 - BORE FLARE BUTT

FIGURE 9-4



TRW-OIEC

SCHEMATIC DIAGRAM, OIL FLOW

DRAWN BY CHECKED BY DATE PROJECT NO.		TITLE SA. 1130101
---	--	----------------------

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

SECTION 10

MISCELLANEOUS

PROTECTION EQUIPMENT

It is of primary importance that all equipment be provided with overspeed protection when there is a potential that the driver may develop more power than the driven equipment. For this application, one example of an excess of power situation is loss of electric load with a three phase fault on the synchronous generator. At that moment the expander continues to develop the steady state power, but the only load is the train inertia; consequently the speed rapidly increases. Included on the thrust end of the ammonia expander shaft is a pin type overspeed trip. As speed is increased a spring-opposed pin in the expander shaft extension is thrown outward by excessive speed until it hits a striker plate. The movement of the striker plate permits a pre-loaded cylinder to move and open oil ports which allow a small amount of bearing oil to dump into the bearing case drain. The loss of oil pressure in a small feed line is sensed by a pressure transducer, which signals the trip valve ahead of the expander to shut off the motive fluid and open the bypass valve. The mechanical trip speed setting is to be ten percent above the operating speed, or 1980 rpm. This expander will also be equipped with a manually operated trip so that it may be tripped at any speed simply by turning the trip handle. See Section 7 for additional overspeed protection devices.

INSTRUMENTATION

Mechanical Instrumentation

The expander will be provided with mechanical instrumentation to continuously monitor the performance of the mechanical components and indicate malfunctions.

The expander will be equipped with proximity type vibration probes and read-out devices to monitor shaft vibration. Two probes will be provided at each bearing, 90 degrees apart, for the measurement of the horizontal and vertical vibration components. If the need arises, these probes can also be connected to suitable equipment to determine the journal orbits.

A proximity probe will be provided for measuring the axial position of the expander to indicate possible thrust bearing failure.

A magnetic type speed pick-up will read interruptions from a 60 tooth gear. This device will provide a speed signal to the speed-load control system. It will also be used as an electronic overspeed trip to signal the trip valve ahead of the expander to shut off the motive fluid at three percent above the operating speed, or 1854 rpm.

Thermocouples, or RTD's, will be provided in journal and thrust bearings to monitor bearing metal temperature. Additionally, locally

mounted thermometers will be placed in the oil drains of the journal bearing, thrust bearing and seals for measurement of throw-off temperature. A higher than normal temperature reading may indicate impending bearing or seal failure.

Locally mounted pressure gages will be mounted in the inlet piping to monitor the lube oil pressure and seal oil pressure.

All of the above instrumentation has been extensively used and is accepted practice for rotating equipment in many industries.

Thermodynamic Instrumentation

Pressure measuring devices at the inlet and exhaust flanges will be used to monitor expander conditions. Position of the variable first row stator blades will be determined from an indicator mounted on the external linkage.

Pressure taps located just ahead of each stationary blade will be used during the initial evaluation. These interstage readings will not be used to determine the performance of the expander per se, but might be of assistance to the manufacturer if a question involving performance arises. Further study of the pressure taps to devise a method of purging the lines will be necessary due to the two phase conditions which will be encountered.

For the initial gas rate evaluation of the expander, three additional items pertaining to the motive fluid are required. Devices to measure quality at the inlet and exhaust flanges in conjunction with the pressure measurements, will provide state point data of the ammonia motive fluid. A flow measuring device of suitable accuracy is the third required item. To obtain the necessary accuracy the flow meter must be on the liquid side of the ammonia cycle just after the condenser. To have a valid expander flow value steps must be taken to insure that the expander bypass valve is closed, and that there are no other leakage paths between the flow meter and the expander inlet.

To complete the gas rate evaluation of the expander/generator system, a high quality calibrated wattmeter to measure generator power output is required. This meter should be retained for monitoring the long-term operation.

A list of the thermodynamic instrumentation required for initial evaluation and long-term operation is contained in Table 10 - 1. Table 10 - 2 is a detailed list of instrumentation for the components of the string.

Gas composition checks should be performed periodically to monitor contaminants and quality of the motive fluid. The gas composition of the motive fluid should be determined with sufficient accuracy for every gas rate evaluation test.

MATERIALS

The preliminary material selections for the major components of the ammonia expander are listed in Table 10 - 3. This listing varies from the usual materials of construction for the specified conditions due to their susceptibility to stress corrosion in the ammonia atmosphere.

For the rotating components the materials proposed are of the same composition as those usually employed for steam turbines. The conditions of heat treatment, however, are different. In conventional steam turbines these materials would be heat treated to a yield strength in the range of 80,000 - 100,000 psi. In this case, in order to improve resistance to stress corrosion cracking, the annealed condition will be used. In this condition, the yield strength will be approximately 30,000 - 50,000 psi, which is sufficient for the application. The problem of stress corrosion cracking of materials of construction in this environment requires further study. Revisions to present selections may be made as a result of such additional investigations.

CODES

The following is a listing of codes and standards applicable to the expander, generator and the lube system.

American National Standards Institute (ANSI)

- B1.1: Unified Screw Threads
- B2.1: Pipe Threads
- B16.5: Steel Pipe Flanges and Flanged Fittings
- B16.11: Forged Steel Fittings, Socket-Welding and Threaded
- B31.3: Petroleum Refinery Piping

American Petroleum Institute (API)

- API 605 Flanges
- API 612 Special Purpose Steam Turbines
- API 614 Lubrication and Seal Oil Systems
- API 617 Centrifugal Compressors

American Society of Mechanical Engineers (ASME)

Boiler and Pressure Vessel Code:

- Section VIII, Division 1, Unfired Pressure Vessels
- Section IX, Welding Qualifications

American Society for Testing and Materials (ASTM)

- A106 Specification for Seamless Carbon Steel Pipe for High Temperature Service
- A193 Specification for Alloy-Steel Bolting Materials for High-Temperature Service
- A194 Specification for Carbon and Alloy Steel Nuts for Bolts for High-Pressure and High-Temperature Service
- A266 Specification for Carbon Steel Drum Forgings

A307 Specification for Low-Carbon Steel Externally and Internally Threaded Standard Fasteners

E109 Dry Powder Magnetic Particle Inspection

E125 Reference Photographs for Magnetic Particle Testing of Ferrous Castings

E138 Wet Magnetic Particle Inspection

National Electrical Manufacturer's Association (NEMA)

SM-21 Turbines, Mechanical Drive Service Multi-Stage

MG-1 Motors and Gears

IS1.1 Enclosures for Industrial Controls and Systems

Tubular Exchange Manufacturer's Association, Inc. (TEMA C)

National Fire Protection Association (NFPA)

Bulletin No. 70: National Electrical Code, Article 500

"Hazardous Location"

SCALABILITY

The scalability of the expander/generator set is controlled by both machines. Since the intention is to use existing generator designs to the maximum extent possible without unduly penalizing the expander, the scalability emphasis will be on the expander,

Brown Boveri Corporation has indicated that they can provide a 4-pole synchronous generator up to 50 MVA. This means that with a 0.8 lagging power factor and 1.0 service factor that the maximum generator power is 40 MW or 53,600 horsepower. Consequently, one of these large

4-pole generators with electronic excitation and double ended shaft can be driven by duplicate ammonia expanders to the design set forth in this study. The maximum single train plant size using a 4-pole generator is, therefore, 30 MW(e) gross.

Four stage double flow ammonia expanders can be scaled from the 15 MW(e) gross units for this study to larger capacities. The first item to consider in scaling is that the use of a gear in the string adds an undesirable parasitic loss of 1-1/2 to 2 percent. To eliminate this loss all we have to do is scale the expanders to operate at a speed which matches a generator speed. Therefore, expanders have been scaled to operate at 1200 rpm and 900 rpm; see Table 10 - 4.

To optimize performance at 1200 rpm, the scaled unit will have to operate at the same velocity ratio as the 1800 rpm unit. Consequently, the scaled pitch diameter will have to be 1.5 times ($1800 \div 1200$) the 1800 rpm unit's pitch diameter. If we retain the same L/D ratio the new scaled base diameter will also be 1.5 times the 4-pole unit, or 46.5 (1.5 x 31) inches. Since pitch diameter and blade length have both increased by 50 percent, the 1200 rpm expander flow passing capacity will be 2.25 times (1.5 x 1.5) the 1800 rpm unit. Efficiency will be just slightly higher for the larger machine as shown in Figure 10 - 1. Plant capacity for the one 46.5 base diameter expander driving a 6-pole generator will be 33.75 MW (e) gross. Once again, if the generator is double ended, two 46.5 inch base diameter expanders can drive one

generator for a 67.5 MW(e) gross plant. At this time, it is important to note that the controls to balance two expanders will be somewhat more involved; the maximization of power feature will require particular attention.

In a similar fashion an expander could be scaled to operate at the 8-pole speed of 900 rpm. The capacity of this unit would be 4 times the 1800 rpm unit. Therefore, the plant capacity would be 60 MW(e) gross for the single body and 120 MW(e) gross if duplicate units are attached to each end of the generator shaft. It has been assumed that 8-pole generators are available for the required output.

This scaling necessarily limits the available output power, since it is done on the basis of synchronous running speed. If synchronous generator operation is required, the optimum scales of the 15 MW(e) gross design are the two previous designs discussed, the 33.75 MW(e) gross and the 60 MW(e) gross. For any other required power, lower efficiency will result. A direct scale of the 15 MW(e) gross design to any other power in the range of 25 MW(e) gross to 75 MW(e) gross will operate at nonsynchronous speed and a gear, along with its 2 percent power loss, would have to be employed. This gear loss is responsible for lower efficiencies at other than optimum scales.

The units in the range of 25 MW(e) gross to 75 MW(e) gross would be scaled on the basis of power output, with the speed being scaled

later. For a 25 MW(e) gross power output, the scaling factor would be $25 \div 15$, or 1.667. The pitch diameter and the base diameter would both be scaled by the square-root of 1.667, since the L/D ratios would be constant. This results in a base diameter of 40 inches. The speed would be scaled by the inverse of the square root of 1.667 in order to maintain the proper velocity ratio. This resulting speed is 1394 RPM. A 75 MW(e) gross power output unit would be scaled similarly, except the scale factor would be 5.00 ($75 \div 15$). The new base diameter would be 69.3 inches (31×2.236) and the new operating speed would be 805 RPM ($1800/2.236$).

Each scaled design of the 15 MW(e) gross unit will be the highest performing design for their own particular scaled speed. This does not necessarily mean that a scaled design running at a scaled, nonsynchronous speed cannot be out performed by another design running at a synchronous speed. It is possible for a nonscaled design running at a synchronous speed driving a synchronous generator to produce more power than a scaled design running at a nonsynchronous speed driving through a gear to a synchronous generator. The latter incurs a performance penalty from the gear, possibly lowering its output power below that of the former. If the generator can be run at a nonsynchronous speed for any reason, the scaled design running at a scaled speed will be the most efficient for any desired gross power output.

So far, this discussion of scalability has considered only the

thermodynamic aspects. Manufacturability must also be considered in the determination of maximum expander size. The 15 MW(e) gross output expander set forth in this study is approaching the limits of this manufacturer's plant capabilities. It is felt that any of these scaled units are within the worldwide state-of-the-art of manufacturability.

T A B L E 10 - 1

THEMODYNAMIC INSTRUMENTATION REQUIREMENTS

<u>ITEM</u>	<u>REQUIREMENT</u>	
	<u>INITIAL</u>	<u>LONG-TERM</u>
FLOW METER	YES	YES
INLET PRESSURE	YES	YES
INLET QUALITY	YES	YES
EXHAUST PRESSURE	YES	YES
INTERSTAGE PRESSURE AHEAD OF EACH STATOR	YES	NO
COMPOSITION	YES	YES

T A B L E 10 - 2

INSTRUMENTATION

<u>Area of Use or Type of Instrument</u>	<u>Recommended Quantity</u>	<u>Signal Type</u>
<u>Mechanical Instrumentation</u>		
Lube Oil Console Instrumentation		
1) Oil Reservoir Level Alarm Switch	1	Voltage
2) Differential Pressure Indicator Switch	1	Voltage
3) Temperature Switch	1	Voltage
4) Pressure Switch	7	Voltage
5) Differential Pressure Switch	4	Voltage
5) Temperature Indicator	9	Voltage
7) Pressure Indicator	6	Voltage
3) Differential Pressure Indicator	2	Voltage
Expander		
1) Overspeed Trip Pressure Transducer	1	Voltage
2) Magnetic Speed Pickup	1	Frequency
3) Bentley Vibration Probes	4	Voltage
4) Bentley Axial Position Probe	1	Voltage
5) Bearing Thermocouples or RTD's	6	Voltage

F-153

T A B L E 10 - 2 (cont.)

INSTRUMENTATION

<u>Area of Use or Type of Instrument</u>	<u>Recommended Quantity</u>	<u>Signal Type</u>
Generator		
1) Stator ETD's	6	Voltage
2) Bearing RTD's	2	Voltage
3) Cooling Air RTD's	3	Voltage
4) Cooling Water RTD's	1	Voltage
5) Cooling Water Leakage Detector	1	Voltage
6) Bentley Vibration Probes	4	Voltage
7) Watt Meter For Generator Load	1	Binary Coded Decimal
 <u>Thermodynamic Instrumentation</u>		
1) Inlet Pressure Transducers	4	Voltage
2) Exhaust Flange Pressure Transducers	4	Voltage
3) Interstage Pressure Transducers	12	Voltage
4) Liquid Ammonia Calibrated Venturi Tube		
a) Pressure Transducers	8	Voltage
b) Thermocouples	2	Voltage

F-154

T A B L E 10 - 3

MATERIALS OF CONSTRUCTION
FOR MAJOR COMPONENTS
OF AMMONIA EXPANDER

<u>PART</u>	<u>MATERIAL</u>	<u>FORM</u>	<u>MIN. YIELD - psi</u>
OUTER CASING BARREL	SA-516 GRADE 60	PLATE	32,000
ENDWALLS	SA-226 CLASS 1 SA-516 GR 60	FORGED PLATE	30,000 32,000
STATOR HOUSING	SA-216 GR WCB	CAST	36,000
DIAPHRAGMS	SA-516 GR 60	PLATE	32,000
STATOR BLADES	AISI TYPE 405	BAR	25,000
ROTOR BLADES	AISI TYPE 403 ANNEALED	BAR	35,000
DISCS	AISI 4140 ANNEALED	FORGED	50,000
SHAFT	AISI 4140 ANNEALED	FORGED	50,000

T A B L E 10 - 4


SCALED EXPANDERS

<u>GROSS OUTPUT MW(e)</u>	<u>SPEED RPM</u>	<u>BASE DIAMETER INCHES</u>	<u>RELATIVE THRUPUT</u>
15	1800	31.0	1.0
33.75	1200	46.5	2.25*
60	900	62.0	4.0 *
25	1394	40.0	1.667*
75	805	69.3	5.0 *

*Assumes synchronous generators are available at these speeds for the required output with the same efficiency as the 15 MW(e) gross unit.

FIGURE 10-1

TRW-OTEC SCALABILITY STUDY, FOUR STAGE
DOUBLE FLOW DESIGNS
REAL BLADES



ATTACHMENT 1

REFERENCES

1. Ainley, D.C. and Mathieson, G.C.R., "A Method of Performance Estimation for Axial-Flow Turbines", British Aeronautical Research Council, R & M 2974, 1951.
2. Dunham, J. and Came, P.M., "Improvements to the Ainley-Mathieson Method of Turbine Performance Prediction", ASME Paper 70-GT-2, 1970.
3. Craig, H.R.M and Cox, H.J.A., "Performance Estimation of Axial Flow Turbines", Proceedings of The Institution of Mechanical Engineers, 1970 - 71.
4. Silver, H.F. and Nydahl, J.E., Introduction to Engineering Thermodynamics, West Publishing Company, 1977.
5. Reisweber, R.C., "Supercharger Diffuser Development", Elliott Company, TM 272, 1965.
6. Hench, J.E. and Johnston, J.P., "Two-Dimensional Diffuser Performance with Subsonic, Two-Phase, Air-Water Flow, ASME Paper 71-FE-30, 1971.
7. Shepherd, D.G., Principles of Turbomachinery, The Macmillan Company, 1956.
8. More, M.J. and Sieverding, C.H., Two-Phase Steam Flow in Turbines and Separators, Hemisphere Publishing Corporation, Washington, 1976.

9. Handbook of Chemistry and Physics, 45th Edition, 1964 - 65.
10. Claydon, J.E., "Moisture Erosion", Elliott Company Letter, April 14, 1975.
11. Sawyer's Gas Turbine Engineering Handbook, Second Edition, 1972.
12. Liquid Rocket Engine Turbines, NASA - SP-8110, January, 1974.

ATTACHMENT 2

NOMENCLATURE

SYMBOLS

C_o	Isentropic velocity, $C_o = 223.77 \sqrt{\Delta H_o}$ (ft./sec.)
C	Absolute velocity (ft./sec.)
L/D	Ratio of blade height to mean blade path diameter
N	Shaft speed (rpm)
P	Pressure (psia)
T	Temperature ($^{\circ}F$)
U	Mean blade speed (ft./sec.)
U/C_o	Velocity ratio
V	Specific volume (ft. ³ /lbm.)
W	Relative velocity (ft./sec.)
α	Fluid absolute angle measured from tangential plane, at stator exit
β	Fluid relative angle measured from tangential plane, at rotor inlet
β_3	Fluid relative angle measured from tangential plane, at rotor inlet
ΔH_o	Isentropic heat drop (BTU/lbm.)

SUBSCRIPTS

IN	At expander inlet
EX	At expander exhaust
1	At stator exit or rotor inlet
2	At rotor exit

DEFINITIONS

Axial Width ---- The axial width is the maximum width of the blade in the axial direction at the specified section as shown in Figure B-1.

Base Diameter -- The base diameter of a blade is the minimum diameter of the blade where the blade joins the hub as shown in Figure B-2.

Free-Vortex ---- Free-vortex flow is flow with a specified variation in the absolute tangential velocity within the blade path with diameter such that radial inflow equilibrium is maintained. For this type of flow the axial velocity is constant across the entire blade path while the tangential velocity decreases linearly with diameter. Therefore, as the diameter increases across the blade row the stage reaction constantly increases.

- Gauging Angle** -- The blade gauging angle is defined as the design blade fluid exit angle, and is calculated as the arcsine of the blade throat divided by blade pitch distance. See Figure B-1 for a pictorial representation of the gauging angle.
- Mean Diameter** -- The diameter of the blade suction half way between (average) the blade base and tip suctions.
- Normalized Efficiency** ---- Normalized efficiency is defined as being the calculated efficiency divided by the efficiency of a four stage, 31 inch base diameter design with similar blading.
- Pitch** ----- The distance between similar points on adjacent blades in the circumferential direction as shown in Figure B-1.
- Stage Reaction** - The ratio of energy transfer in the rotor resulting from a static pressure change to the total energy transfer in the stage.
- Throat** ----- The minimum flow area between adjacent blades as shown in Figure B-1.
- Tip Diameter** --- The tip diameter is the highest or last blade section as shown in Figure B-2.


Velocity Ratio - The velocity ratio for a single stage configuration
(12)

is $\frac{U}{C_0} = \frac{\text{pitchline velocity}}{\text{theoretical spouting velocity}}$; however,
for a multistage turbine design, the numerator of
the velocity-ratio term represents the square root
of the sum of the squares of the pitchline velocities
of each stage. Therefore, the precise expression for
velocity ratio for either a single stage or multi-
stage turbine is $\sqrt{\sum U^2}/C_0$. However, the velocity
ratio will be consistently expressed as U/C_0 , it
being understood that for a multistage turbine

$$U = \sqrt{\sum U^2}.$$

FIGURE B-1


BLADE TERMINOLOGY



$$\text{GAUGING ANGLE} = \text{ARCSIN} \left(\frac{\text{THROAT}}{\text{PITCH}} \right)$$

FIGURE B-2

TURBINE STAGE DIAMETERS



APPENDIX G
TUBE CLEANER DESIGN

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX G.1
HYDRAULIC TUBE CLEANER ANALYSIS

G.1. HYDRAULIC TUBE CLEANER ANALYSIS

SCOPE

This analysis investigates the design parameters of the hydraulic tube cleaner. The analysis was required for the preliminary design. The following parameters were studied:


- Tube dimensions
- Water volume and weight
- Piston size
- Flow area
- Pump head
- Required power
- Flow rate
- Bouyancy
- Slippage flow rate

PREPARED C Williamson 4/2/78 REPORT NO.

CHECKED _____

MODEL _____

Hydraulic Tube Cleaner



PREPARED C. Williamson 5/30/78

REPORT NO.

CHECKED _____

Hydraulic Tube cleaning
concept

MODEL _____

Tube Dimensions

- 1.00" OD BASIC X 0.031 wall (E) X 0.026" wall (C)
- 0.990 " Finished
- 0.866 ID "
- 0.037 inner mill depth
- 0.883 Equiv H₂O dia. ; $A_e = \frac{\pi (0.883)^2}{4} = 0.6124 \text{ IN}^2$
- 36 Flutes

Volume of H₂O in a single tube

$$V_t = \frac{\pi}{4} (0.883)^2 (30') (12) = 220 \text{ IN}^3$$

$$= 0.1276 \text{ FT}^3$$

$$= 0.9543 \text{ gal}$$


size Piston (Pig behind brush)

Assume 1/64 diametral clearance

$$D_p = 0.866 - 0.016 = 0.850$$

$$A_p = \frac{\pi}{4} (0.850)^2 = 0.567 \text{ IN}^2$$

Inner Mill Area

Estimated as trapezoid of 

$$A = \frac{1}{2} h (a+b) \cdot 36 = \frac{1}{2} (0.037) (0.04 + 0.012) (36)$$

$$= 0.0346 \text{ IN}^2 \text{ (Approx)}$$

Total Flow Area/tube

$$A_T = 0.567 + 0.0346 = 0.602 \text{ IN}^2$$

(should be 0.6124 IN²)

Pump Head to Drive Brush (w/ 60% margin)

Assume brush drag \approx 5 lbs (use 8 lbs)

$$p = F/A = \frac{8}{0.567} = 14.1 \text{ psid}$$

$$= \frac{14.1 \text{ PSI}}{0.433 \frac{\text{PSI}}{\text{ft H}_2\text{O}}} = \underline{\underline{32.58 \text{ ft of H}_2\text{O}}}$$

CHECKED _____

Hydraulic cleaner

MODEL _____

Wt of H₂O / 100 tubes

$$W = (100) (0.1276) (62.4) = 796 \text{ lbs}$$

$N \quad \text{ft}^3$

Pump Horsepower (w/o slippage past pig)

Assume 20 sec stroke time (one way) ($V \approx 1.5 \text{ fps}$)

$$w = \frac{796 (60)}{20} = 2388 \text{ lbs H}_2\text{O/min}$$

$$W \text{ HP} = \frac{w h}{33,000} = \frac{2388 (32.58)}{33,000} = \underline{\underline{2.35 \text{ HP}}}$$

Find Slippage Flow Rate

$$A_s = 0.0346 + \frac{1}{128} \pi \left[\frac{0.866 + 0.850}{2} \right] \quad (0.858)$$

(p.i.)

$$" + 0.0211 = \underline{\underline{0.0556 \text{ in}^2}}$$

$$Q = c A \sqrt{2gh}$$

$$c \approx 0.6 ; h = 32.58 ; A = \frac{0.0556}{144} = 3.86 \times 10^{-4}$$

$$= 0.6 (3.86 \times 10^{-4}) \sqrt{2 (32.2) (32.58)}$$

$$= 0.0106 \text{ ft}^3/\text{sec} \times 62.4 \times 60 = \underline{\underline{39.72}} \frac{\text{lb H}_2\text{O}}{\text{min}}$$

$(\frac{\text{ft}^3}{\text{sec}}) \quad (\frac{\text{sec}}{\text{min}})$

tube

Slippage HP Loss

$$W_s \text{ HP} = \frac{(39.72 \times 100) (32.58)}{33,000} = \underline{\underline{3.92 \text{ HP}}}$$

Total HP

$$W \text{ HP}_T = 3.92 + 2.35 = \underline{\underline{\underline{6.27 \text{ HP}}}}$$

Hydraulic cleaner

Basic Flow Rate in Tubes

$$v = c_v \sqrt{2gh} \quad \text{where: } c_v \approx 0.6$$

$$h = 8 \text{ ft H}_2\text{O}$$

$$v = \text{fps}$$

$$= 0.6 \sqrt{2(32.2)(8)} = \underline{13.62 \text{ fps}}$$

$$Q = AV \quad A = 0.6124 \text{ in}^2$$

$$= 0.0043 \text{ ft}^2$$

$$= (0.0043)(13.62) = 0.0579 \text{ ft}^3/\text{sec}$$

$$= 3.47 \text{ ft}^3/\text{min}$$

$$\approx 217 \text{ lb/min}$$

$$= 3.61 \text{ lb/sec}$$

Flow Rate per tube w/brush

$$v_b = c_v \sqrt{2g h_e} \quad c_v \approx 0.6$$

$h_e = \text{pump head} - \text{head loss due to brush force}$

$$= 32.58 - \frac{5 \text{ lbs}}{0.567 \text{ in}^2} \times \frac{1 \text{ ft}}{0.433 \frac{\text{lb}}{\text{in}^2}}$$

?

$$= \dots - 20.36 = 12.21 \text{ ft H}_2\text{O}$$

$$v_b = 0.6 \sqrt{2g(20.36)} = \underline{21.73 \text{ fps}}$$

$$Q = AV_b = \frac{0.6124}{144} (21.73) = 0.092 \frac{\text{ft}^3}{\text{sec}}$$

$$= 5.54 \text{ ft}^3/\text{min}$$

$$= 346 \text{ lb/min}$$

$$= \underline{5.76 \text{ lb/sec}}$$

Potential Buoyancy per in of Hollow pig length

PIG O.D = 0.850
Assume 0.032 wall

$d_i = 0.7860$ $A_i = 0.4852 \text{ in}^2$

$H_2O = 62.4 \frac{\text{lb}}{\text{ft}^3} = 0.0361 \frac{\text{lb}}{\text{in}^3}$

$\text{Buoyancy} = (0.4852)(0.0361) = 0.0175 \frac{\text{lb}}{\text{in}}$
(Negligible)

CASE # 2

Find Slippage Flow Rate in smooth part of tube

Tube OD = 1.000 1.000
Wall = $0.31 \times 2 = 0.062$
0.938 ID

Flow Area = $\frac{\pi}{4} [0.938^2] - 0.567$ (From p. 1)
 $= 0.1240 \text{ in}^2 = 8.6 \times 10^{-4} \text{ ft}^2$

$Q_s = C_v A \sqrt{2gh}$
 $= 0.6 (8.6 \times 10^{-4}) \sqrt{2(32.58)}$
 $= 0.0236 \text{ ft}^3/\text{sec}$
 $= 1.47 \frac{\text{lb}}{\text{sec}} = 88 \text{ lb/min/tube}$
 $= 8800 \text{ lb/min for 100 tubes}$

Find Head Developed in smooth section

Assume constant flow pump @ 2388 + 3972 lb/min

$Q_s = C_v A \sqrt{2gh}$ $= 6360 \text{ lb/min}$
 $= 1.699 \text{ ft}^3/\text{sec}$

$h = \frac{1}{2g} \left[\frac{Q}{C_v A_s} \right]^2$

$A_s = 8.6 \times 10^{-4} (10)$
 $= 8.6 \times 10^{-3} \text{ ft}^2 / 100 \text{ tubes}$

$= \frac{1}{64.4} \left[\frac{1.699 \times 10^2}{(0.6)(8.6)} \right]^2$
 $= 16.84 \text{ ft of } H_2O$

Globe proposes a "Net Fit" brush serrated to match the convolutes. Brush lengths of from 18" to 2' Long are proposed by Globe and brush force of 5 lbs is their estimated drag.

with such brush lengths, it is expected that the slippage flow will be a small fraction of the 3972 lbs/min estimated on p. 2. Therefore, the force delivered to the brush due to the pump head of 32 1/2 ft will approach the effective H₂O flow area (0.883" dia)

$$F \approx (14.1)(0.883)^2 \frac{\pi}{4} = 8.63 \text{ lbs}$$

Hydraulic Tube Cleaner




Figure 8

JIC Symbols

CHECKED _____

HYDRAULIC CLEANER

MODEL _____

VOL OF WATER IN 102 TUBES - 20 SEC

VOL. WATER PER TUBE = 0.9543 GAL (PER WILLIAMSON)
PER 102 TUBES = 97.34 GAL.

FOR 20 SEC. STROKE PUMP FLOW RATE JUST TO FILL TUBES = $3 \times 97.34 \text{ GAL} = 292 \text{ GPM}$

PER WILLIAMSON ASSUME SLIPPAGE FLOW RATE IS ONLY FRACTION OF TUBE VOL. SAY 25%

THEN PUMP CAPACITY = $292 \text{ GPM} + \frac{292 \text{ GPM}}{4} = 365 \text{ GPM}$
@ 14

VOL WATER IN 70 TUBES (REMOVE 32 PERIMETER TUBES)

= $0.9543 \times 70 = 66.801 \text{ GAL}$

FOR 30 SEC. STROKE PUMP FLOW TO FILL TUBES
= $66.801 \text{ GAL} \times 2 = 133.602 \text{ GPM}$

ASSUMING SOME SLIPPAGE WILL OCCUR (SAY 10%)

SIZE PUMP TO 150 GPM @ 25 PSI MAX OUTPUT PRESS.

PUMP CAPACITY REQ'D FOR 30 SEC. BRUSH STROKE 102 TUBES

$97.34 \text{ GAL} / 30 \text{ sec} = 194.68 \text{ GPM}$ ASSUMING 25% SLIP FLOW

TOTAL FLOW RATE REQ'D = $195 + \frac{195}{4} = 244 \text{ GPM}$

OUTPUT PRESS = 50 PSI (EST.)

SAY 250 GPM

APPENDIX G.2

OTHER DESIGN CONSIDERATIONS WITH RESPECT TO THE HYDRAULIC TUBE CLEANER

G.2. OTHER DESIGN CONSIDERATIONS WITH RESPECT TO THE HYDRAULIC TUBE CLEANER

SCOPE

Discussions pertaining to the design of the mechanical latch, magnetic latch, passive ultrasonic transducer, active ultrasonic transponder, and nuclear detector device are presented herein. All these discussions consider some device to indicate the bottom of the stroke for the hydraulic tube cleaner.

MECHANICAL LATCH

The mechanical latching system is illustrated in Figure 1. The brush has two pigs located at each end with protruding springs, and one pig in the middle of the brush to contain a latching mechanism. As shown in Figure 1 the two springs are connected with a string which runs in a small tube along with other wires that hold the bristles of the brush. The string is wound around a drum on the latching mechanism (shown as a permanent magnet) in the middle pig.


At the top of the stroke the top spring protrudes from the tube, expands, pulls on the string, and cocks the latch in one position. At the bottom the other spring recocks the latch. The latch itself could be a permanent magnet as shown in Figure 1 whose position could be detected by a simple electronic circuit.

Note that there is no way that the latch could be cocked or recocked during transit unless one end of the brush actually protrudes outside the tube.

Advantages/Disadvantages:

In principle this is a very simple mechanical device which should be 100 percent reliable. However, it may not be as easy to design and build as it appears. For example assembly and sealing of the device would present some challenging problems.

FIG 1 MECHANICAL LATCH




MAGNETIC LATCH

This system contains magnetic latches incorporated in each brush as illustrated in Figure 2. The magnetic latches are set prior to starting the downstroke by an electric magnet and reset by permanent magnets located at the bottom of the tubes. Monitoring the current through the electric magnet during the "set" operation it will be possible to determine whether the magnet has been properly reset by the permanent magnets at the bottom of the stroke.

Disadvantage: Each tube would require a permanent magnet installed at the bottom. Although these magnets could be very cheap (~5¢ each) they would require extensive testing to insure that they last the lifetime of the system. In addition, if some of the magnets failed for some reason, it would be difficult, if not impossible to repair them in situ.

FIG 2 MAGNETIC LATCH



G-18


PASSIVE ULTRASONIC TRANSDUCER

This system incorporates passive ultrasonic transponders in the brushes as shown in Figure 3. The transponders are connected to receiver/transmitter antennas which protrude from the bottom of the brushes. The transponders, in form of a metallic dumbbell act like tuning forks when excited by exterior ultrasonic waves. Each brush has a transponder that responds to a different frequency. When the brushes are at the bottom of a stroke with their antennas protruding below the bottom tube sheet an external ultrasonic transducer transmits signals of the appropriate frequencies, and then listens for a return. Thus it would be possible to check that all the brushes have reached the bottom of the stroke.


Advantages: Very simple, inexpensive and possibly perfectly reliable system.

Disadvantages: Would require extensive testing after installation to insure that harmonics and resonances do not give false signals.

FIG 3. ULTRASONIC - PASSIVE



SIGNAL



$$f = \frac{1}{2\pi} \sqrt{\frac{k}{m}}$$

ACTIVE ULTRASONIC TRANSPOWER



This device illustrated in Figure 4 consists of an active ultrasonic transmitter and receiver incorporated in each brush. At the start of the cycle the transmitter in each brush is charged up by a magnetic coupling arrangement as illustrated in lower left hand corner of Figure 4. When the brush reaches the bottom of the stroke, the brush stops are arranged so that the transmit/receive antennas protrude through the lower tube sheet. An external ultrasonic transducer located in the chamber below the heat exchanger interrogation could be done by coding each of the brushes with a different signature which the ultrasonic transponders in the brushes recognize and answer to. For example: the external transducer would send out the code for brush #1, receive an answer, the brush #2, etc.

Advantages: The active ultrasonic transponder appears to be the best system for detecting the brushes of all the approaches considered here. The main advantages are that this system should be very reliable and require very little testing or adjustment after installation.

Disadvantages: Some development effort would be required to design the ultrasonic transducers as well as the transducer interrogating system.

ACTIVE ULTRASONIC TRANSPONDER


FIG 4



G=22

POWER SUPPLY

EXTERNAL COIL



NUCLEAR DETECTOR DEVICE


This scheme, shown in Figure 5 uses an ionization chamber located in a pig attached to the brush and radioisotope sources (such as cobalt-60 or cesium -137) located at the bottom of the tubes. At the start of the stroke the ionization chamber is charged up by external means. When the brush reaches the bottom of the tube the ionization chamber is discharged by the radiation from the radioisotope sources. After the brush is returned back to the brush holder the status of the ionization chamber is interrogated via a magnetic coupling device as illustrated in Figure 5a.

Since the ionization chamber can be discharged only by penetrating nuclear radiation there is virtually no chance that it could discharge before reaching the radioisotope sources at the bottom of the tubes. A very intense cosmic ray shower could have some effect, however, it would be possible to design the system in such a way that the probability of the ionization chamber discharge by cosmic rays would be extremely small.

Advantages: The nuclear detector device should be inexpensive and simple to build. Also it should be very reliable and operate for a long time without maintenance.

Disadvantages. Use of radioisotope sources always presents a practical problem of red tape, safety analyses, etc. Although there should be no real hazard from these radioisotopes, public's lack of understanding of nuclear radiation and sometimes irrational reluctance to accept it makes it difficult to implement nuclear systems in practice.

NUCLEAR DETECTOR FIG 5.



- TOP POSITION - IONISATION CHAMBER IS CHARGED BY EXTERNAL MEANS
- BOTTOM - IONISATION CHAMBER IS DISCHARGED BY RADIATION COMING FROM RADIOISOTOPE SOURCES LOCATED AT THE BOTTOM OF THE TUBES

MAGNETIC COUPLING FIG 5a


SECONDARY
TRANS-
FORMER
WINDING

Power in

PRIMARY TRANSFORMER
WINDING

ELECTRONICS

TUBE



THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX G.3

**MAINTENANCE AND OPERATING PLAN INPUTS FOR THE
10 MWe AND THE 0.2 MWe TUBE CLEANERS**

INTEROFFICE CORRESPONDENCE

PSD-I-463
78.6853.6-011

TO: S. Vincent

CC: A.H. Hausrath
W.G. Hample
R. Williams
R. Pearson

DATE: 9 August 1978

SUBJECT: Maintenance and Operating Plan Inputs for
the 10 MWe and the 0.2 MWe Tube CleanersFROM: C. Williamson *C*
BLDG. MAIL STA. EXT.
81 1513 62635

- Reference:
1. CP-SS14-45 Prime Item Development Specification for PSD-1 Heat Exchanger Biofouling Control Subsystem Tube Cleaner
 2. CP-EQ2-556 Critical Item Product Function Specification for the 10 MWe HX Tube Cleaner Positioner
 3. CP-EQ2-557 Critical Item Product Function Specification for the 10 MWe HX Tube Cleaner Cleaner Head
 4. CP-EQ2-556 Critical Item Product Function Specification for the 10 MWe HX Tube Cleaner Controller/Recorder
 5. CP-EQ2-561 0.2 MWe HX Tube Cleaner
- a) 10MWe HX Tube Cleaner (References 1 thru 4)
- 1) Operation - The 10 MWe HX tube cleaner has been configured to operate automatically according to the functional flow (Figure 1) and the time line shown in Figure 2 except as noted in Figure 1 and summarized below
 - a) Move cleaning head to a selected HX under manual control. For the 40 MWe system, interconnecting rails are envisioned. For the 10 MWe system, this movement requires an on-board crane or hoist to position the cleaner to its support pads on the HX. This will require two persons minimum; one to operate the hoist and others to engage the pad locking pins.
 - b) Position the cleaning head at the start point (under manual controls). This is accomplished by commanding the positioner to seek a specific X-Y position and verifying this location from position indicator readouts. At this point the automatic controls are commanded to take over but the operator will stand by for several cycles to insure proper performance.

- c) If an incomplete brush retraction is sensed, the controller shuts down the machine and signals for corrective action. When a crew member is available, he will execute corrective action by proceeding as follows:
- Override the controls to command the brushes to down stroke again in the same position and re-attempt retraction.
 - If complete retraction is still not indicated, repeat above at higher (TBD) air pressure in increments of (TBD) up to a maximum of (TBD) pressure.
 - If complete retraction is still indicated, the retraction sensor is suspect and maintenance shall be scheduled.

It should be noted that the same procedure shall be followed if locating pin disengagement is not sensed.

- 2) Maintenance - Reference 1 specifies that the level of repairability shall be such that the vessel maintenance crew can execute maintenance and repairs using multipurpose (tools) and test equipment. Two levels of maintenance are specified. They are:
- a) Servicing/maintaining the cleaner in its normal operating position, ie, lubrication, minor adjustments, brush replacement, inspection for degradation, etc.
 - b) On-deck major maintenance - This entails transporting the cleaner to a open deck service area for dis-assembly and repairs. To provide access to all parts of the cleaning head, it shall be de-erected to the horizontal position and supported at working level for convenience of repair. Major maintenance shall consist of parts/subassembly replacement/repairs, removal and reapplication of protective coating, reassembly and re installation onto a heat exchanger.
 - c) Controller servicing/maintenance - The controller/recorder shall be housed inside of a ship bay or compartment immediately adjacent to the heat exchangers to permit line of sight to the tube cleaner. It will not be exposed to the environment such as is the rest of the cleaner subsystem.

Maintenance will require an electrician versed in the operation of the unit and will be performed on location.

b) 0.2 MWe HX Tube Cleaner. (Reference 5)


- 1) Operation - This unit requires an operator to position the cleaning head into preselected positions for cleaning. Positioning shall be done manually by turning lead screw wheels to pre-identified position in the X and Y matrix. Note in Figure 3 that there are eight discrete X-X positions and 28 Y-Y positions (max). A single operator can set the X-X position, then move to the cleaning head and position it in Y-Y and execute the multiple brush stroking up to 28 times before repositioning in the X-X direction.

The brushes shall be driven pneumatically by the operator operating valves. He will be required to monitor the seven lights signalling completion of the down stroke and seven lights signalling completion of the up stroke.

- 2) Maintenance - The maintenance of the 0.2 MWe HX Tube Cleaner is as described in A-2-a & b above.

Note: Further details of operation and maintenance will depend on the selected designs as developed by the subcontractor. This document can provide an over view only and will be expanded for the proposal after selection of a subcontractor. The final O&M plan has been identified as a deliverable from the subcontractor.

CW:dp



PSD-1 BIOFOULING CONTROL SUBSYSTEM TUBE CLEANER FUNCTIONAL FLOW

Figure 1 PSD-1 Biofouling Control Subsystem Tube Cleaner Functional Flow

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX G.4
TUBE CLEANER MEASUREMENTS AND CONTROLS

INTEROFFICE CORRESPONDENCE

78.6853.6-007

TO: R. Williams

CC: S. Vincent
W. Hample
A. Hausrath
M. Nee

DATE: 26 July 1978

SUBJECT: Tube Cleaner Measurements & Controls

FROM: C.E. Williamson *ls*
BLDG. 81 MAIL STA. 1513 EXT. 62635

The tube cleaner subsystem is defined by specs CP-SS14-45, CP EQ2-556, 557 & 558. *(Attached) A projected operating time line (Figure 1) and a functional flow (Figure 2) is attached. The subsystem has been designed to normally operate closed loop complete with data recorder. The primary data to be recorded is the location of tubes which are not accepting the cleaning devices (brushes) to their full stroke and groups of tubes that are skipped by the cleaner. Note that the memory disks will be blanked to negate recording of no-brush-motion where there are no tubes. Following any tube plugging operation, a new disk blank will be required to also negate newly blocked tubes from the record.

Sensors

Within this subsystem, there are sensors to measure the following:

- 1) Engagement of the cleaning head with the guide pins in the tube sheet. (one sensor)
- 2) Completion of the down stroke (95 sensors)
- 3) Completion of the up stroke (95 sensors)
- 4) Redundant encoders on the X, Y, and Z axes of the positioner

The output from sensor (1) above signals the controller to proceed with stroking the brushes. If a no-go signal is received, the controller directs the cleaning head to retract and return the positioner to the nearest X-Y matrix sensor to verify encoder position information. If on the next attempt a no-go signal is received, the positioner moves to the next location (n+1). If engagement is made, cleaning proceeds and the failure to clean position (n) is recorded. If a no-go signal is received at position (n+1) the system will command shut down and signal for corrective action. The output from sensor (2) is recorded but does not interrupt the cleaning sequence. The output from sensors (3) permits the cleaning to proceed. Encoders (4) position the cleaning head responding to the programmed controller output. If on the second try a no-go is received, shut down/corrective action signal is issued.

From the above, it can be seen that only two types of data are recorded:

26 July 1978

- 1) Failure to position for cleaning an entire group of tubes (95 tubes) and their location in the matrix.
- 2) Incomplete down stroke of any brush; its group location in the matrix and its position in the group of 95 tubes.

The use of this data is a subject for the system engineers to address but it is our intent that its to be used by the plant operator to plan/execute maintenance/repair activity.

Controls

The cleaning sequence for a heat exchanger shall be initiated manually by shipboard personnel at a control console. Signals for corrective action will also require attention (not necessarily immediate except in an emergency situation) from ship personnel.

We donot envision the need for a dedicated operator for this subsystem. Also note that the timeline permits completion of cleaning of a single heat exchanger in a 12 hour shift.

Transfer

It is proposed to use a single cleaner for the 10 MWe system for cleaning both the evaporator and the condenser. This will require transfer from one to the other approximately once per week (two transfers per week). It is assumed that this can be accomplished by the regular maintenance crew. Note that a crane will be required for this operation.

For the 40MWe system, two cleaners are envisioned; each dedicated to one side of the ship.

CEW:dp

*Attachments only for R. Williams

TUBE CLEANER TIMELINE





Figure 1



A- MANUAL

B- SIGNAL FOR MANUAL
CORRECTIVE ACTION

Figure 2. PSD-1 Biofouling Control Subsystem, Tube Cleaner Functional Flow

APPENDIX H
AMMONIA LEAK DETECTION

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

APPENDIX H.1
OTEC AMMONIA LEAK DETECTION SYSTEM

TRW

DEFENSE AND SPACE SYSTEMS GROUP

ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278


INTEROFFICE CORRESPONDENCE

TO: Paul Edris

CC:


4341.AC.78-174
DATE: 8 September 1978

SUBJECT: OTEC Ammonia Leak Detection System

FROM:  J. S. Shapiro/ J. Wilson
BLDG. 01 MAIL STA. 2030 EXT. 62451

Attached is our Final Report and Proposal Input regarding the Ammonia Leak Detection System. We feel this report should meet your program requirements quite well and was performed according to our recent PWA. The report is on schedule and the budget was adhered to.

Approved


L. E. Ryan, Section Head
Analytical Chemistry

B. DUBROW
W. CHEW
P. FUKUNAGA
G. GIBSON
A. GRANT
R. JONES
L. KENT
D. REEVES
S. VINCENT

CONTENT

	<u>Pages</u>
1. INTRODUCTION.....	H-6
2. THE SELECTED AMMONIA DETECTION SYSTEM.....	H-7
3. OTHER DETECTION SYSTEMS INVESTIGATED BUT ASSESSED AS UNSATISFACTORY	H-9
4. SAMPLING SYSTEM	H-12
5. SUMMARY.....	H-33
ATTACHMENT 1.....	H-35
ATTACHMENT 2.....	H-36

1. INTRODUCTION

Ammonia is the working fluid in the OTEC PSD-1 module. Because the heat exchangers are submerged and sea water flows through them, any leaks in the tubes or tubesheets or interfaces will release ammonia into sea water. A twofold study has been conducted to determine the best means of detecting ammonia leaks.

The first problem is that of monitoring the heat exchanger discharge streams to determine whether any leak exists. This requires ammonia detection in the 0.1 ppm range, based on an allowable leak rate of 40 pounds/hour NH_3 from the condenser which has 2.5×10^8 pounds/hour water flowing through it. The allowable leak from the evaporator is 50 pounds/hour ammonia. If total mixing between the leaking ammonia and effluent water occurs, the result is a solution 0.16 ppm in ammonia. Because the configuration of the lower water shroud has not been established at this time, calculations have been based on maximum dilution. Technicon Monitor IV equipment can detect ammonia levels as low as 0.01 ppm in sea water; consequently either this instrument or an equivalent one will be used in this application.

The second problem is that of locating the tube or joint that leaks so that repair measures can be instituted. Leak location will be accomplished using the tube cleaning equipment in a modified version for sample collection. Effluents from each bank of 95 tubes will be analyzed as a composite; high ammonia results for any composite will be a signal to search for leaks in that tube bank. The Technicon Monitor IV to be used in this application will be modified to accept new samples every two minutes, which is the cycle time of the tube cleaning equipment.

Once a leaking composite is located, the effluents from individual tubes can be analyzed. The task of feasibly locating individual tube leaks requires complicated and costly valving and TRW recommends the adoption of a simplified system which can narrow the leak to a 19 tube composite. Figure 4.3 in Section 4.1.3 is a schematic of both such systems; the only difference is the number of valves and lines entering the reservoir without previous manifolding.

2. THE SELECTED AMMONIA DETECTION SYSTEM

2.1 THEORY

The specific method for ammonia detection is the Berthelot Reaction, which is in accordance with the procedure for automated analysis in "Methods for Chemical Analysis of Water and Wastes," published by the Water Quality Office of the EPA (Appendix 1, No. 1). In this method samples are treated with alkaline hypochlorite and phenol in the presence of sodium nitroprusside, $\text{Na}_2\text{Fe}(\text{CN})_5(\text{NO})$. A solution of potassium sodium tartrate and sodium citrate is added to the sample stream to eliminate the precipitation of the hydroxides of calcium and magnesium; the tartrate and citrate ion are good complexing agents. A blue indophenol dye is produced from the ammonia and is measured spectrophotometrically. Both the sensitivity and specificity of the method are well documented. (Appendix 1, No. 2)

2.2 CHOICE OF EQUIPMENT

The Technicon Monitor IV, or a similar type of unit, is the instrument of choice to monitor the level of ammonia in sea water. The Technicon equipment is attractive for the following reasons:

- The company's extensive experience in automated analysis.
- On-the-shelf availability of system sensitive to NH_3 in sea water at 0.01 ppm level.
- Satisfaction of current users of Technicon equipment.

The Monitor IV unit uses the principles of continuous flow analysis developed by Technicon. The delivery of reagents, air and sample is accomplished by a peristaltic pump. The sample stream is continuously drawn into the system. Chemical reactions are performed on the manifold where such functions as mixing, heating, and, when necessary, dilutions, are accomplished. Ultimately, the colored reaction product is measured with a colorimeter.

The analytical system is very flexible and can easily be modified in the field to accommodate a wide ammonia concentration range. Ambient

ammonia concentration in sea water will vary with location, season, temperature, and depth, but 0.03 ppm is a probable maximum (Appendix 1, No. 3). Ammonia levels in each heat exchanger's inlet water will be monitored as a reference and subtracted from effluent readings.

2.2.1 Vendor Qualifications

Technicon provides a one-week training course for operators of their equipment and has a worldwide network of service and support facilities. In addition, we have spoken to numerous laboratories who use their equipment for analyses of sea water and have excellent results. These laboratories included the Public Health Department for the State of California, Scripps Institute of Oceanography and the National Marine Fisheries Service.

2.3 ESTIMATION OF DETECTABLE LEAKS

At the allowable leak rate of 40 pounds/hour of ammonia from the condenser, the effluent will contain 0.16 ppm of ammonia if complete mixing takes place. The Technicon Monitor IV is sensitive to a change of .01 ppm NH_3 , which represents about a 6% change in the ammonia leak rate. If a new leak is in a single location, its 95-tube composite will contain about 3 ppm of ammonia. The evaporator has a tolerable maximum leak of 50 pounds/hour of ammonia; hence its detection limit is slightly better than that of the condenser.

Because analysis of the 95-tube composites can detect leaks at a much lower level than analysis of the bulk effluent, periodic composite analyses may be useful in preventive maintenance even when bulk effluent ammonia levels are satisfactory. For example, a 0.4 pound/hour leak in a single tube, which represents 1% of the allowable condenser leak rate but which is too small to be seen in the bulk effluent, would produce an easily detected 0.6 ppm ammonia change in the 95-tube composite.

The process of using a vacuum for sample transfer was evaluated. The solubility of ammonia in water is so high that, until the ammonia level approaches several thousand ppm, the vacuum level of 2 psig required for sampling will not change the ammonia concentration in the system.

3. OTHER DETECTION SYSTEMS INVESTIGATED BUT ASSESSED AS UNSATISFACTORY

3.1 AMMONIA SPECIFIC ION ELECTRODE

Initially the ion selective electrode (ISE) for ammonia was considered a good possibility for the analysis. For maximum sensitivity, solutions to be analyzed by the ISE must be at about pH 11. Above pH 9.2, $Mg(OH)_2$ precipitates from sea water, and adherence of this precipitate would reduce electrode sensitivity significantly over periods of extended use. Disadvantages also include the fact that electrodes currently being used in sea water applications require frequent wiping of the membrane surface with acid solutions to remove precipitates. In addition, the response time of the electrode is quite slow at the levels of ammonia expected in the bulk sample. Technicon, the supplier of the Monitor IV, offers either the ISE or the Berthelot wet chemical method of NH_3 analyses for about the same cost, but for long-term reliable process analysis of ammonia in sea water, Technicon concurs with our recommendation of the Berthelot wet chemical method.

Orion, the manufacturer of an ISE, suggested the possibility of carrying out the analysis at sea water pH (7.8 - 8.3), under which conditions the electrode would sense about 10% of the ammonia present. Such a system would be too insensitive for the bulk analysis mode and would require development work to determine if it is suitable for individual tube analysis. The expected lifetime of an ISE under sea water conditions is still unknown. The situation is further complicated by the fact that the sensitivity of the electrode would vary with sample pH, and it would be necessary to adjust the pH of all solutions to a set value somewhere between ambient pH and the pH at which $Mg(OH)_2$ would begin to interfere.

3.2 pH ELECTRODES

The possibility of monitoring pH changes caused by leaking ammonia was also investigated. Sea water is a highly buffered system due to the presence of approximately 2×10^{-3} M bicarbonate ion. Thus the introduction of ammonia produces much smaller changes in pH than would be seen in fresh water. The high concentration of magnesium ion in sea water (5×10^{-2} M) is another complicating factor. Magnesium hydroxide

precipitates above a pH of about 9.2, serving to reduce even further the change in pH expected from the addition of ammonia.

It was concluded that pH changes are too small to be used for detection of leaks in the bulk mode. Development work would be required to establish the method's suitability for leak location in individual tubes or banks of tubes.

3.3 ION CHROMATOGRAPHY

Another method considered was ion chromatography which used a conductimetric detector. Technical representatives of Dionex Corporation, manufacturer of ion chromatography equipment, said that ammonia can be analyzed by their system only when there is no more than a thousand-fold excess of sodium present. In a sea water medium, ammonia detection would be greatly complicated by the 10^4 ppm interfering concentration of Na^+ .

3.4 INFRARED SPECTROPHOTOMETRIC TECHNIQUES

The same ionic interference phenomenon provides a serious drawback for infrared analysis which would have required concentration of the ammonia on a column followed by stripping. A continuous sample technique of this type has yet to be developed.

3.5 MICROCOULOMETRIC ANALYSES

Microcoulometric methods of analyses were sensitive enough for our purposes but process-type equipment for continuous monitoring is not currently available.

3.6 LIGHT SCATTERING TECHNIQUES

It might be possible to locate leaks greater than about 50 ppm NH_3 by monitoring the light scattering which accompanies the formation of the white magnesium hydroxide precipitate at pH values above 9.2. A considerable amount of development work would be necessary to verify the feasibility of this approach.

3.7 INDICATORS

Another possibility which would involve development expense is the addition of a compound such as fluorescein in ppm amounts to the ammonia.

Leaks could then be located by fluorescence detectors at the condenser and evaporator exits.

4. SAMPLING SYSTEM

4.1 GENERAL

As mentioned earlier, a workable systematic system is required for detecting an ammonia leak. It is our proposal to use three modes of operation, classified as

- Bulk outlet sampling
- Composite tube sampling
- Individual tube sampling

Criteria used in decision making included, but were not limited to:

- Fluid mechanics associated with transporting sea water contaminated with ammonia from potential leak sources.
- Detection limit of <0.1 ppm.
- Thorough flushing of each line with solution to be analyzed prior to taking an aliquot.
- The potential leak sources are 1) shell to tube sheet, 2) tube sheet to H-X tube, and 3) H-X tube.
- Use of existing tube cleaning apparatus for sampling sea water (modified version)

4.1.1 Bulk Outlet Sampling Mode

The bulk outlet sampling mode consists of aspirating tubes located in the outlet stream of each quadrant of the H-X tube bundle. Samples are withdrawn from each tube by pumping into a mixing reservoir at atmospheric pressure. The reservoir provides a continuous flow sample to an auto-analyzer capable of monitoring the system continuously. When the bulk sample exceeds a recorded preset level, an audio/visual alarm is initiated. The general leak location of the particular quadrant can be determined by sampling the quadrant sampling tubes individually by sequencing the air operated valves. Figure 4-1 shows the bulk outlet sampling mode schematically.

H-13




Figure 4-1. Bulk Outlet Sampling - Schematic

4.1.2 Composite Sampling Mode

The composite sampling mode is initiated whenever the bulk sampling system indicates that a leak is present. The concept consists of directing a modified biofouling tube cleaner to the indicated quadrant and sampling a composite of 95 H-X tubes. Sample sea water is taken from each tube and transported to a storage reservoir. Transporting the sample fluid is accomplished by differential pressure from the H-X outlet to a reduced pressure (~ 2 PSIA) reservoir as shown schematically by Figure 4-2.

Two reservoirs will be provided so that as one reservoir is being analyzed, the other one can be filling with a new sample. This would allow the cleaning head to progress uninterrupted to the next bank of 95 tubes.

Any group of tubes may be sequenced for composite sampling and for narrowing the leak to a specific set of tubes. At that point, a decision would be made either to seal that group of tubes or to continue the sequential analytical approach and perform individual tube sampling.

4.1.3 Individual Tube Sampling

After the initial survey of 95-tube composites, the modified brush cleaning apparatus would return to any bank which showed a level of ammonia higher than a specific preset value. Either individual tubes or a composite sample of from 2 to 95 tubes may be obtained by sequencing the multiplex valving manifold system. During this sequence, only one reservoir would be utilized due to the unique design of our reservoir and sampling mode as shown schematically in Figure 4-3. The unique feature of this mode is the transportation of sea water samples by a single pump (vacuum) and the labeling and storage of these samples for either composite or individual analysis.

If it were feasible to seal off as many as 19 tubes at a time, the system could be greatly simplified by removal of individual valves. Groups of 19 tubes could be sampled as a composite via a manifold, and only one valve would be needed for each 19-tube bank. This would reduce the flexibility of the system, however, and would necessitate manual sampling in the event that location of an individual leaking tube ever became desirable.




Figure 4-2. Composite Sampling Mode - Schematic (One Tube Sample Shown)




Figure 4-3. Individual Sampling Mode - Schematic

4.2 GENERAL REQUIREMENTS

A purge pump is provided to supply a background sample between effluent analyses or to wash down the process equipment into a deluge holding tank for subsequent discharge to the sea. Copious flushing is required to prevent cross-contamination from sample to sample.


A pump/filtering assembly is shown for filtering and back flushing. This assembly contains a positive displacement pump capable of 25 feet suction lift. The pump will also serve as a static pressure limiter since the reservoirs are expected to be located at an elevated level exceeding the 5 PSIG working pressure of the auto-analyzer.

4.3 TECHNICAL DISCUSSION

A cursory study was made to establish a feasible method of obtaining a sea water sample representative of a leak from the shell to tube sheet, tube to tube sheet and an individual H-X tube. The shell to tube sheet leak can probably be detected by the bulk system sample test. The tube/tube sheet interface and H-X tube leak is determined by the composite and individual tube sample testing of 95 tube groups. This requires development in certain areas as will be discussed in the design development section. A practical approach is to use the existing tube cleaning subsystem machinery for cost considerations.

Modifications to the existing design are necessary and may also require some development effort. The modification identified at this time requires a hollow (tube fabrication) brush rod for fluid passage to the sample storage reservoir. Also an interchangeable or modified brush head assembly will be required. This brush head will require a check valve, centering brushes and multi-hole entry ports. The concept of the reservoir location and brush assembly is shown by the sketch illustrated in Figure 4-4.

In order to prevent clogging of the sampling inlet lines, transfer lines and valving system, filter assemblies will be added at the inlet to the modified brush unit as shown in Figure 4.4. The major cause of



ENLARGED
 DETAIL 'A'




Figure 4-4. RESERVOIR LOCATION AND BRUSH ASSEMBLY

particulates would most likely be from the formation of $Mg(OH)_2$ caused by ammonia leakage into sea water containing relatively high concentrations of magnesium ions [1000 ppm or more].

A preliminary sizing for the hollow brush diameter and sample flow was conducted. Several available tube sizes were analyzed and are tabulated:

<u>O.D.</u>	<u>WALL</u>	<u>ID</u>	<u>A_0-Ft²</u>	<u>D_H-Ft.</u>
1/2	.049	.402	8.814×10^{-4}	.0335
3/8	.065	.245	3.274×10^{-4}	.0204
1/4	.028	.194	2.053×10^{-4}	.0162

Figure 4-5 shows the pressure drop (PSI/Ft) characteristics for the above tube sizes for laminar flow and Figure 4-6 for turbulent flow. It is recommended that the sample reservoir be located on top of the brush unit and connected with short lines to minimize the static lift, entanglement, and dynamic pressure losses. Assuming the brush head can traverse one foot above the water box water level located another foot above the brush head, the maximum available ΔP would be 32 PSI with a minimum reservoir pressure of 1.66 PSIA limited by the saturation temperature of 120°F to preclude boiling. The ΔP will vary from 32 PSI to 13.5 PSI when the brush tip immersion depth varies from 42 feet to 1 foot. The allowable pressure loss over this range would only vary from 12.15 PSI to 13.49 PSI because the pressure gradient is somewhat compensated by the elevation gradient. Therefore, nearly constant flow should exist for the steady state.

The system pressure drop was calculated assuming 100 feet of 1/4 inch ODX.028" wall tubing, four 90° mitre turns, entrance/exit loss, and a static head of 44 feet. Figure 4-7 illustrated the expected steady state flow variation from 0.25 to 0.27 GPM. The sample reservoir volume is sized for approximately 1.77 cubic feet (13.2 gallons) and filling to half capacity would take 17 seconds for 95 tube samples. The reservoirs are spherical in shape with an ID of 18 inches which should contain 95 1 inch diameter 50 ml containers located at the center line.




Figure 4-5. Brush Rod Pressure Drop vs Laminar Flow For Various Tube Sizes




Figure 4-6. Brush Rod Pressure Drop vs Turbulent Flow For Various Tube




Figure 4-7. System Flow vs Pressure Drop

4.4 DESIGN DEVELOPMENT

This study revealed certain areas requiring design development. These areas are discussed briefly as design development tasks which are identified at this time.

4.4.1 Bulk Sampling Mode

The chief concern of this mode is the number, size and location of the sampling tubes within the flow stream of the H-X outlet. Presently there is no information describing an outlet shroud. The objective would be to determine the minimum number of sampling tubes necessary to provide a representative effluent sample and to narrow the location of a leak to a specific quadrant.

4.4.2 Composite Sampling Mode

Additional system studies are required for the feasibility of combining the composite sampling system with the biofouling control subsystem. Design development is required for the following modifications.

- Locating two reservoirs with an inlet and outlet valve manifold on a moving platform above the cleaning head.
- Modifying the brush rod for flow passage to reservoirs.
- Development or modifying the existing brush head with a check valve, brush and entry ports.
- Modify the brush actuators from 95 individual brush cylinders to two large brush head cylinders.

Additional effort is required for studying alternative concepts and detail analysis of the vacuum transport concept.

4.4.3 Individual Sample Mode

Hardware design is required for the multiplex valve/manifold and associated programmable micro processor. This valve/manifold shall have 95 inlet ports and 95 outlet ports for parallel thruput for one function. Another function is to bypass 95 inlet flows into a common manifold with a single outlet. In addition each of the 95 inlets may be sequenced in any predetermined combination. Each valve must have a low pressure drop (less than 0.20 psi at 0.25 GPM) and must also seal an internal vacuum. These functions are shown schematically by Figure 4-5.

The tentative selection for the analytical instrument is a "Technicon Monitor IV". This instrument may require re-packaging into a hermetic enclosure with temperature control for a continuous salt environment and to preclude electrical ignition of concentrated NH_3 atmosphere. Special shock mounts are also recommended.

EQUIPMENT ANALYSIS AND SAMPLING SYSTEM

4.5.1 INSTRUMENTATION AND CONTROLS

Suitable instrumentation and controls shall be provided for automatic operation. Air operated valves are suggested or explosion proof electric devices. Lists of measurement devices are tabulated in Tables 4-1 and 4-3.

4.5.2 EQUIPMENT AND COMPONENTS

Lists of the equipment and components are tabulated in Tables 4-3 and 4-4. Items specified for the sampling system are for one H-X system only.

The number of Monitor IV instruments required for bulk effluent analysis will depend on the final design of the OTEC PSD-1 module. If the evaporator and condenser are located close enough to each other, a single Monitor IV can be used to measure the ammonia level at the exit of each on a time-sharing-basis. Because the Monitor IV contains a heating bath to bring all sample and reagent solutions to a constant temperature, the difference in temperature of the condenser and evaporator effluents (40°F and 80°F) would not be a problem.

For leak location, a modified Monitor IV, which can accept samples at a rate faster than that needed for the bulk analysis, will be used in conjunction with each tube cleaner/sampling equipment set-up.

Table 4-1. Measurement List — Analysis System

A. For Evaporator

	<u>Quantity</u>	<u>Range</u>	<u>Function</u>
1. NH ₃ level at exit of evaporator (12 sample sites to locate leaking quadrant)	Continuous 1	0.00-0.30 ppm	Leak detection
2. NH ₃ level at entrance to evaporator	Continuous 1	0.00-0.30 ppm	Background NH ₃ Estimation
3. NH ₃ level of 95 tube composite samples from tube cleaner and sampler as it traverses suspect quadrant(s)	110-440 as needed	0-1 ppm	Leak Location
4. NH ₃ level of each of 95 tubes	95, as needed	0-1 ppm	Leak Location
5. Location of cleaner/sampler which corresponds to leaking bank of 95 tubes		TBD	Leak Location
6. Location of leaking tube/tubes		TBD	Leak Location
7. Reagent reservoir level	8	Full-empty	Monitor reagent supply
8. Flow rate of sample lines into instruments	2	0-5 ml/min	Monitor inlet to instrument
9. pH of complexing reagent stock solution	1/week	Determine pH=5.0	Preparation of reagent solution
10. Weights of reagents in making stock solutions	4 solutions to be prepared once a week	0.00-500.00 g	Preparation of reagent solutions
11. Pressure of air supply to continuous filter; regulator to 80 psig	2	TBD	Operations of continuous filter

Table 4-2. Equipment List — Analysis System

A. For Evaporator

I. Bulk Sampling

<u>Part No.</u>	<u>Qty</u>	<u>Product Description</u>
188-A003-01	1	Technicon Autoanalyzer Monitor IV System consisting of the following: One integral monitoring unit, incorporating a phototube calorimeter to provide linear readout and a 0-5 volt dc signal, proportional to concentration, for data handling or storage, a two speed proportional pump, 7 inch strip chart recorder, reagent containers and all necessary accessories. Monitor IV System for the determination of ammonia (2.8-140 µg-N/L) in water and seawater, complete with:
188-B028-01	1	A plattered manifold with heating bath
170-B070P27	1	Set/2, Interference Filters, 630 nm
ACC	1	Programmer Mechanism for automatic recalibration (Autocal)
Alarm	1	Hi-Level Alarm with Contact Closure
180-A001-01	1	Continuous Filter/Sampler (if ordered with Monitor IV System)
170-0144-01	4	Technicon In-Line reagent filter
	4	5-L reagent containers to provide larger reagent reservoirs for 1-week operation (1 container opaque)
	1	Simple acid scrubber bottle for air entering reagent bottle

Table 4-2. Equipment List — Analysis System (Continued)

A. For Evaporator (Continued)

II. Composite and Individual Sampling Mode

<u>Part No.</u>	<u>Qty</u>	<u>Product Description</u>
188-A003-01 188-B028-01 170-B070P27	1	Technicon Autoanalyzer system for NH ₃ with the following modification: 15 x 1.5 mm short flow cell, type AA2, which will permit 60 samples/hour to be analyzed during leak search
180-A001-01	1	Continuous filter/sampler
170-0144-01	4	Technicon In-Line Reagent Filters
	4	5-L reagent containers, one of which opaque

B. For Condenser

I. Bulk Sampling

If the evaporator and condenser are located close enough to each other, a single Monitor IV can be used to measure the NH₃ level at the exit of each.

The following time-sharing option would allow both exit streams to be monitored on the same Monitor IV.

<u>Part No.</u>	<u>Qty</u>	<u>Product Description</u>
ACC	1	Automatic, Adjustable Programmer Control for two streams, including sequential valving system
		Otherwise duplicates of the equipment listed for the evaporator under "Bulk Sampling" must be purchased.

Table 4-2. Equipment List -- Analysis System (Continued)

B. For Condenser (Continued)

II. Composite and Individual Sampling Mode

Duplicate requirements for evaporator "Composite and Individual Sampling Mode."

Separate equipment is recommended to minimize length of sample tubing required.

If there is a need to cut costs, and if the evaporator and condenser are close enough, there is a possibility that a single Technicon IV could be used for leak location in either (not simultaneously).

C. General

	<u>Qty</u>	<u>Product Description</u>
1.	1	Microprocessor to be used in monitoring the following: <ul style="list-style-type: none"> a. Condenser effluent NH₃, continuous b. Evaporator effluent NH₃, continuous c. 95-tube-composite NH₃ level (1-440 composites, as needed), condenser d. 95-tube-composite NH₃ level (1-440 composites, as needed), evaporator e. NH₃ level of individual tubes, as needed, condenser f. NH₃ levels of individual tubes, as needed, evaporator
2.		Housing for analytical equipment and reagent supplies Size depends on proximity of condenser and evaporator, which in turn determines the number of Technicon Monitor IV's to be purchased and the location of each.

Table 4-2. Equipment List — Analysis System (Continued)

C. <u>General</u> (Continued)		
	<u>Qty</u>	<u>Product Description</u>
3.	1	Top-loading balance 0-1200 g (or TBD, depending on number of instruments and amount of reagent needed)
4.	1	Simple pH meter
5.		Reagent storage cabinet
6.	3	5-gal solution bottles — for solution batches. Heavy-duty polypropylene carbons
7.		Miscellaneous glassware
8.		Distilled water ~40 gal/week/instrument Solar-powered still on board?
9.		Compressed air Purchase by the tank or install air compressor, depending on amount needed (= function of No. of Technicon Monitor IV's)

TABLE 4.3 - MEASUREMENT LIST - SAMPLING SYSTEM

A. BULK SAMPLING MODE

	<u>DESCRIPTION</u>	<u>REF. SYM</u>	<u>QTY.</u>	<u>RANGE</u>	<u>FUNCTION</u>
1.	FLOW METER	FM1	1	0.10-1.00 GPM	CONTROL SAMPLE FLOW
2.	REAGENTS LEVEL	L3-L6	4	TBC	MONITOR REAGENT SUPPLY
3.	RESERVOIR LEVEL INDICATOR	L1, L2	2	TBC	MAINTAIN SAMPLE SUPPLY
4.	TEMPERATURE SENSOR	T1	1	32 ⁰ F-150 ⁰ F	MONITOR SAMPLE TEMPERATURE

B. COMPOSITE AND INDIVIDUAL SAMPLING MODE (FIGURE 4.0 AND FIGURE 5.0)

1.	VAC. PRESS. TRANSDUCER	PT1-PT2	2	0-30"Hg	CONTROL RESERVOIR PRESS (FLOW)
2.	TEMPERATURE SENSOR	T1-T2	2	32 ⁰ F-150 ⁰ F	MONITOR SAMPLE TEMPERATURE
3.	VAC. PUMP PRESS GAUGE	P1	1	0-30"Hg	MONITOR VACUUM PUMP OPERATION
4.	PURGE PUMP PRESS GAUGE	P2	1	0-100 PSI	MONITOR PURGE SYSTEM PRESSURE
5.	PURGE PUMP FLOW METER	FM2	1	0.2-2 GPM	MONITOR PURGE FLOW RATE
6.	HOLDING TANK LEVEL	L1	1	TBD	MONITOR HOLDING TANK LEVEL
7.	SAMPLE RESERVOIR LEVEL	L2-L3	2	TBD	MONITOR SAMPLE RESERVOIR LEVEL
8.	REAGENT RESERVOIR LEVEL	L4	1	TBD	MONITOR REAGENT SUPPLY
9.	CONTROL AIR PRESS GAUGE	P3	1	0-100 PSIG	MONITOR VALVE CONTROL AIR SUPPLY

TABLE 4.4 - EQUIPMENT LIST - SAMPLING SYSTEM

A. BULK SAMPLING MODE

	<u>DESCRIPTION</u>	<u>REF SYM</u>	<u>QTY.</u>	<u>RANGE/SIZE</u>	<u>FUNCTION</u>	<u>MFG.*</u>	<u>P/N*</u>
1.	PNEUMATIC VALVES	V1-V4, V7	5	0- .25 GPM	SAMPLE FLOW CONTROL	NUPRO	SS-8BK-91N0
2.	SUBMERSIBLE PUMP	PM1	1	0-1.0 GPM	BULK FLOW SOURCE	BYRON JACKSON	---
3.	SAMPLE RESERVOIR	RSV 2	1	TBD	SAMPLE STORAGE	TBD	TRW DCS
4.	HOLDING RESERVOIR	RSV 1	1	TBD	WASTE STORAGE	TBD	TRW DCS
5.	PUMP VALVES	V5-V6	2	0-1.0 GPM	PURGE FLOW CONTROL	WHITNEY	SS-5PDF8

* Suggested Source and Part Number

TABLE 4.4 - EQUIPMENT LIST - SAMPLING SYSTEM (CON'T)

B. COMPOSITE & INDIVIDUAL SAMPLING MODE

<u>DESCRIPTION</u>	<u>REF. SYM</u>	<u>QTY.</u>	<u>RANGE/SIZE</u>	<u>FUNCTION</u>	<u>MFG*</u>	<u>P/N*</u>
1. INDIVIDUAL RESERVOIR	RSV1	1	13 gal. (50 liters)	LABEL & STORAGE LOT #1	TBD	TRW DCS
2. COMPOSITE RESERVOIR	RSV2	1	13 gal. (50 liters)	LABEL & STORAGE LOT #2	TBD	TRW DCS
3. VACUUM PUMP	VP1	1	0-30"Hg, 30 CFM	RESERVOIR PLMP DOWN	KINNEY	TBD
4. COLD TRAP	CT	1	0-30"Hg	CONDENSE MOISTURE	KINNEY	TBD
5. VACUUM PRES. REG.	PR1	1	0-30"Hg	CONTROL RESERVOIR PRESS.	KINNEY	TBD
6. RESERVOIR VENT VALVE	V2-V6	2	0-30"Hg	RELEASE RESERVOIR VAC.	NUPRO	SS-8BK-91NC
7. VACUUM VALVES	V3-V7	2	0-30"Hg	FLOW CONTROL	NUPRO	SS-8BK-91NC
8. RESERVOIR VALVES	V4-V8	2	0-0.01 GPM	SAMP. FLOW SHUTOFF&DRAIN (3-WAY)	TBD	TBD
9. PURGE PUMP	PM1	1	0.2-2.0 GPM	PURGE SAMPLE SYSTEM "PRICE" H ⁰ -175, 3/4 H ⁰	TBD	TBD
10. PURGE CHECK VALVE	CV1	1	0.2-2.0 GPM	BACKFLOW CONTROL	NUPRO	SS-8C-10
11. FLOW CONTROL VALVE	V12	1	0.2-2.0 GPM	PURGE FLOW CONTROL	WHITNEY	SS-5PDF8
12. PURGE FILTER	F1	1	0.2-2.0 GPM	FILTER PURGE FLOW	NUPRO	SS-8TF-140S
13. PURGE VALVES	V1-V9	2	0.2-2.0 GPM	PURGE SEQUENCING	NUPRO	SS-8BK-91NC
14. HOLDING TANK	RSV3	1	TBD	PREVENT SEA WATER POLLUT.	TBD	TRW DCS
15. HOLDING TANK VALVE	V11	1	TBD	DRAIN HOLDING TANK	NUPRO	SS-8BK-91NC
16. REAGENT VALVES	SV11	1	0-0.016 GPM	CONTROL REAGENT FLOW	NUPRO	SS-4BK-91NC
17. PUMP/FILTER ASSEMBLY	PF1	2	(TECHNICON)	FILTRATION OF SAMPLES	TECHNICON	TBD
18. INLET MULTIFLEX VALVE	(ASSEMBLY)	95	0-.5 GPM	INDIVIDUAL SAMPLE CONTROL	NUPRO	SS-8BK-91NO
19. OUTLET MULTIFLEX VALVE	(ASSEMBLY)	95	0-.5 GPM	INDIVIDUAL SAMPLE CONTROL	NUPRO	SS-8BK-91NO
20. AIR PILOT SOLENOIDS VALVES		250	0-100 PSIG	PILOT VALVE FOR SYS. CTRL.	TBD	TBD
21. TANK RELIEF VALVES		2	50-100 PSIG	TANK SAFETY VALVES	NUPRO	SS-4CPAZ-50
22. INSTR. AIR COMPRESSOR		1	0-100 PSIG, 10 SCFM	SOURCE FOR AIR ACTUATED VLVS.	TBD	TBD

* SUGGESTED SOURCE

5. SUMMARY

A very feasible system has been devised for ascertaining the concentration of ammonia in sea water. A composite total sample will be analyzed and, in event of excessive leakage, individual composites of 95 tubes will be analyzed via use of a modified brush cleaning unit. Further, more limiting composites will be sequentially analyzed in order to narrow the leak to a small group of tubes or to the individual tube. Refer to Figure 5-1 showing a Logic Diagram used in Decision Criteria.

The detection system will use the standard Berthelot Reaction which is well documented and very reliable for measuring ammonia concentrations in sea water.

The sampling system concept has been finalized, and only localized design study will be needed. All transfer principles have been examined, including vacuum transfer, general line flushing, back-flushing, and final chemical analyses.

This system should prove very reliable and an asset to the program.




Figure 5-1. Logic Diagram for Sampling

ATTACHMENT 1

1. Methods for Chemical Analysis of Water and Wastes, 1971 Environmental Protection Agency, Water Quality Office, Cincinnati, Ohio.
2. Van Slyke, D.D. and Hillen, A.J., Bio Chem., 102, p. 499, 1933.
Kallman, S., Presentation at Div. I Meeting of ASTM Committee E-3, April 1967, San Diego, California.
Bolleter, W.T., Bushman, C.J. and Tidwell, P.N., Anal. Chem., 33, p. 592, 1961.
Tellow, J.A. and Wilson, A.L., Analyst, 89, p. 453, 1964.
Tarugi, A. and Lenci, F., Boll Chim. Farm., 50, p. 907, 1912.
FWPCA Methods of Chem. Anal. of Water and Wastewater, Nov., 1969, p. 137.
Gilbert, T.R. and Clay, A.M., Anal. Chem 45, p. 1757 (1973).
Zadorojny, C., Saxon, S., and Finger, R., Journal WPCF, 45, p. 905 (1973).
3. Riley, J.P. and Skirrow, G., "Chemical Oceanography, Vol. 1," Academic Press, London, 1965, p. 387.

ATTACHMENT 2

REFERENCES

IOC No. 4341.AC 78-161, J.S. Shapiro/J. Wilson to Lee Leventhal.

IOC No. 78.4725.3-126, W.F. Chew to L. Ryan.

APPENDIX H.2

OTEC PSD-1, EFFECTS OF SEAWATER LEAKAGE INTO AMMONIA SYSTEM

TRW

DEFENSE AND SPACE SYSTEMS GROUP

ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278

INTEROFFICE CORRESPONDENCE

TO: Paul Edris

CC:

4341.AC.78-183
DATE: 14 September 1978

SUBJECT: OTEC PSD-1, Effects of Sea Water Leakage
Into Ammonia System

FROM: J. S. Shapiro/J. Wilson
BLDG. 01 MAIL STA. 2030 EXT. 62451

Attached is the report on our study of the possibility of seawater flow into ammonia in the OTEC system. The chemistry of the ammonia-seawater system is discussed, and suggestions for minimizing harmful effects on the heat exchangers are presented.

Distribution

M. BIANCHI
W. CHEW
P. FUKUNAGA
G. GIBSON
A. GRANT
R. JONES
J. KAELLIS
L. KENT
D. REEVES
L. ROSALES
S. VINCENT

After reviewing the effects of ammonia leakage into water, the next logical step would be to review the effects of sea water leakage into ammonia, if any. One can look at this problem as being somewhat remote, but there still exists the possibility of incursion of sea water into the ammonia system.

POSSIBLE LEAKAGE



Since the lower pressure limit for the NH₃ system is about 90 psia and the water pressure at the bottom tube sheet will be only about 35 psia, the amount of sea water entering the ammonia is expected to be very small. Essentially back diffusion would be the main source of leakage. The other major source of leakage would be reduced pressure in the ammonia system. To prevent this, we recommend that make-up ammonia be added on a continuous basis so that any possible ammonia leak will not reduce the system pressure. This will minimize the back-diffusion of sea water into ammonia and deleterious effects on the efficiency of the power system.

The expected decrease in efficiency caused by water in ammonia used for the power loop has already been studied. [See attached addendum].

Any sea water entering the system would reduce thermal efficiency by lowering the pressure in the evaporator. However, blowdown pumps have already been designed into the system to permit removal of wet ammonia. This ammonia would be distilled and purified.

CHEMICAL EFFECTS

The salt content of the sea water presents the most serious threat to system efficiency. Magnesium ions present at a 1350 ppm level in sea water will precipitate as Mg(OH)₂ in the presence of the hydroxide ions formed in wet ammonia. The equations for this reaction are:



Accumulation of $Mg(OH)_2$ on the ammonia side of the heat exchanger tubes will provide a barrier or insulation of the tubes with the resultant decrease of heat transfer and the reduction of plant efficiency.

Calculations were made to estimate the magnitude of the problem for leaks of various sizes. The assumptions and data used in the calculations are:

- Magnesium hydroxide is very insoluble in water ($K_{sp} = 1.2 \times 10^{-11}$).
- The dielectric constant of ammonia is lower than that of water, making ammonia a poorer electrolytic solvent than water.
- Although no K_{sp} value was found for $Mg(OH)_2$ in ammonia, magnesium hydroxide would be expected to be less soluble in ammonia than in water.
- The aqueous solubility product constant for $Mg(OH)_2$ was used in the calculations, and for simplicity it was assumed that all Mg^{+2} present would precipitate if the K_{sp} were exceeded.

Table 1 summarizes the amounts of precipitate expected from different levels of sea water in a 200,000 pound ammonia system.

Formation of $Mg(OH)_2$ Precipitate from Sea Water Leak Into Ammonia System	
Leak, ppm Sea Water in NH_3	Pounds of $Mg(OH)_2$ Which Would Precipitate in NH_3 System
50 ppm	No ppt
200	No ppt
1000	0.6
5000	3.0
200,000	12.0

While reviewing the data, other assumptions should be considered.

- Use of a K_{sp} value for $Mg(OH)_2$ in ammonia, which is expected to be smaller than that in water, would reduce the leak level at which precipitate begins forming but would not change the total amount of precipitate expected.

- The density of the $Mg(OH)_2$ is about four times greater than that of liquid ammonia, and the precipitate is expected to accumulate on the bottom tube sheet. It is impossible to estimate how much build-up on tube walls might occur at various leak sites in the system.

OTHER POSSIBLE CHEMICAL REACTIONS

Another problem anticipated is the precipitation of Calcium Carbonate, $CaCO_3$, caused by the increase in the sea water pH as it enters the ammonia system. Buildup of solid $CaCO_3$ would further reduce the thermal transfer efficiency of the system. Since only aqueous K_{sp} values are available, the magnitude of the problem must be determined experimentally.

The solubility of sodium chloride in ammonia is 3.02g NaCl/100g NH_3 , compared with a solubility in water of 37g/100g H_2O . Even in leaks which result in sea water levels of 200,000 ppm, no NaCl is expected to precipitate.

POSSIBLE CORRECTIVE/PREVENTIVE ACTION

It may be possible to inhibit the formation of $Mg(OH)_2$ and $CaCO_3$ by the addition of a sequestering agent, such as acid Versene, EDTA, which is available as a solid.

The compound is very soluble in water and is expected to be soluble in ammonia, but development work would be necessary to test the feasibility of this approach. Because the pH of the ammonia will be a function of the water present, it must also be verified that the magnesium-EDTA and the calcium-EDTA complexes will be stable at the expected pH levels.

An alternative approach for removal of these potential precipitates would be periodic cleaning of the system with an acid. This would necessitate removal of the ammonia, flushing with an acid which is compatible with titanium, and then flushing with appropriate solvent to remove said acid. It would be necessary to avoid nitric, sulfuric, or any halogenated acid.

MATERIALS COMPATIBILITY

Studies on the effect of sea water in ammonia on the materials of construction of the system have already been performed by Louis A. Rosales and

Maurice P. Bianchi of the Materials Engineering Department of the Manufacturing Division. In speaking with them, they stated that the details have all been documented and reported to the OTEC Program Office. As a consequence, we did not belabor this facet.

CONCLUSION

It is unlikely that sea water leakage into ammonia would occur to any extent, but in the event of some leakage, it would be imperative to have a method for removal of any solids formed. The primary chemical reactions would produce $Mg(OH)_2$ and $CaCO_3$.

This potential leakage and resultant compounds underscore the necessity of a good NH_3 leak detection system on the water side of the heat exchangers. As soon as a leaking tube is located and plugged, the possibility of sea water's entering the NH_3 system at that point is eliminated.

Approved



L. E. Ryan, Section Head
Analytical Chemistry

ADDENDUM

AMMONIA SUPPORT SUBSYSTEMS

EFFECT OF AMMONIA PURITY Water in ammonia used for the power loop will concentrate in the evaporator because it is less volatile than ammonia. With a constant evaporator temperature, as set by the warm seawater, the presence of water will lower the pressure in the evaporator. The net result is a reduction in the efficiency of the power loop. More ammonia would have to be evaporated and equipment sizes and parasitic loads would increase.

The table that follows compares operation of the power loop with pure ammonia and with 98 weight percent ammonia in the evaporator. The following were fixed for both cases. Temperature in the evaporator. Pressure drop from evaporator to turbine inlet. Turbine exhaust pressure. Turbine efficiency. And gross power output. There would be about 20 ppm of water in the vapor leaving the evaporator in the 98 weight percent ammonia case.

BLOWDOWN As pointed out in the paragraph on ammonia purity, water in the evaporator will reduce the power system efficiency. To control the amount of water build up in the evaporators, blowdown pumps are provided so liquid from the evaporators can be blown down to the heel storage tank. From there, the blowdown is fed to the rectifying column.

If the water concentration in the evaporators is held at 1000 ppm, there will be a drop in evaporator pressure at constant temperature of about 0.1 psi and a system loss in efficiency of about 0.2 percent. This is based upon a straight line interpolation of the comparison given earlier between performance for pure ammonia and for 98 weight percent ammonia. It is assumed that 1000 ppm of water in the evaporator is a practical concentration to hold and that the 0.2 percent loss in system efficiency is tolerable.

TRW, CTEC, Project 5304-P, January 10, 1978

ADDENDUM

AMMONIA SUPPORT SUBSYSTEMS

EFFECT OF AMMONIA PURITY Continued

	PURE NH ₃ IN EVAPORATOR	98 WEIGHT PERCENT NH ₃ IN EVAPORATOR
Temperature in evaporator, °F	70	70
Pressure in evaporator, psia	128.8	126.7
Pressure drop to turbine, psi	1.5	1.5
Pressure at turbine, psia	127.3	125.2
Temperature at turbine, °F	69.53	69.49
Vapor enthalpy at turbine, Btu/lb	629.1	629.6
Vapor entropy at turbine, Btu/lb °F	1.2153	1.2179
Turbine outlet pressure, psia	89.2	89.2
Moisture at turbine outlet, wt %	2.90	2.65
Enthalpy at turbine outlet at constant entropy, Btu/lb	609.9	611.2
ΔH at constant entropy, Btu/lb	19.2	18.4
Ammonia flow for 34.77 MWe at 85% turbine efficiency, lb/hr	7,271,000	7,587,000
Ammonia flow increase, %	-	4.3
Increased heat to evaporator, %	-	4.6
Increased heat to condenser, %	-	4.7

The increases in heat to the evaporator and to the condenser are slightly greater than the increase in flow because the enthalpies leaving the evaporator and entering the condenser are also slightly higher for the 98 weight percent case than for the pure ammonia case. The increase in parasitic loads for a fixed net power output means even a greater disadvantage than shown.

TRW, OTEC, Project 5304-P, January 10, 1978

TABLE 4.4 - EQUIPMENT LIST - SAMPLING SYSTEM (CON'T)

B. COMPOSITE & INDIVIDUAL SAMPLING MODE

	<u>DESCRIPTION</u>	<u>REF. SYM</u>	<u>QTY.</u>	<u>RANGE/SIZE</u>	<u>FUNCTION</u>	<u>MFG*</u>	<u>P/N*</u>
	1. INDIVIDUAL RESERVOIR	RSV1	1	13 gal. (50 liters)	LABEL & STORAGE LOT #1	TBD	TRW DCS
	2. COMPOSITE RESERVOIR	RSV2	1	13 gal. (50 liters)	LABEL & STORAGE LOT #2	TBD	TRW DCS
	3. VACUUM PUMP	VP1	1	0-30"Hg, 30 CFM	RESERVOIR PUMP DOWN	KINNEY	TBD
	4. COLD TRAP	CT	1	0-30"Hg	CONDENSE MOISTURE	KINNEY	TBD
	5. VACUUM PRES. REG.	PR1	1	0-30"Hg	CONTROL RESERVOIR PRESS.	KINNEY	TBD
	6. RESERVOIR VENT VALVE	V2-V6	2	0-30"Hg	RELEASE RESERVOIR VAC.	NUPRO	SS-8BK-91NC
	7. VACUUM VALVES	V3-V7	2	0-30"Hg	FLOW CONTROL	NUPRO	SS-8BK-91NC
	8. RESERVOIR VALVES	V4-V8	2	0-0.01 GPM	SAMP. FLOW SHUTOFF&DRAIN (3-WAY)	TBD	TBD
	9. PURGE PUMP	PM1	1	0.2-2.0 GPM	PURGE SAMPLE SYSTEM "PRICE" H ⁰ -175, 3/4 H ⁰	TBD	TBD
H-45	10. PURGE CHECK VALVE	CV1	1	0.2-2.0 GPM	BACKFLOW CONTROL	NUPRO	SS-8C-10
	11. FLOW CONTROL VALVE	V12	1	0.2-2.0 GPM	PURGE FLOW CONTROL	WHITNEY	SS-5PDF8
	12. PURGE FILTER	F1	1	0.2-2.0 GPM	FILTER PURGE FLOW	NUPRO	SS-8TF-140S
	13. PURGE VALVES	V1-V9	2	0.2-2.0 GPM	PURGE SEQUENCING	NUPRO	SS-8BK-91NC
	14. HOLDING TANK	RSV3	1	TBD	PREVENT SEA WATER POLLUT.	TBD	TRW DCS
	15. HOLDING TANK VALVE	V11	1	TBD	DRAIN HOLDING TANK	NUPRO	SS-8BK-91NC
	16. REAGENT VALVES	SV11	1	0-0.016 GPM	CONTROL REAGENT FLOW	NUPRO	SS-4BK-91NC
	17. PUMP/FILTER ASSEMBLY	PF1	2	(TECHNICON)	FILTRATION OF SAMPLES	TECHNICON	TBD
	18. INLET MULTIPLEX VALVE	(ASSEMBLY)	95	0-.5 GPM	INDIVIDUAL SAMPLE CONTROL	NUPRO	SS-8BK-91NO
	19. OUTLET MULTIPLEX VALVE	(ASSEMBLY)	95	0-.5 GPM	INDIVIDUAL SAMPLE CONTROL	NUPRO	SS-8BK-91NO
	20. AIR PILOT SOLENOIDS VALVES		250	0-100 PSIG	PILOT VALVE FOR SYS. CTRL.	TBD	TBD
	21. TANK RELIEV VALVES		2	50-100 PSIG	TANK SAFETY VALVES	NUPRO	SS-4CPAZ-50
	22. INSTR. AIR COMPRESSOR		1	0-100 PSIG, 10 SCFM	SOURCE FOR AIR ACTUATED VLVS.	TBD	TBD

* SUGGESTED SOURCE

APPENDIX I
HEAT EXCHANGER DESIGN SUPPORTING DATA

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX I.1
THERMAL/HYDRAULIC ANALYSIS

I.1. THERMAL/HYDRAULIC ANALYSIS

The tube side (sea water) heat transfer coefficients and the shell side heat transfer coefficients, both the ammonia condensing and the ammonia evaporating, were determined from equations developed from experimental data. The tube metal wall conductance was calculated on the basis of a "thermal thickness". All heat transfer coefficients were referred to an equivalent inside smooth tube; that is, a tube with an inside diameter which has the same flow area as the fluted tube. The overall heat transfer coefficient U was determined in the usual manner as the reciprocal of the sum of the reciprocals of the individual heat transfer coefficients plus the fouling factor.

I.1.1 Tube Side Equations - Heat Transfer and Pressure Drop

Seawater Heat Transfer. The seawater heat transfer coefficients were determined from equations developed from experimental data in the CMU thermal-hydraulic laboratories. These equations are based on the postulate that the seawater heat transfer coefficient for a fluted tube is greater than that of a smooth tube by the ratio of surface area of the fluted tube to that of an equivalent inside diameter smooth tube. This ratio is termed the area ratio.

The tube side equation developed at CMU is:

$$Nu = 0.027Re^{0.8}Pr^{1/3}AR$$

where Nu, Re, Pr are respectively the Nusselt, Reynolds and Prandtl numbers. The diameter used in both the Nusselt and Reynolds Numbers is the diameter of the equivalent smooth tube;

AR = the area, or surface, ratio.

It is the ratio of the surface of the fluted tube to that of the equivalent smooth tube.

$$Nu = \frac{hD}{k} ; h_{\text{tube side}} = Nu \frac{k}{D}, k = \text{thermal conductivity of seawater}$$

This equation is in the form originally proposed by Dittus-Boelter. Figures 1 thru 6 show plots of the same equation in the form proposed by Colburn, together with experimental points:

$$j_H = AR \times j_{H/S} = \frac{h}{C_p V \rho} Pr^{2/3}$$

V = velocity and ρ = density

j_H = Colburn j factor for heat transfer in a fluted tube

$j_{H/S}$ = Colburn j factor for the equivalent smooth tube

Figures 1 thru 6 also show the j_F factor for a fluted tube as determined from the Blasius Equation together with experimental points. For a smooth tube, the Blasius Equation is:

$$f_s = \frac{0.316}{Re^{0.25}}$$

For a fluted tube this becomes

$$f = \frac{0.316 \times AR}{RE^{0.25}}$$

j_F for a fluted tube, thus is determinable as

$$j_F = \frac{f}{2} = \frac{0.316 \times AR}{2 \times Re^{0.25}} = \frac{f_s}{2} \times AR$$

The equation actually used in design is:

$$f_s = \exp[0.025 (\ln Re)^2 - 0.7534 (\ln R) + 1.1386]$$

which was developed by TRW. In the range $20,000 \leq Re \leq 60,000$. Both the Blasius and TRW equation give substantially the same values; however, for high Reynolds numbers the Blasius Equation extrapolates below all the published data for smooth drawn tubes whereas the TRW equation is consistent with published results.

I.1.2 Evaporation Heat Transfer Coefficient

Experimental data from CMU Heat Transfer Laboratories, for the composite evaporation heat transfer coefficient (a composite coefficient includes the metal wall) for the evaporation of Freon 11 on fluted 26 mill

tubes is shown in Figure 8. Experiments with 40 mill fluted tubes gave essentially the same results. This data on Freon 11 was converted to ammonia data by use of a correction factor. The ammonia evaporation composite heat transfer coefficient is 6.27 times the Freon 11 composite heat transfer coefficient. The validity of this correction factor was verified by further experiments with ammonia evaporating from 26 mill fluted tubes. Curve "B", shown on Figure 8, is then the starting relation between the expected local composite ammonia evaporation coefficient and the local Reynolds number. This curve was integrated between Re_B (Reynolds number at the bottom of the evaporator, always less than 3000) and Re_T (Reynolds number at the top of the evaporator, always greater than 3000). The Reynolds number is defined as:

$$Re = \frac{4\Gamma}{\mu}$$

μ = viscosity and Γ = tube loading
 = (lb/hr)/(ft of "smooth tube peripheral length")
 "smooth tube peripheral length" = πD where
 D is the rill diameter.

The integrated equation, divided by $Re_T - Re_B$, is thus the mean value of the composite heat transfer coefficient.

$$h_{e/mean} = \frac{(2.939 Re_T^{0.4151} - 63.217) 8 \times 10^5 - 5.633 Re_B^{1.8452}}{(Re_T - Re_B)} \quad \begin{array}{l} Re_B \leq 3000 \\ Re_T \geq 3000 \end{array}$$

Re_T and Re_B must satisfy a material balance; that is the tube loading difference, and thus Reynolds number difference, between the top and bottom of the tube must reflect the quantity of ammonia evaporated. In addition, the maximum value of $h_{e/mean}$ is obtainable if Re_T and Re_B satisfy the relation:

$$Re_T = \frac{3.17508 \times 10^8}{Re_B^{1.44537}}$$

This equation and the material balance permit determining Re_T and Re_B for optimum (maximum $h_{e/mean}$) operation.

$h_{e/\text{mean}}$ thus determined, is corrected to a pure evaporation heat transfer coefficient by removing the metal resistance of the experimental evaporation tube and adding the metal resistance of the design tube.

The metal resistance of the experimental tube is 4.6695×10^{-5} .

$$h_{e,\text{composite,design}} = \frac{1}{\left(\frac{1}{h_{e/\text{mean}}} - 4.6695 \times 10^{-5} + r_m\right)}$$

r_m = metal wall resistance of the design tube.

I.1.3 Condensing Heat Transfer Coefficient

The experimental data for tube E in Oak Ridge Report ORNL-5356, Figure 7, was used as the basis for the condensing coefficient. This data was chosen because it most resembles the fluted tubing used for the TRW-OTEC design. The original Oak Ridge data was revised to an equivalent smooth tube surface basis in accordance with the TRW calculation procedure by use of the $A_{O.R.}/A_s$ ratio. The ratio $A_{O.R.}/A_s$ is the ratio of the total surface as used by Oak Ridge to the surface of a smooth tube having the same diameter as the rill diameter of Tube E. The heat transfer coefficient was divided by this ratio and the flux multiplied by this ratio. The experimental data was then fitted to an equation to give the following expression:

$$h_c = -3231.62 + \frac{3.684 \times 10^8}{\left(\frac{q}{A} + 20129.28\right)}$$

q = total flux BTU/hr

A = total smooth tube surface referred to rill diameter

The metal resistance of the experimental tube was then subtracted from this composite and the metal resistance of the actual tube reinserted in

a manner similar to that described for the evaporator composite coefficient. The resistance of tube E used in the Oak Ridge experiment is 2.245×10^{-5}

$$h_{c, \text{composite, design}} = \frac{1}{\left(\frac{1}{h_c} - 2.245 \times 10^{-5} + r_m \right)}$$

r_m = metal wall resistance

Both the evaporation and condensing coefficients have a rather small influence on the size of the final design since the attenuation factors, listed in Table 1 are 0.05 and 0.03 respectively for the evaporator and condenser.

I.1.4 Metal Resistance

Procedures for determining the metal wall resistance of tubes fluted both internally and externally are not generally available in the literature.

The metal resistance was determined as a thermal thickness divided by the tube thermal conductivity. The thermal thickness is the wall thickness of a smooth tube which has the same wall resistance as the fluted tube. Tube curvature, as encountered in a round tube, influences the results to such a small extent that it was ignored. Thermal thickness is determined in the following manner:

The one-dimensional Fourier Equation in finite difference form is:

$$q = -k PL \frac{\Delta T}{\Delta X} \quad (1)$$

in which L is the length of the slab (visualize as corresponding to the length of the tube) and P is a distance perpendicular to the flux (visualize as the perimeter of the tube); ΔX is the thickness of the slab. The equation may be written:

$$\frac{\Delta X}{P} = \frac{-k \Delta T}{\frac{q}{L}} \quad (2)$$

For several slabs in series we may add equation (2) for each of the slabs to obtain:

$$\Sigma \frac{\Delta X}{P} = \Sigma \frac{-k\Delta T}{\frac{q}{L}}$$

Since k and q/L are constant we may factor these outside of the Σ operator. The term $\Sigma \Delta T$, which remains, is simply the overall temperature difference, thus for a series of slabs

$$\Sigma \frac{\Delta X}{P} = \frac{-k\Delta T_{o.a.}}{\frac{q}{L}} \quad (3)$$

Now, we consider a hypothetical single slab (corresponding to a smooth tube) which has the same heat rate per unit length and the same overall temperature difference, equation (2) becomes

$$\frac{\Delta X_s}{P_s} = \frac{-k\Delta T_{o.a.}}{\frac{q}{L}} \quad (4)$$

Since we have postulated that the right hand side of equations (3) and (4) are equal, we may equate the left hand sides to obtain

$$\Delta X_s = \left(\Sigma \frac{\Delta X}{P} \right) P_s \quad (5)$$

ΔX_s is the thickness of a smooth tube having a thermal thickness equivalent to a fluted tube and P_s may, essentially, be considered as the distance between lines of flute symmetry, i.e., about one-half the pitch, as shown in Figure 9 and Figure 10.

We now consider the method of determining $\Sigma \frac{\Delta X}{P}$. On the seawater side the purpose of the flutes is to enable the high thermal conductivity metal to protrude past the low conducting laminar sublayer into the turbulent core. In actuality the laminar sublayer in the rill of the flutes is much thicker than the laminar sublayer for a smooth tube, implying much poorer heat transfer, and significantly thinner on the crest, implying much improved heat transfer. We arbitrarily assume all surface

of the flute from the bottom of the rill to a distance 4.5 mills above the bottom of the rill to be an adiabatic and the remainder of the flute to be an isotherm.

For condensing on external flutes, condensate and essentially all of the heat, enters at the crest of the flute. Similarly, for evaporation, all of the heat leaves at the crest of the flute. We arbitrarily assume 50 percent of the flute surface close to the rill is an adiabatic. The lines of symmetry are, of course, adiabatics. The adiabatic lines are shown in Figure 9.

Once the adiabatics are established, the isotherms are lines between the adiabatics and perpendicular to the adiabatics, although in actual practice no attention was paid to the fact that the isotherms must be perpendicular to the adiabatics.

The lengths of each of the two adiabatics were measured and segmented into ten equally spaced distances. Lines were then drawn between the adiabatic connecting the terminus of each of the segments, these lines are considered isotherms; several isotherms are shown in Figure 9. Distances between isotherms measured at the midpoint, are considered to be the thicknesses (ΔX) of a stacking of slabs. The lengths of the isotherm is the distance (P) for use in equation 5.

Thermal thicknesses are now being determined by finite difference procedures using SINDA, a generally available library computer code, and are also being verified by testing specific evaporator and condenser tubes for use in the TRW OTEC design.

I.1.5 Shell Side Pressure Drop

The shell side pressure drop was determined by Carnegie-Mellon University using the Gunter-Shaw correlation (Gunter, A.Y. and Shaw, W.A., "A General Correlation of Friction Factors for Various Types of Surfaces in Crossflow", Trans. A.S.M.E., 67, 643 (1945)). These calculations are included elsewhere in the appendix. The Gunter-Shaw correlation was corrected using a correction factor determined experimentally at CMU. The equation was integrated across the tube bundle with due consideration for

the change in both flow and flow area across the bundle. The final equation obtained by CMU is, assuming no vapor lanes:

$$\Delta P = 6.36 \times 10^{-7} D^{2.855}$$

ΔP = pressure drop, #F/in.²

D = Bundle dia., ft

This equation is applicable to a 1-1/2 inch tube on a 1.25 pitch to diameter ratio with 9.02 ft³/(hr. ft. of tube) condensed on a one inch tube. The actual condensing rate in the TRW design is 7.44 ft³/(hr. ft. of tube). Since pressure drop across the bundle varies as the cube of the tube diameter, and as the 1.855 power of the vapor generated, corrections are conveniently made for tube diameter and flow differences, and the corrected equation becomes:

$$\Delta P_c = 3.189 \times 10^{-6} D^{2.855}$$

In the evaporator, the evaporation rate is 5.94 ft³/hr. ft. of tube). Pressure drop also varies with the 0.855 power of the density. The equation developed for the condenser, where flow is outward, is also applicable to the evaporator, where flow is inward. After correcting for diameter, flow differences and the higher density in the evaporator we obtain:

$$\Delta P_e = 2.805 \times 10^{-6} D^{2.855}$$

For the TRW design, assuming no vapor lanes, the pressure drop from bundle periphery to bundle center in the condenser is 0.031 psi and from center to periphery in the evaporator 0.027 psi. With these pressure drop values no flow distribution difficulties are expected.

Entrance and exit losses were calculated on the basis of K, or resistance coefficients, in the expression $\Delta P = KV^2\rho/2g$. $\Delta P, V, \rho$ and g are respectively the pressure drop, velocity, density and gravitational constant. K for an entrance was assumed to be 0.5 and an exit 1.

The total pressure drop in the evaporator is the sum of the entrance, distribution plenum crossing, orifice, bundle penetration and exit losses as diagrammed in Figure 11.

Total pressure drop in the condenser is the sum of the entrance and bundle penetration losses as diagrammed in Figure 11.

I.1.6 Evaporator and Condenser Dimensions

The tube bundle diameters for both the evaporator and condenser are determined by the required number of tubes.

The region between the condenser shell inlet and the condenser tube bundle, the vapor dome, was sized to have sufficient volume and flow areas to prevent the possibility of tube vibration due to high inlet velocities. The criterion for determining flow areas in this region was taken from the "Standards of Tubular Exchanger Manufacturers Association" (TEMA) which requires that at the inlet $\rho V^2 \leq 500$; ρ = density in lb/ft^3 and V is velocity in ft/sec . A shell diameter was then chosen which would accommodate this required flow area. Since vapor flow diminishes around the periphery of the tube bundle, a decreasing flow area, around the periphery, incorporating an eccentric shell was chosen. An impact baffle consisting of solid round bars was installed at the vapor inlet to disperse the inlet flow and prevent direct impingement on the tube.

A similar design procedure was followed for the evaporator except that a rod impact baffle is not required at the vapor outlet. A rod baffle was installed at the liquid inlet.

I.1.7 Non-Condensibles

I.1.7.1 Startup Removal

Initial non-condensable removal was determined by considering the system to resemble mixing tanks in series. $W(\text{lb}/\text{hr})$ of atmospheric ammonia enters the first tank. The tanks are initially full of nitrogen. The derivation was cognizant of density variation within the tanks due to the difference in molecular weight of ammonia and nitrogen. The expression for the concentration of non-condensibles in the effluent from the system

is given by the equations. The derivation of these equations is given later in the appendix.

$$\alpha = C_0 \rho_0 \left\{ 1 - e^{-PN} \sum_{i=1}^N \frac{(PN)^{N-i}}{(N-i)!} \right\}$$

$$C_{N.C.} = \frac{1 - \frac{\alpha}{\rho_0}}{1 + \alpha V_0 \left(\frac{1}{M_{N_2}} - \frac{1}{M_{NH_3}} \right)}$$

$C_{N.C.}$ = conc. of non-condensibles, lb_{N.C.}/lb mix in effluent from last tank

ρ_0 = density of ammonia entering = 0.04396 lb/ft³

C_0 = concentration of ammonia entering $\frac{1b_{NH_3}}{1b \text{ mix}} = 1$

V_0 = mole volume at purging conditions = 386 ft³

M_{N_2}, M_{NH_3} = molecular wt. of nitrogen and ammonia respectively, 28 and 17

P = number of purges

N = number of tanks in series

A plot of the exiting non-condensable concentration versus the number of purges is given in Figure 12, for several different "number of tanks" in series. The system is expected to operate as, or close to, three tanks in series. Approximately two to three purges should be sufficient to reduce the non-condensibles to a value which will permit pressurization of the system and further removal by the procedures for removing non-condensibles during normal operation. Figure 13 is a plot of non-condensable concentration in the exiting gas versus time if the system is being flushed at a rate of 1600 ft³/min. of atmospheric ammonia.

I.1.7.2 Operational Removal of Non-Condensibles

Non-condensable purging during operation was considered in the following manner. A leak is presumed to occur which ultimately results in the inlet vapor to the condenser entering with a constant concentration of non-condensable. This process continues to build up non-condensibles in

the condenser until "discovery time." Discovery is initiated by some evidence of degraded system operation. Discovery time and normalized concentration are related by the expression:

$$t_D = \beta/D \frac{\rho V}{W}$$

t_D = discovery time - hrs.

V = free condenser volume - ft³

W = vapor inlet rate - lb/hr

ρ = vapor density

β/D = normalized concentration, ratio of concentration of non-condensibles in condenser to concentration of non-condensibles in inlet vapor at discovery time.

Purging begins at discovery time, while non-condensibles continue to enter, and the ratio of tank to inlet concentration is given by the expression:

$$\beta = \left(\frac{W}{\rho V} t_D - \frac{1}{F} \right) \exp \left[- \frac{FW}{\rho V} (t - t_D) \right] + \frac{1}{F}$$


F = fraction of the inlet flow removed by the purging system

t = total time from initial entry of non-condensibles - hr.

Both the above equations are derived elsewhere in the appendix. Figures 14 and 15 are plots of tank concentration for discovery times of 0.25 and 0.5 hrs respectively. The parameter is $F \times 100$, the percent of the inlet flow purged. It is apparent that the shorter the discovery time (the greater the leak) the more difficult is recovery. Consideration of Figure 14 indicates that a 0.6 percent purge rate reduces condenser non-condensibles to about 37 percent of its discovery time value in 0.4 of an hour. Since the concentration after recovery is 37 percent of that value which made degraded system performance evident, it is presumed the system can continue to operate in a reasonable manner with purging until the leak is discovered and remedial steps taken.

The condenser purging system consists of an evacuation tube with holes, or orifices in the tube wall. The evacuation tube can remove considerably more than 0.6 percent of the inlet flow used in the above illustration. The evacuation is not limited by pressure drop since all the pressure within the condenser (approximately 75 psig) is available for flow. At a 0.6 percent withdrawal rate the velocity through the evacuation tube orifices is about 65 ft/sec. whereas the sonic velocity is about 1400 ft/sec. Pressure drop through the evacuation tube is at least two orders of magnitude less than pressure drop through the evacuation tube orifices, thus assuring uniform pick-up along its length. The evacuation tube has been positioned at the point where the non-condensibles have the greatest concentration, namely at the end of the vapor train (which is in the center of the condenser).

1.57-45-1.0



1.57-60-1.0





Figure 2.

1.57-45-1.5



157-60-15






Figure 4.

2-45-150



2-60-15






Figure 7. Composite condensing heat transfer coefficients for ammonia.

h_f VS. REYNOLDS NUMBER FOR FREON 11 IN THE EVAPORATOR




Figure 8. N_{Re} (Reynolds Number)

I-23

Table 1. ATTENUATION FACTORS ("CLEAN CONDITION")

	Evaporator	Condenser
Seawater, Convection	0.30	0.36
Metal Wall, Conduction	0.25	0.17
Ammonia, Convection	0.05	0.03

As an illustration, a 10% deviation of all the heat transfer coefficients in the evaporator (all in the same direction), would give a performance deviation of $(0.1 \times 0.30) + (0.1 \times 0.25) + (0.1 \times 0.05) = 0.06$, or a 6% deviation in performance.




Figure 9.

I-25




Figure 10.

TPD = TOTAL PRESSURE DROP
 IPD = INCREMENTAL PRESSURE
 DROP ALL PRESSURE DROPS
 ARE IN PSI




Figure 11.




Figure 12




Figure 13.




Figure 14.




Figure 15.

ATTACHMENT 1
INTRODUCTION

TASK 3

Provide final analysis of expected heat exchanger thermal/hydraulic performance to verify satisfaction of system requirements.

CONCLUSIONS

Requested analysis is satisfied by attachment 1. Within the scope of the present state of the art, the calculated thermal/hydraulic performance will satisfy system requirements.

CHECK PSD-I
EVAPORATOR and CONDENSER RATING

This enclosed analysis;

1. Determines the individual heat transfer coefficients on the tube, metal wall and shell side and the overall U for the evaporator.
2. Checks the heat flow in the evaporator with the computer results.
3. Determines the individual heat transfer coefficients on the tube, metal wall and shell side and the overall U for the condenser.
4. Checks the heat flow in the condenser with the computer results.
5. Checks the evaporation heat transfer coefficient and condensation heat transfer coefficient as calculated from the equations against the plotted values in the original references.
6. Summarizes all heat transfer coefficients, tube velocities and heat rates calculated for the evaporator and condenser and compares the values with the optimization program computer results.
7. Determines the tube side pressure drops for both the evaporator and condenser.
8. Determines the thermal thickness for the evaporator and condenser.

A summary of the results and a comparison with the results of the Computer calculation is given on page 8.

PREPARED J. Kaellis
 CHECKED _____
 MODEL _____

REPORT NO. _____

Check PSD-I Evaporator
 & Condenser rating

Evaporator

Tube side resistance

$$Nu = .027 Re^{.8} Pr^{.43} \cdot AR$$

$$w = 2.7348 \times 10^8 \text{ lb/hr.}$$

$$G = \frac{2.7348 \times 10^8}{42667 \times \frac{\pi (.87965)^2}{4}}$$

42667 tubes

$$D_w = .87965$$

$$\frac{\frac{\text{lb}}{\text{hr.}}}{\text{ft}^2}$$

$$\frac{1518749.8 \text{ lb}}{\text{hr. ft}^2} \times \frac{\text{ft}^3}{63.8 \text{ lb}} \times \frac{\text{hr.}}{3600 \text{ sec.}}$$

$$= 6.6125 \text{ ft}^3/\text{sec.}$$

$$G = 1518749.8 \text{ lb/hr. ft}^2$$

$$R = 63.8 \text{ lb/ft}^3 @ 75^\circ\text{F}$$

$$Re = \frac{.87965}{12} \times \frac{1518749.8}{2.387}$$

$$Vis = \frac{2.387 \text{ lb}}{\text{ft. hr.}} @ 75^\circ\text{F}$$

$$\frac{\text{ft.} \cdot \frac{\text{lb}}{\text{hr. ft}^2}}{\frac{\text{lb}}{\text{ft. hr.}}}$$

$$Re = 46640.425$$

$$h = .027 \frac{k}{D} Re^{.8} Pr^{.43} \cdot AR$$

$$Pr = 6.5306$$

@ 75°F

$$= .027 \times \frac{.3495}{(.87965)} \left(\frac{46640.425}{6.5306} \right)^{.8} \cdot AR$$

$$k = .3495 \text{ BTU/(hr. ft}^2\text{ }^\circ\text{F)} @ 75^\circ\text{F}$$

$$= .13072045 \times 1.46$$

$$AR = 1.46$$

$$h_{\text{tube}} = 1908.5185$$

$$r_{\text{tube}} = 5.23966 \times 10^{-4}$$

Heat Transfer
 Coefficient and
 Resistance Evaporator

6/11/78

PREPARED J. Kaellis

REPORT NO.

PAGE 2

CHECKED _____

Check PSD - I Evaporator
f Condenser Rating

MODEL _____

$$h_{\text{metal}} = \frac{11.5}{0.05623} \times 12 = 2454.2059$$

Evaporator metal heat transfer coefficient evaporator

thermal thickness see page 11

$$\frac{\text{DTU}}{\text{hr. ft}^2 \text{ } ^\circ\text{F/ft.}} \times \frac{12 \text{ in}}{\text{ft.}}$$

$$r_{\text{metal}} = 4.07463 \times 10^{-4}$$

metal heat transfer resistance evaporator

$$h_{\text{composite}} = \frac{(2.939 Re_T^{.4151} - 63.217) \times 10^5 - 5.633 Re_B^{1.8452}}{Re_T - Re_B}$$

(C.M.U. Tube A1)

$$Re_T = 5.2243 \times 10^3$$

$$Re_B = 2.0403 \times 10^3$$

From Attached computer sheet for Case No. 17

$$= 7655.6751$$

$$r_{\text{composite}} = 1.30622 \times 10^{-4}$$

(C.M.U. Tube A1)

$$R_0 = \frac{.065}{12(116)} = 4.66954 \times 10^{-5}$$

Evaporation heat transfer coefficient and resistance evaporator

$$r_{\text{evap}} = 1.30622 \times 10^{-4} - 4.66954 \times 10^{-5}$$

$$= 8.39265 \times 10^{-5}$$

$$h_{\text{evap}} = 11915.173$$

$$r_{\text{composite}} = 4.91389 \times 10^{-4}$$

(Ti tube)

$$h_{\text{composite}} = 2035.0451$$

(Ti tube)

$$f_{\text{oul}} = .0001 \text{ fouling factor}$$

$$Re_T \approx \frac{3.17508 \times 10^8}{Re_B^{1.44537}} = \frac{3.17508 \times 10^8}{(2.0403 \times 10^3)^{1.44537}}$$

$$= 5224.2332$$

Check Reynolds Number top of tube

6/11/78

PREPARED J. Kaellis
CHECKED _____
MODEL _____

REPORT NO.

Check PSD-I Evaporator
& Condenser Rating

Evaporator

$$R = \frac{D_w \Gamma_{\text{composite}} + \Gamma_{\text{tube}} + f}{D}$$

$$= \frac{87965 \times 4.9789 \times 10^{-4}}{.91} + 5.23766 \times 10^{-4} + .0001$$

$$R = 1.09896 \times 10^{-3}$$

$$U = 909.945$$

Total resistance and overall heat transfer coefficient evaporator

$$q = -(T-t) W C_p (1 - e^{-\frac{UA}{W C_p}})$$

T = 70

t = 80

W = 2.7348 x 10⁸ lb/hr. ← from computer cal. sheet

C_p = .9562 @ 75°C

U = 909.945

A = 26.5 x π ($\frac{.8725}{12}$) x 42467 = 260,385.33 ft²

$$\frac{909.945 \times 260,385.33}{2.7348 \times 10^8 \times .9562}$$

$$q = -(70-80) \times 2.7348 \times 10^8 \times .9562 (1 - e^{-\dots})$$

heat rate in evaporator

$$q = 1.55825 \times 10^9 \approx 1.5431 E+09$$

PREPARED J. Kaellis
 CHECKED _____
 MODEL _____

REPORT NO.

Check PSD - I Evaporator & Condenser Rating

Condenser

Tube side resistance

$$Nu = .027 Re^{.8} Pr^{.3} AR$$

$$W = 2.5262 \times 10^8 \text{ lb/hr.}$$

$$G = \frac{2.5262 \times 10^8}{43678 \times \frac{\pi}{4} \left(\frac{.889}{12}\right)^2} = 1341757.6 / 3678 \text{ tubes}$$

lb/hr./ft² Dw = .889

$$Re = \frac{.889}{12} \times 1,341,757.6$$

3.628

$$\frac{\text{ft.} \cdot \frac{\text{lb}}{\text{ft}^2 \cdot \text{hr.}}}{\frac{\text{lb}}{\text{ft}^2 \cdot \text{hr.}}}$$

$$1,341,757.6 \frac{\text{lb}}{\text{ft}^2 \cdot \text{hr.}} \times \frac{\text{ft}^3}{64.00 \text{ ft}^3} \times \frac{\text{hr.}}{3600 \text{ sec}}$$

= 5.8236 $\frac{\text{ft}^3}{\text{sec}}$

$P = 64.00 \frac{\text{lb}}{\text{ft}^3}$
 @ 45°F

$\nu = 3.628 \frac{\text{lb}}{\text{ft}^2 \cdot \text{hr.}}$
 @ 45°F

$$Re = 27398.533$$

$$k = .027 \frac{k}{D} Re^{.8} Pr^{.3} AR$$

$$= .027 \times \frac{.334}{\left(\frac{.889}{12}\right)} (27398.533)^{.8} (10.370214)^{.3} \cdot 1.46$$

$k = .334 \text{ BTU}/(\text{hr. ft}^2 \text{ } ^\circ\text{F})$
 @ 45°F

$Pr = 10.370214$
 @ 45°F

$$h_{\text{tube}} = 1375.6892$$

$$r_{\text{tube}} = 7.26908 \times 10^{-4}$$

heat transfer coefficient and resistance condenser

6/11/78

PREPARED J. Kaellis

REPORT NO.

PAGE 5

CHECKED _____

Check PSD - I Evaporator & Condenser Rating

MODEL _____

Condenser

$$h_{\text{metal}} = \frac{11.5}{0.04716} \times 12 = 2926.2066$$

$$r_{\text{metal}} = 3.41739 \times 10^{-4}$$

metal heat transfer coefficient and resistance
Condenser thermal thickness see page 13

$$h_{\text{composite}} = K_1 + \frac{K_2 \frac{P_{OR}}{P_{TRW}}}{\frac{Q}{A_{OR}} \frac{P_{OR}}{P_{TRW}} + K_3 \frac{P_{OR}}{P_{TRW}}}$$

(ORNL Tube Al)

$$h_{\text{comp}} \times \frac{P_{OR}}{P_{TRW}} = K_1 \frac{P_{OR}}{P_{TRW}} + \frac{K_2 \left(\frac{P_{OR}}{P_{TRW}}\right)^2}{\frac{Q}{A_{OR}} \frac{P_{OR}}{P_{TRW}} + K_3 \frac{P_{OR}}{P_{TRW}}}$$

(ORNL Tube Al)

$$h_{\text{comp}} = C_1 + \frac{C_2}{\frac{Q}{A_{TRW}} + C_3}$$

(ORNL Tube Al - based on TRW system - smooth tube equivalent)

$$h_{\text{comp}} = 3231.62 + \frac{3.684 \times 10^8}{\frac{Q}{A_{TRW}} + 20129.26}$$

(ORNL Tube AL-based on TRW system - smooth tube equivalent)

$$\frac{Q}{A_{TRW}} = \frac{1.4950E09}{43678 \pi \left(\frac{9.9}{12}\right) \times 29} = 4553.928 \frac{\text{BTU}}{\text{hr. ft}^2}$$

h_{comp}
(ORNL Tube AL - based on TRW system - smooth tube equivalent)

$$r_{\text{comp}} = 8.55171 \times 10^{-5}$$

Check PSD-I Evaporator & Condenser Rating

$$r_{cond} = 8.55171 \times 10^{-5} - \frac{\text{Condenser Thermal thickness } 0.03125}{\frac{12 \times 116}{2.24437 \times 10^5} \text{ Al conductivity}} = 6.30673 \times 10^{-5}$$

$$h_{cond} = 15856.053$$

$$r_{composit} = 6.30673 \times 10^{-5} + 3.47739 \times 10^{-4} = 4.04806 \times 10^{-4}$$

$$f_{owl} = .0001$$

Condensing heat transfer coefficient
fouling factor

$$h_{comp} = 2470.3167$$

composite condensing coefficient for Ti tubes

$$R = \frac{D_o}{D} r_{composit} + r_{owl} + f$$

$$R = \frac{.889}{91} \times 4.04806 \times 10^{-4} + 226908 \times 10^{-4} + .0001$$

$$R = 1.22237 \times 10^{-3}$$

$$U = 819.08109$$

overall resistance and heat transfer coefficient condenser

$$q = (T-t) w c_p (1 - e^{-\frac{UA}{w c_p}})$$

$$T = 50$$

$$t = 40$$

$$w = 2.5262 E+08$$

$$c_p = .9547 @ 45^\circ$$

$$U = 819.08109$$

$$A = 29 \times \pi \left(\frac{.889}{12}\right) \times 43679 = 294,802.47$$

$$q = (50-40) \times 2.5262 \times 10^8 \times .9547 \cdot \left(1 - e^{-\frac{819.08109 \times 294802.47}{2.5262 \times 10^8 \times .9547}}\right)$$

$$q = 1.5245 \times 10^9 \approx 1.495 \times 10^9 \checkmark$$

heat rate condenser

PREPARED J. Krollis
 CHECKED _____
 MODEL _____

REPORT NO.

PAGE 7

Check PSD-I Evaporator
 & Condenser Rating

- Check evaporator equation

$$Re_T = 5.2243 \times 10^3$$

$$Re_B = \frac{2.0403 \times 10^3}{2L}$$

$$\frac{2.0403 \times 10^3}{3632.3}$$

Sally Ann Ward's Thesis

$$h_{comp} \approx 11,000 \text{ (Composite)} \times .8 = 8800.$$

cal. 7655.6751 accept

Check Condenser Equation

$$q'' = \frac{Q}{A_{TRW}} = 4553.824 \frac{\text{BTU}}{\text{hr ft}^2}$$

$$q''_{ORNL} = 4553.824 \times \frac{P_{TRW}}{P_{OR}} = 4553.824 \times \frac{2454}{41667} = 2692.001$$

$$h_{ORNL} \approx 6500$$

Composite

$$h_{TRW} = 6500 \times \frac{P_{OR}}{P_{TRW}} = 6500 \times \frac{41667}{2454} = 11036.491 \approx 11697.566 \text{ cal.}$$

PREPARED J. Kallias
 CHECKED _____
 MODEL _____

REPORT NO. _____

Check PSD-I Evaporator
 & Condenser Rating

Summary:

	$T_{in} \text{ vel}$	h_{tube}	k_{total}	h_{evap}	U	q
Evap Cal.	6.6125	1908.5185	2456.2	11915.2	909.945	1.55825×10^9
Computer	6.614	1939.05	2302.6	11915.3	895.524	1.5431×10^9
Cond Cal.	5.8236	1375.69	2926.21	15856.05	818.08	1.5245×10^9
Computer	5.8228	1349.84	2774.56	15421.61	796.018	1.4950×10^9

P.D. tube side

Evaporator

$Re = 46640.425$ say $\frac{L}{D} = 0.0026$

$f = .021 \times 1.46 = .03066$

$f_p = e \left[\frac{.025 (\ln Re)^2}{2.699117} - .7534 (\ln Re) + 1.386 \right]$

$f_p = .0216396 \times 1.46 = .0318659$

$h = f \left(\frac{L}{D} \right) \frac{v^2}{2g}$

$\Delta P = f \left(\frac{L}{D} \right) \frac{v^2 \rho}{2g} = f \frac{L}{D} \frac{G^2}{2g\rho}$

$= .0319 \times \frac{30}{\frac{.8765}{12}} \times \frac{1519745.8^2}{64.4 \times 63.8} \times \frac{1}{144} \times \frac{1}{3600^2}$

$\frac{\frac{h}{\rho}}{\frac{h}{\rho}} = \frac{16}{h \rho} \times \frac{G^2}{\rho} \times \frac{L}{D} \times \frac{h}{3600^2 \rho}$

$= 3.927199 \text{ Psi}$

E.E. losses $= 1.5 \frac{v^2}{2g} = 1.5 \frac{v^2 \rho}{2g\rho} = \frac{1.562}{2g\rho}$
 $K = .5 \text{ enter } K = 1. \text{ exit } K_{total} = 1.5$

Check PSD-I Evaporator & Condenser Rating

$$h_L = 1.5 \frac{G^2}{29 P^2}$$

$$\Delta P = 1.5 \frac{G^2}{29 P^2} \times \frac{1}{3600^2 \times 144}$$

$$\frac{16^2}{144} \times \frac{50^2}{144} \times \frac{16^2}{3600^2} \times \frac{1}{144}$$

$$\Delta P = 1.5 \times \frac{1519749.6^2}{64.4 \times 67.8} \times \frac{1}{3600^2} \times \frac{1}{144}$$

$$= .45122 \text{ psi}$$

$$\Delta P_{\text{total}} = 3.927188 + .45122 = 4.3784 \text{ psi} \quad \text{compare } 4.115$$

$$4.3784 \frac{16}{144} \times \frac{1}{63.816} \times \frac{144}{144} = 9.882 \frac{1}{144}$$

tube side pressure drop including entrance & exit losses but not nozzle losses evaporator

P.D. Condenser tube side

$$Re = 27398.533 \quad \frac{L}{D} = .00006$$

$$f = .024 \times 1.46 = .03504$$

$$f_p = e \left[\frac{.025 \times (\ln Re)^2}{2.6102902} - .7534 (\ln Re) + 1.3867 \right]$$

$$f_p = .02467 \times 1.46 = .0360205$$

$$\Delta P = .036 \left(\frac{30}{12} \right) \times \frac{1,341,757.76^2}{64.4 \times 64} \times \frac{1}{144} \times \frac{1}{3600^2}$$

$$\Delta P = 3.4121 \text{ psi}$$

$$E.E. \text{ loss} = 1.5 \frac{G^2}{29 P^2} = \frac{1}{3600^2 \times 144} = 1.5 \frac{1,341,757.76^2}{64.4 \times 64} \times \frac{1}{3600^2 \times 144}$$

$$= .35108$$

$$\Delta P_{\text{total}} = 3.76314 \text{ psi} \quad \text{compare } 3.6 \quad 3.76318 \times \frac{1}{64} \times 144 = 9.467$$

Tube side pressure drop including entrance and exit losses but not nozzle losses condenser

Tube Geometric Properties

Page 10

$$\text{Diameter to center of circle} = 0.86 + 2 \times 0.037 \\ = 0.934''$$

$$\text{Area 1} = \pi (0.467)^2 = 0.68515 \text{ in}^2$$

$$\text{area without semi-circle} = 0.68515 - 1/2 \times \pi \times (0.037)^2 \\ = 0.60773 \text{ in}^2$$

$$R_w^2 = \frac{0.60773}{\pi} \quad , \quad R_w = 0.4398$$

$$D_w = 0.87965''$$


$$\text{arc} = 1.41372 \times 0.037 + 1.53589 \times 0.0025 \\ = 0.056147$$

$$\frac{x}{\pi} = \frac{81}{180} \quad \text{arc based on } D_w = 0.038382$$

$$AP = \frac{0.056147}{0.038382} = 1.46$$

ΔY	P	Normal thickness	ΔY	$\frac{\Delta Y}{P}$
$\frac{3}{8}$.375	$1\frac{3}{8}$ 1.375		.26125	.2045454
$\frac{3}{16}$.1875	$1\frac{7}{16}$ 1.4375		.21475	.1521739
$\frac{1}{4}$.25	$1\frac{9}{16}$ 1.5625		.21875	.14
$\frac{3}{16}$.1875	$1\frac{23}{32}$ 1.71875		.171875	.1
$\frac{5}{32}$.15625	$1\frac{3}{4}$ 1.75		.125	.0714285
$\frac{3}{32}$.09375	$1\frac{3}{4}$ 1.75		.21875	.125
$\frac{1}{32}$.3125	$2\frac{3}{16}$ 2.1875		.296875	.1357142
$\frac{1}{4}$.25	$2\frac{1}{4}$ 2.25		.21875	.097222
$\frac{3}{16}$.1875	$2\frac{3}{16}$ 2.1875		.203125	.0928571
$\frac{7}{32}$.21875	$2\frac{1}{4}$ 2.25		.390625	.1736111
$\frac{9}{16}$.5625				<u>1.2925522</u>

$$\sum \frac{\Delta Y}{P} \times \frac{\text{Pitch}}{2} = 1.2925522 \times .0435 = .056226$$



I-43

Thermal Thickness for Condenser

for 0.031" thickness

$$\text{thermal thickness} = 0.05623''$$

for 0.026" thickness

$$\frac{t_{\text{wall}_1}}{t_{\text{wall}_2}} = \frac{t_{d_1}}{t_{d_2}}$$

$$\begin{aligned} \text{the thermal thickness} &= \frac{0.026}{0.031} \times 0.05623 \\ &= 0.04716'' \end{aligned}$$

CASE NO 17

	W WATER PIPE	C WATER PIPE
16TH FEET	300	2900.0000
METER FT	15.0975	15.2525
NUMBER OF PIPES	1	1
H2O VEL FT/S	6.0000	6.0000
WATER FLOW LB/HR	2.7348E+08	2.5262E+08
PRESSURE DROP PSI	.5577	3,0504
	EVAPORATOR	CONDENSER
BOTTOM REYNOLDS NUM	2.0403E+03	2.7510E+03
TOP REYNOLDS NUM	5.2243E+03	0.0
HEAT TRAN LENGTH FT	26.5000	29.0000
TOTAL LENGTH FT	30.0000	30.0000
SHELL DIAM FT	24.9483	25.2422
TUBE DIAMETER IN	.9900	.9900
NUMBER TUBES	42667	43678
TUBE MAT COST \$/FOOT	1.6500	1.3100
WATER TUBE VEL FT/SEC	6.6140	5.8228
NH3 ENT FLOW CFS		2.5943E+03
NH3 EXIT FLOW CFS	1.8666E+03	2.0691E+01
HEAT TRAN AREA SQ. FT.	2.6039E+05	2.9481E+05
HEAT TRANSFERED BTU/H.	1.5431E+09	1.4950E+09
OVERALL BTU/HR/F/FT**2	-895.5240	796.0179
NH3 HTC BTU/HR/F/FT**2	11915.3145	15421.6060
WALL HTC BTU/HR/F/FT**2	2302.5576	2774.5603
WATER HTC BTU/HR/F/FT**2	1939.0474	1349.8842
H2O AREA RATIO	1.4600	1.4600
FULING (FT**2 HR F/BTU)	1.0000E-04	1.0000E-04
ENTRANCE TEMP F	80.0000	40.0000
CHANGE IN WATER TEMP	5.9000	6.2000
PRESSURE DROP PSID	4.1150	3.6098
NH3 OUTLET TEMP F	70.0000	50.0000
NH3 OUTLET PRES PSIA	128.7997	89.1924

MAY 18 1978

GREGORY S. GIBSON

CYCLE DATA

GROSS POWER MW	1.4032E+01
WW PUMPS MW	1.3514E+00
NH3 PUMPS MW	4.0766E-01
TUR ENTHAL BTU	1.6813E+01
PLANT EFF	2.3217E-02

NET POWER MW	1.0500E+01
CW PUMPS MW	1.7731E+00
EVAPOR (LB/HR)	8.0715E+02
TUR EX QUALITY	2.4553E-02

LB/Sec w/...

COST BREAKDOWN (\$)

EVAP HE COST	4.8252E+06
WW PUMP COST	4.5070E+05
NH3 R PUMP	1.0394E+05
GEN COST	6.2274E+05
CW PIPE	1.4591E+06
TOTAL SYSTEM	1.4425E+07

CON HE COST	4.1391E+06
CW PUMP COST	4.1885E+05
NH3 F PUMP	8.0886E+04
TURBINE COST	8.2473E+05
MISCEL	1.5000E+06
TOTAL BOTH HE	8.9643E+06

EVAPORATOR

PART	MATERIAL	LABOR
TUBES	2.1120E+06	1.1905E+06
CLAD	0.	0.
UNCLAD	7.7713E+04	3.0886E+05
PLATES	1.0071E+04	5.9842E+04
SHELL	7.0431E+04	2.2675E+05
BOXES	1.2459E+04	1.9359E+05
NOZZLES	9.9773E+03	7.7768E+04
PORT	2.3415E+04	1.1471E+05
STILE	1.7091E+04	1.9405E+05
INLETS	1.0886E+04	7.9390E+04
SUPPORT	3.5777E+03	3.2076E+04
EACH TOTAL	2.3335E+06	5.0776E+06

CONDENSER

PART	MATERIAL	LABOR
TUBES	1.7165E+06	1.2187E+06
CLAD	0.	0.
UNCLAD	8.0059E+04	3.2173E+05
PLATES	1.0437E+04	6.1685E+04
SHELL	7.2345E+04	2.3118E+05
BOXES	1.2769E+04	1.9661E+05
NOZZLES	1.0084E+04	7.8998E+04
PORT	0.	0.
STILE	0.	0.
INLETS	1.1050E+04	8.0580E+04
SUPPORT	3.6663E+03	3.2579E+04
EACH TOTAL	1.9170E+06	2.2221E+06

PREPARED Joe Kaellis
 CHECKED _____
 MODEL _____

REPORT NO. _____
 PAGE _____

Method of calculating attenuation factors

Basic Equation

$$q = (T-t) w c_p (1 - e^{-\frac{UA}{w c_p}})$$

$$\frac{dq}{d \cdot h_x} = \frac{dq}{dU} \frac{dU}{dh_x}$$

$$\frac{dq}{dU} = (T-t) w c_p (-) e^{-\frac{UA}{w c_p}} \frac{(-) A}{w c_p} = (T-t) e^{-\frac{UA}{w c_p}} A$$

$$U = \frac{1}{\frac{1}{h_{sw}} + \frac{1}{h_{metal}} + \frac{1}{h_{NH_3}}}$$

$$\frac{dU}{dh_x} = (-) \frac{1}{\left(\frac{1}{h_{sw}} + \frac{1}{h_{metal}} + \frac{1}{h_{NH_3}}\right)^2} \frac{(-)}{h_x}$$

$$\frac{dU}{dh_x} = U^2 \frac{1}{h_x^2}$$

$$\frac{dq}{dh_x} = (T-t) e^{-\frac{UA}{w c_p}} UA \frac{U}{h_x^2}$$

$$dq = (T-t) e^{-\frac{UA}{w c_p}} UA \frac{U}{h_x^2} dh_x$$

$$\frac{dq}{q} = \frac{(T-t) e^{-\frac{UA}{w c_p}} UA \frac{U}{h_x^2} \frac{dh_x}{h_x}}{(T-t) w c_p (1 - e^{-\frac{UA}{w c_p}}) \frac{U}{h_x}} \frac{dh_x}{h_x}$$

$$\frac{dq}{q} = \left(\frac{UA}{w c_p} \frac{e^{-\frac{UA}{w c_p}}}{(1 - e^{-\frac{UA}{w c_p}})} \frac{U}{h_x} \right) \frac{dh_x}{h_x}$$

attenuation factor $\alpha_x = \frac{UA}{w c_p} \frac{e^{-\frac{UA}{w c_p}}}{(1 - e^{-\frac{UA}{w c_p}})} \frac{U}{h_x}$
 % variation in $q = \alpha_x \times (\% \text{ variation in } h_x)$

7/17/78

PREPARED

J. Kaellis

REPORT NO.

PAGE

CHECKED

MODEL

Vapor
P.D. through tube bundle1. Description

Determine the shell side pressure drop in the evaporator and condenser

2. Assumptions made

Gunter - Shaw equation used by CMU
The equation was integrated across the tube bundle by CMU.

3. Input data used

Basic equation was derived by CMU -
submitted by CMU on 17 October 1977

4. Strategy

CMU equation used

5. Equations

Pressure drop as a function of tube bundle diameter is given for the following conditions

Tube overall dia 1.5 inches

Tube length 25 ft.

Seawater vel. 6 ft/sec.

Seawater inlet temp 40°F

Ammonia saturation temp. 50°F

Triangular pitch dia. 1-7/8 inches (1.25 x 1.5 = 1.875)

7/17/78

PREPARED J. Koellis

REPORT NO.

PAGE

CHECKED

MODEL

Vapor
P.D. through Tube bundle

Basis: No vapor lanes, feed passes from periphery
to center

$$\frac{9.02 \text{ ft}^3}{\text{hr. ft. of tube}} \text{ for a 1.5 inch tube}$$

$$\Delta P = 6.36 \times 10^{-7} D^{2.855}$$

ΔP = press drop

D = tube bundle diameter in feet

The correction for a 1" tube bundle is

$$\frac{\Delta P_1}{\Delta P_2} = \left(\frac{\text{O.D. tube 1}}{\text{O.D. tube 2}} \right)^3$$

thus for a 1" tube bundle

$$\Delta P = 2.147 \times 10^{-6} D^{2.855}$$

$$9.02 \times \left(\frac{1}{1.5} \right)^3 = 6.0133 \frac{\text{ft}^3}{\text{hr. ft. of tube}} \text{ condensed}$$

TRW Design Condenser

$$\frac{807 \frac{\text{lb}}{\text{Sec.}}}{43678 \text{ tubes} \times 29 \text{ ft.}} \times \frac{3600 \text{ Sec}}{\text{hr.}} \times \frac{3.245 \text{ ft}^3}{\text{lb}} @ 50^\circ \text{F} = 7.44269$$

Correcting for the increased vapor generation
in the TRW Design

$$\Delta P = 2.147 \times 10^{-6} \left(\frac{7.44269}{6.0133} \right)^{1.855} \times D^{2.855}$$

$$\Delta P = 3.18867 \times 10^{-6} D^{2.855} \text{ Condenser}$$

7/17/74

PREPARED

J. Kaellis

REPORT NO.

PAGE

CHECKED

MODEL

Vapor P.D. through
Tube Bundle

$$\Delta P \sim \rho \times \rho^{-.145} \sim \rho^{.855} \sim V^{-.855}$$

TRW Design Evaporator

$$\frac{807 \frac{\text{lb}}{\text{sec.}}}{42667 \times 26.5} \times \frac{3600 \text{ sec}}{\text{hr.}} \times \frac{2.312 \text{ ft}^3}{\text{lb}} = 5.94054 \frac{\text{ft}^3}{\text{hr. ft. of tube}}$$

$$\Delta P = 2.147 \times 10^{-6} \left(\frac{5.94054}{6.0133} \right)^{1.855} \left(\frac{2.312}{3.245} \right)^{-.855} D^{2.855}$$

$$\Delta P = 2.8044 \times 10^{-6} D^{2.855} \text{ Evaporator}$$

Say both a 25 ft. bundle

$$\Delta P_{\text{condenser}} = 3.1887 \times 10^{-6} (25)^{2.855} = .03124 \text{ psi}$$

$$\Delta P_{\text{evaporator}} = 2.8044 \times 10^{-6} (25)^{2.855} = .02748 \text{ psi}$$

(assuming no vapor lanes)

6. Results and Conclusions

Pressure drop of vapor penetrating the condenser bundle is less than .031 psi

Pressure drop of vapor penetrating the evaporator bundle is less than .027 psi

PREPARED J. Kallin

REPORT NO.

PAGE

CHECKED _____

Vapor P.D. through
Tube Bundle

MODEL _____

Peripheral vel. in evap

$$\frac{807 \text{ lb}}{\text{sec}} \times \frac{2.312 \text{ ft}^3}{\text{lb}} = 1865.784 \frac{\text{ft}^3}{\text{sec}}$$

Dia bundle $272\frac{1}{2}$ inches

$$\pi (272.5) \times \frac{.25}{1.25} = \overset{\text{minimum}}{\text{free inches}} = 171.216 \text{ inches}$$

escape area around bundle

$$\frac{171.216}{12} \times 26.5 \text{ ft.} = 378.102 \text{ ft}^2$$

length

$$\text{peripheral vel} = \frac{1865.784}{378.102} = 4.934 \frac{\text{ft}}{\text{sec}}$$

Too low for
vapor to shear off
liquid

PREPARED

J. Kaehler

REPORT NO.

PAGE 1

CHECKED

J/N 3442-82

P.D. in Evaporator Shell

1. Description / definition of issue

Determine the pressure drop in the distributing plenum of the evaporator for an assumed uniform flow distribution.

Determine the required pressure drop through the orifice to maintain this uniform distribution.

Determine the pressure drop to vapor formation and movement of this vapor to outside the tube bundle.

Determine total pressure drop from liquid entering the distribution plenum to vapor in the exit nozzle

2. Assumptions made - 3. Input source data used

Data used ^{is that} for pressure drop across the distributing plenum as determined by CMV using the Guntter, Shaw correlation and corrected for the TRW design

4. Method / strategy / logic applied

Method of Guntter, Shaw used and the pressure drop across the bundle was integrated

ΔP THROUGH EVAPORATOR DISTRIBUTING CHAMBER-

		ΔP AS FUNCTION OF BUNDLE DIA. FT. OF NH_3 LIQUID - FOR $1\frac{1}{2}$ " O.D.			
NR	D (FT.)	BUNDLE DIA. FT.			
		18	25	35	50
0	1	.626	~	~	~
	2	.173	.440	1.15	~
	3	.082	.207	.541	1.50
1	1	.756	~	~	~
	2	.209	.973	~	~
	3	.099	.459	2.23	~
3	1	.068	.278	~	~
	2	.019	.077	.349	1.82
	3	.008	.037	.164	.857
5	1	.029	.140	.377	~
	2	.015	.039	.104	.470
	3	.007	.018	.049	.222

NR = NUMBER OF TUBE ROWS REMOVED
FROM EACH OF 6 RADIAL LANES

D = DEPTH OF DISTRIBUTION PLENUM

DATA IS FOR $1\frac{1}{2}$ " TUBES ON P/D RATIO OF 1.25
CORRECT FOR DIFFERENT P/D RATIO WITH
THE FOLLOWING CORRECTION FACTOR

P/D	CORRECTION FACTOR
1.25	1.
1.375	.346
1.5	.168
1.625	.1029
1.75	.0648

CORRECT FOR DIFFERENT TUBE O.D.

$$\Delta P_{O.D.} = \Delta P_{1\frac{1}{2}} \left(\frac{1.5}{O.D.} \right)^{4.855}$$

5. Equations and Calculations

Pressure drops are tabulated on page 2 for the following conditions:

1 1/2" tubes P/D 1.25

$$\frac{424.5 \text{ lb}}{\text{hr. ft. of tube circumference}}$$

$$\frac{166.7 \text{ lb}}{\text{hr. (from MV)}} \times \frac{1}{\pi(1.5) \text{ in}} \times \frac{12 \text{ in}}{\text{ft.}} = 424.5$$

Assume a $Re_{TOP} = 5000. = \frac{4 \Gamma}{\mu}$

$\mu = .359 \frac{\text{lb}}{\text{ft. hr.}} @ 70^\circ \text{F}$

$\Gamma = \frac{5000 \times .359}{4} = 448.75 \frac{\text{lb}}{\text{hr. ft. of tube circumference}}$

Correction factor to data on page 2

$$\left(\frac{1.5}{1.}\right)^{4.855} \left(\frac{448.75}{424.5}\right)^{1.855} = 7.9374$$

Choose a 2 ft. bundle ^{height} with 6 radial lanes 3 tube row removed from each radial lane

$P_{10.5}^{D_{10.5}}$ on page 2 = .077 ft of NH₃ (for a 25 ft. Bundle)

$.077 \times 7.9374 = .6118 \text{ ft. NH}_3$

PREPARED J. Kaellis
 CHECKED _____
 MODEL _____

REPORT NO.

P.D. in Evaporator Shell

$$.61118 \frac{\text{ft}}{\text{ft}^2} \times \frac{38.16}{\text{ft}^2} \times \frac{\text{ft}^2}{144 \text{ in}^2} = .16128 \text{ psi}$$

Pressure drop in crossing bundle for a uniform flow is .16128 psi

orifice pressure drop - say 4 to 5 times greater

$$.16128 \times 4.5 = .72576$$

say .72

$$\text{Total Press. Drop to under orifice} = .16128 + .72 = .88128$$

$$\text{Total Press. Drop to outside bundle} = .88128 + .027 = .90828$$

↑
previous cal.

P.D. vapor exiting
 assume .5 vel heads

$$h = .5 \frac{v^2}{2g}$$

$$\Delta P = .5 \frac{v^2 \rho}{2g} = \frac{.5 G^2}{2g\rho}$$


110" outlet

$$\frac{.807 \frac{\text{lb}}{\text{sec}}}{\frac{\pi (110)^2 \text{ in}^2}{4}} = .0849177 \frac{\text{lb}}{\text{sec} \cdot \text{in}^2} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 12.22815$$

$$\Delta P = \frac{.5 \times 12.22815^2}{64.4} \times 2.312 \times \frac{1}{144} = .0186393$$

$$\frac{\frac{167}{500} \frac{\text{ft}^4}{\text{ft}^2}}{\frac{\text{ft}^2}{500}} \times \frac{\text{ft}^5}{\text{ft}^6} = \frac{16}{\text{ft}^2} \times \frac{\text{ft}^2}{144 \text{ in}^2}$$

Total Press Drop to vapor outlet from liquid inlet = 908287.018693
= 9269193



added 7/21/78

P.D. liquid entering

$$h = K \frac{v^2}{2g} \quad K=1.$$

$$\Delta P = K \frac{v^2 \rho}{2g} = \frac{K G^2}{2g \rho}$$

$$W = 111.7 \text{ lb/hr. tube} \times 42667 \text{ tubes} = 4.766 \times 10^6 \text{ lb/hr.}$$

$$G = \frac{1323.86 \text{ lb/sec.}}{976 \text{ in}^2} \times \frac{144 \text{ in}^2}{\text{ft}^2} = 195.77 \frac{\text{lb}}{\text{sec. ft}^2}$$

Tube Turns = 36" std pipe

$$\Delta P = 1. \times \frac{195.77^2}{64.4 \times 36} \times \frac{1}{144}$$

$$\Delta P = .109 \frac{\text{lb}}{\text{ft}^2} \times \frac{\text{ft}^2}{\text{ft}^2} = \frac{1 \text{ lb}}{\text{ft}^2} \times \frac{\text{ft}^2}{144 \text{ in}^2}$$

Total ΔP include entrance & exit = $927 + .109 = 1086 \text{ PSI}$
= 1.036 PSI

PREPARED

J. Kaelis

REPORT NO.

PAGE

CHECKED

J/N

3442-82

START-UP NON-CONDENSABLE
Removal

STATEMENT OF PROBLEM

DETERMINE THE RATE AND QUANTITY OF AMMONIA REQUIRED TO PURGE THE SYSTEM OF NON-CONDENSABLES PRIOR TO START-UP


APPROACH

THE EQUATION GIVING THE CONC. OF NON-CONDENSABLES IN THE EFFLUENT FROM "N" MIXING TANKS IN SERIES WAS DEVELOPED. FIGURE 1 GIVES THE EFFLUENT CONCENTRATION VERSUS THE NUMBER OF PURGES FOR THE SPECIFIED NUMBER OF SERIES TANKS. PURGING PROCEDURE, PRESUMING THREE SERIES TANKS AND 1600 CFM OF AMMONIA ENTERING, IS DESCRIBED IN FIGURE 2.

CONCLUSION

APPROXIMATELY 3482 POUNDS OF AMMONIA IS REQUIRED TO REDUCE NON-CONDENSABLE CONCENTRATION TO LEVELS WHICH CAN BE REMOVED BY THE CONDENSER EVACUATION TUBE. THE OPERATION REQUIRES APPROXIMATELY .85 HRS.

Consider N mixing tanks in series



inlet - outlet = accumulation

$$C_{n-1}v - C_n v = \frac{dV P_n C_n}{dt}$$

$$\frac{\text{lb NH}_3}{\text{lb mix}} \times \frac{\text{ft}^3}{\text{hr}} \times \frac{\text{lb mix}}{\text{ft}^3} = \frac{\text{ft}^3 \text{ lb mix}}{\text{ft}^3 \text{ lb mix}} \frac{\text{lb NH}_3}{\text{lb mix}}$$

v = flow rate $\frac{\text{ft}^3}{\text{hr}}$

V = tank volume = ft^3

$$\text{Molar volume} = 359 \times \frac{(460+70)}{492} \times \frac{14.7}{14.7} = 386.7264$$

$$P_n = \frac{1}{386.7264 \left(\frac{1-C_n}{\text{M.W. N.C.}} + \frac{C_n}{\text{M.W. NH}_3} \right)}$$

$$= \frac{1}{\frac{\text{ft}^3}{\text{lb mole}} \left(\frac{\text{lb mix}}{\text{lb mole N.C.}} + \frac{\text{lb mix}}{\text{lb mole NH}_3} \right)}$$

$$= \frac{1}{\frac{\text{ft}^3}{\text{lb mole}} \left(\frac{\text{lb moles N.C.}}{\text{lb mix}} + \frac{\text{lb moles NH}_3}{\text{lb mix}} \right)}$$

$$= \frac{\text{lb mix}}{\text{ft}^3}$$

PREPARED J. Kaellis

REPORT NO.

PAGE 2

CHECKED _____

Start-up Non-Condensable Removal

MODEL _____

$$P = \frac{1}{386.72764 \left(\frac{1-C_N}{28} + \frac{C_N}{17} \right)}$$

Mo. wt. N.C. = 28

Mo. wt. NH₃ = 17

$$C_N P_N = \frac{C_N}{386.72764 \left(\frac{1-C_N}{28} + \frac{C_N}{17} \right)}$$

$C_1 = C_2 = C_3 = \dots = C_n = \dots = 0$ at time = 0

$C_0 = 1$ inlet to first tank at all time = 1.

$$C_0 P_0 = \frac{1}{386. \left(\frac{1-1}{28} + \frac{1}{17} \right)} = \frac{17}{386} = .0439585 = \alpha_0 \frac{\text{lb NH}_3}{\text{mi}^3}$$

$$V (C_{N-1} P_{N-1} - C_N P_N) = V \frac{dC_N P_N}{dt}$$

$$V (d_{N-1} - d_N) = V \frac{d\alpha_N}{dt}$$

Start-up Non-Condensable
Removal

For N tanks

$$(\alpha_0 - \alpha_1) = \frac{V}{N} \frac{d\alpha_1}{dt}$$

$$(\alpha_1 - \alpha_2) = \frac{V}{N} \frac{d\alpha_2}{dt}$$

$$(\alpha_{N-1} - \alpha_N) = \frac{V}{N} \frac{d\alpha_N}{dt}$$

La place transform

$$\frac{d_0}{s} - \alpha_1 = \frac{V}{N} (s\alpha_1 - 0)$$

$$\alpha_1 - \alpha_2 = \frac{V}{N} (s\alpha_2 - 0)$$

$$\alpha_{N-1} - \alpha_N = \frac{V}{N} (s\alpha_N - 0)$$

$$\frac{d_0}{s} = \left(\frac{V}{N}s + 1\right) \alpha_1$$

$$\alpha_1 = \left(\frac{V}{N}s + 1\right) \alpha_2$$

$$\alpha_{N-1} = \left(\frac{V}{N}s + 1\right) \alpha_N$$

$$\alpha_1 = \frac{d_0}{s \left(\frac{V}{N}s + 1\right)}$$

$$\alpha_2 = \frac{\alpha_1}{\left(\frac{V}{N}s + 1\right)}$$

$$\alpha_N = \frac{\alpha_{N-1}}{\left(\frac{V}{N}s + 1\right)}$$

PREPARED J. Kaellis
CHECKED _____
MODEL _____

REPORT NO. _____ PAGE 4
start-up Non-condensable Removal

$$\alpha_N = \frac{\alpha_0}{s} \frac{1}{(1 + \frac{v}{v} s)^N}$$

$$= \frac{\alpha_0}{s (\frac{v}{v})^N (\frac{v}{v} + s)^N}$$

Inverse Laplas transform

$$\alpha_N = \frac{\alpha_0}{(\frac{v}{v})^N} \int_0^t L^{-1} \frac{dr}{(s + \frac{v}{v})^N}$$

$$\alpha_N = \frac{\alpha_0}{(\frac{v}{v})^N} \int_0^t e^{-\frac{v}{v} r} (L^{-1} \frac{1}{s^N}) dr$$

$$\alpha_N = \frac{\alpha_0}{(\frac{v}{v})^N} \int_0^t e^{-\frac{v}{v} r} \frac{v^{N-1}}{(n-1)!} dr$$

$$\alpha_N = \frac{\alpha_0}{(n-1)!} \int_0^t e^{-\frac{v}{v} r} (\frac{v}{v} r)^{n-1} d(\frac{v}{v} r)$$

$$\frac{v}{v} r = \beta$$

$$\alpha_N = \frac{\alpha_0}{(n-1)!} \int_0^{\frac{v}{v} t} e^{-\beta} \beta^{n-1} d\beta$$

No. 403 Peirce

$$\int x^m e^{ax} dx = e^{ax} \left[\frac{x^m}{a} - \frac{m x^{m-1}}{a^2} \right.$$

$$\left. + \sum_{i=3}^{m+1} (-1)^{i+1} \frac{m(m-1)\dots(m-i+2)}{a^i} x^{m-i} \right]$$

PREPARED

J. Kaellis

REPORT NO.

PAGE 5

CHECKED

MODEL

Start-up non-condensable Removal

$$\alpha_N = \frac{\alpha_0}{(m-1)!} \int_0^{\left(\frac{v}{V}t\right)} e^{-\beta} \beta^{m-1} d\beta$$

$$a = -1 \quad m = N-1$$

$$\alpha_N = \frac{\alpha_0}{(N-1)!} \left\{ e^{-\beta} \sum_{i=1}^N (-1)^{i+1} \frac{(N-1)!}{(N-1-i+1)!} \frac{\gamma^{N-1-i+1}}{(-1)^i} \right\}^{\frac{v}{V}t}$$

$$= \frac{\alpha_0}{(N-1)!} \left\{ - e^{-\beta} \sum_{i=1}^N \frac{(N-1)!}{(N-i)!} \gamma^{N-i} \right\}^{\frac{v}{V}t}$$

$$\alpha_N = \frac{\alpha_0}{(N-1)!} \left\{ - e^{\frac{v}{V}t} \sum_{i=1}^N \frac{(N-1)!}{(N-i)!} \left(\frac{v}{V}t\right)^{N-i} \right.$$

$$\left. + e^0 \sum_{i=1}^N \frac{(N-1)!}{(N-i)!} (0)^{N-i} \right\}$$

Now

$$\sum \frac{(N-1)!}{(N-i)!} (0)^{N-i} = \frac{(N-1)!}{(N-1)!} (0)^{N-1} + \frac{(N-1)!}{(N-2)!} (0)^{N-2}$$

$$+ \dots + \frac{(N-1)!}{(N-(N-1))!} (0)^{N-(N-1)}$$

$$+ \frac{(N-1)!}{(N-N)!} (0)^{N-N}$$

$$= 0^{N-1} + (N-1) (0)^{N-2} + \dots + \frac{(N-1)!}{1!} 0^1 + \frac{(N-1)!}{0!} (0)^0$$

Thus

$$\sum_{i=1}^N \frac{(N-1)!}{(N-i)!} (0)^{N-i} = \frac{(N-1)!}{1} (0)^0 \neq 0 = (N-1)!$$

PREPARED J. Kaellis
 CHECKED _____
 MODEL _____

REPORT NO. _____

PAGE **6**

start-up Non-Condensable Removal

$$\alpha_N = \frac{d_0}{(N-1)!} \left\{ -e^{-\frac{v}{V}t} \sum_{i=1}^N \frac{(N-1)!}{(N-i)!} \left(\frac{v}{V}t\right)^{N-i} + (N-1)! \right\}$$

$$\alpha_N = d_0 \left\{ 1 - e^{-\frac{v}{V}t} \sum_{i=1}^N \frac{\left(\frac{v}{V}t\right)^{N-i}}{(N-i)!} \right\}$$

$$C_i P_i = \frac{C_i}{386.72764 \left(\frac{1-C_i}{24} + \frac{C_i}{17} \right)} = d_i$$

$$C_i = \frac{386}{24} (1-C_i) d_i + \frac{386}{17} C_i d_i$$

$$C_i = \frac{386}{24} d_i - \frac{386}{24} C_i d_i + \frac{386}{17} C_i d_i$$

$$C_i = \frac{386}{24} d_i + C_i d_i \left(-\frac{386}{17} - \frac{386}{24} \right)$$

$$C_i = \frac{\frac{386}{24} d_i}{1 + d_i \left(\frac{386}{24} - \frac{386}{17} \right)} = \text{conc. NH}_3$$

$$C_{N.C.} = \text{Conc. Non-Condensables} = 1 - C_N$$

$$C_{N.C.} = \frac{1 + d_i \left(\frac{386}{24} - \frac{386}{17} \right) - \frac{386}{24} d_i}{1 + d_i \left(\frac{386}{24} - \frac{386}{17} \right)}$$

$$= \frac{1 - \frac{386}{17} d_i}{1 + d_i 386 \left(\frac{1}{24} - \frac{1}{17} \right)} = \frac{1 - 22.749611 d_i}{1 - 8.9369546 d_i}$$

$$C_{N.C.} = \frac{1 - 22.749611 d_i}{1 - 8.936954 d_i}$$

$$d_0 = .0439595$$

V_T = total volume of system

$\frac{V_T}{N}$ = volume of one tank = V

$\frac{V_T}{v} = \frac{ft^3}{hr} = hr = \text{flush time (time for one flush)}$
 $= t_F$

$\frac{t}{t_F} = \text{no. of flushes}$

thus

$$\frac{v}{V} t = \frac{v N t}{V_T} = \frac{t}{t_F} N = FN$$

F = no. of system flushes

$$\alpha_i = .0439585 \left\{ 1 - e^{-FN} \sum_{i=1}^N \frac{(FN)^{N-i}}{(N-i)!} \right\}$$

$$C_{N.c.} = \frac{1 - 22.748611 \alpha_i}{1 - 8.936954 \alpha_i}$$

$C_{N.c.}$ = Conc. α after " F " flushes - assume N tanks in series

PURGES
in exit gas

Figure 1 - Conc. α vs. No. of flushes (purges)

Figure 2 - Conc. in exit gas vs. time hrs. assume 1600 cfm of atm ammonia entering, 40,000 ft³ total

system volume and a 3 series tank system.


$$C_{N.c.} = \frac{17}{359} \times \frac{492}{530} = .04366$$

$$1600 \frac{ft^3}{min} \times .04366 \frac{lb}{ft^3} \times .825 hr. \times \frac{60 min}{hr.} = 3481.5 \text{ lbs required for initial purge}$$

I-64

NON-CONDENSABLE CONC. IN EXIT GAS

LB/LB MIX



N = NUMBER OF MIXING TANKS IN SERIES

FIGURE 1




FIG. 2

PREPARED

J. Kallis

REPORT NO.

PAGE

CHECKED

MODEL

Non-Condensable Purging
During Operation

LIST OF SYMBOLS

C_e, C_T = lb ratio entering, inside tank $\frac{\text{lb noncondensibles}}{\text{lb ammonia}}$

F = fraction of inlet flow bled off by noncondensable evacuation tube

t, t_0 = time, discovery time hrs.


V = total free volume of condenser

W = lb/hr, ammonia and noncondensibles entering condenser

ρ = density $\frac{\text{lb/ft}^3}{\text{ft}^3}$

Non-Condensable Purging During Operation

Approach: Postulate a non-condensable leak into the system & time to discover this leak. Determine the time to reduce the non-condensable concentration at discovery time to a fraction (25 to 50%) of its value at discovery time. We assume that a concentration of 25. to 50% of its value at discovery time is insufficient to create large difficulties with system operation.



Density changes due to concentration changes are too small to be considered since concentration change span is very small.

$$\text{inlet} - \text{outlet} = \text{rate of accumulation}$$

$$Wc_e - 0 = \frac{dVPC_r}{dt}$$

$$\frac{\text{lb/hr.}}{\text{hr.}} \times \frac{\text{lb/c.}}{\text{ft}^3} = \frac{\text{ft}^3 \frac{\text{lb/hr.}}{\text{ft}^3} \frac{\text{lb/c.}}{\text{ft}^3}}{\text{hr.}}$$

$\text{lb/hr.} \approx \text{lb mix}$

$\text{lb/hr.} \approx \text{lb mix}$ } since conc. of non condensable is small

PREPARED J. Kaellis

REPORT NO.

PAGE 2

CHECKED _____

Non-condensable Purging During Operation

MODEL _____

$$Wc_e = \frac{dVPC_T}{dt}$$

$$\frac{Wc_e}{VP} = \frac{dC_T}{dt}$$

$$C_T \Big|_0^{C_T} = \frac{Wc_e}{VP} t \Big|_0^t$$


$$\frac{C_T}{C_e} = \frac{W}{VP} t$$

$$\frac{C_{TD}}{C_e} = \frac{W}{VP} t_D$$

$t_D =$ discovery time
 $C_{TD} =$ conc. at discovery time

At discovery time conc. of non-condensables in condenser is C_{TD} .

Starting with a non-condensable conc. in condenser of C_{TD} and an inlet conc. of c_e remove F fraction of inlet flow - determine conc. in condenser as a function of time



PREPARED J. Kaellis

REPORT NO.

PAGE 3

CHECKED _____

Non-Condensable Purging During Operation

MODEL _____

inlet - outlet = rate of accumulation

$$w c_e - w F c_T = \frac{dV P c_T}{dt}$$

$$\frac{lb_{NH_3}}{hr.} \frac{lb_{N.C.}}{lb_{NH_3}} - \frac{lb_{NH_3}}{hr.} \frac{lb_{N.C.}}{lb_{NH_3}} = \frac{\cancel{lb_{NH_3}} \frac{lb_{N.C.}}{\cancel{lb_{NH_3}}}}{hr.}$$

$lb_{NH_3} \approx lb_{mix}$ since $lb_{N.C.}$ is very small

$$VP \frac{dc_T}{dt} = w c_e - w F c_T$$

$$\frac{dc_T}{w(c_e - F c_T)} = \frac{dt}{VP}$$

$$\frac{dc_T}{F c_T - c_e} = -\frac{w}{VP} dt$$

$$\frac{1}{F} \ln(F c_T - c_e) = \int_{c_{T0}}^{c_T} = -\frac{w}{VP} t \Big|_{t_0}^t$$

$$\ln \frac{F c_T - c_e}{F c_{T0} - c_e} = -\frac{FW}{VP} (t - t_0)$$

$$\frac{F c_T - c_e}{F c_{T0} - c_e} = e^{-\frac{FW}{VP} (t - t_0)}$$

$$c_T = \frac{(F c_{T0} - c_e) e^{-\frac{FW}{VP} (t - t_0)} + c_e}{F}$$

$$\frac{c_T}{c_e} = \left(\frac{c_{T0}}{c_e} - \frac{1}{F} \right) e^{-\frac{FW}{VP} (t - t_0)} + \frac{1}{F}$$

but $\frac{c_{T0}}{c_e} = \frac{w}{VP} t_0$

$$\frac{c_T}{c_e} = \left(\frac{w t_0}{VP} - \frac{1}{F} \right) e^{-\frac{FW}{VP} (t - t_0)} + \frac{1}{F}$$

PREPARED J. Kaellis
CHECKED _____
MODEL _____

REPORT NO. _____
PAGE 4
Non-condensable purging during Operation

Build up time (time to discovery)

$$\frac{C_T}{C_e} = \frac{W}{PV} t$$

At discovery time


$$\frac{C_{TD}}{C_e} = \frac{W}{PV} t_D$$

After discovery time

$$\frac{C_T}{C_e} = \left(\frac{W}{PV} t_D - \frac{1}{F} \right) e^{-F \frac{W}{PV} (t - t_D)} + \frac{1}{F}$$

Volume of a 23.9 ft. Dia x 37 ft. long cylinder

$$\frac{\pi (23.9)^2}{4} \times 37 = 16,599.209 \text{ ft}^3$$



Consider a tube cell

tube area = $\frac{\pi D^2}{4}$

cell area $P^2 \sin 60$

Fraction of cell area occupied by the tube = $\frac{\frac{\pi D^2}{4}}{P^2 \sin 60} = \frac{\pi}{\left(\frac{P}{D}\right)^2 4 \sin 60}$



$\frac{1}{6} + \frac{1}{3} + \frac{1}{6} + \frac{1}{3} = 1.$

$= \frac{.9069001}{\left(\frac{P}{D}\right)^2}$

Fraction not occupied by the tube - free area

$= 1 - \frac{.9069001}{\left(\frac{P}{D}\right)^2} = \frac{\left(\frac{P}{D}\right)^2 - .9069001}{\left(\frac{P}{D}\right)^2}$

PREPARED J. Kaellis

REPORT NO.

PAGE 5

CHECKED _____

Non-Condensable Purging During Operation

MODEL _____

Say $\frac{P}{D} = 1.25$

$$\text{Free area} = \frac{(1.25)^2 - .9069001}{(1.25)^2}$$

$$= .4195939$$

Free volume = 16,599.209 x .4195939 = 5230. ft³

$$\frac{1}{P} = 3.294 \frac{\text{ft}^3}{\text{lb}} \quad P = .3035822 \frac{\text{lb}}{\text{ft}^3}$$

$$W = 8.282 \times 10^2 \frac{\text{lb}}{\text{sec}}$$

$$\frac{W}{PV} = \frac{8.282 \times 10^2}{.3035822 \times 5230.} \times 3600 = 1977.8 / \text{hr.}$$

$$\frac{\frac{\text{lb}}{\text{sec}}}{\frac{\text{lb}}{\text{ft}^3} \text{ft}^3} \times \frac{3600 \text{ sec}}{\text{hr.}}$$

$$\frac{C_I}{C_e} = 1977.8 t$$

$$\frac{C_I t_0}{C_e} = 1977.8 t_0$$

$$\frac{C_I}{C_e} = (1977.8 t_0 - \frac{1}{F}) e^{-F 1977.8 (t-t_0)} + \frac{1}{F}$$

Figure 1 is a plot of $\frac{C_I}{C_e}$ for a 15 minute (.25 hr. discovery time)

Figure 2 is a plot of $\frac{C_I}{C_e}$ for a 30 minute (.5 hr. discovery time)

PREPARED J. Kaellis

REPORT NO.

PAGE 6

CHECKED _____

MODEL _____

Non-condensable Purging During
Operation

Conclusion: The smaller the discovery time the more serious the non-condensable leak. A .6% purge rate ($F = .006$) will reduce the concentration of non-condensables in the condenser to 35% of its discovery time value in about .4 of an hr. (24 minutes). Design purge system to accommodate a .006 fraction purge rate or $.006 \times 828.2 \frac{\text{lb}}{\text{sec}} = 4.969 \frac{\text{lb}}{\text{sec}}$.

NORMALIZED CONCENTRATION OF NON-CONDENSABLES





FIGURE 1 TIME HRS.



PREPARED

J. Kaelis

REPORT NO.

PAGE 1

CHECKED

J/N 3442-82

Heat Losses Due To Immersion

Problem: To determine the heat gain to the condenser when submerged in 80°F water

Page 112 Brown & Marsch

eqn 7-7

I.D. shell = 3/5"

say O.D. = 320" = L_{horiz}

$L_{horiz} = 26.6667$ ft.

$L_{vert} = 30$ ft.

$$\frac{1}{L} = \frac{1}{L_{horiz}} + \frac{1}{L_{vert}}$$

$$= \frac{1}{26.6667} + \frac{1}{30}$$

$$= .0708333$$

$$L = 14.1176$$

a for pure water at 80°F = 30×10^8

$$aL^3 \theta = 3 \times 10^8 \times 14.1176^3 \times (80 - 50)$$

$\theta = \text{temp. diff.}$

$$= 2.53235 \times 10^{13}$$

per page 113 $d = 1/3$

$C_1 = .12$ page 114.

$$h = C_1 k (a\theta)^{1/3}$$

$$h = .12 \times .352 \times (3 \times 10^8 \times 30)^{1/3} k = .355 \text{ pure water @ } 80^\circ\text{F}$$

$$h = 87.8626 \quad k = .352 \text{ sea water @ } 80^\circ\text{F}$$

Considering wave motion say $h = 100$

* sea water is 2 1/2% lower 8/1/78

I-75

PREPARED J. Kaelis

REPORT NO.

PAGE 2

CHECKED _____

Heat Losses Due to Immersion

MODEL _____

Metal conductance

1 1/2" shell wall, after corrosion

$$k_{\text{carbon steel}} = 30. \text{ BTU} / (\text{hr. ft}^2 \text{ } ^\circ\text{F/ft.}) \quad \text{TEMA}$$

$$h_m = \frac{30}{1.5/12} = 240.$$

Condensing

$$h_c = 1000. \quad \text{ORNL Report ORNL-5356 Fig. 6-1}$$

$$U = \frac{1}{\frac{1}{100} + \frac{1}{240} + \frac{1}{1000}} = \frac{1}{.0151666} = 65.934$$

Surface of Condenser shell

$$\pi (26.6667) \times 30 = 2513.274 \text{ ft}^2$$

$$q = U A \Delta t = 65.934 \times 2513.27 \times 30 = 4,971,298.3 \text{ BTU/hr.}$$

$$4,971,298.3 \frac{\text{BTU}}{\text{hr.}} \times \frac{\text{hr.}}{60 \text{ min}} \times \frac{\text{min KW}}{56.87 \text{ BTU}} \times \frac{\text{M.W.}}{1000 \text{ KW}} = 1.456967 \text{ M.W.}$$

$$\text{Total heat transferred in condenser} = 1.4950 \times 10^9$$

$$\text{Fraction of heat gained} = \frac{4971298.3}{1.4950 \times 10^9} = .00332528$$

.33%

Added tubes required

$$43678 \times .00332528 = 145.2417$$

Heat ~~loss~~ gain

$$7.5 \times 10^6 \text{ BTU/m.}$$

7×10^{-4}
 100×10^{-2}

3

direct loss
\$
yr

$$= \frac{7.5 \times 10^6 \text{ BTU/m.}}{3,413 \frac{\text{BTU}}{\text{kw}\cdot\text{hr}}} \times 8000 \frac{\text{hr}}{\text{year}} \times (.025) \times .03 / \text{kw}\cdot\text{hr}$$

$$= \underline{\underline{\$ 13,185 / \text{yr}}}$$

P.V. for 30 yr. series = 9.43

P.V. = $13,185 (9.43) = \underline{\underline{\$ 124,333}}$

For. $Q = 5 \times 10^6 \frac{\text{BTU}}{\text{m.}}$ ^{ref. Joe Kuehlis 7/25/78}

P.V. $\approx \frac{2}{3} (124,333) = \underline{\underline{\$ 82,900}}$

Amount that can be spent for applying perfect insulation to condenser for 30 yr life.

Per Forest Clement of C. F. Braun
7/26/78 - insulation present value will be \$100,000. which is greater than \$82,900 - therefore do not insulate
G. M. Kekun 7/25/78
I. K.

PREPARED

J. Kallin

CHECKED

J/N

3442-82

Evaporator Bundle & shell diameters
Condenser Bundle & shell diameters
Non-condensable pipe dimension

This analysis calculates

- ① Evaporator and Condenser vapor nozzles
- ② Diameter of evaporator and condenser tube bundles
- ③ Evaporator and Condenser shell diameters
- ④ Shell and tube bundle eccentricities in evaporator & condenser
- ⑤ Size of non-condensable evacuation tube and number and size of tube holes required and the size of the discharge pipe

PREPARED Joe Kallis

REPORT NO.

PAGE 1

CHECKED _____

MODEL _____

Evaporator Bundle & shell dimensions
 Condenser Bundle & shell dimensions
 Re-Condensate pipe dimensions

Inlet Nozzle

Criterion for vapor nozzle sizes

$PV^2 = 500$, 807.15 lb/sec enters or leaves

Condenser

$P = .3036$

$V^2 = \frac{500}{.3036}$

$V = 40.582 \frac{ft}{sec}$ (permissible vel.)

$807.15 \frac{lb}{sec} \times \frac{ft^2}{.3036 lb} \times \frac{sec}{40.582 ft}$

$807.15 \times \frac{1}{V}$

$= 65.5117 ft^2$

$= \frac{\pi D^2}{4}$

$D = 9.13302 ft$

$d = 109.596 \text{ inches}$

$\times 1.1 = 120.552$

Say 120" outlet

Condenser inlet nozzle

Evaporator

$P = .43253$

$V^2 = \frac{500}{.43253}$

$V = 33.9998 \frac{ft}{sec}$

$807.15 \frac{lb}{sec} \times \frac{ft^2}{.43253 lb} \times \frac{sec}{33.9998 ft}$

$= 54.885 ft^2$

$= \frac{\pi D^2}{4}$

$D = 8.3556024 ft$

$d = 100.31522 \text{ inches}$

$\times 1.1 = 110.343$

Say 110" outlet

Evaporator * outlet nozzle

* later changed to a 72" ID since an outlet has less severe requirements

$V = 807.15 \frac{lb}{sec} \times \frac{ft^2}{.43253 lb} \times \frac{1}{\frac{\pi (72)^2}{4}} ft^2$

$= 65.87$

$PV^2 = .43253 \times 65.87 = 1877$


I-79

PREPARED _____

CHECKED _____

MODEL _____

Dia. of tube bundles



Area/tube

$$4 \left(\frac{1}{2} \text{ base} \times \text{altitude} \right)$$

$$4 \left(\frac{1}{2} \frac{1.25}{2} \times 1.25 \sin 60 \right)$$

$$1.25^2 \sin 60 = 1.353164 \text{ in}^2/\text{tube}$$

← area occupied by "1" tube

Cond

$$1.353 \frac{\text{in}^2}{\text{tube}} \times 43678 \text{ tubes} = 59103.499 \text{ in}^2$$

$$= \frac{\pi D^2}{4}$$

$$D = 274.32264 \text{ in}$$

say $D = 275 \text{ in.}$ ← diameter of condenser tube bundle
 $R = 137.5 \text{ in}$

Evap

$$1.353 \times 42667 =$$

$$57735.451$$

$$= \frac{\pi D^2}{4}$$

$$D = 271.12923 \text{ in}$$

say $D = 272 \text{ in}$
 $R = 136 \text{ in}$


← diameter of evaporator tube bundle

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

Shell dia

$1.25 \text{ Nozzle area} = \text{escape area}$



$1.25 \pi \frac{D^2}{4} = \pi D \times L$
Circumference x length


$\frac{1.25}{4} D = L$

Cond.

$\frac{1.25 \times 20}{4} =$

$37.5" = L$

escape area
Condenser



L 37.5

3" 3.

Bundle dia 275.0'

5" 5.0

320.5 inches

say $320."$

shell diameter
condenser

Evap

$\frac{1.25 \times 1.10}{4} =$

$34.375 = L$

escape area
evaporator

L = 34.375

3.

272.

5.

314.375

say $315."$

shell diameter
evaporator

PREPARED _____

CHECKED _____

MODEL _____

Exentricity

Cond.

distance to bundle ϕ

$$\begin{array}{r} \text{L} \quad 37.5 \\ 3'' \quad 3 \\ \hline 275.0 \\ 2 \quad \quad 137.5 \\ \hline 178.0 \end{array}$$

distance to shell ϕ

$$\frac{320}{2} = 160$$

$$\text{exentricity} = 178 - 160$$

$$= 18''$$

exentricity
Condenser

E vap.

$$\begin{array}{r} 34.375 \\ 3 \\ \hline 136 \\ \hline 173.375 \end{array}$$

$$\frac{315}{2} = 157.5$$

$$173.375 - 157.5$$

$$= 15.875$$

$$\text{say } 15\frac{1}{2}$$

exentricity
evaporator

Size of Evacuation tube in Condenser

$$\frac{h_L}{\left(\frac{L}{D}\right) \frac{V^2}{2g}} = f \quad \text{from Crane}$$

$$h_L = f \frac{L}{D} \frac{V^2}{2g}$$

$$w \times \frac{1}{\pi D^2} \times \frac{1}{4} = V$$

$$\frac{w}{hr.} \times \frac{1}{\pi D^2} = \frac{V}{4}$$

$$h_L = f \frac{L}{D} \frac{w^2}{\left(\frac{\pi D^2}{4}\right)^2 2g}$$

$$\frac{f}{ft.} \times \frac{L}{ft.} \times \frac{w^2}{hr.^2} \times \frac{1}{\left(\frac{\pi D^2}{4}\right)^2} \times \frac{1}{2g} = \frac{h_L}{ft.} \times \frac{1}{ft.^2}$$

$$\Delta P = f \frac{L}{D^5} \frac{w^2}{\left(\frac{\pi}{4}\right)^2 \rho^2 2g}$$

$$\Delta P = \frac{1}{\left(\frac{\pi}{4}\right)^2 2g} \int \frac{L}{d^5} \frac{w^2}{\rho}$$

$L = ft.$ $d = \text{inches}$ $w = \frac{lb}{hr.}$ $\rho = \frac{lb}{ft.^3}$

$$\frac{1}{\frac{ft.}{sec^2}} \times \frac{ft.}{in^5} \times \frac{\frac{lb^2}{hr.^2}}{\frac{lb}{ft.^3}} = \frac{lb \cdot ft.^5 \cdot sec^2}{hr.^2 \cdot in^2} \times \frac{hr.}{3600^2 sec^2} \times \frac{12^3 \cdot ft.}{in^3}$$

$$\Delta P = \frac{1.3333 \times 10^{-4}}{\left(\frac{\pi}{4}\right)^2 \times 64.4} \int \frac{L}{d^5} \frac{w^2}{\rho} = 1.3333 \times 10^{-4}$$

$$\Delta P = 3.35639 \times 10^{-6} \int \frac{L}{d^5} \frac{w^2}{\rho}$$

Pressure drop equation $L = ft.$, $d = \text{inches}$
 $w = \frac{lb}{hr.}$ $\rho = \frac{lb}{ft.^3}$

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

$$dP = 3.35639 \times 10^{-6} \frac{f}{d^5 P} w^2 dL$$

w varies with L

w=0 L=0

w=w/a L=l l = total length

w = mL + b

0 = m*0 + b

b = 0

w_{exit} = m.l

m = $\frac{w_{exit}}{l}$

$w = \frac{w_{exit}}{l} L$

variation of w for of vapor
uniform pick-up along
evacuation tube from L=0
to L=l

$$dP = 3.35639 \times 10^{-6} \frac{f}{d^5 P} \left(\frac{w_{exit}}{l}\right)^2 L^2 dL$$

$$\int_{P_1}^{P_2} dP = 3.35639 \times 10^{-6} \frac{f}{d^5 P} \left(\frac{w_{exit}}{l}\right)^2 \int_0^l L^2 dL$$

$$P_2 - P_1 = 3.35639 \times 10^{-6} \frac{f}{d^5 P} \left(\frac{w_{exit}}{l}\right)^2 \frac{l^3}{3}$$

$$\Delta P = \frac{3.35639 \times 10^{-6}}{3} \frac{f}{d^5 P} w_{exit}^2 l$$

d inches w = $\frac{lb}{hr}$
l ft.
P $\frac{lb}{ft^2}$

P.D. in evacuation
tube for uniform
pick up of vapor
from L=0 to L=l

I-84

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

PAGE 7

$$Re = \frac{D W}{\frac{\pi D^2}{4} \mu}$$

$$= \frac{4}{\pi} \frac{W}{D} \times \frac{1}{\mu}$$

$$W = 807 \frac{\text{lb}}{\text{sec}} \times \frac{3600 \text{ sec}}{\text{hr}} \times 0.006 \text{ (6\% purge)} = 17,431.2$$

$$Re = \frac{4}{\pi} \frac{17,431.2}{d \text{ in}} \times \frac{12 \text{ in}}{\text{ft.}} \times \frac{1}{0.0254}$$

$$\frac{4}{\pi} \frac{17,431.2 \times 12}{d \text{ ft.}} \times \frac{1}{0.0254}$$

$$Re = \frac{10,322,834}{d} \text{ at exit.}$$

d	Re at exit	f
1	10,322,834	.0103
5	2,064,566.8	.0113
10	1,032,283.4	.0125
15	688,188.9	.0132

say $f = .015$

DETERMINE
AVERAGE FRICTION
FACTOR

$$\Delta P = \frac{3.75639 \times 10^{-6}}{3} \times \frac{.015}{.3036} \frac{(17,431.2)^2 \times 30}{d^5}$$

$$= \frac{503.86765}{d^5}$$

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

$$V = 807 \frac{\cancel{lb}}{sec} \times 0.006 \times \frac{\cancel{ft^3}}{.3036 \cancel{lb}} \times \frac{1}{\frac{\pi d^2}{4}} \times \frac{144 \cancel{in^2}}{\cancel{ft^2}}$$

$$V = \frac{2924.122}{d} \frac{ft}{sec}$$

Some vel. =

\sqrt{RT}

d	$\Delta P = \frac{503.86765}{d^5}$	$V = \frac{2924.122}{d^2}$ d cft
1	503.86765	2924.122
2	15.745864	731.0305
3	2.073529	324.902
4	.4920592	182.757
5	.1612376	116.965
6	.0647977	81.226 * chosen
7	.0297796	59.6759
8	.0153768	45.689
9	8.53304×10^{-3}	36.100
10	5.03867×10^{-3}	29.24 + chosen

$r = 1.3$

$$R = 10.731 \frac{ft^3}{in^2} \frac{lb}{sec^2} R$$

$$\times \frac{1 \cancel{lb}}{17 \cancel{lb}} \times \frac{32.17 \cancel{ft}}{sec^2} \times 144 \frac{in^2}{ft^2}$$

$$R = \frac{10.731 \times 32.17 \times 144}{17}$$

$$= 2924.1849 \frac{ft^2}{sec^2} \frac{460}{510} R$$

$$a = \sqrt{1.3 \times 2924 \times 510}$$

$$= 1392.3 \frac{ft}{sec}$$

straight pipe

PREPARED _____
 CHECKED _____
 MODEL _____



holes
 say 1 hole every 2"

$$\frac{\text{hole}}{2 \text{ inches}} \times 30 \times 12 \text{ inches} = 180 \text{ holes}$$

$$\frac{17,431.2 \frac{\text{lb}}{\text{hr.}}}{180 \text{ holes}} = 96.84 \frac{\text{lb}}{\text{hr. hole}} \times \frac{\text{hr.}}{3600 \text{ sec}} = .0269 \frac{\text{lb}}{\text{sec. hole}}$$

$$V = .61 \sqrt{2gh}$$

$$V^2 = .61^2 2gh$$

$$h = \frac{V^2}{.61^2 \times 2g}$$

Choose hole size and numbers so that pressure drop through holes is an order of magnitude greater than pressure drop through evacuation pipe (an order of magnitude greater than .065) - thus ensuring good evacuation distribution

$$\frac{\frac{\text{ft}^2}{\text{sec}^2}}{\frac{\text{ft}^2}{\text{sec}^2}} \times \frac{\text{P lb.}}{\text{ft}^2} \times \frac{\text{ft}^2}{144 \text{ in}^2}$$

$$\Delta P = \frac{V^2}{.61^2 \times 2g} \frac{\rho}{144}$$

P.D. through hole in evacuation tube

$$W \times \frac{1}{P} < \frac{1}{\frac{V^2}{144}} \times 144 = V$$

$$\frac{\text{lb}}{\text{sec.}} \frac{\text{ft}^2}{\text{in}^2} \frac{1}{\text{in}^2} \times 144 \text{ in}^2$$

$$\frac{4W}{\pi P d^2} \times 144 = V$$

$$\frac{4}{\pi} \times .0269 \times 144 = V$$

$$\sqrt{\frac{4.9320207}{P d^2}} = V$$

Velocity through hole in evacuation tube

PREPARED _____
CHECKED _____
MODEL _____

REPORT NO. _____

$$\Delta P = \frac{4.9320207^2 \cdot \rho}{\rho \cdot d^4 \cdot 144} = \frac{4.9320207^2}{.61^2 \times 64.4 \cdot d^4} = \frac{4.9320207^2}{.3036 \times 144} \times \frac{1}{.61^2} \times \frac{1}{64.4} \times d^4$$

$$= \frac{.0232186}{d^4} \quad \rho = .3036$$

d_n	$\Delta P = \frac{.0232186}{d^4}$	$V = \frac{.0232186}{\frac{1}{n^4}} = .0232186 \times 16^4 = \frac{1521.6672}{n^4}$
$\frac{1}{16}$ 1	1521.6672	4158.7526
$\frac{2}{16}$ 2	95.104	1039.69
3	18.786	462.1
4	6.9440	259.9
5	2.43466	166.3
6	1.1741259	115.5
7	.6337639	84.87
8	.37	64.98

$$V = \frac{807 \times .006 \frac{lb}{sec} \times \frac{1}{3036}}{180} \times \frac{1}{\frac{\pi d^2}{4} \times 144} = \frac{16.245127}{d^2} = \frac{16.245127}{\frac{n^2}{16^2}} = \frac{4158.7526}{n^2}$$

Choose $\frac{8}{16}$ " holes & 10 " I.D. pipe

PREPARED _____

REPORT NO. _____

CHECKED _____

MODEL _____

Discharge pipe

$$\Delta P = 3.35639 \times 10^{-6} f \frac{L}{d^5} \frac{w^2}{\rho} \quad \text{from page 5}$$

$$f \approx .0125$$

$$L \approx \frac{137.5 \text{ m}}{12 \text{ m}} \times 1 = 11.458$$

$$w = 807 \frac{\text{lb} \times .00623600 \text{ sec}}{\text{sq. hr.}} = 17431.12 \quad \rho = .3036$$


$$\Delta P = \frac{3.35639 \times 10^{-6} \times .0125 \times 11.458 (17431.12)^2}{d^5 \times .3036}$$

$$= \frac{481.10963}{d^5}$$

$$V = \frac{2924.122}{d^2} \quad \text{from page 8}$$

d	$\Delta P = \frac{481.10963}{d^5}$	V	n	rows removed
1	481.109	2924	.6	1
2	15.0346	731.0305	1.4	2
3	1.9798	324.902	2.2	3
4	.4698	182.757	3.	4
5	.153955	116.965	3.8	4 *
6	.061871	81.226	4.6	5
8	.0146023	36.609	6.2	7

n rounded to next integer
choose



$$1.25 \times (n-1) + 2(1.25) = \text{distance available}$$

$$1.25 \times (n-1+2) - 1 = \text{if remove 1st}$$

$$1.25 \times (n+1) - 1 = d$$

$$n = \frac{d+1}{1.25} - 1$$

discharge pipe

PREPARED _____

CHECKED _____

MODEL _____

Conclusion

10 1/2" center pipe

150 - 8/16" holes

8" ~~1/2~~ exiting pipe

October 17, 1977

**Pressure Losses in Condenser Tube Bundle
(No Vapor Lanes)**

The pressure loss from periphery to center of a cylindrical condenser tube bundle was calculated for various bundle radii, under the following conditions:

Tube overall diameter	1.5 inches
Tube length	25 ft
Sea water velocity	6 ft/sec
Sea water inlet temperature	40°F
Ammonia saturation temperature	50°F
Triangular pitch diameter	1-7/8 inches
No vapor lanes	
Feed, periphery to center	

For these conditions, pressure drop from periphery to center of bundles can be represented by the equation

$$\Delta P = 4.6 \times 10^{-6} r^{2.855} \text{ (psi)}$$

r = bundle radius, in feet

Calculated values of ΔP for various bundle radii are given in Table A.

TABLE A

<u>Tube Bundle Radius, ft</u>	<u>Pressure Drop, psi</u>
5	0.00045
10	0.003294
15	0.0105
20	0.0238
25	0.045
35	
50	

If tubes were reduced to 1 inch diameter, the losses would be roughly 3.38 times as high, which is still small except perhaps for bundles in excess of 20 ft radius.

It appears that vapor lanes will not be needed in condensers of the size contemplated.

50 feet will need (maybe) vapor lanes

Support calculations follow.

Pressure Losses in Condenser Tube Bundle (No Vapor Lanes)

Date

The pressure loss from periphery to center of a $\frac{1}{2}$ inch condenser tube bundle was calculated for various bundle radii, under the following conditions:

Tube inside diameter	1.5 inches
Tube length	25 ft
Sea water velocity	6 ft/sec
Sea water inlet temperature	40°F
Ammonia saturation temperature	50°F
Triangle pitch dia	1 7/8 inches
No vapor lanes.	
Feed, <u>periphery</u> to center	

For these conditions, pressure drop from periphery to center of bundles can be represented by the equation

$$\Delta P = 4.6 \times 10^{-6} R^{2.855} \quad (\text{psi})$$

R = bundle radius, in feet

Calculated values of ΔP for various bundle radii are given in Table A

Table A

Tube bundle: rods, ft

Pressure drop, psi

5

0.00045

10

0.003294

15

0.0105

20

0.0238

25

0.045

If tubes were reduced to 1 inch diameter, the sizes would be roughly 3.38 times as high, which is still small except perhaps for bundles or cases of 20 or more rods.

It appears that vapor lanes will not be needed in condensers of this size contemplated.

Support calculations follow.

I Geometric Calculations

$$\text{Tube OD, } D_o = 1.5 \text{ inches}$$

$$\text{External flutes, } 0.040 \quad - 0.80 \text{ "}$$

$$\text{Wall thickness } 0.109 \quad - 0.218 \text{ "}$$

$$\text{Internal root diameter} \quad \underline{1.202 \text{ "}}$$

$$\text{Water diameter } D_w$$

$$= (1 - 0.065) \cdot (\text{ID diameter})$$


$$= 1.1239 \text{ inches}$$

$$= 0.0936 \text{ ft.}$$

Triangular pitch (specified)

$$S_T = 1.5 \times 1.25 = 1.875 \text{ inches}$$

$$S_L = 1.875 \times \cos 30^\circ = 1.624 \text{ inches}$$



Area/tube

$$= S_T \cdot S_L = 1.875^2 \cos 30^\circ = 3.045 \text{ sq in/tube}$$

Tube area

$$= \frac{\pi}{4} \cdot 1.5^2 = 1.767 \text{ sq in}$$

Packing ratio

$$= \frac{3.045}{1.767} = 1.723$$

II Ammonia vapor generated per foot of tube

L	Tube length, assumed	25 ft
D_w	Water diameter	0.0936 ft
ΔT_i	ΔT at water inlet	10°F
v	Sea water velocity, ft/sec	21,600 ft/hr
ρ	Sea water density	64.02 lb/ft ³
C_p	Sea water heat capacity	0.9543 BTU/lb·ft ³ ·°F
U	Overall heat transfer coeff.	627 BTU/hr·ft ² ·°F

$$\theta = \Delta T_i (1 - e^{-\beta}) \quad (1)$$

$$\beta = \frac{4UL}{D_w v \rho C_p}$$

θ = sea water temperature rise

$$\beta = \frac{4 \times 627 \times 25}{0.0936 \times 21600 \times 64.02 \times 0.9543} = 0.5076$$

$$e^{-\beta} = 0.6019$$

$$\theta = 10(1 - 0.6019) = 3.981^\circ \text{F}$$

$$q = \frac{\pi}{4} D_w^2 v \rho C_p \theta \quad (2)$$

q = heat transfered per tube

$$q = \frac{\pi}{4} (0.0936)^2 (21600) (64.02) (0.9543)$$

$$= 3.615 \times 10^4 \text{ BTU/hr/tube} \quad 1-96$$

Ammonia vapour

$$= \frac{9F}{\Delta H}$$

$$\Delta H = \text{latent heat of } \text{NH}_3 \text{ at } 50^\circ\text{F} = 527.3 \text{ Btu/lb}$$

$$= \frac{3.615 \times 10^4}{527.3} = 68.55 \text{ lb/hr/ton}$$

$$= 68.55 \times 3.294 = 225.8 \text{ cu ft/hr/ton}$$

$$\text{Vapour volume at } 50^\circ = 3.294 \text{ cu ft/lb}$$

$$\text{or } \frac{225.8}{25} = 9.02 \text{ cu ft/hr/ton of feed}$$

III Guntter-Shaw Calculations

← Guntter-Shaw, (generalized)

$$\frac{-\Delta P}{\rho L} = 1.92 Re_v^{-0.145} \left(\frac{V^2}{2g_c d_v} \right) \left(\frac{d_v}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6}$$

where

$$d_v = 4 \left(\frac{S_L S_T - \pi D_o^2}{4} \right) = \frac{4 S_T S_L}{\pi D_o} - D_o$$

$$V = \text{velocity of vapor at constriction} = \frac{Q}{S_T - D_o}$$

$$Re_v = \frac{d_v V \rho}{\mu}$$

Q - Annular vapor flow through, ^{transverse} gap between tubes

$x =$ flow length
 Rodfin corrector for specified tube size = 0.81

Corrected Guntter-Shaw

$$\frac{-\Delta P}{\rho L} = 0.81 \times 1.92 \left(\frac{d_v V \rho}{\mu} \right)^{-0.145} \left(\frac{V^2}{2g_c d_v} \right) \left(\frac{d_v}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6}$$

$$= (0.81 \times 1.92) \left(\frac{d_v \rho}{\mu} \right)^{-0.145} \left(\frac{1}{2g_c d_v} \right) \left(\frac{d_v}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6} V^{1.855}$$

Substituting

$$d_v = \frac{4 \cdot 1.875^2 \cdot 4230}{1.5 \pi} - 1.5 = 1.084 \text{ inches}$$

$$= 0.09036 \text{ ft}$$

And

$$(0.81)(1.92) \left(\frac{0.0258 \cdot 3294}{0.09036} \right)^{0.145} \left(\frac{1}{2 \times 32.17 + 36 \text{ ft}^2 \times 0.09036} \right) \left(\frac{7.054}{1.875} \right)^{0.1} \left(\frac{1.624}{1.875} \right)$$

$$= 1.507 \times 10^{-8}$$

So

$$\frac{\Delta P}{\rho \alpha} = 1.507 \times 10^{-8} \text{ V}^{1.855}$$

(3)

IVCalculation of V + ΔP

$$\text{Tricks per longitudinal ft} = \frac{12}{S_L} = \frac{12}{1.624} = 7.389$$

Vapor released per longitudinal foot per column, perfect depth

$$= 7.389 \text{ tricks} \times 9.03 \text{ cu ft/ft} = 66.74$$

$$V = \frac{\text{Vapor released}}{\text{mole ratio}} = \frac{CF/M}{S_T - D_0} = \frac{CF/h}{0.875/12} = 32 \times CF/h \text{ vapor per ft}$$

III one-dimensional flow

$$V = 32 \times 66.74 \times Z = 2135.6 Z, \text{ ft}^3/h. \quad (4)$$

At $Z=0$... $\rho = 0$ given Z

$$\frac{\Delta P}{\rho \Delta Z} = 1.507 \times 10^{-8} (2135.6 Z)^{1.855}$$

$$\frac{\Delta P}{\rho} = \left(\frac{1.507 \times 10^{-8} \times 2135.6}{2.855} \right) Z^{2.855}$$

$$= 7.921 \times 10^{-3} Z^{2.855}$$

Z	$\frac{\Delta P}{\rho}$	$\frac{\Delta P}{\rho} \text{ (ft}^2/\text{s}^2)$
5	0.784	
10	3.673	0.012
15	18.05	
20	41.04	0.087
25	77.64	0.164

In cylindrical flow, V at any point is half that in an equivalent flow, etc.

$$V = \frac{2135.6 \text{ ft}}{2} \text{ ft/min.}$$

$$\frac{dP}{\rho dR} = 1.507 \times 10^{-8} \left(\frac{2135.6 \text{ ft}}{2} \right)^{1.855}$$

$$\frac{\Delta P}{\rho} = \frac{1.507 \times 10^{-8}}{2.855} \left(\frac{2135.6 \text{ ft}}{2} \right)^{2.855}$$

which is $\left(\frac{1}{2}\right)^{1.855}$ times the value for an equivalent flow-

$$\left(\frac{1}{2}\right)^{1.855} = 0.276$$

So, for circular tube banks without lanes, for the same size, geometry, and operating conditions specified above

$$\Delta P = \frac{0.276 \times 7.921 \times 10^{-3} \text{ ft}^{2.855}}{1414 \times 3.294} = 4.6 \times 10^{-6} \text{ ft}^{2.855} \text{ (psi)}$$

Pressure drops through bundles of various radii are given in Table A

V Pressure Loss in Tube Bundles - Scaling Equations

Relations will be developed to predict pressure losses on tube bundles geometries similar but different in scale. i.e. using 1" tubes instead of 1/2" tubes, but with all distances scaled down proportionately.

The basic Carman-Chow equation:

$$\frac{-\Delta P}{\rho L} = 0.81 \times 1.92 Re_v^{-0.145} \left(\frac{v^2}{2g_d v} \right) \left(\frac{d_v}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6}$$

Contains ^{some} groups unaffected by the scale, and other that are affected. Thus the factors:

$$0.81 \times 1.91 \left(\frac{d_v}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6}$$

are functions of geometry, arrangement and not of scale. Designating them by F.

$$\frac{-\Delta P}{\rho L} = F Re_v^{-0.145} \left(\frac{v^2}{2g_d v} \right)$$

The first term is identifiable as a Froude No.

$$Re_v = \frac{d_v V \rho}{\mu}$$

And in one dimensional flow (along a tube column)

$$V = \frac{\lambda m L}{w}$$

λ = gas conductance / ft of tube

m = no of tubes / ft of column, $\sim d_v^{-1}$

w = width of aperture, $\sim d_v$

L = length of column from origin

$$\frac{m}{w} \sim \frac{d_v^{-1}}{d_v} = d_v^{-2}$$

Also

$$\lambda \sim U D_w \Delta T$$

$$V \sim \frac{U D_w \Delta T L}{d_v^2}$$

So, at any x

$$\frac{-\Delta P}{\rho x} \sim \left(\frac{d_v V \rho}{\mu} \right)^{-0.145} \left(\frac{V^2}{d_v^2} \right) = \left(\frac{\mu}{\rho} \right)^{0.145} \frac{V}{d_v^{1.145}}$$

$$-\frac{dp}{\rho dx} \sim \left(\frac{\mu}{\rho}\right)^{0.145} \frac{(U D_w \Delta T)^{1.855}}{d_v^{3.71} d_v^{1.145}}$$

Integrating

$$-\frac{\Delta P}{\rho} = \left(\frac{\mu}{\rho}\right)^{0.145} \frac{(U \Delta T D_w)^{1.855} L^{2.855}}{d_v^{4.855}}$$

To a close approximation, $D_w \sim d_v$. Assuming $\mu, \rho, \Delta T, \text{ and } U$ constants, for some $L(n)$

$$-\Delta P \sim d_v^{-3} \sim D_0^{-3} \quad (\text{approximately})$$

So in 1" tubes, $\Delta P = 1.5^3 = 3.375$ times that in 1/2" tube bundles.

Evaporator Plenum for Liquid Ammonia

Summary

The layout of tubes in a vertical OTEC evaporator must satisfy constraints on the pressure drop of the liquid ammonia flowing in the inlet plenum. A plenum design has been determined for one case near the center of the projected range of design and operating variables. In this case,

Outside diameter of tubes = 1.5 in.

Pitch-to-diameter ratio = 1.25

Length of tubes = 25 ft.

Inlet water temperature = 80°F

Average water velocity = 6 ft/sec

Ammonia saturation temperature = 70°F

Inlet liquid ammonia temperature = 65°F

Ammonia applied per tube = 166.7 lb/hr

The tubes are doubly fluted with 60-mil, area ratio 2.0 flutes on the water side and 40-mil constant radius flutes on the ammonia side. Liquid from the plenum is applied through apertures formed by truncating the flutes to a height of 15 mils.

The pressure drop through the apertures from the plenum to the vapor space below is 4.4 ft. of liquid ammonia, allowing for 0.4° tilt, pressure differences within the plenum can be kept within 10 per cent of the nominal value. The point-to-point variation affects the flow rate of liquid on individual tubes by no more than about 5 per cent, thus maintaining almost constant heat flux from tube to tube.

The layout of tubes is basically a circular bundle cut by six radial mains which separate the bundle into six identical pie-shaped segments. Entering liquid flows from the periphery of the bundle in a complex way. In the present calculations, however, pressure drops along three simple paths have been evaluated and the highest have been selected for conservative design.

Plenum heights and the widths of the radial mains that produce allowable pressure drops are associated with various shell diameters. For the illustrative case at hand, the plenum height L_T and the number of tube rows N_R removed to form a main are as follows:

Shell Diam. (ft)	18	25	35	50
Assumed Bundle Diam. (ft)	17	23	32	46
L_T (ft)	2	2	2	3
N_R	0*	3	3	5

* no radial mains are needed in this instance

These results are not optimized. They indicate, however, that radial mains alone are adequate to control the pressure distribution.

Pressure drops in the vapor space are negligible, being in the order of 0.01 to 0.03 psi in the calculated case.

$L = 2.5$ ft only

①

Evaporator Plenum for Liquid NH_3

Concept

The design is based on a cylindrical tube bank of radius R with the tubes in equilateral staggered array having pitch S . To reduce pressure drops, the bank is divided into six identical segments (pie-shaped) by radial mains, each of which is formed by removing N_R tubes.

Approach

The extent of maldistribution of liquid NH_3 is associated with the maximum pressure drop between the periphery of the tube bank and some point within the bank. To avoid time-consuming search for this particular point, the pressure drops along three paths have been studied.


Figure 1 illustrates these paths:

- BD is the path of flow directly into the bank to the interior point D
- ACD and A'C'D are paths along the main for half the radius of the bank, then to point D by the direction normal to the main through the bank
- AE and A'E are paths of flow in the mains along the whole radius of the bank.

Figure 2 shows how the direction of flow influences the transverse and longitudinal pitches. These, in turn, affect the pressure drop.

②

Fig. 1. Geometry of Equilateral Tube-Bank Segment



Tubes occupy total area $ABA'E$. Main AE and $A'E$ are formed by removing Nr tubes.

Pressure drops are evaluated along NH_3 paths BD , ACD ($A'C'D$) and AE ($A'E$) as shown by arrows.

③




Fig 2. Geometry of Equilateral Tube Array

<u>Path</u>	<u>Transverse Pitch</u>	<u>Longitudinal Pitch</u>
I	S	$\sqrt{3} S / 2$
II	S	$\sqrt{3} S / 2$
III	$(N_R + 1) \sqrt{3} S / 2$	S

Data Base for Pressure Drops

Pressure drops in both the uniform tube bundle and the mains are calculated by means of the equation of Gunter and Shaw (1) with appropriate adjustments. As shown by Boucher and Rapsfle (2), the Gunter-Shaw equation correlates data on in-line arrays better than those on staggered arrays. It is uncertain, however, how much of the fault lies with the correlation and how much with uncontrolled factors in the contributing experiments.


The convenient form of the Gunter-Shaw equation has been maintained and a simple multiplying factor has been used to bring the correlation into agreement with experimental data. The multiplying factor is shown in Figure 3 as a function of pitch-to-diameter ratio for various tube arrays.

The curve for equilateral, staggered array in Figure 3 corresponds closely to the data of Grimison (3). The curve for square, in-line array resembles Jakob's correlation (4) of Grimison's data, although older published data suggest that the Jakob correlation predicts too-high pressure drops at pitch-to-diameter ratios less than 1.5, data recently obtained in the OTEC laboratory at Carnegie-Mellon indicate that Jakob's correlation has the right trend.

Data obtained at Carnegie-Mellon also indicate that the adjusted Gunter-Shaw equations, applied locally, can be integrated without change to account for generation or loss of fluid at each tube position. This finding has been applied in the present case.

FIGURE 3
ADJUSTMENT OF THE GUNTER-SHAW
EQUATION TO CONFORM TO PUBLISHED DATA

RPP 10/13/77



(6)


How much pressure drop in the plenum of the evaporator can be tolerated depends on the pressure difference between the plenum and the vapor space below it. The relationship of discharge rate and pressure difference depends on the design of the device for applying liquid NH_3 to the outer surface of the fluted tube.

Experiments at Carnegie-Mellon have established the head vs discharge characteristics of apertures formed by truncating the flutes and closely fitting them to holes in the bottom of the plenum. These data have been applied directly to the present case.

⑦

References Cited

1. Gunter, A. Y. and W. A. Shaw, "A General Correlation of Friction Factors for Various Types of Surfaces in Crossflow", Trans. A.S.M.E., 67, 643 (1945).
2. Boucher, D. F. and C. E. Lapple, "Pressure Drop Across Tube Banks: Critical Comparison of Available Data and of Proposed Methods of Correlation", Chem. Eng. Progress, 44, 117 (1948)
3. Grimison, E. D., "Correlation and Utilization of New Data on Flow Resistance and Heat Transfer for Cross Flow of Gases Over Tube Banks", Trans. A.S.M.E., 59, 583 (1937).
4. Jakob, M., Trans. A.S.M.E., 60, 384 (1938).
Summarized in Mc Adams, W. H., "Heat Transmission", 3rd ed., McGraw-Hill Book Company, 1954, pp. 162-3.



(8)

Gunter - Shaw Equation

Let (CF) = correction factor (Fig. 3)

Except at very low Reynolds numbers,
not significant in the present case,

$$\begin{aligned} \frac{L}{(CF)} \frac{1}{\rho} \frac{dp}{dL} &= 1.92 \left(\frac{\mu}{D_r V_{max} \rho} \right)^{0.145} \left(\frac{1}{D_r} \right) \left(\frac{D_r}{S_T} \right)^{0.4} \left(\frac{S_L}{S_T} \right)^{0.6} \frac{V_{max}^2}{2g_c} \\ &= 1.92 \left(\frac{\mu}{\rho} \right)^{0.145} D_r^{-0.745} S_L^{0.6} S_T^{-1} \frac{V_{max}^{1.855}}{2g_c} \end{aligned}$$

where V_{max} = velocity through minimum cross-section
 S_T = transverse pitch
 S_L = longitudinal pitch
 g_c = conversion factor = $32.2 \frac{(\text{lb mass})(\text{ft})}{(\text{lb force})(\text{sec}^2)}$
 $= 4.18 \times 10^8 \frac{(\text{lb mass})(\text{ft})}{(\text{lb force})(\text{hr}^2)}$
 D_r = equivalent diameter
 $= \frac{4(S_T S_L - \frac{\pi}{4} D_o^2)}{\pi D_o} = D_o \left[\frac{4}{\pi} \left(\frac{S_T}{D_o} \right) \left(\frac{S_L}{D_o} \right) - 1 \right]$
 D_o = outside diameter of tube.
 L = length of travel in direction of flow
 p = static pressure
 ρ = density of fluid
 μ = viscosity of fluid

For an equilateral staggered array with
pitch = S and flow such that $S_T = S$, by
virtue of Fig. 2, $S_L = \sqrt{3}S/2$.

$$D_r = D_o \left[\frac{4}{\pi} \frac{\sqrt{3}}{2} \left(\frac{S}{D_o} \right)^2 - 1 \right] = D_o \left[1.103 \left(\frac{S}{D_o} \right)^2 - 1 \right]$$

⑨

Integration of the Garter-Shaw Equation
Within the Uniform Tube Bank

Let n = number of tubes in a row
 $L = S_L n$ if n is more than a few
 $dL = S_L dn$ (continuum model)

$$\frac{1}{(CF)} \frac{dp/\rho}{dn} = 1.92 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \frac{S_L^{1.6}}{S_T} \frac{V_{max}^2}{2g_c}$$

But $V_{max} = \dot{V}/A_{min} = \dot{V}/(S_T - D_o) L_T$

where \dot{V} = volumetric flow rate, cfs
 L_T = height of plenum, ft.
 V_{max} = velocity, ft/sec
 $g_c = 32.2 \text{ (lb-mass)(ft)/(lb-force)(sec}^2)$

If the velocity reaches zero n_0 tubes from the inlet, the initial volumetric flow rate \dot{V}_i must be

$$\dot{V}_i = \dot{V}_e n_0 \quad \text{and} \quad d\dot{V} = \dot{V}_e dn$$

where \dot{V}_e = volumetric rate of depletion per tube

$$dn = \frac{d\dot{V}}{\dot{V}_e} = \frac{(S_T - D_o) L_T}{\dot{V}_e} dV_{max}$$

$$\frac{1}{(CF)} \frac{dp}{\rho} = 1.92 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{S_L^{1.6}}{S_T}\right) \frac{(S_T - D_o) L_T}{\dot{V}_e} \frac{V_{max}^2 dV_{max}}{2g_c}$$

(10)

Integrating from $V_{max} = V_{maxi}$ to $V_{max} = 0$

$$\frac{1}{(CF)} \frac{\Delta P}{\rho} = \frac{1.92}{2.855} \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{S_L^{1.16}}{S_T}\right) \frac{(S_T - D_o) L_T}{\dot{V}_o} \frac{V_{maxi}^{2.855}}{2g_c}$$

$$\text{But } V_{maxi} = \frac{\dot{V}_i}{A_{min}} = \frac{\dot{V}_e n_o}{(S_T - D_o) L_T}$$

$$\begin{aligned} \frac{1}{(CF)} \frac{\Delta P}{\rho} &= 0.0104 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{S_L^{1.16}}{S_T}\right) \left(\frac{\dot{V}_e}{S_T - D_o}\right)^{1.855} \frac{n_o^{2.855}}{L_T^{1.855}} \\ &= 0.0104 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{1}{S_T}\right) \left(\frac{1}{S_L}\right)^{1.255} \left(\frac{\dot{V}_e}{S_T - D_o}\right)^{1.855} \frac{L}{L_T^{1.855}} \end{aligned}$$

(11)

Solution of a Particular Case

Evaporator:

$$D_o = 1.5 \text{ inches} = 0.125 \text{ ft.}$$

$$S/D_o = 1.25$$

$$\text{Length of tube} = 25 \text{ ft.}$$

$$\text{Inlet water temperature} = 80^\circ\text{F}$$

$$\text{Water velocity} = 6 \text{ ft/sec.}$$

$$\text{NH}_3 \text{ saturation temperature} = 70^\circ\text{F}$$

$$\text{Inlet liquid NH}_3 \text{ temperature} = 65^\circ\text{F}$$

$$\text{NH}_3 \text{ supplied / tube} = 166.74 \text{ lb/hr}$$

At 65°F , for liquid NH_3 ,

$$\mu = 0.370 \text{ lb/(hr)(ft)} = 1.028 \times 10^{-4} \text{ lb/(sec)(ft)}$$

$$\rho = 38.3 \text{ lb/ft}^3$$

$$(\mu/\rho)^{0.145} = 0.1556$$

$$\dot{V}_t = 166.74 / (38.3)(3600) = 0.001209 \text{ cfs / tube}$$

$$\dot{V}_t^{1.855} = 3.8717 \times 10^{-6}$$

$$(S_T - D_o)^{1.855} = (0.375/12)^{1.855} = 0.001614$$

$$S_L^{1.6} / S_T = (0.135)^{1.6} / 0.156 = 0.260$$

$$D_v = D_o \left[\frac{4}{\pi} \left(\frac{S_T}{D_o} \right) \left(\frac{S_L}{D_o} \right) - 1 \right] = 0.0906$$

$$(1/D_v)^{0.745} = 5.983$$

$$L = n S_u$$

$$(CF) = 0.81$$

$$\frac{1}{(CF)} \frac{\Delta P}{\rho} = (0.0104) (0.1556) (0.260) \left(\frac{3.8717 \times 10^{-6}}{0.001614} \right) (5.983) \frac{n_o^{2.855}}{L_T^{1.855}}$$

$$\frac{\Delta P}{\rho} = 4.89 \times 10^{-6} n_o^{2.855} / L_T^{1.855}$$

(12)

In alternative form,

$$\frac{\Delta p}{\rho} = \frac{4.89 \times 10^{-6}}{S_L^{2.855}} \frac{L^{2.855}}{L_T^{1.855}} = 0.00149 \frac{L^{2.855}}{L_T^{1.855}}$$

The effects of design parameters can be seen in the following forms of the local and integrated equations.

Local gradient:

$$\frac{dp/p}{dL} = 0.0273 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_0}\right)^3 \frac{(CF) (\dot{V}/L_T)^{1.855}}{\left(\frac{S}{D_0}\right)^{0.4} [1.103 \left(\frac{S}{D_0}\right)^2 - 1]^{0.745} \left[\frac{S}{D_0} - 1\right]^{1.855}}$$

Integrated for depletion:

$$\frac{\Delta p}{\rho} = 0.0125 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_0}\right)^{4.855} V_c^{1.855} \frac{(CF) L^{2.855} / L_T^{1.855}}{\left(\frac{S}{D_0}\right)^{2.255} [1.103 \left(\frac{S}{D_0}\right)^2 - 1]^{0.745} \left[\frac{S}{D_0} - 1\right]^{1.855}}$$

The terms containing the pitch-to-diameter ratio are numerically evaluated in Table 1. S is the nominal pitch, in this case the transverse pitch S_r .

Table 1. Effect of Pitch-to-Diameter Ratio on Pressure Drop Within Equilateral, Staggered Arrays

Pitch / Diam. (S/D _o)	(CF)
	$\left[\left(\frac{S}{D_o} \right)^{0.4} \left[1.103 \left(\frac{S}{D_o} \right)^2 - 1 \right]^{0.745} \left[\frac{S}{D_o} - 1 \right]^{1.855} \right]$
1.25	12.34
1.375	4.27
1.50	2.07
1.625	1.27
1.75	0.80

Pitch / Diam. (S/D _o)	(CF)
	$\left[\left(\frac{S}{D_o} \right)^{2.255} \left[1.103 \left(\frac{S}{D_o} \right)^2 - 1 \right]^{0.745} \left[\frac{S}{D_o} - 1 \right]^{1.855} \right]$
1.25	8.16
1.375	2.37
1.50	0.98
1.625	0.52
1.75	0.28

These results apply to the paths BD and CD (C'D) of Figure 1. The path lengths are

$$\overline{BD} = R - \frac{2}{\sqrt{3}} \left(\frac{R}{2} \right) = 0.423 R$$

$$\overline{CD} = \overline{C'D} = \frac{1}{\sqrt{3}} \left(\frac{R}{2} \right) = 0.289 R$$

Arbitrarily, set $R = 11.5$ ft for a shell diameter of 25 ft and maintain $R = (11.5/25) \times$ shell diameter for other shell sizes.


Shell diam. (ft)	18	25	35	50
R (ft)	8.3	11.5	16.1	23.0
L for path \overline{BD} (ft)	3.5	4.9	6.8	9.7
L for path \overline{CD} (ft)	2.4	3.3	4.7	6.7
$L^{2.855}$ for path \overline{BD}	35.8	93.4	238	657
$L^{2.855}$ for path \overline{CD}	12.2	30.2	83.0	228
$(\Delta p/p) L_T^{1.855}$ for path \overline{BD}	0.053	0.140	0.354	0.977
$(\Delta p/p) L_T^{1.855}$ for path \overline{CD}	0.018	0.045	0.123	0.339
$(\Delta p/p) L_T^{1.855}$ for whole R	0.626	1.590	4.156	11.51

Except for the smallest shell diameters it is therefore necessary to install radial mains to reduce the pressure drop, unless relatively large plenum heights are to be used.

Radial mains

When six radial mains are used, the number (N_R) of tubes removed to form the main determines whether the tubes on the sides of the main are in-line or staggered in relation to the direction of flow. This is shown in Figure 2. If N_R is an odd number, an in-line array results. This is the case to be analyzed here.

For the arrangement shown in Figure 1, each main draws from two isosceles triangles having a base of R length and 30° base angles.



Let r = radial distance from center of exchanger
 h = depth of triangular bank at r .
 H = distance $\overline{C'D}$ or \overline{CD} of Figure 1. = $0.289R$
 R = radius of tube bundle

$$\text{From } r=0 \text{ to } r = \frac{R}{2} \quad h = \frac{2H}{R} r = 0.578 r$$

$$\text{From } r = \frac{R}{2} \text{ to } r = R \quad h = \frac{2H}{R} (R-r) = 0.578(R-r)$$

(16)

Let n = number of tubes per row in the uniform bank

$$n = h / (0.866S) = h / (0.866 D_o (S/D_o)) \\ = 1.155 h / D_o (S/D_o)$$

Each row of tubes parallel to $\overline{C'D}$ carries the volumetric flow rate \dot{V}_r where

$$\dot{V}_r = 2 \dot{V}_t n = 2.31 \dot{V}_t h / D_o (S/D_o)$$

\dot{V}_t is the volumetric depletion rate / tube and the factor of 2 accounts for the fact that each main is fed by two triangular sections.

The number of rows parallel to $\overline{C'D}$ that deplete the main is related to r :

$$dn_r = -dr / S$$

Let \dot{V} = volumetric flow rate at r
 \dot{V}_i = volumetric flow rate in at $r = R$
 $\dot{V}_{i/2}$ = volumetric flow rate at $r = R/2$

From $r = \frac{R}{2}$ to $r = 0$..,

$$\dot{V} = \dot{V}_{i/2} - \int_{\dot{V}_{i/2}}^{\dot{V}} \dot{V}_r dn_r = \dot{V}_{i/2} - \frac{2.31 \dot{V}_t}{S D_o (S/D_o)} \int_{R/2}^r h dr$$

$$= \dot{V}_{i/2} - \frac{(2.31)(0.578) \dot{V}_t}{S D_o (S/D_o)} \int_{R/2}^r r dr$$

$$= \dot{V}_{i/2} - \frac{0.668 \dot{V}_t}{D_o^2 (S/D_o)^2} \left[\left(\frac{R}{2}\right)^2 - r^2 \right]$$

(17)

at $r=0$, $\dot{V}=0$

$$V_{1/2} = \frac{0.167 \dot{V}_c R^2}{D_o^2 (S/D_o)^2}$$

From the geometry of Figure 1, \dot{V}_i must equal the area $R \times 0.289 R \times$ depletion rate per unit area.

$$\begin{aligned} \dot{V}_i &= 0.289 R^2 \dot{V}_c / S_L S_T \\ &= 0.289 R^2 \dot{V}_c / 0.866 S^2 \\ &= 0.334 R^2 \dot{V}_c / D_o^2 (S/D_o)^2 \end{aligned}$$

From $r=R/2$ to $r=0$,

$$V = \frac{0.668 \dot{V}_c R^2}{D_o^2 (S/D_o)^2} \left(\frac{r}{R}\right)^2$$

$$\dot{V} = 2 \dot{V}_i (r/R)^2$$

From the geometry $\dot{V}_{1/2}$ would be expected to equal $0.5 \dot{V}_i$ as shown.

(18)

From $r = R$ to $r = R/2$,

$$\dot{V} = \dot{V}_i - \frac{2.31 \dot{V}_t}{D_0^2 (S/D_0)^2} \int_R^{R/2} r dr$$

$$= \dot{V}_i - \frac{(2.31)(0.578 \dot{V}_t)}{D_0^2 (S/D_0)^2} \int_0^{R/2} (R-r) d(R-r)$$

$$= \dot{V}_i - \frac{0.668 \dot{V}_t R^2}{D_0^2 (S/D_0)^2} \left[1 - \left(\frac{1}{2}\right) \right]^2$$

$$= \frac{0.668 \dot{V}_t R^2}{D_0^2 (S/D_0)^2} \left[\frac{1}{2} - 1 + 2\left(\frac{1}{2}\right) - \left(\frac{1}{2}\right)^2 \right]$$

$$\dot{V} = \frac{0.668 \dot{V}_t R^2}{D_0^2 (S/D_0)^2} \left[2\left(\frac{1}{2}\right) - \left(\frac{1}{2}\right)^2 - \frac{1}{2} \right]$$

(19)

Gunter - Shaw Equation for mains

$$\frac{1}{(CF)} \frac{dp/p}{dr} = 1.92 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{S_L}{S_T}\right)^{0.6} \frac{V_{max}^{1.855}}{2gc}$$

$$V_{max} = \dot{V} / (S_T - D_o) L_T \text{ as before}$$

$$\frac{1}{(CF)} \frac{dp/p}{dr} = 1.92 \left(\frac{\mu}{\rho}\right)^{0.145} \left(\frac{1}{D_v}\right)^{0.745} \left(\frac{S_L}{S_T}\right)^{0.6} \left[\frac{1}{(S_T - D_o) L_T}\right]^{1.855} \frac{\dot{V}^{1.855}}{2gc}$$

$$\frac{1}{(CF)} dp/p = K_1 \dot{V}^{1.855} dr$$

$$\frac{1}{(CF)} \frac{\Delta p}{\rho} = K_1 \int \dot{V}^{1.855} dr = K_1 R \int \dot{V}^{1.855} d\left(\frac{r}{R}\right)$$

$$\text{From } r=R \text{ to } r=R/2, \quad \dot{V} = K_2 \left[2\left(\frac{r}{R}\right) - \left(\frac{r}{R}\right)^2 - \frac{1}{2}\right]$$

$$\frac{1}{(CF)} \frac{\Delta p_1}{\rho} = K_1 R K_2^{1.855} \int_{1/2}^1 \left[2\left(\frac{r}{R}\right) - \left(\frac{r}{R}\right)^2 - \frac{1}{2}\right]^{1.855} d\left(\frac{r}{R}\right)$$

We can approximate the integral by numerical methods.

	r/R	$\Delta(r/R)$	$\left[2\left(\frac{r}{R}\right) - \left(\frac{r}{R}\right)^2 - \frac{1}{2}\right]^{1.855}$
0	1.000	0.125	0.276
1	0.875	"	0.260
2	0.750	"	0.216
3	0.625	"	0.150
4	0.500	"	0.076

By Simpson's Rule

$$\text{Integral} = \frac{1}{3}(0.125) [0.352 + 1.640 + 0.432] = 0.101$$

(20)

$$\frac{1}{(CF)} \frac{\Delta P_1}{\rho} = 0.101 R \left[\frac{0.668 \dot{V}_t R^2}{D_o^2 (S/D_o)^2} \right]^{1.855} K_1$$

$$\text{where } K_1 = \frac{1.92}{2g_c} \left(\frac{\mu}{\rho} \right)^{0.145} \left(\frac{1}{D_o} \right)^{0.745} \left(\frac{S_L^{0.6}}{S_T} \right) \left[\frac{1}{(S_T - D_o) L_T} \right]^{1.855}$$

$$\text{From } r = R/2 \text{ to } r = 0, \quad \dot{V} = K_2 \left(\frac{r}{R} \right)^2$$

$$\frac{1}{(CF)} \frac{\Delta P_2}{\rho} = K_1 R K_2^{1.855} \int_0^{1/2} \left(\frac{r}{R} \right)^{3.71} d\left(\frac{r}{R} \right)$$

$$= \frac{K_1 R K_2^{1.855}}{4.71} \left(\frac{1}{2} \right)^{4.71} = 0.00811 K_1 R K_2^{1.855}$$

$$\frac{1}{(CF)} \frac{\Delta P_2}{\rho} = 0.00811 R \left[\frac{0.668 \dot{V}_t R^2}{D_o^2 (S/D_o)^2} \right]^{1.855} K_1$$

The total pressure drop in the main is the sum

$$\frac{\Delta P}{\rho} = 0.1091 (CF) R \left[\frac{0.668 \dot{V}_t R^2}{D_o^2 (S/D_o)^2} \right]^{1.855} K_1$$

(21)

$$\begin{aligned}
 D_v &= D_0 \left[\frac{4}{\pi} \left(\frac{S_r}{D_0} \right) \left(\frac{S_L}{D_0} \right) - 1 \right] \\
 &= D_0 \left[\frac{4}{\pi} \frac{\sqrt{3}}{2} \left(\frac{S}{D_0} \right)^2 (N_R + 1) - 1 \right] \\
 &= D_0 \left[1.103 \left(\frac{S}{D_0} \right)^2 (N_R + 1) - 1 \right]
 \end{aligned}$$

$$\begin{aligned}
 S_L^{0.6} / S_r &= S^{0.6} / \frac{\sqrt{3}}{2} (N_R + 1) S = 1.163 / (N_R + 1) S^{0.4} \\
 &= \frac{1.163 / D_0^{0.4}}{(N_R + 1) (S / D_0)^{0.4}}
 \end{aligned}$$

$$\begin{aligned}
 (S_r - D_0) &= \frac{\sqrt{3}}{2} (N_R - 1) \left(\frac{S}{D_0} \right) D_0 - D_0 \\
 &= D_0 \left[0.866 (N_R + 1) (S / D_0) \right]
 \end{aligned}$$

Solution of the Particular Case Previously Stated

$$D_v = D_0 [1.723 (N_R + 1) - 1] = 0.125 [1.723 (N_R + 1) - 1]$$

$$S_L^{0.6} / S_r = \frac{1.163 / 0.435}{1.093 (N_R + 1)} = \frac{2.446}{N_R + 1}$$

$$(S_r - D_0) = 0.125 [0.866 (N_R + 1) (1.25)] = 0.1353 (N_R + 1)$$

$$(u/p)^{0.145} = 0.1556 \text{ as before}$$

N_R		1	3	5
$N_R + 1$		2	4	6
D_v		0.306	0.736	1.167
$D_v^{0.745}$	→	0.414	0.796	1.122
$S_L^{0.6} / S_r$	→	1.223	0.612	0.408
$S_r - D_0$		0.2706	0.5412	0.8118
$(S_r - D_0)^{1.235}$	→	0.0885	0.320	0.679

(22)

$$K_1 = \frac{1.92}{64.4} (0.1556) \frac{1}{D_v^{0.745}} \left(\frac{S_L^{0.6}}{S_T} \right) \left(\frac{1}{S_T - D_0} \right)^{1.855} \left(\frac{1}{L_T} \right)^{0.855}$$

$$K_1 L_T^{1.855} = 0.00464 \frac{1}{D_v^{0.745}} \left(\frac{S_L^{0.6}}{S_T} \right) \left(\frac{1}{S_T - D_0} \right)^{1.855}$$

$\frac{NR}{K_1 L_T^{1.855}} \rightarrow$	1	3	5
	0.155	0.0111	0.00248

$$\left[\frac{0.668 \dot{V}_L R^2}{D_0^2 (S/D_0)^2} \right]^{1.855} = \left[\frac{(0.668)(0.001209) R^2}{(0.125)^2 (1.25)^2} \right]^{1.855}$$

$$= (0.03308 R^2)^{1.855}$$

$$= 0.001794 R^{3.71}$$

(CF)
↓

$$\frac{\Delta P}{\rho} = (0.1091)(1.17)(0.001794) K_1 R^{4.71}$$

$$= 0.000229 K_1 R^{4.71}$$

$\frac{NR}{R^{4.71}} \left[\frac{(\Delta P/\rho) L_T^{1.855}}{R^{4.71}} \right] \rightarrow$	1	3	5
	3.55×10^{-5}	2.54×10^{-6}	5.68×10^{-7}

Shell Diam. (ft) →	18	25	35	50
R (ft) →	8.3	11.5	16.1	23.0
R ^{4.71}	2.13 × 10 ⁴	9.91 × 10 ⁴	4.83 × 10 ⁵	2.59 × 10 ⁶

(Δp/p) L _T ^{1.855} →				
N _R = 1	0.756	3.52	17.1	91.9
N _R = 3	0.054	0.252	1.23	6.58
N _R = 5	0.012	0.056	0.274	1.47

<u>N_R</u>	<u>L_T (ft)</u>	<u>Δp/p in main</u>			
1	1	0.756	3.52	17.1	91.9
	2	0.209	0.973	4.73	25.4
	3	0.099	0.459	2.23	12.0
3	1	0.054	0.252	1.23	6.58
	2	0.015	0.070	0.340	1.82
	3	0.007	0.033	0.160	0.857
5	1	0.012	0.056	0.274	1.47
	2	0.003	0.015	0.076	0.406
	3	0.002	0.007	0.036	0.192

(24)

Add the following pressure drop through \overline{CD}

Shell diam. (ft)	18	25	35	50
	<u>$\Delta p/p$ in \overline{CD}</u>			
$L_T = 1$ ft	0.018	0.045	0.123	0.339
2	0.005	0.012	0.034	0.094
3	0.002	0.006	0.016	0.044

92.6% of the pressure drop through the main occurs between $r = R$ and $r = R/2$. For the shell diameters above, this is as follows:

Shell Diam (ft)	18	25	35	50	
<u>N_R</u>	<u>$\Delta p/p$ in $1/2$ main</u>				
	<u>L_T (ft)</u>				
1	11	0.700	3.26	15.8	85.1
	2	0.194	0.901	4.38	23.5
	3	0.092	0.425	2.06	11.1
3	1	0.050	0.233	1.14	6.09
	2	0.014	0.065	0.315	1.68
	3	0.006	0.031	0.148	0.794
5	1	0.011	0.052	0.254	1.36
	2	0.003	0.014	0.070	0.376
	3	0.002	0.006	0.033	0.178

(25)

Total $\Delta P/P$ Through Outer
Half of main and Path \overline{CD}

Shell Diam. (ft)		<u>18</u>	<u>25</u>	<u>35</u>	<u>50</u>
<u>NR</u>	<u>L_T (ft)</u>	<u>$\Delta P/P$ (ft. of liquid NH₃)</u>			
1	1	0.718	-	-	-
	2	0.199	0.913	-	-
	3	0.094	0.431	2.08	-
3	1	0.068	0.278	-	-
	2	0.019	0.077	0.349	1.72
	3	0.008	0.037	0.164	0.838
5	1	0.029	0.097	0.377	-
	2	0.008	0.026	0.104	0.470
	3	0.004	0.012	0.049	0.222

Pressure Drop Through Path \overline{BD}

Shell Diam. (ft)		18	25	35	50
		<u>$\Delta P/P$ through \overline{BD}</u>			
<u>L_T = 1 ft</u>		0.053	0.140	0.354	0.977
2		0.015	0.039	0.098	0.270
3		0.007	0.018	0.046	0.127

(26)

Pressure Drop Through Tube
Bank Having No Mains

Shell Diam, (ft)	18	25	35	50
	<u>$\Delta P/P$ in Solid Bank</u>			
$L_T = 1 \text{ ft}$	0.626	-	-	-
2	0.173	0.440	1.15	-
3	0.082	0.207	0.541	1.50

10000

APPENDIX I.2
STRESS ANALYSIS

I.2. STRESS ANALYSIS

Mechanical design calculations for the 10 MWe OTEC evaporator and condenser attempt to determine the basic metal thickness requirements with no more than 20 percent error in weight requirements for elements of the pressure envelopes. Because the design is preliminary, little detailed consideration is made for local reinforcement requirements at nozzles, tubesheet to shell joints, or similar points of high localized stress where further design effort in the final design stage is indicated.

Calculations for the 0.2 MWe exchangers are less rigorous than those for the 10 MWe exchangers due to the less severe environment and to the more straightforward construction.

The first approximation for the wall thickness in the evaporator and condenser shells is based on the ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, using a 136 psig shell pressure in the evaporator with an inside diameter of 315 inches and a minimum wall thickness of 2 inches including 1/2 inch allowance for corrosion. Similarly the 325 inch diameter condenser shell requires 1-1/2 inch thickness for a design pressure of 86.3 psig. However, the 1-1/2 inch thick condenser shell requires stiffening rings in order to withstand a specified external pressure of 13.5 psig.

In both the evaporator and the condenser, the tubesheets are stayed by the 1 inch tubes spaced on a 1-1/4 inch spacing. Since the 274-1/4 inch diameter evaporator tube bundle is eccentric to the shell by 14 inches, the maximum unsupported span in the tubesheet is 34-3/8 inches. A stayed flat head with 34-3/8 inch pitch and 20 percent ligament efficiency would seem to imply a 4-5/16 inch thickness according to the code, although no Section 8, Division 1, rules exist to combine considerations of ligament efficiency and stay rod pitch for a flat head. The above deduction is conservative, and tubesheet thicknesses of 4-13/16 inches for the evaporator and of 4-5/16 inches for the condenser are therefore selected for further investigation.

In both the evaporator and the condenser, deformed titanium tubes are to be used. Thirty-six ridges are to be rolled or pressed into the wall of 1 inch diameter tubing, 0.031 inch thick in the case of the evaporator and 0.026 inch thick in the case of the condenser. The deformation will occur for the entire length of each tube except at the tube ends, where the tube joints the tubesheet. Since the tube stiffness is reduced by compressing the tube wall material inward toward the tube axis, subsequent mechanical analysis requires that the deformed tubes be assigned a combination of wall thickness and diameter such that the "equivalent tube" has the same cross-sectional area and moment of inertia as the deformed tube.

The remainder of the preliminary calculations consider a shellside pressure containment envelope to consist of six elements. There is the tube bundle, the upper and lower tubesheets which have the same outside diameter as the tube bundle, the upper and lower annular rings which bridge the span between the tubesheet and the shell, and finally the shell itself. Stresses within the elements of the shellside pressure envelope are investigated by approximating the system with an axisymmetric system. Since high shell stresses at the annular ring are anticipated, the maximum ring width is assumed. The tubesheet diameter is reduced accordingly. Dimensions of the shell and tubes are assumed unchanged from the earlier shell and "equivalent tubes". A computer program is used to investigate system stresses resulting from axial loads caused by weight, shellside and tubeside fluid pressures, and temperature changes.

A design life of 30 years is desired. This period is defined as 1000 shellside pressure cycles as well as an undefined number of specified accelerations representing loading cycles due to motion of the ocean surface. Additional undetermined loads will result from motion of the vessel upon which the apparatus is mounted and from impact of ocean waves upon the apparatus. The specified accelerations due to motion of the ocean surface are so low as to make resulting stress ranges trivial, and they are therefore ignored. Motion of the vessel and impact of ocean waves is beyond the scope of preliminary design, and these effects are therefore undefined.

The computer program used to evaluate the effects of system loading yields stress values based upon elastic deformation only. High secondary stresses therefore indicate that local yielding can be expected to occur. This shakedown plastic deformation occurs typically during hydrostatic testing. Final design should explore the possible need for reinforcement in areas where high secondary stress is indicated.

Only the shell stresses are expected to undergo significant stress variations resulting from shellside pressure cycling. Other loading cycles however may cause the final design to incorporate reinforcement for the shell.

APPENDIX I.2.1
10 MWe HEAT EXCHANGER

Customer	TRW	Pages	Page	5
Subject	Evaporator & Condenser Tubes	By	U R M	
Project	5304-100	Date	9-18-75	

Tube moment of inertia (Evaporator)

Undeformed tube 1" OD x .031

$$I = \frac{\pi}{64} (D^4 - d^4) = .0110873$$

$$J = .0221746$$

$$A = \frac{\pi}{4} (D^2 - d^2) = .0943703$$

polar radius of gyration

$$\rho = [J/A]^{1/2} = 0.4847414$$

mean radius of wall

$$\bar{r} = \frac{1}{4} (D^2 + d^2) = 0.469961$$

$$A\bar{r}^2 = 0.0208429$$

$$J - A\bar{r}^2 = 0.0013317$$

Deformed tube

Note: It is obviously inaccurate but of relatively small error to hold $(J - A\bar{r}^2)$ constant

$$J - A\bar{r}^2 = 0.0013317$$

$$\bar{r} \approx \frac{1}{4} (.99 + .82) = 0.4625$$

$$J = 0.021518$$

$$I = 0.010759$$

Customer	TRW	Pages	Page 6
Subject	Evaporator & Condenser Tubes	By	
Project	S304-100	Date	

Equivalent evaporator tube dimensions

$$A = .0943703 = \frac{\pi}{4} (D_e^2 - d_e^2)$$

$$I = .010759 = \frac{\pi}{64} (D_e^4 - d_e^4)$$

FOR PRELIMINARY DESIGN

$$D_e^4 - d_e^4 = .2191805$$

$$D_e^2 - d_e^2 = .1201559$$

$$D_e^2 = .1201559 + d_e^2$$

$$D_e^4 = .0144374 + .2403118 d_e^2 + d_e^4$$

$$.0144374 + .2403118 d_e^2 = .2191805$$

$$.2403118 d_e^2 = .2047431$$

$$d_e = .9230326$$

$$D_e = .9859741$$

Customer	TRW	Pages	Page 7
Subject	Evaporator & Condenser tubes	By	
Project	5304-100	Date	

(Condenser)
Undeformed tube 1" OD x .026 wt

$$I = \frac{\pi}{64} (D^4 - d^4) = .009441$$

$$J = .018882$$

$$A = \frac{\pi}{4} (D^2 - d^2) = .0795576$$

$$P = [J/A]^2 = .4871728$$

$$\bar{r} = \frac{1}{4} (D^2 + d^2) = .474376$$

$$A\bar{r}^2 = 0.0179257$$

$$J - A\bar{r}^2 = 0.0009563$$

PRELIMINARY
FOR DESIGN

Deformed tube

$$\bar{r}_c \approx \frac{1}{4} (.99487) = .465$$

$$J \approx 0.0181586$$

$$I = 0.0090793 = \frac{\pi}{64} (D_c^4 - d_c^4)$$

$$A = 0.0795576 = \frac{\pi}{4} (D_c^2 - d_c^2)$$

$$D_c^4 - d_c^4 = .1849619$$

$$D_c^2 - d_c^2 = .1012958$$

$$D_c^4 = .0102608 + .015912 d_c^4 + d_c^4$$

$$12025916 d_c^4 = .849619 - .0102608 = .8393582$$

$$d_c = 0.928613$$

$$D_c = 0.931645$$

Customer	TRW	Pages	Page
Subject	Evaporator / Condenser	By	NRT
Project	5304-100-117-1	Date	8/25/73

Pursue Section VIII div 1 design further

I Evaporator
Shell side

for NH₃ sat @ 70°F

$$p_{sat} = 123.8 \text{ psia} = 114.1 \text{ psig}$$

$$v_g = 2.312 \text{ ft}^3/\text{lbm}$$

$$\rho_g = .4325259 \text{ lbm/ft}^3$$

$$= .0002503043 \text{ lbm/in}^3$$

Tube sheet

Item 10


$$\theta_{s1} = 57.8^\circ \text{ F} \quad \theta_{s2} = 70^\circ \text{ F}$$

$$p_{s1} = .0002503043 \text{ lbm/in}^3 \text{ (vapor)}$$

$$T_s = 150^\circ \text{ F}$$

$$p_s = 136 \text{ psia}$$

$$d_b = 315''$$



$$D_t = 274.25'' \text{ } \infty \text{ tube bundle}$$

$$D_{pt} = 1'' \text{ } \infty \text{ tube in TS}$$

$$t_{pt} = .031'' \text{ tube in TS}$$

Tube side

$$\theta_{t1} = 80^\circ \text{ F} \quad \theta_{t2} = \underline{(74.1^\circ \text{ F})}$$

equivalent tube properties
for stiffness:

$$D_p = 1.3542698$$

$$t'_p = 0.0225566$$

for flow

$$d'_p = 0.860''$$

$$\text{depth of groove} = 0.025''$$

$$n_p = 42667 \text{ tubes}$$

$$p_{t1} = 63.77 \text{ lbm/ft}^3 = .0369039 \text{ lbm/in}^3 @ 80^\circ \text{ F}$$

$$p_{t2} = 63.8072 \text{ lbm/ft}^3 = .0369254 \text{ lbm/in}^3 @ 74.1^\circ \text{ F}$$

$$\dot{m}_t = 273,500,000 \text{ lbm/hr} = 75972.222 \text{ lbm/sec}$$

Customer	Pages	Page →
Subject	By	
Project	Date	

MAX HEAD LOSS

assumed flow area

$$a'_f = \frac{\pi}{4} (.860)^2 = .5808804$$

$$A_f = 24784.424 \text{ in}^2$$

$$\rho_{avg} = .0369146 \text{ lbm/in}^3$$

$$\dot{m} = \bar{\rho} A V_{avg} \quad ; \quad V_{avg} = \frac{\dot{m}}{\bar{\rho} A_f}$$

$$= 83.038181 \text{ in/sec}$$

$$(6.9 \text{ ft/sec})$$

$$\mu_{avg} = \frac{\mu_1 + \mu_2}{2}$$

$$= \frac{2.24 + 2.5756}{2}$$

$$= 2.3778 \frac{\text{lbm}}{\text{ft-hr}}$$

$$= 55.041626 \times 10^{-6} \frac{\text{lbm}}{\text{in-sec}}$$

$$N_{RE} = \frac{\bar{\rho} V_{avg} d_p'}{\mu}$$

$$= .0478941 \times 10^6$$

PRELIMINARY
FOR DESIGN

Customer	Pages	Page 10
Subject	By	
Project	Date	

Re: Binder: Fluid Mechanics 3rd

assume $e/D = .012$ (very rough)
 $V_{avg} = 83.03 \text{ } 8181 \text{ in/sec}$

V	83.04	106.7	106.2 ←
N_{RE}	4.79×10^4	6.16×10^4	6.13×10^4
$(\frac{V}{V_{avg}})$.778	.782	<u>.782</u>

PRELIMINARY
FOR DESIGN

flow is turbulent
 $f = 0.04$

$$\begin{aligned} \text{head loss} &= f \cdot \frac{1}{d_p} \cdot \frac{V^2}{2g} \\ &= .04 \cdot \frac{12}{186} \cdot \frac{83.04^2}{144 \times 2 \times 32.2} \\ &= 0.415 \text{ ft/ft} \end{aligned}$$

in a 29' long tube

head loss = 12.035' plus entrance and exit losses

This is close enough to TRW's guess to accept their value of 9'-6"

Customer	TRW	Pages	Page 11
Subject	10 MWe EVAPORATOR	By	FWC
Project	5304-100-117-1	Date	7/28-78

PRELIMINARY
 FOR DESIGN

1. INTERNAL PRESSURE PER UG 27

$P = 136 \text{ PSIG}$, $CA = \frac{1}{2}''$ OUTSIDE INSIDE
 $MTL - SA - 516 - 60$
 $T = \text{UNDER } 650 \text{ F}$

$$t = \frac{PR}{SE - 6P} + C = \frac{136 \times 157.5}{15000 \times 1 - .6 \times 136} + \frac{1}{2} = 1.436 + \frac{1}{2} = 1.936$$

100% X-R & PWHT REQUIRED USE 2" R

2. EXTERNAL PRESSURE PER UG 28

$P = 13.5 \text{ PSIG}$ $CA \frac{1}{2}''$ OUTSIDE , 0 INSIDE
 $MTL - SA 516 - 60$
 $T - < 300 \text{ F}$ $A = .0004$

$$L/D_o = \frac{348}{318} = 1.09 \quad B = 5900$$

$$D_o/t = \frac{318}{1.5} = 212$$

$$P_a = \frac{4}{3} \frac{B}{(D_o/t)} = \frac{4}{3} \times \frac{5900}{212} = 37.1 \text{ PSIG} > 13.5 \text{ OK}$$

NO RINGS NEEDED w/ $\frac{1}{2}''$ R (+ $\frac{1}{2}''$ CA).
 BUT USE RINGS AS FINAL DESIGN, INCORPORATING
 WAVE EFFECTS, WILL CERTAINLY REQUIRE STIFFENING.

Customer	TRW	Pages	Page 12
Subject	10 MW CONDENSER	By	Fwc
Project	5304-100-117-1	Date	7-26-78

3. INTERNAL PRESSURE PER UG 27

$P = 86 \text{ PSIG}$ CA $\frac{1}{2}$ OUTSIDE INSIDE


MTL - SA 516-60

T - UNDER 650F

$$t = \frac{PR}{SE - 6P} + C = \frac{86 \times 162.5}{15000 \times 1 - 6 \times 86} + \frac{1}{2} = .935 + \frac{1}{2} = 1.434$$

USE $1\frac{1}{2}$ TR

100% X-R IS REQUIRED



4. EXTERNAL PRESSURE PER UG 28

$P = 13.5 \text{ PSIG}$ CA $\frac{1}{2}$ OUTSIDE, 0 INSIDE

MTL - SA 516-60

T < 300F

$A = .00038$

$$L/D_o = \frac{174}{326.875} = .532$$

$B = 5500$

$$D_o/t = \frac{326.875}{.9375} = 349$$

$$F_a = \frac{4}{3} \frac{B}{(D_o/t)} = \frac{4}{3} \times \frac{5500}{349} = 21.0 \text{ PSIG} > 13.5 \text{ OK}$$

ONE RING REQUIRED BUT USE 2 RINGS TO STRADDLE VAPOR INLET

5. SIZE THE STIFFENING RINGS PER UG-29


RING { NEW: 11" x 2 1/2" A₁ = A₂
CORR: 10.5" x 1 1/2"

$A_1 = 10.5 \times 1\frac{1}{2} = 15.75 \text{ IN}^2$

$A_2 = .937 \times [1.1 \sqrt{D_o t}]$

$A_2 = .937 \times [1.1 \sqrt{326.875 \times .937}]$

$A_2 = 18.11 \text{ IN}^2$



Customer	TRW	Pages	Page 13
Subject	10 MWE CONDENSER	By	FWC
Project	5304-100-117-1	Date	7-26-78

SIZING STIFFENER RING (CONT)

$$I_1 = \frac{1.5 \times 10.5^3}{12} = 144.7 \text{ IN}^4$$

$$I_2 = \frac{19.25 \cdot .937^3}{12} = 1.320 \text{ IN}^4$$

COMPOSITE CG

$$C = \frac{C_1 A_1 + C_2 A_2}{A_1 + A_2} = \frac{6.687 \times 15.75 + .462 \times 18}{15.75 + 18} = 3.371$$

COMPOSITE I'

$$I' = I_1 + A_1 d_1^2 = 144.7 + 15.75 \cdot 3.316^2 = 317.9$$

$$I'' = I_2 + A_2 d_2^2 = 1.32 + 18 \cdot 2.902^2 = 152.7$$

TOTAL I 470.8 IN⁴ AVAILABLE.

$$B = \frac{3}{4} \left[\frac{P D_o}{t + A_s/L_s} \right] = \frac{4}{3} \left[\frac{13.5 \times 326.875}{.937 + \left(\frac{15.75}{12} \right)} \right] = 5485$$

$$A = .00038$$

I_s' REQUIRED

$$I_s' = \frac{[D_o^2 L_s (t + \frac{A_s}{L_s}) A]}{10.9}$$

$$I_s' = \frac{[326.875^2 \times 116 (.937 + \frac{15.75}{116}) .00038]}{10.9}$$

$$I_s' = 463 \text{ IN}^4 \text{ REQUIRED}$$


2 - 11" x 2 1/2" RINGS REQUIRED

PRELIMINARY
FOR DESIGN

Customer	Pages	Page 14
Subject	By	
Project	Date	

Tubesheet

PRELIMINARY
FOR DESIGN



$$p = \frac{1.25 \sqrt{3}}{2} = 1.0825317$$

$$P = 136 \text{ psi}$$

$$S = 15000$$

$$C = 2.2$$

$$t = 1.0825317 \sqrt{\frac{136}{2.2 \times 15000}}$$

$$t_R = 0.06 \text{ " req'd.}$$

However, the dist. of tube bundle to shell is 34.375" max

$$\text{ligament efficiency} = \eta = \frac{1.25 - 1.0}{1.25} = 0.2$$

$$p' = \frac{34.375 \sqrt{3}}{2} = 29.769623$$

$$P = 136$$

$$\eta S = 3000$$

$$C = 2.2$$

$$\therefore t = 29.8 \sqrt{\frac{136}{2.2 \times 3000}} = 4.2734 \text{ "}$$

$4 \frac{13}{16}$ " thickness suffices

Customer	Pages	Page 15
Subject	By	ukm
Project	Date	9/13/8

PRELIMINARY
FOR DESIGN

Item 101 Evaporator
Shell Side (subscript "s")

$T_{s \text{ in}} = 57.8^\circ\text{F}$

$T_{s \text{ out}} = 70^\circ\text{F}$

$P_{\text{sat}} @ 70^\circ\text{F} = 129.8 \text{ psia} = 114.1 \text{ psig}$

$P_{\text{design}} = P_s = 136 \text{ psig}$


$\rho_s = .0002503043 \text{ lbm/in}^3 \text{ (vapor)}$

$d_s = 315" \text{ ID}$

$D_s = 319" \text{ OD}$

Tubesheet

actual tubesheet 274.25" OD w/ 42667 ea 1" ϕ holes



equivalent tube sheet 274.25" avg, 246.25 min, 302.25 max

Tube Side


$T_{t \text{ in}} = 80^\circ\text{F}$

$T_{t \text{ out}} = 74.1^\circ\text{F}$

$\rho_{t_1} = .0369039 \text{ lbm/in}^3 @ 80^\circ\text{F}$

$\rho_{t_2} = .0369254$

Customer	Pages	Page 16
Subject	By	
Project	Date	



Input to FTS program

$$A_p = .0943763 \times 42667 = 4026.4975 \text{ in}^2$$

$$A_f = \frac{\pi}{4} [1 - (.025 + .04)]^2 \times 42667 = 25367$$

$$A_t = \frac{\pi}{4} (274.15)^2 - A_p - A_f = 29681.543 \text{ in}^2$$

$$l_p = \text{tube length} = 348'' \quad \underline{\underline{59072.197 \text{ in}^3}}$$

Tube bundle volume

$$l_p (A_p + A_t) = 11730397 \text{ in}^3$$

$$\text{wt of sea water displaced} = 432897.39 \text{ lb}_m$$

$$P_{t1} = 9.5' \times 64 / 144 = 4.222 \text{ psi}$$

$$P_{t2} = 348 \times 64 / 1728 = 12.838 \text{ psi}$$

wt. of tubes	227130.30	lb
tubesheets	71047.018	
baffles	51175.22	
tube bundle wt	<u>349353.03</u>	lb
tube bundle ΔP force	<u>249415.34</u>	
total downward force	598763.97	lb
less displacement	<u>432897.39</u>	
apparent wt, app	165871.58	lb

Customer	Pages	Page 17
Subject	By	
Project	Date	

**PRELIMINARY
FOR DESIGN**

In the computer runs,
Horizontal run neglects gravity effects.

In operation, effective $\Delta P = (4.222 - 12.883) \frac{274.25}{242.25}$

$\Delta P = -10.749611$

Vertical run includes gravity effects

In operation, effective weight: 165871.58 lbf

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

Customer	Pages	Page 15
Subject	By	
Project	Date	

1
2
3
4
5
6
7
8
9

**PRELIMINARY
FOR DESIGN**

CH15

PROJECT 5304-100
PROBLEM NO 21

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-76

INPUT

EVAPORATOR ITEM 101 315 IN ID 348 IN LG 274-1/4 IN TB
HORIZONTAL W/SMALL TUBE BUNDLE & THIN WALLS

UNITS


LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	HORIZONTAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	PRESSURE DROP

40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

Customer	Pages	Page 19
Subject	By	
Project	Date	



CH15

PROJECT 5304-100
PROBLEM NO 21

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

16-78

TUBE DATA

OD	0.98597
THICKNESS	0.03147
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	42667
OPERATING PRESSURE	4.22220
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	77.05000
AVERAGE TEMPERATURE	70.47500
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.62834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	-10.75000

30
31
32
33
34
35
36
37
38
39
40

Customer	Pages	Page 20
Subject	By	
Project	Date	

PRELIMINARY
FOR DESIGN

CH15

PROJECT 5304-100
PROBLEM NO 21

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

SHELL DATA

ID	315.00000
THICKNESS	2.00000
OPERATING PRESSURE	136.00000
HYDROSTATIC TEST PRESSURE	204.00000
AVERAGE METAL TEMPERATURE	71.95000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00025
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.81250	4.81250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.03100	0.03100
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
THIRF RIND F OD	246.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	80.00000	80.00000
SHELLSIDE	57.80000	57.80000
AVERAGE	68.90000	68.90000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	79.60000	79.60000
TEMPERATURE DROP	22.20000	22.20000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

Customer	Pages	Page 21
Subject	By	
Project	Date	

* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.
CH15

PROJECT 5304-100
PROBLEM NO 21

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

PRELIMINARY
FOR DESIGN

		OUTPUT		
		H-1	H-2	H-3
	PSI	NORMAL OPERATING	HYDROSTATIC TEST SHELL	HYDROSTATIC TEST TUBES
PRESSURE				
TUBESIDE		4.222	0.000	25.889
SHELLSIDE		136.000	204.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.475	70.000	70.000
SHELL		71.950	70.000	70.000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		18.806	18.746	6.678
TUBESHEET 2		18.806	18.746	6.678
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1364.404	1644.492	-462.229
ALLOWABLE		18750.000	28125.000	-4813.922
TUBESHEETS				
1 BENDING CALCULATED		8384.180	10573.885	2689.474
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		787.848	304.648	-273.293
ALLOWABLE		16000.000	24000.000	24000.000
2 BENDING CALCULATED		8304.180	10573.885	2689.474
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		787.848	304.648	-273.293
ALLOWABLE		16000.000	24000.000	24000.000
RINGS				
1 BENDING CALCULATED		9287.214	21922.555	531.411
ALLOWABLE		32000.000	48000.000	48000.000
2 BENDING CALCULATED		9287.214	21922.555	531.411
ALLOWABLE		32000.000	48000.000	48000.000
SHELL				
CALCULATED		95404.114*	127438.999*	-3035.160
ALLOWABLE		64000.000	96000.000	96000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2887.677	4470.298	567.312
ALLOWABLE		12500.000	18750.000	18750.000
SHELL				
CALCULATED		14325.333	16065.000	0.000
ALLOWABLE		15000.000	22500.000	22500.000

Customer	Pages	Page 22
Subject	By	
Project	Date	


* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

PROJECT 5304-100
PROBLEM NO 21

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

OUTPUT



		LOSS OF TUBESIDE POWER ^{H-4}	LOSS OF SHELLSIDE POWER ^{H-5}	BUNDLE AND FLUID WEIGHT ^{H-6}
PRESSURE	PSI			
TUBESIDE		0.000	4.222	0.000
SHELLSIDE		136.000	0.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.475	70.475	70.000
SHELL		71.950	71.950	70.000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		18.806	3.314	0.000
TUBESHEET 2		18.806	3.314	0.000
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1442.800	-66.206	0.000
ALLOWABLE		18750.000	-3208.972	18750.000
TUBESHEETS				
1 BENDING CALCULATED		8799.091	1301.764	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR CALCULATED		835.684	-42.148	0.000
ALLOWABLE		16000.000	16000.000	11250.000
2 BENDING CALCULATED		8799.091	1301.764	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR CALCULATED		835.684	-42.148	0.000
ALLOWABLE		16000.000	16000.000	11250.000
RINGS				
1 BENDING CALCULATED		9336.767	-109.212	0.000
ALLOWABLE		32000.000	32000.000	22500.000
2 BENDING CALCULATED		9336.767	-109.212	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHELL				
CALCULATED		96053.418*	-915.099	0.000
ALLOWABLE		64000.000	64000.000	64000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2980.199	61.920	0.000
ALLOWABLE		12500.000	12500.000	12500.000
SHELL				
CALCULATED		14325.333	0.000	0.000
ALLOWABLE		15000.000	15000.000	15000.000

Customer	Pages	Page 23
Subject	By	
Project	Date	

1
2
3
4
5
6
7
8
9
10
11
12

PRELIMINARY
FOR DESIGN

CH15

PROJECT 5304-100
PROBLEM NO 22

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

INPUT

EVAPORATOR ITEM 101 315 IN ID 348 IN LG 274-1/4 IN TB
VERTICAL W/SMALL TUBE BUNDLE & THIN WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

Customer	Pages	Page 24
Subject	By	
Project	Date	

PRELIMINARY
FOR DESIGN

CH15

PROJECT 5304-100
PROBLEM NO 22

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

TUBE DATA

OD	0.98597
THICKNESS	0.03147
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	42667
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	165872.00000

49
50
51
52
53
54
55
56
57
58
59
60


Customer	Pages	Page 25
Subject	By	
Project	Date	

CH15

PROJECT 5304-100
PROBLEM NO 22

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78



SHELL DATA

ID	315.00000
THICKNESS	2.00000
OPERATING PRESSURE	136.00000
HYDROSTATIC TEST PRESSURE	204.00000
AVERAGE METAL TEMPERATURE	71.95000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00025
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.81250	4.81250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.03100	0.03100
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	246.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	80.00000	80.00000
SHELLSIDE	57.80000	57.80000
AVERAGE	68.90000	68.90000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	79.60000	79.60000
TEMPERATURE DROP	22.20000	22.20000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

Customer	Pages	Page 26
Subject	By	
Project	Date	

CH15 * REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

PROJECT 5304-100 FIXED TUBESHEET EXCHANGERS 9-16-78
 PROBLEM NO 22 ENGLISH UNITS

		OUTPUT		
		NORMAL OPERATING	HYDROSTATIC TEST SHELL	HYDROSTATIC TEST TUBES
PRESSURE	PSI			
TUBESIDE		4.218	0.000	25.889
SHELLSIDE		136.000	204.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.900	70.000	70.000
SHELL		71.950	70.000	70.000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		18.806	18.746	6.678
TUBESHEET 2		18.806	18.746	6.678
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1352.264	1643.172	-487.830
ALLOWABLE		18750.000	28125.000	-4813.922
TUBESHEETS				
1 BENDING CALCULATED		10933.219	22984.372	12832.831
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		876.049	652.794	327.765
ALLOWABLE		16000.000	24000.000	24000.000
2 BENDING CALCULATED		5876.980	13676.722	15067.399
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		693.308	-281.928	-682.208
ALLOWABLE		16000.000	24000.000	24000.000
RINGS				
1 BENDING CALCULATED		8179.166	16519.751	5934.214
ALLOWABLE		32000.000	48000.000	48000.000
2 BENDING CALCULATED		10440.409	27528.486	5181.540
ALLOWABLE		32000.000	48000.000	48000.000
SHELL				
CALCULATED		107219.540*	159717.212*	-34497.951
ALLOWABLE		64000.000	96000.000	96000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2887.769	4470.290	567.312
ALLOWABLE		12500.000	18750.000	18750.000
SHELL				
CALCULATED		14325.333	16065.000	0.000
ALLOWABLE		15000.000	22500.000	22500.000

FOR DESIGNER'S OR ELIMINATE


Customer	Pages	Page 27
Subject	By	
Project	Date	

CH15 * REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

PROJECT 5304-100
PROBLEM NO 22


FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78



		LOSS OF TUBESIDE POWER	LOSS OF SHELLSIDE POWER	BUNDLE AND FLUID WEIGHT
OUTPUT				
PRESSURE	PSI			
TUBESIDE		0.000	4.218	0.000
SHELLSIDE		136.000	0.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.900	70.900	70.000
SHELL		71.950	71.950	70.000
INSTAYED THICKNESS	INCH			
TUBESHEET 1		18.806	3.312	0.000
TUBESHEET 2		18.806	3.312	0.000
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1430.725	-72.200	-7.967
ALLOWABLE		18750.000	-3208.972	-3209.281
TUBESHEETS				
1 BENDING CALCULATED		11347.032	4030.989	3257.594
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR CALCULATED		923.866	73.439	88.810
ALLOWABLE		16000.000	16000.000	11250.000
2 BENDING CALCULATED		6290.794	4031.206	-3257.580
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR CALCULATED		741.125	-137.238	-93.931
ALLOWABLE		16000.000	16000.000	11250.000
RINGS				
1 BENDING CALCULATED		8228.575	-1215.188	1111.420
ALLOWABLE		32000.000	32000.000	22500.000
2 BENDING CALCULATED		10489.818	-1098.550	-1149.823
ALLOWABLE		32000.000	32000.000	22500.000
SHELL				
CALCULATED		107867.207*	-12353.882	-11891.008
ALLOWABLE		64000.000	64000.000	64000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2980.199	61.858	0.000
ALLOWABLE		12500.000	12500.000	12500.000
SHELL				
CALCULATED		14325.333	0.000	0.000
ALLOWABLE		15000.000	15000.000	15000.000

Customer	Pages	Page 28
Subject	By	R 31
Project	Date	1/18/8



Analysis of FTS Computer Run
 (RESOLUTION INTO FORCES AND MOMENTS)
 Tubesheet Shears

TS dia = 246.25"

TS thk = 4.8125"

TS shear area = 3692.7949 in²

TS 1

TS 2

1. Consider bundle & shell fluid wt submerged in sea water (column V6)	stress	+ 88.10	- 93.931
	load	<u>325335.22 lb ↓</u>	<u>346867.9 lb ↓</u>
2.* Consider wt of seawater displaced * NOT ON COMPUTER RUN		(+59.614) <u>216448.69 lb ↓</u>	(-59.614) <u>216448.69 ↓</u>
3. Consider shellside pressure @ 136 psi (column H4)	stress	+ 835.684	+ 835.684
	load	<u>3086009.5 ↑</u>	<u>3086009.5 ↓</u>
4. Consider tubeside pressure @ 4.222 psi (column H5)	load	- 42.148 <u>155643.91 ↓</u>	- 42.148 <u>155643.91 ↑</u>
5. Consider wt of shellside fluid [columns (V4-V6-H4)]	stress	+ 0.082	- 0.623
	load	<u>302.90317 ↓</u>	<u>2319.0751 ↑</u>
6. Consider wt & ΔP of tubeside fluid [columns (V5-H5-V6)]	stress	+ 27.427	- 1.159
	load	<u>101503.55 ↓</u>	<u>4279.9491 ↓</u>
7. Consider thermal effects (V1+V6-V4-V5)	stress	- 32.446	- 4.510
	load	<u>119816.42 ↑</u>	<u>16654.50 ↓</u>

Customer:	Pages	Page 29
Subject	By	
Project	Date	

PRELIMINARY
FOR DESIGN

Evaporator

I Tubesheet 1

open shear force : $F_t = 876.049 \times 4.8125 \times 246.25 \pi$
 $= +3\,261\,558.8 \text{ lb}_f$

submerged
 (from FTS output)

$$\sigma_p \text{ max} \approx \frac{6 M_b}{t^2}$$

$$= 10\,933.219 \text{ psi}$$

$$\sigma_b \text{ max} = 136 \text{ psi}$$

$$\sigma_\lambda \text{ max} = -136 \text{ psi}$$

$$\therefore \sigma_p - \sigma_\lambda = 11\,069.219 \text{ psi}$$

II Tubesheet 2

open shear force = $693.308 \times 4.8125 \times 246.25 \pi$
 $= +2\,581\,208.7 \text{ lb}_f$

$$\sigma_p \text{ max} = 5976.980 \text{ psi}$$

$$\sigma_b = 136 \text{ psi}$$

$$\sigma_\lambda = -136 \text{ psi}$$

$$\therefore \sigma_p - \sigma_\lambda = 6012.98 \text{ psi}$$

III Shell

$$\sigma_E = 14\,325.333 \text{ psi}$$

$$A_s = 1496.1536 \text{ in}^2$$

$$E_s = 118\,215.95 \text{ in}^3$$

(from FTS output) $\sigma'_\lambda = 107\,219.54 \text{ psi}$

Customer	Pages	Page 30
Subject	By	
Project	Date	

add effects of buoyancy $\sigma_{\lambda}'' = 422.8909 \text{ psi}$
 add effects of eccentricity $\sigma_{\lambda}''' = \frac{14}{\pi} \frac{F_t}{\dots} = 306.956 \text{ psi}$

$$\sigma_{\lambda} = 107948.11 \text{ psi}$$

$$\sigma_p = -136 \text{ psi}$$

$$\sigma_{\lambda} - \sigma_p = 107741.79 \text{ psi}$$

FOR PRELIMINARY DESIGN

II Tubesheet 1
de-pressurized
submerged

shear force = $F_t = 541733.21 \text{ lb}$

$$\sigma_p \text{ max} = 3257.594 \text{ psi}$$

$$\sigma_z = 0$$

$$\sigma_{\lambda} = 0$$

$$\therefore \sigma_p - \sigma_{\lambda} = 3257.594 \text{ psi}$$

V Tubesheet 2

$$F_t = 563316.59 \text{ lb}$$

de-pressurized
 submerged

$$\sigma_p \text{ max} = 3257.580 \text{ psi}$$

$$\sigma_z = -12.88 \text{ psi}$$

$$\sigma_{\lambda} = -12.88 \text{ psi}$$

$$\therefore \sigma_p - \sigma_{\lambda} = 3270.46 \text{ psi}$$

VI Shell
 de-pressurized
 submerged


$$\sigma_z = -1370.5154 \text{ psi}$$

$$\sigma_{\lambda}' = -11991.008 \text{ psi}$$

(due to buoyancy) $\sigma_{\lambda}'' = -422.8909 \text{ psi}$

(due to eccentricity) $\sigma_{\lambda}''' = \pm 64.162024 \text{ psi}$

$$\sigma_{\lambda} = 12378.060 \text{ psi}$$



Customer	Pages	Page 31
Subject		
Project		


$$\sigma_a - \sigma_g = 13748.5$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

	TS1	TS2	Shell
Stress Differences {	11069.219	6012.98	107998.11
	3257.594	3270.46	12378.06
Range	7811.625	2742.52	95570.65
Alt. Stress Intensity	3905.8 < 10,000psi	1371.26 < 10,000psi	47785.03

Note: Alt. Stress intensity only exceeds 10000psi in the shell at the tubesheets.

$$N = 10,600 \text{ cycles}$$



Customer	Pages	Page 32
Subject	By	
Project	Date	

Investigate ^{axial} shell stress attributed
 tube bundle weight
EVAPORATOR

- | | | |
|--|--|-------------|
| 1. Submerged in Sea Water (v-6) | stress | -11 891.009 |
| 2. Sea Water | | |
| | $\frac{58.614}{88.100} \times 11891.008 =$ | - 7911.2315 |
| 1. Total axial shell stress
due to tube bundle weight | | - 19802.239 |
| 4. Stress Range ($\pm .05g$) | | 1980.224 |

$S < 10,000 \text{ psi}$
 $N \rightarrow \infty$

\therefore Alternating stress intensity due to
 sea state 6 ^{vertical} water surface acceleration
 is trivial.

Customer	Pages	Page 33
Subject	By	
Project	Date	

PRELIMINARY
FOR DESIGN

Item 102 Condenser

Shell side (subscript "s")

$\theta_{s, in} = 50^{\circ}F$

$\theta_{s, out} = 50^{\circ}F$

$P_{sat @ 50^{\circ}F} = 89.19 \text{ psia} = 74.5 \text{ psig}$

$P_{design} = 101 \text{ psia} = 86.3 \text{ psig}$


$P_s = .0001603739 \text{ lb/in}^2 \text{ in}$

$d_s = 325^{\circ}OD$

$D_s = 328^{\circ}OD$

Tube sheet

actual TS 278.25" OD w/43883 tubes @ 1" hole



Equivalent TS 278.25 avg; 244.25 min; 312.25 max
Tubeside

$\theta_{p, in} = 40^{\circ}F$

$\theta_{p, out} = 46.2^{\circ}F$

(45° avg metal temp)

(48.1° avg metal temp)

46.55 avg tube temp


$P_{p, in} = (8'-4" \text{ head}) = 37.037036 \text{ psig}$

$P_{p, out} = 12.8888 \text{ psig}$

$\Delta P = -9.185185$

Customer	Pages	Page 34															
Subject	By																
Project	Date																
<div style="border: 2px solid black; transform: rotate(-15deg); padding: 10px; display: inline-block;"> PRELIMINARY FOR DESIGN </div>																	
$A_p = 3491.2261 \text{ in}^2$ $A_f = 26087.03 \text{ in}^2$ $A_t = \frac{31229.671}{60807.927} \text{ in}^2$																	
$l_p = \text{tube length} = 348''$ Tube bundle volume = 12 082 961 in ³ wt of sea water displaced = 447 517.06 lb $P_{t1} = 8.333 \times 64 / 144 = 3.7037036 \text{ psig}$ $P_{t2} = 348 \times 64 / 1728 = 12.888 \text{ psig}$																	
<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">wt tubes</td> <td style="text-align: right;">196 936.65</td> <td style="text-align: right;">lb</td> </tr> <tr> <td>tubesheets</td> <td style="text-align: right;">78 910.04</td> <td></td> </tr> <tr> <td>baffles</td> <td style="text-align: right;"><u>51 175.22</u></td> <td></td> </tr> <tr> <td>tube bundle</td> <td style="text-align: right;">327 021.91</td> <td style="text-align: right;">lb</td> </tr> <tr> <td>ΔP</td> <td style="text-align: right;"><u>225 214.53</u></td> <td></td> </tr> </table>	wt tubes	196 936.65	lb	tubesheets	78 910.04		baffles	<u>51 175.22</u>		tube bundle	327 021.91	lb	ΔP	<u>225 214.53</u>			
wt tubes	196 936.65	lb															
tubesheets	78 910.04																
baffles	<u>51 175.22</u>																
tube bundle	327 021.91	lb															
ΔP	<u>225 214.53</u>																
total downward force 552 236.44 lb less displacement <u>447 517.06</u> apparent wt, gm 104 719.38																	

Customer	Pages	Page 35
Subject	By	
Project	Date	



In the computer run, tube bundle is assumed to shell stress for eccentricity.

In the horizontal run, neglecting gravity forces on the steel

$$\text{effective } \Delta P = (12.8888 - 3.7037) \left(\frac{278.25^2}{276.25} \right) = -11.727398 \text{ psi}$$

In the vertical run, including gravity forces on the steel

$$\text{effective wt} = 104719.38 \text{ lb}$$

PROJECT 5304-100
 PROBLEM NO 23

FIXED TUBESHEET EXCHANGERS
 ENGLISH UNITS

9-19-78

**PRELIMINARY
 FOR DESIGN**

INPUT

CONDENSER ITEM 102 325 IN ID 348 IN LG 278-1/4 IN TH
 HORIZONTAL W/SMALL TUBE BUNDLE & THIN WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	HORIZONTAL
TENA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	PRESSURE DROP

PROJECT S304-100
PROBLEM NO. 23FIXED TUBESHEET EXCHANGER
ENGLISH UNITS

9-19-78

PRELIMINARY
FOR DESIGN

TUBE DATA

OD	0.98165
THICKNESS	0.02652
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	43883
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	-11.75000

PROJECT 5304-100
PROBLEM NO 23

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-19-78

**PRELIMINARY
FOR DESIGN**

SHELL DATA

ID	325.00000
THICKNESS	1.50000
OPERATING PRESSURE	86.30000
HYDROSTATIC TEST PRESSURE	129.50000
AVERAGE METAL TEMPERATURE	65.00000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00030
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.31250	4.31250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.02600	0.02600
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	244.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	40.00000	40.00000
SHELLSIDE	50.00000	50.00000
AVERAGE	45.00000	45.00000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	45.00000	45.00000
TEMPERATURE DROP	10.00000	10.00000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

CH15

PROJECT 5304-100
PROBLEM NO 23FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-19-78

		OUTPUT		
		NORMAL OPERATING	HYDROSTATIC TEST SHELL	HYDROSTATIC TEST TUBES
PRFSSURE	PSI			
TUBESIDE		4,218	0.000	25.880
SHELLSIDE		86,300	129,500	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70,900	70,000	70,000
SHELL		65,000	70,000	70,000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		15.455	15.410	6.890
TUBESHEET 2		15.455	15.410	6.890
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1698.155	1484.822	-704.567
ALLOWABLE		18750.000	28125.000	-4818.175
TUBESHEETS				
1 BENDING CALCULATED		9852.821	14445.168	3849.170
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		1107.062	1051.970	-420.256
ALLOWABLE		16000.000	24000.000	24000.000
2 BENDING CALCULATED		9852.821	14445.168	3849.170
ALLOWABLE		32000.000	48000.000	48000.000
SHEAR CALCULATED		1107.062	1051.970	-420.256
ALLOWABLE		16000.000	24000.000	24000.000
RINGS				
1 BENDING CALCULATED		4590.054	13923.787	554.114
ALLOWABLE		32000.000	48000.000	48000.000
2 BENDING CALCULATED		4590.054	13923.787	554.114
ALLOWABLE		32000.000	48000.000	48000.000
SHELL				
CALCULATED		62426.586*	115262.271*	-4516.135
ALLOWABLE		64000.000	96000.000	96000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2134.208	3367.119	673.138
ALLOWABLE		12500.000	18750.000	18750.000
SHELL				
CALCULATED		14066.900	14029.167	0.000
ALLOWABLE		15000.000	22500.000	22500.000

* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

PROJECT 5304-100
PROBLEM NO 23

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-19-78

PRELIMINARY
FOR DESIGN

		OUTPUT		
		LOSS OF TUBESIDE POWER	LOSS OF SHELLSIDE POWER	TUBE AND SHELL WEIGHT
PRESSURE	PSI			
TUBESIDE		0.000	4.218	0.000
SHELLSIDE		86.300	0.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.900	76.300	70.000
SHELL		70.900	65.000	70.000
INSTAYED THICKNESS	INCH			
TUBESHEET 1		15.455	3.417	0.000
TUBESHEET 2		15.455	3.417	0.000
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1722.529	-82.378	0.000
ALLOWABLE		18750.000	-3192.064	18750.000
TUBESHEETS				
1 BENDING				
CALCULATED		12259.500	2377.864	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR				
CALCULATED		1142.973	-43.851	0.000
ALLOWABLE		16000.000	16000.000	11250.000
2 BENDING				
CALCULATED		12259.500	2377.864	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR				
CALCULATED		1142.973	-43.851	0.000
ALLOWABLE		16000.000	16000.000	11250.000
RINGS				
1 BENDING				
CALCULATED		4486.235	254.216	0.000
ALLOWABLE		32000.000	32000.000	22500.000
2 BENDING				
CALCULATED		4486.235	254.216	0.000
ALLOWABLE		32000.000	32000.000	22500.000
SHELL				
CALCULATED		80308.960*	-2817.892	0.000
ALLOWABLE		64000.000	64000.000	64000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2243.879	73.808	0.000
ALLOWABLE		12500.000	12500.000	12500.000
SHELL				
CALCULATED		14066.900	0.000	0.000
ALLOWABLE		15000.000	15000.000	15000.000

* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

CH15

41

PROJECT 5304-100
PROBLEM NO 24

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

**PRELIMINARY
FOR DESIGN**

INPUT

CONDENSER ITEM 102 325 IN ID 348 IN LG 278-1/4 IN TH
VERTICALAL W/SMALL TUBE BUNDLE & THIN WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

CH15

42

PROJECT 5304-100
PROBLEM NO 20FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

TUBE DATA

OD	0.98165
THICKNESS	0.02652
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	43883
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63962E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	104719.00000

PRELIMINARY
FOR DESIGN

CH15

PROJECT 5304-100
PROBLEM NO 24

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78

PRELIMINARY
FOR DESIGN

SHELL DATA

ID	325.00000
THICKNESS	1.50000
OPERATING PRESSURE	86.30000
HYDROSTATIC TEST PRESSURE	129.50000
AVERAGE METAL TEMPERATURE	65.00000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00030
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.31250	4.31250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.02600	0.02600
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	244.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	40.00000	40.00000
SHELLSIDE	50.00000	50.00000
AVERAGE	45.00000	45.00000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	45.00000	45.00000
TEMPERATURE DROP	10.00000	10.00000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

CH15

44

PROJECT 5304-100 FIXED TUBESHEET EXCHANGERS 9-16-78
 PROBLEM NO 24 ENGLISH UNITS

		OUTPUT		
		NORMAL OPERATING	HYDROSTATIC TEST SHELL	HYDROSTATIC TEST TUBES
PRESSURE	PSI			
TUBESIDE		4,218	0,000	25,889
SHELLSIDE		86,300	129,500	0,000
METAL TEMPERATURE	DEGREE F			
TUBE		70,900	70,000	70,000
SHELL		65,000	70,000	70,000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		15,455	15,410	6,890
TUBESHEET 2		15,455	15,410	6,890
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1692,765	1453,060	-732,324
ALLOWABLE		18750,000	28125,000	-4818,175
TUBESHEETS				
1 BENDING				
CALCULATED		11507,925	28960,960	17698,533
ALLOWABLE		32000,000	48000,000	48000,000
SHEAR				
CALCULATED		1174,531	1499,362	386,323
ALLOWABLE		16000,000	24000,000	24000,000
2 BENDING				
CALCULATED		8227,209	18195,381	18269,274
ALLOWABLE		32000,000	48000,000	48000,000
SHEAR				
CALCULATED		1037,056	584,935	-887,291
ALLOWABLE		16000,000	24000,000	24000,000
RINGS				
1 BENDING				
CALCULATED		3631,995	7342,895	7135,006
ALLOWABLE		32000,000	48000,000	48000,000
2 BENDING				
CALCULATED		5368,043	20688,291	6320,450
ALLOWABLE		32000,000	48000,000	48000,000
SHELL				
CALCULATED		96842,695*	170941,580*	-59144,872
ALLOWABLE		64000,000	96000,000	96000,000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2134,208	3367,119	673,138
ALLOWABLE		12500,000	18750,000	18750,000
SHELL				
CALCULATED		14066,900	14029,167	0,000
ALLOWABLE		15000,000	22500,000	22500,000


* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.

CH15

PROJECT 5304-100
PROBLEM NO. 24

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-16-78



		OUTPUT LOSS OF TUBESIDE POWER	LOSS OF SHELLSIDE POWER	LOSS OF TUBESHEET WEIGHT
PRESSURE	PSI			
TUBESIDE		0.000	4.218	0.000
SHELLSIDE		86.300	0.000	0.000
METAL TEMPERATURE	DEGREE F			
TUBE		70.900	76.300	70.000
SHELL		70.900	65.000	70.000
UNSTAYED THICKNESS	INCH			
TUBESHEET 1		15.455	3.417	0.000
TUBESHEET 2		15.455	3.417	0.000
SECONDARY STRESSES	PSI			
TUBES				
CALCULATED		1717.139	-86.487	-5.393
ALLOWABLE		18750.000	-3192.064	-3212.116
TUBESHEETS				
1 BENDING				
CALCULATED		13914.604	5128.956	3177.412
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR				
CALCULATED		1210.443	57.592	67.469
ALLOWABLE		16000.000	16000.000	11250.000
2 BENDING				
CALCULATED		10633.889	4003.524	-3177.000
ALLOWABLE		32000.000	32000.000	22500.000
SHEAR				
CALCULATED		1072.967	-113.856	-70.006
ALLOWABLE		16000.000	16000.000	11250.000
RINGS				
1 BENDING				
CALCULATED		3728.176	721.774	758.059
ALLOWABLE		32000.000	32000.000	22500.000
2 BENDING				
CALCULATED		5264.224	1032.204	-777.989
ALLOWABLE		32000.000	32000.000	22500.000
SHELL				
CALCULATED		94785.069*	-17339.316	-14521.449
ALLOWABLE		64000.000	64000.000	64000.000
PRIMARY STRESSES	PSI			
TUBES				
CALCULATED		2243.079	73.848	0.000
ALLOWABLE		12500.000	12500.000	12500.000
SHELL				
CALCULATED		14066.900	0.000	0.000
ALLOWABLE		15000.000	15000.000	15000.000

* REQUIRES LOCAL REINFORCEMENT. LOCAL REINFORCEMENT WILL BE PROVIDED IN THE DETAILED DESIGN.


Customer	Pages	Page 46
Subject	By	VRM
Project	Date	9/18/8

**PRELIMINARY
FOR DESIGN**

Condenser
Analysis of FTS Computer run Results
(Resolution into FORCES)

TUBESHEETS
 TS dia = 244.25"
 TS thk = 4.3125"
 TS shear area = 3309.1273 in²

		[TS 1]	[TS 2]
1. Consider bundle & shell fluid submerged in sea water (column V6)	stress	+67.469	-70.006
	load	<u>223 263.54 ↓</u>	<u>231 658.84</u>
2. Consider wt of seawater displaced (wt on computer run)	stress	(+67.618592)	(-67.618582)
	load	<u>223 758.53 ↓</u>	<u>223 758.53 ↓</u>
3. Consider shellside pressure @ 86.3 psi (column H4)	stress	+1142.973	+1142.973
	load	<u>3 782 243.74</u>	<u>3 782 243.74 ↑</u>
4. Consider tubeside pr. @ 4.218 psi (column H5)	stress	-43.851	-43.851
	load	<u>145 108.56 ↑</u>	<u>145 108.56 ↓</u>
5. Consider wt of shellside fluid columns (V4-V6-H4)	stress	+ .001	0
	load	<u>3.309 ↓</u>	<u>0</u>
6. Consider wt & ΔP of tubeside fluid columns (V5-V6+H5)	stress	+33.974	+ .001
	load	<u>112 424.3 ↓</u>	<u>3.309 ↓</u>
7. Consider thermal effects columns (V1+V6-V4-V5)	stress	-26.035	+7.000
	load	<u>86 153.142 ↑</u>	<u>26 371.165 ↓</u>



Customer _____ Pages _____
 Subject _____ Page 47
 Project _____ Date _____

Condenser

I Tubesheet 1
operating
submerged

Shear Force $F_t = 3,885,973.1 \text{ lbf}$

$\sigma_p \text{ max} = 11507.925 \text{ psi}$

$\sigma_t = 86.3 \text{ psi}$

$\sigma_\lambda \text{ max} = -86.3 \text{ psi}$

$\therefore \sigma_p - \sigma_\lambda = 11594.225 \text{ psi}$

II Tubesheet 2
open
submerged

$F_t = 3,431,750.8$

$\sigma_p \text{ max} = 8227.209 \text{ psi}$

$\sigma_t = 86.3$

$\sigma_\lambda \text{ max} = -86.3$

$\sigma_p - \sigma_\lambda = 8313.509$

III Shell

$\sigma_s = +14000.9 \text{ psi}$

$A_s = 1027.3007 \text{ in}^2$

$Z_s = 83726.575 \text{ in}^3$

- (from computer approx) $\sigma_\lambda' = \pm 96,842.695$
- (add effects of buoyancy) $\sigma_\lambda'' = -214.22817$
- (add effects of eccentricity) $\sigma_\lambda''' = \pm 696.79907$

$\sigma_\lambda = \pm 97325.256$

$\sigma_\lambda - \sigma_t = 111392.15 \text{ psi}$

IV Tubesheet 1
depressurized
submerged

$F_t = 447,022.07 \text{ lbf}$


$\sigma_p \text{ max} = 3177.412 \text{ psi}$

$\sigma_t = 0$

$\sigma_\lambda = 0$

$\therefore \sigma_p - \sigma_\lambda = 3177.412 \text{ psi}$

Customer	Pages	Page. 48
Subject	By	
Project	Date	



V Tubesheet 2

$$F_c = 455.407 \text{ lb}_t$$

$$\sigma_p \text{ max} = -3190.1 \text{ psi}$$

$$\sigma_B \approx 0$$

$$\sigma_{\lambda \text{ max}} = -12.553 \text{ psi}$$

$$\sigma_p - \sigma_{\lambda} = 3177.4 \text{ psi}$$

VI Shell

$$\sigma_B = -2113.7776 \text{ psi}$$

$$\sigma_{\lambda}^I = -14521.449$$

(due to buoyancy)

$$\sigma_{\lambda}^{II} = -214.22817$$

(due to eccentric.)

$$\sigma_{\lambda}^{III} = \pm 92.468781$$

$$\sigma_{\lambda} = -14643.208 \text{ psi}$$

$$\sigma_B - \sigma_{\lambda} = 12529.431 \text{ psi}$$

	TS 1	TS 2	Shell
Stress Differences	11594.225	8313.589	111392.15
	3177.412	3177.412	12529.4


Range 8416.813 5136.097 98862.75

Alt. Stress Intensity 4208.4 2568.5 49431.4

Note: only shell is significant

N = 3000 cycles

Customer	Page 43
Subject	By
Project	Date



investigate axial shell stress
tube bundle weight

CONDENSER

1. Submerged in sea water (v-6) stress - 14521.449
2. Sea Water


$$\frac{67.6185}{67.469} \times -14521.449 = -14553.625$$
3. Total axial shell stress due to tube bundle wt - 29075.074
4. Stress Range ($\pm .05g$) 2907.507

$$S < 10,000 \text{ psi}$$

$$N \rightarrow \infty$$

\therefore Alternating stress intensity due to sea state 6 vertical water surface acceleration is trivial.

Customer	Pages	Page 50
Subject		
Project		



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

Tubesheet thickness

Bending (TEMA R-7.122)

where $G = 316 \text{ mhd}$

$$\frac{t_c}{ID_s} = \frac{4.8125}{316.000} = .0152$$

$$F = 1.00$$

$$T = \frac{FG}{2} \sqrt{\frac{P}{S}}$$

where P is the effective shellside, tube side or differential design pressure

In order to establish tubesheet thickness requirements, actual tube bundle dimensions should be used with varying shell diameter accounting for tubesheet eccentricity

orig prob	problem	AR width	shell dia
22	31	6.375	287
22	32	34.375	343.00
24	41	6.375	291
24	42	40.375	359

CH15

PROJECT 5304-100
PROBLEM NO 31

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

INPUT

EVAPORATOR ITEM 101 315 IN ID 348 IN LG 274-1/4 IN TB
VERTICAL W/ACT TUBE BUNDLE 8 THIN SM DIA WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

PROJECT 5304-100
 PROBLEM NO 31

FIXED TUBESHEET EXCHANGERS
 ENGLISH UNITS

9-22-78

TUBE DATA

OD	0.98597
THICKNESS	0.03147
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	42667
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	165872.00000

PRELIMINARY
 FOR DESIGN

PROJECT 5304-100
PROBLEM NO 31

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

SHELL DATA

ID	287.00000
THICKNESS	2.00000
OPERATING PRESSURE	136.00000
HYDROSTATIC TEST PRESSURE	204.00000
AVERAGE METAL TEMPERATURE	71.95000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00025
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.81250	4.81250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.03100	0.03100
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	246.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	80.00000	80.00000
SHELLSIDE	57.80000	57.80000
AVERAGE	68.90000	68.90000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	79.60000	79.60000
TEMPERATURE DROP	22.20000	22.20000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

PROJECT 5304-100
PROBLEM NO - 31

FIXED TUBESHEET EXCHANGERS
- ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

THICKNESSES OF TUBESHEETS REQUIRED BY TEMA (CORROSION)

	FROM BENDING	FROM SHEAR
RESULT 1	4.9715	0.9860 **
RESULT 2	4.9715	0.9860 **

RESULT 1 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 1

RESULT 2 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 2

** THICKNESS REQUIRED BY TEMA K-7.121

NOTE: NOT CONTROLLING SEE PROB 32.

CH15

PROJECT 5304-100
PROBLEM NO 32

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

INPUT

EVAPORATOR ITEM 101 315 IN ID 348 IN LG 274-1/4 IN TO
VERTICAL W/ACT TUBE BUNDLE & THIN LG DIA WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

CH15

56

PROJECT 5304-100 FIXED TUBESHEET EXCHANGERS
 PROBLEM NO 32 ENGLISH UNITS

9-22-78

TUBE DATA

OD	0.98597
THICKNESS	0.03147
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	42667
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSON'S RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62857E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	165872.00000

PRELIMINARY
 FOR DESIGN

PROJECT 5304-100
PROBLEM NO 32

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

SHELL DATA

ID	343.00000
THICKNESS	2.00000
OPERATING PRESSURE	136.00000
HYDROSTATIC TEST PRESSURE	204.00000
AVERAGE METAL TEMPERATURE	71.95000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00025
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.81250	4.81250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.03100	0.03100
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	246.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	80.00000	80.00000
SHELLSIDE	57.80000	57.80000
AVERAGE	68.90000	68.90000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	79.60000	79.60000
TEMPERATURE DROP	22.20000	22.20000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

PROJECT 5304-100
 PROBLEM NO 32

FIXED TUBESHEET EXCHANGERS
 ENGLISH UNITS.

9-22-78

THICKNESSES OF TUBESHEETS REQUIRED BY TEMA (CORROSION) INC

FROM BENDING FROM SHEAR

RESULT 1	6.0084	0.9860 **
RESULT 2	6.0084	0.9860 **

RESULT 1 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 1.

RESULT 2 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 2.

*THICKNESS REQUIRED BY TEMA R-7.121

*NOTE: CONTROLLING FOR THE EVAPORATOR.
 ANTICIPATED TUBESHEET THICKNESS REQUIRE-
 MENT FOR FINAL DESIGN IS LESS THAN
 4.8125 IN. A VENDORS QUOTATION BASED
 ON TEMA R TUBESHEET THICKNESS IS
 THEREFORE CONSERVATIVE.*

PRELIMINARY
 FOR DESIGN

PROJECT 5304-100
PROBLEM NO 41

FIXED-TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

INPUT

CONDENSER ITEM 102 325 IN ID 348 IN LG 278-1/4 IN TH
VERTICAL W ACT TUBE BUNDLE & THIN SM DIA WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CCIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TEMA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

PROJECT 5304-100
PROBLEM NO 41

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

TUBE DATA

OD	0.98165
THICKNESS	0.02652
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	43883
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63962E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	104719.00000

PROJECT 5304-100
PROBLEM NO 41

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

SHELL DATA

TD	291.00000
THICKNESS	1.50000
OPERATING PRESSURE	86.30000
HYDROSTATIC TEST PRESSURE	129.50000
AVERAGE METAL TEMPERATURE	65.00000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00030
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.31250	4.31250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE IN TUBESHEET OD	1.00000	1.00000
TUBE IN TUBESHEET THICKNESS	0.02600	0.02600
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE HUNDLE OD	244.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	40.00000	40.00000
SHELLSIDE	50.00000	50.00000
AVERAGE	45.00000	45.00000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	45.00000	45.00000
TEMPERATURE DROP	10.00000	10.00000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

CH15

62.7

PROJECT 5300-100
PROBLEM NO. 41FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

**PRELIMINARY
FOR DESIGN**

THICKNESSES OF TUBESHEETS REQUIRED BY TEMA (CORRODED) IN

FROM BENDING

FROM SHEAR

RESULT 1 3.8347 0.9817 **

RESULT 2 3.8347 0.9817 **

RESULT 1 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 1

RESULT 2 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED ON INPUT FOR TUBESHEET 2

**THICKNESS REQUIRED BY TEMA R-7.121

NOTE: NOT CONTROLLING. SEE PROB. 42.

PROJECT 5304-100
PROBLEM NO 42

FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

INPUT

CONDENSER ITEM 102 325 IN ID 348 IN LG 278-1/4 IN TB
VERTICAL W ACT TUBE BUNDLE & THIN LG DIA WALLS

UNITS

LENGTH	INCH
TEMPERATURE	DEGREE F
PRESSURE	PSI
STRESS	PSI
MASS	LB
DENSITY	LB/CUIN

OPTIONS

TUBESHEETS	SYMMETRIC
EXCHANGER	VERTICAL
TE IA	REQUESTED
TUBES	ROLLED
EXPANSION JOINT	NO
WT OR PRES	BUNDLE WEIGHT

PROJECT 5304-100
PROBLEM NO 42FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

TUBE DATA

OD	0.98165
THICKNESS	0.02652
LENGTH	348.00000
UNSUPPORTED LENGTH	
BAFFLE TO BAFFLE	58.00000
TUBESHEET TO BAFFLE	58.00000
LAYOUT ANGLE	60.00000
PITCH	1.25000
NUMBER OF TUBES	43883
OPERATING PRESSURE	4.21800
HYDROSTATIC TEST PRESSURE	25.88900
MAXIMUM TEMPERATURE	76.30000
AVERAGE TEMPERATURE	70.90000
YIELD STRENGTH AT	
MAX TUBE TEMPERATURE	40000.00000
SHELL TEMPERATURE	40000.00000
ATMOSPHERIC	40000.00000
INSIDE CORROSION ALLOWANCE	0.00000
OUTSIDE CORROSION ALLOWANCE	0.00000
POISSONS RATIO	0.34000
ELASTIC MODULUS AT	
MAX TUBE TEMPERATURE	1.62837E+07
AVERAGE TEMPERATURE	1.63834E+07
SHELL TEMPERATURE	1.63982E+07
ATMOSPHERIC	1.64000E+07
ALLOWABLE STRESS AT	
MAX TUBE TEMPERATURE	12500.00000
SHELL TEMPERATURE	12500.00000
ATMOSPHERIC	12500.00000
EXPANSION COEFFICIENT	4.80000E-06
BUNDLE WEIGHT OR PRESSURE DROP	104719.00000

PROJECT 5304-100 FIXED TUBESHEET EXCHANGERS
 PROBLEM NO 42 ENGLISH UNITS

9-22-78

PRELIMINARY
FOR DESIGN

SHELL DATA

ID	359.00000
THICKNESS	1.50000
OPERATING PRESSURE	86.30000
HYDROSTATIC TEST PRESSURE	129.50000
AVERAGE METAL TEMPERATURE	65.00000
YIELD STRENGTH AT OPERATING	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000
ALLOWABLE STRESS AT OPERATING	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000
ELASTIC MODULUS AT OPERATING	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07
CORROSION ALLOWANCE	0.50000
EXPANSION COEFFICIENT	6.13000E-06
DENSITY OF FLUID	0.00030
POISSONS RATIO	0.30000
AMBIENT TEMPERATURE	70.00000

TUBESHEETS

	1	2
THICKNESS	4.31250	4.31250
FLEXURAL EFFICIENCY	0.00000	0.00000
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
TEMPERATURE DROP	22.20000	22.20000
TUBE ID TUBESHEET OD	1.00000	1.00000
TUBE ID TUBESHEET THICKNESS	0.02600	0.02600
CORROSION ALLOWANCE TUBESIDE	0.00000	0.00000
CORROSION ALLOWANCE SHELLSIDE	0.00000	0.00000
TUBE BUNDLE OD	244.25000	
ELASTIC MODULUS AT OPERATING	2.90000E+07	2.90000E+07
ELASTIC MODULUS AT ATMOSPHERIC	2.90000E+07	2.90000E+07
TEMPERATURE		
TUBESIDE	40.00000	40.00000
SHELLSIDE	50.00000	50.00000
AVERAGE	45.00000	45.00000
YIELD STRENGTH AT MAX TEMP	32000.00000	32000.00000
YIELD STRENGTH AT ATMOSPHERIC	32000.00000	32000.00000
ALLOWABLE STRESS AT MAX TEMP	15000.00000	15000.00000
ALLOWABLE STRESS AT ATMOSPHERIC	15000.00000	15000.00000
POISSONS RATIO	0.30000	0.30000
ANNULUS RING		
EXPANSION COEFFICIENT	6.13000E-06	6.13000E-06
AVERAGE TEMPERATURE	45.00000	45.00000
TEMPERATURE DROP	10.00000	10.00000
ELASTIC MODULUS	2.90000E+07	2.90000E+07

CH15

66

PROJECT 5304-100
PROBLEM NO 42FIXED TUBESHEET EXCHANGERS
ENGLISH UNITS

9-22-70

PRELIMINARY
FOR DESIGN

THICKNESSES OF TUBESHEETS REQUIRED BY TEMA (CORRODED) IN

	FROM BENDING	FROM SHEAR
RESULT 1	4.7576	0.9817 **
RESULT 2	4.7576	0.9817 **

RESULT 1 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED IN INPUT FOR TUBESHEET 1

RESULT 2 THICKNESSES ARE REQUIRED FOR BOTH TUBESHEETS OF THE EXCHANGER CONSIDERING THAT THEY BOTH HAVE THE SAME MATERIAL PROPERTIES AND TEMPERATURES AS THOSE SPECIFIED IN INPUT FOR TUBESHEET 2

** THICKNESS REQUIRED BY TEMA R-7.121

*NOTE : CONTROLLING FOR THE CONDENSER,
ANTICIPATED TUBESHEET THICKNESS FOR
FINAL DESIGN IS LESS THAN 4.3125 INCH.
A VENDOR'S QUOTATION BASED ON
TEMA-R TUBESHEET THICKNESS IS
THEREFORE CONSERVATIVE.*

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX I.2.2
0.2 MWe TEST ARTICLES

Customer	TREW	Pages	Page 67
Subject	- 2 MW TBM PARTIAL	By	7262
Project	5304-100	Date	8-12-75

PRELIMINARY
FOR DESIGN

CODE - U9-27

CIRCUMFERENTIAL STRESS -

$$t = \frac{PR}{SE - 6P} \quad \text{WHERE } E = .85 \quad S = 15,000 \quad R = 49\frac{1}{8} \text{ IN.} \quad P = 136 \text{ PSI}$$

CH. 1/8"

$$t = \frac{136(49.125)}{15000(.85) - 6(136)} + .125 = .577 + .125 = .652 \text{ IN.}$$

$$S_{CIRC} = \frac{136(49.125)}{t_{REQUIRED}} + 6(136) = 12536 \text{ PSI}$$

LONGITUDINAL STRESS -

$$t = \frac{136(49.125)}{2(15000)(.85) + 4(136)} + .125 = .2614 + .125 = .386 \text{ IN.}$$

$$S_{LONG} = \frac{136(49.125)}{2(.527)} - 4(136) = 6284 \text{ PSI}$$

USING F_{516-60} @ 28×10^6

UNIT - STRAIN -

TOTAL STRAIN -

$$\frac{6284}{28 \times 10^6} = .00022 \quad .00022 \times 352 = 0.077 \text{ IN. (EXTENSION)}$$

TUBE LENGTH 30'-0" END TO END -

SPRUE - 39'-4" BACK TO BACK OF TUBESHEETS - (352")

LONGITUDINAL STRAIN ABOVE ASSUMES ALL END LOADING ON THE SHEET.

IN ACTUAL PRACTICE THE LOAD COULD ALSO BE DISTRIBUTED TO THE VAPOR BARRIERS AND SOME TO THE TUBESHEET.

TUBESHEET CONSTRAINT IS PRIMARILY ACCOMPLISHED WITH THE VAPOR BARRIERS AND THE SPRUERS, AS SHOWN, PINE UNDER LOW STRESS.

SINCE THE TUBESHEET IS STRESSED AS A SEMICIRCULAR FLAT PLATE WITH HOLES

PRELIMINARY
FOR DESIGN

Customer	T.V.U.	Pages	Page 68
Subject	2 MW TEST ARTICLE	By	ZGC
Project	5304-100	Date	8-12-71

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21

FIXED, AND SINCE THE VAPOR BARRIERS ACT AS TUBESHEET STAYS AND FIX EACH SEMICIRCULAR TUBESHEET SECTION, ANY LOADING OF THE TUBES IS INCONSEQUENTIAL WITH ONLY A ΔT_{EMP} OF $2^{\circ}F$ BETWEEN THE TUBES AND THE STEEL SHELL (OR BARRIERS) THERE IS NO TEMPERATURE EXPANSION STRESS ON THE TUBES.

22
23
24
25
26
27
28

ACCOMPANYING CALCULATIONS SHOW THAT THE VAPOR BARRIERS ALONE ARE CAPABLE OF CARRYING 1,091,000 # OF END FORCE.

29
30

TOTAL END FORCE = 920,000 POUNDS.

31
32
33
34
35
36
37

THEREFORE, THE TUBES ARE NOT REQUIRED TO SUSTAIN ANY END FORCES.

38
39
40
41
42
43
44
45
46
47

ASSUMING THE TUBES ARE BEING PULLED BY THE ELONGATION OF THE SHELL AND VAPOR BARRIERS - THE MAXIMUM STRESS IN THE TUBES IS 3,924 PSL

48
49
50
51
52
53
54
55
56
57
58
59
60

THE TUBES HAVE AN ALLOWABLE STRESS OF AT LEAST 10,600 PSL PER GRADE II MATERIAL SPECIFICATION. THEREFORE, THE TUBES ARE ONLY STRESSED TO 37% OF THEIR ALLOWABLE.

Customer	TRW	Pages	Page 69
Subject	.2 MWE TEST ARTICLE EVAPORATOR	By	Iwc
Project	5304-100-117-2	Date	8-2-78

INTERNAL PRESSURE PER UG 27

$$P = 136 \text{ PSIG}, \quad CA \quad \frac{1}{8}$$

T - UNDER 650 F

MTL SA 516-60

$$t = \frac{PR}{SE - .6P} + C = \frac{136 \times 49.125}{15000 \times .85 - .6 \times 136} + \frac{1}{8} = .527 + \frac{1}{8} = .652$$

SHELL USE $\frac{11}{16}$ " TE.

WATER BOX - USE $\frac{3}{8}$ " TE.

BOTTOM CONE PER UG 32 (g)

PRESSURE 18.6 PSI.

$$t = \frac{PD}{2 \cos \alpha (SE - .6P)} + C$$

$$= \frac{18.6 \times 90.25}{2 \cos 30^\circ (15000 \times .85 - .6 \times 18.6)} + \frac{1}{8}$$

$$t = .076 + \frac{1}{8} = .201 \text{ USE } \frac{1}{4} \text{ TE MIN}$$

NOZZLE REINFORCEMENT (PER UG 37)

MANWAY 20" WITH 20" SCHD 80 PIPE NECK.

AREA REQ'D

$$A = d \times t_r \times F \quad \text{WHERE } F = 1$$


$$A = (17.938 + .25)(.448)$$

$$A = 8.145 \text{ in}^2$$

$$A_1 = (E_1 t - F t_r) \times \frac{1}{2} = (.563 - .448) 18.188 = 2.092 \text{ in}^2$$

$$A_2 = (E_2 t - F t_r)(t_n + t)^2 = (.963 - .448)(.906 + .563)^2 = .338 \text{ in}^2$$

Customer	TRW	Pages	Page 70
Subject	.2 MW _e TEST ARTICLE EVAPORATOR	Rev	
Project		Date	



$$A_2 = (t_n - t_{rn}) 5t = (.906 - .083) 5 \times .563 = 2.317 \text{ in}^2$$

OR

$$A_2 = (t_n - t_{rn}) 5t_n = (.906 - .083) 5 \times .906 = 3.728 \text{ in}^2$$

$$A_3 = 0$$

$$A_4 = 2 \times .5 \times .25 = .25$$

TOTAL AVAILABLE 4.659

$$\text{REINF PAD REQ'D} = 8.145 - 4.659 = 3.486 \text{ in}^2$$

USE PAD $\frac{1}{2}$ " X 27" ϕ PAD

NOZZLE NZ 18" SCHD 80 PIPE NECK.

$$\text{AREA REQ'D, } A = d t_r F = 16.376 \times .448 \times 1 = 7.336 \text{ in}^2$$

$$A_1 = (E_t - F t_r) d = (.563 - .448) 16.376 = 1.883$$

OR

$$A_1 = (E_t - F t_r) (t_n + t) 2 = (.563 - .448) (.812 + .563) 2 = .316$$

$$A_2 = (t_n - t_{rn}) 5t = (.812 - .075) 5 \times .563 = 2.070$$

$$A_3 = 0$$

$$A_4 = 2 \times .5 \times .25 = .25$$

AVAILABLE 4.209 in²

$$\text{NET ADD} = 7.336 - 4.209 = 3.127 \text{ in}^2$$

USE $\frac{1}{2}$ " X 25" ϕ PAD

PRELIMINARY
FOR DESIGNARY

Customer	T R W I	Pages	Page 71
Subject	.2 MWe TEST ARTICLE EVAPORATOR	By	FWC
Project	5304-100-117-2	Date	8-3-75

NOZZLE N1 5" X-STR. PIPE. 5.563" OD x .375 wall

AREA REQ'D, $A = d \times t_r + F = 5.063 \times .563 \times 1 = 2.850 \text{ in}^2$

$A_1 = (E_i t - F t_r) d = (.563 - .448) 5.063 = .644$

$A_1 = (E_i t - F t_r) (t_n + t)^2 = (.563 - .448) (.25 + .563)^2 = .187$

$A_2 = (t_n - t_{rn}) 5t = (.25 - .0023) 5 \times .563 = .639$

$A_3 = 0$

$A_4 = 2 \times .5 \times .25 = .25$


TOTAL AVAIL 1.533 in²

REQ'D IN PAD = 2.850 - 1.533 = 1.317 in²

USE 1/2" x 9 1/2" φ PAD. 2" WIDE MIN PAD.


Customer	TRW	Pages	Page 72
Subject	.2 MV/e TEST ARTICLE EVAPORATOR	By	W.C.
Project		Date	8-3-78

FIXED TS DESIGN.



PRELIMINARY
FOR DESIGN

LOOK AT UNSTAYED PORTION OF TS. ASSUME FULL SEMICIRCLE.



$$\sigma_A = -0.42 \frac{q a^2}{t^2}$$

$$t^2 = -0.42 \frac{q a^2}{\sigma_A}$$

WHERE $\sigma_A = 15000$ PSI

$$t_A = \sqrt{0.42 \frac{136.5 \times 49^2}{15000}} = 3.029 + \frac{1}{8} = 3.15"$$

$$t_B = \sqrt{0.36 \times \frac{136.5 \times 49^2}{15000}} = 2.805 + \frac{1}{8} = 2.93"$$

$$t_C = \sqrt{0.21 \times \frac{136.5 \times 49^2}{15000}} = 2.14 + \frac{1}{8} = 2.267"$$

3.15" MIN TS THICKNES REQD FOR THE UNSTAYED PORTION.
METHOD FROM ROARK & YOUNG FIFTH EDITION, CASE 30 PP371

3 3/8" \approx (FULL CIRCLE) IS STRESSED TO 14000 PSI

Customer	TRW	Pages	Page 73
Subject	2 MW TEST ARTICLE EVAPORATOR	By	FWC
Project	5304 - 100 - 117 - 2	Date	8-3-78

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

FIXED TS DESIGN. RUFF CALCS.

(TEMPERATURE DIFFERENCES ARE OF LITTLE CONSEQUENCE)

TOTAL TUBE CROSS SECTION

$$A_t = (1 - 0.938^2) \cdot 7854 \times 854 = 102.6 \text{ in}^2$$

$$P_T = SA_t = 12500 \times 102.6 = 1.2825 \times 10^6 \text{ lbs. ALLOWABLE}$$

$$\text{END LOAD ON TS.} \quad 9.38 \times 10^5 \text{ lbs.}$$

$$E_{TS} = 29 \times 10^6$$

$$E_{TUBE} = 16.4 \times 10^6$$

$$9.38 \times 10^5 \times \frac{16.4}{29} = 530,532 \text{ on TS}$$

$$938 \times 10^5 - 530,532 = 407,633 \text{ on TUBES}$$

TS.

$$t^2 = \frac{3W}{8\pi M S} (3m + 1)$$

$$t^2 = \frac{3 \times 530,532}{8\pi \times 3.333 \times 15000} (3 \times 3.333 + 1)$$

$$t^2 = 13.932$$

$$t = 3.733 + \frac{1}{8} = 3.85 \text{ SAY } 4" \text{ THICK.}$$

TUBES

$$S = \frac{D}{A} = \frac{407,633}{102.6} = 3973 \text{ in}^2$$

THIS DOES NOT TAKE INTO ACCOUNT THE VAPOR BARRIERS WELDED TO BOTH TUBESHEETS.

**PRELIMINARY
FOR DESIGN**

Customer	TRW	Pages	Page 74
Subject	2 MW TEST ARTICLE	By	EEC
Project	5304-100	Date	8-10-78

PRELIMINARY
FOR DESIGN

TOTAL END LOADING - EVAPORATOR -

USING 136 PSL DESIGN -

$$ID = 98\frac{1}{4} \text{ " } \phi$$

$$TUBES = 854 \text{ } 1 \text{ " } \phi \quad AREA = 854 \times .7854 \text{ IN}^2 = 670.73 \text{ IN}^2$$

$$TOTAL AREA = \frac{98.25^2 \pi}{4} = 7581.5$$

$$PRESSURE AREA \text{ (NOT SUBTRACTING FOR BUFFLES)} \\ = 6911 \text{ IN}^2$$

$$ASSUME BUFFLES @ \frac{3}{4} \text{ " THICK} \times 96 \text{ " LONG} = 149 \text{ IN}^2$$

$$NET AREA FOR PRESSURE = 6767 \text{ IN}^2$$

$$TOTAL END PRESSURE = 6767 \times 136 = 920,312 \text{ POUNDS}$$

TOTAL PERIMETER TO HOLD END LOAD

$$98.25 \pi + 2(96) = 500.66 \text{ INCHES}$$

$$LOAD REQUIRED / INCH = 1,838 \text{ POUNDS}$$

REVISE FOR $\frac{3}{8}$ " BUFFLE - ADD - 72 IN^2 TO END LOADING

$$\text{OR } 6839 \text{ IN}^2$$

$$TOTAL END PRESSURE 6839 \times 136 = 930,104 \text{ #}$$

$$\text{OR } 1,857 \text{ # PER LIN INCH}$$

$$\text{STRESS ON } \frac{3}{8} \text{ " THK BUFFLE} = 4,954 \text{ PSL } \uparrow 9903 \text{ PSL } \uparrow$$

$$\text{STRESS ON } \frac{9}{16} \text{ (NET) SHELL} = 3,301 \text{ PSL } \uparrow 6602 \text{ PSL } \uparrow$$

Customer	TTEW.	Pages	Page 75
Subject	.2 MW TEST PARTIAL	By	RSC
Project	5304-100	Date	8-19-76

TUBES - 1" OD X .938 ID

L = 352"

$$\Delta L = .077''$$

$$L \epsilon = \Delta L \text{ (INCHES)}$$

$$\epsilon = \frac{\Delta L}{L} = \frac{.077}{352} = .000218$$

$$\epsilon = \frac{S}{E}$$

$$E = 18 \times 10^6 \text{ PSI}$$

$$S = E \epsilon$$

$$S = 18 \times 10^6 \times .000218 = 3,924 \text{ PSI}$$

PRELIMINARY
FOR DESIGN

**PRELIMINARY
FOR DESIGN**

Customer	TRW	Pages	Page 76
Subject	2 MW TEST ARTICLE	By	FWC
Project	5304-100-117-2	Date	8-3-78

VAPOR BARRIER.

$$A = 2 \times \frac{3}{8} \times 97 = 72.75 \text{ in}^2$$

ASSUME WELD SIZED TO CARRY SAME LOAD
WHAT CAN THE BARRIER CARRY?

$$P = SA = 72.75 \times 15000 = \underline{1,091,250} \#$$

THIS IS MORE THAN THE HYDROSTATIC END LOAD.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK


APPENDIX I.2.3
HEAT EXCHANGERS SUPPORT

PREPARED L R MORTALONI 29 AUG 1978 REPORT NO.

CHECKED _____

MODEL PSD-I, 10 MWe, PDR

**HEAT EXCHANGERS SUPPORT
STRESS ANALYSIS**




I-214

1/8" = 1'-0"


CHECKED _____

MODEL _____

TOP SUPPORT SADDLE



HEAT EXCHANGER TOP SUPPORT INTERFACE ATTACHMENT BRACKET



HEAT EXCHANGER TOP SUPPORT SADDLE

I-215



3/16" = 1/40

PREPARED L R MORTALONI 29 Aug 1975 REPORT NO.

CHECKED _____

MODEL _____

CONDENSER SUPPORTS.



HEAT EXCHANGER COFFERDAM SIDE PLATE SUPPORTS


3/16" = 1'-0

I-216


CHECKED _____

MODEL _____

BOTTOM SUPPORT SADDLE



HEAT EXCHANGER BOTTOM SUPPORT INTERFACE ATTACHMENT BRACKET.



HEAT EXCHANGER BOTTOM SUPPORT SADDLE

$$A_{\text{TOTAL LINE A}} = 23.25 \times 12 \times 0.75 + 2 \times 16 \times 1.5 + 6 \times (16 - 0.75) \times 1.5 = 394.5 \text{ D}''$$

PER SUPPORT

$$I = 2.961 \times 10^6 \text{ IN}^4$$


LINE A

$$\frac{3}{16}'' = 1 \text{ D}''$$

PREPARED L R MORTALONI 1 SEPT 1978 REPORT NO.

CHECKED _____

MODEL _____




(A)

REF. SHEET 1

CHECKED _____

MODEL _____



LOWER SHELL (ESTIMATED)

315" ID X 15'-0" X 1" THICK.

WT = 50,671# (DRY)

WT = 44,053# (WET)

6618# DELTA.

DISPLACED WATER

1/16" = 1'-0"

CHECKED _____

MODEL _____

COFFERDAM

PLATE THICKNESS

MAX. PRESSURE = $37.5 \times 64 = 2400 \text{ #/ft}^2 = 16.67 \text{ #/in}^2$

$M_{max} = \frac{WL^2}{8} = \frac{16.67 \times 60^2}{8} = 7500 \text{ in-k/in}$


$t_{min} = \sqrt{\frac{6M}{F_y}} + 0.5 = 1.618 \text{ in} \Rightarrow \text{TRY } 1\frac{5}{8} \text{ PL}$

NOTE:

LET $F_y = 36 \text{ k/in}^2$ SINCE THIS LOADING CONDITION IS ONLY TEMPORARY
 CORROSION ALLOWANCE

STIFFENER BEAMS

SECTION PROPERTIES



FOR COMPOSITE SECTION


$A_f = 107.21 \text{ in}^2$

$I_T = 478.1 \text{ in}^4$

$S_{max} = 360.1 \text{ in}^3$ TENSION SIDE

$S_{min} = 47.6 \text{ in}^3$

CHECK BENDING



$f_b \text{ MAX} = \frac{M}{S_{min}} = 36.1 \text{ k/in}^2$

O.K.
 DUE TO TEMP. LOAD.

CHECKED _____

MODEL _____

COFFERDAM - CONTI

TRY REDUCE BEAM SPACING TO 4'-3" = 51"

$W = 16.67 \# 10''$ $M_{max} = 5418.75 \text{ } ^1\text{-K}/\text{IN}$

$t_{min} = 0.95 + 0.5 = 1.45'' \Rightarrow \text{TRY } 1\frac{1}{2}''$

STIFFENER BEAMS. $W = 33.25 \times 4.25 \times 64 = 9049 \#/\text{FT.}$

$M_{max} = 124.64 \text{ } ^1\text{-K} \Rightarrow S_{min} = \frac{124.64 \times 12}{36} = 41.5 \text{ } \text{IN}^3$
N.T.G.A.S.

TRY VERTICAL STIFFENER BEAMS (WILL PROBABLY BE REQUIRED FOR SHEAR)

PLATE THICKNESS - TWO WAY PLATE BENDING

$W = 16.67 \text{ } \text{IN}^2$

$A = 48''$ $\frac{B}{A} = 1.25$
 $B = 60''$

REF. "THEORY OF PLATES AND SHELLS" BY TIMOSHENKO

$M_{max} \approx 0.0666 W A^2$
 $= 2536.3 \text{ } ^1\text{-K}/\text{IN}$

$t_{min} = \sqrt{\frac{6M}{F_y}} + 0.5 = 1.15 \text{ } \text{IN} \Rightarrow \text{USE PL } 1\frac{1}{4}''$

STIFFENER BEAMS.

SHORT BEAMS.


$M_{max} = \frac{16.67 \times 60^2}{8} \times 48 = 360072 \text{ } ^1\text{-K} = 360.07 \text{ } ^1\text{-K}$

$S_{min} = \frac{360.07}{36} = 10.0 \Rightarrow \text{USE } W6 \times 15.5$

LONG BEAMS.

$M_{max} = 143.33 \text{ } ^1\text{-K} \Rightarrow \text{USE } W10 \times 33$

$A_T = 84.71 \text{ } \text{IN}^2$
 $I_T = 440.82 \text{ } \text{IN}^4$
 $S_{min} = 45.2 \text{ } \text{IN}^3$
 $S_{max} = 351.1 \text{ } \text{IN}^3$



O.K. DUE TO CONSERVATIVE NATURE OF CALCULATIONS

PREPARED: LR MORTALONI 30 Aug 1978

REPORT NO.

CHECKED _____

MODEL _____

COEFFERDAM - CONTI

EST WEIGHT

SIDE PL.

$$2 * ((51'-0) * (11'-0) * \frac{1.25}{12}) * 490 = 57269\#$$

STIFFENERS.

W10X 33.

2- 9 BMS @ 11'-0

$$2 * (9 * 11 * 33) = 6534\#$$

W6 X 15.5.

2- 2 BMS @ 51'

$$2 * (2 * 51 * 15.5) = 3162\#$$

FLANGES (ESTIMATE THICKNESS).

PL 1/4" X 8" X 102'

$$102 * \frac{1.25 * 8}{12} * 490 = 41650\#$$

SUBTOTAL

$$= 108615\#$$

SUPPORT SADDLES

@ 15,000\#

$$= 30,000\#$$

$$\underline{138,615\#}$$

OR

$$VOL = 282.8 \text{ FT}^3 - \text{FOR BOUYANCE CALC.}$$

EQUIVALENT UNIT AREAS.

$$\text{NO. OF BMS.} \rightarrow \bar{A} = \frac{9 * 9.71 + 1.25 * 51 * 12}{51 * 12} = 1.39 \text{ O}''/\text{IN}$$

$$A_{TOTAL} = 852.39 \text{ O}'' \text{ PER SIDE}$$

CHECKED _____

MODEL _____

CONDENSER WEIGHTS - FROM INTEGRAL HULL AND 40MW_e SHIP DATA

TUBES.		
TUBE	241495 #	
WATER		380,163 #
SHELL	247094	
WATERBOX.		
SHELL	59093	
WATER		346360
TUBESHEET	130909	
NH ₃		12503
BAFFLES & TIE RODS	96592	
COEFFER DAM	138615	
LOWER SHELL	50671	

BY MISTAKE I USE EVAPORATOR WEIGHTS. USE THESE VALUES FOR THE SUPPORT DESIGN SINCE THEY ARE GREATER THAN THAT OF THE CONDENSER

964469 # + 739026 # = 1,703,495 # = 852 TONS

↑
DRY WT.
USE 980,000 # (490T)
FOR SUPPORT DESIGN

↑
OPERATING FLUID WT.

↑
TOTAL OPERATING WT.

BOUYANCY WEIGHT
CONDENSER

$O.D. = 32.5 + 2 \times 2 \frac{3}{8} + 2 \times \frac{1}{2} = 330.75'' = 27.5625'$

$V_{cond} = 30' \times \frac{\pi}{4} \times 27.5625^2 + 282.8 = 18,182.6 \text{ FT}^3$

OR

$\Delta = 18182.6 \times 64 + 6618 = 1,170,305 \text{ #} = 1170 \text{ KIPS}$

NET REACTION - $R_{cond} = 1703 - 1170 = 533 \text{ K}$ - USE 600 K FOR DESIGN

NOTE: FROM OTEC-PSD-1, HEAT EXCHANGER DESIGN CRITERIA THE FOLLOWING ACCELERATIONS ARE IMPOSED

SEA STATE	VERTICAL ACCELERATION	HORIZONTAL ACCELERATION
SS 6	0.05g	0.01g
SS 9	0.15g	0.07g


CHECKED _____

MODEL _____

SUPPORT CALCULATIONS


EXCHANGER IN HORIZ POSITION - OCCURS DURING TRANSPORTATION

GRAVITY LOADS



HORIZONTAL LOADS - DUE TO BARGE TRANSPORTATION LOADS

SURGE LOADING:



ASSUMING E70XX ELECTRODES

$\phi_{ALL} = 0.928^k/in / \frac{1}{16}''$ WELD SIZE

∴ WELD STRESSES WOULD NOT BE EXCESSIVE

UNIT SHEAR = $\frac{24.2}{241 * 12} = 0.09^k/in$


CHECKED _____

MODEL _____

SUPPORT CALCULATIONS - CONTI

EXCH. HORIZ^b - LON

HORIZONTAL LOADS - CONTI
SWAY LOADING



VERTICAL LOAD - HEAVE ACCELERATIONS (+ OR -)

SEE GRAVITY LOADS.

$$R_1 = 0.15 * 439 = 65.9^k$$

$$R_2 = 0.15 * 541 = 81.2^k$$

SUMMARY FOR SUPPORT LOADS

MAX. REACTIONS

$$R_1 = 541 + 24.2 + 81.2 = 646.4^k - \text{USE } 700^k \text{ FOR DESIGN}$$

$$R_2 = 439 + 24.2 + 65.2 = 528.4^k - \text{USE } 550^k \text{ FOR DESIGN}$$

MIN. REACTIONS

$$R_2 = 439 - 24.2 - 65.9 = 348.9^k$$

BOTTOM SUPPORT PLATE THICKNESS



$$w = \frac{700}{18 * 282} = 0.138 \text{ k/in} \quad \text{O.K.}$$

ASSUME 18" WIDTH

$$M_{\text{max}} = \frac{15}{142} w L^2 = \frac{15}{142} * 0.138 * 40.286^2 = 23.6 \text{ k-in}$$

$$t_{\text{min}} = \sqrt{\frac{6M}{F_y}} = \sqrt{\frac{6 * 23.6}{27}} = 2.29" \rightarrow \text{SEE TOP SUPPORT FOR THICKNESS REQ'D.}$$


PREPARED L R MORTALONI 31 Aug 1978

REPORT NO.

CHECKED _____

MODEL _____

TOP SUPPORT - ACCESS REQUIRED



CHECK STRESSES IN THE STEEL

$$f = \frac{P}{A} \pm \frac{Mc}{I} = \frac{550}{230.79} \pm \frac{617.4 \times 12 \times 141}{1.24 \times 10^6}$$

$$= 2.383 \pm 0.845 = \begin{cases} 3.23 \text{ k/ID} \text{ OK} \\ 1.54 \text{ k/ID} \text{ OK} \end{cases}$$

CHECK IF TENSION EXISTS FOR MIN. REACTIONS.

$$f = \frac{398.9}{230.79} - \frac{617.4 \times 12 \times 141}{1.24 \times 10^6} = 0.67 \text{ k/ID}$$

COMPR.

COMPR. →
3.23 k/ID OK
1.54 k/ID OK

$$\frac{1}{8} = 1/0$$

CHECKED _____

MODEL _____


TOP SUPPORT - CONTI
BASE PL. THICKNESS

$$f_b = \frac{P}{A_{PL}} \pm \frac{Mc}{I_{PL}} = \frac{550}{5130} \pm \frac{7408.8 * 142.5}{3,472 * 10^7} = 0.107 \pm 0.03$$


SMALL
NEGLECT

$$w = \frac{550 * 18}{23.5K * 12 * 18} = 0.108 \text{ K/10" * 18} = 1.944 \text{ K/IN}$$

SYM. ABOUT




NOTE: BEAM BENDING
SOLVED BY
MOMENT DISTRIBUTION



$$t = \sqrt{\frac{6M}{6F_y}} = \sqrt{\frac{6 * 1154.4}{18 * 27}} = 3.78"$$

USE PL 4"

STIFFENER PL




$b = 16"$
 $t = 1\frac{1}{2}"$
 $A = 24 \text{ in}^2$
 $I = 4.5$

$K = 1.0$

$$\frac{KL}{r} = 73.9 \Rightarrow F_a = 1601 \text{ K/10"}$$

$$f_a = \frac{63.49}{24} = 2.65 \text{ K/10" O.K.}$$




$$f_a = \frac{158.04}{24} = 6.59 \text{ K/10" O.K.}$$


CHECKED _____

MODEL _____

SUPPORT CALCULATIONS
EXCHANGERS IN
EXCESS EXCHANGER WEIGHT



NOTE: FOR VERTICAL ACCELERATION
 $P = 0.15 * 1703 = 255.45^k$
 $R_1 = 90.2^k$
 $R_2 = 5.01^k/ft.$
OR $2.50^k/ft/support.$



$A_{TOTAL} = 2 * 852.39 + 394.5 * 2$
 $= 2493.78 \text{ } \square \text{ } "$

$Q_{SADDLE} = \frac{394.5}{2493.78} * 119.2 = 18.9^k/support$
 $Q_{PLATE} = \frac{852.39}{2493.78} * 119.2 = 40.7^k/side\ support$
OR $f_{WELD\ PLATE_2} = \frac{40.7}{51 * 12} = 0.067^k/in$

CHECKED _____

MODEL _____

SUPPORT CALCULATIONS - CONTI

CHECK WELD STRESS ON COFFERDAM SIDE PLATE
LINE 1

$$f_{w, \text{VERTICAL}} = \frac{600 + 255.45}{2 \times 51 \times 12} = 0.699 \text{ K/IN}$$

$$f_{w, \text{HORIZ}_1} = \frac{40.7}{51 \times 12} = 0.067 \text{ K/IN}$$

$$f_{w, \text{HORIZ}_2} = \frac{54.6}{5 \times 12} = 0.91 \text{ K/IN}$$

$$f_R = \sqrt{f_{w, \text{V}}^2 + f_{w, \text{H}_1}^2 + f_{w, \text{H}_2}^2}$$

$$= 1.15 \text{ K/IN}$$


1/4" FW OK

SEE CALL. BELOW FOR W10 REACTION

LINE 2

$$f_{w2} = \frac{211.8 + 90.2}{2 \times 11 \times 12} = 1.4 \text{ K/IN} \quad 1/4" \text{ F.W. OK}$$

COFFERDAM SIDE PL FLANGES



$$f = \frac{54.6}{5 \times \pi} = 10.92 \text{ K/BOLT}$$

← REACTION FROM HYDROSTATIC PRESSURE ON W10 X 33

← SPACING OF W10

$$\text{TOTAL SHEAR PER BOLT} = \frac{1}{2} \sqrt{8.39^2 + 10.92^2} = 6.88 \text{ K/BOLT}$$

(CONSERVATIVE). O.K. FOR 1/4" ϕ BOLT.

REACTION FROM W10 X 33 - SEE COFFERDAM PLATE DESIGN

OTHER LOADS DO NOT GOVER SADDLE DESIGN.

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

APPENDIX I.3

TUBE SELECTION/DESIGN DATA



ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278

INTEROFFICE CORRESPONDENCE

TO: R. Pearson

CC: see Distribution

78.6853.6-005
DATE: 18 April 1978

SUBJECT: Fluted Tube Design Studies

FROM: C. E. Williamson

BLDG	MAIL STA.	EXT.
81	1513	62635

A study of fluted tube configurations manufactured by the GROB, INC process has been performed to establish candidate flute shapes with large (approx 1.5) area enhancement on configurations considered producible. The study included the following considerations:

1. Prediction of the GROB flute shape for a 2" dia tube scaled from GROB's 1" dia specimen.
2. Maintenance of an 0.040 deep convolute, regardless of tube diameter.
3. Constant thickness walls.
4. Wall thinning based on the GROB, INC/Union Carbide tube samples.
5. Wall thinning based on the GROB, INC/TRW first samples.

GROB, INC provided TRW with a drawing (Attachment 1) of the tubes they proposed to deliver to us. When received, the specimens matched the drawing precisely. These are the samples currently being tested for collapse pressure.

Our first design efforts were directed by the Project Office to address 2" dia tubes. Hence, the GROB 1" dia concept was scaled to a 2" dia based on maintaining the same level of material thinning. Attachment 2 was prepared and used as the basis for initial buckling analyses. Note: both the 1" and 2" tubes have low (approx 1.3) area enhancement.

Design layouts of 1", 1-1/2" and 2" dia fluted tubes based on maintaining the requested 0.040 flute depth were made. Tube wall thicknesses were based on preliminary predictions of thicknesses required for a corrugated/spiraled tube. Constant thickness was assumed. These concepts are illustrated in Attachment 3. Note that maintaining the 0.040 flute depth results in degraded

area enhancement at the larger diameters. Also note that equal 0.020 radii are not practical, when appropriate wall thicknesses are accounted for.

The next design iteration (Attachment 4, pages 1, 2, and 3) was based on constant wall thicknesses with tangent radii of the inner surfaces and ignoring the 0.040 flute depth constraint. The number of teeth was reduced until some tool tip radii was attained in the rills. These concepts are academic, since material thinning will occur during forming. Note that internal area enhancement is over 1.5.

Next, the degree of thinning experienced for the GROB, INC/Union Carbide tube was applied to the concepts of Attachment 4. These concepts are illustrated in Attachment 5, pages 1, 2, and 3 for the three diameters. Note that improved tool tip radii and tool wedge angles resulted. The inner profile, which is governed by the die remained unchanged. Area enhancement greater than 1.5 is realized.

The final design iteration is illustrated in Attachment 6, pages 1, 2, and 3. This concept accounts for wall thinning consistent with the first GROB/TRW specimens. Further improvement in tool tip radii and wedge angle was achieved. Note that these configurations, especially page 1, closely resembles the CMU configuration.

Status

No further design studies are planned unless requested by the Project Management, since these studies were considered out of scope with our PWA.

Recommendations

Depending on the results of the collapse pressure tests, we offer the following recommendations:

1. Review the designs of Attachment 6 for thermal characteristics.
2. Submit page 1 of Attachment 6 to GROB, INC for their review and request samples for pressure tests, if they concur.
3. Perform finite element analyses of these concepts to refine wall thicknesses.
4. Perform cost analyses to establish tube diameter for titanium in fluted configuration vs extruded aluminum.

Other Considerations

From a material volume standpoint, the titanium tubes in a CMU configuration are not competitive with fluted tubes unless the fins contribute to resistance to collapse pressures. Further studies are required to establish their contribution.

Tube cleaning considerations favor larger tubes.

Mike Nee and Dr. Hausrath favor consideration of smooth interior walled tubes in composite (0.020 inner liner of titanium in carbon steel or aluminum outer tubes). Several candidate fabrication methods require investigation, such as shrink fit, explosive forming or hydroforming. This concept may permit the use of larger diameter tubes. Thermal characteristics require analyses.

CEW:bai

DISTRIBUTION

T. Baumann
J. Denton
T. Dvorak
P. Edis
P. Fukunaga
A. Hausrath
J. Kaellis
L. Rosales
W. Tallon

attachments

TUBE O.D. - 1.000

.985 DIA.

.028

.935 DIA.

.888 DIA.

.844 DIA.

0.0355

I-235

TRW

THOMAS C. DVORAK
Member of Technical Staff
Applied Materials Department

SYSTEMS GROUP OF TRW INC.
One Space Park, Redondo Beach, California 90278 (213, 679-8711)


GROB INC. GRAFTON, WIS.

PROPOSED TOOTH SHAPE FOR TRW
22 TEETH 1" O.D. X .028 WALL TITANIUM

DRN. MFV	TR.	CH.
DATE 2-70	SCALE 50X	O. K.


TRW

NO. 8000	PART NO.	MATERIAL	HEAT TREATMENT
----------	----------	----------	----------------




NOTE : ESTIMATED PROPORTIONS BASED
 ON GPOB, INC FORMING TECHNIQUE.

6X 3/8, 19




CONSTANT WALL THICKNESS CORRUGATED TUBES W/0.040 DEEP INNER SURFACE CONVOLUTIONS




I-238


CONSTANT THICKNESS DESIGN FOR 1" DIA FINISHED O.D.




CONSTANT THICKNESS DESIGN FOR 1-1/2" DIA FINISHED O.D.




CONSTANT THICKNESS DESIGN FOR 2" DIA FINISHED O.D.




CONSTANT THICKNESS, 1" DIA FINISHED O.D. ADJUSTED
FOR THINNING BASED ON GROB/UNION CARBIDE RESULTS



CONSTANT THICKNESS, 1-1/2" DIA FINISHED O.D. ADJUSTED
FOR THINNING BASED ON GROB/UNION CARBIDE RESULTS



CONSTANT THICKNESS, 2" DIA FINISHED O.D. ADJUSTED FOR THINNING BASED ON GROB/UNION CARBIDE RESULTS




CONSTANT THICKNESS 1" DIA FINISHED O.D. ADJUSTED FOR THINNING BASED ON FIRST SAMPLES OF GROB/TRW DESIGN

1.000
1.000
1.000


.000
 $.021 R \times 50 = 1.05 R$
 .985 DIA
 .015 on DIA
 $.0075 \text{ on } R \times 50 = .375$

I-244

1.000
 .838
 .162 on DIA
 $.001 \text{ on } R \times 50 = .05$
 = 4.05
 1.000
 .896
 .104 on DIA
 .052 on DIA
 =
 2.16
 50X



CONSTANT THICKNESS, 1-1/2" DIA FINISHED O.D. ADJUSTED FOR THINNING BASED ON FIRST SAMPLES OF GROB/TRW DESIGN



CONSTANT THICKNESS, 2" DIA FINISHED O.D. ADJUSTED
FOR THINNING BASED ON FIRST SAMPLES OF GROB/TRM DESIGN



DEFENSE AND SPACE SYSTEMS GROUP

ONE SPACE PARK • REDONDO BEACH • CALIFORNIA 90278

INTEROFFICE CORRESPONDENCE

TO: P. Edris

CC:

DATE: 19 May 1978

SUBJECT: Producibility Considerations for Tube Configuration Selection

FROM: L. A. Rosales 

BLDG.

MAIL STA.

EXT.

01

2220

52630

Reference: "Tube Selection Meeting Minutes", P. Edris to Distribution,
17 May 1978

For convenience, the backup tube producibility data used for the selection (see reference) is included. The formability limits are given in graph form with best engineering judgement used to assess these limits. The first tubes attempted by Teledyne will be a 1.00 inch O.D. x .028 inch wall, C.P. Titanium (ASME SB338 GR2) formed to the CMU shape with a .040 inch amplitude (flute to rill). A total of 36 flutes will be attempted (pitch approximately .087 inch).

It is expected that the results of this run will be available about June 15, 1978.

LAR:dj

Distribution

T. Baumann W. Tallon
J. Denton C. Williamson
R. Douglass
T. Dvorak
P. Fukunaga
A. Hausrath
J. Hsu
J. Kaellis
G. Kikin
R. Pearson
W. Rogers

TUBE CONFIGURATION SELECTION

CRITERIA:

1. CMU Shape on OD.
2. Maximum Possible Enhancement on ID.
3. Maximum No of Flutes Possible
4. Titanium Tubing
5. Lowest Cost Forming Process

SELECTION

1. 1.00 INCH OD TUBE, 36 FLUTES, .040 INCH FLUTE HEIGHT, CORRUGATED CROSS SECTION.

RATIONALE: THIS TUBE CONFIGURATION HAS A POSSIBILITY OF BEING ACCOMPLISHED BY AVAILABLE PROCESSES.

BACKUP POSITION


1. INVESTIGATE EFFECT ON HX COST/PERFORMANCE IF WE MUST USE:
 - a) 28 FLUTES
 - b) 32 FLUTES
 - c) MODIFIED CMU PROFILE W/36 FLUTES
2. INVESTIGATE ALTERNATE MATERIAL (ALLEGHENY 6X).

RATIONALE: IF 36 FLUTE PROFILE CAN NOT BE ACCOMPLISHED IN THICKNESSES REQUIRED FOR DTEE, EITHER THE PITCH MUST BE MODIFIED ^{AND/OR} OR THE SHAPE MUST BE CHANGED.

: IF DOE DATA SHOWS THAT THE CORROSION ALLOWANCE REQUIRED FOR ALLEGHENY 6X IS VERY LOW ($<.002$), THEN THIS MATERIAL CAN BE USED SINCE $E = 30 \times 10^6$, $F_{ty} = 90 \text{ KSI}$ (INITIAL WALL CAN BE THINNER).

TLIBE PRODUCIBILITY DATA

"CORRUGATED" APPROACH






Mat'l: C.P. Titanium
 ASME SB 338 GR 2.
 Tubing of
 Equivalent

Key:

PRODUCIBLE		} BEST ENGINEERING JUDGEMENT AS OF 18 MAY 1978
POSSIBLY PRODUCIBLE		
NOT PRODUCIBLE		

O.D. / ^{nominal} thick. / d / R_1 / R_2 / shape = Identification Code

Identification Code	Number of Flures (Pitch)									
	0+22	24	26	28	30	32	34	36	38	40
	(0-.143)	(.131)	(.121)	(1.12)	(1.05)	(.098)	(.092)	(.087)	(.083)	(.079)




Candidate Forming Processes / Fabricators

1. Form / Roll Teledyne - Aero Cal, San Marcos, Calif
2. Drawing Valley Metals, El Cajon, Calif (or) La Fiel Tube, Santa Fe Spr., Calif.
3. Pneumatic (Hot) Rockwell, Los Angeles, Calif
4. Roll / Upset Grob Inc, Grafton, Wis. (or) Yorkshire - Imperial, Leeds, England.
5. Hydraulic TRW - Materials Engineering Dept.

TUBE PRODUCIBILITY DATA


"RIBBED" APPROACH




Mat'l: C.P. Titanium
 ASME SB 338 GR2
 Tubing or Equivalent

Key:

PRODUCIBLE
 POSSIBLY PRODUCIBLE
 NOT PRODUCIBLE



BEST ENGINEERING
 JUDGEMENT AS OF
 18 MAY 1978



Candidate Processes / Fabricators

1. Roll / Upset: Grob, Grafton, Wis. (Info reflected in graph)
2. Coining: Nardon, Alhambra, Calif (Info incomplete)
3. Roll: (No vendor ~~was~~ located)
4. Extrusion: Nuclear Metals, Concord, Mass. (Very expensive)
5. Embossing: Rigidized Metal, Buffalo, NY. (Refused to quote).

INTEROFFICE CORRESPONDENCE

TO: J. W. Denton

CC: Distribution

DATE: 30 May 1978

SUBJECT: OTEC Heat Exchanger Tube Structural
Trade-off and AnalysisFROM: T. R. Baumann *TAB*
BLDG. MAIL STA. EXT.
81 1513 62635INTRODUCTION

This memorandum summarizes the results of the structural tradeoff studies of five selected titanium tube candidates for the OTEC Heat Exchanger tubes. It also summarizes the structural design criteria used in the analysis.

SUMMARY

Five selected candidate configurations for OTEC Heat Exchanger tubes were analyzed. The results of the analysis are summarized in Table 1. All candidates were titanium corrugated tubes having diameters of 1, 1 1/2 and 2 inches. The thickness requirements for each of these candidates were established from ASME pressure vessel code requirements for round tubes. Each candidate was analyzed by a finite element computer analysis to derive a "corrugation factor" which accounts for the effect of the difference between the actual tube shape and a round tube. Some of the candidate configurations showed a substantial reduction in external pressure capability due to corrugation.

DISCUSSION

Five titanium tube candidates were selected for analysis. Thickness requirements were established for each candidate for an evaporator pressure of 136 psi and a condenser pressure of 86 psi in tube diameters of 1, 1 1/2 and 2 inches.

Each candidate configuration was first analyzed by a finite element computer analysis to derive its corrugation factor. The "corrugation factor" is the ratio of the buckling pressure of the corrugated tube to that of an equivalent round tube of the same diameter and reference thickness. The SAP - IV finite element computer program was used for this analysis. Previous studies of a similar corrugated tube configuration have shown excellent comparison of SAP IV results with static analysis using the Nastran computer program. An attempt was made to derive a corrugation factor with the Nastran shell buckling procedure, this was however unsuccessful due to problems encountered in the Nastran software by the program vendor.

Tests conducted on a limited number of corrugated and round tubes samples have shown that the static analysis for derivation of the corrugation factor is adequate for use in tube design.

The corrugation factors for each candidate were used to compute an effective pressure of an equivalent round tube of the same diameter and reference thickness. The effective pressure was then applied to round tube design curves derived from the ASME pressure vessel code to select the required thickness of the corrugated tube. The results of this analysis are shown in Table 1 and Figure 1. The use of the ASME code data rather than a less conservative procedure is discussed in the following paragraphs.

DESIGN CRITERIA OPTIONS

Three structural design criteria options were evaluated in the tube structural requirements study. The effect of these options is shown in Figure 2 for the selected tube design candidate (1 inch tube/36 corrugations). Option 3 results in a decrease in required wall thickness of .005 inches in the evaporator and .004 inches in the condenser. This option was however not selected due to its extremely high risk. Option 2 results in a decrease of .001 inches in the evaporator and .0015 inches in the condenser. Since these savings are small and the option involves both additional risk and potential test problems Option 2 was not selected. Option 1, which was the baseline option in the study, was selected as the appropriate structural design criteria for sizing OTEC Heat Exchanger tubes. This option uses the ASME pressure vessel code for round tubes and compensates for loss of external pressure capability based upon finite element deflection analysis of the corrugated tube.

OPTION 1

This procedure is based upon the ASME pressure vessel code. Corrugated tubes are evaluated based upon an equivalent round thin walled cylinder shape. The degradation of buckling pressure due to corrugation is accounted for by an analytical corrugation factor which is derived by finite element analysis of both the corrugated tube and equivalent round tube. The corrugation factor is the ratio of the buckling pressure of the corrugated shape to the buckling pressure of the equivalent round tube. The round tube allowable buckling pressures are computed using the procedure for determining the thickness of shells and tubes under external pressure, according to the ASME boiler and pressure vessel code (Section VIII, Division 1, UG - 28). Tubes designed to this procedure should present no problems when tested to a pressure of 1.5 times the maximum allowable pressure required by the ASME code for hydrostatic testing. They also should present no problems under operating conditions when subjected to additional loading conditions such as sea state dynamics. This option is a conservative low risk approach which will require a minimum of effort to satisfy safety and environment requirements. Qualification and acceptance testing will also be minimized.

OPTION 2

This analytical procedure is similar to that in Option 1 with the following exception. The allowable buckling pressure is computed based upon the theory of elastic stability for round cylindrical tubes having an initial out of roundness of one percent. Corrugated tube requirements are obtained by use of the same analytical corrugation factor derived for Option 1. This procedure increases the allowable buckling pressure. Since it also removes most of the ASME code safety margin a factor of safety of 1.25 must be added to assure that the tubes will not fail. This is considered the minimum acceptable factor and will lower the allowable pressure accordingly. Tubes designed to this procedure should be able to withstand a pressure of 1.25 times the maximum allowable pressure required by the ASME code for pneumatic testing but may not be able to withstand the pressure required for hydrostatic testing of the Heat Exchanger structure according to ASME code and may require either pneumatic testing or an exemption from testing to the ASME code. This option may also present problems when combined loading conditions due to sea state dynamics are analyzed. It will require a substantial effort to show that it satisfies safety and environmental requirements and will require a more extensive effort for tube qualification and acceptance testing. This procedure is a moderate risk approach.

OPTION 3

The analytical procedure for Option 3 is almost the same as Option 2, However, instead of using elastic stability theory, a curve based upon the mean of actual test results is used. Past testing of steel tubes shows that the actual buckling pressure is somewhat higher than predicted by use of an initial one percent out of roundness assumption in elastic stability theory. The steel tube test data is converted to equivalent titanium data and utilized to predict the buckling pressure of round thin walled cylindrical tubes. Corrugated tube data is again obtained by use of the analytical corrugation factor. The risk in this procedure is high since the test data curve is based upon the average of a great many commercial tubes taken at random from stock. In several individual tests buckling pressures comparable to perfectly round tubes were achieved while other tests had failures at lower pressures than the test data curve. As in the case of Option 2 this procedure requires use of a minimum factor of safety of 1.25. Tubes designed to this procedure might be able to withstand a pressure required by the ASME code for pneumatic testing but there is a high degree of risk of tube failure. Hydrostatic testing according to the ASME code should not even be considered for this option unless the tubes are pressurized internally. This option also involves a high degree of risk for combined loading conditions. The procedure would require a large analytical and test effort to show that it satisfies safety and environmental requirements.

REFERENCE LIST

- 1) ASME "ASME Boil and Pressure Vessel Code Section VIII Division I", 1 July 1977, Amer. Soc. of Mechanical Engineers
- 2) KING "Piping Handbook", Fifth Edition 1967, Mc Graw Hill Co.
- 3) ASME "Pressure Vessel and Piping Design Collected Papers 1927-1959" 1960, American Soc of Mechanical Engineers
- 4) MEGYESY "Pressure Vessel Handbook", Oct, 1977, Pressure Vessel Handbook Publishing Co.
- 5) FER 73-11 "SAP IV Structural Analysis Program for Static and Dynamic Response of Linear System", April, 1974 Univ. of Calif. Berkeley, CA.

**TABLE 1
TITANIUM TUBE THICKNESS REQUIREMENTS
FOR OTEC HEAT EXCHANGER TUBES
(1, 1 1/2 AND 2 INCH TUBE DIAMETERS)**

CANDIDATE TUBE CONFIGURATIONS	CORRUGATION FACTOR	EFFECTIVE PRESSURE (PSI)		TUBE THICKNESS (INCHES)					
				EVAPORATOR TUBE DIAMETER (INCHES)			CONDENSER TUBE DIAMETER (INCHES)		
				EVAP.	COND.	1"	1-1/2"	2"	1"
SINGLE FLUTE TUBE SMOOTH INSIDE (64 CORRUGATIONS)*	1.000	136	86	.023	.035	.047	.020	.030	.040
DOUBLE FLUTE TUBE .026 AMP. (64 CORRUGATIONS)**	.840	162	102	.024	.036	.049	.021	.032	.043
DOUBLE FLUTE TUBE .040 AMP. (64 CORRUGATIONS)**	.660	207	130	.026	.039	.053	.023	.034	.046
GROB CONFIGURATION TUBE (24 CORRUGATIONS)***	.375	363	229	.033	.049	.065	.027	.041	.055
CMU EXTERNAL CONFIGURATIONS TUBE (36 CORRUGATIONS)***	.416	327	207	.031	.047	.063	.026	.040	.053

- 1) ALL THICKNESSES ARE IN INCHES
- 2) ALL THICKNESS REQUIREMENTS ARE BASED UPON ASME CODE AND SAP IV COMPUTER ANALYSIS.
- 3) THICKNESS ARE MINIMUM AND SHOULD BE INCREASED BY 10% FOR MANUFACTURING TOLERANCES TO OBTAIN NOMINAL THICKNESSES.

* BASED UPON INSIDE DIAMETER. THICKNESS DOES NOT INCLUDE FLUTE MATERIAL.

** BASED UPON AVERAGE INSIDE DIAMETER. THICKNESS IS MINIMUM THICKNESS OF TUBE.

*** BASED UPON EXTERNAL DIAMETER. THICKNESS IS ORIGINAL ROUND TUBE THICKNESS PRIOR TO CORRUGATION PROCESS. MINIMUM THICKNESS IS 60% OF ORIGINAL THICKNESS.

FIGURE 1
TITANIUM HEAT EXCHANGER TUBE
CANDIDATE COMPARISON

I-256





FIGURE 2
 STRUCTURAL DESIGN OPTION COMPARISON
 (1 INCH TITANIUM TUBES 36 CORRUGATIONS)

1-257



INTEROFFICE CORRESPONDENCE

TO: J. W. Denton

CC: Distribution

DATE: 1 June 1978

SUBJECT: Test Report for OTEC Heat Exchanger Tube Tests

FROM: T. R. Baumann *TAB*

BLDG 81 MAIL STA. 1513

EXT. 62635

INTRODUCTION

This memorandum presents the results of the OTEC Titanium heat exchanger tube tests conducted on 18-19 April 1978. A comparison is made of the test results with various analytical computer studies used to determine tube external pressure capability.

SUMMARY

A comparison of the test results with predictions shows that the round tubes tested had buckling pressures close to the theoretical limit for perfectly round tubes, which is better than anticipated. Based upon the limitations in the number of samples this data cannot be utilized directly in tube design without additional test substantiation. Comparison of test data with the results of the analytical procedure for derivation of a "corrugation factor" showed that the analytical SAP-IV 3 DOF procedure was sufficiently accurate for design of corrugated tubes when used in conjunction with the ASME code procedures for pressure vessel design.

DISCUSSION

Tube testing was performed to determine the maximum external pressure capability of corrugated titanium tubes and to verify the analytical procedure for computing the reduction in pressure capability due to the effects of corrugation. The test specimens consisted of three corrugated titanium tubes (22 corrugations) manufactured by GROB Inc. from 1 inch round titanium tubing having a nominal wall thickness of .028 inches. Two round tubes of .028 nominal wall thickness were also tested. Cross sections to these tubes are shown in Figures 2 and 3. Table 1 presents the results of the five tests. Figure 1 shows a comparison of the test results to the predicted test values and to buckling strength relationships commonly used for design of round tubes. Tube strength predictions prior to testing were based upon the one percent out of round elastic stability relationship which is the generally accepted lower limit for round tube buckling under external pressure. Past testing on steel tubes indicates a somewhat higher pressure capability, however, the test relationship is based upon the average of a large number of commercial steel tubes taken at random from stock.

Individual failures during past testing ranged all the way from round tube theory for perfectly round tubes to values near the one percent out of round relationship. The round titanium samples of this test achieved pressures of 710 and 720 PSI in test which is slightly above the theoretical limit for perfectly round tubes. Some of the factors which account for the test pressure being above the theoretical limit are the tube thickness (average thickness was slightly above .026 used in predictions) and modulus of elasticity (15.5×10^6 PSI lower limit for titanium was used in computations). Taking these factors in account it is concluded that the particular samples tested achieved buckling pressures close to those predicted by round tube theory rather than one percent out of round theory even though these tubes had an initial out of roundness of approximately one percent prior to testing. Since the two sections of round tube tested were cut from the same tube this observation is limited to the particular tube tested and cannot be used as a design point for design of OTEC heat exchanger tubes without additional test substantiation.

A comparison of the buckling strength of corrugated tubes to round tubes resulted in good correlation with analytical predictions using the SAP-IV and Nastran computer codes (see table 2). Although the test samples were limited, the three corrugated tubes failed at approximately the same pressure and the corrugation factor determined by test (.32) was close to that previously predicted (.44). After the pre test prediction was made the SAP-IV computer program model was increased from a two degree of freedom node model to three degrees of freedom. This resulted in even better comparison with test data (.40). A check using the Nastran computer code verified the SAP-IV analysis and derived a corrugation factor of (.37). It is concluded that the analytical SAP-IV procedure is sufficiently accurate to be used in tube design in conjunction with the ASME code procedures for pressure vessel design.

TEST SPECIMENS

The test specimens consisted of three corrugated tubes, having 22 corrugations each, manufactured by Grob Inc, and two round tubes. All tubes were titanium and were manufactured based upon a nominal wall thickness of .028 inches. Measurement of actual wall thickness prior to testing showed an average wall thickness which was closer to .026 inches. This was true for both the round tubes and undeformed ends of the corrugated tubes. The test specimens prior to testing are shown in Figures A-1 through A-4. Pictures of the deformed specimens are shown in Figures C-1 through C-4. Sketches of the round tube, Grob tube corrugation and computer corrugation model are shown in Figures 2 and 3.

TEST FACILITY AND DATE

Tests were conducted in facilities of the Applied Technology Division of TRW on 18 & 19 April 1978. The test conductor was Ed Burchman and the responsible engineer was T. R. Baumann.

TEST SETUP AND INSTRUMENTATION

Pictures of the test fixture, test setup and instrumentation are shown in Figures B-1 through B-4. The test fixture consisted of aluminum tube sections welded to end flanges. Two end plates were used to hold the test specimens. The end plates utilized "O-Ring" seals to provide a pressure seal having minimum restraining effects at the ends of the specimens. Details and dimensions of the test fixture are given in Figure 4. Water was used as the pressurizing fluid between the test fixture and external walls of the test specimens. The test specimens were open at both ends to allow internal tube measurements, during the tests. Two pressure gages were used for the tests. The smaller gage had a maximum capability of 150 PSI and was used to measure pressures up to its maximum capability and to verify the calibration of the larger gage up to 150 PSI.

TEST PROCEDURE

The test procedure was similar for all specimens. After installation in the test fixture the test specimen was measured internally with an inter-mike or bore gage to determine the approximate location and orientation of its minimum internal diameter. During testing this point was monitored periodically to determine deflection under pressure. The fluid pressure was increased in initial increments up to 150 PSI. At 150 PSI the small pressure gage was disconnected and the pressure was increased incrementally using the larger gage. In the vicinity of the failure point all corrugated tubes were measured at 5 PSI increments and all round tubes at 10 PSI increments.

TEST RESULTS

All test specimens behaved similarly during testing. Deformations were not measureable during the early stages of testing. During the higher test pressures slight deformations were encountered but these were barely measurable. Within 10-20 PSI of failure the deformations started to become significant. Deformations increased very rapidly near the failure pressure. At failure there was a rapid decrease in gage pressure. Despite attempts to pump up and increase the pressure the deformation of the tubes increased correspondingly and would not support higher pressure. Two of the corrugated tubes eventually cracked as the deformations became large. The other corrugated tube was not deformed to the point of cracking but probably would have cracked had pumping continued. The round tubes deformed much more than the corrugated tubes without cracking but they might have also experienced cracks if pumping had continued. In all tests the tube collapse occurred near the point of minimum internal diameter.

The test results are given in Table 1. The buckling pressure is the maximum pressure shown on the pressure gage prior to tube collapse. The mean buckling pressure was 715 PSI for the two round tube specimens and 231.3 PSI for the three corrugated specimens.

TRB:dp

TABLE 1
TEST RESULTS

SPECIMEN NUMBER	BUCKLING PRESSURE	
SPECIMEN #1 CORRUGATED	232	PSI
SPECIMEN #2 CORRUGATED	232	PSI
SPECIMEN #3 CORRUGATED	230	PSI
SPECIMEN #4 ROUND TUBE	710	PSI
SPECIMEN #5 ROUND TUBE	720	PSI


TABLE 2


CORRUGATION FACTOR COMPARISON

TYPE OF ANALYSIS OR TEST	CORRUGATION FACTOR
SAP IV PREDICTED TEST VALUE (TWO DEGREE OF FREEDOM NODES)	.44
TEST RESULTS (ROUND TUBE VRS CORRUGATED TUBES)	.32
SAP IV ANALYSIS (THREE DEGREE OF FREEDOM NODES)	.40
NASTRAN STATIC ANALYSIS THREE DEGREE OF FREEDOM NODES	.37


CORRUGATION FACTOR IS THE RATIO OF THE BUCKLING PRESSURE OF THE CORRUGATED TUBE TO THAT OF AN EQUIVALENT ROUND TUBE HAVING THE SAME REFERENCE DIAMETER AND THICKNESS.

FIGURE 1
TITANIUM TUBE TESTS
PREDICTIONS AND TEST RESULTS






NOTE :

1. ALL DIMENSIONS ARE IN INCHES.
2.  ANALYTICAL MODEL

**FIGURE 2 . GROB TUBE CONFIGURATION
(CORRUGATION DEFINITION)**



**FIGURE 3.
GROB TUBE COMPARISON**




FIGURE 4




FIGURE A-1
TEST SPECIMENS FULL LENGTH




FIGURE A-2
CORRUGATED TUBE CLOSEUP
I-268




FIGURE A-3
CORRUGATED TUBE CROSS SECTION




FIGURE A-4
CORRUGATED CROSS SECTION CLOSEUP




FIGURE B-1
TEST SETUP & INSTRUMENTATION




FIGURE B-2
TEST FIXTURE INCLINED VIEW

I-270




FIGURE B-3
TEST FIXTURE FRONT VIEW




FIGURE B-4
TEST FIXTURE DETAILS
I-271




FIGURE C-1
FAILED SPECIMENS NARROW SIDE




FIGURE C-2
FAILED SPECIMENS FLAT SIDE




FIGURE C-3
FAILURE DETAILS NARROW SIDE




FIGURE C-4
FAILURE DETAILS FLAT SIDE
I-273

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**


APPENDIX I.4
0.2 MWe TEST ARTICLE LOOP

APPENDIX I.4

0.2 MWe TEST ARTICLE LOOP

This appendix provides additional details of the design and equipment for 0.2 MWe test article loop.

It includes sketches on the proposed layout, plan views, equipment details and the piping and instrumentation diagram.



CONTROL STATION - PLAN VIEW


PREPARED P.L. TRUBSY 6-24-76

CHECKED _____

MODEL _____

REPORT NO.

OTEC OIL MWE TEST ARTICLE
PROPOSED LAYOUT



PLAN VIEW \updownarrow 1'-0"

PREPARED P.L. TRUBEY


REPORT NO. _____

PAGE 3

CHECKED _____

DTEC 0.2 MW_e TEST ARTICLE
PROPOSED LAYOUT

MODEL _____




FOR ALL DWGS :


- 1) ALL ELBOWS 1 1/2-D (LONG RADIUS)
- 2) CRITICAL DIMENSIONS GIVEN
- 3) SCALE (MEASURED) DIMENSIONS APPROXIMATE

EQUIPMENT DETAILS


1) FILTER




2) PUMP




3)





DESIGNED P. TRUPEY	OTEC 0.2 MWe TEST ARTICLE PROPOSED LAYOUT	REVISION		BY	APPD
DRAWN H. HUDSON		YFWM		DRAWING NUMBER	
CHECKED		FACILITIES, MECHANICAL AND POWER INTEGRATION LABORATORY		6850.78-71	
APPROVALS				ISSUE DATE	CHK LTR
FACE OFFICE					

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**



NOTES:

1 AMMONIA VENTS, RELIEFS & SEAL PURGES SHALL CONNECT TO COMMON VENT LINE & RETURN TO AMMONIA RECOVERY SYSTEM.

T-1
EVAPORATOR SUMP
 CAPACITY 1,000 GAL
 DESIGN PRESS 150 PSIG
 DESIGN TEMP -28F TO 120F

E-1
EVAPORATOR
 HX RATING .2 MWe
 10,694 GPM WATER 84F
 325 GPM AMMONIA 135 PSIA

F-1
FILTER
 5 MICRON
 1 PSI ΔP
 325 GPM

P-1
NH₃ RECIRCULATION PUMP
 325 GPM 58 FT TDH 3 BHP

INSTRUMENT LIST

NO.	SENSOR NAME	PURPOSE	RANGE	ACCU.	SET POINT	COMMENTS
DP-1	DIFFERENTIAL PRESSURE	PRESSURE DROP ACROSS FILTER UNIT F-1	0-10 PSI	+ 0.10 PSI	NA	LOCAL AND REMOTE READING
FE-1	FLOW ELEMENT	MEASURE NH ₃ FLOW RATE	0-350 GPM			SONIC FLOW MEASUREMENT SYSTEM WITH REMOTE READ AND STRIP RECORDER, INPUT SIGNAL TO FLOW CONTROL VALVE V-3
FT-1	FLOW TRANSMITTER	TRANSMITS FE-1 OUTPUT				
FRC-1	FLOW RECORDING CONTROLLER	DISPLAYS AND RECORDS FE-1 OUTPUT			325	
LE-1	LEVEL ELEMENT	INDICATE NH ₃ FLOTD LEVEL IN TANK T-1	0-4 FT	±1"	2 FT	CONTROLS FEED RATE
PE-1	PRESSURE ELEMENT	INDICATE E-1 NH ₃ FLUID INLET PRESSURE	0-150 PSI	0.5% OF F.S.	NA	TO RECORDER
PE-2	PRESSURE ELEMENT	INDICATE PUMP P-1 DISCHARGE PRESSURE	0-150 PSI		NA	TO RECORDER
PE-3	PRESSURE ELEMENT	INDICATE PUMP P-1 SUCTION PRESSURE	0-150 PSI		NA	TO RECORDER
TE-1	TEMPERATURE ELEMENT	INDICATE E-1 NH ₃ FLUID INLET TEMPERATURE	-30 TO +120°F	0.25% OF F.S.	NA	TO RECORDER
TE-2	TEMPERATURE ELEMENT	INDICATE PUMP P-1 SUCTION TEMPERATURE			NA	TO RECORDER

INSTRUMENT SYMBOLS

- DIFFERENTIAL PRESSURE
- FLOW ELEMENT
- FLOW TRANSMITTER
- FLOW RECORDING CONTROLLER
- LEVEL ELEMENT
- PRESSURE ELEMENT
- TEMPERATURE ELEMENT
- LOCAL READOUT
- SIGNAL TRANSMITTED TO CONTROL ROOM PANEL

EQUIPMENT LIST

ITEM NO.	ITEM FUNCTION	MANUFACTURER	PART NUMBER	SIZE & TYPE CONNECTION	DESIGN PRESSURE (PSIG)	TYPE OPERATOR	SERVICE WEIGHT (POUNDS)	COST (\$)	LONG LEAD (WEEKS)	MISCELLANEOUS DATA
T-1	EVAPORATOR SUMP TANK	SEE SPECIFICATION		4' 10x10' TANGENTS	150	NA NH ₃			L	ASME FLANGED & DISHED HEADS 18" MANWAY
P-1	AMMONIA RECIRCULATION PUMP	SEE SPECIFICATION		6" 300# R.F. SUCT. 4" 300# R.F. DISCH.	150	ELEC. MOTOR DRIVE NH ₃	205	2K	L	SPECIFY LOW NPSH AMMONIA SERVICE
F-1	AMMONIA FULL FLOW FILTER UNIT	SEE SPECIFICATION		8" BW	150	NA NH ₃			L	ΔP(DIRTY)=1.0 PSI 325 GPM MULTIPLE UNITS 40MICRON ABSOLUTE
V-1	PUMP SHUTOFF	POST-SEAL		6" 300# BUTTERFLY	150	MANUAL NH ₃	37	432 (M)		ETHYLENE PROPYLENE O-RINGS, STEEL SEAT
V-2	PUMP SHUTOFF	POST-SEAL		6" 300# BUTTERFLY	150	MANUAL NH ₃	37	472 (M)		SAME AS V-1
V-3	FLOW CONTROL MODULATING TANK T-1	POST-SEAL		6" 300# BUTTERFLY	150	PNEUMATIC NH ₃	70	1522 (M)	L	SAME AS V-1 AND PNEUMATIC OPERATOR
RV-1	TANK T-1 PRESSURE RELIEF	COMMERCIAL		4" 300#	150	NA NH ₃				SET 150 PSI C/S
RV-2	LINE RELIEF	COMMERCIAL		2" 300#	150	NA NH ₃				SET 150 PSI C/S
RV-3	LINE RELIEF	COMMERCIAL		2" 300#	150	NA NH ₃				SET 150 PSI C/S

- RELIEF VALVE
- BUTTERFLY VALVE
- DIAPHRAGM OPERATED VALVE
- FLOW METER
- REDUCER

DESIGNED <i>E. DIOMILLO</i>	.2 MWe EVAPORATOR TEST LOOP P. I.D.	TRW FACILITIES, MECHANICAL AND POWER INTEGRATION LABORATORY	DRAWING NUMBER 6550.78-70	
DRAWN <i>R. WELTHER</i>			ISSUE DATE	CHG LTR
CHECKED <i>Ed Juley</i>				
APPROVALS				
PROG OFFICE				