

DEC 22 1964

Copy No 19

**MASTER**  
**APAE MEMO-297**

AEC Research and  
Development Report  
UC-81, Reactors - Power  
(Special Distribution)

**SINGLE ELEMENT FLOW TESTS  
FOR TYPE 3 (SM-2) FUEL ELEMENTS  
IN SM-1, SM-1A, AND PM-2A CORES**



**ALCO PRODUCTS, INC.**

NUCLEAR POWER ENGINEERING DEPARTMENT  
P. O. BOX 414, SCHENECTADY 1, N. Y.

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

APAE Memo - 297

AEC Research and  
Development Report  
UC-81, Reactors - Power  
(Special Distribution)

**SINGLE ELEMENT FLOW TESTS  
FOR TYPE 3 (SM-2) FUEL ELEMENTS  
IN SM-1, SM-1A, AND PM-2A CORES**

By  
P. S. Krause

Approved By:  
M. H. Dixon, Project Engineer

Issued: November 27, 1961

Contract No. AT (30-1)-2639  
with U. S. Atomic Energy Commission  
New York Operations Office

**ALCO PRODUCTS, INC.**  
Nuclear Power Engineering Department  
Post Office Box 414  
Schenectady 1, N. Y.



## AEC LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights:

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

## ALCO LEGAL NOTICE

This report was prepared by Alco Products, Incorporated in the course of work under, or in connection with, Contract No. AT(30-1)-2639, issued by U.S. Atomic Energy Commission, NYOO; and subject only to the rights of the United States, under the provisions of this contract, Alco Products, Incorporated makes no warranty or representation, express or implied, and shall have no liability with respect to this report or any of its contents or with respect to the use thereof or with respect to whether any such use will infringe the rights of others.

## DISTRIBUTION

### External Copies

- 1 - 3      New York Operations Office  
U. S. Atomic Energy Commission  
376 Hudson Street  
New York 14, New York  
Attention: Chief, Army Reactors Staff  
Reactor Division
- 4 - 6      U. S. Atomic Energy Commission  
Washington 25, D. C.  
Attention: Chief, Water Systems Project  
Branch (Army Reactors)  
Division of Reactor Development  
Mail Station F-311
- 7          U. S. Atomic Energy Commission  
Washington 25, D. C.  
Attention: Chief, Evaluation and  
Planning Branch  
Civilian Reactors  
Div. of Reactor Development  
Mail Station F-311
- 8          U. S. Atomic Energy Commission  
Chief, New York Patent Group  
Brookhaven National Laboratory  
Upton, New York  
Attention: Harman Potter
- 9          Idaho Nuclear Power Field Office  
P. O. Box 2558  
Idaho Falls, Idaho
- 10        U. S. Atomic Energy Commission  
Reports and Statistics Branch  
Division of Reactor Development  
Washington 25, D. C.
- 11 - 12    Office of the Chief of Engineers  
Department of the Army  
Building T-7  
Washington 25, D. C.  
Attention: Chief, Projects Branch  
Nuclear Power Division

External  
Copies

DISTRIBUTION (CONT'D)

- 13 - 15      Nuclear Power Field Office  
             U. S. Army Engineer Reactors Group  
             Fort Belvoir, Virginia  
             Attention: Chief, Nuclear Power  
                         Field Office
- 16            Nuclear Power Field Office  
             U. S. Army Engineer Reactors Group  
             Fort Belvoir, Virginia  
             Attention: O. I. C. SM-1
- 17            Chief, U. S. Army Reactors Group  
             Fort Greely, Alaska  
             APO 733  
             Seattle, Washington  
             Attention: O. I. C. SM-1A
- 18            Commanding Officer  
             U. S. Army Polar Research  
             and Development Center  
             Fort Belvoir, Virginia  
             Attention: Nuclear Power Officer
- 19 - 21      Office of Technical Information Extension  
             P. O. Box 62  
             Oak Ridge, Tennessee
- 22            Union Carbide Nuclear Corporation  
             Oak Ridge National Laboratory  
             Y-12 Building 9704-1  
             P. O. Box "Y"  
             Oak Ridge, Tennessee  
             Attention: L. D. Schaffer
- 23            The Martin Company  
             P. O. Box 5042  
             Middle River, Maryland  
             Attention: AEC Contract Document Custodian
- 24 - 25      Combustion Engineering, Incorporated  
             Nuclear Division  
             Prospect Hill Road  
             Windsor, Connecticut  
             Attention: Mr. J. B. Anderson

DISTRIBUTION (CONT'D)

External  
Copies

26 - 27

Alco Products, Inc.  
Post Office Box 145  
Fort Belvoir, Virginia  
Attention: W. K. Stromquist  
F. G. Moote

Internal  
Copies

28	K. Kasschau
29	J. Gronan
30	J. F. Haines
31	J. G. Gallagher
32	M. H. Dixon
33	W. T. Williams
34	R. E. Williams
35	J. A. Christenson
36	J. P. Tully
37	F. T. Matthews
38	S. L. Davidson
39	G. R. Griffith
40	L. A. Taylor
41	P. S. Krause
42	R. E. Neville
43 - 50	NPED File

**THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK**



## ABSTRACT

Channel-to-channel flow distribution within Type 3 (SM-2) stationary and control rod fuel elements modified for use in the SM-1, SM-1A and PM-2A core support structures and control rod tubes was measured in single element flow testing. The experimentally determined flow maldistribution would be applied in thermal analysis of Type 3 elements. Plots of channel-to-channel flow distribution and element pressure drop at various element flow rates are given. Flow distribution for the top-orificed SM-1A and PM-2A stationary elements was within the  $\pm 12\%$  deviation from element average utilized in previous thermal analyses of these cores. Testing of the bottom-orificed SM-1 stationary element and the SM-1, SM-1A and PM-2A control rod assemblies showed flow distribution exceeded  $\pm 12\%$  deviation from average. Simple modifications to the SM-1 stationary element indicated the possibility of improving flow distribution in that element.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT -----	vii
1.0 SUMMARY -----	1-1
2.0 INTRODUCTION -----	2-1
3.0 CALIBRATION TESTING OF CONTROL ROD AND STATIONARY FUEL ELEMENT -----	3-1
3.1 Purpose of Tests -----	3-1
3.2 Description of Test Rig and Instrumentation -----	3-1
3.3 Test Procedure -----	3-1
3.4 Test Results -----	3-5
3.4.1 Stationary Fuel Element -----	3-5
3.4.2 Control Rod Fuel Element -----	3-17
3.4.3 Effect of Reynolds Number on $V_{ave}/V_{max}$ -----	3-17
4.0 STATIONARY FUEL ELEMENT FLOW TESTING -----	4-1
4.1 Purpose of Tests -----	4-1
4.2 Description of Test Rig -----	4-1
4.2.1 Description of Instrumentation -----	4-1
4.3 Description of Test Specimen -----	4-1
4.4 Test Procedure -----	4-9
4.5 Data Reduction -----	4-19
4.6 Sources of Error -----	4-19
4.7 Test Results -----	4-19
4.7.1 SM-1 Stationary Fuel Element Flow Tests -----	4-19
4.7.1.1 Test with Maximum Orifice -----	4-20
4.7.1.2 Test with Minimum Orifice -----	4-20
4.7.1.3 Test with Minimum Orifice and Conical Diffuser (Proof of Principle) -----	4-20

## TABLE OF CONTENTS (CONT'D)

	<u>Page</u>
4. 7. 1. 4 Test with Minimum Orifice and Perforated Plate (Proof of Principle) - - - - -	4-27
4. 7. 1. 5 Pressure Drop Test - - - - -	4-27
4. 7. 2 SM-1A Stationary Fuel Element Flow Tests - - - - -	4-35
4. 7. 2. 1 Test with Minimum Orifice - - - - -	4-35
4. 7. 2. 2 Test with Locating Pin Removed - - - - -	4-42
4. 7. 2. 3 Pressure Drop Test - - - - -	4-42
4. 7. 3 PM-2A Stationary Fuel Element Flow Test - - - - -	4-42
4. 7. 3. 1 Pressure Drop Test - - - - -	4-42
4. 8 Checks of Measurements - - - - -	4-49
5. 0 CONTROL ROD ASSEMBLY TESTING - - - - -	5-1
5. 1 Purpose of Tests - - - - -	5-1
5. 2 Description of Test Rig and Instrumentation - - - - -	5-1
5. 3 Description of Test Specimen - - - - -	5-1
5. 4 Test Procedures - - - - -	5-11
5. 5 Data Reduction - - - - -	5-11
5. 6 Test Results - - - - -	5-11
5. 6. 1 SM-1 Control Rod Assembly Test - - - - -	5-11
5. 6. 2 SM-1A and PM-2A Control Rod Assembly Test - - - - -	5-14
5. 7 Checks of Measurements - - - - -	5-14
6. 0 CONCLUSIONS - - - - -	6-1
6. 1 Stationary Fuel Element Flow Distribution - - - - -	6-1
6. 1. 1 SM-1 Stationary Element - - - - -	6-1
6. 1. 2 SM-1A Stationary Element - - - - -	6-1
6. 1. 3 PM-2A Stationary Element - - - - -	6-1
6. 2 Control Rod Assembly Flow Distribution - - - - -	6-2
6. 2. 1 SM-1 Control Rod Assembly - - - - -	6-2
6. 2. 2 SM-1A and PM-2A Control Rod Assembly - - - - -	6-2
7. 0 RECOMMENDATIONS - - - - -	7-1
8. 0 BIBLIOGRAPHY - - - - -	8-1

## LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3-1	Photograph of Calibration Test Rig (Photo)	3-3
3-2	$\Delta h$ -standard Meter Tube Vs. $\Delta h$ Velocity Head	3-9
3-3	Velocity (FPS) Vs. $\Delta h$ Velocity Head	3-10
3-4	$\Delta h$ -inches Blue Fluid Vs. $\Delta h$ -inches H <sub>2</sub> O	3-11
3-5	Maximum Channel Velocity Vs. Average Channel Velocity - Stationary Fuel Element	3-15
3-6	Maximum Channel Velocity Vs. Average Channel Velocity - Control Rod Fuel Element	3-19
3-7	$V_{avg}/V_{max}$ Vs. Reynolds Number	3-20
4-1	Drawing B9-50-1282 - Stationary Fuel Element Test Section	4-3
4-2	Photograph of Stationary Fuel Element Test Loop	4-4
4-3	Photograph of Exploded View of Stationary Element and Internals of Test Section	4-5
4-4	Photograph of Assembled View of Stationary Fuel Element	4-6
4-5	Photograph of Manometer Board	4-7
4-6	Drawing C9-50-2498 - Instrument Penetration Ring	4-8
4-7	Drawing R9-50-1268 - Instrumented Dummy Stationary Fuel Element	4-11
4-8	Drawing C9-50-2487 - Fuel Element End Box - Outlet (PM-2A)	4-13
4-9	Drawing C9-50-2486 - Fuel Element End Box - Outlet (SM-1, SM-1A)	4-15
4-10	Drawing C9-13-2197 - Fuel Element End Box - Inlet	4-17
4-11	SM-1 Core Flow Distribution and Orifice Size	4-21
4-12	Flow Distribution SM-1 with 2.02 in. Orifice	4-22



## LIST OF FIGURES (CONT'D)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
4-13	Flow Distribution - SM-1 with 1.19 in. Orifice	4-23
4-14	Location of Conical Diffuser within Inlet End Box	4-24
4-15	Flow Distribution - SM-1 with 1.19 in. Orifice and Conical Diffuser Located at Inlet	4-29
4-16	Perforated Plate for Element Modification	4-30
4-17	Flow Distribution - SM-1 with 1.19 in. Orifice and Perforated Plate Located in Inlet End Box	4-31
4-18	SM-1 Stationary Fuel Element Pressure Drop Vs. Flow Rate	4-37
4-19	SM-1 Stationary Fuel Element Pressure Drop Vs. Flow Rate	4-38
4-20	SM-1A Core Flow Distribution and Orifice Size	4-39
4-21	Flow Distribution - SM-1A with 1.68 in. Orifice at Exit	4-40
4-22	Flow Distribution - SM-1A with 1.68 in. Orifice at Exit and Locating Pin Removed	4-43
4-23	PM-2A Core Flow Distribution	4-47
4-24	Flow Distribution - PM-2A with 1.83 in. Orifice at Exit	4-48
4-25	PM-2A Stationary Fuel Element Pressure Drop Vs. Flow Rate	4-53
5-1	Drawing C9-50-1279 - Control Rod Assembly Test Section	5-3
5-2	Photograph of Control Rod Assembly Test Section	5-5
5-3	Drawing D9-50-1269 - Instrumented Dummy Control Rod Fuel Element	5-7
5-4	Photograph of Control Rod Assembly and Test Section - Exploded View	5-9
5-5	Photograph of Control Rod Assembly - Assembled View	5-10
5-6	Flow Distribution - SM-1 Control Rod Assembly	5-15
5-7	Distribution - SM-1A and PM-2A Control Rod Assemblies	5-16

## LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3-1	Stationary Fuel Element Measurements	3-7
3-2	Control Rod Fuel Element Measurements	3-8
3-3	Results of Stationary Element Calibration Test	3-13
3-4	Results of Control Rod Fuel Element Calibration Test	3-18
4-1	SM-1 Stationary Fuel Element Flow Distribution 2.02 in. Orifice at Inlet	4-25
4-2	SM-1 Stationary Fuel Element Flow Distribution 1.19 in. Orifice at Inlet	4-26
4-3	SM-1 Stationary Fuel Element Flow Distribution 1.19 in. Orifice at Inlet with Conical Diffuser	4-33
4-4	SM-1 Stationary Fuel Element Flow Distribution 1.19 in. Orifice with Perforated Plate at Inlet	4-34
4-5	SM-1 Stationary Fuel Element Pressure Drop	4-35
4-6	SM-1A Stationary Fuel Element Flow Distribution 1.68 in. Orifice at Exit	4-41
4-7	SM-1A Stationary Fuel Element Flow Distribution 1.68 in. Orifice at Exit - Locating Pin Removed	4-45
4-8	SM-1A Stationary Fuel Element Pressure Drop	4-49
4-9	PM-2A Stationary Fuel Element Flow Distribution	4-50
4-10	PM-2A Stationary Fuel Element Pressure Drop	4-51
5-1	SM-1 Control Rod Assembly Flow Distribution	5-12
5-2	SM-1A and PM-2A Control Rod Assembly Flow Distribution	5-13

## 1.0 SUMMARY

Channel-to-channel flow distribution studies were conducted on the stationary fuel element and control rod assembly of the SM-1, SM-1A and PM-2A, utilizing Type 3 (SM-2) fuel elements in both cases. These studies were carried out as part of Task 3.0 - Replacement Core Development, of the AEC-Army PWR Support and Development Program. (1) The test objective was to determine flow maldistribution to be used in calculating a maldistribution factor (deviation from average channel velocity) for use in thermal analysis of the Type 3 replacement cores for the SM-1, SM-1A and PM-2A. This thermal analysis will be presented in APAE No. 105. (2) Previous thermal analyses were conducted using a  $\pm 12\%$  maldistribution factor for both the stationary and control rod elements.

Test results indicate that:

1. Flow distribution in the SM-1 stationary fuel element with minimum orifice ranges from +44% to -55% of average channel velocity at design flow rate; flow distribution in the maximum orificed element ranges from +6.8% to -8.8% of average channel velocity at design flow rate.
2. Flow distribution in the SM-1A stationary fuel element with minimum orifice ranges from +6.1% to -6.7% average channel velocity at design flow rate.
3. Flow distribution in the PM-2A stationary fuel element with minimum orifice ranges from +6.2% to -11% of average channel velocity at design flow rate.
4. Flow distribution in the SM-1 control rod assembly ranges from +23.5% to -27.8% of average channel velocity at design flow rate.
5. Flow distribution on the SM-1A control rod assembly ranges from +14% to -23% (both extrapolated) of average channel velocity at design flow rate.
6. Flow distribution in the PM-2A control rod assembly ranges from +13.2% to -22.8% of average channel velocity at design flow rate.

Some modification to the minimum orificed SM-1 stationary element should be made if flow maldistribution in these elements is a problem. Testing has shown that improvements in flow distribution can be made with simple modifications to the element.

## 2.0 INTRODUCTION

### 2.1 BACKGROUND

As part of Task 3.0, Replacement Core Development, of the AEC-Army PWR Support and Development Program, <sup>(1)</sup> a single element flow test program was performed in the Alco General Engineering Laboratory to investigate channel-to-channel flow distribution within Type 3 stationary and control rod fuel elements modified for use in the SM-1, SM-1A and PM-2A cores. Data obtained from this program will provide information for calculation of a maldistribution factor to be used in calculating hot channel factors and burnout ratios as well as providing important information on the present cores now in SM-1, SM-1A and PM-2A.

The Type 3 fuel element differs from Types 1 and 2 fuel elements used in the original cores of SM-1, SM-1A and PM-2A in that the Type 3 fuel plates are 40-mils thick compared to 30 mils in the original cores, resulting in a 10-mil reduction in channel width from 133 to 123 mils. The increased plate thickness as well as the increased fuel concentration in the plate matrix results in a significant increase in total fuel inventory, thereby increasing the prospective core life.

### 2.2 DESCRIPTION OF REACTORS

The SM-1, SM-1A and PM-2A are pressurized water reactors having APPR type cores with design power outputs of 10, 20 and 10 tMW respectively. Operating conditions for the SM-1 are 1200 psi and 427°F reactor inlet temperature; for the SM-1A, 1200 psi and 423°F inlet temperature; and for the PM-2A, 1750 psi and 500°F reactor inlet temperature. The core array for each reactor is a basic 7 x 7 array with the four corner elements removed in both the SM-1 and SM-1A, and three elements removed from each corner of the PM-2A.

The SM-1 is a bottom orificed core with 38 stationary fuel elements and 7 control rod fuel elements. The SM-1A and PM-2A are both top orificed cores with the SM-1A having 38 stationary and 7 control rod fuel elements and the PM-2A having 32 stationary and 5 control rod fuel elements.

### 2.3 APPROACH

Stationary element testing utilized a single fuel element with removable end boxes, and various orifice plates for each different core. In each case the minimum orificed element of each core was selected for testing because this orifice has the greatest adverse effect upon flow distribution. Thus, the results of this report present the most adverse conditions of flow distribution within each core. Control rod testing utilized a Type 3 control rod fuel element within the SM-1, SM-1A and PM-2A control rod tubes.

The test loop used for both stationary and control rod testing was capable of delivering flow in excess of design for each respective test. In all cases, the test fluid was water, maintained within a temperature range of 70-80°F.

Similar single element flow studies performed on ETR(3), the MTR(4), and the SM-2(5) show results comparable to those achieved in this test program.



### 3.0 CALIBRATION TESTING OF CONTROL ROD AND STATIONARY FUEL ELEMENTS

#### 3.1 PURPOSE OF TEST

Since the measured velocity readings taken at the centerline of the fuel element channels are peak or maximum velocity values and average velocity readings are required for analysis, it was necessary to establish an average-to-maximum velocity ratio. The purpose of this test was to experimentally determine this ratio for each channel and obtain an overall ratio for the entire element which could be applied to data received from full fuel element flow testing.

#### 3.2 DESCRIPTION OF TEST RIG AND INSTRUMENTATION

The test rig utilized in calibration testing consisted of two large plenum chambers, a tube which held the fuel element, a surge tank to minimize flow surges, and a standard meter tube. The meter tube consisted of a standard orifice installation. City water entered the surge tank and from there passed through the standard meter tube which was connected to a special channel adapter which channeled all flow (leakage kept to minimum) through an individual channel. Flow control was provided by a valve located before the calibrated flow tube. The test rig is shown in Fig. 3-1.

For this test the instrumentation consisted of both static and total probes located in each channel of the element. Probes were fabricated from 0.065 in. stainless steel tubing and located at channel center by an instrument rake. Each pair of static and total probes measured a maximum channel velocity. An average channel flow rate was measured by a calibrated standard meter tube. All measurements were recorded on U-tube manometers using Meriam blue fluid (sp. gr. 1.75) as the indicating fluid.

#### 3.3 TEST PROCEDURE

During early attempts to calibrate each individual channel, readings were inconsistent, which indicated that instrument lines were not bled properly. A pressurized system was devised which allowed fast and positive bleeding of the instrument lines.

For each individual channel calibration, the following procedure was followed. The loop was filled and pressurized to approximately 30 psi. The loop pressure was maintained by a valve controlling flow from the outlet plenum chamber. Upon filling the loop, the manometers and lines were bled of all air and zeroed.

At various flow rates, as recorded by the meter tube, maximum channel velocity readings were recorded. Average readout time (time for readout instrument to stabilize) was from 12 to 15 minutes per flow setting. The range of channel flow

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK




Fig. 3-1 - Calibration Test Rig

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

was between 2 and 10 gpm, with readings being taken at three different flow rates going up in flow and essentially the same flow rates going down in flow. This was done to insure the repeatability of the instrumentation. All measurements were recorded on 24-in. manometers and were read within  $\pm 0.1$  inches of Meriam blue fluid (sp. gr. 1.75).

### 3.4 TEST RESULTS

A complete set of channel dimensions were taken prior to testing. Channel measurements, taken at the point of velocity measurement, enabled calculations of average channel velocity to be made from the established relationship of  $Q = AV$ , where:

$Q$  = flow rate ( $\text{ft}^3/\text{sec}$ ) as measured by the calibrated flow tube  
 $A$  = calculated flow cross-section area ( $\text{ft}^2$ )  
 $V$  = is average channel velocity (fps).

At the point of measurement, three channel measurements were made; one at the top of the channel (bordering side plate), one at the center, and one at the bottom of the channel (bordering side plate). These three measurements together with a measurement made across the side plates enabled an accurate calculation of channel area to be made by a trapezoidal approximation. The complete set of measurements taken on the stationary and control rod fuel elements is tabulated in Tables 3-1 and 3-2 respectively. Calculated channel areas are presented in Table 3-3 and Table 3-4.

For each individual channel of the fuel element, a plot of  $\Delta h$  across the standard meter tube vs.  $\Delta h$  channel velocity head was made from data recorded during the test. A typical plot of the best straight line fit of recorded data is shown in Fig. 3-2. Conversion of  $\Delta h$ -vel. head inches blue fluid into velocity (fps) was facilitated by the graph shown in Fig. 3-3. This is a plot of  $V = \sqrt{2gh}$ , with a factor for conversion of  $\Delta h$  from inches of blue fluid (sp. gr. 1.75) under water to feet of water. Another plot shown in Fig. 3-4, enabled the conversion of  $\Delta h$ -inches blue fluid across the meter tube, into inches of water which was then converted into flow rate by referring to a plot of flow rate (gpm) vs. differential (in. water) for the standard orifice installation. The data mentioned above was utilized in obtaining a correlation between average and maximum velocity for both the stationary and control rod fuel elements.


#### 3.4.1 Stationary Fuel Element Test Calibration

Results of testing at three flow rates are tabulated in Table 3-3. These results apply to all three stationary element assemblies (SM-1, SM-1A and PM-2A). From this data a plot of average channel velocity vs. maximum channel velocity was made. This plot shown in Fig. 3-5, represents the best straight line fit of data obtained from the calibration of the 17 individual channels and is utilized in obtaining average channel velocity from the measured maximum channel velocity recorded during the flow testing of the entire element (Section 4.0).



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

**TABLE 3-1**  
**CHANNEL MEASUREMENTS FOR**  
**STATIONARY FUEL ELEMENT**




	Channel Letter																
	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q
1)	121	119	114	125	118	124	129	124	121	116	129	123	114	120	121	119	130
2)	122	116	116	125	119	124	130	123	121	116	128	123	115	120	120	119	130
3)*	122	122	119	124	122	125	124	124	122	123	124	123	124	122	122	121	122
	123	118	114	125	118	124	129	123	120	116	129	123	114	121	118	120	129
	122	121	123	122	124	124	123	125	124	125	122	125	121	122	119	121	124
4)	123	116	115	125	118	123	129	122	121	115	129	123	115	121	119	120	129
5)	123	117	116	124	119	124	129	122	122	115	129	123	115	121	119	120	129
6)*	123	121	120	124	123	125	124	124	122	123	124	123	124	122	122	120	122
	122	117	116	124	119	125	130	121	122	116	129	123	115	121	119	121	128
	122	121	124	122	123	125	123	124	124	125	122	125	121	122	119	121	124
7)	121	117	115	125	118	125	129	123	122	115	129	123	116	120	120	119	130
8)	122	118	115	125	118	124	130	123	121	116	129	123	115	121	119	120	129
9)	122	118	115	125	119	124	130	123	121	116	129	123	115	121	119	119	129
10)*	123	122	122	123	124	125	124	124	123	123	124	124	123	123	123	122	125
	122	118	115	125	118	123	131	122	121	116	130	122	115	121	120	118	130
	124	122	123	122	123	124	124	125	123	123	124	123	123	122	122	119	125
11)	122	117	115	125	118	124	131	122	122	115	131	122	115	121	120	119	130
12)	122	118	115	124	118	124	131	123	122	115	131	122	114	121	119	120	128
13)	122	118	115	124	118	124	131	123	122	114	131	122	115	120	119	121	128
14)*	124	123	122	123	123	125	123	125	123	123	123	124	123	123	123	122	125
	123	118	115	124	118	124	131	123	122	114	131	122	115	121	119	120	129
	126	124	124	122	122	124	123	125	124	123	124	123	123	122	122	118	125
15)	123	118	114	124	119	123	130	123	122	115	130	122	115	121	119	120	128
16)	122	119	114	125	118	123	130	123	122	115	130	122	115	120	120	118	129
17)	122	118	115	125	118	123	130	124	122	115	130	121	115	121	119	118	129
18)*	122	122	119	124	122	125	124	124	123	122	124	122	124	122	122	120	122
	122	118	114	125	117	123	129	124	121	115	130	122	115	121	119	118	129
	123	121	122	121	123	124	123	124	124	123	123	124	121	122	120	120	124
19)	121	117	114	124	118	123	129	124	122	114	130	122	115	120	119	117	131
20)	122	118	113	125	117	124	129	124	122	114	130	122	115	120	119	117	131
21)	121	119	113	125	117	123	130	125	121	115	131	122	114	120	120	117	130
22)*	124	121	122	123	124	125	124	125	123	124	125	124	123	123	121	124	123
	120	118	115	125	117	124	128	125	122	116	131	122	115	122	120	120	129
	124	121	124	122	122	125	124	126	124	123	124	124	123	121	122	121	126

NOTE: 1st measurement 1-1/4" from inlet end of fuel plate. All others at 1" increments; measurement given in mils.

\* All three positions - Top, center and bottom; all other measurements made at center.

**TABLE 3-2**  
**CHANNEL MEASUREMENTS FOR**  
**CONTROL ROD FUEL ELEMENT**



Channel Letter

	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
1)*	123	122	122	122	123	122	123	122	125	123	122	121	123	124	122
	121	122	125	118	126	119	124	125	120	125	123	124	122	124	127
	123	124	121	122	122	122	123	123	123	123	123	125	125	133	124
2)	118	122	124	117	126	118	123	124	120	125	122	121	117	122	124
3)	121	119	126	117	125	119	123	124	120	125	122	122	116	122	124
4)	121	118	126	117	125	119	123	122	120	126	121	121	116	121	124
5)*	122	121	122	120	122	121	121	120	122	122	120	121	120	121	120
	121	118	126	116	125	119	123	122	120	126	121	121	117	122	124
	120	120	120	120	122	119	122	122	120	123	120	121	122	120	121
6)	120	119	125	118	124	119	124	122	120	125	121	122	117	121	124
7)	121	118	126	118	124	120	123	122	121	125	121	121	117	123	124
8)	121	119	126	118	125	119	123	123	120	125	121	121	117	123	124
9)*	122	119	122	119	120	121	122	120	122	121	121	119	119	120	117
	121	119	127	117	125	119	123	123	121	125	121	121	117	123	124
	119	119	120	119	123	120	124	121	122	123	119	120	123	119	121
10)	122	118	127	118	125	119	123	124	119	125	121	121	117	123	124
11)	122	119	125	118	125	119	123	125	120	125	121	121	117	123	124
12)	121	119	125	119	125	119	124	124	120	125	122	120	118	122	125
13)*	120	120	121	121	121	121	121	121	121	122	120	120	119	122	119
	122	119	125	119	124	120	124	124	120	125	121	120	118	123	124
	121	121	120	120	122	120	123	122	121	122	121	121	121	121	121
14)	122	119	125	118	124	121	123	124	120	125	121	121	118	123	124
15)	122	119	125	119	124	120	124	124	121	124	121	120	119	121	125
16)	122	119	125	118	125	121	123	123	121	125	121	120	119	121	125
17)*	122	121	120	121	121	121	121	120	122	122	120	121	120	122	120
	122	119	125	119	124	120	124	123	121	125	121	120	119	122	124
	121	121	120	120	122	120	123	122	122	122	121	121	121	121	121
18)	122	120	125	119	124	120	125	124	121	125	121	121	119	121	125
19)	122	120	125	118	124	119	124	123	121	125	122	120	119	121	124
20)*	122	121	121	121	121	121	121	121	122	123	120	120	120	122	120
	122	120	126	119	124	119	125	123	121	125	121	121	117	122	125
	121	120	120	120	122	120	123	122	122	122	122	121	121	121	121
21)	122	119	126	118	124	119	125	123	121	124	122	119	120	122	125
22)	121	120	125	118	125	119	124	124	121	126	122	119	119	121	127
23)	120	123	125	121	125	121	124	124	121	126	123	121	120	122	125

NOTE: 1st measurement 1/2" from inlet end of fuel plate, remainder at 1" increments from 1st measurement, all measurements in mils.




Fig. 3-2 - Channel K Calibration  $\Delta h$  Standard Meter Tube Vs  $\Delta h$  Vel. Head




Fig. 3-3 - Velocity Vs. Velocity Head Measured Fluid - Water 80°F




Fig. 3-4 - h-Inches of Water Vs h-Inches of Blue Fluid

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

**TABLE 3-3**  
**RESULTS OF STATIONARY FUEL ELEMENT CALIBRATION TEST**

	Area (Calculated)	Q = 3 gpm			Q = 5.5 gpm			Q = 8 gpm		
Channel	Ft <sup>2</sup> x 10 <sup>-3</sup>	$\bar{V}$	V <sub>max</sub>	$\bar{V}/V_{max}$	$\bar{V}$	V <sub>max</sub>	$\bar{V}/V_{max}$	$\bar{V}$	V <sub>max</sub>	$\bar{V}/V_{max}$
A	2.366	2.83	3.60	.786	5.18	6.18	.838	7.53	8.70	.866
B	2.317	2.88	3.56	.809	5.29	6.08	.870	7.69	8.60	.894
C	2.307	2.90	3.64	.797	5.31	6.28	.846	7.73	8.90	.869
D	2.399	2.79	3.48	.802	5.11	6.12	.835	7.43	8.75	.849
E	2.327	2.87	3.75	.765	5.27	6.45	.817	7.66	9.10	.842
F	2.414	2.77	3.60	.769	5.08	6.31	.805	7.38	9.00	.820
G	2.443	2.74	3.61	.759	5.02	6.25	.803	7.30	8.80	.830
H	2.428	2.75	3.48	.790	5.05	6.12	.825	7.34	8.79	.835
I	2.380	2.81	3.52	.798	5.15	6.22	.828	7.49	8.98	.834
J	2.322	2.88	3.49	.825	5.28	6.15	.859	7.68	8.70	.882
K	2.477	2.70	3.27	.826	4.95	5.68	.871	7.20	8.09	.890
L	2.385	2.80	3.42	.819	5.14	6.05	.850	7.47	8.62	.867
M	2.307	2.90	3.52	.824	5.31	6.21	.855	7.73	8.90	.869
N	2.365	2.83	3.50	.809	5.18	6.00	.863	7.54	8.40	.898
O	2.341	2.86	3.27	.875	5.23	5.60	.934	7.61	7.75	.982
P	2.351	2.84	3.45	.823	5.21	5.88	.886	7.58	8.22	.922
Q	2.457	2.72	3.29	.827	4.99	5.65	.883	7.25	8.00	.906
Total Flow Area	40.386									
Avg. Flow Area	2.376	2.82	3.50	.806	5.16	6.07	.851	7.51	8.61	.873

NOTE: All velocities in fps.



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK




Fig. 3-5 -  $V_{\max}$  Vs  $V_{ave}$  Results of Stationary Element Calibration

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

### 3.4.2 Control Rod Fuel Element Calibration

A tabulation of results from calibration of the instrumented control rod fuel element is given in Table 3-4. A plot of average velocity vs. maximum velocity, representing the average of a family of curves is shown in Fig. 3-6. This curve was used to obtain average channel velocity in the flow test of the control rod assembly. The lattice passages, i. e., those formed by the outer fuel plate and control rod tube, were not calibrated but the average channel velocity for these channels was arrived at by using the above mentioned curve (Fig. 3-6).

### 3.4.3 Effect of Reynolds Number on $\bar{V}/V_{\max}$

From data obtained in the two preceding sections an interesting correlation between  $\bar{V}/V_{\max}$  and Reynolds number was developed. For each channel of the stationary element, the ratio of  $\bar{V}$  (average velocity) to  $V_{\max}$  was obtained at different channel flow rates. The same ratio was developed from control rod data. At the different flow rates, Reynolds number was computed by using average channel velocity and average channel dimensions. A plot showing the relationship between  $V_{\text{avg}}/V_{\max}$  vs. Reynolds number is given in Fig. 3-7.

TABLE 3-4  
RESULTS OF CONTROL ROD CALIBRATION TEST

	Calculated Area	Q = 3.25 gpm			Q = 5.35 gpm			Q = 8.74 gpm		
Channel	$Ft^2 \times 10^{-3}$	$\bar{V}$ -FPS	$V_{max}$ -FPS	$\bar{V}/V_{max}$	$\bar{V}$ -FPS	$V_{max}$ -FPS	$\bar{V}/V_{max}$	$\bar{V}$ -FPS	$V_{max}$ -FPS	$\bar{V}/V_{max}$
B	2.160	3.35	4.05	.827	5.52	6.56	.841	9.02	10.40	.867
C	2.173	3.33	4.10	.812	5.49	6.53	.841	8.96	10.20	.878
D	2.187	3.31	4.02	.823	5.45	6.50	.838	8.90	10.25	.868
E	2.130	3.40	4.12	.825	5.60	6.60	.848	9.14	10.35	.883
F	2.206	3.28	3.93	.835	5.40	6.36	.849	8.83	10.10	.874
G	2.142	3.38	4.07	.830	5.56	6.53	.851	9.09	10.22	.889
H	2.196	3.30	4.09	.807	5.43	6.50	.835	8.87	10.12	.876
I	2.201	3.29	3.95	.833	5.42	6.40	.847	8.85	10.15	.872
J	2.169	3.34	4.18	.799	5.50	6.65	.827	8.98	10.35	.868
K	2.201	3.29	3.92	.839	5.42	6.31	.859	8.85	9.91	.893
L	2.177	3.33	4.05	.822	5.48	6.40	.856	8.94	9.95	.898
M	2.189	3.31	4.05	.817	5.45	6.50	.838	8.90	10.18	.874
N	2.179	3.32	4.05	.820	5.47	6.56	.834	8.94	10.40	.860
O	2.192	3.30	4.06	.813	5.44	6.50	.837	8.88	10.15	.875
P	2.212	3.27	4.07	.803	5.39	6.53	.825	8.80	10.20	.863
Total	32.714									
Avg.	2.181	3.32	4.05	.820	5.47	6.50	.842	8.93	10.20	.876




Fig. 3-6 -  $V_{\max}$  Vs  $V_{\text{ave}}$  Results of Control Rod Fuel Element Calibration




Fig. 3-7 -  $\bar{V}/V_{\max}$  Vs  $N_{Re}$

## 4.0 STATIONARY FUEL ELEMENT FLOW TESTING

### 4.1 PURPOSE OF TEST

The purpose of these tests was to measure channel-to-channel flow distribution within a Type 3 (SM-2) stationary fuel element modified to fit SM-1, SM-1A and PM-2A cores. Overall pressure drop across the stationary element was also required.

### 4.2 DESCRIPTION OF TEST RIG AND INSTRUMENTATION

This rig consists of an entrance and exit plenum chamber, two flanged 5-in. tube sections, element supports and a flow adjuster assembly. The test section, shown in Fig. 4-1, was inserted into a flow loop which has a pump with capacity of 1500 gpm against a hydrostatic head of 196 ft. The assembled loop is shown in Fig. 4-2. An exploded view of the test element and various internals of the test section are shown in Fig. 4-3. The angles and bands around the element were used to prevent any outer plate buckling due to a pressure differential caused by flow in the outer channels of the element. These were not an integral part of the element. An assembled view of the same components is shown in Fig. 4-4.

The loop also has a heat exchanger capable of maintaining an almost constant loop temperature within a range of 70-80°F. Loop pressure was maintained at approximately 20 psi for all phases of testing.

#### 4.2.1 Instrumentation


To measure velocity head in each of the 17 channels, a bank of U-tube manometers was assembled. (See Fig. 4-5). The bank consisted of 18 manometers with Meriam blue fluid (sp. gr. 1.75) used as the indicating fluid. Velocity signals ( $P_{\text{total}} - P_{\text{static}}$ ) were transmitted from 0.065 in OD static and total probes located at channel exit through a penetrated ring (See Fig. 4-6), and over to the manometers by 1/8 in. OD copper tubing. Each tube of the manometer had a shutoff valve and air bleed valve.

Loop flow was measured by a standard orifice installation, with the signal from the orifice being transmitted to a mercury manometer for accurate measurement.

### 4.3 DESCRIPTION OF TEST SPECIMEN

The test element for this program was a standard Type 3 (SM-2) fully welded element fabricated by the Alco Welding Laboratory. The same basic element was utilized in testing of the SM-1, SM-1A and PM-2A; the only difference in the three





NOTE: "SK" NUMBERS  
REFER TO MECH. LAB. DRAWING NOS.

PART NO.  
**B9-50-1282**

BREAK SHARP EDGES  
REMOVE ALL BURRS

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES.  
TOLERANCES ON FINISHED  
FRACTIONAL DIMENSIONS  
TO BE  $\pm$

✓ FINISH AS INDICATED  
IN MICROINCHES.

f<sub>1</sub> MACHINE FINISH - ROUGH

f<sub>10</sub> FLAME CUT OR SAW

DATE	LET.	REVISION RECORD	AUTH.	DR.	CHK.

7	1	C9-50-1086	FLOW ADJUSTER
6	1	SK-1272	ORIFICE PLATE
5	1	SK-1269	ELEMENT SUPPT-INLET
4	1	SK-1262	TUBE SECTION ASSY
3	1	SK-1070	PLENUM CHAMBER-CENTER
2	1	SK-1266	ELEMENT SUPPT-OUTLET
1	1	SK-1271	ORIFICE PLATE
Pc No	QUAN.	DWG NO. OR MATERIAL	DESCRIPTION

**ALCO**

**ALCO PRODUCTS, INC.**  
NUCLEAR POWER ENGINEERING DEPT.  
SCHENECTADY, N. Y., U. S. A.

SCALE 1/4" = 1"	REF.	DR.	B. PARKER	9-29-61
MATERIAL SPEC.		TR.		
		CHK.	Dochow	9-29-61
		APPR.	R. House	9-29-61
		APPR.		
		MET.	Aluminum	1/2" x 1/2"

NAME **STATIONARY ELEMENT  
TEST SECTION ASSEMBLY**

PART NO.  
**B9-50-1282**






Fig. 4-2 - Stationary Fuel Element Test Section






Fig. 4-3 - Exploded View of Statationary Element and Internals of Test Section 1, 2, 3, 4, 5, 6, 7, 8, 9, 10 and 11






Fig. 4-4 - Assembled View of Stationary Fuel Element with Element Holder and Orifice Plate







Fig. 4-5 - Single Element Flow Test - Manometer Board





NOTE:  
COAT WITH RUST PREVENTIVE

DATE	LET.	REVISION RECORD	AUTH.	DR.	CHK.

PART NO.  
**C9-50-2498**

<b>ALCO</b>		<b>ALCO PRODUCTS, INC.</b>	
NUCLEAR POWER ENGINEERING DEPT.		SCHENECTADY, N. Y., U. S. A.	
SCALE $3/4" = 1"$	REF. C9-50-2360	DR. A. K. R. 3-28-61	
MATERIAL SPEC.		TR.	
CARBON STEEL		CHK. Docher 4-4-61	
ASTM A-283-B		APPR. P. K. R. 4-4-61	
ALCO SPEC 54140 or 54170		APPR. W. J. R. 4-4-61	
OR SIMILAR		MET. J. J. R. 4-4-61	
NAME		NAME	
PENETRATION RING		PENETRATION RING	
PART NO.		PART NO.	
C9-50-2498		C9-50-2498	

BREAK SHARP EDGES  
REMOVE ALL BURRS

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES.  
TOLERANCES ON FINISHED  
FRACTIONAL DIMENSIONS  
TO BE  $\pm 1/32$

- ✓ FINISH AS INDICATED IN MICROINCHES.
- (f1) MACHINE FINISH - ROUGH
- (f10) FLAME CUT OR SAW

elements being the outlet end box, which was mechanically fastened for test purposes only. The element assembly is shown in Fig. 4-7. The element was fabricated to Type 3 specifications with all but three channels falling within the required channel width of 0.123 in.  $\pm$  0.005 in. Complete channel measurements are given in Table 3-1. The test element drawing exactly duplicated the production drawings made for Task 3.3 of the PWR Support Program. The instrument rake was not permanently fastened to the element; it was held in place by the exit end box which was mechanically fastened to the element. The end boxes used were production units previously utilized in testing of the SM-1, SM-1A, and PM-2A cores. They were mechanically fastened to the element so the same fuel element bundle could be utilized in SM-1, SM-1A and PM-2A stationary fuel element flow testing.

Since reactor lattice passage dimensions could not be accurately simulated in this test, no attempt was made to mock-up the lattices and to measure lattice velocity. All loop flow was passed through the element (bypass leakage if any, was negligible).

#### 4.4 TEST PROCEDURE




Before each test was begun, all manometers were checked to see that all air was removed from the instrument lines. This was done by checking each manometer to see that it zeroed out properly at the no-flow condition. Any manometer which did not zero-out properly was re-bled. All bleeding was done at low system pressure which facilitated the operation.

After all manometers were balanced (zeroed), the loop pressure was increased to the operating level of approximately 20 psi; no-flow readings were again recorded to make certain each manometer remained zero.

Upon recording the no-flow readings, the pump was started and loop flow throttled to the first test flow rate of 50 gpm. Loop flow was indicated on a manometer. After all manometers had stabilized (approximately 12-15 minutes), velocity readings were taken by recording each column height of the U-tube manometer. After all manometers were read, loop flow was again increased to the next nominal flow rate of 75 gpm. This same procedure was followed in testing at 100 gpm and 125 gpm. These target flow rates were met in testing of all configurations with the exception of the minimum orificed SM-1 stationary element, and the SM-1 control rod assembly which had channel velocities exceeding the range of the manometers.

At each flow rate, the following data was recorded:

1. Total loop flow - gpm
2. Water temperature - °F
3. Velocity pressure - in. blue fluid (sp. gr. 1.75)
4. Overall element pressure drop - in. hg



ASSEMBLY NOTE:-

VELOCITY PROBES TO EXTEND  
1/2" AHEAD OF RAKE  
STATIC PROBES TO EXTEND 1"  
STATIC HOLE  $\phi$  PARALLEL  
TO PLATES. .031" STATIC I.D.  
.065" ANNEALED STN. STL. TUBING  
TO BE USED FOR BOTH VELOCITY  
AND STATIC PROBES.  
PROBES TO BE ASSEMBLED TO  
RAKE BEFORE MAIN ASSEMBLY

DRG. NO.	A	B	C	D	E	F	G	REACTOR	NO. RECD
R3-50-268-1	2	2	2.250 2.246	2	1	33	C9-50-2456	SM, 5M-1A	1
R3-50-268-2	3	3	2.493 2.453	OMIT	OMIT	31	C9-50-2467	PM-2A	1

T.I.G. WELD (NO FILLER) 1/2 - 3.  
 ODD NUMBER PLATES START 1/8 FROM INLET END.  
 EVEN NUMBER PLATES START 1/8 FROM INLET END.  
 ON OPPOSITE SIDE OF FUEL ELEMENT.  
 ODD NUMBER PLATES START 1/8 FROM INLET END.  
 EVEN NUMBER PLATES START 1/8 FROM INLET END.  
 END WELDS ON OUTSIDE PLATE 1/4 FROM  
 END OF PLATE 1/2 LONG.

NOTE: AXIS Y MUST PASS THRU POINTS "D" & "E"  
DIAMETERS MARKED "X" CONCENTRIC WITH AXIS Y WITHIN .002 T.I.R.  
SURFACE Z SQUARE WITH AXIS Y WITHIN .002 T.I.R.



125 ✓ ALL OVER  
EXCEPT AS NOTED.

NOTES:-  
BLEND UNIFORMLY FROM  $\frac{1}{8}$  RADIUS AT POINT "X"  
TO  $\frac{1}{8}$  RADIUS AT POINT "Y" AS SHOWN IN SECTION "A-A"

LOCUS LINE OF CENTERS  
OF BLEND RADII.


THESE SURFACES TO BE  
SMOOTH (EQUIVALENT TO  $\sqrt[125]{T}$ )

SEE NOTE  
SECTION-"A A"

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES.  
TOLERANCES ON FINISHED  
FRACTIONAL DIMENSIONS  
TO BE  $\pm .004$ .



✓	FINISH AS INDICATED IN MICROINCHES.
f <sub>1</sub>	MACHINE FINISH - ROUGH
f <sub>10</sub>	FLAKE CUT OR SAW

SM 2 FUEL ELEMENT  
END BOX  
FOR PM 2A REACTOR.

		<b>ALCO PRODUCTS, INC.</b> NUCLEAR POWER ENGINEERING DEPT. SCHENECTADY, N. Y. U. S. A.	
		SCALE <b>FULL</b>	DR. <b>J. L. Bond</b>
MATERIAL SPEC <b>RS 50-128-2</b>		DATE <b>2/13/61</b>	
STN. STL. CASTING. TYPE 304 OR 316		TR.	
CKK. <b>Dodley</b>		2-27-61	
APPR. <b>Thorne</b>		2-28-61	
APPR. <b>Thorne</b>		2-28-61	
MET. <b>252464</b>		2/28/61	
NAME <b>SINGLE FLEET</b>			
FUEL FLEET <b>100</b>			
(OUTLET) <b>1200-PIPE</b>			

SIM. TO 69-13-2197


DATE	LET.	REVISION RECORD	AUTH.	OR.	CHK.



NOTE:-  
BLEND UNIFORMLY FROM A 1" RADIUS AT  
POINT "X" TO A 1/8" RADIUS AT POINT "Y".

LOCUS LINE OF CENTERS  
OF BLEND RADII

125 ALL OVER  
EXCEPT AS NOTED.



SM 2 FUEL ELEMENT END BOX  
FOR SM 1 & SM 1A REACTORS

PART NO.  
C9-50-2486

BREAK SHARP EDGES  
REMOVE ALL BURRS



UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES  
TOLERANCE IS ON FINISHED  
FRACTIONAL DIMENSIONS  
TO BE ± 1/64

✓ FINISH AS INDICATED  
IN MICROINCHES.  
① MACHINE FINISH - R32/6H  
② FLAME CUT OR SAW


<b>ALCO</b>		ALCO PRODUCTS, INC.	
		NUCLEAR POWER ENGINEERING DEPT.	
		SCHENECTADY, N. Y., U. S. A.	
DESIGN	REV.	DR.	DATE
FULL	R5-50-1268-1	DR.	2/10/61
MATERIAL SPEC.		TR.	
STN. STL. CASTINGS		CHK.	2-22-61
TYPE-304 OR 316		APPR.	2-22-61
		APPR.	2-22-61
		MET.	2-22-61
NAME: SINGLE ELEMENT FLOW TEST TASK-3.4			
FUEL ELEMENT END BOX			
(OUTLET) AE-90-1PE			
PART NO.		C9-50-2486	

DRG NO.	A
C9-13-2197-1	USE
C9-13-2197-2	OMIT

DATE	LET	REVISION RECORD	AUTH.	DR.	CHK.



NOTES:  
 BLEND UNIFORMLY FROM 1/8 RADIUS AT POINT "X"  
 TO 3/8 RADIUS AT POINT "Y" AS SHOWN IN SECTION "A-A"



SM-2 FUEL ELEMENT END BOX  
 FOR SM-1 & SM-1A REACTORS

THESE SURFACES TO BE  
 SMOOTH (EQUIVALENT TO 125)

BREAK SHARP EDGES  
 REMOVE ALL BURRS

UNLESS OTHERWISE SPECIFIED  
 DIMENSIONS ARE IN INCHES  
 TOLERANCES OR FINISHES  
 FRACTIONAL DIMENSIONS  
 TO BE 1/64

✓ FINISH AS INDICATED  
 IN REWORKING  
 (1) MACHINING FINISH  
 (10) FLAME CUT OR SAW

<b>ALCO</b>		<b>ALCO PRODUCTS, INC.</b>	
NUCLEAR POWER ENGINEERING DEPT.		SCHENECTADY, N.Y., U.S.A.	
SCALE	FULL	REVISED	10-15-1965
MATERIAL SPEC.	STAINLESS STL. CASTING	TR.	1-23-61
CHK.	1-23-61	CHK.	1-23-61
APP.	1-23-61	APP.	1-23-61
NAME	FUEL ELEMENT END BOX	NAME	(NLEET)
PART NO.	C9-13-2197	PART NO.	C9-13-2197

At least two comparable runs were made at each different flow rate to insure reliable results.

#### 4.5 DATA REDUCTION

Test data, consisting of readings of two column heights for each manometer, was reduced by calculating the velocity pressure differential represented by these columns and then converting this differential into velocity (maximum) in feet per second. This conversion was facilitated by using the graph shown in Fig. 3-3 which is a plot of  $V = \sqrt{2gh}$ . Once maximum velocity was obtained, average channel velocity was determined by going to a plot of  $V_{avg}$  vs.  $V_{max}$  shown in Fig. 3-6. This plot represents the best straight line fit of data obtained from calibration of the stationary fuel element.

#### 4.6 SOURCES OF ERROR

Although all precautions were taken to minimize error in obtaining data, some possible sources of error that were present are listed:

1. Velocity probe misalignment - Alignment was checked prior to installation and after testing; no change was noted.
2. Leakage in instrument leads - a constant check was made to insure a tight, leak-free instrument system. No external leakage was noted and possible internal leakage could not be checked.
3. Air in instrument lines - the source of error was easily detected since it resulted in very erratic readings. Frequent checks were made to guard against this possible source.

These same sources of error apply to control rod testing.

#### 4.7 TEST RESULTS

With the exception of the SM-1 element with minimum orifice, test results showed flow distribution to be within the  $\pm 12\%$  of element average used in previous analyses. A complete description of each test is presented in the following sections.

##### 4.7.1 SM-1 Stationary Fuel Element Flow Tests

The Type 3 stationary element for SM-1 was tested with two different orifice selections. The first selection was the maximum orifice : 2.02 in. diam (element #54); the second selection being the minimum orifice : 1.19 in. diam (element #12, #21, #27, #61, #67). The tolerance on these orifice diameters was  $\pm 1/64"$ . The orifice location for both these tests was at the element inlet. The core location of the different selections tested is shown in Fig. 4-11.

#### 4. 7. 1. 1 SM-1 Test with Maximum Orifice

Average channel velocity distribution for the maximum orifice (2.02 in.) selection is shown in Fig. 4-12. The graph shows the flow distribution obtained at nominal flow rates of 50, 76, 100, and 125 gpm. The actual flow rate prescribed for this element in the SM-1 core is 106.13 gpm. At the prescribed flow rate maximum deviations of +6.8% and -8.8% were noted in channels D and J respectively. A complete tabulation of this data is given in Table 4-1.

#### 4. 7. 1. 2 SM-1 Test with Minimum Orifice

The results of this test are plotted in Fig. 4-13. Flow distribution was obtained at nominal flow rates of 52, 75 and 87 gpm. Higher flow rates could not be obtained because velocity readings in the center channels exceeded the range of the manometer. The prescribed flow rate for this element in the core ranges between 43.66 and 45.60 gpm. At the nominal test flow rate of 52 gpm, maximum deviations of +44% and -55% of average were recorded in channels G and A respectively. A complete tabulation of the data is given in Table 4-2.


A marked difference can be seen when comparing flow distribution results of the maximum and minimum orifice selections. A completely different flow profile was obtained. This difference in profile can probably be traced to the downstream movement of the vena contracta resulting from the increase in flow velocity past the smaller orifice. The inlet end box of the element did not allow sufficient distance for the flow pattern to recover from the vena contracta before entering the channels; thus flow was starved in the outer channels and over-abundant in the center.

When flow was increased from a nominal flow rate of 52 gpm to a nominal rate of 75 gpm the flow profiles were very nearly identical; but, as element flow was increased further, a transition occurred and the profile changed. It was quite apparent that this increase in flow velocity caused the vena contracta to move farther downstream, thus causing the flow profile to become more peaked in the center channels and more starved in the outer channels.

#### 4. 7. 1. 3 SM-1 Test with Minimum Orifice and Conical Diffuser - "Proof of Principle"

Because of the poor flow distribution obtained in the SM-1 test with minimum orifice, investigation was made to determine the effects upon flow distribution of a flow device capable of being installed in the element entrance. The first attempt, a conical diffuser, 2 inches long with 1/2 in. top diam and 1 in. bottom diam, was fabricated and located as shown in Fig. 4-14. For test purposes only, the diffuser was attached to the orifice plate (attachment could have been made to end box) with the leading edge of the diffuser even with the leading edge of the orifice plate.

	12*	13	14	15	16	
	46.57 1.190	56.27 1.345	59.57 1.380	57.63 1.325	45.60 1.220	
21*	22	23	24	25	26	27*
43.66 1.190	67.13 1.500	89.64 1.750	94.34	88.28 1.720	66.75 1.520	45.60 1.190
31	32	33	34	35	36	37
55.30 1.380	87.70 1.750	89.20	100.90 2.010	100.60 1.920	87.31 1.800	56.85 1.280
41	42	43	44	45	46	47
57.63 1.390	94.69	106.13 1.940	94.34	105.16 1.890	92.16	62.89 1.315
51	52	53	54*	55	56	57
58.60 1.330	86.34 1.720	97.40 1.830	106.13 2.020	89.00	88.48 1.780	57.43 1.270
61*	62	63	64	65	66	67*
44.24 1.190	67.91 1.500	92.75 1.740	94.69	86.93 1.750	67.99 1.500	45.21 1.190
	72	73	74	75	76	
	47.15 1.200	58.60 1.340	58.99 1.380	50.25 1.325	45.21 1.210	



\*Positions Tested

Fig. 4-11 - SM-1 Core Flow Distribution and Orifice Size




Fig. 4-12 - SM-1 Stationary Element Flow Distribution - 2.02" Orifice Located at Inlet




Fig. 4-13 - SM-1 Stationary Element Flow Distribution - 1.19" Orifice Located at Inlet






Fig. 4-14 - Location of Conical Diffuser within Inlet End Box

TABLE 4-1  
SM-1 STATIONARY ELEMENT FLOW DISTRIBUTION - 2.02 In. Orifice at Inlet

Channel Letter	Q = 50 gpm		Q = 76 gpm		Q = 100 gpm		Q = 125 gpm	
	V <sub>max-meas</sub> fps	$\bar{V}$ <sub>correct</sub> fps	V <sub>max-meas</sub> fps	$\bar{V}$ <sub>correct</sub> fps	V <sub>max-meas</sub> fps	$\bar{V}$ <sub>correct</sub> fps	V <sub>max-meas</sub> fps	$\bar{V}$ <sub>correct</sub> fps
A	3.20	2.58	4.66	3.82	6.21	5.32	7.80	6.77
B	3.35	2.72	4.95	4.15	6.62	5.70	8.30	7.22
C	3.37	2.73	5.01	4.20	6.68	5.75	8.38	7.30
D	3.45	2.80*	5.11	4.29*	6.80	5.84*	8.50	7.40*
E	3.32	2.70	4.91	4.11	6.55	5.63	8.20	7.13
F	3.36	2.72	4.91	4.11	6.50	5.58	8.07	7.01
G	3.29	2.67	4.90	4.10	6.45	5.54	8.00	6.95
H	3.07	2.44⊗	4.55	3.76	6.03	5.14	7.49	6.49
I	3.10	2.45	4.58	3.80	5.98	5.09	7.40	6.40
J	3.10	2.45	4.49⊗	3.70⊗	5.85	4.99⊗	7.22	6.23⊗
K	3.29	2.67	4.81	4.00	6.32	5.41	7.80	6.77
L	3.32	2.70	4.85	4.05	6.42	5.50	7.98	6.92
M	3.21	2.59	4.73	3.93	6.30	5.40	7.82	6.80
N	3.42	2.78	5.02	4.21	6.65	5.70	8.30	7.22
O	3.40	2.76	5.00	4.20	6.62	5.69	8.25	7.15
P	3.22	2.60	4.75	3.95	6.37	5.46	7.78	6.75
Q	3.17	2.54	4.64	3.85	6.14	5.24	7.65	6.62
Average		2.64		4.01		5.47		6.89
* +% of Avg.		6.1		7.0		6.8		7.4
⊗ -% of Avg.		7.6		7.7		8.8		9.6

**TABLE 4-2**  
**SM-1 STATIONARY ELEMENT FLOW DISTRIBUTION**  
**1.19 In. Orifice at Inlet**

Channel	Q = 52 gpm		Q = 75 gpm		Q = 87 gpm	
	V <sub>max</sub>	$\bar{V}$	V <sub>max</sub>	$\bar{V}$	V <sub>max</sub>	$\bar{V}$
	fps	fps	fps	fps	fps	fps
A	1.84	1.28 ⊕	2.41	1.80 ⊕	2.10	1.52 ⊕
B	2.28	1.68	2.94	2.29	2.65	2.01
C	2.76	2.10	3.70	3.00	3.62	2.91
D	3.38	2.70	4.71	3.91	4.91	4.10
E	3.97	3.25	5.65	4.79	6.40	5.49
F	4.49	3.71	6.48	5.55	8.00	6.95
G	4.91	4.10*	7.18	6.19*	9.47	8.30
H	4.83	4.04	7.09	6.10	9.80	8.60
I	4.75	3.95	6.95	5.97	9.82	8.61*
J	4.55	3.77	6.78	5.82	9.18	8.04
K	4.64	3.85	6.94	5.97	8.90	7.78
L	4.35	3.59	6.48	5.55	7.65	6.62
M	3.70	3.00	5.54	4.69	6.01	5.12
N	3.23	2.55	4.75	3.95	4.62	3.82
O	2.69	2.05	3.81	3.10	3.35	2.67
P	2.10	1.52	2.97	2.30	2.28	1.68
Q	1.89	1.31	2.73	2.10	2.24	1.65
Average		2.85		4.30		5.05
* +% of Avg	44		44		70.5	
⊕ -% of Avg	55		58		70	

Flow distribution was obtained at nominal flow rates of 51, 75, 100 and 125 gpm. At the flow rate closest to the prescribed element flow rate (43.66-45.60 gpm), maximum deviations were +34% and -23.1% of average in channels A and J respectively. The results are plotted in Fig. 4-15. A complete tabulation is presented in Table 4-3. By comparing Fig. 4-13 and Fig. 4-15 one can observe the effect of the conical diffuser; a complete reversal in profile in which the flow in channel A went from -55% to +34% of element average, and the flow in channel J went from +32.6% to -23.1% of the element average. The low depression of channel flow in the center channels could possibly be improved by redesign of the element locating pin which goes completely across the end box, and is known to have an effect upon center channel velocity distribution.

Comparison of overall pressure drop (including  $\Delta P$  across orifice) before and after addition of the diffuser cone has shown that pressure drop actually decreases with the addition of the conical diffuser. These results are given in Section 4.7.1.5.

#### 4.7.1.4 SM-1 Test With Minimum Orifice and Perforated Plate - "Proof of Principle"

A second attempt to improve upon the poor SM-1 flow distribution resulted in selection of a perforated plate - 1/8-in. thick with a series of holes 1/8 in. diam and 3/16 in. diam arranged so the outer channels would receive a greater proportion of flow than the center channels. The perforated plate is shown in Fig. 4-16. The plate was fitted into the inlet end box just before the comb of the fuel element. The effect of this modification on flow distribution can be seen in Fig. 4-17. A complete tabulation of this data at nominal element flow rates of 50, 75, 100 and 125 gpm is given in Table 4-4. The results of this test were encouraging, since the modification does exactly what it was intended to do; re-distribute flow from the center channels into the outer channels. At the prescribed element flow rate of 50 gpm (an approximate value), the flow distribution was +21% and -29.4% of element average in channels H and P respectively. As flow rate increases, the flow profile shifts slightly. This is probably due to the shifting of the vena contracta as the flow is increased.

#### 4.7.1.5 Pressure Drop Test of SM-1 Stationary Element

To accurately determine the overall stationary element pressure drop (across element assembly only), a test was run with the velocity instrumentation and orifice plate removed. Results of this test are tabulated in column #1, Table 4-5. A plot of this data is shown in Fig. 4-18.

To determine the effect of the conical diffuser on pressure drop, a test was conducted with and without the conical diffuser. Since the conical diffuser was attached to the orifice plate for test purposes, the pressure drop comparison also included the pressure drop across the orifice. This data is also tabulated in Table 4-5 and plotted in Fig. 4-18. Comparison of this data (column 2 and 3, Table 4-5) shows that the conical diffuser actually reduces the total pressure drop across the element and orifice plate, probably because it breaks up the vena contracta and re-distributes the flow.

**THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK**




Fig. 4-15 - SM-1 Stationary Fuel Element Flow Distribution  
 1.19" Orifice with Diffuser Cone Located at  
 Element Inlet




Fig. 4-16 - Perforated Plate for SM-1 Element




Fig. 4-17 - SM-1 Stationary Element Flow Distribution - 1.19" Orifice and Perforated Plate Located at Element Inlet



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

TABLE 4-3  
SM-1 STATIONARY FUEL ELEMENT FLOW DISTRIBUTION  
WITH DIFFUSER CONE LOCATED IN  
EXTRANCE END BOX - 1.19" ORIFICE

Channel	Qelem = 51 gpm		Qelem = 75 gpm		Qelem = 100 gpm		Qelem = 125 gpm	
	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS
A	4.43	*3.66	5.94	*5.05	7.58	*6.56	9.30	*8.15
B	4.20	3.46	5.82	4.95	7.49	6.48	9.10	7.98
C	3.73	3.02	5.49	4.73	7.12	6.12	8.51	7.46
D	3.44	2.74	5.36	4.52	7.00	6.02	8.30	7.22
E	3.16	2.49	5.02	4.21	6.60	5.66	7.80	6.78
F	2.96	2.30	4.77	3.98	6.40	5.49	7.42	6.41
G	2.94	2.29	4.54	3.78	6.18	5.28	7.18	6.20
H	2.83	2.20	4.15	3.41	5.60	4.74	6.48	5.56
I	2.86	2.22	3.96	3.22	5.40	4.56	6.18	5.28
J	2.72	*2.10	3.83	*3.11	5.15	*4.32	6.05	*5.15
K	2.90	2.26	4.01	3.29	5.29	4.45	6.28	5.38
L	3.10	2.44	4.19	3.43	5.43	4.60	6.63	5.70
M	3.20	2.53	4.28	3.51	5.45	4.61	6.82	5.87
N	3.73	3.02	4.83	4.04	6.18	5.28	7.95	6.90
O	3.94	3.22	5.20	4.38	6.76	5.81	8.97	7.82
P	3.99	3.26	5.49	4.64	7.10	6.12	9.52	8.35
Q	3.94	3.22	5.60	4.75	7.24	6.25	9.45	8.29
Avg.		2.73		4.05		5.43		6.74
* % of Avg.		34		24.3		21		23.9
* -% of Avg.		23.1		23.4		20.5		23.6

TABLE 4-4  
 SM-1 STATIONARY FUEL ELEMENT FLOW DISTRIBUTION  
 1.19" ORIFICE AT INLET  
 PERFORATED BAFFLE PLATE LOCATED IN ENTRANCE END BOX

Channel	Qnom. = 50 gpm		Qnom. = 75 gpm		Qnom. = 100 gpm		Qnom. = 125 GPM	
	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS
A	3.35	2.67	4.90	4.10	4.74	⊗3.95	5.53	⊗4.70
B	3.88	3.16	5.72	4.86	5.56	4.71	6.46	5.54
C	3.88	3.16	5.75	4.89	6.28	5.37	7.36	6.37
D	3.76	3.05	5.51	4.66	6.95	5.99	8.35	7.27
E	3.38	2.70	4.90	4.10	6.78	5.82	8.16	7.09
F	3.04	2.39	4.36	3.61	6.10	5.20	7.36	6.37
G	2.79	2.16	3.94	3.21	5.78	4.92	7.20	6.21
H	2.45	⊗1.85	3.38	2.70	5.54	4.70	7.01	6.04
I	2.49	1.88	3.20	⊗2.53	5.53	4.69	7.10	6.11
J	2.37	1.77	3.29	2.61	5.60	4.75	7.12	6.12
K	2.68	2.04	3.89	3.17	6.45	5.53	8.02	6.98
L	3.47	2.78	9.52	3.75	7.75	6.72	9.56	8.39
M	3.17	2.51	4.70	3.91	7.77	6.75	9.57	8.40
N	3.84	3.13	5.66	4.80	8.02	*6.99	9.80	*8.61
O	4.06	*3.33	6.03	*5.15	7.24	6.26	8.74	7.62
P	3.89	3.17	5.92	5.04	6.01	5.12	7.20	6.21
Q	3.47	2.78	5.11	4.30	5.47	4.62	6.49	5.56
Avg.		2.62		3.96		5.42		6.68
* % Avg.		21		30.1		29		28.9
⊗ % Avg.		29.4		36.2		27.2		29.7

The results of testing with the perforated plate are also tabulated below and plotted in Fig. 4-19. A reading of pressure drop was not obtained at 125 gpm because the signal was greater than the range of the instrument. A comparison of the results from this test with the results obtained from testing with the 1.19 in. orifice shows that this plate adds slightly to the total drop across the orifice and element. However, at the low flow rate prescribed for this element, no significant increase in pressure drop is noted. Only at higher flow rates was the increase noted.

**TABLE 4-5**  
**SM-1 STATIONARY ELEMENT PRESSURE DROP**

Element Flow Rate, gpm	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
	Element Pressure Drop - Ft H <sub>2</sub> O No Orifice	Element $\Delta P$ with 1.19" Orifice Incl. Ft H <sub>2</sub> O	Element $\Delta P$ with 1.19" Orifice & Diffuser Cone Incl. Ft H <sub>2</sub> O	Element $\Delta P$ with 1.19" Orifice & Perforated Plate Incl. Ft H <sub>2</sub> O
50	1.14	8.18	6.18	8.13
75	2.31	17.95	13.29	18.81
100	3.91	31.76	23.35	33.30
125	5.95	48.64	37.64	*53.30

\* Extrapolated from Curve.

#### 4.7.2 SM-1A Stationary Fuel Element Flow Tests

The Type 3 stationary element for SM-1A was tested with one orifice selection: the minimum orifice - 1.68 in. diam (element position #22). The orifice location for this test was at the element outlet (corresponding to the top of the core support structure). The minimum orifice was chosen since it has the greatest adverse effect on flow distribution. The position of this element in the core is shown in Fig. 4-20.

##### 4.7.2.1 Test with Minimum Orifice

Results of this test at nominal element flow rates of 50, 75, 100 and 125 gpm are plotted in Fig. 4-21. At the prescribed flow rate of 127 gpm (see Fig. 4-20) the maximum deviation from average channel velocity was +6.1% and -6.7% in channels D and A respectively. A complete tabulation of this data is given in Table 4-6.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK




Fig. 4-18 - SM-1 Stationary Fuel Element Pressure Drop - Ft H<sub>2</sub>O  
Vs Element Flow Rate - gpm





Fig. 4-19 - SM-1 Stationary Fuel Element (with Orifice and Perforated Plate at Inlet) Pressure Drop - Ft H<sub>2</sub>O Vs Element Flow Rate-gpm

	12 138 1.758	13 146 1.882	14 148 1.870	15 148 1.855	16 136 1.745	
21 132 1.705	22* 127 1.680	23 142 1.764	24 147	25 142 1.808	26 131 1.734	27 131 1.673
31 146 1.767	32 135 1.720	33 147	34 157 1.815	35 149 1.823	36 135 1.730	37 145 1.815
41 148 1.773	42 147	43 152 1.823	44 147	45 155 1.864	46 147	47 148 1.833
51 146 1.817	52 135 1.707	53 153 1.840	54 155 1.790	55 147	56 141 1.820	57 155 1.802
61 132 1.740	62 127 1.735	63 136 1.733	64 147	65 143 1.790	66 129 1.736	67 129 1.750
	72 134 1.734	73 147 1.800	74 149 1.810	75 149 1.925	76 141 1.820	

Inlet

Core Position



Element Flowrate (gpm)

Orifice Size (in)

\* Position Tested

Fig. 4-20 - SM-1A Core Flow Distribution and Orifice Size






Fig. 4-21 - SM-1A Stationary Element Flow Distribution - 1.68" Orifice Located at Exit

TABLE 4-6  
SM-1A STATIONARY ELEMENT FLOW DISTRIBUTION  
1.68 In. Orifice at Exit

Channel	$Q_{nom}$ 50.5 gpm		$Q_{nom}$ 75.8 gpm		$Q_{nom}$ 100 gpm		$Q_{nom}$ 125	
	$V_{max-FPS}$	$\bar{V}-FPS$	$V_{max-FPS}$	$\bar{V}-FPS$	$V_{max-FPS}$	$\bar{V}-FPS$	$V_{max-FPS}$	$\bar{V}-FPS$
A	3.17	2.50*	4.58	3.80*	6.00	5.12	7.39	6.38*
B	3.41	2.72	4.88	4.08	6.36	5.45	7.75	6.72
C	3.53	2.85	5.00	4.20	6.60	5.66	8.00	6.95
D	3.61	2.91*	5.19	4.35*	6.80	5.85*	8.35	7.26*
E	3.56	2.88	5.09	4.27	6.69	5.74	8.20	7.12
F	3.56	2.88	5.09	4.27	6.68	5.73	8.15	7.08
G	3.59	2.89	5.11	4.30	6.69	5.74	8.18	7.10
H	3.41	2.72	4.83	3.94	6.30	5.40	7.70	6.68
I	3.35	2.67	4.81	3.91	6.20	5.30	7.63	6.60
J	3.23	2.57	4.67	3.89	6.07	5.17	7.40	6.40
K	3.41	2.72	5.01	4.21	6.51	5.60	8.00	6.95
L	3.56	2.88	5.09	4.27	6.64	5.70	8.16	7.09
M	3.47	2.79	4.96	4.15	6.48	5.56	7.91	6.87
N	3.56	2.88	5.15	4.34	6.70	5.75	8.28	7.20
O	3.47	2.79	5.05	4.25	6.51	5.60	8.02	6.98
P	3.29	2.61	4.77	3.88	6.15	5.25	7.51	6.50
Q	3.23	2.57	4.62	3.84	5.99	5.10*	7.37	6.38*
Avg $\bar{V}$		2.75		4.11		5.51		6.84
* +% of Avg	5.8		5.8		6.2		6.1	
* -% of Avg	9.1		7.5		7.5		6.7	

#### 4. 7. 2. 2 Test With Minimum Orifice with Element Locating Pin Removed

When testing both the SM-1 with maximum (2.02 in. diam) orifice, and the SM-1A with minimum orifice, a definite dip in flow through the center channels was noted. A profile such as this was entirely unexpected since results of MTR<sup>(3)</sup> and ETR<sup>(4)</sup> testing with similar end boxes show a profile peaking at element center. Since the only object obstructing flow was the 1/4 in. diam locating pin located approximately 3-1/2 in. from the fuel plates, this pin was removed. The effect of the removal of this pin can be seen by comparing Fig. 4-21 and Fig. 4-22. The center channels are now above average while flow in the outer channels has dropped off considerably. In fact, flow maldistribution has increased to +12% and -13.7% in channels G and A respectively at the prescribed element flow rate of 127 gpm. Some irregularity was still noted in the center channels. A tabulation of this data is presented in Table 4-7.

#### 4. 7. 2. 3 Pressure Drop Test of SM-1A Stationary Element

Overall stationary element pressure drop (no  $\Delta h$  across orifice) at flow rates of 50, 75, 100 and 125 gpm is tabulated below. These pressure drops are identical to those obtained in testing of the SM-1 stationary element since the two elements are identical and no orifice pressure drop was included.

#### 4. 7. 3 PM-2A Stationary Fuel Element Flow Test

The PM-2A stationary fuel element differed from the SM-1 and SM-1A fuel element in one respect; it had a different exit end box which reduced the overall element length by 2 in. The orifice plate for this element is located at the element exit (corresponding to top of core support structure).

Once again, the smallest orifice -1.83 in. diam - was selected for test purposes since this orifice has the greatest adverse effect on flow distribution. The position of this element (element #22) within the core, together with the required element flow rate, is shown in Fig. 4-23.

Flow distribution results at nominal element flow rates of 50, 75, 100 and 125 gpm are plotted in Fig. 4-24. At the test flow rate nearest the required element flow rate of 113 gpm, flow maldistribution is +6.2% and -11.1% of average channel velocity in channels D and Q respectively. The data is tabulated in Table 4-9.

#### 4. 7. 3. 1 Pressure Drop Test of PM-2A Stationary Element

Overall stationary element pressure drop (across element assembly only) was obtained with the instrument rake and orifice plate removed. Data was obtained at flow rate of 50, 75, 100 and 125 gpm. This data is tabulated in Fig. 4-10 and plotted in Fig. 4-25.

Average Channel Velocity - Feet Per Second




Fig. 4-22 - SM-1A Stationary Element Flow Distribution 1.68" Orifice  
Located at Exit - Locating Pin Removed

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

TABLE 4-7  
SM-1A STATIONARY ELEMENT FLOW DISTRIBUTION  
1. 68 In. Orifice at Exit  
No Locating Pin in Inlet End Box

Channel	Q <sub>elem</sub> = 51.3 gpm		Q <sub>elem</sub> = 75.0 gpm		Q <sub>elem</sub> = 100 gpm		Q <sub>elem</sub> = 125 gpm	
	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS
A	3.04	2.39	4.21	3.48 ⊕	5.55	4.70 ⊕	6.80	5.85 ⊕
B	3.20	2.53	4.38	3.62	5.75	4.89	7.10	6.11
C	3.26	2.58	4.49	3.71	5.94	5.06	7.34	6.35
D	3.41	2.72	4.79	3.99	6.32	5.42	7.84	6.80
E	3.47	2.78	4.90	4.10	6.47	5.55	8.00	6.95
F	3.62	2.92	5.08	4.27	6.71	5.77	8.35	7.27
G	3.78	3.08*	5.31	4.49*	7.00	6.03*	8.70	7.60*
H	3.59	2.89	5.04	4.24	6.67	5.73	8.28	7.20
I	3.65	2.95	5.14	4.32	6.81	5.86	8.49	7.40
J	3.47	2.78	4.90	4.10	6.48	5.56	8.01	6.96
K	3.65	2.95	5.15	4.34	6.84	5.89	8.50	7.42
L	3.59	2.89	5.10	4.29	6.72	5.78	8.34	7.26
M	3.45	2.77	4.77	3.98	6.30	5.40	7.79	6.76
N	3.41	2.72	4.85	4.06	6.35	5.45	7.89	6.84
O	3.29	2.61	4.65	3.86	6.12	5.22	7.51	6.50
P	3.10	2.44	4.33	3.59	5.69	4.82	7.00	6.03
Q	3.00	2.35 ⊕	4.26	3.51	5.59	4.73	6.88	5.91
Avg.	3.41	2.79	4.79	4.00	6.31	5.40	7.80	6.78
* +% of Avg	10.4		12.3		11.7		12.0	
⊕ -% of Avg	15.8		13.0		13.0		13.7	

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK





Fig. 4-23 - PM-2A Core Flow Distribution and Orifice Size






Fig. 4-24 - PM-2A Stationary Element Flow Distribution - 1.83" Orifice Located at Exit

TABLE 4-8  
SM-1A STATIONARY ELEMENT PRESSURE DROP

<u>Flow Rate</u> <u>gpm</u>	<u>Overall Pressure Drop</u> <u>Ft H<sub>2</sub>O</u>
50	1.14
75	2.31
100	3.91
125	5.95

#### 4.8 CHECKS OF MEASUREMENTS

The following is a sample calculation of those made at each flow rate to obtain a check on velocity measurements given in Section 4.7. Since all loop flow passed through the stationary element, loop flow equals element flow. Any difference would be due to leakage past the element or to slight measurement error.

SM-1A Stationary Element (1.68 In. Orifice) - at 125 gpm loop flow

$$\text{Average channel velocity} = 6.84 \text{ fps}$$

$$\text{Flow Area} = 40.386 \times 10^{-3} \text{ ft}^2$$

$$\text{Flow} = 6.84 \times 40.386 \times 10^{-3} = 276.24 \times 10^{-3} \text{ cfs}$$

$$= \frac{276.24 \times 10^{-3}}{2.228 \times 10^{-3}} = 123.98 = 124 \text{ gpm}$$

This calculation indicates that at 125 gpm element flow, only 1 gpm is lost due to leakage or possible instrument error and that data would be consistent. Thus it can be assumed that the velocities reported are valid.

TABLE 4-9  
PM-2A STATIONARY FUEL ELEMENT FLOW DISTRIBUTION  
1.83 In. Orifice at Exit

Channel	Q = 50 gpm		Q = 75 gpm		Q = 100 gpm		Q = 125 gpm	
	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS	V <sub>max</sub> -FPS	$\bar{V}$ -FPS
A	3.07	2.42	4.49	3.71	5.96	5.07	7.38	6.38
B	3.32	2.64	4.79	3.99	6.33	5.44	7.84	6.80
C	3.38	2.70	4.90	4.10	6.42	5.50	7.97	6.91
D	3.44	2.75 *	5.03	4.23*	6.67	5.72*	8.29	7.20*
E	3.41	2.72	4.91	4.11	6.52	5.60	8.09	7.02
F	3.32	2.64	4.90	4.10	6.50	5.58	8.05	7.00
G	3.36	2.68	4.91	4.11	6.52	5.60	8.10	7.04
H	3.23	2.57	4.69	3.90	6.20	5.30	7.65	6.63
I	3.20	2.52	4.67	3.89	6.14	5.24	7.58	6.56
J	3.13	2.49	4.49	3.71	5.92	5.03	7.30	6.30
K	3.32	2.64	4.88	4.08	6.40	5.49	7.96	6.90
L	3.36	2.68	4.91	4.11	6.52	5.60	8.09	7.02
M	3.36	2.68	4.83	4.04	6.39	5.48	7.92	6.87
N	3.44	2.75*	5.02	4.21	6.64	5.70	8.24	7.15
O	3.32	2.64	4.88	4.08	6.48	5.55	8.00	6.95
P	3.13	2.49	4.58	3.80	6.09	5.19	7.48	6.47
Q	2.94	2.29 ⊗	4.24	3.50 ⊗	5.67	4.82 ⊗	7.01	6.03 ⊗
Avg.	2.61		3.98		5.41		6.78	
* +% of Avg	5.5		6.3		5.8		6.2	
⊗ -% of Avg	12.1		12.1		10.8		11.1	

**TABLE 4-10**  
**PM-2A STATIONARY ELEMENT PRESSURE DROP**

<u>Flow Rate</u> <u>gpm</u>	<u>Overall Element Pressure Drop</u> <u>Ft H<sub>2</sub>O</u>
50	0.929
75	1.990
100	3.435
125	5.210

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK




Fig. 4-25 - PM-2A Stationary Fuel Element Pressure Drop (Ft. H<sub>2</sub>O)  
Vs Element Flow Rate (gpm)

## 5.0 CONTROL ROD ASSEMBLY TEST

### 5.1 PURPOSE OF TESTS

The purpose of this test was to determine channel-to-channel flow distribution within a Type 3 (SM-2) control rod fuel element installed in SM-1, SM-1A and PM-2A control rod assemblies.

### 5.2 DESCRIPTION OF TEST RIG AND INSTRUMENTATION

The test rig used for control rod testing was identical to the rig used in stationary element testing with the exception of an extension piece added to house the additional length of the control rod assembly. The test rig is shown in Fig. 5-1 and 5-2.


The control rod fuel element was instrumented in the same manner as the stationary fuel element (Sec. 4.2.1). Instrument lines were connected to a penetrated ring and out to manometers. Loop flow was again measured by a standard orifice installation connected to a mercury monometer for accurate measurement. Since all loop flow passed through the control rod, loop flow is equivalent to element flow.

### 5.3 DESCRIPTION OF TEST SPECIMEN

The control rod fuel element was a standard Type 3 (fully welded) element fabricated by the Alco Welding Laboratory. The instrumented element control rod fuel element is shown in Fig. 5-3. Complete channel measurements are presented in Table 3-2. This element was fabricated to Type 3 Specifications in accordance with production drawings made for Task 3.3 of the PWR Support and Development Program.

The control rod assembly consisted of the following components: absorber, fuel element, and tube and piston section. Absorbers and tubes were production units previously utilized in testing of SM-1 and SM-1A and PM-2A cores. No control rod cap was used since this item was not available to the program and proved to be too expensive to fabricate. Besides, the chief objective of the test was to determine channel-to-channel flow distribution, which would not be affected by the cap assembly located so far downstream. An exploded view showing the SM-1A control rod components and test section is shown in Fig. 5-4. An assembled view of the same components is shown in Fig. 5-5. This same test specimen was used in PM-2A testing since the only difference between the SM-1A and PM-2A control rod assemblies is the overall length, which would not affect flow distribution in the fuel element located so far downstream of the exit of the assembly.

5-3



DATE	LET.	REVISION RECORD	AUTH.	DR.	CHK.

PART NO.  
**C9-50-1279**

NOTE: "SK" NUMBERS  
REFER TO MECH. LAB. DRAWING NOS.

6	1	SK-1262	TUBE SECT. ASSY
5	1	SK-1275	ASSY- EXTENSION TUBE SECT.
4	1	SK-1070	PLENUM CHAMBER-CENTER
3	2	SK-1078	SUPPORT FLANGE
2	2	SK-1072	PLENUM CHAMBER
1	1	C9-50-2498	PENETRATION RING
PC No	DWG NO OR MATERIAL	DESCRIPTION	

		ALCO PRODUCTS, INC.	
		NUCLEAR POWER ENGINEERING DEPT. SCHENECTADY, N. Y., U. S. A.	
SCALE 1/4" = 1"	REF.	DR.	B. PARKER 9-29-61
MATERIAL SPEC.	TR.	CHK.	D. L. 3-29-61
	APPR.	B. PARKER 9-29-61	
	APPR.		
	MET.	AL-1/2" x 1/4" x 1/4"	
NAME CONTROL ROD TEST SECTION ASSEMBLY			
PART NO. <b>C9-50-1279</b>			

BREAK SHARP EDGES  
REMOVE ALL BURRS

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES.  
TOLERANCES ON FINISHED  
FRACTIONAL DIMENSIONS  
TO BE ±

- ✓ FINISH AS INDICATED IN MICRINCHES.
- (1) MACHINING FINISH - ROUGH
- (10) FLAME - UT OR SAW



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK





Fig. 5-2 - Control Rod Assembly Test Loop



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



5-7



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK






Fig. 5-4 - Control Rod Assembly and Test Section - Exploded View






Fig. 5-5 - SM-1A Control Rod Assembly Assembled View

The SM-1 test specimen differed slightly from the SM-1A type in that no flow holes were present at the bottom of the tube, thereby presenting a different entrance flow condition than experienced in the SM-1A, PM-2A test. The fuel element and absorber were inserted and positioned in the tube as centrally as possible. No special attempt was made to control the lattice passages formed by the outer fuel plates and the tube.

#### 5.4 TEST PROCEDURE

Control rod assembly test procedures were identical to those utilized in testing of the stationary element (See Section 4.4). However, no overall assembly pressure drop was obtained because the cap assemblies were not available for these tests. The following data was recorded at each flow rate:

- (1) Total loop flow - gpm
- (2) Water temperature -  $^{\circ}\text{F}$
- (3) Velocity pressures - in. Blue Fluid (Sp.gr. 1.75)

At least two comparable runs were made at each different flow rate to insure reliable results.

#### 5.5 DATA REDUCTION

The method of data reduction used in control rod testing was identical to that discussed in Section 4.5 except that average channel velocity was determined from Fig. 3-7 which is a plot  $V_{\text{avg}}$  vs.  $V_{\text{max}}$  obtained from calibration of the control rod fuel element.

#### 5.6 TEST RESULTS

Test results obtained from the two different control rod assemblies are presented in the following sections.

##### 5.6.1 SM-1 Control Rod Assembly Test

Flow distribution within the Type 3 control rod fuel element for SM-1 at flow rates of 50, 76, 99, and 114 gpm is shown in Fig. 5-6. A complete tabulation of this data is presented in Table 5-1.

Required control rod flow rates are shown in Fig. 4-11. These range from 89.00 to 94.69 gpm. The test flow rate most comparable to the required control rod flow rate is 99 gpm. At this flow rate, average channel velocity-(lattices



TABLE 5-1  
SM-1 CONTROL ROD ASSEMBLY FLOW DISTRIBUTION

Channel	Q = 50 gpm		Q = 76 gpm		Q = 99 gpm		Q = 114 gpm	
	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS
A (Lattice)	3.10	2.50	4.28	3.51	5.49	4.56	6.24	5.23
B	3.07	2.47	4.17	3.44**	5.34	4.42**	6.08	5.09**
C	3.32	2.69	4.75	3.91	6.16	5.16	7.05	5.95
D	3.53	2.87	5.28	4.39	6.86	5.78	7.86	6.67
E	3.44	2.79	4.98	4.12	6.39	5.36	7.30	6.18
F	4.09	3.34	6.10	5.10	7.93	6.75	9.07	7.82
G	4.30	3.52	6.40	5.37	8.30	7.09	9.50	8.23
H	4.35	3.57	6.59	5.54	8.58	7.36	9.80	8.52
I	4.46	3.66*	6.70	5.64*	8.80	7.56*	10.10	8.82*
J	4.38	3.60	6.59	5.54	8.64	7.40	9.90	8.62
K	4.26	3.50	6.40	5.37	8.39	7.17	9.60	8.32
L	4.11	3.36	6.15	5.15	8.03	6.84	9.20	7.94
M	3.59	2.91	5.18	4.30	6.72	5.66	7.65	6.49
N	3.61	2.93	5.25	4.35	6.80	5.72	7.79	6.61
O	3.44	2.79	4.69	3.86	5.85	4.89	6.63	5.57
P	3.04	2.45**	4.31	3.54	5.53	4.61	6.28	5.26
Q (Lattice)	2.68	2.13 ⊗	3.94	3.22 ⊗	5.19	4.31 ⊗	5.92	4.94 ⊗
Avg. (Inc. Lattice)		3.00		4.49		5.92		6.84
* % of Avg.		22		25.6		27.7		28.9
⊗ % of Avg.		29 Latt.		28.3		27.2		27.8
Avg. (No. Lattice)		3.10		4.64		6.12		7.07
* % of Avg.		18		21.6		23.5		24.8
** % of Avg.		21		25.9		27.8		28

TABLE 5-2  
SM-1A AND PM-2A CONTROL ROD ASSEMBLY FLOW DISTRIBUTION

Channel	Q = 50 gpm		Q = 75 gpm		Q = 100 gpm		Q = 120 gpm	
	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS	V <sub>max</sub> -FPS	V-FPS
A (Lattice)	3.20	2.59	4.45	3.65	5.74	4.79	6.82	**5.73
B	3.23	⊗2.63	4.55	⊗3.75	5.88	⊗4.91	6.97	⊗5.87
C	3.38	2.74	4.91	4.06	6.48	5.44	7.73	6.56
D	3.84	3.14	5.53	4.60	7.25	6.14	8.69	7.45
E	3.86	3.15	5.56	4.64	7.30	6.18	8.76	7.51
F	4.01	3.29	5.90	4.92	7.74	6.57	9.31	8.04
G	4.12	3.37	5.97	4.98	7.85	6.67	9.49	8.21
H	4.17	3.41	6.05	5.05	8.00	6.81	9.65	8.37
I	4.26	*3.50	6.18	*5.17	8.18	*6.98	9.88	*8.60
J	4.20	3.44	6.15	5.15	8.10	6.91	9.80	8.52
K	4.12	3.37	6.08	5.09	8.00	6.81	9.62	8.35
L	4.12	3.37	6.01	5.02	7.89	6.70	9.50	8.23
M	3.89	3.17	5.69	4.74	7.43	6.29	8.94	7.69
N	3.77	3.07	5.44	4.52	7.14	6.01	8.59	7.36
O	3.59	2.91	5.19	4.30	6.80	5.72	8.10	6.91
P	3.35	2.71	4.83	4.00	6.27	5.25	7.52	6.37
Q (Lattice)	3.10	**2.50	4.43	**3.64	5.74	**4.79	6.90	5.81
Avg.(inc. Lattice)		3.08		4.55		6.06		7.39
* % of Ave.		13.6		13.6		15.2		16.4
** - % of Ave.		18.8		20.0		21.0		22.5
Avg. (no Lattice)		3.15		4.67		6.23		7.60
* % of Ave.		11.1		10.7		12.0		13.2
⊗ - % of Ave.		16.5		19.7		21.2		22.8

excluded) was 6.12 fps, with channel I being 23.5% above average and channel B 27.8% below average. If lattices are included, the maximum deviations from average channel velocity (5.92 fps) now appear in lattice Q and channel I with lattice Q being 27.2% below average and channel I 27.7% above average.

Although no particular effort was made to centrally position the fuel element within the tube, the lattices show very good flow symmetry. Because of the limited scope of the program no effort was made to determine the effect of non-central positioning on flow distribution.

#### 5.6.2 SM-1A and PM-2A Control Rod Assembly Test

Channel-to-channel flow distribution for this test is shown in Fig. 5-7 with a complete tabulation of data presented in Table 5-2.

Referring to Fig. 4-20, the required control rod flow rate for the SM-1A is 147 gpm. The test flow rate nearest the required flow rate is 120 gpm. A higher flow rate was not used since channel velocity measurements went beyond the manometer range. At this flow rate, average channel velocity, lattices excluded, was 7.60 fps with channel I being 13.2% above average and channel B 22.8% below average. Maximum deviations from average become 16.4% and -22.5% of average channel velocity (7.39 fps) in channels I and Q respectively when lattices are included. The same analysis pertains to the PM-2A since the required control rod flow rate is 114 gpm as shown in Fig. 4-23.

From the data obtained at different flow rates one can see that flow maldistribution increases slightly as flow rate increases. To obtain a maldistribution factor at 147 gpm, a slightly higher factor than reported here would have to be used.

By comparing Fig. 5-7 and 5-8, one can observe the effect of the bottom flow holes present on the SM-1A and PM-2A type assembly. At each flow rate a definite improvement in maldistribution is noted. Velocity peaking in the channels adjacent to the center channel was reduced while flow in the outer channels and lattices increased slightly.

#### 5.7 CHECK OF MEASUREMENTS

The following sample calculation was made at each flow rate to obtain a check on velocity measurements given in the preceding Section 5.6. The sum of the flow through the control rod fuel element and the active lattices (formed by the outer fuel plates and control rod tube) should approximately equal the total loop flow.




Fig. 5-6 - SM-1 Control Rod Assembly Flow Distribution




Fig. 5-7 - SM-1A and PM-2A Control Rod Assembly Flow Distribution

Any difference would be due to bypass leakage past the control rod tube, or to measurement error.

SM-1 Control Rod Assembly at 50 gpm.

Average channel velocity (lattices excluded)	=	3.10 fps
Average lattice velocity	=	2.32 fps
Element flow area	=	$32.714 \times 10^{-3} \text{ ft}^2$
Lattice (active) flow area	=	$3.391 \times 10^{-3} \text{ ft}^2$

$$\begin{aligned}\text{Element flow} &= (32.714 \times 10^{-3}) (3.10) = 101.41 \times 10^{-3} \text{ cfs} \\ &= (101.41 \times 10^{-3}) (4.488 \times 10^2) = 45.51 \text{ gpm}\end{aligned}$$

$$\begin{aligned}\text{Lattice flow} &= (3.391 \times 10^{-3}) (2.32) = 7.867 \times 10^{-3} \text{ cfs} \\ &= (7.867 \times 10^{-3}) (4.488 \times 10^2) = 3.53 \text{ gpm}\end{aligned}$$

$$\text{Summation of the flows } 45.51 + 3.53 = 49.04 \text{ gpm}$$

This calculation, with a total loop flow of 50 gpm, indicated an uncertainty of 1 gpm due to buildup of possible instrument errors or bypass leakage.

## 6.0 CONCLUSIONS

### 6.1 STATIONARY FUEL ELEMENT FLOW DISTRIBUTION

#### 6.1.1 SM-1 Stationary Element (Bottom Orificed)

Testing of the Type 3 stationary element modified for SM-1, with the maximum orifice (2.02 in. diam) showed channel-to-channel flow distribution ranged from  $\pm 6.8\%$  to  $-8.8\%$  of average channel velocity at the design flow rate. This is well within the  $\pm 12\%$  maldistribution factor used in previous thermal analyses. Testing with the minimum orifice (1.19 in. diam) indicated flow distribution within the element ranged from  $\pm 44\%$  to  $-55\%$  of average channel velocity (far above the  $\pm 12\%$  target value). Because of the limited scope of the program, no intermediate orifices were tested to determine at which point the target values were exceeded.

Preliminary investigations were made to determine the effects of two element flow fixes upon flow distribution. One was a conical diffuser, the other a perforated plate; both were capable of becoming an integral part of the element. The investigation showed that definite improvement can be made in the flow distribution within this minimum orificed element.

#### 6.1.2 SM-1A Stationary Element (Top orificed)

Testing of the Type 3 stationary element modified for SM-1A, with the minimum orifice (1.68 in. diam) showed channel-to-channel flow distribution ranged from  $\pm 6.1\%$  to  $-6.7\%$  of average channel at the design flowrate. This is well within the assumed target value of  $\pm 12\%$  used in previous thermal analyses. Since the minimum orifice represents the condition having the most adverse effect upon flow distribution, presumably flow distribution within the elements with larger orifices is also within the acceptable limits of  $\pm 12\%$ .

#### 6.1.3 PM-2A Stationary Element (top orificed)

Flow distribution ranged from  $\pm 6.2\%$  to  $-11.1\%$  of average channel velocity in testing the PM-2A stationary element with minimum orifice (1.83 in. diam). Since flow distribution in the element with minimum orifice was within the acceptable limits, it can be concluded that flow distribution in all other elements of the core is also within the acceptable limits.

## 6.2 CONTROL ROD ASSEMBLY FLOW DISTRIBUTION

### 6.2.1 SM-1 Control Rod Assembly

Flow distribution within the fuel element ranged from  $\pm 23.5\%$  to  $-27.8\%$  of average channel velocity at the design flow rate. This is much greater than the assumed  $\pm 12\%$  target value, indicating that some modification should be made to the inlet end design.

### 6.2.2 SM-1A and PM-2A Control Rod Assembly

Flow distribution ranged from  $\pm 14\%$  to  $-23.4\%$  (both extrapolated) in the SM-1A and from  $\pm 13.2\%$  to  $-22.8\%$  in the PM-2A. The slight improvement in flow distribution over the SM-1 can be traced to the presence of additional flow holes at the bottom (inlet end) of the control rod tube. Additional modifications should be made to the inlet end of the control rod tube to improve the above maldistribution, since it is still not within the acceptable limits.



## 7.0 RECOMMENDATIONS

1. An investigation should be made to determine methods of improving the poor flow distribution within the SM-1 stationary elements with small orifices, and determine the feasibility of using such a flow improvement device in all future elements of the SM-1 type.
2. A design study and test program should be initiated to determine a method for improving the flow distribution within the control rod assemblies of the SM-1, SM-1A and PM-2A.
3. An investigation should be made to measure local flow velocities and velocity profile within a single SM or PM- channel to provide fundamental information for use in thermal analysis.
4. A test program should be initiated to determine the effect on flow distribution of non-central positioning of the control rod fuel element within the control rod tube.
5. In future design of reactor cores, bottom orificing should be used only if a flow test program is performed to establish flow distribution patterns within each element.

## 8.0 BIBLIOGRAPHY

1. APAE No. 86, "Mid-Year Summary Report Army PWR Support and Development Program, October 1, 1960, -March 31, 1961," June 2, 1961.
2. Davidson, S. L., Seglaman, I., "Thermal Analysis of Type 3 Cores in SM-1, SM-1A and PM-2A Plants," APAE 105 (To be issued)
3. Conner, W. D., "MTR Technical Branch Quarterly Report," IDO-16297, August 16, 1956.
4. Beck, R. G., "Hydraulics of Modified Fuel Elements for ETR," IDO-16465, November 7, 1958.
- 5.. Krause, P. S., "SM-2 Single Element Final Test Report," APAE Memo No. 267, October 28, 1960.