12
7-24-99 JS(1)

PNL-8179

UC-350

An Energy Equivalency Analysis of Trade-Offs Between Thermal Efficiency and Standby Loss Requirements for Commercial Gas Service Water Heaters

S. Somasundaram
R. E. Jarnagin
J. M. Keller
J. S. Schliesing

June 1992

Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute

Received OSTI

JUL 24 1992

PNL-8179

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any **warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

Printed in the United States of America

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831;
prices available from (615) 576-8401. FTS 626-8401.

Available to the public from the National Technical Information Service,
U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

AN ENERGY EQUIVALENCY ANALYSIS OF TRADE-OFFS
BETWEEN THERMAL EFFICIENCY AND STANDBY LOSS
REQUIREMENTS FOR COMMERCIAL GAS SERVICE WATER
HEATERS

S. Somasundaram
R. E. Jarnagin
J. M. Keller
J. S. Schliesing

June 1992

Prepared for
the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

EP

SUMMARY

The American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE) Standing Standard Project Committee 90.1 has approved an addendum (90.1b) to *ASHRAE/IES Standard 90.1-1989*. The addendum specifies an increase in the minimum thermal efficiency requirement (from 77% to 78%), accompanied by an easing of the standby loss requirements, for commercial gas-fired service water heaters.

The Pacific Northwest Laboratory performed an energy equivalency analysis to assess the impact of trade-offs between the improved thermal efficiency and the less stringent standby loss requirements. The analysis objective was to estimate whether the energy savings during firing would offset the increased energy losses during standby periods.

The analysis results indicate that energy equivalency for lower firing-rate units (<155,000 Btu/h) is achieved if the firing times are between 5 and 9 h per day. Energy equivalency for the higher firing-rate units (inputs >200,000 Btu/h) is achieved at considerably lower daily firing times (1.5 to 3.5 h). If the minimum thermal efficiency is increased to 79%, energy equivalency for the lower firing-rate units occurs at 3 to 5 h of firing time. A further increase in thermal efficiency to 80% results in energy equivalency at 2 to 4 h of firing time for the same units. However, the lower firing-rate units represent only one quarter of the annual shipments.

Based on a description of the weighted average firing times, a total of 70% of the shipments (firing rates of $\leq 200,000$ Btu/h) would be energy-equivalent if the average firing times for all applications across the industry were at least 4 h. While some applications would meet or exceed the 4-h requirement, others clearly would not. The effect of lowering the temperature difference between the ambient and the hot water in the storage tank or raising the thermal efficiency of the water heater is to reduce the number of firing hours required for energy equivalency.

Published water heater sizing and usage criteria, as well as metered end-use data, indicate that median values for firing times range from 2 to 6 h per day for various commercial building types. The commercial building energy

consumption data also show that hot water energy use is quantitatively similar for both the office building stock and the food service industry.

Based on this study and the U.S. Department of Energy mandate for achieving maximum practicable energy-use efficiency in equipment standards, the recommended minimum thermal efficiency requirement is 80% for commercial gas-fired service water heaters. Together with the standby loss criteria (as approved in Addendum 90.1b), this requirement would ensure that the entire stock of units is designed and used in the most energy-efficient manner possible.

CONTENTS

SUMMARY	iv
1.0 INTRODUCTION	1
2.0 ANALYSIS	3
2.1 METERED DATA ANALYSIS	5
2.2 SIZING METHODOLOGY	6
3.0 RESULTS	11
4.0 DISCUSSION	17
4.1 SENSITIVITY ANALYSES	17
4.1.1 Effect of Changing ΔT	17
4.1.2 Effect of Changing Thermal Efficiency Requirements . .	17
4.2 INDUSTRY SHIPPING DATA	18
4.3 WEIGHTED AVERAGE FIRING TIMES	18
4.4 OVERALL ENERGY CONSUMPTION OF HOT WATER	19
4.5 STANDBY LOSS DEFINITION	19
5.0 SUMMARY OF RESULTS	21
6.0 RECOMMENDATIONS	23
7.0 REFERENCES	25
APPENDIX A - FIRING TIME DATA DETAILS	A.1
APPENDIX B - SIZING METHODOLOGY DETAILS	B.1
APPENDIX C - ENERGY EQUIVALENCY ANALYSIS DETAILS	C.1

FIGURES

1	Comparison of Current and Proposed Standby Loss Criteria for Gas-Fired Service Water Heaters	4
2	Net Daily Energy Savings as a Function of the Firing Times for Gas-Fired Service Water Heaters	14
3	Firing Times for Equivalent Energy at Different Thermal Efficiencies	15
4	Firing Times for Equivalent Energy at Different Thermal Efficiencies and Standby Loss Formulas	16
A.1	Firing Times for Electric Water Heaters in Office Buildings	A.1
A.2	Firing Times for Electric Water Heaters in Restaurants	A.1
A.3	Firing Times for Electric Water Heat in Retail Buildings	A.2
A.4	Firing Times for Electric Water Heaters in Grocery Stores	A.2
A.5	Firing Times for Electric Water Heaters in Warehouses	A.3

TABLES

1	Performance Requirements for Commercial Gas Water Heaters	4
2	Hot Water Use Derived from ELCAP Data	6
3	Sizing Data for Different Commercial Building Types	8
4	Equivalent Energy Comparison - Gas Water Heaters	12
5	Equivalent Energy Comparison - Gas Water Heaters	13
C.1	Changes in Hourly Standby Loss Requirements	C.2

1.0 INTRODUCTION

The Standing Standard Project Committee (SSPC) 90.1 of ASHRAE was responsible for developing *ASHRAE/IES Standard 90.1-1989*, "Energy Efficient Design of New Buildings Except Low-Rise Residential Buildings," hereinafter referred to as the Standard. Section 11 of the Standard specifies minimum energy-efficiency requirements for commercial service water heaters (SWH).

When the Standard was undergoing public review, the Gas Appliance Manufacturers Association (GAMA) commented that the Standard was too restrictive with respect to the 1992 standby loss requirements for the gas-fired units with low firing rates. Representatives of GAMA's Water Heater Division presented a proposal to the SWH Task Group of ASHRAE SSPC 90.1 that represented an easing of the standby loss requirements while increasing the thermal efficiency of large gas-fired units. This proposal was extensively discussed and a negotiated agreement published as Addendum 90.1b (hereinafter referred to as the Addendum) to the Standard.

The proposal results in improved energy efficiency during firing at the expense of greater energy loss during standby. The Addendum provides for a standby loss requirement of $(1.3 + 114/V)$ in percent per hour for gas water heaters with firing rates of 155,000 Btu/h or less, and $(1.3 + 95/V)$ in percent per hour for firing rates greater than 155,000 Btu/h, where V is the actual storage volume in gallons.

The technical analysis reported herein was undertaken by Pacific Northwest Laboratory (PNL) researchers as a part of the technical analysis and demonstration phase of the Building Energy Standards Program for the U.S. Department of Energy (DOE). The analysis was to assess the energy equivalency between the reduction of the standby loss requirements and the increase in the thermal efficiency level for gas-fired service water heaters.

The primary focus of this report is to summarize the major results of the analysis and provide a recommendation for minimum energy-efficiency commercial gas-fired service water heaters. Limitations to the availability of detailed performance and energy-use data for these commercial water heaters are also pointed out.

This report contains seven sections and three appendixes. In Section 2, the details of the analysis method are presented. The major results of the energy equivalency analysis to obtain the relative firing times of units with different input rates are presented in Section 3. A detailed discussion of the results and the various limitations of the analysis (Section 4) is followed by the conclusions in Section 5. The recommended minimum energy-efficiency requirement for commercial gas-fired service water heaters is given in Section 6. The references in Section 7 are followed by Appendixes A through C. These provide, respectively, the details of the metered data analysis, sizing methodology, and energy equivalency analysis.

2.0 ANALYSIS

The main difference between the requirements in the Standard that became effective on January 1, 1992, and the proposed Addendum for gas- and oil-fired storage water heaters is the reduction in the standby loss requirements accompanied by an increase in the thermal efficiency requirements. While DOE has developed its own standards, the California Energy Commission (CEC) has essentially adopted the ASHRAE standards for hot water equipment. For illustrative purposes, the current DOE, ASHRAE, and CEC standby loss requirements are plotted against those of the Addendum in Figure 1. The preceding ASHRAE (and CEC) requirements entailed a thermal efficiency of 76% and a standby loss requirement of $(2.3 + 67/V)$, which are also shown in Figure 1. The current thermal efficiency and standby loss criteria for DOE, ASHRAE, and CEC standards are as shown in Table 1.

An equivalent energy analysis was performed to compare the effects of the trade-offs between thermal efficiency and standby loss. This comparison balanced the energy savings resulting from a single percentage point increase in thermal efficiency during the cumulative firing periods of the water heater against the energy losses caused by the less stringent standby loss requirements during the cumulative standby periods.

The critical issue for this type of comparison is the length of time the water heater is in a standby (non-firing) mode versus that in a firing mode during a 24-h day. The amount of time available to each condition depends upon the nature (magnitude and type of use) and schedule (time of demand) of the commercial end user for the water heater. Because the firing times depended on actual conditions of use of a given water heater, field performance data that would provide some measure of water heater usage were of interest. In addition to the metered data analysis, another method of determining firing times is described in Section 2.2. The method uses prescribed sizing procedures in water heater manufacturers' catalogs to supply building hot water loads. The hot water requirement information was obtained for standard commercial building types.

FIGURE 1. Comparison of Current and Proposed Standby Loss Criteria for Gas-Fired Service Water Heaters

TABLE 1. Performance Requirements for Commercial Gas Water Heaters

	Standby Loss (% per hour)	Thermal Efficiency
DOE	$1.3 + 38/V$	77%
ASHRAE 90.1	$1.3 + 38/V$	77%
CEC	$1.3 + 38/V$	77%
ASHRAE Addendum 90.1b	$1.3 + 114/V^{(a)}$ ($\leq 155,000$ Btu/h)	78%
	$1.3 + 95/V$ ($> 155,000$ Btu/h)	78%

(a) Actual storage volume in gal; other Vs are rated (nameplate) volumes in gal.

2.1 METERED DATA ANALYSIS

One source of metered data reflecting commercial building energy performance is the Bonneville Power Administration (BPA) End-Use Load and Consumer Assessment Program (ELCAP) (Pratt et al. 1990). Electricity consumption data for hot water equipment are available in the ELCAP data set for a number of commercial buildings. Data for different types of commercial buildings were examined to determine the length of time per day that the buildings' water heaters were in use. ELCAP hot water and end-use load data were available for electric water heaters only. Consequently, buildings with gas water heaters were excluded from the firing time analysis.

The results from the ELCAP data analysis are shown in Table 2. The table contains a list of the building types, the number of buildings in the data set, and the calculated firing times for each of the building types. Firing times were calculated for each building for which complete, year-round metered data were available by dividing each building's average annual hot water energy consumption (in watt-hours) by the peak measured hot water load (in watts) for that building, and then dividing that quotient by the number of days in a year. The mean, median, minimum, and maximum firing times observed in the data set represented by each building type were also determined.

The results displayed in Table 2 reveal that the mean observed firing times vary from 1.95 h to 5.67 h among the different building types. Note that the mean firing times are never less than the median firing times. Substantial differences between the observed mean and median values can suggest some skewing of the data. The variation in individual building data for the different building types is shown in Appendix A, with the 25th, 50th, and 75th percentile lines also shown. The figures in this appendix suggest that, in some cases (such as the office and retail), the median values (50th percentile line) are more representative of the typical firing times because the mean values are strongly influenced by a few extreme outliers in the data set. As shown in Table 2, the median firing time for office building water heaters was 1.8 h/day, while that for restaurants was 3.5 h/day.

TABLE 2. Hot Water Use Derived from ELCAP Data

<u>Building Type</u>	<u>No. of Buildings</u>	<u>Firing Time, hours per day</u>			
		<u>Mean</u>	<u>Median</u>	<u>Min</u>	<u>Max</u>
Office	20	3.04	1.79	0.62	12.53
Restaurant	6	4.34	3.51	2.57	9.29
Retail	17	1.95	1.38	0.23	8.84
Grocery	12	4.80	3.94	1.48	9.66
Warehouse	10	1.96	1.89	0.46	3.71
Hotel	2	3.30	3.30	3.29	3.30
School	1	5.67	5.67	5.67	5.67
University	1	3.97	3.97	3.97	3.97
Other	2	1.95	1.95	0.87	3.03

2.2 SIZING METHODOLOGY

An alternative method of determining firing times was to size the water heaters for different types of commercial buildings and then match them to the building hot water loads, as would be done by the end user. The water heater sizing was done for the different commercial building types using manufacturers' catalogs, so that the units' firing times could be obtained based on the building hot water requirements prescribed by the ASHRAE Handbook (ASHRAE 1987). For the building types designated as apartments, general purpose, and hotel/motels, the sizing was done according to guidelines in three catalogs: A. O. Smith (1989), Rheem (1988), and Bock (1989). The efficiency of the units was assumed to be 77% (minimum as per the standard) unless otherwise stated in the catalog. Many of the larger units, both gas and oil, have stated efficiencies of 80%. The hot water required was based on the average day column of Table 1 of the Handbook (ASHRAE 1987).

Estimated firing times can be determined using the manufacturers' sizing data and the ASHRAE building hot water requirements by performing an energy balance on the water heater.

An energy balance between the energy input to the water and the amount of stored energy in the tank yields the following relation:

$$\begin{aligned} &\text{Firing Time (h)} * \text{Firing Rate (Btu/h)} * \text{Efficiency (\%)} = \\ &\text{Volume of Hot Water (gal)} * \text{Density of Hot Water (lb/gal)} * \text{Specific} \\ &\text{Heat (Btu/lb-}^\circ\text{F)} * \text{Temp. Rise (}^\circ\text{F)} \end{aligned}$$

after neglecting the standby loss of the water heater because it is less than 5% of the stored energy. The firing time of the unit, in hours, can then be determined by rearranging the above relation as

$$\text{Firing Time} = \frac{(\text{Gal Req'd} * 8.25 \text{ lb/gal}) * C_p * \Delta T (= 90^\circ\text{F})}{(\text{Firing Rate, Btu/h}) * \text{Efficiency}}$$

where C_p is the specific heat of water and is assumed to be 1.0 Btu/lb $^\circ$ F.

The details of the sizing calculations are shown in Appendix B for each of the building types considered. The results of the firing time calculations for the different commercial building types are given in Table 3. It should also be pointed out that several of the units considered for this sizing analysis already had a listed thermal efficiency of 80%.

For the apartments, a comparison of the firing times for the three manufacturers shows that units sized using the A. O. Smith guidelines have the highest firing times, while Rheem's have the lowest, and Bock's are somewhere in between (see Table 3). The general-purpose sizing was somewhat more difficult because the manufacturers did not seem to specifically deal with office building types. Rheem suggests using the school tables without the showers, while A. O. Smith suggests using a 1-h peak period. Therefore, the Rheem catalog was used to size the load as closely as possible, while the A. O. Smith unit was sized using the "1-h availability" table for demand without attempting to meet any storage requirements. The gallons required were based on the 0.4 gal/h/person number in the Handbook (ASHRAE 1987). The firing times do seem to be a little higher than they are in some of the other building types.

TABLE 3. Sizing Data for Different Commercial Building Types

Building Type (Units)	No. of People	Mfr.	Model No.	No.	Size, sq ft	R.Cap, gal/h	Fir. Rate, Btu/h	Eff.	Gal. Reqd	Firing Time, h/unit
Apartment (20)	50	A. O. Smith	BT-80	2	75	88	75,100	77%	840	5.99
	50	Boek	100G-180	1	100	191	199,900	77%	840	4.50
	50	Rheem	RFD300-92	1	92	291	300,000	80%	840	2.89
Apartment (50)	125	A. O. Smith	BT-197	2	100	191	197,000	80%	2,000	5.23
	125	Boek	500G	1	80	455	500,000	77%	2,000	4.29
	125	Rheem	GD800-77	1	77	545	600,000	77%	2,000	3.57
Apartment (100)	250	Boek	350G	3	75	318	350,000	77%	3,700	3.78
	250	Rheem	RD400-86	4	86	384	399,900	77%	3,700	2.48
	250	A. O. Smith	BTC-240	3	100	232	240,000	80%	3,700	5.30
Gen. Purpose (25,700 sq.ft.)	250	Rheem	RF120-87	1	87	109	120,000	77%	250	2.23
	250	A. O. Smith	BT-86	1	50	45	50,000	77%	250	5.36
Gen. Purpose (50,000 sq.ft.)	500	A. O. Smith	BT-100	1	100	72	80,000	77%	500	6.70
	500	Rheem	RFD156-82	1	82	151	156,000	80%	500	3.31
Gen. Purpose (100,000 sq.ft.)	1,000	Rheem	RD380-72	1	72	328	360,000	77%	1,000	2.98
	1,000	A. O. Smith	BT-199	1	98	179	199,000	77%	1,000	5.38
Gen. Purpose (500,000 sq.ft.)	5,000	Rheem	RD400-86	4	86	384	399,900	77%	5,000	3.35
	5,000	A. O. Smith	BTP-540	2	89	519	540,000	80%	5,000	4.77
Building Type	No. of Rooms	Mfr.	Model No.	No.	Size, sq ft	R.Cap, gal/h	Fir. Rate Btu/h	Eff.	Gal. Reqd	Firing Time, h/unit
Hotel/Motel * Assumes 2-h peak and * 1.5 persons per room	20	A. O. Smith	BT-80	2	75	88	75,100	77%	400	2.95
	20	A. O. Smith	BT-86	3	50	45	50,000	77%	400	2.88
	80	A. O. Smith	BTP-140	3	86	134	140,000	80%	840	2.08
	80	A. O. Smith	BTC-179	3	86	188	179,000	77%	840	1.87
	80	A. O. Smith	BT-199	3	86	179	199,000	77%	840	1.51
	100	A. O. Smith	BT-197	3	100	191	197,000	80%	1,000	1.74
	100	A. O. Smith	BTP-140	4	86	134	140,000	80%	1,000	1.84
	100	A. O. Smith	BT-86	4	50	45	50,000	77%	400	2.14
* Assumes 1-h peak	20	A. O. Smith	BTP-140	2	86	134	140,000	80%	400	1.47
	80	A. O. Smith	BT-251	3	84	243	251,000	80%	840	1.15
	80	A. O. Smith	BTP-270	3	86	259	270,000	80%	840	1.07
	80	A. O. Smith	BTC-240	3	100	232	240,000	80%	840	1.20
	100	A. O. Smith	BT-197	4	100	191	197,000	80%	1,000	1.31
	100	A. O. Smith	BT-251	4	84	243	251,000	80%	1,000	1.03
	100	A. O. Smith	BTP-270	4	86	259	270,000	80%	1,000	0.95
	100	A. O. Smith	BTP-270	4	86	259	270,000	80%	1,000	0.95
Building Type	Max. Meals ^(a)	Mfr.	Model No.	No.	Size, sq ft	R.Cap, gal/h	Fir. Rate, Btu/h	Eff.	Gal. Reqd ^(b)	Firing Time, h/unit
Food Service * Assume 3-h peak during which 80% of the meals are served	80	A. O. Smith	BT-86	1	50	45	50,000	77%	240	5.14
	96	A. O. Smith	BT-86	1	50	45	50,000	77%	380	8.14
	120	A. O. Smith	BT-86	1	50	45	50,000	77%	480	10.29
	250	A. O. Smith	BT-155	1	89	139	155,000	77%	1,000	6.91
	250	A. O. Smith	BTP-140	1	86	134	140,000	80%	1,000	7.37
	250	A. O. Smith	BTC-154	1	89	146	154,000	78%	1,000	6.87
	326	A. O. Smith	BTC-154	1	89	146	154,000	78%	1,300	8.93
	326	A. O. Smith	BTP-140	1	86	134	140,000	80%	1,300	9.58
	326	A. O. Smith	BT-155	1	89	139	155,000	77%	1,300	8.99
	326	A. O. Smith	BT-199	1	86	179	199,000	77%	1,340	7.21
	335	A. O. Smith	BTC-179	1	86	188	179,000	77%	1,340	7.98
	335	A. O. Smith	BTP-199	1	86	191	199,000	80%	1,340	8.94
	490	A. O. Smith	BTC-240	1	100	232	240,000	80%	1,980	8.42
	490	A. O. Smith	BTP-270	1	86	259	270,000	80%	1,980	7.49
	490	A. O. Smith	BT-270	1	100	243	270,000	77%	1,980	7.78
	650	A. O. Smith	BTP-370	1	75	355	370,000	80%	2,600	7.25
	650	A. O. Smith	BT-385	1	75	329	365,000	77%	2,600	7.83
	750	A. O. Smith	BTP-370	1	75	355	370,000	80%	3,000	8.36
	750	A. O. Smith	BT-500	1	89	450	500,000	77%	3,000	6.43
	900	A. O. Smith	BTP-540	1	89	370	540,000	80%	3,600	6.88

(a) Maximum Meals is directly from A. O. Smith catalog.

(b) Based on an assumption of 2.4 gal hot water required per meal served.

The hotel/motel sizing was done strictly from the A. O. Smith catalog, as it was the only one to offer any guidance. The number of rooms was chosen to match the values in Table 1 of the Handbook, and multiple choices of models are shown for illustrative purposes. The A. O. Smith guideline suggests a 2-h peak period, except when the hotel/motel has convention facilities or is located near an interstate highway, then it has only a 1-h peak.

The gallons required are from Table 1 of the Handbook for the number of units specified and an average day's usage. The firing times seem relatively low for all the sizes and types of water heaters.

In the case of the food service industry, the sizing appears to be extremely design-dependent. Most restaurants use a two-heater system: one for general purpose 140°F water and another to boost the temperature to 180°F for the dishwasher. Another less frequently used method is to employ a mixing valve where all the water is heated to 180°F and the required amount of general purpose water is mixed with cold water to reduce the temperature to 140°F. The 180°F water is often translated into equivalent 140°F water for sizing purposes. Only the A. O. Smith catalog was used for this building type because it was the only one offering a sizing method without any knowledge of the dishwasher being used. The maximum number of meals served was assumed to be 60% of the average number per day because the A. O. Smith catalog stated that 60% of the daily hot water was being used during the combined peak period. The gallons required are obtained by multiplying the average number of meals served by 2.4 gal/average meal/day number in the Handbook (ASHRAE 1987). Of all the building types considered here, only those in the food service industry exhibit firing times that may be in the 6- to 8-h range for which energy equivalency will be valid, even for lower firing-rate units (<155,000 Btu/h), as discussed in Section 3. There is a wide variation of the firing times spread over the different sizes and models considered. The restaurant with the highest firing time (10.29 h) has the same size heater recommended as the one with the lowest firing time (5.14 h). Obviously, there is no single method to exactly size a water heater for every given application. This results in oversizing or undersizing of the unit to some extent. Therefore, the magnitudes of the firing time versus the standby time

become especially important for characterizing the water heater performance under different operating conditions.

A comparison of the firing time data based on the sizing guidelines shows that general purpose (office building) water heaters have a median value of 4.1 h/day, whereas for the food service industry it is 7.6 h/day. These are, however, more than double the values from the ELCAP data discussed earlier. A reason for the discrepancy may be in the fact that sizing guidelines based on manufacturers' catalogs were matched with estimates of hot water requirements from the ASHRAE Handbook, and that may not yield the optimum water heater sizes for the different building types. On the other hand, ELCAP data are based on actual measured energy-use data. To compare the total energy use for hot water in office buildings and the food service industry, an estimate was made based on nationwide survey data for nonresidential buildings (Energy Information Administration 1989) (see Section 4.4).

3.0 RESULTS

Based on the reference data for storage water heater firing times, the equivalent energy comparison analysis was done for different firing rates of the various models available in the market (see Tables 4 and 5). Assuming the thermal efficiency to be 77%, the energy input to the water for an hour of firing was obtained by multiplying the firing rate by the efficiency figure (Table 4, Column B). For the same energy input to the water, the more efficient unit (thermal efficiency of 78%) will require less energy input to the unit. This is obtained by dividing the energy input to the water by 0.78 (Column C). The difference between the two input rates is the hourly savings (energy credit, Column D). Columns F through H account for the different standby loss criteria (standby energy loss in percent per hour multiplied by the magnitude of the stored energy, Column E) that are applicable in the Standard and the Addendum for a reference ΔT (temperature difference between the ambient and the steady-state hot water temperature) of 90°F. These values are essentially independent of the storage volume of the water heaters, as shown in Appendix C. The difference of allowable standby loss between the Standard and the Addendum is the energy debit (negative number) to the whole scheme and is given within parentheses in Column I.

The values in Columns M through T (Table 5) were obtained by totaling the energy "credits" (hourly credit in Column D multiplied by the number of hours in a day that the unit is firing) and the energy "debits" (hourly debit in Column I multiplied by the number of hours during which the unit is on standby, which is the number of firing hours subtracted from 24 hours in a day). The net negative values are given in parentheses, which implies that the tradeoff in the Addendum is less restrictive than before. An example calculation of the equivalent energy comparison is given in Appendix C.

Referring to Figure 2, the number of hours of firing time at which the daily energy savings becomes zero (or changes sign) is the minimum value at which the energy equivalency is achieved (for a given firing rate). These hours of firing times for energy equivalency are also shown in Column U of Table 5 for different firing rates. Based on the discussion of ELCAP and sizing data analysis, office buildings with lower firing-rate water heaters

TABLE 4. Equivalent Energy Comparison - Gas Water Heaters

Firing Rate Btu/h	Input to Water @ 77%, Btu	Input to Unit @ 78%, Btu	Hourly Savings	Stored Energy, Btu	-- Hourly Standby Energy Loss -- 1.3+38/V	1.3+114/V	1.3+95/V	Change in Hourly Standby Loss
(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I)
75,000	57,750	74,038	962	70,538	1,185	1,763		(578) (a)
80,000	61,600	78,974	1,026	70,538	1,185	1,763		(578)
85,000	65,450	83,910	1,090	70,538	1,185	1,763		(578)
90,000	69,300	88,846	1,154	70,538	1,185	1,763		(578)
100,000	77,000	98,718	1,282	70,538	1,185	1,763		(578)
105,000	80,850	103,654	1,346	70,538	1,185	1,763		(578)
110,000	84,700	108,590	1,410	70,538	1,185	1,763		(578)
115,000	88,550	113,526	1,474	70,538	1,185	1,763		(578)
120,000	92,400	118,462	1,538	70,538	1,185	1,763		(578)
125,000	96,250	123,397	1,603	70,538	1,185	1,763		(578)
130,000	100,100	128,333	1,667	70,538	1,185	1,763		(578)
135,000	103,950	133,269	1,731	70,538	1,185	1,763		(578)
140,000	107,800	138,205	1,795	70,538	1,185	1,763		(578)
145,000	111,650	143,141	1,859	70,538	1,185	1,763		(578)
150,000	115,500	148,077	1,923	70,538	1,185	1,763		(578)
155,000	119,350	153,013	1,987	70,538	1,185	1,763		(578)
160,000	123,200	157,949	2,051	70,538	1,185		1,622	(437)
165,000	127,050	162,885	2,115	70,538	1,185		1,622	(437)
170,000	130,900	167,821	2,179	70,538	1,185		1,622	(437)
175,000	134,750	172,756	2,244	70,538	1,185		1,622	(437)
180,000	138,600	177,692	2,308	70,538	1,185		1,622	(437)
185,000	142,450	182,628	2,372	70,538	1,185		1,622	(437)
190,000	146,300	187,564	2,436	70,538	1,185		1,622	(437)
195,000	150,150	192,500	2,500	70,538	1,185		1,622	(437)
200,000	154,000	197,436	2,564	70,538	1,185		1,622	(437)
220,000	169,400	217,179	2,821	70,538	1,185		1,622	(437)
240,000	184,800	236,923	3,077	70,538	1,185		1,622	(437)
260,000	200,200	256,667	3,333	70,538	1,185		1,622	(437)
280,000	215,600	276,410	3,590	70,538	1,185		1,622	(437)
300,000	231,000	296,154	3,846	70,538	1,185		1,622	(437)
320,000	246,400	315,897	4,103	70,538	1,185		1,622	(437)
340,000	261,800	335,641	4,359	70,538	1,185		1,622	(437)
360,000	277,200	355,385	4,615	70,538	1,185		1,622	(437)
380,000	292,600	375,128	4,872	70,538	1,185		1,622	(437)
400,000	308,000	394,872	5,128	70,538	1,185		1,622	(437)
420,000	323,400	414,615	5,385	70,538	1,185		1,622	(437)
440,000	338,800	434,359	5,641	70,538	1,185		1,622	(437)
460,000	354,200	454,103	5,897	70,538	1,185		1,622	(437)
480,000	369,600	473,846	6,154	70,538	1,185		1,622	(437)
500,000	385,000	493,590	6,410	70,538	1,185		1,622	(437)

(a) Numbers shown in parentheses represent net energy loss.

($\leq 155,000$ Btu/h) will not be energy-equivalent, whereas those with rates of $>200,000$ Btu/h do become energy-equivalent. With respect to the food service industry, the units with firing times in the range of 6 to 8 h will be energy-equivalent, even for the lower firing rates.

TABLE 5. Equivalent Energy Comparison - Gas Water Heaters

Firing Rate, Btu/h	Net Daily Savings from Change Based on Firing Time in Hours Per Day, Btu/day								Hours for Energy Equivalency
	0	4	6	8	10	12	14	24	
(A)	(M)	(N)	(O)	(P)	(Q)	(R)	(S)	(T)	(U)
75,000	(13,882) ^(a)	(7,722)	(4,642)	(1,562)	1,518	4,598	7,677	23,077	9.01
80,000	(13,882)	(7,466)	(4,257)	(1,049)	2,159	5,367	8,575	24,615	8.65
85,000	(13,882)	(7,209)	(3,873)	(537)	2,800	6,136	9,472	26,154	8.32
90,000	(13,882)	(6,953)	(3,488)	(24)	3,441	6,905	10,370	27,692	8.01
100,000	(13,882)	(6,440)	(2,719)	1,002	4,723	8,444	12,165	30,769	7.46
105,000	(13,882)	(6,184)	(2,334)	1,515	5,364	9,213	13,062	32,308	7.21
110,000	(13,882)	(5,927)	(1,950)	2,028	6,005	9,982	13,960	33,846	6.98
115,000	(13,882)	(5,671)	(1,565)	2,540	6,646	10,751	14,857	35,385	6.76
120,000	(13,882)	(5,414)	(1,181)	3,053	7,287	11,521	15,754	36,923	6.56
125,000	(13,882)	(5,158)	(796)	3,566	7,928	12,290	16,652	38,462	6.36
130,000	(13,882)	(4,901)	(411)	4,079	8,569	13,059	17,549	40,000	6.18
135,000	(13,882)	(4,645)	(27)	4,592	9,210	13,828	18,447	41,538	6.01
140,000	(13,882)	(4,389)	358	5,104	9,851	14,598	19,344	43,077	5.85
145,000	(13,882)	(4,132)	743	5,617	10,492	15,367	20,242	44,615	5.70
150,000	(13,882)	(3,876)	1,127	6,130	11,133	16,136	21,139	46,154	5.55
155,000	(13,882)	(3,619)	1,512	6,543	11,774	16,905	22,036	47,692	5.41
160,000	(10,496)	(542)	4,436	9,413	14,390	19,367	24,345	49,231	4.22
165,000	(10,496)	(285)	4,820	9,926	15,031	20,137	25,242	50,769	4.11
170,000	(10,496)	(29)	5,205	10,439	15,672	20,906	26,139	52,308	4.01
175,000	(10,496)	228	5,590	10,951	16,313	21,675	27,037	53,846	3.92
180,000	(10,496)	484	5,974	11,464	16,954	22,444	27,934	55,385	3.82
185,000	(10,496)	741	6,359	11,977	17,595	23,214	28,832	56,923	3.74
190,000	(10,496)	997	6,743	12,490	18,236	23,983	29,729	58,462	3.65
195,000	(10,496)	1,253	7,128	13,003	18,877	24,752	30,627	60,000	3.57
200,000	(10,496)	1,510	7,513	13,516	19,518	25,521	31,524	61,538	3.50
220,000	(10,496)	2,535	9,051	15,567	22,082	28,598	35,114	67,692	3.22
240,000	(10,496)	3,561	10,590	17,618	24,647	31,675	38,704	73,846	2.99
260,000	(10,496)	4,587	12,128	19,669	27,211	34,752	42,293	80,000	2.78
280,000	(10,496)	5,612	13,666	21,721	29,775	37,829	45,883	86,154	2.61
300,000	(10,496)	6,638	15,205	23,772	32,339	40,906	49,473	92,308	2.45
320,000	(10,496)	7,664	16,743	25,823	34,903	43,983	53,063	98,462	2.31
340,000	(10,496)	8,689	18,282	27,874	37,467	47,060	56,652	104,615	2.19
360,000	(10,496)	9,715	19,820	29,926	40,031	50,137	60,242	110,769	2.08
380,000	(10,496)	10,741	21,359	31,977	42,595	53,214	63,832	116,923	1.98
400,000	(10,496)	11,766	22,897	34,028	45,159	56,290	67,422	123,077	1.89
420,000	(10,496)	12,792	24,436	36,080	47,723	59,367	71,011	129,231	1.80
440,000	(10,496)	13,817	25,974	38,131	50,288	62,444	74,601	135,385	1.73
460,000	(10,496)	14,843	27,513	40,182	52,852	65,521	78,191	141,538	1.66
480,000	(10,496)	15,869	29,051	42,233	55,416	68,598	81,781	147,692	1.59
500,000	(10,496)	16,894	30,590	44,285	57,980	71,675	85,370	153,846	1.53

(a) Figures shown in parentheses represent net energy loss.

Under those circumstances, the net daily energy savings would increase (or the net daily energy loss would decrease) because the standby losses would now occur across a lower value of ΔT . This would, in turn, reduce the number of firing hours required for energy equivalency (by about an hour for firing rates <155,000 Btu/h), assuming all other conditions remained the same.

FIGURE 2. Net Daily Energy Savings as a Function of the Firing Times for Gas-Fired Service Water Heaters

The minimum firing times for equivalent energy between the increase in thermal efficiency and the relaxing of standby loss requirements as a function of the thermal efficiency (79% and 80%) were also evaluated. The results are displayed in Figure 3, which shows the reduction in necessary firing time as the thermal efficiency requirement on the water heater is increased from 78% to 79% and further to 80%. The resulting firing times, especially for the lower firing-rate units, are closer to the field performance data (ELCAP) for water heaters as discussed in Section 2.1. The asymptotic portion of the curve for the larger firing rate units can be extended back to the lower firing rates as well (see Figure 4), if the same standby loss criterion ($1.3 + 95/V$) were used instead of switching to a further relaxation of the standby loss requirement of ($1.3 + 114/V$) at the lower firing rates. This would further improve the situation by lowering the firing time required for energy equivalency.

FIGURE 3. Firing Times for Equivalent Energy at Different Thermal Efficiencies

FIGURE 4. Firing Times for Equivalent Energy at Different Thermal Efficiencies and Standby Loss Formulas

4.0 DISCUSSION

In addition to discussing the details of the results, this section contains the elaboration of certain practical issues including the industry shipping data of water heaters, weighted firing times, overall energy consumption for hot water, and the definition of the standby loss.

4.1 SENSITIVITY ANALYSES

Having completed the energy equivalency analysis for the proposed requirements, certain sensitivity analyses were carried out to determine the effect of changing the variables on the firing times required for energy equivalency.

4.1.1 Effect of Changing ΔT

The standard value (specified by the test procedure) of the temperature difference (ΔT) between the ambient and the hot water in the storage tank is assumed to be 90°F. This is the value used to determine the magnitude of the stored energy in the tank for calculating the changes in the standby loss requirements. If, instead, the water heater were placed in a conditioned space, the value of ΔT would be closer to 70°F (assuming that the design water temperature remained at 140°F and the ambient temperature was now at 70°F).

4.1.2 Effect of Changing Thermal Efficiency Requirements

The proposed minimum thermal efficiency requirement for commercial gas-fired water heaters is set at 78%. However, if we assumed that it were raised to 80% while retaining the proposed standby loss requirements, then the length of firing times required for energy equivalency would be reduced. This would imply that even the lower firing-rate units (<155,000 Btu/h) would be rendered energy-equivalent at 2 to 4 h of firing time, and that this would cover the entire gamut of commercial building types with regard to energy efficiency in water heater performance.

4.2 INDUSTRY SHIPPING DATA

To put the energy equivalency analysis in context, it is important to know the relative number of units in each firing range that are being shipped by the industry. The preferred approach would provide information on the number of units actually installed. However, for commercial units, shipping data are the only data readily available. If the assumption is made that distributors are not increasing inventories of commercial units, then the shipping data from the industry represent a good surrogate for the installation data.

Based on information supplied by the Gas Appliance Manufacturers Association (GAMA), the industry shipped approximately 99,000 commercial water heaters in 1990. The approximate breakdown of units by input rate is shown below:

<u>Input, kBtu/h</u>	<u>Percentage of Total Shipments</u>
> 75 and ≤ 155	25%
>155 and ≤ 200	45%
>200 and <500	24%
>500	6%

Comparing information to the results shown in Table 5 indicates that approximately 70% of the shipments have input rates that reach energy equivalency in 3.6 to 9.0 h of firing. Results from the ELCAP data shown in Table 2 indicate that the median daily firing times for most building types are less than this range. The ELCAP data represent firing times for electric service water heaters; however, the firing times for gas water heaters should not differ significantly from similarly sized electric water heaters. Assuming similar firing times for gas and electric water heaters, the ELCAP data would suggest that the agreement between standby loss and thermal efficiency requirements is not energy-equivalent.

4.3 WEIGHTED AVERAGE FIRING TIMES

Combining the industry shipping data with the energy savings analysis

provides another assessment of the energy equivalency issue. An implicit assumption in this approach is that the distribution of firing rates is relatively uniform within a specific size category. Using this assumption, it is possible to calculate the average hours for energy equivalency by shipment category using the data from Tables 4 and 5. For the three categories that constitute 94% of all units shipped, the average hours for equivalency are as follows:

<u>Input, kBtu/h</u>	Percentage of <u>Total Shipment</u>	<u>Equivalency Hours</u>
>75 and ≤155	25%	6.73
>155 and ≤200	45%	3.84
>200 and <500	24%	2.33

The data shown above may be combined by applying the shipment percentage to the equivalency hours and then summing across all input rates. This yields an average-shipment-weighted firing time of 3.95 h for energy equivalency. This result suggests that for the agreement to be energy-equivalent, the average firing times for all applications across the industry would have to be approximately 4 h or greater. Although some applications would meet or exceed the 4-h requirement, others clearly would not. The ELCAP data indicate that for offices, retail, warehouses, and some hotels and restaurants, the typical daily firing times are below the 4-h requirement.

4.4 OVERALL ENERGY CONSUMPTION OF HOT WATER

National data on commercial energy end use can be used to assess the potential impact of service hot water energy consumption. A major national data set for commercial building energy-use data was based on Nonresidential Buildings Energy Consumption Survey (NBECS) data (Energy Information Administration 1989) for different building types. The survey data (1980-1986) show that the office buildings comprising 27.8% of the total commercial building stock have over 2.5 billion square feet of total area, while the food

service industry has over 350 million square feet of area (3.9% of total building stock). Using the occupancy density values and the service hot water requirements data from the Standard (Tables 13-2 and 13-7, respectively) for the two building types, the total hot water consumption for a given day is of the same order of magnitude for the office buildings and the food service industry. This implies that the energy use for hot water in office buildings is just about as important as that in the food service industry when it comes to greater energy efficiency and the associated savings in energy costs. While it is likely that office buildings might typically install more electric water heaters because of the lower installation costs as well as lower projected use, it is important to note that gas water heater energy use in office buildings may be just as significant as that in food service facilities.

4.5 STANDBY LOSS DEFINITION

The definition of standby loss for gas-fired water heaters is as prescribed in the standard test procedure (10 CFR 430, Subpart B, Appendix E, "Uniform Test Method for Measuring the Energy Consumption of Water Heaters," 55 FR 42169, October 17, 1990, U.S. Department of Energy). The standby loss quantity determined from the test (and given as a percentage of stored energy per hour) actually corresponds to the energy input to compensate for the loss occurring from the storage tank while the heater is in a standby mode. It already accounts for the thermal efficiency of the unit by determining the fuel energy input required during the entire standby period. The standby loss calculated from the prescribed relation is, therefore, not the actual energy loss occurring through the walls of the water storage tank, as is normally assumed. Hence, the quantity of energy input should perhaps be referred to as the energy required to maintain the steady-state temperature of the hot water in the tank at 140°F (or whatever the design temperature) during the standby periods. This would avoid any further confusion of terminologies in the future.

5.0 SUMMARY OF RESULTS

The equivalent energy analysis presented in the report provided the basis for the following summary of the main findings.

1. The efficiency requirement for commercial water heaters, as proposed in the Addendum, is energy-equivalent for the lower firing-rate units (<155,000 Btu/h) if the prevalent firing times in the commercial buildings are between 5 and 9 h in a given day. This seems to be the case only for a limited number of commercial building types, based on the data analyses described in this report.
2. Energy equivalency for the higher firing-rate units (inputs >200,000 Btu/h) is achieved at considerably lower daily firing times (1.5 to 3.5 h). This represents about 30% of all the commercial gas water heaters sold. The intermediate range of heat inputs between 155,000 Btu/h and 200,000 Btu/h accounts for nearly 45% of the units shipped.
3. If the minimum thermal efficiency requirement is raised to 79%, energy equivalency for the lower firing-rate units occurs at 3 to 5 h of firing time. A further increase in thermal efficiency to 80% results in energy equivalency at 2 to 4 h of firing time for the same units.
4. Based on a discussion of the weighted average firing times, a total of 70% of the shipment volume (firing rates of $\leq 200,000$ Btu/h) would be energy-equivalent if the average firing times for all applications across the industry were greater than 4 h. While some applications would meet or exceed this requirement, others clearly would not.
5. Lowering the temperature difference between the ambient and the hot water in the storage tank reduces the number of firing hours required for energy equivalency. Increasing the thermal efficiency of the water heater would also reduce the number of firing hours required for energy equivalency.
6. Energy and end-use data from ELCAP showed that median values for firing times ranged from 2 to 6 h per day, depending on the commercial building type.

7. Published water heater sizing guidelines indicate that typical firing times (median values) for service water heaters range from 2 to 8 h per day, depending on the commercial building type considered. Hot water energy use (from NBECS data) is quantitatively similar for both the office buildings and the food service industry.

6.0 RECOMMENDATIONS

Based on the results of the data analyses and the energy equivalency analysis, and the DOE mandate for achieving maximum practicable energy-use efficiency in equipment standards, a recommendation is made for a minimum thermal efficiency requirement of 80% for commercial gas-fired water heaters. This would ensure that the entire stock of units (including the lower firing-rate units) is designed and used in the most energy-efficient manner possible. It would also set an energy-efficiency precedent that a part of the industry has already achieved in its currently available water heater designs.

This page left blank intentionally.

7.0 REFERENCES

American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. 1987. "Service Water Heating." In *ASHRAE Handbook - HVAC Systems and Applications*, Chapter 54. Atlanta, Georgia.

American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. 1989. "Service Water Heating Systems and Equipment." In *ASHRAE/IES Standard 90.1-1989*, "Energy Efficient Design of New Buildings Except Low-Rise Residential Buildings," Section 11. Atlanta, Georgia.

A. O. Smith Water Products Company. 1991. *A. O. Smith Water Products Catalog*. Irving, Texas.

Bock Water Heaters, Inc. 1989. *Bock Water Heaters Catalog*. Madison, Wisconsin.

Energy Information Administration. 1989. *Nonresidential Buildings Energy Consumption Survey: Commercial Buildings Consumption and Expenditures 1986*. DOE/EIA-0318(86), Superintendent of Documents, U.S. Government Printing Office, Washington, D.C.

Pratt, R. G., M. A. Williamson, E. E. Richman, and N. E. Miller. 1990. *Commercial Equipment Loads - End-Use Load and Consumer Assessment Program (ELCAP)*. DOE/BP-13895-24, Bonneville Power Administration, Portland, Oregon.

Rheem Water Heater Division. 1989. *Rheem Water Heaters Catalog*. Atlanta, Georgia.

U.S. Department of Energy. 1989. *10 CFR 435, Subpart A, Energy Conservation Voluntary Performance Standards for Commercial and Multi-Family High Rise Residential Buildings; Mandatory for New Federal Buildings; Interim Rule*, 54 FR 4554, January 30, 1989. Superintendent of Documents, U.S. Government Printing Office, Washington, D.C.

APPENDIX A

FIRING TIME DATA DETAILS

APPENDIX A

FIRING TIME DATA DETAILS

This appendix contains detailed plots of the firing time results from ELCAP data for the different building types.

FIGURE A.1. Firing Times for Electric Water Heaters in Office Buildings

FIGURE A.2. Firing Times for Electric Water Heaters in Restaurants

FIGURE A.3. Firing Times for Electric Water Heaters in Retail Buildings

FIGURE A.4. Firing Times for Electric Water Heaters in Grocery Stores

FIGURE A.5. Firing Times for Electric Water Heaters in Warehouses

APPENDIX B

SIZING METHODOLOGY DETAILS

APPENDIX B

SIZING METHODOLOGY DETAILS

This appendix contains examples of the calculation methods used to size the water heaters listed in Table 3. These units were sized according to guidelines provided by the manufacturers' catalogs, while the hot water requirements for the different building types were as prescribed by the ASHRAE Handbook. Because most of the units considered are from A. O. Smith, the examples below are all from that catalog. The examples are presented in the same order as in Table 3.

Apartments

The number of apartment units (20, 50, or 100) was chosen to match those in Table 1 of the ASHRAE Handbook, for which hot water demand values are given. This example will be for 20 apartments. Assuming 2.5 persons per apartment, we get 50 persons per building. From Table A, pg. B 103 of A. O. Smith's catalog, we find that 500 gal are required for the 3-h peak period (at 40°F and 100°F temperature rise). Also from Table A, the minimum storage capacity required is 130 gal. On the 3-h availability table, part B (gas-fired tank-type water heaters-manifolded), search the gallons storage and gallons available columns to find the closest match to the requirements above. This results in choosing two Model BT-80 water heaters with 150 gal storage and 512 gal available, or, alternatively, three Model BT-65 heaters with 150 gal storage and 510 gal available.

The hot water requirement value in gallons per day was taken from ASHRAE Table 1 as follows for the various number of apartments:

20 apartments	42 gal/apartment
50 apartments	40 gal/apartment
100 apartments	37 gal/apartment

The firing time for each of the two BT-80 model units chosen for this example was determined using the following relation:

Firing time/unit =

$$\frac{(\text{Gal reqd} \times 8.25 \text{ lb/gal}) \times C_p \times \Delta T (= 100 \text{ }^\circ\text{F})}{(\text{Firing Rate, Btu/h}) \times \text{Number of Units}}$$

$$= \frac{840 \times 8.25 \times 1 \times 100}{75,100 \times 0.77 \times 2} = 5.99 \text{ h}$$

General Purpose

The term "general purpose" was chosen from sizing guidelines in the Rheem catalog. It is synonymous with "office buildings" with regard to A. O. Smith guidelines. To size the unit to meet the peak demand, assume that the hot water required is 0.4 gal/person during a maximum hour from ASHRAE Table 1. For example, a building with 250 persons will require 100 gal of storage capacity to meet the peak demand. A. O. Smith suggests a 2-h peak period; therefore, use the 2-h availability table for gas storage heaters. Looking at gallons available, find a unit to meet the 100-gal demand. Choose one BT-65 model, with 125 gal available.

The gallons required column for all building sizes is based on the average day column in ASHRAE Table 1 of one gal/person/day. Therefore, for the building with 250 persons, the firing time of the hot water heater is given by

$$\frac{250 \text{ gal} \times 8.25 \times 1 \times 100}{50,000 \times 0.77 \times 1} = 5.36 \text{ h}$$

An additional note: The A. O. Smith sizing guidelines for office buildings suggest the possible interpretation that the heater should have ample storage capacity to meet the peak demand from storage alone. This would result in a larger unit, with correspondingly lower firing times.

Hotel/Motel

Water heaters for the hotel/motel are sized similarly to those for apartments, except that the 1- or 2-h availability table is used, depending on the assumed peak period. A. O. Smith suggests a 2-h peak period, except where the hotel/motel has convention facilities or is located near an interstate highway. Again, the number of units (or rooms in the hotel/motel) was chosen to correspond to ASHRAE Table 1, for which hot water demand values were given. For example, a 20-unit hotel/motel requires 300 gal and 130 gal of minimum storage capacity (Table B, pg. B-105 of the catalog). Searching the 2-h availability table results in selection of two Model BT-80 heaters with 150 gal storage and 378 gal available. Alternatively, three Model BT-65 heaters would have 150 gal storage and 375 gal available. A similar exercise on the 1-h availability table results in four Model BT-65 heaters with 200 gal storage and 320 gal available, or two Model BTP-140 heaters with 172 gal storage and 398 gal available.

The hot water requirement in gallons per average day was taken from ASHRAE Table 1 for the various numbers of units:

20 units	20 gallons/unit
60 units	14 gallons/unit
100 units	10 gallons/unit.

Therefore, for the 20-room hotel/motel example, the total daily hot water requirement is 400 gal. The firing time for each of the two BT-80 models chosen is then given by

$$\frac{400 \text{ gal} \times 8.25 \times 1 \times 100}{75,000 \times 0.77 \times 2} = 2.85 \text{ h}$$

Food Service

Food service sizing using the A. O. Smith catalog requires a specified number of maximum meals served during the peak periods. Various numbers of

maximum meals were chosen directly from the A. O. Smith Catalog Table 2, pg. B-005. Then, it was a simple matter to choose the proper size for the unit by tracing across the table. Where multiple choices were available, all were included for the study. The first example is for maximum meals of 60 and the unit selected is a BT-65 model with a firing rate of 50,000 Btu/h.

The hot water requirement value for food service establishments was expressed as average (total) meals served in an average day (Table 1, ASHRAE Handbook). Therefore, a relationship was required between the maximum meals served during the peak periods and the total meals served during an average day. The A. O. Smith catalog had stated that 60% of the daily hot water was being used during the peak period. It was inferred, therefore, that 60% of the total meals served were the number of maximum meals served during the peak period. Hence, if the maximum meals served were 60, then the total number of meals served during the day was given by $60/0.6 = 100$. The hot water requirement was given as 2.4 gal per average meal per day, so the total hot water requirement is 240 gal. The firing time for the unit was then given by

$$\frac{240 \text{ gal} \times 8.25 \times 1 \times 100}{50,000 \times 0.77 \times 1} = 5.14 \text{ h}$$

APPENDIX C

ENERGY EQUIVALENCY ANALYSIS DETAILS

APPENDIX C

ENERGY EQUIVALENCY ANALYSIS DETAILS

A sample calculation for the equivalent energy comparison is shown below. At a firing rate of, say 80,000 Btu/h, the energy input to the unit in 1 h of firing time is 80,000 Btu. The input to the water (if the heater thermal efficiency was 77%) for 1 h of firing is given by $80,000 * 0.77 = 61,600$ Btu. For the same energy input to the water, the more efficient unit (at a thermal efficiency of 78%) will require an input of only $61,600/0.78 = 78,974$ Btu, resulting in an energy savings (for 1 h of firing of the unit) of 1,026 Btu (Column D of Table 4). If the stored hot water were on standby for 1 h, then the difference in the standby loss requirements between the Standard and the Addendum is derived below.

The standby loss criterion in the current Standard is $1.3 + 38/V$, where V is the rated (or nameplate) volume of the storage tank (say, 100 gallons for our example). However, the stored energy in the tank should be calculated in terms of the actual volume (measured during the testing of the unit), which, for our discussion, will be assumed to be 95% of the rated volume (95 gal for our example). The standby loss criteria in the Addendum are calculated using the actual volumes also. Therefore, the standby loss requirement of the Standard is $1.3 + 38/100 = 1.68\%$ of the stored energy ($= 95 \text{ gal} * 8.25 \text{ lb/gal} * C_p \text{ of } 1.0 \text{ Btu/lb}^\circ\text{F} * \Delta T \text{ of } 90^\circ\text{F} = 70,538 \text{ Btu}$), which works out to be 1185 Btu. The corresponding hourly standby energy loss term in the Addendum is given by

$1.3 + 114/95 = 2.5\%$ of the stored energy ($= 70,538 \text{ Btu}$) = 1763 Btu [Column G] (for units with firing rates of $\leq 155,000 \text{ Btu/h}$), whereas the criterion would have been $1.3 + 95/V$, with V being the actual volume for units with firing rates $> 155,000 \text{ Btu/h}$ (Column H). The difference in the hourly standby loss requirements, therefore, is

$$1185 - 1763 = (578) \text{ Btu (for firing rates } \leq 155,000 \text{ Btu/h).}$$

The difference in the hourly standby loss requirements (Btu) as a function of the rated storage volume is given in Table C.1. As can be seen, there is a very slight variation of the difference as the volume is increased from 50 to 100 gal.

TABLE C.1. Changes in Hourly Standby Loss Requirements

Firing Rates, Btu/h	Rated Storage Volume, gal ^(a)								
	50			75			100		
	Std	Addm	Chg	Std	Addm	Chg	Std	Addm	Chg
75,000	726	1305	(579)	956	1534	(578)	1185	1763	(578)
100,000	726	1305	(579)	956	1534	(578)	1185	1763	(578)
130,000	726	1305	(579)	956	1534	(578)	1185	1763	(578)
155,000	726	1305	(579)	956	1534	(578)	1185	1763	(578)
180,000	726	1164	(438)	956	1393	(437)	1185	1622	(437)
200,000	726	1164	(438)	956	1393	(437)	1185	1622	(437)
400,000	726	1164	(438)	956	1393	(437)	1185	1622	(437)
500,000	726	1164	(438)	956	1393	(437)	1185	1622	(437)

(a) Actual volume is 95% of rated volume.

To calculate the net daily energy savings, we multiply the energy savings resulting from the higher thermal efficiency by the number of firing hours of the unit--say, 8 h--and then add the result to the total standby energy loss (hourly loss multiplied by the number of standby hours, which, in our example, will be 24 - 8 = 16 h). Therefore, we obtain

$$1026 \text{ Btu} * 8 + (578) \text{ Btu} * 16 = (1040) \text{ Btu/day (Column P of Table 5)}$$

which is a net energy loss for the assumed firing time conditions.

Finally, the number of firing time hours at which the Addendum is energy- equivalent is determined by equating the energy savings from the increase in thermal efficiency to the total energy loss resulting from the

relaxing of the standby loss requirements as shown by

$$1026 \text{ Btu} * X = 578 \text{ Btu} * (24-X)$$

Solving for X, we get the following result:

$$X = 24 * 578 / (578 + 1026) = 8.65 \text{ h (Column U)}.$$

DISTRIBUTION

No. of
Copies

OFFSITE

12 DOE/Office of Scientific and
Technical Information

J. J. Boulin CE-43
Office of Codes and Standards
U.S. Department of Energy
1000 Independence Avenue S.W.
Washington, DC 20585

S. J. Turchen CE-43
Office of Codes and Standards
U.S. Department of Energy
1000 Independence Avenue S.W.
Washington, DC 20585

S. Walder CE-43
Office of Codes and Standards
U.S. Department of Energy
1000 Independence Avenue S.W.
Washington, DC 20585

R. E. Cool
7701 Starkey Road, #747
Seminole, FL 34647

R. Dixon
Florida Department of
Community Affairs
2740 Centerview Drive
Tallahassee, FL 32399-2100

A. H. Fanny
National Institute of
Standards and Technology
Clopper Road, Building 226,
Room B3-20
Gaithersburg, MD 20899

D. B. Goldstein
Suite 1825
71 Stevenson Street
San Francisco, CA 94105-2939

No. of
Copies

OFFSITE

G. C. Groff
Marquardt Switches, Inc.
2711 Route 20 East
P.O. Box 465
Cazenovia, NY 13035

J. J. Heldenbrand
American Society of Heating,
Refrigerating and Air-
Conditioning Engineers, Inc.
1791 Tullie Circle N.E.
Atlanta, GA 30329

R. M. Martin
Building and Appliance
Efficiency Office
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814-5512

M. F. McBride
Owens-Corning Fiberglas
2790 Columbus Road, Bldg. 72
Granville, OH 43023

B. Nelson
Department of Public Service
Energy Division
900 American Center Building
150 East Kellogg Boulevard
St. Paul, MN 55101

F. Stanonik
Gas Appliance Manufacturers
Association
1901 No. Moore Street
Arlington, VA 22209

S. T. Taylor
1241 Blackjack Court
Marietta, GA 30062

No. of
Copies

ONSITE

DOE, Richland Field Office

D. R. Segna

20 Pacific Northwest Laboratory

M. R. Brambley
J. L. Carlson
D. R. Conover
R. E. Jarnagin
L. D. Kannberg
J. M. Keller
B. L. Mohler
J. S. Schliesing
T. J. Secrest
S. Somasundaram (5)
Publishing Coordination
Technical Report Files (5)

END

**DATE
FILMED
8 / 12 / 92**