WSRC--RP--91-345

DE92 018381

MODIFICATION OF K-14.1 SPARJET LOADING FOR LOSS OF TARGET ACCIDENT(U)

by

N. T. Hightower, III, and C. E. Morgan

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

JUL 24 1992

The information contained in this document was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U.S. Department of Energy. By acceptance of this report, the publisher and/or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this report, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted report.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

WESTINGHOUSE SAVANNAH RIVER COMPANY
SAVANNAH RIVER LABORATORY

WSRC-RP-91-345
SRL-SAG-910128

KEY WORDS: K-14.1 RELOAD
RETENTION TIME: LIFETIME

DISTRIBUTION

R. T. BEGLEY, 773-A
D. C. RICHARDSON, 773-A
J. D. SPENCER, 773-A
M. J. HITCHLER, 773-A
L. A. WOOTEN, 773-41A
N. T. HIGHTOWER, III, 773-69A
I. K. PAIK, 773-41A
J. R. CHANDLER, 773-41A
A. J. GARRETT, 773-A
T. W. BURNETT, 773-41A
D. A. SHARP, 773-41A
D. J. BAKER, 773-41A
T. E. BRITT, 676-14T
M. R. BUCKNER, 773-A
C. E. APPERSON, 773-42A
M. R. ROSSER, 707-C
C. G. NICKELL, 707-C
G. Z. MORGAN, 703-41A
B. STUBBS, 703-41A
T. HSIEH, 703-41A

P. D. RICE, 703-A
C. L. PECKINPAUGH, 704-C
F. BERANEK, 704-C
H. F. ALLEN, 707-C
F. D. BENTON, 707-C
R. F. SWINGLE, 707-C
T. M. MONAHON, 707-C
A. M. VINCENT, III, 707-C
R. L. SALIZZONI, 707-C
C. M. SCHAUMAN, 707-C
S. D. CURRY, 707-C
D. W. CALL, 703-A
A. F. McFARLANE, 703-A
G. H. CLARE, 703-31A
R. J. SKWAREK, 773-53A
V. S. O'BLOCK, 773-54A
D. S. LEACH, 773-53A
SRL RECORDS (4), 773-A
S. B. WHITFIELD (SAG FILE), 773-41A

April 12, 1991

P. D. RICE,
VICE PRESIDENT AND GENERAL MANAGER
REACTOR RESTART DIVISION

ATTENTION:

C. L. PECKINPAUGH,
DEPUTY GENERAL MANAGER
REACTOR OPERATIONS DEPARTMENT

AND

F. BERANEK,
MANAGER
REACTOR ENGINEERING DEPARTMENT

**MODIFICATION OF K-14.1 SPARJET LOADING FOR LOSS OF
TARGET ACCIDENT (U)**

Paul R. Rice 4/11/91
SARM Derivative Classifier, Principal Engineer

INTRODUCTION AND SUMMARY

Based on the current Loss Of Target Accident (LOTA) analysis, the Safety Analysis Group (SAG) has found that the current practice concerning the loading of the sparjet shadow rods is to load 15 slugs and no spacer into the insert (also referred to as the guide tube), such that the bottom of the bottom slug rests on the insert bottom end fitting. This places the bottom of the stack of lithium slugs about 10 inches below the lowest sparjet nozzles. There is no forced circulation in this region below the lowest sparjet nozzles, and all cooling must be by convection currents lifting warm water to mix with the forced convection through the lowest nozzles. While this heat removal mechanism appears to be adequate during normal operation, it does not provide a large margin for postulated flow reductions into the sparjet.

RECOMMENDATIONS

It is recommended that the "B" spacer be loaded as shown on drawings S5-1-1208 and S3-1-219, such that the bottom of the stack of lithium slugs is at least 21 inches above the lowest sparjet nozzles. With this configuration, forced circulation through the lowest three levels of sparjet nozzles will remove the gamma and neutron moderation heating produced. This will provide the largest margin for postulated flow reductions into the sparjet. However, if the "B" spacer is not available, it is acceptable to load the "A" spacer as shown on drawings S5-1-1208 and S3-1-219.

This recommendation has been discussed with R.F. Swingle of RRD/ROD/RED and found to be acceptable.

M. J. HITCHLER, MANAGER
REACTOR SAFETY RESEARCH SECTION

By: N.T. Hightower, III
N. T. Hightower, III
Lead Engineer, Non-LOCA Transient Analysis
RSRS/Safety Analysis Group

C. E. Morgan Jr.
C. E. Morgan Jr.
RSRS/Safety Analysis Group

Technical
Review:

I. K. Paik
I. K. Paik
Principal Engineer,
RSRS/Safety Analysis Group

Approval:

L. A. Wooten
L. A. Wooten
RSRS/Safety Analysis Group

**DATE
FILMED
8/3/92**