MASTER

DR. 1163

#153
9/80

Distributed Energy Systems: A Review of Related Technologies

November 1979

Prepared for:
U.S. Department of Energy
Assistant Secretary for Policy and Evaluation
Office of Advanced Technology and
R and D Policy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DOE/PE 03871-01
Dist. Category Uc-13

Distributed Energy Systems: A Review of Related Technologies

November 1979

Prepared by:
Arthur D. Little, Inc.
Cambridge, Massachusetts

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacture, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Prepared for:
U.S. Department of Energy
Assistant Secretary for Policy and Evaluation
Office of Advanced Technology and
R and D Policy
Washington, D.C. 20585

Contract No. EX-76-C-01-3871

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Available from:

National Technical Information Service (NTIS)
U.S. Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22161

Price:	Printed copy:	\$16.50 27.40
	Microfiche:	\$3.00 50

PREFACE

Recent widespread interest in the contribution that distributed energy systems (DES) may make to the nation's energy supply has prompted the preparation of this report. It is intended to act as a source of technical information on the technologies upon which DES are based. It attempts to present a balanced description of the present state of these technologies, expectations for their future growth and the problems that may be encountered. There is brief mention of the complex systems that may have to be created if DES are to provide reliable and predictable supplies of energy, or are to be connected to the central electrical power network. Estimates of equipment capital and operating costs are also provided.

The report was prepared under the direction of the Office of Technical Program Evaluation and its successor, the Office of Advanced Technology and R and D Policy, Assistant Secretary for Policy and Evaluation, U.S. Department of Energy.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

TABLE OF CONTENTS

<u>CHAPTER</u>	<u>PAGE</u>
1 DISTRIBUTED ENERGY SYSTEMS	
1.1 Introduction	1-1
1.2 Distributed Energy Systems	1-2
1.3 The Structure of this Report	1-10
1.4 Summary of Technologies and Factors Affecting the Evaluation	1-12
1.5 Direct Costs	1-17
1.6 Indirect Costs and Credits	1-22
1.7 Conclusions	1-33
References	1-35
2 PHOTOVOLTAIC SYSTEMS	
2.1 Introduction	2-1
2.2 Technical Discussion	2-1
2.3 Economics Discussion	2-11
2.4 Limitations	2-13
References	2-19
3 SOLAR-THERMAL SYSTEMS	
3.1 Introduction	3-1
3.2 Technical Discussion	3-2
3.3 Economics Discussion	3-23
3.4 Limitations	3-28
References	3-33
4 SOLAR HEATING AND COOLING	
4.1 Introduction	4-1
4.2 Technical Discussion	4-1
4.3 Economics Discussion	4-19
4.4 Limitations	4-25
References	4-27
5 RUN-OF-THE-RIVER HYDROELECTRIC POWER GENERATION	
5.1 Introduction	5-1
5.2 Technical Discussion	5-1
5.3 Economics Discussion	5-7
5.4 Limitations	5-12
References	5-19
6 WIND POWER SYSTEMS	
6.1 Introduction	6-1
6.2 Technical Discussion	6-1
6.3 Economics Discussion	6-14
6.4 Limitations	6-20
References	6-29

TABLE OF CONTENTS (continued)

<u>CHAPTER</u>	<u>PAGE</u>
7 SOURCES OF BIOMASS AND THEIR DIRECT CONVERSION TO ENERGY	
7.1 Introduction	7-1
7.2 Biomass Resources	7-1
7.3 Technical Discussion	7-11
7.4 Economics Discussion	7-19
References	7-25
8 SOLID FUELS DERIVED FROM BIOMASS	
8.1 Introduction	8-1
8.2 Technical Discussion	8-2
8.3 Economics Discussion	8-5
8.4 Limitations	8-8
References	8-11
9 ENERGY FROM BIOMASS VIA BIOCONVERSION PROCESSES	
9.1 Introduction	9-1
9.2 Technical Discussion	9-1
9.3 Economics Discussion	9-8
9.4 Limitations	9-11
References	9-15
10 BIOMASS GASIFICATION AND LIQUIFACTION	
10.1 Introduction	10-1
10.2 Technical Discussion	10-1
10.3 Economics Discussion	10-9
10.4 Limitations	10-11
References	10-13
11 FLUIDIZED-BED COMBUSTION	
11.1 Introduction	11-1
11.2 Technical Discussion	11-3
11.3 Economics Discussion	11-11
11.4 Limitations	11-14
References	11-15
12 ON-SITE COMBUSTION TURBINE-POWERED ENERGY SYSTEMS	
12.1 Introduction	12-1
12.2 Technical Discussion	12-2
12.3 Economics Discussion	12-16
12.4 Limitations	12-18
References	12-21

TABLE OF CONTENTS (continued)

<u>CHAPTER</u>	<u>PAGE</u>
13 ON-SITE DIESEL-POWERED ENERGY SYSTEMS	
13.1 Introduction	13-1
13.2 Technical Discussion	13-2
13.3 Economics Discussion	13-7
13.4 Limitations	13-10
References	13-11
14 STIRLING ENGINE-POWERED ENERGY SYSTEMS	
14.1 Introduction	14-1
14.2 Technical Discussion	14-3
14.3 Special Attributes of Stirling Engines	14-17
14.4 Applications	14-20
14.5 Limitations	14-24
References	14-27
15 ORGANIC RANKINE CYCLE ENGINES	
15.1 Introduction	15-1
15.2 Technical Discussion	15-2
15.3 Economics Discussion	15-10
15.4 Limitations	15-12
References	15-18
16 FUEL CELLS	
16.1 Introduction	16-1
16.2 Technical Discussion	16-2
16.3 Economics Discussion	16-5
16.4 Limitations	16-9
16.5 Recent Developments	16-10
References	16-11
17 HEAT PUMPS	
17.1 Introduction	17-1
17.2 Technical Discussion	17-5
17.3 Economics Discussion (Residential Applications)	17-24
17.4 Limitations	17-26
References	17-31
18 COAL-BASED DOMESTIC HEATING	
18.1 Introduction	18-1
18.2 Technical Discussion	18-2
18.3 Economics Discussion	18-9
18.4 Limitations	18-11
References	18-13

TABLE OF CONTENTS (continued)

<u>CHAPTER</u>	<u>PAGE</u>
19 THERMAL ENERGY STORAGE	
19.1 Introduction	19-1
19.2 Technical Discussion	19-2
19.3 Economics Discussion	19-15
19.4 Limitations	19-18
References	19-21
20 SECONDARY BATTERIES	
20.1 Introduction	20-1
20.2 Technical Discussion	20-2
20.3 Economics Discussion	20-8
20.4 Limitations	20-13
References	20-15
21 HEAT TRANSPORT BY HEAT PIPES	
21.1 Introduction	21-1
21.2 Technical Discussion	21-3
21.3 Limitations	21-14
References	21-19
22 INDUSTRIAL COGENERATION	
22.1 Introduction	22-1
22.2 Technical Discussion	22-5
22.3 Factors Affecting the Use of Industrial Cogeneration	22-26
22.4 Future Prospects for Cogeneration	22-29
References	22-33
23 TOTAL ENERGY SYSTEMS	
23.1 Introduction	23-1
23.2 Technical Discussion	23-3
23-3 Economics Discussion	23-16
23-4 Limitations	23-25
References	23-31

CHAPTER 1
DISTRIBUTED ENERGY SYSTEMS

Section 1.1: Introduction

The modern industrialized society depends upon the widespread availability of inexpensive and reliable supplies of energy. The invention of the steam engine permitted the energy in coal to be converted to mechanical energy and was a major factor in the Industrial Revolution. It also made possible the generation of electricity on a large scale. As technology developed, the equipment for converting the energy in fossil fuels to more usable forms improved in efficiency and grew in size. As a consequence, the energy conversion industries became noted for their ability to produce energy reliably and at progressively lower unit cost. To meet the apparently ever-growing demands of their customers, they developed systems for the production and distribution of energy-rich fuels, such as coal, natural gas and oil, and for the centralized generation and distribution of electricity. As these power systems grew in power capacity and extent, they made obsolete, older, smaller, less efficient, and less reliable energy conversion plants.

Within the past decade, and particularly since 1973, the energy industries have become increasingly the targets of public criticism. The three areas of most common concern appear to be the rapid increase in energy prices, the environmental impact of large energy installations such as electric power plants, and the reliability of supply, particularly to urban areas. Critics accuse the industries of failing to operate in the nation's best interests by making inefficient use of non-renewable fossil and mineral fuels, and of being insensitive to the economic and environmental concerns of their customers. The plans offered by the critics generally advocate:

- reduction of demand, e.g., through changes in patterns of use and technical developments such as better thermal insulation of buildings;

- improvements in efficiency of use, e.g., by cogeneration of electricity and heat for domestic or industrial use;
- the greater use of energy conversion systems which take advantage of local energy sources and deliver energy matched to local needs;
- more extensive use of renewable energy sources, e.g., solar, wind, hydropower, and biomass.

The final category has been referred to as the "soft" energy path. The conventional use of non-renewable fossil and nuclear fuels, for comparison, is referred to as the "hard" energy path.

The term "distributed energy systems" (DES) is applied to those energy systems which use (largely, but not exclusively) local energy sources to meet local energy needs. They may vary in size from small solar systems designed to supplement the hot water needs of a single-family residence, to a cogeneration plant which uses, for example, wood wastes to provide electricity and process steam to a paper mill and the local community. The systems may be relatively simple, as in the case of the solar hot water heater, or complex, if electrical or thermal energy storage systems are included; they may be isolated or they may be connected to the local electric utility either to receive power in times of shortage or to deliver it to the utility in times of surplus. The role that DES will play in the future cannot be clearly designated. It is likely to depend upon population density, local energy resources, and energy demands. DES can supplement the existing centralized power system or they may, as hypothesized in the California study to be examined later, become a dominant component of the overall energy supply system.

Section 1.2: Distributed Energy Systems

Many of the principal arguments in favor of the greater use of DES are to be found in the works of Schumacher,⁽¹⁾ Lovins,^(2,3) and Commoner.^{(4)*} Lovins, for example, has presented his perception (Figure 1-1) of the United States' energy future if the present reliance upon centralized energy industries is continued. He offers for comparison

*References are listed at the end of each chapter.

SOURCE: From Reference 3, SOFT ENERGY PATHS, Copyright 1977, Friends of the Earth International. Reprinted with permission from Ballinger Publishing Company.

FIGURE 1-1 AN ILLUSTRATIVE SCHEMATIC FUTURE FOR U.S. GROSS PRIMARY ENERGY USE, BASED ON CENTRALIZED ENERGY SYSTEMS

"an alternative illustrative future" (Figure 1-2) in which fossil and nuclear fuels are replaced by "soft" technologies by the year 2025. Lovins' criticisms of the conventional or "centralized" approach (responsible for Figure 1-1) are based principally upon (a) environmental effects (large quantities of warm cooling water from central electric power plants, the operation of coal and uranium mines, and the increased concentration of carbon dioxide in the atmosphere from the combustion of fossil fuels); and (b) the combination of accelerating capital costs and long lead times which, he claims, will lead the electric utility industry to bankruptcy.

The alternative, Figure 1-2, requires a massive reduction in demand to 30% of that predicted for 2025 in Figure 1-1. This is to be achieved, first, by "technical fixes," e.g., improved thermal insulation of buildings and more extensive use of cogeneration and, second, by "social changes," e.g., car pools, smaller cars, and mass transit stimulated by changes in prices, regulatory requirements, or "gentler inducements." The residual demand in Figure 1-2 is to be met by the widespread use of "soft" technologies which are characterized by their use of renewable energy sources, by diversity, by the use of "low" technology, and by their being matched in scale and in energy quality to their end-use.

The preceding approach to meeting future U.S. energy needs has received extensive criticism. Perry and Streiter⁽⁵⁾ have questioned the validity of Lovins' economic analysis. They suggest that if the "technical fixes" prove to be as successful and as cost-effective as he claims, then they will stimulate increased demand and the hoped-for energy savings, based upon improved energy efficiency, will be less than expected. Yulish⁽⁶⁾ has edited a selection of 10 essays by economists, sociologists, and technologists with reputations and backgrounds in solar energy, nuclear engineering, physics, and chemical engineering. As a group, the writers take Lovins to task for technical inaccuracies, particularly in his treatment of solar energy, for unrealistically low projections of future growth, for faulty economic analysis, and for ignoring the political and social implications of the widespread introduction of "soft" energy technologies.

The extent to which the energy needs of a highly developed

SOURCE: From Reference 3, SOFT ENERGY PATHS, Copyright 1977, Friends of the Earth International. Reprinted with permission from Ballinger Publishing Company.

FIGURE 1-2 AN ALTERNATE ILLUSTRATIVE FUTURE FOR U.S. GROSS PRIMARY ENERGY USE, BASED ON THE USE OF "SOFT" ENERGY TECHNOLOGIES

modern society (the state of California in the year 2025) can be supplied by an energy system that is based substantially upon distributed and renewable energy sources is analyzed in the interim report "Distributed Energy Systems in California's Future."⁽⁷⁾ The results of the study are contained in the two energy supply/demand balances for California - 2025 presented in Figures 1-3 and 1-4. The former presents the "centralized case" and its method of meeting a demand for 5.3 quads*; the latter presents the components of the "distributed case" in meeting a demand for 4.7 quads. The differences in approach are clear.

The distributed case implies the following: (a) the use of electric vehicles for urban transportation; (b) half of the available land that contains non-commercial forest, brush and grasslands (almost 17% of the total land area in California) as well as municipal and agricultural wastes will be required to produce 1 quad of energy from biomass; and (c) the generation of 0.7 quad of electricity from the wind will require "17,000 to 35,000 wind energy conversion devices with an average rated capacity of 3.5 megawatts . . . Such a system would extend over about 6% of the land area, but would occupy only a small part of that area which could be used at the same time for farming or grazing."⁽⁷⁾ In discussing the "centralized case," the report states: "If the same end-use requirements developed here were to be met by using conventional energy forms, the resource requirements and environmental impacts would be substantial. If all energy were derived from coal (using electricity, synfuels, etc.), California in 2025 would require the mining of about 380 million tons per year, about 60% of the coal used by the entire United States today. If electricity produced from nuclear plants were used to meet all the electricity needs (except those met by hydropower), about twenty-two 1000-megawatt plants would be required which would replace 54 million tons of coal per year."⁽⁷⁾

The preceding paragraphs in this section suggest the following conclusions:

* 1 quad = 10^{15} Btu.

SOURCE: Reference 7.

FIGURE 1-3 ENERGY SUPPLY/DEMAND BALANCE FOR CALIFORNIA -- 2025
(Centralized Case; energy in units of 10^{12} Btu)

SOURCE: Reference 7.

FIGURE 1-4 ENERGY SUPPLY/DEMAND BALANCE FOR CALIFORNIA -- 2025
(Distributed Case; energy in units of 10¹² Btu)

- There are problems and deficiencies in the existing "centralized" energy industries, and there are alternative energy sources and technologies that may have been insufficiently exploited in the past;
- the proponents of DES may have overstated their energy and economic benefits; but the supporters of centralized systems have also been optimistic in estimating their costs and benefits;
- it is not at all clear that the large-scale use of biomass to produce liquid fuels, or solar energy to generate electricity, will not encounter problems and organizational structures similar to those of today's centralized power utilities;
- it is unlikely that the future energy systems in the United States will be all "hard" or all "soft"; it is much more likely that both classes of technology will be required, and ways must be found to ensure that the two complement one another;
- the social, institutional, and legal implications of the widespread use of DES are not understood and probably have been greatly understated, particularly in their impact upon the urban resident or the working farmer.

As was pointed out by Perry and Streiter: (5)

"Claims that new technologies are both economic and ready to be applied widely on a commercial scale are common in the scientific and engineering community -- even when there is little or no basis for such claims. It is only necessary to cite a few examples, . . . to illustrate how carefully claims of the availability and economic competitiveness of a new technology must be evaluated. The evaluation must include not only an examination of the technical and economic status but, just as importantly, the nature of the environmental, political, institutional, legal, regulatory, and financial barriers that must be overcome before the technology can be

deployed widely enough to make an important contribution to energy supply. Making such evaluations has been just as difficult for new "hard" technologies as it has been for "soft" ones."

In the report which follows we have attempted to begin this investigation of the technical, economic, institutional, and social implications of the large-scale use of distributed energy systems. We have started at the beginning by limiting our attention to those questions that may be described as necessary if not sufficient -- the technical feasibility and the readiness for commercial deployment of those selected technologies which may be considered as future components of an energy supply system based upon distributed energy sources. We have not attempted to analyze the technical^{*} and social issues raised by the possible widespread use of DES, although we recognize that these questions may be of major importance in the future. Within the limits of available funding and time we have attempted to present a balanced description of the states of the different technologies, their costs and environmental effects, and how they may be used individually or in combination. We have also presented a guide to additional sources of information.

Section 1.3: The Structure of This Report

Chapters 2 through 23 are each devoted to an examination of a technology, or a combination of technologies, that is likely to find a place in future distributed energy systems. The objective is to provide the reader, who has some technical background but is not a specialist, with enough scientific and engineering information to indicate the present state of technical development, where the problems are, and the probable direction of future improvements. Each chapter includes a discussion, or at least a brief mention, of related questions, e.g., environmental impacts, problems connected with energy storage or connection to the electric utility system, if desirable, and institutional problems. An extensive list of references is provided.

* Such as interconnection, centralized control, and energy storage.

Information on costs, both present and expected, is presented in the manner that is conventional for each technology, but enough detail is provided so that the reader may reconstruct, from the base data provided, derived information, e.g., the expected costs of delivered energy. A summary sheet^{*} accompanies each chapter; it presents, in condensed form, the information on performance and costs contained in the chapter.

A comment upon the costs presented in the technology chapters is in order. As far as possible, the information on current costs reflects accurately the costs of manufactured equipment. In some cases, however, these may be subject to rapid change, and in others, installation costs represent a large and variable fraction of total system costs. In both cases, accuracy may be less than the published costs might suggest. Future costs present an even more difficult problem. When there is little consensus, even among experts, on future energy costs or rates of inflation, it is clearly unwise to regard predictions of future costs with anything less than skepticism. In the case of technologies that are still evolving or, having achieved technical success, are now approaching commercialization, it is hard to estimate future costs with any accuracy: (a) for systems that have yet to achieve technical maturity, there is an inevitable tendency to confuse future cost predictions with the desires or the objectives of the proponents; (b) for technologies ready for commercialization (in which case it is customary to assume unit costs will be reduced as production and the market grow), government intervention may be required to stimulate the creation of the market.

In the remainder of this chapter we review some of the problems that must be addressed if there is to be a large-scale introduction of distributed energy systems. We also compare, on the basis of cost information presently available, the costs of energy produced by the various technologies. This analysis should be regarded principally

^{*}

Cost data in the technology summary sheets are given in 1977 dollars. Average unit O&M costs include the costs of parts and labor for maintenance; they do not include "annual capitalization charges" and costs of fuel.

as a means of comparing one technology with another -- on the basis of our present understanding of it -- not as an absolute prediction of future energy costs.

Section 1.4: Summary of Technologies and Factors Affecting Their Evaluation

The individual chapters which follow contain technical descriptions of various distributed energy systems, along with estimates of important economic parameters. The purpose of this chapter is to discuss the factors which enter into a comparison of these technologies and the evaluation of their suitability for meeting part of our national energy requirements. The technologies may be classified as follows:

Group I. Those which produce energy from fuel that is essentially free and is received directly in usable form from the environment:

- Photovoltaic conversion
- Solar thermal generation of electricity
- Solar heating and cooling
- Run-of-the-river hydropower
- Windmills

Group II. Those which produce energy from fuel that must be mined, grown, or otherwise prepared:

- Biomass (including refuse material) --
 - direct conversion by burning
- Fluidized-bed combustion
- Domestic burning of coal
- Diesel engines
- Organic Rankine cycle engines
- Stirling engines
- Gas turbines
- Fuel cells

Group III. Those which are not primary energy-producing devices, but rather are complementary to such devices:

- Pyrolysis (fuel producing)
- Fermentation (fuel producing)

Solid fuels from biomass (fuel producing)

Heat pumps (electrically powered)

Batteries

Thermal storage

Heat pipes

Group IV. Combined systems:

Industrial cogeneration

Total energy systems

Table 1-1 contains a summary of the principal characteristics and applications of these technologies. It should be kept in mind that many of the electricity-producing technologies also admit the option of waste heat recovery, usually for water-heating or space-conditioning applications.

One of the advantages of decentralized and smaller scale technologies is that they may be better adapted to particular applications, especially with respect to the efficient use of energy. For example, despite various heat-recovery cycles, large central generation stations release substantial quantities of waste heat. Because these stations are usually sited some distance from the population centers they serve, and also because of various institutional factors, it is generally not possible to find uses for this waste heat. On the other hand, the waste heat produced by an on-site generation system is often easily recoverable for process or space-conditioning applications. Decentralized sources of energy can (and must) be designed and evaluated with site-specific characteristics in mind, among them being:

- balance between and extent of electrical and thermal requirements,
- daily and seasonal variations in energy requirements,
- local availability of renewable resources, e.g., sunlight, wind, water power,
- projected fuel prices and vulnerability to sudden changes,
- capital availability,
- environmental restrictions,

- reliability requirements,
- personnel capabilities, and
- local utilities (rates, gas pressure, etc.).

Even though there can be significant economies of scale associated with large central stations, the adaptability of distributed systems can more than make up for this fact in a number of specific circumstances. Fuel cost changes and technical improvements over the next 20 years are expected to increase the importance of some of these decentralized technologies.

While an advantage in their implementation, the site-specific dependency and numerous potential configurations of these technologies make it difficult to compare and evaluate them in general terms. Other phases of the Department of Energy program will be able to do this for specific scenarios and case studies. Such work is outside the scope of the present report, the purpose here being to summarize the basic general data, so far as they are available, and to outline the factors which require detailed treatment in more specialized studies.

Factors which enter into an evaluation of this type include:

- direct costs (capital, fuel, operation and maintenance);
- indirect costs and credits (heat recovery, transmission and distribution, reliability, etc.); and
- matters which are difficult or impossible to measure in economic terms (institutional barriers, safety, regulatory patterns, environmental effects, etc.).

It is important to keep in mind further that evaluations of data may lead to different conclusions for persons or groups with different points of view. For example, the user of energy might simply compare the costs of various systems to the rates available from the utility. If a utility is trying to evaluate the effects of a significant level of implementation of decentralized power production, perhaps owned by the utility itself, it will also consider system-wide effects on transmission and distribution requirements, probably to a greater extent than would the individual user. These considerations will be reflected in various costs of power

Technology	Input (primary)	Output (primary)			Status ¹	Principal Applications						Complementary Technologies	Comments
		Shaft Power or Electricity	Heat	Fuel		Individual Residences	Residential & Commercial Complexes	Industrial	Utility	Isolated	Communities		
Photovoltaic	sunlight	100W-1MW			pilot	✓	✓	✓	✓	✓		batteries and/or back-up generation	intermittency: daily, seasonal, weather
Solar thermal	sunlight	1kW-150MW			pilot		✓	✓	✓	✓	✓	batteries or thermal storage and/or back-up generation	intermittency: daily, seasonal, weather requires direct insolation
Solar heating/cooling	sunlight		water & space heating/cooling		commercial (early)	✓	✓	✓		✓	✓	thermal storage	intermittency: daily, seasonal and weather
Run-of-river hydro	water power	50kW-500MW			commercial	(2)		✓	✓			small pondage	seasonal fluctuations
Windmills	wind	100W-2.0MW			pilot ³	✓	✓	✓	✓	✓		batteries and/or back-up generation	wind variations
Biomass-direct combustion	crops, wastes	1MW-100MW	(4)		commercial (early)			✓	✓	✓	✓	biomass production, collection, and distribution	
Pyrolysis	municipal solid waste			gas, oil methanol	pilot						✓	energy conversion device for fuel produced	
Fermentation	crops, wastes			methane ethyl alcohol	developmental			✓	✓		✓	energy conversion device for fuel produced	
Solid fuels from biomass	municipal solid waste			refuse derived solid fuel	commercial (early)			✓	✓		✓	energy conversion device for fuel produced	
Fluidized bed	coal ⁵				large-scale testing			✓	✓		✓	coal distribution and disposal	
Domestic coal	coal		water & space heating		commercial	✓						coal distribution and disposal	coal handling a serious problem
Diesel engines	diesel fuel, natural gas	100kW-1MW			commercial (mature)	(6)	✓	✓	✓		✓	fuel supply	environmental effects may be significant
Organic Rankine engines	low temperature heat ⁷	2kW-2MW			developmental		✓	✓				low temperature heat source, such as waste heat or solar system	promising in several combined cycles
Heat pumps	electricity		water & space heating/cooling		commercial	✓	✓	✓				electricity supply	both heating and cooling
Stirling engines	high temperature heat	3kW-500kW			developmental		✓	✓	✓	✓		high temperature heat source	fuel versatility
Gas turbines	distillate fuel natural gas ⁸	700kW-25MW			commercial (mature)		✓	✓	✓		✓	fuel supply	
Fuel cells	light hydrocarbons	200kW-26MW			pilot		✓	✓	✓		✓	fuel supply	
Batteries	electricity	storage			pilot	✓	✓	✓	✓	✓	✓		
Thermal storage	heat		storage		developmental ⁹	✓	✓	✓			✓		
Heat pipes	heat		transport		commercial								
Industrial cogeneration	coal, residues, oil, gas	500kW-400MW	steam		commercial		✓	✓					
Total energy systems	coal, oil, gas, sunlight	500kW-30MW	water & space heating/cooling		pilot		✓	✓	✓		✓		

Notes:

1. Status description may vary with size or nature of application.
2. Very small units to supply residences or farms that have appropriate water supplies are commercially available, although they are far from being competitive economically in most cases and are not expected to become so.
3. Windmills have been available commercially for limited applications (e.g., irrigation pumping) for many years.
4. Primary and supplementary heating systems based on wood are available commercially for small units, such as residences. The larger units referred to in this entry can also supply steam for various uses, as an alternative to or in addition to driving steam turbine generators.

5. Sludge and other waste materials are important long term possibilities.
6. Generally only used as an emergency back-up power source in this application.
7. These engines may be driven by waste heat or solar heat.
8. Coal-derived fuels are being investigated.
9. Temperature change (vs. phase change) systems are commercially available as part of solar heating systems.

TABLE 1-1

PRINCIPAL CHARACTERISTICS AND APPLICATIONS OF DISTRIBUTED ENERGY TECHNOLOGIES

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

generation and supply, and the results may be quite different from the utility rates themselves. When the government evaluates such systems, considerations such as dependence on foreign fuels, vulnerability to sabotage, effects on the economy, etc., may all become more prominent in the analysis.

Section 1.5: Direct Costs

The direct costs involved in the installation of energy-producing equipment include:

- capital costs of the plant,
- fuel costs, and
- maintenance and other operating costs.

In themselves, these do not constitute a sufficient basis for choosing between candidate technologies, but they do provide a starting point. Capital costs are generally given in terms of the peak power capacity of a unit (e.g., \$/kW), while the other costs are given in terms of energy produced (e.g., \$/kWh). By amortizing the capital cost over the expected lifetime of the plant and by considering the plant's expected energy output, the capital cost can also be represented on a dollar per unit energy basis. The sum of all these energy costs may be regarded as the life-cycle energy production cost of the technology. It gives one indication of the economic picture associated with a particular type of plant. (Obviously, variations in assumptions concerning cost of capital, inflation, fuel cost escalation, etc., may critically affect the relative values of this parameter for different technologies.) For plants with similar operating characteristics, size, and location within the electric utility network, a comparison of life-cycle costs can be very important in choosing among alternatives. This would be the case, for example, in comparing large coal-fired and nuclear generating stations. In the case of comparisons between technologies with highly different operating characteristics, however, this parameter is only one aspect of the picture. The reason for this is that different technologies can have vastly different effects on the overall energy system, and the indirect costs associated with

these can be enormous. For example, that fraction of photovoltaic capacity which requires conventional generation back-up during periods of low insolation must bear the cost of the additional capacity. On the other hand, energy sources distributed so that they are close to the load do not entail the large transmission and distribution costs of central generators.

Further discussion of such system effects will be presented in the next section, but it is useful to begin here with a summary of the direct costs associated with the various technologies. Figure 1-5 summarizes typical data for various electricity-producing technologies. To lend some perspective, Table 1-2 gives a recent estimate of the average cost of delivered electricity to industrial users in certain major U.S. cities. The approximate annual costs for various home heating systems are shown in Table 1-3. Critical economic assumptions are listed in Table 1-4.

It must be emphasized again that the energy costs given in this section cannot simply be compared directly in order to evaluate the relative merits of different technologies. These data are only starting points, which require the further addition of various indirect costs and credits, as well as application and site-specific considerations, before being useful to the evaluative process. It must also be kept in mind that all of these calculations are based largely on cost projections, often for technologies in an active stage of development. Therefore, the tables should be interpreted in the sense: "If costs and parameters are such, then the energy costs will be as calculated." The data are not firm enough to regard the conclusion alone as a forecast. Furthermore, wide ranges of costs may be obtained, depending on site-specific conditions and trends in the economy. Certain observations can be made from some of these calculations, however. For example, even though solar-thermal electric systems presently exhibit cost advantages over photovoltaic systems, the former depend primarily on mechanical components whose prices are not expected to decrease. On the other hand, projected solar cell developments with possibly dramatic cost savings give this technology a competitive advantage in the long run. One also observes

All calculations are in constant 1978 dollars. Conversion from the 1977 basis of the individual chapters has been accomplished using an inflation rate of 7%. For the purpose of this comparison, two factors have been standardized: a system operating life of 20 years, and annual maintenance cost equal to 5% of the capital cost. The cost of capital was assumed to be 6% because constant dollars were used. Capital costs are amortized over the 20 year life, and each system is assumed to have zero salvage value. Average operating efficiencies for combustion turbines and diesels were taken to be 27% and 35%, respectively.

Fuel cost escalation ranges (growth in terms of constant dollars) were assumed as follows: coal, 1-3%; diesel fuel and naphtha, 3-6%; natural gas, 3-6%. Fuel costs used in these calculations were as follows in 1978 dollars: coal, \$1.20/10⁶ Btu; diesel fuel, \$2.90/10⁶ Btu; naphtha, \$4.10/10⁶ Btu; natural gas, \$1.90/10⁶ Btu. The prices of fuels vary widely because of sulfur content, transportation distance, and contractual duration; the fuel prices shown here represent typical mid-1978 values. For a range of fuel prices to utilities in the United States, see any issue of *Electrical Week*. The widening cost ranges for certain technologies, such as Stirling engines, are due to increasing fuel cost uncertainties further into the future.

Note that most of the parameters and costs cited above may vary considerably depending on site, equipment and configuration, ownership, etc. and that fuel and maintenance costs used for this comparison are not necessarily the same as the costs used in each chapter.

FIGURE 1-5 LIFE CYCLE ELECTRICAL ENERGY PRODUCTION COSTS FOR VARIOUS TECHNOLOGIES (1978 \$/kWh)

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

TABLE 1-2

REGIONAL DELIVERED ELECTRICITY COSTS TO INDUSTRIAL USERS (\$/kWh)

<u>Atlanta</u>	<u>Boston</u>	<u>Chicago</u>	<u>Los Angeles</u>	<u>Portland (Ore.)</u>
.028	.041	.031	.030	.017

Source: Reference 8 (1978 data).

TABLE 1-3

APPROXIMATE ANNUAL ENERGY COSTS FOR DOMESTIC HEATING SYSTEMS

<u>Type</u>	<u>\$/10⁶ Btu (1)</u>	<u>\$/kWh (2)</u>	<u>Annual Cost (3)</u>
Oil	6.42	.022	\$963
Gas	3.75	.013	563
Coal	8.96	.031	1344
Solar	19.26	.066	2889
Electric Resistance	11.53	.039	1730
Heat Pump	9.94	.034	1491

- (1) All costs are in 1978 dollars. All systems are assumed to have a 25-year life. Capital costs and data in terms of \$/10⁶ Btu are taken from individual chapters. Annual fixed cost (less maintenance) is installed cost divided by 25; i.e., homeowners are not expected to pay fixed charges based on interest over the life of the system. Annual maintenance cost was assumed to be 5% of the capital cost. System efficiencies were assumed as follows: electric resistance, 95%; gas, 75%; oil, 65%; coal, 55%. The heat pump coefficient of performance was assumed to be 2.0.
- (2) Data in this column are based upon an exact conversion of 3413 Btu per kWh.
- (3) A typical home heating requirement of 150 x 10⁶ Btu per year was assumed. This column is simply column 1 (\$/10⁶ Btu) times 150.

ECONOMIC DEFINITIONS AND ASSUMPTIONSCost of Capital

The cost of capital is the weighted cost of money (capital) to an organization, and is based upon the yield (interest) paid on bonds, common stocks and preferred stocks. The cost of capital varies considerably depending on the type of organization. It is lowest for organizations which can secure federal or state government backing of securities and preferential tax treatment (such as electrical cooperatives and state power authorities), and highest for investor-owned organizations which do not have government-backed securities and preferential tax treatment accorded to investor income.

Fixed Charge Rate

The fixed charge rate is a number, expressed in decimal or percentage form, which is used to determine the annual fixed costs associated with owning an investment (such as a power-generating facility). A fixed charge rate includes the cost of capital, which is the dominant component, and provisions for amortization of investments, insurance, taxes, etc. The range of fixed charge rates primarily reflects differing costs of capital and tax treatment; fixed charge rates of 10% to 19% may be appropriate, depending on the type of organization, for equipment operating lifetimes on the order of 20 years. For short equipment lifetimes (e.g., 5 years), the fixed charge rate will be higher. Annual fixed charges are determined by multiplying the capital cost of a facility times the fixed charge rate. The fixed charge rates used in each chapter reflect the probable type of investing organization.

Operation and Maintenance Costs

Operation and maintenance costs, also known as O&M costs, are defined in this report to include all of the costs associated with operating and maintaining a facility during a year, excluding fuel costs. O&M costs include labor and materials used to keep a facility in operation, plus incidental non-capital charges as appropriate.

that fuel price escalation may make a number of alternative technologies competitive over the next 20 years.

Section 1.6: Indirect Costs and Credits

The following paragraphs discuss various credits and indirect costs associated with distributed energy systems. Representative quantitative results determined in other studies are presented.

A. Heat Recovery

Most of the electricity-generating technologies discussed in the previous section produce significant quantities of thermal energy. Recent increases in energy costs have caused considerable attention to be focused on the recovery of much of this energy. Modes of recovery include:

- high-pressure process steam
- space heating (direct or via heat pumps)
- heat-actuated air conditioning
- water heating
- bottoming cycles (such as an organic Rankine cycle) for additional electric generation.

These are in addition to certain heat-recovery functions which are standard parts of the basic equipment design (such as preheating of air for gas turbines). The ratios of recoverable thermal energy to the electric energy output, as well as the temperature, vary from one technology to another and are important factors in assessing specific applications. A monetary credit for the recovered heat can be determined by estimating the cost of producing an equivalent amount of heat by other methods. For rough calculations, the principal component of this credit is generally taken to be the fuel savings involved. (Capital costs of alternative heating equipment or of heat-recovery equipment are small by comparison when computed on a life-cycle basis.) If electricity is produced at 33% efficiency and if it is possible to recover half the waste heat, then for each kWh of electricity produced one obtains about 3,400 Btu. The cost of producing 3,400 Btu from an efficient (85%) boiler using

fuel oil at $\$2.70/10^6$ Btu is \$.011, and thus this credit can be applied to the electricity cost. This is just one example, based on experience with diesels and gas turbines, but heat-recovery credits are also possible for various potential applications of photovoltaic, solar thermal, biomass conversion, fluidized bed combustion, Stirling, and fuel cell systems. The chapters on cogeneration and total energy systems will give more detailed examples.

B. Transmission and Distribution

The calculation of transmission and distribution credits for distributed energy technologies is very problematic. Some of the work which has been done on this subject is summarized in the next paragraph.

There have been studies by Brookhaven National Laboratory and by the Bechtel Corporation, among others, concerning the cost of transmission and distribution equipment associated with new central generation capacity. Brookhaven estimates \$75/kW for transmission and \$140/kW for distribution,⁽⁹⁾ both in 1974 dollars. Bechtel estimates \$69/kW for transmission and \$420/kW for distribution,⁽¹⁰⁾ also in 1974 dollars. Obviously such estimates depend on many assumptions, such as user requirements, fraction of lines which are underground, etc. (Some of the differences are discussed by Lovins.⁽³⁾) However, these details are not important for our purposes. Lovins' approach is to add these figures to central station generating costs as part of the calculation of the cost of marginal increases in delivered electric power.

Other workers have computed, on the basis of certain scenarios, the savings in transmission and distribution requirements that might accompany the implementation of load-leveling batteries as a distributed energy technology. In particular, a study by one utility of the effect of battery installations at distribution substations as a substitute for a total of 500 MW of peaking generators (5% of total installed capacity) yielded credits of \$61/kW and \$3/kW for transmission and distribution savings.⁽¹¹⁾ This work has been reviewed to incorporate a revised economic basis and possible extrapolation to other situations, but this review has not resulted in substantial modifications to these particular credits.⁽¹²⁾

One reason why the treatment of these credits is problematic is that there are wide variations in possible configurations for distributed technologies. For systems incorporating a utility back-up, there would be little or no credit available for transmission or distribution. For systems without such a back-up, the resulting savings would vary greatly depending upon installation size, voltage requirements, location, and other factors. Even for an installation in a densely populated area, the introduction of utility power to an institution or complex may necessitate the construction of a separate substation. (For hospitals, sometimes two substations are required by law.⁽¹³⁾) A fairly typical example is that of a suburban college which was already supplied by utility power and which wanted to extend power to a new sports complex containing an ice rink and tennis courts. To cover the peak load of 560 kW, it would have been necessary to construct a separate substation at a cost of \$45,000, or roughly 25% of the capital cost of the independent diesel power supply that was eventually installed.⁽¹⁴⁾

In a case such as the one just described, where the owner/user is not the electric utility, it is doubtful that incremental changes in the burden on the transmission system or on other sections of the distribution system would have any effect on a user's course of action. The user would generally calculate the life-cycle energy cost by taking this direct substation credit off the capital cost and then comparing the resulting energy cost with the rate offered by the utility. In the case cited, with credits for heat recovery and distribution, the energy cost came to about \$.04/kWh, which compared favorably with the (rather high) rate of \$.06/kWh available from the utility.⁽¹⁴⁾

This example introduces a second reason why a general discussion of transmission and distribution credit is problematic, namely, that the correct credit depends on one's point of view. The user will take a "local" point of view, seeing specific cost comparisons affecting him. This fact is important in estimating the commercialization potential of many of these technologies. On the other hand, the utility will take a broader point of view, positing a certain level of implementation of decentralized power supply (perhaps installed and owned by the utility)

and then calculating the resulting changes in system requirements and costs. At this level, as well as from the viewpoint of governments, which may be concerned with state, regional, national energy requirements, the full credits for transmission and distribution may indeed be appropriate.

C. Waste Disposal

For power systems based in whole or in part on municipal solid waste, credits may be assigned according to the alternative cost of waste disposal as well as the recovery of recyclable materials. These credits depend on specific circumstances.

D. Capacity Displacement

Solar and wind energy conversion systems have the inherent disadvantage of being dependent on fluctuating sources of energy. While such systems usually contain as an integral part some degree of storage, this is ordinarily sufficient to cover relatively short periods of negligible input (such as the night-time when there is no solar radiation), but inadequate to cover several days of unfavorable weather conditions. Increasing storage to guarantee reliability at a level comparable to that generally provided by the utility industry is not a cost-effective alternative, except in rare circumstances. The provision of alternative on-site generators is a viable option for some cases. Nevertheless, the option generally considered to be of greatest applicability is a utility connection for back-up power. However, there are serious complications associated with this. It is most economical for utilities to produce electricity at a steady level. If their load shows significant fluctuations, then enough generating capacity must be built up to cover the highest peaks, but much of this will stand idle during periods of low demand. Thus, the capital expense of the generating equipment must be distributed over a smaller energy output, resulting in a higher unit cost of electrical energy. The economics of the situation are such that to meet the steady (baseload) part of the load, utilities do best to invest in capital-intensive generation equipment (e.g., nuclear, coal) whose associated fuel costs are relatively low. To meet cyclic and peak demands,

it is better to use less expensive equipment (e.g., gas turbines), although they have higher fuel costs. Elaborate computer programs are used by utilities to determine the optimal mix of new equipment they should add in order to meet expected load increases. This represents a straightforward, albeit complicated, economic optimization problem whose inputs include the desired level of system reliability, the parameters associated with all the different kinds of equipment, the load forecast, and any special constraints relevant to the situation. It is possible to incorporate solar and wind systems into this scheme and to measure the changes in the conventional generation mix and capacity called for when they are included, although accurate and efficient ways of doing this are only now being developed. (Selected examples follow later in this section.)

Suppose one wants to determine the effect of a total of 100 MW of photovoltaic capacity on a certain system. If the photovoltaic capacity had about the same availability and reliability as conventional equipment, then this 100-MW capacity would be equivalent to 100 MW of conventional equipment for operating purposes, and one could say that the capacity displacement credit of the photovoltaic systems is 100%. If the photovoltaic capacity were "totally unreliable," then clearly it would not displace any required conventional capacity, and its credit would be 0%. This does not mean that the system would be useless, but only that it requires a total back-up. Its value then would be measured simply in terms of the fuel that would be saved by the back-up system whenever the photovoltaic system was working. (This is called the "fuel saver mode" and represents the least favorable framework within which to evaluate the economic merits of such a system.)

If the photovoltaic capacity had some intermediate level of reliability, then a corresponding capacity displacement credit could be calculated. This calculation would require the specification of parameters relating to the availability of the system, the time correspondence between system daily peak loads and array output, etc. In short, when the optimal generation planning program is run with 100 MW of photovoltaic capacity as a constraint, the amount of conventional capacity will generally be reduced by some amount between 0 and 100 MW over the case

without the photovoltaic system. This reduction (as a percentage of 100 MW) would be the capacity credit. Although it is customary to speak of these credits in terms of power units, in fact the economic significance depends on what kind of units they are. It actually turns out that the proportions in the generation mix may be altered, so a comparison of the total costs of the plans must be made to estimate accurately the results in dollars.

Determinations of this type are specific to utility service areas, and recently a number of examples of this type have been run. The same kind of calculations are also possible for model utilities and other artificial scenarios. Since scenario and case studies do not fall within the scope of this phase of the DOE program, only some brief indication of past work will be mentioned. Naturally, the same principles apply to all the solar technologies.

A study based on data and projections for the Salt River Project (Arizona)⁽¹⁵⁾ calculated a capacity credit of 48 MW (=48%) for 100 MW of photovoltaic penetration, and a credit of 65 MW (=16%) for 400 MW of penetration. (These levels of penetration represented 1.5% and 6%, respectively, of total installed capacity.) The point here is that increased dependence on the solar system introduces additional unreliability, which must be compensated for by a larger reserve margin.

A study of solar thermal systems⁽¹⁶⁾ indicated capacity credits anywhere from 8% to 92%, depending on various system options. Effects on the generation mix were also given. In general, solar thermal plants would be expected to displace intermediate generation capacity in present real systems, although some degree of baseload displacement would occur in systems where the generation mix was close to optimal.⁽¹⁶⁾

Studies of capacity credits appropriate to wind energy conversion systems have concentrated on large wind farms located at carefully chosen and geographically separated sites. In one case,⁽¹⁷⁾ capacity credits ranging from 16% to 29% were calculated, but the plant sizes made extrapolation to the smaller system scale of the present report impossible. (In particular, twelve 500-MW sites and four 1500-MW sites were the options treated.) The combination of wind units with conven-

tional or pumped hydro systems is one way to enhance reliability,⁽¹⁸⁾ but this would generally only be appropriate for rather large installations.

A report⁽¹⁹⁾ and a book⁽²⁰⁾ on solar space conditioning discuss the fact that these systems may even increase the utility's peak load, while certainly decreasing the load factor. As an example of how this can happen, the authors point out that equipment designed for solar use (such as an absorption cooling system) can be much less efficient to run in the back-up mode than the conventional equipment that would have been installed otherwise (i.e., compression cycle refrigeration).

Utility customers who require back-up service to support intermittent capacity would generally be assessed an approximation of its additional cost by means of a periodic demand charge, based on the difference between their peak and average demand levels.

Certain other technologies also exhibit some of the characteristics just discussed. These include the following:

- Hydropower. In many areas, rivers and streams run at their lowest levels during the summer (lower precipitation, high evaporation) and winter (water captured as ice). But most utilities have their peak demands during these periods. The result is that the contribution from hydropower services does not reduce by very much the total alternative capacity that must be built (although it may affect the desired generation mix).
- Biomass. Certain biomass conversion schemes may have seasonally varying outputs due to fuel availability. When the power produced is primarily intended for and well matched to on-site requirements, then a large capacity credit may be associated with the system. This has been the case with past experience in the sugar industry, where crop wastes are burned to produce steam and electricity for process needs.⁽²¹⁾ (The processing season may be relatively short, e.g., 70 days in Louisiana.)

E. Reliability and Reserve Margin

Some discussion of reliability appeared in the previous section, but that was in connection with fluctuating sources of energy. There is, in fact, another aspect of reliability inherent in any configuration of distributed energy systems that feed power into a central network.

To illustrate the basic principle, we consider an extremely simple example. Suppose a constant load of 100 MW is to be met by a utility, one of whose power supplies is a 100-MW central station with an outage rate^{*} of 10%. If the reliability constraint on the system requires that the load be met at least 99% of the time, then complete redundancy must be built in to cover most of the time that the central station is down. Another central station of 100 MW with the same availability factor would be sufficient, for at least one of the units would be available all but $.1 \times .1 = .01 = 1\%$ of the time. In this case, one refers to the extra 100 MW as the "reserve margin." As a percentage of the load, it is 100% in this case. Obviously, it is undesirable to have to maintain such a large reserve margin. For a given level of system reliability, a smaller reserve margin would mean lower capital requirements.

To see how this may come about, suppose that the 100-MW load were to be met by a utility having one-hundred 1-MW generators feeding in power, as might be the case in a more distributed system, and suppose that each of these also has an outage rate of 10% and that these outages are independent of each other. (Thus, we are discussing effects of 'mechanical' reliability, rather than outages due to weather effects, which would generally be highly correlated for sun and wind machines.) From a probabilistic standpoint, it is quite unlikely that all 100 generators would be down simultaneously ($\text{prob} = (.1)^{100} = 10^{-100}$); in fact, it is quite unlikely that the number that will be down at any time will differ very much from 10. Straightforward statistical calculations show that

* Outage time generally includes several categories, principally forced outages and scheduled maintenance. The distinction is not important for the present illustration.

supplementing the system with 20 more similar 1-MW units will satisfy the overall reliability constraint. In this case then, a reserve margin of 20 MW or 20% is sufficient. The source of the advantage here is that a large number of independent generators behave in aggregate much closer to the predicted statistical mean, and fewer large deviations need to be protected against. (This same factor implies that loss of load, during that small fraction of time when it does occur, may be expected to be much less in the case of a large number of independent generators.)

The factor illustrated here will play a role in the calculation of the optimal generation mix for a particular system. Obviously, the example given of a 100% reserve margin was exaggerated to make the point, but even an effect of a few percentage points on the size of the reserve margin would have significant economic implications for a utility. The technologies most likely to contribute to this effect are those which have high availability and which can provide power to the utility network from a number of decentralized locations. Prime candidates include fuel cells, run-of-river hydro-plants, gas turbines, and, in certain circumstances, industrial cogeneration plants⁽²²⁾ with surplus electricity.

F. Utility Interface

In previous sections, as well as in the individual technology chapters, reference has been made to several possible relationships between a decentralized energy source and the central utility network. It may be useful to summarize them here.

Independent Systems. A number of applications are viable without any connection to the utility. These range from isolated wind-powered irrigation systems to total energy systems at the community level. Almost all such applications need to incorporate some reserve capacity, which may be in the form of storage, alternative generators, or some combination.

One-Way Systems. These are systems which can only import power along their utility connection. Economic penalties include the cost of installing the utility connection (which may include one or more substations) and a high demand charge. If the on-site generator or storage system produces direct current, then inversion equipment will be necessary for many applications. Self-commutated inverters tend to be quite expensive (see Table 2-3), while line-commutated inverters may constitute a substantial reactive load for the utility.* If storage is part of the on-site system, then it may also be possible to use it in a load management mode, so as to lessen the poor load factor effect on the utility. Another option presently being investigated by some utilities is the provision of such backup power on an interruptible basis, which would also lessen the capacity requirements on the utility.

Two-Way Systems. Systems in which energy can be exported from a decentralized energy source to the utility have additional problems, among them the following:

- Power may only be available when it is not very useful to the utility, such as during the night when operations at a cogenerating plant are at a lower level.
- Legal requirements concerning the price to be paid by the utility for this power may be disadvantageous economically. For example, simply running the electric meter in reverse (thereby using the standard customer rate) fails to account for the utility's cost of providing back-up capacity. In addition, this rate may be more than it costs the utility to generate off-peak power itself. Experiments involving such two-way systems have been begun by a number of utilities,⁽²³⁾ but they are expected to be slow to encourage this option.

* There are programs sponsored by DOE and EPRI to develop more efficient and economical self-commutated inverters.

- Utilities want to be sure to have control over what enters their power lines, both for the safety of their workers and the security of their system (e.g., stability). While controls have been well tested on cogenerating industrial plants feeding the electrical network, a large number of quite small systems (e.g., residential photovoltaic arrays) might be more difficult to deal with.

Distributed Utility Generators. Some distributed generators would actually be part of the utility system. For example, these might be fuel cells installed relatively close to the load or even on-site cogeneration plants owned and operated by the utility.

Section 1.7: Conclusions

All of the distributed energy technologies discussed in this report represent potentially viable options for contributing to the country's needs, although the residential burning of coal is not expected to show much additional promise. Even machines which have traditionally been wasteful of prime fuels (diesels, gas turbines) are expected to have an important role in our energy development, this because of increased emphasis on cogeneration and because of the potential for coal-derived fuels. The economics of various systems are very much in doubt because further technological development is necessary in order to evaluate them properly. For a recent economically oriented analysis of America's energy future, the reader is referred to the Ford Foundation Study, Energy: The Next Twenty Years.⁽²⁴⁾ Two other widely publicized recent books, Energy in America's Future, The Choices Before Us⁽²⁵⁾ (a study prepared for the Resources for the future National Energy Strategies Project) and Energy Future⁽²⁶⁾ (Report of the Energy Project at the Harvard Business School), also deal with distributed energy systems within the larger context of long-term energy options. With previously cited references they present a spectrum of views and analytic approaches to the larger problem whose technologies are addressed in this report. For example, Stirling engines, which might

compete directly with Diesel engines, but have wider fuel options, have not even been built in the sizes envisioned. The development of much less expensive photovoltaic arrays awaits major technical improvements. Even the technology of windpower, which is relatively old, shows interesting new developments that are not well tested (e.g., vertical axis machines). And basic to the success of many of these technologies are hoped-for improvements in energy storage.

REFERENCES

1. Schumacher, E.F. Small is Beautiful. New York: Harper and Row, 1973.
2. Lovins, A.B. "Energy Strategy: The Road Not Taken?" Foreign Affairs, October 1976. pp. 65 ff.
3. Lovins, A.B. Soft Energy Paths: Toward a Durable Peace. Cambridge, Massachusetts: Ballinger Publishing Company, 1977.
4. Commoner, B. The Poverty of Power. New York: Alfred A. Knopf, 1976.
5. Perry, H., et al. Multiple Paths for Energy Policy, A Critique of Lovins' Energy Strategy. New York: National Economic Research Associates, 1977.
6. Yulish, C.B. Soft vs. Hard Energy Paths: 10 Critical Essays on Amory Lovins' "Energy Strategy: The Road Not Taken?". New York: Charles Yulish Associates, 1977.
7. Craig, P., et al. Distributed Energy Systems in California's Future. Interim Report. Prepared under Contract No. W-7405-ENG-48 by Lawrence Berkeley Laboratory/Lawrence Livermore Laboratory for U.S. Department of Energy, March 1978. NTIS Report No. HCP P7405-01/02.
8. "How Energy Costs Vary." Business Week, April 10, 1978. p. 44H.
9. Beller, M. Sourcebook for Energy Assessment. Prepared by Brookhaven National Laboratory. December 1975. NTIS Report No. BNL-50483.
10. Carasso, M., et al. The Energy Supply Planning Model. Reports prepared by Bechtel Corporation for National Science Foundation, August 1975. NTIS Report Nos. PB245 382 and PB245 383.
11. Public Service Electric and Gas Company. Economic Assessment of the Utilization of Lead Acid Batteries in Electric Utility Systems. Report to Energy Research and Development Administration, November 1977. NTIS Report No. HCP/T2857-1.
12. METREK Division of MITRE Corporation. Lead Acid Battery: An Evaluation of Commercialization Strategies. Report to Energy Research and Development Administration, November 1977. NTIS Report No. MTR-7592.
13. New England Memorial Hospital, Stoneham, Massachusetts. Private correspondence with the Plant Supervisor, 1978.
14. Cummins Engine Company, Inc., Dedham, Massachusetts. Cogeneration Feasibility Study for Babson College, Wellesley, Massachusetts, 1976.

REFERENCES (continued)

15. Chowaniec, C.R., et al. "A Reliability Assessment Technique for Generating Systems with Photovoltaic Power Plants." Energy Development IV. IEEE Power Engineering Society, 1978. pp. 137 ff. Publication 78TH0050-5-PWR.
16. Ballance, J.W., et al. "Integration of Solar Generation into Electric Utility Systems." Energy Development IV. IEEE Power Engineering Society, 1978. pp. 6 ff. Publication 78TH0050-5-PWR.
17. General Electric Company. Wind Energy Mission Analysis. Report to Energy Research and Development Administration, February 1977. NTIS Report No. C00/2578-1/2.
18. Todd, C.J., et al. Cost Effective Electric Power Generation from the Wind. Bureau of Reclamation, Denver, Colorado, 1977. NTIS Report No. PB273 582.
19. Feldman, S.L., et al. "The Effect of Solar Buildings on Peak Load." Electrical World 191(6): 150, March 15, 1978.
20. Feldman, S.L., et al. The Economics of Solar Energy: The Public Utility Interface. (In preparation).
21. Lipinsky, E.S. "Fuels from Sugarcane and Corn." Energy Development IV. IEEE Power Engineering Society, 1978. pp. 39 ff. Publication 78TH0050-5-PWR
22. Solt, S.M. "Cogeneration Becoming More Attractive." Electrical World 191(6): 119, March 15, 1978.
23. Yamagiwa, A., et al. "Experimental Evaluation of a Solar/Wind-Powered Space Heating and Hot Water Heating System in the Pacific Northwest." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1243 ff.
24. Landsberg, J.J., et al. Energy: The Next Twenty Years. Cambridge, Massachusetts: Ballinger Publishing Company, 1979.
25. Schurr, S.H., et al. Energy in America's Future, The Choices Before Us. Baltimore, Maryland: The Johns Hopkins University Press, 1979.
26. Stobaugh, R. and Yergin, D., eds. Energy Future. New York, New York: Random House, 1979.

SUPPLEMENTARY BIBLIOGRAPHY

1. General Electric Company. Requirements Assessment of Photovoltaic Power Plants in Electric Utility Systems. Prepared for Electric Power Research Institute, June 1978. EPRI Report No. EPRI ER-685-SY.
2. Pittman, P.F. Conceptual Design and Systems Analysis of Photovoltaic Power Systems. Prepared by Westinghouse Electric Corporation for U.S. Department of Energy, April 1977. NTIS Report No. ALO-2744-13.
3. Southern California Edison Co. Integration of Solar Thermal Power Plants into Electric Utility Systems. Vols. 1 and 2. Prepared for U.S. Energy Research and Development Administration, September 1976. NTIS Report Nos. TID 27627/1 and TID 27627/2.
4. Aerospace Corporation. Penetration Analysis and Margin Requirements Associated with Large-Scale Utilization of Solar Power Plants. Prepared for Electric Power Research Institute, August 1976. EPRI Report No. EPRI ER-198. (NTIS Report No. PB 257 546).
5. Aerospace Corporation. SHACOB: Requirements Definition and Impact Analysis. Prepared for Electric Power Research Institute, June 1978. EPRI Report No. EPRI ER-808.
6. Nathanson, D., et al. "Solar Heating and Cooling: An Electric Utility Perspective." Energy Technology 5: Challenge to Technology, Proceedings of the 5th Energy Technology Conference, Washington, D.C., February 27 - March 1, 1978. Washington, D.C.: Government Institutes, Inc., April 1978.
7. Nathanson, D., et al. "Preferred Residential Solar Heating and Cooling Systems Compatible with Electric Utility Operation." Proceedings of the 1977 Meeting of the International Solar Energy Society. Parkville, Victoria, Australia, June 1977.
8. Marsh, W.D. "Utility Applications of Wind Power Plants." Energy Technology 5: Challenge to Technology, Proceedings of the 5th Energy Technology Conference, Washington, D.C., February 27 - March 1, 1978. Washington, D.C.: Government Institutes, Inc., April 1978. pp. 83 ff.
9. Feldman, S.L. et al. Public Utility and Solar Energy Interface: An Assessment of Policy Options. Final Report. Prepared by Clark University and Total Environmental Action, Inc. for U.S. Energy Research and Development Administration, December 1976. NTIS Report No. DSE/2523-2.

CHAPTER 2
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: PHOTOVOLTAIC SYSTEMS</p> <p>DESCRIPTION: Electric power is produced by the direct conversion of sunlight.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, industrial, electric, utility, agriculture, remote on-site</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Single-crystal photovoltaic cell technology is well advanced for silicon and gallium arsenide. Several photovoltaic demonstration projects are in operation using single-crystal silicon cells. Low-cost photovoltaic technology based on polycrystalline and/or thin-film materials is still in early development and subject to significant change.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (kW) ⁽¹⁾ PRIMARY</td><td>.1-1</td><td>1-10</td><td>100-1000</td></tr> <tr> <td>SECONDARY</td><td>(ii)</td><td>(ii)</td><td>(ii)</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY</td><td>220-2200</td><td>2200-22,000</td><td>220,000-2.2x10⁶</td></tr> <tr> <td>SECONDARY</td><td>(ii)</td><td>(ii)</td><td>(ii)</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.25</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.10-.29</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.08</td><td>.13-.14</td><td>.16</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Sunlight AMOUNT NEEDED PER UNIT OUTPUT: 28,500 Btu/kWh @12% efficiency</p> <p>ALTERNATIVE FUEL(S): None IS SYSTEM READILY CONVERTIBLE? No</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Seasonal sunlight cycle Day/night sunlight cycle Cloud cover variation</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Yes, although stand-alone photovoltaic systems may suffice in certain applications.</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Yes</p> <p>SYSTEM: Batteries or alternative generation may be advantageous in certain cases.</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (kW) ⁽¹⁾ PRIMARY	.1-1	1-10	100-1000	SECONDARY	(ii)	(ii)	(ii)	UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	220-2200	2200-22,000	220,000-2.2x10 ⁶	SECONDARY	(ii)	(ii)	(ii)	AVERAGE EFFECTIVE CAPACITY FACTOR:	.25	same	same	RANGE OF CAPACITY FACTORS:	.10-.29	same	same	EFFICIENCY (BTU OUT/BTU IN):	.08	.13-.14	.16
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (kW) ⁽¹⁾ PRIMARY	.1-1	1-10	100-1000																																
SECONDARY	(ii)	(ii)	(ii)																																
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	220-2200	2200-22,000	220,000-2.2x10 ⁶																																
SECONDARY	(ii)	(ii)	(ii)																																
AVERAGE EFFECTIVE CAPACITY FACTOR:	.25	same	same																																
RANGE OF CAPACITY FACTORS:	.10-.29	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.08	.13-.14	.16																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/Peak kW)</td><td>12,600 - 31,200</td><td>330 - 4100</td><td>400-1900</td></tr> <tr> <td>(INCLUDES: Switching, no storage)</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE UNIT O&M:</td><td>Unknown</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>6 mos</td><td>same</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/Peak kW)	12,600 - 31,200	330 - 4100	400-1900	(INCLUDES: Switching, no storage)				AVERAGE UNIT O&M:	Unknown	same	same	CONSTRUCTION PERIOD:	6 mos	same	same												
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/Peak kW)	12,600 - 31,200	330 - 4100	400-1900																																
(INCLUDES: Switching, no storage)																																			
AVERAGE UNIT O&M:	Unknown	same	same																																
CONSTRUCTION PERIOD:	6 mos	same	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Minimal; total 1977 production was 800 kW of peak array output per year.</p> <p>GEOGRAPHIC LIMITATIONS: All areas of U.S. to latitude 43°N have sufficient annual insolation to be potentially suitable for photovoltaic power production.</p> <p>ENVIRONMENTAL EFFECTS: Minimal regarding installation and use; production issue is complex.</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: Array ownership and installation area acquisition, insolation rights and utility interconnection.</p>																																		
COMMENTS	<p>(1) Unit power output is expressed in terms of peak watts at 1 kW/m² insolation.</p> <p>(11) Recovery of waste heat from the array is possible, but would add to system cost.</p>																																		

CHAPTER 2

PHOTOVOLTAIC SYSTEMS

Section 2.1: Introduction

A photovoltaic converter produces direct current electrical power from sunlight by a physical process which does not require the use of a heat engine. The electrical power available is directly proportional to the total solar flux intercepted by the photovoltaic array and is, therefore, proportional to the land surface occupied by the light-collecting elements of the array. All presently envisioned photovoltaic array designs are modular in concept, with the basic array elements quite small, i.e., a few cm^2 to a few m^2 . In general, the photovoltaic array must be interfaced with its load via a power conditioner, and other elements of the photovoltaic distributed energy system (PV-DES) may include a utility tie line and energy storage, e.g., batteries.

Because the technology of photovoltaic devices and systems is still rapidly evolving, predictions of the future design, performance, energy and dollar cost cannot be made with certainty. However, it does appear that the PV-DES will offer considerable flexibility in application and may be of value to a wide range of industrial, agricultural, commercial, and residential power consumers.

Section 2.2: Technical Discussion

A. The Photovoltaic Converter

Photovoltaic converters are semiconductor devices in which electrical energy is produced from photons of light by a two-step process:^(1,2)

1. The photon is absorbed by the semiconductor and its energy utilized in the production of an electron-hole pair.
2. The electrical charges are separated at a potential barrier within or at the surface of the semiconductor and made available for work in an external load.

Although the quantum process of electron-hole pair production is nearly 100% efficient for photons of energy greater than the semiconductor bandgap energy, there is considerable energy loss because only that portion of the photon energy equal to the semiconductor bandgap energy is potentially recoverable. Photons with energy less than the bandgap energy do not produce charge pairs, and photons with energy in excess of bandgap energy have their surplus energy converted into heat. For a given spectral distribution of solar irradiance, there is an optimum converter bandgap. Figure 2-1, which is patterned after the presentation of Prince,⁽³⁾ shows the theoretical efficiency, η , vs. bandgap curve for Air Mass Zero (AM0) illumination; that is, the insolation available outside the atmosphere. The bandgap positions of various candidate photovoltaic semiconductors are noted.

SOURCE: Adapted from Reference 3.

FIGURE 2-1 THEORETICAL EFFICIENCY OF PHOTOVOLTAIC MATERIALS

The efficiencies presented in Figure 2-1 are based upon 100% efficient electron-hole pair production and charge collection for all photons of energy greater than the bandgap energy and ideal diode behavior of the semiconductor junction. Losses due to shunt and series resistance in the photovoltaic cell are also neglected. Nevertheless, efficiencies within a few percent of the theoretical values have been demonstrated for single-crystal silicon (Si) and gallium arsenide (GaAs) photovoltaic cells.

Although photovoltaic semiconductors may be utilized in novel ways, such as for thermophotovoltaic conversion⁽⁴⁾ or in edge-illuminated⁽⁵⁾ or multiple-junction, graded-bandgap devices,⁽⁶⁾ the most likely technology for the 1977-2000 period is the single-potential barrier cell utilizing illumination normal to the junction.

Table 2-1 summarizes the range of array efficiencies likely to be achieved in the 1985-2000 time period for those photovoltaic materials now receiving the greatest attention. Air Mass One (AM1) illumination, i.e., clear day, sun directly overhead, and no concentration of the sunlight, is assumed. The references identified provide a technical review of the candidate materials. The array efficiencies are Arthur D. Little, Inc., estimates and allow for optical losses within the array which may range from as little as 2% for a planar array to as high as 20% for a concentrating array employing supplemental protective covers.

TABLE 2-1
THE THEORETICAL AND PROJECTED ARRAY
EFFICIENCIES OF SELECTED PHOTOVOLTAIC MATERIALS

<u>Material</u>	<u>Theoretical Efficiency (%)</u>	<u>Array Efficiency (%)</u>	<u>Reference</u>
Silicon-crystalline	22	10-14	7
Silicon-amorphous	15 (1)	7-11	8
Gallium arsenide	24	12-16	9
Cadmium sulfide	17	7-11	10

- (1) The difference between this efficiency and that shown in Figure 2-1 is the result of excessive losses because of the amorphous structure.

Single-crystal silicon has been the preferred photovoltaic material for more than a decade. Its theory, technology, and application are well developed, and a high degree of confidence exists that the projected

array efficiency of 10-14% given in Table 2-1 will be realized.

The major thrust of present single-crystal, silicon-solar-cell development is to reduce material preparation cost. Several novel crystal-growing methods are being developed. The objective is to grow ready-to-use material in strip form so that the conventional process of sawing and polishing wafers from bulk single-crystal material can be replaced.

Cast polycrystalline silicon is also being investigated,⁽¹¹⁾ and though this material has the same theoretical efficiency as single-crystal silicon, the presence of grain boundaries gives rise to additional losses and a lower realizable efficiency. Most interesting of the casting techniques are those which produce sheet material of 50-100 μm , a thickness which provides essentially total optical absorption of the AM1 spectrum in a ready-to-use substrate. However, for good current collection efficiency, such material must have grains which extend completely through the sheet and are several sheet thicknesses in diameter. So far, such material is not being reliably produced and post-casting treatments are being investigated to improve grain size, including laser and electron-beam-pulse melting followed by rapid recrystallization.

Another approach to a thin-film silicon photovoltaic cell involves the use of hydrogenated amorphous silicon. This material is prepared by establishing a glow discharge in silane, SiH_4 , and recombining the atomic components of the dissociated gas on a substrate placed near the discharge. If substrate temperature is controlled, a specific amount of hydrogen can be incorporated into the amorphous film. The result is a reduction in the amorphous silicon defect density and an adjustment in the bandgap energy. Material prepared by the discharge method has a very high optical absorption coefficient for photons of energy in excess of the bandgap value, and only 1- μm -thick films are needed to provide nearly complete photon absorption. In addition, the higher bandgap energy of amorphous silicon promises less efficiency decline with increased operating temperature than occurs with crystalline silicon. To date, however, the highest efficiency demonstrated in an amorphous silicon photovoltaic device at AM1 illumination is less than 6%.⁽⁸⁾ With some confidence, an efficiency of 7-8% can be projected, but additional, fundamental discovery will be required to reach the

11% array efficiency cited in Table 2-1.

Gallium arsenide, GaAs, is a nearly ideal photovoltaic material in terms of its excellent energy bandgap match, 1.43 electron volts, to AM1 sunlight and its high optical absorption coefficient above the threshold wavelength. Devices of about 23%⁽⁹⁾ conversion efficiency at AM1 have been produced, and the ability of this material to work at a higher temperature than silicon or cadmium sulfide-copper sulfide ($\text{CdS-Cu}_2\text{S}$) has favored its application in high-concentration systems. As with crystalline silicon, GaAs photovoltaic devices are well understood and the projected array efficiency of 12-16% given in Table 2-1 is well supported.

Thin-film polycrystalline GaAs films have been grown by vapor deposition on a variety of substrates, but the performance of p-n junction photovoltaic devices using this material has been compromised by excessive grain-boundary diffusion of the dopants used for junction formation. Schottky barrier polycrystalline GaAs cells have been made with an efficiency of about 5%.

The $\text{CdS-Cu}_2\text{S}$ system has been widely studied since its photovoltaic properties were discovered in 1954. The interest in this system has been sustained by the promise of at least two low-cost manufacturing technologies suited to very large-scale production and by the hope that further research would overcome the early problems of modest efficiency, 5-6% for typical production cells, and poor life except under carefully controlled environmental conditions. To date an efficiency of 9.15%⁽¹²⁾ has been achieved in the laboratory for $\text{CdS-Cu}_2\text{S}$ photovoltaic cells, and a projection to 10% device efficiency for this material is well founded. The higher efficiency required to yield an array value of 11% is based on the cited development of the $[\text{CdZn}]\text{S-Cu}_2\text{S}$ cell, where the incorporation of the zinc is intended to give a better electron affinity and lattice match across the junction. However, preliminary experimental results with this system have indicated difficult development ahead, and the array efficiency may be limited to the middle of the projected range.

For a long life and reliable operation, all photovoltaic cells require some form of protective covering. Aside from protection against dirt and moisture, the active region of the cells must be kept free from contact with various atmospheric pollutants which can migrate through the semiconductor and deteriorate performance. Some solar cells such as CdS-Cu₂S are particularly dependent on a glass-faced, hermetic enclosure for a useful life, but, even for silicon and gallium arsenide, it is not clear that anything less than this type of completely hermetic encapsulation will provide the 10- to 20-year cell life desired.

B. System Options

Figure 2-2 shows a generalized diagram of a solar photovoltaic power plant, including provisions for a utility tie line over which power may be extracted or transmitted, depending on the requirements of the local load and the local photovoltaic power generation. Individual installations, particularly in the 10-kW peak to 100-kW peak range, are likely to be less complex than the system shown and may contain as little as a solar cell panel, the DC switchgear, and a DC load. Addition of the DC/AC inverter to this basic system would permit AC loads to be serviced. The addition of batteries and the charging regulator would increase the power plant utilization factor. The further addition of the AC switchgear and the AC/DC converter would permit the utility tie-line connection, and, finally, concentrators and/or cell heat exchangers could be added for cost or performance reasons.

The first major component of the system is the photovoltaic array itself, which may be a directly illuminated flat panel, or it may incorporate a concentrator. Unlike the solar thermal converter, there is relatively little direct performance benefit to operating photovoltaic materials at very high intensity levels,⁽¹³⁾ and the principal reasons for considering concentration in a photovoltaic system are economic. At present, the per-unit-area cost of reflectors (or refractive lenses) is 5-15 times lower than the unit-area cost of crystalline silicon photovoltaic

SOURCE: Reference 14.

FIGURE 2-2 SOLAR PHOTOVOLTAIC POWER PLANT SCHEMATIC

cells. Therefore, the cost of a photovoltaic panel can be greatly reduced if expensive photovoltaic cell area is replaced by relatively inexpensive reflector (or lens) area capable of concentrating solar radiation. Clearly this advantage of concentration will be diminished as the cost of photovoltaic cells is reduced and will vanish entirely when cell cost becomes roughly equivalent to that of reflectors on a per-square-foot basis.

An additional reason for considering concentration is that it may make feasible the use of very high efficiency (20-40%) photovoltaic cells, which may be extremely expensive on a unit-area basis, and/or which may be fabricated from material of limited availability. Some of the multiple-junction III-V* compound photovoltaic cells now in development might fall into this category. The use of such high-efficiency material could dramatically reduce the collecting aperture for a given system-power level, and thereby provide a more attractive system option from both environmental and cost viewpoints.

Concentrators applicable to photovoltaic arrays range from simple flat reflectors to refractive Fresnel lenses and Cassegrain optical systems. (See Chapter 3 for more detail on concentrating optics.) The type of concentrator selected will be largely dependent upon the level of concentration desired. The flat-plate or passive reflector will provide concentration ratios up to 2X. Compound parabolic concentrators are best suited for concentration ratios in the 2X - 10X range. Linear concentrators, such as parabolic troughs, are appropriate for concentration ratios in the 10X - 40X range. For concentration levels greater than 40X, point-focus systems are being developed.

The use of concentrators and the resultant increase in solar cell irradiance requires careful thermal design to limit the solar-cell operating temperature. Liquid cooling is generally used above 2X, and there may be an opportunity to apply the warm water to local heating needs. With silicon cells, the maximum water temperature would be limited to about 50°C. With a higher bandgap material such as GaAs, the water temperature could be allowed to rise to 85-90°C.

*These are compounds formed from elements of the third and fifth columns in the periodic table.

The second essential component of the photovoltaic system, the DC switchgear, has two functions. First, it must allow selection of load alternatives, e.g., storage, load usage, or transmission via utility tie line; and second, it must optimize the power transfer from the array to the load by continually adjusting the array interconnections so that an impedance match is maintained. In view of the variations in illumination intensity over the array, and from one location on the array to another under scattered clouds, the DC switching function is extremely important in achieving good array performance.

DC-to-AC inversion will be required for most local loads, since the majority of electrical equipment now in use has been designed for AC operation.

The AC switchgear will function primarily to direct power from or to the utility tie line, if one is used, to balance the AC load requirements against the power which is locally produced.

The contribution of energy storage to the operational value of PV power systems has been considered in several studies, ^(15,16,17) and the economic benefit of such storage has been found to be very sensitive to the rate structure and power sell-back opportunities associated with the local utility grid. Battery life is also an important consideration. Without time-of-day pricing, no sell-back of excess PV power, and a 10-year battery life, the value of storage was found to be less than \$20/kWh (1977 dollars). ⁽¹⁵⁾ A time-of-day rate variation of 3:1, a sell-back ratio of 0.5, and an assumed battery life of 20 years were found to justify storage costs in the range of \$100-\$150/kWh (1979 dollars). ⁽¹⁷⁾

The optimum size of the PV array for a given user is also strongly influenced by the availability of storage.

Figure 2-3, which has been taken from the General Electric study, ⁽¹⁵⁾ shows the effect of array size and energy storage (in this example, battery storage) on the PV displacement of central station power for three selective locations. It is readily evident that the addition of moderate amounts of such storage, about six hours of peak

SOURCE: Reference 15.

FIGURE 2-3 PERFORMANCE SENSITIVITY TO ARRAY AND BATTERY SIZE

array output, would provide significant additional displacement of central station power. Where storage is economically justifiable (based on the consideration given above), its use increases the optimum size of the PV array.

Section 2.3: Economics Discussion

A. The Photovoltaic Array

Because the technology of photovoltaic material and array production is still rapidly evolving, the ultimate costs of manufacture are difficult to project. The driving force for the present broad-range cost reduction effort in photovoltaics is the DOE Photovoltaic Conversion Program.⁽¹⁸⁾ The objectives of this program are summarized in the National Photovoltaic Program Plan (February 3, 1978) and include photovoltaic array price targets of \$2000/peak kW by 1982, \$500/peak kW by 1986, and \$100-300/peak kW by 1990. These targets are given in 1975 dollars. All subsequent costs will be given in 1977 dollars, where one 1975 dollar = 1.12 1977 dollars.

Of the several estimates of future PV array prices^(19,20,21) for those photovoltaic materials identified in Table 2-1, the more optimistic involve extremely large extrapolations from present manufacturing costs and require fundamental technical and manufacturing advances in order to be realized. Table 2-2 illustrates the range of PV price estimates which must be considered at this time. The upper price limit is set by assuming that single-crystal silicon remains the dominant PV material and that only modest production efficiency gains and the use of concentrators are employed to reduce prices. The lower price limit, on the other hand, could be realized by a breakthrough in thin-film cells, in which case, the simple planar array would be favored. For comparison, the DOE price targets are also given in Table 2-2, expressed now in terms of 1977 dollars. These targets are seen to be close to the most optimistic price projections.

TABLE 2-2

PHOTOVOLTAIC ARRAY PRICE PROJECTIONS⁽¹⁾ IN 1977 (\$/Peak kW)

	<u>1977</u>	<u>1982</u>	<u>1985</u>	<u>1986</u>	<u>1990</u>	<u>2000</u>
Upper	20,000		3,000			1,000
Lower	12,000		500			100
DOE Targets	--	2,240		560	112-336	

(1) Note that no allowance has been included for space cost or supporting structure.

SOURCE: References 18, 19, 20, 21, and Arthur D. Little, Inc.

B. Balance of the Photovoltaic System

Unlike the technology of the photovoltaic array, the technology required for switching and conditioning the power produced by the array is well established, and prices may be estimated accurately from available production components. Table 2-3 provides a summary of such costs. The price ranges indicated depend principally on the scale of the installation with the lower figure appropriate to equipment of 100 kW and larger, and the higher figure applicable to equipment of 10 kW or smaller. For these estimates, it is assumed that:

- the local load is primarily for AC power;
- a utility tie line is available to supply power in excess of the photovoltaic capability; and
- a good power factor is presented to the utility tie lines.

Increased production volume is projected to reduce the above prices by about 20% for the year 2000. Table 2-4 provides a summary of the capital cost projections for the PV-DES without storage. The addition of storage equal to six hours of peak array output would add \$500-\$800/kW to the estimates, thus improving energy availability at higher cost and lower overall system efficiency.

TABLE 2-3

POWER CONDITIONING AND SWITCHING COSTS 1977 (\$/Peak kW)

DC Array Switching ⁽¹⁾	100-150
AC Switching ⁽²⁾	30- 50
DC/AC Inversion	
• Line Commutated ⁽³⁾	100-200
• Self-Commutated ⁽⁴⁾	200-500

(1) To optimize power transfer to load

(2) Utility/local load/PV power interface.

(3) Residential units under 10 kW.

(4) Required for stand-alone systems or where utility tie line cannot supply switching current.

SOURCE: Arthur D. Little, Inc., estimates based upon discussions with manufacturers, June 1978.

TABLE 2-4

PV-DES CAPITAL COST PROJECTION IN 1977 \$/PEAK kW

	<u>1977</u>	<u>1985</u>	<u>2000</u>
Land ⁽¹⁾			
Support Structure ⁽¹⁾	100 - 200	100 - 200	100 - 200
Photovoltaic Array ⁽²⁾	12,000 - 30,000	500 - 3,000	100 - 1,000
Power Conditioning	<u>500 - 1,000</u>	<u>230 - 900</u>	<u>200 - 700</u>
	12,600 - 31,200	830 - 4,100	400 - 1,900

(1) No separate land acquisition cost is allocated since arrays will most likely be integrated with the exterior of the buildings they serve. The support structure cost figure is an estimate of the supplemental cost of such buildings or the cost to modify existing ones.

(2) Cost of the photovoltaic array in $\$/m^2 = \eta I \times \text{cost in } \$/kW$, where η = array efficiency, and I = peak solar irradiance in kW/m^2 .

SOURCE: Arthur D. Little, Inc., estimates.

Section 2.4: Limitations

Other than economics, the principal non-institutional limitations on the application of the PV-DES are :

- the availability of sunlight,
- the availability of photovoltaic material,
- the energy requirements of production,
- the life expectancy and reliability of the photovoltaic array, and
- the environmental impact of the production of PV-DES components, their installation, and their use.

As previously noted, the flat-plate array is likely to be the most prevalent form of photovoltaic energy collector, and a number of analyses have been made^(22,23,24) of the solar radiation incident on a tilted surface. Such analyses are based upon National Weather Service horizontal insolation measurements^(25,26) and upon models of the direct and diffuse solar radiation. These data have been compiled, rehabilitated, and coordinated with surface meteorological observations by the National Oceanic and Atmospheric Administration.⁽²⁷⁾

Neville⁽²⁸⁾ has computed the solar energy which is potentially available at selected sites within the United States for flat-plate collectors, i.e., planar photovoltaic arrays, of both tracking and non-tracking designs. His results, summarized in Table 2-5, show that local weather conditions are even more important than latitude in determining solar energy availability. In some parts of the continental United States, the solar energy available for fixed-position, flat-plate arrays is double that available in other regions, for example, the clear weather areas of the Southwest versus Seattle or Boston. However, up to latitudes of 43° at least, the energy availability is 60-70% of the Southwest levels. Thus the PV-DES may not be at a great disadvantage in the more northerly areas of the country.

Figure 2-4 illustrates the impact of current material availability on the potential for power generation in that it shows the peak power generating capability which would be realized if the total annual

TABLE 2-5

POTENTIAL SOLAR ENERGY FOR SELECTED CITIES - ANNUAL TOTAL(in units of kWh/m^2)

	HONOLULU, HI	MIAMI, FL	NEW ORLEANS, LA	PHOENIX, AZ	SANTA BARBARA, CA	FLAGSTAFF, AZ	FRESNO, CA	WASHINGTON, DC	NEW YORK, NY	BOSTON, MA	BURLINGTON, VT	SEATTLE, WA	FAIRBANKS, AK
North Latitude	21°18'	25°47'	29°51'	32°27'	34°25'	35°12'	36°44'	38°54'	40°45'	42°4'	44°18'	47°37'	64°48'
$E_{TP}^{(1)}$	3195	3177	3037	3004	2966	2957	2915	2862	2832	2795	2748	2678	2210
E_{TPW}	2085	2076	1817	2580	2163	2141	2401	1688	1721	1629	1370	1272	1073
E_{HOR}	1307	1235	1078	1476	1184	1198	1334	907	1003	849	716	634	423
E_{10}	1532	1425	1276	1785	1450	1459	1627	1153	1119	1058	900	812	720
E_{20}	1713	1852	1466	2050	1700	1675	1898	1311	1311	1236	1044	952	720
E_{WT-10}	1987	1953	1701	2369	1935	1930	2203	1517	1511	1420	1194	1097	787

(1) Here, E_{TP} is the maximum amount of solar energy available; E_{TPW} is the energy available to an ideal tracking collector after correction for weather; E_{HOR} is the energy which a horizontal collector will provide; E_{10} that of a flat-plate collector inclined 10° to the horizontal and facing south; E_{20} inclined 20° facing south; and E_{WT-10} the energy supplied by a collector inclined 10° facing south but with east-west tracking.

SOURCE: Reference 28.

SOURCE: Reference 29.

FIGURE 2-4 PEAK POWER PRODUCTION CAPABILITY OF SEVERAL MATERIALS USING PRESENT PRODUCTION RATE IN THE U.S. 10% EFFICIENCY, 100 MW/cm² INSOLATION, NO CONCENTRATION

United States production of Cd, Ga, In and semiconductor grade Si were dedicated to photovoltaic use in planar, non-concentrating arrays at 10% efficiency. The curve labelled GaAs(Al), rather than the lower GaAs curve, would apply if the gallium present in aluminum ore were recovered rather than discarded as waste.

Further considerations on material abundance^(29,30) show that of the elements contained in the candidate semiconductors, only silicon, zinc, copper, tin, sulfur, phosphorus, and oxygen place no limits on photovoltaic cell production due to their availability. Cadmium, antimony, and gallium are intermediate in availability, and their large-scale use, i.e., annual production of new peak capacity greater than 10⁹ We, could cause supply dislocations, while indium and tellurium are so scarce that they can be considered only for very material-conserving systems, i.e., those operating at high concentration ratios.

The energy costs of photovoltaic cell manufacture have been estimated for selected production processes^(31,32) primarily involving single-crystal silicon, but it is very difficult to assess the relevance of such

estimates to the production methods which will ultimately be applied in large-scale manufacture. Clearly, the energy consumption required to produce photovoltaic arrays will become increasingly important as production quantities rise since this energy requirement will be in competition with other energy needs in a period of escalating energy cost and declining availability from fossil fuel sources.

The life expectancy of photovoltaic arrays will depend upon the choice of photovoltaic materials, the cell design, the method and materials used for encapsulation, and the operating temperature. Gandel et al.⁽³¹⁾ have estimated that silicon and gallium arsenide photovoltaic cells will have a life expectancy of about 10 years and cadmium sulfide cells will have a life expectancy of about 5 years. The basis for these estimates was not detailed and their applicability to future production cells is uncertain. Reliable life expectancy data will be available only when photovoltaic cells of production design have been subjected to long-term testing under actual field conditions.

The environmental impact of the PV-DES may also be largely associated with the manufacturing process. The actual deployment of the arrays themselves should have little impact on the local environment, particularly if they are mounted on existing structures or future buildings which satisfy other local needs. However, the manufacture of the arrays will require substantial mining of selected materials and subsequent chemical and electronic processing. These processes and their energy requirements may indeed have substantial environmental consequences.

REFERENCES

1. Rappaport, P., et al. "The Photovoltaic Effect." Photoelectronic Materials and Devices. Edited by S. Larach. New York: D. Van Nostrand Company, Inc., 1965. pp. 239 ff.
2. Landsberg P.T. "An Introduction to the Theory of Photovoltaic Cells." Solid State Electronics 18(12):1043, December 1975.
3. Prince, M.B. "Silicon Solar Energy Converters." Journal of Applied Physics 26(5):534, May 1955.
4. Swanson, R.M., et al. Silicon Photovoltaic Cells in Thermophotovoltaic Conversion. Prepared by Stanford Electronics Laboratories for Electric Power Research Institute, February 1977. EPRI Report No. EPRI-ER-478.
5. Sodba, M.S., et al. "Performance of Diffused Vertical Multijunction Solar Cell." Solar Energy 18(3):265, 1976.
6. Varian Associates, 611 Hansen Way, Palo Alto, California 94303. Private communications. 1977.
7. Wolf, M. "A New Look at Silicon Solar Cell Performance." Energy Conversion. New York: Pergamon Press, 1971. Vol. II. pp. 63 ff.
8. Carlson, D.E., et al. "Amorphous Silicon Solar Cells." Applied Physics Letters 28(11):671, June 1, 1976.
9. Hovel, H.J. "Solar Cells." Semiconductors and Semimetals. Edited by R.K. Willardson and Alfred C. Beer. New York: Academic Press, 1975. Vol. II. pp. 71 ff.
10. Rothwarf, A. Theoretical Prospects of the CdS-Cu₂S Solar Cell. Prepared by Delaware University, Institute of Energy Conversion for National Science Foundation, March 1976. NTIS Report No. PB 252 409.
11. Lindmayer, J. "Semi-crystalline Silicon Solar Cells." Twelfth IEEE Photovoltaic Specialists' Conference, Baton Rouge, Louisiana, November 15-18, 1976. Paper 2.3.
12. Meakin, J.D. "Cadmium Sulfide-Copper Sulfide Heterojunction Cell Research." Photovoltaics Advanced Materials Review Meeting Proceedings, October 1978. Sponsored by Solar Energy Research Institute, Golden, Colorado. pp. 291 ff.
13. Dean, R.H., et al. "Silicon Solar Cells for Highly Concentrated Sunlight." RCA Review 36(2):324, June 1975.
14. Pope, M.D. "Solar Photovoltaic Field Tests and Applications Program." Proceedings of the ERDA Semiannual Solar Photovoltaic Program Review Meeting, Orono, Maine, August 3, 1976. Sponsored by Maine University for Energy Research and Development Administration. pp. 588 ff. NTIS Report No. CONF-760837-P2.

REFERENCES (continued)

15. Kirpich, A. Conceptual Design and Systems Analysis of Photovoltaic Systems. 3 volumes. Prepared by General Electric Company for Energy Research and Development Administration, March 1977. NTIS Report No. ALO/3686-14 (V.1-3).
16. Clark, R., Sandia Laboratories. "Storage for Photovoltaics." Photovoltaic Advanced Research and Development Annual Review Meeting Proceedings, Denver, Colorado, September 17-19, 1979. Sponsored by Solar Energy Research Institute, Golden, Colorado. To be published December 1979.
17. Pittman, P.F. Conceptual Design and Systems Analysis of Photovoltaic Power Systems. Final Report. Volume 1: Executive Summary. Prepared by Westinghouse Electric Corporation for Energy Research and Development Administration, April 1977. NTIS Report No. ALO-2744-13 (V.1).
18. U.S. Department of Energy. National Photovoltaic Program Plan. February 3, 1978. NTIS Report No. DOE/ET-0035(78).
19. Office of Technology Assessment. Application of Solar Technology to Today's Energy Needs. Washington, D.C., June 1978. Vol. I, Chapt. X. pp. 393-394, 405 ff.
20. Moore, R.M. "Cost Predictions for Photovoltaic Energy Sources." Solar Energy 18(3):225, 1976.
21. RCA Corporation, 30 Rockefeller Plaza, New York, New York 10020. Private communications. 1977.
22. Liu, B.Y., et al. "Daily Insolation of Surfaces Tilted toward the Equator." ASHRAE Transactions. 68:526, 1962
23. Norris, D.J. "Solar Radiation on Inclined Surfaces." Solar Energy 10(2):72, 1966.
24. Klein, S.A. "Calculation of Monthly Average Insolation on Tilted Surfaces." Solar Energy 19(4):325, 1977.
25. Baldwin, J.L. Climates of the United States. Prepared by U.S. Department of Commerce, National Oceanic and Atmospheric Administration. Washington, D.C.: Government Printing Office, 1973. GPO Document No. C55.202:c61.
26. National Climatic Center. Local Climatological Data; National Summary. Asheville, North Carolina: Environmental Data and Information Service, National Oceanic and Atmospheric Administration, published monthly and annually. Superintendent of Documents Classification No. C55.287/2.
27. National Oceanic and Atmospheric Administration. Hourly Solar Radiation - Surface Meteorological Observations, SOLMET, Vol. 1, Users Manual. Washington, D.C.: U.S. Department of Commerce, December 1977.

REFERENCES (continued)

28. Neville, R.C. "Solar Energy and the Residence - Some System Aspects." Solar Energy 19(5):539, 1977.
29. Hovel, H.J. "Solar Cells." Semiconductors and Semimetals. Edited by R.K. Willardson and Alfred C. Beer. New York: Academic Press, 1975. Vol. II. pp. 217-222.
30. Arthur D. Little, Inc. Evaluation of Solar Cells for Potential Space Satellite Power Applications. Prepared for National Aeronautics and Space Administration, June 1977. NASA Report No. 77-30612/4GA. pp. 11 ff.
31. Gandel, M.G., et al. Assessment of Large-Scale Photovoltaic Materials Production. Prepared by Lockheed Missiles and Space Company, July 1976. Report No. LMSC-HREC-D496940. Available from Defense Documentation Center, Cameron Station, Alexandria, Virginia 22314.
32. Duncan, C.S., et al. Low Cost Silicon Solar Array Project. Large Area Silicon Sheet Task: Silicon Web Process Development. Report prepared by Westinghouse Research and Development Center for Jet Propulsion Laboratory under contract with the National Aeronautics and Space Administration, 1977. NTIS Report No. N78-23563/7GA.

CHAPTER 3
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: SOLAR THERMAL POWER SYSTEMS</p> <p>DESCRIPTION: Solar energy is converted into heat in a collector system. The heat is used to operate some form of heat engine. The output of the engine can be used for pumping water or gases (irrigation pumping, cooling systems, etc.) or for electric power generation.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, industrial, utilities</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Not yet available on a commercial basis. Several demonstration and prototype systems in operation for solar total energy, irrigation water pumping, electric power generation, and air conditioning.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td><td>.001-30⁽ⁱ⁾</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td>(ii)</td><td>(ii)</td><td>(ii)</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY</td><td>900-2200</td><td>same</td><td>same</td></tr> <tr> <td>(per kW of capacity)⁽ⁱⁱⁱ⁾ SECONDARY</td><td>(ii)</td><td>(ii)</td><td>(ii)</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.20</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:⁽ⁱⁱⁱ⁾</td><td>.10-.25</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.04-.20</td><td>.05-.25</td><td>.05-.30</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Solar Energy AMOUNT NEEDED PER UNIT OUTPUT: 28,500 Btu/kWh @ 12% efficiency</p> <p>ALTERNATIVE FUEL(S): None IS SYSTEM READILY CONVERTIBLE? No</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Follows availability of solar insolation (except for systems with storage)</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Depends on application</p> <p>TECHNICALLY PRACTICAL? Yes, with proper controls</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? SYSTEM: Thermal storage would buffer equipment from short heat input interruptions and/or permit operation of system when solar energy is not available.</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.001-30 ⁽ⁱ⁾	same	same	SECONDARY	(ii)	(ii)	(ii)	UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	900-2200	same	same	(per kW of capacity) ⁽ⁱⁱⁱ⁾ SECONDARY	(ii)	(ii)	(ii)	AVERAGE EFFECTIVE CAPACITY FACTOR:	.20	same	same	RANGE OF CAPACITY FACTORS: ⁽ⁱⁱⁱ⁾	.10-.25	same	same	EFFICIENCY (BTU OUT/BTU IN):	.04-.20	.05-.25	.05-.30
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.001-30 ⁽ⁱ⁾	same	same																																
SECONDARY	(ii)	(ii)	(ii)																																
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	900-2200	same	same																																
(per kW of capacity) ⁽ⁱⁱⁱ⁾ SECONDARY	(ii)	(ii)	(ii)																																
AVERAGE EFFECTIVE CAPACITY FACTOR:	.20	same	same																																
RANGE OF CAPACITY FACTORS: ⁽ⁱⁱⁱ⁾	.10-.25	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.04-.20	.05-.25	.05-.30																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: structural, controls, installation, engine and collector costs)</td><td>2000-4000^(iv)</td><td>1600-3200</td><td>1400-3000</td></tr> <tr> <td>AVERAGE UNIT O&M: ^(v) (\$/kWh)</td><td>.06-.11</td><td>.05-.09</td><td>.04-.09</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>6 - 24 mos</td><td>same</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: structural, controls, installation, engine and collector costs)	2000-4000 ^(iv)	1600-3200	1400-3000	AVERAGE UNIT O&M: ^(v) (\$/kWh)	.06-.11	.05-.09	.04-.09	CONSTRUCTION PERIOD:	6 - 24 mos	same	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: structural, controls, installation, engine and collector costs)	2000-4000 ^(iv)	1600-3200	1400-3000																																
AVERAGE UNIT O&M: ^(v) (\$/kWh)	.06-.11	.05-.09	.04-.09																																
CONSTRUCTION PERIOD:	6 - 24 mos	same	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Limited, but can expand to meet market demand</p> <p>GEOGRAPHIC LIMITATIONS: Limited to areas with suitable insolation characteristics</p> <p>ENVIRONMENTAL EFFECTS:</p> <ol style="list-style-type: none"> 1. Effects related to thermal engine (working fluid leaks, noise, etc.). 2. Effects attributable to heat rejection equipment (cooling towers, etc.). 3. Acquisition of land area. 4. Effects related to land coverage by collectors. <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS:</p>																																		
COMMENTS	<p>(i) For utility size applications, systems up to 125 MW are envisioned.</p> <p>(ii) For some applications waste heat may be recoverable.</p> <p>(iii) These numbers correspond to case with no storage. Higher system capacity factors are possible with storage, in which case the ratio of the rated engine output to array output will be lower.</p> <p>(iv) Cost range for prototype systems in advanced state of development. (See Figure 3-12.)</p> <p>(v) Estimated at 5% of initial system costs and 20% capacity factor. (See Section 3.3.)</p> <p>NOTE: Effective operation is possible only in areas with a high percentage of direct radiation.</p>																																		

CHAPTER 3

SOLAR THERMAL POWER SYSTEMS

Section 3.1: Introduction

In a solar thermal power system, solar energy is converted to heat by a collector system (usually using some degree of solar concentration); this heat is then used to operate a heat engine. The shaft output of the heat engine can be used to drive any form of rotary electric or mechanical equipment such as electric generators, water pumps, or the compressors of cooling systems.

Solar thermal power systems are being developed both for small-scale (1-25 kW) on-site applications^(1,2,3) (irrigation pumping, air conditioning) and for large central systems that produce electric power for the utility grid.^(4,5,6) This size flexibility could make solar thermal power systems well suited for distributed energy system applications.

Many approaches to solar thermal power are being investigated. These include low- to medium-temperature (200-500°F) systems which can utilize low levels of solar concentration, and high-temperature systems (600-1800°F) which require higher levels of solar concentration. Several of the system options are listed below:

Low Levels of Solar Concentration (1X-10X):

- Flat-plate collector with Rankine cycle engine,
- Compound parabolic concentrator (CPC) with Rankine cycle engine, and
- Flat-plate collector using planar reflector with Rankine cycle engine.

Medium Levels of Solar Concentration (10X-40X):

- Parabolic trough with Rankine cycle engine,
- Linear-slat concentrator with Rankine cycle engine, and
- Linear Fresnel lens with Rankine cycle engine.

High Levels of Solar Concentration (50X-2000X):*

- Parabolic dish with open Brayton cycle engine,
- Parabolic dish with Stirling engine,**
- "Power Tower" system with steam turbine, and
- "Power Tower" system with open Brayton cycle engine.

The economic performance of solar thermal power systems is most influenced by the cost and thermal performance of the solar collector subsystem used to convert solar energy into heat.

It should be noted that all of the collectors using medium or high levels of concentration require highly collimated solar radiation (referred to as direct) for their operation. As indicated in the "Limitations" discussion of Section 3.4, in most parts of the country a rather high percentage of the incident solar radiation is scattered by moisture, dust, etc. This radiation, referred to as diffuse, is not utilizable by concentrating systems. In New England, about 40% of the total radiation incident on a south-facing surface tilted at the latitude angle through the year is diffuse, while in the desert areas of the Southwest only 20-25% of the annual radiation is diffuse. Consequently, the performance of medium- and high-level concentrators will vary greatly depending on location.

Several of these collector subsystems appropriate for thermal power applications are discussed in the following sections.

Section 3.2: Technical Discussion

A. Low Level Concentrators

Flat-plate collectors of advanced design have been used as heat sources for operating organic Rankine cycle engines*** at low temperature levels (175-250°F).⁽¹⁾ At these low operating temperature levels, the efficiency of the engines is so low that large areas of collectors are required for a specified power output. It is, therefore, doubtful that

* Higher levels of concentration are possible, but this range is generally considered attainable with current technology.

** Chapter 14.

*** Chapter 15.

solar power units using flat-plate collectors will find wide use, with the possible exception of specialized remote power applications where system simplicity is of paramount importance.

Organic Rankine cycle engines, however, can be operated efficiently with relatively moderate heat-input temperatures of 250-600 °F which can be achieved with low levels (2X-10X) of solar concentration. The most advanced of the options available for low-level focussing (which do not require continuous tracking) is the compound parabolic concentrator (CPC) shown in Figure 3-1. This collector arrangement is in an advanced development stage at the Argonne National Laboratory, and several industrial firms have license agreements, which will probably lead to its near-term commercial availability.

The external appearance of this collector is similar to that of a conventional flat-plate collector. The outer glass or plastic cover plate protects the reflective surfaces from dirt and moisture, helping to ensure stable performance characteristics. Because of its optics, the CPC can utilize solar radiation over a wide acceptance angle (the magnitude depending on concentration ratio). Consequently, the collector need not track the sun on a daily basis and can utilize some of the diffuse radiation.* (See Section 3.4.A for discussion of insolation limitations.) This makes the use of CPC collectors appropriate in a wide range of climatic conditions, and could result in their widespread use within distributed energy systems.

The average annual efficiency of several CPC collector options is shown in Figure 3-2, along with that of a parabolic trough design. As indicated, low-level concentrators can achieve annual efficiency levels of 40-55% at temperatures of 300-550°F, which are consistent with the operation of Rankine cycle engine systems.

B. Medium Level Concentrators

Three types of medium-level concentrators either in use or in an advanced stage of development are:

*Typically, 20-35% for concentration ratios between 3 and 5.

a) Using conventional flat-plate absorber

b) Using evacuated glass tube receivers

Characteristics:

- Accepts radiation over a wide half angle (13.6° for a 3X concentrator) which increases efficiency and minimizes number of tilt adjustments.
- Reflectors are protected by the cover plate which improves efficiency and reliability.
- No tracking required which simplifies installation and operation.

SOURCE: Arthur D. Little, Inc.

FIGURE 3-1 CHARACTERISTICS OF COMPOUND PARABOLIC CONCENTRATOR COLLECTOR

SOURCE: Reference 7.

FIGURE 3-2 ANNUAL COLLECTOR PERFORMANCE

- Parabolic troughs,
- Segmented mirrors, and
- Fresnel lenses.

In a parabolic trough collector, shown in Figure 3-3, the cross section of the reflector perpendicular to the major axis of the collector is a constant parabola which focusses the solar energy on a line. The linear receiver is rigidly located at the focus of this parabola. Several types of receivers are being used, depending on the operating temperature levels under consideration. Evacuated tube receivers, such as those shown in Figure 3-1b, are often considered for use in solar power applications, where there is an incentive to operate at elevated temperature levels.

The geometric concentration ratios for parabolic trough concentrators are typically in the 20X-40X range. The major losses from the more sophisticated collector designs (in general, those using a special or evacuated receiver configuration) tend to be optical and not thermal in nature. Optical losses include the following:

- Surface Quality: For engineering surfaces capable of operation under severe climatic conditions, specular reflectivities range from 0.7 to 0.9. The higher end of this range requires the use of silvered glass which is difficult to form in the shape of a parabolic trough. The use of silvered glass is, however, consistent with several of the segmented mirror configurations.
- Geometric Errors: Precise surface contours (0.1-0.25 degree error tolerance) are required to direct all the reflected light to the receiver assembly. In practice, there will usually be surface contour errors which result in 5-10% of the reflected light being misdirected.
- Dust Factor: Under many realistic operating conditions there will be thin layers of dirt or dust on the reflector surface and these will reduce reflectivity.

SHADOW BAND TRACKER

ABSORBING RECEIVER TUBE

REFLECTING LIGHTING SHEET

MOTOR DRIVE

SOURCE: Acurex Aerotherm, 485 Clyde Avenue, Mountain View, California 94042.

FIGURE 3-3 PARABOLIC TROUGH COLLECTOR

Such layers of dust can easily reduce the amount of reflected light by 5%, even if the reflector is cleaned frequently.

There will also be optical losses associated with transmitting the concentrated sunlight into or onto the receiver. These take the form of transmission losses through glass tubes (with evacuated tube receivers) and non-ideal absorption into the absorber plate. The projected annual efficiency (energy collected annually divided by the total annual insolation incident on the collector) of a typical 25X parabolic trough concentrator for the Albuquerque area is shown in Figure 3-2. Even at noon on a clear day, the optical losses referred to above reduce the efficiency of the collector by about 30%, even at low temperature levels.

A segmented mirror-type concentrating collector is comprised of a receiver assembly and a series of parallel mirrors that reflect the incident energy onto the receiver in much the same fashion as the parabolic trough collectors. Two configurations that are in advanced stages of development are illustrated in Figures 3-4 and 3-5. In the first (SLATS^{®*}), the receiver is affixed to the basic frame of the assembly and the mirrors are rotated about their major axis to direct the light into the stationary receiver.^(8,9) In the second concept, Fixed-Mirror Solar Collector (FMSC), the mirrors are fixed in place and the receiver swings overhead to account for the daily apparent movement of the sun.⁽¹⁰⁾

One motivation for such designs is to reduce the amount of equipment necessary to provide tracking, since it requires a smaller, simpler mechanism to move several small mirrors, or one pipe, than it does to move a comparatively large, rigid trough and receiver assembly. In addition, making the mirror segments to the required tolerance should be less complex than making a large surface to corresponding specifications. Repairs to the reflector surface are also simplified, since only the damaged slat(s) need be replaced. For the rotating-slat design, protection for the reflective surfaces is provided by downward rotation during night, cloudy, or no-demand periods.

* Registered trademark of Suntec Systems, Inc.

SOURCE: Reference 8.

FIGURE 3-4 SLATS[®] COLLECTOR CONFIGURATION

SOURCE: Reference 9.

FIGURE 3-5 FIXED-MIRROR SOLAR COLLECTOR (FMSC) CONFIGURATION

All segmented mirror-type configurations are medium-level concentrators. Therefore, the comments on the optical and thermal losses associated with the parabolic trough designs apply here also.

A Fresnel concentrator can be of either medium- or high-level design.^(9,11) The distinguishing feature of these devices is that light is refracted and not reflected onto the receiver. As illustrated in Figure 3-6, light energy is incident on the top surface of the Fresnel lens. This energy passes through the material (either glass or plastic) and is refracted by small ridges or grooves on the underside of the lens which, though shown flat in the figure, can be either flat or curved. A curved Fresnel concentrator has a shorter focal length than a flat lens system, but is correspondingly more difficult to manufacture.

Tracking requirements are similar to those of reflector-type concentrators for equal levels of solar concentration. Durability of plastic lenses and the difficulty of manufacturing linear glass Fresnel lenses are major challenges which have limited the use of these lens systems. In addition, the difficulty in maintaining clean surfaces under actual use (the grooves tend to become clogged with dust) is of real concern.

C. High Level Concentrators

As previously mentioned, practical medium-level concentrators can achieve concentration ratios of about 20X-40X. High-level concentrators with similar tracking and geometrical accuracies can achieve concentration ratios of 400X to 2000X. However, this higher concentration ratio capability requires two-axis tracking which makes the design and operation of high-level concentrating systems more complicated than those of medium-level concentrators.

Two basic approaches to high concentration systems are being investigated:

- Central receiver, and
- Distributed collector configuration.

SOURCE: Reference 11.

FIGURE 3-6 MEDIUM-LEVEL FRESNEL LENS CONCENTRATOR

A central receiver system (also known as the "power tower" concept) utilizes a large number of individually guided mirrors (heliostats) placed in an array at the base of a tall tower, as shown in Figure 3-7. The incident solar energy is reflected from the mirrors to a receiver mounted on top of the tower, where it is absorbed by a heat-transfer medium (usually steam). The steam so generated can be used to operate conventional steam turbine generator equipment.^(4,5)

The major cost component in such a system is expected to be the heliostats, which require precise two-axis tracking, highly reflective and geometrically precise surface contours, and structural rigidity to withstand high wind loads. Several of the heliostat concepts under development are shown in Figure 3-8.

The primary advantage of the "power tower" concept is that the solar energy from a large area is collected in a central location, which greatly reduces the requirements for piping heat-transfer medium over large distances in comparison with those for systems using a distributed collector array (troughs, etc.). Also, because of the high levels of solar concentration involved (1000X-2000X), it is possible to attain temperatures in the 900-1200°F range, which allows efficient operation of conventional steam power equipment.

The "power tower" system is most often considered for use at high power levels (100 megawatts and higher) in arid, high-insolation regions, with a high percentage of direct radiation. However, the DOE is now studying the use of a mini-power tower for individual irrigation pumping systems at the 150-kW power level which might be applicable for distributed energy systems in some remote geographical regions.⁽¹²⁾

Another approach to high-level concentration, which is well adapted to distributed energy system applications, is the use of parabolic dish concentrators.^(13,14) One such system is shown in Figure 3-9. In this system the concentrated solar energy is used to operate an open Brayton cycle engine, thereby eliminating the need for a heat-rejection system as required by Rankine cycle engines. Brayton cycle engines (which require temperature levels in excess of 1200°F for efficient operation)

NAMEPLATE CAPACITY	215 MW (e)
AVG OVER 4000 HRS	147 MW (e)
TOWER HEIGHT	1500 FT
MIRROR FIELD SIZE	6200 FT OD (outside diameter)
	1160 FT ID (inside diameter)

SOURCE: Reference 5.

FIGURE 3-7 CENTRAL RECEIVER CONCEPT

BOEING

HONEYWELL

MARTIN
MARIETTA

MCDONNELL DOUGLAS

3-15

SOURCE: Reference 9.

FIGURE 3-8 HELIOSTAT CONFIGURATIONS

SOURCE: Reference 14.

FIGURE 3-9 CONCEPTUAL DESIGN FOR 10-kw PARABOLIC DISH/BRAYTON CYCLE ENGINE SYSTEM

are also being considered for use in conjunction with the "power tower" point concentrator system previously described.

Advantages of parabolic dishes include their ability to generate very high temperature levels (Figure 3-10) and their flatter output curve during the day (as compared to that of medium-level concentrators) as a result of following the sun with a two-axis tracking system.

D. System Performance

There is a wide range in the projected thermal/economic performance levels of the various collector/heat engine solar power options being investigated. In general, when operating in arid regions, the higher concentration systems (such as the "power tower") are projected to have more favorable performance characteristics than lower level concentrating systems, primarily because of their ability to operate at higher temperatures and, thereby, higher efficiency levels. On the other hand, these high-concentration systems may entail a higher degree of risk because of uncertainties in the nature of solar radiation (discussed in Section 3.4) and the requirement to maintain precise two-axis tracking under severe environmental conditions.

The systems for which there is the most operational experience at this time are those using parabolic trough collectors and organic Rankine cycle engines. Several such systems have been installed in the United States, and their performance characteristics are currently being evaluated. The performance of this system, which is well adapted for use in distributed energy systems, should be similar to that of other linear concentrator/engine options that are under consideration (for example, segmented mirror systems with steam Rankine cycle engines). Therefore, this system configuration is considered below to illustrate the general performance characteristics of distributed solar thermal power systems in this size range.

SOURCE: Reference 14.

FIGURE 3-10 VARIATION OF PARABOLIC DISH COLLECTOR EFFICIENCY WITH TEMPERATURE

The annual thermal performance of the parabolic trough collectors in these systems is similar to that shown in Figure 3-2. The efficiency characteristics of the organic Rankine cycle engines which can be used to convert solar energy into mechanical power are discussed in Chapter 15.

The collector efficiency and engine efficiency characteristics can be used to determine an overall system efficiency defined as:

$$\eta_s = \eta_c \times \eta_e$$

where:

$$\begin{aligned}\eta_s &= \text{system efficiency,} \\ \eta_c &= \text{collector efficiency, and} \\ \eta_e &= \text{engine efficiency.}\end{aligned}$$

The resultant system efficiency is presented in Figure 3-11. As indicated, for this (and any other collector-engine combination), there is an operating temperature which maximizes system efficiency and, therefore, minimizes collector array area requirements for any specified output. For the design considered, the system efficiency under average solar flux conditions is about 14% and occurs at an operating temperature of about 600°F. However, the efficiency vs. temperature curve is fairly flat, and there may be practical advantages for operating the system at as low a temperature as possible, consistent with acceptable efficiency levels. Such practical considerations include the ability to use a hot water thermal storage system (limited by operating pressures) and choice of materials of construction, pumps, valves, etc. System operation in clear-day, noon flux conditions will result in a higher system efficiency than those shown in Figure 3-11.

E. Energy Availability and Storage

If no storage is used, most of the output from a solar thermal power unit will be produced during a relatively short period of 5-6 hours during the middle of the day. Consequently, without storage, solar thermal power units can be used only to supplement conventional power sources or to handle loads that can be satisfied on a discretionary basis (for example, irrigation water pumping). Without the use of energy storage, 1 kW of

NOTE: Solar insolation = 300 Btu/hr-ft².

SOURCE: Arthur D. Little, Inc.

FIGURE 3-11 OVERALL SYSTEM EFFICIENCY

capacity will generate about 5-8 kWh of electric energy. In fairly sunny areas such as Albuquerque, N.M., the annual capacity factor* of a zero storage system would be roughly 12-16%. This should be considered when comparing the cost of solar thermal power systems with conventional systems which can operate at rated capacity on demand (24 hours per day, as available).

For many applications, energy storage will be required for practical system operation. For solar thermal power systems, thermal storage is generally utilized; this allows operation of the heat engine during periods of low (or zero) insolation and provides a buffer to prevent unnecessary thermal cycling of equipment. For low-temperature systems (up to about 300°F), water can be used as the storage medium. For temperatures up to about 750°F, heat-transfer oils can be used for energy storage, while at higher temperatures various heat-of-fusion salts have been considered.⁽⁹⁾ Practical higher-temperature, energy storage systems are still in the developmental stage.^(15,16)

The output of a solar thermal power system is mechanical energy in the form of shaft power. This form of output is highly flexible and can be used as appropriate to drive electrical generators, the compressors of cooling systems, or water pumps. The applications which are receiving primary attention for use with solar thermal power units are discussed below.

Irrigation Water Pumping:

Water pumping is a particularly favorable application for solar thermal power systems, since the water being pumped can be used for cooling the condenser of the heat engine, the water can be pumped primarily when the sun is shining, thereby eliminating or reducing the need for thermal storage, and water pumping is often required in rural areas where

* Annual capacity factors for system operation without storage in more cloudy regions, such as New England, would be about 9-12%.

conventional energy costs are high. Consequently, irrigation water pumping is the most advanced of the solar thermal power applications. Several dozen small (1-25 kW) water pumps using flat-plate collectors and organic Rankine cycle engines have been installed by Sofretes (a division of Renault Moteurs International of France) in rural areas of Africa and Mexico. (3,17)

A 25-kW system was installed under DOE sponsorship in the Estancia Valley of New Mexico using parabolic trough collectors and an organic Rankine cycle engine. A 150-kW system of similar design was installed in Gila Bend, Arizona, as part of a program sponsored by the Northwest Mutual Life Insurance Company. (18)

Air Conditioning:

The output of a solar thermal power unit can be directly coupled to the compressor of a vapor compression cooling system. Solar air conditioning has the potential advantage that the heaviest air conditioning loads often occur during periods of high solar flux.

Several solar air conditioning systems using solar collector/organic Rankine cycle engine combinations to drive vapor compression cycles have been demonstrated. (2,19) These systems are primarily in the 2-25 ton range (requiring approximately 2-25 hp of solar drive engine capacity) and have utilized both flat-plate and linear concentrator collector systems.

Electric Power Generation:

Any solar thermal power unit can be used to generate electric power, which replaces or supplements that provided by the utility. This application is often complicated by the requirement for precise speed control and switch gear to ensure a proper interface between the solar power system and the utility. To date, solar thermal electric power systems have not been extensively demonstrated. However, the primary thrust of the DOE program and, in particular, the "power tower" program is to generate electricity to be fed into the electric grid. Furthermore,

the Jet Propulsion Laboratory has initiated a program to develop smaller (1-5 MW) solar thermal electric power systems for use within a distributed energy system context. (20)

Total Energy System:

The heat engine of a solar thermal power system rejects most (60-85%) of its input energy as heat at relatively low temperature levels (80-200°F). This lower temperature reject heat can be used for space heating or for process/domestic hot water preheating. For this reason, there has been an active program at the Sandia Laboratories for over four years to develop solar thermal power systems for use within a total energy system context. (21,22)

Solar total energy systems are particularly well suited for use within a distributed energy system since the energy-conversion devices (both electrical and thermal) can be placed close to the buildings being served.

Section 3.3: Economics Discussion

There has been very limited experience with solar thermal power systems because they are in the experimental stage. Thus, there is a wide variation in cost projections, making it difficult to establish even a rough guide with regard to the cost and economic performance of the power system options.

The system option for which costs are best formulated is the example system discussed in Section 3.2, i.e., a parabolic trough/organic Rankine cycle engine. It is expected that these costs will be similar to those of many other distributed system (SLATS[®], CPC, etc.) arrangements. Such systems are being considered for small power units (typically 3-500 kW) which might be used in remote regions for pumping and power-generating functions. Such applications are often serviced by engine-driven pumps and generators.

Table 3-1 indicates the present and projected costs of a range of solar concentrator options. The costs indicated for larger quantities were rough estimates at the time of the survey (1976) and generally not based on time-proven designs (because they are subject to change as dictated by experience). However, these figures indicate that a concentrator

TABLE 3-1

STATUS OF SOLAR CONCENTRATOR SYSTEMS

<u>TYPE</u>	<u>COMPANY</u>	<u>CONCENTRATION RATIO</u>	<u>PRESENT WHOLESALE PRICE (\$/ft²)</u>	<u>MASS PROD. PRICE (\$/ft²)</u>	<u>CURRENT STATUS</u>
CPC	Steelcraft, Inc.	-	25 (excluding rack)	15-20 (excluding rack)	commercial production
Parabolic trough	Alberquerque- Western, Inc.	20	4.50-4.75 (plus tracker)	developing advanced design	commercial production
Parabolic trough	Beam Engineering	-	22 or less	"much less"	commercial production
Parabolic trough	Acurex Corp. 6' wide	58	15-22	less	commercial
	4' wide	-	13-20	8	production
Parabolic trough	Solartec Corp.	-	9-16	about same	commercial production
Fixed trough; tracking receiver	AAI	8	-	8-9	R&D
Fixed stepped trough; tracking receiver	General Atomic Co.	60	-	6 (installed)	R&D
Fixed stepped trough; tracking receiver	Scientific Atlanta	-	14-15	about same	commercial production
Linear heliostat	Itek	-	-	10	R&D
Linear heliostat	Schedahl	40	20-25	4-10	prototype testing
Linear Fresnel lens	Northrup, Inc.	10	12-17	8 (installed)	commercial production
Parabolic dish	ANSALDO/ Messerschmidt	-	165	less	ready for order
Parabolic dish	JPL	1000	-	11	R&D
Parabolic trough	Sunpower Systems	-	12	about same	commercial production
Multiple parabolic dishes w/solar cells	Varian	1000	60-90 (w/o cells)	very low	R&D
Multiple parabolic dishes w/solar cells	MIT	300-500	-	?	R&D
Fixed dish; tracking receiver	E-Systems, Inc.	-	-	3-5 (installed)	R&D
Multiple Fresnel lens w/solar cells	Sandia Labs	50-100	21 (w/o cells)	5 (w/o cells)	prototype
Parabolic trough	Polysolar	25	NA*	NA	NA

*NA - Not Available.

SOURCE: Reference 9.

cost of approximately $\$8/\text{ft}^2$ to $\$12/\text{ft}^2$ may be attainable in production quantities.⁽⁹⁾ The resultant system cost on an installed basis is estimated in Figure 3-12. As indicated, installed system cost would approach $\$2000/\text{peak kW}$ (without storage), based on the assumptions indicated. The installation costs are significant and probably the most difficult to estimate, because of variations in labor costs, site preparation, etc.

The useful output of a solar thermal power system is measured in kWh per year. For the example system this would be approximately 1750 kWh per year per peak kW of installed capacity when operated in a favorable climatic region such as Albuquerque, New Mexico.

The cost of electrical energy from a solar power unit is a function of many variables, including:

- initial cost,
- operation and maintenance costs,
- interest rates,
- depreciation (useful life), and
- capacity factor.

The curves of Figure 3-13 assume operation in a high solar flux area, the installed system cost shown in Figure 3-12, annual fixed charges of 12%, and annual operating and maintenance costs of 5% of the installed system cost.⁽²³⁾ Curves are provided for two assumptions regarding the time duration of the load:

Case A: Year-round operation

This case assumes that the power unit is used on a year-round basis. Such applications could include electric power generation and desalination.

Case B: Periodic operation

This case assumes that the system is used only half the year.

(1) Refers to peak kilowatt, no storage included.

SOURCE: Reference 23.

FIGURE 3-12 COST OF INSTALLED SOLAR THERMAL POWER SYSTEM
(Parabolic Trough/Organic Rankine Cycle Engine)

SOURCE: Reference 23.

FIGURE 3-13 COST OF ELECTRICAL ENERGY (Parabolic Trough/Organic Rankine Cycle Engine)

This may be the case for many air conditioning and irrigation pumping applications.

The cost of power produced by the system is in the 16-34¢/kWh range for systems with year-round operation. This cost of power is still much higher than that from large central utilities, but may approach that from small Diesel and gas turbine power units if anticipated increases in fuel costs occur.

Power costs from large (150-MW) central receiver power systems are projected to be in the 8-15¢/kWh range.⁽²⁴⁾ These relatively low power-cost projections reflect, in part, the large size of these power units and the assumption of large-scale production of key subsystems. They assume solar availability typical of Albuquerque, New Mexico (approximately 0.7×10^6 Btu/ft²/yr total) and installed heliostat costs in the \$8-\$10/ft² range. These low heliostat costs are estimated to require minimum production levels of 50,000 heliostats per year (sufficient for a total capacity of 250 MW). Because of technical performance and cost uncertainties associated with these systems, there is still considerable disagreement whether the overall economic performance goals for this type of system will be achieved.

Section 3.4: Limitations

A. General Considerations

Solar thermal power generation will probably require some degree of flux concentration to be practical, because of the elevated temperatures required for efficient operation of most heat engines. With the exception of the CPC design, this implies some form of concentrating optics which accept only highly collimated solar radiation. Since, in many areas, a significant portion of the insolation is diffuse (measurements in Phoenix indicate that 20-25% of its total annual insolation is diffuse),⁽²⁵⁾ systems which can utilize only this direct insolation will be at a disadvantage. To make matters worse, a portion of that insolation classified as direct (originating from within 5.5 degrees of the sun) is also

unusable to these systems since they are unable to focus energy from outside the angle subtended by the solar disk (0.5 degree).⁽²⁶⁾

The above considerations could limit the applicability of higher concentration systems to arid portions of the country, where there is less solar scattering by dust, clouds, haze, pollution, etc.

B. Equipment Availability

There are a number of companies offering solar collectors which utilize some degree of concentration and which could be used in power systems. Four of the firms which have supplied concentrating collectors for various demonstration projects are listed in Table 3-2, along with specifications for their equipment. The collector systems indicated have usually been provided on a demonstration basis and, therefore, the supply of these collectors is not as assured as for the flat-plate variety. The CPC collector, which is in advanced development, is not at this time commercially available, although it is expected to be available in the near term (one-three years).

While both the parabolic dish and power tower are being experimentally investigated, neither is available on a commercial basis. The major emphasis being given the "power tower" program indicates, however, that heliostats could become commercially available in the near term (five years) if the test programs now being initiated are successful.

The availability of the heat engines which might be used in solar thermal power systems is discussed separately in their respective chapters.

C. Safety

Aside from the safety considerations associated with the engine (outlined in chapters devoted to each engine), these systems should not encounter safety problems other than those attributable to any system using high-temperature, heat-transfer fluids (oil, high-pressure water, etc.). Care should be taken to avoid spills, burns, etc.

TABLE 3-2

MANUFACTURERS OF CONCENTRATING SOLAR COLLECTORS

<u>Manufacturer</u>	<u>Model</u>	<u>Collector Type</u>	<u>Dimensions</u> (of one unit)	<u>Geometric Concentration Ratio</u>	<u>Temp. Range</u> °F	<u>Cost</u> \$/ft ²	<u>Comments</u>
Acurex-Aerotherm 485 Clyde Avenue Mountain View CA 94042 (415) 964-3200	3001	Parabolic trough	10' x 6'	35:1	250-500		Glass outer receiver tube
	3002-01	Parabolic trough	10' x 4'	40:1	140-250	15 ⁽¹⁾	Exposed absorber
	3002-02	Parabolic trough	10' x 4'	40:1	250-350		Exposed absorber
Hexcel Corp. 11711 Dublin Blvd. Dublin CA 94566 (415) 828-4200		Parabolic trough	20' x (up to 9')	50:1	Air to 600 Water to 350 Oil to 600	17	Receiver contained in box with aperture window
Suntec Systems, Inc. SLATS [®] 21405 Hamburg Ave. Lakeville MN 55044 (612) 469-3471		Movable mirror, fixed receiver slat	10' x 11'	40:1	140-350 ⁽²⁾	20 ⁽¹⁾	All mirrors controlled by common motor and linkage
Northrup, Inc. 302 Nicols Drive Hutchins TX 75141 (214) 225-4291		Fresnel	1' x 10'	10-15:1	Up to 600	28 ⁽³⁾	Mounted in groups of four in a one-axis (North-South) tracking system

(1)Based on 5,000 ft² to 10,000 ft².

(2)Higher-temperature system under development.

(3)Includes tracking mechanism and controls, insulated manifolding, frame, and expansion joints.

SOURCE: Based on data compiled by Arthur D. Little, Inc.,

D. Environmental Concerns

Distributed solar thermal energy systems are expected to be environmentally quite benign. There will be no burned fuel residue or hazardous waste material to dispose of, as with more conventional energy systems, although each engine type may have environmental considerations associated with its use, e.g., with its working fluid.

If a cooling tower is used, the plume could perhaps have a very minor effect on local climate, and the tower itself could adversely affect the view of the landscape. Care would have to be taken to avoid large temperature rises and working-fluid leaks into a local body of water, should this method of direct condenser cooling be selected. However, by the very nature of a distributed energy system, the cooling loads will be comparatively small. Such small-scale systems are not expected to have a serious impact on local ecosystems.

Even a small 10-MW (peak) power plant will require about 80 acres of land for installation. Therefore, one environmentally related issue which could significantly impact the use of solar thermal power units is land availability. In regions of the country where there are large areas of arid land, the land availability issue may not be a significant economic or environmental barrier. In other parts of the country, however, the environmental impact of a solar thermal power plant could be significant since the installation of significant capacities of solar thermal power generating capacity may require utilization of tracts of what is now farm, forest, or grassland.

E. Output

The basic output of all the solar thermal power systems is shaft power which can be used to drive generators, pumps, or compressors. This provides a great deal of flexibility in the use of solar thermal power systems and facilitates integration with the utility (since synchronous alternating power can be produced directly).

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Biancardi, F., et al. "Design and Operation of a Solar-Powered Turbocompressor Air Conditioning and Heating System." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 186 ff.
2. Prigmore, D., et al. "A Prototype Solar Powered Rankine Cycle System Providing Residential Air Conditioning and Electricity." 9th Intersociety Energy Conversion Engineering Conference, San Francisco, California, August 26-30, 1974. pp. 326 ff.
3. Girardier, J.P., et al. "Les Moteurs Solaires et L'Habitat pour Les Zones Arides-Realisations Actuelles et Perspectives." Conference on the Sun in the Service of Mankind, Paris, France, July 2-6, 1973.
4. Sandia Laboratories. Highlights Report Solar Thermal Conversion Program Central Power Projects. Report prepared for Energy Research and Development Administration, March 1977. NTIS Report No. SAND77-8011.
5. Powell, J.C. Dynamic Conversion of Solar Generated Heat to Electricity. Vol. II, Executive Summary. Prepared by Honeywell, Inc. for National Aeronautics and Space Administration, August 1974. NASA Report No. N75-16079.
6. Grosskreutz, J., et al. "Solar Thermal Conversion to Electricity Utilizing a Central Receiver, Open Cycle Gas Turbine Design." 12th Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1209 ff.
7. Arthur D. Little, Inc. Conceptual Design and Analysis of a Compound Parabolic Concentrator Collector Array. Final Report. Prepared for Argonne National Laboratory, August 1977. NTIS Report No. ANL-K-77-3855-1.
8. Suntec Systems, Inc., Lakeville, Minnesota. Product literature. May 1977.
9. Office of Technology Assessment. Application of Solar Technology to Today's Energy Needs. Vol. II. Washington, D.C. June 1977.
10. Aerospace Corporation. Technical Summary of Distributed Collector Concepts. Prepared under Contract No. E(04-3)1101 for U.S. Energy Research and Development Administration, 1976. NTIS Report No. ATR-76 (7523-07)-1(II).
11. Northrup, Inc., Hutchins, Texas. Product literature. November 1976.
12. Alvis, R.L., et al. Solar Irrigation Program Plan. Second Revision. Sandia Laboratories, May 1978. NTIS Report No. SAND78-0308.

REFERENCES (continued)

13. Gupta, B., et al. Technical Feasibility Study of Modular Dish Solar Electric Systems. Prepared under Contract No. NAS3-19740 by Honeywell, Inc. for U.S. Energy Research and Development Administration, March 1976. NTIS Report No. ERDA/NASA/19740-76/1.
14. Arthur D. Little, Inc. Phase I Report - Preliminary Design of a 10KW Solar Heated Open Brayton-Cycle Engine. Prepared for Civil Engineering Laboratory, Naval Construction Battalion Center, Port Hueneme, California, 1977.
15. Comstock and Wescott, Inc., Cambridge, Massachusetts. Product literature and personal communications. May 1977.
16. Bramlette, T.T. et al. Survey of High Temperature Thermal Energy Storage. Report prepared by Sandia Laboratories, March 1976. NTIS Report No. SAND75-8063.
17. Sofretes (Renault Moteurs International), L. Boursdidiere, France. Product literature. May, 1976.
18. Alexander, G., et al. Final Report on the Modification and 1978 Operation of the Gila-Bend Solar-Powered Irrigation Pumping System. Prepared by Sandia Laboratories, March 1979. NTIS Report No. SAND79-7009.
19. Eckard, S. "Test Results for a Rankine Engine Powered Vapor Compression Air-Conditioner for 366K Heat Source." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 1169 ff.
20. Jet Propulsion Laboratory. Executive Summary Point Focusing Distributed Receiver Technology Project. Report prepared for Department of Energy, 1978. Pasadena, California, Jet Propulsion Laboratory Report No. 5104-26.
21. Sandia Laboratories. Proceedings of the Solar Total Energy Symposium. Sponsored by U.S. Energy Research and Development Administration, Albuquerque, New Mexico, January 1977. NTIS Report No. SAND77-0029.
22. Petterson, B., Jr. Solar Total Energy Test Facility Project. Semi-annual Report - October 1976 - March 1977. Report prepared by Sandia Laboratories, August 1977. NTIS Report No. SAND77-0738.
23. Arthur D. Little, Inc. Phase I Report - Solar Assessment Study in Support of the International Ekistics Program. Report prepared for the Argonne National Laboratory, Argonne, Illinois, 1977.
24. Sandia Laboratories. Recommendations for the Conceptual Design of the Barstow, California Solar Central Receiver Pilot Plant - Executive Summary. October, 1977. NTIS Report No. SAND77-8035.

REFERENCES (continued)

25. Information from Desert Sunshine Exposure Tests, Inc., Phoenix, Arizona, September 1976.
26. Gruther, D., et al. "Results from Circumsolar Radiation Measurements." Sharing the Sun! Solar Technology in the Seventies. A joint conference of the American Section of the International Solar Energy Society and the Solar Energy Society of Canada, Inc., Winnipeg, Canada, August 15-20, 1976. Vol. I. pp. 363 ff.

SUPPLEMENTARY BIBLIOGRAPHY

1. Sandia Laboratories. Solar Total Energy Program Semi-Annual Report, April 1975 - September 1975. April 1976. NTIS Report No. SAND76-0078.
2. Selcuk, M. A Preliminary Technical and Economic Assessment of Solar Thermal Power Plants Using Line Concentrators. Jet Propulsion Laboratory, July 1975. NTIS Report No. EM342-302.
3. University of Minnesota and Honeywell, Inc. Research Applied to Solar Thermal Power Systems. Report prepared for National Science Foundation, January 1974. NTIS Report No. NSF/RANN/SE/GI-34871/PR/73/4.
4. Jarvinen, R. "Solar-Heated Air Turbine Generating Systems." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 583 ff.
5. Backus, C. "Fixed Mirror Solar Concentration for Electrical Generation." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 601 ff.
6. Wen, L., et al. "Comparative Performance of Solar Thermal Power Generation Concepts." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 1206 ff.
7. Caputo, R., et al. "Solar Thermal Electric Power Plants: Their Performance Characteristics and Total Social Costs." 11th Intersociety Energy Conversion Engineering Conference, State Line Nevada, September 12-17, 1976. pp. 1216 ff.
8. The Aerospace Corporation. Highlights of the Solar Total Energy Systems, Distributed Collector Systems, and Research and Development Projects Semiannual Review, Atlanta, Georgia, January 26-27, 1976. Sponsored by the Energy Research and Development Administration under Contract No. E(04-3)-1101. El Segundo, California, March 26, 1976. Aerospace Report No. ATR-76(7523-11)-5.
9. Sandia Laboratories. Solar Total Energy Program Semiannual Report, October 1975 - March 1976. June 1976. NTIS Report No. SAND76-0205.
10. McCulloch, W.H. et al. Small Solar Thermal Power Systems Projects Semiannual Report, October 1977 - March 1978. Report prepared by Sandia Laboratories, February 1979. NTIS Report No. SAND78-0951.
11. Sandia Laboratories. An Introductory Comparison of Brayton and Rankine Power Cycles for Central Solar Power Generation. July 1978. NTIS Report No. SAND78-8010.
12. Jet Propulsion Laboratory. Thermal Power Systems Applications Project, Annual Technical Report. Vol. 1. Pasadena, California: California Institute of Technology, Jet Propulsion Laboratory, January 1979.

CHAPTER 4
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: SOLAR HEATING AND COOLING</p> <p>DESCRIPTION: Solar energy is collected as heat for space conditioning, domestic water heating, or industrial process heat.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, industrial</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Basic concepts well established, product design in early stage, although many designs already available</p>																																			
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (Btu/hr) PRIMARY</td><td>10⁴-10⁶ (i)</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10⁶ Btu) PRIMARY</td><td>13-1300</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.15</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.10-.20⁽ⁱⁱ⁾</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.20-.50</td><td>.25-.55</td><td>.30-.60</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Sunlight AMOUNT NEEDED PER UNIT OUTPUT: See Efficiency.</p> <p>ALTERNATIVE FUEL(S): None IS SYSTEM READILY CONVERTIBLE? No</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Diurnal, weather-related, and seasonal variation in sunlight</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p style="padding-left: 20px;">DESIRABLE FOR USER? Yes - active systems generally require electrical ancillary power; passive systems may not.</p> <p style="padding-left: 20px;">TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G. BATTERIES) DESIRABLE? Yes</p> <p style="padding-left: 20px;">SYSTEM: Fossil fuel or electric back-up; thermal storage</p>					1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (Btu/hr) PRIMARY	10 ⁴ -10 ⁶ (i)	same	same	SECONDARY				UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ Btu) PRIMARY	13-1300	same	same	SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:	.15	same	same	RANGE OF CAPACITY FACTORS:	.10-.20 ⁽ⁱⁱ⁾	same	same	EFFICIENCY (BTU OUT/BTU IN):	.20-.50	.25-.55	.30-.60
	1977	1985	2000																																	
UNIT POWER OUTPUT CAPACITY: (Btu/hr) PRIMARY	10 ⁴ -10 ⁶ (i)	same	same																																	
SECONDARY																																				
UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ Btu) PRIMARY	13-1300	same	same																																	
SECONDARY																																				
AVERAGE EFFECTIVE CAPACITY FACTOR:	.15	same	same																																	
RANGE OF CAPACITY FACTORS:	.10-.20 ⁽ⁱⁱ⁾	same	same																																	
EFFICIENCY (BTU OUT/BTU IN):	.20-.50	.25-.55	.30-.60																																	
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/10⁶ Btu/yr)⁽ⁱⁱⁱ⁾</td><td></td><td></td><td></td></tr> <tr> <td></td><td>120 - 240</td><td>95 - 142</td><td>71 - 120</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/10⁶ Btu)^(iv)</td><td>2.4 - 4.8</td><td>1.9 - 2.8</td><td>1.4 - 2.4</td></tr> <tr> <td>CONSTRUCTION PERIOD: Varies with size from a few days for residential water heaters to several months for large industrial systems</td><td></td><td></td><td></td></tr> </tbody> </table>					1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/10 ⁶ Btu/yr) ⁽ⁱⁱⁱ⁾					120 - 240	95 - 142	71 - 120	AVERAGE UNIT O&M: (\$/10 ⁶ Btu) ^(iv)	2.4 - 4.8	1.9 - 2.8	1.4 - 2.4	CONSTRUCTION PERIOD: Varies with size from a few days for residential water heaters to several months for large industrial systems															
	1977	1985	2000																																	
TOTAL INSTALLED UNIT CAPITAL COST: (\$/10 ⁶ Btu/yr) ⁽ⁱⁱⁱ⁾																																				
	120 - 240	95 - 142	71 - 120																																	
AVERAGE UNIT O&M: (\$/10 ⁶ Btu) ^(iv)	2.4 - 4.8	1.9 - 2.8	1.4 - 2.4																																	
CONSTRUCTION PERIOD: Varies with size from a few days for residential water heaters to several months for large industrial systems																																				
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Small at present, but could expand rapidly^(v)</p> <p>GEOGRAPHIC LIMITATIONS: No U.S. limitations</p> <p>ENVIRONMENTAL EFFECTS: Minimal</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: Sun rights, local codes, and installation expertise</p>																																			
COMMENTS	<p>(i) Lower end of range corresponds to residential water heaters.</p> <p>(ii) Based on range of peak-to-annual storage collection rates resulting from geographic variations in incident solar radiation profiles and equipment collection efficiency.</p> <p>(iii) Results per page 4-21 of text are based primarily on data (and estimates) for space heating and hot water systems; however, they may also be valid for many industrial process heat applications.</p> <p>(iv) Based on very preliminary estimate of 2% of initial capital cost per year. Few data are available at present.</p> <p>(v) For most flat-plate collector systems, basic materials and components are commercially available and production tooling is minimal. Existing distribution channels can be used.</p>																																			

CHAPTER 4

SOLAR HEATING AND COOLING

Section 4.1: Introduction

Solar heating and cooling systems use heat collected from the sun's radiation for space conditioning or domestic water heating. The equipment elements include: solar collectors, thermal storage devices, heat-actuated air conditioners (for solar cooling), and the necessary controls and ancillary equipment. Since it is generally agreed that, at least in the near future, solar heating and cooling will tend to supplement rather than supplant conventional systems, the interfaces with conventional equipment and utility-supplied back-up energy are critical. As with all systems involving solar collection, the collected energy will be proportional to the collector area (and efficiency). Present system sizes range from the order of 50 ft² for small domestic water heaters to more than 5,000 ft² for large commercial space heating and/or cooling systems. 37

Solar heating and cooling constitutes an infant but rapidly expanding industry. As recently as the end of 1974, the United States had only 62 solar houses,⁽¹⁾ and now they number in the thousands. The solar heating and cooling industry is projected to have an annual sales volume of \$1.5 to \$2.5 billion by 1990 -- with the cumulative installed capacity equivalent to a savings in national energy use of 0.3 to 0.5%.⁽²⁾ Recent projections of the Domestic Policy Review and Council on Environmental Quality indicate solar heating and cooling may supply 6% of the U.S. energy needs by the year 2000.⁽³⁾ It has also been estimated that, by 2020, solar heating and cooling might supply from 5-10% of the national energy use.⁽⁴⁾

Section 4.2: Technical Discussion

A. Solar Collectors

Solar collectors are devices which, by virtue of geometry or surface properties, absorb solar energy as heat and impart this energy

to a heat-transfer fluid circulated through the collector. The thermal design of collectors involves maximizing the amount of heat absorbed and, at the same time, minimizing the various heat losses. Since the heat losses from the collector will increase with collection temperature, the efficiency of a solar collector (the ratio of heat energy collected to solar energy incident) will decrease with increasing collection temperature.

Flat-plate (or non-concentrating) collectors in which the absorber surface is essentially planar are more applicable to low and moderate temperatures and function successfully for diffuse as well as direct radiation. Very-low-temperature designs (e.g., swimming pool heaters) consist merely of a black metal or plastic absorber sheet through which liquid is circulated. However, in most collectors for space conditioning, the absorber is insulated on the back side and covered on the sunlit side by one or more glazings which are transparent to solar radiation but inhibit convective and radiative losses. A basic collector might employ one or two glass or plastic panes above a flat black absorber. Improvements to this design which can result in increased performance at additional cost and complexity include:

- selective surface coatings on the absorber which are highly absorbent to solar energy but have a low infrared emittance;
- improved pane transmittance by means such as surface etching (to reduce reflection loss) or reduction of absorption within the pane itself (e.g., the use of low iron glass); and
- minimizing convective transfer between the absorber and cover pane by means of transparent honeycomb cells.

The evacuated tubular design is an advanced collector concept capable of moderate- to high-temperature operation without substantial concentration. This device consists of a selective black absorber located within an evacuated cylindrical tube so that radiation and

conduction losses are greatly reduced. The evacuated tubular collector, like the flat-plate collector, collects diffuse as well as direct sunlight.

The concentration of solar energy increases collection efficiency by reducing the absorber area relative to the aperture (collection) area.* High-temperature collection is enhanced by an increased concentration ratio, but this incurs the expense of greater precision of construction and more sophisticated requirements for sun tracking. A variety of designs exist. Many of the designs involve focussing optics that bring the sun's rays to a single point or line focus. On the other hand, non-imaging designs have been proposed which act as light funnels, concentrating the radiation in a smaller area, but without the precision required for focussing and with a greater tolerance in terms of sun tracking. The methods of tracking vary widely, including designs where either the absorber, the complete reflector, or segments of the reflector move. Typical designs discussed in more detail in Chapter 3 include:

- Cylindrical collectors, which result in a line focus. High-concentration parabolic cylinders aligned with axes in the north-south direction can achieve high temperature at the expense of continuous, although rotation only, tracking. Lower concentrating troughs aligned in the east-west position--in approximately the direction of the apparent path of the sun--may require only periodic, seasonal adjustments.
- The compound parabolic reflector⁽⁵⁾ is an example of a non-imaging concentrator which, for a given concentration ratio, may be more tolerant of off-axis radiation than focussing designs.
- The Fresnel lens concentrator, which accomplishes concentration with a Fresnel lens instead of a reflector mirror.⁽⁶⁾

* This permits the economical use of the more sophisticated collection technology.

- The Solar Linear Array Thermal Systems (SLATS)[®] collector utilizes a series of slat-like mirror segments which are moved slightly during the course of the day to track the sun.⁽⁷⁾

The concentrating designs, and particularly the more highly concentrating versions, are not effective in collecting diffuse radiation; and, therefore, the applicability of these collectors may be limited to regions with a large amount of direct insolation. Also, because higher temperature performance generally entails some penalties in terms of cost and system complexity, these designs are more likely to find application in commercial installations requiring air conditioning or industrial process heat applications, rather than residential hot water or space heat applications.

Figure 4-1 illustrates the performance of three typical collectors -- a two-pane, flat-plate collector; a vacuum-insulated tubular collector; and a concentrating collector of the SLATS[®] variety.

This plot, which is the common way of expressing the performance of flat-plate collectors, shows efficiency (the ratio of collected to incident solar energy) as a function of the parameter $\frac{\Delta T}{I}$, where ΔT is the temperature difference between the fluid entering the collector and the ambient air surrounding the collector, and I is the solar radiation incident on the collector per unit area. (In the case of concentrating collectors, which collect only direct radiation, the efficiency and the parameter $\frac{\Delta T}{I}$ should be based on the direct component of total insolation.)

For low-temperature applications, such as solar water heating, the temperature difference between collector and ambient may typically be in the range of 50°F. Therefore, for an average incident radiation of 250 Btu/hr-ft², the parameter $\frac{\Delta T}{I}$ would be about 0.2. In this range, the higher-temperature designs generally do not have a sufficient performance advantage over flat-plate collectors to justify their increased cost and system sophistication -- particularly for small, residential systems. Note that we would expect the collection efficiency to be higher with the

$$\frac{\Delta T}{I} = \frac{\text{Inlet Fluid Temperature} - \text{Ambient Air Temperature}}{\text{Incident Radiation}}$$

SOURCE: Manufacturer's data per Reference 8.

FIGURE 4-1 COLLECTOR PERFORMANCE DATA

evacuated tubular collector -- particularly under cloudy conditions, which lead to higher values of $\frac{\Delta T}{I}$. On the other hand, a concentrator, while having some advantages in performance under clear sky conditions, would not function as well in cloudy weather, where a large portion of the radiation would be diffuse.

For higher-temperature applications, such as air conditioning and many industrial process heat applications, where the parameter $\frac{\Delta T}{I}$ may be in excess of 0.4, the higher-temperature designs generally have a clear advantage over flat-plate collectors.

Solar collectors may employ either liquid or air as the heat-transfer fluid. Liquid heat-transfer fluids tend to result in more effective heat transfer and minimum pumping power at the expense of requiring provisions to avoid freezing, overheating, or corrosion. Air has advantages in reliability and potential for storage stratification, offset to some extent by reduced heat transfer, higher fluid circulation power, and larger duct sizes. For space heat applications, the reasons for choosing between air and liquid may be quite specific to the application and the designer's preference. In concentrating collectors, or where heat-actuated cooling is required, air is unlikely to be effective because of its limited heat-transfer capabilities.

B. Thermal Storage

Thermal storage must function to accept the solar heat when available from the collector and supply it to the system load elements as needed. Functionally, it must have both the desired storage capacity and heat-transfer capability. Most existing systems utilize storage with capacity sufficient for diurnal variations in solar flux -- or, at most, a few cloudy days. An alternative approach is to use long-term storage, designed to cope with several cloudy days,⁽⁹⁾ or even to level seasonal variations in solar radiation and load. Long-term storage designed to use summer sun for winter has been technically demonstrated in early solar work at MIT and by others, although the large storage sizes required have been considered uneconomical to date.⁽¹⁰⁾ The Annual Cycle Energy

Storage (ACES) concept is a variation of long-term storage which uses the storage of ice for summer cooling and its production by means of a heat pump for winter heating.⁽¹¹⁾

The vast majority of present-day solar storage systems utilize materials with high specific heats -- such as water or rocks. However, developments continue on phase-change materials which would result in markedly reduced storage volume and weights. In some instances, where substantial interior temperature swings can be tolerated, the mass of the building can be used effectively for thermal storage.

For low-temperature thermal storage (below 200°F), water has the advantage of high specific heat and good heat-transfer characteristics and has been the material of choice for low-temperature systems involving liquid collectors. The most common containment for water storage has been steel tanks ranging in size from residential solar water heater tanks of as few as 50 gallons to tanks of several thousand gallons for large systems. Other design approaches have included concrete, fiberglass-reinforced plastic, and plastic or rubber-lined wooden containers.⁽¹²⁾

Where air collectors are used, rock storage consisting of beds of approximately 1-in. pebbles is generally used. Rock storage is commonly contained in insulated concrete or wooden bins. This type of storage results in larger stratification, permitting the air sent out to the collectors to be nearly room temperature.

Change-of-phase or latent heat materials have the advantage of high storage capacity. The use of these materials requires the resolution of many technical problems, such as incongruent melting and settling in salt hydrates, a tendency to supercooling, volume expansion on melting, and corrosiveness. Although work continues in this area and it appears to show promise, no change-of-phase heat storage systems have yet been taken to the manufacturing stage other than for small temperature-stabilizing containers. Change-of-phase materials would be particularly attractive for cold storage, since the operating temperature range of materials used for cold storage for air conditioning must necessarily be small -- on the order of 10°F.

Table 4-1 illustrates the relative performance of rocks, water, and a phase-change material for a temperature swing of 20°F. The sensible heat content (per unit weight or volume) of rocks or water corresponding to a temperature change of 20°F is small compared to that of a material experiencing a phase change. Thus the weights and volumes required to store the same amount of heat are considerably larger than those for the phase-change material. For larger temperature swings, the sensible heat content of rocks and water would be increased and the advantage of the phase-change material would be less pronounced. Additional discussion on thermal storage for solar and other applications is presented in Chapter 19.

TABLE 4-1

RELATIVE WEIGHTS AND VOLUMES OF THERMAL STORAGE
MATERIALS FOR 20°F TEMPERATURE SWING AND EQUAL HEAT STORAGE

	<u>Relative Weight</u>	<u>Relative Volume</u>
Typical Phase-Change Material	1.0	1.0
Water	5.0	8.0
Rocks	25.0	17.0

SOURCE: Reference 13.

C. Heat-Actuated Cooling

Heat-actuated cooling (i.e., a cooling system whose power is derived from a thermal energy source) could be used for air conditioning or for a variety of industrial processes involving refrigeration and/or dehumidification. Several heat-actuated refrigeration cycles exist, including the absorption cycle, Rankine cycle, and desiccant cycle.

Absorption machines represent a well-developed technology for air conditioning. Several manufacturers (Carrier, York, Trane) presently market units of 100-ton capacity or greater. Arkla Industries also has equipment down to three tons, including units specifically designed for solar cooling.⁽¹⁴⁾ The lithium-bromide absorption machines can operate at

relatively low inlet temperatures (200°F) and have the advantage of a very close approach to ideal Carnot cycle performance. However, they do require a cooling tower, which is a disadvantage, at least for residential applications.

The Rankine cycle, or other heat-engine-driven cycles, has the capability of shaft-power production, electric drive in the auxiliary mode, and (with some penalty in performance) air cooling. For a given temperature level, the coefficient of performance (COP) is not likely to be superior to that of the lithium-bromide water-absorption machines. However, as development of advanced concentrating collectors progresses, Rankine and other heat engine cycles operating at higher temperatures are expected to have more potential.

Desiccant drying systems use materials, desiccants, or sorbents, which can attract and remove water from an air stream. The materials commonly used remove water by reversible reactions and, therefore, can be regenerated with heat. Some systems involve partial rehumidification with "overdrying" to achieve cooling as well as dehumidification. Some types can operate at relatively low temperatures (i.e., 160°F or less).

Liquid absorbents, such as triethylene glycol, have been used in commercial systems for dehumidification of inlet ventilation air for space conditioning applications and other process uses. Commercial liquid absorbent systems are manufactured by Niagara Blower, Midland Ross, and others. An experimental solar hot-air-driven liquid absorption machine was operated successfully by Löf in the early 1950's.⁽¹⁵⁾ A variation of this design was planned for the Citicorp building, but was not implemented.⁽¹⁶⁾

Concepts involving solid desiccants have been studied experimentally.⁽¹⁷⁾ The Institute of Gas Technology is designing a solid desiccant device for residential use, with a probable size range of 3 to 10 tons of cooling.⁽¹⁸⁾

D. System Design

1. Solar Hot Water Heating

Solar hot water systems can be used for domestic hot water in a variety of building types and for process hot water in industrial applications. In many applications, solar water heating can be relatively cost-effective, since the reasonably low operating temperatures and seasonally steady-load profiles promote high collection efficiency, and the displaced energy is frequently high-cost electric resistance heat.

As shown in Figure 4-2, a solar water heater will consist of a solar collector, a heat-storage tank, and a heat-transfer loop with the necessary ancillary equipment and controls. This configuration, as pictured, is typical of the pumped-loop, remote-storage design most common in the United States. This basic solar hot water heater concept is applicable to a range of building types and process applications and can utilize a variety of different types of solar collectors and heat-transfer loops (including different types of heat-exchanger and freeze-prevention methods), and interface with different types of auxiliary energy. Thermosiphon loops and combined storage/collector units are also design options which, to date, have been used most extensively overseas.

The solar water heater system can be designed either as a preheater with dedicated solar storage or integrated with the auxiliary in such a way that a single tank is used for both solar storage and auxiliary heat addition. The preheater version, with its independent solar storage (frequently equal to daily water consumption), can be readily interfaced with any type of auxiliary water heater. In the integrated tank version which is currently available only with electric auxiliary, the solar heat input is normally supplied near the bottom of the tank and the electric heater element located at approximately midheight, such that the bottom of the tank serves as solar storage and the top as the auxiliary water heater. Both types are in common use, with the integrated type being favored for compactness (and

a. Preheater Version

b. Integrated Tank Version

FIGURE 4-2 SCHEMATIC OF SOLAR WATER HEATING SYSTEMS

lower equipment cost) and the preheater having advantages of easy interfacing with all auxiliaries, as well as providing extra large storage where water consumption is very high.

Solar water heaters are generally designed to supply from 40-70% of hot water load on an annual basis. The economic optimum size, which varies with climatic conditions, is normally a balance between having the system large enough to achieve a reasonably low cost per unit area -- yet not close enough to 100% solar to substantially reduce overall efficiency because the system has excess capacity in summer months.

2. Solar Space Heat and Hot Water

Although there may be certain space-heating-only opportunities, especially when building mass can be used for thermal storage, in most instances solar space heating is combined with a hot water system. Figure 4-3 shows a space heat and hot water system with heat pump and resistance heat auxiliary. In this system, the thermal storage, heated by the solar collector, serves both to preheat water and to provide space heating. Auxiliary heat, shown here in the form of an electric heat pump and resistance elements, supplies the domestic water and space heating requirements when the temperature of thermal storage is not adequate.

For the sake of generality, the heat pump is shown schematically in a multi-mode configuration, having the dual capability of either supplying auxiliary heat in parallel with the solar system as an air-to-air heat pump, or operating in series with the solar tank as a liquid source "solar-assisted" heat pump. The merits of series vs. parallel operation have received considerable attention. The series liquid-source heat pump will tend to have a higher coefficient of performance (COP)^{*} than the parallel air-source heat pump, since its source temperature is generally higher. (Low source temperatures not only reduce COP, but even

* The COP of an electric heat pump is the dimensionless ratio of heat output to electric power input.

FIGURE 4-3 SCHEMATIC OF SPACE HEAT AND HOT WATER SYSTEM WITH HEAT PUMP AND RESISTANCE HEAT AUXILIARY

more importantly, as discussed in Chapter 17, lead to reduced capacity with the resulting need for supplemental resistance heat.) On the other hand, the parallel air-source heat pump operates a smaller fraction of time than the series liquid-source heat pump since, in the parallel mode, solar is allowed to supply heat directly -- and under favorable conditions might supply the total heating load. Most current investigators seem to agree that, in terms of energy consumption, there is no significant difference, although the parallel mode may have a small advantage. (19,20)

In general concept, this system is applicable to a wide range of building types and auxiliary energy sources, since the heat pump can be replaced by fossil fuel heat. The capacity factor of systems involving space heating tends to be lower than hot-water-only systems because of the seasonal variation in load. In northern areas where the seasonally variable space heating load is much larger than the seasonally steady hot water load, it is particularly difficult to achieve both high solar fractions and high capacity factors (without employing very large long-term seasonal storage). However, in terms of overall economics, this can sometimes be offset by the larger space heating systems that have lower costs per unit area because of economies of scale.

3. Combined Cooling, Space Heat, and Hot Water

Figure 4-4 shows schematically a combined space cooling and heating and hot water system. This system involves the addition of a heat-actuated air conditioner to the hot water supply from the solar tank and is otherwise conceptually the same as the space heating system. The addition of cooling tends to level annual load profiles, but the higher temperatures required for the heat-actuated cooling machines either result in low collector efficiency or may require more efficient, more expensive collectors. Also, the performance of systems involving solar cooling tends to be penalized by the relatively low COP of heat-actuated equipment relative to that of electric vapor-compression devices.

FIGURE 4-4 SCHEMATIC OF COMBINED SPACE COOLING AND HEATING SYSTEM WITH HOT WATER SUPPLY, USING HOT AND COLD STORAGE

4. Electric Load Management Aspects

While solar systems reduce the amount of auxiliary energy needed, they do not necessarily reduce the power capacity that a utility must maintain to supply the building. Therefore, it may be desirable to the utility (and to the consumer in terms of reduced energy costs) to incorporate load management into the solar system. One load management approach is to use on-site thermal storage, particularly since the solar system already has storage equipment which might be utilized and/or expanded for this purpose. The Electric Power Research Institute is conducting an extensive, experimental study of solar and/or load management techniques involving thermal storage (in the context of reducing energy consumption and diurnal peak demand) in 10 all-electric residences in Albuquerque, New Mexico, and on Long Island, New York.⁽²¹⁾ Long-term storage may also be appropriate, particularly where the major concern is seasonal, rather than diurnal, peaks. As an alternative to thermal storage, the building's peak demand requirements might be reduced by on-site storage of another energy form -- such as the use of an oil-fired back-up furnace.

5. Passive Systems

Although more difficult to categorize than the active systems discussed above, there are a number of passive methods of using solar energy for building heating and cooling which, in some instances, are more cost-effective than active systems.^(22,23) Although not initially receiving the attention (and Government funding) given to active systems, interest in passive systems is increasing. A recent DOE research and development project summary lists more than 30 passive solar projects.⁽²⁴⁾

Although no complete definition of passive heating and cooling systems has yet evolved, it is generally accepted that in these systems thermal energy flows by natural means such as radiation, conduction, and convection, and any non-renewable energy used to control this process is very small in comparison with the prime energy flows.^(25,26) This definition precludes the type of pumps or blowers

characteristic of the fluid movement in active systems but does not rule out use of small quantities of non-renewable energy for movement of insulation or changes in damper position. A general characteristic of passive systems is that room temperature control is not likely to be as precise as in mechanically controlled conventional, or active solar, systems. The use of building elements for collection and thermal storage, rather than detached collectors and storage tanks, both allows opportunities for improvements in efficiency and economics and results in building temperatures being more responsive to diurnal variations in solar gain and heat loss as well as to extensive cloudy periods. Whether or not the resulting temperature stability is adequate depends on both the skill of the passive solar designer and the attitude of the building occupants.

The simplest type of passive solar system is the direct gain system, using large south-facing windows for solar collection with the building mass providing thermal storage. Some involve dual-purpose collection/storage walls, such as the Trombe wall in systems designed by Centre National de la Recherche Scientifique⁽²⁷⁾ and the drumwall design of S. Baer of Zomeworks Corporation.⁽²⁸⁾ The use of a greenhouse outside a thermal storage wall combines the two approaches discussed above. The Hay-Skytherm system⁽²⁹⁾ is an example of a roof pond with movable insulation which collects heat in the winter and rejects heat in the summer. Thermal siphon systems for hot water heating and space heating are also classed definitionally as passive systems, although in terms of the hardware involved (i.e., the solar collector panels), they have a great similarity to active systems. MIT Solar Building 5, which represents a rather sophisticated approach to temperature control in a direct-gain system, uses light-weight ceiling tiles (containing a phase change material) which are charged with sunlight reflected from louvers in south-facing windows.^(30,31)

Passive systems have traditionally been difficult to quantify because of both the diversity of types and the lack of design and operational data. Although, in general, passive systems are still not

as well defined as active systems, recent work has served both to improve understanding of this approach and indicate its promise. Results of operating passive systems have shown that these systems are capable of supplying substantial portions of building energy, even in relatively poor climates -- in part, because of their relatively low operating temperatures.⁽²⁵⁾ Recent results from HUD programs indicate that the two passive systems measured achieved substantially higher collection efficiency than the active systems measured.⁽³²⁾ Analytical methods are being developed which will be valuable in the analysis of the design of passive systems. The preliminary results indicate that these systems would be expected to have a performance comparable to that of active systems.⁽³³⁾

6. Industrial Process Heat

Industrial process heat accounts for about 25% of all U.S. energy usage -- or approximately equal to that used for heating and cooling of buildings -- with about one-third at temperatures of 350°F or less.⁽³⁴⁾ The possible solar applications range from relatively low-temperature water or air heating for washing or agricultural drying, to high-temperature steam and hot air heating for use in distillation and high-temperature drying. At the lower end of the temperature spectrum, flat-plate collectors may be adequate, whereas, for the higher temperature applications, various concentrating systems will be required.

Although temperature levels and collector design requirements may vary widely from one application to another, industrial process heat installations generally have the common features of large size, permitting economies of scale, and relatively steady load, leading to good equipment utilization and high annual collection efficiencies. The large size of the installations may permit sophistications of design and control and rigorous maintenance procedures which might not be practical in smaller installations, such as those more commonly used for space heating and cooling.

Because of the large investment required, solar heating for

industrial processes has proceeded somewhat more slowly, and the examples are fewer than those for heating and cooling of buildings. However, in recent years, the number of industrial process heat applications has increased, either with private or public funding. Examples include systems for drying agricultural products and lumber, heating or pre-heating process water, pasteurizing beer, curing concrete, and drying fabrics. (35,36)

7. Energy Conservation

Although by definition it is somewhat independent of solar heating and cooling, energy conservation should always be considered in the design of solar heating and cooling systems. In passive systems, the two are likely to be very closely related, as in the case of large windows which must have adequate multiple glazing and/or curtains or other methods of movable insulation to keep heat loss to a tolerable level. Even with active systems where energy conservation methods may be physically distinct from the solar system, it is extremely important that energy conservation be implemented to the point where incremental improvements in energy conservation would have life cycle costs comparable to those of the solar system.

Section 4.3: Economics Discussion

There are many economic indices for judging solar systems. One convenient and graphic parameter which allows the cost of solar heat to be compared with that of heat produced by other energy forms* is the solar heat cost formulation originally used in the pioneering economic work of Löff and Tybout. (37) As shown below, solar heat cost can also be readily related to payback. Solar heat cost (SHC) can be written as:

$$SHC = \frac{(C/A)R}{\bar{\eta} Q_1/A}$$

where:

C/A = total solar system installed cost per unit collector area,

* The benefit of the solar system is the cost of conventional fuel not used--the "fuel saver" mode of operation.

R = annual ownership cost (including amortization and operating and maintenance costs) expressed as a fraction of system cost,

$\bar{\eta}$ = annual collection efficiency (energy removed by heat-transfer fluid/incident solar radiation), and

Q_1/A = annual solar energy incident on the collector, per unit area.

As an alternative index, the standard payback period (SPP), defined as the ratio of first cost to first-year energy savings, can be written:

$$SPP = \frac{C/A}{\bar{\eta} Q_1/A (V/Q)} = \frac{SHC}{R(V/Q)}$$

where:

V/Q = cost, per unit heat quantity, of heat delivered from conventional fuels.

Data and estimates on system costs vary widely. Solar water heaters installed in the New England Electric experiment averaged about \$2,000 for systems which incorporated normally 50 ft² of collector, for an average cost of \$40/ft².⁽³⁸⁾ The installed costs of residential water heaters in Florida in early 1977 averaged about \$30/ft² for new construction and \$35/ft² for retrofit.⁽³⁹⁾ A variety of systems installed on commercial buildings ranged from \$15-50/ft².⁽⁴⁰⁾ A detailed study by MITRE presents costs for various generic solar system types in terms of both fixed costs (largely nonsolar-related) and area-dependent costs (subdivided into ultimate mass production costs and costs subject to experience) for both residential and commercial buildings.⁽⁴¹⁾

Typical results from the MITRE work⁽⁴¹⁾ indicate the 1977 cost of a 50 ft² water heater is about \$31/ft², with an expected ultimate cost of \$23/ft². A recent DOE analysis uses current installed costs of \$25-40/ft² for space heat and hot water systems--with reduction to \$15-20/ft² foreseen.⁽⁴²⁾ As the basis of a 1977 analysis of market development,⁽²⁾ system cost ranges were estimated as \$25-50/ft² for 1977, \$20-30/ft² for 1985, and \$15-25/ft² for 1990 -- all in constant (1977) dollars. These ranges, which appear in reasonable agreement with other sources, were used in the estimation of solar heat costs.

It should be pointed out that these estimates represent costs prior to application of tax credits. The ranges given are intended to be averages of the general spectrum of sizes, equipment types, installation requirements, etc. The cost savings with time arise from projected improvements in distribution, installation techniques, and product design.

Collection efficiency is dependent on collector and system design. Flat-plate systems optimally sized for water heating, and for some space heating applications, can achieve an annual efficiency of about 35%.⁽²⁾ However, systems designed to supply large fractions of space heating -- or to provide high temperature for solar cooling -- can have significantly lower annual efficiency. Likewise, somewhat higher annual efficiencies may be achieved with advanced collectors. However, it is felt that the annual efficiency of 35% is a reasonable average to be used in conjunction with the system costs discussed previously.

Annual incident radiation will vary from about 750,000 Btu/ft² in the Southwest to about 500,000 Btu/ft² in the Northeast. As a nationwide average, we used 600,000 Btu/ft².

Annual ownership cost is defined as the overall annual rate, expressed as a percentage of system capital costs, which covers interest, depreciation, taxes, and operating and maintenance costs. We used a value of 10% -- corresponding to a 20-year mortgage at 8.5%. We further assumed that O&M costs are offset by the positive effects of tax benefits.

On the basis of the foregoing costs and assumptions, we arrived at the solar space heating costs shown in Table 4-2.

TABLE 4-2
SOLAR SPACE HEATING COSTS (1977 Dollars)

<u>Year</u>	<u>\$/10⁶ Btu</u>
1977	12.0 - 24.0
1985	9.5 - 14.2
1990	7.1 - 12.0

SOURCE: Arthur D. Little, Inc., estimates, based on a 10% annual ownership cost, and other assumptions stated in the text.

The above solar space heating costs can be compared directly with the cost of heat delivered from conventional energy. A 1976 survey of typical locations presents the cost of heat delivered from oil and gas (at 60% combustion efficiency) at \$4-6/10⁶ Btu and \$2-5/10⁶ Btu, respectively, and (omitting Seattle, Washington) the cost of electric heating from resistance and heat pump at \$8-15/10⁶ Btu and \$4-7/10⁶ Btu, respectively.⁽⁴³⁾ A 1977 tabulation of conventional energy prices by state leads to similar results.⁽⁴⁴⁾ Note that the solar costs (\$/10⁶ Btu) divided by the annual ownership costs (10%/yr) result in the total installed capital costs (\$/10⁶ Btu/yr) presented on the technology summary sheet.

Table 4-3 compares the cost of solar heat with heat delivered by other conventional energy sources for the 1977 time period, and presents the range of standard payback periods achieved by solar when it displaces conventional energy sources. Note that the standard payback period is an index defined simply as the ratio of first cost of the solar equipment to the first-year energy savings--and, as shown previously (Section 4.3), is equal to the solar heat cost divided by the product of the unit cost of heat delivered from conventional fuels and the annual ownership cost. (When the solar heat cost equals the cost of heat delivered from conventional fuels, the standard payback period equals the reciprocal of the cost of ownership--or, in this case, 10 years.)

TABLE 4-3
1977 DELIVERED HEAT COSTS AND ACHIEVABLE PAYBACK PERIOD

<u>Energy Source</u>	<u>Cost of Delivered Heat (\$/10⁶ Btu)</u>	<u>Standard Payback Period⁽¹⁾ (Years)</u>
Solar	12 - 24	--
Electric Resistance	8 - 15	8 - 30
Electric Heat Pump	4 - 7	17 - 60
Oil	4 - 6	20 - 60
Gas	2 - 5	24 - 120

- (1) This is the payback period for a solar system which displaces the identified alternative energy source.

SOURCE: Arthur D. Little, Inc., estimates per Table 4-2 and other assumptions stated above.

The comparison shows solar heat to be competitive with resistance heating in areas of high electric costs, although not yet with fossil fuels or heat pumps. In the time period from 1985 to 1990, solar heat costs will become increasingly competitive with electric heating and, perhaps, fossil fuels, depending on the cost escalation of these fuels relative to that of solar equipment.

The economic analysis presented above deals with rather simple indices of solar heat costs and simple payback and does not attempt to deal explicitly with all the elements which may go into making financial decisions on solar. However, it is valuable to recognize the impact of some of these factors, particularly operating and maintenance expenses and Government incentives, such as tax credits.

Data on operating and maintenance (O&M) expenses for solar heating and cooling systems are in a very preliminary state. MITRE estimates indicate annual O&M of the order of 1% of initial capital cost per year.⁽⁴¹⁾ Ward, et al.⁽⁴⁵⁾ indicate costs of 1% a year, for maintenance only, for air systems. Calculations of operating costs for solar hot water heaters indicate pump electrical input is equivalent to about 0.5% of initial capital cost per year. As a preliminary estimate, 2% of initial cost per year, as is noted in the summary sheet at the beginning of this chapter, appears reasonable. The economic analysis above did not deal with O&M cost explicitly, or with other issues such as tax credits and escalation in energy savings. The solar heat costs presented assume O&M is one of the factors leading to an annual ownership cost of 10%. In the payback calculations, the first-year energy savings are based solely on the cost of the conventional (electrical or fossil) energy displaced by solar energy. (If the 2% O&M had been included as a penalty against the first-year energy savings, the payback period would be 12.5 years rather than 10.)

The inclusion of tax credits can substantially reduce first cost and make a large impact on solar financing. At this writing, the federal tax credit is 30% on the first \$2,000 of system cost and 20% on the next \$8,000. Additionally, many states offer tax credits, which may be taken in addition to the federal credit. For a \$2,000 solar hot water heater, the federal tax credit alone makes a reduction of 30% in the solar heat costs and standard payback. Arguments can be made that, with this tax credit and by appropriately financing the solar system,

it is possible for the consumer to maintain a net positive cumulative cash flow for a solar hot water heater, even when displacing a reasonably low-cost energy form, such as natural gas⁽⁴⁶⁾ at present energy costs.

The economic outlook for an active system involving direct solar cooling appears less satisfactory in the reasonably near term than for hot water and (optimally sized) space heat and hot water systems, because heat-actuated machinery requires high collection temperatures and tends to have a low coefficient of performance relative to electric air conditioning. For instance, at design point, the inlet water temperature for a 3-ton lithium bromide absorption machine is 195°F, and the system's thermal coefficient of performance* (COP) is 0.72.⁽¹⁴⁾ This relatively low thermal COP puts solar cooling at a disadvantage when competing against electric air conditioning where the electric COP (cooling achieved per unit electrical input) may be three to four times higher. Also, at least for residential applications, the first cost of heat-actuated cooling equipment is very high.

The economics of passive systems are more difficult to quantify and will vary widely with the system type. It is likely that some types of direct-heat-gain passive systems, which may primarily involve substituting double-glazed windows for what might otherwise have been an opaque south wall, can be cost-effective and may result in better economies than active space heat systems. Early data from solar demonstration projects indicate very low system costs for a passive system consisting of plastic glazing retrofitted to an existing warehouse wall.⁽⁴⁷⁾

Industrial process heat applications may permit sophistication in solar system design and maintenance procedures which would be impractical for most heat and cooling applications -- as well as opportunities to achieve some economies of scale with very large systems. On the other hand, these solar systems must meet industrial economic criteria which can be different, and possibly more severe, than for residential applications. It has been estimated that because fossil fuel is currently a tax-deductible expense to industry, and because industry needs a high

* Thermal cooling achieved per unit of solar heat input.

rate of return on capital, allowable system costs may have to be much lower than for residential equipment -- therefore, significant tax incentives may be required to achieve economic viability.⁽³⁴⁾ Lastly, the public relations aspects of solar systems and the possibility of loss of normal energy supplies may have a very important impact on what otherwise would be purely financial decisions.

Section 4.4: Limitations

Other than the major element of economic competitiveness discussed previously, the major obstacles for widespread implementation of solar heating and cooling systems include:

- geographic variation in sunlight,
- siting constraints, and
- institutional problems.

The geographic variation in sunlight, discussed in more detail in Chapter 2, results in areas in the Northeast having only slightly more than half the solar radiation enjoyed in sections of the Southwest. At present, this is somewhat counterbalanced by the fact that the price of competing fuels is likewise higher in the Northeast; however, in the future, there may be a trend toward equalization of energy prices. In addition, certain systems employing concentrating collectors which might be quite effective in the Southwest would suffer a great performance penalty in the Northeast where much more of the total radiation is diffuse rather than direct.

Siting constraints may preclude the application of solar systems to many buildings. These constraints include blockage by adjacent trees and/or buildings and a building/roof orientation which is inappropriate or difficult for collector mounting. These problems are particularly acute in retrofit situations where there is no opportunity to adjust the siting of the building to be compatible with solar energy utilization.

Also, if the collector were to be ground-mounted or placed in a very conspicuous and awkward location on the roof, there could be

esthetic problems. There are even situations where reflections caused by the collector may be considered an annoyance to neighboring residents. Lastly, the subject of vandalism must always be kept in mind, although, to date, experience has been that this has been a very minor problem, even with ground-mounted collectors. (38)

Depending on how the industry matures, institutional problems may impede the growth of solar heating and cooling. In early programs, such as the New England Electric Solar Water Heater Experimental Program, the lack of personnel skilled in installation, troubleshooting, and maintenance has resulted in high installation costs and unsatisfactory operation. (38,48) Also, there will be a period of time required for standards and warranty arrangements to develop which will both protect the consumer and not be unduly restrictive in terms of solar system design.

REFERENCES

1. Shurcliffe, W.A. Solar Heated Buildings - A Brief Survey. Twelfth edition. Available from W.A. Shurcliffe, 19 Appleton Street, Cambridge, Massachusetts. March 3, 1976.
2. Arthur D. Little, Inc. Solar Heating and Cooling of Buildings (SHACOB) Commercialization Report. Part B - Analysis of Market Development, Vol II: Technical Report. Final Report prepared under Contract No. CR-05-70066-00 to Federal Energy Administration, 1977.
3. "Solar Advocates Allies of Oil Execs; U.S. 20% Solar by Year 2000: Harvard." Solar Energy Intelligence Report, January 29, 1979. pp. 43 ff.
4. Stanford Research Institute. Solar Energy in America's Future. Report to Energy Research and Development Administration, March 1977. NTIS Report No. DSE/115-2.
5. Winston, R. "Principles of Solar Concentrators of a Novel Design." Solar Energy 16(2):89, 1974.
6. Pendleton, R.L. "Evaluating a Solar Energy Concentrator." ASHRAE Journal 18 (11):47, November 1976.
7. Davidson, J.H., et al. "The Solar Linear Array Thermal System." Solar Age, February 1978. pp. 12 ff.
8. Manufacturers' Product Literature.
 - (a) PPG Solar Systems Data Sheet 3, Form G-752. Available from PPG Solar System Sales, One Gateway Center, Pittsburgh, Pennsylvania 15222.
 - (b) The Owens-Illinois SUNPAK Shaped Reflector. Brochure No. 6-4380-24-10M, 1976. Available from Richard E. Ford, Owens-Illinois, Inc., P.O. Box 1035, Toledo, Ohio 43666.
 - (c) SLATS[®] - A New Concept in Solar Collectors. May, 1977. Available from George Kannapel, Suntec Systems, 2101 Wooddale Drive, St. Paul, Minnesota 55119.
9. Hyman, M. Jr. "100% Solar Space for New England." ASHRAE Journal 18(1):66, January 1976.
10. Anderson, B. Solar Energy: Fundamentals in Building Design. New York: McGraw-Hill Book Company, 1977. pp. 230-234.

REFERENCES (continued)

11. Moyers, J.C., et al. "The Annual Cycle Energy System Concept and Application." Proceedings of the International Conference on Energy Use Management, Tucson, Arizona, October 24-28, 1977. New York: Pergamon Press, 1978.
12. Pickering, E.E. "Residential Hot Water Solar Energy Storage." Proceedings of the Workshop on Solar Energy Storage Subsystems for the Heating and Cooling of Buildings, Charlottesville, Virginia, April 16-18, 1975. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., 1975. NTIS Report No. NSF/RA/N-75/041.
13. Telkes, M. "Thermal Storage for Solar Heating and Cooling." Proceedings of the Workshop on Solar Energy Storage Subsystems for the Heating and Cooling of Buildings, Charlottesville, Virginia, April 16-18, 1975. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., 1975. NTIS Report No. NSF/RA/N-75/041.
14. Arkla Industries, Evansville, Indiana. Product literature.
 - (a) Solaire 36--3 Ton Absorption Chiller for Solar Air Conditioning. Form No. SA-41030, November 1976.
 - (b) Solaire 300--25 Ton Absorption Chiller for Solar Air Conditioning. Form No. SA-41041, October 1978.
 - (c) Arkla Solaire Puts the Sun in One Neat Package. Form No. SS-11210, January 1978.
15. Löf, G.O.G. "Cooling with Solar Energy." World Symposium on Applied Solar Energy, Phoenix, Arizona, November 1955. pp. 171 ff.
16. National Science Foundation. "NSF Grant Funds for Study of Solar Energy System Atop New York Skyscraper." News Release, February 1975.
17. Lunde, P.J. Solar Powered Desiccant Air Conditioning System, Final Report, June 1, 1974 - December 31, 1974. Prepared by The Center for Environment and Man, Inc. for National Science Foundation, April 1, 1975. NTIS Report No. CEM-4171-526.
18. Rush, W. "Solar Desiccant Systems." Workshop Proceedings on Solar Cooling for Buildings, Los Angeles, California, February 6-8, 1974. Document No. NSF-RA-N-74-063. NTIS Report No. PB 239 419.
19. Freeman, T.L., et al. "Computer Modeling of Heat Pumps and the Simulation of Solar-Heat Pump Systems." American Society of Mechanical Engineers Winter Meeting, Houston, Texas, November 30 - December 4, 1975. ASME Paper 75-WA-Sol-3.

REFERENCES (continued)

20. Marvin, W.C., et al. "Optimum Combination of Solar Energy and the Heat Pump for Residential Heating." Sharing the Sun! Solar Technology in the Seventies. A joint conference of the American Section of the International Solar Energy Society and the Solar Energy Society of Canada, Inc., Winnipeg, Canada, August 15-20, 1976. Vol. 3. pp. 321-323.
21. Arthur D. Little, Inc. System Definition Study: Solar Heating and Cooling Residential Project. Summary Report Prepared for Electric Power Research Institute, July 1977. Report No. EPRI ER-467-SY.
22. Stromberg, R.P. Passive Solar Buildings: A Compilation of Data and Results. Prepared by Sandia Laboratories, August 1977. NTIS Report No. SAND77-1204
23. Keller, M.H., ed. Passive Solar Heating and Cooling. Proceedings of a conference and workshop, coordinated by Los Alamos Scientific Laboratory, Albuquerque, New Mexico, May 18-19, 1976. NTIS Report No. LA-6637-C.
24. U.S. Department of Energy. Solar Heating and Cooling Research and Development Project Summaries. May 1978. NTIS Report No. DOE/CS-0010.
25. Balcomb, D.J. "Summary of the Passive Solar Heating and Cooling Conference." Passive Solar Heating and Cooling. Proceedings of a conference and workshop coordinated by Los Alamos Scientific Laboratory, Albuquerque, New Mexico, May 18-19, 1976. NTIS Report No. LA-6637-C.
26. Yellot, J. "Passive Solar Heating and Cooling Systems." ASHRAE Journal 20(1):60, January 1978.
27. Trombe, F., et al. "Concrete Walls to Collect and Hold Heat." Solar Age, August 1977. pp. 13 ff.
28. Baer, S. "The Drum Wall." Proceedings of the Solar Heating and Cooling for Buildings Workshop, Part I: Technical Sessions. Sponsored by the National Science Foundation, Washington, D.C., March 21-22, 1973. NTIS Report No. PB 223 536.
29. Hay, H.R. "Evaluation of Proved Natural Radiation Flux Heating and Cooling." Proceedings of the Solar Heating and Cooling for Buildings Workshop, Part I: Technical Sessions. Sponsored by the National Science Foundation, Washington, D.C., March 21-22, 1973. NTIS Report No. PB 223 536.
30. Johnson, T.E. "Lightweight Thermal Storage for Solar Heated Buildings." Solar Energy 19(6):19, 1977.
31. Mahone, D. "Three Solutions for Persistent Passive Problems." Solar Age, September 1978. pp. 21 ff.

REFERENCES (continued)

32. Freeborne, W. "Performance of HUD Residential Solar System." Pre-conference Proceedings - Solar Heating and Cooling Systems Operational Results, Colorado Springs, Colorado, November 28 - December 1, 1978. Washington, D.C.: U.S. Department of Energy, 1978.
33. Balcomb, J.D. "Simulation Analyses of Passive Solar Heated Building - Preliminary Results." Solar Energy 19(3):277, 1977.
34. Dickinson, W.C. "Solar Energy for Industrial Process Heat." Solar Age, August 1977. pp. 29 ff.
35. "Solar Supplements Industry Needs." Solar Engineering, August 1978. pp. 25 ff.
36. "Industrial Process Heat-Creative Opportunities in Solar Design." Solar Age, March 1979. pp. 19 ff.
37. Löf, G.O.G., et al. "Solar House Heating." Natural Resources Journal 10(2):268, April 1970.
38. Arthur D. Little, Inc. Interim Report on New England Electric Residential Solar Water Heating Experiment. Westborough, Massachusetts: New England Electric (System), Inc., May 1977.
39. Florida Solar Energy Center. New and Retrofit Solar Hot Water Installation in Florida, January through June, 1977. Prepared for U.S. Department of Energy, April 1978. NTIS Report No. HCP/15663-01.
40. Intertechnology Corporation. Intertechnology Corporation Report of Solar Energy Systems Installation Costs for Selected Commercial Buildings. Prepared for U.S. Energy Research and Development Administration, December 1976. NTIS Report No. C00/2688-76-13.
41. MITRE Corporation. System Description and Engineering Costs of Solar Related Technologies, Vol. II: Solar Heating and Cooling of Buildings (SHACOB). Prepared for U.S. Energy Research and Development Administration, June 1977. NTIS Report No. MTR-7485-VOL-2.
42. Bezdek, R.H. An Analysis of the Current Economic Feasibility of Solar Water and Space Heating. U.S. Department of Energy, January 1978. NTIS Report No. DOE/CS-0023.
43. U.S. Energy Research and Development Administration. An Economic Analysis of Solar Water and Space Heating. Prepared by Division of Solar Energy of ERDA, November 1976. NTIS Report No. DSE-2322-1.
44. Roach, F. Prospects for Solar Energy: The Impact of the National Energy Plan. Los Alamos Scientific Laboratory, December 1977. NTIS Report No. LA 7064-MS.

REFERENCES (continued)

45. Ward, J.C., et al. "Maintenance Costs of Solar Air Heating Systems." Proceedings 1977 Annual Meeting of the American Section of the International Solar Energy Society. Cape Canaveral, Florida: Florida Solar Energy Center, 1977. pp. 10-2 ff.
46. Butt, S.H. "The Fallacy of Cutback." Solar Energy Industries Association Newsletter, 4(16), December 1978.
47. King, T.A., et al. "Cost Data Collection from Solar Demonstration Projects." Preconference Proceedings - Solar Heating and Cooling Systems Operational Results, Colorado Springs, Colorado, November 28 - December 1, 1978. Washington D.C.: U.S. Department of Energy, 1978.
48. Sullivan, C.N. "Installation: A Key to Successful Solar Program." Solar Age, September 1977.

CHAPTER 5
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: RUN-OF-THE-RIVER HYDROELECTRIC POWER GENERATION</p> <p>DESCRIPTION: This technology utilizes small, distributed water sources for numerous, dispersed hydroelectric generation facilities. The water flow is used when available; thus, the expenditures for water impoundment structures are minimal.</p> <p>POTENTIAL USER CLASSES: Electric utilities, public or otherwise; industrial users of electricity</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Fully commercialized⁽¹⁾</p>																																					
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 40%;">UNIT POWER OUTPUT CAPACITY: (MW)</td><td style="width: 10%;">PRIMARY</td><td style="width: 10%;">1977</td><td style="width: 10%;">1985</td><td style="width: 10%;">2000</td></tr> <tr> <td></td><td>SECONDARY</td><td>.05-500⁽¹¹⁾</td><td>same</td><td>same</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh)</td><td>PRIMARY</td><td>130-1.3x10⁶</td><td>same</td><td>same</td></tr> <tr> <td></td><td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td></td><td>.3</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td></td><td>.12-.5</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY:</td><td></td><td>.85-.92</td><td>same</td><td>same</td></tr> </table> <p>PRIMARY FUEL(S): Water AMOUNT NEEDED PER UNIT OUTPUT: See Comments.⁽¹¹¹⁾</p> <p>ALTERNATIVE FUEL(S): None IS SYSTEM READILY CONVERTIBLE? No</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Seasonal and daily fluctuations are due to local hydrology.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p style="padding-left: 20px;">DESIRABLE FOR USER? Yes</p> <p style="padding-left: 20px;">TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? No</p> <p style="padding-left: 20px;">SYSTEM:</p>			UNIT POWER OUTPUT CAPACITY: (MW)	PRIMARY	1977	1985	2000		SECONDARY	.05-500 ⁽¹¹⁾	same	same	UNIT ANNUAL ENERGY OUTPUT: (kWh)	PRIMARY	130-1.3x10 ⁶	same	same		SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:		.3	same	same	RANGE OF CAPACITY FACTORS:		.12-.5	same	same	EFFICIENCY:		.85-.92	same	same
UNIT POWER OUTPUT CAPACITY: (MW)	PRIMARY	1977	1985	2000																																		
	SECONDARY	.05-500 ⁽¹¹⁾	same	same																																		
UNIT ANNUAL ENERGY OUTPUT: (kWh)	PRIMARY	130-1.3x10 ⁶	same	same																																		
	SECONDARY																																					
AVERAGE EFFECTIVE CAPACITY FACTOR:		.3	same	same																																		
RANGE OF CAPACITY FACTORS:		.12-.5	same	same																																		
EFFICIENCY:		.85-.92	same	same																																		
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 40%;">TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)</td><td style="width: 10%;">1977</td><td style="width: 10%;">1985</td><td style="width: 10%;">2000</td></tr> <tr> <td>[INCLUDES: minimal civil engineering costs]</td><td>320-3200</td><td>same</td><td>same</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh)</td><td>.002-.004^(iv)</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>1-8 years - variable with the site</td><td></td><td></td></tr> </table>			TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)	1977	1985	2000	[INCLUDES: minimal civil engineering costs]	320-3200	same	same	AVERAGE UNIT O&M: (\$/kWh)	.002-.004 ^(iv)	same	same	CONSTRUCTION PERIOD:	1-8 years - variable with the site																					
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)	1977	1985	2000																																			
[INCLUDES: minimal civil engineering costs]	320-3200	same	same																																			
AVERAGE UNIT O&M: (\$/kWh)	.002-.004 ^(iv)	same	same																																			
CONSTRUCTION PERIOD:	1-8 years - variable with the site																																					
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Extensive - many manufacturers in U.S. and Europe; industrial base would expand to meet larger market.</p> <p>GEOGRAPHIC LIMITATIONS: Sites may not be in the vicinity of loads.</p> <p>ENVIRONMENTAL EFFECTS: Relatively small; they would vary from site to site.</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: Conflicting uses for water, water rights, ownership of plant, licensing difficulties</p>																																					
COMMENTS	<p>(1) R&D to improve turbine and generator materials, designs, governor and control systems, and intake/discharge systems continues.</p> <p>(11) The larger units (500 MW) are used in centralized utility networks.</p> <p>(111) AMOUNT NEEDED PER UNIT OUTPUT: Installation using a 20-foot head requires roughly 2,500 ft³ of water to produce 1 kWh of electrical energy.</p> <p>(iv) Higher if plant requires special manning.</p>																																					

CE

CHAPTER 5

RUN-OF-THE-RIVER HYDROELECTRIC POWER GENERATION

Section 5.1: Introduction

During the past 40 years, many small* hydro power plants were abandoned in favor of large, centralized, fossil-fueled and large hydro-electric power plants. The economic rationale (high costs for operating personnel and low availability) for abandoning the low-head, essentially "run-of-the-river" hydro plants was correct when the decisions were made. However, subsequent changes in the technology and the relative economics of small hydro power plants now prompt a re-examination of the issue.

Section 5.2: Technical Discussion

A. Turbine Types

The two general classes of water turbines and their appropriate subclasses are:

1. Reaction turbines
 - a. Francis turbine
 - b. Propeller turbines
 - i. Nagler turbine (fixed propeller blades)
 - ii. Kaplan turbine (variable pitch propeller)
2. Impulse turbines

The parameters of a specific project determine the most appropriate type of turbine. Table 5-1 outlines the usual limits on the operating head. The Francis turbine (Figure 5-1) is a modern version of the old water wheel of Colonial times. It is also called a pressure turbine; this term reflects the pressure change across the turbine runner.**

* Up to 5 MW.

** The turbine runner is the revolving part of the turbine and is made up of a number of blades or buckets attached to a hub.

TABLE 5-1
GENERAL ARRANGEMENTS OF TURBINE INSTALLATIONS
AND USUAL HEAD LIMITS EMPLOYED

Type	Setting	Construction	Number of runners	Usual head limits for direct-connected units, ft
Reaction turbines, 5-to 1,300-ft head	Open flume, 5-to 40-ft head	Vertical.....	1	5-40
		Horizontal.....	1	12-40
			2	16-40
	Encased, 15-to 1,300-ft head	Plate steel { vertical..... horizontal..... horizontal.....	4	16-30
			1	40-300
			1	30-100
		Concrete, vertical..... Concrete spiral, vertical.....	2	30-100
			1	15-50
Impulse wheels, 500-to 5,500-ft head	Encased	Cast or welded-plate steel spiral { vertical..... horizontal..... horizontal.....	1	15-90
			1	75-1,300
		Horizontal.....	1	50-600
			2	50-500
		Vertical.....	1	500-5,500

SOURCE: Reference 1.

This pressure/potential energy is converted to mechanical energy by turning the runner. The direction of water flow at the turbine entrance is perpendicular to the rotor's axis of rotation; water flow at the turbine exit is parallel to the rotor's axis.

In the propeller turbines, the direction flow is almost parallel to the runner's axis of rotation (axial or vertical shaft turbines). The runners resemble a ship's propeller, or its inverse, and are much simpler than those of the Francis turbine. The pitch of the propeller blades of the Kaplan turbine varies automatically during operation in order to keep the speed of the turbine constant, despite variations in the operating conditions, so that the turbine will always operate at maximum efficiency.

A recent variation of the Kaplan turbine design is the tubular-type turbine (Figure 5-2). This was developed to simplify the water flow passages and thereby reduce the required amount of ancillary construction work at the hydro generation plant. The most recent development in tubular turbines is the bulb unit (Figure 5-3)

SOURCE: Reference 1.

FIGURE 5-1 MEDIUM-HEAD FRANCIS TURBINE

SOURCE: Reference 2.

FIGURE 5-2 TUBULAR TURBINE WITH THE SYNCHRONOUS GENERATOR
OUTSIDE THE WATER STREAM

SOURCE: Reference 2.

FIGURE 5-3 TUBULAR TURBINE WITH WATER FLOW AROUND THE SYNCHRONOUS GENERATOR (BULB TURBINE)

in which the generator is completely encased in a bulb in the middle of a flow conduit. The disadvantage is the difficulty associated with maintenance.

The impulse turbine is usually found at sites where high heads (> 500 ft) are available. The pressure/potential energy of the water is converted to kinetic energy in a nozzle or guide vanes. The resulting high-velocity stream of water is then directed on to the runner; there is no pressure change across the turbine. An example of this type of unit is shown in Figure 5-4.

The availability of hydro turbines to take advantage of our available hydro resources does not appear to be a problem. Until recently, there was only one major U.S. manufacturer (James Leffel & Co.) of extremely small hydro turbines (<1 MW),⁽⁴⁾ although several U.S. companies claim they can manufacture the larger units. The bulb turbine, now commercially available in Europe, could become available from U.S. manufacturers rather quickly when the market develops. Significant competition presently exists between U.S. and foreign manufacturers. The hydro turbine represents a mature technology; changes in this technology will probably be evolutionary in form rather than revolutionary and encouraged by the continuing competition.

SOURCE: Reference 3.

FIGURE 5-4 AN OSSBERGER TURBINE ASSEMBLY
(AN EXAMPLE OF AN IMPULSE TURBINE)

B. Power Potential at a Specific Site

All turbines require that water be channeled to them, under pressure, in large pipes or penstocks, from a source some height above the turbine. The maximum water flow rate and pressure determine the maximum (not the average) amount of electric power that can be generated at the site. The water flow rate is defined by the characteristics of the site, i.e., the amount of local rainfall, drainage area, the soil type in the drainage basin, etc. The pressure available at any particular site, however, can be changed by increasing the hydraulic head available behind a dam installed at the site either by increasing the height of the dam or by placing the powerhouse downstream and lower than the base of the dam. Figure 5-5 shows how the power available at a site varies with the water flow rate and the hydraulic head.

Some hydro sites may not require the construction of new dams since some hydro power (mechanical and electrical) plants have been abandoned during the past 40 years. While the turbines were usually removed from the sites when the plants were decommissioned, the civil works, i.e., the dams, penstocks, etc., remain and, if in good condition, might be reclaimed. In addition, many large-scale hydro plants and dams constructed for other purposes do not exploit the total hydro power resources available at their sites; it is possible that additional power generating equipment could be installed at these dams at minimal cost. However, since many of these dams are very old and may require extensive rehabilitation, each site must be evaluated individually.

Section 5.3: Economics Discussion

A. Capital Cost of Run-of-the-River Hydrogeneration

The head and water flow rate at a site will both tend to define the capital cost of the hydro power unit at the site. If the head is low, the amount of water which must flow through the turbine in order to generate a kWh of electric energy must be high. The equipment necessary to process these large water flows is larger and more costly

SOURCE: References 3 and 5.

FIGURE 5-5 POWER AVAILABLE FROM A HYDROGENERATOR AND UNIT COST AS A FUNCTION OF THE HYDRAULIC HEAD AND WATER FLOW RATE. (The efficiency is assumed to be a constant. Costs include turbogenerators, control systems and minimal civil works.)

than the equipment needed to process smaller water flows. In general, for the same generated power, the higher the head, the lower the capital cost of the design capacity power plant.

One estimate⁽⁵⁾ (generally confirmed by References 3 and 4) of the variation of the capital cost* of run-of-the-river hydro plants with head and water flow rates has been plotted as constant-cost contours in Figure 5-5 (dashed lines). These contours demonstrate the previously mentioned increase in the unit cost with the maximum water flow rate, given the same electrical output. They also show the economies of scale that result from installing large amounts of capacity at a single site. Because of the strong dependence of the cost of the needed civil works on site, these costs should be used only to indicate the approximate cost of run-of-the-river hydrogeneration.

To minimize the capital costs of the plant by using the economies of scale, the number of generating units should be kept to a minimum. However, other considerations, such as flexibility of operation, higher-efficiency operation during times of low power demand, and the minimum loss of capacity during shutdown for repair or maintenance, might indicate the use of multiple units where one unit would be feasible in terms of physical size. For example, Figure 5-6 presents data on the variation of the hydro plant efficiency with power output when the plant has multiple units. Figure 5-7 shows how the same effect can be obtained in an impulse turbine with a segmented runner.

Most of the investigators of run-of-the-river hydrogeneration have limited themselves to a consideration of low-head installations (<50 ft) as one way of reducing the size and cost of the associated civil works. However, natural high-head sites do exist and could be very useful in a distributed energy system. The equipment (impulse turbines) needed to use these heads is available in the appropriate sizes (100 kW - 10 MW). The cost contours in Figure 5-5 for the high-head systems were derived with the assumptions that the head occurs naturally and that only a minimal amount of civil works is required.

* Cost includes the cost of turbines, generators, control systems, and minimal civil works (e.g., earth-moving, construction of dams, etc.).

* The forebay is the water supply area before the entrance to the penstock. The tailrace is the channel into which the water from the turbine is discharged. The gross head is the difference in height between the two.

SOURCE: Reference 6.

FIGURE 5-6 PERFORMANCE CURVES FOR A LOW-HEAD HYDROELECTRIC POWER PLANT

EFFICIENCY

SOURCE: Reference 3.

FIGURE 5-7 EFFICIENCY AS A FUNCTION OF THE GATE OPENING:
OSSBERGER (IMPULSE) TURBINE WITH A SPLIT RUNNER
AND THE FRANCIS TURBINE

B. Operation and Maintenance Requirements and Costs

Discussions with the maintenance personnel of two utilities⁽⁷⁾ indicated that small, low-speed hydrogenerators can operate for years with only a relatively small amount of scheduled maintenance. For example, the four run-of-the-river units on the Deerfield River in Massachusetts were all installed before 1910 and have operated, essentially without trouble, for more than 67 years. Therefore, an estimate of O&M costs of \$0.002 to \$0.004/kWh is generally accepted unless special manning requirements justify a higher figure.⁽⁷⁾

The cost of operating the plants is often cited as one of the reasons why so many small run-of-the-river hydrogenerators were shut down in the 1940's. Before the equipment became available to control the hydro plants remotely, it was necessary to have plant operators on-site 24 hours a day to take full advantage of the available water. Thus, it cost about the same amount to operate smaller plants as to run larger plants. When the cost of fuels for the fossil plant was low, the total cost per kWh of operating the large fossil-fueled plant (including fuel) could be comparable to the total cost per kWh of running the small hydro plant; however, the plants were usually retired only when they required major rehabilitation. With remote control systems, one operator can control several hydro plants from a single location. The cost of operating a small station is no longer the predominant factor determining the economic desirability of small hydro power units.

Section 5.4: Limitations

Statistics compiled by the Federal Power Commission⁽⁸⁾ indicate that as of January 1, 1976, sites capable of providing a total additional 113.7 GWe of hydroelectric power at an average capacity factor of 0.4 had been identified. Excluding Alaska, the data show 80.4 GWe at an average capacity factor of 0.33. These sums do not include the sites along waterways in protected wilderness areas or parkland. However, the cost of developing each of these sites and the limitations on the energy availability at each site affect the development potential of this resource. Unfortunately, the water flow at any site is not constant throughout the year. Thus, the energy availability at a site bears little

relationship to the peak power availability, which is the reason for the relatively low capacity factor.

The FPC report⁽⁸⁾ contains a list of hydroelectric sites in which individuals have shown interest at some time in the past. It provides information on the peak power available at each site, the total amount of energy available at each site in an average year, the available proposed head, and the corresponding amount of storage capacity (pondage) at each site. It does not describe how the volume of water flow varies during the year.

The capacity available from run-of-the-river hydroelectric plants will vary throughout the year. Typically, water flow rates reach a maximum during the spring run-off and a minimum either during the heat of summer or when the surface water is frozen into position and cannot run off. Unfortunately, the times of peak demand for electrical energy occur during the summer (air conditioning load) or the winter (lighting and heating load). The run-of-the-river plant might be unavailable to the utility because of low-water conditions during the utility's peak demand season. If the electric utility cannot rely on the hydrogeneration capacity during the period of peak demand, additional fossil-fueled capacity would be required to meet the peak demand. This consideration would reduce the value of the run-of-the-river power plants to the utility.

If the hydro plant is owned by a non-utility, the local utilities' problems may be exacerbated. The private owner reaps all the benefits of low-cost power when the water flow is available but must turn to the utility for back-up power when the water flow is unavailable. The utility gets little or none of the benefits of the hydro plant but may still need to install fossil-fueled capacity to meet the power demand of the hydro plant owner during the season of minimum water flow. If this season coincides with the utility's peak demand season, the cost impact on the utility, and indirectly on the other customers of the utility, could be significant.

One method of dealing with seasonal variations of the water flow to the run-of-the-river plants is to control the river. The water flow to the four units on the Deerfield River in Massachusetts is controlled by

a single dam upstream. The cost of the dam and associated reservoir can be split between all four hydro units. By operating the hydro units to meet the daily peak during all seasons, the utility can maximize its fuel (oil or gas) savings throughout the year. Because all of the previously mentioned dams on the Deerfield River and the upstream reservoir are owned by the same corporation, the question of cost allocation was not important. It is, however, possible to allocate upstream reservoir costs to the different owners of several downstream plants.

The undeveloped or abandoned hydro power sites listed in the FPC survey⁽⁸⁾ for New York State as having no pondage are shown in Figure 5-8 according to their hydraulic head and potential rated power. The wide variation of these two parameters from site to site clearly shows why any general statements about these resources can be misleading. The cost contours of Figure 5-5 have also been replotted in Figure 5-8. It should be noted that a few of the sites listed by the FPC for New York State can be eliminated because their capital costs are very high. It should also be noted that many of the low-head sites were developed and then abandoned. (The plans and blueprints of these sites are probably still available.)

The U.S. Army Corps of Engineers⁽⁹⁾ estimates that the national hydro power potential at existing small dams (head <100 ft, power <5 MW) is 26.6 million kW with a potential energy yield of 85×10^9 kWh/yr. The Corps' methodology (dictated by the short time available for the Corps' study) yielded estimates only, and the actual potential may be somewhat less.

One of the postulated advantages of distributed energy systems is the location of the energy source close to the energy demand, resulting in a reduction in transmission costs and losses, and an increased flexibility in the system's operations. Unfortunately, there is no guarantee that hydro sites, run-of-the-river or otherwise, will be available in the vicinity of the load. Therefore, geographic distribution and proximity to load centers will be critical factors in assessing the potential of increased run-of-the-river hydrogeneration and the associated costs.

SOURCE: References 4 and 8.

FIGURE 5-8 UNDEVELOPED AND ABANDONED HYDROELECTRIC SITES IN NEW YORK STATE

Detailed studies of particular geographic areas have been initiated recently, as, for example, in New England and New York.⁽¹⁰⁾ Whatever the geographic distribution of the small hydrogeneration sites, the chances are that these sites will be located on the distribution network (69 kV or less) rather than on the transmission network. Thus, they will probably be used to meet the needs of the customers located off the local distribution feeders rather than those of customers located on the other side of the utility's service area.

The utilization of hydro power at particular sites may be inconsistent with other important water uses. For example, removing large amounts of water from a river for irrigation during the dry season at a point upstream from a hydroelectric power plant will reduce the dependable stream capacity of the plant during that period of time. Water rights, like mineral rights, are bought and sold independently of the land. The water at potential hydro power sites may now be owned by institutions which may expect to use the water for purposes which will eliminate the power-generating potential at the downstream sites. The mutipurpose aspects of river basin development are recognized in the Federal Power Act, which requires the Federal Power Commission^{*} to evaluate a water resources plan prior to licensing.⁽¹¹⁾

The environmental aspects of hydro power developments vary significantly from site to site. The construction of new dams can result in erosion, dust, and other discharges that may contribute to downstream siltation and pollution. Following construction, the physical and chemical characteristics of the water may be changed from that which previously existed; dissolved oxygen levels may decline. Dams act as barriers to the flow of heavier-than-water chemicals, organisms, and silt. Thus, the presence of a dam may have a major impact on the local site ecology and on related recreational opportunities. The installation of new generating equipment at existing dams avoids most of the impacts associated with construction of a new dam, whereas the construction of a large number of new small dams might attract significant opposition. However, these environmental

^{*} Now the Federal Energy Regulatory Commission (FERC).

impacts may be less than the impact of alternative fossil fueled power plants; each installation must be evaluated independently.

The issue of small dam safety is also relevant to a discussion of run-of-the-river hydro power. In particular, one must consider the safety of animals and people in the water near a normally functioning facility, as well as the safety of downstream installations should the dam fail. With respect to the former, there exist standard design procedures for minimizing hazards around the water passages.⁽¹²⁾ With respect to the latter, design criteria generally call for construction sufficient to withstand the largest flood that can reasonably be expected to occur at the site.⁽¹²⁾ However, a review of the nation's dams by the Army Corps of Engineers⁽¹³⁾ indicated that approximately 20,000 of the 49,329 dams of the nation are so located that failure of the dam or misoperation of the discharge facilities could result in loss of human life and appreciable property damage, and that dam safety programs in most jurisdictions are either nonexistent or inadequate to protect the public from hazards created by dams. Run-of-the-river facilities are relatively safe because the pondage for these dams is small; however, in view of the findings of the Corps, this issue warrants close study.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Rheingans, W.J. "Hydraulic Turbines." Standard Handbook for Mechanical Engineers. 7th ed. Edited by T. Baumeister. New York: McGraw-Hill. pp. 9-183 ff.
2. Brown-Boveri, North Brunswick, New Jersey. Product literature on synchronous machines for water power generation. August, 1977.
3. E.W.E. Staphenhorst, Inc., Montreal, Quebec. Product literature on synchronous machines for water power generation. August, 1977.
4. National Academy of Sciences. Energy for Rural Development. Washington, D.C., 1976.
5. O'Brien, E. "Small Hydro Plants for the Northeast." Electrical World 188 (4):61, August 15, 1977.
6. Steinberg, M.J., et al. Economic Loading of Power Plants and Electrical Systems. New York: John Wiley and Sons, 1943.
7. New England Power Company, Westborough, Massachusetts and Wisconsin Public Service Corporation, Green Bay, Wisconsin. Private communication. August 1977.
8. Federal Power Commission. Hydroelectric Power Resources of the United States. Washington, D.C., 1976.
9. McDonald, R.J. Estimate of National Hydroelectric Power Potential at Existing Dams. Washington, D.C.: U.S. Army Corps of Engineers, July 1977.
10. "New York Launches Study of Hydroelectric Capacity." Electrical Week, September 12, 1977. p.5.
11. Federal Power Commission. The 1970 National Power Survey. Washington, D.C., 1971.
12. U.S. Department of the Interior. Design of Small Dams. Washington, D.C., 1973.
13. U.S. Army Corps of Engineers. National Program of Inspection of Dams. Washington, D.C., May 1975.

CHAPTER 6
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: WIND POWER SYSTEMS</p> <p>DESCRIPTION: Electricity is generated using a wind turbine.</p> <p>POTENTIAL USER CLASSES: Any user or producer of electricity from 1.5 kW to 3.0 MW</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Units from 0.1 to 25 kW are commercially available. Larger sizes are under development.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: ⁽ⁱ⁾ (MW) PRIMARY</td><td>.0001-.025</td><td>.0001-.5</td><td>.0001-3.0</td></tr> <tr> <td>SECONDARY</td><td>NA*</td><td>NA</td><td>NA</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: ⁽ⁱⁱ⁾ (MWh) PRIMARY</td><td>.22-55</td><td>.26-1300</td><td>.31-9200</td></tr> <tr> <td>SECONDARY</td><td>NA</td><td>NA</td><td>NA</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR</td><td>.25</td><td>.30</td><td>.35</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS: ⁽ⁱⁱⁱ⁾</td><td>.10-.40</td><td>.10-.45</td><td>same</td></tr> <tr> <td>EFFICIENCY: Typical fraction of wind power available as electrical power at rated conditions (horizontal axis)</td><td>.40</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Wind AMOUNT NEEDED PER UNIT OUTPUT: NA</p> <p>ALTERNATIVE FUEL(S): None</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Zero to maximum rated capacity, depending on wind speed</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Yes, if hook-up is available</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</p> <p>SYSTEM: Yes, when system must stand alone, hook-up with fuel-powered generator (diesel or turbine) and/or batteries or other storage system is desirable</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: ⁽ⁱ⁾ (MW) PRIMARY	.0001-.025	.0001-.5	.0001-3.0	SECONDARY	NA*	NA	NA	UNIT ANNUAL ENERGY OUTPUT: ⁽ⁱⁱ⁾ (MWh) PRIMARY	.22-55	.26-1300	.31-9200	SECONDARY	NA	NA	NA	AVERAGE EFFECTIVE CAPACITY FACTOR	.25	.30	.35	RANGE OF CAPACITY FACTORS: ⁽ⁱⁱⁱ⁾	.10-.40	.10-.45	same	EFFICIENCY: Typical fraction of wind power available as electrical power at rated conditions (horizontal axis)	.40	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: ⁽ⁱ⁾ (MW) PRIMARY	.0001-.025	.0001-.5	.0001-3.0																																
SECONDARY	NA*	NA	NA																																
UNIT ANNUAL ENERGY OUTPUT: ⁽ⁱⁱ⁾ (MWh) PRIMARY	.22-55	.26-1300	.31-9200																																
SECONDARY	NA	NA	NA																																
AVERAGE EFFECTIVE CAPACITY FACTOR	.25	.30	.35																																
RANGE OF CAPACITY FACTORS: ⁽ⁱⁱⁱ⁾	.10-.40	.10-.45	same																																
EFFICIENCY: Typical fraction of wind power available as electrical power at rated conditions (horizontal axis)	.40	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) ^(iv)</td><td>1500 - 7500 ^(v)</td><td>1300 - 1500</td><td>700 ^(vi) - 1000</td></tr> <tr> <td>(INCLUDES: Complete system to AC output without storage).</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE UNIT O&M: ^(vii)</td><td>3%/yr</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD: ^(viii)</td><td></td><td></td><td></td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) ^(iv)	1500 - 7500 ^(v)	1300 - 1500	700 ^(vi) - 1000	(INCLUDES: Complete system to AC output without storage).				AVERAGE UNIT O&M: ^(vii)	3%/yr	same	same	CONSTRUCTION PERIOD: ^(viii)															
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) ^(iv)	1500 - 7500 ^(v)	1300 - 1500	700 ^(vi) - 1000																																
(INCLUDES: Complete system to AC output without storage).																																			
AVERAGE UNIT O&M: ^(vii)	3%/yr	same	same																																
CONSTRUCTION PERIOD: ^(viii)																																			
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Not a limitation (capacity can expand to meet need)</p> <p>GEOGRAPHIC LIMITATIONS: Economics best in high wind areas: coastal New England, Pacific mountain areas, and central plains</p> <p>ENVIRONMENTAL EFFECTS (QUANTIFY IF POSSIBLE): T.V. interference, visual impact</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Wind rights</p>																																		
COMMENTS	<p>(i) Rated capacity.</p> <p>(ii) Using average capacity factor shown.</p> <p>(iii) For target future units. Smaller systems usually have lower capacity factors.</p> <p>(iv) Based on rated capacity; cost per average annual output significantly higher depending on distribution of wind power available.</p> <p>(v) Average costs for 1-and 25-kW machine; refer to Figure 6-6 for more data.</p> <p>(vi) DOE target for turbines rated at 500 kW or greater.</p> <p>(vii) Annual O&M costs were assumed to equal 3% of the capital cost.</p> <p>(viii) Days to years, depending on size; no significant improvement with further development.</p> <p>* NA = Not Applicable.</p>																																		

CHAPTER 6

WIND POWER SYSTEMS

Section 6.1: Introduction

There is a great deal of experience in the use of wind power plants for generating electricity or mechanical pumping power.* Systems range from do-it-yourself installations ^(2,3) to utility-sized applications. ⁽⁴⁾ Systems are in use today and are being installed in remote areas where power from the central utility system is not available or too expensive, or where operation of engine-generators is impractical. ^(5,6) Most of the commercially available wind generators have maximum outputs in the 0.1- to 15-kW range. ⁽⁷⁾ The upper end of this size range may be applicable to residential on-site power units in the United States. ^(8,9) The present worldwide market for small wind generators is estimated to be only about \$3 to \$6 million, but it is expected to grow substantially as the cost of conventional energy sources increases and the technical/economic performance of wind turbine systems is improved.

There are several DOE-supported programs underway to develop larger wind power units with output capacities in the 100- to 3000-kW range. ^(10,11) These units, several of which are in the preliminary testing stage, would be applicable to on-site applications, serving multiple residential units, commercial buildings, and small industrial operations.

Section 6.2: Technical Discussion

A. Types of Wind Turbines

Wind generators are generally classified as being horizontal- or vertical-axis types. Within these categories a large number of different designs have been developed. Figure 6-1 shows some of the configurations.

* Reference 1 has an excellent discussion of the history and operation of wind power systems.

HORIZONTAL AXIS

SINGLE-BLADED

DOUBLE-BLADED

THREE-BLADED

U.S. FARM WINDMILL
MULTIBLADED BICYCLE
MULTIBLADED

UP-WIND

DOWN-WIND

ENFIELD-ANDEAU

SAIL WING

MULTIROTOR

COUNTER-
ROTATING BLADES CROSS-WIND
SAVONIUS CROSS-WIND
PADDLES

DIFFUSER

CONCENTRATOR

UNCONFINED
VORTEX**VERTICAL AXIS****PRIMARILY DRAG-TYPE**

SAVONIUS

MULTIBLADED
SAVONIUS

PLATES

SHIELD

CUPPED

PRIMARILY LIFT-TYPE

Φ - DARRIEUS

Δ - DARRIEUS

GIROMILL

TURBINE

COMBINATIONS SAVONIUS
Φ DARRIEUS SPLIT
SAVONIUS

MAGNUS

AIRFOIL

OTHERS

DEFLECTOR

SUNLIGHT

VENTURI

CONFINED
VORTEX

SOURCE: Reference 1.

FIGURE 6-1 WIND MACHINE CONFIGURATIONS

Most units currently in use are horizontal-axis wind turbines with either two or three blades. Figure 6-2 shows one such machine. The design of the blades is similar to that of an airplane propeller (in fact, wind turbine blades have often been made by companies which make propellers for small airplanes). Sophisticated aerodynamic shapes result in wind turbines that have coefficients of performance which are approximately 80% of the theoretical maximum. It is doubtful, therefore, that significant improvements can be made in the aerodynamic efficiency of these machines which would, in turn, lead to reductions in size for a given output. Wind turbine/generators of this type with blade diameters up to 25 feet are commercially available from a number of companies cited below.

The most common vertical axis wind generators utilize Darrieus Rotor or Savonius S-Shape Rotor configurations. Darrieus Rotor machines have higher coefficients of performance and better wind speed/output characteristics than Savonius Rotor machines and are, therefore, probably better suited for larger-scale applications. Several firms^{*} now offer vertical axis wind generators of the Darrieus Rotor type with outputs ranging up to 37 kW. A schematic of one of these machines is shown in Figure 6-3.

The principal advantages of vertical axis wind generators are: since they can accept wind from any direction, the machine design is simpler than that of the horizontal axis machines which must face into the wind; since the position of the electric generator is fixed relative to the ground, complicated linkages and slip rings are not required; since the generator can be mounted on the ground rather than on a tower, access to the generator equipment is improved. These advantages must be balanced against the efficiency levels of approximately 75% of those having horizontal-axis equipment, ⁽¹⁾ as well as the fact that most designs are not self-starting.

The following discussion concentrates on horizontal-axis wind turbines, since this is the main type being used for electrical power production at this time. Although the vertical-axis machines may have a competitive advantage in smaller sizes, the basic economics of wind power generation

* See Table 6-1 for sample firms; also see Reference 12 for general listing of firms in the wind energy field.

SOURCE: Reference 13.

FIGURE 6-2 DOE/NASA 100 kW MOD-0 WIND TURBINE

TABLE 6-1

COSTS OF WIND GENERATOR SYSTEMS
PARTIAL LIST OF COMMERCIALY AVAILABLE WIND MACHINES

<u>Manufacturer</u>	<u>Model</u>	<u>Output Rating (kW)</u>	<u>Rated Windspeed (MPH)</u>	<u>Swept Area (ft²)</u>	<u>Equipment⁽¹⁾ Cost (1976 \$)</u>	<u>Estimated Output in 14 MPH Wind (kW)</u>
Aerowatt	150 FP7	0.1	16	35.2	\$ 3,560	0.08
Windcharger	NA ⁽²⁾	0.2	23	28.3	650	0.05
Aerowatt	300 FP7	0.275	16	89.8	5,750	0.25
Aerowatt	1100 FP7	1.1	16	218.4	10,310	1.0
Electro	WV 15G	1.2	23	76.1	3,040	0.31
Kedco	1200	1.2	NA	113.0	1,800	NA
Dunlite	2000	2.0	25	132.3	4,640	0.46
Aerowatt	4100 FP7	4.1	16	739.1	22,890	3.5
Electro	WV 35G	4.5	24	162.5	5,570	1.10
Electro	WV G50G	6.0	30	210.9	6,270	1.21
Grumman	WINDSTREAM	15.0	26	490.6	21,870	3.30
DAF ⁽³⁾	6.1m	7-14	NA	314.1	15,000	NA
Dynergy ⁽³⁾	5 m	3.3	24	150.0	NA	1.5
Alcoa ⁽³⁾	NA	5	25	325.0	NA	NA

(1) Includes tower, generator, and controls.

(2) NA = Not Available.

(3) Darrieus-type vertical-axis wind turbines.

SOURCE: Reference 14, discussions during 1976 and 1977 with the Department of Energy (Rocky Flats Small Wind Generator Test Facility), and manufacturers:

Alcoa, Alcoa Center, Pennsylvania

Aerowatt SA, Paris, France

Dominion Aluminum Fabricating, Ltd. (DAF), Mississauga, Ontario

Dunlite Electrical Co. Pty. Ltd., Adelaide, Australia

Dynergy Corp., Laconia, N.H.

Elektro, G.m.b.H., Winterthur, Switzerland

Grumman Energy Systems, Ronkonkoma, New York

Kedco, Inc., Inglewood, California

Windco, Sioux City, Iowa

SOURCE: Reference 15.

FIGURE 6-3 VERTICAL-AXIS WIND TURBINE

discussed below should apply to both cases.

B. System Description

Several different system configurations have been proposed for on-site generation of electrical power. In one, the wind turbine would stand alone, isolated from any electric utility. Batteries or backup generating capacity would be provided. In another, the wind turbine would be backed up by the utility so that power would automatically be drawn from the utility whenever the demand exceeded on-site supply. Excess capacity would be wasted or stored in batteries or as heat in water. In a third configuration, the wind turbine system would be backed up by the utility; excess capacity would be passed to the utility, and no on-site storage would be used. One study⁽¹⁶⁾ indicated that this last mode of operation would be most economical.

A schematic of a typical small isolated wind turbine generator with on-site storage is shown in Figure 6-4. The system shown consists of several major components:

- A wind turbine sub-assembly which includes the blades, hub mechanism with overspeed controls, generator, and turntable to allow the turbine to rotate into the wind.
- A tower to support the wind turbine sub-assembly at the proper height for the length of the blades and the variation in wind velocity with height above ground and local obstructions.
- A battery pack (with appropriate charging circuits) to store excess output for use as determined by load profiles.
- An inverter system to convert the dc output of the wind turbine generator and the battery pack into ac power, consistent with the distribution system and appliance loads.
- An auxiliary engine to drive the ac generator if the battery pack is exhausted and insufficient electricity is available from the wind turbine.

SOURCE: Arthur D. Little, Inc.

FIGURE 6-4 SCHEMATIC OF AN ISOLATED WIND POWER SYSTEM

The schematic shown is for commercially available wind power units which generate dc power, in order to eliminate the need to operate at a precisely controlled constant speed for ac power generation. For these systems, an inverter would be used to convert dc output to ac power for use with conventional appliances. The larger wind turbine systems under development operate at constant speed (by proper control of blade angle) so that a synchronous ac generator can be driven directly.

C. Operational Characteristics

The power of the wind is proportional to the cube of the wind-speed,⁽¹⁰⁾ but the output of the wind turbine is less than the total power available, as discussed in the following paragraphs. The strong sensitivity of wind power to wind speed implies that a small variation in wind speed can significantly affect the power output of a wind turbine. As a result, the viability of wind turbine systems can be highly variable with location. Consequently, locations only a few miles apart can have significantly different potentials for wind power utilization, depending on factors such as tree cover, bodies of water, and local topography.* These general data on wind velocities do not necessarily correlate with the actual distribution at a site and site-specific measurements should be made.

The actual output curve (power vs. wind speed) of a wind turbine typically consists of three pieces:

- (1) the output is zero below a "cut-in" wind speed V_{in} (in the region of 6 to 9 mph);
- (2) the output increases with wind speed to the speed V_r at which the turbine delivers its rated power, P_r ; and
- (3) above a wind speed V_m , (which is at or slightly greater than V_r), the output of the machine is held constant at P_m by control of the pitch of the blades to prevent excessive tip speeds in high winds. At a speed V_{out} the machine is closed down and the blade is feathered for self-protection.⁽¹⁾

The design curve for a modern, recently installed large wind turbine is presented in Figure 6-5.⁽²⁰⁾ The data points indicate that the actual

*References 17, 18, and 19 discuss siting considerations and wind distribution throughout the United States.

The boxes show actual recorded power outputs, and the lines indicate ± 1 standard deviation.

SOURCE: Reference 20.

FIGURE 6-5 THEORETICAL OUTPUT POWER FOR CLAYTON, NM, WIND MACHINE (MOD-OA) AT VARIOUS WIND SPEEDS

performance of the machine was close to expectations.

The output power of a turbine is less than the power theoretically present in the wind stream. Their ratio is commonly referred to as the power coefficient, C_p . Aerodynamic analysis⁽¹¹⁾ predicts an "ideal" maximum for C_p for propeller windmills of approximately 60%. Typically observed maximum values of C_p are lower and depend upon the type of machine,⁽²¹⁾ e.g., 47% for two-blade types, 35% for Darrieus rotor machines, and 30% for Savonius rotor machines.

The variation of the power output, P , of an actual machine with windspeed between V_{in} and V_r can be calculated only with difficulty, even with full and accurate knowledge of the aerodynamic and control characteristics of the machine. Alternatively, it may be convenient to assume for P (see, for example, Justus⁽²¹⁾) a cubic polynomial relationship in V , in which the coefficients are determined by matching at V_{in} and V_r or V_m . The design output curve in Figure 6-5 follows the equation:

$$P = 0.0226V^3 + 0.538V - 21.3$$

for $V_{in} \leq V \leq V_r$ within less than 5% of P .

Wind turbine generators are usually rated at their maximum output capability which occurs typically at wind speeds in the 20-30 mph range for commercially available equipment. Even in areas of favorable wind regimes, average wind speeds are rarely over 12-16 mph near ground level. In these areas, the average output of wind turbines is only 1/8 to 1/3 of the rated output, which indicates that the rated output is usually a poor indicator of actual output performance. NASA designs for large capacity systems reach rated outputs at lower wind velocities. This leads to higher capacity factors than those of the commercial units currently available. Depending on site location, DOE expects to have capacity factors which range from 25-40% for 500 to 3000-kW units.⁽²²⁾

In addition to the factors which reduce the conversion efficiency cited above, there are further losses in the conversion of shaft power to electricity. Generators typically have an efficiency of 95%. When a dc generator is used, an inverter must be employed to produce ac.

Typical full-load efficiencies range from 85% for 15-kW units to 93% for 100-kW units and up. At partial load conditions, this efficiency is reduced. For a horizontal-axis machine, combining these efficiencies yields an instantaneous conversion rate, ac output divided by available wind power, of approximately 0.4. This must be further reduced by the capacity factor discussed above to obtain the actual annual output.

One of the major difficulties in utilizing wind turbine systems is matching the demand for power with the availability of wind. Because of the wide variations in available wind power discussed above, it would be necessary to incorporate a substantial energy storage system if the wind system were to be the only source of power. In most cases, the economics of substituting an on-site wind turbine system for power from a central utility without a provision for backup by the utility are not advantageous. Several different approaches to this problem, currently used or being considered, are discussed briefly in the following paragraphs.

Very large wind turbine systems of the type being developed by NASA for DOE which are used to generate power within a central power system could be used in situations where an existing hydroelectric capability exists nearby.⁽²³⁾ In this case, wind power would be used to displace hydropower whenever sufficient wind velocity was available. When the wind velocity dropped below a certain point, hydro would pick up the load. The savings in this case would be in the form of the dammed water which would not be used to generate power when wind was available.

In a central power system, the total capacity added by a wind turbine system cannot be used to replace base load-generating capacity because of the random availability of wind power. The primary advantage comes from the displacement of higher cost fuels for peaking equipment with wind energy.

Larger systems without a connection to the central power system utilize other forms of backup. A system currently being installed on Cuttyhunk Island in Massachusetts uses a diesel-powered system to provide energy when the wind velocity is too low.^(23,24) This diesel system is already providing power on the island, and the wind power system will simply be added to reduce operating cost when the wind velocity is

sufficient to generate power. The diesel system will automatically start up when the output from the wind turbine system drops below a minimum value. Similar systems with diesel backup have been installed in other remote areas.

D. Energy Storage

Lead-acid batteries may be included in a wind turbine system to provide short-term storage capability. These battery systems are sized to store a fraction of the energy generated for use in meeting peak demands during the typical daily cycle. However, they do not store sufficient energy to supply the system over a prolonged period of low wind availability. These systems generally rely on the use of energy from the utility system for backup. If batteries are employed, it is important to account for losses within the storage subsystem.⁽²⁵⁾

A number of other storage systems have been proposed for use with wind power systems.^(1,5) These include:

- hydrogen storage systems in which hydrogen is generated by electrolysis of water and stored to provide heat or to power fuel cells when energy is required;
- thermal storage in which mechanical work is converted to heat or in which electrical energy is stored as heat for use in space heating;
- flywheel storage in which electrical or mechanical energy is used to drive flywheels which subsequently produce electricity on demand;
- compressed air storage in which the mechanical or electrical energy generated by the wind system is used to compress air, which is pumped underground; and
- the use of wind power to generate nitrogen fertilizer which can be stored as generated and used when required.⁽²⁶⁾

These systems are all in the conceptual or early experimental stage at this point and estimates of the storage costs associated with them are not well defined.

E. Equipment Availability

There are about two dozen companies now making wind turbine generators in the United States, Europe, and Australia. These units were developed primarily to generate power in remote areas where the cost of operating engine-generators or extending the utility grid was prohibitive. The characteristics of some commercially available wind turbine generators are shown in Table 6-1.*

Section 6.3: Economics Discussion

A. Cost of Wind Turbine Systems

Figure 6-6 shows how the installed cost of complete wind generators varies with system capacity. Typical commercially available units are in the 1-25 kW range and have installed costs of \$1500-\$3000 per kW based on maximum output capacity.**⁽¹⁴⁾ Cost estimates of systems in the 1000-kW size range were taken from a number of reports as analyzed by JBF.⁽²⁷⁾ Table 6-2 summarizes their data. The cost shown in Figure 6-6 as "DOE goal" is the cost which DOE projects for large units (500-1500 kW) once they are fully developed and in production.⁽²³⁾ The larger size units may be applicable for some on-site applications involving apartments, commercial buildings, and industrial plants.

Representative breakdowns of costs for several wind power systems are summarized in Table 6-3. As indicated, the wind turbine (blades, hub, generator, and controls) comprises the major system cost. The relative costs of components are similar to those for other wind turbine generators in this capacity range.

* See Reference 27 for other companies and addresses.

** Based on average wind speeds, the cost/kW can be significantly higher and varies depending on the wind conditions at each individual site.

SOURCE: Arthur D. Little, Inc.

FIGURE 6-6 COST OF WIND GENERATORS

TABLE 6-2

INSTALLED CAPITAL AND ENERGY COST ESTIMATES FOR 1 MEGAWATT WIND
TURBINE SYSTEMS PURCHASED IN 100-UNIT LOTS

<u>Study Source (a)</u>	<u>Capital Cost (b) (1977 \$/kW)</u>	<u>Capacity Factor (%)</u>	<u>Energy Cost (c) (1977 mills/kWh)</u>
Lockheed (28)	1211	53.7	38.4 (d)
G.E. (29)	504	38.0	28.0
Kaman (30)	652	43.0	32.0
Aerospace (31)	588	40.0	31.0
Honeywell (32)	739	43.0	36.3
SWRI (33)	842	59.0	30.1
G.E. (34)	793	38.0	44.0 (d)

(a) In Reference 27, the JBF Study, data from previous studies were analyzed. The reference numbers of these studies (28-34) are shown in parentheses.

(b) Costs taken from Reference 27, Table B4, and escalated at 8% for two years to represent 1977 costs of all equipment, installation, and site preparation.

(c) Energy cost (EC) calculated by Reference 27 as follows:

$$EC = \frac{C_c (\$/kW) \times FCR(\%) \times 10^3}{8760(\text{hrs}) \times CF(\%)}$$

where C_c = capital cost of system,

FCR = fixed charge rate = 18.5%, which includes a 3% component due to O&M costs, and

CF = capacity factor.

(d) These energy costs were calculated using the equation in note (c), but have been normalized by JBF(27) to account for variations in the (the vertical wind speed profile coefficient) assumed in the Lockheed (28) and General Electric Studies.(29,34)

TABLE 6-3

COST SUMMARY FOR THREE SIZES OF WIND TURBINES
(in 1977 \$/kW in 18-mph Wind)⁽¹⁾

Nameplate Rating	<u>6 kW</u> ⁽²⁾	<u>100 kW</u> ⁽³⁾	<u>1000 kW</u> ⁽⁴⁾
Rated Wind Speed	30 mph	18 mph	18 mph ⁽⁵⁾
Output in 18-mph Wind (kW)	2.5	100	1000
Component Cost for System			
Rotor (blades, pitch change, hub)	NA ⁽⁶⁾	740 (45%) ⁽⁷⁾	470 (50%)
Mechanical (gear box, bed plate, yaw control, shafts)	NA	290 (18%)	200 (22%)
Electrical (generator, controls, etc.)	NA	175 (11%)	75 (7%)
Total Wind Turbine Cost	1700	1205	745
Tower and Foundation	260	425 (26%)	200 (21%)
Total Equipment Costs	1960	1630	945
Transportation, Site Prep., Installation & Testing	1065	800	120
<u>TOTAL COST (\$/kW)</u>	<u>3025</u>	<u>2430</u>	<u>1065</u>

(1) 18 mph is common rating point.

(2) Based on estimates from Elektro, G.m.b.H., Switzerland, for unit costs if manufactured in production quantities.

(3) Reference 35.

(4) Reference 19.

(5) Measured at 49-foot height.

(6) Not Available.

(7) Percent of total equipment costs in parentheses.

Note: Original cost data (Notes 2,3,4) revised to 1977 dollars.

B. Future Cost Reductions

Several of the commercially available wind turbine generators are technically sophisticated, and their performance approaches the best obtainable. It is, therefore, doubtful that large cost reductions can be expected in the smaller units as a result of improvements in performance. However, based on experience with similar products, increased production would probably have cost benefits on the order of 20-50%, and simplified design and/or reduced material requirements may also decrease costs.

The unit costs projected for the larger units are seen to be less than half those of the smaller units (Figure 6-6) due, in part, to economies of scale associated with the major components such as generators, blades, and towers. These lower costs represent goals at this time and are not as firm as the costs indicated for smaller units which are commercially available.

C. Wind Turbine Energy Costs

The costs associated with owning and operating a wind power system include:

- Annual capital charges including interest on the initial cost and taxes,
- O&M costs, consisting of normal maintenance and periodic repairs of broken or faulty components.

Few reliable data are available on factors such as O&M costs, forced outage rates, etc. Routine maintenance includes tasks such as lubrication, replacing worn generator brushes, checking wiring and fasteners, etc. In estimating costs, a value of 3% of capital costs per year has been used as a representative number for these types of operations. ⁽²²⁾

Figure 6-7 shows estimates of future wind energy costs reported by NASA ⁽³⁶⁾ for three sizes of wind turbines :

- MOD-OA has a rated power output of 200 kW at a wind speed of 20 mph. This model is regarded as "first-

SOURCE: Reference 36.

FIGURE 6-7 ESTIMATED COST OF ELECTRICITY VS. SITE MEAN WIND SPEED FOR MOD-OA, MOD-1, MOD-2, AND MOD-2 (MATURE PRODUCT) WIND TURBINES. The assumptions involved in preparing the estimates are listed in the Notes.

NOTES:

$$A) \text{ COE} = \frac{\text{ACC} + (\text{O\&M})}{\text{AEO}}$$

where COE = Cost of Electricity (\$/kWh),

ACC = Annual Capital Charges
(Capital cost x .18) (Note B),

O&M = Capital Cost x .03, and

AEO = Annual Energy Output (Figure 6-9).

B) Installed Capital Cost (1977\$)

Model	Total	Per kW
OA	1.6×10^6	\$8000
MOD-1	4.8×10^6	2400
MOD-2	2.8×10^6	1100
MOD-2 (mature)	1.4×10^6	560

generation-technology"; its power output curve is presented in Figure 6-5.

- MOD-1 is a larger first-generation-technology machine with a rated output of 2000 kW at 22 mph. The first example of this type was undergoing acceptance tests in early 1979.
- MOD-2 is a second-generation-technology machine designed to be "cost competitive, safe, reliable . . . for utility applications at moderate wind sites." It has a rated output of 2500 kW at 18 mph. MOD-2 machines are scheduled to begin operations in 1980.

The power output curves of these three machines are presented in Figure 6-8. With a knowledge of the distribution of wind speeds at a typical site and the output characteristics of the turbine, the annual energy outputs can be calculated. They are presented in Figure 6-9 as a function of mean wind speed for an assumed machine availability of 90%. The resulting energy costs are presented in Figure 6-7 for MOD-0A, MOD-1, and two generations of MOD-2 turbines. The "mature" version of the MOD-2 machine assumes significant capital cost reductions as a result of experience and large-scale manufacture.

The data presented in Figure 6-7 clearly indicate that the cost of energy increases rapidly with decreasing average wind speed. They emphasize the importance of operating wind turbine generators only in areas having favorable wind regimes -- probably where the mean wind speed is 15 or greater.

Section 6.4: Limitations

A. Introduction

As indicated above, the major factor which will limit the widespread implementation of on-site wind turbine generators will be their cost when compared to conventional power sources. Institutional and

SOURCE: Reference 36.

FIGURE 6-8 POWER OUTPUT AS A FUNCTION OF WIND SPEED
FOR THREE WIND TURBINES

SOURCE: Reference 36.

FIGURE 6-9 ANNUAL ENERGY OUTPUT VS. SITE MEAN WIND SPEED FOR THREE WIND TURBINES, AT AN ASSUMED MACHINE AVAILABILITY OF 90%

industrial barriers may be associated with such issues as the ability to provide a sufficient number of skilled technicians for system installations, integration with central utility systems, and component production limitations. Other serious barriers to the widespread implementation of wind turbines for on-site use will probably be those associated with:

- availability of land and "wind rights,"
- interference with television reception due to blade motion,
- geographic limitations, and
- negative visual impacts resulting from the height of the wind turbine installations.

B. Detailed Discussion

1. Geographic Limitations

As mentioned in the technical discussion, the actual power output of a wind turbine generator is extremely sensitive to wind speed. In order for a system to be economically attractive, a high annual average wind power is required. Although local conditions may cause anomalies in the data, it is possible to identify areas where wind turbines are most likely to be effective. Figure 6-10 shows a map of the United States on which average wind power is plotted. From this map, it can be seen that Northeast and Pacific coastal areas and the central plains represent the most likely sites. However, even in these regions variations from one year to another can be as large as 40%.⁽⁵⁾ Therefore, system designs must include provision for extended periods of low wind availability. In addition, wind turbines generate wakes which limit how closely the units can be spaced.⁽¹²⁾ Thus, for large groupings of turbines, a significant land area may be required. The question of wind rights can arise if the wind system to a turbine is blocked by a neighboring turbine or building.

2. Aesthetics

In order to make reasoned judgments on the visual impact of

*Perpendicular to wind, 33 feet above surface. 0 indicates location measurement made.

SOURCE: Reference 37.

FIGURE 6-10 AVAILABLE WIND POWER - ANNUAL AVERAGE

on-site wind turbine power plants, it is important to consider the sizes of the units that would be used in typical residential and commercial applications. As previously indicated, the size of a unit required to produce a given power output is very sensitive to the average wind speed. Therefore, the size of the system (blade diameter, tower height, etc.) required for any given application will depend on the typical wind velocities prevalent in the location under consideration. Table 6-4 presents estimates for the size of wind turbine power plants that would be used for three potential applications. The following wind regimes are shown:

- Strong Wind Regime (~ 16 mph) - This would correspond to these areas of the country with particularly high average wind conditions such as parts of the Great Plains and coastal areas of New England.
- Average Wind Regime (~ 12 mph) - Corresponds to areas with fairly average wind conditions such as the Middle Atlantic states and parts of the Rocky Mountain area.
- Low Wind Regime (~ 9 mph) - Corresponds to areas with below average wind speed conditions such as parts of the West Coast and the Southwest.

In an area of "average" wind conditions, a single-family house would require a tower approximately 35 feet high and a turbine blade diameter of 19 feet to satisfy a major portion of the electrical power requirements. Small apartment houses would require a tower about 80 feet high with wind turbine blades 100 feet in diameter if a single wind turbine generator were used, and a typical commercial building would require a tower over 100 feet high to support a turbine with a blade diameter of 150 feet. Clearly, there are serious questions whether it would be acceptable to the public to use a multiplicity of wind turbines of these sizes in residential and commercial areas.

TABLE 6-4

BLADE DIAMETER (FEET)⁽¹⁾ FOR ON-SITE APPLICATIONS
WITH DIFFERENT AVERAGE WIND SPEEDS

	<u>High Wind</u> <u>(16 mph)</u>	<u>Average Wind</u> <u>(12 mph)</u>	<u>Low Wind</u> <u>(9 mph)</u>
Residence (16 kWh/day)	12	19	26
Apartment House (480 kWh/day)	62	101	140
Commercial Building (1300 kWh/day)	92	150	212

(1) Wind turbine sizing assumes 20% electrical losses in power conditioning and storage battery subsystems, and 40% of power used without passing through storage system.

SOURCE: Arthur D. Little, Inc.

3. Electrical Interference

The motion of metal wind turbine blades may cause interference problems for television receivers. This is particularly true for the larger turbines which might service groups of houses, apartments, or commercial properties. For these larger units, the range of the interference problem could severely limit the placement of wind turbine systems. (38,39)

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Mitre Corporation. Wind Machines. Report prepared for the National Science Foundation, October 1975. Report No. NSF-RA-N-75-051.
2. Park, J. "Operational Experience with Small Wind Units, Vol. II." Proceedings of the Eleventh Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-16, 1976. pp. 1795 ff.
3. Page, J.K., et al. "The New Alchemy: How to Survive in Your Spare Time." Smithsonian Magazine 5(11):82, 1975.
4. Malver, F., et al. "The Application of Wind Power Systems to the Minnesota Power and Light Company." Sharing the Sun! Solar Technology in the Seventies. A joint conference of the American Section of the International Solar Energy Society and the Solar Energy Society of Canada, Inc., Winnipeg, Canada, August 15-20, 1976. pp. 289 ff.
5. Merriam, M.F. "Wind Energy for Human Needs." Technology Review 79:29, January 1977.
6. Higgin, R., et al. "Preliminary Assessment of the Potential for Medium and Large Capacity Wind Generators Used as Fuel Savers for AC Diesel Based Power Systems in Ontario." Sharing the Sun! Solar Technology in the Seventies. A joint conference of the American Section of the International Solar Energy Society and the Solar Energy Society of Canada, Inc., Winnipeg, Canada, August 15-20, 1976. pp. 180 ff.
7. Product information from the following companies:
 - a. ENERTECH CORPORATION
P.O. Box 420
Norwich, Vermont 05055
 - b. GRUMMAN ENERGY SYSTEMS
4175 Veterans Memorial Highway
Ronkonkoma, New York 11779
 - c. REDE CORPORATION
P.O. Box 212
Providence, Rhode Island 02901
 - d. BOSTON WIND, INC.
2 Mason Court
Charlestown, Massachusetts 02129
 - e. THE HELLER-ALLER COMPANY
22920 North Bellwood Drive
Southfield, Michigan 48034
 - f. AUTOMATIC POWER
P.O. Box 18738
Houston, Texas 77023

REFERENCES (continued)

8. Yamagiwa, A. "Experimental Evaluation of a Solar/Wind Powered Space Heating and Hot Water Heating System in the Pacific Northwest." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1243 ff.
9. Quinn, B. "The Consumer's Cost of Electricity from Windmills." Proceedings of the Eleventh Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-16, 1976. pp. 1745 ff.
10. Hirschfeld, F. "Wind Power." Mechanical Engineering 99:20, 1977.
11. Puthoff, R., et al. Status Report of 100 kW Experimental Wind Turbine Generator Project. National Aeronautics and Space Administration, 1975. NASA Technical Memorandum No. NASA TM X-71758.
12. American Wind Energy Association. An Index of Manufacturers, Researchers, and Distributors Currently Involved in the Development of Wind Energy Conversion Systems. Prepared under Contract No. E-(29-2)-3533 for U.S. Department of Energy, February 1978.
13. Obermier, T. An Economic Evaluation of Small Scale Wind Powered Electric Generation Systems. American Society of Mechanical Engineers, 1976. Paper No. 76-WA/ENER-1.
14. Kaza, K.R.V., et al. Evaluation of Mostas Computer Code for Predicting Dynamic Loads in Two-Bladed Wind Turbines. Washington, D.C.: U.S. Department of Energy, 1979.
15. Sandia Laboratories. Sandia Vertical-Axis Wind Turbine Program, Technical Quarterly Report, October - December 1975. April 1976. NTIS Report No. SAND76-0036.
16. General Electric Space Division. Applied Research on Energy Storage and Conversion for Photovoltaic and Wind Energy Systems. January 1978, NTIS Report No. HCP/T-22221-01/1.
17. Sandia Laboratories. Wind Power Climatology. December 1974. NTIS Report No. SAND74-0435.
18. Radice, F.C. "Siting of Wind Driven Apparatus." Proceedings of the Eleventh Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-16, 1976. pp. 1736 ff.
19. Lockheed-California Company, Burbank, California. Wind Energy Mission Analysis. Prepared under Contract No. EY-76-C-03-1075 for Energy Research and Development Administration, April 1976.

REFERENCES (continued)

20. Reddock, T.W., et al. "No Ill Winds for New Mexico Utility." IEEE Spectrum 16(3):57, 1979.
21. Justus, C.G. Winds and Wind System Performance. Philadelphia, Pennsylvania: Franklin Institute Press, 1978.
22. Metz, W.D. "Wind Energy: Large and Small Systems Competing." Science 197:971, 1977.
23. Bechtel Corporation. Energy Storage and Power Conditioning Aspects of Photovoltaic Solar Power Systems. Prepared under Contract No. F(11-1) - 2748 for Energy Research and Development Administration, October 1975.
24. "Island Eyes Wind Energy Proposal." Boston Herald American, September 4, 1977. pp. A3.
25. Dubey, M. "Conversion and Storage of Wind Energy as Nitrogenous Fertilizer." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 525 ff.
26. Federal Energy Administration. Wind Energy Conversion Systems Manufacturing and Sales Activity 1975 and 1976. April 1977. NTIS Report No. FEA/B-77/121. pp. 265 ff.
27. JBF Scientific Corporation. Summary of Current Cost Estimates of Large Wind Energy Systems. Report prepared for Energy Research and Development Administration, February 1977. NTIS Report No. DSE/2521-1.
28. Lockheed-California Company, Burbank, California. Wind Energy Mission Analysis. Prepared under Contract No. EY-76-C-03-1075 for Energy Research and Development Administration, April 1976.
29. General Electric Corporation. Design Study of Wind Turbines 50 kW to 3000 kW for Electric Utility Application. Vol. II Analysis and Design. Report prepared for National Aeronautics and Space Administration, December 1976. NTIS Report No. ERDA/NASA/9403-76/2.
30. Kaman Aerospace Corporation. Design Study of Wind Turbines 50 kW to 3000 kW for Electric Utility Applications - Analysis and Design. Report prepared for National Aeronautics and Space Administration, February 1976. NTIS Report No. DOE/NASA-9404-76/2.
31. The Aerospace Corporation. Wind Power for the California Aqueduct. El Segundo, California, March 1976.
32. Honeywell, Inc. The Application of Wind Power Systems to the Service Area of the Minnesota Power and Light Company, Executive Summary. October 1976 - March 1977. Quarterly Report No. 3. Minneapolis, Minnesota, 1977.

REFERENCES (continued)

33. Ligon, C. et al. Operational Cost and Technical Study of Large Windpower Systems Integrated with an Existing Electric Utility. Prepared by Southwestern Public Service Company, April 1976. NTIS Report No. COO-2621-2.
34. General Electric Corporation. Wind Energy Mission Analysis. Prepared under Contract No. EY-76-C-02-2578 for Energy Research and Development Administration, October 1976.
35. Böer, K.W., ed. Sharing the Sun! Solar Technology in the Seventies. A joint conference of the American Section of the International Solar Energy Society and the Solar Energy Society of Canada, Inc., Winnipeg, Canada, August 15-20, 1976.
36. Robbins, W.H., et al. "Large Horizontal Axis Wind Turbine Development." Wind Energy Innovative Systems Conference, Colorado Springs, Colorado, May 23-25, 1979. NASA Technical Memorandum No. NASA TM-79174.
37. Blackwell, B.F., et al. Wind Energy -- A Revitalized Pursuit. Sandia Laboratories, 1975. NTIS Report No. SAND75-0166.
38. Sengupta, D.L., et al. Electromagnetic Interference by Wind Turbine Generators. Final Report prepared under Contract No. EY-76-S-02-2846. A001 for the U.S. Department of Energy, March 1978.
39. Senior, T.B.A., et al. Wind Turbine Generator Siting and TV Reception Handbook. Prepared by University of Michigan under Contract No. EY-76-S-02-2846A001 for the U.S. Department of Energy, January 1978. University of Michigan Technical Report No. 014438-1-T.

CHAPTER 7
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: SOURCES OF BIOMASS AND THEIR DIRECT CONVERSION TO ENERGY</p> <p>DESCRIPTION: Combustion of biomass residues or crops primarily for steam raising. This includes waterwall incineration and controlled-air incineration.</p> <p>POTENTIAL USER CLASSES: Utilities, large industries, municipalities</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Mostly well advanced; some technology in early years of commercialization.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th style="text-align: center;">1977</th><th style="text-align: center;">1985</th><th style="text-align: center;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY</td><td style="text-align: center;">To 1000</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td style="text-align: right;">SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY</td><td style="text-align: center;">To 6.6</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td style="text-align: right;">SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td style="text-align: center;">.75</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td style="text-align: center;">.6-.9</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td style="text-align: center;">.40-.70</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Biomass, crops, residues, MSW⁽¹⁾ AMOUNT NEEDED PER UNIT OUTPUT: 0.15-0.25 ton/10^6 Btu</p> <p>ALTERNATIVE FUEL(S): Fossil fuels IS SYSTEM READILY CONVERTIBLE? Yes, except where flue gas cleaning may be required for fossil fuel. Conversion can result in derating.</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Can be steady for baseload, except in some cases of municipal or industrial wastes when waste deliveries are intermittent, e.g., weekdays only.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p style="padding-left: 20px;">DESIRABLE FOR USER? Not unless there is a sufficiently large excess of steam to justify power generation for sale. This would not ordinarily be the case.</p> <p style="padding-left: 20px;">TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Not needed--energy is stored as fuel.</p> <p style="padding-left: 20px;">SYSTEM:</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY	To 1000	same	same	SECONDARY				UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY	To 6.6	same	same	SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:	.75	same	same	RANGE OF CAPACITY FACTORS:	.6-.9	same	same	EFFICIENCY (BTU OUT/BTU IN):	.40-.70	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY	To 1000	same	same																																
SECONDARY																																			
UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY	To 6.6	same	same																																
SECONDARY																																			
AVERAGE EFFECTIVE CAPACITY FACTOR:	.75	same	same																																
RANGE OF CAPACITY FACTORS:	.6-.9	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.40-.70	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th style="text-align: center;">1977</th><th style="text-align: center;">1985</th><th style="text-align: center;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input)</td><td style="text-align: center;">19,000-32,600⁽ⁱⁱ⁾</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/10^6 Btu)</td><td style="text-align: center;">1.55-3.95⁽ⁱⁱⁱ⁾</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td style="text-align: center;">4 mos to 3 yrs</td><td style="text-align: center;">same</td><td style="text-align: center;">same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input)	19,000-32,600 ⁽ⁱⁱ⁾	same	same	AVERAGE UNIT O&M: (\$/ 10^6 Btu)	1.55-3.95 ⁽ⁱⁱⁱ⁾	same	same	CONSTRUCTION PERIOD:	4 mos to 3 yrs	same	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input)	19,000-32,600 ⁽ⁱⁱ⁾	same	same																																
AVERAGE UNIT O&M: (\$/ 10^6 Btu)	1.55-3.95 ⁽ⁱⁱⁱ⁾	same	same																																
CONSTRUCTION PERIOD:	4 mos to 3 yrs	same	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION:</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: Generally less severe than for fossil fuels, except for severe land use implications</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Waterwall boilers for waste disposal have gained a reputation as pollution sources when MSW is burned. While appropriate pollution control technologies are now available, there is likely to persist some resistance to their implementation.</p>																																		
COMMENTS	<p>(1) MSW = Municipal Solid Waste.</p> <p>(ii) Equivalent to \$0.07 - \$0.20/Btu/hr output.</p> <p>(iii) Equivalent to \$1.71 - \$4.35/1000 pounds of steam out, at 1100 Btu per pound of steam.</p>																																		

CHAPTER 7

SOURCES OF BIOMASS AND THEIR DIRECT CONVERSION TO ENERGY

Section 7.1: Introduction

The sources of biomass that are presently of the greatest interest as new sources of energy are as follows:

- Biomass Farms
 - Land
 - Water
- Cellulosic Residues
 - Crop (agricultural)
 - Wood (forestry)
 - MSW (municipal solid wastes)
- Other Biological Residues
 - Manure
 - Sewage Sludge.

Biomass farms (plantations) would grow terrestrial crops, such as timber, forage grass, and sugar cane, or aquatic crops, such as water hyacinth and algae to be converted to other energy forms by combustion, fermentation, gasification, or liquefaction. The gasification product could be used to produce ammonia, an important chemical intermediate, and thereby displace the large fossil energy requirement in conventional plants.

Cellulosic residues, such as crop residues, wood residues (primarily those presently left in the forests), and MSW* (primarily the combustible organic fraction) could also be converted to energy by similar techniques.

Section 7.2: Biomass Resources

Numerous studies have been conducted to investigate the possibility of growing annual crops such as corn,⁽¹⁾ sorghum,⁽²⁾ kenaf,⁽³⁾ or

* Municipal Solid Waste.

sunflowers,⁽³⁾ or perennial crops such as sugarcane,⁽²⁾ Sudan grass,⁽³⁾ or wood⁽⁴⁾ as energy sources. The crop offering the highest yield per acre per year, sugarcane (20 tons dry biomass/acre/year), also requires large quantities of water, fertilizer, and other energy expenditures, including those for harvesting, to promote maximum yield. Yields from hardwoods -- such as eucalyptus, cottonwoods, and red alder -- and warm season grasses -- such as perennial sorghums and Bermuda grasses -- are much lower (8-10 tons dry biomass/acre/year), but the water and fertilization requirements also are much lower.^(3,5)

Limiting factors in the utilization of agricultural residues as an energy source are the competing demands for use of these materials as silage for livestock (influenced by grain prices) and the need for these residues for field mulch and soil tilth. In addition, the seasonality of agricultural waste production and its susceptibility to biological degradation also are drawbacks to the utilization of agricultural wastes.

A large percentage of the wood residue generated at pulp and paper mills, sawmills, and plywood plants is already being utilized as fuel or converted to wood products. The residues generated in the forest logging operations represent a source that could be more efficiently utilized in some cases, but new developments, such as whole-tree chipping to utilize more of the wood for paper pulp production, could eventually lead to a reduction in the availability of this residue.

Most of the fuel value of MSW is due to its paper content. The heat value of this paper fraction may be recovered either directly from MSW by thermal or biological processes, or by first separating the paper fraction and then converting it to fuel. Essentially all of the waste paper (95%, Arthur D. Little, Inc., estimate) recycled to papermaking is segregated at the point of generation of waste and does not appear in MSW. Depending on waste-paper-market conditions, which tend to fluctuate widely, some of this paper might also be available for use as fuel or as an energy source.

The total quantity of livestock manure generated annually is about 1.9 billion wet tons⁽⁶⁾ which is equivalent to about 350 million dry tons.

The vast majority of this falls on open pasture land; only about 26 million dry tons⁽⁷⁾ specifically are collected and returned to the soil. Depending on the economics, a major portion of this might also be made available for energy production, and much of the residue could be recycled to the land for its nutrient value.

Sewage sludge is, for the most part, an ineffectively used source of energy. Most of this sludge is anaerobically or aerobically digested; but in the digestion systems used today, a major portion of the fuel energy created is required for heating the digestors. An estimated 5.6 million tons of sewage sludge were generated in 1974.⁽⁶⁾ As more municipalities are required to increase their treatment of sewage, this figure can be expected to increase. Sewage sludge, like MSW and unlike manure and agricultural wastes, is generated in more highly populated areas closer to the energy demand market.

A. Fuel Farms: Land

Table 7-1 summarizes the current yields and nutrient requirements for selected possible energy crops at various U.S. locations. The table shows the ranges of yield -- from about 5 dry tons per acre for some hardwoods to more than 20 dry tons per acre for sugarcane in Hawaii. To sustain these yields in most locations requires about 10 lb of nitrogen (as N), 0-5 lb of phosphorus (as P_2O_5), and 0-20 lb of potassium (as K_2O) per dry ton of biomass yield. Water requirements vary from moderate levels for hardwoods, which can be supplied by natural rainfall in many locations, to very high levels, requiring significant irrigation, in most U.S. areas.

The land area which would be required to support the energy needs of a small electric power plant (100 MW, operating at an annual average output of 60 MW) is about 50 square miles for Populas and 17 square miles for sugarcane (Texas).*

* Assumes a power plant heat rate of 10,500 Btu/kWh, and an energy content of 17×10^6 Btu/ton for wood and 15×10^6 Btu/ton for sugarcane.

TABLE 7-1

YIELD AND RESOURCE REQUIREMENTS OF POTENTIAL ENERGY CROPS

Species	Location	Yield (DT ⁽¹⁾ /acre/yr)	Fertilizer (lb/acre)			Water (acre-ft/yr)	Ref. No.
			N	P ₂ O ₅	K ₂ O		
Sugarcane	Florida	10.9	0	10- 15	180	10	(2)
	Louisiana	7.5	80-140	40	80	8	(2)
	Texas	11.7	0	0- 40	0	12	(2)
	Hawaii	15.8	300-400	45- 55	~200	16	(2)
		20.0	180	75	180	14.7	(8)
	Puerto Rico	10.2	120-150	0-168	0-224	10	(2)
Sugar beet	Continental U.S.	3.7	20-150	50-150	100-300	10 - 13	(2)
Sweet Sorghum	Southeastern U.S.	6-8	40	40	30- 40	5 - 14	(2)
Corn	Continental U.S.	4-5	120-140	40- 70	20- 80	1.5 - 2	(2)
American Sycamore	Continental U.S.	6	69	13	71	3.5	(10,11)
Eucalyptus	Continental U.S.	5	58	11	60	3.5	(10,11)
Populas	Continental U.S.	9-10	104-112	20- 22	107-112	3.5	(10,11)
Red Alder	Continental U.S.	9	104	20	107	3.5	(10,11)

(1) DT = dry tons.

These estimates give support to earlier work of Povich,⁽⁸⁾ who estimated that a 100-MW power plant would require a 32-square mile Hawaiian sugarcane plantation when operated at full capacity (19 square miles @ 60 MW); and of Stanford Research Institute (SRI),⁽⁹⁾ which estimated that a large, 1000-MW power plant would require a 245-square mile area of high-yield land. SRI further estimated that a total of 5 acre-feet of water per acre per year would be required.

Table 7-2 summarizes the recent production levels of crops which are candidates for biomass energy plantations. The table includes the possible future production rates if sufficient effort were directed to biomass energy projects. Affecting the ability to achieve these production levels are factors such as:

- urgency of the U.S. energy needs;
- quality of land cultivated -- much land not now used for agriculture is of poorer quality than that already being produced;
- rainfall -- since most energy plantation concepts will require some irrigation, the availability of water will be quite important; and
- need to recycle nutrients -- very large-scale energy farming will demand significant quantities of nutrients, especially phosphate and potassium, relative to present production levels and in-ground resources.

Battelle⁽²⁾ estimated that in 1976 the cost of producing sugarcane in the United States ranged from \$18-32/ton of combustible organics (\$1.20-\$2.13/10⁶ Btu). This assumption is probably reasonable for 1977 also. Further, Battelle has speculated that in a critical need situation, the cost of sugarcane biomass production in 1985 and 2000 can be reduced to \$15-28/ton (\$.99-\$1.30/10⁶ Btu) and \$13-19/ton (\$.85-\$1.27/10⁶ Btu), respectively, through close spacing of crops. These costs are in 1977 dollars, updated by 6% from 1976 dollars.

MITRE⁽¹⁰⁾ estimates that silvicultural biomass production costs of \$0.99-\$1.57/10⁶ Btu will be feasible in the future at 10 specific sites

TABLE 7-2

CURRENT AND POTENTIAL FUTURE PRODUCTION OF BIOMASS ENERGY

<u>Crops</u>	<u>Year(s)</u>	<u>Recent Historical</u>			<u>Possible - 2000</u>			<u>Ref. No.</u>
		<u>Yield</u> (DT/acre)	<u>Land Area</u> (10 ⁶ acres)	<u>Production</u> (10 ⁶ DT/yr)	<u>Yield</u> (DT/acre)	<u>Land Area</u> (10 ⁶ acres)	<u>Production</u> (10 ⁶ DT/yr)	
Sugarcane	1975	12.9	0.77	10.0	8-25	3.4	48.7-73.4	2
Sweet Sorghum	(avg 1973-1975)	6-8	0.01	0.07	6-10	1.8	15	2
Sugar beets	1975	19.3	1.52	29.3	*	3.0	*	2
Corn	(avg 1973-1975)	0.85	60.7	51.7	6-7	100	600-700	1
Forest Products	1976	0.90	500	450	--	--	--	18
Biomass Farms	--	--	--	--	5-20	270-325**	410-488	10

* Sugar beet production levels are expected to be guided by the demand for food sugar. Any production increases would displace other sugar sources which might be diverted to energy production. Increased land dedicated to sugar beets would be diverted from other crops, not noncrop land.

** Assumes 10% of land available for silvicultural biomass farms.

in the United States. The costs at these sites range from \$1.28-\$2.62/ 10^6 Btu (updated by 6% from 1976 to 1977).

Irrigation can contribute significantly to the cost of crops with high water demand, such as sugarcane. Using MITRE's figures⁽¹¹⁾ of \$100-670/acre for installation and \$20-50/acre/year for operation and maintenance, we estimate the total cost of irrigation to be \$30-150/acre/year, depending on the system employed. If the crop yield is 30 dry tons/acre at 15×10^6 Btu/dry ton, the irrigation system cost amounts to about \$0.07-\$0.33/ 10^6 Btu plus the cost of water.

B. Fuel Farms: Water

Ryther⁽¹²⁾ has pointed out that seaweed can be cultivated in U.S. waters with appreciable yields -- from 15-28 dry tons/acre/year in temperate Massachusetts to 57 dry tons/acre/year in subtropical Florida. Dynatech⁽¹³⁾ has indicated that, as producers of organic matter, aquatic plants have several advantages over terrestrial plants:

- without the need to attach themselves to the earth, the aquatic plants devote more of their photosynthate to biomass than to elaborate structural tissue;
- water is not a limitation;
- CO_2 is not as growth-limiting, particularly in the ocean; and
- microscopic algae, in particular, are well suited to the absorption of sunlight and diffusion of nutrients because of their small size and simple shape.

On the other hand, nutrient limitations are an important factor. In the open ocean, nitrogen and phosphorus are the most severely limited nutrients in terms of limitations on plant growth; in coastal waters their concentrations are somewhat higher.⁽¹³⁾ Other nutrients such as carbon, hydrogen, oxygen, chlorine, sodium, potassium, calcium, magnesium, and sulfur are ordinarily present in ample quantities in the ocean. Trace elements and certain organic substances (vitamins) are also required.

Dynatech⁽¹³⁾ concludes that the design of an aquatic biomass culture system involves the maximization of two major parameters: nutrient availability and sunlight. When limiting nutrients are provided in sufficient quantity, the problem of optimum design becomes one of optimal use of incident sunlight. This can be controlled by both the culture depth and the rate of removal (harvesting) of material from the culture.

To date, no satisfactory cost-effective approach has been found for removing unicellular algae from the culture volume, although several methods -- including centrifugation, flocculation, flotation, sedimentation, and filtration--have been tried.⁽¹³⁾ Larger plants can, however, be harvested relatively easily.

CSO International, Inc., prepared a cost analysis for a 100-square-mile microalgae biomass system.⁽¹⁴⁾ Assuming an annual average biomass growth rate of 20 tons/acre/year, CSO estimated that the capital cost of this farm would be \$222.2 million, with no allowance for the cost of land. The operating cost (excluding depreciation and other capital related charges) would be an additional \$18 million per year. If capital charges are added at 15%, the algae cost would be in excess of \$40/ton or about \$2.70/10⁶ Btu.

C. Cellulosic Residues: Crop (Agricultural) and Wood

Approximately 75% (237 million dry tons) of the 322 million dry tons of crop residue is returned to the soil.⁽⁷⁾ Of the balance, 61 million tons are fed to livestock directly, 13 million tons are sold as fodder, 9 million tons used as fuel, and only 2 million tons wasted. About 48% of this residue is from small grains and grasses and 35% is from grain, corn, and sorghums, which have an average energy content of about 14 x 10⁶ Btu/ton.

The use of crop (agricultural) residues as a fuel energy source would withdraw the material from use as field mulch and soil tilth, which could in many cases have an adverse effect on subsequent growth

of crops.⁽³⁾ Crop residues presently being used for livestock feed might also be used as a fuel source, but would require replacement by other animal feeds (e.g., grain). Seasonal availability, transportation cost, the possible adverse effect on cropland, and drying/storage requirements would all detract from the potential of this material as an energy source. The use of a mobile pyrolytic converter would reduce transportation cost and allow nutrients to be returned to the soil, but the fuel or energy produced would then have to be utilized locally or transported to where it could be used.

The cost of recovering logging residues and transporting them to the mill in conjunction with the regular harvest is estimated by SRI⁽¹⁵⁾ to be about \$1.20-\$4.00/10⁶ Btu (1977 dollars). The estimated total volume of this harvesting residue in the logging area amounted to about 88 million dry tons in 1976, containing an average heating value of about 15 x 10⁶ Btu/ton. The unused wood and bark residues generated at the mill this same year were about 19 million dry tons.⁽¹⁶⁾

D. Municipal Solid Waste (MSW)

The average quantity of MSW generated in the United States in the mid-1970's has been estimated at about 134 million tons per year.⁽¹⁷⁾ The average composition of this waste in 1973 was estimated to be as follows:⁽¹⁸⁾

Paper	39.6%	Textiles	1.6%
Glass	10.3	Wood	3.6
Metals	9.9	Food	13.3
Plastics	4.1	Yard Waste	14.1
Rubber & Leather	2.7	Miscellaneous	1.5

The heating value of MSW is presently 4500-5000 Btu/lb and is expected to increase because the percentage of paper and plastic in MSW is increasing.

The generation of MSW is concentrated in areas of high population, where there is also the greatest market for energy as well as a well-developed transportation system. It is common practice to transfer MSW from packer (collection) trucks into transfer vehicles when collection is remote from the disposal site. Arthur D. Little, Inc., estimates of typical costs for operation of the transfer station, transportation, and final disposal are as follows:

Transfer Station	(600-1400 tons/day capacity)	\$0.60 \$1.00/ton
Hauling Cost	\$1.60/ton for 10 miles, one way	
	\$4.80/ton for 50 miles, one way	
Disposal Cost	\$5.00-20.00/ton for landfill or incineration.	

Another potential source of energy (that is related to MSW) is waste paper. A competing use for waste paper (segregated at the source of waste generation from MSW) is recycle to papermaking. The value of waste paper recycled to papermaking in 1976 was as follows:

<u>Grade</u>	<u>Price (\$/ton)</u>	<u>Equivalent \$/10⁶ Btu</u>
Corrugated Containers	20-40	1.33 - 2.67
Newsprint	15-25	1.00 - 1.67
Mixed	5-15	0.33 - 1.00

Under market conditions similar to 1976's, the separated waste paper could be an economical energy source.

E. Manure

Obviously, the states where most of the animal manure is generated are in agricultural areas (e.g., Iowa, Illinois, California, Oregon, Kansas, etc.). It is not surprising, therefore, that 26 million of the collectable 30 million dry tons are applied to the soil.⁽⁷⁾ The cost of applying the manure to the soil varies from \$1.50 to \$4/ton of dry manure. This manure, which contains 5800-7700 Btu/lb (dry),⁽⁷⁾ can also be used as feed for energy (methane) generation, but its agricultural value would have to be replaced by other fertilizers and by returning the nutrient-rich, digested residue to the soil.

F. Sewage Sludge

An estimated 5.6 million tons of sewage sludge were generated in 1974 in wastewater treatment facilities serving a population of 155 million.⁽⁶⁾ Approximately 30% of municipal wastewater sludge is incinerated, with almost the entire remainder being anaerobically or aerobically digested prior to land application or ocean disposal. Following installation of full secondary treatment facilities in all municipalities, we estimate that the generation of municipal sewage sludge would nearly double. The additional sludge generated could be processed for energy recovery in more efficiently designed conversion systems.

Section 7.3: Technical Discussion

A. Combustion of Biomass Crops and Residues

Biomass can be burned to produce steam or thermal energy for process, power generation, or heating use. In the past, the ash content of solid fossil fuels and the potential for char and slag formation have rendered them too dirty for many direct heating purposes.* As a result, most of the technology practiced to date has been limited to the steam-raising options. Today, with the increasing need for high energy conversion efficiency and with the increased attention to cleaner, renewable biomass fuels, the ability to utilize solid fuels in direct-fired applications (such as fluidized bed combustors) is improving.

MITRE⁽¹⁰⁾ has summarized the range of biomass fuel combustion techniques. These include:

- fluidized bed combustion,
- charcoal/oil slurry firing,
- stoker firing, and
- suspension firing (analogous to pulverized coal firing).

The first two techniques are still under development by the Department of Energy and are not commonly practiced on a commercial scale in the United States. Chapter 11 discusses the technology and economics of fluidized-bed combustion. While that discussion emphasizes coal applications,

*Examples of direct-fired wood waste applications are described in References 19 and 20.

fluidized beds may be used also for biomass combustion. An inherent advantage of using biomass in a fluidized bed -- as in any combustor -- is the relatively low sulfur content of the fuel. For the most part, the technology being developed to capture sulfur evolved from coal in a dolomite bed will not be required for biomass. Therefore fluidized beds should be able to be commercialized for biomass systems somewhat sooner and less expensively than for fossil fuel systems.

Stoker and suspension firing are commonly practiced solid-fuel combustion alternatives. The choice between the two is an economic one, depending most importantly on the capacity of the furnace in question, but also on the specific fuel. Suspension firing requires a more severe pretreatment involving size reduction of the fuel to less than 100 microns, and sometimes drying to facilitate the necessary grinding. In larger furnaces (usually in the range of $50\text{--}200 \times 10^6 \text{ Btu/hr}$), this more severe treatment can be justified on the basis of its favorable economy of scale and its slightly improved combustion efficiency relative to the simple grinding and sizing (approximately 1/4 in.) required for stoker firing.

By far the most common device for recovery of the heat of combustion of a solid fuel is the steam boiler. Depending on the conditions of temperature and pressure of the steam, it may be used for its thermal value and/or motive power to drive process equipment or an electric generator.

Conventional steam generation is a very old technology which has been modified and updated over the years to reduce investment requirements, improve efficiency, extend operating life, adapt to different fuels, and more recently, to minimize air pollution. The boiler type, firing method, and specific design requirements depend critically on fuel properties and burning capacity. Ideally, the boiler would be designed to burn a specific biomass fuel rather than be adapted at a later date. Usually, conversion from gas or oil to solid-fuel firing involves derating the boiler to permit sufficient residence time for combustion of the solid particles.

When coupled with the additional need for fuel storage and pretreatment, this option is often uneconomical. In short, boiler fuels, whether biomass-derived or otherwise, are not readily substitutable as fuels for a particular boiler.

Municipal solid waste differs from most other terrestrial biomass sources in that it is a non-homogeneous mixture containing significant quantities of metals, glass, and dirt in addition to the primarily cellulosic combustible fraction. On the other hand, it is usually drier than harvested biomass. The non-homogeneity of MSW often requires that prior to combustion it be processed for the removal of recyclables and contaminants, which can corrode, erode, or foul heat-transfer equipment. (This is often the case whether the MSW is to be converted directly to thermal energy or to a solid, liquid, or gaseous fuel. Chapter 8 discusses conceptually some of the process steps which are often employed in MSW preprocessing.)

One of the major areas of improvement in combustion/boiler technology has been the degree of integration of the furnace and the heat exchanger components (economizer, boiler superheater, etc.) into a single unit. Today, nearly all large water-tube steam generators employ so-called waterwall construction, which minimizes the cost of the equipment by:

- eliminating the need for refractory lining to keep the steel shell cool -- water cooling accomplishes this;
- permitting shop fabrication in more cases (up to large sizes) because very little refractory must be applied in the field; and
- recovering energy in the furnace wall area.

The sales of industrial (no steam reheat) water-tube boilers in the United States in 1977 are presented in Table 7-3. They are arranged by fuel to illustrate the extent to which biomass fuels have found widespread application.

These boilers are generally supplied by large manufacturers such as Babcock and Wilcox, Combustion Engineering, Foster Wheeler, Riley Company, and Zurn Industries, and by many other smaller companies. Some manufacturers

TABLE 7-3

INDUSTRIAL WATER TUBE BOILER SALES IN THE UNITED STATES, 1977

<u>Fuel</u>	<u>Units Sold</u>	<u>Capacity Sold (lb steam/hr)</u>
Wood	28	2,700,000
Bagasse	6	800,000
Black Liquor	4	1,300,000
Municipal Waste	2	140,000
Industrial Waste ⁽¹⁾	4	1,800,000
Fossil, all	428	33,960,000

(1) Probably mostly non-biomass.

SOURCE: "Stationary Water-tube Boiler Sales, 1977"
American Boiler Manufacturers Association, Arlington, VA. 1978.

produce all the system components (boilers, stokers or pulverizers, and burners, etc.); others purchase them from independent firms or even their competitors. Some firms specialize in burning certain fuels (e.g., The Bigelow Company, whose specialty is bagasse).

The city of Burlington, VT, is contemplating the installation of a 50-MW wood-fired power plant. Feasibility studies currently under way are concentrating on assessing the availability of wood at economic prices in the quantities required.⁽²¹⁾ The city is presently burning a mixture of 75% wood chips and 25% oil to generate up to 9 MW in a boiler originally designed for coal firing.⁽²²⁾

Boiler units of the water-tube design for municipal wastes are referred to as waterwall incinerators. This technology has been practiced most widely in Europe.^(23,24) In the United States, waterwall incinerators are available using any of three proprietary grate designs from Wheelabrator-Frye, UOP, and Nashville Thermal Transfer Corp.; the Wheelabrator and UOP designs are based on the technology of Von Roll and Martin, respectively, which were developed in Europe. Non-proprietary systems are also offered by numerous architect-engineers. In either case the major components are generally supplied by the same manufacturers. Current applications of these technologies in the United States are shown in Table 7-4.

TABLE 7-4

CURRENT APPLICATIONS OF WATERWALL INCINERATORS IN THE UNITED STATES

<u>Location</u>	<u>Operator</u>	<u>Technology</u>	<u>Capacity (tons MSW/day)</u>	<u>Operational</u>
Saugus, MA	RESCO	Wheelabrator- Frye	1200	1975
Chicago, IL	Chicago (Northwest)	UOP	1800	1971
Nashville, TN	Tennessee	Nashville Thermal Transfer Corp.	720	1974
Harrisburg, PA	Harrisburg	--	720	1972

SOURCE: Reference 25.

For these systems, the estimated average MSW-to-steam efficiency is about 67%,⁽¹⁸⁾ which compares with about 80% (+ 10%) for many moderately sized industrial coal-fired boilers.

Another combustion device which has been applied on a small scale, mainly to solid waste materials, has become known as a modular controlled-air incinerator, or starved-air incinerator. It is shown schematically in Figure 7-1. (26,27,28) Since the primary chamber is deficient in oxygen, it acts as a pyrolyzer and vaporizes the volatile components of the feed. The gases leaving the primary chamber contain large amounts of soot, hydrocarbons, and other combustibles which are completely burned in the secondary chamber by maintaining temperatures above 1400°F by operation of the auxiliary fuel burner. A thermocouple at the exit of the secondary chamber switches the burner on when the gas temperature at the exit falls below a preset temperature. At a high temperature setting, the burner is shut off, thereby conserving fossil fuel.

If the unit is designed for batch operations, ash is removed manually by opening a door at the end of the primary chamber; if the unit is designed for continuous operation, ash is removed by a continuous ash removal system at the end of the primary chamber.

SOURCE: Arthur D. Little, Inc.

FIGURE 7-1 REPRESENTATION OF A CONTROLLED-AIR INCINERATOR

For steam recovery, either a waste-heat boiler can be mounted on the secondary chamber preceding the stack of the modular incinerator, or the hot flue gases can be ducted to a separate waste-heat boiler. If there are several modular incinerators in a plant, ducting the hot gases to a separate waste-heat boiler may have some advantage in that the operation of the steam system would be simplified. Boiler feed-water treatment equipment and pumps are also required if steam is to be generated.

A typical overall fuel energy balance for the incinerator system at steady state is presented in Table 7-5. In calculating this balance, it has been assumed⁽²⁰⁾ that the total fuel energy input to the incinerator is 10.6×10^6 Btu/ton of feed, 9.5×10^6 Btu in burning the feed, and 1.1×10^6 Btu in burning 8 gallons of oil. The product steam (5700 lb/ton of incoming MSW) contains 6.1×10^6 Btu; energy losses include 1.0×10^6 Btu in the plant and 3.5×10^6 Btu in the stack gases. The net energy recovered is 6.1×10^6 Btu less the purchased energy of 1.6×10^6 Btu, or 4.5×10^6 Btu, which is equivalent to 42% of the total waste plus oil energy fed. Both the quantity and quality of the steam produced would change, depending upon assumptions made concerning the composition of the MSW, the auxiliary fuel consumed, the operation of the unit, and the design of the boiler. Therefore, the figures shown are only for purposes of illustration.

The controlled-air incinerator has been specifically designed to minimize the entrainment of particulates in the flue gases and thus to avoid the need for air pollution control equipment. Design constraints caused by this emission control requirement limit the size of modular incinerators to 25 to 50 tons/day of waste feed capacity. Units of capacities on the order of 100 lb/hr of waste are generally available from the same manufacturers. Many of these small units have found application in commercial establishments (e.g., restaurants) and institutional buildings (hospitals). However, because of current economics, most installations do not include the steam recovery option.

TABLE 7-5

ENERGY BALANCE FOR CONTROLLED AIR INCINERATION WITH HEAT RECOVERY

Basis: One ton MSW Burned

	<u>10⁶ Btu</u>	<u>%</u>
<u>Energy Input to Incinerator</u>		
Municipal Solid Waste	9.5	89.6
Fuel Oil	<u>1.1</u>	<u>10.4</u>
	10.6	100.0
<u>Energy Output from Incinerator</u>		
Steam Pipeline	0.4	3.8
Dissipated at Stack	3.5	33.0
Other Losses (residue, etc.)	<u>0.6</u>	<u>5.7</u>
Total Heat Losses	4.5	42.5
Energy Sold as Steam	<u>6.1</u>	<u>57.5</u>
Total Heat Out	10.6	100.0
<u>Net Energy Recovered</u>		
Energy Sold as Steam	6.1	57.5
Less Purchased Energy Consumed:		
Fuel Oil to Incinerator	1.1	10.4
Electricity for Auxiliaries	0.3	2.7
Gasoline for Loader	<u>0.2</u>	<u>1.9</u>
Net Energy Recovered	4.5	42.5

SOURCE: Arthur D. Little, Inc., calculations based on 1977 manufacturers' data, including Consumat Systems, Inc., Richmond, VA., Environmental Control Products, Inc., Charlotte, NC., and Kelley Company, Milwaukee, WI.

An analog of this technology is finding increasing popularity as a domestic heat device. (29,30,31,32) The so-called air-tight wood stove operates on the starved-air principle, usually with two stages of combustion and an extended path for the combustion gases to maximize the opportunity for heat recovery in the building. Because of the relative simplicity of burning wood logs on a grate, wood stoves do not require the sophisticated controls of the large-scale incinerators and can operate essentially unattended. They are available in a wide variety of designs from many U.S. and foreign manufacturers. Since the stoves are ordinarily located in the living area, aesthetics are a consideration in the design.

The major advantage of air-tight stoves is that they avoid the loss of large, uncontrolled quantities of warm room air by admitting only that air actually required for combustion, plus a nominal excess to ensure complete burning. The principal disadvantage is that for most conventionally designed homes, a wood stove is not capable of acting as a central heating system.

Section 7.4: Economics Discussion

A. Biomass

The estimated costs of producing and/or recovering various forms of biomass have been discussed above in conjunction with the technical discussions. In summary, it is projected that by 1985-2000 some biomass forms, such as sugarcane and hardwoods, can be produced at costs competitive with coal's. Other forms, such as microalgae, may be produced at higher cost but in a form that may be converted to substitute natural gas at an overall cost competitive with that of synthetic natural gas (SNG) from coal. Of course, such projections assume reasonable advances in the current state of technology to achieve economically sound yields and recoveries.

A detailed cost estimate for a 55-MW wood-fired power plant for electricity production was developed by MITRE⁽³³⁾ in 1976. The capital cost totaled \$55 million, or \$1000/kW. Annual operation and maintenance costs of \$3.6 million were estimated, exclusive of capital charges or fuel costs. The technology is quite similar to that practiced in the pulp and paper industry; direct cost comparisons are not possible because of the many specific requirements of integration in a pulp and paper plant, including cogeneration of electricity, extraction of steam at various pressure levels, and combustion of special wastes such as black liquor.

B. Municipal Solid Waste

Table 7-6 summarizes the estimated economics of waterwall incineration. The capital investment for a plant to process and convert 1000 tons/day of MSW is estimated to be \$30.8 million in 1976 dollars, or \$30,800/daily ton (equivalent to about \$32.6 million in 1977 dollars, or \$32,600/ton/day). The estimated annual costs in 1977, including capital charges of 10% and 18% as computed by Alich, et al.,⁽³⁴⁾ are, respectively, \$20.13 and \$28.03/ton of MSW, or \$3.36 and \$4.68/1000 lb of steam. Any credits for dumping (tipping) fees or sale of scrap metals would lower the overall costs.

A similar economic analysis for modular-controlled air incinerators is presented in Table 7-7. The capital investment was estimated to be \$19,000/ton/day of MSW capacity in 1977; this includes no feed preparation or scrap recovery, as none is required for the incinerator. Because of the relatively small size of the units and labor intensity, they are assumed to be operational only 5 days per week. Debt amortization is 8% for 20 years, which is comparable to the 10% capital charge rate used in the waterwall system example. The disposal cost, including no credit for tipping fees, is estimated on this basis to be \$20.17/ton -- equivalent to about \$3.53/1000 lb of steam sold.*

* Assumes 5710 lb steam/ton of MSW.

TABLE 7-6

ESTIMATED ANNUAL OPERATING COST OF A
WATERWALL INCINERATOR
 (1000-ton/day Plant)

	<u>\$000/yr</u>	<u>\$/ton of MSW</u>	<u>\$/1000 lb Steam⁽¹⁾</u>
Capital Investment (1977 dollars)	32,600		
Annual Operating & Maintenance Costs			
Operating Labor	1,121	3.40	0.57
Maintenance Labor and Materials	1,195	3.62	0.60
Purchased Utilities	462	1.40	0.23
Miscellaneous	308	0.93	0.16
Residue Disposal	<u>297</u>	<u>0.90</u>	<u>0.15</u>
TOTAL	3,383	10.25	1.71
Annual Capital Charges (ACC)			
10%	3,260	9.88	1.65
18%	5,868	17.78	2.97
Total Revenue Required ⁽²⁾			
10% ACC	6,643	20.13	3.36
18% ACC	9,251	28.03	4.68
Credits			
Ferrous Metals	533	1.68	0.27
Total Revenue Required from Sale of Steam (excluding dumping fee)			
10% ACC	6,110	18.45	3.09
18% ACC	8,718	26.35	4.41

(1) Assumes about 1100 Btu/lb of steam at 67% efficiency from MSW to steam.

(2) "Total Revenue Required" is the annual cost of plant operation which must be reimbursed from plant income.

SOURCE: Stanford Research Institute,⁽³⁴⁾ updated to 1977 dollars by Arthur D. Little, Inc.

TABLE 7-7

ESTIMATED ANNUAL OPERATING COST OF A
MODULAR-CONTROLLED AIR INCINERATOR WITH STEAM RECOVERY

Fixed Capital Investment (\$000)		1,393		
Daily Plant Capacity (tons/day)		73.0		
Investment (\$/ton/day)		19,000		
<u>Annual Operating Costs</u>		<u>\$000/yr</u>	<u>\$/ton of MSW</u>	<u>\$/1000 lb steam</u>
Variable Costs				
Fuel Oil	- 8 gal/ton @ \$0.35/gal	56.0	2.80	0.48
Power	- 25 kWh/ton @ \$0.02/kWh	10.0	0.50	0.09
Residue	- 0.3 ton @ \$3.75/ton	22.6	1.13	0.20
Supplies		<u>4.0</u>	<u>0.20</u>	<u>0.04</u>
		92.6	4.63	0.81
Semi-Variable Cost				
Operating Labor	- 3 shifts, 7 men each @ \$5.00/hr	231.0	11.51	2.04
Labor Overhead	- 20% of Operating Labor	46.2	2.30	0.41
Administration	- 35% of Operating Labor	80.9	4.03	0.72
Maintenance	- 3% of Fixed Capital Investment	<u>41.8</u>	<u>2.09</u>	<u>0.37</u>
		399.9	19.93	3.54
Fixed Costs				
Amortization	- 20 years @ 8%	142.1	7.10	1.25
Insurance	- 1% of Fixed Capital Investment	<u>13.9</u>	<u>0.70</u>	<u>0.12</u>
		156.0	7.80	1.37
Total Revenue Required from Sale of Steam (excluding dumping fee)				
		648.5	32.36	5.72

SOURCE: Arthur D. Little, Inc., estimates, based on 1977 manufacturers' data, including Consumat Systems, Inc., Richmond, VA., Environmental Central Products, Inc., Charlotte, NC., and Kelley Company, Milwaukee, WI.

C. Resources

The relatively low availability of biomass and MSW resources in required quantities near energy-consuming (populated) areas may be a significant factor in deferring the broad commercialization of an energy-from-biomass industry. Farming itself is also an energy-intensive industry, but much of the energy required is in a form other than solid biomass (e.g., nitrogen fertilizers and liquid fuels for heavy farm equipment). Thus, the direct use of biomass as a generic energy source on farms is limited.

In the case of dedicated biomass plantations, the limitations of other natural resources, e.g., water and phosphorus, may be critical.

Stanford Research Institute has performed a comprehensive study of biomass systems for the Department of Energy.⁽³⁵⁾ From more than 1100 candidates, 15 were selected for detailed study on the basis of technical feasibility and were subjected to further analysis by an economic model. Based on expected market penetration, four systems indicated the greatest near-term commercialization potential:

<u>Biomass</u>	<u>Process</u>	<u>Product</u>
Wood and Low-Moisture Plants	Combustion	Steam
Wood and Low-Moisture Plants	Combustion	Cogeneration of Steam and Electricity
Wood and Low-Moisture Plants	Pyrolysis	Fuel Oil and Char
Manure and High-Moisture Terrestrial Crops	Anaerobic Digestion	Intermediate Btu Gas

Process modifications make possible additional products from these same biomass fuels, with somewhat lesser economic incentive under the cost assumptions used by SRI. However, these conclusions are framed in a generally competitive environment against conventional fuels and are not influenced by the particular character of a distributed energy system.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Lipinsky, E.S., et al. Systems Study of Fuels from Sugarcane, Sweet Sorghum, and Sugar Beets, Vol. IV: Corn Agriculture, Task 77. Final Report. Prepared by Battelle Columbus Laboratories for U.S. Energy Research and Development Administration, March 31, 1977. pp. 203 ff. NTIS Report No. BMI-1957A(v.4).
2. Lipinsky, E.S., et al. Systems Study of Fuels from Sugarcane, Sweet Sorghum, and Sugar Beets, Vol. II: Agricultural Considerations, Task 77. Final Report. Prepared by Battelle Columbus Laboratories for U.S. Energy Research and Development Administration, March 31, 1977. NTIS Report No. BMI-1957(v.2).
3. Jewell, W.J. "Energy, Agriculture and Waste Management." Proceedings of the 1975 Cornell Agricultural Waste Management Conference, Ithaca, N.Y., 1975.
4. Inman, R.E., et al. Silvicultural Biomass Farms, Vol. I: Summary Report. Prepared by MITRE Corporation for Energy Research and Development Administration, May 1977. pp. 62 ff. NTIS Report No. MTR 7347(v.1).
5. Burwell, C.C. "Solar Biomass Energy: An Overview of U.S. Potential." Science 199(4333):1041, March 10, 1978.
6. Prior, L.A. Land Availability, Crop Production and Fertilizer Requirements in the U.S. Washington, D.C.: Environmental Protection Agency, October 1975. EPA Report No. EPA/530/SW-166.
7. Alich, J.A., Jr., et al. An Evaluation of the Use of Agricultural Residues as an Energy Feedstock. Volumes 1 and 2. Report prepared by Stanford Research Institute for National Science Foundation, July 1976. NTIS Report Nos. PB 260 763 and PB 260 764.
8. Povich, M.J. "Fuel Farming." Chemtech 6(7):434, July 1976.
9. Alich, J.A., Jr., et al. Effective Utilization of Solar Energy to Produce Clean Fuel. Report prepared by Stanford Research Institute for National Science Foundation, June 1974. NTIS Report No. PB 233 956.
10. Inman, R.E., et al. Silvicultural Biomass Farms, Vol. IV: Site-Specific Production Studies and Cost Analyses. Report prepared by MITRE Corporation for Energy Research and Development Administration, May 1977. NTIS Report No. MTR 7347(v.4).
11. Howlett, K., et al. Silvicultural Biomass Farms, Vol. II: The Biomass Potential of Short Rotation Farms. Report prepared by MITRE Corporation for Energy Research and Development Administration, May 1977. NTIS Report No. MTR 7347(v.2).

REFERENCES (continued)

12. Ryther, J.H., et al. "Cultivation of Seaweeds for Hydrocolloids, Waste Treatment, and Biomass for Energy Conversion." Preprint. Proceedings of the IX International Seaweed Symposium, Santa Barbara, California, August 1977.
13. Wilson, E.H., et al. Special Topical Report on Sources and Systems for Aquatic Biomass as an Energy Resource. Report prepared by Dynatech Corporation for the U.S. Department of Energy, October 21, 1977. Dynatech Report No. 1679. pp. 206 ff.
14. CSO International, Inc. Cost Analysis of Microalgae Biomass Systems, Final Report: Design Assumptions and Engineering Plans for 100-Square Mile System. Report prepared for the U.S. Department of Energy, April 1978. pp. 98 ff. NTIS Report No. HCP/T1605-01.
15. Alich, J.A., et al. An Evaluation of the Use of Agricultural Residues as an Energy Feedstock - A Ten Site Survey, Vol. 2: Study Area Analysis. Report prepared by Stanford Research Institute for Energy Research and Development Administration, July 1977. pp. 404 ff. NTIS Report No. TID-27904/2.
16. Ellis, T.H. "The Role of Wood Residues in the National Energy Picture." Proceedings of the Forest Products Research Society Meeting on Wood Residue as an Energy Source, Denver, Colorado, September 3-5, 1975.
17. Hansen, P. Residential Paper Recovery: A Municipal Implementation Guide. Prepared by U.S. Environmental Protection Agency in cooperation with National Center for Resource Recovery, Inc., 1975. NTIS Report No. PB 259 454.
18. Resource Planning Associates. Waste Flow Characteristics and Resource Recovery. Prepared for Energy Research and Development Administration, October 1976. NTIS Report No. TID-27633.
19. Deardorff, D. "Direct Combustion Systems." Proceedings of the Forest Products Research Society Meeting on Wood Residue as an Energy Source, Denver, Colorado, September 3-5, 1975.
20. Jasper, M.T., et al. "Suspension Burning of Green Bark to Direct-Fired High-Temperature Kilns for Southern Pine Lumber." Proceedings of the Forest Products Research Society Meeting on Wood Residue as an Energy Source, Denver, Colorado, September 3-5, 1975.
21. Cronin, T., Public Relations Department, Burlington Electric Company, Burlington, Vermont. Personal communications. July 1979.

REFERENCES (continued)

22. Bentley, G.K. New England Rural Energy Sources - Wood, Small-Scale Hydro, Direct Solar and Wind - An Assessment of Near-Term Potential. Washington, D.C.: Energy Task Force of the New England Congressional Caucus, February 1979.
23. Resource Planning Associates, Inc. European Waste-to-Energy Systems: Case Study of Koersor, Denmark. Prepared for the Energy Research and Development Administration, June 1977. NTIS Report No. CONS/2103-3.
24. Resource Planning Associates, Inc. European Waste-to-Energy Systems, An Overview. Prepared for the Energy Research and Development Administration, June 1977. NTIS Report No. CONS/2103-6.
25. County Sanitation Districts of Los Angeles County. Report on Status of Technology in the Recovery of Resources from Solid Wastes. Los Angeles, California, January 1976.
26. Arthur D. Little, Inc. Opportunities for Regional Solid Waste Management. Report to the Regional Solid Waste Committee, Auburn, Maine, April 1975.
27. Arthur D. Little, Inc. Opportunities for Regional Solid Waste Management. Report to Minuteman Regional Refuse Disposal Planning Board, Bedford, Massachusetts, April 1975.
28. Arthur D. Little, Inc. An Analysis of Selected Solid Waste Disposal Alternatives for the Town of Acton. Prepared for the Town of Acton, Massachusetts, May 1975.
29. Self, C.R. Wood Heating Handbook. Blue Ridge Summit, Pennsylvania: TAB Books, 1977.
30. Irving, D. The Complete Book of Woodburning Stoves. New York: Drake Publishers, Inc., 1978.
31. Daniels, M.E. Fireplaces and Wood Stoves. New York: Bobbs-Merrill, 1977.
32. Harrington, G. The Wood-Burning Stove Book. New York: MacMillan Publishing Company Inc., 1977.
33. Bliss, C., et al. Silvicultural Biomass Farms, Vol. V: Conversion Processes and Costs. Report prepared by MITRE Corporation for Energy Research and Development Administration, May 1977. NTIS Report No. MTR 7347(v.5).

REFERENCES (continued)

34. Alich, J.A., et al. Program Definition for Fuels from Biomass. Prepared by Stanford Research Institute for the State of California Energy Resources Conservation and Development Program, 1976. SRI Project 5527.
35. SRI International. Mission Analysis for the Federal Fuels from Biomass Program, Vol. I: Summary and Conclusions. Report prepared for the U.S. Department of Energy, December 1978.

CHAPTER 8
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: SOLID FUELS DERIVED FROM BIOMASS</p> <p>DESCRIPTION: It can be advantageous to upgrade biomass fuels, particularly low-bulk-density wastes with significant quantities of oversized non-combustible materials. Concepts for recovering solid fuels from biomass are principally based on technologies now practiced for refuse-derived fuels (RDF). For the latter, scrap metals and glass can also be recovered.</p> <p>POTENTIAL USER CLASSES: Municipalities, utilities, large industrial complexes</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Commercial plants being built and operated for MSW* conversion</p>																							
TECHNICAL	<table style="width: 100%;"> <tr> <td style="width: 45%; vertical-align: top;"> <p>UNIT POWER OUTPUT CAPACITY: 10^6 Btu/hr) PRIMARY</p> <p>UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY</p> <p>AVERAGE EFFECTIVE CAPACITY FACTOR</p> <p>RANGE OF CAPACITY FACTORS</p> <p>EFFICIENCY (BTU OUT/BTU IN) (1)</p> <p>PRIMARY FUEL(S): MSW</p> <p>ALTERNATIVE FUEL(S): Cellulosic wastes and crops</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Where primary purpose is municipal waste conversion, shutdowns may be daily or weekly due to waste supply.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Refuse-derived fuel (RDF) can be used by utility</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</p> <p>SYSTEM:</p> </td><td style="width: 10%; vertical-align: top; text-align: center;"> <p>SECONDARY</p> <p>SECONDARY</p> </td><td style="width: 45%;"> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>To 200</td><td>To 500</td><td>To 1000</td></tr> <tr> <td>0-1.2</td><td>0-3.1</td><td>0-6.1</td></tr> <tr> <td>.7</td><td>same</td><td>same</td></tr> <tr> <td>.3 - .9</td><td>same</td><td>same</td></tr> <tr> <td>.65 - .8</td><td>same</td><td>same</td></tr> </tbody> </table> <p>AMOUNT NEEDED PER UNIT OUTPUT: Approximately 2 tons input per ton of fuel output</p> <p>IS SYSTEM READILY CONVERTIBLE? Yes</p> </td></tr> </table>			<p>UNIT POWER OUTPUT CAPACITY: 10^6 Btu/hr) PRIMARY</p> <p>UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY</p> <p>AVERAGE EFFECTIVE CAPACITY FACTOR</p> <p>RANGE OF CAPACITY FACTORS</p> <p>EFFICIENCY (BTU OUT/BTU IN) (1)</p> <p>PRIMARY FUEL(S): MSW</p> <p>ALTERNATIVE FUEL(S): Cellulosic wastes and crops</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Where primary purpose is municipal waste conversion, shutdowns may be daily or weekly due to waste supply.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Refuse-derived fuel (RDF) can be used by utility</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</p> <p>SYSTEM:</p>	<p>SECONDARY</p> <p>SECONDARY</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>To 200</td><td>To 500</td><td>To 1000</td></tr> <tr> <td>0-1.2</td><td>0-3.1</td><td>0-6.1</td></tr> <tr> <td>.7</td><td>same</td><td>same</td></tr> <tr> <td>.3 - .9</td><td>same</td><td>same</td></tr> <tr> <td>.65 - .8</td><td>same</td><td>same</td></tr> </tbody> </table> <p>AMOUNT NEEDED PER UNIT OUTPUT: Approximately 2 tons input per ton of fuel output</p> <p>IS SYSTEM READILY CONVERTIBLE? Yes</p>	1977	1985	2000	To 200	To 500	To 1000	0-1.2	0-3.1	0-6.1	.7	same	same	.3 - .9	same	same	.65 - .8	same	same
<p>UNIT POWER OUTPUT CAPACITY: 10^6 Btu/hr) PRIMARY</p> <p>UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY</p> <p>AVERAGE EFFECTIVE CAPACITY FACTOR</p> <p>RANGE OF CAPACITY FACTORS</p> <p>EFFICIENCY (BTU OUT/BTU IN) (1)</p> <p>PRIMARY FUEL(S): MSW</p> <p>ALTERNATIVE FUEL(S): Cellulosic wastes and crops</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Where primary purpose is municipal waste conversion, shutdowns may be daily or weekly due to waste supply.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Refuse-derived fuel (RDF) can be used by utility</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</p> <p>SYSTEM:</p>	<p>SECONDARY</p> <p>SECONDARY</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>To 200</td><td>To 500</td><td>To 1000</td></tr> <tr> <td>0-1.2</td><td>0-3.1</td><td>0-6.1</td></tr> <tr> <td>.7</td><td>same</td><td>same</td></tr> <tr> <td>.3 - .9</td><td>same</td><td>same</td></tr> <tr> <td>.65 - .8</td><td>same</td><td>same</td></tr> </tbody> </table> <p>AMOUNT NEEDED PER UNIT OUTPUT: Approximately 2 tons input per ton of fuel output</p> <p>IS SYSTEM READILY CONVERTIBLE? Yes</p>	1977	1985	2000	To 200	To 500	To 1000	0-1.2	0-3.1	0-6.1	.7	same	same	.3 - .9	same	same	.65 - .8	same	same				
1977	1985	2000																						
To 200	To 500	To 1000																						
0-1.2	0-3.1	0-6.1																						
.7	same	same																						
.3 - .9	same	same																						
.65 - .8	same	same																						
ECONOMIC	<table style="width: 100%;"> <tr> <td style="width: 55%; vertical-align: top;"> <p>TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day/ input)</p> <p>AVERAGE UNIT O&M: (\$/10^6 Btu fuel output) (11)</p> <p>CONSTRUCTION PERIOD:</p> </td><td style="width: 45%;"> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>44,800 (11)</td><td>same</td><td>same</td></tr> <tr> <td>1.87</td><td>same</td><td>same</td></tr> <tr> <td>2 years</td><td>same</td><td>same</td></tr> </tbody> </table> </td></tr> </table>			<p>TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day/ input)</p> <p>AVERAGE UNIT O&M: (\$/10^6 Btu fuel output) (11)</p> <p>CONSTRUCTION PERIOD:</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>44,800 (11)</td><td>same</td><td>same</td></tr> <tr> <td>1.87</td><td>same</td><td>same</td></tr> <tr> <td>2 years</td><td>same</td><td>same</td></tr> </tbody> </table>	1977	1985	2000	44,800 (11)	same	same	1.87	same	same	2 years	same	same							
<p>TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day/ input)</p> <p>AVERAGE UNIT O&M: (\$/10^6 Btu fuel output) (11)</p> <p>CONSTRUCTION PERIOD:</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>44,800 (11)</td><td>same</td><td>same</td></tr> <tr> <td>1.87</td><td>same</td><td>same</td></tr> <tr> <td>2 years</td><td>same</td><td>same</td></tr> </tbody> </table>	1977	1985	2000	44,800 (11)	same	same	1.87	same	same	2 years	same	same											
1977	1985	2000																						
44,800 (11)	same	same																						
1.87	same	same																						
2 years	same	same																						
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Requires buildup of a new industry</p> <p>GEOGRAPHIC LIMITATIONS: For MSW, should be near population and industrial centers</p> <p>ENVIRONMENTAL EFFECTS: Solid residue of significantly less volume than incoming wastes</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: None</p>																							
COMMENTS	<p>(1) Conversion to fuel only; efficiency for subsequent burning is 0.7-0.9, depending on size and type of equipment.</p> <p>(11) Equivalent to \$0.14/Btu/hr output.</p> <p>(111) Credits for tipping fees and scrap materials are likely, but are not included in this O&M cost estimate; see page 8-8 for a discussion of possible credits.</p> <p>* MSW = Municipal Solid Waste.</p>																							

FE

CHAPTER 8

SOLID FUELS DERIVED FROM BIOMASS

Section 8.1: Introduction

Most of the activity devoted to recovering the energy values of biomass materials in the form of combustible solid fuels has been limited to wood residues and municipal solid waste (MSW).

Generally, pulp and paper plants and sawmills are located close to the source of raw material and are relatively remote from major population centers. As a result, where energy recovery is feasible, most wood wastes generated by these plants are burned by the plant operators to produce steam for electric power generation and process needs, rather than being transported significant distances to be burned by other energy consumers. In some cases, wood pellets or synthetic fireplace logs are produced, if there is an excess of wood wastes near an appropriate market.

MSW, on the other hand, is generated over wider areas in industrial and population centers where energy needs are large and diverse. Many commercial firms and municipalities have proposed resource recovery systems as an alternative to direct incineration and landfill. The purpose of resource recovery is the sale and recycle of values contained in the MSW in order to offset, at least partially, the costs of collecting the waste and disposing of its residue. Among the recoverable resources are:

- energy-producing materials or fuels,
- ferrous metals,
- nonferrous metals, principally aluminum, and
- glass.

Solid fuels can be produced in shredded, powdered, or fibrous form, using wet or dry processing. Most solid fuels are processed by shredding in one or two stages, magnetic separation for ferrous metal recovery, and one or more classification steps to remove non-combustibles. Drying may be included.

Powdered fuel is produced by a proprietary dry process (Combustion Equipment Associates, Inc.'s Eco-Fuel®-II process).⁽¹⁾ In this process a finely divided, high-bulk-density, dry, low-ash fuel is produced. Ferrous metals are recovered, and processing for recovery of other materials can be added.

Fibrous fuel is produced by Black-Clawson⁽²⁾ in its proprietary wet process based on wood pulping technology. This process was originally developed to recover fibers from MSW, but because of the limited markets for the low-quality, low-value fibers, Black-Clawson now plans to market the fibers as a fuel. This process also recovers the ferrous and non-ferrous metals and glass.

Solid-fuel systems are offered by a number of system suppliers and architect-engineers. Most dry systems make use of similar equipment that has been well proven in other industries, although its use in processing MSW is new.

Since most commercial biomass-based solid fuels are derived from municipal solid waste, the technology discussion emphasizes this source. The technology can be adapted to accept other biomass forms where appropriate, including both agricultural products grown specifically for their energy values and residues from agricultural production for other purposes.

Section 8.2: Technical Discussion

A. Terrestrial Biomass Crops and Residues

The conversion of biomass products and residues has not been widely considered. The technology for size reduction of the terrestrial biomass materials is readily transferrable from that developed for the MSW resource recovery plants described below. The basic difference lies in collection and preprocessing of the materials. Agricultural residues are generally more dispersed than MSW which is usually concentrated in urban areas. Agricultural commodities and residues are generally more homogenous

than MSW, which requires several preprocessing steps, such as the recovery and removal of recyclable metals and glass. Overall thermal efficiency, however, would probably be somewhat lower than that for MSW because of the lower moisture content and lesser need for drying the latter.

B. MSW

A refuse recovery facility is designed to produce a number of products of sufficient quality to be sold as acceptable items of commerce. Equipment to produce quality byproducts, e.g., ferrous metals, is not directly relevant to a discussion of recovery of energy values, but noted to the extent that the equipment is required to "purify" the solid fuel to a reasonable quality (low ash content). Figure 8-1 shows the schematic process flow diagram for a conceptual resource recovery facility.⁽³⁾

In this flowsheet, MSW is fed to a first-stage hammermill. The underflow from the hammermill is fed onto a conveyor which passes under a magnetic separator. The ferrous scrap which is removed is low grade because it is contaminated with organics. Further processing can clean this scrap and enhance its value.

The shredded material is discharged from the conveyor belt into a trommel (or screen) which removes a fraction of the glass and dirt. The discharge from the trommel enters a second hammermill where the size of the shredded material is further reduced. From the second hammermill the material passes into a second trommel to remove additional glass and dirt. The glass and dirt removed from the two trommels would contain about 50% organics, would be of no value without further processing, and would be suitable only for disposition in a sanitary landfill. The shredded material from the second trommel passes into an air classifier. The light fraction from the air classifier is discharged into a surge bin and fed to a pellet mill from which the pellets are discharged to a fuel storage area. This is the clean fuel portion of the MSW.

SOURCE: Reference 3.

FIGURE 8-1 RESOURCE RECOVERY SCHEMATIC FLOW DIAGRAM

The heavy fraction from the air classifier is fed to a device which separates the salable non-ferrous metals from the other heavy disposable high-moisture residues. The estimated solid-fuel product yield of the process is 7.2×10^6 Btu/ton of MSW,⁽³⁾ equivalent to about an 80% energy yield on the basis of MSW at 4500 Btu/lb.

The pellet mills in the process are a proprietary application of Systems Resource Recovery (SRR).⁽³⁾ They could be omitted and the shredded organic fraction sold directly for its energy value; the energy yield would be slightly improved. The drawback of this approach would be the relatively low bulk density of the product which would add to the costs of storage and transportation.

An alternative approach is the proprietary development of Combustion Equipment Associates and Arthur D. Little, Inc.,⁽²⁾ which produces a dry powder of high bulk density known as Eco-Fuel[®]-II. The CEA/ADL process uses an elevated temperature ball mill to reduce the particle size of the product to a powdered state. A chemical addition step precedes the ball mill to embrittle the cellulosic material and minimize the electrical energy requirements of the ball mill.

Table 8-1 summarizes the properties of solid fuels derived from refuse. Table 8-2 shows the components of energy recovery from use in the Eco-Fuel[®]-II process. In all, a net recovery of 83% of that energy available in the feed MSW is estimated as net recoverable solid fuel.

The CEA/ADL process is being commercialized. One plant that will process 25 tons of MSW is now operating at East Bridgewater, Massachusetts. Another that will process 100 tons per hour is in shake-down at Bridgeport, Connecticut, and started up in mid-1978. Other plants are planned for Newark, New Jersey, and New York City.

Section 8.3: Economics Discussion

Malcolm Pirnie, Inc., has estimated the cost of converting 1200 tons per day of municipal solid waste to a powdered fuel.⁽⁴⁾ Including the cost of recovering both ferrous and aluminum scrap materials as

TABLE 8-1

PROPERTIES OF REFUSE-DERIVED FUELS

	<u>Eco-Fuel[®] -II</u>	<u>Shredded Fuels</u>	
		<u>Dried (1)</u>	<u>Undried</u>
Combustibles % by weight	88.6	77.0	50-60
Ash % by weight	9.4	13.0	20
Moisture % by weight	2.0	10.0	20-30
	<u>100.0</u>	<u>100.0</u>	<u>100.0</u>
Higher Heating Value (Btu/lb)	7,800	6,800	~ 5,000
Average Particle Size (inches)	0.0006	0.75 ⁽²⁾	2-3
Bulk Density (lbs/ft ³)	30-35	3-5	4-6
Storage Life	Indefinite	Indefinite	Variable - Two Days Maximum

(1) Dried shredded fuel permits additional ash removal which is included.

(2) Two-stage shredding.

SOURCE: Arthur D. Little, Inc., analysis of products from pilot scale and commercial equipment.

TABLE 8-2

OVERALL ENERGY BALANCE FOR ECO-FUEL®-II PROCESS

	<u>10⁶ Btu/Ton of MSW</u>
Total Energy Available in MSW	10.0
Energy Recovered as Salable Fuel 0.52 ton of fuel/ton of MSW X 15.0x10 ⁶ Btu/ton of fuel	7.8
Energy Used in the Process Electricity - 30 kWh per ton of MSW X 10,000 Btu per kWh	0.3
Diesel Fuel - 0.2 gal/ton of MSW X 140,000 Btu/gal	0.03
Net Energy Produced	7.47
Gross Heat Efficiency: $\frac{\text{energy in product}}{\text{energy in feed}} =$	$\frac{7.8}{10.0} = 78.0\%$
Net Heat Efficiency: $\frac{\text{net energy produced}}{\text{energy in feed}} =$	$\frac{7.5}{10.0} = 75.0\%$

SOURCE: Reference 2.

byproducts, a plant of this type was estimated to require a capital investment in 1977 of \$53.8 million. This is equivalent to \$44,800/ton/day of MSW input, or \$0.14/Btu/hr of output assuming an energy content of 10×10^6 Btu/ton of MSW and a net energy efficiency to powdered fuel of 75% (Table 8-2).

The total estimated annual O&M costs including all labor and overhead, maintenance, insurance, a management fee, and other associated costs are \$6.4 million, equivalent to \$28.10/ton of fuel output or \$1.87/ 10^6 Btu of fuel output. Credits for byproduct metals reduce the net cost of operating the resource recovery facility to \$26.40/ton (or \$1.76/ 10^6 Btu) of fuel output. ⁽⁴⁾ These costs would be further offset if a disposal (or tipping) fee were charged for the incoming MSW consistent with the cost of alternative disposal methods in the area which are usually in the range \$5-20/ton of MSW, equivalent to \$0.68 - 2.70/ 10^6 Btu of solid fuel output.

Depending on the nature of the MSW feed, it is expected that the cost of producing shredded MSW is lower than that of Eco-Fuel[®]-II or refuse-derived pellets because of the differences in capital costs. However, the ultimate choice among the three forms of solid fuel must be made on the basis of a trade-off between product quality (principally bulk density as it relates to storage and transportation), product value, and plant costs.

Section 8.4: Limitations

The principal limitation on the wide-scale implementation of solid-fuels-from-waste technologies is cost. If inexpensive options are available for waste disposal, such as a local low-cost landfill, it may be difficult to justify a resource recovery facility on economic grounds, unless the entire system and related costs are carefully examined for a true comparison.

Another potential limitation, which is a function of the MSW composition, is the degree to which impurities in the solid fuel would foul the combustion and boiler equipment or pollute the air. The ash

contained in the refuse-derived fuel would create excessive fly ash emissions if the equipment were not able to process impurities. (5)

Chlorides present in plastics can contribute to air emissions and may be a source of corrosion of boiler tubes. Further species, such as sodium, may lower the fusion temperature of the ash and contribute to fouling of boiler tubes.

To date, operating experience with these fuels has been limited and the technology cannot be considered fully commercial. Detailed operating data can alter the above estimates and potentially slow the development of future large-scale plants.

A final limitation is that of the availability of MSW in quantities and continuity sufficient to represent a significant energy source. (A discussion of MSW availability is presented in Chapter 7.) MSW itself represents a steady product of urban areas, but other low-moisture terrestrial biomass products, or byproducts, are available only seasonally or must be collected from extensive areas. The resultant transportation and storage costs may represent a decisive factor in the economics of such a system.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Chemical Profiles. New York: Schnell Publishing Company, Inc., 1977.
2. Beningson, R.M., et al. "Production of Eco-Fuel[®] II from Municipal Waste, CEA/ADL Process." American Institute of Chemical Engineers 80th National Meeting, Boston, Massachusetts, September 7-10, 1975.
3. Systems Resource Recovery. Report to Southern Mid-Coast Regional Planning Commission. Long Beach, California, September 1974.
4. Malcolm Pirnie, Inc. Resource Recovery and Solid Waste Management Program. Summary Report for Westchester County, New York, Department of Public Works, December 1977.
5. Arthur D. Little, Inc. Opportunities for Regional Solid Waste Management. Report to Minuteman Regional Refuse Disposal Planning Board, Bedford, Massachusetts, April 1975.

SUPPLEMENTARY BIBLIOGRAPHY

1. Franklin, M. A. "The Preparation of Fuels and Feedstocks from Municipal Solid Waste." Proceedings of a Workshop Held at New Orleans, Louisiana on February 8-10, 1977. Sponsored by the Municipal Environmental Research Laboratory, Cincinnati, Ohio, December 1977. NTIS Order No. PB 279 077.
2. Weinstein, N. J. Municipal-Scale Thermal Processing of Solid Wastes. Report prepared by RECON Systems, Inc. for the Environmental Protection Agency, 1977. NTIS Report No. PB 263 396.
3. Wilson, E., et al. Engineering and Economic Analysis of Waste to Energy Systems; Final Report, April 1975 - June 1977. Report prepared by Ralph M. Parsons Company for the Industrial Environmental Research Laboratory, Cincinnati, Ohio, May 1978. NTIS Report No. PB 285 797.
4. County Sanitation Districts of Los Angeles County, California. Status of Technology in the Recovery of Resources from Solid Wastes. Los Angeles, January 1976.
5. Resource Planning Associates, Inc. Waste Flow Characteristics and Resource Recovery. Report prepared for Energy Research and Development Administration, October 1976. NTIS Report No. TID 27633.
6. Drobny, N. L. et al. Recovery and Utilization of Municipal Solid Waste: A Summary of Available Cost and Performance Characteristics of Unit Processes and Systems. Report prepared by Columbus Laboratories of Battelle Memorial Institute for the Environmental Protection Agency, 1971. NTIS Report No. PB 204 922.

CHAPTER 9
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: ENERGY FROM BIOMASS VIA BIOCONVERSION PROCESSES</p> <p>DESCRIPTION: Biomass forms are broken down enzymatically or microbially to methane gas or ethyl alcohol for use as fuels. Includes anaerobic digestion, recovery of landfill gas, fermentation of carbohydrates and sugars, and hydrolysis of cellulose to produce sugars.</p> <p>POTENTIAL USER CLASSES: Municipalities, utilities, pulp and paper mills, agricultural groups</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Mostly commercial. Some research ongoing to improve efficiencies and expand range of feedstocks.</p>																																			
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (10⁶ Btu/hr) PRIMARY (i)</td><td>[A]2.4-63.6; [B]12</td><td>same</td><td>same</td></tr> <tr> <td>(ii)</td><td>[C]105-525; [D]NA*</td><td>[C]same; [D]105-525</td><td>same</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10⁹ Btu) PRIMARY (i)</td><td>[A]17-446; [B]84</td><td>same</td><td>same</td></tr> <tr> <td>(ii)</td><td>[C]736-3679; [D]NA</td><td>[C]same; [D]736-3679</td><td>same</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.8</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.50-.95</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.15-.70</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Manure, crop residue AMOUNT NEEDED PER UNIT OUTPUT: Approx. 0.2 ton/10⁶ Btu of product</p> <p>ALTERNATIVE FUEL(S): IS SYSTEM READILY CONVERTIBLE? Yes, from one primary fuel to another</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Continuous except for options where primary purpose is waste disposal (e.g., MSW**); shutdown can be daily or weekly depending on waste supply.</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER?</p> <p>TECHNICALLY PRACTICAL? Yes, but small contribution to any utility load</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? SYSTEM: Methane -- connect to in-place natural gas distribution Alcohol -- storable, as any other liquid fuel</p>					1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (10 ⁶ Btu/hr) PRIMARY (i)	[A]2.4-63.6; [B]12	same	same	(ii)	[C]105-525; [D]NA*	[C]same; [D]105-525	same	UNIT ANNUAL ENERGY OUTPUT: (10 ⁹ Btu) PRIMARY (i)	[A]17-446; [B]84	same	same	(ii)	[C]736-3679; [D]NA	[C]same; [D]736-3679	same	AVERAGE EFFECTIVE CAPACITY FACTOR:	.8	same	same	RANGE OF CAPACITY FACTORS:	.50-.95	same	same	EFFICIENCY (BTU OUT/BTU IN):	.15-.70	same	same
	1977	1985	2000																																	
UNIT POWER OUTPUT CAPACITY: (10 ⁶ Btu/hr) PRIMARY (i)	[A]2.4-63.6; [B]12	same	same																																	
(ii)	[C]105-525; [D]NA*	[C]same; [D]105-525	same																																	
UNIT ANNUAL ENERGY OUTPUT: (10 ⁹ Btu) PRIMARY (i)	[A]17-446; [B]84	same	same																																	
(ii)	[C]736-3679; [D]NA	[C]same; [D]736-3679	same																																	
AVERAGE EFFECTIVE CAPACITY FACTOR:	.8	same	same																																	
RANGE OF CAPACITY FACTORS:	.50-.95	same	same																																	
EFFICIENCY (BTU OUT/BTU IN):	.15-.70	same	same																																	
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/Btu/hr) (i)</td><td>[A]0.063; [B]0.071</td><td>same</td><td>same</td></tr> <tr> <td>(ii)</td><td>[C]0.15; [D] NA</td><td>[C]same; [D]0.43</td><td>same</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/10⁶ Btu) (i)</td><td>[A]1.6-16.3; [B]0.79</td><td>same</td><td>same</td></tr> <tr> <td>(ii)</td><td>[C]4.3; [D] NA</td><td>[C]4.3; [D]7.55</td><td></td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>2 mos - 3 yrs</td><td></td><td></td></tr> </tbody> </table>					1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/Btu/hr) (i)	[A]0.063; [B]0.071	same	same	(ii)	[C]0.15; [D] NA	[C]same; [D]0.43	same	AVERAGE UNIT O&M: (\$/10 ⁶ Btu) (i)	[A]1.6-16.3; [B]0.79	same	same	(ii)	[C]4.3; [D] NA	[C]4.3; [D]7.55		CONSTRUCTION PERIOD:	2 mos - 3 yrs										
	1977	1985	2000																																	
TOTAL INSTALLED UNIT CAPITAL COST: (\$/Btu/hr) (i)	[A]0.063; [B]0.071	same	same																																	
(ii)	[C]0.15; [D] NA	[C]same; [D]0.43	same																																	
AVERAGE UNIT O&M: (\$/10 ⁶ Btu) (i)	[A]1.6-16.3; [B]0.79	same	same																																	
(ii)	[C]4.3; [D] NA	[C]4.3; [D]7.55																																		
CONSTRUCTION PERIOD:	2 mos - 3 yrs																																			
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Production -- small Distribution -- large, based on existing distribution systems for natural gas and liquid fuels</p> <p>GEOGRAPHIC LIMITATIONS: Resources may be remote from energy loads</p> <p>ENVIRONMENTAL EFFECTS: Unconventional solid residues are significant. Products are very clean fuels.</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Ethyl alcohol -- regulated (taxed) by Treasury Dept.</p>																																			
COMMENTS	<p>(i) [A] Methane-digestion; [B] landfills.</p> <p>(ii) [C] Ethanol from grain; [D] cellulose.</p> <p>* NA = Not Applicable.</p> <p>** MSW = Municipal Solid Waste.</p>																																			

CHAPTER 9

ENERGY FROM BIOMASS VIA BIOCONVERSION PROCESSES

Section 9.1: Introduction

Fermentation is a general term referring to a group of processes whereby microbial activity under controlled conditions is used to transform organic material into desired end products. In the context of DES, the desired end products are substances that can be used as fuels for the purpose of generating electrical or motive power, or for space or domestic hot-water heating.

Biomass raw materials generally considered suitable for biological conversion into fuels include agricultural and maricultural crops, crop wood and feedlot residues, sewage sludge, and municipal solid waste. The most suitable fuel (in terms of ease of production and already established fuel markets) that can be produced from these materials by fermentation is methane gas.

Generally, only biomass having a high sugar or starch content can be converted directly into ethyl alcohol by anaerobic fermentation. In this specific type of fermentation process, yeast cells feed upon the biomass and convert the sugars or hydrolyzed starches into ethyl alcohol by means of a series of complex biochemical reactions. Because the biomass must have a high sugar or starch content, the primary feedstock for the production of ethyl alcohol has traditionally been edible crops (such as grains, sugar cane molasses, sugar beet molasses, and fruits) rather than crop or wood residues.

Section 9.2: Technical Discussion

A. Methane

1. Anaerobic Digestion of Animal Residues and Aquatic Biomass

Anaerobic digestion is an attractive process for converting biomass residues into fuel because it is a relatively simple and well understood process that can accept a wide variety of organic waste materials.

Briefly, anaerobic digestion is the decomposition of organic materials by micro-organisms, in the absence of oxygen, to carbon dioxide and methane. The decomposition occurs in two steps: (1) the breakdown of the organic matter to organic acids (mainly acetic acid) by one type of micro-organism, and (2) the conversion of these acids to methane and carbon dioxide by another type of micro-organism. The second step usually proceeds more slowly than the first.⁽¹⁾ The overall reaction is assumed to be:⁽¹⁾

Most biomass has a high cellulose content. The anaerobic digestion of cellulose $(C_6H_{10}O_5)_n$ would produce carbon dioxide and methane in equal volumetric proportion. The complete digestion of 1 pound of cellulose would yield 14.1 cubic feet of dry gas* at 60°F, which would have a heating value of 505 Btu/ft³.⁽¹⁾

Gas generation is often calculated on the basis of the volatile solids content of the feed which is quantified as the weight of solids that is lost from a sample when it is heated to and held at 600°C. The volatile solids are that fraction which is generally amenable to attack by micro-organisms. One pound of volatile solids having the general chemical composition of $C_6H_{8.9}O_{4.1}$ will theoretically require 9.212 pounds of water and will provide 0.875 pound of carbon dioxide and 0.337 pound of methane.

In practice, the degree of conversion is much less than 100% and the gas composition will vary somewhat. The degree of conversion usually ranges from 25-70% (equivalent to gas production rates of 3.5 to 9.9 ft³/pound of biomass).^(2,3) In addition to the specific nature of the feed, factors that influence the degree of conversion include temperature, degree of mixing, residence time, pH, solid concentrations, and the amount of nutrients and toxic materials.

Usually, the gas composition will range from 40-60% methane by volume, with carbon dioxide being the other major component. The prin-

* Containing approximately 50% methane.

cipal impurity present in small concentration is hydrogen sulfide, which is formed from the small amount of sulfur contained in most biomass wastes. Hydrogen sulfide is of concern because of its ability to poison catalysts (or fuel cell electrolytes) and its corrosive action on many metallic surfaces.

The digestion process is relatively simple in terms of physical equipment -- a digester, which is an appropriately sized agitated tank, to which water and biomass are added; dewatering and/or drying equipment, to reduce the mass and volume of the digested residue prior to disposal; and often gas cleaning and storage facilities. (3,4,5)

The anaerobic digestion of biomass materials has been studied by a number of researchers. (2,6,7,8,9) Presently, there is a considerable amount of variation in the reported values of gas production by type of material. Most likely these differences are caused by inconsistency in the basis for reporting results. Factors which importantly influence the degree of conversion are temperature, residence time, agitation, and the volatile solids content of the biomass waste. Data on these parameters are not always completely documented, making correlations between references difficult. However, sufficient data are available for the preparation of preliminary designs and cost estimates for digestion systems.

a. Temperature

Temperature has a strong influence on both the rate of gas production and the degree of conversion of biomass to gas. (6,7,8,) As an example, with a given retention time, say 20 days, an anaerobic digester operating at a temperature of about 130°F will produce gas at a rate which is generally three times that of a digester operated at 60°F. (6) The relationship between temperature and rate of gas generation is somewhat different in different temperature regimes. (1,10) Mesophillic microorganisms are most active at temperatures below 110°F and have a maximum activity at about 94°F. Above 110°F thermophillic microorganisms are most active and have a maximum activity at about 135°F. The gas production rate falls off quite rapidly when the temperature exceeds 135°F. (6)

b. Retention Time

Retention time also has a large influence on the degree of conversion.^(6,7) At lower temperatures, digestion is still proceeding at a significant rate after 20 days, and many systems have been built which provide more than 50 days' residence time. At elevated temperature, digestion is nearly complete in 20 days. The optimum residence time for a particular system would be determined by balancing the value and availability of the biomass waste and cost of the digester.

c. Degree of Agitation

The degree of agitation also has a large influence on the degree of conversion at all temperatures. Systems have been operated with continuous agitation,^(6,7,9) intermittent agitation,⁽⁹⁾ and no agitation.^(2,4,5) Continuous agitation can double the degree of conversion relative to no agitation. The disadvantage is that the agitation consumes power and will increase operating costs. Agitation can be provided by mechanical mixers or by gas recirculation using a compressor and a suitable static mixing device.

d. Solids Concentration

The solids concentration of the slurry being digested is also important. Since the nonvolatile solids are essentially inert materials which do not influence the digestion reactions, the solid concentration is usually expressed in terms of the volatile solids, which for manure and crop residues are generally about 70% and 90%, respectively.^(2,5,11,12)

e. pH

The preferred pH range for digestion is in the range of 6.6 to 7.6.^(1,2) Normally, if no control is provided, the pH falls (becomes acidic) because CO_2 forms bicarbonate by reaction with the hydroxyl ion.⁽³⁾ Alkaline materials, such as limestone, lime, or soda ash, can be used to control the pH by neutralizing or buffering this tendency. This condition, which favors the reaction and/or dissolution of CO_2 , tends to increase the concentration of methane in the gas-phase product.

f. Nutrients

The micro-organisms require nitrogen, phosphorus, and some trace elements for optimum activity.^(1,2,3,5) Generally, animal wastes contain most of these nutrients. Plant wastes may not contain all of them. Nutrients, particularly nitrogen, may have to be added for optimum activity.

g. Toxic Materials

A number of toxic substances must be excluded from the process because they destroy the micro-organisms.^(1,2,3) Among these are oxygen, high concentrations of salts, ammonia, sulfides, and toxic organics, and low concentrations of the soluble heavy metal ions, such as copper, nickel, zinc, and hexavalent chromium.

2. Methane from Landfills

Solid-waste disposal sites are a potential source of energy in the form of a methane-containing gas stream which can be captured via strategically located wells within the site. Three ongoing projects in California are typical of such operations.^(13,14,15) The chemistry of the decomposition of biomass materials is the same as that described above in Section 9.2A.1. The principal difference between the two techniques is that the environmental conditions of the landfill are not practically controllable. Therefore, yields, production rates, and other parameters of interest cannot be controlled or optimized.

A landfill gas-recovery facility would typically include several wells, a piping system to carry the collected gas to a gas purification system, and the purification system. The depth of the wells and rate of gas removal are limited by the allowable rate of air infiltration since infiltration dilutes the product gas and lowers its value.

The purification system is conventional and uses sorbents for removal of CO₂ and water from the raw gas.⁽¹³⁾ A compressor is usually required to withdraw the gas through the wells, into the treatment system, and eventually into a gas distribution network or to a captive user. At City of Industry, California, it is anticipated that about 400 ft³/min

of landfill gas (50% methane) can be sustained for up to 15 years.⁽¹⁴⁾ This is equivalent to about 12×10^6 Btu/hr. For comparison, the output from Mountain View, California, is projected at about 11×10^6 Btu/hr.⁽¹³⁾

B. Ethyl Alcohol - Fermentation of Biomass Crops and Residues

The basic reaction in the production of ethyl alcohol by fermentation is the conversion of sugars to ethyl alcohol by the microbial activity of yeast. Alcohol-tolerant yeast strains of Saccharomyces cerevisiae are usually used. They convert hexose sugars, such as glucose, fructose, sucrose, mannose, and galactose, to ethyl alcohol and carbon dioxide, theoretically yielding 51% and 49% by weight, respectively, as expressed by the equation:⁽¹⁶⁾

Organic materials, such as molasses, that contain fermentable sugars can be fermented directly, merely by mixing with water, adding yeast and nutrients, and adjusting environmental conditions such as pH and temperature. After alcohol accumulates to a sufficient concentration, the fermented mash is distilled.⁽¹⁶⁾

When ethyl alcohol is produced from grain, an additional step is required because none of the commercial yeasts is capable of fermenting starch directly. The grain must first be milled, mixed with water, and then cooked to hydrate and gelatinize the starch into a mash. Malt or mold enzyme preparations are added to enzymatically convert the mash into fermentable sugars. The resultant liquor is fermented into alcohol using yeast. The unconverted materials, referred to as distillers' dried grains, are a protein-rich byproduct, readily marketed as an animal feed.

While the production of ethyl alcohol from sugar- and starch-containing food crops dates back many centuries, ethyl alcohol production from biomass residues involves relatively new technology and is still the subject of research. The main problem is the conversion of the biomass into sugars that can be fermented by yeast. The cellulose in many plants is difficult to break down because of its crystalline nature and because

in many plants (particularly trees) it is bound into a matrix of lignin, a substance particularly resistant to microbial degradation. A number of processes are available for the degradation of cellulosic materials into sugars. These are briefly described in the following paragraphs.

Acid Hydrolysis. It has been known for many years⁽¹⁷⁾ that sulfuric acid can hydrolyze cellulose to glucose when the mixture is heated to about 130°C under pressure. The solution must be neutralized to allow the growth of yeast when inoculated. The process has drawbacks, including: extensive pretreatment (size reduction and heating) of the biomass material; high acid costs; the need for corrosion-resistant, pressurized equipment; and the pollution problems associated with the disposal of moderately concentrated salt solutions from the neutralization step. Convesse, et al.⁽¹⁸⁾ have noted that a promising area for improvement of the process would be the development of a plug flow reactor. The improvements would be realized in terms of higher sugar yields and greater heat conservation.

Enzymatic Saccharification. It is generally recognized by researchers in this area that the conversion of cellulosic material into sugars by enzymatic action is a more promising process because of its efficiency at low concentrations under mild conditions of temperature and pH. A conceptual enzymatic saccharification process is that of Wilke.⁽¹⁹⁾ The cellulose material is first pulverized, heated and sterilized, and cooled. It is then fed to a series of three mixer-filters where it countercurrently contacts the product sugar solution to recover about 95% of the enzyme. The solids and recovered enzyme then pass to the five-stage agitated digester where they are held for 40 hours at 45°C at a solid/liquid ratio of 1/20. The sugar concentrates to a level of about 4% under these conditions. The makeup enzyme is produced in a biosynthesis system consisting of a growth fermentor and several induction fermentors where the fungus Trichoderma viride⁽²⁰⁾ and a medium consisting of product sugars, protein, and minerals is employed. Spent solids from the hydrolyzer system are utilized in a boiler to produce the necessary process heat for both the hydrolyzation and the subsequent alcohol fermentation plant.

To apply the above described hydrolysis technologies to the organic fraction of MSW, one would preprocess the MSW for the removal of inorganic materials which may be recyclable. The purpose would be to maximize operational control of the hydrolysis process, to minimize the size of the equipment, and to retain the inorganics in a relatively dry state. The chemistry of the technology would be unchanged. In fact, some of the technology as described above has been developed using newsprint as the cellulose source.

Ethyl alcohol from biomass is enjoying substantial growth as a fuel, particularly in automotive use.^(21,22,23) Gasohol, a mixture of 10% ethyl alcohol in gasoline, can be burned in internal combustion engines with no changes to the carburetor or other engine components and with no substantial change in mileage performance. There is, however, modest octane benefit when ethyl alcohol is added to most gasoline blends and gasohol is often able to compete as a premium fuel. Most of the ethyl alcohol being produced for gasohol comes from corn processed in conventional plants originally designed to produce beverage-grade alcohol.

The Archer-Daniels-Midland Company, currently the nation's largest producer of ethyl alcohol for fuel use, has its Decatur, Illinois, plant operating near its nameplate capacity of 75,000 gallons per day or 27×10^6 gal/yr.⁽²³⁾ While it is feasible to run a plant to produce small quantities of ethyl alcohol, most ventures being considered fall in the range of $10-50 \times 10^6$ gal/yr.^(22,23)

Section 9.3: Economics Discussion

A. Methane

Many peripheral factors affect the economics of producing energy in the form of methane by anaerobic digestion, such as the preparation of the biomass feed, cleaning of the gas generated (particularly if it is to be pumped into a pipeline or used in fuel cells), disposal of the digested residues, and treatment of the organically contaminated supernatant, if necessary. The extent of gas storage requirements also affects the overall cost importantly.

Dynatech⁽¹²⁾ has estimated (Table 9-1) the cost of methane production from manure in 1977 and has evaluated the sensitivity of the results from several viewpoints. The baseline design was a 10,000-head (cattle) feedlot using an environmental feedlot design and a continuously stirred tank reactor (CSTR) digester. An environmental feedlot employs a grate beneath the animals to facilitate the frequent removal of manure from the feedlot, which minimizes the loss of volatile material from the manure and maximizes methane yield. The estimated capital investment for the manure recovery and methane ($98,600,000 \text{ ft}^3/\text{yr}$, approximately $98,600 \times 10^6 \text{ Btu/yr}$) production system was \$694,000 (about \$0.063/Btu/hr of output), excluding engineering fee and contingency.

TABLE 9-1
1977 COST OF METHANE PRODUCTION FROM MANURE

<u>Feedlot Size, Head</u>	<u>Type</u>	<u>No. of CSTR Reactors</u>	<u>Methane Production Cost (\$/Mcf)⁽¹⁾</u>		<u>Annual Gas Production (Mcf)</u>
			<u>O&M</u>	<u>Total</u>	
10,000	Environmental	One	3.75	5.17	98.6
10,000	Dirt	One	16.26	22.45	20.9
10,000	Concrete	One	10.07	13.15	31.6
30,000	Environmental	One	2.26	3.17	278.4
60,000	Environmental	One	1.81	2.54	556.9
100,000	Environmental	One	1.62	2.24	928.1
10,000	Environmental	Optimum	3.52	4.93	107.9

(1) \$/Mcf is approximately equal to $\$/10^6 \text{ Btu}$ for methane.

SOURCE: Reference 12.

The estimated cost of methane from the Mountain View, California, landfill is $\$2.79/10^6 \text{ Btu}$ of which $\$0.79/10^6 \text{ Btu}$ is for operation and maintenance. The capital investment for a system to recover $97,650 \times 10^6 \text{ Btu/yr}$ would be \$788,000 (about \$0.071/Btu/hr).⁽¹³⁾

For comparison, in 1977 natural gas was selling between \$1.07 and $\$2.98/\text{ft}^3$ in the continental United States.⁽²⁴⁾

B. Ethyl Alcohol

Development Planning and Research Associates estimated the cost of producing ethanol via conventional fermentation in 1977.⁽²⁵⁾ A grain-based plant to produce 20 million gallons of ethanol per year (approximately as large as any plant module operating in the United States) would cost about \$31.3 million (\$1.56/gal/yr or \$0.15/Btu/hr capital investment). If grain (corn) were charged at \$2.50/bushel and byproduct distillers' dried grains were credited at \$110/ton, the cost of ethanol production would be \$1.35/gal (\$16.00/10⁶ Btu), including O&M at \$0.363/gal (\$4.30/10⁶ Btu). This compares with a maximum selling price of \$1.15/gal of industrial ethanol (95% proof) in 1977, most of which was derived from ethylene.

Since 1978, several states have waived all or a portion of their gasoline taxes for gasohol.⁽²²⁾ The Federal Government has also begun subsidizing gasohol by waiving its 4¢/gallon excise tax which amounts to \$0.40/gallon of ethyl alcohol.

Wilke⁽¹⁹⁾ estimated the cost of producing sugars from biomass via the advanced enzymatic saccharification process described earlier. Eight hundred and eighty-five tons/day of cellulosic biomass (newsprint) would be converted to 238 tons/day of sugars in a 4% solution. The estimated fixed capital investment is \$23.4 million and the overall production cost is \$0.052/lb of sugars. A similar plant (including acid pretreatment to increase sugar production) to convert wheat straw to a like quantity of sugars would cost about \$30 million to construct and the cost of sugars would be about \$0.047/lb.

Wilke⁽¹⁹⁾ further estimated the cost of converting these sugars to ethanol (about 6.9×10^6 gal/yr or 585×10^9 Btu/yr) by fermentation by Saccharomyces cerevisiae. The plant, comprising sugar concentration, fermentation, distillation, and yeast recovery, would cost about \$5.4 million. When sugars are charged at \$0.052/lb (as above), the cost of 95% ethanol is estimated to be \$1.05/gal. The overall capital investment for the ethanol-from-cellulose process totals \$28.8 million (\$0.43/Btu/hr of ethanol). Of the total production cost of \$1.05/gal (\$12.43/10⁶ Btu), feedstock MSW was charged at zero value; O&M amounts to \$0.64/gal (\$7.55/10⁶ Btu).

Section 9.4: Limitations

Methane from anaerobic digestion and from landfills can make a contribution to local energy needs where there may be sufficient resources available. However, the total contribution to the national energy requirements would be severely constrained by the availability of resources. For example, if 20% of all cattle manure (132 million head total population) were converted to methane at $9.28 \times 10^6 \text{ ft}^3$ per 1000 head, approximately 0.24 quad of energy would be produced.⁽¹²⁾ Similarly, if methane could be produced from landfills at the rate projected for City of Industry, California ($3 \times 10^9 \text{ ft}^3$ from 3.5 million tons of solid waste over 19 years⁽¹⁴⁾), the entire estimated U.S. solid waste resource of 134 million tons (Chapter 7) would be capable of producing only about 0.11 quad. It should also be recognized that an important consideration in the recovery of methane from landfills is often the protection of surrounding areas from subsurface migration of explosive gas.

Crop residues, wood residues, inedible plants, and many other types of cellulosic biomass usually have low alternative value relative to the value of their contained energy. Thus, in producing energy from these materials, there would generally be few competing non-fuel alternative uses for the raw material. When considering the production of methane or ethyl alcohol from crop wastes, one should recognize that the seasonal availability of feedstock for the digestion process creates both economic penalties and technological difficulties caused by irregular capacity utilization. Generally, the limitations of feedstock availability would be consistent with those discussed in Chapter 7. Furthermore, regardless of the type of biomass used in the digestion process, in most cases a significant amount of digested residue or sludge is produced, thus requiring some solid waste disposal. However, disposal of these materials on agricultural land can often have the benefit of restoring nutrient and/or soil-conditioning value.

Enzymatic conversion of cellulose is not yet a well-developed technology. In addition, the primary use of ethyl alcohol today, when produced by fermentation, is for alcoholic beverages, which renders its

value far greater than that of its energy content. Cost estimates for enzymatic processes should be viewed with a degree of caution. The economics can vary greatly with the type of biomass used, and unforeseen technical problems might significantly increase the production costs. As in the case of methane generation from biomass, maintaining a steady supply of biomass material could be a problem with regard to operating and crop storage costs and maintaining optimum plant throughput.

An extremely important competing factor is that enzymatic conversions are also being used for the production of single-cell proteins, which have considerable value as an animal feed. Thus, a concerted attempt to expand both concepts commercially could present some serious growth limitations. With these limitations in mind, it is difficult to envision ethyl alcohol produced by fermentation being used to any significant extent as a competitive liquid fuel in the United States.

Ethyl alcohol produced from grain and molasses (i.e., biomass sources) is usually not competitive with ethyl alcohol produced synthetically from ethylene (see Economics Discussion). In 1977 only about 6% of all industrial ethyl alcohol production in the United States was via fermentation.⁽²⁶⁾ Thus, significant technical advances appear necessary before ethyl alcohol can become an economical energy form.

Use of ethyl alcohol from renewables has the potential benefit of improving farm prices and the general health of U.S. agriculture. However, food prices -- most corn is used for beef production -- may be significantly impacted. As an example, if 5% of the U.S. consumption of gasoline were displaced by ethyl alcohol, about 5.8 billion gallons would be required.⁽²²⁾ A yield of 2.6 gallons of alcohol per bushel of corn would require about 2.2 billion bushels of feedstock. This compares with a 1976 U.S. crop of 5.7 billion bushels,⁽²⁷⁾ but this alcohol can also be produced from other biomass sources of starches and sugars.

Ethyl alcohol which is intended or otherwise suitable for human consumption is regulated by the U.S. Treasury Department's Bureau of Alcohol, Tobacco, and Firearms (ATF). Ethyl alcohol which is produced for industrial or fuel use must be rendered unfit for human con-

sumption (denatured) by use of a small quantity of any of a number of denaturants, such as one part gasoline in one hundred parts of alcohol. (28)

Methane and alcohol fuels discussed in this chapter are generally considered relatively clean fuels for most applications. For the most part they are at least as environmentally acceptable as the fuels they would displace.

There is considerable controversy as to whether fuel-grade ethyl alcohol requires a greater energy input for production than can be obtained by burning it as fuel. (29,30) The net energy loss depends in large part on the methodology used in the energy analysis. (30) Future technological developments should result in improved energy balance. (31)

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Pohland, F.G., ed. Anaerobic Biological Treatment Processes. Washington, D.C.: American Chemical Society, 1971. (Advances in Chemistry Series #105).
2. Alich, J.A., et al. An Evaluation of the Use of Agricultural Residue as an Energy Feedstock. Vol. I. Prepared by Stanford Research Institute for National Science Foundation, July 1976. NTIS Report No. PB 260 763.
3. Ad Hoc Panel of the Advisory Committee on Technology Innovation. Methane Generation from Human, Animal, and Agricultural Wastes. Washington, D.C.: National Academy of Sciences, 1977.
4. Prasad, C.R., et al. Economic and Political Weekly 9:1347, 1974.
5. Singh, R.B. "The Bio-Gas Plant; Generating Methane from Organic Waste." Compost Science 13(1):20, 1972.
6. Pfeffer, J.T. "Temperature Effects on Anaerobic Fermentation of Domestic Refuse." Biotechnology and Bioengineering 16:771, 1974.
7. Pfeffer, J.T., et al. "Energy from Refuse by Bioconversion, Fermentation and Residue Disposal Processes." Resource Recovery and Conservation 1:295, 1976.
8. Trevelyan, W.E. "Renewable Fuels, Ethanol Produced by Fermentation." Tropical Science 17(1):1, 1975.
9. Clausen, E.C., et al. "Converting Crops into Methane." Chemical Engineering Progress 73(1):71, January 1977.
10. Jewell, W.J., et al. Anaerobic Fermentation of Agricultural Residue: Potential for Improvement and Implementation. Final Report. Prepared by Cornell University for the U.S. Department of Energy, February 1978. pp. 427 ff. NTIS Report No. HCP/T2981-07.
11. Lank, R. "Cattle, Swine and Chicken Manure Challenges Waste Disposal Methods." Water and Sewage Works 117(4):134, 1970.
12. Ashare, E., et al. Fuel Gas Production from Animal Residue. Prepared by Dynatech R/D Company, 1977. pp. 202 ff. NTIS Report No. C00/2991-10.
13. James, S.C., et al. "Methane Production, Recovery, and Utilization from Landfills." Symposium on Energy from Biomass and Wastes, Institute of Gas Technology, Washington, D.C., August 14-18, 1978. pp. 317 ff.

REFERENCES (continued)

14. Stearns, R.P., et al. "Recovery and Utilization of Methane Gas from a Sanitary Landfill - City of Industry, California." Symposium on Energy from Biomass and Wastes, Institute of Gas Technology, Washington, D.C., August 14-18, 1978. pp. 325 ff.
15. Rice, F.C. "Commercial Production of Pipeline Quality Gas at Palos Verdes Landfill." Symposium on Energy from Biomass and Wastes, Institute of Gas Technology, Washington, D.C., August 14-18, 1978. pp. 345 ff.
16. Peppler, H.J. Microbial Technology. New York: Reinhold Publishing Corporation, 1967.
17. Kressman, F.W. The Manufacture of Ethyl Alcohol from Wood Waste. Washington, D.C.: U.S. Department of Agriculture, 1922. Bulletin 410.
18. Convesse, A.O., et al. Acid Hydrolysis of Cellulose in Refuse to Sugar and Its Fermentation to Alcohol. Hanover, New Hampshire: Thayer School of Engineering, Dartmouth College, June 1973.
19. Wilke, C.R. "Production of Sugars and Ethanol Based on the Enzymatic Hydrolysis of Cellulose." Fuels from Biomass Symposium, University of Illinois at Urbana-Champaign, April 18-19, 1977.
20. Spano, L.A., et al. Enzymatic Hydrolysis of Cellulosic Wastes to Glucose. Natick, Massachusetts: U.S. Army, Natick Development Center, September 1975.
21. Anderson, Earl V. "Gasohol: Energy Mountain or Molehill?" Chemical and Engineering News 56:8, July 31, 1978.
22. "U.S. Presses Drive for Use of Gasohol." Oil & Gas Journal 77:54, July 2, 1979.
23. Levy, R. "How Far Can Gasohol Go?" Dun's Review 114:44, July 1979.
24. Winton, J.M. "Plant Sites 1979." Chemical Week 123(18):41, November 1, 1978.
25. Development Planning and Research Associates, Inc. Gasohol, Economic Feasibility Study. Lincoln, Nebraska: Energy Research and Development Center, University of Nebraska, July 1978.
26. Chemical Profiles. New York: Schnell Publishing Company, Inc., 1977.
27. Lipinsky, E.S., et al. Systems Study of Fuels from Sugarcane, Sweet Sorghum, Sugar Beets and Corn, Vol. IV: Corn Agriculture, Task 77. Final Report. Prepared by Battelle Columbus Laboratories for Energy Research and Development Administration, March 31, 1977. NTIS Report No. BMI-1957A(V.4).

REFERENCES (continued)

28. Department of the Treasury, Bureau of Alcohol, Tobacco and Firearms. Ethyl Alcohol for Fuel Use. Washington, D.C., September 1978. Information brochure. No. ATF P 500.1.
29. Weisz, P.B. et al. "High-Grade Fuels from Biomass Farming: Potentials and Constraints." Science 206(4414):24. October 5, 1979.
30. Chambers, R.S. et al. "Gasohol: Does It or Doesn't It Produce Positive Net Energy?" Science 206(4414):789. October 5, 1979.
31. "Lowering the Cost of Alcohol." Science 206(4414):41. October 5, 1979.

CHAPTER 10
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: BIOMASS GASIFICATION AND LIQUEFACTION</p> <p>DESCRIPTION: Conversion of biomass materials (wastes and/or crops) to gas, oil, or methanol</p> <p>POTENTIAL USER CLASSES: Municipalities, gas and electric utilities, energy companies</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Pilot plant scale, approaching demonstration scale</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY</td><td>100-1000</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY</td><td>.7-7</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.85⁽¹⁾</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.6-.9</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.40-.70</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): MSW^A AMOUNT NEEDED PER UNIT OUTPUT: .15-.25 ton/10^6 Btu</p> <p>ALTERNATIVE FUEL(S): Biomass residues IS SYSTEM READILY CONVERTIBLE? Yes</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Should operate steadily if feed is reasonably uniform in quantity and quality</p> <p>CONNECTION TO CENTRAL UTILITY: NA^{**}</p> <p>DESIRABLE FOR USER?</p> <p>TECHNICALLY PRACTICAL?</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? NA</p> <p>SPECIFY SYSTEM:</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY	100-1000	same	same	SECONDARY				UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY	.7-7	same	same	SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:	.85 ⁽¹⁾	same	same	RANGE OF CAPACITY FACTORS:	.6-.9	same	same	EFFICIENCY (BTU OUT/BTU IN):	.40-.70	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (10^6 Btu/hr) PRIMARY	100-1000	same	same																																
SECONDARY																																			
UNIT ANNUAL ENERGY OUTPUT: (10^{12} Btu) PRIMARY	.7-7	same	same																																
SECONDARY																																			
AVERAGE EFFECTIVE CAPACITY FACTOR:	.85 ⁽¹⁾	same	same																																
RANGE OF CAPACITY FACTORS:	.6-.9	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.40-.70	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input) (INCLUDES: Process units)</td><td>9,900-82,500⁽¹¹⁾</td><td>same</td><td>same</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/10^6 Btu)</td><td>.97-2.59</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>(111)</td><td>2-3 years</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input) (INCLUDES: Process units)	9,900-82,500 ⁽¹¹⁾	same	same	AVERAGE UNIT O&M: (\$/ 10^6 Btu)	.97-2.59	same	same	CONSTRUCTION PERIOD:	(111)	2-3 years	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/ton/day input) (INCLUDES: Process units)	9,900-82,500 ⁽¹¹⁾	same	same																																
AVERAGE UNIT O&M: (\$/ 10^6 Btu)	.97-2.59	same	same																																
CONSTRUCTION PERIOD:	(111)	2-3 years	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Adequate to meet demand</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: Possible significant solid residue</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Serious technical problems at prototype facilities may forestall large-scale commercialization.</p>																																		
COMMENTS	<p>(1) For a commercially viable venture.</p> <p>(11) Equivalent to \$.02-\$.20/Btu/hr output.</p> <p>(111) Only small units commercially available; large units require further demonstration.</p> <p>* MSW = Municipal Solid Waste.</p> <p>** NA = Not Applicable.</p>																																		

CHAPTER 10

BIOMASS GASIFICATION AND LIQUEFACTION

Section 10.1: Introduction

Biomass may be converted to liquids and/or gases by pyrolysis, which is the breakdown of organic materials by the application of heat.⁽¹⁾ Strictly speaking, pyrolysis takes place in the absence of molecular oxygen. However, since the reaction of oxygen with a portion of the solid fuel is a convenient and commonly used method of supplying the necessary heat for pyrolysis, the term is also used in a less strict sense to mean the gasification or liquefaction of biomass materials in a controlled but deficient amount of oxygen.⁽²⁾

Depending on the severity of the pyrolysis treatment, the products will be one or more of the following:

- hydrocarbon gases,
- carbon monoxide,
- carbon dioxide,
- hydrogen,
- water,
- oil,
- ash, and
- char.

Generally, when the desired product is a fuel gas, the principal output is a gaseous mixture of somewhat controllable portions of the first five constituents. These can be converted, usually catalytically, to other fuels such as methanol or methane, or utilized directly for their energy value.

Section 10.2: Technical Discussion

A. Terrestrial Biomass Crops and Residues

There are numerous pyrolysis processes under development to produce gaseous fuels and one that produces a liquid fuel from cellulosic

materials.⁽³⁾ While many of these processes have been developed primarily to convert municipal wastes, they are also applicable to cellulosic materials of any type.

One process which has been researched is a mobile air-blown pyrolysis converter for agricultural wastes. The system proposed by the Georgia Institute of Technology Engineering Experiment Station would be capable of converting up to 200 tons/day of wastes in the field into about 45 tons of a char-oil mixture.⁽⁴⁾ The chief advantage of such a system is potential savings in transportation costs of the agricultural waste to a central processing facility.

In principle, the process (mounted on two large flatbed trailers) would pyrolyze wet cellulosic feedstock in a manner analogous to the vertical shaft concept of Purox (described below) using air as the oxidant. The major research and development need is to gain knowledge of the product fuel properties so that the use of an available or specifically designed combustor can be assessed.

A partial listing of additional biomass gasifier manufacturers in the United States is shown in Table 10-1. A more comprehensive directory of air gasifiers for biomass can be found in Reference 5, which also summarizes the proven status of air-gasifier technology. A good track record based on the development of necessary equipment along with the sales and service network remains to be demonstrated. Presentation of generalized costs is not warranted in this report because economic viability requires a unique set of circumstances.⁽⁵⁾ Often the economics are published only for such unique circumstances, e.g., low prices for feedstocks and other process requirements, and low capital-related costs (interest and profit) as is the case for the data presented on page 8-2 of Reference 5.

B. Municipal Solid Waste (MSW)

The systems developed by Monsanto (Landgard) and Torrax (a subsidiary of Carborundum Environmental Systems) produce a low heating-value gas that is burned on-site to generate steam in a waste-heat boiler.

TABLE 10-1

PARTIAL LIST OF BIOMASS GASIFIER MANUFACTURERS IN THE UNITED STATES

<u>Manufacturer</u>	<u>Type</u>	<u>Status</u> ⁽¹⁾	<u>Input</u> ⁽²⁾ <u>(10⁶ Btu/hr)</u>
Applied Engineering, Orangeburg, SC	Updraft	D	8
Biomass Fuel Conversion, Yuba City, CA	Downdraft	D	14
Century Research, Gardena, CA	Updraft	C	85
Davis Gasifier, U. of Calif., CA	Downdraft	D	14
DeKalb Agricultural Research, DeKalb, IL	Updraft	D	1.7
Forest Fuels, Keene, NH	Updraft	C	1-12
Foster-Wheeler, Livingston, NJ	Updraft	D	50
Halcyon, E. Andover, NH	Updraft	C	8
Pioneer Hi-Bred Inst., Johnston, IA	Updraft	D	7
Woodex Corp., Eugene, OR	Updraft	C	10

(1) Status of project: C, Commercial -- at least one unit in field
D, Demonstration, Testing

(2) Fuel Consumption in tons/hr is approximately $10^6 \text{ Btu/hr} \div 16 \times 10^6 \text{ Btu/dry ton}$.

SOURCE: Reference 6.

The process developed by Union Carbide Corporation produces a medium heating value gas that can be shipped via pipeline to commercial and utility users. A process that produces a fuel oil has been developed by Occidental Research Corporation, a subsidiary of Occidental Petroleum Company.

The following subsections describe these processes in some detail. Where they are to be used for converting terrestrial biomass crops and residues, the need, if any, to remove tramp components (i.e., larger than 1/4-inch metals, glass, and other non-biomass materials) is, of course, obviated with an inherent reduction in cost. However, efficiencies of conversion of the organic fractions of the feeds should vary only slightly depending most importantly on the moisture content of the reactor feed.

1. Monsanto Landgard System

In this process, ^(7,8,9) wastes are shredded, conveyed to a storage silo, and subsequently fed to a rotary kiln where the material is gasified. The kiln is fired with the small quantity of oil which is produced within the process. The burner is arranged to provide a counter-current flow of gases and solids, thus exposing the wastes to progressively higher temperatures as they pass through the kiln. The finished residue is exposed to the highest temperature of 1800°F just before it is discharged from the kiln and quenched in a water-filled tank. The residue includes ash and char and, in the case of MSW, glassy aggregate and metal scrap.

Gases leaving the pyrolysis reactor at a temperature of 1200°F have a low heating value (120 Btu/ft³), making off-site transportation uneconomical. Therefore, these gases are immediately mixed with air and burned in an afterburner to liberate the heat of combustion. The combustion gases then pass through the waste heat boilers where steam is generated for distribution. About 4800 pounds of steam are recovered from 1 ton of municipal solid waste (MSW). ⁽⁷⁾

Monsanto started up a 1000-ton/day demonstration plant in Baltimore in 1975, but this plant has been troubled by its inability to meet

particulate emission standards.⁽¹⁰⁾ Monsanto has since withdrawn from the project, and the system has been shut down for the installation of an electrostatic precipitator to control the emissions.^(10,11)

2. Torrax System

The Torrax system,^(7,8,9) which was developed by the Carborundum Company and is marketed by ANDCO, is a high-temperature slagging pyrolysis system which, like the Landgard system, reduces cellulose to a low heating-value fuel gas. In this process the feed is charged as received (without shredding) into a gasifier, a vertical shaft furnace designed so that the descending refuse and the ascending high-temperature gases become a countercurrent heat exchanger. As the solid descends, three distinct process changes occur: (1) drying, where moisture is driven off; (2) pyrolysis due to the heat transfer from the ascending hot gases to the solid mass; and (3) combustion in the hearth where some of the carbonaceous char is oxidized to carbon dioxide in the presence of preheated air.

In the Torrax system, approximately 160 pounds of this char per ton of feed processed need not be oxidized; it becomes a byproduct. About 15% of the gross product gas is recycled for preheating the processed air which is supplied to the gasifier hearth. The remaining 85% of the product gas, which has a heating value of 100 Btu/ft³ is injected into an afterburner or secondary combustion chamber where it is burned to completion. The heat which is thus released is then directed to a waste heat boiler where it is recovered as steam. About 45,000 ft³ of gas are available for each ton processed. Thus, in the Torrax process, 1 ton of MSW yields about 4.5 million Btu.

The principles of the Torrax process were originally proven in a 75-ton/day pilot plant operated intermittently since 1971. This plant, which is located in Erie County, New York, has processed a mixture of municipal solid waste and dried sewage sludge. A 200-ton/day prototype plant is now undergoing startup in Luxembourg, and at least two other plants are scheduled to be built in Europe in the near future.⁽⁷⁾

3. Union Carbide Purox System

The Purox system^(7,8,9,12,13) developed by Union Carbide Corporation employs a slagging pyrolysis process that uses oxygen in place of air. The process produces a clean fuel gas and a fused ash. The key element of this system is a vertical shaft furnace. Shredded biomass is fed into the top of the furnace reactor through a piston air-lock system, while oxygen is injected into the bottom of the furnace. The solid material falls through varying temperatures zones on its downward passage through the vertical reactor. Char forms as the solids devolatilize at the top of the reactor. The char is then reacted with oxygen in a lower section to produce a temperature of about 3000°F. The rising hot gases then provide the necessary heat for treating the incoming material in the upper portion of the reactor. When solid waste is fed to the gasifier, metals, glass, and other non-combustibles are transformed into a molten slag by the high temperatures generated in the lower portion of the reactor.

Gases leaving the reactor contain 30% to 40% moisture. This is removed in a clean-up step along with ash, tars, and other condensable liquids. The heating value of the resulting gas is approximately 300 Btu/cubic foot. The gas is compressed to 35 psig for delivery to the customer. Each ton of processed solid waste yields about 22,000 cubic feet of gas. Thus, this process generates about 6.8 million Btu/ton of input waste.

Following an evaluation of the process in a pilot plant, Union Carbide constructed a 200-ton/day facility in 1974 in South Charlestown, West Virginia, which demonstrated the feasibility of the concept. It has subsequently been shown that it is feasible to co-dispose of sewage sludge and MSW in the Purox systems. Union Carbide's plans to market the system are presently uncertain, most likely because of the rapidly escalating estimated costs of the process.

4. Occidental Flash Pyrolysis System

This system,^(7,8,9,12) in contrast to the pyrolysis systems discussed above, provides for a front-end separation that permits the

recovery of a full spectrum of secondary materials from MSW. The Occidental process for municipal solid waste utilizes two stages of shredding, air classification, magnetic separation, drying, and screening to produce shredded refuse-derived fuel (RDF) for the pyrolyzer feedstock.

The shredded RDF, which represents about 60% of the input waste, or other clean biomass fuel, is fed into a vertical stainless-steel reactor, along with hot residue consisting of ash and/or char that is a by-product from the pyrolysis reaction. The hot char provides the energy needed to pyrolyze the organics. The material present in the reactor consists of a mixture of char, ash, and the pyrolysis gases. If the gases are cooled rapidly before they can completely react, a portion of the gas is condensed into an oil-like liquid fuel. Both the remaining gas and the char are reused within the system.

The fuel product is a viscous, highly oxygenated combustible liquid which may pose storage, corrosion, and handling problems. The average heating value of the pyrolytic "oil" is about 10,500 Btu/pound,⁽⁹⁾ compared with 18,000 Btu/pound for typical No. 6 fuel oil. The Occidental process yields about 0.24 ton of oil per input ton of waste, or about 0.4 ton per ton of solid material fed to the pyrolyzer. Thus, the liquid pyrolysis system yields slightly more than 0.5 million Btu/million Btu input.

The first prototype plant, a 200-ton/day facility, has been built by San Diego County with the financial assistance of a demonstration grant from the U.S. Environmental Protection Agency and a subsidy from Occidental Petroleum. The system was run "sporadically from December, 1977 to last March (1978)."⁽¹⁴⁾ Except for a brief run, the operation has been suspended since that time because of "operating failures and rising costs."⁽¹⁴⁾

C. Conversion of Gasifier Products to Methane (Substitute Natural Gas) or Methanol

Gasifier products are generally rich in carbon monoxide, hydrogen, and methane. These gases can be converted by appropriate catalytic processes to either methane or methanol as described briefly below.

1. Shift Conversion

Shift conversion, or the water-gas reaction, involves the reaction of carbon monoxide to produce hydrogen:

The reaction is generally employed to adjust the ratio of hydrogen to carbon monoxide in a gas mixture, usually for the purpose of a downstream synthesis step such as for the production of methane-rich gas or methanol. The process is widely practiced and the technology of the fixed-bed catalytic system is well known.^(15,16)

2. Methanation

Methanation involves the reaction of carbon monoxide (or carbon dioxide) and hydrogen to produce a gas containing more than 90% (dry basis) methane by:

Until recently, these processes have been developmental, with the primary emphasis being to produce substitute natural gas from coal-derived gas streams. Most work on the fixed-bed catalytic approaches undertaken by the various developers has centered on the removal of heat from the highly exothermic reaction under controlled conditions. This generally involves recycling a portion of the product gas to the feed and/or staging of several reactors in series. Several developers are now offering their systems commercially.

3. Methanol Synthesis

Methanol has been synthesized chemically for many years to produce a product for chemical use. It is now being more widely considered as a fuel mainly for utility and transportation uses.⁽¹⁷⁾ The methanol is usually synthesized by the reaction of hydrogen and carbon monoxide (or carbon dioxide) in a fixed-bed catalytic reactor (Imperial Chemical Industries, Ltd., process):

Chem Systems, Inc., is developing a process which, if successful, will produce methanol in a lower-cost, liquid-phase catalytic reactor.⁽¹⁸⁾

Section 10.3: Economics Discussion

Reported costs for plants to convert municipal solid waste via pyrolysis are tabulated comparatively in Table 10-2. The capital investments are for the fixed plant only and do not include items such as land, startup cost, construction loan interest, etc. It is noteworthy that the estimated capital costs vary widely among references. They are highest (in 1977 dollars) for the most recent references. Byproducts, where recovered, are credited to the operating cost, but the energy value of the product fuel is not credited. All MSW is delivered at the plant gate and a credit for applicable tipping (disposal) fee, which can range from \$5 to \$20 per ton, is not included.

In assessing the operating costs per unit capacity, one must remember that the capital charges are included only to the extent of debt retirement. There are no provisions for land, other capital needs, or business risk. Further, the products are of limited utility unless (1) used in the immediate locality of the plant because of high transportation costs of gaseous fuels and steam, or (2) upgraded, e.g., hydrogenation of the Occidental pyrolysis oil, or methanation of the Purox gas. The costs of such upgrading can vary so widely as a function of the fuel properties, that it is not worthwhile to estimate ranges. Moreover, the needs for pollution control equipment are not completely defined, and these needs can contribute substantially to the cost of implementing the technologies.

In applying these technologies to other biomass fuel sources, it is possible -- even likely -- that the plant requirements and costs will drop somewhat because of the relative homogeneity and absence of tramp materials in these fuels. However, the costs associated with obtaining alternative waste materials or growing biomass fuels must be factored into the analysis.

TABLE 10-2

COSTS OF PYROLYSIS OF MSW

<u>Process</u>	<u>Capacity (Ton/Day MSW)</u>	<u>Capital Cost⁽¹⁾ (1977 \$/Ton/Day MSW)</u>	<u>Operating Cost⁽²⁾</u>		<u>Efficiency MSW To Fuel (%)</u>	<u>Reference</u>
			<u>\$/Ton MSW</u>	<u>\$/10⁵ Btu⁽³⁾ Product</u>		
Monsanto- Landgard	500-1000	16,400	6.12	1.30 ⁽⁴⁾	NA	9
Torrax	300	21,300	NA ⁽⁵⁾	NA	40-60 to steam	9
Purox	500-1000	51,300 - 76,900	NA	NA	NA	3
	200-1000	15,200	5.39	NA	NA	9
	1000	32,100	17.35	2.45	66	12
Occidental Research	1000-1500	64,500 - 82,500	NA	NA	NA	3
	150-2000	9,900	4.87	0.97	~50	9
	1000	28,400	10.58	2.59	46	12
	1000-1500	50,600 - 66,000	NA	NA	NA	3

(1) Capital costs updated from reference using the Chemical Engineering Plant Cost Index.

(2) Operating costs updated from reference at 6% per year.

(3) Assumes 10×10^6 Btu/ton of raw MSW and the conversion efficiency shown.

(4) Assumes 50% efficiency as a basis for comparison only.

(5) NA = Not Available.

Section 10.4: Limitations

In addition to any economic constraints or competitive factors which may defer implementation of pyrolysis options, the finiteness of the resource base (discussed in Chapter 7) is a limiting factor.

The technology is presently in a very early stage of pilot plant testing and demonstration. A few small-scale gasifiers are operating successfully in the field, but most of the activity remains at the pilot plant level. Larger-scale MSW converters have suffered technical setbacks and are not progressing into commercialization at the rate originally hoped.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

10-12

REFERENCES

1. Morrison, R.T., et al. Organic Chemistry. 2nd edition. Boston, Massachusetts: Allyn and Bacon, Inc., 1966.
2. Lamb, T.J. "Fundamentals of Pyrolysis." Preprint. International Symposium on Energy Recovery from Refuse, 1975. Available from the author c/o Arthur D. Little, Inc., Acorn Park, Cambridge, Massachusetts.
3. Bechtel Corporation. Edison Coordinated Joint Regional Solid Waste Energy Recovery Project. San Francisco, California, April 1977.
4. Milton, E., et al. Engineering and Economic Analysis of Waste to Energy Systems. Prepared by Ralph M. Parsons Co. for Environmental Protection Agency, May 1978. NTIS Report No. PB 285 797.
5. Solar Energy Research Institute. Retrofit '79. Proceedings of a Workshop on Air Gasification, Seattle, Washington, February 2, 1979.
6. Reed, T.B., et al. "Technology and Economics of Close-Coupled Gasifiers for Retrofitting Gas/Oil Combustion Units to Biomass Feedstock." React '78. The Biomass Energy Institute, Inc. Winnipeg, Manitoba, Canada, October 3-4, 1978.
7. Stanford Research Institute. Program Definition for Fuels from Biomass. Prepared for the California Energy Resources Conservation and Development Commission, Sacramento, California, 1976.
8. Snyder, N.W. "Pyrolysis of Municipal Solid Waste to Fuels and Chemicals." AIChE Symposium Series 73(162):150, 1977.
9. Midwest Research Institute. Resource Recovery, Catalogue of Processes. Washington, D.C.: Council on Environmental Quality, February 1973.
10. St. Clair, C.W. "Resource Recover Update." Pollution Engineering 10(9):44, September 1978.
11. Haslbeck, J.L., et al. Source Emission Tests at the Baltimore Demonstration Pyrolysis Facility. Prepared by TRW, Environmental Engineering Division for the Environmental Protection Agency, December 1978. NTIS Report No. BP 292 113.
12. Bechtel Corporation. Fuels from Municipal Refuse for Utilities, Technology Assessment. Prepared for Electric Power Research Institute, Palo Alto, California, March 1975.
13. Mathematics Sciences Northwest, Inc. Feasibility Study: Conversion of Solid Waste to Methanol or Ammonia. Seattle, Washington: City of Seattle, Department of Lighting, September 6, 1974.

REFERENCES (continued)

14. "Pyrolysis Failure." Engineering News Record 201:18, July 27, 1978.
15. Battelle Pacific Northwest Laboratories. The Gasification of Coal. A Battelle Energy Program report. Richland, Washington, July 1974. pp. 1 ff.
16. Arthur D. Little, Inc. Assessment of Fuels for Power Generation by Electric Utility Fuel Cells. Prepared for Electric Power Research Institute, October 1975. EPRI Report No. EPRI 318.
17. Hagen, D.L. Methanol: Its Synthesis, Use as a Fuel, Economics, and Hazards. Thesis prepared for University of Minnesota, December 1976. NTIS Report No. NP-21727.
18. Chem Systems, Inc. Liquid Phase Synthesis of Methanol. Interim Report. Prepared for Electric Power Research Institute, May 1978. EPRI Report No. EPRI AF-693.

TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: FLUIDIZED-BED COMBUSTION</p> <p>DESCRIPTION: Coal is burned in a fluid bed with a high rate of heat transfer to a working fluid (steam or flue gas) and with simultaneous absorption of SO₂ in the bed.</p> <p>POTENTIAL USER CLASSES: Commercial, industrial for steam generation; electric utility for electricity generation</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Technology in early stages of testing on a large scale; industrial boilers offered commercially</p>																				
TECHNICAL	<p>UNIT POWER OUTPUT CAPACITY: (10⁶ Btu/hr) PRIMARY</p> <p>UNIT ANNUAL ENERGY OUTPUT: (10¹⁰ Btu) SECONDARY</p> <p>AVERAGE EFFECTIVE CAPACITY FACTOR:</p> <p>RANGE OF CAPACITY FACTORS:</p> <p>EFFICIENCY (BTU OUT/BTU IN): (for steam generation)</p> <p>PRIMARY FUEL(S): Coal</p> <p>ALTERNATIVE FUEL(S): Sludge, other wastes, wood, oil, and gas</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Load following</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Probably for electric power and/or gas for startup</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? NA*</p> <p>SYSTEM:</p>	<table border="1"> <thead> <tr> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>100-400</td> <td>100-1000</td> <td>same</td> </tr> <tr> <td>78-312</td> <td>78-780</td> <td>same</td> </tr> <tr> <td>.90</td> <td>same</td> <td>same</td> </tr> <tr> <td>.60-.95</td> <td>same</td> <td>same</td> </tr> <tr> <td>.75-.90</td> <td>same</td> <td>same</td> </tr> </tbody> </table> <p>4015 Btu/kWh thermal 8600-9500 Btu/kWh electrical</p> <p>IS SYSTEM READILY CONVERTIBLE? If designed for this purpose</p>	1977	1985	2000	100-400	100-1000	same	78-312	78-780	same	.90	same	same	.60-.95	same	same	.75-.90	same	same	
	1977	1985	2000																		
100-400	100-1000	same																			
78-312	78-780	same																			
.90	same	same																			
.60-.95	same	same																			
.75-.90	same	same																			
ECONOMIC	<p>TOTAL INSTALLED UNIT CAPITAL COST: (\$/10⁶ Btu/hr)</p> <p>(INCLUDES: Complete boiler only)</p> <p>AVERAGE UNIT O&M: (\$/10⁶ Btu, excluding fuel)</p> <p>CONSTRUCTION PERIOD: (yr/unit)</p>	<table border="1"> <thead> <tr> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>5.13-8.83 x 10⁴</td> <td>same</td> <td>same</td> </tr> <tr> <td>1.47-1.90⁽¹⁾</td> <td>same</td> <td>same</td> </tr> <tr> <td>2-3</td> <td>same</td> <td>same</td> </tr> </tbody> </table>	1977	1985	2000	5.13-8.83 x 10 ⁴	same	same	1.47-1.90 ⁽¹⁾	same	same	2-3	same	same							
1977	1985	2000																			
5.13-8.83 x 10 ⁴	same	same																			
1.47-1.90 ⁽¹⁾	same	same																			
2-3	same	same																			
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Existing boiler manufacturers</p> <p>GEOGRAPHIC LIMITATIONS: All regions of U.S. suitable</p> <p>ENVIRONMENTAL EFFECTS: Limitation in SO₂ removal and/or high absorbent use. Lower NO_x release than conventional. Potential for high cost of spent solids disposal.</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: None</p>																				
COMMENTS	<p>Note:</p> <p>When technology is commercial, most industrial boiler manufacturers will be capable of fabricating fluidized-bed combustion systems.</p> <p>* NA = Not Applicable.</p> <p>(1) Equivalent to \$1.76 - \$2.28/1000 lb. of steam. The costs are derived from Table 11-1; O&M costs equal Item D (unit steam cost) less the total of fuel, capital, taxes, and administration costs.</p>																				

CHAPTER 11

FLUIDIZED-BED COMBUSTION

Section 11.1: Introduction

When a stream of gas (or liquid) is passed upward through a bed of particles at an increasing rate, a stage is reached when the weight of the particles is overcome by the force exerted by the fluid flowing upward. At this stage the system resembles a violently boiling liquid and the bed of particles is considered to be fluidized. This state of fluidization is stable over a wide range of gas (or liquid) fluidizing velocities, and the fluidized or fluid bed is characterized by a high degree of particle mixing, excellent mass transfer between the fluidizing gas (or liquid) and the particles, and excellent heat transfer between the gas (or liquid), the particles, the sidewalls and immersed heat-transfer surfaces.

The fluidized-bed combustion of coal involves the combustion of coarse (1/4-in.) particles of coal at atmospheric or elevated pressures in a fluidized bed of dolomite or limestone and coal ash at temperatures of 1500-1750°F. This operating temperature is below the ash-softening point. The SO_2 generated during combustion is absorbed by the limestone ("sorbent"), and spent sorbent and coal ash are removed from the bed. The low operating temperature reduces NO_x formation and also reduces the volatilization of alkali salts (such as sodium and potassium sulfate) in the fuel. To maintain the bed temperature at the desired level, the heat generated by the combustion is removed from the bed by immersing cooling tubes carrying a working fluid such as water, steam, or air in the bed. Alternatively, bed temperature can be maintained by supplying a substantial quantity of excess air to the bed to carry away the heat. Heat in the gases leaving the fluidized bed can also be transferred to the working fluid.

In contrast, the conventional combustion of coal involves the combustion of very small particles (74 microns) of pulverized coal entrained in the combustion air. Only the smaller boiler sizes can economically burn coarse coal on a moving grate. The conventional system operates at high temperatures -- typically 1800-2200°F in boiler furnaces where the mineral matter in the coal is removed as dry ash, or up to

2700°F in boiler furnaces where the mineral matter is removed as a molten slag. The SO_2 generated during combustion has to be removed by flue-gas desulfurization (scrubbing) techniques. Because of higher operating temperatures, NO_x formation is difficult to control, but is achieved by controlling combustion air. The heat generated by coal combustion is transferred to the working fluid -- steam/water -- in different sections of the boiler, e.g., superheater, reheater, preheater, convection sections, economizer, water-wall sections and the air preheater.

Fluidized-bed combustion of coal can be used for generating industrial process heat and electricity on a variety of thermodynamic cycles. Generally, these cycles fall into two broad categories: cycles based on a single working fluid--air, combustion products, or steam--and cycles based on two working fluids--steam and combustion products. The cycles are labelled open or closed depending on whether the working fluid is used just once or whether it is recycled. Examples are: simple open cycle (heat is transferred to combustion products and excess air in a pressurized fluid bed; electricity is generated in a gas turbine); closed cycle (heat is transferred to steam or gas in the cooling tubes immersed in the bed; electricity is generated in a steam/gas turbine); and combined cycle (in pressurized fluid-bed combustion, the flue gases are expanded in a gas turbine while heat from the gas turbine exhaust and from the fluidized bed is transferred into a steam cycle).

Fluidized-bed boilers are in the early stage of large-scale testing and demonstration in the United States. Because of this, predictions of efficiency and cost cannot be made with certainty. Even with an accelerated testing program, fluidized-bed boilers are not expected to be in widespread commercial use until 1985 or 1990⁽¹⁾ and might be delayed even longer. However, a few manufacturers of industrial-scale fluidized-bed boilers are offering these boilers "commercially," i.e., under guarantees or warranties similar to those for conventional boilers. Under such warranties, the seller of the boiler does not assume any contingent liability and is not liable for any loss of production should such a loss

result from non-performance of the fluidized-bed boiler. Thus it is not surprising that few, if any, such boilers have been ordered at this time except for further testing and demonstration.

In the long run, it appears that simpler fluidized-bed boiler systems may be better suited than conventional boilers with scrubbers for small- to medium-scale applications where they potentially offer a relatively compact and simple system for the generation of steam, and perhaps lower cost. However, costs of coal distribution and handling will have a major effect on the economics of these smaller systems. For large power-generating systems, these systems offer, at best, modest improvements in power generation efficiency or in cost over conventional systems.⁽²⁾ In this area, the more complex pressurized fluid-bed boilers and combined cycles appear to be more promising in terms of efficiency, but their success is contingent on the availability of a combination of high-temperature particulate removal techniques and improved reliability of gas turbine technology.

With respect to larger systems, a TVA report⁽²⁾ concludes: "When uncertainties are included, the estimated cost of electricity for the three alternatives [conventional boiler with flue gas desulfurization, atmospheric fluidized bed combustion, and pressurized fluidized-bed combustion] is so close that all are considered to be within the competitive range for further considerations." In contrast to flue gas scrubbing, which produces a wet sludge, fluidized-bed coal combustion produces a dry granular waste. Future solid waste regulations will change the cost of disposal of wet and dry wastes and may affect the ranking. However, if this waste is considered to contain hazardous pollutants, it is likely that both types of wastes will require similar disposal strategies and involve similar disposal costs.

Section 11.2: Technical Discussion

A. Advantages

Combustion of coal in fluidized beds has been under investigation for about 20-25 years. The aim of many of the earlier processes was to utilize high-ash coal fines (very small coal particles -- typically minus

28 mesh -- not acceptable for grate burning) without incurring the high costs of grinding for pulverized coal firing.⁽³⁾ The aim of the processes of current interest is to utilize the superior heat and mass transfer properties of the fluidized bed in order to burn coal while absorbing SO_2 in the combustor.

The expected advantages of fluidized-bed combustion are the following:

1. The SO_x emissions are reduced by adding limestone or dolomite to the bed; NO_x emissions are reduced because of lower combustion temperatures.
2. Costs are lowered, because a wider range of fuels can be used. These include high-ash, low-rank coals, sludge from secondary treatment of sewage, wood wastes and other biomass materials, and wastes from sulfite pulping of wood.
3. Capital costs would be lower than for conventional boilers with scrubbing because of higher heat-transfer coefficients and the resulting compactness of size. In addition, it is expected that fluidized-bed boilers with a capacity up to 250,000 lb/hr of steam could be shop-fabricated and shipped by rail.⁽¹⁾
4. The combustor operates at high efficiency at lower combustion temperatures. Therefore, there is less volatilization and melting of minor components such as alkali metal compounds. This results in less emission of trace inorganic species and reduced fouling of heat-transfer surfaces.
5. Grinding costs are lower since a fluidized bed requires coarser coal than conventional pulverized coal firing.

However, as described later in this section, all aspects of fluidized-bed combustion are undergoing intensive study. In light of data accumulated so far, it appears that while the advantages mentioned above can probably be realized, some tradeoffs are necessary in order to achieve these advantages. These tradeoffs occur in the following areas:

1. Range of operating temperatures: High temperatures are preferred for rapid and complete combustion, but lower temperatures are necessary for SO_2 absorption and to prevent slagging or melting of coal ash constituents. The usual approach has been to operate below the CaSO_4 decomposition temperature (1800°F) and to maximize carbon utilization by recirculating fine particles from the primary reactor, or to provide a second-stage reactor for burning up the carbon associated with particles that have been elutriated from the bed. For larger-scale boilers, efficient utilization of carbon is important. For smaller boilers, the loss of some unburned carbon to the solid-waste streams is less important. While some fluidized-bed combustors have operated under agglomerating ash conditions (e.g., the Igni-fluid boiler⁽⁴⁾), most of the current designs incorporate SO_2 absorption in the bed and avoid ash agglomeration. These considerations result in operating temperatures in the range of $1500\text{--}1750^\circ\text{F}$. This temperature limits the thermodynamic efficiency of power generation cycles based on fluidized beds to about the same level as that obtained in modern conventional systems.

On the other hand, NO_x emissions are not a problem. Limited data obtained with pressurized fluid beds indicate that NO_x emissions are about $0.2 \text{ lb}/10^6 \text{ Btu}$ compared to the New Source Performance Standards of $0.7 \text{ lb}/10^6 \text{ Btu}$.⁽⁵⁾ More data are needed to confirm these low levels of NO_x emissions and the effect of high excess air.

2. SO_x removal:⁽⁵⁾ SO_x is removed by formation of CaSO_4 by reaction with limestone or dolomite in an oxidizing environment. The bed temperature has to be below the decomposition temperature of CaSO_4 . It has been found that dolomite is more efficient (from the stoichiometric viewpoint) than limestone as an absorbent, but that in both cases about two to three times the stoichiometric amount of calcium oxide

is required. Pressurized fluid beds are somewhat more efficient, and typical efficiencies are more than 90% sulfur capture for dolomite at stoichiometric ratios around 2. When limestone is used, the sulfur capture efficiency is lower and varies with the type of limestone. In atmospheric fluid beds, tests were conducted to determine limestone addition to give SO_2 emissions of $1.2 \text{ lb } \text{SO}_2 / 10^6 \text{ Btu}$. The results indicate that calcium/sulfur ratios of 2.5 to 4.4 or more are required.⁽⁶⁾ It has been found that the addition of salt (NaCl) decreases limestone requirements, presumably by opening of pores, but may lead to some agglomeration within the bed and possibly to superheater tube corrosion. The long-term effect of salt on fouling and corrosion in the fluidized-bed combustor is not known. In general, these high calcium/sulfur ratios result in an increase in operating costs when the absorbent is used on a once-through basis. Because of this, regenerative systems which remove SO_2 from CaSO_4 via thermal decomposition or other chemical reactions are also being studied. Such regenerative systems are more complex, requiring a multiplicity of fluidized-bed reactors, and consequently involve higher capital costs. Regeneration will increase the efficiency of sorbent utilization but lower fuel efficiency. A simple schematic of a fluidized-bed combustor without regeneration is given in Figure 11-1.⁽¹⁾

3. Erosion and corrosion: There appear to be relatively few data on the performance of boiler tubes in an abrasive environment such as a fluidized bed. However, this is not considered to be an area of major concern at the present time as the operating units do not show signs of

- Combustion Pressure - close to atmospheric (usually balanced draft)
- Bed Temperature - 1500-1750°F
- Gas Velocity - 2 to 12 ft/sec
- Bed Material - limestone or dolomite, or inert material for low-sulfur fuels not requiring sulfur capture
- Fuel - coal, fuel oil, bark and wood wastes, coke, char, etc.

SOURCE: Reference 1.

FIGURE 11-1 SCHEMATIC DIAGRAM OF ATMOSPHERIC PRESSURE FLUIDIZED-BED COMBUSTION BOILER

material loss. Corrosion of superheater tubes is an uncertainty, even though it is believed that conventional superheater tube materials will be adequate. EPRI-sponsored work shows significant corrosion in the vicinity of coal injection points.⁽⁶⁾

4. Selection of bed material: The physical integrity of the bed material (limestone or dolomite) is important. Bed material which disintegrates into smaller particles under the thermal and mechanical shocks is unsuitable. The degree to which different deposits of limestone and dolomite comply with these requirements and the efficiency of SO₂ absorption are not well known. Data on the behavior of different limestones are being compiled.⁽⁷⁾
5. Adaptability to different fuels: While a variety of fuels can be burned in a fluidized bed (e.g., sewage sludge, black liquor from sulfite pulping of wood, low-rank coals, sulfide minerals, and so on), a fluidized bed designed for one fuel will require considerable modification in fuel handling/fuel injection equipment to switch to another fuel. Coal injectors are a big technical problem area. Other materials such as sewage sludge and pulping wastes are usually injected as a slurry through nozzles.

Comprehensive descriptions of the various developmental programs are available.^(5,8) We present below a description of some of the major avenues of research.

B. Atmospheric Pressure Systems

These systems are attractive for industrial-scale boilers (about 300,000 lb/hr steam) and can be built in utility-scale units. Typical conditions for atmospheric pressure systems, based on Reference 9, and Arthur D. Little, Inc., estimates, are:

Particle Size	1/4 in.
Bed Depth	2-8 ft
Superficial Velocity*	2-12 ft/sec
Bed Temperature	1400-1700°F
Excess Air	10-50%

The major program in this area is the 30-MW module constructed by Pope, Evans and Robbins at Rivesville, West Virginia, under DOE funding.⁽⁸⁾ In this plant, steam is generated via water tubes immersed in the bed. In addition, the unit has water-tube walls, a convection economizer, and a separate carbon burn-up cell.

Other programs^(8,10) in this area include a series of projects on industrial applications of fluid-bed technology for producing saturated steam, superheated steam, high-temperature air, and process heat in this country (e.g., Alliance, Ohio) and abroad (especially in the U.K.), a component test and integration unit at Morgantown Energy Research Center, and a turbine technology unit (external combustor for gas turbine) at Oak Ridge National Laboratory. Additional work is in progress on plant conversions and on the utilization of anthracite waste.

C. Pressurized Systems

Pressurized systems appear to utilize the dolomite sorbent more effectively than the atmospheric pressure systems.⁽¹¹⁾ A critical problem area in the pressurized system is the need for cleaning particulates from the combustion gases at high temperatures in order to prevent buildup on or the corrosion/erosion of the gas turbine blades.** Typical conditions, based on Reference 11, and Arthur D. Little, Inc., estimates, are:

Particle Size	1/4 in.
Bed Depth	6-15 ft
Superficial Velocity	2-10 ft/sec

* Superficial velocity is defined as the volumetric flow of the fluidizing gas at operating conditions divided by the cross-sectional area of the bed.

** When the fluidized bed gasses power a gas turbine.

Bed Temperature	1500-1800°F
Excess Air	10-300%
Pressure	100-200 psi

Research on these systems is being conducted by Westinghouse, General Electric, British Coal Utilization Research Association (BCURA), Combustion Systems Ltd., Exxon, Argonne National Laboratory, Oak Ridge National Laboratory, Combustion Power, Curtiss-Wright and others.

D. Control

The ability of a combustor to alter combustion rates in response to changing loads (e.g., turndown) is important in most applications. The fluidized bed boiler can adapt to changing loads in a variety of ways, depending on the type of fluidized-bed combustor in question and the degree of change required.

The heat transfer to the coils immersed in the bed can be varied by varying the bed temperature. This approach is likely to achieve a turndown of only about 60-65% of full load in pressurized systems.⁽¹²⁾ For larger load variations, the fluidized bed can be compartmentalized so that successive compartments can be shut off. Alternatively, since the heat-transfer coefficient to the tubes immersed in the bed is greater than that to the tubes in the freeboard, change can be achieved by altering the height of the bed by adding or removing solids from the bed. In addition, it has been suggested that compressed air storage can be used so that during periods of peak demand, the stored air can be used for fluidization and all of the gas turbine's^{*} output used for power generation.⁽¹²⁾

E. Startup

Any fluidized-bed installation requires an auxiliary fuel (oil, natural gas, or perhaps pulverized coal) for heating the bed material to the operating temperature before coal injection can begin. Similarly, an auxiliary power source is required to drive the fluidizing air fan.

* Driven by the combustion gasses of the fluidized bed.

Section 11.3: Economics Discussion

A fluidized-bed combustor, whether used in industrial-scale or utility-scale boilers, produces steam of a certain quality and is able to reduce emissions to the environment by the use of a sorbent for SO_2 control and by selecting suitable operating conditions for NO_x control. In terms of system performance, electric power plants based on atmospheric pressure combustors are projected to have heat rates of about 9500 Btu/kWh and steam conditions of 2400 psi/1000°F/1000°F, (steam pressure/superheater temperature/reheater temperature). The pressurized system at low excess air is projected to have heat rates of 8600 Btu/kWh, while the high-excess-air combustor offers a heat rate of about 9100 Btu/kWh. Modern conventional plants meeting environmental standards have heat rates around 9100 Btu/kWh.⁽¹³⁾ Thus, fluidized-bed boilers compete directly against modern conventional boilers with their associated stack-gas scrubbing system.

Economic comparisons between these two systems are difficult because the different technologies involved represent different levels of technological development and therefore of technical risk. Conventional boilers represent a mature technology and the potential for technical improvement is low. While accurate estimates for conventional systems are available, these estimates are often tailored and optimized for a specific type of coal. Costs can vary significantly as coal type and other site-specific factors are varied.⁽¹⁴⁾ Stack gas scrubbing and other environmental control technologies are still on a learning curve and fall in an intermediate category where the costs of certain systems are known fairly accurately, but where a significant potential for improvement and for cost reduction exists. Fluidized-bed boilers represent a higher level of risk at present because long-term operating data are still unavailable. Only these data can answer questions about reliability, maintenance costs, applicability to different coal types, etc., which have an important bearing on the relative economic performance of this technology.

Economic comparisons currently available between conventional and fluidized-bed technology typically show capital cost savings with fluidized-bed technology to be in the range of 10-20% and operating cost savings to be in the range of 5-15%.^(2,12) Table 11-1 presents estimates prepared by the Exxon Research and Engineering Company for EPA/FEA/ERDA for industrial size boilers. The original estimates were in 1975 dollars. These have been updated to 1977 dollars using a uniform inflation factor of 1.12. (This factor corresponds to the changes in the Marshall & Stevens equipment cost index over this period and is equivalent to an inflation rate of 5.1% per year.) In these estimates, an attempt was made by Exxon R&E to discount for technical risk by increasing capital investment by a "process development allowance." However, this allowance is relatively small (20% for the unproven parts of the fluidized-bed system) and might not be adequate. While analogies are hazardous, it is instructive to recall that early estimates of the costs of flue gas desulfurization typically were less than the actual costs of successful systems by a factor of 2.

Table 11-1 indicates that, on an industrial boiler scale, a fluidized-bed boiler will require 20-30% less capital investment and have a 15-20% lower operating cost. However, in our opinion, this difference cannot be considered significant at this time. In analyzing the components of the operating cost, it can be seen that the major impact is due to the difference in capital investment. Of lesser importance is the difference in labor costs between the two systems. It is not clear why a conventional proven system will require more labor than a somewhat similar unproven system.

TABLE 11-1

COMPARISON OF A FLUIDIZED-BED-BOILER VS. A CONVENTIONAL
BOILER WITH FLUE GAS DESULFURIZATION

A. Basis: Independent industrial boiler plant; 1977 dollars; high-sulfur (3.5% S) coal; capacity factor, 90%.

	<u>Fluidized-Bed Combustion</u>		<u>Conventional with Scrubber</u>	
Steam Rate (1000 lb/hr)	<u>100</u>	<u>400</u>	<u>100</u>	<u>400</u>
Annual Steam Prod. (10^6 lb/year)	788.4	3,153.6	788.4	3,153.6
<u>B. Capital Investment</u> (\$ $\times 10^6$)				
Fuel Handling	2.0	3.0	2.0	3.0
Boiler and Stack	6.5 ⁽¹⁾	16.0 ⁽¹⁾	6.1 ⁽²⁾	17.9 ⁽²⁾
Environmental and Waste Disposal	<u>2.1</u>	<u>5.6</u>	<u>5.2</u>	<u>13.7</u>
Total Investment	10.6	24.6	13.3	34.6
<u>C. Operating Cost</u> (¢/1000 lb of Steam, Excluding Fuel Cost)				
Labor	63	20	85	27
Materials	50	41	37	29
Utilities	28	28	34	38
Local Taxes, Administration, etc.	40	24	50	33
Ash/Sludge Disposal	20	20	25	25
Boiler Feed Water	<u>67</u>	<u>67</u>	<u>67</u>	<u>67</u>
Sub-Total - Direct Operating Costs	268	200	298	219
Capital Charges at 14% ⁽³⁾	<u>188</u>	<u>109</u>	<u>236</u>	<u>154</u>
Total (Ex. Fuel Cost)	456	309	534	373
Fuel @ \$1.00/ 10^6 Btu (85% efficiency)	<u>141</u>	<u>141</u>	<u>141</u>	<u>141</u>
<u>D. Unit Steam Cost</u> ⁽⁴⁾ (¢/1000 lb)	597	450	675	514

(1) Fluidized-bed boiler investments include a 20% "process development" allowance.

(2) Scrubber investments include a 10% "process development" allowance.

(3) "Normal" capital charge for industrial plants of 20% has been reduced by 6% inflation to convert to a constant dollar basis.

(4) Steam @ 1200 Btu/lb.

NOTE: Data escalated to 1977 dollars using a factor of 1.12 by Arthur D. Little, Inc.

SOURCE: Reference 1.

Section 11.4: Limitations

The principal limitations on the use of fluidized-bed combustors on the industrial boiler scale include:

- environmental regulations, and
- cost and reliability of fluidized bed boilers.

The Clean Air Act Amendments of 1977 require the use of Best Available Control Technology for the permanent control of emissions of air pollutants to the atmosphere. At the current state of knowledge, fluidized beds are relatively inefficient in their use of sorbent, and this inefficiency appears to increase as the degree of sulfur dioxide removal is increased. While the efficiency of the sorbent can be increased by adding sodium chloride, the side effects of these additions have not been fully evaluated. Thus, it appears that any New Source Performance Standard which requires a high degree of SO₂ capture would tend to decrease the cost advantages of this technology.

The extensive large-scale pilot plant and demonstration program will be able to answer the questions that will ultimately define the costs of this technology vis-à-vis conventional boilers with flue-gas desulfurization. These questions are related to corrosion, erosion, materials of construction, startup and shutdown problems, maintenance requirements, carbon utilization efficiency, sorbent efficiency, turn-down, etc. As noted earlier, while fluidized-bed combustion is a relatively flexible technology, the tradeoffs required involve additional equipment whose ramifications are not always included in the available cost estimates. For example, while there are various strategies available for achieving system turndown, it is not clear that the incremental cost for achieving a degree of control comparable to conventional systems has been included in the current cost estimates.

In the near term, fluidized-bed boilers are likely to be installed for the generation of process steam in industrial applications. As noted earlier, fluidized-bed boilers of approximately 250,000 lb/hr of steam can be shop-fabricated and shipped by rail, resulting in significantly lower cost than a conventional boiler of this size which would require field fabrication/assembly.

REFERENCES

1. Farmer, M.H., et al. Application of Fluidized Bed Technology to Industrial Boilers. Report prepared by Exxon Research and Engineering Company for the Environmental Protection Agency, the Federal Energy Administration and the Energy Research and Development Administration, January 1977. NTIS Report No. EPA 600/7-77-011.
2. Reese, J.T. Utility Boiler Design/Cost Comparison: Fluidized Bed Combustion versus Flue Gas Desulfurization. Prepared by Tennessee Valley Authority for Environmental Protection Agency, November 1977. NTIS Report No. EPA 600/7-77-126.
3. Skinner, D.F. The Fluidized Combustion of Coal. London: Mills and Boon, Ltd., 1971.
4. Squires, A.M. "Clean Power from Coal." Science 169(3949):821, August 28, 1970.
5. MITRE Corporation. Proceedings of the Fifth International Conference on Fluidized Bed Combustion, coordinated by the METREK Division, Washington, D.C., December 12-14, 1977. Vol. II. pp. 594-624, 544-558, 875-890.
6. "Fossil Fuel and Advanced Systems Division R&D Report." EPRI Journal, May 1977. pp. 39 ff.
7. Vogel, G.J., et al. Supportive Studies in Fluidized Bed Combustion, Annual Report July 1976 - June 1977. Report prepared by Argonne National Laboratory, 1977. NTIS Report No. ANL/CEN/FE-77-3.
8. Energy Research and Development Administration. Fossil Energy Program Report, July 1975 - October 1976. September 1977. NTIS Report No. ERDA-77-70. pp.70 ff.
9. MITRE Corporation. Proceedings of the Fifth International Conference on Fluidized Bed Combustion, coordinated by the METREK Division, Washington, D.C., December 12-14, 1977. Vol. II. pp. 157-374.
10. MITRE Corporation. Proceedings of the Fifth International Conference on Fluidized Bed Combustion, coordinated by the METREK Division, Washington, D.C., December 12-14, 1977. Vol. I. pp. 31-99.
11. MITRE Corporation. Proceedings of the Fifth International Conference on Fluidized Bed Combustion, coordinated by the METREK Division, Washington, D.C., December 12-14, 1977. Vol. II. pp. 385-458.

REFERENCES (continued)

12. Locke, H.B., et al. "Fluidized Beds: Clean Heat and Power Cycles Using Fluidized Combustion." Chemical Engineer, November 1975. pp. 667 ff.
13. Keairns, D.L. "Fluidized Bed Combustion." Proceedings of the Third Annual Conference on Coal Gasification and Liquefaction, University of Pittsburgh, Pittsburgh, Pennsylvania, August 1976.
14. Bechtel Corporation. Coal Fired Power Plant Capital Cost Estimates. Report to the Electric Power Research Institute, January 1977.

CHAPTER 12
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: ON-SITE COMBUSTION TURBINE-POWERED ENERGY SYSTEMS</p> <p>DESCRIPTION: A gas turbine drives an electric generator, and heat from exhaust gases is recovered in a waste heat recovery boiler.</p> <p>POTENTIAL USER CLASSES: Industrial complexes, hospitals, shopping centers, commercial installations, city districts.</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Mature; present research efforts concentrated on the use of coal and/or coal derived fuels.</p>																																						
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td><td>.7-25</td><td>same</td><td>same</td></tr> <tr> <td>(Btu/hr) SECONDARY (i)</td><td>$3.8 \times 10^6 - 1.4 \times 10^8$</td><td>same</td><td>same</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY</td><td>$3.4 \times 10^6 - 1.2 \times 10^8$</td><td>same</td><td>same</td></tr> <tr> <td>(Btu) SECONDARY</td><td>$1.8 \times 10^{10} - 6.6 \times 10^{11}$</td><td>same</td><td>same</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.55</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.40-.70</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN): (ii)</td><td>.20-.33</td><td>same</td><td>same</td></tr> <tr> <td>(iii)</td><td>.50-.70</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Distillate fuel AMOUNT NEEDED PER UNIT OUTPUT: Distillate fuel 0.063-0.120 gal/kWh Natural gas Natural gas 7.8-21 scf/kWh (iv)</p> <p>ALTERNATIVE FUEL(S): Coal and/or coal-derived fuel (v) IS SYSTEM READILY CONVERTIBLE? Yes (distillate fuel to gas and vice versa)</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Has quick response to load fluctuations; specific fuel consumption (gal/kWh) increases at low loads.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Yes; larger installations can sell power to central utility.</p> <p>TECHNICALLY PRACTICAL? Yes; the units have rapid load response and can be automatically paralleled.</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Not necessary</p> <p>SYSTEM:</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.7-25	same	same	(Btu/hr) SECONDARY (i)	$3.8 \times 10^6 - 1.4 \times 10^8$	same	same	UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	$3.4 \times 10^6 - 1.2 \times 10^8$	same	same	(Btu) SECONDARY	$1.8 \times 10^{10} - 6.6 \times 10^{11}$	same	same	AVERAGE EFFECTIVE CAPACITY FACTOR:	.55	same	same	RANGE OF CAPACITY FACTORS:	.40-.70	same	same	EFFICIENCY (BTU OUT/BTU IN): (ii)	.20-.33	same	same	(iii)	.50-.70	same	same
	1977	1985	2000																																				
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.7-25	same	same																																				
(Btu/hr) SECONDARY (i)	$3.8 \times 10^6 - 1.4 \times 10^8$	same	same																																				
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	$3.4 \times 10^6 - 1.2 \times 10^8$	same	same																																				
(Btu) SECONDARY	$1.8 \times 10^{10} - 6.6 \times 10^{11}$	same	same																																				
AVERAGE EFFECTIVE CAPACITY FACTOR:	.55	same	same																																				
RANGE OF CAPACITY FACTORS:	.40-.70	same	same																																				
EFFICIENCY (BTU OUT/BTU IN): (ii)	.20-.33	same	same																																				
(iii)	.50-.70	same	same																																				
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th><th>1977</th><th>1985</th><th>2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (iii)</td><td>215-415</td><td>same</td><td>same</td></tr> <tr> <td>(INCLUDES: Turbine, electric generator, heat recovery equip., controls, installation)</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)</td><td>.002-.004 (vi)</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>2-4 mos (vii)</td><td>same</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (iii)	215-415	same	same	(INCLUDES: Turbine, electric generator, heat recovery equip., controls, installation)				AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.002-.004 (vi)	same	same	CONSTRUCTION PERIOD:	2-4 mos (vii)	same	same																
	1977	1985	2000																																				
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (iii)	215-415	same	same																																				
(INCLUDES: Turbine, electric generator, heat recovery equip., controls, installation)																																							
AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.002-.004 (vi)	same	same																																				
CONSTRUCTION PERIOD:	2-4 mos (vii)	same	same																																				
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION:</p> <p>About 85 manufacturers, mostly in the U.S. and U.K.</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: No emission problems from burning of natural gas or distillate fuels but possible higher emission levels of NO_x and particulates from burning of coal-derived fuels; noise level of up to 90 dB(A) which acoustic shielding can reduce to 50-55 dB(A). (The average background noise in an office is about 50 dB(A).)</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS:</p> <p>Local, state, and federal regulation on electric rates affects economic viability of such systems.</p>																																						
COMMENTS	<p>(i) Hot water and/or steam; assuming 70% fuel utilization (overall efficiency for heat recovery plus electrical power generation), 27% electric generation efficiency.</p> <p>(ii) Electric generation only.</p> <p>(iii) Electric generation and heat recovery.</p> <p>(iv) The ranges reflect variations in unit efficiencies and fuel Btu content.</p> <p>(v) Research project sponsored by DOE.</p> <p>(vi) See page 12-28.</p> <p>(vii) From delivery of the unit to startup.</p>																																						

CHAPTER 12

ON-SITE COMBUSTION TURBINE-POWERED ENERGY SYSTEMS

Section 12.1: Introduction

A. Development of the Technology

The principles of present combustion turbines* were first established by Dr. F. Stalze in 1872 and the first turbine in the United States was built at Cornell University in 1902.⁽¹⁾ The development of the technology, however, was delayed for several decades by the lack of knowledge in the field of aerodynamics and the unavailability of materials to withstand turbine inlet temperatures necessary for adequate overall cycle efficiencies.

Major technological breakthroughs in the field were pioneered in the 1930-1940 decade by Brown-Boveri, Sulzer Brothers, and Escher Wyss in Switzerland and by Air Commodore Frank Whittle in England.⁽²⁾ In the United States, the Navy Department began serious investigations into the feasibility of using combustion turbines for aviation and marine propulsion in 1938. Today there are about 85 manufacturers of combustion turbines in the United States, England, Switzerland, France, Germany, the USSR, and Japan with a preponderance being in the United States and England.⁽³⁾

The Department of Energy is currently sponsoring a series of development and product-improvement research projects directed toward the clean burning of residual oils and coal-derived fuels in combustion turbines. Among the participant team leaders are Westinghouse/General Motors, General Electric, Curtiss-Wright, and United Technologies.⁽⁴⁾

*Commonly known as gas turbine; referred to here as combustion turbine to emphasize that the unit is capable of burning gaseous or liquid fuels.

B. General Characteristics

Combustion turbines are relatively small and lightweight; hence they require only modest space and foundation. They do not require any cooling water and are therefore suitable for installation in arid climates. Combustion turbines can be controlled remotely and run unattended, and they permit rapid startup and loading.

C. Applications

Smaller combustion turbines are predominantly used for military and commercial aviation and their discussion is beyond the scope of the present report. The oil and gas industries are major users of land-based combustion turbines for powering compressors in gas pipeline transmission, compressor and pump drives in refineries and oil-well pressurization, as well as for electric power generation on offshore gas and oil platforms. The electric utility industry is another major user of combustion turbines for power generation, particularly as peak load and emergency backup units.

In total energy system applications, the combustion turbine drives an electric generator, and the exhaust heat is recovered in a waste-heat recovery boiler for on-site application. Potential markets for this mode of operation include industrial complexes, shopping centers, commercial facilities, and city districts.

Section 12.2: Technical Discussion

A. The Thermodynamic Cycle

Operation of a combustion turbine is based on the Brayton cycle. The simple combustion turbine consists of a compressor, a combustion chamber, and a turbine. Figure 12-1 is a schematic representation of these components. The compressor takes in the ambient air and pressurizes it. The pressurized air enters the combustion chamber where the fuel is injected. The combustion process heats the pressurized air which is allowed to expand in a turbine to a lower pressure, producing work. The air is then discharged at a lower temperature. The efficiency of the

FIGURE 12-1 SCHEMATIC OF AN OPEN-CYCLE COMBUSTION TURBINE

FIGURE 12-2 SCHEMATIC OF AN OPEN-CYCLE COMBUSTION TURBINE WITH REGENERATOR

Brayton cycle is a function of the ratio of the compressor's output pressure to its input pressure (P_2/P_1 in Figure 12-1) and the ratio of the turbine inlet temperature to the ambient air temperature. It is possible to increase the efficiency of the cycle by utilizing the heat of the exhaust of the turbine to increase the temperature of the pressurized air entering the combustion chamber; this is done by installing a counter-flow heat exchanger called a regenerator.

Figure 12-2 illustrates a regenerative cycle. The influence of the compressor's pressure ratio on the ideal Brayton and regenerative cycles* is shown in Figure 12-3.⁽⁵⁾ The reason for the negative effect of the pressure ratio on the regenerative cycle is that, in contrast to the Brayton cycle, the efficiency depends not only on the compressor's pressure ratio but also on the ratio of minimum temperature, T_1 , at the compressor's intake to the maximum temperature, T_2 , at the combustion chamber's outlet.⁽⁶⁾

We must also note that the efficiencies given in Figure 12-3 are for the ideal cycles with ideal (i.e., no losses) turbines and compressors. Actual combustion turbines have efficiencies much lower than the 40% to 50% shown in Figure 12-3. One reason for the low efficiency of the combustion turbines (ideal or actual) is the large amount of work required by the compressor. For example, in an ideal combustion turbine, the compressor might require 40% of the turbine work; if the same pressure and temperature conditions are applied to an actual combustion turbine, the compressor work is as much as 60% of the turbine output and only 40% is delivered as net work.

The turbine inlet temperature is also an important factor in the efficiency of a combustion turbine. Figure 12-4 illustrates the actual efficiency of a combustion turbine for various turbine inlet temperatures as a function of the pressure ratio. The structural integrity of blade material sets the upper limit on the turbine inlet temperature. In general, the thermal efficiency of combustion turbines built today falls somewhere in the range of 20-33%.⁽³⁾

*Figure 12-3 indicates the ideal (maximum possible) efficiencies obtainable. By comparing the ideal cycle efficiencies with the actual cycle efficiencies, the reader can judge the improvements to actual (non-ideal) system efficiencies that may result from component development.

* Pressure ratio refers to $\frac{P_2}{P_1}$ in Figure 12-2.

SOURCE: Reference 5.

FIGURE 12-3 CYCLE EFFICIENCY AS A FUNCTION OF PRESSURE FOR THE IDEAL BRAYTON AND REGENERATIVE CYCLES

* Pressure ratio refers to $\frac{P_2}{P_1}$ in Figure 12-2.

SOURCE: Reference 3.

FIGURE 12-4 EFFECTS OF PRESSURE RATIO ON THERMAL EFFICIENCY FOR A SIMPLE GAS-TURBINE CYCLE AT VARIOUS TURBINE INLET TEMPERATURES (T_2)

B. Components

Major components of a combustion turbine consist of the compressor, the combustion chamber, and the turbine.

The primary requirement of a combustion turbine compressor is that it handle a large volume of air at the highest possible efficiency. Multi-stage axial flow compressors are used in all the larger combustion turbines. Centrifugal compressors, which are simpler and more rugged than axial flow compressors, have lower efficiencies and are not readily adaptable to multi-staging. Compression ratios of the compressors used in land-based combustion turbine installations vary from 6:1 to 12:1, depending upon the size and design of the unit.

The combustion chamber has the function of bringing the gas to the desired uniform temperature with minimum impurities and minimum loss of pressure. In open-cycle combustion turbines, fuel is introduced into the combustion chamber under pressure and is mixed with the combustion air (primary air) at an air-fuel ratio of 50:1 to 70:1.⁽⁷⁾ The gases of combustion are cooled by mixing them with the balance of the air (cooling or secondary air) which flows between the inner and the outer shells of the combustion chamber. The degree of cooling of the combustion gases is determined by the permissible maximum temperature that the blades of the first stage of the turbine can be exposed to. The mixing of cool air and hot combustion gases further complicates the design of the combustion chamber since it must produce a uniform turbine inlet temperature. Figure 12-5 shows a diagram of a combustion chamber.

The basic design and operating characteristics of the turbines used in combustion turbines are similar, in principle, to those for turbines used in steam plants; however, the blade materials used in the combustion turbine have to be able to withstand corrosion and erosion due to products of combustion. Figure 12-6 shows a sketch of the major components of a gas turbine assembly.

SOURCE: Reference 8.

FIGURE 12-5 REVERSE-FLOW COMBUSTION CHAMBER FOR GENERAL ELECTRIC SERIES 5001 GAS TURBINES

SOURCE: Reference 9.

FIGURE 12-6 SKETCH OF A 900-kW GAS TURBINE

C. Fuels

Since the blades of the turbine are directly exposed to the products of combustion, these products must be free of impurities that can cause corrosion, and the residual solids must be small enough to avoid erosion of the turbine blades. Natural gas, refinery gas, and distillate oils all meet the required fuel specifications for the combustion turbines. Residual fuels must be treated to avoid hot-ash corrosion and deposition. (Vanadium pentoxide and sodium sulfate are principal condensates that cause corrosion and deposition in the 1250°F to 1500°F range.)⁽¹⁰⁾ Fuel additives, such as magnesium oxide, magnesium sulfate and aluminum silicate, are sometimes used to reduce the adverse effects of combustion products.

Because of the relatively low efficiency of combustion turbines, the heat rate and fuel consumption are generally high.

D. Heat Recovery

Although in the past, land-based combustion turbines have been used primarily for mechanical power production, increasing fuel prices have encouraged the recovery of the exhaust heat in order to increase the overall efficiency of the cycle. This is done by installing a waste heat recovery boiler in the exhaust path of the turbine. The steam produced in the waste heat boiler may be used for several purposes, such as space conditioning or process use.

E. Output Power Range

Today combustion turbines are manufactured anywhere in the range of 35 kW to 85 MW.^(11,12) This range includes small emergency power units as well as large utility installations. For on-site power applications, the output power range varies from 700 to 25,000 kW. It should be noted here that the power output of a particular unit increases with the increase of the ambient pressure (decreasing elevation above sea level),

and decreases as the ambient temperature rises; this is due to the inherent characteristics of the thermodynamic cycle (Brayton cycle) of the combustion turbine. Manufacturers typically specify the output power and heat rate of their units at standard pressure and temperature, with zero inlet and exhaust pressure losses, and supply charts and graphs for temperature, altitude, and inlet and exhaust pressure loss corrections. Figure 12-7 shows the altitude correction factor for the Model GS-4000 (3000-kW) gas turbine (manufactured by the Solar Division of International Harvester). Figures 12-8 and 12-9 show the effect of ambient temperature on total power output of the same unit for gaseous and liquid fuels.⁽⁹⁾

The size of the units for a particular on-site power generation application depends primarily on the total electric load of the system, and for a cogeneration scheme, the thermal requirements of the site may determine the size of the unit. For reasons of reliability as well as routine (maintenance, overhaul) and forced outages, it is recommended that the total load be distributed over several units in order to have reserve capacity.

Heat rates for combustion turbines are considerably higher than those for diesel engines. In general, the heat rate of combustion turbines is somewhere in the range of 10,000 Btu/kWh (33% efficiency) to 17,000 Btu/kWh (20% efficiency).^(11,13) One manufacturer has built an exceptionally efficient combustion turbine with a heat rate of 8553 Btu/kWh (40% efficiency). The principal design characteristics of this unit include extraordinarily good component efficiency and attention to their aerodynamic details, high pressure ratio (12:1), and efficient cooling of the turbine blades, which allows turbine inlet temperatures as high as 2100°F, while maintaining a metal temperature (blade temperature) of 1525°F.⁽¹⁴⁾

The heat value of fuels used for combustion turbines is in the range of 18,000 to 20,000 Btu/lb for liquid fuels (corresponding to 142,200 Btu/gal to 158,000 Btu/gal, assuming an average specific gravity of 7.09 lb/gal), and in the range of 800 to 1000 Btu/scf (standard cubic foot) for gas. Therefore, the liquid fuel consumption of an engine with 20% efficiency (17,000 Btu/kWh) and with 18,000 Btu/lb fuel

* 101.3 kPa = 14.7 psia = atmospheric pressure at sea level.

** Available power output at a given altitude is equal to the rated power output at sea level multiplied by the value of δ for that altitude.

SOURCE: Reference 9.

FIGURE 12-7 ALTITUDE CORRECTION** FOR OUTPUT POWER
(International Harvester-Solar's Model
GS-4000, 3000-kW Rated)

SOURCE: Reference 9.

FIGURE 12-8 TYPICAL MAXIMUM OUTPUT POWER VARIATION AS A FUNCTION OF INLET AIR TEMPERATURE FOR UNITS BURNING NATURAL GAS (Solar GS-4000, 3000-kW Rated)

SOURCE: Reference 9.

FIGURE 12-9 TYPICAL MAXIMUM OUTPUT POWER VARIATION AS A FUNCTION OF INLET AIR TEMPERATURE FOR UNITS BURNING LIQUID FUEL (Solar GS-4000, 3000-kW Rated)

is about 0.12 gal/kWh, and an engine using 20,000 Btu/lb (158,000 Btu/gal) fuel and which is 33% efficient (10,000 Btu/kWh) consumes about 0.063 gal/kWh of fuel. If the combustion turbine uses natural gas with a heat value of 800 Btu/scf and is only 20% efficient, it consumes 21 scf/kWh; for an efficiency of 33% and gas with a heat value of 1,100 Btu/scf, the consumption is 7.8 scf/kWh.

It is important to note that part-load operation of a combustion turbine causes a considerable heat rate, and hence fuel consumption, penalty. On one occasion,⁽¹⁵⁾ a 6445-hp (4834-kW) gas turbine was operated at below 50% maximum rated output and required a 20% increase in specific fuel consumption;* this test represents the best part-load operation achieved to date.

It is possible to improve the overall fuel utilization in a combustion turbine through the recovery of the exhaust waste heat. Waste heat recovery reduces the mechanical power output of the combustion turbine, and the size of the waste heat recovery boiler is determined by the electric generation efficiency, overall fuel utilization, and the cost of the heat recovery equipment. Also, in units fired with liquid fuels containing sulfur compounds, the exhaust temperature must be kept above the sulfur compound's dewpoint temperature to avoid the formation of deposits on surfaces; such a limitation generally does not exist with units fired with natural gas. Heat recovery can result in 50-70% fuel utilization rates. In a particular total energy project⁽¹³⁾ (electric generation/district heating), an overall fuel utilization as high as 81% and a power generation of 24% were achieved, meaning that it was possible to recover as much as 75% of the discharged exhaust heat. Without heat recovery, an electric generation efficiency of 33% was recorded.

* lb of fuel/hp-hr.

Section 12.3: Economics Discussion

A. Market Opportunities

The principal application of land-based combustion turbines is for electrical generation or mechanical power production (continuous or standby). The oil and gas industries as well as the utility industry are major users of larger (10-MW and higher) combustion turbines. For on-site total energy applications, the feasibility of installing combustion turbines depends on:

- availability of power from a utility;
- peak and average electrical load of the site;
- peak and average thermal load of the site;
- daily load profile and overall load factor* of the on-site plant;
- relationship of the capital, fuel, and operating cost of on-site-generated energy to the cost of purchased power; and
- comparative assessment of: (a) conventional boilers for heat generation and purchasing electric power from a utility, (b) steam-condensing cycle for electric and thermal energy generation, and (c) diesels with waste heat recovery.

The plant load factor is an important consideration in combustion turbine installations since the specific fuel consumption increases rapidly with part-load operation. Potential users include:

- industrial complexes,
- shopping centers,
- commercial installations, and
- city districts.

* Load factor is the ratio of the average hourly demand to the maximum hourly demand during the same period.

B. Costs

Costs associated with combustion turbine installations include capital and installation costs, fuel cost, maintenance costs, and other operating costs. Capital costs of combustion turbines (compressor, turbine, generator) range from \$100/kW to \$225/kW,^(16,17,18) depending on the manufacturer and the accessory equipment required (e.g., sound-attenuating enclosure, weather-proof enclosure, filtration for sand, dust, and salt). Installation costs range from \$40/kW to \$65/kW, depending on the size of the machine, geographic location, and necessary site preparations. Therefore, the cost of installed combustion turbines without heat recovery ranges from \$140/kW to \$290/kW,^(16,17,18) with \$240/kW being the cost of a typical installed unit. The addition of heat recovery equipment will increase the installed cost by \$75/kW to \$125/kW, depending on the equipment. Hence the cost of combustion turbines with heat recovery is in the range of \$215/kW to \$415/kW, and \$340/kW is the cost of a typical installation with heat recovery.^(16,19) Since the unit prices vary with efficiency, accessories, and machine design, it is difficult to generalize about unit prices (\$/kW). However, unit prices generally decrease with increasing machine capacity.

In Section 12.2-E, the fuel consumption rate was estimated to be from 0.063 gal/kWh to 0.120 gal/kWh for liquid-fuel-fired units and from 7.8 scf/kWh to 21 scf/kWh for gas-fired units. The price of fuels varies greatly according to geographic location and depends also on the Btu content. For the purposes of this chapter, assuming fuel prices of \$0.50/gal for liquid fuel and \$3.00/Mcf (million ft³) for gas, fuel consumption costs will be \$0.032/kWh to \$0.060/kWh for units using distillate fuels, and \$0.023/kWh to \$0.063/kWh for units using natural gas.

On the average, a combustion turbine on continuous duty requires major overhaul after every 20,000 hours of operation. Units on standby that go through frequent startups and shutdowns may require overhaul more frequently. A unit can have several overhauls during its lifetime. Therefore, it can have an operating lifetime of 80,000-100,000 hours.⁽¹⁶⁾ The cost of operation and maintenance of combustion turbines (excluding fuel cost and salaries for a full-time operator, but including labor and parts

for routine maintenance and periodic overhaul) is estimated to be about \$0.002/kWh to 0.004/kWh.⁽¹⁶⁾ Therefore, the total operating cost (fuel, operation, maintenance) is in the range of \$0.025/kWh to \$0.067/kWh for combustion turbines burning natural gas or distillate fuels. It is not possible at this time to estimate the operation and maintenance costs for combustion turbines burning coal-derived fuels, but it is certain that they will be higher.

Section 12.4: Limitations

Factors limiting the application of combustion turbine total energy systems include economic disincentives of declining electric block rates (set by the utilities and regulatory agencies for large consumers) and environmental considerations (noise and air pollutions).

The declining utility block rate system discourages customers with large electric demand from generating their own electricity. Several load management programs (to reduce peak electricity demand) are under way around the country, and the trend is toward different rate systems, in particular to time-of-day rate schedules. However, it is not clear to what extent these would be applied to large industrial and commercial users, and it remains to be seen how future electric rate systems will affect the cost-benefit analysis of on-site cogeneration. From the environmental viewpoint, areas of concern are the noise level of combustion turbines and their effect on local air quality. In general, gas turbines are designed to achieve a sound level of approximately 90 dB(A)* just outside the enclosure, in accordance with the near-field noise standards;⁽²⁰⁾ this results in a far-field (about 400 ft) noise level of around 50-55 dB(A). In order to reduce the noise level to about 45 dB(A) (the noise level for a quiet street) requires additional buildings and barriers.

Present design of combustion turbines requires burning of clean fuels (natural gas or distillate fuels); as a result, the emissions generally conform with the provisions of the Clean Air Act. There is, however, considerable research and development under way to produce coal-

* dB(A) = frequency-weighted decibel scale for industrial purposes.

derived fuels as a substitute for imported oil. The extent to which coal-derived fuels can be "cleaned up" is yet to be determined. The emissions from such fuels may result in particulate, sulfur compound, and NO_x discharges above the levels set by the Environmental Protection Agency or by state and local regulatory agencies, and hence limit the use of such fuels in combustion turbines for on-site energy systems.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Gill, P.W., et al. Fundamentals of Internal Combustion Engines. Annapolis, Maryland: The U.S. Naval Institute, 1964. p. 16.1.
2. Gill, P.W., et al. Fundamentals of Internal Combustion Engines. Annapolis, Maryland: The U.S. Naval Institute, 1964, p. 16.3.
3. Morrisson, R. "Gas Turbines." Standard Handbook for Mechanical Engineers. 7th ed. Edited by T. Baumeister. New York: McGraw-Hill, 1967. p. 9-150.
4. "Gas Turbine Development Program for the Next Decade." Gas Turbine International, 17(5):24, September - October 1976.
5. Van Wylen, G.J., et al. Fundamentals of Classical Thermodynamics. New York: John Wiley and Sons, Inc., 1965. p. 303.
6. Van Wylen, G.J., et al. Fundamentals of Classical Thermodynamics. New York: John Wiley and Sons, Inc., 1965. p. 308.
7. Morrisson, R. "Gas Turbines." Standard Handbook for Mechanical Engineers. 7th ed. Edited by T. Baumeister. New York: McGraw-Hill, 1967. p. 9-153.
8. General Electric Co., Schenectady, New York. Product literature, Series 5001 gas turbines. 1976.
9. International Harvester, Solar Division. "Gas Turbine Generator Sets." Handbook for Architects and Consulting Engineers. San Diego, California, 1976.
10. Morrisson, R. "Gas Turbines." Standard Handbook for Mechanical Engineers. 7th ed. Edited by T. Baumeister. New York: McGraw-Hill, 1967. p. 9-155.
11. "Stand-by Gas Turbine Specification." Turbomachinery International, January-February 1978. pp. 32 ff.
12. General Electric Company, Wellesley, Massachusetts. Private correspondence. March 1978.
13. Schmoch, O.R. Land Gas Turbines 10-80 MW. London: Diesel Engineers and Users Association, 1973. Publication 355.
14. Detroit Diesel Allison, Box 894, Dept. U-5, Indianapolis, Indiana 46206. Private correspondence. March 1978. See also Reference 11, p. 34.
15. "Model 570 Rates 6445 hp with 8473 Btu Heat Rate." Gas Turbine World 7(3):58, March 1977.

REFERENCES (continued)

16. General Electric Company, Wellesley, Massachusetts; Curtiss-Wright Corporation, Wood Ridge, New Jersey; Avco-Lycoming Division, Stratford, Connecticut; Solar Division of International Harvester, Boston, Massachusetts. Private correspondence. March 1978.
17. "Competitive Bids and Orders." Gas Turbine World 7(7):5, July 1977.
18. "Competitive Bids and Orders." Gas Turbine World 8(1):5, January 1978.
19. "3-5 MW Plant to Pay for Itself in Three to Four Years." Gas Turbine World 7(5):20, May 1977.
20. "Noise Control Economics of Siting Gas Turbine Power Plants." Gas Turbine International 18(3):22, May - June 1977.

TECHNOLOGY SUMMARY SHEET

GENERAL -	<p>TECHNOLOGY TITLE: ON-SITE DIESEL-POWERED ENERGY SYSTEMS</p> <p>DESCRIPTION: Diesel engine drives an electric generator and recovered engine heat provides thermal energy.</p> <p>POTENTIAL USER CLASSES: Apartment complexes, hospitals, hotels & motels, industrial facilities, shopping centers</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Mature</p>																																							
TECHNICAL	<table border="1" data-bbox="858 474 1362 730"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY</td> <td>100-3000</td> <td>same</td> <td>same</td> </tr> <tr> <td>(Btu/hr) SECONDARY (i)</td> <td>3.7×10^5-11.1×10^6</td> <td>same</td> <td>same</td> </tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY (ii)</td> <td>4.4×10^5-13.2×10^6</td> <td>same</td> <td>same</td> </tr> <tr> <td>(Btu) SECONDARY (ii)</td> <td>1.6×10^9-4.8×10^{10}</td> <td>same</td> <td>same</td> </tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td> <td>.5</td> <td>same</td> <td>same</td> </tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td> <td>.4-.6</td> <td>same</td> <td>same</td> </tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN): (iii)</td> <td>.30-.40</td> <td>same</td> <td>same</td> </tr> <tr> <td>(iv)</td> <td>.55-.75</td> <td>same</td> <td>same</td> </tr> </tbody> </table> <p>PRIMARY FUEL(S): Diesel fuel, natural gas AMOUNT NEEDED PER UNIT OUTPUT: 0.053-0.080 gal/kWh for liquid fuels</p> <p>ALTERNATIVE FUEL(S): Residual and coal-derived fuels IS SYSTEM READILY CONVERTIBLE? Gas engines will require engine modifications by the manufacturer.</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Load following and base load operation</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Depends on the premium paid to the utility for the connection and additional cost for a sub-station (if needed) vs. the cost of additional standby units for added reliability</p> <p>TECHNICALLY PRACTICAL? Yes, provided proper frequency control devices and circuit breakers are installed in order to prevent system-wide instability in case unit malfunctions.</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Not necessary</p> <p>SYSTEM:</p>					1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY	100-3000	same	same	(Btu/hr) SECONDARY (i)	3.7×10^5 - 11.1×10^6	same	same	UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY (ii)	4.4×10^5 - 13.2×10^6	same	same	(Btu) SECONDARY (ii)	1.6×10^9 - 4.8×10^{10}	same	same	AVERAGE EFFECTIVE CAPACITY FACTOR:	.5	same	same	RANGE OF CAPACITY FACTORS:	.4-.6	same	same	EFFICIENCY (BTU OUT/BTU IN): (iii)	.30-.40	same	same	(iv)	.55-.75	same	same
	1977	1985	2000																																					
UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY	100-3000	same	same																																					
(Btu/hr) SECONDARY (i)	3.7×10^5 - 11.1×10^6	same	same																																					
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY (ii)	4.4×10^5 - 13.2×10^6	same	same																																					
(Btu) SECONDARY (ii)	1.6×10^9 - 4.8×10^{10}	same	same																																					
AVERAGE EFFECTIVE CAPACITY FACTOR:	.5	same	same																																					
RANGE OF CAPACITY FACTORS:	.4-.6	same	same																																					
EFFICIENCY (BTU OUT/BTU IN): (iii)	.30-.40	same	same																																					
(iv)	.55-.75	same	same																																					
ECONOMIC	<table border="1" data-bbox="852 1155 1362 1323"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: diesel engine, electric generator, control devices, and heat recovery equipment and installation)</td> <td>250-525</td> <td>same</td> <td>same</td> </tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, excluding fuel)</td> <td>.0075-.0090^(v)</td> <td>same</td> <td>same</td> </tr> <tr> <td>CONSTRUCTION PERIOD:</td> <td>2-4 mos^(vi)</td> <td>same</td> <td>same</td> </tr> </tbody> </table>					1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: diesel engine, electric generator, control devices, and heat recovery equipment and installation)	250-525	same	same	AVERAGE UNIT O&M: (\$/kWh, excluding fuel)	.0075-.0090 ^(v)	same	same	CONSTRUCTION PERIOD:	2-4 mos ^(vi)	same	same																				
	1977	1985	2000																																					
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: diesel engine, electric generator, control devices, and heat recovery equipment and installation)	250-525	same	same																																					
AVERAGE UNIT O&M: (\$/kWh, excluding fuel)	.0075-.0090 ^(v)	same	same																																					
CONSTRUCTION PERIOD:	2-4 mos ^(vi)	same	same																																					
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Commercially available in large quantities</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: Nitrogen oxides and particulates from exhaust emissions; future legislation for emission standards is possible.</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: Electricity rate structure affects the economic incentive for such systems.</p>																																							
COMMENTS	<p>(i) Hot water and/or steam; assuming 35% electric efficiency, 10% radiative losses, 55% of energy input contained in jacket water and exhaust, with 80% of the jacket water heat and 50% of the exhaust heat recovered.</p> <p>(ii) Assuming capacity factor of 0.5.</p> <p>(iii) Without heat recovery.</p> <p>(iv) With heat recovery.</p> <p>(v) See page 13-9.</p> <p>(vi) From unit delivery to startup.</p>																																							

CE

CHAPTER 13

ON-SITE DIESEL-POWERED ENERGY SYSTEMS

Section 13.1: Introduction

The diesel engine^{*} was patented in 1892 by Dr. Rudolph Diesel in Germany. The first successful commercial diesel engine was installed in St. Louis, Missouri, in 1898, and by 1910 the diesel engine had become a common source of shaft horsepower. Major engine design improvements were the advent of turbocharging in the mid-1940's and charge-air cooling in the 1950's. Since the 1960's, U.S. development has been limited to obtaining higher operating pressures and engine speeds.⁽¹⁾ European diesel development (Sulzer, Brown Boveri, MAN) resulted in lower-speed residual fuel engines. Today diesel engine sizes vary anywhere from small portable 1.6-kW sets to large 40,000-kW units installed by utilities for power generation. For on-site power applications, unit sizes usually fall in the 100-kW to 3000-kW range.

Although the diesel engine was developed primarily for mechanical power, recovery of the engine heat from the jacket's cooling water and the exhaust gases is practical and, for on-site power generation application, is in fact desirable. In terms of mechanical power production, the efficiency of diesels varies from 30-40% (at 80% rated capacity), depending on the size and design of the engine. In addition, part-load efficiencies down to as low as one-third full power remain high. Recovery of the otherwise rejected engine heat can increase the overall energy efficiency of the engine to the range of 55-75%, depending on the type and degree of sophistication of heat-recovery equipment.

* Here diesel engine refers to engines operating on liquid fuels - diesel fuel, bunker C residual fuel, etc. Diesel engines that operate by burning natural gas are referred to as gas engines and differ only in the fuel injection system.

The feasibility of installing diesel engines for on-site electric power and heat generation should be based on a careful analysis of the total energy requirements, the balance between the demand for electricity (or mechanical power) and the demand for heat, the plant load factor, and the relationship of fuel cost to the cost of energy available from other sources.

Section 13.2: Technical Discussion

A. Design Principles

The diesel engine is an internal-combustion reciprocating engine. It is similar to the standard automobile engine, with the principal difference being in the way in which the fuel-air mixture is ignited. In the automobile engine, ignition is accomplished by means of an electrical spark, whereas in the diesel the compression stroke itself produces a sufficiently high pressure (hence temperature) to cause ignition. The diesel engine requires higher compression ratios than the gasoline engine (in the range of 12:1 to 20:1 for the diesel as compared to the range of 5:1 to 10:1 for a gasoline engine).⁽²⁾

The engine speed is a principal design consideration. There are three basic categories: low-speed (80-300 rpm), medium-speed (300-900 rpm), and high-speed (900 rpm and up). Low-speed diesels are used primarily for marine propulsion and sometimes for power generation in large central stations. Medium-speed engines are used for marine propulsion and standby or continuous-duty power generation. High-speed engines are used almost exclusively for automotive, locomotive, and on-site power generation.

Almost all of the diesel engines manufactured today in the United States operate on a four-stroke cycle comprised of:

1. Intake stroke -- in which the moving piston draws in fresh air;
2. Compression stroke -- in which air is compressed by the upward moving piston and fuel is injected into the cylinder;
3. Power stroke -- in which combustion of the mixture of air and atomized fuel occurs and the expanding

gases force the piston down; and

4. Exhaust stroke -- in which the products of combustion are forced out through the exhaust valve by the upward-moving piston.

The lower-speed European diesels operate on a two-stroke cycle combining intake and compression strokes in one stroke and power and exhaust strokes in another stroke.

B. Output Power Range

There are many diesel engine manufacturers in the United States and around the world, some with more than half a century of experience in the field. Diesel engines built today range from small 1.6-kW sets (Bernard four-stroke air-cooled, manufactured by Bermotor of England) to large units of more than 40,000 kW, e.g., the lower-speed, two-stroke cycle version built primarily by Sulzer and MAN in Europe which are mainly used for marine propulsion. In the United States, DeLaval of Oakland, California, manufactures medium-speed engines of up to 10,000 kW; these are the largest units built in this country.

On-site generating stations (for electric power or combined electric power and heat), similar to large utilities, must be able to modify their output to meet the daily and weekly load profiles. For this and for reasons of reliability, it is necessary to distribute the total load (mechanical and heat) of a facility among several generating units. Load centers suitable for diesel-powered prime movers (schools, hospitals, shopping centers, etc.) usually install several units in the range of 100-3000 kW each. ^(3,4)

The units must be optimized for simultaneous delivery of heat and electricity to the load. This is necessary since it is not possible to reduce the electrical energy output of the machine in order to gain more thermal energy and vice versa.

C. Units Without Heat Recovery

Diesel engines without heat recovery are used to drive electric generators, compressed air and air conditioning compressors, and deep-well

pumps, and to pump gas in distribution lines as well as in ship propulsion systems. Units can provide either continuous or standby power. If continuous service is required, it is necessary to provide reserve capacity so that the system will still have full-load supply capability in case of a forced outage or routine maintenance of one unit. Standby units can usually be brought on-line in less than 5 seconds for units up to about 300 kW and in less than 30 seconds for units on the order of 1000 kW. This applies to units on "hot" standby where the engine oil is maintained at operating temperature. Larger units of several megawatts and upward require several minutes for startup and power delivery.

An internal combustion reciprocating engine is the most efficient heat engine available today for converting the energy content of a prime fuel into shaft horsepower. Today the efficiencies of diesel engines vary from 30% to approximately 40%^(3,4,5) (corresponding to heat rates of about 11,000 to 8500 Btu/kWh, respectively), depending on the size, design, manufacturer, age, and maintenance condition of the unit.

D. Units With Heat Recovery

In a diesel engine, as mentioned above, about 30-40% of the total available fuel energy is utilized in the form of mechanical power; the remaining energy appears in the form of heat, and if not recovered, is rejected to the environment. Of the 60-70% heat energy, about 5-10% is radiated away by the engine and is not recoverable; of the remaining 50-60%, about one-half is contained in the jacket cooling water and the other half in the exhaust gases from the engine.^(6,7) While all of the heat in the jacket water is available for recovery, only part (approximately one-half) of the heat energy of exhaust gases can be recovered. (If the temperature of the exhaust gases drops below the sulfur compounds' dewpoint temperatures, sulfur compound deposits are formed on the surfaces.)

Jacket water heat can be recovered by three methods:

- the hot water system,
- the hot water and steam system
(with flash boiler), and
- the ebullient system.

In the hot water system, jacket water with an outlet temperature of about 180°F is passed through a heat exchanger (water tube type) for additional heat recovery from the exhaust gases, and then passed through a shell-and-tube heat exchanger, where the heat is transferred to a secondary circuit. It is possible to obtain higher hot water temperatures by operating the jacket cooling-water loop under pressure (to prevent boiling of water in the loop). Typical pressures range from 5 psig to 20 psig with outlet temperatures in the 220°F to 250°F range.

The hot water and steam system incorporates many features of the hot water system, plus a flash boiler for generating low-pressure (2 to 8 psig) steam.⁽⁷⁾ The jacket water circuit is always maintained at higher pressures than the boiler to prevent boiling within the engine. Steam is generated in the flash boiler and in the piping to the boiler, because of the pressure differential that exists in the system by design.

The ebullient system utilizes the heat of vaporization to remove rejected heat from the engine. Heat removal is based on natural water circulation within the engine due to inlet and outlet water density differential. Steam is not separated within the engine but is removed through the water passages, along with the high-temperature water, to a steam separator located at a higher elevation than that of the engine. Figure 13-1 shows the ebullient system and the various components of a two-unit diesel package with both jacket-water heat recovery (ebullient) and exhaust-gas heat recovery.

E. Control

The control system and switchgear for an on-site diesel installation vary in the degree of sophistication and depend on the type of facility and load served by the plant. The basic consideration is whether the plant is controlled manually or automatically. In the case of installations

Ebullient System

SOURCE: References 4 and 7.

FIGURE 13-1 SCHEMATIC DIAGRAMS OF EBULLIENT HEAT RECOVERY (Top) AND A TWO-UNIT DIESEL PACKAGE WITH EBULLIENT AND EXHAUST HEAT RECOVERY (Bottom)

operated manually, the plant attendant places units on or off service as demanded and load-sharing is controlled by manual adjustments.

In automatically controlled installations, units are placed on or off service by signals from an automatic load-sensing device and are paralleled by an electric governor.⁽³⁾ In addition to customary safety controls (e.g., reverse current trips, low oil pressure, high oil temperature, overspeed shutdown, etc.), unattended installations should have automatic shutdown capability for high oil temperatures, low coolant level, or excessive vibration, as well as remote read-out devices to indicate when other than routine servicing is required.

F. Reliability

Over the years, the diesel engine has gone through many stages of design and manufacturing improvement, along with millions of hours of operating experience. It represents a fully developed and mature technology with the availability of marine-type engines (slow-speed, two-stroke) approaching more than 90%.

A recent study⁽¹⁾ has indicated that the average rate of failure to start is one in every 650 attempts; 80% of these failures were due to electrical faults (the starting system), and only random mechanical faults were noted. In continuous operation, world-wide failure rate is reported⁽¹⁾ to be one "stoppage" in every 2500 hours, for a forced outage rate of 3.5 per year. The majority of the forced outages are associated with fuel system failure.

System reliability can be improved by dividing the total load into "essential" and "non-essential" parts, so that, in case of a partial outage, non-essential load can be dropped and the essential load can be served without interruption.

Section 13.3: Economics Discussion

A. Market Opportunities

The diesel-powered on-site energy system has many applications, including:

- Apartment complexes,
- Hospitals,
- Hotels and motels,
- Industrial facilities,
- Schools,
- Office buildings, and
- Shopping centers.

Careful cost/benefit analysis is required in each case and factors affecting the outcome include:

- relationship of the capital, fuel, and operating cost of generated energy to the cost of purchased power;
- the plant load factor; and
- the balance between mechanical and thermal energy requirements.

Lower cost of generated power than purchased power, a high plant load factor, and about equal mechanical and thermal loads will result in a favorable rate of return on investment for on-site diesel power.

B. Costs

Costs associated with an on-site diesel installation include capital cost, fuel cost, maintenance cost, and other operating costs. High-speed engines cost less, have a higher fuel consumption rate, and shorter life than medium- and low-speed engines. Low-speed engines have a slightly better fuel consumption rate than medium-speed engines. Also, low-speed engines can burn heavy bunker C fuels, whereas high-speed engines require cleaner diesel fuel.

Capital costs for high-to-medium-speed engines (including heat recovery boiler) range from \$250 to \$525 per installed kW, depending on the size (a few hundred to a few thousand kW), engine design, speed, and control equipment furnished, ^(3,4,8) with \$375 per installed kW being a typical cost within this range. The high end in this range applies to unattended medium-speed installations, and the low end applies to high-speed units.

Fuel costs relate to the efficiency as well as to the fuel acceptability of the engine. For an efficiency range of 30-40%, corresponding to heat rates of 11,000 to 8500 Btu/kWh, fuel consumption is calculated below.

Assuming the heat content of diesel fuel to be 18,835 to 19,376 Btu/lb and a fuel density of 7.4 to 8.2 lb/gal, a heat value of 140,000 to 160,000 Btu/gal for diesel fuel is obtained. At 8500 Btu/kWh, fuel consumption will be in the 0.053-0.060 gal/kWh range; for 11,000 Btu/kWh, fuel consumption increases to 0.070-0.080 gal/kWh, depending on the heat value of the fuel. A reasonable rate for the bulk delivery of diesel fuel is about \$0.40/gal. Therefore, the fuel cost will range from a low of \$0.0212/kWh for an engine with 40% efficiency (mechanical) and burning 160,000 Btu/gal fuel, to a high of \$0.032/kWh for an engine with 30% efficiency (mechanical) and burning 140,000 Btu/gal fuel.

With the addition of a heat recovery boiler, the overall efficiency increases to the 55-70% range. The economic benefit can be estimated by calculating the cost of the fuel required to heat the water directly, taking into account the cost of the boiler.

The maintenance and other operating costs of an on-site diesel installation are not so easily estimated as fuel and initial capital costs. However, maintenance and service contracts, which are being offered at an increasing rate, can be used to estimate these costs. Maintenance contracts vary from agreements for complete service and maintenance (including engine rebuilding), covering all parts and labor, to contracts for routine maintenance (oil change and check, filter change, etc.). The contracts are generally written for a definite period of time, usually for 10 years, which in fact corresponds to the average life of a diesel engine. A complete service and maintenance contract costs in the range of \$0.0075-\$0.0090/kWh.^(3,4) Therefore, the total fuel and operating costs (including fuel, operation, and maintenance, but excluding salaries of full-time operators) of an on-site diesel plant vary from approximately \$0.029/kWh to \$0.041/kWh, with \$0.034/kWh being typical within this range.

Section 13.4: Limitations

Factors limiting the use of diesel engines for on-site power and heat generation include economic disincentives of declining electric rates set by utilities and regulatory agencies, as well as adverse effects of exhaust emissions on local air quality.

The declining utility block rate system is an institutional and economic issue that may discourage customers with large electric demands from generating their own electricity.

As mentioned before, diesel engines are capable of burning natural gas (in which case the engine is referred to as "gas engine") and distillate fuels, as well as heavy residual fuels. The emissions from burning of natural gas and distillate fuels generally conform with the provisions of the Clean Air Act. However, burning of residual fuels or coal-derived fuels^{*} may have adverse effects on local air quality and hence limit the application of diesels for on-site energy systems with such fuels.

*

The Department of Energy has funded research and development projects for the production of clean burning coal-derived fuels.⁽⁹⁾

REFERENCES

1. Shearer, A.B. "The Historical Development and Future Prospects of the Diesel Engine." Diesel Engineering 72(790):155, 1976.
2. Gill, P.W., et al. Fundamentals of Internal Combustion Engines. Annapolis, Maryland: The U.S. Naval Institute, 1964. p. 11.2.
3. Cummins Engine Company, Inc., 100 Allied Drive, Dedham, Massachusetts 02036. Private correspondence. March 1978.
4. Caterpillar Tractor Company, 100 N.E. Adams, Peoria, Illinois 61629. Private correspondence. March 1978.
5. Shearer, A.B. "The Historical Development and Future Prospects of the Diesel Engine." Diesel Engineering 72(790):156, 1976.
6. O'Shea, J.A. "Kalamazoo Adopts Diesel-Based Total Energy." Diesel Engineering 72(788):33, 1976.
7. Jones, R.A. Caterpillar on Total Energy. London: Diesel Engineers and Users Association, 1972. Publication 345.
8. DeLaval Turbine Inc., 550 85th Ave., Oakland, California 94621. Private correspondence. March 1978.
9. Power Systems Division of United Technologies, Inc., 1690 New Britain Ave., Farmington, Connecticut 06032. Private correspondence. February 1978.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

13-12

CHAPTER 14
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: STIRLING ENGINE-POWERED ENERGY SYSTEMS</p> <p>DESCRIPTION: Stirling engines drive an electric generator and engine heat may be recovered for thermal applications.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, and industrial complexes</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Early developmental stages for these applications; prototypes being tested for automotive use</p>																																				
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977⁽ⁱ⁾</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY</td><td>3-100</td><td>3-2000</td><td>same</td></tr> <tr> <td>(Btu/hr) SECONDARY</td><td>.05x10⁵-1.7x10⁵</td><td>.05x10⁵-3.3x10⁶</td><td>same</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY</td><td>1x10⁴-3.5x10⁵</td><td>1x10⁴-7.0x10⁶</td><td>same</td></tr> <tr> <td>(Btu) SECONDARY</td><td>.17x10⁸-6.0x10⁸</td><td>.17x10⁸-120x10⁸</td><td>same</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.4</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.2-.6</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.25-.40⁽ⁱⁱ⁾</td><td>.35-.48⁽ⁱⁱ⁾</td><td>same</td></tr> <tr> <td></td><td>.37-.60⁽ⁱⁱⁱ⁾</td><td>.52-.72⁽ⁱⁱⁱ⁾</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Coal AMOUNT NEEDED PER UNIT OUTPUT: 8500-13,600 Btu/kWh. ⁽ⁱⁱ⁾</p> <p>ALTERNATIVE FUEL(S): Municipal solid waste, woodchips, biogas, low-Btu gas, solar heat IS SYSTEM READILY CONVERTIBLE? Yes, with modification of combustion chamber only</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Steady output is desired for coal or other solid fuels. Output follows load when heater section is directly heated by products of combustion.</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Depends on the premium paid to the utility for the connection and additional cost for a substation (if needed) vs. the cost of additional standby units for added reliability.</p> <p>TECHNICALLY PRACTICAL? Yes, provided proper frequency-control devices and switch-gear are installed.</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Not necessary.</p> <p>SYSTEM:</p>		1977 ⁽ⁱ⁾	1985	2000	UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY	3-100	3-2000	same	(Btu/hr) SECONDARY	.05x10 ⁵ -1.7x10 ⁵	.05x10 ⁵ -3.3x10 ⁶	same	UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	1x10 ⁴ -3.5x10 ⁵	1x10 ⁴ -7.0x10 ⁶	same	(Btu) SECONDARY	.17x10 ⁸ -6.0x10 ⁸	.17x10 ⁸ -120x10 ⁸	same	AVERAGE EFFECTIVE CAPACITY FACTOR:	.4	same	same	RANGE OF CAPACITY FACTORS:	.2-.6	same	same	EFFICIENCY (BTU OUT/BTU IN):	.25-.40 ⁽ⁱⁱ⁾	.35-.48 ⁽ⁱⁱ⁾	same		.37-.60 ⁽ⁱⁱⁱ⁾	.52-.72 ⁽ⁱⁱⁱ⁾	same
	1977 ⁽ⁱ⁾	1985	2000																																		
UNIT POWER OUTPUT CAPACITY: (kW) PRIMARY	3-100	3-2000	same																																		
(Btu/hr) SECONDARY	.05x10 ⁵ -1.7x10 ⁵	.05x10 ⁵ -3.3x10 ⁶	same																																		
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	1x10 ⁴ -3.5x10 ⁵	1x10 ⁴ -7.0x10 ⁶	same																																		
(Btu) SECONDARY	.17x10 ⁸ -6.0x10 ⁸	.17x10 ⁸ -120x10 ⁸	same																																		
AVERAGE EFFECTIVE CAPACITY FACTOR:	.4	same	same																																		
RANGE OF CAPACITY FACTORS:	.2-.6	same	same																																		
EFFICIENCY (BTU OUT/BTU IN):	.25-.40 ⁽ⁱⁱ⁾	.35-.48 ⁽ⁱⁱ⁾	same																																		
	.37-.60 ⁽ⁱⁱⁱ⁾	.52-.72 ⁽ⁱⁱⁱ⁾	same																																		
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)</td><td>(iv)</td><td>290^(v)-655^(vi)</td><td>250^(v)-575^(vi)</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)</td><td>.008</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>(iv)</td><td>2-4 mos</td><td>same</td></tr> </tbody> </table>		1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)	(iv)	290 ^(v) -655 ^(vi)	250 ^(v) -575 ^(vi)	AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.008	same	same	CONSTRUCTION PERIOD:	(iv)	2-4 mos	same																				
	1977	1985	2000																																		
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)	(iv)	290 ^(v) -655 ^(vi)	250 ^(v) -575 ^(vi)																																		
AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.008	same	same																																		
CONSTRUCTION PERIOD:	(iv)	2-4 mos	same																																		
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Can be developed to meet demand if machines become a viable option</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: Stirling engines have flue gases that depend on fuel used; they are expected to be quieter than diesel engines.</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: None</p>																																				
COMMENTS	<p>(i) Only experimental units available.</p> <p>(ii) Without heat recovery.</p> <p>(iii) Heat recovery is assumed to be half of generator output.</p> <p>(iv) No commercial experience at this time.</p> <p>(v) Preliminary estimate of oil-fired engine, complete with generator. ⁽¹²⁾</p> <p>(vi) Preliminary estimate of coal-fired engine, complete with generator. ⁽¹²⁾</p>																																				

CE

CHAPTER 14

STIRLING ENGINE-POWERED ENERGY SYSTEMS

Section 14.1: Introduction

The principles of the Stirling thermal engine were understood long ago, and operating devices based on them were introduced in 1818. Nevertheless, it required modern technology to translate the concept into practical devices that may compete favorably with more established prime movers. For this reason, the Stirling engine is not yet in commercial use and is relatively unfamiliar to the engineering community compared with Otto, Diesel, and Rankine cycle engines. Accordingly, it may be useful to review the development of the Stirling engine, citing reasons for its introduction and until recently its lack of acceptance and growth to a competitive position.

The invention of the Stirling engine was disclosed in a patent issued in 1816 to Robert Stirling, a Scottish minister. The invention record shows a hot-air engine in a configuration remarkable in that it had all the features of a modern unit. Over a period of years, attempts were made to have the engine perform satisfactorily, but the safe working temperature of the cast iron hot parts was exceeded under conditions of practical power output, and they usually failed in less than a year. Stirling's last air engine was replaced by a steam engine in 1847. From then until 1938, steam engines -- and later internal combustion engines -- completely overshadowed the concept of the Stirling engine.

In 1938, the Philips Research Laboratories in Eindhoven, the Netherlands, needed a small, quiet, reliable heat-driven source of power for radios and similar equipment used in parts of the world where batteries and electric power were scarce. In this context, Philips reviewed alternatives and chose the Stirling engine.⁽¹⁾

In the following years, Philips subjected the Stirling system to detailed investigations, and prototypes of many small engines were built. Later, electronic developments and the more widespread availability of batteries made the air engine less attractive as a power source for small electronic equipment. However, the research had provided deeper insight into the potential of higher-power models. Philips has continued research and development on a broad front. Engines demonstrating low vibration, low noise, and high efficiency have been constructed, although their performance has been inhibited by large size, heavy weight, and high cost. The reduction of these non-competitive characteristics has been an evolutionary process, mainly involving improvements in drive mechanisms, seals, and the materials used in the hot parts.

United Stirling, a Swedish firm, holds a license from Philips and has been actively developing a Stirling automotive engine since 1968. Two German licensees, MAN and MWM, have built heavy-duty engines including one demonstrated in a bus.

In 1958, General Motors became the first licensee in the United States, but terminated the contract in 1970.⁽²⁾ In this period, GM constructed and tested a number of engines of different sizes, with 25,000 hours of operating experience. Part of GM's work led to the delivery and test of silent, portable motor generator sets rated at 3 kW.^(3,4)

In about 1970, Ford Motor Company conducted an in-house review of Stirling technology, being motivated by the increasingly stringent exhaust regulations established by the Federal Government and the potential of the external combustion feature of the Stirling engine to accommodate these regulations. As a result of this review, Ford proceeded to negotiate agreements with Philips and with United Stirling⁽⁵⁾ in 1972.

In a joint Ford/United Stirling program, various engineering model versions of a 40-kW (54-hp) engine were tested, including some operation in a Ford Pinto and a Ford Taunus.⁽⁶⁾ Ford/Philips have co-operated to examine and test a 170-hp Stirling engine alternative

to Ford's 351 CID conventional gasoline automobile engine. From 1975 to 1977, Ford worked under contract to DOE^(5,7) on the "80-100 hp Stirling Engine Feasibility Design Study Program."

In October 1977, DOE and Ford signed a cost-shared contract for the development of a Stirling passenger car engine.⁽⁸⁾ DOE is also funding a parallel Stirling engine development program with a team consisting of United Stirling, American Motors, and Mechanical Technology, Inc.⁽⁸⁾

Section 14.2: Technical Discussion

A. Basic Operation

The basic principle of Stirling engine operation is shown in Figure 14-1. First, a cool volume of gas, entrapped by a piston, is compressed (Figure 14-1a) and then heated by an external heat source (Figure 14-1b). As the gas heats, its pressure increases and the piston is driven downward to turn the crankshaft (i.e., to produce mechanical work). After expansion (Figure 14-1c), the gas is cooled by an external cooling source (Figure 14-1d). Its pressure decreases and the gas is once again compressed. Since, as indicated in Figure 14-2, the pressure during the hot expansion is much higher than during the cool compression, there is a net work output from the engine. The complete cycle takes place in one revolution of the crankshaft as opposed to two revolutions required by most conventional engines.

Since exchanging the heating and cooling sources is a cumbersome process, Robert Stirling replaced the alternating use of hot and cold sources by adding a displacer piston. This mechanism allows the heating source to be stationary at one end of the cylinder and the cooling source to be stationary at the other end (Figure 14-3).

One more element -- a regenerator -- is required in an engine which executes the thermodynamic cycle shown in Figure 14-2. The regenerator (Figure 14-3) is located between the fixed heating and cooling sources. It stores the heat that is otherwise wasted during the constant volume

SOURCE: Reference 9.

FIGURE 14-1 SIMPLIFIED ILLUSTRATION OF THE STIRLING
ENGINE CYCLE

FIGURE 14-2 STIRLING ENGINE THERMODYNAMIC CYCLE

SOURCE: Reference 9.

FIGURE 14-3 ILLUSTRATION OF THE IDEAL STIRLING
ENGINE CYCLE WITH DISPLACER PISTON

cooling process and returns it to the gas during the heating phase. Figure 14-3a shows the cooled gas being compressed by the power piston as in a conventional internal combustion engine. In Figure 14-3b, the compressed gas is being heated and its pressure increased because the displacer piston is moving a portion of the gas into the upper or hot part of the displacer section. The pressure increase is felt on the power piston. In Figure 14-3c, the hot high-pressure gas has completed its heating cycle, the displacer piston has completed its stroke, and the power piston, driven by the high-pressure gas, is descending. Figure 14-3d shows the displacer piston moving upward to force the working gas through the regenerator where the gas pressure is reduced as its temperature is lowered. The power piston is now ready to repeat the compression stroke, thus completing the cycle.

B. Ideal Efficiency

The ideal Stirling engine cycle shown in Figure 14-2 consists of:

- an isothermal expansion during which heat is added to the cycle;
- a decrease in temperature and pressure at constant volume which results from moving the gas from the hot zone to the cold zone, during which heat is transferred into a regenerator matrix;
- an isothermal compression during which heat is rejected from the gas; and
- an increase in temperature and pressure at constant volume which results from moving the gas from the cold zone to the hot zone, during which heat is transferred from the regenerator matrix back into the gas.

In an ideal Stirling cycle the efficiency is the same as the Carnot efficiency. In principle, therefore, it can achieve the highest efficiency possible for a heat engine. This efficiency is plotted in Figure 14-4 for a range of maximum and minimum cycle temperatures.* As will be indicated later, most Stirling engines built to date operate at input temperatures, T_H , of about 1400°F and rejection temperatures, T_C , of 170°F. These engines typically have actual efficiencies of 30-35% or only about 50-60% of that of the ideal cycle.

C. Loss Mechanisms

Several loss mechanisms significantly reduce the efficiency of practical Stirling engines from the ideal. These include:

- mechanical losses in the pistons and the drive mechanisms,
- flow losses (pressure drops) resulting from the cyclic motion of the gas between the hot and cold spaces and, in particular, in the regenerator matrix,
- deviations from isothermal compression and expansion processes,
- conduction-heat transfers between the hot and cold ends of the engine cylinders,
- less than 100% regeneration of heat during the constant volume processes, and
- non-ideal relative motion between the power and displacer pistons because of the use of practical drive mechanisms.

* T_H and T_C , respectively, in Figure 14-2.

* Corresponding to T_H and T_C in Figure 14-2.

FIGURE 14-4 IDEAL CYCLE EFFICIENCY OF STIRLING ENGINES

D. Effect of Temperature Levels

As indicated in Figure 14-4, the efficiency of a Stirling engine increases with increasing heat-input temperature levels. Most Stirling engines to date have been limited to working gas temperatures of about 1400°F in part because of high working pressures* (2000-3000 psi). At these temperatures engine efficiencies have typically been in the 30-35% range. If higher-temperature alloys and/or ceramic heaters can allow operation at temperatures of 1900-2200°F, efficiency levels of 42-48% may be obtainable, assuming that a constant percentage of Carnot efficiency is obtained (a conservative assumption).

E. Practical Configurations

In an ideal Stirling cycle engine, the power piston and the displacer would move in a fixed relationship to one another (90° out of phase) in a series of discrete movements. In practice, all engines use mechanisms which allow both the power and displacer pistons to move in a sinusoidal motion which comes close to the movement required of an ideal engine. In many of the earliest engines, this motion was developed by using simple crankshaft arrangements that put the motion of the power and displacer pistons 90° out of phase. A diagram of one of the earliest (1938) hot-air engines developed by Philips is shown in Figure 14-5. In this arrangement the power and displacer systems are contained in a common cylinder and the relative motion between the two pistons is maintained by a crankshaft/rocker arm arrangement.

The type of configuration represented by Figure 14-5 has several drawbacks, including:

- large physical volumes,
- unbalanced motion, and
- requirement for a pressurized crankcase.

* Required to achieve high power densities for automotive propulsion applications.

Diagram of a crank drive as previously used in small hot-air engines. The forked connecting rod of the piston is driven directly by the crankshaft. The displacer connecting rod is actuated by means of a rocker arm, which is driven from a point on the piston connecting rod.

SOURCE: Reference 10.

FIGURE 14-5 STIRLING ENGINE WITH CRANKSHAFT/ROCKER ARM DRIVE

These problems are particularly severe for Stirling engines in vehicular propulsion applications, which require compact physical arrangements, low-vibration operation, and light weight. The latter two problem areas were resolved by the development of the rhombic drive⁽¹⁰⁾ in 1953, which made it possible to design a displacer engine with a non-pressurized crankcase. It also permitted a single-cylinder engine to be fully balanced. The further evolution of practical configurations, however, required innovative as well as evolutionary improvement in the seals, heater heads, and mechanical drives, as described in the following paragraphs.

1. Seals

The coaxial motion of the rhombic drive mechanisms allows for the use of "rollsock" seals to separate the high-pressure working space from the crankcase (Figure 14-6). This seal arrangement can, in principle, maintain the desired separation of working space. However, in practice, it has been one of the greatest sources of unreliability because of hydrogen diffusion through the seal material and mechanical failures after extended (thousands of hours) cyclic motion.

A serious source of concern relative to the rollsock seal is that it fails in a catastrophic mode. Failure can, in effect, disable the engine and lead to a very expensive repair operation. This is one reason for the efforts to develop alternative seal arrangements which allow some (hopefully small) gas leakage, but are not susceptible to catastrophic failure.

2. Heater Heads

Early Stirling engines used heater heads which, at best, used ribs or fins to increase heat transfer between the head and the working gas. These simple heater-head arrangements were not consistent with the high heat fluxes required by high-power-density engines as a result of their use of pressurized hydrogen or helium as the working gas. In

(a) Rollsock Seal Subsystem
(Philips Laboratories)

(b) Oil Pumping Ring
(Philips Laboratories)

SOURCE: Reference 10.

FIGURE 14-6 ROLL SOCK SEAL ARRANGEMENT

a modern Stirling engine, therefore, the heater heads are made from tubes which allow for the very high surface-area-to-volume ratios required by a high power-density engine operating with high-pressure gas.

3. Double-Acting Designs

While the rhombic drive engine has been the primary tool in recent Stirling engine development work, it is still excessively large and complex for use in vehicular propulsion systems. A more recent Stirling engine development, the double-acting piston, results in an engine better suited for automotive use.⁽⁹⁾ Philips has found it is possible to construct an engine of four separate interconnected cylinders, as shown in Figure 14-7, and to control the motion of the pistons by a device which phases them at 90° intervals. With this type of construction, each piston serves as both a power piston and as a displacer for the adjacent cylinder, thus, the name "double-acting."

Arranging the four double-acting piston configuration into a cylinder forms a compact swashplate engine in which the four separate heating sources are grouped into one common source. The four-cylinder swashplate engine is perfectly balanced and has four torque impulses per revolution similar to an eight-cylinder internal combustion engine. However, the magnitude of the impulses is much less than that of an eight-cylinder internal combustion engine.

Figure 14-8 shows a cutaway of a double-acting swashplate engine. At the front of the engine is the single burner which supplies heat to the heater tubes. A rotating preheater, concentric with the burner, recovers waste heat from the exhaust and transfers it to the incoming combustion air. Regenerator and cooling tubes are located between and slightly outboard of the cylinders. A rollsock seal on the piston rod retains the working gas within the engine. The piston rods are connected to the swashplate by lubricated slider bearings.

SOURCE: Reference 11.

FIGURE 14-8 DOUBLE-ACTING SWASHPLATE ENGINE

F. Summary

Most activity in the Stirling engine field is now directed toward further refining the double-acting engine designs similar to the one shown in Figure 14-8. (In-line designs, with crankshafts, are also being considered.) This arrangement results in a highly compact, low-weight engine consistent with the use in vehicular propulsion applications. It is not clear, however, that the design best suited to automotive use is necessarily best for stationary applications in distributed energy systems where size and weight may be less important than efficiency, reliability, multi-fuel capability, maintainability, etc.

Table 14-1 summarizes the performance of many of the Stirling engines developed to date, indicating important parameters such as power level, pressure levels, working gas, temperature levels, and operating speeds. It should be noted that all these engines operate at the high power densities required for vehicular propulsion applications by using high-pressure working gases and high operating speeds.

Section 14.3: Special Attributes of Stirling Engines

The primary potential advantages of the Stirling engine which could make its use attractive in stationary applications are similar to those associated with automotive applications:

- high thermal efficiency,
- good part load characteristics,
- fuel flexibility,
- low emissions,
- good reliability, and
- low noise.

Of these advantages, those which could be most decisive are:

- The possibility of achieving very high efficiency (in the 40-48% range), and

TABLE 14-1

STIRLING ENGINE CHARACTERISTICS

Manufacturer	Philips 4-215	Philips	United Stirling	GMRL* GPU-3	Philips 4-235	Philips 40 hp	United Stirling	MAN- MWM 4-400
Status	Proto * (Ford)	Analy.* (opti- mized)	Proto	Proto	Proto	Proto	Analy. phase I	Proto
Type	Two piston	Piston- disp	Two piston	Piston- disp	Piston- disp	Piston- disp	Two piston	Piston- disp
Working fluid	H ₂	He	H ₂	H ₂	He	H ₂	H ₂	He
Max. Press. $\bar{P}$, psi	2850	3200	2100	1000	3200	2058	2100	1570
No. of cylinders	4	4	4	1	4	1	8	4
Max bhp *	170	275	49	11	200	40	200	120
RPM at max power	4000-4200	1600	3400	3600	3000	1500	2400	1500
Max torque, ft-lbs	300	1287	120	19	253	108	520	475
RPM at max torque	1400	400	955	1200- 2400	1000	900	600	700
Gas temp (hot), °F	1300	~1400	1275	1400 ⁽¹⁾	1260	1200	1325	1170
Gas temp (cold), °F	175	160	160	180	108	60	160	105
Efficiency at max bhp, %	24	30	24	25	30	30	30	29
Max efficiency, %	32 ⁽²⁾	43 ⁽²⁾	30	26.5 ⁽²⁾	31	38	35	32
Power at max efficiency, bhp	75	100	35	~7	~175	23	76	88
RPM at max efficiency	1100-2000	600	2000	1900	1800	725	1200	1000
Weight, ⁽³⁾ lb	750	N/D *	N/D	165 ⁽⁴⁾	1272	N/D	1435	N/D
Dimensions, ⁽³⁾ ft	N/D	4.9 x 4.3 x 2.2	N/D	1.3 x 1.3 x 2.4	4.1 x 1.7 x 3.6	N/D	3.7 x 2.7 x 3.1	5.0 x 2.3 x 4.3
Applications	Auto	Bus	Auto	EPS *	Bus	LRE *	Bus, truck	LRE

(1) Heater-tube wall temperature.

(2) Net brake efficiency accounting for all auxiliaries including cooling fan, combustion blower, and water pump, among others.

(3) Includes all auxiliaries except cooling system with fan and transmission.

(4) Engine and auxiliaries less electrical power generator.

(5) Engine only.

* Abbreviations:

Proto: operating prototype engine; LRE: Laboratory Research Engine; Analy: computer design projection;
 N/D: no data; EPS: electric power supply; bhp: brake horse-power; GMRL: General Motors Research Laboratories.

- The ability to use a multiplicity of fuel forms including coal, municipal wastes, and low Btu gases (from digester systems).

These two issues are discussed further in the following paragraphs.

A. Efficiency

Although Stirling engines with efficiency levels approaching 40% have been built and tested as part of the Philips development programs, most Stirling engines built to date have efficiency levels of about 32-35%. The ideal efficiency of these engines would be as high as 60-70%; therefore, most present engines achieve about 50% of Carnot efficiency. The rather large divergence between obtained efficiency and the ideal is due, in part, to the restrictions placed on the engines as a result of their predominant development for automotive propulsion. This application emphasizes low first costs, high-power-to-volume (or power-to-weight) ratios, and air cooling.

Since these features need not apply so strongly to Stirling engine design for stationary applications, there is greater opportunity to develop a design that maximizes efficiency consistent with a low overall operating cost (capital charges + fuel charges). For Stirling engines operating with a high-capacity factor, efficiency can be a strong economic driving force. For example, one study indicated that increasing operating efficiency for an oil-fired unit from 40% to 42% can justify \$55/hp⁽¹³⁾ in added initial cost when the value of future fuel savings is considered.

The realistic limit on Stirling engine efficiency is difficult to specify. However, extrapolations of existing data indicate that Stirling engine efficiencies of about 45% are a realistic goal, and even higher efficiency levels may be obtainable if ceramic heat exchangers can be developed which allow operation at higher temperatures.

These high efficiency levels are expected to be obtainable in engines covering a wide power range (a few kilowatts to thousands of kilowatts), thus making them viable for a number of distributed energy system applications.

B. Fuel Flexibility

One of the major advantages of the Stirling engine is its ability to use a multiplicity of fuels, including coal, municipal solid wastes, and possibly biomass-derived fuels (wood chips, biogas, etc.).

Figure 14-9 shows a system demonstrated by Philips⁽¹⁴⁾ which would allow for using such a multiplicity of fuels. In this system, the heat is transferred to the Stirling engine by a sodium heat pipe system. (See Chapter 21.) This allows for a uniform, high-flux heat input to the Stirling engine heater without subjecting the heater tubes to the potential corrosion and fouling associated with the combustion of many solid-fuel forms. The heat input to the heat-pipe system can be via heat exchanger configurations (fins, etc.) which are easily cleaned and which have sufficient heat-transfer area to keep down gas-to-metal heat fluxes and temperature drops. It should be noted that the above arrangement is not without problems, particularly those associated with the safety of liquid metal systems and the choice of containment materials.

The fuel flexibility of the Stirling engine in distributed energy system applications is matched only by the Rankine cycle engine alternatives. However, simple Rankine cycle engines using water or organic working fluids would not have nearly the efficiency of the Stirling engine systems, which will be an increasingly important factor in the choice of a power system.

Section 14.4: Applications

The high efficiency and fuel flexibility of Stirling engines make them well suited for stationary applications within distributed energy systems. Their use could be particularly attractive within total energy or "co-generation" systems where reject heat from the engine coolers could also be put to use.⁽¹⁵⁾

SOURCE: Reference 14.

FIGURE 14-9 STIRLING ENGINE CONNECTED TO A FLUIDIZED BED OF COAL BY A HEAT PIPE

Such distributed energy system arrangements (power plus heat) could be utilized over a wide range of sizes from residential units (3 kW)⁽¹⁶⁾ to larger-scale facilities (100 kW and higher) required for industrial, commercial, and residential complexes.

As indicated in Figure 14-10, there are two sources of heat in a Stirling engine which can be used to heat water. The hot water can, in turn, be used for a variety of applications including hot water, space heating and the operation of absorption cooling systems. The two heat sources are:

- Coolers: Stirling engines require coolers where heat is rejected from the cycle during compression. These coolers should operate at as low a temperature as possible so they are attractive sources of energy to preheat domestic or process hot water at temperatures of 90°-140°F.
- Exhaust gases: Even with air preheaters, the exhaust gases from the Stirling engine combustor are at temperatures in excess of 500°F. A portion of this exhaust gas heat could be used to heat water to temperatures in excess of 300°F, thereby increasing the range of applications for this heat source.

In the system illustrated in Figure 14-10, heat is stored at two temperature ranges to provide maximum system flexibility and thermal loads.

A Stirling engine with a recovery system such as that shown in Figure 14-10 can be used within total energy systems. In such systems, both hot water and space heating needs are satisfied by preheating the water at modest temperatures with heat provided by the coolers. Higher temperature water can be provided by the burner exhaust-heat recovery system. Space heating is provided by passing warm water from the coolers through a coil placed in the air distribution system.

SOURCE: Arthur D. Little, Inc.

FIGURE 14-10 SCHEMATIC OF STIRLING ENGINE HEAT-RECOVERY SYSTEM

One advantage of the Stirling engine in total energy systems is that the heat can be extracted from the coolers in the form of hot water at little, or no, additional cost since the coolers must be provided with water cooling, even if the only function of the engine is electric power production. This is in contrast to the situation with diesel or gas turbine engines. In these systems, much of the heat must be extracted by placing waste heat boilers in the hot exhaust-gas streams. These heat exchangers represent an additional cost factor in the overall total energy system.

The above advantage (i.e., ease of extracting heat) is, however, somewhat counterbalanced by the fact that this heat will be primarily at lower temperature levels (200°F), unless significant degradations in engine efficiency are acceptable. This may increase the cost of the energy distribution and storage systems as compared to the diesel and gas turbine options where heat can be readily generated in the form of steam or pressurized hot water in the waste-heat boilers.

Section 14.5: Limitations

A. General Considerations

Efficient Stirling engines can be (and have been) built and operated experimentally for thousands of hours using present technology. The long-term stability of Stirling engines has, however, not been well demonstrated in the field. In particular, the seal arrangement and hydrogen permeation through hot surfaces are recognized reliability issues still requiring resolution. Also, higher-temperature heaters, regenerators, and air preheaters will have to be developed and their reliability demonstrated before the full efficiency potential of the Stirling engine can be realized.

B. Equipment Availability

At present, there are no firms offering Stirling engines on a commercial basis. Although most present developments stress automotive applications, these engines can be adapted for stationary

applications and have been provided on a contractual basis for test and evaluation. Based on the schedule for the automotive Stirling engine program, engines would not be available for that high-production application until the late 1980's or early 1990's. However, Stirling engines could probably be made available for more limited applications within 5-10 years if there were an incentive to do so.

C. Costs

Very few cost data are available on Stirling engines, particularly those being considered for stationary application. When making an economic analysis, several investigators^(11,17) have assumed that the cost of Stirling engines will be about \$50/kW higher than that for comparable diesel engines. This cost differential is justified by the larger number of heat exchangers required by the Stirling engines (as compared with the number required by a diesel) and the need for a sophisticated combustion system. Another study⁽¹²⁾ estimated capital costs of \$290/kW for oil-fired Stirling engines and \$655/kW for coal-fired Stirling engines. It was emphasized, however, that these costs were highly tentative because of the lack of data in this field.

No maintenance cost data are available for these engines. However, for diesels driving 200- to 300-kW generators, maintenance costs range from 7-9 mills/kWh. We shall assume, as a preliminary estimate, that Stirling-cycle, engine-maintenance costs are 8 mills/kWh. Assuming a fuel cost of \$0.42/gal (\$2.77/10⁶ Btu) and an engine efficiency of 46%, fuel oil costs amount to \$0.021/kWh.

D. Safety

Most Stirling automotive engines utilize pressurized hydrogen as the working gas. For stationary applications where engine weight is not so critical, pressurized helium could also be used. (If efficiencies comparable to those of hydrogen engines are to be achieved, helium must be used at higher pressures, which necessitates a heavier engine.) Clearly, there is the potential for safety problems with the use of hot, high-pressure hydrogen, although the quantities involved are relatively small.

In stationary applications using "dirty" fuels (coal, etc.), there is a good possibility that a liquid-metal heat pipe could be used to transfer heat between the heat source (combustion chamber) and the tubular structure of the engine heaters. These hot liquid metals, e.g., sodium, would constitute another potential safety hazard.

E. Environmental Concerns

It is expected that the Stirling engine would have a less adverse environmental effect compared with other engine types. This is due to 1) high efficiency resulting in less fuel consumption, and 2) external combustion processes which are more consistent with low exhaust emissions than internal combustion engines. ⁽¹⁸⁾

REFERENCES

1. Meijer, R.J. "Philips Stirling Engine Activities." International Automotive Engineering Congress, Detroit, Michigan, January 11-15, 1965. Warrendale, Pennsylvania: Society of Automotive Engineers, 1965.
2. Percival, W.H. Historical Review of Stirling Engine Development in the United States from 1960 to 1970. Energy Research and Development Administration and National Aeronautics and Space Administration. July 1974. NASA Report No. NASA CR-121097.
3. Flynn, Jr., G., et al. GMR Stirling Thermal Engine: Part of the Stirling Engine Story, 1900 Chapter. Warren, Michigan: General Motors Corporation, Research Laboratories, August 1966.
4. Heffner, F.E. Highlights of 6500 Hours of Stirling Engine Operation. Warren, Michigan: General Motors Corporation, Research Laboratories, 1965.
5. Ford Motor Company, Power Train Research Office. "Stirling Engine Program." Advanced Automotive Power Systems Contractors' Coordination Meeting. Dearborn, Michigan, May 8, 1975.
6. Rosenqvist, N.K.G., et al. "The Development of a 150 kW (200 hp) Stirling Engine for Medium Duty Automotive Application -- A Status Report." International Automotive Engineering Congress, Detroit, Michigan, February 28 - March 4, 1977. Warrendale, Pennsylvania: Society of Automotive Engineers, 1977.
7. Ford Motor Company, Power Train Research Office. "Stirling Engine Program." Advanced Automotive Power Systems Contractors' Coordination Meeting. Dearborn, Michigan, October 19, 1976.
8. "ERDA Authorization Bill Advances." Energy Research Digest 3(2):4, October 10, 1977.
9. Postma, N.D., et al. "The Stirling Engine for Passenger Car Application." Preprint. Society of Automotive Engineers Meeting, June 18-22, 1973. SAE Preprint No. N 730648.
10. Meijer, R.J. The Philips Stirling Engine. Eindhoven, The Netherlands: Philips Physical Laboratories, 1966.
11. Hogland, L., et al. A Technology Evaluation of the Stirling Engine for Stationary Power Generation in the 500-2000 Horsepower Range. Report prepared by Amtech, Inc. under Contract No. EC-77-C-05-5392 for the Department of Energy, September 1978. DOE Report No. ORD/5-392-1.

REFERENCES (continued)

12. Jet Propulsion Laboratory, California Institute of Technology. Should We Have a New Engine?: An Automobile Power Systems Evaluation. Vol. II. Pasadena, California, August 1975. Jet Propulsion Laboratory Report No. JPL-SP-43-17.
13. Steitz, P., et al. Assessment of the Role of Advanced Technologies in Small Utilities. Report prepared by Burns & McDonnell Engineering Company for Electric Power Research Institute, May 1978. EPRI Report No. EPRI EM-696.
14. Asselman, G.A.A. Fluidized Bed Coal Combustion as a Heat Source for Stirling Engines. Eindhoven, The Netherlands: Philips Research Laboratory, 1976.
15. Lehrfeld, D. Systems Analysis Design and Proof of Concept Experiment of Total Energy System. Briarcliff, New York: Philips Laboratories, 1977.
16. Beale, W.T., et al. Free-Piston Stirling Engines - A Progress Report. Warrendale, Pennsylvania: Society of Automotive Engineers, June 1973. Paper No. 730647.
17. Lehrfeld, D. "Practicability Study of Stirling Total Energy Systems." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington D.C., August 28 - September 2, 1977. pp. 1504 ff.
18. Davis, S.R., et al. Combustion and Emission Formation in the Stirling Engine with Exhaust Gas Recirculation. Warrendale, Pennsylvania: Society of Automotive Engineers, June 1971. Paper No. 710824.

CHAPTER 15
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: ORGANIC RANKINE CYCLE ENGINES</p> <p>DESCRIPTION: An organic fluid is boiled and the resulting vapor drives a turbine, similar to a steam turbine system, but the organic fluid can be used at lower temperatures and in smaller capacities.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, and industrial</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Not yet widely available on a commercial basis; several demonstration and prototype systems in operation using waste heat or solar energy as heat sources.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 40%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 15%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td><td>.002-2</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY</td><td>10⁴-10⁷</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.65</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.25 - 1.00</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.05 - .30</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Solar energy, waste heat AMOUNT NEEDED PER UNIT OUTPUT: 17,000 Btu/kWh at 20% efficiency ALTERNATIVE FUEL(S): Can be designed for a variety of fuels IS SYSTEM READILY CONVERTIBLE? Design depends on heat source characteristics</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Dependent on heat source availability</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Depends on application</p> <p>TECHNICALLY PRACTICAL? Yes, with proper controls</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? SYSTEM: Thermal storage would buffer equipment from heat input fluctuations and/or permit operation of engine when heat source not available.</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.002-2	same	same	SECONDARY				UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	10 ⁴ -10 ⁷	same	same	SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:	.65	same	same	RANGE OF CAPACITY FACTORS:	.25 - 1.00	same	same	EFFICIENCY (BTU OUT/BTU IN):	.05 - .30	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.002-2	same	same																																
SECONDARY																																			
UNIT ANNUAL ENERGY OUTPUT: (kWh) PRIMARY	10 ⁴ -10 ⁷	same	same																																
SECONDARY																																			
AVERAGE EFFECTIVE CAPACITY FACTOR:	.65	same	same																																
RANGE OF CAPACITY FACTORS:	.25 - 1.00	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.05 - .30	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 40%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 15%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW)⁽ⁱ⁾ Does not include storage or cooling tower, electric generator and heat source or collector-associated costs</td><td>700-1400</td><td>500-1000</td><td>400-800</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh)⁽ⁱⁱ⁾</td><td>.007-.015</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>4-8 mos</td><td>2-6 mos</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) ⁽ⁱ⁾ Does not include storage or cooling tower, electric generator and heat source or collector-associated costs	700-1400	500-1000	400-800	AVERAGE UNIT O&M: (\$/kWh) ⁽ⁱⁱ⁾	.007-.015	same	same	CONSTRUCTION PERIOD:	4-8 mos	2-6 mos	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) ⁽ⁱ⁾ Does not include storage or cooling tower, electric generator and heat source or collector-associated costs	700-1400	500-1000	400-800																																
AVERAGE UNIT O&M: (\$/kWh) ⁽ⁱⁱ⁾	.007-.015	same	same																																
CONSTRUCTION PERIOD:	4-8 mos	2-6 mos	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Limited at this time, but can expand to meet market demand.</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS:</p> <ol style="list-style-type: none"> 1. Effects attributable to heat source 2. Working fluid leaks (into cooling stream or atmosphere) 3. Cooling tower effects on local climate and landscape 4. Temperature effects on cooling medium (lakes, rivers, etc.) <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: None</p>																																		
COMMENTS	<p>Organic Rankine cycle engines are well suited for distributed energy systems, since they can operate with good efficiency at relatively low temperatures (200 -600°F) and over a wide range of power capacities (2kW-2MW). In addition to good performance under off-design or part-load conditions, they can be designed to utilize a variety of different heat sources such as solar energy, waste heat, or geothermal heat.</p> <p>(i) Reflects manufacturers' expectations assuming firm orders for multiple units. No commercial practice established to verify these cost ranges.</p> <p>(ii) Zero fuel costs are assumed since most applications could utilize waste heat, solar heat, or geothermal energy sources.</p>																																		

62

CHAPTER 15

ORGANIC RANKINE CYCLE ENGINES

Section 15.1: Introduction

An organic Rankine cycle (ORC) engine converts heat energy into mechanical energy by alternately evaporating a working fluid at high pressure and producing shaft power from the high-pressure vapor as it expands through a turbine (or some other suitable expansion device) to a condenser which operates at low pressure. Similar in concept to a simple steam Rankine cycle, ORC engines can use any one of a number of organic working fluids, the choice being a function of peak cycle temperature and expander type. The use of organic working fluids allows the engine to operate efficiently at lower temperatures and in smaller sizes than more conventional steam systems.

ORC engines have several characteristics which may make their use particularly appropriate for distributed energy systems. They are one of the few engines which can effectively utilize heat at relatively low temperatures in the 200-600°F range. This gives ORC engines great flexibility for use with a variety of heat sources such as solar energy, industrial waste heat streams, geothermal energy, and hot engine exhausts. Also, ORC engines can be designed for use over a wide range of capacity levels as indicated by present development programs which include 2-kW systems for on-site solar applications and 2-MW systems for waste heat applications.

The advantages of ORC engines have resulted in programs by a number of companies to develop systems that could become commercially available in the next two to five years. ORC engines could, therefore, represent a near-term option for distributed energy system applications.

Section 15.2: Technical Discussion

A. System Configuration

A schematic of an organic Rankine cycle engine for waste heat applications is shown in Figure 15-1. This system consists of:

- a "boiler," which can transfer heat from solar collectors, engine exhausts, or a direct combustion process in order to convert the working fluid to a vapor;
- an expander (turbine or positive displacement configuration), which produces shaft power when supplied with a pressurized vapor;
- a condenser, consisting of a water-cooled heat exchanger in most applications, in which the low-pressure vapor is condensed to a liquid; and
- a feedpump (positive displacement or centrifugal).

With some working fluids, the vapor leaving the expander is superheated. To increase cycle efficiency, a recuperator may be placed at the outlet of the expander to use the superheat energy for preheating the fluid from the feedpump before it flows into the boiler.

The efficiency of the system depends on both the ideal thermodynamic efficiency of the cycle (assuming 100% component efficiencies and zero pressure drop in the heat exchangers) and the actual efficiencies of the major system components, such as the expander and feedpump. The results of testing by a number of firms for a range of component configurations indicate that the following efficiencies (energy out/energy in) can be obtained using existing technology:

- Expander efficiency, 70-85%; and
- Feedpump efficiency, 70-93%.

The component efficiencies used to calculate the system performance curves shown in Figure 15-2 are an expander efficiency of 75%, a feedpump efficiency of 75%, and a recuperator effectiveness of 0.9. As these figures indicate, system performance tends to improve as the peak cycle temperature increases and as the condenser temperature decreases.

SOURCE: Arthur D. Little, Inc.

FIGURE 15-1 SCHEMATIC OF A WASTE-HEAT-RECOVERY ORGANIC RANKINE CYCLE ENGINE

SOURCE: Arthur D. Little, Inc.

FIGURE 15-2 RANKINE CYCLE ENGINE EFFICIENCY - VARIATION WITH PEAK CYCLE TEMPERATURE

B. Component Configuration

Most of the components of organic Rankine cycle engines would be standard commercial items. For example, the boiler and condenser could be tube-in-shell counterflow heat exchangers commonly used in the air conditioning industry. The feedpump might be a hydraulic fluid pump modified to account for the low viscosity of refrigeration fluids.

The key component within the system that is of a unique nature is the expander, used to convert high-pressure vapor into mechanical work during its expansion from boiler to condenser pressure. To a great extent, this component determines the thermal efficiency of the system. A number of expander types can be used with the organic Rankine cycle including:

- reciprocating engines,
- turbines, and
- positive displacement rotary devices, such as rotating vane and screw expanders.

For relatively large systems (in excess of 100 kW), turbines are generally the most appropriate expander type. However, for smaller units, positive displacement expanders have several advantages, ^(1,2,3) including low operating speeds, high efficiency, and good part-load performance.

The heat exchangers acting as boiler, regenerator, and condenser are by far the largest components, based on physical size. This is indicated by Figure 15-3, which shows the layout of a 2000-kW system. These heat exchangers will also tend to dominate system costs, particularly in larger production quantities.

C. Working Fluid Considerations

The performances of organic Rankine cycle engines using several working fluids are shown in Figure 15-2. Several common refrigeration fluids, such as R-114, are candidates for lower-temperature applications (up to 400°F), while fluids with high thermal stability, such as benzene, toluene, and F-85 (Fluorinol) must be used for higher-temperature applications.

A large number of working fluids can be considered for use in addition to those indicated in Figure 15-2. The characteristics of several working fluids which are now being used in developmental engines are summarized

SOURCE: Reference 4.

FIGURE 15-3 LAYOUT OF A 2-MEGAWATT ORGANIC RANKINE CYCLE ENGINE
(R-113 Working Fluid, $T_m = 325^\circ\text{F}$)

in Table 15-1. Choice of a fluid will depend on a number of factors, including:

- peak operating and heat rejection temperatures,
- type of expander (turbine or positive displacement),
- power level, and
- toxicity and/or flammability restrictions.

As indicated in Figure 15-2, there are relatively modest variations in efficiency between working fluid options at any given temperature; and therefore, working fluid choice is usually determined by considerations such as the need for a recuperator, line size requirements, compatibility with expander type, and safety.

To date, R-11 and R-113, toluene, and F-85 have been the fluids most commonly used in those applications utilizing turbine equipment. Lower-volume-flow-rate-fluids (such as R-22 and R-114) might be better choices if positive displacement equipment is used.

D. Applications

In its initial development, the organic Rankine cycle engine was generally a flame-fired device. Areas investigated for possible use include automotive power plants, gas-fired cold generators for air conditioners, and military generators. The advantages of the organic Rankine engine in these applications include low exhaust emissions (because of the more easily controlled external combustion process) and a high degree of fuel flexibility (also attributable to external combustion).

However, the primary advantages of this engine cycle are its ability to use a variety of heat sources (solar, waste heat, geothermal, etc.) over a wide temperature range (200-800°F) and the fact that system performance is not drastically affected by system size. In comparison, conventional Rankine cycle power systems using steam are generally considered only for large-scale (1-Megawatt and higher) applications with heat source temperatures in excess of 800°F. The flexibility of the organic Rankine engine indicated above with respect to the heat source used and system output make it ideally suited for distributed energy system use.

TABLE 15-1

ORGANIC POWER-CYCLE WORKING FLUIDS USED IN SYSTEM TESTING OR IN DEVELOPMENT

Fluid	Maximum Boiler Outlet Temperature (°F)	Freezing Point (°F)	System Test Experience	Flammability	Current Development Underway	Comments
R-11	~250	-168	Yes	Nonflammable	Yes	Favorite low-temperature working fluid; power and combined power/air conditioning.
R-114	~400	-137	Limited	Nonflammable	No	Combined power/air conditioning.
R-22	425	-256	Yes	Nonflammable	No	Combined power/air conditioning.
Isobutane	~500	-217	Yes	Highly flammable	Yes	Other aliphatic hydrocarbons, such as propane and butane, are under consideration, primarily for geothermal use. Sofretes (France) has operated a propane system.
Thiophene	550	- 37	Yes	Highly flammable	No	Toxic
FC-75	~600	- 76	Yes	Nonflammable	No	Requires very high regeneration, generally lower efficiency than other fluids at given boiler outlet temperature.
Chlorobenzenes	~600	- 49 (Mono- chloro- benzene)	Yes	Fire Resistant	No	Used in Ormat (Israel) system.
Monoisopropyl Biphenyl	~600	- 68	Yes	Highly flammable	No	Requires high regeneration, very low condenser pressure.
Fluorinol	625-650	- 82	Yes	Fire Resistant	Yes	Extensive experience, seven years of system testing.
Pyridine/ water mixture	~700	- 75	No	Flammable	No	Toxic
Dowtherm-A®	~700-750	+ 54	Yes	Flammable	No	Requires high regeneration, very low condenser pressure.
Toluene (CP-25)	~750	-140	Yes	Highly flammable	Yes	Extensive experience.
Hexafluoro- benzene Octafluoro- benzene mixture	~800-850	- 40	Yes	Nonflammable	No	Very expensive fluid at present.
Hexafluoro- benzene Pentafluoro- benzene mixture	~800-850	- 40	No	Nonflammable	Yes	Very expensive fluid at present.

SOURCE: Undated product literature, Thermo Electron Corporation,
Waltham, Massachusetts.

The following is a list of promising DES applications for organic Rankine cycle engines:

- o Bottoming cycles on existing generating equipment^(5,6,7)
 - diesel exhaust
 - gas turbine exhaust
- o Waste heat applications^(2,8,9,10)
 - furnace and flue exhausts
 - boiler exhaust
 - hot process water
- o Solar applications^(4,11,12,13)
- o Geothermal applications^(14,15)
- o Flame-fired applications^(16,17,18)
 - using a variety of fuels (biomass, biogas, oils, gas, etc.).

The engines for each of these applications are basically the same (shown schematically in Figure 15-1), with the exception of the vapor generator (or boiler) used for transferring heat to the working fluid.

Since the output of ORC engines is shaft power, it is possible to use any of the above applications to: 1) generate electric power (AC or DC), 2) directly drive vapor-compression refrigeration units (to chill water or provide comfort conditioning), or 3) to pump a liquid or gas (irrigation water, compressed air, etc.).

E. Auxiliary Components

The auxiliary components required for an organic Rankine engine system depend on the application. With all systems, some type of cooling must be provided, and for locations without a nearby river or cool-water source, a cooling tower (wet or dry) will most likely be used. Similarly, all systems require a heat-input system to vaporize the heat-transfer fluid used in the engine boiler. This is generally a gas-to-liquid or liquid-to-liquid heat exchanger, depending on the heat source.

An ORC engine can be used to drive directly an electric generator, compressor, or pump as required by each specific application. When electric

power is produced, it may be desirable to use this power in parallel with utility-supplied power. The utility interface will require switchgear and associated controls to ensure appropriate phasing of the on-site and utility power sources.

For solar applications, some form of thermal storage may be desirable, so that operation during periods of darkness or cloudiness can be maintained, and to smooth out short-term fluctuations in output due to passing clouds. This storage would probably take the form of pressurized hot water, a mixture of heat-transfer oil and crushed rock, or just heat-transfer oil. The approach taken for energy storage would depend on factors such as the operating temperature levels and storage capacity requirements. (See Chapter 19.)

Section 15.3: Economics Discussion

The cost of organic Rankine cycle engines is difficult to estimate. These engines are not widely available on a strictly commercial basis. Furthermore, the cost depends on several variables, including:

- o power output,
- o temperature of heat input, and
- o production levels.

Figure 15-4 shows estimates for the cost of organic Rankine cycle engines based on conversations from 1976 through 1978 with several potential manufacturers, Arthur D. Little, Inc., estimates, and literature on the subject.^(8,19,20) The rather wide cost range reflects, in part, the limited commercial experience with these engines. These figures do not include any energy storage, generator, or cooling tower costs (estimated at \$50/kW). Furthermore, these figures do not include the cost of extra heat exchangers that might be required to transfer heat to a medium suitable for the Rankine engine boiler.

As indicated, at lower power levels, engine system costs per unit output decrease as the power level increases. This is due to the fact that the cost of mechanical equipment (expanders, pumps, etc.) and controls tends to increase slowly with increasing power level. For larger capacity engines, the cost of heat exchangers predominates and engine cost per unit output is not significantly affected by engine capacity.

Condenser Cooling Systems not included.

SOURCE: References 8, 19, and 20.

FIGURE 15-4 COST PROJECTIONS FOR ORGANIC RANKINE CYCLE ENGINES

In all cases, ORC engines are expected to be highly reliable once they are fully developed because of their sealed construction (similar to vapor compression air conditioning systems) and their relatively low operating temperatures. The O&M costs associated with their operation could be quite variable, however, depending on operating temperature levels, nature of the heat source (flue gases, solar collectors, etc.), system size, and type of condenser cooling system. For purposes of this power cost analysis, O&M costs are assumed to be 6% of the initial system cost. This number is quite tentative at this time because of the lack of long-term operating experience.

Figure 15-5 shows energy cost as a function of engine capacity, based on annual capital costs of 14% (including depreciation and interest), a 6% O&M, and a "free" source of heat (such as would be available in a waste heat application). The lower curve is based on a load factor of 1.0 (24-hour-a-day operation at full load, 365 days a year) and the upper curve, a load factor of 0.5. The economics of ORC engines benefit from a high degree of engine utilization during the year. (This is especially true with a fuel cost of zero, as assumed here for waste heat recovery applications.)

Section 15.4: Limitations

A. Equipment Availability

A number of firms have made prototype organic Rankine cycle engines for a diversity of applications, including industrial waste heat recovery, bottoming cycles on diesel engines, solar irrigation pumping, and solar air conditioning. A list of the most active firms in the field is shown in Table 15-2. The efforts of several of these firms are sponsored by DOE as part of the solar cooling, geothermal, and energy conservation programs.

A 60-kW system using geothermal hot water as the heat source began operation in September, 1977, in El Centro, California.⁽²¹⁾ This system uses isobutane as the working fluid and operates at a temperature of about 325°F. Work is also proceeding on a 500-kW system which will operate on either isobutane or pentane in a similar operating temperature range.

Several solar-powered demonstration ORC engine systems have been assembled in the United States, primarily as a result of government-

SOURCE: Arthur D. Little, Inc.

FIGURE 15-5 COST PROJECTIONS FOR ORGANIC RANKINE CYCLE ENGINES

TABLE 15-2

DEVELOPERS AND/OR SUPPLIERS OF ORGANIC RANKINE CYCLE ENGINES

	<u>Type of Mechanical Equipment</u>	<u>Output (kW)</u>	<u>Working Fluid</u>	<u>Applications</u>
Thermo Electron Corporation	Reciprocating & Turbine	3 - 1000	F-85 & Water	Automotive & Bottoming Cycle
Sunstrand	Turbine	20 - 500	Toluene	Solar Power, Waste-Heat Recovery
Barber-Nichols	Turbine	2 - 100	R-11, R-113, F-85, Iso- butane	Solar Power, Air Conditioning, Waste-Heat Recovery, Geothermal
Aerojet General	Turbine	150	Proprietary, Pyridine- Water	Automotive, Waste-Heat Recovery
General Electric	Rotary Vane	3 - 10	R-11	Solar Air Conditioning
DuPont	Rotary Boiler & Turbines	10 - 200	Proprietary	Automotive
Kinetics, Inc.	Generator, Helical Screw	1 - 5000	R-12, R-114	Solar & Waste-Heat Recovery
Ormat (Israel)	Turbine	1 - 5	Monochloro- benzene	Remote Power System
IHI (Japan)	Turbine	100 - 500	R-11	Waste-Heat Recovery
United Technologies	Turbine	3	R-11	Solar Air Conditioning
Sofretes (France)	Reciprocating & Turbine	1 - 50	R-11	Solar Pumping
Mechanical Technologies, Inc.	Turbine	~500	R-114 & Water	Waste-Heat Recovery

SOURCE: Compiled by Arthur D. Little, Inc.

sponsored programs. These include a 2-1/2-hp solar-driven engine using R-113⁽¹²⁾ as the working fluid. These engines are directly coupled to the compressor of air conditioning systems.

A 32-kW system is being used at Sandia Laboratories⁽²²⁾ in their solar "total energy" test system. This system uses toluene as the working fluid at a relatively high temperature (between 500°-600°F) because of the use of focusing collectors.

One firm (Sofretes in France)⁽²³⁾ is now producing a limited number of solar water pumping units using flat-plate collectors and an organic Rankine cycle engine. These systems are primarily for use in remote areas of developing countries. Ormat* has been manufacturing small (1-kW) ORC engines for more than 10 years. These systems are of highly specialized, costly design which emphasizes high reliability. They are most often used in unattended remote areas (mountain tops, polar regions, etc.) to operate critical communications and signal equipment.**

The development of solar-driven irrigation pumping systems using ORC engines as the prime mover is also receiving a great deal of attention in the United States. One 25-hp system (sponsored by DOE) recently initiated operation in the Estancia Valley of New Mexico and a 50-hp system (sponsored by Northwest Mutual Life Insurance Company) is now operating in Gila Bend, Arizona.⁽²⁴⁾ Both these systems use ORC engines with R-113 as the working fluid and operate at temperatures of 300-400°F.

As part of the DOE energy conservation program, three firms will make demonstration engines in the 500-kW range which will use diesel engine exhaust heat or industrial waste heat as the energy input. Manufacturers listed in Reference 23 report that these engines are in an advanced development stage and operation was initiated in late 1978.

No U.S. firms offer solar-driven engines on a strictly commercial basis (although prototype units are available by negotiation), but there are a number of major firms in the United States and elsewhere which perceive that solar-powered organic Rankine cycle engines represent a viable

*Ormat Turbines, Ltd. of Yavne, Israel.

**In sunny regions solar cell power units are increasingly being used for these functions. (See Chapter 2.)

approach to on-site power generation, air conditioning, and water pumping. All indications are that the number of such firms is increasing and that ORC engine systems will be available on a commercial basis in the near term (2-5 years) over a range of system capacities from 3 kW for solar air conditioning applications to more than 1 MW for waste heat and geothermal applications.

B. Fuel Availability

It is expected that most applications of organic Rankine engines will use solar, geothermal, hot engine exhausts, and industrial waste heat sources. Fossil fuel availability will have, therefore, only an indirect effect on the economic viability or range of applications.

C. Safety

Because of the nature of these systems, safety considerations (other than those associated with any piece of rotating equipment) are mainly limited to working-fluid properties. None of the organic working fluids is completely free of problems associated with flammability and toxicity. Low-cost fluids such as toluene, benzene, and isobutane are all flammable, and may also be toxic and carcinogenic. Both thiophene and pyridine are quite toxic (including the inhaled vapor), which will tend to restrict their application. Fluorinol appears to be one of the safest of the high-temperature working fluids since both toxicity and flammability levels are quite low.⁽²⁵⁾

The fluorocarbon refrigerant fluids being considered for organic Rankine cycle engine applications are nonflammable and have low toxicity.⁽²⁶⁾ One of the more serious safety considerations with the refrigeration fluids could be the products of their thermal decomposition. These products can include phosgene, which is highly toxic. This consideration may be a serious one in some waste heat recovery applications, particularly if the "boiler" is in a hot flue-gas stream.

D. Environmental Concerns

Environmental concerns beyond those associated with the heat source are principally due to working fluid considerations and any

effects associated with the condenser cooling system. With some refrigerant working fluids, atmospheric ozone layer degradation due to released working fluid gas is of concern. If a cooling tower is used, the plume could perhaps have an effect on local climate, and the tower itself could adversely affect the view of the landscape. Care would have to be taken to avoid large temperature rises and working-fluid leaks into a local body of water, should this method of direct condenser cooling be selected.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Marsters, G.F., et al. "Rotary Vane Expander Development: Some Design Considerations." 7th Intersociety Energy Conversion Engineering Conference, San Diego, California, September 25-29, 1972. pp. 249 ff.
2. Eckard, S.E. "Multi-Vane Expander as Prime Mover in Low Temperature Solar or Wasteheat Applications." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 1399 ff.
3. Teagan, W.P., et al. "3KW Organic Rankine Cycle Power System." Proceedings of the 25th Power Sources Symposium, Atlantic City, New Jersey, May 23-25, 1972. Sponsored by the U.S. Army Electronics Command, Fort Monmouth, New Jersey. -Available from PSC Publications Committee, P.O. Box 891, Red Bank, NJ.
4. Teagan, W.P., et al. "Solar Thermal Power Generation." COMPLES International Meeting, Petroleum and Minerals University, Dhahran, Saudi Arabia, November 1977. Sponsored by Coopération Méditerranéenne pour l'Energie Solaire. Paper available from author c/o Arthur D. Little, Inc., Cambridge, Massachusetts.
5. Thermo Electron Corporation. Organic Rankine Bottoming Cycle for Long Haul Diesel Trucks. Waltham, Massachusetts, November, 1975. Thermo Electron Corporation Report No. TE4193-40-76.
6. Doyle, E.F., et al. "Diesel-Organic Rankine Compound Engine Development." 12th Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1073 ff.
7. Rheinhardt, H., et al. "Development Status; Binary Rankine Cycle Waste Heat Recovery System." 12th Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1090 ff.
8. Drexel University. Industrial Applications Study. Volume 1. Executive Summary: Industrial Waste Energy Data Base Technology Evaluation. Final Report. Prepared for Energy Research and Development Administration, December 1976. NTIS Report No. C00/2862-1.
9. Lewis, G., et al. "Sulfuric Acid Plant Rankine Cycle Waste Heat Recovery." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 1182 ff.
10. Lacey, R.D., et al. "600 KW Organic Rankine Cycle Waste Heat Power Conversion System." 12th Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 1095 ff.

REFERENCES (continued)

11. Curran, H.M., et al. Assessment of the Rankine Cycle for Potential Application to Solar-Powered Cooling of Buildings. Prepared by Hittman Associates, Inc. for National Science Foundation, August 1974. NTIS Report No. PB 238 069.
12. Prigmore, D.R., et al. "A Prototype Solar Powered, Rankine Cycle System Providing Residential Air Conditioning and Cooling." 9th Intersociety Energy Conversion Engineering Conference, San Francisco, California, August 26-30, 1974. pp. 326 ff.
13. Eckard, S. "Test Results for a Rankine Engine Powered Vapor Compression Air-Conditioner for 366 K Heat Source." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 1169 ff.
14. Walter, R.A., et al. "Economic Optimization of Binary Fluid Cycle Power Plants for Geothermal Systems." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 731 ff.
15. Eskesen, J.H. "Cost and Performance Comparison of Flash Binary and Steam Turbine Cycles for the Imperial Valley, California," 12th Intersociety Energy Conversion Engineering Conference. Washington, D.C., August 28 - September 2, 1977. pp. 842 ff.
16. Morgan, D., et al. "Laboratory Test Results - Low Emission Rankine Cycle Engine with Organic Based Working Fluid and Reciprocating Expander for Automobiles." 8th Intersociety Energy Conversion Engineering Conference, Philadelphia, Pennsylvania, August 13-17, 1973. pp. 158 ff.
17. Wigmore, D.B. Determination of the Optimum Fluid and System Variables for .5-5 KWE Rankine Cycle Power Systems. Report prepared by Sundstrand Aviation for U.S. Army Mobility Equipment Research and Development Center, February 1972. NTIS Report No. AD 741 835.
18. Sundstrand Corporation. Organic Rankine Cycle Silent Power, 15KW, 28 VDC. Report prepared for U.S. Army Mobility Equipment Research and Development Center, February 1972.
19. Barber, R. "Solar Powered Organic Rankine Cycle Engines - Characteristics and Costs." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976 pp. 1151 ff.
20. Sternlicht, B. "The Equipment Side of Low Level Heat Recovery." Power 119(6):71-77, June 1975.
21. "New Heat Exchangers in Binary Cycle Process Used to Generate Electricity from Geothermal Fluids." DOE News Release, October 4, 1977. Available from U.S. Department of Energy, Washington, D.C.

REFERENCES (continued)

22. Petterson, B., Jr. Solar Total Energy Test Facility Project; Semi-annual Report, October 1976 - March 1977. August 1977. Prepared by Sandia Laboratories for Energy Research and Development Administration. NTIS Report No. SAND77-0738.
23. Promotional Literature from:
 - a) Ishikawajima-Harima Heavy Industries Co., Ltd.
New Ohtemachi Bldg., 2-chome, 2-1 Ohtemachi, Chiyoda-ku,
Tokyo, Japan
 - b) Thermo Electron Corporation
101 First Avenue
Waltham, Massachusetts 02154
 - c) Sundstrand Corporation
4751 Harrison Avenue
Rockford, Illinois 61101
 - d) Barber-Nichols Engineering Company
6325 W. 55th Avenue
Denver, Colorado 80221
 - e) Kinetics Corporation
3822 Colerain Avenue
Cincinnati, Ohio 45223
 - f) Sofretes (Renault Moteurs International)
La Boursdidiere, France.
24. U.S. Department of Energy. Solar Powered Irrigation Systems Technical Progress Report. February 28, 1978. NTIS Report No. SAN-1101/PA2-21.
25. Hazards Research Corporation. Flammability Studies in Fluorinol 61 and Fluorinol 85. Report prepared for Halocarbon Products Corporation, 1974. Report No. 3344.
26. E.I. DuPont deNemours, 1007 Market, Wilmington, Delaware 19898.
"Freon Compounds and Safety." Product Brochure, S-16. 1969.

CHAPTER 16
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: FUEL CELLS</p> <p>DESCRIPTION: Fuels are converted to electrical energy by electrochemical processes.</p> <p>POTENTIAL USER CLASSES: Electric utilities and industry</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Demonstration, on-site, of first-generation fuel cells (phosphoric acid electrolyte) scheduled early 1980.</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 45%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 25%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td><td>.2-10⁽ⁱ⁾</td><td>.2-26⁽ⁱ⁾</td><td>same⁽ⁱⁱ⁾</td></tr> <tr> <td>SECONDARY</td><td>(iii)</td><td></td><td></td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY</td><td>260-13,000</td><td>500-68,000</td><td>same</td></tr> <tr> <td>SECONDARY</td><td>(iii)</td><td></td><td></td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR: (iv)</td><td>.15</td><td>.30</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>0-.95</td><td>same</td><td>same</td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.37⁽ⁱⁱⁱ⁾</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Light hydrocarbons AMOUNT NEEDED PER UNIT OUTPUT: 9000 Btu/kWh</p> <p>ALTERNATIVE FUEL(S): Methanol, coal IS SYSTEM READILY CONVERTIBLE? No gases and liquids</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Load following</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Yes</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? No SYSTEM:</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.2-10 ⁽ⁱ⁾	.2-26 ⁽ⁱ⁾	same ⁽ⁱⁱ⁾	SECONDARY	(iii)			UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY	260-13,000	500-68,000	same	SECONDARY	(iii)			AVERAGE EFFECTIVE CAPACITY FACTOR: (iv)	.15	.30	same	RANGE OF CAPACITY FACTORS:	0-.95	same	same	EFFICIENCY (BTU OUT/BTU IN):	.37 ⁽ⁱⁱⁱ⁾	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.2-10 ⁽ⁱ⁾	.2-26 ⁽ⁱ⁾	same ⁽ⁱⁱ⁾																																
SECONDARY	(iii)																																		
UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY	260-13,000	500-68,000	same																																
SECONDARY	(iii)																																		
AVERAGE EFFECTIVE CAPACITY FACTOR: (iv)	.15	.30	same																																
RANGE OF CAPACITY FACTORS:	0-.95	same	same																																
EFFICIENCY (BTU OUT/BTU IN):	.37 ⁽ⁱⁱⁱ⁾	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 45%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 25%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Fuel processor, power conditioner)</td><td></td><td>365-382^(v)</td><td>300</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)</td><td></td><td>.0027-.0065</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td></td><td>1 year</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Fuel processor, power conditioner)		365-382 ^(v)	300	AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)		.0027-.0065	same	CONSTRUCTION PERIOD:		1 year	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Fuel processor, power conditioner)		365-382 ^(v)	300																																
AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)		.0027-.0065	same																																
CONSTRUCTION PERIOD:		1 year	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Limited to one major corporation at present</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: None</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: None</p>																																		
COMMENTS	<p>(i) Electric utility use.</p> <p>(ii) See Section 16.5 for recent developments.</p> <p>(iii) For industrial cogeneration, waste-heat recovery potential estimated at 2500-3500 Btu/kWh, ranging in form from 60 psig steam to 140°F hot water.</p> <p>(iv) Capacity factors will be dictated by economics, not technical limitations.</p> <p>(v) These are projected costs; current costs are significantly higher.</p>																																		

CHAPTER 16

FUEL CELLS

Section 16.1: Introduction

A fuel cell is an electrochemical device that converts the chemical energy of a fuel directly into electricity. As such, it is a primary source of electrical energy, not a storage device, that is well suited to a distributed energy system. The characteristics that make it an attractive candidate are modular construction, good load following capabilities without loss of efficiency, automatic startup and shutdown, low-pollutant emissions, and silent operation.

The major limitation in the application of existing fuel cell technology (based on a phosphoric acid electrolyte operating at 190°C) is the requirement for a clean fuel that can be used to generate hydrogen, such as naphtha. Hydrogen is the only fuel that can be oxidized in the fuel cell itself at acceptable power levels. A thermally integrated steam reformer and fuel-cell stack scheduled for demonstration in early 1980 are expected to operate at a heat rate of 9300 Btu/kWh.⁽¹⁾ A second-generation molten-carbonate-electrolyte fuel cell operating at 600°C and using advanced fuel conversion technology would make less stringent demands for a clean fuel. It is anticipated that if the technology can be developed, a heat rate of 7340 Btu/kWh⁽²⁾ would be obtained but this is not expected before the late 1980's.

Present technical activities revolve around the on-site demonstration of a fuel cell and reformer module for 4.8 MW.⁽³⁾ Though originally considered primarily for peak load operation, depending on location, fuel availability and price, fuel cells could be used to meet intermediate loads. An installation of this size is particularly attractive if there is an on-site use for the waste heat from the system -- the concept of cogeneration. There also appears to be the promise of using molten-carbonate cells for baseload operation. However, baseloaded fuel cell power plants, like conventional and other advanced system concepts, would have to be quite large to match

the use of energy obtainable from large coal-burning plants. As such, they would not qualify as distributed energy systems and are not considered in this report.

Section 16.2: Technical Discussion

The physical form of a fuel cell is very similar to that of a battery -- two electrodes separated by an ionically conductive electrolyte. The difference between the fuel cell and a battery is that the latter stores its chemical energy internally, while the fuel cell requires a continuous external supply and, in turn, provides continuous electrical power. The most common fuel is hydrogen, although attempts have been made (unsuccessfully) to use propane, methanol, and hydrazine directly.

The hydrogen fuel is fed to the anode of the fuel cell; oxygen from air reacts at the cathode. The overall chemical reaction is the formation of water, and it is the free energy of this reaction that defines the maximum electrical energy that a fuel cell can produce. Since there is no thermomechanical work involved, the efficiency of the energy-conversion process is not limited by the Carnot cycle. However, there are voltage losses associated with internal resistance, mass-transport limitations, and kinetics of the electrode reactions. The variation of voltage with load is shown in Figure 16-1. The output is low-voltage high-current power from a single cell with a voltage of 0.65 and a current density of 250 amperes/ft² of electrode. Present technology consists of multi-cell stacks that are approximately 4 ft² in cross section, producing 1000 amperes at 50-300 volts, depending on the size of the stack.

The types of fuel cell are most easily classified by temperature and the nature of the electrolyte. Currently available technology⁽¹⁾ is based on a phosphoric acid cell operating at 190°C. Acid systems are favored because they do not react with carbon dioxide, and thus may use air as the oxidant. Phosphoric acid is preferred because it is a system in which it is relatively easy to control water removal. The most difficult aspect of fuel cell technology is the establishment of the three-phase interface between the

SOURCE: Reference 2.

FIGURE 16-1 TYPICAL CURRENT-VOLTAGE CURVE FOR A FUEL CELL

reacting gases, the electrolyte, and the electrodes. In the phosphoric acid cell the electrodes are made wetproof (hydrophobic) by using a plastic binder for the platinum-on-carbon electrocatalyst. The electrolyte is contained by capillarity in a porous separator.

Another fuel cell type under active engineering development⁽²⁾ has a molten carbonate as its electrolyte and operates at 600°C. A mixture of potassium and lithium carbonates is contained in a solid or semi-solid ceramic matrix. The electrochemical reaction at the cathode is the reduction of oxygen from the air with added carbon dioxide to form carbonate ions. At the anode a fuel, such as carbon monoxide or hydrogen, is oxidized by the carbonate ions that migrate through the electrolyte to produce carbon dioxide and water. The carbon dioxide is recycled to the cathode. The performance characteristics are similar to those of a phosphoric acid fuel cell, the principal advantages of the molten-carbonate fuel cell being that it is tolerant to carbon monoxide and is potentially less expensive than the phosphoric acid cell.

A third type of fuel cell, still in the engineering research phase, is based on a solid-oxide electrolyte that operates at 1000°C. The electrolyte most commonly used is doped zirconia, which has good ionic conductivity related to the migration of oxide ions. The biggest difficulty is obtaining long life. This system is unlikely to be operational before 1990.

A complete fuel cell generator consists of the cell stack, plus a fuel processor that converts a commercial fuel to a form suitable for feeding to the cell stack. For example, in a phosphoric acid fuel cell, naphtha (after sulfur removal) is steam-reformed to produce hydrogen and carbon monoxide; then a shift reactor converts the carbon monoxide and steam to produce a fuel stream of hydrogen with low levels of carbon monoxide and hydrogen sulfide. The molten-carbonate system can utilize the hydrogen-carbon monoxide stream directly; that is, no separate shift reactor is needed, but it is still important to remove the sulfur. The hope for baseload systems is to achieve an overall heat rate of 7500 Btu/kWh by integrating a coal gasifier with the molten-carbonate system.

As mentioned above, a fuel processor is necessary for the fuel cell to use commercially available fuels. The key to obtaining high efficiency is the use of waste heat from the fuel cell in fuel processing. A power conditioner converts the DC power of the fuel cell to AC power at a voltage level compatible with the local distribution system. A schematic of a fuel cell system is shown in Figure 16-2.

The fuel cell generator has many advantages to offer to a dispersed energy system. Modular construction confers flexibility in size. There is capability to follow load without loss of efficiency at low loads. (See Figure 16-3.) Note that pressurized cell operation is needed to maintain a proper water balance, and twin-flow turbocompressors are used, since it is necessary to have a low-flow unit to maintain high efficiency at lower power output. Fuel consumption closely follows the power demand. Fuel cell systems are being designed to operate automatically and to require no supervision and a minimum of maintenance. Low pollutant levels and silent operation allow a wide range of siting options.

Present technology is based on the phosphoric acid cell; the first unit is scheduled to be tested on-site in early 1980.⁽¹⁾ The basic size is a single 4.8-MW module. More than 50 modules of this type are planned for installation in the future, but the extent to which this will take place is very dependent on the success of the first demonstration. This number of systems, with approximately 10,000 cells per 4.8-MW module, represents a modest manufacturing effort that should in no way inhibit the application of fuel cells in dispersed energy systems.

Section 16.3: Economics Discussion

Table 16-1 gives the projected costs for three fuel cell systems: steam reforming coupled with the phosphoric acid cell, steam reforming with a molten-carbonate cell, and auto-thermal reforming with a molten-carbonate cell. Total capital costs are expected to approach \$400/kW

SOURCE: Reference 4.

FIGURE 16-2 SCHEMATIC DIAGRAM OF A FUEL CELL SYSTEM INCLUDING FUEL CELL, FUEL PROCESSOR (REFORMER, SHIFT CONVERTER AND AUXILIARIES), WASTE HEAT RECOVERY SYSTEM, AND POWER CONDITIONER

SOURCE: Reference 2.

FIGURE 16-3 FUEL CELL EFFICIENCY AS A FUNCTION OF POWER OUTPUT

TABLE 16-1

ESTIMATES OF 1985 CAPITAL AND ENERGY COSTS FOR FUEL CELL SYSTEMS (1977\$)⁽¹⁾

	Cell/Processor Technology					
	Acid Steam Reforming		Molten-Carbonate Steam Reforming		Molten-Carbonate Auto- thermal Reforming	
Heat Rate, Btu/kWh	9,000		7,945		7,340	
Feed Sulfur Content, ppm ⁽²⁾	200	0.5	200		200	2,000
<u>Capital Costs (\$/kW)</u>						
Processor and thermal	168	163	180		168	174
Power cell	146	146	146		146	146
Site ancillaries	<u>56</u>	<u>56</u>	<u>56</u>		<u>56</u>	<u>56</u>
<u>Total Capital Cost</u>	370	365	382		370	376
<u>Energy Costs (mills/kWh)</u>						
Capital Charge ^{(3) (4)}	22.2	21.9	22.9		22.2	22.6
O&M Expenses ⁽⁴⁾	3.2	2.7	3.1		3.1	6.5
Fuel Charge ⁽⁵⁾	<u>30.2</u>	<u>33.7</u>	<u>26.6</u>		<u>24.6</u>	<u>24.2</u>
<u>Total Energy Cost</u>	55.6	58.3	52.6		49.9	53.3

(1) Includes cell stacks, inverter, and turbocompressor.

(2) ppm: parts per million.

(3) 18% of capital investment.

(4) 3,000 hours operation per year.

(5) Assumes naphtha at \$3.30 (2,000 ppm sulfur), \$3.35 (200 ppm sulfur), and \$3.75 (0.5 ppm sulfur) per 10⁶ Btu.

SOURCE: Reference 5, updated from 1975 dollars to 1977 dollars.

in 1985 with delivered energy costs (including fuel and capital charges) in the range of 50 to 58 mills/kWh.

Certain capital cost credits can be applied to these figures for a distributed energy system. One credit includes transmission and distribution savings of \$29 to \$36/kW⁽⁶⁾ because the fuel cell can be located close to the load. Another credit of \$4 to \$15/kW is due to a decrease in the need for spinning reserve, which is required by conventional power plants that operate at relatively low efficiency at low loads.⁽⁶⁾

It should be emphasized that the power cost estimates reported in Table 16-1 are for fuel cell systems operated only 3,000 hours/year (peak to intermediate range). It would be unrealistic to attempt to compare these figures with the cost of power from baseloaded systems which write off their capital charges over many more operating hours.

On-site fuel cell cogeneration systems have been studied for a number of industrial applications.⁽⁷⁾ In these cases the economics are improved both by higher capacity factors (since the systems are usually baseload) and by credits for waste-heat recovery in the form of steam and hot water for plant use. The economies of scale derive from the fuel processor and ancillary equipment rather than the power system itself which is modular in construction. Waste heat output from both the molten carbonate and phosphoric acid systems is generally estimated at 2500-3500 Btu/kWh at 100-130°C.

Section 16.4: Limitations

It is perhaps premature to assess the limiting factors that might prevent acceptance of fuel cells as primary power generators. The first objective is a successful demonstration of the phosphoric acid cell in a utility application; the prime factor is a cell stack life of at least 10,000 hours at an acceptable level of performance. Also important is meeting a cost goal of \$400/kW. The next objective is to demonstrate technical success with molten-carbonate technology.

Without credits and other intangible factors, the phosphoric acid cell is only marginally attractive and at best should be considered

only in the context of transition to the more efficient molten-carbonate system. Unless it turns out that the molten-carbonate cell is not technically feasible, fuel cell systems must be considered as primary candidates for future distributed energy systems and other selected applications in which the low-grade waste heat can be used advantageously.

Section 16.5: Recent Developments

The molten carbonate fuel cell has long been considered tolerant to high-sulfur fuels, and it is true that anode performance and life are little affected. However, if the anode exhaust is recycled to the cathode as a source of carbon dioxide, then its sulfur content is absorbed almost completely in the oxidizing environment. The sulfur (as sulfate) can then migrate across the cell and attack the nickel components of the anode. Complete sulfur removal from the fuel will add significantly to both the capital and operating cost of molten-carbonate fuel cells.⁽⁸⁾

Major improvements have been made, however, in molten-carbonate cell fabrication.⁽⁹⁾ These improvements increase the time for mixing of the fuel and oxidant streams to occur through the electrolyte--a major source of inefficiency and limitation on life in earlier designs.

REFERENCES

1. Handley, L.M., et al. "4.80 Megawatt Fuel Cell Module Demonstrator." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington D.C., August 28-September 2, 1977. pp. 341 ff.
2. King, J.M. Advanced Technology Fuel Cell Program. Report prepared by United Technologies Corporation for Electric Power Research Institute, November 1977. EPRI Report No. EPRI-EM-576.
3. Lawrence, L.R. "The ERDA Fuel Cell Program." Energy Development IV. IEEE Power Engineering Society, 1978. pp. 199 ff. IEEE Paper No. 78TH0050-S-PWR.
4. Cusamano, J.A., et al. Assessment of Fuel Processing Alternatives for Fuel Cell Power Generation. Report prepared by Catalytica Associates, Inc., for Electric Power Research Institute, October 1977. pp. 3-2 ff. EPRI Report No. EPRI-EM-570.
5. Stickles, R.P., et al. Assessment of Fuels for Power Generation by Electric Utility Fuel Cells. Vol. I. Report prepared by Arthur D. Little, Inc., for Electric Power Research Institute, March 1978. EPRI Report No. EPRI-EM-695.
6. Wood, W., et al. Economic Assessment of the Utilization of Fuel Cells in Electric Utility Systems. Report prepared by Public Service Electric and Gas Company, for Electric Power Research Institute, November 1976. EPRI Report No. EPRI-EM-336.
7. United Technologies, Power Systems Division. On-Site Fuel Cell Resources Conservation in Industrial Process Applications. Report prepared for Energy Research and Development Administration, August 1977. ERDA Report No. FCR-0439.
8. Appleby, J., ed. Proceedings of the DOE/EPRI Workshop on Molten Carbonate Fuel Cells, Oak Ridge National Laboratory, November 1978. To be published by NTIS.
9. Appleby, J., Electric Power Research Institute, Palo Alto, California. Private communication. March 1979.

SUPPLEMENTARY BIBLIOGRAPHY

1. Bockris, J.O., et al. Fuel Cells: Their Electrochemistry. New York: McGraw-Hill, 1969.
2. Liebhafsky, H.A., et al. Fuel Cells and Fuel Batteries. New York: John Wiley & Sons, Inc., 1968.
3. Baker, B.S., ed. Fuel Cell Systems-II. Washington, D.C.: American Chemical Society, 1969.
4. Baker, B.S., ed. Hydrocarbon Fuel Cell Technology. New York: Academic Press, 1965.
5. Young, G.J., et al., eds. Fuel Cell Systems. Washington, D.C.: American Chemical Society, 1965.
6. Mitchell, W. Jr., ed. Fuel Cells. Vol. I.: Chemical Technology. New York: Academic Press, 1963.
7. Steitz, P., et al. An Assessment of the Fuel Cell's Role in Small Utilities. Report prepared by Burns and MacDonnell for Electric Power Research Institute, February 1978. EPRI Report No. EPRI-AF-696.
8. Houghtby, W.E., et al. Advanced Technology Fuel Cell Program. Report prepared by United Technologies, Corp. for Electric Power Research Institute, December 1978. EPRI Report No. EPRI-EM-956.
9. Wakefield, R., et al. An Analysis of the Application of Fuel Cells in Dual Energy Use Systems. Report prepared by Mathtech, Inc. for Electric Power Research Institute, February 1979. EPRI Report No. EPRI-EM-981.
10. Simons, S.N., et al. Comparison of Fuel-Cell and Diesel Integrated Energy Systems and a Conventional System for a 500-Unit Apartment. National Aeronautics and Space Administration, November 1978. NASA Report No. NASA-TM-79037.
11. Stickles, R.P., et al. Assessment of Industrial Applications for Fuel Cell Cogeneration Systems. Report prepared by Arthur D. Little, Inc. for National Aeronautics and Space Administration, September 1978. NASA Report No. NASA-CR-135429.
12. Dynatrend, Inc. National Fuel Cell Seminar, Boston, Massachusetts, June 21, 1977. Prepared by the U.S. Department of Energy, 1977. NTIS Report No. CONF-770664.
13. Energy Research and Development Administration. ERDA/EPRI Fuel Cell Seminar, Palo Alto, California, June 29, 1976. Sponsored jointly by the Division of Conservation Research and Technology of the Energy Research and Development Administration and the Electric Power Research Institute, June 1976. NTIS Report No. CONF-7606156.

SUPPLEMENTARY BIBLIOGRAPHY (continued)

14. Cavagnaro, D. Hydrocarbon Fuel Cells (Citations from the American Petroleum Institute Data Base). Report for 1967 - April 1978. National Technical Information Service, July 1978. NTIS Report No. NTIS/PS-78/0651.
15. Cavagnaro, D. Fuel Cells. Vol. 3: 1977 - June 1978. National Technical Information Service, June 1978. NTIS Report No. NTIS/PS-78/0633.
16. Cavagnaro, D. Fuel Cells. Vol. 2: 1974-1976. National Technical Information Service, July 1978. NTIS Report No. NTIS/PS-78/0632.
17. Burnett, W.M. Fuel Cell Benefits: The Program Management Office Viewpoint. Energy Research and Development Administration, 1976. NTIS Report No. TID-27748.
- 18.. Energy Research and Development Administration. Fuel Cells: A Bibliography. June 1977. NTIS Report No. TID-3359.
19. King, J.M. Energy Conversion Alternatives Study (ECAS). Integrated Coal Gasifier/Molten Carbonate Fuel Cell Powerplant Conceptual Design and Implementation Assessment. Final Report on Phase 2. Report prepared by United Technologies Corporation for National Aeronautics and Space Administration, 1976. NTIS Report No. PB 270 016.
20. Mixon, W.R., et al. Market Assessment of Fuel Cell Total Energy Systems Summary Report. Oak Ridge National Laboratory, March 1979. NTIS Report No. ORNL/CON-36.
21. Wood, W., et al. "Economic Assessment of the Utilization of Fuel Cells in Electric Utility Systems." IEEE Trans. Power Apparatus and Systems PAS-97(5):1805, September/October 1978.
22. Cameron, D.S. "Fuel Cell Energy Generators; Platinum Catalysts Used in Alternative Energy Source." Platinum Met. Rev. 22(2):38, April 1978.
23. Voelker, G.E. "Department of Energy Fuel-Cell Program." Workshop on Dual Energy Use Systems, Yarmouth, Maine, September 19, 1977. Sponsored by the Electric Power Research Institute. EPRI Report No. EPRI-EM-718-W.
24. Fickett, A.P. "DEUS Fuel Cells." Workshop on Dual Energy Use Systems, Yarmouth, Maine, September 19, 1977. Sponsored by the Electric Power Research Institute. EPRI Report No. EPRI-EM-718-W.
25. Davis, J.C. "Fuel-Cell Trials: Utilities Now, CPI Next?" Chemical Engineering 85:79, August 14, 1978.

SUPPLEMENTARY BIBLIOGRAPHY (continued)

26. Fickett, A.P., ed. Conference Proceedings: Fuel Cell Catalysis Workshop, Palo Alto, California, January 15-17, 1975. Prepared by Electric Power Research Institute, August 1975. NTIS Report No. PB 245 115.
27. Blurton, K.F. "Gas Utilities and Fuel Cells." Conference on Fuel Cells and the Hydrogen Economy: A Viable Alternative Source of Energy for New York State, Old Westbury, New York, September 14, 1978. NTIS Report No. CONF-7809101-1.

TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: HEAT PUMPS</p> <p>DESCRIPTION: A device which absorbs heat at one temperature and rejects the heat at a higher temperature through the expenditure of work. Most often the heat pump is used for space heating or cooling of a building but can be used for waste heat recovery applications.</p> <p>POTENTIAL USER CLASSES: Residential and Commercial</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: The heat pump is a commercial item for sizes commonly found in residential and commercial buildings.</p>																																										
TECHNICAL	<table border="1" data-bbox="837 520 1353 777"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (10³ Btu/hr) PRIMARY</td> <td>18-60 (cooling)</td> <td>same</td> <td>same</td> </tr> <tr> <td>SECONDARY</td> <td>30-105 (heating)</td> <td></td> <td></td> </tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10⁶ Btu) PRIMARY</td> <td>22-74 (cooling)</td> <td></td> <td></td> </tr> <tr> <td>SECONDARY</td> <td>42-147 (heating)</td> <td></td> <td></td> </tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR: (i)</td> <td>.14 (cooling)</td> <td>same</td> <td>same</td> </tr> <tr> <td></td> <td>.16 (heating)</td> <td></td> <td></td> </tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td> <td>.05-.23 (cooling)</td> <td>same</td> <td>same</td> </tr> <tr> <td></td> <td>.02-.29 (heating)</td> <td></td> <td></td> </tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN): (ii)</td> <td>1.5-2.5</td> <td>2-3</td> <td>same</td> </tr> </tbody> </table> <p>PRIMARY FUEL(S): Electricity AMOUNT NEEDED PER UNIT OUTPUT: 0.67 - 0.4</p> <p>ALTERNATIVE FUEL(S): Gas heat pumps IS SYSTEM READILY CONVERTIBLE? No may be available in the future.</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: The output (heating/cooling) and efficiency of output fluctuates directly with outdoor temperature.</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Not applicable</p> <p>TECHNICALLY PRACTICAL? Not applicable</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? SYSTEM: Not applicable</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (10 ³ Btu/hr) PRIMARY	18-60 (cooling)	same	same	SECONDARY	30-105 (heating)			UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ Btu) PRIMARY	22-74 (cooling)			SECONDARY	42-147 (heating)			AVERAGE EFFECTIVE CAPACITY FACTOR: (i)	.14 (cooling)	same	same		.16 (heating)			RANGE OF CAPACITY FACTORS:	.05-.23 (cooling)	same	same		.02-.29 (heating)			EFFICIENCY (BTU OUT/BTU IN): (ii)	1.5-2.5	2-3	same
	1977	1985	2000																																								
UNIT POWER OUTPUT CAPACITY: (10 ³ Btu/hr) PRIMARY	18-60 (cooling)	same	same																																								
SECONDARY	30-105 (heating)																																										
UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ Btu) PRIMARY	22-74 (cooling)																																										
SECONDARY	42-147 (heating)																																										
AVERAGE EFFECTIVE CAPACITY FACTOR: (i)	.14 (cooling)	same	same																																								
	.16 (heating)																																										
RANGE OF CAPACITY FACTORS:	.05-.23 (cooling)	same	same																																								
	.02-.29 (heating)																																										
EFFICIENCY (BTU OUT/BTU IN): (ii)	1.5-2.5	2-3	same																																								
ECONOMIC	<table border="1" data-bbox="869 1203 1356 1371"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/10² Btu/hr) (iii)</td> <td>5.6-6.5</td> <td>same</td> <td>same</td> </tr> <tr> <td>AVERAGE UNIT O&M: \$/year (iv)</td> <td>\$58.00</td> <td>same</td> <td>same</td> </tr> <tr> <td>CONSTRUCTION PERIOD:</td> <td>1-10 days</td> <td>same</td> <td>same</td> </tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/10 ² Btu/hr) (iii)	5.6-6.5	same	same	AVERAGE UNIT O&M: \$/year (iv)	\$58.00	same	same	CONSTRUCTION PERIOD:	1-10 days	same	same																								
	1977	1985	2000																																								
TOTAL INSTALLED UNIT CAPITAL COST: (\$/10 ² Btu/hr) (iii)	5.6-6.5	same	same																																								
AVERAGE UNIT O&M: \$/year (iv)	\$58.00	same	same																																								
CONSTRUCTION PERIOD:	1-10 days	same	same																																								
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: The major air conditioner manufacturers market heat pumps for commercial and residential buildings.</p> <p>GEOGRAPHIC LIMITATIONS: Operation in the northern climates (35° north latitude and above) requires careful application and may not offer as high an economic return on investment as more southern installations.</p> <p>ENVIRONMENTAL EFFECTS: None - other than the possible release of fluorocarbons to the atmosphere</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: Heat pumps may impact the peak demand for electricity.</p>																																										
COMMENTS	<p>(i) The annual energy output is highly dependent on climatic conditions. 400 compressor hours are typical for cooling and 2500 compressor hours are typical for heating in Boston; 2000 cooling and 200 heating compressor hours are typical for the Gulf Coast according to Arthur D. Little, Inc. test data.</p> <p>(ii) The efficiency or coefficient of performance (COP) of the heat pump is the delivered heat per unit of electric power used to drive the unit. Improvements are expected to raise the efficiency in the future.</p> <p>(iii) Cost figures are based on 1977 dollars (1978 dollars divided by 1.07) from Figure 17-15. These values are for 3- and 5-ton units.</p> <p>(iv) Operating and maintenance costs are based on a single-family dwelling requiring a 3- and 5-ton capacity heat pump (heating and cooling). These do not include energy costs which add \$600-\$1000 per year, depending on climatic conditions and local energy cost. (19)</p>																																										

CHAPTER 17

HEAT PUMPS

Section 17.1: Introduction

A. What is a Heat Pump?

A heat pump is a thermodynamic refrigeration cycle machine which moves heat from a low-temperature source to a higher-temperature sink by the addition of work. When low temperatures are desired, as in air conditioning or refrigeration, the heat pump removes unwanted heat and expels it to a higher-temperature sink (such as warm outside air or water). When high-temperature heating applications are desired, the heat pump supplies this energy by drawing it from a low-temperature source (usually cold outside air or water). Thus, there is little difference between a refrigerator and heat pump; the difference is entirely in the purpose of the process.

In many applications, including most residential and commercial uses, the same machine may at one time operate as an air conditioner, and at another time as a heater. In some industrial applications, the heat pump may be used for cooling at one temperature level and simultaneously for heating at another temperature. For instance, in a brewery in Florida,⁽¹⁾ a heat pump is being considered to remove heat (i.e., refrigerate) from the fermentation vats and "pump" this heat up to heat water to be used elsewhere in the facility. In large commercial buildings, heat pumps have been used to "pump" heat from the warm side of the building (sun load or internal heat generation) to the colder side of the building.

Figure 17-1 shows the thermodynamic system. The absolute temperature of the source is T_L degrees, and the heat extracted from the source is Q_L . The energy rejected to the sink at temperature T_H degrees is Q_H . Both effects are accompanied by the input of work, W . From the first law of thermodynamics:

$$Q_H = Q_L + W ;$$

FIGURE 17-1 A THERMODYNAMIC SYSTEM ACTING AS A HEAT PUMP

that is, the heat output, Q_H , is the sum of that heat extracted from the cold region plus the energy added to the heat pump. Therefore, the total heat output will always be greater than the energy required to run the device, and thus the coefficient of performance (COP) will always be greater than unity:

$$COP_{HP_H} = Q_H/W > 1.$$

It is important to note that sometimes a portion of the heat, Q_H , is not delivered to the desired space. For example, when outdoor compressor units are used, some of the energy available for space heating is lost before it can enter the house. Under these conditions, the actual COP based on delivered Q_H can be less than 1.

Conversely, heat removed in air conditioning or refrigeration is less than the heat rejected, and therefore the COP of a heat pump in the cooling mode is less than when it is used for heating. It can be shown that

$$COP_{HP_{AC}} = Q_L/W = COP_{HP_H} - 1.$$

Vapor cycles utilizing mechanical compression are most common for heat pumps. The majority of heat pumps used in the United States are refrigeration cycle machines which typically use liquid-vapor refrigerant as the working fluid in a vapor-compression cycle. The primary components of a vapor-compression cycle and a typical set of fluid states during cycle operation are shown in Figure 17-2. Compressed vapor is liquefied in the condenser and subcooled to a temperature 5° to 10°F less than the condensing temperature. The subcooled liquid is expanded through a flow restriction (a valve or capillary tube), creating a two-phase, low-pressure, cold fluid which passes through the evaporator where heat is drawn from the environment to be cooled, evaporating the cold liquid so that gas may be returned for compression. Compressors used in residential applications are typically positive displacement devices and are capable of providing compressed gas over a wide range of pressures.

SOURCE: Arthur D. Little, Inc., estimates based on a 45°F outdoor temperature and a 20°F air-to-heat exchanger temperature difference, standard fluid properties of refrigerant 22, and an ideal gas compression process. Derived from General Electric sales literature entitled "General Performance Curves for Packaged Units," July 1973.

FIGURE 17-2 TYPICAL FLUID STATES DURING HEAT PUMP HEATING MODE

B. Typical Applications for Heat Pumps

The predominant use of heat pumps sold for residential and commercial purposes is for space heating in the winter and space cooling in the summer. During the winter, heat is extracted from outdoor air and "pumped up" to the desired temperature levels for heating indoor air; during the summer, the heat pump cycle is reversed and operated as a conventional air conditioner wherein heat is removed from the indoor space and rejected to higher-temperature outdoor air. Because of its ability to move heat "uphill" from a low-temperature source to a higher temperature, the heat pump can also be used as a heat recovery unit. In a 1977 study for ERDA,⁽²⁾ a heat pump was incorporated into a drain-water heat-recovery system to supply heat to a hot water tank. A schematic for this system is shown in Figure 17-3.

Another use of heat pumps has been in the annual cycle energy storage (ACES) concept⁽³⁾ in which a heat pump is used to draw heat from a large container of water during the winter for use in heating the house, and this large chilled container is then used for space cooling in the summer. This system is discussed in Chapter 19 (Thermal Energy Storage).

Section 17.2: Technical Discussion

A. System Description

Common heat pumps can be categorized as either air-source or water-source heat pumps, as shown in Figure 17-4. Air-source equipment, including air-to-air (first term refers to source, second to sink) and air-to-water units, is dependent upon outside air for heat exchange. Water-source equipment, including water-to-air and water-to-water units, makes use of groundwater tables, large reservoirs, and, in some commercial applications, rivers.

Heat pumps can be either self-contained (i.e., packaged) or split-system. (See Figure 17-5.) Self-contained heat pumps typically consist of a hermetic compressor (housed in an isolated compartment to cut the sound level), a condenser, evaporator, fans, defrost controls,

SOURCE: Reference 2.

FIGURE 17-3 SCHEMATIC OF A DRAIN-HEAT-RECOVERY SYSTEM FOR WATER PREHEAT

* All single-stage compression

SOURCE: Reference 4.

FIGURE 17-4 COMMON HEAT PUMP CATEGORIES

SOURCE: Reference 5.

FIGURE 17-5 SAMPLE HEAT PUMP SCHEMATICS

and an optional supplemental electric resistance heating element. In current split-system heat pumps, the air-handling unit (indoor coil, fan, and supplemental heater, if used) is remote from the main unit, which is outdoors. This configuration is similar to that of conventional residential central air conditioning installations.

Air and water source models can be found in either configuration, though self-contained air-to-air units are by far the most common, particularly in residential construction, where unit capacities typically range from 1.5 to 3 tons.* Large water-to-water machines are used mainly for commercial or industrial applications. Light commercial units run about 5-25 tons, while large commercial and industrial units exceed 25 tons.⁽⁵⁾ Water-to-water machines also come in sizes small enough for residential applications, but the costs of a water interchanger and a water-cooled condenser make such installations expensive.

Packaged air-to-air heat pumps typically do not exceed 15 tons of cooling capacity. Packaged water-to-air machines are available with up to 40 tons of cooling capacity, and some models go up to 200 tons. Split-system heat pumps have no upper limit on capacity, and commercial systems have been installed with centrifugal compressors and capacities exceeding 10,000 tons.

The major manufacturers of heat pumps, in order of ranking by sales volume, are: General Electric, Carrier, Lennox, Amana, and Westinghouse.⁽⁶⁾ All are suppliers of a broad range of equipment, although only Carrier offers large equipment for commercial projects and only General Electric provides water source equipment.

Since 1975, when 158,000 units were shipped, sales of air-to-air heat pumps have risen rapidly although not as steeply as projected. For example, estimates from Reference 7 show sales of 560,000 units in

* The common unit of refrigeration is the ton. This was originally intended to be the rate of heat transfer necessary to freeze 1 ton (2,000 lb mass) of water at 32°F in 24 hours. If the latent heat or enthalpy of fusion of liquid water to ice is taken as 144 Btu/lb, the definition is obtained: 1 ton is equivalent to the removal of 288,000 Btu/day, which is more conveniently applied as 12,000 Btu/hr or 200 Btu/min.

1978 and projected sales of 475,000 to 525,000 in 1979 which is about 500,000 less than projected sales for 1979 made a year earlier. (See Figure 17-6.)

Table 17-1⁽¹⁰⁾ shows the 1974 end-use of heat pumps by sector and type. While Reference 10 has not been updated for subsequent years, the residential market probably now holds an even greater percentage of total shipments, since the growth of heat pump sales is in large part due to new home installations.

B. Operational Characteristics

Whether the heat pump application is conventional air-to-air or water-to-air or a heat-recovery unit, the heat pump performance is highly dependent on the two temperatures between which it operates. For a typical heat pump during the heating season, the following performance variations with outdoor and indoor temperature variations were found by Kelley:⁽⁹⁾

- +1.1% increase in COP per 1°F increase in outdoor temperature;
- +1.3% increase in COP per 1°F decrease in return indoor air temperature.

This dependence on temperature is common for all thermodynamic refrigeration cycles, for which an "ideal" thermodynamic efficiency can be defined. The French physicist Carnot hypothesized a perfect thermodynamic cycle using perfect machines for pumping heat between two temperature sources. For this cycle the upper limit of the coefficient of performance is found to be:

$$\text{COP}_{\text{HP}_H} = \frac{T_H}{T_H - T_L}.$$

Absolute temperatures are used (Rankine or Kelvin) for the high temperature, T_H , and low temperature, T_L . The maximum Carnot (ideal) efficiency, assuming ideal heat exchangers, is shown in Figure 17-7, along with Kelley's data representing the actual measured efficiency of a particular heat pump presently sold for residential air-to-air application. The deviation between the ideal and the actual is due to three real machine constraints:

SOURCE: References 7 and 8.

FIGURE 17-6 HEAT PUMP SHIPMENTS (INCLUDING EXPORTS)

TABLE 17-1

END-USE OF HEAT PUMPS SHIPPED TO U.S. MARKETS, 1974

(thousands of units)

	<u>Self-Contained</u>	<u>Split System</u>	<u>Total</u> ⁽¹⁾
Residential	47 ⁽²⁾	49	96
Commercial	24	7	31
Total	71	56	127

SOURCE: (1) Reference 10.
(2) Reference 8.

COP_{HP H} denotes the coefficient of performance (COP) for a heat pump (HP) during the heating mode (H).

FIGURE 17-7 COP_{HP H} VERSUS T_{OUTSIDE} (T_O)

- finite size of heat exchangers, which causes the heat pump to operate between greater temperature differences than the differential between room temperature and outdoor temperature, in order to transfer the heat pumped;
- fan power requirements which do not add to the heating capacity but add to the power requirement; and
- non-ideal compressor efficiencies (typically around 60-70% isentropic efficiency).

The non-ideal heat exchangers with limited size cause the refrigeration unit to reach elevated temperatures on the condensing side in order to reject the heat and depressed temperatures on the evaporator side to absorb the heat. Figure 17-8 shows the effect of the real heat exchanger capacity on the system performance when compared to an ideal heat exchanger.*

If the non-ideal features of a compressor are added, the final COP drops to the level shown in Figure 17-9. Also shown in this figure is the range of reported COP's for air-to-air heat pumps presently sold in the United States. Our estimate of the performance of real components lies somewhat lower than that of the average heat pump sold currently in the United States because we chose to use Hiller's⁽¹¹⁾ estimate of heat exchanger and compressor efficiencies.

The characteristics of the heat pump efficiency discussed in the foregoing section were based on steady-state efficiencies of the units. Three non-steady state factors affect the actual annual Seasonal Performance Factor (SPF), defined as the total seasonal heating over the total energy consumption:

- 1) Supplemental electric resistance heating is required when the heat pump capacity is unable to keep up with the heating load;

* The ideal heat exchanger used here is one in which a constant temperature difference is maintained between the refrigerant and the air temperature. Maintaining constant temperature would in actuality require a variable-flow-rate fan that just matches the heating capacity with the airflow volume.

SOURCE: Arthur D. Little, Inc., calculations based on a typical unit performance.

FIGURE 17-8 EFFECT OF REAL HEAT EXCHANGERS ON HEAT PUMP COP_{HPH}
[FOR $T_H = 70^{\circ}F$ (INDOOR TEMP)]

KEY TO FIGURE		HEAT PUMP		CAPACITY (Btu/hr)
◇	WESTINGHOUSE	HLO	30C 2 1/2 TON SPLIT	30,000
○	SOUTHWEST	SHP	25I 2 1/2 TON SPLIT	34,000
△	TRANE	RPHA	40 4 TON SPLIT	45,000
□	TRANE	SPHC	506 5 1/2 TON SPLIT	65,000

* Air Conditioning and Refrigeration Institute.

SOURCE: Arthur D. Little, Inc., calculations and manufacturers' product literature as follows:
 Westinghouse data from "An Investigation of Methods to Improve Heat Pump Performance and Reliability in a Northern Climate," Final Report, Vol. II, App.A, prepared by Electric Power Research Institute, Report No. EPRI EM-319.
 Southwest data from newspaper advertisement (date unknown).
 Trane data from untitled 1977 product literature on models SPHC 506 and RPHA 40.

FIGURE 17-9 EFFECT OF COMPRESSOR EFFICIENCY ON HEAT PUMP PERFORMANCE

- 2) During mild, humid, outdoor temperature conditions (below 45°F) the outdoor coil will accumulate frost which limits heat exchange and must be removed, and this requires additional energy that does not contribute to the useful space heating; and
- 3) Cycling of the heat pump will accumulate energy losses because of the cooldown of the heating coil when it is not contributing to the space heating.

As the outdoor temperature falls, the capacity of the heat pump also falls, while the heating requirements of the building rise. This is shown in Figure 17-10. At the cross-over point or the "balance point," the heat pump must be operated continuously in order to keep up with the heating requirement. At temperatures below this balance point, auxiliary electric resistance heating is required.* At these lower temperatures, the COP_{HPH} of the heat pump begins to approach that of an electrical resistance system (i.e., $COP_{HPH} \rightarrow 1$).

As the outdoor temperature falls below approximately 45°F, the outdoor coil temperature is generally below freezing and frost accumulates on the outdoor coil. Most heat pumps defrost the outdoor coil by reversing the cycle temporarily (2 to 10 minutes) to provide warm refrigerant to the outdoor coil to melt the frost. Depending on the outdoor temperature, reversing-cycle defrost may add between 5 and 10% to the annual energy cost of the heat pump. (13)

The reverse cycling of the heat pump not only causes the annual energy consumption to rise but is thought to reduce the life of the unit. A sudden thermal shock to the system components occurs during the reversing operation, and after many thousands of these reversals, the performance of the compressor may deteriorate. (14)

Each start and stop of the heat pump has a loss or inefficiency associated with it. There are two causes of this transient loss:

* Growing attention has been given to supplementing the electric heat pump with a gas-fired backup because of the lower cost of gas per end-point Btu. Lennox sells a Fuelmaster Plus based on this principle; see Reference 12.

SOURCE: Reference 12.

FIGURE 17-10 COMPARISON OF HEAT PUMP OUTPUT TO THE HEATING REQUIREMENTS OF A TYPICAL RESIDENCE VS. OUTDOOR TEMPERATURE

- Heat stored in the indoor coil is allowed to dissipate into a non-useful space, and
- Each compressor start must separate the refrigerant from the lubricating oil within the system; this requires energy, causing a small but noticeable loss in system performance.

Kelley's data⁽⁹⁾ on the defrost and the start-up and stop requirements of a heat pump indicate the distinct drop in COP_{HP} of about 20% at 38°F. The energy cost of defrost, start and stop, and the auxiliary electric resistance heating lowers the annual SPF from an average value of 2-2.5 to 1.5-2.0.

Most heat pumps used in the United States locate the compressor unit outdoors because of the noise associated with compressor operation. Some of the heat rejected by the heat pump is lost from the hot compressor to the cold outside air. Electrical resistance heaters are sometimes employed to keep the compressor warm to offset some of the adverse start-up problems with a cold compressor; this means that additional energy is lost with the compressor located outside. Present Air Conditioning and Refrigeration Institute (ARI) test procedures permit the inclusion of the compressor heat as useful space heating if indeed this heat will be usefully provided to the indoor conditions. Some manufacturers have recognized this advantage and have begun to package compressors on the indoor units and provide sound insulation to make this application acceptable, although compressor heat rejected indoors in summer may decrease the heat-pump cooling capacity.

C. Advanced Heat Pumps

An improvement under development is the two-stage or two-speed compressor. In this case, a single stage of compressor capacity is used when the outdoor temperature is above the balance point, and a second stage of heat pump capacity is brought on line below the outdoor balance point. The details of this concept are discussed in References (1) and (9).

Advanced heat pumps using higher motor-compressor efficiencies, variable speed compressors, rotary compressors, increased heat-exchanger surface areas, and improved fans have been under study by the Department

of Energy.⁽¹⁵⁾ Figure 17-11 shows the relationship of anticipated improvements in heat-pump space-heating energy use with the estimated relative capital cost for a single-family home in Atlanta, Georgia. For purposes of comparison with these systems, the relative space-heating energy use and capital cost for domestic gas-fired heating systems is also included. Figure 17-12 gives similar data for Philadelphia where conventional gas-fired heating-system improvements can achieve a 40% savings; but beyond that level, improvements in gas-fired heating require heat pump operation.

The greatest disadvantage of the electric vapor-compression refrigeration system is the expenditure of electricity and the associated fuel consumption at a power plant. The elimination of this work (except for a relatively small liquid pumping requirement) is largely responsible for the perceived economic success of various chemical absorption and absorption-vapor refrigeration systems in commercial use. The systems operate on the principle that certain substances attract and hold large quantities of vapor of other substances at a relatively low temperature which are driven off when the temperature is raised. When the vapor is retained on the surface, or in the capillary pores of the solid, the process is adsorption. When the two substances react, or when the vapor goes into solution, the process is absorption; and for practical combinations of refrigerant and absorbent (exothermic reactions), the chemical reaction heat must be removed along with the latent heat of the vapor. Since the refrigerant-absorbent solution is liquid, it can be pumped to condenser pressure with very little shaft work, and the vapor refrigerant is then driven from the absorbent by heating. Thus the absorption system is attractive where electricity is costly and natural gas or low-grade heat energy (such as waste steam) is plentiful.

The Department of Energy, the Gas Research Institute, and Allied Chemical Corp. are undertaking research to develop an absorption heat pump. It is expected that the machine will be similar in principle to the standard absorption refrigeration cycle shown in Figure 17-13, although specific components and the organic working fluids (absorbent and refrigerant) will be designed for a heat pump characterized by higher temperature differentials than those experienced in a refrigeration unit.⁽¹⁶⁾ The expected performance of the heat pump using proprietary organic working fluids is shown in

(Systems shown are for a single-family home in Atlanta, Ga. The filled in circles represent existing technologies; the open circles represent advanced technologies.)

SOURCE: Reference 15.

FIGURE 17-11 ANNUAL SPACE-HEATING ENERGY USE FOR IMPROVED GAS FURNACES AND ADVANCED HEAT PUMPS VERSUS RELATIVE CAPITAL COST

(Units and combinations of units (multiple numbers) are shown for a single-family home in Philadelphia, PA.)

SOURCE: Reference 15.

FIGURE 17-12 ANNUAL SPACE-HEATING ENERGY USE FOR CONVENTIONAL AND ADVANCED GAS-FIRED SYSTEMS VERSUS RELATIVE CAPITAL COST

Symbol	Typical System	
R - refers to refrigerant	Ammonia	Water
C - refers to absorbent	Water	Lithium Bromide

SOURCE: Reference 17.

FIGURE 17-13 A SIMPLE ABSORPTION REFRIGERATION SYSTEM

Figure 17-12 (point 9) in comparison with energy-conserving approaches on a standard gas-fired furnace (points 1-7). Combinations (e.g., 3, 5, and 7) of improvements are also shown in this figure.

In addition to the gas-fired absorption heat pump, DOE is sponsoring the development of the Stirling/Rankine gas heat pump which has a gas-fired Stirling engine that produces power for driving a conventional Rankine cycle heat pump. The relative cost and energy conservation potential of the Stirling/Rankine gas heat pump are shown in Figure 17-12 as data point 8.

An alternative absorption system is based on batch chemical processes as opposed to flow processes as in the Allied Chemical absorption heat pump. This concept is presently under investigation by the Department of Energy and Sandia Laboratories. In this system, shown in Figure 17-14, heat from a solar collector or fossil fuel is used to evolve a gas, B, over to the condensing unit to form a chemical compound, BC, releasing heat. After this has been accomplished, the chemical, B, is once again driven off the compound, BC, but at a substantially lower temperature, which provides the refrigeration effect at the low-temperature unit. During the heating mode, low-grade energy is used to evolve the gas at the low-temperature source, BC, from which it is transported to the high-temperature unit. Here the gas, B, condenses to form chemical compound AB, thereby liberating thermal energy for space heating. The difficulty of using this system is that it is inherently a batch or non-flow system. This means that a duplicate system must run on alternate cycles in order to maintain a constant heat pump capacity.

Four chemical systems are presently under consideration:

- salt-methanol,
- an ammoniated salt,
- a hydrated salt, and
- sulfuric acid and water.

Section 17.3: Economics Discussion (Residential Applications)

The limited availability of gas to heat new housing and increasing energy prices have encouraged installation of electric heat

SOURCE: Reference 18.

FIGURE 17-14 PROPOSED CHEMICAL ABSORPTION HEAT PUMP

pumps. The growing demand for central air conditioning has also enhanced the market appeal of the heat pump, as has the increasing cost of fuel oil in relation to electric energy for residential heating. There is also a sizable market in add-on's, where electric hot-air furnaces are being upgraded to electric heat pumps to provide air conditioning as well as heating.

A study by Gordian Associates⁽¹⁹⁾ for the Federal Energy Administration reported owning and operating costs for selected heating/air conditioning systems. (See Table 17-2.)^{*} In this study, heating and cooling loads and equipment performance were computer-modeled for eight representative cities and calibrated by actual data from a test house in which the alternative heating/cooling systems were installed. Equipment was sized for each city by established commercial practice and price-corrected for the local labor rate. Annual owning and operating costs include operating and maintenance costs as well as the annual cost required to replace the equipment at the end of its service life. At current energy prices, the first cost of an electric heat pump is still too high to make it cost-competitive with the gas furnace/central air conditioning system; the heat pump is competitive only in temperate regions.

Installed cost of residential split-system heat pumps is plotted in Figure 17-15. This is a 1978 estimate made by a Boston contractor. Comparative pricing is given in Table 17-3^{*} for 1978 installed costs of alternative heating/air conditioning systems.

Table 17-3 also indicates that annual maintenance costs for the heat pump are comparable to those for other heating/air conditioning systems.

Section 17.4: Limitations

One of the principal limiting factors on the use of heat pumps is their performance in the northern climates. As indicated in Section 17.3, heat pump capacity and efficiency fall rapidly with any decrease in

^{*} Note: The original data in Tables 17-2 and 17-3 were escalated to 1978 dollars (unlike the cost data in other chapters) for consistency with the 1978 data in Figure 17-15.

TABLE 17-2

ANNUAL OWNING AND OPERATING COSTS FOR
ALTERNATIVE RESIDENTIAL SPACE CONDITIONING SYSTEMS

(1978 Dollars)

<u>City</u>	<u>Heat Pump</u>	<u>Gas Furnace and Central Air Conditioning</u>	<u>Electric Furnace and Central Air Conditioning</u>	<u>Oil Furnace and Central Air Conditioning</u>	<u>Baseboard Resistance Heaters and Room⁽¹⁾ Air Conditioning</u>
Houston	(688.80) 854 ⁽²⁾	(544.80) 676	(574.04) 712	(685.72) 851	(410.21) 508
Birmingham, AL	(697.66) 866	(572.54) 711	(684.88) 849	(767.00) 951	(499.72) 620
Atlanta	(700.78) 869	(560.57) 696	(656.74) 815	(743.77) 923	(482.98) 599
Tulsa	(744.42) 923	(598.23) 742	(735.74) 913	(811.59) 1007	(538.89) 668
Philadelphia	(885.89) 1099	(743.09) 921	(944.61) 1172	(935.28) 1159	(728.23) 903
Seattle	(477.29) 591	(518.30) 642	(473.23) 587	(684.70) 849	(312.83) 388
Columbus, OH	(876.61) 1087	(701.70) 870	(946.10) 1173	(964.60) 1197	(757.86) 940
Cleveland	(943.29) 1169	(637.59) 791	(1071.75) 1329	(954.83) 1184	(823.81) 1022
Concord, NH	(1044.92) 1296	(667.69) 828	(1219.93) 1513	(928.32) 1151	(1024.90) 1271

(1) Individual room cooling equivalent to 57-89% of full cooling load.

(2) Original cost estimates ⁽¹⁹⁾ are given in 1975 dollars in parentheses. The adjacent costs (including fuel costs) in 1978 dollars were obtained by escalating 1975 dollars by 24%.

* 1 Ton = 12,000 Btu/hr.

SOURCE: Reference 20.

FIGURE 17-15 INSTALLED COST (excluding ducting) RESIDENTIAL SPLIT-SYSTEM HEAT PUMP

TABLE 17-3

COST OF HEATING SYSTEMS⁽¹⁾
(1978 Dollars)

Type	Size of Unit	Heating Unit	Installed Cost				Annual Maintenance Contract Cost
			A/C	Ductwork	Chimney	Total	
Split-System Heat Pump	36,000 Btu/hr	2935 ⁽²⁾ (2,367)		508 (410)	--	3443 (2,777)	62 (50)
Gas Furnace -	64,000 Btu/hr	918	1556	434	92	3000	62
Central A/C	36,000 Btu/hr	(740)	(1,255)	(350)	(74)	(2,419)	(50)
Electric Furnace -	15.36 kW	1147	1371	508	--	3026	62
Central A/C	36,000 Btu/hr	(925)	(1,106)	(410)		(2,441)	(50)
Baseboard Electric -	12.00 kW	1318	865	--	--	2183	37
Three-Room A/C	36,000 Btu/hr	(1,063)	(698)			(1,761)	(30) ⁽³⁾
Oil Furnace -	64,000 Btu/hr	1323	1556	434	220	3534	74
Central A/C	36,000 Btu/hr	(1,067)	(1,255)	(350)	(178)	(2,850) ⁽⁴⁾	(60)

(1) Philadelphia, 1975.

(2) Original cost estimates ⁽¹⁹⁾ are given in 1975 dollars in parentheses. The adjacent costs in 1978 dollars were obtained by escalating 1975 dollars by 24%.

(3) Assumed equal to cost of contract for central air conditioners.

(4) Includes installed cost of oil tank -- \$270.

SOURCE: Reference 19: Gordian Associates, Inc. equipment costs are based on catalog prices or quotations from General Electric Co. except for room air conditioner prices which were taken from Sears, Roebuck and Co. catalog.

outdoor temperature. Improvements in the northern-climate heat pumps will permit their introduction in these areas. Defrost requirements for heat pumps are a limitation since present reverse-cycle-defrost methods reduce performance and are the single largest contributor to reduced system life. Studies^(1,19) indicate that acceptable operating life can be expected from available heat pumps but few data are available. With improved defrost techniques, lifetimes can clearly be extended and the attractiveness of the heat pump enhanced. Extensive data on the average life of modern heat pumps are not yet available, but it is probably approaching 8-10 years.

REFERENCES

1. Looney, Q., Electric Power Research Institute, Palo Alto, California. Personal communications. April 1978.
2. Arthur D. Little, Inc. Design, Development, and Demonstration of a Promising Integrated Appliance, Phase I - Design. Prepared under Contract No. EY-76-C-03-1209 for the Energy Research and Development Administration, September 1977.
3. Moyers, J.C., et al. "The Annual Cycle Energy System Concept and Application." Proceedings of the International Conference on Energy Use Management, Tucson, Arizona, October 24-28, 1977. Vol. II. pp. 231 ff. New York: Pergamon Press, 1978.
4. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. ASHRAE Handbook and Product Directory: 1973 Systems. New York: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1973.
5. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. ASHRAE Handbook and Product Directory: 1975 Equipment. New York: American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., 1975.
6. "Manufacturers' Share of Market or Order of Ranking." Appliance Manufacturer, January 1976. pp. 81 ff.
7. Duffy, G. "Statistical Panorama XIV." Air Conditioning, Heating, and Refrigeration News 146(5):3, January 29, 1979.
8. Duffy, G. "Statistical Panorama XIII." Air Conditioning, Heating, and Refrigeration News 143(5):3, January 30, 1978.
9. Kelley G.E., et al. Dynamic Performance of a Residential Air-to-Air Heat Pump. Washington, D.C.: National Bureau of Standards, 1977.
10. U.S. Department of Commerce. "Air Conditioning and Refrigeration Equipment, 1974." Current Industrial Reports, Series MA-35M. Table 7.
11. Hiller, C.C. et al. "Energy Savings in Vapor Compression Refrigeration and Heating Devices." Proceedings of the Technical Opportunities for Energy Conservation in Appliances, Boston, Massachusetts, May 11, 1976. Conference conducted by Arthur D. Little, Inc. for Energy Research and Development Administration, 1976. NTIS Report No. CONF-7605139.
12. Consdorf, A.P. "Stage Research for Heat Pump Boom." Appliance Manufacturer, November 1975. pp. 43 ff.

REFERENCES (continued)

13. Comley, J., et al. Heat Pumps; Limitations and Potential. Schenectady, New York: Corporate Research and Development, General Electric Company, 1975.
14. Groff, G., et al. "Investigation of Heat Pump Performance in the Northern Climate Through Field Monitoring and Computer Simulation." Preprint. American Society of Heating, Refrigerating and Air-Conditioning Engineers 1978 Semiannual Meeting, Atlanta, Georgia, January 29 - February 2, 1978. To be published in ASHRAE Transactions 84 (Part 1), 1978.
15. Hirst, E. Energy and Economic Benefits of Residential Energy Conservation RD and D. Prepared by Oak Ridge National Laboratory, February, 1978.
16. Murphy, K.P., Allied Chemical Corporation, Morristown, New Jersey. Personal communications. December 1, 1978.
17. Wood, B.D. Applications of Thermodynamics. Reading, Massachusetts: Addison-Wesley, 1969. (Addison-Wesley Series in Mechanics and Thermodynamics.) pp. 205 ff.
18. Miller, M. "Chemical Heat Pumps Now Seem Technically Feasible." Air Conditioning, Heating, and Refrigeration News 143(12):14, March 20, 1978.
19. Gordian Associates. Evaluation of the Air-to-Air Heat Pump for Residential Space Conditioning. Prepared for the Federal Energy Administration, April 23, 1976. NTIS Report No. PB 255 652.
20. American Air Conditioning Company, Boston, Massachusetts. Personal communications. March 1978.

CHAPTER 18
TECHNOLOGY SUMMARY SHEET

GENERAL	<p><u>TECHNOLOGY TITLE:</u> COAL-BASED DOMESTIC HEATING</p> <p><u>DESCRIPTION:</u> Coal is burned in a mechanically stoked domestic furnace for space heating.</p> <p><u>POTENTIAL USER CLASSES:</u> Residences, small businesses</p> <p><u>STATUS OF TECHNOLOGY DEVELOPMENT:</u> Commercial</p>																																		
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td><u>UNIT POWER OUTPUT CAPACITY:</u> (Btu/hr) PRIMARY</td><td>80,000-350,000⁽ⁱ⁾</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td><u>UNIT ANNUAL ENERGY OUTPUT:</u> (10⁶Btu) PRIMARY</td><td>130-550⁽ⁱⁱ⁾</td><td>same</td><td>same</td></tr> <tr> <td>SECONDARY</td><td></td><td></td><td></td></tr> <tr> <td><u>AVERAGE EFFECTIVE CAPACITY FACTOR:</u> (Annual)</td><td>.18⁽ⁱⁱⁱ⁾</td><td>same</td><td>same</td></tr> <tr> <td><u>RANGE OF CAPACITY FACTORS:</u></td><td>.1-.3</td><td>same</td><td>same</td></tr> <tr> <td><u>EFFICIENCY (BTU OUT/BTU IN):</u></td><td>.70</td><td>same</td><td>same</td></tr> </tbody> </table> <p><u>PRIMARY FUEL(S):</u> Coal <u>AMOUNT NEEDED PER UNIT OUTPUT:</u> 4875 Btu/kWh thermal</p> <p><u>ALTERNATIVE FUEL(S):</u> None <u>IS SYSTEM READILY CONVERTIBLE?</u></p> <p><u>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS:</u> Depends on load</p> <p><u>CONNECTION TO CENTRAL UTILITY:</u> Electricity needed for furnace controls and blowers</p> <p><u>DESIRABLE FOR USER?</u></p> <p><u>TECHNICALLY PRACTICAL?</u></p> <p><u>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</u> No</p> <p><u>SYSTEM:</u></p>				1977	1985	2000	<u>UNIT POWER OUTPUT CAPACITY:</u> (Btu/hr) PRIMARY	80,000-350,000 ⁽ⁱ⁾	same	same	SECONDARY				<u>UNIT ANNUAL ENERGY OUTPUT:</u> (10 ⁶ Btu) PRIMARY	130-550 ⁽ⁱⁱ⁾	same	same	SECONDARY				<u>AVERAGE EFFECTIVE CAPACITY FACTOR:</u> (Annual)	.18 ⁽ⁱⁱⁱ⁾	same	same	<u>RANGE OF CAPACITY FACTORS:</u>	.1-.3	same	same	<u>EFFICIENCY (BTU OUT/BTU IN):</u>	.70	same	same
	1977	1985	2000																																
<u>UNIT POWER OUTPUT CAPACITY:</u> (Btu/hr) PRIMARY	80,000-350,000 ⁽ⁱ⁾	same	same																																
SECONDARY																																			
<u>UNIT ANNUAL ENERGY OUTPUT:</u> (10 ⁶ Btu) PRIMARY	130-550 ⁽ⁱⁱ⁾	same	same																																
SECONDARY																																			
<u>AVERAGE EFFECTIVE CAPACITY FACTOR:</u> (Annual)	.18 ⁽ⁱⁱⁱ⁾	same	same																																
<u>RANGE OF CAPACITY FACTORS:</u>	.1-.3	same	same																																
<u>EFFICIENCY (BTU OUT/BTU IN):</u>	.70	same	same																																
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;"></th><th style="width: 16.6%;">1977</th><th style="width: 16.6%;">1985</th><th style="width: 16.6%;">2000</th></tr> </thead> <tbody> <tr> <td><u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10⁶Btu/vr)</td><td></td><td></td><td></td></tr> <tr> <td>(INCLUDES: furnaces, excluding duct work)</td><td>17.54</td><td>same</td><td>same</td></tr> <tr> <td><u>AVERAGE UNIT O&M:</u> (\$/10⁶Btu, excluding fuel)^(iv)</td><td>.88</td><td>same</td><td>same</td></tr> <tr> <td><u>CONSTRUCTION PERIOD:</u></td><td>1-2 days^(v)</td><td>same</td><td>same</td></tr> </tbody> </table>				1977	1985	2000	<u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10 ⁶ Btu/vr)				(INCLUDES: furnaces, excluding duct work)	17.54	same	same	<u>AVERAGE UNIT O&M:</u> (\$/10 ⁶ Btu, excluding fuel) ^(iv)	.88	same	same	<u>CONSTRUCTION PERIOD:</u>	1-2 days ^(v)	same	same												
	1977	1985	2000																																
<u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10 ⁶ Btu/vr)																																			
(INCLUDES: furnaces, excluding duct work)	17.54	same	same																																
<u>AVERAGE UNIT O&M:</u> (\$/10 ⁶ Btu, excluding fuel) ^(iv)	.88	same	same																																
<u>CONSTRUCTION PERIOD:</u>	1-2 days ^(v)	same	same																																
LIMITING FACTORS	<p><u>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION:</u> Furnace production could increase were demand to grow. Coal distribution at this level could be a serious barrier.</p> <p><u>GEOGRAPHIC LIMITATIONS:</u> None</p> <p><u>ENVIRONMENTAL EFFECTS:</u> SO₂, hydrocarbons, and fine particulates emitted; flammability of particulated coal in air, ash disposal</p> <p><u>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS:</u> Distribution system for coal or coal/limestone mixtures</p>																																		
COMMENTS	<p>(i) See page 18-9 and Reference 5.</p> <p>(ii) A typical residential annual heating load is 150x10⁶Btu.</p> <p>(iii) This annual average capacity factor is based on a heating season of seven months during which its furnace will operate 30% of the time.</p> <p>(iv) See Table 18-3, excluding capital recovery costs and fuel costs.</p> <p>(v) This refers to installation time at site.</p>																																		

CHAPTER 18

COAL-BASED DOMESTIC HEATINGSection 18.1: Introduction

Until the widespread availability of distillate fuels, light petroleum fractions, and natural gas, the primary domestic fuels were coal, wood, and charcoal. Coal was usually burned in fireplaces or in hand-stoked domestic furnaces or boilers. Considerable labor was involved in stoking or tending the fire several times per day and in disposing of ash and clinker (fused ash particles) about once a day or slightly less frequently. The resulting smoke also noticeably reduced the air quality in heavily populated areas. In Europe, considerable work has been done to convert coal to a smokeless fuel (via low-temperature carbonization) suitable for domestic use. However, the availability, cost, and convenience of liquid or gaseous fuels effectively ended dependence on coal for domestic heating except in isolated locations.

It has recently been claimed^(1,2) that the technical problems in domestic coal-based fluidized-bed furnaces have been substantially solved and that such furnaces should be cheaper than and indistinguishable from an oil furnace. This chapter compares approaches that would allow the return to coal-based domestic heating. (This excludes burning coal in fireplaces or in open grates, because this approach has very high emissions and is inefficient. Such open-grate burning of coal has been banned in many cities, e.g., London, for many years for this reason.) Obviously, these methods would compete against oil- or gas-based domestic heating.

The approaches for a return to coal-based domestic heating are:

- hand-stoked or mechanically stoked-coal furnaces or boilers;
- fluidized-bed combustion; and
- coal/oil slurries.

Of these, hand-stoked and mechanically stoked furnaces are now available on the market. Much of the work on the small fluidized-bed boiler has been performed in the United Kingdom by Fluidfire, but it appears that the units developed there are not being sold commercially.^(1,3) Coal/oil slurries are prepared by suspending fine particles of coal, about 40% by weight, in distillate or residual fuel oil. Typically, the slurry contains 4-6% water and 0.5% chemicals which are added to stabilize the slurry. These slurries have been burned successfully in boilers designed for gas/oil firing. In principle, this approach could be extended to domestic heating where it would have apparent advantages in being able to use existing tanks for distribution and storage. However, since such slurries would still contain about 55% fuel oil, the cost saving from coal additions would probably not compensate for increased maintenance requirements caused by ash in the coal and residual oil and particulate emission problems. Because of this, coal/oil slurries for domestic heating have not been evaluated, but the other two approaches are evaluated in detail.

Section 18.2 Technical Discussion

A. Hand-Stoking and Mechanical Stoking

1. Hand-Stoking

Hand-stoking was the traditional method used to burn coal in small boilers. In such boilers, ideal uniform combustion cannot be maintained because firing is intermittent. The best condition of the fuel bed is obtained when the coal is fired frequently, in small amounts, and with proper distribution; when caked masses of coal (if any) are broken up as rapidly as formed; and when ashes and clinkers are not allowed to clog the fuel bed. The hand-stoking of a boiler requires skill and technique. There are three general methods:

- Spread-firing. A small amount of fresh coal is distributed evenly over the entire surface of the fire. This is commonly done with anthracite and other low-volatile coals.

- Alternate-firing. Fresh coal is fired on just one-half of the grate at a time. The freshly liberated volatile matter absorbs the necessary heat for combustion from the brighter parts of the fire. It is particularly suitable for non-caking coals.
- Coking-firing. Fresh coal is placed on the front edge of the fire and allowed to coke. After distillation is complete, the coke is spread over the fire. It is especially suited to caking coals. Lower rates of combustion are obtained with this method than with the other two.

We believe that a return to these methods on a large scale is unlikely in the near-term future on any significant scale because of the labor involved (all the coal has to be shoveled and properly sprinkled on the grate), the messy/grimy nature of handstoking which would be unacceptable in most homes, and the high emissions that would result from improper hand stoking. A few manufacturers still sell boilers in this size range. (3,4)

2. Mechanical Stoking

The Prill furnace, ⁽⁵⁾ shown in Figure 18-1, is an example of a domestic, mechanically stoked hot air furnace for space heating. The Prill Manufacturing Company also sells a domestic hot water heater of similar design. Coal is stored in a bunker, withdrawn mechanically by an auger, and fed to a rotating ring that serves as a grate on which the coal burns. The ring slopes slightly downward towards its outer edge so that coal ash falls over this edge into an ash pan as new coal is pushed up through the center of the ring. The ash falling into the pan has to be removed and disposed of periodically. Thus, the furnace is an updraft forced-air furnace somewhat similar to underfeed-stokers used in larger installations. It is interesting that while the larger underfeed-stoker was designed specifically to handle bituminous caking coals, ⁽⁶⁾ the Prill furnace is advertised for use only with non-caking sub-bituminous coal or lignite. ⁽⁵⁾ The furnace has automatic

SOURCE: Undated sales literature (circa. 1977),
Prill Manufacturing Co., Sheridan, Wyoming.

FIGURE 18-1 SCHEMATIC DIAGRAM OF THE PRILL FURNACE

controls and draft regulators. This furnace is started with "charcoal lighter fluid" or a propane torch at the beginning of the heating season and always maintains a "pilot fire" so that the start-up procedure does not have to be repeated each time the thermostat demands heat. The flue gases heat the air or water and are discharged to the atmosphere through a chimney. The environmental emissions from mechanical stokers are shown in Table 18-1, along with comparative figures for other systems, i.e., oil, gas, and fluidized bed. Equivalent data for hand-stoking are not available, but these emissions would be comparable to those for mechanical stoking if the operator is skilled, or would be much higher if the operator is unskilled. The table shows that emissions are significantly higher for coal-based systems and might cause pollution problems in urban locations which already have problems in achieving federal ambient air quality standards.

B. Fluidized-Bed Combustion

Domestic fluidized-bed boilers have been described enthusiastically as a transitional technology by Lovins:⁽²⁾

"They are very compact: a unit producing 8.8 kW(t) (30kBtu/hr) is about 25 x 25 x 36 cm. From the user's point of view it should be indistinguishable from an oil furnace (except cheaper). Granular coal is delivered by hose from a tank truck to a bunker, then gravity fed to a small packaged furnace with very low emissions (NO_x typically a few parts in 10^6). Ash is collected by overflow in a snap-on container akin to a vacuum cleaner bag, changed at each fuel delivery, or in a bunker that can be emptied by a coupled vacuum hose. The technical problems of such a system appear to be substantially solved, and plans for U.S. field testing are proceeding despite lack of federal interest outside CEQ and EPA."

TABLE 18-1

EMISSIONS COMPARISONS

	<u>SO₂</u>	<u>NO₂</u>	<u>CO</u>	<u>HC</u>	<u>PM</u>
<u>Federal Standard</u> ⁽¹⁾ (μg/m ³)					
Annual arith. mean	80	100	10,000	160	75
<u>In Flue Gas</u> mg/m ³ ⁽²⁾					
Gas	NIL	100	25	12	NIL
Oil	220	80	30	20	30
Coal stoker (Prill)	1530	140	400	120	80
Fluidized-Bed Coal	1470	610	860	28	75

(1) Federal standard is for ambient air level.

(2) Assumes excess air of 30% for gas, 50% for oil and coal stoker, and 30% for fluidized-bed coal.

SOURCE: Reference 3.

This description, based on an experimental unit at the University of Aston, England, simplifies the problems involved in installing an appliance of this type for cyclic duty in a home. The potential problems are several.

The pneumatic handling of powdered coal is dangerous since coal/air mixtures are explosive. While coal/air mixtures are handled in industrial power plants during pulverizing, this equipment is ruggedly constructed and designed for proper venting of unavoidable explosions. Venting of explosions in the domestic context could be quite hazardous.

The University of Aston unit is apparently vented to the atmosphere as shown by Squires in a drawing reproduced here as Figure 18-2.⁽¹⁾ A fluidized bed operating in this mode would be expected to discharge the particulates to the atmosphere. Even with cyclones and bag filters, discharge of heavy metals in the form of fine particulates would continue. Further, in a variable environment such as a home heating furnace, it is doubtful if such bag filters would receive proper maintenance and whether temperature excursions could always be prevented. In addition, a shallow fluidized bed, as suggested by the late Professor Elliott,⁽¹⁾ is likely to have high concentrations of carbon monoxide in the flue gas. While SO_2 emissions would be controlled by adding limestone or dolomite to the bed along with the coal, the efficiency of SO_2 control in a shallow bed would also be low.

Another problem is one of startup and of cyclic operation. The University of Aston furnace was reportedly started with a propane burner until the bed solids had reached the operating temperature.⁽¹⁾ Electric heating for this purpose is a suggested alternative.⁽³⁾ For cyclic operations, the bed solids would be expected to retain their heat for a few hours if the fluidized-bed were "slumped" (defluidized). However, the heat loss problem would be severe because of the low solids inventory.

Overall, many safety-related operating problems have to be overcome before the fluidized-bed heater could be considered for domestic installation. Technical solutions to these problems are unlikely to result in a furnace that is "cheaper" than an oil furnace as is claimed by Lovins.⁽²⁾

SOURCE: Reference 1.

FIGURE 18-2 THE FLUIDFIRE FURNACE OF DOUGLAS ELLIOTT,
THE UNIVERSITY OF ASTON, BIRMINGHAM, ENGLAND

Section 18.3: Economics Discussion

Any coal-based domestic heating system requires an infrastructure for the distribution of coal (or a coal/limestone mixture). Cart et al.⁽³⁾ investigated the availability and estimated the cost of such services. However, many problems have to be addressed regarding modes of delivery and storage. Table 18-2 shows the capital cost differences between the Prill furnace and oil- or gas-fired furnaces of the same capacity of about 105,000 Btu/hr.* As might be expected, the coal furnace is the most expensive in terms of initial investment. A very detailed analysis by Cart⁽³⁾ reaches essentially a similar result and concludes that for a specific location (Columbus, Ohio) direct coal utilization and coal-derived substitute natural gas would cost virtually the same in terms of annual costs to a consumer.

Given the environmental and safety problems of the domestic fluidized-bed boiler, we have not attempted to estimate its capital or operating cost. However, the solutions to all the technical problems are likely to result in a furnace that is at least as costly as the Prill furnace, which is significantly costlier than an oil furnace. It should be noted that the capital investment and maintenance costs for these systems were estimated by Cart⁽³⁾ to be approximately the same as those for the Prill furnace.

TABLE 18-2
CAPITAL COST COMPARISON FOR A PRILL COAL FURNACE

<u>Capital Investment</u>	<u>Prill Coal⁽¹⁾ Furnace and Bunker</u>	<u>Oil Furnace⁽²⁾ and Tank</u>	<u>Gas Furnace⁽²⁾</u>
FOB Plant Cost	\$1,960	\$590	\$360
Shipping Cost - 10¢/lb	83	24	22
Installation @ 30%	588	184	109
Total Investment	\$2,631	\$798	\$491
Total Investment (\$/10 ⁶ Btu/yr) ⁽³⁾	17.54	5.32	3.27

SOURCE: (1) Reference 5.

(2) Sears Roebuck and Co., Fall/Winter Catalog, pp. 1000-1004, 42G76182N2(gas) 42G74121N(oil).

(3) Heating load is assumed to be 150×10^6 Btu/yr.

*Prill furnaces range in capacity from 80,000 to 350,000 Btu/hr.⁽⁵⁾

Table 18-3 shows estimates of the operating costs for the Prill furnace, and operating costs and breakeven fuel costs for oil and gas furnaces using the economic ground rules used by Cart,⁽³⁾ i.e., personal discount rate, 7%; mortgage interest rate, 9%; initial equity in the house, 20%; depreciation period, 10 years; personal marginal income tax rate, 25%; local property tax rate, 3%; and property insurance cost, 0.4%. These economic ground rules result in a capital recovery factor of 0.1695. These numbers have been converted to a constant dollar basis by deducting an inflation rate of 6%, resulting in a capital recovery factor of 11%.

The units are typically sized so that the unit operates only 25-30% of the total time during an average winter.⁽³⁾ Table 18-3 assumes that the annual heating load will be 150×10^6 Btu/yr. The assumed cost of coal, delivered to the home is \$2.50/ 10^6 Btu and the annual maintenance costs are 5% of investment, consistent with Cart.⁽³⁾

TABLE 18-3

TOTAL OPERATING COST FOR A PRILL FURNACE AND CORRESPONDING
FUEL BREAKEVEN COSTS FOR OIL AND GAS SYSTEMS

	<u>Prill Furnace</u>	<u>Oil Furnace</u>	<u>Gas Furnace</u>
	-----	One Year	-----
Capital recovery @ 11%	\$289.41	\$ 87.80	\$ 54.00
Maintenance @ 5%	131.55	39.90	24.60
Fuel Cost ⁽¹⁾	535.67	828.93	878.03
TOTAL	<u>\$956.63</u>	<u>\$956.63</u>	<u>\$956.63</u>
\$/ 10^6 Btu ⁽²⁾	6.38	6.38 ⁽¹⁾	6.38 ⁽¹⁾

(1) Coal at \$2.50/ 10^6 Btu; oil and gas costs are equivalent breakeven costs at \$4.42 and \$4.68/ 10^6 Btu, respectively, to give \$6.38/ 10^6 Btu.

(2) Heating load is assumed to be 150×10^6 Btu/yr.

Section 18.4: Limitations

There are numerous barriers that would have to be overcome before the direct use of coal for domestic heating could become widespread. The safety and environmental aspects have been discussed already. Equally important is the lack of a retail distribution system for coal which would provide the automatic delivery and service currently available from fuel oil retailers. The ashes would also present a disposal problem.

The combustion of coal in urban areas will emit significant quantities of hydrocarbons to the atmosphere, as shown in Table 18-1. During the early years of this century, these emissions were reduced in Europe by preparing a "smokeless fuel" for domestic use by low-temperature carbonization of coal. These processes were never widespread in the United States. Currently, only one plant produces such briquettes ("Grilltime" briquettes by Husky) which are nationally distributed.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. Squires, A.M. "Coal: A Past and Future King." Ambio 3(1): 1-14, 1974.
2. Lovins, A.B. Soft Energy Paths: Toward a Durable Peace. Cambridge, Massachusetts: Ballinger Publishing Company, 1977.
3. Cart, E.N., Jr., et al. Evaluation of the Feasibility for Widespread Introduction of Coal into the Residential and Commercial Sectors. Vols. 1 and 2. Report prepared by Exxon Research and Engineering Company for the Council on Environmental Quality, 1977. NTIS Report Nos. PB 281 191 and PB 281 192.
4. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. ASHRAE Handbook and Product Directory: 1975 Equipment. New York: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1975.
5. PMC Corporation, Box 6416, Sheridan, Wyoming. "Engineering Data and Specifications." Undated product literature.
6. Salisbury, J.K. and C. Carmichael, eds. Kent's Mechanical Engineers' Handbook. 12th ed. 2 volumes. New York: John Wiley and Sons, 1950.

CHAPTER 19
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: THERMAL ENERGY STORAGE</p> <p>DESCRIPTION: Thermal energy is stored either as sensible heat (in solids or liquids), as the latent heat associated with a phase change or as the heat of reversible chemical reactions.</p> <p>POTENTIAL USER CLASSES: Residential, commercial, industrial, utility, transportation</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Residential systems developed and cost-effective in some applications; various new systems under development for all user classes.</p>																	
TECHNICAL	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;"><u>THERMAL STORAGE ENERGY DENSITY (Btu/ft³) FOR SPACE HEATING APPLICATIONS: (i)</u></td><td style="width: 20%; text-align: center;">2000</td><td style="width: 30%; text-align: center;">(Solar input)</td></tr> <tr> <td></td><td style="text-align: center;">9000</td><td style="text-align: center;">(Electric input)</td></tr> </table> <p><u>UNIT SIZES (Btu) FOR TYPICAL DIURNAL CYCLE:</u></p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">RESIDENTIAL HEATING</td><td style="width: 20%; text-align: center;">400,000</td><td style="width: 30%;"></td></tr> <tr> <td>COMMERCIAL HEATING</td><td style="text-align: center;">8x10⁶</td><td></td></tr> <tr> <td>UTILITY POWER GENERATION</td><td style="text-align: center;">10¹⁰</td><td></td></tr> </table> <p><u>EFFICIENCY</u> 50 - 90%</p> <p><u>PRIMARY FUEL(S):</u> Electric, solar energy, fossil, nuclear fuels <u>AMOUNT NEEDED PER UNIT OUTPUT:</u> See Efficiency.</p> <p><u>ALTERNATIVE FUEL(S):</u> Waste heat <u>IS SYSTEM READILY CONVERTIBLE?</u> No</p> <p><u>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS:</u> NA*</p> <p><u>CONNECTION TO CENTRAL UTILITY:</u></p> <p><u>DESIRABLE FOR USER?</u> Yes, for peak shaving applications</p> <p><u>TECHNICALLY PRACTICAL?</u> Yes</p> <p><u>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE?</u> No</p> <p><u>SYSTEM:</u> -</p>			<u>THERMAL STORAGE ENERGY DENSITY (Btu/ft³) FOR SPACE HEATING APPLICATIONS: (i)</u>	2000	(Solar input)		9000	(Electric input)	RESIDENTIAL HEATING	400,000		COMMERCIAL HEATING	8x10 ⁶		UTILITY POWER GENERATION	10 ¹⁰	
<u>THERMAL STORAGE ENERGY DENSITY (Btu/ft³) FOR SPACE HEATING APPLICATIONS: (i)</u>	2000	(Solar input)																
	9000	(Electric input)																
RESIDENTIAL HEATING	400,000																	
COMMERCIAL HEATING	8x10 ⁶																	
UTILITY POWER GENERATION	10 ¹⁰																	
ECONOMIC	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; vertical-align: top;"> <p><u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10⁶ Btu)</p> <p>Residential off-peak space heating</p> <p><u>AVERAGE UNIT O&M:</u> (Maintenance only) (ii)</p> <p><u>CONSTRUCTION PERIOD:</u> (iii)</p> </td><td style="width: 50%; border: 1px solid black; text-align: center; vertical-align: top;"> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; border: 1px solid black;">1977</td><td style="width: 33%; border: 1px solid black;">1985</td><td style="width: 33%; border: 1px solid black;">2000</td></tr> <tr> <td style="border: 1px solid black;">3175</td><td style="border: 1px solid black;">same</td><td style="border: 1px solid black;">same</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">2-15% of initial cost/year</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">hours to months</td></tr> </table> </td></tr> </table>			<p><u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10⁶ Btu)</p> <p>Residential off-peak space heating</p> <p><u>AVERAGE UNIT O&M:</u> (Maintenance only) (ii)</p> <p><u>CONSTRUCTION PERIOD:</u> (iii)</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; border: 1px solid black;">1977</td><td style="width: 33%; border: 1px solid black;">1985</td><td style="width: 33%; border: 1px solid black;">2000</td></tr> <tr> <td style="border: 1px solid black;">3175</td><td style="border: 1px solid black;">same</td><td style="border: 1px solid black;">same</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">2-15% of initial cost/year</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">hours to months</td></tr> </table>	1977	1985	2000	3175	same	same	2-15% of initial cost/year			hours to months			
<p><u>TOTAL INSTALLED UNIT CAPITAL COST:</u> (\$/10⁶ Btu)</p> <p>Residential off-peak space heating</p> <p><u>AVERAGE UNIT O&M:</u> (Maintenance only) (ii)</p> <p><u>CONSTRUCTION PERIOD:</u> (iii)</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%; border: 1px solid black;">1977</td><td style="width: 33%; border: 1px solid black;">1985</td><td style="width: 33%; border: 1px solid black;">2000</td></tr> <tr> <td style="border: 1px solid black;">3175</td><td style="border: 1px solid black;">same</td><td style="border: 1px solid black;">same</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">2-15% of initial cost/year</td></tr> <tr> <td colspan="3" style="border: 1px solid black;">hours to months</td></tr> </table>	1977	1985	2000	3175	same	same	2-15% of initial cost/year			hours to months							
1977	1985	2000																
3175	same	same																
2-15% of initial cost/year																		
hours to months																		
LIMITING FACTORS	<p><u>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION:</u> Some materials suggested as storage media not available in commercial quantities. Production capability adequate.</p> <p><u>GEOGRAPHIC LIMITATIONS:</u> None</p> <p><u>ENVIRONMENTAL EFFECTS</u> Safety of some systems questionable</p> <p><u>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS:</u> Public utility regulations and electric utility pricing policies</p>																	
COMMENTS	<p>Potential thermal storage applications are widespread. However, at present, only systems using solar and electric input for residential and commercial space heating, water heating, and air conditioning have been commercialized. Cost-effectiveness of systems will depend on cost of various energy sources including utility rate structures which encourage off-peak use.</p> <p>(i) Different temperature ranges and specific heats lead to different energy densities. (See Section 19.2.)</p> <p>(ii) Little experience on most systems; estimates based on similar devices. No fuel costs involved. (See Section 19.3.)</p> <p>(iii) Construction period varies from a few hours for preassembled units to several months for large units fabricated on site.</p> <p>* NA = Not Applicable.</p>																	

CHAPTER 19

THERMAL ENERGY STORAGESection 19.1: Introduction

Thermal energy storage can be used for several general types of applications. The primary ones are:

- Storing thermal energy for use in reducing peak loads on utility power plants,
- Reducing energy consumption by recovering heat that would normally be wasted and storing it until such time as it can be used either by the same process or by another process (e.g., recovering waste heat from air conditioners for water heating or industrial waste heat recovery),
- Improving the efficiency of heating or cooling devices by reducing cyclic losses,*
- Providing a better source/sink temperature match by storing energy when favorable ambient conditions exist (e.g., an air conditioner could be run at night to charge a cold storage device, or summer heat could be stored to provide space heating in the winter), and
- Making it practical to utilize renewable energy sources which are periodic (e.g., excess solar energy collected during the day can be stored for heating during the night).

For the application involving storage to reduce utility peak loads, either thermal energy is stored at a central utility during off-peak periods to be used to generate power to meet peak demands, or it

* Losses associated with starting a device and bringing it up to its efficient operating range, or similarly with shutting such a device off.

is stored at the point of use in storage appliances such as water heaters, space heaters, or air conditioners using off peak electricity. During peak demand periods, inputs to these storage devices are turned off and energy is withdrawn from storage. The utility in this case may be a central power plant or it may be an on-site system. In either case, thermal energy storage is important in reducing operating costs and capital equipment investment.* Reducing peak demand will result in conserving gas and oil for peak shaving and in higher utilization of coal and nuclear baseload generation equipment.

In most industrial applications, waste heat is recovered and stored for use at a later time.^(5,6) This energy may be used in the industrial process itself to reduce energy consumption, or it may be used to supply space heating or cooling either to the industrial complex or to the nearby area. The waste heat from a utility may also be used in this way.

Section 19.2: Technical Discussion

A. Types of Storage Media

1. Sensible Heat

One way to store thermal energy is as sensible heat. In this case, a mass of material is heated to raise its temperature. The temperature rise required to store a given amount of heat depends on the specific heat of the material. This is numerically equal to its heat capacity which in engineering units is the amount of energy (Btu's) required to raise the temperature of 1 lb of the material 1°F. Water has one of the highest heat capacities. Its value is 1 Btu/lb°F. Rock has a value of approximately 0.2/lb°F. The specific heats of most metals fall in the range

* For further information on these applications for thermal storage see References 1, 2, 3 and 4, and Chapter 3, Solar-Thermal Power Systems, and Chapter 23, Total Energy Systems, of this report.

of 0.05 to 0.2, while insulating materials typically have values ranging from 0.2 to 0.5.

In considering a material for use as a heat storage medium, the density of the material is also important because the heat stored per unit volume depends on both the specific heat and the density. A denser material requires a smaller container, less insulation, and smaller heat exchangers. Since the major cost elements of systems are the storage medium, the container, the heat exchangers and the insulation, units with high volumetric heat capacity are likely to be less expensive.

As energy is withdrawn from a sensible heat storage system, the temperature of the material falls in direct proportion to the amount of heat taken out. Unless appropriate designs are employed, this produces a continuously decreasing exit temperature as the storage unit is discharged. To produce a constant exit temperature in European electric storage space heaters, hot air from storage is mixed with cool return air using thermostatically controlled baffles. Another approach, common in solar applications, uses geometries which promote thermal stratification in the storage medium so that the heat-transfer medium exits from the storage unit at a temperature close to the highest storage temperature. In either case, the storage unit is discharged when the exit temperature of the heat-transfer medium drops below a useful level. This determines the effective storage capacity of a particular design. To charge a storage system, heat must be available at a temperature greater than that to which the device will be elevated due to temperature drops in heat exchangers. These considerations are important in considering how well a heat storage system utilizing a sensible heat storage material will match the application requirements.

Most commercially available thermal storage systems employ sensible heat storage. Examples include storage units for electric space heating, which use ceramic bricks or cast iron, and storage systems for solar space heating, which employ water or rock beds. The former have been used successfully in Europe to improve central utility load factors.⁽⁷⁾

The latter systems have been installed in a variety of U.S. demonstration applications. Representative rock bed and water storage systems for solar applications are shown in Figures 19-1 and 19-2. Storage densities and system sizes selected to meet various residential, commercial, and industrial energy demands have been calculated and are shown in Table 19-1.

2. Phase Change

A second method for storing heat is to use a material which undergoes a phase change at about the temperature at which the energy is also to be used. When a material undergoes a phase change, it absorbs or releases a greater amount of thermal energy than would be exchanged if the material were simply heated or cooled. Phase changes which may be utilized involve the process of solidification, vaporization, crystallization, or hydration. The heat of crystallization is absorbed or released (depending upon whether the process is exothermic or endothermic) when a salt in a saturated solution crystallizes. The heat of hydration is the heat which is released or absorbed when a salt takes on or releases water molecules in going from one hydrate form to another.*

A number of phase change systems are currently being marketed for solar heating applications. Many of these use sodium sulfate decahydrate (Glauber's salt) as the heat storage medium. Among the organizations marketing these systems are:

- OEM Products, Tampa, Florida,
- Architectural Research Corporation, Livonia, Michigan,
- Institute of Energy Conversion, University of Delaware, Newark, Delaware, and
- Solar, Inc., Meads, Nebraska.

A calcium chloride hexahydrate system developed by Dow Chemical, Midland, Michigan, and marketed by Texxor Corp., Omaha, Nebraska, under the trade name of Thermal 81, has been recently introduced.⁽¹⁰⁾ Table 19-2 gives information on these two types of systems plus others which are currently under development.

* Reference 9 presents a general discussion of chemical storage systems.

SOURCE: Solaron Corporation, Denver, Colorado, undated product literature.

FIGURE 19-1 ROCK BED THERMAL STORAGE SYSTEM

SOURCE: Reference 8.

FIGURE 19-2 WATER-BASED THERMAL STORAGE SYSTEM

TABLE 19-1

TYPICAL CHARACTERISTICS OF POSSIBLE HEAT STORAGE SYSTEMS

<u>Storage System</u>	<u>Energy Source</u>	<u>Application</u>	<u>Cycle</u>	<u>Energy Density₃ (Btu/ft³)</u>	<u>Typical Systems Size (Btu)</u>
Water	Solar	Residential Space Heating	Diurnal	3400	400,000
Rock bed	Solar	Residential Space Heating	Diurnal	1100	400,000
Ceramic	Off-peak Electricity	Residential Space Heating	Diurnal	9000	400,000
Water	Solar	Residential Space Heating	Seasonal	1910	20×10^6
Water	Solar	Commercial Space Heating	Seasonal	1910	400×10^6
Hot Oil	Power Plant Steam System	Utility Power Generation	Diurnal	5000	10^{10}

SOURCE: Arthur D. Little, Inc., estimates.

TABLE 19-2

THERMAL ENERGY STORAGE SYSTEMS USING PHASE CHANGE MATERIALS

Type of System	Application	Material(s)	Approximate Melting Point (°F)	Firm
PCM* in 3.6 lb plastic film sausages 2" dia. x 22" long	Solar Heating	$\text{Na}_2\text{SO}_4 \cdot 10 \text{ H}_2\text{O}$	89	University of Delaware ⁽¹⁾ Newark, DE
	Electric Cooling	$\text{Na}_2\text{SO}_4 \cdot 10 \text{ H}_2\text{O}$, Na Cl $\text{NH}_4 \text{ Cl}$	55	University of Delaware ⁽¹⁾ Newark, DE
Direct contact between immiscible fluids	Electric Cooling	Trimethylamine & Dowtherm - J®	43	Franklin Institute ⁽¹⁾ Philadelphia, PA
PCM in aerosol type cans 2-1/2" dia. x 7-1/2" high	Electric Heating	$\text{Mg} (\text{NO}_3)_2 \cdot 6 \text{ H}_2\text{O}$	192	Dow Chemical Co. ⁽¹⁾ Midland, MI
	Solar Heating	$\text{Mg} (\text{NO}_3)_2 \cdot 6 \text{ H}_2\text{O}$ & NH_4NO_3	126	Dow Chemical Co. ⁽¹⁾ Midland, MI
PCM in plastic tubes 3-1/2" dia. x 6' long	Solar Heating	$\text{Ca Cl}_2 \cdot 6 \text{ H}_2\text{O}$	81	Dow Chemical Co. ⁽²⁾ Midland, MI
Direct contact between immiscible fluids	Solar Heating	$\text{Na}_2\text{S}_2\text{O}_3 \cdot 5 \text{ H}_2\text{O}$ & Therminol 60	118	Clemson University ⁽¹⁾ Clemson, SC
Phase change in form-stable crystalline polymer pellets.	Solar Heating and Cooling (Absorption)	Polyethylene	266	Monsanto Company ⁽¹⁾ Dayton, OH
Concrete blocks filled with PCM and sealed with epoxy	Passive Solar Heating and Cooling	$\text{CaCl}_2 \cdot 6 \text{ H}_2\text{O}$ Eutectic	74-79	Suntek Research Associates ⁽¹⁾ Corte Madera, CA
Scraped tube heat exchanger	Solar Thermal Power	NaNO_3	~ 550	Honeywell, Inc.-ERC ⁽¹⁾ Minneapolis, MN
PCM in large containers with internal heat exchangers	Electric Water Heating or Power Generation	NaOH	~ 600	Comstock and Wescott, Inc. ⁽³⁾ Cambridge, MA
Heat pipe concept	Solar Thermal Power	Mixed chlorides	~ 750	Naval Research Lab ⁽⁴⁾ Washington D.C.
Shell and tube	Solar & Conv. Thermal Power	Mixed carborates	~1000	Institute of Gas Technology, Chicago, IL
Shell and tube	Solar Thermal Power & Road Vehicle Propulsion	Mixed fluorides	~1500	Philips Research Laboratories ⁽⁵⁾ Eindhoven, The Netherlands

*Phase change material.

SOURCE: (1) Reference 12.
 (2) Reference 10.
 (3) Reference 11.
 (4) Reference 13.
 (5) Reference 14.

In order to utilize phase change materials, a number of design problems must be solved. First, the materials are generally corrosive. Second, they may involve a state change which can limit heat transfer because of a build-up of solid material on heat exchanger surfaces. In order to provide better heat transfer, "active" heat exchangers are being developed which employ mechanical methods to remove solidified material from heat exchanger surfaces or to prevent the material from forming on the surfaces. Other research is directed toward developing immiscible fluid systems which employ direct contact heat between a heat-transfer fluid and a saturated solution of a salt to avoid the problem of crystal build-up on heat exchanger surfaces. The major problem with this approach is the selection of two fluids which are truly immiscible. In practice, although fluids may be immiscible initially, repeated thermal cycling with agitation leads to the formation of emulsions. A third problem with the advanced phase-change systems is that they are more expensive than the systems based on sensible heat materials.

It is anticipated that these disadvantages will be offset by economies which result from the ability to store and remove heat at a constant temperature and thus more closely match the requirements for a particular application. For instance, when water is used as the storage medium, it is typically cycled from a low temperature of 100°F to a high temperature between 150 and 200°F. In this case a collector will have to provide energy at a temperature of 175-225°F. The use of a phase-change material for the storage medium means that a simpler, lower cost, and more efficient collector could be used. Similarly, in a cold storage application where a heat pump, air conditioner, or ice maker is used to cool a mass of material, the operating efficiency of the compressor decreases as the temperature of the storage medium drops. The use of a material which maintains a constant temperature means that the compressor can be smaller and consequently lower in cost and in energy required to operate it.

3. Chemical Systems

The third class of storage systems involves chemical reactions. In this case, a chemical reaction which goes in one direction or another

direction, depending on the temperature at the two end-points, is utilized to store energy. Because the thermal energy is stored chemically, standby losses are minimized. This makes these systems particularly attractive for long-term storage applications.

In one type of chemical storage system intended for solar space heating and cooling applications, energy is put in at a high temperature (250-400°F), driving a gas off a salt. This gas either combines exothermally with another salt at a lower temperature (50-100°F), or it is condensed in a low-temperature container. The reaction is reversed in order to give up heat as required by the application. This is done by adding heat to the low-temperature reservoir from ambient, while heat is removed from the higher temperature reservoir. These systems, called "chemical heat pumps," can provide both heating and cooling. The space heating coefficient of performance is greater than one if the heat rejected while charging the system is used for space heating and the unit is discharged by supplying low-temperature energy at outdoor ambient conditions. This means that less collector area will be required to meet a given heating load.

Higher temperature chemical reactions are being explored for storing energy over longer periods for solar power generation. In this case, heat at temperature levels of 500-1000°F from a concentrating collector or collector field is used.

A number of different chemical reactions are currently being explored for these applications. (See Table 19-3.) As with the phase change systems, none of these is presently commercially available, and there are many technical areas which must be considered before they can be utilized. The materials are generally corrosive. Some reactions involve combustible or hazardous gases. In addition, the processes may use gases at pressures of 10 atmospheres or more and require sophisticated instrumentation and controls. It is hoped that the costs associated with solving these areas will be balanced by the fact that the storage material is at ambient temperature and therefore can be used to store energy over a long period of time with minimum standby losses.

TABLE 19-3

CHEMICAL REACTION-BASED THERMAL ENERGY STORAGE SYSTEMS

<u>Chemical Reaction(s)</u>	<u>Application</u>	<u>Temperature Range (°F)</u>	<u>Firm Developing</u>
$\text{CaCl}_2 \cdot 2\text{CH}_3\text{OH}$ (solid) + Heat $\rightleftharpoons$ CaCl_2 (solid) + $2\text{CH}_3\text{OH}$ (vapor)	Solar heating and cooling	100 - 250	EIC Corp. ⁽¹⁾ Newton, MA
$\text{H}_2\text{SO}_4 \cdot \text{H}_2\text{O}$ (liquid) + Heat $\rightleftharpoons$ H_2SO_4 (liquid) + H_2O (vapor)	Solar heating and cooling	100 - 380	Rocket Research ⁽¹⁾ Corp. Woodinville, WA
$\text{MgCl}_2 \cdot 6\text{NH}_3$ (solid) + Heat $\rightleftharpoons$ $\text{MgCl}_2 \cdot 2\text{NH}_3$ (solid) + 4NH_3 (vapor)	Paired reactions for solar heating and cooling	200 - 350	Martin-Marietta ⁽¹⁾ Denver, Colorado
$\text{CaCl}_2 \cdot 8\text{NH}_3$ (solid) + Heat $\rightleftharpoons$ $\text{CaCl}_2 \cdot 4\text{NH}_3$ (solid) + 4NH_3 (vapor)		60 - 100	
$\text{MgCl}_2 \cdot 4\text{H}_2\text{O}$ (solid) + Heat $\rightleftharpoons$ $\text{MgCl}_2 \cdot 2\text{H}_2\text{O}$ (solid) + $2\text{H}_2\text{O}$ (vapor)	Solar heating and cooling	100 - 250	Chemical Energy ⁽²⁾ Specialists Corda Mesa, CA.
SO_3 (vapor) + Heat $\rightleftharpoons$ SO_2 (vapor) + $\frac{1}{2} \text{O}_2$ (vapor)	Power generation	750 - 1600	Boeing ⁽³⁾ Seattle, WA
Mg(OH)_2 (solid) + Heat $\rightleftharpoons$ MgO (solid) + H_2O (vapor)	Solar heating or power generation	700	Atomics ⁽⁴⁾ International Canoga Park, CA
NH_4HSO_4 (liquid) + Heat $\rightleftharpoons$ NH_3 (vapor) + H_2O (vapor) + SO_3 (vapor)	Solar heating or power generation	750 - 1600	U. of Houston ⁽¹⁾ Houston, Texas

(1) Reference 12.

(2) Reference 15.

(3) Reference 16.

(4) Reference 17.

B. Storage Duration

The length of time during which thermal energy must be stored depends on the particular application. Most systems are planned to operate on a fairly regular cycle, which may range from a day to a year. A daily cycle might be used in some solar systems, where heat collected during the day can then be used to heat through the night. To cover extended periods of low insolation, such systems might be increased to several days' capacity. Alternatively, an electrically based heating system might benefit from thermal storage, which could be charged during periods with lower cost, off-peak electricity. Seasonal storage systems, which would have a yearly cycle, may also be practical. The Annual Cycle Energy System (ACES)⁽¹⁸⁾ is one such system. In this system, a heat pump is used to make ice while it is heating a building in the winter. This ice is stored in a large bin and is used as a heat sink in the summer to provide space cooling. In addition to improving seasonal heat pump performance, the ACES system can be used to reduce peak demand on utilities. Recently, several installations have been made in commercial buildings based solely on economic analyses of payback periods. Examples include the Reedburg Vocational School, Reedburg, Wisconsin, and the Getty Manufacturing Company, Racine, Wisconsin.⁽¹⁹⁾

Seasonal storage is also being investigated both to utilize the seasonal temperature changes by storing energy available in one season for use in another season and for recovering waste energy which may be available throughout the year but can only be utilized at particular times during the year.⁽¹⁵⁾ In the latter case, heat rejected by a power plant could be stored in a large storage system continuously and withdrawn as needed by a group of residences in a distributed heating system. Several groups are investigating the possibility of storing this heat underground in large aquifers.⁽²⁰⁾ Water heated by solar collectors, waste heat from a utility, industrial process, or from a total energy system would be pumped underground. When heat was required, the hot water would be extracted. Cold storage can function in a similar way by using cooling ponds, cooling towers, or large natural bodies of water to cool water which is pumped underground.⁽²¹⁾

C. Active vs. Passive Systems

Another distinction which is made in considering storage systems is whether they are active or passive. Active systems generally involve the movement of a fluid to transfer energy from a source of some sort to the point at which energy is to be stored and/or the movement of another fluid to extract energy from storage and transfer it to the point of use. In these systems, energy can be extracted on demand. The source in this case may be a heat exchanger located in a waste stream, a solar collector, or a similar device. The transfer fluid may be water, a heat-transfer oil such as Dowtherm[®], a methanol solution which does not freeze, or air. A similar type of fluid plus heat exchangers may be required on the output side.

In passive systems, various building elements, such as walls, ceilings, and floors, may be used to store energy.⁽²²⁾ The energy may be obtained as solar heat from the outside, by a heating system such as a fuel-fired furnace on the inside of the building, or from waste heat. In passive systems, methods for controlling input and withdrawal of energy are limited to means such as shading a structure from the sun with curtains, overhangs, etc., or by opening or closing ducts to modify natural convective flow.

In an early example of this type of storage (Figure 19-3), a concrete wall was built directly behind a large south-facing window. Recent efforts⁽²⁴⁾ have attempted to improve the passive systems by impregnating porous concrete blocks with phase change materials to increase their thermal capacity at a temperature suitable for space heating or cooling and thereby providing a constant temperature source or sink. A major advantage of any heat storage capacity in the walls of a building is that it tends to dampen the effect of external temperature swings.⁽²⁵⁾ Thus, during the summer, air conditioning demand is reduced by the storage in the walls of a building.

D. Storage Efficiency

The turn-around efficiency of a storage device depends on various

SOURCE: Reference 23.

FIGURE 19-3 TROMBE WALL PASSIVE THERMAL STORAGE SYSTEM

factors, such as its operating temperature range, surface area, insulation, storage interval, etc. Most of the systems currently available are used for space heating in residential buildings on a diurnal basis and are installed in the building. A percentage of standby "losses" contributes useful space heating. The actual percentage depends on whether the unit is located in a space which is normally heated, whether the space is overheated, air circulation paths in the building, etc. These losses are typically 10% or less. Seasonal storage systems may be installed outside and, in addition, standby losses will be higher due to the length of the storage interval. In this case, the losses may be as high as 50%. Estimating efficiencies of the advanced systems is difficult because many are only conceptual designs or laboratory models; however, the efficiencies should lie between the two extremes discussed above.

Section 19.3: Economics Discussion

Costs of thermal energy storage systems in most cases are not well defined at this point. Systems for use with solar energy inputs are generally designed on a one-of-a-kind basis, and, even in the residential market, only a limited number of installations have actually been made. Water and rock are the two media generally used for these applications, with about 70% of the installed systems utilizing water. Approximate costs for these systems for a representative storage capacity are shown in Table 19-4. These are based on the same temperature differential, assuming that the supply temperature from the solar collector is the same in both cases. The cost estimates include insulation and installation of the systems.

Units for storing off-peak electric energy for space heating have been available in Europe for many years. In recent years European companies have begun to market similar units in the United States. These have been modified to meet the more demanding performance and safety requirements of American space heating systems. The system shown in Table 19-4 for this application utilizes bricks and is based on the system manufactured by Creda Corporation in Europe and currently marketed in the United States by TPI Corporation of Johnson City, Tennessee. The

TABLE 19-4

COSTS OF RESIDENTIAL THERMAL ENERGY STORAGE SYSTEMS⁽¹⁾

Input Energy	Method	Quantity of Storage	Cost ⁽²⁾ (\$)	Capacity (Btu) ⁽³⁾	Temperature Swing (°F)	\$/10 ⁶ Btu
Solar	Unpressurized Water	900 gal	2000	400,000	55	5000
Solar	Rock	30,000 lb	1500 ⁽⁴⁾	400,000	55	3750
Electric	Bricks	1,380 lb	1270 ⁽⁵⁾	400,000	1200	3175
Electric	Ice	630 lb	600	108,000	Melting 20	5560
Electric	Pressurized Hot Water	363 gal	5000 ⁽⁶⁾	400,000	160	12500

(1) These are representative of systems that are commercially available or have been extensively field-tested.

(2) Cost includes installation. These are Arthur D. Little, Inc., estimates based on manufacturers' data referenced below and, for unpressurized water storage, Reference 26. For the ice system, the cost is actually estimated as \$100 plus twice the projected production cost from Reference 27; these units are not commercially available.

(3) Residential sizes for residential applications.

(4) Based on Solaron Corporation, Denver, Colorado, designs and construction costs from 1978 (Building Construction Cost Data - 1978, Robert Snow Means Co., Inc., Duxbury, Massachusetts).

(5) TPI, Corporation, Johnson City, Tennessee, 1979 quote plus installation estimated at 2 man-days @ \$20/hr.

(6) Megatherm, Providence, Rhode Island, 1978 quote plus installation at 2 man-days @ \$20/hr.

price shown is a reasonably firm one for this particular application.

Cold storage for off-peak air conditioning is a relatively new field. Several companies are developing and marketing such systems, but the costs are high and do not yet reflect economies of large production volumes.

The systems shown in this table represent the state-of-the-art for thermal energy storage for residential and commercial heating and cooling equipment. Costs per million Btu's are expected to be somewhat lower for larger systems.* However, while the costs associated with the space required are not significant for these small diurnal residential systems, they are increasingly significant for larger seasonal storage systems and commercial-size installations.

The advanced systems currently being developed have not yet reached the point where production cost estimates are available. As mentioned earlier, it is anticipated that the advanced systems will cost more for an equivalent capacity than the sensible heat systems, but that this cost differential will be offset by improved operational characteristics and reduced space requirements of as much as 50%. Within the next year or so, more definitive comparisons of these systems should be possible.

Installation of commercially available, factory-built, off-peak electric space heating is similar to installation of electric furnaces and requires several hours. Larger systems are assembled on site or fabricated from materials obtained from a variety of suppliers. The installation may include large excavation, erecting large tanks, etc., and take several months.

The annual maintenance requirements of most of these systems are not well established as most are available only as field test prototype or laboratory units. Typical maintenance requirements would include replacing electrical components, recharging spent material, replacing leaking or corroded parts, etc., in order to give an average life of 15 to 20 years which would be required in most applications. Estimates of

* Unpublished calculations suggest that unit storage costs (\$/Btu) may be reduced by a factor of 2 for an increase in system size by a factor of 10. These estimates are limited in their application to residential and commercial diurnal applications.

maintenance costs ranging from 2-15% of initial cost per year have been made by Arthur D. Little, Inc., in unpublished work by comparing these systems on a component-by-component basis with similar components in other applications. Salvage value of the materials is low. No fuel costs are included in operating costs. Some systems use blowers and pumps which require electric input, typically 5% or less of total capacity.

Section 19.4: Limitations

No real barriers exist to the distribution of the commercially available residential systems other than the economics associated with their use. The economic advantages are dependent upon current energy costs and prices. At present, much attention is being given to development of electric rate structures which would encourage the use of off-peak devices. Many utilities are experimenting with storage devices in an attempt to develop guidelines for reasonable off-peak rate structures. The European experience indicates that this is a viable means of shaping utility loads, and the changing fuel price structure in the United States will undoubtedly encourage its further implementation.

Barriers to commercialization which must be considered when evaluating the advanced thermal storage systems are:

- use of space;
- availability of materials; and
- safety.

Storage systems require devoting a significant amount of space in a structure to the storage device. This is a factor which affects the cost of the building itself. In some cases the storage systems can be put underground, but the cost of this type of installation may be higher than the cost of including it within a building. The advanced systems are generally more compact than the systems available commercially, which may offset to some extent their higher costs.

Availability of materials is an important consideration for energy storage systems because large quantities of heat storage material

would be required. Many chemicals currently being considered as heat-storage materials are available in such limited quantities that widespread use would affect the supply and raise the price above levels which are acceptable at present.

The materials being considered for the advanced systems are in many cases corrosive or toxic. In addition, they are stored at elevated temperatures. For example, the Rocket Research System cited above employs concentrated sulfuric acid heated to temperatures of 350-400°F. Another uses ammonia. Clearly these systems will have to be properly engineered and thoroughly tested before they can be accepted for use in residential and commercial installations. This must include demonstrations of these systems to convince insurance companies, regulatory agencies, builders and banks which will provide financing that the systems are reliable and cost-effective.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. "Energy Storage User Needs and Technology Applications." Engineering Foundation Conference, Asilomar, Pacific Grove, California, February 8-13, 1976. NTIS Report No. CONF-7602/2.
2. Public Service Electric and Gas Company. An Assessment of Energy Storage Systems Suitable for Use by Electric Utilities. Report prepared under Contract No. E(1101)-2501 for Energy Research and Development Administration, July 1976. NTIS Report No. EM-2 64.
3. Segaser, C.L., et al. MIUS Systems Analysis - The Effects of Thermal Energy Storage and Solid Waste Incineration Option on MIUS Cost and Fuel Consumption. Oak Ridge National Laboratory, July 1976. NTIS Report No. ORNL/HUD/MIUS-26.
4. Wolfer, B.M. The Potential Benefit of an Advanced Integrated Utility System. National Aeronautics and Space Administration, Lyndon B. Johnson Space Center, Houston, Texas, November 1975. NASA Report No. N76-18671.
5. Cutler, R.R., et al., "Energy Savings through Heat Recovery in the Glass Industry." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 505 ff.
6. Glenn, D.R. Technical and Economic Feasibility of Thermal Energy Storage. General Electric Company, Philadelphia, Pennsylvania, February 1976. NTIS Report No. C00 2558-1.
7. Asbury, J.G., et al. Electric Storage Heating: The Experience in England and Wales and in the Federal Republic of Germany. Argonne National Laboratory, May 1976. NTIS Report No. ANL/ES-50.
8. Patton, A.R. Solar Energy for Heating and Cooling of Buildings. Noyes Data Corporation, New Jersey, 1975. (Energy Technology Review, No. 7.)
9. Grodzka, P.G. Thermal Energy Storage. Lockheed Missiles and Space Company, Inc., Huntsville, Alabama, November 1975. NASA Report No. N76-13592.
10. "Dow Enters Solar Storage Field." Energy User News 4(19):1, May 7, 1979.
11. Cohen, B.M., et al. Development of a Phase-Change Thermal Storage System Using Modified Anhydrous Sodium Hydroxide for Solar Electric Power Generation. Comstock and Wescott, Cambridge, Massachusetts, December 1978.

REFERENCES (continued)

12. Proceedings of the Third Annual Thermal Energy Storage Contractors' Information Exchange Meeting, U.S. Department of Energy, Springfield, Virginia, December 5-6, 1978. To be published as NTIS Report Nos. CONF-781231.
13. Maru, H.C., et al. Molten Salt Thermal Energy Storage Systems. Institute of Gas Technology, Chicago, Illinois, March 1978. NTIS Report No. C00-2888-3.
14. Asselman, G.A.A. "Design Considerations on a Thermal Energy Storage Stirling Engine Automobile." International Automotive Engineering Congress, Society of Automotive Engineers, Detroit, Michigan, February 28 - March 4, 1977. SAE Paper No. 770080.
15. Proceedings of the Second Annual Thermal Energy Storage Contractors' Information Exchange Meeting, Energy Research and Development Administration, Gatlinburg, Tennessee, September 29, 1977. Published as NTIS Report Nos. CONF-770955.
16. Gintz, J.R. Technical and Economic Assessment of Phase Change and Thermochemical Advanced Thermal Energy Storage (TES) Systems. Report prepared by Boeing Engineering and Construction for Electric Power Research Institute, December 1976. Report No. EPRI-EM-256.
17. Ervin, G. "Solar Heat Storage Based on Inorganic Chemical Reactions." Solar Energy Storage Subsystems for the Heating and Cooling of Buildings, Workshop Proceedings, Charlottesville, Virginia, April 16-18, 1975. NTIS Report No. PB 252-449.
18. Fischer, H.C., et al. The Annual Cycle Energy System: Initial Investigations. Oak Ridge National Laboratory, October 1976. NTIS Report No. ORNL/TM-5525.
19. Minturn, R., Oak Ridge National Laboratory, Oak Ridge, Tennessee. Personal communications. February 28, 1979.
20. Thermal Energy Storage in Aquifers, Workshop Proceedings, Berkeley, California, May 10-12, 1978. NTIS Report No. CONF-7805140.
21. Davison, R.R., et al. "Storing Sunlight Underground - The Solaterre System." Chemical Technology 5:736, December 1975.
22. Berlad, A.L., et al. Enthalpy Management in Buildings: An Analysis and an Integrated Approach. Brookhaven National Laboratory, July 1975. NTIS Report No. BNL 20572.

REFERENCES (continued)

23. Duffie, J.A., et al. Solar Energy Thermal Processes. New York: John Wiley and Sons, 1974.
24. Charoudi, D. "Thermocrete and Thermotile Components with Isothermal Heat Storage." Second Annual Proceedings of Thermal Energy Storage Contractors' Information Exchange Meeting, September 1977. NTIS Report No. CONF-770955.
25. Wessling, Jr., F.G. Thermal Energy Storage in Adobe and in Stone Structures. American Society of Mechanical Engineers. 1974. ASME Paper No. 74-WA/HT-15.
26. Szego, G.C. "Hot Water Storage Systems Group Report." Solar Energy Storage Subsystems for the Heating and Cooling of Buildings, Workshop Proceedings, Charlottesville, Virginia, April 16-18, 1975. NTIS Report No. PB 252 449.
27. Cook, R.E., et al. "Concept and Development of a Residential Ice Storage System." ASHRAE Transactions 83(Part 1):687, 1977.

TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: SECONDARY BATTERIES</p> <p>DESCRIPTION: Reversible electrochemical reactions are used to store electrical energy.</p> <p>POTENTIAL USER CLASSES: Electric utility, industrial, commercial, residential</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Established technology is expensive; emerging technology promises more attractive economics.</p>																																		
TECHNICAL	<table border="1"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td> <td>.020-20</td> <td>same</td> <td>same</td> </tr> <tr> <td>SECONDARY</td> <td></td> <td></td> <td></td> </tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY</td> <td>26-26,000</td> <td>same</td> <td>same</td> </tr> <tr> <td>SECONDARY</td> <td></td> <td></td> <td></td> </tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td> <td>.15⁽ⁱ⁾</td> <td>same</td> <td>same</td> </tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td> <td>0-.40</td> <td>same</td> <td>same</td> </tr> <tr> <td>EFFICIENCY: (kWh out/kWh in)</td> <td>.75</td> <td>same</td> <td>same</td> </tr> </tbody> </table> <p>PRIMARY FUEL(S): Electrical energy AMOUNT NEEDED PER UNIT OUTPUT: See Efficiency.</p> <p>ALTERNATIVE FUEL(S): NA* IS SYSTEM READILY CONVERTIBLE? NA</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Load following</p> <p>CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Yes</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? SYSTEM: NA</p>				1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.020-20	same	same	SECONDARY				UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY	26-26,000	same	same	SECONDARY				AVERAGE EFFECTIVE CAPACITY FACTOR:	.15 ⁽ⁱ⁾	same	same	RANGE OF CAPACITY FACTORS:	0-.40	same	same	EFFICIENCY: (kWh out/kWh in)	.75	same	same
	1977	1985	2000																																
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	.020-20	same	same																																
SECONDARY																																			
UNIT ANNUAL ENERGY OUTPUT: (MWh) PRIMARY	26-26,000	same	same																																
SECONDARY																																			
AVERAGE EFFECTIVE CAPACITY FACTOR:	.15 ⁽ⁱ⁾	same	same																																
RANGE OF CAPACITY FACTORS:	0-.40	same	same																																
EFFICIENCY: (kWh out/kWh in)	.75	same	same																																
ECONOMIC	<table border="1"> <thead> <tr> <th></th> <th>1977</th> <th>1985</th> <th>2000</th> </tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Converter)</td> <td>520⁽ⁱⁱ⁾</td> <td>400⁽ⁱⁱⁱ⁾</td> <td>250^(iv)</td> </tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)</td> <td>.002</td> <td>same</td> <td>same</td> </tr> <tr> <td>CONSTRUCTION PERIOD:</td> <td>1 year</td> <td>same</td> <td>same</td> </tr> </tbody> </table>				1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Converter)	520 ⁽ⁱⁱ⁾	400 ⁽ⁱⁱⁱ⁾	250 ^(iv)	AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.002	same	same	CONSTRUCTION PERIOD:	1 year	same	same																
	1977	1985	2000																																
TOTAL INSTALLED UNIT CAPITAL COST: (\$/kW) (INCLUDES: Converter)	520 ⁽ⁱⁱ⁾	400 ⁽ⁱⁱⁱ⁾	250 ^(iv)																																
AVERAGE UNIT O&M: (\$/kWh, <u>excluding fuel</u>)	.002	same	same																																
CONSTRUCTION PERIOD:	1 year	same	same																																
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Not limiting</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: No direct effects; effects in vicinity of manufacturing or disposal facility only</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Institutional barrier if perceived as "stop gap" technology</p>																																		
COMMENTS	<p>(i) Capacity factor corresponds to use of a 5-hour discharge, 5 days per week.</p> <p>(ii) For 5-kWh storage capability per rated kilowatt. See Table 20-4 and the discussion on page 20-11. For more hours of storage, costs will be higher. Future cost projections, assuming economies of scale in manufacturing, suggest \$445/kWh.</p> <p>(iii) Refer to Table 20-5 in text.</p> <p>(iv) Estimate.</p> <p>*NA = Not Applicable.</p>																																		

PR

CHAPTER 20

SECONDARY BATTERIES

Section 20.1: Introduction

Batteries constitute a complementary technology in the concept of distributed energy systems (DES). They can assist in the more effective use of centrally generated electrical power by load leveling or peak shaving. Also, they are an almost essential component of distributed primary generating systems, such as photovoltaic arrays or windmills, that operate on a variable or intermittent basis. Batteries can also assist dispersed primary generators to meet peak demands above the generator's rated power capability.

The manufacture of batteries based on the lead-acid system is a long established technology that is available today. However, the industry has little experience in building the very large batteries contemplated for load leveling (that is, routine deep discharge). Very large emergency power systems, designed for occasional deep discharge, have been very carefully designed and engineered for our telephone systems.⁽¹⁾ In anticipation of the need for batteries for load leveling, five major U.S. companies have developed detailed cost and design studies^(2,3,4,5,6) geared to the production of large lead-acid batteries. The lead time to full-scale production is estimated to be two to three years from the time of the decision to go ahead. New battery systems, described later, are also at the engineering stage. (A compendium of these activities and the level of effort in each has been published.⁽⁷⁾) The preferred systems will probably require 10 years to reach large-scale production.

Secondary batteries (that is, batteries used to store energy produced elsewhere) have no immediately discernible environmental impact in operation, but there are many safety factors that require special attention.⁽⁸⁾

Section 20.2: Technical Discussion

Batteries are familiar devices that can store electricity as chemical energy. In a primary battery, for example, a flashlight battery, electrical energy is derived from packaged chemicals in an irreversible discharge process. In a secondary battery, such as a car battery, the chemical reactions can be reversed after discharge by returning electrical energy to the cell. To be a useful storage device for DES applications, the secondary battery should be capable of being charged and discharged many times. (With rare exceptions, for example, military applications, primary batteries are small and may be disregarded in any analysis of DES.) This discussion is restricted to those battery systems that can meet, or be expected to meet, certain performance and cost goals. The numbers presented refer specifically to such systems and should not be compared to similar battery systems designed for other applications.

The general objectives for the system are as follows:

- low cost,
- long life (number of cycles and calendar life),
- high efficiency (ratio of Watt-hours delivered to Watt-hours required to charge),
- high energy density (measured as kWh/ft³ or kWh/ft² of floor space), and
- high power density (the capability to deliver the stored energy at the maximum demand rate).

The goals that are generally used⁽⁹⁾ are for a compact system, capable of more than 2000 cycles at a five-hour discharge rate (to 20% rated capacity) and 200 cycles/year at a cost of between \$20 and \$30/kWh of storage capacity.

The efficiency and cycle life are very much a function of the pattern of use, primarily rate of charge and discharge, depth of discharge, and the extent of routine overcharge. (This is true for all secondary batteries, regardless of application.) The definitions of energy and power densities

of a battery designed for energy storage require special comment. Conventionally, batteries are compared on a specific volume basis, but because of the large floor area involved in even a moderate size energy storage system, the footprint (kWh/ft^2) becomes important. One technical tradeoff is between the smaller cells (say, 5 kWh) that can be moved for maintenance purposes with a forklift truck, and can therefore be stacked in tiers, and the large cells that offer some economy of scale, but require an overhead crane to be moved and cannot be stacked. This factor explains the range of cell sizes, 5 kWh to 125 kWh for the lead-acid battery system in Table 20-1.

The battery systems under immediate consideration for energy storage are listed in Table 20-1. The engineering development work is directed at producing units with megawatt hours of storage capacity that will meet the requirements of the electric utilities in load leveling. For DES, this means a range from a typical substation capability to deliver 40 megawatts down to smaller units rated at hundreds of kilowatts.

The smallest installation compatible with present demands (such as a photovoltaic array) is approximately 60 kWh. For special circumstances, a 20-kWh battery might suffice. From Table 20-1, it is apparent that the lead-acid battery is the only system that can make a contribution in the immediate future. The zinc-chlorine cell, which also operates at ambient temperature,^{*} is a reasonable candidate for DES. Again, there is no depth of experience in the large-scale production or operation of this system. The sodium-sulfur^{**} cell depends on a conductive ceramic as the electrolyte, which limits the projected size of individual cells to less than 0.5 kWh. However, the degree of reliability in the manufacture of the ceramic electrolyte is such that large batteries can be expected to be built, and will be available in the mid 1980's. The lithium-iron sulfide

* A summary of the physical and performance characteristics of each of the cells listed in Table 20-1 is presented later in this chapter as Table 20-3.

** Development of the sodium antimony chloride cell which also uses a Beta-alumina electrolyte has recently been abandoned.

TABLE 20-1

SECONDARY BATTERIES FOR DISTRIBUTED ENERGY SYSTEMS

<u>System</u>	<u>Current Status</u>		<u>Near-Term Developments</u>	<u>MWh-Sized Unit in</u>
	<u>Cell Size (kWh)</u>	<u>Life Cycles</u>		
Lead-Acid	5-125	2500 ⁽¹⁾	Prototypes of full-size cells built in 1978	1980
Zinc-Chlorine	2 ⁽²⁾	>2000 ⁽¹⁾	50-kWh battery now on test	1981
Sodium-Sulfur	0.3	2000 ⁽³⁾	10-kWh module now on test	1984
Lithium-Iron Sulfide	0.15	600	14-kWh cell now on test	1985

-
- (1) Projections for state-of-the-art designs.
 (2) Modular building block of bipolar cells.
 (3) Based on tests of β -alumina electrolyte.

SOURCE: References 2, 3, 4, 5, 6, 7, and 8.

cell is being studied extensively.⁽⁹⁾ The primary problems are with materials of construction, but it is anticipated that these problems will be solved and that production of large batteries will be possible by the mid-1980's.⁽⁷⁾

Immediate opportunities are, therefore, limited to the lead-acid system. Five manufacturers have carried out design (and cost) studies^(2, 3, 4, 5, 6) on lead-acid batteries intended specifically for the large-scale storage of electrical energy. A description of each design is given in the references cited above; a comparison of the individual specifications has also been made.⁽⁸⁾ A summary is given in Table 20-2; the principal variation is in individual cell size and the influence this has on the footprint. The gravimetric energy density is low, but technically this is of minor importance from the standpoint of DES. However, since the bulk of the weight is due to the lead, the ultimate cost (discussed in the next section) is affected and is very sensitive to the price of lead.

The prime reason for developing new secondary batteries is to reduce the capital cost and to increase cycle life. A summary of the characteristics of the various candidates is presented in Table 20-3 and a discussion of their special problems follows.

The zinc-chlorine battery has an aqueous electrolyte which is recirculated through the cell at ambient temperatures. Chlorine generated during the charging process is carried by the electrolyte to a chiller, where it forms solid chlorine hydrate. The hydrate requires only slight refrigeration to provide convenient storage for the chlorine. For discharge, the hydrate is warmed to liberate chlorine. Principal problems are the control of electrolyte flow, achieving simplicity in the ancillary equipment, and the minimization of the parasitic pumping and refrigeration loads.

The sodium sulfur battery depends on a β -alumina ceramic electrolyte and operates at temperatures ranging from 400-700°F. The ceramic is made in tubular form; it is difficult to make and there is a limit to the size -- measured in tens of inches in height. This means that tens of thousands of tubes would be needed for

TABLE 20-2

LEAD/ACID BATTERY CELL SPECIFICATIONS (1)

<u>Specification</u>	<u>Manufacturers</u>				
	<u>C&D (2)</u>	<u>ESB (2)</u>	<u>Globe-Union</u>	<u>Gould</u>	<u>Westinghouse</u>
Capacity (kWh at 5-hr rate)	17.9	18.2	36.9	128.0	5.19
Gravimetric Energy Density (Wh/lb)	9.0	8.6	8.0	8.8	10.3
Footprint (kWh/ft ²)	5.2	5.5	2.4	6.2	4.5
Lead Weight (lb/Wh)	62.2	76.7	63.8	60.3	70.7

(1) For electric utility storage application.

(2) The C&D Battery Division is part of the ELTRA Company; ESB is a division of the International Nickel Company.

SOURCE: References 7, 8, and 10.

TABLE 20-3

CHARACTERISTICS OF BATTERIES FOR DES

	Operating Temperature (°F)	<u>Energy and Power Densities</u>			Efficiency (%)
		<u>Wh/kg</u>	<u>W/kg</u>	<u>kWh/ft³</u>	
Lead-Acid	Ambient	20	45	1.0	70
Zinc-Chlorine	Ambient	55	65	3.4	65
Sodium-Sulfur	660	88	100	4.3	70
Lithium-Iron Sulfide	800	88	66	2.8	75

SOURCE: References 7, 8, and 11.

a multi-MW capability, a factor that puts a severe strain on the reliability of a component already acknowledged to be difficult to manufacture.

The lithium-iron sulfide cells operate at very high temperatures -- 800°F -- and at these temperatures there are severe problems in corrosion of the cell container, breakdown of the separator between the plates, and breakdown of the insulators in the terminal feed-throughs.

It is anticipated that all the previously described problems, and some⁽¹²⁾ too detailed to mention here, will be solved. The incentives for their solution are derived to a large extent, from other potential applications, such as electric vehicles, but the cost savings for DES could be significant, as is discussed in the next section.

Section 20.3: Economics Discussion

As cited earlier, detailed cost analyses^(2,3,4,5,6) for lead-acid batteries have been carried out by five companies for current technology. Their findings are summarized in Table 20-4. Note that these costs were derived using 26¢/lb as the price of lead. Since approximately 30% of the cost of a lead-acid battery can be attributed to the lead content, the future price will be quite sensitive to any change in the price of lead (at 58¢/lb in 1979).

For the other systems, the only figures available are cost goals, derived from raw material costs and assumptions on manufacturing costs in large quantities. Both sets of figures are presented in Table 20-5. A comparison of the two sets immediately points to the basis for selection of other than the lead-acid system. The cost of advanced state-of-the-art lead-acid batteries may be reduced to approximately \$40/kWh⁽¹³⁾ in the early 1980's, and the newer systems would have to be significantly below this figure to warrant the investment in their engineering development. (It is for economic reasons, among others, that nickel-iron and nickel-zinc systems are excluded from energy storage applications, although they are under active consideration for electric vehicles.*)

* The weight savings of the nickel-iron and nickel-zinc systems over lead-acid are important for electric vehicle use, but are less important in load-leveling applications.

TABLE 20-4

ECONOMIC SPECIFICATIONS FOR LEAD-ACID BATTERIES DESIGNED FOR FIVE-HOUR DISCHARGE AT RATED POWER⁽¹⁾
(in 1977 dollars)

<u>Specification</u>	<u>C & D</u> ⁽²⁾	<u>ESB</u>	<u>Globe-Union</u>	<u>Gould</u>	<u>Westinghouse</u>
Cost (\$/kWh) ⁽³⁾	55	56	58	54 ⁽⁴⁾	49
Life (cycles @ 77°F)	2000	2000	2000	2000	1750 (95°F)
Capital Cost/Cycle (mill/kWh)	27	28	29	27	28
Efficiency (%) ⁽⁵⁾	73	76	72	70	68
Replacement Price (\$/kWh)	40	32	38	25	34
Maintenance Cost (mills/kWh)	0.28	0.18	NA	NA	NA

(1) For utility applications.

(2) Based upon 85% depth of discharge to achieve 2000 cycles instead of 95% depth of discharge to achieve 1250 cycles at a price of \$29/kWh.

(3) Assumes 26¢/lb lead.

(4) Installed cost.

(5) Includes inversion efficiency of 90%.

*NA = Not Available.

SOURCE: Reference 8.

TABLE 20-5

GUIDE TO COSTS FOR BATTERY ENERGY STORAGEFrom Cost and Design Studies in 1976⁽¹⁾

<u>Lead Acid Batteries (5-hour rate)</u>	<u>\$/kWh</u> (1977 \$)
C&D	55
ESB	56
Globe Union	58
Gould	54
Westinghouse	49

Cost Goals for 1985 in 1977 \$⁽²⁾Zinc-Chlorine

EDA	15-40
-----	-------

Sodium-Sulfur

Dcw	15-30
Ford Motor Co.	15-30
General Electric	15-30

Lithium-Iron Sulfide

ANL	20-30
General Motors	20

SOURCE: (1) From Reference 14.
 (2) From Reference 7.

The replacement costs, as listed in Table 20-4, could be as low as \$25/kWh because of the intrinsic value of the lead. The situation could be quite different with the newer systems. Since they are essentially based on inexpensive and relatively abundant materials, solutions to the technical problems should lead to economically viable storage systems.

The cost of storage batteries per unit power capacity, C (\$/kW), is given by the expression,

$$C = C_s T + C_p,$$

where C_s is the cost per unit energy storage capacity (\$/kWh),

T is the time (hrs) for which the battery can deliver rated power ($T = 5$ for a "five-hour battery"), and

C_p is the "balance of plant" costs which include ac-dc power conversion, building, installation and site costs.

C_p is typically about \$245/kW⁽¹⁵⁾ so that if $C_s = \$55/\text{kWh}$ (Table 20-4), $C = \$520/\text{kW}$ for a five-hour battery.

Using these costs, one can calculate the costs of energy delivered by a storage battery discharged 5 hours per cycle, 260 cycles per year, and charged with inexpensive base load power. The results are presented in Table 20-6.

For utility-owned battery installations, several credits may be applied toward the computation of the delivered energy cost. These include:

- transmission and distribution savings (batteries located close to load center),
- reduction in spinning reserve requirements (when utility is servicing daily peak demand) and power production costs, and
- replacement capacity (capital cost of gas turbines).

TABLE 20-6

COSTS OF DELIVERED ENERGY FROM A
BATTERY STORAGE SYSTEM

(all costs in 1977 dollars)

<u>Item</u>	
1. Capital Cost (\$/kW)	520.00
2. Fixed Charge Rate ⁽¹⁾	.2374
3. Annual Charge (no salvage) (\$/kW)	123.00
4. Salvage Credit ⁽²⁾ (\$/kW)	15.00
5. Total of Annual Fixed Charges (\$/kW)	108.00
6. Annual Hours of Operation ⁽³⁾	1300
7. Energy Cost due to Fixed Charges (\$/kWh)	.083 (line 5 ÷ line 6)
8. Maintenance ⁽⁴⁾ (\$/kWh)	.002
9. Range of Basic Charging Energy Costs (\$/kWh)	.006 (nuclear) .020 (coal)
10. Actual Charging Energy Required ⁽⁵⁾ (\$/kWh)	.008 (nuclear) .027 (coal)
11. Total Energy Cost (\$/kWh)	.083 + .002 + (.008 to .027)
12. Range of Delivered Energy Cost (\$/kWh)	.093 to .112

(1) Based on battery life of 5 years, 6% "cost of capital" because constant (\$1977) dollars are used throughout.

(2) Assumes batteries represent \$275/kW out of the \$520/kW, of which 30% is due to recoverable lead. Salvage value of \$83/kW taken at end of 5-year life and converted to annual credit of \$14.72, or \$15.

(3) Assumes operation 5 days per week, 5 hours per day.

(4) Estimate based on Table 20-4.

(5) Because the system efficiency is 75%, 4 kWh of charging energy are required for 3 kWh of output.

SOURCE: Arthur D. Little, Inc. calculation, based on data in text.

Details of their significance and impact as they apply to a particular utility can be obtained from the analysis carried out by Johnson et al.⁽¹³⁾ and updated by MITRE⁽¹⁵⁾ in 1978. They calculate total credits of up to \$405/kW toward installed costs of \$445/kW*. The resulting net cost of \$40/kW is very sensitive to the nature of the assumptions made in calculating the credits.

When battery storage is used in support of a remote primary generator, the cost and benefits of each system must be analyzed on an individual basis. For example, the option of battery storage in a photovoltaic system is discussed in Chapter 2.

Section 20.4: Limitations

From a technical viewpoint, secondary batteries can play a role in DES in the immediate future. However, the economic penalties of adding an energy storage system to a primary energy generator are very large. These penalties are tolerable in remote locations and can be offset to some extent when used in an existing power distribution system. New technology, in the form of the zinc-chlorine cell and the high-temperature cells, looks as if it might reduce costs by about a factor of 2. Although this is significant, the battery storage system remains an expensive component. This is particularly true when it is realized that batteries continuously degrade in capacity and efficiency during their lifetimes so that overdesign is needed initially.

Further limitations might be site-specific, for example, lack of floor space, climate, accessibility for required maintenance, and lack of skilled personnel.

Some account must also be taken of possible poor acceptance of the concept of a decentralized energy installation with the additional complexity of a large storage battery. Also, because of the demands for capital, the major battery manufacturers might limit their investments to meet the premium priority needs of the electric utilities and not provide production capabilities for a more wide-reaching market.

*Based on expected future costs of \$40/kWh as a result of large-scale manufacturing economies.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

REFERENCES

1. "Twelve Papers on the Development of Reserve Batteries for Bell System Use." Bell Technical Journal 49:1249, 1970.
2. Westinghouse Electric Corporation. Study of the Manufacturing Costs of State-of-the-Art Lead Acid Batteries for Peaking Power. Prepared under Contract No. E949-180-2114 for Energy Research and Development Administration, December 1977.
3. ESB Incorporated. Design and Cost Study for State-of-the-Art Lead Acid Load Leveling and Peaking Batteries. Prepared for Electric Power Research Institute, February 1977. EPRI Report No. EPRI EM-375.
4. Hellman, E.V. "Lead-Acid Battery Design for Electric Utility Load Leveling." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 113 ff.
5. Boden, D.P. "A New Lead-Acid Battery for Utility Peaking." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 127 ff.
6. Towle, W.L. "Lead-Acid Cell of High Performance for Utility Networks." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 145 ff.
7. Nelson, P.A. "Comparison of U.S. and European High Temperature Battery Program." Proceedings of the Symposium and Workshop on Advanced Battery Research and Design, Argonne, Illinois, March 22-24, 1976. NTIS Report No. ANL-76-8. pp. A99 ff.
8. Birk, J.R. "The Lead-Acid Battery for Electric Utilities: A Review and Analysis." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 163 ff.
9. Cairns, E.J., et al. "High Temperature Batteries." Proceedings of the Symposium and Workshop on Advanced Battery Research and Design, Argonne, Illinois, March 22-24, 1976. NTIS Report No. ANL-76-8. pp. A 81 ff.
10. Stolte, W.J. "An Engineering Study of a 20 MW Lead-Acid Battery Energy Storage Demonstration Plant." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 329 ff.

REFERENCES (continued)

11. Symons, P.C. Development of High-Efficiency Cost-Effective Zinc-Chlorine Batteries for Utility Peak-Shaving, 1976. Report prepared by Energy Development Associates for Electric Power Research Institute, March 1978. Interim Report No. EPRI-EM-711.
12. Murie, R.A. "Post Test Analysis of Lithium Iron Sulphide Compact Cells." Proceedings of the Twelfth Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 349 ff.
13. Johnson, A.C., et al. "Economic Assessment of the Utilization of Lead-Acid Batteries in Electric Utility Systems." Lead-Acid Batteries for Utility Application: Workshop II. March 1977. Electric Power Research Institute Special Report No. EPRI-EM-399-SR. pp. 4 ff.
14. Smith, J.C. "Summary Economic Comparisons." Lead-Acid Batteries for Utility Application: Workshop II, March 1977. Electric Power Research Institute Special Report No. EPRI EM-399-SR. pp. 349 ff.
15. Davis, F., et al. Lead-Acid Battery: An Evaluation of Commercialization Strategies. Report prepared under Contract No. EC-77-C-01-5025 by METREK Division of MITRE Corporation for U.S. Department of Energy, November 1977.

CHAPTER 21
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: HEAT TRANSPORT BY HEAT PIPES</p> <p>DESCRIPTION: Heat pipes transport high-flux heat energy from a source of heat to a point of application.</p> <p>POTENTIAL USER CLASSES: Industrial heat recovery unit users; coal gasifying plants; Stirling engine energy systems; solar systems.</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Heat pipes operating below 900°F are commercially available. High-temperature applications are in research stage.</p>																										
TECHNICAL	<p>UNIT POWER OUTPUT CAPACITY:</p> <p>UNIT ANNUAL ENERGY OUTPUT:</p> <p>AVERAGE EFFECTIVE CAPACITY FACTOR:</p> <p>RANGE OF CAPACITY FACTORS:</p> <p>EFFICIENCY (BTU OUT/BTU IN):</p> <p>PRIMARY FUEL(S): NA</p> <p>ALTERNATIVE FUEL(S): NA</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: NA</p> <p>CONNECTION TO CENTRAL UTILITY: NA</p> <p style="padding-left: 20px;">DESIRABLE FOR USER?</p> <p style="padding-left: 20px;">TECHNICALLY PRACTICAL?</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? NA</p> <p style="padding-left: 20px;">SYSTEM:</p>	<p>PRIMARY</p> <p>SECONDARY</p> <p>PRIMARY</p> <p>SECONDARY</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33.33%;">1977</th><th style="width: 33.33%;">1985</th><th style="width: 33.33%;">2000</th></tr> </thead> <tbody> <tr><td>(i)</td><td></td><td></td></tr> <tr><td>NA*</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> <tr><td>almost 100%⁽ⁱⁱ⁾</td><td></td><td></td></tr> </tbody> </table> <p>AMOUNT NEEDED PER UNIT OUTPUT: NA</p> <p>IS SYSTEM READILY CONVERTIBLE? NA</p>	1977	1985	2000	(i)			NA*			NA			NA			NA			NA			almost 100% ⁽ⁱⁱ⁾		
1977	1985	2000																									
(i)																											
NA*																											
NA																											
NA																											
NA																											
NA																											
almost 100% ⁽ⁱⁱ⁾																											
ECONOMIC	<p>TOTAL INSTALLED UNIT CAPITAL COST: (\$/10⁶ Btu/yr)</p> <p>AVERAGE UNIT O&M:</p> <p>CONSTRUCTION PERIOD:</p>		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33.33%;">1977</th><th style="width: 33.33%;">1985</th><th style="width: 33.33%;">2000</th></tr> </thead> <tbody> <tr><td>.26⁽ⁱⁱⁱ⁾</td><td>same</td><td>same</td></tr> <tr><td>No data^(iv)</td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td></tr> </tbody> </table>	1977	1985	2000	.26 ⁽ⁱⁱⁱ⁾	same	same	No data ^(iv)			NA														
1977	1985	2000																									
.26 ⁽ⁱⁱⁱ⁾	same	same																									
No data ^(iv)																											
NA																											
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Heat pipes operating below 900°F are available in large quantities commercially.</p> <p>GEOGRAPHIC LIMITATIONS: None</p> <p>ENVIRONMENTAL EFFECTS: The working fluid in a heat pipe may be Freon or liquid metals. In case of leakage due to mechanical damage, Freon may degrade the ozone layer. Liquid metals, when exposed to air, are quite flammable. This constitutes a safety hazard, which can be protected against.</p> <p>LEGAL, SOCIAL, OR INSTITUTIONAL BARRIERS: None</p>																										
COMMENTS	<p>(i) Heat-transfer rate through a typical 1-inch diameter x 9-ft long heat pipe is 2×10^4 Btu/hr.</p> <p>(ii) Heat pipes can transfer heat with negligible thermal loss when adequately insulated.</p> <p>(iii) Based on the cost of a 1-inch diameter x 9-ft long heat pipe with a heat-transfer rate of 20,625 Btu/hr, equivalent to \$.0023/Btu/hr. An alternative method of estimating costs, based on the surface area for external heat transfer, is described in Section 21.3 (B).</p> <p>(iv) Probably insignificant but no data are available because of limited experience.</p> <p>*NA = Not applicable.</p>																										

CHAPTER 21

HEAT TRANSPORT BY HEAT PIPES

Section 21.1: Introduction

A heat pipe is a device that transports heat energy from one point to another through a pipe. Heat flux through a heat pipe can be a thousand times more than that through a solid copper conductor of the same diameter, since the heat-transfer mechanism is the evaporation and condensation of a fluid with high latent heat. This very high effective thermal conductivity makes heat pipes very valuable tools in a variety of distributed energy system applications.

The heat pipe consists of a sealed pipe with a working fluid inside (Figure 21-1) contained under its own vapor pressure. When one end of the heat pipe is exposed to a higher temperature, fluid in contact with the heated wall absorbs heat and evaporates. The vapor then flows to the cooler end, where it rejects heat and condenses. The midsection of the pipe length is usually insulated. The condensed fluid returns to the evaporator section by gravity and/or by the capillary action of grooves, wicks, etc., along the pipe wall. The operation then repeats.

In addition to the advantage of very high effective thermal conductivity, heat pipes have the unique capability to function as thermal transformers. As such, heat can be supplied to the evaporator section at relatively low flux levels and rejected at the condenser at high flux levels (and vice versa). This characteristic permits the utilization of heat pipes for the thermal coupling of high heat-flux energy-conversion devices, such as Stirling engines, to thermionic converters with relatively low heat-flux flame-fired heat sources.

Other application areas for heat pipes have been solar collectors, hot water heaters, thermal control of spacecraft, cooling of electronic parts by non-metallic tubes, coal gasification, heat recovery from

Evaporation
(boiling)

Condensation

SOURCE: Reference 1.

FIGURE 21-1 HEAT PIPE CONSTRUCTION

exhaust gases, and cryosurgery.^(2,3,4,5,6,7) The most widely publicized application of heat pipes has been in the Alaska pipeline, where they are used to keep support columns of above-ground pipelines colder than the permafrost ground so that the problems of thawing foundations and consequent weakening of support structures are eliminated.⁽⁸⁾

Section 21.2: Technical Discussion

A. Heat Pipe Construction

Heat pipes have three basic components: (1) the sealed tube, (2) the working fluid inside the tube, and (3) the wick structure, which helps return the working fluid from the condenser section to the evaporator section.

Selection of materials for these three parts depends on the requirements of a particular application. The main factors are: (1) temperature of heat source, (2) temperature of heat sink, and (3) other operational requirements (exposure to flue gases, safety, heat-flux requirements, etc.).

Typical tube materials for lower-temperature applications are aluminum, copper, or steel. Special steel is used for temperatures in the vicinity of 1700°F. Ceramic tubes are used for temperatures above 2700°F.⁽⁹⁾ At the evaporator and condenser sections of the pipe, extended surfaces are often provided, as in conventional liquid-to-air heat exchangers. At operating temperatures, the tube material must be compatible with the working fluid and the wick material. The tube must also be able to withstand the vapor pressure of the working fluid and not be subjected to stress-corrosion effects.

Some commonly used working fluids and their ranges of temperatures are given in Figure 21-2 and Tables 21-1 and 21-2.^(1,10) Working fluids should have a high latent heat, since boiling-condensation is the mechanism by which heat is transferred. They should have a low viscosity and a high surface tension, so that the condensate will return rapidly

SOURCE: Reference 1.

FIGURE 21-2 TYPICAL TEMPERATURE RANGES FOR HEAT PIPE WORKING FLUIDS

TABLE 21-1

PROPERTIES OF MOST COMMONLY USED HEAT PIPE WORKING FLUIDS

FLUID	BOILING POINT	MELTING POINT	DENSITY		VISCOSITY		SURFACE TENSION	LATENT HEAT	SPECIFIC HEAT	HEAT OF FUSION	CRITICAL FLUX
	F (deg) C (deg)	F (deg) C (deg)	LIQUID	VAPOR	LIQUID	VAPOR					
			lb/cu ₃ ft g/cm ³	lb/cu ₃ ft g/cm ³	cps cs	cps cs	dynes/cm	Btu/lb cal/g	Btu/lb°F cal/g°C	Btu/lb cal/g	w/sq in w/cm ²
Freon 12 (C ₁ Cl ₂ F ₂)	- 21.6 - 29.8	-252 -158	92.6 1.48	0.395 0.00633	0.37 0.249	0.0127 2.01	16.6	71.04 39.47	0.21 0.21		138 21.5
Ethyl Chloride (CH ₃ CH ₂ Cl)	54 12.27	-218 -138.7	56.0 0.898	0.1872 0.0030	0.30 0.326	0.0093 3.1	20.39	163.6 90.55	0.36 0.36		203 31.5
Acetone (CH ₃ COCH ₃)	133 56.6	-139 - 95	48 0.77	0.135 0.0022	0.24 0.31	0.0085 3.88	17.4	224 124.5	0.55* 0.55*	42 23.4	218 33.8
Methanol (CH ₃ OH)	148.3 64.65	-144 - 97.8	49.8 0.796	0.0756 0.0012	0.34 0.43	0.0135 11.15	22.6	473 262.3	0.566 0.566	28.6 16.4	368 57
Hexafluoro- benzene (C ₆ F ₆)	176 80.2	39.2 3.8	100 1.62	0.402 0.0064			21.4	73 40.6	0.285 at 24°C 0.285	26.8 14.88	131 20.4
DC-200® - 65 CS	212 100	- 90 - 67.7	47.5 0.763	0.075* 0.001*	0.45 .65 at 25°C	0.01* 10.0*	15.9 at 25°C	95.8 52.4	0.504 0.504		74 11.5
Dowtherm-E®	352 177.78	0 - 18	70.8 1.127	0.269 0.0046	0.335 0.30	0.01093 2.38	37 at 25°C	119.1 66.3	0.411 0.411	38 21.1	192 30
Dowtherm-A®	495.8 257.7	53.6 12	53.28 0.854	0.2485 0.00398	0.27 0.316	0.0103 2.59	40 at 25°C	128 71.3	0.524 0.524	42.2 23.4	172 26.7
CP-9®	566.6 297	- 85 - 65	50* 0.81*	0.25* 0.004	0.25* 0.32	0.01* 2.5	41 at 20°C	120.5 67			162* 25
Water (H ₂ O)	212 100	32 0	60 0.9584	0.0373 0.0006	0.2838 0.299	0.0125 20.9	72 at 25°C	970 539.55	1.0 1.0	144 79.71	703 109
Ammonia (NH ₃)	- 28.1 - 33.34	-107.9 - 77.7	42.5 0.681	0.0552* 0.000738 at 0°C	0.25 0.367	0.0079	42.41	587.59 326.44	1.07 1.07	142.6 79.4	446 59.1

NOTES:

1. All values given at the Boiling point unless otherwise noted.
2. An asterisk indicates estimated or approximate values.

SOURCE: Reference 1.

TABLE 21-2
PROPERTIES OF LIQUID METAL WORKING FLUIDS

Metal	Boiling Point (°F) (°C) @760mm Hg	Melting Point (°F) (°C)	Density of Liquid (g/cc)	Viscosity of Liquid (Centipoise)	Surface Tension (dynes/cm)	Latent Heat of Vap. (cal/g)	Specific Heat (cal/g°C)	Heat of Fusion (cal/g)
Cesium	1301 705	83.0 28.5	1.84 @28°C	0.406 @140.5°C		146.0	0.060 @28.5°C	3.766
Lithium	2403 1317	354.0 179.0	0.474 @600°C	0.554 @208.1°C		4680.0	1.0 @1000°C	158
Potassium	1400 760	147.0 63.7	0.576 @700°C	0.136 @700°C	86 @150°C	496.0	0.188 @800°C	14.6
Mercury	675 357	-38.0 -38.9	12.88 @300°C	1.01 @200°C	394 @354°C	69.7	0.033 @450°C	2.8
Sodium	1616 880	208.0 97.8	0.780 @700°C	0.182 @700°C	401 @327°C	1005.0	0.303 @800°C	27.05

SOURCE: Reference 10.

to the evaporation section by the capillary effect of the wick structure. In addition, the fluids must be chemically compatible with the tube and the wick materials. Finally, the fluid must be thermally stable at the operating temperature of the heat pipe.

Water is often considered as the working fluid at temperatures in the range of 150°F to 450°F.⁽¹¹⁾ At lower temperatures the low vapor pressure of water leads to low heat-flux levels, while at higher temperatures the vapor pressure of water is excessive (for example, 680 psia at 500°F). For temperatures in the 400-750°F range, various organic fluids, such as Dowtherm[®], can be utilized. The upper temperature limit for heat pipes with organic fluids results from the fact that these fluids tend to decompose at higher temperature levels. Various liquid metals such as sodium, potassium, and lithium can be used as the working fluids in heat pipe systems at higher temperature levels, i.e., in excess of 1000°F.

The temperature of the working fluid will be between that of the source and that of the sink, and is fairly uniform throughout the pipe. The "soak" temperature of a heat pipe is the maximum temperature to which it can be exposed on a continuous basis without damage to tube or fluid, when there is no heat removal at the condenser section. Usually the heat pipe design is chosen so that the source temperature is less than the "soak" temperature. However, there is often a significant temperature difference between the heat source (such as hot gas) and the wall of the heat pipe because of relatively low air-to-surface heat-transfer coefficients. Under these conditions, heat pipes can be used in heat sources above their "soak" temperatures if proper controls are used to remove the heat source should a malfunction result in an excessive temperature condition.

A wide variety of wick configurations is available, including stainless-steel wire mesh, sintered metal, and grooves of various types in the tube wall (Figure 21-3). The primary requirement is that the wick return the

SOURCE: Reference 1.

FIGURE 21-3 TYPICAL HEAT PIPE WICK STRUCTURES

condensate rapidly to the evaporator. Considerations in the selection of the wick type are compatibility with other materials, cost, and the ability to prevent entrainment of the condensate by the vapor stream moving in the opposite direction. Wicking capabilities have already been analyzed⁽¹²⁾ for various structures. This capability can be augmented further by wire cloth covers over the grooves.

Heat flux through a heat pipe depends upon the properties of the working fluid, e.g., viscosity, density, latent heat of evaporation, and pipe characteristics such as inclination, diameter, and length, and the thermal resistance of the interface between the wick structure and heat pipe envelope. Heat flux along the heat pipe varies inversely with the effective transport length of the heat pipe.⁽¹²⁾ A 40-ft long, 1-inch diameter heat pipe with water as the working fluid can have a heat flux per unit cross-sectional area as high as 5500 Btu/hr-ft²°F compared to 5.5 Btu/hr-ft²°F for a 40-ft long copper rod.⁽¹⁾ Such high heat-flux rates are quite common in many heat pipe applications. For example, in the Alaska pipeline support structure, one 2-inch diameter, 40-ft long heat pipe transfers heat at a rate of 60,000 Btu/hr with only a few degrees temperature difference between the ends.⁽⁸⁾

B. Advanced Developments

To extend the operating range of heat pipes, DOE is currently sponsoring a program at the Los Alamos Scientific Laboratory to develop a high-temperature heat pipe.⁽⁹⁾ The objective is to handle temperatures in excess of 2000°F for application in advanced high-temperature processes such as coal gasification. The design to be evaluated uses a ceramic tube lined on the inside with a thin coat of metal. The working fluid will be a liquid metal. Sodium and lithium are two candidates for this purpose.

C. Applications

Heat pipes can be used in various distributed energy systems, such as the following:

1. Solar Collector

Heat pipes have been considered for a variety of applications in solar collector systems where their operational simplicity and low temperature-drop heat-transfer characteristics can be used to advantage. In one such system, shown in Figure 21-4, the heat pipes are used to transfer heat from parabolic solar collectors to the steam generators.^(11,13) Experiments have already been performed⁽¹¹⁾ on such applications. Each heat pipe is made of 1-inch diameter, 17-ft long stainless-steel tube; the evaporator section is about 13.5 ft long and the condenser section is 2.0 ft long. The wick structure is made of 100-mesh, stainless-steel screen. Water is found to be a good working medium in this case. Heat pipes are also being considered to transfer heat from a flat-plate solar collector to the circulating fluid in a solar heating system.⁽¹⁴⁾

2. Stirling Engine Thermal Coupling

Stirling engines (discussed in Chapter 14) are externally heated engines in which a gas (usually pressurized hydrogen or helium) is used as a working medium. For high efficiency, the heater head temperature of the engine is required to be quite high, typically 1200°-1500°F. They can, in principle, use any external heat source, e.g., coal-fired furnace, solar concentrators, combustion of lithium with sulfur hexafluoride,⁽¹⁵⁾ heat accumulators,⁽¹⁶⁾ etc. Heat pipes can be used to connect these or any non-conventional heat source to the Stirling engine. The heat pipe has particular advantages for such applications since it can receive heat from the source at low intensity and deliver it at high intensity to the engine.

Figure 21-5 shows a schematic of one such application in which a heat pipe connects the Stirling engine to a fluidized-bed coal combustor acting as a heat source.⁽¹³⁾ Maximum bed temperature is 1750°F. Material for the heat pipe is stainless steel and the working fluid is sodium.

3. Coal Gasifier

In another high-temperature application, heat pipes can be utilized in indirect coal gasifiers, as shown in Figure 21-6, to obtain high-heat recovery efficiency along with other benefits.⁽⁶⁾ The heat

FIGURE 21-4 HEAT PIPE IN PARABOLIC SOLAR COLLECTOR TRANSPORTS HEAT TO STEAM GENERATOR

SOURCE: Reference 15.

FIGURE 21-5 A HEAT PIPE IS USED TO CONNECT A STIRLING ENGINE TO A FLUIDIZED-BED COAL COMBUSTOR

SOURCE: Reference 6.

FIGURE 21-6 HEAT PIPES CONNECT CENTRAL COMBUSTION REGION TO CONCENTRIC HIGH-PRESSURE COAL-GASIFICATION REGION IN INDIRECT COAL GASIFIER

pipes are shown with a slight tilt so that gravity can assist the return of condensed working fluid from the reaction vessel to the combustion vessel. The most suitable working fluid for an operating temperature of 2000°F is sodium. Ceramic tube is usually considered in the heat pipe for such high-temperature applications.

4. Heat-Recovery

Use of heat pipes in heat-recovery units has been commercialized in recent years and now represents the largest commercial application of heat pipes. Figure 21-7 shows how the heat pipes are grouped together to make a thermal recovery unit. For waste-heat recovery units, metal tubes are usually used, and water and organic fluids are common working fluids up to 750°F. The bulk of these applications involves preheating make-up air for ovens and dryers, for example, in textile ovens and automotive paint-drying ovens.

5. Residential and Commercial

Energy-saving heat pipe applications for appliances such as water heaters have been proposed.⁽¹⁷⁾ Other gas-fired appliances where heat pipes can be effectively used to obtain uniform temperature, fast response to temperature changes, compactness, and operating efficiency are griddles and deep fryers.

Section 21.3: Limitations

A. Equipment Availability

Six firms in the United States manufacture heat pipe units, primarily for waste-heat applications. These firms, indicated in Table 21-3, are: Q-Dot, Isothermics, Hughes, Dynatherm, Gamewell, and Heat Pipe of America Corporation.

The types of fins used, the standard number, and the method of attachment vary from manufacturer to manufacturer. All manufacturers use freon or water for working fluids in the lower temperature ranges. At higher temperatures, most use "proprietary" fluids. These are probably organic heat-transfer fluids similar to Dowtherm-A[®] (Table 21-1).

SOURCE: Reference 18.

FIGURE 21-7 TYPICAL HEAT PIPE HEAT-RECOVERY UNIT

CHARACTERISTICS OF U.S. HEAT PIPE HEAT EXCHANGERS

MANUFACTURER	TEMPERATURE LIMIT (°F)	TYPE OF TUBE USED	FIN TYPE	WORKING FLUID	WICKS	COMMENTS
Q-Dot	525	1" diameter aluminum stan- dard, copper or steel available	Continuous flat plate on all models; mechanical contact all temperatures	Freons, water, and proprietary fluid	Circumferential grooves	Process and HVAC
	900	1" diameter steel				
		Protective coatings available				
Isothermics	450	1" diameter aluminum	Continuous flat plate for HVAC only; spiral integral fins (ISOFIN) for commercial applications	Freon 113 Water Dowtherm-A®	Circumferential grooves or wire mesh	Process and HVAC
	800	1" diameter copper, steel				
	up to 1500 special	1" diameter welded steel				
		special coatings available				
Hughes, Ther- mal Products Division	600	1" diameter aluminum	All fins continuous flat plate; for medium temperatures, mechanical contact obtained by expanding tube; for high temperatures, contact insured by metallurgical bond	Water and proprietary fluid	Circumferential grooves inside tube	Process and HVAC
	900	1" diameter copper or steel				
		special coatings available				
Dynatherm	300	1" diameter aluminum standard, copper or steel available	All fins spiral type: for low temperature use, aluminum held in place by tension; higher temperatures use copper or stainless brazed on to insure good thermal contact	Freon	Grooves	5°-10° tilt angle required; built in 2 row modules for easy cleaning
	700	1" diameter copper or steel		Water	Stainless mesh	
Gamewell	550	5/8" diameter copper	Continuous flat plate, aluminum, mechanical contact	Freons 12 and 22 and water	Circumferential grooves in tube wall	Process and HVAC: installed horizontally but can switch from heating to cooling incoming air without tilting
	900	5/8" diameter steel	Steel fins metallurgically bonded	Proprietary fluid		
		special coatings available				
Heat Pipe of America Corporation	500	1/2" diameter copper	Aluminum fins	Freons and water	Note required as long as angle from horizontal greater than 5 degrees	HVAC only

SOURCE: Compiled by Arthur D. Little, Inc. from information provided by the listed manufacturers.

The temperature ranges quoted by various manufacturers in Table 21-3 vary greatly. The temperatures above 700°F are the maximum exhaust stream temperature, assuming that a suitable system of safeguards has been included to prevent the heat pipe surfaces from reaching a temperature greater than 700°F if removal of heat from the cooler end should be reduced.

B. Costs

It is often difficult to give precise cost estimates or predictions for most pipes since they are normally manufactured for highly specific purposes and may be integral with other parts of the equipment. Furthermore, for most applications, except in heat-recovery heat exchangers, they are still in the experimental stage. The following example may, however, give an indication of costs. One manufacturer, Q-Dot, produces heat exchanger units consisting of sixty-four 9-ft aluminum heat pipes, 1 inch in diameter. The cost is \$47.50 per pipe, and the design heat-transfer rate is 20,625 Btu/hr (per heat pipe)⁽¹⁷⁾ equivalent to about \$.0023/Btu/hr ($\$.26/10^6$ Btu/yr). More commonly, costs are estimated in somewhat different terms. Most heat pipes are provided with a finned external surface for better overall fluid-to-gas heat exchange. The heat transfer ability of this surface must match that of the heat pipe so that this area is a measure of the heat pipe's performance. Following the practice common in the heat exchanger industry, we estimate the costs of heat pipe recovery units with external heat transfer surfaces are about \$.90/ft² of heat transfer surface.⁽¹⁹⁾ This cost is comparable to that of more conventional heat exchangers, such as plate-type recuperators. Heat pipe recovery units have the advantage of being easier to clean and more compact than plate-type units.

C. Environmental and Safety Considerations

The primary environmental and safety considerations associated with heat pipes are those connected with the working fluids in the event that the fluid leaks out of the pipe because of faulty construction or

an accident. For example, several of the Freon-type working fluids used in medium-temperature heat pipes are among those suspected of causing degradation of the ozone layer. Also, direct contact of several of these organic fluids with a flame can result in the formation of harmful phosgene-type compounds. The liquid metals which might be used in high-temperature heat pipes are often quite flammable when exposed to air or moisture and can, therefore, constitute a significant safety hazard.

The above environmental and safety issues are somewhat mitigated by the fact that the liquid inventory present in a heat pipe system is quite small since the principal heat-transfer mode involves evaporation and condensation.

D. Failure Modes and Reliability

The effective operation of heat pipes requires that the liquid in the pipe be sealed in a vacuum so that there are no significant amounts of non-condensable gases present. If non-condensable gases are present, they will tend to be swept down to the cold end of the pipe, thereby reducing the area available for condensation. This effect can make the heat pipe totally inoperable. Non-condensable gases can result from leakage of air into the pipe because of faulty construction, or from chemical degradation of the working fluid following operation at excessive temperatures.

Experience with commercial heat pipe heat-recovery equipment appears to indicate, however, that heat pipe failures, such as those discussed above, are not a major problem when the equipment is used correctly. Consequently, the guarantees offered on such equipment are consistent with those offered on more conventional heat exchanger packages,⁽¹⁸⁾ which is indicative of commercial maturity.

REFERENCES

1. Basiulis, A., et al. "Designers' Guide to Heat Pipes." Design News 29(6): 159, March 1974.
2. The Aerospace Corporation. Technical Summary of Distributed Solar Power Collector Concepts. Prepared for Energy Research and Development Administration under Contract No. E(04-3)1101. El Segundo, California, undated. Aerospace Report No. ATR-76(7523-07)-1(II).
3. Asselman, G.A.A. "Fluidized Bed Coal Combustion as a Heat Source for Stirling Engines." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. Paper No. 729132.
4. Aronson, R.B. "Heat Pipe: Hot New Way to Save Energy." Machine Design 48(6): 52, 1976.
5. Midwest Research Institute. Heat Pipes. Report prepared for National Aeronautics and Space Administration, 1975. NASA Report No. NASA-CR-2508.
6. Ranken, W.A. "The Potential of the Heat Pipe in Coal Gasification Processes." 11th Intersociety Energy Conversion Engineering Conference, State Line, Nevada, September 12-17, 1976. pp. 876 ff.
7. Bienert, W.B., et al. "Application of Heat Pipes to Solar Collectors." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 1533 ff.
8. Waters, E.D., et al. "The Application of Heat Pipes to the Trans-Alaska Pipeline." 10th Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 1496 ff.
9. Ranken, W.A. Ceramic Heat Pipe Heat Exchangers. Report prepared by Los Alamos Scientific Laboratory for Energy Research and Development Administration, October 1976. NTIS Report No. LA-6514-MS.
10. Rohsenow, W.M., et al. Handbook of Heat Transfer. New York: McGraw-Hill, 1972. pp. 2 ff.
11. The Aerospace Corporation. Highlights of the Solar Total Energy Systems, Distributed Collector Systems, and Research and Development Projects Semiannual Review, Atlanta, Georgia, January 26-27, 1976. Sponsored by the Energy Research and Development Administration under Contract No. E(04-3)-1101. El Segundo, California, March 26, 1976. Aerospace Report No. ATR-76(7523-11)-5.
12. Yip, F.C. "Design Parameter for Assessing Wicking Capabilities of Heat Pipes." Journal of Spacecraft 13(4):237, 1976.
13. Uhlemann, H., et al. "The Combination of a Stirling Engine in a Remotely Placed Heat Source." 9th Intersociety Energy Conversion Engineering Conference, San Francisco, California, August 26-30, 1974. pp. 620 ff.

REFERENCES (continued)

14. Schroeder, J. "Thermal Energy Storage Using Fluorides of Alkali and Alkaline Earth Metals." Proceedings of the Symposium on Energy Storage, 148th Meeting of The Electrochemical Society, Dallas, Texas, October 5-9, 1975. Princeton, New Jersey: The Electrochemical Society, Inc., 1976. pp. 206 ff.
15. Jet Propulsion Laboratory, California Institute of Technology. A Preliminary Technical and Economic Assessment of Solar Power Plants Using Line Concentrators. Pasadena, California, July 1978.
16. Bienert, W.B., et al. Heat Pipes Applied to Flat-Plate Solar Collectors. Cambridge, Massachusetts: Dynatherm Corporation, 1976.
17. Lazaros, J.S. Energy Saving Heat Pipe Applications for Residential and Commercial Appliances. Waltham, Massachusetts: Thermo Electron Corporation, 1974.
18. Q-Dot Corporation, Dallas, Texas. Product literature. 1978.
19. Arthur D. Little, Inc., Cambridge, Massachusetts. Data based on personal communications with selected manufacturers. January 1978.

CHAPTER 22
TECHNOLOGY SUMMARY SHEET

GENERAL	<p>TECHNOLOGY TITLE: INDUSTRIAL COGENERATION</p> <p>DESCRIPTION: The output steam from a steam turbine is used to meet process heat requirements and to generate electricity.</p> <p>POTENTIAL USER CLASSES: Industrial</p> <p>STATUS OF TECHNOLOGY DEVELOPMENT: Mature</p>																																
TECHNICAL	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 10%;">2000</th></tr> </thead> <tbody> <tr> <td>UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY</td><td>0.5-400</td><td>same</td><td>same</td></tr> <tr> <td>(10⁶ Btu/hr) SECONDARY⁽¹⁾</td><td>10.0-8.0x10³</td><td>same</td><td>same</td></tr> <tr> <td>UNIT ANNUAL ENERGY OUTPUT: (10⁶ kWh) PRIMARY</td><td>3.5-2.8x10³</td><td>same</td><td>same</td></tr> <tr> <td>(10¹⁰ Btu) SECONDARY</td><td>7.0-5.6x10³</td><td>same</td><td>same</td></tr> <tr> <td>AVERAGE EFFECTIVE CAPACITY FACTOR:</td><td>.8</td><td>same</td><td>same</td></tr> <tr> <td>RANGE OF CAPACITY FACTORS:</td><td>.7-0.9</td><td></td><td></td></tr> <tr> <td>EFFICIENCY (BTU OUT/BTU IN):</td><td>.75</td><td>same</td><td>same</td></tr> </tbody> </table> <p>PRIMARY FUEL(S): Coal, manufacturing residue</p> <p>ALTERNATIVE FUEL(S): Oil, gas</p> <p>AMOUNT NEEDED PER UNIT OUTPUT: 4600 Btu/kWh, taking credit for process steam</p> <p>IS SYSTEM READILY CONVERTIBLE? Yes, to alternatives, but not from oil or gas to coal and residue</p> <p>EXTENT AND NATURE OF OUTPUT FLUCTUATIONS: Steady base-load operation preferred</p> <p>CONNECTION TO CENTRAL UTILITY:</p> <p>DESIRABLE FOR USER? Yes, in many cases</p> <p>TECHNICALLY PRACTICAL? Yes</p> <p>CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Not needed</p> <p>SYSTEM:</p>		1977	1985	2000	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	0.5-400	same	same	(10 ⁶ Btu/hr) SECONDARY ⁽¹⁾	10.0-8.0x10 ³	same	same	UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ kWh) PRIMARY	3.5-2.8x10 ³	same	same	(10 ¹⁰ Btu) SECONDARY	7.0-5.6x10 ³	same	same	AVERAGE EFFECTIVE CAPACITY FACTOR:	.8	same	same	RANGE OF CAPACITY FACTORS:	.7-0.9			EFFICIENCY (BTU OUT/BTU IN):	.75	same	same
	1977	1985	2000																														
UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY	0.5-400	same	same																														
(10 ⁶ Btu/hr) SECONDARY ⁽¹⁾	10.0-8.0x10 ³	same	same																														
UNIT ANNUAL ENERGY OUTPUT: (10 ⁶ kWh) PRIMARY	3.5-2.8x10 ³	same	same																														
(10 ¹⁰ Btu) SECONDARY	7.0-5.6x10 ³	same	same																														
AVERAGE EFFECTIVE CAPACITY FACTOR:	.8	same	same																														
RANGE OF CAPACITY FACTORS:	.7-0.9																																
EFFICIENCY (BTU OUT/BTU IN):	.75	same	same																														
ECONOMIC	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;"></th><th style="width: 15%;">1977</th><th style="width: 15%;">1985</th><th style="width: 10%;">2000</th></tr> </thead> <tbody> <tr> <td>TOTAL INSTALLED UNIT CAPITAL COST: ⁽¹¹⁾ (\$/kW)</td><td>970-1600</td><td>same</td><td>same</td></tr> <tr> <td>AVERAGE UNIT O&M: (\$/kWh, excluding fuel)</td><td>.003</td><td>same</td><td>same</td></tr> <tr> <td>CONSTRUCTION PERIOD:</td><td>2 years</td><td>same</td><td>same</td></tr> </tbody> </table>		1977	1985	2000	TOTAL INSTALLED UNIT CAPITAL COST: ⁽¹¹⁾ (\$/kW)	970-1600	same	same	AVERAGE UNIT O&M: (\$/kWh, excluding fuel)	.003	same	same	CONSTRUCTION PERIOD:	2 years	same	same																
	1977	1985	2000																														
TOTAL INSTALLED UNIT CAPITAL COST: ⁽¹¹⁾ (\$/kW)	970-1600	same	same																														
AVERAGE UNIT O&M: (\$/kWh, excluding fuel)	.003	same	same																														
CONSTRUCTION PERIOD:	2 years	same	same																														
LIMITING FACTORS	<p>EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Adequate U.S. manufacturing</p> <p>GEOGRAPHIC LIMITATIONS: Coal is more expensive in certain regions due to transportation distance.</p> <p>ENVIRONMENTAL EFFECTS: More efficient fuel use reduces overall stack emissions; although shifting location from utility plant to industrial plant may pose siting problems. Use of steam for process heat reduces or eliminates condenser water use.</p> <p>LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Utility purchase of excess power may involve institutional and regulatory complications.</p>																																
COMMENTS	<p>(1) Process steam at 150 psig.</p> <p>(11) See Section 22.2.4 and Reference 1. These total installed costs are for typical 100,000 lb/hr to 500,000 lb/hr (6-MW to 30-MW) industrial steam turbine cogeneration plants; data for a much wider range are not available.</p>																																

CHAPTER 22
INDUSTRIAL COGENERATION

Section 22.1: Introduction

A heat engine is a device that converts thermal energy at a high temperature to useful work, e.g., driving machinery, and rejects a smaller amount of thermal energy at a lower temperature. According to the principle of conservation of energy, the thermal energy provided by the fuel equals the sum of the work performed and the heat rejected provided all these quantities are expressed in the same units. The Second Law of Thermodynamics postulates that in an "ideal" engine the ratio of the heat input to the heat rejected is the ratio of the absolute temperature* at which the heat is absorbed, T_u , to the lower absolute temperature, T_L , at which heat is rejected. It follows that the ratio of the work performed to the heat input is equal to $(T_u - T_L)/T_u$. This "ideal" measure of performance is the Carnot efficiency, ϵ_c , and can be used to predict the maximum work output that can be obtained, in principle, from any heat engine. Two aspects are important: (a) heat is always rejected in any real engine so that the energy absorbed from the fuel is never completely converted to useful work, and (b) the actual work output of a real engine is always less than that predicted by ϵ_c because of heat losses, friction, non-ideal thermodynamic behavior of the thermal fluid, and unavoidable temperature differences in heat exchangers. For example, a steam engine with an input temperature of 1000°F which rejects heat to ambient (80°F) has an ideal efficiency of 63%, corresponding to a heat rate of 5400 Btu/kWh, whereas the most efficient coal fired steam turbine generators have an efficiency of approximately 40%, i.e., a heat rate of 8500 Btu/kWh. Figure 22-1 illustrates the work output versus heat rejected from an ideal heat engine with input temperature of 900°F as it operates to different lower (i.e., heat rejection) temperatures, T_L .

*The absolute temperature, expressed in °R, equals (°F + 460).

FIGURE 22-1 WORK OUTPUT AND HEAT REJECTED FROM AN IDEAL HEAT ENGINE WITH AN INPUT OF 10^6 BTU AT A TEMPERATURE, T_U , OF 900°F VS. HEAT REJECTION TEMPERATURES, T_L , BETWEEN 100°F AND 600°F

When heat rejection occurs at or close to ambient temperatures the temperature of the "waste" heat is so low that it is of little use. If, however, the machine is modified so that the exhaust heat is delivered at, for example, 150°F, the heat can be used for space heating; or if it is made available at still higher temperatures, for example, 300-400°F (50 psig^{*} to 230 psig when the working fluid is saturated steam) the heat could be used for industrial processes (process heat).

The simultaneous production of work (usually converted into electricity) and usable (process) heat from a heat engine is "cogeneration." It is a technique widely used in industry to make available, from the same fuel source, power and usable heat at the cost of a reduction in the real efficiency of power generation but providing, overall, more efficient use of the thermal energy input. (From Figure 22-1 it is clear that, as the extraction or delivery temperature, i.e., T_L , rises above ambient, less of the fuel's energy is converted into work and more becomes available as process heat.) To put this statement in perspective, consider a heat engine operating between $T_u = 900^\circ\text{F}$ and either $T_L = 100^\circ\text{F}$ or $T_L = 365^\circ\text{F}$ (150 psig). The results,** for a postulated electricity output of 1 kWh (3413 Btu), are presented in Table 22-1.

Several different power generation technologies are available and have been used in industrial cogeneration; other more advanced technologies have been proposed for use in the future. The systems in use today are steam turbine, combustion*** turbine and diesel-powered electricity generation. The steam turbine cycle will be examined in detail in Section 22.2.1. Combustion turbine and diesel generation systems are discussed in Chapters 12 and 13, respectively, so that their description here will be limited to those features of particular importance in cogeneration. In Section 22.2.3 we shall present a comparison of those features

* psig = lbs/in^2 (gauge) or pressure above atmospheric pressure, i.e., approximately 15 lbs/in^2 less than the absolute pressure (psia). A fixed relationship between steam temperature and pressure exists only for saturated non-superheated steam. This situation may be assumed for process steam; both parameters are needed to define the input steam conditions.

** The details of the analysis will be given in Section 22.2.

*** Commonly known as "gas" turbines.

TABLE 22-1
THERMAL ANALYSIS OF IDEAL AND REAL HEAT ENGINES⁽¹⁾

Case A - Ideal - $T_L = 100^\circ\text{F}$

Fuel input:	5,802 Btu
Rejected heat:	2,389 Btu
Heat rate:	5,802 Btu/kWh
Fuel usage:	$3,413/5,802 = 59\%$

Case B - Real (est.) - $T_L = 100^\circ\text{F}$

Fuel input:	9,641 Btu
Rejected heat:	6,228 Btu
Heat rate:	9,641 Btu/kWh
Fuel usage:	$3,413/9,641 = 35\%$

Case C - Real (est.) - $T_L = 365^\circ\text{F}$

(1) <u>Heat wasted</u>	Fuel input:	31,319 Btu
	Recovered process heat:	0
	Heat loss:	27,906 Btu
	Heat rate:	31,319 Btu/kWh
	Fuel usage:	$3,413/31,319 = 11\%$
(11) <u>Heat recovered</u> <u>and used</u> <u>(cogeneration)</u>	Fuel input:	31,319 Btu
	Recovered process heat:	20,076 Btu (64% of input)
	Heat loss:	7,830 Btu (25% of input)
	Fuel usage:	$\frac{(3,413 + 20,076)}{31,319} = 75\%$
	Incremental input heat (needed to generate electricity): ⁽²⁾	4,740 Btu
	Incremental heat rate:	4,740 Btu/kWh (72% efficiency)

- (1) This analysis is based on delivering 1 kWh (3,413 Btu) of work from an input at 900°F and with exhaust temperatures of 100°F and 365°F (with and without heat recovery). The "real" cases are representative of a typical modern steam turbine cogenerator. See Section 22.2 for details.
- (2) That is to say, if the steam turbine could be bypassed in a lossless manner, then only 26,579 Btu of input heat would be needed to provide 20,076 Btu of process heat ($26,579 = 31,319 - 4,740$).

SOURCE: Arthur D. Little, Inc. calculations.

that play a role in their selection for industrial cogeneration.

Advanced technologies proposed for use in cogeneration in the future are Stirling cycle, and organic Rankine cycle engines and fuel cell systems. None of these is presently in commercial use for power generation; since they have been discussed extensively in Chapters 14, 15 and 16, their reviews in Section 22.2.5 will be brief.

Cogeneration systems fall into two general categories - "topping" and "bottoming" cycles. If process heat is required for industrial use at temperatures between ambient and, for example, 400°F, it might be economically attractive to construct a boiler capable of delivering steam at 900°F and to use the energy available between 900°F and 400°F for electricity generation. This is a steam "topping" cycle. If, however, process heat is required at still higher temperatures, then it might be worthwhile to deliver the process heat directly from the boiler at an appropriate selected temperature. After use, the process heat could be recovered at some still useful temperature, e.g., 300°F, for electricity generation in a "bottoming" cycle provided, for example, by an organic Rankine cycle engine.

The balance of this chapter consists of the following: Section 22.2 -- a review of cogeneration technologies; Section 22.3 -- a discussion of the factors affecting the use of industrial cogeneration; and Section 22.4 -- a review of future prospects for cogeneration.

Section 22.2: Technical Discussion

Introduction

The practical cogeneration of electricity and heat places fairly stringent requirements on the systems used: they must be mechanically reliable and maintainable, reasonably cost-effective, environmentally acceptable, available in a size appropriate to the job at hand, and give promise of long-term fuel availability. Traditionally, a number of configurations have survived the trade-offs between these requirements; however,

changing conditions may permit new technologies to gain acceptance in the future.

The application of cogeneration is discussed in detail in Section 22.4. Here we summarize to explain our choice for sample calculations.

Potential applications of cogeneration range from small units supplying a single building complex such as a shopping center or business park with electricity and space heat to large centralized electric power stations which also supply steam for district heating and industrial process heat. Potential intermediate size applications of several to tens of megawatts can be found in larger industrial plants.

At present, cogeneration finds its widest application in six industries (food, textiles, pulp and paper, chemicals, petroleum refining and steel). The technical, economic and institutional factors which induce these industries to cogeneration also appear to indicate that their potential for further technically feasible cogeneration exceeds that of all other industries combined.* For example, the pulp and paper industry provides a nearly ideal basis for cogeneration because plant sizes are large enough to support economical units utilizing proven technology; the need for electricity and process steam is well balanced; organic waste for fuel supplementation is available; and siting is often sufficiently remote that utility-supplied power is more expensive and less reliable than locally cogenerated electricity.

Because cogeneration in the intermediate multi-megawatt range typical of these six industries is most likely to contribute to the nation's energy pool, the example case used below for comparison of alternative technologies is sized to their needs. More specifically, we consider a process steam plant typical of that found in the pulp and paper industry⁽¹⁾ which has been modified for cogeneration. Table 22-2 lists the major parameters which define this specimen plant.

* See Table 22-8 for data.

TABLE 22-2

PARAMETERS DEFINING THE "TYPICAL" STEAM COGENERATION
PLANT USED IN THIS CHAPTER

<u>Size:</u>	500,000 pounds of steam per hour (Electricity output depends on alternatives considered.)
<u>Cycle:</u>	Topping
<u>Generator Inlet Conditions:</u>	1,250 psig, 900°F
<u>Generator Exhaust Conditions:</u>	150 psig, 350°F (saturated)
<u>Process Steam Input Conditions:</u>	150 psig, 350°F (saturated)
<u>Recycled Boiler Water Conditions:</u>	75% recycled at 180°F 25% makeup at 70°F

- Notes:
- Parameters dependent on system choice are given in the text or in Table 22-3.
 - Of the total number of new boilers installed by the pulp and paper industry in the period 1965-1975, 20% operated at 850 psig or greater pressure. These represent 44% of the steam capacity installed during that period with mean unit steam generation (at 80% capacity factor) of 460,000 lbs/hour. Boilers in this pressure range represented 31% of total installed steam capacity in 1975 and more than half of total cogeneration capacity.(1) Thus the chosen system is indeed typical of new capacity.
 - Because the specific heat of superheated steam is so much smaller than the latent heat, process steam will nearly always be saturated. Similarly, it is uneconomic for the turbine exhaust to be more than slightly superheated.

Each potential application of cogeneration technology presents its own system requirements. It is therefore perhaps fortunate that the three widely used cogeneration technologies differ significantly in major system parameters: size range, capital and operating costs, division of output power between steam and electricity, efficiency, fuel, etc. These technology-dependent characteristics are summarized later, after each is discussed. In order to be relatively complete, we include below both efficiency equations and system parameter graphs to permit the reader to perform similar calculations for applications other than our sample case.

As mentioned in Section 22.1, topping cycles are cycles in which the highest "quality," i.e., highest temperature and pressure, working fluid (steam or combustion product) is used to generate electricity with the lower temperature exhaust used for heating purposes. Bottoming cycles utilize the high quality heat stream for heating and the cooled-down steam for electricity generation. In either case, unused heat is either wasted or returned to the heat source for reheating.

As a general rule, topping cycles are more desirable than bottoming cycles. It is more difficult efficiently to extract an equal amount of electrical energy from a low-temperature stream than from a high-temperature stream. The lower pressure requires larger, more expensive machinery. Also, although much of the stream into a bottoming generator can be used, a bottoming generator operating on a low quality heat stream and small temperature differences is thermodynamically less efficient than its topping cycle counterpart. Lower overall system efficiency is inevitable. Why then consider bottoming cycles at all? In certain cases, a large high quality heat stream is needed and the exhaust may well contain large amounts of extractable energy, providing practical and economic bottoming cycles can be developed.

Section 22.2.1: Steam Turbine Topping Cycle

Of the cycles mentioned in Section 22.1, the steam turbine topping cycle has found the widest acceptance in relatively large-scale applications such as those which occur in the pulp and paper industry.

The cycle produces electrical power by means of a back-pressure (non-condensing) steam turbine and generator. The exhaust steam from the turbine provides process heat for the industrial plant. Figure 22-2 shows this cycle in schematic form (stack gas heat recovery economizers and space heating applications are not shown). An efficient, modern steam generator which provides generator inlet steam conditions of 1,250 psig and 900°F is assumed. The exhaust conditions are design parameters; 150 psig was chosen as a normative value.

A major advantage of the steam turbine topping cycle lies in its very high fuel utilization efficiency -- approaching 75%.^{*} Assuming a well-balanced operating system in which steam and electricity requirements are compatible, the major loss is in heat lost through the boiler smoke stack; generator and turbine losses are smaller contributors. Essentially all the heat carried off by the low temperature outlet steam stream can be recovered as process heat or can be recycled to the boiler as hot condensate. (In a conventional steam turbine generator most of the wasted energy is rejected through the condenser at relatively low temperatures.) The numerical examples following assume that 75% of the process steam is condensed and returned to the boiler as 180°F water. In order to run in a steady-state, the 25% lost is made up as 70°F water. To be more specific, the heat energy, Q_{tot} , available from burning a unit of fuel can be expended in three ways: as useful process or recycled heat, E_H , as electrical energy, E_E , or as wasted energy, E_{loss} ,

$$Q_{tot} = E_E + E_H + E_{loss} \quad (22-1)$$

The overall system or fuel utilization efficiency, η_{FU} , is

$$\eta_{FU} = \frac{E_E + E_H}{Q_{tot}} = \frac{E_E}{Q_{tot}} + \frac{E_H}{Q_{tot}} \quad (22-2)$$

The advantage of cogeneration is that its fuel utilization efficiency can be much larger than the thermodynamically limited efficiency

^{*} In the overall cogeneration process.

SOURCE: Arthur D. Little, Inc.

FIGURE 22-2 ALTERNATIVE COGENERATION SYSTEMS - SIMPLIFIED SCHEMATICS

of electric generation without waste heat recovery. The overall fuel utilization efficiency, η_{FU} , of the sample steam turbine topping cycle is typically 75%.⁽¹⁾ A similar plant optimized for electric generation alone would be about 35% efficient ($E_H \sim 0$, Equation 22-2). It is worth stressing that the cogeneration of electricity is an incremental process; a little more steam energy is generated than needed for process heat and most of this "extra" energy is extracted as electrical energy. A small fraction of the "extra" energy is lost up the boiler smoke stack and smaller fractions to friction and other heat sinks, but the large fraction which would otherwise be wasted as exhaust enters the process heat stream. Thus the effective* efficiency for conversion of the incremental heat input to electrical energy is high.

To be more specific, for the sample case described here and in Reference 1, process steam alone can be generated at an efficiency somewhat greater than 75%; the effective (or marginal) efficiency, η'_E , for electricity generation is about 72% when a steam turbine topping cycle is added to the process steam boiler. That is to say, 72% of the incremental heat energy input, ΔQ , required for the output of one unit of electrical energy, E_E , appears as electricity. Thus, the incremental heat energy required for this form of electrical cogeneration is roughly half of that required by a central power station. The positive implications for the nation's fuel utilization and the institutional constraints on the implementation of large-scale industrial cogeneration are discussed elsewhere^(1,2) and in Sections 22.3 and 22.4.

The division of the useful output energy between electricity and heat depends on the purpose and design of the entire system; this will be discussed in detail later. For the sample case with steam turbine topping cycle cogeneration, the ratio of electrical energy output to process heat output, α , is small (about 1/6).⁽¹⁾ If the input heat energy utilized for process steam generation, Q_p , ($Q_p = Q_{tot} - \Delta Q$) is utilized with efficiency, η_H , we can summarize as follows:

*The phrase "marginal efficiency" is generally used to describe the effective efficiency of electricity cogeneration; the phrase "incremental efficiency" is also appropriate. The point to be taken is that the increment in heat input is used efficiently to generate electrical energy and process steam energy - not that the second law of thermodynamics can be abrogated to permit greater than 70% efficient generation of electricity alone.

$$\eta_{FU} Q_{tot} = \eta_{FU} (Q_P + \Delta Q) = E_H + E_E;$$

$$E_E = \alpha E_H; \quad (22-3)$$

$$\eta'_E \Delta Q = E_E;$$

$$\eta_H Q_P = E_H.$$

where $\eta_{FU} = 0.75$, $\eta'_E = 0.72$, and $\alpha = 0.17$. The efficiency of process heat generation, η_H , is not particularly meaningful because an entirely different boiler system is used for process steam generation without cogeneration. Nonetheless, it is useful in comparing cogenerating and non-cogenerating steam supply systems. In this case, the set of Equations 22-3 can be solved to give $\eta_H \sim 75.5\%$.

Conventionally, heat rate, rather than its inverse, efficiency, is used as a system design parameter. In this case, the major concern is with the marginal heat rate, ρ'_E ; the overall heat rate, ρ_{FU} , is also used in the literature

$$\rho'_E = \frac{1}{\eta'_E} = \frac{\Delta Q}{E_E}; \text{ and} \quad (22-4)$$

$$\rho_{FU} = \frac{1}{\eta_{FU}} = \frac{Q_{tot}}{E_H + E_E}.$$

Note that because energy is used in more than one way in cogeneration, more than one efficiency (or heat rate) can be defined.

Also, conventionally, heat energy is measured in British thermal units (Btu) and electrical energy in kilowatt-hours (kWh). Because one kWh is equivalent to 3,413 Btu, a heat rate of 3,413 Btu/kWh is equivalent

to 100% efficiency. That is to say, the sample 75% efficient cogeneration system would have an overall heat rate of approximately 4,550 Btu/kWh ($4,550 = 3,413/0.75$); a fuel input of 4,550 Btu would give 1 kWh of useful energy divided between electrical power and heat for process applications. The corresponding marginal heat rate for electrical generation is 4,740 Btu/kWh ($4,740 = 3,413/0.72$).

Figure 22-3, adapted from Figure 3-1 of Reference 1, is a plot illustrating the preceding discussion. The horizontal line at 3,413 Btu/kWh represents 100% efficiency in fuel use; the horizontal line at about 4,740 Btu/kWh illustrates that steam turbine cogeneration efficiency is nearly independent of outlet steam quality. Also shown are curves for combustion turbine and diesel cogeneration which will be discussed later. Note, however, that both are less efficient electricity producers (more Btu's of fuel required per kWh of useful output) and grow progressively less efficient as process steam quality requirements increase. Note that Figure 22-3 assumes the given boiler, recycle and makeup conditions, and that no heat is extracted for supplementary, higher quality steam.

The division between heat energy available for process utilization and the amount generated as electricity remains to be discussed. If it is assumed that the generator exhaust is not significantly superheated,* a single parameter, taken to be process steam pressure, is adequate to describe this division. Figure 22-4 gives the ratio of the electrical energy generated to process heat energy (E_E/E_H) as a function of process steam pressure for the three topping cycles. The left hand vertical axis is labeled in terms of available power both in kilowatts of electrical power available per million Btu/hour of heat power and nondimensionally as α (in a common set of units). The right hand vertical axis gives the percentage of the total usable energy available as electricity. At 150 psig steam pressure, 14.5% of the available energy appears as electricity and $\alpha = 0.17$. The steam turbine topping cycle is a notably efficient producer of high quality process steam and, therefore, produces less electricity per unit of process heat than its competitors. As steam quality is reduced, e.g., for district heating, the steam turbine topping cycle produces relatively more electricity. In any case, it is

*See footnote 3 to Table 22-2.

SOURCE: Reference 1.

FIGURE 22-3 INPUT HEAT REQUIREMENTS FOR ELECTRICAL COGENERATION AS A FUNCTION OF PROCESS STEAM PRESSURE

SOURCE: Reference 1.

FIGURE 22-4 ELECTRIC POWER GENERATION CAPABILITIES PER UNIT OF PROCESS STEAM USING DIFFERENT COGENERATION TOPPING TECHNIQUES

overall the most fuel efficient of the three systems.

Backpressure turbines, in which all of the exhaust stream is delivered as process heat and steam, are the most commonly used type of turbine in steam turbine cogeneration. Typically, exhaust pressures range from 100 to 300 psig. Specific applications, however, may require a larger ratio of electricity to process heat. This can be achieved by the use of extraction turbines in which part of the steam supply is extracted from the turbine at an appropriate pressure and temperature for process use, while the diminished steam continues to produce power in the lower pressure expansion stages of the turbine. Since the final output pressure and temperature may be too low for process application, the system may be less energy efficient than the backpressure turbine although it provides more electricity. Steam turbine topping cycles are therefore quite flexible in design but very inflexible in economic use.*

Steam turbine generators are available in unit sizes from a few kilowatts to over 1,000 megawatts. The range of sizes applicable to the pulp and paper industry cover the range from below 100 kW to more than 5 MW of electrical output with most applications in the high end of the range.

Steam turbine generators consistently operate up to several years without a major inspection and ten years between overhauls.⁽¹⁾ Service life is very long; many units presently in operation are over 40 years old. The steam turbine generator cogeneration configuration has demonstrated reliability higher than either diesel or combustion turbine cycles. It is a mature product, and further development can be expected only in the form of minor improvements. Installation of a steam turbine generator takes about two years from commitment to startup.

Fuels which can be used for steam turbine cogeneration are principally coal, oil, gas, wood wastes and manufacturing residue. It is significant that otherwise unusable residue can be used and supplemented with coal, essentially replacing purchased oil and gas while substantially reducing the problems of waste disposal. In the wood pulp industry, wood wastes may be able to meet all fuel requirements. Gas or

*Because steam turbines can be operated efficiently and safely only within a narrow range of operating parameters. Excess electricity might be sold to a public utility; excess heat will be wasted.

oil requirements can be reduced to that required only for startup and flame stabilization.

Siting of a power plant of this type is easier than siting a major generation plant. With the exception of the pulp and paper industry, plants are frequently located in an already industrialized area and are much smaller than electric utility installations. The cooling problem is less severe, because exhaust steam is delivered to the process rather than to a water-cooled condenser or cooling tower. With increasing burning of coal, emission control will be an expensive requirement. Low sulfur western coal is not readily available to eastern plants, and scrubbers may be necessary even with low sulfur coal.⁽¹⁾

Section 22.2.2: Other Current Cogeneration Technologies

In addition to steam turbine cogeneration, combustion turbines and diesel engine plants are used for cogeneration. They are reviewed only briefly in the following paragraphs since they have been discussed at length in Chapters 12 and 13.

A. Combustion Turbine Cogeneration

In this system, a combustion (gas) turbine (see Chapter 12) is used to generate electricity and the high temperature exhaust is passed through a heat recovery steam generator to provide steam for industrial process heat at temperatures up to approximately 400°F (200 psig). Because the temperature of hot gas in the combustion turbine is much higher (up to 1,500°F) than that of the steam from the boiler (900°F in the preceding discussion), it contains more thermal energy that can be used to generate electricity before the residual heat is used to generate process steam. As a result, the ratio of electrical power to process steam heat is higher for a combustion turbine than for a steam turbine cogeneration plant. This is illustrated in Figure 22-4 which indicates that, at the same process steam temperature, the available electrical power output of a combustion turbine system (called there a gas turbine) may be 3 to 5 times that of a steam turbine cogeneration plant.* This is not

*For the nominal case, the combustion turbine topping cycle achieves an overall 65% efficiency ($\eta_{FU} = 0.65$), with 62.5% marginal electrical generation efficiency ($\eta_E = 0.625$). The corresponding marginal heat rate is 5,460 Btu/kWh. Without cogeneration, combustion turbine electricity generators operate at about 23% efficiency.

to be interpreted as a statement that the combustion turbine is a good producer of electricity but rather that it is a poor producer of steam because of the relatively poor heat transfer from the exhaust gas to the heat recovery boiler. Operating flexibility in the ratio of steam produced per unit of electricity can be obtained by providing supplemental heating in the steam generator, usually with gas or oil, or by by-passing part of the turbine exhaust.

Combustion turbine generators are commercially available in sizes from below 300 kW to 100 MW. The attractive features of combustion turbines are that they are quickly started and brought on line, do not require a cooling system, and are easily installed because of their simplicity and light weight. Lead time is one to two years from decision to startup. The installed cost per kW is less than that for a steam turbine, but operation and maintenance costs are higher. A hot-section inspection (approximately one day of downtime) is required every six months, and major overhauls in the range of 20,000-30,000 hours of operation. Service life of 15 to 20 years can be expected.

Combustion turbines have been in use for many years for electricity generation; recent developments in materials and design have improved operating life and cycle efficiency. This equipment is now quite mature in its development cycle, and only improvements of an evolutionary nature are expected.

Combustion turbines require liquid or gaseous hydrocarbon fuels. Many are operating on crude oil. While experimental work has been done on the use of pulverized coal, these efforts have been discontinued because of the apparently insurmountable difficulties of extensive turbine blade erosion.⁽¹⁾ This implies that the combustion turbine topping cycle is one that cannot be directly based on coal (in the near future at least) and requires oil, gas, or coal-derived fuels.

Combined cycles have been proposed in which the process steam developed in the combustion turbine exhaust heat recovery boiler is used to generate additional electricity. The residual stream is then low-pressure process steam. Clearly, as the second stage of power generation

exhausts to lower and lower temperatures, the heat recoverable as process steam continues to diminish and the overall process approaches utility power generation. This complex system thus loses its attractiveness as a conservation measure and is only of interest in specialized applications where the demand for process steam is small and variable.

B. Diesel Engine Cogeneration

As discussed in Chapter 13 and also in Chapter 23 (Total Energy Systems) waste heat can be recovered from the cooling system and from the exhaust of the diesel engine. Since the diesel engine uses fuel relatively efficiently, much of the waste heat is at relatively low temperatures. The ratio of work (that is, electricity) to recoverable process heat is high (Figure 22-4). Hence, the diesel engine is used in cogeneration systems where the demand for electricity determines the size of the plant and waste heat becomes a useful but not size-determining consideration. In addition, since the power output is determined by fuel supply to the engine and the efficiency of fuel use varies only slightly with power output, the ratio of electrical and thermal output does not vary greatly (Figure 22-4). In consequence, the split between electricity and process steam is relatively inflexible. Electric incremental heat rates are in the 6,000 to 7,000 Btu/kWh range corresponding to 57% to 49% overall energy use efficiency.

Typical diesel engine sizes in cogeneration use are in the 1 to 3 MW range. A major drawback to substantial increase in the use of diesel generation, which applies also to gas turbines, is their need for the use of petroleum based fuels. Some of the larger diesels, however, can burn residual fuels and combustion turbines can use natural gas.

Industry is showing substantial interest in the purchase of small prepackaged diesel cogeneration plants for use where electricity costs are high.^(3,4) The long-term effects of the resulting increased consumption of diesel fuel have not been considered (at least publicly) although the effect upon the local utility load is causing concern.⁽³⁾ Neither have the environmental effects received wide attention although

these units are frequently installed in non-industrial urban locations. Unit size for small prepackaged diesel cogeneration systems ranges from 200 kW to 4 MW, which has made them attractive to small industries and large buildings.*

Section 22.2.3: Summary of Cogeneration Characteristics

Table 22-3, entitled Characteristics of Important Cogeneration Systems, provides a generalized comparison of the steam turbine, combustion turbine and diesel topping cycles. Some of the data presented, e.g., concerning diesel generation, is discussed in detail elsewhere in this report. Nonetheless, it is appropriate to summarize in capsule form at this point. Justification and amplification for the simplified summary statements can be found in the text, extracted from the tables and graphs, or is directly referenced.

Meaningful cost comparisons are especially difficult to make because of the very different characteristics of the three systems; for any given application, no more than two approaches are competitive. As an illustrative rough comparison, the two turbine cycles are costed for the example process requiring 500,000 pounds of steam per hour. A diesel based system which generates one half million pounds of 150 psig steam per hour would also generate about 200 megawatts of electricity. Because diesel cogeneration of that much electricity is highly improbable,** we list the cost of a diesel cycle generating about the same amount of electricity as the steam turbine cycle. This system could produce only about 100,000 pounds of steam per hour. Therefore, the diesel cycle cost should be further incremented by the additional cost of providing 400,000 pounds of steam per hour, an additional $\$12 \times 10^6$ ⁽¹⁾, thus demonstrating

* Diesel cogeneration is characterized by a relatively low-quality heat stream. It is best suited for small installations providing electricity and space heating. This is borne out by the fact that about 600 such installations are in the field in the form of partial or complete "total energy" packages.⁽⁴⁾

** Very few industrial applications would be capable of utilizing half the electricity generated by a 190-megawatt system. In that case, it is questionable if this distillate oil-powered system would qualify for the cogeneration exemption⁽⁵⁾ to the Power Plant and Industrial Fuel Use Act of 1978.

TABLE 22-3

CHARACTERISTICS OF IMPORTANT COGENERATION SYSTEMS

	<u>Steam Turbine Topping Cycle</u>	<u>Combustion Turbine Topping Cycle</u>	<u>Diesel Topping Cycle</u>
<u>Reliability</u>			
overall (comparative)	highest	high	lowest ⁽⁴⁾
typical inspection/overhaul periods	3-5 yrs/10 yrs	6 mos/2-4 yrs	600 hrs 1-3 yrs
typical service life	30-50 yrs	15-20 yrs	20-25 yrs
<u>Costs</u> ⁽¹⁾ (lbs steam/hr/elec. gen.)	500,000/30x10 ⁶ W	500,000/120x10 ⁶ W	100,000 ⁽²⁾ /40x10 ⁶ W
initial (incremental)	\$15x10 ⁶	\$20x10 ⁶	\$10x10 ⁶
per kW generating capacity	\$500	\$170	\$280
of electricity generated	2.0c/kWh ⁽³⁾	2.4c/kWh	2.8c/kWh
<u>Fuel Requirements</u>	flexible, can use coal or waste products	residual oil or gas	distillate
<u>Fuel Utilization Efficiency</u> (nominal)	75%	65%	70%
output mix - electricity	14%	40%	52%
- heat	86%	60%	48%
<u>Flexibility in Design</u>			
overall (comparative)	high	highest	limited
size range	500 kW-400x10 ⁶ W	300 kW-100x10 ⁶ W	100 kW-4x10 ⁶ W
electricity/heat ratio ⁽⁴⁾	± 30%	± 5%	± 6%
steam quality	high	moderate	limited
<u>Flexibility in Operation</u> (in heat to electricity ratio)	low, efficiency penalty	high, efficiency penalty	lowest, but good part load electrical performance
<u>Siting Problems</u>	few	least	noise
<u>Emissions</u>	depends on fuel, can be a major problem	none to low	low
<u>Technological Status</u>	← mature →		
<u>Installation Time</u>	2 years	1-2 years	~ 1 year

(1) Costs are in 1977 dollars; for more details see Section 22.2.4 and Reference 1.

(2) Multiple unit system; additional 400,000 lbs steam generation would increase cost by about \$1x10⁷.
Larger units, to 40 megawatts, are available for utility service.

(3) Fuel assumed is coal with no use of waste byproducts.

(4) Without extraction or supplementary heating.

SOURCE: Reference 1 and Arthur D. Little, Inc., calculations.

that diesel cogeneration is not cost-effective when large amounts of process steam are required. All costs are in 1977 dollars and based on information in Reference 1; in Section 22.2.4 the costing assumptions are given. The listed costs are the incremental costs required for electrical generation over and above steam production.

Section 22.2.4: Cost Estimates

The busbar cost for electricity produced by cogeneration is estimated in Table 22-4. The costs listed there are based on the costs of complete cogeneration systems designed to produce both steam and electricity less the cost of 150 psig steam generating equipment. This approach permits calculation of electrical energy cost due solely to the electrical part of a cogeneration system. There is wide installation-specific variation in cogeneration system costs because more diverse demands are placed on cogeneration systems than on single-purpose electrical generation or steam plants.⁽⁶⁾ Thus the costs given here are for comparison purposes only; nonetheless, they fall centrally within the inflation adjusted range of costs recently estimated for twenty-nine selected sites in New York State.⁽⁶⁾ Similarly, in the base line year (1977), oil costs were very variable depending on a number of factors, which cannot be all addressed in a simplified, industry-wide, cost estimate. For this reason, we have used a single cost for combustion turbine and diesel fuel.*

Finally, for completeness, Table 22-5 also includes total costs for entire cogeneration systems.

Section 22.2.5: Proposed Cogeneration Technologies

Several energy conversion technologies now in an advanced stage of development have been proposed for use in future cogeneration systems. These are: Stirling engines, fuel cells, and organic Rankine cycles. None of these systems is currently available in commercial sizes likely to be of industrial interest. Nevertheless, their potential usefulness warrants their receiving attention for possible use in cogeneration systems when and if they reach commercial and technical maturity. Stirling cycle engines (Chapter 14) are attractive for their high thermal

* See Chapter 1 for a discussion of fuel costs.

TABLE 22-4
INCREMENTAL⁽¹⁾ BUSBAR COST OF ELECTRICAL ENERGY FROM COGENERATION
 (1977 dollars)

<u>Steam Flow</u> (lbs/hr)	<u>Coal-fired Steam Turbine</u> (\$/kWh)	<u>Oil-fired Combustion Turbine</u> (\$/kWh)	<u>Diesel</u> (\$/kWh)
100,000	0.027	0.025	0.028
300,000	0.022	0.024	0.028
500,000	0.020	0.024	0.028

ASSUMPTIONS

1. 15% charge rate based on 10% cost of capital, 25 year operating life, miscellaneous fixed charges of 4%.
2. Capital costs from Reference 1 with inflation multiplier of 1.134 (1975-1977).
3. 80% capacity factor.
4. Coal-fired steam turbine cogeneration @ \$1.20/10⁶ Btu -- use of waste byproducts, as is possible in the pulp and paper industry, can significantly lower fuel costs. Oil-fired combustion and diesel cogeneration @ \$2.90/10⁶ Btu.
5. Process steam credit at following marginal efficiencies: Steam turbine -- 72%, combustion turbine -- 62.5%, diesel engine -- 56%.
6. O&M costs (excluding fuel): Steam turbine -- \$0.003/kWh, combustion turbine and diesel -- \$0.004/kWh.
7. For capital costs see Table 22-5. The busbar costs above are based on incremental cost of electricity generation.

(1) These include incremental capital costs. (See Table 22-5.) O&M costs (excluding fuel) are allocated entirely to electricity generation because with cogeneration these costs are much greater than those for low-pressure process steam boilers.

SOURCE: Reference 1 and Arthur D. Little, Inc., calculations.

TABLE 22-5
COGENERATION SYSTEMS TOTAL CAPITAL AND ELECTRICAL INCREMENTAL COSTS
 (1977 dollars)

<u>Steam Flow</u> <u>(lbs/hr)</u>	<u>Coal-fired</u> <u>Steam Turbine</u> <u>(\$/kW)</u>		<u>Oil-fired</u> <u>Combustion Turbine</u> <u>(\$/kW)</u>		<u>Diesel</u> <u>(\$/kW)</u>	
	<u>Total</u>	<u>Increm.</u>	<u>Total</u>	<u>Increm.</u>	<u>Total</u>	<u>Increm.</u>
100,000	1600	830	350	240	360	280
300,000	1100	590	280	170	360	290
500,000	970	500	270	170	350	290

ASSUMPTIONS

1. Costs from Reference 1 with 1.134 inflation factor (1975 - 1977).
2. Steam turbine totals include fuel and ash handling equipment and pollution control equipment. Incremental costs exclude fuel handling, ash handling and pollution control equipment as these would be required for process steam generation.
3. Combustion turbine and diesel incremental costs are based on differential between complete system and alternative oil-fired process heat boiler system with the requisite fuel handling and pollution control systems. Coal-fired process heat boiler cost differentials are about \$27/kW and \$34/kW less for diesel and combustion turbines, respectively.

SOURCE: Reference 1.

efficiency and their ability to use many different types of fuel. Since the waste heat can be extracted relatively easily (as in the case of a diesel engine) their application to cogeneration systems is unlikely to present major difficulties.

Fuel cells (Chapter 16) are not yet available in large commercial sizes and the temperature at which waste heat can be made available by existing cells is limited to 260°F. Nevertheless, the relative simplicity by which heat can be extracted may make fuel cells attractive in situations where the electricity demand establishes system size and where there is a need for quantities of heat at modest temperatures.

The technical and financial issues associated with the use of utility-owned, grid-connected, dispersed fuel cells operating as dual energy use systems (DEUS) have been assessed in an investigation supported by the Electric Power Research Institute.⁽⁷⁾ The study examined the role of fuel cells to provide economic intermediate or peaking duty for the electric utility system, and to satisfy thermal loads in the residential, commercial, industrial and utility sectors. The results indicated that both phosphoric acid and molten carbonate fuel cells were economically attractive and technically viable for DEUS applications. The most attractive applications were building systems such as universities and hospitals; paper and pulp mills in industry; and air preheating for utility power plants.

Organic Rankine cycle machines (Chapter 15) may be of use where the residual stream at the low temperature end of the process steam cycle is present in sufficient quantity and quality to justify the addition of a bottoming cycle the capital costs of which tend to be high. The technology is available to construct organic Rankine cycle machines of commercially attractive sizes, but this new and operationally unproven technique has not yet attracted open market interest. Clearly, such bottoming cycles are only of interest where there is a need for process steam at high temperatures and an absence of attractively priced electricity.

Section 22.3: Factors Affecting the Use of Industrial Cogeneration

It has been recognized for some time that the fraction of electricity demand that industry has met by cogeneration has decreased substantially between the 1950's and the early 1970's. The pattern of electricity generation and use for the six major power consuming industries--food, textiles, pulp and paper, chemicals, petroleum refining and steel--for the years 1947 and 1976 is presented in Table 22-6. It indicates that although total electricity generated by these industries increased by 91% and total electricity consumption by 382%, the fraction cogenerated decreased from 31.6% to 12.5% of the total consumption. (8)

During this period the electric generating capacity of the U.S. increased by a factor of 8.7 and was associated with a drop in the real price of electricity for all classes of customers. As a result it became harder for an industry, planning to construct process steam producing boilers, to justify the incremental cost of the electric generating plant.

The cost of electricity from the local utility is not the only factor to be considered although it may be a major one. Other considerations are technical and institutional. Technical considerations include, for example, the constancy, or lack thereof, of a plant's demand for electricity and the ability of the local utility to handle a demand which may vary seasonally. For example, sugar cane processing is seasonal and for much of the year the demand on the utility is low. On the other hand, agricultural waste products provide an inexpensive fuel supply so that cogeneration can become attractive. The ratio of electricity to process steam and its constancy determine the type of cogeneration plant that is desirable and consequently the costs of cogenerated energy.

In a 1975 report to the National Science Foundation by the Dow Chemical Company⁽⁹⁾ the following factors were suggested as causes of the decline in industrial cogeneration:

- a. corporate income tax rates that encourage the

TABLE 22-6

PATTERN OF ELECTRICITY GENERATION AND USE FOR SIX MAJOR U.S. INDUSTRIES

<u>Industry</u>	Electricity Generated by Industry and Used by Generating Company			
	10 ⁶ kWh		% of Industry Consumption	
	<u>1947</u>	<u>1976</u>	<u>1947</u>	<u>1976</u>
Food	1753	2584	17.2	6.2
Textiles	1753	484	17.5	1.7
Pulp and Paper	9211	25487	59.9	37.0
Chemicals	7647	14954	39.0	9.3
Petroleum Refining	2745	4499	42.2	14.0
Steel	<u>9217</u>	<u>13698</u>	<u>22.7</u>	<u>8.5</u>
Total	32326	61706	31.6	12.5

SOURCE: Reference 8.

- substitution of expenses for capital investments, and generally tend to foster shorter term thinking;
- b. decreasing prices for electricity from central power stations that encourage substituting electric power for steam in some situations, thereby eroding the industrial steam base over time;
 - c. changes in the labor situation that make it difficult for industry to find and keep people able to handle the problems of coal-fired boilers;
 - d. availability of gas- and oil-fired low-pressure packaged boilers that replace higher pressure coal-fired boilers suitable for cogeneration;
 - e. the shortened work week in many industries that increases operating problems and lowers the utilization of capital equipment;
 - f. the continual widening of a difference in average size of central power stations vs. industrial power generators, thus tilting economies of scale in favor of central power stations;
 - g. an attitude on the part of industrial management either to say, in effect, "we're not in the power business" or to impose on power operations those policies relating to operation, maintenance, spare parts, etc., which apply to the major portion of the business;*

* For example, power plant maintenance usually comes in infrequent but expensive doses. In his desire to keep up production levels, the uninitiated manager may attempt arbitrary economies, which may appear successful because a power plant normally has substantial built-in reserves. Continuation of this practice, based upon its apparent success, can bring the manager to a point at which he suddenly finds himself without a functioning power plant. Industrial plants have abruptly connected to the utility following the above scenario, and the process has seldom been reversed.(9)

- h. long-standing policies on the part of most privately owned electric utilities, such as declining rate schedules and heavy electrical demand charges that have discouraged the generation of electricity by other types of organization.

In addition to the technical complexities of matching the utility to the industrial plant's demand, the above considerations inevitably play a role in a company's decision to undertake the construction of a cogeneration facility. The decision, in each case, will reflect the objectives and perspectives of the individual company and the power supply and financial conditions in which it finds itself. The effect of institutional constraints to be faced in the implementation of cogeneration is well summarized in the following quotation from Reference 6: "Of vital concern to industrial plant managers is security of supply and flexibility of operation; cogeneration systems will not be implemented, irrespective of the extent by which they reduce purchased power costs, if product manufacture or essential services are put at risk."

Section 22.4: Future Prospects for Cogeneration

The discussion of the preceding paragraphs has made two points clear: (1) much more complete use can be made of the energy in fuels when electricity and process steam or heat are cogenerated than when they are produced separately, and (2) technologies are available and others are being developed for efficient and economic cogeneration for a wide variety of industrial applications. Since it is widely recognized that energy conservation is the most cost-effective way of reducing the nation's demand for fuels of all types, cogeneration is likely to play an important role. The question then arises -- What national benefits can be achieved by the widespread use of cogeneration, and what must be done to realize them?

Two studies (1,10) have examined in detail the economics and techniques of cogeneration; (a) "A Study of Inplant Power Generation in the Chemical, Petroleum Refining, and Paper and Pulp Industries," by Thermo Electron Corporation for the Federal Energy Administration, (1)

and (b) "The Potential for Cogeneration Development in Six Major Industries by 1985," by Resource Planning Associates, Inc. (RPA) for the Department of Energy.⁽¹⁰⁾ The RPA report studied the factors that industry considers in deciding whether or not to install a cogeneration plant. It then provided an estimate of the potential for growth in cogeneration if economic and regulatory conditions remained unchanged (no Government action) and if the U.S. Government were to act to reduce the perceived barriers to the widespread installation of cogeneration. Table 22-7 summarizes their finding if there were no Government action.

With U.S. Government action, the predicted 1985 cogenerated steam total of 1.7×10^{15} Btu can, according to RPA, be increased to a possible maximum of 2.6×10^{15} Btu, an increase of 0.9×10^{15} Btu. (See Table 22-8.) The corresponding increase in power generating capacity will be between 2000 and 6000 MW. (For comparison, the total installed generating capacity of the U.S. electric industry in 1978 was 557 GW.) These very substantial increases in cogeneration plant capacity could result from the following government actions:

- a 30% investment tax credit;
- a 12 year depreciation option;
- government loan guarantees;
- exemption from FERC and PUC jurisdictions of industrial cogeneration plants operating in parallel with, but not selling to, a utility;
- equitable prices for purchases of power by utilities from cogeneration plants;
- establishment of industrial electric power flat rate structures;
- exemption from oil and gas use taxes;
- relaxation of sulfur dioxide emission standards; and
- preferential treatment on oil and gas allocations.

The first two actions are expected to induce the greatest development of cogeneration and thus result in the largest energy savings, but the remainder are generally more cost-effective. The reader is referred to the original report for a more detailed discussion and for estimates of the contributions to more cogeneration that each action would stimulate.

TABLE 22-7

COMPARISON OF COGENERATED PROCESS STEAM PRODUCTION IN 1976 AND 1985 (EST.)
IN SIX MAJOR INDUSTRIES (NO GOVERNMENT ACTION)

Cogenerated Process Steam (10^{15} Btu)

<u>Industry</u>	<u>1976</u>	<u>1985</u>
Food	0.027	0.049
Textiles	0.015	0.013
Pulp and Paper	0.236	0.891
Chemicals	0.190	0.408
Petroleum Refining	0.015	0.107
Steel	<u>0.101</u>	<u>0.247</u>
	<u>0.584</u>	<u>1.715</u>

Corresponding Electrical Capacity 4,000 MW

10,000 MW

SOURCE: Reference 10.

TABLE 22-8

PROCESS STEAM COGENERATION AND COGENERATION POTENTIAL(in units of 10^{12} Btu)

	<u>Requirements</u>		<u>Cogeneration without Government Action</u>		<u>Additional Capacity Economically Attractive without Government Action</u> ⁽¹⁾		<u>Additional Cogeneration Expected by 1985 with Government Action</u> ⁽¹⁾	
	<u>1976</u>	<u>1985</u>	<u>1976</u>	<u>1985</u>	<u>1976</u>	<u>1985</u>	<u>Minimum</u> ⁽²⁾ <u>Development Program</u>	<u>Maximum</u> ⁽²⁾ <u>Development Program</u>
Six industries ⁽³⁾	4100	5900	584	1715	250	1160	279	859
Others	5600	8000	40-50 ⁽⁴⁾	(5)	25	120	(5)	(5)

(1) By 1985 most of the economically attractive cogeneration capacity would be utilized by the six industries (1131×10^{12} Btu of 1160×10^{12} Btu). The maximum likely process steam cogeneration in 1985 is 2574×10^{12} Btu ($2574 = 1715 + 859$).

(2) Minimum development program -- regulatory encouragement only. Maximum development program -- heavy government financial involvement, see page 22-30.

(3) Food, Textiles, Pulp and Paper, Chemicals, Petroleum Refining, Steel.

(4) Arthur D. Little, Inc. estimate based on data in References 1 and 10.

(5) No calculations made, increments are small (less than 120×10^{12} Btu).

SOURCE: Reference 10.

REFERENCES

1. Thermo Electron Corporation. A Study of Inplant Electric Power Generation in the Chemical, Petroleum Refining, and Paper and Pulp Industries. Prepared for Federal Energy Administration, June 1976. NTIS Report No. PB255 659.
2. Arthur D. Little, Inc. Energy Penalties Associated with Environmental Regulations in the Pulp and Paper Industry. Vol. II, Analytical Results. Washington, D.C.: Environmental Protection Agency, Office of Planning and Management, June 1977.
3. Alexander, T. "The Little Engine that Scared Con Ed." Fortune 98 (13):80. December 31, 1978.
4. Cummins Cogeneration Co., Inc., Empire State Building, 350 Fifth Avenue, New York, New York. Personal communication. September 1979.
5. Economic Regulatory Administration, U.S. Department of Energy. "Powerplant and Industrial Fuel Use Criteria for Petition for Exemption from Prohibitions." (Interim Rule). Federal Register 44(97): 28949. May 17, 1979.
6. Acres American, Inc. Survey of Cogeneration Potential of Selected New York State Industries. Albany, New York: New York State Energy Office, June 1979.
7. Mathtec, Inc. An Analysis of the Application of Fuel Cells in Dual Energy Use Systems. Vol. 2. Report prepared for Electric Power Research Institute, February 1979. EPRI Report No. EM-981.
8. O'Neill, J.K. et al. "Cogeneration in the Chemical Process Industries." Unpublished paper. Cambridge, Massachusetts: Arthur D. Little, Inc., [1979].
9. Dow Chemical Company. Energy Industrial Center Study, Report prepared for National Science Foundation, June 1975. NTIS Report No. PB 243 823.
10. Resource Planning Associates, Inc. The Potential for Cogeneration Development in Six Major Industries by 1985. Report prepared for U.S. Department of Energy, December 1977. NTIS Report No. HCP/M60172-01/2.

SUPPLEMENTARY BIBLIOGRAPHY

1. Bos, P.G. et al. "Cogeneration's Future in the CPI." Chemical Engineering 86(5):104. February 26, 1979.
2. Troop, P.A. "Cogeneration in a Changing Regulatory Environment." Chemical Engineering 86(5):111. February 26, 1979.
3. Javetski, J. "Cogeneration: Washington Fiddles While Industry Burns." Power 122(4):35. April 1978.
4. Hallman, D.W. "Save Energy by Cogeneration." Hydrocarbon Processing 57(5):151. May 1978.
5. Hilsen, N.B. et al. "Environmental, Economic and Conservation Aspects of Integrated Energy Systems." Proceedings of the 12th Intersociety Energy Conversion Engineering Conference, Washington, D.C., August 28 - September 2, 1977. pp. 621 ff.

TECHNOLOGY SUMMARY SHEET

GENERAL	TECHNOLOGY TITLE: TOTAL ENERGY SYSTEMS DESCRIPTION: Systems produce electric power on-site with diesel, combustion turbine, or steam turbine generators and use reject heat from power cycle for space, water heating, and air conditioning.(1)																																	
	POTENTIAL USER CLASSES: Residential complex (high density), shopping centers, hospitals, industrial parks, schools, and other building complexes requiring large amounts of power and heat. STATUS OF TECHNOLOGY DEVELOPMENT: Technology is mature for systems using oil and gas fuel sources. Improvements needed in systems burning coal, particularly in lower capacity range.																																	
TECHNICAL	UNIT POWER OUTPUT CAPACITY: (MW) PRIMARY (ii) (10 ⁶ Btu/hr) SECONDARY (iii)	<table border="1"> <tr><th>1977</th><th>1985</th><th>2000</th></tr> <tr><td>1-5</td><td>same</td><td>same</td></tr> <tr><td>3.7-18</td><td>same</td><td>same</td></tr> <tr><td>5.3-26</td><td>same</td><td>same</td></tr> <tr><td>1.2-6.0</td><td>same</td><td>same</td></tr> <tr><td>electricity .6</td><td></td><td></td></tr> <tr><td>heat(iv) .4</td><td>same</td><td>same</td></tr> <tr><td>electricity .5-.8</td><td></td><td></td></tr> <tr><td>heat 3-5</td><td>same</td><td>same</td></tr> <tr><td>.35-.7</td><td>.50-.85(v)</td><td>.60-.85(v)</td></tr> </table>	1977	1985	2000	1-5	same	same	3.7-18	same	same	5.3-26	same	same	1.2-6.0	same	same	electricity .6			heat(iv) .4	same	same	electricity .5-.8			heat 3-5	same	same	.35-.7	.50-.85(v)	.60-.85(v)		
	1977	1985	2000																															
1-5	same	same																																
3.7-18	same	same																																
5.3-26	same	same																																
1.2-6.0	same	same																																
electricity .6																																		
heat(iv) .4	same	same																																
electricity .5-.8																																		
heat 3-5	same	same																																
.35-.7	.50-.85(v)	.60-.85(v)																																
UNIT ANNUAL ENERGY OUTPUT: (10 ³ MWh) PRIMARY (10 ¹⁰ Btu) SECONDARY AVERAGE EFFECTIVE CAPACITY FACTOR: RANGE OF CAPACITY FACTORS: EFFICIENCY (BTU OUT/BTU IN):	Depends on prime mover and efficiency of system Oil or gas to coal - no Coal to oil or gas - yes																																	
ECONOMIC	PRIMARY FUEL(S): Oil, gas, coal AMOUNT NEEDED PER UNIT OUTPUT: ALTERNATIVE FUEL(S): Future emphasis on coal IS SYSTEM READILY CONVERTIBLE?																																	
	Can vary widely during day and by season if major loads are residential or commercial. This reduces electrical capacity factor to .60 and heat capacity factor to .4. CONNECTION TO CENTRAL UTILITY: DESIRABLE FOR USER? Yes, since this reduces requirements for backup capacity in total energy system and can significantly increase fuel utilization efficiency by adjusting output to meet heat loads. However, there may be tradeoffs mitigating against such a connection. TECHNICALLY PRACTICAL? Yes																																	
LIMITING FACTORS	CONNECTION TO COMPLEMENTARY SYSTEM (E.G., BATTERIES) DESIRABLE? Perhaps SYSTEM: Use of thermal storage may be desirable to help smooth thermal loads.																																	
	EXTENT OF INDUSTRIAL BASE FOR PRODUCTION AND DISTRIBUTION: Ample capacity for conventional subsystems GEOGRAPHIC LIMITATIONS: No specific limitations, but there is a wide difference in system configurations dependent on climate conditions. ENVIRONMENTAL EFFECTS: Overall environmental effect is positive since less fuel is consumed for the combined power/heat load. Local emission problems may be increased due to operation of power systems on-site. LEGAL, SOCIAL OR INSTITUTIONAL BARRIERS: Institutional barriers associated with utility interface and labor practices. Systems serving buildings under diverse ownership face legal barriers associated with hookup requirements.																																	
COMMENTS	(i) It has been suggested that future total energy systems may use fuel cells, Stirling engines, or organic Rankine cycle engines, or coal-fired combustion turbines or diesel engines. Numerical data on this sheet are for diesels, the currently dominant technology. See Tables 23-4 and 23-5. (ii) Sometimes the "primary" output is heat instead of electricity. (iii) Unless otherwise indicated, excludes large district heating systems which are outside the scope of this report. (iv) About 2/3 of the available heat is utilized. (v) Future technologies. (vi) Includes cost of power unit, heat recovery system, and auxiliary components required of total energy system. Does not include heat distribution system, the cost of which is very application specific. (vii) See Table 23-5. (All O&M costs are assigned to electricity generation.)																																	

CE

CHAPTER 23

TOTAL ENERGY SYSTEMS

Section 23.1: Introduction

Central power generating systems (steam plants, combustion turbines, diesels) convert 20-40% of the energy content of the fuel into power. The remaining 60-80% of the energy is rejected in the condenser and/or exhaust gas streams. A portion of this rejected heat can, in principle, be recaptured and used for a range of space heating and water heating applications. Systems which perform such a dual function (power generation and heating) have been utilized for years under a variety of descriptive names, such as total energy, district heating, and cogeneration. "Total energy" usually refers to the production, on site, of electrical power for large residential, commercial, or institutional building complexes (hospitals, hotels, etc.) by diesel engines or combustion turbines, with the rejected heat being used for space and water heating applications.

In more than 40 cities in the United States, heavily populated downtown areas are serviced by a district heating system where the heat is supplied by a central utility.⁽¹⁾ In some cases, the steam is supplied by back pressure or extraction turbines in central steam power plants operated by the electric utility. Cogeneration* usually refers to the combined generation of power and process heat in large industrial plants, such as paper mills.

Despite the high energy efficiency of total energy systems (as compared to those that generate electric power only), their use has been quite limited and, in fact, has tended to diminish over the last decade. One reason for this has been the increasing efficiency of large central generators which has resulted, until recently, in steadily declining electric power rates. This factor, combined with the high costs of operating and maintaining sophisticated on-site power generating equipment, has tended to put total energy systems at an economic disadvantage.

* Discussed in more detail in Chapter 22.

Furthermore, there are additional economic penalties associated with part load performance of isolated total energy systems. For total energy systems where the primary concern is electric power, the penalties of part load performance can be substantial, especially in the cases of combustion turbines and steam turbines. The part load performance degradation is basically due to the drop in efficiency and hence the increase in fuel consumption per kilowatt hour of electricity generated. Diesel engines have somewhat better part load performance and have often been the choice for applications where cyclic demand variations are expected.

If, on the other hand, the primary purpose of a total energy system is providing heat energy, then the effects of part load performance may not be significant because one way or the other the fuel heat energy is effectively utilized.

The recent rapid increases in the cost of energy delivered by central utility systems have significantly altered the competitive position of total energy systems. As a consequence of the emphasis being placed on conserving energy supplies, the government now supports several programs intended to improve the technology options available for total energy systems and to encourage their extended use.

The Modular Integrated Utility System (MIUS) program,^(2,3) which was started by the Department of Housing and Urban Development (HUD) in 1972, has as its major thrust the development of total energy systems for use in residential/commercial communities. They are based on standard components and a standard modular construction to allow for easy expansion and reduced engineering and design costs. The MIUS programs also include integration of other utility services required by a community (waste disposal, potable water, etc.) into the overall system concept.

The Integrated Community Energy Systems (ICES) program^(4,5) is sponsored by the U.S. Department of Energy (DOE). The goal of this program is to develop total energy systems for communities to support energy conservation and the use of coal as the primary fuel. The ICES program also uses total energy systems in conjunction with the utility

power network to: (a) reduce the need for redundant or excess capacity in the total energy package, (b) provide for a sales outlet for excess electric power produced by the total energy system, and (c) provide the utility with relatively inexpensive distributed power sources which can be used, if needed on an emergency basis.

The combination of changing energy economics, increased R&D in more efficient and reliable equipment, and government participation in demonstration projects, is expected to increase the future use of total energy systems so that they may become a significant factor in the overall energy picture.

Section 23.2: Technical Discussion

A. System Description

The prime mover options most often used to generate electrical power in total energy systems are: steam turbines (Rankine cycle engines), diesel engines, and combustion turbines (Brayton cycle engines). In addition to these conventional prime movers, total energy systems using advanced technologies, such as Stirling engines and fuel cells, are also being developed. The systems using these advanced technologies are not yet commercially available, however. The choice of engine generator systems is influenced by many factors including system size, temperature requirements of heating loads, fuel flexibility requirements, ratio of electrical to thermal demands, initial costs, and operation and maintenance costs.

Schematics of simplified total energy arrangements using the three conventional prime mover options are shown in Figures 23-1, 23-2, and 23-3. In steam turbine systems, hot, high-pressure steam is produced in a boiler and passed through a turbine to produce power. The partially expanded and cooled steam can then be extracted and used for space heating or water heating functions. The heat from this steam can also be transferred in a condenser to a pressurized hot water loop. Usually the steam is used at temperatures in the 212-350°F range to limit pressure levels and to reduce efficiency penalties in the operation of the steam turbine system.

SOURCE: Reference 6.

FIGURE 23-1 TOTAL ENERGY SYSTEM SCHEMATIC USING STEAM TURBINE

SOURCE: Reference 6.

FIGURE 23-2 TOTAL ENERGY SYSTEM SCHEMATIC USING DIESEL ENGINE

SOURCE: Reference 6

FIGURE 23-3 TOTAL ENERGY SYSTEM SCHEMATIC USING COMBUSTION TURBINE

In systems using diesel engines as the prime mover, most (~65%) of the heat is generated in waste heat boilers placed in the hot (600-1000°F) engine exhaust stream. Hot water at lower temperatures can be generated from the engine jacket water cooling systems. With combustion systems, all the heat is generated in heat recovery boilers placed in the engine exhaust.

These options have different efficiency levels for converting thermal energy into power and, therefore, different power-to-heat ratios. These are indicated in Figure 23-4 for a number of systems used or being considered for use in total energy systems. If all of the rejected heat available in a total energy system arrangement based on any of the above technology options could be recovered and utilized, the overall efficiency of energy utilization would be in the 75-85% range. However, such an efficiency level could require a consistent match between the electrical power and thermal energy loads. Where the system output is dictated by the demand for electrical power, this match is usually not the case all year if a major share of the thermal loads is determined by climatic conditions, e.g., space heating and air conditioning. Typical steam load curves for a residential/commercial community are shown in Figure 23-5. The thermal loads vary considerably by season, while the electrical demand remains fairly constant during the year.

One common subsystem in all the total energy systems indicated in Figures 23-1, 23-2, and 23-3 is a heat-actuated cooling machine (typically lithium bromide absorption chillers). The use of absorption cooling helps to even out the thermal load during the year when a major portion of the thermal output of the total energy systems is for space conditioning.

For most community applications there is also a wide daily variation in electrical and thermal loads (as per Figure 23-6). Those daily load variations can lead to additional mismatches between electrical output requirements and thermal needs. Such mismatches which occur on a daily cycle can, however, be somewhat smoothed out by use of thermal storage (either hot water for heating or chilled water for air conditioning).

FIGURE 23-4 WASTE HEAT AVAILABLE FROM TOTAL ENERGY SYSTEM PRIME MOVERS

SOURCE: Reference 9.

FIGURE 23-5 VARIATION IN STEAM DEMAND DURING THE YEAR FOR A TYPICAL COMMUNITY

SOURCE: Reference 9.

FIGURE 23-6 TYPICAL THERMAL MISMATCH BETWEEN HEAT REQUIRED AND RECOVERABLE HEAT FOR A TOTAL ENERGY PLANT OF A RESIDENTIAL COMPLEX IN NORTHERN LATITUDES

As a result of the above considerations, most total energy systems must dissipate excess thermal energy during the course of the year, with the result that net system fuel utilization is usually in the 50-70% range, which is still much better than that of electrical power production alone. One of the goals of the ICES program is to operate the system according to thermal demand and to sell excess electric power produced back to the utilities. A system so designed has the advantage that it can attain very high annual efficiency levels since no thermal energy is ever dissipated. It does, however, require an agreement with the local electric utility to accept excess power from the total energy system, which may not be practical in many cases.

Operational flexibility of these systems is fairly limited. For the conventional installation operated to meet electrical demand, flexibility can be achieved by wasting heat or firing auxiliary boilers. The first option reduces fuel utilization efficiency, the second increases capital costs. These systems have typically been diesel powered partly because diesels exhibit good part load performance, thus permitting some electrical flexibility. Multiple-unit diesel systems are, of course, more flexible than single-unit systems because additional units can be brought on line as needed. For units operated to meet thermal demand, flexibility will be provided by the connection to public utility grids. Equitable allocation of the costs of these widely varying loads is not simple, although the interconnection of many total energy systems will tend to average the load fluctuations somewhat.

B. Advanced Systems

The areas of advanced development for total energy systems include solar-based and coal-fired energy sources, and fuel cells.

- Solar-based Total Energy Systems

The concept of total energy utilization is being extended to combined solar power/heating/cooling systems, such as is indicated in Figure 23-7. These systems are under development at Sandia Laboratories

SOURCE: Reference 10.

FIGURE 23-7 SCHEMATIC DIAGRAM OF A SOLAR TOTAL ENERGY SYSTEM

as part of the DOE solar program.⁽¹⁰⁾ Generally, solar total energy systems use concentrating solar collectors to allow for the operation of heat engine driven generators (usually Rankine cycles). The rejected heat from the heat engine systems is then used for space and water heating functions as with conventional total energy system arrangements. A variation of this approach (Figure 23-8) uses solar energy in conjunction with diesel generators within a total energy arrangement.⁽¹¹⁾ Such a system may have synergistic effects since the heat engine and thermal storage unit can make use of two heat sources (solar and engine exhaust).

- Coal-Fired Total Energy Systems

The decreasing availability of oil and gas provides a strong incentive to develop total energy systems which can use coal as the basic energy source. Of course, coal can be, and is, used to fire large total energy systems using boiler/steam turbine configurations. Present coal-fired systems in smaller sizes typical of total energy systems are, however, often quite inefficient, costly to maintain, and difficult to operate consistent with environmental regulations. Consequently, there is now a significant effort to develop advanced coal-fired systems. One major activity in this field is work at Oak Ridge National Laboratories in support of the MIUS program.⁽¹²⁾ One system under particular consideration as a result of this effort is the use of fluidized-bed reactors providing heat to closed Brayton cycle engines. This system is projected to convert about 30% of the energy into electricity and about 50% into heat which can be used for space and water heating. A primary incentive behind the use of the fluidized-bed combustion is its ability to use a wide variety of coals with little environmental impact. (See Chapter 11.) Argonne National Laboratory has recently started to evaluate the use of Stirling engines in total energy systems, again with particular emphasis on coal-fired systems.⁽¹³⁾ The potential advantages of Stirling engines include potentially very high electric efficiency (35%), low noise levels, good part load performance, and a ready adaptability for using the waste heat dissipated.⁽¹³⁾ (See Chapter 14 for a further discussion of the Stirling Engine.)

SOURCE: Reference 11.

FIGURE 23-8 SCHEMATIC OF A COMBINED SOLAR/CONVENTIONAL TOTAL ENERGY SYSTEM

- Fuel Cells

In recent years, fuel cells have been greatly improved and are under development in sizes up to several megawatts (see Chapter 16) and large enough to be able to make useful contributions to the nation's electricity supply.⁽⁸⁾

The application of fuel cells to total energy systems also results from its efficiency which is not limited by the Carnot cycle efficiency as in the case for heat engines. A recent study⁽¹⁴⁾ shows that fuel cells operating as a source of both heat and electricity can have overall efficiencies in excess of 80%. Furthermore, a fuel cell has nearly constant efficiency from 25 to 100% of its rated power output and hence has an excellent load-following characteristic. (See Chapter 16.)

A major project concerned with the total energy application of fuel cells is presently at the planning stage. It is an extension of the TARGET project (Team to Advance Research for Gas Energy Transformation). The TARGET project was initiated in 1967 by the United Technologies Corporation and a consortium of gas and gas-electric utilities for the development of on-site residential and commercial phosphoric acid fuel cell power plants, utilizing gas (natural or synthetic) as fuel. In 1972 and 1973, more than 60 power plants of 12.5-kW capacity were tested, and in 1975 a 40-kW plant was developed.⁽¹⁵⁾ Now an extension of the TARGET project supported by the Department of Energy and the Gas Research Institute has the objective of testing 50 plants of 40-kW capacity between 1979 and 1981 and a fully commercialized technology by 1982.

C. Applications

To date, the primary applications of total energy systems have been within large buildings or clusters of buildings under the control of a single owner. Typical applications have been in large school buildings, hospitals, apartment complexes, shopping centers, office buildings, and institutional complexes.

In addition, there are more than 40 district heating systems

in the United States serving downtown areas of large cities. These systems, usually operated by the electric utility, often* use back-pressure or extraction steam from a turbine system (Figure 23-1). Although they can be classified as a type of total energy system, large-scale district heating systems are not normally so considered.

Table 23-1 indicates the specifications for several typical total energy systems in the United States and Canada; Table 23-2 lists the location and capacity of the major district heating systems in the United States. As indicated, almost half of all the installed capacity is located in New York City (operated by Consolidated Edison Company).

It should be noted that the present government-sponsored total energy programs (MIUS and ICES) are intended to serve complete communities, or significant portions of complete communities. As such, these systems will often require the laying of pipes for hot water or steam distribution in public streets as is the case with district heating systems (with their associated institutional and cost problems as discussed later). Table 23-3 indicates the specifications for four ICES systems to be connected to the public power network which are now in the design phase.

Section 23.3: Economics Discussion

The energy conservation incentives behind total energy systems have been well known for a long time. Nevertheless, total energy in all its forms has had a very uneven developmental history. This is primarily because, in many situations, the overall costs associated with total energy systems have been higher than the costs for purchasing electricity from the utility and operating conventional fuel-fired heating systems. Several economic factors now tend to favor the introduction of total energy systems. They include the following:

*However, in some cities most of the steam is produced in separate central boilers without any associated electrical power generation.

TABLE 23-1

REPRESENTATIVE TOTAL ENERGY SYSTEMS IN THE UNITED STATES AND CANADA

<u>System Location</u>	<u>Application</u>	<u>Power Source</u>	<u>Total Capacity (MW)</u>
1. Brooklyn Union Gas Co. Rochdale Village, New York	Apartment building and shopping center	2 Steam turbines	15.0
2. Regency Square Jacksonville, Florida	Shopping center	9 Natural gas engines ⁽¹⁾	4.2
3. Park Plaza Little Rock, Arkansas	Shopping center	1 Combustion turbine 2 Natural gas engines ⁽¹⁾	1.2
4. Gulf of Mexico	Oil drilling rigs	Combustion turbines	0.3
5. Hillcrest, Edmonton, Alberta, Canada	Junior high school	2 natural gas engines ⁽¹⁾	0.6
6. Burns Brick Co. Macon, Georgia	Industrial building w/machines, cranes, hoist	Natural gas-fired combustion turbine ⁽¹⁾ Natural gas engine	1.2
7. Engineered Plastics Ltd. Edmonton, Alberta, Canada	Production plant	2 Natural gas engines ⁽¹⁾	0.5
8. Cattle Marketeers, Inc. St. Cloud, Florida	Drying plant	Combustion turbine	0.33
9. Ohio State University Columbus, Ohio	Student residence	4 Natural gas engines ⁽¹⁾	1.8

TABLE 23-1 (Continued)

<u>System Location</u>	<u>Application</u>	<u>Power Source</u>	<u>Total Capacity (MW)</u>
10. Kansas City, Missouri	Apartment blocks	Natural gas engines ⁽¹⁾	1.4
11. Peoria, Illinois	High school	Diesel engines	0.57
12. Wendover, Nevada	Motel	Diesel engines	0.5
13. Anoka, Minnesota	Mill	Diesel engines	0.15
14. Chenoa, Illinois	Manufacturing	Diesel engines	0.28
15. Sheldon, Illinois	Manufacturing	Diesel engines	0.11
16. Galesburg, Illinois	School	Diesel engines	0.25
17. Lake Forest, Illinois	Service station	Diesel engines	0.17
18. Chicago, Illinois	Service center	Diesel engines	0.53
19. New Haven, Missouri	Bottling	Diesel engines	0.25

(1) Modified diesel engines.

SOURCE: References 9 and 16.

TABLE 23-2

DISTRICT HEATING SYSTEMS IN THE UNITED STATES

<u>City</u>	<u>Company Name</u>	Total Steam Delivered (10 ⁶ lb)
New York, NY	Consolidated Edison Co. of N.Y.	41,886
Philadelphia, PA	Philadelphia Electric Co.	8,461
Detroit, MI	Detroit Edison Co.	6,573
Boston, MA	Boston Edison Co.	6,543
Indianapolis, IN	Indianapolis Power & Light Co.	4,864
Rochester, NY	Rochester Gas & Electric Corp.	3,732
Cleveland, OH	Cleveland Elec. Illuminating Co.	2,540
Milwaukee, WI	Wisconsin Electric Power Company	2,499
Baltimore, MD	Baltimore Gas & Electric Co.	2,496
St. Louis, MO	Union Electric Co.	1,929
Dayton, OH	Dayton Power & Light Co.	1,836
Cambridge, MA	Cambridge Steam Corp.	1,644
Denver, CO	Public Service Co. of Colorado	1,459
Pittsburgh, PA	Allegheny County Steam Htg. Co.	1,678
Seattle, WA	Seattle Steam Corp.	1,400
Harrisburg, PA	Pennsylvania Power & Light Co.	1,121
San Francisco, CA	Pacific Gas & Electric Co.	987
Lansing, MI	Board of Water & Light	923
Grand Rapids, MI	Consumers Power Co.	819
Minneapolis, MN	Central Heating Co.	692
Eugene, OR	Eugene Water & Electric Board	629
Akron, OH	Ohio Edison Co.	727
Spokane, WA	Washington Water Power Co.	622
Erie, PA	Pennsylvania Electric Co.	613
Birmingham, AL	Alabama Power Co.	565
St. Paul, MN	Northern States Power Co.	532
Toledo, OH	The Toledo Edison Co.	467
Youngstown, OH	Ohio Edison Co.	494
Scranton, PA	Community Central Energy Corp.	455
Hartford, CT	Hartford Steam Service Co.	371
Rochester, MN	Rochester Public Utilities	287
Nashville, TN	Nashville Thermal Transfer Corp.	207
Salt Lake, UT	Utah Power & Light Co.	221
Concord, NH	Concord Steam Corp.	155
Bronxville, NY	Lawrence Park Heat, Light & Power Co.	194
Piqua, OH	Municipal Power System	142
Springfield, OH	Ohio Edison Co.	128
Southfield, MI	Dayton Hudson Properties	87
Rice Lake, WI	Rice Lake Steam Corp.	66
San Antonio, TX	City Water Board	72

SOURCE: Reference 1 (1975 data).

TABLE 23-3

PROPOSED ICES DEMONSTRATION PROJECTS

<u>Community</u>	<u>Type</u>	<u>Size</u>	<u>On-Site Power Source</u>
Clark University Worcester, MA	Small Campus - Education and Residential Buildings	1 million ft ² 1.5 MWe 20,000 lb/hr steam	Diesel Engines
City of Trenton Trenton, NJ	Downtown Redevelopment - Commercial, Institutional, Residential Buildings	2 million ft ² 10 MWe 120,000 lb/hr steam	Combustion Turbines
Health Education Authority of Louisiana (HEAL) New Orleans, LA	Medical Complex - Hospitals and Health Educational Buildings	3 million ft ² present 7.5 million ft ² ultimate 11.7 MWe 157,000 lb/hr steam	Coal Boilers
University of Minnesota Minneapolis, MN	Large University Campus and Adjacent Hospitals	14 million ft ² 7.5 to 12.5 MWe 300,000 lb/hr steam	Coal Boilers and Solid-Waste Gasifier

SOURCE: Reference 4 .

- Electric utility rates are generally increasing faster than inflation as fuel costs and the costs of new plant construction increase dramatically. This is in contrast to the period from 1950-1965 when utility rates were declining;
- The costs of all fossil fuels are increasing rapidly and their availability (gas and oil) is becoming more questionable. This provides an additional incentive to improve the efficiency of fuel utilization and consider systems with some degree of fuel flexibility;
- The equipment required for total energy systems is improving, partly as a result of government programs;
- A number of government financial incentives (tax credits) reduce the effective cost of total energy systems to their tax-paying owners;
- Electric utilities are showing more flexibility about integrating total energy systems into the electric power network and thereby reducing the need for expensive standby power systems. This is indicated, for example, by the willingness of several major utilities to buy back power from the ICES systems listed in Table 23-3.⁽⁴⁾

Several of the major cost factors associated with the installation and operation of total energy systems are:

- Direct costs of power-generating equipment, heat recovery units, sophisticated electrical switching systems, relatively complex controls, as well as the costs of satisfying environmental regulations;
- Cost of providing the considerable space required for a total energy system (which requires, at least, twice the space of a simple heating unit);
- Costs associated with the skilled manpower needed to keep the equipment functioning under normal operation and to repair equipment as needed; and
- Increased taxes and insurance costs associated with having expensive equipment in-house.

Table 23-4 lists the approximate costs on an installed basis of conventional power units which might be appropriate for use in total energy arrangements. The lowest cost systems are seen to be gas turbines. Counteracting this initial cost advantage is the low thermal efficiency of gas turbines and their present restriction to burn only high priced (and increasingly scarce) fuel forms (natural gas, refined oil products). All costs are for complete engine-generator systems with all controls and switchgear.

For total energy systems serving a single, large building complex, the cost of distributing heat to the loads is generally not significantly different from a conventional system. However, for those systems serving a complete community (or section thereof), such as district heating, there are large additional costs associated with the steam or hot water piping system required to distribute heat from a central location to all the buildings being served. In present district heating arrangements in urban areas, the formidable cost associated with the distribution system is a major impediment to system expansion.

There are many factors affecting the choice of hot water or steam heat distribution systems. The principal advantage of a steam distribution system is that, since return piping is not required* (as opposed to a hot water system where return piping is necessary), the cost of the distribution system is substantially lower. A steam distribution system is more appropriate for applications where a high temperature ($\sim 250^{\circ}\text{F}$) heat source is needed. For long distance heat transport, the hot water system is generally used due to pressure losses associated with steam distribution and because hot water systems can carry more power per unit cross sectional area. European practice, which frequently involves long distance heat transport, tends to hot water distribution; U.S. practice tends to steam distribution. In

*The mass flow rate in low-pressure steam systems tends to be low enough to encourage dumping used condensate into the local sewer system. This practice has encouraged utilities to move to separate boilers for district heating when they replace old cogenerating steam turbine systems; the cost of conditioning make-up water for modern high-temperature turbines is high and wasting the exhaust steam becomes uneconomical.

TABLE 23-4

COST AND PERFORMANCE OF ENGINE/GENERATOR SYSTEMS⁽¹⁾
(in 1977 dollars)

	Unit Cost ⁽²⁾ (1977\$/kW)	Efficiency for Electricity (%)
Diesel ^(3,4) (.5-5MW)	300 - 625	30 - 40
Combustion Turbine (1-20 MW)	250 - 450	20 - 33
Steam Turbines ⁽⁵⁾		
10 MW	400 - 700	17 - 24
50 MW	300 - 500	22 - 30

-
- (1) Installed costs including site preparation, switchgear, etc. The cost of a coal-fired boiler is included for steam turbine stations.
- (2) Includes heat recovery apparatus, but not heat distribution system.
- (3) Derated for continuous operation, and hence cost in \$/kW is slightly higher than that given in Chapter 13. (Turbine system costs are also derated for continuously operating systems.) In this size range, the heat recovery system is approximately 10-15% of the total system cost.⁽¹⁷⁾
- (4) Typical fuel utilization for a diesel total energy plant is as follows: electricity generation - 35% of input energy, available heat - 37%, wasted heat - 28% (10% radiative losses, 18% minimum stack losses to prevent exhaust condensation). As discussed previously, annual average fuel utilization is typically about 60% because of mismatch of the electrical and thermal loads and other inevitable heat losses. If 25% of the input energy is utilized in the heat load, the effective annual heating capacity factor is 25/37 of the electrical capacity factor.
- (5) Simple cycle.

SOURCE: References 9 and 18. References 19, 20, 21, 22, and 23 corroborate these values for a variety of cases including several specific applications.

many cases, familiarity and past practice will be the determining factors in a close trade-off. Distribution losses can range from as little as 5-10% for a compact, well designed and maintained system to 50% in an old, leaky and underutilized district heating system.

The thermal/electrical characteristics associated with total energy systems vary widely, depending on application. Further complicating the economic evaluation of total energy is the sensitivity of the analysis to a wide variety of parameters including:

- interest rates,
- taxes,
- fuel costs (present and projected),
- utility rate structures and utility policies,
- environmental regulations, and
- local codes and labor regulations.

The potential economics of total energy systems is indicated by considering a simplified example where:

- there are no incremental costs associated with the heat distribution system (such as might be the case in a single, large building);
- thermal mismatch is relatively small so that the effective operating efficiency is relatively high;
- power is generated by a diesel-generator system and building thermal needs are provided by a waste heat recovery boiler on the engine exhaust and a water preheater on the cooling jacket;
- space is already available for system installation at no direct additional cost;
- the fuel input required by the heating loads is unaffected; and
- the cost of heating equipment (waste heat boilers, etc.) is approximately the same as conventional equipment to perform the same function.

The above situation is quite beneficial for a total energy installation and, therefore, should indicate the potential economic benefits of total energy in well selected applications.

The economic performance of systems with the basic characteristics indicated above is indicated in Table 23-5 for two capacities, 1 MW and 5 MW. As indicated, the larger system provides power at a cost of about 3.5¢/kWh, while power from the smaller system costs about 4.7¢/kWh. This power cost range is competitive with utility-supplied power in many parts of the country. The costs of Table 23-5 illustrate a common characteristic of total energy systems, namely, that small systems tend to be less economical than larger ones. One reason for this is the relatively high cost of operating personnel, which becomes an increasingly high percentage of overall O&M costs as size decreases.

Although the costs of Table 23-5 are for illustrative purposes only, they also indicate the importance of economic parameters and capacity factor on system economics. In particular, the cost of power from the system is reduced if the capacity factor is increased (making better use of high cost capital equipment) or if annual capital charges can be reduced as a result of reduced interest rates, tax credits, or the use of longer life equipment.

Section 23.4: Limitations

A. Equipment and Fuel Availability

Conventional total energy systems can be implemented using power-generating and heat-transfer equipment of standard design. The only available equipment, however, which can use coal or solid wastes as fuel is based on the boiler-steam turbine system. These systems are readily adaptable only in larger power levels (20 MW+) and are not very efficient within the relatively limited output range of total energy systems (as compared to central utilities). Also, the economical burning of coal in small power plants consistent with environmental regulations can represent a problem. (4,5,24)

As indicated earlier, advanced systems for burning coal (fluidized beds) and for efficiently and reliably converting heat into power (closed

TABLE 23-5

SIMPLIFIED ESTIMATE OF TOTAL ENERGY SYSTEMS ECONOMICS
(in 1977 dollars)

ASSUMPTIONS: Diesel System Capital Cost ⁽¹⁾	\$500/kW @ 5 MW \$600/kW @ 1 MW
Cost of Capital	10%
Misc. Fixed Costs (taxes, insurance, etc.)	4%
Operating Life	25 years
Capacity Factor	0.6
Effective operating efficiency	60%
Fuel Costs ⁽²⁾	\$2.90/10 ⁶ Btu

	<u>ANNUAL COSTS</u>	
	<u>5 MWe</u>	<u>1 MWe</u>
Fixed Charges	\$375,000	\$ 90,000
Fuel Costs	438,700	87,740
Operating and Maintenance Costs ⁽³⁾	<u>108,000</u>	<u>68,000</u>
TOTALS	\$921,700	\$245,740
Annual generation (kWh)	2.63x10 ⁷	5.26x10 ⁶
Cost of power (\$/kWh)	0.035	0.047

- (1) These represent typical costs for installations of these sizes, and correspond to the upper range of capital costs given in Table 23-4.
- (2) See Chapter 1.
- (3) Including labor and materials but excluding fuel. Because electricity generation dominates these O&M costs, they have been allocated entirely to electricity. Parts and lubricants contribute about \$0.0005/kWh to O&M costs. Labor costs, therefore, dominate O&M costs, but these are very variable. Smaller units, up to about 1 MW, are heavily automated; larger units economically employ a supporting crew including a qualified technician/shift supervisor. Outside service and maintenance contracts for the smaller unit typically cost about \$0.008/kWh (See Chapter 13). Some total energy projects have found it necessary to maintain a full two-man crew for three shifts; in this case, the O&M costs for the 1 MWe plant would be considerably higher (a two-man crew at \$12/hr. total pay would cost \$105,000/year).

SOURCE: References 9 and 17.

Brayton cycle engines, Stirling engines) are in various stages of development. However, most of these more advanced systems are not expected to be commercially available for 10 years or more.

B. Environmental Issues

There are several environmental issues associated with total energy systems. Two of the most important are noise and emissions.

- Noise

The operation of all power plants involves some degree of noise generation. This problem is of particular concern for diesel engines. In general, the noise resulting from the on-site power generators can be kept within acceptable limits by proper muffling of engine exhausts and the use of sound-insulated enclosures.

- Emissions

The control of exhaust emissions from total energy systems can often be somewhat more difficult than from conventional boilers if engine generators (diesel engines, gas turbines) are the prime movers. Also the large-scale implementation of total energy systems may require increasing use of coal-fired systems which are more difficult to operate within acceptable environmental limits than oil- or gas-fired systems. In addition, these systems will be located on site, and so emissions will be of concern to the users and the surrounding population. Ambient air quality regulations may affect the nature and operation of the system. In many cases, total energy systems must, therefore, be provided with appropriate emission control equipment, which can add significantly to initial and operational costs.

C. Institutional Issues

Several institutional issues have affected the implementation of total energy systems in the past and still remain serious issues when considering specific applications. These particularly important issues are local codes which often affect labor requirements, the nature of the utility interface, and how power delivery can be guaranteed in a community system.

- Codes and Regulations

Labor can be a major cost factor in the operation of total energy systems. In some cases, the cost of labor is increased by local and state codes and regulations beyond that which may, in fact, be sufficient for reliable operation. For example, the operation of coal-fired steam boiler/generator systems in some locations may require the continuous supervision of skilled labor with a 2nd class fireman's license.⁽²⁵⁾ Similar rules governing the supervision of other forms of on-site generating equipment can significantly increase operational costs.

Some of these codes and regulations may now be unnecessary in the light of improved equipment reliability and automatic safety controls. To the extent that unnecessary codes remain in force, they could impede the implementation of a total energy system.

- Utility Interface

In the past, most electric utilities have opposed total energy systems* lest they would decrease electric energy sales and increase utility load factor problems (in the case of total energy system malfunction).⁽²³⁾ The concerns of some utilities have been manifested in a reluctance to allow total energy systems to connect into the network and, in the case of connection, in levying a very high charge for such a connection. In very few cases have utilities allowed total energy systems to sell electricity back to the utility. These utility interface barriers are being reduced, but still are very important when evaluating total energy system operations.⁽²³⁾

- Load Guarantee

If a total energy system services a single building or building complex, the owner of the total energy system controls the load (and therefore guarantees demand). The situation is quite different for community energy systems where the electrical and thermal loads are associated with a multiplicity of buildings under private (and diverse) ownership.

*Except utility-operated district heating systems.

The high costs associated with heat (steam or hot water) piping systems usually require that a high percentage of the potential loads do, in fact, connect into the heat distribution grid. One example of the effect of market penetration in an urban area on delivered cost of heat is indicated in Figure 23-9. How a high market penetration can be ensured within the existing social framework is a serious problem. This problem is not a new one and has troubled district heating systems in the United States and Europe in the past.

SOURCE: Reference 9.

FIGURE 23-9 TYPICAL RELATIONSHIP BETWEEN DISTRIBUTED HEAT COST AND PERCENTAGE OF AREA MARKET PENETRATION

REFERENCES

1. Energy and Environmental Sciences Division, Argonne National Laboratory. Potential for Scarce-Fuel Savings in the Residential/Commercial Sector through the Application of District Heating Systems. Draft. Prepared for Energy Research and Development Administration, Undated.
2. Leighton, G.S. "The Modular Integrated Utility System - A New Approach to the Supply of Utility Services." Proceedings of the Eighth Intersociety Energy Conversion Engineering Conference, Philadelphia, Pennsylvania, August 13-16, 1973. pp. 648ff.
3. Office of Research and Technology, U.S. Department of Housing and Urban Development. Modular Integrated Utility Systems - Program Description. Washington, D.C., December 1972.
4. Davis, S.A. "An Overview of Grid-Connected Integrated Community Energy Systems (ICES) Demonstration Projects." Preprint prepared for presentation at the Third ERDA Energy Management Symposium, Knoxville, Tennessee, September 19-21, 1977.
5. Kennedy, A.S., et al. Integrated Community Energy System (ICES) Commercialization Case Studies. Vol. 1. Argonne National Laboratory, 1978. NTIS Report No. ANL/ICES-TM-4.
6. Kurtz, N.D. "Total Energy Keynote Address." Proceedings of the Solar Total Energy Symposium, Albuquerque, New Mexico, January 25, 1977. NTIS Report No. SAND77-0029.
7. Arthur D. Little, Inc. Assessments and Recommendations of the Potential for Stirling Engines in Integrated Community Energy Systems Applications. Report prepared for Argonne National Laboratory under Contract No. 89-8421, December 1977.
8. Shields, V.Y., et al. "Application of Fuel Cells with Heat Recovery for Integrated Utility Systems." Proceedings of the Tenth Intersociety Energy Conversion Engineering Conference, Newark, Delaware, August 17-22, 1975. pp. 278ff.
9. Diamant, R.M.E. Total Energy. Oxford, England: Pergamon Press, 1970 (International Series in Heating, Ventilation and Refrigeration, Vol. 6.)
10. Patterson, B. Solar Total Energy Test Facility Project-Semiannual Report, October 1976-March 1977. Sandia Laboratories, August 1977. NTIS Report No. SAND77-0738
11. Arthur D. Little, Inc. Solar Assessment Study in Support of the International Ekistics Program, Phase I Report. Report prepared for Argonne National Laboratory, July 1977. NTIS Report No. ANL/ICES-TM-12.

12. Fraas, A.P. "Small Coal Burning Gas Turbine for Modular Integrated Utility Systems." Proceedings of the Ninth Intersociety Energy Conversion Engineering Conference. San Francisco, California, August 26-30, 1974, pp. 499 ff.
13. Lehrfeld, D., System Analysis Design and Proof-of-Concept Experiment of a Total Energy System. Quarterly Progress Report, August 16, 1976 - November 15, 1976. Report prepared by Philips Laboratories for Energy Research and Development Administration, December 1976. NTIS Report No. COO-2947-2.
14. Mathtec, Inc. An Analysis of the Application of Fuel Cells in Dual Energy Use Systems, Vol. 2. Report prepared for Electric Power Research Institute, February 1979. EPRI Report No. EM-981.
15. United Technologies Corporation. Venture Analysis Case Study for On-Site Fuel Cell Energy Systems. Volume 1. Final Report, FCR-0783. Prepared for U.S. Department of Energy, July 31, 1978.
16. Oil Total Energy. Washington: National Oil Fuel Institute, 1966.
17. Cummins North Atlantic, Inc., Dedham, Massachusetts. Personal communication. September 1979.
18. Independence, Missouri. Grid Connected Integrated Community Energy System. Final Report. Vol. 1 Executive Summary. Report prepared for Energy Research and Development Administration, July 1977. NTIS Report No. COO/4213-1/1.
19. Clark University. A Preliminary Feasibility Study of a Grid-Connected Integrated Community Energy System at Clark University. Vol. 1 Executive Summary. Report prepared for Energy Research and Development Administration, July 1977. NTIS Report No. COO-4211-1/1.
20. Department of Planning and Development, Trenton, New Jersey. Trenton ICES, Vol. 1, Phase 1, Final Report. Report prepared for Energy Research and Development Administration, July 14, 1977, NTIS Report No. COO/4212-1/1
21. DeLaureal Engineers, Inc. Grid-Connected ICES Preliminary Feasibility Analysis and Evaluation. Final Report. Vol. 1, Executive Summary. Report prepared for Energy Research and Development Administration, June 1977. NTIS Report No. COO/2414-1/1.
22. Minnesota University. Grid-Connected Integrated Community Energy System. Executive Summary. Final Report. Phase 1, February 1, 1977-May 31, 1977. Report prepared for Energy Research and Development Administration, June 1977. NTIS Report No. COO/4210-1.

23. Weber, E.R. "On-Site Solar Systems, A Utility Point of View." Proceedings of the Solar Total Energy Symposium, Albuquerque, New Mexico, January 25, 1977. Sandia Laboratories, 1977. NTIS Report No. SAND77-0029.
24. District Heating Working Party of the Combined Heat and Power Group, U.K. Department of Energy. District Heating Combined with Electricity Generation in the United Kingdom. London: H.M. Stationery Office, 1977.
25. Uniform Boiler and Pressure Vessel Laws Society. Synopsis of Boiler and Pressure Vessels, Laws, Rules and Regulations. Hartford, Connecticut: The Society, September 1978.