DOE/mc/21338-T2

PERFORMANCE EVALUATION OF A CERAMIC CROSS-FLOW FILTER
ON A BENCH-SCALE COAL GASIFIER

Westinghouse Principal Investigators
D. F. Ciliberti and T. E. Lippert

Second Quarterly Project Report
January 1, 1985 - March 31, 1985
Contract Number DE-AC21-84MC21338

DOE Project Officer: Randall J. Dellefield
Department of Energy
Morgantown Energy Technology Center
P.O. Box 880
Collins Ferry Road
Morgantown, WV 26505

DOE 7/28/92

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PERFORMANCE EVALUATION OF A CERAMIC CROSS-FLOW FILTER
ON A BENCH-SCALE COAL GASIFIER

DOE/MC/21338--T2

DE92 017660

Westinghouse Principal Investigators
D. F. Ciliberti and T. E. Lippert

Second Quarterly Project Report
January 1, 1985 - March 31, 1985
Contract Number DE-AC21-84MC21338

DOE Project Officer: Randall J. Dellefield
Department of Energy
Morgantown Energy Technology Center
P.O. Box 880
Collins Ferry Road
Morgantown, WV 26505

DISCLAIMER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PATENT STATUS

This technical report is being transmitted in advance of DOE patent clearance and no further dissemination or publication shall be made of the report without prior approval of the DOE Patent Counsel.

TECHNICAL STATUS

This technical report is being transmitted in advance of DOE review and no further dissemination or publication shall be made of the report without prior approval of the DOE Project/Program Manager.

OVERALL PROGRAM OBJECTIVES

The Department of Energy is currently supporting a program that will aid in the development of cross flow filtration technology as applied to combined cycle power generation with coal gasification. The stated overall goal is to gain information on both the operational and economic feasibility of the implementation of cross flow filtration in various gasifier options. Westinghouse has prepared a comprehensive program that will lead directly to these program goals in an efficient manner.

The proposed program is composed of three major technical tasks. Task 1 is directed at the design and actual test of a cross flow filter at a DOE bench scale gasifier. Task 2 is composed of several smaller theoretical and experimental efforts that are intended to firm up areas where engineering and design principles are lacking or considered inadequate. The third task is intended to integrate the results of the first two tasks in a conceptual design and cost analysis such that proper economic perspective for the filter concept can be gained. A brief summary of the approach taken in the technical tasks is presented in the following discussion.

In the conduct of Task 1, we will design, fabricate, install, and operate a cross flow test system at the AGC. The actual test article will incorporate provisions for a scaled down cross flow element that will accommodate all of the gasifier flow. From this element, we will gain information on filtration parameters such as efficiency, pressure drop, and cleanability. The element will be instrumented with high speed differential pressure transducers that will allow us to quantify the pulse jet parameters that are required for successful blow back cleaning. These will subsequently serve as inputs to scaling models for full size module calculations.

In Task 2 we propose to conduct a series of independent tests. The efforts center on the following areas: 1) a task to develop a filter element with improved mounting and delamination properties, 2) a task to refine our model that describes the dynamics of pulse jet cleaning, 3) a task to quantify the dust cake properties of char and sulfur sorbent fines, and 4) a chemical stability test of the cross flow filter in a simulated gasifier environment.

The third technical task will involve the integration of new test data and model refinements into a sound conceptual design for at least three gasifier systems. Westinghouse personnel that have had past and current responsibility for commercial gasification systems design and cost analysis will assume the primary responsibility for this task. We are confident that the approach of coupling a sound scientific data base and scaling methodology with a broad systems understanding and capability will result in a sound conceptual design and costing basis.

PROJECT SUMMARY FOR SECOND QUARTERLY REPORT

TASK 1 - Vessel Design and Testing

Vessel Supply:

During the period from January to March we requested and received quotes from several vendors for the supply of the pressure vessel for housing the filter. With good and responsive cooperation from DOE project personnel we were able to simultaneously reach a final, approved vessel design so that the purchase order for the pressure vessel could be issued by mid-February with a short 5-6 week delivery from a local shop. Designs for all of the vessel internals were completed and fabrication drawings were submitted to in-house shops for fabrication. Many parts have already been delivered with the expectation that all components will be completed by mid April.

Instrumentation and Control:

The data recording and filter control system have been designed, specified and procurement has been carried out. Many components have been delivered. The actual control cabinet has been laid out and individual panels for instrument mounting have been delivered from our shop. Completion of the panel installation and wiring is anticipated by late April or early May.

Operating Procedure:

A preliminary operating procedure document was prepared by Westinghouse and delivered to METC in January. Subsequent to this effort, METC has developed its own preliminary operating procedure for the entire gasifier/filter test system.

This document has been reviewed by Westinghouse and our comments and feedback have been provided back to DOE. The METC preliminary operating procedure document has allowed us to proceed to the second step in evolving a final operating procedure. We are currently attempting to integrate our filter operating procedure into the METC overall plan in such a fashion that our second revision will be a suitable plan for operating the entire test system when configured for the Westinghouse cross flow filter. We anticipate delivery of this procedure to DOE by early May.

TASK 2 - Design Principles

Blow Back System Studies

Modeling:

During this quarter we have completed a short theoretical task in which we attempted to analyze the pulse jet cleaning process at a level where analytical results could be retained, rather than a strictly numerical approach. The purpose of this effort was to help identify important groups of parameters as they relate to the cleaning process. A special effort was made to include the induced flow (or eductor effect) in the process. This effort has led to methods that allow reasonably quick estimates of peak pulse pressure rises, and has identified alternative means of quantifying the eductor effect.

A second effort in the pulse modeling work has been the transfer of a previously developed numerical model from the R&D Center main frame computer to a local IBM-XT. The current system has been made interactive and easier to use as well as inexpensive to run. Efforts are under way to incorporate parts of the analytical model into the microcomputer code and to prepare this code for calibration data from a large scale pulse testing system, that is currently being built.

Experimental:

A full scale cross flow filter module has been designed fabricated and is currently being assembled. The unit is about 13 feet long and is 9 inches by 9 inches in square cross section. Thirty-six porous metal sheets have been mounted on the module to simulate the actual cross flow filter. The module will be instrumented with high speed differential pressure transducers and a microcomputer data acquisition system so that the pulse pressure rise distribution can be studied as a function of many operating parameters. The primary purpose of the unit is to provide a means of calibrating and exercising our numerical model of the pulse jet cleaning process.

Filter Supply:

GTE:

Some initial contractual difficulties were experienced in getting GTE involved in the program. These revolved around GTE's concern about the flow down of conditions from the DOE/Westinghouse contract. These initial contractual problems have been resolved and a well defined, four task scope of work is in place.

GTE has experienced some difficulty in fabricating the cross flow filter bodies that have adequate pore size. Early projections of filler requirements to achieve the nominal 100 micron pore size were inadequate, and the first few firings have yielded bodies which do not have high enough permeability. An additional problem has arisen in their attempt to seal the filter element end opposite the clean air exhaust. The first prototype unit fired had some sealing problems, and subsequent batches have been even worse. GTE is currently rethinking the sealing method and will probably elect to take an entirely different approach.

The bottom line of these eventualities is that we do not have any elements for test yet, and do not expect any before mid May at the earliest. This of course seriously jeopardizes GTE's chance of being included in the METC test program.

Coors:

Early purchasing difficulties between Westinghouse and Coors precluded an early start on the fabrication of flanged filters by Coors. This caused some scheduling problems with the commercial plate presses that are used to form the green plates which are eventually machined into the filter layer shapes, and subsequently laid up in the form of the cross flow geometry. Fortunately several pressed plates were discovered from the previous Westinghouse/DOE cross flow filter program so a bottleneck in the manufacturing process was avoided. Unfortunately, the first two elements fabricated, were ruined when a temperature excursion occurred in the firing process. A second pair of elements has been prepared and should be shipped by the end of April, however, this leaves very little, if any, time for pre-METC testing of the new flanged designs.

QUARTERLY REPORT FOR JANUARY TO MARCH 1985

TASK 1 - Vessel Design and Testing

Vessel Supply:

During the month of January we received quotes from four potential suppliers of the filter housing pressure vessel. These quotes varied quite widely, ranging from roughly \$7,000 to \$14,000 with delivery times on the order of 6 to 10 weeks. It appeared that local supply of the vessel will be no problem. While we were awaiting preliminary review of the vessel design by DOE safety personnel, Westinghouse negotiated a purchase agreement with a local vendor for the supply of the filter pressure vessel. A very favorable delivery date of 5-6 weeks was obtained and we anticipate delivery in the first week of April. DOE safety personnel were helpful in expediting this process by reviewing our design drawings and providing timely feedback. We have maintained follow-up contact with Reynolds Mfg. Co. (the fabricator) and at this point in time it appears delivery will occur on schedule.

Vessel Internals:

The design of the vessel internals was begun in January under the assumption that no major changes in vessel design will be requested by DOE. This effort included the design of the vessel liners, insulation system, internal heaters, tube sheet, and filter mounting assembly. Design of the mounting assembly has been relatively difficult since we plan to be able to accommodate two different types of filters, neither of which has been firmly designed.

We have elected to design the system with fibrous blanket type insulation and liners rather than using a cast refractory system. We have used such systems in the past, and have found the added flexibility of this design to be valuable. An additional benefit of the blanket insulation system is the very low heat loss that can be achieved with even a modest thickness of insulation.

The vessel heating system chosen after consultation with Chromalox design personnel. It will consist of three sets of tubular heaters, each set containing three 40 inch long heaters (TRI-4045 Inconel sheath). Each set of three heaters are to be connected in a Wie type connection. When powered by 208, 3 phase electrical hook up, each set will produce about 1.25 kw.

Since there had been some differences of opinion on the estimate of power requirements we prepared a short computer program to estimate the heat loss from the cylindrical vessel surface. Estimates from this work indicated heat losses of only about 1.2 kw, so we feel that adequate margin has been incorporated into our design. This calculation has been appended to this report. Also attached are an assembly drawing of the vessel and internals, as well as detailed drawings of the internals.

The current status of this effort is that the design of vessel internals has been completed and the drawings have been submitted to in-house shops for fabrication. Many parts are finished and delivered, with the rest due out of the shop by early April.

Instrumentation:

The filter instrumentation and control system has been specified and all hardware has been ordered and received. This system will display and record the filter

differential pressure, temperature and flow. Provisions have also been made to monitor and display up to 28 other various temperatures, and control the filter blow back system from the panel. The control panel will also be equipped with a visual and sound alarm for detection of a blown rupture disk. At this point in time the control rack panels have been designed, punched out and are ready for mounting of the various instruments. Scotch Cal labeling decals have been designed and are currently in graphic arts being prepared. We anticipate the completion of the control panel by mid May.

Operating Procedure Document:

Another task associated with design and specification of the testing equipment was completed in January when Westinghouse submitted an initial operating procedure document for the cross flow test program. Since the Westinghouse supplied system will have to be integrated into the DOE system it is to be expected that this document will evolve iteratively. A copy of this preliminary procedure is attached to this report. In late February DOE provided us with their preliminary operating procedure for the entire gasifier/filter test system. We have reviewed this document, and provided suggestions and feedback to DOE personnel. Additionally, a meeting of Westinghouse and DOE project personnel was held in early March at METC to review the Westinghouse operating and safety procedures for the test program, as well as DOE's. These efforts have been integrated into the formulation of a second revision of the Westinghouse Operating Procedure Document. This document is currently being prepared and will be submitted to DOE for review by late April or early May.

TASK 2 - Design Principles

Blow Back System Studies

Modeling:

Personnel from the R&D Center Fluid Dynamics Department completed a brief analysis of the blow back process for the cross flow system in January. The analysis we requested was to include pulse jet entrainment effects. An attempt was made to keep the analysis simple enough such that important dimensionless groups and parameters could be identified. The subsequent report details the assumptions and major conclusions, as well as some preliminary calculations. Details of the analysis and calculations are included in the attachment to this report. It should be noted that this analysis stops short of an actual solution of the pressure and temperature equations for the filter system, however, it does provide important insights to important time constants and groups of parameters, as well as a means of making quick estimates of final or maximum pressure pulse pressure rises in the filter plenum.

In February work was begun on the task of updating the previously developed numerical pulse jet cleaning model in order to reflect new insights gained from the recent analytical modeling effort. We are hopeful that new expressions for entrained flow (or the eductor effect) can be incorporated into the working numerical model. In addition, work has begun in the transfer of the numerical model code from the R&D Center mainframe to our IBM PC-XT. We believe this effort will make it easier and less expensive to work on the model in the future, since the code has been made to operate in an interactive mode and since the microcomputer usage time is essentially free.

At this point, the status of the modeling work is such that we are ready to begin calibrating with the results from planned experimental pulse rise measurements.

Large Scale Blow Back Experiments:

The R&D personnel who will actually conduct the large scale pulse experiments were identified in January and were brought up to speed on the project task goals. Pulse characterization equipment was identified and ordered. This equipment consisted of a set of high speed differential pressure transducers with which we intend to characterize pulse pressure rises in a full scale cross flow filter module. The primary purpose of this effort is to provide scaling of calibration data for the numerical model of the pulse jet cleaning process. A preliminary design basis for the large scale pulse manifold was established and linear flow resistors to mimic the cross flow elements were specified. The final designs for the test system were sent to in-house shops in February.

The set of shop sketches are shown in Figures 1 and 2. Figure 3 presents a sketch of the test system as it is to be laid out upon completion. The full scale manifold to be used for actual pulse jet cleaning studies, will be 9" x 9" by 12 ft long. It will be composed of three 4 ft sections each equipped with 12 filters, 3 to a side. The shop sketches have been discussed with the in-house sheet metal shop and they are proceeding with fabrication.

The porous metal sheet that will be mounted on the plenum to mimic the cross flow filter has been identified and ordered. The actual material ordered from Mott Metallurgical Corp. is a porous 40 micron stainless steel sheet which is 0.078 inches thick. This material has been determined to have approximately the same flow

8B30-XFLOW-01 E.E. Smeltzer x2240
 All Material - Carbon Steel

Cold Flow Filter Test Module

2/25/85
 EES

Figure 1 - Pulse Jet Cleaning Plenum Section

Cold Flow Filter Test Module

Quantity Needed: 3

All sealing surfaces to be provided with $\frac{1}{8}"$ Neoprene gaskets and light bead of RTV Silicone sealant.

Machine screw threads to be sealed with thread dope.

Figure 2 - One of 3 Sections of Pulse Jet Plenum Assembly

2/25/85
EES

Figure 3 - Cleaning Pulse Test System for Full Scale Cross Flow Filter Module

characteristics as the cross flow filter when compensation for filter area has been made. Additionally, sheets of porous polypropylene have been ordered so that the effect of various filter resistances can be examined by sandwiching the porous metal and plastic sheets.

A final activity in this area has been the assembly of the data acquisition system for the pulse pressure rise experiments. We intend to use a system based on a microcomputer with an analog to digital converter system to rapidly read the pulse transducers and store the data on floppy disks for subsequent analysis, graphing and manipulation.

The current status of the pulse testing is that all of the hardware has been fabricated and delivered. Assembly of the system has been started and we plan to start testing by mid April and finish by early May.

Filter Supply

GTE:

GTE Sylvania proceeded with initial efforts on the project in spite of some difficulty in the contractual process. In January they fabricated a test system for the determination of pore size by the bubble pressure test method. They also fabricated a cross flow filter block from their standard heat exchanger materials to confirm their ability to fabricate ceramic bodies of our design. They tested their standard heat exchanger material for porosity in order to establish a reference point. GTE has plans to formulate up to seven additional mixes in order to explore a whole range of porosities. GTE has fabricated the prototype 6" x 6" x 2" cross flow filter from their standard heat exchanger material in order to obtain experience in the fabrication of this size element, and to

explore methods of sealing the face opposite the clean gas exhaust. The first block has been shipped to Westinghouse and has been found to have excellent layer to layer bonding, but very poor adhesion of the plate that is intended to seal the back end of the element. Figure 4 presents a photo of this element.

In the period between mid January and March GTE fabricated two additional sets of blocks. Each time improvement was made on achieving the nominal 100 micron pore size, however, the back plate delamination problem became worse. We anticipate that GTE will attempt an entirely different approach to the end sealing problem in their next attempt to make useful filters.

We have experienced some contractual difficulties with GTE. These have resulted from problems with the manner in which Westinghouse's purchasing department has interfaced with GTE's contracts personnel, concerning the flowdown conditions from the prime DOE/Westinghouse contract. I believe that the situation has been resolved with an agreement to proceed with a purchase order approach, wherein GTE will bill Westinghouse upon completion of each of the four well defined tasks described below.

GTE will supply components and/or appropriate documentation to satisfy the requirements of the following four tasks. At the completion of each task, GTE will invoice Westinghouse.

Item 1. TASK 1 - Fabricate and deliver prototype geometry. 6" x 6" x 2" to determine the feasibility that filter element geometric fabrication capability exists. Unit will be fabricated with GTE current recuperator material - MAS-8400. Westinghouse will make recommendations concerning configuration at this time.

Figure 4 - Photo of GTE Prototype Cross Flow Filter Showing Back Wall Sealing Problem

Item 2. TASK 2 - Delivery of test results confirming that permeability of the ceramic developed by GTE meets the specification delivered to GTE. (i.e., pore size/100 micron/-25) material designation will be PMAS-8400.

Item 3. TASK 3 - Delivery of prototype unit of a modified ceramic material - PMAS-8400. Unit size will be 6" x 6" x 2" in the approved configuration determined in Task 1 by March 15, 1985.

Item 4. Delivery of 10 elements with size ranging from 6" x 6" x 2" to 12" x 12" x 4" to Westinghouse within four (4) weeks of Task 3.

The tasks to be performed by GTE will be done on a best efforts basis, and it is understood that specific goals of each task must be met prior to proceeding to the subsequent task. Westinghouse will however, pay GTE in full for any task that they direct GTE to commence activity on after GTE provides to Westinghouse a report detailing the problems encountered and recommendations. Details of the report will not include any proprietary information but would be of sufficient enough detail to establish that a "best effort" was in fact, made to fulfill the objectives of the specific task. Any inventions developed under this program by GTE are the property of GTE.

Coors

A purchasing difficulty of another nature has also hindered efforts to get the Coors effort under way. A purchase order given to NTD purchasing in early December was finally placed in mid January, however, it was not received by the appropriate personnel at Coors by the end of January so a new order was reissued. Since the initial

Coors effort requires some fairly costly starting materials formulation and set-up of the numerically controlled milling machines, they elected not to begin work until a valid purchase order was in hand. This delay could have seriously impacted Coor's ability to supply test elements in a time frame consistent with our test schedule, however, personnel at Coors discovered several pressed plates of the "green" ceramic starting material that had been used in the most recent Westinghouse work. This has saved substantial time in the manufacturing and delivery process. The numerical milling machine code has been developed and the first two flanged test elements were fabricated and fired in early April. Unfortunately an uncontrolled temperature excursion occurred during the firing causing both the initial bodies to slump and be ruined. A second pair of test elements is to be machined and Coors indicates a late April delivery is possible.

The current status of the filter supply task is as follows:

- o To date we have received no working filter elements from either supplier.
- o We don't anticipate any test elements before late April or early May.
- o GTE is experiencing some unexpected difficulties in fabricating the elements.

The implications of this situation are that we will likely have little or no high temperature and pressure element test time prior to installation at METC. We are uneasy about this situation since we are attempting new mounting and sealing techniques in addition to new filter elements.

ATTACHMENT 1

**CURRENT VESSEL LAYOUT DRAWING AND DETAILS
OF SYSTEM INTERNALS**

Washington Electric Corp. (R)
 INDUSTRIAL COIL GAS CROSS FLOW
 FILTER HOUSING
 14
 NEW 423
 2D27221
 1

TITLE		CROSS FLOW PUMP VESSEL	
DRAWING		LINER DET & WELDMENT	
DWG 7201C15		REV	
ITEM	NOTE	PLANT NAME	DATE
01	TUBE	7.62 O.D. 2.000 I.D. X 1.625 WALL SST 304	9/11/03
02	COVER	12.25 SQ. O.D. 1.625 THK SST SN TYP 304	9306-0101
03	TOP LINER	38.00 X 28.00 I.F. 1.625 THK SST SN TYP 304	9306-0101
04	BOSS	75 O.D. 1.25 DIA SST TYP 304	7009-0101
		MATERIAL SPECIFICATION OR REF DWG	DATE
		W.R.P.D. 517.4.3	
		PROJECT NO.	DATE
		LINE NO.	
		01	
		02	
		03	
		04	
		05

[illegible]

Technical drawing of Section B-B of a Heliarco component. The drawing shows a cross-section of a long cylindrical part with various features and dimensions.

- Overall Length:** 17.88
- Section Line:** SECTION B-B GROUP # 2
- Callout 05:** Points to a feature on the main body.
- Callout 06:** Points to a circular feature at the end.
- Dimensions:**
 - .500 R IF-06
 - .212
 - DIA
 - 1.25 STK
 - 10.88
 - .50
 - .875 DIA
 - $T=.005$
 - 1.005 DIA STK
 - HELIARCO
 - DIA 1.000 STK

26

TITLE		CROSS REFERENCE		REV	
DWG 7201023		FILTER MTG BOX DET		REV	
ITEM	NOTE	PART NAME	QTY	UNIT	REMARKS
01		CL AMP	1	EA	
02		LOCKING FLANGE	1	EA	

D	903321	1																																		
IT	CHANGE																																			
<table border="1"> <tr> <th colspan="3">TOLERANCES</th> </tr> <tr> <th colspan="3">UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <th>F. IN. DEC.</th> <th>F. IN. DEC.</th> <th>ANGLES</th> </tr> <tr> <td>± .02</td> <td>± .009</td> <td>± .40°</td> </tr> </table>			TOLERANCES			UNLESS OTHERWISE SPECIFIED			F. IN. DEC.	F. IN. DEC.	ANGLES	± .02	± .009	± .40°																						
TOLERANCES																																				
UNLESS OTHERWISE SPECIFIED																																				
F. IN. DEC.	F. IN. DEC.	ANGLES																																		
± .02	± .009	± .40°																																		
FINISH TO BE ✓ UNLESS OTHERWISE SPECIFIED																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr> <tr> <td>GROUND</td> <td></td> </tr> <tr> <td>GRIND</td> <td></td> </tr> <tr> <td>DRILL</td> <td></td> </tr> <tr> <td>TURN</td> <td></td> </tr> <tr> <td>PLANAR</td> <td></td> </tr> <tr> <td>SPINDLE</td> <td></td> </tr> <tr> <td>WHEEL</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> <tr> <td>FLAT</td> <td></td> </tr> <tr> <td>CONCAVE</td> <td></td> </tr> <tr> <td>CONVEX</td> <td></td> </tr> <tr> <td>ROUND</td> <td></td> </tr> </table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓	GROUND		GRIND		DRILL		TURN		PLANAR		SPINDLE		WHEEL		FLAT		CONCAVE		CONVEX		ROUND		FLAT		CONCAVE		CONVEX		ROUND	
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓																																			
GROUND																																				
GRIND																																				
DRILL																																				
TURN																																				
PLANAR																																				
SPINDLE																																				
WHEEL																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
FLAT																																				
CONCAVE																																				
CONVEX																																				
ROUND																																				
<table border="1"> <tr> <th>FINISH TO BE</th> <th>UNLESS OTHERWISE SPECIFIED</th> </tr> <tr> <td>AS FURNISHED</td> <td>✓</td> </tr></table>			FINISH TO BE	UNLESS OTHERWISE SPECIFIED	AS FURNISHED	✓																														
FINISH TO BE	UNLESS OTHERWISE SPECIFIED																																			
AS FURNISHED	✓

LINE			ITEM	QTY	UNIT	PRICE	TOTAL	TAX	NET	GROSS
01	1	1000	1000	1	EA	1000.00	1000.00	0.00	1000.00	1000.00
02	2	2000	2000	2	EA	2000.00	4000.00	0.00	4000.00	4000.00
03	3	3000	3000	3	EA	3000.00	9000.00	0.00	9000.00	9000.00
04	4	4000	4000	4	EA	4000.00	16000.00	0.00	16000.00	16000.00
05	5	5000	5000	5	EA	5000.00	25000.00	0.00	25000.00	25000.00
06	6	6000	6000	6	EA	6000.00	36000.00	0.00	36000.00	36000.00
07	7	7000	7000	7	EA	7000.00	49000.00	0.00	49000.00	49000.00
08	8	8000	8000	8	EA	8000.00	64000.00	0.00	64000.00	64000.00
09	9	9000	9000	9	EA	9000.00	81000.00	0.00	81000.00	81000.00
10	10	10000	10000	10	EA	10000.00	100000.00	0.00	100000.00	100000.00
11	11	11000	11000	11	EA	11000.00	121000.00	0.00	121000.00	121000.00
12	12	12000	12000	12	EA	12000.00	144000.00	0.00	144000.00	144000.00
13	13	13000	13000	13	EA	13000.00	169000.00	0.00	169000.00	169000.00
14	14	14000	14000	14	EA	14000.00	196000.00	0.00	196000.00	196000.00
15	15	15000	15000	15	EA	15000.00	225000.00	0.00	225000.00	225000.00
16	16	16000	16000	16	EA	16000.00	256000.00	0.00	256000.00	256000.00
17	17	17000	17000	17	EA	17000.00	289000.00	0.00	289000.00	289000.00
18	18	18000	18000	18	EA	18000.00	324000.00	0.00	324000.00	324000.00
19	19	19000	19000	19	EA	19000.00	361000.00	0.00	361000.00	361000.00
20	20	20000	20000	20	EA	20000.00	400000.00	0.00	400000.00	400000.00
21	21	21000	21000	21	EA	21000.00	441000.00	0.00	441000.00	441000.00
22	22	22000	22000	22	EA	22000.00	484000.00	0.00	484000.00	484000.00
23	23	23000	23000	23	EA	23000.00	529000.00	0.00	529000.00	529000.00
24	24	24000	24000	24	EA	24000.00	576000.00	0.00	576000.00	576000.00
25	25	25000	25000	25	EA	25000.00	625000.00	0.00	625000.00	625000.00
26	26	26000	26000	26	EA	26000.00	676000.00	0.00	676000.00	676000.00
27	27	27000	27000	27	EA	27000.00	729000.00	0.00	729000.00	729000.00
28	28	28000	28000	28	EA	28000.00	784000.00	0.00	784000.00	784000.00
29	29	29000	29000	29	EA	29000.00	841000.00	0.00	841000.00	841000.00
30	30	30000	30000	30	EA	30000.00	900000.00	0.00	900000.00	900000.00
31	31	31000	31000	31	EA	31000.00	961000.00	0.00	961000.00	961000.00
32	32	32000	32000	32	EA	32000.00	1024000.00	0.00	1024000.00	1024000.00
33	33	33000	33000	33	EA	33000.00	1089000.00	0.00	1089000.00	1089000.00
34	34	34000	34000	34	EA	34000.00	1156000.00	0.00	1156000.00	1156000.00
35	35	35000	35000	35	EA	35000.00	1225000.00	0.00	1225000.00	1225000.00
36	36	36000	36000	36	EA	36000.00	1296000.00	0.00	1296000.00	1296000.00
37	37	37000	37000	37	EA	37000.00	1369000.00	0.00	1369000.00	1369000.00
38	38	38000	38000	38	EA	38000.00	1444000.00	0.00	1444000.00	1444000.00
39	39	39000	39000	39	EA	39000.00	1521000.00	0.00	1521000.00	1521000.00
40	40	40000	40000	40	EA	40000.00	1600000.00	0.00	1600000.00	1600000.00
41	41	41000	41000	41	EA	41000.00	1681000.00	0.00	1681000.00	1681000.00
42	42	42000	42000	42	EA	42000.00	1764000.00	0.00	1764000.00	1764000.00
43	43	43000	43000	43	EA	43000.00	1849000.00	0.00	1849000.00	1849000.00
44	44	44000	44000	44	EA	44000.00	1936000.00	0.00	1936000.00	1936000.00
45	45	45000	45000	45	EA	45000.00	2025000.00	0.00	2025000.00	2025000.00
46	46	46000	46000	46	EA	46000.00	2116000.00	0.00	2116000.00	2116000.00
47	47	47000	47000	47	EA	47000.00	2209000.00	0.00	2209000.00	2209000.00
48	48	48000	48000	48	EA	48000.00	2304000.00	0.00	2304000.00	2304000.00
49	49	49000	49000	49	EA	49000.00	2401000.00	0.00	2401000.00	2401000.00
50	50	50000	50000	50	EA	50000.00	2500000.00	0.00	2500000.00	2500000.00
51	51	51000	51000	51	EA	51000.00	2601000.00	0.00	2601000.00	2601000.00
52	52	52000	52000	52	EA	52000.00	2704000.00	0.00	2704000.00	2704000.00
53	53	53000	53000	53	EA	53000.00	2809000.00	0.00	2809000.00	2809000.00
54	54	54000	54000	54	EA	54000.00	2916000.00	0.00	2916000.00	2916000.00
55	55	55000	55000	55	EA	55000.00	3025000.00	0.00	3025000.00	3025000.00
56	56	56000	56000	56	EA	56000.00	3136000.00	0.00	3136000.00	3136000.00
57	57	57000	57000	57	EA	57000.00	3249000.00	0.00	3249000.00	3249000.00
58	58	58000	58000	58	EA	58000.00	3364000.00	0.00	3364000.00	3364000.00
59	59	59000	59000	59	EA	59000.00	3481000.00	0.00	3481000.00	3481000.00
60	60	60000	60000	60	EA	60000.00	3600000.00	0.00	3600000.00	3600000.00
61	61	61000	61000	61	EA	61000.00	3721000.00	0.00	3721000.00	3721000.00
62	62	62000	62000	62	EA	62000.00	3844000.00	0.00	3844000.00	3844000.00
63	63	63000	63000	63	EA	63000.00	3969000.00	0.00	3969000.00	3969000.00
64	64	64000	64000	64	EA	64000.00	4096000.00	0.00	4096000.00	4096000.00
65	65	65000	65000	65	EA	65000.00	4225000.00	0.00	4225000.00	4225000.00
66	66	66000	66000	66	EA	66000.00	4356000.00	0.00	4356000.00	4356000.00
67	67	67000	67000	67	EA	67000.00	4489000.00	0.00	4489000.00	4489000.00
68	68	68000	68000	68	EA	68000.00	4624000.00	0.00	4624000.00	4624000.00
69	69	69000	69000	69	EA	69000.00	4761000.00	0.00	4761000.00	4761000.00
70	70	70000	70000	70	EA	70000.00	4900000.00	0.00	4900000.00	4900000.00
71	71	71000	71000	71	EA	71000.00	5041000.00	0.00	5041000.00	5041000.00
72	72	72000	72000	72	EA	72000.00	5184000.00	0.00	5184000.00	5184000.00
73	73	73000	73000	73	EA	73000.00	5329000.00	0.00	5329000.00	5329000.00
74	74	74000	74000	74	EA	74000.00	5476000.00	0.00	5476000.00	5476000.00
75	75	75000	75000	75	EA	75000.00	5625000.00	0.00	5625000.00	5625000.00
76	76	76000	76000	76	EA	76000.00	5776000.00	0.00	5776000.00	5776000.00
77	77	77000	77000	77	EA	77000.00	5929000.00	0.00	5929000.00	5929000.00
78	78	78000	78000	78	EA	78000.00	6084000.00	0.00	6084000.00	6084000.00
79	79	79000	79000	79	EA	79000.00	6241000.00	0.00	6241000.00	6241000.00
80	80	80000	80000	80	EA	80000.00	6400000.00	0.00	6400000.00	6400000.00
81	81	81000	81000	81	EA	81000.00	6561000.00	0.00	6561000.00	6561000.00
82	82	82000	82000	82	EA	82000.00	6724000.00	0.00	6724000.00	6724000.00
83	83	83000	83000	83	EA	83000.00	6889000.00	0.00	6889000.00	6889000.00
84	84	84000	84000	84	EA	84000.00	7056000.00	0.00	7056000.00	7056000.00
85	85	85000	85000	85	EA	85000.00	7225000.00	0.00	7225000.00	7225000.00
86	86	86000	86000	86	EA	86000.00	7396000.00	0.00	7396000.00	7396000.00
87	87	87000	87000	87	EA	87000.00	7569000.00	0.00	7569000.00	7569000.00
88	88	88000	88000	88	EA	88000.00	7744000.00	0.00	7744000.00	7744000.00
89	89	89000	89000	89	EA	89000.00	7921000.00	0.00	7921000.00	7921000.00
90	90	90000	90000	90	EA	90000.00	8100000.00	0.00	8100000.00	8100000.00
91	91	91000	91000	91	EA	91000.00	8281000.00	0.00	8281000.00	8281000.00
92	92	92000	92000	92	EA	92000.00	8464000.00	0.00	8464000.00	8464000.00
93	93	93000	93000	93	EA	93000.00	8649000.00	0.00	8649000.00	8649000.00
94	94	94000	94000	94	EA	94000.00	8836000.00	0.00	8836000.00	8836000.00
95	95	95000	95000	95	EA	95000.00	9025000.00	0.00	9025000.00	9025000.00
96	96	96000	96000	96	EA	96000.00	9216000.00	0.00	9216000.00	9216000.00
97	97	97000	97000	97	EA	97000.00	9409000.00	0.00	9409000.00	9409000.00
98	98	98000	98000	98	EA	98000.00	9604000.00	0.00	9604000.00	9604000.00
99	99	99000	99000	99	EA	99000.00	9801000.00	0.00	9801000.00	9801000.00
100	100	100000	100000	100	EA	100000.00	10000000.00	0.00	10000000.00	10000000.00
101	101	101000	101000	101	EA	101000.00	10201000.00	0.00	10201000.00	10201000.00
102	102	102000	102000	102	EA	102000.00	10404000.00	0.00	10404000.00	10404000.00
103	103	103000	103000	103	EA	103000.00	10609000.00	0.00	10609000.00	10609000.00
104	104	104000	104000	104	EA	104000.00	10816000.00	0.00	10816000.00	10816000.00
105	105	105000	105000	105	EA	105000.00	11025000.00	0.00	11025000.00	11025000.00
106	106	106000	106000	106						

NOTE
A - SUPPLIED BY ENGR.

903321		1
CHANGE		
2D27241 WESTINGHOUSE Electric Corporation THIS CROSS FLOW FILTER VESSEL FILTER NUMBER AND DET & WELDMENT 2D27240

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

ATTACHMENT 2

**PRELIMINARY OPERATING PROCEDURE FOR
WESTINGHOUSE CROSS FLOW FILTER**

**PRELIMINARY OPERATING PROCEDURE FOR
WESTINGHOUSE CROSS FLOW FILTER**

**REVISION 1
JANUARY 1985**

Prepared for

**U. S. Department of Energy
Under Contract DE-AC21-84MC21338
Morgantown Energy Technology Center
P.O. Box 880
Collins Ferry Road
Morgantown, WV 26505**

1) Introduction and Overview

The Department of Energy has undertaken several experimental programs aimed at the development of hot gas cleaning technologies for application in combined cycle power generation for fluid bed coal gasification. Westinghouse has been contracted to design, fabricate and operate a bench scale cross flow filter unit at the Morgantown Energy Technology Center's advanced gasification test facility.

This document is intended to indicate the general operating procedures that are anticipated for the Westinghouse cross flow filter unit that will be tested. It should be noted that this test module will be operated as a single component of the overall AGC gasification system and that some iterative efforts between Westinghouse and DOE procedures will be required before the test unit can effectively be integrated into the overall system operating procedure document or program.

The following presents a very brief summary of the manner in which we intend to operate the crossflow filter system. Subsequent sections present the details of start up, steady operation and both normal and emergency shut down as best we know them at this point in time.

With reference to Figure 1, (the pressure vessel and internal schematic) the filter operates in the following fashion:

Dusty gas enters the filter pressure vessel through the inlet nozzle and is diffused by impact of the inlet stream on the back of the cross flow filter mounting assembly.

Dusty gas then enters both exposed faces of the cross flow filter by flowing into the body of the element through the roughly $1/4 \times 1/2$ inch through channels (see Figure 2). Gas then permeates the porous ceramic floors and ceilings of the filter and finds itself in channels that are oriented perpendicularly to the inlet channels. These channels flow directly into the clean gas outlet plenum. The filtered gas then flows upward through the tube sheet and exits the pressure vessel into the temperature conditioning, sampling and flow control systems.

As dust accumulates within the filter the resistance to flow increased and the filter pressure drop rises to a predetermined trigger pressure differential, (typically 10-30 in Wg).

Fig. 2 —Cross-flow ceramic membrane filter

At this point the filter by-pass valve is opened to momentarily provide a path for flow around filter system. Then a high pressure pulse is administered to the clean side of the filter by momentarily opening the pulse cleaning solenoid valve which is connected by 3/8 inch tube to a high pressure N2 supply. For about 0.1 to 0.3 seconds this pulse raises the clean side pressure of the filter to a pressure 1-5 psi above the dirty side. This causes flow to occur in the reverse direction through the filter.

This brief reverse flow causes dust to be expelled from the filter in large lumps which then fall to the dust hopper. The system by-pass valve is immediately short, thereby causing all flow to again pass through the filter, and the next filtration cycle is underway.

The primary parameters to be monitored during the test program are the filter pressure drop as a function of time for a given dust loading and gas flow, the ease with which the filter is cleaned or regenerated by pulse jet cleaning and finally the efficiency with which the filter removes particulates from the stream.

2) Normal Start Up

2.1) Prior to starting the system a check of all valves should be made to insure that all valves associated with operation and control of the filter system are in their correct initial position. Table I presents a list of filter system valves and their correct initial positions. During this checkout each valve should be exercised to insure proper working order. With reference to Figure 3:

2.2) Start cooling water to heat exchangers (BV3 and BV4)

2.3) Open flow path for nitrogen (BV5 and set pressure and flow controls to purge conditions ($P = 0$ psig, flow = 300 scfh)

2.4) Open N2 supply (HCV2) and allow system to purge for 10 minutes.

2.5) Control PCV1 to bring system to leak test pressures in 50 psig increments up to the planned operating pressure. Test equipment flanges and connections are to be leak tested at these 50 psi increments and any appropriate corrective measures are to be taken. During this time filter system flow and pressure instrumentation should be checked for proper operation.

2.6) System heat up is achieved by bringing the DOE supplied gas heater on line. At the same time the internal vessel heaters should be energized and controlled to match the vessel inlet temperature provided by the DOE gas

Table 1

VALVE POSITION TABLE FOR WESTINGHOUSE CROSS FLOW FILTER SYSTEM

Valve Tag	Start Up										Normal Op.										Shut Down									
	2.1	2.2	2.3	2.4	2.5	2.7	2.8	3.1	3.2	3.3	4.1	4.2	4.2	4.2	4.2	4.3	4.5	4.7	4.8	4.9										
HCV ₁	C						0									C				C										
HCV ₂	C			0			C									0														
PCV ₁	C				0													C												
SV ₁	0								C				C																	
SV ₂	0								C				C																	
BV ₂	C					0																								
SV ₃	C								0																					
BV ₁	C							0		C			0			C	0													
BV ₃	C	0																												
BV ₄	C	0																												
BV ₅	C		0																											
BV ₆	C																													
BV ₇	C																													
FCV ₁	C		0															C												
BV ₈	C										C																			
BV ₉	C																													
BV ₁₀	C																		0

heater. For our system there are virtually no limits on system heat-up rate and we anticipate being able to accommodate whatever heat up rate the gas heater provides.

2.7) Set the pressure regulator ,PR, on the pulse accumulator tank to the pressure called for in the daily test plan and open BV2.

2.8) To initiate actual testing a transition from nitrogen to gasifier flow must be accomplished. This is done by gradually closing HCV2 and opening HCV1 in such a fashion so as to maintain essentially constant flow to the system.

2.9) System flow, temperature, pressure, and dust injection are trimmed to the daily test plan requirements and the system start up phase has been completed.

3) Normal Operation

During normal operation of the filter system very little operation interface is anticipated.

3.1) Pulse cleaning will periodically be required. This is to be initiated when the pressure drop across the filter reaches the trigger level set by the daily operating test plan. At this time the by pass valve BV1 is opened, allowing a parallel path for gas flow.

3.2) Pulse solenoid valve SV3 is energized from the filter control panel where the pulse timer/relay is located. Simultaneously SV1 and SV2 close thereby isolating the differential pressure transmitter PDT1 from the cleaning pulse.

3.3) Close bypass valve BV1 to cause full flow through the filter to be resumed.

3.4) Assess whether current pressure drop cycle is consistant with minimum acceptable conditions called for in daily operating plan. If not begin normal shut down procedure. If filter operations are considered within acceptable standards, proceed with next filtration cycle.

3.5) On a fixed schedule of approximately 1 hour the operator should visually inspect the system for obvious leaks and hot spots as detected by temperaure sensitive paint.

4) Normal Filter System Shut Down

We anticipate the normal shut down procedure for the filter system will consist of the following steps.

4.1) Turn off dust injector system (BV8).

4.2) Pulse jet clean the system in normal fashion.

4.3) Operate the nitrogen supply valve HCV2 and the gasifier supply gas in such a fashion that maintains constant flow but which gradually switches the system to all nitrogen flow.

4.4) Allow the system to purge while at temperature for 10-20 minutes.

4.6) Drop both gas heater and vessel heater power.

4.7) Simultaneously operate pressure and flow controllers to bring system flow and pressure to zero.

4.8) Bleed blowback reservoir pressure down to zero.

4.9) Return all valves to end of test condition as indicated in Table 1.

5) Emergency Shut Down

Specifications of a detailed emergency shutdown procedure for the system are difficult at this point in time since it will likely have to be carefully integrated into the overall gasification system and DOE procedure. A general philosophy of emergency shutdown, however, can be established and a list of situations that might constitute reason for an emergency shut down can be started.

The general goal of an emergency shut down would be to first isolate the filter system from the gasifier by closing HCV1. The next concern would be to shut off power to the heaters. Finally, one would like to bleed the system pressure down to ambient and purge.

Occurrences that we think might require an emergency shut down are:

- o Hot spot on vessel or piping as determined by heat sensitive paint
- o Sharp uncontrollable spike in filter pressure drop
- o Noticeable leak of gas on rupture of pressurized line
- o Bursting disk rupture
- o Plugged inlet flow line
- o Uncontrolled temperature excursion.

ATTACHMENT 3

**SUMMARY OF BLOWBACK ANALYSIS, ASSUMPTIONS
AND MAJOR CONCLUSIONS**

From R&D CENTER, 501-2B20
WIN 236-1966
Date January 22, 1985
Subject Design of Filter Blowback Systems

To D. F. Ciliberti - R&D, 501-3E29
T. E. Lippert - R&D, 501-3D20

cc: C. L. S. Farn, R&D, 501-2B18
D. L. Ayers, R&D, 501-2W33

I have reviewed the filter flowback systems described in 83-9E5-CERAM-R2 and 84-2B3-FACTA-R1 with a view towards determination of the simplest design parameters and criteria as well as giving some thought to design procedures which might be relevant to construction of large 40 filter module units.

In a set of calculations (attached) I have developed the following scenario:

1. Opening the blowdown tank initiates flow through the blowdown line which is critical (choked) at some point in the system. Although this flow will become subsonic after the ratio of tank pressure to ambient pressure becomes subcritical we have ignored this transition and approximate the subsonic flow with the sonic.
2. The flow expands from the minimum area and fills the cross section of the blowback line at the acoustic pressure, density, and temperature.
3. After the blowback flow leaves the line it spreads as a turbulent radial jet, entraining some of the surrounding fluid as its velocity decreases (although its momentum is conserved).
4. When this expanding jet is "contained" by side-walls of the filter plenum it ceases expansion and its momentum is converted into pressure which enables the flow to turn 90 degrees into the filter elements.

Discard Date

5. We assume that the flow through the filter elements is not controlling—at least for the short periods of time we are considering. This would be the case if the inertia of the dust cake were very high or if the pressure "out" in the filter element channels were very low.

Examining the experimental results in the two reports mentioned above with this scenario we find:

1. The pressure-time relationship in the filter manifold is set by the blowdown pressure vessel time constant.
2. The peak filter manifold pressure is determined by the distance of the manifold opening from the blowdown line outlet (if the outlet is outside the manifold), or by the position at which the expanding jet "fills" the manifold cross-section (if the outlet is inside the manifold).
3. The rapid pressure raise in the manifold is due to its small characteristic time relative to the blowdown tank characteristic time.
4. The blowdown tank characteristic time is proportional to its volume and inversely proportional to the square root of its temperature. In the case considered it is 0.57 seconds.
5. The manifold characteristic time is proportional to the blowdown tank characteristic time. The constant of proportionality is the ratio of the initial mass of gas in the manifold to that in the blowdown tank. In the case considered it is 0.01 seconds.

Since it is desirable to model a rather large scale filter manifold with perhaps 8 to 40 filters, it would probably be desirable to include several aspects of the backflow not included in the present case: these would include pressure drop in the filter elements and, perhaps, the inertia of the dust cake; also pressure drop and flow along the manifold would be of considerable importance with respect to unbalanced parallel channel flow.

There is no part of this problem which should not be amenable to simple, straightforward, analytical or semi-analytical solution.

Mike Roidt
Fluid Dynamics Research

:nfm

We consider the following system:

A reservoir of volume V_0 is at pressure, p_0 , temperature, T_0 , and density, ρ_0 , when a quick acting solenoid valve is opened to allow the stored gas to blow down as a jet. This jet is to be used to clean out a filter element but at first we will consider only jet development.

The state conditions surrounding the jet are denoted by the subscript s and are usually quite high for pressure and temperature, i.e., 150 psig and 1000°F. If k is the ratio of specific heats for the blowdown gas (air) we know that if

$$\frac{p_s}{p_0} < \left(\frac{2}{k+1}\right)^{\frac{k}{k-1}} = 0.5283 \quad (1)$$

then the flow will be choked somewhere in the system and the mass flow rate, $\dot{m}$, will be given by

$$\dot{m} = \sqrt{\frac{k g}{R} \left(\frac{2}{k+1}\right)^{\frac{k+1}{k-1}}} \frac{p_0 A^*}{\sqrt{T_0}} = .532 \frac{p_0 A^*}{\sqrt{T_0}} \quad (2)$$

for a perfect gas ,

In Equation (2) R is the gas constant ($R = 53.3 \text{ ft lb/lb}^\circ\text{R}$ for air) and $g = 32.17 \text{ ft/sec}^2$. The minimum area in the blowdown line is A^* . If

$$\frac{p_s}{p_o} \geq 0.5283 \quad (3)$$

then

$$\dot{m} = \left(\frac{p_s}{p_o}\right)^{1/k} \sqrt{1 - \left(\frac{p_s}{p_o}\right)^{\frac{k-1}{k}}} \frac{A^* p_o}{\sqrt{T_o}} \quad (4)$$

Let us assume the flow is choked at some point so that Equation (2) holds. If we let primed quantities indicate the time varying quantities inside the reservoir after the valve has been (instantaneously) opened, then

$$m' = m_o - \int_0^{\tau} \dot{m} d\tau \quad (5)$$

where τ is time.

We assume that the expansion process in the reservoir is reversible and adiabatic as is the expansion to the minimum area A^* . We have

$$p_o V_o = m_o RT_o \quad (6)$$

and

$$p' V_o = m' RT' \quad (7)$$

as well as

$$\frac{p'}{p_o} = \left(\frac{p'}{p_o}\right)^k ; \quad \frac{T'}{T_o} = \left(\frac{p'}{p_o}\right)^{\frac{k-1}{k}} \quad (8)$$

Then

$$\frac{p' V_o}{RT'} = \frac{p_o V_o}{RT_o} - \int_0^{\tau} .532 \frac{p' A^*}{\sqrt{T'}} d\tau \quad (9)$$

where we must use primed quantities in Equation (2) since the stagnation conditions in the reservoir are changing with time. Equation (9) can be made dimensionless by multiplying by RT_0/p_0V_0 to obtain

$$\frac{p'}{p_0} \left(\frac{T'}{T_0}\right)^{-1} = 1 - .532 \frac{RT_0^* A^*}{p_0 V_0} \int_0^\tau \frac{p'}{\sqrt{T'}} d\tau \quad (10)$$

$$\left(\frac{p'}{p_0}\right)^{1/k} = 1 - .532 \frac{RA^* \sqrt{T_0}}{V_0} \int_0^\tau \left(\frac{p'}{p_0}\right)^{\frac{1+k}{2k}} d\tau \quad (11)$$

If $\xi = p'/p_0$ and $\tau^* = V_0 / (.532 RA^* \sqrt{T_0})$ then we have

$$\xi^{1/k} = 1 - \frac{1}{\tau^*} \int_0^\tau \xi^{\left(\frac{1+k}{2k}\right)} d\tau \quad (12)$$

where τ^* is the system characteristic time. Differentiating Equation (12)

$$\frac{1}{k} \xi^{\frac{1}{k}-1} \frac{d\xi}{d\tau} = - \frac{\xi^{\frac{1+k}{2k}}}{\tau^*} \quad (13)$$

and thus

$$\int_1^{\xi'} \left(\xi_1 - \frac{3k-1}{2k}\right) d\xi = - \int_0^\tau \frac{k}{\tau^*} d\tau \quad (14)$$

so

$$\xi = \left\{1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right\}^{-\frac{2k}{k-1}} \quad (15)$$

Equation (15) will hold until $\xi = 0.5283$ or

$$\frac{\tau}{\tau^*} = \frac{2}{k-1} \left\{ \frac{1}{\sqrt{\frac{2}{k+1}}} - 1 \right\} = 0.477 \quad (16)$$

To evaluate τ^* we must have the minimum cross-sectional area. A^* , in the blowdown line. From 84-2B3-FACTA-R1 we have a curve of $\dot{m}$ versus p_0 which gives

$$\dot{m} = .33 \text{ lb/sec at } p_0 = 515 \text{ psia}$$

Since $V_0 \sim .075 \text{ ft}^3$ (from 83-9E5-CERAM-R2) and $T_0 \sim 540^\circ\text{R}$ we find

$$.33 = .532 A^* \frac{515}{\sqrt{540}}$$

or $A^* \approx 0.028 \text{ in}^2$ or approximately a 0.2 inch diameter orifice. The characteristic time is given by

$$\tau^* = \frac{V_0}{.532 R A^* \sqrt{T_0}} = \frac{.075 (144)}{.532 (53.3) (.028) \sqrt{540}} = .57 \text{ sec}$$

Thus Equation (16) is applicable until

$$\tau = .477 \tau^* = 0.27 \text{ seconds.}$$

It is interesting that the system characteristic time is only a first order function of geometric variables, V_0 and A^* , and a weak function of the initial stagnation temperature, T_0 . The latter parameter arises due to the variation of acoustic velocity with $\sqrt{T_0}$.

While a "patchwork" solution covering the entire blowdown period is possible by switching in equations from Equation (2) to Equation (4) at $\tau = \tau^*$ for the present we will assume Equation (15) adequate for our purposes.

At the position, A^{*}, in the blowdown system the fluid properties will be denoted by a superscripted asterisk and

$$\frac{T^*}{T'} = \frac{2}{k+1} = 0.8333 \quad (17)$$

$$\frac{\rho^*}{\rho'} = \left(\frac{2}{k+1}\right)^{\frac{1}{k-1}} = 0.6339 \quad (18)$$

$$\frac{p^*}{p'} = \left(\frac{k}{k+1}\right)^{\frac{2}{k-1}} = 0.5283 \quad (19)$$

so that, from expressions for adiabatic expansion we find

$$\begin{aligned} T^* &= .8333 T' = .8333 T_o \xi^{\left(\frac{k-1}{k}\right)} \\ &= .8333 T_o \left\{1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right\}^{-2} \end{aligned} \quad (20)$$

$$\rho^* = .6339 \rho' = .6339 \rho_o \xi^{1/k} = .6339 \rho_o \left\{1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right\}^{-\frac{2}{k-1}} \quad (21)$$

$$p^* = .5283 p' = .5283 p_o \xi = .5283 p_o \left\{1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right\}^{-\frac{2k}{k-1}} \quad (22)$$

also since

$$\rho_o = p_o / RT_o$$

$$\rho^* = .6339 \frac{p_o}{RT_o} \left\{1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right\}^{-\frac{2}{k-1}} \quad (23)$$

The mass flow rate is given by

$$\dot{m} = .532 A^* \frac{P}{\sqrt{T}} = .532 A^* \frac{P_0}{\sqrt{T_0}} \xi^{1/k}$$

or

$$\dot{m} = .532 A^* \frac{P_0}{\sqrt{T_0}} \left\{ 1 + \frac{k-1}{2} \frac{\tau}{\tau^*} \right\}^{-\frac{2}{k-1}} \quad (24)$$

To characterize the jet leaving the blowdown tube we need both the mass flow rate and the velocity at the minimum flow area, A^* . This latter should be independent of everything but $\sqrt{T_0}$. Combining equations (23) and (24)

$$u^* = \frac{\dot{m}}{A^* \rho^*} = \frac{.532 A^* \frac{P_0}{\sqrt{T_0}} \left\{ 1 + \frac{k-1}{2} \frac{\tau}{\tau^*} \right\}^{-\frac{2}{k-1}}}{A^* (.6339) \frac{P_0}{RT_0} \left\{ 1 + \frac{k-1}{2} \frac{\tau}{\tau^*} \right\}^{-\frac{2}{k-1}}} \quad (25)$$

$$u^* = \frac{.532 R \sqrt{T_0}}{.6339} = 44.7 \sqrt{T_0}$$

This is roughly ten percent below the "accepted" value

$$u^* = 49 \sqrt{T_0}$$

If the subscript, j , refers to the jet at the blowdown exit then

$$\rho_j u_j A_j = \rho^* u^* A^* \quad (26)$$

and taking $\rho_j \sim \rho^*$ we have

$$u_j = u^* \frac{A^*}{A_j}$$

$$u_j = 49 \sqrt{540} \left(\frac{.0289}{\frac{\pi}{4} (.305)^2} \right) \approx 450 \text{ ft/sec.} \quad (27)$$

If we assume a value of p_o of 515 psia and T_o of 540°R we have

$$\rho_j = \rho^* = .6339 \frac{p_o}{RT_o} = .6339 \frac{515 \times 144}{53.3 (540)} \quad (28)$$

$$\rho_j = 1.633 \text{ lb/ft}^3$$

so that we have a dynamic pressure head of

$$p = \frac{\rho_j u_j^2}{2g} = \frac{1.633 (450)^2}{2 (32.17) (144)} = 35.7 \text{ psia}$$

To obtain an indication of when the jet "fills" the 1" x 2" rectangular duct and its kinetic energy is converted to pressure is difficult for two reasons: first, the determination of a jet "boundary" is difficult and arbitrary even without the presence of solid boundaries and second, does intersection of the jet boundary with the width (the sides one inch apart) or the breadth (the sides two inches apart) terminate the "jet type" behavior. We know that generally circular jets increase in radius linearly with distance, x , from the nozzle, e.g., $b = .1x$ where b is the radius at which the jet velocity is one half of its maximum (centerline) value. What we will do at this point is approximate the outer jet radius as twice the regular b value and take the jet diameter as $d_j = .4x$.

Under conditions where the density of the gas jet and its surroundings are the same we would say that axial momentum is conserved and the pressure recovered from the jet is given by

$$p = \frac{\rho \bar{u}^2}{2g} = \frac{\rho}{2g} u_o^2 \frac{A_o}{A(x)} = \frac{\rho}{2g} u_o^2 \frac{D^2}{d_j^2} = \frac{\rho}{2g} u_o^2 \frac{D^2}{.16 x^2} \quad (29)$$

where D is the initial jet diameter, D = .305 inches.

In our case however the density of the initial jet is 1.633 lb/ft³ and the surrounding gas at 165 psia and 1000°F has

$$\rho_s = \frac{P_s}{RT_s} = \frac{165 \times 144}{53.3 (1460)} = .305 \frac{\text{lb}}{\text{ft}^3}$$

so that a correction must be made for the mean density. B. J. Hill* has shown that the mass in a jet can be given by

$$\dot{m} = \dot{m}_0 \left[1 + 0.32 (1 - \exp \{-.4 \frac{x}{D}\}) \sqrt{\frac{\rho_s}{\rho_j}} \frac{x}{D} \right] \quad (30)$$

where $\dot{m}_0$ is the mass flow at $x = 0$, the beginning of the jet. The average density in the jet may be calculated from

$$\bar{\rho} = \frac{\rho_j \dot{m}_0 + (\dot{m} - \dot{m}_0) \rho_s}{\dot{m}} = \frac{\rho_j + (\frac{\dot{m}}{\dot{m}_0} - 1) \rho_s}{\dot{m}/\dot{m}_0} \quad (31)$$

Using the various numbers we have found we may produce the following Table I.

*Hill, B. J., "Measurement of local entrainment rate in the initial region of axisymmetric turbulent air jets", J. Fluid Mech. Vol. 51, part 4, 1972.

Table I

$\bar{x}$ (inches)	$\bar{x}/D$	$\dot{m}/\dot{m}_0$	$\bar{\rho}$ ($\mu\text{m}/\text{ft}^3$)	$\bar{p}$ (lbf/in^2)
.5	1.64	1.11	1.50	205
1.0	3.27	1.33	1.30	21.2
1.5	4.91	1.58	1.14	6.7
2.0	6.55	1.84	1.03	3.2
2.5	8.20	2.09	.941	1.8
3.0	9.84	2.33	.88	1.18
4.0	12.5	2.80	.79	.55
5.0	16.4	3.26	.71	.37
6.0	19.6	3.70	.65	.25

The average impact pressure at any point in the jet's path may be calculated from

$$p = \frac{\bar{\rho} \bar{u}^2}{2g} = \frac{\bar{\rho}}{2g} \left(\frac{\dot{m}}{\bar{\rho} A_j} \right)^2 = \frac{\dot{m}^2}{2g \bar{\rho} A_j^2} \quad (32)$$

where $\dot{m}$ is from Eq. (30), $\bar{\rho}$ is from Eq. (31) and

$$A_j \approx \frac{\pi}{4} d_j^2 \approx \frac{\pi}{4} (.4x)^2 = .125 x^2 \quad (33)$$

so that

$$p = 15.6 \frac{(\dot{m}/\dot{m}_0)^2}{\bar{\rho} x} \text{ (psia) } (x \text{ in inches}) \quad (34)$$

This is the pressure given in the right hand column of Table I and plotted in Figure 1. If we assume we must have a peak pressure rise of 5 psi at a position 1.5 inches from the nozzle (as the experiments

Relative Increase In Mass Flow In Pulse Jet

Fig 1 - Dist From Orifice (in)

Average Density In Jet

Fig 2 — Dist From Orifice (in)

Jet Recovery Pressure

$T_o = 540\text{ R}$ and $P_o = 515\text{ psia}$

Fig 3 - Dist From Orifice (in)

indicate) then we find we must use

$$d_j = 0.43x \quad (35)$$

We will continue to use $0.4x$ for these calculations. This would imply the expanding jet "fills" the rectangular duct at about 1.68 inches from the nozzle when it is roughly 0.7 inches in diameter, i.e., the narrow gap controls the jet development.

Also, at 1.68 inches the jet mass flow rate has increased by nearly seventy percent.

The additional mass flow of $.7 (.33) = .231$ lb/sec being drawn into the duct will result in a pressure drop if the jet is confined as it was in the first experiments. This pressure drop is given by the pressure head of the induced flow.

$$u_{\text{induced}} = \frac{.231}{.305 \left(\frac{2}{144}\right)} \left(\frac{\text{lb}}{\text{sec}}\right) \left(\frac{1}{\frac{\text{lb}}{\text{ft}^3} \text{ft}^2}\right) = 55 \text{ ft/sec}$$

so that

$$\Delta P = - \frac{\rho u^2}{2g} = - \frac{.305 (55)^2}{64.34} \frac{1}{144} \approx .1 \text{ psi} \approx 3 \text{ inches H}_2\text{O}$$

This pressure drop is much less than the 3 psi actually measured and I can't explain it. One possibility is that a confined jet is often unstable with respect to location within the duct and will adhere to one wall or the other rather than simply moving down the center of the duct. If this were to happen in the experiment with the nozzle protruding one inch into the chamber then, depending upon the location

of the pressure tap, almost any pressure down to a vacuum could be obtained.

If we look at Eq. (34) and Eq. (24) we note a time variation in pressure given by

$$p = 15.6 \frac{(\dot{m}/\dot{m}_o)^2}{\bar{\rho} x^4} = \frac{15.6}{\bar{\rho} x^4} \left\{ 1 + \frac{k-1}{2} \frac{\tau}{\tau^*} \right\}^{-\frac{4}{k-1}} \quad (36)$$

At $x = 1.5$, $\bar{\rho}_p = 1.14$, and $\tau^* = .57$ this expression becomes

$$p = 6.7 \{ 1 + 0.3508 \tau \}^{-10} \quad (37)$$

This pressure is shown in Figure 2 compared with the measured value and it appears to represent the trend reasonably well. If we use $d_j = .43x$ we follow the curve somewhat more closely as is indicated in the figure.

This relatively close correlation between Eq. (37) and the experimental results imply that the pressure pulse is governed by the blowdown tank time constant.

$$\tau^* = \frac{V_o}{.532 RA^* \sqrt{T_o}} \quad (38)$$

For this to be the case certain conditions must be met with respect to the plenum into which the jet is injected which we will denote by the subscript p and its initial state by " p_o ." If we assume that, during the initial pressure surge, the inertial resistance of the caked dust is large then we may write:

$$m_p = m_{p0} + \int_0^\tau \dot{m} d\tau \quad (39)$$

where

Figure 4. Pressure versus time curves

$$\dot{m} = .532 \frac{p_o A^*}{\sqrt{T_o}} \left(1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right)^{-\frac{2}{k-1}} \quad (40)$$

or

$$\dot{m} = \frac{V_o p_o}{\tau^* R T_o} \left(1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right)^{-\frac{2}{k-1}} = \frac{m_o}{\tau^*} \left(1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right)^{-\frac{2}{k-1}} \quad (41)$$

Using the perfect gas law we may re-write Eq. (39)

$$m_p = \frac{p_p V_p}{R T_p} = \frac{p_{po} V_{po}}{R T_{po}} + \frac{m_o}{\tau^*} \int_0^{\tau} \left(1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right)^{-\frac{2}{k-1}} d\tau \quad (42)$$

So that differentially Eq. (42) with $\xi_p = \rho_p / \rho_{po}$ and $\beta_p = T_p / T_{po}$ leads to

$$\frac{1}{\xi_p} \frac{d\xi_p}{d\tau} - \frac{1}{\beta_p} \frac{d\beta_p}{d\tau} = \frac{R T_{po} m_o}{p_{po} V_{po} \tau^*} \frac{\epsilon_p}{\xi_p} \left(1 + \frac{k-1}{2} \frac{\tau}{\tau^*}\right)^{\frac{2}{k-1}} \quad (43)$$

which defines a time constant, τ_p^* ,

$$\tau_p^* = \tau^* \frac{m_{po}}{m_o} \quad (44)$$

For the very steep initial pressure rise rate shown in Figure (2) we must have $\tau_p^* \ll \tau^*$ or $m_{po} \ll m_o$. In the present case we have

$$\frac{m_{po}}{m_o} \approx \frac{\frac{2 \times 6 \times 1}{1728} \text{ ft}^3 (.305 \frac{\text{lb}}{\text{ft}^3})}{.075 \text{ ft}^3 (1.633 \frac{\text{lb}}{\text{ft}^3})} = 0.0173$$

so that we have $\tau_p^* \ll \tau^*$.

ATTACHMENT 4

PROGRAM FOR COMPUTATION OF FILTER VESSEL HEAT LOSS

```

10 CLS
12 LPRINT:LPRINT
15 INPUT"K (btu-ft/hr-ft^2-F) = "; K
20 INPUT"Thot , Tamb (F) =";TH,TA
30 INPUT"Vessel ID , OD (in) =";ID,OD
35 INPUT"Vessel Length (ft) = ";LV
40 E = .99
50 TS = 200
60 GOSUB 1000
70 GOSUB 2000
80 GOSUB 3000
90 FX = QCV + QRD - QCD
100 DFX = 1.25*QCV/(TS - TA) + .001812*OD*E*((TS+460)/100)^3
110 DFX = DFX + QCD/(TH - TS)
120 TSP = TS - FX/DFX
130 IF ABS((TSP-TS)/TS) > .00001 THEN TS=TSP: GOTO 60
140 TS = TSP
145 PRINT:PRINT
150 LPRINT"OD(in) , ID(in) = ";OD,ID
152 PRINT"OD , ID = ";OD,ID
155 LPRINT"Vessel Length (ft) = ";LV
157 PRINT"Vessel Length (ft) = ";LV
160 LPRINT"K(btu-ft.hr-ft^2-F) = ";K
162 PRINT"K = ";K
170 LPRINT"Thot = ";TH
172 PRINT"Thot = ";TH
180 LPRINT"Tamb = ";TA
182 PRINT"Tamb = ";TA
185 PRINT:PRINT
190 LPRINT"Tsurf = ";TS
192 PRINT"Tsurf = ";TS
200 LPRINT"Qcd (btu/hr-ft) = ";QCD
202 PRINT"Qcd (btu/hr-ft) = ";QCD
210 LPRINT"Qcv = ";QCV
212 PRINT"Qcv = ";QCV
220 LPRINT"Qrd = ";QRD
222 PRINT"Qrd = ";QRD
225 PWR = (LV*QCD)/3412 :LPRINT:LPRINT
226 LPRINT"Power Required (Kw) = "; PWR
228 PRINT"Power Required (Kw) = "; PWR
230 END
1000 QCD = 6.2832*K*(TH-TS)/LOG(OD/ID) : RETURN
2000 QCV = .27*((TS-TA)*12/OD)^.25*.2618*OD*(TS-TA) : RETURN
3000 QRD = .0453*E*OD*((TS+460)/100)^4 - ((TA+460)/100)^4) : RETURN

```

```

OD(in) , ID(in) = 24      12
Vessel Length (ft) = 6
K(btu-ft.hr-ft^2-F) = .05
Thot = 1600
Tamb = 70
Tsurf = 128.1043
Qcd (btu/hr-ft) = 667.1178
Qcv = 228.8486
Qrd = 438.2696

```

```

Power Required (Kw) = 1.173126

```

END

**DATE
FILMED**

8 / 31 / 92