DOE/MC/27227--3082

DE92 001268

Design of Gasifiers to Optimize Fuel Cell Systems

Topical Report

February 1992

Work Performed Under Contract No.: DE-AC21-90MC27227

For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
Morgantown, West Virginia

By
Energy Research Corporation
Danbury, Connecticut

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

Design of Gasifiers to Optimize Fuel Cell Systems

Topical Report

Work Performed Under Contract No.: DE-AC21-90MC27227

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
Energy Research Corporation
3 Great Pasture Road
Danbury, Connecticut 06813**

February 1992

ACKNOWLEDGEMENTS

This effort was conducted by Energy Research Corporation in collaboration with Fluor Daniel and the University of North Dakota/Energy & Environmental Research Center under the direction of the U.S. Department of Energy Morgantown Energy Technology Center. The DOE/METC project manager is Mr. Justin Beeson.

Fluor Daniel conducted the detailed system configuration and analysis. The Fluor project manager was Thurlie Moss and principal investigators were Steven J. Meyers and Arthur Lee. The University of North Dakota/Energy & Environmental Research Center evaluated options for disposable gasification catalysts. The UND/EERC project manager was William B. Hauserman with principal investigators Everett A. Sondreal, Warrack G. Willson, Steve Cisney, and Ron Timpe.

Energy Research Corporation was overall project coordinator and provided fuel cell performance data for the carbonate fuel cell system and the Hydrogen Transfer Device (HTD) as well as recommendations for system configurations. ERC participants included Dr. Bernard Baker, Dr. Hans Maru, A. Kush, and Jennifer Fruchtman, who prepared this final report.

In addition to the project participants mentioned above, a Utility Advisory Committee consisting of representatives from EPRI, Southern Company Services Inc., Dakota Gasification Company and DOE were consulted. These advisors included Mr. Neville A. Holt of EPRI, Mr. Rodney E. Sears of Southern Company Services, Mr. Donald C. Pollock of Dakota Gasification Company and Mr Lawrence K. Rath of DOE/METC.

EXECUTIVE SUMMARY

Pursuing the key national goal of clean and efficient utilization of the abundant domestic coal resources for power generation, this study was conducted to evaluate the potential of optimizing the integrated catalytic gasification/carbonate fuel cell power generation system.

Conventional gasification systems evolved from process requirements which dictate high temperatures for complete conversion of hydrocarbons to produce a tar-free gas. These high temperatures are normally achieved by an oxidant fed to the gasifier, which consumes a portion of the coal feed to provide the required heat. The thermal needs of this process result in fuel gas temperatures that are higher than necessary for most end use applications as well as gas cleanup purposes. This results in some efficiency and cost penalties. Electrochemical conversion of coal-derived gas by carbonate fuel cells, while feasible and attractive with conventional gasification systems, would be greatly improved by modifying and integrating the gasification process with the carbonate fuel cell. This involves recycling fuel cell exhaust back to the gasifier to provide chemical and thermal energy, which allows lowering the gasification temperature to approximately the fuel cell operating temperature of 1200 F, and improves efficiency. To date, the system studies on coal gas/carbonate fuel cells have assumed presently available gasifiers, which are not necessarily optimal for this use. Carbonate fuel cell power plants would be most efficient if the energy were delivered to fuel cells in "chemical" energy form rather than in heat. Thus, gasifiers specifically developed for carbonate fuel cell power plants may provide higher overall efficiency.

With this objective in mind, ERC, in close collaboration with Fluor Daniel (providing engineering design and costing), conducted a detailed configuration study under a Department of Energy, Morgantown Energy Technology Center sponsored effort to evaluate various catalytic gasification/carbonate fuel cell power plant configurations. In addition, as part of this investigation, present-day as well as emerging alternate coal-based power plant technologies were compared to the catalytic gasification/carbonate fuel cell configurations to assess their competitive position.

The study approach consisted of a comparison of two system configurations based on a high-methane vs. high-hydrogen producing gasification step, and an initial evaluation of basic gasifier operating conditions. These results were used to configure three catalytic gasification/carbonate fuel cell power generation systems. The three system configurations investigated were:

- Recoverable Gasification Catalyst with Cold Gas Cleanup
- Disposable Gasification Catalyst with Cold Gas Cleanup
- Disposable Gasification Catalyst with Hot Gas Cleanup

The initial evaluation showed that a system which produced a high-methane content in the gasifier effluent was 40% more efficient and 29% lower in capital cost than a system which produced a high-hydrogen content in the gasifier effluent. The lower efficiency of the "High-Hydrogen" configuration is due primarily to the carbon dioxide separation step. The high capital cost of this design approach is a result of the high throughput, low pressure, and the CO₂ removal system. The hydrogen requirement of the catalytic gasifier at the baseline "High-Methane" producing conditions (500 psia, 1275 F) imposed a significant power requirement for hydrogen separation and recompression. Lower hydrogen recycle rates, and hence higher efficiency, were obtained by reducing the gasifier temperature from 1275 F to 1200 F, increasing the gasifier pressure from 500 to 750 psia, and by adding air to the gasifier.

Efficiencies achieved by integrated catalytic gasification/carbonate fuel cell systems were 51-54% (HHV). This compares well with conventional gasification fuel cell efficiencies of 45-47% (HHV) obtained in a previous study

and 49.7% (HHV) in a more recent study. Disposable gasification catalyst systems with cold cleanup reduced O&M costs but capital costs and COE were slightly higher, compared to recoverable gasification catalyst systems, due to lower activity of the catalyst.

Hot gas cleanup in conjunction with the disposable catalyst case produced the highest system efficiency (54% HHV) with a 6% improvement over the cold cleanup system. This efficiency is also 4 percentage points higher than conventional gasification/carbonate fuel cell systems. The disposable gasification catalyst/carbonate fuel cell with hot gas cleanup system also has 4% higher efficiency and an estimated 7% lower capital cost compared to the recoverable gasification catalyst/carbonate fuel cell with cold gas cleanup system. The COE for this configuration is estimated to be slightly lower than the other two system configurations studied.

A comparison to competing non-fuel cell systems indicated that the efficiency of catalytic gasification/carbonate fuel cell systems is 57 to 65% higher than the pulverized coal with coal cleanup and wet flue gas desulfurization. The efficiency of the advanced IGCC is 20 to 24% lower than the efficiency of the catalytic gasification/carbonate fuel cell systems.

Environmental emissions are a major concern in today's power generation technologies. The sulfur emissions of the catalytic gasification/carbonate fuel cell systems, at <0.02 lb/MWh, are projected to be well below future stringent environmental regulations. The PC and AFBC technologies in use today have sulfur emissions of up to two orders of magnitude greater. The advanced IGCC technology has sulfur emissions of up to 4 times the rate of catalytic gasification/carbonate fuel cell systems.

The NO_x emissions of the catalytic gasification/carbonate fuel cell systems total less than 10% of the NO_x emissions from the IGCC, PC or AFBC technologies. The carbon dioxide emissions of the catalytic gasification/carbonate fuel cell systems ranges from 25 to 38% lower than the CO_2 emissions from the other technologies. Catalytic gasification/carbonate fuel cell systems generate 18% less CO_2 than conventional gasification/carbonate fuel cell systems due to higher efficiencies, and reduced oxygen consumption by the gasifier.

Disposable gasification catalysts have the potential to simplify plant design by avoiding a catalyst recovery step. In this study, limestone and iron-based catalysts were assumed as disposable catalysts. Based on limited experimental data obtained to supplement the gasification catalyst literature survey, the activity of these catalysts, used in dry form, was lower than potassium carbonate. Additional experimental testing is required to assess the impact on gasification kinetics and hence gasifier sizing with disposable gasification catalysts. Catalysts such as limestone or iron-based catalysts may be economic alternatives but are not as active in dry form as the recoverable catalyst potassium carbonate and hence require larger gasifiers to maintain the needed residence time. Catalysts with activities approaching or surpassing the activity of potassium carbonate are required to reduce the capital cost of these systems.

Hot gas cleanup offers a distinct advantage in efficiency and cost. The thermodynamics and kinetics of gasification and in-situ sulfur capture at low temperatures must be evaluated further to establish the feasibility of simultaneous gasification/sulfur capture by a catalyst/sorbent mix.

In summary, the system study results show significant benefits for thermochemical integration of coal gas/carbonate fuel cell power plants. Specifically, methane producing gasifiers operating at temperatures more compatible with internal reforming carbonate fuel cells would be advantageous for high-efficiency, environmentally superior coal gas/carbonate fuel cell power plants. Methane-producing gasifiers have been explored at bench-scale, but further studies, particularly aimed at fuel cell integration, and low-cost disposable catalysts are recommended.

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 INTRODUCTION	1
2.0 METHODOLOGY	3
3.0 RESULTS AND DISCUSSION.....	5
3.1 HIGH-METHANE AND HIGH-HYDROGEN EVALUATION	5
3.2 GASIFIER/FUEL CELL SYSTEM DESIGN STUDIES	10
3.2.1 Parametric and System Configuration Evaluation.....	13
3.2.2 Case 1 Recoverable Gasification Catalyst System	13
3.2.3 Case 2 Disposable Catalyst/Cold Gas Cleanup	21
3.2.4 Case 3 Disposable Catalyst/Hot Gas Cleanup	24
4.0 PROGRAM ASSESSMENT	27
4.1 CASE COMPARISON	27
4.1.1 Design Comparison	27
4.1.2 Heat Rate Comparison	27
4.1.3 Capital Cost	27
4.1.4 Cost of Electricity	33
4.2 SYSTEM COMPARISON	34
4.2.1 Heat Rate Comparison	34
4.2.2 Environmental Impact Comparison	36
5.0 CONCLUSIONS AND RECOMMENDATIONS.....	38
5.1 RECOMMENDATIONS	39
REFERENCES	41
APPENDICES	
Appendix A High-Methane vs. High-Hydrogen Gasification	
Appendix B System and Parametric Evaluation for Case 1	
Appendix C Case 1 Process Description	
Appendix D Evaluation of Disposable Catalyst Options	

LIST OF TABLES

<u>Title</u>	<u>Page No.</u>
Table 1 High H ₂ vs. High CH ₄ Material Balance for Figures 3, 4 and 5	7
Table 2 Preliminary Case 1 Power Summary and Heat Rate	12
Table 3 Stream Flow Summary for Case 1	18
Table 4 Case 1 Power Summary and Heat Comparison	20
Table 5 Stream Flow Summary for Case 2	23
Table 6 Stream Flow Summary for Case 3	26
Table 7 Gasifier Design Parameters	28
Table 8 Internal Reforming Carbonate Fuel Cell Design Parameters	29
Table 9 Catalyst and Chemicals Comparison	30
Table 10 Power Summary and Heat Rate Comparison	31
Table 11 Relative Capital Cost Comparison	32
Table 12 Heat Rate Comparison with Competing Systems	35
Table 13 Environmental Impact Comparison with Competing Systems.....	37

LIST OF FIGURES

<u>Title</u>	<u>Page No.</u>
Figure 1 Gasifier/Carbonate Fuel Cell Configurations	2
Figure 2 Program Approach	4
Figure 3 "High Methane" Approach Configuration	6
Figure 4 "High Hydrogen" Approach With Shift Configuration	8
Figure 5 "High Hydrogen" Approach With No Shift Configuration	9
Figure 6 Preliminary Case 1 Process Flow Sketch	11
Figure 7 Effect of Gasifier Conditions on H ₂ Rate	14
Figure 8 Gasifier Steam and Air Effect on Raw Gas Methane Content and Hydrogen Recycle Rate.....	15
Figure 9 Effect of Adding Air to the Gasifier	16
Figure 10 Case 1 - Process Flow Sketch	17
Figure 11 Case 2 - Process Flow Sketch	22
Figure 12 Case 3- Process Flow Sketch	25

PROJECT SUMMARY

TITLE: DESIGN OF GASIFIERS TO OPTIMIZE FUEL CELL SYSTEMS

CONTRACT NUMBER: DE-AC21-90MC27227

CONTRACTOR: ENERGY RESEARCH CORPORATION
3 Great Pasture Road
Danbury, CT 06813

PERIOD OF PERFORMANCE: September 28, 1990 to September 27, 1991

OBJECTIVE: To configure coal gasification/carbonate fuel cell systems that can significantly improve the economics, performance, and efficiency of electric power generation systems.

CONTRACT TASKS:

Status

TASK 1.	Project Work Plan	completed
TASK 2.	Gasifier/Fuel Cell System Design Studies	completed
Task 2.1	Design Studies	completed
Task 2.2	Technical/Economic Analysis	completed
TASK 3.	Program Assessment	completed

1.0 INTRODUCTION

More than 50% of the electricity generated in the United States is derived from coal. Although the abundant coal reserves in the U.S. assure us a 400 year supply of this low cost energy source, its utilization in an efficient and environmentally acceptable manner is becoming more critical as energy independence issues become more crucial and environmental issues more pressing.

The technologies currently utilized for coal-based power generation rely on combustion of coal and flue gas desulfurization. These include Pulverized Coal Combustion Boiler/Flue Gas Desulfurization (PC/FGD), Atmospheric Fluid Bed Combustion (AFBC), and Pressurized Fluid Bed Combustion (PFBC). These technologies are inherently limited in the efficiencies achievable. As existing U.S. power plant equipment reaches the end of its useful life, more efficient, lower cost, and environmentally superior replacements will be necessary as we prepare to enter the next century.

The carbonate fuel cell is recognized as a highly efficient power generating device that can also provide environmentally acceptable utilization of coal. Unlike thermomechanical devices such as turbines that convert thermal energy to electricity, the carbonate fuel cell electrochemically converts chemical energy directly to electricity. This requires a coal gasification conversion process rather than the older coal combustion process. The gasification process offers both efficiency and environmental advantages over the combustion process.

Conventional gasification systems are based on the requirements of the gasification process itself. The process requires high temperatures for complete hydrocarbon conversion in order to produce a tar-free gas. These high temperatures are normally achieved by an oxidant fed to the gasifier, which consumes a portion of the coal feed to produce the needed heat. In addition, the high gasification temperatures are above those necessary for most end use applications as well as gas cleanup purposes. This results in some efficiency and cost penalties. A typical gasification/carbonate fuel cell configuration for this type of system is illustrated in Figure 1a. The fuel gas is primarily hydrogen, carbon dioxide, and carbon monoxide, and waste heat is converted to steam for the gasifier and the bottoming cycle. A recent DOE/METC supported system study⁽¹⁾ conducted by ERC and Fluor Daniel evaluated a number of systems based on this configuration.

Catalytic gasification offers the potential for novel approaches to fuel cell integration. By catalyzing the gasification reaction, lower temperatures are sufficient, and use of an oxidant can be minimized while hydrogen recycle to the gasifier is used⁽²⁾. The lower gasification temperature contributes to improved efficiency and improved thermal integration with the carbonate fuel cell which operates at approximately the same temperature. The recycle requirement to the gasifier can be provided in several ways as investigated in this and other studies.

Several studies were conducted to evaluate the integration of catalytic gasification with fuel cells. One such study⁽³⁾ suggests recycling the fuel cell exhaust back to the gasifier. The fuel cell exhaust provides the chemical energy required by the gasifier and increases system efficiency. This approach maximizes hydrogen production by operating the gasifier at low pressure and separates carbon dioxide for injection into the fuel cell cathode as shown in Figure 1b. Other approaches have been proposed⁽⁴⁾ which recycle the anode exhaust back to the gasifier at high pressure.

1a.) Conventional CGCFC Concept
(Only Thermal Integration)

1b.) Advanced Gasification/Carbonate
Fuel Cell System-High-Hydrogen Case
(Thermochemical Integration)

1c.) Advanced Gasification/Carbonate
Fuel Cell System-High-Methane Case
(Thermochemical Integration)

LD1204g

FIGURE 1
GASIFIER/CARBONATE FUEL CELL CONFIGURATIONS

The present study evaluated the potential of optimizing the integrated catalytic gasification/carbonate fuel cell power generation system in order to improve efficiency and lower costs. In addition, the optimized catalytic gasification/carbonate fuel cell systems were compared to present day as well as emerging alternate coal-based power technologies to assess its competitive position.

The study methodology consisted of an initial evaluation on two basic design approaches: recycling anode fuel cell exhaust back to a low pressure gasifier (high-hydrogen approach) and recycling only separated hydrogen from the fuel cell to the gasifier (high-methane approach). After comparing the two approaches on the basis of heat rate and capital cost, the selected approach was used in the design of three case configurations:

- Recoverable Gasification Catalyst with Cold Gas Cleanup Technology
- Disposable Gasification Catalyst with Cold Gas Cleanup Technology
- Disposable Gasification Catalyst with Hot Gas Cleanup Technology

These three cases were analyzed to obtain the most attractive configuration. Subsequently the three systems were compared with three alternative coal-based technologies: Pulverized Coal (PC), Atmospheric Fluidized Bed Combustion (AFBC) and Integrated Gasification Combined Cycle (IGCC).

2.0 METHODOLOGY

This program was designed to evaluate catalytic coal gasification systems that can significantly improve the economics, performance and efficiency of electric power generation systems by the integration of coal gasification with carbonate fuel cells. This was accomplished by design studies of conceptual integrated catalytic coal gasification/fuel cell systems. The objective was to adapt the coal gasification system to meet the requirements of the fuel cell rather than fitting the fuel cell to the gasification system. Therefore, the conceptual coal gasification system was designed to supply fuel gases at temperatures, pressures, and compositions appropriate for the optimized performance of the integrated system.

The program logic and methodology is shown in Figure 2. The first step in this program involved the selection of a system approach. At one set of conditions the gasifier product stream contains a high-hydrogen content ("High-Hydrogen Approach") and in another set of conditions a high-methane content ("High-Methane Approach"). Three configurations using the chosen approach were evaluated for optimum overall system efficiency. These are:

- a) Recoverable Gasification Catalyst with Cold Gas Cleanup
- b) Disposable Gasification Catalyst with Cold Gas Clean-up
- c) Disposable Gasification Catalyst with Hot Gas Clean-up

Each configuration was evaluated with respect to heat rate, capital cost, and cost of electricity. Finally, a comparison based on heat rate and environmental impact of these configurations with the conventional coal power generation systems was made.

FIGURE 2
THE PROGRAM APPROACH

LD1363b

3.0 RESULTS AND DISCUSSION

3.1 HIGH-METHANE AND HIGH-HYDROGEN EVALUATION

In this evaluation two alternate design approaches for a gasification/carbonate fuel cell power plant were compared:

- High-Methane Gasification
- High-Hydrogen Gasification

A screening evaluation was performed in order to select which of the two concepts would be used for the follow-on studies. The two concepts were compared using gasifier simulations, material balances, power summaries, and a heat rate and relative cost comparison.

Depending on the gasifier operating conditions the gasifier effluent can contain a relatively high-methane content or a relatively high-hydrogen content. In the "High-Methane" approach the gasifier is operated at high (500 psia) pressure to promote methane production. The methane makes use of the internal reforming capacity of the fuel cell and increases the gasification efficiency. The effluent from the gasifier is cooled, cleaned and expanded, then fed to the atmospheric carbonate fuel cells. The anode exhaust is fed through a shift reactor to increase hydrogen content and lower carbon monoxide content, and then through a hydrogen transfer device (HTD). The HTD is an ERC development based on phosphoric acid fuel cell technology that electrochemically separates hydrogen from a gas stream. The hydrogen-rich stream is recompressed and recycled to the gasifier while the remainder of the gas is combusted and then fed to the carbonate fuel cell cathode. Figure 3 shows this configuration, while flow rates and gas compositions are listed in Table 1.

In the "High-Hydrogen" approach the gasifier operates at a low (88 psia) pressure to promote hydrogen production. Carbon dioxide leaving the gasifier is separated via an amine unit after the gasifier effluent has been cleaned. The separated CO₂ is routed to the carbonate fuel cell cathode while the rest of the gas goes to the anode. After the fuel cell all of the anode exhaust is recycled back to the gasifier. Two designs using this approach were considered; one design contained a raw gas shift reactor to convert CO to CO₂ while the other did not. The benefit of the shift reactor is that the higher CO₂ content of the gas increases the effectiveness of the CO₂ separation unit and also reduces the raw gas and recycle gas flow rates by ~50%. These configurations are illustrated in Figures 4 and 5, while the flow rates and gas compositions are listed in Table 1.

The details of this analysis are shown in Appendix A. The heat rate of the "High-Methane" approach is only ~70% of the heat rate from either of the "High-Hydrogen" designs. The high heat rate for the "High-Hydrogen" approach is due primarily to the high power required for the CO₂ separation unit. This required power is produced by burning more coal (even though this case produces 9% more power than the "High-Methane" approach, it has a 55% higher coal feed rate). The capital cost of the "High-Hydrogen" approach was 1.4 times greater than the "High-Methane" approach, again as a result of the CO₂ separation unit and the increased coal feed rate. Based on these figures it was conclusively shown that the "High-Methane" was more attractive and it was decided to use this approach for the follow-on studies.

FIGURE 3
HIGH METHANE APPROACH CONFIGURATION

TABLE 1
HIGH H₂ vs. HIGH CH₄ STUDY
MATERIAL BALANCE
FOR FIGURES 3, 4, 5

Stream Number		1	2	3	4	5	6	7
Stream Description		Raw Gas	AGR Feed	CFC Feed	Anode Out	Shift Out	Recycle Gas	To Cathode
Case A, High CH₄								
Lb Mol/Hr	H ₂	5,070	5,070	5,070	5,658	8,454	8,170	284
	H ₂ O	6,394	0	3,542	9,595	6,799	80	4,363
	CH ₄	3,336	3,336	3,336	15	15	0	15
	CO	482	482	482	3,441	645	0	645
	CO ₂	<u>948</u>	<u>948</u>	<u>790</u>	<u>10,887</u>	<u>13,683</u>	<u>0</u>	<u>13,683</u>
	Total	16,230	9,836	13,220	29,596	29,596	8,250	18,990
Mole %	H ₂	31.2	51.5	38.4	19.1	28.6	99.0	1.5
	H ₂ O	39.4	0.0	26.8	32.4	23.0	1.0	23.0
	CH ₄	20.6	33.9	25.2	0.1	0.1	0.0	0.1
	CO	3.0	4.9	3.6	11.6	2.2	0.0	3.4
	CO ₂	<u>5.8</u>	<u>9.6</u>	<u>6.0</u>	<u>36.8</u>	<u>46.2</u>	<u>0.0</u>	<u>72.1</u>
	Total	100.0	100.0	100.0	100.0	100.0	100.0	100.0
Case B, High H₂ - With Shift								
Lb Mol/Hr	H ₂	11,868	17,990	17,990	16,943	-	16,943	0
	H ₂ O	7,900	0	3,733	11,962	-	739	0
	CH ₄	3,810	3,810	3,810	219	-	219	0
	CO	8,762	2,639	2,639	7,320	-	7,320	0
	CO ₂	<u>9,092</u>	<u>15,217</u>	<u>0</u>	<u>9,640</u>	-	<u>9,640</u>	<u>15,217</u>
	Total	41,432	39,656	28,172	46,084	-	34,861	15,217
Mole %	H ₂	28.6	45.4	63.9	36.8	-	48.6	0.0
	H ₂ O	19.1	0.0	13.3	26.0	-	2.1	0.0
	CH ₄	9.2	9.6	13.5	0.5	-	0.6	0.0
	CO	21.1	6.7	9.4	15.9	-	21.0	0.0
	CO ₂	<u>21.9</u>	<u>38.4</u>	<u>0.0</u>	<u>20.9</u>	-	<u>27.7</u>	<u>100.0</u>
	Total	100.0	100.0	100.0	100.0	-	100.0	100.0
Case C, High H₂ - No Shift								
Lb Mol/Hr	H ₂	14,170	14,170	14,170	20,791	-	20,791	0
	H ₂ O	8,984	0	12,782	13,712	-	1,118	0
	CH ₄	4,103	4,103	4,103	328	-	328	0
	CO	15,946	15,946	15,946	13,676	-	13,676	0
	CO ₂	<u>15,759</u>	<u>15,759</u>	<u>0</u>	<u>16,824</u>	-	<u>16,824</u>	<u>15,759</u>
	Total	58,962	49,978	47,001	65,331	-	52,737	15,759
Mole %	H ₂	24.0	28.4	30.1	31.8	-	39.4	0.0
	H ₂ O	15.2	0.0	27.2	21.0	-	2.1	0.0
	CH ₄	7.0	8.2	8.7	0.5	-	0.6	0.0
	CO	27.0	31.9	33.9	20.9	-	25.9	0.0
	CO ₂	<u>26.7</u>	<u>31.5</u>	<u>0.0</u>	<u>25.8</u>	-	<u>31.9</u>	<u>100.0</u>
	Total	100.0	100.0	100.0	100.0	-	100.0	100.0

FIGURE 5
HIGH HYDROGEN APPROACH NO SHIFT CONFIGURATION

3.2 GASIFIER/FUEL CELL SYSTEM DESIGN STUDIES

Having compared the high-methane gasification versus the high-hydrogen gasification approach, it was concluded that the high-methane gasification approach was preferred. Three configurations were prepared:

- Case 1 - Recoverable Gasification Catalyst System with Cold Cleanup
- Case 2 - Disposable Gasification Catalyst System with Cold Cleanup
- Case 3 - Disposable Gasification Catalyst System with Hot Cleanup

The objective of this task was to configure a gasifier/carbonate fuel cell system for a 200MW baseload power plant. The facility is based in the Illinois-Wisconsin area and is fueled by Illinois No. 6 bituminous coal. It uses catalytic gasification based on the Exxon catalytic process and internal reforming carbonate fuel cells.

A preliminary system configuration for Case 1, shown in Figure 6, resulted in the power summary shown in Table 2. The results obtained indicated that the heat rate was not sufficiently attractive as was observed in the previous comparison of the high-methane versus high-hydrogen gasification approaches. An effort was therefore pursued to improve the system heat rate by evaluating gasification operating parameters and system configuration options, as discussed in Section 3.2.1.

After evaluating several options in gasification parameters, a change was made in gasification conditions and the three case studies were evaluated. The process description of each is described below.

FIGURE 6
PRELIMINARY CASE 1 PROCESS FLOW SKETCH

TABLE 2
PRELIMINARY CASE 1
POWER SUMMARY AND HEAT RATE

H ₂ Separation Device	HTD
Power Summary (MW)	
Production	
Carbonate Fuel Cell	162.1
Fuel Gas Expander	17.7
Steam Turbine	21.5
Total Production	201.3
Consumption	
HTD	23.6
Recycle Gas Compression	11.1
Cathode Recycle Blower	0.0
Carbonate Fuel Cell Air Blower	4.9
Anode Blower	2.0
Steam and Cooling Water	0.1
Other	0.8
Total Consumption	42.5
Net Power Generation	158.9
Coal Consumption (TPD)	
Gasification	1,366
Total	1,366
Heat Rate (Btu/kWh) (HHV)	7,236

3.2.1 Parametric and System Configuration Evaluation

A significant portion (56%) of the system power consumption was determined to be in the separation and recompression of the fuel cell anode exhaust recycle to the gasifier. An evaluation of gasification parameters was therefore conducted to explore the potential for an improved heat rate by altering the conditions of the gasifier and thus decreasing the hydrogen recycle rate. Figure 7 illustrates the result of this analysis in terms of the gasification operating pressure, temperature, and steam addition rate to the gasifier.

The results indicate that there is a thermodynamic benefit to increased gasification pressures and reduced temperatures compared to the chosen baseline conditions as depicted by the reduced hydrogen recycle rate required to keep the gasifier in heat balance. This is due to increased methanation in the gasifier. It should be noted however, that these results do not account for kinetic effects. Data from EERC indicates that a 75°F reduction in temperature will approximately double the gasifier bed size, for limestone used in dry form.

In addition to the evaluation of the gasification operating parameters, 17 system variations were explored to improve the heat rate by:

- air addition to the gasifier
- hydrogen recycle by non-electrochemical means
- altering fuel cell operating conditions
- changing steam addition to the gasifier

Figures 8 and 9 illustrate the effect of air addition to the gasifier. The equilibrium data indicates that air addition significantly lowers the hydrogen recycle rate, but reduces the heat content of the fuel gas. Interestingly, one mole/hr of air offsets ~one mole/hr of hydrogen recycle. The compressions costs would therefore remain approximately constant with savings on hydrogen separation costs. Based on this evaluation, gasifier conditions were chosen at 1200°F, 750 psia, with air addition. The results of these studies are shown in Appendix B.

3.2.2 Case 1 - Recoverable Gasification Catalyst System

The final design configuration for Case 1 was chosen with respect to both heat rate and capital cost considerations. In general, the configurations with the better heat rate were also expected to have higher capital costs. After reviewing the heat rate results from this screening evaluation and qualitatively considering the capital cost impacts, the design which added air to the gasifier and used an HTD for hydrogen separation from the carbonate fuel cell anode exhaust was selected. Figure 10 is a process flow sketch for this configuration and the molar compositions for the numbered streams are listed in Table 3. The Case 1 process is described in detail in Appendix C.

FIGURE 7
EFFECT OF GASIFIER CONDITIONS ON HYDROGEN FEED RATE

(Base Conditions: 500 psia, 1275°F, 7728 lbmol/h Steam)

GASIFIER STEAM AND AIR EFFECT
ON HYDROGEN RECYCLE RATE

GASIFIER STEAM AND AIR EFFECT
ON RAW GAS METHANE CONTENT

FIGURE 8
**GASIFIER STEAM AND AIR EFFECT ON RAW GAS METHANE CONTENT
AND HYDROGEN RECYCLE RATE**

FIGURE 9
EFFECT OF ADDING AIR TO THE GASIFIER

FIGURE 10
CASE 1 – PROCESS FLOW SKETCH

TABLE 3
STREAM FLOW SUMMARY FOR CASE 1
(FIGURE 10)

Stream No.	1	2	3	4	5	6	7	8	9	10
Stream Description	Raw Gas	AGR Feed	Fuel Cell Feed	Anode Exhaust	Shift Exhaust	Recy. Gas	To Cathode	Catalytic Burner Exhaust	Cathode Inlet	Cathode Exhaust
Temp. (F)	1,200	100	1,050	1,250	482	267	392	881	1,050	1,250
Press. (psia)	750.0	700.0	16.1	15.9	14.5	785.0	14.3	16.1	16.1	15.9
MW	21.34	23.13	21.17	32.58	32.58	2.09	34.70	31.08	29.68	28.35
Flow (1000 lb/hr)	279.9	190.0	211.6	774.9	774.9	2.7	762.9	1,865.8	3,652.6	3,089.3
Hydrogen	1,814	1,805	1,805	866	1,610	1,280	330	0	0	0
H2O	4,776	17	2,267	7,611	6,868	6	6,349	6,678	15,838	15,837
Methane	2,232	2,230	2,203	0	0	0	0	0	0	0
CO	427	425	425	790	46	0	46	0	0	0
Moles CO2	2,130	2,068	1,723	12,947	13,690	0	13,690	13,737	19,705	10,319
per Oxygen	0	0	0	0	0	0	0	7,821	12,113	7,420
Hour Nitrogen	1,577	1,572	1,573	1,573	1,573	0	1,573	31,795	75,406	75,406
Ammonia	62	0	0	0	0	0	0	0	0	0
H2S	98	98	0	0	0	0	0	0	0	0
COS	1	0	0	0	0	0	0	0	0	0
HCl	3	0	0	0	0	0	0	0	0	0
Total	13,120	8,216	9,996	23,778	23,787	1,286	21,988	60,031	123,061	108,982
Hydrogen	13.8	22.0	18.1	3.6	6.8	99.5	1.5	0.0	0.0	0.0
H2O	36.4	0.2	22.7	32.0	28.9	0.5	28.9	11.1	12.9	14.5
Methane	17.0	27.1	22.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
CO	3.3	5.2	4.3	3.3	0.2	0.0	0.2	0.0	0.0	0.0
CO2	16.2	25.2	17.2	54.4	57.6	0.0	62.3	22.9	16.0	9.5
Mole Oxygen	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.0	9.8	6.8
% Nitrogen	12.0	19.1	15.7	6.6	6.6	0.0	7.2	53.0	61.3	69.2
Ammonia	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
H2S	0.7	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
COS	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HCl	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

File: C1MBAL.XLS

ENERGY RESEARCH CORPORATION

The power summary results and heat rate comparison for the preliminary Case 1, "HTD Only", and "Air and HTD" systems are presented in Table 4. The calculated heat rate for the "Air and HTD" design compares well with the preliminary Case 1 ("HTD Only") design, improving the heat rate from 7,621 Btu/kWh to 6,606 Btu/kWh. The objectives of reducing the hydrogen recycle requirement by adding air to the gasifier were achieved. This results in a smaller HTD size, a decrease in HTD power requirement (by 80%), and a reduced hydrogen recycle compression power load (by 78%). However, there is the additional need for the gasifier air compression which offsets some of the power reductions. The net reduction in power requirement in the recycle and compression block is about 67%.

The carbonate fuel cell power production increased by 1.1% due to the increase in cell voltage from 0.70 to 0.74 volts. This causes the fuel cell efficiency to improve 5.7% because more power is produced from a feed gas that is 3.1% depleted of its energy due to the air addition, as indicated by the lower cold gas efficiency of the gasifier for the "HTD and Air" Case 1 (Table 4).

The hot gas expander power production increased by ~22%. This is due to both increasing the inlet temperature from 700 F to 1050 F and increasing the throughput by adding air to the gasifier.

Overall, Case 1 has a net power production of 174.1 MW as compared with 150.9 MW for the initial "HTD Only" design. With the same rate of coal input, this results in a heat rate reduction of ~13%. The improvement is due to the 51% reduction in consumption power, most of which is achieved by the reduced hydrogen recycle rate.

TABLE 4
CASE 1 POWER SUMMARY
AND HEAT RATE COMPARISON

Case	HTD Only	HTD and AIR
Gasifier Data		
Temperature (°F)	1,275	1,200
Pressure (psia)	500	750
Recycle from HTD (lb-mol/hr)	6,506	1,282
Raw Gas CH ₄ Content (mol %)	20.5	17.0
Cold Gas Efficiency (%)	95.8	92.9
Heat Rate, HHV (Btu/KWh)	7,621	6,606
Power Summary (MW)		
Production		
Carbonate Fuel Cell	162.1	163.9
Fuel Gas Expander	17.7	21.6
Steam Turbine	15.3	10.1
Total Production	195.1	195.5
Consumption		
HTD	23.7	4.7
H ₂ Recycle Gas Compression	10.7	2.4
Gasifier Air Compression	0.0	4.1
Raw Gas Recycle Compression	0.0	2.1
Cathode Recycle Blower	0.0	1.0
Carbonate Fuel Cell Air Blower	4.9	2.4
Carbonate Fuel Cell Anode Blower	2.0	2.3
Steam and Cooling Water	2.2	1.6
Other	0.8	0.8
Total Consumption	44.3	21.5
Net Power Production	150.9	174.1
Coal Data, "as received"		
Consumption (lb/hr)		
Gasifier	108,592	108,592
Coal Dryer Furnace	5,250	5,250
Total	113,842	113,842
Total Consumption (TPD)	1,366	1,366
HHV (Btu/lb)	10,100	10,100

3.2.3 Case 2 - Disposable Catalyst/ Cold Gas Cleanup

In an effort to make the catalytic gasification process more economically feasible, the use of disposable gasification catalysts was investigated. A literature search was conducted by the University of North Dakota/Energy & Environmental Research Center⁽⁶⁾ to provide recommendations for disposable catalyst options. The results of this study are contained in Appendix D.

Case 2 differs from Case 1 in the use of relatively low cost, disposable limestone (CaCO_3) as the gasification catalyst instead of recoverable potassium carbonate (K_2CO_3). The use of a disposable catalyst was intended to lower plant capital cost by eliminating the catalyst recovery equipment and reducing make-up chemical costs. However, this would be offset by an increase in the gasification cost as limestone is less effective than K_2CO_3 as a gasification catalyst.

A process sketch of this configuration is shown in Figure 11 and the accompanying stream flow summary is listed in Table 5. The design impacts using this configuration are discussed below.

Catalyst Handling

Using a disposable catalyst significantly simplifies the catalyst handling equipment. Limestone is received and stored as a solid containing 95% CaCO_3 . At a rate of 140 tons/day, the catalyst is crushed, mixed with dried coal, and pneumatically conveyed to the gasifier. The ash and spent catalyst leaving the atmospheric fluidized bed combustor (AFBC) is routed directly to slag storage.

Because limestone is received as a solid, the catalyst and coal drying equipment is significantly smaller than Case 1, and the coal feed to the drying furnace is reduced by 45%. As a result, the total "as received" coal feed to the plant fell by 2.5%.

Gasifier Size

Limestone catalyst is not as effective as K_2CO_3 in promoting the steam carbon gasification reactions. Hence, the gasification bed volume must be increased by about a factor of two in order to achieve the same 90% conversion. Due to this increase in bed volume, the limestone catalyzed gasifier requires two gasification trains, each with a 22' ID x 161' T-T gasifier. In comparison, Case 1 uses one train with a 23.5' ID x 125' T-T gasifier. To achieve reasonable gasifier diameters, the Case 2 raw gas recycle rate has increased over 50% from Case 1 (from 1,110,000 lb/hour in Case 1 to 1,686,000 lbs/hour in Case 2).

The additional gasifier train results in an increase in the total heat loss from the gasification unit to the environment, from 25 MM Btu/hour to 51 MM Btu/hour.

FIGURE 11
CASE 2 – PROCESS FLOW SKETCH

TABLE 5
STREAM FLOW SUMMARY FOR CASE 2
(FIGURE 11)

Stream No.	1	2	3	4	5	6	7	8	9	10
Stream Description	Raw Gas	AGR Feed	Fuel Cell Feed	Anode Exhaust	Shift Exhaust	Recy. Gas	To Cathode	Catalytic Burner Exhaust	Cathode Inlet	Cathode Exhaust
Temp. (°F)	1,200	120	1050.0	1250.0	481.9	266.8	392.0	885.2	1050.0	1250.0
Press. (psia)	750	700	16.10	15.92	14.52	785.00	14.25	16.10	16.10	15.92
Molec. Wgt.	21.88	23.03	22.01	32.63	32.63	2.09	34.53	31.09	29.73	28.42
Flow (1000 lb/hr)	306.9	197.9	229.0	766.0	766.0	2.4	756.0	1,812.3	3,523.1	2,986.1
Hydrogen	1,843	1,835	1,835	810	1,532	1,151	382	0	0	0
H2O	4,905	17	1,920	7,069	6,347	5	5,920	6,302	14,755	14,755
Methane	2,090	2,062	2,062	0	0	0	0	0	0	0
CO	447	445	445	768	46	0	46	0	0	0
Moles CO2	2,253	1,823	1,823	12,510	13,232	0	13,232	13,278	19,086	10,137
per Oxygen	0	0	0	0	0	0	0	7,458	11,459	6,985
Hour Nitrogen	2,322	2,316	2,316	2,316	2,316	0	2,316	31,263	73,199	73,199
Ammonia	62	0	0	0	0	0	0	0	0	0
H2S	98	90	98	98	98	98	98	98	98	98
COS	1	1	1	1	1	1	1	1	1	1
HCl	3	3	3	3	3	3	3	3	3	3
Total	14,024	8,592	10,503	23,575	23,575	1,258	21,998	58,402	118,601	105,178
Hydrogen	43.1	21.4	17.5	3.4	6.5	91.5	1.7	0.0	0.0	0.0
H2O	35.0	0.2	18.3	30.0	26.9	0.4	26.9	10.8	12.4	14.0
Methane	14.9	24.0	19.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0
CO	3.2	5.2	4.2	3.3	0.2	0.0	0.2	0.0	0.0	0.0
CO2	16.1	21.2	17.4	53.1	56.1	0.0	60.2	22.7	16.1	9.6
Mole Oxygen	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.8	9.7	6.6
% Nitrogen	16.6	27.0	22.1	9.8	9.8	0.0	10.5	53.5	61.7	69.6
Ammonia	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
H2S	0.7	1.0	0.9	0.4	0.4	7.8	0.4	0.2	0.1	0.1
COS	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0
HCl	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0
Total	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

File: 23MATBAL.XLS

Gasifier Air Rate

As a result of the increased heat loss from the gasifier, the gasification air feed rate has increased by 45%. Increasing the air feed to the gasifier generates more heat from the exothermic partial oxidation reactions but also increases the size of the downstream equipment by 4 to 10%, with the exception of the fuel cell. At the fuel cell, less power is produced because the feed gas has a lower heating value.

3.2.4 Case 3 - Disposable Catalyst/Hot Gas Cleanup

Case 3 is similar to Case 2 with the use of a disposable catalyst, but differs from both Case 1 and 2 by using a hot, zinc ferrite cleanup system. Figure 12 is a process sketch of the Case 3 configuration and Table 6 lists the accompanying material balance summarizing key process streams. The design repercussions of the hot gas cleanup system are discussed below.

Hot Gas Cleanup System

In the hot gas cleanup system, the 1200°F raw gas is first routed through a ceramic filter to remove particulates and then passed through a disposable nacholite chloride guard bed. From the guard bed, the gas is directed to one of two zinc ferrite beds where the bulk of the sulfur is adsorbed. While one bed captures the sulfur, the other bed is regenerated with steam and air. The 1250°F regeneration gas, with sulfur in the form of SO₂, is routed back to the gasifier where the sulfur is adsorbed.

The relatively clean syngas is cooled to 700°F and passed through a disposable zinc oxide bed. This polishing bed lowers the sulfur concentration to 0.35 ppmv. A disposable CuO polishing bed was added upstream of the shift reactor to further reduce the sulfur content to the acceptable level of 0.01 ppmv. This bed was not required with cold gas cleanup systems.

After passing through the zinc oxide bed, the clean fuel is heated to 1050°F and routed to hot fuel gas expansion. The moisture level of this gas is acceptable (35.2%) and therefore fuel gas moisturization is not required to prevent carbon deposition in the carbonate fuel cell unit.

FIGURE 12
CASE 3 - PROCESS FLOW SKETCH

TABLE 6
STREAM FLOW SUMMARY FOR CASE 3
(FIGURE 12)

Stream No.	1	2	3	4	5	6	7	8	9	10
Stream Description	Raw Gas	ZnO Bed Outlet	Fuel Cell Feed	Anode Exhaust	Shift Exhaust	Recy. Gas	To Cathode	Catalytic Burner Exhaust	Cathode Inlet	Cathode Exhaust
Temp. (°F)	1200.00	700.00	1050.00	1250.00	468.60	266.77	392.00	915.05	1050.00	1250.00
Press. (psia)	750	675	16.1	15.9	14.5	785.0	14.3	16.1	16.1	15.9
Molec. Wgt.	21.88	21.79	21.81	31.21	31.21	2.09	32.85	30.58	29.37	27.95
Flow (1000 lb/hr)	306.9	303.4	302.4	845.6	845.6	2.4	832.3	1,901.9	3,393.1	2,849.9
Hydrogen	1,843	1,843	1,843	936	1,568	1,151	417	0	0	0
H2O	4,905	4,905	4,905	9,992	9,360	5	8,753	9,170	19,234	19,234
Methane	2,090	2,090	2,090	0	0	0	0	0	0	0
CO	447	447	447	662	30	0	30	0	0	0
Moles CO2	2,253	2,253	2,253	13,181	13,813	0	13,813	13,842	19,100	10,047
per Oxygen	0	0	0	0	0	0	0	7,544	10,856	6,329
Hour Nitrogen	2,322	2,322	2,322	2,322	2,322	0	2,322	31,629	66,347	66,347
Ammonia	62	62	62	62	62	0	62	0	0	0
H2S	98	0	0	0	0	0	0	0	0	0
COS	1	0	0	0	0	0	0	0	0	0
HCl	3	0	0	0	0	0	0	0	0	0
Total	14,024	13,922	13,922	27,154	27,154	1,156	25,396	62,184	115,537	101,958
Hydrogen	13.1	13.2	13.2	3.4	5.8	99.5	1.6	0.0	0.0	0.0
H2O	35.0	35.2	35.2	36.8	34.5	0.5	34.5	14.7	16.6	18.9
Methane	14.9	15.0	15.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
CO	3.2	3.2	3.2	2.4	0.1	0.0	0.1	0.0	0.0	0.0
CO2	16.1	16.2	16.2	48.5	50.9	0.0	54.4	22.3	16.5	9.9
Mole Oxygen	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.1	9.4	6.2
% Nitrogen	16.6	16.7	16.7	8.6	8.6	0.0	9.1	50.9	57.4	65.1
Ammonia	0.4	0.4	0.4	0.2	0.2	0.0	0.2	0.0	0.0	0.0
H2S	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
COS	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HCl	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

File: 23MATBAL.XLS

4.0 PROGRAM ASSESSMENT

4.1. CASE COMPARISON

4.1.1 Design Comparison

A comparison of the gasifier design parameters for the different configurations is listed in Table 7. The increased air flow to the disposable gasification catalyst systems (Case 2 and 3) lowers the cold gas efficiency ~3%. As stated earlier, the lower reactivity of the disposable gasification catalyst doubles the number of gasifiers needed, each with more than 12% increase in bed volume over the gasifier designed for the recoverable gasification catalyst used in Case 1.

The internal reforming carbonate fuel cell design parameters are compared in Table 8 and a catalyst and chemicals cost comparison is given in Table 9. The total annual cost for catalyst and chemicals for the disposable gasification catalyst configuration is nearly three times lower than the annual costs for the recoverable gasification catalyst configuration. This cost gain is offset in the hot gas cleanup/disposable gasification catalyst configuration by the large quantity of taconite tailings used in the gasifier. Alternate sources of iron and/or lower addition rates if practical, may prove more cost-effective.

4.1.2 Heat Rate Comparison

A detailed heat rate and power summary of the three cases is shown in Table 10. As indicated, the heat rate of Case 3 is 6,377 Btu/kWh, 3.6% lower than Case 1 (6,606 Btu/kWh). This improvement is the result of increased fuel gas expansion power from the higher gas flow. The heat rate for Case 2 is 6,705 Btu/kWh, 1.5% higher than for Case 1. This increase primarily stems from higher gasifier heat loss, and associated increased air usage.

4.1.3 Capital Cost

A relative cost comparison between Case 1 and 2 was performed and is presented in Table 11. In this evaluation the cost of each unit was estimated from the April 1990 TAG II study. Then, the incremental cost between Case 1 and Case 2 was more accurately calculated. The capital costs for Case 2 is predicted to be 1.4% higher than for Case 1.

A conventional cost estimation was not developed for Case 3. The 1990 ERC/Fluor study gave a cost comparison between coal gasification/carbonate fuel cells power plants using cold cleanup and hot cleanup. One of the conclusions from that study was that the capital cost of the design using hot gas cleanup was ~7% lower than the cold gas cleanup configuration.

TABLE 7
GASIFIER DESIGN PARAMETERS

Technology Basis Gasifier Type	Exxon Bubbling Fluidized Bed Catalytic - Dry Ash C-1/2 Mo, Refractory Lined Illinois No. 6 - Bituminous Dense Phase Pneumatic 108,592 Lbs/hr "as received" 62,376 Lbs/hr in Coal		
Materials of Construction Coal Coal Feed Method Coal Feed Rate Carbon Feed Rate			
Case Number	1	2	3
Gas Cleanup Technology	Cold	Cold	Hot
Catalyst	K ₂ CO ₃	CaCO ₃	CaCO ₃ +Fe
Operating Conditions			
Temperature (F)	1200	1200	1200
Pressure (psia)	750	750	750
Cold Gas Efficiency (%)	92.9	90.1	90.1
Raw Gas Flow Rate (Lbs/Lb C)	22.3	18.4	18.4
Raw Gas Methane (Vol %)	17.0	14.9	14.9
Superficial Gas Velocity (ft/s)	1.1	1.1	1.1
Feed Gas Rates (Lbs/Lb C)			
Steam	2.2	2.2	2.2
Air	0.92	1.36	1.36
H ₂ Recycle Gas	0.042	0.038	0.038
Raw Gas Recycle	18	27	27
Catalyst Feed Rate			
K ₂ or Ca (moles/mole C)	0.022	0.022	0.022
Fe (moles/mole S captured)	0	0	2
Total (Lbs/Lb C)	0.25	0.19	0.81
Gasifier Kinetics			
Carbon conversion	90%	90%	90%
Carbon reactivity (1/hr)	0.255	0.103	0.103
Raw Gas Equilibrium Approach (F)			
Shift	-16	-16	-16
COS Hydrolysis	8	8	8
Methanation	24	24	24
Gasifier Size			
Number of Gasifiers	1	2	2
Bed Volume (cu.ft)	38,102	42,785	42,785
Bed Diameter (ft)	22	20	20
Bed Height (ft)	100	136	136
Freeboard (ft)	25	25	25
Total Height, T-T (ft)	125	161	161
Vessel I.D. (ft)	23.5	21.5	21.5

File: GASIF.VK1

TABLE 8
INTERNAL REFORMING CARBONATE FUEL CELL
DESIGN PARAMETERS

Case Number Gas Cleanup Technology Catalyst	HO Cold K ₂ CO ₃	1 Cold K ₂ CO ₃	2 Cold CaCO ₃	3 Hot CaCO ₃ +Fe
Developer	ERC	ERC	ERC	ERC
Operating Conditions				
Inlet Temperature (F)	1,050	1,050	1,050	1,050
Outlet Temperature (F)	1,250	1,250	1,250	1,250
Pressure (psia)	16	16	16	16
Methane in Feed (vol %)	25.4	22.0	19.8	15.1
Power Production (MW DC)	166.4	168.8	161.0	162.9
Fuel Utilization (%)				
Per Pass	57.4	85.0	85.0	85.0
Overall	92.6	96.3	96.3	96.3
Oxygen Utilization (%)	30.7	60.0	60.0	60.0
Cell Voltage (volts)	0.70	0.74	0.74	0.74
Current Density (ASF)	281.0	165.5	170.9	158.6
Physical Configuration				
Active Cell Area (MM ft ²)	0.85	1.38	1.27	1.39
Cell Size (ft x ft)	2 x 3	2 x 3	2 x 3	2 x 3
Number of Cells	151,524	246,938	228,141	248,641
Cells Per Stack	301	286	302	288
Number of Stacks	504	864	756	864
Stacks Per Module	12	12	12	12
Number of Modules	42	72	63	72
Modules Per Train	14	24	21	24
Number of Trains	3	3	3	3
Power Per Train (MW AC)	54.0	54.6	52.1	52.7

File: STUDY.WK1

TABLE 9
CATALYST AND CHEMICALS COMPARISON
(Costs are in 1988 \$)

Catalyst or Chemical	Unit Cost (\$)	Units	Case 1				Case 2				Case 3				
			Initial		Annual		Initial		Annual		Initial		Annual		
			Usage	Cost (\$)	Usage	Cost (\$)	Usage	Cost (\$)	Usage	Cost (\$)	Usage	Cost (\$)	Usage	Cost (\$)	
Gasification															
KOH	\$174.00	Tons	3,544	616,608	18,478	3,215,172	0	0	0	0	0	0	0	0	0
Quicklime	\$42.00	Tons	2,456	103,170	29,477	1,238,034	0	0	0	0	0	0	0	0	0
Limestone	\$20.00	Tons	0	0	0	0	4,252	85,042	51,025	1,020,500	4,252	85,042	51,025	1,020,500	0
Tachonite (51.8% Fe)	\$27.64	Tons	0	0	0	0	0	0	0	0	0	0	0	0	0
Gas clean-up															
AGR solvent	\$1.37	Lbs	138,361	189,547	13,356	18,297	138,361	189,547	13,356	18,297	0	0	0	0	0
COS hydrolysis	\$377.92	CF	1,103	416,843	367	138,696	1,103	416,843	367	138,696	0	0	0	0	0
Sulfur Polishing	\$145.00	CF	2,335	338,575	467	67,715	2,335	338,575	467	67,715	15,886	2,303,470	2,763	400,835	0
Zn-Fe	\$242.00	CF	0	0	0	0	0	0	0	0	1,966	475,811	3,837	928,583	0
Chlorine Guard	\$99.32	Tons	0	0	0	0	0	0	0	0	57	5,661	1,278	126,926	0
Claus catalyst	\$33.00	CF	850	28,048	200	6,600	850	28,048	200	6,600	0	0	0	0	0
SCOT catalyst	\$117.03	CF	32	3,745	7	819	32	3,745	7	819	0	0	0	0	0
SCOT solvent	\$1.43	Lbs	2,409	3,445	708	1,012	2,409	3,445	708	1,012	0	0	0	0	0
Fuel Cell Unit															
HTD shift catalyst	\$260.00	CF	4,514	1,173,532	903	234,706	4,473	1,163,073	895	232,615	5,152	1,339,643	1,030	267,929	0
Sulfur polishing	\$260.00	CF	0	0	0	0	0	0	0	0	1,288	334,911	258	66,362	0
Balance of plant	-	-	-	83,336	-	437,771	-	83,336	-	437,771	-	83,336	-	437,771	0
Total (100% capacity)	-	-	-	2,958,848	-	5,358,822	-	2,311,653	-	1,924,025	-	4,881,524	-	6,293,150	0
Total (85% capacity)	-	-	-	-	-	4,554,999	-	-	-	1,635,421	-	-	-	5,349,177	0

15-JUL-91 FILE: KVLCHEN.WK1

TABLE 10
POWER SUMMARY AND
HEAT RATE COMPARISON

Case Gas Cleanup Technology Catalyst	Case 1 Cold K ₂ CO ₃	Case 2 Cold CaCO ₃	Case 3 Hot CaCO ₃ +Fe
Gasifier Data			
Temperature (°F)	1,200	1,200	1,200
Pressure (psia)	750	750	750
Recycle from HTD (lb-mol/h)	1,282	1,154	1,154
Raw Gas CH ₄ Content (mol %)	17.0	14.9	14.9
Cold Gas Efficiency (%)	92.9	90.1	90.1
Heat Rate, HHV (Btu/kWh)	6,606	6,748	6,377
Power Summary (MW)			
Production			
Carbonate Fuel Cell	163.9	156.3	158.1
Fuel Gas Expander	21.6	22.4	29.7
Steam Turbine	10.1	11.0	11.4
Total Production	195.5	189.8	199.2
Consumption			
HTD	4.7	4.2	4.2
H ₂ Recycle Gas Compression	2.4	2.2	2.2
Gasifier Air Compression	4.1	6.0	6.0
Raw Gas Recycle Compression	2.1	3.1	3.1
Cathode Recycle Blower	1.0	1.0	0.9
Carbonate Fuel Cell Air Blower	2.4	2.3	2.4
Carbonate Fuel Cell Anode Blower	2.3	2.3	2.6
Steam and Cooling Water	1.6	1.7	1.2
Other	0.8	0.8	0.8
Total Consumption	21.5	23.7	23.5
Net Power Production	174.1	166.1	175.7
Coal Data, "as received"			
Consumption (lb/h)			
Gasifier	108,592	108,592	108,592
Coal Dryer Furnace	5,250	2,366	2,366
Total	113,842	110,958	110,958
Total Consumption (TPD)	1,366	1,331	1,331
HHV (Btu/lb)	10,100	10,100	10,100

TABLE 11
RELATIVE CAPITAL COST COMPARISON
CASE 1 - CASE 2

Case Number	1	2	DELTA
Gas Cleanup Technology	Cold	Cold	-
Catalyst	K ₂ CO ₃	CaCO ₃	-
Gasification + Gas Cleanup			
Coal Preparation	5.6	5.5	0.1
Catalyst System	5.0	0.0	5.0
Air Compression	1.1	1.7	-0.6
Raw Gas Compression	1.6	2.5	-0.9
Gasification	17.3	23.4	-6.1
AFBC	2.7	2.9	-0.2
Ash Handling & Disposal	1.1	0.9	0.2
Raw Gas Cooling/Scrubbing	4.6	4.9	-0.3
Acid Gas Removal	2.6	2.6	0.0
Sulfur Recovery	1.6	1.6	0.0
Total	43.2	46.0	-2.7
Fuel Cell Power Block			
Cell Stacks	6.7	6.3	0.4
Piping & Equipment	6.0	6.0	0.0
Power Conditioning	12.2	11.7	0.5
Total	25.0	24.1	0.9
Recycle Gas System			
H ₂ Separation	4.3	4.0	0.4
Compression	0.8	0.8	0.0
Heating	1.5	1.3	0.2
Total	6.6	6.0	0.6
Turbine Power Generation			
Fuel Gas Expander	2.3	2.4	-0.1
Steam Turbine	1.9	2.1	-0.2
HRSG	2.0	1.9	0.0
Total	6.2	6.4	-0.2
General Facilities	19.0	19.0	0.0
Total	100.0	101.4	-1.4

* The relative cost comparison shown is on an absolute dollar basis. Plant size for the two cases is the same based on a coal feed rate to the gasifier, although Case 2 produces less power. On a \$/kW basis Case 2 is 6.3% higher than for Case 1.

FILE: KvLS.WP.1
03-Sep-91

The relative capital cost comparison for Cases 1 and 2 indicate that the cold gas cleanup units (Raw Gas Cooling and Scrubbing, Acid Gas Removal, and Sulfur Recovery) comprise about 9% of the total capital cost. If these units were eliminated and replaced with the hot gas cleanup reactors, the total capital cost could conceivably drop by 7%. Based on these two data points, the capital cost for Case 3 is assumed to be 7% lower than Case 2, but still 1.3% higher than Case 1. These percentages further assume that the same contingency is applied to each case. If a more detailed analysis were to be performed, Case 3 would likely be assigned a higher contingency because the hot gas cleanup technology is less developed than the cold gas cleanup processes.

4.1.4 Cost of Electricity

The relative cost of electricity (COE) between Cases 1 and 2 was calculated. In this evaluation, the COE for Case 1 was based on the TAG II Exxon catalytic system ECS Case⁽¹⁾. Adjustments were made for capital cost, catalyst and chemical cost, fuel cell replacement cost, power output, and fuel consumption. Adjustments were also made to make the COE analysis consistent with the 1989 EPRI Technical Assessment Guide and a June 1991 time frame. The Case 2 COE was then calculated by adjusting the Case 1 input to reflect the higher heat rate, higher capital cost, lower catalyst and chemical costs and reduced fuel cell area. The calculated COE for Case 2 was approximately one-third higher than the COE for Case 1.

The relative COE for Case 3 was calculated in a similar manner as for Case 2. The results show that the COE for Case 3 is over 4% lower than for Case 2 and over 3% lower than for Case 1.

4.2 SYSTEM COMPARISON

Three competitive coal-based power generation technologies were selected to provide data for the competitive position of the internal reforming coal gasification/carbonate fuel cell technology. The selected technologies included:

- Atmospheric Fluidized Bed Combustion (AFBC)
- Pulverized Coal Combustion Boiler/Flue Gas Desulfurization (PC/FGD)
- Integrated Gasification Combined Cycle (IGCC)

Data for this comparison was taken from the 1990 ERC/Fluor⁽¹⁾ study. PC with FGD is the industry standard for producing electrical power from coal. AFBC is a more recently developed technology having lower NO_x and SO_x emissions due to a lower bed temperature and in-bed desulfurization. The IGCC is a developmental application of gas turbines to coal gas systems slated for introduction into the commercial market in the mid 1990's. The performance of all the competing systems was at approximately the same net power production as the three cases configured in this study, 200 MW. The technologies were compared on two issues:

- Heat Rate
- Environmental Impact

4.2.1 Heat Rate Comparison

The heat rates of the coal gasification/fuel cell systems are compared to competing technologies in Table 12 on a higher heating value basis (HHV). The AFBC and PC cases have two cases each. One is with 90% sulfur recovery and one with 98% and 96% respectively. The latter were intended to meet the stringent new source performance standard (NSPS) of 95% sulfur removal. The integrated coal gasification/fuel cell systems are superior in heat rate when compared to any of the competing technologies. The heat rate of the three case studies range from 36 to 40% lower than the pulverized coal with coal cleanup and wet flue gas desulfurization (6,377 - 6,748 versus 10,571 Btu/kWh) and ~33% lower than the AFBC without the added expenditure of increased coal cleanup. The heat rate of the advanced IGCC system (8420 Btu/kWh), based on KRW gasification and hot gas cleanup, is 20 to 24% higher than the heat rate of the three case studies. Integrated gasification/fuel cell systems therefore offer significant efficiency advantages over the competing systems shown.

TABLE 12
HEAT RATE COMPARISON WITH COMPETING SYSTEMS

TECHNOLOGY	Integrated Gasification/Fuel Cell Systems			Competing Systems				
	Case 1	Case 2	Case 3	IGCC	AFBC ⁽¹⁾	AFBC ⁽²⁾	PC ⁽¹⁾	PC ⁽³⁾
	Recoverable Catalyst Cold Gas Cleanup	Disposable Catalyst Cold Gas Cleanup	Disposable Catalyst Hot Gas Cleanup	KRW Cryogenic Oxygen Blown Hot Gas Cleanup	In-Bed Desulfurization	Coal Cleanup with In-Bed Desulfurization	Wet FGD Cleanup	Coal Gas Cleanup with Wet FGD and Catalytic DeNO _x
Heat Rate (I-HV), Btu/kWh	6,606	6,748	6,377	8,420	10,120	10,780	9,928	10,571

(1) 90% Sulfur Recovery

(2) 98% Sulfur Recovery

(3) 96% Sulfur Recovery

4.2.2 Environmental Impact Comparison

Today's power generation systems must not only be efficient and cost effective but also environmentally benign. The amount of SO_x , NO_x , and CO_2 a facility emits along with the amount of makeup water it uses are important issues to consider. The environmental impact of the different technologies is listed in Table 13. In all aspects compared, the integrated coal gasification/carbonate fuel cell concept proved to be a much cleaner power generation system.

The sulfur cleanup and recovery system in the integrated coal gasification/carbonate fuel cell technology results in sulfur emissions of less than 0.1% of the feed (<0.02 lb/MWh). This is well below future stringent emissions requirements. Other technologies in use today cannot compare with this low figure, having sulfur emissions ranging up to two orders of magnitude greater. Today, PC and AFBC power generation systems emit up to 10% of the sulfur in the feed (up to 4 lb/MWh). This figure can be lowered from 2 to 4% with coal cleanup systems, but still remains much higher than the integrated coal gasification/carbonate fuel cell systems. Even though the advanced IGCC system has a relatively low sulfur emissions value (0.08 lb/MWh), it is four times higher than the case studies.

The coal gasification/carbonate fuel system emits much lower levels of NO_x than the alternative power generation systems (trace levels as compared with up to 1.1 lb/MWh). Carbon dioxide emissions are also much lower for the case studies, ranging from 25 to 38% lower than the competing systems. CO_2 emissions of integrated gasification/carbonate fuel cell systems are also 18% lower than conventional gasification/carbonate fuel cell systems due to improved efficiencies and lower oxygen consumption in the gasifier. The makeup water for the case studies, taken from the Case 1 steam balance, was only 20-24% of the other competing systems.

Integrated gasification/carbonate fuel cell systems therefore have minimal impact on the environment compared to other coal-based power generating technologies.

TABLE 13
ENVIRONMENTAL IMPACT COMPARISON WITH COMPETING SYSTEMS

TECHNOLOGY	Integrated Gasification/Fuel Cell Systems			Competing Systems				
	Case 1	Case 2	Case 3	IGCC	AFBC ⁽¹⁾	AFBC ⁽²⁾	PC ⁽¹⁾	PC ⁽³⁾
Description	Recoverable Catalyst Cold Gas Cleanup	Disposable Catalyst Cold Gas Cleanup	Disposable Catalyst Hot Gas Cleanup	KRW Cryogenic Oxygen Blown Hot Gas Cleanup	In-Bed Desulfurization	Coal Cleanup with In-Bed Desulfurization	Wet FGD Cleanup	Coal Cleanup with Wet FGD and Catalytic DeNO _x
Sulfur Released (lb/MWh)	< 0.02	< 0.02	< 0.02	0.08	4.00	1.80	3.93	0.79
NO _x (lb/MWh)	0.08	0.08	0.08	1.01	0.81	0.81	6.1	1.1
CO ₂ (lb/MWh)	1322	1387	1313	1857	2107	2107	2070	2070
Makeup Water (lb/MWh)	1188	—	—	4807	4857	5007	5858	6008

(1) 90% Sulfur Recovery
(2) 98% Sulfur Recovery
(3) 96% Sulfur Recovery

5.0 CONCLUSIONS AND RECOMMENDATIONS

The integration of developmental catalytic gasification with carbonate fuel cells can potentially improve the performance and efficiency of future power generation plants. The catalytic low temperature gasification of coal offers the potential of more efficient gasification at temperatures more compatible with the operating temperatures of carbonate fuel cells and integration with fuel cell exhaust streams. This study was designed to evaluate the potential of integrating carbonate fuel cells with the gasification process to obtain a more efficient and cost effective system. Two basic approaches were considered: one which recycles fuel cell anode exhaust to a low pressure gasifier, "high-hydrogen approach", and one which separates hydrogen from fuel cell exhaust for recycle to a high pressure gasifier, "high-methane approach". The latter was selected for further study because of higher efficiency and lower cost. Using the selected approach three cases were evaluated:

- Case 1 - a recoverable gasification catalyst case with cold cleanup.
- Case 2 - a disposable gasification catalyst case with cold cleanup.
- Case 3 - a disposable gasification catalyst case with hot cleanup.

Both recoverable and disposable gasification catalysts were considered with the potential that disposable catalysts can offer advantages by eliminating the catalyst recovery steps required for recoverable catalysts. Limited experimental testing by TGA was conducted to supplement the literature survey and to assist in making disposable catalyst recommendations. In addition, both hot and cold cleanup systems were also evaluated.

Conclusions relating to system configuration and gasifier design are summarized below.

SYSTEM CONFIGURATION

- Catalytic gasification systems integrated with carbonate fuel cells offer the potential of 53.5% efficiency (HHV). This is an improvement of 3.8 percentage points compared to conventional gasification/carbonate fuel cell systems with 49.7% HHV system efficiency.
- The recoverable gasification catalyst/carbonate fuel cell system with cold gas cleanup has a slight advantage in terms of cost and efficiency compared to a disposable gasification catalyst system with cold cleanup, due to higher activity.
- The disposable gasification catalyst/carbonate fuel cell system with hot gas cleanup has a 3.5% higher efficiency and an estimated 7% lower capital cost compared the recoverable gasification catalyst system.
- Hot Gas Cleanup produced the highest system efficiency (53.5% HHV) with a 2.9 percentage point improvement over the cold cleanup system (efficiency 50.6%).
- The COE for the disposable gasification catalyst case with hot gas cleanup is 5% lower than for the disposable gasification catalyst with cold cleanup and 3% lower than the COE for the recoverable gasification catalyst case with cold cleanup.

- The high-methane gasification system configuration appears advantageous over the high-hydrogen gasification configuration.
 - Efficiency of the high-methane system is 40% higher and the capital cost is 29% lower compared to the high-hydrogen system.
 - The energy requirement for carbon dioxide separation step in the high-hydrogen case, based on conventional technology, is primarily responsible for the lower efficiency. Development of future technologies that are less energy intensive may change these results.
 - The high throughput, low pressure, and CO₂ removal of the high-hydrogen gasification system more than doubles the capital cost of the gasification and cleanup system compared to the high-methane case.

GASIFICATION

- The hydrogen requirement of the catalytic gasifier at the baseline conditions (500 psia, and 1275 F) imposed a significant power requirement for hydrogen separation and recompression. Lower hydrogen recycle rates, and hence lower heat rates, were obtained by reducing the gasifier temperature from 1275 to 1200 F, increasing the gasifier pressure from 500 to 750 psia and by adding air to the gasifier.
- Disposable catalysts such as limestone or iron-based catalysts in dry form are not as active as potassium carbonate and require larger gasifiers to maintain the required residence time. Higher gasification temperatures and/or more intimate penetration into the coal may be required to make these catalysts more competitive.

5.1 RECOMMENDATIONS

The utilization of low-temperature catalytic gasification offers the potential of efficiency and cost advantages over conventional gasification. The thermochemical integration of catalytic gasification with carbonate fuel cells makes it possible to attain higher overall system efficiencies. The gasification process efficiency improves by promoting the formation of methane and minimizing or eliminating the use of oxygen or air in the gasifier. This has the potential of eliminating the need for oxygen plants or air compressors for gasification power plants offering both cost and efficiency improvements. The resulting high-methane fuel gas when utilized by an internal reforming carbonate fuel cell results in an overall more efficient coal to bus bar conversion efficiency.

Specific recommendations of this study are:

- Development and optimization of high-methane producing gasifiers should be encouraged.
- Continue development of the H₂ separation device and internal reforming carbonate fuel cells.
- Experimental testing is required to assess the impact on gasification kinetics and hence gasifier sizing of disposable gasification catalysts such as limestone, taconite and possibly others.

ENERGY RESEARCH CORPORATION

- Experimental testing and development of catalytic gasification catalysts with activities approaching or surpassing the activity of potassium carbonate are required. Preferably these catalysts should be of sufficiently low cost to allow disposal with the coal ash. This would simplify the plant by avoiding a catalyst recovery step.
- Experimental testing should include simulation of thermal and chemical recycle streams to the gasifier, such as hydrogen.
- Hybrid catalysts incorporating some potassium carbonate should be investigated if satisfactory results cannot be obtained with other alternatives.
- The thermodynamics and kinetics of gasification and in-situ sulfur capture at low temperatures must be evaluated further to establish the feasibility of simultaneous gasification/sulfur capture by a catalyst/sorbent.
- Based on data from experimental testing a more detailed capital cost and cost of electricity must be established for these types of systems to make a more detailed comparison to other systems.
- Alternate system concepts and configurations should be evaluated further to explore ways to improve efficiency and reduce cost of future advanced systems.
- Extension of currently available technologies should be encouraged to make available technologies such as high temperature expanders for these type of systems.

REFERENCES

1. Energy Research Corporation and Fluor Daniel, "Assessment of Coal Gasification/Carbonate Fuel Cell Power Plants," Final Topical Report submitted to DOE/METC, Contract No. DE-AC21-87MC23274 (June 1990).
2. Exxon Research and Engineering Company, Baytown, Texas, "Exxon Catalytic Coal Gasification Process Predevelopment Program," Final Project Report, Contract No. EX-76-C-01-2369 (Dec. 1978).
3. Gmeindl F.D., R.A. Geirsbrecht, K.R. Craig, S. Kasper, Morgantown Energy Technology Center; V.N. Shah, EG&G Washington Analytical Services, "New Directions in Molten Carbonate Fuel Cell Systems," Proceedings of the Ninth Annual Gasification and Gas Stream Cleanup Systems Contractors Review Meeting, Morgantown, WV, June 1989. Report No. DOE/METC-89/6107, Vol 2 (Order No. DE89011707).
4. United Technologies Corporation, "The Study of Integrated Coal Gasifier Molten Carbonate Fuel Cell Systems," Final Technical Report prepared for the Jet Propulsion Laboratory (July 10, 1983).
5. Energy Research Corporation, "High Efficiency CGMCFC Power Plant System Using Methane Producing Gasifier," U.S. Patent Application in preparation.
6. Sondreal E., W. Wilson, R. Timpe, S. Cisney, W. Hauserman, "Recommendations for Disposable Gasification Catalysts to Optimize Integrated Gasifier/Fuel Cell Systems," submitted to Energy Research Corporation, Jan. 1991.
7. Energy Research Corporation and Fluor Daniel, "100MW Class Fuel Cell Power Plant Commercialization Activities," in process, DOE/METC Contract No. DE-AC21-90MC27168.

APPENDIX A

High-Methane vs. High-Hydrogen Gasification

The purpose of this study was to determine the merits of two alternative design approaches for utility based power plants using integrated coal gasification/carbonate fuel cells. This screening evaluation was used to select the design approach for the remaining case studies. The two alternatives are described below. Case A is a high CH_4 approach and Case B and C are two variations on the high H_2 design. A process sketch, material balance, and estimated power summary for each case is attached.

CASE DESCRIPTION

Case A - High Methane

In this alternative, a high pressure (500 psia) catalytic gasifier converts coal, steam, and hydrogen recycle gas to raw syngas. High operating pressure was selected to promote high-methane production. The raw syngas is cooled, cleaned, and expanded then fed to the carbonate fuel cells. The anode exhaust is fed through a shift reactor and a hydrogen transfer device (HTD). The separated hydrogen is recompressed and recycled to the gasifier. The H_2 depleted gas is routed to the cathode. This configuration is shown in Figure A-1 and the materials balance of the process flow streams is given in Table A-1.

The catalytic gasifier was simulated using an equilibrium gasifier model. Using gasifier operating conditions, carbon conversion and feed stream data, the C-H-O content of the raw gas is calculated. The raw gas composition is then computed through simultaneous solution of the equilibrium reactions for shift methanation, and COS hydrolysis. The heat loss is calculated and the flow rate of the recycle gas adjusted until the heat loss equals a predetermined value.

The process units between the gasifier and the fuel cell are fairly conventional. The acid gas removal is accomplished with a DOW GAS/SPEC process. Fuel gas moisturization levels are set to avoid carbon deposition. The fuel gas expansion is accomplished in a two stage expander with a 700°F inlet temperature.

The carbonate fuel cell operates between 1050°F and 1250°F at atmospheric pressure. The cell voltage is set at 0.7 volts and the fuel utilization of 52%. The hydrogen from the fuel cell exhaust is the fuel in the recycle gas and thus the low utilization is dictated by the required H_2 recycle rate to the gasifier.

A low-temperature shift reactor is provided upstream of the HTD thereby increasing the hydrogen content of the stream while also decreasing the CO content. This improves HTD performance which is inhibited by high CO concentrations. The shift reactor is designed for a 400°F inlet and a 25°F approach temperature.

The hydrogen transfer device (HTD) separates 92% of the H_2 from the shift reactor effluent. The HTD is based on phosphoric acid technology to electrochemically separate hydrogen. It operates at a 342°F inlet temperature and a 392°F outlet temperature while consuming ~30 MW of DC power. Waste heat from the HTD is used to preheat carbonate fuel cell air.

The H_2 compression unit increases the pressure of the H_2 rich stream from 16 psia to ~550 psia in a four stage compressor. Compressor inlet temperatures are maintained at 95°F with precoolers and intercoolers.

FIGURE A-1
CASE A - HIGH CH₄ - BLOCK FLOW DIAGRAM

TABLE A-1
HIGH H₂ vs. HIGH CH₄ STUDY
MATERIAL BALANCE
FOR FIGURES A-1, A-2, A-3

Stream Number		1	2	3	4	5	6	7
Stream Description		Raw Gas	AGR Feed	CFC Feed	Anode Out	Shift Out	Recycle Gas	To Cathode
Case A, High CH₄								
Lb Mol/Hr	H ₂	5,070	5,070	5,070	5,658	8,454	8,170	284
	H ₂ O	6,394	0	3,542	9,595	6,799	80	4,363
	CH ₄	3,336	3,336	3,336	15	15	0	15
	CO	482	482	482	3,441	645	0	645
	CO ₂	<u>948</u>	<u>948</u>	<u>790</u>	<u>10,887</u>	<u>13,683</u>	<u>0</u>	<u>13,683</u>
	Total	16,230	9,836	13,220	29,596	29,596	8,250	18,990
Mole %	H ₂	31.2	51.5	38.4	19.1	28.6	99.0	1.5
	H ₂ O	39.4	0.0	26.8	32.4	23.0	1.0	23.0
	CH ₄	20.6	33.9	25.2	0.1	0.1	0.0	0.1
	CO	3.0	4.9	3.6	11.6	2.2	0.0	3.4
	CO ₂	<u>5.8</u>	<u>9.6</u>	<u>6.0</u>	<u>36.8</u>	<u>46.2</u>	<u>0.0</u>	<u>72.1</u>
	Total	100.0	100.0	100.0	100.0	100.0	100.0	100.0
Case B, High H₂ - With Shift								
Lb Mol/Hr	H ₂	11,868	17,990	17,990	16,943	-	16,943	0
	H ₂ O	7,900	0	3,733	11,962	-	739	0
	CH ₄	3,810	3,810	3,810	219	-	219	0
	CO	8,762	2,639	2,639	7,320	-	7,320	0
	CO ₂	<u>9,092</u>	<u>15,217</u>	<u>0</u>	<u>9,640</u>	-	<u>9,640</u>	<u>15,217</u>
	Total	41,432	39,656	28,172	46,084	-	34,861	15,217
Mole %	H ₂	28.6	45.4	63.9	36.8	-	48.6	0.0
	H ₂ O	19.1	0.0	13.3	26.0	-	2.1	0.0
	CH ₄	9.2	9.6	13.5	0.5	-	0.6	0.0
	CO	21.1	6.7	9.4	15.9	-	21.0	0.0
	CO ₂	<u>21.9</u>	<u>38.4</u>	<u>0.0</u>	<u>20.9</u>	-	<u>27.7</u>	<u>100.0</u>
	Total	100.0	100.0	100.0	100.0	-	100.0	100.0
Case C, High H₂ - No Shift								
Lb Mol/Hr	H ₂	14,170	14,170	14,170	20,791	-	20,791	0
	H ₂ O	8,984	0	12,782	13,712	-	1,118	0
	CH ₄	4,103	4,103	4,103	328	-	328	0
	CO	15,946	15,946	15,946	13,676	-	13,676	0
	CO ₂	<u>15,759</u>	<u>15,759</u>	<u>0</u>	<u>16,824</u>	-	<u>16,824</u>	<u>15,759</u>
	Total	58,962	49,978	47,001	65,331	-	52,737	15,759
Mole %	H ₂	24.0	28.4	30.1	31.8	-	39.4	0.0
	H ₂ O	15.2	0.0	27.2	21.0	-	2.1	0.0
	CH ₄	7.0	8.2	8.7	0.5	-	0.6	0.0
	CO	27.0	31.9	33.9	20.9	-	25.9	0.0
	CO ₂	<u>26.7</u>	<u>31.5</u>	<u>0.0</u>	<u>25.8</u>	-	<u>31.9</u>	<u>100.0</u>
	Total	100.0	100.0	100.0	100.0	-	100.0	100.0

Case B - High Hydrogen with Shift

In this alternative, a low pressure (88 psia) catalytic gasifier converts coal, steam and anode exhaust to raw syngas. The low pressure was selected to promote hydrogen production. The raw gas is quenched and shifted. Sulfur is removed from the shifted gas with an iron chelate absorption process and then CO_2 is removed with an amine unit. The CO_2 is routed to the carbonate fuel cell cathode while the rest of the fuel gas is expanded then fed to the carbonate fuel cell anode. The anode exhaust is compressed and recycled to the gasifier. A block diagram of this approach is illustrated in Figure A-2 and the material balance for the process flow streams is listed in Table A-1.

The catalytic gasifier was again simulated using the equilibrium based gasifier model. The gasifier design parameters were kept the same as for Case A except for the operating pressure and recycle gas composition. The raw gas rate of the resulting design is about 14 times larger than Case A on a volumetric basis (~2.5 times larger on a molar basis). Case B would therefore require five 22'ID x 34'T-T gasifiers, while Case A could use one 14'ID x 137'T-T gasifier.

The raw gas shift reactor maximizes the CO_2 content of the amine unit feed. This improves the effectiveness of the CO_2 separation, which therefore reduces the recycle gas and raw gas flow rates by ~50%. This effect is fully realized by comparing Case B to Case C. The shift reactor is the only configuration difference between the two cases. The shift reactor was designed for an inlet temperature of 400 F and a 50 F approach to equilibrium.

An iron chelate absorption process, Sulferox, removes about 34 long TPD of sulfur from the shifted gas. Unlike amine processes, Sulferox does not absorb CO_2 and therefore allows the clean CO_2 to be removed downstream by the chemical absorption process. Sulferox is not cost effective for large gas cleanup operations where significant CO_2 absorption can be tolerated, but was recommended by DOW for this application as CO_2 is removed downstream by the amine unit.

The amine unit utilized DOE GAS/SPEC (MDEA) technology to separate over 15,000 MPH of CO_2 from the cleaned syngas. The Case A GAS/SPEC unit absorbed about 250 MPH of CO_2 plus H_2S . DOW indicated that about 1,400 MPH of CO_2 would remain in the fuel gas, however for this evaluation the limiting case was assumed that all of the CO_2 would be removed. The separated CO_2 is mixed with air and routed to the carbonate fuel cell cathode.

As in Case A, fuel gas moisturization levels are set to avoid carbon deposition at the carbonate fuel cell anode. The fuel gas expansion was accomplished in a single stage expander with inlet temperatures of 700 F.

The operating conditions for the carbonate fuel cells were the same as in Case A except for fuel utilization. In this design, a lower utilization of 30% is needed to increase the fuel value of the anode exhaust gas recycled to the gasifier. In Case A, the flow rate of the H_2 recycle was adjusted in order to bring the gasifier into heat balance. For Case B, the heat was balanced by also adjusting the fuel value of the anode exhaust gas.

The recycle gas compression unit raises the pressure of the anode exhaust gas from 16 psia to ~100 psia in a two stage compressor. Compressor inlet temperatures are maintained at 95 F with precoolers and intercoolers.

Case C - High Hydrogen Without Shift

As stated above, Case C is nearly identical to Case B with the exception that this case does not have a shift reactor upstream of the CO₂ unit. This results in a 50% increase in the raw gas and recycle gas flow rates because less CO₂ is removed and sent to the cathode side of the fuel cell. Case C is illustrated in Figure A-3 and the material balance of the process flow streams is listed in Table A-1.

Case Evaluation

The heat rate for each case was evaluated and the results are shown in Table A-2. The power consumption and production was calculated based on the material balance for each case. The balance of plant power consumption was estimated from the TAG II Exxon case from the 1990 ERC/METC study⁽¹⁾.

The Case A steam turbine power was estimated by performing an overall heat balance and assuming a reasonable steam cycle efficiency. In order to determine if the high H₂ cases (Cases B and C) include steam power generation, an incremental heat balance was developed. These included the following:

- Latent heat of HRSG stack gas.
- Low pressure steam consumed by the CO₂ removal unit.
- Process condensation from raw gas cooling. In Case A, it was assumed that all this heat could be recovered. In Cases B and C, the process condensation temperature is below 200°F, which is too low to recover all the heat. Therefore it was assumed that the heat would be lost unless it could be used for fuel gas saturation heating.
- Process condensation from the recycle gas compression unit.

As shown in Table A-2, the high H₂ cases have much less waste heat available than Case A (about 850 MM Btu/h). This difference is primarily due to the steam requirement for the CO₂ separation unit (713 MM Btu/h). Since Case A had only 215 MM Btu/h of waste heat, the high H₂ cases would need another source of heat to produce power at the levels indicated. In order to calculate the heat rate of this evaluation, it was assumed that coal would be burned to generate this heat.

As shown in Table A-3, the heat rates obtained for Cases B and C are about 42 % worse than for Case A (7,943 Btu/kWh for Case A as opposed to 11,167 and 11,341 Btu/kWh for Cases B and C respectively). These high rates are essentially due to the 55% higher coal feed rate and only 9% higher power production of the high-hydrogen cases compared to the high-methane case.

An evaluation of these results showed that the higher power production was offset by the increased coal rate in terms of the COE. The high H₂ approach would have about the same COE as the high-methane approach, as long as the installed capital costs were about the same.

A relative cost comparison was performed between Case A and B, and is listed in Table A-4. The installation costs of the high H₂ design are ~42% greater than for the high CH₄ design. The cost of the CO₂ separation and the increased cost of gasification outweigh the saving in the H₂ separation area.

Based on the magnitude of both the capital cost difference and the heat rate comparison, the high CH₄ approach, Case A, was selected for the follow-on studies.

FIGURE A-3
CASE C - HIGH H₂ NO SHIFT- BLOCK FLOW DIAGRAM

TABLE A-2
POWER SUMMARY AND ESTIMATED
HEAT RATE COMPARISON
HIGH CH₄ vs. HIGH H₂

CASE High CH ₄ or H ₂ Case Raw Gas Shift Reactor	A CH ₄ No	B H ₂ Yes	C H ₂ No
Power Summary (MW)			
Production			
Carbonate Fuel Cell	162	177	177
Expander	18	20	33
Steam Turbine	16	0	0
Total	196	197	210
Consumption			
HTD	30	0	0
Recycle Compressors	14	30	45
Balance of Plant	7	7	7
Total	51	37	52
Net Power Generation	145	160	158
Heat Losses (MM Btu/h)			
HRSG Stack Water	66	0	0
Amine Unit Steam	20	713	713
Raw Gas Condensate, unrecovered	0	48	26
Recycle Gas, Condensate	46	222	249
Total	131	983	988
Incremental, relative to Case A	---	852	857
Fuel Input (MM Btu/h)			
Gasification	1,150	1,150	1,150
Steam Production			
Incremental Heat Loss	---	852	857
Available from Bottoming Cycle	---	215	215
Total Required	---	637	642
Total	1,150	1,787	1,792
Incremental Heat Rate (Btu/kW-h) Relative to Case A	---	3,223	3,398

TABLE A-3
HIGH CH₄ vs. HIGH H₂ CASE FEATURES

Case High CH ₄ or H ₂ Raw Gas Shift	A CH ₄ No	B H ₂ Yes	C H ₂ No
Heat Rate (Btu/kW-h)	7,943	11,167	11,341
Gasification			
Pressure (psia)	500	88	88
Temperature (°F)	1,275	1,275	1,275
No. Gasifiers Required	1	5	8
Gasifier Size (ft)			
Diameter	14	22	22
Height, T-T	137	34	30
Coal Feed Rate	1,303	1,303	1,303
Catalyst	K ₂ CO ₃	K ₂ CO ₃	K ₂ CO ₃
Raw Gas			
CH ₄ Content (%)	31.2	28.6	24.0
Molar Flow Rate (MPH)	16,230	41,432	58,962
Mass Flow Rate (PPH)	233,800	872,300	1,395,600
Volumetric Flow Rate (ACFM)	9,965	145,763	207,624
Sulfur Removal			
Process	GAS/SPEC	Sulferox	Sulferox
Sulfur Removal (MPH)	98	98	98
CO ₂ Absorbed (MPH)	152	0	0
No. Units Required	1	1	1
CO ₂ Removal			
Process	None	GAS/SPEC	GAS/SPEC
Removal (MPH)	---	15,200	15,800
No. Units Required	---	8	8
Steam Consumption (MM Btu/h)	---	713	713
Carbonate Fuel Cell Unit			
Fuel Utilization (%)			
Per Pass	52	30	23
Overall	91	100	100
Power Output (MW DC)	166	183	183
Cell Voltage (volts)	0.7	0.7	0.7
Pressure (psia)	16	16	16
Recycle Gas, at Gasifer			
Source	HTD	Anode	Anode
Molar Flow Rate (MPH)	8,170	34,861	52,737
Mass Flow Rate (PPH)	17,800	679,800	1,190,100

TABLE A-4
RELATIVE CAPITAL COST COMPARISON
HIGH CH₄ vs. HIGH H₂ EVALUATION

CASE	Case A High CH ₄	Case B High H ₂
Gasification + Gas Cleanup		
Coal Preparation	51	6.6
Catalyst System	4.6	4.6
Gasification	12.7	18.0
AFBC	2.4	2.4
Ash Handling & Disposal	1.0	1.3
Raw Gas Cooling/Scrubbing	4.2	7.7
Sulfur Removal & Recovery	3.8	5.3
CO ₂ Removal	0.0	24.8
Total	33.8	70.8
Carbonate Fuel Cell Power Block		
Carbonate Fuel Cell Stacks	6.1	4.7
Carbonate Fuel Cell Piping & Equipment	5.5	4.6
Carbonate Fuel Cell Power Conditioning	11.2	12.2
Total	22.7	21.4
Recycle Gas System		
H ₂ Separation	12.3	0.0
Compression	2.9	5.6
Heating	1.5	5.0
Total	16.7	10.6
Turbine Power Generation		
Fuel Gas Expander	2.1	2.2
Steam Turbine	5.6	0.0
HRSG	1.8	1.8
Total	9.5	4.0
PC Boiler	0.0	17.7
General Facilities	17.3	17.3
Total	100.0	141.9

APPENDIX B

System and Parametric Evaluation for Case 1

The initial Case 1 configuration is based on a variation of the Exxon case (ECS) developed in the TAG II phase of the recent ERC/Fluor study⁽¹⁾. The basic difference between the TAG II case and initial Case 1 is the source of hydrogen recycle gas fed to the gasifier. In the TAG II case the hydrogen recycle is a H₂ and CO₂ mixture separated from the clean syngas via a high pressure membrane. In Case 1, the hydrogen recycle is pure hydrogen from the carbonate fuel cell anode exhaust separated using a Hydrogen Transfer Device (HTD).

The initial heat and material balance, along with a cost estimate, revealed that the initial Case 1 design was not competitive due to the high-hydrogen recycle. The hydrogen recycle rate is dictated by the heat balance around the catalytic gasifier. Increasing the hydrogen recycle rate promotes the exothermic methanation reaction. Other gasifier conditions which also affect methanation, such as pressure, temperature, carbon conversion, steam and catalyst feed rates, were kept at the same values as in the TAG II Exxon case (ECS) in the 1990 study⁽¹⁾ and in the original Exxon design.

Five basic approaches were identified for reducing this hydrogen recycle rate:

- Adjust the gasifier operating conditions to promote methanation (i.e., higher pressure, lower temperature, and lower steam rate).
- Minimize the energy needed to heat up the reactants to gasification temperature, either by lowering the gasifier temperature or increasing the temperature of the steam and recycle gas. The latter alternative is severely limited by the availability of high temperature heat sources.
- Generate heat within the gasifier with the conventional addition of an oxidant.
- Use another technology to recycle hydrogen or carbon monoxide. This is most easily accomplished by using a membrane or PSA unit after the raw gas cleanup. These technologies use high pressure as the separation driving force and are therefore not expected to compete well with the HTD at low pressure.
- Utilize high temperature heat transfer. The temperature of the catalytic combustor outlet could be higher than the gasifier when high temperature catalytic combustor technology is available.

A parametric evaluation was performed to gauge the impact of gasifier pressure, temperature, steam feed rate and oxidant (air) addition. These results are discussed below. Using these results a number of case configurations were then developed.

Gasifier Parameter Evaluation

The effect of gasifier operating conditions on hydrogen recycle and raw gas methane content were studied using a series of gasifier simulations. In each simulation, the following gasifier parameters were kept constant: coal and catalyst rate, carbon conversion, feed stream temperatures and compositions, and the gas phase equilibrium approach temperatures for shift, methanation and COS hydrolysis. One of the following parameters were then varied: operating temperature, operating pressure, and steam and air feed rate.

Figure B-1 shows the effect of temperature from 1200°F to 1350°F, pressure from 250 psia to 1000 psia, and steam feed rate from ~500 lb-mole/h to 10,000 lb-mol/h. The base conditions match those used in the original Exxon design, 1275°F, 500 psia, and 7728 lb-mol/h steam, which corresponds to 1.282 lbs steam/lb coal "as received". High pressure, low temperature, and low steam feed rate help reduce the hydrogen recycle and increase methane content.

The gasifier size is significantly affected by operating temperature due to carbon reactivity. A 75°F reduction in temperature will approximately double the required gasifier bed size. The effect of pressure on carbon reactivity (and hence gasifier size) is expected to be negligible. Carbon reactivity increases with steam rate and therefore the effect of kinetics is opposite that of equilibrium.

Figures B-2A and B-2B are three-dimensional surface plots illustrating the effects of steam and air feed rates on hydrogen recycle and raw gas methane content. Air feed rate varies from 0 to 2500 lb-mol/h and the steam to coal ratio (lb steam/lb coal "as received") varies from 0.3 to 1.5. As can be seen, adding air to the gasifier significantly lowers the hydrogen recycle rate. However, one mole per hour of air feed appears to offset ~one mole per hour of hydrogen recycle, meaning there would be no reduction in feed gas compression costs. Adding air to the gasifier also significantly reduces the methane content in the raw gas, resulting in a lower heat content and consequently lower power production levels in the carbonate fuel cell.

Case 1 Configurations

Variations in the operating conditions were evaluated in order to obtain the highest efficiency and lowest heat rate. Seventeen case studies were evaluated and are summarized in Table B-1 by system type. A case naming convention was developed to identify the configuration and selected operating parameters. The first two letters designate the case configuration, AO, HO, AH, AM, or HM, as shown in Table B-1A. The remaining letters and numbers designate operating parameter variations and are listed in Table B-1B. The final results of these studies are shown in Tables B-2A and B-2B with block diagrams of the systems in Figures B-3 to B-7.

FIGURE B-1
EFFECT OF GASIFIER CONDITIONS ON HYDROGEN FEED RATE
 (Base Conditions: 500 psia, 1275° F, 7728 lbmol/h Steam)

FIGURE B-2A
GASIFIER AIR EFFECT ON METHANE CONTENT

FIGURE B-2B
GASIFIER AIR EFFECT ON RECYCLE

TABLE B-1A

SUMMARY OF RECOVERABLE GASIFICATION CATALYST CASE VARIATIONS

Configuration	Description
AO - Air Only	Enough air is added to the gasifier to totally eliminate the hydrogen recycle (Figure B-3). The carbonate fuel cell anode exhaust is mixed with air and combusted, then mixed with additional air and fed to the cathode. The Heat Recovery Steam Generator (HRSG) recovers the heat from the cathode exhaust to generate power in a steam bottoming cycle.
HO - HTD Only	This is the initial Case 1 configuration in which the carbonate fuel cell anode exhaust goes through a shift reactor and then the HTD. Water is separated from the rich hydrogen stream of the HTD and the dry gas is recycled through a compression train back to the gasifier. The rest of the carbonate fuel cell exhaust gas is burned with air in a catalytic combustor and fed to the cathode. The hydrogen recycle rate to the gasifier is dictated by the gasifier heat needs. The carbonate fuel cell fuel utilization must be lowered from the base level of 85% to increase the hydrogen content of the anode exhaust. Figure B-4 illustrates this configuration.
AH - Air and HTD	This is similar to the HO (HTD Only) configuration except that air is also added to the gasifier. The carbonate fuel cell fuel utilization is maximized at 85%. This sets the HTD hydrogen recycle rate. As this rate is not adequate to satisfy the gasifier heat requirement, air is added to make up the difference. A flow sketch of this configuration is shown in Figure B-5.
AM - Air and Membrane	This configuration is identical to the Case ECS design except that air is added to the gasifier. This supplies the additional heat needed for the gasifier, as noted earlier and is illustrated in Figure B-6.
HM - HTD and Membrane	Hydrogen is provided by membrane separation upstream of the fuel cells as well as HTD separation from the carbonate fuel cell anode exhaust (Figure B-7). This reduces the hydrogen recycle rate to half the rate in the "HTD Only" configuration and eliminates the need for air introduction into the gasifier. Although this approach is more complex in comparison with other systems, the overall heat rate is fairly attractive.

TABLE B-1B
NAMING CONVENTION FOR CASE 1 OPERATING PARAMETER VARIATIONS ¹

LETTER	OPERATING PARAMETER	BASIS
T	Gasifier Temperature	1275°F
P	Gasifier Pressure	500 psia
V	Carbonate Fuel Cell Voltage	0.7 volts
S	Gasifier Steam Rate	7728 lb-moles/hr
O	Carbonate Fuel Cell Oxygen Utilization	40%

¹ A "1" indicates that the parameter is set below the base level and a "3" indicates that the parameter is set above the base level.

TABLE B-2A
DESIGN SELECTION STUDY

CASE DESCRIPTION	Air Only		HTD Only				Membrane	
	AO	AOP3	HO	HOP3T1	HOV3	HOP3T1V3	Air AM	HTD HM
Gasifier Data								
Temperature (°F)	1,275	1,275	1,275	1,178	1,275	1,178	1,275	1,275
Pressure (psia)	500	750	500	750	500	750	500	500
Raw Gas CH ₄ Content (mol %)	8.8	10.9	20.5	24.2	20.5	24.2	12.1	20.5
Cold Gas Efficiency (%)	89.9	90.3	95.8	95.9	95.8	95.9	92.7	95.8
Heat Rate, HHV (Btu/kWh)	7,468	7,419	7,821	8,864	7,184	6,748	6,843	7,124
Power Summary (MW)								
Production								
Carbonate Fuel Cell	121.3	124.0	162.1	167.0	176.0	171.8	151.9	166.7
Fuel Gas Expander	15.8	14.9	17.7	15.6	17.7	15.6	13.6	13.4
Steam Turbine	34.8	33.4	15.3	11.2	10.3	9.1	23.2	14.8
Total Production	171.9	172.4	195.1	193.8	204.0	196.5	188.7	194.9
Consumption								
HTD	0.0	0.0	23.7	11.4	23.7	11.4	0.0	12.0
H ₂ Recycle Gas Compression	0.0	0.0	10.7	5.7	10.7	5.7	5.8	12.1
Gasifier Air Compression	7.5	7.1	0.0	0.0	0.0	0.0	5.4	0.0
Other	10.4	10.3	9.9	9.1	9.1	9.0	9.4	9.4
Total Consumption	17.9	17.4	44.3	26.2	43.5	26.1	20.6	33.5
Net Power Generation	154.0	155.0	150.9	167.5	160.5	170.4	168.0	161.4
Coal Data								
Consumption (PPH "as received")								
Gasification	108,592	108,592	108,592	108,592	108,592	108,592	108,592	108,592
Coal/Catalyst Drying	5,250	5,250	5,250	5,250	5,250	5,250	5,250	5,250
Total	113,842	113,842	113,842	113,842	113,842	113,842	113,842	113,842
Total Consumption (TPD)	1,368	1,368	1,368	1,368	1,368	1,368	1,368	1,368
HHV (Btu/lb "as received")	10,100	10,100	10,100	10,100	10,100	10,100	10,100	10,100
Carbonate Fuel Cell Data								
Power Production (MW DC)	125.0	127.9	166.4	171.8	180.7	176.8	156.8	171.5
Cell Voltage (volts)	0.70	0.70	0.70	0.70	0.76	0.72	0.70	0.70
Active Cell Area (MM ft ²)	0.88	0.88	0.85	1.04	1.21	1.17	1.11	1.03
Fuel Utilization (%)	85.0	85.0	57.4	73.9	57.4	73.9	85.0	72.8
Oxygen Utilization (%)	40.0	40.0	30.7	40.0	34.1	40.0	40.0	40.0

TABLE B-2B
DESIGN SELECTION STUDY

CASE DESCRIPTION	Air + HTD, Base Steam Rate					Air + HTD, Reduced Steam Rate			
	AH	AHT3	AHP3T1	AHP3	AHP3T3	AHS1	AHS1P3T1	AHS1P3	AHS1P3T3
Gasifier Data									
Temperature (°F)	1,275	1,372	1,178	1,275	1,373	1,275	1,178	1,275	1,372
Pressure (psia)	500	500	750	750	750	500	750	750	750
Raw Gas CH ₄ Content (mol %)	10.9	5.6	19.3	13.4	7.8	23.7	35.7	27.1	18.0
Cold Gas Efficiency (%)	91.4	87.6	94.6	91.9	88.4	88.6	90.8	89.1	86.6
Heat Rate, HHV (Btu/kWh)	7,175	7,653	6,790	7,041	7,453	7,168	6,890	7,065	7,355
Power Summary (MW)									
Production									
Carbonate Fuel Cell	145.4	130.2	159.9	149.7	135.6	145.9	155.0	148.6	139.1
Fuel Gas Expander	16.4	19.0	15.4	17.5	20.2	15.3	15.5	16.7	18.7
Steam Turbine	20.9	27.0	13.6	18.2	24.1	21.2	17.1	19.6	23.1
Total Production	182.8	176.2	188.9	185.4	179.9	182.5	187.6	184.9	180.9
Consumption									
HTD	4.3	3.7	4.9	4.4	3.9	4.3	4.6	4.4	4.0
H ₂ Recycle Gas Compression	2.0	1.7	2.5	2.3	2.0	2.1	2.4	2.3	2.1
Gasifier Air Compression	6.1	10.1	2.6	5.5	9.5	5.9	4.1	5.7	8.4
Other	10.1	10.5	9.5	9.9	10.3	9.8	9.6	9.7	10.1
Total Consumption	22.5	26.0	19.5	22.1	25.7	22.1	20.7	22.1	24.6
Net Power Generation	160.2	150.2	169.3	163.3	154.3	160.4	166.9	162.8	156.3
Coal Data									
Consumption									
(PPH "as received")									
Gasification	108,592	108,592	108,592	108,592	108,592	108,592	108,592	108,592	108,592
Coal/Catalyst Drying	5,250	5,250	5,250	5,250	5,250	5,250	5,250	5,250	5,250
Total	113,842	113,842	113,842	113,842	113,842	113,842	113,842	113,842	113,842
Total Consumption (TPD)	1,366	1,366	1,366	1,366	1,366	1,366	1,366	1,366	1,366
HHV (Btu/lb "as received")	10,100	10,100	10,100	10,100	10,100	10,100	10,100	10,100	10,100
Carbonate Fuel Cell Data									
Power Production (MW DC)	149.8	134.1	164.7	154.1	139.7	150.3	159.6	153.0	143.3
Cell Voltage (volts)	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70	0.70
Active Cell Area (MM ft ²)	0.91	0.90	1.13	1.05	0.94	1.04	1.07	1.02	0.97
Fuel Utilization (%)	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0
Oxygen Utilization (%)	40.0	40.0	40.0	40.0	40.0	40.0	40.0	40.0	40.0

FIGURE B-3
AO (AIR ONLY) FLOW SKETCH

FIGURE B-5
AH (AIR AND HTD) FLOW SKETCH

FIGURE B-6
AM (AIR AND MEMBRANE) FLOW SKETCH

FIGURE B-7
COMBINATION HTD/MEMBRANE

ENERGY RESEARCH CORPORATION

The final design configuration for Case 1 was chosen with respect to both heat rate and capital cost considerations. In general, the configurations with the better heat rate were also expected to have higher capital costs. After reviewing the heat rate results from this screening evaluation and qualitatively considering the capital cost impacts, the "AH-Air and HTD" design was selected.

Changes were made to the initial Case 1 design in order to improve the heat rate. A gasifier temperature and pressure of 1200°F and 750 psia were selected to maximize methane production and minimize hydrogen recycle. The resulting improvement in heat rate may offset the increased capital costs for a larger, higher pressure gasifier.

A full flow gasification steam rate, consistent with the initial Case 1 design, was also chosen. When the gasification steam rate is lowered, the condensate removal rate from raw gas cooling decreases. However, the water addition rate in the fuel gas moisturization increases as moisturization levels are set to avoid carbon deposition in the carbonate fuel cell anode. Overall, the total water vaporization rate is not significantly affected. As a result, the effect of gasification steam rate on heat rate is small. The total capital cost of steam generation, raw gas cooling and fuel gas moisturization is likely to decrease for reduced steam rates. However reduced steam rate will reduce carbon reaction rates making it unattractive.

Two additional changes to the initial Case 1 design were also made to improve heat rate. First, the carbonate fuel cell voltage was increased from 0.7 to 0.74 volt. At a set fuel utilization, an increase in voltage decreases the current density of the carbonate fuel cell. This increases the carbonate fuel cell efficiency and, hence, power production. Second, suction temperature for each of the two fuel gas expander stages was increased from 700°F to 1050°F. The higher temperature increases the turbine power output. Heat is safely transferred from the 1250°F and oxygen bearing carbonate fuel cell exhaust to the fuel gas using a heat transfer salt circulation loop.

APPENDIX C

Case 1 Process Description

Figure C-1 is a block diagram of the overall plant, depicting both process flows and heat integration of process units. The Case 1 process is described in detail below.

Coal Preparation and Catalyst Drying

Illinois No.6 coal is received into the plant and fed to integrated coal crushing and drying systems. These systems combine gas-swept impact mills with entrained drying columns. The coal is crushed to minus 8 mesh size and dried to 4.4 wt.% moisture on a dry coal basis. Flue gas is recirculated to supply heat and carrier gas for the drying columns. The gas is heated to 900°F in a single fired burner.

Catalyst from the catalyst recovery section is in the form of a concentrated water solution of 37 wt.% equivalent of K_2CO_3 . This is added to the crushed coal in a gentle mixing step using zig-zag blenders. The mixture is then dried in entrained columns. The heat for this drying step is supplied by recirculating flue gas and burning coal as in the first drying step. A total of 4.61% of the original coal feed is burned in both drying steps to supply the heat needed to dry the coal and catalyst slurry to a prescribed moisture level. The resulting prepared coal feed contains 15 wt.% K_2CO_3 and 4.4 wt.% moisture on a dry coal basis.

Coal Gasification and AFBC

The dried coal and catalyst mixture is pressurized via a lockhopper and fed into the bottom of the gasifier with dense phase pneumatic conveying. Superheated steam, recycled hydrogen, recycled raw gas, and air are introduced to the bottom of the gasifier. The coal and catalyst are maintained in a bubbling fluidized bed operating at 1200°F and 750 psia. Within the bed 90% of the coal chars are converted to gas and the water-gas shift and methanation reactions proceed essentially to equilibrium.

Unconverted coal chars together with the ash and spent catalyst are withdrawn from the bottom of the gasifier and routed to the atmospheric fluidized bed combustor (AFBC). Here the unconverted char is burned to completion to produce heat. This heat is used to preheat the steam and recycle hydrogen to 1543°F and to generate low pressure steam. The steam is originally generated by the HRSG at 815 psia and superheated to 750°F. It is mixed with the recycle hydrogen stream from the carbonate fuel cell anode exhaust, via the hydrogen compression unit, before entering the AFBC.

Air enters the gasifier at 770 psia and 268°F after being compressed by a five stage centrifugal compression train. Interstage cooling is accomplished with cooling water.

The raw gas withdrawn from the top of the gasifier contains 17.0% methane, 3.3% carbon monoxide, 16.2% carbon dioxide, 13.8% hydrogen, and 36.4% water vapor. Most of this gas is recompressed back up to 770 psia and recycled to the gasifier, while a small portion (20.2%) is routed downstream for raw gas cooling and scrubbing.

C-2

FIGURE C-1
 CASE 1 - PROCESS BLOCK DIAGRAM

The raw gas recycle is necessary to provide a reasonable gasifier height. The height is dictated by the gasifier bed volume and diameter. The bed volume is set by the predicted carbon conversion kinetics while the diameter is set by the velocity limits of the fluidized bed. Raw gas is recycled through the gasifier in order to use a shorter, larger diameter gasifier while maintaining the required superficial bed velocity (1.1 fps). In this case, raw gas recycle changes the gasifier bed dimensions from an impractical 10.2'ID x 463.6'H to 22'ID x 100.2'H. This change is expected to reduce the fabrication costs and pressure drop of the gasifier. The raw gas recycle compressor is required to operate at a high temperature (1200°F) and high sulfur environment. Blowers for high temperature exist, but compressors for this service will have to be developed. The total power required for compression is 2.1 MW.

The gasifier vessel is built with low-alloy (C- $\frac{1}{2}$ Mo) steel using a 9-inch refractory lining. About 25 feet of freeboard is provided above the fluidized bed to minimize carry over. As a result, the 22'ID x 100.2'H gasifier bed requires a 23'6"ID x 125'6"T-T gasifier vessel.

Catalyst Recovery

The process for catalyst recovery draws directly from the original Exxon design. Spent solids from the AFBC are mixed with aqueous $\text{Ca}(\text{OH})_2$ recycled from the catalyst recovery unit and fed into $\text{Ca}(\text{OH})_2$ digestion vessels operating at 70 psia and 300°F. Here they are further mixed with feed lime (CaO) and makeup 30 wt% KOH solution. The CaO hydrolzes in the digestors to form $\text{Ca}(\text{OH})_2$. The ratio of calcium in the lime feed to potassium in the feed char is maintained at 0.7 lb Ca/lb K. The spent solids are soaked in the digestors for two hours. Each digestor is equipped with a three-impeller agitator to maintain the solids in solution. Under these "digestion" conditions, 90% of the potassium in the spent solids is solubilized, the rest leaves with the solids in water-insoluble compounds. Steam is added to the digestors to preheat the feed lime and makeup KOH and to maintain the operating temperature.

The effluent slurry from the digestors is pumped through first stage hydroclones for solid/liquid separation. The overflow from the first-stage hydroclones, which is the most concentrated potassium solution in the system, contains 37 wt% K_2CO_3 equivalent. This is the recovered "rich" catalyst solution. It is fed to holding drums and pumped to the coal drying/catalyst addition section of the plant.

The first-stage hydroclone underflow slurry is mixed with the third-stage hydroclone overflow solution in the second-stage mixing drum. The mixed slurry from this vessel is pumped through the second stage hydroclones. The "semi-rich" overflow solution from this second stage is used to slurry the spent solids from the AFBC. The underflow from the second-stage hydroclones is fed into the third-stage mixing drum along with the overflow from the fourth-stage hydroclones. This counter-current water-washing or "leaching" sequence continues until the fourteenth stage, where makeup wash water is preheated and added to the system. The leached solids in the last stage underflow are sent to solid waste handling.

Raw Gas Scrubbing and Cooling

As a cold gas cleanup system is used, the hot raw gas from the gasification unit must be cooled. The high temperature (1200°F) raw gas is used to heat the carbonate fuel cell feed gas and the hot fuel gas expansion suction gas. Cooled to 537°F, the raw gas is then routed through a contact scrubber to remove particulates. The scrubbed gas is passed through a catalytic COS hydrolysis reactor to convert the bulk of the COS to H_2S . COS hydrolysis is required

because the acid gas removal process, GAS/SPEC, only removes 50% of the COS. The converted gas, at 409°F, is used to generate 100 psia steam and heat both the saturator recirculation water and steam system condensate. The raw gas is cooled to 100°F with cooling water before entering the GAS/SPEC unit.

Acid Gas Removal (GAS/SPEC)

Acid gas removal occurs as the scrubbed gas enters the Dow GAS/SPEC unit. Here the 100°F gas contacts Dow's proprietary MDEA solvent counter-currently on acid gas removal trays. Almost 100% of the H₂S and 50% of the COS is removed along with 17% of the CO₂. A small portion of the treated gas from the absorber is sent to the SCOT tail gas treating unit. The bulk of the treated gas enters an additional H₂S removal unit (PURASPEC) where the sulfur level is decreased to about 0.001 ppmv. The carbonate fuel cell unit requires a total sulfur level below 0.1 ppmv in order to achieve reasonable catalyst life for the shift reactor.

The rich solvent from the absorber is heated by the hot regenerated solvent in the lean/rich solvent exchanger. The rich solvent is then directed to the regenerator for stripping dissolved gases, i.e., mainly H₂S, COS, and CO₂. The regenerated (lean) solvent is cooled in the exchanger and in the lean solvent cooler, filtered to remove solids and organic contaminants, and stored in the solvent storage tank. The acid gases stripped from the rich solvent are directed to the Claus unit for sulfur recovery.

Sulfur Recovery (Claus)

The acid gas from the GAS/SPEC unit is routed to the Claus sulfur removal plant and SCOT tail gas treating process where 3174 lb/hr of elemental sulfur is produced. This sulfur production represents a recovery of about 73% of the sulfur entering with the coal. Another 23% leaves with the gasifier ash as solid waste. Actual sulfur recovery per pass in the Claus plant is about 98.0% of the total sulfur entering the sulfur plant. Unrecovered sulfur is sent to the tail gas treating unit where sulfur is recovered as H₂S and is recycled to the sulfur plant.

The sulfur plant is a three-stage, acid gas, straight-through-type Claus unit. H₂S in the sour gas from the process water treating, the recycle from the tail gas plant, and one third of the acid gas from the GAS/SPEC unit is converted to H₂O and SO₂ in the sulfur furnace. Air for combustion is supplied by a blower. Heat from the combustion is recovered by generating 100 psia steam in the waste boiler. The exhaust gas from the waste heat boiler is mixed with the flow of acid gas that bypasses the furnace. The resultant gas mixture is fed to the sulfur converter No. 1. The amount of gas bypassing the furnace is controlled to maintain a ratio of H₂S to SO₂ slightly greater than 2:1 to force the converter reaction toward completion.

The exhaust gas/acid gas mixture passes through a three-step sulfur converter/condenser process. The gaseous sulfur produced in converter No. 1 is condensed and recovered by cooling the effluent gas in sulfur condenser No. 1. Steam at 55 psia is generated by this cooling process. The sulfur condenses in the tubes and flows by gravity to either one of the concrete sumps. Sulfur, a solid at ambient temperatures, is kept molten by condensing 55 psia steam in pipe coils that cover the bottom of the sumps.

The gases from sulfur condenser No. 1 react further in sulfur converter No. 2. As in condenser/converter No. 1, the gaseous sulfur produced in the second converter is cooled and condensed in sulfur condenser No. 2. The cooling

in this step is accomplished using the effluent gas from condenser No. 2. The condensed sulfur flows to the concrete sumps. The process is repeated in sulfur converter No. 3 and sulfur condenser No. 3.

Tail gas may contain sulfur in the form of H_2S with smaller amounts of SO_2 , COS, and elemental sulfur. For final sulfur recovery, this gas flows through a tail gas coalescer and then enters the SCOT Unit.

Tail Gas Treating (SCOT)

The gas from the tail gas coalescer in the sulfur recovery unit contains unreacted H_2S , SO_2 , COS, and elemental sulfur species S_6 and S_8 . Further processing in the Tail Gas Treating Unit removes these sulfur compounds.

The SCOT process is designed to first convert residual SO_2 to H_2S , then remove the H_2S from the atmospheric tail gas. Clean medium-BTU gas produced in the acid gas removal unit is used to supply both the hydrogen for the SO_2 conversion and the heat needed for the reactions. A small portion of the clean medium-BTU gas is combusted in a fired heater, increasing the temperature of the tail gas to the required 550°F. The hot gas goes to the hydrogenation reactor where the sulfur conversion reactions take place.

The effluent from the hydrogenation reactor is cooled in the waste heat boiler where 100 psia steam is generated. The partially cooled gas then passes through the water wash cooling tower where the gas is further cooled by direct contact with water.

Warm water from the bottom of the water wash cooling tower is pumped through a water-cooled exchanger. The cooled stream then reenters the top of the water wash cooling tower. A small stream of warm water from the bottom of the vessel is removed to maintain water balance in the unit. Cooled gas from the top of the water wash cooling tower enters the amine absorber where essentially all the H_2S is absorbed by countercurrent contact with an amine solution. Only a portion of the carbon dioxide is co-absorbed. The treated gas contains approximately 200 ppm total sulfur.

Sulfur rich amine solution from the bottom of the absorber is pumped through the lean/rich solvent exchanger. Here it is heated by exchange with regenerated lean amine solution. Acid gases are stripped from the rich amine solution in the regenerator by application of indirect heat, supplied by condensing 100 psia steam in the regenerator reboiler. Regenerated lean amine solution is cooled via the lean/rich solvent exchanger and the lean solvent cooler prior to reentering the top of the amine absorber. Cooling in the lean solvent cooler is supplied by cooling water.

Acid gas from the regenerator overhead is cooled in the regenerator condenser, which uses cooling water to remove heat from the gas stream. Condensate is collected in the acid gas knockout drum and is refluxed to the regenerator. The acid gas is recycled to the Claus plant for sulfur recovery.

Fuel Gas Moisturization

Water is added to the clean fuel gas in order to inhibit the Boudouard reaction:

and thus prevent carbon deposition at the carbonate fuel cell anode. This is accomplished with a saturator column in order to use relatively low level heat to evaporate the water. Clean fuel gas at 110.5°F enters the bottom of the saturator. Water at a rate of 2245 lb-mole/hr is absorbed by the fuel gas stream. The water exiting the bottom of the saturator is heated by low temperature raw gas coolers and then mixed with fresh boiler feed water (BFW) from the steam system. The moist gas exiting the top of the saturator is then routed to fuel gas expansion.

Hot Fuel Gas Expansion

Clean 655 psia syngas from the fuel gas moisturization is heated from 348°F to 1050°F, expanded across a turbine to around 95 psia, reheated from 650°F to 1050°F, then expanded again to 17.1 psia. The expanded gas is fed to the carbonate fuel cell unit at 700°F. The high suction temperature (1050°F) maximizes power output by improving thermal efficiency. The fuel gas expanders produce 21.6 MW, 11% of the total plant power.

The feed gas from the moisturization unit is heated from 348°F to 890°F against a high temperature raw gas. Heat from the HRSG is used to complete the fuel preheating and to accomplish the interstage heating. However, heat cannot be transferred directly from oxygen containing 1237°F carbonate fuel cell exhaust to the high pressure fuel gas due to the potential danger of explosion. Therefore, the heat is transferred using a secondary circulation loop of Olin's Solar Salt. This heat transfer fluid is a eutectic mixture of molten sodium nitrate and potassium nitrate (about 60 wt% NaNO₃ and 40 wt% KNO₃), with a maximum operating temperature of over 1,150°F and a melting temperature of 425°F. The product has been tested extensively for the U.S. Department of Energy.

Hot fuel expanders with a service at 1050°F or above are not commercially available. Designs for high temperature blades and seals or cooling methods must continue to be developed.

Carbonate Fuel Cells

The expanded fuel gas at 17.1 psia and 700°F is fed to the carbonate fuel cell unit. As shown in Figure 4, the carbonate fuel cell unit includes the fuel cell stacks, a low temperature shift reactor, hydrogen transfer device (HTD), catalytic combustor, DC/AC inverter and various blowers and heat exchangers. Overall, the unit consumes fuel gas and air and produces flue gas, recycle hydrogen and 83.8% of the total electrical power output.

The total heat loss to the atmosphere from the carbonate fuel cell equipment and piping is 30 MMBtu/hr. Overall, 80.7 MMBtu/hr of heat needs to be transferred from the HRSG and Raw Gas cooling unit to the carbonate fuel cell unit.

- Carbonate Fuel Cell Stacks

The expanded fuel gas is heated from 700°F to 1050°F against high temperature raw gas then fed to the anode side of the internal reforming carbonate fuel cell stacks. Within the anode hydrogen is consumed by the half reaction:

Methane and carbon dioxide are converted to hydrogen via the reforming and shift reactions. The anode exhaust gas composition (54.4% CO₂, 32.0% H₂O, 3.6% H₂, 3.3% CO and 6.6% N₂) is close to a reforming and shift equilibrium composition.

On the cathode side, carbon dioxide and oxygen are consumed by the cathode half reaction:

Carbonate ions continuously migrate across the electrolyte to the anode to maintain the chemical balance and transfer electrical charge.

The carbonate fuel cell is designed for a fuel utilization of 85%, an oxygen utilization of 60% and a cell voltage of 0.74 volts. It produces 168.8 MW of DC power and has a current density of 165.5 ASF. A total of 864 fuel cell stacks, each containing about 286 2' x 3' cells, are required for a total active fuel cell area of 1.38 million square feet.

- Shift Reactor and Hydrogen Transfer Device

The anode exhaust gas is routed through a shift reactor and Hydrogen Transfer Device (HTD) in order to separate out the hydrogen. The separated hydrogen is recycled back to the gasifier via the hydrogen compression unit. The hydrogen depleted gas is mixed with air and fed to the catalytic combustor.

The HTD is in essence a phosphoric acid fuel cell operating in reverse, consuming DC power to separate hydrogen. The hydrogen is consumed by the anode reaction:

and produced by the cathode reaction:

Like phosphoric acid fuel cells, the HTD operates at about 400°F and is poisoned by high levels of CO. As the carbonate fuel cell anode exhaust contains 3.3 mole% CO, a low temperature shift reactor is placed

upstream of the HTD in order to consume the bulk of the CO via the water-gas shift reaction:

Anode exhaust is cooled from 1250°F to 425°F by transferring heat to the catalytic converter feed gas and carbonate fuel cell air. The cooled gas is then fed to the low temperature shift reactor. In this adiabatic reactor, water-gas shift conversion decreases the CO content of the exhaust to 0.20%, an acceptable level for the HTD. This also increases the temperature of the gas to 482°F, a temperature recommended by the vender to maximize shift conversion. The bed was designed for a 1 psi pressure drop.

The shifted gas is cooled to 342°F by transferring heat to the carbonate fuel cell air intake, and then fed to the HTD. The HTD recovers 79.5% (1280 lb-moles/hr) of the hydrogen from the anode exhaust. The hydrogen rich stream contains 71.1% H₂ and 28.9% H₂O. The hydrogen depleted stream contains only 1.5% hydrogen. Both streams exit the HTD at 392°F, resulting in a heat loss of 4.8 MMBTU to the environment. The HTD consumes 3.65 Kwh/lb-mole of hydrogen transferred for a total DC consumption of 4.7 MW.

- Carbonate Fuel Cell Air Intake, Catalytic Converter and Cathode Recycle Blower

The hydrogen depleted exhaust gas is routed through a blower to boost the pressure from 14.25 psia to 16.3 psia. The blower discharge is mixed with 426°F carbonate fuel cell air and heated to 804°F against the hot anode exhaust gas. The heated gas is then fed to a catalytic converter. The catalytic converter combusts the residual CO and H₂ to produce CO₂ required for the downstream carbonate fuel cell cathode. A catalytic type burner is required due to the low heating value of the HTD exhaust gas.

The hot (881°F) converter outlet gas is mixed with the cathode recycle gas and fed to the carbonate fuel cell cathode. This feed gas has a temperature of 1050°F and a composition of 16.0% CO₂, 9.8% O₂, 12.9% H₂O, and 61.3% N₂. At an oxygen utilization of 60%, the cathode outlet composition is 9.5% CO₂, 6.8% O₂, 14.5% H₂O, and 69.2% N₂. The cathode outlet flow is split: 58% is recycled back to the cathode inlet via the cathode recycled blower, 42% is fed to the HRSG. The recycle blower consumes a total power of 1.0 MW.

Carbonate fuel cell air intake is composed of filtered ambient air which is compressed to 16.8 psia and 90°F. The air is preheated to 258°F against the HRSG, to 370°F against the HTD feed gas, and to 426°F against the anode exhaust gas.

- DC/AC Converter

As fuel cells produce DC power, a DC/AC power inverter is required to provide AC power for export. The inverter is sized to convert the DC power produced from the carbonate fuel cell less the DC power consumed by the HTD. With an overall inversion efficiency of 97%, a total of 159.2 MW is inverted.

Hydrogen Compression

The rich hydrogen stream from the carbonate fuel cell unit is cooled to 90°F using cooling gas whereby some of the water condenses out of the gas phase. The gas stream is then compressed in a multi stage reciprocating compressor to a final pressure of 785 psia and 267°F. Between stages, the gas stream is cooled to 90°F by cooling water. The total power required for compression is 2.4 MW.

Heat Recovery Steam Generator (HRSG)

The exhaust gas from the carbonate fuel cell unit is routed to the HRSG for heat recovery. The HRSG provides a total duty of 378.4 MMBTU/hr, which is shared by the molten salt for the hot gas expander, 815 psia steam generation, boiler feed water superheating, and carbonate fuel cell air preheating. The stack gas exits to the atmosphere at 177°F, assuming a unit loss of 2% (7.7 MMBTU/hr).

Steam and Condensate Systems

The steam and condensate systems use waste heat from the process units to generate process steam and hot water, provide steam heating, and produce electrical power with a condensing turbine. Condensate is recirculated through a deaerator to the steam generators. Figure C-2 illustrates the steam balance.

From the deaerator, 940 psia boiler feed water (BFW) is preheated to 495°F in the HRSG. A portion is used to provide hot make-up water to raw gas cooling and fuel gas moisturization and to generate superheated 800 psia, 750 F steam in the HRSG. Most of the superheated steam is routed to the catalytic gasifier, the rest is fed to a condensing turbine.

The steam turbine is a multi stage expander utilizing 100 psia steam injection and a surface condenser. First stage suction uses 750°F, 800 psia superheated steam into which a small amount of 100 psia steam is injected. The net power produced is 10.1 MW. The discharge is condensed in the surface condenser operating at 2.5 inches of Hg. The surface condenser cooling duty of 21.8 MMBTU/hr is provided by cooling water.

Demineralized water is added to the condensate and the mixture is pumped to the condensate storage and polishing. The polished condensate is heated to 195°F in the HRSG, mixed with the condensate from the 100 psia steam user, then routed to the deaerator.

The 100 psia and 55 psia steam producers are provided with BFW from the deaerator. The bulk of the 100 psia steam is routed to 100 psia steam users, the rest is split between the steam injection for the condensing turbine and steam stripping for the deaerator. The balance of the stripping steam is provided by the 55 psia steam producers and steam from the condensate and blowdown flash drums. The deaerator is required to remove CO₂ and O₂. It operates at 25 psia.

FIGURE C-2
CASE 1 -- STEAM BALANCE DIAGRAM

APPENDIX D

Evaluation of Disposable Catalyst Options

Catalytic gasification of coal has been studied for many years and the types of compounds considered effective catalysts are generally known. For the purpose of this study UND/EERC evaluated the options and made recommendations for disposable gasification catalysts for both hot and cold cleanup systems.

The assessment was performed with the objective of providing design data applicable to the type of coal used in the plant design (Illinois #6), but since the preponderance of data available was for other coals, conclusions were drawn on the basis of broad inference. The overall criteria used in recommending disposable catalysts were:

- Quantitative gasification rate constants
- Qualitative information on selectivity for methane and hydrogen
- Sulfur sorption
- Ash and bed agglomeration
- General perception of relative cost.

The question of whether a catalyst should be considered disposable depends on an economic evaluation, which was not within the scope of this effort. For the purpose of this study, broad qualitative considerations were used to arrive at recommendations for disposable catalysts which, relative to the potassium carbonate catalyst used in Case 1, could conceivably be economically disposable.

D-1 Background

There is general agreement on the superior catalytic activity of alkali metals (Ca, K, Na, and Li) over the alkali earths (Ba, Sr, Ca, and Mg), with reactivities decreasing with atomic weight. However, the order of activity changes with the carbon being gasified, for example, Na has shown greater reactivity than K in some cases. Among the anions represented, carbonates and hydroxides are superior to halides. For calcium, the catalytic activity was determined to be in the order of $\text{CaO} > \text{Ca acetate} > \text{CaCO}_3 > \text{CaSO}_4$.

Coal char and alkali carbonates are believed to interact by means of a redox mechanism, whereby carbon reduces the carbonate to metal, the metal reacts with water to release hydrogen, and the resulting metal hydroxide recombines with CO_2 to regenerate the carbonate. Electrochemical and free radical mechanisms have also been proposed which involve the formation of an alkali-O-C complex on the coal surface. Here the initial oxygen content on the coal surface is important in determining the active sites. The catalytic activity of low rank coals is believed to be established by ion exchange on carboxylates.

Catalysis is reported to be enhanced by the wetting properties of the catalyst. Low catalytic activity can be attributed to the following:

- Interaction with Coal Ash Components
- Sulfur Poisoning
- Loss of Volatiles
- Loss of Active Sites

Alkali catalysts have shown to be extremely mobile upon heating with carbon, meaning that their initial dispersion has very little to do with their ultimate distribution under gasification conditions. However this cannot be concluded for the alkali earth catalysts. The activity of alkali carbonate catalysts increases with loading up to a saturation level of ~10% by weight. Above that level the number of active sites becomes the limiting factor. The effects of catalyst loading for alkali earths are less clearly defined, with the effect of weight percent CaCO_3 increasing up to 20% or 30%.

Reactivities for the first order steam gasification of catalyzed coal were determined at UND/EERC by TGA for three coals treated by different catalysts. The results for temperature range from 650 to 850°C (1202 to 1562°F) are presented in Table D-1. Reactivities are expressed as first order rate constants for the conversion of coal carbon.

D-2 Disposable Catalyst Recommendation With Cold Gas Cleanup (Case 2)

Limestone or dolomite is recommended for this case as there is no in-bed sulfur capture. The turnover rate was determined by operating parameters taken from fluidized-bed combustion: ash rejection as 15% bottom ash and 85% fly ash, and a bed attrition of 10% per hour. An additional basis for computing bed turnover is the possible need to purge calcium sulfide from the reactor, where sulfation can be computed based on the equilibrium sulfur capture. Bed addition rates for both removing bottom ash and adding back attrition are cumulative. The bed volume and weight can be computed at 45 lb/ft³ for the reactor diameter and bed depth determined on the basis of gas velocity, carbon reactivity, and the percentage of carbon in the bed. Reactivity is assumed to be equivalent to the level of 20% limestone reported in Table D-1.

The basic recommendation for Case 2, which is to gasify coal in a fluidized limestone bed, provides much of the catalytic activity of an alkali catalyst, without the cost and plant complexities associated with a recoverable catalyst. Based on laboratory results for Velva North Dakota lignite, the addition of calcium carbonate (limestone) alone provides one half to one third the catalytic effect of potassium carbonate. Between 650 and 800°C (1202 and 1472°F), the addition of 10% CaCO_3 increased reactivity on average by a factor of 3, compared to a factor 3.5 for 20% CaCO_3 and 5.3 for 10% K_2CO_3 . Reactivities observed in the EERC 6-inch CPU using a limestone bed were in the same range as those determined for 10% and 20% CaCO_3 by laboratory TGA. It is also known that the limestone bed serves to crack tars, as evidenced in the EERC CPU by the almost total absence of condensable hydrocarbons in testing performed at 700 to 800°C.

The addition of alkalis (Na or K) to the limestone bed to improve catalytic activity has both advantages and disadvantages and it is not clear whether the gain in catalytic activity is worth the cost and potential for operating problems. To be effective, the added alkali must be very inexpensive, added in very small amounts, or be naturally retained in the limestone bed without causing bed agglomeration.

Obvious low cost candidates for improving the activity of a limestone bed are the sodium minerals trona and nacholite. EERC has shown these minerals have a TGA reactivity fully comparable to K_2CO_3 . However subsequent tests in the 6-inch fluidized-bed CPU reactor on trona resulted in massive bed agglomeration and shutdown in testing conducted at 700 to 800°C. Trona provided a relatively high TGA activity at 650°C (1.92 hr⁻¹) and reasonable extrapolation would indicate a value between 0.5 and 1 hr⁻¹ at 600°C. At these lower temperatures, it is likely that bed agglomeration would be greatly reduced at the cost of

TABLE D-1
REACTIVITIES (K, HR⁻¹) FOR FIRST ORDER STEAM GASIFICATION
OF COALS TREATED WITH VARIOUS CATALYSTS

	Temperature, °C				
	650	700	750	800	850
VELVA N.D. LIGNITE					
No Catalyst	0.30	1.35	2.10	3.56	
10% K ₂ CO ₃	1.35	4.06	8.17	34.80	
10% Trona (Na ₂ CO ₃)	1.92	6.05	16.46		
10% Limestone	0.48	0.81	6.49	15.50	
20% Limestone	0.55	5.00	8.76	15.00	
10% Taconite		1.33	1.63	2.85	
16% Taconite, 4% Trona (Na ₂ CO ₃)		3.56	8.46		
WYODAK WYO SUBBITUMINOUS					
No Catalyst	0.37	1.16	1.31	3.06	
10% K ₂ CO ₃	1.25	4.3	8.24	13.48	
10% Trona, 10% Taconite		1.00	3.33	7.65	
ILLINOIS #6 BITUMINOUS					
No Catalyst		0.07	0.14	0.33	
10% K ₂ CO ₃			4.36		
10% Wood Ash, Cold Leachate		0.95	2.60	8.54	
10% Wood Ash, Hot Leachate		0.61	3.01	5.15	
20% Limestone			0.59	1.45	3.22
20% Dolomite			0.25	0.90	1.78
18% Limestone, 2% K ₂ CO ₃			0.36		
15% Limestone, 5% K ₂ CO ₃			0.89		
12.6% Limestone, 7.4% K ₂ CO ₃			3.55		
10% Limestone, 10% K ₂ CO ₃			5.38		
15% Taconite, 5% K ₂ CO ₃			0.15		
10% Taconite, 10% K ₂ CO ₃			4.97		
5% Taconite, 15% K ₂ CO ₃			4.17		

requiring a large reactor volume. Reactivities in this range may be suitable for a system operating at moderate pressure and high gas recycle rate.

The activity data for varying proportions K_2CO_3 and $CaCO_3$ catalysis of Illinois coal #6 show that small amounts of potassium do not suffice to achieve significant improvement in reactivity. Addition of larger amounts of K_2CO_3 as part of a disposable catalyst is not economically viable unless a very inexpensive source is acquired or the potassium can be retained. Possible solutions for retaining the potassium have been investigated but the costs still outweigh the activity gains.

The KCl-containing minerals sylvinite and sylvine have been suggested as low-cost sources of potassium, and the use of KCl with limestone has been shown to achieve activities higher than either alone, due to the in situ anion exchange of CO_3^{2-} for Cl^- on potassium in the gasifier. However, the addition of sizable amounts of chlorine to the pressure reactor is not recommended due to corrosion problems. Another potential source of low cost potassium is wood ash. A cost-benefit assessment is needed to address the balance between the cost of gathering wood ash from many small distributed sources versus the advantage of a smaller reactor size.

D-3 Disposable Catalyst Recommendation With Hot Gas Cleanup (Case 3)

For in-bed sulfur capture capability, a bed of 50% limestone or dolomite and 50% taconite tailings is recommended. The considerations made in this case were the same as in Case 2 with the added considerations of in-bed sulfur sorbent and related effects of gasification catalysis, tar cracking, and ash or bed agglomeration. The sulfur sorbents that are low enough in cost to be considered disposable are limited to calcium and iron compounds.

Calcium compounds were investigated and found to be unacceptable for use at these operating temperatures. However calcium sorbents may prove effective at temperatures above 750°C.

Iron oxide (Fe_3O_4) has been investigated as an H_2S sorbent over a wide range of temperatures. Up to 90% sulfur removal was achieved in tests using iron oxide. Equilibrium concentrations of H_2S over Fe_3O_4 have been reported to be 560 ppmv at 593°C. No effect due to the increased operating pressure in the high-methane case is expected as the reaction is equimolar:

Based on calculated H_2S levels for 5% sulfur Illinois #6 coal, the equilibrium sulfur removal potential corresponding to 560 ppmv in the gasifier effluent is 93% for the high-methane configuration.

The source and form of iron oxide are important in determining the surface area and reactivity for gasification catalysis and sulfur sorption. From a cost standpoint, it is believed that taconite tailings are the most promising source. Activity data is listed in Table D-1, however no sulfide sorption data is available. Based on METC data on ash-Fe pellets, a 50% iron utilization is recommended in determining addition rates.

BIBLIOGRAPHY

- Abbasian, J.; Rehmat, A.; Leppin, D.; Banerjee, D.D. "H₂S Removal from Fuel Gas During Coal Gasification," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, **35** (1), 196-206b (1990).
- Abbasian, J.; Rehmat, A.; Leppin, D.; Banerjee, D.D. "Desulfurization of Fuels with Calcium-Based Sorbents," *Fuel Processing Technology*, **25**, 1-15a (1990).
- Abel, W.T.; Shultz, F.G.; Langdon, P.F. "Removal of Hydrogen Sulfide from Hot Producer Gas by Solid Absorbents," U.S. Bureau of Mines, Washington, DC (1974).
- Adler, J.; Huttinger, K.J.; Minges, R. "Mixtures of Potassium Sulphate and Iron Sulphate as Catalysts for Water Vapour Gasification of Carbon," *Fuel*, **63**, 1397-1403 (1984).
- Barnes, J.R.; Clague, A.D.H.; Clayden, N.J.; Dobson, C.M.; Jones, R.B. "The Application of ²⁹Si and ²⁷Al Solid-State N.M.R. Spectroscopy to Characterizing Minerals in Coals," *Fuel*, **65**, 437-441 (1986).
- Bedick, R.C. "Status of Hot-Gas Cleanup Technology," *Proceedings of the Second Annual Fuel Cells Contractors Review Meeting*, May 1990, pp 105-120.
- Cicero, D.C.; Jain, S.C. "Status and Overview of the DOE-Funded Projects Related to the Chemical Gas Stream Cleanup Program," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, **30** (4), 1-16 (1985).
- Conoco Coal Development Company. "Plant Operations Final Report: CO₂ Acceptor Process Gasification Pilot Plant," Final Report for the Period January 1972 - October 1977, **12**, 208.
- Cox, J.L.; Sealock, L.J., Jr.; Hoodmaker, F.C. "Sulfur Problems in the Direct Catalytic Production of Methane from Coal-Steam Reactions," *Energy Sources*, **2** (1), 83-100 (1975).
- Curran, G.P.; et al. "Production of Clean Fuel Gas from Bituminous Coal," Work sponsored by EPA under Contract No. EHSD 71-75 (December 1973).
- Delannay, F.; Tysoe, W.T.; Heineman, H.; Somerjai, G.A. "The Role of KOH in the Steam Gasification of Graphite: Identification of the Reaction Steps," *Carbon*, **22** (4/5), 401-407 (1984).
- Guo, C-T.; Zhang, Li-M. "Kinetics of Coal Char Gasification at Elevated Pressures," *Fuel*, **65**, 1364-1367 (1986).
- Hengel, T.D.; Walker, P.L., Jr. "Catalysis of Lignite Char Gasification by Exchangeable Calcium and Magnesium," *Fuel*, **63**, 1214-1220 (1984).

- Hirsch, R.L.; Gallagher, J.E., Jr.; Lessard, R.R.; Wesselhoft, R.D. "Catalytic Coal Gasification: An Emerging Technology," *Science*, **215** (4529), 121-127 (1982).
- Nuttinger, K.J.; Minges, R. "Water Vapour Gasification of Carbon: Improved Catalytic Activity of Potassium Chloride Using Anion Exchange," *Fuel*, **64**, 486-490b (1985).
- Nuttinger, K.J.; Minges, R. "Catalytic Water Vapour Gasification of Carbon," *Fuel*, **64**, 491-494a (1985).
- Ishimori, M.; Senshu, S. "Development Status of Hot-Gas Cleanup Technology for IGCC Systems," *Proceedings of the Eighth Annual EPRI Conference on Coal Gasification*, Palo Alto, CA, August 1989, pp15-1 - 15-13.
- Johnson, G.E.; Field, J.H.; Decker, W.A.; Jameson, R.M. "Removing Hydrogen Sulfide from Synthesis Gas with Iron Oxide at Elevated Pressure," U.S. Department of the Interior, U.S. Bureau of Mines, Washington, DC (1962).
- Kasaoka, S.; Sakata, Y.; Tong, C. "Kinetic Evaluation of the Reactivity of Various Coal Chars for Gasification with Carbon Dioxide in Comparison with Steam," *International Chemical Engineering*, **25** (1), 160-175 (1985).
- Keleman, S.R.; Freund, H.; Mims, C. "Characterization of Potassium Catalysts Added as KOH to Carbon Surfaces," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, **30** (1), 349-359 (1985).
- Kertamus, N.J.; Woolbert, G.D. "The Direct Production of Methane from Heavy Hydrocarbons and Steam," *Energy Sources*, **2** (2), 203-216 (1975).
- Kimura, S.; Tone, S. Otake, T. "Methane Formation and Water-Gas Shift Reactions Over Potassium Carbonate Loaded on Coal Char at Elevated Pressure in H₂-CO-H₂O System," *Chemical Engineering of Japan*, **18**, 225-230 (1985).
- Kinoshita, McLarnon and Cairns. Complete manuscript pending (1988).
- Kokorotsikos, P.S.; Stavropoulos, G.G.; Sakellaropoulos, G.P. "Effect of Catalyst Impregnation Conditions on Greek Lignite Hydrogasification," *Fuel*, **65**, 1462-1465 (1986).
- Linares-Solano, A.; Hippo, E.J.; Walker, P.L., Jr. "Catalytic Activity of Calcium for Lignite Char Gasification in Various Atmospheres," *Fuel*, **65**, 776-779 (1986).
- Linares-Solano, A.; Almela-Alarcon, M.; Salinas-Martinez de Lecea, C.; Cazorla-Amoros, D. "Calcium Deactivation in CO₂ and Steam, Gasification Reactions," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem*, **34** (1), 136-143 (1989).

ENERGY RESEARCH CORPORATION

- Mims, C.A.; Pabst, J.K. "Role of Surface Salt Complexes in Alkali-Catalyzed Carbon Gasification," *Fuel*, **62**, 176-179 (1983).
- Miura, K.; Aimi, M.; Naito, T.; Hashimoto, K. "Steam Gasification of Carbon: Effect of Several Metals on the Rate of Gasification and the Rates of CO and CO₂ Formation," *Fuel*, **65**, 407-411 (1986).
- Nizinska-Bazaniak, B. "Steam Gasification of Coal Using Potassium Carbonate as a Catalyst," *Proceedings of the Sixth Annual International Pittsburgh Coal Conference*, Pittsburgh, PA, 1989, pp 811-818.
- Notestein, J.E. "Update on Department of Energy Hot Gas Cleanup Programs," *Proceedings of the Eighth Annual EPRI Conference on Coal Gasification*, Palo Alto, CA, August 1989, pp 14-1 - 14-43.
- Otake, T.; Tone, S.; Kimura, S.; Hino, Y. "Methane Formation Over Potassium Carbonate Catalyst Loaded on Coal Char," *Chemical Engineering of Japan* **17** (5), 503-508 (1984).
- Padrick, T.D.; Dees, D.D. "Catalytic Effects in Coal Gasification," Quarterly Report for the Period October - December 1980, pp 1-16.
- Pigeaud, A.; Yuh, C.-Y. "Effects of Coal-Derived Trace Species on the Performance of Molten Carbonate Fuel Cells," *Proceedings of the Second Annual Fuel Cells Contractors Review Meeting*, May 1990, pp 61-65.
- Pitrolo, A.A.; Bechtel, T.F. "Simplified IGCC: Coal's 'Adam Smith' Response to a Changing World," *Proceedings of the Seventh Annual EPRI Contractors Conference on Coal Gasification*, Palo Alto, CA, October 1988, pp 5-3 - 5-58.
- Pullen, J.R.; "Catalytic Coal Gasification," Report No. ICTIS/TR26, IEA Coal Research, London (June 1984).
- Ratcliffe, C.T.; Vaughn, S.N. "Population and Turnover Number of Active Potassium Sites on Bituminous Coals During Gasification," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, **30** (1), 305-310 (1985).
- Saber, J.M.; Falconer, J.L.; Brown, L.F. "Carbon Dioxide Gasification of Carbon Black: Isotope Study of Carbonate Catalysis," *Journal of Catalysis*, **90**, 65-74 (1984).
- Sams, D.A.; Talverdian, T.; Shadman, F. "Temperature Programmed Reaction Studies of Potassium/Carbon Interactions and Catalyst Loss," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, **30** (1), 341-348 (1985).
- Sears, R.E.; Timpe, R.C. "Production of Hydrogen from Low-Rank Coals," Quarterly Technical Progress Report for the Period January-March 1989," U.S. DOE, Morgantown, WV (1989).

ENERGY RESEARCH CORPORATION

- Sears, R.E.; Timpe, R.C. "Production of Hydrogen from Low Rank Coals," Quarterly Technical Progress Report, Energy and Mineral Research Center, May 1989, 24 p.
- Sears, R.E.; Timpe, R.C. "Production of Hydrogen from Low-Rank Coals," *Proceedings of the Ninth Annual Gasification and Gas Stream Cleanup Systems Contractors Review Meeting*, DOE/METC, 1989, pp 171-180.
- Stoddard, L.E.; Hughes, J.R.; Kulberg, H.A. "Production of Hydrogen from Low-Rank Coals," Final Report for the Period Ending May 1, 1989, U.S. DOE, Morgantown, WV (1989).
- Struck, R.T.; Schora, F.C., Jr. "Alkali Carbonate and Nickel Catalysis of Coal Stream Gasification," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, 18 (2), 29-42 (1973).
- Takarada, T.; Tamai, Y.; Tomita, A. "Effectiveness of K_2CO_3 and Ni as Catalysts in Steam Gasification," *Fuel*, 65, 679-683 (1986).
- Timpe, R.C.; Sears, R.E. "Anion Effects on Calcium Catalysts of Low-Rank Coal Char-Steam Gasification," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, 35 (2), 530-534 (1990).
- Timpe, R.C. Unpublished EERC Data (1991).
- Timpe, R.C.; Sears, R.E.; Willson, W.G.; Sondreal, E.A. "Production of Hydrogen from Low-Rank Coals: Char Properties and Reactivity," Topical Report, DOE Contract No. DE-FC21-86MC10637 (May 1989).
- Timpe, R.C.; Sears, R.E.; Willson, W.G.; Sondreal, E.A. "Production of Hydrogen from Low-Rank Coals," Topical Report for the Period April 1, 1986 - March 31, 1989, U.S. DOE, Morgantown, WV (1989).
- Timpe, R.C.; Sears, R.E.; Willson, W.G.; Sondreal, E.A. "Production of Hydrogen from Low-Rank Coals: Char Properties and Reactivity," Topical Report, DOE Contract No. DE-FC21-86MC10637 (May 1989).
- Vadovic, C.J.; Eakman, J.M. "Kinetics of Potassium Catalyzed Gasification," *Prepr. Pap.--Amer. Soc., Div. Fuel Chem.*, 23 (3), 89-107 (1978).
- Willson, W.G.; Sealock, L.J., Jr.; Hoodmaker, F.C.; Hoffman, R.W.; Cox, J.L.; Stinson, D.L. "Alkali Carbonate and Nickel Catalysis of Coal Steam Gasification," *Prepr. Pap.--Amer. Chem. Soc., Div. Fuel Chem.*, 18 (2), 29-42 (1973).
- Wood, B.J.; Sancier, K.M. "The Mechanism of the Catalytic Gasification of Coal Char: A Critical Review," *Science Engineering*, 26 (2), 233-279 (1984).

END

**DATE
FILMED**

7 / 27 / 92