RESEARCH & DEVELOPMENT REPORT
FISCAL YEARS 1989 & 1990

Bonneville

ALL RIGHTS RESERVED. NO PART OF THIS PUBLICATION MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT PERMISSION IN WRITING FROM BONNEVILLE.

Credits

*Editorial Board: Walter E. Myers,
R&D Manager; James J. Pachot, R&D
Engineer; James J. Ray, Transmission
Technology R&D Coordinator;
Jon R. Biemer, Energy Resources R&D
Coordinator; Gregory E. Drais, Fish
and Wildlife R&D Coordinator
Photography: BPA Photo Lab and
Sharon Blair*

Legal Notice

The Bonneville Power Administration (BPA) makes no warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report. Neither is any warranty or representation made that the use of information disclosed, whether about an apparatus, product, or process, might not infringe upon privately-owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply an endorsement, recommendation, or favoring by BPA. Nor does BPA assume any liability with respect to the use of, or the damages resulting from use of, any information, apparatus, method, or process disclosed in this report.

RESEARCH & DEVELOPMENT REPORT

FISCAL YEARS 1989 & 1990

DOE/BP--1418

*Office of the Assistant Administrator for Engineering
Bonneville Power Administration
U.S. Department of Energy
August 1991*

DE92 000884

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

400-

C O N T E N T S

List of Figures _____	2
List of Tables _____	2
List of Acronyms and Abbreviations _____	3
Obtaining Further Information _____	3
PROLOGUE	
<i>Collaboration, The Yeast of R&D</i> _____	4
Fish and Wildlife	
SPOTLIGHT	
<i>The More Oxygen, The More Fish!</i> _____	8
SPOTLIGHT	
<i>Squawfish Fall Prey to Bounty Hunters</i> _____	12
SPOTLIGHT	
<i>White Sturgeon (Acipenser transmontanus)</i> _____	14
CURRENT PROJECTS	
<i>Reservoir Mortality and Water Budget</i>	
Smolt Collection Efficiency, McNary Dam _____	17
Fish Survival and Smolt Physiology _____	17
Behavior Workshops _____	17
Survival Rates, Lower Granite Reservoir _____	17
Flow Effects on Chinook Salmon, John Day Reservoir _____	17
<i>Hatchery Effectiveness</i>	
Hatchery Design, Yakima and Klickitat Rivers _____	17
Juvenile Salmonid Behavior, Columbia River Estuary _____	17
Malachite Green Removal _____	18
Rearing and Imprinting Fall Chinook, John Day _____	18
Wild Adult Steelhead Protection, Upper Snake River _____	18
Low-cost Saimon Production Facilities _____	18
Distribution of Columbia Hatchery Chinook to Pacific Salmon Fishery _____	18
<i>Fish Disease</i>	
Vitamin Nutrition: Effects on Immune Response System _____	18
Vaccine Development for Bacterial Kidney Disease (BKD) _____	18
<i>Supplementation</i>	
Analysis of Supplementation Efforts _____	19
<i>Evaluation and Monitoring</i>	
Freeze Brand and PIT Tag Data, McNary Dam _____	19
<i>Related and Support Projects</i>	
Reservoir Level Requirements, Hungry Horse _____	19
Reproductive Success of Kokanee, Hungry Horse and Kerr Dams _____	19
<i>Additional Projects</i> _____	20
INFORMATION RESOURCES _____	21

Energy Resources

SPOTLIGHT	
<i>Adjustable Speed Drives (ASD)</i> _____	24
SPOTLIGHT	
<i>Amorphous Transformers Keep on Saving—Day In, Day Out!</i> _____	27
SPOTLIGHT	
<i>Geothermal: The Resource Whose Time Has Come</i> _____	30
SPOTLIGHT	
<i>Understanding Ventilation in Energy-Efficient Residences</i> _____	32
CURRENT PROJECTS	
<i>Commercial Conservation</i>	
The Energy Edge Occupant Satisfaction Study _____	36
Evaluation of Energy Management Systems (EMS) _____	36
<i>Industrial Conservation</i>	
High Efficiency Electric Motor Rewind Study _____	37
Energy-Efficient Dessicant Dehumidifier (EEDD) _____	37
Pneumatic Conveying of Wood Waste _____	37
Vencer Cooler Sorter _____	37
Pinch Technology in Pulp and Paper Application _____	37
Case Study on Dehumidification Drying of Lumber _____	37
High Efficiency Electric Motor Guidebook _____	37
<i>Residential Conservation</i>	
High-Resistivity (High-R) Windows _____	38
Wall Moisture Study _____	38
<i>Utility Conservation</i>	
Conservation Voltage Reduction (CVR) _____	38
Quality of Power _____	38
<i>Generation</i>	
Adaptive Power Factor Controller _____	39
Brushless Doubly Fed Machine _____	39
Generation Technology Studies _____	39
Variable Speed Generation _____	39
<i>Additional Projects</i> _____	40
INFORMATION RESOURCES _____	41

Transmission Technology

SPOTLIGHT

<i>Advanced Tools for System Operation and Maintenance</i>	44
Communications Alarm Processor	44
Lightning Monitoring System	45
Security Enhancement System (SES)	45
Extra-High Voltage (EHV) Current Transformer Monitor	45
Equipment Diagnostics and Maintenance Techniques	46
Reliability-centered Maintenance (RCM)	46

SPOTLIGHT

<i>Treatment of Penta-contaminated Soils</i>	47
--	----

SPOTLIGHT

<i>Advanced Technologies in Substation Equipment and Design</i>	50
Power Circuit Breaker Controls	50
Power Electronics and Solid-state Equipment	52

SPOTLIGHT

<i>Stability Prediction and Control</i>	53
---	----

CURRENT PROJECTS

<i>Environment, Health, and Safety</i>	
Magnetic Fields Characterization	54
<i>Substation Equipment and Design</i>	
Grounding Study	54
Substation Rock Reclamation	54
Capacitor Studies	54
High-strength, Conductive Adhesives	54

Advanced System Studies

Voltage Collapse Identification	55
Tacoma Load Modeling	55
Signal Analysis	55
Dynamic Interaction Monitoring System	55
Staged System Testing Methods and Techniques	55

Power System Control

Digital Stability Controller	56
Static VAR Control for Power System Damping	56
Relay Tests	56
Protection and Control Test Systems	56
Consolidated Operator-machine Interface	56

Transmission Line Technology

Moro Structural Mechanical Test Program	57
Reliability-based Design of Transmission Lines	57
Conductor Vibration Field Test	57

System Operation and Maintenance

Rotor-mounted Scanner	57
Hotline Detector	57
EHV Laboratory Studies	57

<i>Additional Projects</i>	58
----------------------------	----

INFORMATION RESOURCES	62
-----------------------	----

List of Figures

Figure 1.	Oxygen Transfer Columns at Willamette Hatchery	9
Figure 2.	Diagram of Oxygen Transfer Columns	10
Figure 3.	Prototype Low-Head Oxygen System Layout	11
Figure 4.	BPA's Squawfish Bounty Gets Results	13
Figure 5.	Side Views of Stages of White Sturgeon Larvae and Fry Development	15
Figure 6.	Columbia River: Boundaries of Sampling Area	16
Figure 7.	Estimated Mean Densities of Juvenile White Sturgeon	16
Figure 8.	Basic Block Diagram of an ASD System	25
Figure 9.	ASD Applications Matrix	26
Figure 10.	Customer-Installed Amorphous Steel Transformers, City of McMinnville	28
Figure 11.	Schematic of a Typical Geothermal System	31
Figure 12.	Whole House Ventilation Integrated with Central Forced Air System	33
Figure 13.	Air Exchange Rates and Unit-to-Unit Air Flows	34
Figure 14.	Sample Occupant Survey Form	35
Figure 15.	PCP Contaminated Soils Research Process	48
Figure 16.	Photographs of Sampling Process	49
Figure 17.	A. Conventional Substation Equipment B. Integration of Substation Functions	51
Figure 18.	Electronic Speed in a Power Circuit Breaker	52

List of Tables

Table 1.	R&D Budget, Fiscal Years 1989 and 1990	6
Table 2.	Major Behavioral Events in Early Life History of Columbia River White Sturgeon	17
Table 3.	Calculating Costs of Amorphous Steel Transformers	28
Table 4.	The Case for Geothermal	31

List of Acronyms and Abbreviations

AC	alternating current
ASHRAE	American Society of Heating, Refrigerating, and Air Conditioning Engineers
BKD	bacterial kidney disease
BPA	Bonneville Power Administration
DC	direct current
EHV	extra-high voltage
EMF	electro-magnetic fields
EMTP	Electro-magnetic Transient Program
EPA	Environmental Protection Agency
EPRI	Electric Power Research Institute
FACTS	flexible AC transmission system
FY	fiscal year
GIS	gas-insulated substation
high-R	high resistivity
HVAC	high-voltage alternating current
HVDC	high-voltage direct current
Hz	Hertz
IDFG	Idaho Department of Fish and Game
IHN	infectious hematopoietic necrosis
IPP	implementation planning process
kv	kilovolt
kVA	kilovoltampere
kWh	kilowatthour
MCS	Model Conservation Standards
MW	megawatt
MW-Hr	megawatt hour
NMFS	National Marine Fisheries Service
ODFW	Oregon Department of Fish and Wildlife
ORNL	Oak Ridge National Laboratory
OSU	Oregon State University
PCP	pentachlorophenol
PCB	polychlorinated biphenyl
R&D	research and development
RODS	real-time operating and dispatch system
RTU	real-time unit
RTV	room-temperature vulcanized
SCADA	supervisory control and data acquisition
SIC	Standard Industrial Classification
SMES	Superconducting Magnetic Energy Storage
TAU	Testing Automation Unit
TCDS	Transmission Control and Dispatch System
TCSC	thyristor-controlled series compensation
UHV	ultra-high voltage
USGS	U.S. Geological Survey
USFS	U.S. Forest Service
USFWS	U.S. Fish and Wildlife Service
WDF	Washington Department of Fisheries
WDW	Washington Department of Wildlife

Obtaining Further Information

There are two avenues provided in this report for the reader who wishes further information.

First, each of the three sections ends with **Information Resources**, a bibliography of project reports and technical articles in the particular technological category. Many of the reports are available in technical journals; others through BPA's Public Involvement Office.

Address your inquiries to Public Involvement, Bonneville Power Administration, P.O. Box 12999, Portland, OR 97212 or by calling 503/230-3478. In Oregon, you may call the Public Involvement Office toll free at 1-800/452-8429. From other western states (Oregon, Washington, Idaho, Montana, Wyoming, California, Nevada, and Arizona), you may call toll free to 1-800/547-6048.

If a document number is specified (*example*: DOE/BP-11111), you may leave a message at the document request line at 1-800/841-5867 (for Oregon callers) or 1-800/624-9495 (for callers from other western states).

Secondly, with each project description, individuals are listed as contacts by full name and mail routing code. Readers may elicit further information by addressing those individuals, with the routing code, at the Bonneville Power Administration, P.O. Box 3621, Portland, Oregon 97208. Those individuals may also be reached through the main BPA switchboard at 503/230-3000.

Collaboration, the Yeast of Research and Development

Since the 1940s, the Bonneville Power Administration (BPA), has sought to advance an efficient system to provide the Pacific Northwest region with safe, reliable, and cost-effective electrical power. Research and development (R&D) activities support that mission.

Each biennium, R&D managers issue a digest report of the various programs and activities in each of the technological arenas. The report covers a few projects, considered as yielding particularly significant results, as **spotlights**. Others are described less fully; in some cases with a simple annotation.

The report's divisions correspond to the major categories of R&D projects:

- Fish and Wildlife,**
- Energy Resources, and**
- Transmission Technology.**

The report reaches our BPA colleagues, customers and industry peers, and other researchers throughout the international electric utility community. The report serves as a networking vehicle for BPA to record and transfer knowledge from a broad scope of research interests, enabling both people within the organization and people elsewhere to share information or to seek ways to collaborate in meeting common goals. In fact, the theme of this biennium's report is **research collaboration**.

Collaboration is the underpinning of creative activity, of mastering a new skill or unmasking new information or strategies. We rely on our own training, but reach out for others' perspectives, for others' expertise. We want that interplay of ideas and concepts. We are aware that the integration of diverse experiences can spark discovery, inspire change, transcend individual abilities.

Collaborators reach out, tying one discipline or specialty to another, bringing together theoretical and practical knowledge, getting the program leaders to sit down with those from the field. Like the yeast in bread-making, collaboration is a catalyst. The yeast acts on the basic flour particles and water droplets to expand that simple mixture in bulk, flavor, and appeal.

Thus collaboration amplifies individual contributions into outcomes more innovative, more complete, and more useful, than what each person, working alone, could have accomplished. What a rich difference!

Managers sometimes focus on the cost sharing aspect of collaboration. And that's important. Dwelling on just that facet, however, constrains us from the full vision of collaboration's advantages. As co-funding gives us financial leverage, so does co-experimenting, co-planning, co-working, or co-discovering gives us intellectual leverage.

The leverage of co-funding is outweighed by the leverage that comes from sharing resources, directions, and perspectives. Shared expertise. Exchanges of ideas. Participatory work planning. Support networks. Interactions between disciplines. Co-sponsored facilities. Mutually agreed goals and applications. Transfers of technology. Accelerated accomplishments. Broader acceptance of results.

Collaboration as a catalyst is nowhere more evident than in technical research and development.

An apt illustration comes from the chronology of BPA's involvement in underground cable research. 1988, the agenda of a technical gathering in Portland, Oregon, delineated the problems utilities were having with extruded dielectric cables. Discussions continued throughout the year at meetings of the Northwest Electric Utility Engineering Forum. By fall, the Forum's R&D committee had sponsored a cable symposium held in British Columbia.

As part of the follow-up to that symposium, BPA helped to develop and host the first distribution cable workshops for EPRI's member utilities in 1989. Similar workshops are now given in various locations throughout the country. Another cable fault location workshop was held in the spring of 1990 hosted by BPA and the Clark County (Washington) Public Utilities.

A full-fledged working group formed, inspired by more than 70 responses from a mailing to the contingent of utilities serving the Pacific Northwest. By 1991, meetings of that working group had occurred in Portland, Seattle, and Spokane. The group identified itself as a platform for discussion of underground cable problems and solutions and as a forum for sharing research and techniques. In addition, the group agreed to establish a library of materials and training aids and to sponsor appropriate workshops.

From the expressed interest, a research project has evolved, to produce an expert system for cable fault location.

On the whole BPA has found that collaboration means that research and development proceeds more efficiently, brings about more complete and relevant results, and—ultimately—that products and processes become accepted and used more widely if more entities are involved. And along the way, projects take on a robust quality that cannot be replicated in a project done in a vacuum, so to speak, without the collaborative flavor and fervor.

One word of caution: Collaboration is a means to accomplish needed research, not an outcome of that research. The incentive to collaborate must, on a case-by-case basis, determine that benefits will accrue to the participants and exceed the value of the effort.

The Electric Power Research Institute— Collaboration Exemplified

The Electric Power Research Institute (EPRI), founded in 1972, established for private and public utilities the ultimate vehicle for collaborative opportunities. EPRI's members represent more than 69 percent of the nation's electric service. BPA's membership in EPRI serves as the conduit for 118 customers in the Pacific Northwest, along with several other federal agencies, to participate in and help shape a research program funded by 660 utilities nationwide.

The benefits are very direct. EPRI research results are available to members, to state agencies, to the Northwest Power Planning Council, and numerous other entities. Each utility can tap into the combined experience of all the other utilities in formulating new programs, building new system components, tracking down and solving problems, keeping up with emerging technologies, and understanding rapid shifts in policy or regulations or markets.

*In 1990, EPRI introduced a new approach to R&D through **tailored collaboration**. Members now have even greater flexibility in choosing R&D opportunities, moving research into the market-driven arena and targeting regional needs.*

Other Effective Collaborations

BPA pursues cooperative efforts in many venues and encourages its personnel to become involved in a host of organizations to maintain and extend an active role in fostering contacts, developing networks, exchanging information, and cooperating in projects. These networking opportunities are not an idle pastime, but a vital link in the definition, initiation, and execution of research programs that benefit BPA's service area.

Internationally, we are involved in contacts with foreign utilities and manufacturers, the Conference Internationale des Grands Reseaux Electriques a haute tension (CIGRE), and many committees and working groups under the aegis of the Institute of Electrical and Electronic Engineers (IEEE).

Nationally and regionally, the number of collaborators are nearly endless: U.S. Department of Energy (DOE), U.S. Fish and Wildlife Service, Bureau of Land Management, Corps of Engineers, Northwest Power Planning Council, regulatory bodies, national laboratories, state agencies, academic institutions, industry and user groups, and professional societies of several disciplines.

Collaboration as a Base for the Future

Perhaps most importantly, the collaborative approach that we have built gives our R&D programs an important momentum that carries us into the future. Our project outcomes will continue to give practical results within the industry, applicable solutions to our customers, and will ensure meeting our mission to the region's ratepayers.

Walter E. Myers, Manager
Research and Development

	FY 1989 Obligations (\$000)*	FY 1990 Obligations (\$000)*
Energy Resources		
Generation Sector	1,100	1,030
Industrial, Agricultural & Utility Sector	350	150
Commercial Sector	180	420
Residential Sector	260	350
	1,890	1,950
Transmission Technology		
Environment, Health and Safety	490	860
Substation, Equipment and Design	720	930
Advanced System Studies	550	680
Power System Control	1,510	930
Transmission Line Technology	490	570
System Operations and Maintenance	390	550
R&D Management	370	310
	4,520	4,830
Fish and Wildlife Total	1,200	1,200
Electric Power Research Institute	6,500	6,700
BPA R&D Program Total	14,110	14,680

* Dollar amounts shown do not include agency overheads

Table 1: R&D Budget, Fiscal Years 1989 and 1990

BPA's mission is inextricably linked with environmental responsibilities, as the agency balances the needs of maintaining both the adequate, reliable power service so vital to the region's population and the bounty of the Northwest's environmental resources.

The Northwest Power Planning Council shares these concerns and has formulated far-reaching guidelines for biological assessment, study, and protection measures targeted toward fish and wildlife populations. The Council's Columbia Basin Program, one of the most comprehensive fish and wildlife rehabilitation programs in the world, uses substantive funding from BPA.

In recent years, BPA has instituted a collaborative implementation planning process (IPP) for all fish and wildlife funding and activities, including R&D. The process brings in the knowledge and expertise of federal, state, and tribal organizations to define R&D needs. Representatives from the region's utility industry and from special interest groups also participate in the IPP.

The IPP includes a scientific review group of fisheries and wildlife scientists who assess project proposals, methods, and likelihood of success. The IPP is still in a formative stage but has already proven valuable as a tool, ensuring more direct applicability of fish and wildlife R&D projects.

On another front, cooperation with the Electric Power Research Institute (EPRI) is key. For example,

EPRI had undertaken a study of fish protection systems using data from 100 sites, incorporating a literature survey, and including a detailed report (*Assessment of Downstream Migrant Fish Protection Technologies for Hydroelectric Application*). BPA and other utilities were also faced with the need for this data. EPRI's study was so comprehensive that BPA did not need to replicate the effort, resulting in savings of about \$150,000.

The following narrative reports on some Fish and Wildlife projects in detailed spotlights. Briefer project descriptions cover the categories of reservoir mortality and the water budget; hatchery effectiveness; disease; artificial supplementation of natural populations; and evaluation and monitoring.

At the end of each project description, a contact individual is named, with a mail routing code. To obtain more information about a particular project, please address correspondence to that individual, including the routing code, at the Bonneville Power Administration, P.O. Box 3621, Portland, OR 97208, or call the listed individual through BPA's main switchboard at 503/230-3000. [See also **Information Resources** section on page 21 and **Obtaining More Information** section on page 3.]

Greg Drais, Coordinator

Fish and Wildlife Research and Development

The More Oxygen, The More Fish!

In fish culture, one of the critical factors in growth and survival is density. The population size at hatchery ponds has been limited by that density, widely accepted as dependent on the amount of available oxygen. If fish hatcheries outstrip a certain ratio of fish to space, negative effects follow, including stress and disease.

"We want to see if we can eliminate oxygen as a limiting factor relative to the number of fish we can raise in a given amount of water," explains Gerald Bouck, a BPA fisheries expert. If oxygen supplementation at existing hatcheries can increase rearing capacity, it will enable BPA and the Northwest Power Planning Council to expand hatchery product capacity much more economically, saving millions of dollars and valuable time.

The oxygenation supplementation appears able to increase harvests without big increases in capital costs.

Cooperating in the project at the Willamette Hatchery (Oakridge, Oregon) are the Oregon Department of Fish and Wildlife and Oregon State University.

Oxygen Use by Fish

Fish use dissolved oxygen from water brought into their blood via their gills. Put in the simplest of terms, the oxygenated water comes into close contact with the blood's hemoglobin for extraction. Gill tissue has differentiated to increase the surface area available for the process. The rate and level of diffusion of oxygen into the blood depends in large part upon oxygen pressure in the water.

At the same time, the gill tissue acts as an outlet for discharge of waste products: carbon dioxide, ammonia, and urea. The actual exchange process, a complex one, is itself the subject of much debate and experimentation. Calculating the oxygen requirements of fish has become an integral part of determining water quality standards for rivers and lakes. Other reviews have concentrated on the requirements for fish culture.

Oxygen absorption is the key in metabolic processes that produce energy for growth, renewal and movement. For BPA's research purposes, the emphasis is on the oxygen needs of salmonids to meet the demands of metabolic rates that change from basal to active depending on the situation.

Where oxygen concentrations are too low, numerous side effects occur, although the extent of the impacts vary from species to species. Some effects can involve:

- reduced growth rates,
- increased diseases,
- lowered food conversion, and
- impaired swimming ability.

Air contains only 21 percent oxygen and about 78 percent nitrogen. Careful control is necessary to prevent harm to the fish from an excess of dissolved gases

(gas bubble disease) or from toxic amounts of oxygen. The use of relatively pure oxygen ensures that the nitrogen will be displaced.

Careful analysis eliminated some concerns anticipated earlier in the project. Water quality dropped little, despite the exhalation of carbon dioxide, primarily because the water in this

region is natural buffered, or light in minerals and chemicals. Pneumonia and feces buildup did not prove problematic.

Fish Hatchery Design

The project has renovated an existing hatchery near Willamette Falls to incorporate the equipment needed to increase the amount of dissolved oxygen available to the salmonid fingerlings.

The project uses a "multiple pass system," explains BPA researcher Alan Ruger. "Water comes through one raceway, where oxygen is added, and then through another raceway where more oxygen is added. The two-step process seems to cause less stress and therefore the fish remain more resistant to disease. On the other hand, there is the potential for greater exposure to disease by using the multiple pass system."

Different oxygen transfer systems have been tested in fish culture applications. Some are high pressure, some low, and others passive. The BPA project's remodeled facility based its oxygen transfer columns on a design used by the Michigan Department of Natural Resources (see figures 1 and 2).

Key characteristics of the Michigan columns are:

- no packing to plug inside the column,
- a discharge pipe smaller than the column itself, and
- production of a partial vacuum inside the column to remove nitrogen.

The columns for oxygen injection developed some excessive vibration under full impact of needed water flow. Supports were devised to dampen this vibration and extend the columns' useful life. Other installed equipment, and modifications, included:

- walkways for feeding fish,
- meters unaffected by temperature to regulate oxygen flow,
- electrical alarms to monitor continuous operation of pumps and other system components,
- modified raceway baffles, and
- slotted intake screens.

Absorption Rates

The oxygen absorption rates of the Michigan-style columns ranged from 30 to 60 percent.

In addition to testing the Michigan columns, the project has examined a newly developed prototype unit of a low-head oxygen distribution unit. (See figure 3.) The oxygen is introduced into one cell and then flows across other cells. Water flows first through a distribution plate and across the cells in parallel. The cells are not packed with any media.

Absorption efficiencies as high as 90 percent are possible for these units.

Figure 1 Oxygen Transfer Columns at Willamette Hatchery

Rearing Costs with Oxygen Supplementation

A oxygen supplementation program can save the capital investment of expanded or new hatchery construction through the refitting of existing facilities. However, the cost of oxygen supplies has to be factored in to assess overall cost-effectiveness. In that picture, the absorption rate for the oxygen is a critical factor.

The annual oxygen demand for the Willamette Hatchery supplementation project is approximately 31,713 pounds of oxygen. Based on a purity of 99.6 percent and oxygen costing \$0.40/100 cubic feet, the annual costs could range between \$1500 and \$6100.

Contribution to Smolt Migration Studies

Ultimately, the project's success will be measured in terms of the success of fingerlings in surviving the life cycles of downstream migration and returns. Currently, about 40 to 50 percent of the chinook on the Willamette River are lost. Researchers need to know if those hatchery fish raised in an oxygen-supplemented facility behave typically as they migrate. The long-term need to track smolt from the supplementation project has also contributed a substantial amount of new information to ongoing smolt migration studies for BPA.

Quite directly, the need to track hatchery salmonids from the oxygen supplementation program has led to "plowing new ground about fish behavior," as Bouck puts it.

C. Samuel Bradford and Carl Schreck of Oregon State University have learned some fairly surprising things about the migration patterns of the spring juvenile chinook tagged for observation from Willamette Hatchery.

The majority begin downstream movement immediately on release and travel at about three miles per hour for the first 48 hours of their migration. Ten to nineteen percent temporarily stop just above Willamette Falls and then resume seaward migration within two weeks. Up to ten percent stay in the upper river, close to the release site, for two weeks or more. Juveniles feed actively during migration, primarily on aquatic insects.

Returning adult spring chinook migrate upstream at a rate of about 12 to 18 miles each day, arriving in the upper river within two weeks of passing Willamette Falls. Unexpectedly, a large number turn out to be wanderers, acting in ways quite contrary to expectations about migration behavior. Some of the straying fish lead radio tracking teams a merry chase. Salmonids have roared up the Santiam, come back to Portland harbor, and then plunged back along to the Clackamas River, or ended up hooked in Dog Creek.

The information on the migratory characteristics is necessary to the assessment of oxygen supplementation as a means of improving hatchery production. The data may also show that this sideline—the examination of migratory characteristics in hatchery smolts—will prove even more informative, according to Schreck.

Figure 2. Diagram of Oxygen Transfer Columns

Project Outcomes

Meanwhile, the increased production of healthy salmonids through use of oxygen supplementation has led to a cooperative effort with the confederated Umatilla tribes and the Oregon Department of Fish and Wildlife to build and operate a similar hatchery operation close to the Umatilla River.

The Willamette hatchery experience—including the problems encountered throughout design and construction and the solutions instituted—has already proven invaluable to the Umatilla project. BPA began funding design of the Umatilla facility in FY 1980; the master plan was approved in FY 1989. Oxygen supplementation at the Umatilla operation is expected to produce up to 290,000 pounds of summer steelhead and chinook smolts. BPA will fund operation and maintenance at the hatchery and will begin planning for satellite facilities that could come on line by the mid-1990s.

Contact: Gerald Bouck, P/E, Alan Ruger, P/JSR

Figure 3. Prototype Low-Head Oxygen System Layout

Squawfish Fall Prey to Bounty Hunters

In what is perhaps a first in BPA's history, the agency has arranged for a bounty payment on a predatory fish. The predator fish, the northern squawfish, is the central villain identified by a resource management program striving to improve survival of baby salmon and steelhead in the lower Columbia and Snake rivers. Research between 1982 and 1988 determined that about three million juvenile salmon and steelhead were consumed each year in the John Day Reservoir by squawfish, walleyes, and smallmouth bass.

That represented an unacceptable loss of 14 percent of all the juvenile salmonids entering the pool, with sub-yearling fall chinook the most vulnerable. The fall chinook suffered losses of up to 60 percent when water temperatures were warm and predators active. Other major losses were suffered among spring chinook and sockeye.

About 78 percent of the loss was credited to the squawfish, any one of which might ingest seven or more smolts a day. BPA biologist Bill Maslen notes that he has observed squawfish in "a virtual feeding frenzy."

With a 10 to 20 percent reduction in the number of squawfish in the lower Columbia and Snake rivers, it is believed about ten million more salmon could survive to continue downstream to the ocean. Eventually, biologists estimated that would mean tens of thousands more adult salmon and steelhead returning to the Columbia each year. The concentrated efforts to reduce encroachments on salmon runs has led BPA to funding a bounty program.

The program is multi-faceted and implemented cooperatively by regional fishery agencies and tribes. The Oregon Department of Fish and Wildlife (ODFW) coordinates the overall program. Assistance comes from the U.S. Fish and Wildlife Service (USFWS), Columbia River Inter-Tribal Fish Commission, Nez Perce Tribe, Confederated Tribes of the Umatilla Indian Reservations, Confederated Tribes of the Yakima Indian Nation, Washington Department of Wildlife (WDW), University of Washington, Oregon State University, Computer Services Corporation, Pacific States Marine Fisheries Commission, and the National Marine Fisheries Service (NMFS).

In 1990, a pilot program was conducted to assess the feasibility of a full-scale fishery. Three tribal fishers set long-lines in the John Day reservoir and captured over 1,400 squawfish. Sports fishers received up to \$3 for every squawfish; they reeled in about 4,700 fish. Technicians working for ODFW fished in the restricted zones at lower Columbia River dams in 1990. Over 11,000 squawfish were harvested using this technique.

In 1991, WDW will manage the sport-reward fishery; the Pacific States Marine Fisheries Commission will cope with reward payments and accounting.

The Columbia River Inter-Tribal Fish Commission will manage the dam angling fisheries with the aid of tribal representatives. ODFW will coordinate the tribal long-line fishery and a program evaluation with the support of USFWS. The University of Washington and NMFS will test various harvest techniques. Oregon State University (OSU) is responsible for research into squawfish use and for a socio-economic evaluation of the program.

All in all, a lot of folks are ending up with a lot of squawfish. And this giant member of the minnow family is a mass of bones; biting into one has been compared to biting into a box of exploding toothpicks.

However, the fish won't be wasted, not if OSU's fisheries economist Sue Hanna can help it. She has found ways to market the fish. Hanna has arranged for the fish to go from collection point freezers to a deboning plant in Astoria. Hanna is also investigating ways that processors might experiment with squawfish in a fish-skin leather of similar texture to eel-skin. Perhaps the best idea of all is grinding the

catch up for fish meal. Ultimate destination? Hatcheries, to feed baby salmon!

The goal is a 50 percent reduction in predation in the lower reservoirs of the Columbia and Snake rivers. Based on computer modeling by BPA, that would increase the relative survival of upriver stocks to below Bonneville Dam by 15 to 35 percent for spring, summer and fall chinook and sockeye. That level of a reduction may take up to ten years.

Contact: Bill Maslen, PJI

*Figure 4 BPA's Squawfish Bounty Gets Results
Bill Johnson and sons, Mark (8) and Jim (11), turn in
34.2 lbs. of squawfish at Corvallis Landing near Bonneville Dam*

White Sturgeon (*Acipenser transmontanus*)

Since 1984, BPA has funded ongoing programs to study sturgeon populations in the Columbia Basin, as the sturgeon has become an increasingly important element in the commercial and sports fisheries of the area. Impacts on the sturgeon from the development and operation of the hydroelectric system were thought substantial, but had not been precisely defined. Management decisions regarding the Columbia River white sturgeon, as a valued resource, depend on understanding the species' life cycles, vulnerabilities, and habitat requirements.

A series of workshops determined a work plan for sturgeon research. This was submitted to the Northwest Power Planning Council and component tasks identified. Two projects are currently funded by BPA:

Life History and Genetics. The life history requirements and genetic makeup of stocks throughout the Columbia Basin, under the coordination of a research team at the University of Idaho.

Habitat Requirements. A four-agency, six-year project to determine habitat requirements and the status of stocks downstream from McNary Dam.

Life History and Genetics

Assistance in obtaining field samples has come from many sources: NMFS, ODFW, Washington Department of Fisheries (WDF), Kettle Falls National Park Service, Idaho Department of Fish and Game (IDFG), the Coverts Landing fishery, the University of California at Davis, and many sports fishers.

Investigations included both laboratory work at the University of Washington's School of Fisheries and field observations. Field data provided the base for laboratory studies to simulate environmental situations in the Columbia. Researchers collected field samples for the electrophoresis analysis from Roosevelt Lake, the Snake River, the mid-Columbia, and below Bonneville Dam, to represent the distribution range of white sturgeon. Samples were also gleaned from sport and commercial fishery harvests and from fish packing facilities.

Early life cycles. White sturgeon are spawned on the substrate, but not covered. White sturgeon eggs are very adhesive and attach on contact. The species is very fecund and mortality rates at this stage seem high. However, hatching usually occurs in darkness, providing immediate cover for the new larva.

Yolk sac larvae then swim randomly in the water column for several days before seeking shelter, under rocks and in other hiding places on the stream bottom. The larva respond to water currents, using them to disperse away from the spawning ground. The latter hiding behavior reduces their vulnerability to predation but its effectiveness also depends on the composition of the available substrate.

Feeding habits. Yolk absorption (see figure 5) and the start of feeding coincide at about 10 days after hatching (see table 2). Larva actively forage on the substrate and in the water column. Once feeding starts, juvenile fish move continuously. Feeding, whatever the age, continues to exhibit ran-

dom, opportunistic patterns, indicating that visual cues are not used.

In feeding, olfactory cues are apparently more important than visual: the sturgeon develops large olfactory rosette receptors. These allow the fish to find the general location of foodstuffs. However, capture of particular prey is subject to physical contact by the barbel, which triggers a carefully timed protrusion of the jaw to engulf the food item.

Hiding tactics. Juvenile white sturgeon are seldom observed in nature until they reach two or three years of age. Older fish stick to bottom areas and seldom use shallow waters. Both the young and adult fish seem to use low illumination cues for hiding as a strategy to avoid predators.

Temperatures, oxygen, salinity. Once fish begin to feed, temperature changes have little affect on their behaviors. Low oxygen levels bring larva out of hiding, but older

Days Post Hatch	Event
Hatch	Hatching occurred during darkness in 16.4 °C water
0	Upon hatch yolk sac larvae enter water column
1	Larvae in high velocity arena begin to settle upon substrate within cover
5	All fish in both arenas upon substrate within cover
9	Yolk sac almost depleted, fry moving out onto open substrate, initiation of feeding
13	Yolk sac depleted, all fry upon open substrate actively feeding (Water temperature 16.0 °C)

Table 2 Major Behavioral Events in Early Life History of Columbia River White Sturgeon

Figure 5 Side Views of Stages of White Sturgeon Larvae and Fry Development

white sturgeon apparently lower their activity rates to wait out temporary oxygen deficits. White sturgeon prefer salinity levels of 10 parts per thousand or less. At greater salinities, the young suffer fairly high mortality.

Genetics. Analyses performed on fish throughout the Columbia have discerned only minor population differences and evidence is very weak that genetic differences occur between the upper and lower reaches of the river. Some evidence has been found to indicate that white sturgeon stocks in Roosevelt Lake and the Kootenai River are somewhat genetically differentiated from stocks in the Columbia's main stem.

Habitat Requirements

The second area of research depends on a collaborative effort between agencies, with each undertaking a specific set of study objectives. ODFW reports have described the life history of subadults and adults between Bonneville and McNary dams. WDW research has focused on the recreational fishery of the same area, and description of the reproductive and early life history characteristics downstream from Bonneville Dam.

The USFWS work concentrates on habitat requirements for spawning and rearing activities between the two dams, and catalogs the available habitat. The NMFS effort defines reproductive and early life history and available suitable habitat downstream of Bonneville.

The approach is to work concurrently downstream and upstream from Bonneville Dam. Work began in the Dalles Reservoir in 1987 and expanded to the Bonneville and John Day reservoirs in 1989.

A vast bank of statistics was obtained over the research period: abundance, overall mortality, fishery catches, size and growth, ages, habitat, and reproduction.

Above Bonneville dam, white sturgeon samples were taken by ODFW teams from April through August in 1989 and in June and July in 1990. (See figure 6.) The 774 seelings in the Bonneville Reservoir caught 3,378 white sturgeon; 70 seelings in The Dalles reservoir caught 232 fish. Fork length of the fish ranged from 27 to 256 centimeters, while ages spanned 1 to 38 years.

Sturgeon moved throughout both reservoirs. Some of the recaptured fish (tagging began in 1987) had moved up to 5.1 kilometers (km) from the site of original capture and marking; nearly 25 percent had moved at least 10 km.

Interviews in 1989 included 7,757 recreational anglers at The Dalles Reservoir, 5,682 at the Bonneville Reservoir, and 1,867 at the John Day Reservoir. Estimated harvest by recreational fishery was 199 sturgeon from The Dalles, 2,619 from Bonneville, and 282 from John Day in 1989. Boat anglers had almost twice the success of bank anglers.

Below Bonneville Dam, 7,036 sturgeon were caught using gill nets in 1989. Of those fish caught, 5,389 were tagged; that includes 1,273 fish tagged in the Columbia River estuary. In addition, 1,409 sturgeon caught by recreational anglers were also examined.

Samples were also taken of eggs and larvae; additional data collected covered substrate characteristics, fish size, water temperatures and turbidity, feeding habits, ages, water column velocities, and water composition including dissolved oxygen.

By sampling eggs, larvae, and juveniles between Bonneville and McNary dams from February through November 1989, the U.S. Fish and Wildlife Service determined evidence of predation on white sturgeon eggs by large-scale sucker, common carp, sculpin, and northern squawfish. White sturgeon consumed a variety of prey, mostly benthic invertebrates. *Corophium salmonis* accounted for 33 percent of the total diet by weight. The same prey was preferred by white sturgeon below Bonneville Dam.

NMFS conducted two benthic surveys to help determine habitat preferences of spawning white sturgeon. Where eggs and larvae were found, substrate samples were also taken. These were analyzed by the North Pacific Division Materials Laboratory of the U.S. Corps of Engineers for sediment grain size and volatile solids. In addition, water temperatures, turbidity, depths, and velocities were itemized.

Using Study Results

The extensive data collected and analyzed during the life cycle and population dynamics studies contribute directly to the design and implementation of other projects, such as assessments of dam impacts on reproduction and hatchery construction.

For example, construction is underway of a sturgeon hatchery on the Kootenai Indian Reservation in Idaho. BPA has designed the hatchery as a low-end capital investment. The agency and the tribe will explore ways to make effective year-round use of the hatchery facility.

A preparatory project with the IDFG began in FY 1988 to assess sturgeon stocks in the Kootenai River downstream of Bonners Ferry, Idaho. The study defined the likely effectiveness of the hatchery operations.

Contact: Fred Holm, PJSR

Figure 6 Columbia River: Boundaries of Sampling Area

Figure 7 Estimated Mean Densities of Juvenile White Sturgeon

Reservoir Mortality & Water Budget

Studies in this category seek a balance between flow requirements for power and spill requirements of fish populations.

The balance is a difficult one to maintain. On the one side is the need to manage the available water resource for maximum potential for production of safe, reliable, cost-effective energy. On the other is the need to ensure survival rates of fish and other wildlife and to mitigate any possible adverse effects from the hydroelectric system.

Smolt Collection Efficiency, McNary Dam

The accuracy of estimates of fish survival directly affect evaluation of water budget effectiveness. A technical working group determined that collection efficiency is central in longer term planning for mainstem survival estimation research.

This project assessed potential sources of error in collection efficiency of chinook salmon and steelhead smolts at McNary Dam during the 1988 and 1989 smolt migration seasons. The estimates of daily juvenile fish passage and survival showed high variations. The study used passive integrated transponder (PIT) tags to evaluate the effects on fish of handling, point of origin, and release factors such as time of day.

The project makes possible more valid estimates of passage numbers and survival rates, as well as providing a valuable alternative to the typical mark and recapture method of estimating survival.

Contact: Patrick Poe, PJI

Fish Survival and Smolt Physiology Behavior Workshops

The project provides a better understanding and definition of:

- the potential role and application of smolt survival studies in long-range planning of mainstem passage research;
- fish physiology and conditions that affect downstream migrant behavior and survival; and
- future studies to determine the causes and extent of reservoir and system mortality.

Workshops included participation in sessions on fish survival experiments at Colorado State University, scoping sessions, and a survival workshop at the Friday Harbor Laboratory facility of the University of Washington. The session participants have reviewed existing information and identified the most feasible, practical methods of estimating smolt survival.

The workshops have also outlined research needs and recommended future research directions for the Reservoir Mortality and Water Budget Effectiveness Technical Working Group (RM WBE TWG). A draft proceedings is circulating for comments.

Contact: Dale Johnson, PJI

Survival Rates, Lower Granite Reservoir

Both NMFS and IDFG have cooperated in this study of the survival rates of juvenile and yearling chinook salmon passing through the Lower Granite Reservoir at Little Goose Dam. This work has helped to determine the usefulness of PIT tagging as a method in survival studies.

Contact: Dale Johnson, PJI

Flow Effects on Chinook Salmon, John Day Reservoir

Monitoring the stream flow and spill at John Day Reservoir—as related to the time needed for passage of summer and fall chinook—has led to a better understanding of the effects of passage time on survival rates.

Contact: Thomas Vogel, PJSF

Hatchery Effectiveness

A central issue in the balance of power needs with resource protection of anadromous fish is the use of artificial means to supplement naturally occurring populations. BPA's research addresses ways to rear fish safely and in the best condition possible for survival through all migratory cycles. Covered in this category are projects related to hatchery facilities, propagation, nutrition, and disease control.

Hatchery Design, Yakima and Klickitat Rivers

In 1987, the Northwest Power Planning Council asked BPA to develop a focused experimental program to test the success of supplementation of wild stocks of salmon and steelhead. One response had been the development of a staff team that can identify critical elements in experimental designs of facilities. Preliminary engineering and experimental designs were completed in 1990.

BPA is now funding the final design of salmon and steelhead facilities in the Yakima and Klickitat river basins in the State of Washington. Cooperating in the project are WDF, WDW, and the Yakima Indian Nation.

Contact: Thomas Chime, PJIW

Juvenile Salmonid Behavior, Columbia River Estuary

The project has established research strategies to better understand the migration and survival of hatchery smolts in their transition from fresh to salt water. Objectives will include ways of matching release times to physical and biological conditions of the river, estuary, and near-shore ocean environments.

Contact: Jerry Bauer, PJSR

Malachite Green Removal

Malachite green is a fungicide extensively used at hatchery facilities in the Columbia River basin. The Food and Drug Administration, however, has insisted that the fishery community develop and test filtering technologies to remove malachite green from discharge waters. Otherwise, use of the fungicide will no longer be permitted.

The project included work with the Carson National Fish Hatchery on the Wind River and the Abernathy Center in Longview, Washington, to identify and test two different removal systems. One was a carbon filtration unit capable of processing 50 to 150 gallons per minute of incubation water; the other system was also a carbon filtration unit but used to process race-way rearing waters (at a rate of 500 to 1000 gallons per minute).

The final report states that carbon filters can handle the necessary removal, thereby justifying continued use of the fungicide.

Contact: Jerry Bauer, PJSR

Rearing and Imprinting Fall Chinook, John Day

The U.S. Fish and Wildlife Service evaluated effectiveness of rearing and imprinting upriver bright fall chinook salmon in net pens located in the backwaters of the Columbia River. Techniques used could increase the total juvenile fish released for possible harvest, both in the river and in the ocean.

As an adjunct, the BPA study has surveyed ten potential sites in the Columbia River basin for placement of acclimation ponds. The sites were at John Day, Hat Rock, Willow Creek, Tidewater Barge, Ringold Springs, White Bluffs, Granger Channel, Prosser, Sunnyside Dam, Union Gap, and Walla Walla.

Contact: Alan Ruger, PJSR

Wild Adult Steelhead Protection, Upper Snake River

One outcome of extensive hydroelectric development in the Snake River system is the depletion of stocks of wild steelhead; the paradox is that

hatchery fish are present in abundance. Yet wild species of upriver anadromous fish have a high priority in the region's attention to resource protection. With cooperation from the IDFG and the Dworshak National Fish Hatchery, the project marked hatchery steelhead by removing the adipose fin. Sports fishermen can then differentiate between wild and hatchery fish stocks. The hatchery fish can then be selectively harvested, allowing wild fish to escape and spawn.

Contact: Ronald Morinaka, PJSR

Low-cost Salmon Production Facilities

In 1976, the Clatsop Economic Development Committee began a salmon enhancement project in Young's Bay in the Columbia River estuary. Before the project began, fewer than 100 adult fall chinook were caught there annually.

The project investigated and tested low-cost techniques for salmon production including earthen ponds and net-pen rearing. The study, now complete, has increased the harvested yield to over 5000 fish each year.

What has been learned here can be applied directly to other BPA funded salmon production facilities, such as those in the Yakima River Basin and Northeastern Oregon.

Contact: Thomas Clune, PJSR

Contribution of Columbia Hatchery Chinook to Pacific Salmon Fishery

In cooperation with NMFS, this project has assessed effectiveness of the hatcheries in mitigating the impacts of hydroelectric facilities in the Columbia River. The long-term project looked at the distribution, contribution, and value of chinook salmon raised at Columbia River hatcheries in the Columbia Basin to the overall Pacific Coast salmon harvest. Regulatory bodies have found the results useful in negotiating, setting, and adjusting the fishing seasons and related locations and catch limits.

Contact: Jerry Bauer, PJSR

Fish Disease

Projects involve the collection of health data on fish populations, including any problems of diseases. Emphasized are studies that promote anadromous fish survival through all migratory cycles.

Vitamin Nutrition: Effects on Immune Response System

Researchers at Oregon State University and the U.S. Fish and Wildlife Service determined the amounts of selected vitamins (pyridoxine, folic acid, pantothenic acid, riboflavin, ascorbic acid, and alpha-tocopherol) required to assure maximum growth in hatchery-reared salmonids. The study also measured the level of vitamin intakes that best promotes resistance and immunity to *aeromonas salmonicida* and to bacterial kidney disease (BKD).

Project results indicate that those dietary levels of tested vitamins recommended by the National Research Council were indeed ample for growth and immunological function. The research will produce smolts in better condition to survive migratory cycles. Studies also increase the knowledge base concerning fish immune systems, which in turn benefits disease control efforts throughout the Columbia River Basin.

Contact: Alan Ruger, PJSR

Vaccine Development for Bacterial Kidney Disease (BKD)

Researchers examined candidate antigens for efficacy in providing adequate immunity. Also subjected to analysis were methods of immune response evaluation and the application of substances that might moderate the immunological function.

The outcome is a recommendation that prophylactic attempts need to focus on elicitation of cellular immunity by use of preparations of *mycobacterium mageritense*. Future studies should look at other species of developing and using such substances.

Contact: Alan Ruger, PJSR

Supplementation

A focus of regional efforts to mitigate the effects of hydroelectric development has been to supplement naturally occurring populations of fish with hatchery-reared stocks.

Analysis of Supplementation Efforts

Supplementation, or planting, of salmon and steelhead stocks into the various river systems in the Pacific Northwest has occurred for many years. Attempts to increase fish runs have involved planting all life stages of anadromous species, from eggs to adults. Success varies widely, depending on such factors as:

- species,
- stock,
- genetics,
- geographical area,
- habitat type,
- water attributes,
- population statistics and distribution,
- selected planting times and seasons, and
- planting methods.

The project included extensive literature review and analysis of historical records at several fishery management agencies. An assessment of the available information, together with a summary of current stocking projects and studies, sheds light on successful (and unsuccessful) strategies in supplementation programs.

From this systematic summary comes a model of the concepts and factors that affect planting programs as well as an identification of key areas of research and information still needed.

Contact: Thomas Vogel, PJSP

Evaluation and Monitoring

The Pacific Northwest Electric Power Planning and Conservation Act (Law 96-501) authorizes funding mitigation measures to the extent that fish and wildlife are actually proven affected by the operation and facilities of the hydroelectric power system. That necessitates a thorough, accurate assessment of the base line information and later changes. In cooperation with other agencies and tribal groups, BPA conducts several projects to monitor fish populations throughout life stages and at multiple locations in the Columbia basin. Monitoring includes the multi-faceted Smolt Monitoring Program (SMP) and the Water Budget Program.

Freeze Brand and PIT Tag Data, McNary Dam

The project determines differences in the recovery rates of freeze-branded and PIT-tagged yearling chinook and steelhead.

Contact: Dale Johnson, PJI

Related and Support Projects

The R&D of other categories in Fish and Wildlife at BPA focuses on migratory populations of salmon and steelhead. This category encompasses projects on anadromous fish abundance and predators, but also covers other fish species: white sturgeon, cutthroat and rainbow trout, kokanee, smallmouth bass, whitefish, and northern pike.

Reservoir Level Requirements, Hungry Horse

The study determines the effects on game fish of drawing down the water levels in the Hungry Horse Reservoir on the North Flathead River. The evaluation covers changes in the distribution patterns, use and timing in various reservoir zones, and the changes in life stages of the fish. The intent is to incur seasonal drawdown levels that are compatible with the needs of the game fish. Cooperating in the study is the Montana Department of Fish, Wildlife, and Parks.

Contact: Dale Johnson, PJI

Reproductive Success of Kokanee, Hungry Horse and Kerr Dams

For eight years, the Montana Department of Fish, Wildlife, and Parks studied flows from the two dams in terms of optimal spawning, incubation, and rearing conditions for kokanee in the upper Flathead River and in Flathead Lake. Researchers monitored control of flows and water discharge with the timing and distribution of kokanee runs to determine effects on:

- reproduction and survival above the lake and
- spawning and incubation in the lake.

Information collected included diet patterns, egg incubation and survival, embryo development and survival, habitat use and patterns, migration characteristics and success rates, and spawning and reproduction statistics.

Contact: Fred Holm, PJSR

Additional Projects

Annotated in this section are additional research, development, and demonstration projects that are currently active in the area of Fish & Wildlife. Again, a contact is listed for each endeavor; i. at individual may be reached at 503 230-3000 or by writing in care of the Bonneville Power Administration, P. O. Box 3621, Portland, Oregon 97208.

Stock Assessment of Anadromous Salmonids

Statistics are consolidated for salmon and steelhead for Oregon, Washington, and Idaho.

Contact: Larry Everson, PJSR

Fish Marking Trailer

A mobile trailer is used to conduct marking programs with juvenile salmonids. Approximately 1.5 million fish were marked in 1989. This is a cooperative project with USFWS.

Contact: Bill Maslen, PJI

Spill Mitigation

Monitor juvenile salmonid migrations at four projects in accordance with the Long-Term Fish Spill Memorandum Agreement. Information is used to manage spill for fish passage by fishery agencies and tribes.

Contact: Bill Maslen, PJI

Smolt Monitoring and Water Budget Program

This program provides for the long-term tracking and assessment of smolt. Several program elements including: smolt condition studies, migration survival, water budget efficiency, and others are included.

Contact: Dale Johnson or Patrick Poe, PJI

Coded Wire Tag/Sampling

Recovery of tagged fish to evaluate fish survival, migration cycles and timing is the major emphasis of this project.

Contact: Bill Maslen, PJI

Freeze Brand Recovery Data

Monitor fish to determine whether PIT-tagged and freeze-branded chinook and steelhead recover at different rates.

Contact: Dale Johnson, PJI

Smoltification Research Methods

Provides for a technical working group to develop methods to determine smolt health and physiological conditions at hydro facilities as input to water budget decisions.

Contact: Dale Johnson, PJI

Pool Survival Working Group

Develop methods to determine mortality of smolts between dams and in reaches of the Columbia and Snake rivers.

Contact: Dale Johnson, PJI

Dworshak Photoperiod

Study decreased travel times related to increased light and warmth during weeks just prior to hatchery release. Completed study in 1989.

Contact: Bill Maslen, PJI

Clearwater River Study

Evaluate existing anadromous fish habitat in Clearwater River, Idaho, in cooperation with Nez Perce Tribe.

Contact: Jeffery Gislason, PJSR

Epidemiology and Control of Infectious Diseases

Contract with OSU Department of Microbiology to research *Ceratomyxa Shasta* including identification of host.

Contact: Alan Ruger, PJSR

Infectious Hematopoietic Necrosis (IHN) Virus Studies

Evaluation of immunization methods and vaccine development. Life cycle studies of IHN.

Contact: Ron Morinaka, PJSR

Dworshak Dam Impacts

Assesses effects of construction and operation on resident fishery—kokanee, rainbow trout, small mouth bass. Also effects on habitat and food stock (zooplankton).

Contact: Robert Austin, PJSR

Warm Springs Fish Habitat

Monitoring of juvenile salmonid densities and changes in habitat.

Contact: Rickey Stoots, PJIW

Erythromycin Registration Research

Collection of needed information to complete data package for Food and Drug Administration for commercial registration of a drug to control BKD in salmonids.

Contact: Ron Morinaka, PJSR

Weid Canal, Umatilla Basin

Evaluate loss of juvenile fish through or over Weid Canal screen bypass; also study large number of fall chinook spawning below Three Mile Dam.

Contact: Jerry Bauer, PJSR

For additional information about a specific project or to obtain DOE BP publications from the following list, please use the procedure described on page 3. If you encounter any difficulties, please address your queries to Greg Drais or Gerald Bouck at mail routing Pj, in care of the Bonneville Power Administration, P. O. Box 3621, Portland, Oregon 97208.

Apperson, Kimberly A. and Paul J. Anders. **Kootenai River white sturgeon investigations and experimental culture.** Fisheries Research Section, IDFG, Contract No. DE-AI79-88BP93497. DOE BP 93497-1. June 1990.

Bonneville Power Administration (pub.) **Assessment of present anadromous fish production facilities in the Columbia River Basin.** Five volumes. Project no. 89-045. n.d.

Bouck, G. R. (ed.) **Papers on use of supplemental oxygen to increase hatchery rearing capacity in the Pacific Northwest.** Pacific Northwest Fish Culture Conference. American Fisheries Society. December 2-4, 1986. Springfield, Oregon. March 1987.

Bradford, C. S. and Carl B. Schreck. **Migratory characteristics of spring chinook salmon in the Willamette River.** Contract DE-AI79-88BP92818. Annual Report. September 1990.

Brannon, E. et al. **Columbia River white sturgeon (Acipenser transmontanus): early life history and genetics study.** Final Report. Contract No. DE-AI-84BP189522. School of Fisheries, University of Washington. December 1985.

Ewing, R. D. and J. E. Sheahan. **Annual progress report: Willamette oxygen supplementation studies.** Contract DE-AI79-88BP92818. Oregon Department of Fish and Wildlife. Draft. August 1990.

Fickeisen, Duane H. **White sturgeon bibliography.** Final report 1985. Contract DE-AI-84BP22209. DOE BP 22209-2. March 1986.

Fish Factory. **Evaluation of pure oxygen systems at the Willamette Hatchery.** Contract DE-AP79-89BP00852. DOE BP 00852-1. May 1990.

Floyd, Mark. **Wired: migrating salmon do get lost . . .** Oregon's Agricultural Progress. Oregon State University. Fall 1990. Winter 1991.

Holm, Fred. **Predation by resident fish on juvenile salmonids in John Day Reservoir, 1983-1986.** DOE/BP-34796-5. 1988.

Idaho Department of Fish and Game. **Smolt monitoring at the head of Lower Granite Reservoir and Lower Granite Dam.** Annual Report. Project 83-323. DOE/BP-11631-6. 1989.

Oregon Department of Fish and Wildlife. **Development of rations for the enhanced survival of salmon.** Annual Report. Project 83-363. DOE/BP-38372-2. 1989.

———. **Status and habitat requirements of white sturgeon populations in the Columbia River downstream from McNary Dam.** Annual progress report. April 1989 - March 1990. Contract No. DE-AI79-86BP63584. Project 86-50. DOE/BP-63584-4. November 1990. [See also reports for previous project years in this series: DOE BP-63584-1, DOE BP-63584-2, DOE BP-63584-3.]

Umatilla Confederated Tribes. **Mint-born Spring Creek summer juvenile release and adult collection facility.** Annual Report. Project 83-435. 1989.

University of Washington. **Smolt survival workshop, February 1-3, 1989.** Projects 87-413, 86-118. DOE BP-35885-2. January 1990.

U.S. Fish and Wildlife Service (Seattle, Washington). **Assessment of smolt condition for travel time analysis.** Annual Report. Project 87-401. DOE BP-35245-2. January 1989. [See also DOE BP-35245-3, January 1991.]

———. **Magnitude and dynamics of predation [on] juvenile salmonids in Columbia and Snake River reservoirs.** Annual Report. Project 82-003. 1989.

———. **Pen rearing and imprinting of fall chinook salmon.** Annual Report. Project no. 83-313. DOE/BP-13084-4. 1989. [See also DOE/BP-13084-5. August 1990.]

———. **Proceedings of the predator-prey modeling workshop, May 16-19, 1989.** Project 82-003. DOE/BP-01830-5. May 1990.

Westers, Harry. **The role and application of oxygen in intensive fish culture.** Michigan Department of Natural Resources. 1989.

BPA focuses on technologies to stabilize and increase the energy resource potential of the Pacific Northwest, both through generation and through conservation.

Generation research includes analysis and development of power production capacity in such fields as wind, solar, biomass, hydroelectric, and geothermal. Conservation research investigates strategies and technologies that reduce or make more efficient the energy consumption by all users—commercial, industrial, utility, and residential.

Cooperative activities are an increasingly important aspect of these BPA research efforts. Collaborative funding will occur in about 57 percent of projects now planned, compared with 48 percent of currently active projects and only 17 percent of the completed projects. This trend reflects the fact that BPA is no longer alone in its efforts to establish conservation and renewable resources as viable alternatives to conventional generation.

As a tool to encourage cooperative research, BPA published the **Conservation and Load-Management Research Plans, 1989 North American Index**. (See listing on page 41.) The volume lists research plans for 100 state, utility, public service, and national government organizations and is the only such index that looks forward, enabling cooperative planning for research projects. A second edition

of the index of demand-side management (DSM) projects (**The Official Guide to DSM Programs and Research**) is scheduled for publication as a commercial venture in 1991 by the Utility Data Institute in Washington, D.C. The index will become a standard in research management as more and more organizations learn of its availability and participate in its development.

The following pages describe four R&D projects in some detail and others more briefly. At the end of each description is the name and mail routing code for a specific contact person. To obtain more information, please address inquiries to that individual, including the routing code, at the Bonneville Power Administration, P. O. Box 3621, Portland, OR 97208, or call the listed contact through BPA's main switchboard at 503/230-3000.

In the **Information Resources** section is a list of recent reports and publications resulting from BPA's R&D activities in energy resources. Procedures to use in reaching individuals or ordering publications are detailed on page 41 and in the **Obtaining More Information** section on page 3.

Jon Biemer, Coordinator

Energy Resources Research and Development

Adjustable Speed Drives Change the World of Electric Motors

Advantages of electric motors are numerous: They are convenient, readily available, safe, free from smoke and odor, and comparatively quiet. They are available in sizes from a small fraction of a horsepower to many thousands of horsepower, making them useful in many applications. They meet a wide range of service requirements—starting, accelerating, running, braking, holding, conveying, or stopping a load.

In most industries (apart from smelting operations), electric motors are the highest users of electricity—higher than space heating or cooling, higher than ventilation, higher than lighting. In manufacturing processes, electric motors consume about 24 percent of the firm demand in the Pacific Northwest.

For industrial customers interested in conservation measures, BPA understands that it is therefore important to more closely match the motor's capacity with the actual requirements of a specific use. Unfortunately, the available electrical power supply is at a fixed frequency (60 hertz). Typically, a user must depend on speed reduction devices to control the revolutions per minute (rpm) needed in a process.

Various devices have been used to achieve this control: belts, pulleys, gear reducers, magnetic clutches, hydraulic clutches, fluid couplings, valves, eddy current clutches, and other mechanisms.

For example, in liquid flow situations, the pump is usually driven by a constant speed motor. Flow requirements are met by opening or closing valves. Only when the pump is providing full flow is it operating at peak efficiency. Operation at less than full flow still requires about the same power input to the motor and valuable energy is lost.

What is more, these speed control devices often involve high maintenance costs, with increased time set aside for adjustments. Such mechanisms are also limited in application flexibility.

The development of low cost, reliable, sophisticated electronics has made an alternative—adjustable speed drives (ASDs)—successful. Two schemes are possible.

1. The single frequency 60 hertz alternating current is converted (rectified) to direct current, which is in turn inverted to an adjustable frequency alternating current.

2. Three-phase 60 hertz waves are chopped into pulses that have adjustable widths. The pulses are filtered and recombined to emulate an adjustable frequency alternating current, which is supplied to induction and synchronous motors.

ASDs are usually used in closed loop control systems, as shown in the generic block diagram (figure 8). In addition to energy savings and process control, the systems enjoy many advantages: efficient and continuous speed adjustment, torque control, limited adjustment and maintenance time, high acceleration and deceleration, and fast response.

Disadvantages can include high initial cost, voltage and current harmonics that require special filtering, complexity, and floor space to install the electronic components.

"Adjustable speed drives can make industrial processes more efficient, more productive," notes Gayland Smith, an engineer working with BPA's industrial sector R&D

Figure 8: Basic Block Diagram of an ASD System

programs. "Through improved control, there is tremendous benefit to industry, and in turn to the utility serving that industry, in the scope of energy savings." Energy savings differ substantially for each application, depending on the operating time needed at each motor speed during the cycles of a specific process. The more time that a machine operates at less than full load during its duty cycle, the more energy savings are possible by using an ASD. Actual savings also depend on the prevailing cost of a kilowatt hour.

Other savings occur. A strong factor in considering ASDs, for example, is their proven ability to reduce maintenance costs by superior control of torques during acceleration and deceleration. Precise savings estimates are quantified by examining the maintenance history of conventional installations and the comparable records for a similar ASD application. Again, the actual dollars saved will vary substantially from application to application.

The study has reviewed available literature and research on alternating current motors with ASDs and surveyed applications among industries throughout the BPA service area. That information has been indexed by Standard Industrial Classification (SIC) and by process, system, and type of equipment.

A survey of industrial plants, manufacturers, research institutions, engineering organizations, and others in the BPA service area found that most plants are systematically adopting adjustable speed drives as they replace motors or add processes. Energy savings and the possibility of process and control improvements were the main motivators for adding the drives.

The only problems encountered among those surveyed involved:

- inadequate information about selecting a drive suited to a particular process and
- a lack of trained maintenance personnel.

Drive suppliers offer a range of stock units. In selecting a suitable drive, it is therefore less important to understand the drive itself than to understand the load and process requirements for which that drive will be used.

Application Guidebook. From the initial research, a contractor has developed an application guide with concrete, usable information about selecting and applying ASD

technology to industrial loads. Potential users gain an easily understood description of load types and a matching definition of the commercially available ASDs suited for connection to those loads.

The guidebook shows ways of increasing benefits from ASDs through cooperative efforts between industries and utilities in engineering, installing, and maintaining the equipment. The guide assists industry decision-makers—both electrical and non-electrical staff—who are working together to improve plant performance and who are, therefore, considering adjustable speed technology. The guidebook (see listing in **Information Resources** on page 41) includes procedures and checklists that will assist potential users in examining the technical and economic feasibility of replacing conventional systems with ASDs.

The guidebook covers the following variables in assessing adjustable speed technology for a particular application:

- drive system types,
- electrical power needs,
- process control,
- product quality,
- equipment costs,
- automation costs, and
- maintenance costs.

The guidebook also supplies information on typical applications: ventilation fan, water pump, fork lift, lathe, screw feeder, grinder, conveyor turntable, and others. Figure 9 shows a matrix of applications by machine type and process requirements.

Case Studies. In a closely related project, BPA and EPRI are co-funding demonstration projects to "scope out the universe of real life applications," says Smith.

"We are looking at applications other than fans and pumps," continues Smith. "Most of the previous work in this area has been with fans and pumps. The applications we're more interested in testing and documenting include machine tools, conveyor belts, screw compressors, cranes and hoists, mixing processes, and other applications. We hope this fills a vacuum in the literature and research to date."

From the project will come a book of case studies describing actual installations of adjustable speed drives in Pacific Northwest industrial plants. These case studies,

together with the guidebook, will aid industrial plant managers and engineers as they evaluate upgrades or

replacement of conventional systems with electronic adjustable speed drive technology.

Contact: Gayland Smith, RMID

PROCESS REQUIREMENTS	MACHINE TYPES																								
	BLENDEES & MILLS	CRUSHERS & MILLS	GRINDERS	SANDERS	SPIN BARBERS	WHEELS	MILLING MACHINES	PLANERS	SPINDERS/SPLITTERS	STOCK CLEANERS	STOCK WASHERS	MIXERS	FILTER PRESS	COMPRESSORS	TRAYS	SORTERS	DRYERS	GLUE SPREADERS	FEEDERS	PUMPS	FORKLIFT	GRINDER	EXTRUDER		
GAS AND LIQUID FLOWS																									
MATERIAL HANDLING																									
CHEMICAL PROCESSES																									
MACHINING/FABRICATION																									
EXTRUSION/MOLDING																									
PRECISION/FINISH																									
MASS FLOW RATES																									
PRODUCTION CONTROL																									
WINDING/UNWINDING																									
HORSEPOWER < 50																									
50 - 250																									
> 250																									
MOTOR TYPES: INDUCTION																									
SYNCHRONOUS																									
SPEED RANGES: < 1000 RPM																									
1000 - 2000 RPM																									
> 2000 RPM																									
VOLTAGE LEVEL < 600 V																									
1000 - 5000 V																									
> 5000 V																									
TORQUE REQUIREMENTS: HIGH																									
LOW																									
DUTY CYCLE: HIGH																									
LOW																									
REVERSING																									
REGENERATIVE																									
CONTROL STRATEGY: FLOW																									
SPEED																									
PRESSURE																									
MULTIPLE DRIVE																									

Figure 9 ASD Applications Matrix

Amorphous Transformers Keep on Saving—Day In, Day Out!

Credited with dramatic savings in no-load losses, amorphous core transformers are driving other distribution transformers from the BPA service region. Not only is BPA committed to purchasing transformers made with amorphous steel cores to replace station service transformers with silicon steel cores, but the agency's 131 utility customers are following suit, attracted by installation incentives and conservation potential.

All transformers dissipate some energy, even when there is no load to serve. Use of amorphous metals in the transformer core was estimated by the manufacturers to reduce those no-load losses by 60 to 70 percent. That means, if the 20 to 40 million distribution transformers in service today in the United States were replaced by amorphous core units, energy savings would be 6 to 14 billion kilowatt hours per year.

The value placed on no-load losses ranges from less than \$1 per watt to more than \$10 per watt over the expected 30-year lifetime of a transformer. EPRI calculates energy savings using amorphous steel transformers at \$300 to \$700 million. The cumulative reduction in needed generation capacity over 20 years, throughout the country, could mount to over 5000 megawatts (MW). That's the equivalent of four to five large nuclear plants.

But it is never enough to offer formulas and promises of energy savings. Many technologies justify operating savings but are costly at the front end: manufacturers can't afford development of the commercial product and buyers can't chance the initial investment. Cooperation between EPRI and General Electric illustrated the energy savings and placed the product advantageously in the marketplace.

With 90 other utilities, BPA participated in a field evaluation program conducted by EPRI. The program involved installation of 1000 prototype transformers, demonstrating their reliability and the agreement of manufacturer performance estimates with actual field measurements. Twelve single-phase 25 kilovoltampere (kVA) amorphous steel transformers have operated since 1986 at BPA substations.

BPA investigator and engineer Barry Kennedy promotes the advantages of these transformers: the savings "occur all day, every day, all year long. In addition, these units are commercially available at a relatively low cost." Other features are:

- a low operating temperature and
- a unit size and weight comparable to conventional units having silicon steel cores.

BPA conducted a corollary study to identify technologies and estimate savings that would most benefit customer utilities. Of the 15 sophisticated technologies identified and evaluated, the most significant potential for reduction in losses could be achieved by replacing standard transformers with amorphous core units.

	Conventional Core	Amorphous Core
	48 watts × (\$ 5 watt)	18 watts × (\$ 5 watt)
No-Load Losses	\$ 240	\$ 90
	284 watts × (\$ 1 watt)	249 watts × (\$ 1 watt)
Load Losses	\$ 284	\$ 249
Total Cost of Losses	\$ 524	\$ 339
Purchase Price	\$ 510	\$ 695
Total Owning Cost	\$1,034	\$1,034

Source: Electric Power Research Institute

Table 3- Calculating Costs of Amorphous Steel Transformers

If all of BPA's customers made that substitution for existing transformers (currently numbering 1.3 million units ranging in size from 5 to 100 kVA), about 115 average megawatts could be saved annually. When utilities propose approved conservation measures, such as the replacement of conventional transformers with amorphous steel units, BPA offers credits against power purchases by customer utilities. The recent count of proposals from customers shows their intention to purchase over 40,000 such transformers over the next six years.

Contact: Barry Kennedy, RMID

Figure 16- Customer-Installed Amorphous Steel Transformers, City of McMinnville Substation. Rich Custer, McMinnville Water and Light, examines newly installed amorphous steel service transformer

Making the Metal

The unique properties of amorphous metals come about in the way they are cooled. When molten metals cool gradually, the atoms arrange themselves in an orderly pattern, forming tiny crystals. If cooled suddenly enough, however, the atoms do not have time to form crystals, but instead freeze in a random arrangement. This amorphous internal structure is similar to that of glass, so alloys produced this way are sometimes called metallic glasses.

Because the amorphous metals are not crystalline, the magnetic properties are also dissimilar to other metal alloys. That random arrangement reduces the usual magnetic flip flops, or magnetic friction, that eats up kilowatt hours in the conventional silicon steel cores.

For the currently available amorphous steel transformers, the manufacturer is using quickly cooled ribbons of metal alloy comprising iron, boron, and silicon. The patents for the trademarked METGLAS are held by Allied Signal.

Amorphous metal has sold in recent years at about twice the price of silicon steel. A decade ago, when first available, its cost was 100 times that of conventional transformer core material. Amorphous metal production takes fewer manufacturing steps and thus less energy to produce; further reductions in costs therefore depend on volume production.

Geothermal: The Resource Whose Time Has Come

BPA has long been committed to the development of additional cost-effective, reliable power sources to serve the Pacific Northwest. The agency has participated as a leader in examining and testing alternative resources, including solar, wind, biomass, and geothermal. A current investigation targets the geothermal potential in this region, but draws upon the experiences of others.

Locales as diverse as Italy and New Zealand have recognized geothermal availability and developed it fairly early to share a full-fledged slot in the marketplace. During the oil shortages of the 1960s and 1970s, alternatives among the renewable energy resources emerged into the limelight in North America as well.

- At Lardarello, Italy, a geothermal operation began generating power in 1904 and is still in service with over 400 MW on line.
- Producing power since 1963 is a plant at Wairakei, New Zealand. Its installed, or nameplate, capacity stands at 192 MW.
- A 5 MW experimental plant design was built and operated briefly at Raft River, Idaho. Its shakedown run was in fall 1981; unfortunately its funding was cut in June 1982.
- The Geysers projects in Sonoma and Lake counties (California) were begun in 1960. Total capacity is over 2000 MW, an output comparable to the output of two typical nuclear plants.

All in all, the timing for geothermal development in the Pacific Northwest finally seems right. The region has experienced a strong load growth and simultaneously tapped into lucrative markets for any surplus power. An abundance of geothermal resource is believed located in the Pacific Northwest. Power costs should be competitive with new coal plants.

Given these factors, area agencies are cooperating in the preliminary steps leading to development of a geothermal resource. BPA, in response to a need expressed for resource development by the Northwest Power Planning Council, has offered to participate in three geothermal pilot projects.

The contracts offered by BPA will commit to the purchase only of output, an estimated 10 average MW from each of the three projects. BPA will not finance exploration; each project will have a utility as a partner with the developer and BPA. Thus, overall project size could exceed 10 MW. Contracts will include an option to purchase additional output from a resource area.

Each project will tap into a different resource area and, preferably, involve a different developer. Scheduled for issue in mid-1991 is the first Notice of Program Interest (NOPD) to attract developer proposals.

Projects, insofar as practicable, will meet the following criteria:

Location in a resource area assessed as eventually capable of supporting 100 MW or more of generation. The expense of development is only justified by projects with a large resource potential.

Location on federal land. The site leases and environmental impact assessments will therefore fall under the jurisdiction of the Bureau of Land Management (BLM)

- ① Renewable Resource Thought to be Abundant in This Region
- ② Firm Power
- ③ Mature Technology
- ④ Incremental Development
- ⑤ Confirmed Sites Can be Developed Rapidly
- ⑥ Few Environmental Impacts Compared to Other Large-Scale Power Sources
- ⑦ Stable Fuel Cost
- ⑧ Not Vulnerable to Fuel Supply Interruptions
- ⑨ Schedulable

Table 4: The Case for Geothermal

as a lead agency, with BPA in the role of a cooperating agency.

Suited to coordinated operation. Defining each resource area (rather than each single project) as a unit will ensure the best use of the geothermal potential. BLM's management of the site leases helps to ensure the application of this unit concept.

Another major consideration in selecting projects is their impact on the existing transmission system. Preferred are

those projects near, or easily linked to, the established transmission grid or load centers such as Seattle or Portland.

As part of the process, baseline studies are undertaken. Such studies outline likely impacts—environmental, economic, and operational—in areas showing promise for further geothermal research. The studies establish an area's character before its development as well as identifying possible problems so that solutions can be planned as needed. Hydrologic baseline studies, arranged with the U.S. Geological Survey, are about to begin.

BPA is in the process of contracting for additional study components—fauna, flora, seismicity, archaeological or cultural sites, and other surveys—in cooperation with the U.S. Forest Service (USFS) at Newberry Volcano. Additional financing is underway, again in cooperation with USFS, to help make informed, intelligent decisions in a promising resource area south of Sisters, Oregon.

BPA is also co-funding a public information and involvement program by the Deschutes National Forest that includes workshops, presentations, and traveling exhibits.

BPA recognizes that geothermal must prove itself as environmentally acceptable, that land use issues have emerged as concerns, and that pilot projects are above reproach to avoid tainting future exploration of geothermal projects in this region.

BPA is requesting that interested developers provide letters of intent by September 1991, with an overview of the intended pilot project.

Contact: George Darr, RMGB

Source: Trans-Pacific Geothermal Corporation.

Figure 11: Schematic of a Typical Geothermal System

Understanding Ventilation in Energy-Efficient Residences

Various projects are assessing the effectiveness and efficiency of ventilation systems in residential construction. Research is driven by concerns over indoor air quality in buildings designed as energy efficient and by a need to align building standards with actual construction practices for both single- and multi-family residences.

Several related projects previously undertaken by BPA and others had concentrated on finding effective strategies, designs, and equipment to tighten homes to a high level of energy efficiency. This led to the development of Model Conservation Standards (MCS). Other projects had identified concerns with indoor air quality, characterized potential pollutants, and verified the impacts on occupant health.

However, researchers found a need for a more complete understanding of the relationship between infiltration and mechanical ventilation in single and multi-family structures. Closely related concerns involved the suitability of ventilation standards, the accuracy and reliability of testing methods, and uncertainties about the capabilities and knowledge of both equipment installers and occupant operators of that equipment.

In November 1989, a workshop on ventilation research was held in Golden, Colorado. Co-sponsors included BPA, EPRI, Colorado State University's Solar Energy Applications Laboratory, the Solar Energy Research Institute, the Environmental Protection Agency, and the American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE).

Participants recommended 44 specific components for inclusion in a multi-year research plan, including computer modeling, laboratory experiments, equipment and hardware design, field tests and measurements, and demonstration projects. The need was to look more closely at the realities of infiltration as it related to the design and installation of ventilation systems in residential construction.

Infiltration, or **passive ventilation**, exchanges indoor and outdoor air. Air leaks through cracks and around windows or flows in and out of opened windows and doors. Varying levels of infiltration occur with differences in occupant habits, wind speed, temperatures, or time of year.

Active ventilation systems, on the other hand, allow control of air exchange rates through use of mechanical systems such as motor driven fans or blowers. Two common systems of active ventilation are **air-to-heat exchangers** and **exhaust-only systems**.

BPA researchers agreed that participating in activities such as those proposed at the Colorado conference would round out the agency's several research directions on home construction practices and ventilation needs. A consortium of organizations developed, EPRI, Honeywell, and Pacific Gas and Electric. These organizations were willing to join BPA in projects to develop test methods, evaluate actual infiltration rates, and assess the efficacy of installed active ventilation systems in single- and multi-family dwellings.

Source: Final Environmental Impact Statement on New Energy-efficient Homes Programs, DOE/EIS-0127F, August 1988.

Figure 12 Whole House Ventilation Integrated with Central Forced Air System

Substantial field work has been completed

One project examined manufactured homes. Such construction represents about 30 percent of the single-family housing starts that are heated by electricity in BPA's service area. Eighteen builders construct all these homes, creating a unique opportunity to understand and influence energy conservation and ventilation practices.

Tests have shown significant differences in tightness and exhaust-fan flow rates between different manufacturers. These and related findings emphasize the need for further research into the causes of various infiltration rates and the need to develop reliable methods of construction. Without clearly

understanding the problems and having realistic training programs in place, the MCS and other ventilation standards remain specifications with unpredictable consequences.

For example, ASHRAE Standard 62-1989 sets minimum whole-house ventilation at a 0.35 air-change rate (ACH), yet in measuring 160 manufactured homes in the Pacific Northwest, 72 percent of the homes fell below that standard. Further analysis is needed to determine if the test methods are accurate, if the standards are too stringent (perhaps related to climate zones), or if these failure rates are, indeed, precise indicators of a potentially serious problem with construction practices, equipment design or installation, or other factors.

Another R&D project sponsored by BPA involves case studies on multi-family building projects. A ventilation audit of several similar multi-unit buildings in different Northwest cities used blower door and flow hood testing to evaluate the systems and make leakage assessments. In addition, the teams made repairs and adjustments as needed in equipment installations and conducted occupant surveys.

The teams found that properly installed and sealed systems of fans, flow restrictors, and duct work functioned well and met ventilation standards. However, the audit teams deemed installation of some equipment as very poorly done, indicating a serious need for BPA and state energy offices to step up training efforts. The design and conduct of such training for installers and inspectors must translate into actual improvements in field construction practices.

Still another study, contracted to Battelle's Pacific Northwest Laboratory, sought to measure air exchange rates in multi-family units built to MCS. Using the perfluorocarbon tracer (PFT) technique, researchers conducted 88 air exchange measurements in four MCS-constructed apartment buildings in Washington.

The PFT method allows determination of the fresh air flow from the outside into any specific building unit as well as the air flow between adjacent units. (See example in figure 13.)

Also measured were volumetric air flow, usage of the installed mechanical ventilation systems, temperature, wind speed and other weather factors, structure characteristics, and occupancy data. An occupant survey was taken (figure 14).

Key findings of this study were:

- The air exchange rate was highly variable between units, revealing the significant impact of occupant behavior on ventilation.
- The air exchange rate was less variable within each building than in the sample as a whole.

A significant fraction of each unit's air flow comes from adjacent units. The greatest air flow was from lower units to upper units. Ventilation systems were out of balance, not maintained and not well understood by occupant operators.

BPA's project manager, Mark Jackson, notes that the most useful information comes from a look at residential ventilation systems after they are "in place for awhile. Has the system been reprogrammed? turned off? How often is it used? What are the impacts of mechanical devices on other leaks in the building's shell? What is the occupant's perception of comfort?"

He stresses that the presence of many pollutants is not perceptible to householders and that, by altering a system's performance, occupants may be canceling the advantages of the system as originally intended.

This would indicate a need for improved occupant education and better control strategies. In fact, with the advent of expert system computer technologies, control systems could conceivably alert residents to specifics about pollutants, levels, and provide solutions—all within a device no larger than a typical furnace thermostat.

Contact: Mark Jackson, RMRI

Figure 13 Air Exchange Rates (per hour) and Unit-to-unit Air Flows for a 12-Unit Tacoma Building

- Renewable Resource Thought to be Abundant in This Region
- Firm Power
- Mature Technology
- Incremental Development
- Confirmed Sites Can be Developed Rapidly
- Few Environmental Impacts Compared to Other Large-Scale Power Sources
- Stable Fuel Cost
- Not Vulnerable to Fuel Supply Interruptions
- Schedulable

Table 4: The Case for Geothermal

as a lead agency, with BPA in the role of a cooperating agency.

Suited to coordinated operation. Defining each resource area (rather than each single project) as a unit will ensure the best use of the geothermal potential. BLM's management of the site leases helps to ensure the application of this unit concept.

Another major consideration in selecting projects is their impact on the existing transmission system. Preferred are

those projects near, or easily linked to, the established transmission grid or load centers such as Seattle or Portland.

As part of the process, baseline studies are undertaken. Such studies outline likely impacts—environmental, economic, and operational—in areas showing promise for further geothermal research. The studies establish an area's character before its development as well as identifying possible problems so that solutions can be planned as needed. Hydrologic baseline studies, arranged with the U.S. Geological Survey, are about to begin.

BPA is in the process of contracting for additional study components—fauna, flora, seismicity, archaeological or cultural sites, and other surveys—in cooperation with the U.S. Forest Service (USFS) at Newberry Volcano. Additional financing is underway, again in cooperation with USFS, to help make informed, intelligent decisions in a promising resource area south of Sisters, Oregon.

BPA is also co-funding a public information and involvement program by the Deschutes National Forest that includes workshops, presentations, and traveling exhibits.

BPA recognizes that geothermal must prove itself as environmentally acceptable, that land use issues have emerged as concerns, and that pilot projects are above reproach to avoid tainting future exploration of geothermal projects in this region.

BPA is requesting that interested developers provide letters of intent by September 1991, with an overview of the intended pilot project.

Contact: George Darr, RMGB

Source: Trans-Pacific Geothermal Corporation.

Figure 11 Schematic of a Typical Geothermal System

Understanding Ventilation in Energy-Efficient Residences

Various projects are assessing the effectiveness and efficiency of ventilation systems in residential construction. Research is driven by concerns over indoor air quality in buildings designed as energy efficient and by a need to align building standards with actual construction practices for both single- and multi-family residences.

Several related projects previously undertaken by BPA and others had concentrated on finding effective strategies, designs, and equipment to tighten homes to a high level of energy efficiency. This led to the development of Model Conservation Standards (MCS). Other projects had identified concerns with indoor air quality, characterized potential pollutants, and verified the impacts on occupant health.

However, researchers found a need for a more complete understanding of the relationship between infiltration and mechanical ventilation in single and multi-family structures. Closely related concerns involved the suitability of ventilation standards, the accuracy and reliability of testing methods, and uncertainties about the capabilities and knowledge of both equipment installers and occupant operators of that equipment.

In November 1989, a workshop on ventilation research was held in Golden, Colorado. Co-sponsors included BPA, EPRI, Colorado State University's Solar Energy Applications Laboratory, the Solar Energy Research Institute, the Environmental Protection Agency, and the American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE).

Participants recommended 44 specific components for inclusion in a multi-year research plan, including computer modeling, laboratory experiments, equipment and hardware design, field tests and measurements, and demonstration projects. The need was to look more closely at the realities of infiltration as it related to the design and installation of ventilation systems in residential construction.

Infiltration, or **passive ventilation**, exchanges indoor and outdoor air. Air leaks through cracks and around windows or flows in and out of opened windows and doors. Varying levels of infiltration occur with differences in occupant habits, wind speed, temperatures, or time of year.

Active ventilation systems, on the other hand, allow control of air exchange rates through use of mechanical systems such as motor-driven fans or blowers. Two common systems of active ventilation are **air-to-heat exchangers** and **exhaust-only systems**.

BPA researchers agreed that participating in activities such as those proposed at the Colorado conference would round out the agency's several research directions on home construction practices and ventilation needs. A consortium of organizations developed: EPRI, Honeywell, and Pacific Gas and Electric. These organizations were willing to join BPA in projects to develop test methods, evaluate actual infiltration rates, and assess the efficacy of installed active ventilation systems in single- and multi-family dwellings.

SOURCE: Final Environmental Impact Statement on New Energy-efficient Homes Programs, DOE/EIS-0127F, August 1988.

Figure 12. Whole House Ventilation Integrated with Central Forced Air System

Substantial field work has been completed

One project examined manufactured homes. Such construction represents about 30 percent of the single-family housing starts that are heated by electricity in BPA's service area. Eighteen builders construct all these homes, creating a unique opportunity to understand and influence energy conservation and ventilation practices.

Tests have shown significant differences in tightness and exhaust-fan flow rates between different manufacturers. These and related findings emphasize the need for further research into the causes of various infiltration rates and the need to develop reliable methods of construction. Without clearly

understanding the problems and having realistic training programs in place, the MCS and other ventilation standards remain specifications with unpredictable consequences.

For example, ASHRAE Standard 62-1989 sets minimum whole house ventilation at a 0.35 air-change rate (ACH), yet in measuring 160 manufactured homes in the Pacific Northwest, 72 percent of the homes fell below that standard. Further analysis is needed to determine if the test methods are accurate, if the standards are too stringent (perhaps related to climate zones), or if these failure rates are, indeed, precise indicators of a potentially serious problem with construction practices, equipment design or installation, or other factors.

Another R&D project sponsored by BPA involves case studies on multi-family building projects. A ventilation audit of several similar multi-unit buildings in different Northwest cities used blower door and flow hood testing to evaluate the systems and make leakage assessments. In addition, the teams made repairs and adjustments as needed in equipment installations and conducted occupant surveys.

The teams found that properly installed and sealed systems of fans, flow restrictors, and duct work functioned well and met ventilation standards. However, the audit teams deemed installation of some equipment as very poorly done, indicating a serious need for BPA and state energy offices to step up training efforts. The design and conduct of such training for installers and inspectors must translate into actual improvements in field construction practices.

Still another study, contracted to Battelle's Pacific Northwest Laboratory, sought to measure air exchange rates in multi-family units built to MCS. Using the perfluorocarbon tracer (PFT) technique, researchers conducted 88 air exchange measurements in four MCS-constructed apartment buildings in Washington.

The PFT method allows determination of the fresh air flow from the outside into any specific building unit as well as the air flow between adjacent units. (See example in figure 13.)

Also measured were volumetric air flow, usage of the installed mechanical ventilation systems, temperature, wind speed and other weather factors, structure characteristics, and occupancy data. An occupant survey was taken (figure 14).

Key findings of this study were:

- The air exchange rate was highly variable between units, revealing the significant impact of occupant behavior on ventilation.
- The air exchange rate was less variable within each building than in the sample as a whole.

A significant fraction of each unit's air flow comes from adjacent units. The greatest air flow was from lower units to upper units. Ventilation systems were out of balance, not maintained and not well understood by occupant operators.

BPA's project manager, Mark Jackson, notes that the most useful information comes from a look at residential ventilation systems after they are "in place for awhile. Has the system been reprogrammed? turned off? How often is it used? What are the impacts of mechanical devices on other leaks in the building's shell? What is the occupant's perception of comfort?"

He stresses that the presence of many pollutants is not perceptible to householders and that, by altering a system's performance, occupants may be canceling the advantages of the system as originally intended.

This would indicate a need for improved occupant education and better control strategies. In fact, with the advent of expert system computer technologies, control systems could conceivably alert residents to specifics about pollutants, levels, and provide solutions—all within a device no larger than a typical furnace thermostat.

Contact: Mark Jackson, RMRD

Figure 13 Air Exchange Rates (per hour) and Unit-to-unit Air Flows for a 12-Unit Tacoma Building

OCCUPANT ACTIVITIES RECORD

Please record the following events on a daily basis each week of PFI testing.

Week of _____	Mon	Tue	Wed	Thur	Fri	Sat	Sun
1 Hours of Woodstove Use							
2 Hours of Fireplace Use							
3 Hours of Opened Windows							
4 Minutes of all Exhaust Fan Use							
5 Minutes of Clothes Dryer Use (inside home only)							
6 Unusual Events (Place number under appropriate day and indicate below the event and its impact)							
(Example: 1 Party with several guests)							

Figure 14 Sample Occupant Survey Form

Energy-Efficiency and Indoor Air Quality

Homes defined as energy efficient incorporate thermal windows and doors, higher levels of insulation, and a host of other features that prevent the escape of warm air and the entry of cold air. Energy savings benefit the home's owners, the region's ratepayers, and—ultimately—help to avoid expensive capital investment in new generation sources.

Every home built without energy-saving features is a lost opportunity for the Northwest's utilities and rate-payers.

That same energy-efficiency, however, is detrimental if unhealthy pollutants accrue in the dwelling. Here in the Northwest, BPA has been a leader in structuring the MCS. These standards, written by the Northwest Power Planning Council, have become adopted as the Northwest Energy Code into the region's community building codes.

Programs such as the Super Good Cents Program and the Residential Construction Demonstration Project have encouraged extensive improvements in building practices and techniques. Builders have worked with BPA and state energy offices throughout the Northwest to document benefits associated with MCS construction.

Yet the increased comfort, lasting value, and lower energy costs may be a mixed blessing if precautions aren't taken to avoid deteriorations in indoor air quality. Polluting substances can come from the outside environment, from materials used in constructing or decorating the building, and from activities practiced by the home's inhabitants.

Health concerns related to indoor air quality are extensive, although precise effects in each area are as yet unknown:

- nose, throat, and eye irritations;
- headaches and dizziness;
- respiratory infections and bronchitis;
- lung and nasal cancers; and
- heart disease.

Examples of pollutants that infiltrate homes from the outside environment include carbon monoxide and nitrogen dioxide from automobile and industrial emissions or radon from underlying soils. Other major pollution of indoor air quality comes from formaldehyde and other chemicals emitted by certain building materials (e.g., paints, wood glues, shellacs and varnishes) home furnishings (e.g., glues, fabric finishes), cleaning agents, or pesticides.

A home's residents might add to the indoor pollution by smoking; using indoor grills, wood stoves and fireplaces; pursuing workshop or hobby activities, or through using cleansers, detergents, hair sprays, or similar substances. Most commonly, a home's occupants will begin to complain of indoor air quality in terms of mustiness, stuffiness, smells, or the presence of humidity or condensation.

Commercial Conservation

Commercial users in the Pacific Northwest consume approximately one-fifth of all electrical energy sold in the region. This sector of use has experienced greater growth in energy consumption in recent years than other sectors. Space heating, space cooling, and lighting dominate. Users are diverse business and institutional applications with a wide variety of new and emerging energy technologies underway.

In its planning, the Northwest Power Planning Council has requested that BPA establish, maintain, and distribute the results of its R&D projects that study conservation technologies, construction techniques, and products for commercial buildings. In this way, information accumulates about the size, costs, availability, delivery mechanisms, and necessary lead times for development of the conservation capacity inherent within the commercial sector.

The Energy Edge Occupant Satisfaction Study

This BPA study culminates five years of research into ways to improve conservation efforts and increase productivity in commercial buildings. The study—conducted at buildings in the "Energy Edge" project—investigates how satisfied the occupants are with workstation conditions, temperature, ventilation, and lighting. Information gathered will establish patterns and assist in setting acceptable performance standards.

Perhaps the results will facilitate greater overall conservation measures (EEMS) that will not be ignored, neglected, or required. Without the project, simply as with the commercial conservation research, is attributed to the current satisfaction. In those spaces the test of EEMS conservation program can be successful.

BPA, through an interagency agreement with the Department of Energy's Richland office, has contracted the project to the University of Washington's College of Architecture and Urban Planning in Seattle; the principal investigator is Dr. Judith Heerwagen. Surveys of six office buildings and several non-office buildings were completed. The next step is to tally and publish the results; this should occur by August 1991.

Contact: Dick Jamieson, RM/CB

Evaluation of Energy Management Systems (EMSS)

The project captures information for transfer to others on EMSS. Planned products include a short, easy-to-read publication that provides guidance about when such systems are suitable, typical specifications and maintenance needs, and likely investment. This publication will assist project sponsors in making decisions about adding an EMS to their operations.

In addition, a number of descriptive case studies will illustrate and document installed systems, with the emphasis on actual experiences. The case studies will help project sponsors to differentiate between good and bad systems. The publications will also contribute to training sponsored through the Oregon Department of Energy, BPA's Smart Design program, and other venues. The project enables those considering EMSS to evaluate savings opportunities and the necessary conditions for those savings to occur before investing in a system for a particular commercial building. A consultant—Branch, Richards, Anderson, & Co. of Seattle—and the Oregon State University Energy Extension Service are cooperating in the project.

Contact: Dick Jamieson, RM/CB

Industrial Conservation

Electrical energy consumption by industries in the region accounts for about 40 percent of the total firm demand. The Northwest Power Planning Council has previously noted the difficulty of assessing conservation potential in the industrial sector. Factors that contribute to the difficulty of estimating conservation savings include:

- diverse uses of electricity; site-specific conservation potential; and

- industry attitudes that energy use is proprietary information.

It is therefore very difficult to generalize about end uses of energy or the amounts used in a so-called typical plant. For example, the primary metals industry uses about 80 times the electricity—per dollar of produced output—as does the apparel industry.

To increase understanding of electric energy use in this sector, the Council has recommended that BPA conduct R&D in collaboration with industry to identify potential costs and savings from efficiency improvements in industrial processes that apply to a spectrum of firms.

High Efficiency Electric Motor Rewind Study

BPA, using motor rewinding technology developed by the company Unity Plus, has initiated tests of electric motors both before and after such a rewind mechanism has been installed. This project will validate manufacturer claims that the device reduces power consumption between 5 and 20 percent. If proven, this device signals a major breakthrough in motor efficiency improvements. This advancement could cut the energy consumption of electric motors in manufacturing processes, which currently comprises about 24 percent of the total firm demand in the region.

Contact: Craig Wohlgenuth, RMID

Energy-Efficient Desiccant Dehumidifier (EEDD)

In the second phase of this project, BPA has contracted the design, building, and testing of a prototype EEDD to IIT Research Institute. The outcome of a demonstration installation of a commercial-sized EEDD will help industries identify and initiate conservation and load preservation where processes require strict humidity control.

Contact: Gayland Smith, RPED

Pneumatic Conveying of Wood Waste

Carroll, Hatch and Associates is working with BPA to design, and demonstrate three techniques for reducing electrical energy consumption in pneumatic conveying systems in the wood products industry. Initial findings indicate that pneumatic conveying systems can be an energy conserving reality. Brochures for the wood products industry explain how to improve efficiency in pneumatic handling of wood waste.

Contact: Brad Miller, RMID

Veneer Cooler Sorter

This project investigated the feasibility of a cooler sorter working in conjunction with a radio-frequency dryer for plywood veneer. Phases I and II of the project have verified the technology as very beneficial to plywood production facilities. Not only would the cooler sorter permit more efficient use of existing resources, it also allows the plywood manufacturer to use energy more efficiently and decrease the lead time for production.

Contact: Brad Miller, RMID

Pinch Technology in Pulp and Paper Application

Pinch technology is an analysis methodology used to predict the potential increase in the overall energy efficiency of plant processes. As an analytical tool, it can ensure minimum energy use and capital cost in designing a new plant or retrofitting an existing plant.

Pinch analysis plots the overall heating and cooling demands of the plant on composite curves. Where the curves overlap represents the maximum passive heat recovery or process-to-process heat exchange that can occur in the plant. Where the two curves come closest is called the pinch point, where the smallest temperature difference exists between the cold and hot process streams.

The technology can define the cost-effective use of heat pump technology in lumber drying applications. Successful applications of the pinch analysis to major regional loads will provide a significant tool in demand-side management. The use of this methodology can also help to meet increasingly strict state and federal environmental requirements.

This project—co-funded by BPA and EPRI—set out to determine if pinch technology in Northwest pulp and paper mills would conserve energy. This last year, a site was chosen and a study contracted to Lanhoff March, Inc. to report on the results of thermal analysis, define the project, and install and test equipment. Included in the project is development of a workshop program for area pulp and paper mills, utility representatives, and BPA area personnel.

Contact: Gayland Smith, RMID

Case Study on Dehumidification Drying of Lumber

The joint BPA-OSU study seeks to determine if the use of heat pump dehumidification is an energy-efficient alternative to present drying practices for the lumber industry. Preliminary results—in cooperation with Diamond Wood Products in Eugene, Oregon—indicate that heat pump technology is a sound and viable approach to kiln drying, if systems are properly sized. Certain specific restrictions for use of the technology depend on the type of lumber, the desired moisture level, and the final product's quality specifications.

Contact: Brad Miller, RMID

High Efficiency Electric Motor Guidebook

In 1983, the Washington State Energy Office compiled a guide entitled **High Efficiency Electric Motor Application** for local governments as part of a technical assistance program. The booklet succinctly compares standard motors with high efficiency units and describes the factors that affect motor selection and operating efficiency. BPA is updating the book to remove outdated cost information and to add case studies, sample forms, and calculation examples that will assist plant engineers and electricians in their decision-making. The project supports BPA's development activities concerning energy efficient motors.

Contact: Craig Wohlgenuth, RMID

Residential Conservation

The residential sector consumes just over one-third of the electric power used in the Pacific Northwest. Dominant uses are space heating, water heating, and appliance operation. Other uses include lighting and space cooling. BPA has developed several programs to meet recommendations of the Northwest Power Plan, namely:

- *Northwest Energy Code Program.*
- *Residential Weatherization Program.*
- *Super GOOD CENTS Program.*
- *Blue Clue Refrigerator Freezer Program.*

High-Resistivity (High-R) Windows

A study of ways to improve the energy efficiency of residential windows is in its final phase. High-resistivity windows were obtained from manufacturers, installed in model homes, and monitored. The field tests showed that these windows significantly reduce the heating energy used. When compared with conventional windows in Pacific Northwest climates, the high-R windows are three to four times more energy efficient. The project accelerates the commercial availability of high-efficiency windows from manufacturers. Cooperating in the tests is the Lawrence Berkeley Laboratory.

Contact: Mark Jackson, RPE/D

Wall Moisture Study

Designed to determine why condensation appeared on the walls of homes built to Model Conservation Standards (MCS), this study assists BPA in developing more appropriate specifications for such construction. The technical results affect program policy and ventilation specifications. Researchers took wood moisture samples from 27 homes in the summer of 1989, for comparison with samples from 16 homes taken

during late winter 1988-89. Information was also collected on air flow rates.

Most problems derive from:

- moisture entering walls from the inside of the house,
- moisture entering walls from outside the house, or
- high relative humidities outdoors in coastal regions.

The project's final report recommends techniques that reduce high wall-moisture levels in houses built conventionally and houses built with MCS practices.

Contact: Roy Reinhardt, RMR/D

Utility Conservation

BPA's R&D activities assess the costs and availability of efficiency improvements in the transmission and distribution systems of the region's utilities. Tied to this focus is the assessment of loss reduction through improved voltage regulation.

A study by Battelle's Pacific Northwest laboratories found that 340 average megawatts could be saved for less than five cents per kilowatt hour by improving the efficiency of investor- and publicly-owned systems. In the same study, Battelle researchers discovered that regulating secondary voltages to a narrower range would save from 170 to 270 average megawatts at a cost of less than five cents per kilowatt hour. BPA is committed to assisting utilities so that every possible advantage is taken of such savings potential.

Conservation Voltage Reduction (CVR)

Three feeders from the Snohomish County Public Utility District's no. 1 distribution system are monitored under this project. The data is compiled and modeled in a distribution system analysis and simulation (DSAS) computer program. The project will allow

BPA to determine and to demonstrate the conditions and requirements that are prerequisites for CVR as a viable technology that can reduce energy consumption with minimum impact on the quality of service.

Contact: Barry Kennedy, RMR/D

Quality of Power

The recent proliferation of sophisticated electronic equipment at all user levels—commercial, residential, industrial, utility—has intensified the need for a supply of electricity that meets high standards for continuity, constant voltage levels, waveshape distortion limits, and other factors of reliability and quality. Nationally, indications are that about 80 percent of the power quality problems experienced are due to poor wiring in the end user's facilities.

BPA has begun assessing the extent of power quality problems in its service area and is seeking solutions to those problems. In cooperation with other members of the Northwest Utility Engineering Forum, BPA is pursuing the power quality issue through workshops and forums. In addition, BPA has sponsored an EPRI power quality workshop for customers.

The agency is also developing materials to provide utilities and their customers with feasible methods of solving power quality problems, whether caused by end user or utility circumstances.

Contact: Barry Kennedy, RMR/D

Generation

R&D efforts in generation provide information to BPA's resource planning by investigating technologies and approaches likely to be cost-effective in the Pacific Northwest, refining previously tested technologies through demonstrations, and verifying performance claims made by vendors and others.

Over the past decade, activities by BPA and others have developed a substantial amount of information from a first generation of pilot projects, demonstrations, and initial commercial applications that have used emerging conservation technologies or renewable fuels. During the next few years, work will emphasize the examination of lessons learned from these demonstrations, revision of technical and economic predictions, and comparisons of various potential technologies against future BPA resource requirements.

Adaptive Power Factor Controller

Developed in this project is a reactive power compensation device that automatically senses the energy requirement of a given engine and then switches in capacitors to minimize loading of transmission lines or generating sources. Through this adjustment to fluctuating power

requirements, regional power systems can increase efficiency. This will permit the deferral of investment in new generation and avoid or reduce delivery system losses.

The project, in cooperation with the University of Washington's Department of Electrical Engineering, has installed a 480-volt device to demonstrate the compensation of highly variable reactive energy loads from elevators at the university's hospital. Energy efficiency savings have reached approximately \$600 per month. A rock crushing plant owned by co-sponsor Southern California Edison has had similar results from a 5 kilovolt (kV) prototype device.

A sawmill in Sedro Wooley expects savings from installation of a 15 kV device. Derived from the project is U.S. Department of Energy (USDOE) patent number 4,677,364.

Contact: Nick Butler, RMGB

Brushless Doubly Fed Machine

Continuing its emphasis on conservation, BPA plans to install an electrical machine combining the high efficiency of synchronous operation with the low cost and rugged endurance features of the common squirrel cage induction machine. It is hoped that such a highly efficient, more cost-effective adjustable speed drive (that can also be used as a variable speed generator) will permit efficient conservation and end-use improvement programs. Variable speed pump turbine applications are also anticipated.

BPA has contracted with the University of Oregon's Department of Electrical and Computer Engineering to begin laboratory testing.

Contact: Nick Butler, RMGB

Generation Technology Studies

The study updates progress of R&D efforts and the status of technical, environmental, operational, utility interface, regulatory and economic aspects of generation resources. The results guide BPA's R&D programs by providing technical and economic data for development of resource supply forecasts.

Recent work with Fluor Daniel Inc., has yielded new cost data and a siting analysis for gas turbines and combined cycle plants. An analysis of the repowering of the Hanford generation project was also prepared. In the next twelve months, cost data for wind resources will be updated.

Contact: Norman Fuller, RMGB

Variable Speed Generation

Cooperating in the project are BPA, Oregon State University's Electrical and Computer Engineering department, Electronic Power Conditioning Inc., the California Energy Commission, and the University of Hawaii's Natural Energy Institute (HNEI). The project investigates use of a series resonant converter (SRC) to improve hydrogen generation efficiency. The early phases of the research into variable speed generation systems were described in detail in BPA's **Research and Development Report, Fiscal Years 1987 and 1988** (pages 32-34).

The past year's effort has included initiation of a pump-storage demonstration project with HNEI including physical site work at Kahua Ranch. The design and fabrication of the SRC pump turbine is nearly complete and the California Energy Commission has been contracted for demonstration of a 100 kVA device.

Contact: Nick Butler, RMGB

Additional Projects

The following projects are active; some are without substantive additional findings beyond those already detailed for in the previous biennium's R&D report) and others are in very early stages of set-up and definition. In still other cases, projects have entered an ongoing data acquisition or monitoring phase. Those interested in following the progress of any of these studies are encouraged to contact the listed individual, using the mail routing code given with the person's name, at Bonneville Power Administration, P.O. Box 3261, Portland, Oregon 97208.

Screw Compressor Refrigeration System

Investigation of load flexibility for energy savings in food marketing operations.

Contact: Allan Grill, RMCB

Direct Use of Water for Space Conditioning

A study of the use of geothermal water sources to pre-condition fresh air used in building ventilation. Detailed as a project spotlight in **Research and Development Report, Fiscal Years 1987 and 1988** (pages 30-31).

Contact: Allan Grill, RMCB

Anaerobic Digestion Facility

Feasibility of treating dairy animal waste using anaerobic biological processes to reduce pollution potential of the material is investigated.

Contact: Pat Fox, RMGB

Cross-Flow Turbine

Improved operating efficiency of a cross-flow hydraulic turbine is investigated using hydraulic model. The contractor is preparing a patent disclosure.

Contact: Lee Sheldon, RMGB

Key Wind Data Station Monitoring

Provides for the data collection and reduction from five key stations in BPA wind data network.

Contact: Nick Butler, RMGB

Schneider Hydraulic Turbine

Testing of new runner (rotating element) for a Schneider turbine at Turlock Irrigation District.

Contact: Lee Sheldon, RMGB

Compressed Air System Energy Efficiency

Identification of ECMs in four industries where potential exists for energy efficiencies in compressed air systems.

Contact: Gayland Smith, RMID

Industrial Lighting

A new four-phase study to evaluate effective lighting conservation; also to develop and distribute information and recommendations through publication of a guidebook.

Contact: Brad Miller, RMID

Power Factor Improvements in Mill

Selective application of power factor improving capacitors in mills to save energy, enlarge mill capacity, and reduce utility line losses.

Contact: Barry Kennedy, RMID

Compact Vacuum Insulation (CVI)

Engineering prototypes and demonstration of savings potential of CVI technology in appliances, particularly refrigerators.

Contact: Al Lou, RMRD; Joe Flores, E

Vacuum Windows

Field tests of Solar Energy Research Institute designs in BPA-sponsored homes; co-sponsored by DOE's Office of Buildings and Community Systems.

Contact: Joe Flores, E

Refrigerator Energy Consumption

Data collection to assess average annual energy consumption of Japanese refrigerator units installed in homes.

Contact: Al Lou, RMRD

Many of the reports listed below have DOE/BP publication numbers and are available through BPA's Public Involvement Office by following the procedures detailed in **Obtaining More Information** on page 3. Anyone encountering difficulties, please contact Jon Biemer, mail routing RPED, at the Bonneville Power Administration, P. O. Box 3261, Portland, Oregon 97208.

Bonneville Power Administration. **Adjustable Speed Drive Application Guidebook**. Editor: Gayland Smith. DOE/BP-34906-1. May 1990.

———. **Conservation and Load-Management Research Plans, 1989 North American Index**. DOE/BP-1103. 1989.

———. **Development of Combustion Turbine Capital and Operating Costs**. DOE/BP-63056-1. n.d.

———. **Energy Management System Study, Phase I**. DOE/BP-9208-1. April 1989.

———. **Energy Management System Study, Phase II**. DOE/BP-9208-2. 1990.

———. **Final Environmental Impact Statement on Energy-Efficient Homes Programs**, vols. 1, 2, and Summary. DOE/EIS-0127F. August 1988.

———. **Hanford Generating Project Repowering Analysis**. DOE/BP-63056-2. 1989.

———. **Issue Backgrounder: Energy-Efficient New Homes & Indoor Air Pollutants**. DOE/BP-467. August 1989.

———. **Office of Energy Resources 1987/1988 Yearbook**. DOE/BP-1125. August 1989.

———. **Research and Development Report. Fiscal Years 1987 and 1988**. Office of the Senior Assistant Administrator for Power Facilities. DOE/BP-1211. August 1989. [Earlier volumes in this series of reports are also available.]

———. **Siting Analysis for Combustion Turbine-Based Generating Resources**. n.d.

———. **Vacuum Window Glazings for Energy-Efficient Buildings, Summary Report**. DOE/BP-64357-2. May 1990.

Butler, Nick. **Control Aspects of the Brushless Doubly-Fed Machine**. DOE/BP-332-1. March 1991.

———. **Development and Field Testing of an Adaptive Power Factor Controller**. IEEE '87 Winter Meeting Transactions, 226-4.

———. **Development and Field Testing of a Closed Loop Adaptive Power Factor Controller**. IEEE '87 Summer Meeting 412-0.

Darr, George. **Optioning Geothermal Resources: Assessment of the Feasibility of Purchasing Options on Geothermal Power Generated within the BPA Service Area**. Task 1 report. n.d.

———. **The Bonneville Power Administration's Geothermal Program**. Geothermal Resource Council Transactions, v. 14, part II, pp. 491-494. 1990.

Ecotope. **Innovative Ventilation System Case Study #1: Ashley Gardens Apartments, Ashland, Oregon**. Draft. February 11, 1991.

Jackson, Mark. **Multi-zone tracer gas testing to determine infiltration and ventilation rates**. December 1990.

Kennedy, Barry. **Amorphous Metal Transformer Demonstration Project Final Report**. December 1989.

Miller, Brad. **A Case Study: Application of Heat Pump Dehumidification Drying of Lumber . . .** DOE/BP-92758-1. 1991.

Northwest Power Planning Council. **Recommendations of the Research, Development, and Demonstration Advisory Committee Regarding Confirmation Agendas for Geothermal, Ocean, Wind, and Solar Resources**. Publication no. 90-13. 1990.

Palmiter, Larry, et al. **Measured Infiltration and Ventilation in Manufactured Homes**. Contract No. DE-AM79-87BP35738; Ecotope, Inc., Seattle, Washington. Draft. December 10, 1990.

Parker, G. B. **Ventilation Measurements in Energy-Efficient Multi-Family Dwelling Units in the Pacific Northwest Region**. Contract No. DE-AM79-86BP64352. DOE/BP-64352-1. 1990.

Tsongas, George. **The Northwest MCS Wall Moisture Study**. DOE/BP-91489-1. June 1990.

At BPA, transmission technology R&D involves the development, demonstration, and transfer to customers of new techniques, equipment, safeguards, and other system innovations. The tradition of collaborative R&D—regionally, nationally, and internationally—has been particularly evident in areas such as:

- ultra-high voltage (UHV) systems,
- high-voltage direct current (HVDC) transmission,
- system engineering, protection, and analysis, and environmental impacts.

A major collaboration instituted by BPA in the past two years has been the environmental study of possible effects from electro-magnetic fields (EMF) on the melatonin levels of sheep raised or grazing under 500 kV lines. The project involved six utilities, DOE, EPRI, and three academic institutions (Portland State University, Oregon State University, and the Oregon Regional Primate Center). Project progress and results have appeared in several BPA publications and in presentations at national forums.

In another project, BPA and EPRI cooperated in research into the causes of premature failures in underground cables, which normally have a life of 25 to 30 years. As mentioned in the prologue to this R&D report, BPA is assisting as customer utilities pool resources to solve the problem.

Still another cooperative effort with EPRI has saved BPA's R&D budget about \$175,000. Electric utilities face increased non-linear loads (from such energy-saving devices as fluorescent lighting, industrial rectifiers, and HVDC converters) and, as a corollary, increasing problems with harmonic signals. These harmonics interfere with communications, protective relays, and computers.

EPRI had developed a harmonic power flow (HARMFLO) software package that analyzes generation and spread in power systems of the harmonics produced by non-linear loads. Using HARMFLO, BPA has been able to assist a customer with the installation of tuned shunt capacitors to solve an electrical instability problem. The cost savings came from eliminating the need for extensive field testing.

Much of the attention paid to collaborative

efforts focuses on work with external organizations: manufacturers, universities, governmental agencies and jurisdictions, customer utilities, or research centers.

Another level of collaboration is equally essential: the cooperation between the various organizations within BPA. The R&D program is planned and accomplished by staff in the line organizations: engineering, operations, maintenance, construction, area offices, and district offices. Most projects lead to field tests on the BPA system, which in turn requires the assistance of other segments in the agency. That teamwork is fundamental in furthering the R&D program and bringing the advantages of R&D results to reality.

An example is the use of wood poles instead of steel poles, a system practice that grew out of an R&D project. Findings indicated less maintenance and lower building costs for the directly embedded steel poles. Late in 1990, those benefits were confirmed as a new 48-mile, 115 kV line was completed ahead of schedule and under budget between LaPine and Fort Rock in eastern Oregon. The line serves Midstate Electric Cooperative and a U.S. Air Force radar site.

Two other examples of the diversity of cooperative efforts are the projects concerning penta-contaminated soils and rotor-mounted scanners. The following pages contain details of these and other projects in transmission R&D.

Included with each project description is a contact name and mail routing code for use by those readers who wish more information. In addition, a bibliography is included; please see the **Information Resources** section beginning on page 62.

If you encounter any difficulty in obtaining a publication or project details, please contact the Transmission Technology R&D coordinator through BPA's main switchboard, 503-230-3000.

Jim Ray, Coordinator
Transmission Technology
Research and Development

Advanced Tools for System Operation and Maintenance (O&M)

As BPA's service area has evolved, with ever increasing interconnections with other utilities' systems, equipment has also grown to staggering complexity. At the same time, the system itself is aging, making necessary the refitting or replacement of certain components. And, ever-present, is the drive to keep costs from escalating, by finding and using the most efficient possible devices and approaches. All these factors impel BPA's R&D program to adopt advanced technologies, procedures, mechanisms, and tactics that will assure system operation at peak reliability.

Recent R&D projects which have been pursued to assist in the development of advanced tools for operating and maintaining the system have included:

- A communications alarm processor that employs expert system technology.
- A lightning detection and tracking system that decreases system vulnerability.
- An extra-high voltage (EHV) current transformer monitor to detect impending failures and contribute to design improvements.
- Advanced equipment diagnostics for transformers, on-line air compressors, bushings, and other devices.
- A reliability-centered maintenance program that moves away from the conventional reliance on preventive maintenance at fixed intervals to maintenance cycles based on operating experience and prudence.

Communications Alarm Processor

This sophisticated diagnostic tool uses emerging expert system technology to gather and process alarm data (eliminating most of the non-critical data from alarm systems) in near real time. Control and engineering personnel can therefore avail themselves of the most important information about equipment performance, operating problems, and determine remaining system capacity.

A major goal of the project is to gain experience with expert systems in a control center environment. BPA's telecommunications systems is, after all, integral to the power system, with 183 high density microwave sites, 137 substations operated on supervisory control and data acquisition (SCADA), 605 terminals for microwave transfer trip, hundreds of telemetering quantities, and more. Personnel rely on telecommunications to support:

- stability control functions,
- high speed relaying (microwave transfer trip),
- SCADA control,
- telemetering and data acquisition, and
- voice communications.

Two systems are currently available at BPA to monitor communications and equipment: a microwave alarm system which reports specific equipment failures and a microwave monitor system that evaluates microwave performance in real time. The first tends to produce enormous quantities of data that must then be interpreted by human experts. That takes time. The second gathers far less data but lacks the selectivity to isolate problems.

The major need was for assistance in analysis of alarm data. BPA staff decided to look at expert systems, a subset of the rapidly evolving field of artificial intelligence, as a likely technology in solving the need.

The research staff developed the underlying concepts and boundaries of the project in house before contracting with Oak Ridge National Laboratory (ORNL) to design a prototype system. The basic system was delivered in January 1989. By June 1989, components were added to the prototype to resolve difficulties discovered during set-up. By spring 1990, further additions allowed a more effective evaluation of the processor's applicability to the BPA system.

The expert system relies on a complex chain of rules and a detailed data base for alarm analysis. The rules were developed as the ORNL specialist interviewed BPA's human experts, incorporating their vast knowledge base into the processing system. The care in collecting, sifting, and encoding that human expertise as a data base is the key in the level of confidence that can be assigned to the processor's eventual analyses.

The project is the first significant foray into expert systems at BPA. It will benefit the BPA system by diagnosing problems on the communications system to a specific station and identifying equipment with substandard performance. As a spin-off, BPA will also develop practical experience in the use of expert systems. That may lead to greater use of such aids on the BPA system.

Lightning Monitoring System

BPA has installed a real-time system at the Dittmer Control Center to:

- detect and track advancing lightning storms that could disrupt the transmission system and
- correlate lightning storms with line outages.

A recent lightning storm caused an extensive and damaging outage. That event and its aftermath have triggered an increased interest among operators and dispatchers in this warning system, to anticipate and compensate for such circumstances in future. The monitoring system will allow operations to schedule maintenance outages of lines or bring other lines into service when a lightning threat is present.

The project also enables mapping of the density of lightning hits at ground level. This can improve predictions of outage rates due to lightning for existing lines. The mapped data could also assist in safely routing new lines away from areas of high lightning activity.

EPRI and researchers at the State University of New York (SUNY) cooperated to develop the detection and tracking system. Additional monitors are planned for installation at several locations in the eastern part of the BPA system and at headquarters in Portland.

Security Enhancement System (SES)

In the economic climate of today, the pressure is on for electrical transmission systems to operate at peak reliability. Mandated are increasingly sophisticated control and data acquisition systems and improvements in system security. As BPA's SCADA functions were reconfigured onto Dittmer's

Transmission Control and Dispatch System (TCDS), it was decided to move security tools to a separate host computer.

Security analysis tools, while important, are not as critical as the SCADA functions. In addition, security analysis tools are very computer intensive, using up a large portion of the available time and space on the host computer.

The revised plan provides security applications on Digital Equipment Corporation's VAX work stations, tied into the TCDS computer for real time data, switch status, and analog measurements. The powerful and relatively inexpensive work stations provide a practical and efficient alternative.

The R&D project focuses on a program from ESCA Corporation called Step-Up. The VAX work station both performs necessary security tasks and links the SES with the Dittmer Control Center. The linkages involved the TCDS and Real-Time Operation and Dispatch System (RODS) replacement computers as well as the forthcoming consolidated man-machine interface system.

The Step-Up package comprises a full set of advanced applications—topology processor, bus load model, security monitor, network loss factor calculation, state estimator, power flow, short circuit analysis, contingency analysis, and others. Also included in the package are training simulators for dispatchers and economic analysis tools (e.g., system load forecasting). This permits a utility to select those functions that best supplement existing systems.

EHV Current Transformer Monitor

Several incidents of violent failure of 500 kV current transformers have prompted serious concern at BPA and other utilities. Concerns include personnel safety, property damage, repair costs, clean-up efforts, and customer power losses. Normal preventive maintenance and electrical testing techniques seem unable to detect the likelihood of these problems.

Monitors on the current transformers, properly designed and installed, will elucidate performance questions. From that analysis, BPA can determine improvements to eliminate the difficulties.

Acoustic and other methods are being explored to detect noise discharge. Three different designs of acoustic devices have been tried. All three were capable of detecting partial discharge under the right conditions. However, some designs seem more sensitive than others, and when tested under field conditions, were not always able to survive the transients arising from disconnect switch operations.

Investigations to date indicate that most problems are associated with older oil-filled current transformers. The recommendation is for monitors that measure pressure levels, to indicate any changes resulting from insulation deterioration or discharge.

A device, under development by one manufacturer in concert with EPRI, worked well generally, but was found inadequately shielded against electro-magnetic interference.

Two current transformers are now being subjected to special processing and will be filled with transformer oil having known properties. The transformers return to service will be under tightly controlled conditions. A contractor will develop the data base program to analyze test data.

Over the coming months, laboratory research will refine diagnostic tests and methods (such as power factor, partial discharge, and dissolved gas-in-oil analysis) to determine whether better detection approaches exist to pinpoint deteriorating 500 kV current transformers.

Equipment Diagnostics and Maintenance Techniques

R&D projects are examining many methods, in addition to the current transformer monitors described above, to stay abreast of the status of transmission system components. Early detection of potential failures has become critical; also required are more accurate identification of problems and causes and a more precise estimate of any required corrective action.

Improvements in diagnostic techniques will save BPA thousands of dollars if equipment problems are not allowed to reach catastrophic outage proportions. Diagnostics also play a central role in the reliability-centered maintenance program that could, in turn, extend equipment life, reduce replacement costs, and improve overall system efficiency and safety.

One investigation focuses on transducers and other devices that measure heat or pressure. Substation equipment such as current and voltage transformers, bushings, load tap changers, and surge arresters cannot be adequately tested in the field. BPA's R&D projects seek improved ability to detect the internal changes which presage failures in such equipment. Needed is the research to adapt off-the-shelf sensors—such as those for partial discharge, dissolved gas, pressure, temperature, leakage current—to instrumentation systems that will continuously monitor and diagnose substation equipment problems.

Another area of concern is the detection of low levels of hydrogen and other gases that indicate deterioration in insulating oils. Commercially available instruments seem unstable in an electrical environment. A palladium-silver sensor may possess the desired characteristics, but first the sensor must be adapted for use in an energized transformer.

Other Maintenance Techniques

A remote-controlled, pneumatically-driven brush suited to removal of particulates from the surface of energized porcelain insulators would also be very useful. The concept has been tested and is inherently safe and could apply to both alternating and direct current stations. The ability to clean insulators on energized equipment would have tremendous economic benefit. The next step is to develop a working prototype and demonstrate its effectiveness on actual system components in the laboratory and under field conditions.

Yet another project related to advances in equipment diagnostics is the development of a prediction method for the condition of the core and coil assembly in large power transformers. One approach that looks promising uses vibration analysis.

Another type of equipment requiring a high degree (and therefore cost) of maintenance are the on-line air compressors in air-blast circuit breakers. A contractor is developing a solid-state compressor control and monitoring package

that will reduce the costs. Field trials of prototypes will ensure their usefulness in the energized substation environment.

The kind of projects briefly alluded to above can provide advanced instrumentation that will monitor and diagnose components of high voltage equipment in real time and on line. Applications of such diagnostic and monitoring devices will improve productivity and avoid failures, as well as eliminate unnecessary maintenance.

Reliability-centered Maintenance (RCM)

The ever-increasing availability and use of new concepts and tools in instrumentation, measurement, and data acquisition systems means that traditional approaches to system maintenance can also change. As performance information from system equipment is more readily available through such tools and devices as those described above, maintenance procedures can move away from rigidly scheduled, arbitrarily established intervals. With more detailed understanding of outage causes and interrelationships, maintenance personnel can concentrate efforts where the likelihood is greatest.

ORNL has assisted BPA in an appraisal of the informational requirements and other plan elements necessary as precedents to such changes in the RCM program. With the model plan in place, BPA has begun a demonstration of such a maintenance approach at Alvey Substation. As the project proceeds, maintenance staff will decide on the suitability of RCM for various specific equipment on the BPA system.

Where RCM proves effective, the maintenance program will revise its guidelines, using the criterion of system reliability as opposed to time-drive maintenance. This approach improves both equipment life and staff productivity.

Contacts: Fred Johnson, MMED; Ken Hemmelman, MMED; Roger Houlett, EESF; Jim Graffy, EEDA; Roger Sarkinen, MMEB; Vicki VanZandt, MMEB; Pam Odam, ELRF; Chuck Nellis, ELE

Treatment of Penta-contaminated Soils

Pentachlorophenol (PCP) is a preservative frequently used in the past to treat the wood poles found in transmission and distribution systems. The advent of environmental concerns and legislation has led BPA to replace PCP use with other preservatives. The legacy of previous PCP use at BPA, however, remains.

As a result of past accidental spills during wood pole treatment activities, BPA has in storage at its Ross facility over 250 drums (approximately 200,000 pounds) of PCP-contaminated soil. The Environmental Protection Agency (EPA) standard for disposal of this waste material is incineration. Yet no incinerator is currently holding a valid permit to incinerate this kind of waste, due to problems in meeting the technical standards.

Rather than continue storage of the contaminated material, BPA has chosen to look at treatment options which might make disposal possible.

EPRI provides focused scientific research to utilities in an effort to address the environmental and waste disposal issues faced by the power industry. As a part of EPRI's Land and Water Quality Studies, various projects are investigating the environmental behaviors of organic substances (EBOS).

The Potential for Biological Treatment

Research data documents the probable usefulness of in situ biological treatments (micro-organisms) to reduce contamination in limited volumes or of low toxic levels and recognizes the practicality of such options. Certain attempts at biological and microbial transformation have occurred in funded programs such as the EPA's Superfund Innovative Technology Evaluation or in state research programs.

However, these methods have not been approved by regulatory agencies as a standard treatment for most contaminant situations. BPA project manager, Nancy De Mond, clarifies why some regulations are not yet current with available technology. "Those examining the technology for such treatments are mostly private sector firms. These firms do not want problem sites known because of the potential for extensive and costly regulatory requirements. If a contamination problem disappears, the firm is content that no problem exists and, therefore, the need for added compliance is neutralized."

She continues, "The private sector insists that these biological treatment processes work. The regulatory agencies would consider such approaches—and standard setting would follow—if they could obtain supporting data. Private firms maintain the prerogative to categorize their research data as proprietary information. And, without that evidence, regulators will not change compliance standards."

A Focus on PCPs

Dr. Ishwar Murarka, program manager in EPRI's Environment Division, found a collaborator in BPA to investigate the problem. Using co-funded research, EPRI and BPA developed a project to investigate the options to treat penta-contaminated soils and resolve BPA's storage problem.

De Mond explains the importance of considering options other than disposal to a landfill. "We need to begin focusing on treatment and solutions to waste management, not just moving it around or storing it. Reducing toxicity concentration or eliminating volume at the source are the directions that regulatory compliance is taking us."

Project Phases and Methods

Problems in methodology were addressed first. How are the PCP samples safely extracted from storage drums? How are the samples handled? What regulations and procedures will the research need to follow? What tests will provide accurate characterizations of the soils?

Answers in hand, the research began, as shown in figure 15, including sampling, analysis and characterization, experiments, and transformation studies. A team of contractors from private firms and universities conducted scoping experiments to obtain additional information about the kinetics of distribution and transformation processes—both geochemical and microbiological—associated with PCPs in soils. Also being examined are the effects of fungal and aerobic micro-organisms in transforming the organic compound residues.

A. Protective safety gear was worn to limit the potential of dermal exposure or dust inhalation during sampling.

B. Core soil samples were pulled with an augur to obtain a homogenous (top to bottom) and representative composite soil sample. Grab samples were also taken—at the surface, midway down, and at the bottom of the drums—to demonstrate the potential variances of material within the containers.

Resulting profiles and statistical summaries describe the overall chemical, physical, and microbiological measurements and ranges. Laboratory tests evaluate anything and everything that can facilitate movement (kinetics) or composition changes (transformation) of PCP in soils: indigenous soil microbes, chemical reductants, moisture, nutrients, white rot fungus, or other factors.

Future work will include a thorough examination of the data from this project, from other EPRI research, and from a parallel project now underway at the Western Area Power Administration (WAPA). More rigorous experiments in the laboratory will establish the validity of transferring findings to the storage site for feasibility studies of on site treatment field conditions for further demonstration.

Project Outcomes

The penta-related research is stimulating interest. Other utilities have contacted BPA to discuss the research effort and contribute resources to the scope of work. The chance of extending the collaboration is a welcome one, to attempt using the biological and geochemical treatments on still more waste stream components.

The project managers for BPA, EPRI, and WAPA hope for an additional outcome: influencing regulators to accept this treatment method and project data in standard setting. "It's important," says De Mond, "to provide a solution to BPA's storage problem, and then take the approach one step further and apply it to other contaminant situations."

Figure 15 PCP-Contaminated Soils Research Process

BPA has begun to address historical contamination problems resulting from use of chemical substances in the building and operation of the power system. Wastes have remained on site in upper soils or have collected at points such as outfalls, drainage ditches, or lagoons. The agency has developed a 10-year plan for its pollution control and abatement program. Cleanup efforts include the excavation of soils contaminated by PCP or polychlorinated biphenyls (PCBs) and disposal to appropriate land fills.

The scope of the project will broaden next year to investigate in situ PCB contamination in soils. In fiscal year 1992, the project will expand still further to address waste in the aqueous phase, such as mixed wastes in lagoons.

Already, the project team is meeting with representatives from the State of Washington's Department of Ecology to share the work plan and to discuss the eventual process of changing regulatory requirements for suitably treated soils. The state representatives are very encouraged by this project and are hoping that the philosophy and methods of waste handling can be extended into other areas.

Contact: Nancy De Mond, MMNC

Figure 16: Photographs of Sampling Process

Advanced Technologies in Substation Equipment and Design

Much about substation technology has remained the same for the last 30 to 40 years, with change a frequently suspect quantity. As the century draws to a close, new factors are crowding in. Radical change in substation design is becoming the norm rather than the exception. The familiar substation control room, full of individual components to perform each function, will take on a new look.

Technologies integral to the changes have developed rapidly—computer capabilities, optical sensors, fiber optics, digital communications; the sophistication of technology has often outstripped our ability to include them in normal design and installation applications.

BPA is currently involved in several projects intended to bring those technologies to bear in changing its approach to substation design and operation. Projects focus on power circuit breakers and thyristor-protected series capacitors.

Power Circuit Breaker Controls

Over the years, reliability surveys of power circuit breaker operations have tended to show that 20 percent of major failures and 13 percent of minor failures are caused by breakdowns in the control systems. Even more to the point, failures of the newest generation of breakers indicate that these percentages remain essentially unchanged. At present, all of the redundant protections and controls in a substation connect to a single circuit breaker, each of which is a complex mechanical device (especially at EHV levels).

Recent technical advances have greatly reduced the mechanical complexity of circuit breakers; metal-oxide surge arresters, for example, have eliminated the need for closing resistors on 500 kV, air-blast circuit breakers. However, the control circuitry has not changed significantly in 40 years. The controls continue to depend on electro-mechanical relays to perform elementary control and logic functions. A further impetus for advancing control design is that the relays are expensive and often hard to find.

Specific features of BPA's R&D undertaking in breaker control technology are:

- optical current measurement,
- low level signals for measurement and control,
- electronic breaker controls,
- fiber optic data communications,
- integrated, single system for protection and control functions, and
- use of expert system technology in performance monitoring.

Certain areas already have commercially available products. To be verified is their suitability and effectiveness on BPA's system. Other items need development, optical voltage measurement, digital relays for series compensated lines, the integration of new designs with existing equipment where high level signals exist, and commercial availability of solid-state circuit breaker controls. In addition, redundancy concepts for integrated control and protection systems need analysis and refinement.

A demonstration at the John Day Marion line has monitors installed for observation on the EHV air-blast circuit breakers. At Keeler Substation, a demonstration project will incorporate

Wires To/From Switchyard Devices

Switchyard Devices

Figure 1-1A Conventional Substation Equipment

Fiber Optic Cable

Fiber Optic Cable

Fiber Optic Cable

Switchyard Devices

Figure 1-1B Integration of Substation Functions

several new technologies—optical current transformers, fiber optics, and solid state electronics—into circuit breaker control. That project also includes controlled closing and self-diagnosis of the circuit breaker.

Among the issues that BPA's research will examine are the following.

Integration. Will relays be part of the circuit breaker, part of a master computer, or stand alone?

Remote data requirements. What level of detail is needed in information?

Redundancy extent. Given that any system has the capacity to fail, to what level should redundant protections be designed? At what juncture does the redundancy itself adversely affect the system's efficiency and reliability?

Obsolescence. Technological advances are so fast-paced that equipment of ten years ago is now obsolete and cannot be maintained. Can the control system designed by BPA in this project avoid this pitfall, making the system independent of hardware?

Standards. If many functions are integrated, equipment compatibility between manufacturers could become difficult. Will this project develop standards so that utilities, not manufacturers, guide compatible product development?

As part of the program, a circuit breaker monitor will be evaluated. That monitoring system can then assess the condition of high voltage power circuit breakers (dielectric strength, contact wear, operational speed, drive load) will allow corrective servicing before failures can occur. The monitor will indicate when preventive maintenance is prudent, making this monitor an integral part of the reliability-centered maintenance concept (see page 46).

Power Electronics and Solid-state Equipment

According to many experts, complex interconnected power transmission networks of today require speed and flexibility in dispatching power. Adding to the problem is the fact that the flow direction of alternating current (AC) networks is not readily controlled.

The lack of control means the possibility that a bulk transfer of power may follow the most electrically direct corridor of lines, not the contract path; such a phenomenon is known as loop flow.

To meet this challenge and create increasingly sophisticated controls, EPRI is investigating a flexible AC transmission system (FACTS) that would combine high-power electronic devices and computerized system automation. Large solid-state switches, or thyristors, would manipulate the AC flow. That voltage flow is complicated by the existence of reactive power (volt-amperes reactive, or VARs) that is present due to the impedances of the transmission lines and the loads.

To maintain the proper voltage, one approach would use shunt reactors and shunt capacitors combined with a thyristor-controlled switch. This would result in voltage corrections to keep the flow uniform, even when having to respond very rapidly to line disturbances.

Another approach would be to optimize the power angle (the phase difference between voltages at opposite ends of the line) to solve the loop flow problem. Phase-shifting transformers have been used already to redirect

power flow from one line to another. Changing the power angle setting of such a transformer, however, can take time; repeated changes cause arcing which wears out equipment. Using thyristors to change the tap setting reduces the time involved to milliseconds and, because there are no moving parts, virtually eliminates the need to restrict the frequency of resettings.

A third approach would be to change the impedance (total opposition to ac flow). The thyristor directly controls

Source: EPRI Journal, June 1989, page 10

Figure 18 Electronic Speed in a Power Circuit Breaker

the capacitance inserted in series on a line, and dials in or out just the right amount to stabilize the system.

The first step, that of producing semiconductor materials capable of handling high voltage and current, has already been accomplished. Next comes the step of designing and testing a new generation of solid-state devices. BPA has an agreement with EPRI to serve as a host utility to demonstrate the thyristor-controlled series compensation (TCSC). General Electric is performing system studies and supplying specific equipment.

BPA is locating TCSC equipment for field testing at a site selected on the basis of suitability for demonstrating subsynchronous resonance (SSR) benefits, damping control, electrical performance, and transient stability improvements. The site must also be accessible, yet where testing activities will minimally affect the surroundings.

Future work will need to develop communication and computer capabilities that can take advantage of the greater speed and flexibility that the new control hardware permits. Utilities could then increase loading on existing transmission lines and handle more transactions and yet not compromise reliability.

Contacts: John Brunke, EOLIA, Brian Furumasa, EOLIA

Stability Prediction and Control

In August 1986, a contract between BPA and the Virginia Polytechnic Institute and State University, began a project to develop a synchronized phasor measurement hardware system that would be suited to installation on the BPA transmission grid. By 1989, the first digital system was installed; by September 1990 it was fully operational. Remote stations are located at John Day and Malin substations on the Pacific Intertie. These transmit data to the master computer at the BPA laboratories in Vancouver, Washington.

The two digital systems directly measure power changes and disturbance on the transmission system.

A master analog system also transmits data from Malin to:

- a power system disturbance monitor located at the Dittmer Control Center and
- the laboratory facilities located nearby.

To examine the capabilities of the digital phasor systems, data transmissions during four system disturbances were contrasted with the data presented by the analog system.

The three systems track very closely. Waveform records showed excellent correlation. Overall calibration between the systems varied by up to 3 percent of full scale. All the disturbance detection algorithms tended to be rather slow, taking one to four seconds after the event actually started. The phasor system records the phase angle which the analog system does not.

Data from the phasor system shows faster response and is inherently less noisy than the analog data. Data from the phasor system also seems to have a greater resolution. All systems show a strong 0.3 hertz (Hz) reaction to all disturbances.

The results are encouraging. Areas that need further work include calibration, frequency algorithm, disturbance triggers, and the algorithm for the rate of frequency change. The digital phasor measurement unit is now being commercially developed, based on the work by BPA and Virginia Tech.

The project has implications for increasing the flexibility of direct current transmission that may have larger benefits in increased power transfers.

Development of the phasor measurement system led to a method for tracking incipient voltage instability using the measurements. Included in the studies was an evaluation of strategies to control and recover from approaching voltage collapse through load shedding. Extensive simulations have confirmed that the system could indeed recover from a voltage collapse.

In addition, the digital measurement system provides tracking of phase angles in its data gathering repertoire. It has been proposed, as part of a program to improve the dynamic performance of the two direct current (DC) transmission links (3100 MW Pacific HVDC Intertie and the 1920 MW Intermountain Power Project), that these phase angle measurements could be used along with satellite timing systems as very remote sensors. These sensors could become integral in a control strategy based on response-oriented expert systems to handle disturbances on very large networks.

Contact: Carson Taylor, EOH

Environment, Health, and Safety

A variety of research, development, and demonstration projects focus on environmental protection and on the health and safety of utility workers and the public.

Magnetic Fields Characterization

BPA is more precisely profiling the magnetic fields surrounding the agency's transmission lines. A research team at Portland State University has collected data from all categories of transmission lines in the BPA system. The study has involved selection of instrumentation, development of measurement protocols, training of information gathering teams, and the construction of a database. A long-term measurement program has already established methods that are valid for single circuit lines; confirmation of the methodology's validity on double circuit lines will be complete this year.

A software program converts SCADA records from more than 400 different transmission lines. BPA has a corona and field effects computer program that calculates the magnetic field levels for each line and comprehensive data books are created for 115 kV, 230 kV, and 500 kV voltage classes.

Results describe magnetic field levels under actual operating conditions. The analysis during field monitoring of a 230 kV line and historical SCADA records of 500 kV, 345 kV, 300 kV, 230 kV, and 115 kV lines shows the following:

- Statistics measuring current loading have the same validity independent of the time intervals of data collection.
- Magnetic field statistics can be accurately calculated using hourly SCADA data along with line geometry characteristics.
- Load current is the most important factor in calculating magnetic field statistics on or off the right-of-way; magnetic fields associated with overhead transmission is less dependent (in contrast with electric field)

on height of line conductors beyond the edge of the right-of-way.

Other projects involving the environmental assessment of effects from magnetic fields will use the information to establish project scope and limitations.

Contact: Rick Stearns, EESB; Brian Furumasa, EOHHA

Substation Equipment and Design

This subcategory of R&D projects deals with advances that will make substations and their equipment safer, more reliable, and more cost-effective.

Grounding Study

The intent of this project has been to improve grounding grid designs and lower costs. Montana State University researchers completed development and delivered new programs to design grounding grids. Two computer programs are operational; more programs are coming. Several papers on this topic were presented during the last two years.

Contact: Don Blank, EESA

Substation Rock Reclamation

A consultant is testing potential reuse of crushed rock and the possible cost savings. The question is whether the removal of soil particles (which reduce insulation value) is cost-effective. Tests at three substations indicate that reuse is practical and efficient, with the resistivity and original depth of the rock layer restored. A demonstration at Ringold Substation on February 20, 1991 was observed by BPA representatives from various specialties and field offices, and by representatives from several customer utilities.

Contact: Don Blank, EESA

Capacitor Studies

In the future, BPA will replace all of its existing polychlorinated biphenyl contaminated capacitors and will, undoubtedly, add new ones to meet new load conditions. If the life of these capacitors is increased, thousands of dollars can be saved. This project helped develop new test methods to uncover problems in new capacitor designs.

In the past, BPA has submitted capacitors to special design tests, beyond those standard in the industry. BPA's existing technical specifications have thus eliminated some manufacturers from bidding on new capacitor purchases. The study looked at whether changing the technical specifications would jeopardize quality or reliability.

The project is using units rated at 7960 volt and 200 KVAR which are purchased from three domestic manufacturers. In addition to looking at other performance factors, any failures among these units will be compared with units that have failed while in operation on the BPA system.

Contact: Ron Denis, ELEE

High-Strength, Conductive Adhesives

High-strength adhesives may replace costly butt-welded aluminum bus joints. The capacity to structurally connect aluminum and other metallic components in the field would mean cost reductions up to 75 percent for new bus installations and repairs.

The first phase of the project determined suppliers and available adhesives.

The second phase is looking at the needed pre-treatment of metal components, the mechanical durability, and the electrical reliability of the adhesive connections over time. Preliminary work has shown both:

- how important the pretreatment of bus important is to produce necessary low resistance connections and
- that thermal curing reduces conductivity.

A patent application has been filed.

Contact: Marvin Nelson, EFDI

Advanced System Studies

This category of R&D projects focuses on the big picture in system planning, striving to analyze, design, and prepare techniques and equipment that ensure meeting future needs in BPA's service district.

Voltage Collapse Identification

The project is developing generalized algorithms to predict voltage collapse. Early identification of potential problems could reduce planning time and the associated costs of conducting other studies. The process of algorithm development uses theoretical analysis and the technology of expert systems for its decision making. Cooperating in the project are EPRI and researchers at Howard University.

Contact: Jim Ray, EO

Tacoma Load Modeling

An examination of BPA power flow data will provide information pertinent to the development of quantified

load models. If that information content proves adequate, new models will be constructed and compared with those already in use in system planning. The project also develops any data acquisition tools and mathematical software needed to accomplish project goals.

The results will:

- validate the load models used in system planning,
- enhance the tools for data analysis and model construction, and
- provide insight into actual load behavior and statistics.

Contact: John Hauer, EOHC

Signal Analysis

The project is reviewing signal analysis methods and the software applicable to direct estimation of power system damping. Results will include:

- construction of models for actual power system,
- measurement of damping in system planning models, and
- improvement in the estimators for on-line use, including stability monitoring and control.

Cooperating in the study are Parametrics, Inc. and researchers at the University of Colorado and Montana State.

Contact: John Hauer, EOHC

Dynamic Interaction Monitoring System

Initial work in monitoring hardware and validation of power system disturbances has been completed in an Intertie performance monitoring project. The next task is development of a computer-based data acquisition system to monitor interactions among the major AC and DC facilities throughout the BPA service area. The project will also develop ways to coordinate system monitoring capabilities of BPA with those of other utilities.

Intended outcomes are improvements in the early detection of emerging problems on the system or in specific facilities or equipment and the analysis of power system disturbances. Another related project seeks to extend existing methods of access to information that can only be obtained from the power system itself and thus to allow more effective use of staff expertise.

Contact: John Hauer, EOHC

Staged System Testing Methods and Techniques

The Division of Laboratories conducts ongoing, staged tests on the system to verify that:

- new equipment operates according to design,
- simulation results are accurate, and
- new technologies are compatible with the intended reliability and stability standards of BPA's system.

During the last biennium, a second trailer for automated data acquisition during system tests was completed. The trailer is shielded and equipped with fiber optic data links, digitizers, microvax computer for data storage and analysis, and an analog backup system. Upgraded computers are now in place. Additional software contracts will ensure increased data analysis capability during staged system tests. Training is increasing the number of personnel capable of operating the test trailer equipment.

The next stage of the project will initiate development of a digital data acquisition system that is portable for use in remote locations.

Contact: Steve Sarkinen, ELEE

Power System Control

Projects in this category emphasize the development of improvements in protection systems and reliability criteria to meet not only expansion requirements on the Pacific Intertie but also other future control needs on the overall power system.

Digital Stability Controller

This project is evaluating and testing commercially available programmable controller technology. The equipment must prove reliable in a substation environment. If successful, these systems could significantly reduce overall costs of installed control systems, saving staff time in the design phases and in material costs. Tests will include both laboratory and field work; plans call for a test unit to be installed during the coming year, probably at Garrison Substation.

Contact: Paul Schaad, EEPA

Static VAR Control for Power System Damping

The intent of this project is to extend the industry's options, including BPA's, for engineering of large-scale damping control systems. Both self-tuning and adaptive control methods may prove practical as a means to maintain acceptable levels of controller performance as the system's operating conditions change.

The project will assist in developing an EPRI stability program that supports user-coded modeling of an advanced control system. The project will also develop more effective protocols and resources work being accomplished at the University of Montana, so its researchers may more fully participate in industry R&D efforts.

Contact: John Hauer, EOHIC

Relay Tests

Testing at the laboratory evaluates newly available relay systems for potential use on the BPA system. The tests provide a review of performance independent of manufacturer testing.

Reports—available to anyone in the industry upon request—are prepared by the Division of Laboratories

and the Division of Electrical and Electronics Engineering

Contact: Susan Wiese, EEPB

Relays previously purchased and tested at the laboratory are installed at Redmond and Harney substations to compare field data with that obtained in the lab. The project may expand to include relay tests for the main transmission grid, including traveling wave relays, advanced microprocessor relays, and adaptive relays. The results will increase reliability on the Intertie and other transmission systems. It will also provide information useful in future relay procurement.

Contact: Jon Dauter, MMEC

Protection and Control Test Systems

The project develops tests and systems to improve the evaluation process and to assist in trouble shooting and quality control for any devices being considered for application on the BPA system. Savings come from testing these devices under actual conditions before purchase or installation commitments are made.

The relay evaluation system, for example, was successfully used in this biennium to evaluate the responsiveness of equipment proposed for procurement and use on the third AC intertie. Program uses will include evaluation of transformer differential, bus differential, and solid state relays. The laboratory intends to develop smaller versions of this evaluation system for use by system protection and maintenance engineers in the various districts.

Contact: Jerry Nordstrom, EHP

Consolidated Operator-machine Interface

This project studies and demonstrates an operator's use of a single network-based work station to interface with the multiple systems, each fairly autonomous, at Dittmer Control Center.

Contact: Jim Dow, EED

Transmission Line Technology

Research in this category addresses improvements in the design, testing, and repair of components in the transmission line system, from disconnect switches and conductors to insulators and structural materials.

Moro Structural/Mechanical Test Program

This ongoing program has studied the performance of the Moro transmission line to advance line design at all voltage levels. A main focus in recent years has been to collect data on the accumulation of ice on single and bundle conductors to improve design criteria. Recent benefits include improvements in load predictions that allow structures to approach optimum design and minimum costs. A new data recording system provides both measured quantities and recorded data values by phone modem.

Contact: Michael Johnson, ELMM

A related project will develop an archive to permit effective storage and retrieval of the test data collected in the 1200 kV studies at the Moro site. This would include an index of site data cross-referenced to show where copies of the data can be found. The data's availability is an important resource for BPA and for other utilities.

Contact: Ron Thorkildson, EFDH

Reliability-based Design of Transmission Lines

In cooperation with EPRI and researchers at the University of Maine, BPA is investigating use of reliability-based design methods. A literature search has been completed. Investigators are participating in an advisory group established by EPRI and the National Science Foundation for development of methodology.

Contact: Leon Kempner, LFDG

Conductor Vibration Field Test

A field test is investigating the adequacy of standard criteria for three different conductor designs, in order to determine if standard practices for aeolian vibration damping are safe. Improved self-damping characteristics in the all-aluminum and in the trapezoidal-wire designs may allow criteria changes which could in turn lead to greater efficiencies in conductor tensioning. Also examined is the likelihood of inter-strand fatigue damage.

Contact: Len Custer, EFDH

System Operation and Maintenance

This group of R&D projects contributes to make the day-to-day operations of the transmission system more efficient, more cost-effective, and more reliable. Projects look at techniques that will achieve maximum efficiency from existing equipment. This permits BPA to plan the most cost-effective strategies and schedules for needed maintenance, modifications, or replacement of system components.

Rotor-mounted Scanner

The rotor-mounted scanner (RMS) continuously monitors heat level and other traits characteristic of progressive fault conditions in a hydro generator. The RMS can detect overheating or incipient insulation failures. With timely corrections, these conditions need not result in catastrophic failures of turbines. Prevented are losses in service and in revenues. Operators and plant maintenance engineers will be able to schedule cost effective corrective or preventive maintenance. The philosophy behind this project is closely related to other efforts of reliability-based maintenance described on page 46.

The BPA project is jointly sponsored by EPRI and Seattle City Light. Under test are two RMS units at Seattle City Light's Boundary Project and one

funded solely by BPA at the Corps of Engineers' Lower Granite Project. Prototype refinements should lead to marketable unit designs within a relatively short time.

Contact: Nick Butler, RMGB

DC Hotline Detector

Development of a hotstick live line detector would assist in indicating the presence of DC voltage without indicating the presence of AC voltage. Development of a prototype is underway.

Contact: Randy Melzer, LDT

EHV Laboratory Studies

Evaluation and applications for digitizers and controllers in high voltage measurements continue. An electric field sensor (fiber optic coupled) has potential usefulness in saving time and effort for staged system tests where midline voltage measurements are needed. Development is underway of a voltage divider capable of measuring steep front waveforms as used to perform puncture tests on suspension insulators.

BPA also hosted the IEEE PES workshop on magnetic fields, May 16-18, 1989. The sessions compared all commercially available magnetic field survey and exposure meters. When the calibration loops are placed over a very good ground plane, the project found that the field calculated from the geometry of the loop was reduced due to eddy currents in the metallic material in the ground.

Contact: Phil Renner, ELEE

Additional Projects

Annotated in this section are additional research, development, and demonstration projects that are currently active in the area of Transmission Technology. Again, a contact is listed for each endeavor; that individual may be reached at 503 230-3000 or by writing in care of the Bonneville Power Administration, P. O. Box 3621, Portland, Oregon 97208.

Biological Studies

An on-going team effort to review and assess information about the biological effects of high-voltage transmission lines.

Contact: Jack Lee, EFBG

Transmission and Livestock Reproduction

A study to determine electro-magnetic field effects of alternating current (if any) on the pineal hormone melatonin in sheep.

Contact: Jack Lee, EFBG

Bundle Conductor Marking

Development of a sphere that is electrically and mechanically suited for installation on multiple bundle conductors.

Contact: Arnie Reeder, EESG

Bird Collision Study

Investigation of marking strategies and devices to mitigate transmission line collisions by birds.

Contact: Philip Harens, EFBG

Oil Sensors

Procedures and test equipment set up for evaluation of several different units that activate and close valves when an oil spill is detected.

Contact: Frank Worth, EHH

HVDC Insulation Studies

Ongoing studies of natural pollution problems associated with HVDC systems, i.e., testing surface coating materials on insulators and stress tests on insulators to determine flashover point.

Contact: Phil Renner, EHE

HVDC Gas-Insulated Substation (GIS) Test Pole

Demonstration of the long-term performance of air-insulated bushings in converter stations.

Contact: Ed Yasuda, FOH

HVDC Wall Bushing Tests

Investigation of silicone rubber coatings on exterior porcelain surfaces of bushings to reduce, or eliminate, costly flashovers of in-service equipment. Cooperating in the project are EPRI and the Los Angeles Department of Water and Power.

Contact: Charles Nellis, EEE

Room Temperature Vulcanized (RTV) Coated DC Substation Insulators

Investigation of RTV coatings on porcelain insulators; accelerate aging of coatings (for test purposes) in a salt fog chamber.

Contact: Brian Furumasa, FOHA

Materials Studies

Monitoring earth resistivity to identify factors that lower resistance of grounded structures.

Contact: Ronald Nilson, EMM

230-kV 3-in-1 GIS

Determination of cost effectiveness and reliability for these compact designs.

Contact: Jim Ray, FO

High Energy Metal Oxide Varistors

A cooperative project with General Electric and EPRI to develop a varistor with a higher energy handling capability per unit volume and a higher current density capability.

Contact: Gerald Lee, FOHA

HVDC Breaker Insulation

Proving dielectric capability of HVDC breaker to operate as intended on the HVDC Intertie.

Contact: Ed Yasuda, FOH

Nitech Power Donut Sensor System

Evaluation of performance, measurement accuracy, system stability, and reliability of sensors that monitor line current, voltage, phase angle, and conductor temperatures; ties into the overall BPA effort to explore all methods that could assist with reliability-based maintenance concept.

Contact: Rick Stearns, EESB

Portable Transducer System

Meets the need for improved, portable instrumentation for data acquisition and control in signal processing of power system dynamics.

Contact: John Hauer, FOHC

Power System Performance Monitor

Collect and analyze high speed system data from Dittmer Control Center.

Contact: Gary Suoboda, EEDA

Telemetry Equipment Development

Development of specifications and selection of next generation of remote units that will collect kilowatt and kilowatt-hour data.

Contact: Richard North, EEDB

AC Electrostatic Field Study

Determination of electro-magnetic fields around transmission equipment to determine areas of high field strength and to mitigate high-speed traveling waves. Results will allow maintenance personnel to work safely on high voltage equipment.

Contact: Eugene Davis, EOHIC

Outage Cost Survey

Determination of interruption costs to direct service industrial customers.

Contact: Brian Silverstein, EOB

Distribution Automation with Customers

Continuation of the investigation of the benefits of distribution automation in reduced losses and the transfer of related technologies.

Contact: Jim Ray, EO

Superconducting Magnetic Energy Storage System (SMES)

Proposed placement of a 20 MW-Hr SMES unit on BPA power system at Hanford.

Contact: John Haner, EEPA

RTU Simulator

Currently testing units on SCADA's replacement system (CDS Master).

Contact: Jay Coleman, EEDC

Electro-magnetic Transient Program (EMTP) Restructuring

Improved computational techniques and computer codes for more rapid solutions using less sophisticated hardware.

Contact: William S. Meyer, EOHIC

Dispersed Small Generation EMTP Studies

Investigation of possible future connection of self-exciting small generation units to BPA system.

Contact: Dan Goldsworthy, EOHIC

Electro-magnetic Field Exposure Meter

EPRI-developed metering device for determining electric and magnetic field exposure among utility workers. Device was worn by various utility personnel to quantify exposure levels. As expected, substation workers have highest overall magnetic field exposure with distribution linemen having the highest mean exposure.

Contact: Vern Chartier, ELE

Chemistry Studies

Development of testing procedures and analysis methods to increase efficiency of laboratory studies, from soil sample preparation method to determining toxic byproducts from SFO equipment. Co-funded by BPA, EPRI and several others. Conducted by Oak Ridge National Laboratory, the National Institute of Standards and Technology, and Ontario Hydro.

Contact: William White, ELM

Hazardous Waste Vitrification

Review of available documentation concerning the technology and economics of in-situ vitrification of hazardous waste to ascertain its possible use of BPA.

Contact: Dean Landers, MMN

Control Equipment's Generic Test System

The Testing Automation Unit (TAU) simulates "real" world events by providing input to the system under test, i.e., for verification of control systems such as the Intertie's remedial action control system and the HVDC Master Control System.

Contact: Don Winchester, EEPG

Application of Precise Time Synchronization

Evaluation of Global Positioning System (GPS) satellite receivers for use in the new BPA central timing system; development of the interface to extract time code output from the real time clock in the new remote fault locator (FLAR) unit. Project has confirmed the use of GPS receivers as being suitable and allows accurate time codes at any BPA substation equipped with a FLAR. Receivers have been installed at Dittmer and Colstrip for a demonstration phase after undergoing stringent test procedures at Ross laboratory.

Contact: Mike Street, EECC

Millisecond Timing System Verification

Investigates millisecond timing synchronization between substations as well as corrective measures to improve availability. Includes theoretical research, model development, and purchase and testing of time code devices.

Contact: Richard North, EEDB

Frequency Dependent Transformer

Development of a high frequency model to assist in solving problems in gas-insulated disconnect switching, capacitor switching, etc. Outcomes could reduce need to be as conservative in planning and design, while still ensuring reliability and safety.

Contact: William S. Meyer, EOHIC

Artificial Intelligence (AI) Applications

Investigation of ways to effectively use AI to solve BPA system problems, e.g., a contract with the University of Washington to develop an AI based system to evaluate complex and extensive results from laboratory relay testing.

Contact: Gary Stemler, EII

Expert System for HVDC Intertie

Examination of feasibility of using expert systems for the master controller, because system operation has become so complex that traditional programming techniques cannot cope.

Contact: Dan Winchester, EEPG

Phasor Measurement System

Evaluation of a system developed by Virginia Polytechnic Institute and its applications at BPA; studies indicate the system is sensitive, accurate, and fast for detecting power system swings.

Contact: Ken Martin, EEP

Tests of System Electrical Data

Actual system measurements are compared with calculated data to verify calculations and engender more accurate relay settings.

Contact: Jon Dattome, MMEC

Fiber Optic Telephone Protection

Provision of ground mat isolation for telephone lines.

Contact: Larry Hartnell, EEDB

Integrated Transfer Trip System

Modifications for single pole relaying; development of automated testing features.

Contact: Kevin Smiley, EEP

Hybrid Generation System

Final reports have been issued on solar wind hybrid generation at Jack Mountain radio site installation.

Contact: John Hahn, EECB

Upgraded Microwave Monitor Parameter Detection Card

New design with major improvements: broadband input, switch-tuned local oscillator, and an intermediate frequency repeatable passband.

Contact: Mike Street, EECG

Transient Coupling Transducer

Provides and tests a cost-effective method for fault location at remote substations.

Contact: Mike Street, EECG

Data Acquisition Systems: Design and Application

Ongoing work with instrumentation, measurement techniques, control system hardware, and software development.

Contact: Louis Lee, RMRD

Insulator Tests

On-line testing of DC transmission insulators; includes installation of silicone non-ceramic insulators and design of strut assembly.

Contact: Robert Brown, EEDH

Non-Ceramic Insulator Evaluation.

Developed designs for 100-inch 500 kV insulators and a test standard for 115 kV and 230 kV procurement, and field tested 500 units.

Contact: Robert Brown, EEDH

Dynamic Loading of Transmission Lines

Presentation of technical paper on completion of 95 percent of scale model tests.

Contact: Leon Kempner, EEDG

Cold Form Structural Shapes

Literature review concerning advantages and disadvantages of its use in transmission towers.

Contact: George Green, EEDG

Transmission Tower Foundation Uplift

Evaluation and more accurate analysis of tower foundation uplift capacity; possibility for increased span lengths.

Contact: Jim Rustold, EEDJ

Tower Steel Fracture Criteria

Development of fracture toughness criteria; application of criteria to past cracked steel problems at BPA.

Contact: Leon Kempner, EEDG

Limit-State Modeling

Analysis guide document and expert system computer program to use with limit-states structural analysis program already developed.

Contact: Mike Miller, EEDG

Photogrammetric Studies: Data Evaluation, Testing, Applications

Data consolidation, analysis, and summarization of findings in obtaining accurate, three-dimensional measurements of existing transmission lines.

Contact: Richard Pries, EEBH

Clothing Flammability

In cooperation with Duke Power, determination of fabrics that protect workers in and around electrical facilities from electrical arc burns.

Contact: Ken Kuehn, MMEA

Gas-Insulated Substation Studies

Ongoing testing related to fault location, commissioning, internal transient modeling, component performance, and maintenance practices.

Contact: Dan Bradley, EEL

Fault Locators and Digital Fault Recorders

Comparison of various units and software programs on market.

Contact: Jon Daume, MMEC; Ken Hemmelman, MMED

Visual Mitigation With Plantings

Feasibility of using vegetation of dwarf species to mitigate impacts of right-of-ways and access roads.

Contact: Rich Embree, EFBC

900 MHz Field Test

Radio equipment evaluation using field test package.

Contact: Robert Day, EECC

Power Scheduling

Feasibility study for expert systems applied to Division of Power Supply schedules.

*Contact: Jim Bolton, PSP;
Jim Dow, EED*

Load Current Influence on HVDC Fields and Ions

A contract with Washington State University for cylindrical corona cage at the university's new engineering building. Researchers to profile the ion currents throughout the 360 degrees of rotation.

Contact: Vern Chartier, ELE

Detection Relays

Based on need to improve and/or replace power change detection relays designed and built in 1970s; study defines functional requirements and plans prototype procurement.

Contact: Paul Schaad, EEPA

Solar-Powered Cathodic Protection Submarine Cable

Monitoring and final report on 10-year project in San Juans.

Contact: Dan Nichols, EESF

Submarine Cable Repair Plan

Development of tools and procedures to repair submarine cable systems cost effectively.

Contact: Dan Nichols, EESF

High-Energy Surge Control Resistors

With Westinghouse and General Hybrid, develop resistor for use in switching 500 kV transformers and perhaps eliminate need for circuit breaker in many applications.

Contact: John Brunke, EOHA

For additional information about the projects described in the previous pages, please contact the listed individual [see the name and mail routing code in brackets with each description] at P.O. Box 3621, Bonneville Power Administration, Portland, OR 97208, or call the contact person through the BPA switchboard at 503 230-3000.

To obtain publications listed below with DOE BP designations, please use the procedures described on page 3. Conference papers and technical journal articles are usually available at university or professional libraries. If you have difficulty in obtaining copies of these reports, please contact Jim Ray through the BPA switchboard at 503 230-3000 or Jim Pachot at 503 230-4373.

Blank, D. et al. **Evaluation of ground resistance of a grounding grid of any shape.** IEEE 90-WM-129-7-PWRD, January 1990.

———. **Ground resistance of concrete-encased electrodes (field tests).** American Power Conference, April 1990.

Bradley, D. **A voltage sensor for measurements of GIS fast transients.** International Symposium on High Voltage Engineering, August 1989.

Bradley, D. and S. Lowder. **Control wiring and outer sheath transient measurements at BPA's Buckley 500 kV Gas-Insulated Substation.** Canadian Electrical Association conference, March 1989.

Brunke, John and Wayne Litzenberger. **New Directions in Substation Control and Protection.** BPA Engineering Conference Paper, n.d.

Bunch, R., Litzenberger, W., Reynolds, M., et al. **Completion and Initial Operation of the Expanded Four-Converter Celilo-Sylmar Pacific Northwest Southwest Intertie.** CIGRE, Aug. 1990.

Chartier, V. L. **Comprehensive empirical formulas for predicting EMI from overhead power line corona.** US-Japan Seminar on Electro-magnetic Interference (EMI), 1988.

———. **Joint HVAC transmission EMF environmental study: electrical monitoring.** n.d.

———. **Magnetic field characterization project.** BPA 1988 Engineering Conference.

Chartier, V. L. et al. **Examination of the Grizzly Mountain database to determine effects of relative air density and conductor temperature on HVDC corona phenomena.** IEEE 90-WM-020-8-PWRD, February 1990.

Electric Power Research Institute. **HVDC wall bushing studies.** Interim Report, RP 3039-1, n.d.

Erickson, D. C. et al. **The potential use of optical sensors for the measurement of electrical field distribution.** IEEE 89-WM-051-4-PWRD, January 1989.

Esztergalyos, J., Brunke, J., Schweitzer, E. O., et al. **Micro Computer Based Breaker Failure Relaying for 500kV Air-Blast Type Circuit Breakers.** 16th Western Area Protective Relay Conference, Oct. 24-26, 1989.

Gillies, D. A. et al. **Field and test experience with insulating rope at BPA.** IEEE Electrical Safety Maintenance Operators, Toronto, Ontario, Summer 1990.

Hauer, J. F. **BPA Experience in the Direct Measurement of Power System Dynamics.** American Power Conference, Chicago, IL, April 23-25, 1990, Paper 35b.

———. **BPA Experience in the Direct Measurement of Power System Dynamics.** Joint EPRI-CRIEPI Symposium on Power System Dynamics and Stability, Monterey, CA, May 8-10, 1989.

———. **Dynamic Utility Applications of SMES.** CIGRE, Aug. 1990.

———. **Identification of Power System Models for Large Scale Damping Control.** 28th IEEE Conference on Decision and Control, Tampa, FL, Dec. 13-15, 1989, Paper IS-25-2.

———. **Initial results in the use of Prony methods to determine the damping and modal composition of power system dynamic response signals.** Department of Energy report DOE BP-1183, October 1988.

———. **Robust Damping Controls for Large Power Systems.** IEEE Control Systems Magazine, pp. 12-19, Jan. 1989.

———. **Use of Prony analysis to determine modal content and equivalent models for measured power system response.** Eigenanalysis and Frequency Domain Methods for System Dynamic Performance, IEEE publication 90TH0292-3-PWR, pp. 105-115, n.d.

Hauer, J. F. and E. Vakili. **An oscillation trigger for power system monitoring.** IEEE Transactions, Power Systems, pp. 74-79, February 1990.

Hauer, J. F. et al. **A supplementary adaptive VAR unit controller for power system damping.** IEEE 89-WM-197-5-PWRS, January 1989.

———. **An Enhanced LQ Adaptive VAR Unit Controller for Power System Damping.** IEEE Transactions on Power Systems, pp. 443-451, May 1989.

———. **A Supplemental Adaptive VAR Unit Controller for Power System Damping.** IEEE Transactions on Power Systems, pp. 1017-1023, Aug. 1989.

———. **Initial results in Prony analysis of power system response signals.** IEEE Transactions, Power Systems, pp. 80-89, February 1990.

———. **Square Butte HVDC Modulation Field Tests.** IEEE Transactions on Power Delivery, pp. 351-357, Jan. 1990.

Hennelmann, Ken et al. **Communications Alarm Processor: Expert Systems Applications.** Electric Power Industry Conference, June 1989.

Kempner, L., Klinger, et al. **Tower Strength using Post-Buckling Member Behavior Correlated to Full Scale Tower Tests.** CIGRE, Aug. 1990.

Klinger, M. et al. **The Prospect of Superconducting (SC) Technology Impact on Future Power System Equipment in the United States.** CIGRE Aug. 1990.

Lee, Jack. **Project brief: Ostrander EMF environmental study.** DOE BP-1328, April 1990.

McCoy, M., et al. **Important Factors Influencing Power System Composite Reliability - An Analysis of Brazilian and US Cases.** CIGRE, Aug. 1990.

McReynolds, W. T. et al. **Modified automatic time error control and inadvertent interchange reduction for the WSCC interconnected power systems.** IEEE 90-SM-3947-PWRD, July 1990.

Mittlestadt, W., Taylor, T., Klinger, M., Mechenbier, J., et al. **Voltage Instability Modeling and Solutions as Applied to the Pacific Intertie.** CIGRE, Aug. 1990.

Murarka, Ishwar. **Transformation of pentachlorophenol contamination in soils by geochemical and microbiological treatment.** Electric Power Research Institute, n.d.

Nellis, C. L. et al. **Experience with HVDC contamination monitors in different U.S. locations.** Symposium on High Voltage Engineering, IEEE IRE CIGRE 1989.

———. **Long-term tests of HVDC insulators under natural pollution conditions at the Big Eddy test center.** IEEE Transactions on Power Delivery, vol. 4, no. 1, p. 248, January 1989.

———. **Operating experience of the Pacific HVDC Intertie.** Panel session, IEEE T&D Conference, New Orleans, Louisiana, April 2, 1989.

———. **Results from BPA's test and evaluation program on HVDC insulation.** Canadian Electrical Association conference, March 1987.

Nordstrom, Jerry. **Evaluating relay performance using fault recorder data records.** 1989 Digital Fault Recorder Conference. Also presented: Western Protective Relay Conference, n.d.

Phadke, A. G. **Power system stability prediction and control based on on-line phasor measurement.** Final Summary, Virginia Polytechnic Institute and State University, Blacksburg, Virginia 24061, November 5, 1990.

Pries, R. A. and S. A. Veress. **Photogrammetric evaluation of transmission lines.** Fifth Annual Northwest Conference on Surveying and Mapping, Whistler, British Columbia, June 14-17, 1987.

Pries, R. A. and R. A. Schowengerdt. **Extracting roads from digital images for cartographic products.** Fifth Annual Northwest conference on Surveying and Mapping, Whistler, British Columbia, June 14-17, 1987.

Pries, R. A. et al. **Computer assisted GIS/LIS.** Proceedings: American Society of Photogrammetry and Remote Sensing, Falls Church, Virginia, pp. 1-10, n.d.

Renner, Philip. **A joint utility investigation of unexplained transmission line outages.** EPRI report EL-5735, 1988.

———. **In situ condition tests on service-aged 2400 Amp disconnect switch.** DOBLE Conference, Boston, Massachusetts, April 1989.

Schneider, H. M. **HVDC wall bushing studies.** Final report, RP 3039-1, n.d.

———. **Rain and contamination tests on HVDC wall bushings with and without RTV coatings.** IEEE PES 1990 Summer Power Meeting, 90-SM-393-9-PWRD, 1990.

Schowengerdt, R. A. et al. **Thermal scanner monitoring of conductor temperatures.** Contract No. DE-AM79-87BP65094, Interim report, January 19, 1988, Final report, June 30, 1988.

Silverstein, B. et al. **Bulk system reliability: measurement and indices.** IEEE Working Group on Measurement Indices, IEEE 89-WM-155-3-PWRS, January 1989.

Taylor, C.W., Hauer, J.F., **Supplementary HVDC Controls in a Power System with Parallel AC and DC Transmission: HVDC Controls Proliferation versus Simplicity.** HVDC Colloquium, Recife, Brazil, Aug. 14-15, 1989.

Tonn, Bruce, et al. **Expert systems microwave communications systems alarm processing: a feasibility study.** Oak Ridge National Laboratory, ORNL TM-10429, July 1987.

———. **Bonneville Power Administration communications alarm processor expert system: phase I description.** Oak Ridge National Laboratory, February 1989.

Veress, S. A. **Modifying USGS program K658 (direct constraint analytical aerotriangulation) for BPA's applications.** March 1988.

Veress, S. A. and Hatem Eid. **An evaluation of oblique photogrammetric methods.** Final report, March 1989.

———. **3-D Conductor computation using monoscopic oblique photogrammetry.** Contract No. DE-AM79-87BP65016, January 1990.

Walker, Stel. **Ambient weather model research and development.** Final report, Energy Resources Research Laboratory, Oregon State University, August 31, 1990.

White, J. et al. **Mutual coupling between horizontal earth return conductors using actual routing parameters.** IEEE 90-WM-057-0-PWRD, January 1990.

END

**DATE
FILMED**

11/105191

11