 Rockwell International Atomics International Division		SUPPORTING DOCUMENT		NUMBER N266ER000-001	REV LTR/CHG NO NC <small>SEE SUMMARY OF CHG</small>																						
PROGRAM TITLE Intermediate-Size Inducer Pump (ISIP)				DOCUMENT TYPE Engineering Design Report																							
DOCUMENT TITLE ISIP Design Report				KEY NOUNS Pump, Inducer, Design																							
PREPARED BY/DATE T. J. Boardman <i>T. Boardman</i> 731 LB08				ORIGINAL ISSUE DATE June 15, 1979																							
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO.				GO NO 09280	S/A NO. 23000																						
APPROVALS G. J. Hallinan <i>G. J. Hallinan 6-18-79</i> R. V. Anderson <i>R.V. Anderson 6-15-79</i>				PAGE 1 OF 765 TOTAL PAGES REL. DATE <i>6-19-79 et</i>																							
DISTRIBUTION				SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)																							
<table border="1"> <thead> <tr> <th>* NAME</th> <th>MAIL ADDR</th> </tr> </thead> <tbody> <tr><td>* R. V. Anderson (6)</td><td>LB17</td></tr> <tr><td>* T. J. Boardman (2)</td><td>LB08</td></tr> <tr><td>* H. Marson</td><td>LB24</td></tr> <tr><td>** G. W. Meyers</td><td>LA10</td></tr> <tr><td>** C. Dunn</td><td>LB08</td></tr> <tr><td>** R. Hoshide</td><td>JB05</td></tr> <tr><td>* J. E. Wolf</td><td>055/AB24</td></tr> <tr><td>** E. D. Jackson</td><td>055/AC51</td></tr> <tr><td>** D. E. Davis</td><td>055/AB48</td></tr> <tr><td>** G. J. Hallinan</td><td>LB39</td></tr> </tbody> </table>				* NAME	MAIL ADDR	* R. V. Anderson (6)	LB17	* T. J. Boardman (2)	LB08	* H. Marson	LB24	** G. W. Meyers	LA10	** C. Dunn	LB08	** R. Hoshide	JB05	* J. E. Wolf	055/AB24	** E. D. Jackson	055/AC51	** D. E. Davis	055/AB48	** G. J. Hallinan	LB39	(CHECK ONE BOX ONLY)	
* NAME	MAIL ADDR																										
* R. V. Anderson (6)	LB17																										
* T. J. Boardman (2)	LB08																										
* H. Marson	LB24																										
** G. W. Meyers	LA10																										
** C. Dunn	LB08																										
** R. Hoshide	JB05																										
* J. E. Wolf	055/AB24																										
** E. D. Jackson	055/AC51																										
** D. E. Davis	055/AB48																										
** G. J. Hallinan	LB39																										
				UNCL <input checked="" type="checkbox"/> ERDA <input type="checkbox"/> DOD <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>																						
				CONF <input type="checkbox"/>	DEFENSE INFO <input type="checkbox"/>																						
				SECRET <input type="checkbox"/>																							
				AUTHORIZED CLASSIFIER	DATE																						
ABSTRACT <p>This report summarizes the mechanical, structural, and hydrodynamic design of the Intermediate-Size Inducer Pump (ISIP). The design was performed under Atomics International's DOE Base Technology Program by the Atomics International and Rocketdyne Divisions of Rockwell International. The pump was designed to utilize the FFTF prototype pump frame as a test vehicle to test the inducer, impeller, and diffuser plus necessary adapter hardware under simulated Large-Scale Liquid Metal Fast Breeder Reactor service conditions. The report describes the design requirements including the purpose and objectives, and discusses those design efforts and considerations made to meet the requirements. Included in the report are appendices showing calculative methods and results. Also included are overall assembly and layout drawings plus some details used as illustrations for discussion of the design results and the results of water tests performed on a model of the inducer.</p> <p style="text-align: center; font-size: 1.5em;"><i>A 703-765F76026</i></p>																											
731-D.263 ** Complete document without Appendices.				RESERVED FOR PROPRIETARY/LEGAL NOTICES <p style="text-align: center;">THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE</p> <p>This report was prepared as an account of work sponsored by the United States Government. Neither the U S Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.</p>																							
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																											

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.



DOE/SF/76026--T73

CONTENTS

DE81 026943

	<u>Page</u>
1.0 INTRODUCTION.....	6
1.1 Purpose.....	6
1.2 Objectives.....	6
1.3 Technical Background.....	7
2.0 REQUIREMENTS.....	9
2.1 General.....	9
2.2 Specifications.....	9
2.3 Hydrodynamic Design Requirements.....	10
2.4 Structural Design Requirements.....	10
2.5 Mechanical Design Requirements.....	12
2.6 Materials and Processes.....	15
3.0 PRESENT DESIGN.....	17
3.1 Description.....	17
3.2 Mechanical Design.....	20
3.2.1 Prototype Pump Part Modifications.....	20
3.2.2 Impeller.....	22
3.2.3 Inducer.....	25
3.2.4 Diffuser Assembly.....	27
3.2.5 Tie-Bolt and Shaft Adapter Nut.....	29
3.2.6 Piston Ring Gland.....	31
3.2.7 Rotordynamics.....	34
3.2.8 Vibration.....	34
3.2.9 Clearances and Tolerance Stackup.....	35



CONTENTS (continued)	<u>Page</u>
3.2.9.1 Axial Clearances.....	35
3.2.9.2 Radial Clearances.....	36
3.3 Hydrodynamic Design.....	39
3.3.1 Impeller.....	43
3.3.2 Inducer.....	48
3.3.3 Impeller/Inducer Assembly.....	51
3.3.4 Diffuser.....	52
3.4 Structural Design.....	53
3.4.1 Steady-State Analysis.....	53
3.4.2 Thermal Transient Analysis.....	54
4.0 DESIGN VERIFICATION.....	56
4.1 Reviews.....	56
4.2 Feature Tests.....	57
4.3 Assembly Checks.....	59
5.0 TEST PLANS.....	60
6.0 REFERENCES.....	63



CONTENTS (continued) Page

APPENDICES

Appendix

A.	Calculations.....	65
B.	Design Specification - Pump, Sodium, Inducer, Intermediate-Size (ISIP)(Impeller/Inducer/Diffuser Retrofit).....	84
C.	Recirculating Flow Analyses of Intermediate-Size Inducer Pump.....	131
D.	Customer Design Review Intermediate-Size Inducer Pump.....	149
E.	Rotordynamics of the Intermediate-Size Inducer Pump (ISIP).....	192
F.	Radial Tolerance Stackup - ISIP.....	206
G.	Hydrodynamic Design Report.....	243
H.	Steady-State Structural Analysis (Pump Internals).....	276
I.	Intermediate-Size Inducer Pump - Structural Analysis and Transient Deformation Studies.....	365
J.	Transient Thermal Analysis of ISIP.....	499
K.	Verification of Thermal Model for ISIP (Inter- mediate-Size Inducer Pump).....	607
L.	Model Inducer Water Tunnel Test Report.....	685
M.	Model Inducer Water Tunnel Test Report - Eccentric Operation.....	723

TABLES

Table

1.	Hydrodynamic Design Requirements.....	11
----	---------------------------------------	----



CONTENTS (continued)

Page

FIGURES

Figure

1.	Intermediate-Size Inducer Pump - Interface Control Drawing.....	14
2.	General Assembly (ISIP).....	18
3.	Intermediate-Size Inducer Pump (ISIP) (Design Layout).....	19
4.	Intermediate-Size Inducer Pump, Westinghouse Components (Rework).....	21
5.	Impeller - Intermediate-Size Inducer Pump (AI Sodium Pump).....	23
6.	Inducer - Intermediate-Size Inducer Pump (AI Sodium Pump).....	26
7.	Diffuser Vanes Assembly of Intermediate-Size Inducer Pump (AI Sodium Pump).....	28
8.	Piston Ring - Diffuser Shroud Seal (ISIP).....	32
9.	ISIP - Predicted Performance at 1,110 RPM.....	42



1.0 INTRODUCTION

1.1 PURPOSE

The Intermediate Size Inducer Pump (ISIP) project was initiated to demonstrate, by test, the applicability of axial flow inducers to centrifugal pumps for primary coolant service in large sodium-cooled reactors. This project is the second step in the DOE inducer pump development program which was started at Atomics International with a smaller, "subscale" inducer pump which was designed, fabricated, and tested in water, and is now undergoing endurance tests in sodium.⁽¹⁾ Achievement of program objectives is based on utilizing the combined engineering capabilities of Atomics International (AI), a division of Energy Systems Group (ESG), where there has been considerable sodium, reactor, and ASME Code design experience, and of the Rocketdyne Division which has developed the hydrodynamic technology needed to produce inducers that can operate at low suction pressure (high suction specific speed) while meeting Liquid Metal Fast Breeder Reactor (LMFBR) life requirements.

1.2 OBJECTIVES

The principal project objective, as stated in the Task Proposal/Agreement,⁽²⁾ is the demonstration of the inducer technology through the design of an intermediate-size inducer, impeller, and diffuser system; a system which can be sodium-tested using the Fast Flux Test Facility (FFTF) Prototype Primary Pump as a test vehicle. The design task, therefore, includes hydrodynamic and structural design of the impeller, inducer, and diffuser, plus necessary adapter hardware, to operate inside the existing FFTF Prototype Primary Pump in lieu of the present FFTF Prototype Pump impeller. Because the prototype pump is designated as a plant spare for FFTF, it was necessary that the ISIP design not include any requirements for change or modification of existing hardware that might jeopardize the "spare" status. This



required that the ISIP design be physically and functionally compatible with existing configurations and operating requirements of the prototype pump.

1.3 TECHNICAL BACKGROUND

The advantage of using inducers to permit centrifugal pump operation at lower suction pressures was initially used at Rockwell International, by the Rocketdyne Division, in the development of fuel and oxidizer pumps for rocket engines. In this application, the hydrodynamic goals for inducers were the same as for reactor coolant pumps; i.e., reduction of the suction pressure requirements. However, the design problems were significantly different than those faced in designing a pump for reactor coolant service. For rocket engine applications it was necessary to use extremely high speeds (which result in high centrifugal stresses), in order to reduce the size and weight of the pump to proportions suitable for flight service. Design life requirements were short, measured in minutes or hours, as opposed to life requirements, measured in years for reactor coolant service. Also, for rocket engines, the operating temperatures were very low, in the cryogenic range, and thermal cycles were few, whereas sodium-cooled reactors require temperatures in the order of 1000⁰F and equipment must be capable of withstanding a significant number of thermal cycles over the long (20-40 yr) life.

In the intervening period, between developing inducer pumps for rocket engine application and the present development of similar pumps for reactor coolant service, the Rocketdyne Division developed a commercial line of inducer pumps for use in water jet propulsion systems of hydrofoil craft. The design of those pumps did not have to consider the temperature extremes of cryogenic or reactor service, but had to provide extended life (5,000 to 20,000 hr) free from disabling damage due to



cavitation. In addition to meeting the long life requirements, the physical size of the inducers had to be increased from the small, high-speed units used for rocket engines to sizes slightly larger than that being used for ISIP.

The most recent development in sodium inducer pumps is the Subscale Inducer Pump, a small pump specifically designed for operation with low suction pressures (high suction specific speed) in high temperature sodium. This pump was originally built and tested in water and in sodium under DOE contract. It was later modified and further tested in sodium under contract from ANL.⁽¹⁾ As of this date, the Subscale Inducer Pump has successfully completed a 2,000 hr design point endurance test in sodium at 950⁰F, with a suction pressure margin of 200% above the conventionally defined cavitation point (3% reduction in head due to cavitation). The inducer and impeller showed no signs of cavitation as a result of this test.



2.0 REQUIREMENTS

2.1 GENERAL

Initial design requirements for the Intermediate-Size Inducer Pump (ISIP) were based principally on those requirements originally used for the Fast Flux Test Facility (FFTF) Prototype Primary Pump, and were contained in pump specification HWS-1551.⁽³⁾ Since the ISIP design effort covered only those hydrodynamic elements and adapters used to replace the prototype pump impeller, much of the information given in HWS-1551 was not pertinent to this project. It was assumed that the FFTF Prototype Pump met the requirements of HWS-1551 and that as long as the operating conditions for those parts to be used in the ISIP assembly were not changed, or were not outside of the range of specification requirements, no further analyses of prototype pump parts were needed. Also, because the ISIP was to be used only for testing (as opposed to reactor service), some of the requirements, such as design life and thermal transients, were rewritten in terms of test requirements. These requirements were planned to be identical to those used for Phase B sodium testing of the FFTF Prototype Pump by Energy Technology Engineering Center (ETEC) (then Liquid Metal Engineering Center (LMEC)) in the Sodium Pump Test Facility (SPTF).

2.2 SPECIFICATIONS

In order to permit early initiation of the cooperative design effort to be performed by Atomics International and Rocketdyne, a set of technical requirements⁽⁴⁾ based on HWS-1551 was developed. The set covered the basic hydrodynamic and structural design requirements, including expected limiting values (upper and lower limits) for those parameters which could not be quantified precisely at the time. Subsequently, a more formal and inclusive design specification was written



(Appendix B). This specification was revised once as a result of design review comments.

2.3 HYDRODYNAMIC DESIGN REQUIREMENTS

Hydrodynamic design requirements, with the exception of suction performance, are basically the same as those used in HWS-1551 for the FFTF Prototype Pump. The principal parameters are shown in Table I, which was extracted from the design specification. Added to the original FFTF Prototype Pump requirements was a requirement for operation at design speed, flow, and temperature, with a net positive suction head (NPSH) of 12.8 ft "without cavitation" as defined in the specification. For both the ISIP and the FFTF Prototype Pump "without cavitation" is defined as operating under this condition; the total head across the pump is not reduced by more than 3%, due to reduced suction pressure from its noncavitating (adequate suction pressure) value. The NPSH at this 3% head reduction condition is designated as the required net positive suction head (NPSHR).

The fluid properties on which the hydrodynamic design is based are those contained in ANL 7323⁽¹²⁾ which is the same source document as used for design of the FFTF Prototype Pump. Although later publications of sodium properties may have been available, it was felt that use of these properties, in the design and test evaluation of the ISIP, would provide more consistent comparison between performance characteristics of the ISIP and those of the FFTF Prototype Pump which was tested in the same loop.

2.4 STRUCTURAL DESIGN REQUIREMENTS

The initial structural design requirements given in Reference 4 were established to provide a basis for design initiation. These criteria



TABLE I
HYDRODYNAMIC DESIGN REQUIREMENTS

DESIGN POINT

Flow	14,500 gpm
Head	500 ft
Speed	1,110 rpm
Required NPSH	12.8 ft (max.)

MAXIMUM FLOW POINT
(2-Loop Operation)

Flow	18,000 gpm
Head	375 ft (min.)
Speed	1,110 rpm
Cover Gas Pressure	36 ft Na (min.)
Submergence (Overdischarge centerline)	4 ft (min.)



covered steady state structural design only. The maximum primary membrane stress and the maximum primary membrane plus bending stress were limited to those values which had been previously calculated for the FFTF Prototype Pump impeller (7450 psi and 7730 psi, respectively). Since the ISIP impeller has a similar configuration, it was felt that having the initial design based on these previously successful values would allow a high probability of success in limiting the stresses during thermal transients to values obtained using Code Case N-47 (1592-10) as guidance. These criteria are given in Reference 3.

Unlike many design approaches which require design for specified thermal transients, requirements for structural design of the ISIP components were based on developing a structurally conservative steady state design. This design would have a high probability of meeting the transient requirements, then analyzing the design to determine which, if any, of the specified test thermal transients could not be met within the structural design criteria. The scope of analysis,⁽⁴⁾ was based on limiting the structural analysis effort to elastic, and simplified inelastic, methods to make this determination.

2.5 MECHANICAL DESIGN REQUIREMENTS

Using the FFTF Prototype Pump frame as a test vehicle dictated a number of physical and functional interface requirements. The requirements were to be included in the ISIP design specification in order to avoid the risk of damage to the pump frame. Other mechanical design requirements were based on developing the original concept arrangement, as depicted in the early proposal, into a fully detailed assembly which would be suitable for reactor coolant service.

The following changes from the FFTF Prototype Pump design, in physical interface requirements, were implemented with HEDL concurrence.⁽⁵⁾



- a) Axial Clearance - The prototype pump had 3/4 in. axial clearance above and below the impeller. The ISIP design specification requires 1/2 in. axial clearance above and below the impeller.

- b) Radial Clearance - The prototype pump has .100 in. radial clearance at the lower (front) labyrinth seal. The ISIP design specification requires that the design provide .015 in. minimum radial clearance margin against rubbing under the combined effects of eccentricity, thermal distortion, and .025 in. radial movement at the lower labyrinth seal and the inducer blade tips.

Other physical interfaces with the prototype pump frame are defined on the interface control drawing (ICD) (Figure 1), which includes "as-built" measurements from the prototype pump components, and on the rework drawing which defines modifications in the prototype pump parts made to accommodate ISIP components.

Functionally, design of the ISIP components was to provide for necessary internal circulation, and to avoid excess loads on the prototype pump components. To alleviate the effects of thermal transients, the ISIP design had to maintain the provision for circulation of 50 gpm, up through the hollow lower end of the prototype shaft; to the radial holes above the impeller. The ISIP impeller/inducer design had to provide recirculation capability to maintain the pressure at the lower end of the sodium bearing below 18 psi. This requirement was necessary to assure adequate flow over the lower bearing sill.


The specification requires axial loads to be limited to within 70,000 lb upward thrust and 40,000 lb downward thrust. That is within the thrust bearing capability - rotor weight considered. These axial

NOTES UNLESS OTHERWISE SPECIFIED

1. DIMENSIONS ARE IN INCHES, TOLERANCE ON DECIMALS ± 0.02, ANGLES ± 30', R.2-D-1/2 OR CHAMFER ALL EDGES .03 MAX, FILLET RADIUS .042.02, CHAMFERS 1:1
2. (A) DIMENSIONS ARE REFERENCED FROM DRAWINGS
3. DIMENSIONS MARKED (B) ARE CALCULATED FROM DRAWINGS MARKED (A)

PART NO	REV	DRAWING TITLE	ORGANIZATION
114 E 799	18	SH-RT. FINAL MACHINING PROTOTYPE	WESTINGHOUSE
114 E 814	9	SH-RT. WELDS & MACHINING PROTOTYPE	WESTINGHOUSE
115 E 100	3	SH-RT. MACHINING PROTOTYPE	WESTINGHOUSE
933 D 257	10	DIFFUSER, CASTING & COUGH MACHINING, SEDUM PUMP	WESTINGHOUSE
933 D 972	8	DIFFUSER & TURNING VANE ASSEMBLY, SEDUM PUMP	WESTINGHOUSE
114 E 727	14	ASSEMBLY, WELDING & MACHINING, SEDUM PUMP	WESTINGHOUSE
114 E 939	8	BEARING SUPPORT MACHINING, SEDUM PUMP	WESTINGHOUSE
930 C 265	4	CUBO-VENTILATION PERSYS, SEDUM PUMP	WESTINGHOUSE
689 J 000	1	GENERAL LAYOUT KFTF PROTOTYPE PIPE	WESTINGHOUSE
933 D 704	5	BEARING SUPPORT CASTING	WESTINGHOUSE
933 D 269	9	BELLOWS ASSEMBLY SEDUM PUMP	WESTINGHOUSE
933 D 763	7	TURNING VANE, CASTING & COUGH MACHINING, SEDUM PUMP	WESTINGHOUSE

- AS-BUILT DIMENSIONS:
- (A) DIM. FOR VANE NO. START FROM CL OF SUCTION GOING CW DIRECTION
 - (B) DIM. FOR VANE NO. START FROM CL OF SUCTION GOING CCW DIRECTION
- | | | | |
|-------|-------|-------|-------|
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
| 2.654 | 2.654 | 2.654 | 2.654 |
- N266E000011 0 TOLERANCE STUDY - AXIAL (SKETCH) A.I.
- REVISION OF EXISTING PARTS PER DWG. N266E000017 (A1)



VANE	1	2	3	4
1.791	1.659	1.720	1.666	
1.455	1.516	1.483	1.442	
1.278	1.253	1.205	1.201	
1.341	1.251	1.204	1.218	
1.408	1.355	1.259	1.255	
1.700	1.647	1.647	1.647	
1.458	1.411	1.324	1.328	
1.640	1.619	1.709	1.590	
1.638	1.700	1.690	1.670	
1.600	1.720	1.710	1.710	
1.660	1.720	1.791	1.710	
1.710	1.700	1.821	1.720	
1.720	1.750	1.821	1.720	

Figure 1
INTERFACE CONTROL DRAWING

THIS DOCUMENT MAY NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

RELEASED

DATE	SCALE	DRAWING SIZE	SHEET NO.	TOTAL SHEETS
	1/4"	11" x 17"	14	14



thrust limits must be met under the effect of a 10% difference in static head between the upper (back) and lower (front) shrouds of the impeller; a requirement based on changes in axial thrust which have been noted on many pumps. This includes water tests of the prototype pump when flow is throttled significantly below the design value.

Other mechanical design requirements included provision of methods of venting and draining the ISIP components (these features were already included in the design of the prototype pump), and provision for attachment of lifting and handling tools. The specification anticipated that some new tools or modification of the existing prototype pump tools might be required. Lifting tools were to conform to the requirements of RDT F8-6T⁽⁶⁾ and support stands were to conform to the Uniform Building Code requirements for this region.

2.6 MATERIALS AND PROCESSES

Materials and processes required for use on the ISIP were selected to be compatible with those materials presently in the FFTF Prototype Pump. All forged parts were to be made from Type 304 forgings, as was the prototype pump. Also, like the prototype pump, the impeller was to be fabricated from CF8, the chemically equivalent cast material to 304. Unlike the prototype, threaded fasteners in the ISIP were to be made from ASME SA-638, Grade 660, commercially known as A286. This alloy was chosen because of its reduced tendency to gall against stainless steel and its compatibility with the thermal expansion coefficient of stainless steel. This nickel alloy also has the advantage of a higher strength than Type 304. The piston ring which is used to restrict leakage from the impeller discharge to the inducer inlet, was to be made from a precipitation hardened nickel alloy, ASME SA-637, Grade 718, commercially known as Inconel alloy 718.



The specification also required that the major parts be given a supplemental heat treatment as a part of the fabrication process to develop dimensional stability. The purpose of this requirement was to avoid, or minimize, the effects of material densification during extended exposure to high temperatures. These effects were identified as having contributed to the sodium bearing failure during Phase A testing of the prototype pump.




3.0 PRESENT DESIGN

3.1 DESCRIPTION

The final design of the Intermediate-Size Inducer Pump (ISIP) is shown in Figure 2. This figure was taken from general assembly Drawing N266000032 which is the top level drawing showing all ISIP components. The drawing includes components from the Fast Flux Test Facility (FFTF) Prototype Pump and those new components provided by Rockwell. The material list provides entry to the drawing tree. This permits identification of all lower level drawings of subassemblies and individual components. The ISIP general assembly drawing was produced by modifying a copy of the original FFTF Prototype Pump general assembly Drawing 114E829. Using lines and cross-hatching over information from the prototype pump assembly drawing which does not apply to the ISIP assembly, permits easy identification of those items which were changed for the ISIP configuration. The "find numbers" (equivalent to the prototype pump piece numbers) in the parts list for the new ISIP components start with No. 400. This permits easy distinction from the original piece numbers which end with No. 216.

Detailed information concerning principal dimensions and fits for the ISIP hydrodynamic components is shown in Figure 3 which was taken from the detail layout Drawing N266R000015. Fits and clearances at interfaces with original prototype pump components shown on the layout, are based on design dimensions for the prototype pump parts. Actual fits and clearances may be slightly different when considering the present "as built" dimensions for the prototype pump parts shown in Figure 1. Differences between design dimensions and "as built" dimensions for prototype pump components are probably a result of previously operating the prototype pump at elevated temperatures during sodium tests at the Sodium Pump Test Facility (SPTF). Following the tests,

32 24 31 23 30 22 29 21 28 20 27 19 26 18 25 17 24 16 23 21 20 19 18 17 16 15 14 13 12 11 10 9 8 7 6 5 4 3 2 1



32 24 31 23 30 22 29 21 28 20 27 19 26 18 25 17 24 16 23 21 20 19 18 17 16 15 14 13 12 11 10 9 8 7 6 5 4 3 2 1

1. IDENTIFY PER AGG1010001 TAG WITH PART NUMBER.
 2. CLEAN PER NGO1010001 LEVEL 1.
 3. WELD PER NGO1010001 VISUALLY INSPECT & P.M.I. FOR A.V.I. OF GEARS.
 4. BEND WASHER AS SHOWN IN VIEW TO LOCK BOLT IN PLACE.
 5. LUBRICATE MAIN GEARS USING NEVER-SEEZ
 6. LUBRICATE MAIN GEARS WITH NEVER-SEEZ COMPOUND. NEVER-SEEZ COMPOUND OIL BROADTYPE.

USE PONY MOTOR WITH A GEAR UNIT RATIO OF 10:1 TO
 A-SUPPLIED BY ARD.

GENERAL NOTE:
 1-ENGINEERING APPROVAL MUST BE OBTAINED TO EMPLOY OPEN FLAME
 2-USE TO ADJUST ASSEMBLY/DISASSEMBLY OPERATIONS. REFER TO PART DRAWING
 3-HEATING COMPONENTS DURING DISASSEMBLY OPERATIONS, THE
 COMPONENT PART TEMP IS LIMITED TO 500°F.

U-BREKTEL DWG #A-23991 SUPPLIED BY ARD.
 V-APPLY LUBRICANT SPRINKLY TO DRIVING SURF. INSTALLATION IN GROOVE.
 W-REMOVE EXCESS BUILD-UP WITH CLEAN CLOTH. SO OT DRING APPEARS SHINY.
 X-REMOVE TOOTH. TABLE ON SHEET 2.
 Y-SUPPLIED BY SITE AT ASSEMBLY.
 Z-FURNISHED FROM THE SUPPLIER BY ARD.
 D-LOCK PER SCREW LOCKING CLIP ASSY. DWG. 160A272.
 E-MOUNTING BY SITE IN AMBIENT ENVIRONMENT.
 F-CLASS 1 IDENTIFICATION PER S. 55600.
 G-SEE TORQUE TABLE ON SHEET 2.
 H-APPLY LOCKWIRE PER S. 29261-1.
 I-LOCK PER DWG. 160A 5050.

PART NO.	DESCRIPTION	MATERIAL	QTY
10000010001	DRIVING SHAFT	304 SS	1
10000010002	DRIVING GEAR	304 SS	1
10000010003	DRIVING BEARING	6000	2
10000010004	DRIVING HOUSING	ALUMINUM	1
10000010005	DRIVING FLANGE	304 SS	1
10000010006	DRIVING BOLT	304 SS	1
10000010007	DRIVING WASHER	304 SS	1
10000010008	DRIVING KEY	304 SS	1
10000010009	DRIVING GEAR MESH	304 SS	1
10000010010	DRIVING GEAR MESH	304 SS	1

PART NO.	DESCRIPTION	MATERIAL	QTY
10000010011	DRIVING BEARING	6000	2
10000010012	DRIVING HOUSING	ALUMINUM	1
10000010013	DRIVING FLANGE	304 SS	1
10000010014	DRIVING BOLT	304 SS	1
10000010015	DRIVING WASHER	304 SS	1
10000010016	DRIVING KEY	304 SS	1
10000010017	DRIVING GEAR MESH	304 SS	1
10000010018	DRIVING GEAR MESH	304 SS	1
10000010019	DRIVING GEAR MESH	304 SS	1
10000010020	DRIVING GEAR MESH	304 SS	1


RELEASED
 DIVISION
 DATE

PART NO.	DESCRIPTION	MATERIAL	QTY
10000010021	DRIVING GEAR MESH	304 SS	1
10000010022	DRIVING GEAR MESH	304 SS	1
10000010023	DRIVING GEAR MESH	304 SS	1
10000010024	DRIVING GEAR MESH	304 SS	1
10000010025	DRIVING GEAR MESH	304 SS	1
10000010026	DRIVING GEAR MESH	304 SS	1
10000010027	DRIVING GEAR MESH	304 SS	1
10000010028	DRIVING GEAR MESH	304 SS	1
10000010029	DRIVING GEAR MESH	304 SS	1
10000010030	DRIVING GEAR MESH	304 SS	1

Figure 2

RELEASED
 DIVISION
 DATE

PART NO.	DESCRIPTION	MATERIAL	QTY
10000010031	DRIVING GEAR MESH	304 SS	1
10000010032	DRIVING GEAR MESH	304 SS	1
10000010033	DRIVING GEAR MESH	304 SS	1
10000010034	DRIVING GEAR MESH	304 SS	1
10000010035	DRIVING GEAR MESH	304 SS	1
10000010036	DRIVING GEAR MESH	304 SS	1
10000010037	DRIVING GEAR MESH	304 SS	1
10000010038	DRIVING GEAR MESH	304 SS	1
10000010039	DRIVING GEAR MESH	304 SS	1
10000010040	DRIVING GEAR MESH	304 SS	1



- 1 THIS LAYOUT IS BASED ON WESTINGHOUSE COMPONENTS MODIFIED BY REMOTE PDC DRAWING N266SK000017 (A1)
- 2 INTERFERENCE CONTROL DIMENSIONS PER N266E000002 (A1) TOLERANCE STUDY PER N266SK000017 (A1)
- 3 ORIGIN SYMBOLS OF REFERENCED DRAWINGS:
(A1) ATOMICS INTERNATIONAL
(R1) ROCKETDYNE DIVISION
(R2) WESTINGHOUSE ELECTRIC CORPORATION
- 4 ASSEMBLY AND DISASSEMBLY PER QM 051 00 005, REVISION 2, ADDENDUM 1
- 5 DYNAMIC BALANCE OF ROTATING PARTS PER SPEC N266ST000001 (A1)
- 6 LOCATION OF MATERIAL AVAILABLE FOR MACHINING TO BALANCE A COMPONENT
- 7 PASSAGE FOR H_2 VENTING H_2 DRAINING
- 8 DIMENSION 1117 IS TO BE READ: 1114 TIGHT (INTERFERENCE FIT) 1114 LOOSE (CLEARANCE FIT), FITS ARE GIVEN PER DIAMETER.
- 9 PROVISIONS FOR:
(A) ASSEMBLY
(B) DISASSEMBLY
(C) HANDLING (HOISTING)
(D) TOOLING
- 10 REMOVE IN FINAL ASSEMBLY
- 11 ORIENTATION OF DIFFUSER VANES TO BE ESTABLISHED PER DRAWING N266SK000017 9IN 5, 6 & 7.
- 12 CALCULATED VOLUME OF RESIDUAL SODIUM IN UNGRAINED PROCKETS 48 IN³.
- 13 SYMBOL \oplus INDICATES CENTER OF GRAVITY
- 14 FITS ARE BASED ON ARITHMETIC AVERAGE OF SIZES BY MEASUREMENT OF AS-BUILT COMPONENTS, OTHER FITS ARE BASED ON DRAWING SIZES AND THEIR TOLERANCES.
- 15 PER SPECIFICATION N266E000001 VISUALLY INSPECT 5% MAG FOR EVIDENCE OF CRACKS
- 16 ALL COMPONENTS OF THE ASSEMBLY TO BE CLEANED PER N266A010001, LEVEL 3.
- 17 CONFORM TO THE REQUIREMENTS OF THE SPECIFICATION NO N266ST310001
- 18 LAYOUT PER SPECIFICATION N266ST310001

Figure 3

NO.	DESCRIPTION	DATE	BY	CHKD
1	DESIGN	10/15/54	J. H.
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

Rockwell International Corporation
Atomic International Division
SANTA FE, CALIFORNIA

SCALE: FULL VIEW
SCALE: 2:1 (5:2) (DESIGN LAYOUT)
SCALE: 1:1 (DRAWING SIZE)

SHAFT, FULL LENGTH PROTOTYPE
1/4 E 727 (A)
MATERIAL: TYPE 304 SS (REF)

BEARING SUPPORT MACHINING
1/4 E 932 (A)
MATERIAL: TYPE 304 SS (REF)

HEADCAP SCREEN - 16 PL
1/4 E 939 MOD REF
1/4 E 727 (A)
MATERIAL: TYPE 304 SS (REF)

DIFFUSER VANE ASSY OF SHIP
R0019602 (A)
MATERIAL: TYPE 304 SS

IMPELLER, 151P
R0019601 (A)
MATERIAL: TYPE 304 SS

HEADCAP SCREEN - 24 PL
1/4 E 939 MOD REF
1/4 E 727 (A)
MATERIAL: TYPE 304 SS (REF)


WASHER, TAB LOCK (151P) 6X
N26600024 (A1)
MATERIAL: TYPE 304 SS

BUSHING, 151P
N26600023 (A1)
MATERIAL: INK0 718

PUMP SHAFT INSERT, 151P
N26600022 (A1)
MATERIAL: TYPE 304 SS
SEE VIEW C (2)

TAB, 151P
N26600022 (A1)
MATERIAL: TYPE 304 SS

INDUCER, 151P
R0019603 (A)
MATERIAL: TYPE 304 SS



DIFFUSER VANES RELATION - VIEWING FROM TOP TO BOTTOM
SCALE 1/2

NO.	DESCRIPTION	DATE	BY	CHKD
1	DESIGN	10/15/54	J. H.
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

NO.	DESCRIPTION	DATE	BY	CHKD
1	DESIGN	10/15/54	J. H.
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

RELEASED
DISSEMINATION REPORT



there was evidence of some material densification due to exposure to high temperatures, which could have caused small dimensional changes.

3.2 MECHANICAL DESIGN

Basically, mechanical design of the ISIP is very similar to that of the FFTF Prototype Pump. For the ISIP, the prototype impeller and impeller nut are replaced by the ISIP impeller/inducer assembly, the tie-bolt, and the nut adapter. The ISIP diffuser assembly mounts on the lower side of the prototype bearing support flange and functions both as an adapter-diffuser, between the ISIP impeller outlet and the prototype diffuser inlet, and as a support for the inducer tunnel which is part of the diffuser shroud. A shroud insert is installed into the lower labyrinth seal of the prototype static hydraulics. This insert has a hard-surfaced cylindrical bore against which the piston ring, mounted on the ISIP diffuser shroud, rides to restrict leakage toward the inducer inlet while permitting radial and axial motion as needed to accommodate tolerance stackups, and as might occur during thermal transients.

3.2.1 Prototype Pump Part Modifications

Mounting of the ISIP diffuser assembly onto the prototype bearing support flange and installation of the shroud insert into the prototype static hydraulics required some modification of the bearing support flange and of the static hydraulics. These modifications are shown in Figure 4, taken from N266000017. All of the modification work, except drilling of the two drain holes in the static hydraulics, were to be performed by the Westinghouse-Sunnyvale plant. Design of the modifications was coordinated with HEDL to assure that the changes would not affect the "spare" status of the prototype parts, and with Westinghouse-Sunnyvale to assure that the modifications were within the capability of the existing machine tools.

REVISIONS E022514			
REV	DESCRIPTION	DATE	APPROVED
1	SEE REVISION REQUIRED	7/9/68	[Signature]

NOTES: UNLESS OTHERWISE SPECIFIED ON THIS DRAWING

1. DRAWING INTERPRETATION PER STOPS N0018
2. WESTINGHOUSE DWG NO 114E 939
3. WESTINGHOUSE DWG NO 114E 727
4. MACHINING TO THIS DIMENSION FOR BELLOWS SEAL ONLY; CHIT FOR PISTON RING CONCEPT.
5. ANGLE (A) TO BE DETERMINED BY MEASURING ANGLE BETWEEN SUCTION NOZZLE CENTERLINE AND FIRST DIFFUSER VANE LEADING EDGE CLOCKWISE FROM CENTERLINE WHEN LOOKING DOWN ON STATIC HYDRAULICS.
6. LOCATION OF DIFFUSER PIN HOLE TO BE DETERMINED BY LAYING OUT ANGLE, \pm MINUS 20° , COUNTERCLOCKWISE FROM DONEL PIN (955 B 521 H01) CENTERLINE, WHEN LOOKING AT BOTTOM OF BEARING SUPPORT FLANGE (DONEL PIN IS SAME AS SUCTION NOZZLE).
7. TAPPED HOLES (16 EQUALLY SPACED) TO BE LOCATED WITH DIFFUSER PIN MIDWAY BETWEEN TWO HOLES.
8. CLEAN PER N001A0110001, LEVEL 3.
9. PACKAGE PER N001A016001 LEVEL B.




Figure 4

RELEASED
ENGINEERING DEPT

APPROVED	[Signature]
DATE	7/9/68
BY	[Signature]
CHKD BY	[Signature]
DATE	7/9/68
BY	[Signature]
CHKD BY	[Signature]
DATE	7/9/68
BY	[Signature]
CHKD BY	[Signature]
DATE	7/9/68

THIS DOCUMENT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH BUREAU		118 ASSEMBLY		PAGE FROM 114E 727 601	
THIS DOCUMENT WAS PREPARED AS AN ACCOUNT OF WORK SPONSORED BY THE UNITED STATES GOVERNMENT. NEITHER THE U.S. GOVERNMENT NOR ANY OF ITS EMPLOYEES, NOR ANY OF ITS CONTRACTORS, SUBCONTRACTORS, OR OTHER EMPLOYEES, MAKES ANY WARRANTY, EXPRESS OR IMPLIED, OR ASSUMES ANY LEGAL LIABILITY OR RESPONSIBILITY FOR THE ACCURACY, COMPLETENESS OR USEFULNESS OF ANY INFORMATION, APPARATUS, PRODUCT OR PROCESS DISCLOSED OR REPRESENTS THAT ITS USE WOULD NOT INFRINGE PRIVATELY OWNED RIGHTS.		BY EACH SPO		PAGE FROM 114E 939 H01	
Rockwell International Corporation Atomica International Division		EXEMPT		118 545, 523, 114E 939 H01	
INTERMEDIATE SIZE INDUCER PUMP WESTINGHOUSE COMPONENTS (2 ENDR)		OR BY		P. ENCH 3	
(151P)		CHKD BY		K. J. Co	
N266000017		DATE		7/9/68	
E 09976		BY		[Signature]	
N266000017		DATE		7/9/68	
REV. A		BY		[Signature]	
PAGE 1		DATE		7/9/68	




3.2.2 Impeller

The ISIP impeller, Figure 5, was designed to have the same fit with the prototype pump shaft as the prototype impeller, and the same assembly criteria was to be used, i.e., an interference fit to be achieved by advancing the impeller .025 in. further along the shaft taper than its cold set position. This criteria results in a .0026 in. diametral interference fit in the approximately 8 in. mean diameter of the tapered bore (1/8 in. taper on diameter per foot of length). The taper fit and tolerances permit using hot (180⁰F) water to heat the impeller before mounting to achieve the design interference. The 12 1.25 in. diameter holes through the impeller hub are designed to channel the recirculating internal flow from the upper (back) labyrinth, and from the lower end of the sodium bearing, back to the eye of the impeller. The total 669 gpm flow had to be accommodated while maintaining the pressure between the hub and the bearing no more than 18 psi above suction pressure (see Figure 2 of Appendix C). The pressure criteria was provided by HEDL to assure adequate flow out of the pump hydrostatic bearing pocket, across the lower sill of the pocket.

The impeller design provides additional material at both (upper and lower) ends of the hub and near the tips of the two shrouds for dynamic balancing. Balancing of the impeller and inducer was accomplished under ESG Specification N4007, ⁽¹³⁾ which requires the impeller and inducer to be balanced individually; then an assembly check balance performed after the inducer is mounted on the lower end of the impeller hub. Because the impeller is a sand casting, subject to core shifts during the casting process, it was necessary that a liberal amount of material be available for removal during balancing operations.

Alignment for the inducer, which mounts on the lower end of the impeller hub, is provided by the 5.5007 in. diameter and 8.600 in.

REVISIONS	DATE	BY	DESCRIPTION
1			DESIGNED & DRAWN BY
2			REDESIGNED & REDRAWN
3			EFFECT OF TEST
E.O. 82951			



NOTE: Proprietary Information as defined in the contract with DOE has been removed from this drawing.



RELEASED
ENGINEERING DEPT.

E.O. 82951

Figure 5

1. PRIOR TO MACHINING SETUP EYE DIAMETER [14] FOR BEST AVERAGE CONCENTRICITY AFTER SETUP OF DISCHARGE CENTERLINE FOR MINIMUM RUNOUT. IMPELLER DISCHARGE CENTERLINE TO BE ESTABLISHED PRIOR TO MACHINING BY DETERMINING AVERAGE CENTERLINE LOCATION OF 14 BLADES THEN SCRIBING THE CENTERLINE 0.025 IN LONG ON THE PRESSURE SIDE OF EACH FULL INLET AT THE DISCHARGE END. THIS LINE IS TO BE USED FOR SETUP AND START OF MACHINING [12].
2. COORDINATE DATA FOR BLADE LEADING EDGES ARE SURFACE EXTENSIONS (SECTION SIDE AND PRESSURE SIDE) BEFORE TRIMMING PATTERNS TO FINAL ANGLE (1) SHOWN IN BLENDED VIEW [13] AND BEFORE TAPERING AS SHOWN IN SECTION D-D [15].
3. MACHINING PER PAR 103-008.
4. REMOVE IMPERFECTS FOR DAMAGE HERE.
5. DYNAMICALLY BALANCE TO 20 GRAM-INCHES.
6. ELECTROCHEMICAL ETCH IDENTIFY PER PAR 103-008 INCLUDE HEAT TREAT AND PURCHASE ORDER NO.

005	MAKE THIS WORK		
003	304 CRES SHEET		ASME Y32.10 SP-10 CFB
100	MATERIAL	SIZE	SPECIFICATION

NONE			
NONE			
NOTED			

Rockwell International Corporation
Rockledge Division
Cocoa, Florida 32922
DOC NO. 2132
REV. 1



diameter cylindrical surfaces on the impeller hub, and by the shoulder which is machined perpendicular to the axis of the impeller bore within .0005 in. The 5.5007 in. diameter was designed for an interference fit with the inducer bore. After installation in the ISIP, the upper end of the inducer hub is held against the square shoulder on the impeller by the tie-bolt and nut.

Considerable discussion was given to design of the impeller labyrinth seals. The original labyrinth seals on the prototype pump had a series of annular grooves in the stationary member running in close proximity (0.100) to a cylindrical surface on the impeller. The grooves were 1/8 in. deep and the lands between the grooves had a 1/8 in. pitch (Ref. 7). The nominal radial clearance was .050 in. at the rear (upper) labyrinth, and .100 in. at the front (lower) labyrinth. To minimize leakage through the labyrinth seals, it was decided to combine several features which were not included in the prototype pump. First, a stepped labyrinth design was used to help break up the velocity carry-over effect from fluid leaving one stage of the labyrinth before it reached the next stage. Second, the pitch and groove depth between labyrinth stages was drastically increased from a 0.125 in. depth to 0.5 in., and from a 0.125 in. pitch to 1.25 in. (1.4 in. for the upper labyrinth). Thereby, the path length between lands was increased, and the cross-section area available for velocity dispersion, and associated momentum destruction, was also increased. Third, the form of the land and groove was specially designed to deflect a part of the fluid jet leaving one land down into the pocket, then redirecting it back against the fluid entering that pocket. The intent of this action is to destroy fluid momentum by taking a part of the velocity stream and directing it back against itself. The tooth form of the labyrinth and its effectiveness, particularly for relatively large radial clearances, had been reported in the technical literature referred to in the Engineering responses to the design review report (see Attachment III in Appendix D). Calculations indicated that this labyrinth




design would be more effective in limiting internal leakages than the more conventional straight labyrinth, under the required radial clearances.

3.2.3 Inducer


Mechanical design of the inducer, Figure 6, was concerned principally with the internal surfaces of the bore, where provisions for mounting and for transmitting torque had to be provided. External surfaces of the hub and blade surface coordinates were dictated by hydrodynamic considerations. Blade thicknesses and blade-to-hub fillets were based on compromise between ideal hydrodynamic and structural conditions, with structural given as much dominance as practical, without undue detractions from hydrodynamic performance. Practically, this approach results in the leading edges and outer portions of the blade being controlled almost entirely by hydrodynamic requirements, while the inner portions, including the root, and trailing edges being controlled mostly by structural requirements (exclusive of the general blade shape).

Internal to the hub, the inducer design includes two internal bores at 5.4995 and 8.601 in. diameters, to match the 5.5007 and 8.600 in. diameters on the impeller hub. This arrangement provides for an interference fit at the smaller diameter, near the axial center of the inducer blades, and a close tolerance clearance fit at the upper (back) end of the inducer to react against transverse moments. These moments could occur if pressure distribution around the inducer is not exactly symmetrical. Like the taper fit between the impeller and the shaft, the fit between the inducer and the impeller is designed to permit the use of hot (180°F) water. Hot water is used to heat the inducer before mounting it on the impeller, to achieve the design interference. A 5/8 in. square key transmits torque from the impeller hub to drive the inducer during operation.

DATE	DESCRIPTION	DATE	APPROVED



SECTION A - A
148



TAP DRILL THRU
90° GSK .3125 BOTH ENDS
.3125-18UNJC-2B
4 HOLES EQ SP
[A-B]003 DIA

DRILL .3125-18UNJC-2B
.3125 DIA
.375 DEEP
FAR SIDE 4 HOLES EQ SP
[A-B]003 DIA

NOTE: Proprietary Information
as defined in the contract with
DOE has been removed from this
drawing.

- ① CARBON CC4 MINIMUM
- ② REMOVE MATERIAL FOR BALANCE HERE
- ③ DYNAMICALLY BALANCE TO 20 GRAM-INCHES
- ④ ALL OVER
- ⑤ BASIC BLADE SECTION DATA
- ⑥ ALL R/F/O SURFACES SHALL BLEND SMOOTHLY BETWEEN DEFINED CONTOUR POINTS AND SECTIONS
- ⑦ DEEP ELECTRO-CHEMICAL ETCH IDENTIFY PER RADIO4-CC5
- ⑧ PENETRANT INSPECT PER RAD15-118
- ⑨ INSPECT PER RADIO5-012 CLASS A
- ⑩ FORGE PER VL-S-7190 GRADE C
- 1. ALL FILLET RADII TO BE .060
- 2. MACHINE PER RADIO3-G16

RELEASED
ENGINEERING DEPT.
FORM 722-A 8 NOV 67-4
ED. 86528



Figure 6

③	WELDER	WATER	22.00 +.50 MAX 6.50 +.50	22-S-763
③	WELDER	WATER	SIZE	SPECIFICATION

NO.	REV.	DESCRIPTION	DATE	BY	CHKD.

102602

0019603		
---------	--	--



The internal flange of the inducer has four tapped holes and four clearance holes which are aligned with tapped holes in the impeller hub. The four tapped holes permit the use of jacking screws in removing the inducer from the impeller. The clearance holes permit temporary assembly bolts to be installed, holding the two parts together safely for handling during operations, such as during dynamic balancing. All eight tapped holes (four in the inducer and four in the impeller) provide connection for the lifting tool used to hoist the impeller/inducer assembly during pump assembly.

3.2.4 Diffuser Assembly

The diffuser assembly, Figure 7, serves a number of purposes in adapting the ISIP impeller and inducer to the existing FFTF Prototype Pump parts. First, the diffuser provides structural support for the stationary vanes designed to guide fluid leaving the ISIP impeller to the existing prototype diffuser. Second, the diffuser assembly serves as the stationary member of the upper and lower labyrinth seals for the impeller. Third, the assembly provides structural support for the inducer tunnel. The labyrinth seals are designed to operate with close running tolerances (nom. .050 in.), therefore, the diffuser must maintain concentricity at these locations. The lower end of the diffuser shroud forms the inducer tunnel, a cylindrical bore which, like the labyrinth seals, has a .050 in. running clearance and must be maintained concentric with the rotating element. The diffuser tunnel outside diameter, although stationary, has a .050 nominal clearance with the prototype pump parts, and must be maintained concentric with those parts during normal operation.

The diffuser shroud is designed for an interference fit at its mounting on the diffuser vanes, as are the diffuser vanes designed for an interference fit with the upper labyrinth bore in the prototype pump

REV	DESCRIPTION	DATE
1	ISSUED FOR FABRICATION	10/2/50
2	REDESIGNED FOR 16 HOLES	10/2/50
3	ADDED .6250-11 UNJC-3B	10/2/50
4	AND RELATED DIMENSIONS	10/2/50
5	21-750-10 UNJC 10 3B WAS	10/2/50
6	1.9375 ± .0005 DIA	10/2/50
7	1.1300 DIA WAS 1.000 DIA	10/2/50
8	AND ADDED 1.1300 DIA	10/2/50
9	ADDED .6250-11 UNJC-3B	10/2/50
10	ADDED 1.1300 DIA TO .001	10/2/50
11	ADDED .6250-11 UNJC-3B	10/2/50
12	ADDED .6250-11 UNJC-3B	10/2/50
13	ADDED .6250-11 UNJC-3B	10/2/50
14	ADDED .6250-11 UNJC-3B	10/2/50
15	ADDED .6250-11 UNJC-3B	10/2/50
16	ADDED .6250-11 UNJC-3B	10/2/50
17	ADDED .6250-11 UNJC-3B	10/2/50
18	ADDED .6250-11 UNJC-3B	10/2/50
19	ADDED .6250-11 UNJC-3B	10/2/50
20	ADDED .6250-11 UNJC-3B	10/2/50
21	ADDED .6250-11 UNJC-3B	10/2/50
22	ADDED .6250-11 UNJC-3B	10/2/50
23	ADDED .6250-11 UNJC-3B	10/2/50
24	ADDED .6250-11 UNJC-3B	10/2/50



LIMITED RIGHTS IN PROPRIETARY DATA
 THIS "PROPRIETARY DATA" IS UNDER CONTRACT NO. ET 76-C-80-
 WITH THE DEPARTMENT OF DEFENSE AND IS NOT TO BE USED BY THE
 GOVERNMENT OR THE ASSISTANT SECRETARY FOR RESEARCH AND
 DEVELOPMENT FOR ANY PURPOSES WITHOUT THE PRIOR PERMISSION OF THE
 CONTRACTOR EXCEPT THAT IT MAY BE USED FOR THE PURPOSES OF THE
 GOVERNMENT PROGRAMS FOR THE DEVELOPMENT OF MECHANICAL SYSTEMS
 SIMILAR IN SIZE OR CAPABILITY TO THOSE BEING DEVELOPED UNDER THIS
 CONTRACT PROVIDED THAT THE CONTRACTOR IS TO REMAIN THE SOLE SOURCE
 FOR SUCH PROGRAMS. HOWEVER, THE CONTRACTOR IS TO BE KEPT ADVISED OF
 SUCH PROGRAMS. CONTRACTOR'S OBLIGATION TO THE GOVERNMENT UNDER THIS
 CONTRACT SHALL BE LIMITED TO THE DESIGN AND FABRICATION OF THE
 SPECIFIC PUMP MANUFACTURED BY THE CONTRACTOR UNDER THIS CONTRACT
 AND SHALL NOT BE USED FOR THE DEVELOPMENT OF OTHER PUMPS OR
 COMPONENTS OF OTHER PUMPS. THE CONTRACTOR'S OBLIGATION TO THE
 GOVERNMENT UNDER THIS CONTRACT IS LIMITED TO THE DESIGN AND
 FABRICATION OF THE SPECIFIC PUMP MANUFACTURED BY THE CONTRACTOR
 UNDER THIS CONTRACT AND SHALL NOT BE USED FOR THE DEVELOPMENT OF
 OTHER PUMPS OR COMPONENTS OF OTHER PUMPS. THE CONTRACTOR'S
 OBLIGATION TO THE GOVERNMENT UNDER THIS CONTRACT IS LIMITED TO THE
 DESIGN AND FABRICATION OF THE SPECIFIC PUMP MANUFACTURED BY THE
 CONTRACTOR UNDER THIS CONTRACT AND SHALL NOT BE USED FOR THE
 DEVELOPMENT OF OTHER PUMPS OR COMPONENTS OF OTHER PUMPS.
 THESE RESTRICTIONS DO NOT APPLY TO THE GOVERNMENT'S RIGHTS TO USE
 OR DISCLOSE ANY DATA OBTAINED FROM ANOTHER SOURCE WITHOUT
 RESTRICTION. THIS LEGEND SHALL BE MARKED ON ANY REPRODUCTION
 OF THIS DATA IN WHOLE OR IN PART.


RELEASED
 ENGINEERING DEPT.
 FORM 723-A-2 NOV 6-54

Figure 7

EO 82510

NO.	DESCRIPTION	DATE
003	MAKE FROM NOS	11/2/50
007	MAKE FROM NOS	12/2/50
MCS	3/2 PFG S	11/2/50
MCS	3/2 PFG S	11/2/50
MCS	3/2 PFG S	11/2/50
NO	1 MATERIAL	11/2/50

- 7. ALL OVER
- ⑥ DEEP ELECTROCHEMICAL ETCH IDENTIFY PER RADIO-008 FURNISH AS MATCHED SET
- ④ INSPECT PER RADIO-012 CLASS A
- ③ FORGE PER MIL-S-7190 GRADE C
- 2. ALL FILLET RADII TO BE .060
- 1. MACHINE PER RADIO-016



Redwood International Corporation
 Redwood Division
 Redwood Plant
 Redwood, California
 408-821-2144
 408-821-2145
 408-821-2146
 408-821-2147
 408-821-2148
 408-821-2149
 408-821-2150
 408-821-2151
 408-821-2152
 408-821-2153
 408-821-2154
 408-821-2155
 408-821-2156
 408-821-2157
 408-821-2158
 408-821-2159
 408-821-2160



bearing flange. Both fits are provided with tapped holes to permit use of jacking bolts during disassembly. The interference fits are designed to be accomplished using dry ice (-110°F) to chill the male portion of the fit to a temperature approximately 100°F below ambient temperature.

Mounting the diffuser to the bearing support flange and the diffuser shroud to the diffuser using interference fits reduced the maximum eccentricity at the lower labyrinth and at the inducer tips from what might have been encountered if these parts were fixed to the diffuser shroud of the prototype pump. The .050 in. radial clearance with the prototype pump outside the inducer tunnel, combined with the .050 in. radial clearance inside the inducer tunnel permits the Hanford Engineering Development Laboratory (HEDL) required transverse motion of the prototype pump parts at the lower labyrinth, even under the most adverse tolerance stackup while still adequate margin against rubbing at the inducer blade tips or the lower labyrinth seal. (See Paragraph 3.2.9.2 for a detailed discussion of radial clearances.)

3.2.5 Tie-Bolt and Shaft Adapter Nut

The tie-bolt serves as an extension to the existing prototype pump shaft and as the principal tension member in holding the impeller/inducer assembly on the shaft. The upper end of the tie-bolt connects to the 5 in. thread at the lower end of the shaft (where the shaft nut is installed in the prototype pump design) and provides a 3.75 in. thread at the lower end of the tie-bolt where the shaft adapter nut is installed to clamp the inducer/impeller assembly onto the shaft taper. The hole through the center of the tie-bolt provides passageway for the calculated 50 gpm flow, up through the shaft to a region above the sodium bearing, to control temperature differences during thermal transients. Provision for flow through the shaft was a feature designed into the prototype pump. Despite the slight increase in flow resistance



offered by addition of the tie-bolt, the flow rate is not expected to be affected significantly.

In addition to holding the impeller/inducer on the shaft, the tie-bolt is also part of the puller tool used to remove the impeller/inducer from the shaft during disassembly. For this application, the tie-bolt is unscrewed from the 5 in. thread on the shaft end and the puller tool attached to the 3.75 in. thread on the tie bolt. The pull is against the internal shoulder of the impeller hub. Also, during assembly and disassembly, the modified guide plate which is used to clamp the bearing support flange to the shaft assembly, is connected to the shaft assembly through the 2.75 in. internal thread at the lower end of the tie-bolt.

Material for the tie-bolt is A286 (ASME SA-638, Grade 660), and is used to minimize the risk of thread galling. The thermal expansion coefficient of this material is comparable to that of Type 304 stainless steel, but is slightly lower. Therefore, as the pump temperature rises during service, it is expected that the tension in the tie-bolt will increase. To compensate for this effect, the tightening torque for the shaft nut adapter is specified as 100 ft/lb, instead of the 450 ft/lb used in mounting the prototype impeller on the shaft. This torque is expected to provide adequate tension at the minimum operating temperature (400°F). The impeller/inducer is held in place this way under the influence of axial thrust, while still not causing an overstressed condition due to differential thermal expansion at the maximum temperature of 1050°F. The 13,300 in.-lb hydrodynamic moment on the inducer is reacted at the 5.5 and 8.6 in. diameter turns at the lower end of the impeller hub.

The shaft nut adapter is a sleeve-type nut with an internal hex, which mounts on the 2.75 in. thread of the tie-bolt. The lower end of the nut has six lugs, two of which are lock welded to the lower end of



the inducer hub at assembly (the remaining four lugs are for subsequent assemblies, if required). Lock welding the nut to the inducer hub prevents the nut from turning (relative to the shaft). However, it is not a positive lock against the tie-bolt turning, despite the difference between the 5 in. thread pitch and the 3.75 in. thread pitch (four threads/in. vs eight threads/in.). Therefore, two "L" shaped locking keys are included in the assembly. The keys are installed into keyways at the lower end of the tie-bolt before the nut is installed. Then they are lock welded to the inside of the nut. Since both the nut and keys are Type 304 stainless steel, the lock weld does not involve dissimilar materials.


3.2.6 Piston Ring Gland

The piston ring gland is comprised of a piston ring assembly, Figure 8, installed in a groove in the ISIP diffuser shroud, and the shroud insert which is installed in the prototype pump static hydraulics, as shown in Figure 3. The static hydraulics were modified to accept the shroud insert by machining a controlled tolerance recess (23.450 in. diameter) and mounting seat, and providing six 3/4-in. tapped holes for the mounting bolts as shown in Figure 4. Also, two 1/4-in.-diameter drain holes were provided, to drain the groove which would exist between the outside diameter of the shroud insert and the prototype pump shroud. Concentricity of the shroud insert, within the static hydraulics, is maintained by an interference fit between the shroud insert and the lower labyrinth grooves of the prototype pump. Like the diffuser parts, the interference fit is designed to permit the use of dry ice to cool the insert 100^oF below ambient before installation. Tapped holes are provided in the insert to permit use of jacking bolts at disassembly.

Design of the piston ring gland was based on three basic criteria:

LTR	DESCRIPTION	DATE	APPROVED
-----	-------------	------	----------

N266ER000-001
Page 32



VIEW A
SCALE 3/1

NOTES: UNLESS OTHERWISE SPECIFIED ON THIS DRAWING

1. DRAWING INTERPRETATION PER STONISNADOM
2. SUPPLIER TO IDENTIFY ITEM WITH PART NUMBER AND SOURCE CONTROL DRAWING NUMBER N266E000023-01
3. PACKAGING AND PACKING SHALL BE IN ACCORDANCE WITH SUPPLIER COMMERCIAL PRACTICE AND COMMON CARRIERS REGULATIONS
4. MATERIAL: NICKEL ALLOY ASME SA637 GRADE 718; PRECIPITATION HARDENED CONDITION; DOUBLE VACUUM MELTED
5. FLAT WITH A 21.5 LB WEIGHT PLACED ON THE SIDE FACE
6. ONLY THE ITEM DESCRIBED ON THIS DRAWING, WHEN PROCURED FROM THE SUPPLIER LISTED HEREON IS APPROVED BY ENERGY SYSTEMS GROUP, CANDIGA PARK, CA., FOR USE IN THE APPLICATION SPECIFIED HEREON. A SUBSTITUTE ITEM SHALL NOT BE USED WITHOUT PRIOR APPROVAL BY ENERGY SYSTEMS GROUP OR BY HEDL.

SOURCE CONTROL DRAWING

SOURCE OF SUPPLY		
SCD DASH NUMBER	SUPPLIER	SUPPLIER PART NO
-01	DOVER 20201 COOK AERONAUTIC DIVISION, LOUISVILLE, KY, 40201	AAI-15227

QTY PERD	FIND NO	PART OR IDENTIFYING NO.	NOMENCLATURE OR DESCRIPTION	MATERIAL	DATA: SPECIFICATIONS SIZES, NOTES, VENDORS	LINE NO.
	05					005
	04					004
	1 03	-03	MARCEL SPRING	302 SST	MIL-S-5059C	003
	1 02	-02	PISTON RING	4		002
	01	N266E000023-01	PISTON RING ASSY			001

PARTS LIST

Rockwell International Corporation
Atomics International Division
PISTON RING - DIFFUSER
SHROUD SEAL
(151P)
SIZE C CODE IDENT NO. 09974 DRAWING NO. N266E000023

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES.
TOLERANCES ON:
DECIMALS ANGLES FRACTIONS
XX ± .03 ± 30' ± 1/32
XXX ± .010

DO NOT SCALE PRINT
HOLES NOTED "DRILL"
.013 THRU .040 + .001 - .001
.041 THRU .130 + .002 - .001
.131 THRU .229 + .003 - .001
.230 THRU .500 + .004 - .001
.501 THRU .750 + .005 - .001
.751 THRU 1.000 + .007 - .001
1.001 THRU 2.000 + .010 - .001

DASH NO.	NEXT USING DWG	MODEL
01	N266000015	266

APPLICATION

THIS DOCUMENT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, ERDA

THIS DOCUMENT WAS PREPARED AS AN ACCOUNT OF WORK SPONSORED BY THE UNITED STATES GOVERNMENT. NEITHER THE U.S. GOVERNMENT, NOR ANY OF ITS EMPLOYEES, NOR ANY OF ITS CONTRACTORS, SUBCONTRACTORS, OR THEIR EMPLOYEES, MAKES ANY WARRANTY, EXPRESS OR IMPLIED, OR ASSUMES ANY LEGAL LIABILITY OR RESPONSIBILITY FOR THE ACCURACY, COMPLETENESS OR USEFULNESS OF ANY INFORMATION, APPARATUS, PRODUCT OR PROCESS DISCLOSED, OR REPRESENTS THAT ITS USE WOULD NOT INFRINGE PRIVATELY OWNED RIGHTS.

RELEASED
ENGINEERING DEPT.
FORM 723-P-3 NEW 8-74

N266E000023



- 1) Limiting the leakage through the gland. Eighty-five gpm at 177 psi differential pressure was specified.
- 2) Limiting the axial load against the ISIP diffuser shroud, due to sliding friction, which might occur as a result of relative motion during thermal transients. A friction factor of 0.5 was assumed for this application.
- 3) Avoiding possible "hangup" which might fracture the ring during assembly for the most adverse misalignment conditions. Since this is a blind assembly under heavy load, failure of the ring during assembly might not be identified.

The ring itself was a purchased item with limiting groove dimensions and lead-in taper dimensions provided to the supplier. The supplier's recommendation to use a centering spring under the piston ring simplified the lead-in taper design aim; to prevent the ring from catching on the shroud insert and breaking during pump assembly. The calculated maximum permissible eccentricity between the ring and inducer shroud is .09 in., considering all adverse tolerances. Also included in the supplier's design is an end-hook arrangement to limit expansion of the ring prior to pump assembly.

To reduce the risk of galling, the base of the shroud insert, where the piston ring seats, has a hard-surface overlay (Stellite). The ring is made from a precipitation hardened material, Inconel 718, and has chamfered corners.

Conservative estimates of leakage through the piston ring, considering the effective radial gap to be 1/2 the diametral tolerance of the Shroud Insert, and the axial gap to be 1/2 the required flatness of



the ring, yield a calculated value of 90.9 gpm vs the specified 85 gpm. This calculated estimate also considers no fluid friction losses in the gap, only a 0.5 velocity head entrance loss and a 1.0 velocity head exit loss. The 90.9 gpm estimate was judged sufficiently close to the 85 gpm requirement for acceptance of the ring design (see Appendix A).

3.2.7 Rotordynamics

Rotordynamic analysis of the shaft assembly was performed to assure that substitution of the ISIP impeller/inducer assembly for the original prototype impeller would not result in a critical speed problem during operation. To perform the analysis an analytical "stick" model of the shaft assembly was made. The model was similar to the one in Reference 8 which was used to analyze the prototype rotor assembly. Calculations were also made using a finite element dynamics computer program. Verification of the modeling technique and program operation was done by - first running a model of the prototype shaft in the finite element program - then checking the results against those reported in Reference 8 for the prototype pump. The results of the verification run and the ISIP analysis are reported in Appendix E. The two programs (the program used by Atomics International, and the program used by Westinghouse) for prototype pump design showed close agreement for the verification. The critical speed for the ISIP configuration was slightly higher than that predicted for the prototype pump. Since no critical speed problems were encountered during sodium tests of the prototype pump, it was concluded that shaft critical speed problems would be unlikely in the ISIP.

3.2.8 Vibration

Previous vibration problems had been encountered during sodium testing of the prototype pump; therefore, this was a concern in the ISIP design. The previous problem had been due to excitation by turbulent



vortices which were generated by flow through the upper (back) labyrinth. The vortex shedding frequency resonated in the chamber above the impeller and excited a harmonic of the impeller labyrinth seal. Such occurrences are practically impossible to predict. However, the ISIP design includes changes in configuration which were made in an effort to avoid repetition of the problem. The upper (back) labyrinth ring on the impeller has a tapered cross-section, making it less susceptible to excitation by a single frequency. Calculation of the natural frequencies of the inducer blades and of the impeller did not show frequencies in a range where excitation could be anticipated. (Actual measurement of natural frequencies was specified as part of the preassembly data recording requirements.)

3.2.9 Clearances and Tolerance Stackup

3.2.9.1 Axial Clearances

The ISIP was designed to use basically the same procedures for axial positioning of the impeller, with respect to the diffuser, as the FFTF Prototype Pump. Mounting details for installation of the impeller onto the existing tapered shaft have the same dimensional relationship, including tolerances, between taper bore in the hub and impeller discharge centerline, as the prototype pump. Because the ISIP diffuser is mounted on the bearing support flange and not in the static hydraulics like the prototype, initial axial positioning of the shaft assembly, which involves alignment between the ISIP diffuser inlet centerline and the impeller discharge centerline, can be set and verified more readily than could be on the prototype pump before installing the upper assembly on the static hydraulics.

The ISIP design provides 1/2 in. axial clearance above and below the impeller, as opposed to the 3/4 in. provided in the prototype pump.



The reduction in axial clearance was made to minimize disk friction losses from the impeller shrouds and with HEDL concurrence that 1/2 in. would be acceptable based on the existing shaft, oil bearing, and SP/SC design. The largest differential change in axial length was calculated to be 0.043 in., occurring when the pump speed is suddenly reduced from high speed, with all sodium pumped from the shaft tunnel, to low speed, when sodium suddenly flows back up in the shaft tunnel (see Appendix A).

3.2.9.2 Radial Clearances

The nominal radial clearance at the lower labyrinth seal of the FFTF Prototype Pump impeller was 0.100 in. The nominal radial clearance at the lower labyrinth seal of the ISIP impeller is 0.050 in. The radial clearance at the ISIP inducer blade tips is also 0.050 in. Both the FFTF and ISIP impellers have a 0.050-in. radial clearance at the upper labyrinth seal. Soon after the start of design, AI requested HEDL approval of the 0.050-in. ISIP impeller lower labyrinth seal radial clearance. At that time, the ISIP inducer tunnel and lower labyrinth seal (both a part of the diffuser shroud) were guided by a seal sleeve in the static hydraulics as shown in Figure A-1 of Appendix A. The clearance between the sleeve and the ISIP inducer tunnel was only enough for assembly. In response to the AI request, HEDL stated that at least a 0.065-in. radial clearance would be necessary. This necessary clearance was based on a 0.025-in. allowance for stackup of tolerances, a 0.025-in. allowance for thermal distortion (occurring as lateral motion at the top of the Prototype Pump suction elbow), and a 0.015-in. margin against rubbing.

Re-evaluation of the hydrodynamic design showed that the 0.050-in. inducer blade tip radial clearance was the maximum permissible for proper operation of the ISIP. Therefore, to provide a 0.015-in. margin as requested by HEDL, the ISIP was redesigned to provide the configuration shown in Figure A-2 of Appendix A. This configuration maintains



the 0.050-in. rotating clearances at the ISIP impeller lower labyrinth seal and inducer blade tips. The design introduces an additional 0.050-in. stationary radial gap behind the inducer tunnel (part of the diffuser shroud) and the Prototype Pump static hydraulics. Recirculation flow through this gap is restricted by a piston ring seal which can accommodate more than 0.050 in. radial motion.

Based on this design (Figure A-2), the radial tolerance stackup analyses were performed (Appendix F). These analyses showed, that under the most adverse stackup of tolerances at assembly, a 0.012-in. minimum radial clearance would exist at the inducer blade tips, at room temperature (Condition 5, Dimension J). The corresponding minimum stationary radial gap behind the inducer tunnel would be 0.0255 in. (Condition 5, Dimension O). These were calculated with the shaft bearing journals against opposite sides of the upper (oil) and lower (sodium) bearings. The condition includes the effects of looseness at rabbet fits, perpendicularity, and concentricity for all stationary and rotating parts from the oil bearing to the inducer.

As previously stated, the tolerance stackup analyses assumed contact at opposite sides of the oil and sodium bearings to establish the minimum inducer tip clearance of 0.012 in. In actuality, with the pump operating, the specified minimum sodium bearing film thickness is 0.005 in. (this is continuously monitored during operation). Taking account of the amount of rotor overhang, this translates to an increase of 0.0054 in. on the calculated minimum radial clearance at the inducer tip, providing a calculated minimum clearance of 0.0174 in. (0.012 + 0.0054) during operation. The minimum calculated stationary radial gap behind the diffuser tunnel is not affected by bearing film thickness and remains at 0.0255 in.



The minimum calculated clearances were compared to the required clearance values from HEDL. The HEDL allowance for tolerance stackup was 0.025 in., and this tolerance stackup was accounted for by the stackup analyses which were based on design tolerances for each individual part. The HEDL value for thermal distortion (lateral movement at the top of the suction elbow) was 0.025 in., which can be accommodated by the stationary gap of 0.0255 in. behind the inducer tunnel. The HEDL value for margin against rubbing, after accounting for tolerance stackup and thermal distortion, was 0.015 in., which is met by the calculated minimum clearance at the inducer tip of 0.0174 in.

In addition to considering the foregoing margin requirement provided by HEDL, a more detailed evaluation was made which considers local thermal distortions in addition to the 0.025-in. lateral movement at the top of the suction elbow. Referring to Table 1 of the transient structural analysis and deformation studies (Appendix I), Transient Events E-208 and E-203 cause the greatest reductions in inducer tip clearance (Location E) and inducer tunnel stationary clearance (Location F) due to local distortions. The inducer tip clearance at the Location E is the most critical running clearance on the ISIP rotor.

For Transient E-208, local distortions cause the stationary gap behind the inducer tunnel to increase by 0.0131 in., changing the minimum stationary clearance from 0.0255 in. to 0.0386 in., which is more than the 0.025-in. lateral motion at the top of the suction elbow. At the same time, the minimum inducer tip clearance is reduced by 0.0037 in. from 0.0174 in. to 0.0137 in., which is more than twice the 0.0054-in. allowance at the inducer tip for minimum sodium bearing film thickness. It is, therefore, concluded that no rubbing would occur for this transient at the inducer tips.



For Transient E-203, the minimum stationary gap is reduced by 0.0061 in. from 0.0255 in. to 0.0194 in. A lateral motion of 0.025 in. at the top of the suction elbow could cause a lateral motion of 0.0056 in. (0.025-0.0194) at the inducer tunnel. At the same time, the minimum inducer tip clearance (without lateral motion of the tunnel) is increased by 0.0029 in. from 0.0174 in. to 0.0203 in. Subtracting the 0.0056 in. lateral motion of the inducer tunnel from this minimum clearance leaves a minimum clearance of 0.0147 in., which is also more than twice the 0.0054 in. allowance at the inducer tip for minimum sodium bearing film thickness. Therefore, it is also concluded that for this transient no rubbing would occur at the inducer tips.

NOTE: The minimum clearances utilized above are based on the worst tolerance stackup as calculated from the dimensions of individual parts in the ISIP assembly. The actual stackup as subsequently measured during Assembly Procedures AP-39-PP-036 and AP-39-PP-043 resulted in a 0.037-in. minimum clearance at the inducer tips (versus a calculated 0.012 in.) and a 0.054-in. minimum clearance behind the inducer tunnel (vs a calculated 0.0255 in.).

3.3 HYDRODYNAMIC DESIGN

Hydrodynamic design of the ISIP components was based on meeting the same noncavitating performance requirements as the FFTF Prototype Pump, which were also included in the ISIP design specification (Appendix B). The following is a list of the basic requirements:



Design Point:

Flow	14,500 gpm
Head	500 ft
Speed	1,100 rpm

Maximum Flow Point:

Flow	18,000 gpm
Head	375 ft (minimum)
Speed	1,110 rpm

In addition to the above requirements, the ISIP is also designed to have a required net positive suction head (NPSHR) of not more than 12.8 ft when operating at design flow and speed, and to be capable of operating at 200% margin above the required net positive suction head for 2,000 hours without any visual effect of damage due to cavitation damage. The present margin is defined as:

$$\% \text{ Margin} = \left(\frac{\text{NPSHA}}{\text{NPSHR}} - 1 \right) 100$$

where: NPSHR = Required NPSH
NPSHA = Available NPSH

Refer to Paragraph 2.3 for definition of NPSHR.

Three hydrodynamic elements are included in the ISIP design: impeller, inducer, and diffuser. These elements are to be installed in the impeller cavity of the prototype pump. An existing hydrodynamic element, the prototype pump diffuser, will remain in the pump and its characteristics will also contribute to the overall hydrodynamic performance. The hydrodynamic design process (not unlike other design efforts) was necessarily an iterative one, especially in the early stages, consisting of assuming or selecting certain parameters or



configuration features and calculating their impact and compatibility with other features. This report covers basically the final step, or steps of this process.

Initial steps in the hydrodynamic design effort consisted of sizing the impeller (determining its tip diameter) to verify the feasibility of the conceptual design, which included an intermediate (ISIP) diffuser between the impeller discharge and the prototype pump diffuser inlet, and evaluating the internal recirculation flows to predict actual flow rates through each of the various hydrodynamic elements. The diameter of the inducer was limited to about 19 in. by the existing inlet configuration of the prototype pump (see Figure 2). The outlet diameter of the ISIP diffuser was limited to about 41.75 in. by the inside diameter of the existing prototype diffuser. Calculation of the internal recirculation flows is presented in N266TI000003 (Appendix C). This report shows the internal flows originally calculated for the FFTF Prototype Pump design, and the changes in those flows resulting from the ISIP design. Using these flow rates and the head requirements from the design specification, calculation of the impeller tip diameter was completed. Final, detail hydrodynamic calculations were performed by the Rocketdyne Division using computer programs containing both theoretical and empirical relations developed through design and test of numerous, similar configurations. For detail description of the final hydrodynamic design process and calculated results, see the hydrodynamic design report, Appendix G. This report describes the design criteria and identifies the computer programs used for hydrodynamic analysis. It also includes tables and curves of calculated performance parameters such as overall performance, blade loadings, and internal losses. Figure 9 shows a composite of the expected head, efficiency, and NPSHR characteristics at 1,110 rpm. The following subparagraphs discuss the initial calculations used to establish design feasibility prior to submitting the problem for computer analysis.




FIGURE 9. ISIP - PREDICTED PERFORMANCE AT 1,110 RPM



3.3.1 Impeller

The first step in the impeller design effort was to establish a practical impeller discharge diameter and blade trailing edge configuration which would permit reducing the impeller diameter sufficiently, from that of the prototype impeller, to permit installation of a varied intermediate (ISIP) diffuser between the ISIP impeller discharge and the existing prototype diffuser inlet. The ISIP diffuser was needed to extend the permissible range of flow variation toward the low-flow regime, and to provide better control of clearances between the inducer and the inducer tunnel. Radial tolerance stackup and possible transverse movement of the existing inlet structure in the prototype pump would not permit adequate control of clearances.

Based on an assumed head rise efficiency for the pump (not including efficiency losses due to internal recirculation), the required Euler head (H_e), or head rise for the rotating vane system (impeller plus inducer), was calculated. The impeller tip diameter and blade discharge angle, as determined from this head, is not appreciably affected by the head rise through the inducer in the ISIP configuration.

$$\begin{aligned}
 H_e &= H/\eta_h & \text{where:} & & H &= \text{net head rise through pump (ft)} \\
 &= 500/0.8 & & & \eta_h &= \text{pump head rise efficiency} \\
 H_e &= 625 \text{ ft} & & & & \text{(assumed = 80 percent)} \\
 & & & & H_e &= \text{Euler head of rotating vane} \\
 & & & & & \text{system (ft)}
 \end{aligned}$$

The Euler head is proportional to the product of the impeller tip velocity (U_2) and the tangential component of the absolute fluid velocity leaving the impeller (C_{U2}). With the selected (through design iteration)



tip diameter of 35.4 in. and the specified rotating speed of 1,100 rpm, the tangential fluid velocity component is calculated by use of the Euler equation:

$$H_e = C_{u2} U_2 / g \quad \text{where:} \quad C_{u2} = \text{tang. absolute fluid vel. (ft/sec)}$$

$$g = \text{gravitational constant (ft/sec}^2\text{)}$$

$$\therefore C_{u2} = g H_e / U_2$$

$$U_2 = \text{impeller tip velocity (ft/sec)}$$

$$= (171.4 \text{ based on } 35.4\text{-in. diameter at } 1,110 \text{ rpm})$$

$$= 32.2 (625) / 171.4$$

$$C_{u2} = 117.4 \text{ ft/sec}$$

The prototype pump impeller had a blade tip diameter of 38.6 in. and produced the same net head rise with approximately the same pump head rise efficiency. For this initial calculation, losses were not assumed to vary significantly between the prototype pump and the ISIP pump design; therefore, reduction of the ISIP impeller diameter to 35.4 in. required increasing the head coefficient above that used for the prototype pump impeller design. The methods by which the head coefficient for a radial discharge impeller may be increased have been publicized in various texts on impeller design and become apparent by examination of the discharge velocity triangle and the Euler head equation (refer to impeller blade calculations in Appendix A). These methods principally consist of:

- 1) Increasing the angle of the impeller blade (β_2) in the region of the impeller tip (blade trailing edge).



- 2) Increasing the number of impeller blades to provide better flow guidance, forcing the angle of the relative flow into better conformance with the blade angle in the tip region.

Both of these techniques were used in the design of the ISIP impeller. The blade discharge angle was increased by about ten degrees (approximately from 20° to 30°), and the number of blades at the discharge was increased from six to 10. Five of the 10 blades were designed as partial blades to avoid excessive blockage of through flow area in the eye, due to the total vane thickness. The blade width (B_2) at the ISIP impeller discharge was increased from 2.40 in. to 2.75 in. to match the width at the diffuser inlet (both ISIP and prototype pump diffusers) in an effort to minimize turbulent losses when the fluid travels from one vane system to the next.

Impeller blade calculation results show a blade discharge angle of 31.5° (Appendix A). The calculation method was based on theoretical considerations as presented in the text of Reference 9. The method consists of calculating a correction for the discharge velocity triangle based on the exit geometry using the method derived by Stodola. The Stodola correction was put in the form which includes a coefficient, nominally equal to 1.0 for impellers with vane overlap but for which further modification is available based on published theoretical work by Busemann. Considering the tangential component of the absolute discharge velocity (C_{u2}), necessary to produce the required Euler head (H_e), the "maximum usable" velocity triangle correction (Δv_{SA}) was calculated for various blade discharge angles. These correction values were then compared to calculated corrections (Δv_{SA}) predicted from the theoretical methods in the text. Plotting the results of two, the calculations, with the discharge angle as the independent variable, yields a solution at the intersection of the two curves where the



"maximum usable" correction equals the predicted correction. The solution, although not exact, indicated that the hydrodynamic requirements would result in a practical impeller discharge configuration which could be fabricated, and not be outside the range of experience at Rocketdyne or commercial pump manufacturers.

These initial calculations were based on frictionless flow through the impeller since, at the time, head losses through the pump were lumped under one assumed head-rise efficiency (η_h). Also, the Stodola coefficient, as determined by Busemann, is based on blades with a logarithmic spiral (constant blade angle). The foregoing calculations are approximate, but no refinement was attempted, since the quantitative effects of impeller discharge geometry does not readily lend itself to theoretical analysis. Instead, at Rocketdyne, as at other pump designers, empirical data built up from published information and from the design organization's own past experience is normally relied upon. For the ISIP, detail calculations were made using two company developed computer programs developed through design and test evaluation of numerous impellers.

Initial calculation of the inlet angle for the impeller blades was based on accepting the flow leaving the inducer blade system with a minimum amount of entry losses (see Appendix A). Using an inducer Euler head (H_{ei}), assumed as 12% of the total head rise through the rotor, the tangential component of the absolute velocity leaving the inducer (C_{u2i}) can be calculated from the Euler equation. With the tip diameter limited by the existing prototype pump inlet configuration, the inducer exit hub diameter was first determined using company data from inducers with similar hydrodynamic characteristics. The impeller inlet hub diameter was set equal to the inducer hub outlet diameter, thereby establishing the through flow area and permitting calculation of the meridional approach velocity to the impeller. For initial evaluation, fluid and



blade velocities at the tip, or outer periphery, are the principal concern because they are usually most critical to the design. Subsequent detail calculations considering radial equilibrium and axial velocity distribution for various steam tubes are performed by the computer program to determine impeller inlet blade angle variation between the tip and the hub.

As can be seen from the blade inlet calculations in Appendix A, use of an inducer aids in suppressing cavitation in the impeller, not only by generation of static pressure, but also by providing prewhirl which reduces the relative velocity of the fluid entering the impeller vane system. Proper prediction of this velocity angle and magnitude permits lower entry shock losses for the impeller than would be achievable without an inducer. Results of the calculations show the relative angle of the fluid approaching the blade (β_1) as 28 degrees. To minimize entry losses, the impeller leading edge is set at this angle plus a slight positive correction to account for the increase in meridinal velocity (C_{m1}) due to vane blockage.

It was previously mentioned that the Busemann value for the Stodola correction coefficient was based on blades assumed to have a constant angle (logarithmic spiral). Comparison of the calculated blade inlet angle of 28 degrees (plus a small positive correction) to the discharge angle of 31.5 degrees shows that this was a reasonably accurate assumption for the ISIP impeller.

Final calculations, as presented in the hydrodynamic design report (Table 1 of Appendix G), predict a .9% head margin for the impeller. During conventional development of impeller designs, which include water tests of full-size impellers or scale models, some adjustment in the pump head (either decrease or increase) can be made by decreasing the impeller diameter or underfilling the impeller vane tips. For the ISIP



impeller, no water testing is scheduled, therefore, pump head may be subject to some error due to the lack of opportunity to "fine tune" the impeller discharge geometry on the basis of test results.

3.3.2 Inducer

The inducer is a high specific speed, axial flow runner, characterized by a low head rise, compared to the flow and speed. There is considerably more theoretical and empirical data available for axial flow runners than for radial flow runners, where blade shapes and solidity (length to spacing rates) effects, as applied to the function of generating head, are concerned. However, in addition to the obvious objective of head generation to suppress impeller cavitation, the following two objectives must also be met for inducer applications requiring long life, such as for primary sodium pumps.

- 1) The inducer itself must operate with low suction pressure (low NPSH) without (gross) cavitation, to the extent that head rise in the inducer or in the following impeller would be impaired.
- 2) Any local cavitation, which might occur near the low suction pressure limit must be handled in a way that prevents collapse of cavitation bubbles which would cause material damage on the surface of the inducer or the following impeller.

To achieve the above objectives, Rocketdyne makes heavy use of empirical data compiled from the results of testing previous successful designs. In addition to information from previous designs, a thorough knowledge of how the thermodynamic and transport properties of fluids affect the cavitation problem also had to be developed. Finally,



knowledge of the effects of varying various local details such as clearances, contours, and vane-edge shapes, which might be varied in any one design, had to be developed, specifically in application to the hydrodynamic runner. The procedures for applying this information have largely been put into computer programs to minimize calculative time requirements. Since the problems are seldom straightforward (implicit) many iterations are required for a solution. Also, for any particular design, optimizations, requiring repetition of the iteration process, are also required. (See Appendix G for detail description of the inducer design.)

Achievement of the first objective, performance at low suction pressures, is met through the design of the vane shapes and hub profile. The design must ensure that entry losses are minimized and momentum is imparted to the fluid by the blades in a manner which does not result in pressures low enough to cause cavitation on the low-pressure (suction) side of the blade. Pressure distributions, due to rotational fields and influence of adjacent vanes, are among the design considerations.

The second objective, avoidance of material damage due to local cavitation, involves:

- . Predicting transport paths from the point of generation to the point of collapse in the free stream
- . Predicting possible bubble formation in local areas, such as the blade leading edges, where there are high fluid accelerations with local static reductions
- . Predicting possible bubble formation in clearance areas where there is likely to be high fluid shear rates and flow separation.



The inducer profile is shown in Figure 6, with some of the features resulting from the design effort required to install an inducer in the existing prototype configuration. For the blade tips, the nominal inlet diameter of 19 in. in the prototype pump was reduced to 18.53 in. to provide room for the inducer tunnel (low end of the ISIP diffuser) to extend down into the 19-in. inlet bore of the remachined prototype inlet (see Figure 3). The nominal 0.050-in. radial gap between the inducer blade tips and the bore of the diffuser tunnel was calculated for this blade shape. The purpose of this allowance was to carry any bubbles which might form in flow through the gap, away from the blade surface and into the fluid stream between blades before collapse. The leading edge configuration provides a low loss entry into the vane system, with the blade "rake" imparting slight prewhirl to the fluid before reaching the blade tip leading edge.

The inducer inlet hub diameter was a compromise selection between having optimum hydrodynamic performance and providing adequate area for the 50-gpm through-the-shaft flow to the top of the bearing (see Figures 1 and 2 of Appendix C), plus room for inducer mounting hardware. The increased exit hub diameter provides some increase in head for the hub-side stream tube by virtue of its larger (than the inlet hub) tangential velocity, making a more uniform head profile across the exit radius.

Approximate velocity triangle calculations for the inducer are shown in Appendix A. These figures indicate that the change in blade angle is low, approximately 11 degrees over the length of the blade, making the inducer blades appear somewhat like a constant angle helix. The calculations are approximate, similar to the sizing calculations for the impeller. Actual vane angles and hub profile are performed in detail and optimized with the computer programs, considering local fluid velocities, accelerations, and blade pressure differences. The high



solidity blading permits low local blade loading and avoids the risk of flow separation within the blade system.

3.3.3 Impeller/Inducer Assembly

Two hydrodynamic requirements had been established for the impeller/inducer assembly; these were regarding limits for the hydrodynamic radial and axial thrust loads which have to be supported by the pump bearing. The radial load requirement was a qualitative one, stating that symmetry should be used where feasible to minimize radial loads. The ISIP impeller and diffuser are designed with polar symmetry. The only existing hydrodynamic asymmetry in the ISIP design is in the existing suction elbow. However, through test experience, it is known that hydrodynamic radial loads will occur due to eccentricities resulting from manufacturing and assembly tolerances, bearing characteristics, and flow phenomena. The radial loads due to flow phenomena are most pronounced at low (throttled) flows when flow angles are markedly different from vane angles. In such cases, an asymmetrical flow and pressure distribution pattern is possible. The estimated maximum radial thrust for the impeller given in Appendix G is 800 lb. For the inducer there is an estimated transverse moment (normal to the shaft axis), due to asymmetrical axial pressure gradients of 13,300 in.-lb. If acting in the same line, the combined radial load at the sodium bearing could be 984 lb (see Appendix A).

Control of axial thrust generated by the impeller/inducer assembly is achieved by sizing the labyrinth seals to provide thrust within the specification limits. Inputs for the thrust calculations include momentum change through the assembly (axial components only), radial pressure distribution along the lower (front) and upper (back) shrouds, and the radial pressure distribution between the upper (back) labyrinth and the shaft. For configurations such as the shroud, an assumption



that the fluid rotates at about half the angular velocity of the impeller is usually adequate; for other configurations, such as between the upper labyrinth and shaft where the rotating surface area is relatively large compared to the stationary area, higher fluid rotational velocities are justified for use in the calculations.

3.3.4 Diffuser

With a new pump design, one diffuser would normally be considered adequate for conversion of impeller discharge velocity into pressure. However, for the ISIP, being installed into an existing configuration, there were two considerations as to why the intermediate (ISIP) diffuser was included in the hydrodynamic design: hydrodynamic performance at low (throttled) flow conditions, and structural support at the inducer tunnel.

Performance tests of the Westinghouse Prototype Pump (with its existing diffuser) showed unstable, and high, radial loads when the discharge flow was throttled below about 80% of its design value at constant speed ($Q/N \cong 11$). The result was evidenced in the performance of the hydrostatic sodium bearing during which the position of the journal within the bearing would start to vary, both in angle from a fixed reference and offset from the bearing center, until the minimum film thickness would start to decrease below *minimum permissible operating* value, which was 25% of the available radial clearance, approximately 0.005 in.. Rocketdyne attributed this instability to flow separation (similar to stalling) in the curved diffusion passageways of the prototype diffuser when the inlet flow angle was changed from its design value by throttling. In an effort to permit a wider range of operation, the ISIP diffuser was designed to provide fluid flow to the prototype diffuser at a nearly constant angle. Not having curved diffusion passageways, the ISIP diffuser is expected to be less sensitive to variations of the inlet flow angle which occur during throttling.



The structure that supports the lower labyrinth seal of the prototype pump permits too much lateral motion to use for support of the diffuser tunnel.

Proper operation of the inducer requires that the inducer blade tip-to-inducer tunnel bore radial clearance be maintained at .050 in. (nominal) within close tolerance. Therefore, the inducer tunnel was designed as part of the ISIP diffuser shroud which is supported from the pump bearing support structure through the 11 ISIP diffuser vanes. This mechanical arrangement permitted maintaining the blade radial clearance independent of motion at the prototype lower labyrinth. Otherwise, attaching the diffuser tunnel to the stationary member of the prototype lower labyrinth would have required a greater clearance, as evidenced by the 0.100 in. radial clearance for the prototype lower labyrinth as opposed to the 0.050 in. radial in the upper labyrinth, which is a part of the bearing support flange (see 2.9.3 for discussion of radial clearances).

The ISIP diffuser has 11 vanes, as has the prototype diffuser. The vanes are installed so the wake from the trailing edge of the ISIP diffuser vanes will feed into the middle of the channels of the prototype diffuser throats. The staggering of vanes was chosen to minimize the potential for boundary layer buildup through the prototype diffuser passageways. Like the ISIP impeller, the width of the ISIP diffuser was maintained equal to the prototype diffuser inlet width (2.75 in.) to minimize flow losses.

3.4 STRUCTURAL DESIGN

3.4.1 Steady-State Analysis

Analyses of the structural integrity of ISIP components were performed in two parts. The first part was the steady-state structural



analysis based on steady-state operation at design temperature. At the time of the steady-state analysis, the design temperature was specified as 1050⁰F, and the structural design criteria were those given in the technical requirements document (Ref. 4). The work was performed using computer models of the components as shown in the design layout drawing (Figure 3). Other input data included the mechanical loadings due to pressure distributions around the various components. The data were based on results from the hydrodynamic analysis, centrifugal forces due to rotation, and assembly loads resulting from shrink fits. The impeller-to-shaft fit was the most intensive in this category. The results are reported in the steady-state stress report of Appendix H. The results show that the steady-state design criteria are met. It should be noted that in view of these results, the reported margins are with respect to the design criteria of Reference 4 which also have margin included to allow for additional stresses to be imposed during thermal transients. For hydrodynamic loadings resulting from other than design point operation, the steady-state design criteria could be relaxed some to reduce the margins since all thermal transients are scheduled to be run at design speed and flow. No effort was made to revise the steady-state structural analysis and calculated stress margins after the specified test temperature was reduced from 1050⁰F to 950⁰F, since the effect was to increase the allowable stresses by about 15%, which would have increased the calculated margins above already acceptable values.

3.4.2 Thermal Transient Analysis

Structural response of the ISIP during thermal transients was analyzed by first calculating the temperature distribution throughout the lower end of the structure, which would occur during the test thermal transients; then, on the basis of selecting most adverse temperature distributions, calculating the resulting thermal stresses. The calculated temperature distributions were also used to calculate thermal distortions which affect internal fits and running clearances.



Results of the thermal stress and distortion calculations are given in Appendix I. These are based on the temperature distortions calculated in Appendix J. In order to verify the adequacy of the ISIP thermal model, it was first used to calculate temperatures from the previous prototype pump tests, using actual test input temperatures. The calculated temperatures were then compared to temperatures measured during the tests. The results of this verification study is given in Appendix K.

In addition to transient structural analysis of the ISIP components, an investigation of the adjacent, existing prototype components was made; particularly of the bearing support flange. The investigation was made to determine whether they would be subjected to more severe transient conditions during ISIP tests, than they had previously withstood successfully during transient tests of the prototype pump, and for which they had been previously analyzed. The results, as shown in Appendix I, show that the prototype pump parts will not be subjected to more severe conditions during ISIP tests than were encountered during prototype pump tests. Therefore, no further structural evaluation was made.



4.0 DESIGN VERIFICATION

Final verification of the ISIP design will be through meeting the hydrodynamic and cavitation performance criteria of the specification, as evidenced by sodium test results and post-test inspection. To gain confidence that the ISIP will meet these ultimate objectives, a number of checks were made during the design and fabrication process. These checks can be divided into three categories: reviews, feature tests, and assembly checks.

4.1 REVIEWS

Due to the developmental nature of the ISIP project, the design was subject to continuous review, generally informal, throughout its progress. In addition to this continuous surveillance, three more structured reviews were held, the last of which included customer participation. For the structured reviews, a review board was selected from persons within the Energy Systems Group and the Rocketdyne Division. Those chosen are knowledgeable in specific areas of design, fabrication, and testing, and if possible, have not had part in generating the information to be reviewed.

The initial review was held on December 8, 1977, for the purpose of determining the adequacy of the conceptual design layout drawing and technical requirements. This review was designated as an "Engineering Review" since the board's function was to provide recommendations and questions for consideration as the design progressed. No engineering response to these recommendations and questions was required.

The second review was held on April 10, 1978, and designated as a "Preliminary Design Review." Its purpose was to review the preliminary design, as represented by the design layout drawing, and the pump specification. The review also served to define those items for which



additional work was required prior to the final.(customer) design review to be held before fabrication.

The third review was held on May 10, 1978 and was designated as a "Customer Design Review." The review board included members from Argonne National Laboratory (ANL), who represented the interests of the customer (DOE), and from Hanford Engineering Development Laboratory (HEDL), who represented the test vehicle owner. The Rockwell members included persons skilled in the areas of materials, structural and thermal analyses, hydrodynamics, mechanical design, test, quality assurance, and manufacturing. The design layout drawing and pump specifications were reviewed along with supporting documentation, including material specifications and analytical reports. The review resulted in a number of action items and recommendations which were subsequently resolved with the board members by the Engineering Department. A copy of the completed review report is included as Appendix D. The issue shown (Change No. 1) includes a statement, on the cover page, to the effect that all action items were answered satisfactorily, and is signed by the chairman and the administrator of the review board. Final release of the layout drawing, Figure 3, includes a decal adjacent to the title block with approval signatures by the review board members.

An additional review to be performed is the test readiness review, which will be held approximately one week prior to rotation. The purpose of this review is to verify that both the pump assembly and the test facility are ready for the initiation of testing.

4.2 FEATURE TESTS

Feature tests are used to verify that specific design features will perform as expected, prior to the completion of the pump assembly. For the ISIP, one feature test was performed. This was a test series to



verify that hydrodynamic design of the inducer was adequate. These tests were run on a 6-in. diameter scale model of the inducer in the water tunnel test loop at the Rocketdyne Division, where the inducer was designed and fabricated. The tests consisted of measuring the cavitation performance (variation of inducer head with net positive suction head) of the model inducer in water, and running simulated life tests to assess the capability for long-term operation in sodium at 200% NPSH margin without cavitation damage. Model tests were run ranging from 80% to 130% of the design flow, with NPSH margins from zero percent to 258%. A surface coating of "Magic Marker Type A" ink, as was used for previous model tests of the subscale inducer, was applied to the blades for the simulated life tests. The life tests were evaluated under the assumption that if dye removal occurs as a result of cavitation effects during water tests, there is almost a certainty that cavitation effects will eventually occur during operation in sodium under similar conditions. The converse is also assumed. The tests were run for both concentric and eccentric positioning of the inducer tunnel. Test results, as reported in Appendices L and M, show that the inducer has good life expectancy with respect to the design requirements when operating at rated condition (14,500 gpm, 1,110 rpm, 950⁰F) with 200% NPSH margin.

NOTE: Due to the proprietary nature of some information contained in the original issue of Appendices L and M, those pages containing proprietary information (i.e., inducer blade surface coordinates, inducer leading edge trim, inducer trailing edge trim, and impeller leading edge trim) have been deleted from the appendices.



4.3 ASSEMBLY CHECKS

Assembly checks verify the design, manufacturing, and often a portion of the assembly procedures with respect to fits, clearances, and tolerances. Those checks are over and above the normal dimensional inspection, and generally relate to functionability. For the ISIP, four assembly checks were included. The first was to verify that the 1-in. total axial clearance between the impeller and diffuser shroud was actually provided prior to pump assembly. Measurements made prior to assembly, using the actual parts, showed that 0.999-in. clearance was available. The second assembly check was to verify that the fits and lead-in tapers of the design were adequate to align the diffuser shroud to the static hydraulics, without interference or damage to the thin lower end of the diffuser shroud. That check was also to verify that the piston ring would compress without damage during assembly of the upper internals (SP/SC sodium bearing assembly, oil bearing assembly, and shaft assembly) to the static hydraulics. The ring cannot be seen as it starts into the static hydraulics, nor is there any "feel" due to the weight of the upper internals (approximately 45 tons). The initial check, using the diffuser assembly mounted on the bearing support flange, showed no problem with piston ring compression or diffuser shroud alignment.

The third assembly check was the shaft alignment check, designed to verify that assembly of the upper internals had been accomplished satisfactorily within the calculated tolerance stackup limits. Measurements taken of the inducer blade-to-inducer tunnel shroud clearance showed a minimum measured clearance of .037 in. vs a calculated worst condition of .012 in. (Appendix F). Radial eccentricity of the inducer with respect to the axis of the shaft journal bearings was .005 in. vs a **calculated maximum value of .007 in.**, and eccentricity of the diffuser shroud around the inducer was .003 in. vs a calculated maximum value of .0075 in.



5.0 TEST PLANS

Testing of the Intermediate-Size Inducer Pump (ISIP) is to be performed in the Sodium Pump Test Facility (SPTF) at the Energy Technology Engineering Center (ETEC) where sodium tests were run on the Fast Flux Test Facility (FFTF) Prototype Pump. The prototype pump tank, which will also be used for the ISIP, is still installed in the SPTF test loop. Pump assembly and disassembly, also considered a part of testing, is to be performed by ETEC in the Component Handling and Cleaning Facility (CHCF) which is adjacent to the SPTF. Special tools required for assembly will be principally the same tools as used for assembling the prototype pump. Some modifications of the prototype tools and new tools specially designed to fit ISIP components were provided by Atomics International.

As originally planned, testing of the ISIP in SPTF would repeat most of the Phase B tests previously performed on the prototype pump with basically the same instrumentation. In addition to utilizing existing facilities, this approach has the advantage of permitting comparative evaluation of two different types of pumps, one with an inducer and one without, without introducing questions of test setup or facility differences when evaluating the results.

An Approval-in-Principle (AIP) was prepared and submitted to Department of Energy for approval of the tests to be run by ETEC (Ref. 10). Next, a Request for Test (RFT) was prepared (Ref. 11) giving detail requirements for tests to be performed in the ISIP. In addition to the tests previously performed on the FFTF Prototype Pump during Phase B tests at SPTF, the RFT also included an interim disassembly and inspection, to be performed after determining NPSH requirements at various flows. These tests were to be followed by a 2000 hr design point endurance test at 200% NPSH margin, then a 300 hr off-design



endurance test to be run at runout loop impedance but reduced pump speed to match the design flow, and finally the series of thermal transient tests which had been run on the FFTF prototype pump.

The NPSH value corresponding to 200% margin would be based on the measurement NPSH required at design flow and speed (14,500 gpm and 1,110 rpm) to limit the overall head drop, due to cavitation, to 3%. For the off-design endurance test, the NPSH would remain the same as for the 200% margin at design condition, but the flow impedance of the test loop would be decreased to that defined by the runout flow condition (18,000 gpm at 1,110 rpm). The pump speed would be decreased to 894 rpm to maintain the 14,500 gpm flow rate. Based on results from water tests of an inducer model, the NPSH margin for this off-design condition is expected to be approximately 89%.

The Request for Test was subsequently revised to delete those tests which, although important for the FFTF Prototype Pump, would add little information concerning the ISIP design. Tests deleted included the one-hour NPSH demonstration test which was based on FFTF plant requirements, the 8-hr post NPSH test endurance run which would be covered by the 2000-hr endurance run, two low-rate (0.4⁰F/sec) thermal transients which would retest the prototype pump structure but not the ISIP components, and one up transient which was basically a repeat of a similar transient at lower temperatures. Also deleted was the interim disassembly and inspection. The maximum test temperature was reduced from 1050⁰F to 950⁰F which obviated those tests designed to monitor pump operation from 950⁰F to 1050⁰F, and those 1050⁰F tests which were a repeat of the 950⁰F tests. When the test request was originally written, water test results of the ISIP inducer model were not yet available. These results later showed that inducer performance in the specified operating range was expected to be very good (see Appendices L and M). Test results from the subscale inducer model also indicated that the water test results



were valid for predicting good suction performance in sodium, as later confirmed by sodium tests of that pump. These test results provided the confidence level needed for the AI recommendation to delete the interim disassembly and inspection from the ISIP test plans.



6.0 REFERENCES

1. ANL Contract 31-109-38-4473, "Subscale Inducer Pump Prototype Update"
2. ESG-DOE-13265, "Task Proposal/Agreement," SA033, dated March 15, 1979
3. HWS-1551, Rev. 1, "Specification - LMFBR Low-Capacity Prototype Pump and FFTF Primary Pump," dated January 1974, including Modifications to RDT-E3-2T dated January 1974 and Addenda through 1P dated May 24, 1977
4. N266TI000001, "Intermediate-Size Inducer Pump Technical Requirements," dated January 20, 1978
5. HEDL Letter 7850652 dated February 10, 1978 (1906AT), W. J. McShane (HEDL) to Director, FFTF-PO, "HEDL Approval of AI ISI Bearing Drain Methodology and Labyrinth Clearances.
6. RDT F 8-6T, "Hoisting and Rigging of Critical Components and Related Equipment"
7. Westinghouse Drawing 160A243, "Standard Labyrinth Seal Grooves"
8. EM4708, "FFTF Primary Pump Rotor Dynamics Analysis," by L. C. McNutt, February 9, 1977 - Westinghouse Electric Corp., Electro-Mechanical Division, Cheswick, Pa.
9. "Fluid Mechanics of Turbomachinery," by George F. Wislicenas; 2nd Ed., Vol. I, Dover Publications Inc., N.Y., N.Y., 1965
10. AI Letter 78AT-2187, R. V. Anderson (AI) to Director, DOE-SAN "Intermediate-Size Inducer Pump (ISIP), Revised Request for Approval-In-Principle (AIP)," dated March 7, 1978
11. N266RFT000001, "Sodium Testing of Intermediate-Size Inducer Pump in SPTF at ETEC" by J. O. Pfouts
12. ANL-7323, "Thermophysical Properties of Sodium," by G. H. Golden and J. V. Tokar, Argonne National Laboratory, Argonne, Illinois, August 1967
13. N40007, "Intermediate-Size Inducer Pump (ISIP) Impeller/Inducer Dynamic Balance," October 9, 1978



APPENDICES

<u>Appendix</u>	<u>Page</u>
A. Calculations.....	65
B. Design Specification - Pump, Sodium, Inducer, Intermediate-Size (ISIP)(Impeller/Inducer/Diffuser Retrofit).....	84
C. Recirculating Flow Analyses of Intermediate-Size Inducer Pump.....	131
D. Customer Design Review Intermediate-Size Inducer Pump.....	149
E. Rotordynamics of the Intermediate-Size Inducer Pump (ISIP).....	192
F. Radial Tolerance Stackup - ISIP.....	206
G. Hydrodynamic Design Report.....	243
H. Steady-State Structural Analysis (Pump Internals).....	276
I. Intermediate-Size Inducer Pump - Structural Analysis and Transient Deformation Studies.....	365
J. Transient Thermal Analysis of ISIP.....	499
K. Verification of Thermal Model for ISIP (Intermediate-Size Inducer Pump).....	607
L. Model Inducer Water Tunnel Test Report.....	685
M. Model Inducer Water Tunnel Test Report - Eccentric Operation.....	723




APPENDIX A

	<u>Page</u>
CALCULATIONS	
Radial Clearances	66
Piston Ring Leakage Estimate	69
Impeller Blade Calculations	72
Inducer Blade Calculations	76
Radial Loads on Sodium Bearing	79
Axial Motion of Impeller with Respect to Diffuser	81



RADIAL CLEARANCES



DIFFUSER SHROUD

IMPELLER

DIFFUSER

SEAL SLEEVE & BELLOWS

*.050" Running Clearance
(Ref. 3)*

Assembly Clearance

.050"

*Prototype Lower
Labyrinth*

INDUCER

N266ER000-001
Page 67

TIE BAR

SHAFT NUT

Figure A-1
Radial Clearances for Initial Design






Figure A-2
 Radial Clearances for Final Design



PISTON RING LEAKAGE ESTIMATE

PREPARED BY: <i>JFB</i>	 Rockwell International Energy Systems Group	70
CHECKED BY:		PAGE NO. OF N266ER000-001
DATE: 12/14/78	ISIP - Estimate of Leakage Past Piston Ring	REPORT NO.
		MODEL NO. 266



LEAKAGE ESTIMATE

- ASSUMPTIONS: ① Head across piston ring = head across pump (= 500 ft)
 ② Radial gap equivalent to radial tolerance of Insert
 ③ Zero fluid friction in gap, $1\frac{1}{2}$ vel. hd. entrance plus exit loss

A. RADIAL GAP

(δ_d) Diametral tolerance

$$\delta_d = .003" \quad \text{Ref. N266000012}$$

(δ_r) Radial tolerance

$$\delta_r = \delta_d / 2 = .003 / 2 = .0015"$$

(D) Seal diameter

$$D = 21.500" \text{ (nom.)}$$

(A_r) Area of radial gap

$$A_r = \pi D \delta_r = \pi (21.5)(.0015) = 0.101 \text{ in}^2 \quad \text{Assumption ②}$$

(V_m) Maximum velocity thru gap

$$1.5 \frac{V_m^2}{2g} = H \quad \text{Assumption ③}$$

$$V_m = \sqrt{2gH / 1.5} = \sqrt{2(32.2)(500) / 1.5} \quad \text{Assumption ①}$$


$$V_m = 146 \text{ ft/sec}$$

(Q_m) Maximum flow thru gap

$$Q_m = A_r V_m / .321 \quad \text{Where .321 = Conversion factor for in}^2, \text{ ft/sec, gpm}$$


$$(.101)(146) / .321$$

$$Q_m = 46.24 \text{ gpm}$$

PREPARED BY: <i>JFB</i>	 Rockwell International Energy Systems Group	71
CHECKED BY:		PAGE NO. _____ OF _____
DATE: 12/14/78	ISIP - Piston Ring Leakage (Cont'd) Estimate	REPORT NO. N266ER000-001
		MODEL NO. 266

B. AXIAL GAP

ASSUMPTIONS : ④ Axial gap equivalent to 1/2 piston ring flatness



(D_o) Outer diameter of seal

$$D_o = 21.35''$$

Ref. R0019602

(W) Width of seal

$$W = 0.560''$$

Ref. N266E000023

(D_i) Inner diameter of seal

$$D_i = 21.35 - 2(0.560) = 20.23''$$

(S_a) Equivalent axial gap

$$S_a = .003/2 = .0015''$$

Assumption ④

Ref. N266E000023

(\bar{D}) Root mean square dia. (for evaluating V^2 pct.)

$$\bar{D} = \sqrt{\frac{21.35^2 + 20.23^2}{2}} = 20.79''$$

(A_a) Area of axial gap

$$A_a = \pi \bar{D} S_a = \pi (20.79)(.0015) = 0.979 \text{ in}^2$$

(V_{m2}) Maximum Velocity thru gap

$$V_{m2} = \sqrt{2gH/1.5} = 146 \text{ ft/sec}$$

Assumptions ③ & ④

(Q_{m2}) Maximum flow thru gap

$$Q_{m2} = A_a V_{m2} / 1.321 = 0.979(146) / 1.321$$

$$Q_{m2} = 44.7 \text{ gpm}$$


(Q) Total flow thru piston ring seal

$$Q = Q_{m1} + Q_{m2} = 46.24 + 44.7 = 90.9 \text{ gpm}$$


Considering the conservative assumptions concerning gap and flow losses, the calculated 90.9 gpm is close enough to the specified 80 gpm to accept the piston ring design



IMPELLER BLADE CALCULATIONS

PREPARED BY: <i>JMB</i>		73
CHECKED BY:		PAGE NO. OF
DATE: 4/9/75	ISIP - Impeller Blade Calculations (Initial Estimate)	N266ER000-001 REPORT NO.
		MODEL NO.

Ref. "Fluid Mechanics of Turbomachinery" by G.F. Wislicenas



- (Q) Impeller flow $Q = 15,917 \text{ gpm}$ (See Appendix)
 (D_2) Impeller tip diameter $D_2 = 35.4 \text{ in}$
 (B_2) Impeller tip width $B_2 = 2.75 \text{ in}$
 (N) Rotating speed $N = 1110 \text{ rpm}$
 (z) No. of blades $z = 10$
 (H) Required head $H = 500 \text{ ft}$
 (η_h) Head rise efficiency (assumed) $\eta_h = 80 \text{ percent}$

(H_e) Euler head

$$H_e = H / \eta_h = 500 / 0.8$$

$$H_e = 625 \text{ ft}$$

(U_2) Impeller tip velocity

$$U_2 = \pi D_2 N / 720 = \pi (35.4) / 720$$

$$U_2 = 171.4 \text{ ft/sec}$$

(C_{u2}) Tangential absolute exit velocity (required)

$$C_{u2} = g H_e / U_2 = 32.2 (625) / 171.4$$

$$C_{u2} = 117.4 \text{ ft/sec}$$

(C_{m2}) Thru flow velocity (0.85 vane thickness blocking factor assumed)

$$C_{m2} = 0.321 Q / 0.85 \pi D_2 B_2 = 0.321 (15917) / 0.85 \pi (35.4) (2.75)$$

$$C_{m2} = 19.6 \text{ ft/sec}$$

BLADE DISCHARGE ANGLE CALCULATION

Parameters for 10 blade impeller

(d') Discharge throat height

$$d' = \frac{\pi D_2}{3} \sin \beta_2^* \quad \text{Ref. Sec. 52}$$

$$d' = \frac{\pi (35.4)}{10} \sin \beta_2^* \text{ in}$$

$\beta_2^* \rightarrow$ 20° 30° 40° 50° 60°

$d' \rightarrow$ 3.80 5.56 7.14 8.52 9.63

(A_{t2}) Discharge throat area

$$A_{t2} = d' B_2 \text{ in}^2$$

$A_{t2} \rightarrow$ 10.46 15.29 19.66 23.43 26.48

(W₂^{*}) Relative discharge velocity (fictitious)

$$W_2^* = \frac{.321 Q}{3 A_{t2}} \quad \text{Ref. Sec.'s 33 & 36 Eq. (162)}$$

$W_2^* = .321 (15917) / 10 \cdot A_{t2} \text{ ft/sec}$ $W_2^* \rightarrow$ 48.84 33.41 25.99 21.81 19.29

(W_{u2}^{*}) Tangential relative discharge velocity

$$W_{u2}^* = W_2^* \cos \beta_2^* \text{ ft/sec}$$

$W_{u2}^* \rightarrow$ 45.90 28.93 19.91 14.02 9.65

(ΔN'_{SA}) Maximum usable Stodola correction

$$\Delta N'_{SA} = (U_2 - C_{u2}) - W_{u2}^* \text{ ft/sec}$$

$\Delta N'_{SA} \rightarrow$ 8.10 25.06 34.09 39.98 44.35

(K'_{SA}) Stodola correction coefficient (based on Busemann's theoretical results)


Ref. Fig. 127
(interpolated)

$K'_{SA} \rightarrow$ 1.19 0.96 0.84 0.78 0.75


(ΔN_{SA}) Predicted Stodola correction

$$\Delta N_{SA} = K'_{SA} W_2^* \frac{\pi \sin \beta_2^*}{3} \quad \text{Ref. Eq. (309)}$$

$= \frac{171.4 \pi}{10} K'_{SA} \sin \beta_2^* \text{ ft/sec}$ $\Delta N_{SA} \rightarrow$ 21.92 25.85 29.07 32.17 34.97



SOLUTION: $\beta_2^* = 31.5^\circ$

PREPARED BY: <i>JB</i>	 Rockwell International Energy Systems Group	75 PAGE NO. OF
CHECKED BY:		N266ER000-001 REPORT NO.
DATE: 4/9/79	ISIP - Impeller Blade Calculations (Initial Estimate)	MODEL NO.

BLADE ANGLE INLET CALCULATIONS

(D_i) Eye diameter

$$D_i = 19 \text{ in}$$

Set by existing inlet diameter

(d_h) Hub diameter

$$d_h = 11.36 \text{ in}$$

Based on inducer outlet hub
sizing

(H_{ei}) Inducer Euler head

$$\begin{aligned} H_{ei} &= .12 H_e \\ &= .12 (625) \\ H_{ei} &= 75 \text{ ft} \end{aligned}$$

Expected maximum inducer
head for size and speed limit
Subscript (i) denotes inducer

(U_i) Impeller inlet tangential velocity

$$\begin{aligned} U_i &= \pi D_i N / 720 \\ &= \pi (19)(1110) / 720 \\ U_i &= 92 \text{ ft/sec} \end{aligned}$$

NOTE: $U_i \approx U_{2i}$ (inducer tip velocity)

(C_{u1}) Tangential fluid velocity approaching impeller

$$\begin{aligned} C_{u1} &= C_{u2i} = g H_{ei} / U_{2i} \\ &= 32.2(75) / 92 \\ C_{u1} &= 26.24 \text{ ft/sec} \end{aligned}$$

(C_{m1}) Meridional (thru-flow) velocity approaching impeller

$$\begin{aligned} C_{m1} &= .321 Q / A_e \quad \text{Where } A_e = \text{Eye area} \\ &= .321 (15917) / .785(19^2 - 11.36^2) \\ C_{m1} &= 28.0 \text{ ft/sec} \end{aligned}$$

(β₁) Relative approach angle

$$\begin{aligned} \beta_1 &= \tan^{-1} C_{m1} / (U_i - C_{u1}) \\ &= \tan^{-1} 28.0 / (92 - 26.24) \end{aligned}$$


$$\beta_1 = 23^\circ$$

(W₁) Relative approach velocity

$$\begin{aligned} W_1 &= C_{m1} / \sin \beta_1 \\ &= 28 / \sin 23^\circ \\ W_1 &= 71.4 \text{ ft/sec} \end{aligned}$$



INDUCER BLADE CALCULATIONS

PREPARED BY: <i>JJB</i>	 Rockwell International Atomics International Division	77
CHECKED BY:		PAGE NO. OF
DATE: <i>4/9/79</i>	ISIP- Inducer Blade Calculations (Initial Estimate)	REPORT NO. N266ER000-001
		MODEL NO.

(A₁) Inlet Flow Area

$$A_1 = (D_i^2 - D_{hi}^2) \pi / 4$$

$$= (18.63^2 - 6.63^2) \pi / 4$$

$$A_1 = 238 \text{ in}^2$$

Where: A_1 = Inlet Flow Area (in²)
 D_i = Inducer Tunnel bore (in)
 D_{hi} = Inducer inlet hub OD (in)

(C_{m1}) Axial fluid velocity (approaching inducer)

$$C_{m1} = 0.321 Q / A_1$$

$$= 0.321 (14600 / 238)$$

$$C_{m1} = 19.68 \text{ ft/sec}$$

Where: Q = Inducer flow (gpm)
 (= 14600 gpm from App.)
 C_{m1} = Axial inlet vel. (ft/sec)

(U₁) Blade tip velocity at inlet

$$U_1 = \pi D_t N / 720$$

$$= \pi (18.53) (1110) / 720$$

$$U_1 = 89.75 \text{ ft/sec}$$


Where: U_1 = Tang. vel at blade tip (ft/sec)
 D_t = Blade tip dia (in)
 N = Rotating speed (rpm)


(B₁) Fluid inlet angle, relative to blade tip

$$\beta_1 = \text{arc tan} (C_{m1} / U_1)$$

$$= \text{arc tan} (19.68 / 89.75)$$

$$\beta_1 = 12.36^\circ$$



PREPARED BY: <i>JJB</i>	 Rockwell International Atomics International Division	78
CHECKED BY:		PAGE NO. OF
DATE: <i>4/9/79</i>	ISIP - Inducer Blade Calculations (Initial Estimate)	REPORT NO. N266ER000-001
		MODEL NO.

(C_{u2}) Tangential fluid velocity at exit

$$C_{u2} = g H_{ei} / U_2$$

$$= 32.2 (75) / 89.75$$

$$C_{u2} = 26.91$$

Where C_{u2} = Tang. abs. exit vel. (ft/sec)
 H_{ei} = Inducer head (ft)
 (See imp. inlet calculation)
 U_2 = Blade tip vel. @ exit (ft/sec)
 (= U_1)

NOTE: This value differs slightly from the 26.24 ft/sec velocity calculated for the impeller inlet velocity triangle due to the slight difference in assumed inducer diameters (18.53 vs 19 in.)

(A_2) Exit flow area

$$A_2 = (D_i^2 - D_{h2}^2) \pi / 4$$

$$= (18.63^2 - 11.36^2) \pi / 4$$

$$A_2 = 171 \text{ in}^2$$

Where: A_2 = Exit flow area (in²)
 D_{h2} = Inducer exit hub OD (in)

(C_{m2}) Axial fluid velocity (leaving inducer)

$$C_{m2} = 0.321 Q / A_2$$

$$= 0.321 (14600) / 171$$

$$C_{m2} = 27.35$$

Where: C_{m2} = Axial exit vel. (ft/sec)


(β_2) Fluid exit angle relative to blade tip

$$\beta_2 = \arctan [C_{m2} / (U_2 - C_{u2})]$$

Where: β_2 = Reh angle at exit (deg)


$$= \arctan [27.35 / (89.75 - 26.91)]$$


$$\beta_2 = 23.52^\circ$$





RADIAL LOADS ON SODIUM BEARING

PREPARED BY:	 Rockwell International Atomics International Division	80
CHECKED BY:		PAGE NO. OF
DATE:	ISIP Radial Loads on Sodium Bearing	REPORT NO. N266ER000-001
		MODEL NO.



(R) Sodium Bearing Reaction Load

$$R_{MAX} = T\left(1 + \frac{A}{L}\right) + M/L$$


Where: $T = 800 \text{ lb}$
 $M = 13300 \text{ in-lb}$
 $A = 18.5 \text{ in}$
 $L = 296 \text{ in}$


$$R_{MAX} = 800\left(1 + \frac{18.5}{296}\right) + 13300/296$$

$$R_{MAX} = 895 \text{ lb}$$



AXIAL MOTION OF IMPELLER WITH RESPECT TO DIFFUSER

PREPARED BY:	 Rockwell International Atomics International Division	82
CHECKED BY:		PAGE NO. OF
DATE:	ISIP - Axial Motion of Impeller with respect to Diffuser	N266ER000-001 REPORT NO.
		MODEL NO.




VARIATION OF AXIAL TEMPERATURE GRADIENTS WITH PUMP SPEED

Initial Conditions: Low speed
 Shaft & SP/SC have same temperature profile (shown on left side of diagram)

Final Conditions: High speed
 Shaft temp. profile changes as shown on right side of diagram
 SP/SC temp. profile remains the same

ASSUMPTIONS:
 1. All temperature gradients are linear

PREPARED BY: <i>JFB</i>	 Rockwell International Atomics International Division	83
CHECKED BY:		PAGE NO. OF
DATE:	<i>ISIP - Axial Motion of Impeller with respect to Diffuser</i>	N266ER000-001 REPORT NO.
		MODEL NO.

1. Top zone (1st 105") temperature gradient remains unchanged.
 \therefore no change in length occurs

2. Middle zone (next 55")

a.) the temperature gradient changes from: 950F-to-1050F

$$\begin{aligned} \text{to: } & 950F - t_0 - \left[950 + \frac{55}{132} (1050 - 950) \right] \\ & = 950F - t_0 - [950 + 41.7] \\ & = 950F - t_0 - 991.7 \end{aligned}$$

b) the mean temperature changes from: $\frac{950+1050}{2} = 1000F (=537.7^\circ C)$
 to: $\frac{950+991.7}{2} = 971F (=521.7^\circ C)$

c) for this range, the instantaneous coefficient of thermal expansion is:
 $\alpha = 20.25 \times 10^{-6} / ^\circ C$ Ref. - Nuclear Systems Materials Handbook, Vol. I

$$\times \frac{5}{9} = 11.25 \times 10^{-6} / ^\circ F$$

d) the change in length, based on the change in mean temp.'s is -

$$\begin{aligned} \Delta L_1 &= L_1 \alpha (\Delta t) = 55 (11.25 \times 10^{-6}) (1000 - 971) \\ \Delta L_1 &= .0179 \text{ in} \end{aligned}$$

3. Lower zone (next 77")

a.) the temperature gradient changes from: 1050F-to-1050F (0.0 gradient)
 to: 991.7F - t_0 - 1050F

b.) the mean temperature changes from: 1050F (=565.5°C)
 to: $\frac{991.7+1050}{2} = 1021^\circ F (=549^\circ C)$

c.) for this range, the instantaneous coefficient of thermal expansion is:
 $\alpha = 20.35 \times 10^{-6} / ^\circ C$
 $\times \frac{5}{9} = 11.31 \times 10^{-6} / ^\circ F$

d) the change in length, based on the change in mean temp.'s is

$$\begin{aligned} \Delta L_2 &= 77 (11.31 \times 10^{-6}) (1050 - 1021) \\ \Delta L_2 &= .0252 \text{ in} \end{aligned}$$

4. Total change in length

$$\Delta L_{\text{total}} = \Delta L_1 + \Delta L_2 = .0179 + .0252 = .043 \text{ in.}$$



APPENDIX B

DESIGN SPECIFICATION - PUMP, SODIUM, INDUCER,
INTERMEDIATE SIZE (ISIP) (IMPELLER/INDUCER/DIFFUSER RETROFIT)

ESG Document N266ST310001



Rockwell International
Atomics International Division

PREPARED BY <i>D.R. Paradise</i> D.R. Paradise Specs. & Stds. Engineer	DESIGN SPECIFICATION	NUMBER N266ST310001	
		<input type="checkbox"/> REV B	<input type="checkbox"/> AMEND
TYPE COMPONENT			
DATE 5-22-79		TOTAL PAGES 44	E.O. 91299 ^{5/20/79}

TITLE
 PUMP, SODIUM, INDUCER, INTERMEDIATE SIZE (ISIP) (IMPELLER/INDUCER/DIFFUSER RETROFIT)

APPROVALS

<p><i>R.V. Anderson</i> _____ R.V. Anderson Project Manager</p>	<p><i>L.R. Woehler Sr.</i> _____ L.R. Woehler, Sr., Manager Specifications & Standards</p>
<p><i>J. Boardman</i> _____ J. Boardman Project Engineer</p>	<p><i>E. Andrews</i> _____ E. Andrews Quality Assurance</p>

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE

This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

RELEASED
ENGINEERING DEPT.

FORM 723-P-3 NEW 8-74



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

1.1

SUMMARY OF CHANGES

This Summary of Changes delineates the changes which constitute Revision B. The outside margins have been marked to indicate where changes, deletions, or additions from the previous issue have been made.

Revision B changes were made to bring this specification in line with Request for Test (N266RFT000001) Rev. C. changes.

<u>Page</u>	<u>Paragraph</u>	<u>Title-Description of Change</u>
3-1	3.1.1.3	<u>Radial Clearance</u> In the first sentence, following word "clearance" deleted statement "but in no case shall the radial clearance be less than 0.050 inch using the most adverse tolerance stackup." Added new second sentence beginning with "At least...and ending with transient tests."
3-2	3.2.2.1	<u>Operating Life</u> In the second sentence added word "design" preceding operating and after 4000 hours deleted words "minimum, at conditions described in 4.45" and substituted words beginning "of which 3000 hours...and ending with 1110 rpm."
3-2	3.2.2.2	<u>Flow/Speed Ratio</u> (was titled System Resistance) System resistance was defined in terms of flow/speed ratio instead of specific speed.
3-14	Figure 3-1A	<u>Pump Main Motor Operation Envelope.</u> System resistance lines were redefined (see paragraph 3.2.2.2 above).
4-3	4.4.5	<u>Performance Testing</u> Extensive test changes made to first and third paragraphs. Added new second paragraph.
4-4	4.4.5.1	<u>Determination of NPSHR</u> In first sentence (950 F) was (1050 F), and deleted 14,000 gpm. In subparagraph b, second sentence, added "(Elevation at the lower end of the inducer blade tip)."
4-4	4.4.5.2	<u>Determination of Suction Capability at Runout Flow</u> Deleted entire paragraph.
4-4	4.4.5.3	<u>Test Success Criteria</u> Renumbered paragraph to 4.4.5.2.
4-5	Figure 4-1	<u>NPSHR Determination</u> Added explanatory words "97% of initial head".



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV

B

AMEND.

PAGE NO

1.2

<u>Page</u>	<u>Paragraph</u>	<u>Title-Description of Change</u>
4-6 & 4-7	TABLE 4-I	<u>Test Sequence</u> Deleted previous sequence numbers/test descriptions 14, 15, 16, 17, 19 and 23. Added new test descriptions for sequence numbers 15 and 16. Deleted from sequence numbers 17 through 19, thermal transients 201, 205 and 206.
4-8	TABLE 4-II	<u>Test Thermal Transients</u> Deleted events 201, 205 and 206.



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO.

1.2

TABLE OF CONTENTS

<u>Title</u>	<u>Paragraph</u>	<u>Page</u>
SCOPE	1.	1-1
DCCUMENTS	2.	2-1
Applicable Documents	2.1	2-1
Other Documents	2.2	2-3
REQUIREMENTS	3.	3-1
Item Definition	3.1	3-1
Interface Definition	3.1.1	3-1
Performance	3.2	3-2
Hydrodynamic Design Point	3.2.1	3-2
Range of Operation	3.2.2	3-2
Suction Performance	3.2.3	3-3
Design Requirements	3.3	3-3
Stress Criteria	3.3.1	3-3
Mechanical Load Criteria	3.3.2	3-4
Design for Recirculating Flows	3.3.3	3-4
Drainability and Venting	3.3.4	3-4
Threaded Fasteners	3.3.5	3-5
Special Tool Design	3.3.6	3-5
Critical Speed	3.3.7	3-5
Direction of Rotation	3.3.8	3-5
Natural Resonant Vibration	3.3.9	3-5
Identification and Marking	3.4	3-5
Materials, Processes and Parts	3.5	3-6
Material Specification	3.5.1	3-6
Fluid Properties	3.5.2	3-6
Fabrication Procedures	3.5.3	3-6
QUALITY ASSURANCE PROVISIONS	4.	4-1
Quality Assurance Program	4.1	4-1
Design Verification	4.2	4-1
Quality Examination	4.3	4-1
Visual and Dimensional Examination	4.3.1	4-1
Special Measurements and Recordings	4.3.2	4-1
Test Requirements	4.4.	4-2
Test Scope	4.4.1	4-2
Assembly and Installation	4.4.2	4-2
Instrumentation and Controls	4.4.3	4-2
Auxiliary Equipment	4.4.4	4-2
Performance Testing	4.4.5	4-3
Cleaning and Disassembly	4.4.6	4-4
PACKAGING AND PACKING	5.	5-1



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 1.3

DOCUMENTS, DATA, AND REPORTS	6.	6-1
Drawings	6.1	6-1
General Assembly Drawing	6.1.1	6-1
Engineering Layout Drawing	6.1.2	6-1
Spot Layout Drawings	6.1.3	6-1
Detail Drawings	6.1.4	6-1
Interface Control Drawing	6.1.5	6-1
Documentation	6.2	6-2
Reports	6.2.1	6-2
Request For Test	6.2.2	6-2
Operations and Maintenance Manual (OMM) Addendum	6.2.3	6-2
Reference Documents	6.3	6-2
Notes	6.4	6-3
Data Submittal	6.5	6-4
APPENDIX 10 DATA SUBMITTAL REQUIREMENTS		10-1
APPENDIX 20		20-1

LIST OF FIGURES

Figure 3-1A	Inducer Pump Operation Envelope	3-14
Figure 3-1B	Inducer Pump Pony Motor Operation Envelope	3-14
Figure 3-2	Suction Performance NPSHR Target Valves for Intermediate Size Inducer Pump (ISIP)	3-15
Figure 3-3	Design Fatigue Strain Range, E, 304SS and 316SS --- Elastic Analysis	3-16
Figure 4-1	NPSHR Determination	4-5



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.
B

AMEND.

PAGE NO.
1.4LIST OF TABLES

TABLE 3-I	HYDRODYNAMIC DESIGN POINT	3-9
TABLE 3-II	PERFORMANCE REQUIREMENTS	3-10
TABLE 3-III	STRUCTURAL DESIGN CRITERIA STRESS LIMITS FOR DESIGN OF THE ISIP INDUCER, IMPELLER, AND DIFFUSER	3-12
TABLE 4-I	TEST SEQUENCE	4-6
TABLE 4-II	TEST THERMAL TRANSIENTS	4-8
TABLE 10-I	STRUCTURAL DESIGN CRITERIA	10-4
TABLE 10-II	FFTF IMPELLER DESIGN RULES	10-5
TABLE 20-I	DESIGN VERIFICATION METHOD	20-1



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV

B

AMEND

PAGE NO

1-1

SPECIFICATION FOR
PUMP, SODIUM, INDUCER, INTERMEDIATE SIZE (ISIP)

1. SCOPE This specification defines the requirements for the Intermediate-Size Inducer Pump, (also referred to herein as the ISIP) which is to be made by replacing the impeller of the FFTF Prototype Pump with a new inducer, impeller, diffuser, seal, and necessary adapter hardware. Subsequent testing requirements of the complete pump assembly are included.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO. 2-1

2. DOCUMENTS

2.1 Applicable Documents

American Society of Mechanical Engineers (ASME)

ASME Boiler and Pressure Vessel Code, 1977 Edition,
including Summer 1977 Addenda

ANSI/ASME BPV-III-NCA	Division 1 and Division 2 Nuclear Power Plant Components; General Requirements
ANSI/ASME BPV-III-1-NB	Class 1 Components
ASME SA-182	Specification for Forged or Rolled Alloy-Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High Temperature Service
ASME SA-351	Specification for Austenitic Steel Castings For High- Temperature Service
ASME SA-453	Specification For Bolting Materials, High Temperature, 50 to 85 KSI Yield Strength, with Expansion Coefficients Comparable to Austenitic Steel
ASME SA-637	Specification For Precipitation Hardening Nickel Alloy Bars, Forging Stock For High-Temperature Service
ASME SA-638	Specification For Precipitation Hardening Iron Base Superalloy Bars, Forgings, and Forging Stock for High-Temperature Service
Code Case N-47(1592-10)	Class 1 Component Elevated Temperature Service



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV

B

AMEND

PAGE NO

2-2

Rockwell International Corporation (RI)

Drawing

N266E000002 Interface Control Drawing
 (ICD), "Intermediate-Size
 Inducer Pump"

Specification

N001A0110001 Cleaning and Cleanness

N001A0116001 Packaging and Packing for
 Shipping and Storage; dated 27
 April 1977

N266RFT000001 Sodium Testing of Intermediate
 Size Inducer Pump in SPTF at
 IMEC

MW1-08061-000 General Weld Procedure; dated
 November 1975

Department of Energy, Nuclear Power Development Division

RDT Standards

RDT F 2-2 Quality Assurance Program
 Requirements, August 1973,
 including Amendments 1 through
 4

RDT F 8-6T Hoisting and Rigging of
 Critical Components and
 Related Equipment with
 Amendments 1 through 3

Argonne National Laboratory (ANL)

ANL-7273 Thermophysical Properties of
 Sodium

International Conference of Building Officials

UBC-1976 Edition Uniform Building Code



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.
B

AMEND.

PAGE NO
2-3

Westinghouse Electric Corporation

HWS-1551

LMFBR Low Capacity Prototype
Pump -- FFTF Primary Pump,
Rev. 1, January 1974,
including addendum 1P (June
1977)

WDTRS 25.14, Rev. 18

Sodium Testing of the FFTF
Prototype Pump

WEMD 114E829, Rev. 12

General Assembly, Prototype
Sodium Pump

American National Standards

ANSI B46.1-1962 (R1971) Surface Texture

2.2 Other Documents (See 6.3).



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV B	AMEND.	PAGE NO 3-1

3. REQUIREMENTS

3.1 Item Definition The FFTF Prototype Pump's original construction requirements are defined in document HWS-1551. The basic pump frame for the ISIP is from the FFTF Prototype Pump. This specification defines the design, fabrication, assembly and test for utilizing this pump frame with a new inducer/impeller/diffuser and necessary adapter hardware in place of the original impeller. For a complete description of the FFTF Prototype Pump, refer to referenced Document a., (CMM-051-00-005, hereinafter referred to as OMM).

3.1.1 Interface Definition The physical interface of the ISIP components are defined by ICD N266E000002. Changes in the interface shall be minimized wherein the pump shall be capable of being restored to its original configuration.

3.1.1.1 Impeller Mounting Mounting of the inducer/impeller on the existing taper at the lower end of the pump shaft shall be designed for controlled advance onto the taper such that the stress criteria of Table 3-III are not exceeded.

3.1.1.2 Axial Clearance At least one-half inch axial clearance shall be provided by the design above and below all rotating members.

3.1.1.3 Radial Clearance Radial clearance at the wear rings and at the inducer vane tips shall be based on assembly stackup of tolerances for the parts determining the clearance. At least 0.015 inch margin shall be provided against rubbing when the pump is operating with the most adverse radial tolerance stackup and is concurrently subject to distortion resulting from thermal transient tests.

3.1.1.4 Tool Interfaces

- a. The inducer, impeller, adapter diffuser, and other new parts (weighing in excess of 10 pounds) designated for installation into the existing pump frame, shall be designed to permit lifting and handling in accordance with the requirements of RDT F 8-6. In addition, the parts shall be designed to interface with the special assembly tools as part of the assembly procedure described in the specially addended version of the OMM.
- b. Tool interface requirements shall be met by designing the parts to interface with existing,



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

3-2

modified, or new special assembly tools (refer to 3.4.6).

- c. The bearing support flange (approximate weight 10,000 pounds) shall be positioned and supported from the impeller (or shaft) during upending and installation of the shield plug/support cylinder (SP/SC) over the shaft. During installation, the shaft assembly shall be supported from the lower end.

3.2 Performance

3.2.1 Hydrodynamic Design Point The hydraulic design conditions for which the pump shall be designed shall be in accordance with Table 3-I.

3.2.2 Range of Operation The range of operation for which the inducer and impeller and associated components shall be designed is presented in Table 3-II, which also includes the design point, and is depicted in Figures 3-1A and 3-1B.

3.2.2.1 Operating Life The inducer and impeller shall be designed for testing over the operating ranges depicted in Figures 3-1A, 3-1B and under the suction conditions (NPSHA) given in 3.2.2.3. The design operating test time shall total 4,000 hours, minimum, of which 3000 hours shall be at design temperature and speed, and 1000 hours shall be at temperatures of 400F, 600F and 800F at speeds between 500 to 1110 rpm.

3.2.2.2 Flow/Speed Ratio The system resistance (R) curves shown on Figure 3-1A represent coincident curves of constant flow/speed (Q/N) ratio for the pump. The following table defines specified flow/speed ratios corresponding to the various system resistance designations:

System Resistance Designation (R)	R-0	R-1	R-2	R-3	R-4	R-5	R-6
Flow/Speed Ratio (Q/N)	0.0	6.576	8.243	9.459	13.063	16.216	22.400



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO.

3-3

3.2.2.3 Net Positive Suction Head Available The net positive suction head available (NPSHA) to the pump varies with output flow rate at 1050F in accordance with the following relationship:

$$\text{NPSHA} = 56.5126 - 1.125 \times 10^{-6} Q^2 \quad (\text{ft})$$

Where: NPSHA = Net Positive Suction Head at pump inlet nozzle, minus the elevation difference, in feet, from the inducer inlet elevation down to the inlet nozzle centerline. (ft)

Q = Output volumetric flow rate (gpm)

(NOTE: Inducer inlet flow may be slightly higher than pump outlet flow due to internal leakage.)

3.2.3 Suction Performance

3.2.3.1 Design Flow NPSH The pump shall be designed to operate with a net positive suction head of 12.8 feet, or less, at design speed, flow and temperature and with less than 3 percent reduction of head due to cavitation (refer to Explanation note 6.4a).

3.2.3.2 Runout Flow NPSH The pump shall be designed to operate at 18,000 gpm at design speed and temperature, with less than 3 percent reduction in head due to cavitation, when the suction conditions correspond to minimum submergence (refer to Explanation note 6.4b).

3.3 Design Requirements

3.3.1 Stress Criteria All parts (except instrumentation) shall be designed and analysed to meet the structural design criteria of Table 3-III.

3.3.1.1 Steady-State Conditions A reduction of the structural design criteria in Table 3-III shall be determined and the reduced criteria used for design under steady-state temperature conditions.

3.3.1.2 Thermal Transients The design shall be analyzed to identify which of the test thermal transients described in Table 4-II may be run without exceeding the structural design criteria of Table 3-III. The pump shall be analyzed subsequently to determine which thermal transients, listed in



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 3-4

HWS-1551, the pump could withstand without exceeding the structural design criteria of Table 3-III.

The foregoing analysis shall be limited to use of elastic and simplified inelastic methods. Those areas where inelastic analysis would be required shall be identified.

3.3.2 Mechanical Load Criteria

3.3.2.1 Unbalanced Rotating Loads The impeller and inducer design shall include provisions to permit dynamic balancing of the inducer-impeller assembly within 3.5 inch-ounces at each balance plane when mounted on a balance spindle.

3.3.2.2 Radial Thrust Loads Design of the inducer, impeller, and diffuser adapter shall be such that polar symmetry is maintained.

3.3.2.3 Axial Thrust Loads The wear ring diameters shall be designed to maintain axial thrust between the limits of 70,000 pounds upward and 40,000 pounds downward over the operating range of the pump. Axial thrust calculations shall consider the possibility of at least ten percent difference between the static head at the tip of the lower (front) shroud and static head at the tip of the upper (back) shroud. Balance piston arrangements based on variation of axial clearances shall not be used to balance axial thrust.

3.3.3 Design for Recirculating Flows The design shall include internal passageways to permit ducting flow from the lower end of the hydrostatic bearing and recirculating flow from the back wear ring of the impeller, to a low pressure region of the inducer/impeller assembly. Flow from the bearing will be 100 gpm at design conditions. To minimize distortion under thermal transient conditions, passageways shall be symmetrical about the pump axis. At design operating conditions, passageways shall be sized to maintain the static pressure below the hydrostatic bearing to less than 18 psi above the inducer inlet pressure.

3.3.4 Drainability and Venting All internal parts shall be designed for self draining and venting. The use of drain holes and vent holes at specific locations shall be acceptable providing flow through these holes is considered in the hydrodynamic design. Concurrent draining and venting through the same holes shall not be permitted.

3.3.5 Threaded Fasteners All internal threaded fasteners shall be positively locked to prevent loosening (friction



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV B	AMEND.	PAGE NO 3-5

locks are not acceptable), and the head of the fastener shall be trapped to prevent entry into the fluid stream in the event of failure of the fastener shank. Unless otherwise specifically required, threads shall be the coarse thread series (UNC) and shall have a nominal diameter of one-half inch or greater. Mating surfaces of internal and external threads shall be of different materials.

3.3.6 Special Tool Design Special tools, or equipment to permit adapting existing special tools to the ISIP, shall be provided as required to permit handling and assembly of the pump internals. The design, fabrication, and proof testing of all lifting tools shall conform to the requirements of RDT F 806 for tackle. Support stands and similar static equipment shall meet the requirements of the Uniform Building Code for this region. Tool surfaces designed to contact the stainless steel pump parts shall be corrosion resistant. Stainless steel, nickel plate, chrome plate or nylon are chemically suitable contact surface materials. The design of the special tools shall permit assembly of the ISIP as described in the OMM (refer to 6.3a).

3.3.7 Critical Speed The calculated critical speed of the rotating assembly, including the ISIP inducer and impeller, shall not be more than 5 percent below the calculated critical speed for the FFTF Prototype Pump.

3.3.8 Direction of Rotation The inducer and impeller shall be designed to rotate counterclockwise when viewed from the pump drive end (top).

3.3.9 Natural Resonant Vibration The ISIP components (inducer/impeller, diffuser and diffuser shroud) shall be designed to avoid resonant vibration while under the influence of flow induced pressure pulses (such as the vortex shedding frequency of labyrinth seals) and mechanically induced pressure pulses (such as primary rotating and impeller-to-diffuser blade passing frequency).

3.4 Identification and Marking Identification and marking of parts shall be according to applicable detail design drawings.



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

3-6

3.5. Materials, Processes and Parts

3.5.1 Material Specification Material for the major parts shall conform to the following material specifications:

<u>Part</u>	<u>Material Specification</u>
1. Inducer	Forging, Grade F 304
2. Diffuser	Austenitic Stainless Steel, conforming to requirements of ASME SA-182; to the requirements of ANSI/ASME BPV-III-1-NB, Article NB-2000, and supplemental requirements to be specified by RI.
3. Diffuser Adapter	
4. Impeller	Casting, Grade CF8 Austenitic Stainless Steel, conforming to the requirements of ASME SA-351; to the requirements of ANSI/ASME BPV-III-1-NB, Article NB-2000, and to the supplemental requirements to be specified by RI.
5. Piston Ring	Nickel Alloy, ASME SA-637 Grade 718, precipitation hardened condition, made from double vacuum melted ingot.
6. Bolting Stock (Threaded fasteners, shaft keys, etc.)	(A286 Bolting Stock) Conforming to ASME SA-638, Grade 660, Type 2 or ASME SA-453, Grade 660, Class B.

3.5.2 Fluid Properties The thermophysical properties of sodium to be used for this design and subsequent test evaluation shall be according to ANL-7323.

3.5.3 Fabrication Procedures

- a. Equipment Protection Extreme care shall be exercised to protect all surfaces from contamination during fabrication, handling, testing, and storage. Precautions necessary to ensure such protection shall be incorporated in the detailed component or fabrication procedure. Detailed procedures for cleanliness control, in-



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

3-7

process cleaning, and final cleaning of all parts, components, and assemblies shall be utilized.

- b. Supplemental Heat Treatment After rough machining and prior to final machining, the inducer, impeller, diffuser, and adapter shall be given a supplemental heat treatment in order to develop dimensional stability.

These heat treated parts shall be subsequently protected from moisture which can promote intergranular attack or stress corrosion. Contaminates to be avoided include oxidizing agents (such as nitric acid), halide environments (such as salt air or fluorides from weld fluxes or smoke) and caustic solutions (such as hydroxides).

- c. Surface Finish The definitions, measurement and designation of surface finishes shall be in accordance with ANSI B46.1.
- d. Lock Welds All lock weld (bolt capture) joints shall be in accordance with MW1-08061-000. Lock welds shall be visually examined under 5X magnification for evidence of cracks.
- e. Special Processes Any nonstandard fabrication processes employed shall be identified and a procedure for their application specified. Examples of nonstandard processes are electro-discharge or electrochemical machining and electron beam welding.
- f. Cleaning All cleaning shall be in accordance with the requirements of RI Specification N001A0110001. Final cleaned surfaces shall meet the requirements for cleanliness Level 3. All cleaning procedures shall be submitted and approved by RI.
- g. Lubricant/Coolant A lubricant/coolant may be employed during machining operations provided it does not contaminate any crevice or inaccessible area that cannot be subsequently cleaned, and provided the lubricant is removed after completion of all operations. Lubricants used on austenitic stainless steel shall have a sulfur or chloride content of less than 5,000 ppm.



Rockwell International

Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO.

3-8

- h. Thread Lubricant Thread lubricants shall be used during assembly. The following lubricants, or equivalent shall be specified on assembly drawings.

<u>Type</u>	<u>Manufacturer</u>
Never-Seez Pure Nickel Special, Nuclear Grade	Never-Seez Compound Corporation, Broadview, Ill.
N-5000 Nuclear Grade Fel-Pro	Fel-Pro Incorporated, Skokie, Ill.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV B	AMEND	PAGE NO 3-9

TABLE 3-I
HYDRODYNAMIC DESIGN POINT

Flow Rate	14,500 gpm
Total Head Across Pump	500 ft
Shaft Speed	1,110 rpm
*Minimum Submergence (above impeller discharge centerline)	4 ft
**Minimum Cover Gas Pressure (at minimum submergence)	36 ft Na absolute (at 1050F)
Fluid	Sodium
Fluid Inlet Temperature	1050F
Fluid Density	50.97 lb/ft ³

*Refer to 3.2.2 for normal operating conditions.

**Resulting NPSH is approximately 41.3 ft, referred to inducer inlet elevation. This value includes pump inlet velocity head, but does not include internal suction elbow losses.



Rockwell International
 Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

3-10

TABLE 3-II

PERFORMANCE REQUIREMENTS

1	Design flow rate, gpm	14500
2	Total head at design flow rate, ft.	500
3	Design speed, rpm	1110
4	Minimum sodium level above impeller discharge centerline, ft.	4
5	Minimum cover gas pressure at minimum sodium level, ft of sodium absolute, 1050F	36
6	Maximum required NPSH at design flow rate, ft.	Note 1
7	Maximum required NPSH at runout flow rate, ft.	Note 1
8	Flow rate, at pony motor speed, qpm (maximum	1400
9	Total head at shutoff, ft. (maximum)	Note 2
10	Total head (at pony motor speed) ft. (see Note 3)	5 (max)
11	Runout flow rate, gpm	18000
12	Runout head, ft. (minimum)	375
13	Maximum inlet temperature, F (See Note 4)	1050
14	Minimum inlet temperature, F	350
15	Allowable change of free-surface level, ft.	11
16	Performance rangeability N	Note 5
17	Maximum shaft horsepower (shp) at design speed (1100 rpm) and design flow (14,500 gpm) with 400F sodium	2500

NOTES:

1. The minimum available NPSH at a flow of 18,000 qpm shall be that corresponding to minimum cover gas



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

3-11

pressure occurring concurrently with minimum sodium level. The pump shall not lose more than 3 percent head due to cavitation under these conditions and over the range of operation as specified in 3.2.2.

2. The pump shall have a stable (negative slope) head-capacity curve between flows of 8,000 to 18,000 gpm at design speed. A runout head of greater than 375 ft. is specified to assure smooth, stable operation at runout.
3. At pony motor operation, the maximum allowable head shall be 5 ft. A design objective at pony motor speed is to meet 4 ft. head at a flow of 1,100 to 1,450 gpm.
4. For the maximum outlet temperature, the heat input from the pump shall be taken into account.
5. The pump shall be capable of continuous operation between the boundaries shown on Figure 3-1A.

**Rockwell International Corporation
Atomics International Division**

CODE IDENT NO 09974

NUMBER N266ST310001	REVISION LETTER						PAGE 3-12
	A	B					

TABLE 3-III

STRUCTURAL DESIGN CRITERIA STRESS
LIMITS FOR DESIGN OF THE ISIP INDUCER,
IMPELLER, AND DIFFUSER

A. HIGH TEMPERATURE CRITERIA ($\geq 800^\circ\text{F}$)

Use Code Case N-47 (1592-10) (as guidance)

A.1 Primary Stress LimitsA.1.1 Design ConditionDesign Pressure + Dead Load + Design Mechanical
Load (includes seismic)

$$P_M \leq S_o$$

$$P_M + P_b \leq 1.5S_o$$

A.1.2 Normal Operating Conditions

Pressure + Mechanical Loads + Dead Weight

$$P_M \leq S_{Mt}$$

$$P_L + P_b \leq kS_{Mt}$$

$$P_L + \frac{P_b}{K_t} \leq S_t$$

A.2 Secondary Stress LimitsA.2.1 Strain Accumulation Limits

Average Inelastic Strain \leq 0.5% weld
 1.0% base material

or

$$X + Y \leq S_a / S_y$$

 $S_a = 1.25 S_t$ (maximum temperature for 10^4 hours)

 $S_y =$ Yield at average temperature of cycle

$$\frac{T_{max} + T_{min}}{2}$$

or

Rockwell International Corporation
Atomics International Division

CODE IDENT NO 09974

NUMBER N266ST310001	REVISION LETTER						PAGE 3-13
	A	B					

TABLE 3-III

STRUCTURAL DESIGN CRITERIA STRESS
LIMITS FOR DESIGN OF THE ISIP INDUCER,
IMPELLER, AND DIFFUSER
(continued)

$$X + Y \leq 1$$

$$T_{M,N} \leq \text{temperature at which } S_M = S_t \text{ at } 10^5 \text{ hours}$$

A.2.2 Creep Fatigue Limits

$$\frac{\Sigma b}{N_a} + \frac{\Sigma t}{T_d} \leq 0.6$$

Figure 3-3 shall be used as the design fatigue curve for pressure or other high-cycle oscillations.

B. LOW TEMPERATURE CRITERIA (<800°F)

Section III, Subsection NB (as guidance)

B.1 Primary + Secondary Stress Limits

B.1.1 Design Condition

Design Pressure + Design Dead Weight + Design Mechanical Load (include seismic)

$$P_M \leq S_M$$

$$P_L + P_b \leq 1.5S_M$$

B.1.2 Normal Operating Condition


Pressure + Thermal + Mechanical Load + Dead Weight

$$P_L + P_b + Q \leq 3S_M$$

**Rockwell International Corporation
 Atomics International Division**

CODE IDENT NO. 09974


NUMBER N266ST310001	REVISION LETTER						PAGE 3-14
	A	B					



LEGEND:

- ① Design Point
- ② Maximum Control Speed
- ③ Runout Point

Figure 3-1A
 Pump Main Motor
 Operation Envelope



LEGEND:

- ④ Design Point
- ⑤ Shutoff Point

Figure 3-1B
 Pump Pony Motor
 Operation Envelope

Refer: HWS-1551, Fig. 2

CODE IDENT NO 09974

NUMBER N266ST310001	REVISION LETTER					PAGE 3-15
	A	B				





Figure 3-2. Suction Performance NPSHR Target Values for Intermediate Size Inducer Pump (ISIP)

CODE IDENT NO 09974

NUMBER N266ST310001	REVISION LETTER						PAGE 3 - 16
	A	B					



Design fatigue strain range, ϵ_f , 304 SS and 316 SS - elastic analysis

Design Fatigue Strain Range, ϵ_f , for 304 SS and 316 SS (Elastic Analysis)

N_d Number of Cycles	ϵ_f , Strain Range (in./in.) at Temperature				
	800 F	850 F	900 F	950 F	1000 1200 F
10^1	.0448	.0303	.0201	.0107	.00915
2×10^1	.0318	.020	.0124	.0078	.00472
4×10^1	.0231	.0145	.00867	.0051	.00322
10^2	.0168	.00982	.00587	.00355	.00212
2×10^2	.0125	.00772	.00469	.0028	.00174
4×10^2	.00956	.00612	.00387	.0024	.00152
10^3	.00711	.00462	.00304	.00198	.00129
2×10^3	.00576	.00382	.00257	.00173	.00114
4×10^3	.00476	.00322	.00222	.00153	.00104
10^4	.00376	.00261	.00186	.0013	.000922
2×10^4	.00316	.00222	.00164	.00116	.000842
4×10^4	.00269	.00202	.00144	.00106	.000762
10^5	.00224	.00162	.00122	.000899	.000662
2×10^5	.00196	.00147	.00108	.000799	.000602
4×10^5	.00176	.00131	.000966	.000719	.000544
10^6	.00151	.00112	.000826	.000619	.000482

Reference ASME Code Case N-47 (1592-10), Fig. T-1430-1A,1B and Table 1430-1A,1B

Figure 3-3



Rockwell International
 Atomics International Division

NUMBER		Page III	
N266ST310001			
REV	AMEND	PAGE NO	
B		4-1	

4. QUALITY ASSURANCE PROVISIONS

4.1 Quality Assurance Program A quality assurance program shall be established and maintained meeting the requirements of RDT F 2-2, Section 1, Section 2 (except 2.5.1), Section 3 (except 3.3.5 and 3.9), Section 4 (except 4.12), and Section 5 (except 5.3, 5.9 and 5.14).

4.2 Design Verification Compliance with the design requirements of Section 3 of this specification, shall be demonstrated by analysis and accepted procedures (refer to Table, Appendix 20) and assessed by an independent formal design review.

4.3 Quality Examination

4.3.1 Visual and Dimensional Examination All fabricated parts shall be subjected to a visual examination and a dimensional check to verify compliance with drawings and applicable specifications.

4.3.2 Special Measurements and Recordings

4.3.2.1 Inducer/Impeller Surface Measurements Prior to initial assembly and after post-test cleaning, coordinates of the inducer blade surfaces shall be measured and recorded in accordance with inspection requirements to be provided in the addendum to the OMM (refer to 6.2.3). In addition to measurement of inducer blade, surface coordinates, photographs and cast replicas of the inducer and impeller blade surfaces, including those regions near the leading and trailing edges, shall be taken before and after the test and maintained as test records.

4.3.2.2 Natural Resonant Vibration Measurement The natural vibration frequencies of the individual ISIP components (inducer, impeller, diffuser and diffuser shroud) shall be measured and recorded prior to assembly to conform to requirement 3.3.9.

4.3.2.3 Fit and Clearance Measurements The assembly fit of the bearing support assembly, diffuser, diffuser shroud, shroud insert and static hydraulics shall be physically checked. The check shall include measurement and recording of minimum and maximum clearances between the shroud lower end (inducer tunnel) and the bore at the suction elbow upper end. In addition, the radial play (looseness) between the bearing support and static hydraulics shall be measured.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 4-2

4.4. Test Requirements

4.4.1 Test Scope Testing is considered to start with the recording of the receipt of inspection data and to continue through assembly, installation, performance testing, removal, cleaning, and post-test inspection. All information regarding the condition or performance of the pump and its auxiliaries, whether or not the information concerns the inducer, shall be considered as test data.

4.4.2 Assembly and Installation Pump parts shall be received, inspected, and assembled in accordance with the addended OMM by the testing organization. Following assembly of the internals, the internal subassembly shall be installed in the pump tank, then installation of the motor and connection of auxiliaries completed. Assembly and installation shall be performed in accordance with specific procedures in accordance with OMM requirements.

4.4.2.1 Special Tools In addition to the operating equipment, there is a set of special tools used for assembly and disassembly of the pump. These tools are "pump peculiar," designed specifically to meet pump requirements. Other general purpose and "facility peculiar" tools are not included.

For complete description of the special tools, refer to the OMM.

4.4.3 Instrumentation and Controls Instrumentation to be used for sodium testing of the ISIP shall be the same, or equivalent to, instrumentation used for testing the prototype FFTF pump during Phase B tests, with the exception of the mid-shaft bearing and MTI probes which will be deleted. The complete list of instrumentation is described in N266RFT000001.

4.4.3.1 Internal Instrumentation Internal instrumentation, consisting of thermocouples, accelerometers, and proximity probes, and including necessary clips and penetration seals, will be supplied by RI for installation by the ETEC testing organization.

4.4.3.2 External Instrumentation Controls and Equipment External instrumentation, controls and auxiliary equipment (4.4) shall be supplied by the ETEC testing organization.

4.4.4 Auxiliary Equipment Auxiliary equipment requirements, in addition to the liquid rheostat shall include:



Rockwell International
Atomics International Division

NUMBER		
N266ST310001		
REV.	AMEND.	PAGE NO
B		4-3

- a. The liquid rheostat control cabinet (C201A).
- b. An alarm/monitor control cabinet (C999 - sometimes referred to as (C201B) which includes an annunciator panel, lube oil and motor temperature indicators and which functions as an interface junction between the pump and the facility control system.
- c. An oil lubrication system to provide oil circulation, cooling and filtration for the upper, oil lubricated bearings. Includes indicators of temperature, pressure, and level to monitor performance of the oil lubrication system.

4.4.5 Performance Testing After all equipment has been installed and preoperational checkouts completed per the OMM, pump performance tests shall be performed. The performance test shall repeat those selected tests performed during Phase B testing of the prototype pump including a locked rotor impedance test (refer to WDTRS 25.14) in accordance with the Request for Test (refer to 6.2.2) and detail test procedures to be prepared by the ETEC test organization. The maximum test temperature shall be 950F. The sequence of tests shown in Table 4-I shall be used. Temperature ranges and rates for thermal transient testing shall be as listed in Table 4-II.

For the cavitation performance tests, the suction pressure shall be reduced to the point of 3.0 percent reduction in total head across the pump at 14,500, 16,000, and 18,000 gpm.

After cavitation performance testing, a 2,000 hour design point endurance test at 950F, 14,500 gpm and full speed shall be conducted with a 200 percent NPSH margin over the value determined for a 3 percent reduction in non-cavitating head. Following the design point endurance test, a 300 hour off-design endurance test shall be run at 950F, 14,500 gpm and speed of 894 rpm with the same NPSH as was used for the design point endurance test.

Percent NPSH margin shall be calculated using the following equation:

$$\%M = 100 (NPSHT/NPSHR - 1)$$

Where: %M = Percent NPSH margin

NPSHT = NPSH to be provided to the pump during the test



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.
B

AMEND.

PAGE NO
4-4

NPSHR = NPSH required to limit pump head reduction to 3% of the non-cavitating head under the same speed, flow and temperature conditions. (test value)

4.4.5.1 Determination of NPSHR Pump tests to determine the net positive suction head required (NPSHR) to limit the cavitation head loss to 3 percent, shall be performed at design speed (1110 rpm) and design temperature (950F) at initial measured flow rates of 14,500, 16,000 and 18,000 gpm. The tests shall be run with fixed (constant) flow impedance. The NPSHR shall be reported for each initial measured flow by two methods (refer to Figure 4-1):

- a. Inlet Nozzle Centerline Elevation as Reference
NPSHR shall be determined at the measured flow corresponding to a 3 percent head drop (point (a) of Figure 4-1) below the initial (non-cavitating) head at the initial flow. NPSH shall be referenced to the inlet nozzle centerline (refer to Explanation 6.4c).
- b. Inducer Inlet Centerline Elevation as Reference
NPSHR shall be determined at the measured flow corresponding to a 3 percent head drop (point (b) of Figure 4-1) at the actual (not initial) flow (refer to Explanation 6.4d). NPSH shall be referenced to the inducer inlet elevation (elevation at the lower end of the inducer blade tip).

4.4.5.2 Test Success Criteria Verification of design shall be by inspection of the impeller and inducer after testing. The criteria for success shall be the absence of visual evidence of material damage (which can be attributed to cavitation) when reviewed with the unaided eye.


4.4.6 Cleaning and Disassembly Removal from the pump tank, cleaning and disassembly of the ISIP shall be performed in accordance with the addended OMM using detail procedures prepared by the test organization. During removal, the pump internals shall be maintained in an inert atmosphere until cleaned. The alcohol cleaning process shall be used. Following general cleaning, disassembly and spot cleaning (as required) shall be completed. All disassembled parts shall be inspected and inspection data recorded on special data forms provided in the addended OMM.

CODE IDENT NO. 09974

NUMBER	REVISION LETTER					PAGE
N266ST310001	A	B				4-5

Figure 4-1

NPSHR Determination



POINT (a) - NPSHR DETERMINED USING INLET NOZZLE CENTERLINE ELEVATION AS REFERENCE & 97% OF THE INITIAL NON-CAVITATING HEAD

POINT (b) - NPSHR DETERMINED USING INDUCER INLET CENTERLINE ELEVATION AS REFERENCE & 97% OF TEST FLOW NON-CAVITATING HEAD



Rockwell International
Atomsics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 4-6

TABLE 4-I
TEST SEQUENCE

Sequence Number	Test Identification (WDTRS 25.14)	Test Description
1.	7.2.1	Pump Assembly and Installation
2.	7.2.2	Auxiliary System Check
3.	7.2.3	Preheat and Sodium Fill
4.	7.2.4	Initial Startup and Operation During Wetting
5.	7.2.5.4	Pony Motor Flow Scan
6.	7.2.5.5	Main Motor (R4) Speed Scan
7.	-	500 rpm Flow Scan ⁽¹⁾
8.	7.2.7.1	700F Checkout
9.	7.2.7.2	750F Checkout and Speed Scan & Endurance Test
10.	7.2.7.4	800F Checkout
11.	7.2.7.5	850F Checkout and Speed Scan
12.	7.2.7.8	900F Checkout
13.	7.2.8.1	950F Checkout and Speed Scans & Endurance Test
14.	7.2.11.B	Cavitation Performance
15.	-	2000 Hour Design Pt. Endurance Test at 200% NPSH Margin

(1) Test needs to be based on results of Pony Motor Flow Scan.



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV

B

AMEND

PAGE NO

4-7

TABLE 4-I
TEST SEQUENCE
(Continued)

Sequence Number	Test Identification (WDTRS 25.14)	Test Description
16.	-	3000 Hour Off-Design Endurance Test at Reduced Speed
17.	7.2.7.3	Low-Temperature Thermal Transients 202 and 203
18.	7.2.7.6	Mid-Temperature Thermal Transient 204
19.	7.2.7.6	High-Temperature Thermal Transients 207, 208, and 210



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 4-8

TABLE 4-II
TEST THERMAL TRANSIENTS

Event ⁽¹⁾	Initial ⁽²⁾⁽³⁾ Speed/Flow (rpm/gpm)	Initial Temp. (F)	Final Temp. (F)	Temp. Change (F)	Trans Rate (F/sec)	Main Drive Trip	Soak Time (hr)
202	1,110/14,500	750	600	-150	-1.5	No	6
203	1,110/14,500	500	650	+150	+1.5	No	6
204	1,110/14,500	850	650	-200	-2.0	No	8
207	1,110/14,500	1050	720	-330	-1.2	No	12
208	1,110/14,500	1050	825	-225	-2.0	No	9
210	1,110/14,500	1050	900	-150	-3.0	No	6

- (1) Reference WDTRS 25.14.
- (2) Initial speed and flow is shown at the beginning of the thermal transient.
- (3) All thermal transient events shall be run with constant speed and discharge throttle valve settings, and with a constant sodium level within facility level control limits.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 5-1

5. PACKAGING AND PACKING Finished component castings, forgings and machined parts shall be packaged and packed in accordance with the requirements of RI Specification N001A0116001. Packaging to Level A shall be required to maintain a dry argon purge gas environment during shipment and storage. Packing to Level B applies using wood packing crates.



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND

PAGE NO

6-1

6. DOCUMENTS, DATA, AND REPORTS

6.1 Drawings Drawing requirements for the ISIP shall include the following:

- a. General Assembly Drawing
- b. Engineering Layout Drawing
- c. "Spot" Layout Drawings (as required)
- d. Detail Drawings
- e. Interface Control Drawing

6.1.1 General Assembly Drawing The general assembly drawing shall be the top level drawing for the ISIP, through which access to all other drawings can be attained. This drawing shall be a modified or addended version of the existing Westinghouse Drawing 114E829 for the FFTF Prototype Pump.

6.1.2 Engineering Layout Drawing The engineering layout drawing shall be a cross-section assembly drawing showing assembled dimensions, tolerances, and clearances for the inducer/impeller and its hydrodynamic surroundings. This drawing shall have sufficient dimensional data and auxiliary views to permit engineering stress and thermal analysis. The layout drawing shall be maintained in an up-to-date status as new or revised dimensional data is received.

6.1.3 Spot Layout Drawings Spot layout drawings shall be prepared as required to show assembled dimensional information in local regions. These drawings shall be for temporary use in providing up-to-date engineering information as the design develops and as supplements to the overall layout drawing between update periods.

6.1.4 Detail Drawings Detail drawings shall be prepared for each new part showing all the requirements for fabricating and inspecting the part.

6.1.5 Interface Control Drawing An interface control drawing shall show all dimensional and functional interface data required for the design of new parts. The source of all data shall be referenced on the drawing.



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV.

B

AMEND.

PAGE NO

6-2

6.2 Documentation

6.2.1 Reports The following reports shall be prepared to record and support the design, analysis, and test effort:

- a. Hydrodynamic design report
- b. Steady-state stress analysis report
- c. Final design report, including thermal transient analysis
- d. Interim test reports
- e. Final test report, including post-test inspection
- f. Status reports, weekly and monthly, to report project status with relation to established milestones, recent accomplishments, and problem areas.

6.2.2 Request for Test A Request for Test shall be prepared in accordance with requirements of the test facility, describing all those tests to be run and the sequence of testing to be used. In addition, the Request for Test shall define restrictive limits, non-test operation of the pump, and data recording and reporting requirements. The Request for Test shall contain sufficient detail to permit preparation of test procedures by the testing organization. The Request for Test shall include the requirement for determination of locked rotor impedance of the pump.

6.2.3 Operations and Maintenance Manual (OMM) Addendum An addendum shall be prepared for the existing OMM (refer to document a.) to cover assembly, disassembly, and inspection of those new parts used to construct the ISIP from the existing prototype pump. The addendum shall include graphic material and detail instructions for the use of special tools at least to the extent presently provided in the existing manual.

6.3 Reference Documents

- a. OMM-051-00-005, Rev. 2, Westinghouse Electric Corporation Electro-Mechanical Division (WARD), "Operation and Maintenance Manual, Liquid Metal Coolant Pump, Model LMP-1, for the Fast Flux Test Facility (Prototype and Primary) Contract E(45-1)-2170."



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV B	AMEND	PAGE NO 6-3

- b. 77 LMEC-DRF-2476, letter from R.E. Fenton (LMEC) to T.A. Mangelsdorf (HEDL), "FFTF Prototype Pump - Phase B - Minimum NPSH Demonstration at Runout Flow and Pump Cavitation Performance at Selected Flowrates," July 19, 1977.
- c. Engineering Memorandum 4438, Westinghouse Electric Corporation, E-M Division, "Stress Analysis of the FFTF Impeller, FFTF Primary Pump," S.O. U360, August 31, 1972, by R.J. Oleyar.
- d. FRA-152-3, Draft for RDT F 9-1, "Interim Supplementary Structural Criteria for Elevated Temperature," A.L. Snow, November 6, 1970.

6.4 Notes

- a. Explanation of 3.2.3.1.

The criterion for NPSH is defined as the total (static plus velocity) head available to the pump at the inlet nozzle*, referred to the elevation of the inducer inlet, less the vapor head of the sodium, all expressed in feet of sodium at design temperature. Suction performance will be the principal criteria to be used for evaluating the inducer/impeller assembly relative to a conventional impeller. Target values for the net positive suction head required (NPSHR) to limit the head loss to 3 percent cavitation are shown in Figure 3-2.

*Subtract the elevation difference between the inducer inlet and the pump inlet centerline.

- b. Explanation of 3.2.3.2.

Minimum submergence comprises 4 feet above the impeller discharge centerline concurrent with a minimum cover gas pressure of 36 feet absolute of sodium at 1050F. Corresponding conditions for this criterion are defined as having the sum of the submergence and absolute cover gas head equal to 40 feet.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO. 6-4

c. Explanation of 4.4.5.1a.

NPSHR, corresponding to method defined in 4.4.5.1a was reported in Reference Document b in 6.3.

d. Explanation of 4.4.5.1b.

This NPSHR valve will require determination of an imperial equation to represent the non-cavitating H-Q characteristic.

6.5 Data Submittal Data on subcontract purchase items (i.e., castings, forgings, and other machined parts), shall be submitted as defined in Appendix 10 and as specified in the applicable Procurement specification and purchase order. A supplier data list (SDRL) shall be prepared, as applicable, for each procurement specification.



Rockwell International
Atomics International Division

NUMBER		
N266ST310001		
REV	AMEND	PAGE NO
B		10-1

APPENDIX 10

DATA SUBMITTAL REQUIREMENTS



Rockwell International
Atomics International Division

NUMBER

N266ST310001

REV

B

AMEND

PAGE NO

10-2

APPENDIX 10
DATA SUBMITTAL REQUIREMENTS

10.1 INTRODUCTION This appendix establishes the requirement for data to be submitted to RI. It is comprised of two major elements: a set of general requirements which apply to all data items; a Supplier Data Requirements List (SDRL)* which lists all of the data items required and provides the schedule and submittal requirements.

10.2 GENERAL REQUIREMENTS

10.2.1 Document Identification Requirements

10.2.1.1 Title Each document submitted shall bear a title which is descriptive of the contents and which distinguishes it from other similar documents.

10.2.1.2 Numbering All documents shall be numbered. The Supplier's document numbering system may be used provided that it prohibits the use of the same number on more than one document. The document number shall appear on each page of the document. The Supplier's drawing numbering system shall meet the following minimum requirements:

- a. The document number shall not exceed 15 characters. These characters may include numbers, letters, and dashes, with the following limitations:
 - (1) Letters I, O, and Q shall not be used.
 - (2) Letters shall be upper case (capitals).
 - (3) Numbers shall be whole Arabic (1, 2, 3, etc.) numerals. Fractional, decimal, and Roman numerals shall not be used.
 - (4) Blank spaces are not permitted.

Each page of multisheet documents shall be numbered. The first page shall indicate the total number of pages.

*SDRL to be provided in applicable procurement document.



Rockwell International
Atomics International Division

NUMBER N266ST310001		
REV. B	AMEND.	PAGE NO 10-3

10.2.1.3 Revisions The supplier's document revision system shall include a requirement for advancing the revision letter or number each time the document is revised and reissued.

10.2.1.4 Identification The first page of the document shall show the supplier's name and address (city and state are required, street address is optional), the document title, document number, current revision letter or number, and date.

10.2.2 Document Legibility and Reproducibility

10.2.2.1 Clarity All documents submitted shall be of sufficient clarity such that, when reproduced, lines, numbers, letters, and characters of the reproductions will be clearly legible and readable.

10.2.2.2 Reproducible Copies When reproducible copies of drawings are ordered, they shall be direct reading black-on-white translucents. Sepias are not acceptable. Reproducibles shall be of such quality that when microfilmed, copies made from the microfilm meet the requirements of Paragraph 10.2.2.1.

10.2.2.3 Subtier Documents All documents forwarded from subtier suppliers shall comply with these same requirements.

10.2.3 Contractual Due Dates When the due date specified in the SDRL occurs on Saturday, Sunday, or a holiday, the due date becomes the subsequent working day. Unless otherwise specified, all schedules are expressed in calendar days.

10.2.4 Preparation for Shipment

10.2.4.1 Transmittal Letter The supplier shall submit all data under a transmittal letter (or equivalent) which includes the following:

- a. RI Purchase Order number
- b. Purchase Order line item number
- c. SDRL line item number. (If the document satisfies more than one item number, then all applicable line item numbers will be listed.)
- d. Supplier document identification number, title, and revision or date



Rockwell International

Atoms International Division

NUMBER

N266ST310001

REV

B

AMEND

PAGE NO

10-4

- e. Quantity and type (reproducible or nonreproducible) of data transmitted
- f. Action required (e.g., RI approval, review, or for information)

10.2.4.2 Method of Transmittal All reproducible of "B" (11 in. by 17 in.) and larger sized drawings shall be shipped rolled (unfolded) inside mailing tubes. All prints of "B" and larger size drawings shall be folded to 8-1/2 in. by 11 in. and shipped flat. All "A" (8-1/2 in. by 11 in.) size documents shall be shipped flat.

**Rockwell International Corporation
Atomics International Division**

N266ER000-001
Page 128

CODE IDENT NO. 09974

NUMBER N266ST310001	REVISION LETTER						PAGE 20-1
	A	B					

APPENDIX 20

TABLE 20-1. DESIGN VERIFICATION METHOD

Paragraph	Requirement	Verification Method					Comment
		Analysis	Drawing Review	Checking	Tolerance Stackup	Test	
3.1.1.1	Impeller Mounting						Procedure in OMM Addendum (6)
3.1.1.2	Axial Clearance			X	X		
3.1.1.3	Radial Clearance			X	X		
3.1.1.4(a)	Tool Interfaces		X	X			RDT F 8-6 Stress Signoff
(b)			X	X			
(c)			X	X			
3.2.1	Hydrodynamic Design Point	X					Analysis (1)
3.2.2	Range of Operation	X					Analysis (1)
3.2.2.1	Operating Life	X					Analysis (1,3) Report (2)
3.2.3.1	Design Flow NPSH	X				X	Analysis (1) Test (4.4.5.1) (4)
3.2.3.2	Runout Flow NPSH					X	Test (4.4.5) (4)
3.3.1	Stress Criteria	X					Analysis (3)
3.3.1.1	Steady State Conditions	X					Analysis (3)
3.3.1.2	Thermal Transients	X					Analysis (5)
3.3.2.1	Unbalanced Rotating Loads		X	X			
3.3.2.2	Radial Thrust Loads	X	X	X			(a) Analysis (1) (b) Test Org & Insp
3.3.2.3	Axial Thrust Loads	X	X	X			Analysis (1,3)
3.3.3	Design for Recirculating Flows	X	X	X			Report (2)
3.3.4	Drainability and Venting	X	X	X			
3.3.5	Threaded Fasteners		X	X			
3.3.6	Special Tool Design		X	X			OMM Addendum (6)
3.3.7	Critical Speed	X					
3.3.8	Direction of Rotation		X	X			
3.3.9	Natural Resonant Vibration	X				X	4.3.2.2
3.4	Identification and Marking		X	X			Procurement Spec
3.5.1	Material Specification		X	X			Procurement Spec's
3.5.2	Fluid Properties	X					Analysis, Reports (1,4)
3.5.3	Fabrication Procedures		X				Procurement Spec's

Reference Documents

- (1) Hydrodynamic Analysis Report (Est. Complete 4/7/78) by Rocketdyne
- (2) Design Report (Est. Complete Dec.) by AI
- (3) Structural Analysis Report (Est. Complete 4/7/78) by Rocketdyne
- (4) Final Test Report (Est. Complete Dec. 1980) by AI
- (5) Test Transient Identification, T1 (Est. Complete Sept. 1978) by AI
- (6) OMM Addendum (Est. Complete Jul. 10, 1978) by AI



(This page intentionally blank)



(This page intentionally blank)



APPENDIX C

RECIRCULATING FLOW ANALYSES OF
INTERMEDIATE SIZE INDUCER PUMP

ESG Document N266TI000003



SUPPORTING DOCUMENT

NUMBER N266TI000003 REV LTR/CHG NO. SEE SUMMARY OF CHG

PROGRAM TITLE
Intermediate- Size Inducer Pump

DOCUMENT TYPE
Technical Information

DOCUMENT TITLE
Recirculating Flow Analyses of Intermediate Size Inducer Pump (ISIP)

KEY NOUNS
Inducer Pump

ORIGINAL ISSUE DATE
April 20, 1978

PREPARED BY/DATE DEPT MAIL ADDR
R. K. Hoshide *RK Hoshide 4/20/78* 731 JB05

GO NO. S/A NO. PAGE 1 OF TOTAL PAGES 17
09280 23000 REL. DATE 4-21-78BK

APPROVALS DATE
L. Stabinsky *L Stabinsky* 4/20/78
T. J. Boardman *T Boardman* 4/20/78

SECURITY CLASSIFICATION
(CHECK ONE BOX ONLY) (CHECK ONE BOX ONLY)
UNCL ERDA DOD
CONF. RESTRICTED DATA
SECRET DEFENSE INFO.
AUTHORIZED CLASSIFIER DATE

DISTRIBUTION
* NAME MAIL ADDR

ABSTRACT

- * R. V. Anderson LB17
- * T. J. Boardman(17) LB39
- * C. Dunn LB39
- * R. K. Hoshide JB05
- * L. Stabinsky JB05

Enclosed is a report which documents the recirculation flow analyses for the Intermediate-Size Inducer Pump (ISIP), from which the primary flowrates through the pump were obtained. The front and rear impeller labyrinth seals, which incorporate stepped pockets with slanted and rounded ribs were checked. These seal design features should minimize the impeller labyrinth seal leakages and also provide excellent shutoff head characteristics.

RESERVED FOR PROPRIETARY/LEGAL NOTICES
THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, ERDA
This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY

Recirculating Flow Analyses of Intermediate Size Inducer Pump (ISIP)

- Refs:
- (1) AI Drawing, "Intermediate-Size Inducer Pump Layout, ISIP," Drawing N266R000015, Issue 1, March 16, 1978
 - (2) Allen, H. G., "Hydraulics Design Report FFTF Primary Pump," Engr. Memo 4476, Westinghouse Electric Corporation, Electro-Mechanical Div., Cheswick, Pennsylvania, January 15, 1973
 - (3) Crane, "Flow of Fluids Through Valves, Fittings, and Pipe," Technical Paper 410, Crane Company, New York, N.Y., 1976
 - (4) Internal Letter, "Pump Impeller Labyrinth Seal Study," DDR-712-3012, Isaacson, J., Rocketdyne Division, Rockwell International, Canoga Park, California, December 4, 1957
 - (5) Crewdson, E., "Water-Ring Self-Primary Pumps," Vol. 170, No. 13, Institution of Mechanical Engineers, Westminster, South Wales, 1956

INTRODUCTION

Recirculating flows of the ISIP were analyzed, and the calculations are shown in Appendix A. Secondary flow paths were first obtained before the primary flow rates through the pump were obtained. Analyses were also conducted to check the impeller labyrinth seal design and the drain and vent hole leakages.

SUMMARY

Recirculation flow rates were obtained and are shown in Figures 1 and 2. From these recirculation flows, the primary flow rates through the pump were obtained and are also shown in Figures 1 and 2.

The impeller labyrinth seal design incorporates good design features which are stepped pockets with slanted and rounded ribs. These features are especially helpful in minimizing the leakage flows for this large clearance seal application.

DISCUSSION

The ISIP layout drawing (Reference 1) was used to determine the various recirculation flow paths through the pump. Recirculation flows which remained the same from the previous pump design were obtained from Reference 2 and are shown in Figure 1.

Secondary flow paths were first obtained and are summarized below:

1. Q_1 , leakage between suction nozzle outlet cone and inlet to suction elbow = 160 gpm.
2. Q_2 , leakage through inlet static seal = 85 gpm.
3. Q_3 , flow through drive shaft = 50 gpm.
4. Q_4 , leakage through front impeller labyrinth seal = 648 gpm.
5. Q_5 , leakage through rear impeller labyrinth seal = 569 gpm.
6. Q_6 , flow through hydrostatic bearing = 200 gpm.
7. Q_7 , leakage through the diffuser and radial bearing housing = 131 gpm.
8. Q_8 , leakage through discharge bellows static seal = 10 gpm.
9. Q_9 , leakage through impeller return holes = 669 gpm.

These recirculation flow calculations are shown in the appendix, and the flows are shown in Figures 1 and 2. Friction factors used were obtained from Crane (Reference 3).

Impeller labyrinth seal leakage rates were checked using previous Rocketdyne empirical data (Reference 4) and results obtained from E. Jackson (addendum to Reference 5). The seal flow coefficient obtained for both front and rear labyrinth seals was 0.428 which is realistic for the present design. These labyrinth seal designs incorporate the step configuration from Reference 4 and the slanted rounded backs of the ribs from Reference 5. These features should minimize these leakages and also provide excellent shutoff head characteristics.

The shaft extension does not affect the flow rate through the drive shaft. Only a small decrease (less than 1/2 gpm), which includes the vent/drain holes contribution, is realized and was neglected for this analysis.

From this recirculation flow analysis, the following primary flow rates through the pump were obtained:

1. Q disch., discharge flow rate = 14,500 gpm.
2. Q inlet, inlet flow rate = 14,500 gpm.
3. Q suct. el., suction elbow flow rate = 14,660 gpm.
4. Q ind., flow through inducer = 14,695 gpm.
5. Q imp., flow through impeller = 15,997 gpm.
6. Q trans. diff., flow through transition diffuser = 14,780 gpm.
7. Q exist. diff., flow through existing diffuser = 14,841 gpm.

PREPARED BY: <i>RKH</i>	Rockwell International Atomic International Division	PAGE NO. 5 OF
CHECKED BY:		REPORT NO. N266TI000008
DATE: 3-22-78		MODEL NO.






FIG. 1 WEMD RECIRCULATION FLOWS

FIG 2 ISIP RECIRCULATION FLOWS



PREPARED BY: <i>RZH</i>	 Rockwell International Atomics International Division	PAGE NO. <i>7</i> OF
CHECKED BY:		REPORT NO. <i>N266TI000003</i>
DATE: <i>3-22-78</i>	APPENDIX A - FLOW ANALYSES	MODEL NO.


I. THIS FLOW ANALYSES INCLUDES: 1) SECONDARY & PRIMARY FLOWS, 2) LABYRINTH SEAL, DRAIN, & VENT HOLE FLOWS.

A. THE SECONDARY FLOW PATHS ARE DEFINED AS FOLLOWS:

1. Q_1 LEAKAGE BETWEEN SUCTION NOZZLE OUTLET CONE AND INLET TO SUCTION ELBOW.
2. Q_2 LEAKAGE THROUGH INLET STATIC SEAL.
3. Q_3 FLOW THROUGH DRIVE SHAFT.
4. Q_4 LEAKAGE THROUGH FRONT IMPELLER LABYRINTH SEAL.
5. Q_5 LEAKAGE THROUGH REAR IMPELLER LABYRINTH SEAL.
6. Q_6 FLOW THROUGH HYDROSTATIC BEARING.
7. Q_7 LEAKAGE THROUGH THE DIFFUSER AND RADIAL BEARING HOUSING.
8. Q_8 LEAKAGE THROUGH DISCHARGE BELLOWS STATIC SEAL.
9. Q_9 LEAKAGE THROUGH IMPELLER RETURN HOLES.

B. FROM THESE DEFINITIONS, THE FOLLOWING PRIMARY FLOWRATES ARE OBTAINED:

1. $Q_{DISCH.} = \text{DISCHARGE FLOWRATE}$
 $= 14,500 \text{ GPM}$
2. $Q_{INLET} = \text{SUCTION NOZZLE FLOWRATE}$
 $= Q_{DISCH.} = 14,500 \text{ GPM}$
3. $Q_{SUCT. EL.} = \text{SUCTION ELBOW FLOWRATE}$
 $= Q_{INLET} + Q_1$
 $= Q_{INLET} + Q_3 + \frac{1}{2} Q_6 + Q_8$
4. $Q_{IND.} = \text{FLOW THROUGH INDUCER}$
 $= Q_{SUCT. EL.} + Q_2 - Q_3$
5. $Q_{IMP.} = \text{FLOW THROUGH IMPELLER}$
 $= Q_{IND.} + Q_9 + Q_4 - 15 \text{ GPM}$

PREPARED BY: <u>RKZ</u>	 Rockwell International Atomics International Division	PAGE NO <u>8</u> OF
CHECKED BY:		REPORT NO <u>N266TI000003</u>
DATE: <u>3-22-78</u>		MODEL NO.

6. $Q_{TRANS. DIFF.} = FLOW THROUGH TRANSITION DIFFUSER$

$$= Q_{IMP} - Q_4 - Q_5$$

7. $Q_{EXIST. DIFF.} = FLOW THROUGH EXISTING DIFFUSER$

$$= Q_{TRANS. DIFF.} + Q_7 - Q_2 + 15 \text{ GPM}$$

8. $Q_{DISCH.} = Q_{EXIST. DIFF.} - Q_6 - Q_7 - Q_8$

$$= 14,500 \text{ GPM.}$$

C. THIS SECONDARY FLOW ANALYSES ARE AS FOLLOWS:

1. Q_6 HYDROSTATIC BEARING

SAME AS WEMD REPORT (REF. 2)

$$Q_6 = \underline{200 \text{ GPM}} \leftarrow$$

2. Q_7 DIFFUSER AND RADIAL BEARING HOUSING

SAME AS WEMD REPORT (REF. 2)

$$Q_7 = \underline{131 \text{ GPM}} \leftarrow$$

3. Q_8 DISCHARGE BELLOWS STATIC SEAL

SAME AS WEMD REPORT (REF. 2)

$$Q_8 = \underline{10 \text{ GPM}} \leftarrow$$

4. Q_4 FRONT IMPELLER LABYRINTH SEAL

FROM ROCKETDYNE DIV., ROCKWELL INT.
6633 CANOGA AVE, CANOGA PK., CA.

$$Q_4 = \underline{648 \text{ GPM}} \leftarrow$$

5. Q_5 REAR IMPELLER LABYRINTH SEAL

FROM ROCKETDYNE DIV., ROCKWELL INT.
6633 CANOGA AVE, CANOGA PK, CA.

$$Q_5 = \underline{569 \text{ GPM}} \leftarrow$$

6. Q_2 INLET STATIC SEAL


GIVEN: MEAN SEAL DIA. = 23.2 IN.

FACE WIDTH = $\frac{1}{8}$ IN

CLEARANCE = 0 TO 3 MILS, SAY 1.5 MILS
PER SEAL:

AREA = π (MEAN DIA) CLEARANCE

$$= \pi (23.2) (.0015) = 0.109 \text{ IN}^2$$

PREPARED BY: <u>RZL</u>	 Rockwell International Atomics International Division	PAGE NO. <u>9</u> OF
CHECKED BY:		REPORT NO. <u>N266TI000003</u>
DATE: <u>3-22-78</u>		MODEL NO.

LET: HEAD LOSS (H_2) THROUGH GAP EQUAL TO:

$$H_2 = 1.5 \frac{V^2}{2g} + f \frac{L}{D} \frac{V^2}{2g}$$

WHERE: V = VEL THROUGH GAP

f = FRICTION FACTOR

= 0.037 FOR VERY SMALL CLEARANCES

L = LENGTH

$$= \frac{1}{8} \text{ IN.}$$

D = EQUIVALENT DIA

= TWICE THE CLEARANCE

$$= 2(0.0015) = 0.003 \text{ IN.}$$

g = ACCELERATION DUE TO GRAVITY

$$= 32.174 \text{ FT/SEC}$$

SUBSTITUTING :

$$H_2 = 1.5 \frac{V^2}{2g} + \frac{0.037 \left(\frac{1}{8}\right) V^2}{(0.003) 2g}$$

SOLVING FOR V :

$$V = \left(\frac{2g H_2}{3.04} \right)^{\frac{1}{2}}$$

LET: $H_2 = 500 \text{ FT (MAX.)}$

$$V = \left(\frac{2g 500}{3.04} \right)^{\frac{1}{2}} = 103 \text{ FT/SEC}$$

$$V = \frac{Q 144}{A 448.83}$$

WHERE:

Q = FLOWRATE THROUGH SEAL


A = AVE. LEAKAGE AREA = 0.109 IN.²

$$\therefore Q = \frac{VA 448.83}{144} = \frac{103(0.109) 448.83}{144} = 35 \text{ GPM}$$

FOR BOTH FACES:

$$Q = 2(35) = 70 \text{ GPM}$$

ADDITIONAL LEAKAGE THROUGH THE 2 EA $\frac{1}{4}$ IN. DRAIN HOLES MUST BE ACCOUNTED FOR

PREPARED BY: <i>RKZ</i>	 Rockwell International Atomics International Division	Page 141
CHECKED BY:		PAGE NO. 10 OF
DATE: <i>3-22-78</i>		REPORT NO. N266TI000003
		MODEL NO.

$$\Delta P = 35.8 - 15.1 = 20.7 \text{ PSID}$$

$$A = \frac{2\pi}{4(144)} \left(\frac{1}{4}\right)^2 = 0.000682 \text{ FT}^2$$

$$\text{HEAD LOSS} = 1.5 \frac{V^2}{2g} + f \frac{L}{D} \frac{V^2}{2g}$$

$$\text{LET: } f = 0.037$$

$$\therefore V = \left(\frac{2g \Delta H}{1.587} \right)^{\frac{1}{2}} = \left(\frac{2g (20.7) 144}{(1.587) \rho} \right)^{\frac{1}{2}}$$

$$\text{WHERE: } \rho = \text{DENSITY} \\ = 50.971 \text{ LB/FT}^3$$

$$\therefore V = 48.7 \text{ FT/SEC}$$

$$\text{AND } Q = VA = 488.83 = 48.7(0.000682) 448.83 \\ = 14.9 \text{ GPM, SAY } 15 \text{ GPM}$$

∴ TOTAL INLET STATIC SEAL LEAKAGE IS:

$$Q_2 = 70 + 15 = 85 \text{ GPM}$$

CHECK ON REYNOLD'S NO. (Re)

$$Re = \frac{\rho V d}{\mu}$$

WHERE: d = DIA., FT

μ = VISCOSITY

$$= 0.5221 \text{ LB/FT HR}$$

SUBSTITUTING:

$$Re = \frac{50.971(48.7) \cdot \frac{.25}{12} (3600)}{0.5221} = 3.5 \times 10^5$$

$$\text{LET: } \frac{e}{d} = \frac{0.0001}{\frac{1}{4}} = 0.0004$$

FROM CRANE (REF. 3)


$$f = 0.0173$$

$$\therefore \Delta H = 1.5 \frac{V^2}{2g} + (0.0173) \frac{.59}{\frac{1}{4}} \frac{V^2}{2g}$$

$$V = \left(\frac{2g \Delta H}{1.54} \right)^{\frac{1}{2}} = \left(\frac{2g (20.7) 144}{1.54 \cdot 50.971} \right)^{\frac{1}{2}} = 49.4 \text{ FT/SEC}$$

$$Q = 49.4(0.000682) 448.83 = 15 \text{ GPM}$$

$$\therefore Q_2 = 70 + 15 = \underline{\underline{85 \text{ GPM}}}$$

PREPARED BY: <u>RKZ</u>	 Rockwell International Atomics International Division	PAGE NO. <u>11</u> OF
CHECKED BY:		REPORT NO. <u>N266TI000003</u>
DATE: <u>3-22-78</u>		MODEL NO

7. Q₃ DRIVE SHAFT

FROM THE WEMD REPORT (REF. 2)

$$Q_3 = 49.8 \text{ GPM}$$

BECAUSE THE ISIP DESIGN HAS AN ADDITIONAL SHAFT EXTENSION, THE ADDITIONAL PRESSURE LOSS AND ACCOMPANYING DECREASE IN FLOW-RATE WAS CHECKED AS FOLLOWS:

$$\text{LET: } d = 1.95 \text{ IN. (DISTANCE ACROSS FLATS)}$$

$$\therefore A = \frac{\pi}{4} (1.95)^2 = 0.0207 \text{ FT}^2$$

$$\text{LET: } Q = 49.8 \text{ GPM}$$

$$\therefore V = \frac{Q}{A} = \frac{49.8}{(0.0207) 448.83} = 5.36 \text{ FT/SEC}$$

$$Re = \frac{50.971 (5.36) \frac{1.95}{12} (3600)}{0.5221}$$

$$= 3.07 \times 10^5$$

$$\frac{e}{d} = \frac{0.001}{1.95} = 0.0005$$

FROM CRANE

$$f = 0.0182$$

$$\Delta H = 7.5 \frac{(5.36)^2}{2g} + \frac{0.0182 (13.9) (5.36)^2}{1.95 (2g)}$$

$$= 0.73 \text{ FT}$$

$$Q = K \sqrt{\Delta H}, \text{ OR: } K = \frac{Q}{\sqrt{\Delta H}}$$

FROM WEMD (REF. 2)


$$K = \frac{49.8}{\sqrt{49.84}} = 7.054$$

$$\therefore Q_3 = 7.054 \sqrt{49.84 - 0.73} = 49.44 \text{ GPM}$$

$$\text{DECREASE IN FLOW} = 49.8 - 49.44$$

$$= 0.36 \text{ GPM (NEGLIGIBLE)}$$

$$\therefore \text{LET } Q_3 = \underline{\underline{50 \text{ GPM}}}$$

PREPARED BY: <u>RKN</u>	 Rockwell International Atomics International Division	PAGE NO. <u>12</u> OF
CHECKED BY:		REPORT NO. <u>N266TI000003</u>
DATE: <u>3-22-78</u>		MODEL NO

8. Q₁ SUCTION NOZZLE OUTLET CONE AND INLET TO SUCTION ELBOW

$$\begin{aligned}
 Q_1 &= Q_3 + \frac{1}{2} Q_6 + Q_8 \\
 &= 50 + \frac{1}{2} (200) + 10 \\
 &= \underline{\underline{160 \text{ GPM}}} \leftarrow
 \end{aligned}$$

9. Q₉ IMPELLER RETURN HOLES

$$\begin{aligned}
 Q_9 &= Q_5 + \frac{1}{2} Q_6 \\
 &= 569 + \frac{1}{2} (200) \\
 &= \underline{\underline{669 \text{ GPM}}} \leftarrow
 \end{aligned}$$

D. IMPELLER LABYRINTH SEAL CHECK

FROM ROCKETDYNE DIV., ROCKWELL INT.

$$Q_4 = 648 \text{ GPM}$$

$$Q_5 = 569 \text{ GPM}$$

$\Delta P_4 =$ DELTA PRESSURE (STATIC) ACROSS FRONT LABYRINTH SEAL

$$= 129.7 - 35.8 = 93.8 \text{ PSID}$$

$\Delta P_5 =$ DELTA PRESSURE (STATIC) ACROSS REAR LABYRINTH SEAL

$$= 126.9 - 39.7 = 87.2 \text{ PSID}$$

FRONT SEAL AVE. DIA. = 22.5 IN.

REAR SEAL AVE. DIA. = 20.45 IN.

DIAMETRAL CL. = 0.100 TO 0.110 IN.


AVE DIAMETRAL CL = 0.105 IN.

FRONT CASING DIA. = 22.5 + 0.105 = 22.605 IN.

REAR CASING DIA. = 20.45 + 0.105 = 20.555 IN.

$$\begin{aligned}
 \text{FRONT SEAL CL. AREA} &= \frac{(22.605^2 - 22.5^2) \pi}{4(144)} \\
 &= 0.02583 \text{ FT}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{REAR SEAL CL. AREA} &= \frac{(20.605^2 - 20.5^2) \pi}{4(144)} \\
 &= 0.02348 \text{ FT}^2
 \end{aligned}$$

PREPARED BY: RZK	 Rockwell International Atomics International Division	Page 144
CHECKED BY:		PAGE NO 13 OF
DATE: 3-22-78		REPORT NO N266TI000003
		MODEL NO

$$\text{FLOW IN FT}^3/\text{SEC} = KA (29 \Delta H)^{1/2}$$

$$\text{OR } K = \frac{Q}{A (29 \Delta H)^{1/2}} \frac{1}{448.83}$$

$$\Delta H = \Delta P \left(\frac{144}{50.971} \right)$$

WHERE: K = SEAL FLOW COEFFICIENT

$$\therefore K \text{ FOR FRONT SEAL} = \frac{648}{0.02583 (29 (93.9) \frac{144}{50.971})^{1/2}} \frac{1}{448.83}$$

$$= 0.428$$

$$K \text{ FOR REAR SEAL} = \frac{569}{0.02348 (29 (87.2) \frac{144}{50.971})^{1/2}} \frac{1}{448.83}$$

$$= 0.428$$

$$Re = \frac{d_h V \rho}{\mu}$$

WHERE: $d_h = \frac{4 (\text{CL AREA})}{\text{WETTED PERIMETER}}$, FT

$$V = \frac{Q_L}{A (448.83)}, \text{ FT/SEC}$$

$$\mu = \text{VISCOSITY}$$

$$= 0.5221 \text{ LB/FT HR}$$

$$\text{FRONT SEAL WETTED PERIMETER} = \frac{\pi (22.605 + 22.5)}{12}$$

$$= 11.81 \text{ FT}$$

$$\text{REAR SEAL WETTED PERIMETER} = \frac{\pi (20.555 + 20.45)}{12}$$


$$= 10.74 \text{ FT}$$

$$\therefore \text{FRONT SEAL } Re = \frac{4 (0.02583) 648}{11.81 (0.02583) 448.83} \frac{(50.971)}{0.5221 \frac{1}{3600}}$$

$$= 1.72 \times 10^5$$

$$\text{REAR SEAL } Re = \frac{4 (569) (50.971) (3600)}{10.74 (448.83) (0.5221)} = 1.66 \times 10^5$$

THE K VALUES FOR BOTH SEALS ARE OF REALISTIC VALUES BASED ON PREVIOUS ROCKETDYNE DATA (REF. 4) AND FROM THE RESULTS OF EA. JACKSON (ADDENDUM OF REF. 5).

PREPARED BY:	 Rockwell International Atomics International Division	Page 145
CHECKED BY:		PAGE NO 14 OF
DATE:		REPORT NO. N266TI000003
		MODEL NO.

THE LABYRINTH SEAL CONFIGURATION INCORPORATES FEATURES FROM BOTH REFERENCES, NAMELY:

1. STEP CONFIGURATION FROM REF. 4.

2. ROUNDED BACKS OF SLOPED RIBS FROM REF. 5

THE STEP CONFIGURATION RESULTS IN LOW LEAKAGE FLOWS COMPARED TO NON-STEPPED CONFIGURATIONS (REF. 4).

THE ROUNDED BACK ALSO RESULTS IN LOW LEAKAGE FLOWS, ESPECIALLY FOR SEALS WITH LARGE CLEARANCES (AS IN OUR DESIGN). THIS ROUNDED BACK DESIGN ALSO PROVIDES FOR EXCELLENT SHUT-OFF HEAD CHARACTERISTICS WHERE HIGH PUMP HEAD IS MAINTAINED, (REF. 5).

E. DRAIN AND VENT HOLE CHECK

VARIOUS DRAIN AND VENT HOLES LOCATED MAY ALLOW LEAKAGE FLOWS WITHIN THE PUMP. THESE HOLES ARE IDENTIFIED BY CIRCLED NUMBERS (SEE FIG. 2)

① INDUCER AND IMPELLER (FRONT SHROUD) HOUSING DRAIN HOLES = 15 GPM (SEE PG A4)

② IMPELLER DRAIN HOLES (2 EA, $\frac{1}{4}$ IN DIA.)

$$\Delta H = \frac{U_2^2 - U_1^2}{2g}$$

$$U_2 = \frac{\pi D_2 N}{720} = \frac{\pi (13.8) 1110}{720} = 66.8 \text{ FT/SEC}$$

$$U_1 = \frac{\pi D_1 N}{720} = \frac{\pi (11.2) 1110}{720} = 54.2 \text{ FT/SEC}$$


$$\Delta H = \frac{66.8^2 - 54.2^2}{2g} = 23.6 \text{ FT}$$

$$\Delta H = \frac{1.5V^2}{2g} + f \frac{L}{D} \frac{V^2}{2g}$$

$$= \frac{1.5V^2}{2g} + 0.0173 \frac{(4.8)}{0.25} \frac{V^2}{2g}$$

$$V = \left(\frac{2g \Delta H}{1.83} \right)^{\frac{1}{2}} = \left(\frac{2g (23.6)}{1.83} \right)^{\frac{1}{2}} = 28.8 \text{ FT/SEC}$$

$$Q = VA = 448.83 = 28.8 (0.000682) 448.83 = 9 \text{ GPM.}$$

PREPARED BY: <i>RKH</i>	 Rockwell International Atomic International Division	Page 146
CHECKED BY:		PAGE NO. 15 OF
DATE: 3-22-78		REPORT NO. N266TI000003
		MODEL NO.

③ DRAIN HOLES IN SHAFT EXTENSION (2 EA., $\frac{1}{4}$ IN. DIA.)

$$U_2 = \frac{\pi (3.6) 1110}{720} = 17.4 \text{ FT/SEC}$$

$$U_1 = \frac{\pi (2.4) 1110}{720} = 11.6 \text{ FT/SEC}$$

$$\Delta H = \frac{17.4^2 - 11.6^2}{2g} = 2.6 \text{ FT}$$

④ VENT HOLES IN SHAFT EXTENSION (2 EA., $\frac{1}{4}$ IN. DIA.)

$$U_2 = \frac{\pi (6.6) 1110}{720} = 32 \text{ FT/SEC}$$

$$U_1 = \frac{\pi (5.0) 1110}{720} = 24.2 \text{ FT/SEC}$$

$$\Delta H = \frac{32^2 - 24.2^2}{2g} = 6.8 \text{ FT}$$

⑤ DRAIN HOLES IN IMPELLER HUB (2 EA., $\frac{1}{4}$ IN. DIA.)

$$U_2 = \frac{\pi (5.3) 1110}{720} = 25.8 \text{ FT/SEC}$$

$$U_1 = \frac{\pi (3.7) 1110}{720} = 17.9 \text{ FT/SEC}$$

$$\Delta H = \frac{25.8^2 - 17.9^2}{2g} = 5.4 \text{ FT}$$

⑥ VENT HOLES IN IMPELLER HUB (2 EA., $\frac{1}{4}$ IN. DIA.)

$$U_2 = \frac{\pi (8.2) 1110}{720} = 39.7 \text{ FT/SEC}$$

$$U_1 = \frac{\pi (6.5) 1110}{720} = 31.5 \text{ FT/SEC}$$

$$\Delta H = \frac{39.7^2 - 31.5^2}{2g} = 9.1 \text{ FT}$$

REFERRING TO FIG. 2 ΔH ③ IS ACTING AGAINST ΔH ④ AND ΔH ⑤ IS ACTING AGAINST ΔH ⑥.


$$\therefore \Delta H ④ - \Delta H ③ = 6.8 - 2.6 = 4.2 \text{ FT}$$

$$\Delta H ⑥ - \Delta H ⑤ = 9.1 - 5.4 = 3.7 \text{ FT}$$

$$\text{AND } \Delta H ④ = 1.5 \frac{V^2}{2g} + 0.0173 \left(\frac{.75}{.25} \right) \frac{V^2}{2g} = 4.2 \text{ FT}$$

$$V ④ = \left(\frac{2g(4.2)}{1.55} \right)^{\frac{1}{2}} = 13.2 \text{ FT/SEC}$$

$$Q ④ = 13.2 (0.000682) 448.83 = 4 \text{ GPM}$$

PREPARED BY: <i>RKH</i>	 Rockwell International Atomics International Division	Page 147
CHECKED BY:		PAGE NO 16 OF
DATE: <i>3-22-78</i>		REPORT NO. <i>N266TI000003</i>
		MODEL NO.

$$\Delta H_6 = \frac{1.5V^2}{2g} + 0.0173 \frac{(.98)}{.25} \frac{V^2}{2g} = 3.7 \text{ FT}$$

$$V_6 = \left(\frac{2g(3.7)}{1.568} \right)^{\frac{1}{2}} = 12.3 \text{ FT/SEC}$$

$$Q_6 = 12.3(0.000682) 448.83 = 3.8 \text{ GPM.}$$

∴ RECIRCULATION FLOWS ARE:

$$Q_3 = 4 \text{ GPM}$$

$$Q_4 = 4 \text{ GPM}$$

$$Q_5 = 3.8 \text{ GPM}$$

$$Q_6 = 3.8 \text{ GPM}$$

SEE FIG. 2 FOR FLOW DIRECTION

BECAUSE AN ADDITIONAL 4 GPM FLOWS THROUGH THE SHAFT EXTENSION, Q_3 FLOWRATE IS CHECKED.

F. CHECK OF Q_3 FLOW THROUGH DRIVE SHAFT

$$\text{LET: } Q' = 49.8 + 4 = 53.8 \text{ GPM}$$

$$V' = \frac{53.8}{0.0207(448.83)} = 5.79 \text{ FT/SEC}$$

$$Re = \frac{50.971(5.79) \frac{1.95(3600)}{12}}{0.5221} = 3.3 \times 10^5$$

FROM CRANE, $f = 0.0182$

$$\Delta H = \frac{1.5(5.79)^2}{2g} + \frac{0.0182(13.9)(5.79)^2}{1.95(2g)}$$

$$= 0.85 \text{ FT}$$


$$K = 7.054 \text{ (SEE PG. A5)}$$

$$\therefore Q = 7.054 \sqrt{49.84 - .85} = 49.37 \text{ GPM}$$

$$\text{DECREASE IN FLOW} = 49.84 - 49.37$$

$$= 0.47 \text{ GPM (NEGLIGIBLE)}$$

$$\therefore \text{LET: } Q_3 = \underline{\underline{50 \text{ GPM}}}$$

PREPARED BY: <u>RZH</u>	 Rockwell International Atomic International Division	Page 148
CHECKED BY:		PAGE NO 17 OF
DATE: <u>3-22-78</u>		REPORT NO. <u>N266TI000003</u>
		MODEL NO.

G. PRIMARY FLOWRATES THROUGH PUMP

FROM PARA B, PAGES A1 AND A2, THE FOLLOWING FLOWRATES ARE OBTAINED:

$$1. Q_{DISCH} = \underline{14,500 \text{ GPM}} \leftarrow$$

$$2. Q_{INLET} = \underline{14,500 \text{ GPM}} \leftarrow$$

$$3. Q_{SUCT. EL.} = Q_{INLET} + Q_1 \\ = 14,500 + 160 = \underline{14,660 \text{ GPM}} \leftarrow$$

$$4. Q_{IND.} = Q_{SUCT. EL.} + Q_2 - Q_3 \\ = 14,660 + 85 - 50 \\ = \underline{14,695 \text{ GPM}} \leftarrow$$

$$5. Q_{IMP.} = Q_{IND.} + Q_3 + Q_4 - 15 \\ = 14,695 + 669 + 648 - 15 \\ = \underline{15,997 \text{ GPM}} \leftarrow$$

$$6. Q_{TRANS \text{ DIFF.}} = Q_{IMP.} - Q_4 - Q_5 \\ = 15,997 - 648 - 569 \\ = \underline{14,780 \text{ GPM}} \leftarrow$$

$$7. Q_{EXIST. \text{ DIFF.}} = Q_{TRANS \text{ DIFF.}} + Q_7 - Q_2 + 15 \\ = 14,780 + 131 - 85 + 15 \\ = \underline{14,841 \text{ GPM}} \leftarrow$$


$$8. Q_{DISCH} = Q_{EXIST. \text{ DIFF.}} - Q_6 - Q_7 - Q_8 \\ = 14,841 - 200 - 131 - 10 \\ = \underline{14,500 \text{ GPM}} \leftarrow$$



APPENDIX D

CUSTOMER DESIGN REVIEW
INTERMEDIATE SIZE INDUCER
PUMP (ISIP)

ESG Document N266DRR000003



SUPPORTING DOCUMENT

NUMBER
N266DRR000003

REV LTR/CHG NO.
1
SEE SUMMARY OF CHG

PROGRAM TITLE
Intermediate-Size Inducer Pump (ISIP)

DOCUMENT TYPE
Design Review Report

DOCUMENT TITLE
Customer Design Review Intermediate-Size Inducer Pump

KEY NOUNS
Inducer Pump

ORIGINAL ISSUE DATE
May 12, 1978

PREPARED BY/DATE DEPT MAIL ADDR
C. F. Sternburg 5/10/78 731 LB26

GO NO. S/A NO. PAGE 1 OF TOTAL PAGES
09280 23000 42
REL. DATE
10-18-78 SW

IR&D PROGRAM? YES NO IF YES, ENTER TPA NO. _____

SECURITY CLASSIFICATION
(CHECK ONE BOX ONLY) ERDA DOD (CHECK ONE BOX ONLY)
UNCL RESTRICTED DATA
CONF. DEFENSE INFO.
SECRET

APPROVALS DATE
L. E. Glasgow 5/12/78
E. Q. Cookwell 5-12-78

AUTHORIZED CLASSIFIER DATE

DISTRIBUTION

ABSTRACT

* NAME	MAIL ADDR
* R. V. Anderson	LB17
* E. G. Andrews	KB45
* R. W. Atz	T486
* J. A. Birg	LB39
* T. J. Boardman	LB39
* R. J. Bremner	LB49
* D. O. Cipra	LB35
* C. Dunn	LB39
* L. E. Glasgow	LB39
* G. Hallinan	LB26
* R. K. Hoshide	JB05
* E. D. Jackson	055-AC51
* P. G. Jencek	LB49
* A. T. Marsik	KB43
* C. P. Messina	LB03
* H. M. Minami	LB30
* E. M. Mouradian	LB35
* J. M. Nishizaka	LB35
* D. R. Paradise	NB14
* K. Rothe	
* M. Sasaki	055-AC14
* C. F. Sternburg	LB26
* J. E. Wolf	055-AB24
* J. M. Zorad	055-AC51
* N. K. Doshier	KB43
* N. A. Marrazzo	T482
* R. E. Schnurstein	LB11
* C. Q. Torrijos	LB26

This report documents the discussions of the customer design review for the Intermediate-Size Inducer Pump (ISIP). The meeting was held on May 9, 1978, and resulted in 28 action items and 10 recommendations. The design was given a conditional approval subject to the satisfactory completion of the action items and recommendations.

C.F. Sternburg 10-17-78
L.E. Glasgow 10/17/78

CHANGE I
ALL ACTION ITEMS RELEASED WITH THIS DRR HAVE BEEN SATISFACTORILY ANSWERED AND ARE NOW ON FILE IN ENGINEERING DATA.
REL. DATE 10-18-78

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY

RESERVED FOR PROPRIETARY/LEGAL NOTICES
THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, ERDA

This report was prepared as an account of work sponsored by the United States Government. Neither the U S Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.



Rockwell International

Atoms International Division

DESIGN REVIEW REPORT		DRR- N266DRR000003	
PROGRAM <u>ISIP</u>		REVIEW DATE <u>May 10, 1978</u>	
REVIEWED DOCUMENT NO. <u>See Page 4</u>			
DOCUMENT TITLE <u>Customer Design Review, Intermediate-Size Inducer Pump</u>			
TYPE OF REVIEW			
<input type="checkbox"/> CONCEPTUAL <input type="checkbox"/> PRELIMINARY <input type="checkbox"/> FINAL <input checked="" type="checkbox"/> SPECIAL EXPLAIN <u>Customer</u>			
REVIEW RESULTS			
<input type="checkbox"/> APPROVED <input type="checkbox"/> DISAPPROVED-RESCHEDULE <input type="checkbox"/> SEE REMARKS <input checked="" type="checkbox"/> CONDITIONALLY APPROVED Document(s) reviewed to be approved upon the satisfactory completion of all action items All action items will require a written answer or a copy of a released EO indicating completion for the DRB Files			
DESIGN REVIEW BOARD MEMBERS			
Name and Dept		Review Responsibility	
Name and Dept		Review Responsibility	
L. E. Glasgow 731	Chairman	R. W. Atz 720	Test
C. F. Sternburg 731	Administrator	R. J. Bremner 731	Mechanical Design
C. P. Messina 731	M&P	R. Karr	ANL
J. M. Nishizaka 731	Stress	G. Jacobson	HEDL
E. M. Mouradian 731	Thermal/Hydraulics		
E. G. Andrews 755	QA		
A. T. Marsik 784	Manufacturing		
K. Rothe	Hydrodynamics		
GUESTS			
<u>AI</u>		<u>Rocketdyne</u>	
<u>ANL</u>			
R. V. Anderson*	P. Jeneck	E. D. Jackson*	R. Jaross
T. J. Boardman* (PE)	G. Hallinan	J. E. Wolf* (PE)	
R. K. Hoshide*	H. Minami*	J. M. Zorad	<u>HEDL</u>
D. O. Cipra*	N. Marrazzo	M. Sasaki*	M. Young
C. Dunn	D. Paradise		<u>DOE</u>
N. K. Doshier	R. Schnurstein		K. Absher
*Presenter	C. Torrijos		J. Nulton
REMARKS			



DESIGN REVIEW REPORT

DRR- N266DRR000003

REVIEWED DOCUMENT NO. Page 4

SUMMARY

The purpose of the meeting was to review the intermediate-size inducer pump preliminary design as described in the documents listed on Page 4 of this report.

The intent of the review was to have the DRB assess that the preliminary design, as described during the presentation by the various disciplines, met all the requirements as depicted in Specification N266ST310001 and that these requirements were reflected in the design.

The Chairman requested that written comments be submitted by the Board Members on the critique of the data package, as indicated on the IL sent to the DRB.

The design review meeting was opened on May 9, 1978, by the Chairman, and after a brief introductory statement, the meeting was turned over to the responsible engineers for their presentations. During the course of the presentations, questions and concerns that were not satisfactorily resolved at the meeting resulted in action items. Those written comments by the DRB that did not result in action items are listed as recommendations.

The meeting was concluded by granting "Conditional Approval" to the design, subject to the satisfactory completion of the action items and recommendations.

All action items shall be resolved within 30 days from the date of the design review. Responses to the recommendations are due within 15 days of the design review. Responses to the action items and recommendations shall be forwarded to the Board Chairman and the Administrator by IL. Procedures of EMP 5-3, Design Reviews, apply.



DESIGN REVIEW REPORT

DRR- N266DRR000003

REVIEWED DOCUMENT NO. _____

SUMMARY

CUSTOMER DESIGN REVIEW
INTERMEDIATE-SIZE INDUCER PUMP
DATA PACKAGE

Review Items

N266R000015 Design Layout Drawing
N266ST310001 Pump Specification

Supporting Documents

N266E000002 Interface Control Drawings
N266SK00017 Rework Sketch for Static Hydraulics and Bearing Support
Flange
N266TI000002 Pump Shaft Rotodynamics
N266TI000003 Recirculating Flow Analyses
N266B0160001 Specification, CF8 Castings
N266B0160002 Specification, 304 Forging
R/H 8113-3630 Hydrodynamic Design Report
Steady-State Stress Analysis Summary Assembly Outline Procedure



DESIGN REVIEW REPORT

DRR- N266DRR000003

REVIEWED DOCUMENT NO. Page 4

SUMMARY
Agenda

Intermediate-Size Inducer Pump
Customer Design Review

Place: Conference Room 1
Time: 8:10 a.m., May 9, 1978
Attendees: AI, Rocketdyne, ANL, and HEDL

		<u>Approximate Time</u>
I.	Introduction	L. Glasgow 8:55 a.m.
II.	Project Description and Goals	R. V. Anderson 8:20 a.m.
III.	Design Approach	T. J. Boardman 8:30 a.m.
IV.	Description of Hydrodynamics Components	J. Wolf 8:55 a.m.
V.	Hydrodynamic Design Description	E. D. Jackson 9:15 a.m.
VI.	Systems Analysis Recirculation Flow Analysis	R. K. Hoshide 10:00 a.m.
VII.	Stress Analysis	H. Minami 10:20 a.m.
VIII.	Stress Analysis Rotordynamics	D. O. Cipra 10:30 a.m.
IX.	Stress Analysis Steady State	M. Sasaki 10:45 a.m.
X.	DRB Review of Documentation	Board 11:15 a.m.
XI.	Review of Board Poll and Con- tingent Sign-Off	



DESIGN REVIEW REPORT

DRR- N266DRR000003

ACTION ASSIGNMENTS

No	Description	Assigned to	Completion Date
	<p>The following comments are <u>action items</u> to which the responsible designers and project office agreed. A written response to the Chairman and a copy to each Board Member is required in 30 days stating what action was taken.</p> <p style="text-align: center;"><u>Specification N266T310001</u></p>		
1.	<p>Paragraph 3.1.1: Exhibit evidence that HEDL agrees with the requirements of this paragraph and the meaning of "minimized."</p>	Boardman/ Paradise	6/9/78
2.	<p>Paragraph 3.2.2.1: Add an equation as a footnote. Add a paragraph defining NPSH margin to the verification section.</p>	Boardman/ Paradise	6/9/78
3.	<p>Paragraph 3.2: Add the requirement to determine the locked rotor impedance of the pump.</p>	Boardman/ Paradise	6/9/78
4.	<p>Paragraph 3.2.2.1: Provide an inspection plan to include visual observation and replicas of the leading and trailing edges of the inducer and impeller.</p>	Andrews/ Paradise	6/9/78
5.	<p>Paragraph 3.2.3.1: Identify the requirement that goes into this paragraph.</p>	Boardman	6/9/78



DESIGN REVIEW REPORT		DRR- N266DRR000003	
ACTION ASSIGNMENTS			
No.	Description	Assigned to	Completion Date
6.	Paragraph 3.3.1: Add a parenthetical quantity stating that the stress report shall be signed by the manager of the stress group.	Paradise	6/9/78
7.	Paragraph 3.3.2: Add a paragraph to specify the requirements for vibration stiffness of the AI diffuser and inducer tunnel.	Boardman/ Paradise	6/9/78
8.	Compare the structural design requirements of the FFTF pump with those of the ISIP.	Boardman	6/9/78
9.	Paragraph 3.5.1, Part 5: Replace "bellows seal" with "piston ring" which fits into the bellows seal area. Modify the specification to remove "bellows."	Boardman/ Paradise	6/9/78
10.	Examine the impact of material dilation.	Friske/ Nishizaka	6/9/78
11.	Paragraph 3.5.3b: Remove the word "maximum" from the first sentence.	Paradise	6/9/78
12.	Paragraph 3.5.3b: Separate this paragraph into a heat treatment paragraph and a sensitization protection paragraph.	Friske/ Paradise	6/9/78
13.	Paragraph 3.5.3e: Remove the first sentence.	Paradise	6/9/78
14.	Paragraph 3.5.3e: Lock welding should be to the Code requirements.	Friske/ Paradise	6/9/78



DESIGN REVIEW REPORT		DRR- N266DRR000003	
ACTION ASSIGNMENTS			
No.	Description	Assigned to	Completion Date
15.	Table 3-II: Callout the efficiency requirements.	Boardman/ Paradise	6/9/78
16.	Table 3-II, Note 1: Reword to say that the pump shall not lose more than 3% head at the specified flow.	Boardman/ Paradise	6/9/78
17.	Table 3-II, Note 2: Correct "design objectives" to specific requirements.	Boardman/ Paradise	6/9/78
18.	Paragraph 4.1: Add the locked rotor test to this list.	Boardman/ Paradise	6/9/78
19.	Paragraph 4.2: Change the word "verified" to "assessed."	Paradise	6/9/78
20.	Paragraph 4.4.3" Reword this paragraph to add the deletion of the MTI probes.	Paradise	6/9/78
<u>Drawing Layout N266R000015</u>			
21.	Add to the general notes: Construct to the requirements of the ASME BPV Section III, Class 1.	Boardman	6/9/78
22.	Material callout should be added to the drawing.	Jencek	6/9/78
23.	Correct the weld symbols on the lock welds.	Friske/ Jencek	6/9/78
24.	Add "Revision 2" to the specification number in Note 4.	Paradise	6/9/78



DESIGN REVIEW REPORT		DRR- N266DRR000003	
ACTION ASSIGNMENTS			
No.	Description	Assigned to	Completion Date
25.	Prepare a radial tolerance analysis and compare it to the FFTF pump tolerance analysis.	Boardman/ Jencek	6/9/78
26.	Clear up the clearance of N266R000015 Layout Sheet 2.	Boardman/ Jencek	6/9/78
27.	Check the edges of the different assemblies during assembly operations. Add to the QA section "to check the clearances between the inlet elbow and the diffuser tunnel."	Boardman/ Paradise	6/9/78
<u>Support Documents</u>			
28.	Examine the torsional vibration criteria with respect to the blade passing frequency plus other excitations.	Nishizaka/ Cipra	6/9/78



DESIGN REVIEW REPORT		DRR- <u>N266DRR000003</u>	
RECOMMENDATIONS			
No	Description	Assigned to	Completion Date
	<p>The following comments are <u>recommendations</u> requiring a written response. If accepted, they become action items. Normally, responses to recommendations should be made within 15 days.</p> <p style="text-align: center;"><u>Specification N266T310001</u></p>		
1.	Paragraph 3.1.1.1: Look into the need of blueing to check the fit defined in this paragraph.	Andrews/ Doshier	5/25/78
2.	Paragraph 3.2.1: Put down all of the terms involved in the NPSH.	Boardman/ Paradise	5/25/78
3.	Paragraph 3.2.2.1: Move the verification section from the requirement section back to the verification section.	Boardman	5/25/78
4.	Paragraph 3.3.5: The specification should require that steps be taken to reduce the possibility of galling of the threaded fasteners.	Boardman	5/25/78
5.	Paragraph 3.5.1, Part 5: Justify aluminization of the piston ring seal compared to the use of stellite or other hard facing techniques.	Boardman	5/25/78
6.	Paragraph 3.5.3c: Review the requirements of this paragraph.	Boardman	5/25/78



DESIGN REVIEW REPORT		DRR- N266DRR000003	
RECOMMENDATIONS			
No	Description	Assigned to	Completion Date
	<u>Drawing Layout N266R000015</u>		
7.	Supply data to justify the saw tooth design.	Boardman	5/25/78
8.	Examine the natural frequency of the pump blading.	Boardman	5/25/78
	<u>Support Documents</u>		
9.	Make sure the impeller and the threads are dry after heating in water.	Boardman	5/25/78
10.	Examine the impact of the fact that the shaft is stepped at the taper.	Nishizaka	5/25/78

Internal Letter



Rockwell International

Date

No.

N266DRR000003

PAGE 12

TO

FROM

Name Organization Internal Address Phone

Design Review Board Members

L. E. Glasgow
731, 071-LB39

1372

Customer Design Review
Intermediate-Size Inducer Pump

The Design Review Board approves the preliminary
design of the Intermediate-Size Inducer Pump (ISIP)
as presented in the design
review meeting of May 9, 1978 and as exhibited in the following
documents:

See Page 4

The board approves the design provided that the action items and recom-
mendations are completed to the satisfaction of the board members:

Design *[Signature]*

M&P *[Signature]*

Stress *[Signature]*

Thermal/Hyd *[Signature]*

Reliability/Maintainability *[Signature]*

Quality Assurance *[Signature]*

Manufacturing *[Signature]*

Test *[Signature]*

Hydrodynamics *[Signature]*

ANL - R. Karr

MEEL G.O. Jackson

[Signature]
Design Review Chairman

[Signature]
Design Review Administrator

feh:624

L. E. Glasoow
731, 071-LB39

T. J. Boardman
731, 071-LB39


1759

Intermediate-Size Inducer Pump (ISIP)

Ref: N266DRR000003, Customer Design Review, Intermediate-Size Inducer Pump

Attached is a list of the steps planned by Project Engineering for resolution of the action items and recommendations listed in the referenced report for the pump layout drawing (N266R000015) and for the supporting documents. Please indicate whether additional effort, other than implementation, is required for resolution.

Response to the action items and recommendations against the specification was transmitted under separate IL.


T. J. Boardman

jdj:525

Attachment

cc: G. Hallinan
R. Anderson
C. Dunn
P. Jencek
W. Friske
J. Page
C. Torrijos
R. Schnurstein
J. Wolf (Rocketdyne)
D. Paradise
L. Woehler
C. Sternburg (12)

Att. to
IL to L. . .
May 25, 1978

DRR Action Items for Layout Drawing N266R000015

21. Comment: Add to the general notes: Construct to the requirements of the ASME BPV Section III, Class 1.
- Response: A note will be added to the drawing covering this requirement.
22. Comment: Material callout should be added to the drawing.
- Response: Material callouts for each part will be added to the layout drawing. Basically, the impeller will be CF8; all other points will be 304 forgings excepting the threaded fasteners and the tie bolt which will be A286.
23. Comment: Correct the weld symbols on the lock welds.
- Response: The lock weld symbols will be changed to show single V full penetration joints.
24. Comment: Add "Revision 2" to the specification number in Note 4.
- Response: The note will be changed to designate, "OMM-051-00-005, Revision 2, Addendum 1".
25. Comment: Prepare a radial tolerance analysis and compare it to the FFTF pump tolerance analysis.
- Response: A comparative radial tolerance analysis will be prepared for the region of concern. That is from the hydrostatic bearing down to the lower end of the rotor assembly.
26. Comment: Clear up the clearance of N266R000015, Layout Sheet 2.
- Response: The information shown on Sheet 2 during the design review will be transferred to the original layout (Sheet 1) with all pertinent clearances shown. The layout will then be issued as Revision A.
27. Comment: Check the edges of the different assemblies during assembly operations. Add to the QA section, "to check the clearances between the inlet elbow and the diffuser tunnel".
- Response: Checks, measurements, and other assembly monitoring functions will be specified in the OMM Addendum where

pump assembly directions will be written. These, in turn, will be described step-by-step in the detail assembly procedures to be written by ETEC and approved by AI. Assembly procedures include a signoff requirement for each step and provide forms for recording measurements. Completed assembly procedures become a part of test data.

7. Comment: Supply data to justify the saw tooth design.

Response: This comment resulted from a review meeting discussion concerning the ISIP labyrinth seal tooth spacing and the cavitation potential resulting from using three teeth widely spaced as opposed to closely spaced teeth in the prototype design.

The prototype pump front (lower) labyrinth is a "straight" (not staggered) type having a radial clearance of .100 in. (.050 in. for the back labyrinth) and a tooth spacing of .125 in. The tooth form is tapered (29 deg.) with a zero slant angle and a groove depth of .125 in. (reference WEMD Drawing 160A243). Thus, the tooth spacing, radial clearance, and groove depth (tooth height) were all of the same order of magnitude. The ISIP has a staggered (stepped) labyrinth with a radial clearance of .050 in. and a tooth spacing of approximately 1.0 in. The tooth form has a curved back (downstream side), is slanted against the direction of flow, and has a groove depth (tooth height) of 0.5 in. The ratio of radial clearance to tooth spacing is 0.1 as is the ratio of radial clearance to tooth height. The stepped arrangement and the low clearance-to-spacing ratio help minimize the velocity carryover effect, enabling each tooth to act more like an independent restriction with zero approach velocity, thus increasing the friction factor as shown in Figure 4 of Reference 1.^(a) The low clearance-to-tooth height ratio permits rapid expansion of the fluid stream after crossing the tooth, encouraging the formation of turbulent eddies (a loss effect).

Figure 7 of Reference 2^(b) illustrates the increased leakage effect of reducing tooth (blade) spacing for a fixed clearance, despite increasing the number of teeth. While the quantitative data of this reference

(a) Reference 1: W. Zabriskie and B. Sternlicht, "Labyrinth Seal Leakage Analysis," ASME Paper 58 A-118, Transactions of the ASME, Journal of Basic Engineering (contributed for the November 30-December 5, 1958, Annual Meeting, New York, New York)

(b) Reference 2: F. E. Heffner, "A General Method for Correlating Labyrinth-Seal Leak-Rate Data" Transactions of the ASME, Journal of Basic Engineering, June 1960 (Pages 265-275)

may not be directly applicable due to differences in tooth form and fluid compressibility (the reference was written for compressible flow), the proportional trends are shown to be consistent for low-pressure ratios (which correspond to low-pressure ratio function θ) where compressibility effects are minor.

The effects of slanting the tooth profile against the direction of flow is also illustrated in Figure 4 of Reference 1,^(a) showing that the friction factor for the slanted configuration is higher than for the nonslanted type.

Effects of the rounded back tooth form were presented in the review meeting by R. Hoshide. This data, plus additional data developed by General Motors for similar profiles, is being assembled and will be transmitted to the review board. The data shows the increased effectiveness of that particular profile.

In order to assess the potential for cavitation, the cavitation number will be evaluated at the minimum pressure following the last (third) labyrinth tooth for both the front (lower) and rear (upper) labyrinths. This data will be presented to the review board with the aforementioned profile data.

8. Comment: Examine the natural frequency of the pump blading.

Response: The natural frequency of the impeller and diffuser blading will be examined and compared to known exciting frequencies. As a sand casting with draft to be added by the foundry, results for the impeller are expected to be qualitative at best. However, since the impeller blades are supported on each side, as were the prototype impeller blades, they are expected to have a fairly high natural frequency which would be difficult to excite.

(a) Reference 1: W. Zabriskie and B. Sternlicht, "Labyrinth Seal Leakage Analysis," ASME Paper 58 A-118, Transactions of the ASME, Journal of Basic Engineering (contributed for the November 30-December 5, 1958, Annual Meeting, New York, New York)

DRR Action Items for Support Documents

28. Comment: Examine the torsional vibration criteria with respect to the blade passing frequency plus other excitations.

Response: The torsional vibration criterion as stated in Paragraph 3.3.2.9 of RDT E 3-2T reads "The first torsional and lateral critical speeds shall not be less than 125% of the design speed or as specified in the Ordering Data." The HWS 1551 ordering data does not modify this requirement.

For both the prototype pump and the ISIP, the design speed corresponds to a frequency of 18.5 Hz. Using the AI model, both pumps have a torsional frequency more than 142% above the design speed (26.69 Hz for ISIP and 26.34 Hz for the prototype); therefore, the rotating speed will not excite the torsional frequency.

The ISIP has ten impeller discharge vanes and eleven diffuser vanes, potentially generating pulses at 185 Hz, 2035 Hz, and 1850 Hz at design speed. At reduced speeds, these pulses will match the torsional critical frequency at 160 rpm, 14.5 rpm, and 16 rpm, none of which are in the steady-state operating range of the pump (94 rpm plus 400 to 1132 rpm). The 160 rpm will occur during the startup transient between pony motor speed (94 rpm) and minimum main motor speed (400 rpm) but will be for very short duration due to motor acceleration, and at low energy level due to the low speed. Other torsional excitation due to motor windings and rotor/starter slot combinations in the motor will remain unchanged. Therefore, no torsional vibration problems are predicted.

Similar to the ISIP, the prototype pump blade frequency matched the torsional critical frequency at 263 rpm which also occurred during startup transients. No vibration problems were observed during startups while sodium testing at SPTF.

DRR Recommendations for Support Documents

9. Comment: Make sure the impeller and the threads are dry after heating in water.
- Response: A requirement for drying the threads will be included in the OMM Addendum for assembling ISIP and in the ETEC assembly procedure, requiring specific signoff by the operator. Based on prototype pump assembly experience, the assembly temperature (~180°F) will greatly enhance drying for exposed tapped holes.
10. Comment: Examine the impact of the fact that the shaft is stepped at the taper.
- Response: The impact of the relief in the middle of the shaft taper will be examined by Rocketdyne (Sasaki) as part of the steady-state stress analysis.

Internal Letter

Rockwell Int.

DATE May 26, 1978

ATTACHMENT II

N266DRR000003
Page 19
Change 1

TO

L. E. Glasgow
731, 071-LB39

FROM

T. J. Boardman
731, 071-LB39

1759

N266ER000-001
Page 168

Intermediate Size Inducer Pump (ISIP)

Ref: N266DRR000003 Customer Design Review Intermediate Size Inducer Pump

Attached is a list of the steps planned by Project Engineering for resolution of the action items and recommendations listed in the referenced report for the pump specification (N266ST310001). Please indicate whether additional effort, other than implementation, are required for resolution.

Response to the action items and recommendations against the layout drawing and supporting documents will be covered under a separate IL.


T. J. Boardman

jew:4/1

Attachments

cc: R. Anderson
C. Dunn
W. Friske
C. Hallinan
R. Hoshide
P. Jencek
J. Page
D. Paradise
R. Schnurstein
C. Torrijos
L. Woehler
J. Wolf (Rocketdyne)
C. Sternburg (12)

I. DRR ACTION ITEMS FOR N266ST3100001

1. Comment - Paragraph 3.1.1: Exhibit evidence that HEDL agrees with the requirements of this paragraph and the meaning of "minimized."

Response - HEDL agreement with the requirements of this paragraph will be evidenced by HEDL approval of AI Drawing N266000017, "Intermediate Size Inducer Pump, Westinghouse Components (Rework)" which shows interface changes to be made on the FFTF pump parts. A statement will be added to 3.1.1 to the effect that all such changes shall be approved by HEDL prior to implementation.

2. Comment - Paragraph 3.2.2.1: Add an equation as a footnote. Add a paragraph defining NPSH margin to the verification section.

Response - The equation referred to was an equation for NPSH margin.

A period will be put after the second line in the second paragraph then reference to Paragraph 4.4.5 will be made.

Test requirements and an equation for NPSH margin will be added to Paragraph 4.4.5.

The equation will not be in a footnote since it will be part of a requirement (method of determining margin for this test) not an explanatory note.

3. Comment - Paragraph 3.2: Add the requirement to determine the Locked rotor impedance of the pump.

Response - This requirement will be added to the test requirements under Paragraph 6.2 instead of under Performance in 3.2, since there is no specified locked rotor resistance requirement for design or verification.

4. Comment - Paragraph 3.2.2.1: Provide an inspection plan to include visual observation and replicas of the leading and trailing edges of the inducer and impeller. See insert for 3.2.2.1 and 4.3.1.

Response - Requirements for pre- and post-test inspection including measurement, visual observation, and replicas will be included under 4.3.1.

5. Comment - Paragraph 3.2.3.1: Identify the requirement that goes into this paragraph.

Response - Paragraph 3.2.3.1 and 3.2.3.2 are being rewritten to specify the 12.8 ft NPSH requirement given in the Hydrodynamic Design Report (R/H 8113-3630) distributed as a supporting document for the design review.

6. Comment - Paragraph 3.3.1: Add a parenthetical quantity stating that the stress report shall be signed by the manager of the stress group.

Response - The stress report requires signature by manager of the stress unit and by the project engineer, as indicated in Table 1 on Page 10 of N266RPA000001 for this project.

7. Comment - Paragraph 3.3.2: Add a paragraph to specify the requirements for vibration stiffness of the AI diffuser and inducer tunnel.

Response - A paragraph stating that the pump shall be designed such that no malfunction or damage shall result from vibration will be added, similar to that in Paragraph 3.3.5.4 of Amendment 2 to RDT E 3-2T.

8. Comment - Compare the structural design requirements of the FFTF pump with those of the ISIP.

Response - Comparison of the structural design requirements has been made. Attachment 2 summarizes the results of this comparison. Generally, with a few additions (such as the vibration requirement), the ISIP requirements are comparable to those for FFTF when the limited life and noncritical function (test as opposed to primary system cooling) are considered.

9. Comment - Paragraph 3.5.1, Part 5: Replace "bellows seal" with "piston ring" which fits into the bellows seal area. Modify the specification to remove "bellows."

Response - These changes will be made to the specification.

10. Comment - Examine the impact of material dilation.

Response - It is presumed that this should be "material densification."

The impact of this phenomenon has been examined and the results of the examination are summarized in Attachment 3. Since information on this subject is severely limited, the results and conclusions represent our best judgement based on available data.

11. Comment - Paragraph 3.5.3b: Remove the word "maximum" from the first sentence.

Response - The word "maximum" will be removed.

12. Comment - Paragraph 3.5.3b: Separate this paragraph into a heat treatment paragraph and a sensitization protection paragraph.

Response - The two subjects will be separated into two grammatical paragraphs, both under 3.5.3b. The requirement is for heat treatment, which will be in the first paragraph. A result will be sensitization, which will be addressed in the second paragraph in terms of handling precautions to be followed. M&P, with Project Engineering concurrence, does not want these requirements under different paragraph numbers because one is a direct consequence of the other, therefore, the requirements should remain associated.

13. Comment - Paragraph 3.5.3e: Remove the first sentence.

Response - This paragraph will be revised to cover lock welding only and will specify AI requirements equivalent to those specified for lock welds on the FFTF prototype pump (See W EMD Drawing 114E829). The AI requirements were previously approved by HEDL for use in the pump.

The revision will implement removal of the first sentence.

14. Comment - Paragraph 3.5.3e: Lock welding should be to the Code requirements.

Response - See response for Action Item 13. Design of the locking devices will be based on using RDT M 6-2T as a guide.

15. Comment - Table 3-II: Callout the efficiency requirements.

Response - Efficiency requirements will be implied by specifying maximum shaft horsepower (equal to rated motor horsepower.)

16. Comment - Table 3-II, Note 1: Reword to say that the pump shall not lose more than 3% head at the specified flow.

Response - The note will be reworded as indicated.

17. Comment - Table 3-II, Note 2: Correct "design objectives" to specific requirements.

Response - Note 2 will be revised to require a negative slope between 8,000 and 18,000 gpm, corresponding to the estimated performance curve in the Hydrodynamic Design Report. The shutoff head goal will be deleted on the same basis.

These were originally requirements set for the FFTF prototype pump for operation in the FFTF plant. Since the ISIP is essentially a retrofit design to put the inducer and impeller in the same cavity as the prototype pump impeller, the same dimensional design flexibility needed to achieve those requirements is no longer available. Also the primary purpose of ISIP is for suction performance tests, as opposed to plant operation.

18. Comment - Paragraph 4.1: Add the locked rotor test to this list.

Response - A locked rotor test will be specified under 6.2.2. (see Action Item 7).

19. Comment - Paragraph 4.2: Change the word "verified" to "assessed."

Response - This change will be made to the specification.

20. Comment - Paragraph 4.4.3: Reword this paragraph to add the deletion of the MTI probes.

Response - The MTI probes will be added to those excepted instruments.

II. DRR RECOMMENDATIONS FOR N266ST310001

1. Comment - Paragraph 3.1.1.1: Look into the need of blueing to check the fit defined in this paragraph.

Response - The ISIP impeller bore will be machined to the same dimensions and tolerances as the FFTF impellers, which are interchangeable; therefore, a specification requirement for blueing should not be required in the specification (nor was it required in HWS-1551 or RDT E 3-2T.) However, like W EMD, AI will add this requirement to the assembly procedure as a precaution and final check on the fit.

2. Comment - Paragraph 3.2.1: Put down all of the terms involved in the NPSH.

Response - NPSH may be expressed in terms of a number of different variables, usually depending on those which can be measured. Instead of putting down the "terms," a word description will be provided allowing the use of engineer flexibility to select those measurable variables which can be combined to provide the correct value.

3. Comment - Paragraph 3.2.2.1: Move the verification section from the requirement section back to the verification section.

Response - This will be accomplished as part of the revision under Action Items 2 and 4.

4. Comment - Paragraph 3.3.5: The specification should require that steps be taken to reduce the possibility of galling of the threaded fasteners.

Response - The specification will include a requirement for mating surfaces of internal and external threads to be different materials and for thread lubricants to be used at assembly.

5. Comment - Paragraph 3.5.1, Part 5: Justify aluminization of the piston ring seal compared to the use of stellite or other hard facing techniques.

Response - Present plans are to aluminize the bore of the Type 304 steel cylinder. The piston ring will be made of Inco 718. This material combination has been discussed with the AI M&P Department, LMEC, and HEDL. Inco 718 against an aluminized surface has been tested in sodium at HEDL and found to have reasonable wear resistance. The thickness of the hard surface will be approximately 3-4 mils, of which approximately half will build up on the surface. Based on HEDL information, the expected friction coefficient is between 0.2 and 0.5. Stellite was not selected because of its high local heat input and the potential effects of its lower thermal expansion coefficient during thermal transients.

6. Comment - Paragraph 3.5.3c: Review the requirements of this paragraph.

Response - This paragraph will be reviewed carefully and revised as appropriate. From an initial reading, the intent of the paragraph is not clear, despite the fact that the requirement is explicit.

COMPARISON OF STRUCTURAL DESIGN REQUIREMENTS
OF FFTF PUMP WITH THOSE OF ISIP

- References:
- (1) RDT E 3-2T Centrifugal Free-Surface Sodium Pump with Electrical Drive, May 1971; including Amendment 1, February 1972, and Ammendment 2, June 1974.
 - (2) HWS-1551 LMFBR Low Capacity Prototype Pump--FFTF Primary Pump, Revision 1, January 1974, including Addendum 1P, June 1977.
 - (3) N266ST310001 Pump, Sodium, Inducer, Intermediate Size (ISIP.)

Structural design requirements for the FFTF pump are to be found under Paragraph 3.3.5, Structural Design, and its subparagraphs in both the RDT standard (Reference 1) and the ordering data (Reference 2.) Structural design requirements for the ISIP may be found under Paragraph 3.3, Design Requirements, in the pump sepcification (Reference 3.)

1. Allowable Stresses

- a. RDT E 3-2T Ammendment 1, Paragraph 3.3.5.1

Allowable stresses are to be in accordance with the Code, supplemented by Code Case 1331 and RDT F 9-1.

- b. N266ST310001, Paragraph 3.3.1 (refers to Table 3-III)

Table 3-III uses allowable stresses extracted from the Code and Code Case 1592-10 as guidance for high temperature (800^oF) application.

Code Case 1592 is an outcome of the initial high-temperature criteria developed on the FFTF program under RDT F 9-1 for application of Code Case 1331.

2. Earthquakes

- a. RDT E 3-2T, Paragraphs 3.3.5.2 and 3.4.4

Requires pump to be designed to seismic criteria specified in ordering data.

b. HWS-1551, Appendix A

States seismic design loads (JABE-WADCO-02) and performance requirements under various load categories (OBE, DBE, etc.)

c. N266ST310001

Since ISIP has no operational requirements during or after an earthquake, OBE and DBE type requirements are not applicable for the ISIP components. In the event of an earthquake, the pump can be stopped and the system drained immediately under an emergency operating procedure. The FFTF structure has already been analyzed by Westinghouse. The impeller/inducer assembly mass is of the same order of magnitude, but slightly lighter than the FFTF pump impeller, therefore, no additional loads will be applied to the pump shaft. The diffuser and shroud assembly will be checked against Uniform Building Code (UBC) requirements for this area, under a requirement to be added to the specification.

3. Vibration

a. RDT E 3-2T, Paragraph 3.3.5.4

Requires that design avoid damage or malfunction due to internally or externally excited vibration.

b. N266ST310001, Paragraph 3.3.2

An equivalent requirement is being added under Action Item 7 from the design review.

4. Thermal Stresses and Deflections

a. RDT E 3-2T, Paragraph 3.3.5.5

Requires analysis for transient induced stresses and deflections.

b. N266ST31001

Requires test transient effects to be analysed and results evaluated against Code criteria to determine permissible transients. Recirculation (internal) flows and calculated temperature distributions will be compared to the FFTF pump to determine whether additional deflection analyses are warranted.

5. Residual Stresses

a. RDT E 3-2T, Paragraph 3.3.5.6

Requires design to prevent damage or malfunction due to residual stresses or to utilize stress relief processes to relieve residual stresses.

N266DRR000003
Page 27
Change 1

- b. N266ST310001, Paragraph 3.5.3(b)

Requires heat treatment to achieve dimensional stability.

6. Creep

- a. RDT E 3-2T, Paragraph 3.3.5.7

Requires design to central or limited accumulated creep within limits required for satisfactory operation.

- b. N266ST310001, Paragraph 3.3.1 (refers to Table 3-III)

Specifies creep-fatigue and strain accumulation limits.

- c. N266ST310001, Paragraph 3.5.3(b)

Requires heat-treatment to achieve dimensional stability.

EXAMINATION OF THE IMPACT OF MATERIAL
DENSIFICATION ON ISIP COMPONENTS

The stainless steel internal components of the ISIP will be given a supplemental heat treatment intended to promote dimensional stability during subsequent sodium pump service. This heat treatment is designed to accelerate metallurgical transformations in the microstructure which increases the density and results in dimensional shrinkage of the component. Westinghouse reported that one FFTF sodium pump casting exhibited a density increase of 0.16% after the stabilizing heat treatment with no change during subsequent heating at 1050°F for 1,000 hr. HEDL is currently conducting a series of tests on cast CF-8 specimens to further evaluate the effectiveness of the heat treatment. The HEDL tests also indicate an increase in density, up to about 0.15%, following the heat treatment. In subsequent heating at 1050°F, a small additional increase in density of about 0.02% was also indicated during the first 500 hr, but there were no significant changes during continued exposures. To date, the HEDL specimens have completed more than 4,500-hr exposure time.

The above data indicate that the supplemental heat treatment does promote densification. Since the components will be final machined after the heat treatment, any further increase in density during sodium service should be minimal with no significant dimensional change.

Internal Letter



Rockwell Int'l

N266DRR000003

Page 29

Change 1

TO June 7, 1978

TC

ATTACHMENT III

FDCM

L. E. Glasgow
731, 071-LB39

T. J. Boardman
731, 071-LB39

1759 N266ER000-001
Page 178

Intermediate-Size Inducer Pump (ISIP)

- Ref:
- (1) IL dated May 25, 1978, Boardman to Glasgow, "Intermediate-Size Inducer Pump (ISIP)"
 - (2) N266DRR000003, Customer Design Review, Intermediate-Size Inducer Pump

Reference 1 was prepared in response to the action items and recommendations listed in Reference 2 for the design layout drawing (N266R000015) and for the supporting documents. The response to Recommendation 7 stated that the potential for cavitation in the labyrinth would be evaluated separately and transmitted to the review board with copies of the data used to determine the labyrinth profile.

Attached is AI's assessment of the cavitation potential which, based on the cavitation number, is not expected to present a problem. Also attached are copies of the two references upon which the profile and performance estimates were based. Please have this information transmitted to the Rockwell members of the review board as completion of Recommendation 7. Copies will be transmitted to non-Rockwell members of the board by the Program Office.


T. J. Boardman

lad:67

Attachments

cc w/attachment:

G. Hallinan
C. Dunn
P. Jencek
P. Ferry
J. Page
C. Torrijos
R. Schnurstein
J. Wolf
D. Paradise
L. Woehler
R. Hoshide

cc w/attachment and references for attachments:

R. V. Anderson (7)
C. Sternburg (10)

Subject: Summary of Intermediate Size Inducer Pump (ISIP) Impeller
Labyrinth Seal Design and Evaluation of Cavitation Potential

- Ref: (1) Crewdson, E., "Water-Ring Self-Priming Pumps,"
Vol. 170, No. 13, Institution of Mechanical Engineers,
Westminster, South Wales, 1956
- (2) Stocker, H. L., "Advanced Labyrinth Seal Design
Performance for High Pressure Ratio Gas Turbines,"
ASME Publication 75-WA/GT-22, New York, New York,
1975

INTRODUCTION

Because the impeller front and rear labyrinth seal configurations were changed from the original Westinghouse design, a briefing on the new seal design was presented at the ISIP Customer Design Review held at Atomics International on May 9, 1978. Charts 1 through 4 were presented at the briefing. A summary sheet on the important seal design parameters is also attached along with the two applicable references (References 1 and 2).

SUMMARY

Test results from E. A. Jackson showed that use of slanted round backed teeth gave the highest resistance to flow through the leakage passage. Shutoff pump head was 1-1/2 times higher when compared to the slanted flat topped teeth design. Flow had little tendency to enter the pocket in the flat topped design.

Test results from H. L. Stocker showed that increased internal seal cavity turbulence resulted in lower leakage compared to the baseline seal. Leakage rates were reduced from 10 to 29 percent during static tests. Comparable leakage rates from 11 to 25 percent reduction were obtained under rotating conditions. Results of the dynamic tests showed little effect on the leakage rates through the seal.

DISCUSSION

General

Impeller labyrinth seal leakages (front and rear) are important in any pump design. Leakage of these seals are recirculated through the impeller and results in efficiency penalties. This leakage can also affect the

head-flow curve under throttled conditions and especially the shutoff head. Rockwell experience has shown that standard straight circular groove labyrinth seal designs are very poor in reducing leakage of impeller labyrinth seals especially when the clearance gets large. Stepped configurations have shown to be much more effective (about 50% greater resistance) than the standard straight circular groove design.

Test Results of E. A. Jackson

Charts 1 through 4 were presented at the Customer Design Review and summarize the data obtained by E. A. Jackson (Addendum to Reference 1). Three different experimental test programs (stationary model, pump experiments, and large-scale model) were conducted to develop the form of teeth which offered the greatest resistance to water flow through a clearance gap.

Stationary model test results for the slanted flat topped and slanted round backed teeth are shown in Chart 2. Note that the round backed design gave the highest resistance to flow through the passage.

Pump experiments (Chart 3) demonstrated that with the slanted round backed design, 1-1/2 times more head was developed at shutoff. The slope of the head-flow curve remained negative and smooth. This characteristic is very desirable for large-scale breeder reactor (LSBR) sodium pumps. Reduction of leakage through the impeller labyrinth seals, especially during throttled conditions, will help maintain the desired negative slope pump characteristic.

Large-scale model tests (Chart 4) showed that flow had little tendency to enter the pocket in the flat topped design while flow tended to follow the round backed teeth. The rate of circulation was nearly twice that of the flat topped teeth. Based on previous Rockwell experience and from the results of E. A. Jackson (Reference 1), the ISIP impeller labyrinth seal design was obtained.

Test Results of H. L. Stocker

H. L. Stocker (Reference 2) conducted water tunnel studies, static air rig, and dynamic air rig tests with various labyrinth seal designs. All designs (nine each) were of the stepped configuration and many had slanted round backed teeth.

Water tunnel flow visualization tests were used as a preliminary evaluation of the turbulence generated by the candidate configurations. Results of these tests showed that increased internal seal cavity turbulence resulted in lower leakage compared to the baseline seal.

Static air rig test results demonstrated that leakage over a standard step seal was reduced from 10 to 29 percent with flow going from a larger diameter to a smaller diameter (as in our design).

Testing under rotating conditions up to 786 ft/sec resulted in lower leakage compared to the baseline seal from 11 to 25 percent. Results of

the dynamic tests showed little effect on the flow parameter characteristic of the seals and that the seals tested produced zero to 3.2 percent increase over the static flow parameter. This magnitude of change was within the accuracy of the test data.

ISIP Seal Design

Impeller labyrinth seal design parameters were obtained from the hydrodynamic analysis and are listed on Chart 5 for both front and rear seals. Note that since the front labyrinth seal leakage discharges between the inducer exit and impeller inlet, the static pressure is 35.8 psia. This pressure is high and should prevent cavitation. Also, the maximum fluid velocity through the labyrinth is only 56 ft/sec (low). The rear labyrinth seal leakage discharges into a zone where the static pressure is 39.7 psia. Again, this pressure is high and should prevent cavitation. Maximum fluid velocity through the labyrinth is also low at 54 ft/sec. For the front labyrinth, the minimum local cavitation number* across the last labyrinth blade would be 2.2 at 1050F if no flow contraction is assumed, as would be expected with the rounded backs. Since the rear labyrinth discharges to a higher pressure, 39.7 psia vs 35.8 psia, the last labyrinth blade would have a higher cavitation number. From this hydrodynamic analysis, cavitation is not anticipated to be a problem at either front or rear impeller labyrinth seal locations or in the zones where the leakage flows are discharged.

*

$$K = \frac{P - P_v}{1/2\rho V^2}$$

Where:

- K = cavitation number
- P = static pressure
- P_v = vapor pressure
- ρ = fluid mass density
- V = fluid velocity

;

CHART 1

JACKSON, E.A., "EXPERIMENTS TO DETERMINE THE BEST SHAPE AND NUMBER OF VANES FOR A GGE PUMP RUNNER," ADDENDUM TO CREWDSON, E., "WATER-RING SELF-PRIMING PUMPS," THE INSTITUTION OF MECHANICAL ENGINEERS, VOL. 170, NO. 13, WESTMINSTER, SOUTH WALES, 1956

- OBJECTIVE - DEVELOP THE FORM OF TEETH WHICH OFFERED THE GREATEST RESISTANCE TO WATER FLOW

- EXPERIMENTAL TESTING
 - STATIONARY MODEL
 - PUMP EXPERIMENTS
 - LARGE-SCALE MODEL

N266ER000-001
Page 182

N266DR000003
Page 33 Change 1

TEST SETUP




Fig. 13. Experimental Tooth Forms Tested in Stationary Model

ROUND
BACKED
TEETH

FLAT
TOPPED
TEETH

RESULTS




Fig. 14. Curves Showing Effect of Tooth Shape on the Flow Resistance

○ Passage 1/4 inch deep. ● Passage 1/4 inch deep.
+ Passage 1/2 inch deep. × Passage 1/2 inch deep.

- FLAT TOPPED TEETH - HIGHEST RESISTANCE TO FLOW WITH MINIMUM CLEARANCE
- ROUND BACKED TEETH - HIGHEST RESISTANCE TO FLOW WITH MAXIMUM CLEARANCE

CHART 3 PUMP EXPERIMENTS




Fig. 15. Performance Curves for Three Types of Pump Runner

- Vanes 35 deg., rounded backs.
- + Vanes 35 deg., flat tops.
- x Vanes 90 deg., flat tops.

- ROUND BACKED TEETH 1-1/2 TIMES MORE HEAD AT SHUTOFF
- 90° VANE CONFIGURATION HEAD DEVELOPED WAS CONSIDERABLY LOWER THAN FOR INCLINED VANES

CHART 4 LARGE-SCALE MODEL




Fig. 16. Large-scale Model of Water-ring Self-priming Pump

- Regions of high pressure.
- Regions of low pressure.
- Approximate line of maximum pressure downstream of tooth.

Length and directions of arrows represent approximate velocity and direction of flow.

- FLAT TOPPED TEETH

- FLOW HAD LITTLE TENDENCY TO ENTER POCKET

- ROUND BACKED TEETH

- FLOW TENDED TO FOLLOW ROUND BACKED TEETH
 - RATE OF CIRCULATION NEARLY TWICE THAT OF FLAT TOPPED TEETH

CHART 5
ISIP IMPELLER LABYRINTH SEAL DESIGN PARAMETERS

<u>DESIGN PARAMETER</u>	<u>IMPELLER LABYRINTH</u>	
	<u>FRONT</u>	<u>REAR</u>
LEAKAGE FLOW RATE, GPM	648	569
SEAL DELTA PRESSURE, PSID	93.8	87.2
DISCHARGE STATIC PRESSURE, PSIA	35.8	39.7
SEAL SPEED, FPS	109	99
AVERAGE DIAMETER, IN.	22.5	20.5
AVERAGE DIAMETRICAL CLEARANCE IN.	0.105	0.105
AVERAGE FLOW THROUGH AREA, IN. ²	3.72	3.38
AVERAGE FLUID VELOCITY, FPS	56	54

Internal Letter



Rockwell International
N266DRR000003
Page 38
Change 1

DATE June 13, 1978

No.

TO

FROM

Design Review Board Members

L. E. Glasgow
731, 071-LB39

1754 N266ER000-001
Page 187

Intermediate-Size Inducer Pump Design Review Action Items

Ref: N266DRR000003, Customer Design Review Intermediate-Size Inducer Pump

The Design Review Board Members have reviewed the action item responses and the updated referenced documents and concur with the implementation of the action items and responses to the recommendations. Approval of this IL by the board members listed below denotes that they concur with the responses to the design review action items.

Design *[Signature]*

M&P *C. P. [Signature]*

Stress *John M. [Signature]*

Thermal/Hyd *Edward M. [Signature]*

Hydrodynamics *[Signature]*

Quality Assurance *Edward G. [Signature]*

Manufacturing *G. J. [Signature]*

Test *Robert W. [Signature]*

[Signature]
Design Review Chairman

[Signature]
Design Review Administrator

cp:2/4

June 19, 1978

N266DRR000003
Page 39
Change 1

Design Review
Board Members

L. E. Glasgow
731, 071-LB39

1754

Intermediate-Size Inducer Pump Design Review Action Items

Ref: N266DRR000003, Customer Design Review Intermediate-Size
Inducer Pump

The Design Review Board Members have reviewed the action item responses and the updated referenced documents and concur with the implementation of the action items and responses to the recommendations for the Equipment Specification (N266ST310001). Approval of this letter by the board members listed below denotes that they concur with the responses to the design review action items for this document. This form is for signature by non-Rockwell board members. A similar Internal Letter form will be signed by Rockwell board members.

Argonne National Laboratory _____
R. Karr

Hanford Engineering Development Laboratory _____
G. Jacobson

L. E. Glasgow
Design Review Chairman

Charles F. Sternburg
Design Review Administrator

Internal Letter

N266ER000-001
Page 189

June 19, 1978

N 266DRR000003

Page 40

Change 1

L. E. Glasgow
731. 071-L839

1754

Design Review
Board Members

*Tel-copy To
R.V. Anderson AI
RK*

Intermediate-Size Inducer Pump Design Review Action Items

Ref: N266DRR000003, Customer Design Review Intermediate-Size Inducer Pump

*Mail Out
to Anderson*

cc RK

The Design Review Board Members have reviewed the action item responses and the updated referenced documents and concur with the implementation of the action items and responses to the recommendations for the Equipment Specification (N266ST310001). Approval of this letter by the board members listed below denotes that they concur with the responses to the design review action items for this document. This form is for signature by non-Rockwell board members. A similar Internal Letter form will be signed by Rockwell board members.

Argonne National Laboratory

R. Karr 6/22/78

R. Karr

Hanford Engineering Development Laboratory

G. Jacobson

L. E. Glasgow

Design Review Chairman

Charles H. Sternburg

Design Review Administrator

*to Bob
Hoshida*

Jbv:1/4

Internal Letter

N266ER000-001
Page 190

Rockwell International
N266DRR000003
Page 41
Change 1

Date June 30, 1978

TO Name, Organization, Internal Address
Design Review
Board Members

L. E. Glasgow
731, 071-LB39

1754

Subject Intermediate-Size Inducer Pump Design Review Action Items

Ref: N266DRR000003, Customer Design Review Intermediate-Size Inducer Pump

The Design Review Board Members have reviewed the action item responses and the updated referenced documents and concur with the implementation of the action items and responses to the recommendations for the ISIP Design Layout, (N266R000015, D2 release). Approval of this letter by the board members listed below denotes that they concur with the responses to the design review action items for this document. This form is for signature by non-Rockwell board members. A similar Internal Letter form will be signed by Rockwell board members.

Argonne National Laboratory

R. Karr

Hanford Engineering Development Laboratory

G. Jacobson

L. E. Glasgow
Design Review Chairman

Charles G. Sternburg
Design Review Administrator

jbv:629

June 30, 1978

TO

Design Review
Board Members

L. E. Glasgow
731, 071-LB39

1754

Intermediate-Size Inducer Pump Design Review Action Items

Ref: N266DRR000003, Customer Design Review Intermediate-Size Inducer Pump

*Tel-Copy
To R.V.
Anderson
A.I.
Mail Only
to
Anderson*

The Design Review Board Members have reviewed the action item responses and the updated referenced documents and concur with the implementation of the action items and responses to the recommendations for the ISIP Design Layout, (N266R000015, D2 release). Approval of this letter by the board members listed below denotes that they concur with the responses to the design review action items for this document. This form is for signature by non-Rockwell board members. A similar Internal Letter form will be signed by Rockwell board members.

*cc R K
DN*

Argonne National Laboratory

** R. Karr 10/10/78*

R. Karr

Hanford Engineering Development Laboratory

G. Jacobson

Lyle S. Glasgow Design Review Chairman
Charles H. Sternburg Design Review Administrator

** The draft Test Request N266 RFT 000001 Section 7.6.1 Interim Disassembly Inspection, Data Collection, has a Note that reads, "This data set will include detail inducer measurements to be performed by AI." I recommend the Test Request be amplified to require carbon chrome replicates and electron microscope photos be taken of the replicates as part of the before, interim and final inspection steps.*

Jbv:629

RIC




APPENDIX E

ROTOR DYNAMICS OF THE INTERMEDIATE
SIZE INDUCER PUMP (ISIP)

ESG Document N266TI000002

Pages A2 thru A23 and B2 thru B93 (computer printout) have been removed from this document for brevity.

 Rockwell International <small>Atomic International Division</small>		SUPPORTING DOCUMENT		NUMBER N266TI000002	REV LTR/CHG NO. SEE SUMMARY OF CHG
PROGRAM TITLE Intermediate Size Inducer Pump				DOCUMENT TYPE Technical Information	
DOCUMENT TITLE Rotordynamics of the Intermediate Size Inducer Pump (ISIP)				KEY NOUNS Pump Shaft, Rotordynamics	
PREPARED BY/DATE D. O. Cipra				ORIGINAL ISSUE DATE	
DEPT 731		MAIL ADDR LB35		GO NO. S/A NO. PAGE 1 OF 09280 22000 TOTAL PAGES 127	
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				REL. DATE 9-22-72	
SECURITY CLASSIFICATION					
APPROVALS R. M. Minami		DATE 3/2/78		(CHECK ONE BOX ONLY)	
				(CHECK ONE BOX ONLY)	
				UNCL <input checked="" type="checkbox"/> DOE <input type="checkbox"/> DOD <input type="checkbox"/> RESTRICTED DATA <input type="checkbox"/>	
				CONF. <input type="checkbox"/> DEFENSE INFO. <input type="checkbox"/>	
				SECRET <input type="checkbox"/>	
AUTHORIZED CLASSIFIER				DATE	
DISTRIBUTION			ABSTRACT		
*	NAME	MAIL ADDR	<p>This report documents the analysis performed to determine the critical shaft speeds for the FFTF Primary Pump with the AI-designed Inducer/Impeller attached to the unaltered pump shaft.</p> <p>The results indicate that the proposed arrangement would have a first lateral critical shaft speed of 22.1 Hz (1330 rpm). This speed is 121% of the shaft design speed (1100 rpm). The torsional critical shaft speed was found to be 26.7 Hz (1618 rpm).</p> <p style="text-align: center;">THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, ERDA</p> <p>This report was prepared as an account of work sponsored by the United States Government. Neither the U.S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.</p>		
+	R. V. Anderson	LB17			
+	T. J. Boardman	LB39			
*	D. O. Cipra	LB35			
	C. C. Conners	LB30			
	P. Jencek	LB49			
+	H. M. Minami	LB35			
*	J. M. Nishizaka	LB35			
	C. Q. Torrijos	LB26			
	H. C. Wieseneck	LB13			
731-V. 90/bes			+ Complete Document without Appendix B		
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY					

INDEX

	<u>Page</u>
INTRODUCTION.....	3
SUMMARY.....	4
DISCUSSION.....	5
CONCLUSIONS.....	10
REFERENCES.....	11
APPENDIX A (CRT PLOTS).....	A1
APPENDIX B (COMPUTER OUTPUT).....	B1

INTRODUCTION

The purpose of this report is to document the rotordynamic analysis of the Intermediate Size Inducer pump (ISIP). This study was performed to determine the rotordynamic effect of installing the AI-designed inducer/impeller subassembly in the existing FFTF primary pump. The pump shaft during this conversion was left unchanged, and, therefore, the dynamic finite element shaft model of the original FFTF pump was remodeled using the proposed inducer/impeller mass and stiffness properties.

SUMMARY

The rotordynamic analysis performed indicates that the ISIP rotating assembly exhibits little change in frequency when compared to that of the FFTF primary pump. This is because the change of effective mass (both translational and rotational) of the hydraulic assembly is practically negligible compared to the overall mass of the rotating assembly.

The first lateral critical shaft speed was found to be 22.1 Hz (121% of the shaft operating speed), and the critical torsional speed was found to be 26.7 Hz (147% of the shaft operating speed).

DISCUSSION

Method of Analysis



The FFTF pump rotor with the inducer/impeller was modeled using the finite element program SAPV (Reference 1). Since the pump shaft is left unchanged, with only the rotating hydraulic assembly being changed, the basic computer rotordynamic model developed for the FFTF pump (Reference 2) was used. The mass properties of the rotating assembly were calculated based on a preliminary drawing of the inducer/impeller (see Figure 1). The calculated mass properties are presented in Table 1.

TABLE 1. COMPUTED MASS DATA FOR INDUCER/IMPELLER

Item	Weight (lb)	Polar Moment of Inertia (lb-sec ² -in.)	Diametrical Moment of Inertia (lb-sec ² -in.)
Inducer	160.	26.6	18.4
Impeller	1025.	500.	376.

Analytic Model

The SAPV ISIP rotordynamic model is presented in Figure 2. The shaft portion of the model is left unchanged from the Westinghouse FFTF primary pump rotordynamic analysis (Reference 2). The computer listing of the Westinghouse model was provided in their report and was used as input data in AI's model. To verify that the model was accurate, the initial FFTF configuration was dynamically analyzed and compared to the FFTF results. The first lateral frequency calculated was 2.5% lower than the Westinghouse



- SHAFT FINAL MACHINING 14 E 727 (R)
- BEARING SUPPORT MACHINING 14 E 939 (R)
- KEY HEAD AND SCREW 16 PL NO 12-0022-0509 (R1) 3/8-10 UNC-2B 2H 16 PL
- DIFFUSER VANES ASSY OF ISIP 20019602 (R0)
- IMPELLER ISIP 20019601 (R0)
- BOLT 20 PL NO 12-0024-0303 (R1)
- ASSEMBLY WELDING/MACHINING 14 E 727 (R)
- WASHER TAB LOCK 20 PL 20019605 (R0)
- SEAL BELLOWS ISIP N266E000016 (R1)
- PUMP SHAFT INSERT ISIP N266E000018 (R1)
- TAG ISIP 16 PL N266E000022 (R1)
- INDUCER ISIP 20019601 (R0)
- CG IMPELLER (1025 LBS) 5009-9UN-2B (2H) 3/8-10 UNC-2B (2H) 500-13 UNK-3B (2H) 14 PL
- PN DIFFUSER ORIENTATION ISIP N266E000021 (R1)
- KEY INDUCE ISIP 20015502 (2H) 9 PL USE 12 BOLT (R1) 14 PL USE MS 24676-101 (BOLT) (2H) 6 PL THE BOLT ISIP N266E000019 (R1)
- CG INDUCE (160 LBS) 155-18 UNK-3B (2H) 9 PL USE MS 24676-33 (BOLT) (2H) 325-18 UNK-2B (2H) 9 PL USE MS 24676-61 (BOLT) (2H) 325-81-2B (2H)
- PUMP SHAFT NUT ADAPTER ISIP N266E000020 (R1)
- CG NUT (65 LBS) 275-81-2B (2H)

- 1 THE LAYOUT IS BASED ON WESTINGHOUSE COMPONENTS HAVING 3/8 CENTER PER DRAWING N266SK000017 (R1)
- 2 REFERENCE CONTROL DIMENSIONS PER N266E000002 (R1) CLEARANCE STUDY PER N266SK000011 (R1)
- 3 SEE ALL SYMBOLS OF REFERENCED DRAWINGS: (R1) ROCKWELL INTERNATIONAL (R2) WESTINGHOUSE DIVISION (R3) WESTINGHOUSE ELECTRIC CORPORATION
- 4 ASSEMBLY AND DISASSEMBLY PER OHM-051-00-805 ADDENDUM 1
- 5 3/8 NAME BALANCE OF ROTATING PARTS PER SPEC N266S1270000 (R1)
- 6 3/8 LOCATION OF MATERIAL AVAILABLE FOR MACHINING TO BALANCE A COMPONENT
- 7 3/8 PASSAGE FOR 3/8 VENTING, 3/8 DRAINING
- 8 3/8 TENSION NUT IS TO BE READ: MAX TIGHT (INDICATED BY Y) LOOSE (CLEARANCE ID), THIS ARE GIVEN PER 3/8 CENTER.
- 9 3/8 DIMENSIONS FOR ASSEMBLY, DISASSEMBLY, HANDLING (HOISTING), TOOLING
- 10 3/8 PEOPLE IN FINAL ASSEMBLY
- 11 3/8 ORIENTATION OF DIFFUSER VANES TO BE ESTABLISHED PER DRAWING N266SK000017 (R1) 5, 6 & 7.
- 12 3/8 CALCULATED VOLUME OF RESIDUAL SOLID IN UNGRAINED POCKETS 48 IN³
- 13 3/8 SYMBOL 3/8 INDICATES 3/8 PLACE OF CENTER

Rockwell International Corporation
 Altonna International Division
 CANADA PARK, CALIFORNIA

FIGURE 1
 INTERMEDIATE SIZE INDUCE
 PUMP (ISIP) LAYOUT
 N266E000015

CHECKING PRINT

IN WERE
 DOCUMENT NOT RELEASED

NOT ASSY
 FOR THE
 FOR THE
 FOR THE

DATE

SCALE FULL SIZE

DRAWING SIZE J

17 OF 19




Figure 2. Dynamic Stick Model of ISIP

Atomics International

NO . N266TI000002

PAGE . 8

results. The model was also checked for accuracy, and no "bugs" were found to exist. This difference in the two frequencies is considered to be within the allowable tolerance between two different finite element programs. The torsional frequency was found to be high by 9% when compared to the FFTF results.

In the real sense, the pump shaft is a free-free system in the torsional direction, and SAPV is unable to solve this problem. In order to make the model stable, a relatively soft torsional spring is added to the motor rotor. This first frequency is a fictitious type mode with the shaft acting as a rigid body and does not affect the true shaft torsional frequency. This was verified by lowering the torsion spring-rate and noting an insignificant change in the true torsional frequency.

Results of Analysis

The significant natural frequencies and their descriptions are presented in Table 2. The results show the ISIP first critical shaft frequency of 22.13 Hz (1,328 rpm). The plotted mode shape is presented in Appendix A. This speed is 121% of the running speed of the pump. Note that there exists some discrepancy between the frequencies obtained from the AI model of the FFTF primary pump and the Westinghouse model. However, the change in frequencies when the inducer/impeller is used is small, suggesting that the installation will have little effect on operating dynamics. The torsional frequency of the ISIP will be higher (as noted in Table 2) because of the lower radius of gyration of the ISIP inducer/impeller.

TABLE 2. ISIP CRITICAL SHAFT FREQUENCIES
AND MODE DESCRIPTIONS

Mode	Calculated Natural Frequencies (Hz)			Mode Description
	ISIP	FFTF (AI Model)	FFTF (Westinghouse Model)	
1	.28	.28	--	*Fictitious Rigid Body Mode
2	22.14	22.14	22.87	First Pump Shaft Lateral Frequency (Critical shaft speed)
3	25.08	25.08	25.36	Motor Shaft First Lateral Frequency
4	26.69	26.34	23.95	Motor/Pump Shaft Torsional Frequency

* Required to make the SAPV model stable in the torsional direction

CONCLUSIONS

Based on the observation that little change (less than 2%) in frequency is noted with the inducer/impeller hydraulic assembly in place of the existing impeller on the FFTF primary pump, the following conclusion is made: Assuming an inducer/impeller balancing procedure consistent with the procedure used on the original FFTF pump impeller, there will be a minimal effect on the mechanical vibrational response of the ISIP.

Atomics International

NO . N266TI000002
PAGE . 11

REFERENCES

1. SAPV, "Structural Analysis Program," E. Wilson, University of California, Berkeley, California, USC Version - 1976
2. "FFTF Primary Pump Rotor Dynamics Analysis," Engineering Memorandum No. 4708, Revision 2, by L. C. McNutt, Westinghouse Electric Corporation, Electro-Mechanical Division, Cheswick, Pennsylvania, February 9, 1977

Atomics International

NO . N266T1000002
PAGE . A1

APPENDIX A

SAPV CRT PLOTS

(Plots removed for brevity)

Atomics International

NO . N266TI000002
PAGE . B1

APPENDIX B

SAPV COMPUTER OUTPUT


(Computer printout removed for brevity)



APPENDIX F

RADIAL TOLERANCE STACKUP - ISIP

ESG Document N266TI000004

 Rockwell International <small>Atomics International Division</small>		SUPPORTING DOCUMENT		NUMBER N266TI000004	REV LTR/CHG NO. A <small>SEE SUMMARY OF CHG</small>
PROGRAM TITLE Intermediate-Size Inducer Pump				DOCUMENT TYPE Design Verification	
DOCUMENT TITLE Radial Tolerance Stackup - ISIP				KEY NOUNS Radial Stackup	
PREPARED BY/DATE M. Grisham 11/28/78				DEPT 731	MAIL ADDR LB26
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				GO NO 09280	S/A NO. 21000
APPROVALS C. Torrijos 8-14-78 T. Boardman 8-14-78 R. V. Anderson 8-14-78				ORIGINAL ISSUE DATE 5-10-79 PK	
SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)				(CHECK ONE BOX ONLY)	
UNCL <input checked="" type="checkbox"/>				RESTRICTED DATA <input type="checkbox"/>	
CONF <input type="checkbox"/>				DEFENSE INFO <input type="checkbox"/>	
SECRET <input type="checkbox"/>				AUTHORIZED CLASSIFIER _____ DATE _____	
DISTRIBUTION			ABSTRACT		
*	NAME	MAIL ADDR	<p>A radial stackup analysis for the Intermediate Sodium Inducer Pump (ISIP) has been performed to determine the minimum-maximum clearances between the rotating and stationary components at room temperature. The effect of transient temperatures to these clearances will be determined as a part of the thermal transient analysis. The calculated radial clearances at the inducer blade tip for the four conditions examined are:</p> <ol style="list-style-type: none"> 1. .050-.055 in. for all fits and bearing clearance being concentric 2. .069-.036 in. for maximum parallel offset of all fits and clearances of static/hydraulic diffuser assembly and impeller assembly 3. .077-.028 in. for maximum parallel offset of all fits and clearances, and maximum angularity of stationary components 4. .0930-.0120 in. for worst condition of parallel offsets and angularity 		
*	R. V. Anderson (8)	LB07			
*	H. Minami	LB30			
*	E. Andrews	KB45			
*	T. Boardman	LB39			
*	R. Bremner	LB49			
*	N. Doshier	KB43			
*	P. Pastor	KB07			
*	J. Nishizaka	LB35			
*	J. Page	LB03			
*	D. Paradise	NB14			
*	C. Dunn	LB39			
*	C. Torrijos	LB26			
*	P. Jencek	LB26			
731-Y-27/jdj			RESERVE FOR PROPRIETARY/LEGAL NOTICES ORIGINAL OF THE PATENT BRANCH, ERDA This report was prepared as an account of work sponsored by the United States Government. The U.S. Government, nor any of its employees nor any of its contractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.		
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY					

Energy Systems Group

NO. N266TI000004
PAGE 1.

REV	SUMMARY OF CHANGE	APPROVALS AND DATE
A	<p>Page 16 was deleted. It is no longer a controlling fact. The possible .002 offset between the diffuser and diffuser shroud was added to tolerance Stackup.</p> <p>For condition 4, possible tilt of inducer was changed to .0080 from .0045.</p> <p>Condition 5 was added.</p>	<p><i>M. Brisham</i> <i>R. V. Duda</i> 5-10-79 <i>J. Berman</i> <i>W. Souin</i> 5/10/79 Rel. Date: 5-10-79 BK</p>

CONTENTS

	<u>Page</u>
I. INTRODUCTION.....	3
II. APPLICABLE DRAWINGS.....	4
III. SUMMARY.....	5
IV. COMPUTATION.....	7
A. Condition 1.....	7
B. Condition 2.....	14
C. Condition 3.....	19
D. Condition 4.....	24
E. Condition 5.....	



I. INTRODUCTION

The existing FFTF primary sodium pump is used in the hot leg of the reactor heat transport system. It is designed to pump liquid sodium at 1050⁰F temperature, with the low 350⁰F temperature of transient slugs. The flow rate is 14,500 gpm, with total head of 500 ft. The FFTF prototype sodium pump was fabricated by Westinghouse (EMD) and initially tested in the sodium test facility (SPTF) in the Energy Technology Engineering Center (ETEC). To build the Intermediate-Size Inducer Pump (ISIP), the prototype sodium pump is to be modified by HEDL to facilitate interchangeable installation of an inducer type pump, engineered and fabricated by Rockwell International. The rework involves modification of the Westinghouse bearing support flange for a closer control of axial dimension and of normality, and of the static hydraulics for a control of axial size and flatness. All rework is to be performed per AI Drawing N266000017.

This analysis was performed to demonstrate that the radial clearances of assembly will be adequate to prevent rubbing. Evaluation of the results was by magnitude of the calculated minimum clearances and comparison of these values for those in the FFTF Prototype Pump which was tested under similar conditions in SPTF without evidence of rubbing. Completion of this analysis completes the Engineering response for Action Item No. 25 in the ISIP design review report (N22DRR000003).

The computed radial clearances for selected location are performed for four conditions with progressively compounding effects.



II. APPLICABLE DRAWINGS

Item	Drawing Number	Revision	Title
1	114E799	14	Shaft, Final Machining Prototype
2	114E939	8	Bearing, Support Machining, Sodium Pump
3	114E727	14	Assembly, Welding and Machining, Sodium Pump
4	115E116	7	Bearing Assembly
5	R0019601	NC	Impeller - Intermediate-Size Inducer Pump (AI Sodium Pump)
6	R0019602	NC	Diffuser/Vanes - Assembly of Intermediate-Size Inducer Pump (AI Sodium Pump)
7	R0019603	NC	Inducer - Intermediate-Size Inducer Pump (AI Sodium Pump)
8	N266000012	D1	Pump Shroud Insert - ISIP
9	N266000017	D2	Intermediate Size Inducer Pump, Westinghouse Components Rework Sketch (ISIP)



III. SUMMARY

The computations of radial clearances indicate a minimum gap .012 in. wide between rotating component R0019603 (inducer) and stationary R0019602 (diffuser assembly) in Location "J" of Condition 4, at ambient temperature.

Although mathematically this condition is possible, the stackup of multiple adverse coincidences in maximum values is improbable and represents a hydrostatic bearing failure mode by film depletion expressed in Condition 2. Due to R0019603 rotation, the value "J" in Condition 4 is extreme in one location only, as defined by the plane of maximum tilt of Part R0019602.


All values of radial gaps, in specific locations and under cited conditions, are summarized on Page 6.

Computation of radial gap values are to be found on Pages 7 through 32.

REV	DESCRIPTION	DATE	APPROVED

NOTED UNLESS OTHERWISE SPECIFIED ON THIS DRAWING

- ① DIMENSIONS .XXX INDICATE MIN-MAX VALUES PER RADIUS BASED ON DRAWING TOLERANCES
- ② DIMENSIONS [XXX] INDICATE MIN-MAX VALUES PER RADIUS BASED ON AVERAGE OF MEASURED ("AS BUILT") SIZES
- ③ .XXX INDICATES A SIZE OF RADIAL GAP ON OPPOSITE SIDE BASED ON MAX SIZES OF CONDITION 1.
- ④ FOR CLARIFICATION OF MOVEMENTS SEE NOTE IN COMPUTATION SHEETS



CONDITION:	LOCATION	A	B	C	D	E	F	G	H	J	K	L	M	N	O	P	R	S	T	U	V	
① ①	1 NOMINAL ASSEMBLY (CONCENTRIC GAUGE)	.010 .012	.050 .055	.000 .001	.300 .380	.005 .012	.050 .055	.035 .110	.000 .002	.050 .085	.085 .130	.075 .090	.0475 .0625	.025 .035	.0475 .0625	.020 .030						
② ②	2 A-.000 SHAFTHOLE TO FIT SHAFTHOLE AND THE 1/2" OFFSET RADIUS OF G. AND SHAFTHOLE OFFSET RADIUS OF G. AND SHAFTHOLE	.024 .000	.047 .038	SAME AS IN 1A	.302 .328	.000 .012	.049 .036	.122 .083	SAME AS IN 1A	.069 .036	.169 .071	.104 .061	.0765 .0335	.049 .011	.0665 .0335	.013 .037						
③ ③	3 PART 20019602 TILTED & ECCENTRIC PER COMPUTATION SHEET PAGES 25-26 PARALLEL	SAME AS IN 2A	.068 .037	SAME AS IN 2A	.395 .325	SAME AS IN 2A	.073 .032	.123 .082	SAME AS IN 2A	.077 .028	.149 .066	.056 .109	.0825 .0275	.055 .005	.0745 .0255	SAME AS IN 2A						
④ ④	4 PARTS 20019601 & 20019603 TILTED & ECCENTRIC PER PAGE 25 THRU 30 OF COMPUTATION SHEET	SAME AS IN 2A	.068 .035	SAME AS IN 2A	.394 .327	SAME AS IN 2A	.076 .029	SAME AS IN 2A	SAME AS IN 2A	.085 .020	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A						
⑤ ⑤	5 OIL BEARING ASSEMBLY & SHAFT TO BEARING SUPPORT FLANGE ECCENTRIC PER COMPUTATION SHEET PAGES 32 THRU 35	SAME AS IN 2A	.0345	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	.081	SAME AS IN 2A	SAME AS IN 2A	.093	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A	SAME AS IN 2A						
6																						
7																						

Rockwell International Corporation
Atomic's International Division
RADIAL STACK UP - 151P
PAGE 6

DATE: 09974
DRAWING NO: N266T1000004

APPLICABLE

Atomics International

NO . N266TI000004
PAGE . 7


IV. COMPUTATION


A. CONDITION 1


All parts are concentric, and axes are parallel. This is an ideal condition. Clearance values are nominal.


PREPARED BY: <i>P. JENCEK</i>	Atoms International Division Rockwell International	PAGE NO. <i>8</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N26671000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP-151P-</i>	MODEL NO.


CONDITION 1 - CONCENTRIC



PREPARED BY: <i>P. JENCKE</i>		 Atomics International Division Rockwell International	PAGE NO. <i>9</i> OF <i>35</i>	
CHECKED BY:			REPORT NO. <i>N26671 000004</i>	
DATE: <i>7-7-78</i>		<i>RADIAL STACK UP - 151P-</i>		MODEL NO.
ITEM	SOURCE	COMPUTATION		
<i>1A</i>	<i>114 E 789 115 E 116</i>	<i>11.993 DIA</i>	<i>11.991 DIA</i>	<i>SH 40</i>
		<i>12.013 DIA</i>	<i>12.015 DIA</i>	
		<i>.020/DIA</i>	<i>.024/DIA</i>	
		<i>.010/RAD</i>	<i>.012/RAD</i>	
<i>1B</i>	<i>R0019601 R0019602 (3 PLACES)</i>	<i>20.100 DIA</i>	<i>20.095 DIA</i>	<i>SH 40</i>
		<i>20.200 DIA</i>	<i>20.205 DIA</i>	
		<i>.100/DIA</i>	<i>.110/DIA</i>	
		<i>① .050/RAD</i>	<i>.055/RAD</i>	
		<i>20.500 DIA</i>	<i>20.495 DIA</i>	<i>SH 40</i>
		<i>20.600 DIA</i>	<i>20.605 DIA</i>	
		<i>.100/DIA</i>	<i>.110/DIA</i>	
		<i>② .050/RAD</i>	<i>.055/RAD</i>	
		<i>20.900 DIA</i>	<i>20.995 DIA</i>	<i>SH 40</i>
		<i>21.000 DIA</i>	<i>21.005 DIA</i>	
		<i>.100/DIA</i>	<i>.110/DIA</i>	
		<i>③ .050/RAD</i>	<i>.055/RAD</i>	
<i>1C</i>	<i>114 E 939 R0019602 (PER DWGS)</i>	<i>22.100 DIA</i>	<i>22.105 DIA</i>	<i>SH 40</i>
		<i>22.100 DIA</i>	<i>22.098 DIA</i>	
		<i>.000/DIA</i>	<i>(L) .007/DIA</i>	


PREPARED BY: P. JENCKE		 Atomic International Division Rockwell International		PAGE NO. 10 of 35	
CHECKED BY:				REPORT NO. N266T1000004	
DATE: 7-7-76		RADIAL STACK UP - 151P		MODEL NO.	
1C (CONT.)	N266E000002 (AS BUILT-AVG) R0019602 TAKE "AS BUILT" DIMENSION	22.098 DIA 22.100 DIA - .002/DIA (INTERF. FIT)	22.098 DIA 22.098 DIA .000/DIA	SH	SH
1D	R0019601 R0019602	35.410 DIA 36.090 DIA .680 /DIA .340 /RAD	35.390 DIA 36.150 DIA .760 /DIA .380 /RAD	SH	HO
1E	114E 939 114E 727	44.000 DIA 43.990 DIA .010 /DIA .005 /RAD	44.007 DIA 43.983 DIA .024 /DIA .012 /RAD	HO	SH
1F	R0019601 R0019602 (3 PLACES)	22.900 DIA 23.000 DIA ① .050 /RAD	22.895 DIA 23.005 DIA .110 /DIA .055 /RAD	SH	HO
		22.500 DIA 22.600 DIA ② .050 /RAD	22.495 DIA 22.605 DIA .110 /DIA .055 /RAD	SH	HO

PREPARED BY: P. JENNETE		 Atomics International Division Rockwell International	PAGE NO. 11 of 35	
CHECKED BY:			N266000004	
DATE: 7-7-78		RADIAL STACK UP - ISIP		REPORT NO.
				MODEL NO.
1F (CONT)		22.100 DIA	22.095 DIA	SH
		22.200 DIA	22.215 DIA	HO
		<u>.100/DIA</u>	<u>.110/DIA</u>	
		③ .050/RAD	.055/RAD	
1G	114E727 R0019602 (PER DWGS)	41.765 DIA	41.815 DIA	HO
		41.600 DIA	41.570 DIA	SH
		<u>.185/DIA</u>	<u>.245/DIA</u>	
		.0925/RAD	.1225/RAD	
	N266E000002 (AS BUILT) R0019602	41.790 DIA	41.790 DIA	HO
		41.600 DIA	41.570 DIA	SH
		<u>.190/DIA</u>	<u>.220/DIA</u>	
	TAKE "AS BUILT" DIM	.095/RAD	.110/RAD	
1H	-007 R0019602	36.200 DIA	36.202 DIA	HO
	-009	36.200 DIA	36.198 DIA	SH
		<u>.000/DIA</u>	(L) .004/DIA	
		.000/RAD	(L) .002/RAD	
1J	R0019602	18.630 DIA	18.635 DIA	HO
	R0019603	18.530 DIA	18.525 DIA	SH
		<u>.100/DIA</u>	<u>.110/DIA</u>	
		.050/RAD	.055/RAD	

PREPARED BY: <i>P. JENCKER</i>	 Atomics International Division Rockwell International	PAGE NO. <i>12</i> of <i>35</i>
CHECKED BY:		REPORT NO. <i>N266T1000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP - ISIP</i>	MODEL NO.

1K

AA1-15227
(COVER URP -
CAK AIRTOMIC DIV.)
R0019602
N266000012



<i>.330</i>	<i>.327</i>
<i>.320</i>	<i>.323</i>
<i>.010</i>	<i>.004</i>

<i>21.500</i>	<i>21.503</i>	<i>21.350</i>	<i>21.323</i>
<i>-1.120</i>	<i>-1.080</i>	<i>1.140</i>	<i>1.160</i>
<i>20.380</i>	<i>20.423</i>	<i>20.210</i>	<i>20.163</i>
<i>20.210</i>	<i>20.163</i>		

.170/DIA .260/DIA
.085/RAD .130/RAD → *(1K)*


<i>21.500</i>	<i>21.503</i>
<i>2.350</i>	<i>21.323</i>

.150/DIA .180/DIA
.075/RAD .090/RAD → *(1L)*

CONCLUSION:

IF 1K → .130(MAX) 1L = .090(MAX)
(1K > 1L) NO BOTTOMING
IF 1K → .085(MIN) 1L = .075(MIN)
(1K > 1L) NO BOTTOMING


1L

PREPARED BY: <i>P. JENICEK</i>		 Atomics International Division Rockwell International	PAGE NO. <i>13</i> OF <i>35</i>
CHECKED BY:			REPORT NO. <i>N266T1000004</i>
DATE: <i>7-7-78</i>		MODEL NO. <i>RADIAL STACK UP - ISIP</i>	
<i>1M</i>	<i>R0019602</i> <i>N266000012</i>	<i>20.010 DIA</i> <i>20.105 DIA</i> <hr/> <i>.095/DIA</i> <i>.0475/RAD</i>	<i>19.990 DIA</i> <i>20.115 DIA</i> <hr/> <i>.125/DIA</i> <i>.0625/RAD</i> <i>SH</i> <i>HO</i>
<i>1N</i>	<i>R0019602</i> <i>N266000012</i>	<i>20.055 DIA</i> <i>20.165 DIA</i> <hr/> <i>.050/DIA</i> <i>.025/RAD</i>	<i>20.045 DIA</i> <i>20.115 DIA</i> <hr/> <i>.070/DIA</i> <i>.035/RAD</i> <i>SH</i> <i>HO</i>
<i>1Ø</i>	<i>R0019602</i> <i>N266000017</i>	<i>18.930 DIA</i> <i>19.025 DIA</i> <hr/> <i>.095/DIA</i> <i>.0475/RAD</i>	<i>18.925 DIA</i> <i>19.030 DIA</i> <hr/> <i>.105/DIA</i> <i>.0525/RAD</i> <i>SH</i> <i>HO</i>
<i>1P</i>	<i>114E727</i>	<i>.040</i> <i>.060/DIA</i> →	<i>.020</i> <i>.030/RAD</i>





B. CONDITION 2


- 1) The shaft moves parallel within the bearing by .012 in. for metal - to metal contact. During the pump operation, this represents an entry into the failure phase.
- 2) The static hydraulic moves parallel by .012 against bearing support in the opposite direction of shaft movement.
- 3) Parts 114E939, 115E116, and R0019602 are thus approached from both sides to decrease radial clearances for same values as radial clearances increase 180° apart.
- 4) The diffuser shroud moves Parallel by .002 relative to the diffuser.


PREPARED BY: <i>P. JENCEK</i>	 Atomics International Division Rockwell International	PAGE NO. <i>15</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266T1000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP - 1SIP-</i>	MODEL NO.

CONDITION 2: PARALLEL OFFSETS



PREPARED BY: <i>F. JENCOTE</i>		 Atomics International Division Rockwell International		PAGE NO. <i>16</i> OF <i>35</i>	
CHECKED BY:				REPORT NO. <i>N26671000004</i>	
DATE: <i>7-7-78</i>		<i>RADIAL STACK UP-1SIP</i>		MODEL NO.	
		<i>THIS SIDE</i>	<i>OPP SIDE</i>		
<i>2A</i>	<i>1A</i> $\Delta = .012$ <i>(A = 0 THIS SIDE)</i>	<i>.012</i> <i>-.012</i> <i>.000</i>	<i>.012</i> <i>+.012</i> <i>.024</i>		
<i>2B</i>	<i>1B</i>	<i>.050</i> <i>-.012</i> <i>.038</i>	<i>.055</i> <i>+.012</i> <i>.067</i>		
<i>2C</i>	<i>SAME AS 1C</i>				
<i>2D</i>	<i>1D</i>	<i>.340</i> <i>-.012</i> <i>.328</i>	<i>.380</i> <i>+.012</i> <i>.392</i>		
<i>2E</i>	<i>1E</i> <i>1) ALTHOUGH MAX. RADIAL MOVEMENT OF 114E727 IS .007 (BASED ON MAX GAP .015 IN 90° INTERVAL) THE MOVEMENT IN MIN GAP CONDITION 1E WILL BE .005</i>	<i>.005</i>	<i>.012</i>	<i>.005</i>	<i>.012</i>
<i>REF 4</i>					
<i>2F</i>	<i>1F</i>	<i>.050</i> <i>-.002</i> <i>-.048</i> <i>-.012</i> <i>.036</i>	<i>.055</i> <i>+.002</i> <i>.057</i> <i>+.012</i> <i>.069</i>		
<i>2G</i>	<i>1G</i>	<i>.095</i>	<i>.110</i>		

PREPARED BY: <i>P. JENCER</i>		 Atomics International Division Rockwell International		PAGE NO. <i>17</i> OF <i>35</i>	
CHECKED BY:				REPORT NO. <i>N266T1000004</i>	
DATE: <i>7-7-78</i>		<i>RADIAL STACK UP-151P</i>		MODEL NO.	
<i>2G (CONT)</i>		<i>-.012</i>	<i>+.012</i>		
		<i>.083</i>	<i>.122</i>		
<i>2H</i>	<i>SAME AS 1H</i>				
<i>2J</i>	<i>1J</i>	<i>.050</i>	<i>.055</i>		
		<i>-.002</i>	<i>+.002</i>		
		<i>-.048</i>	<i>.057</i>		
		<i>-.012</i>	<i>+.012</i>		
		<i>.036</i>	<i>.069</i>		
<i>2K</i>	<i>1K</i>	<i>.085</i>	<i>.130</i>		
		<i>-.002</i>	<i>+.002</i>		
		<i>.083</i>	<i>.132</i>		
		<i>-.012</i>	<i>+.012</i>		
		<i>.071</i>	<i>.144</i>		
<i>2L</i>	<i>1L</i>	<i>.075</i>	<i>.090</i>		
		<i>-.002</i>	<i>+.002</i>		
		<i>.073</i>	<i>.092</i>		
		<i>-.012</i>	<i>+.012</i>		
		<i>.061</i>	<i>.104</i>		
<i>2M</i>	<i>1M</i>	<i>.0475</i>	<i>.0625</i>		
		<i>-.0020</i>	<i>+.0020</i>		
		<i>.0455</i>	<i>.0645</i>		
		<i>-.0120</i>	<i>+.0120</i>		
		<i>.0335</i>	<i>.0765</i>		
<i>2N</i>	<i>1N</i>	<i>.025</i>	<i>.035</i>		
		<i>-.002</i>	<i>+.002</i>		
		<i>.023</i>	<i>.037</i>		
		<i>-.012</i>	<i>+.012</i>		
		<i>.017</i>	<i>.049</i>		
<i>2φ</i>	<i>1O</i>	<i>.0475</i>	<i>.0525</i>		
		<i>-.0020</i>	<i>+.0020</i>		
		<i>.0455</i>	<i>.0545</i>		
		<i>-.0120</i>	<i>+.0120</i>		
		<i>.0335</i>	<i>.0665</i>		

PREPARED BY: <i>P. JENCEK</i>		 Atomics International Division Rockwell International		PAGE NO. <i>18</i> OF <i>35</i>
CHECKED BY:				REPORT NO. <i>N266 T1000004</i>
DATE: <i>7-7-78</i>		<i>RADIAL STACK UP- 1S1P</i>		MODEL NO.
<i>2P</i>	<i>1P</i>	<i>.020</i>	<i>.030</i>	
		<i>-.007</i>	<i>+.007</i>	
		<i>.013</i>	<i>.037</i>	




C. CONDITION 3


Due to normalcy and parallelism tolerances of Parts 114E939 and 114E727, Part R0019602 is tilted. The origin of tilt is approximately at elevation of interface between Parts 114E939 and 114E727.


Radial clearances are calculated by use of variable correction value as a function of distance from the tilt origin.


The resulting radial clearances of Condition 3 are compounded values including those of Condition 2.

PREPARED BY: <i>P. JENCEK</i>	 Atomics International Division Rockwell International	PAGE NO. <i>20</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266T1000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP - 151P</i>	MODEL NO.

CONDITION 3: TILT (DUE TO \perp & \parallel TOLERANCE)



PREPARED BY: P. JENCKE	 Atoms International Division Rockwell International	PAGE NO. 21 OF 35
CHECKED BY:		REPORT NO. N26671000004
DATE: 7-7-78	RADIAL STACK UP-151P	MODEL NO.



(114E727)
N266000017

R0019602

- ① 114 E 727
- ② N266000017

$$13.00 \times .0058 = 20.00 \times X$$

$$X = \frac{20.00 \times .0058}{13.00} = .0089$$

(R0019602) CONCENTRICITY
CONCENTRICITY


$$(\pm) .00445$$


$$(\pm) .0005$$

$$(\pm) .0025$$

$$\hline (\pm) .00745 \sim \pm .0075$$

$\textcircled{C} .015 \phi @ 20''$

PREPARED BY: <i>P. JENCEK</i>		 Atomics International Division Rockwell International	PAGE NO. <i>22</i> OF <i>35</i>	
CHECKED BY:			REPORT NO. <i>N266T1000004</i>	
DATE: <i>7-7-76</i>		<i>RADIAL STACK VP-151P</i>		MODEL NO.
<i>3A</i>	<i>2A</i> (Δ <i>.000</i>)	<i>.020</i> <i>-.0</i>	<i>.024</i> <i>+.0</i>	
		<i>.020</i>	<i>.024</i>	
<i>3B</i>	<i>2B</i> (Δ <i>.001</i>)	<i>.038</i> <i>-.001</i>	<i>.067</i> <i>+.001</i>	
		<i>.037</i>	<i>.068</i>	
<i>3C</i>	<i>2C</i>	<i>SAME AS 1C</i>		
<i>3D</i>	<i>2D</i> (Δ <i>.003</i>)	<i>.328</i> <i>-.003</i>	<i>.392</i> <i>+.003</i>	
		<i>.325</i>	<i>.395</i>	
<i>3E</i>	<i>2E</i> (+)	<i>SAME AS 2E</i>		
<i>3F</i>	<i>2F</i> (Δ <i>.004</i>)	<i>.036</i> <i>-.004</i>	<i>.069</i> <i>+.004</i>	
		<i>.032</i>	<i>.073</i>	
<i>3G</i>	<i>2G</i> (Δ <i>.001</i>)	<i>.083</i> <i>-.001</i>	<i>.122</i> <i>+.001</i>	
		<i>.062</i>	<i>.123</i>	
<i>3J</i>	<i>2J</i> (Δ <i>.005</i>)	<i>.036</i> <i>-.005</i>	<i>.069</i> <i>+.005</i>	
		<i>.028</i>	<i>.077</i>	
<i>3K</i>	<i>2K</i> (Δ <i>.005</i>)	<i>.071</i> <i>-.005</i>	<i>.144</i> <i>+.005</i>	
		<i>.066</i>	<i>.149</i>	


PREPARED BY: P. JENCEK		 Atomics International Division Rockwell International	PAGE NO. 23 of 35	
CHECKED BY:			REPORT NO. N26671000004	
DATE: 7-7-78		RADIAL STACK UP-151P		MODEL NO.
3M	2M (Δ) (.006)	.0335 - .006	.0765 + .006	
		.0275	.0825	
3N	2N (Δ) (.006) FIT IN AREA M.	.011 - .006	.049 + .006	
		.005	.055	
3O	2O (Δ) (.008)	.0335 - .008	.0665 + .008	
		.0255	.0745	
3P	2P	SAME AS 2P		
3L	2L (Δ) (.005)	.061 - .005	.104 + .005	
		.056	.109	




D. CONDITION 4


This condition compounds the effect of tilts, originating in concentricity tolerance callouts of Parts 114E799, R0019602, R0019603 on the radial stackup of values of Condition 3. Considered are:


- 1) Concentricities of the shaft taper to the axis of shaft rotation (male taper).
- 2) Concentricity of the impeller taper ends (female taper).
- 3) Concentricity and diametrical clearance of two (male) impeller pilots and normalcy of impeller interface plane against the inducer - extrapolated and related to axis of rotation.
- 4) Concentricity of two (female) pilots and normalcy tolerance of mating plane for the inducer interfacing with the impeller - extrapolated to lower end of the full inducer vane diameter and related to axis of rotation.
- 5) Item 4 is then related to tilted Part R0019602 from Condition 3.

PREPARED BY: <i>P. JENCEK</i>	 Atomics International Division Rockwell International	PAGE NO. <i>25</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266T1000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP - 151P</i>	MODEL NO.

CONDITION 4: COMPOUNDED TILT
(DUE TO \odot & \perp TOLERANCES)





PREPARED BY: T. JENCEK	 Atoms International Division Rockwell International	PAGE NO. 26 OF 35
CHECKED BY:		REPORT NO. N266 T1 000004
DATE: 7-7-78	RADIAL STACK UP - ISIP	MODEL NO.





$$\begin{array}{r}
 .001 \\
 (R0019601) \\
 \\
 \frac{20.00}{6.74} \\
 \hline
 13.26 \\
 \\
 \frac{.00216}{.00100} \\
 \hline
 .00316
 \end{array}$$

$$\begin{array}{l}
 .0005" @ \frac{9.25}{2} \\
 \times @ 20.00" \\
 \hline
 \times .0005 = 20.00 : \frac{9.25}{2} \\
 \times = \frac{.0005 \times 20.00 \times 2}{9.25} = .00216
 \end{array}$$


PREPARED BY: P. JENCEK	 Atoms International Division Rockwell International	PAGE NO. 27 of 35
CHECKED BY:		REPORT NO. N266T1000004
DATE: 7-7-78	RADIAL STACK UP - 1SIP	MODEL NO.





PREPARED BY: P. JENCKE	 Atoms International Division Rockwell International	PAGE NO. 28 OF 35
CHECKED BY:		REPORT NO. N266T1000004
DATE: 7-7-78	RADIAL STACK UP-1SIP	MODEL NO.



NOTE: COMPOSITE NORMALCY TOLERANCE OF PARTS R0019601 & R0019603 .00125 ALLOWS THE INDUCER TO TILT, AS CAUSED BY THE COMBINED LOOSENESS & CONCENTRICITY TOLERANCE IN PILOT B, WITH THE FULCRUM OF TILT IN PILOT A (INTERF. FIT)

PREPARED BY: <i>P. JENCEX</i>	 Atomics International Division Rockwell International	PAGE NO. <i>29</i> of <i>35</i>
CHECKED BY:		REPORT NO. <i>N266TI000004</i>
DATE: <i>7-7-78</i>	<i>RADIAL STACK UP-1S1P</i>	MODEL NO.





PREPARED BY: <i>P. JENCEK</i>		 Atomics International Division Rockwell International	PAGE NO. <i>30</i> OF <i>35</i>	
CHECKED BY:			REPORT NO. <i>N266T1000004</i>	
DATE: <i>7-7-78</i>		<i>RADIAL STACK UP - 1SIP</i>		MODEL NO.
<i>4A</i>	<i>3A</i>	<i>SAME AS 3A</i>		
<i>4B</i>	<i>3B (Δ .0015)</i>	<i>.037</i> <i>- .0015</i>	<i>.068</i> <i>+ .0015</i>	
		<i>.0355</i>	<i>.0695</i>	
<i>4C</i>	<i>3C</i>	<i>SAME AS IN 1C</i>		
<i>4D</i>	<i>3C (Δ .0013)</i>	<i>.3250</i> <i>- .0013</i>	<i>.3950</i> <i>+ .0013</i>	
		<i>.3237</i>	<i>.3963</i>	
<i>4E</i>	<i>3E</i>	<i>SAME AS 3E</i>		
<i>4F</i>	<i>3F (Δ .003)</i>	<i>.032</i> <i>- .003</i>	<i>.073</i> <i>+ .003</i>	
		<i>.029</i>	<i>.076</i>	
<i>4G</i>	<i>3G</i>	<i>SAME AS 3G</i>		
<i>4H</i>	<i>3H</i>	<i>SAME AS 3H</i>		
<i>4J</i>	<i>3J (Δ .008)</i>	<i>.028</i> <i>- .008</i>	<i>.077</i> <i>+ .008</i>	
		<i>.020</i>	<i>.085</i>	
<i>4K</i>	<i>3K</i>	<i>SAME AS 3K</i>		
<i>4L</i>	<i>3L</i>	<i>SAME AS 3L</i>		
<i>4M</i>	<i>3M</i>	<i>SAME AS 3M</i>		
<i>4N</i>	<i>3N</i>	<i>————— 3N</i>		
<i>4O</i>	<i>3O</i>	<i>————— 3O</i>		
<i>4P</i>	<i>3P</i>	<i>————— 3P</i>		





CONDITION 5


- 1) There is an .008 addition tolerance due to accumulation of tolerances in those portions of the pump above the bearing which had not been taken into consideration previously.

PREPARED BY: <i>M. Gristor</i>	 Rockwell International Atomics International Division	PAGE NO. <i>32</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266TI000004</i>
DATE: <i>5/3/79</i>	RADIAL STACK UP-1SIP	MODEL NO.




PREPARED BY: <i>M. A. Ristam</i>	 Rockwell International Atomsics International Division	PAGE NO. <i>33</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266TI000004</i>
DATE: <i>5/2/79</i>	RADIAL STACKUP - ISIP	MODEL NO.




PREPARED BY: <i>M. G. Gisham</i>	 Rockwell International Atomic International Division	PAGE NO. <i>34</i> OF <i>35</i>
CHECKED BY:		REPORT NO. <i>N266TI000004</i>
DATE: <i>5/3/79</i>	RADIAL STACK UP - ISIP	MODEL NO.

Total offset of shaft from up bearing

Joint identification	Tolerance	⊙	⊥	Total
R	.001			.001
S	.0045	.0015		.0060
T	.0045	.015		.0195
U	.013	.0005		.0135
V			.0490	.0490



PREPARED BY: M. Grisham		 Rockwell International Atomic International Division	PAGE NO. 35 of 35	
CHECKED BY:			REPORT NO. N266T1000004	
DATE: 4/30/79		RADIAL STACK UP-1SIP		MODEL NO.
5A	4A	SAME AS 4A		
5B	4B	Δ (.001)	$\begin{array}{r} .0355 \\ - .0010 \\ \hline .0345 \end{array}$	$\begin{array}{r} .0695 \\ + .0010 \\ \hline .0705 \end{array}$
5C	4C	SAME AS 4C		
5D	4D	SAME AS 4D		
5E	4E	SAME AS 4E		
5F		Δ (.005)	$\begin{array}{r} .029 \\ - .005 \\ \hline .024 \end{array}$	$\begin{array}{r} .076 \\ + .005 \\ \hline .081 \end{array}$
5G	4G	SAME AS 4G		
5H	4H	SAME AS 4H		
5J	4J	Δ (.008)	$\begin{array}{r} .020 \\ - .008 \\ \hline .012 \end{array}$	$\begin{array}{r} .085 \\ + .008 \\ \hline .093 \end{array}$
5K	4K	SAME AS 4K		
5L	4L	SAME AS 4L		
5M	4M	SAME AS 4M		
5N	4N	SAME AS 4N		
5O	4O	SAME AS 4O		
5P	4P	SAME AS 4P		



APPENDIX G

HYDRODYNAMIC DESIGN REPORT

Rocketdyne Document R/H 8113-3630
(Assigned ESG Document number is N266ER000-002)



SUPPORTING DOCUMENT

NUMBER
N266ER000-002

REV LTR/CHG NO.
SEE SUMMARY OF CHG

PROGRAM TITLE
Intermediate-Size Inducer Pump

DOCUMENT TYPE
Engineering Report

DOCUMENT TITLE
Hydrodynamic Design Report

KEY NOUNS
Pump, Inducer, Hydrodynamics

ORIGINAL ISSUE DATE
April 2, 1979

PREPARED BY/DATE DEPT MAIL ADDR
E. D. Jackson 545-113 AC51
(Rocketdyne, Div. 055)

GO NO. S/A NO. PAGE 1 OF 32
09280 23000 TOTAL PAGES 32

REL. DATE
4-4-79 SW

IR&D PROGRAM? YES NO IF YES, ENTER TPA NO. _____

SECURITY CLASSIFICATION
(CHECK ONE BOX ONLY) (CHECK ONE BOX ONLY)

UNCL <input type="checkbox"/>	ERDA <input type="checkbox"/>	DOD <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>
CONF. <input type="checkbox"/>			DEFENSE INFO. <input type="checkbox"/>
SECRET <input type="checkbox"/>			

APPROVALS DATE
T. J. Boardman *T. Boardman* 3/30/79
R. V. Anderson *R.V. Anderson* 3/30/79
Ch. Sorijn 4-3-79

AUTHORIZED CLASSIFIER _____ DATE _____

DISTRIBUTION		MAIL ADDR
* NAME		
* T. Boardman		LB08
* R. Anderson		LB17
* J. Lockett		LB39
* J. Pfouts		JB05
* R. Hoshide		JB05
* C. Dunn		LB08
G. Hallinan		
R. Schnurstein		
E. Andrews		
L. Stabinsky		
J. Page		
* C. Torrijos		
C. Conners		
D. Nelson		

ABSTRACT

This report summarizes the results of the hydrodynamic design effort performed for the Intermediate-Size Inducer Pump (ISIP). The report describes the design criteria and identifies the computer programs used for hydrodynamic analysis. The report also includes tables and curves of calculated performance parameters such as overall performance, blade leadings, and internal losses. The calculated results show that the ISIP is expected to achieve an NPSH requirement as low as 12.8 ft when operated in sodium at design flow, speed, and temperature (14500 gpm, 1110 rmp, 1050F°). Calculated results also show that the impeller will have approximately 9% margin over the required head (500 ft) for these flow conditions. This report was prepared by Rocketdyne (Div. 055) under IDWA N-1289 and released from that division under the number R/H 8113-3630.

RESERVED FOR PROPRIETARY/LEGAL NOTICES

THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE

This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY



Rockwell International
Rocketdyne Division

R/H 8113-3630
26 April 1978

HYDRODYNAMIC DESIGN REPORT
INTERMEDIATE SIZE INDUCER PUMP
FOR SODIUM OPERATION

CONTRACT EY-76-C-03-0824

Prepared for
ATOMICS INTERNATIONAL DIVISION
ROCKWELL INTERNATIONAL CORPORATION

Prepared by:

J. A. King
J. A. King
Member Technical Staff
Hydrodynamic Unit
Rocketdyne

F. C. O'Hern
F. C. O'Hern
Member Technical Staff
Hydrodynamic Unit
Rocketdyne

E. D. Jackson
E. D. Jackson
Manager
Hydrodynamic Unit
Rocketdyne

Approved by:

E. D. Jackson
E. D. Jackson
Manager
Hydrodynamic Unit
Rocketdyne

D. E. Davis
D. E. Davis
Program Manager
Advanced Programs
Rocketdyne

INTRODUCTION

The Intermediate-Size Inducer Pump (I.S.I.P.) was designed to operate in the existing FFTF pump housing and to achieve the required pump head rise at the same speed and flow as the existing pump. The existing pump consists of four basic hydrodynamic elements:

1. Inlet Elbow
2. Centrifugal Impeller
3. Vaned Diffuser
4. Discharge Housing

All of these elements except the centrifugal impeller were to be retained in an unmodified form for the I.S.I.P. design. The centrifugal impeller was to be replaced with a new design consisting of both an inducer and centrifugal impeller. The objective is to demonstrate the capability of designing an inducer pump for long life in sodium operation so that the advantages of the inducer pump can be realized in future sodium pump applications. These advantages consist primarily in the smaller envelope size and lower weight realized as a result of the better suction performance capability of the inducer. These advantages result in significant cost savings and ease of fabrication and handling for the very large pumps required in many of the reactor coolant loop systems.

The vaned diffuser in the existing design attempts to diffuse the flow while turning it which typically limits the stable range of operation. Tests of the existing pump have demonstrated instability at a flow of approximately seventy percent of the design flow. The I.S.I.P. design must use this same diffuser, therefore to attempt to extend the stable operating range, Rocketdyne has chosen to design the centrifugal impeller to a smaller outer diameter to leave sufficient space to add an intermediate vaned diffuser upstream of the existing diffuser. This new diffuser would be designed to operate over a wider flow range and should provide a wider range of stable operation for the overall pump.

Thus, the I.S.I.P. design consists of three new hydrodynamic elements:

1. Inducer
2. Centrifugal Impeller
3. Intermediate Vaned Diffuser

This report describes the hydrodynamic design features of each of these. The report also discusses the design rationale and methods of analysis. Following this, the hydrodynamic performance of the design is presented and compared with the design specification.

The specified sodium characteristics used in the design are:

Fluid Inlet Temperature = 1050⁰ F

Fluid Specific Weight = 50.97 lb/ft³

SUMMARY

An inducer pump has been designed to fit within the existing housing of the FFTF facility. The new design consists of three primary hydrodynamic components: An inducer, centrifugal impeller, and intermediate vaned diffuser. The hydrodynamic design of each component has been based on the design procedures and analytical techniques developed over a twenty-five year period and proven to be accurate by detailed comparison with test data.

The design has been shown to meet the specified requirements in every area where an analytical prediction of the performance can be made. The head-rise and efficiency of the pump have design margins so that the calculated values actually exceed requirements over the full range of operation. The suction performance of the design provides a very large margin at the operating NPSH value which is the major advantage of using the inducer pump. The suction performance margin at off-design is estimated to be adequate for suction performance, but may not be as large as desired for life considerations. Testing of a model inducer is required to verify the suction performance at off-design and to evaluate the life potential. Operation of an impeller pump with similar margins would also require test verification of the life potential.

The design has incorporated features that provide for long life at the design point. These features have been established based on proven performance of commercial waterjet pumps designed by Rocketdyne. Each of the major design parameters contributing to long life fall within the range of previously verified designs except for a somewhat larger tip clearance. Analysis has indicated that the tip clearance is acceptable.

DESIGN DESCRIPTION

Inducer

Figure 1 shows a layout of the pump configuration indicating the various hydrodynamic components to be discussed. The inducer design was based on the same design practices established and demonstrated by the successful waterjet inducer designs at Rocketdyne.

The inducer was designed with four blades to minimize the potential of tip vortex collapse on the blade surface and thereby eliminate collapse damage. The four-bladed design also provides minimum potential for radial loads for any NPSH margin provided to the inducer. The envelope of the pump was sufficient to handle the required length of the inducer using only four full blades without any partial blades. Elimination of the partials improves confidence in achieving the long life required.

The inducer tip diameter was designed to be 18.53 inches, an unshrouded tip configuration being used to achieve cavitation collapse in the fluid passages and not on the blade material. The tip diameter was dictated by three factors:

1. The existing housing outer diameter.
2. The required operating clearance of 0.050 in. radial.
3. The need to provide a smooth wall contour over the inducer tip.

The longer length of the four-bladed inducer requires it to extend beyond the point where the leading edge of the existing impeller was located. As a result, if the existing housing were used without a liner over the tip of the inducer, a circumferential slot would occur over the inducer and could create cavitating vortices which could cause hardware damage. Thus, a liner was added to eliminate any slot over the inducer itself.




FIGURE 1.

-5-

5

The required tip clearance is set by the rotor dynamics of the pump in the facility. This clearance is somewhat larger than values commonly achievable in waterjet practice. However, the effect of the larger clearance was included in both the performance and life analyses. To further avoid any potential for rubbing at the tip, the blade was designed for zero cant angle so that any blade movement would not decrease the operating clearance.

The hub contour was selected to optimize the performance and match the required impeller inlet design. The hub diameter at the inlet is 6.626 in. giving a hub/tip diameter ratio of 0.358. This inlet diameter is selected to achieve the desired suction performance and to maintain the flow coefficient in the region where confidence in long life is high. The discharge hub diameter is 11.358 in. and is selected for optimum efficiency of the inducer-impeller combination. The contour shape of the hub from inlet-to-discharge is based on established procedures optimized for achieving the proper head-rise distribution along the stream surfaces through the inducer.

The blade design includes such factors as leading edge blade angles, blade camber distribution, blade thickness distribution, leading-edge and trailing-edge sweep and blade solidities. These values are selected based on previous commercial experience, and in each case the I.S.I.P. values are consistent with waterjet design experience at Rocketdyne. The blade design is of primary importance in achieving

1. The optimum suction performance capability
2. The long-life with no detrimental blade damage
3. The required head and maximum efficiency

One of the results desired in the design is a head-rise distribution through the inducer that is monotonically increasing at a somewhat uniform rate. Figure 2 shows the result achieved in the I.S.I.P. inducer design

ISIP INDUCER
PREDICTED HEAD RISE THROUGH INDUCER
(BASED ON R3DP)
Q = 14600 GPM
N = 1110 RPM

N266ER000-001
Page 252

N266ER000-002
Page 9

-7-




FIGURE 2.

indicating its agreement with this design criterion. It is also desirable to achieve a relatively uniform head distribution at the inducer discharge and impeller inlet. Figure 3 indicates that this was accomplished.

Five Rocketdyne computer programs were used in the hydrodynamic design and analysis of the inducer. The first was the nonisentropic radial equilibrium program (NISRE) which calculates the head-rise and meridional velocity leaving the inducer at all radii for a fixed (radial) blade. This was used in the preliminary design portion of the analysis to obtain the desired moderate blade loading.

After the blade meanline was calculated, an initial blade thickness was assigned on the basis of past experience. The entire inducer geometry was then input into the three-dimensional analysis program. This program (unlike the NISRE) takes into account the curvature of the walls before, within, and following the inducer as well as the blade contours. It calculates the local static pressures on the suction and pressure sides of the blades at all stations and at all radii. These pressures are used to determine where the blade will cavitate and where the cavity will collapse. They are also used by Stress to determine the blade loadings from which the final blade thickness is determined. The program also calculates the head-rise at each streamline and the relative velocities entering the centrifugal impeller. These are used to determine the desired blade angles at this station.

The third program used was the blade leading edge loading program which calculates the loading on the leading edge wedge. This loading was combined with that of the three-dimensional analysis program and given to Stress. The combined loads at the design point are shown on Figure 4.

The fourth program predicts the jet stopping distance of a cavity progressing across the passage from the suction side of the blade to the pressure side. If the cavity travels as far as the pressure side of the next blade before collapsing, it might cause damage on that blade.

ISIP INDUCER
PREDICTED HEAD RISE AT
INDUCER DISCHARGE
Q = 14600 GPM
N = 1110 RPM




FIGURE 3.

ISIP FOUR-BLADED INDUCER
BLADE LOADING
Q = 14600 GPM
N = 1110 RPM




FIGURE 4.

The fifth program is the "INDANA" program which is used to calculate the inducer head and efficiency over the full operating range. The calculated performance for I.S.I.P. is presented later in the report in the performance section.

Impeller

The impeller is a shrouded radial-discharge centrifugal-type impeller designed to generate the required head-rise. The impeller has five full blades and five additional partial blades at the discharge. The location of the leading edge of the partials is shown schematically on Figure 1. The number of blades is chosen to optimize the efficiency and generate the required head at the design point. The transition from four inducer blades to five inlet impeller blades is not uncommon in optimum design practice and creates no detrimental effects.

The inlet diameters and blade angles were set based on flow conditions at the inducer discharge. The diameters are essentially a continuation of the inducer discharge diameters. The flow angles at the impeller blade leading edge are a result of an extrapolation from the inducer discharge using continuity of flow and constant angular momentum. The eye diameter is 19.0 inches and inlet hub diameter is 11.36 inches. The eye diameter is slightly larger than the inducer diameter to accommodate the additional wear ring leakage flow.

The inlet section of the blades are designed for no cavitation, and therefore no cavitation damage and long life are assured. This is made possible by the inclusion of the upstream inducer which provides sufficient head-rise to eliminate impeller cavitation either on the blade or in the vortices generated in the wear ring return flow.

The discharge width of 2.75 inches was set equal to the first diffuser width which in turn was set equal to that of the existing diffuser.

This width is wider than required for this operating condition and probably results in a somewhat lower efficiency. However, the I.S.I.P. design must match the existing diffuser in the existing housing, and a mismatch on the width could be a larger efficiency penalty than using the existing width. The discharge diameter of 35.40 inches, number of blades, and blade angle were balanced in such a way to allow room for another diffuser and still generate the required head. This was based on previous Rocketdyne pump experience developed in the design and test of numerous centrifugal impellers used in the turbopumps of the engines for the national space program.

The shroud and hub contour shapes and the blade camber distributions are selected to achieve a uniform loading and head generation distribution. Figure 5 presents the average head-rise at the design point generated through the impeller as a function of meridional length. Similar pressure loading curves at lower flows were generated to assure structural integrity at off design. Figure 6 presents the blade load distribution generated for the Stress department to determine blade stresses.

Two computer programs are used in the impeller design and analysis effort. The quasi-three-dimensional analysis program "VELDIS" was used to analyze the local velocity and pressure field throughout the impeller bladed section. This program provides the design verification that no detrimental regions of back flow or cavitation are occurring in the impeller. The output from the program also provides the head distribution and blade loads previously presented in Figures 5 and 6. The second program is an overall pump performance prediction program that performs a detailed calculation of the various losses that can occur in the pumping elements as well as in the diffusers. This program was used to calculate the head and efficiency over the full operating range, and the results are presented in a later section.

Intermediate Vaned Diffuser

A short, ring diffuser was added between the impeller and the existing

INTERMEDIATE-SIZE INDUCER PUMP
IMPELLER HEAD RISE ONLY

Q = 15816 GPM

N = 1110 RPM

N266ER000-001
Page 258

-13-




FIGURE 5.


N266ER000-002
Page 15

INTERMEDIATE-SIZE INDUCER PUMP

"VELDIS" SOLUTION

Q = 15816 GPM

N = 1110 RPM



PERCENT MERIDIONAL LENGTH

FIGURE 6.

diffuser in an attempt to increase the stable flow range of operation. This diffuser will provide a flow into the Westinghouse diffuser with a smaller angular variation over the flow range than would be available directly from the impeller.

The discharge width and number of vanes were set to provide a match of the inlet flow angles to the vanes of the Westinghouse diffuser. The eleven vanes of the intermediate diffuser are staggered between the eleven vanes of the existing diffuser to minimize boundary layer build up and separation with its attendant loss in efficiency. The diameters of the intermediate diffuser are 37.2 in. at the inlet and 42.0 in. at the discharge. The discharge diameter was set by the housing geometry and the inlet diameter was set by the impeller diameter, allowing sufficient clearance to avoid cavitation or fatigue damage to the impeller or diffuser.

The vane profile is a double-circular-arc design with a 7.4 percent thickness. The profile and thickness were selected consistent with good hydrodynamic practice and to control the hydrodynamic loading on the vanes to meet the required structural integrity.

The inlet vane angle was set to match the flow from the impeller at the design flow and the discharge angle was set to provide a flow matching the inlet vane angle of the Westinghouse diffuser. The required vane angles and diameters combine to give a solidity that provides the required diffusion.

The diffuser was designed using the same methods developed for the space program centrifugal pump designs. These design techniques have been proven based on tests over an extensive flow range. The losses associated with the flow through the diffuser were calculated using the same centrifugal pump loss program discussed in the impeller section.

HYDRODYNAMIC PERFORMANCE

Design Point

The specification design point required an overall head-rise of 500 feet flange-to-flange while pumping a delivered flow of 14500 gpm of sodium at a rotational speed of 1110 rpm. The I.S.I.P. calculated head-rise at these conditions is 546 feet providing a nine percent margin in meeting the required 500 feet. The projected efficiency of the pump at the design point is 74 percent giving a required power of 2037 Hp. This quoted efficiency also has a margin, based on calculations, of four percent.

The program used for the analysis has been quite successful in the prediction of performance on other pumps. This program was developed over the past twenty-five years and checked out by consistently comparing predicted results with pump internal data collected in various test facilities. The program calculates the Euler head-rise for each of the rotating elements and the losses that affect both head-rise and power in each of the components. Table 1 presents the respective head and loss values for each of the components at the design point indicating the margin in the design head-rise. The head can easily be reduced to exactly 500 feet, if required, by trimming the impeller. The calculations for the Westinghouse diffuser system were performed with the available information for the design, but they contain a degree of uncertainty due to the lack of more specific design information.

Range of Operation

The pump is required to operate over a relatively large flow range. The maximum flow at the design speed is 18,000 gpm at which point the head-rise must exceed 375 feet. The minimum flow is not specified, but it was desired to achieve a stable operation for flows lower than that achieved with the Westinghouse design.

TABLE 1
DESIGN POINT PERFORMANCE CALCULATIONS

DELIVERED FLOW = 14,500 GPM
SPEED = 1110 RPM

<u>COMPONENT</u>	<u>EULER HEAD</u>	<u>LOSSES</u>	<u>CUMULATIVE DEVELOPED HEAD</u>
INDUCER	79.2	7.2	72 FT.
IMPELLER	630.0	63.0	639
INTERMEDIATE DIFFUSER	-	17.0	622
WESTINGHOUSE DIFFUSER	-	43.0	579
DISCHARGE SYSTEM	-	33.0	546 FT.
DESIGN MARGIN = 46 FT. (9%)			

The predicted overall head and efficiency are shown in Figure 7 assuming that the margin shown by the calculations is not realized in actual operation. The head-rise at the 18,000 gpm flow is projected to be 470 feet well in excess of the 375-foot minimum value. The negative slope of the head-flow curve is predicted to extend down to 8000 gpm. The existing pump was reported to have a stability problem between 10,000 and 12,000 gpm, and the vaned diffuser is expected to be the primary cause of the instability. The additional diffuser designed by Rocketdyne should help to extend the stable flow range, but the stable range cannot be guaranteed because the same Westinghouse diffuser is being used.

Figure 8 presents the head and efficiency of the inducer portion of the pump. This head must be sufficient to keep the impeller out of the cavitation region which causes head fall-off.

Pony Motor Operation

The specification required that at the pony motor speed of 94 rpm, the head-rise was not to exceed five feet of head. Figure 9 presents the scaled head-rise over the required flow range. The maximum head is four feet which is within the specification requirement.

Life Requirements

The specification requires a 20 year life at the design point and a worst-case, off-design life of 250 hours at 18,000 gpm and design speed of 1110 rpm. The inducer design incorporates the long-life design features established and verified through Rocketdyne's waterjet pump experience. The significant parameters that affect the life of the machine have all been chosen to fall within the range of those parameters actually used in the waterjets. This includes such parameters as the leading edge sweep, flow coefficient, incidence angle, inlet blade angle distribution, cant angle, and tip thickness. The one parameter which was slightly outside

INTERMEDIATE-SIZE INDUCER PUMP
PREDICTED PERFORMANCE
1110 RPM




FIGURE 7.

INTERMEDIATE - SIZE INDUCER PUMP
PREDICTED PERFORMANCE
INDUCER ONLY

1110 RPM
TIP DIAMETER = 18.53 IN.




FIGURE 8.

INTERMEDIATE-SIZE INDUCER PUMP
PREDICTED PERFORMANCE
PONY MOTOR OPERATION
94 RPM




FIGURE 9.

the waterjet experience range was the tip-clearance-to-blade-height ratio. However, Rocketdyne does have an analytical program for predicting the influence of this clearance on the potential damage due to the tip vortex cavity. This analytical program has been correlated with waterjet life test results. The analysis indicates that the selected four-bladed design will be able to operate with long life at the required operating clearance.

Other features incorporated to maximize the life include designing for zero cant angle of the blade to prevent a detrimental minimum tip clearance in case of blade bending, elimination of the slot over the inducer to prevent generation of slot-edge vortex cavitation, and increasing the blade thickness at the tip to the maximum value consistent with good hydrodynamic suction performance. This latter feature was included to provide more structural integrity to the blade to minimize blade movement in the high temperature sodium environment.

The maximum flow of 18,000 gpm represents a 24 percent increase in flow over the design point. At such a large off-design condition any rotating component, inducer or impeller, would experience some cavitation damage if the NPSH margin is low. The NPSH margin required to prevent such damage for the I.S.I.P. design must be determined from water tests of model hardware. Such testing does provide a very economical approach to the problem and yields the required technological data for assessing the design in the very early stages of the overall program. This provides the opportunity for hardware modifications, if necessary, before fabricating any full-size hardware.

Suction Performance

The available NPSH provided to the inducer at the design flow is 47 feet. At 18,000 gpm this value drops to 40 feet. Rocketdyne's I.S.I.P design is capable of achieving a predicted required NPSH of 12.8 feet at the design flow. This capability is based on the assumption that the required

suction performance is the same in sodium as in water. Since both fluids have a very low vapor pressure, the thermodynamic suppression head effects should be negligible so that the above assumption is valid.

Rocketdyne's ability to meet this predicted performance is based on an extensive background of designing and testing high suction performance inducers. More recently, the capability of the subscale sodium inducer demonstrated the ability to achieve the predicted performance. The design features which are required to achieve these results have been designed into the I.S.I.P. consistent with previous Rocketdyne experience. No design compromises were required due to the sodium operation or other pump features with one exception. The outer diameter of the inducer was reduced, raising the required NPSH, to provide a smooth liner over the inducer and eliminate the slot over the inducer present in the existing housing.

The suction performance at off-design conditions is more difficult to predict. Based on the subscale sodium inducer the ratio of breakdown NPSH at 1.24 times design flow (18,000 gpm) compared to that at the design point (14,500 gpm) was 2.26. Using this ratio, the I.S.I.P. required NPSH at the maximum flow would be 29 feet giving a margin of 38 percent. This is an adequate margin for suction performance but is relatively low for achieving life. An inducer or impeller operating with such small margin at this off-design value would be expected to experience damage, and the life then depends on the damage rate compared to the off-design life requirement. At 250 hours of life over a 20 year period, the inducer could be expected to maintain its performance capability even though some damage occurred.

The presence of the inducer provides sufficient head-rise at the impeller inlet to keep the impeller from experiencing cavitation performance loss. The maximum required suction specific speed of the impeller is only approximately 5200 at the off-design flow of 18,000 gpm. At the design flow, it will be significantly less than this.

Radial Loads

The specification requires that the design incorporate polar symmetry to minimize radial loads. Such polar symmetry was incorporated in the design. The radial loads are also minimized by the incorporation of a four-bladed inducer, use of a lower impeller diameter than used in the existing pump, use of a more stable vaned diffuser system, and the complete polar symmetry of the existing diffuser discharge. The maximum radial loads to be experienced would occur at the lower flows. The radial loads should be less for the Rocketdyne design than the existing design, but for purposes of analysis a not-to-exceed maximum load was estimated at a low flow of 8000 gpm. These not-to-exceed estimates were:

Impeller: 800 pounds

Inducer: 13,300 in-lb moment

The impeller load is based on an estimate of six percent of the axial thrust acting as a radial thrust. The inducer moment is based on tests of three-bladed inducers which are more likely to experience radial loads. However, the inducer radial load would not be expected to occur at the NPSH margins expected for the I.S.I.P. design.

Axial Thrust Control

The specification required that the axial thrust not exceed 70,000 pounds in the upward direction and 40,000 pounds downward. It also required that these thrust values be met with an assumed variation of the impeller discharge static pressure of ten percent from front shroud to rear shroud. The axial thrust control was to be achieved without use of a balance piston.

Figure 10 presents the nominal axial thrust for the I.S.I.P. design. The nominal thrust is less than 13,000 pounds at all operating conditions.

INTERMEDIATE-SIZE INDUCER PUMP
N = 1110 RPM
INDUCER INLET PRESSURE = 16.64 PSIA TOTAL
12 BLEED HOLES
1.25 IN. BLEED HOLE DIAMETER




FIGURE 10.

With the additional assumption of the ten percent variation in static pressure the following maximum conditions were obtained:

1. Maximum thrust equals 24,800 pounds downward at 8000 gpm.
2. Maximum thrust equals 7,200 pounds upward at 18000 gpm.


Case one assumes the rear shroud pressure is higher by ten percent and case two assumes the front shroud pressure is higher. This ten percent variation in static pressure is believed to be higher than will be experienced in the pump, but the thrust values are all well within the limits specified, and no balance piston system is required.

Recirculating Flows

The specification originally required that the hydrostatic bearing discharge pressure was not to exceed 10 psi above the inducer inlet pressure at the design point. To achieve this goal would require that the bearing discharge flow be ducted back to the inducer inlet. However, because the pump must be fitted into the existing housing, the impeller rear wear ring flow would also have to be dumped into the inducer inlet, or at least a portion of it if another rotating seal were added. Rocketdyne did not like this concept because dumping any significant amount of fluid into the inducer inlet could be detrimental to the suction performance capability. A simpler approach was analyzed and is shown in Figure 11. The bearing discharge flow and rear wear ring flow are collected and dumped into the impeller inlet rather than the inducer inlet. The impeller has the tolerance required to accept the flow without any degradation in overall suction performance. Using this approach gives a bearing discharge pressure that is 13 psi above the inducer inlet pressure rather than the 10 psi originally specified. It was agreed at Atomics International to change the specification to approve the Rocketdyne design.

RECIRCULATION FLOWS
INTERMEDIATE-SIZE INDUCER PUMP
1110 RPM
DESIGN FLOW

N266ER000-001
Page 272



-27-

FIGURE 11.

N266ER000-002
Page 29

Figure 12 shows the differential pressure of the bearing discharge pressure minus inducer inlet pressure as a function of flowrate. The curve results are based on usage of twelve bleed holes at a diameter of 1.25 inches. The total flowrate through the impeller includes the bearing flow, rear wear ring flow, and front wear ring flow. The wear rings are located to achieve the axial thrust results previously presented. The flow through the wear rings is minimized by using properly designed stepped-labyrinth seals.

INTERMEDIATE-SIZE INDUCER PUMP
N = 1110 RPM
INDUCER INLET PRESSURE = 16.64 PSIA TOTAL
12 BLEED HOLES
1.25 IN. BLEED HOLE DIAMETER

ΔP = BRG. DISCH. STATIC PRESS. - INDUCER INLET STATIC PR.




FIGURE 12.

CONCLUSIONS

The hydrodynamic design has been based on techniques developed and proven over the past twenty-five year period. The analytical tools used are the most advanced available and have been checked out by correlation with available test data. The confidence in achieving the design performance predictions is, therefore, very high.

The design has been shown to meet the specification requirements in all cases where analytical predictions can be made. In fact, design margins have been included in all of these cases to provide additional confidence in meeting the predicted values. Two areas need verification through testing, regardless of whether an inducer pump or an impeller-only design is incorporated. The first is the suction performance margin at the highest flow condition. The quoted margin of 38 percent is expected to be representative but requires test support. The second area is the life characteristics of the design. All of the design features are based on proven designs for long life waterjet pumps at the design point. Life at the off-design flow requires test evaluation.




APPENDIX H

STEADY-STATE STRUCTURAL ANALYSIS
(PUMP INTERNALS)

ESG Document N266SR000001

Figures 1 thru 29 (except Figure 9) have been removed from this document because they contain proprietary information, as defined by DOE contract.

		SUPPORTING DOCUMENT		NUMBER N266SR000001	REV LTR/CHG NO. SEE SUMMARY OF CHG
PROGRAM TITLE Intermediate-Size Inducer Pump				DOCUMENT TYPE Stress Report	
DOCUMENT TITLE Steady-State Structural Analysis (Pump Internals)				KEY NOUNS Pump, Inducer, Steady-State Stress	
PREPARED BY/DATE M. Sasaki (Rocketdyne Div. 055) 545-114 AC14				ORIGINAL ISSUE DATE August 1, 1978	GO NO. 09280 S/A NO. 23000 PAGE 1 OF TOTAL PAGES 116 REL. DATE 8-7-78 <i>ll</i>
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				SECURITY CLASSIFICATION (CHECK ONE BOX ONLY) (CHECK ONE BOX ONLY)	
APPROVALS T. J. Boardman <i>T. J. Boardman</i> 8/3/78 H. M. Minami <i>H. M. Minami</i> 8/04/78 R. V. Anderson <i>R. V. Anderson</i> 8/14/78				UNCL <input checked="" type="checkbox"/> DOE <input checked="" type="checkbox"/> DOD <input type="checkbox"/> RESTRICTED DATA <input type="checkbox"/> CONF. <input type="checkbox"/> SECRET <input type="checkbox"/> DEFENSE INFO. <input type="checkbox"/>	AUTHORIZED CLASSIFIER _____ DATE _____
DISTRIBUTION			ABSTRACT		
* NAME	MAIL ADDR	This report summarizes the structural analyses of the Intermediate-Size Inducer Pump. The report contains a brief explanation of the method of analysis used and the results of the steady-state stress analysis performed on the inducer, impeller, diffuser assembly and the shaft extension bolt. This report was prepared by Rocketdyne (Div. 055) under IDWA 1289.			
* T. Boardman	LB39				
* R. Anderson	LB17				
* H. Minami	LB30				
* J. Nishizaka	LB30				
* L. Rico	LB30				
G. Hallinan	LB39				
R. Schnurstein	LB17				
E. Andrews	KB45				
L. Stabinsky	JB05				
J. Pfouts	JB05				
R. Hoshide	JB05				
P. Ferry	LB03				
C. Torrijos	LB26				
P. Jeneck	LB26				
C. Conners	LB30				
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY			RESERVED FOR PROPRIETARY/LEGAL NOTICES <div style="border: 1px solid black; padding: 10px; display: inline-block;"> NOTE: Proprietary Information as defined in the contract with <u>DOE</u> has been removed from this document for use in N266ER000-001. </div>		

AI INTERMEDIATE-SIZE INDUCER PUMP
STRUCTURAL SUMMARY

Introduction

In accordance with the Statement of Work per Intermediate-Size Inducer Pump, IDWA N-1289, Ref. 1, a steady-state stress analysis has been performed on the inducer, impeller, diffuser assembly and the shaft extension bolt. The components are structurally adequate for the steady-state operation. The method of analysis and the results are summarized in this summary report.

Design Criteria

The design criteria used in the analysis was established by Atomics International (AI) and is set forth in Ref. 2. The AI allowable stress limits are lower than those allowed by the ASME Boiler and Pressure Vessel Code to leave margin for thermal transient stresses. The AI allowable stress limits for 304 stainless steel at 1050°F are:

1. Primary membrane stress (P_M) = 7450 psi.
2. Local membrane plus bending ($P_L + P_B$) = 7730 psi.

However, two specific exceptions were granted by AI to cover the two locations where the ($P_L + P_B$) stresses exceeded the recommended allowables. The two locations are the forward fillet radius in the inside diameter of the inducer hub and the diffuser vane. The calculated inducer fillet stress was 9630 psi. An increase in the allowable stress to 11200 psi was granted for the inducer, Ref. 3. The calculated diffuser vane stress was 8410 psi and the allowable stress was increased to 9000 psi, Ref. 4.

The design criteria for A286 material used in the shaft extension bolt is set forth in Ref. 4. The recommended allowable stresses at 1050°F are 15000 psi for (P_M) and 20000 psi for ($P_L + P_B$).

Operating Conditions

The pump components were analyzed for steady-state operation at the following operating points.

1. Steady-state design point.
2. Steady-state maximum pressure condition.
3. Steady-state maximum power condition.
4. Transient maximum operating pressure condition.

Table 1 lists the speed, flowrate and the temperature of the above four operating points.

The pump components were analyzed based on operating points or combination of operating points which produced the maximum load condition. These loads were treated as steady-state loads.

Inducer

The inducer blade and hub were analyzed under steady-state operating conditions in order to determine their structural adequacy and compliance with the AI steady-state structural criteria (Ref. 1).

Inducer Blade

The inducer blade was analyzed to:

1. Determine stresses at the blade-hub intersection.

2. Determine stresses throughout the blade.

The analysis of step 1. assumes that the blade acts as a series of wedge-shaped cantilever beams under a combined loading of:

- a. Pressure bending moment.
- b. Centrifugal radial force.
- c. Centrifugal bending moment for canted blades.

Bending and membrane stresses are determined at the root of each wedge-shaped beam and then correction factors are applied in order to account for:

- a. the blade twist due to the helix angle;
- b. the tangential load carrying capability of the blade (disk effect);
- c. the distribution of moment at the hub due to plate behavior of the blade.

Under step 2. a finite element computer program was used to calculate stresses and deflections throughout the blade. The blade was modeled as a grid of elastic, triangular plate elements of linearly varying thickness with Δp pressure and centrifugal loads.

The Δp pressure load used in the analysis is a composite of the maximum pressure differences for flowrates at a speed of 1110 RPM. Pressures for 8000 GPM control over the first one-third to one-half of the blade length while pressures for 14500 GPM control for the remainder of the blade. The Δp pressure distribution contours plots are shown in Figure 1. All centrifugal forces are at 1110 RPM.

Results of the inducer blade analysis are summarized in Figure 2. The operating conditions corresponding to the most severe blade loading, the resulting stress intensities, stress intensity contour plots, material, allowable ($P_L + P_B$) stress and design margins are shown. The stress intensities shown are located on the blade pressure surface where tension from centrifugal loading and pressure bending combine to produce the most severe stress condition. The maximum stress intensity in the blade is 5.60 KSI and occurs at the blade-hub intersection at a location corresponding to the start of the full blade height. This maximum stress intensity results in a design margin of:

$$D. M. = \frac{7.73}{5.60} - 1 = .38$$

Figures 3 through 6 are stress contour plots of the radial, tangential, shear in radial and tangential plane and maximum shear on the blade pressure side. Figure 7 is a contour plot of blade deflection in the axial direction.

Inducer Hub

The inducer hub was analyzed using a finite element computer program for axisymmetric solids. In addition, the hub was analyzed for the non-axisymmetric loads. The non-axisymmetric load analysis consisted of hand calculation using the theories of plates and shells. The results from the non-axisymmetric analysis were superimposed on the results from the finite element analysis.

The inducer hub was evaluated under the following loads:

I. Axisymmetric loads

1. Pressure loads on the inner and outer surface.
2. Axial load during operation which includes the effect of initial preload and operating thrust.
3. Centrifugal loading due to rotation of the hub and the blades.

II. Non-axisymmetric loads

1. Bending of the hub due to blade bending at the blade-hub intersection.
2. Couple on the hub from the key.
3. Bending of the hub due to a hydrodynamic couple.

The pressure loads are shown in Figure 8. The 695 psia shown in Figure 8 represents axial load in terms of pressure.

The maximum loading condition on the inducer hub results in the stress intensity contours shown in Figure 9. The maximum stress intensity in the hub occurs in the fillet radius joining the hub inlet section and the retaining nut bearing flange. The close spacing of the contours indicates a highly localized stress concentration effect at a gross structural discontinuity. The maximum stress intensity in the hub of 9.63 KSI is due to combined axisymmetric and non-axisymmetric loads and results in a design margin of .16. It should be noted that in the inlet region of the inducer hub, provision has been made for the removal of material for balancing purposes. If the maximum material were removed, the maximum stress intensity

at the balance groove surface will be equal to the maximum allowable stress intensity of 7.73 KSI. The Figure 9 also summarizes the operating conditions, material, and design criteria. Figures 10 through 29 are stress contour plots of the radial, axial, tangential, shear in radial and axial plane, and maximum shear for the axisymmetric loads.

Impeller

Compliance of the impeller design with the AI stress criteria was determined through:

1. hand analysis of the impeller full and partial vanes;
2. a two dimensional, axisymmetric finite element analysis of the hub and shroud.

Impeller Vanes

The impeller vanes were analyzed as fixed-ended beams of constant thickness and unit width connecting the outer shroud to the hub. Loading for each beam was assumed to be:

1. A uniform pressure difference across the vane width.
2. Centrifugal loading due to rotation of the vane.

A typical vane section with the pressure and centrifugal loadings is shown in Figure 30. The pressure distribution imposed on the vanes is shown in Figure 31. The maximum stress intensities as well as the corresponding design margins and wrap angle locations in the full and partial vanes are:

	<u>Wrap Angle</u>	<u>S_{MAX} KSI</u>	<u>D. M.</u>
Full Vanes	90°	2.41	2.21
Partial Vanes	10°	1.08	6.16

It should be noted that for the impeller vanes, the wrap angle is measured from the trailing edge which is the reverse of the convention used for the inducer blade.

Impeller Hub and Shroud

The impeller hub and shroud were analyzed for the following loads:

I. Axisymmetric loads

1. Fluid pressures.
2. Axial load during operation from the effect of initial preload and operating thrust.
3. Centrifugal loading due to rotation of the hub and shroud as well as the impeller vanes.
4. Shrink fit corresponding to a maximum radial interference of .0013 inches between the impeller hub and pump shaft.

II. Non-axisymmetric loads

1. Couple on the hub from the shear keys.
2. Bearing at the impeller keyway.

For axisymmetric loads, the hub and shroud were analyzed using a finite element computer code for axisymmetric solids. The basic finite element model is modified in the bleed hole and vane regions to account for a reduced tangential (hoop) continuity.

In the vane region the model is further modified to account for material distribution and vane orientation. Such modifications are made in an attempt to simulate the vane behavior in as much as this behavior affects the stress distribution in the impeller hub and shroud. As a result, stresses in the vane region from the finite element model are not true stresses. In order to simulate the impeller-shaft elastic interaction the finite element model also includes a portion of the existing shaft.

Figure 32 shows the impeller profile and the maximum loadings imposed upon it under steady-state operating conditions. The resulting stress intensity contours from the finite element model are shown in Figure 33. The maximum stress intensity of 7.48 KSI occurs in the hub at the hub-shaft interface and results in a design margin of .03.

Figure 34 shows the stress intensity contours on the hub profile resulting from the shrink fit of the impeller onto the stepped, tapered shaft. The shrink fit procedure involves sliding the impeller onto the shaft until contact is made and then removing and heating the impeller. The impeller is then replaced on the shaft to a position .025 inches axially beyond the original contact point and allowed to cool. This results in a maximum radial interference of .0013 inches.

Figures 35 through 59 are stress contour plots in the impeller hub and shroud of the following stresses: radial, axial, tangential, shear in axial and radial plane, and maximum shear for the axisymmetric loads.

Diffuser Assembly

The transition diffuser assembly was analyzed using a two-dimensional finite element computer program. The loading is primarily a pressure differential across the diffuser thickness and the local effects of the mounting and connecting bolt loads. In the diffuser vane region of the computer model, allowance is made to account for the lack of tangential (hoop) continuity and the actual vane geometry in an attempt to simulate the correct vane behavior. For this reason, stresses in the vane region from the finite element model are used only to determine the membrane loads and bending moments imposed on the vanes. Figure 60 shows the operating conditions corresponding to the maximum diffuser pressure load and the pressure distribution imposed upon the diffuser assembly. Figure 61 summarizes the result of the diffuser assembly analysis. The operating condition, material, allowable stress intensities, stress contour plots and design margin at various locations of the diffuser assembly are shown. The maximum stress intensity of 8.41 KSI occurs in the diffuser vanes and is shown in Figure 62.

Figures 63 through 102 are stress contour plots of the radial, axial, tangential, shear in radial and axial plane, and maximum shear for the axisymmetric pressure loads.

Shaft Extension

The shaft extension was examined using appropriate hand analyses based on shell and ring theory. It should be noted that the shaft material is A286 steel while the inducer, impeller, and diffuser materials are all 304 stainless steels.

The shaft extension maximum load operating conditions as well as the resulting stress intensities and design margins at various locations are listed in Figure 103. The maximum stress intensity of 15.6 KSI with a design margin of .28 occurs at a fillet, (location A), as a result of combined axial membrane tension and bending due to eccentricity of the axial load.

References

1. Intermediate-Size Inducer Pump IDWA N-1289.
2. AI Letter 77AT-10423, R. V. Anderson (AI) to R. E. Davis (Rocketdyne), Intermediate-Size Inducer Pump, IDWA N-1289, Revision A, dated November 11, 1977.
3. AI Letter, T. Boardman (AI) to J. Wolf (Rocketdyne), Intermediate-Size Inducer Pump (ISIP) Structural Design Criteria, dated May 17, 1978.
4. AI Letter, T. J. Boardman (AI) to J. E. Wolf (Rocketdyne), Intermediate-Size Inducer Pump (ISIP), IDWA N-1289 Allowable Stress Values, dated April 19, 1978.

TABLE I
AI INTERMEDIATE SIZE SODIUM PUMP

• OPERATING CONDITIONS:

• SPEED RPM


• FLOWRATE GPM

• TEMPERATURE °F

		STEADY STATE			TRANSIENT MAX. OP. PRESS. CONDITION
		DESIGN POINT	MAX. S.S. PRESS. CONDITION	MAX. POWER CONDITION	
		1110	1110	1110	1110
		14500	11750	18000	8000
		1050°	1050°	1050°	1050°

FIGURE 9

INDUCER HUB STRESS INTENSITIES



*S MAX. = 9.63 KSI

● OPERATING CONDITIONS

TEMPERATURE 1050 F
 SPEED 1110 RPM
 AXIAL LOAD 22.6 KIPS
 FLOWRATE 8000 GPM

● MATERIAL: 304 CRES

$S_M = 7.73 \text{ KSI (PL + PB)}$

* $S_{M \text{ Max.}} = 11.20 \text{ KSI}$

● STRESS INTENSITIES

LOCATION	S, KSI	DESIGN MARGIN
A	.06	127.83
B	.59	12.10
C	1.17	5.61
D	1.76	3.39
E	2.35	2.29
F	2.94	1.63
*S MAX.	9.63	.16

FIGURE 30
AXIAL VIEW OF IMPELLER FULL VANE LOOKING
FROM IMPELLER INLET TOWARD OUTLET





FIGURE 31

IMPELLER VANE P PRESSURE LOADING
N = 1110 RPM
Q = 8000 and 14500 GPM




FIGURE 33
 IMPELLER STRESS INTENSITIES
 STEADY STATE CONDITIONS

LOADING:

SHRINK FIT 0.0013 IN, RADIAL
 TEMP. 1050F
 SPEED 1110 RPM
 FLOWRATE 8000 GPM
 PRELOAD 21 KIPS

STRESS INTENSITIES

LOCATION	S KSI	DESIGN MARGIN
K	7.48	.03
J	6.72	.15
H	5.88	.31
G	5.04	.53
D	2.52	2.07
B	.84	8.20

MATERIAL: 304 CRES

$$S_m = 7.73 \text{ KSI } (P_1 + P_b)$$




FIGURE 34
 IMPELLER STRESS INTENSITIES
 SHRINK FIT

N266ER000-001
 Page 295

LOADING:


SHRINK FIT .0013 IN RADIAL
 TEMP. 70F and 1050F
 SPEED 0 RPM
 PRESSURE 0
 PRELOAD 21 KIPS

STRESS INTENSITIES

LOCATION	S KSI		DESIGN MARGIN	
	70F	1050F	70F	1050F
K	10.50	8.20	.90	-.06
J	9.44	7.37	1.12	.05
H	8.26	6.45	1.42	.20
G	7.08	5.52	1.82	.40
F	5.90	4.61	2.39	.68

MATERIAL: 304 CRES

70F: $S_m = 20.00$ KSI ($P_1 + P_b$)
 1050F: $S_m = 7.73$ KSI ($P_1 + P_b$)



N266SR000001
 Page 47

FIGURE 35

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-P IS PLOTTED




FIGURE 36

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 37

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 38

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 39

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 40

RI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED





FIGURE 41

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED



A	-2.65X10 ⁰²	B	-2.07X10 ⁰²	C	-1.43X10 ⁰²	D	-7.96X10 ⁰¹	E	-1.40X10 ⁰¹	F	5.04X10 ⁰¹	Z . P . 11
G	1.15X10 ⁰²	H	1.79X10 ⁰²	J	2.44X10 ⁰²	K	3.02X10 ⁰²					

FIGURE 42

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 43

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 44

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED





FIGURE 45

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED



	0	5	10	15	20	
A -4.41X10 ⁰³	B -3.42X10 ⁰³	C -2.33X10 ⁰³	D -1.23X10 ⁰³	E -1.46X10 ⁰²	F 9.47X10 ⁰²	Z . . .
G 2.04X10 ⁰³	H 3.13X10 ⁰³	J 4.22X10 ⁰³	K 5.21X10 ⁰³			

FIGURE 46

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED





FIGURE 47

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED



	5.0	6.0	7.0	8.0	9.0	10.0	11.0
A	-2.76×10^{03}	-2.18×10^{03}	-1.55×10^{03}	-9.15×10^{02}	-2.79×10^{02}	3.56×10^{02}	Z . A '9
G	9.92×10^{02}	1.62×10^{03}	2.25×10^{03}	2.83×10^{03}			

FIGURE 48

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 49

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED





FIGURE 50

A1 INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED



	0	5	10	15	20	
R	-1.28X10 ⁰³	-1.03X10 ⁰³	-7.63X10 ⁰²	-4.90X10 ⁰²	-2.18X10 ⁰²	3.40X10 ⁰¹
G	3.26X10 ⁰²	5.99X10 ⁰²	8.71X10 ⁰²	1.11X10 ⁰³		

FIGURE 51

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 52

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 53

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 54

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 55

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 56

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 57

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 58

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 59

AI INTERMEDIATE SODIUM PUMP IMPELLER
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 60





FIGURE 61

DIFFUSER STRESS INTENSITIES



● Operating Conditions

Temperature 1050 F
 Speed 1110 RPM
 Flowrate 8000 GPM

● Material: 304 CRES


$S_M = 7.73$ KSI ($P_L + P_B$)
 $*S_M = 9.00$ KSI

● Stress Intensities

<u>Location</u>	<u>S, KSI</u>	<u>Design Margin</u>
A	.14	54.21
B	1.37	4.64
C	2.74	1.82
D	4.11	.88
E	5.48	.41
*F	7.36	.22
*S _{Vanes}	8.41	.07

FIGURE 62

DIFFUSER VANES STRESS INTENSITIES



OPERATING CONDITIONS

TEMPERATURE 1050 F
SPEED 1110 RPM
FLOWRATE 8000* AND 12000 GPM

MATERIAL: 304 CRES
 $S_M = 7.73 \text{ KSI } (P_L + P_B)$
* $S_M = 9.00 \text{ KSI}$

STRESS INTENSITIES

<u>FLOWRATE</u>	<u>SMAX</u>	<u>DESIGN MARGIN</u>
*8000	*8.41	*.07
12000	7.61	.02

FIGURE 63

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 64

RIISP DIFFUSER - SHROUD T=90, SUPPORT T=90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 65

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED





FIGURE 66

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED



	11.0	12.0	13.0	14.0	15.0	16.0	Z . . . A X I S
A	-3.23X10 ⁰³	B -2.97X10 ⁰³	C -2.69X10 ⁰³	D -2.40X10 ⁰³	E -2.11X10 ⁰³	F -1.82X10 ⁰³	
G	-1.53X10 ⁰³	H -1.25X10 ⁰³	J -9.63X10 ⁰²	K -6.75X10 ⁰²	L -3.87X10 ⁰²	M -9.96X10 ⁰¹	
N	1.88X10 ⁰²	O 4.76X10 ⁰²	P 7.63X10 ⁰²	Q 1.05X10 ⁰³	R 1.33X10 ⁰³	S 1.59X10 ⁰³	

FIGURE 67

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 6000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED





FIGURE 68

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED



15.0	16.0	17.0	18.0	19.0	20.0
A -3.08X10 ⁰³	B -2.30X10 ⁰³	C -2.49X10 ⁰³	D -2.18X10 ⁰³	E -1.87X10 ⁰³	F -1.57X10 ⁰³
G -1.26X10 ⁰³	H -9.55X10 ⁰²	J -6.46X10 ⁰²	K -3.38X10 ⁰²	L -3.07X10 ⁰¹	M 2.77X10 ⁰²
N 5.85X10 ⁰²	O 8.93X10 ⁰²	P 1.20X10 ⁰³	Q 1.50X10 ⁰³	R 1.81X10 ⁰³	S 2.09X10 ⁰³
					Z .9X1S

FIGURE 69

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 70

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-R IS PLOTTED




FIGURE 71

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 RPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 72

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED





FIGURE 73

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED



	9.0	10.0	11.0	12.0	13.0	
R -1.06X10 ⁰³	B -9.97X10 ⁰²	C -9.23X10 ⁰²	D -8.48X10 ⁰²	E -7.74X10 ⁰²	F -6.99X10 ⁰²	Z . AXIS
G -6.25X10 ⁰²	H -5.50X10 ⁰²	J -4.76X10 ⁰²	K -4.01X10 ⁰²	L -3.27X10 ⁰²	M -2.52X10 ⁰²	
N -1.78X10 ⁰²	O -1.03X10 ⁰²	P -2.92X10 ⁰¹	Q 4.52X10 ⁰¹	R 1.19X10 ⁰²	S 1.86X10 ⁰²	

FIGURE 74

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 75

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 76

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 77

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 78

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-Z IS PLOTTED




FIGURE 79

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 81

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 EPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 82

AIISP DIFFUSER - SHPOUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 83

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED





FIGURE 84

RIISP DIFFUSER - SHROUD T=90, SUPPORT T=90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED



15.0	16.0	17.0	18.0	19.0	20.0
A -2.81X10 ⁰³	B -2.64X10 ⁰³	C -2.45X10 ⁰³	D -2.26X10 ⁰³	E -2.08X10 ⁰³	F -1.89X10 ⁰³
G -1.70X10 ⁰³	H -1.51X10 ⁰³	J -1.33X10 ⁰³	K -1.14X10 ⁰³	L -9.56X10 ⁰²	M -7.69X10 ⁰²
N -5.82X10 ⁰²	O -3.95X10 ⁰²	P -2.07X10 ⁰²	Q -2.05X10 ⁰¹	R 1.66X10 ⁰²	S 3.35X10 ⁰²
					Z . 9X13

FIGURE 85

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 86

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-T IS PLOTTED




FIGURE 87

AIISP DIFFUSER - SHROLD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 88

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 89

AIISP DIFFUSER - SHROUD T=90, SUPPORT T=90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 90

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-PZ IS PLOTTED




FIGURE 91

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 92

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 93

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 94

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS SIGMA-RZ IS PLOTTED




FIGURE 95

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 96

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 97

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 98

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 99

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 100

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 101

RIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TAU-MAX IS PLOTTED




FIGURE 102

AIISP DIFFUSER - SHROUD T=.90, SUPPORT T=.90, 8000 GPM
AXISYMMETRIC ANALYSIS TRU-MAX IS PLOTTED





FIGURE 103

SHAFT EXTENSION STRESS INTENSITIES



• OPERATING CONDITIONS

TEMPERATURE 1050°F
 SPEED 1110 RPM
 AXIAL LOAD 22.6 KIPS

• MATERIAL: A286

1 $S_M = 15.0$ KSI (P_M)
 $S_M = 20.0$ KSI ($P_L + P_B$)

• STRESS INTENSITIES


<u>LOCATION</u>	<u>S KSI</u>	<u>DESIGN MARGIN</u>
A	15.6	.28
B	15.1	.32
C	7.9	1.53
D	6.5	2.08
E ¹	4.5	2.33
F ¹	2.7	4.56
G ¹	4.0	2.75



APPENDIX I

INTERMEDIATE SIZE INDUCER PUMP -
STRUCTURAL ANALYSIS AND TRANSIENT
DEFORMATION STUDIES

ESG Document N266SR000-002

 SUPPORTING DOCUMENT		NUMBER N266SR000-002	REV. TR/CHG NO. NC <small>SEE SUMMARY OF CHG</small>																																						
PROGRAM TITLE Intermediate Size Inducer Pump (ISIP)		DOCUMENT TYPE Stress Report																																							
DOCUMENT TITLE Intermediate Size Inducer Pump - Structural Analysis and Transient Deformation Studies		KEY NOUNS ISIP, Structural and Transient Deformation																																							
PREPARED BY/DATE T. K. Cheng <i>T.K. Cheng</i> 731 LB35 J. N. Nishizaka <i>J.N. Nishizaka</i> 731 LB35		ORIGINAL ISSUE DATE	GO NO. 09280 S/A NO. 22000 PAGE 1 OF TOTAL PAGES 132 REL. DATE 5-7-79 <i>BL</i>																																						
IR&D PROGRAM? YES <input type="checkbox"/> NO <input type="checkbox"/> IF YES, ENTER TPA NO.		SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)																																							
APPROVALS R. V. Anderson <i>R.V. Anderson</i> 5/7/79 T. J. Boardman <i>T.J. Boardman</i> R. A. Castle <i>R.A. Castle</i>		(CHECK ONE BOX ONLY) UNCL <input checked="" type="checkbox"/> DOE <input type="checkbox"/> DOD <input type="checkbox"/> CONF. <input type="checkbox"/> DEFENSE INFO. <input type="checkbox"/> SECRET <input type="checkbox"/>	AUTHORIZED CLASSIFIER _____ DATE _____																																						
DISTRIBUTION		ABSTRACT																																							
<table border="1"> <thead> <tr> <th>* NAME</th> <th>MAIL ADDR</th> </tr> </thead> <tbody> <tr><td>* R. V. Anderson (8)</td><td>LB02</td></tr> <tr><td>R. J. Beeley</td><td>T019</td></tr> <tr><td>* T. J. Boardman</td><td>LB13</td></tr> <tr><td>R. A. Castle</td><td>LB35</td></tr> <tr><td>* T. K. Cheng</td><td>LB35</td></tr> <tr><td>C. C. Conners</td><td>LB30</td></tr> <tr><td>* C. Dunn</td><td>LB02</td></tr> <tr><td>M. A. Grisham</td><td>LB26</td></tr> <tr><td>G. J. Hallinan</td><td>LB39</td></tr> <tr><td>R. K. Hoshide</td><td>JB05</td></tr> <tr><td>* J. L. Lockett</td><td>LB39</td></tr> <tr><td>* A. A. Loffredo</td><td>LB35</td></tr> <tr><td>E. M. Mouradian</td><td>LB35</td></tr> <tr><td>G. W. Meyers</td><td>LA10</td></tr> <tr><td>D. K. Nelson</td><td>LB35</td></tr> <tr><td>* J. N. Nishizaka</td><td>LB35</td></tr> <tr><td>C. Q. Torrijos</td><td>LB26</td></tr> <tr><td>K. H. Yun</td><td>LB35</td></tr> </tbody> </table>		* NAME	MAIL ADDR	* R. V. Anderson (8)	LB02	R. J. Beeley	T019	* T. J. Boardman	LB13	R. A. Castle	LB35	* T. K. Cheng	LB35	C. C. Conners	LB30	* C. Dunn	LB02	M. A. Grisham	LB26	G. J. Hallinan	LB39	R. K. Hoshide	JB05	* J. L. Lockett	LB39	* A. A. Loffredo	LB35	E. M. Mouradian	LB35	G. W. Meyers	LA10	D. K. Nelson	LB35	* J. N. Nishizaka	LB35	C. Q. Torrijos	LB26	K. H. Yun	LB35	<p>This report summarizes the structural and thermal transient deformation analysis of the Intermediate Size Inducer Pump. The analyses were performed in accordance to the requirements of N266ST310001, the specification for the ISIP.</p> <p>The results of stress analysis indicate that the thermal transient stress and strain are within the stress strain limits of RDT standard F9-4 which was used as a guide. The summary of results are shown on Pages 17, 21, and 25.</p>	
* NAME	MAIL ADDR																																								
* R. V. Anderson (8)	LB02																																								
R. J. Beeley	T019																																								
* T. J. Boardman	LB13																																								
R. A. Castle	LB35																																								
* T. K. Cheng	LB35																																								
C. C. Conners	LB30																																								
* C. Dunn	LB02																																								
M. A. Grisham	LB26																																								
G. J. Hallinan	LB39																																								
R. K. Hoshide	JB05																																								
* J. L. Lockett	LB39																																								
* A. A. Loffredo	LB35																																								
E. M. Mouradian	LB35																																								
G. W. Meyers	LA10																																								
D. K. Nelson	LB35																																								
* J. N. Nishizaka	LB35																																								
C. Q. Torrijos	LB26																																								
K. H. Yun	LB35																																								
731-D.260/abg/jdj		RESERVED FOR PROPRIETARY/LEGAL NOTICES <p style="text-align: center;">THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE</p> <p>This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.</p>																																							
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																																									



CONTENTS

	<u>Page</u>
1.0 INTRODUCTION.....	6
2.0 SUMMARY.....	7
3.0 DISCUSSION.....	8
3.1 Test Criteria.....	9
3.2 Analytical Procedure.....	10
3.3 Transient Data.....	10
3.4 Structural Criteria.....	11
4.0 REFERENCES.....	23
APPENDICES.....	24
A. Structural Analysis.....	24
a. Strain Limit Evaluation.....	24
b. Creep-Fatigue Damage Evaluation.....	24
B. Thermal Deformation Analysis.....	61



TABLES

<u>Table</u>	<u>Page</u>
1. Critical Clearance Change.....	17
2. Component Strain.....	21
3. Component Thermal Stresses.....	22
A-1 Component Stresses.....	27
A-2 Component Strain.....	28
B-1 Radial Clearance for Test Transient E-202 @ Bearing Area....	74
B-2 Radial Clearance for Test Transient E-203 @ Bearing Area....	75
B-3 Radial Clearance for Test Transient E-204 @ Bearing Area....	76
B-4 Radial Clearance for Test Transient E-207 @ Bearing Area....	77
B-5 Radial Clearance for Test Transient E-208 @ Bearing Area....	78
B-6 Radial Clearance for Test Transient E-210 @ Bearing Area....	79
B-7 Radial Clearance for Test Transient E-202 @ Diffuser Shroud.....	80
B-8 Radial Clearance for Test Transient E-203 @ Diffuser Shroud.....	81
B-9 Radial Clearance for Test Transient E-204 @ Diffuser Shroud.....	82
B-10 Radial Clearance for Test Transient E-207 @ Diffuser Shroud.....	83
B-11 Radial Clearance for Test Transient E-208 @ Diffuser Shroud.....	84
B-12 Radial Clearance for Test Transient E-210 @ Diffuser Shroud.....	85
B-13 Radial Clearance Change for Test Transient E-202 @ Front Labyrinth Seal.....	86
B-14 Radial Clearance Change for Test Transient E-203 @ Front Labyrinth Seal.....	87
B-15 Radial Clearance Change for Test Transient E-204 @ Front Labyrinth Seal.....	88
B-16 Radial Clearance Change for Test Transient E-207 @ Front Labyrinth Seal.....	89
B-17 Radial Clearance Change for Test Transient E-208 @ Front Labyrinth Seal.....	90
B-18 Radial Clearance Change for Test Transient E-210 @ Front Labyrinth Seal.....	91



TABLES
(Continued)

<u>Table</u>	<u>Page</u>
B-19 Radial Clearance Change for Test Transient E-202 @ Rear Labyrinth Seal.....	92
B-20 Radial Clearance Change for Test Transient E-203 @ Rear Labyrinth Seal.....	93
B-21 Radial Clearance Change for Test Transient E-204 @ Rear Labyrinth Seal.....	94
B-22 Radial Clearance Change for Test Transient E-207 @ Rear Labyrinth Seal.....	95
B-23 Radial Clearance Change for Test Transient E-208 @ Rear Labyrinth Seal.....	96
B-24 Radial Clearance Change for Test Transient E-210 @ Rear Labyrinth Seal.....	97
B-25 Radial Clearance Change for Test Transient E-202 @ Inducer Blade.....	98
B-26 Radial Clearance Change for Test Transient E-203 @ Inducer Blade.....	99
B-27 Radial Clearance Change for Test Transient E-204 @ Inducer Blade.....	100
B-28 Radial Clearance Change for Test Transient E-207 @ Inducer Blade.....	101
B-29 Radial Clearance Change for Test Transient E-208 @ Inducer Blade.....	102
B-30 Radial Clearance Change for Test Transient E-210 @ Inducer Blade.....	103
B-31 Radial Clearance Change for Test Transient E-202 @ Bearing Support.....	104
B-32 Radial Clearance Change for Test Transient E-203 @ Bearing Support.....	105
B-33 Radial Clearance Change for Test Transient E-204 @ Bearing Support.....	106
B-34 Radial Clearance Change for Test Transient E-207 @ Bearing Support.....	107
B-35 Radial Clearance Change for Test Transient E-208 @ Bearing Support.....	108
B-36 Radial Clearance Change for Test Transient E-210 @ Bearing Support.....	109
B-37 Thermal Transient.....	122



FIGURES

<u>Figure</u>	<u>Page</u>
1. Schematic of Inducer-Impeller Assembly.....	16
2. Finite Element Model.....	18
3. Typical Temperature Field.....	19
4. Ratchet Limits (Bree Complete Relaxation).....	20
B-1 APSA Model for Static Assembly.....	62
B-2 APSA Model for Rotating Assembly.....	63
B-3 Finite Element Model @ Bearing Area - Node Point No.....	64
B-4 Finite Element Model @ Bearing Area - Element No.....	65
B-5 Finite Element Model @ Impeller Shaft - Node Point No.....	66
B-6 Finite Element Model @ Impeller Shaft - Element No.....	67
B-7 Finite Element Model @ Diffuser - Node Point No.....	68
B-8 Finite Element Model @ Diffuser - Element No.....	69
B-9 Finite Element Model @ Inducer Blade - Node Point No.....	70
B-10 Finite Element Model @ Inducer Blade - Element No.....	71
B-11 Finite Element Model @ Diffuser Shroud - Node Point No.....	72
B-12 Finite Element Model @ Diffuser Shroud - Element No.....	73
B-13 Transient E-202.....	110
B-14 Transient E-203.....	111
B-15 Transient E-204.....	112
B-16 Transient E-207.....	113
B-17 Transient E-208.....	114
B-18 Transient E-210.....	115
B-19 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	116
B-20 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	117
B-21 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	118
B-22 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	119
B-23 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	120
B-24 Stress Intensity @ Pump Component for Transient E-207 @ Time = 275 Sec.....	121



FIGURES
(Continued)

<u>Figure</u>		<u>Page</u>
C-1	Flow Chart.....	125
C-2	JCL Setup.....	126
C-3	JCL Setup.....	127
C-4	JCL Setup.....	128



1.0 INTRODUCTION

The Intermediate Size Inducer Pump (ISIP) utilizes the pump frame from the FFTF Prototype Pump as a test vehicle for an inducer impeller assembly. Construction requirements for the FFTF prototype pump may be found in Westinghouse Specification EWS-1551, which was written for the complete pump. ESG Specification N266ST310001 covers construction requirements for those parts used in the ISIP design to replace prototype pump parts. A complete description of the prototype pump is given in the Westinghouse Operation and Maintenance Manual, OMM-051-00-005. The ISIP Operation and Maintenance Manual N266OMM000001 (Reference 10) describes those parts of the pump assembly which are different for the ISIP configuration.

Structural analyses of the ISIP components in the region of the inducer/impeller assembly was performed to determine the effects of steady-state operation and of thermal transients which are defined as part of the test requirements in the ISIP specification. Evaluation of the structural integrity of the ISIP parts was based on using analytical methods and acceptance criteria of the Section III ASME Boiler and Pressure Vessel Code and appropriate RDT standards as applied to designs for high-temperature service. Evaluation of the steady-state effects are reported in N266SR000001 (Reference 5). This report covers the effects of operation during thermal transients, superimposed on those steady-state conditions.

In addition to the structural analysis, a thermal deformation analysis was conducted to determine the effects of thermal transients on critical regions such as fits and running clearances to permit evaluation of the functionability of the design and of the restrictions, if any, which should be placed on transient testing.

* RDT F9-4 (REF. 1)



2.0 SUMMARY

The thermal deformation analysis was performed for the six test transients for which thermal analysis are reported in Reference 7. The critical clearance changes between rotating and static components are listed in Table 1.

The analysis shows a reduction of 3 mils during thermal transient E-207 at the bearing and journal, and a 7-mil clearance reduction at the rear labyrinth seal during transient E-203.

Table 2 summarizes the results of component strain evaluation. Based on the criteria of RDT Standard F9-4, Section 6, for strain limit, the total accumulated strain of 0.23% is within the 1%, and the total creep-fatigue damage fraction of 0.026 is less than 0.6 as allowed in the specification (REF. 6)



3.0 DISCUSSION

The functional and structural integrity of the inducer/impeller assembly of the intermediate size inducer pump was evaluated based on Subsection NB, Section III Class 1 and Code Case 1592. In addition to the Code criteria used for evaluation of the final analysis, the following stress limits were used for evaluation of the initial steady-state analysis performed by Rocketdyne (Division 055) under IDWA N-1289 (Reference 5).

Steady-state stress limits for Type 304SS and CF8 stainless steel parts at 1050°F were:

$$\left. \begin{array}{l} \text{Primary Membrane Stress } (P_m) = 7,450 \text{ psi} \\ \text{Local Membrane Plus Bending } (P_L + P_b) = 7,730 \text{ psi} \end{array} \right\} \text{Ref. 8}$$

The design criteria for the A286 material used in the shaft extension tie-bolt at 1050°F are:

$$\left. \begin{array}{l} P_m = 15,000 \text{ psi} \\ P_L + P_b = 20,000 \text{ psi} \end{array} \right\} \text{Ref. 8}$$

These steady-state stress limits were selected to have adequate margin below the Code criteria, to provide a high probability of success in meeting the Code criteria during subsequent transient analyses.

Before using the ESG thermal model for analysis of ISIP test transients, an "umbrella" set of transients was selected from those actual transients which had been run during sodium testing of the FFTF prototype pump and analyzed with the ESG thermal model. Reference 4 shows a comparison of the calculated temperatures output from the ESG model



(using actual test input data) to actual temperatures measured during the tests. This data was used to verify the validity of the model. The model was then used with the ISIP test input requirements (which do not differ from previous FFTF pump test requirements) to show that the predicted temperature variations around the critical sodium bearing support structure and other adjacent FFTF parts would not be more severe, or significantly different, than those which had been previously undergone during sodium tests. Structural integrity of the prototype pump parts and functionability of the sodium bearing during ISIP transient tests was based on these results. For the recently designed ISIP parts, results of the thermal analysis were used as input to the ESG stress model for structural evaluation. Calculated stresses for the thermal transient stresses are shown in Table 2.

3.1 TEST CRITERIA

The original transient test requirements of the ISIP specification (Reference 6) included nine thermal transients identical to those previously specified for the FFTF prototype pump. Three of the transient tests were subsequently deleted, leaving six transient tests to be performed on the ISIP, as presently described in Reference 9. The three transients which were deleted were judged not to be significant to the ISIP parts and would only retest the overall pump structure. Based on the test request, the total operating time is expected to be approximately 4000 hours. It is estimated that about 3000 hours will be logged as steady-state operation at 950⁰F, including a 2000-hour design point endurance run and a 300-hour off-design endurance run, and the remainder of the time will be at reduced temperatures (400⁰F to 850⁰F). The total time during which the pump structure will be responding to thermal transients will be less than 6 hours.



Table B-37 shows the six thermal transients from the present test request. The original maximum temperature, as listed in the design specification, was 1050⁰F. For testing, this temperature was later reduced to 950⁰F as being more representative of the maximum temperature for which present LMFBR's are being designed.⁽⁹⁾ The rate and range (Δt) of the transients was not changed.

3.2 ANALYTICAL PROCEDURE

The analysis of deformation and stress of the inducer/impeller assembly was performed using the APSA (Axisymmetrical, Planar Structural Analysis) finite element computer code. Finite element models were developed to structurally represent the area of concern. A separate finite element model consisting of time histories of temperature field for thermal transients was developed. The TAP (Thermal Analysis Program) computer code was used to calculate and provide the temperature field. The worst critical time slice in determining the maximum stress and maximum deformation at various sections of the pump was determined from TAP printout. APSA computer model utilized the TAP temperature field for thermal stress analysis and the deformation analysis.

The steady-state condition (operating condition) which considered the maximum combination of stresses was documented in Reference 5. The stress intensities of various sections were utilized in the calculation of strain fatigue evaluation.

3.3 TRANSIENT DATA

Temperature distributions in the pump inducer/impeller regions were determined as a function of time for the transients.



Transients, time-history thermal analysis was performed and documented in Reference 7. The calculated temperature results were stored on tapes that were used as input for the deformation and stress analysis. The points for which temperatures were calculated and stored are exhibited in Figure 3.

The capacitance-weighted average temperature of various locations in the inducer/impeller region were determined as a function of time and transient. The differences between these temperatures were plotted, as exhibited in Appendix B.

The capacitance-weighted average temperature plots were examined to determine the worst time slice for various interfaces. There were six transients considered (Reference 7), and two worst time slices for each transient were utilized in determining the deflection and stress. The clearance change at various interfaces utilized the transient time slice and were documented in Appendix B. Table 3 shows the worst stress intensities of the pump element for each transient.

3.4 STRUCTURAL CRITERIA

The structural criteria employed in evaluating the pump inducer/impeller is described below.

All components were evaluated using elastic analysis methods as provided for in the pump specification (Reference 6, Paragraph 3.2.4). The analysis criteria are as presented in the RDT Standard F9-4(REF. 1) "Construction of Nuclear System Components at Elevated Temperature."

A summary of the method used in evaluating the strain fatigue limits is outlined below:



Structural Analysis Method Outline

Accumulated Strain Analysis (Ref.1)

Bree Complete Relaxation Method. Deformation and strain limits for structural integrity are considered to have been satisfied and a detailed inelastic ratcheting analysis need not be performed if the following four conditions are satisfied:

1. The approximate inelastic strain averaged through the thickness, ϵ_{avg} , is less than the limit of T-1310 of RDT F 9-4, with:

$$\epsilon_{avg} = \epsilon_c + \epsilon_r ,$$

where: ϵ_c = cumulative creep strain based on the primary stress $(P_L + P_b/K_t)^*$ and the appropriate isochronous stress-strain curves,

ϵ_r = cumulative ratchet strain based on Bree's complete relaxation analysis.

The values of ϵ_r are given by:

$$\epsilon_r = \sum_i N_i (\Delta\epsilon_r)_i ,$$

where: N_i = number of type i cycles,

$(\Delta\epsilon_r)_i$ = ratchet strain per cycle for type i cycles from Bree's complete relaxation equations.



$$(\Delta \epsilon_r)_i = \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} ,$$

in region S_1 of Fig. 4

$$(\Delta \epsilon_r)_i = \frac{S_m}{E} \left\{ 1 - x'' + 2y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} ,$$

in region R_1 of Fig. 4

$$(\Delta \epsilon_r)_i = \frac{S_m}{E} [x''(y'' - 1)] ,$$

in regions S_2 and P of Fig. 4 and:

$$(\Delta \epsilon_r)_i = \frac{S_m}{E} [x''(2y'' - 1) - 1] ,$$

in region R_2 of Fig. 4 In the above:

$$x'' = \left(P_L + \frac{P_b}{K_t} \right)_{\max} / S_m$$

and:

$$y'' = (Q_R)_{\max} / S_m ,$$



Creep-Fatigue Damage Analysis (SIMPLIFIED METHOD)

Assume $\epsilon_{eff} = \epsilon_{eff\ range} = \epsilon_t$

Assume $\epsilon_{eff} = \frac{\sigma_{eff}}{E}$

- 1) Pick σ_{eff} and E for the relevant element in the APSA printout (namely, the element at the critical surface of the selected section), for every transient.
- 2) Using the "Design ϵ_t vs No. of Allowable Cycles" plot, Figure T1430 (CODE CASE 1592) , find N_d for every transient.
- 3) Determine the number of occurrences for each transient
- 4) Total fatigue damage fraction = $\sum \frac{n}{N_d}$.
- 5) Creep Damage Analysis: Creep Damage Fraction - Simplified Analysis Method for the Cycle Selection



Determine $[(P_L + P_B + Q_{max})]$

If $S_y \geq [P_L + P_B + Q_{max}]$ then $S_K = [P_L + P_B + Q_{max}]$

If $S_y \leq [P_L + P_B + Q_{max}]$ then

$$S_K = \underline{\text{lesser of } 1.25 \times S_y}$$

In stress rupture curve, find T_d using $\frac{S_K}{0.9}$.

$$6) \sum \frac{n}{N_d} + \sum \frac{t}{T_d} \leq 0.6$$




FIG 1 SCHEMATIC OF INDUCER-IMPELLER ASS'Y




TABLE 1
CRITICAL CLEARANCE CHANGES
(mils)

Location*	Design Clearance	Transient					
		E-202 100 sec	E-203 100 sec	E-204 100 sec	E-207 275 sec	E-208 115 sec	E-210 50 sec
A	13	+2.4	-1.7	+3.1	+4.6	+3.7	+2.2
B	13	+1.9	-1.3	+2.6	+3.5	+2.8	+2.4
C	50	+6.7	-7.2	+9.2	+11.8	+10.6	+6.6
D	50	+0.9	+5.2	-0.7	-1.5	-0.9	+2.6
E	50	+2.0	+2.9	-3.3	-2.9	-3.7	-3.0
F	50	+8.7	-6.1	+11.6	+13.0	+13.1	+10.5

Note: The values listed under the transient column are changes in the original clearance at isothermal temperature conditions.

For example, at Location A, the original clearance (13 mils) is increased by 0.0024 in. during Event E-202 and decreased by 0.0017 in. during E-203.

*See Figures 1 and 2.



ROTATING ASSEMBLY

STATIC ASSEMBLY

FIG. 2 FINITE ELEMENT MODEL




FIG. 3 TYPICAL TEMPERATURE FIELD




Fig. 4 Ratchet Limits

COMPONENT (ELEMENT)	TEST TRANSIENT						STRAIN SOURCE	Design Margin
	E-202	E-203	E-204	E-207	E-208	E-210		
INDUCER HUB (531)	0.00073	0.00056	0.00380	0.00110	0.00450	0.00380	Q: Per cycle	$D.M. = \frac{1\%}{.034} - 1$ >10
	0.02	0.02	0.02	0.02	0.02	0.02	P _m	
	ACCUMULATED STRAIN						0.034 %	
INDUCER BLADE (666)	0.00108	0.01042	0.01903	0.01100	0.02100	0.01790	Q	7.33
	0.04	0.04	0.04	0.04	0.04	0.04	P _m	
	ACCUMULATED STRAIN						0.12 %	
IMPELLER (648)	0.00977	0.00200	0.00990	0.00840	0.01230	0.00980	Q	9.86
	0.04	0.04	0.04	0.04	0.04	0.04	P _m	
	ACCUMULATED STRAIN						0.092 %	
SHAFT (412)	0.01020	0.00960	0.02100	0.04540	0.02800	0.01100	Q	3.44
	0.1	0.1	0.1	0.1	0.1	0.1	P _m	
	ACCUMULATED STRAIN						0.225 %	


TABLE 2 COMPONENT STRAIN (Allowable strain 1%)

PREPARED BY:	
CHECKED BY:	
DATE:	
MODEL NO.:	
REPORT NO.:	21



COMPONENT (ELEMENT)	TEST TRANSIENT					
	E-202	E-203	E-204	E-207	E-208	E-210
	100 hcc	100 hcc	100 hcc	275 hcc	115 hcc	50 hcc
INDUCER HUB (531)	15400	15800	20000	16000	20600	19000
INDUCER BLADE (666)	13000	22200	27600	22200	28000	25600
IMPELLER (648)	21200	14000	21000	19800	22000	20000
SHAFT (412)	18800	18600	25000	33400	28160	18400

TABLE 3 THERMAL STRESS (Q) psi

PREPARED BY:	
CHECKED BY:	
DATE:	
 Rockwell International Energy Systems Group	
MODEL NO.	



4.0 REFERENCES

1. Guidelines and Procedures for Design of Nuclear System Components at Elevated Temperature, RDT F 9- 4
2. Rules for Class 1 Components in Elevated Temperature Service, ASME Boiler and Pressure Vessel Code, Code Case N-47-12 (1592)
3. Intermediate Size Inducer Pump (ISIP) Design Layout Drawing N266R000015, Atomics International, Rockwell International
4. E. M. Mouradian, A. A. Loffredo, and K. H. Yun, "Verification of Thermal Model for ISIP (Intermediate-Size Inducer Pump)," N266TI000-007, Atomics International, Rockwell International (March 7, 1979)
5. M. Sasaki, "Steady-State Structural Analysis (Pump Internal)," N266SR00001, Rocketdyne Division, Rockwell International (August 7, 1978)
6. Design Specification, "Pump Sodium, Inducer Intermediate (ISIP) (Impeller/Inducer/Diffuser Retrofit)," N266ST310001
7. E. M. Mouradian, A. A. Loffredo, and K. H. Yun, "Transient Thermal Analysis of ISIP (Intermediate-Size Inducer Pump)," N266TI000-008, Atomics International, Rockwell International (April 30, 1979)
8. T. J. Boardman, "Intermediate-Size Inducer Pump Technical Requirements," N266TI000001, Atomics International, Rockwell International (January 20, 1978)
9. J. O. Pfouts, "Sodium Testing of Intermediate-Size Inducer Pump in SPTF at ETEC," N266RFT000001, Atomics International, Rockwell International (April 24, 1979, Revision C)



Rockwell International

Energy Systems Group

NO . N266SR000-002

PAGE . 23.1

10. Operating and Maintenance Manual Addendum to Westinghouse OMM-051-00-005 for Intermediate-Size Inducer Pump, Model 266, N2660MM000001, Atomics International, Rockwell International (November 20, 1978)

APPENDIX A
STRUCTURAL ANALYSIS

- a. Strain Limit Evaluation
- b. Creep-Fatigue Damage Evaluation




STRUCTURAL ANALYSIS

The Bree Complete Relaxation Method of RDT Standard (Reference 1) was used to determine the creep strain limit for pump components. The primary stress ($P_b + P_j$) has utilized the stress intensity value from the stress report by Rocketdyne on the steady-state stress analysis (N266SR000001, Reference 5). The thermal transients stress (Q) were obtained from the time-history iteration of transients. Two worst-time slices were selected for each transient. The procedure was described in Section 3 of this report.

Table A-1 and Table A-2 summarized the stresses and strains, respectively, for different parts of inducer-impeller assembly for each transient.

The total creep-fatigue damage fraction was analyzed based on the method described in Section 3 of this report. The calculation showed that the creep-fatigue damage fraction of 0.026 which was smaller than 0.6.


PREPARED BY: TK CHENG	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		25
DATE:	ISIP	REPORT NO.
		MODEL NO.

stress Intensities (steady state)

Component	Stress	D.M.
@ inducer hub	$P_m = 2.97 \text{ Ksi}$	1.63
@ Inducer Blade	$P_m = 5.6 \text{ Ksi}$	0.38
@ Impeller	$P_m = 5.9 \text{ Ksi}$	0.31
@ shaft	$P_m = 7.48 \text{ Ksi}$	0.03

* stress intensity are from N266SR000001 (ref. 5)

- 1) See page 8
- 2) stress intensities base on 1050°F
- 3) Actual T = 950°F
- 4) $S_0 = 14,300 \text{ psi}$ (used 7,730 psi in this Analysis)

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		26
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

@ Inducer Hub

$$P_b + P_L / 0.9 = 2.9 \text{ KSI}$$

$$\epsilon_c = 0.02 \%$$

(Fig. T-1B00-A.4
Code Case 1592)

@ Inducer Blade

$$P_b + P_L / 0.9 = 5.6 \text{ KSI}$$

$$\epsilon_c = 0.04 \%$$

@ Impeller

$$P_b + P_L / 0.9 = 5.9 \text{ KSI}$$

$$\epsilon_c = 0.04 \%$$


@ shaft

$$P_b + P_L / 0.9 = 7.5 \text{ KSI}$$

$$\epsilon_c = 0.1 \%$$

COMPONENT (ELEMENT)	TEST TRANSIENT						STRESS SOURCE (KSI)
	E-202	E-203	E-204	E-207	E-208	E-210	
	100 bec	100 bec	100 bec	275 bec	115 bec	50 bec	
INDUCER HUB (531)	2.93	2.93	2.93 ksi	2.93	2.93	2.93	P _m
	15.4	15.8	20.0	16.0	20.6	19.0	Q
	18.33	18.73	22.93	18.93	23.53	21.93	P _m + Q
INDUCER BLADE (666)	5.6	5.6	5.6	5.6	5.6	5.6	P _m
	13.0	22.2	27.6	22.2	28.0	25.6	Q
	18.6	27.8	33.2	27.8	33.6	31.2	P _m + Q
IMPELLER (648)	5.9	5.9	5.9	5.9	5.9	5.9	P _m
	21.2	14.0	21.0	19.8	22.0	20.0	Q
	27.1	19.9	26.9	25.7	27.9	25.9	P _m + Q
SHAFT (412)	7.5	7.5	7.5	7.5	7.5	7.5	P _m
	18.8	18.6	25.0	33.4	28.2	18.4	Q
	26.3	26.1	32.5	40.9	35.7	25.9	P _m + Q

TABLE A-1

DATE:		PREPARED BY:		MODEL NO.	
		CHECKED BY:	Rockwell International Energy Systems Group	Page 395	N266ER000-001
		M.T.A.		27	N266SR000002

COMPONENT (ELEMENT)	TEST TRANSIENT						STRAIN SOURCE
	E-202	E-203	E-204	E-207	E-208	E-210	
	%	%	%	%	%	%	
INDUCER HUB (531)	0.00073	0.00092	0.00380	0.00110	0.00450	0.00380	Q (per cycle)
	0.02000	0.02000	0.02000	0.02000	0.02000	0.02000	P _m
	0.02073	0.02092	0.02380	0.02110	0.02450	0.02380	Total
INDUCER BLADE (666)	0.00108	0.01042	0.01903	0.01100	0.02100	0.01790	Q (per cycle)
	0.04000	0.04000	0.04000	0.04000	0.04000	0.04000	P _m
	0.04108	0.05042	0.05903	0.05100	0.06100	0.05790	Total
IMPELLER (648)	0.00977	0.00200	0.00990	0.00840	0.01230	0.00980	Q (per cycle)
	0.04000	0.04000	0.04000	0.04000	0.04000	0.04000	P _m
	0.04977	0.04200	0.04990	0.04840	0.05230	0.04980	Total
SHAFT (412)	0.01020	0.00960	0.02100	0.04540	0.02800	0.01100	Q (per cycle)
	0.10000	0.10000	0.10000	0.10000	0.10000	0.10000	P _m
	0.11020	0.10960	0.12100	0.14540	0.12800	0.11100	Total

TABLE A-2

DATE:

CHECKED BY: W.D.F.


PREPARED BY:

ISIP

Rockwell International
Energy Systems Group

MODEL NO.

N266SR000002
28N266ER000-001
Page 396

PREPARED BY.	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: K.E.F.		29
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-202 @ 100 Sec.
Element 531 @ Inducer Hub (Fig. B-6)

$$Q = 15.4 \text{ Ksi}$$

$$P_m = 2.9 \text{ Ksi}$$

Temperature for E-202 $750^\circ\text{F} \rightarrow 600^\circ\text{F}$

$$\left. \begin{array}{l} s_y = 17.8 \text{ Ksi @ } 750^\circ\text{F} \\ s_y = 18.2 \text{ Ksi @ } 600^\circ\text{F} \end{array} \right\} s_{y \text{ mean}} = 17.8 \text{ Ksi}$$

$$s_m = 15.1 \text{ Ksi @ } 675^\circ\text{F (Mean Temp.)}$$


(Table I-14.3A Code Case 1592)

$$E = 25.0 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{array}{l} x'' = 2.9 / 15.1 = 0.19 \\ y'' = 15.4 / 15.1 = 1.02 \end{array} \right\} \text{Region } s_1$$

$$\begin{aligned} \Delta \epsilon_r &= \frac{s_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1-x''}{y''} \right)^{1/2} \right] \right\} \\ &= \frac{15100}{25 \times 10^6} \left\{ 1 - 0.19 + 1.02 \left[1 - 2 \left(\frac{1-0.19}{1.02} \right)^{1/2} \right] \right\} \\ &= 0.00073 \% \text{ per cycle} \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: WEF		30
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-202 @ 100 Sec.

Element 666 @ Inducer Blade (Fig. B-10)

$$Q = 13.0 \text{ Ksi}$$

$$P_m = 5.6 \text{ Ksi}$$

Temperature for E-202 $750^\circ\text{F} \rightarrow 600^\circ\text{F}$

$$\begin{aligned} S_y &= 17.3 \text{ Ksi @ } 750^\circ\text{F} \\ S_y &= 18.2 \text{ Ksi @ } 600^\circ\text{F} \end{aligned} \left. \vphantom{\begin{aligned} S_y &= 17.3 \text{ Ksi @ } 750^\circ\text{F} \\ S_y &= 18.2 \text{ Ksi @ } 600^\circ\text{F} \end{aligned}} \right\} S_{y_{\text{mean}}} = 17.8 \text{ Ksi}$$

$$S_m = 15.1 \text{ Ksi @ } 675^\circ\text{F (mean temp.)}$$

(Table I-14.3A code case 1592)

$$E = 25.0 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{aligned} x'' &= 5.6 / 15.1 = 0.37 \\ Y'' &= 13.0 / 15.1 = 0.86 \end{aligned} \right\} \text{Region } S_1$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} \\ &= \frac{15100}{25 \times 10^6} \left\{ 1 - 0.37 + 0.86 \left[1 - 2 \left(\frac{1 - 0.37}{0.86} \right)^{1/2} \right] \right\} \\ &= 0.00108 \% \end{aligned}$$

Strain Limits Evaluation

Test Transient E-202 @ 100 Sec.

Element 64B @ Impaler (FIG. B-10)

$Q = 21.2 \text{ Ksi}$

$P_m = 5.9 \text{ Ksi}$

Temperature for E-202 $750^\circ\text{F} \rightarrow 600^\circ\text{F}$.

$\sigma_y = 17.8 \text{ Ksi @ } 750^\circ\text{F}$
 $\sigma_y = 18.2 \text{ Ksi @ } 600^\circ\text{F}$

$\sigma_{y, \text{mean}} = 17.8 \text{ Ksi}$

$\sigma_{sm} = 15.1 \text{ Ksi @ } 675^\circ\text{F (mean temp.)}$
 (Table I-14.3A code case 1592)

$E = 25.0 \times 10^6 \text{ psi}$


1. Bree Relaxation Method (RDT F 9-5T)

$x'' = 5.9 / 15.1 = 0.39$
 $Y' = 21.2 / 15.1 = 1.4$

Region S1

ratchet strain per cycle ($\Delta\epsilon_r$)

$$\begin{aligned}
 (\Delta\epsilon_r) &= \frac{\sigma_{sm}}{E} \left\{ 1 - x'' + Y' \left[1 - 2 \left(\frac{1-x''}{Y'} \right)^{1/2} \right] \right\} \\
 &= \frac{15100}{25 \times 10^6} \left\{ 1 - 0.39 + 1.4 \left[1 - 2 \left(\frac{1-0.39}{1.4} \right)^{1/2} \right] \right\} \\
 &= 0.00977 \%
 \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 32
CHECKED BY: <i>1. P. L.</i>		N266ER000-001 Page 400
DATE:		ISIP

Strain Limits Evaluation

Test Transient E-202 @ 100 sec.
Element 412 @ shaft (FIG. B-6)

$$Q = 18.8 \text{ Ksi}$$

$$P_m = 7.5 \text{ Ksi}$$

Temperature for E-202 $750^\circ\text{F} \rightarrow 600^\circ\text{F}$

$$\left. \begin{aligned} S_y &= 17.3 \text{ Ksi @ } 750^\circ\text{F} \\ S_y &= 18.2 \text{ Ksi @ } 600^\circ\text{F} \end{aligned} \right\} S_{y, \text{mean}} = 17.8 \text{ Ksi}$$

$$S_m = 15.1 \text{ Ksi @ } 675^\circ\text{F (Mean temp.)}$$

(Table I-14.3A code case 1592)


$$E = 25.0 \times 10^6 \text{ psi}$$

1. Brze Relaxation Method

$$\left. \begin{aligned} x'' &= 7.5 / 15.1 = 0.5 \\ Y'' &= 18.8 / 15.1 = 1.25 \end{aligned} \right\} \text{Region } S_1$$

ratchet strain per cycle ($\Delta\epsilon_r$)

$$\begin{aligned} (\Delta\epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + Y'' \left[1 - 2 \left(\frac{1 - x''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{15100}{25 \times 10^6} \left\{ 1 - 0.5 + 1.25 \left[1 - 2 \left(\frac{1 - 0.5}{1.25} \right)^{1/2} \right] \right\} \\ &= 0.0102 \% \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 33
CHECKED BY: <i>W. E. P.</i>		N266ER000-001 Page 401
DATE:	ISIP	

Strain Limits Evaluation

Test Transient E-203 @ 100 sec

Element 531 @ Inducer Hub

$Q = 15.8 \text{ Ksi}$

$P_m = 2.9 \text{ Ksi}$

Temperature for E-203 $500^\circ \text{F} \rightarrow 650^\circ \text{F}$

$S_y = 19.4 \text{ Ksi @ } 500^\circ \text{F}$
 $S_y = 18.0 \text{ Ksi @ } 650^\circ \text{F}$

$S_{y, \text{mean}} = 18.7 \text{ Ksi}$

$S_m = 15.1 \text{ Ksi @ } 575^\circ \text{F (Mean Temp)}$

(Table I-14.3A Code Case 1592)

$E = 25.4 \times 10^6 \text{ psi}$


1. Bree Relaxation Method

$x'' = 2.9/15.1 = 0.19$
 $y'' = 15.8/15.1 = 1.05$

} Region 51

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned}
 (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} \\
 &= \frac{15100}{25.4 \times 10^6} \left\{ 1 - 0.19 + 1.05 \left[1 - 2 \left(\frac{1 - 0.19}{1.05} \right)^{1/2} \right] \right\} \\
 &= 0.00092 \%
 \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 34
CHECKED BY: <u>W.P.F.</u>		REPORT NO.
DATE:	<u>ISIP</u>	MODEL NO.

Strain Limits Evaluation

Test Transient E-203 @ 100 sec
Element 666 @ Inducer Blade

$$Q = 22.2 \text{ Ksi}$$

$$P_m = 5.6 \text{ Ksi}$$

Temperature for E-203 $500^\circ \text{F} \rightarrow 650^\circ \text{F}$

$$\begin{array}{l}
 S_y = 19.4 \text{ Ksi @ } 500^\circ \text{F} \\
 S_y = 18.0 \text{ Ksi @ } 650^\circ \text{F}
 \end{array}
 \left. \vphantom{\begin{array}{l} S_y = 19.4 \\ S_y = 18.0 \end{array}} \right\} S_{y_{\text{mean}}} = 18.7 \text{ Ksi}$$

$$S_m = 15.1 \text{ Ksi @ } 575^\circ \text{F (Mean Temp)}$$

(Table I-14.3A Code Case 1592)


$$E = 25.4 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{array}{l}
 X'' = 5.6 / 15.1 = 0.37 \\
 Y'' = 22.2 / 15.1 = 1.47
 \end{array} \right\} S_1 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned}
 (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - X'' + Y'' \left[1 - 2 \left(\frac{1 - X''}{Y''} \right)^{1/2} \right] \right\} \\
 &= \frac{15100}{25.4 \times 10^6} \left\{ 1 - 0.37 + 1.47 \left[1 - 2 \left(\frac{1 - 0.37}{1.47} \right)^{1/2} \right] \right\} \\
 &= 0.01042 \%
 \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 35
CHECKED BY: W.F.A.		REPORT NO.
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-203 @ 100 sec

Element 648 @ Impeller

$$Q = 14.0 \text{ Ksi}$$

$$P_m = 5.9 \text{ Ksi}$$

Temperature for E-203 $500^\circ \text{F} \rightarrow 650^\circ \text{F}$

$$\begin{aligned} S_y &= 19.4 \text{ Ksi @ } 500^\circ \text{F} \\ S_y &= 18.0 \text{ Ksi @ } 650^\circ \text{F} \end{aligned} \quad \left. \vphantom{\begin{aligned} S_y &= 19.4 \text{ Ksi @ } 500^\circ \text{F} \\ S_y &= 18.0 \text{ Ksi @ } 650^\circ \text{F} \end{aligned}} \right\} S_{y, \text{mean}} = 18.7 \text{ Ksi}$$

$$S_m = 15.1 \text{ Ksi @ } 575^\circ \text{F (Mean Temp)}$$

(Table I-14.3A Code Case 1592)


$$E = 25.4 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\begin{aligned} X'' &= 5.9 / 15.1 = 0.39 \\ Y'' &= 14.0 / 15.1 = 0.93 \end{aligned} \quad \left. \vphantom{\begin{aligned} X'' &= 5.9 / 15.1 = 0.39 \\ Y'' &= 14.0 / 15.1 = 0.93 \end{aligned}} \right\} S_1 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - X'' + Y'' \left[1 - 2 \left(\frac{1 - X''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{15100}{25.4 \times 10^6} \left\{ 1 - 0.39 + 0.93 \left[1 - 2 \left(\frac{1 - 0.39}{0.93} \right)^{1/2} \right] \right\} \\ &= 0.002 \% \end{aligned}$$

PREPARED BY:	 Page 404 Rockwell International Energy Systems Group	N266SR000002 of 36
CHECKED BY: LEE		REPORT NO.
DATE:	IGIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-203 @ 100 sec

Element 412 @ shaft

$$Q = 18.6 \text{ Ksi}$$

$$P_m = 7.5 \text{ Ksi}$$

Temperature for E-203 $500^\circ \text{F} \rightarrow 650^\circ \text{F}$

$$\begin{aligned} S_y &= 19.4 \text{ Ksi @ } 500^\circ \text{F} \\ S_y &= 18.0 \text{ Ksi @ } 650^\circ \text{F} \end{aligned} \quad \left. \vphantom{\begin{aligned} S_y &= 19.4 \text{ Ksi @ } 500^\circ \text{F} \\ S_y &= 18.0 \text{ Ksi @ } 650^\circ \text{F} \end{aligned}} \right\} S_{y_{\text{mean}}} = 18.7 \text{ Ksi}$$

$$S_m = 15.1 \text{ Ksi @ } 575^\circ \text{F (Mean Temp)}$$

(Table I-14.3A Code Case 1592)


$$E = 25.4 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\begin{aligned} x'' &= 7.5 / 15.1 = 0.5 \\ \gamma'' &= 18.6 / 15.1 = 1.23 \end{aligned} \quad \left. \vphantom{\begin{aligned} x'' &= 7.5 / 15.1 = 0.5 \\ \gamma'' &= 18.6 / 15.1 = 1.23 \end{aligned}} \right\} S_1 \text{ Region}$$

hatched strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + \gamma'' \left[1 - 2 \left(\frac{1 - x''}{\gamma''} \right)^{1/2} \right] \right\} \\ &= \frac{15100}{25.4 \times 10^6} \left\{ 1 - 0.5 + 1.23 \left[1 - 2 \left(\frac{1 - 0.5}{1.23} \right)^{1/2} \right] \right\} \\ &= 0.0096 \text{ in/in} \end{aligned}$$

PREPARED BY:	 Page 405 Rockwell International Energy Systems Group	N266SR000002 37
CHECKED BY: I.S.F.		REPORT NO.
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-204 @ 100 sec.

Element 531 @ Inducer Hub

$$Q = 20.0 \text{ Ksi}$$

$$P_m = 2.9 \text{ Ksi}$$

Temperature for E-204 $850^\circ\text{F} \rightarrow 650^\circ\text{F}$

$$S_y = 16.5 \text{ Ksi @ } 850^\circ\text{F}$$

$$S_y = 17.9 \text{ Ksi @ } 650^\circ\text{F}$$

$$S_{y \text{ mean}} = 17.2 \text{ Ksi}$$

$$S_m = 15.0 \text{ Ksi @ } 750^\circ\text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 24.5 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$X'' = 2.9 / 15.0 = 0.19$$

$$Y'' = 20.0 / 15.0 = 1.33$$


} S_2 Region

ratchet strain per cycle ($\Delta \epsilon_r$)

$$(\Delta \epsilon_r) = \frac{S_m}{E} [X''(Y''-1)]$$

$$= \frac{15000}{24.5 \times 10^6} [0.19(1.33-1)]$$

$$= 0.0038 \%$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: <u>W.F.A.</u>		38
DATE:	<u>ISIP</u>	REPORT NO.
		MODEL NO.

Strain Limits Evaluation

Test Transient E-204 @ 100 sec.

Element 666 @ Inducer Blade

$$Q = 27.6 \text{ Ksi}$$

$$P_m = 5.6 \text{ Ksi}$$

Temperature for E-204 850°F → 650°F

$$S_y = 16.5 \text{ Ksi @ } 850^\circ\text{F}$$

$$S_y = 17.9 \text{ Ksi @ } 650^\circ\text{F}$$

$$S_y = 17.2 \text{ Ksi}$$

mean

$$S_m = 15.0 \text{ Ksi @ } 750^\circ\text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 24.5 \times 10^6 \text{ psi}$$

1. Brze Relaxation Method

$$X'' = 5.6/15.0 = 0.37$$

$$Y'' = 27.6/15.0 = 1.84$$


} S_m Region

ratchet strain per cycle

$$(\Delta \epsilon_r) = \frac{S_m}{E} [X'' (Y'' - 1)]$$

$$= \frac{15000}{24.5 \times 10^6} [0.37 (1.84 - 1)]$$

$$= 0.01903 \%$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 39
CHECKED BY: <u>W.F.A.</u>		REPORT NO.
DATE:	<u>ISIP</u>	MODEL NO.

Strain Limits Evaluation

Test Transient E-204 @ 100 sec.

Element 648 @ Impeller

$$Q = 21.0 \text{ Ksi}$$

$$P_m = 5.9 \text{ Ksi}$$

Temperature for E-204 850°F → 650°F

$$\begin{array}{l} S_y = 16.5 \text{ Ksi @ } 850^\circ\text{F} \\ S_y = 17.9 \text{ Ksi @ } 650^\circ\text{F} \end{array} \quad \left. \vphantom{\begin{array}{l} S_y = 16.5 \text{ Ksi @ } 850^\circ\text{F} \\ S_y = 17.9 \text{ Ksi @ } 650^\circ\text{F} \end{array}} \right\} S_{y \text{ mean}} = 17.2 \text{ Ksi}$$

$$S_m = 15.0 \text{ Ksi @ } 750^\circ\text{F (mean temp.)}$$

(Table I-14.2A Code Case 1592)

$$E = 24.5 \times 10^6 \text{ psi}$$

1. Brze Relaxation Method

$$\left. \begin{array}{l} X'' = 5.9 / 15.0 = 0.39 \\ Y'' = 21.0 / 15.0 = 1.40 \end{array} \right\} S_1 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - X'' + Y'' \left[1 - 2 \left(\frac{1 - X''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{15000}{24.5 \times 10^6} \left\{ 1 - 0.39 + 1.4 \left[1 - 2 \left(\frac{1 - 0.39}{1.40} \right)^{1/2} \right] \right\} \\ &= 0.0099 \% \end{aligned}$$



Rockwell International
Energy Systems Group

N266SR000002
40

PREPARED BY:

CHECKED BY: W.E.F.

DATE:

ISIP

REPORT NO.

MODEL NO.

Strain Limits Evaluation

Test Transient E-204 @ 100 sec.

Element 412 @ shaft

$$Q = 25.0 \text{ Ksi}$$

$$P_m = 7.5 \text{ Ksi}$$

Temperature for E-204 850°F → 650°F

$$S_y = 16.5 \text{ Ksi @ } 850^\circ\text{F}$$

$$S_y = 17.9 \text{ Ksi @ } 650^\circ\text{F}$$

$$S_y = 17.2 \text{ Ksi}_{\text{mean}}$$

$$S_m = 15.0 \text{ Ksi @ } 750^\circ\text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 24.5 \times 10^6 \text{ psi}$$

1. Brice Relaxation Method

$$X'' = 7.5 / 15.0 = 0.5$$

$$Y'' = 25.0 / 15.0 = 1.67$$

} S₁ Region

ratchet strain per cycle ($\Delta \epsilon_r$)

$$(\Delta \epsilon_r) = \frac{S_m}{E} \left\{ 1 - X'' + Y'' \left[1 - 2 \left(\frac{1 - X''}{Y''} \right)^{1/2} \right] \right\}$$

$$= \frac{15000}{24.5 \times 10^6} \left\{ 1 - 0.5 + 1.67 \left[1 - 2 \left(\frac{1 - 0.5}{1.67} \right)^{1/2} \right] \right\}$$

$$= 0.0210 \text{ } \phi$$



Rockwell International
Energy Systems Group

N266SR000002

41

PREPARED BY:

CHECKED BY: K. E. F.

REPORT NO.

DATE:

ISIP

MODEL NO.

Strain Limits Evaluation

Test Transient E-207 @ 275 Sec.

Element 531 @ Inducer Hub

$$Q = 16.0 \text{ Ksi}$$

$$P_m = 2.9 \text{ Ksi}$$

Temperature for E-207 $950^\circ\text{F} \rightarrow 620^\circ\text{F}$

$$\begin{aligned} s_y &= 15.0 \text{ Ksi @ } 950^\circ\text{F} \\ s_y &= 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{aligned} \left. \vphantom{\begin{aligned} s_y &= 15.0 \text{ Ksi @ } 950^\circ\text{F} \\ s_y &= 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{aligned}} \right\} s_{y, \text{mean}} = 17.0 \text{ Ksi}$$

$$s_m = 15.0 \text{ Ksi @ } 785^\circ\text{F (Mean Temp.)}$$

(Table I-14.3A code case 1592)


$$E = 24.1 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\begin{aligned} x'' &= 2.9 / 15.0 = 0.19 \\ Y'' &= 16.0 / 15.0 = 1.07 \end{aligned} \left. \vphantom{\begin{aligned} x'' &= 2.9 / 15.0 = 0.19 \\ Y'' &= 16.0 / 15.0 = 1.07 \end{aligned}} \right\} s_1 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{s_m}{E} \left\{ 1 - x'' + Y'' \left[1 - 2 \left(\frac{1 - x''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{15000}{24.1 \times 10^6} \left\{ 1 - 0.19 + 1.07 \left[1 - 2 \left(\frac{1 - 0.19}{1.07} \right)^{1/2} \right] \right\} \\ &= 0.0011 \% \end{aligned}$$

PREPARED BY:	 Page 410 Rockwell International Energy Systems Group	N266SR000002 42
CHECKED BY:		REPORT NO.
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-207 @ 275 sec.

Element 666 @ Inducer Blade

$$Q = 22.2 \text{ Ksi}$$

$$P_m = 5.6 \text{ Ksi}$$

Temperature for E-207 $950^\circ\text{F} \rightarrow 620^\circ\text{F}$.

$$\left. \begin{array}{l} S_y = 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y = 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{array} \right\} S_{y, \text{mean}} = 17.0 \text{ Ksi}$$

$$S_m = 15.0 \text{ Ksi @ } 795^\circ\text{F} \text{ (mean temp.)}$$

(Table I-14.3A code case 1592)


$$E = 24.1 \times 10^6 \text{ psi}$$

1. Brze Relaxation Method

$$\left. \begin{array}{l} X'' = 5.6 / 15.0 = 0.37 \\ Y'' = 22.2 / 15.0 = 1.48 \end{array} \right\} S_1 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - X'' + Y'' \left[1 - 2 \left(\frac{1 - X''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{15000}{24.1 \times 10^6} \left\{ 1 - 0.37 + 1.48 \left[1 - 2 \left(\frac{1 - 0.37}{1.48} \right)^{1/2} \right] \right\} \\ &= 0.011 \% \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 43
CHECKED BY: W.F.F.		REPORT NO.
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-207 @ 275 sec.

Element 648 @ Impeller

$$Q = 19.8 \text{ Ksi}$$

$$P_m = 5.9 \text{ Ksi}$$

Temperature for E-207 $950^\circ\text{F} \rightarrow 620^\circ\text{F}$

$$\left. \begin{array}{l} S_y = 15.0 \text{ Ksi @ } 950^\circ\text{F} \\ S_y = 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{array} \right\} S_{y \text{ mean}} = 17.0 \text{ Ksi}$$

$$S_m = 15.0 \text{ Ksi @ } 785^\circ\text{F (Mean temp.)}$$

(Table I-14.3A Code Case 1592)


$$E = 24.1 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{array}{l} x'' = 5.9/15.0 = 0.39 \\ y'' = 19.8/15.0 = 1.32 \end{array} \right\} S_1 \text{ Region}$$

Ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} \\ &= \frac{15000}{24.1 \times 10^6} \left\{ 1 - 0.39 + 1.32 \left[1 - 2 \left(\frac{1 - 0.39}{1.32} \right)^{1/2} \right] \right\} \\ &= 0.0084 \% \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 44
CHECKED BY: VEF.		REPORT NO.
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-207 @ 275 Sec.

Element 412 @ shaft

$$Q = 33.4 \text{ Ksi}$$

$$P_m = 7.5 \text{ Ksi}$$

Temperature for E-207 $950^\circ\text{F} \rightarrow 620^\circ\text{F}$

$$\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{aligned} \left. \vphantom{\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 18.0 \text{ Ksi @ } 620^\circ\text{F} \end{aligned}} \right\} S_{y, \text{mean}} = 17.0 \text{ Ksi}$$

$$S_m = 15.0 \text{ Ksi @ } 785^\circ\text{F (mean temp.)}$$

(Table I-14.3A code case 1592)


$$E = 24.1 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{aligned} x'' &= 7.5 / 15.0 = 0.5 \\ Y'' &= 33.4 / 15.0 = 2.23 \end{aligned} \right\} R_2 \text{ Region}$$

ratchet strain per cycle ($\Delta\epsilon_r$)

$$\begin{aligned} (\Delta\epsilon_r) &= \frac{S_m}{E} [x''(2Y''-1)-1] \\ &= \frac{15000}{24.1 \times 10^6} [0.5(2 \times 2.23 - 1) - 1] \\ &= 0.0454 \% \end{aligned}$$

PREPARED BY:	 Page 413 Rockwell International Energy Systems Group	N266SR000002 45 of
CHECKED BY: <i>V.L.F.E.</i>		REPORT NO.
DATE:	<i>ISIP</i>	MODEL NO.

Strain Limits Evaluation

Test Transient E-20B @ 115 sec.

Element 531 @ Inducer Hub

$$Q = 20.6 \text{ Ksi}$$

$$P_m = 2.9 \text{ Ksi}$$

Temperature for E-20B $950^\circ \text{F} \rightarrow 725^\circ \text{F}$

$$S_y = 15.9 \text{ Ksi @ } 950^\circ \text{F}$$

$$S_y = 17.5 \text{ Ksi @ } 725^\circ \text{F}$$

$$S_y = 16.7 \text{ Ksi}$$

mean

$$S_m = 14.9 \text{ Ksi @ } 838^\circ \text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 23.7 \times 10^6 \text{ psi}$$

1. Brze Relaxation Method


$$\left. \begin{aligned} x'' &= 2.9 / 14.9 = 0.19 \\ y'' &= 20.6 / 14.9 = 1.38 \end{aligned} \right\} S_2 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$(\Delta \epsilon_r) = \frac{S_m}{E} [x''(y''-1)]$$

$$= \frac{14900}{23.7 \times 10^6} [0.19 (1.38-1)]$$

$$= 0.0045 \%$$

PREPARED BY:	 Page 414 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: L.I.E.		46
DATE:	ISIP	MODEL NO.

Strain Limits Evaluation

Test Transient E-20B @ 115 sec.

Element 666 @ Inducer Blade

$$Q = 28.0 \text{ KSI}$$

$$P_m = 5.6 \text{ KSI}$$

Temperature for E-20B $950^\circ\text{F} \rightarrow 725^\circ\text{F}$

$$\begin{aligned} s_y &= 15.9 \text{ KSI @ } 950^\circ\text{F} \\ s_y &= 17.5 \text{ KSI @ } 725^\circ\text{F} \end{aligned} \quad \left. \begin{array}{l} \text{---} \\ \text{---} \end{array} \right\} s_{y \text{ mean}} = 16.7 \text{ KSI}$$

$$s_m = 14.9 \text{ KSI @ } 838^\circ\text{F} \text{ (mean temp.)}$$

(Table I-14.3A Code Case 1592)


$$E = 23.7 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{aligned} x'' &= 5.6/14.9 = 0.38 \\ y'' &= 28.0/14.9 = 1.88 \end{aligned} \right\} s_2 \text{ Region}$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{s_m}{E} [x''(y''-1)] \\ &= \frac{14900}{23.7 \times 10^6} [0.38(1.88-1)] \\ &= 0.021 \% \end{aligned}$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: JEL		47
DATE:	ISIP	REPORT NO.
		MODEL NO.

Strain Limits Evaluation

Test Transient E-20B @ 115 sec.

Element 64B @ Impeller

$$Q = 22.0 \text{ Ksi}$$

$$P_m = 5.9 \text{ Ksi}$$

Temperature for E-20B $950^\circ\text{F} \rightarrow 725^\circ\text{F}$

$$\begin{array}{l}
 s_y = 15.9 \text{ Ksi @ } 950^\circ\text{F} \\
 s_y = 17.5 \text{ Ksi @ } 725^\circ\text{F}
 \end{array}
 \left. \vphantom{\begin{array}{l} s_y = 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ s_y = 17.5 \text{ Ksi @ } 725^\circ\text{F} \end{array}} \right\} s_{y \text{ mean}} = 16.7 \text{ Ksi}$$

$$s_m = 14.9 \text{ Ksi @ } 838^\circ\text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 23.7 \times 10^6 \text{ psi}$$

1. Pree Relaxation Method

$$\begin{array}{l}
 x'' = 5.9/14.9 = 0.4 \\
 Y'' = 22.0/14.9 = 1.48
 \end{array}
 \left. \vphantom{\begin{array}{l} x'' = 5.9/14.9 = 0.4 \\ Y'' = 22.0/14.9 = 1.48 \end{array}} \right\} \text{Region } S_1$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned}
 (\Delta \epsilon_r) &= \frac{s_m}{E} \left\{ 1 - x'' + Y'' \left[1 - 2 \left(\frac{1 - x''}{Y''} \right)^{1/2} \right] \right\} \\
 &= \frac{14900}{23.7 \times 10^6} \left\{ 1 - 0.4 + 1.48 \left[1 - 2 \left(\frac{1 - 0.4}{1.48} \right)^{1/2} \right] \right\} \\
 &= 0.0123 \%
 \end{aligned}$$

PREPARED BY:

Rockwell International
Energy Systems GroupN266SR000002 of
48

CHECKED BY:

W.F.F.

REPORT NO.

DATE:

ISIP

MODEL NO.

Strain Limits Evaluation

Test Transient E-20B @ 115 sec.

Element 412 @ Shaft

$$Q = 28.2 \text{ Ksi}$$

$$P_m = 7.5 \text{ Ksi}$$

Temperature for E-20B $950^\circ \text{F} \rightarrow 725^\circ \text{F}$

$$\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ \text{F} \\ S_y &= 17.5 \text{ Ksi @ } 725^\circ \text{F} \end{aligned} \quad \left. \begin{array}{l} \text{---} \\ \text{---} \end{array} \right\} S_{y \text{ mean}} = 16.7 \text{ Ksi}$$

$$S_m = 14.9 \text{ Ksi @ } 838^\circ \text{F (mean temp.)}$$

(Table I-14.3A Code Case 1592)

$$E = 28.7 \times 10^6 \text{ psi}$$

1. Bree Relaxation Method

$$\left. \begin{aligned} x'' &= 7.5 / 14.9 = 0.5 \\ y'' &= 28.2 / 14.9 = 1.89 \end{aligned} \right\} \text{Region } S_1$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\} \\ &= \frac{14900}{28.7 \times 10^6} \left\{ 1 - 0.5 + 1.89 \left[1 - 2 \left(\frac{1 - 0.5}{1.89} \right)^{1/2} \right] \right\} \\ &= 0.028 \% \end{aligned}$$



PREPARED BY:

CHECKED BY:

REPORT NO.

DATE:

ISIP

MODEL NO.

Strain Limits Evaluation

Test Transient E-210 @ 50 sec

Element 531 @ Inducer Hub

$$Q = 19.0 \text{ Ksi}$$

$$p_m = 2.9 \text{ Ksi}$$

Temperature for E-210 $950^\circ\text{F} \rightarrow 800^\circ\text{F}$

$$\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 16.8 \text{ Ksi @ } 800^\circ\text{F} \end{aligned} \quad \left. \vphantom{\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 16.8 \text{ Ksi @ } 800^\circ\text{F} \end{aligned}} \right\} S_{y, \text{mean}} = 16.3 \text{ Ksi}$$

$$S_m = 14.6 \text{ Ksi @ } 815^\circ\text{F} \text{ (Mean Temp)}$$

(Table I-14.3A Code Case 1592)

$$E = 23.3 \times 10^6$$

1. Bree Relaxation Method

$$\begin{aligned} x'' &= 2.9 / 14.6 = 0.2 \\ y'' &= 19.0 / 14.6 = 1.3 \end{aligned} \quad \left. \vphantom{\begin{aligned} x'' &= 2.9 / 14.6 = 0.2 \\ y'' &= 19.0 / 14.6 = 1.3 \end{aligned}} \right\} \text{Region } S_2$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} [x'' \cdot (y'' - 1)] \\ &= \frac{14600}{23.3 \times 10^6} [0.2 (1.3 - 1)] \\ &= 0.0036 \% \end{aligned}$$



Rockwell International
Energy Systems Group

N266SR000002
50

PREPARED BY:

CHECKED BY:

V.E.E.

REPORT NO.

DATE:

ISIP

MODEL NO.

Strain Limits Evaluation

Test Transient E-210 @ 50 sec

Element 666 @ Inducer Blade

$$Q = 25.6 \text{ Ksi}$$

$$P_m = 5.6 \text{ Ksi}$$

Temperature for E-210 950°F → 800°F

$$S_y = 15.9 \text{ Ksi @ } 950^\circ\text{F}$$

$$S_y = 16.8 \text{ Ksi @ } 800^\circ\text{F}$$

$$S_{y_{\text{mean}}} = 16.3 \text{ Ksi}$$

$$S_m = 14.6 \text{ Ksi @ } 875^\circ\text{F (Mean Temp)}$$

(Table I-14.3A Code Case 1592)

$$E = 29.3 \times 10^6$$

1. Bree Relaxation Method

$$X'' = 5.6 / 14.6 = 0.38$$

$$Y'' = 25.6 / 14.6 = 1.75$$

} Region S_m

ratchet strain per cycle ($\Delta \epsilon_r$)

$$(\Delta \epsilon_r) = \frac{S_m}{E} [X''(Y''-1)]$$

$$= \frac{14600}{29.3 \times 10^6} [0.38(1.75-1)]$$

$$= 0.0179 \%$$



PREPARED BY:

CHECKED BY:

W.I.D.

DATE:

ISIP

REPORT NO.

MODEL NO.

Strain Limits Evaluation

Test Transient E-210 @ 50 sec

Element 648 @ Impeller

$$Q = 20.0 \text{ Ksi}$$

$$P_m = 5.9 \text{ Ksi}$$

Temperature for E-210 $950^\circ\text{F} \rightarrow 800^\circ\text{F}$

$$\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 16.8 \text{ Ksi @ } 800^\circ\text{F} \end{aligned} \quad \left. \vphantom{\begin{aligned} S_y &= 15.9 \text{ Ksi @ } 950^\circ\text{F} \\ S_y &= 16.8 \text{ Ksi @ } 800^\circ\text{F} \end{aligned}} \right\} S_{y, \text{mean}} = 16.3 \text{ Ksi}$$

$$S_m = 14.6 \text{ Ksi @ } 875^\circ\text{F} \text{ (Mean Temp)}$$

(Table I-14.3A Code Case 1592)

$$E = 23.3 \times 10^6$$

1. Bree Relaxation Method

$$\begin{aligned} x'' &= 5.9 / 14.6 = 0.4 \\ Y'' &= 20.0 / 14.6 = 1.37 \end{aligned} \quad \left. \vphantom{\begin{aligned} x'' &= 5.9 / 14.6 = 0.4 \\ Y'' &= 20.0 / 14.6 = 1.37 \end{aligned}} \right\} \text{Region } S_1$$

ratchet strain per cycle ($\Delta \epsilon_r$)

$$\begin{aligned} (\Delta \epsilon_r) &= \frac{S_m}{E} \left\{ 1 - x'' + Y'' \left[1 - 2 \left(\frac{1 - x''}{Y''} \right)^{1/2} \right] \right\} \\ &= \frac{14600}{23.3 \times 10^6} \left\{ 1 - 0.4 + 1.37 \left[1 - 2 \left(\frac{1 - 0.4}{1.37} \right)^{1/2} \right] \right\} \\ &= 0.0098 \% \end{aligned}$$

PREPARED BY:



Rockwell International

Energy Systems Group

CHECKED BY:

W. I. F.

REPORT NO.

DATE:

ISIP

MODEL NO.

Strain Limits Evaluation

Test Transient E-210 @ 50 sec

Element 412 @ shaft

$$Q = 18.4 \text{ Ksi}$$

$$p_m = 7.5 \text{ Ksi}$$

Temperature for E-210 $950^\circ\text{F} \rightarrow 800^\circ\text{F}$

$$S_y = 15.9 \text{ Ksi @ } 950^\circ\text{F} \quad \left. \begin{array}{l} \\ \end{array} \right\} S_{y_{\text{mean}}} = 16.3 \text{ Ksi}$$

$$S_y = 16.8 \text{ Ksi @ } 800^\circ\text{F}$$

$$S_m = 14.6 \text{ Ksi @ } 875^\circ\text{F (Mean Temp)}$$

(Table I-14.3A Code Case 1592)

$$E = 23.3 \times 10^6$$

1. Bree Relaxation Method

$$x'' = 7.5 / 14.6 = 0.51$$


$$y'' = 18.4 / 14.6 = 1.26 \quad \left. \begin{array}{l} \\ \end{array} \right\} \text{Region } S_1$$

Ratchet strain per cycle ($\Delta \epsilon_r$)

$$(\Delta \epsilon_r) = \frac{S_m}{E} \left\{ 1 - x'' + y'' \left[1 - 2 \left(\frac{1 - x''}{y''} \right)^{1/2} \right] \right\}$$

$$= \frac{14600}{23.3 \times 10^6} \left\{ 1 - 0.51 + 1.26 \left[1 - 2 \left(\frac{1 - 0.51}{1.26} \right)^{1/2} \right] \right\}$$

$$= 0.011 \%$$

PREPARED BY:	 Page 421 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY: W. E. A.		53
DATE:	ISIP	REPORT NO.
		MODEL NO.

Creep - Fatigue Damage

Test Transient E-207

Element

$$P_{m+Q} = 40.9 \text{ Ksi} > S_y = 15.9 \text{ Ksi}$$

$$1.25 S_y / 10.9 = 22.05 \text{ Ksi}$$

1. Creep Damage


The allowable duration T_d , from Fig. I-14.6 A
Code Case 1592

$$T_d = 6 \times 10^4 \text{ Hrs.}$$

the cycle duration of transient 100 Hrs. (Assumed)

the creep damage per cycle

$$\frac{t}{T_d} = \frac{100}{6 \times 10^4} = 0.0017$$

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 of
CHECKED BY: W. F. F.		54
DATE:	ISIP	REPORT NO.
		MODEL NO.

Creep-Fatigue Damage

2. Fatigue Damage

Element 412 @ shaft @ Transient E-207

$$\epsilon_t = 40.9 \times 10^3 / 22.9 \times 10^6 = 0.001786$$

$$N_d = 2 \times 10^3 \text{ cycles (Fig. T-1420-1A code case 1592)}$$

The fatigue damage fraction per cycle will be

$$\frac{n}{N_d} = \frac{1}{2 \times 10^3}$$

3. The total creep-fatigue Damage

$$\sum \frac{t}{T_d} + \sum \frac{n}{N_d} \leq 1$$

$$\sum \frac{t}{T_d} + \sum \frac{n}{N_d} = (6 \times 2) \frac{100}{6 \times 10^4} + (6 \times 2) \frac{1}{2 \times 10^3}$$

$$= 0.02 + 0.006$$

$$= 0.026 < 1$$

Table I-14.3A
 S_{mt} - Allowable Stress Intensity Values, 1000 psi
Type 304 SS - 30-YR, 76-UTS (30-YR, 70-UTS)

Temp. °F	1 hr	10 hr	30 hr	10 ² hr	3 X 10 ² hr	10 ³ hr	3 X 10 ³ hr	10 ⁴ hr	3 X 10 ⁴ hr	10 ⁵ hr	3 X 10 ⁵ hr
800	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1
850	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8	14.8
900	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6
950	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.3	14.2	12.2
1000	14.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	13.1	11.1	9.3
1050	13.6	13.6	13.6	13.6	13.6	13.6	13.6	12.2	10.3	8.7	7.3
1100	13.2	13.2	13.2	13.2	13.2	13.2	11.5	9.7	8.2	6.8	5.7
1150	12.9	12.9	12.9	12.9	12.9	11.0	9.3	7.7	6.4	5.3	4.4
1200	12.7	12.7	12.7	12.2	10.6	8.9	7.4	6.1	5.1	4.1	3.4
1250	12.3	12.3	11.9	10.3	8.7	7.2	5.9	4.9	4.0	3.2	2.7
1300	11.9 (11.8)	11.4	10.0	8.5	7.0	5.9	4.8	3.9	3.2	2.5	2.1
1350	10.9 (10.5)	9.7	8.4	7.1	5.9	4.8	3.9	3.1	2.5	2.0	1.6
1400	9.5 (9.0)	8.1	6.9	5.9	4.8	3.9	3.1	2.5	2.0	1.6	1.2
1450	8.2 (7.5)	6.8	5.8	4.6	3.8	3.0	2.4	1.9	1.5	1.2	0.9
1500	7.0 (6.4)	5.3	4.4	3.5	2.8	2.2	1.7	1.3	1.0	0.8	0.6




Fig. I-14.3A S_{mt} - Type 304 SS

NOTE: Pages 55 to 60 from Code Case 1592. Figure Numbers omitted in this Report

CASE

N-47-12
(1592-12)

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

N266SR000002
56

Table I-14.5
Yield Strength Values, ¹S_y, vs. Temperature

Temp., F	304 SS	316 SS	Ni-Fe-Cr Alloy 800H	2% Cr-1 Mo	Ni-Cr-Fe-Cb Alloy 718
(Stresses in ksi Units)					
RT	30.0	30.0	25.0	30.0	150.0
100	28.8	29.2	24.3	29.4	148.4
200	25.0	25.8	22.5	27.8	143.9
300	22.5	23.3	21.1	26.8	140.7
400	20.7	21.4	20.0	26.6	138.3
500	19.4	19.9	19.0	26.5	136.7
600	18.2	18.8	18.3	26.5	135.4
700	17.7	18.1	17.5	26.5	134.3
750	17.3	17.8	17.2	26.5	133.7
800	16.8	17.6	16.8	26.5	133.1
850	16.5	17.4	16.5	26.3	132.4
900	16.2	17.3	16.3	25.6	131.5
950	15.9	17.1	16.1	24.7	130.5
1000	15.6	17.0	15.8	23.6	129.4
1050	15.2	16.7	15.6	22.1	128.0
1100	14.7	16.5	15.3	20.4	
1150	14.4	16.4	15.0	18.4	
1200	14.1	16.2	14.8	16.1	
1250	13.7	15.8	14.5		
1300	13.2	15.3	14.3		
1350	12.5	14.9	14.0		
1400	11.6	14.4	13.7		
1450	10.6	13.8	13.4		
1500	9.5	13.1	13.0		
1550			12.3		
1600			11.0		

¹The tabulated values of yield strength are those which the Committee believes are suitable for use in design calculations required by this Case. At temperatures above room temperature the yield strength values correspond to the yield strength trend curve adjusted to the minimum specified room temperature yield strength. The yield strength values do not correspond exactly to either "average" or "minimum" as these terms are applied to a statistical treatment of a homogeneous set of data.

Neither the ASME Materials Specifications nor the rules of this Case require elevated temperature testing for yield strengths of production material for use in Code components. It is not intended that results of such tests, if performed, be compared with these tabulated yield strength values for ASME Code acceptance/rejection purposes for materials. If some elevated temperature test results on production material appear lower than the tabulated values by a large amount (more than the typical variability of material and suggesting the possibility of some error) further investigation by retests or other means should be considered.

CASE (continued)
 N-47-12
 (1592-12)

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Table I-14.6A
 Expected Minimum Stress-to-Rupture Values, 1000 psi
 Type 304 SS

Temp., °F	1 hr	10 hr	30 hr	10 ² hr	3 X 10 ² hr	10 ³ hr	3 X 10 ³ hr	10 ⁴ hr	3 X 10 ⁴ hr	10 ⁵ hr	3 X 10 ⁵ hr
800	57	57	57	57	57	57	57	57	51	44.3	39
850	56.5	56.5	56.5	56.5	56.5	56.5	50.2	45.4	40	34.7	30.5
900	55.5	55.5	55.5	55.5	51.5	46.9	41.2	36.1	31.5	27.2	24
950	54.2	54.2	51	48.1	43	38.0	33.5	28.8	24.9	21.2	18.3
1000	52.5	50	44.5	39.8	35	30.9	26.5	22.9	19.7	16.6	14.0
1050	50	41.9	37	32.9	28.9	25.0	21.6	18.2	15.5	13.0	11.0
1100	45	35.2	31	27.2	23.9	20.3	17.3	14.5	12.3	10.2	8.6
1150	38	29.5	26	22.5	19.3	16.5	13.9	11.6	9.6	8.0	6.6
1200	32	24.7	21.5	18.6	15.9	13.4	11.1	9.2	7.6	6.2	5.0
1250	27	20.7	17.9	15.4	13	10.8	8.9	7.3	6.0	4.9	4.0
1300	23	17.4	15	12.7	10.5	8.8	7.2	5.8	4.8	3.8	3.1
1350	19.5	14.6	12.6	10.6	8.8	7.2	5.8	4.6	3.8	3.0	2.4
1400	16.5	12.1	10.3	8.8	7.2	5.8	4.7	3.7	3.0	2.3	1.9
1450	14.0	10.2	8.8	7.3	5.8	4.6	3.8	2.9	2.3	1.8	1.4
1500	12.0	8.6	7.2	6.0	4.9	3.8	3.0	2.4	1.8	1.4	1.1




Fig. I-14.6A Stress-to-rupture (minimum)

CASE N266SR000002
58

N-47
(1592-10)

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

Table I-14.7.
Modulus of Elasticity vs. Temperature

Temp., °F	(Static) Modulus of Elasticity, psi X 10 ⁻⁶			
	304 SS and 316 SS	Ni-Fe-Cr Alloy 800H	2% Cr - 1 Mo	Ni-Cr-Fe-Cb Alloy 718
70	28.3	28.5	29.9	-
100	-	-	-	29.0
200	27.7	27.8	29.5	28.38
300	27.1	27.3	29.0	27.93
400	26.6	26.8	28.6	27.51
500	26.1	26.3	28.0	27.10
600	25.4	25.7	27.4	26.69
700	24.8	25.2	26.6	26.26
750	-	-	-	-
800	24.1	24.6	25.7	25.82
850	23.7	24.4	-	-
900	23.3	24.1	24.5	25.35
950	22.9	23.8	-	-
1000	22.5	23.5	23.0	24.84
1050	22.1	23.3	-	24.56
1100	21.7	22.9	20.4	-
1150	21.3	22.7	-	-
1200	20.9	22.4	15.6	-
1250	20.5	22.1	-	-
1300	20.1	21.7	-	-
1350	19.7	21.4	-	-
1400	19.2	21.1	-	-
1450	18.7	20.7	-	-
1500	18.3	20.3	-	-
1550	-	19.8	-	-
1600	-	19.2	-	-

CASE

N-47
(1592-10)

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

N266SR000002
59




Fig. T-1430-1A,1B Design fatigue strain range, ϵ_f , 304 SS and 316 SS - elastic analysis

Table T-1430-1A, 1B

Design Fatigue Strain Range, ϵ_f , for 304 SS and 316 SS
(Elastic Analysis)

N_d Number of Cycles	ϵ_f , Strain Range (in./in.) at Temperature				
	800 F	850 F	900 F	950 F	1000-1200 F
10^1	.0448	.0303	.0201	.0137	.00915
2×10^1	.0318	.020	.0124	.0078	.00472
4×10^1	.0231	.0145	.00867	.0051	.00322
10^2	.0168	.00982	.00587	.00355	.00212
2×10^2	.0125	.00772	.00469	.0028	.00174
4×10^2	.00956	.00612	.00387	.0024	.00152
10^3	.00711	.00462	.00304	.00198	.00129
2×10^3	.00576	.00382	.00257	.00173	.00114
4×10^3	.00476	.00322	.00222	.00153	.00104
10^4	.00376	.00261	.00186	.0013	.000922
2×10^4	.00316	.00222	.00164	.00116	.000842
4×10^4	.00269	.00202	.00144	.00106	.000762
10^5	.00224	.00162	.00122	.000899	.000662
2×10^5	.00196	.00147	.00108	.000799	.000602
4×10^5	.00176	.00131	.000966	.000719	.000544
10^6	.00151	.00112	.000826	.000619	.000482

CASE (continued)

N-47
(1592-10)

CASES OF ASME BOILER AND PRESSURE VESSEL CODE




Fig. T-1800-A-4 Average isochronous stress-strain curves



APPENDIX B

THERMAL DEFORMATION ANALYSIS

Figure

- B-1 APSA Model for Static Assembly
- B-2 APSA Model for Rotating Assembly
- B-3 Finite Element Model @ Bearing Area - Node No.
- B-4 Finite Element Model @ Bearing Area - Element No.
- B-5 Finite Element Model @ Bearing Area - Node No.
- B-6 Finite Element Model @ Bearing Area - Element No.



THERMAL DEFORMATION ANALYSIS

The finite element computer program (APSA) has been used to determine the deflection of pump component during thermal transient events. As described in Section 3 of this report, the worst-time slices with maximum temperature difference (ΔT) were obtained through the iteration of the temperature time-history process. The worst-time slices for each transient were used in the stress-deformation model to determine the clearance change between all critical components. Figure B-1 through Figure B-12 showed the APSA stress model of nodes and element for various parts of the inducer-impeller assembly. Table B-1 through Table B-36 indicated the calculation of clearance from computer output for pump elements.

INTERMEDIA SODIUM INDUCER PUMP --- BOWL (APSA MODEL)
UNDEFORMED STRUCTURE

*0719083
040979 0002
AXISYMMETRIC ANALYSIS




FIG B-1 APSA MODEL
STATIC ASSEMBLY

INTERMEDIATE SODIUM INDUCER PUMP — PUMP SHAFT REGION
UNDEFORMED STRUCTURE

*0719083
033079 0002
AXISYMMETRIC ANALYSIS






FIG. B-2 APSA MODEL

ROTATING ASSEMBLY





SHAFT & JOURNAL
ROTATING ASSEMBLY

BEARING SUPPORT
STATIC ASSEMBLY

FIG. B-4 FINITE ELEMENT MODEL

ELEMENT NUMBER




FIG. B-5 FINITE ELEMENT MODEL
___ NODE POINT NUMBER






FIG. B-6 FINITE ELEMENT MODEL
ELEMENT NUMBER








FIG. B-9 FINITE ELEMENT MODEL

NODE POINT NUMBER




FIG. B-10 FINITE ELEMENT MODEL
ELEMENT NUMBER




FIG. B-II FINITE ELEMENT MODEL

NODE POINT NUMBER




FIG. B-12 FINITE ELEMENT MODEL

ELEMENT NUMBER

PREPARED BY:


 Rockwell International
 Energy Systems Group

N266SR000002

74

CHECKED BY:

REPORT NO.

DATE:

MODEL NO.

 N266ER000-001
 Page 443

TABLE B-1

 RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.-	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC-ROTATING = (Δ)			STATIC -ROTATING = (Δ)		
145-328	38.7	36.3	+2.4	34.5	32.8	+1.7
193-350	38.8	37.4	+1.4	35.6	33.8	+1.8
239-361	39.7	37.9	+1.8	35.8	34.6	+1.2
287-372	39.0	38.0	+1.0	32.9	34.9	+2.0
331-383	38.5	37.5	+1.0	33.5	34.3	+0.8
350-394	36.9	35.9	+1.0	32.3	33.0	+0.5
369-405	36.4	34.5	+1.9	32.2	32.0	+0.2
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY.

Rockwell International
Energy Systems GroupN266SR000002
75

CHECKED BY.

REPORT NO.

DATE.

MODEL NO.

N266ER000-001
Page 444

TABLE B-2

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES STA.-	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC-ROTATING = (Δ)			STATIC -ROTATING = (Δ)		
145-328	24.9	26.6	-1.7	29.0	30.1	-1.1
193-350	24.8	25.5	-0.7	27.9	29.0	-1.1
239-361	26.0	25.1	+0.9	29.8	28.3	-1.5
287-372	26.7	25.0	+1.7	31.6	28.0	+3.6
331-383	27.2	25.4	+1.8	32.2	28.5	+3.7
350-394	26.6	27.0	-0.4	31.1	29.9	+1.2
369-405	27.1	28.4	-1.3	31.2	30.9	+0.3
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:


 Rockwell International
 Energy Systems Group

N266SR000002

76

CHECKED BY:

REPORT NO.

DATE:

MODEL NO.

N266ER000-001


Page 445

TABLE B-3

 RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E204
 (MILS)

* NODES STA.-	TIME = 100 SEC.			TIME = 210 SEC.		
	STATIC-ROTATING = (Δ)			STATIC -ROTATING = (Δ)		
145-328	44.7	41.6	+3.1	40.8	38.0	+2.8
193-350	44.9	43.1	+1.8	42.1	39.7	+2.4
239-361	45.9	43.8	+2.1	42.2	40.8	+1.4
287-372	44.9	43.9	+1.0	39.7	41.1	-1.4
331-383	44.3	43.2	+1.0	38.9	40.3	-1.4
350-394	42.3	41.1	+1.2	37.4	38.2	-0.8
369-405	41.7	39.1	+2.6	37.2	36.5	+0.7
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 <small>OF</small>
CHECKED BY:		77
DATE:		MODEL NO.

N266ER000-001
Page 446

TABLE B-4

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E207
(MILS)

* NODES STA-	TIME = 275 SEC.			TIME = 385 SEC.		
	STATIC-ROTATING = (Δ)			STATIC -ROTATING = (Δ)		
145-328	45.7	41.1	+4.6	41.1	37.4	+3.7
193-350	47.2	43.7	+3.5	43.4	39.6	+3.8
239-361	47.0	45.3	+1.7	42.8	41.3	+1.5
287-372	43.8	45.7	-1.9	38.9	41.8	-2.9
331-383	42.6	44.5	-1.9	37.7	40.7	-3.0
350-394	40.8	41.0	-0.2	36.3	37.7	-1.4
369-405	40.2	38.3	+3.5	36.0	35.6	+0.4
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY.


 Rockwell International
 Energy Systems Group

 N266SR000002
 78

CHECKED BY.

DATE.

MODEL NO.

 N266ER000-001
 Page 447

TABLE B-5

 RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E208
 (MILS)

* NODES STA.-	TIME = 115 SEC.			TIME = 240 SEC.		
	STATIC-ROTATING = (Δ)			STATIC -ROTATING = (Δ)		
145-328	50.7	47.0	+3.7	45.9	42.8	+3.1
193-350	51.0	48.8	+2.2	47.5	44.6	+2.9
239-361	52.0	49.6	+2.4	47.5	45.9	+1.6
287-372	50.6	49.8	-0.8	44.6	46.2	-1.6
331-383	49.9	49.0	-0.9	43.7	45.4	-1.7
350-394	47.7	46.5	-1.2	42.1	40.0	-0.9
369-405	47.0	44.2	+2.8	41.9	41.3	+0.6
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:


 Rockwell International
 Energy Systems Group

N266SR000002

79

CHECKED BY:

REPORT NO.

DATE:

MODEL NO.


 N266ER000-001
 Page 448

TABLE B-6

 RADIAL CLEARANCE CHANGE
 TEST TRANSIENT E210
 (MILS)

* NODES STA.-ROT.	TIME = 50 SEC.			TIME = 150 SEC.		
	STATIC-ROTATING=(Δ)			STATIC-ROTATING=(Δ)		
145-328	52.1	49.9	+2.2	49.3	46.7	+2.6
193-350	52.0	50.8	+1.2	50.1	48.1	+2.0
239-361	53.7	51.1	+2.6	50.8	48.9	+1.9
287-372	53.5	51.1	+2.4	48.9	49.1	-0.2
331-383	53.1	50.7	+2.4	48.3	48.5	-0.2
350-394	50.9	49.3	+1.6	46.6	46.7	-0.1
369-405	50.3	47.9	+2.4	46.3	45.3	+1.0
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002 80
CHECKED BY:		REPORT NO.
DATE:		MODEL NO.

N266ER000-001
Page 449

TABLE B.7

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.-STA.	TIME = 100 SEC.			TIME = 280 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	67.9	59.2	+ 8.7	60.7	56.5	+ 4.2
772-731	67.7	60.8	+ 6.9	60.5	56.7	+ 3.8
770-729	62.9	56.3	+ 6.6	56.3	52.8	+ 3.5
782-742	63.1	56.7	+ 6.4	56.4	52.8	+ 3.6
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
81

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 450

TABLE B-8

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES STA.-STA.	TIME = 100 SEC.			TIME = 280 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	52.3	58.4	-6.1	59.4	61.1	-1.7
772-731	52.3	56.8	-4.5	59.5	60.8	-1.3
770-729	48.3	53.0	-4.7	55.0	56.6	-1.6
782-742	48.1	52.7	-4.6	54.7	56.5	-1.8
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
82

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 451

TABLE B-9

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E204
(MILS)

* NODES STA.-STA.	TIME = 100 SEC.			TIME = 210 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	77.6	66.0	+ 11.6	69.8	62.6	+ 7.2
772-731	77.6	68.1	+ 9.5	69.8	63.1	+ 6.7
770-729	72.2	63.1	+ 9.1	65.0	58.7	+ 6.3
782-742	72.6	63.6	+ 9.0	65.5	58.8	+ 6.7
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

TABLE B-10

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E207
 (MILS)

* NODES STA.-STA.	TIME = 275 SEC.			TIME = 385 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	74.6	61.8	+13.0	67.3	59.4	+ 7.9
772-731	74.5	63.6	+ 10.9	67.1	60.0	+ 7.1
770-729	69.5	58.9	+ 10.6	62.6	55.7	+ 6.9
782-742	70.2	59.4	+ 10.8	63.1	55.9	+ 7.2
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

PREPARED BY:



Rockwell International

Energy Systems Group

N266SR000002

84

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001

Page 453

TABLE B-11

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E208
 (MILS)

* NODES STA.-STA.	TIME = 115 SEC.			TIME = 240 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	87.5	74.4	+ 13.1	78.6	71.2	+ 7.4
772-731	87.5	76.7	+ 10.8	78.6	71.7	+ 6.9
770-729	81.4	71.1	+ 10.3	73.2	66.7	+ 6.5
782-742	81.8	71.6	+ 10.2	73.7	66.8	+ 6.9
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
85

CHECKED BY:

DATE:

MODEL NO.


N266ER000-001
Page 454

TABLE B-12

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E210
(MILS)

* NODES STA.-STA.	TIME = 50 SEC.			TIME = 150 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
765-694	94.6	84.1	+10.5	87.0	79.9	+7.1
772-731	94.7	86.3	+8.4	87.0	80.5	+6.5
770-729	87.9	80.0	+7.9	80.9	74.8	+6.1
782-742	88.0	80.5	+7.5	81.3	75.0	+6.3
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-11

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		86
DATE:		MODEL NO.

N266ER000-001
Page 455

TABLE B-13

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.- ROT.	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC-ROTATING = (Δ)			STATIC-ROTATING = (Δ)		
633 - 659	62.0	62.1	- 0.1	59.5	58.2	+ 1.3
653 - 658	61.1	60.2	+ 0.9	58.5	56.7	+ 1.8
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
87

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 456

TABLE B-14

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES	TIME = 100 SEC.			TIME = 280 SEC.		
	STA.-ROT.	STATIC-ROTATING = (Δ)		STATIC-ROTATING = (Δ)		
633 - 659	62.2	57.0	+ 5.2	64.6	60.9	+ 3.7
653 - 658	60.8	56.2	+ 4.6	63.4	59.8	+ 3.6
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
88

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 457

TABLE B-15

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E204
(MILS)

* NODES	TIME = 100 SEC.			TIME = 210 SEC.		
	STA.-	ROT.	STATIC-ROTATING = (Δ)	STATIC-	ROTATING = (Δ)	
633 - 659	69.0	69.7	-0.7	65.8	65.6	+0.2
653 - 658	68.1	67.5	+0.6	64.8	63.7	+1.1
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
89

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 458

TABLE B-16

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E207
(MILS)

* NODES	TIME = 275 SEC.			TIME = 385 SEC.		
	STA.-	ROT.	STATIC-ROTATING = (Δ)	STA.-	ROT.	STATIC-ROTATING = (Δ)
633 - 659	64.6	66.1	-1.5	62.4	62.3	+0.1
653 - 658	63.8	63.9	-0.1	61.5	60.4	+1.1
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
90

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 459

TABLE B-17

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E208
(MILS)

* NODES STA.- ROT.	TIME = 115 SEC.			TIME = 240 SEC.		
	STATIC-ROTATING = (Δ)			STATIC-ROTATING = (Δ)		
633 - 659	77.8	78.7	-0.9	74.9	74.2	+0.7
653 - 658	76.8	76.2	+0.6	73.8	72.1	+1.7
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
91

CHECKED BY:

DATE:

MODEL NO.


N266ER000-001
Page 460

TABLE B-18

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E20
(MILS)

* NODES	TIME = 50 SEC.			TIME = 150 SEC.		
	STA.-	ROT.	STATIC-ROTATING = (Δ)	STA.-	ROT.	STATIC-ROTATING = (Δ)
633 - 659			88.2 86.9 +1.3	84.1	82.9	+1.2
653 - 658			86.9 84.3 +2.6	82.7	80.7	+2.0
-						
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		92
DATE:		MODEL NO

N266ER000-001
Page 461

TABLE B-19

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410 - 464	61.6	54.9	+6.7	54.7	51.5	+3.2
446 - 481	60.6	56.9	+3.7	55.7	53.2	+2.5
463 - 499	59.7	58.5	+1.2	55.9	54.6	+1.3
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
93

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 462

TABLE B-20

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410 - 464	42.9	50.1	-7.2	49.7	53.5	-3.8
446 - 481	50.9	51.3	-0.4	55.9	55.0	+0.9
463 - 499	55.1	52.5	+2.6	58.9	56.4	+2.5
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
94

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 463

TABLE B-21

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E204
(MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 210 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410 - 464	70.8	61.6	+9.2	64.3	57.9	+6.4
446 - 481	68.6	64.1	+4.5	63.5	60.0	+3.5
463 - 499	66.9	65.8	+1.1	62.7	61.5	+1.2
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
95

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 464

TABLE B-22

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E207
(MILS)

* NODES STA.-ROT.	TIME = 275 SEC.			TIME = 385 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410 - 464	70.4	58.6	+11.8	62.9	55.4	+7.5
446 - 481	66.0	61.0	+5.0	61.1	57.3	+3.8
463 - 499	63.2	62.6	+0.6	59.8	58.8	+1.0
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY.



Rockwell International
Energy Systems Group

N266SR000002
96

CHECKED BY.

DATE:

MODEL NO.

N266ER000-001
Page 465

TABLE B-23

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E20 B
(MILS)

* NODES STA.-ROT.	TIME = 115 SEC.			TIME = 240 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410-464	80.1	69.5	+10.6	72.1	65.6	+6.5
446-481	77.5	72.2	+5.3	71.7	67.9	+3.8
463-499	75.4	74.1	+1.3	71.0	69.6	+1.4
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-7

PREPARED BY:

Rockwell International
Energy Systems GroupN266SR000002
97

CHECKED BY:

DATE:

MODEL NO.


N266ER000-001
Page 466

TABLE B-24

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E210
(MILS)

* NODES STA.-ROT.	TIME = 50 SEC.			TIME = 150 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
410 - 464	83.8	77.2	+6.6	78.9	73.1	+5.8
446 - 481	84.2	80.0	+4.2	79.6	75.6	+4.0
463 - 499	83.8	82.0	+1.8	79.5	77.6	+1.9
-						
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B.7

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		98
DATE:		REPORT NO.
		MODEL NO.

N266ER000-001
Page 467

TABLE B-25

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	50.3	51.3	-1.0	49.2	49.2	0.0
648-691	51.3	51.6	-0.3	49.3	49.2	+0.1
727-705	53.0	51.7	+1.0	49.6	49.2	+0.4
751-761	52.4	50.9	+2.0	49.4	49.1	+0.3
758-886	50.3	50.3	0	49.1	48.9	+0.2
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9



CHECKED BY:		N266SR000002
DATE:		99
		MODEL NO.

N266ER000-001
Page 468

TABLE B-26

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 280 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	52.5	49.6	+2.9	53.6	52.9	+0.7
648-691	51.5	49.9	+1.6	53.4	52.9	+0.5
727-705	49.8	50.0	-0.2	53.2	52.9	+0.3
751-761	50.4	50.4	0.0	53.2	52.9	+0.3
758-886	52.5	51.5	+1.0	53.5	53.1	+0.4
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9



CHECKED BY:

N266SR000002
100

DATE:

MODEL NO.

N266ER000-001
Page 469

TABLE B-27

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E204
(MILS)

* NODES STA.-ROT.	TIME = 100 SEC.			TIME = 210 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	55.7	59.0	-3.3	54.3	55.2	-0.9
648-691	57.1	58.6	-1.5	54.6	55.1	-0.5
727-705	59.4	58.5	+0.9	55.2	55.1	+0.1
751-761	58.6	57.8	+0.8	55.1	55.0	+0.1
758-886	55.7	56.2	-0.5	54.4	54.4	0.0
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9



CHECKED BY:

N266SR000002
101

DATE:

MODEL NO.

N266ER000-001
Page 470

TABLE B-28

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E207
(MILS)

* NODES STA.-ROT.	TIME = 275 SEC.			TIME = 385 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	52.4	55.3	-2.9	51.4	52.2	-0.8
648-691	53.5	55.0	-1.5	51.8	52.2	-0.4
727-705	55.4	55.0	+0.4	52.4	52.3	+0.1
751-761	54.8	54.5	+0.3	52.3	52.2	+0.1
758-886	52.5	53.0	-0.5	51.6	51.6	0.0
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9

TABLE B-29

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E208
(MILS)

* NODES STA.-ROT.	TIME = 115 SEC.			TIME = 240 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	62.9	66.6	-3.7	61.8	62.6	-0.8
648-691	64.5	66.1	-1.6	62.1	62.5	-0.4
727-705	66.9	66.0	+0.9	62.7	62.5	+0.2
751-761	66.0	65.3	+0.7	62.6	62.4	+0.2
758-886	63.0	63.6	-0.6	62.0	61.9	+0.1
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9

CHECKED BY:

DATE:


N266ER000-001
Page 472

TABLE B-30

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E210
(MILS)

* NODES STA.-ROT.	TIME = 50 SEC.			TIME = 150 SEC.		
	STATIC - ROTATING = (Δ)			STATIC - ROTATING = (Δ)		
630-677	71.3	74.3	-3.0	69.4	70.3	-0.9
648-691	72.9	73.8	-0.9	69.7	70.2	-0.5
727-705	75.3	73.7	-1.6	70.3	70.2	+0.1
751-761	74.3	73.0	-1.3	70.1	70.0	+0.1
758-886	71.1	71.5	-0.4	69.5	69.4	+0.1
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-9

PREPARED BY:	 Rockwell International Energy Systems Group	N266SR000002
CHECKED BY:		104
DATE:		MODEL NO.

N266ER000-001
Page 473

TABLE B-31

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E202
 (MILS)

* NODES STA.-STA.	TIME = SEC.			TIME = SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	51.0	47.7	+3.3	47.4	42.0	+5.4
291-290	50.9	47.4	+3.5	47.5	41.4	+6.1
335-334	50.1	47.0	+3.1	46.1	40.8	+5.3
374-373	50.1	45.6	+4.5	44.8	40.5	+4.3
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
105

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 474

TABLE B-32

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E203
(MILS)

* NODES STA.-STA.	TIME = 100 SEC.			TIME = 280 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	32.3	32.3	0.0	35.7	37.9	-2.2
291-290	32.4	32.6	-0.2	35.6	38.5	-2.9
335-334	33.1	33.0	+0.1	37.0	39.1	-2.1
374-373	33.0	34.3	-1.3	38.3	39.4	-1.1
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:



Rockwell International

Energy Systems Group

N266SR000002

106

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001

Page 475

TABLE B-33

RADIAL CLEARANCE CHANGE (Δ)
 TEST TRANSIENT E204
 (MILS)

* NODES STA.-STA.	TIME = 100 SEC.			TIME = 210 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	59.1	54.9	+4.2	56.0	49.0	+6.9
291-290	58.9	54.6	+4.3	56.1	48.1	+8.0
335-334	57.9	54.0	+3.9	54.4	47.4	+7.0
374-373	57.9	52.2	+5.7	53.1	46.6	+6.5
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:



Rockwell International

Energy Systems Group

N266SR000002
107

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 476

TABLE B-34

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E207
(MILS)

* NODES STA.-STA.	TIME = 275 SEC.			TIME = 305 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	63.0	54.4	+8.4	58.5	48.6	+9.9
291-290	63.0	53.2	+9.8	58.7	47.1	+11.6
335-334	60.4	52.1	+8.3	55.5	46.0	+9.5
374-373	58.9	50.3	+8.6	52.8	45.2	+7.2
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
108

CHECKED BY:

DATE:

MODEL NO.

N266ER000-001
Page 477

TABLE B-35

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E208
(MILS)

* NODES STA.-STA.	TIME = 115 SEC.			TIME = 240 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	67.1	62.0	+5.1	63.2	55.2	+8.0
291-290	67.0	61.5	+5.5	63.3	54.1	+9.2
335-334	65.7	60.8	+4.9	61.3	53.3	+8.0
374-373	65.6	58.8	+6.8	59.6	52.6	+7.0
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3

PREPARED BY:



Rockwell International
Energy Systems Group

N266SR000002
109

CHECKED BY:

DATE:

MODEL NO.


N266ER000-001
Page 478

TABLE B-36

RADIAL CLEARANCE CHANGE (Δ)
TEST TRANSIENT E210
(MILS)

* NODES STA.-STA.	TIME = 50 SEC.			TIME = 150 SEC.		
	OUTER - INNER = (Δ)			OUTER - INNER = (Δ)		
267-266	68.2	65.1	+3.1	66.2	60.2	+6.0
291-290	68.1	65.0	+3.1	66.2	59.8	+6.4
335-334	67.4	64.7	+2.7	65.0	58.9	+6.1
374-373	67.8	63.1	+4.7	64.2	58.1	+6.1
-						
-						
-						
-						

* LOCATIONS EXHIBITED IN FIG. B-3



46 1240

K&E 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

TIME (SECONDS)

FIG. B-13




FIG. B-14

46 1240

K&Z 20 X 20 TO THE INCH 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN USA

46 1240

20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.





FIG. B-15

46 1240

K·E
20 X 20 TO THE INCH 7 X 10 INCHES
REUFFEL & ESSER CO. MADE IN U.S.A.



TIME (SECONDS)

FIG. B-16

TRANS. 207

46 1240

KE 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.




FIG. B-17

46 1240

K&E 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.




FIG. B-1B

INTERMEDIATE SIZE INDUCER PUMP — BOWL (APSA MODEL)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE ID AF1310
ISIP BOWL

*0719083
032379 0005
PLOT NO.5




FIG. B-19 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 Seconds)

INTERMEDIATE SIZE INDUCER PUMP ----- BOWL (APSA MODEL)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE ID AF1310
ISIP BOWL

*0719083
032379 0010
PLOT NO.10




FIG. B-20 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 Seconds)

INTERMEDIATE SIZE INDUCER PUMP — BOWL (APSA MODEL)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE ID AF1310
ISIP BOWL

*0719083
032379 0015

PLOT NO. 15




FIG. B-21 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 Seconds)

INTERMEDIATE SODIUM PUMP---SHAFT (APSA PLOT)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE ID UN0162
SHAFT (BOWL)

*0719983
032379 0005
PLOT NO.5




FIG. B-22 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 seconds)

INTERMEDIATE SODIUM PUMP---SHAFT (APSA PLOT)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE ID UN0182
SHAFT (BOUL)

*0719083
032379 0010
PLOT NO.10




FIG. B-23 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 Seconds)

INTERMEDIATE SODIUM PUMP---SHAFT (AFSA PLOT)
AXISYMMETRIC ANALYSIS STRESS-INTENSITY IS PLOTTED TAPE 10 UN0182
SHAFT (BOAL)

*0719083
032379 0015
PLOT NO.15




FIG. B-24 STRESS INTENSITY

(TEST TRANSIENT E-207 at 275 Seconds)

TABLE B-37

THERMAL TRANSIENTS

Transient Number*	Sodium Flow Rate (gpm)	Initial Temp. °F	Final Temp. °F	$\Sigma \Delta T$ °F	dT/dt °F/sec
201					
202	14500	750	600	-150	-1.5
203	14500	500	650	+150	+1.5
204	14500	850	650	-200	-2.0
205					
206					
207	14500	950**	620**	-330	-1.2
208	14500	950**	725**	-225	-2.0
210	14500	950**	800**	-150	-3.0

*From Specification N266ST310001, Table 4-II (Ref. 6)

** Note see Reference 9



APPENDIX C


COMPUTER PROCEDURES FOR STRUCTURAL AND THERMAL DEFORMATION ANALYSIS


References

1. J. F. Newell and S. F. Persselin, "Finite Element Axisymmetric and Planar Structural Analysis," SSME 74-1282, Rocketdyne Division, Rockwell International, Canoga Park, California 91304, April 18, 1974
2. H. C. Hsiung, "Computer Procedures to Make Thermal Stress Runs Using the APSA Computer Code," IL 600-77-216, Atomics International Division, Rockwell International, Canoga Park, California 91306, June 13, 1977



In the evaluation of structural and thermal deformation analyses for ISIP, APSA-Mark Interface Computer Code has been utilized to input thermal transient data into APSA finite element program. TAP (Thermal Analysis Program) was used to determine critical temperature difference (ΔT) through the time-history iteration of each transient for various cross section of pump components. The critical temperature field and time slices of each transient were then used as input for calculating thermal stress and deflection in APSA program. Figure C1 shows the flow chart of computer procedure used. The basic purpose using APSA-Mark Interface Computer Code was that the two programs have different purposes of usage. The computer input cards setup is shown in Figures C2, C3, and C4. Figure C2 shows the coordinates input of temperature field nodes from TAP tape into APSA tape File 1. Figure C3 is the setup for storing TAP temperature field and time slices in APSA tape File 2. APSA finite element model uses the temperature time slice from File 2 for determining the stress and deflection as shown in Figure C4.

PREPARED BY:	 Rockwell International Energy Systems Group	Page 495
CHECKED BY:		N266SR000002 125
DATE:		MODEL NO.



Note:

The APSA input tape contains the temperature field history data of the selected transients, while the output tape contains the thermal stress analysis results.


FIGURE C1- Flow Chart of Computer Procedures to Use the APSA Code for Thermal Stress Analysis

 * JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL JFSJCL

```
//WCA09027 JOB 'LOFFREDDI      AI731160*0719083      005      9990005 37', *
//  REGION=500K,TIME=1
/*FORMAT PR,DDNAME=JESI001,CONTROL=SINGLE,OVPL=ON
//STPL EXEC @FLINK
//L.SYSIN DD DSN=AWW025.APSAMARK.URJECT,DISP=SHR
//G.FT01F001 DD UNIT=2400-3,DISP=(OLD,KEEP,KEEP),DCB=BUFN0=1,
//  VOL=SER=AF0304,LABEL=(1,SL),DSN=ISI.PUMP.GEOM
//G.FT11F001 DD DISP=(NEW,KEEP,DELETE),VOL=REF=*FT01F001,LABEL=(2,SL),
//  DCB=(RECFM=VRS,BLKSIZE=13030,BUFN0=1),DSN=ISI.PUMP.WNFLW
//G.FT09F001 DD UNIT=2400-3,DISP=(OLD,KEEP,KEEP),DCB=BUFN0=1,
//  VOL=SER=UHB878,LABEL=(1,SL),DSN=ISIP.E202
//G.SYSIN DD *      (APSAMARC IOPTH=2 INPUT DECK FOLLOWS THIS CARD)
  INTERMEDIATE SIZE INDUCER PUMP
    2 643 1 600
/*
```

FIG C-3 JCL SETUP
 (TAP TEMPERATURE FIELD STORE IN APSA TAPE FILE 2)

PREPARED BY:	
CHECKED BY:	
DATE:	
MODEL NO.	



N266SR000002
 127

* JESJCL JFSJCL JFSJCL JESJCL JFSJCL JESJCL JFSJCL JESJCL JESJCL JFSJCL


```
//WCA12070 JOB 'LOFFREDO      AI731160*0719083      005      9990032 37', *
// REGION=800K,TIME=5
//*MAIN TAPEAUTH=WDY
/*FORMAT PR,FORMS=STAND-SW,DDNAME=FT06F001
/*FORMAT PR,DDNAME=JESI0001,CONTROL=SINGLE,OVFL=ON
/*FORMAT PR,DDNAME=JESI0002,CONTROL=SINGLE,OVFL=ON
// EXEC KAPSA,PLOTDSN='ISI.PUMP',DISP=PASS
//A,FT20F001 DD VOL=SER=AF0304,LABEL=(2,SL),DSN=ISI.PUMP.WNFLW
//SYSIN DD *
// EXEC KAPSAPLT,PLOTDSN='ISI.PUMP'
//SYSIN DD *
```

INTERMEDIATE SIZE INDUCER PUMP --- PUMP SHAFT

-1 3 -280 70.

(BLANK CARD) (APSA STRESS MODEL CARDS FOLLOW THIS BLANK CARD)

FIG. C-4 JCL SETUP
(APSA STRESS MODEL UTILIZE TEMPERATURE DATA IN FILE 2)

PREPARED BY:	
CHECKED BY:	
DATE:	
 Rockwell International Energy Systems Group	
MODEL NO.	N266SR000002 128




APPENDIX J

TRANSIENT THERMAL ANALYSIS OF ISIP

ESG Document N266TI000-008

Pages 108 thru 281 (computer printout) have been removed from this document for brevity.

 SUPPORTING DOCUMENT		NUMBER N266TI000-008	REV LTR/CHG NO. SEE SUMMARY OF CHG																																																						
PROGRAM TITLE Intermediate Size Inducer Pump (ISIP)		DOCUMENT TYPE Technical Information																																																							
DOCUMENT TITLE Transient Thermal Analysis of ISIP (Intermediate Size Inducer Pump)		KEY NOUNS ISIP, Thermal Model																																																							
PREPARED BY/DATE K. H. Yun <i>K. H. Yun 5/10/79</i> DEPT 731 MAIL ADDR LB35 A. A. Loffredo <i>A. A. Loffredo 5-10-79</i> DEPT 731 MAIL ADDR LB35 E. M. Mouradian <i>E. M. Mouradian 5/10/79</i> DEPT 731 MAIL ADDR LB35		ORIGINAL ISSUE DATE GO NO. 09280 S/A NO. 22000 PAGE 1 OF 281 TOTAL PAGES REL. DATE <i>5-18-79 lf</i>																																																							
IR&D PROGRAM? YES <input type="checkbox"/> NO <input type="checkbox"/> IF YES, ENTER TPA NO. _____		SECURITY CLASSIFICATION (CHECK ONE BOX ONLY) (CHECK ONE BOX ONLY)																																																							
APPROVALS D. K. Nelson <i>D. K. Nelson</i> DATE <i>5-8-79</i> R. V. Anderson <i>R. V. Anderson</i> DATE <i>5-9-79</i> T. J. Boardman <i>T. J. Boardman</i> DATE <i>5-10-79</i>		UNCL <input checked="" type="checkbox"/> DOE <input type="checkbox"/> DOD <input type="checkbox"/> CONF. <input type="checkbox"/> DEFENSE <input type="checkbox"/> SECRET <input type="checkbox"/> INFO. <input type="checkbox"/>																																																							
DISTRIBUTION		ABSTRACT																																																							
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 5%;">*</th> <th style="width: 75%;">NAME</th> <th style="width: 20%;">MAIL ADDR</th> </tr> </thead> <tbody> <tr><td>**</td><td>R. V. Anderson</td><td>LB17</td></tr> <tr><td>**</td><td>T. J. Boardman</td><td>LB13</td></tr> <tr><td></td><td>R. A. Castle</td><td>LB35</td></tr> <tr><td>*</td><td>T. K. Cheng</td><td>LB35</td></tr> <tr><td></td><td>C. C. Conners</td><td>LB30</td></tr> <tr><td>**</td><td>C. Dunn</td><td>LB39</td></tr> <tr><td></td><td>M. A. Grisham</td><td>LB26</td></tr> <tr><td></td><td>G. J. Hallinan</td><td>LB39</td></tr> <tr><td></td><td>R. K. Hoshide</td><td>JB05</td></tr> <tr><td>**</td><td>J. L. Lockett</td><td>LB39</td></tr> <tr><td>*</td><td>A. A. Loffredo</td><td>LB35</td></tr> <tr><td>*</td><td>E. M. Mouradian</td><td>LB35</td></tr> <tr><td></td><td>D. K. Nelson</td><td>LB35</td></tr> <tr><td>**</td><td>J. N. Nishizaka</td><td>LB35</td></tr> <tr><td></td><td>R. E. Schnurstein</td><td>LB17</td></tr> <tr><td></td><td>C. Q. Torrijos</td><td>LB26</td></tr> <tr><td>*</td><td>K. H. Yun</td><td>LB35</td></tr> </tbody> </table>		*	NAME	MAIL ADDR	**	R. V. Anderson	LB17	**	T. J. Boardman	LB13		R. A. Castle	LB35	*	T. K. Cheng	LB35		C. C. Conners	LB30	**	C. Dunn	LB39		M. A. Grisham	LB26		G. J. Hallinan	LB39		R. K. Hoshide	JB05	**	J. L. Lockett	LB39	*	A. A. Loffredo	LB35	*	E. M. Mouradian	LB35		D. K. Nelson	LB35	**	J. N. Nishizaka	LB35		R. E. Schnurstein	LB17		C. Q. Torrijos	LB26	*	K. H. Yun	LB35	<p>Transient thermal analysis has been performed for the Intermediate Size Inducer Pump (ISIP) for six transients. The overall thermal model of the pump was used. The results have been transmitted to the stress analyst.</p> <p>The transients run are Nos. 202, 203, 204, 207, 208, and 210. The inlet sodium temperature changes considered range from 150° to 330° F. The rate of change of inlet sodium temperatures range from 1.2 to 3.0° F/sec.</p>	
*	NAME	MAIL ADDR																																																							
**	R. V. Anderson	LB17																																																							
**	T. J. Boardman	LB13																																																							
	R. A. Castle	LB35																																																							
*	T. K. Cheng	LB35																																																							
	C. C. Conners	LB30																																																							
**	C. Dunn	LB39																																																							
	M. A. Grisham	LB26																																																							
	G. J. Hallinan	LB39																																																							
	R. K. Hoshide	JB05																																																							
**	J. L. Lockett	LB39																																																							
*	A. A. Loffredo	LB35																																																							
*	E. M. Mouradian	LB35																																																							
	D. K. Nelson	LB35																																																							
**	J. N. Nishizaka	LB35																																																							
	R. E. Schnurstein	LB17																																																							
	C. Q. Torrijos	LB26																																																							
*	K. H. Yun	LB35																																																							
* COMPLETE DOCUMENT ** COMPLETE DOCUMENT, EXCEPT APPENDIX C.		RESERVED FOR PROPRIETARY/LEGAL NOTICES																																																							
731-E.209/kam		<p style="text-align: center;">THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE</p> <p>This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.</p>																																																							
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																																																									



CONTENTS

	<u>Page</u>
I. INTRODUCTION AND SUMMARY.....	5
II. ANALYSIS.....	8
III. DISCUSSION OF RESULTS.....	10
IV. REFERENCES.....	15
APPENDICES.....	40
A. Supporting Calculations.....	40
B. Clearance Changes.....	104
C. Transient Analysis & Computer Listing.....	107



FIGURES

<u>Figure</u>	<u>Page</u>
1. Layout: Intermediate Sodium Inducer Pump.....	16
2. ISIP: Overall Thermal Model.....	17
3. Flow Pattern for Sodium Nodes.....	18
4. Stamp Output CRT.....	19
5. ISIP New Hardware.....	20
6. Weighted Average Temperature - TRANS 202.....	21
7. Weighted Average Temperature - TRANS 203.....	22
8. Weighted Average Temperature - TRANS 204.....	23
9. Weighted Average Temperature - TRANS 207.....	24
10. Weighted Average Temperature - TRANS 208.....	25
11. Weighted Average Temperature - TRANS 210.....	26
12. Node Number Across Inducer, Tie Bolt & Inducer Tunnel.....	27
13. Temperature Differences Across the Inducer, Tie Bolt & Inducer Tunnel - TRANS 202D203.....	28
14. Temperature Differences Across the Inducer, Tie Bolt & Inducer Tunnel - TRANS 204D207.....	29
15. Temperature Differences Across the Inducer, Tie Bolt & Inducer Tunnel - TRANS 208D210.....	30
16. ISIP - Thermal Effect on Radial Clearance.....	31
17. Rear Labyrinth.....	32
18. Rearing Region.....	33
19. Temperature Difference for the Bearing Region, Rear Labyrinth & Radial Clearance - TRANS 202.....	34
20. Temperature Difference for the Bearing Region, Rear Labyrinth & Radial Clearance - TRANS 203.....	35
21. Temperature Difference for the Bearing Region, Rear Labyrinth & Radial Clearance - TRANS 204.....	36
22. Temperature Difference for the Baring Region, Rear Labyrinth & Radial Clearance - TRANS 207.....	37
23. Temperature Difference for the Bearing Region, Rear Labyrinth & Radial Clearance - TRANS 208.....	38
24. Temperature Difference for the Bearing Region, Rear Labyrinth & Radial Clearance - TRANS 210.....	39



TABLES

<u>Table</u>	<u>Page</u>
1. Hydrodynamic Design Report.....	6
2. Test Thermal Transients.....	7
3. Transient Temperature Data.....	11



I. INTRODUCTION AND SUMMARY

The purpose of this study is to evaluate the transient thermal behavior of the intermediate size inducer pump (ISIP) during the six thermal transients.

An overall thermal model (Figure 2) has been set up for the pump based on the drawing of Figure 1 (Reference 1).

Approximately 10 thermal transients are indicated in the specification (Reference 2). Of these, six were analyzed, some with minor temperature modification, as discussed in Reference 3. Table I shows the updated pump design point, and Table II shows the list of six transients that were analyzed.

The basic pump frame for the ISIP is from the FFTF prototype pump. Some of the pump internals have been changed according to the Rockwell International design. The changes included new inducer, impeller, diffuser, and other necessary adapter hardware. The original impeller has been replaced.

The results of the thermal analysis are stored on magnetic computer tape (corresponding to the nodal model of Figure 2). Some of the results are summarized in the figures of this report.

The purpose of the analytical effort (both thermal and structural) is to establish the pump's capability to withstand thermal transients without damage or alternatively, to indicate that particular transients must not be run in the test program.

TABLE I
HYDRODYNAMIC DESIGN POINT

Flow Rate	14,500 gpm
Total Head Across Pump	500 ft
Shaft Speed	1,100 rpm
Type of Fluid	Sodium
Maximum Inlet Transient Temperature	950°F
Minimum Inlet Transient Temperature	600°F

TABLE II

TEST THERMAL TRANSIENTS

TRANSIENT NUMBER	SODIUM FLOW RATE (GPM)	INITIAL TEMP. °F	FINAL TEMP. °F	$\Sigma \Delta T$ °F	dT/dt °F/SEC	CRITICAL TIMES (SEC)
202	14500	750	600	-150	-1.5	100 280
203	14500	500	650	+150	+1.5	100 280
204	14500	850	650	-200	-2.0	100 210
207	14500	950	620	-330	-1.2	275 385
208	14500	950	725	-225	-2.0	115 240
210	14500	950	800	-150	-3.0	50 150



II. ANALYSIS

Thermal analysis was conducted using the TAP computer program package. A conservative two-dimensional model (Figures 2 and 3) was constructed to simulate the geometry of the ISIP. Symmetry was assumed in setting up the model. In Reference 9, calculations were made with this model and the results compared with FFTF tests. These results verified the validity of this model.

The design specification for the thermal model required the ISIP to withstand the specified thermal transients. The effects of thermally induced stresses and deflections must be evaluated.

Figure 3 shows the nodal network and flow pattern for the sodium nodes. Flow paths were obtained from Reference 4. Flow conditions are discussed in Appendix A. The sodium flow pattern is built into the model.

The overall thermal model of the ISIP was set up based on Figure 1. The thermal model in Figure 4 was processed using the STAMP program (Reference 5) generating the nodal network with the areas, form factors, and nodal volumes for use in the TAP program (References 6 and 7). Additional supporting calculations are shown in Appendix A. These include form factor calculations for the inducer, impeller, diffuser, sodium flow node volumes, and heat transfer coefficients.

The thermal properties of sodium were taken as constant as shown in Appendix A. The properties of the stainless steel and sodium were taken from Reference 8. The thermal conductivity and thermal capacity for the stainless steel were input into the TAP program as functions of temperature.



Heat transferred by mass transport between volumes was accounted for by fluid channel elements. For these, specific mass flow rate and direction were specified by Reference 4. Pump bowl and pump casing wall outer surfaces were assumed adiabatic. The inlet nozzle was added to the network generated by hand as shown in Figure 2.



III. DISCUSSION OF RESULTS

The results of the transients computer runs are stored on magnetic tapes, as indicated in Table III. The data now shown on the computer output sheets or CRT's can be retrieved a a later time. Also, the data can be called from the tapes for use with the APSA program for stress and deflection analysis.

The critical times for thermal deflection (i.e., when the deflection is a maximum) during transients has been determined. This determination has been made for three different locations: (1) AI modification, (2) rear labyrinth, and (3) bearing region.

A. AI MODIFICATIONS

Figure 5 shows the relative position of the ISIP new hardware. This includes the impeller, inducer, shaft nut, and tie bolt. The weighted temperature for each of the four components were plotted versus time. It can be seen that for each of the six transients in Figure 6 through Figure 11, the greatest temperature difference occurs between the impeller and the shaft nut. Thus, the critical time is taken to be when the greatest temperature difference occurs. Figure 12 shows some thermal nodes at particular places, tie bolt, inducer, and inducer tunnel. The temperature differences across the tie bolt, inducer, and inducer tunnel can be seen on Figures 13 through 15. Figure 16 shows subdivisions of the ISIP for the rotating and nonrotating parts with their nominal radial clearances.



TABLE III
TRANSIENT TEMPERATURE DATA

Transient Number	Tape Name	Tape Volume Serial Number
202	ISIP.E202	UH 8878
203	ISIP.E203	UG 5728
204	ISIP.E204	UP 8892
207	ISIP.E207	AE 9996
208	ISIP.E208	UP 7819
210	ISIP.E210	UL 1717



B. REAR LABYRINTH

Figure 17 shows the position of the rear labyrinth with its respective radial clearance. For temperature deflections, Nodes 174 and 51 were chosen for the nonrotating part and rotating part, respectively.

C. BEARING REGION

For radial thermal deflection, Figure 18 shows the subdivisions of the bearing region. Temperature differences between the shaft and the bearing, shaft and the bearing support and bearing were plotted as functions of time.

The results of the thermal analysis were made available to the stress unit. On the basis of temperature differences for the three regions discussed above, the critical times for thermal deflections were determined. The temperature distributions for these time slices are employed by the stress analyst to determine stress distributions and gap deflections. Two critical times were determined for each of the six transients. Appendix B shows the thermal deflections for each of the six transients (Reference 10).

The individual transients are discussed below.

1. Transient 202

It is a down transient. The first critical time, 100 sec after the start of the transient, was selected for the region of the inducer and impeller (Figures 6 and 13) and for the radial clearance of the blade and the static assembly (Figure 19). The second critical time (280 sec)



was determined for the bearing region. For the rear labyrinth region, the time was determined to be 180 sec. However, the highest temperature difference at this particular time is only 16^oF, and the gap has a radial clearance of 50 mils.

2. Transient 203

This is the only up transient. The slope of the transient (1.5^oF/sec) is the same value as in Transient 202. Due to the same identical conditions (but different startup temperatures), the critical times were found to be the same as in Transient 202, that is at 100 and 280 sec. It can be seen from Figures 7, 13, and 20, that the temperature differences for the three separate regions are essentially the same as Transient 202 except for a change in sign.

3. Transient 204

It is a down transient. The first critical time (100 sec) was selected for the inducer and impeller (Figures 8 and 14) and for the radial clearance of the blade and the nonrotating part of the ISIP (Figure 21). The second critical time was determined to be 210 sec. At this time, the bearing region and rear labyrinth portion have temperature differentials of 94% and 95%, respectively, of their peak values.

4. Transient 207

This is a down transient with the greatest overall temperature change (nominally 330^oF). According to Figures 9, 14, and 22, the first critical time was determined to be 275 sec for the new hardware of the ISIP. At this time, the rear labyrinth region at 96% of its peak value (Figure 22). For the bearing area, the time chosen was 385 sec. Both temperature differentials are over 95% of their peak values at t = 385 sec.



5. Transient 208

The weighted temperature and temperature differences for the down Transient 208 can be seen in Figures 10, 15, and 23. The first critical time was determined to be 115 sec for the inducer and the impeller region. The second critical time was determined to be 240 sec for the bearing portion and the rear labyrinth area (Figure 23).

6. Transient 210


This is the down transient with the steepest slope, dT/dt (nominally $-3.0^{\circ}\text{F}/\text{sec}$). Figures 11, 15, and 24 show the first critical time to be 50 sec for the new hardware area. The second critical time was determined to be 150 sec for the rear labyrinth portion and the bearing region.



REFERENCES

1. Westinghouse Electric Corporation, Drawing No. 689J080, "General Layout FFTF Prototype Pump"
2. D. R. Paradise, "Design Specification: Pump, Sodium, Inducer, Intermediate Size," N266ST310001, June 10, 1978, Atomics International Division
3. J. M. Nishizaka/E. M. Mouradian, "Estimate for Completion of ISIP Program Thermal/Stress Analysis," IL 620-79-043, March 12, 1979, Atomics International Division
4. R. K. Hoshide, "Recirculation Flow Analyses of Intermediate Size Inducer Pump (ISIP)," TI N266TI000003, April 20, 1978, Atomics International Division
5. R. E. Craig, "Stress to Thermal Adaptation Model Program (STAMP) Description and User's Manual," TI 036-610-007, July 29, 1974, Atomics International Division
6. E. Moody, "Thermal Analyses Program Revision (TAP-4F)," TI 099-411-015, August 1974, Atomics International Division
7. A. V. VonArx, "Thermal Analysis Program (TAP) Description and User's Manual," N036CPM620006, January 1979, Atomics International Division
8. Hanford Engineering Development Laboratory, "Nuclear System Materials Handbook," Volume 1, Book 1 (Steel), and Book 3 (Sodium), TID-26666
9. K. H. Yun/A. A. Loffredo/E. M. Mouradian, "Verification of Thermal Model for ISIP," N266TI000-007, March 9, 1979, Atomics International Division
10. T. K. Cheng/J. N. Nishizaka, "ISIP-Structural and Transient Deformation Analysis," N266SR000-002, May 5, 1979, Atomics International Division

- SHAFT FULL HIGH PORTANCE
1/4 E 789 (P)
MATERIAL: TYPE 304 SS (REF)
- BEARING SUPPORT MACHINING
1/4 E 939 (M)
MATERIAL: TYPE 304 SS (REF)
- NET HEAD CAP OPEN
16 PL
1-10 X 1.50 L6 PER ANSI B 8.21 (M)
MATERIAL: A286 ALLOY PER ASTM A583 GRADE 660, COND B.
- DIFFUSER VANES ASSY OF ISIP
E 00196 02 (E2)
MATERIAL: TYPE 304 SS
- PELLER ISIP
E 00196 01 (E2)
MATERIAL: TYPE 304 SS
- NET HEAD CAP SCREEN
16 PL
1-13 X 1.00 L6 PER ANSI B 8.21 (M)
MATERIAL: A286 ALLOY PER ASTM A583 GRADE 660, COND B.
- ASSEMBLY MACHINING
1/4 E 727 (M)
MATERIAL: TYPE 304 SS (REF)
- WASHER TAB LOCK (10 PL)
E 00196 02 (E2)
MATERIAL: TYPE 304 SS
- FLATON RING ISIP
E 00196 03 (E2)
MATERIAL: TYPE 304 SS
- RIMP SHIELD INSERT ISIP
N26600012 (M)
MATERIAL: TYPE 304 SS
SEE VIEW C (E)
- TAB ISIP
E 00196 02 (E2)
MATERIAL: TYPE 304 SS
- INDUCER ISIP
E 00196 03 (E2)
MATERIAL: TYPE 304 SS



- 1 THIS LAYOUT IS BASED ON WESTINGHOUSE COMPONENTS MODIFIED BY BEVEL PER DRAWING N266SK000017 (M)
- 2 INTERMEDIATE CONTROL DIMENSIONS PER N266E000002 (M) TOLERANCE STUDY PER N266SK000011 (M)
- 3 ORIGIN SYMBOLS OF REFERENCED DRAWINGS:
(M) ATOMIC INTERNATIONAL
(E2) ROCKWELL INTERNATIONAL
(R) WESTINGHOUSE ELECTRIC CORPORATION
- 4 ASSEMBLY AND DISASSEMBLY PER UMM-DSI-00-005, EMISSION 2, ADDENDUM 1
- 5 DYNAMIC BALANCE OF ROTATING PARTS PER SPEC N266ST270000 (M)
- 6 HATCHED LOCATION OF MATERIAL AVAILABLE FOR MACHINING TO BALANCE A COMPONENT
- 7 PASSAGE FOR (M) VENTING (E2) DENIMING
- 8 DIMENSION INT 13 IS TO BE READ: (M) TIGHT (INTERFERENCE FIT) (E2) LOOSE (CLEARANCE FIT); FITS ARE GIVEN PER DIAMETER.
- 9 PROVISIONS FOR:
(M) ASSEMBLY
(E2) DISASSEMBLY
(R) HANDLING (HOISTING)
(E2) TOOLING
- 10 REMOVE IN FINAL ASSEMBLY
- 11 CORRELATION OF DIFFUSER VANES TO BE ESTABLISHED PER DRAWING N266SK000017 QIN 5, 6 & 7.
- 12 CALCULATED VOLUME OF RESIDUAL SODIUM IN UNGRAINED POCKETS 48.2 IN³
- 13 SYMBOL \bar{G} INDICATES CENTER OF GRAVITY
- 14 FITS ARE BASED ON ARITHMETIC AVERAGE OF SIZES BY MEASUREMENT OF "AS BUILT" COMPONENTS; OTHER FITS ARE BASED ON DRAWING SIZES AND THEIR TOLERANCES.
- 15 PER SPECIFICATION N266E000001 VISUALLY INSPECT 5X MAG. FOR EVIDENCE OF CRACKS
- 16 ALL COMPONENTS OF THE ASSEMBLY TO BE CLEANED PER N266A010001, LEVEL 3.
- 17 CONFORM TO THE REQUIREMENTS OF THE SPECIFICATION NO N266ST310001
- 18 LAYOUT PER SPECIFICATION N266ST310001


FIGURE 1
LAYOUT:
INTERMEDIATE SODIUM
INDUCER PUMP

MICROFILMED REDUCED DRAWING

RELEASED
DRAWING 1071

THIS DOCUMENT IS NOT TO BE RELEASED WITHOUT THE APPROVAL OF THE ATOMIC INTERNATIONAL CORPORATION

REV	DATE	BY	CHK	DESCRIPTION
1				INTERMEDIATE SODIUM INDUCER PUMP (15/12) (DESIGN LAYOUT)
2				SCALE: FULL SIZE
3				DATE: 12/17/57
4				FR. 1 OF 3



- △ - AMBIENT OR GAS NODES
- - SODIUM NODES
- - BLADE OR VANE NODES

FIGURE 2

ISI PUMP
OVERALL THERMAL MODEL
-K. YUN, 6-19-78-






FIGURE 3
FLOW PATTERN FOR
SODIUM NODES

FIGURE 4




STAMP OUTPUT CRT
(ISIP)




ISIP NEW HARDWARE

FIGURE 6




WEIGHTED AVERAGE TEMPERATURE - TRANS 202

FIGURE 7




WEIGHTED AVERAGE TEMPERATURE - TRANS 203

FIGURE 8




WEIGHTED AVERAGE TEMPERATURE - TRANS 204

FIGURE 9



WEIGHTED AVERAGE TEMPERATURE - TRANS 207

WEIGHTED AVERAGE TEMPERATURE - TRANS 208



SHAFT DIAMETER

ISIP TRANS 208-REGULAR RUN

CASE NO. 1

TAP - 4H *0717783
03/21/79 032179 0001

FIGURE 10


FIGURE 11

ISIP TRANS 210-REGULAR RUN


TAP - 4H
03/16/79

*0717736
031579 0001

CASE NO. 1




WEIGHTED AVERAGE TEMPERATURE - TRANS 210



NODE NUMBER ACROSS INDUCER, TIE BOLT, AND INDUCER TUNNEL

FIGURE 13

ISIP TRANS 202-REGULAR RUN





Inaucer Node Number: T44-55

Tie Bolt Sodium Node Number: 936-916

Inducer Tunnel Node Number: T23-22


ISIP TRANS 202-REGULAR RUN




TEMPERATURE DIFFERENCES ACROSS THE INDUCER, TIE BOLT & INDUCER TUNNEL - TRANS 202D203

FIGURE 14


ISIP TRANS 204-REGULAR RUN



Inducer Node Number: T44-55
Tie Bolt Sodium Node Number: 936-916
Inducer Tunnel Node Number: T23-22





ISIP TRANS 207-REGULAR RUN



TEMPERATURE DIFFERENCES ACROSS THE INDUCER, TIE BOLT & INDUCER
TUNNEL - TRANS 204/207

FIGURE 15

ISIP TRANS 208-REGULAR RUN




Inducer Node Number: T44-55

Tie Bolt Sodium Node Number: 936-916


Inducer Tunnel Node Number: T23-22

ISIP TRANS 210-REGULAR RUN




TEMPERATURE DIFFERENCES ACROSS THE INDUCER, TIE BOLT & INDUCER TUNNEL - TRANS 208D210

FIGURE 16




ISIP-THERMAL EFFECT ON RADIAL CLEARANCE

FIGURE 17




REAR LABYRINTH

FIGURE 18




BEARING REGION



46 1240

K&E
20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.




46 1240

20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.


K&E

46 1240

K&E 30 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.



TEMPERATURE DIFFERENCE FOR THE BEARING REGION, REAR LABYRINTH & RADIAL CLEARANCE - TRANS 204




TEMPERATURE DIFFERENCE FOR THE BEARING REGION, REAR LABYRINTH & RADIAL CLEARANCE - TRANS 207


46 1240

K&E 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 1240

KE 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.





TEMPERATURE DIFFERENCE FOR THE BEARING REGION, REAR LABYRINTH & RADIAL CLEARANCE - TRANS 210

46 1240


K&E 20 X 20 TO THE INCH • 7 X 10 INCHES
KEUTZEL & ESSER CO. MADE IN U.S.A.




APPENDIX A

SUPPORTING CALCULATIONS

This appendix contains hand calculations made in support of setting up the TAP computer model of the ISIP. Included are calculations on conductances and capacitances of the blade and diffuser regions, sodium node volumes and capacitances, sodium zone flow areas, and hydraulic diameters, and sodium side heat transfer coefficients.

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	Page 540 PAGE NO. 41 OF
CHECKED BY: D.M.H.		REPORT NO. N266TI000-008
DATE: 6/2/78	ISIP - Inducer Blade	MODEL NO.

INDUCER BLADE — FORM FACTOR CALCULATIONS



From AI Drawing No. R0019603
Section A-A :

Average Radius (\bar{R}) of Inducer
Base :

$$\bar{R} = \frac{1}{2} (3.313 + 9.265) = 4.5''$$

- From Drawing No. R0019603 Section B-B :

$$\frac{\text{Blade length}}{\text{Circumference}} = \frac{15.5 + 6.7}{14.55} = 1.526$$


- Total Effective Blade Circumference = 1.526 x Inducer Circumference
- Projected Surface Area of 1 full Circumference of Blades (one face only)

$$= \pi (R_o^2 - \bar{R}^2) = \pi (9.265^2 - 4.5^2) = 206.06 \text{ in}^2$$

- However, we have 1.526 Blades, 2 faces per blade

$$A_{\text{(surface for convection)}} = 206.06 \frac{\text{in}^2}{\text{face}} \times 2 \frac{\text{face}}{\text{blade}} \times 1.526 \text{ blade} = 628.9 \text{ in}^2$$

- Blade Cross section




Base of Triangle = 1.4''

$$\therefore \bar{t} = .7''$$

$$\delta x = \frac{\bar{t}}{4} = \frac{.7}{4} = .175''$$

↑ for conduction in the direction normal to surface

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	Page 541
CHECKED BY: DMH		PAGE NO. 42 OF
DATE: 6/5/78	ISIP - Inducer Blade	REPORT NO. N266TI000-008
		MODEL NO.

INDUCER BLADE - continued

$$Y \left(\begin{array}{l} \text{Normal to blade} \\ \text{Surface:} \\ \text{To Convective} \\ \text{Surface} \end{array} \right) = K \frac{A_{\text{surf}}}{S_x} = K \frac{628.9 \text{ in}^2}{.175 \text{ in}} = 3594 K$$

Say


$$Y \left(\frac{\text{Btu}}{\text{sec} \cdot \text{F}} \right) = 3594 \times K \left(\frac{\text{inch}}{\text{inch}} \right) \left(\frac{\text{Btu}}{\text{sec} \cdot \text{F} \cdot \text{in}} \right)$$

VOLUME:


$$V = (n \text{ blades}) \left(A_{\text{surface}} \right) \left(\bar{L} \right) = 1.526 \times 206.06 \times .7 = 220.1 \text{ in}^3$$

one face
one blade

$$V_{\text{volume steel}} = 220.1 \text{ inch}^3$$

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	Page 542
CHECKED BY: DMH		PAGE NO. 43 OF
DATE: 10/16/78	ISIP BLADE TO INDUCER HUB	REPORT NO. N266TI000-008
		MODEL NO.

CONDUCTION Between INDUCER BLADE TO HUB
 (FROM NODE T800 TO HUB)




$$Y_T = A_T \cdot K_{SS} / h$$

Assume $h = 5.125 / 3 = 1.708$ "

$$A_T = 2\pi(4.5 + 1.708) \times 1.4 \times (2/3) \times 1.526 = 55.55$$

$$Y_T = 55.55 \times K_{SS} / 1.708 = 32.526 \cdot K_{SS}$$




$$Y = Y_T \times G$$


where, G is the ratio

(measured length of element / 13.4")


Y	C	Y
1837	1.2/13.4	2.913 K _{SS}
1838	2.6/13.4	6.317 K _{SS}
1839	2.6/13.4	"
1840	2.6/13.4	"
1841	3.4/13.4	8.253 K _{SS}

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	Page 543
CHECKED BY: DMH		PAGE NO. 44 OF
DATE: 6/5/78	ISIP - Impeller Blade	REPORT NO. N266TI000-008
		MODEL NO.

IMPELLER BLADE FORM FACTOR CALCULATIONS



Based on AI Drawing
No. R0019601




$$A_{\text{(one surface one circum)}} = 2\pi \bar{R} \bar{w} = 2\pi (12.69) (3.88) = 309.4 \text{ in}^2$$

For 2 blades, 2 fac/blade

$$A_{\text{(Total Convective Surface)}} = (2 \text{ blades}) (2 \frac{\text{Face}}{\text{blade}}) (309.4 \text{ in}^2) = 1237 \text{ in}^2$$

$$\bar{t} = .4 \text{ in} \quad \delta x = \frac{\bar{t}}{4} = .1''$$

$$\bar{H} = .5(4 + 3.76) = 3.88 \text{ in} \quad \delta_H = .97''$$

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	PAGE NO. 45 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 6/5/78	ISIP - Impeller Blade	MODEL NO.

$$Y \left(\begin{array}{l} \text{Normal to blade} \\ \text{surface} \\ \text{to convective} \\ \text{surface} \end{array} \right) = K \frac{A}{\delta x} = K \frac{1237}{.1} = \underline{12370 K_{ss}}$$

$$Y = K \frac{A}{\delta H} = K \frac{2 \times 2\pi \times 17.7 \times .4}{.97} = \underline{91.72 K_{ss}}$$


$\frac{\text{Btu}}{\text{Sec} \cdot \text{F}}$
 Blade to Base
 Total

Volume

$$V = (n \text{ blades}) (A_{\text{surface me face}}) (\bar{t}) = (2) (309.4) (.4) = 247.5 \text{ in}^3$$

$$V = 247.5 \text{ in}^3$$

blade
Impeller

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	Page 545
CHECKED BY: DMH		PAGE NO. 46 OF
DATE: 10/17/78	ISIP - Impeller Blade	REPORT NO. N266TI000-008
		MODEL NO.


CONDUCTION FROM Impeller Blade TO Hub

$$Y_T = 91.72 K_{SS}$$

For Y1842 ~ Y1846, $Y = C_1 \times Y_T$


For Y1847 ~ Y1851, $Y = C_2 \times Y_T$

Y	C_1 or C_2	Y
1842	2.4/12.5	17.61 K_{SS} ✓
1843	4.1/12.5	30.08 K_{SS} ✓
1844	3.1/12.5	22.75 K_{SS} ✓
1845	2.3/12.5	16.88 K_{SS} ✓
1846	1.6/12.5	11.74 K_{SS} ✓
1847	1.35/10.	12.38 K_{SS} ✓
1848	2.45/10.	22.47 K_{SS} ✓
1849	2.6/10.	23.85 K_{SS} ✓
1850	2.6/10.	23.85 K_{SS} ✓
1851	1.0/10.	9.172 K_{SS} ✓

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	Page 546
CHECKED BY: DMU		PAGE NO 47 OF
DATE: 6/5/78	ISIP - AI Diffuser Vane	REPORT NO. N266TI000-008
		MODEL NO.

AI Diffuser Vane Form Factor Calculation

Based on AI Drawing No. N266R000015



$$A_{\text{(Cross section one blade)}} = \left(\frac{3}{4}\right) (.2") (3") = .45 \text{ in}^2$$

$$A_{\text{(Cross section 11 blades)}} = (11) \times (.45 \text{ in}^2) = 4.95 \text{ in}^2$$

$$\bar{t} = \left(\frac{3}{4}\right) (t_{\text{max}}) = \left(\frac{3}{4}\right) (.2) = .15 \text{ in}$$


$$A_{\text{(convective surface)}} = n \times n \times (\text{Length}) (\text{height})$$

side blades

$$= 2 \times 11 \times 3" \times 2.75 = 181.5 \text{ in}^2$$

$$A_{\text{(Total convective surface)}} = 181.5 \text{ in}^2$$

$$\bar{t} = .15" \rightarrow \delta x = \frac{\bar{t}}{4} = \frac{.15}{4} = .0375"$$

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	PAGE NO. 48 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 6/5/78	ISIP - AI Diffuser Vane	MODEL NO.

Conduction Normal To Face of Blade :

$$Y = K \frac{A_{surf}}{\delta x} = K \frac{181.5}{.0375} = 4840 K$$

$Y_{\text{(Steel} \rightarrow \text{Na)}} = 4840 K \quad \left(\begin{array}{l} \text{Normal to} \\ \text{Surface} \end{array} \right)$ <p>(Btu/sec in °F)</p>

Conduction From Blade to Base :
(Parallel to Face of Blades)

$$Y_{\text{(Blade} \rightarrow \text{Base)}} = K \frac{A_{\text{cross Sect.}}}{\delta H} = K \frac{4.95}{.6875} = 7.2 K$$

(Btu/sec in °F)


$Y_{\text{Blade to Base}} = 7.2 K$ <p style="text-align: center;">↓ in. (Btu/in sec °F)</p>

$$Y_{1852 \sim 1855} = (7.2/4) K = 1.8 K \quad \checkmark$$

VOLUME :


$$V = (N \text{ blades}) \bar{E} \times L \times H = 11 \times .15 \times 3 \times 2.75 = 13.6125 \text{ in}^3$$

$V = 13.6125 \text{ in}^3$ <p>11 blades</p>

PREPARED BY: K. YUH	 Rockwell International Atomics International Division	Page 548
CHECKED BY: DMH		PAGE NO. 49 OF
DATE: 6/5/78	151P - Westinghouse Diffuser Vane	REPORT NO. N266TI000-008
		MODEL NO.

Westinghouse Diffuser Vane


Based on Drawing No. N266R000015



✓ H_2 : From Westinghouse Draw. 933 D757

4.3"

$$H_2 = (4.3^2 + 2.75^2)^{1/2} = 5.104"$$



$$L_2 = [(H_2 - H_1)^2 + L_1^2]^{1/2} = 10.27"$$

$$A_{\text{(Cross Section)}} = (11) \left[\frac{(10" + 10.27")}{2} \right] (.225") = 25.08 \text{ in}^2$$

11 blade
For Conduction Y

$$A_{\text{(Convective Surface)}} = (11) (2 \text{ sides blade}) \left[\frac{(2.75 + 5.104)}{2} \right] \times (10")$$


11 blade
Both side

$$= 863.9 \text{ in}^2$$

$$\bar{t} = .225" \rightarrow \delta_t = \frac{\bar{t}}{4} = \frac{.225}{4} = .05625"$$

$$\bar{H} = \frac{(2.75 + 5.104)}{2} = 3.927 \rightarrow \delta_H = \frac{\bar{H}}{4} = .98175"$$

$$\bar{L} = \frac{(10 + 10.27)}{2} = 10.135"$$

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	Page 549
CHECKED BY: DMU		PAGE NO. 50 OF
DATE: 6/6/78	ISIP-Westinghouse Diffuser Vane	REPORT NO. N266TI000-008
		MODEL NO.

Conduction Normal to Face of Blade :

$$Y_{\text{steel} \rightarrow \text{Na}} = K \frac{A_{\text{surf}}}{\delta t} = K \frac{863.9}{.05625} = 15360 K$$

Btu/sec. in. °F

$$Y_{\text{steel} \rightarrow \text{Na}} = 15360 K$$

Btu/sec. in. °F

Conduction from Blade To Base :
(Parallel to Face of Blades)

$$Y = K \frac{A_{\text{cross sect.}}}{\delta H} = K \frac{25.08}{.98175} = 25.55 K$$


$$Y_{\text{Blade} \rightarrow \text{Base}} = 25.55 K$$

Btu/sec. in. °F

VOLUME :

$$V = A_{\text{total surface area one side}} \times \bar{t} = (863.9/2) \times .225 = 97.19 \text{ in}^3$$

$$V_{11 \text{ blades}} = 97.19 \text{ in}^3$$


PREPARED BY: K. YUN	 Rockwell International Atomic International Division	PAGE NO. 51 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/17/78	ISIP - W. Diffuser Vane To Hub	MODEL NO.

CONDUCTION FROM WESTINGHOUSE DIFFUSER VANE
TO HUB.

$$Y_T = 25.55 K_{ss} \text{ (Btu/sec } ^\circ\text{F)}$$


$$Y = C \times Y_T$$

Y	C ₁ or C ₂	Y
1856	.6/10.	1.533 K _{ss}
1857	1.8/10	4.599 K _{ss}
1858	2.2/10	5.621 K _{ss}
1859	3.2/10	8.176 K _{ss}
1860	2.2/10	5.621 K _{ss}
1861	2.1/7.2	7.452 K _{ss}
1862	2.1/7.2	7.452 K _{ss}
1863	2.2/7.2	7.807 K _{ss}
1864	.8/7.2	2.839 K _{ss}

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	Page 551
CHECKED BY: DMH		PAGE NO. 52 OF
DATE: 6/5/78	151P - Turning Vane	REPORT NO. N266TI000-008
		MODEL NO.


Turning Vane Form Factor

measured
 $\frac{9.1}{\cos 25} = 10.0''$



Design & Dimension Based
 on W.E.C. Drawing No.
 933D763

$$D = \sqrt{\left(\frac{3.53}{\cos 10}\right)^2 + 2.44^2} = 4.33''$$



$$A_A = .5 (5.28 \times 0.931) = 2.458 \text{ in}^2$$

$$A_B = .5 (3.53 + 5.28) (10 - 0.931) = 39.949 \text{ in}^2$$


ST, $S = .5 (3.53 + 2.44 + 4.33) = 5.15$ Then

$$A_C = \sqrt{S(S - 3.53)(S - 2.44)(S - 4.33)} = 4.306 \text{ in}^2$$

$$A_S = A_A + A_B + A_C = 46.71 \text{ in}^2$$

A_{ST}
 (Total Convective Surface Area)

$$= (16 \text{ vanes}) (2 \text{ Face Blade}) (46.71) = 1494.8 \text{ in}^2$$

PREPARED BY: K. YUP	 Rockwell International Atomics International Division	Page 552
CHECKED BY: DMH		PAGE NO. 53 OF
DATE: 6/5/78	ISIP - Turning Vane	REPORT NO. N266TI000-008
		MODEL NO.

$$\bar{t} = 1.0 \text{ in}$$

$$\delta x = \frac{\bar{t}}{4} = .25''$$

$$Y \begin{matrix} \text{(Normal to Blade} \\ \text{Surface to} \\ \text{Convective Surface)} \end{matrix} = K \frac{A}{\delta x} = K \frac{1494.8}{.25} = \underline{5979. K_{ss}}$$

$$A \begin{matrix} \text{(Cross} \\ \text{Section)} \end{matrix} = .5(10 + 12.8) \times 1 \times 16 = 182.4 \text{ in}^2$$


$$\delta_H \approx .25(5.28 + 3.53) = 2.2 \text{ in}$$

$$Y \begin{matrix} \text{(Blade to} \\ \text{Base)} \end{matrix} = K \frac{A_c}{\delta_H} = K \frac{182.4}{2.2} = \underline{82.9 K_{ss}}$$

Volume

$$V = .5 A_{ST} \times 1.0 = \underline{747 \text{ in}^3}$$

Y	C ₁ or C ₂	Y
1865	.6 / 9.	5.527' K _{ss}
1866	3.6 / 9.	33.16' K _{ss}
1867	4.8 / 9.	44.21' K _{ss}
1868	5.5 / 9.9	46.05' K _{ss}
1869	4.4 / 9.9	36.84' K _{ss}

PREPARED BY: EMM	 Rockwell International Atomic International Division	Page 553
CHECKED BY: DMH		PAGE NO. 54 OF
DATE: 7/20/78	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

CALCULATION OF FLOW NODE VOLUMES and CAPACITANCES.

Assume ρC_p of Sodium at $T_{avg} = 750^\circ F$:

$$\rho = 53.467 \text{ lb}_m / \text{ft}^3$$

$$C_p = 0.3054 \text{ BTU} / \text{lb}_m \text{ } ^\circ F$$

$$\rho C_p = (53.467)(0.3054) = 16.3288 \text{ BTU} / \text{ft}^3 \text{ } ^\circ F$$

$$\frac{16.3288 \text{ BTU} / \text{ft}^3 \text{ } ^\circ F}{1728 \text{ in}^3 / \text{ft}^3} = 0.0094495 \checkmark$$

$\rho C_p = 0.0094495$ Na $\text{BTU} / \text{in}^3 \text{ } ^\circ F$ $\bar{T} = 750^\circ F$
--

$$C = m C_p = V(\rho C_p)$$

CAPACITANCE: SODIUM FLOW NODES.

$$C = (\rho C_p) V = 0.0094495 V$$

$\frac{\text{BTU}}{^\circ F} \quad \frac{\text{BTU}}{\text{in}^3 \text{ } ^\circ F} \quad \text{in}^3 \quad \text{in}^3$

where $V = \text{sodium volume, in}^3$

901 $V = \frac{\pi}{4} D^2 L = \frac{\pi}{4} (24)^2 (16) = 7238.23 \text{ in}^3$

$$V_{901} = 7238.2 \text{ in}^3$$

$$C_{901} = 68.40 \text{ BTU} / ^\circ F \checkmark$$

902 $V = \frac{\pi}{4} D^2 L = \frac{\pi}{4} (24)^2 (11) = 4976.28 \text{ in}^3$


$$V_{902} = 4976.3 \text{ in}^3$$

$$C_{902} = 47.02 \text{ BTU} / ^\circ F \checkmark$$


903 $V = \pi (R_o^2 - R_i^2) L_1 + \pi (R_o^2 - R_i^2) L_2$
 $= \pi (9.5^2 - 3.5^2) (7) + \pi (9.5^2 - 5.75^2) (5.5) = 2703.44 \text{ in}^3$

$$V_{903} = 2703.4 \text{ in}^3$$

$$C_{903} = 25.55 \text{ BTU} / ^\circ F \checkmark$$

PREPARED BY: <i>Σmm</i>	 Rockwell International Atomic International Division	PAGE NO. 55 OF
CHECKED BY: <i>DMH</i>		REPORT NO. N266TI000-008
DATE: <i>7/20/78</i>	ISIP	MODEL NO.

904




$$V_i = 2\pi \bar{R} (A)_{\text{CROSS}}$$

a: $\bar{R}_a \approx 9.5''$
 $A = 3.5 \times 7 = 24.5$
 $V_a = 2\pi (9.5)(24.5)$
 $V_a = 1462.91$

b: $\bar{R}_b \approx (20.6+13)(\frac{1}{2}) = 16.8$
 $A = 2.75 \times 7.5 = 20.625$
 $V_b = 2\pi (16.8)(20.625)$
 $V_b = 2177.12$

$V_{904} = 3639.5 \text{ in}^3$
 $C_{904} = 34.39 \text{ BTU/}^\circ\text{F}$ ✓

905




$$V_i = 2\pi \bar{R} (A)_{\text{CROSS}}$$

a: $\bar{R}_a = (29+20.5)(\frac{1}{2}) = 24.8$
 $A_a = 2.75 \times 9 = 24.75$
 $V_a = 2\pi (24.8)(24.75) = 3856.62$

b: $\bar{R}_b = \frac{31.8+28}{2} = 29.9$
 $A_b = 3.7 \times 3.5 = 12.95$
 $V_b = 2\pi (29.9)(12.95) = 2432.84$

$V_{905} = 6289.5 \text{ in}^3$
 $C_{905} = 59.43 \text{ BTU/}^\circ\text{F}$ ✓

906



$$V = \sum 2\pi \bar{R}_i (A_i)_{\text{CROSS}}$$


a: $\bar{R}_a \approx 29.7''$
 $A = 15.7 \text{ in}^2$
 $V_a = 2\pi (29.7)(15.7) = 2929.79 \text{ in}^3$

b: $\bar{R}_b = 23.8''$
 $A_b = 8 \times 4 = 32$
 $V_b = 2\pi (23.8)(32) = 4785.27 \text{ in}^3$

c: $\bar{R}_c = 17''$
 $A = 27 \text{ in}^2$
 $V_c = 2\pi (17)(27) = 2883.98 \text{ in}^3$

$V_{906} = 10599.0 \text{ in}^3$
 $C_{906} = 100.16 \frac{\text{BTU}}{^\circ\text{F}}$ ✓

907




$$V_i = 2\pi \bar{R}_i (A)_{\text{CROSS}} \text{ OR } \pi (R_o^2 - R_i^2) (L)$$

a: $\bar{R}_a = 16$
 $A_a = 5.5 \times 5.5 = 30.25$
 $V_a = 2\pi (16)(30.25) = 3041.06$
 $V_a = 3041.06 \text{ in}^3$


b: $\bar{R}_b = 17.5$
 $A_b = 10.2 \times 7 = 71.4$
 $V_b = 2\pi (17.5)(71.4) = 7850.84 \text{ in}^3$

$V_{907} = 10891.90$
 $V_{907} = 10891.9 \text{ in}^3$
 $C_{907} = 102.92 \frac{\text{BTU}}{^\circ\text{F}}$

3

PREPARED BY: <i>E M M</i>	 Rockwell International Atomics International Division	PAGE NO. 56 OF
CHECKED BY: <i>D M H</i>		REPORT NO. N266TI000-008
DATE: <i>7/20/78</i>	ISIP	MODEL NO.

908



$$V_a = \pi R^2 \Delta L = \pi (11^2)(11.5) = 4371.53 \checkmark$$

$$V_b = \pi (R_U^2 + R_L^2 + R_U R_L) (\Delta L) \left(\frac{1}{3}\right) = \pi (13^2 + 21.5^2 + 13 \times 21.5) \left(\frac{1}{3}\right) (9) = 8523.62$$

$$V_c = \pi R^2 \Delta L = \pi (21.5)^2 (4) = 5808.20$$

$$V_d = \pi (R_U^2 + R_L^2 + R_U R_L) (\Delta L) \left(\frac{1}{3}\right) = \pi (21.5^2 + 8^2 + 8 \times 21.5) (37.5) \left(\frac{1}{3}\right) = 27420.21$$

$$V_e = \pi R^2 \Delta L = \pi (8)^2 (3.5) = 703.72$$

$$V'_{908} = 46,827.89$$

Subtract Volume of Node 902:

$$V_{908} = V'_{908} - V_{902} = 46,827.9 - 4976.3 = 41,911.6 \text{ in}^3$$

$$V_{908} = 41,911.6 \text{ in}^3 \checkmark$$

$$C'_{908} = 396.05 \frac{\text{BTU}}{\text{°F}} \checkmark$$

909

$$V = \pi R^2 \Delta L = \pi (8)^2 (51) = 10,254.16$$


$$V_{909} = 10,254.2 \text{ in}^3 \checkmark$$

$$C_{909} = 96.90 \frac{\text{BTU}}{\text{°F}} \checkmark$$

910

DISCHARGE NODE

911



$$V_i = 2\pi \bar{R} A_{\text{cross}}$$

a: $\bar{R}_a = 11.5$
 $A_a = (4)(.6) = 2.4$

$$V_a = 2\pi (11.5)(2.4)$$

$$V_a = 173.42 \text{ in}^3$$

b: $\bar{R}_b = 14.5$
 $A_b = (6.5)(.55) = 5.525$

$$V_b = 2\pi (14.5)(5.525)$$

$$V_b = 503.36$$

$$V_{911} = 676.78$$

$$V_{911} = 676.8 \text{ in}^3$$

$$C_{911} = 6.40 \frac{\text{BTU}}{\text{°F}} \checkmark$$

912



$$V = 2\pi \bar{R} A_{\text{cross}}$$


$$\bar{R} = 14.5 \text{ inch}$$

$$A_{\text{cross}} = \frac{1}{2} (3)(2.5) = 10$$


$$V = 2\pi \bar{R} A = 2\pi (14.5)(10) = 911.06$$

$$V_{912} = 911.1 \text{ in}^3 \checkmark$$

$$C_{912} = 8.61 \frac{\text{BTU}}{\text{°F}} \checkmark$$

PREPARED BY: <i>E. M. M. P.</i>	 Rockwell International Atomic International Division	PAGE NO. <i>57</i> OF
CHECKED BY: <i>D.M.H.</i>		REPORT NO. <i>N266TI000-008</i>
DATE: <i>7/20/78</i>	ISIP	MODEL NO.

913



$$V_i = \pi(R_o^2 - R_i^2)(L)$$

$$V_a = \pi(10.6^2 - 10^2)(1.5) = 58.25$$


$$V_b = \pi(11^2 - 9.9^2)(1.5) = 108.34$$

$$V_{913} = 166.59$$

$$V_{913} = 166.6 \text{ in}^3$$

$$C_{913} = 1.57 \frac{\text{BTU}}{^\circ\text{F}}$$

914



$$V_a = 2\pi \bar{R} A$$

$$\bar{R} = \frac{1}{2}(29+13) = 18.5$$

$$A = 13 \times 5.6 = 72.8$$

$$V_a = 2\pi(18.5)(72.8)$$

$$V_a = 8462.19$$

$$V_b = 2\pi \bar{R} A$$

$$\bar{R} = 25.25$$

$$A = \frac{1}{2}(3^2) = 4.5$$

$$V_b = 2\pi(25.25)(4.5) = 713.93$$

$$V_{914} = 9176.12$$

$$V_{914} = 9176.1 \text{ in}^3$$

$$C_{914} = 86.71 \frac{\text{BTU}}{^\circ\text{F}}$$

915

$$V = \pi R^2 L = \pi(1.25)^2(6.5)$$

$$V_{915} = 31.91 \text{ in}^3$$

$$V_{915} = 31.9 \text{ in}^3$$

$$C_{915} = 0.30 \frac{\text{BTU}}{^\circ\text{F}}$$

916

$$V = \pi R^2 L = \pi(1.25)^2(12)$$

$$V_{916} = 58.90 \text{ in}^3$$

$$V_{916} = 58.9 \text{ in}^3$$

$$C_{916} = 0.56 \frac{\text{BTU}}{^\circ\text{F}}$$

917

$$V = \pi R^2 L = \pi(1.25)^2(31.6)$$

$$V = 155.12 \text{ in}^3$$

$$V_{917} = 155.1 \text{ in}^3$$

$$C_{917} = 1.47 \frac{\text{BTU}}{^\circ\text{F}}$$

918

$$V = 2\pi \bar{R} A_{\text{cross}}$$


$$\bar{R} \approx 6''$$

$$A_{\text{cross}} = (3.5)(2) - \frac{1}{2}(1.5)(1.5) = 5.875$$


$$V = 2\pi(6)(5.875) = 221.48 \text{ in}^3$$

$$V_{918} = 221.5 \text{ in}^3$$

$$C_{918} = 2.09 \frac{\text{BTU}}{^\circ\text{F}}$$

PREPARED BY: <i>Elmer</i>	 Rockwell International Atomics International Division	PAGE NO. 58 OF
CHECKED BY: <i>D.M.H.</i>		REPORT NO. N266TI000-008
DATE: 7/20/78	ISIP	MODEL NO.


919



$V_i = 2\pi \bar{R} A_{\text{cross}} \text{ OR } \pi(R_o^2 - R_i^2)L$
 a: $\bar{R}_a = \frac{1}{2}(13.75 + 6) = 9.875$
 $A_a = (5)(13.75 - 6) + (1.5)(1) = 40.25$
 $V_a = 2\pi(9.875)(40.25) = 2497.37 \text{ in}^3$
 b: $\bar{R}_b = 15$
 $A_b = \frac{1}{2}(2)(2) = 2.0$
 $V_b = 2\pi(15)(2) = 188.50 \text{ in}^3$
 c: $R_o = 16.0$ $R_i = 13.75$ $L = 7$
 $V_c = \pi(16^2 - 13.75^2)(7) = 1472.03 \text{ in}^3$
 d: $R_o = 14.3$ $R_i = 12.5$ $L = 1.2$
 $V = \pi(14.3^2 - 12.5^2)(1.2) = 181.86 \text{ in}^3$
 $\Sigma V = 4339.76$

$V_{919} = 4339.8 \text{ in}^3$
 $C_{919} = 41.04 \frac{\text{BTU}}{\text{°F}}$


920



a: $\bar{R} = \frac{1}{2}(16 + 29.5) = 22.75$
 $A = (29.5 - 16)(16.5) = 222.75$
 $V_a = 2\pi \bar{R} A = 2\pi(22.75)(222.75) = 31,840.43 \text{ in}^3$
 b: $\bar{R} \approx 13$
 $A \approx 21 \text{ in}^2$
 $V_b = 2\pi \bar{R} A = 2\pi(13)(21) = 1715.31$
 c: $\bar{R} \approx 24$
 $A \approx \frac{1}{2}(5)(12) = 30$
 $V_c = 2\pi(24)(30) = 4523.89$
 $\Sigma V = 38079.64$


$V_{920} = 38079.6 \text{ in}^3$
 $C_{920} = 359.84 \frac{\text{BTU}}{\text{°F}}$

921




a: $R_o = 38$ $R_i = 31.8$ $L = 25$
 $V_a = \pi(R_o^2 - R_i^2)L = \pi(38^2 - 31.8^2)(25) = 33988.89 \text{ in}^3$
 b: $R_o = 38$ $R_i = 37.25$ $L = 26.5$
 $V_b = \pi(38^2 - 37.25^2)(26.5) = 7698.55$
 $\Sigma V = 38687.44 \text{ in}^3$

$V_{921} = 38687.4 \text{ in}^3$
 $C_{921} = 365.58 \frac{\text{BTU}}{\text{°F}}$

PREPARED BY: Emm1	 Rockwell International Atomics International Division	PAGE NO 59 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 7/20/78	ISIP	MODEL NO.

922



a: $R_0 = 35.75$ $R_1 = 35$ $L = 5.3$

$V_a = \pi (R_0^2 - R_1^2)(L) = \pi (35.75^2 - 35^2)(5.3) = 883.51 \text{ in}^3$

b: $R_0 = 38$ $R_1 = 34.65$ $L = 34.75$

$V_b = \pi (38^2 - 34.65^2)(34.75) = 26569.61 \text{ in}^3$

$\Sigma V = 27453.12 \text{ in}^3$

$V_{922} = 27453.1 \text{ in}^3$

$C_{922} = 259.42 \frac{\text{BTU}}{^\circ\text{F}}$

923



a: $R_0 = 38$ $R_1 = 34.65$ $L = 44$

$V_a = \pi (38^2 - 34.65^2)(44) = 33642.09 \text{ in}^3$

b: $\bar{R}_b \approx 35.5$

$A \approx 10 \times 3.5 = 35$


$V_b = 2\pi \bar{R} A = 2\pi (35.5)(35) = 7806.86 \text{ in}^3$

$\Sigma V = 41,448.95 \text{ in}^3$

$V_{923} = 41,448.9 \text{ in}^3$

$C_{923} = 391.67 \frac{\text{BTU}}{^\circ\text{F}}$

924



a: $\bar{R}_a = 33$

$A = \frac{1}{2}(10)(3.2) = 16$

$V_a = 2\pi \bar{R} A = 2\pi (33)(16) = 3317.52 \text{ in}^3$

b: $R_0 = 32$ $R_1 = 28$ $L = 10.8$

$V_b = \pi (32^2 - 28^2)(10.8) = 8143.01 \text{ in}^3$

c: $R_0 = 28$ $R_1 = 24$ $L = 12.5$

$V_c = \pi (28^2 - 24^2)(12.5) = 8168.14 \text{ in}^3$

d: $R_0 = 24$ $R_1 = 19$ $L = 14.3$

$V_d = \pi (24^2 - 19^2)(14.3) = 9658.83$

e: $R_0 = 19$ $R_1 = 16$ $L = 12.7$

$V_e = \pi (19^2 - 16^2)(12.7) = 4189.31$

f: $\bar{R}_f = 13.5$


$A = (4)(3) = 12$

$V_f = 2\pi \bar{R} A = 2\pi (13.5)(12) = 1017.88$


$\Sigma V = 34,494.69$

$V_{924} = 34,494.7 \text{ in}^3$

$C_{924} = 325.96 \frac{\text{BTU}}{^\circ\text{F}}$

PREPARED BY: <i>EM: 9/77</i>	 Rockwell International Atomic International Division	PAGE NO. 60 OF
CHECKED BY: <i>DMH</i>		REPORT NO. N266TI000-008
DATE: <i>7/20/78</i>	ISIP	MODEL NO.

925



a: $\bar{R}_a \approx 28$

$A = \frac{1}{2} (12 \times 9) = 54$

$V_a = 2\pi \bar{R}_a A = 2\pi (28)(54) = 9500.18$

b. $R_o = 32.5 \quad R_i = 19.5 \quad L = 4.5$

$V_b = \pi (R_o^2 - R_i^2) L = \pi (32.5^2 - 19.5^2)(4.5) = 9556.72$

c. $R_o = 32.5 \quad \bar{R}_i = 20.5 \quad L = 8$

$V_c = \pi (32.5^2 - 20.5^2)(8) = 15984.42$

d. $R_o = 32.5 \quad R_i = 22.5 \quad L = 15.25$

$V_d = \pi (32.5^2 - 22.5^2)(15.25) = 26350.11$

$\Sigma V = 61391.43$

$V_{925} = 61391.43 \text{ in}^3$

$C_{925} = 580.12 \frac{\text{BTU}}{\text{OF}}$

926



a: $\bar{R} \approx 25.6$

$A = \frac{1}{4} (9)(9) = 40.5$

$V_a = 2\pi \bar{R} A = 2\pi (25.6)(40.5) = 6514.41$

b: $R_o = 33 \quad R_i = 30.25 \quad L = 1.5$

$V_b = \pi (R_o^2 - R_i^2) L = \pi (33^2 - 30.25^2)(1.5) = 819.66$

$\Sigma V = 7334.07$

$V_{926} = 7334.1 \text{ in}^3$

$C_{926} = 69.30 \frac{\text{BTU}}{\text{OF}}$

927

$V = \pi (R_o^2 - R_i^2) L$

$R_o = 21 \quad R_i = 13 \quad L = 2.1$


$V = \pi (21^2 - 13^2)(2.1) = 1794.48$


$V_{927} = 1794.5 \text{ in}^3$

$C_{927} = 16.96 \frac{\text{BTU}}{\text{OF}}$

928

NO NODE


PREPARED BY: <i>E. R. G. M.</i>	 Rockwell International Atomics International Division	PAGE NO. <i>61</i> OF
CHECKED BY: <i>DMH</i>		REPORT NO. <i>N266TI000-008</i>
DATE: <i>7/20/78</i>	ISIP	MODEL NO.

929  a: $R_0 = 22.25$ $R_1 = 13$ $L = 10.9$
 $V_a = \pi (R_0^2 - R_1^2) (L) = \pi (22.25^2 - 13^2) (10.9) = 11165.48$
 b: $\bar{R} = 11.7$ $A = (3)(9) = 27$
 $V_b = 2\pi \bar{R} A = 2\pi (11.7)(27) = 1984.85$
 $\Sigma V = 13150.33$ $V_{929} = 13150.3 \text{ in}^3$
 $C_{929} = 124.26 \frac{\text{BTU}}{^\circ\text{F}}$ ✓

930 $\bar{R} = 7.5$ $\Delta R = 0.32$ $L = 9.5$
 $V = 2\pi \bar{R} \Delta R L = 2\pi (7.5)(.32)(9.5) = 143.26$
 $V_{930} = 143.3 \text{ in}^3$
 $C_{930} = 1.35 \frac{\text{BTU}}{^\circ\text{F}}$ ✓


931 $\bar{R} = 5.85$ $\Delta R = 0.2$ $L = 10$
 $V = 2\pi \bar{R} \Delta R L = 2\pi (5.85)(0.2)(10) = 73.51 \text{ in}^3$
 $V_{931} = 73.51 \text{ in}^3$
 $C_{931} = 0.69 \frac{\text{BTU}}{^\circ\text{F}}$ ✓

932 4 - 2.5" DIA - 6" Long Flow Paths
 $V = \left[\pi (2.5^2) / 4 \right] \times 6 \times 4 = 117.81 \text{ in}^3$
 $C_{932} = 1.1132 \text{ BTU}/^\circ\text{F}$ ✓

PREPARED BY: <i>Emm</i>	 Rockwell International Atomic International Division	PAGE NO. 62 OF
CHECKED BY: <i>DMH</i>		REPORT NO. N266TI000-008
DATE: 7/20/78	ISIP	MODEL NO.

933 $R_o = 18''$ $R_i = 10''$ $\Delta L = 1.0''$
 $V = \pi (R_o^2 - R_i^2) (\Delta L) = \pi (18^2 - 10^2) (1) = 703.72$
 $V_{933} = 703.72 \text{ in}^3$
 $C_{933} = 6.65 \frac{\text{BTU}}{\text{OF}} \checkmark$


934




a: $R_o = 8$ $R_i = 4$ $L \approx 5.1$
 $V_a = \pi (R_o^2 - R_i^2) (L) = \pi (8^2 - 4^2) (5.1) = 769.06 \checkmark$
 b: $\bar{R} = 9.0$
 $A = \frac{1}{2} (3)(4) = 6$
 $V_b = 2\pi \bar{R} A = 2\pi (9)(6) = 339.29$
 c: $R_o = 8.25$ $R_i = 6.5$ $L = 4.5$
 $V_c = \pi (R_o^2 - R_i^2) (L) = \pi (8.25^2 - 6.5^2) (4.5) = 364.92$
 $\Sigma V = 1473.27$
 $V_{934} = 1473.3 \text{ in}^3$
 $C_{934} = 13.92 \frac{\text{BTU}}{\text{OF}} \checkmark$


935 12 - 1.25" ID - 12.5" Long Flow Path
 $V = \frac{\pi}{4} (1.25^2) \times 12.5 \times 12 = 184.08 \text{ in}^3$
 $C_{935} = 1.739 \checkmark$

936




a: $\bar{R} = 3.5$ $\Delta R = 0.3$ $L = 2$
 $V_a = 2\pi \bar{R} \Delta R L = 2\pi (3.5)(.3)(2) = 13.19 \text{ in}^3$
 b: $\bar{R} = 3$ $A = \frac{1}{2} (1)(5) = 2.5$
 $V_b = 2\pi \bar{R} A = 2\pi (3)(2.5) = 47.12$
 c: $R_o = 2.5$ $R_i = 1.75$ $L = 2$
 $V_c = \pi (R_o^2 - R_i^2) (L) = \pi (2.5^2 - 1.75^2) (2) = 20.03$
 $\Sigma V = 80.35 \text{ in}^3$
 $V_{936} = 80.3 \text{ in}^3$
 $C_{936} = 0.76 \frac{\text{BTU}}{\text{OF}} \checkmark$

PREPARED BY: EMM	 Rockwell International Atomic International Division	PAGE NO. 63 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 7/20/72		MODEL NO.
937	$\bar{R} = 4$ $A = (0.6)(3) = 1.8$ $V = 2\pi \bar{R} A = 2\pi (4)(1.8) = 45.24 \text{ in}^3$	$V_{937} = 45.24 \text{ in}^3$ $C_{937} = 0.43 \frac{\text{BTU}}{\text{°F}}$ ✓
938	$R_0 = 15.3$ $R_i = 14.0''$ $L = 40.5$ $V = \pi (R_0^2 - R_i^2)(L) = \pi (15.3^2 - 14.0^2)(40.5) = 4846.36$	$V_{938} = 4846.4 \text{ in}^3$ $C_{938} = 45.80 \frac{\text{BTU}}{\text{°F}}$ ✓
939	$R_0 = 15.3$ $R_i = 14.0$ $L = 43.5$ $V = \pi (15.3^2 - 14.0^2)(43.5) = 5205.35$	$V_{939} = 5205.4 \text{ in}^3$ $C_{939} = 49.19 \frac{\text{BTU}}{\text{°F}}$ ✓
940	$R_0 = 38$ $R_i = 31.8$ $L = (77.5 - 43.5) = 34$ $V = \pi (38^2 - 31.8^2)(34) = 46224.89 \text{ in}^3$	$V_{940} = 46224.9 \text{ in}^3$ $C_{940} = 436.80 \frac{\text{BTU}}{\text{°F}}$ ✓
941	$R_0 = 38$ $R_i = 31.8$ $L = 43.5$ $V = \pi (38^2 - 31.8^2)(43.5) = 59140.67$	$V_{941} = 59140.7 \text{ in}^3$ $C_{941} = 558.85 \frac{\text{BTU}}{\text{°F}}$ ✓

PREPARED BY: <i>E. W. ...</i>	 Rockwell International Atomics International Division	PAGE NO. 64 OF
CHECKED BY: <i>DMH</i>		REPORT NO. N266TI000-008
DATE: 7/20/73		MODEL NO.

942



a: Upper: $R_0 = 32.6$ $R_i = 21.3$ $A_u = \pi(R_0^2 - R_i^2) = (32.6^2 - 21.3^2)\pi$
 $A_u = 1913.45$ ✓
 Lower: $R_0 = 32.6$ $R_i = 9$ $A_L = \pi(R_0^2 - R_i^2) = \pi(32.6^2 - 9^2)$
 $A_L = 3084.29$ ✓
 $L = 33.5$

$$V_a = \frac{L}{3} (A_u + A_L + \sqrt{A_u A_L}) = \frac{33.5}{3} (1913.45 + 3084.29 + \sqrt{(1913.45)(3084.29)})$$

$$V_a = 82,935.59 \text{ in}^3 \checkmark$$

b: $R_0 = 32.6$ $R_i = 9$ $L = 10.5$

$$V_b = \pi(R_0^2 - R_i^2)(L) = \pi(32.6^2 - 9^2)(10.5) = 32,385.05 \text{ in}^3$$

c: Ellipsoid. (half)

$$V_c = \frac{1}{2} \frac{4\pi}{3} abc = \frac{4\pi}{2 \cdot 3} (32.6)(32.6)(15) = 33,387.59$$


$$\Sigma V' = 82,935.59 + 32,385.05 + 33,387.59 = 148,708.23 \text{ in}^3$$

Subtract volume 901 $V_{901} = 7238.2$

$$V_{942} = 148,708.23 - 7238.2 = 141,470.0$$

$$V_{942} = 141,470.0 \text{ in}^3$$

$$C_{942} = 1336.83 \frac{\text{BTU}}{\text{cf}}$$

PREPARED BY:	 Rockwell International Atomic International Division	PAGE NO. 65 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE:		MODEL NO.

Y1823 → Y1827

$$A_{\text{SURFACE TOTAL}} = \pi \bar{D}_{\text{PIPE}} \left(\frac{\pi}{2} \bar{R}_{\text{ARC}} \right) = \pi (25 \text{ in}) \left(\frac{\pi}{2} 35 \right) = 4318 \text{ in}^2$$

90° ARC

$$\Delta X (\text{Thickness}) = 1.0 \text{ inch}$$

Y1823 (T719 → T724)

$$\phi (\text{Central angle}) = 27^\circ$$

$$A_{\text{surf}} = \frac{27}{90} (4318) = 1295 \text{ in}^2 \quad \left(\frac{A}{\Delta X} \right) = \frac{1295}{1} = 1295 \text{ in} \checkmark$$

1739

Y1824 (T720 → T725)

$$\phi (\text{Central Angle}) = 21^\circ$$

$$A_{\text{surf}} = \frac{21}{90} (4318) = 1008 \text{ in}^2 \quad \left(\frac{A}{\Delta X} \right) = 1008 \text{ in} \checkmark$$

1740

Y1825 (T721 → T726)

$$\phi (\text{Central Angle}) = 21^\circ$$

$$A_{\text{surf}} = \frac{21}{90} (4318) = 1008 \text{ in}^2 \quad \left(\frac{A}{\Delta X} \right) = 1008 \text{ in} \checkmark$$

1741

Y1826 (T722 → T727)

$$\phi (\text{Central Angle}) = 16^\circ$$

$$A_{\text{surf}} = \frac{16}{90} (4318) = 768 \text{ in}^2 \quad \left(\frac{A}{\Delta X} \right) = 768 \text{ in} \checkmark$$


1742

Y1827 (T723 → T728)

$$\phi = 8^\circ$$


$$A_{\text{surf}} = \frac{8}{90} (4318) = 384 \text{ in}^2 \quad \left(\frac{A}{\Delta X} \right) = 384 \text{ in} \checkmark$$

1743


PREPARED BY: K. YUN	 Rockwell International Atomic International Division	PAGE NO. 66 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/16/78	ISIP	MODEL NO.

CALCULATION OF FORM Factors

DUMMY	Y	CONV. - E = Surface Area COND. - E = Ac/L	
EB01	1801	CONV.	$\pi \times 1.25 \times 12 \times 2.3 = 108.4 \text{ in}^2$
EB02	1802	"	" 4.5 = 212.1 "
EB03	1803	"	" 4.1 = 193.2 "
EB04	1804	"	" 2.1 = 98.96 "
EB05	1805	"	" .3 = 14.14 "
EB06		"	$24 \times 2(2+1) \times 2.1 = 302.4 \text{ "}$
EB07		"	" 2.1 = 302.4 "
EB08		"	$\pi \times 2.5 \times 4 \times 0.5 = 15.708 \text{ in}^2$
EB09		"	" 1.7 = 53.407 "
EB10		"	" 2.2 = 69.11 "
EB11		"	" 1.5 = 47.12 "
EB12		"	" 0.5 = 15.708 "
EB13		(see calculation of Y1823 ~ Y1827)	= 1295 in ²
EB14			= 1008 "
EB15			= 1008 "
EB16			= 768 "
EB17			= 384 "
EB18			= 1295 "
EB19			= 1008 "
EB20			= 1008 "
EB21			= 768 "

PREPARED BY: K. YUW	 Rockwell International Atomics International Division	PAGE NO. 67 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/16/78	151P	MODEL NO.

EB22		= 384 in ²
EB23		= 1295 in
EB24		= 1008 "
EB25		= 1008 "
EB26		= 768 "
EB27		= 384 "
EB28	$\pi(38^2 - 31.8^2)$	= 1360 in ²
EB29		= 1360 in ²
EB30	$\pi(15.3^2 - 14^2)$	= 119.7 in ²
EB31		= 119.7 in ²

PREPARED BY:	 Rockwell International Atomics International Division	PAGE NO. 68 OF
CHECKED BY:		REPORT NO. N266TI000-008
DATE:	ISIP	MODEL NO.

TRANSIENTS:

#	T °F	\bar{T}	
201	750 → 600	675	} deleted by T.I.B.-3-5-79
202	750 → 600	675	
203	500 → 650	575	
204	850 → 650	750	$\bar{T} \approx 793$
205	700 → 850	775	} deleted by T.I.B.-3-5-79
206	1050 → 720	885	
207	1050 → 720	885	} Modified, Temperature reduce by 100°F. T.I.B.-3-5-79
208	1050 → 825	938	
210	1050 → 900	975	

ASSUME $\bar{T}_{Na} \approx 800^\circ F$

SODIUM PROPERTIES @ 800°F (Golden & Tokar)

$$k = 40.62 \text{ BTU/hr ft }^\circ F$$


$$\mu = 0.6437 \text{ lb}_m/\text{hr ft}$$

$$\rho = 53.053 \text{ lb}_m/\text{ft}^3$$

$$z = \frac{\mu}{\rho} = \frac{.6437}{53.053} = 0.01213 \frac{\text{ft}^2}{\text{hr}}$$

$$z = \frac{.6437}{53.053} \times \frac{1}{3600} = 3.37032 \times 10^{-6} \frac{\text{ft}^2}{\text{sec}}$$

2

PREPARED BY:	 Rockwell International Atomics International Division	PAGE NO. 69 OF
CHECKED BY:		REPORT NO. N266TI000-008
DATE:	ISIP	MODEL NO.

$$Q \frac{\text{ft}^3}{\text{sec}} = \text{GPM} \frac{\text{gal}}{\text{min}} \times \frac{\text{min}}{60 \text{ sec}} \times \frac{2.31}{1728} \frac{\text{ft}^3}{\text{gal}} = .002228$$

$$Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = \frac{\text{GPM}}{448.83}$$

$$V \frac{\text{ft}}{\text{sec}} = \frac{Q \frac{\text{ft}^3}{\text{sec}}}{A \text{ ft}^2} = \frac{Q \text{ FPS}}{A \text{ ft}^2}$$

$$Re = \frac{V D_H}{\nu} = \frac{V_{\text{FPS}} D_{H \text{ FT}}}{3.37 \times 10^{-6}} = 2.9671 \times 10^5 V D$$

$$Re \cong 3.0 \times 10^5 \frac{V \text{ FPS}}{\text{FT}} D_H \text{ FT}$$

$$Nu = 7.0 + \frac{1}{40} (Re Pr)^{0.8}$$

$\underbrace{Re}_{\text{Pr}} \uparrow .00482$

$$h = Nu \frac{k}{D_H}$$

$$h \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}} = \frac{40.62}{D_H \text{ FT}} \times Nu$$

FLOW NODE	FULL (100%) FLOW RATE (GPM)
900	14,500
901	14,660
902	14,660
903	14,644
904	16,001
905	14,841
906	14,841
907	14,841
908	14,510
909	14,510
910	14,500
911	648
912	74
913	34
914	-
915	50
916	54
917	50
918	150
919	60
920	150
921	150
922	150
923	10
924	10
925	331
926	331
927	131
928	-
929	200
930	200
931	100
932	90
933	-
934	678
935	678
936	-
937	4

FLOW NODE	FULL (100%) FLOW RATE (GPM)
938	0
939	0
940	0
941	0



RED = $\frac{\text{Flow (gpm)}}{14500 \text{ gpm}}$

N266ER000-001
Page 570





FIG. 1. WEMD RECIRCULATION FLOWS
FROM REFERENCE 4

PREPARED BY: <u>EIR/M</u>	 Rockwell International Atomic International Division	PAGE NO. <u>72</u> OF
CHECKED BY: <u>DAM</u>		REPORT NO. <u>H266TI000-008</u>
DATE: <u>7/ 73</u>	ISIP	MODEL NO.

NODE 901, 902 Tbl 24

FULL FLOW = 14,660 gpm

FLOW CONDITION:
PIPE FLOW.

$$\begin{cases} R = 12'' \text{ inch} \\ D = 24'' \text{ inch} \end{cases}$$

④ $A = \frac{\pi}{4} D^2 = \frac{\pi}{4} (24)^2 (\frac{1}{144}) = 3.1416 \text{ ft}^2$

⑤ $D_H = 2 \times (R) = 2.0 \text{ ft}$

FULL FLOW = 14660 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (14660) = 32.663 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{32.663}{3.1416} = 10.4 \frac{\text{ft}}{\text{sec}}$


② $Re \cong 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (10.3968) (2) = 6,238 \times 10^6$

① $Pe = Re Pr = (6.238 \times 10^6) (.00482) = 3.007 \times 10^4$

① $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (3.007 \times 10^4)^{0.8} = 102.59$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{2} \right) (102.59) = (20.31) (102.59) = 2083.6 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V Ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14660	10.40	6.24 $\times 10^6$	30070	102.6	2084
82.759 %	12132.4	8.60	5.10 $\times 10^6$	24883	59.16	1811
0	0	0	0	0	7	142

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 572 ₇₃
CHECKED BY: <u>DMH</u>		PAGE NO. _____ OF _____
DATE: <u>7/ /78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO. _____

NODE 905

FULL FLOW = 14841 gpm

FLOW CONDITION:
 Radial →

$$\begin{cases} \bar{R} \approx 25'' \text{ inch} \\ H \approx 3'' \text{ inch} \end{cases}$$

① $A = 2\pi \bar{R} H = (2)(\pi)(25)(3) \frac{1}{144} = 3.2725 \text{ ft}^2$

16 vanes. $C = 2\pi \bar{R}$
 Vanes about 10" circum
 $D_v = \frac{4\pi \times 10}{20} = 0.385 \text{ ft}$

② $D_H = 2 \times () = 0.385 \text{ ft}$

FULL FLOW = 14841 gpm

③ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(14841) = 33.06575 \frac{\text{ft}^3}{\text{sec}}$

④ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ CFS}}{A \text{ ft}^2} = \frac{33.06575}{3.2725} = 10.104 \frac{\text{ft}}{\text{sec}}$


⑤ $Re \approx 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (10.104)(.385) = 1.166 \times 10^6$

⑥ $Pe = Re Pr = (1.166 \times 10^6)(.00482) = 5619.5$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (5619.5)^{0.8} = 31.986$

⑧ $h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.385} \right) (31.986) = (105.612) (31.986) = 3378.1 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14841	10.104	1.166×10^6	5620	31.99	3378
82.759 %	12282	8.36	9.65×10^5	4651	28.48	3007
0	0	0	0	0	7	739

PREPARED BY: <i>EMM</i>	 Rockwell International Atomics International Division	PAGE NO. 74 OF
CHECKED BY: <i>DMH</i>		REPORT NO. N266TI000-008
DATE: <i>7/78</i>	ISIP	MODEL NO.

NODE 906

FULL FLOW = 14841 gpm

FLOW CONDITION:
Radial

$$\begin{cases} \bar{R} \approx 24'' \text{ inch} \\ H \approx 4'' \text{ inch} \end{cases}$$

⑥ $A = 2\pi \bar{R} H = 2\pi (24)(4) \frac{1}{144} = 4.1887 \text{ ft}^2$ 16 vanes: $C = 2\pi \bar{R} = 150.79$

⑤ $D_H = 2 \times (\quad) = 0.468 \text{ ft}$

$\Delta C = 9.42''$
 $D_H = \frac{0(0)(9.42)}{2(13.42)} \frac{1}{12} = .468 \text{ ft}$

FULL FLOW = 14841 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(14841) = 33.0657 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{33.0657}{4.1887} = 7.894 \frac{\text{ft}}{\text{sec}}$


② $Re \approx 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (7.894)(0.468) = 1.1082 \times 10^6$

① $Pe = Re Pr = (1.1082 \times 10^6)(.00482) = 5341.5$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (5341.5)^{0.8} = 30.99$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.468} \right) (30.99) = (86.803)(30.99) = 2690.2 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V Ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14841	7.894	1.108×10^6	5342	30.99	2690
82.759 %	12282	6.533	9.17×10^5	4421	27.62	2398
0	0	0	0	0	7	607.6

PREPARED BY: <i>EMM</i>	 Rockwell International Atomic International Division	PAGE NO. 75 OF
CHECKED BY: <i>DMA</i>		REPORT NO. N266TI000-008
DATE: <i>7/ 78</i>	ISIP	MODEL NO.

NODE 907

To 10 27

FULL FLOW = 14841 gpm

FLOW CONDITION:
AXIAL

$$\left\{ \begin{array}{l} R_o \approx 19 \text{ inch} \\ R_i = 13 \text{ inch} \end{array} \right.$$

① $A = \pi (R_o^2 - R_i^2) = \pi (19^2 - 13^2) \left(\frac{1}{144}\right) = 4.189 \text{ ft}^2$

② $D_H = 2 \times (R_o - R_i) = 2(19 - 13) \left(\frac{1}{12}\right) = 1.0 \text{ ft}$

FULL FLOW = 14841 gpm

③ $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002222 \text{ GPM} = 0.002222(14841) = 33.0657 \frac{\text{ft}^3}{\text{SEC}}$

④ $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{33.0657}{4.189} = 7.894 \frac{\text{ft}}{\text{SEC}}$

⑤ $Re \approx 3 \times 10^5 \left(\frac{V}{\text{ft}}\right) (D_H) = 3 \times 10^5 (7.894) (1.0) = 2.368 \times 10^6$


⑥ $Pe = Re Pr = (2.368 \times 10^6) (0.00482) = 11414.5$

⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.5} = 7 + \frac{1}{40} (11414.5)^{0.5} = 51.05$

$h = NU \left(\frac{k}{D_H}\right) = \left(\frac{40.62}{1}\right) (51.05) = (40.62) (51.05) = 2073.5 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

FULL FLOW

%FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14841	7.90	2.37×10^6	11,415	51.05	2073
82.759%	12282	6.53	1.96×10^6	9447	44.86	1822
0	0	0	0	0	7	284.3

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 575
CHECKED BY: <u>DMH</u>		PAGE NO. 76 OF
DATE: <u>7/1/78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 908

71 28

FULL FLOW = 14510 gpm

FLOW CONDITION:

AXIAL: ↓

$R_o = 22$
MAX
 $R_o = 8$
MIN
 $R_o \approx 16''$

$\left\{ \begin{array}{l} R = \text{inch} \\ = \text{inch} \end{array} \right.$

⑥ $A = \pi \bar{R}_o^2 = \pi (16)^2 (\frac{1}{144}) = 5.585 \text{ ft}^2$

⑤ $D_H = 2 \times () = D_H = \frac{32}{12} = 2.66 \text{ ft}$

FULL FLOW = 14510 gpm

④ $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002228 \times \text{GPM} = 0.002228 (14510) = 32.328 \frac{\text{ft}^3}{\text{SEC}}$

③ $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{32.328}{5.585} = 5.788 \frac{\text{ft}}{\text{SEC}}$


② $Re \approx 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (5.788) (2.66) = 4.631 \times 10^6$

① $Pe = Re Pr = (4.631 \times 10^6) (.00482) = 22320 \checkmark$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (22320)^{0.8} = 82.32$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{2.667} \right) (82.32) = (15.2325) (82.32) = 1253.9 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14510	5.79	4.63×10^6	22320	82.32	1254
82.759 %	12008	4.79	3.83×10^6	18472	71.74	1093
0	0	0	0	0	7	106.6

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>77</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/73</u>	ISIP	MODEL NO.

NODE 909

FULL FLOW = 14510 gpm

FLOW CONDITION:

$$\left\{ \begin{array}{l} R_o = 8 \text{ inch} \\ = \text{inch} \end{array} \right.$$

④ $A = \pi R_o^2 = \pi (8')^2 = 1.396 \text{ ft}^2$

⑤ $D_H = 2 \times (8) = \frac{16}{12} = 1.333 \text{ ft}$

FULL FLOW = 14510 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(14510) = 32.328 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{32.328}{1.396} = 23.15 \frac{\text{ft}}{\text{sec}}$


② $Re \cong 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (23.15) (1.333) = 9.2614 \times 10^6$

① $Pe = Re Pr = (9.2614 \times 10^6) (.00482) = 44639.8$

⑥ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (44639.8)^{0.8} = 138.13$

FULL FLOW $h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{1.333} \right) (138.13) = (30.465) (138.13) = 4208.3 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$


% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	14510	23.15	9.26×10^6	44640	138.1	4208
82.75%	12000	19.16	7.66×10^6	36943	119.7	3647
0	0	0	0	0	7	213.3

PREPARED BY: <u>SRM</u>	 Rockwell International Atomics International Division	Page 577
CHECKED BY: <u>DMH</u>		PAGE NO. 78 OF
DATE: <u>7/ 73</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 912 -6 30

FULL FLOW = 74 gpm

FLOW CONDITION:

Radial 

$$\begin{cases} \bar{R} = 14 \text{ inch} \\ H \approx 2 \text{ inch} \end{cases}$$

⑥ $A = 2\pi \bar{R} H = 2\pi(14)(2) \frac{1}{144} = 1.222 \text{ ft}^2$

⑤ $D_H = 2 \times (H) = \frac{2(2)}{12} = 0.333 \text{ ft}$

FULL FLOW = 74 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(74) = 0.165 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.1649}{1.222} = 0.135 \frac{\text{ft}}{\text{sec}}$


② $Re \approx 3 \times 10^5 \left(\frac{V}{\text{ft}} \right) \left(\frac{D_H}{\text{ft}} \right) = 3 \times 10^5 (0.135) (0.333) = 13,495$

① $Pe = Re Pr = (13,495) (0.00482) = 65.05$

⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.5} = 7 + \frac{1}{40} (65.05)^{0.8} = 7.706$

FULL FLOW $h = NU \left(\frac{k}{D_H} \right) = \left(\frac{20.1}{0.333} \right) (7.706) = (121.86) (7.706) = 939.0 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	74	0.135	13,495	65.05	7.706	939
82.759 %	61.2	0.112	11,168	53.83	7.606	927
0	0	0	0	0	7	853.

PREPARED BY: <u>EIMM</u>	 Rockwell International Atomic International Division	Page 578
CHECKED BY: <u>JMM</u>		PAGE NO 79 OF
DATE: <u>7/78</u>	ISIP	REPORT NO N266TI000-008
		MODEL NO

NODE 913

FULL FLOW = 34 gpm

FLOW CONDITION:
AXIAL

$$\left\{ \begin{array}{l} \bar{R} \approx 10.5 \text{ inch} \\ \Delta R \approx 0.5 \text{ inch} \\ \text{avg} \end{array} \right.$$

⑥ $A = 2\pi \bar{R} \Delta R = 2\pi (10.5)(0.5) \frac{1}{144} = 0.229 \text{ ft}^2$

⑤ $D_H = 2 \times (\Delta R) = \frac{1}{12} = .0833 \text{ ft}$

FULL FLOW = 34 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 * \text{GPM} = 0.002228(34) = 0.0758 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{CFS}}}{A_{\text{ft}^2}} = \frac{0.0758}{.229} = 0.331 \frac{\text{ft}}{\text{sec}}$


② $Re \approx 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (.331) (.0833) = 8267$

① $Pe = Re Pr = (8267)(.00482) = 39.85$

⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (39.85)^{0.8} = 7.477$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.0833} \right) (7.477) = (487.14) (7.477) = 3644.5 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

%FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	34	0.331	2267	39.85	7.48	3644
82.75%	28.1	0.273	6842	32.98	7.41	3612
0	0	0	0	0	7	3412

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	Page 579
CHECKED BY: <u>DMP</u>		PAGE NO. 80 of
DATE: <u>7/73</u>	ISIP	REPORT NO N266TI000-008
		MODEL NO

NODE 915

FULL FLOW = 50 gpm

FLOW CONDITION:
 AXIAL. ↑

$$\left\{ \begin{array}{l} R = 1.5 \text{ inch} \\ = \text{inch} \end{array} \right.$$

⑥ $A = \pi R^2 = \pi (1.5)^2 \left(\frac{1}{144}\right) = .0491 \text{ ft}^2$

⑤ $D_H = 2 \times (R) = \frac{3}{12} = 0.25 \text{ ft}$

FULL FLOW = 50 gpm

④ $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002228 \times \text{GPM} = 0.002228 (50) = 0.1114 \frac{\text{ft}^3}{\text{SEC}}$

③ $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ CFS}}{A \text{ FT}^2} = \frac{0.1114}{.0491} = 2.27 \frac{\text{ft}}{\text{SEC}}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FT}}\right) (D_H) = 3 \times 10^5 (2.27) (.25) = 170207$


① $Pe = Re Pr = (170207) (.00482) = 820.4$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (820.4)^{0.8} = 12.36$

$h = Nu \left(\frac{k}{D_H}\right) = \left(\frac{20.1}{.25}\right) (12.36) = (162.48) (12.36) = 2008.2 \frac{\text{BTU}}{\text{hr FT}^2 \text{ } ^\circ\text{F}}$

FULL FLOW

%FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr FT}^2 \text{ } ^\circ\text{F}}$
100 %	50	2.27	170,207	820.4	12.36	2008
82.759 %	41.38	1.88	140,861	672.9	11.61	1886
0	0	0	0	0	7	1137

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	Page 580
CHECKED BY: <u>DMM</u>		PAGE NO. 81 OF
DATE: <u>7/1/78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 916

FULL FLOW = 54 gpm

FLOW CONDITION:

$$\left\{ \begin{array}{l} R = 1.5 \text{ inch} \\ = \text{inch} \end{array} \right.$$

④ $A = \pi R^2 = \pi (1.5)^2 \left(\frac{1}{144}\right) = .0491 \text{ ft}^2$

⑤ $D_H = 2 \times (R) = \frac{3}{12} = .25 \text{ ft}$

FULL FLOW = 54 gpm

⑥ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (54) = 0.1203 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{CFS}}}{A_{\text{ft}^2}} = \frac{.1203}{.0491} = 2.45 \frac{\text{ft}}{\text{sec}}$


② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}}\right) \left(\frac{D_H}{\text{FT}}\right) = 3 \times 10^5 (2.45) (.25) = 183,823 \checkmark$

① $Pe = Re Pr = (183,823) (.00482) = 886 \checkmark$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (886)^{0.8} = 12.7$

$h = Nu \left(\frac{k}{D_H}\right) = \left(\frac{40.62}{.25}\right) (12.7) = (162.48) (12.7) = 2063.5 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	54	2.45	183,820	886	12.7	2064
82.759 %	44.69	2.03	152,130	733.26	11.9	1933
0	0	0	0	0	7	1137

PREPARED BY: <u>ERM</u>	 Rockwell International Atomic International Division	Page 581
CHECKED BY: <u>DMH</u>		PAGE NO 82 OF
DATE: <u>7/ 78</u>	ISIP	REPORT NO N266TI000-008
		MODEL NO

NODE 917

FULL FLOW = 50 gpm

FLOW CONDITION:

$$\left\{ \begin{array}{l} R = 1.5 \text{ inch} \\ = \text{inch} \end{array} \right.$$

④ $A = \pi R^2 = \pi (1.5)^2 \left(\frac{1}{144}\right) = 0.0491 \text{ ft}^2$

⑤ $D_H = 2 \times (R) = \frac{2}{12} = 0.25'$

FULL FLOW = 50 gpm

① $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (50) = 0.1114 \frac{\text{ft}^3}{\text{sec}}$

② $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.1114}{0.0491} = 2.27 \frac{\text{ft}}{\text{sec}}$


③ $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}}\right) \left(\frac{D_H}{\text{FT}}\right) = 3 \times 10^5 (2.27) (0.25) = 170207$

④ $Pe = Re Pr = (170207) (.00482) = 820.4$

⑤ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (820.4)^{0.8} = 12.36$

⑥ $h = Nu \left(\frac{k}{D_H}\right) = \left(\frac{40.62}{0.25}\right) (12.36) = (162.48) (12.36) = 2008.2 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

%FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	50	2.27	107,207	820.4	12.36	2008
82.759%	41.38	1.88	140,861	678.9	11.61	1886
0	0	0	0	0	7	1137

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 582
CHECKED BY: <u>DMM</u>		PAGE NO. 83 OF
DATE: <u>7/ 73</u>	ISIP	REPORT NO N266TI000-008
		MODEL NO.

NODE 918

FULL FLOW = 150 gpm

FLOW CONDITION:

1" Diagonal →

$$\begin{cases} \bar{R} = 6 \text{ inch} \\ H = 2 \text{ inch} \end{cases}$$

⑥ $A = 2\pi \bar{R} H = 2\pi(6)(2) \frac{100 \text{ gpm}}{10.4} = 0.5236 \text{ ft}^2$

⑤ $D_H = 2 \times (H) = \frac{2(2)}{12} = \frac{1}{3} = .333 \text{ ft} \checkmark$

$\frac{.331}{.728} = .45$

$\frac{.4}{.6}$

$\frac{.331}{.728} = .45$

FULL FLOW = 150 gpm

④ $Q \frac{ft^3}{sec} = 0.002228 - GPM = 0.002228(150) = 0.3342 \frac{ft^3}{sec}$

③ $V \frac{ft}{sec} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.3342}{.5236} = 0.638 \frac{ft}{sec}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{ft} \right) (D_H) = 3 \times 10^5 (0.638) (.333) = 63827 \checkmark$

① $Pe = Re Pr = (63827)(.00482) = 307.65 \checkmark$


⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.3} = 7 + \frac{1}{40} (307.65)^{0.3} = 9.445 \checkmark$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{20.1}{.333} \right) (9.445) = (121.86) (9.445) = 1151 \frac{BTU}{hr \text{ ft}^2 \text{ } ^\circ F}$

FULL FLOW

%FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{BTU}{hr \text{ ft}^2 \text{ } ^\circ F}$
100 %	150	.64	63,820	307.6	9.45	1151
82.759 %	124.1	.528	52,823	254.6	9.102	1109
0	0	0	0	0	7	853

(14,500)
(12,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	Page 583
CHECKED BY: <u>D174</u>		PAGE NO. 84 OF
DATE: <u>7/ /78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 919

FULL FLOW = 60 gpm

FLOW CONDITION:
 Radial

$\left\{ \begin{array}{l} R = 11 \text{ inch} \\ H = 5 \text{ inch} \end{array} \right.$

⑥ $A \cong 2\pi \bar{R} H = 2\pi(11)(5) \frac{1}{144} = 2.40 \text{ ft}^2$

⑤ $D_H = 2 \times (11) = \frac{22}{12} = 1.8333 \text{ ft}$

$\frac{231}{7.48 \text{ gal}}$

FULL FLOW = 60 gpm

④ $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002228 \times \text{GPM} = 0.002228(60) = .1337 \frac{\text{ft}^3}{\text{SEC}}$

$\frac{4}{6}$ ③ $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.1337}{2.4} = 0.0557 \frac{\text{ft}}{\text{SEC}}$

$\frac{32.174 \text{ FPS}}{1.48 \text{ ft/s}}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (0.0557)(1.8333) = 30637$


① $Pe = Re Pr = (30637)(.00482) = 147.67$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (147.67)^{0.8} = 8.36$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{1.8333} \right) (8.36) = (22.156) (8.36) = 185.2 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	60	0.056	30640	147.7	8.36	185
82.759 %	49.66	0.046	25355	122.2	8.17	181
0	0	0	0	0	7	155


(14500)
(12,000)

PREPARED BY: <u>SM</u>	 Rockwell International Atomic International Division	Page 584
CHECKED BY: <u>DMH</u>		PAGE NO. 85 OF
DATE: <u>7/78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO

NODE 920

FULL FLOW = 150 gpm

FLOW CONDITION:



$$\begin{cases} \bar{R} = 22 \text{ inch} \\ H = 18 \text{ inch} \end{cases}$$

⑥ $A = 2\pi \bar{R} H = 2\pi (22)(18) \frac{1}{144} = 17.28 \text{ Ft}^2$

⑤ $D_H = 2 \times (H) = \frac{2 \times 18}{12} = 2.0$

FULL FLOW = 150 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (150) = .3342 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ CFS}}{A \text{ FT}^2} = \frac{.3342}{17.28} = 0.0193 \frac{\text{ft}}{\text{sec}} \quad (.23 \text{ in/sec})$


② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (.0193) (2) = 11605$

① $Pe = Re Pr = (11605)(.00482) = 55.94$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (55.94)^{0.8} = 7.625$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{2} \right) (7.625) = (20.31) (7.625) = 154.9 \frac{\text{BTU}}{\text{hr Ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V Ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr Ft}^2 \text{ } ^\circ\text{F}}$
100 %	150	0.019	11600	55.94	7.625	155
82.759 %	124.1	0.016	9604	46.29	7.50	153
0	0	0	0	0	7	142.2

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	Page 585
CHECKED BY: <u>JMH</u>		PAGE NO. 86 OF
DATE: <u>7/78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 921 a

FULL FLOW = 150 gpm

FLOW CONDITION:

→ Radial

$$\begin{cases} \bar{R} = 34.5 \text{ inch} \\ H \approx 12 \text{ inch} \end{cases}$$

④ $A = 2\pi \bar{R} H = 2\pi(34.5)(12)(\frac{1}{144}) = 18.06 \text{ ft}^2$

⑤ $D_H = 2 \times (H) = 2 \times \frac{12}{12} = 2.0 \text{ ft}$

FULL FLOW = 150 gpm

① $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(150) = .3342 \frac{\text{ft}^3}{\text{sec}}$

② $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{.3342}{18.064} = .0185 \frac{\text{ft}}{\text{sec}}$


③ $Re \approx 3 \times 10^5 \left(\frac{V}{\text{ft}} \right) \left(\frac{D_H}{\text{ft}} \right) = 3 \times 10^5 (.0185)(2) = 11,100$

④ $Pe = Re Pr = (11,100)(.00482) = 53.5$

⑤ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (53.5)^{0.8} = 7.6035$

FULL FLOW $h = NU \left(\frac{k}{D_H} \right) = \left(\frac{20.62}{2} \right) (7.6) = (20.31)(7.6) = 154.4 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	150	.0185	11,100	53.5	7.6	154
82.759 %	124.1	.0153	9187	44.3	7.52	153
0	0	0	0	0	7	142.17

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 586
CHECKED BY: <u>DIM</u>		PAGE NO. 87 OF
DATE: <u>7/1/78</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 921b

FULL FLOW = 150 gpm

FLOW CONDITION:
↓ axial

$$\begin{cases} R_o = 38 \text{ inch} \\ R_i = 36.5 \text{ inch} \end{cases}$$

⑥ $A = \pi (R_o^2 - R_i^2) = \pi (38^2 - 36.5^2) \left(\frac{1}{144}\right) = 2.438 \text{ ft}^2$ ✓

⑤ $D_H = 2 \times (\Delta R) = \frac{2(1.5)}{12} = 0.25 \text{ ft}$ ✓

FULL FLOW = 150 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(150) = .3342 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{.3342}{2.438} = 0.137 \frac{\text{ft}}{\text{sec}}$


② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}}\right) \left(\frac{D_H}{\text{FT}}\right) = 3 \times 10^5 (0.137)(.25) = 10281$ ✓

① $Pe = Re Pr = (10281)(.00482) = 49.55$ ✓

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (49.55)^{0.8} = 7.57$

$h = Nu \left(\frac{k}{D_H}\right) = \left(\frac{40.62}{.25}\right) (7.57) = (162.48) (7.57) = 1229.6 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$ ✓

% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	150	0.137	10,281	49.55	7.57	1230
82.759 %	124.1	0.113	8508	41.01	7.49	1217
0	0	0	0	0	7	1137

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 587
CHECKED BY: <u>DMH</u>		PAGE NO. 88 OF
DATE: <u>7/73</u>	ISIP	REPORT NO N266TI000-008
		MODEL NO.

NODE 922

FULL FLOW = 150 gpm

FLOW CONDITION:
Axial ↓

$$\begin{cases} R_o = 38 \text{ inch} \\ R_i = 34.5 \text{ inch} \end{cases}$$

④ $A = \pi (R_o^2 - R_i^2) = \pi (38^2 - 34.5^2) \frac{1}{144} = 5.536 \text{ ft}^2$

⑤ $D_H = 2 \times (R_o - R_i) = 2 (38 - 34.5) \frac{1}{2} = 0.5833 \text{ ft}$

FULL FLOW = 150 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (150) = .3342 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{cfs}}}{A_{\text{ft}^2}} = \frac{.3342}{5.536} = 0.0604 \frac{\text{ft}}{\text{sec}} \quad (.72 \text{ in/sec})$


② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (.0604) (.5833) = 10565$

① $Pe = Re Pr = (10565) (.00482) = 50.92$

② $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (50.92)^{0.8} = 7.58$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.5833} \right) (7.58) = (69.6343) (7.58) = 527.8 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

%FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	150	0.06	10,570	50.9	7.6	528
82.759 %	124.1	0.05	8743	42.14	7.5	522
0	0	0	0	0	7	487.4

PREPARED BY: <u>ETM</u>	 Rockwell International Atomics International Division	Page 588
CHECKED BY: <u>DMH</u>		PAGE NO. 89 OF
DATE: <u>7/ 73</u>	ISIP	REPORT NO. N266TI000-008
		MODEL NO.

NODE 923

FULL FLOW = 10 gpm

FLOW CONDITION:
 AXIAL ↑

$$\begin{cases} R_o = 38 \text{ inch} \\ R_i = 34.5 \text{ inch} \end{cases}$$

⑥ $A = \pi (R_o^2 - R_i^2) \frac{1}{144} = \pi (38^2 - 34.5^2) \frac{1}{144} = 5.536 \text{ ft}^2$

⑤ $D_H = 2 \times (R_o - R_i) = 2 (38 - 34.5) \frac{1}{12} = 0.5833 \text{ ft}$

FULL FLOW = 10 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (10) = .0223 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{.0223}{5.536} = .00402 \frac{\text{ft}}{\text{sec}}$
 (0.0483 in/sec)
 (2.90 in/min)
 (14.5 ft/hr)


② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{ft}} \right) (D_H) = 3 \times 10^5 (.00402) (.5833) = 704$

① $Pe = Re Pr = (704) (.00482) = 3.395$

⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (3.395)^{0.8} = 7.0665$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{49.63}{.5833} \right) (7.0665) = (85.1) (7.0665) = 601 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	10	.00402	704	3.4	7.067	492
82.759 %	8.28	.00333	583	2.81	7.057	491
0	0	0	0	0	7	487

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	Page 589
CHECKED BY: <u>DMH</u>		PAGE NO. <u>90</u> OF
DATE: <u>7/ /78</u>	ISIP	REPORT NO. N266TI000-005
		MODEL NO.

NODE 924

FULL FLOW = 10 gpm

FLOW CONDITION:
diagonal ↗

$$\begin{cases} R \approx 24 \text{ inch} \\ \text{width} \approx 12 \text{ inch} \end{cases}$$

⑥ $A = 2\pi R w = 2\pi (24)(12) \frac{1}{144} = 12.566 \text{ ft}^2$

⑤ $D_H = 2 \times (12") = 2.0 \text{ ft}$

FULL FLOW = 10 gpm

④ $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002228 \times \text{GPM} = 0.002228(10) = .02228 \frac{\text{ft}^3}{\text{SEC}}$

③ $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ CFS}}{A \text{ FT}^2} = \frac{.02228}{12.566} = .00177 \frac{\text{ft}}{\text{SEC}}$

0.021 in/sec
1.28 in/min
6.35 ft/hr


② $Re \approx 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (.00177) (2) = 1064$

① $Pe = Re Pr = (1063.8) (.00482) = 5.127$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (5.127)^{0.8} = 7.092$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{2} \right) (7.092) = (20.31) (7.092) = 144.0 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

%FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	10	.0018	1064	5.13	7.10	144
82.759 %	8.28	.0015	880	4.24	7.08	144
0	0	0	0	0	7	142

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>91</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 925A

FULL FLOW = 331 gpm

FLOW CONDITION:
AXIAL

$$\begin{cases} R_o = 28.5 \text{ inch} \\ R_i = 20.5 \text{ inch} \end{cases}$$

④ $A = \pi(R_o^2 - R_i^2) = \pi(28.5^2 - 20.5^2) \frac{1}{144} = 8.552 \text{ FT}^2$

⑤ $D_H = 2 \times (R_o - R_i) = \frac{2(8)}{12} = \frac{16}{12} = 1.333 \text{ FT}$

FULL FLOW = 331 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(331) = 0.7375 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.7375}{8.552} = .0862 \frac{\text{ft}}{\text{sec}}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (.0862)(1.333) = 34,493$

① $Pe = Re Pr = (34493)(.00482) = 166.26$

⑥ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (166.26)^{0.8} = 8.495$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{1.333} \right) (8.495) = (30.465) (8.495) = 258.8 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$


% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	331	.086	34 500	166.3	8.5	259
82.759 %	273.9	.071	28,550	137.6	8.285	252
0	0	0	0	0	7	213

$\frac{231}{72860}$

$\frac{4}{6}$

$3 \times 10^5 (3)(5)$

(14500),000)

PREPARED BY: K. YUN	 Rockwell International Atomic International Division	PAGE NO. 92 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/13/78	ISIP	MODEL NO.

NODE 925 B

Full Flow = 331 gpm

FLOW CONDITION :
AXIAL

24 - 2" x 1" x - SLOTS

$$A = 24 \times 2 \times 1 = 48 \text{ in}^2 = .333 \text{ Ft}^2$$

$$D_H = 4 \times A_c / P = 4 \times 2 \times 1 / 2 \times (2+1) = 1.333'' = .111'$$

$$Q = 0.002228 \times \text{GPM} = 0.002228 \times 331 = 0.7375 \text{ ft}^3/\text{sec}$$

$$V = Q_{\text{CFD}} / A_{\text{FT}^2} = 0.7375 / .333 = 2.212 \text{ Ft}/\text{sec}$$

$$Re \approx 3 \times 10^5 (V)(D_H) = 3 \times 10^5 (2.212)(.111) = 7.3674 \times 10^4$$

$$Pe = Re Pr = (73674)(0.00482) = 355.1$$

$$Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (355.1)^{0.8} = 9.743$$

$$h_{\text{full flow}} = Nu \left(\frac{K}{D_H} \right) = 9.743 \frac{40.62}{.111} = 3562 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F}$$

% Flow

h Btu/hr ft² °F

100 %


3562 .

82.759

3421 .

0.0

2559 .

PREPARED BY: <u>SKM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>93</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/73</u>	ISIP	MODEL NO.

NODE 926

FULL FLOW = 331 gpm

FLOW CONDITION:

Radial

$$\left\{ \begin{array}{l} \bar{R} \approx 26 \text{ inch} \\ H \approx 5.5 \text{ inch} \end{array} \right.$$

④ $A = 2\pi(\bar{R})(H) = 2\pi(26)(5.5)\left(\frac{1}{144}\right) = 6.2396 \text{ ft}^2$

⑤ $D_H = 2 \times \left(\frac{H}{12} \right) = \frac{2(5.5)}{12} = 0.9166 \text{ ft}$

FULL FLOW = 331 gpm

① $Q \frac{\text{ft}^3}{\text{SEC}} = 0.002228 \text{ - GPM} = 0.002228(331) = 0.7375 \frac{\text{ft}^3}{\text{SEC}}$

② $V \frac{\text{ft}}{\text{SEC}} = \frac{Q \text{ CFS}}{A \text{ FT}^2} = \frac{0.7375}{6.24} = 0.118 \frac{\text{ft}}{\text{SEC}}$

③ $Re \approx 3 \times 10^5 \left(\frac{V}{\text{ft}} \right) \left(\frac{D_H}{\text{ft}} \right) = 3 \times 10^5 (0.118)(0.9166) = 32503$


④ $Pe = Re Pr = (32503)(0.00482) = 156.66$

⑤ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (156.66)^{0.8} = 8.425$

FULL FLOW $h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{20.32}{0.9166} \right) (8.425) = (44.313) (8.425) = 373.3 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V. ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	331	0.118	32500	156.7	8.425	373
82.759 %	273.4	0.098	26900	129.65	8.225	364
0	0	0	0	0	7	310

(14500)
(7,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	PAGE NO. <u>94</u> OF
CHECKED BY: <u>DMA</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 927

FULL FLOW = 131 gpm

FLOW CONDITION:
AXIAL ↓

$$\begin{cases} \bar{R} = 18 \text{ inch} \\ \Delta R \approx 5 \text{ inch} \end{cases}$$

① $A = 2\pi \bar{R} \Delta R = 2\pi (18)(5) \frac{1}{144} = 3.93 \text{ ft}^2$

② $D_H = 2 \times (\Delta R) = \frac{2(5)}{12} = \frac{10}{12} = 0.833 \text{ ft}$

FULL FLOW = 131 gpm

③ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(131) = 0.292 \frac{\text{ft}^3}{\text{sec}}$

④ $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ CFS}}{A \text{ ft}^2} = \frac{0.292}{3.93} = 0.0743 \frac{\text{ft}}{\text{sec}}$

⑤ $Re \approx 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (0.0743) (0.833) = 18581$


⑥ $Pe = Re Pr = (18581) (.00482) = 89.56$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (89.56)^{0.8} = 7.911$

⑧ $h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.833} \right) (7.911) = (48.744) (7.911) = 385.6 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$


% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	131	.074	18580	89.6	7.91	386
82.759 %	108.1	.0615	15,377	74.12	7.783	379
0	0	0	0	0	7	341

(14500)
(7,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. 95 OF
CHECKED BY: <u>DMH</u>		REPORT NO. N266TI000-008
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 929 - 146

FULL FLOW = 200 gpm

FLOW CONDITION:

 Axial

$$\begin{cases} \bar{R} = 16.5 \text{ inch} \\ H = 11 \text{ inch} \end{cases}$$

④ $A = 2\pi \bar{R} H = 2\pi (16.5)(11) \frac{1}{144} = 7.919$

⑤ $D_H = 2 \times (H) = \frac{22}{12} = 1.833 \text{ ft}$

FULL FLOW = 200 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(200) = 0.4456 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{CFS}}}{A_{\text{ft}^2}} = \frac{0.4456}{7.919} = 0.0563 \frac{\text{ft}}{\text{sec}}$

② $Re \cong 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (0.0563)(1.833) = 30947$

① $Pe = Re Pr = (30947)(0.00482) = 149.16$

① $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (149.16)^{0.8} = 8.37$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{1.833} \right) (8.37) = (22.156) (8.37) = 185.5 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$


% FLOW	FLOW gpm	V ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	200	.056	30950	149.2	8.4	185
82.75%	165.5	.0466	25610	123.4	8.18	181
0	0	0	0	0	7	155

$\frac{231}{728 \text{ } 60}$

$\frac{4}{6}$

$3 \times 10^5 (3)(5)$

(14500)
(2,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>96</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 930

FULL FLOW = 200 gpm

FLOW CONDITION:

Assume uniformly distributed axially.
(actually, flow can be fully spread out)

$$\left\{ \begin{array}{l} \bar{R} = 7.5 \text{ inch} \\ H = 10 \text{ inch} \end{array} \right.$$

$\Delta R \approx 0.5$

④ $A = 2\pi \bar{R} H = 2\pi (7.5)(10) \frac{1}{144} = 3.27 \text{ ft}^2$

⑤ $D_H = 2 \times (\Delta R) = 2 \left(\frac{.5}{12} \right) = .0833$
actually, this would be the diameter for

FULL FLOW = 200 gpm

① $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228 (200) = 0.4456 \frac{\text{ft}^3}{\text{sec}}$

② $V \frac{\text{ft}}{\text{sec}} = \frac{Q \text{ cfs}}{A \text{ ft}^2} = \frac{0.4456}{3.27} = 0.1362 \frac{\text{ft}}{\text{sec}}$
(actual, average)

③ $Re \approx 3 \times 10^5 \left(\frac{V}{\text{ft}} \right) \left(\frac{D_H}{\text{ft}} \right) = 3 \times 10^5 (.1362) (.0833) = 3404$

④ $Pe = Re Pr = (3404) (.00482) = 16.408$

⑤ $NU = 7 + \frac{1}{40} (Pe)^{0.5} = 7 + \frac{1}{40} (16.408)^{0.5} = 7.234$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{20.6}{.0833} \right) (7.234) = (487.44) (7.234) = 3526 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V ft/sec	Re	Pe	NU	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	200			16.41	7.234	3526
82.759 %	165.5			13.58	7.201	3510
0	0	0	0	0	7	3412

= U/N/V


$\frac{.31}{728 \text{ } 60}$

$\frac{4}{6}$

$3 \times 10^5 (3)(.5)$

(14500)

(2,000)

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	PAGE NO. 97 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/3/78	ISIP	MODEL NO.

NODE 932

Flow Condition : Radial flow through 4 - 2.5" Dia -
6" Long flow path.

$$A = [\pi (2.5^2) / 4] \times 4 = 19.635 \text{ in}^2 = .13635 \text{ ft}^2$$

$$D_H = D = 2.5" = .2083 \text{ ft}$$

Full Flow = Assume 2/3 of (100+50) GPM = 100 GPM

$$Q \text{ ft}^3/\text{sec} = 0.002228 (100) = 0.2228 \text{ ft}^3/\text{sec}$$

$$V \text{ ft}/\text{sec} = Q \text{ cfs} / A \text{ ft}^2 = 0.2228 / .13635 = 1.634 \text{ ft}/\text{sec}$$


$$Re \approx 3 \times 10^5 (V)(D_H) = 3 \times 10^5 (1.634)(.2083) = 1.021 \times 10^5$$

$$Pe = Re \cdot Pr = (1.021 \times 10^5)(.00482) = 492.17$$

$$Nu = 7 + \frac{1}{40} (Pe)^{.8} = 10.561$$

$$h_{\text{full flow}} = Nu \left(\frac{K}{D_H} \right) = (10.561) \left(\frac{40.62}{.2083} \right) = 2060 \text{ Btu}/\text{hr-ft}^2\text{-}^\circ\text{F}$$

	h
100 %	2060
82.759 %	1962
0	1365

PREPARED BY: V. YUN	 Rockwell International Atomic International Division	PAGE NO. 98 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/3/78	131P	MODEL NO.

NODE 935

Full Flow = 678 GPM

Flow Condition :

Axial flow through 12 - 1.25" DIA - 12.5" LONG
flow paths.

$$A = [\pi (1.25^2) / 4] \times 12 = 14.726 \text{ in}^2 = 0.10226 \text{ ft}^2$$

$$D_H = D = 1.25" = 0.10417 \text{ ft}$$

Full Flow = 678 GPM

$$Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 (678) = 1.5106 \text{ ft}^3/\text{sec}$$

$$V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{CFS}}}{A \text{ ft}^2} = \frac{1.5106}{0.10226} = 14.772 \text{ ft/sec}$$

$$Re \approx 3 \times 10^5 (V)(D_H) = 3 \times 10^5 (14.772)(0.10417) = 4.616 \times 10^5$$


$$Pe = Re \cdot Pr = (4.616 \times 10^5)(.00482) = 2225$$

$$Nu = 7 + \frac{1}{40} (Pe)^{.8} = 18.907$$

$$h_{\text{full flow}} = Nu \left(\frac{K}{D_H} \right) = (18.907) \left(\frac{40.62}{.10417} \right) = 7373 \frac{\text{Btu}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$$

	h
100 %	7373.
82.759 %	6720.
0	2730.

use $h = 10,000 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F}$ since $10^5 > 200$

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	PAGE NO. <u>99</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 936

FULL FLOW = 4 gpm

FLOW CONDITION:
AXIAL ↓

$$\begin{cases} \bar{R} = 2.5 \text{ inch} \\ \Delta R = 1 \text{ inch} \end{cases}$$

⑥ $A = 2\pi \bar{R} \Delta R = 2\pi (2.5)(1) \frac{1}{144} = 0.1091 \text{ ft}^2$

⑤ $D_H = 2 \times (\Delta R) = \frac{2(1)}{12} = 0.1667 \text{ ft}$

FULL FLOW = 4 gpm

④ $Q \frac{\text{ft}^3}{\text{sec}} = 0.002228 \times \text{GPM} = 0.002228(4) = .008912 \frac{\text{ft}^3}{\text{sec}}$

③ $V \frac{\text{ft}}{\text{sec}} = \frac{Q_{\text{CFS}}}{A_{\text{ft}^2}} = \frac{.0089}{.1091} = .082 \frac{\text{ft}}{\text{sec}}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{\text{FPS}} \right) \left(\frac{D_H}{\text{FT}} \right) = 3 \times 10^5 (.082)(.167) = 4085$

① $Pe = Re Pr = (4085)(.00482) = 19.69$


⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (19.69)^{0.8} = 7.27$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{.1667} \right) (7.27) = (243.72)(7.27) = 1772 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$

FULL FLOW

% FLOW	FLOW gpm	V. ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
100 %	4.0	.082	4085	19.7	7.27	1772
82.759 %	3.31	.068	3381	16,295	7,233	1763
0	0	0	0	0	7	1706

(14500)
,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	PAGE NO. 100 OF
CHECKED BY: <u>DMH</u>		REPORT NO. N266TI000-008
DATE: <u>7/1/78</u>	ISIP	MODEL NO.

NODE 938, 939

12

FULL FLOW = 0 gpm

FLOW CONDITION:

$$\begin{cases} R_o = 15.25 \text{ inch} \\ R_i = 14 \text{ inch} \end{cases}$$

⑥ $A = \pi(R_o^2 - R_i^2) = \pi(15.25^2 - 14^2) \frac{1}{144} = 0.80 \text{ FT}^2 \quad \Delta R = 1.25$

⑤ $D_H = 2 \times (\Delta R) = \frac{2(1.25)}{12} = 0.20833 \text{ FT}$

FULL FLOW = 0 gpm

④ $Q \frac{\text{FT}^3}{\text{SEC}} = 0.002228 \times \text{GPM} = 0.002228(0) = 0 \frac{\text{FT}^3}{\text{SEC}}$

③ $V \frac{\text{FT}}{\text{SEC}} = \frac{Q \text{ CFS}}{A \text{ FT}^2} = \frac{0}{0.80} = 0 \frac{\text{FT}}{\text{SEC}}$

② $Re \cong 3 \times 10^5 (V) (D_H) = 3 \times 10^5 (0) (0.20833) = 0$


① $Pe = Re Pr = (0)(0.00482) = 0$

⑦ $Nu = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (0)^{0.8} = 7$

$h = Nu \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{0.20833} \right) (7) = (194.98) (7) = 1365 \frac{\text{BTU}}{\text{hr FT}^2 \text{ } ^\circ\text{F}}$

% FLOW	FLOW gpm	V. ft/sec	Re	Pe	Nu	h $\frac{\text{BTU}}{\text{hr FT}^2 \text{ } ^\circ\text{F}}$
100 %	0					1365
82.759 %	0					
0	0	0	0	0	7	

(14500,000)

PREPARED BY: <u>EMM</u>	 Rockwell International Atomics International Division	PAGE NO. <u>101</u> OF
CHECKED BY: <u>DMH</u>		REPORT NO. <u>N266TI000-008</u>
DATE: <u>7/78</u>	ISIP	MODEL NO.

NODE 940, 941

FULL FLOW = 0 gpm

FLOW CONDITION:

$$\begin{cases} R_o = 38 \text{ inch} \\ R_i = 32 \text{ inch} \\ \Delta R = 6'' \end{cases}$$

⑥ A =

⑤ $D_H = 2 \times (\Delta R) = \frac{2(6)}{1} = 1.0$

FULL FLOW = 0 gpm

④ $Q \frac{ft^3}{sec} = 0.002225 \times GPM = 0.002228(0) = 0 \frac{ft^3}{sec}$

③ $V \frac{ft}{sec} = \frac{Q_{CFS}}{A_{ft^2}} = \frac{0}{1} = 0 \frac{ft}{sec}$

② $Re \cong 3 \times 10^5 \left(\frac{V}{ft \cdot sec} \right) \left(\frac{D_H}{ft} \right) = 3 \times 10^5 (0) (1) = 0$


① $Pe = Re Pr = (0)(.00482) = 0$

⑦ $NU = 7 + \frac{1}{40} (Pe)^{0.8} = 7 + \frac{1}{40} (0)^{0.8} = 7$

$h = NU \left(\frac{k}{D_H} \right) = \left(\frac{40.62}{1} \right) (7) = (40.62) (7) = 284 \frac{BTU}{hr \cdot ft^2 \cdot ^\circ F}$


% FLOW	FLOW gpm	V. ft/sec	Re	Pe	NU	h $\frac{BTU}{hr \cdot ft^2 \cdot ^\circ F}$
100 %						} 284'
82.759 %						
0	0	0	0	0	7	

(14500)
,000)

PREPARED BY: K. YUN	 Rockwell International Atomics International Division	PAGE NO. 102 OF
CHECKED BY: D. H.		REPORT NO. N266TI000-008
DATE: 10/10/76	151P	MODEL NO. 172

NODE 942

Flow Condition: Stagnant



Operating Temp. Range: 600°F ~ 1050°F

Use, $\left(\begin{array}{l} r_1 = 9 \text{ in} = .75 \text{ ft} \quad \checkmark \\ r_2 = 33 \text{ in} = 2.75 \text{ ft} \quad \checkmark \\ H = 52 \text{ in} = 4.33 \text{ ft} \quad \checkmark \end{array} \right.$

$$Ra_H = Gr_H \cdot Pr = A \cdot H^3 \cdot \Delta T \cdot Pr$$

where $A = \rho^2 g \beta / \mu^2$

$$1.35 \times 10^8 \times \Delta T < Ra_H = Gr_H \cdot Pr < 2.25 \times 10^8 \times \Delta T$$

∴ For $|\Delta T|$ (wall - Na) between 37°F ~ 89°F,


$$5 \times 10^7 \leq Ra_H \leq 2 \times 10^{10}$$

Therefore, Eg. 5.107 of O.E. Dwyer can be applied.

$$\begin{aligned} \bar{N}_{u_H} &= \frac{\bar{h} \cdot H}{k} = 0.16 \left[(Ra_H) (r/H) \right]^{0.3} \quad \checkmark \\ &= 0.16 \left[(A \cdot Pr \cdot H^3 \cdot \Delta T) (r/H) \right]^{0.3} \\ &= 0.16 \left[A \cdot Pr \cdot \Delta T \cdot H^2 \cdot r \right]^{0.3} \end{aligned}$$

At a given surface (H, r) \bar{h} becomes

$$\begin{aligned} \bar{h} &= .16 \frac{k}{H} (A \cdot Pr \cdot H^2 \cdot r)^{0.3} (\Delta T)^{0.3} \\ &= C (\Delta T)^{0.3} \quad \text{where, } C = .16 \left(\frac{k}{H} \right) (A \cdot Pr \cdot H^2 \cdot r)^{0.3} \end{aligned}$$

PREPARED BY: K. Yur	 Rockwell International Atomic International Division	PAGE NO. 103 OF
CHECKED BY: DMH		REPORT NO. N266TI000-008
DATE: 10/10/78	ISIP	MODEL NO.

T (°F)	N_a ($\gamma_{ft^3 \cdot ^\circ F}$) $A \cdot Pr = (\rho^2 g \beta / \mu^2) \cdot Pr$	k (Btu/hr ft °F)	C at r_1	C at r_2^*
500	1.42×10^6	45.43	260.06	
600	$1.66 \times "$	43.79	262.7	
700	$1.89 \times "$	42.18	263.1	
800	$2.14 \times "$	40.62	263.	
900	$2.38 \times "$	39.09	261.3	
1000	$2.64 \times "$	37.61	259.3	
1100	$2.90 \times "$	36.17	256.5	
1200	$3.18 \times "$	34.78	253.57	

Data from Golden & Tokar
(r_2/r_1)³

C at r_2 is 1.477 times greater than C at r_1

C at r_1 can be averaged as 260. at all operating temperature range

∴ use

$$C \text{ at } r_1 = 260.$$

$$C \text{ at } r_2 = 384.$$

$$\left(\begin{array}{l} \bar{h} \text{ at } r_1 = 260 (\Delta T)^{.3} \text{ Btu/hr ft}^2 \text{ } ^\circ F = .0005015 (\Delta T)^{.3} \text{ Btu/sec in}^2 \text{ } ^\circ F \\ \bar{h} \text{ at } r_2 = 384 (\Delta T)^{.3} \text{ Btu/hr ft}^2 \text{ } ^\circ F = .0007407 (\Delta T)^{.3} \text{ Btu/sec in}^2 \text{ } ^\circ F \end{array} \right.$$



APPENDIX B

CLEARANCE CHANGES

This appendix contains the results of the thermal radial clearance effect using the APSA program given in Reference 10.

CRITICAL CLEARANCE CHANGES (MILS)


Location*	Design clearance	Transient					
		E-202 100 sec	E-203 100 sec	E-204 100 sec	E-207 275 sec	E-208 115 sec	E-210 50 sec
A	13	+2.4	-1.7	+3.1	+4.6	+3.7	+2.2
B	13	+1.9	-1.3	+2.6	+3.5	+2.8	+2.4
C	50	+6.7	-7.2	+9.2	+11.8	+10.6	+6.6
D	50	+0.9	+5.2	-0.7	-1.5	-0.9	+2.6
E	50	+2.0	+2.9	-3.3	-2.9	-3.7	-3.0

Note =

- The value listed under the transient column are changes in the original clearance at Isothermal temperature conditions.

For example, at location A, the original clearance (13 mils) is increased by 0.0024 inch during Event E 202 and decreased by 0.0017 inch during E 203.

* see Figures 2



ROTATING ASSEMBLY

STATIC ASSEMBLY

FIG. 2 FINITE ELEMENT MODEL

APPENDIX C

TRANSIENT ANALYSIS — COMPUTER LISTING
(TAP PROGRAM)

(Computer printout removed for brevity.)




APPENDIX K

VERIFICATION OF THERMAL MODEL FOR ISIP
(INTERMEDIATE-SIZE INDUCER PUMP)

ESG Document N266TI000-0007

620-78-35

 Rockwell International <small>Atomics International Division</small>		SUPPORTING DOCUMENT		NUMBER N266TI000-007	REV LTR/CHG NO. <small>SEE SUMMARY OF CHG</small>																																																			
PROGRAM TITLE Intermediate Size Inducer Pump Program				DOCUMENT TYPE Technical Information																																																				
DOCUMENT TITLE Verification of Thermal Model for ISIP (Intermediate-Size Inducer Pump)				KEY NOUNS ISIP, Thermal Model																																																				
PREPARED BY/DATE K. H. Yun <i>K.H. Yun</i> DEPT 731 MAIL ADDR LB35 A. A. Loffredo <i>A.A. Loffredo</i> DEPT 731 MAIL ADDR LB35 E. M. Mouradian <i>E.M. Mouradian</i> DEPT 731 MAIL ADDR LB35				ORIGINAL ISSUE DATE GO NO. 09280 S/A NO. 22000 PAGE 1 OF 77 TOTAL PAGES 77 REL. DATE <i>3-9-79</i>																																																				
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO.				SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)																																																				
APPROVALS R.V. Anderson <i>R.V. Anderson</i> DATE <i>3-9-79</i> T.J. Boardman <i>T.J. Boardman</i> D.K. Nelson <i>D.K. Nelson</i> DATE <i>3-3-79</i>				(CHECK ONE BOX ONLY) <table style="width:100%; border: none;"> <tr> <td style="width: 33%;">UNCL <input checked="" type="checkbox"/></td> <td style="width: 33%;">DOE <input type="checkbox"/></td> <td style="width: 33%;">DOD <input type="checkbox"/></td> <td style="width: 33%;">RESTRICTED DATA <input type="checkbox"/></td> </tr> <tr> <td>CONF. <input type="checkbox"/></td> <td>DOE <input type="checkbox"/></td> <td>DOD <input type="checkbox"/></td> <td>DEFENSE INFO. <input type="checkbox"/></td> </tr> <tr> <td>SECRET <input type="checkbox"/></td> <td>DOE <input type="checkbox"/></td> <td>DOD <input type="checkbox"/></td> <td></td> </tr> </table>		UNCL <input checked="" type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>	CONF. <input type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>	DEFENSE INFO. <input type="checkbox"/>	SECRET <input type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>																																								
UNCL <input checked="" type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>																																																					
CONF. <input type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>	DEFENSE INFO. <input type="checkbox"/>																																																					
SECRET <input type="checkbox"/>	DOE <input type="checkbox"/>	DOD <input type="checkbox"/>																																																						
DISTRIBUTION <table style="width:100%; border: none;"> <thead> <tr> <th style="width: 5%;">*</th> <th style="width: 75%;">NAME</th> <th style="width: 20%;">MAIL ADDR</th> </tr> </thead> <tbody> <tr><td>*</td><td>R. V. Anderson</td><td>LB17</td></tr> <tr><td>*</td><td>T. J. Boardman</td><td>LB13</td></tr> <tr><td>*</td><td>T. K. Cheng</td><td>LB35</td></tr> <tr><td>*</td><td>C. C. Conners</td><td>LB30</td></tr> <tr><td>*</td><td>C. Dunn</td><td>LB39</td></tr> <tr><td>*</td><td>M. A. Grisham</td><td>LB26</td></tr> <tr><td>*</td><td>G. J. Hallinan</td><td>LB39</td></tr> <tr><td>*</td><td>R. K. Hoshide</td><td>JB05</td></tr> <tr><td>*</td><td>J. L. Lockett</td><td>LB39</td></tr> <tr><td>*</td><td>A. A. Loffredo</td><td>LB35</td></tr> <tr><td>*</td><td>H. M. Minami</td><td>LB35</td></tr> <tr><td>*</td><td>D. K. Nelson</td><td>LB35</td></tr> <tr><td>*</td><td>J. N. Nishizaka</td><td>LB35</td></tr> <tr><td>*</td><td>R. E. Schnurstein</td><td>LB17</td></tr> <tr><td>*</td><td>C. Q. Torrijos</td><td>LB26</td></tr> <tr><td>*</td><td>K. H. Yun</td><td>LB35</td></tr> </tbody> </table>				*	NAME	MAIL ADDR	*	R. V. Anderson	LB17	*	T. J. Boardman	LB13	*	T. K. Cheng	LB35	*	C. C. Conners	LB30	*	C. Dunn	LB39	*	M. A. Grisham	LB26	*	G. J. Hallinan	LB39	*	R. K. Hoshide	JB05	*	J. L. Lockett	LB39	*	A. A. Loffredo	LB35	*	H. M. Minami	LB35	*	D. K. Nelson	LB35	*	J. N. Nishizaka	LB35	*	R. E. Schnurstein	LB17	*	C. Q. Torrijos	LB26	*	K. H. Yun	LB35	ABSTRACT <p>A thermal nodal (TAP) model has been set up to represent the ISIP (Intermediate-Size Inducer Pump). Verification of the model has been made by running three cases and comparing results with the FFTF pump tests and Westinghouse's predictions for those tests.</p> <p>The AI-calculated results show generally good agreement with the test measurements. The model is therefore considered satisfactory for the further analysis which is planned.</p> <p>The calculations made are for Test Transients 205, 207, and 210.</p>	
*	NAME	MAIL ADDR																																																						
*	R. V. Anderson	LB17																																																						
*	T. J. Boardman	LB13																																																						
*	T. K. Cheng	LB35																																																						
*	C. C. Conners	LB30																																																						
*	C. Dunn	LB39																																																						
*	M. A. Grisham	LB26																																																						
*	G. J. Hallinan	LB39																																																						
*	R. K. Hoshide	JB05																																																						
*	J. L. Lockett	LB39																																																						
*	A. A. Loffredo	LB35																																																						
*	H. M. Minami	LB35																																																						
*	D. K. Nelson	LB35																																																						
*	J. N. Nishizaka	LB35																																																						
*	R. E. Schnurstein	LB17																																																						
*	C. Q. Torrijos	LB26																																																						
*	K. H. Yun	LB35																																																						
RESERVED FOR PROPRIETARY/LEGAL NOTICES				THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, DOE																																																				
731-C.261/jdj				This report was prepared as an account of work sponsored by the United States Government. Neither the U. S. Government, nor any of its employees nor any of its contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.																																																				
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																																																								



CONTENTS

	<u>Page</u>
I. INTRODUCTION.....	5
II. PURPOSE.....	6
III. DISCUSSION.....	7
IV. CONCLUSION.....	10
V. REFERENCES.....	17
APPENDICES.....	18
A. COMPARISON OF AI CALCULATIONS WITH FFTF TEST MEASUREMENTS AND WESTINGHOUSE PREDICTIONS....	18
A-1. TRANSIENT 205-TEST.....	20
A-2. TRANSIENT 207-TEST.....	35
A-3. TRANSIENT 210-TEST.....	50
B. TRANSIENT TEMPERATURE DIFFERENTIALS (LOCATION PAIRS 4-8, 4-9, 4-10, AND 4-11).....	65
B-1. TEMPERATURE DIFFERENTIAL PLOTS.....	66
B-2. TEMPERATURE DIFFERENTIAL TABLES.....	69



FIGURES

<u>Figure</u>		<u>Page</u>
1.	Test Transients.....	11
2.	Nodal Map; Thermal Model ISIP.....	12
3-a, b.	Thermocouple Locations (FFTF Pump Test).....	13
A-1-1 through A-3-14.	Local Temperature Versus Time Plots.....	21
B-1, 2, 3.	Local Temperature Differentials Versus Time Plots.....	66



TABLES

<u>Table</u>		<u>Page</u>
I.	Specification Transients.....	15
II.	Test Transients (205, 207, 210).....	16
A.	Temperature Measurement Locations.....	19
B-1a, b, c.	Local ΔT Versus Time.....	69
B-2a, b, c.	Local ΔT Versus Time.....	72
B-3a, b, c.	Local ΔT Versus Time.....	75



I. INTRODUCTION

The ISIP (Intermediate-Size Inducer Pump) is to be installed within the FFTF pump casing. A thermal model has been set up by AI to represent the ISIP, using techniques of the STAMP and TAP computer programs. The purpose of this thermal model is for use in calculating the thermal behavior of the ISIP during transients. The results are to be employed in stress and deflection analysis.



II. PURPOSE

The purpose of this report is to show the results of checkout runs with the computer thermal model of the ISIP (Intermediate-Size Inducer Pump). The calculated results are compared to the experimental measurements taken during the thermal testing of the FFTF pump. The agreement between the experimental and computer temperature values is reasonably good, such that the thermal model of the ISIP can be considered to be an adequate thermal representation of the pump.



III. DISCUSSION

The FFTF pump underwent extensive thermal transient testing, as reported in Reference 1 (Westinghouse Report 5080). A series of nine transients were planned to be run. Herein, these are referred to as "SPECIFICATION TRANSIENTS," and are shown in Table I (also see Reference 2). The sodium flow rate and pump inlet sodium temperature versus time is indicated.

The manipulation of the experimental facility does not allow exact duplication of the transient that is planned (due to imperfect control on flow rates, temperatures, etc.). Thus, the transients to which the FFTF pump was actually subjected were somewhat different, and are herein referred to as "test transients." These are shown in Figure 1 and Table II, as taken from Reference 1.

The casing of the FFTF pump has been modified somewhat for the installation of different components, such as to form the ISIP (ISI pump). Much of the overall structure remains unchanged. A thermal model has been set up to represent the ISIP using the STAMP and TAP computer programs (References 3 and 4). As a checkout of this model, three test transients were run: 205-TEST, 207-TEST, and 210-TEST (see Figure 1). These three were chosen because:

- 1) Transient 205 is one of only two "up" transients (the other being almost identical in nature)
- 2) Transient 207 is the "down" transient with the greatest overall temperature drop (nominally 330°F)
- 3) Transient 210 is the "down" transient with the steepest slope, dT/dt (nominally 3.0°F/sec).



In Reference 1, temperature versus time plots are shown for 14 different locations (where thermocouples were installed) for both test measurements and Westinghouse's prediction of temperature response. Plots of AI's calculational results for those some 14 locations have been superimposed on the measured and Westinghouse prediction curves taken from Reference 1. These are shown in Appendix A.

The AI data is the calculated response of the nodal points in the AI TAP thermal computer model lying closest to the thermocouple locations. The nodal map for the AI thermal model is shown in Figure 2.

The thermocouple locations are shown in Figures 3a and 3b. Also indicated are the location designations (1 through 14) used in the plots of Appendix A and the AI thermal model node numbers. Reasonably good agreement was obtained between AI's calculations and the measured data, as can be seen by inspection of the figures of Appendix A.

For Location 1, quite good agreement was obtained between AI calculations and measured data.

For Location 2, there was no measured data for 205, with a wide discrepancy between AI and Westinghouse predictions. For 207, there is good agreement with measured data. For 210, there is moderately good agreement, although AI is showing somewhat faster response. The zone of Location 2 is a large sodium cavity in which the mode of mixing is quite uncertain. However, it is a region that does not affect bearing behavior.

For Location 3, Transient 205, agreement between measurements and AI data is not very close, although AI's prediction is closer than the Westinghouse values. For 207 and 210, AI's data shows more sluggish



response than the measured data. Location 3 is a large sodium zone wherein mixing mode is uncertain. Also, it is a zone that does not influence the bearing region. It would appear that the natural convection parameters in the Westinghouse made gives good response for down transients, but does not for up transients. AI's results are intermediate.

For Locations 4, 5, 6, 7, and 8, agreement is generally quite good, although occasionally there appears to be a stray measurement curve (which does not agree with its fellow TC data).

For Location 9, AI's data shows considerably slower response than both the measurements and the Westinghouse prediction. This is because in this region the ISIP's design is different. The zone represented by Location 9 has an extra steel barrier between itself and the flow sodium, so as to delay the transient being felt there.

For Locations 10, 11, 12, 13, and 14, agreement between AI values and the measured data is quite good.

When inspecting the temperature versus time curves of Appendix A, it should be borne in mind that there is some displacement of the measured temperature, due to an offset in the reading of the thermocouples. This is sometimes as much as 20⁰F. Mental adjustment for this displacement should be made when comparing the curves of measured and calculated data.

In addition to the temperature versus time plots shown in Appendix A, several sets of temperature differentials versus time are shown in Appendix B. Temperature differentials between Location Pairs 4-8, 4-9, 4-10, and 4-11 are given. All are expected to show agreement, except Location Pair 4-9. Because of the design change and the resultant more sluggish response at Location 9, the temperature differential, $\Delta T = T_4 - T_9$, should be considerably less than in the FFTF test. The figure of Appendix B shows that that is the case.



IV. CONCLUSION


The purpose of this set of three transient calculations was to check out the thermal computer model set up for the Intermediate-Size Inducer Pump (ISIP). Comparison of the test with the FFTF pump indicates that the model is satisfactory. On this basis, it is judged that the model can be used for further calculations involved in the thermal analysis of the ISIP.

FIGURE 1

"TEST-TRANSIENTS" For FFTF Testing

Taken from Pg. 34, Figure 9 of
Westinghouse E.M. #5080,
Reference 1.

See: 205-TEST
207-TEST
210-TEST






FIGURE 2

NODAL MAP,
 THERMAL MODEL.

INTERMEDIATE SIZE
 INDUCER PUMP
 (ISIP)

ISI PUMP
 OVERALL THERMAL MODEL
 - K. YUN, 6-19-78 -


- △ - AMBIENT OR GAS NODES
- - SODIUM NODES
- - BLADE OR VANE NODES

FIGURE 3-a

FFTF TEST THERMOCOUPLE LOCATIONS

Taken from Pg. 30, Figure 5 of
Westinghouse E.M. #5080,
Reference 1.

① Circled locations
correspond to Appendix A
locations.



SPTF THERMOCOUPLE LOCATIONS


FIGURE 3-b

FFTF TEST THERMOCOUPLE LOCATIONS

(Bearing Area)

Taken from Pg. 29, Figure 4
of Westinghouse E.M. #5080,
Reference 1.

② Circled locations
correspond to Appendix A
locations.



FFTF PROTOTYPE PUMP
BEARING AREA THERMOCOUPLES




TABLE I
SPECIFICATION TRANSIENTS
(Taken from Table 4-II, Reference 2)

Transient Number	Flow (gpm)	Initial Temp. (F)	Final Temp. (F)	Temp. Change (F)	Trans Rate (F/sec)
201	14,500	750	600	-150	-0.4
202	14,500	750	600	-150	-1.5
203	14,500	500	650	+150	+1.5
204	14,500	850	650	-200	-2.0
205	14,500	700	850	+150	+1.5
206	12,000	1050	720	-330	-0.4
207	14,500	1050	720	-330	-1.2
208	14,500	1050	825	-225	-2.0
210	14,500	1050	900	-150	-3.0

TRANSIENT #205 - TEST

FROM E.M. #5080
(REF. 1)

	T START/T END °/°	ΣΔT °	t DUR SEC	dT/dt °/°/SEC
TEST OBJECTIVE	700/850	+150	100	+1.5
TEST SUMMARY	695/880	+185	72.5	+2.0

From
Pg. 24
EM-5080

SODIUM FLOW: = 14,500 gpm = 100 %

EM-5080, Pg. 34, Fig. 9:

t MINUTES	t SEC	T No-INLET	dT/dt °/SEC	ΔT	Δt SEC
0	0	695	0	0	45
0.75	45	695	+1.0	+15	15
1	60	710	+3.2	+32	10
1½	70	742	+2.25	+45	20
1.5	90	787	+1.75	+24	48
2.3	138	871	+0.41	+9	22
2½	160	880	-0.05	-1	20
3	180	879	-0.60	-6	10
3½	190	873	-0.20	-2	10
3½	200	871	-0.025	-1	40
4	240	870	0	0	∞
∞	∞ 10000	870			

TRANSIENT #210 - TEST

FROM E.M. #5080
(REF. 1)

	T START/T END °/°	ΣΔT °	t DUR SEC	dT/dt °/°/SEC
TEST OBJECTIVE	1050/100	-150	50	-3.0
TEST SUMMARY	1050/880	-170	56.7	-3.0

From
Pg. 24
EM-5080

SODIUM FLOW: = 14,500 gpm = 100 %

EM-5080, Pg. 34, Fig. 9:

t MINUTES	t SEC	T No-INLET	dT/dt °/SEC	ΔT	Δt SEC
0	0	1050	0	0	24
0.4	24	1050	-2.96	-160	54
1.3	78	890	-1.25	-15	12
1.5	90	875	+0.25	+10	40
2½	130	885	-0.35	-14	40
2½	170	871	+0.26	+12	46
3.6	216	883	0	0	∞
∞	∞ 10000	883			

TABLE II

"TEST TRANSIENTS"

205, 207 & 210

Taken from Westinghouse EM #5080
Figure 9, Page 34 (Reference 1).

See Figure 1

TRANSIENT #207 - TEST

FROM E.M. #5080
(REF. 1)

	T START/T END °/°	ΣΔT °	t DUR SEC	dT/dt °/°/SEC
TEST OBJECTIVE	1050/720	-330	27.5	-1.2
TEST SUMMARY	1051/715	-336	33.6	-1.0

From
Pg. 24
EM-5080

SODIUM FLOW: = 14,500 gpm = 100 %

EM-5080, Pg. 34, Fig. 9:

t MINUTES	t SEC	T No-INLET	dT/dt °/SEC	ΔT	Δt SEC
0	0	1050	0	0	48
0.8	48	1050	-1.83	-22	12
1	60	1028	-0.72	-43	60
2	120	985	-0.77	-46	60
3	180	939	-1.07	-64	60
4	240	875	-1.33	-80	40
5	300	795	-1.04	-75	72
6.2	372	720	+0.46	+50	108
8	480	770	+0.12	+14	120
10	600	784	0	0	∞
∞	∞ 10000	784			



V. REFERENCES

1. A. E. Reed, "SPTF Thermal Transient Testing: A Comparison of Analysis and Test Results," Engineering Memorandum E.M. 5080, August 1977, Westinghouse Electric Corp., Electro-Mechanical Division, Cheswick, Pennsylvania
2. D. R. Paradise, "Specification: Pump, Sodium, Inducer, Intermediate-Size (ISIP)," N266ST310001, April 1978, and Rev. A, June 1978, Atomics International
3. R. E. Craig, "Stress to Thermal Adaptation Model Program (STAMP) Description and User's Manual," TI-036-610-007, July 1974, Atomics International.
4. E. Moody, "Thermal Analyzer Program Revision (TAP-4SG)," TJ-099-411-015, August 1974, Atomics International



APPENDIX A
COMPARISON OF AI CALCULATIONS WITH FFTF TEST
MEASUREMENTS AND WESTINGHOUSE PREDICTIONS

Reference 1 (Westinghouse E.M. 5080) shows plots of temperature versus time for 14 locations within the FFTF pump. These are results of test measurements and Westinghouse prediction calculations. The plots for Test Transients 205-TEST, 207-TEST, and 210-TEST are shown in this appendix. The results of AI calculations for the same transients and the same locations have been superimposed upon these curves for comparison. The AI curves are the heavy-dashed lines.

Appendices A-1, A-2, and A-3 are for Test Transients 205, 207, and 210, respectively. The 14 locations are as shown in Figure 3 and in Table A. The location is also shown on each individual plot.




TABLE A
TEMPERATURE MEASUREMENT LOCATIONS
(See Figure 3)

Figure and Location Number	Location Description	AI Thermal Model Node Number	TE Numbers
1	Brg. Feed Up	925	33, 34
2	Brg. Feed Mid	925	35
3	Brg. Feed Bot	942	36
4	Brg. Feed	929	5, 6
5	Brg. Feed Out	929	23, 24, 25, 26
6	Brg. Top	144	2A, 2B, 2C, 2D
7	Brg. Bot	168	1, 2, 3, 4
8	Brg. Bot, Out	934	19, 20, 21, 22
9	Up Impl. Leak	927	27, 28
10	Brg. Out Top	932	7, 8
11	Vortex Chamber	920	9, 10
12	Brg. Return Temp Up	921	11, 12, 13, 14
13	Brg. Return	922	29, 30, 31, 32
14	Mid Tank Na	940	15, 16, 17, 18




Rockwell International
Energy Systems Group

NO . N266TI000-007
PAGE . 20

APPENDIX A-1

TRANSIENT 205-TEST


TEST 205



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1
FIGURE 1

BRG FEED UP
TE-0-33
TE-0-34




Page 21

N266T1000-007

N266ER000-001
Page 628

205


TEST 205



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77


A-1
FIGURE 2

205



N266T1000-007
Page 22


TEST 205



A-1
FIGURE 3

205

BRG FEED BOT
TE-0-36




Page 23

N266TI000-007

N266ER000-001
Page 630

TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77


A-1
FIGURE 4

205

BRG FEED
TE-0-5
TE-0-6




TEST 205



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77


A-1
FIGURE 5

BRG FEED OUT
TE-0-23
TE-0-24
TE-0-25
TE-0-26



205

TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77


A-1
FIGURE 6

205

BRG TOP
TE-0-2A
TE-0-2B
TE-0-2C
TE-0-2D



TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1
FIGURE 7

205

BOT BRG


- TE-0-1
- TE-0-2
- TE-0-3
- TE-0-4



N266T1000-007
Page 27

N266ER000-001
Page 634

TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1
FIGURE 8


205

BRG BOT OUT

- TE-0-19
- TE-0-20
- TE-0-21
- TE-0-22




TEST 205



UP IMPL LEAK

TE-0-27

TE-0-28



Page 29


N266TI000-007

N266R000-001
Page 636

205


A-1
FIGURE 9

TEST 205



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1
FIGURE 10




Page 30

N266T1000-007

205

TEST 205



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1


FIGURE 11

205


VORTEX CHAMB

TE-0-9

TE-0-10



TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

FIGURE 12
A-1


205

BRG RETURN TEMP UP

- TE-0-11
- TE-0-12
- TE-0-13
- TE-0-14



TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

FIGURE 13


205

BRG RETURN

- TE-0-29
- TE-0-30
- TE-0-31
- TE-0-32



TEST 205




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 205 2/2/77

A-1
FIGURE 14

205

MID TANK NA

- TE-0-15
- TE-0-16
- TE-0-17
- TE-0-18



N266T1000-007
Page 34



Rockwell International
Energy Systems Group

NO

N266TI000-007


PAGE .

35

APPENDIX A-2

TRANSIENT 207-TEST


TEST 207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 1

BRG FEED UP
TE-0-33
TE-0-34




Page 36

N266T1000-007

N266ER000-001
Page 643


207

TEST 207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 2




Page 37

N266T1000-007

N266ER000-001
Page 644


207

TEST 207




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT, 207 2/24/77

A-2
FIGURE 3




207

TEST 207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 4




Page 39
N266T1000-007

N266R000-001
Page 646

207

TEST 207




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77


A-2
FIGURE 5

207

BRG FEED OUT
TE-0-23
TE-0-24
TE-0-25
TE-0-26



TEST 207




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2


FIGURE 6

BRG TOP

- TE-0-2A
- TE-0-2B
- TE-0-2C
- TE-0-2D




207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 7




Page 42

N266T1000-007

N266ER000-001
Page 649

207

TEST 207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77


A-2


FIGURE 8

207

BRG BOT OUT

- TE-0-19
- TE-0-20
- TE-0-21
- TE-0-22






SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 9

207

UP IMPL LEAK

TE-0-27
TE-0-28




Page 44

N266TI000-007

N266ER000-001
Page 651

TEST 207




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 10

207

BRG OUT TOP

TE-0-7
TE-0-8




Page 45

N266T1000-007

Page 652

N266R000-001




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77


A-2
FIGURE 11

207

VORTEX CHAMB

TE-0-9
TE-0-10






SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77

A-2
FIGURE 12


207

BRG RETURN TEMP UP

- TE-0-11
- TE-0-12
- TE-0-13
- TE-0-14



TEST 207



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77


A-2


FIGURE 13

207

BRG RETURN

- TE-0-29
- TE-0-30
- TE-0-31
- TE-0-32






SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 207 2/24/77
 FIGURE 14

207

A-2

MID TANK NA

- TE-0-15
- TE-0-16
- TE-0-17
- TE-0-18






APPENDIX A-3

TRANSIENT 210-TEST

TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77


A-3
FIGURE 1

210

BRG FEED UP
TE-0-33
TE-0-34




TEST. 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 2

210




TEST 210



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77 FEED BOT
12-0-36

A-3
FIGURE 3




Page 53
N266T1000-007

N266R000-001
Page 660

210


TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 4

210




TEST 210



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77


A-3
FIGURE 5

BRG FEED OUT
TE-0-23
TE-0-24
TE-0-25
TE-0-26



210

TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3


FIGURE 6

210

BRG TOP
TE-0-2A
TE-0-2B
TE-0-2C
TE-0-2D



TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 7


210

BOT BRG

- TE-0-1
- TE-0-2
- TE-0-3
- TE-0-4



TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

FIGURE 8


210

BRG BOT OUT

- TE-0-19
- TE-0-20
- TE-0-21
- TE-0-22



TEST 210



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3


FIGURE 9

210


UP IMPL LEAK

TE-0-27

TE-0-28



TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 10

210


BRG OUT TOP
TE-0-7
TE-0-8



N266T1000-007
Page 60

N266ER000-001
Page 667

TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 11


210

VORTEX CHAMB

TE-0-9
TE-0-10



TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77

A-3
FIGURE 12


210

BRG RETURN TEMP UP

- TE-0-11
- TE-0-12
- TE-0-13
- TE-0-14



TEST 210




SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77


A-3
FIGURE 13

210

BRG RETURN
TE-0-29
TE-0-30
TE-0-31
TE-0-32



TEST 210



SPTF PUMP THERMAL PREDICTIONS VERSUS MEASUREMENTS-EVENT 210 2/17/77


A-3

FIGURE 14

210

MID TANK NA

- TE-0-15
- TE-0-16
- TE-0-17
- TE-0-18



N266T1000-007
Page 64



APPENDIX B
TRANSIENT TEMPERATURE DIFFERENTIALS
(Location Pairs: 4-8, 4-9, 4-10, 4-11)

In Appendix A, temperature versus time plots are shown for the 14 thermocouple locations. Based on this information, temperature differentials between four pairs of locations were determined and plotted. These plots are shown in Figures B-1, B-2, and B-3 for Test Transients 205, 207, and 210, respectively. The data is shown: measured, solid line; AI results, dashed line; and Westinghouse prediction, dotted line.

The results show generally good agreement. An important exception is the ΔT data for the Location Pair 4-9. In the ISIP, there are design changes in the vicinity of Location 9 which cause that region to respond more slowly to the transient. Thus, ΔT (4-9) is expected to be less than for the FFTF test, and this indeed is the case.


Locations for Points 4, 8, 9, 10, and 11 are shown in Figure 3 (also see Table A of Appendix A).

Tables B-1-a through B-3-c are the local temperatures and temperature differentials versus time for the locations indicated. The data for the T.C. measurements and Westinghouse data are taken from the plots of Reference 1, which are also shown in Appendix A. The AI data has been taken from the computer run output.

FIGURE B-1

TRANSIENT # 205-TEST

ΔT
4-8




Measured

AI


w

ΔT
4-9



{ AI Calculation should be considerably lower due to change in design in vicinity of location 9, and it is.

ΔT
4-10



ΔT
4-11





FIGURE B-2


TRANSIENT # 207-TEST



Measured

AI

W



AI Calculation should be considerably lower due to change in design in vicinity of location 9. and it is.






FIGURE B-3


TRANSIENT # 210-TEST



Measured

AI

W
.....



{ AI Calculation should be considerably lower due to change in design in vicinity of location 9. and it is.





TABLE B-1-a

TRANSIENT #205-TEST
FROM T.C. MEASUREMENTS

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T 929, A2 TE 5, 6	T 934 TE 19, 20, 21, 22	T 927 TE 27, 28	T 932 TE 7, 8	T 920 TE 9, 10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	703	703	703	704	710	0	0	-1	-7
60	1	703	705	705	704	710	-2	-2	-1	-7
		713	740	739	720	712	-27	-26	-7	+1
120	2	732	780	776	748	721	(-48)	-44	(-16)	+11
		774	820	826	785	735	-46	(-52)	-11	+39
180	3	799	840	836	811	752	-41	-37	-12	+47
		819				769				(+50)
240	4	828	851	850	835	781	-23	-22	-7	47
300	5	834	856	852	842	798	-22	-18	-8	36
360	6	840	855	852	843	809	-15	-12	-3	31
420	7	842	853	850	844	816	-11	-8	-2	26
480	8	842	851	849	844	820	-9	-7	-2	22
540	9	842	850	848	844	824	-8	-6	-2	18
600	10	842	850	847	844	826	-8	-5	-2	16

TABLE B-1-b
TRANSIENT #205-TEST
AI CALCULATION. 1/10/79

TIME		(4)	(8)	(9)	(10)	(11)	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(AI) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	695	695	695	695	695	0	0	0	0
60	1	695	703	695	697	695	-8	0	2	0
110	1-5/6	712	792	721	728	702	-80	-9	-16	10
120	2	720	808	729	736	704	-88	-9	-16	16
130 150 160		722 746 756	737 823 847 853	729 759 782	746 767	708 716	-95 -103 -117	-113 -112	-112	10 30
180	3	773	857	785	787	731	-84	-12	-14	42
210		794	855	803	802	745	-61	-9	-8	49
240	4	807	857	816	813	757	-50	-9	-6	50
260 280	4-1/3 4-2/3	814 820	858 859	822 827	819 824	764 771	-44 -39	-8 -7	-5 -4	50 49
300	5	824	860	831	828	777	-36	-7	-4	47
360	6	834	862	840	837	791	-28	-6	-3	43
420	7	841	863	846	843	802	-22	-5	-2	39
480	8	845	864	849	848	811	-19	-4	-3	34
540	9	848	865	852	851	817	-17	-4	-3	31
600	10	851	865	854	853	823	-14	-3	-2	28

TABLE B-2-a
TRANSIENT #207-TEST
FROM T.C. MEASUREMENTS

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T 929(AZ) TE 5,6	T 934 TE 19, 20, 21, 22	T 927 TE 27, 28	T 932 TE 7, 8	T 920 TE 9, 10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1058	1063	1060	1060	1060	-5	-2	-2	0
60	1	1056	1054	1055	1058	1060	2	1	-2	-4
120	2	1040	1020	1020	1030	1055	20	20	10	-15
180	3	1016	981	982	1008	1042	35	34	8	-26
240	4	1005	944	935	975	1022	61	61	30	-17
300	5	955	855	845	920	992	100	110	35	-37
360	6	905	800	797	870	958	105	108	35	-53
420	7	855	772	774	825	925	83	81	30	-70
480	8	821	792	794	816	893	29	27	5	-72
540	9	815	803	803	815	877	12	12	0	-62
600	10	815	805	805	815	868	10	10	0	-53

TABLE B-2-b
TRANSIENT #207-TEST
AI CALCULATION 1/9/79

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(AI) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1050	1050	1050	1050	1050	0	0	0	0
60	1	1050	1040	1050	1048	1050	10	0	2	0
120	2	1037	999	1033	1030	1045	38	4	7	-8
180	3	1012	958	1006	1003	1033	54	6	9	-21
240	4	979	901	969	966	1014	78	10	13	-35
280	4 1/3	950	854	938	935	996	96	12	15	-46
300	5	934	830	920	917	986	104	14	(17)	-52
320	5 1/3	910	809	902	900	975	107	19	16	-59
340	5 2/3	898	788	883	882	964	110	15	16	-66
360	6	880	768	865	864	952	(112)	15	16	-72
380	6 1/3	862	752	846	846	939	110	(16)	16	-77
400	6 2/3	846	755	831	834	927	91	15	12	-81
420	7	833	760	820	824	915	73	13	9	(-82)
440	7 1/3	824	766	812	818	905	58	12	6	-81
480	8	814	779	806	812	888	35	8	2	-74
540	9	811	785	804	808	872	26	7	3	-61
600	10	810	790	805	808	862	20	5	2	-52

TABLE B-2-c
TRANSIENT #207-TEST
 W PREDICTION

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(AI) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1050	1050	1050	1050	1050	0	0	0	0
60	1	1049	1034	1037	1041	1049	15	12	8	0
120	2	1034	1010	1004	1020	1041	24	30	14	-7
180	3	1010	966	960	994	1025	44	50	16	-15
240	4	997	920	906	952	1002	77	91	45	-5
300	5	950	857	831	920	961	(93)	119	30	-11
360	6	890	798	770	839	920	92	(120)	(51)	(-30)
420	7	847	774	766	809	868	73	81	38	-21
480	8	810	785	779	797	838	25	31	13	-28
540	9	802	789	785	795	817	13	17	7	-15
600	10	795	791	785	794	808	4	8	1	-13

TABLE B-3-a
TRANSIENT #210-TEST
FROM T.C. MEASUREMENTS

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(AZ) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1057	1058	1059	1059	1062	-1	-2	-2	-5
60	1	1050	1012	1015	1040	1060	38	35	10	-10
120	2	988	936	938	977	1035	(52)	(50)	(11)	-47
180	3	956	915	918	946	1008	41	38	10	-52
240	4	934	909	910	934	988	25	24	0	(-54)
300	5	922	902	905	920	972	20	17	2	-50
360	6	910	895	896	912	960	15	14	-2	-50
420	7	904	890	894	906	948	14	10	-2	-44
480	8	900	882	895	903	940	18	5	-3	-40
540	9	900	895	897	903	935	5	3	-3	-35
600	10	902	900	900	904	935	2	2	-2	-33

TABLE B-3-b
TRANSIENT #210-TEST
AI CALCULATION 12/13/78

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(A2) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1050	1050	1050	1050	1050	0	0	0	0
60	1	1044	977	1039	1031	1048	67	5	13	-4
90	1½	1021	911	1009	1001	1039	110	12	20	-18
120	2	991	904	979	977	1026	87	12	14	-35
150	2½	969	899	959	959	1012	70	10	10	-43
180	3	952	889	943	944	1000	63	9	8	-48
210	3½	939	893	931	934	988	46	8	5	-49
240	4	930	894	924	927	978	36	6	3	-48
300	5	920	891	914	917	963	29	6	3	-43
360	6	913	890	908	911	952	23	5	2	-39
420	7	909	889	904	906	943	20	5	3	-34
480	8	905	888	902	903	936	17	3	2	-31
540	9	903	888	900	900	931	15	3	3	-28
600	10	901	887	898	898	926	14	3	3	-25

TABLE B-3-c
TRANSIENT #210-TEST
W PREDICTION

TIME		④	⑧	⑨	⑩	⑪	ΔT	ΔT	ΔT	ΔT
SEC.	MIN	T929(A2) TE 5,6	T934 TE 19, 20,21,22	T927 TE 27,28	T932 TE 7,8	T920 TE 9,10	(4-8)	(4-9)	(4-10)	(4-11)
0	0	1050	1050	1050	1050	1050	0	0	0	0
60	1	1046	962	940	1015	1045	84	106	31	1
120	2	1006	904	885	966	1015	(102)	(121)	(40)	-9
180	3	969	890	875	938	984	79	94	31	-15
240	4	942	890	881	922	958	52	61	20	(-16)
300	5	922	884	878	908	937	38	44	14	-15
360	6	908	878	871	896	920	30	37	12	-12
420	7	898	875	870	888	907	23	28	10	-9
480	8	889	881	879	885	896	8	10	4	-7
540	9	886	885	884	885	892	1	2	1	-6
600	10	886	887	888	887	891	-1	-2	-1	-5




APPENDIX L

MODEL INDUCER WATER TUNNEL
TEST REPORT

Rocketdyne Document R/H 9113-3741
(Assigned ESG Document number is N266TR000-002)

Figures 12 thru 26 have been removed from this document because they contain proprietary information, as defined by DOE contract.

 Rockwell International <small>Atomics International Division</small>		SUPPORTING DOCUMENT		NUMBER N266TR000-002	REV LTR/CHG NO <small>SEE SUMMARY OF CHG</small>
PROGRAM TITLE Intermediate-Size Inducer Pump				DOCUMENT TYPE Test Report	
DOCUMENT TITLE Model Inducer Water Tunnel Test Report				KEY NOUNS Pump, Inducer, Model-Test	
PREPARED BY/DATE E. D. Jackson <small>(Rocketdyne, Div 055)</small>				DEPT 545-113	MAIL ADDR AC51
APPROVALS T. J. Boardman <i>T. J. Boardman</i> R. V. Anderson <i>R. V. Anderson</i>				DATE 2/20/79 2/20/79	ORIGINAL ISSUE DATE February 9, 1979
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				GO NO. 09280	S/A NO. 23000
				PAGE 1 OF 53	TOTAL PAGES 53
				REL. DATE 3-1-79 <i>sw</i>	
SECURITY CLASSIFICATION					
		(CHECK ONE BOX ONLY)		(CHECK ONE BOX ONLY)	
		UNCL <input checked="" type="checkbox"/>	DOE <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>	
		CONF. <input type="checkbox"/>	DOD <input type="checkbox"/>	DEFENSE INFO. <input type="checkbox"/>	
		SECRET <input type="checkbox"/>	<input type="checkbox"/>		
				AUTHORIZED CLASSIFIER	DATE
DISTRIBUTION			ABSTRACT		
*	NAME	MAIL ADDR	<p>This report summarizes results of water tests performed on a six-inch diameter model of the inducer for the Intermediate-Size Inducer Pump. The report contains descriptions of the test facility, instrumentation and methods of testing used to determine the cavitation performance, and to evaluate the life potential of the inducer with a fixed NPSH margin against cavitation. Test results show good suction performance over a wide range of flow conditions and support a high confidence in achieving good life characteristics (freedom from damage) when the full size pump is operated in sodium. Tests covered by this report are for concentric operation of the inducer within the inducer tunnel. This report was prepared by Rocketdyne (Div. 055) under IDWA N-1327 and released from that division under the number RI/RD79-142.</p>		
*	T. Boardman	LB08			
*	R. Anderson	LB17			
*	J. Lockett	LB39			
*	J. Pfouts	JB05			
*	R. Hoshide	JB05			
*	C. Dunn	LB08			
	G. Hallinan	LB39			
	R. Schnurstein	LB17			
	E. Andrews	KB45			
	L. Stabinsky	JB05			
	J. Page	LB05			
	C. Torrijos	LB26			
	C. Conners	LB30			
	D. Nelson	LB13			
RESERVED FOR PROPRIETARY/LEGAL NOTICES					
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY			<div style="border: 1px solid black; padding: 10px; width: fit-content; margin: auto;"> <p>NOTE: Proprietary Information as defined in the contract with <u>DOE</u> has been removed from this document for use in N266ER000-001.</p> </div>		



Rockwell International

Rocketdyne Division
6633 Canoga Avenue
Canoga Park, California 91304

RI/RD79-142

INTERMEDIATE SODIUM INDUCER PUMP
MODEL INDUCER WATER TUNNEL TEST REPORT

R/H 9113-3741
9 FEBRUARY 1979

PREPARED BY

Rockwell International Corporation
Rocketdyne Division
6633 Canoga Avenue
Canoga Park, California 91304

APPROVED BY

E. D. Jackson
E. D. Jackson
Manager
Hydrodynamics Unit

J. E. Wolf
J. E. Wolf
Project Engineer
Sodium Pump Program

D. E. Davis
D. E. Davis
Program Manager
Dynamic Power Programs

PREPARED FOR

Energy Systems Group
Atomics International Division
Under IDWA No. N-1327
Authorized Under ESG Prime Contract EY-76-C-03-0824

TABLE OF CONTENTS

INTRODUCTION	1
TEST ARTICLE	4
TEST FACILITY	6
TEST INSTRUMENTATION	11
TEST PROGRAM	14
TEST RESULTS	17
CONCLUSIONS	49
REFERENCES	50

INTRODUCTION

The Intermediate-Size Inducer Pump (I.S.I.P.) was designed to operate in the existing FFTP pump housing and to achieve the required pump head rise at the same speed and flow as the existing pump. The existing pump consists of four basic hydrodynamic elements:

1. Inlet Elbow
2. Centrifugal Impeller
3. Vaned Diffuser
4. Discharge Housing

All of these elements except the centrifugal impeller were to be retained in an unmodified form for the I.S.I.P. design. The centrifugal impeller was to be replaced with a new design consisting of both an inducer and centrifugal impeller. The objective is to demonstrate the capability of designing an inducer pump for long life in sodium operation so that the advantages of the inducer pump can be realized in future sodium pump applications. These advantages consist primarily in the smaller envelope size and lower weight realized as a result of the better suction performance capability of the inducer. These advantages result in significant cost savings and ease of fabrication and handling for the very large pumps required in many of the reactor coolant loop systems.

Figure 1 shows a cross-section of the primary pump components. The most significant hydrodynamic challenge in the design is to achieve the long




FIGURE 1.

life in the inducer. To provide early confidence in the design before finalizing the fabrication and initiating testing of the full-size pump in sodium, a model of the inducer was fabricated for testing in the Rocketdyne water tunnel. The testing included both life and performance tests using a one-third scale model. The testing was successful and demonstrated both excellent performance and life characteristics for the Rocketdyne design. This report describes both the test program and test results.

TEST ARTICLE

The inducer was designed based on the same design practices established and demonstrated by the successful waterjet inducer designs by Rocketdyne. The primary dimensions of both the full-size and water model of the inducer are given in Table 1. As can be seen, the model is almost exactly a one-third scale version of the full-size. The model inducer is defined by drawing number EWR 344240.

This test article was installed in the test adapter as shown in drawing number EWR 344200. The test adapter consisted of an inducer shaft supported on the test rolling element bearings and splined to an impeller assembly. The impeller assembly, which was driven by the facility gearbox, provided the head requirements to circulate the fluid through the system.

TABLE 1. I.S.I.P. INDUCER FEATURES

<u>PARAMETER</u>	<u>FULL-SIZE HARDWARE</u>	<u>WATER-MODEL HARDWARE</u>
No. of Blades	4	4
Tip Diameter, In.	18.53	5.986
Inlet Hub Diameter, In.	6.626	2.140
Disch Hub Diameter, In.	11.358	3.669
Tip Radial Clearance, In.	0.050	0.016
Speed, RPM	1110	6322
Tip Speed, FPS	89.7	165.1
Design Flow, GPM	14,600	2803
Inlet Flow Coefficient	0.222	0.222
Disch Flow Coefficient	0.310	0.310

TEST FACILITY

The testing was conducted at Rocketdyne's Pump Calibration Facility in Dept. 592. The pump was driven by a 1200 RPM, reversible, synchronous electric motor, which is rated at 4000 horsepower. The motor drives through a 4000 horsepower gearbox, which has two output shafts. One shaft is capable of producing speeds of 6322 and 8013 RPM. The other shaft is capable of producing speeds of 6322 and 10,029 RPM. The pump was run on the North powerhead (pump position No. 1) at 6322 RPM for this inducer test.

Figure 2 shows a schematic of the drive system and flow loop. An 8000 gallon water tank supplies water for the flow loop. This tank is rated at 150 psi with a vacuum capability of 28.5 inches of vacuum. The flow is measured by a turbine flow meter in the inlet line and regulated by a motor-operated throttle valve in the discharge line, whereas, the inlet pressure is regulated by controlling the tank pressure.

The inlet ducting consists of 8-inch schedule 40 steel piping, and the discharge loop is 4-inch diameter steel piping. All metallic coupling joints were heavily greased to assure an air tight system. An orifice was installed in the inlet line to keep the tank pressure up during cavitation tests to further avoid air leaks.




FIG. 2 Drive System and Flow Loop Schematic

The inducer is mounted on its shaft which is supported by its own bearing system as shown in drawing number EWR 344200. The inducer shaft is connected to an impeller shaft by a quill shaft. The impeller is an 11-inch tip diameter centrifugal impeller previously designed and fabricated at Rocketdyne and used in the current program as a slave impeller to generate the required head to provide the design flow of the inducer. The impeller is far enough downstream of the inducer to permit instrumentation to be inserted between the two for measuring inducer performance without impeller interference. The test arrangement is designed to establish the inducer performance characteristics as an independent component. The only drawback of this facility arrangement is that the only facility torque meter available is located between the impeller and the drive gearbox. Thus, there is no way to separate the drive torque of the inducer from the slave impeller, hence no way to determine the efficiency of the inducer. This is not a significant problem because the overall sodium pump efficiency is determined during sodium pump tests and is primarily driven by the centrifugal impeller and discharge system rather than the inducer.

The impeller housing and shaft system was mounted rigidly to a steel frame to assure perfect alignment with the driving motor and, thus, avoid possible oscillation of the system. Testing verified that both the alignment and quill shaft arrangement were satisfactory to prevent any significant rotor dynamic vibrations in either the inducer or impeller.

The inducer was enclosed in a plastic viewing tunnel, which allowed both

photographic and visual observation of the cavitation characteristics of the flow through the inducer. The test setup is shown in Fig. 3. The inducer-to-tunnel clearance was measured to be 0.016 ± 0.001 inch radially for the initial test series representing a concentric build. Later testing was done with an eccentric tunnel and a reduced clearance concentric tunnel, but only the results of the initial testing are reported here.




FIGURE 3
PUMP TEST FACILITY FOR MODEL SODIUM
INDUCER

TEST INSTRUMENTATION

Table 2 presents a list of the instrumentation used during the testing. The inlet pressure consisted of a 4-hole piezometer ring located sufficiently upstream of the inducer to avoid interference effects due to the inducer tip backflow. Downstream of the inducer, two total pressure (Kiel) probes were used to measure the discharge pressure at the mid-blade height position. These probes are subject to clogging due to solid material in the water, and the use of two probes provides more assurance of getting good data during the tests. Yaw probe surveys were planned to provide head distribution as a function of radius but were not carried out due to scheduling conflicts in the facility. There were also numerous static pressures recorded along the tip over the inducer and at the inducer discharge. These were all single point static pressures and provide an indication of the head distribution through the inducer. Drawing number EWR 344205 shows the location of these taps with the same identification keys as used in Table 2.

Other instrumentation included the turbine flowmeter, speed, and torquemeter. These are all standard facility instruments. The speed is fixed during these tests by the electric motor and is recorded only for measuring transients if desired. As previously discussed, the torquemeter measures the input torque to both the inducer and slave impeller so it cannot be used to determine inducer efficiency. Water temperature is measured in the inlet line to permit calculation of the water density and vapor pressure. The other measured pressures are used

TABLE 2. INSTRUMENTATION

	<u>RANGE</u>
Inlet Static Pressure, Piezometer, PSIA	0 ± 100
Discharge Total Pressure, #1 Tunnel (A) ⁺ PSIG	0 ± 500
Flowrate, GPM	0 ± 4000
Speed, RPM	6322
Torquemeter, IN LB	0 ± 10,000
Water Temperature, °F	40 ± 140
Discharge Total Pressure #2 Tunnel (A) PSIG	0 ± 500
Pump Discharge Static Pressure, Pipe, PSIG	0 ± 500
Pump Delta Pressure, PSI	0 ± 500
Static Pressure, Tunnel (A) , PSIG	0 ± 100
Static Pressure, Tunnel (C) PSIG	0 ± 200
Static Pressure, Tunnel (D) PSIG	0 ± 200
Static Pressure, Tunnel (E) PSIG	0 ± 200
Static Pressure, Tunnel (F) PSIG	0 ± 200
Static Pressure, Tunnel (G) PSIG	0 ± 200
Static Pressure, Tunnel (H) PSIG	0 ± 200
Static Pressure, Tunnel (J) PSIG	0 ± 200

+ Circled letters refer to section locations on Drawing No. EWR 344205

for facility diagnostics and conducting of the tests.

All of the data are recorded by a digital acquisition system (Autodata 9 by Accurex) on a "floppy disk" which is transmitted post-test to a digital computer. The data are reduced to provide all pertinent data and calculated parameters by a data reduction program written specifically for the Pump Test Facility. The data are then printed in tabular form, and if desired, selected CRT (cathode ray tube) printouts are obtained.

In addition to the recorded data, photographic techniques were used with strobe-light stop-action cameras to record the cavitation patterns during certain tests. These photographic records were then spliced together to form an annotated presentation of the results. Still photographs were also used post-test to record the dye patterns after running life tests (to be described).

TEST PROGRAM

The purpose of the test program was to conduct head-flow tests, cavitation tests, and dye tests for demonstrating the long life potential of the inducer by the absence of cavitation damage.

Head-Flow Test

Head-flow tests were conducted using an inducer shaft speed of 6322 RPM, and an inlet pressure of 65.0 psia, well above the region of cavitation. Flowrates from 1950 to 3650 GPM were achieved in the test representing a variation of -30 to +30 percent about design flow. Data were sampled recorded on the Autodata 9 system at each specific flow after the flow had been stabilized. The basic purpose of the test was to define the head-flow characteristic of the inducer.

Cavitation Test

An inducer shaft speed of 6322 RPM was used for the cavitation tests. Inlet pressure was set initially at approximately 50 psia and was allowed to continuously decay until the pump head fell off. This test sequence was performed at flowrates from 2100 to 3650 gpm, representing a flow variation of -25 to +30 percent about design flow. Data were continuously recorded on the AD9 system during the pressure decay. The purpose of the tests was to establish the suction performance characteristics of the inducer.

With the head generated by the inducer, the sodium impeller operates at a low enough suction specific speed that it does not experience any head fall-off due to cavitation until the inducer head falls off significantly (approximately 15 percent inducer head fall-off generally results in approximately 2-3 percent overall pump head fall-off). Thus, the suction performance established for the inducer from these tests also establishes the overall pump suction performance.

Design Point Life Tests

After coating the inducer blades with an insoluble dye, a twenty minute test was performed at 200 percent NPSH margin at the design flow of 2803 GPM. The inducer shaft speed was 6322 RPM and the inlet pressure determined based on the suction performance results of preceding tests. Five samples of data were recorded every five minutes on the Autodata 9. The dye used in the tests was the brand name "Magic Marker" marking ink applied to the blade pressure and suction surfaces by cotton swabs. This particular dye has been used extensively by Rocketdyne in developing other long-life inducer designs. The dye has been shown to be an effective indication of cavitation damage potential in that the dye is clearly removed during the 20 minute test if there is cavitation collapse on the blade, but no dye is removed if the cavitation collapse occurs in the fluid stream. Rocketdyne has tested parts in the field to demonstrate long life without cavitation damage after verifying the long-life design by the same type of dye tests described here. Rocketdyne has also tested models of inducers experiencing damage in the field and duplicated the

damage potential by the dye removal in the model facility. Thus, it is believed such tests are an excellent screening test for providing confidence in the design at an early state in the design process with minimal costs. The use of the "Magic Marker" dye has a degree of correlation with field results and is easily and quickly applied. Thus, Rocketdyne believes that it is a valuable test procedure.

Off-Design Life Test

These tests were conducted in the same manner as the Design Point Life Tests described above. Several flows were used in the test including 130 percent of design flow. The flow and NPSH margin were varied to establish life characteristics over a range of operating conditions to establish the best operating point and provide more confidence in the design. The NPSH margin at each flow was compared to the value resulting from operation at the proper speed and flow for the sodium in its facility. Five samples of data were recorded every five minutes on the Autodata 9 system.

TEST RESULTS

Inducer Head-Flow Performance

Figure 4 shows the head rise for the model inducer. Two computer programs were used to predict the head rise trend, and both showed excellent agreement, both with each other and with the test data. The analytical programs correctly predicted both the design point head and the slope of the head-flow curve (the off-design performance) over a large flow range.

Figure 5 presents the head-flow curve for the full-sized inducer. The slope of the head-flow curve is sufficiently flat to enable the inducer to continue to produce significant head rise at flows over 130 percent of the design flow. This head is sufficient to keep the impeller blades from experiencing cavitation in the sodium operation eliminating cavitation damage to the impeller. This is one of the advantages of the inducer pump over those without an inducer. Conventional centrifugal impellers cannot operate over a large flow range without significant cavitation unless the NPSH supplied is very large.

The slope of the inducer head-flow curve is negative down to at least 70 percent of design flow. This covers the expected range of steady-state operation of the sodium pumps at all but the lowest speed points. The pump would be expected to maintain a negative slope over an even larger

ISIP MODEL INDUCER
TIP DIAMETER = 5.986 IN.
N = 6322 RPM




FIG. 4

ISIP FULL SIZE INDUCER
TIP DIAMETER = 18.53 IN.
N = 1110 RPM




FIG. 5

flow range because the centrifugal impeller following the inducer has sufficient NPSH from the inducer to keep it out of cavitation at these low flows, and it would continue to develop more head after the inducer head began to decrease.

The data from the wall static pressures along the tip of the inducer give an indication of the head rise distribution through the inducer. Figure 6 presents the static pressure rise above inlet static pressure for various flow ratios. The figure also presents a sketch of the inducer with the indicated locations of the pressure taps. The data show an excellent trend of increasing pressure through the inducer. The agreement with theory is also seen to be very good. The data actually are higher than the prediction which probably indicates that there is less blockage through the blade rows than assumed in the quasi-three-dimensional flow analysis model. These results are sufficiently close to the desired distribution to give confidence in the design and its long-life potential.

Inducer Suction Performance

The suction performance tests are run in the test facility with the throttle valve adjusted to maintain constant flow while dropping inlet pressure. The inlet pressure is decreased until a significant loss in head across the inducer is achieved. The data are reduced using computer generated CRT plots as shown in Fig. 7 and 8, the former showing the





FIG. 7. CRT OF INDUCER HEAD RISE VS NPSH

(+) -24 IND HEAD RISE 01 (FT)



-12 INLET SU SPEC SPEED
TEST ITEM ISIP MODEL INDUCER DATED SEPT. 15, 1978 COMMENTS ON HQ AND CAVITATION

FRAME 57

FIG 8. CRT OF INDUCER HEAD RISE VS SUCTION SPECIFIC SPEED

inducer head rise as a function of inlet NPSH and the latter showing the same inducer head rise but as a function of suction specific speed. From these data, the NPSH and/or the suction specific speed can be determined for various percent fall-off of inducer head from its non-cavitating value. Generally, it is more accurate to work with the suction specific speed curve to get better resolution of the data.

A pump typical of the I.S.I.P. sodium pump will generate most of its head in the impeller. The inducer will only generate from 10 to 20 percent of the total head rise, and this inducer falls in the middle of this range. Thus, if the inducer head drops off by a certain percent, the total pump head will drop by a much smaller percent (from one-tenth to one-fifth as much) as long as the inducer is still generating sufficient head to keep the impeller out of cavitation head fall-off. This effect is even further accentuated by the fact that the impeller will actually make up for some of the loss experienced in the inducer because of the effect of the relative fluid angles. Thus, typically for this type of inducer-impeller combination, the critical NPSH quoted for the inducer based on tests without the impeller is defined as occurring at 15 to 20 percent inducer head fall-off. For the I.S.I.P. sodium inducer, the critical NPSH and suction specific speed were conservatively assumed to be at the 15 percent fall-off point. Thus, the total pump head should degrade by less than three percent for the quoted suction specific speeds.

The suction specific speed of the model inducer based on this criterion is shown in Fig. 9. The figure also shows the suction specific speed

ISIP MODEL INDUCER
WATER TEST RESULTS




FIG. 9

based on 5 and 10 percent of inducer head fall-off. All three curves are seen to be above the predicted value at the design flow. They also show good suction performance over a very large flow range. This will provide a much better NPSH margin to the impeller at the off-design points.

It should be understood that the data presented in Fig. 9 are direct results from water tests with no sodium-to-water correction factor. Rocketdyne's experience in testing cryogenic fluids has led to approaches to correct for the transition from water to cryogenic based on the difference in vapor pressure between the two fluids. This approach has also been used by other industrial and academic communities and is analytically sound. The vapor pressures in water and sodium are both so low that no correction factor should be needed. Such correction factors have been reported in some instances but are probably a result of the test facility rather than fluid thermodynamic behavior.

Using the suction specific speed data of Fig. 9, the required NPSH can be calculated for either the full-size or model pump. The calculation is based on the familiar equation

$$\text{NPSH} = \left[N \sqrt{Q/N_{SS}} \right]^{4/3}$$


where NPSH is in feet, speed (N) is in rpm, flow (Q) is in gpm, and N_{SS}

is the suction specific speed. This calculation was made using the flow and speed of the full-size pump to achieve the results shown in Fig. 10. It should be noted that the required NPSH shown in this figure is for a constant speed of 1110 rpm. If speed is varied, the required NPSH would vary directly with speed squared. At the design flow, the required NPSH is slightly over 11 feet. The required NPSH at the lower flows remains low as is typical of a good inducer design. At the higher flows, the required NPSH does increase with flow, but the increase is gradual enough that pump operation will be achieved over the full expected region of operation of flow.

During the cavitation testing, photographic movies were taken to permit observation of the development of the cavities as inlet pressure was dropped. A pressure gage was mounted adjacent to the plastic view tunnel to provide a direct correlation of inlet pressure and cavity development. Selected still photographs were made from the movies to illustrate the cavity patterns in the tip vortex. Figure 11 presents the ratio of the head divided by non-cavitating head as a function of inlet pressure and NPSH with flags to indicate where the still photographs were taken. The photographs included here are all at the design flow and represent NPSH margins from 243 percent down to zero percent.


The photographs are presented in Fig. 12 through 15, beginning at high NPSH and decreasing with successive figures. The inducer is to the left of the pressure gage. Flow direction is from the bottom of the figure up.

ISIP REQUIRED NPSH
FULL SIZE PERFORMANCE BASED ON
MODEL INDUCER WATER TESTS
FULL SIZE SPEED - 1110 RPM
FULL SIZE DESIGN FLOW = 14600 GPM



FLOW/DESIGN FLOW
FIG. 10

ISIP MODEL INDUCER
WATER TEST RESULTS



The inducer is rotating from left to right. The blades can be seen in part, and the tip vortex cavitation is fairly clear. In Fig. 12, this cavity is very small, and the collapse of the vortex can be seen between adjacent blades. In Fig. 13, the cavity has grown but still clearly collapses between blades. In Fig. 14, the cavity can be seen on two adjacent blades, but is still very well contained in the fluid passage and does not extend into the region of the channel flow of the inducer. The last figure (Fig. 15) shows the cavity extended over the full length of the blade, but note that the NPSH margin is down to zero. These photographs indicate in general that the cavity is collapsing in the flow system rather than on the blade, but the dye tests (to be discussed) provide a more positive confirmation of this feature.

Life Test Results

Testing for life in water is not as stringent as testing in sodium for laboratory tests have shown that if cavitation is collapsing in an area to cause damage, the damage rate in sodium is higher than it is in water. The magnitude of the variation has been quoted at different levels ranging from two orders of magnitude (Ref. 1) to a factor of approximately 3.0 (Ref. 2). Part of this difference was compensated for in the water tests of the model by testing at a higher inducer tip speed. Laboratory measurements of the effect of tip speed have not been totally consistent, but the majority of the data appear to support the dependency of damage

on the sixth power of the velocity. The model inducer was tested with a tip speed of 165.1 feet per second (fps) compared to 89.7 fps for the full-size pump in sodium. Using the sixth-power relationship, this is equivalent to a damage rate 39 times faster due to the higher tip speed of the model.

However, the advantage of performing life tests with dye coatings is that the test is not attempting to identify and/or match damage rates. No attempt is made to measure the extent of damage and scale the rate to predict rate of failure of the full-size hardware. The dye test is designed to identify any potential region of cavitation damage regardless of rate. It takes very little time for a cavity bubble collapsing on the blade to remove the dye. Therefore, for a long-life design, no dye removal would be expected, and the dye test would have to verify that condition. Rocketdyne's design approach is to design to eliminate any cavitation collapse near the inducer blades. Thus, no dye removal during dye testing would be the expected result.

Table 3 presents the various operating conditions tested with dye, indicating both the target and actual test conditions. The flow was varied from approximately 95 to 130 percent of design flow, and the NPSH margin was varied for some of the flows. There was no removal of dye for any of the tests performed substantiating the long-life design features of this inducer. In fact, the I.S.I.P. model inducer showed a greater flow

TABLE 3. MODEL I.S.I.P. SODIUM INDUCER DYE TESTS IN WATER

BUILD	TARGET VALUES				TEST RESULT VALUES			
	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	NPSH MARGIN	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	NPSH MARGIN
CONCENTRIC	2663	0.95	50.4	270	2662	0.95	48.5	258
	2803	1.00	50.4	240	2804	1.00	48.6	230
			43.3	200	2811	1.00	43.0	197
			31.7	130	2812	1.00	29.6	115
			27.0	100	2806	1.00	26.0	97
			2943	1.05	50.4	210	2943	1.05
	3083	1.10	54.5	200	3087	1.10	54.4	199
			34.0	100	3086	1.10	33.8	98
	3364	1.20	48.7	100	3372	1.20	48.2	99
	3476	1.24	49.4	70	3473	1.24	49.4	68
3644	1.30	67.0	50	3657	1.30	66.1	47	

N266ER000-001
Page 720

N266TR000-002
Page 40

range for no dye removal due to cavitation than any previous inducer tested to date. The dye tests would indicate that long life could be expected in the sodium testing for flows varying from 95 to 130 percent of design flow and over a significant NPSH range. This provides the very highest confidence in the sodium testing, particularly considering the large difference in tip speeds between model and full-size.

The only way to document the results of the dye tests is through photographs of the blades post-test. Such photographs were made of each inducer blade for each test of Table 3. The photographs are not ideal in that light reflections and dye streaking that occurred when the blade was originally coated can appear as dye removal when no such removal was experienced. Nevertheless, it is instructive to include representative photographs to verify the results. Photographs were taken of each of the four blades of the inducer after each of the tests of Table 3. Reproductions of all of the photographs would be an unnecessary expense, but a representative photograph from each test is shown in Figs. 16 through 26. A mirror was used behind the inducer to show the backside of the blades.

The effects of lighting and dye streaking on the photographic coverage are evident on some of the photographs. Figure 16 shows some evidence of streaking. Several photographs indicate streaking near the trailing edge of the blade, but this is due to the light reflection. The light reflection also presents a light spot near the junction of the blade and the hub at the blade leading edge. The tips of the blades were not coated to prevent smearing any dye on the plastic tunnel.

CONCLUSIONS

The testing of the model I.S.I.P. inducer with a concentric scaled tip clearance has been completed with the highest degree of success. The inducer met its design head and exceeded its design suction performance. The slope of the head-flow curve was consistent and negative over the full test range of ± 30 percent about design flow. The excellent suction performance was maintained over a wide flow range providing good NPSH margin to the impeller over this range. The life tests demonstrated the long-life characteristics of the design, indicating no evidence of dye removal due to cavitation from 95 to 130 percent of design flow and over a significant NPSH range. There was no dye removal under any of the test conditions tested on this inducer. Thus, the full-size pump can be tested in sodium with the highest confidence in its life characteristics.

Further testing of the model inducer with both an eccentric tunnel and with a reduced clearance concentric tunnel have been initiated but will be reported in a separate report.




APPENDIX M

MODEL INDUCER WATER TUNNEL
TEST REPORT - ECCENTRIC OPERATION

Rocketdyne Document R/H 9113-3756
(Assigned ESG Document number is N266TR000-004)

Figures 13 thru 36 have been removed from this document because they contain proprietary information, as defined by DOE contract.

 <p style="text-align: center; font-weight: bold; font-size: 1.2em;">SUPPORTING DOCUMENT</p>	<p>NUMBER N266TR000-004</p>	<p>REV LTR/CHG NO / - SEE SUMMARY OF CHG</p>								
<p>PROGRAM TITLE Intermediate-Size Inducer Pump</p>	<p>DOCUMENT TYPE Test Report</p>									
<p>DOCUMENT TITLE Model Inducer Water Tunnel Test Report - Eccentric Operation and Reduced Clearance Tests</p>	<p>KEY NOUNS Pump, Inducer, Model-Test</p>									
<p>PREPARED BY/DATE W. Rosemann (Rocketdyne, Div. 055)</p>	<p>DEPT 545-113</p>	<p>MAIL ADDR AC51</p>								
<p>IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO _____</p>	<p>GO NO 09280</p>	<p>S/A NO 23000</p>								
<p>APPROVALS T. J. Boardman <i>T. J. Boardman</i> R. V. Anderson <i>R. V. Anderson</i></p>	<p>ORIGINAL ISSUE DATE February 9, 1979</p>									
<p>DATE 5/14/79</p>	<p>PAGE 1 OF 66 TOTAL PAGES 66</p>									
<p>SECURITY CLASSIFICATION</p> <table border="0" style="width:100%;"> <tr> <td style="width:50%;">(CHECK ONE BOX ONLY)</td> <td style="width:50%;">(CHECK ONE BOX ONLY)</td> </tr> <tr> <td>UNCL <input checked="" type="checkbox"/></td> <td>RESTRICTED <input type="checkbox"/></td> </tr> <tr> <td>CONF <input type="checkbox"/></td> <td>DEFENSE INFO <input type="checkbox"/></td> </tr> <tr> <td>SECRET <input type="checkbox"/></td> <td></td> </tr> </table>			(CHECK ONE BOX ONLY)	(CHECK ONE BOX ONLY)	UNCL <input checked="" type="checkbox"/>	RESTRICTED <input type="checkbox"/>	CONF <input type="checkbox"/>	DEFENSE INFO <input type="checkbox"/>	SECRET <input type="checkbox"/>	
(CHECK ONE BOX ONLY)	(CHECK ONE BOX ONLY)									
UNCL <input checked="" type="checkbox"/>	RESTRICTED <input type="checkbox"/>									
CONF <input type="checkbox"/>	DEFENSE INFO <input type="checkbox"/>									
SECRET <input type="checkbox"/>										
<p>AUTHORIZED CLASSIFIER</p>		<p>REL. DATE 12/79</p>								

DISTRIBUTION			ABSTRACT
*	NAME	MAIL ADDR	
*	T. J. Boardman	LB08	<p>This report summarizes results of additional water tests performed on a six-inch diameter model of the inducer for the Intermediate-Size Inducer Pump</p> <p>The report contains descriptions of the test facility, instrumentation and methods of testing used to determine the cavitation performance, and to evaluate the life potential of the inducer with a fixed NPSH margin against cavitation. Test results show good suction performance over a wide range of flow conditions and support a high confidence in achieving good life characteristics (freedom from damage) when the full size pump is operated in sodium. Tests covered by this report are for eccentric operation of the inducer within the inducer tunnel and for operation with reduced inducer blade tip clearance. Initial, concentric test results are reported in N266TR000-002. This report was prepared by Rocketdyne (Div. 055) under IDWA N-1327 and released from that division under the number RI/RD79-192.</p>
*	R. Anderson	LB17	
*	J. Lockett	LB05	
*	J. Pfouts	JB05	
*	R. Hoshide	JB05	
*	C. Dunn	LB08	
	G. Hallinan	LB08	
	R. Schnurstein	LB17	
	E. Andrews	KB45	
	J. Page	LB03	
	C. Torrijos	LB26	
	D. Nelson	LB13	
	E. Baumeister	JB05	

RESERVED FOR PROPRIETARY/LEGAL NOTICES

This "proprietary" information is not to be used outside the contract with Rocketdyne for the purpose of enabling the test to be conducted. Employees of a plant shall be informed of these restrictions without restriction.

NOTE: Proprietary Information as defined in the contract with DOE has been removed from this document for use in N266ER000-001.

may not be used or except vent to anical order a, will r or an tractor pecific sta be source

* COMPLETE DOCUMENT
NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY



Rockwell International

Rocketdyne Division
6633 Canoga Avenue
Canoga Park, California 91304

RI/RD 79-192

INTERMEDIATE SODIUM INDUCER PUMP
MODEL INDUCER WATER TUNNEL TEST REPORT
INFLUENCE OF ECCENTRIC AND REDUCED
TIP CLEARANCE UPON PERFORMANCE

R/H 9113-3756

28 March 1979

PREPARED BY

W. Rosenmann
Rockwell International Corporation
Rocketdyne Division
6633 Canoga Avenue
Canoga Park, California 91304

APPROVED BY

J. E. Wolf
J. E. Wolf
Project Engineer
Sodium Pump Program

E. D. Jackson
E. D. Jackson
Manager
Hydrodynamics Unit

D. E. Davis
D. E. Davis
Program Manager
Dynamic Power Programs

PREPARED FOR

Energy Systems Group
Atomic International Division
Under IDWA No. N-1327
Authorized Under ESG Prime Contract EY-76-C-03-0824

This "proprietary data" furnished under Contract EY-76-C-03-0824 with the Department of Energy may not be used by the Government or the Argonne National Laboratory for purposes of manufacture or be disclosed or used outside the Government or the Laboratory for any purpose without prior permission of the Contractor; except that such "proprietary data" may be disclosed solely for evaluation

purposes, participation of those being ordered to Engineering considered event a is used to use Contr

NOTE: Proprietary Information as defined in the contract with DOE has been removed from this document to be used in N266ER000-001

manufacturers or developer than ver, in hnology ot be the acturer to such pportunity employee

to object to the specific pump manufacturer or specific of a pump manufacturer proposed for such use) under the restriction that the "proprietary data" be retained in confidence.

These restrictions do not limit the Government's rights to use or disclose any data obtained from another source without restriction. This legend shall be marked on any reproduction of this data in whole or in part.

TABLE OF CONTENTS

INTRODUCTION	1
TEST ARTICLE	4
TEST FACILITY	6
TEST INSTRUMENTATION	11
TEST PROGRAM	15
TEST RESULTS	18
CONCLUSIONS	60
REFERENCES	62


INTRODUCTION

The Intermediate-Size Inducer Pump (I.S.I.P.) was designed to operate in the existing FFTP pump housing and to achieve the required pump head rise at the same speed and flow as the existing pump. The existing pump consists of four basic hydrodynamic elements:

1. Inlet Elbow
2. Centrifugal Impeller
3. Vaned Diffuser
4. Discharge Housing

All of these elements except the centrifugal impeller were to be retained in an unmodified form for the I.S.I.P. design. The centrifugal impeller was to be replaced with a new design consisting of both an inducer and centrifugal impeller. The objective is to demonstrate the capability of designing an inducer pump for long life in sodium operation so that the advantages of the inducer pump can be realized in future sodium pump applications. These advantages consist primarily in the smaller envelope size and lower weight realized as a result of the better suction performance capability of the inducer. These advantages result in significant cost savings and ease of fabrication and handling for the very large pumps required in many of the reactor coolant loop systems.

Figure 1 shows a cross-section of the primary pump components. The most significant hydrodynamic challenge in the design is to achieve the long



N266R000-001
Page 729

Page 6
IN4001R000-004

FIGURE 1.

life in the inducer. To provide early confidence in the design before finalizing the fabrication and initiating testing of the full-size pump in sodium, a model of the inducer was fabricated for testing in the Rocketdyne water tunnel. The testing included both life and performance tests using a one-third scale model. The testing was successful and demonstrated both excellent performance and life characteristics for the Rocketdyne design. This report describes both the test program and test results.

TEST ARTICLE

The inducer design was based on the same practices established and demonstrated by the successful waterjet inducer design concepts developed by Rocketdyne. The primary dimensions of both the full-size and water model of the inducer are given in Table 1. As can be seen, the model is approximately a one-third scale version of the full-size. The model inducer is defined by drawing number EWR 344240.

This test article was installed in the test adapter as shown in drawing number EWR 344200. The test adapter consisted of an inducer shaft supported on the test rolling element bearings and splined to an impeller assembly. The impeller assembly, which was driven by the facility gearbox, provided the head requirements to circulate the fluid through the system.

Two new tunnels for the inducer were fabricated. The first was eccentric with 0.007 inch offset of the tunnel inside diameter centerline from the inducer shaft centerline. Radial tip clearance ranged from a minimum of 0.007 inch to a maximum of 0.021 inch. This range represents the scaled worst case of the full size manufacturing tolerance eccentricity. The second tunnel was concentric with the inducer with a reduced radial tip clearance of 0.008 inch compared with the nominal model radial tip clearance of 0.016 inch in Table I. The eccentric tunnel, EWR 360711, was fabricated from clear acrylic plastic, and the concentric tunnel, EWR 360739 was fabricated from aluminum alloy.

TABLE 1. I.S.I.P. INDUCER FEATURES

<u>PARAMETER</u>	<u>FULL-SIZE HARDWARE</u>	<u>WATER-MODEL HARDWARE</u>
No. of Blades	4	4
Tip Diameter, In.	18.53	5.986
Inlet Hub Diameter, In.	6.626	2.140
Disch. Hub Diameter, In.	11.358	3.669
Tip Radial Clearance, In.	0.050	0.016
Speed, RPM	1110	6322
Tip Speed, FPS	89.7	165.1
Design Flow, GPM	14,600	2803
Inlet Flow Coefficient	0.222	0.222
Disch. Flow Coefficient	0.310	0.310

TEST FACILITY

The testing was conducted at Rocketdyne's Pump Calibration Facility in Dept. 592. The pump was driven by a 1200 RPM, reversible, synchronous electric motor, which is rated at 4000 horsepower. The motor drives through a 4000 horsepower gearbox, which has two output shafts. One shaft is capable of producing speeds of 6322 and 8013 RPM. The other shaft is capable of producing speeds of 6322 and 10,029 RPM. The pump was run on the North powerhead (pump position No. 1) at 6322 RPM for this inducer test.

Figure 2 shows a schematic of the drive system and flow loop. An 8000 gallon water tank supplies water for the flow loop. This tank is rated at 150 psi with a vacuum capability of 28.5 inches of vacuum. The flow is measured by a turbine flow meter in the inlet line and regulated by a motor-operated throttle valve in the discharge line, whereas, the inlet pressure is regulated by controlling the tank pressure.

The inlet ducting consists of 8-inch schedule 40 steel piping, and the discharge loop is 4-inch diameter steel piping. All metallic coupling joints were heavily greased to assure an air tight system. An orifice was installed in the inlet line to keep the tank pressure up during cavitation tests to further avoid air leaks.





FIG. 2 Drive System and Flow Loop Schematic

The inducer is mounted on its shaft which is supported by its own bearing system as shown in drawing number EWR 344200. The inducer shaft is connected to an impeller shaft by a quill shaft. The impeller is an 11-inch tip diameter centrifugal impeller previously designed and fabricated at Rocketdyne and used in the current program as a slave impeller to generate the required head to provide the design flow of the inducer. The impeller is far enough downstream of the inducer to permit instrumentation to be inserted between the two for measuring inducer performance without impeller interference. The test arrangement is designed to establish the inducer performance characteristics as an independent component. The only drawback of this facility arrangement is that the only facility torquemeter available is located between the impeller and the drive gearbox. Thus, there is no way to separate the drive torque of the inducer from the slave impeller, hence no way to determine the efficiency of the inducer. This is not a significant problem because the overall sodium pump efficiency is determined during sodium pump tests and is primarily driven by the centrifugal impeller and discharge system rather than the inducer.

The impeller housing and shaft system was mounted rigidly to a steel frame to assure perfect alignment with the driving motor and, thus, avoid possible oscillation of the system. Testing verified that both the alignment and quill shaft arrangement were satisfactory to prevent any significant rotor dynamic vibrations in either the inducer or impeller.

The inducer was enclosed in a plastic viewing tunnel, which allowed both

photographic and visual observation of the cavitation characteristics of the flow through the inducer. The test setup is shown in Fig. 3.



FLOW →

MODEL INDUCER

SLAVE IMPELLER

FIGURE 3
PUMP TEST FACILITY FOR MODEL SODIUM
INDUCER

10



General Information

7XX3697937827A

TEST INSTRUMENTATION

Table 2 presents a list of the instrumentation used during the testing. Figure 4 shows the pressure tap locations in the tester and facility. The inlet pressure consisted of a 4-hole piezometer ring located 30 inches upstream of the inducer to avoid interference effects due to the inducer tip backflow. Downstream of the inducer, two total pressure (Kiel) probes were used to measure the discharge pressure at the mid-blade height position. These probes are subject to clogging due to solid material in the water, and the use of two probes provides more assurance of getting good data during the tests. Yaw probe surveys were carried out to provide flow and pressure data as a function of radius and will be reported separately. There were also numerous static pressures recorded along the tip over the inducer and at the inducer discharge. These were all single point static pressures and provide an indication of the head distribution through the inducer. Drawing number EWR 344205 shows the location of these taps with the same identification keys as used in Table 2. They are also shown in Fig. 4.

Other instrumentation included the turbine flowmeter and an accelerometer fastened to the viewing section to detect excessive vibrations. The electric motor speed is fixed during these tests. The torquemeter is omitted for this test series. Water temperature is measured in the inlet line to permit calculation of the water density and vapor pressure. The




FIGURE 4. GENERAL ARRANGEMENT OF PRESSURE PICKUP LOCATIONS

TABLE 2. INSTRUMENTATION

	<u>RANGE</u>
Inlet Static Pressure, Piezometer, PSIA	0 ± 100
Discharge Total Pressure, #1 Tunnel (A) ⁺ PSIG	0 ± 500
Flowrate, GPM	0 ± 4000
Speed, RPM	6322
Torquemeter, IN LB	0 ± 10,000
Water Temperature, °F	40 ± 140
Discharge Total Pressure #2 Tunnel (A) PSIG	0 ± 500
Pump Discharge Static Pressure, Pipe, PSIG	0 ± 500
Pump Delta Pressure, PSI	0 ± 500
Static Pressure, Tunnel (A) , PSIG	0 ± 100
Static Pressure, Tunnel (C) PSIG	0 ± 200
Static Pressure, Tunnel (D) PSIG	0 ± 200
Static Pressure, Tunnel (E) PSIG	0 ± 200
Static Pressure, Tunnel (F) PSIG	0 ± 200
Static Pressure, Tunnel (G) PSIG	0 ± 200
Static Pressure, Tunnel (H) PSIG	0 ± 200
Static Pressure, Tunnel (J) PSIG	0 ± 200

+ Circled letters refer to section locations on Drawing No. EWR 344205

other measured pressures are used for facility diagnostics and conducting of the tests.

All of the data are recorded by a digital acquisition system (Autodata 9 by Accurex) on a "floppy disk" which is transmitted post-test to a digital computer. The data are reduced to provide all pertinent data and calculated parameters by a data reduction program written specifically for the Pump Test Facility. The data are then printed in tabular form, and if desired, selected CRT (cathode ray tube) graphic printouts are obtained.

In addition to the recorded data, photographic techniques were used with strobe-light stop-action cameras to record the cavitation patterns during certain tests. These photographic records were then spliced together to form an annotated presentation of the results. Still photographs were also used post-test to record the dye patterns after running life tests (to be described).

TEST PROGRAM

The purpose of this test program was to conduct head-flow tests, cavitation tests, and dye tests for demonstrating the relative cavitation damage potential of the inducer at various radial tip clearance conditions.

Head-Flow Test

Head-flow tests were conducted with a constant inlet pressure of 65.0 psig which is sufficiently above the critical NPSH even at high flows to demonstrate non-cavitating inducer performance. Nine flowrates from 1962 GPM to 3644 GPM were run representing a variation from -30 to +30 percent about the design flow of 2803 GPM. Flow was varied by changing the control settings on the automatic flow control valve. Data samples were recorded on the Autodata 9 system at each specific flow when stabilization had been achieved.

Inducer Suction Performance

Inlet pressure was set initially at 80 to 85 psia and was allowed to decay continuously, while the flow was held constant, until the pump pressure rise decayed by 10 to 20 percent. The test sequence was performed at nine different flowrates ranging from 1962 to 3644 gpm. These latter extreme flow points represent ± 30 percent deviation from the design flow of 2803 gpm. Data were continuously recorded on the Autodata system during the pressure

decay. The purpose of these tests was to establish inducer suction performance with the modified tip clearance conditions.

Design Point Life Tests

After coating the inducer blades with a water-insoluble dye, twenty minute tests were performed at the design flow of 2803 GPM. With the eccentric tip clearance tunnel, three NPSH margins of 200, 100, and 50 percent above critical NPSH were used. With the concentric close tip clearance tunnel, the 200 and 100 percent NPSH margins were used. Twenty operating data samples were acquired during these steady parameter runs every five minutes to maintain a record of compliance with specified operating conditions.

The dye erosion tests using "Magic Marker" dye has been proven, through extensive use at Rocketdyne, to be an excellent means of locating areas of potential cavitation damage during relatively short duration tests and thus reduce the need to conduct many costly, long duration runs which involve actual metal damage.

Cavitation sensitive coatings for water tests had been used previously by other researchers (Ref. 1) in connection with tests for liquid metal pumps. They used various types of acrylic coatings and even cadmium plating.

Off-Design Life Test

These tests were conducted in the same manner as the Design Point Life Tests

described above. Nine more tests were conducted with the eccentric tip clearance setup, and six more tests were conducted with the reduced tip clearance setup. NPSH margins ranged from 20 to 200 percent. Data acquisition during these runs was identical to that used during Design Life Tests.

TEST RESULTS

All of the data presented in this report are based on water tests. Long term experience at Rocketdyne has demonstrated that water tests give excellent predictability of pump performance with other liquids if proper conversion factors such as specific weight and vapor pressure are used to calculate the behavior with the other fluids.

Inducer Head-Flow Performance,

Figure 5 shows the head rise for the model inducer with two different tip clearances. The test data for the eccentric tip clearance setup were almost identical to the data presented in Fig. 4 of Ref. 2 in which the same inducer was tested with a concentric tip clearance of .016 inch. In the reduced tip clearance setup, the head rise was slightly higher at design flow and above design flow. Below design flow, the head rise was slightly lower with the reduced tip clearance. The reduced clearance will result in less tip clearance flow and would be expected to lower the tip clearance losses. This would result in slightly higher head and efficiency. No explanation can be given for this curve crossover. Some scattering of data for the head rise values was encountered during the test series. The values shown in this graph were extracted from H-Q runs, high NPSH portions of cavitation runs, and life tests. Figure 6 presents the head-flow for the full-sized inducer using eccentric tip clearance. The performance calculation was based on model inducer data. The impeller has the capability

MODEL ISIP INDUCER
INDUCER HEADRISE VS. FLOW *
N = 6322 RPM
TIP DIA. 5.984





FIGURE 5

ISIP INDUCER
N = 1110 RPM
D_t = 18.53 IN.

ECCENTRIC TIP CLEARANCE
.068 MAX
.025 MIN



N266ER000-001
Page 747

N2661R000-004

FIGURE 6

of functioning normally without serious cavitation problems with this inducer performance. Based on these tests, it is clear that neither the eccentricity nor the reduced clearance had any significant effect on the non-cavitating head rise of the inducer.

Inducer Suction Performance

The suction performance of the inducer using the eccentric tip clearance tunnel is shown in Fig. 7. The curve shows suction specific speed versus Q/Q_{Design} . The latter represents the ratio of actual flow divided by design flow. Two values of head fall-off were used to determine the critical NPSH from which the suction specific speed was calculated. The numerical difference between the two suction specific speed curves amounted to only about three percent. This indicates a sharp head loss near the critical NPSH which is characteristic of well designed inducers. This characteristic can also be seen on the CRT graphic p_{Tot} in Fig. 8. The data shows a stable head rise down to just above the critical NPSH and then a sharp head loss below that point.

For the ISIP inducer, the critical NPSH values were conservatively assumed to be at 15 percent head fall-off. At this operating point, the impeller usually compensates for most of the inducer head loss by increased head rise within the impeller. Figure 9 shows the suction specific speed versus flow ratio for concentric normal tip clearance (from Ref. 2), eccentric normal tip clearance, and concentric reduced tip clearance.

At design flow and above, the three curves have only slight differences. At 70 percent to 90 percent of design flow deviations occurred between the

MODEL INTERMEDIATE SODIUM
INDUCER PUMP (ISIP)

6322 RPM

TIP DIA. = 5.986 INCH

$Q_{DESIGN} = 2803$ GPM

ECCENTRIC TIP CLEARANCE: .021 MAX
.007 MIN




FIGURE 7




FIGURE 8. CRT GRAPHIC DISPLAY SHOWING HEAD RISE VS. NPSH
TIP CLEARANCE ECCENTRIC MIN. .007 IN. - MAX .021 IN.
FLOW: 100 PERCENT OF DESIGN FLOW

ISIP MODEL INDUCER
WATER TEST RESULTS




FIGURE 9
24

three curves. The eccentric clearance setup exhibited somewhat better suction performance at the lower flows.

The reduced tip clearance setup also improved suction performance at flows below design flow. This result conforms with tests on other inducers.


At flows below approximately 85 percent of design flow there is an increase in tip leakage which flows opposite to the main flow direction and has an angular whirl velocity which is approximately one-half the inducer angular velocity. It mixes with the oncoming flow and imparts some angular velocity to it. This pre-whirl plus other flow disturbances usually cause a degradation in suction performance. Any tip clearance reduction which reduces this back flow improves the suction performance.

Inducer Internal Performance

In addition to the upstream piezo ring, static pressure tap, and the downstream kiel total pressure probe, the test instrumentation consisted of wall static pressure taps which were located at various axial and circumferential locations between the leading and trailing edges of the inducer as shown in Fig. 4. The data obtained from these pressures are presented in Fig. 10 and 11.

Figure 10 shows data obtained during an H-Q run. The inlet pressure was high enough to prevent cavitation head loss at all flows which were tested. At design flow, the measured head rise increased almost linearly from the

ISIP MODEL INDUCER
PRESSURE TAP LOCATIONS



leading edge to within 0.50 inch of the trailing edge measured axially along the tip. Aft of this point the rate of pressure rise gradually diminished to zero.

The performance was in full agreement with theoretical predictions based on a quasi-three-dimensional mathematical model. The negative pressure which occurs at station J is due to hub blockage which causes a static pressure drop as compared to conditions which prevail in front of the inducer.

It may also be noticed that the front part of the inducer (between the leading edge and station H) performs like a turbine at flows above Q/Q_{Design} equals 1.10. A survey of the theoretical blade incidence angles leads to an expectation of zero or negative pressure rise at high flows in this area.

Figure 10 also shows predicted pressure rise at design flow based on quasi-three-dimensional analysis.

The predicted data show a sharp pressure drop just aft of the leading edge. This curve dip is primarily due to the limitations of the math modeling analysis but is partially explained by a rapid rate of increase in blockage just aft of the leading edge without a corresponding change in blade angle. This dip could not be defined precisely by experimental data due to lack of a pressure tap at the affected axial location.

Figure 11 shows the data obtained during a cavitation run at design flow.

STATIC PRESSURE RISE VS INLET NPSH
AS MEASURED ALONG VARIOUS AXIAL LOCATIONS
MODEL ISIP INDUCER - EXPERIMENTAL DATA




FIGURE 11

It confirms performance predictions that, at certain operating conditions just above the critical NPSH, the decreased head rise due to partial cavitation in the front part of the inducer is fully compensated by increased head rise in the aft part of the inducer. This phenomenon occurs in this test approximately between inlet NPSH values of between 45 and 60 feet. The reason for the rise in pressure above the non-cavitating pressure at stations G and H cannot be ascertained at this time. One possible reason is that localized increased pressure rise may occur just aft of the trailing boundary of the blade suction side cavity.

The most useful data shown in Figure 11 reveals that cavitation of sufficient magnitude to effect a shift in wall static pressures occurs at 120 feet of NPSH which is 200 percent above the critical NPSH of 40 feet at design flow.

An examination of the data at 80 percent of design flow shows that this pressure shift near the front part of the inducer also first occurs at approximately 200 percent above the critical NPSH.

Further examination of the data at 120 percent of design flow shows that this pressure shift between critical NPSH and 200 percent above critical NPSH virtually disappears since the forward part of the inducer has only a small head rise even in the non-cavitation operating regime.

Motion Picture Test Data

During the cavitation testing, photographic movies were taken to permit


observation of tip vortices and blade cavities as inlet pressure was being reduced. Tip vortices could easily be seen but blade suction side cavities were very difficult to observe due to turbulence. The pulse camera took approximately one picture for each five inducer revolutions. A pressure gage was mounted within the picture to provide direct correlation between inlet pressure and vortex generation. Figure 12 presents the ratio of the head divided by the non-cavitating head as a function of inlet pressure and NPSH with flags to indicate where the still photographs were taken. The photographs in this report include only those which were taken during the design flow run and are shown in Figures 13 through 16.

Life Test Results

Tests by other researches have shown that cavitation damage caused by collapsing vapor bubbles on the pump rotor surface is less in water than in sodium. The magnitude of the variation has been quoted at different levels ranging from two orders of magnitude (Ref. 3) to a factor of approximately 3.0 (Ref. 4). Part of this difference was compensated for in the water tests of the model by testing at a higher inducer tip speed. Laboratory measurements of the effect of tip speed have not been totally consistent, but the majority of the data appear to support the dependency of damage on the sixth power of the velocity. The model inducer was tested with a tip speed of 165.1 feet per second (fps) compared to 89.7 fps for the full-size pump in sodium. Using the sixth-power relationship, this is equivalent to a damage rate 39 times faster due to the higher tip speed of the model.

HEAD
NON CAVITATING HEAD

ISIP MODEL INDUCER
WATER TEST RESULTS



However, the advantage of performing life tests with dye coatings is that the test is not attempting to identify and/or match damage rates. No attempt is made to measure the extent of damage and scale the rate to predict rate of failure of the full-size hardware. The dye test is designed to identify any potential region of cavitation damage regardless of rate. It takes very little time for a cavity bubble collapsing on the blade to remove the dye. Therefore, for a long-life design, no dye removal would be expected, and the dye test would have to verify that condition. Rocketdyne's design approach is to design to eliminate any cavitation collapse on the inducer blades over the operating range.

Tables 3 and 4 present the various operating conditions tested with dye, indicating both the target and actual test conditions. The flow was varied from approximately 70 to 130 percent of design flow, and the NPSH margin was varied for some flows. There was no dye removal above 80 percent of design flow, substantiating the long-life design features of this inducer. In fact, the I.S.I.P model inducer showed a greater flow range for no dye removal due to cavitation than any previous inducer tested to date. The dye tests would indicate that long life could be expected in the sodium testing for flows varying from 90 to 130 percent of design flow and over a significant NPSH range. This provides the very highest confidence in the sodium testing, particularly considering the large difference in tip speeds between model and full-size.

The only way to document the results of the dye tests is through photographs of the blades post-test. Such photographs were made of each inducer

TABLE 3. MODEL I.S.I.P. SODIUM INDUCER DYE TESTS IN WATER

BUILD	TARGET VALUES				TEST RESULT VALUES				FIGURES
	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	PERCENT NPSH MARGIN	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	PERCENT NPSH MARGIN	
ECCENTRIC	2803	1.00	43.3	200	2789	1.00	43.0	198	17
	"	"	27.0	100	2798	"	28.4	109	18
	"	"	18.8	50	2799	"	19.9	57	19
	2663	0.95	39.4	200	2684	0.96	40.2	205	20
	2523	0.90	37.0	200	2525	0.90	38.8	213	21
	2242	0.80	37.0	200	2246	0.80	38.3	210	22
	3083	1.10	54.5	200	3082	1.10	54.3	199	23
	3083	"	34.0	100	3081	"	34.3	101	24
	3364	1.20	48.3	100	3369	1.20	48.3	100	25
	3364	"	34.1	50	3366	"	34.4	51	26
	3644	1.30	67.0	50	3666	1.31	67.2	50	27
	3644	"	51.6	20	3660	"	52.9	22	28

TABLE 4. MODEL I.S.I.P. SODIUM INDUCER DYE TESTS IN WATER

BUILD	TARGET VALUES				TEST RESULT VALUES				
	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	NPSH MARGIN	FLOW (GPM)	Q/Q _{DESIGN}	INLET PRESSURE (PSIA)	NPSH MARGIN	FIGURES
CONCENTRIC REDUCED TIP CLEAR. OF .008 IN.	2803	1.00	43.3	200	2799	1.00	43.9	204	29
	2803	1.00	27.0	100	2804	1.00	28.2	108	30
	2663	0.95	39.4	200	2664	0.95	41.9	217	31
	2523	0.90	37.0	200	2514	0.90	37.9	206	32
	2242	0.80	37.0	200	2234	0.80	38.1	208	33
	3083	1.10	54.5	200	3081	1.10	55.0	202	34
	3364	1.20	48.3	100	3371	1.20	48.6	101	35
	3644	1.30	67.0	50	3660	1.31	66.7	50	36

blade for each test (Table 3). The photographs are not ideal in that light reflections and dye streaking that occurred when the blade was originally coated can appear as dye removal when no such removal was experienced. Nevertheless, it is instructive to include representative photographs to verify the results. Photographs were taken of each of the four blades of the inducer after each of the tests of Table 3. Reproductions of all of the photographs would be an unnecessary expense, but a representative photograph from each test is shown in Figures 17 through 37. A mirror was used behind the inducer to show the backside of the blades.

Many pictures have large white areas on the inducer. These white areas are due to light reflection of the photographers flash from the glossy inducer surface. The tips of the blades were not coated to prevent smearing of dye on the plastic tunnel. In many cases the inducer blades suffered accidental scratch marks due to foreign matter, such as scale, circulating within the water tunnel loop. These scratch marks are not to be confused with erosion due to cavitation action. A typical effect of this scratch erosion may be seen in Figure 36.

In contrast a typical example of dye erosion due to cavitation action may be seen in Figure 22. Cavitation erosion was expected to occur during this test since the flowrate was maintained at 70 percent of design flow.

CONCLUSION

The test program discussed in the Rocketdyne report Ref. 2 revealed that the I.S.I.P. inducer has exceeded all design objectives if installed concentrically with the housing and using a scaled down concentric tip clearance. The test program in this report has revealed that if the model size inducer is mounted eccentrically by approximately 0.007 inch due to manufacturing tolerance buildup, the performance of the inducer will not degrade or be subject to increased cavitation action as demonstrated by the test data shown in this report.

This test program also consisted of an experimental setup in which the I.S.I.P. inducer tip clearance was reduced by approximately 50 percent to .008 inch and concentric. The resulting slight improvement in head rise performance could be considered negligible in the overall pump performance.

There was an improvement in suction performance at 70 percent to 80 percent of design flow. However in this operating regime blade dye removal occurred and the inducer should not be operated for extended periods in this flow range. Severe rubbing marks were discovered in the aluminum sleeve after disassembly of this close tip clearance setup. This does not necessarily signify that rubbing would also occur in the complete pump since the latter may have greater shaft rigidity. However, in the overall picture, it appears that the slight gain in inducer performance does not warrant the increased risk of inducer rubbing against the housing bore. The life tests for the reduced tip clearance installation showed virtually no difference

in cavitation action on the inducer as compared to the normal tip clearance installation as evidenced by dye removal tests.

REFERENCES

1. G. M. Wood, R. S. Kulp, J. V. Altieri, Jr., Pratt & Whitney, "Aircraft-CANEL Symposium on Cavitation in Fluid Machinery", November 1965.
2. E. D. Jackson, Rockwell International, Rocketdyne Division, "Intermediate Sodium Inducer Pump Model Inducer Water Tunnel Test Report", R/H 9113-3741, 9 February 1979.
3. Y. S. Cha and R. L. Miller, "Comparative Studies of Cavitation Inception and Damage in Water and Sodium Using Venturis," Proceedings of Joint Symposium on Design and Operation of Fluid Machinery, Vol. II, June 1978 Symposium at Colorado State University, Fort Collins, Colo., sponsored by ASCE, IAHR/AIHR, ASME
4. Y. S. Cha and P. R. Huebotter, "Final Report and Design Guide for Cavitation-Free LMFBR Hydraulic Components" Technical Memorandum, ANL-CT-78-7, October 1977.