MICHIGAN REGULATORY INCENTIVES STUDY FOR ELECTRIC UTILITIES

JUNE 17, 1991

**COMMITTEE ON
ENERGY CONSERVATION**

**National Association of
Regulatory Utility Commissioners
Room 1102 ICC Building; P.O. Box 684
Washington, D.C. 20044**

Telephone No. (202) 898-2200

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors herein do not necessarily state or reflect those of the United States Government or any agency thereof.

180 Grand Avenue, Suite 1090
Oakland, CA 94612
(415) 893-7800
FAX (415) 893-1321

BARAKAT & CHAMBERLIN, INC.

Oakland
Washington, DC
Toronto

THE MICHIGAN REGULATORY INCENTIVES STUDY FOR ELECTRIC UTILITIES

Phase I Final Report

Submitted to:
Study Policy Group
Michigan Regulatory Incentives Study

Submitted by:
Michael W. Reid
Edward M. Weaver
BARAKAT & CHAMBERLIN, INC.

April 25, 1991

P1326/final.rpt/4-25-91

MACTED

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CONTENTS

Executive Summary	v
I. Introduction	1
II. Current Regulatory Practices in Michigan Affecting Utilities' Resource Selection	7
III. Preliminary Analysis of Incentive Options	21
IV. Detailed Analysis: Capitalization	45
V. Detailed Analysis: Electric Revenue Adjustment Mechanism (ERAM)	60
VI. Detailed Analysis: Shared Benefits	77
VII. Conclusions and Recommendations	92
References	96
Appendix: Financial Models	

EXECUTIVE SUMMARY

This is the final report of Phase I of the Michigan Regulatory Incentives Study for Electric Utilities, a three-phase review of Michigan's regulatory system and its effects on resource selection by electric utilities. The study is a joint effort involving representatives of the Public Service Commission staff, Detroit Edison Company, Consumers Power Company, and major intervenors, who collectively comprise the Study Policy Group. Barakat & Chamberlin prepared this report in its role as consultant to the Study Policy Group.

The goal of Phase I is to identify and analyze financial incentive mechanisms that encourage selection of resources in accord with the principles of integrated resource planning (IRP) or least-cost planning (LCP). Subsequent study phases will involve further analysis of options and possibly a collaborative formal effort to propose regulatory changes.

Interest in incentives to influence utilities' resource selection is an outgrowth of IRP, which seeks to consider all utility resource options on an equal footing. In the late 1980s, concerns arose that traditional regulation biases utilities against use of demand-side management (DSM) and other alternatives to construction of new generating plants. Unless the disincentives were removed, it was argued, the social and economic benefits of IRP might not be realized. With urging from NARUC's Energy Conservation Committee, many state commissions began studying the issue; since 1989, several have created financial incentives for DSM.

The Phase I analysis proceeded in three steps: (1) identification and review of existing regulatory practices that affect utilities' selection of resources, particularly DSM; (2) preliminary analysis of ten financial incentive mechanisms, and selection of three for further study; (3) detailed analysis of the three mechanisms, including consideration of how they could be implemented in Michigan and financial modeling of their likely impacts on utilities and ratepayers.

CURRENT REGULATORY PRACTICES

Barakat & Chamberlin focused on three areas that affect selection of DSM resources: recovery of DSM program costs, treatment of revenue losses resulting from DSM programs, and impacts on utility profitability. Existing DSM programs are funded through a surcharge applied to all energy sales. Special proceedings

apart from general rate cases are used to establish surcharges and ultimately reconcile collections with expenditures. While this system provides steady funding and mitigates the risk of nonrecovery, it is not very flexible, as the surcharges are fixed for multiyear periods.

Regulatory proceedings in Michigan tend to be of long duration, often involving extensive litigation and/or negotiation toward a settlement. Any efforts to encourage DSM through a revised cost recovery mechanism would have to take account of this fact. Another important consideration for potential revisions to cost recovery policies is Michigan's experience with mechanisms that automatically adjust rates to account for changes in utility costs. Two such mechanisms were abandoned in the early 1980s when they fell into disfavor with ratepayers.

Like most states, Michigan does not have any policies or mechanisms to offset the DSM-induced loss of base revenue between rate cases. This issue has been raised in recent proceedings by both Consumers Power and Detroit Edison. While the lost revenue problem is mitigated somewhat by Michigan's use of a future test year for ratemaking, it may still deter expansion of DSM, especially if rate cases do not occur annually.

In 1990 an experimental, performance-based DSM incentive mechanism was established for four of Consumers Power's energy conservation programs. The company collects a bonus, computed on a sliding scale, for each kilowatt-hour saved above target levels. While the incentive is of some benefit to Consumers, it does not make conservation a profitable activity, since the contribution to earnings would be greater if the electricity were sold rather than conserved. It does, however, represent a significant precedent and signals the commission's willingness to link earnings to DSM performance.

PRELIMINARY ANALYSIS OF INCENTIVE MECHANISMS

The second step of the study involved a preliminary analysis of ten possible incentive mechanisms, drawn from reviews of literature in the field and proposals advanced in other states. The options considered, grouped by the areas they address, were:

- Cost Recovery Options
 - Expensing with balancing account reconciliation
 - Capitalization
- Lost Revenue Options
 - Lost revenue adjustment
 - Electric revenue adjustment mechanism (ERAM)
 - ERAM per customer
- Profitability Options
 - Bonus return on certain capitalized expenditures
 - Bonus return on overall rate base
 - Unit price payment
 - Shared benefits
 - Markup on expenditures

Each mechanism was considered in relation to twelve criteria established by the Study Policy Group:

- *Benefits.* What existing problems or disincentives does this alternative rectify, and how well does it address them?
- *Potential Applicability.* Is this alternative applicable to all utilities and resource options?
- *Precedents.* Are there precedents in Michigan for this alternative or related mechanisms? Has this alternative been proposed or implemented in other jurisdictions?
- *Performance Basis.* Is this alternative linked to measurement of performance? Does it reward exemplary performance in integrated resource planning and selection?
- *Use of Positive Motivation.* Does the alternative create a positive motivation (financial or otherwise) to adhere to IRP principles, or does it motivate by threat?

- *Potential Rate/Revenue Requirement Impact.* To what extent might this alternative exert upward pressure on rates? How would these impacts be distributed?
- *Treatment of Externalities.* Does this alternative accommodate consideration of environmental and other external costs?
- *Ease of Regulatory Implementation.* How difficult would it be to effect this change? Would statutory changes be required?
- *Ease of Administration/Operation.* How burdensome would administration of this alternative be for utilities? For the Public Service Commission?
- *Relationship to Other Alternatives.* How easily could this alternative be teamed with other alternatives under consideration? Would conflicts arise if other alternatives were also implemented?
- *Potential for "Gaming."* Could this alternative be manipulated by any party in a way that would distort its purpose?
- *Risks.* What risks might follow from selecting this alternative, and who bears them?

The Study Policy Group then selected one option in each category for more detailed study:

- Capitalization
- ERAM
- Shared benefits

In selecting these three options, the Study Policy Group was *not* expressing its collective preferences for mechanisms that should be implemented in Michigan. The group did feel that concentrating the detailed analysis on these options would represent the best use of the study's limited resources and would provide important information for subsequent study phases.

DETAILED ANALYSES OF CAPITALIZATION, ERAM, AND SHARED BENEFITS MECHANISMS

The third step focused on whether and how each mechanism could be implemented in Michigan, the expected effects on resource selection, and the likely financial impacts. Financial modeling was performed using spreadsheet models developed for the study. Model inputs were prepared jointly by the study's utility participants to represent a hypothetical, composite Michigan utility.

Capitalization

Capitalization is a cost recovery method in which an expenditure is amortized, or charged to ratepayers, over a multiyear period, while the utility earns a return on the unamortized balance. As the cost recovery treatment normally applied to generating plants, it has frequently been proposed for DSM as a means of leveling the playing field on which resource choices are made.

Our analysis concluded that capitalization of DSM could be undertaken in Michigan at the PSC's direction. Implementation requirements are significant but manageable. However, while capitalization has a certain theoretical appeal, it may be disadvantageous to utilities because it increases the risk of incomplete cost recovery. Further, taxes that would be collected on the return component necessitate higher average utility rates.

For the foreseeable future, we believe the need for adequate DSM cost recovery in Michigan would be best served by a flexible form of expensing that would adjust receipts up or down in line with expenditures. This approach could be achieved through modification of the current conservation surcharge system.

ERAM

An Electric Revenue Adjustment Mechanism, or ERAM, periodically reconciles the utility's actual base revenue to authorized base revenue. It automatically adjusts for revenue losses from DSM or self-generation. ERAM eliminates any short-term financial gain to the utility from sales promotion, and also offsets weather- and economic-related revenue fluctuations.

Financial modeling demonstrates that ERAM would likely give utilities greater revenue and earnings stability than they enjoy under current regulation. They would retain the ability to earn profits in excess of their allowed rate of return by cutting costs below the level authorized in the general rate case, as updated through ERAM proceedings. Actual earnings would depend heavily on the adjustments made to authorized base revenue between rate cases.

Utilities in California, having operated under ERAM for several years, support the mechanism, but most utilities in other states are wary. Some regulators and many intervenors are wary also, because ERAM shifts certain risks now borne by utilities to ratepayers.

Applying ERAM in Michigan would require major regulatory changes and would add new proceedings to an already crowded regulatory docket. Substantial technical issues related to the adjustment of base costs would have to be addressed. In light of Michigan's reversal on various cost and profitability adjustment mechanisms in the early 1980s, an effort to implement ERAM may meet with significant public opposition.

Shared Benefits

The shared-benefits, or shared-savings, approach to providing a bonus above costs for DSM has been adopted in several states. It gives the utility a bonus equal to a percentage of the savings that result when DSM is chosen over conventional supply-side resources. It is intuitively understandable and directly links utility earnings to DSM performance.

If coupled with an adjustment for DSM-related lost revenue, a shared-benefits incentive should make DSM a more attractive resource option. Whether it would be sufficient to compensate the utility for the perceived risks of selecting a particular resource would depend on the size of the share retained by the utility.

Since there is already precedent in Michigan for a performance-based DSM bonus, implementing a shared-benefits bonus should not require any significant legal or regulatory changes. There would, however, have to be a strong system for continuing evaluation of the benefits and costs of selected resources.

RECOMMENDATIONS FOR PHASE II

The original study plan envisioned that in the next phase Consumers Power and Detroit Edison would conduct independent assessments of the three options considered in detail in this report. We urge the Study Policy Group to consider whether the list of options to be focused on in Phase II should be altered or expanded. More specifically, we suggest that:

- Unless there is strong interest in capitalization, the mechanics and legal requirements of expensing-type cost recovery options be further explored.
- The viability of ERAM be carefully weighed in light of its substantial implementation requirements and possible ratepayer opposition. If the viability of ERAM appears doubtful, the Study Policy Group should concentrate its further efforts on analysis of resource-specific lost revenue adjustments.

I. INTRODUCTION

This is the final report of Phase I of the Michigan Regulatory Incentives Study for Electric Utilities, a three-phase review of Michigan's regulatory system and its effects on resource selection by electric utilities. Barakat & Chamberlin has prepared this report in its role as consultant to the study participants, who include regulatory, utility, industrial, and consumer representatives. Financial support for the study has been provided by the National Association of Regulatory Utility Commissioners (NARUC), the Michigan Public Service Commission (Michigan PSC), Detroit Edison Company, and Consumers Power Company.

The goal of Phase I is to identify and analyze financial incentive mechanisms that encourage selection of resources in accord with the principles of integrated resource planning (IRP) or least-cost planning (LCP). In Phase II, Michigan's two largest electric utilities, Consumers Power and Detroit Edison, will evaluate independently the suitability and financial impacts of the options analyzed in Phase I. In Phase III, the study participants will explore whether consensus is sufficient for a collaborative formal effort to change the financial determinants of utilities' selection of resources.

THE CONTEXT FOR REGULATORY INCENTIVES

National Context

Interest in providing financial incentives to influence utilities' resource selection is not a new phenomenon. As early as 1980, the Washington state legislature directed that utilities be granted a bonus rate of return on investments that were "reasonably expected to save, produce, or generate energy at a total incremental system cost . . . [that was] less than or equal to the [cost of energy from] conventional energy resources which utilize nuclear energy or fossil fuels" (Wash. Rev. Code Sec. 80.28.025 [1980]). Similar legislation creating financial incentives for energy conservation and alternative resources was adopted in the early 1980s in Kansas and Montana.

More recent interest in financial incentives, however, stems from the mid-1980s development of a new utility planning paradigm known as integrated resource planning or least-cost planning. IRP promised to minimize the costs of energy services (light, thermal comfort, torque, etc.) by expanding the menu of resources

to include "demand-side" resources (for example, investments in energy-efficiency technologies) and nontraditional "supply-side" options (for example, purchases from nonutility power producers).

By 1988, 17 states were practicing some form of IRP, and a majority of states was moving in that direction (Electric Power Research Institute 1988). The practice of IRP varies widely; indeed, there is no generally accepted definition of exactly what constitutes IRP. A typical expression of IRP principles is found in the following statement, taken from a voluntary agreement between Detroit Edison and the Michigan PSC:

An integrated resource plan (IRP) should consider all reasonable resource options for balancing future electricity supply and demand. IRP takes supply- and demand-side options equally into consideration and emphasizes the need to consider multiple criteria and various trade-offs when selecting combinations of resource options for implementation. In evaluating the merits of various combinations of options, IRP considers their comparative total cost, reliability, flexibility, risk, and uncertainty. IRP also takes into consideration the broader social, economic and environmental consequences that might result from implementing various options combinations (quoted in Michigan PSC Staff 1990).

Not stated in the above definition, but inherent in the practice of IRP in a regulatory context, is public disclosure and discussion of a utility's resource plan. IRP opens significant portions of the utility's planning function to scrutiny by regulators and other interested parties.¹ While utilities have traditionally taken a multidimensional approach to planning, and many have long considered demand-side resource options, adoption of an IRP framework implies that a utility's approach to planning will become much more explicit and public.

IRP requires new methodologies for comparing the costs of resources. In this context, regulators and industry analysts focused on the question of whether demand-side management (DSM) and supply-side resources were competing on a level playing field; that is, whether existing methodologies were biased. Some observers went further and questioned whether it was the structure of regulation (rather than just the analytical methodologies) that tilted the playing field

¹Many states require that IRP plans be specifically approved by regulators (after revisions, if necessary) and that utility procurement of resources be consistent with an approved plan.

financially in the favor of traditional supply-side resources, in effect creating financial *disincentives* to alternative resource options.²

Meanwhile, some states were experimenting with financial incentives to encourage demand-side management. In Wisconsin, for example, a 1986 order re Wisconsin Electric Power Company authorized ratebase treatment of a major (\$73 million) investment in DSM and provided a bonus return for the achievement of peak-demand-reduction goals (Docket No. 6630-UR-100, December 30, 1986).

The visibility of the incentives issue increased considerably in April 1988 when David Moskowitz, at the time a member of the Maine commission, addressed NARUC's first least-cost planning conference. Moskowitz's theme, in a nutshell, was that, "without significant reforms to the ratemaking system, least-cost planning is going nowhere" (Moskovitz 1988). In response, the NARUC Energy Conservation Committee investigated the effects of conventional regulation on utilities' economic motivation to follow IRP principles in their selection of resources. In July 1988 the committee adopted a policy statement urging state commissions to

... adopt appropriate mechanisms to compensate a utility for earnings lost through the successful implementation of demand-side programs which are part of a least-cost plan and seek to make the least-cost plan a utility's most profitable resource plan (Energy Conservation Committee 1988).

The NARUC resolution catalyzed many state regulatory commissions to begin studying the issue. Some utilities also began to formulate proposals for financial incentives. Since 1989, developments have proceeded apace. As of February 1991, financial incentives affecting LCP and DSM are being addressed in at least 27 states and the District of Columbia. These activities take one or more of the following forms:

- Initiation of a study, collaborative process, or generic proceeding on incentives;
- Consideration of legislation to remove regulatory barriers or provide financial incentives;

²See, for example, Counihan (1986).

- Formulation and submittal of a specific proposal by a utility or by a commission staff; or
- Enactment of a specific mechanism.

The issue will almost certainly remain prominent for the next several years. The substantial excess generating capacity of parts of the United States will largely disappear by the late 1990s; as a consequence, many more states will be trying to ensure that selection of new resources is consistent with IRP principles. The 1990 Clean Air Act Amendments offer the possibility of additional emission allowances for utilities in states that have removed the financial disincentives to utility-sponsored energy conservation efforts (Public Law 101-549, 1990). Congress is considering additional legislation that would broaden the federal interest in ensuring that efficiency investments are profitable for utilities.

Michigan Context

Integrated resource planning, as carried out through a process open to public scrutiny, is in its early stages in Michigan. Detroit Edison and Consumers Power submitted their initial IRPs to the PSC during 1989 and 1990, respectively, and will continue to submit plans biennially. The staff reviews and comments on the report, but the PSC does not formally approve or disapprove a utility's plan. The PSC has stated, however, that in the future a utility's annual filing of projected fuel and purchased-power costs must be derived from, and consistent with, the most recently filed IRP (Order in Case U-9172, March 29, 1990).

Commission interest in incentives derives, in part, from a concern that Michigan utilities' resource planning makes insufficient use of demand-side options. The staff's review of Detroit Edison's IRP, for example, said the company's use of DSM resources is "disappointing" (Michigan PSC Staff 1990).

According to Detroit Edison's and Consumers Power's IRPs, new DSM resources added between 1990 and 2000 will reduce peak demand in 2000 by approximately 1.3% (Detroit Edison 1989b) and 1.1% respectively (Consumers Power 1990). For this same period, a study for the Electric Power Research Institute estimated that for the nation as a whole, new (post-1990) DSM resources will reduce peak demand by 3.7% (Faruqui et al. 1990). While such data must be interpreted with considerable caution, they suggest that Michigan is behind national trends in this area.

As will be discussed in Chapter II, Michigan has employed a variety of strategies to influence utilities' resource selection, including limited experimentation with DSM incentives, but to date has not sought systematically to expand utilities' reliance on DSM or provide financial motivation for IRP.

THE MICHIGAN REGULATORY INCENTIVES STUDY

The Michigan Regulatory Incentives Study is one of the many efforts noted above that are addressing financial incentives for IRP and resource selection. It uses the case study method to examine resource selection in Michigan, and ultimately to make recommendations for any changes needed to promote balanced selection of resources. It is hoped that the study's lessons will be valuable in Michigan and other states considering the same issues.

Major funding for Phase I of the study was provided by NARUC under its Least-Cost Utility Planning Grant from the U.S. Department of Energy. Co-funding was provided by the Michigan PSC, Detroit Edison, and Consumers Power.

Overall direction for the study is provided by the Study Policy Group, consisting of representatives of the Strategic Planning Division of the Michigan PSC staff, Detroit Edison, Consumers Power, the Michigan Department of Attorney General, and ABATE (Association of Businesses Advocating Tariff Equity), a coalition of major industrial energy users. The Michigan PSC staff serves as the study's administrative manager.

STUDY TASKS

Phase I of the study has proceeded in three major steps. In the first step, Barakat & Chamberlin reviewed existing Michigan regulatory practices that affect electric utilities' selection of resources, with a focus on DSM. Barakat & Chamberlin also developed a preliminary list of financial mechanisms that could be implemented in Michigan to overcome the disincentives affecting some resource options and possibly provide a positive profitability incentive for selection of least-cost resources.

In the second step, Barakat & Chamberlin developed descriptions and evaluations of ten financial incentive mechanisms. The Study Policy Group then selected three of the mechanisms for more detailed study.

The last step encompassed detailed analysis of the three mechanisms, including consideration of what would be required to implement them in Michigan and financial modeling of their potential effects on utilities and ratepayers.

ORGANIZATION OF THIS REPORT

Subsequent chapters mirror the steps of the study as described above. Chapter II discusses Michigan's existing regulatory practices and their effects on electric utilities' resource selection. Chapter III presents summary descriptions of the ten mechanisms that were reviewed in the study's second step.

Chapters IV through VI present the detailed analyses of the three mechanisms selected by the Study Policy Group for further consideration. Finally, Chapter VII presents Barakat & Chamberlin's conclusions and recommendations.

II. CURRENT REGULATORY PRACTICES IN MICHIGAN AFFECTING UTILITIES' RESOURCE SELECTION

As the first step in the study, Barakat & Chamberlin examined current Michigan regulatory practices that affect electric utilities' selection of resources. This examination was conducted in part through interviews with members of the Study Policy Group and others in their respective organizations. We reviewed statutes and regulatory orders dealing with demand-side management, fuel and purchased-power cost recovery, automatic cost adjustment mechanisms, and related issues. We also reviewed various reports and regulatory filings by the PSC staff, Detroit Edison, and Consumers Power, including the companies' initial integrated resource plans as submitted in 1989 and 1990.

Most of the issues that emerged from this process involved DSM resources. This emphasis on DSM is consistent with that seen in other states that have recently investigated the regulatory barriers affecting IRP. While several states' investigations have resulted in the creation of financial incentives for DSM, there is no similar trend to create incentives for purchased power, cogeneration, or other supply-side options that are not part of the utility's investment in generating capacity.³

Below we discuss the regulatory influences on selection of DSM resources and proceed to a discussion of parallels in the selection of certain supply-side resources.

SELECTION OF DSM RESOURCES

Most recent analyses of the regulatory and financial considerations affecting utilities' interest in demand-side resources have focused on three general areas:

- *Cost Recovery.* A utility may acquire DSM resources through a wide variety of possible expenditures—direct purchases of equipment, payment of rebates to customers, promotional costs, salaries of DSM department staff, and others. Collectively, these expenditures represent the utility's direct program costs, and—provided they are

³ The possibility of incentives for certain non-DSM resources has been discussed but not acted upon in some states, including Maine, Ohio, and Washington.

prudently incurred—are ordinarily recoverable in rates. When DSM expenditures are growing, however, a utility may receive less than full recovery of its costs, because rates may not adjust rapidly enough to cover the expanded DSM budget. Sometimes a utility is allowed to recover excess expenditures at a later date, but in the meantime it loses the current use of its money (quantifiable as interest, or carrying charges, on its investment).

The possibility of incomplete cost recovery in these and other circumstances is an obvious financial disincentive to DSM. One component of most DSM incentive proposals, therefore, is a mechanism to ensure the utility's recovery of prudently incurred DSM costs.⁴

- *Lost Revenue.* In most circumstances, DSM programs that reduce sales reduce the utility's base revenue, which is intended to cover the utility's fixed costs, including the authorized return on capital. Under traditional ratemaking practices, the utility's projected fixed costs are allocated across expected sales. Each kilowatt-hour sold thus makes a contribution to the utility's recovery of fixed costs and profit—and each kilowatt-hour *conserved* reduces the contribution to fixed costs and profit. For the same reason, sales promotion is generally in the utility's financial interest, since incremental sales generate incremental contributions to fixed costs and profit.

The profit-reducing effect of DSM is often referred to as the "lost revenue problem"; like incomplete recovery of program costs, it is seen as a significant deterrent to expanded utility reliance on DSM. Hence, a second component of most DSM proposals is a provision to adjust the utility's revenue to compensate for this problem.

Some proposals go farther, seeking not only to correct the penalty for DSM but also to remove the financial incentive to increase sales. Proposals with this latter objective are termed "decoupling" mechanisms, since they aim to decouple the utility's fixed-cost revenue and profits from the level of sales.

⁴ In some cases utilities have profited by spending *less* on DSM than they were authorized to collect in rates. To protect against this possibility, proposals for improved cost recovery generally ensure that the utility recovers no more than its actual expenditures.

- *Profitability.* Under traditional regulation, DSM does not directly contribute to utility profits—even if cost recovery and the lost revenue problem are addressed through regulatory reforms.⁵ The costs of DSM programs are passed through to customers in rates without any markup, and the utility's overall return is not affected by good DSM performance. Selling additional kilowatt-hours and achieving cost savings in operations are normally the *only* ways a utility can increase profits.

Moreover, expanding DSM programs may entail additional risks that could reduce profitability, among them:

- *Performance risk*—DSM is still a relatively young field, and predications of the performance of particular DSM programs are highly uncertain. If programs fail to produce the expected savings, utilities may be penalized by regulators, and they may incur additional costs to make up shortfalls in supply.
- *Rate-level risk*—Many DSM programs that will lead to reductions in the total energy costs incurred by customers will nonetheless necessitate increases in average utility rates. Utilities are concerned about the impacts of such rate increases on their competitiveness, particularly in their ability to retain major commercial and industrial customers who may have sufficient purchasing power to seek other energy alternatives.

The lack of profitability in DSM and its perceived riskiness are being addressed in many states through mechanisms that provide *DSM bonuses*—the third part of most DSM incentive proposals. Such bonuses, which are generally tied to indicators of DSM performance and/or cost-effectiveness, can offset utilities' risk concerns and provide a positive motivation to expand reliance on DSM.

In the sections below, we examine in turn the current treatment of each of these factors in Michigan.

⁵ It might be argued that if DSM produces the claimed long-run efficiencies and cost savings, it will result in financially stronger utilities and customers alike, and thus improve profitability.

DSM Cost Recovery

While we use the term "DSM" in this report to refer collectively to a utility's energy conservation and load management programs,⁶ Detroit Edison and Consumers Power attach a particular meaning to DSM. They reserve "DSM" to refer to new conservation and load management programs undertaken in the context of IRP primarily for their resource benefits of peak-demand reduction and/or energy conservation. Both companies have for several years operated certain energy conservation programs that are not, in the companies' terminology, DSM programs. Some of these programs—for example, residential energy audits and low-income weatherization—have resulted from regulatory or statutory mandates. The operative distinction seems to be that the non-DSM conservation programs were undertaken largely for reasons other than their resource value.

Detroit Edison has two current programs (cool storage and dispersed generation) that are labeled DSM (Detroit Edison 1989a). Consumers Power considers all of its current programs energy conservation programs; its 1990 IRP report proposed five DSM programs for implementation (Consumers Power 1990).

Both companies emphasize that the cost recovery treatment accorded existing conservation programs is not a given for future DSM programs. Bearing this in mind, we refer to the current cost recovery system for conservation programs in the discussion that follows because it represents a precedent that *might* be applicable to larger-scale DSM.

Conservation Surcharges

Both Detroit Edison's and Consumers Power's existing programs are funded through conservation surcharges applied on a per-kWh basis to all sales. The surcharge system originated in 1980 as a means of funding federally mandated residential energy conservation programs (Order in Case U-6700, December 30, 1980). The current surcharges were established in separate settlements involving the utility in question, the PSC, and intervenors. Detroit Edison's surcharge is \$.0001/kWh (Detroit Edison 1989a); for Consumers Power, the surcharges vary by

⁶ The broadest definition of DSM encompasses any utility program designed to influence the level or pattern of customers' consumption. Included in this broad definition are "valley filling" and "strategic load growth" programs, which promote greater sales. In the context of discussions about financial incentive mechanisms, utilities and regulatory commissions tend to use "DSM" as a synonym for conservation and load management only; we adopt that usage in this report.

class, ranging from \$.000085/kWh for industrial sales to \$.00219/kWh for residential sales (Order in Case U-9496, March 13, 1990).

The surcharges provide a steady, albeit modest, level of funding for PSC-approved conservation programs. Assuming program expenditures are roughly level throughout the year, the utilities recover their expenditures in a timely manner. Any differences between actual receipts and expenditures accrue interest at the most recent allowed return on common equity. Receipts and expenditures are reconciled on a two-year cycle (Consumers Power 1989).

Significantly, the utilities have reasonable assurance that their expenditures on approved conservation programs will not be subject to after-the-fact disallowances if evaluations show the programs were not cost-effective. As described by Consumers Power: "The Company [is] authorized to recover all prudently incurred costs of each authorized program regardless of whether, after subsequent evaluation, the program proves not to be cost-beneficial" (Consumers Power 1989).⁷ Prudency reviews on the programs are still a possibility, however.

The surcharge mechanism, however, does not provide much flexibility for conservation or DSM funding. The report approved in the Consumers Power settlement states that "the three-year total projected expenditure level . . . is an upper limit which will not be exceeded" (Consumers Power 1989). Similarly, Detroit Edison states that "in no event will the Company expend more for its energy conservation plan during the three year period than is authorized by the Commission in its order adopting the plan" (Detroit Edison 1989a). Thus, the companies are locked into a particular spending level for a three-year period. Any year-to-year growth in program budgets would be controlled largely by growth in sales, but even then would be limited by the overall authorized budget for the three-year period.

By terms of the settlement with Consumers Power, surcharge revenues cannot be transferred from one customer class to another; they must be used to fund programs within the class from which they were collected. This also limits the utility's flexibility.

⁷ This statement is taken from Consumers' Conservation Report, which was incorporated by reference in the decision approving the settlement surrounding the company's conservation programs (Michigan PSC 1990).

Other Aspects of Regulatory Practice Affecting Cost Recovery

Duration of Proceedings. A pervasive factor in Michigan regulation—cited repeatedly by all participants in the study—is the length of time required for cases to come to a conclusion. Extensive litigation and/or negotiation toward a settlement is the norm.

As an example, consider the history of Consumers Power's current conservation programs and surcharge. A June 1988 order directed Consumers (and the other major utilities) to file an energy conservation report, including proposed surcharges, by January 1, 1989. Consumers did meet this filing deadline; negotiations with intervenors ensued. In December 1989 Consumers filed a revised conservation report, which was approved by the PSC in March 1990—over 14 months from the company's initial filing.

Delays such as this reduce flexibility in planning and implementing programs. They also increase the likelihood that revenues and expenditures will be out of sync due to changes in program needs, costs, and customer interest.

Future Test Year. Like some other states, Michigan uses a future test year for ratemaking purposes. In a rate case, base rates⁸ are established from a projection of revenues and costs in a future one-year period (the test year). This system contrasts with the historic test-year approach, used in a majority of states, in which rates are based on an analysis of actual revenues and expenditures from the most recent year.

Utilities with increasing DSM budgets tend to prefer future test years, because projected expenditure growth can be factored into rates. A future test year, however, is not a panacea for the DSM cost recovery problem; when the test year is over, the DSM budget may still be increasing, but it might be several years before the next rate case.

At present the test year is not a factor in the recovery of Edison and Consumer's conservation costs, since those costs are handled outside rate cases through conservation surcharges. If future DSM costs are to be recovered through base rates, Michigan's use of a future test year still will not ensure that cost recovery

⁸ Base rates are rates exclusive of surcharges (such as the conservation surcharge), power supply cost recovery factors (described below), and any other special adjustments.

will keep up with expenditures. Because rate cases take such a long time, a test year that is future when the case is filed is likely to be wholly or partly historic by the time rates are adjusted. And since utilities may go two, three, or more years between rate cases, the program cost projections built into a future test year become obsolete before the next rate adjustment.

Power Supply Cost Recovery Mechanism. Several states now allow utilities to recover DSM program costs through a fuel adjustment clause (FAC). While the details of FACs vary from state to state, the typical FAC imposes a surcharge on rates that provides nearly automatic pass-through of changes in the utility's fuel costs to customers. Differences between FAC revenues and actual fuel expenses are tracked in a *balancing account*. At regular intervals (say, once per quarter) the balancing account is cleared: if the account shows a deficiency, FAC surcharges are increased, and if the account has a positive balance, FAC surcharges are reduced. FACs became widespread in the 1970s, when utilities suffered financially due to sharp increases in fuel costs over which they had little control. The effect of a FAC is to shift the risk of fuel price volatility from the utility to ratepayers.⁹

Michigan's version of a FAC is known as the Power Supply Cost Recovery (PSCR) mechanism, which covers both fuel and purchased-power costs. As the PSCR is totally separate and distinct from the conservation cost recovery surcharge, it does not currently affect DSM cost recovery. Understanding the PSCR, however, is important to comprehending the larger picture of the regulatory and cost recovery environment in Michigan.

The PSCR mechanism was instituted by statute in 1982 (MCL Sec. 460.6j). It replaced an earlier FAC that had come under significant legal and political challenges (including a ballot initiative to eliminate it) due to the automatic nature of the resulting monthly rate adjustments, which were not subject to challenge by ratepayers. Opponents of the earlier FAC felt it led to unrestrained and unreasonable increases in energy costs.

⁹ Some states' FACs keep the utility at risk for a portion of changes in fuel costs. New York, for example, adjusts the FAC surcharge by 80% of the difference between revenues and costs. This provision gives the utility an incentive to minimize its fuel costs.

The PSCR statute instituted an annual cycle for review of utilities' fuel and purchased-power costs in a full, contested proceeding. At the beginning of the cycle, a utility files a month-by-month projection of its fuel and purchased-power costs for the coming year, and a corresponding set of rate adjustment factors needed to bring fuel and purchased-power revenues in line with expenditures. A proceeding determines the reasonableness of the utility's proposed PSCR factors and, if necessary, sets revised factors. Following the close of the cycle year, a PSCR reconciliation proceeding is held to review the prudence of expenditures and to reconcile them with collections. Under- or overcollections, adjusted for interest, are subsequently collected from or returned to ratepayers.

Several aspects of the PSCR and related statutes are noteworthy:

- The PSCR factor is restricted to collection of "booked" costs of fuel and purchased power. This appears to prohibit the addition of DSM incentive elements to the PSCR mechanism.
- Under- and overrecoveries of PSCR revenue are treated asymmetrically. If the reconciliation proceeding shows that the utility underrecovered its costs, the interest rate applied to the additional recoverable amount is the short-term borrowing rate. If the utility overcollected, the refundable amount is computed using the greater of the short-term borrowing rate or the utility's authorized return on equity. (The authorized return on equity would normally be greater than the short-term borrowing rate.)
- The commission is enjoined from establishing automatic rate adjustment mechanisms:
 - The commission shall not have the power to authorize or approve adjustment clauses that operate without notice and opportunity for a full and complete hearing, and all such clauses shall be abolished (MCL 460.6a(2)).

Also important are several aspects of the way the PSCR statute has been implemented:

- Because they are much more frequent than rate cases, PSCR proceedings have become vehicles for broad reviews of utility

operations beyond the stated issues of fuel and power purchasing practices. The utilities feel this development distorts the purpose of the PSCR statute and adds significantly to the regulatory burden and delay.

- In the utilities' view, the reconciliation proceedings result only in one-way adjustments: some costs are disallowed retroactively, while there is little opportunity to recover additional costs that were prudently incurred. (PSC staff, however, strongly disagrees with this characterization of the proceedings.)
- Due in part to the number of issues addressed and the contentiousness of the proceedings, the PSCR case cycle has become extremely long. Proposed 1989 factors for Consumers Power, for example, were filed in September 1988, but a final order establishing the factors was not issued until March 1990—nearly three months after the 1989 rate year had ended (Order in Case U-9172, March 29, 1990). (The commission is concerned about the length of PSCR proceedings and rate cases and has recently issued proposed guidelines that would require completion of most cases within a nine month period [Notice issued in Case U-9832, March 14, 1991].)

Detroit Edison Settlement. As the result of litigation over its investment in the Fermi nuclear plant, Detroit Edison operates under a settlement agreement that severely constrains for the near future its ability to undertake new demand-side programs that would raise rates. Absent extraordinary circumstances, the company is precluded from filing a rate case until 1993, and rate increases are predetermined (although subject to certain adjustment mechanisms). Operation of the PSCR is suspended through 1992 (Stipulation and Agreement in Case U-8789, December 19, 1988).

Operations and Maintenance Cost Adjustments. Michigan has long used various adjustment mechanisms that authorize changes in the operations and maintenance (O&M) components of the cost of service, between general rate cases and corresponding changes to rates. Like the PSCR mechanism, O&M adjustments do not directly affect DSM cost recovery, but they are part of the regulatory environment in which any proposed DSM incentives would be considered.

Beginning in 1978 the PSC instituted the Other O&M indexing system for the major electric and gas utilities. This mechanism allowed nonfuel operations and maintenance costs, except for production-related maintenance, to adjust automatically with changes in the national Consumer Price Index (CPI).¹⁰ Rates were allowed to adjust annually to cover the authorized cost changes. By allowing a portion of revenues to move upward with inflation, the PSC hoped to reduce the frequency of general rate cases. It also wanted to create an incentive to improve the efficiency of O&M: if a utility could hold increases in its O&M costs below the rate of change in the CPI, it would retain the difference as increased earnings (Order in Case U-5331, July 31, 1978).

The Other O&M indexing system was abandoned in early 1983 due to continuing political fallout over the automatic fuel adjustment clause, which had led to the PSCR legislation described above. The order rescinding the system said, "The Commission believes that it is the public view that the time has come for the operation of O&M Indexing clauses to cease" (Order in Cases U-5979, U-6103, and U-6488, January 31, 1983).

Recently, however, the PSC has been willing to implement variants of O&M indexing, notwithstanding the PSCR statute's general prohibition of automatic rate adjustment mechanisms. As part of the Fermi settlement described above, Detroit Edison operates under an Expense Stabilization Procedure that allows O&M expenses and rates to adjust partially to changes in the CPI (Stipulation and Agreement in Case U-8789, December 19, 1988). Michigan Consolidated Gas Company has an Operating Incentive Plan that serves the same purpose; this mechanism, too, is the product of a settlement (Order in Case U-9475, April 12, 1990).

DSM-Related Lost Revenue

Michigan does not currently have, nor has it had in the past, any policies or mechanisms that explicitly address the lost revenue impacts of DSM programs. The issue has been raised recently by both Detroit Edison and Consumers Power. In 1988 Detroit Edison criticized a PSC staff analysis for "failing to recognize that a successful conservation program may deprive a utility of revenue necessary to recover its fixed costs" (Order in Case U-8528, June 6, 1988). Consumers

¹⁰ The PSC excluded production-related maintenance since it wanted to maintain close oversight over expenditures in that category.

Power's 1990 IRP says that recovery of lost revenue is essential if DSM programs are to be pursued (Consumers Power 1990).

The amount of revenue (or fixed cost recovery) foregone due to DSM is tied to the level of sales assumed for the test year. If the test year has the expected effects of DSM built into it, then lost revenue occurs only to the extent that actual impacts are above anticipated impacts. Michigan's use of a future test year for ratemaking would be expected to minimize the likelihood of lost revenue impacts for the first year of a new rate period. Since there is no requirement that general rate cases occur at any fixed frequency, lost revenue would likely mount beyond the test year if DSM programs were expanding.

DSM Profitability

The settlement agreement approved in 1990 for Consumers Power's conservation programs established an experimental, performance-based incentive mechanism for four of the company's programs. The mechanism will yield Consumers a certain monetary bonus per kilowatt-hour saved in excess of target levels established for each program. The amount of the bonus per kilowatt-hour is computed on a sliding scale according to the cost-effectiveness of the program and ranges from \$.01-\$.05/kWh.

There is an overall cap of \$1.75 million on the amount Consumers can collect in bonus payments. \$1.5 million will be collected prospectively through an adjustment to Consumers' conservation surcharges. In 1992 a reconciliation proceeding on the surcharge and bonus will be held. To gain the full \$1.75 million bonus, the company will be required to demonstrate DSM savings and cost-effectiveness to the PSC's satisfaction (Consumers Power 1989).

This experimental incentive puts Michigan among the minority of states that have implemented performance-based profitability incentives for conservation. While the incentive is of some benefit to Consumers, it has not, however, made conservation a profitable activity for the utility, since there is no corresponding adjustment for lost revenue. According to Consumers, the value of the bonus is less than would be contributed to earnings if the electricity were sold rather than conserved.

No similar conservation-related bonus is available for other Michigan utilities. There is at least one other precedent, however, for an incentive that ties utility

profitability to a measure of performance. During the late 1970s and early 1980s electric utilities were subject to a powerplant availability incentive that could raise the company's allowed return on equity by as much as 50 basis points, or reduce it by as much as 25 basis points, depending on the average annual availability record of its plants. The bonus was collectible through a per-kWh surcharge on all sales. This mechanism was abandoned, however, at about the same time the automatic fuel adjustment clause and the indexing of O&M costs were abolished.

Interestingly, a PSC decision from 1980 implied that the commission was open to proposals for financial incentives to reward good performance in energy conservation programs. The order directing the utilities to undertake a residential conservation service program stated that

Proposals should be offered for the Commission's consideration that recognize successful conservation achievements. Proposals must include objective measurement of results obtained by the [residential conservation service] program (Order in Case U-6700, December 30, 1980).

To our knowledge, the concept of performance-related bonuses was not pursued until the Consumers Power bonus was established in 1990.

SELECTION OF SUPPLY-SIDE RESOURCES

Due to time and resource constraints and the interests of the Study Policy Group, the study did not focus extensively on selection of supply-side resources. A review of activities of other states considering incentives for IRP did not identify any uniquely applicable to non-DSM resources. No specific recommendations for special treatment of non-DSM resources were advanced by the Study Policy Group.¹¹

We did consider whether and how incentives proposed to address the factors inhibiting DSM options might be applicable to certain supply-side resources. Specifically, we considered the following classes of resources:

¹¹ Representatives of ABATE wanted the study to examine the economic and regulatory policies toward wheeling of electricity, but the Study Policy Group felt that this topic and the larger issue of promotion of competition in the utility industry were beyond the scope of the study.

- *Purchased Power.* Utilities have traditionally interchanged power with other utilities under both short- and long-term contracts. In recent years, due in part to the stimulus of the federal Public Utility Regulatory Policies Act (PURPA) of 1978, utilities have substantially increased their power purchases from nonutility sources. Under conventional regulation, in general the utility does not profit from either type of purchase: the cost of purchased power is a pass-through to rates. This is true in Michigan, where power purchases are handled through the PSCR mechanism.

Because power purchases do not directly contribute to utility earnings, while the costs are passed through to ratepayers through the PSCR, utilities have little incentive to make wise purchase decisions. Of course, to the extent that a lower-cost purchased-power arrangement helps hold down rates, a utility may be more competitive; and imprudent power purchases run the risk of disallowance by the commission. But there is not a direct link between the utility's skill in seeking out and negotiating favorable power purchases and its short-term profitability. Financial incentives might be considered as a stimulus to economic power purchasing practices.

- *Customer-Owned Generation.* For some larger utility customers, installation of their own generation equipment—particularly cogeneration systems that produce both electricity and thermal energy—can be a cost-effective option. PSC staff would like to see the utilities encourage customer-owned generation where it is cost-effective. Detroit Edison already has a modest program to take advantage of customers' standby generating capabilities; the program is projected to provide 3–4 MW of capacity in three years.¹²

Like DSM, promotion of customer-owned generation normally is at odds with a utility's economic interest, since it results in a reduction in sales and their contribution to fixed costs and profits (the lost revenue problem). Mechanisms to compensate the utility for revenue lost due to promotion of self-generation may be appropriate.

¹² Analytically, customer-owned generation can be treated as either a supply- or demand-side option. Detroit Edison considers its program a demand-side option.

The following chapters' analyses of specific incentive mechanisms include consideration of their role in utilities' pursuit of purchased power and customer-owned generation.

III. PRELIMINARY ANALYSIS OF INCENTIVE OPTIONS

The second step of the study involved a review and preliminary analysis of several financial incentives intended to influence utilities' resource selection. Barakat & Chamberlin proposed candidate mechanisms for this step based on a review of literature in the field and proposals under consideration or being implemented in other states. The Study Policy Group determined the final list of options for review.

This chapter includes brief summaries of the ten options considered vis-a-vis the twelve criteria described below. (More extensive write-ups of each option were submitted to the Study Policy Group.) The options are in three categories, corresponding to the three major financial considerations affecting resource selection described in Chapter II: cost recovery, lost revenue, and profitability.

- Cost Recovery Options
 - Expensing with balancing account reconciliation
 - Capitalization
- Lost Revenue Options
 - Lost revenue adjustment
 - Electric revenue adjustment mechanism (ERAM)
 - ERAM per customer
- Profitability Options
 - Bonus return on certain capitalized expenditures
 - Bonus return on overall rate base
 - Unit price payment
 - Shared benefits
 - Markup on expenditures

Following the summaries is a discussion of the Study Policy Group's decision as to which options to examine in greater detail.

CRITERIA FOR EVALUATING INCENTIVE OPTIONS

The Study Policy Group established the following twelve criteria for comparing the ten options:

- **Benefits.** What existing problems or disincentives does this alternative rectify, and how well does it address them?
- **Potential Applicability.** Is this alternative applicable to all utilities and resource options?
- **Precedents.** Are there precedents in Michigan for this alternative or related mechanisms? Has this alternative been proposed or implemented in other jurisdictions?
- **Performance Basis.** Is this alternative linked to measurement of performance? Does it reward exemplary performance in integrated resource planning and selection?
- **Use of Positive Motivation.** Does the alternative create a positive motivation (financial or otherwise) to adhere to IRP principles, or does it motivate by threat?
- **Potential Rate/Revenue Requirement Impact.** To what extent might this alternative exert upward pressure on rates? How would these impacts be distributed?
- **Treatment of Externalities.** Does this alternative accommodate consideration of environmental and other external costs?
- **Ease of Regulatory Implementation.** How difficult would it be to effect this change? Would statutory changes be required?
- **Ease of Administration/Operation.** How burdensome would administration of this alternative be for utilities? For the Public Service Commission?

- **Relationship to Other Alternatives.** How easily could this alternative be teamed with other alternatives under consideration? Would conflicts arise if other alternatives were also implemented?
- **Potential for "Gaming."** Could this alternative be manipulated by any party in a way that would distort its purpose?
- **Risks.** What risks might follow from selecting this alternative, and who bears them?

SUMMARY TABLES

Beginning on the next page is a series of tables summarizing the ten options and evaluating each according to the criteria described above.

Table 3-1
Summary and Evaluation: Expensing with Balancing-Account Reconciliation

Description	The utility recovers expenditures for eligible resources as it incurs them, either in base rates or through a surcharge. Cost recovery is based on a projected expenditure level. Differences between actual and projected expenditures (positive or negative) accrue interest. The net difference is applied periodically to adjust the cost recovery amount.
Benefits	Minimizes the utility's cost recovery risk by providing prompt recovery of expenditures. Provides flexibility in program spending levels. Ensures the utility recovers no more and no less than its actual expenditures. Removes any incentive to underspend the authorized budget.
Potential Applicability	DSM, purchased-power arrangements, and expenditures for other resources that are not normally capitalized.
Precedents	A form of expensing with balancing-account recovery is used in Michigan at present for conservation program costs (recovered through a conservation surcharge) and purchased-power costs (recovered through the Power Supply Cost Recovery mechanism).
Performance Basis	Not performance based.
Use of Positive Motivation	Neutral.
Potential Rate/Revenue Requirement Impact	If eligible expenditures are rising, revenue and rates will increase somewhat, since the lag between growth in expenditures and corresponding rate increases is eliminated.
Potential Treatment of Externalities	Not addressed.

Table 3-1
Summary and Evaluation: Expensing with Balancing-Account Reconciliation
(continued)

Ease of Regulatory Implementation	No known regulatory barriers.
Ease of Administration/Operation	Straightforward.
Relationship to Other Alternatives	Only addresses direct cost recovery. Could be combined with any mechanisms for lost revenue recovery and profitability.
Potential for "Gaming"	None identified.
Risks	If costs are automatically passed through, the utility may not have adequate incentive to exercise careful cost control.
Comments	The current implementation of a balancing account for conservation programs in Michigan is one-way in that the utilities cannot recover more than their predetermined conservation budgets. There is no assurance that a balancing account treatment would be allowed for expanded DSM programs.

Table 3-2
Summary and Evaluation: Capitalization

Description	Eligible expenditures are amortized for cost recovery purposes over a long-term period related to the length of benefits. The utility's rate of return on the unamortized balance equals its ordinary cost of capital.
Benefits	Puts cost recovery of demand- and supply-side resources on an equal footing. Provides a return on investment for expenditures that have traditionally been expensed (recovered without a return). Offsets depreciation of rate base without adding supply-side resources. Provides better matching of costs to the period over which benefits are received.
Potential Applicability	Any resource expenditures not normally in a utility's rate base that are substantially front-loaded and provide long-live resource benefits. Most DSM expenditures are of this nature.
Precedents	Under existing regulatory and accounting practices, supply-side investments are rate based, which is a form of capitalization. Capitalization is in use in many states for some or all DSM expenditures. It was used in the early 1980s in Michigan for certain start-up costs associated with residential conservation programs. There are no known precedents for capitalization of nonutility supply-side resources.
Performance Basis	Not performance-based.
Use of Positive Motivation	A simple theoretical model shows that a utility does not benefit from capitalization. In practice, capitalization may provide a weak positive motivation for the utility to invest in eligible resources.

Table 3-2
Summary and Evaluation: Capitalization
(continued)

Potential Rate/Revenue Requirement Impact	On a present-value basis, capitalization requires greater revenue due to tax effects, if discounting is performed using the utility's cost of capital. Capitalization has a smoothing effect on revenue requirements since it spreads the cost of an investment over several years.
Potential Treatment of Externalities	Not addressed.
Ease of Regulatory Implementation	No known regulatory barriers. Ample precedents in other states.
Ease of Administration/Operation	Increases accounting requirements. Once accounting methods are in place, the additional burden is probably moderate. Operation is more complicated if different categories of expenditures require different amortization periods.
Relationship to Other Alternatives	Only addresses direct cost recovery. Could be combined with any mechanisms for lost revenue recovery and profitability. Capitalization is a prerequisite for a profitability mechanism that increases the allowed rate of return on certain expenditures.
Potential for "Gaming"	A traditional concern about capitalization is that it may encourage "goldplating" of eligible resources. Since capitalization spreads recovery of an expenditure over several years, the commission could cut recovery short as a penalty.

Table 3-2
Summary and Evaluation: Capitalization
(continued)

Risks	<p>Because cost recovery is delayed, the risk that the utility will not fully recover its costs is increased.</p> <p>Capitalization increases the proportion of non-bondable property on the utility's balance sheet.</p>
Comments	<p>Capitalization has often been mentioned as an incentive mechanism to encourage DSM.</p> <p>Financial analysis shows that if the rate of return is equal to the cost of capital, capitalization offers the utility no advantage over expensing. If ratepayers' discount rate is higher than the utility's, they should prefer capitalization.</p>

Table 3-3
Summary and Evaluation: Lost Revenue Adjustment

Description	Allows the utility to collect shortfalls in recovery of authorized fixed costs attributable to implementation of sales-reducing resources whose impact was not assessed fully when rates were set.
Benefits	Removes the financial penalty to the utility for promoting the affected resources.
Potential Applicability	DSM and customer-owned generation.
Precedents	DSM-related lost revenue adjustments have been implemented or authorized in Massachusetts, New Hampshire, New York, Ohio, Oregon, and Vermont. Iowa has allowed a utility to recover a portion of the lost revenue associated with a self-generation project.
Performance Basis	The adjustment is tied to performance in promoting sales-reducing resources. It is, however, an adjustment for financial effects that occur between rate cases, not a reward for performance.
Use of Positive Motivation	Removes a disincentive to promotion of resources that reduce energy sales.
Potential Rate/Revenue Requirement Impact	In the short run, average rates will increase to cover the shortfall. There is no long-run impact, as rates would be adjusted at the next rate case to cover fixed costs.
Potential Treatment of Externalities	Not addressed.

Table 3-3
Summary and Evaluation: Lost Revenue Adjustment
(continued)

Ease of Regulatory Implementation	DSM-specific lost revenue adjustments have been implemented or authorized by commissions in four states, and have withstood a legal challenge in a lower court in New York. They may, however, be subject to challenge as retroactive ratemaking; therefore, statutory authorization may be needed.
Ease of Administration/Operation	Measurement of lost sales, estimation of associated base revenue, and verification may be challenging.
Relationship to Other Alternatives	Could be combined with any mechanisms for direct cost recovery and profitability.
Potential for "Gaming"	The utility could collect DSM-related lost revenue at the same time it realizes excess base revenue through sales promotion.
Risks	Public perception of lost revenue recovery may be poor, especially in an economic downturn.
Comments	A lost revenue mechanism recently approved in Oregon requires the utility to return excess revenue if it fails to meet the conservation targets that were assumed in setting rates.

Table 3-4
Summary and Evaluation: Electric Revenue Adjustment Mechanism (ERAM)

Description	The utility's actual and authorized base (non-fuel) revenue is periodically reconciled. Under- or overcollections are collected from, or returned to, ratepayers through an adjustment to rates in the next period. Attrition mechanisms adjust authorized base revenue periodically.
Benefits	Decouples base revenue from sales, removing the short-run incentive to promote sales. Eliminates the lost revenue problem. Stabilizes revenue, possibly reducing the cost of capital. Reduces controversy over the sales forecast in rate cases.
Potential Applicability	Not resource-specific.
Precedents	In use in California since 1981. Instituted in New York for one utility in 1990. Under study in several other states.
Performance Basis	Not performance-based.
Use of Positive Motivation	Removes a disincentive to promotion of resources that reduce sales.
Potential Rate/Revenue Requirement Impact	Effects related to selection of alternative resources will likely be small in relation to those caused by weather, business cycles, etc. Over the long run, revenue-requirement increases should be balanced by decreases.
Potential Treatment of Externalities	Not addressed.

Table 3-4
Summary and Evaluation: Electric Revenue Adjustment Mechanism (ERAM)
(continued)

Ease of Regulatory Implementation	This may be considered an automatic adjustment mechanism within the meaning of MCL 460.6a, in which case statutory authorization would be required. Substantial effort would be required to implement ERAM, primarily in determining methods for adjusting authorized base revenue over multiyear periods (attrition mechanisms).
Ease of Administration/Operation	Significant accounting-related efforts would be needed to track revenue and update authorized levels.
Relationship to Other Alternatives	Could be combined with any mechanisms for direct cost recovery and profitability.
Potential for "Gaming"	None identified.
Risks	There has been continuing concern in California that ERAM reduces utilities' motivation to retain large customers with bypass options, and therefore may lead to higher rates for customers remaining on the system. Automatic cost adjustments tied to indexes have been politically controversial in Michigan.

Table 3-5
Summary and Evaluation: Per-Customer ERAM

Description	The utility's actual and authorized base revenue is periodically reconciled. Under- or over-collections are collected from, or returned to, ratepayers through an adjustment to rates in the next period. Authorized base revenue is automatically adjusted in proportion to changes in the number of customers served.
Benefits	Decouples base revenue from sales, removing the short-run incentive to promote sales. Eliminates the lost revenue problem. Stabilizes revenue, possibly reducing the cost of capital. Provides benefits similar to ERAM without the need for a future test year and attrition mechanisms to adjust authorized revenue.
Potential Applicability	Not resource-specific.
Precedents	Has been proposed in Maine, Ohio, and Washington.
Performance Basis	Not performance-based.
Use of Positive Motivation	Removes a disincentive to promotion of resources that reduce sales.
Potential Rate/Revenue Requirement Impact	Effects related to selection of alternative resources will likely be small in relation to those caused by weather, business cycles, etc. Over the long run, revenue-requirement increases should be balanced by decreases.
Potential Treatment of Externalities	Not addressed.

Table 3-5
Summary and Evaluation: Per-Customer ERAM
(continued)

Ease of Regulatory Implementation	This may be considered an automatic adjustment mechanism within the meaning of MCL 460.6a, in which case statutory authorization would be required. Implementation is not likely to prove difficult (although there are no instances where this mechanism has been implemented).
Ease of Administration/ Operation	Moderate accounting-related efforts would be required to track revenue and update authorized levels.
Relationship to Other Alternatives	Could be combined with any mechanisms for direct cost recovery and profitability.
Potential for "Gaming"	The utility might have an incentive to change its definition of "customer" so as to raise the customer count.
Risks	There has been continuing concern in California that ERAM reduces utilities' motivation to retain large customers with bypass options, and therefore may lead to higher rates for customers remaining on the system. This same concern would likely arise with a per-customer ERAM. The utility's fixed costs might not vary proportionately with the number of customers. If growth in the number of customers is flat while the utility's costs are increasing, the utility would be financially penalized.
Comments	Support for the proposition that the number of customers correlated well with fixed costs is anecdotal only. This proposition could be tested empirically for Michigan's utilities.

Table 3-6
Summary and Evaluation: Bonus Return on Capitalized Expenditures

Description	The utility receives a fixed or performance-based return above its ordinary allowed rate of return on eligible capitalized expenditures.
Benefits	Stimulates reliance on eligible investments by providing a bonus above the cost of capital.
Potential Applicability	Any resource expenditure that can be capitalized. In addition to traditional supply-side investments, this includes DSM expenditures. Capitalization of purchased-power expenditures would likely be difficult.
Precedents	Authorized by statutes in Washington, Montana, Connecticut, and Kansas. Implemented by the commission in Wisconsin.
Performance Basis	Not intrinsically performance-related, but the size of the return increment could vary with performance levels. A reduction in return could be assessed for poor performance.
Use of Positive Motivation	Provides a positive motivation for the utility to invest in eligible resources.
Potential Rate/Revenue Requirement Impact	Probably modest. Eligible investments would likely be a small portion of the utility's rate base, and the bonus on them probably would not exceed a few percentage points.
Potential Treatment of Externalities	The bonus rate of return could be adjusted upward or downward depending on the externality attributes of the resource.
Ease of Regulatory Implementation	Straightforward. Under current Michigan law, would have to be implemented in the context of a general rate case. There is precedent in Michigan for a commission-authorized higher rate of return on certain investments.

Table 3-6
Summary and Evaluation: Bonus Return on Capitalized Expenditures
(continued)

Ease of Administration/ Operation	Moderate accounting-related effort to segregate eligible investments.
Relationship to Other Alternatives	Requires that the affected resources be capitalized (see the summary of capitalization in Table 3-2). Could be implemented with a lost revenue adjustment mechanism.
Potential for "Gaming"	May encourage "goldplating" of eligible resources. Since the bonus is spread over the amortization period, the commission could curtail its receipt as a penalty.
Risks	Because the receipt of the bonus is spread over the amortization period, there is some risk that the utility will not receive its full bonus.

Table 3-7
Summary and Evaluation: Performance-Based Bonus Return on Rate Base

Description	The utility's overall rate of return is increased (or decreased) based on measured performance in one or more areas.
Benefits	Provides a direct incentive for performance in desired areas. Easily made symmetric (penalty for poor performance). Highly visible to investment community.
Potential Applicability	Applicable to resource-oriented performance in virtually any area. Also applicable to operational areas, such as powerplant heat rates, customer service response time, etc.
Precedents	Several state commission have explicit authority to make judgmental adjustments to a utility's overall rate of return to reward or penalize DSM performance. A bonus based on quantified DSM performance is in place for one New York utility and has been proposed elsewhere.
Performance Basis	Directly tied to one or more measurements of performance, which could be chosen to emphasize actions consistent with IRP.
Use of Positive Motivation	Provides motivation to improve performance in specified areas.
Potential Rate/Revenue Requirement Impact	May be significant, depending on the range of the bonus (increment or decrement).
Potential Treatment of Externalities	Quantifiable aspects of externalities (e.g., emissions reductions) could be one of the measurements of performance.
Ease of Regulatory Implementation	Under current Michigan law, would have to be done in the context of a general rate case. Significant effort needed to identify and specify the performance components to be measured.

Table 3-7
Summary and Evaluation: Performance-Based Bonus Return on Rate Base
(continued)

Ease of Administration/ Operation	Measurement and verification of performance components may be challenging.
Relationship to Other Alternatives	Could be combined with any mechanisms for cost recovery and lost revenue adjustment.
Potential for "Gaming"	May encourage substitution of capital items for expense items.
Risks	Depending on how the components of the bonus are weighted, the utility might have an incentive to overemphasize some areas at the expense of others.

Table 3-8
Summary and Evaluation: Unit Price Payment

Description	The utility receives a fixed payment per unit of energy saved or obtained from an eligible resource. The payment is intended to cover costs and motivate the utility to hold costs below the payment level.
Benefits	Encourages the utility to identify and procure resources that cost less than the specified payment level.
Potential Applicability	Any resource for which energy saved, produced, or purchased can be estimated or measured.
Precedents	Massachusetts has implemented bonuses per kW and KWh saved for DSM programs; these payments, however, are independent of program cost recovery.
Performance Basis	Tied to energy saved or produced. The fixed nature of the payment encourages cost minimization.
Use of Positive Motivation	Provides motivation to control costs.
Potential Rate/Revenue Requirement Impact	Difficult to predict. If payments are held below avoided cost, revenue and rate impacts should be favorable. In the long run, however, revenue requirements and rates could be higher than they would be under cost-of-service ratemaking.
Potential Treatment of Externalities	The unit price could be adjusted upward or downward based on the externality attributes of the resource.
Ease of Regulatory Implementation	May be in conflict with existing PSCR mechanism (providing recovery of booked fuel and purchased-power costs). Setting and reviewing payment levels would require significant effort.

Table 3-8
Summary and Evaluation: Unit Price Payment
(continued)

Ease of Administration/ Operation	Requires significant measurement and verification activities.
Relationship to Other Alternatives	Encompasses both cost recovery and a bonus/penalty mechanism for affected resources. Could be combined with any lost revenue adjustment mechanism.
Potential for "Gaming"	The utility would have an incentive to inflate its avoided cost estimates, since they would be the basis for setting the payments.
Risks	If the utility considers the output or performance of the affected resources difficult to predict, it may be reluctant to select those resources. Excessive focus on cost control could cause problems in quality of service.
Comments	Payments could be front-loaded or spread over the period a resource is in service.

Table 3-9
Summary and Evaluation: Shared Benefits

Description	The utility receives a bonus equal to a share of the cost savings attributable to selection of an eligible resource.
Benefits	Rewards the utility for obtaining savings through resource selection. Can be structured to ensure that a majority of the benefits accrue to ratepayers.
Potential Applicability	Any resource for which an avoided cost can be estimated.
Precedents	Implemented for DSM resources in Colorado, California, New Hampshire, New York, Ohio, Rhode Island, and Vermont. Proposed in several other states. Was proposed by a utility for purchased power from utility and nonutility sources in Maine (proposal later withdrawn).
Performance Basis	Tied to estimated performance in terms of resource cost.
Use of Positive Motivation	Positively motivates the utility to maximize the savings to be shared.
Potential Rate/Revenue Requirement Impact	Difficult to predict. Impacts depend on the size of programs, their cost-effectiveness, and the sharing formula.
Potential Treatment of Externalities	An externalities adjustment can be included in the calculation of the benefits. This is being done in New York.
Ease of Regulatory Implementation	Requires agreement on methodologies for measuring and verifying benefits and costs.
Ease of Administration/Operation	Measurement and verification requirements would be substantial. Greater accounting burden if bonus is not front-loaded.

Table 3-9
Summary and Evaluation: Shared Benefits
(continued)

Relationship to Other Alternatives	Could be combined with any cost recovery and lost revenue adjustment mechanisms.
Potential for "Gaming"	The utility would have an incentive to inflate its avoided cost estimates, since they would be the basis for setting the payments.
Risks	Evaluation methodologies and results could become a major area of controversy.
Comments	Additional mechanisms would be needed to create symmetry in reward/punishment. Payments could be front-loaded or spread over the period a resource is in service.

Table 3-10
Summary and Evaluation: Markup on Expenditures

Description	The utility receives a markup above cost on eligible resource expenditures.
Benefits	Encourages utilities to expand expenditures in eligible areas. Allows utilities to profit on eligible expenditures, rather than simply pass them through to ratepayers.
Potential Applicability	Applicable in principle to any expenditure. Most likely candidates are resources that are marginally cost-effective but are desired for other reasons, and/or have benefits that are difficult to measure.
Precedents	In place for informational, low-income, and certain other DSM programs of California utilities.
Performance Basis	Not performance based. Could be made contingent on achievement of target levels of effort or output (such as number of homes weatherized).
Use of Positive Motivation	Motivates the utility positively to increase spending in the affected areas.
Potential Rate/Revenue Requirement Impact	Depends on the size of markup and the scope of eligible expenditures. Precedents suggest impacts would be small, given the modest size of markups and their limitation to a portion of DSM expenditures.
Potential Treatment of Externalities	Larger or smaller markups could be offered based on the externality attributes of the resource.
Ease of Regulatory Implementation	No regulatory barriers identified. Implementation straightforward.

Table 3-10
Summary and Evaluation: Markup on Expenditures
(continued)

Ease of Administration/ Operation	Straightforward.
Relationship to Other Alternatives	Likely to be considered for certain expenditures in concert with performance-based bonuses. Could be combined with any cost recovery and lost revenue adjustment mechanisms.
Potential for "Gaming"	May encourage "goldplating" of eligible expenditures.
Risks	Could encourage continuation of programs that are not cost-effective and should be considered for phase-out.

STUDY POLICY GROUP'S DIRECTIONS FOR FURTHER ANALYSIS

Following its review of the incentive options identified in this chapter, the Study Policy Group selected three options for more detailed study. One option was selected in each of the categories of cost recovery, lost revenue, and profitability. The options selected were:

- Capitalization
- ERAM
- Shared Benefits

In selecting these three options, the Study Policy Group was *not* expressing its collective preferences for mechanisms that should be implemented in Michigan. Rather, it was simply deciding the direction of future study efforts. Members agreed that having detailed analyses of these three options would be valuable in the group's subsequent deliberations.

The next three chapters present detailed reviews and analyses of capitalization, ERAM, and shared-benefits mechanisms.

IV. DETAILED ANALYSIS: CAPITALIZATION

CAPSULE DESCRIPTION

Capitalization is a cost recovery method in which an expenditure is amortized, or charged to ratepayers, over a multiyear period. The utility earns a return on the unamortized balance. This is the same cost recovery treatment normally applied to utility-owned supply-side resources. It has frequently been proposed for DSM resources as a means of leveling the playing field on which resource choices are made.

PURPOSE AND BENEFITS

When applied to DSM resources, capitalization:

- Accords such resources cost recovery similar to that used for utility-owned investments in generation, transmission, and distribution equipment.
- Spreads the costs of the resources to ratepayers over a number of years, thereby matching costs to the period benefits are received, promoting fairness between current and future customers, and contributing to rate stability.
- Allows the utility to earn a return on its investment rather than simply recover its costs, as is true under expensing.

The fact that a utility earns a return on capitalized expenditures is often believed to be financially advantageous to the utility. The financial analysis presented later in this chapter shows that in terms of ultimate cash flow, a utility's shareholders should be indifferent between capitalization and expensing. Other considerations may lead to a preference for one cost recovery method over the other.

BACKGROUND AND STATUS

When a utility invests in long-lived productive capacity, such as generating plants and transmission equipment, it capitalizes the investment. Conventional

ratemaking allows the utility to recover annually through rates a portion of its investment (return *of* investment) plus an allowance for the use of its funds (return *on* investment). The unrecovered portion of the investment is generally referred to as the "rate base"; this is the source of the term "ratebasing," essentially a synonym for capitalized cost recovery.¹³

A utility's operating and maintenance expenditures, on the other hand, are considered period expenses that do not represent long-lived assets. Such expenditures are typically expensed—that is, recovered through rates as they are incurred, with no return. Expensing is the usual cost recovery method for DSM and purchased-power expenditures.

Capitalization has long been suggested for DSM expenditures as a means of leveling the playing field so that demand- and supply-side options compete on an equal footing. The practice dates back to at least 1978, when Pacific Power & Light Company included certain expenditures for its residential conservation programs in rate base (Krasniewski and Murdock 1980).

Many states now allow capitalization for DSM expenditures. In some cases capitalization has been authorized explicitly by legislation, but in most states the commission has implemented it on its own authority. The specification of which DSM expenditures are eligible for capitalization varies. In the most expansive cases, essentially all expenditures on DSM programs have been capitalized, including labor costs, equipment given to customers, and the value of financial incentives paid to influence customer choice. The rationale for broad use of capitalization is that all DSM program expenditures are made with the intent of creating a long-lived benefit: namely, the avoidance of costs through reduction in energy consumption and/or peak demand.

Capitalization rules or statutes in at least three states allow the commission to offer the utility a rate of return on selected assets that is *greater* than the utility's overall allowed return (Reid 1988). This treatment combines a cost recovery

¹³ In rate cases the rate base is the dollar amount to which the commission-authorized rate of return is applied. In most states rate base includes, in addition to tangible utility property, an allowance for working capital and certain other items considered part of the utility's investment. A commission can grant capitalized recovery for DSM expenditures without formally including them in rate base; this has been the practice in Wisconsin, for example, where there is a narrow legal definition of rate base. Informally, such treatment is still considered ratebasing. We use the term capitalization to make clear that this type of cost recovery is not contingent on inclusion of the expenditures in rate base.

method (capitalization) with a profitability incentive (a bonus rate of return). For the remainder of this chapter, however, we consider only straight capitalization without any bonus increment.

While the typical utility has little or no capitalized DSM investment, there are some noteworthy exceptions. In Washington, where a statute authorizes capitalization of DSM, Puget Sound Power & Light has capitalized over \$100 million worth of investment since the early 1980s (Reid 1988). In Wisconsin in 1986, the commission directed Wisconsin Electric Power Company to commence a "conservation construction program," investing \$73 million in capitalized DSM expenditures over a two-year period (Docket No. 6630-UR-100, December 30, 1986).

Whether capitalization could be applied to purchased-power arrangements is debatable. We are not aware of any such proposals. If the purchase would provide capacity and/or energy for several years, and if the payments would be substantially front-loaded (that is, made in a lump sum at the start of the contract), then capitalization would make sense. If, however, contract payments would be spread out over several years—either as fixed payments or as payments that vary with the quantity purchased—capitalization would be difficult to justify and even more difficult to implement.¹⁴ Purchased-power projects normally follow this latter pattern.

Commissions that have considered capitalization have generally agreed that it is an acceptable cost recovery method for DSM expenditures. Utilities, however, are divided over the issue. Some utilities have sought capitalization as a means to equalize the treatment of demand- and supply-side options and to smooth the cost impacts of large-scale DSM expenditures. The desire to offset declines in rate base due to depreciation of existing plants has also been cited by utilities seeking capitalization. Other utilities, however, have opposed capitalization of DSM because it increases the costs borne by ratepayers and may add to the utility's risk. These concerns are discussed below.

¹⁴ One possibility would be to add each year's payment to rate base, amortizing it over the remaining life of the contract.

IMPLEMENTATION AND OPERATION

Legal/Regulatory Status

In the early 1980s the Michigan PSC authorized capitalization of some costs associated with the startup of the Michigan Residential Conservation Service (MRCS) program. The PSC said that certain "developmental" costs—including the costs of equipment, tools, vehicles, software, and the design of procedures—could be amortized over five years with a return. Other MRCS costs were considered operating expenses; utilities were directed to recover those costs as they were incurred. A two-part conservation surcharge on rates was authorized to collect the capital and expense costs of MRCS (Order in Case U-6700, December 30, 1980).

The MRCS case represents a limited precedent for broader ratebasing of DSM expenditures in Michigan. The PSC limited capitalization to those program costs that would be incurred at the start and would benefit the MRCS program over a period of years. If it ever considered capitalization of other costs because of their long-term benefits to ratepayers, it did not discuss that option in the order. At the time MRCS was implemented, however, utilities' conservation programs were being undertaken more for their social benefits than for their resource benefits.

Aside from the 1980 MRCS order, we are aware of no Michigan instances where DSM or other nontraditional resource costs have been capitalized. In the absence of any suggestion to the contrary, however, we believe the PSC could implement broad-based capitalization for DSM or other resource alternatives on its own authority.

Information or Decisions Required for Implementation

Eligibility of Expenditures for Capitalization

The PSC would have to decide whether all DSM expenditures or only particular categories of expenditures would be eligible for capitalization. If the principle that DSM produces long-lived benefits is accepted, then logically all DSM-related expenditures could be capitalized.

Other states' positions on this question vary. Wisconsin, for example, limited Wisconsin Electric's capitalization to the portion of its DSM expenditures used to

provide financial incentives to customers (in the form of rebates or interest-rate buydowns). The Washington commission, in contrast, let Puget Power capitalize virtually all its DSM expenditures.

Amortization Period

Capitalization requires specification of an amortization period. In theory, this should correspond roughly to the service life of the asset in question. The Washington statute authorizing capitalization of DSM and alternative investments permits their inclusion in rate base for up to thirty years (Rev. Code Wash. 80.28.025). In practice, however, much shorter periods are generally used for DSM expenditures; 10 years is a common choice.

A uniform amortization period could be used for all capitalized DSM, or different periods could be used with shorter or longer assumed lives for different categories of expenditures. Use of a single year, or use of at most two or three different years for broad categories of expenditures, would likely prove advantageous from an administrative standpoint.

In general, utilities prefer shorter amortization periods to longer periods. Use of a longer period is believed to increase the risk that the utility might not fully recover its costs and return. This risk is discussed below.

Allowed Rate of Return

The rate of return earned on the unamortized capitalized investment must be specified by the PSC. For comparability with ratebased supply-side investments, capitalized DSM expenditures should earn a return equal to the utility's overall authorized return—normally the estimated weighted-average cost of capital.

It might be argued that DSM investments are riskier than other utility investments and therefore deserve a higher rate of return. This proposition is debatable; conservation advocates, in fact, tend to argue that DSM investments are less risky for a utility than generation investments, given the tendencies toward cost overruns and prudence disallowances that have occurred on the supply side. In any case, applying a higher rate of return to capitalized DSM would confound cost recovery with the provision of a bonus. Setting the DSM return equal to the

overall utility return is consistent with the interpretation of capitalization as primarily a cost recovery mechanism.

Rate Recovery Mechanism

There are two basic options for including DSM capitalization charges (amortization plus return) in utility rates.

One option is to include capitalization charges in base rates at each general rate case. This is the treatment normally used for supply-side resources. Rates then include an allowance for the amortization and return projected for the test year.

Alternatively, the capitalization charges could be included in a surcharge computed outside the general rate case cycle, such as the conservation surcharge, currently on a three-year cycle. The PSCR factor, which is adjusted annually, could conceivably be used for this purpose, but the statutory limitation of the PSCR to booked fuel and purchased-power costs would have to be relaxed.

Carrying Charges Mechanism

A period of time normally elapses between a utility's investment in capitalized DSM and the start of cost recovery. If, for example, capitalization charges are computed in general rate cases, this period can be as long as the interval from one rate case to the next. During this period, the utility should be authorized to earn carrying charges (interest) on its investment. If carrying charges were not earned and a significant time period passed, the utility's eventual cost recovery would be incomplete. To provide complete cost recovery, the carrying charge rate should be equal to the utility's overall authorized rate of return.

Operating Requirements

Accounting procedures would have to be established to track eligible expenditures, classify them into different amortization periods if needed, accumulate carrying charges, and collect amortization and return revenue once recovery begins.

The PSC would have to establish an ongoing procedure to review the prudence of the expenditures proposed for capitalization and the appropriateness of the proposed amortization period. This could be done as part of a general rate case (if recovery is being handled through the rate case) or through the review of the utility's biennial conservation report.

POTENTIAL PROBLEMS OR CONCERNS

Risk of Nonrecovery

Although capitalization has been suggested as a means of improving the cost recovery of DSM expenditures, it may also introduce new cost recovery risks. These risks are of two types.

One risk can arise when significant time elapses between the outlay of an investment and the onset of capitalization charges. Unless the utility has prior assurance that its investment will be granted cost recovery—as might be the case, for example, if it is part of an approved DSM plan—then it is at risk that the commission will disallow the proposed capitalization plan.

The second risk is that the utility will be unable to recover the full authorized amount, including the appropriate return, after recovery begins. Underrecovery could occur, for example, due to a retrospective prudence review (disallowing a portion of an expenditure), or changes in regulatory policy. Increased competition may also prevent full recovery: if alternative fuels and bypass options place additional competitive pressure on prices to larger customers, discounting may effectively limit the utility's ability to collect its full authorized revenue.

Investors' Perceptions

One objection to broad-based capitalization of DSM is that many DSM expenditures do not create hard assets that are owned and controlled by the utility. This objection presumes capitalization should be limited to property and equipment that have clear market value and can be used as collateral for the utility's debt issues.

Capitalized DSM may not be as secure or as valuable an asset as a conventional supply-side investment of comparable magnitude. Nevertheless, well-established

regulatory accounting principles state that an expenditure can be regarded as an asset if it is probable that the regulatory commission will allow future recovery.

One problem with such "regulatory assets" is that they are not considered bondable property—in effect, they cannot be pledged as collateral to support utility debt issues. If capitalized DSM becomes a major component of a utility's balance sheet, the utility could conceivably reach the maximum level of unbondable property allowed by debt underwriters, in which case its ability to issue new debt would be constrained. Even if the limit was not reached, the utility's debt rating might decline.

To date, however, Wall Street analysts have not devoted significant attention to utilities' DSM activities, even in the case of companies with aggressive DSM programs. We are not aware of any empirical evidence that speaks to how investors will view capitalized DSM.

"Goldplating"

Critics of capitalization have occasionally suggested that it may lead to "goldplating," or excessive investment in capital-intensive measures. This criticism is not unique to capitalization of DSM, but rather has been a recurring issue in rate base/rate of return regulation.

The financial analysis presented below shows that if a utility's investment in DSM earns a return equal to the overall cost of capital, there is no financial gain to shareholders. Therefore, concerns about goldplating would be relevant only if a greater-than-normal rate of return was authorized.

FINANCIAL ANALYSIS

To explore the financial impacts of capitalization on utilities and ratepayers, we created a spreadsheet financial model of a utility's DSM activities. A printout of the model is contained in the appendix.

The model was developed from inputs jointly agreed upon by the representatives of Detroit Edison and Consumers Power. It represents a very rough hypothetical composite of Edison and Consumers, in terms of capital structure, rates, growth in demand, avoided costs and other important areas.

For purposes of this analysis, we assumed the utility mounted a DSM program with a budget of approximately 2% of revenue requirements. A program of this size would be moderately ambitious, in comparison to other utilities' DSM activities around the country (utilities with the most ambitious programs spend up to 5% of revenue requirements on DSM). This level is far above the current level of DSM spending in Michigan.

Due to the complexity of modeling the effects of capitalizing multiple years of program expenditures, for this analysis we modeled a one-year DSM program budgeted at \$75 million in utility costs. The \$75 million represents \$70 in incentives (rebates, loan buydowns, etc.) provided to customers, plus \$5 million in utility administrative costs. This investment yields energy and demand savings that are assumed to persist for 15 years. In each year of the 15-year period, the utility spends one-tenth of the original \$75 million (adjusted for inflation) to maintain the savings. These maintenance costs represent continuing incentive payments (say, to customers who participate in load management programs) plus ongoing monitoring and evaluation costs.

We modeled two basic cases for comparison. For the expensing case, we assumed that the utility recovers its DSM expenditures as they are incurred. This treatment approximates the use of a surcharge and balancing account mechanism, which continually matches receipts against actual expenditures and uses interest payments (positive or negative) to smooth out any differences.

For the capitalization case, we assumed the utility is allowed to capitalize its DSM initial investment over the 15-year period during which demand and energy reductions occur. We also assumed the yearly maintenance investments are capitalized over the remainder of the 15-year period. The rate of return applied to the unamortized balance is the utility's weighted-average cost of capital.

A 34% federal income tax rate is assumed. In this model, differences between book and tax accounts are ignored, so there is no provision for deferred tax accounting.

Table 4-1 presents key financial results for the expensing and capitalization scenarios. The upper section of the table shows the utility's cash flows under capitalization. In the initial year, there is an outflow of \$75 million—the original investment in DSM. Returns on the investment are collected over the next 15 years. Also in the next 15 years, there are additional outflows representing the

Table 4-1
Capitalization vs. Expensing

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	Lead
DSM Cash Flow (\$ millions)																	
Capitalization																	
Program Costs Plus Taxes	\$75.0	\$10.4	\$10.9	\$11.4	\$11.9	\$12.5	\$13.0	\$13.6	\$14.1	\$14.7	\$15.2	\$15.7	\$16.2	\$16.7	\$17.0	\$1.6	
Cost Recovery	\$0.0	\$16.3	\$17.2	\$18.3	\$19.4	\$20.5	\$21.8	\$23.1	\$24.5	\$26.1	\$27.9	\$29.9	\$32.5	\$36.0	\$41.4	\$53.7	
Net Cash Flow	(\$75.0)	\$5.8	\$6.3	\$6.9	\$7.4	\$8.1	\$8.8	\$9.5	\$10.4	\$11.4	\$12.7	\$14.2	\$16.3	\$19.3	\$24.4	\$52.1	
Expensing																	
Program Costs	\$75.0	\$7.9	\$8.3	\$8.7	\$9.1	\$9.6	\$10.1	\$10.6	\$11.1	\$11.6	\$12.2	\$12.8	\$13.5	\$14.1	\$14.8	\$15.6	
Cost Recovery	\$75.0	\$7.9	\$8.3	\$8.7	\$9.1	\$9.6	\$10.1	\$10.6	\$11.1	\$11.6	\$12.2	\$12.8	\$13.5	\$14.1	\$14.8	\$15.6	
Net Cash Flow	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Average Rate (cents/kWh)																	
Capitalization	9.344	9.559	9.745	10.802	11.014	11.242	12.450	12.710	12.988	14.370	14.689	15.031	16.615	17.008	17.432	19.212	12.009
Expensing	9.545	9.537	9.722	10.777	10.989	11.215	12.422	12.680	12.957	14.337	14.654	14.993	16.574	16.962	17.376	19.102	12.006
Difference	-0.200	0.022	0.023	0.024	0.026	0.027	0.028	0.030	0.031	0.033	0.035	0.038	0.041	0.047	0.056	0.110	0.002

maintenance investments, plus incremental tax payments to cover income taxes due on the return.

Utility Cash Flow

The utility's net cash flows from capitalization are shown on the third line of Table 4-1; they also are depicted graphically in Figure 4-1. These cash flows are present valued and summed on a cumulative basis in Figure 4-2; the utility's weighted-average cost of capital is used as the discount rate. Figure 4-2 shows that if the entire 15 years of cash flows are received, their net present value to the utility will be zero. If, on the other hand, cost recovery is cut off before the end of the 15-year period, the utility will have a negative cash flow in present value terms.

The middle portion of Table 4-1 restates what is assumed for the expensing scenario; namely, that in each year the utility's cost recovery for its DSM programs matches outlays, so there is no net gain or loss.

This analysis is the basis for the conclusion that capitalization is not financially advantageous to the utility. At best—that is, if full cost recovery during the amortization period is allowed—capitalization yields a neutral result. If recovery is curtailed prematurely (for one of the reasons cited earlier), capitalization produces a financial loss.

Average Rates

We used the same financial model to examine the effects of capitalization vs. expensing on the utility's average rates. These results are shown in the lower portion of Table 4-1 and are graphed in Figure 4-3. Average rates are derived by dividing revenue requirements by assumed sales. Larger rate jumps occur every three years; this reflects an assumption that general rate cases occur on a three-year cycle.

The average rates reported in the table reflect an implicit assumption that there is an automatic adjustment each year for DSM-related lost revenue. Since lost revenue would be the same whether DSM expenditures are capitalized or expensed, this assumption does not materially affect the results.

Figure 4-1
Cash Flow from Capitalization

Figure 4-2
NPV of Cash Flow from Capitalization
Cumulative

Figure 4-3
Expensing versus Capitalization
Average Rates

The table and graph show that in every year past the first year, the utility's average rate is slightly higher under capitalization than expensing. For the first year, expensing requires a slightly higher average rate because of the assumption that the full initial cost of the DSM program is collected in that year. (The difference is two-tenths of a cent, or two mills, per kWh). If the DSM program were proportionately much larger as a percentage of revenue requirements, this difference would be magnified.

Beyond the first year, rate differences between the two approaches are quite small, mostly less than one-half mill per kWh. On a levelized basis over the entire analysis period, capitalization is more costly, but only by nine one-hundredths of a mill per kWh.

The slightly higher cost of capitalization is a consequence of corporate income taxes. The utility must pay income tax on its pretax earnings, including the return on rate base. When an expenditure is capitalized instead of expensed, it creates additional earnings and a corresponding additional tax obligation, which is passed on to ratepayers. Thus, capitalization ultimately costs ratepayers more than expensing, even on a present-value basis, though the costs are spread out over time.

There is one caveat to this result: the present-value analysis uses the utility's cost of capital as the discount rate. If consumers' discount rate is higher than the utility's, then capitalization may look more favorable to consumers, since the higher rate could cancel out the undiscounted cost advantage of expensing.

V. DETAILED ANALYSIS: ELECTRIC REVENUE ADJUSTMENT MECHANISM (ERAM)

CAPSULE DESCRIPTION

An Electric Revenue Adjustment Mechanism, or ERAM, periodically reconciles the utility's actual base revenue to the utility's authorized base revenue.

Variances, positive or negative, are collected from or returned to ratepayers through an adjustment clause to the rate schedule. A forecast test year and attrition adjustments to base revenue compensate for changes in the utility's costs between rate cases.

An ERAM effectively adjusts for lost revenue due to DSM or self-generation. It eliminates any short-term financial gain to the utility from sales promotion. It also removes revenue fluctuations from causes beyond the utility's control, such as variations in weather and general economic cycles.

PURPOSE AND BENEFITS

ERAM was initially developed in California in 1981 for two principal reasons:

- To improve utilities' financial stability by reducing sales-related variation in their rates of return.
- To eliminate utilities' incentive to under-forecast sales in rate cases (in order to justify higher rates) and then to promote higher sales after rates are established (Ziering 1986).

It was recognized at the time that ERAM would eliminate the lost revenue problem for DSM, but this was evidently a side benefit rather than a principal reason for adopting ERAM. Adjusting for lost revenue and removing the sales promotion incentive have become the dominant purposes in most current discussions of ERAM.

By eliminating sales forecasts as a point of contention, ERAM expedites rate case proceedings (Pacific Gas & Electric 1985). An additional benefit of ERAM is that it permits greater experimentation in ratemaking without adverse financial consequences for the utility. If an experimental rate inadvertently affects the

collection of base revenue, ERAM reverses those effects (Marnay and Comnes 1990).

ERAM may seem to guarantee the utility a particular level of profits. While ERAM does make profits more predictable, it does not guarantee profits, since it makes no adjustments for deviations of costs from projected levels. A utility operating under ERAM can have lower profits than projected or can even post a loss if its base costs (costs not covered under a fuel clause or other pass-through mechanism) are greater than the costs built into base rates. Conversely, a utility can improve its profitability under ERAM by reducing costs.

Some analysts have speculated that the revenue-smoothing impacts of ERAM should reduce utilities' cost of capital. Indeed, this possibility was suggested in the original order establishing ERAM: "The revenue stability from [ERAM] should reduce [the utility's] risk and thus the size of the return" (California Public Utilities Commission, Decision No. 93887, December 30, 1981). To our knowledge, no one has tested this proposition by examining the costs of capital to utilities subject to ERAM.

BACKGROUND AND STATUS

The concept and name of ERAM were created in a 1981 case involving Pacific Gas & Electric (PG&E). PG&E was in dire financial straits, caused in large part by continuing cost and technical problems with its Diablo Canyon nuclear plant. The company proposed ERAM as a means of improving its financial stability. ERAM was endorsed by the commission staff and other parties to the case, and it took effect in 1982. Over the next three years, it was implemented for California's other major utilities (Marnay and Comnes 1990).

Some utilities in other states sought ERAM-like mechanisms in the 1980s but these requests were uniformly rejected. For example, in 1987 Connecticut Light & Power (CL&P) requested a "sales adjustment clause" for financial stabilization but was turned down. Interestingly, the commission's decision did not mention the potential effect on CL&P's incentive to pursue DSM (Connecticut Department of Public Utility Control, Docket No. 87-07-01, February 4, 1988).

Since 1988, various states' investigations into the financial disincentives affecting DSM have brought about renewed interest in ERAM. In this context, ERAM has been suggested for two reasons:

- It addresses the lost revenue problem affecting DSM.
- It decouples the utility's short-term profits from sales, meaning that the contribution from sales to coverage of the utility's fixed costs (including its allowed return or profit) is held constant. Former Maine commissioner David Moskowitz has termed such decoupling an essential feature of regulatory reform: "Breaking the link between profits and sales is an important step towards correcting the current regulatory system's [faulty] incentives" (Moskovitz 1989).

While investigations concerning decoupling are in progress in several states, only Connecticut and New York have followed California in adopting decoupling mechanisms.

In Connecticut, a partial decoupling plan was instituted in early 1990 for United Illuminating Company (UI). It is partial in that revenue is reconciled only within a certain bandwidth; above or below this range, no adjustments take place. As it happens, unexpectedly low sales due to the general economic downturn have kept UI's sales below the decoupling bandwidth, so its effects have not been felt (personal communication with Phil Turner, United Illuminating, October 1990).

In New York, the PSC's September 1989 order establishing a DSM incentive (including lost revenue adjustment) for Orange and Rockland (O&R) directed O&R to begin work on a decoupling proposal for consideration in its next rate case. A June 1990 settlement in O&R's rate case proposed the establishment of a Revenue Decoupling Mechanism (RDM) quite similar to ERAM. The commission approved the settlement in August 1990.

For the most part, utilities have opposed ERAM due to concerns that it will impair their profitability—although the California utilities have argued vigorously for its retention (Marnay and Comnes 1990). Some consumer advocates also have opposed ERAM because they believe it insulates utilities from competitive influences that help hold down rates. A recent Wisconsin ERAM proceeding was dropped after utilities and intervenors filed comments opposing ERAM (Newman and Schoengold 1990). Attitudes on both sides are subject to change, however, as the issue receives scrutiny in the several states studying regulatory incentives.

IMPLEMENTATION AND OPERATION

Legal/Regulatory Status

Michigan has, to our knowledge, no direct precedent for a mechanism that reconciles utility revenue collections to an authorized amount. Certain features of ERAM, however, are similar to other regulatory devices that have been used in Michigan.

As will be discussed below, ERAM requires that certain utility cost elements be adjusted periodically according to changes in external indexes. Adjustments of this type were in place in the late 1970s and early 1980s, when Michigan utilities' Other O&M costs were indexed to the CPI. At present, both Detroit Edison (through the Fermi settlement) and Michigan Consolidated Gas Company have mechanisms in place that adjust certain O&M expenses to changes in the CPI. (See Chapter II for more information on these precedents for indexing.)

A relevant question is whether cost indexing could conflict with the statutory prohibition against automatic adjustment clauses:

The commission shall not have the power to authorize or approve adjustment clauses that operate without notice and opportunity for a full and complete hearing, and all such clauses shall be abolished (MCL 460.6a(2)).

A utility attorney suggests that the current O&M indexing mechanisms cited above do not conflict with the statute because they are limited in duration (until the next rate case or the expiration of the settlement) and represent relatively small components of a larger computation of revenue requirements. These arguments would appear to hold true for ERAM as well, since indexing is necessary only in the years when general rate cases are not held, and the utility's costs would be examined comprehensively at each rate case.

In the absence of changes in the utility's costs, ERAM has the effect of adjusting the utility's rate of return up or down to coincide with the level that was set in the rate case. This effect (although not the mechanism for achieving it) is somewhat analogous to the Performance Incentive Provision (PIP) recently established for Michigan Consolidated Gas Company (Order in Case No. U-9475, April 12, 1990). If the utility's return on common equity over a year is outside the range of 12.25%-14.25%, a surcharge or credit is imposed on rates in the following year.

The total amount collected from or returned to ratepayers through the surcharge or credit is 50% of the difference between target and actual net income. Like ERAM, this should have the effect of stabilizing the utility's return.

In summary, there are indirect precedents for an ERAM-type mechanism in Michigan. Whether legal changes would be needed to implement an ERAM depends on the interpretation of the prohibition on automatic adjustment clauses.

Information, Decisions, or Circumstances Required for Implementation

Regular Cycle for General Rate Cases and Interim ERAM Cases

General rate cases are required to establish the utility's authorized base revenue and rates for the first year following the rate case. In subsequent years—until the next general rate case—an ERAM proceeding, of narrower scope than a full rate case, is needed to establish the factors used to adjust base revenue and to compute rate adjustments.

In theory, annual ERAM adjustments could take place indefinitely, and the next general rate case could be continually deferred. But such a practice would likely result in large divergences between the utility's actual costs and the costs assumed in computing authorized revenue requirements. A utility operating under ERAM, without a requirement for rate cases at certain intervals, would defer filing a rate case as long as its actual costs increased at a lesser rate than the indexes used for the annual ERAM adjustments.

The California utilities subject to ERAM are on three-year rate-case cycles: a general rate case, setting revenue requirements and rates for a defined future year (the test year), is held approximately every three years. In the interim, adjustments to rates are made in ERAM proceedings.¹⁵ A similar schedule is envisioned in New York for Orange & Rockland.

A regular rate-case cycle would be a major change for Michigan, where it is up to a utility or the PSC to initiate a case. Some smaller Michigan utilities have gone as much as 10 years between rate cases.

¹⁵ The ERAM proceeding is actually a part of the fuel adjustment clause proceeding, also known as ECAC (energy cost adjustment clause).

Future Test Year

As implied by the preceding paragraph, ERAM is predicated on use of a future test year for ratemaking, because fairness requires that the utility be compensated on the basis of the best available estimate of actual costs that will be incurred in the rate year. Michigan is among the states that use a future test year in general rate cases.

Mechanisms for Adjusting Base Costs

The most critical, and perhaps most elaborate, aspect of ERAM concerns the mechanisms used in non-rate-case years to adjust the utility's authorized base revenue. Such adjustments are needed because of the likelihood of changes in:

- Prices paid by the utility for goods and services that are components of the cost of service;
- The utility's capital structure and costs; and,
- The level of operations needed to meet the utility's obligation to serve (especially if there are significant changes in the number of customers).

Different types of adjustment procedures are appropriate for different components of base costs. Depending on the type of cost, one of five different adjustment procedures may be called for:

- *Indexing*—for costs that change primarily due to inflation, economic growth, and other factors largely external to the utility. Indexes can be based on national activity (e.g., the CPI) or on utility-specific data.
- *Forecasting*—for costs that can be projected but are unlikely to track any index; depreciation and gross operating property are examples.
- *Reconciliation*—for DSM costs and other areas, such as plant maintenance, where a utility's efforts to outperform a cost index would not be of long-run benefit to customers.
- *Updating*—For the embedded cost of debt (part of the cost of capital).

- *Calculation*—for components derived from other factors; income taxes and accumulated depreciation are examples (Central Maine Power 1990a).

Table 5-1 lists the principal components of base revenue and shows possible choices for the adjustment of each component.

Developing, applying, and verifying the adjustment procedures would require considerable effort by the utility and the PSC. This effort would be especially great if they used customized indexes rather than published indexes. For example, changes in certain operating costs could be tied to an index of similar costs incurred by a group of comparable utilities in lieu of the CPI.

As noted above, a special-purpose ERAM proceeding would have to be held annually. The proceedings would be limited to review and approval of the proposed cost adjustment factors.

Collection/Refund Mechanism

A mechanism to incorporate ERAM adjustments into rates would have to be established. In California, the mechanism is a surcharge or credit that is parallel to, but distinct from, the fuel adjustment clause. Changes in the ERAM factor and the fuel clause take place on the same cycle.

Michigan's PSCR statute would appear to prevent the incorporation of ERAM surcharges or credits into the PSCR factor. Therefore, a separate surcharge would have to be established. Like the PSCR factor, it would adjust annually.

A variant of this approach, adopted in New York for Orange & Rockland, is to defer collection or refund of any ERAM balances until the balance exceeds 1% of revenue requirements. When that threshold is reached, the change can be incorporated into base rates (if it coincides with a rate case) or applied as a surcharge or credit.

Table 5-1
Potential Adjustment Methods for Components of Base Revenue

Category	Line Item	Adjustment Mechanism
Operating Expenses	Operations and maintenance expenses	Indexed
	Except: Reconcilable DSM expenses	Reconciled
		Reconciled
	Depreciation	Forecasted
	Income taxes	Calculated
	Taxes other than income	Indexed or reconciled
Rate Base	Gross operating property	Forecasted
	Accumulated depreciation	Calculated
	Investment in associated companies	Forecasted
	Accumulated deferred taxes	Calculated
	Working capital	Forecasted
Cost of Capital	Allowed cost of capital	Updated and calculated
Adjustments to Earnings	Earnings in associated companies	Forecasted
	Other revenue	Indexed

Source: adapted from Central Maine Power (1990a).

Operating Requirements

Ongoing data required to adjust base revenue in non-rate-case years would be extensive. These data would be drawn from detailed reviews of the utility's accounts, as well as from outside sources (e.g., for cost escalation indexes).

Once the adjustment is established, tracking the variances between authorized and actual base revenue should not be difficult, since there is no need to identify the sources of variance.

POTENTIAL PROBLEMS OR CONCERNS

Bypass and its Effects on Average Rates

A long-standing concern about ERAM is that utilities will have insufficient incentive to discourage bypass by major customers. Bypass occurs when a customer leaves the system or substantially reduces its load, generally due to installation of privately owned on-site generating capacity. Since the short-term revenue loss is made up through ERAM, the utility may be indifferent to the loss of its customer.¹⁶ Rates to remaining customers, meanwhile, must rise to cover the fixed costs no longer being recouped from the bypassing customer.

Marnay and Comnes (1990) sum up the bypass pros and cons voiced in California:

Bypass, it is argued, adversely affects the capacity utilization and fuel mix of utilities, increases the State's dependence on imported fossil fuels, wastefully duplicates the State's generating capacity, confounds industry planning, and has negative environmental consequences. The most strident argument against bypass, however, is that the rates of customers remaining on the system rise because the burden of fixed cost recovery falls more heavily on a reduced customer base. Thus, the bypasser evades the common customer responsibility to keep the social contract of cost recovery. Furthermore, since bypassers in California can sell excess power, either to the utility or, to a limited extent, to other utility customers, the economic health of the traditional utilities can be further eroded. On the other hand, since

¹⁶If the bypasser becomes a customer of a company affiliated with the utility—say, a cogeneration subsidiary—the utility might even *prefer* that such bypass occurs.

most bypass projects cogenerate power and heat, they can contribute to improved energy efficiency, and, to the extent that such projects can provide both forms of end-use energy more cheaply than alternative commercial suppliers, economic efficiency can also be improved. Additionally, freely permitting bypass has also been advocated as a mean of easing the industry towards a deregulated future.

The bypass issue led to extensive discussion of selectively eliminating ERAM in California for larger customers, so that the utilities would have an incentive to retain them. Ultimately, however, ERAM was retained for all customers.¹⁷

As noted in the quotation above, bypass can offer efficiency and cost-effectiveness benefits. From an equity standpoint, however, concern about its impact on the rates charged other customers is valid.

Utility Complacency

Related to concerns about bypass is the notion that by assuring a certain revenue level, ERAM reduces the discipline of market competition and makes utilities complacent in their operations. ERAM, however, retains an incentive for the utility to cut costs; in fact, cutting costs below the level authorized in the test year or ERAM proceeding is the principal way the utility can earn a return greater than its cost of capital.¹⁸

Quality and Reliability of Service

The fact that cost-cutting is the only way under ERAM to increase utility profits is the source of a third concern; namely, that utilities will engage in excessive cost-cutting, with adverse consequences for quality and reliability of service. This

¹⁷ While ERAM was retained for California's major utilities, in 1990 it was eliminated for Pacific Power & Light (PP&L) in conjunction with that utility's experimental energy services program. PP&L has only a small service territory in California.

¹⁸ Since ERAM reconciles all base costs (i.e., costs exclusive of fuel and purchased power), the utility is assured of collecting any nonfuel variable costs, whether or not they are incurred. Therefore, the utility has a (presumably small) incentive to encourage sales-reducing DSM activities, since it collects the avoided variable costs.

concern can be addressed, in part, by continued regulatory vigilance over the quality of service. Other options are:

- Reconciling the utility's actual and projected expenditures in critical quality-of-service areas, such as production plant maintenance. Reconciling these costs removes any gain from short-term economizing.
- Creating a financial incentive for high quality of service. This is the approach taken in New York, where Orange & Rockland's overall rate of return can be adjusted $\pm$ 16 basis points on the basis of the company's performance on six measures of customer service.

FINANCIAL ANALYSIS

To explore the financial ramifications of ERAM, we developed the spreadsheet model described in the appendix. This model attempts to replicate the cyclical nature of the regulatory process, including annual fuel and purchased-power (PSCR) adjustments, and periodic general rate cases. Like the model used in the previous chapter to analyze capitalization, it is based on composite data developed by Detroit Edison and Consumers Power and represents a hypothetical Michigan utility.

We modeled four cases:

- A base case, reflecting the current regulatory environment and no DSM programs. General rate cases are assumed to take place every three years, and ratemaking is based on a future test year.
- An ERAM case, which adds ERAM adjustments in between the general rate cases.
- A DSM case, which adds a moderately aggressive DSM program to the assumptions of the base case. As in Chapter IV, we assumed that the DSM program starts out at about 2% of revenue requirements (starting at \$75 million in utility expenditures). We further assumed that the DSM effort expands 5% per year in real terms and continues for five years. The DSM impacts are cumulative—each year's program

increases the cumulative program impact. DSM impacts are assumed to persist for 15 years.

- A DSM-with-ERAM case, which combines the two preceding cases.

In each of these cases, we assumed that the utility's sales and operating costs exactly match the levels assumed for ratemaking. Note that the model is capable of simulating deviations in sales and/or costs from expected levels.

Table 5-2 summarizes key financial results from the model for a seven-year period. The seven years encompass three general rate cases (in years 1, 4, and 7) and four years of interim ERAM adjustments. The results in the table are graphed in Figures 5-1 through 5-3.

Figure 5-1 graphs the utility's return on equity (ROE). Note the base case ROE (marked by open boxes). In each of the three years with general rate cases (years 1, 4, and 7) ROE meets the authorized level of 14 percent. In the two years following the rate case (years 2-3 and 5-6 on the graph), return drops below the authorized level. This is because inflation occurring in the utility's base costs is not reflected in rates. (Inflation occurs in fuel costs also, but is passed through automatically to ratepayers through the PSCR clause.) After the second year of subauthorized ROE, the utility initiates a rate case, which restores earnings to the target level.¹⁹

Now observe what happens when ERAM is imposed on the system. The ERAM case is shown by the horizontal line near the top of the graph. In every year, actual ROE equals the target level of 14%. Of course, this assumes that the utility's costs exactly match those assumed for ratemaking; in practice, its actual costs would be expected to differ from the base established in the test year or the updated base established through the ERAM proceeding.

The third case, marked by diamonds in Figure 5-1, shows the effects of a DSM program without ERAM. For this model run, we assumed full and timely recovery of the DSM program costs, such as might occur through a surcharge mechanism. Lost revenue occurs, however, as the DSM-induced decline in sales cuts into the utility's recovery of fixed costs. The result is a V-shaped pattern similar to the base case, but with even lower returns in the non-rate-case years.

¹⁹ In the model's current form, the interval between rate cases is exogenous. In the real world, falling ROE is usually the event that triggers a rate case.

Table 5-2
Financial Results with and without ERAM and DSM

	Year						
	1	2	3	4	5	6	7
Return on Equity							
Base Case	14.0%	13.6%	13.1%	14.0%	13.4%	12.8%	14.0%
ERAM	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%
DSM	14.0%	12.6%	11.1%	14.0%	12.3%	11.8%	14.0%
DSM with ERAM	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%
Common Earnings (\$ millions)							
Base Case	\$392	\$381	\$368	\$392	\$377	\$359	\$392
ERAM	\$392	\$392	\$392	\$392	\$392	\$392	\$392
DSM	\$392	\$353	\$312	\$392	\$344	\$329	\$392
DSM with ERAM	\$392	\$392	\$392	\$392	\$392	\$392	\$392
Average Rate (\$/kWh)							
Base Case	\$0.095	\$0.097	\$0.099	\$0.102	\$0.105	\$0.107	\$0.112
ERAM	\$0.095	\$0.097	\$0.100	\$0.102	\$0.105	\$0.108	\$0.112
DSM	\$0.098	\$0.100	\$0.102	\$0.109	\$0.111	\$0.110	\$0.115
DSM with ERAM	\$0.098	\$0.102	\$0.105	\$0.109	\$0.112	\$0.112	\$0.115

Figure 5-1

Return on Equity

With and Without DSM and ERAM

Figure 5-2

Common Earnings

With and Without DSM and ERAM

Figure 5-3

Average Rates

With and Without DSM and ERAM

At each rate case, new rates are set against the updated sales level for the test year, so the lost revenue problem temporarily vanishes. It returns in the following year as the expanding DSM program again reduces sales below the test-year level.

Finally, the fourth case—DSM with ERAM—yields the target 14% ROE in every year; the ROE line coincides with that for the ERAM case.

Figure 5-2 shows similar results, stated in terms of the utility's dollar earnings accruing to common equity rather than as a percentage. The value of this graph is that it quantifies the lost revenue problem, which is shown as the difference in earnings between the base case and the DSM case (without ERAM). For the seven years depicted, DSM-induced revenue ranges from zero (in the years with general rate cases) to \$56 million (in year 3). For comparison, the DSM budget for year 3 is \$101 million.

Figure 5-3 shows the utility's average rates for the four cases. The DSM-with-ERAM case results in the highest average rates; this is expected, since the level of sales is declining (putting upward pressure on rates) and ERAM automatically adds a factor to compensate for inflation in the utility's base costs. In year 5, the difference between the DSM-with-ERAM case and the base case reaches \$.007 (7 mills) per kWh. The favorable side of this case is that the higher rates enable the utility to meet its target rate of return in every year.

Finally, note that the cases examined above assume no incremental self-generation (bypass) by customers during the analysis period. Additional self-generation would heighten the magnitude, but not alter the direction, of the results. For example, adding self-generation without ERAM would depress earnings below the DSM-without-ERAM line in Figure 5-1, because greater loss of revenue to cover fixed costs would occur. Adding self-generation to the DSM-with-ERAM case would result in the highest average rates, due to ERAM's automatic adjustment for increased lost revenue.

VI. DETAILED ANALYSIS: SHARED BENEFITS

CAPSULE DESCRIPTION

The shared-benefits mechanism gives the utility a bonus equal to a specified percentage of the net benefits or savings resulting from selection of DSM or purchased-power options in lieu of conventional supply-side resources.

PURPOSE AND BENEFITS

DSM or purchased-power resources are considered cost-effective if their addition to the utility's resource plan reduces the plan's total cost. The shared-benefits mechanism (known also as shared savings or share of net resource savings) allows the utility to capture a share of the savings flowing from selection of such measures. The balance of the savings accrues to ratepayers.

The shared-benefits mechanism is intended to give the utility a positive financial motivation to acquire bonus-eligible resources that otherwise do not contribute directly to profits. If such resources are perceived as risky investments, the bonus can offset that risk.

BACKGROUND AND STATUS

The idea of sharing benefits has many applications in the energy field. Shared-savings contracts, for example, allow building owners to receive the benefits of energy-efficiency improvements in return for ceding a share of the savings to the contractor. Benefit sharing is also embodied in power interchanges among utilities, in which the cost savings is split between the buyer and the seller.

The shared-benefits approach has been widely proposed as a means of giving utilities a bonus incentive to select DSM resources. It is the basis for DSM incentive mechanisms now in place for electric utilities in California, Colorado, New Hampshire, New York, Oregon, and Rhode Island. Commission proposals in Iowa, New Jersey, Nevada, Ohio, Pennsylvania, and Ohio have endorsed it.

A shared-benefits bonus mechanism was instituted in New York for Orange and Rockland utilities in September 1989. The commission determined that O&R

would be allowed to capture 20% of the net benefits attributable in each year to DSM. This decision set the pattern for shared-benefits mechanisms instituted for New York's other investor-owned utilities (New York Public Service Commission, Opinion No. 89-29, September 12, 1989).

The New England Electric System (NEES) filed shared-benefits proposals for its retail operating companies in Massachusetts, Rhode Island, and New Hampshire in September 1989. NEES proposed that it receive 5% of the gross benefits (energy and capacity savings alone, before subtracting program costs) plus 10% of the net benefits attributable to its DSM programs. This proposal was substantially adopted in Rhode Island and New Hampshire.²⁰ The Massachusetts commission substituted a bonus per kW and KWh saved for the shared-benefits concept.

In California, shared-benefits mechanisms were approved for San Diego Gas & Electric and Pacific Gas & Electric in August 1990, giving the utilities 13.5% and 15% of net benefits, respectively. Shared-benefits mechanisms were approved in Colorado for Public Service of Colorado in November 1990 and in Oregon for Portland General Electric in January 1991.

We are aware of no shared-benefits mechanisms that currently allow utilities to capture a share of the savings from purchased-power arrangements. In 1990 Central Maine Power (CMP) proposed that it receive 25% of the difference between its levelized avoided cost and the levelized contract price for all purchased-power agreements of one year's duration or longer. This incentive would have applied to long-term purchases from both utility and nonutility sources (Central Maine Power 1990b). The portion of the proposal dealing with purchased power was dropped, however, when CMP submitted a revised proposal in conjunction with other parties in February 1991. While purchased power incentives have not received serious discussion in Maine, CMP hopes that it can take the issue up again in the near future (personal communication with Curtis Call, Central Maine Power, February 1991).

Shared-benefits proposals have received broad support from commissions and many intervenors because they reward cost-effective choices while ensuring that a majority of the benefits accrue to ratepayers.

²⁰ The Rhode Island commission added a requirement that a threshold level of energy and demand savings be achieved before the utility begins to earn a bonus.

IMPLEMENTATION AND OPERATION

Legal/Regulatory Status

Michigan has no direct precedent for a shared-benefits mechanism, but there is precedent for awarding a utility a performance-based bonus for DSM. As described in Chapter II, Consumers Power is currently eligible to receive a bonus on certain conservation programs that were approved by the PSC in March 1990. Consumers will receive a cents-per-kWh bonus based on estimated savings resulting from the program, with higher cost-effectiveness (as measured by dollars spent per kWh saved) earning a higher bonus. The bonus is collected through a supplement to the conservation surcharge (Order No. U-9496, March 13, 1990).

We interpret the Consumers case to indicate that it is within the PSC's authority to award a utility a bonus in excess of the direct costs incurred to obtain DSM resources. Presumably it would have the same authority to award a bonus on purchased-power resources.

Information, Decisions, or Circumstances Required for Implementation

While the concept of a shared-benefits bonus is straightforward, implementation varies. Choices that would have to be made to implement a shared-benefits bonus in Michigan are described below.

Definition of Benefits

The net benefits, or gross benefits minus costs, to be shared under this type of incentive can be determined from various perspectives. Possible choices include:

- *Total Resource Cost (TRC) Perspective.* The TRC perspective (also known as the all-ratepayers' perspective) considers the total benefits and costs of a resource option, including any costs borne by program participants. Incentives paid to customers to stimulate participation are not considered in the TRC perspective because they are viewed as transfer payments rather than real resource costs.

- *Societal Perspective.* The societal perspective is a variant of the TRC perspective that includes the effects of quantifiable externalities, such as environmental impacts, as either benefits or costs.
- *Utility Cost (UC) Perspective.* The UC perspective measures the cost of a resource option from the utility's standpoint. Incentives paid to customers are counted as a cost. Costs borne by program participants are excluded (California Public Utilities Commission and California Energy Commission 1987).

Shared-benefits mechanisms implemented to date employ a variety of perspectives to estimate net benefits. In California, for example, San Diego Gas & Electric's shared-benefits bonus is calculated from the TRC perspective, while Pacific Gas & Electric's bonus is calculated from the UC perspective. In New York, the UC perspective is taken, but benefits are adjusted upward for the external environmental benefits of DSM, as they might be in the societal perspective.

In comments on Detroit Edison's IRP, the PSC staff stated that utilities' plans should be optimized to minimize utility revenue requirements (Michigan PSC Staff 1990). Use of the UC perspective for measuring net benefits would be consistent with this view, because programs that provide the greatest UC net benefit will reduce revenue requirements by the greatest amount. Note, however, that other states' IRP regulations define minimization of total resource costs as the objective of IRP.

Any of the UC or TRC perspectives is a reasonable choice for measuring net benefits to be shared. More important than the choice of perspective is a utility's consistent use of a single perspective.

Avoided Cost Methodology

Estimation of net benefits relies in part on the concept of avoided costs—the resource costs the utility would incur if it did *not* select the resource option in question. Avoided energy and capacity costs are treated as benefits in both the UC and TRC perspectives.

There are various competing methodologies for estimating avoided costs, and it is beyond the scope of this study to suggest a particular methodology. Further, the PSC is reconsidering the question of avoided cost determination with respect to

power purchases from independent power producers eligible for treatment as "qualifying facilities" under the federal Public Utilities Regulatory Policy Act (Order in Cases U-8869 and U-9798, December 5, 1990). The points to be made here are simply that the PSC must specify a particular methodology and must be able to verify the utility's calculation of its avoided costs.

Ex Ante vs. Ex Post Calculations

Two alternative methods can be followed to estimate the net benefits of resource options:

- *Ex Ante Method.* In this method, net benefits are calculated using predetermined estimates of the net benefits and costs of the resource on a per-unit basis. As resources are secured, the per-unit estimates are scaled up by the appropriate factor (e.g., number of units installed, amount of energy purchased) to determine the total net benefits.

As an example, suppose a DSM program will replace conventional incandescent lamps with high-efficiency compact fluorescent lamps. In advance of the program, the utility would estimate several variables, including:

- The watts saved per lamp.
- The lamp's expected hours of operation and useful life.
- The relevant time-differentiated avoided costs.
- The installed cost per lamp, including an allocation of the utility's program administration costs.
- Net-to-gross factors, used to adjust the savings to reflect what would have occurred in the absence of the utility program.

From the above information the utility would compute the net benefits per lamp installed. The information and the calculations would typically be reviewed and approved by the commission staff. Then, as the program progresses, the actual number of units would be tallied periodically (at least once per year). The product of the units installed and the net benefits per unit would yield the total net benefits to be shared.

An analogous procedure would be followed for purchased-power contracts if they were made eligible for the shared benefits bonus. Based on a levelized contract price and levelized avoided costs, the net benefit to the utility per kWh delivered would be estimated. Actual kWh deliveries would be multiplied by this estimate to compute the total net benefits to be shared.

- *Ex Post Method.* In this method, net benefits are estimated *after* the resources have been secured. To the maximum extent possible, this method relies on the results of evaluation studies that are performed after the DSM measures are in operation or the power has been purchased. Calculations would be similar to those described above. The commission staff would review and approve the calculations.

The *ex post* method has the appeal of tying the bonus calculation to the latest available estimates of benefits, which may be more accurate than the *ex ante* estimates.

The advantage of the *ex ante* method is that it reduces the uncertainty of the size of the bonus. Other things being equal, greater certainty in the bonus amount should increase the attractiveness of the mechanism to the utility—and therefore allow a smaller bonus percentage to yield a reward of equivalent value. Further, *ex ante* determination constrains the size of the bonus, and hence its potential rate impact, to an agreed-upon amount.

If the *ex ante* method is selected, the per-unit benefit estimates should be the same values used in the cost-effectiveness analysis underlying program selection. Using the same values for both purposes should tend to counteract any tendency by the commission or utility to exaggerate a resource's benefits.

Ongoing Commitment to Program Evaluation

Regardless of which benefits-estimation method is adopted, there should be a formal commitment to rigorous, continuing evaluation of benefits. Evaluations are needed to update the estimates of actual benefits and to refine the estimates for use in planning.

The difference between the *ex ante* and *ex post* approaches to evaluation is that in the former case, evaluation results are never used retrospectively to reduce a

utility's shared-benefits bonus; rather, they are used only on a forward-going basis to refine the *ex ante* estimates of benefits to be realized from future installations or purchases.²¹ This principle was accepted in the 1990 collaborative process used to develop new DSM programs in California:

A primary feature of the measurement plan should be the clear designation of activities that will improve the ability to measure program load impacts. . . . [T]he results of these post-implementation measurement activities for each load impact parameter should *not*, unless by mutual agreement, be used retroactively. . . . Results of such studies, however, *should* be used . . . for developing estimates for subsequent program implementation. [Emphasis in original]

Present-Valued Bonus vs. Progress Payments

A shared-benefits bonus can be awarded in at least two ways:

- *Present-Valued Method.* The utility's bonus is calculated as a lump sum from the estimated lifetime net benefits. Collection of the bonus would likely then be spread over a reasonably short period—perhaps a year.
- *Progress Payments Method.* The bonus is calculated and paid yearly, based on the estimated net savings occurring in that year. Under this method, the bonus applicable to a DSM measure with a useful life of 15 years would be received in installments over the 15-year period.

While both methods should yield financially equivalent benefits to the utility, the present-valued method is presumably more attractive to the utility, since it is more likely that the full bonus will be realized. The progress payments method, on the other hand, may be preferred because it would have a smoother impact on rates; also, it may give the utility a stronger incentive to ensure that the benefits of a resource are maintained over the full expected period.

²¹ An exception to this rule would be made if evaluation showed that the number of units installed or kWh purchased were less than the utility reported.

Savings Share

The share of savings to be received by the utility would have to be established, possibly through negotiation with the commission staff. Many variations on a straight percentage share are possible. For example, the utility's share could adjust with the level of net benefits; or a threshold benefits level could be established, so that sharing begins only after a certain target level of benefits has been achieved.

It is also possible to design a shared-penalty mechanism so that the utility would be financially penalized if it failed to meet certain net benefit goals. For example, if the estimated net benefits fell short of the target, the utility could be required to pay a penalty equal to a percentage of the difference between the actual and target benefits.

Bonus Collection Mechanism

A procedure for collecting the bonus would have to be developed. A logical choice would be to fold bonus collection into the mechanism for recovering direct program costs and/or lost revenue. If an ERAM mechanism were established, the bonus could be incorporated into the ERAM surcharge or credit.

The bonus to be received in a particular year could be collected prospectively, with a reconciliation procedure after the end of the year to adjust for any over- or undercollection. Consumers Power's current conservation bonus (approved in Case U-9496) allows the company to collect most of its bonus prospectively.

Operating Requirements

As described above, ongoing evaluation activities should be an integral part of a shared-benefits mechanism. The commission would review the evaluation methodologies and results. A feedback check would ensure that the results of evaluations are taken into account in program revisions and future estimates of net benefits.

POTENTIAL PROBLEMS OR CONCERNS

Cream-Skimming

Other states' proceedings that have examined shared-benefits mechanisms have registered concern that this approach could encourage cream-skimming, or failure to exploit all cost-effective resource choices. The utility might focus its energies on the resources that have the highest benefit-to-cost ratios because they would yield the greatest bonuses, while other options that are less attractive but nonetheless cost-effective would be ignored.

We think the cream-skimming argument has little merit. A straightforward shared-benefits mechanism rewards the utility for any resource that offers benefits in excess of costs. A profit-maximizing utility subject to such an incentive should attempt to exploit all such resources.

Difficult-to-Quantify or Non-Cost-Effective Programs

Some utility conservation programs produce benefits that are difficult to quantify; programs that primarily provide information to customers are often in this category. Other programs may serve social or equity goals, even though they do not appear cost-effective by standard economic tests. Programs that provide assistance to residential low-income customers may be of this type. For both types of programs, a shared-benefits bonus is inappropriate.

One option for handling programs that are difficult to quantify or not cost-effective is to simply exclude them from eligibility for the shared-savings bonus. Alternatively, if there is concern that the utilities would lessen their commitment to such programs in the absence of a bonus, a different bonus mechanism, such as a markup on expenditures, could be used.

FINANCIAL ANALYSIS

To analyze the potential financial impacts of a shared-benefits mechanism, we used the same spreadsheet model that we used to analyze ERAM. See the appendix for a description of the model and sample printout. The model attempts to replicate the cyclical nature of the regulatory process, including annual fuel and purchased power (PSCR) adjustments, and periodic general rate cases. It is based

on composite data developed by Detroit Edison and Consumers Power representing a hypothetical Michigan utility.

We modeled four cases:

- A base case, reflecting the current regulatory environment and no DSM programs. General rate cases are assumed to take place every three years, and ratemaking is based on a future test year.
- A DSM case, which adds a moderately aggressive DSM program to the assumptions of the base case. As in the previous chapters, we assumed that the DSM program starts out at about 2% of revenue requirements (starting at \$75 million in utility expenditures). We further assumed that the DSM effort expands 5% per year in real terms and continues for five years. The DSM impacts are cumulative—each year's program increases the cumulative program impact. DSM impacts are assumed to persist for 15 years. No bonus is assumed in this case.
- A DSM-with-bonus case, with the bonus equal to 15% of the net benefits, computed from the TRC perspective. A 15% bonus is typical of those being received in other states (although the bonus percentages cover a wide range). The bonus is assumed to be collected on a present-value basis concurrent with the DSM programs.
- A second DSM-with-bonus case, substituting the UC perspective for the TRC perspective.

In each of these cases, we assumed that the utility's sales and operating costs exactly match the levels assumed for ratemaking. We assumed the absence of ERAM or any other type of lost-revenue adjustment mechanism.

Table 6-1 summarizes key financial results from the model for a seven-year period. The seven years encompass three general rate cases (in years 1, 4, and 7). The results in the table are graphed in Figures 6-1 through 6-3.

Figure 6-1 shows the same V-shaped patterns to return on equity that were noted in Chapter V in the absence of ERAM. For all cases, the utility's ROE drops in the two years after a general rate case. The drop is most pronounced for the straight DSM case (no bonus). When the shared-benefits bonus is applied (either

Table 6-1
Financial Results with and without DSM and Shared-Benefits Bonuses

	Year						
	1	2	3	4	5	6	7
Return on Equity							
Base Case	14.0%	13.6%	13.1%	14.0%	13.4%	12.8%	14.0%
DSM	14.0%	12.6%	11.1%	14.0%	12.3%	11.8%	14.0%
Shared Benefits/15% TRC Bonus	15.0%	13.7%	12.4%	15.5%	14.0%	11.8%	14.0%
Shared Benefits/15% UC Bonus	15.4%	14.2%	12.9%	16.0%	14.6%	11.8%	14.0%
Common Earnings (\$ millions)							
Base Case	\$392	\$381	\$368	\$392	\$377	\$359	\$392
DSM	\$392	\$353	\$312	\$392	\$344	\$329	\$392
Shared Benefits/15% TRC Bonus	\$419	\$384	\$348	\$434	\$392	\$329	\$392
Shared Benefits/15% UC Bonus	\$430	\$397	\$362	\$449	\$409	\$329	\$392
Average Rate (\$/kWh)							
Base Case	\$0.095	\$0.097	\$0.099	\$0.102	\$0.105	\$0.107	\$0.112
DSM	\$0.098	\$0.100	\$0.102	\$0.109	\$0.111	\$0.110	\$0.115
Shared Benefits/15% TRC Bonus	\$0.100	\$0.101	\$0.103	\$0.110	\$0.112	\$0.110	\$0.115
Shared Benefits/15% UC Bonus	\$0.100	\$0.102	\$0.104	\$0.111	\$0.113	\$0.110	\$0.115

Figure 6-1

Return on Equity

With and Without DSM and Bonus

Figure 6-2

Common Earnings

With and Without DSM and Bonus

Figure 6-3

Average Rates

With and Without DSM and Bonus

on a TRC or UC basis), it is sufficient to offset the disadvantages of DSM, as ROE rises above the base case (except in year 3). Note that in year 6, ROE for the two bonus cases drops down to the level of the DSM case; this is because the utility's DSM program stops after year 5.

Figure 6-2 shows similar results, stated in terms of the total dollar earnings accruing to common equity. The net bonus captured by the utility, after adjusting for lost revenue, appears as the vertical distance from the bonus line to the base case line. In year 5, for example, earnings with the TRC bonus are \$392 million, compared to \$377 million for the base case. The difference of \$15 million is the amount the utility receives in excess of lost revenue.

Both Figures 6-1 and 6-2 show that the UC bonus perspective consistently yields slightly higher bonuses for the utility. This holds true, in general, for DSM programs that have significant energy-saving benefits relative to their peak-load-reduction impacts. The comparison might switch in favor of the TRC perspective if the DSM programs were assumed primarily to reduce peak load.

Figure 6-3 shows the average rates that would result in the four cases. The three DSM cases result in average rates that are consistently higher than the base case. In year 4, the differences reach their maximum, with the DSM bonus cases yielding rates that are approximately 0.9 cents (9 mills) above the base case.

Note that the financial impacts of the bonus cases would be smaller if the bonuses were collected over the period of DSM benefits (progress payments) instead of at the start (present-valued).

Finally, we have not modeled shared-benefits incentives for purchased power resources. Adding purchased power to the analysis would heighten the magnitude, but not change the direction, of the results.

VII. CONCLUSIONS AND RECOMMENDATIONS

This report concludes the first phase of the Michigan Regulatory Incentives Study. The task facing the Study Policy Group is to draw upon the findings in this report to set the direction for further analyses and the possible formulation of proposals to implement resource selection incentives.

This chapter presents Barakat & Chamberlin's conclusions with respect to the three incentive options analyzed in Chapters IV through VI and offers recommendations for next steps.

CONCLUSIONS

Capitalization

Capitalization is a feasible alternative to expensing as a cost recovery method for DSM expenditures. It is not likely to be suitable for purchased-power arrangements, since their costs are not normally front-loaded.

Capitalization strengthens the analogy between DSM and supply-side resources and may, in a theoretical sense, provide better price signals to ratepayers. But it may be disadvantageous to the utility. The risk of incomplete cost recovery is higher than with expensing, and rates may well be higher, because of tax effects. While the utility earns a return on the unrecovered balance, it does not receive any greater returns, in a present-value sense, than it does under expensing.

Broad-based capitalization of DSM could be undertaken in Michigan at the PSC's direction. Implementation requirements are significant but feasible. Its advantages compared to the current conservation surcharge system (with modifications) appear at this time, however, to be slight. If a Michigan utility undertook a very large-scale, short-term DSM program (say, of a few years' duration at most), capitalization could be advantageous, because it would spread over several years what might otherwise be a large short-term rate increase.

For the foreseeable future, we believe the need for adequate DSM cost recovery in Michigan would be best served by a flexible form of expensing that would adjust revenue up or down in line with expenditures. This approach could be achieved through modification of the current conservation surcharge system.

ERAM

An electric revenue adjustment mechanism, or ERAM, would serve the purpose of compensating the utility for lost revenue associated with DSM and cost-effective bypass. It would go beyond mere lost revenue adjustment to achieve the full decoupling of profits from the level of utility sales.

Financial modeling demonstrates that ERAM would likely give utilities greater revenue and earnings stability than they enjoy under current regulation. They would retain the ability to earn profits in excess of their allowed rate of return by cutting costs below the level authorized in the general rate case, as updated through ERAM proceedings. Whether the utility would earn above or below its authorized return in a non-rate-case year would depend heavily on the adjustments to base revenue authorized through ERAM.

While the California utilities believe that institution of ERAM was a net gain, utilities elsewhere are for the most part wary of ERAM. Some regulators and many intervenors are wary also, because ERAM represents a large-scale change in rate-base/rate-of-return regulation and shifts certain risks now borne by utilities to ratepayers.

For Michigan, the practical issues involved in moving to ERAM loom large. ERAM requires a regular cycle for general rate cases as well as annual proceedings to update utilities' authorized base revenue; both types of proceedings must be completed on tight schedules. Further, substantial technical issues related to the adjustment of base costs would have to be addressed.

Finally, Michigan's experience with various cost and profitability adjustment mechanisms in the early 1980s remains an important consideration. Any effort to implement ERAM in Michigan would run the risk of reviving the substantial political and public opposition that led to those earlier mechanisms' demise.

Shared Benefits

The shared-benefits approach to providing a bonus above costs for DSM is growing in popularity in other states. It has several attributes to recommend it. Perhaps the most important are that it is intuitively understandable and it is directly linked to performance. Additionally, most formulations ensure that the vast majority of the savings attributable to eligible resources accrue to ratepayers.

The shared-benefits approach has been proposed elsewhere for purchased power resources but has not been implemented in any jurisdiction. While purchased power may not have the same risk complexion or disincentives as DSM, utilities probably have insufficient incentives to make optimal purchases; this problem could be addressed through inclusion of such resources in a shared-benefits bonus.

If coupled with an adjustment for DSM-related lost revenue, a shared-benefits incentive would be expected to make alternative resource choices more attractive. Whether it would be sufficient to compensate the utility for the perceived risks of making a particular resource choice would obviously depend on the size of the share retained by the utility.

There is already precedent in Michigan for a performance-based DSM bonus; we infer that implementation of a shared-benefits bonus would not require any significant legal or regulatory changes. There would, however, have to be a strong system for continuing evaluation of resources. While evaluation is an important part of any DSM program, it grows in importance when significant bonus dollars are at stake.

RECOMMENDATIONS

The models developed for this study illustrate the approximate financial impacts of the incentive mechanisms under consideration. We recommend, however, that the Study Policy Group carefully review the models' inputs and algorithms before too much credence is placed on the numerical results reported herein.

Once a final base case is established, sensitivity analyses can be performed to expand the understanding of the incentive mechanisms. Given the models' spreadsheet framework, making enhancements to model additional details or mechanisms should not be difficult.

The original plan for the study envisioned that in the next phase Consumers Power and Detroit Edison would conduct independent assessments of the three options considered in detail in this report. Before that phase begins, however, we urge the Study Policy Group to consider whether the list of options to be focused on should be altered or expanded. More specifically, we suggest that:

- Unless there is strong interest in capitalization, the mechanics and legal requirements of a mechanism for expensing-type cost recovery be

investigated. (The financial implications of expensing have already been illustrated in this report.)

- The viability of ERAM be carefully weighed. Members of the Study Policy Group and their respective organizations are in the best position to assess (1) whether the burden of additional proceedings could be accommodated within Michigan's already crowded regulatory docket; and (2) whether ratepayers would accept the wholesale changes in regulatory philosophy that are part and parcel of ERAM. If the results of this examination suggest that ERAM is not viable, the Study Policy Group should concentrate its further efforts on analysis of resource-specific lost revenue adjustments.

REFERENCES

- California Collaborative Process. 1900. *Appendix A: Measurement Protocols for DSM Programs Eligible for Shareholder Incentives*. January.
- California Public Utilities Commission and California Energy Commission. 1987. *Standard Practice Manual: Economic Analysis of Demand-Side Management Programs*. Sacramento: California Public Utilities Commission.
- Central Maine Power Company. 1990a. Revised Proposal. Docket No. 90-085. August 1.
- _____. 1990b. Details of Shared Benefits Incentive Program. Docket No. 90-085. September 21.
- _____. 1990c. Details of Performance Target Incentive Program. Docket No. 90-085. October 17.
- _____. Department of Public Utility Control. 1990. Docket No. 89-08-12. January 24.
- Consumers Power Company. 1989. *Biennial Energy Conservation Report*. Submitted in Case U-9496. October.
- Consumers Power Company. 1990. *Integrated Resource Planning Report*. October.
- Counihan, Richard H. "Adding Conservation to the Rate Base." *Governance: Harvard Journal of Public Policy* (Summer-Fall 1986):55-58.
- Detroit Edison Company. 1989a. *Demand Side Program Report*. (Revision of December 1988 report.) July.
- _____. 1989b. *Integrated Resource Plan 1990-2004*. December 1989.
- Electric Power Research Institute. 1988. *Status of Least-Cost Planning in the United States*. EPRI EM-6133.

- Energy Conservation Committee. 1988. Statement of Position of the NARUC Energy Conservation Committee on Least-Cost Planning Profitability. July 26.
- Faruqui, Ahmad, Ken Seiden and Steven D. Braithwait. "Impact of Utility Demand-Side Management Programs on US Electricity Demand: 1990-2010." *Proceedings of the 1990 ACEEE Summer Study on Energy Efficiency in Buildings*. Volume 5. August.
- Hellman, Marc M., James W. Hagerman, and Ed Busch. 1990. *Investigation into Incentives for Acquisition of Conservation Resources by Electric Utilities*. Salem: Oregon Public Utility Commission. April.
- Krasniewski, R. J. and R. J. Murdock. 1980. "Residential Conservation Service Programs and Their Cost Recovery." *Public Utilities Fortnightly* 105 (June 5): 13-18.
- Marnay, Chris and G. Alan Comnes. 1990. *Ratemaking for Conservation: The California ERAM Experience*. Lawrence Berkeley Laboratory. LBL-28019. March.
- Michigan PSC Staff 1990. *The Michigan Public Service Commission Staff Report on Detroit Edison Company's 1990 Integrated Resource Plan*. August.
- Moskovitz, David. 1988. "Will Least-Cost Planning Work without Significant Regulatory Reform?" Paper presented at the NARUC Least-Cost Utility Planning Conference, Aspen, Colorado. April 12.
- _____. 1989. *Profits & Progress Through Least-Cost Planning*. Washington, D.C.: National Association of Regulatory Utility Commissioners.
- _____. 1990. Speech to NYSERDA Workshop on Regulatory Incentives, Saratoga Springs, New York. October 10.
- _____ and Richard B. Parker. 1988. "How to Change the Focus of Regulation So As to Reconcile the Private Interest with the Public Goals of Least-Cost Electric Planning." Paper presented to the Sixth NARUC Biennial Regulatory Information Conference, Columbus, Ohio. September.

New York Public Service Commission Staff. 1990. "Staff Position Paper Advocating Adoption of a Modified Decoupling Mechanism." Case 89-E-176. February 16.

Newman, Paul C. and David Schoengold. 1990. "Back to Basics: An Innovative Approach Called Traditional Regulation." Paper presented to the EPRI Conference on Innovations in Pricing and Planning, Milwaukee. May 2-4.

Ohio Consumers' Counsel. 1990. "Comments of the Office of the Consumers' Counsel." Case No. 90-723-EL-COI. August 22.

Pacific Gas & Electric Company. 1985. *Resource: An Encyclopedia of Utility Industry Terms*. San Francisco: Pacific Gas & Electric Company.

Puget Sound Power & Light Company. 1990. Testimony submitted to the Washington Utilities & Transportation Commission. August.

Reid, Michael W. 1988. *Ratebasing of Utility Conservation and Load Management Programs*. Washington: The Alliance to Save Energy.

Ziering, Mark. 1986. *Risk, Return, and Ratemaking: A Review of the Commission's Regulatory Mechanisms Pursuant to D.85-12-078*. Sacramento: California Public Utilities Commission. October 1.

APPENDIX

FINANCIAL MODELS

OVERVIEW

In this appendix, we describe the two computer models Barakat & Chamberlin developed to illustrate the financial impacts of various regulatory incentive mechanisms. These spreadsheet models capture the basics of traditional regulatory finance and the most important aspects of different incentive mechanisms. They do not, however, reflect some of the more complicated elements of regulatory finance. In some cases, we simply ignored less important elements, while in others we employed various shortcuts.

We have developed two different models: a single-year model and a multiyear model. The single-year model provides detailed financial information for a single year of resource investments, but covers impacts occurring over all years of the investment life. In this report, we used the single-year model to illustrate certain effects of program cost recovery. However, this single-year approach cannot adequately demonstrate important impacts of certain incentive mechanisms. For example, the impact of lost-revenue recovery depends on the divergence between actual DSM sales impacts and levels estimated for the test year. We developed the multiyear model to capture the effects of multiple, overlapping years of resource investments.

SINGLE-YEAR MODEL

A printout of all inputs and outputs of the single-year model for a single scenario is provided at the end of this section. The printout includes 12 pages, covering 16 years of input and output data. Where necessary, the printout also displays a column of additional input parameters (escalation rates, load factors, etc.). All model inputs are indicated with a box on the printout. All values not designated with a box are calculated by the model. However, some of these calculated values are used as inputs to other model calculations.

The printout is divided into three general sections: Utility and DSM Data (5 pages), Cost-Effectiveness Results (2 pages), and Cost Recovery Results (5 pages). For use in this report, we kept the information in the first two sections constant for all scenarios, testing only the impacts of different cost-recovery mechanisms.

The cost-recovery calculations rely on information from the first two sections as input.

The single-year model and this model description rely, for the most part, on the specific calculations that the Michigan utilities used to provide a generic characterization of a Michigan utility. For simplicity and precision, we incorporated these specific calculations in the single-year model. This allows users to operate the model with only a few input values. However, these inputs are somewhat rigidly defined. In practice, all of the information contained in the first section (Utility and DSM Data) acts as model input, while sections two and three provide model output. The user could use other relationships and calculations to develop the information in the first section, as long as it was internally consistent. For example, the model assumes uniform escalation rates for many variables, while the model could easily accommodate nonuniform streams. Similarly, the model calculates DSM energy impacts and demand impacts based on user-specified estimates of DSM costs, DSM unit costs (\$/kW), and DSM load factors. Users could develop this information using a variety of other approaches.

Utility and DSM Data

This section contains five parts, each displayed on an individual page. These are, in succession: Utility Capitalization Data, Utility Sales and Revenue Data, DSM Portfolio Cost Data, DSM Portfolio Load Impact Data, and Avoided Costs and Rates. In addition, at the top of the first printout page, the model contains some general information specifying the utility and case being modeled, as well as the date.

Utility Capitalization Data

This part contains seven values: six user inputs and one calculation. User inputs include capital structure and cost of capital for each of three types of utility financing (debt, preferred equity, and common equity), as well as the tax rate. The model calculates the utility's average rate of return as the weighted average of the cost of capital for the three financing types. The model assumes that capital structure and cost of capital remain constant for all years. In addition, the model uses the average rate of return as the discount rate for all present value and levelization calculations.

Utility Sales and Revenue Data

This part contains seven groups of values, each specified for 16 years. The model treats all values as occurring before the cost and load impacts of the DSM portfolio. The model uses the first group, escalation indices, to calculate future levels of utility sales and rate base. It develops the indices from user-specified inputs of annual escalation rates. The model calculates the second group, sales, from a base year sales input, the sales escalation index, and user-specified inputs regarding sales share to assign to each rate class. The model calculates the third group, peak demand, for each class using user-specified load factors and then sums to calculate total peak demand. The model calculates the fourth group, revenues, using class sales and peak demands as billing determinants, and applying energy and demand rates by class¹ (specified later in the model). The model calculates total revenues as the sum of class revenues. The model then uses the revenue results to calculate the next two groups, average rates and revenue shares. Revenues divided by sales provide average rates and class revenues divided by total revenues provide revenue shares. The model calculates the final group, rate base, by applying the rate base escalation index to the user-specified base-year value.

DSM Portfolio Cost Data

This part specifies costs required to implement a single year of DSM activity. Any costs specified for years 2 through 16 represent those necessary to maintain DSM measures installed in year 1. The model differentiates costs as incentives (paid from the utility to participants), utility administrative costs, and participant costs. The model follows the California Standard Practice² definitions for these items. Most notably, the Standard Practice defines participant costs as occurring before the effects of utility incentives.

¹ The model relies on the avoided-rate information, by class, used to calculate the revenue impacts of the DSM portfolio. Technically, avoided rates represent only marginal charges to customers, not all charges. For example, most utilities have minimum monthly charges or customer charges that cannot be avoided through DSM impacts. In addition, with blocked rate structures, avoided rates will do a poor job of characterizing total charges. Based on our understanding of Michigan's rate structures, the model produces reasonable estimates of revenues. More important, this approach captures the effects from the diverging escalation rates for fuel and nonfuel charges specified by the Michigan utilities.

² *Standard Practice Manual, Economic Analysis of Demand-Side Management Programs*, California Public Utilities Commission and California Energy Commission, December 1987.

The user specifies first- and second-year costs for each component for the total utility. The model applies the escalation index (produced from the user-specified annual escalation rate) to the second-year costs to calculate future year costs for the total utility. The model then calculates costs by component for each rate class based on user-specified shares of total utility costs.

DSM Portfolio Load Impacts

This part presents DSM load impacts by rate class and year. The model relies on user-specified DSM unit costs and DSM load factors for each rate class. DSM unit costs represent the participant cost in year 1 required to achieve a 1 kW reduction in system peak demand. Again, participant costs reflect the California Standard Practice definition (pre-incentive costs). The life of the installed DSM equipment is user-specified. The model makes no adjustments for DSM performance degradation or free-ridership.

Avoided Costs and Rates

This part contains the avoided cost and rate data that the model uses to calculate supply cost and revenue impacts for the DSM portfolio. The model relies on separate energy and demand values, with energy rates further differentiated into fuel charges and nonfuel charges. Fuel charges represent the total unit fuel cost. For utilities that specify fuel charges as adjustments to the fuel charge embodied in base rates³, the model's fuel charge represents the sum of actual base fuel charge and the fuel adjustment charge. Avoided rates represent customers' marginal rates, which may differ from customers' average rates. For example, at utilities with blocked rate structures, avoided rates should be priced at the block affected by the DSM program—typically the tail block.

The model calculates avoided costs from user-specified start values and escalation rates. The model calculates avoided rates from user-specified start values and rate escalation indices. It calculates rate escalation indices by adjusting a cost escalation index for the expected duration between rate increases awarded the utility. The cost escalation index represents increases in the average costs incurred by the utility for each rate component (demand, fuel, other energy), with average costs specified per appropriate unit (kW or kWh). The rate escalation

³ This is the treatment used by Michigan utilities.

index represents increases in the rates utilities are allowed to charge. The model also calculates avoided rates for the entire utility, using class rates and class billing determinants. These are presented for information only, and are not used elsewhere in the model.

Cost-Effectiveness Results

In this section, the model relies on input data developed in the previous section to calculate cost-effectiveness results for the total utility as well as for each rate class. The model presents results for four perspectives defined by the California Standard Practice—total resource cost (TRC), utility cost (UC), ratepayer impact measure (RIM), and participant. The model also follows Standard Practice calculation guidelines for each of the three tracked cost components (incentives, administrative costs, and participant costs). The Standard Practice also provides for additional minor costs that this model ignores (tax credits, externalities, secondary fuels, etc.). We will not further define these perspectives or calculations in this appendix. For a more detailed explanation, we refer users to the previously referenced *Standard Practice Manual*.

Year 1 values are not discounted in the model's present value calculations. The model first calculates cost-effectiveness results for each class, and sums across classes to develop total results.

Cost Recovery Results

This section begins with the final set of user-specified inputs, and then goes on to calculate cost recovery results for the total utility and for each rate class. Inputs characterize the mechanisms for program cost recovery and for shared benefit bonuses.

To characterize program cost recovery, users specify the percent of the utility's expenditures to expense, the percent to capitalize, and the depreciation life for capitalized items. If the percentages do not sum to 100%, the model presents an error message.

To characterize the shared-benefits bonus, the user specifies the appropriate cost-effectiveness perspective and the benefit share assigned to the utility. To denote the cost-effectiveness perspective, the user must use the terms TRC and UC, using

any combination of upper- and lower-case letters. The model produces an error message if other terms are used. If the user does not want to specify a bonus, the user should specify a 0% utility share, but maintain the term TRC or UC in the cell defining the perspective input.

For the total utility as well as for each rate class, the model presents four groups of cost recovery calculations: costs incurred, DSM rate base accounts, DSM cost recovery, and rate impacts. In addition, for the total utility, the model presents earnings impacts. Where appropriate, the model calculates the net present value (NPV) of individual line items over the sixteen-year time horizon. NPV calculations assume beginning-of-year cash flows (year 1 values are not discounted) and apply the utility's weighted average cost of capital as the discount rate. In addition, the model calculates levelized rate levels that, if in place for all years, would return the same NPV as the annual rate levels calculated by the model.

Costs incurred represent utility expenditures in a given year, whether or not these costs are reimbursed through rates in that year (or ever). The model takes DSM program costs directly from the DSM Portfolio Cost Data section. The model takes taxes from the cost recovery group of calculations (explained below).

DSM Rate Base Accounts track total plant-in-service and annual depreciation associated with capitalized DSM costs. The model capitalizes the user-specified percentage of DSM expenditures, adding costs to plant-in-service at the start of the year following their incursion (year 1 costs are added at the beginning of year 2). Year 1 additions depreciate (straight line) over the depreciation life (years 2 through 16). Future expenditures—incurred to maintain the original DSM installations—depreciate over the remaining depreciation life. For example, at a 15 year depreciation life, year 2 costs depreciate over the remaining 14 years (years 3 to 16), year 3 costs depreciate over the remaining 13 years, etc.

DSM Cost Recovery values represent the costs recovered by the utility in rates in each year. The model assumes no regulatory lag in cost recovery. That is, it calculates the annual dollar amounts required by the specified incentive mechanism and assumes that a balancing account or similar cost recovery mechanism ensures exact recovery of these dollar amounts. (Mechanisms addressed in periodically adjusted base rates produce actual recovery that varies with future sales levels as well as mechanism design.)

As for the individual cost recovery calculations, the model calculates expensed DSM costs as the user-specified percentage of annual DSM expenditures. It takes DSM depreciation directly from values calculated for DSM Rate Base Accounts. It calculates return on DSM rate base by applying the utility's weighted average rate of return to the plant-in-service. It calculates shared benefits by applying the user-specified utility share to the net-present-value DSM benefits from the appropriate cost-effectiveness perspective. It calculates taxes by grossing taxable earnings (preferred interest, equity earnings, and shared benefits) up by the user-specified tax rate.

The model next calculates rate impacts. It presents average rates without DSM, taken directly from Utility Sales and Revenue Data. It then calculates new average rates with DSM and recovery by dividing post-DSM revenues (pre-DSM revenues plus DSM cost recovery minus supply cost savings) and by post-DSM sales (pre-DSM sales minus DSM energy load impacts). This calculation assumes that rates reflect supply cost savings and DSM cost recovery amounts in the year they occur (or that some balancing account for reconciling cost deviations exists). The model next compares post-DSM rates to pre-DSM rates in both absolute (cents per kWh) and percentage terms.

Finally, for the total utility, the model characterizes earnings impacts. It first calculates nominal net cash flow as the difference between costs incurred and total recovery. The model then calculates the incremental rate of return the NPV of this cash flow stream represents to total rate base and common equity. Assuming that the utility earns its return in the absence of DSM activity, the model then calculates effective rates of return by adding these incremental rates to the utility's cost of capital for each component.

DEMAND SIDE MANAGEMENT INCENTIVE MODEL
SINGLE-YEAR MODEL

UTILITY:
DATE:

Michigan
04-Mar

CASE: Capitalization of DSM, 15-year amortization period, DSM bonus

UTILITY CAPITALIZATION DATA

NOTE: Boxes indicate model inputs

Capital Structure

Percent Debt	50.00%
Percent Preferred	10.00%
Percent Equity	40.00%

Cost of Capital

Cost of Debt	10.00%
Cost of Preferred	10.00%
Cost of Equity	14.00%

Average ROR

11.60%

Tax Rate

34.0%

UTILITY SALES AND REVENUE DATA

Escalation Indices

Sales	1.7%	esc.
Rate Base	0.0%	esc.

Pre-DSM Sales (GWh)

Total	38,000	38,646	39,303	39,971	40,651	41,342	42,045	42,759	43,486	44,225	44,977	45,742	46,519	47,310	48,115	48,933
Residential	13,300	13,526	13,756	13,990	14,228	14,470	14,716	14,966	15,220	15,479	15,742	16,010	16,282	16,559	16,840	17,126
Commercial	13,300	13,526	13,756	13,990	14,228	14,470	14,716	14,966	15,220	15,479	15,742	16,010	16,282	16,559	16,840	17,126
Industrial	11,400	11,594	11,791	11,991	12,195	12,403	12,613	12,828	13,046	13,268	13,493	13,723	13,956	14,193	14,434	14,680

Pre-DSM Peak Demand (MW)

Total	6,796	6,912	7,029	7,149	7,270	7,394	7,519	7,647	7,777	7,909	8,044	8,181	8,320	8,461	8,605	8,751
Residential	2,530	2,573	2,617	2,662	2,707	2,753	2,800	2,847	2,896	2,945	2,995	3,046	3,098	3,150	3,204	3,258
Commercial	2,530	2,573	2,617	2,662	2,707	2,753	2,800	2,847	2,896	2,945	2,995	3,046	3,098	3,150	3,204	3,258
Industrial	1,735	1,765	1,795	1,825	1,856	1,888	1,920	1,952	1,986	2,019	2,054	2,089	2,124	2,160	2,197	2,234

Pre-DSM Revenue Requirement

Total	\$3,525	\$3,653	\$3,788	\$4,271	\$4,431	\$4,601	\$5,183	\$5,383	\$5,597	\$6,298	\$6,550	\$6,819	\$7,667	\$7,983	\$8,322	\$9,347
Residential	\$1,397	\$1,444	\$1,494	\$1,687	\$1,747	\$1,809	\$2,012	\$2,116	\$2,194	\$2,474	\$2,567	\$2,665	\$3,002	\$3,118	\$3,242	\$3,649
Commercial	\$1,397	\$1,444	\$1,494	\$1,687	\$1,747	\$1,809	\$2,042	\$2,116	\$2,194	\$2,474	\$2,567	\$2,665	\$3,002	\$3,118	\$3,242	\$3,649
Industrial	\$732	\$765	\$800	\$896	\$938	\$982	\$1,099	\$1,152	\$1,208	\$1,351	\$1,417	\$1,488	\$1,662	\$1,746	\$1,837	\$2,050

Pre-DSM Average rate (\$/kWh)

Total	\$0.093	\$0.095	\$0.096	\$0.107	\$0.109	\$0.111	\$0.123	\$0.126	\$0.129	\$0.142	\$0.146	\$0.149	\$0.165	\$0.169	\$0.173	\$0.191
Residential	\$0.105	\$0.107	\$0.109	\$0.121	\$0.123	\$0.125	\$0.139	\$0.141	\$0.144	\$0.160	\$0.163	\$0.166	\$0.184	\$0.188	\$0.193	\$0.213
Commercial	\$0.105	\$0.107	\$0.109	\$0.121	\$0.123	\$0.125	\$0.139	\$0.141	\$0.144	\$0.160	\$0.163	\$0.166	\$0.184	\$0.188	\$0.193	\$0.213
Industrial	\$0.064	\$0.066	\$0.068	\$0.075	\$0.077	\$0.079	\$0.087	\$0.090	\$0.093	\$0.102	\$0.105	\$0.108	\$0.119	\$0.123	\$0.127	\$0.140

Pre-DSM Revenue Requirement Share

Total	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Residential	40%	40%	39%	40%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%
Commercial	40%	40%	39%	40%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%	39%
Industrial	21%	21%	21%	21%	21%	21%	21%	21%	22%	21%	22%	22%	22%	22%	22%	22%

Pre-DSM Rate Base

\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

DSM PORTFOLIO COST DATA

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
DSM Costs	1.0000	1.0500	1.1025	1.1576	1.2155	1.2763	1.3401	1.4071	1.4775	1.5513	1.6289	1.7103	1.7959	1.8856	1.9799	0.0000
	esc.															

COST ESCALATION INDEX

5.0%

TOTAL UTILITY

Utility Program Costs																
Incentives	\$70.0	\$7.4	\$7.7	\$8.1	\$8.5	\$8.9	\$9.4	\$9.8	\$10.3	\$10.9	\$11.4	\$12.0	\$12.6	\$13.2	\$13.9	\$0.0
Administration	\$5.0	\$0.5	\$0.6	\$0.6	\$0.6	\$0.6	\$0.7	\$0.7	\$0.7	\$0.8	\$0.8	\$0.9	\$0.9	\$0.9	\$1.0	\$0.0
Total	\$75.0	\$7.9	\$8.3	\$8.7	\$9.1	\$9.6	\$10.1	\$10.6	\$11.1	\$11.6	\$12.2	\$12.8	\$13.5	\$14.1	\$14.8	\$0.0
Participant Costs	\$140.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0

RESIDENTIAL

Utility Program Costs																
Incentives	35% share	\$24.5	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.9
Administration	35% share	\$1.8	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.0
Total		\$26.3	\$2.8	\$2.9	\$3.0	\$3.2	\$3.4	\$3.5	\$3.7	\$3.9	\$4.1	\$4.3	\$4.5	\$4.7	\$4.9	\$5.2
Participant Costs	35% share	\$49.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0

COMMERCIAL

Utility Program Costs																
Incentives	35% share	\$24.5	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.9
Administration	35% share	\$1.8	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.0
Total		\$26.3	\$2.8	\$2.9	\$3.0	\$3.2	\$3.4	\$3.5	\$3.7	\$3.9	\$4.1	\$4.3	\$4.5	\$4.7	\$4.9	\$5.2
Participant Costs	35% share	\$49.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0

INDUSTRIAL

Utility Program Costs																
Incentives	30% share	\$21.0	\$2.2	\$2.3	\$2.4	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2
Administration	30% share	\$1.5	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.0
Total		\$22.5	\$2.4	\$2.5	\$2.6	\$2.7	\$2.9	\$3.0	\$3.2	\$3.3	\$3.5	\$3.7	\$3.8	\$4.0	\$4.2	\$4.5
Participant Costs	30% share	\$42.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0

DSM PORTFOLIO LOAD IMPACT DATA

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
TOTAL UTILITY																
Demand (MW)	95	95	95	95	95	95	95	95	95	95	95	95	95	95	95	0
Energy (GWh)	554	554	554	554	554	554	554	554	554	554	554	554	554	554	554	0
RESIDENTIAL																
Demand (MW)	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	0
Energy (GWh)	117	117	117	117	117	117	117	117	117	117	117	117	117	117	117	0
COMMERCIAL																
Demand (MW)	31	31	31	31	31	31	31	31	31	31	31	31	31	31	31	0
Energy (GWh)	161	161	161	161	161	161	161	161	161	161	161	161	161	161	161	0
INDUSTRIAL																
Demand (MW)	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	0
Energy (GWh)	276	276	276	276	276	276	276	276	276	276	276	276	276	276	276	0

\$2,200 /kW
60% LF

\$1,600 /kW
60% LF

\$1,000 /kW
75% LF

COST EFFECTIVENESS RESULTS

TOTAL PORTFOLIO

Cost-Effectiveness Components

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NY
Supply Costs	(\$26.1)	(\$27.8)	(\$29.6)	(\$31.6)	(\$33.8)	(\$36.3)	(\$38.9)	(\$41.9)	(\$45.1)	(\$48.7)	(\$52.6)	(\$56.9)	(\$61.6)	(\$66.9)	(\$72.6)	\$0.0	(\$299)
Revenue Impacts	(\$46.9)	(\$47.9)	(\$48.9)	(\$54.2)	(\$55.3)	(\$56.6)	(\$62.6)	(\$64.1)	(\$65.6)	(\$72.5)	(\$74.3)	(\$76.2)	(\$84.1)	(\$86.3)	(\$88.7)	\$0.0	(\$463)
Utility Costs	\$5.0	\$0.5	\$0.6	\$0.6	\$0.6	\$0.6	\$0.7	\$0.7	\$0.7	\$0.8	\$0.8	\$0.9	\$0.9	\$0.9	\$1.0	\$0.0	\$10
Incentives	\$70.0	\$7.4	\$7.7	\$8.1	\$8.5	\$8.9	\$9.4	\$9.8	\$10.3	\$10.9	\$11.4	\$12.0	\$12.6	\$13.2	\$13.9	\$0.0	\$134
Participant Costs	\$140.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$140

Test Results

	Benefits	Costs	Net	B/C
Total Resource	\$299	\$150	\$150	2.00
Utility	\$299	\$143	\$156	2.09
RIM	\$299	\$606	(\$307)	0.49
Participant	\$597	\$140	\$457	4.26

RESIDENTIAL PORTFOLIO

Cost-Effectiveness Components

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NY
Supply Costs	(\$35.7)	(\$6.1)	(\$6.5)	(\$6.9)	(\$7.4)	(\$7.9)	(\$8.4)	(\$9.1)	(\$9.8)	(\$10.5)	(\$11.3)	(\$12.2)	(\$13.2)	(\$14.4)	(\$15.6)	\$0.0	(\$65)
Revenue Impacts	(\$12.3)	(\$12.5)	(\$12.7)	(\$14.1)	(\$14.4)	(\$14.6)	(\$16.2)	(\$16.5)	(\$16.9)	(\$18.7)	(\$19.1)	(\$19.5)	(\$21.6)	(\$22.0)	(\$22.5)	\$0.0	(\$120)
Utility Costs	\$1.8	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.0	\$3
Incentives	\$24.5	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.9	\$0.0	\$47
Participant Costs	\$49.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$49

Test Results

	Benefits	Costs	Net	B/C
Total Resource	\$65	\$52	\$13	1.24
Utility	\$65	\$50	\$15	1.29
RIM	\$65	\$170	(\$105)	0.38
Participant	\$167	\$49	\$118	3.40

COST EFFECTIVENESS RESULTS

COMMERCIAL PORTFOLIO

Cost-Effectiveness Components

Supply Costs	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
Revenue Impacts	(\$7.9)	(\$8.4)	(\$8.9)	(\$9.5)	(\$10.1)	(\$10.8)	(\$11.6)	(\$12.5)	(\$13.4)	(\$14.4)	(\$15.6)	(\$16.8)	(\$18.2)	(\$19.7)	(\$21.4)	\$0.0	(\$89)
Utility Costs	(\$16.9)	(\$17.2)	(\$17.5)	(\$19.4)	(\$19.8)	(\$20.1)	(\$22.3)	(\$22.8)	(\$23.2)	(\$25.7)	(\$26.2)	(\$26.8)	(\$29.7)	(\$30.3)	(\$31.0)	\$0.0	(\$165)
Incentives	\$1.8	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.3	\$0.0	\$3
Participant Costs	\$24.5	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.9	\$0.0	\$47
	\$49.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$49

Test Results

	Benefits	Costs	Net	B/C
Total Resource	\$89	\$52	\$37	1.71
Utility	\$89	\$50	\$39	1.78
RIM	\$89	\$215	(\$126)	0.42
Participant	\$212	\$49	\$163	4.32

INDUSTRIAL PORTFOLIO

Cost-Effectiveness Components

Supply Costs	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
Revenue Impacts	(\$12.5)	(\$13.3)	(\$14.2)	(\$15.2)	(\$16.3)	(\$17.5)	(\$18.9)	(\$20.3)	(\$21.9)	(\$23.7)	(\$25.7)	(\$27.8)	(\$30.2)	(\$32.8)	(\$35.6)	\$0.0	(\$145)
Utility Costs	(\$17.7)	(\$18.2)	(\$18.7)	(\$20.6)	(\$21.2)	(\$21.9)	(\$24.0)	(\$24.8)	(\$25.5)	(\$28.1)	(\$29.0)	(\$29.9)	(\$32.9)	(\$34.0)	(\$35.1)	\$0.0	(\$178)
Incentives	\$1.5	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.2	\$0.3	\$0.3	\$0.3	\$0.3	\$0.0	\$3
Participant Costs	\$21.0	\$2.2	\$2.3	\$2.4	\$2.6	\$2.7	\$2.8	\$3.0	\$3.1	\$3.3	\$3.4	\$3.6	\$3.8	\$4.0	\$4.2	\$0.0	\$40
	\$42.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$42

Test Results

	Benefits	Costs	Net	B/C
Total Resource	\$145	\$45	\$100	3.23
Utility	\$145	\$43	\$102	3.37
RIM	\$145	\$221	(\$76)	0.66
Participant	\$219	\$42	\$177	5.20

DSM COST RECOVERY AND BONUS TREATMENT

COST RECOVERY

% Expensed	0%
% Capitalized	100%
Depreciation Life	15 yrs

SHARED BENEFITS BONUS

Perspective	UC
% Share to Utility	0%

DSM COST RECOVERY, TOTAL

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV	Level
Costs Incurred																		
DSM Program Costs	\$75.0	\$7.9	\$8.3	\$8.7	\$9.1	\$9.6	\$10.1	\$10.6	\$11.1	\$11.6	\$12.2	\$12.8	\$13.5	\$14.1	\$14.8	\$0.0	\$143.5	
Income Taxes	\$0.0	\$2.6	\$2.6	\$2.7	\$2.8	\$2.9	\$3.0	\$3.0	\$3.0	\$3.0	\$3.0	\$2.9	\$2.8	\$2.5	\$2.2	\$1.6	\$19.2	
Total Costs Incurred	\$75.0	\$10.4	\$10.9	\$11.4	\$11.9	\$12.5	\$13.0	\$13.6	\$14.1	\$14.7	\$15.2	\$15.7	\$16.2	\$16.7	\$17.0	\$1.6	\$162.7	

DSM Rate Base Accounts

Plant in Service	\$0.0	\$75.0	\$77.9	\$80.6	\$83.1	\$85.3	\$87.1	\$88.4	\$89.2	\$89.1	\$88.0	\$85.5	\$81.3	\$74.4	\$63.8	\$46.7		
Depreciation	\$0.0	\$5.0	\$5.6	\$6.2	\$6.9	\$7.8	\$8.7	\$9.8	\$11.1	\$12.7	\$14.7	\$17.1	\$20.3	\$24.8	\$31.9	\$46.7	\$78.1	

15 yr

DSM Cost Recovery

Expensed DSM Costs	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
DSM Depreciation	\$0.0	\$5.0	\$5.6	\$6.2	\$6.9	\$7.8	\$8.7	\$9.8	\$11.1	\$12.7	\$14.7	\$17.1	\$20.3	\$24.8	\$31.9	\$46.7	\$78.1	
Return on Ratebase	\$0.0	\$8.7	\$9.0	\$9.3	\$9.6	\$9.9	\$10.1	\$10.3	\$10.3	\$10.3	\$10.2	\$9.9	\$9.4	\$8.6	\$7.4	\$5.4	\$65.4	
Shared Benefits	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Taxes	\$0.0	\$2.6	\$2.6	\$2.7	\$2.8	\$2.9	\$3.0	\$3.0	\$3.0	\$3.0	\$3.0	\$2.9	\$2.8	\$2.5	\$2.2	\$1.6	\$19.2	
Total Recovery	\$0.0	\$16.3	\$17.2	\$18.3	\$19.4	\$20.5	\$21.8	\$23.1	\$24.5	\$26.1	\$27.9	\$29.9	\$32.5	\$36.0	\$41.4	\$53.7	\$162.7	

11.6%

0.0%

34.0%

Rate Impacts (cents per kWh)

Average Rate	9.277	9.452	9.639	10.685	10.900	11.129	12.327	12.589	12.870	14.242	14.563	14.908	16.480	16.874	17.296	19.102	11.897	
Without DSM	9.344	9.559	9.745	10.802	11.014	11.242	12.450	12.710	12.988	14.370	14.689	15.031	16.615	17.008	17.432	19.212	12.009	
With DSM and Recovery																		
Rate Increase	0.068	0.107	0.106	0.116	0.115	0.113	0.123	0.121	0.118	0.129	0.126	0.123	0.135	0.134	0.136	0.110	0.111	
Absolute Increase	0.7%	1.1%	1.1%	1.1%	1.1%	1.0%	1.0%	1.0%	0.9%	0.9%	0.9%	0.8%	0.8%	0.8%	0.8%	0.6%	0.9%	
% Increase																		

Earnings Impact of Cost Recovery Mechanism

Net Cash Flow	(\$75.0)	\$5.8	\$6.3	\$6.9	\$7.4	\$8.1	\$8.8	\$9.5	\$10.4	\$11.4	\$12.7	\$14.2	\$16.3	\$19.3	\$24.4	\$52.1	\$0.0	
Effective ROR on Rate Base	11.600%																	
Effective ROR on Equity	14.000%																	

DSM COST RECOVERY, RESIDENTIAL

Level

Costs Incurred

DSM Program Costs

Income Taxes

Total Costs Incurred

DSM Rate Base Accounts

Plant in Service

Depreciation

15 yr

DSM Cost Recovery

Expensed DSM Costs

DSM Depreciation

Return on Ratebase

Shared Benefits

Taxes

Total Recovery

Rate Impacts (cents per kWh)

Average Rate

Without DSM

With DSM and Recovery

Rate Increase

Absolute Increase

% Increase

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV	Level
Costs Incurred																		
DSM Program Costs	\$26.3	\$2.8	\$2.9	\$3.0	\$3.2	\$3.4	\$3.5	\$3.7	\$3.9	\$4.1	\$4.3	\$4.5	\$4.7	\$4.9	\$5.2	\$0.0	\$50.2	
Income Taxes	\$0.0	\$0.9	\$0.9	\$1.0	\$1.0	\$1.0	\$1.0	\$1.1	\$1.1	\$1.1	\$1.0	\$1.0	\$1.0	\$0.9	\$0.8	\$0.6	\$6.7	
Total Costs Incurred	\$26.3	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.7	\$4.9	\$5.1	\$5.3	\$5.5	\$5.7	\$5.8	\$6.0	\$0.6	\$56.9	
DSM Rate Base Accounts																		
Plant in Service	\$0.0	\$26.3	\$27.3	\$28.2	\$29.1	\$29.8	\$30.5	\$30.9	\$31.2	\$31.2	\$30.8	\$29.9	\$28.4	\$26.0	\$22.3	\$16.4		
Depreciation	\$0.0	\$1.8	\$1.9	\$2.2	\$2.4	\$2.7	\$3.0	\$3.4	\$3.9	\$4.5	\$5.1	\$6.0	\$7.1	\$8.7	\$11.2	\$16.4	\$27.3	
DSM Cost Recovery																		
Expensed DSM Costs	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
DSM Depreciation	\$0.0	\$1.8	\$1.9	\$2.2	\$2.4	\$2.7	\$3.0	\$3.4	\$3.9	\$4.5	\$5.1	\$6.0	\$7.1	\$8.7	\$11.2	\$16.4	\$27.3	
Return on Ratebase	\$0.0	\$3.0	\$3.2	\$3.3	\$3.4	\$3.5	\$3.5	\$3.6	\$3.6	\$3.6	\$3.6	\$3.5	\$3.3	\$3.0	\$2.6	\$1.9	\$22.9	
Shared Benefits	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Taxes	\$0.0	\$0.9	\$0.9	\$1.0	\$1.0	\$1.0	\$1.0	\$1.1	\$1.1	\$1.1	\$1.0	\$1.0	\$1.0	\$0.9	\$0.8	\$0.6	\$6.7	
Total Recovery	\$0.0	\$5.7	\$6.0	\$6.4	\$6.8	\$7.2	\$7.6	\$8.1	\$8.6	\$9.1	\$9.8	\$10.5	\$11.4	\$12.6	\$14.5	\$18.8	\$56.9	
Rate Impacts (cents per kWh)																		
Average Rate	10.500	10.675	10.862	12.062	12.276	12.505	13.874	14.137	14.418	15.983	16.304	16.649	18.439	18.833	19.255	21.305	13.371	
Without DSM	10.550	10.765	10.952	12.160	12.374	12.602	13.980	14.242	14.522	16.095	16.416	16.760	18.561	18.956	19.383	21.415	13.467	
With DSM and Recovery																		
Rate Increase	0.050	0.090	0.090	0.098	0.098	0.097	0.106	0.105	0.104	0.113	0.112	0.112	0.122	0.123	0.128	0.110	0.096	
Absolute Increase	0.5%	0.8%	0.8%	0.8%	0.8%	0.8%	0.8%	0.7%	0.7%	0.7%	0.7%	0.7%	0.7%	0.7%	0.7%	0.5%	0.7%	
% Increase																		

A-17

DSM COST RECOVERY, COMMERCIAL

Level

Costs Incurred

DSM Program Costs

Income Taxes

Total Costs Incurred

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
\$26.3	\$2.8	\$2.9	\$3.0	\$3.2	\$3.4	\$3.5	\$3.7	\$3.9	\$4.1	\$4.3	\$4.5	\$4.7	\$4.9	\$5.2	\$0.0	\$50.2
\$0.0	\$0.9	\$0.9	\$1.0	\$1.0	\$1.0	\$1.0	\$1.1	\$1.1	\$1.1	\$1.0	\$1.0	\$1.0	\$0.9	\$0.8	\$0.6	\$6.7
\$26.3	\$3.6	\$3.8	\$4.0	\$4.2	\$4.4	\$4.6	\$4.7	\$4.9	\$5.1	\$5.3	\$5.5	\$5.7	\$5.8	\$6.0	\$0.6	\$56.9

DSM Rate Base Accounts

Plant in Service

Depreciation

15 yr

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
\$0.0	\$26.3	\$27.3	\$28.2	\$29.1	\$29.8	\$30.5	\$30.9	\$31.2	\$31.2	\$30.8	\$29.9	\$28.4	\$26.0	\$22.3	\$16.4	
\$0.0	\$1.8	\$1.9	\$2.2	\$2.4	\$2.7	\$3.0	\$3.4	\$3.9	\$4.5	\$5.1	\$6.0	\$7.1	\$8.7	\$11.2	\$16.4	\$27.3

DSM Cost Recovery

Expensed DSM Costs

DSM Depreciation

11.6%

Return on Ratebase

0.0%

Shared Benefits

34.0%

Taxes

Total Recovery

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
\$0.0	\$1.8	\$1.9	\$2.2	\$2.4	\$2.7	\$3.0	\$3.4	\$3.9	\$4.5	\$5.1	\$6.0	\$7.1	\$8.7	\$11.2	\$16.4	\$27.3
\$0.0	\$3.0	\$3.2	\$3.3	\$3.4	\$3.5	\$3.5	\$3.6	\$3.6	\$3.6	\$3.6	\$3.5	\$3.3	\$3.0	\$2.6	\$1.9	\$22.9
\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
\$0.0	\$0.9	\$0.9	\$1.0	\$1.0	\$1.0	\$1.0	\$1.1	\$1.1	\$1.1	\$1.0	\$1.0	\$1.0	\$0.9	\$0.8	\$0.6	\$6.7
\$0.0	\$5.7	\$6.0	\$6.4	\$6.8	\$7.2	\$7.6	\$8.1	\$8.6	\$9.1	\$9.8	\$10.5	\$11.4	\$12.6	\$14.5	\$18.8	\$56.9

Rate Impacts (cents per kWh)

Average Rate

Without DSM

With DSM and Recovery

Rate Increase

Absolute Increase

% Increase

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	NPV
10.500	10.675	10.862	12.062	12.276	12.505	13.874	14.137	14.418	15.983	16.304	16.649	18.439	18.833	19.255	21.305	13.371
10.569	10.783	10.970	12.180	12.393	12.620	14.000	14.261	14.540	16.116	16.435	16.778	18.580	18.974	19.399	21.415	13.485
0.069	0.108	0.107	0.118	0.117	0.115	0.126	0.124	0.122	0.133	0.131	0.129	0.142	0.141	0.144	0.110	0.114
0.7%	1.0%	1.0%	1.0%	1.0%	0.9%	0.9%	0.9%	0.8%	0.8%	0.8%	0.8%	0.8%	0.8%	0.8%	0.5%	0.9%

A - 18

DSM COST RECOVERY, INDUSTRIAL

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 NPV Level

Costs Incurred

DSM Program Costs

Income Taxes

Total Costs Incurred

\$22.5	\$2.4	\$2.5	\$2.6	\$2.7	\$2.9	\$3.0	\$3.2	\$3.3	\$3.5	\$3.7	\$3.8	\$4.0	\$4.2	\$4.5	\$0.0	\$43.0
\$0.0	\$0.8	\$0.8	\$0.8	\$0.8	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.8	\$0.8	\$0.7	\$0.5	\$5.8
\$22.5	\$3.1	\$3.3	\$3.4	\$3.6	\$3.7	\$3.9	\$4.1	\$4.2	\$4.4	\$4.6	\$4.7	\$4.9	\$5.0	\$5.1	\$0.5	\$48.8

DSM Rate Base Accounts

Plant in Service

Depreciation

\$0.0	\$22.5	\$23.4	\$24.2	\$24.9	\$25.6	\$26.1	\$26.5	\$26.7	\$26.7	\$26.4	\$25.7	\$24.4	\$22.3	\$19.1	\$14.0	
\$0.0	\$1.5	\$1.7	\$1.9	\$2.1	\$2.3	\$2.6	\$2.9	\$3.3	\$3.8	\$4.4	\$5.1	\$6.1	\$7.4	\$9.6	\$14.0	\$23.4

DSM Cost Recovery

Expensed DSM Costs

DSM Depreciation

Return on Ratebase 11.6%

Shared Benefits 0.0%

Taxes 34.0%

Total Recovery

\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
\$0.0	\$1.5	\$1.7	\$1.9	\$2.1	\$2.3	\$2.6	\$2.9	\$3.3	\$3.8	\$4.4	\$5.1	\$6.1	\$7.4	\$9.6	\$14.0	\$23.4
\$0.0	\$2.6	\$2.7	\$2.8	\$2.9	\$3.0	\$3.0	\$3.1	\$3.1	\$3.1	\$3.1	\$3.0	\$2.8	\$2.6	\$2.2	\$1.6	\$19.6
\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
\$0.0	\$0.8	\$0.8	\$0.8	\$0.8	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.9	\$0.8	\$0.8	\$0.7	\$0.5	\$5.8
\$0.0	\$4.9	\$5.2	\$5.5	\$5.8	\$6.2	\$6.5	\$6.9	\$7.4	\$7.8	\$8.4	\$9.0	\$9.8	\$10.8	\$12.4	\$16.1	\$48.8

Rate Impacts (cents per kWh)

Average Rate

Without DSM

With DSM and Recovery

Rate Increase

Absolute Increase

% Increase

6.422	6.597	6.785	7.475	7.689	7.919	8.715	8.978	9.259	10.179	10.501	10.845	11.910	12.304	12.726	13.962	8.459
6.470	6.684	6.869	7.568	7.779	8.005	8.810	9.068	9.344	10.273	10.589	10.927	12.001	12.390	12.810	14.071	8.543
0.047	0.086	0.084	0.093	0.090	0.086	0.095	0.091	0.086	0.094	0.088	0.082	0.091	0.086	0.084	0.110	0.084
0.7%	1.3%	1.2%	1.2%	1.2%	1.1%	1.1%	1.0%	0.9%	0.9%	0.8%	0.8%	0.8%	0.7%	0.7%	0.8%	1.0%

MULTIYEAR MODEL

A printout of the all inputs and outputs from the multiyear model for one scenario is provided at the end of this section. The four-page printout covers 16 years of input and output data (years 0 through 15) as well as a column of parameter data, where appropriate. The printout indicates all user inputs with boxes and gray shading. It uses unshaded boxes to indicate a few additional model parameters that users cannot change but that do affect important calculations.

Each of the four pages represents a distinct section of model operation, including Scenario Inputs, DSM Portfolio Specifications, Pro-forma Financial Statements, and Actual Financial Statements.

As was true for the single-year model, this model embodies certain calculations used to characterize a generic Michigan utility. Users could develop some of this information by alternative means without interfering with fundamental model operation. In the multiyear model, users could specify DSM Portfolio Program Costs and Load Impacts using any internally consistent approach.

Scenario Inputs

In the first model section, users provide inputs specifying the regulatory treatment accorded to various components of the utility's revenue requirement. Users input the values 1 or 0 to specify whether or not the regulatory treatment occurs, with 1 indicating occurrence and 0 indicating no occurrence.

Regulatory specifications include whether or not DSM occurs, as well as the treatment accorded program costs, lost revenue, and bonus. If DSM occurs, the model factors in the DSM costs and sales impacts from the DSM Portfolio Specification. If no DSM occurs, the model only considers non-DSM costs and pre-DSM sales levels. The model currently only allows expense treatment for DSM program costs. Users can specify lost revenue recovery treatment by setting both the ERAM and Attrition Adjustments switches to 1. Otherwise the model assumes no lost revenue treatment. Users can specify shared benefits bonus treatment using the perspective and utility share inputs. Users must specify the perspective using the terms TRC and UC, using any combination of upper- and lower-case letters. The model will produce error messages if other terms are used. An entry of 0% as the utility share indicates the absence of a DSM bonus.

The model allows either future or historic test year treatment in setting rates for five rate components: fuel charge, base charge, DSM expense and bonus charge, ERAM charge, and attrition charge. Users can specify future or historic test year treatment for fuel, base, and DSM charges, but the model always assumes future test years for ERAM and attrition charges.

The model allows for various schedules for updating each rate component. An entry of 1 directs the model to recalculate the given rate component to take effect at the beginning of the year specified. The user can specify schedules for fuel, base, and DSM charges, but the model always assumes annual adjustments for ERAM and attrition charges.

The model also allows actual sales and utility expenditures to deviate from the estimates assumed in future test year calculations. Users can specify deviations for base sales (sales occurring before the DSM impacts) and for non-DSM operating expenses (operating expenses excluding fuel, depreciation, taxes, and DSM expenses).

Finally, users specify utility capital specifications, including capital structure and cost of capital for each of three utility financing types (debt, preferred equity, and common equity), as well as the utility's income tax rate. The model calculates the utility's total rate of return as the weighted average of its cost of capital for each financing type.

DSM Portfolio Specifications

In this section, users specify the costs and load impacts of DSM programs operating over a multiyear period, as well as the utility's avoided costs. The model then calculates the associated supply cost benefits, net program benefits, and, if applicable, shared benefits bonus.

Users specify two DSM escalation rates: one for costs and one for effort. Program and participant costs increase over time with both cost and effort, while DSM impacts increase over time with effort only. Users specify base year program costs for incentives (paid from the utility to participants), administrative costs, and participant costs. As described for the single-year model, costs should adhere to the California Standard Practice definitions. Most notably, participant costs should represent costs before the impact of utility incentives. The model escalates base year costs at the product of the cost and effort escalation indices.

The model calculates first year demand impacts by applying a user-specified unit cost. Unit costs represent the participant costs necessary to achieve a 1 kW reduction in system peak demand. The model then calculates future additions to demand impacts by applying the effort escalation index. It then determines retirements from demand impacts by applying the user-specified equipment life. It then accumulates demand impacts for each year. The model calculates energy impacts by applying a user-specified load factor to demand impacts.

The model calculates avoided costs by applying user-specified escalation rates to user-specified start values. The model uses these avoided costs to calculate supply cost benefits associated with DSM investments. It calculates savings from cumulative load impacts as well as savings associated with programs implemented in each year. The model then calculates the net-present-value benefits associated with programs implemented in each year from each of two cost-effectiveness perspectives: total resource costs (TRC) and utility costs (UC). The model uses California Standard Practice definitions of perspectives and calculations. The model then applies the utility share to determine the utility's annual shared benefit bonus.

Pro-forma Financial Statements

The model next develops a set of pro-forma financial statements to determine rates in effect for each year. The model only displays lines used to calculate rates changed in each year. For example, if a utility updates base charges every three years, the model only displays line items necessary to calculate base charges every three years.

In the absence of any DSM programs or DSM incentive mechanisms (including ERAM and attrition treatment), the model uses the following general approach to develop pro-forma statements. It first determines rate base accounts, including plant additions, depreciation, and plant-in-service. It then determines operating expenses, taking depreciation directly from the rate base accounts. It next determines target earnings by applying the user-specified capital structure and costs of capital to plant-in-service. It then determines the amount of taxes to add to revenue requirements to maintain these target earnings levels. Finally, it calculates average prices by dividing the revenue requirement for each rate component (fuel and base) by the appropriate sales basis.

- The model's source for cost line items varies depending on whether the user specifies historic or future test year treatment. With historic treatment, the model relies directly on actual costs from the previous year, as displayed in the Actual Financial Statements. With future treatment, the model increases the previous year's value by the future test year (FTY) factor displayed in the column to the left of year 0. If the term "Actual" appears in the FTY Factor column, the model assumes that the utility can accurately predict the indicated line item, and it takes the appropriate value from the current year of the Actual Financial Statements.

The model uses a similar approach in developing the sales basis in the Pro-forma Financial Statements. However, it first develops base sales estimates (sales prior to DSM), and then nets out DSM sales impacts. With historic treatment, the model takes the previous year's sales and cumulative DSM impacts. With future treatment the model takes the previous year's base sales, which it increases by the FTY factor, and then nets out the current year's cumulative DSM impacts. The model assumes that the utility can accurately predict the current year's cumulative DSM impacts.

If the user allows for attrition adjustments, the model takes a slightly different approach to calculating the cost items that serve as inputs to the attrition charge (these items are the same as those included in the base charge, and include all costs excluding fuel, DSM expenses, DSM bonus, and ERAM balance). In years that the base charge gets updated, the model sets the attrition charge to zero, and calculates the new base charge as described above. However, in intervening years, the model calculates the attrition line items by applying the FTY factors to the previous year's pro-forma values rather than the previous year's values from the Actual Financial Statements.

In the Pro-forma Financial Statements, the model calculates a gross attrition charge, defined as the charge necessary to recover the cost items covered by the base charge. In practice, most utilities maintain a constant base charge and apply a net attrition charge, defined as the difference between the gross attrition charge and the base charge. The model applies a net attrition charge in its calculation of Actual Financial Statements.

Finally, if the user allows for ERAM treatment, the model calculates an ERAM charge by dividing the previous year's ERAM balance from the Actual Financial Statements by the ERAM sales basis, calculated in the same manner as the other sales bases.

Actual Financial Statements

On the final page, the model calculates Actual Financial Statements using the following approach. It first calculates actual revenues as the product of actual sales and average prices. It then subtracts actual operating expenses and annual ERAM amount (if any) to determine pre-tax earnings. Finally, it subtracts debt interest, taxes on preferred and equity earnings, and preferred interest to arrive at common equity earnings.

The model calculates total sales by first projecting base sales from a user-specified start value and annual escalation rate. It then subtracts actual DSM impacts (taken from the DSM Portfolio Specifications) to arrive at net actual sales.

The model determines actual prices based on the user-specified schedule of rate changes. As described previously, the model relies on a net attrition charge, rather than the gross attrition charge developed in the Pro-forma Financial Statements. It calculates the net charge as the difference between the gross attrition charge and the base charge. The model then calculates actual revenues as the product of sales and prices.

The model next determines actual rate base accounts. It calculates total plant-in-service, by applying the user-specified escalation rate to the user-specified start value. It calculates annual depreciation by dividing plant-in-service by the user-specified average depreciation life. Finally, it calculates annual plant additions necessary to maintain the total plant-in-service.

The model next calculates actual operating expenses. It calculates fuel expenses by subtracting the DSM-related fuel savings from base fuel expenses. It calculates base fuel expenses from user-specified start value and annual escalation. It takes DSM savings directly from the DSM Portfolio Specifications, assuming that all supply savings (including capacity savings) flow through to the fuel charge, and not to other accounts. The model takes depreciation expenses directly from the rate base accounts. It calculates non-DSM operating expenses from user-specified inputs for start value and annual escalation. Finally, the model takes DSM expenses directly from the DSM Portfolio Specification.

If the user allows ERAM treatment, the model next calculates ERAM balances, defined as the difference between authorized revenue requirement and actual revenues. Negative values imply overcollection and result in negative ERAM charges.

Finally, the model calculates earnings. It calculates pretax earnings by subtracting from total revenue the sum of operating expenses and the annual change in the ERAM balance. The model then subtracts debt interest payments, and applies the utility's tax rate to the resulting taxable income. It then subtracts preferred interest payments to arrive at earnings for common.

The model also displays the utility's earned rates of return. It calculates rate of return on rate base by dividing total earnings (debt and preferred interest plus common earnings) by total rate base. It calculates rate of return on common by dividing common earnings by the portion of rate base supported by common equity.

P1326/APPENDIX/6-7-91

DSM REGULATORY INCENTIVES MULTIYEAR MODEL

UTILITY: Michigan
DATE: 05-Mar

REGULATORY SPECIFICATIONS

DSM Occurs?	1
Program Cost Treatment Expensed (Assumed)	1
Lost Revenue Treatment	1
ERAM	1
Attrition Adjustments	1
NPV Shared Savings Treatment	
Perspective	TRC
After Tax Utility Share	0%

HISTORIC TEST YEAR?

Costs	Salts
Fuel	0
Base	0
DSM Expenses/Bonus	0
Attrition/ERAM (FTY Assumed)	0

RATE CASE IN EFFECT THIS YEAR?

Year	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Fuel		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Base		1	0	0	1	0	0	1	0	0	1	0	0	1	0	0
DSM Expenses & Bonus		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Attrition/ERAM (Annual Cases Assumed)		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

DEVIATION FROM FUTURE YEAR PRO-FORMA VALUES

Base (Pre-DSM) Sales	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
Non-DSM Operating Expenses	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%

UTILITY CAPITAL SPECIFICATIONS

Capital Structure	
Debt	50%
Preferred	10%
Common	40%
Target Rate of Return	
Debt	10.0%
Preferred	10.0%
Common	14.0%
Total	11.6%
Tax Rate	34.0%

DSM PORTFOLIO SPECIFICATIONS

(Costs in Millions)

DSM ESCALATION INDICES

Costs	5.0%	esc.
Effort	5.0%	esc.

PROGRAM COSTS

Utility Incentives	\$70
Utility Admin	\$5
Participant Costs	\$140

LOAD IMPACTS	15 yr life
Demand Impacts (MW)	\$1,475 /kW (real)

Additions	95	100	105	110	115	121	0	0	0	0	0	0	0	0	0	0	0
Retirements	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	95
Cumulative	95	195	299	409	524	645	645	645	645	645	645	645	645	645	645	645	551
Energy Impacts (GWh)																	
Additions	554	582	611	641	673	707	0	0	0	0	0	0	0	0	0	0	0
Retirements	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	554
Cumulative	554	1,136	1,746	2,388	3,061	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,214

AVOIDED COSTS	
Demand (\$/kW-yr)	\$100
Energy (\$/kWh)	\$0.033

SUPPLY COST BENEFITS

Cumulative Benefits	\$26	\$57	\$93	\$136	\$187	\$247	\$265	\$285	\$307	\$331	\$358	\$387	\$419	\$455	\$494	\$458
PV Supply Benefits By Start Year																
Energy	\$74	\$77	\$81	\$85	\$90	\$94	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Demand	\$226	\$261	\$301	\$348	\$402	\$464	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Total	\$299	\$338	\$382	\$433	\$491	\$558	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

NPV DSM BENEFITS BY START YEAR

TRC	\$154	\$178	\$206	\$239	\$277	\$322	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
UC	\$224	\$255	\$291	\$333	\$381	\$436	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Shared Savings Bonus																	
TRC	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0

PRO-FORMA FINANCIALS FOR PRICES
(Costs in Millions)

SALES BASIS

FTY Factors

Expected DSM Impacts (GWh)

Historic Test Year

Future Test Year

Net Sales Basis (GWh)

Fuel Charge	1.7%
Base Charge	1.7%
Attrition Charge	1.7%
DSM/Bonus Charge	1.7%
ERAM Charge	1.7%

RATE BASE ACCOUNTS

Plant Additions	Actual
Depreciation	Actual
Plant in Service	Actual

OPERATING EXPENSES

Fuel	Actual
Base Fuel	Actual
DSM Savings	Actual
Net Fuel	Actual

Depreciation	5.0%
Other Base Expenses	Actual
DSM Expenses	Actual
Total Expenses	Actual

TARGET EARNINGS

Base Earnings for Common
Preferred Interest
Base Taxes
Debt Interest
Shared Savings Bonus
Taxes for Bonus
Total Earnings and Taxes

REVENUE REQUIRED TO MEET EARNINGS

Fuel
Base
"Gross" Attrition
DSM Expenses & Bonus
BOY ERAM Balance
Total Revenue

AVERAGE PRICES REQUIRED TO MEET EARNINGS

Fuel Charge
Base Charge
"Gross" Attrition Charge
DSM Bonus Charge
ERAM Charge

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
---	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----

	554	1,136	1,746	2,388	3,061	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768
1,136	1,746	2,388	3,061	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768	3,768
37,510	37,557	37,583	37,590	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	
37,510	37,557	37,583	37,590	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	
37,510	37,557	37,583	37,590	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	
37,510	37,557	37,583	37,590	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	
37,510	37,557	37,583	37,590	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	
	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350
	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350
	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000
	\$1,034	\$1,125	\$1,224	\$1,332	\$1,450	\$1,577	\$1,717	\$1,868	\$2,033	\$2,212	\$2,407	\$2,619	\$2,850	\$3,102	\$3,375
	(\$57)	(\$93)	(\$136)	(\$187)	(\$247)	(\$265)	(\$285)	(\$307)	(\$331)	(\$358)	(\$387)	(\$419)	(\$455)	(\$494)	(\$458)
	\$977	\$1,032	\$1,088	\$1,145	\$1,203	\$1,313	\$1,432	\$1,561	\$1,702	\$1,854	\$2,020	\$2,200	\$2,395	\$2,608	\$2,917
	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350
	\$1,234	\$1,296	\$1,360	\$1,428	\$1,500	\$1,575	\$1,654	\$1,736	\$1,823	\$1,914	\$2,010	\$2,110	\$2,216	\$2,327	\$2,443
	\$83	\$91	\$101	\$111	\$122	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$2,643	\$2,768	\$2,899	\$3,034	\$3,175	\$3,237	\$3,435	\$3,647	\$3,875	\$4,118	\$4,380	\$4,660	\$4,961	\$5,285	\$5,710
	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392
	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70
	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238
	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050
	\$977	\$1,032	\$1,088	\$1,145	\$1,203	\$1,313	\$1,432	\$1,561	\$1,702	\$1,854	\$2,020	\$2,200	\$2,395	\$2,608	\$2,917
	\$2,634	\$2,696	\$2,760	\$2,828	\$2,900	\$2,975	\$3,054	\$3,136	\$3,223	\$3,314	\$3,410	\$3,510	\$3,616	\$3,727	\$3,843
	\$83	\$91	\$101	\$111	\$122	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
	\$3,693	\$3,818	\$3,949	\$4,084	\$4,225	\$4,287	\$4,485	\$4,697	\$4,925	\$5,168	\$5,430	\$5,710	\$6,011	\$6,335	\$6,760
	\$0,026	\$0,027	\$0,029	\$0,030	\$0,032	\$0,034	\$0,037	\$0,039	\$0,042	\$0,045	\$0,048	\$0,051	\$0,055	\$0,059	\$0,064
	\$0,070	\$0,072	\$0,073	\$0,075	\$0,077	\$0,078	\$0,078	\$0,078	\$0,080	\$0,081	\$0,081	\$0,082	\$0,083	\$0,084	\$0,084
	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000
	\$0,002	\$0,002	\$0,003	\$0,003	\$0,003	\$0,003	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000
	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000	\$0,000

ACTUAL FINANCIALS (Costs in Millions)

ACTUAL SALES

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Base Sales	38,646	39,303	39,971	40,651	41,342	42,045	42,759	43,486	44,225	44,977	45,742	46,519	47,310	48,115	48,933	
DSM Impacts	(1,136)	(1,746)	(2,388)	(3,061)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,768)	(3,214)	
Net Sales	37,446	37,510	37,557	37,583	37,574	38,276	38,991	39,718	40,457	41,209	41,974	42,751	43,542	44,347	45,718	

1.7% trend

AVERAGE PRICES

Fuel Charge	\$0.026	\$0.027	\$0.029	\$0.030	\$0.032	\$0.034	\$0.037	\$0.039	\$0.042	\$0.045	\$0.048	\$0.051	\$0.055	\$0.059	\$0.064	
Base Charge	\$0.070	\$0.070	\$0.070	\$0.075	\$0.075	\$0.075	\$0.078	\$0.078	\$0.078	\$0.080	\$0.080	\$0.080	\$0.083	\$0.083	\$0.083	
"Net" Attrition Charge	\$0.000	\$0.002	\$0.003	\$0.000	\$0.002	\$0.002	\$0.000	\$0.001	\$0.001	\$0.000	\$0.001	\$0.002	\$0.000	\$0.001	\$0.001	
DSM Charge	\$0.002	\$0.002	\$0.003	\$0.003	\$0.003	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	
ERAM Charge	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	
Total Charge	\$0.098	\$0.102	\$0.105	\$0.109	\$0.112	\$0.112	\$0.115	\$0.118	\$0.122	\$0.125	\$0.129	\$0.134	\$0.138	\$0.143	\$0.148	

REVENUES

Fuel	\$977	\$1,032	\$1,088	\$1,145	\$1,203	\$1,313	\$1,432	\$1,561	\$1,702	\$1,854	\$2,020	\$2,200	\$2,395	\$2,608	\$2,917	
Base:	\$2,634	\$2,637	\$2,639	\$2,828	\$2,827	\$2,880	\$3,054	\$3,110	\$3,168	\$3,314	\$3,376	\$3,438	\$3,616	\$3,683	\$3,797	
"Net" Attrition	\$0	\$58	\$121	\$0	\$73	\$95	\$0	\$26	\$55	\$0	\$34	\$72	\$0	\$44	\$46	
DSM	\$83	\$91	\$101	\$111	\$122	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
ERAM	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Total Revenues	\$3,693	\$3,818	\$3,949	\$4,084	\$4,225	\$4,287	\$4,485	\$4,697	\$4,925	\$5,168	\$5,430	\$5,710	\$6,011	\$6,335	\$6,760	

RATE BASE ACCOUNTS

Plant Additions	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	
Depreciation	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	
Plant in Service	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	\$7,000	

20 year trend
0.0%

OPERATING EXPENSES

Fuel	\$1,034	\$1,125	\$1,224	\$1,332	\$1,450	\$1,577	\$1,717	\$1,868	\$2,033	\$2,212	\$2,407	\$2,619	\$2,850	\$3,102	\$3,375	
Base Fuel	(\$57)	(\$93)	(\$136)	(\$187)	(\$247)	(\$265)	(\$285)	(\$307)	(\$331)	(\$358)	(\$387)	(\$419)	(\$455)	(\$494)	(\$538)	
DSM Fuel Savings	\$924	\$977	\$1,032	\$1,088	\$1,145	\$1,203	\$1,261	\$1,319	\$1,377	\$1,435	\$1,493	\$1,551	\$1,609	\$1,667	\$1,725	
Net Fuel	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	
Depreciation	\$1,175	\$1,234	\$1,296	\$1,360	\$1,428	\$1,500	\$1,575	\$1,654	\$1,736	\$1,823	\$1,914	\$2,010	\$2,110	\$2,216	\$2,327	
Non-DSM	\$75	\$83	\$91	\$101	\$111	\$122	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
DSM	\$2,524	\$2,643	\$2,768	\$2,899	\$3,034	\$3,175	\$3,323	\$3,475	\$3,632	\$3,795	\$3,964	\$4,138	\$4,316	\$4,498	\$4,685	
Total Expenses																

8.8% trend

ERAM BALANCES

BOY Balance	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
Under (Over) Collection	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
EOY Balance	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	

EARNINGS

Pre-Tax Earnings	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	\$1,050	
Debt Interest	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	\$350	
Taxes	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	\$238	
Preferred Interest	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	\$70	
Earnings for Common	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	\$392	
Total Earnings	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	\$812	

EARNED RATES OF RETURN

On Rate Base	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	11.6%	
On Common	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	14.0%	

END

DATE
FILMED
6126192