BNL-33780

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

TRANSIENTS -- ABNORMAL AND OTHERWISE

by

BNL--33780

DE84 002877

Joseph M. Hendrie
Department of Nuclear Energy
Brookhaven National Laboratory
Upton, New York 11973

September 27, 1983

American Nuclear Society Meeting on
Anticipated and Abnormal Transients in Light Water Reactors
Jackson Hole, Wyoming

MASTER*EMB*

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

TRANSIENTS -- ABNORMAL AND OTHERWISE*

Joseph M. Hendrie
Department of Nuclear Energy
Brookhaven National Laboratory
Upton, New York 11973

Good evening. I extend my warm greetings to you. Especially to those of you who are members of the American Nuclear Society and whose reasoned judgment and clear perception of merit led you to vote for me in the recent Society election.

I have always admired people who deal with transient phenomena. Your colleagues who study static systems have an easier time; they can contemplate their subjects at leisure. They can stroll around, go to dinner, climb a mountain, and when they return all will be as they left it -- unchanged. But your objects of interest move and change in various ways and sometimes abruptly. One untimely sneeze and you have missed the whole thing. It is a difficult field, this study of transients, and I am honored to be with you at this meeting.

In a moment of introspection, I wondered why I was included in this distinguished company. But on reflection, I find that I have experience with assorted kinds of transients. In fact, the beginning of my career in nuclear engineering was on a transient experiment on the old Brookhaven Graphite Reactor. That was so long ago that it seldom comes to mind. It strikes me that few among you would remember those days. Would you believe that in those days we came to work in black frock coats and stove-pipe hats? And that we threw them in the

*This work carried out under the auspices of the U. S. Department of Energy.

air when President Lincoln came to wish us well? No? Well, I probably exaggerate a little bit. Actually, it was Teddy Roosevelt. "Bully reactor", he said, "Bully".

Anyway, the Brookhaven Graphite Reactor was a grand machine. It was one of the best research reactors ever built and provided neutrons for research for a long time. It was an air-cooled, graphite-moderated, natural uranium-fueled machine. Later on we refueled it with enriched uranium.

The containment was a fine classical industrial building with handsome brick walls and large glass windows. The air cooling meant that five great blowers sucked a quarter-million cubic feet per minute of air through the channels of the core and ejected the exhaust air at four or five hundred degrees Fahrenheit up an enormous stack. That stack, which was a forerunner of the very high coal-fired plant stacks of more recent times, was over 300 feet high, and that was measured from the top of what passes for a high hill on Long Island. The stack was 17 feet in inside diameter at the top and even with the blowers off and the pile shut down, there was always enough of a draft at the bottom to blow your hat off if you opened the inspection port. When the reactor was running, with the blowers all going and the exhaust air hot, the plume from the stack went straight up into the sky, punched holes in any cloud cover, and, for all I know, went straight into orbit.

That stack was the greatest radioactive waste disposal facility I've ever seen. We put something like seven or eight thousand curies of argon-41 a day up the stack. Occasionally a fuel element would leak and let out some fission gases. Once in a while those old natural uranium fuel slugs would grow in an odd way and breach the aluminum can and a chunk of spent fuel would go into the

exhaust stream. Never mind. It went up that stack headed for outer space and was never seen again.

My experiment was to measure the temperature coefficient of the pile during an annealing run. The graphite reactor had to be annealed periodically to relieve the radiation damage in the graphite. The annealing runs were done by running the machine at low power and restricting the cooling so that the whole graphite core block rose in temperature above the annealing threshold. That relatively isothermal condition of the pile made for ideal temperature coefficient measurements.

The reactivity changes due to graphite temperature were measured by a series of period measurements. Those were done with a stopwatch, and the data were reduced by slide rule as they came in. In the 30 years since those days, the instrumentation for that sort of measurement has gotten very much more sophisticated. I feel constrained, however, to point out that with stopwatch and slide rule and graph paper, we knew precisely where we were and what we were doing minute by minute throughout the entire run.

There were a couple of delightful aspects to the graphite reactor in those annealing runs. The first was that it was the most sensitive barometric instrument on Long Island. The nitrogen content of the air drawn in to cool the reactor was a slight neutron poison. With the machine cooking quietly along at a megawatt or so, you could track the slightest changes in barometric pressure by the reactivity effect. If the barometric pressure was decreasing, there would be slightly less nitrogen per cubic foot of incoming air and thus slightly less neutron poison in the air in the core. That would show up as a positive reactivity and the pile would drift slightly supercritical and begin to rise on a

slow period. You could track the barometric pressure over several days during the annealing run by plotting control rod positions to maintain critical.

The second aspect was that from a reactivity standpoint the graphite reactor was very nearly a point reactor. The kinetics were therefore fairly clean-cut. By comparison, the reactivity control of today's large light water reactors is more like herding cattle than controlling a precision machine. That is, reactivity control of a modern light water reactor is a matter of controlling the aggregate motion of a large number of individual critical regions that together form the core.

Later on, I worked on a project that was sort of all transient and no steady state at all. It was a pulsed fast reactor. It was to have plutonium fuel and sodium cooling and to be pulsed by swinging a pair of reflector blocks past the core. There was a big, fast rotor and a smaller, slower rotor, going in opposite directions. When the rotor tips lined up next to the core, the excess reactivity shot up to maybe ten dollars and the reactor let loose a whale of a power pulse. Upwards of five thousand megawatts from a 60-litre core. The pulse would have a width at half-maximum of about 90 microseconds and the peak power density would be up around 200 megawatts per litre of core volume. The fuel temperature would rise during that power pulse at a rate of about two million degrees Fahrenheit per second.

Now that is a power transient worth talking about. It is probably a good thing we never got to build that machine. In those days the government reactors were reviewed by the regulatory staff and the ACRS in a process that paralleled the reviews of commercial plants. I have often wondered what the staff would have made of our pulsed reactor. It was only 30 megawatts average power, but

I don't think the staff was ready for those five thousand megawatt pulses or for that large reflector rotor that developed about Mach One at the tip and would cut a slice off the core if there was excessive vibration in the shaft.

As a producer of time-dependent problems to be analyzed, our pulsed fast reactor was a machine of unparalleled excellence. One of the problems was the question of fuel pin fatigue failure from inertial stresses. The power pulse and the accompanying temperature pulse in the fuel were so fast that the fuel pin did not have time to respond by expanding to match the temperature rise. On each power pulse, the fuel pins would suddenly find themselves much too short for the temperature to which they had abruptly risen. The result would be an axial expansion of the fuel pins at the propagation velocity of sound in the pin material. The power pulse would be over and long gone but the fuel pins would be left with inertial stress waves traveling up and down them for a number of cycles until the internal friction would finally damp them out. Calculating all of that and trying to decide what the fatigue limit would be in those conditions was a really splendid problem. We hadn't solved it when the project was terminated. As I say, it is probably a good thing we did not build that machine.

I have some experience with other matters that involve transients. ATWS, for instance. For the few to whom that is a new word, it is the way we pronounce the letters A-T-W-S. It stands for Anticipated Transients Without Scram.

I could hardly come to a meeting on transients and not say something about ATWS. I was around on the Advisory Committee on Reactor Safeguards when E. P. Epler invented ATWS. In service on the ACRS, the regulatory staff, and the Nuclear Regulatory Commission, I have spent enough time being lectured to about ATWS to have completed the residence requirements for a doctorate in Medieval

Literature. And, I must tell you, a degree in Medieval Literature would have been almost as much help in understanding ATWS and what to do about it as all of those interminable hours I have spent listening to the experts of government and industry on this most arcane subject.

It is going on a decade and a half since I first heard Epler on the subject and there are arguments still going on about whether ATWS is a sufficient menace to plant integrity to require protective measures or not. On the other hand, events of recent times, notably the failure of half the rods to scram at a Brown's Ferry unit and the recent Salem scram breaker failures, suggest that we ought to stop arguing and make some changes.

Now, if ATWS is a problem, for whatever reason, I have already solved that problem twice. The first time was in 1973. That solution is contained in a notable volume entitled WASH-1270. It separated the plants into classes according to age and whether they were in or out of construction, and said this group do this and that group do that, and you fellows that are not too far along ought really to fix the problem, and come in by 1976 and let's see what your designs look like.

It seemed like a reasonable proposition at the time and I can remember Manning Muntzing, who was then Director of Regulation and who has more lately been our President of the American Nuclear Society, asking me about a month after WASH-1270 had been published why he was not getting cries of rage from every quarter. I pointed out that the art of successful regulation, like the art of successful taxation, was in easing the feathers off the goose without disturbing the bird.

Anyway, the WASH-1270 proposition raised some interesting possibilities from industry design groups. The best one, to my way of thinking, was one from

Combustion Engineering. That was to install some concentrated boric acid poison tanks driven by high pressure nitrogen accumulators and connected at the discharges of the reactor coolant pumps with something like explosive-driven, diaphragm-sealed valves. If instruments or the operator saw an anticipated transient and no scram, the valves would fire, the poison would go into the pump discharge water stream, and would be carried rapidly into the reactor vessel to shut down the core.

Unfortunately, the regulatory staff was holding out in those days for a backup shutdown system that would have the same performance standards as the control rod system, that is, shut down when needed with no fuel damage. The liquid poison injection system had a time constant comparable to the circulation time of the primary system, that is, twenty to thirty seconds, and it shut down the core all right, but not quite in time to avoid some of the hotter fuel rods developing leaks. So the staff rejected the liquid poison proposition as not meeting their ad hoc requirements. I had left the game by that time, but I suspect the staff was engaged in a sort of standard staff practice to press and see how far you could go with one of these requirements. In this case, they kept pressing a little too long and the offer got withdrawn in favor of more and more complicated analyses to show that ATWS was not a problem. So my 1973 solution didn't go anywhere.

Later on, in the closing days of my tenure on the Nuclear Regulatory Commission, I proposed an ATWS rule that had two parts. The first part had some hardware requirements to fix obvious deficiencies. Things like the reactor coolant pump trip that has already been installed in all of the boiling water reactors. The second part was a requirement that plants develop a reliability engineering program for their protection and scram systems. My thought was to

get people who understood each individual plant to sit down and think carefully and methodically about the ways in which scram action might be defeated when it was needed. I will claim that if two or three clever people had been thinking along those lines at the Salem plant, a year or two ago, there is a reasonable likelihood that the recent Salem events would have been forestalled.

This last ATWS proposition of mine did not get a very good press from either the regulatory staff or the industry side, although in a spasm of generosity my colleagues on the Commission voted to publish it for public comment. The complaint about my ATWS rule, from both industry and regulatory staff sides, was that the reliability engineering program requirement was not specific enough. The industry people didn't want to be told to go and think carefully about a subject; they wanted to know what specific steps they should take to satisfy what might become a regulatory requirement. Their concern seemed to be whether or not they could easily satisfy the formal requirements that might flow from the rule rather than whether they might learn something from thinking innovatively about a prospective problem.

The regulatory staff didn't like my proposition on reliability engineering initiatives because these were not framed in detailed and specific terms. My rule, in essence, said that each plant operator was to lay out a reliability engineering program for his protection and scram system and to tell the regulatory staff about it in due time. The regulatory staff didn't like that very much because it didn't have any clear and specific points against which they could enforce the rule if it were put in place. The staff has always been very big on enforcement of rules and license requirements. My reliability engineering requirement didn't seem to have any clearly-defined enforceable points in it, and so the staff wasn't much taken with it.

I may not get a chance to propose a third solution to the ATWS problem, if it is a problem, because the Commission seems about to act on an ATWS rule. I am sure it will have lots of good enforceable points in it, and I hope it all turns out to be as effective as I think either of my two ATWS solutions would have been.

* * * *

In nuclear plant operation, the aim is to get the machine at power and operating smoothly and to keep it there for a long time. Operating crews that manage two and three hundred-day uninterrupted runs get congratulations from the front office and the general admiration of their peers. But there are not very many long, uninterrupted runs like that. Relays hang up, valves malfunction, and the ubiquitous instrument technicians will cram their screwdrivers into the wrong places. Plant upsets are bound to occur, although not at the excessive rate that seems to be American standard practice.

Since one of the principles of banquet speaking is to discover the obvious, I will point out that from a risk standpoint it is quite as good to diminish the rate of challenge to plant safety systems as it is to increase the likelihood of successfully meeting those challenges. I have been looking at some numbers for reactor trips that suggest 1983 is going to be a banner year for challenges to reactor protection systems. Gary Holahan of the NRC, who collects and analyzes this sort of information, has kindly shared his data with me.

In recent years, American plants have been averaging between five and six reactor trips a year. That is an average for the whole industry, of course, and

the trip rate varies substantially from plant to plant. The average trip rate has actually been trending slightly downward in the last few years: 5.9, 5.8, and 5.5 trips per unit-year for 1980, '81, and '82. The rate for 1983, extrapolated from data through the end of August, would be 6.8 trips per unit. That is a rather uncouth increase of some 24% in the average reactor trip rate over 1982.

While those numbers are fresh in mind, I will cite two other interesting statistics. The first is that for reactors recently started in operation, that is, within about two years of startup, the average reactor trip rate in 1982 was 11.5 per unit, compared to the all-industry average of 5.5. That is consistent with the conventional wisdom that units coming into operation go through a shakedown period for both staff and equipment. It is, however, a rather high trip rate and deserves some work to get it down.

The second statistic is that 24 operating units in Japan had a total of 7 reactor trips in 1982 for an average rate of 0.3 trips per unit-year, compared to the American average of 5.5. 1982 seems to have been a very good year for reactor operation in Japan. I understand that a more normal rate in Japan is between 1 and 2 reactor trips per unit-year. That is still a lot better than current American practice and, even allowing for some differences in definitions, again suggests that we have substantial room for improvement.

My initial thought, in looking at the overall numbers on reactor trip rates, and particularly at the substantial increase in the 1983 rate, was that a lot of those reactor trips were probably spurious. That is, some equipment malfunction or personnel error had caused a reactor trip that was unnecessary to protect the plant. There are, indeed, a number of spurious trips in the data, but fewer than I had thought. For the 1983 data that are in hand, something

like 1/4 to 1/3 of the total number of reactor trips are spurious. The rest of them, the great majority, were needed to protect the plant because a personnel error or equipment malfunction, or some other operational event, occurred that created a transient which required a reactor scram.

Looking further at the 1983 data to see if it is the people or the equipment that caused all those trips, the honors appear to be pretty evenly split at this point. In the personnel error category, contrary to what you might have guessed, trips caused by personnel errors during surveillance testing amount to less than one-third of the trips from personnel errors of all kinds.

These are very interesting data and are worthy of some careful study by plant operating staffs. They are particularly worth studying at those plants where the reactor trip rate is significantly above the industry average.

I suppose that an appeal to reduce the rate at which reactor protection systems are challenged might be poorly received by a group of people who study transients and might be regarded as a restraint of trade message. Please accept my assurances that operating staffs are not about to eliminate all personnel errors and equipment failures and other sources of transients. Your skills and best efforts will be needed urgently as far into the future as I can see.

Since some plant upsets and transients are inevitable in operation, it behooves us, as many here have pointed out before me, to study transient phenomena so that we understand them and can manage them to prevent more serious events. The study of transient phenomena in reactors is a long-standing and honorable practice that goes back to the very beginning of the business. In the early days, it had mostly to do with point reactor kinetics. It is a much broader field now and includes such esoteric matters as space-dependent kinetics, thermal and hydraulic phenomena, and probabilistic risk assessment techniques.

Transient management is a newer art and is still in the development phase. Some of you may have been busy with your own work and not have paid much attention to this new field. It is really quite simple. I can explain the whole thing to you in a hundred words, as follows.

The essentials of transient management are first, to see where the machine is going, and second, to plan ahead. The objective of transient management is to achieve the three fundamental conditions of reactor safety. Those are also very simple. They are to shut down the nuclear reaction, to keep the core covered with water, and to remove the afterheat. In the event of a planned upset, the transient managers use standard and special instrumentation to see what is going on and what the plant condition is and, using emergency operating procedures and their knowledge of the plant, maneuver plant systems so as to carry out the essential safety functions of shutting down the core, keeping it covered, and taking out the afterheat.

So, see where you are and plan ahead: that is transient management. I told you it was simple; practically nothing to it. I know, you're going to say it's a lot more complicated than that and I didn't mention any of the details or cautions. But you have to remember that I'm the banquet speaker. I give you the big picture. If you want all that detailed stuff, you have to go listen to the papers.

There are a couple of more detailed comments that I want to make, however. One has to do with the "see where you are going" part of transient management. Being able to see what the reactor is doing and the condition of plant systems is absolutely essential for successful transient management.

We have decided that conventional control room instrumentation is not as good as it should be in this regard. The safety parameter display board was

first conceived as a gathering together in one place of a dozen or so of the essential reactor parameter indicators so that in the event of a transient, the operators did not have to run up and down the control room to see what was going on. The safety parameter display systems that are under development by various industry groups go well beyond that initial simple concept. They use color television screens hooked to the plant computers and show all sorts of system diagrams and functions and parameter values. That is a very good thing for successful transient management and I look forward to the implementation of these systems on operating plants. I hope I do not have to wait much longer for general implementation of these systems. They have been developed far enough so that operating plants can begin to place orders, and I encourage that order-placing to start.

A caution is in order here. As the system designs become more sophisticated, there may be a tendency for them to become more engineer-directed than operator-directed. Now these systems should indeed be used by and useful for engineers, but the initial or top-level displays in the system hierarchy ought to be reserved for operator use and designed to fit operator needs and capabilities. The operators' displays ought to show just the essential plant conditions and, most important, in a manner that allows the operators to sense intuitively in which directions they must maneuver the plant to keep within safety limits. I think that is the intent of the designers of these systems and my caution is just to remind them to stick to it.

Another comment has to do with the "plan ahead" part of transient management. We are now moving to symptom-based emergency procedures. We have improved operator training in dealing with plant upsets and transients. We have shift technical advisors ready at hand with special engineering and accident

analysis training. We have a developing field of transient management. Those are all good things in the "plan ahead" department.

The new emergency operating procedures, once shaken down and understood, provide a much better prescription for what to do in a transient than the old procedures. And with better operator training, with the technical advisors at hand, with transient management concepts, shift crews are much better prepared to use the emergency procedures correctly.

They are also much better prepared to know when it is time to go outside procedures to avoid a serious event. We have provided and encouraged this latter capability -- the capability of the shift crew to think for itself in off-normal conditions. And that is all to the good.

But now a caution to the regulators, particularly the inspectors. Watch out that you do not paralyze this capability by being interested only in adherence to procedures as the measure of proper operation, rather than in what was needed and appropriate at the time. I raise this caution because I observe a certain amount of nit-picking at operating plants over adherence to procedures, and the inspector's interpretation of procedures at that, regardless of plant circumstances. You regulators have to be willing to take account of plant conditions that may make operator actions other than rigid adherence to procedures the best course.

Most of the time, correctly following emergency procedures is the best course. But once in a while, circumstances will be such as to make some deviations from procedures appropriate. The regulatory system has to make allowance for such cases, or it will drive operators to behave as though plant safety was less important than blindly following procedures.

* * * *

You may have noticed that I have gotten rather well along in this speech without mentioning Three Mile Island. That's because it is not one of my favorite transients. You recall the famous words of the man who was about to be hung before a large gathering in the town square: "If it weren't for the honor of the thing, I'd just as soon have stayed at home." Actually, Three Mile Island was a whole set of transients, but that doesn't make it any more likeable.

You may have seen one of those coupled oscillator toys. There will be a row of three or four or a dozen little steel balls all hanging on rods that connect to a common support bar. You push the ball on the end and it oscillates back and forth. After a bit it slows down and stops and the next ball begins to oscillate. Then that ball slows down and the next one starts to oscillate. And so on.

Three Mile Island worked that way. First, the reactor and the operators did their transient. Nobody else did much of anything. Oh, the NRC got some people over to the site, but not much else happened. After the operators were about through, and the reactor was stabilized, the various human institutions began to oscillate. The NRC, the press and electronic media, the rest of the Federal government, and a lot of people in Pennsylvania, each group in turn went through its transient. Some of those people, Congressional subcommittee staff people mostly, still seem to be oscillating and exciting one another.

But, like it or not, Three Mile Island was a very illuminating experience. It showed that none of us were prepared for competent transient management. The operators at that unit certainly were not prepared and the unit managers didn't

do much better when they arrived and took charge. The NRC wasn't very well prepared either.

The obvious deficiencies revealed by Three Mile Island have been remedied by now and we are much better prepared on all levels to deal with plant upsets.

But let's not stop here. We need to keep working on transient analysis, to improve our techniques and understand these things better.

We need to keep working on the symptom-based emergency operating procedures and on shift crew training, particularly on plant-specific simulators with improved capability.

We need to improve the computer-based plant safety status displays now under development and the built-in computational and analytical capabilities of these systems to collect and correlate the information available in plant computers and to present it in improved formats.

We need to develop further the concept of transient management as a function of senior people on shift who have special training in assessing overall plant status in off-normal conditions and in planning the best course to recover the plant to normal conditions.

This meeting, the first ANS topical meeting on operational transients, is evidence of the importance of the subject and the interest in it. I commend the organizers of this meeting and the authors of the many interesting papers being presented here for their fine efforts. The work is well underway. Let us all speed it along.

Thank you.