Lawrence Berkeley Laboratory

UNIVERSITY OF CALIFORNIA

ENERGY & ENVIRONMENT DIVISION

OCCUPANT-GENERATED CO₂ AS AN INDICATOR OF VENTILATION RATE

Isaac Turiel and John Rudy

April 1980

For Reference

Not to be taken from this room

RECEIVED
LAWRENCE
BERKELEY LABORATORY

JUN 20 1980

LIBRARY AND
DOCUMENTS SECTION

LBL-10496c.1

DISCLAIMER

This document was prepared as an account of work sponsored by the United States Government. While this document is believed to contain correct information, neither the United States Government nor any agency thereof, nor the Regents of the University of California, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by its trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or the Regents of the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof or the Regents of the University of California.

Occupant-generated CO₂ as an Indicator of Ventilation Rate

Isaac Turiel and John Rudy

Energy Efficient Buildings Program
Energy and Environment Division
Lawrence Berkeley Laboratory
University of California
Berkeley, California 94720

April 1980

The work described in this report was funded by the Office of Buildings and Community Systems, Assistant Secretary for Conservation and Solar Energy of the U.S. Department of Energy under contract No. W-7405-ENG-48.

ABSTRACT

Ventilation rates in buildings are generally determined by means of tracer-gas techniques that permit calculation of the number of air changes per hour occurring in a given area, or, alternatively, by measuring the actual air flow in the ventilation ducts. There are difficulties associated with both of these methods. In this study in a San Francisco office building, we used occupant-generated CO₂ as an indicator of the actual ventilation rate. Two techniques were employed, a decay method and an integral method and, in both cases, measurements were conducted simultaneously at several locations. The decay method compared favorably with the conventional measurement methods in both the all-outside-air and recirculation modes, whereas the integral method showed a considerable deviation from the other methods in the recirculation mode. Both techniques show promise of being suitable methods for measuring ventilation rate in commercial or institutional buildings.

Keywords: buildings, carbon dioxide, indoor air quality, office building, tracer gas, ventilation

Occupant-Generated CO₂ as an Indicator of Ventilation Rate

Isaac Turiel and John Rudy

INTRODUCTION

In response to national efforts to conserve energy, new construction in both the residential and non-residential sectors now incorporate features designed to reduce infiltration and ventilation rates and thereby lower heating and cooling requirements.^{1,2} One of the ramifications of reducing infiltration and ventilation rates, however, is that indoor air quality may deteriorate, compromising the health and comfort of building occupants.³ At Lawrence Berkeley Laboratory (LBL), we have initiated a broad-scale program to assess the impact of ventilation-related energy conservation measures on indoor air quality. There are two approaches to evaluating the quality of indoor air in institutional and commercial buildings: the first is to directly measure the concentrations of indoor air pollutants and the second is to infer the quality of the indoor air by measuring the ventilation rate.

In this paper we describe two methods of measuring ventilation rates in occupied buildings. Both methods use occupant-generated CO₂ as an indicator of the ventilation rate at the stratum of the occupied space where occupants breathe the air. We will confine the present discussion to non-residential buildings, although these methods are also suitable for use in residential buildings where CO₂ may be generated by combustion appliances such as gas stoves.

In both methods to be described, the concentration of CO₂ generated by occupants is measured simultaneously in several locations throughout

the building. This procedure permits making time-integrated calculations of ventilation rate. Precise measurement of the ventilation rate at the occupied stratum in a room becomes particularly important if both outside air and total air-circulation rates are reduced, because such a reduction may aggravate the problem of delivering the contaminant-diluting ventilation air to the breathing level of the inhabitants of the conditioned space. As ventilation rates are lowered, CO_2 levels rise and, thus, the accuracy of the measurement techniques increases.

Two frequently used methods of determining ventilation rate rely on tracer-gas techniques or air-flow measurements within ventilation air ducting systems. In the first method, a gas, such as sulfur hexafluoride (SF_6), ethane (C_2H_6), or nitrous oxide (N_2O) is injected into the space and measured (concentration in ppm of air) as a function of time. If the tracer gas is well mixed throughout the space, the number of air changes per hour (ach) is obtained from the slope of the exponential decay curve plotted on a semi-logarithmic scale. To convert this air-change rate to a volume-flow rate, the mixing volume -- which may or may not be the total room volume -- must be known. Other problems associated with injecting these gases into occupied spaces have to do with properties of the gas used. SF_6 is heavier than air and requires fans to ensure thorough mixing⁴. In the case of C_2H_6 , special handling is required to avoid an explosion which might occur if the ethane concentration exceeds 3%⁵. Because of the potential health hazard to occupants, N_2O cannot be used at concentrations greater than 25 ppm⁶. When using these gases for such experimental purposes, permission should be obtained from the building manager. It is obvious that using occupant-generated CO_2 as a tracer gas avoids most or all of the above problems

and, from any vantage point,⁷ is considerably more convenient.

The second method, measuring air flow in ventilation ducts, has the advantage of providing direct-source ventilation rates. A major disadvantage, however, is that duct measurements do not necessarily correlate with actual air flows in the conditioned space or at the breathing stratum of the occupied space. For example, there may be ventilation air losses from the air-distribution system and ineffective and/or unequal distribution of ventilation air within the occupied space or spaces. Further, supply and return air ducts in mechanical ventilation systems are often inconveniently located, making it difficult to perform accurate measurements. Even when accurate measurements can be made in the distribution system, the ventilation rate determined from these measurements, as noted above, is not necessarily a measure of the actual ventilation rate experienced by the building occupants. In contrast, using the CO₂ generated by the occupants themselves assures that we can determine the "effective" ventilation rate for the occupied stratum of the conditioned space.

EXPERIMENTAL SITE CHARACTERISTICS

During the fall of 1979, we monitored CO₂ concentration in the eight-story San Francisco Social Services (SFSS) Building. The building had been occupied for one year at the time of our studies. It operates two separate mechanical ventilation systems, one for the first floor and another for the second through eighth floors. On the first floor, where our monitoring was conducted, the ventilation system mixes outside air with recirculated air which is then passed through an air-conditioning unit. Air from this unit is transmitted to induction terminal devices,

some of which have heating coils, located above the ceiling of the conditioned space. Return and recirculated air enters this plenum above the ceiling through slots in the lighting fixtures. Air from this plenum is then induced to recirculate back into the occupied space, returned to the air conditioning unit, or exhausted from the building.

In this study, the quality of the outside air and the air in the first-floor applicant interview area was monitored continuously. The interview area is almost triangular in shape and contains a large waiting room and several office cubicles with partitions approximately seven feet high. Smoking is permitted in the office cubicles. The dimensions of the area are 30.5m X 27.5m X 39.6m (100ft X 90ft X 130ft) with a 3.35m (11 ft) high ceiling. The area tested (~20% of the total first-floor space) had a volume of $1,405\text{m}^3$ ($50,000\text{ft}^3$.) Each of three selected locations within this test area was sampled sequentially at ten-minute intervals. CO_2 concentration was measured with an infrared absorption instrument, and occupancy was determined every hour on the hour by visually counting the number of people in the test sector.

Tests of ventilation rates were made with the air-conditioning unit in both a recirculation mode (15% outside air) and an all-outside-air mode. In the recirculation mode the CO_2 concentrations throughout the first floor varied by as much as 20%, being highest in the heavily populated waiting room.

METHODOLOGY

1. Ventilation Rate by CO_2 Measurement

Tracer-Gas Decay Method -- Our first method of calculating the ventilation rate is based on routine tracer-gas decay methods. Assuming that the mixture of CO₂ and room air is homogeneous when the generation of CO₂ ceases, the concentration C_i(t), falls exponentially according to the equation:

$$C_i(t) - C_o = (C_1 - C_o) e^{-Qt} \quad (1)$$

where

C_i = inside concentration of CO₂

C_o = outside concentration of CO₂

C₁ = initial indoor concentraion of CO₂

Q = outside air ventilation rate (hr⁻¹)

Solving for Q, the air exchange rate, we have:

$$Q = \frac{1}{(t_2 - t_1)} \left[\ln (C_1 - C_o) - \ln (C_i(t) - C_o) \right] \quad (2)$$

Integral Method -- Equation (3) models the air flow into and out of a space of volume V, where CO₂ is being generated at the rate G by each of N people:

$$\frac{d}{dt} (C_i V) = GN - (C_i - C_o) Q \quad (3)$$

where

V = volume of space where CO_2 concentration is measured (m^3)

N = number of people in volume V

G = average CO_2 generation rate of people in space in $m^3/h/person$

In the above equation, it is assumed that CO_2 is homogeneous in the space and does not diffuse to other spaces surrounding the space of volume V . Rearranging and expressing equation (3) in integral form yields:

$$\int_{t_1}^{t_2} Q(C_1 - C_o) dt = \int_{t_1}^{t_2} GN(t) dt - \int_{C_1}^{C_2} V dC_1 \quad (4)$$

If one chooses times t_1 and t_2 such that $C_1 = C_2$ then the third integral will equal zero and equation (5) results:

$$Q = \frac{\int_{t_1}^{t_2} GN(t) dt}{\int_{t_1}^{t_2} [C_1(t) - C_o] dt} \quad (5)$$

The ventilation rate can be calculated by integrating the occupancy and concentration functions over the chosen time period and using the appropriate CO_2 generation rate, G .

2. Ventilation Rate by Air-Flow Measurements

Air velocity was measured, using a hot-wire constant-temperature anemometer, at the return air connection to the air-conditioning unit and in the mixed air chamber upstream from the cooling coil. In each case, the average velocity was multiplied by the associated area to determine the air-flow quantity. The return air flow was deducted from the total air flow to determine the outside air flow.

RESULTS

Fig. 1 illustrates the time dependence of occupancy and CO_2 concentration in the waiting room on a day when the ventilation system was in the all-outside-air mode. The CO_2 concentration was found to vary slightly (~10%) among the three indoor locations where CO_2 was continuously monitored. The outside CO_2 concentration was found to be essentially constant (~325 ppm).

Fig. 2 illustrates the time dependence of occupancy and CO_2 concentration in the waiting room on a day when the ventilation system was in the constant recirculation mode with both the outside and return air dampers in fixed positions. In general, CO_2 concentration follows occupancy patterns rather well.

Decay Method -- As is evident in Figs. 1 and 2, CO_2 concentration drops sharply when occupants leave the area at the end of the day. When the indoor CO_2 concentration, minus the outdoor CO_2 concentration, C_o , is plotted against the time of day (beginning at 5 p.m., the end of occupancy for this area) on semi-logarithmic graph paper, a straight-line fit can be obtained as shown in Fig. 3. The slope of this straight line

is the air-exchange rate. Fig. 3 is a plot of CO_2 decay for September 18, 1979 and corresponds to the tail portion of Fig. 2, corrected for outside CO_2 concentration. The air-exchange rate for that particular day, determined in this manner, was 0.38 ach. For the five days (September 17-21) when the CO_2 decay rate was determined in the above manner, the average air-exchange rate was 0.44 ach. Four of the five measurements ranged between 0.38 and 0.42 ach and the fifth measurement was 0.57 ach. During all of these days, the ventilation system was in the recirculation mode. On September 20, The Research Corporation of New England (TRC) performed a tracer-gas measurement, injecting SF_6 into the supply air duct and measuring its concentration in the test area every ten minutes (by gas chromatography) for a one-hour period. A ventilation rate of 0.55 ach was obtained by this method. The LBL measurement on September 20, was 0.39 ach.

When the ventilation system was in the all-outside-air mode (September 25-28), the concentration of CO_2 was significantly lower than when in the recirculation mode. As a result, the measurement of the CO_2 decay rate was more difficult to obtain. In order to gather enough data to accurately plot the CO_2 decay curve over a short time period, we monitored CO_2 concentration at one location continuously instead of sequentially sampling for ten minutes at each of four locations. Fig. 4 shows the CO_2 decay curve and a straight-line "best fit" for the time period between 5:00 and 5:30 p.m. on that test day (September 27). The resulting air-exchange rate was 2.4 ach. TRC performed SF_6 decay measurements under the same ventilation conditions and obtained a ventilation rate of 2.3 ach on September 27, and an average ventilation rate of 2.4 ach (range 2.2 to 2.7 ach) for the four days. TRC measurements were made by

releasing SF_6 at several locations in the interview area and mixing it by means of fans, as well as by releasing SF_6 into the supply air duct.

Integral Method -- Equation (3) was used to calculate ventilation rate using the data presented in Figs. 1 and 2. The lower and upper limits, t_1 and t_2 respectively, were chosen so that $C_1 = C_2$. The generation rate of CO_2 was taken to be $0.021 \text{ m}^3/\text{h}/\text{person}$ ($0.74\text{ft}^3/\text{h}/\text{person}$), an average for sedentary people and people performing desk work⁸. The area under each curve was separately calculated and $\int_{t_1}^{t_2} C_o \, dt$ was subtracted

from $\int_{t_1}^{t_2} C_i(t) \, dt$.

For Fig. 1, the following was obtained:

$$Q = \frac{0.021 \text{ m}^3/\text{h}/\text{person} \times (611.5 \text{ person hrs.})}{3,332 \times 10^{-6} \text{ hrs.}} = 3,865 \text{ m}^3/\text{h} = 2,274 \text{ cfm}$$

Therefore, for the all-outside-air mode we find the outside-air ventilation rate to be $3,865 \text{ m}^3/\text{h}$ (2.73 ach) by this method. This can be compared to 2.43 ach as determined by the CO_2 decay method.

Similarly, for the recirculation mode, we analyzed Fig. 2 and found that

$$Q = .021 \frac{\text{m}^3/\text{h}/\text{person} \times (558 \text{ person hrs.})}{9,595 \times 10^{-6} \text{ hrs.}} = 1,221 \text{ m}^3/\text{h} = 718 \text{ cfm}$$

The CO_2 decay method yielded an average air-exchange rate of 0.44 ach ($618 \text{ m}^3/\text{h}$) for this ventilation mode.

The results of air-flow measurements in the ventilation ducts are shown in Table 1. The outside air ventilation rate in the all outside air mode is seven times that in the recirculation mode.

DISCUSSION

When the ventilation system is in the all-outside-air mode, there is good agreement among the methods used to calculate ventilation rate. As can be seen in Table 1, less ventilation air actually reaches the occupied stratum than air-flow measurements in the ducts would indicate. Distribution losses in the ventilation ducting system may account for the lower ventilation rates predicted by the other calculation methods.

In the recirculation mode, the agreement between the CO_2 decay method and air-flow measurements in the ducts is very good; with the CO_2 integral method, however, it is not. The SF_6 and CO_2 decay measurements differ by about 20%, a larger differential than we expected. On the other hand, only one SF_6 measurement was taken in this ventilation mode, and the one-hour measurement period may not have been long enough to establish an equilibrium situation throughout the first floor.

In the same ventilation mode, the CO_2 integral method of calculation yielded a ventilation rate twice as high as that obtained by the CO_2 decay method or by the air-flow measurements. A possible explanation for this result is that, in the recirculation mode, unequal CO_2 concentration between the test area and other spaces on the first floor led to transfer of CO_2 from the test area and increased its loss rate beyond that which would result from outside-air dilution alone. At the end of the day, when the CO_2 decay measurements were taken, the air throughout

the first floor would have reached a more homogeneous condition so that the CO_2 decay measurement would produce a more accurate indication of ventilation rate.

If we select $3,400 \text{ m}^3/\text{hr}$ ($2,000 \text{ cfm}$) as the rate at which ventilation air is supplied to the test area in the all-outside-air mode, then we find that the ventilation rate ranges from 34 to $57 \text{ m}^3/\text{h}$ (20 - 33 cfm) per person during periods of high occupancy. Similarly, if we choose $620 \text{ m}^3/\text{h}$ (360 cfm) as the rate at which ventilation air is supplied to the test area in the recirculation mode, we find a ventilation rate of 6 - $10 \text{ m}^3/\text{h}$ (4 - 6 cfm) per person during high occupancy periods. Under maximum occupancy conditions (~ 100 occupants) occupant density in the test area is one person per 14 m^3 (500 ft^3). Typically, the design criteria for occupant density in office areas is one person per 28 m^3 ($1,000 \text{ ft}^3$).

CONCLUSIONS

The CO_2 decay method of measuring ventilation rate compares favorably with both SF_6 tracer-gas measurements and with air-flow measurements in the ducts. This method should be applicable to any commercial or institutional building where most of the occupants leave at approximately the same time and occupant density is reasonably homogeneous. When outside-air ventilation rates are low, as in energy-conserving buildings, CO_2 concentrations rise and, thus, the CO_2 decay method is more easily applied. The integral method of determining ventilation rate appears to be satisfactory in the all-outside-air mode but overestimates the ventilation rate in the recirculation mode, perhaps because of the presence of CO_2 gradients. In addition, there is always some

uncertainty in fixing the value of G (CO₂ generation rate), and this factor will affect the calculation of ventilation rate.

Indoor air-quality studies performed by LBL^{9,10} have confirmed that CO₂ concentration is a good indicator of indoor air quality in many non-residential buildings. Under contract to LBL, Honeywell, Inc., is now testing an automatic variable ventilation control system based on CO₂ detection at a junior high school in the Minneapolis area.¹¹ We believe that significant energy savings can result when ventilation systems are designed to be responsive to occupancy/activity levels rather than to fixed standards based on maximum occupancy code requirements.

REFERENCES

1. Besant, R.W., Dumont, R.S., and Schoenav, G., "Saskatchewan House: 100 Percent Solar in a Severe Climate," Solar Age:18-20, May 1979.
2. The American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., Standard for Energy Conservation in New Building Design, ASHRAE 90-75R, 1977.
3. Hollowell, C.D., Berk, J.V., Boegel, M.L., Miksch, R.P., Nazaroff, W.W., and Traynor, G.W., Building Ventilation and Indoor Air Quality, LBL-10391 (January 1980).
4. Grimsrud, D.T., Sherman, M.H., Jannsen, J.E., Pearman, A.N., and Harrje, D.T., An Inter-comparison of Tracer Gases Used for Air Infiltration Measurements, Lawrence Berkeley Laboratory Report, LBL-8394 (November 1979).

5. Sax, N.I., Dangerous Properties of Industrial Materials, Van Nostrand-Reinhold, New York, 1979.
6. U.S. Department of Health, Education and Welfare, Occupational Exposure to Waste Anesthetic Gases and Vapors, HEW Publication No. (NIOSH) 77-140, Supt. of Documents, U.S. Government Printing Office, Washington, D.C., 1977.
7. Hunt, C.M., "Ventilation Measurements in the Norris Cotton Federal Office Building in Manchester, N.H.," ASHRAE Transactions, 85, 1; 1979.
8. The American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1978 Applications Handbook, ASHRAE, New York, 1978.
9. Turiel, I., Rudy, J., and Hollowell, C.D., The Effects of Reduced Ventilation on Indoor Air Quality in an Office Building, Lawrence Berkeley Laboratory Report, LBL-10479 (in preparation).
10. Berk, J.V., Hollowell, C.D., Lin, C., and Turiel, I., The Effect of Reduced Ventilation on Indoor Air Quality And Energy Use in Schools, Lawrence Berkeley Laboratory Report, LBL-9382 (June 1979).
11. Turiel, I., Hollowell, C.D., and Thurston, B.E., Variable Ventilation Control Systems: Saving Energy and Maintaining Indoor Air Quality, Lawrence Berkeley Laboratory Report, LBL-9380 (June 1979).

Table 1

Summary of Ventilation Rate Measurements: SF Office Building

Mode	<u>Calculation Method</u>				Velometer in Ducts
	CO ₂ decay	SF ₆ decay ^a	CO ₂ Integral		
All outside air	3,434 (2,020) ^b	3,365 (1,980)	3,865 (2,274)		4,490 (2,642) ^c
Recirculation	609 (358)	782 (460)	1220 (718)		621 (365) ^d

^a Measured by TRC.

^b m³/h (cfm).

^c An 8-point traverse was taken in the supply air duct

^d A 32-point traverse was taken in the supply air duct and a 12-point traverse in the return air duct.

Acknowledgments

We wish to thank James Berk, James Koonce, and Rodger Young of LBL's Ventilation and Indoor Air Quality group for their assistance in carrying out the measurements reported here. Dick Duffee and Paul Jann of The Research Corporation of New England were very helpful in supplying us with their SF₆ tracer measurement results. We are especially grateful to Peter Warren of the Building Research Establishment in Watford, England for several informative discussions concerning the CO₂ integral method of measuring ventilation rate.

Figure Captions

- Figure 1 Time dependence of carbon dioxide concentration and occupancy in the waiting room of the San Francisco Social Services Building. The ventilation system is in the all-outside-air mode.
- Figure 2 Time dependence of carbon dioxide concentration and occupancy in the waiting room of the San Francisco Social Services Building. The ventilation system is in the recirculation mode.
- Figure 3 Carbon dioxide decay curve for the recirculation mode.
- Figure 4 Carbon dioxide decay curve for the all-outside-air mode.

XBL804-596

Figure 1 Time dependence of occupancy and of carbon dioxide concentration in the waiting room of the San Francisco Social Services Building. The ventilation system is in the all-outside-air mode.

XBL804-597

Figure 2 Time dependence of occupancy and of carbon dioxide concentration in the waiting room of the San Francisco Social Services Building. The ventilation system is in the recirculation mode.

XBL 7910-4478

Figure 3 Carbon dioxide decay curve for the recirculation mode.

XBL 7910-4477

Figure 4 Carbon dioxide decay curve for the all-outside-air mode.