MCR-80-1377

MCR--80-1377

DE82 007235

SOFTWARE/FIRMWARE DESIGN SPECIFICATION

for

10-MWe SOLAR-THERMAL
CENTRAL-RECEIVER PILOT PLANT

March 1981

(Interim Release)

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Prepared Under Contract No. DE-AC03-80SF10539

by

Martin Marietta Corporation

for

Department of Energy

NOTICE

FOR ONLY

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It
has been reproduced from the best available
copy to permit the broadest possible avail-
ability.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Ⓔ

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

The following pages are an exact
representation of what is in the original
document folder.

10 MW_e COLLECTOR SUBSYSTEM
CENTRAL RECEIVER SYSTEM
SOFTWARE/FIRMWARE DESIGN SPECIFICATION

5 March 1981

(Interim Release)

Prepared by:

Timothy D. Ladewig
HAC Lead Engineer

Concurrence:

Mike DiAls
HFC/HC Lead Engineer

Approved by:

Paul S. Thames
Solar Collector Lead Software Engineer

Approved by:

Walt Hart
Collector Subsystem Controls Manager

Approved by:

Paul R. Brown
Program Manager
Collector Systems

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	INTRODUCTION	1
1.1	Scope	1
1.2	Problem Statement	1
1.3	Design Approach	2
2.0	APPLICABLE DOCUMENTS	3
3.0	DESIGN REQUIREMENTS	4
3.1	System Functional Description	4
3.1.1	Hardware System Description	4
3.1.1.1	HAC Computer System	4
3.1.1.2	HFC Microprocessor	9
3.1.1.3	HC Microprocessor	9
3.1.1.4	Chromatics Intelligent Terminals	10
3.1.2	Software/Firmware System Description	10
3.1.2.1	HAC Software Description	10
3.1.2.1.1	Terminology	10
3.1.2.1.2	Operating Modes	11
3.1.2.1.3	Functional Overview	12
3.1.2.2	HFC Firmware Description	16
3.1.2.3	HC Firmware Description	16
3.1.2.4	Chromatics Intelligent Terminal (GDC) Software Description	17
3.2	HAC Software Design	17
3.2.1	Man-Machine Interface Module - (MANMIF)	18
3.2.1.1	Purpose	18
3.2.1.2	Requirements	18
3.2.1.2.1	Design Requirements	18
3.2.1.2.2	Derived Requirements	19
3.2.1.3	Design Approach	20
3.2.1.3.1	Functional Allocations	20
3.2.1.3.2	Resource Budgets	28
3.2.1.4	Design Description	28
3.2.1.4.1	Module Structure	28
3.2.1.4.1.1	Submodule I - MMI	32

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.1.4.1.2	Submodule II - MMIWRD	42
3.2.1.4.1.3	Submodule III - MMCHK	42
3.2.1.4.1.4	Submodule IV - MMINUM	44
3.2.1.4.1.5	Submodule V - MMIMAP	49
3.2.1.4.1.6	Submodule VI - MMIERR	52
3.2.1.4.1.7	Submodule VII - MMIRSP	56
3.2.1.4.1.8	Submodule VIII - MMIAID	59
3.2.1.4.1.9	Submodule IX - MMISTR	61
3.2.1.4.1.10	Submodule X - MMIREF	63
3.2.1.4.1.11	Submodule XI - DSK	65
3.2.1.4.1.12	Submodule XII - DSKAIM	67
3.2.1.4.1.13	Submodule XIII - DSKBIA	73
3.2.1.4.1.14	Submodule XIV - CFO	75
3.2.1.4.1.15	Submodule XV - CFOPOS	78
3.2.1.4.1.16	Submodule XVI - CFOGET	78
3.2.1.4.1.17	Submodule XVII - CFOMSG	80
3.2.1.5	Interface Description	85
3.2.1.6	Test Requirements	85
3.2.2	Command Processor Module (CMDPRC)	89
3.2.2.1	Purpose	89
3.2.2.2	Requirements	90
3.2.2.2.1	Design Requirements	90
3.2.2.2.2	Derived Requirements	90
3.2.2.3	Design Approach	91
3.2.2.3.1	Functional Allocations	93
3.2.2.3.1.1	Task Activations	94
3.2.2.3.1.2	Task Satisfaction of Derived Requirements	97
3.2.2.3.2	Resource Budgets	98
3.2.2.4	Design Description	99
3.2.2.4.1	Module Structure	99
3.2.2.4.1.1	Submodule I - CMD	101
3.2.2.4.1.2	Submodule II - CMDSCK	107
3.2.2.4.1.3	Submodule III - CMDFAD	113
3.2.2.4.1.4	Submodule IV - CMDBAD	122
3.2.2.4.1.5	Submodule V - CMDINO	128

TABLE OF CONTENTS (con't)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.2.4.1.6	Submodule VI - CMDARA	133
3.2.2.4.1.7	Submodule VII - CMDSAL	137
3.2.2.4.1.8	Submodule VIII - CMDTRK	145
3.2.2.4.1.9	Submodule IX - CMDDSK	151
3.2.2.4.1.10	Submodule X - CMDPOS	153
3.2.2.4.1.11	Submodule XI - CMDSBY	157
3.2.2.4.1.12	Submodule XII - CMDSDN	159
3.2.2.4.1.13	Submodule XIII - CMDBCS	162
3.2.2.4.1.14	Submodule XIV - CMDSUP	164
3.2.2.4.1.15	Submodule XV - GET	167
3.2.2.4.1.16	Submodule XVI - GETINI	169
3.2.2.4.1.17	Submodule XVII - GETAIM	173
3.2.2.4.1.18	Submodule XVIII - GETAL1	179
3.2.2.4.1.19	Submodule XIX - GETAL2	182
3.2.2.4.1.20	Submodule XX - GETWSH	184
3.2.2.4.1.21	Submodule XXI - GETSTO	187
3.2.2.4.1.22	Submodule XXII - GETSAR	192
3.2.2.4.1.23	Submodule XXIII - SEQ	196
3.2.2.4.1.24	Submodule XXIV - SEQGAT	203
3.2.2.4.1.25	Submodule XXV - SEQBPT	208
3.2.2.4.1.26	Submodule XXVI - SEQCCK	211
3.2.2.4.1.27	Submodule XXVII - SEQCOR	215
3.2.2.4.1.28	Submodule XXVIII - SEQADD	218
3.2.2.4.1.29	Submodule XXIX - SEQRLK	225
3.2.2.4.1.30	Submodule XXX - SEQDEL	227
3.2.2.4.1.31	Submodule XXXI - BHI	231
3.2.2.4.1.32	Submodule XXXII - BHISH5	234
3.2.2.4.1.33	Submodule XXXIII - BHC	234
3.2.2.5	Interface Description	238
3.2.2.6	Test Requirements	238
3.2.3	Sun Vector Module - SUNVEC	243
3.2.3.1	Purpose	243
3.2.3.2	Requirements	243
3.2.3.2.1	Design Requirements	243

TABLE OF CONTENTS (con't)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.3.2.2	Derived Requirements	243
3.2.3.3	Design Approach	243
3.2.3.3.1	Functional Allocations	243
3.2.3.3.2	Resource Budgets	245
3.2.3.4	Design Description	245
3.2.3.4.1	Module Structure	245
3.2.3.4.1.1	Submodule I - SUN (Main Routine)	246
3.2.3.4.1.2	Submodule II - SUNPOS	247
3.2.3.4.1.3	Submodule III - SUNDJ	251
3.2.3.4.1.4	Submodule IV - SUNCON	251
3.2.3.4.1.5	Submodule V - SUNPOL	255
3.2.3.4.1.6	Submodule VI - SUNDMA	257
3.2.3.5	Interface Description	259
3.2.3.6	Test Requirements	259
3.2.4	Field Communications Processor Module - FLDCOM	261
3.2.4.1	Purpose	261
3.2.4.2	Requirements	261
3.2.4.2.1	Design Requirements	261
3.2.4.2.2	Derived Requirements	262
3.2.4.3	Design Approach	262
3.2.4.3.1	Functional Allocations	266
3.2.4.3.2	Resource Budgets	267
3.2.4.4	Design Description	272
3.2.4.4.1	Module Structure	272
3.2.4.4.1.1	Submodule I - FCP	272
3.2.4.4.1.2	Submodule II - FCPOUT	275
3.2.4.4.1.3	Submodule III - FCPIN	278
3.2.4.4.1.4	Submodule IV - FCPCHO	281
3.2.4.4.1.5	Submodule V - FCPCHI	284
3.2.4.4.1.6	Submodule VI - FCPUPD	286
3.2.4.4.1.7	Submodule VII - FCPSWH	287
3.2.4.5	Interface Description	289
3.2.4.6	Test Requirements	292

TABLE OF CONTENTS (con't)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.5	Alarm Processor Module - ALARMS	293
3.2.5.1	Purpose	293
3.2.5.2	Requirements	293
3.2.5.2.1	Design Requirements	293
3.2.5.2.2	Derived Requirements	293
3.2.5.3	Design Approach	293
3.2.5.3.1	Functional Allocations	293
3.2.5.3.2	Resource Budgets	298
3.2.5.4	Design Description	299
3.2.5.4.1	Module Structure	299
3.2.5.4.1.1	Submodule I - ALM	301
3.2.5.4.1.2	Submodule II - ALMDTC	303
3.2.5.4.1.3	Submodule III - ALMFLD	305
3.2.5.4.1.4	Submodule IV - ALMLNE	307
3.2.5.4.1.5	Submodule V - ALMHFC	309
3.2.5.4.1.6	Submodule VI - ALMHC	311
3.2.5.4.1.7	Submodule VII - ALMGET	313
3.2.5.4.1.8	Submodule VIII - ALMCLT	319
3.2.5.4.1.9	Submodule IX - ALMRPT	320
3.2.5.4.1.10	Submodule X - ALMBLK	322
3.2.5.4.1.11	Submodule XI - ALMQUE	326
3.2.5.4.1.12	Submodule XII - ALO	329
3.2.5.4.1.13	Submodule XIII - ALOBLD	330
3.2.5.4.1.14	Submodule XIV - ALODQU	335
3.2.5.4.1.15	Submodule XV - ALOCVT	338
3.2.6	Status Display Module - STATUS	341
3.2.6.1	Purpose	341
3.2.6.2	Requirements	341
3.2.6.2.1	Design Requirements	341
3.2.6.2.2	Derived Requirements	341
3.2.6.3	Design Approach	343
3.2.6.3.1	Functional Allocations	343
3.2.6.3.2	Resource Budgets	346

TABLE OF CONTENTS (con't)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.6.4	Design Description	358
3.2.6.4.1	Module Structure	358
3.2.6.4.1.1	Submodule I - STS	358
3.2.6.4.1.2	Submodule II - STSGET	359
3.2.6.4.1.3	Submodule III - STA	362
3.2.6.4.1.4	Submodule IV - STAFLD	364
3.2.6.4.1.5	Submodule V - STAIND	364
3.2.6.4.1.6	Submodule VI - STAMOD	367
3.2.6.4.1.7	Submodule VII - STARNG	369
3.2.6.4.1.8	Submodule VIII - STAGET	371
3.2.6.5	Interface Description	373
3.2.6.6	Test Requirements	373
3.2.7	Data Base Initialization Module - DBINIT	375
3.2.7.1	Purpose	375
3.2.7.2	Requirements	375
3.2.7.2.1	Design Requirements	375
3.2.7.2.2	Derived Requirements	375
3.2.7.3	Design Approach	376
3.2.7.3.1	Functional Allocations	383
3.2.7.3.2	Resource Budgets	394
3.2.7.4	Design Description	395
3.2.7.4.1	Module Structure	395
3.2.7.4.1.1	Submodule I - Task DIN	395
3.2.7.4.1.2	Submodule II - DINLOC	406
3.2.7.4.1.3	Submodule III - DINTRF	425
3.2.7.4.1.4	Submodule IV - DININC	426
3.2.7.4.1.5	Submodule V - DINSRT	431
3.2.7.4.1.6	Submodule VI - DINTTL	432
3.2.7.4.1.7	Submodule VII - DINANG	435
3.2.7.4.1.8	Submodule VIII - DINPAC	439
3.2.7.4.1.9	Submodule IX - DINFLG	443
3.2.7.4.1.11	Submodule XI - DBI (Task)	446
3.2.7.4.1.12	Submodule XII - DBIFAC	448

TABLE OF CONTENTS (con't)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.7.4.1.13	Submodule XIII - DBICRT	450
3.2.7.4.1.14	Submodule XIV - DBIGRF	453
3.2.7.4.1.15	Submodule XV - DBITRP	456
3.2.7.4.1.16	Submodule XVI - DBIDTA	459
3.2.7.4.1.17	Submodule XVII - DBIDSK	462
3.2.7.4.1.18	Submodule XVIII - DBICOR	465
3.2.7.4.1.19	Submodule XIX - DBIAIM	469
3.2.7.4.1.20	Submodule XX - DBIBCK	473
3.2.7.4.1.21	Submodule XXI - DBIERR	477
3.2.7.4.1.22	Submodule XXII - CLK (Task)	482
3.2.7.4.1.23	Submodule XXIII - CLKEST	483
3.2.7.4.1.24	Submodule XXIV - CLKONL	485
3.2.7.4.1.25	Submodule XXV - CLKACT	488
3.2.7.5	Interface Description	492
3.2.7.6	Test Requirements	492
3.2.8	Operating System Modifications Module - MAXIVM	494
3.2.8.1	Buffer Management Function	494
3.2.8.1.1	Purpose	494
3.2.8.1.2	Requirements	494
3.2.8.1.2.1	Design Requirements	494
3.2.8.1.2.2	Derived Requirements	495
3.2.8.1.3	Design Approach	495
3.2.8.1.3.1	Functional Allocations	495
3.2.8.1.3.2	Resource Budgets	495
3.2.8.1.4	Design Description	495
3.2.8.1.4.1	Module Structure	495
3.2.8.1.4.1.1	Submodule I - QINIT	495
3.2.8.1.4.1.2	Submodule II - LEASE	496
3.2.8.1.4.1.3	Submodule III - FREE	499
3.2.8.1.4.1.4	Submodule IV - ENQUE	499
3.2.8.1.4.1.5	Submodule V - DEQUE	502
3.2.8.1.4.1.6	Submodule VI - QRST	505
3.2.8.1.4.1.7	Submodule VII - BMFIF	507

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.8.1.5	Interface Description	507
3.2.8.1.6	Test Requirements	511
3.2.8.2	"Clock" Function	518
3.2.8.2.1	Purpose	518
3.2.8.2.2	Requirements	518
3.2.8.2.2.1	Design Requirements	518
3.2.8.2.2.2	Derived Requirements	518
3.2.8.2.3	Design Approach	519
3.2.8.2.3.1	Functional Allocations	519
3.2.8.2.3.2	Resource Budgets	519
3.2.8.2.4	Design Description	519
3.2.8.2.4.1	Module Structure	519
3.2.8.2.4.1.1	TOK - Major Interval Timer	519
3.2.8.2.4.1.2	TIK - Minor Interval Timer	523
3.2.8.2.5	Interface Description	523
3.2.8.2.6	Test Requirements	527
3.2.8.3	Receiver Trip	527
3.2.8.3.1	Purpose	527
3.2.8.3.2	Requirements	527
3.2.8.3.2.1	Design Requirements	527
3.2.8.3.2.2	Derived Requirements	527
3.2.8.3.3	Design Approach	527
3.2.8.3.3.1	Functional Allocations	528
3.2.8.3.3.2	Resource Budgets	528
3.2.8.3.4	Design Description	528
3.2.8.3.4.1	Module Structure	528
3.2.8.3.4.1.1	Submodule I - RTH	528
3.2.8.3.4.1.2	Submodule II - RTL	529
3.2.8.3.5	Interface Description	531
3.2.8.3.6	Test Requirements	533
3.2.8.4	Switching Function	534
3.2.8.4.1	Purpose	534

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.8.4.2	Requirements	534
3.2.8.4.2.1	Design Requirements	534
3.2.8.4.2.2	Derived Requirements	534
3.2.8.4.3	Design Approach	534
3.2.8.4.3.1	Functional Allocations	534
3.2.8.4.3.2	Resource Budgets	535
3.2.8.4.4	Design Description	535
3.2.8.4.4.1	Module Structure	535
3.2.8.4.4.1.1	Submodule I - SWI (Task)	535
3.2.8.4.4.1.2	Submodule II - SWIRGD	537
3.2.8.4.4.1.3	Submodule III - SWIINT	539
3.2.8.4.4.1.4	Failover Interrupt Handler	541
3.2.8.4.5	Interface Description	544
3.2.8.4.6	Test Requirements	544
3.2.8.5	Field Power Loss	544
3.2.8.5.1	Purpose	545
3.2.8.5.2	Requirements	545
3.2.8.5.2.1	Design Requirements	545
3.2.8.5.2.2	Derived Requirements	545
3.2.8.5.3	Design Approach	545
3.2.8.5.3.1	Functional Allocations	545
3.2.8.5.3.2	Resource Budgets	546
3.2.8.5.4	Design Description	546
3.2.8.5.4.1	Module Structure	546
3.2.8.5.4.1.1	Submodule I - PLH	546
3.2.8.5.4.1.2	Submodule II - PLL	547
3.2.8.5.5	Interface Description	549
3.2.8.5.6	Test Requirements	549
3.2.9	Graphics Display Processor Module - (GRAPHIC)	551
3.2.9.1	Purpose	551
3.2.9.2	Requirements	551
3.2.9.2.1	Design Requirements	551
3.2.9.2.2	Derived Requirements	551

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.9.3	Design Approach	552
3.2.9.3.1	Functional Allocations	552
3.2.9.3.2	Resource Budgets	563
3.2.9.4.1.1	Submodule I - GRF (Task)	563
3.2.9.4.1.2	Submodule II - GRFSEG	567
3.2.9.4.1.3	Submodule III - GRFFLD	572
3.2.9.5	Interface Description	574
3.2.9.6	Test Requirements	574
3.2.10	External Interface Module - EXTINF	576
3.2.10.1	Purpose	576
3.2.10.2	Requirements	576
3.2.10.2.1	Design Requirements	576
3.2.10.2.2	Derived Requirements	576
3.2.10.3	Design Approach	577
3.2.10.3.1	Functional Allocations	577
3.2.10.3.2	Resource Budgets	579
3.2.10.4	Design Description	579
3.2.10.4.1	Module Structure	579
3.2.10.4.1.1	Submodule I - CSI Task (Main Routine)	579
3.2.10.4.1.2	Submodule II - CSO Task	581
3.2.10.4.1.3	Submodule III - EXI Task	584
3.2.10.5	Interface Description	587
3.2.10.6	Test Requirements	591
3.2.11	BCS Automatic Processing Module - BCSMOD	592
3.2.11.1	Purpose	592
3.2.11.2	Requirements	592
3.2.11.2.1	Design Requirements	592
3.2.11.2.2	Derived Requirements	593
3.2.11.3	Design Approach	594
3.2.11.3.1	Functional Allocations	599
3.2.11.3.2	Resource Budgets	602
3.2.11.4	Design Description	603
3.2.11.4.1	Module Structure	603
3.2.11.4.1.1	Submodule I - BCS Task	603

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.2.11.4.1.2	Submodule II - BCSMES	607
3.2.11.4.1.3	Submodule III - BCSOC	611
3.2.11.4.1.4	Submodule IV - BCSLSQ	612
3.2.11.4.1.5	Submodule V - BCSOCS	616
3.2.11.4.1.6	Submodule VI - BCSSEQ	619
3.2.11.4.1.7	Submodule VII - BCSCON	625
3.2.11.4.1.8	Submodule VIII - BCSLOG	630
3.2.11.4.1.9	Submodule IX - BCSCRT	632
3.2.11.4.1.10	Submodule X - BCSTMT	636
3.2.11.4.1.11	Submodule XI - BCSDIS	638
3.2.11.4.1.12	Submodule XII - BCSRNG	640
3.2.11.4.1.13	Submodule XIII - BCSGO	642
3.2.11.4.1.14	Submodule XIV - BCSTOFF	646
3.2.11.4.1.15	Submodule XV - BCSCAL	647
3.2.11.4.1.16	Submodule XVI - BCSBIA	649
3.2.11.4.1.17	Submodule XVII - BCSDSK	651
3.2.11.4.1.18	Submodule XVIII - BCSCOR	655
3.2.11.4.1.19	Submodule XIX - BCSGIM	656
3.2.11.4.1.20	Submodule XX - BCSLIN	658
3.2.11.4.1.21	Submodule XXI - BCSLSC	660
3.2.11.4.1.22	Submodule XXII - BCSSUN	662
3.2.11.4.1.23	Submodule XXIII - BCSNOR	664
3.2.11.4.1.24	Submodule XXIV - BCSEPD	666
3.2.11.4.1.25	Submodule XXV - BCSVEC	668
3.2.11.4.1.26	Submodule XXVI - BCSAL2	670
3.2.11.5	Interface Description	674
3.2.11.6	Test Requirements	674
3.3.1	Data Base Design	677
3.3.1.1	Purpose	677
3.3.1.2	Requirements	677
3.3.1.2.1	Design Requirements	678
3.3.1.2.2	Derived Requirements	679
3.3.1.3	Design Approach	684

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.3.1.3.1	Functional Allocations	684
3.3.1.3.2	Resource Budgets	685
3.3.1.4	Design Description	685
3.3.1.4.1	Structure	685
3.3.1.4.1.1	Global Common Area COM1S1	685
3.3.1.4.1.2	Global Common Area COM1S2	686
3.3.1.4.1.3	Global Common Area COM1S3	687
3.3.1.4.1.4	Global Common Area COM1S4	688
3.3.1.4.1.5	Global Common Area COM1S5	691
3.3.1.4.1.6	Global Common Area COM1S6	697
3.3.1.4.1.7	Global Common Area COM8S1	698
3.3.1.4.1.8	Global Common Area COM8S2	699
3.3.1.4.1.9	Global Common Area COM8S3	700
3.3.1.4.1.10	Global Common Area COM8S4	701
3.3.1.4.1.11	Global Common Area COMIN1	701
3.3.1.4.1.12	Global Common Area COMIN2	702
3.3.1.4.1.13	Global Common Area COMIN3	702
3.3.1.4.1.14	Global Common Area COMIN4	705
3.3.1.4.1.15	Free Storage (COMQUE)	709
3.3.1.4.1.16	Free Storage (COMQU2)	710
3.3.1.4.1.17	Disk Data Base	710
3.3.1.5	Interface Description	713
3.3.1.6	Test Requirements	724
3.4	HFC Firmware Design	732

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.4.1	HFC Firmware Module - HFCMOD	732
3.4.1.1	Purpose	732
3.4.1.2	Requirements	732
3.4.1.2.1	Design Requirements	732
3.4.1.2.2	Derived Requirements	733
3.4.1.3	Design Approach	733
3.4.1.3.1	Functional Allocations	733
3.4.1.3.2	Resource Budgets	734
3.4.1.4	Design Description	734
3.4.1.4.1	Module Structure	734
3.4.1.4.2	Submodule I - Command Interpreter (CMDI)	736
3.4.1.4.2.2	CMDI Subroutine I - CMDCMD	737
3.4.1.4.2.3	CMDI Subroutine II - CMDINI	742
3.4.1.4.2.4	CMDI Subroutine III - CMDS4	742
3.4.1.4.2.5	CMDI Subroutine IV - POL1HC	745
3.4.1.4.3	Submodule II - Corridor-Walk Calculation (CWCALC)	745
3.4.1.4.3.1	Main Routine	745
3.4.1.4.4	Submodule III - HC Operations (HCOPS)	748
3.4.1.4.4.1	Main Routine	748
3.4.1.4.4.2	HCOPS Subroutine I - HCOSSC	751
3.4.1.4.4.3	HCOPS Subroutine II - HCOCRR	751
3.4.1.4.4.4	HCOPS Subroutine III - HCOPOL	751
3.4.1.4.5	Submodule IV - Emergency Corridor-Walk Operations (ECWOPS)	755
3.4.1.4.5.1	Main Routine	755
3.4.1.4.5.2	ECWOPS Subroutine I - ECWMG	757

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.4.1.4.5.3	ECWOPS Subroutine II - ECWSEQ	759
3.4.1.4.6	Submodule V - HFC Timer Interrupt Handlers (HFCTMR)	763
3.4.1.4.6.1	Main Routine	763
3.4.1.4.6.2	HFCTMR Subroutine I - HFCTOC	765
3.4.1.4.6.3	HFCTMR Subroutine II - HFCTOF	765
3.4.1.4.7	Submodule VI - HAC Input Interrupt Handler (HACIN)	767
3.4.1.4.7.1	Main Routine	767
3.4.1.4.8	Submodule VII - HAC Output Interrupt Handler (HACOUT)	771
3.4.1.4.8.1	Main Routine	771
3.4.1.4.9	Submodule VIII - HC Input Interrupt Handler (HCIN)	771
3.4.1.4.9.1	Main Routine	771
3.4.1.4.10	Submodule IX - HC Output Interrupt Handler (HCOUT)	773
3.4.1.4.10.1	Main Routine	773
3.5	HC Firmware Design	777
3.5.1	HC Firmware Module - HCMOD	777
3.5.1.1	Purpose	777
3.5.1.2	Requirements	777
3.5.1.2.1	Design Requirements	777
3.5.1.2.2	Derived Requirements	777
3.5.1.3	Design Approach	778
3.5.1.3.1	Functional Allocations	778
3.5.1.3.2	Resource Budgets	786
3.5.1.3.2.1	Submodule Priority	786
3.5.1.3.3	Operating System Variables	786
3.5.1.4	Design Description	786
3.5.1.4.1	Module Structure	795
3.5.1.5	Interface Description	798
3.5.1.6	Test Requirements	798
3.6	Graphic Display Console (GDC) Software	799
3.6.1	Purpose	799
3.6.2	Requirements	799
3.6.2.1	Design Requirements	799

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.6.2.2	Derived Requirements	804
3.6.3	Design Approach	804
3.6.3.1	Functional Allocations	804
3.6.3.2	Resource Budgets	805
3.6.4	Design Description	806
3.6.4.1	Module Structure	806
3.6.4.1.1	Submodule I - EXEC (Main Routine)	806
3.6.4.1.2	Submodule II - RCV	808
3.6.4.1.2.1	Subroutine 1 - RCVISR	808
3.6.4.1.2.2	Subroutine 2 - HACAVAIL	810
3.6.4.1.2.3	Subroutine 3 - HACDATA	810
3.6.4.1.3	Submodule III - KBD	810
3.6.4.1.3.1	Subroutine 1 - KBDISR	814
3.6.4.1.3.2	Subroutine 2 - KBDVAAIL	814
3.6.4.1.3.3	Subroutine 3 - KBDDATA	816
3.6.4.1.4	Submodule IV - SEND (Main Routine)	816
3.6.4.1.5	Submodule V - DIALOG	820
3.6.4.1.6	Submodule VI - FFDISP	821
3.6.4.1.6.1	Subroutine 1 - FFDISPI (Full-Field Display Initialization)	821
3.6.4.1.6.2	Subroutine 2 - FFDISPU (Full-Field Display Update)	823
3.6.4.1.6.3	Subroutine 3 - FFDISPD (Full-Field Display Delete)	826
3.6.4.1.7	Submodule VII - SEGDISP	826
3.6.4.1.7.1	Subroutine 1 - SEGDISPI (Segment Display Initialization)	826
3.6.4.1.7.2	Subroutine 2 - SEGIDSPU (Segment Display Update)	828
3.6.4.1.7.3	Subroutine 3 - SEGDISPD (Segment Display Delete)	831
3.6.4.1.8	Submodule VIII - HELP	831
3.6.4.1.8.1	Subroutine 1 - HELPI (Initialize HELP Display)	831
3.6.4.1.8.2	Subroutine 2 - HELPD (Delete HELP Display)	833
3.6.4.1.9	Submodule IX - PROHAC	833
3.6.4.1.10	Submodule X - FFPREP	833
3.6.4.1.11	Submodule XI - SEGPREP	838

TABLE OF CONTENTS (con't.)

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.7	System Interfaces	841
3.7.1	HAC/HFC Interface Description	841
3.7.2	HFC/HC Interface Description	841
3.7.3	HAC/OCS-DAS Interface Description	841
3.7.4	HAC/GDC Interface Description	841
3.7.5	HAC/Receiver Interface Description	842
3.7.6	Man-Machine Interface Description	842
3.7.6.1	Command Input Mode	842
3.7.6.2	Command File Execute Mode	842
3.7.6.3	Command Logging Mode	842
3.7.6.4	Alarm Response Mode	843
3.7.6.5	Status Display Mode	843
4.0	SOFTWARE/FIRMWARE SYSTEM VALIDATION	907
4.1	Test Phases	907
4.2	Functional Testing	907
4.3	Integration Testing	907
4.4	Breadboard Integration Testing	908
4.5	System Level Testing	908
5.0	ACRONYMS	909

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.1-1	"Prime"	5
3.1-2	"Backup"	6
3.1-3	HAC Computer System Hardware Configuration	7
3.1-4	HAC Task Activation Flow	13
3.2.1-1	MANMIF Hierarchical Overview	29
3.2.1-1a	MMI Functional Overview	30
3.2.1-1b	DSK and CFO Functional Overview	31
3.2.1-2	Flowchart - MMI	37
3.2.1-3	Flowchart - MMIWRD	43
3.2.1-4	Flowchart - MMCHK	46
3.2.1-5	Flowchart - MMINUM	50
3.2.1-6	Flowchart - MMIMAP	53
3.2.1-7	Flowchart - MMIERR	57
3.2.1-8	Flowchart - MMIRSP	60
3.2.1-9	Flowchart - MMIAID	62
3.2.1-10	Flowchart - MMISTR	64
3.2.1-11	Flowchart - MMIREF	66
3.2.1-12	Flowchart - DSK	68
3.2.1-13	Flowchart - DSKAIM	70
3.2.1-14	Flowchart - DSKBIA	74
3.2.1-15	Flowchart - CFO	77
3.2.1-16	Flowchart - CFOPOS	79
3.2.1-17	Flowchart - CFOGET	81
3.2.1-18	Flowchart - CFOMSG	83
3.2.2-1	Hierarchy Diagram for the Command Processor Module (CMDPRC)	95
3.2.2-2	Module CMDPRC Overview	96
3.2.2-3	CMD Hierarchy	100
3.2.2-4	Task GET Hierarchy	102
3.2.2-5	Task SEQ Hierarchy	103
3.2.2-6	Tasks BHI, BHC Hierarchy	104
3.2.2-7	Flowchart - CMD	108
3.2.2-8	Flowchart - CMDSCK	114
3.2.2-9	CMDSCK Input/Output Buffers	119
3.2.2-10	Flowchart - CMDFAD	120
3.2.2-11	Flowchart - C MDBAD	129
3.2.2-12	Flowchart - CMDINO	134

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.2-13	Flowchart - CMDARA	138
3.2.2-14	Flowchart - CMDSAL	146
3.2.2-15	Flowchart - CMDTRK	152
3.2.2-16	Flowchart - CMDDSK	155
3.2.2-17	Flowchart - CMDPOS	158
3.2.2-18	Flowchart - CMDSBY	160
3.2.2-19	Flowchart - CMDSDN	163
3.2.2-20	Flowchart - CMDBCS	165
3.2.2-21	Flowchart - CMDSUP	168
3.2.2-22	Flowchart - GET	170
3.2.2-23	HC Bias File (HCB)	174
3.2.2-24	HC Coordinates (HCC)	175
3.2.2-25	Flowchart - GETINI	176
3.2.2-26	Aim-Point Arrays File (AIM)	178
3.2.2-27	Flowchart - GETAIM	180
3.2.2-28	Format and Structure of HC ALT1STOW Angles Disk File	181
3.2.2-29	Flowchart - GETAL1	183
3.2.2-30	Format and Structure of ALT2STOW Angle Disk File	185
3.2.2-31	Flowchart - GETAL2	186
3.2.2-32	Format and Structure of Wash Angles File (WSH)	188
3.2.2-33	Flowchart - GETWSH	189
3.2.2-34	Format and Structure of HC Stow Angles Disk File	191
3.2.2-35	Flowchart - GETSTO	193
3.2.2-36	Tracking Configuration Save File (AIM)	197
3.2.2-37	Flowchart - GETSAR	198
3.2.2-38	Wait-Sequence List (WAITSQ)	201
3.2.2-39	Flowchart - SEQ	206
3.2.2-40	Flowchart - SEQGAT	209
3.2.2-41	Flowchart - SEQBPT	212
3.2.2-42	Flowchart - SEQCCK	216
3.2.2-43	Flowchart - SEQCOR	219
3.2.2-44	Example of ACTLIS Management	222
3.2.2-45	Flowchart - SEQADD	226

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.2-46	Flowchart - SEQRLK	228
3.2.2-47	Flowchart - SEQDEL	232
3.2.2-48	Flowchart - BHI	235
3.2.2-49	Flowchart - BHISH5	236
3.2.2-50	Flowchart - BHC	239
3.2.3-1	SUNVEC Module	244
3.2.3-2	Flowchart - SUN	248
3.2.3-3	Flowchart - SUNPOS	252
3.2.3-4	Flowchart - SUNDJ	254
3.2.3-5	Flowchart - SUNCON	256
3.2.3-6	Flowchart - SUNPOL	258
3.2.3-7	Flowchart - SUNDMA	260
3.2.4-1	Flowchart - FCP Functional Overview	268
3.2.4-2	FLDCOM One-Second Communications Time Frame	269
3.2.4-3	FLDCOM Module	273
3.2.4-4	Flowchart - FCP Task	276
3.2.4-5	Flowchart - FCPOUT	279
3.2.4-6	Flowchart - FCPIN	282
3.2.4-7	Flowchart - FCPCHO	285
3.2.4-8	Flowchart - FCPCHI	288
3.2.4-9	Flowchart - FCPUPD	288
3.2.4-10	Flowchart - FCPSWH	290
3.2.5-1	Alarms Processing Overview	294
3.2.5-2	Alarms Status Levels and Related Tables	296
3.2.5-3	Alarms Module Structure	300
3.2.5-4	Flowchart - ALM	304
3.2.5-5	Flowchart - ALMDTC	306
3.2.5-6	Flowchart - ALMFLD	308
3.2.5-7	Flowchart - ALMLNE	310
3.2.5-8	Flowchart - ALMHFC	312
3.2.5-9	Flowchart - ALMHC	314
3.2.5-10	Flowchart - ALMGET	318
3.2.5-11	Flowchart - ALMCLT	321

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.5-12	Flowchart - ALMRPT	323
3.2.5-13	Flowchart - ALMBLK	325
3.2.5-14	Flowchart - ALMQUE	328
3.2.5-15	Flowchart - ALO	331
3.2.5-16	Flowchart - ALOBLD	336
3.2.5-17	Flowchart - ALODQU	339
3.2.5-18	Flowchart - ALOCVT	340
3.2.6-1	STATUS Module Structure	344
3.2.6-2	HAC Operator's Console Synchronous Status Display	345
3.2.6-3	STAFLD - Field Status Display	348
3.2.6-4	STAIND Display Format	351
3.2.6-5	STAMOD Display Format	355
3.2.6-6	STARNG Segment Track Status	356
3.2.6-7	Flowchart - STS	360
3.2.6-8	Flowchart - STSGET	363
3.2.6-9	Flowchart - STA	365
3.2.6-10	Flowchart - STAFLD	366
3.2.6-11	Flowchart - STAIND	368
3.2.6-12	Flowchart - STAMOD	370
3.2.6-13	Flowchart - STARNG	372
3.2.6-14	Flowchart - STAGET	374
3.2.7-1	Hierarchy Diagram of the Data Base Initialization Module (DBINIT)	377
3.2.7-2	Functional Diagram of the Disk Initialization Task	378
3.2.7-3	Functional Allocation of the HAC Initialization Task	379
3.2.7-4	Functional Diagram of the System Interface Initialization Submodule	380
3.2.7-5	Functional Diagram of the Data Initialization Control Submodule	381
3.2.7-6	Functional Diagram of the HAC Start-Up Task	382
3.2.7-7	HC Numbering Scheme Mappings	403
3.2.7-8	Segment Map and Segment Pointer Interaction	405
3.2.7-9	Flowchart - DIN	407
3.2.7-10	Flowchart - DINLOC	418

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.7-11	Flowchart - DINTRF	427
3.2.7-12	Inclusion-Area Check Diagram	429
3.2.7-13	Flowchart - DININC	430
3.2.7-14	Flowchart - DINSRT	433
3.2.7-15	Flowchart - DINTTL	436
3.2.7-16	Flowchart - DINANG	440
3.2.7-17	Flowchart - DINPAC	444
3.2.7-18	Flowchart - DINFLG	447
3.2.7-19	Flowchart - DBI	449
3.2.7-20	Flowchart - DBIFAC	451
3.2.7-21	Flowchart - DBICRT	454
3.2.7-22	Flowchart - DBIGRF	457
3.2.7-23	Flowchart - DBITRP	460
3.2.7-24	Flowchart - DBIDTA	463
3.2.7-25	Flowchart - DBIDSK	466
3.2.7-26	Flowchart - DBICOR	470
3.2.7-27	Flowchart - DBIAIM	474
3.2.7-28	Flowchart - DBIBCK	478
3.2.7-29	Flowchart - DBIERR	481
3.2.7-30	Flowchart - CLK	484
3.2.7-31	Flowchart - CLKEST	486
3.2.7-32	Flowchart - Computation of Local Time	489
3.2.7-33	Flowchart - Computation of GMT Parameters	490
3.2.7-34	Flowchart - CLKONL	491
3.2.7-35	Flowchart - CLKACT	493
3.2.8.1-1	Internal Buffer Structure	497
3.2.8.1-2	Flowchart - QINIT	498
3.2.8.1-3	Flowchart - LEASE	500
3.2.8.1-4	Flowchart - FREE	501
3.2.8.1-5	Message Structure	503
3.2.8.1-6	Flowchart - ENQUE	504
3.2.8.1-7	Flowchart - DEQUE	506

LIST OF FIGURES (cont't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.8.1-8	Flowchart - QRST	508
3.2.8.1-9	Flowchart - BMFIF	509
3.2.8.1-10	Interface Specification for QINIT	510
3.2.8.1-11	Interface Specification for LEASE	512
3.2.8.1-12	Interface Specification for FREE	513
3.2.8.1-13	Interface Specification for ENQUE	514
3.2.8.1-14	Interface Specification for DEQUE	515
3.2.8.1-15	Interface Specification for QRST	516
3.2.8.1-16	Interface Specification for BMFIF	517
3.2.8.2-1	Clock Module, Component Task Interaction	520
3.2.8.2-2	Flowchart - TOK	524
3.2.8.2-3	Flowchart - TIK	525
3.2.8.3-1	Flowchart - RTH	530
3.2.8.3-2	Flowchart - RTL	532
3.2.8.4-1	Flowchart - SWI	538
3.2.8.4.2	Flowchart - SWIRGD	540
3.2.8.4.3	Flowchart - SWIINT	542
3.2.8.4-4	Flowchart - Failover Interrupt Handler	543
3.2.8.5.1	Flowchart - PLH	548
3.2.8.5.2	Flowchart - PLL	550
3.2.9-1	GRAPHIC Functional Interface Diagram	553
3.2.9-2	Functional Allocation of the GRF Task	558
3.2.9-3	Flowchart - GRF	568
3.2.9-4	Flowchart - GRFSEG	573
3.2.9-5	Flowchart - GRFFLD	575
3.2.10-1	External Interface Module	578
3.2.10-2	Flowchart - CSI	582
3.2.10-3	Flowchart - CSO	585
3.2.10-4	Flowchart - EXI	588
3.2.11-1	BCS Submodule Diagram	600
3.2.11-2	Flowchart - BCS	608
3.2.11-3	Flowchart - BCSMES	610
3.2.11-4	Flowchart - BCSOC	613

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.2.11-5	Flowchart - BCSLSQ	617
3.2.11-6	Flowchart - BCSOCS	620
3.2.11-7	Flowchart - BCSSEQ	626
3.2.11-8	Flowchart - BCSCON	631
3.2.11-9	Flowchart - BCSLOG	633
3.2.11-10	Flowchart - BCSCRT	637
3.2.11-11	Flowchart - BCSTMT	639
3.2.11-12	Flowchart - BCSDIS	641
3.2.11-13	Flowchart - BCSRNG	643
3.2.11-14	Flowchart - BCSGO	645
3.2.11-15	Flowchart - BCSEFF	648
3.2.11-16	Flowchart - BCSCAL	650
3.2.11-17	Flowchart - BCSBIA	652
3.2.11-18	Flowchart - BCSDSK	654
3.2.11-19	Flowchart - BCSCOR	657
3.2.11-20	Flowchart - BCSGIM	659
3.2.11-21	Flowchart - BCSLIN	661
3.2.11-22	Flowchart - BCSLSC	663
3.2.11-23	Flowchart - BCSSUN	665
3.2.11-24	Flowchart - BCSNOR	667
3.2.11-25	Flowchart - BCSEPD	669
3.2.11-26	Flowchart - BCSVEC	671
3.2.11-27	Flowchart - BCSAL2	673
3.2.11-28	CS-BCS Operational & Message Flow Diagram	675
3.2.11-29	BCS Interfaces Within HAC	676
3.3.1.4-1	Format and Structure of the Aim-Point File (AIM)	711
3.3.1.4-2	Format and Structure of the HC ALT1STOW Angles Disk File (AL1)	712
3.3.1.4-3	Format and Structure of ALT2STOW Angles Disk File (AL2)	714
3.3.1.4-4	Format and Structure of File DIN	715
3.3.1.4-5	Format and Structure of the HC Locations Disk File (HCC)	717
3.3.1.4-6	Format and Structure of the Bias Disk File (HCB)	718
3.3.1.4-7	Alarm Messages Stored in File SAM/DBI	719

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.3.1.4-8	Tracking Configuration Save File (AIM)	720
3.3.1.4-9	Format and Structure of HC Stow Angles Disk File (STO)	721
3.3.1.4-10	Format and Structure of the Wash Angles Disk File (WSH)	722
3.4.1-1	HFC Module Structure	735
3.4.1-2	Flowchart - CMDI	739
3.4.1-3	Flowchart - NRMHI	741
3.4.1-4	Flowchart - CMDCMD	743
3.4.1-5	Flowchart - CMDINI	744
3.4.1-6	Flowchart - CMDS4	746
3.4.1-7	Flowchart - POL1HC	747
3.4.1-8	Flowchart - CWCALC	749
3.4.1-9	Flowchart - CKDELTAB	750
3.4.1-10	Flowchart - HCOPS	752
3.4.1-11	Flowchart - HCOSSC	753
3.4.1-12	Flowchart - HCOCRR	754
3.4.1-13	Flowchart - HCOPOL	756
3.4.1-14	Flowchart - ECWOPS	758
3.4.1-15	Flowchart - ECWMG	760
3.4.1-16	Flowchart - MG1HC	761
3.4.1-17	Flowchart - ECWSEQ	764
3.4.1-18	Flowchart - HFCTOC	766
3.4.1-19	Flowchart - HFCTOF	768
3.4.1-20	Flowchart - HACIN	769
3.4.1-21	Flowchart - HACIND	770
3.4.1-22	Flowchart - HACOUT	772
3.4.1-23	Flowchart - HCIN	774
3.4.1-24	Flowchart - HCIND	775
3.4.1-25	Flowchart - HCOUT	776
3.5.1-1	HC System Memory Map	779
3.5.1-2	Flowchart - INIT	780
3.5.1-3	Flowchart - SYSCLK	781
3.5.1-4	Flowchart - DECODE	782

LIST OF FIGURES (con't)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.5.1-5	Flowchart - POINT	783
3.5.1-6	Flowchart - READE	784
3.5.1-7	Flowchart - AZMOTR, ELMOTR, POWER	785
3.5.1-8	Flowchart - SCIO	787
3.5.1-9	Flowchart - CALC	788
3.5.1-10	Flowchart - System Block Diagram	796
3.5.1-11	System State Diagram	797
3.6.2-1	Full Field Display	800
3.6.2-2	3 X 5 Symbol/Color Encoding for Full-Field Display	801
3.6.2-3	Segment Display	802
3.6.2-4	5 X 10 Symbol/Color Encoding For Segment Displays	803
3.6.4-1	GDC Module Structure	807
3.6.4-2	Flowchart - EXEC	809
3.6.4-3	Flowchart - RCVISR	811
3.6.4-4	Flowchart - HACAVAIL	812
3.6.4-5	Flowchart - HACDATA	813
3.6.4-6	Flowchart - KBDISR	815
3.6.4-7	Flowchart - KBDVAAIL	817
3.6.4-8	Flowchart - KBDDATA	818
3.6.4-9	Flowchart - SEND	819
3.6.4-10	Flowchart - DIALOG	822
3.6.4-11	Flowchart - FFDISPI	824
3.6.4-12	Flowchart - FFDISPU	825
3.6.4-13	Flowchart - FFDISPD	827
3.6.4-14	Flowchart - SEGDISPI	829
3.6.4-15	Flowchart - SEGDISPU	830
3.6.4-16	Flowchart - SEGDISPD	832
3.6.4-19	Flowchart - PROHAC	834
3.6.4-20	Flowchart - FFPREP	837
3.6.4-21	Flowchart - SEGPREP	840
3.7-1	FLDCOM One-Second Communications Time Frame	844

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3.1-I	HAC Computer Hardware Acronyms and Model Numbers	8
3.2.1-I	Collector Subsystem Command List	21
3.2.1-II	Collector Subsystem Command Addressing Format	26
3.2.1-III	MANMIF Errors	35
3.2.1-IV	Description of ARGADD	45
3.2.1-V	OCS/DAS-HAC Commands Format	86
3.2.1-VI	HAC-OCS/DAS Environment Format	87
3.2.2-I	CMD Error Return Codes and Resulting MMI Display Messages	106
3.2.2-II	Operational Commands and Their Valid Initial Orientations	109
3.2.2-III	MMI/CMD HC Block Buffer	123
3.2.2-IV	MMI/CMD Command Buffer	126
3.2.2-V	Sequence Data Packet	140
3.2.2-VI	Disk Data Packet Format	154
3.2.2-VII	Typical Cell in Active-Sequence List (ACTLIS)	220
3.2.5-I	ALARM Tables in Memory	316
3.2.5-II	ALARM Detection Tables	317
3.2.5-III	Compressed Message Format	327
3.2.5-IV	ASCII Alarm Formats	333
3.2.6-I	Heliostat Mode Definitions	342
3.2.6-II	10 MWe Status (STSGET)	347
3.2.6-III	HAC-OCS/DAS Environment Status (Field) Format	349
3.2.6-IV	HAC-OCS/DAS Environment Status (HC) Format	352
3.2.6-V	HAC-OCS/DAS Environment Status (Mode) Format	354
3.2.6-VI	HAC-OCS/DAS Environment Status (Ring) Format	357
3.2.7-I	Data Base Card Format - Card Type 1	384
3.2.7-II	Data Base Card Format - Card Type 2	385
3.2.7-III	Data Base Card Format - Card Type 3	386
3.2.7-IV	Data Base Card Format - Card Type 4	387
3.2.7-V	Data Base Card Format - Card Type 5	388
3.2.7-VI	Data Base Card Format - Card Type 6	389
3.2.7-VII	Source Data Error Handling Procedure	390

LIST OF TABLES (con't)

<u>Table</u>	<u>Title</u>	<u>Page</u>
3.2.7-VIII	Error Messages	480
3.2.9-I	GDC-HAC GDC Command	554
3.2.9-II	GDC-HAC GDC Command	555
3.2.9-III	GDC-HAC GDC Command	556
3.2.9-IV	GDC-HAC GDC Command	557
3.2.9-V	HAC-GDC Text Message to GDC	559
3.2.9-VI	HAC-GDC Graphics Initialization	560
3.2.9-VII	HAC-GDC Full Field Status	562
3.2.9-VIII	HAC-GDC HAC Segment Status	564
3.2.11-I	BCS Task Command Description	595
3.2.11-II	BCS Messages	609
3.3.1-I	Task Utilization of Global Common COMDAT	723
3.3.1-II	Global Common to Task Assignments	729
3.3.1-III	Task Utilization of Message Queue Global Common COMQUE	730
3.3.1-IV	Task Utilization of Data Base Disk Files	731
3.4.1-I	HFC State Transition Matrix	738
3.5.1-I	HC System Operating Variables	789
3.6.4-I	HAC-to-GDC Record Format	836
3.7-I	HC Initialization Command Format	845
3.7-II	Beam Pointing Command Format	846
3.7-III	Corridor-Walk Start-Up Command Format	847
3.7-IV	Azimuth/Elevation Pointing Command Format	848
3.7-V	Status Poll Command Format	849
3.7-VI	Four Heliostat Status Response Format	850
3.7-VII	Heliostat Controller Status Bit Breakdown	852
3.7-VIII	HFC Status Breakdown	853
3.7-IX	Sun Position Command Format	854
3.7-X	HFC Initialization Command Format (Subtypes 0,1,2)	855
3.7-XI	HFC Initialization Command Format (Subtypes 3,4,5)	856
3.7-XII	HFC Initialization Command Format (Subtype 6)	857
3.7-XIII	HC Sun/Synchronization Command Format (Beam Pointing)	858
3.7-XIV	HC Sun/Synchronization Command Format (Azimuth/ Elevation Pointing)	861
3.7-XV	Sun/Synchronization Command Format (HC Initialization)	864

LIST OF TABLES (con't)

<u>Table</u>	<u>Title</u>	<u>Page</u>
3.7-XVI	HC Command Response Format	867
3.7-XVII	HC Status Poll Command Format	868
3.7-XVIII	HC Status Response Format	869
3.7-XIX	OCS/DAS-HAC Commands Format	870
3.7-XX	HAC-OCS/DAS Environment Format	871
3.7-XXI	HAC-OCS/DAS Environment Status (Field) Format	872
3.7-XXII	HAC-OCS/DAS Environment Status (Mode) Format	874
3.7-XXIII	HAC-OCS/DAS Environment Status (HC) Format	875
3.7-XXIV	HAC/OCS-DAS Environment Status (Ring)Format	877
3.7-XXV	HAC/BCS BCS Initiation Request Message Format	878
3.7-XXVI	BCS/HAC BCS Initiation Response Message Format	879
3.7-XXVII	HAC/BCS BCS Measurement Initiation Request Message Format	880
3.7-XXVIII	BCS/HAC BCS Measurement Initiation Response Message Format	881
3.7-XXIX	HAC/BCS Heliostat on BCS Target Message Format	882
3.7-XXX	BCS/HAC Heliostat BCS Removal Request Message Format	884
3.7-XXXI	Heliostat BCS Removal Response Message Format	885
3.7-XXXII	BCS/HAC BCS Measurment Results	886
3.7-XXXIII	HAC/BCS BCS Measurements Results Response	888
3.7-XXXIV	HAC/BCS BCS Termination Message Format	890
3.7-XXXV	HAC/BCS Heliostat Measurement Historical Data Request Message Format	891
3.7-XXXVI	HAC/BCS Heliostat Measurement Historical Data Response Format	892
3.7-XXXVII	HAC/BCS Heliostat Bias Results	894
3.7-XXXVIII	HAC-GDC Field Position Initialization	896
3.7-XXXIX	HAC-GDC Full Field Status	898
3.7-XL	HAC-GDC Segment Status	899
3.7-XLI	HAC-GDC Text Message to GDC	900
3.7-XLII	HAC-GDC Graphics Initialization	901
3.7-XLIII	GDC-HAC GDC Command	902
3.7-XLIV	GDC-HAC GDC Command	903
3.7-XLV	GDC-HAC Command	904
3.7-XLVI	GDC-HAC GDC Command	905
3.7-XLVII	Receiver-to-HAC Trip Signal Logic	906

1.0 INTRODUCTION

1.1 Scope

This Collector Subsystem Software/Firmware Design Specification exists as a stand-alone document to provide a complete description of the software and firmware employed for the operation of the 10 MWe Solar Thermal Central Receiver Pilot Plant Collector Subsystem.

1.2 Problem Statement

The software/firmware systems have the capability to allow operator control of up to 2048 heliostats in the operation of the 10 MWe Solar Thermal Central Receiver Pilot Plant at Barstow, California. This function includes the capability of operator-commanded mode control, graphic displays, status displays, alarm generation, system redundancy and interfaces to the Operational Control System (OCS), the Data Acquisition System (DAS), and the Beam Characterization System (BCS) through the OCS. The operational commands will provide for the following:

- a. Safe beam movement whenever automatic beam movement is required;
- b. Single and multiple heliostat addressing;
- c. Emergency heliostat movement for high-wind conditions and receiver problems; and
- d. Recovery for full or partial power-loss conditions.

The control hardware consists of a host computer, the Heliostat Array Controller (HAC), interfaced to a group of communication controllers, the Heliostat Field Controllers (HFCs), communicating with individual processors, the Heliostat Controllers (HCs), which monitor and command a single heliostat. The system consists of two HACs and 64 HFCs with up to 32 HCs per HFC.

The solar position data must be calculated accurately and often enough so that the reflected beams remain on target throughout the day. The status interface must include general field status updated automatically, while specific heliostat status is available upon operator request. Alarms must be generated and displayed for abnormal conditions requiring operator attention.

An interface must be available to the OCS for command input, status requests and alarms allowing the operator a single Master Control System for plant control. In addition, an interface must be maintained with the DAS to provide data collection capability for plant study and analysis. The Collector Subsystem (CS) is one

of the most critical components of the pilot plant thus requiring redundant HACs and dual communications to the field. This system redundancy is necessary to minimize interruptions to plant operations due to computer failures.

1.3

Design Approach

The method used to design this software/firmware system was to functionally decompose the requirements into eleven software modules for execution in the HAC computer, one firmware module for execution in the HFC microprocessor, and one firmware module for execution in the HC microprocessor. First the interfaces between the HAC computer/HFC microprocessor and HFC microprocessor/HC microprocessor were thoroughly defined. Next, the interfaces between the individual HAC software modules were defined. Further decomposition of the modules was performed until each submodule (independent tasks or subroutines) was defined.

The design of these modules is presented in paragraphs 3.2, 3.4, and 3.5. The data packets have been defined for the interface with the OCS, BCS, DAS, and between the Chromatics terminals and the HAC.

APPLICABLE DOCUMENTS

The following are the documents applicable to the development of the software for the project:

- a. Department of Energy Request for Proposal No. DE-RP03-79SF10539 for "Phase II, Collector Subsystem for the 10 MWe Solar Thermal Central Receiver Pilot Plant" received 7 June 1979;
- b. Amendment 2 to RFP DE-RP03-79SF10539, received 16 July, 1979;
- c. Amendment 3 to RFP DE-RP03-79SF10539, received 20 July 1979;
- d. CS-MCS and CS-Plant Interface Requirements document, (MDC G7852) dated 18 April 1980; RE changed by items j and k;
- e. Martin Marietta Proposal for Phase II, Collector Subsystem for 10 MWe Solar Central Receiver Pilot Plant, dated 6 August 1979
 - 1. Volume 1 - Technical Proposal P79-48372-1
 - 2. Volume 2 - Price/Business Proposal P78-48372-2;
- f. Martin Marietta Denver Division Software Development Procedure (Standard Procedure 1.4 dated 19 May 1978);
- g. Martin Marietta Corporation Aerospace Division Software Standards (Denver Division Engineering Practices Manual G13 dated 2 July 1979);
- h. 10 MWe Collector Subsystem Software/Firmware Development Plan;
- i. 10 MWe Collector System Contract Change Order #4, dated 19 February 1980;
- j. STMPO letter dated 16 April 1980, Collector Control System Changes;
- k. STMPO letter dated 5 May 1980, Collector Interface Meeting on 28 April 1980;
- l. 10 MWe Collector System Contract Change Order #8, dated 30 May 1980;
- m. Martin Marietta Denver Division Policy TO-8-D1, Software Development Management and Control.
- n. 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, MCR-80-1341 dated 12 June 1980.

3.0

DESIGN REQUIREMENTS

The requirements satisfied by each module of the Software/firmware system are taken from the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification. In addition, this section details the design of the modules to satisfy the requirements, the interfaces between the computers, the software system structure, and the computers in which the software and firmware will execute.

3.1

System Functional Description

The top-level flowchart diagrams of the HAC "Prime" and "Backup" software system are shown in Figures 3.1-1 and 3.1-2 and show the data flow of the system. The structure of the software system relies heavily on the Request Executive Services feature of the MAX IV Operating System which allows tasks to suspend themselves until a specified time has elapsed, and to activate other tasks which have been suspended. These tasks remain memory resident, but use no processing time until activated. The structure of the software system in the HAC computer can be described as a synchronous sequence of tasks and an asynchronous sequence of tasks.

The synchronous sequence tasks execute in one-second intervals or "frames." The purpose of these "frames" is field synchronization and communications. During the one-second frame: the sun position vector is transmitted to the entire field; a new sun position is calculated to be used in the next "frame;" a status poll is generated and status is received from one-eighth of the field; status is updated and reported based on the status data; alarms are generated automatically for irregular heliostat operation; global data required for failover is transferred to the "Backup" computer; status data is made available for transfer to the Graphics terminals; and processed commands are transmitted to the field.

The asynchronous sequence of tasks is initiated by command input from the CS Control Console, data received from the Chromatics Terminals, command input from the OCS or DAS, or activation by another task within the system. Inter-task communication is handled via the global common data base.

3.1.1

Hardware System Description

The computer systems of the Control Subsystem are the HAC computer, the HFC microprocessor, the HC microprocessor, and the Chromatics Intelligent Terminals. Each of these computers is described in the following paragraphs.

3.1.1.1

HAC Computer System

The HAC computer system hardware configuration is shown in Figure 3.1-3 and the HAC computer hardware Acronyms and Model Numbers are listed in Table 3.1-I. This consists of

Figure 3.1-1 "Prime"

Figure 3.1-2 "Backup"

HAC COMPUTER HARDWARE ACRONYMS AND MODEL NUMBERS

7861	MODCOMP Classic Central Processing Unit.
CPU	See "7861"
3765	Combination 4137 disk and operator's console controller board
4137	Disk pack drive, with one removeable and one fixed disk. Each disk has 816 tracks, 24 sectors per track, 256 bytes per sector (total 10 megabytes per drive). These drives are also known loosely as "200 TPI" drives.
TI-820	Hard-copy operator's console, manufactured by Texas Instruments, capable of 120 characters/second.
3771	Dual port direct memory access (DMP) processor.
4903	Chassis box and power supply for containing peripheral controllers. Also known as a Peripheral Controller Interface (PCI).
4906	Same as 4903, but containing electronics allowing one of two CPUs to connect itself to the enclosed peripherals either manually or via automatic control. Also known as a Peripheral Control Switch (PCS).
4824	One half of a full duplex CPU-CPU serial link, operating at 125K baud.
4811	General purpose asynchronous controller, with two independent full duplex channels.
4411	DMP card reader with controller.
4227	Teletype Model 40 printer with controller.
4228	TI Model 810 RO terminal, used as low-speed printer.
3109	Communications Processor (CP), an independent microprocessor-controlled communications controller.
1907-A	Communications line multiplexor.
1930	Chassis and power supply for communications handlers, such as 1931s.
1931	A two channel, full duplex asynchronous controller.
PCI	See 4903.
PCS	See 4906.
CP	See 3109.
4148	Nine-track 800 bpi magnetic tape

Table 3.1-I

two MODCOMP CLASSIC computers (#7861) each with 256K words of MOS memory, combination disk and operator's console controller (#3765), dual-port direct memory access (DMP) processor (#3765), Communication Processor (CP) option (#3109), and two Peripheral Controller Interfaces (PCIs) (#4903). One of the PCIs contains a communication line multiplexer (#1907-A-2) for communications with the field, the other contains a general purpose asynchronous controller (#4811) for communications with the OCS and DAS and a CPU-CPU serial link (#4824) for communications with the other HAC computer. The field communications is handled via the 1907-A-2 which addresses either the normal or alternate two-channel asynchronous controllers (#1931) within the Universal Communications Chassis (#1930).

For the peripheral equipment, each HAC computer contains a TI-820 terminal for a systems console and a 10 Megabyte Disk unit (#4137). The other peripheral equipment is referenced by one of two Peripheral Control Switches (PCS) (#4906). One PCS contains a 300 cards-per-minute card reader (#4411), a nine-track 800 bits-per-inch magnetic tape unit (#4148), a TI-810 low-speed printer (#4228) and a Chromatics Terminal (#1999). The other PCS contains a WWVB receiver, an ISC 8001 Color CRT, a Teletype 40 printer (#4227) and another Chromatics Terminal (#1999).

3.1.1.2

HFC Microprocessor

The HFC microprocessor is a Motorola #6803 microprocessor with 4096 8-bit bytes of read only memory and 1152 8-bit bytes of random access memory. Communications with the HAC computer is maintained by the microprocessor's two external ACIA's, with accompanying line drivers and receivers to provide redundancy and switchable communications lines. Communications with the HC microprocessor is through the HFC microprocessor's serial input/output port. In addition, the HFC microprocessor requires a dead-man timer, as well as a dip switch, to tell the HFC which one he is. These two devices are accessed through the microprocessor's parallel input/output port.

3.1.1.3

HC Microprocessor

The HC microprocessor is a Motorola #6803 microprocessor with 2048 8-bit bytes of read only memory and 256 8-bit bytes of random access memory. Communications with the HFC microprocessor is maintained through the microprocessor's serial input/output port. Like the HFC microprocessor, the HC microprocessor uses a dead-man timer and dip switches, accessed through the microprocessor's parallel input/output

port. In addition, the HC uses an external parallel interface adapter (PIA), through which the HC interfaces with the azimuth and elevation incremental encoders. The motor drive signals also use this PIA.

3.1.1.4 Chromatics Intelligent Terminals

The graphics display systems consists of two identical Chromatics CG1999 intelligent color graphic terminals and their associated peripherals. These systems include user-programmable Z-80 microprocessors with 33K bytes program random-access memory (RAM), 18K bytes system program read-only memory (ROM), 128K bytes of screen refresh memory, 512x512 resolution, 19-inch diagonal, 8-color display CRT, dual 256K bytes floppy-disk drives, RS232C serial input/output Port, a light pen, and an alphanumeric keyboard with user-definable function keys.

3.1.2 Software/Firmware System Description

The HAC Software Design is located in Sections 3.2 and 3.3. The HFC Firmware design is located in Section 3.4, and HC Firmware design is located in Section 3.5, and the Chromatics Intelligent Terminal software design is located in Section 3.6.

3.1.2.1 HAC Software Description

3.1.2.1.1 Terminology

The software for the HAC computer consists of modules, tasks and submodules. The definition of each and the scheme used to identify them are as follows:

- a. Module - Six unique alpha characters that identify a specific function (i.e. SUNVEC for the sun vector generation function). The module name does not identify a piece of code, it represents a function of related tasks and submodules.
- b. Task - Three unique alpha characters that identify a specific task within a module. The task has code associated

with it either as a stand-alone program or a main submodule and a series of submodules. If the task calls a series of submodules, it will be considered the main submodule.

- c. Submodule - Six alpha characters, the first three equal to the task name which calls the submodule, and the second three are a unique description of the submodule. Submodules called by more than one task will be identified by the most frequent calling task.

3.1.2.1.2

Operating Modes

All tasks within the HAC will be executing under the MODCOMP MAXNET IV operating system. These tasks are subdivided into one of three operating modes: system initialization mode; synchronous mode; and the asynchronous mode.

The system initialization mode is composed of both an offline and a real-time portion. The offline portion is designed to initialize the disk resident data base files and provides initialization data to the Chromatics Terminals. An offline activity was elected because of time considerations and added flexibility for the operator. This portion of the initialization process may be done at the operator's convenience. The real-time system initialization mode consists of those tasks within the DBINIT module that execute in response to system boot-up. These tasks initialize the global common data base, CS control console and backup system, establishes tasks and system interfaces, and provides initialization and synchronization of the universal and local system time base. The system initialization tasks will no longer exist in main memory when the initialization function is complete.

The synchronous mode is initiated upon activation by the timing tasks within the MAXIVM module. This mode consists of those tasks which automatically operate every time frame and they may be activated by other tasks within the synchronous loop or self-activated by time delays. Synchronous processing is required by the FLDCOM, SUNVEC, MAXIVM, CMDPRC, ALARMS, and STATUS modules. The tasks required for synchronous processing in general will be given higher priorities than the asynchronous tasks in order to ensure that the synchronous processing is accomplished each time frame.

The asynchronous mode consists of those tasks which are activated only when processing is necessary. These tasks may be activated by any other task within the system, specifically when commands or status requests are entered or when the graphics software requires data for displays. The asynchronous tasks may emulate the synchronous tasks as long as there is an outstanding request for a specific task's function. For example, the sequencing task of the CMDPRC module will operate periodically as long as there is

an active command sequence within the system. As soon as all command sequences have been terminated, the command sequence task will be inactivated and only reactivated when required by another sequence command. Asynchronous processing is required by the MANMIF, MAXIVM, CMDPRC, ALARMS, STATUS, GRAPHC, BCSMOD and EXTINF modules.

3.1.2.1.3

Functional Overview

The functional overview of the system is presented in the following paragraphs (see figure 3.1-4).

The HAC software is readied for system operation through the initialization process. This process is broken into the offline initialization phase and the real-time initialization phase.

DIN, the offline initialization task of the Data Base Initialization module (DBINIT), is executed at the operator's convenience well in advance of anticipated field control. DIN edits source data from cards or magnetic tape to create the disk-resident data base and transmits required initialization data to the Chromatics graphic terminals. This Chromatics initialization function is handled offline due to the amount of time required for transmission.

Following the offline initialization of the disk-resident data base and graphics terminals, the real-time system is booted. The prescheduled task, DBI (DBINIT module), is automatically activated to initialize the real-time system including global common and system interfaces. Communications with the backup system is established at this time via the activation of the switching task, SWI, of the Operating Systems Modification module (MAXIVM).

In order to release memory for subsequent tasks, DBI activates a smaller task, CLK (DBINIT module), for real-time task establishment and activation, and then terminates. After all resident tasks have been established, CLK activates TOK and TIK, the timekeeping tasks of the MAXIVM module. Task TIK is subsequently self-activated once per second to maintain the time in the global common data base and to initiate the synchronous loop for each time frame by activating the Field Communications Processor module (FLDCOM) task, FCP.

The task FCP transmits the sun position vector to the entire field. It then activates the sun position calculation task, SUN, of the Sun Vector module (SUNVEC). The task FCP then suspends itself, to be reactivated at approximately 310 milliseconds into the frame for status polling. During this time, the SUN task calculates the sun position to be used in the next frame. It then suspends itself until activated in the next frame. At the time for status poll of the field, FCP is reactivated by the operating system. The task polls the heliostat field, receives status information for up to one-eighth of the field, and stores the status data in the data base. FCP then performs preliminary checking of the status data to determine communications status. If alarm conditions are found, this data

Figure 3.1-4 HAC Task Activation Flow

is passed to the alarm task for alarm display. FCP then activates the HFC initialization task, BHI, of the Command Processor module (CMDPRC), the alarms monitoring task, ALM, of the Alarms Processor module (ALARMS), and the synchronous status task, STS, of the Status Display Processor module (STATUS), and suspends itself until time to transmit the operational commands to the field (approximately 725 milliseconds into the "frame").

BHI monitors the HFC status determining which HFCs, if any, require initialization data. It then begins the initialization process for the indicated HFCs and suspends itself until activated in the next frame.

ALM executes to monitor the status data and generates alarms for irregularly operating heliostats. If alarms are generated, ALM activates the alarms output task, ALO (ALARMS module), to display the alarms and suspends itself until activated next frame. If ALO is activated, it displays all successfully queued alarms and suspends itself.

STS executes to process the latest received status and report the field status on the CS Control Console. It checks to determine if there is an operator status request pending, and if so, STS activates the asynchronous status task, STA (STATUS module), and then suspends itself until activated next frame. Task STA will determine the type of status requested, scan the status data array, format the status message, and transmit the status via the console output task, CSO, or the external interface task, EXI, of the External Interface Module (EXTINF), depending on the requesting source. It then suspends itself.

When the time to transmit operational commands arrives, FCP is reactivated by the system. It scans its buffer of commands ready for transmission and transmits any commands waiting. After command transmission, FCP checks the data base buffer to see if CMDPRC has additional commands to be transmitted. If so, FCP transfers these commands into its buffer of commands waiting for transmission. Task FCP then activates task BHC (CMDPRC module), and suspends itself until started by the timekeeping task at the start of the next "frame." Task BHC checks the array of 2048 possible heliostat commands. If commands are ready for transmission, and the HFC buffer of commands in the data base is available for a new command, the task will compress all similar HC commands into an HFC command (with the HC bit mask) and load the new command into the HFC command buffer. The task will then suspend itself.

The asynchronous sequence of tasks is also initiated by the start-up control task, CLK (DBINIT module). The communications tasks within EXINF that establish and maintain communications with the OCS, DAS, CS Control Console, and Chromatics terminals are activated by CLK. EXI establishes and maintains communication with the OCS and DAS. EXI accepts commands and status requests

from the OCS and status requests from the DAS, and passes these inputs to the MMI task (MANMIF module) for syntax checking and processing. EXI will also transmit the resultant data from these requests back to the respective source, OCS or DAS. The console interface task, CSI (EXTINF module), accepts inputs from the CS Control Console and Chromatics terminals and routes the input to either the MANMIF module for commands, or to the Graphics Display Processor Module (GRAPHC) for graphic display status requests. CSO will transmit responses back to the CS control console. When the graphics processing task, GRF (GRAPHC module), receives a request for data, it determines the type of request and scans for the appropriate data in the status array created by the synchronous STS task. The status packet is formatted and held for transmission pending a request to send message from the CSI task. Once the data has been transmitted, GRF terminates itself.

The Central Receiver requires constant monitoring in order to prevent receiver damage. Consequently, CLK activates the receiver trip high task, RTH, and receiver trip low task, RTL (MAXIVM module), to monitor receiver status. This status consists of two signals, one the inverse of the other, which when reversed from normal, cause a DEFOCUS command to be transmitted to MMI.

When MMI receives a command from any source through a series of priority queues (the emergency command queue is highest priority), it checks each command for valid syntax and source. If an error occurs, the source of the command will be notified, and MMI will suspend itself until activated by another command. If the command is valid and requires disk updating, task DSK (MANMIF module) will be activated to process the command, and MMI will suspend itself. DSK processes all commands that only require updating of the disk data base. If the valid command requires a command file from disk to be started, MMI will activate task CFO (MANMIF module) to process the command file and then suspend itself. If the command is a status request, MMI will notify STA via the data base that status has been requested and then suspend itself. If the valid command requires communication with the field, MMI will build a data packet, activate task CMD (CMDPRC module) and then suspend itself.

CMD will check the command for reasonableness and report via the data base an error code or a success ratio. MMI will report either the error or the success ratio to the operator. If an error occurred, CMD will terminate itself; otherwise the task will begin processing the command. CMD will build the HC commands array and mark the commands ready for BHC to map into HFC commands. If the command requires data from disk to complete processing, CMD will activate task GET (CMDPRC module) to read the disk data and then suspend itself. Once the disk operation is complete, CMD is resumed to finish processing. If the command requires a sequence for implementation, task SEQ (CMDPRC module) is activated to perform this processing. After CMD builds the necessary commands and activates or resumes the appropriate tasks, it terminates itself.

SEQ, once activated, will run periodically by setting timers for self-activation as long as there are sequences to process. The system allows up to 16 concurrent sequences, and SEQ is reactivated on an optimal basis to monitor one particular sequence per "visit" in a modified round-robin fashion. When there is no longer an active sequence, SEQ terminates itself.

3.1.2.2

HFC Firmware Description (see Figure 3.4.1-1)

The HFC firmware interposes between the HAC and the HCs. The HFC firmware performs command translation from HAC to HC, status collection and formatting from HC to HAC, corridor-walk sequencing, and emergency corridor-walk sequencing. HFC firmware consists of a set of foreground (interrupt level) and background (non-interrupt) tasks.

HAC input and HAC output are two foreground tasks which do byte to/from message packet translation to allow the HFC background tasks to communicate on a message basis. HC input and HC output are the two foreground tasks which perform the same function for HC I/O. HFC timers is a foreground task which provides delay and dead-man timers of different granularities to the background tasks.

Three background tasks operate in a serial fashion under control of the main background task, CMDI. CMDI controls the operational mode of the HFC (restart, normal, or emergency corridor walk) according to the current mode and input stimulus, and processes all commands from the HAC. However, once each second, whether triggered by a sun/sync message from the HAC or by an internal timer during emergency corridor walk, CMDI activates the three other background tasks in order, to perform the main HFC functions. HC operations task is called first. HC operations commands the HCs, collects and formats command/response information, polls four HCs each second for status, and collects and formats the returned status. Second is the corridor walk calculation. The corridor walk calculation task updates the current corridor target points and handles corridor end conditions. The final task is emergency corridor walk sequencing. Emergency corridor walk sequencing normally does nothing, but during emergency corridor walk mode it generates commands, in sequence, and checks the operation of the HCs in order to accomplish the emergency corridor walk. After these three tasks complete, CMDI is ready to accept any HAC commands again.

3.1.2.3

HC Firmware Description (see Figure 3.5.1-1)

HC firmware positions the heliostat to commanded or calculated positions based on direct position commands or target position coordinates. HC firmware consists of a set of foreground tasks (Initiated by system interrupts) and background tasks. INIT is a background task activated by power up or in the event of a

communications loss. The primary function of INIT is to set the system operating devices to the proper state (i.e. motor power, line driver and receiver enables and disables) and initialize system memory and status flags.

CALC is the second background task activated by the communications handler (SCIO) upon acceptance of a command requiring position calculation. The function of CALC is to determine actual azimuth and elevation positions based on current target, heliostat, and sun vectors. This involves vector addition, subtraction, and normalization routines as well as cartesian to polar conversions utilizing the "cordic algorithm."

SYSCLK is a foreground task activated by a hardware timer. The primary function of SYSCLK is to assure activation of time critical events such as command response or motor control.

SCIO is a foreground task activated by the internal hardware transmitter or receiver. The function of SCIO is to handle communications between the HFC and the HC.

POINT is a foreground task activated by SYSCLK. The function of POINT is to perform closed-loop control of the heliostat. This is accomplished by activating azimuth and elevation motors in either high or low speeds while acquiring data from incremental position encoders.

3.1.2.4

Chromatics Intelligent Terminal (GDC) Software Description

The GDC software module consists of foreground (interrupt driven) submodules, background (real time) processing submodules and offline (non-real time) preprocessing submodules.

The offline preprocessors (FFPREP and SEGPREP) are run whenever the field configuration data base on the HAC is updated. They manage the formatted data transferred from the HAC and conversion of that data into run-time efficient, unformatted, disk-resident files.

GDC online software includes foreground submodules which handle interrupts from the SIO link (RCV) and keyboard (KBD). These submodules provide data buffering and signal availability of data to the EXEC, which invokes appropriate background tasks to process the data. These background tasks include the interactive user/GDC dialogue controller (DIALOG) and real-time display updating tasks (FFDISP and SEGDISP). A collection of utility functions (UTIL) provides application-oriented numeric and character-handling capabilities to both offline and online processes.

3.2

HAC Software Design

The detail design of the modules and submodules of the HAC system software are presented in the following paragraphs.

3.2.1 Man-Machine Interface Module - (MANMIF)

3.2.1.1 Purpose

The Man-Machine Interface Module serves as an interface between the operator(s) and the HAC, through which an operator can implement commands for heliostat field control and monitoring and data base updating. MANMIF is comprised of a main module, MMI, and 13 submodules: MMIWRD, MMCHK, MMNUM, MMIMAP, MMIERR, MMIRSP, MMIAID, MMISTR, MMIREF, DSK, DSKADM, DSKBIA, and CFO.

3.2.1.2 Requirements

3.2.1.2.1 Design Requirements

Section 3.1 of the Software/Firmware Functional Requirements Specification (12 June 1980) lists the following requirements which concern MANMIF:

- a. Control of up to 2048 heliostats in all modes required to operate the heliostats.

This requirement indicates the need for operator-entered commands to be interpreted, processed, and forwarded to the CMDPRC module for implementation.

- b. Monitor and display the operational status of all heliostats.

This requirement indicates the need for an operator status request to be interpreted, processed, and forwarded to the STATUS module for implementation.

- c. Detect, report, and respond to failures and irregularities.

This requirement indicates the need for operator-entered response to be interpreted, processed, and forwarded to the ALARMS module for further processing.

- d. Maintain a "Prime" and "Backup" system, as well as redundant processing in the "Backup" system in order to keep disk files up to date.

- e. Maintain safe beam control.

This requirement indicates a need to perform inclusion area checking of new aim-point data.

- f. Respond to receiver trip for emergency defocus.

This requirement indicates a need to format a DEFOCUS command to be forwarded to the CMDPRC module upon receiving a receiver trip.

- g. Maintain command/response protocol and data transfer with the OCS.

This requirement indicates a need to determine the source of a given command, build response messages appropriate to the command, and send the responses to the source of the command.

- h. Provide status data to the DAS.

This requirement indicates a need for operator-entered status requests from the DAS to be interpreted, processed, and forwarded to the STATUS module.

- i. Provide automatic control of beam characterization within the HAC.

This requirement indicates the need for operator-entered commands to be interpreted, processed and forwarded to the BCSMOD module for implementation.

3.2.1.2.2

Derived Requirements

Section 3.2.1.1 of the Software/Firmware Functional Requirements Specification (12 June 1980) lists the following derived requirements for the MANMIF module:

- a. Accept commands from the CS control console, OCS, DAS, and CS graphics console, and read command files from disk;
- b. Decode command addresses for the Command Processor Module and convert commands to internal computer format;
- c. Check all commands for valid syntax;
- d. Generate error messages and route them to the appropriate output devices;
- e. Pass valid operational commands to the Command Processor Module;
- f. Log all commands on the console/printer with appropriate time stamps;
- g. Update a heliostat's bias disk file upon operator request; and
- h. Update aim-point array and perform inclusion-area checking.

Additionally, the MANMIF module must be able to:

- a. Generate operator-aid menus of various formats upon request;
- b. Control operation of execution of command files;
- c. Refresh the CS console CRT screen upon request;
- d. Generate messages responding to each command, indicating successful completion of the command, or syntax or other errors; and
- e. Exclude certain commands during emergency processing, or those from invalid sources.

A list of valid commands and their effects is given in Table 3.2.1-I, and the addressing formats are described in Table 3.2.1-II. It should be noted that at least the first four, and up to eight, of the letters of each command are necessary.

3.2.1.3

Design Approach

MANMIF is comprised of 14 submodules, including three tasks: MMI, DSK, and CFO. MMI is the main routine, and may activate DSK for any disk data updating or CFO for command file execution. MMI and its nine submodules perform syntax checking of the command string and build data packets for the CMDPRC, STATUS, and BCSMOD modules. DSK and CFO handle all disk operations separately from the syntax checking and operational command processing.

3.2.1.3.1

Functional Allocations

MANMIF is comprised of 14 submodules; the basic function of each is described below.

Main routine for syntax checking and operational commands:

MMI - Accepts operator commands from the CS console, the OCS, DAS, and Graphics Display via the EXTINF module, or from command file sequences via submodule CFO. The EXTINF module, CFO task and the receiver trip function activate MMI by enqueueing the ASCII command string in one of five queues as follows:

- Queue 0 - Emergency commands from any source
- Queue 1 - CS-entered commands
- Queue 2 - OCS-entered commands
- Queue 3 - DAS-entered commands
- Queue 4 - Command file sequences

The queues are checked and processed in order from zero to four, effectively generating a priority scheme with

COMMAND	INPUT SOURCE	ADDRESSING	DESCRIPTION
<u>TRACK</u>	CS OCS	Heliostat Segment Wedge Ring Field Controller Arc	Directs heliostat(s) tracking the STANDBY position to track the target.
<u>INCREASE</u>	CS OCS	Segment Wedge Ring	Directs heliostat(s) tracking the STANDBY position to track the target. **The optional number address may be used with this command (see Table Ia.).
<u>LOAD</u>	CS	Heliostat Field Controller Field Arc	This command will cause download of initialization data to the heliostat controller.
<u>MARK</u>	CS	Heliostat Field Controller Segment Wedge Ring Field Arc	Directs heliostat(s) to move in both axes such that shafts pass reference marks on encoders. Used to determine accurate heliostat orientation prior to use.
<u>STANDBY</u>	CS OCS	Heliostat Segment Wedge Ring Field Controller Arc	Directs heliostat(s) tracking the target to track the STANDBY position.
<u>STOW</u>	CS OCS	Heliostat Segment Field Arc	Directs heliostat(s) to respective STOW positions
<u>POSITION</u>	CS	Heliostat Segment Wedge Ring Field Controller Arc	Directs heliostat(s) to commanded orientation. Beam safety is operator responsibility.
<u>ONLINE</u>	CS	Heliostat Segment Wedge Ring Field Controller Arc	No heliostat movement results from this command. Allows heliostat(s) previously commanded OFFLINE to be commanded.

Table 3.2.1-I. Collector Subsystem Command List

COMMAND	INPUT SOURCE	ADDRESSING	DESCRIPTION
<u>OFFLINE</u>	CS	Heliostat Segment Wedge Ring Field Controller Arc	Directs heliostat(s) to remain in current position and accepts no further commands to these heliostats until ONLINE command entered.
<u>DECREASE</u>	CS	Segment Wedge Ring	Directs heliostat(s) tracking the target to track the STANDBY position. **The optional number address may be used with this command (see Table Ia.).
<u>BCSTRACK</u>	CS	Heliostat	Directs heliostat to track BCS target to which it is assigned.
<u>RETURN</u>	CS	Heliostat	Directs heliostat(s) in BCS mode to track the STANDBY point.
<u>WASH</u>	CS	Heliostat Arc	Directs heliostat(s) to go to their respective WASH orientation. This command may be unsafe if used during the period when the sun is present.
<u>ALT1STOW</u>	CS	Heliostat Segment Wedge Ring Field Controller Arc Field	Directs heliostat(s) to respective SLT1STOW positions
<u>ALT2STOW</u>	CS	Heliostat Segment Field Arc	Directs heliostat(s) to respective ALT2STOW elevations while maintaining last reported azimuth.
<u>RESTORE</u>	CS	Field	Restores aimpoint array assignment from saved configuration to track target and heliostat(s) that were tracking STANDBY points. Only heliostat(s) in TRACK or STANDBY modes will respond to this command.

Table 3.2.1-I. Collector Subsystem Command List (cont.)

COMMAND	INPUT SOURCE	ADDRESSING	DESCRIPTION
<u>UNSTOW</u>	CS OCS	Heliostat Segment Wedge Ring Field Controller Field Arc	Directs heliostat(s) in one of STOW positions to track the STANDBY position.
<u>STHIWIND</u>	CS OCS GRAPHIC	Field	Directs all heliostats in the allowable modes to their respective STOW positions. No further commands allowed until RLHIWIND command is entered. Those heliostats doing corridor walk will be allowed to complete the corridor before responding.
<u>DEFOCUS</u>	CS OCS RS GRAPHIC	Field	Directs all heliostat(s) tracking the target or going to the target to track the STANDBY position. No further target tracking commands accepted until DEFRLSE command.
<u>AIMPOINT</u>	CS OCS	(Segment Field), NN (Array Number)	This command will assign aimpoint arrays for the segment(s) commanded. If any heliostats in the commanded segment(s) are tracking the target, they will be redirected to the newly assigned aimpoint.
<u>HOLD</u>	CS	Heliostat	Directs a transitioning heliostat to maintain current orientation. Includes those heliostats doing corridor walk.
<u>SAVE</u>	CS	Field	No heliostat movement results from this command. Tracking configuration saved for use with restore command. Aimpoint array assignment also saved.
<u>RELWASH</u>	CS	Heliostat Arc	This command is the only way a heliostat may be released from the WASH mode. No movement occurs and the heliostat is placed in the DIRECTED POSITION mode.

Table 3.2.1-I. Collector Subsystem Command List (cont.)

COMMAND	INPUT SOURCE	ADDRESSING	DESCRIPTION
<u>ESTANDBY</u>	CS OCS	Heliostat Field Controller Segment Wedge Ring Field Arc	This command allows an operator to command heliostats to the STANDBY mode after power loss and initialization.
<u>ESTOW</u>	CS OCS	Heliostat Field Controller Segment Wedge Ring Field Arc	This command allows an operator to command heliostats directly to STOW with no beam safety after power loss and initialization.
<u>RLHIWIND</u>	CS	Field	No heliostat movement results from this command. This command allows heliostat(s) affected by STHIWIND command to be commanded again.
<u>DEFRLSE</u>	CS	Field	No heliostat movement results from this command. This command allows heliostats which were put in STANDBY mode due to DEFOCUS command to be commanded to track again. This command will not be accepted if the Receiver Trip signal has not returned to normal.
<u>UPA1M</u>	CS	NN (Array number to be updated)	This command will replace the array specified with a completely new array from magnetic tape.
<u>UPBIAS</u>	CS	H/NNNN, AZ, EL NNNN = heliostat AZ - Azimuth bias in HEX EL - Elevation bias in HEX	This command updates the encoder bias file on disc.
<u>STATUS</u>	CS OCS DAS	Heliostat Mode Ring Field	Allows request for STATUS in one of four forms: 1) individual heliostat STATUS including mode, orientation, commanded mode and position compare flag; 2) list of the heliostats in requested mode; 3) number of heliostats within ring which are in the TRACK and STANDBY modes, and 4) number of heliostats in all modes.

Table 3.2.1-I Collector Subsystem Command List (cont.)

COMMAND	INPUT SOURCE	ADDRESSING	DESCRIPTION
<u>HELP</u>	CS	Blank, Command or Address	No address will give the operator a list of all commands available. By using an individual command, the information will contain the format and valid addressing.
<u>CFSTART</u>	CS OCS	FFF (File name)	This command will cause the execution of a particular command file to begin.
<u>CFABORT</u>	CS	N/A	This command will stop the execution of a particular command file.
<u>CFWAIT</u>	CS	SSSS (seconds)	This command will hold the execution of a particular command file for the specified number of seconds.
<u>REFRESH</u>	CS	N/A	Allows the CS control console to be completely refreshed.
<u>BCSSTART</u>	CS	N/A	This command starts automatic BCS processing.
<u>BCSABORT</u>	CS	N/A	This command stops automatic BCS processing

Table 3.2.1-I. Collector Subsystem Command List (cont.)

COLLECTOR SUBSYSTEM COMMAND ADDRESSING FORMAT

ADDRESS	FORMAT
HELIOSTAT (H)	H/NNNN,NNNN...NNNN WHERE: NNNN IS THE HELIOSTAT NUMBER EXAMPLE: STOW H/2901
HELIOSTAT FIELD CONTROLLER (F)	F/NN,NN...NN WHERE: NN IS THE FIELD CONTROLLER NUMBER EXAMPLE: UNSTOW F/02
SEGMENT (S)	(XX)/S/NNN,NNN...NNN WHERE: XX IS THE (OPTIONAL)NUMBER OF HELIOSTATS PER SEGMENT. IF NOT INCLUDED THE WHOLE SEGMENT IS ASSUMED. NNN IS THE SEGMENT NUMBER EXAMPLE: INCREASE 10/S/302
WEDGE (W)	(SS)/W/NN,NN...NN WHERE: XX IS THE (OPTIONAL) NUMBER OF HELIOSTATS REQUIRED OUT OF EACH SEGMENT IN THE WEDGE. IF NOT INCLUDED THE WHOLE WEDGE IS ASSUMED. NN IS THE WEDGE NUMBER EXAMPLE: DECREASE 05/W/01
RING (R)	(XX)/R/N,N...N WHERE: XX IS THE (OPTIONAL) NUMBER OF HELIOSTATS REQUIRED OUT OF EACH SEGMENT IN THE RING. IF NOT INCLUDED THE WHOLE RING IS ASSUMED. N IS THE RING NUMBER EXAMPLE: INCREASE 10/R/5
ARC (A)	A/NNNN,NNNN/NNNN,NNNN/.../NNNN,NNNN WHERE: THE FIRST NNNN IS THE BEGINNING HELIOSTAT NUMBER. THE SECOND NNNN IS THE ENDING HELIOSTAT NUMBER. NOTE: THESE NUMBERS ARE EITHER EVEN INCLUSIVE OR ODD INCLUSIVE. EXAMPLE: WASH A/2901,2909
FIELD (ALL)	ALL THE WHOLE FIELD.
MODE (M)	<div> <div> TRK - TRACK STB - STANDBY BCS - BCS STO - STOW AL1 - ALT1STOW AL2 - ALT2STOW </div> <div> TRN - TRANSITION WSH - WASH DPO - DIRECTED POSITION OFF - OFFLINE MRK - MARK INI - INIT </div> </div> EXAMPLE: STAT M/TRK

TABLE 3.2.1-II. Collector Subsystem Command Addressing Format

emergency commands having the highest priorities, and command file sequences the lowest.

After dequeuing the highest priority message present, MMI calls MMIWRD to divide the ASCII command string into "words," then MMICLK to determine which command is being processed and the addressing used. Depending upon the command, MMI will call one or more of the following submodules, then activate CMDPRC for operational commands, BCS, DSK, or CFO for other commands.

MMI Subroutines:

- a. MMIWRD - Divides the ASCII command string into "words" separated by a single delimiter;
- b. MMICLK - Checks a word in the command string against a list of valid commands and addressing formats, and checks for validity of the address and source of the command (CS, OCS, etc.);
- c. MMINUM - Checks each requested ASCII numeric representation for validity for various addressing, converts from ASCII to binary representation, and stores the results in a local array;
- d. MMIMAP - Maps from various addressing schemes to internal heliostat numbers;
- e. MMIERR - Generates error messages for invalid syntax or other errors and routes this output to the source of the command;
- f. MMIRSP - Generates messages upon successful implementation of a command to indicate which or how many heliostats were affected by the command, or other success indicators;
- g. MMIAID - Provides operator aid of differing formats to the CS or OCS consoles, as a result of the HELP command;
- h. MMISTR - Processes status requests and sets global command words for the STATUS module; and
- i. MMIREF - Clears the CS console CRT screen and rewrites the ALARMS and STATUS areas of the screen.

Disk updating operation:

DSK - This task is activated by MMI and calls one of its two submodules to perform disk operations.

DSK subroutines:

- a. DSKAIM - Updates the heliostat aim-point file from card-image input for the UPAIM command; and
- b. DSKBIA - Updates the heliostat bias file for the UPBIAS command.

Command file operations:

CFO - Reads command file sequences and enques MMI with the ASCII command string at specified time intervals.

See Figure 3.2.1-1 for the MANMIF hierarchical overview.
See Figure 3.2.1-1a for the MMI functional overview and
3.2.1-1b for the DSK and CFO functional overview.

3.2.1.3.2

Resource Budgets

- a. MANMIF's three tasks have the following memory requirements (estimated):
 1. MMI - 10K 16-bit words
 2. DSK - 6K 16-bit words
 3. CFO - 4K 16-bit words
- b. Disk and magnetic tape utilization:
 1. MMI - none
 2. DSK - Access to the heliostat aim point array file, the heliostat bias file, a scratch disk file, and access to magnetic tape and/or a card reader.
 3. CFO - access to the command file disk file.
- c. Other:
 1. MMI - line printer to log commands
 2. DSK - none
 3. CFO - none

3.2.1.4

Design Description

3.2.1.4.1

Module Structure

The MANMIF module is composed of the 14 submodules briefly described in sections 3.2.1.3 and 3.2.1.3.1, above, and described in more detail in sections 3.2.1.4.1.1 through 3.2.1.4.1.14.4, below.

Figure 3.2.1-1 MANMIF Hierarchical Overview

Figure 3.2.1-1a
MMI Functional Overview

Figure 3.2.1-1b DSK and CFO Functional Overview

3.2.1.4.1.1 Submodule I - MMI

3.2.1.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - Activated by EXTINF and CFO via enqueue.
- c. Constraints and limitations - The operator-entered ASCII command string must follow the syntax rules described below. Additionally, scanning of the string ends when two delimiters in a row are encountered.
- d. Processing - In the following description, any syntax or other error in the command will cause an error flag to be set, MMIERR called, and processing ended.

1. Upon being activated by EXTINF, CFO or the receiver trip, MMI checks five input queues as follows:

Queue 0 = Emergency commands from any source
Queue 1 = CS-entered commands
Queue 2 = OCS-entered commands
Queue 3 = DAS-entered commands
Queue 4 = Command file sequences

The queues are checked in order from zero to four, effectively generating a priority scheme with emergency commands having the highest priority and command file sequences the lowest.

2. After dequeuing an ASCII character string from the highest priority queue containing data, subroutine MMIWRD is called to begin processing of the string. Checks are made on the local common data set by MMIWRD to check for the presence of a valid number of characters in the actual command characters.
3. Next MMICLK is called to determine the validity of the command (see Table 3.2.1-I), the validity of the source (CS, OCS, DAS or command file, and, if emergency command flags are set, to see if the command is allowable following an emergency command or during an emergency sequence (indicated by global word set in the CMDPRC module).
4. If the command is STHI WIND or DEFOCUS, as indicated by MMICLK, control is passed to Step 9 below. No further syntax checking of these commands is done.

5. Steps (6) through (10) below will refer only to "operational" commands; i.e., those commands which may immediately affect the heliostat field and must be implemented by CMDPRC. These are commands "TRACK" through "ESTOW" as listed in Table 3.2.1-I; and with the exception of "POSITION" and "AIMPOINT" the remainder of the command string will consist of an address ("H," "A," "F," "S," "W," "R," or "ALL") followed by a delimiter, then followed by addressing parameters (heliostat or segment numbers, etc.) separated by delimiters. "POSITION" and "AIMPOINT" have the above format, with additional parameters appended. Processing for non-operational commands continues at step 11, below.
6. Next MMCHK is called again to determine which addressing is being used and if it is allowable for the command. If the result indicates an invalid address and the command is "INCREASE" or "DECREASE," MMI calls MMINUM to decode the possible number; otherwise an error results.
7. Next MMINUM is called to decode the addressing parameters and stores the results in local common array NUMARY. Checks are made to insure that each ASCII number has the proper number of characters, contains no non-numeric characters, and that the results are within acceptable values (see Section 3.2.1.4.1.4, MMINUM, for details).
8. Next, MMIMAP is called to obtain the heliostat numbers which are defined by the addressing format and parameters. The heliostat numbers are stored in global array HCMAPG (See Section 3.2.1.4.1.5, MMIMAP for details).
9. MMI then activates the CMDPRC module and suspends itself until reactivated by CMDPRC. Upon reactivation, global array HCMAPG will contain success rates for the command, or global word CPPRTG will contain an error message number.
10. The final step in processing operational commands is to call MMIERR, if the command could not be implemented, or MMIRSP, to report on the success rate of the command.

11. Processing of non-operational commands is best described on a command-by-command basis as follows:

- a) RLHIWIND - the "High'Wind Stow" (STHIWIND) command lock (LOKSTG) is cleared.
 - b) DEFRLSE - the "DEFOCUS" command lock (LOKDEG) is cleared.
 - c) UPAIM and UPBIAS - the rest of the string is syntax checked, global words DISKRG are set, and DSK is activated.
 - d) STATUS - is further processed by MMISTR.
 - e) HELP - is further processed by MMIAID.
 - f) CFSTART - submodule CFO is enqueued with the ASCII file name and the source of this command.
 - g) CFABORT - global word CFABOG is set.
 - h) CFWAIT - the ASCII wait time is decoded and stored in global word CFWATG.
 - i) REFRESH - MMIREF is called for further processing.
 - j) BCSSTART - the BCS task is activated.
 - k) BCSABORT - the BCS task is aborted.
- e. Error Messages and recovery - Syntax checking of the command string is done from left to right (except for POSITION or AIMPOINT). If a syntax error is encountered, IERR is set appropriately and control passed to MMIERR for reporting. Other errors (invalid source, emergency locks set, etc.) are also reported by MMIERR.

CMDPRC will set global word CPPRTG to a non-zero value if it is unable to implement a command, and these errors are also reported by MMIERR.

See Table 3.2.1-III for a list of reported errors.

Syntax Errors (Message contains the part of the command string found to be invalid)

- 1) Invalid Command
- 2) Invalid Addressing Character
- 3) This Addressing not allowed for command
- 4) Non-Numeric character
- 5) Number of range
- 6) Improper number of characters
- 7) Invalid mode request
- 8) Invalid file name

Non-Syntax Errors

- 1) Invalid Source of command
- 2) Command not allowed during DEFOCUS
- 3) Command not allowed during STHIWIND
- 4) Command not allowed during Emergency Sequence
- 5) Command File processing not Active (CFABORT or CFWAIT)
- 6) DEFOCUS command not given (DEFRLSE)
- 7) STHIWIND command not given (RLHIWIND)
- 8) BCS processing not active (BCSABORT)
- 9) BCS processing active (BCSSTART)
- 10) Command File Active (CFSTART)

Errors returned by the CMDPRC module

- 1) No heliostats in correct mode
- 2) No heliostats installed
- 3) All heliostats offline
- 4) BCSTRACK: only one HC/target.
- 5) Command Disallowed: only 16 sequences possible

TABLE 3.2.1-III MANMIF Errors

Input data:

A2 - ASCII command string enqueued to MANMIF by the EXTINF module or MANMIF submodule CFO containing two characters per 16-bit word.

Output data:

Global common: (see section 3.3.1, data base, for more details on global common.)

CPPG(1) - Command
CPPG(2) - > $\emptyset$ = # HCs/block in HCMAPG
 < $\emptyset$ = entire field
 $\emptyset$ = entire block in HCMAPG
CPPG(3) - Hex azimuth for "POSITION" command, or
 "AIMPOINT" array number
CPPG(4) - Hex elevation for "POSITION" command
HCMAPG - array of heliostat numbers addressed in the
 command
CFABOG - command file abort flag
CFWATG - command file wait time (seconds)
ISTATG - array containing status request data
LOKSTG - High-Wind Stow lock indicator
LOKDEG - Defocus lock indicator
DISKRG - array containing disk operations request data
 for submodule DSK

Local common: (MMICOM)

ONWORD - word in command string which is being syntax
 checked
IERR - error message number
NUMARY - array of decoded addressing parameters
A1 - ASCII command string containing one character
 per 16-bit word
KMAND - command number (1-39)
ADDRES - addressing used (1-7)
SOURCE - source of command:
 1 = CS console
 2 = OCS
 3 = DAS
 4 = command file
CFSORC - source of CFSTART command
NWORD - number of words in command string
CHRPOS - array of character positions of the words in
 the command string
NPBLOK - array containing the number of blocks in
 HCMAPG per addressing parameter

3.2.1.4.1.1.3 Internal Data Description

Miscellaneous local pointers and counters.

3.2.1.4.1.1.4 Flowchart

See Figure 3.2.1-2 for the MMI flowchart.

Figure 3.2.1-2 Flowchart-MMI

Figure 3.2.1-2 Flowchart-MMI (cont.)

Figure 3.2.1-2 Flowchart-MMI (cont.)

Figure 3.2.1-2 Flowchart-MMI (cont.)

Figure 3.2.1-2 Flowchart-MMI (cont.)

3.2.1.4.1.2 Submodule II - MMIWRD

3.2.1.4.1.2.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - Processing of the command string stops when two delimiters in a row are encountered.
- d. Processing - MMIWRD divides the command string into "words" (groups of ASCII characters separated by delimiters), and finds the character position of the beginning of each "word." Processing ends when two delimiters (space, comma, or slash) are encountered, or if the first character checked is a delimiter.
- e. Error messages and recovery - None

3.2.1.4.1.2.2 Data, Logic and Command Paths

Input data:

A1 - local common ASCII command string
FROM - character position to start processing
TO - character position to end processing

Output data:

NWORD - local common number of "words" in ASCII string
CHRPOS - local common 40-element array containing the character position of the beginning of each word

3.2.1.4.1.2.3 Internal Data Description

Miscellaneous local counters and pointers

3.2.1.4.1.2.4 Flowchart

See figure 3.2.1-3 for the MMIWRD flowchart.

3.2.1.4.1.3 Submodule III - MMICLK

3.2.1.4.1.3.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by MMI
- c. Constraints and limitations - None
- d. Processing - MMICLK is called by MMI to determine:

Figure 3.2.1-3 Flowchart-MMIWRD

1. If the command syntax is valid;
 2. If the command is allowable from its source;
 3. Which addressing mode is being used;
 4. If the addressing is valid for the given command; and
 5. If the command is allowable while LOKSTG or LOKDEG are set, or during an emergency command sequence being processed by the CMDPRC module.
- e. Error messages and recovery - Returns values for IERR and ONWORD if syntax or other errors are found.

3.2.1.4.1.3.2 Data, Logic and Command Paths

Input data (Local common):

- KMAND - zero value indicates check for command type, source validity, and emergency lock checks. Values from one to 39 indicate check for addressing type and validity.
- IAID - flag to indicate call by MMIAID (only command type or address type is checked)

Output data (local common):

- KMAND - command number returned from valid command check.
- ADDRES - addressing number returned from valid addressing check
- IERR - error number returned if syntax or other error found.
- ONWORD - word in string causing error, if any
- CHKBUFF - array of ASCII data for MMIAID

3.2.1.4.1.3.3 Internal Data Description

- ARGADD - a forty-word array whose values indicate which addressing and sources are valid for a command, and whether the command is allowable during emergencies. See Table 3.2.1-IV
- KMANDS - an 8 by 40 word array containing the ASCII representation of the 39 commands.
- ARGU - a seven-element array containing the ASCII representation of the seven addressing modes.

3.2.1.4.1.3.4 Flowchart

See figure 3.2.1-4 for the MMICLK flowchart

3.2.1.4.1.4 Submodule IV - MMINUM

INTERNAL DATA LAYOUT

APPLICATION MANMIF - MMICK

VARIABLE - ARGADD

Bit Position	PROGRAMMER	P. Orum	DATE
0		0	HC Addressing Allowed
			ARC " "
			HFC " "
3		3	SEGMENT " "
			WEDGE " "
			RING " "
6		6	FIELD " "
			NOT USED
8		8	Allowable from Command File
			DAS
			OCS
11		11	CS
12		12	Disallowed when LOKSTG set (STHIWIND)
			Disallowed when LOKDEG set (DEFOCUS)
14		14	Disallowed during emergency sequence (CMDRRRC)
			NOT USED

The above are indicated for the command whose number (KMAND) is the index to ARGADD if the appropriate bits are set "on."

Table 3.2.1-IV Description of ARGADD

Figure 3.2.1-4 Flowchart-MMCHK (cont.)

3.2.1.4.1.4.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - None
- d. Processing - MMINUM is called to decode the ASCII numeric representation into binary form, and store the results in local common NUMARY.

Prior to actually decoding the data, MMINUM optionally checks each ASCII number to insure that it has the proper number of characters, and after decoding, checks to make sure that the resultant number (N) is within range as follows:

<u>Addressing type</u>	<u>Number of characters</u>	<u>Range</u>
(1) Heliostat	Four	N/100: 1-29 MOD(N,100): 1 to the number of HCs in row N/100
(2) Arc	Same as heliostat	same as heliostat
(3) HFC	Two	N: 1-64
(4) Segment	Three	N/100: 1-5 MOD(N,100): 1-12, unless n/100=5, whence MOD(N,100): 4-9
(5) Wedge	Two	N: 1-12
(6) Ring	One	N: 1-5

- e. Error messages and recovery - Errors found in the number of characters, the presence of non-numeric characters, or the result being out of range cause IERR to be set. NUMARY is then cleared.

3.2.1.4.1.4.2 Data, Logic and Command Paths

Input data:

- FWORD - First word to decode
- TWORD - Last word to decode
- A1 - Local common ASCII command string
- CHRPOS - Local common character string pointer
- ICLK - 1-6 = type of check to make (1 = heliostat, 2 = arc, etc.
- other = no check to be made

ICON - 0 = integer conversion
1 = Hex conversion

Output data:

IERR - local common error number returned
ONWORD - local common word which caused error
NUMARY - local common array of converted numbers

3.2.1.4.1.4.3 Internal Data Description

- a. Array containing number of characters necessary for each addressing type; and
- b. Values to check the ranges against.

3.2.1.4.1.4.4 Flowchart

See figure 3.2.1-5 for the MMINUM flowchart.

3.2.1.4.1.5 Submodule V - MMIMAP

3.2.1.4.1.5.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by MMI
- c. Constraints and Limitations - all input data must have been validity checked.
- d. Processing - MMIMAP obtains lists of the heliostats which may be affected by a given command, for use by the CMDPRC module. The processing is handled in three distinct manners for (1) Segment, wedge or ring addressing; (2) Heliostat or arc addressing; and (3) HFC addressing.

1. Segment, Wedge or Ring Addressing - MMIMAP uses global arrays SEGPTG and SEGMPG to put lists of heliostat numbers from each desired segment, wedge or ring into global array HCMAPG. The index to SEGPTG is given by:

$$\text{INDEX} = (\text{RING} - 1) * 12 + \text{WEDGE}$$

where RING = Ring Number (range 1-5), and
WEDGE = Wedge number (range 1-12). For
Segment addressing:

$$\text{RING} = \text{SEG\#} / 100$$

and

$$\text{WEDGE} = \text{MOD} (\text{SEG\#}, 100)$$

Figure 3.2.1-5 Flowchart-MMINUM

For Ring addressing, the ring number is given and a loop is made with WEDGE varying from one to twelve, and for wedge addressing the wedge number is known, and a loop is made with RING varying from one to five to obtain each index to SEGPTG.

Now SEGPTG(INDEX) points to the beginning of the list of heliostats in this segment in SEGMPG. A loop is made, loading these heliostat numbers from SEGMPG into HCMAPG in pecking order. If local common word KMAND indicates that the "DECREASE" command is being processed the heliostat numbers are loaded into HCMAPG in reverse pecking order.

2. Heliostat and Arc Addressing - MMIMAP uses global arrays MDNPRG and MD2HCG to convert from MDAC heliostat numbers to HFC-HC numbers. For a given MDAC heliostat number (MDHC), the HFC-HC number is given by;

$$\text{HFCHC} = \text{MD2HCG} (\text{MDNPRG} (\text{MDHC}/100) + \text{MOD}(\text{MDHC}, 100))$$

For arc addressing, a loop is made through the MDAC heliostat number between the given pair of heliostat numbers. Checks are made to be sure that both the heliostat numbers in the given pair are in the same row and are both odd or even.

3. HFC Addressing - the HFC-HC numbers are calculated from the given HFC number by:

$$\text{HFCHC} = (\text{HFC}-1) * 32 + \text{IHC}$$

where IHC varies from one to 32.

- e. Error messages and recovery - All input data has been validity checked by MMINUM, except for checking to be sure that both HC numbers used in arc addressing are in the same row and are both odd or both even. These errors cause IERR to be set appropriately.

3.2.1.4.1.5.2 Data, Logic and Command Paths

Input data:

SEGPTG - contains pointers to SEGMPG
SEGMPG - contains HFC-HC numbers by segment in pecking order
MDNPRG - contains the total number of heliostats in all rows numbered lower than the index
MD2HCG - contains HFC-HC numbers ordered by rows
NUMARY - array of input heliostat, HFC, segment, wedge, or ring numbers

ADDRES - local common addressing mode to decode:

- 1 = HC
- 2 = Arc
- 3 = HFC
- 4 = Segment
- 5 = Wedge
- 6 = Ring

KMAND - used to check for "DECREASE" command

Output data:

HCMAPG - global array of HFC-HC numbers

IERR - local common error flag

3.2.1.4.1.5.3 Internal Data Description

Internal pointers used as follows:

- INUM - pointer to NUMARY
- IMAP - pointer to HCMAPG
- IPTG - pointer to SEGPTG
- IMPG - pointer to SEGMPG
- ROW - pointer to MDNPRG
- 12HC - pointer to MD2HCG

3.2.1.4.1.5.4 Flowchart

See figure 3.2.1-6 for the MMIMAP flowchart

3.2.1.4.1.6 Submodule VI - MMIERR

3.2.1.4.1.6.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI if command errors are found
- c. Constraints and limitations - none
- d. Processing - MMIERR produces error messages in two formats:
 - 1. A specific error message.
 - 2. A generic error message in which the offending part of the command string is echoed back along with a short text string indicating the error type.

See Table 3.2.1-III for a list of these messages.

For producing a specific error response, MMIERR simply loads a text string from local data into an output buffer and Enques it to the EXTINF module.

Figure 3.2.1-6 Flowchart-MMIMAP

Figure 3.2.1-6. Flowchart-MMIMAP (cont.)

Figure 3.2.1-6 Flowchart-MMIMAP (cont.)

For producing a generic error response, MMIERR builds an output buffer consisting of the offending word in the command string and a short message. The word from the command string (truncated to eight characters if it is longer) is loaded into the output buffer in the same character position as it was in the command string, and the message loaded into the left side of the buffer, if it will fit, or into the right, if not. If the output is to the CS console, additional words are added to the output string before the word causing the error, and before the message string, in order to have the error word appear in a complementary color to the message. The colors are TBD.

- e. Error messages and recovery - MMIERR itself will not flag any errors.

3.2.1.4.1.6.2 Data, Logic and Command Paths

Input data (local common):

ONWORD - word in command string causing the error; Ø
implies specific message
CHRPOS - character position of ONWORD
IERR - error message number
SOURCE - code indicating where to send message (OCS, DAS
or CS console)

Output data:

ASCII string enqueued to EXTINF.

3.2.1.4.1.6.3 Internal Data Description

MMIERR contains arrays of error messages and an output buffer.

3.2.1.4.1.6.4 Flowchart

See Figure 3.2.1-7 for the MMIERR flowchart.

3.2.1.4.1.7 Submodule VII - MMIRSP

3.2.1.4.1.7.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - None
- d. Processing - MMIRSP is called by MMI to output command success rates returned by CMDPRC in HCMAPG. Each "block"

Figure 3.2.1-7 Flowchart-MMIERR

of heliostat numbers given to CMDPRC in HCMAPG will have a "total affected" returned in HCMAPG. For "N" blocks, the first "n" elements of HCMAPG will contain these totals.

1. A loop is made through the addressing parameters in the command string. Each addressing parameter (two parameters for ARC addressing) is loaded from the command string into an output buffer (if the output is to be sent to the CS console, additional words are added to the output data); then a loop is made through the number of blocks for this addressing parameter as indicated by local common array NPBLK (the number of blocks per addressing parameter will be one for heliostat, HFC, ARC and segment addressing, and may be up to five for Wedge, and up to 12 for Ring addressing).
2. The loop through the blocks for each addressing parameter consists of encoding the values returned in HCMAPG and loading the ASCII results into the output buffer, separated by commas. The output buffer pointer is checked each time, and after 80 output characters are loaded, the buffer is enqueued to the source of the command.
3. After the loop (2) is complete, processing returns to step (1) and continues until all the addressing parameters have been processed.

3.2.1.4.1.7.2 Data, Logic and Command Paths

Input data:

WORD1 - first word in command string containing an addressing parameter.
WORD2 - as above, but the last word
ADDRES - used only for ARC addressing
HCMAPG - global common word containing the totals to output

Output data:

ASCII string enqueued to the source of the command.

3.2.1.4.1.7.3 Internal Data Description

MMIRSP contains a buffer to hold the ASCII data to output, and a set of color codes for CS console output.

3.2.1.4.1.7.4 Flowchart

See Figure 3.2.1-8 for MMIRSP flowchart.

3.2.1.4.1.8 Submodule VIII - MMIAID

3.2.1.4.1.8.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - none
- d. Processing -
 1. After being called by MMI upon receipt of a "HELP" command, MMIAID checks local common NWORD. If NWORD = 1, a general aid message is loaded one line at a time and enqueued to EXTINF.
 2. If NWORD is greater than 1, MMIAID calls MMICLK to determine if the remaining words in the command string are valid commands or valid arguments. If the word is a valid command, an output buffer consisting of this command followed by a list of its valid arguments is enqueued to EXTINF. If the word is a valid addressing character (or "ALL"), the output buffer will consist of the addressing character followed by a short description of the addressing. If the word is neither a valid command nor a valid addressing character, the output buffer will consist of the word in question followed by a message indicating its validity.
- e. Error messages and recovery - words in the command string which are neither valid commands nor addressing parameters are flagged as described in part "d" above.

3.2.1.4.1.8.2 Data, Logic and Command Paths

Input data (local common):

- A1 - ASCII string
- SOURCE - flag indicating where to output data
- CHKBUF - array containing ASCII data from MMICLK

Figure 3.2.1-8 Flowchart-MMIRSP

Output data:

ASCII output buffer Enqued to EXTINF

3.2.1.4.1.8.3 Internal Data Description

MMIAID has local arrays containing ASCII help data.

3.2.1.4.1.8.4 Flowchart

See figure 3.2.1-9 for the MMIAID flowchart.

3.2.1.4.1.9 Submodule IX - MMISTR

3.2.1.4.1.9.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - none
- d. Processing - MMISTR is called by MMI to complete the processing of a STATUS request and set global common words ISTATG for the STATUS module. First MMISTR calls MMICLK to determine the addressing used ("H," "R," or "ALL"), and if this test fails, an internal test is made for "M" (Mode) addressing. The four addressing modes are treated as follows:
 1. "M" (Mode) addressing - a check is made against an internal list of mode characters (TRK, BCS, STB, etc.), and after a match is found, the now known mode number is loaded into ISTATG(1).
 2. "H" (Heliostat) addressing - MMINUM is called to decode the MDAC heliostat number, then MMIMAP is called to obtain the HFC-HC number. ISTATG(1) is set to 14 to indicate heliostat addressing and ISTATG(2) is set to the HFC-HC number.
 3. "R" (Ring) addressing - MMINUM is called to decode the ring number, a check is made to insure that the ring number is between one and five, then ISTATG(1) is set to 15 to indicate a Ring request, and ISTATG(2) is set to the Ring number.
 4. "ALL" (Field) addressing - ISTATG(1) is set to 13 to indicate a Field request.

Figure 3.2.1-9 Flowchart-MMIAID

In all cases ISTATG(3) is set equal to local common word SOURCE to tell STATUS where to send the output.

- e. Error messages and recovery - errors detected in any of the above processes will cause IERR to be appropriately set and processing ended.

3.2.1.4.1.9.2 Data, Logic and Command Paths

Input data (local common):

A1 - ASCII command string
SOURCE - source of request

Output data:

ISTATG - global array for use by the STATUS module
IERR - local common error flag

3.2.1.4.1.9.3 Internal Data Description

MMISTR contains a list of three-digit ASCII mode codes as follows (in order by mode number):

TRK, STB, BCS, TRN, STO, AL1, AL2, MRK, DPO, WSH, INI, and OFF.

See section 3.2.6, STATUS, for more details of the "STATUS" command formats.

3.2.1.4.1.9.4 Flowchart

See figure 3.2.1-10 for the MMISTR flowchart.

3.2.1.4.1.10 Submodule X - MMIREF

3.2.1.4.1.10.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by MMI
- c. Constraints and limitations - CS console not in "scroll" mode.
- d. Processing - MMIREF clears the CS console screen and rewrites the two ALARMS areas, the synchronous STATUS area, and outputs global words MODEG and GTIMEG. Data is output via the EXTINF module.
- e. Error messages and recovery - none

Figure 3.2.1-10 Flowchart-MMISTR

3.2.1.4.1.10.2 Data, Logic and Command Paths

Input data:

MODEG - field status information
GTIMEG - local time and date

Output data:

ASCII string enqueued to EXTINF

3.2.1.4.1.10.3 Internal Data Description

MMIREF contains variables defining the CS console display.

3.2.1.4.1.10.4 Flowchart

See figure 3.2.1-11 for the MMIREF flowchart.

3.2.1.4.1.11 Submodule XI - DSK

3.2.1.4.1.11.1 Description

- a. Language used - FORTRAN
- b. How invoked - activated by MMI
- c. Constraints and limitations - Disk operations are aborted if they are active when an emergency command is received.
- d. Processing - DSK checks global common word DISKRG(1) to determine which of its submodules to call. All disk updating is done through MAXNET to the prime and backup disk files.
- e. Error messages and recovery - none; each submodule reports its own errors.

3.2.1.4.1.11.2 Data, Logic and Command Paths

Input data:

DISKRG(1) - contains a command number set by MMI, used to determine which submodule to call as follows:

<u>DISKRG(1)</u>	<u>Command</u>	<u>Submodule</u>
28	UPAIM	DSKAIM
29	UPBIAS	DSKBIA

3.2.1.4.1.11.3 Internal Data Description

Miscellaneous data only.

Figure 3.2.1-11 Flowchart-MMIREF

3.2.1.4.1.11.4 Flowchart

See Figure 3.2.1-12 for the DSK flowchart.

3.2.1.4.1.12 Submodule XII - DSKAIM

3.2.1.4.1.12.1 Description

- a. Language used - FORTRAN
- b. How invoked - called DSK
- c. Constraints and limitations - none within the constraints upon DSK.
- d. Processing - DSKAIM updates the heliostat aim-point array file from card-image input data.
 1. Since DSKAIM must check the validity of the data on each card, a scratch disk file is used for temporary data storage as the cards are read. Pertinent data from each card-image record are:
 - a) MDAC heliostat numbers;
 - b) Aim-point array numbers; and
 - c) Aim-point X, Y, and Z coordinates.

As the cards are read, the above data is validity checked before the data is packed into the scratch output buffer, which is written to the scratch file when full. When an end of file on the input is reached, the buffer is written if it is partially filled.

2. After all card-image data has been checked and written to the temporary scratch file, this file is rewound and the data read from the scratch file into the scratch output buffer. A loop is then made through each heliostat's data in the buffer to determine the record number of the aim-point array file to read. This aim-point record is read, the aim-point X, Y, and Z values are replaced, and the heliostat number in the scratch buffer is zeroed to indicate that its processing is completed. The rest of the scratch buffer is then checked to see if there is any more updating to perform on the given aim-point file record (NOTE: this will not happen if only one aim-point array number is being processed. If more than one array number is

Figure 3.2.1-12 Flowchart-DSK

updated, disk I/O will be minimized by ordering the card-image input by heliostat number.) This process repeats until the last scratch record has been finished.

e. Error messages and recovery - the following input errors will be flagged and processing stopped:

1. Card-image input read error
2. Array number out of range or invalid
3. Aim-point coordinates invalid
4. MDAC heliostat number invalid

Error message(s) include the offending card's numerical position.

Disk I/O errors will be flagged and processing stopped.

3.2.1.4.1.12.2 Data, Logic and Command Paths

Input data:

DISKRG(2) - aim-point array number to update
 DISKRG(3) - card-image input device code
 Card-image data - heliostat number, aim-point array number, and aim-point coordinates

Output data:

Written to the aim-point array file

Algorithms:

The aim-point coordinates are checked to be sure they lie within the receiver volume.

3.2.1.4.1.12.3 Internal Data Description

Scratch buffer format (126 words), seven 16-bit words per heliostat

1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Aimpoint				Array HFC				Aimpoint				Array HFC		etc.
X,Y,Z				# HC#				X,Y,Z				# HC#		

7 words/heliostat

7 words/heliostat

This format allows the 126-word scratch buffer to hold data from 18 input cards.

DSKAIM also has arrays containing ASCII error messages.

3.2.1.4.1.12.4 Flowchart

See Figure 3.2.1-13 for the DSKAIM flowchart.

Figure 3.2.1-13 Flowchart- DSKAIM

Figure 3.2.1-13 Flowchart-DSKAIM (continued)

Figure 3.2.1-13 Flowchart-DSKAIM (continued)

3.2.1.4.1.13 Submodule XIII - DSKBIA

3.2.1.4.1.13.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by DSK
- c. Constraints and limitations - none within the constraints upon DSK
- d. Processing - DSKBIA is called by DSK to process the "UPBIAS" command and update the heliostat bias file. DSKBIA calculates the record number and the two words (Azimuth and Elevation) to replace with the new value, reads this record, replaces the two words, and writes the record back to the bias file.
- e. Error messages and recovery - disk I/O errors are reported.

3.2.1.4.1.13.2 Data, Logic and Command Paths

Input data (global common):

DISKRG(2) - HFC-HC number
DISKRG(3) - New Azimuth value
DISKRG(4) - New Elevation value

Output data:

Written to the heliostat bias file.

Algorithms:

Calculation of record number and words in record to replace:

$$\text{REC NUM} = (\text{HFCHC} - 1) / 64 + 1$$
$$\text{AZ WORD} = (\text{HFCHC} - (\text{RECNUM} - 1) * 64) * 2$$
$$\text{EL WORD} = \text{AZ WORD} + 1$$

3.2.1.4.1.13.3 Internal Data Description

Bias file format:

See section 3.2.7, DBINIT, for the bias file format.

DSKBIA contains an array of error messages.

3.2.1.4.1.13.4 Flowchart

See figure 3.2.1-14 for the DSKBIA flowchart

Figure 3.2.1-14 Flowchart-DSKBIA

3.2.1.4.1.14 Submodule XIV - CFO

3.2.1.4.1.14.1 Description

- a. Language used - FORTRAN
- b. How invoked - activated by MMI
- c. Constraints and limitations - processing stops if an emergency sequence is in operation.
- d. Processing - CFO is the controlling program for the submodules used to process command files.
 - 1. CFO calls CFOPOS to position on the command file specified in CFNAMG.
 - 2. If no errors are encountered while positioning on the file, CFO calls CFOGET to read the record and enqueue the command string to MMI.
 - 3. CFO calls CFOMSG to report any error conditions or results to the CS console and then exits.
- e. Error messages and recovery - None (see CFOMSG)

3.2.1.4.1.14.2 Data, Logic and Command Paths

Input data:

CFWATG - global common, additional wait time
CFABOG - global common, abort flag
CFNAMG - global common, command file name
IERR - local common, condition codes

Output data:

None

3.2.1.4.1.14.3 Internal Data Description

The command strings will reside in the directoried SED source partition CFM. This partition will be sized at 100k bytes and contain a maximum of 100 source files.

Each record will have the following format:

SSSSCCCC....

where SSSS is the time delay in seconds,

and CCCCC.... is the command string.

The right justified delay is the time to wait before implementing the command string CCCCC....

Each record may contain up to 80 bytes (characters): four bytes of time delay, and up to 76 for the command string.

3.2.1.4.1.14.4 Flowchart

See Figure 3.2.1-15 for the CFO flowchart.

Figure 3.2.1-15 Flowchart - CFO

3.2.1.4.1.15 Submodule XV - CFOPOS

3.2.1.4.1.15.1 Description

- a. Language used - FORTRAN and MODCOMP Assembler
- b. How invoked - Called by CFO
- c. Constraints and limitations - None
- d. Processing - CFOPOS is the submodule that positions on the file name specified in CFNAMG.
 - 1. CFOPOS reads the SED directory to find the file name. If the file name is not in the directory an error flag is set.
 - 2. If there is no directory in this partition another error flag is set.
 - 3. If the file name is found the starting record number is placed in the compressed read routine and CFOPOS returns to the calling program.
- e. Error messages and recovery - None (see CFOMSG)

3.2.1.4.1.15.2 Data, Logic and Command Paths

Input data:

CFNAMG - global
CFM - command file disk partition

Output data:

IERR - local common
WRECK - record number of file

3.2.1.4.1.15.3 Internal Data Description - None

3.2.1.4.1.15.4 Flowchart

See Figure 3.2.1-16 for the CFOPOS flowchart.

3.2.1.4.1.16 Submodule XVI - CFOGET

3.2.1.4.1.16.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by CFO
- c. Constraints and limitations - None

Figure 3.2.1-16 Flowchart - CFOPOS

- d. Processing - CFOGET reads the records from the file that has been positioned by CFOPOS. The reads are done using the compressed read routines.
 - 1. CFOGET decodes the delay time and if good computes a new total delay time before this message is to be sent to MMI.
 - 2. A message is sent to the CS console indicating the delay time before this command is to be executed.
 - 3. CFOGET then calls the wait routine to delay until the time has expired and then enques the command to MMI.
 - 4. Flags are reset and error flags set if necessary and CFOGET returns.

e. Error messages and recovery - None (see CFOMSG)

3.2.1.4.1.16.2 Data, Logic and Command Paths

Input data:

CFABOG - global common
CFWATG - global common
Records from disk file

Output data:

CFABOG - global common
CFWATG - global common
IERR - local common
Enque to MMI

3.2.1.4.1.16.3 Internal Data Description

Total delay time computed from CFWATG and decoded delay time.

3.2.1.4.1.16.4 Flowchart

See Figure 3.2.1-17 for the CFOGET flowchart.

3.2.1.4.1.17 Submodule XVII - CFOMSG

3.2.1.4.1.17.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by CFO and CFOGET
- c. Constraints and limitations - None

Figure 3.2.1-17 Flowchart - CFOGET

d. Processing - CFOMSG is called to send informational and error messages to the CS console and logger.

1. CFOMSG determines if the message is informational or an error and sets the appropriate color.
2. It then encodes the messages with the appropriate format text based on the data in IERR.
3. The message is written to the CS console and logger. If the CS console enqueue fails, a message is written to the system console and CFOMSG returns to the caller.

e. Error messages and recovery -

IERR = 1 command ok display new wait time
IERR = 2 command file done display records processed
IERR = 3 bad delay time
IERR = 4 CFABORT entered
IERR = 5 no directory in the CFM partition
IERR = 6 file entered not found
IERR = 7 Enqueue to MMI failed

3.2.1.4.1.17.2 Data, Logic and Command Paths

Input data:

CFNAMG - global common
IERR - local common
TICKS - local common
WRECK - local common

Output data:

IERR - global common
Messages to CS console, logger, TTY

3.2.1.4.1.17.3 Internal Data Description

Format statements corresponding to the IERR indicators.

3.2.1.4.1.17.4 Flowchart

See Figure 3.2.1-18 for the CFOMSG flowchart.

Figure 3.2.1-18 Flowchart - CFOMSG

Figure 3.2.1-18 Flowchart - CFOMSG (Continued)

3.2.1.5

Interface Description

Input ASCII commands are enqueued to MANMIF through the five queues in MMI. Operator entered commands are enqueued by the EXTINF module, command file commands by MANMIF submode CFO, and the Receiver Trip function may enqueue a DEFOCUS command. Responses to commands are enqueued to EXTINF by MMIRSP or MMIERR. Responses to commands are sent to the source of the command (except for emergency commands, where the response is sent to the source of the CFSTART command). See tables 3.2.1-V and 3.2.1-VI for these message formats.

MANMIF communicates with the CMDPRC module via global words CPGG, HCPAPG and CPPRTG, and with the STATUS module through global words ISTATG. Communication with submodule DSK is via global words DISKRG, and with submodule CFO via global words CFABOG, CFWATG and via initial enqueue.

3.2.1.6

Test Requirements

The MANMIF module's main routine, MMI, must be tested to be sure that each type of command is being properly processed by its submodules. The submodules should be tested as follows:

MMIWRD - insure that proper values of NWORD and CHRPOS result for all types of character strings.

MMICHK - insure that commands and addresses are properly identified and that addressing and source allowability checks work properly

MMINUM - insure that the validity checks for the numerical data work properly, and that the ASCII input data is correctly decoded.

MMIMAP - insure that HCPAPG has the proper format and the calculated heliostat numbers are correct.

MMIERR - insure proper error message for a given error code number.

MMIRSP - insure that the values returned in HCPAPG are properly displayed.

MMIAID - insure that the information provided is correct for the request.

MMISTR - insure that global words ISTATG are properly set for all STATUS command formats.

MMIREF - insure that the CS console is properly refreshed and that the status display is correct.

APPLICATION	OCS/DAS - HAC	MESSAGE TYPE	OCS/DAS COMMANDS
-------------	---------------	--------------	---------------------

DATE _____

MESSAGE LAYOUT

APPLICATION HAC OCS/DAS HAC
MESSAGE TYPE ENVIRONMENTS

PROGRAMMER P. Orum DATE

1	HEADER			1	ASCII H = HAC Originator
					Message byte count
	E	M			
5	R	S	5	ASCII MSG	ERR
	R	G			
	A	E			ASCII
	L	R			
	A	R			
10	R	O	10		
	M	R			
	M	S*			
	E	T			
	S	A			
	S	T			
15	A		15		
	G				
	E				
	T				
	E				
	X				
	T				
20			20		
25			25		
30			30		
78			78		
79			79		
80	CHECKSUM		80	Checksum	

Table 3.2.1-VI HAC-OCS/DAS Environment Format

DSK - insure that the proper submodule is called.

DSKAIM - insure that error detection and file updating is correct.

DSKBIA - same as for DSKAIM.

CFO - insure that the command strings are properly enqueued to MMI and that the delay times are properly decoded.

CFOPOS - position the file specified by scanning the SED Directory.

CFOGET - read the positioned command file.

CFOMSG - display informational and error messages.

3.2.2

COMMAND PROCESSOR MODULE (CMDPRC)

3.2.2.1

Purpose

The purpose of the Command Processor Module is to convert high-level operator commands from the Man-Machine Interface Module (MANMIF) into explicit commands for the field of heliostats. These commands are output by the Field Communications Module (FLDCOM) to the field of heliostat controllers (HCs). Phase II command processing is designed as follows:

- a. CMD (Command Processor) - This task checks commands sent by the MANMIF module for reasonableness (proper orientation) and separates the HCs involved into HC number arrays depending upon their current orientation. It determines whether a sequence (multiple HC commands required) is needed, whether a new sequence may be added (16 simultaneously is maximum), and generates output commands for those HCs which may be immediately commanded. CMD consists of 14 submodules and activates tasks GET and SEQ as needed.
- b. GET (Get Disk Data for HC Commands) - This task is activated by CMD or SEQ if disk data is needed to complete the operator input command. CMD activates GET for those commands that require disk data prior to any HC commands being completed. GET is activated by SEQ for those commands that require disk data after a corridor walk to complete a sequence. GET consists of eight submodules.
- c. SEQ (Sequence Control Processor) - This task is responsible for monitoring and commanding HCs involved in one or more concurrent sequences. It is activated by CMD whenever a new sequence must be processed. When one or more sequences are active, SEQ reactivates itself via a system timer to monitor one particular sequence per "visit". SEQ activates GET for those commands that require disk data after a corridor walk to complete a sequence. SEQ is activated by GET to terminate a sequence. SEQ consists of eight submodules.
- d. BHC (Build Heliostat Commands) - This task is activated once each frame by the FCP task following output of HC commands. BHC is responsible for building HC commands in a format such that FCP can output them to the field of heliostat controllers. Since only one HC command per frame may be sent to the HFC, a HC command priority scheme is used by BHC when searching for HC commands. If identical HC commands are found for HCs connected to the same HFC, the BHC task will compress these commands into a single command. BHC consists of one submodule.

e. BHI (Build HFC Initialization Commands) - This task will be activated by FCP in each frame. This will occur just after FCP processes the last status response input from the field. BHI is responsible for monitoring HFC status, building HFC initialization commands, if required, and placing them in the output buffer used by FCP. BHI consists of two submodules. Via the flags and buffers that CMD, GET, and SEQ set for BHC, the Command Processor Module becomes the interface between certain asynchronous man-machine activities and the field-oriented synchronous ones.

3.2.2.2

Requirements

3.2.2.2.1

Design Requirements

The software requirements listed in Section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980 that apply to the CMDPRC module are:

- a. Control operational phase sequences as required for integrated control of a field of up to 2048 heliostats;
- b. Generate and transmit heliostat mode commands as required by the phase sequences during either operational or maintenance phases while maintaining safe beam control
- c. Maintain safety through controlled beam movement and inclusion-area processing; (inclusion-area processing not applicable to this module);
- d. Transmit emergency DEFOCUS command upon receiver trip;
- e. Provide automatic HFC initialization and the capability to command heliostats away from the receiver following initialization within 60 seconds after power restoration.

3.2.2.2.2

Derived Requirements

The software requirements listed in Section 3.2.1.2 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980, that apply to the CMDPRC module are:

- a. Check command arguments for reasonableness;
- b. Check heliostat's state for ability to execute commands;
- c. Translate operational commands and command sequences into individual HC commands;
- d. Maintain commanded heliostat mode table;
- e. Allow up to 16 command sequences at any one time;

- f. Obtain individual target or HC initialization information from disk; and
- g. Combine HC commands into HFC groups for faster throughput, whenever possible.

Further software requirements which are an expansion of those above and others, not stated, are:

- h. Allow the STHIWIND and HOLD command processing to rob heliostats from existing sequences;
- i. Ignore processing of heliostats which are involved in automatic operations except for STHIWIND;
- j. Allow only one emergency sequence (STHIWIND) at any given time;
- k. Provide feedback to MMI on the "degree of success" (how many HCs are in proper orientation) for each operator input command;
- l. Provide appropriate error-message feedback to MMI if no HCs can respond to the operator input command;
- m. Obtain orientation angles for Stow, Alt1stow, Alt2stow, and Wash positions from disk;
- n. Ability to stow and retrieve the field tracking configuration on disk;
- o. Terminate all sequences in the HAC upon detection of full-field power loss;
- p. Allow only one sequence to walk a given corridor at any particular time due to beam safety constraints;
- q. Reestablish management of current sequences in the backup HAC upon HAC failover;
- r. Provide a priority scheme for HC output commands;
- s. Determine eligible HCs in pecking-order-dependent operator commands; and
- t. Automatically reinitialize any HFC which reports a power loss.

3.2.2.3

Design Approach

The following is a list of assumptions used in the design of the CMDPRC module:

- a. Any data fetched from memory-resident or disk-resident files

has been checked for beam safety and/or reasonableness during off-line operations;

- b. All files referenced for HC data have been created and initialized;
- c. If task GET experiences any disk error, an alarm message is sent to Alarms Output task (ALO), the entire disk is considered unusable, and HAC failover criteria is established; and
- d. If a full-field power loss occurs and is then restored, it is assumed all sequences have been terminated prior to subsequent HC initialization.

Terms which are used in the following design approach are defined below:

- a. Orientation - the current mode/submode and position compare information which establishes a heliostat's status;
- b. Command phase - generation of an HC output command based upon the input command and the HC's orientation;
- c. Sequence - the actions and/or necessary data required to move a set of HCs through one or more corridors to the desired destination;
- d. Sequence command - an input command possibly requiring more than one HC command (multiple command phases) to be sent to the field over a predetermined time interval (Example: track to stow via corridors);
- e. Critical (emergency) commands - those input commands which require quick movement (or cessation of movement) of HCs for safety purposes; these commands will have the "critical command" bit set in the HC's HCCMDG word; type 1 critical commands are DEFOCUS and STHIWIND; type 2 critical commands are HOLD and LOAD;
- f. Software offline - the status condition produced when the operator wishes to isolate a normally-operating HC from further positioning (until an ONLINE command is entered for the HC);
- g. Field error offline - the status condition produced when the software detects an abnormal field status for an HC; the abnormal status bits in the HC's HCST2G word are: communication error, serious alarm, unmarked, and time-out (Note: the ONLINE command will reset all except the unmarked bit);
- h. Block - a set of HC numbers passed to task CMD from MMI

which represent an operator-addressable group of the entire field (i.e., arc, segment, wedge, ring); the degree of success in commanding each input block is reported back to MMI for each input command;

- i. Sequence state - sequences can exist in one of three states: non-corridor gather, corridor(s) management, and waiting for corridor(s);
- j. Non-corridor gather - the command phase of a sequence which requires collecting a group of HCs at the upper or lower-limit points of one or more corridors; the HCs at the upper or lower-limit points of one or more corridors; the HCs are not moving within any corridors;
- k. Corridor management - the command phases of a sequence which require corridor-walk commands, HC timeout checks, and issuance of the appropriate beam-pointing commands to those HCs completing the corridor walks;
- l. Waiting for corridor(s) - the command phase of a sequence which examines the corridor status words (CORRSG) for all corridor(s) required; when all corridor(s) are free, the sequence state is changed to corridor management;
- m. Enque - operating system service call which allows one task to activate another and simultaneously pass a data buffer;
- n. Deque - operating system service call which allows one task to retrieve the contents of a data buffer passed by the task (using Enque);
- o. Internal HC numbers - a contiguous set of integers in the range: one is less than or equal to N which is less than or equal to 2048 used to index into data arrays; MDAC numbers input by operator(s) are translated into the internal numbering system by the MANMIF module.

3.2.2.3.1

Functional Allocations

The Command Processor Module is decomposed into the following functional areas:

- a. Check input command reasonableness and translate into individual HC commands;
- b. Fetch disk-resident data for certain input commands;
- c. Manage sequence commands;
- d. Monitor HFC status and reinitialize if necessary; and

- e. Build and combine HC commands on a priority basis for output to the field of HCs.

This function is shown in Figure 3.2.2-1.

The requirements for module CMDPRC are met by the five tasks briefly described in the purpose section above. Their interrelationship is shown on the module overview, Figure 3.2.2-2. Only the most pertinent global common arrays are shown.

3.2.2.3.1.1

Task Activations

There are ten activations into the CMDPRC module:

- a. Module MANMIF activates task CMD whenever a new operator-input command needs to be processed; the MANMIF task (MMI) suspends itself until resumed by CMD;
- b. CMD activates task SEQ whenever an input command requires multiple HC commands (sequence); CMD builds the appropriate HC commands; if some HCs involved can be moved immediately (not requiring corridor walks); CMD will not initiate any corridor walks itself;
- c. CMD activates task GET when an input command needs disk data to build HC commands or requires data to be saved on disk;
- d. SEQ reactivates itself periodically depending on sequence load and timing decisions;
- e. SEQ activates GET whenever a sequence has completed a corridor walk and now requires disk data for the final phase of HC commands;
- f. GET activates SEQ whenever the final HC commands have been prepared for a sequence and the sequence is to be deleted;
- g. Module FLDCOM activates task BHI every frame to determine if any HFC needs to be reinitialized;
- h. Module FLDCOM activates task BHC every frame to detect, build, and group (by HFC) all types of HC commands except sun-position data;
- i. Module MAXIVM activates SEQ to terminate all sequences when it detects a full-field power loss; and
- j. Module MAXIVM activates SEQ to reestablish sequence management whenever a HAC failover occurs.

Data transfer takes place via global common or disk files. Pertinent areas of global common are shown on the overview figure (Figure 3.2.2-2) as well as the specific disk files accessed by task GET.

Figure 3.2.2.-1 Hierarchy Diagram for the Command Processor Module (CMDPRC)

Legend:

Activation: - - - - -

Data Flow: _____

Synchronous Task: *

Figure 3.2.2-2

Module CMDPRC Overview

3.2.2.3.1.2

Task Satisfaction of Derived Requirements

The functions of the five tasks in the CMDPRC module are:

- a. CMD - Evaluate operator input commands for reasonableness and executability; determine current orientation for all HCs involved in the input command; determine whether a sequence is required by examining the input command and current orientations; invoke the error exit if 16 sequences active and input command requires sequencing; rob HCs in an active sequence for the HOLD and STHIWND emergency input commands; respond to emergency DEFOCUS command; provide task BHC with a count of type 1 and 2 critical commands; build HC commands for those HCs which may be commanded immediately; prepare buffers to be used by tasks GET and SEQ; activate GET if HC command data is not memory-resident; allocate new sequences; activate SEQ if a new sequence is required; report back to the MANMIF module how many HCs were able to participate in the input command; report an error number to the MANMIF module if no HCs were able to participate in an input command. This task meets derived requirements "a" thru "e," and "h" thru "l," and "s."
- b. GET - Determine disk data request type and build appropriate HC commands after disk access; fetch HC Coordinates data and HC Bias data for LOAD commands; fetch Stow azimuth/elevation angles for final phase of STOW commands; fetch Alt1stow azimuth/elevation angles for final phase of ALT1STOW commands; fetch Alt2 stow elevation angle data from disk for final phase of ALT2STOW commands; fetch Wash azimuth/elevation angles for WASH commands; fetch aim-point data by aim-point array number for AIMPOINT commands; write field tracking configuration for SAVE commands; fetch field tracking configuration data for RESTORE commands; report any disk errors to the ALARMS module via global common; activate SEQ after building HC commands for final phase of sequence commands. This task meets derived requirements "c," "d," "f," "m," and "n."
- c. SEQ - Accept (Deque) new sequences from CMD; determine whether a sequence must wait for corridors or join the corridor management group of sequences which are actively moving and monitoring their set of HCs; recompute the minimum expected time and maximum expected time associated with an active sequence monitoring; determine which non-waiting sequence must be analyzed during "visit"; gather HCs at their respective CULPs or CLLPs; tag any HC which does not report position-compare by the sequence phase maximum time (set HC's timeout bit); build HC commands for initiating corridor walks; reactivate itself depending on sequence loading and timing decisions; activate GET

whenever disk data is needed to complete the sequence; reorder the active-sequence list whenever a sequence has been completed and deleted; examine waiting sequences to detect one or more candidates eligible for insertion into the active-sequence list; manage lists of HCs belonging to the individual sequences; allow deletion of all sequences upon detection of a full-field power loss; allow assumption of control of existing sequences upon HAC failover. This task meets derived requirements "b" thru "e," and "o" thru "q."

- d. BHC-Scan HC-Command array for new HC commands; act on any type 1 or type 2 commands first; build and combine HC commands for the appropriate HFCs; format these similar commands for output transmission by task FCP. This task meets derived requirements "g" and "r."
- e. BHI-Scan HFC status array to detect any HFCs requesting an initialization series of commands; relieve the operator of the HFC reinitialization duties. This task meets derived requirement "t."

3.2.2.3.2

Resource Budgets

This section represents currently available module information.

a. Memory requirements:

- 1. CMD - 12K
- 2. GET - 9K
- 3. SEQ - 10.25K
- 4. BHC - 2.5K
- 5. BHI - 2K

b. Timing:

- 1. CMD - asynchronous upon operator input
- 2. GET - asynchronous from CMD or SEQ
- 3. SEQ - asynchronous from CMD or GET; periodic when active sequences dictate
- 4. BHC - synchronous after FCP outputs commands available in global common buffer CMDBFG (55 msec steady state)
- 5. BHI - synchronous after FCP processes last status response (5 msec steady state)

c. Disk files:

- 1. HC Coordinates (HCC) - 20,480 bytes, 64 records
- 2. HC Biases (HCB) - 8,192 bytes, 32 records
- 3. Aim-point file (AIM) - 524,288 bytes total, 2,048 records (words 1-100 of each record)
- 4. Alt1stow AZ/EL angles (AL1) - 8,192 bytes, 32 records

5. Alt2stow EL angle (AL2): 8,192 bytes, 32 records
6. Wash AZ/EL angles (WSH): 8,192 bytes, 32 records
7. Tracking Configuration Snapshot (AIM): 524,288 bytes, 2048 records (words 123-128 of each record) same file as item 3 above.
8. Stow AZ/EL angles (STO): 8,192 bytes, 32 records

d. Disk accesses:

GET - maximum is 4096 for field addressing LOAD command

e. Magnetic tape access - none

f. Task priorities:

The tasks within the Command Processor module are responsible for qualifying and translating operator commands into HFC-compatible commands. They need a priority number just below that of the synchronous timing and field input/output tasks due to command through-put requirements. CMD has higher priority than GET or SEQ because the MMI task is suspended until CMD's completion.

1. CMD - 115
2. GET - 120
3. SEQ - 125
4. BHC - 65
5. BHI - 60

3.2.2.4 Design Description

3.2.2.4.1 Module Structure

The structure of module CMDPRC is depicted in the overview figure (Figure 3.2.2-2). The five tasks communicate via scheduling (MAX IV REX Activate or Enque or its FORTRAN equivalent), global common, and various operational disk files. These tasks and their associated submodules are briefly described below:

a. CMD - Command processor task (see Figure 3.2.2-3)

1. CMDSCK - orientation test control
2. CMLSAL - sequence allocation
3. CMDTRK - track-the-target processor
4. CMDDSK - disk packet build
5. CMDPOS - AZ/EL-pointing processor
6. CMDSBY - track-the-CULP processor
7. CMDSDN - down-corridor sequence preprocessor

Figure 3.2.2-3 CMD Hierarchy

8. CMDBCS - track the BCS-target processor
9. CMDSUP - up-corridor sequence preprocessor
10. CMDFAD - field addressing commands
11. CMDBAD - block addressing commands
12. CMDINO - initial orientation tests
13. CMDARA - HC output buffer tests

b. GET - Disk data acquisition task (see Figure 3.2.2-4):

1. GETINI - HC-initialization processor
2. GETAIM - Aim-point update processor
3. GETAL1 - Alt1stow-angles processor
4. GETAL2 - Alt2stow-angles processor
5. GETWSH - Wash-angles processor
6. GETSTO - Stow-angles processor
7. GETSAR - tracking configuration save and restore

c. SEQ - Command sequence control task (see Figure 3.2.2-5):

1. SEQGAT - HC-gathering processor
2. SEQBPT - Beam-pointing processor
3. SEQCK - Corridor availability test
4. SEQCOR - Corridor-walk processor
5. SEQADD - Add sequence to active list
6. SEQRLK - Relink sequence in active list
7. SEQDEL - Delete sequence from active list

d. BHC - Task to build and combine HC commands into HFC packets by priority levels (see Figure 3.2.2-6)

e. BHI - Automatic HFC initialization task (see Figure 3.2.2-6):

BHISH5 - Bit-shift processor for building HFC initialization commands

3.2.2.4.1.1 Submodule I - CMD

3.2.2.4.1.1.1 Description

CMD is the submodule (task) which gains control when an operator input command is to be processed for possible HC output commands. CMD accepts operator input commands in binary format from task MMI of the MANMIF module. All addressing parameters have been translated into their respective internal HC numbers (1-2048). Commands specifying "field" addressing have no HC numbers passed to CMD.

- a. Language used - FORTRAN IV
- b. How invoked - activated by MMI to process all operational commands (MMI is suspended until CMD completes).
- c. Constraints and limitations - None

Figure 3.2.2-4

Task GET Hierarchy

Figure 3.2.2-5 Task SEQ Hierarchy

Figure 3.2.2-6 Tasks BHI, BHC Hierarchy

d. Processing -

1. Initialize by zeroing the disk-data required flag (DISDAT) and the sequence-required flag (SEQREQ).
2. Submodule CMDSCK is called to interpret the input command.
3. Upon return from CMDSCK, the error flag CPPRTG is checked. If set, go to step (5). See Table 3.2.2-I for all error codes.
4. If no error is returned, SEQREQ is checked to determine if the operator command requires a sequence. If no sequence is needed, go to step (5). If a sequence is needed, submodule CMDNAL is called to allocate a sequence and build the sequence packet for task SEQ. If a sequence is needed and the field power fail flag is set, free the HC # buffer for the sequence, set CPPRTG to eight, and go to step (5). Task SEQ is Enqueued.
5. The disk-data flag DISDAT is checked. If set, task GET is Enqueued.
6. Task MMI is resumed via the REX RESUME service call and task CMD relinquishes control.

- e. Error messages and recovery - Error code 8 is set if a sequence is allocated and the power fail flag is set.

3.2.2.4.1.1.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. CPPG(1) - command number
2. CPPRTG - CMD error return word to MMI

b. Local common:

1. SEQREQ - sequence required flag
2. DISDAT - disk data required flag

CMD Error Code & Location

1	(See note, offset = 10000)	HC not in correct orientation
2	(See note, offset = 20000)	HC offline
3	(See note, offset = 30000)	HC not installed
4	CPPRTG	BCSTRACK allows only 1 HC per BCS target at a time
5	CPPRTG	Sequence disallowed; only 16 sequences possible at a time
8	CPPRTG	Sequence disallowed; power fail flag set

NOTE: HCMAPG contains applicable internal HC #s for non-field addressing. Add an error-indicative offset # to the HC # if it cannot respond to the input command.

Table 3.2.2-I CMD Error Return Codes

Output data:

a. Global common:

CPPRTG - CMD error return word to MMI

b. Enque of task SEQ

c. Enque of task GET

d. Local common:

1. SEQREQ - sequence required flag

2. DISDAT - disk-data required flag

3.2.2.4.1.1.3 Internal Data Description

None

3.2.2.4.1.1.4 Flowchart

See Figure 3.2.2-7 for the CMD flowchart.

3.2.2.4.1.2 Submodule II - CMDSCK

3.2.2.4.1.2.1 Description

CMDSCK is responsible for determining type of input command to be processed, how to size the HC number buffers (IMARAY, SQARAY, SBARAY, COARAY), which type of addressing is specified, how many HCs are able to respond, whether a sequence is required, which output command processing submodule to call, and setting the MMI error return word CPPRTG.

a. Language used - FORTRAN IV

b. How invoked - called by CMD

c. Constraints and limitations -

1. Accepts only those operational commands listed in Table 3.2.2-II.
2. Allows up to 16 sequences simultaneously.
3. Allows only STHIWIND, LOAD, and HOLD to rob HCs from sequences.

Figure 3.2.2-7 Flowchart - CMD

<u>Command No.</u>	<u>Command</u>	<u>Acceptable Abbreviation</u>	<u>Valid Initial Orientations</u>
1	TRACK	(TRAC)	Standby
2	INCREASE	(INCR)	Standby
3	LOAD	(LOAD)	All
4	MARK	(MARK)	Stow
5	STANDBY	(STAN)	Track
6	STOW	(STOW)	Initialization Alt1stow Position Mark Standby Track
7	POSITION	(POSI)	All except offline and auto-BCS
8	ONLINE	(ONLI)	Offline
9	OFFLINE	(OFFL)	Stow Alt1stow Alt2stow Position
10	DECREASE	(DECR)	Track
11	BCSTRACK	(BCST)	Standby
12	RETURN	(RETU)	BCS
13	WASH	(WASH)	All except offline and auto-BCS
14	ALT1STOW	(ALT1)	Stow Position Standby Track
15	ALT2STOW	(ALT2)	Position Standby
16	RESTORE	(REST)	All

Table 3.2.2-II Operational Commands and Their Valid Initial Orientations

<u>Command No.</u>	<u>Command</u>	<u>Acceptable Abbreviation</u>	<u>Valid Initial Orientations</u>
17	UNSTOW	(UNST)	Stow Alt1stow Alt2stow
18	STHIWIND	(STHI)	Initialization } Alt1stow } Position } Position Mark } compare CLLP } or in Standby } transition Track } BCS } Corridor walk } In transition to Wash }
19	DEFOCUS	(DEFO)	Track: at or approaching the target
20	AIMPOINT	(AIMP)	All
21	HOLD	(HOLD)	Any transition: position compare false
22	SAVE	(SAVE)	Track Standby
23	RELWASH	(RELV)	Wash
24	ESTANDBY	(ESTA)	Initialized (sent HC a 'LOAD') and orientation at power fail time was: Track: at or approaching the target, or Standby: at or approaching the CULP
25	ESTOW	(ESTO)	Initialized (sent HC a 'LOAD') and orientation at power fail time was: In corridors, or at or approaching the CLLP

d. Processing -

1. Initialize all appropriate flags and counters.
2. Determine the proper offset into the initial orientation array (INORIE). Determine the non-sequence orientation count (IMCNT) and the sequence orientation count (SQCNT).
3. Determine the sizes of the HC number buffers by examining the LMODE array. The LMODE array specifies which MODEG words are required to calculate the appropriate buffer size.
4. Determine the input addressing type in CPPG(2); see Figure 3.2.2-8. If field addressing (is less than zero,) call submodule CMDFAD. Otherwise, addressing is of block type; call submodule C MDBAD.
5. Upon return, determine whether any HCs can respond to the input command. If none, set CPPRTG and go to step (10).
6. Determine if a sequence is required. If not, go to step (9). Check if the maximum-sequences flag (MAXSEQ) is set. If so, go to step (8). Otherwise, check if the command is STHIWIND. If not, go to step (9).
7. If the command is STHIWIND, set the emergency-sequence flag (EMSEQG), and go to step (9).
8. Check if the command is STHIWIND. If not, set EFLAGI equals five, and go to step (10). If STHIWIND, use REX option number ten to output to the system console the message:

STHI WITH 16 SEQUENCES ALREADY IN PROGRESS
and go to step (10).

9. Submit the command number to a CASE statement to determine the proper processing submodule for output commands. All submodules return to step (10). The submodule branch decisions are:
 - a) Call CMDTRK for TRACK or INCREASE (command number equal to 1 or 2);
 - b) Call CMDDSK for LOAD, WASH, ALT2STOW, SAVE, AIMPOINT, RESTORE, or ESTOW (command number equals 3,13,15,16,20,22, or 25);
 - c) Call CMDPOS for MARK, POSITION, ONLINE,

OFFLINE, HOLD, or RELWASH(command number equals 4,7,8,9,21, or 23);

- d) Call CMDSBY for STANDBY, DECREASE, RETURN, DEFOCUS, or ESTANDBY(command number equals 5,10,12,19, or 24);
- e) Call CMDSDN for STOW, ALT1STOW, or STHIWIND(command number equals 6,14, or 18);
- f) Call CMDBCS for BCSTRACK(command number equals 11); and
- g) Call CMDSUP for UNSTOW(command number equals 17).

- 10. Set the MMI-error return flag CPPRTG to the value of the internal-error flag(EFLAGI) and return to CMD.

e. Error messages and recovery - If maximum-sequence flag set and a sequence is required:

- 1. If not STHIWIND, set CPPRTG equals five, and return to CMD.
- 2. If STHIWIND, output text message to system console and return to CMD.

3.2.2.4.1.2.2 Data, Logic and Command Paths

Input data:

a. Global common:

- 1. MODEG - HC-mode array
- 2. CPPG(1) - command number
- 3. HCMAPG - command success value(s)

b. Local common:

- 1. IOPTR - INORIE pointer array
- 2. INORIE - orientation-value and mask array
- 3. MODPTR - LMODE pointer array
- 4. LMODE - MODEG value array
- 5. SUCPTR - HCMAPG output success pointer
- 6. MAXSEQ - maximum-sequences flag

Output data:

a. Global common:

EMSEQG - emergency sequence-in-progress flag

b. Local common:

- 1. EFLAGI - internal error value
- 2. IMCNT - non-sequence orientation count

3. SQCNT - sequence orientation count
4. IMSIZE - IMARRAY size
5. SQSIZE - SQARRAY size
6. SBSIZE - SBARRAY size
7. COSIZE - COARRAY size
8. CNT - HC number array size
9. ECNT - non-sequence MODEG-value count
10. KIN - non-sequence INORIE pointer
11. LIN - sequence INORIE pointer
12. IMSPTR - static IMARRAY pointer
13. IMDPTR - dynamic IMARRAY pointer
14. SQSPTR - static SQARRAY pointer
15. SQDPTR - dynamic SQARRAY pointer
16. SBSPTR - static SBARRAY pointer
17. SBDPTR - dynamic SBARRAY pointer
18. COSPTR - static COARRAY pointer
19. CODPTR - dynamic COARRAY pointer

3.2.2.4.1.2.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.2.4 Flowchart

See Figure 3.2.2-8 for the CMDSCK flowchart.

3.2.2.4.1.3 Submodule III - CMDFAD

3.2.2.4.1.3.1 Description

CMDFAD is responsible for initial processing of input commands using field addressing. Because the HCMAPG array is not used for this type of addressing, every installed HC is initially considered as involved. Those HCs which are able to respond to the input command are placed in the appropriate HC-number array by submodule CMDARA. Only one word in HCMAPG is set for the input command's success count.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK
- c. Constraints and limitations - None
- d. Processing -

1. Perform DO-UNTIL processing where HC equals

Figure 3.2.2-8 Flowchart - CMDSCK

Figure 3.2.2-8 Flowchart - CMDSCK (continued)

Figure 3.2.2-8 Flowchart - CMDSCK (continued)

one to 2048. If HC is greater than 2048, set the final success count by:

HCMAPG(SUCPTR) = SUCCNT

and return to CMDSCK.

2. Check if HC is installed by examining HCST2G(HC). If value is less than zero (not installed), set EFLAGI to equal three and go to step (1). Otherwise, call the initial orientation processor submodule CMDINO for this HC.
3. Upon return, check the initial orientation-okay flag(PASS). If greater than zero, HC has passed normal initial orientation tests for this input command; go to step (4). Otherwise, HC did not pass normal tests; check if command is STHIWIND. If not, set EFLAGI to equal one, and go to step (1). If STHIWIND, set bit 7 of HCST2G(HC) to inform the ALARMS module that this HC could not respond to STHIWIND; go to step (1).
4. If command is not ESTANDBY, go to step (5). For ESTANDBY commands, determine the orientation when full-field power loss was detected:

FLDORI = PWHC1G(HC).AND.#7C.

If FLDORI equals #20(Track), go to step (6). Otherwise, if FLDORI equals #30(Standby), go to step (6). If neither, set PASS to equal zero and EFLAGI to equal one; go to step (1).

5. If the command is not ESTOW, go to step (6). For ESTOW commands, determine the orientation when full-field power loss was detected:

FLDORI = PWHC1G(HC).AND.#70

If FLDORI equals #40(Corridor), go to step (6). Otherwise, if FLDORI equals #50(Corridor), go to step (6). If neither, set up other test by:

FLDORI = PWHC1G(HC).AND.#7C

If FLDORI equals #34(CLLP), go to step (6). Otherwise, set PASS to equal zero and EFLAGI to equal one; go to step (1).

6. Determine if the HC is in a sequence by examining HCST3G(HC), bits 11 through 15. If zero, go to step (7). If nonzero, check if command is STHIWIND. If not, go to step (1). If STHIWIND, determine if HC is in a Stow sequence by examining HCST3G(HC), bit 7. If set, ignore this HC because STHIWIND also sends HCs to the Stow orientation; go to step (1). If not set, delete (rob) the HC from its sequence by zeroing bits 11 through 15 of HCST3G(HC).

7. Call submodule CMDARA to place the HC number into one of four HC number buffers (see Figure 3.2.2-9).
8. Upon return, increment the success count (SUCCNT) by one, and go to step (1).
- e. Error messages and recovery - EFLAGI is set to one if an HC is not in the correct orientation and set to three if an HC is not installed.

3.2.2.4.1.3.2 Data, Logic and Command Paths

Input data:

- a. Global common:
 1. HCST2G - HC installed status
 2. CPPG(1) - command number
 3. PWHC1G - HC orientation at power fail
 4. HCST3G - HC sequence assignment
- b. Local common:
 1. SUCCNT - command's success count
 2. PASS - initial-orientation okay flag
 3. HC - current HC number

Output data:

- a. Global common:
 1. HCMAPG - command's success array
 2. HCST2G - STHIWIND alarm bit
 3. HCST3G - HC sequence assignment
- b. Local common:
 1. EFLAGI - internal error flag
 2. FLDORI - field orientation
 3. PASS - initial-orientation okay flag
 4. SUCCNT - command's success count
 5. SUCPTR - HCMAPG output-success pointer
 6. HC - current HC number

3.2.2.4.1.3.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.3.4 Flowchart

See Figure 3.2.2-10 for the CMDFAD flowchart.

<u>Event</u>	<u>Description</u>
1	Get command #, addressing type
2	Get all valid initial orientations for command
3	Get addressed HC #s (if non-field addressing)
4a	Get last reported orientation for HC
4b	Get last commanded orientation
5a	Store HC #s for immediate, non-sequence movement
5b	Store HC #s for non-corridor, sequence movement
5c	Store HC #s for corridor, sequence movement
5d	Store HC #s for corridor walk gather (STHI only)
6	Store command's degree of success in buffer

Figure 3.2.2-9 CMDSCK Input/Output Buffers

Figure 3.2.2-10 Flowchart - CMDFAD

Figure 3.2.2-10 Flowchart - CMDFAD (continued)

3.2.2.4.1.4 Submodule IV - CMDBAD

3.2.2.4.1.4.1 Description

CMDBAD is responsible for initial processing of input commands using block addressing (see Table 3.2.2-III). Only those HC numbers contained in the blocks of HCMAPG are initially considered as involved. Those HCs which are able to respond to the input command are placed in the appropriate HC number buffer by submodule CMDARA. A success-count value for each HCMAPG block is inserted into HCMAPG for MMI feedback to the command input source.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK
- c. Constraints and limitations - None
- d. Processing -

1. Set the INPTR augment value (INPTRA) to one. If command is not INCREASE or DECREASE, go to step (2). Otherwise, check for the optional number allowed with INCREASE or DECREASE commands, CPPG(2). If zero (use entire block), go to step (2). Otherwise, add the negative block length (see Table 3.2.2-III) to CPPG(2). If the result is greater than zero, go to step (2). If less than zero, set the INPTR augment value:

$$\text{INPTRA} = -\text{HCMAPG}(\text{INPTR}) - \text{CPPG}(2) + 1.$$

This value is used to increment INPTR to point to the next negative block count whenever the current block has been completed. Set LOOP to equal CPPG(2) to only process the optional number of HCs for the INCREASE or DECREASE command. Go to step (3).

2. Set LOOP equal to -HCMAPG(INPTR) to process all the HCs in the block.
3. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (13).
4. Increment the HCMAPG input pointer (INPTR) by one to point to the next HC number in the block. Extract the HC number by:

$$\text{HC} = \text{HCMAPG}(\text{INPTR}).$$

Check if the HC is installed by examining HCST2G(HC). If less than zero (not installed), set EFLAGI equal to three, and go to step (3). Otherwise, call the initial orientation process or submodule CMDINO for this HC.

5. Upon return, check the initial-orientation okay

I. MMI-to-CMD (Single block of HC #s)

<u>Array (Element)</u>	<u>Value</u>	<u>Description</u>
HCMAPG (1)	$-N_t$	Total # of HCs in block
(2)	HC #	N_t HCs
.	.	
.	.	
.	.	
(N_t+1)	HC #	
(N_t+2)	-9999_{10}	End of data

II. MMI-to-CMD (Multiple blocks of HC #s)

HCMAPG (1)	-N ₁	# of HCs in 1st block	1st block
(2)	HC #	N ₁ HCs in pecking order	
.	.		
.	.		
.	.		
(N ₁ +1)	HC #		
(N ₁ +2)	-N ₂	# of HCs in 2nd block	2nd block
(N ₁ +3)	HC #	N ₂ HCs in pecking order	
.	.		
.	.		
.	.		
(N ₁ +N ₂ +2)	HC #		
.			
.			
.			
NB			
($\sum_{i=1}^{NB} N_i + NB + 1$)	-9999 ₁₀	End of data	

Where NB = # of blocks inherent in command addressing

Table 3.2.2-III MMI/CMD HC Block Buffer

III. CMD-to-MMI Statistics (degree of success)

<u>Array (Element)</u>	<u>Value</u>	<u>Description</u>
HCMAPG (1)		# of HCs successful from 1st block or for field addressing
(2)		# of HCs successful for 2nd block
.		
.		
.		
(N+1)	-9999 ₁₀	(End of data)

NOTE: These statistics reflect initial success rate; any subsequent HC timeout problems are reported via alarms.

HCMAPG(1) will be set to 0 for non-field addressing if no HCs within any block can respond.

Table 3.2.2-III MMI/CMD HC Block Buffer (cont'd)

flag (PASS). If greater than zero, HC has passed the normal initial orientation tests for this input command; go to step (7).

6. HC did not pass all initial orientation tests. Set EFLAGI to equal one, and go to step (3).

7. Check if command is HOLD. If not, go to step (8). For HOLD, do two additional tests. Get HC's field orientation:

FLDORI = HCST1G(HC).AND.#7C.

If FLDORI equals #18 (initialization), ignore this HC by going to step (3). Otherwise, get HC's last commanded orientation:

FLDORI = HCCMDG(HC).AND.#D07C.

If FLDORI equals #9030, HC is participating in a DEFOCUS action; ignore this HC by going to step (3). If HC is not being commanded via a DEFOCUS command, go to step (8).

8. If command is not ESTANDBY, go to step (9). For ESTANDBY commands, determine orientation when full-field power loss was detected:

FLDORI = PWHC1G(HC).AND.#7C.

If FLDORI equals #20 (Track), go to step (10). Otherwise, if FLDORI equals #30 (Standby), go to step (10). If neither, set PASS equal to zero and EFLAGI equal to one; go to step (3).

9. If command is not ESTOW, go to step (10). For ESTOW commands, determine orientation when full-field power loss was detected:

FLDORI = PWHC1G(HC).AND.#70.

If FLDORI equals #40 (Corridor), go to step (10). Otherwise, if FLDORI equals #50 (Corridor), go to step (10). If neither, set up other test by:

FLDORI = PWHC1G(HC).AND.#7C.

If FLDORI equals #34 (CLLP), go to step (10). Otherwise, set PASS to equal zero and EFLAGI to equal one; go to step (3).

10. Determine if HC is in a sequence by examining HCST3G(HC), bits 11 through 15. If zero, go to step (11). If non-zero, check if command is HOLD. If not, go to step (6). If HOLD, delete (rob) the HC from its sequence by zeroing bit 7 (Stow sequence status) and bits 11 through 15 (sequence number) of HCST3G(HC).

11. Call submodule CMDARA to place the HC number into one of four HC number buffers (see Table 3.2.2-IV).

<u>Array (Element)</u>	<u>Description</u>
CPPG(1)	Command # (range: 1 to 25)
CPPG(2)	<p>>0: # of HC's/block (used only for pecking order related commands; e.g., INCREASE 10/R/5 would cause the number 10 to appear in this word)</p> <p>=0: Use entire block</p> <p><0: Use entire field</p>
CPPG(3)	Azimuth (for POSITION commands) or Aim-point Array # (for AIMPOINT commands) or 0
CPPG(4)	Elevation (for POSITION commands) or 0

For "segment", "wedge", or "ring" addressing, a block is a segment. For "field controller" addressing, a block is a HFC. For "heliostat" or "arc" addressing, a block is the set of addressed HCs. For "field" addressing, CPPG(2) < 0 and no blocks of HC numbers are passed in the HCMAPG array (Figure 3.2.2-8). HC numbers involved in a non-field command are transmitted in the HCMAPG array.

Table 3.2.2-IV MMI/CMD Command Buffer

12. Upon return, increment the block's success count (SUCCNT) by one, and go to step (3).

Block processing has been completed. Section to look for end of data or next block:

13. Set block's final success count by:

HCMAPG (SUCPTR) = SUCCNT.

Set INPTR to next block count by:

INPTR = INPTR + INPTRA.

Zero the block's success count (SUCCNT).

14. Examine the next block count word in HCMAPG to check for end of data (-9999). If -9999, return to CMDSCK. Otherwise, another block is present. Increment the success-count pointer (SUCPTR) by one, and go to step (1).

- e. Error messages and recovery - EFLAGI is set to one if an HC is not in the correct orientation and set to three if an HC is not installed.

3.2.2.4.1.4.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. HCST2G - installed bit
2. CPPAG(1) - command number
3. FWHC1G - HC orientation at power fail
4. HCST3G - HC sequence assignment

b. Local common:

1. SUCCNT - block's success count
2. PASS - initial-orientation okay flag
3. HC - current HC number

Output data:

a. Global common:

1. HCMAPG - command's success array
2. HCST3G - HC sequence assignment

b. Local common:

1. EFLAGI - internal error value
2. FLDORI - field orientation
3. PASS - initial-orientation okay flag
4. SUCCNT - block's success count
5. SUCPTR - HCMAPG output-success pointer
6. HC - current HC number

3.2.2.4.1.4.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.4.4 Flowchart

See Figure 3.2.2-11 for the CMDBAD flowchart.

3.2.2.4.1.5 Submodule V - CMDINO

3.2.2.4.1.5.1 Description

CMDINO is responsible for determining whether the input HC is in a valid initial orientation for the input command. It also tests for non-software offline (field problem) and participation in the automatic BCS operations. The initial-orientation okay flag (PASS) is non-zero for an HC in a valid orientation.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDFAD or CMDBAD
- c. Constraints and limitations - only STHIWIND can rob an HC from automatic BCS operations.
- d. Processing -
 1. Zero the initial-orientation okay flag (PASS) and the HC-in-sequence orientation flag (SEQOR). Check the non-sequence orientation count (IMCNT). If zero, command is ONLINE or LOAD and all orientations are valid; set PASS to equal one and go to step (9). Otherwise, check HC to be offline due to a field problem by examining HCST2G(HC), bits 1 through 4 and 8. If non-zero (field problem), go to step (10). Otherwise, set the non-sequence, initial-orientation array (INORIE) index K to equal KIN. KIN was set in CMDSCK to point to the input command's first non-sequence orientation value in INORIE.

Test HC to be in a non-sequence orientation. This means a sequence will not be required to move the HC to the final destination specified in the input command.

2. Perform DO-UNTIL processing where M equals one to IMCNT. If M is greater than IMCNT, check the input command's sequence-orientation count (SQCNT). If greater than zero (sequence orientations exist in INORIE), go to step (5). If zero, go to step (10).
3. Get the next valid non-sequence orientation for the input command:

ORIENT = INORIE(K).

Increment K by one and get the corresponding mas

Figure 3.2.2-11 Flowchart - CMDBAD

Figure 3.2.2-11 Flowchart - CMDBAD (continued)

Figure 3.2.2-11 Flowchart - CMDBAD (continued)

for HC's field orientation:

MASK = INORIE(K).

Get the current field orientation by:

FLDORI = HCST1G(HC).AND.MASK.

See Figure 3.2.2-9 for overview.

4. Compare the valid orientation value against the field orientation value. If they match, set PASS to equal one and go to step (9). If not, increment K by one, and go to step (2).

Test HC to be in a sequence orientation. This means a sequence will be required to move HC to final destination specified in the input command.

5. Set the HC-in-sequence orientation flag (SEQOR). Set the sequence, initial-orientation array (INORIE) index L to equal LIN. LIN was set in CMDSCK to point to input command's first sequence orientation value in INORIE.
6. Perform DO-UNTIL processing where M equals one to SQCNT. If M is greater than SQCNT, HC is not in a proper orientation; go to step (10).
7. Get the next valid sequence initial orientation for the input command, ORIENT equals INORIE(L). Increment L by one and get the corresponding mask for HC's field orientation, MASK equals INORIE(L). Get the current field orientation by:

FLDORI = HCST1G(HC).AND.MASK.

See Figure 3.2.2-9 for overview.

8. Compare the valid orientation value against the field orientation value. If they match, set PASS to equal one and go to step (9). If not, increment K by one, and go to step (6).

Test successful HC to be in automatic BCS operations:

9. Get the automatic BCS status by:

BCSFLG = HCST3G(HC).AND.#80.

If zero, go to step (10). Otherwise, check command to be STHIWIND. If not, ignore HC by setting PASS to equal zero, and go to step (10). If STHIWIND, delete(rob) the HC from automatic BCS by:

HCST3G(HC) = HCST3G(HC).AND.#FFEF.

10. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.5.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. HCST2G - HC offline status
2. HCST1G - HC field status
3. HCST3G - HC automatic BCS status
4. CPPG(1) - command number

b. Local common:

1. IMCNT - non-sequence orientation count
2. SQCNT - sequence orientation count
3. KIN - non-sequence orientation pointer
4. LIN - sequence orientation pointer
5. INORIE - initial-orientation value and mask array

Output data:

a. Global common:

HCST3G - HC automatic BCS status

b. Local common:

1. PASS - initial-orientation okay flag
2. SEQOR - sequence orientation flag
3. K - non-sequence orientation into INORIE
4. L - sequence orientation into INORIE
5. ORIENT - valid orientation value from INORIE
6. MASK - field-orientation mask value from INORIE
7. FLDORI - masked field orientation
8. BCSFLG - automatic BCS status for HC

3.2.2.4.1.5.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.5.4 Flowchart

See Figure 3.2.2-12 for the CMDINO flowchart.

3.2.2.4.1.6 Submodule VI - CMDARA

3.2.2.4.1.6.1 Description

Figure 3.2.2-12 Flowchart - CMDINO

Figure 3.2.2-12 Flowchart - CMDINO (continued)

CMDARA is responsible for inserting the HC number specified in local common word "HC" into the appropriate HC number buffer for subsequent processing. The value of flag SEQOR dictates whether the HC number goes into the non-sequence buffer (IMARAY) or one of the sequence buffers (SQARAY, SBARAY, COARAY). The non-sequence buffer is used to build a disk packet for those input commands requiring disk data. The sequence buffers are used to build a sequence packet for those input commands requiring sequence processing.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDFAD or CMDBAD
- c. Constraints and limitations - None
- d. Processing -

1. Determine the type of orientation found for the current HC by examining flag SEQOR. IF greater than zero, HC must be command with sequence processing; go to step (2). If zero, put the HC number in IMARAY by setting HCARAY(IMDPTR) to equal HC. Increment the dynamic IMARAY pointer (IMDPTR) by one and increment the IMARAY size (IMSIZE) by one; go to step (6).

2. Ignore the position-compare bit when getting HC's field orientation:

FLDORI = HCST1G(HC).AND.#7C.

If FLDORI equals #20 (Track), go to step (3).
If FLDORI equals #2C(BCS), go to step (3). If FLDORI equals #60 (Stow), go to step (3). If FLDORI equals #70 (Alt1stow), go to step (3). Otherwise, go to step (4).

3. Put the HC number in SQARAY by setting HCARAY(SQDPTR) to equal HC. Increment the dynamic SQARAY pointer (SQDPTR) by one and increment the SQARAY size (SQSIZE) by one; go to step (6).
4. If FLDORI is not #30 (Standby), go to step (5). Otherwise, put the HC number in SBARAY by setting HCARAY(SBDPTR) to equal HC. Increment the dynamic SBARAY pointer (SBDPTR) by one and increment the SBARAY size (SBSIZE) by one; go to step (6).
5. Orientation is corridor walk and only used by STHIWIND command. Put the HC number in COARAY by setting HCARAY(CODPTR) to equal HC. Increment the dynamic COARAY pointer (CODPTR) by one and increment the COARAY size (COSIZE) by one; go to step (6).
6. Return to caller.

- e. Error messages and recovery - None

3.2.2.4.1.6.2 Data, Logic and Command Paths

Input data:

a. Global common:

HCST1G - HC field status

b. Local common:

1. SEQOR - HC's sequence-orientation flag
2. FLDORI - field orientation
3. IMDPTR - dynamic IMARRAY pointer
4. IMSIZE - IMARRAY size
5. SQDPTR - dynamic SQARRAY pointer
6. SQSIZE - SQARRAY size
7. SBDPTR - dynamic SBARRAY pointer
8. SBSIZE - SBARRAY size
9. CODPTR - dynamic COARRAY pointer
10. COSIZE - COARRAY size
11. HC - current HC number

Output data:

Local common:

- a. HCARAY - overall HC-number buffer area
- b. FLDORI - field orientation
- c. IMDPTR - dynamic IMARRAY pointer
- d. IMSIZE - IMARRAY size
- e. SQDPTR - dynamic SQARRAY pointer
- f. SQSIZE - SQARRAY size
- g. SBDPTR - dynamic SBARRAY pointer
- h. SBSIZE - SBARRAY size
- i. CODPTR - dynamic COARRAY pointer
- j. COSIZE - COARRAY size

3.2.2.4.1.6.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.6.4 Flowchart

See Figure 3.2.2-13 for the CMDARA flowchart.

3.2.2.4.1.7 Submodule VII - CMDSAL

3.2.2.4.1.7.1 Description

CMDSAL is responsible for determining a sequence number when

Figure 3.2.2-13 Flowchart - CMDARA

the input command requires sequence processing. It then determines all of the corridors needed for the sequence. Then it builds the sequence packet (see Table 3.2.2-V) required for CMD to Enque task SEQ. Possible sequence commands are UNSTOW, STOW, STHIWIND, and ALT1STOW.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMD to allocate a sequence for the input command and build a sequence packet.
- c. Constraints and limitations - assume maximum number of corridors is eight.
- d. Processing -

Allocation of sequence number:

- 1a. Set loop count (LOOP) to equal 16 for the maximum number of sequences.
- 1b. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, set CPPRTG to equal five and go to step (31).
- 1c. If SEQLSG(I) is greater than zero, go to step (1b).
2. When a negative number is found in SEQLSG(I), take the two's-complement and update this array element. Set the allocated sequence number (SEQNO) to this positive value. Increment the active-sequences count (SEQNMG) by one, and if SEQNMG equals 16, set the maximum-sequences flag (MAXSEQ). Otherwise, clear MAXSEQ.

To determine all the corridors required by this sequence:

3. Clear the corridors-required array (CORARY), zero the corridors-required count (CORCNT), zero the HC-buffers count (BUFCNT), and zero the command-phase word (CPHASE).
4. If the size word (SBSIZE) of the HCs-in-standby array (SBARAY) is not greater than zero, go to step (7). If greater than zero, set LOOP to equal SBSIZE, set CPHASE to equal five, and set CALLER to equal one.
5. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (7).
6. Set N to equal SBARAY(I) and call internal search routine (steps (32) to (36)) to find the corridor associated with this HC in SBARAY. The routine increments CORCNT when inserting a unique corridor number in CORARY. Upon return, check CORCNT to equal eight (maximum number of corridors). If so, go to step (13). Otherwise, go to step (5).
7. If the size word (SQSIZE) of the HCs-not-at-standby array (SQARAY) is not greater than zero,

<u>WORD</u>	<u>DESCRIPTION</u>
1	COMMAND # = 0: FIELD POWER LOSS or HAC FAILOVER 6: STOW 14: ALT1STOW 17: UNSTOW 18: STHIWIND
2	COMMAND PHASE = 4: GATHER HCs COMMANDED BY TASK CMD 5: WAIT FOR ALL REQUIRED CORRIDORS TO BE FREE 10: END SEQUENCE 20: FIELD POWER LOSS 30: HAC FAILOVER
3	SEQUENCE #: RANGE 1 to 16
4	# of CORRIDORS REQUIRED: RANGE 1 to 8
5 to N	CORRIDORS #(s) REQUIRED
N+1	# of BUFFER DESCRIPTIONS TO FOLLOW: UNSTOW: 1 STOW: 1 or 2 ALT1STOW: 1 or 2 STHIWIND: 1, 2, or 3
N+2	OFFSET (INTO COMQU2) FOR LEASED HC# BUFFER
N+3	ORIENTATION FOR BUFFER #1 ORIENTATION CODES ARE: 1 (HCs MOVING to CULP) 2 (HCs at CULP) 3 (HCs MOVING in CORRIDORS) 4 (HCs MOVING to CLLP) UNSTOW: 4 ALT1STOW or STOW: 1 or 2 STHIWIND: 1, 2, or 3
N+4	SIZE FOR BUFFER #1: RANGE 1 to 2048
N+5	OFFSET (INTO COMQU2) for BUFFER #1
FOLLOWING WORDS ARE OPTIONAL:	
N+6	ORIENTATION FOR BUFFER #2 ALT1STOW or STOW: 2 STHIWIND: 2 or 3
N+7	SIZE FOR BUFFER #2: RANGE 1 to 2047
N+8	OFFSET (INTO COMQU2) for BUFFER #2
N+9	ORIENTATION for BUFFER #3 STHIWIND: 2
N+10	SIZE for BUFFER #3: RANGE 1 to 2046
N+11	OFFSET (INTO COMQU2) for BUFFER #3

go to step (10). If greater than zero, set LOOP to equal SQSIZE, increment BUFCNT by one, set CPHASE to equal four, and set CALLER to equal two.

8. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (10).
9. Set N to equal SQARRAY(I) and call internal search routine (steps (32) to (36)) to find the corridor associated with this HC in SQARRAY. The routine increments CORCNT when inserting a unique corridor number in CORARY. Upon return, check CORCNT to equal eight (maximum number of corridors). If so, go to step (13). Otherwise, go to step (8).
10. If the size word (COSIZE) of the HCs-in-corridor-walks array (COARRAY) is not greater than zero, go to step (13). If greater than zero, set LOOP to equal COSIZE, increment BUFCNT by one, set CPHASE to equal four, and set CALLER to equal three.
11. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (13).
12. Set N to equal COARRAY(I) and call internal search routine (steps (32) to (36)) to find the corridor associated with this HC in COARRAY. The routine increments CORCNT when inserting a unique corridor number in CORARY. Upon return, check CORCNT to equal eight. If so, go to step (13). Otherwise, go to step (11).

Determine size of sequence packet:

13. Determine the sequence packet size using the equation:

$$\begin{aligned}
 \text{PACSIZ} = & 5 \text{ (words 1 to 4 and N+1 in Table 3.2.2-V) +} \\
 & \text{CORCNT (size for words 5 to N in Table 3.2.2-V) +} \\
 & \text{BUFCNT*2 (total number of buffer orientation and size words in Table 3.2.2-V) +} \\
 & \text{SQSIZE (size of HCs-not-at-standby array) +} \\
 & \text{SBSIZE (size of HCs-in-standby array) +} \\
 & \text{COSIZE (size of HCs-in-corridor-walks array).}
 \end{aligned}$$

14. The local common area used for building the packet is BUFR.

Set up the packet header:

15. Set BUFR(1) to equal CPPG(1), the command number. Set BUFR(2) equal to CPHASE, the command phase. Set BUFR(3) to equal SEQNO, the allocated sequence number. Set BUFR(4) to equal CORCNT, the corridor count. Set LOOP to equal CORCNT and set BUFR index J to equal five, the first location for corridor numbers in the packet.
16. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (18).
17. Set BUFR(J) to equal CORARY(I), which transfers corridor numbers to the packet area. Increase J by one, and go to step (16).
18. Set BUFR(J) to equal BUFCNT, the number of HC buffers to be passed in the packet. Increment J by one.

Move HC numbers into the packet:

19. If SQSIZE is not greater than zero, go to step (23). If more than zero, check command to be UNSTOW. If so, set the first buffer orientation word BUFR(J) to equal four to describe this set of HC numbers as moving towards their CLLPs. If not UNSTOW, set BUFR(J) to equal one to describe this set of HC numbers as moving towards their CULPs.
20. Increment J by one and set BUFR(J) to equal SQSIZE to specify size of first buffer. Set LOOP to equal SQSIZE and increment J by one.
21. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (23).
22. Set BUFR(J) to equal SQARAY(I) to move the HC number into the packet area. Increment J by one, and go to step (21).
23. If COSIZE is not greater than zero, go to step (27). If greater than zero, set BUFR(J) to equal three to describe this set of HC numbers as moving in their corridor(s). This buffer will only be used for the STHWIND command.
24. Increment J by one and set BUFR(J) to equal COSIZE to specify size of this buffer. Set LOOP equal to COSIZE and increment J by one.
25. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (27).
26. Set BUFR(J) equal to COARAY(I) to move the HC number into the packet area. Increment J by one,

and go to step (25).

27. If SBSIZE is not greater than zero, go to step (31). If greater than zero, set BUFR(J) equal to two to describe this set of HC numbers as being at their CULPs.
28. Increment J by one and set BUFR(J) equal to SBSIZE to specify size of this buffer. Set LOOP to SBSIZE and increment J by one.
29. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, the sequence packet is completely built and ready for the REX Enque call in CMD; go to step (31).
30. Set BUFR(J) equal to SBARAY(I) to move the HC number into the packet area. Increment J by one, and go to step (29).
31. Return to CMD.

Search routine to add corridor number to array of required corridors:

32. Determine HC's corridor number by setting
CORR = HCST3G(N).AND.#FOOO
and shift right 12 bits. Set LOOP equal to eight for the maximum number of corridors.
33. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (35).
34. If CORARY(I) equals CORR, go to step (36). If not, go to step (33).
35. Add the corridor number found to CORARY array by setting:
CORARY(CORCNT+1) equals CORR.
Increment the corridor count (CORCNT) by one.
36. Return to calling section by using flag CALLER. If CALLER equals one, go to step (6). Otherwise, go to step (9) for CALLER to equal two. If CALLER equals three, go to step (12).

- e. Error messages and recovery - If an unused sequence number is not found in SEQLSG, the MMI-error return value (CPPRTG) is set to five and control is returned to CMD.

3.2.2.4.1.7.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. SEQLSG - sequence-number list array

2. SEQNMG - active-sequences count
3. HCST3G - HC corridor assignment
- b. Local common:
 1. SBSIZE - SBARRAY size
 2. SBARRAY - HCs-in-standby array
 3. CORCNT - required-corridors count
 4. CORARY - required-corridors array
 5. CALLER - search-routine caller flag
 6. SQSIZE - SQARRAY size
 7. SQARRAY - HCs-not-at-standby array
 8. COSIZE - COARRAY size
 9. COARRAY - HCs-in-corridor-walk array
 10. BUFCNT - HC buffers-in-packet count
 11. CPHASE - command phase for packet
 12. SEQNO - allocated sequence number

Output data:

- a. Global common:
 1. SEQLSG - sequence number list array
 2. SEQNMG - active sequences count
- b. Local common:
 1. SEQNO - allocated sequence number
 2. MAXSEQ - maximum-sequences flag
 3. CORARY - required-corridors array
 4. CORCNT - required-corridors count
 5. BUFCNT - HC buffers-in-packet count
 6. CPHASE - command phase for packet
 7. CALLER - search-routine caller flag
 8. CORR - right-justified HC corridor assignment
 9. LEASAD - leased buffer address
 10. PACSIZ - sequence-packet size
- c. Call to Lease for packet buffer.

3.2.2.4.1.7.3 Internal Data Description

- a. Required-corridors count:

CORCNT has range of one through eight
- b. Required-corridors array:

CORARY is a 1x8 array used to collect up to eight

unique corridor numbers necessary to control the allocated sequence.

c. HC buffers count:

BUFCNT has a range of one through three to indicate the differing orientations of the HCs involved in this sequence command.

d. HC corridor assignment:

CORR has a range of one through eight.

e. Packet buffer:

BUFR is a 2067-word area used for building a sequence packet.

3.2.2.4.1.7.4 Flowchart

See Figure 3.2.2-14 for the CMDSAL flowchart.

3.2.2.4.1.8 Submodule VIII - CMDTRK

3.2.2.4.1.8.1 Description

CMDTRK is responsible for building beam pointing/target HC commands for the TRACK and increase input commands. It uses the HC numbers placed in the IMARAY array by CMDARA.

a. Language used - FORTRAN IV

b. How invoked - called by CMDSCK

c. Constraints and limitations - None

d. Processing -

1. Set LOOP equal to IMSIZE.
2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, return to caller. Let N equal IMARAY(I).
3. Set HCDATG(N) equal to AIMPTG(N) for all five words of target X,Y,Z coordinates.
4. Set HCCMDG(N) equal to #8020. Go to step (2).

e. Error messages and recovery - None

3.2.2.4.1.8.2 Data, Logic and Command Paths

Input data:

a. Global common:

AIMPTG - memory-resident aim-point array

b. Local common:

1. IMARAY - non-sequence HC number array
2. IMSIZE - IMARAY size

Output data:

a. Global common:

Figure 3.2.2-14 Flowchart - CMDSAL

Figure 3.2.2-14 Flowchart - CMDSAL (continued)

Figure 3.2.2-14 Flowchart - CMDSAL (continued)

Figure 3.2.2-14 Flowchart - CMD5AL (continued)

Figure 3.2.2-14 Flowchart - CMD5AL (continued)

1. HCDATG - HC data output array
2. HCCMDG - HC command output array

b. Local common:

LOOP - loop count

3.2.2.4.1.8.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.8.4 Flowchart

See Figure 3.2.2-15 for the CMDTRK flowchart.

3.2.2.4.1.9 Submodule IX - CMDDSK

3.2.2.4.1.9.1 Description

CMDDSK is responsible for building the disk packet of HC numbers to be sent to task GET for those commands which require disk data to determine the output commands. This submodule is either called by CMDSCK for the LOAD, WASH, SAVE, RESTORE, ALT2STOW, AIMPOINT, and ESTOW input commands, or may also be called by CMDSDN submodule when certain addressed HCs can move to the Stow or Alt1stow positions without beam-safety requirements.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK or CMDSDN
- c. Constraints or limitations - None
- d. Processing -

1. A local buffer area is used to build the disk packet for task GET. Set up the header as follows:
 - a) BUF(1) = CPPG(1), the command number
 - b) BUF(2) = command phase equals three
 - c) BUF(3) = 0, sequence number
 - d) BUF(4) = CPPG(3) if command number equals 20 (AIMPOINT) this is the aim-point number specified by operator
= 1 otherwise to indicate one buffer being passed
2. If command is RESTORE, set BUF(5) equal to zero and go to step (5). Otherwise, set BUF(5) equal to IMSIZE to record the buffer size and set LOOP equal to IMSIZE. Set the buffer pointer J equal to six.
3. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (5).

Figure 3.2.2-15 Flowchart - CMDTRK

4. Move the HC numbers in the IMARRAY array to the GET packet. Increment J and go to step (3).
5. Set the disk-data flag (DISDAT) and return to caller.

e. Error messages and recovery - None

3.2.2.4.1.9.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. CPPG(3) - aim-point array number for command number equals 20.
2. CPPG(1) - command number

b. Local common:

1. IMARRAY - non-sequence HC number array
2. IMSIZE - IMARRAY size

Output data:

Local common:

- a. Local common buffer BUF used to build disk packet (see Table 3.2.2-VI for format)
- b. DISDAT - disk-data flag
- c. LOOP - loop count

3.2.2.4.1.9.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.9.4 Flowchart

See Figure 3.2.2-16 for the CMDDSK flowchart.

3.2.2.4.1.10 Submodule X - CMDPOS

3.2.2.4.1.10.1 Description

CMDPOS is responsible for building all AZ/EL pointing output commands (MARK, POSITION, INLINE, OFFLINE, HOLD, and RELWASH) which do not require disk data. It also processes the ONLINE command which only resets global common bits in the HC's HCST2G word.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK.
- c. Constraints and limitations - ONLINE processing will not reset HCs which are unmarked.
- d. Processing -
 1. Set LOOP equal to IMSIZE.
 2. Perform DO-UNTIL processing where I equals one

<u>WORD</u>	<u>DESCRIPTION</u>
1	COMMAND #
2	COMMAND PHASE: <ul style="list-style-type: none"> = 3: WHEN CMD ENQUES GET = 9: WHEN SEQ ENQUES GET
3	SEQUENCE #: <ul style="list-style-type: none"> = 0: WHEN CMD ENQUES GET ≠ 0: WHEN SEQ ENQUES GET
4	AIMPOINT # (IF COMMAND # = 20) # OF HC BUFFERS (FOR ALL OTHER COMMANDS)
5	BUFFER SIZE
6	HC # BUFFER LEASE OFFSET: <ul style="list-style-type: none"> = 0: RESTORE COMMAND = 0: ALL OTHER COMMANDS REQUIRING DISK DATA

Table 3.2.2-VI Disk Data Command Packet

Figure 3.2.2-16 Flowchart - CMDDSK

- to LOOP. If I is greater than LOOP, return to caller. Let N equal IMARAY(I).
3. If command is ONLINE, reset HCST2G(N), bits 1 through 3 and 8. Go to step (2).
 4. If command is MARK, insert the local Mark mode values into HCDATG(N). Set HCCMDG(N) equal to #8064, and go to step (2).
 5. If command is POSITION, insert the operator-specified AZ/EL contained in CPPG(3) and CPPG(4) into HCDATG(N). Set HCCMDG(N) equal to #806C, and go to step (2).
 6. If command is OFFLINE, set HCST2G(N), bit three and set HCDATG(N) to AZIMG(N) and ELEVG(N), the last reported AZ/EL values from the field. Set HCCMDG(N) equal to #806C, and go to step (2).
 7. If command is HOLD, set HCDATG(N) equal to AZIMG(N) and ELEVG(N). Set HCCMDG(N) equal to #906C. Increment EMCC1G(2) by one to tell the BHC task how many type-2 critical commands exist in the HCCMDG array. Go to step (2).

e. Error messages and recovery - None

3.2.2.4.1.10.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. CPPG(1) - command number
2. CPPG(3) - operator-specified azimuth for POSITION
3. CPPG(4) - operator-specified elevation for POSITION
4. AZIMG - last reported azimuth array
5. ELEVG - last reported elevation array

b. Local common:

1. IMARAY - non-sequence HC number array
2. IMSIZE - IMARAY size
3. MARKAZ - Mark mode azimuth
4. MARKEL - Mark mode elevation

Output data:

Global common:

- a. HCDATG - HC-data output array
- b. HCCMDG - HC-command output array
- c. HCST2G - HC derived-status array
- d. EMCC1G(2) - type-2 critical command count

3.2.2.4.1.10.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.10.4 Flowchart

See Figure 3.2.2-17 for the CMDPOS flowchart.

3.2.2.4.1.11 Submodule XI - CMDSBY

3.2.2.4.1.11.1 Description

CMDSBY is responsible for building non-sequence, beam pointing/track-the-CULP output commands for the STANDBY, RETURN, DEFOCUS, DECREASE, and ESTANDBY input commands. It uses the HC numbers placed in the IMARAY array by CMDARA.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK
- c. Constraints and limitations - None
- d. Processing -
 1. Set LOOP equal to IMSIZE.
 2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, return to caller. Let N equal IMARAY(I).
 3. Determine the HC's corridor assignment, J equals HCST3G(N), bits zero through three. Set HCDATG(N) equal to CORRCG(1-5,J) for all five words of CULP X,Y,Z coordinates. If command is not DEFOCUS, go to step (5).
 4. Set HCCMDG(N) equal to #9030. Increment EMCC1G(1) to tell task BHC how many type-1 critical commands exist in the HCCMDG array. Go to step (2).
 5. Extract the BCS target assignment for the HC if the command is RETURN. If not RETURN, go to step (6). Right-justify the BCS target
 $(TGT) = HCST3G(N).AND.\#60.$
Compute the mask for BCSBYG by:
 $BCSMSK = 2^{**}TGT.$
Reset the BCS-busy status bit in BCSBYG by:
 $BCSBYG = BCSBYG.XOR.BCSMSK.$
 6. Set HCCMDG(N) equal to #8030, and go to step (2).
- e. Error messages and recovery - None

3.2.2.4.1.11.2 Data, Logic and Command Paths

Input data:

Figure 3.2.2-17 Flowchart - CMDPOS

a. Global common:

1. CPPG(1) - command number
2. HCST3G - HC corridor and BCS assignment
3. CORRCG - corridor coordinates
4. BCSBYG - BCS-busy status

b. Local common:

1. IMARAY - non-sequence HC number array
2. IMSIZE - IMARAY size

Output data:

a. Global common:

1. HCDATG - HC data output array
2. HCCMDG - HC command output array
3. EMCC1G(1) - type-1 critical command count
4. BCSBYG - BCS-busy status

b. Local common:

1. LOOP - loop count
2. TGT - BCS assignment
3. BCSMSK - BCS status mask

3.2.2.4.1.11.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.11.4 Flowchart

See Figure 3.2.2-18 for the CMDSBY flowchart.

3.2.2.4.1.12 Submodule XII - CMDSDN

3.2.2.4.1.12.1 Description

CMDSDN is responsible for building output commands, if necessary, for the STOW, STHIWIND, and the ALT1STOW input commands. If any involved HCs are in a non-sequence orientation, they are assembled into a disk packet in submodule CMDDSK. Sequence orientations are checked and HCs are moved towards their respective CULPs if required.

a. Language used - FORTRAN IV

b. How invoked - called by CMDSCK for down-corridor initial processing

c. Constraints and limitations - None

d. Processing -

1. Check IMSIZE to be non-zero. If so, there are some involved HCs which can be moved without

Figure 3.2.2-18 Flowchart - CMDSBY

beam-safety requirements. Call CMDDSK to handle this orientation. If IMSIZE equals zero, go directly to step (2).

2. Check the sequence-required flag (SEQREQ), and if not set, go to step (9). If set, check if the command is STHIWIND. If so, set BIT3 equal to #1000; otherwise, set BIT3 to zero. This word is used later in building the HCCMDG word (bit 3 is the critical-command bit).
3. Set LOOP equal to SQSIZE.
4. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (9).
5. Set N equal to SQARRAY(I) to determine HC number.
6. Determine the HC's corridor assignment J equal to HCST3G(N), bits zero through three. Set HCDATG(N) equal to CORRCG(1-5,J) for all five words of CULP X,Y,Z coordinates.
7. Set HCCMDG(N) equal to #8030 plus BIT3.
8. If BIT3 is non-zero, increment EMCC1G(1) to tell task BHC how many type-1 critical commands exist in the HCCMDG array. If not ALT1STOW, set stow-sequence bit in HCST3G, and go to step (4).
9. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.12.2 Data, Logic and Command Paths

Input data:

- a. Global common:
 1. HCST3G - HC corridor assignment
 2. CORRCG - corridor coordinates
- b. Local common:
 1. IMARRAY - non-sequence HC number array
 2. IMSIZE - IMARRAY size
 3. SQSIZE - SQARRAY size
 4. SQARRAY - HCs-not-at-standby array
 5. SEQREQ - sequence-required flag

Output data:

- a. Global common:
 1. HCDATG - HC-data output array
 2. HCCMDG - HC-command output array
 3. HCST3G - HC-in-Stow-sequence status bit

b. Local common:

LOOP - loop count

3.2.2.4.1.12.3 Internal Data Description

Critical-command bit value:

BIT3 = 0: non-critical command

= #1000: critical command (STHIWIND)

3.2.2.4.1.12.4 Flowchart

See Figure 3.2.2-19 for the CMDSDN flowchart.

3.2.2.4.1.13 Submodule XIII - CMDBCS

3.2.2.4.1.13.1 Description

CMDBCS is responsible for building manual BCS output commands whenever the BCSTRACK input command is entered. Only one HC may be tracking a BCS target at one time.

a. Language used - FORTRAN IV

b. How invoked - called by CMDSCK

c. Constraints and limitations - only one HC may be commanded for each entry of the BCSTRACK command.

d. Processing -

1. Set HC equal to IMARAY(1) as this will be the only HC processed.

2. Extract and right-justify the HC's BCS target number (TGT) from HCST3G(HC), bits nine through ten. It will have a range of zero through three.

3. Determine BCS-busy mask by setting:

BCSMSK = 2**TGT.

4. Determine the BCS-target busy status by setting:

BCSSTA = BCSMSK.AND.BCSBYG.

5. If result is non-zero, set the internal-error flag (EFLAGI) to four, and go to step (9). If result is zero, set the BCS-target busy by setting:

BCSBYG = BCSBYG + BCSMSK.

6. Set TGT equal to TGT plus one for index purposes.

7. Set HCDATG(HC) equal to BCSTGG(1-5,TGT).

8. Set HCCMDG(HC) equal to #802C.

9. Return to caller.

e. Error messages and recovery - If the BCS target is already busy, EFLAGI is set to four.

Figure 3.2.2-19 Flowchart - CMDSDN

3.2.2.4.1.13.2 Data, Logic and Command Paths

Input data:

Global common:

- a. HCST3G - HC's BCS target number
- b. BCSBYG - BCS-target busy status
- c. BCSTGG - BCS target coordinates

Output data:

a. Global common:

1. HCDATG - HC-data output array
2. HCCMDG - HC-command output array
3. BCSBYG - BCS-target busy status

b. Local common:

1. TGT - BCS target index
2. BCMSK - bit mask for BCSBYG
3. EFLAGI - CMD-error flag
4. BCSTA - BCS-target busy status

3.2.2.4.1.13.3 Internal Data Description

a. BCS target index:

TGT has value of zero through three when right-justified from HCST3G(HC).

b. Bit mask for BCSBYG:

BCMSK has value of one, two, four, or eight.

3.2.2.4.1.13.4 Flowchart

See Figure 3.2.2-20 for the CMDBCS flowchart.

3.2.2.4.1.14 Submodule XIV - CMDSUP

3.2.2.4.1.14.1 Description

DMDSUP is responsible for building output commands for the UNSTOW input command. If any involved HCs are in the Alt2stow orientation, they are immediately commanded to their CULPs without beam-safety requirements. HCs in the Stow and Alt1stow orientations are commanded to their CLLPs as the first step of the up-corridor sequence.

- a. Language used - FORTRAN IV
- b. How invoked - called by CMDSCK
- c. Constraints and limitations - None
- d. Processing -

1. Check IMSIZE to determine if any HCs can be

Figure 3.2.2-20 Flowchart - CMDACS

1

moved without beam-safety considerations. If zero, go to step (6). Otherwise, set LOOP equal to IMSIZE.

2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (6).
3. Set N equal to IMARRAY(I) to determine HC number.
4. Determine the HC's corridor assignment, J equals HCST3G(N), bits zero through three. Set HCDATG(N) equal to CORRCG(1-5,J) for all five words of CULP X,Y,Z coordinates.
5. Set HCCMDG(N) equal to #8030, and go to step (2).
6. Check the sequence-required flag (SEQREQ) to determine if any involved HCs are in a Stow or Alt1stow orientation. If not, go to step (11). If so, set LOOP equal to SQSIZE.
7. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (11).
8. Set N equal to SQARRAY(I) to determine HC number.
9. Determine HC's corridor assignment J equals HCST3G(N), bits zero through three. Set HCDATG(N) equal to CORRCG(6-10,J) for all five words of CLLP X,Y,Z coordinates.
10. Set HCCMDG(N) equal to #8034, and go to step (7).
11. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.14.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. HCST3G - HC corridor assignment
2. CORRCG - corridor coordinates

b. Local common:

1. IMARRAY - non-sequence HC number array
2. IMSIZE - IMARRAY size
3. SQARRAY - HC-not-at-Standby HC number array
4. SQSIZE - SQARRAY size
5. SEQREQ - sequence-required flag

Output data:

a. Global common:

1. HCDATG - HC-data output array
2. HCCMDG - HC-command output array

b. Local common:

LOOP - loop count

3.2.2.4.1.14.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.14.4 Flowchart

See Figure 3.2.2-21 for the CMDSUP flowchart.

3.2.2.4.1.15 Submodule XV - GET

3.2.2.4.1.15.1 Description

GET is responsible for disk-data accesses for operational commands. HC numbers are passed in a disk packet. GET Deques the entire packet into a local buffer DBUF and preserves the format in case it needs to send it back to the task SEQ for sequence deletion.

- a. Language used - FORTRAN IV
- b. How invoked - Enqueued by CMD or SEQ
- c. Constraints and limitations - DBUF buffer is 2048 words long, assuming no more than 2048 HC numbers may be passed in a packet.
- d. Processing -
 1. Initialize:

Zero the SEQ-call flag (SEQCAL), the disk-error flag (DKERR), the record numbers in memory (MREC1, MREC2), and set the DBUF Index J to five.
 2. Call Deque REX service to obtain the disk data packet and have it transferred to local buffer DBUF.
 3. Examine DBUF(2). If set to nine, set SEQCAL to one. Set LOOP equal to DBUF(5) to establish the loop count.
 4. Submit the command number in DBUF(1) to a CASE statement to determine appropriate processing submodule to call:
 - a) Call GETINI if command number = 3(Load);
 - b) Call GETAIM if command number = 20(AIMPOINT);
 - c) Call GETAL1 if command number = 14(ALT1STOW);
 - d) Call GETAL2 if command number = 15(ALT2STOW);
 - e) Call GETWSH if command number = 13(WASH);
 - f) Call GETSTO if command number = 6, 18 or 25(STOW, STHI, or ESTOW); and

Figure 3.2.2-21 Flowchart - CMDSUP

g) Call GETSAR if command number = 16 or 22
(SAVE or
RESTORE).

5. All submodules return to this step. Examine DKERR. If zero, go to step (6). If non-zero, Enqueue the alarms output task ALO with a disk-read error critical-alarm message. Go to step (7).
6. Examine the SEQ-call flag (SEQCAL). If zero, go to step (7). Otherwise, revise the command phase word in DBUF by setting it to ten (delete sequence-command phase). Enqueue SEQ using the DBUF address.
7. Relinquish control of task GET.

e. Error messages and recovery - a disk-read error message is sent to task ALO for any disk error.

3.2.2.4.1.15.2 Data, Logic and Command Paths

Input data:

Local common:

- a. Buffer DBUF contains all packet information
- b. DKERR - disk-error flag
- c. SEQCAL - SEQ-call flag

Output data:

- a. Enqueue of SEQ
- b. Enqueue of ALO
- c. DBUF(3) - command phase

3.2.2.4.1.15.3 Internal Data Description

See Table 3.2.2-VI for disk data-packet format.

3.2.2.4.1.15.4 Flowchart

See Figure 3.2.2-22 for the GET flowchart.

3.2.2.4.1.16 Submodule XVI - GETINI

3.2.2.4.1.16.1 Description

GETINI is responsible for fetching the HC bias AZ/EL angles from file HCB, the HC X,Y,Z coordinates from disk file HCC, and the last reported AZ/EL angles for the LOAD input command. HC numbers come from the local buffer DBUF.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET

Figure 3.2.2-22 Flowchart - GET

Figure 3.2.2-22 Flowchart - GET (continued)

c. Constraints and limitations - None

d. Processing -

1. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (16).
2. Increment J by one.
3. Set HC equal to DBUF(J).
4. Zero out all bits in HCST2G(HC) except the not-installed (bit 0) and the error-reporting (bits 11-15).
5. Set the unmarked bit (bit 4) in HCST2G(HC).
6. Compute the HC bias record number:
$$BREC = ((HC - 1) / 64) + 1.$$
7. Test if the bias record is already in memory by checking BREC equals MREC1. If so, go to step (8). If not, read the bias record into memory and set MREC1 equals BREC. If disk error occurs, set DKERR, and go to step (16).
8. Compute the HC's offset into the bias record.
9. Insert the bias AZ/EL angles into the first two words of HCDATG(HC).
10. Compute the HC coordinates record number:
$$CREC = ((HC - 1) / 32) + 1.$$
11. Test if the coordinates record is already in memory by checking CREC equals MREC2. If so, go to step (12). If not, read the coordinates record into memory and set MREC2 equals CREC. If disk error, set DKERR, and go to step (16).
12. Compute the HC's offset into the coordinates record.
13. Insert the five word HC X,Y,Z coordinates into words three through seven of HCDATG(HC).
14. Set HCCMDG(HC) equal to #9818.
15. This is a type-2 critical command. Increment EMCC1G(2) to tell task BHC how many type-2 commands exists in the HCCMDG array. Go to step (1).
16. Return to caller.

e. Error messages and recovery - for disk error, set DKERR and immediately return to caller.

3.2.2.4.1.16.2 Data, Logic and Command Paths

Input data:

- a. Local buffer DBUF contains HC number, size and HC numbers
- b. Disk file HCB (see Figure 3.2.2-23)
- c. Disk file HCC (see Figure 3.2.2-24)

Output data:

a. Global common:

- 1. HCST2G - derived HC status
- 2. HCDATG - HC-data output array
- 3. HCCMDG - HC-command output array
- 4. EMCC1G(2) - type-2 critical command count

b. Local common:

- 1. MREC1 - bias record number in memory
- 2. MREC2 - coordinates record number in memory
- 3. BREC - fetched record number for bias
- 4. CREC - fetched record number for coordinates
- 5. DKERR - disk-error flag

3.2.2.4.1.16.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.16.4 Flowchart

See Figure 3.2.2-25 for the GETINI flowchart.

3.2.2.4.1.17 Submodule XVII - GETAIM

3.2.2.4.1.17.1 Description

GETAIM is responsible for fetching the target aim-point X,Y,Z coordinates from the disk file AIM for the AIMPOINT input command. This data updates the memory-resident aim-point array AIMPTG. It also must test each HC whose number was passed in the data packet to determine if that HC is at, or approaching, the target. If so, the new target coordinates are sent to the HC. HC numbers come from the local buffer DBUF.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET
- c. Constraints and limitations - None
- d. Processing -
 - 1. Set the aim-point record offset (OFFSET) equal to DBUF(2) which is the aim-point array number.
 - 2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (9).

Figure 3.2.2-23 HC Bias File (HCB)

Figure 3.2.2-24 HC Coordinates (HCC)

Figure 3.2.2-25 Flowchart - GETINI

3. Increment J by one.
4. Set HC equal to DBUF(J).
5. Set the aim-point record number equal to HC and read the aim-point record into memory. Compute the offset to the HC data:

$$HOFSET = 5*(OFFSET-1).$$
 If disk error, set DKERR, and go to step (9).
6. Update the memory-resident aim-point array, AIMPTG(HC) equals HC aim-point X,Y,Z coordinates in record.
7. Test the HC to be at, or approaching, its target. If:

$$HCST1G(HC).AND.\#007C = \#0020,$$
 go to step (8). Otherwise, go to step (2) for next HC.
8. Set HCDATG(HC) to the five words of aim-point X,Y,Z coordinates. Set HCCMDG(HC) equal to #8020, and go to step (2).
9. Return to caller.
- e. Error messages and recovery - for disk error, set DKERR and immediately return to caller.

3.2.2.4.1.17.2 Data, Logic and Command Paths

Input data:

- a. Global common:
 - HCCMDG - last commanded status
- b. Local common:
 1. OFFSET - offset into aim-point record
 2. Local buffer DBUF for HC numbers
- c. Disk file AIM (see Figure 3.2.2-26)

Output data:

- a. Global common:
 1. HCDATG - HC-data output array
 2. HCCMDG - HC-command output array
 3. AIMPTG - memory-resident aim-point array
- b. Local common:
 1. LOOP - loop count
 2. OFFSET - offset into aim-point record
 3. HOFSET - aim-point offset
 4. DKERR - disk-error flag

NOTE: Aim-point data is contained in words 1-100 of each record, while words 123-128 are used by the SAVE and RESTORE commands.

Figure 3.2.2-26 Aim-Point Arrays File (AIM)

3.2.2.4.1.17.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.17.4 Flowchart

See Figure 3.2.2-27 for the GETAIM flowchart.

3.2.2.4.1.18 Submodule XVIII - GETAL1

3.2.2.4.1.18.1 Description

GETAL1 is responsible for fetching the Alt1stow AZ/EL angles from disk file AL1 for the input command ALT1STOW. HC numbers come from the local buffer DBUF.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET
- c. Constraints and limitations - None
- d. Processing -
 1. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (8).
 2. Increment J by one.
 3. Set HC equal to DBUF(J).
 4. Compute the record number:
$$BREC = ((HC-1)/64)+1.$$
 5. Test if record number already in memory by checking BREC equals MREC1. If so, go to step (6). If not, read the Alt1stow record into memory and set MREC1 equal to BREC. If disk error, set DKERR, and go to step (8).
 6. Compute the HC's offset into the Alt1stow record.
 7. Insert the Alt1stow AZ/EL angles into words one through two of HCDATG(HC). Set HCCMDG(HC) equal to #8070, and go to step (1).
 8. Return to caller.
- e. Error messages and recovery - for disk error, set DKERR, and immediately return to caller.

3.2.2.4.1.18.2 Data, Logic and Command Paths

Input data:

- a. BREC - fetched record number
- b. Local file DBUF
- c. Disk file AL1 (see Figure 3.2.2-28)

Figure 3.2.2-27 Flowchart - GETAIM

Figure 3.2.2-28 Format and Structure of HC ALT1STOW Angles Disk File

Output data:

a. Global common:

1. HCDATG - HC-data output array
2. HCCMDG - HC-command output array

b. Local common:

1. LOOP - loop count
2. MREC1 - record number in memory
3. BREC - fetched record number

3.2.2.4.1.18.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.18.4 Flowchart

See Figure 3.2.2-29 for the GETAL1 flowchart.

3.2.2.4.1.19 Submodule XIX - GETAL2

3.2.2.4.1.19.1 Description

GETAL2 is responsible for fetching the Alt2stow elevation angle from the disk file AL2 for the input command ALT2STOW. HC numbers come from the local buffer DBUF. The azimuth angle for the output command comes from the AZIMG array.

a. Language/used - FORTRAN IV

b. How invoked - called by GET

c. Constraints and limitations - None

d. Processing -

1. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (8).
2. Increment J by one.
3. Set HC equal to DBUF(J).
4. Compute the record number:
$$BREC = ((HC-1)/64)+1.$$
5. Test if record is in memory by checking BREC equals MREC1. If so, go to step (6). If not, read the Alt2stow record into memory and set MREC1 equal to BREC. If disk error, set DKERR and go to step (8).
6. Compute HC's offset into the record.
7. Insert the Alt2stow elevation into word 2 of HCDATG(HC) and insert AZIMG(HC) into word 1 of HCDATG(HC). Set HCCMDG(HC) equal to #8074, and go to step (1).

Figure 3.2.2-29 Flowchart - GETAL1

8. Return to caller.

- e. Error messages and recovery - for disk error, set DKERR and immediately return to caller.

3.2.2.4.1.19.2 Data, Logic and Command Paths

Input data:

- a. Global common:
 - AZIMG - last reported azimuth angle for HC
- b. Local common:
 - 1. Local buffer DBUF
 - 2. BREC - fetched record number
- c. Disk file AL2 (see Figure 3.2.2-30)

Output data:

- a. Global common:
 - 1. HCDATG - HC-data output array
 - 2. HCCMDG - HC-command output array
- b. Local common:
 - 1. LOOP - loop count
 - 2. MREC1 - record number in memory
 - 3. BREC - fetched record number

3.2.2.4.1.19.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.19.4 Flowchart

See Figure 3.2.2-31 for the GETAL2 flowchart.

3.2.2.4.1.20 Submodule XX - GETWSH

3.2.2.4.1.20.1 Description

GETWSH is responsible for fetching the Wash AZ/EL angles from the disk file WSH for the input command WASH. HC numbers come from the local buffer DBUF.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET
- c. Constraints and limitations - None
- d. Processing -
 - 1. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (8).
 - 2. Increment J by one.

Figure 3.2.2-30 Format and Structure of ALT2STOW Angle Disk File

Figure 3.2.2-31 Flowchart - GETAL2

3. Set HC equal to DBUF(J).
 4. Compute the record number:

$$BREC = ((HC-1)/64)+1.$$
 5. Test if record number already in memory by checking BREC equals MREC1. If so, go to step (6). If not, read the Wash record into memory and set MREC1 equal to BREC. If disk error, set DKERR and go to step (8).
 6. Compute HC's offset into the Wash record.
 7. Insert the Wash AZ/EL into words one through two of HCDATG(HC). Set HCCMDG(HC) equal to #8068 and go to step (1).
 8. Return to caller.
- e. Error messages and recovery - for disk error, set DKERR and immediately return to caller.

3.2.2.4.1.20.2 Data, Logic and Command Paths

Input data:

- a. BREC - fetched record number
- b. Local buffer DBUF
- d. Disk file WSH (see Figure 3.2.2-32)

Output data:

- a. Global common:
 1. HCDATG - HC-data output array
 2. HCCMDG - HC-command output array
- b. Local common:
 1. LOOP - loop count
 2. MREC1 - record number in memory
 3. BREC - fetched record number

3.2.2.4.1.20.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.20.4 Flowchart

See Figure 3.2.2-33 for the GETWSH flowchart.

3.2.2.4.1.21 Submodule XXI - GETSTO

3.2.2.4.1.21.1 Description

GETSTO is responsible for fetching the Stow AZ/EL angles from disk file STO for the input commands STOW, STHIWIND, or ESTOW.

Figure 3.2.2-32 Format and Structure of Wash Angles File (WSH)

Figure 3.2.2-33 Flowchart - GETWSH

HC numbers come from the local buffer DBUF.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET
- c. Constraints and limitations - None
- d. Processing -
 1. Zero, the critical-command bit value (BIT3).
 2. If command is STHIWIND, set BIT3 equal to #1000.
 3. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (10).
 4. Increment J by one.
 5. Set HC equal to DBUF(J).
 6. Compute the record number:
$$BREC = ((HC-1)/64)+1.$$
 7. Test if the record number is in memory by checking BREC equals MREC1. If so, go to step (8). If not, read the Stow record into memory and set MREC1 equal to BREC. If disk error, set DKERR and go to step (10).
 8. Compute the HC's offset into the Stow record.
 9. Insert the Stow AZ/EL into words one through two of HCDATG(HC). Set HCCMDG(HC) equal to #8060 plus BIT3. If DBUF(3) equals nine, reset HC-in-Stow-sequence:
$$HCST3G(HC) = HCST3G(HC).AND.\#FEFF.$$

Go to step (3).
 10. Return to caller.
- e. Error messages and recovery - for disk error, set DKERR and immediately return to caller.

3.2.2.4.1.21.2 Data, Logic and Command Paths

Input data:

- a. Local buffer DBUF
- b. BREC - fetched record number
- c. Disk file STO (see Figure 3.2.2-34)

Output data:

- a. Global common:
 1. HCDATG - HC-data output array
 2. HCCMDG - HC-command output array
- b. Local common:
 1. LOOP - loop count
 2. MREC1 - record number in memory
 3. BREC - fetched record number

Figure 3.2.2-34. Format and Structure of HC Stow Angles Disk File

3.2.2.4.1.21.3 Internal Data Description

Critical command bit value:

- BIT3 = 0: command is not STHIWIND
- = #1000: command is critical (STHIWIND)

3.2.2.4.1.21.4 Flowchart

See Figure 3.2.2-35 for the GETSTO flowchart.

3.2.2.4.1.22 Submodule XXII - GETSAR

3.2.2.4.1.22.1 Description

GETSAR is responsible for two command actions:

- a. Write the field's Tracking configuration (those HCs which are in the Standby and Track orientations) to disk file SAV; and
- b. Fetch the saved Tracking configuration from disk file SAV and try to restore this configuration to the field.

The local buffer DBUF contains the HCs which are in either Standby or Track orientation for the SAVE command. RESTORE processing does not get HC numbers in the DBUF buffer and must read every record of file SAV and input the current HC status from the HCSTIG array. Alarms bits are set for those HCs which are unable to return to their saved orientation.

- a. Language used - FORTRAN IV
- b. How invoked - called by GET
- c. Constraints and limitations - None
- d. Processing -

1. If the command is not SAVE, go to step (12).

SAVE processing:

2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (4).
3. Insert the HC number in DBUF(I) into the sort buffer SOBUF(I) in ascending order, and go to step (2).
4. Set the SOBUF buffer index J equal to 1.
5. Perform DO-UNTIL processing where I equals one to 2048. If I is greater than 2048, go to step (11).
6. Set record number MREC1 equal to I. If J is greater than LOOP, set the SAV-file HC number, SAVHC equal to zero, and go to step (7). Otherwise, set the SAV-file HC number, SAVHC equal to SOBUF(J).

Figure 3.2.2-35 Flowchart - GETSTO

7. Clear the SAV-file record buffer: SOBUF(1-6) equals zero.
8. If I is not equal to SAVHC, go to step (9) to write a blank record in the SAV file for this HC number. Otherwise, increment J by one and get the HC status:

HC1 = HCST1G(SAVHC).AND.#7C.

If HC1 equals #30 (Standby), set SBUF(1) equal to minus one, and go to step (9). Otherwise, set SBUF(1) equal to one (save orientation is Track) and place the HC's aim-point in the record, SBUF(2-6) equals AIMPTG(1-5,SAVHC).

9. Write a record to disk file SAV using MREC1 as the record number. If no disk error occurs, go to step (5).
10. For disk errors, set disk-error flag DKERR equal to one.
11. Return to caller.

RESTORE processing:

12. Perform DO-UNTIL processing where I equals one to 2048. If I is greater than 2048, go to step (11).
13. Set record number MREC1 equal to I. Read a record from the disk file SAV using MREC1 as record number. If disk error occurs, go to step (10).
14. Get the HC status:

HC1 = HCST1G(I).AND.#7C.

If the first word of the SAV record, SBUF(1) equals zero, this HC was not in Standby or Track at save time; go to step (12). Otherwise, if SBUF(1) is greater than zero (save orientation was Track), go to step (19). Otherwise, SBUF(1) is less than zero (save orientation was Standby).

15. If HC1 equals #30 (Standby), HC is in proper orientation and requires no movement; go to step (12). Otherwise, if HC1 is not equal to #20, go to step (18) to set HC's alarm bit. If HC1 equals #20 (at or approaching Track), it can be commanded back to its save orientation (Standby).
16. Get the HC's corridor assignment by:

L=HCST3G(I).AND.#FOOO.

Right-justify by shifting right 12 bits.

17. Set HCDATG(1-5,I) equal to CORRCG(1-5,L) to pick

up the five-word CULP X,Y,Z coordinates. Set HCCMDG(I) equal to #8030, and go to step (12).

Alarms processor for RESTORE, one step only:

18. Set the RESTORE alarms bit (bit 6) in HCST1G(I) to tell Alarms-dection task ALM that this HC was not in the proper orientation to return to its save orientation. Go to step (12).
19. If HC1 equals #20 (at or approaching Track), HC is in proper orientation but could be assigned a different aim-point than the one saved at save time; go to step (21). Otherwise, if HC1 is not equal to #30, go to step (18) to set HC's alarm bit. If HC1 equals #30 (Standby), fall through to step (20).
20. Set HCDATG(1-5,I) equal to SBUF(2-6) to pick up the five-word save-time aim-point X,Y,Z coordinates. Set HCCMDG(I) equal to #8020. Update the memory-resident aim-point array by setting AIMPTG(1-5,I) equal to SBUF(2-6). Go to step (12).
21. If the save-time aim-point located in SBUF(2-6) is equal to the latest memory-resident aim-point, AIMPTG(1-5,I), no adjustment movement to a new aim-point is required; go to step (12). Otherwise, the save-time aim-point must be sent to the HC in the field; go to step (20).

- e. Error messages and recovery - for disk errors, set DKERR and immediately return to caller.

3.2.2.4.1.22.2 Data, Logic and Command Paths

Input data:

a. Global common:

1. HCST1G - HC status
2. AIMPTG - memory-resident aim-point array
3. CORRCG - corridor coordinates
4. HCST3G - HC corridor assignment

b. Local common:

1. DBUF - local buffer of HC numbers
2. SBUF - 6-word SAV record buffer

Output data:

a. Global common:

1. HCDATG - HC-data output array
2. HCCMDG - HC-command output array
3. HCST2G - HC-derived status, restore-alarm bit

4. AIMPTG - memory-resident aim-point array

b. Local common:

1. MRECL - file record number
2. HC - involved HC number
3. HCL - current HC field status
4. SBUF - 6-word SAV record buffer

c. Disk file SAV (see Figure 3.2.2-36)

3.2.2.4.1.22.3 Internal Data Description

SAV record buffer:

SBUF - 6-word record buffer for disk file SAV processing

3.2.2.4.1.22.4 Flowchart

See Figure 3.2.2-37 for the GETSAR flowchart.

3.2.2.4.1.23 Submodule XXIII - SEQ

3.2.2.4.1.23.1 Description

SEQ is responsible for overall control of sequence processing. It determines the correct processing path for command phases 4, 5, 10, 20, and 30. The dequeued sequence command packet follows the format of Table 3.2.2-V.

a. Language used - FORTRAN IV

b. How invoked - activated via Enque by tasks CMD or GET or by timer expiration connected and thawed by this task.

c. Constraints and limitations - None

d. Processing -

1. Call TIMDT4 to acquire current time: minutes since midnight and ticks in minutes.
2. Call DEQU to attempt to acquire a sequence command packet. If the message length returned by DEQU is 0 (queue empty), activation was activated by a timer expiration; go to Step (9). If the length is nonzero, the sequence command packet is located in buffer SBUF.

Where Save Mode = 0 : other

> 0 : HC was at Track and its Aim point is in words 1-5

< 0 : HC was at Stand by

NOTE: Aim-point data is contained in words 1-100 of each record, while words 123-128 are used by the SAVE and RESTORE commands.

Figure 3.2.2-36 Tracking Configuration Save File (AIM)

Figure 3.2.2-37 Flowchart - GETSAR

Figure 3.2.2-37 Flowchart -GETSAR (continued)

Decode the dequeue message:

3. If the command phase in SQBUF(2) is not four, go to Step (4). At least some of the heliostats involved in the sequence command are moving towards either their CLLPs or CULPs. Zero the relink flag (RELINK) and call submodule SEQADD to put sequence in the active-sequence list (ACTLIS). Upon return, go to Step (12).
4. If the command phase is five, go to Step (7). If the command phase is not ten, go to Step (5). Call submodule SEQDEL to delete sequence. Upon return, go to Step (8).
5. The activation of this task was caused by an enqueue by either the field power fail task (PLH) or the HAC failover task (SWI). If the command phase is not 20 (field power loss), go to Step (6). Set the delete level = -2 (delete all sequences) and call submodule SEQDEL. Unconnect timer if one was assigned to this task and go to Step (13).
6. If the command phase is not 30 (HAC failover), go to Step (8). Set the relink flag (RELINK) and go to Step (12) to set up timer.
7. Add the sequence to the wait-sequence list (WAITSQ). See Figure 3.2.2-38 for format. If list is full, call MSSG4 to print following message on system console:

"CANNOT ADD SEQUENCE TO WAIT LIST"

and go to Step (12).

8. Call submodule SEQCCK to add and/or search the wait-sequence list and determine whether any sequence has all of its required corridors free. If not, go to Step (12). Otherwise, zero the relink flag and call submodule SEQADD to put sequence into the active-sequence list (ACTLIS). Upon return, call submodule SEQCOR to move the heliostats into their respective corridor(s). Upon return, go to Step (12).

Activation caused by timer expiration:

9. Determine visit sequence by examining the time-link pointer (DUMTLP). Call submodule SEQGAT to gather the sequence's heliostats

WAIT SEQ. CELL #	WAIT SEQUENCE CELLS
1	(See Table 3.2.2-V for format)
.	
.	
.	
15	

NOTES: Entries are up to 23 words long.

First word = 0 for unused entries.

All data comes from the deque sequence command
packet buffer SQBUF.

Figure 3.2.2-38 Wait-Sequence List (WAITSQ)

arriving at either their CLLPs or CULPs. Upon return, go to Step (10) if gather process done. Otherwise, check if the sequence was completely robbed (the commands STHIWIND, LOAD, or HOLD may rob some or all heliostats from an established sequence). If so, go to Step (4) to delete sequence. Otherwise, set the relink flag and call submodule SEQRLK to relink visit time-links in the active-sequence list. Upon return, go to Step (12).

10. When the gather process is done, check the command phase to be eight (corridor gather). If so, go to Step (11). If command phase is four, all of the involved HCs are either at their CULPs or CLLPs. The sequence must be taken out of the active-sequence list and added to the corridor-wait list to check if all required corridors are free. Therefore, transfer sequence data into SQBUF, set the delete level = 0 (delete sequence only from active-sequence list) and call SEQDEL. Upon return, go to Step (7).
11. If command phase is eight, call submodule SEQBPT to command the involved HCs to track either their CULPs or CLLPs. Upon return, check the command phase to be ten and if so, go to Step (4) to delete sequence. If updated command phase is nine, call ENQU to send a disk data command packet to task GET in order to send HCs to their final destination. Go to Step (8).

Exit processing:

12. If relink flag is zero, go to Step (13). Fetch the next visit time using the active-sequence time-link pointer (DUMTLP). If zero, call UNCON4 to unconnect any timer allocated to this task. For a valid revisit time, call CONNCT to obtain a timer. Call THAW4 to unfreeze the timer.
 13. Call RETIRE to exit and save timer resource.
- e. Error messages and recovery - if wait-sequence list has no unoccupied entries for a new wait sequence, output text message to system console and go to exit processing.

3.2.2.4.1.23.2 Data, Logic and Command Paths

Input data:

Local common:

- a. SQBUF - deque buffer for sequence packet
- b. WAITSQ - wait sequence list (see Figure 3.2.2-38)
- c. ACTLIS - dummy-cell time link in active-sequence list

Output data:

Local Common:

- a. RELINK - relink ACTLIS flag
- b. STUB - future-definition event flag
- c. WAITSQ - wait-sequence list

3.2.2.4.1.23.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.23.4 Flowchart

See Figure 3.2.2-39 for the SEQ flowchart.

3.2.2.4.1.24 Submodule XXIV - SEQGAT

3.2.2.4.1.24.1 Description

SEQGAT is responsible for gathering HCs at either their CLLPs or CULPs for the sequence being visited. As HCs report position compare, they are deleted from the gather buffer and inserted into a leased buffer. When the gather buffer is empty or the maximum time is reached, the gather process is done. Any HC not responding by the maximum time will be set offline and out of the sequence by setting the HC's timeout bit in HCST2G(HC).

- a. Language used - FORTRAN IV
- b. How invoked - called by SEQ for command phases four and eight
- c. Constraints and limitations - None
- d. Processing -
 1. Set gather loop count (LOOP) equal to the gather buffer size.
 2. If the sequences-gather lease flag is set, go to Step (3). Otherwise, a buffer must be leased. Call routine LEASE to obtain an area in which to put the HCs reporting position compare. Save the lease-area address in the sequence's ACTLIS entry. Zero the lease buffer size and set the gather-lease flag.
 3. Determine the lease buffer pointer K equals lease size plus one.
 4. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to Step (9).

Figure 3.2.2-39 Flowchart - SEQ

Figure 3.2.2-39. Flowchart - SEQ (Continued)

Figure 3.2.2-39 Flowchart - SEQ (continued)

5. Set N equal to element I of the gather buffer. Check if HC is still in the sequence. If so, go to Step (7).
6. Decrement the gather buffer size by one and delete the HC number from the gather buffer. Go to Step (4).
7. Check if the HC reports position compare. If so, go to Step (8). Otherwise, check if the timeout flag is set. If not, go to Step (4). If so, set the timeout flag in the HCST2G word (bit 8), and go to Step (6).
8. Transfer the HC number from the gather buffer to the lease buffer. Increment the lease buffer-pointer K and the lease buffer size. Go to Step (6).
9. If the timeout flag is set, go to Step (10). Otherwise, check the gather buffer size. If zero, gather is done; set return flag equal to one, and go to Step (11). If not zero, gather is not done; set return flag to zero, and go to Step (11).
10. Check if the lease buffer size is zero. If so, the sequence was robbed by an emergency command; set return flag equal to minus one, and go to Step (11). If not zero, gather is done; set return flag equal to one, and go to Step (11).
11. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.24.2 Data, Logic and Command Paths

Input data:

- a. Global common:
 1. HCST3G - HC sequence assignment
 2. HCST1G - HC position-compare bit
- b. Local common:
 1. Gather buffer
 2. Gather-lease flag
 3. TMOUT - sequence maximum-time flag

Output data:

- a. Global common:
 - HCST2G - HC timeout bit
- b. Local common:
 1. Lease buffer - those HCs reporting position compare for gather process
 2. Lease buffer address
 3. Lease buffer size
 4. Lease buffer pointer
 5. Gather buffer size
 6. Gather buffer
 7. Gather return flag

3.2.2.4.1.24.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.24.4 Flowchart

See Figure 3.2.2-40 for the SEQGAT flowchart.

3.2.2.4.1.25 Submodule XXV - SEQBPT

3.2.2.4.1.25.1 Description

SEQBPT is responsible for issuing beam-pointing output commands for tracking either the CULP or the CLLP. When all involved HCs have been so commanded, release the corridor resources and free the buffer leased in submodule SEQGAT if the command is UNSTOW.

- a. Language used - FORTRAN IV
- b. How invoked - called by SEQ
- c. Constraints and limitations - none
- d. Processing -
 1. Set LOOP to the HC buffer size.
 2. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (6).
 3. Set N equal to element I in the HC buffer to get HC number. If HC is in the sequence, go to step (4). If not, decrement the buffer size and delete the HC number from the buffer. Go to step (2).
 4. If the command is not UNSTOW, go to step (5). Otherwise, find the HC's corridor number J and right-justify. Set HCDATG(1-5,N) equal to CORRCG(1-5,J) to pick up the five-word CULP X,Y,Z coordinates. Set HCCMDG(N) equal to #8030, and go to step (2).
 5. If the command is UNSTOW, find HC's corridor number J and right-justify. Set HCDATG(1-5,N) equal to CORRCG(6-10,J) to pick up the five-word CLLP X,Y,Z coordinates. Set HCCMDG(N) equal to #8034, and go to step (2).
 6. Initialize for releasing corridor resources by setting sequence-packet corridor index J equal to four. Set LOOP equal to number of corridors in packet, SQBUF(4).
 7. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (9).
 8. Increment J by one and set corridor number COR equal to SQBUF(J). Zero the corridor/sequence

Figure 3.2.2-40 Flowchart - SEQGAT

Figure 3.2.2-40 Flowchart - SEQGAT (continued)

number element: CORSQG(COR) equals zero.
Zero the corridor status element CORRSG(COR)
equal to zero. Go to step (7).

9. If the command is UNSTOW(corridor-up sequence),
go to step (10). Otherwise, set the command
phase to nine, and go to step (11).
10. For UNSTOW commands, call routine FREE to
release the leased buffer obtained in SEQGAT.
Set the command phase to ten.
11. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.25.2 Data, Logic and Command Paths

Input data:

a. Global common:

HCST3G - HC corridor and sequence assignment

b. Local common:

SQBUF - HC sequence packet

Output data:

a. Global common:

1. HCDATG - HC-data output array
2. HCCMDG - HC-command output array
3. CORSQG - corridor/sequence number array
4. CORRSG - corridor-status array

b. Local common:

LOOP - loop counter

3.2.2.4.1.25.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.25.4 Flowchart

See Figure 3.2.2-41 for the SEQBPT flowchart.

3.2.2.4.1.26 Submodule XXVI - SEQCCK

3.2.2.4.1.26.1 Description

SEQCCK is responsible for searching the corridor-wait list (WAITSQ) and determining if any sequence can be added to the active-sequence-list. This is allowed only if all the corridors required by the sequence are free. When this occurs, the sequence is deleted from the wait list and the sequence-ready flag is set.

a. Language used - FORTRAN IV

b. How invoked - called by SEQ

Figure 3.2.2-41 Flowchart - SEQBPT

Figure 3.2.2-41 Flowchart - SEQBPT (continued)

c. Constraints and limitations - None

d. Processing -

1. Perform DO-UNTIL processing where J equals one to 15. If J is greater than 15, go to step (5).
2. See Figure 3.2.2-38 for the WAITSQ array format. Check WAITSQ(J,1) for a negative number. If so, this is the end of list; go to step (5). If not, determine if a sequence is present (WAITSQ(J,1) is non-zero). If not, go to step (1). If so, set the loop count LOOP equal to WAITSQ(J,2), the number of corridors required for the sequence. Set the WAITSQ corridor index ICOR equal to three to point at the first corridor number in the entry.
3. Perform DO-UNTIL processing where K equals one to LOOP. If K is greater than LOOP, go to step (6).
4. Set the corridor number COR equal to WAITSQ(J,ICOR). If CORRSG(COR) equals zero (corridor is free), go step (3). If not, go to step (1) to get another wait-sequence entry.
5. Clear the sequence-ready flag, and go to step (1).
6. Set corridor index ICOR equal to three.
7. Perform DO-UNTIL processing where K equals one to LOOP. If K is greater than LOOP, go to step (9).
8. Get corridor number COR equal to WAITSQ(J,ICOR). If command is UNSTOW, set command phase equal to six and set the corridor's status word for ready to go up, CORRSG(COR) equals one; go to step (7). If not UNSTOW, set the command phase equal to seven and set the corridor's status word for ready to go down, CORRSG(COR) equals two; go to step (7).
9. Set SQAD equal to address of the sequence packet which is contained in WAITSQ(J,11). Delete the sequence from the wait-sequence list by WAITSQ(J,1) equal to zero.
10. Set the sequence-ready flag.
11. Return to caller.

e. Error messages and recovery - None

3.2.2.4.1.26.2 Data, Logic and Command Paths

Input data:

a. Global common:

CORRSG - corridor-status array

b. Local common:

1. WAITSQ - wait-sequence list
2. SQBUF(1) - command number

Output data:

a. Global common:

CORRSG - corridor-status array

b. Local common:

1. LOOP - loop count
2. Sequence-ready flag
3. WAITSQ - wait-sequence list
4. COR - corridor assigned to sequence
5. ICOR - WAITSQ-entry corridor index
6. SQBUF(2) - command phase for sequence
7. SQAD - address of sequence packet

3.2.2.4.1.26.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.26.4 Flowchart

See Figure 3.2.2-42 for the SEQCK flowchart.

3.2.2.4.1.27 Submodule XXVII - SEQCOR

3.2.2.4.1.27.1 Description

SEQCOR is responsible for commanding the involved HCs into their respective corridors. If an HC has been robbed from the sequence, the HC is deleted from the buffer.

a. Language used - FORTRAN IV

b. How invoked - called by SEQ

c. Constraints and limitations - None

d. Processing -

1. Set LOOP equal to buffer size.
2. If command is UNSTOW (up corridor), set HFCCOI (HFC corridor-increment word) to zero. If not UNSTOW, set HFCCOI equal to four.
3. Perform DO-UNTIL processing where I equals one to LOOP. If I is greater than LOOP, go to step (7).
4. Set N equal to element I in the buffer to get the HC number.
5. Determine if HC is still in the sequence. If so, go to step (6). If not, decrement the buffer

Figure 3.2.2-42 Flowchart - SEQCCK

Figure 3.2.2-42. Flowchart - SEQCK (continued)

size by one and delete the HC number from the buffer. Go to step (3).

6. Set HCCMDG(N) equal to #8040 plus HFCCOI, and go to step (3).

7. Set command phase equal to eight (gather HCs in corridor) and return to caller.

e. Error messages and recovery - None

3.2.2.4.1.27.2 Data, Logic and Command Paths

Input data:

a. Global common:

HCST3G - HC sequence-assignment array

b. Local common:

1. Gather buffer

2. HFCCOI - HFC corridor-increment word

3. Gather buffer size

Output data:

a. Global common:

HCCMDG - HC-command output array

b. Local common:

1. LOOP - loop count

2. HFCCOI - HFC corridor-increment word

3. SQBUF(2) - command phase

4. Gather buffer

5. Gather buffer size

3.2.2.4.1.27.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.27.4 Flowchart

See Figure 3.2.2-43 for the SEQCOR flowchart.

3.2.2.4.1.28 Submodule XKVIII - SEQADD

3.2.2.4.1.28.1 Description

SEQADD is responsible for either adding a sequence to the active-sequence list (ACTLIS) or merely providing a call to the relink submodule (SEQRLK). See Table 3.2.2-VII for ACTLIS format.

a. Language used - FORTRAN IV

b. How invoked - called by SEQ

c. Constraints and limitations - None

d. Processing -

Figure 3.2.2-43 Flowchart - SEQCOR

<u>WORD</u>	<u>DESCRIPTION</u>
1,2	NEXT VISIT TIME FOR THIS SEQUENCE (MINUTES & TICKS SINCE MIDNIGHT)
3	TIME-LINK CELL POINTER; CONTAINS THE CELL # HAVING THE NEXT CHRONOLOGICAL VISIT TIME AS COMPARED TO THIS SEQUENCE'S VISIT TIME
4	NEXT AVAILABLE MEMORY CELL; WHEN THIS CELL IS EMPTY, VALUE IS NEXT EMPTY CELL #; WHEN A SEQUENCE OCCUPIES THIS CELL, VALUE IS THIS CELL #
5,6	MAXIMUM (FINAL) GATHER TIME FOR THIS SEQUENCE (MINUTES & TICKS SINCE MIDNIGHT)
7	COMMAND # (VALUES: 6, 14, 17 or 18)
8	COMMAND PHASE (VALUES: 4 or 8)
9	SEQUENCE # (RANGE: 1 to 16)
10	# OF CORRIDORS REQUIRED (RANGE: 1 to 8)
11-N	CORRIDOR #(s)
N+1	# OF BUFFER DESCRIPTIONS TO FOLLOW
N+2	OFFSET (INTO COMQU2) FOR LEASED HC # BUEFER
N+3	SEQUENCE GATHER COUNT
N+4	SIZE FOR BUFFER #1 (RANGE: 1 to 2048)
N+5	OFFSET (INTO COMQU2) FOR BUFFER #1
N+6 thru N+11	Optional - see Table 3.2.2-V

NOTE: Format of words 7 thru N+11 follow Table 3.2.2-V except word N+3 which is assigned as a counter. List is 16 cells of 29 words per cell. It is a time-linked list of active sequences (HCs moving).

Table 3.2.2-VII Typical Cell in Active - Sequence List (ACTLIS)

1. If the command phase is four (gather), go to step (2). Otherwise, set the corridor-walk gather minimum and maximum times to current time plus 360 and 424 seconds, respectively. Go to step (3).
2. Set the non-corridor gather minimum and maximum times to current time plus 400 and 464 seconds, respectively.
3. Insert the sequence number and minimum time into the cell (add cell) referred to as available in the dummy cell in ACTLIS. Insert the maximum time, the gather buffer address, and size. Zero the lease-flag word in the cell. Swap the available memory numbers between the add cell and the dummy cell. If the dummy time-link cell number is not equal to zero, go to step (4). If zero, no other sequences are active; set the dummy time-link cell number equal to add cell number. Set the relink flag, and go to step (9). Reorder the time-linked list (see Figure 3.2.2-44 for example).
4. Set the old cell equal to zero for dummy reference. Set the compare cell equal to dummy time-link cell.
5. Check if the add-cell's time is less than compare-cell's time. If yes, go to step (7). Reorder the time-linked list (see Figure 3.2.2-44 for example). Otherwise, check if add-cell's time equals compare-cell's time. If yes, increment the add-cell's time by 500 milliseconds and check if the compare-cell's time link is zero. If not, go to step (6). If so, set compare-cell's time link equal to add-cell number. Set the add-cell's time link equal to zero (add cell has largest visit-time value in ACTLIS). Go to step (9).
6. Set old cell equal to compare cell. Set compare cell equal to compare-cell's time link. Go to step (5).
7. Check if the old cell equals zero (dummy). If so, set dummy time link equal to add cell. If not, set old-cell's time link equal to add cell. Set the add-cell's time link equal to compare cell. If old cell equals zero, set the relink flag, and go to step (8). Otherwise, go to step (9).
8. Call submodule SEQRLK to relink all time-link cell pointers according to visit times.
9. Return to caller.

e. Error messages and recovery - None

$\begin{pmatrix} 0 & 0 \\ 0 & 1 \end{pmatrix}$ <p>DUMMY CELL</p> $\begin{pmatrix} 0 & 0 \\ 0 & 2 \end{pmatrix}$ <p>CELL #1</p> $\begin{pmatrix} 0 & 0 \\ 0 & 3 \end{pmatrix}$ <p>CELL #2</p> $\begin{pmatrix} 0 & 0 \\ 0 & 0 \end{pmatrix}$ <p>CELL #3</p> <p>Assume ACTLIS to hold 3 seqs. for this example. Only first 5 words of an entry are used here. Dummy cell is at top and contains no visit time value.</p> <p>Legend:</p> <p>V.T. SEQ</p> <p>T.L. A.M.</p> <p>V.T. - Visit time (minutes, ticks)</p> <p>A.M. - Next available memory cell when this cell cleared</p> <p>T.L. - Time link pointing to cell with next visit time</p> <p>SEQ - Sequence #</p>	$\begin{pmatrix} 1 & 0 \\ \emptyset & 2 \end{pmatrix}$ <p>1</p> $\begin{pmatrix} 10:06:40 & 1 \\ \emptyset & \emptyset \end{pmatrix}$ <p>0 1 2</p> $\begin{pmatrix} 0 & 0 \\ 0 & 3 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \\ 0 & 0 \end{pmatrix}$ <p>Action: Add seq. 1, cmd phase = 4</p> <ul style="list-style-type: none"> - Current time = 10:00 - Seq min = visit time = 10:06:40 - Seq max = 10:07:44 - Av. mem cell in dummy cell is 1 (add cell) - Insert visit time, seq # in cell 1 - Swap av. mem. #s between add cell and dummy cell - Dummy T.L. = 0 ? Yes - Dummy T.L. = add cell - Set relink flag 	$\begin{pmatrix} 1 & 0 \\ 1 & 3 \end{pmatrix}$ <p>2</p> $\begin{pmatrix} 10:06:40 & 1 \\ 2 & 1 \end{pmatrix}$ <p>$\emptyset$</p> $\begin{pmatrix} 10:07 & 2 \\ \emptyset & \emptyset \end{pmatrix}$ <p>0 2 2</p> $\begin{pmatrix} 0 & 0 \\ 0 & 0 \end{pmatrix}$ <p>Action: Add seq. 2, cmd phase = 8</p> <ul style="list-style-type: none"> - Current time = 10:01 - Seq min = visit time = 10:07 - Seq max = 10:08:04 - Av. mem cell in dummy cell is 2 (add cell) - Insert visit time, seq # in cell 2 - Swap av. mem. #s between add cell and dummy cell - Dummy T.L. = 0 ? No - Old cell = 0 (Dummy) - Comp cell = dummy T.L. = 1 - Add cell V.T. < comp cell V.T. ? No - Comp cell T.L. = 0 ? Yes - Comp cell T.L. = add cell = 2 - Add cell T.L. = 0
--	---	---

Figure 3.2.2-44 Example of ACTLIS Management

$\begin{pmatrix} 0 \\ 1 & 3 \end{pmatrix}$ $\begin{pmatrix} 56 \\ 10:06:40 & 1 \end{pmatrix}$ $\begin{pmatrix} 2 & 1 \end{pmatrix}$ $\begin{pmatrix} 10:07 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ <p>Action: Visit seq. 1</p> <ul style="list-style-type: none"> - Current time = 10:06:41 - Old cell = 0 - Visit cell visit time = 10:06:56 - Comp cell = visit cell T.L. = 2 - Comp cell = 0 ? No - Visit time < comp. cell V.T. ? Yes - Dummy T.L. = visit cell = 1 	$\begin{pmatrix} 0 \\ 2 & 3 \end{pmatrix}$ $\begin{pmatrix} 10:07:12 \\ 10:06:56 & 1 \end{pmatrix}$ $\begin{pmatrix} 0 & 1 \end{pmatrix}$ $\begin{pmatrix} 2 & 1 \end{pmatrix}$ $\begin{pmatrix} 10:07 & 2 \end{pmatrix}$ $\begin{pmatrix} 1 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ <p>Action: Visit seq. 1</p> <ul style="list-style-type: none"> - Current time = 10:06:57 - Old cell = 0 - Visit cell V.T. = 10:07:12 - Comp cell = visit cell T.L. = 2 - Comp cell = 0 ? No - Visit time < comp cell V.T. ? No - Visit time = comp cell V.T. ? No - Comp cell T.L. = 0 ? Yes - Comp cell T.L. = visit cell = 1 - Visit cell T.L. = 0 - Old cell = 0 ? Yes - Dummy T.L. = comp cell = 2 	$\begin{pmatrix} 0 \\ 1 & 3 \end{pmatrix}$ $\begin{pmatrix} 10:07:12 & 1 \end{pmatrix}$ $\begin{pmatrix} 2 & 1 \end{pmatrix}$ $\begin{pmatrix} 10:07:16 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 2 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ $\begin{pmatrix} 0 & 0 \end{pmatrix}$ <p>Action: Visit seq. 2</p> <ul style="list-style-type: none"> - Current time = 10:07 - Old cell = 0 - Visit cell V.T. = 10:07:16 - Comp cell = visit cell T.L. = 1 - Comp cell = 0 ? No - Visit time < comp cell V.T. ? No - Visit time = comp cell V.T. ? No - Comp cell T.L. = 0 ? Yes - Comp cell T.L. = visit cell = 2 - Visit cell T.L. = 0 - Old cell = 0 ? Yes - Dummy T.L. = comp cell = 1
--	---	---

Figure 3.2.2-44 Example of ACTLIS Management (cont'd)

	0
1	0
	3
10:07:12	1
2	1
10:07:16	2
3	2
∅	
10:14:20	3
∅	∅
0	3
	∅

Action: Add seq. 3, cmd phase = 4

- Current time = 10:07:40
- Seq. min = visit time = 10:14:20
- Seq. max = 10:15:24
- Av. mem. cell in dummy cell = 3 (add cell)
- Insert visit time, seq. # in cell 3
- Swap av. mem. #s between add cell and dummy cell
- Dummy T.L. = 0 ? No
- Old cell = 0 (Dummy)
- Comp cell = Dummy T.L. = 1
- Add cell V.T. < comp cell V.T. ? No
- Add cell V.T. = comp cell V.T. ? No
- Comp cell T.L. = 0 ? No

- Old cell = comp cell = 1
- Comp cell = comp cell T.L. = 2
- Add cell V.T. < comp cell T.L. ? No
- Add cell V.T. = comp cell T.L. ? No
- Comp cell T.L. = 0 ? Yes
- Comp cell T.L. = add cell = 3
- Add cell T.L. = 0

	0
2	1
1	∅
0	0
10:07:12	1
2	0
	1
10:07:32	2
3	2
10:14:20	3
0	3

Action: Delete Seq. 1

- Current time = 10:07:45
- Old cell = 0 (Dummy)
- Comp cell = dummy T.L. = 1
- Comp cell = 0 ? No
- Comp cell seq # = del seq. # ? Yes
- Del cell seq # = 0
- Del cell V.T. = 0
- Swap av. mem. #s between del cell and dummy cell
- Comp cell T.L. = 0 ? No
- Old cell = 0 ? Yes
- Dummy T.L. = comp cell T.L. = 2
- Step 6 of SEQDEL

Figure 3.2.2-44 Example of AC Management (cont'd)

3.2.2.4.1.28.2 Data, Logic and Command Paths

Input data:

Local common:

- a. RELINK - relink flag
- b. SQBUF(2) - command phase

Output data:

Local common:

ACTLIS - active-sequence list

3.2.2.4.1.28.3 Internal Data Description

ACTLIS (see Table 3.2.2-VII)

3.2.2.4.1.28.4 Flowchart

See Figure 3.2.2-45 for the SEQADD flowchart.

3.2.2.4.1.29 Submodule XXIX - SEQRLK

3.2.2.4.1.29.1 Description

SEQRLK is responsible for reordering the active-sequences list (ACTLIS) for ascending-order visit times. The visit sequence is that sequence which has just been processed by submodule SEQGAT.

- a. Language used - FORTRAN IV
- b. How invoked - called by SEQ
- c. Constraints and limitations - None
- d. Processing -

Reorder the time-linked list (see Figure 3.2.2-44 for example):

1. Initialize by: zero the equal flag (EQUAL). Set old cell equal to zero (dummy). Update the visit-sequence's time for next visit by adding 16 seconds to its value in the ACTLIS entry. Set the compare cell equal to visit-cell time link. Check if the compare cell equals zero. If yes, go to step (7).
2. Check if visit time is less than compare-cell time. If so, go to step (6). If not, check visit time to equal compare-cell time. If so, go to step (5). Check the compare-cell's time link (t.l.) to be zero. If not, go to step (3). Set the compare-cell's time link equal to visit cell and set the visit-cell time link equal to zero to put the visit sequence at the bottom of the linked-list temporarily. Go to step (8).

Figure 3.2.2-45 Flowchart - SEQADD

3. Set dummy-cell time link equal to visit-cell time link and set the visit-cell time link equal to compare-cell time link.
4. Set old cell equal to compare cell and set compare cell equal to compare-cell's time link. Go to step (2).
5. Set visit time equal to visit time plus 500 milliseconds to break conflict when two sequences have same revisit time. Go to step (4).
6. Check if equal flag (EQUAL) set. If so, set the visit-cell time link equal to old-cell's time link.
7. Check if old cell equals zero. If so, set dummy time link equal to visit cell and return to caller. Otherwise, set the old-cell's time link equal to visit cell and return to caller.
8. Check if old cell equals zero. If so, set dummy time link equal to compare cell and return to caller. Otherwise, set old cell equal to compare cell and return to caller.

e. Error messages and recovery - None

3.2.2.4.1.29.2 Data, Logic and Command Paths

Input data:

Local common:

ACTLIS - active-sequence list

Output data:

Local common:

a. ASTLIS - active-sequence list

b. EQUAL - visit-sequence's time matched another sequence's time during processing

3.2.2.4.1.29.3 Internal Data Description

ACTLIS (see Table 3.2.2-VII for format)

3.2.2.4.1.29.4 Flowchart

See Figure 3.2.2-46 for the SEQRLK flowchart.

3.2.2.4.1.30 Submodule XXX - SEQDEL

3.2.2.4.1.30.1 Description

SEQDEL is responsible for deleting a sequence from the active-sequence list (ACTLIS).

Figure 3.2.2-46 Flowchart - SEQRLK

Figure 3.2.2-46 Flowchart - SEQRLK (continued)

- a. Language used - FORTRAN IV
- b. How invoked - called by SEQ
- c. Constraints and limitations - None
- d. Processing -

See Figure 3.2.2-44 for example.

1. Set old cell equal to zero (dummy) and set compare cell equal to dummy time link. If compare cell equals zero, go to step (7).
2. Check compare cell's sequence number to delete cell's sequence number. If equal, go to step (4).
3. Set old cell equal to compare cell and set compare cell equal to compare-cell time link. Go to step (2).
4. Clear the delete cell by zeroing sequence number and visit time. Swap the available memory cell numbers between the delete cell and the dummy cell. Check if the compare-cell's time link equals zero (no sequence has later visit time). If not, go to step (5). If so, zero the relink flag (RELINK) and check if old cell equals zero. If so, the delete cell was the only active cell; set dummy time link equal to zero and go to step (6). If old cell is non-zero, set old-cell's time link equal to zero, and go to step (6).
5. Check if old cell equals zero. If so, set dummy time link equal to compare-cell's time link. Set the relink flag (RELINK), and go to step (6). If old cell non-zero, set old-cell's time link equal to compare-cell's time link. Set the relink flag, and go to step (6).
6. Reset the sequence status in the SEQLSG array to the negative sequence number by SEQLSG (SQBUF(3)) equal to minus SEQLSG (SQBUF(3)). Set SEQNMG equal to SEQNMG minus one to decrement the number of sequences in progress. If the command is STHIWIND, clear the emergency-sequence flag EMSEQG equal to zero.
7. Return to caller.

- e. Error messages and recovery - None

3.2.2.4.1.30.2 Data, Logic and Command Paths

Input data:

Local common:

- a. ACTLIS - active-sequence list
- b. SQBUF(1) - command number

Output data:

Local common:

- a. ACTLIS - active-sequence list
- b. RELINK - relink flag

3.2.2.4.1.30.3 Internal Data Description

There is no data internal to this submodule.

3.2.2.4.1.30.4 Flowchart

See Figure 3.2.2-47 for the SEQDEL flowchart.

3.2.2.4.1.31 Submodule XXXI - BHI (Task)

3.2.2.4.1.31.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - It is invoked by FCP task once each second after the status response messages have been processed and before commands are output to the HFCs.
- c. Constraints and limitations - The task BHI is constrained to send one subtype of HFC initialization command each second. Task BHI is allowed 40 msec to execute and shall have a high-priority just below the FCP task.
- d. Processing - When activated by FCP, the BHI task shall check the HFC status to determine if any require initialization. Checks shall be made to ensure the HFC is installed, requires initialization, and does not already have a command ready to be output. If all these conditions are true, the BHI task will construct the appropriate subtype initialization message and place it into the command buffer.

Subroutine BHISH5 is called to manipulate a five-word command input buffer and place the command byte into the command output buffer. After checking all HFCs, the BHI task will release control.
- e. Error messages and recovery - None

3.2.2.4.1.31.2 Data, Logic and Command Paths

Input data:

- a. HFC status words (HFCS1G, HFCS2G, and HFCS3G).
- b. Corridor coordinates (CORRCG).

Output data:

HFC initialization commands in command buffer (CMDBFG).

Algorithms:

Logic to calculate corridor assignment masks. BHISH5 formats the command buffer.

Figure 3.2.2-47 Flowchart - SEQDEL

Figure 3.2.2-47 Flowchart - SEQDEL (continued)

- 3.2.2.4.1.31.3 Internal Data Description
Miscellaneous variables for temporary storage.
- 3.2.2.4.1.31.4 Flowcharts
See Figure 3.2.2-48 for the BHI flowchart.
- 3.2.2.4.1.32 Submodule XXXII - BHISH5
- 3.2.2.4.1.32.1 Description
- a. Language used - MODCOMP Classic Assembler
 - b. How invoked - called by the BHI task.
 - c. Constraints and limitations - input and output arrays are five-word buffers.
 - d. Processing - the BHISH5 routine takes a five-word input array (i.e. corridor coordinates) and shifts all ten bytes right, losing the original last byte. Then it adds the command byte at the first byte location and places the result in a five-word output array.
 - e. Error messages and recovery - None
- 3.2.2.4.1.32.2 Data, Logic and Command Paths
- Input data:
- a. FORTRAN-compatible input parameter five-word array (corridor coordinates).
 - b. Command to be inserted into array.
- Output data:
- FORTRAN-compatible output parameter is the five-word array consisting of the shifted combination of the two input parameters.
- 3.2.2.4.1.32.3 Internal Data Description
Seven-word register save area.
- 3.2.2.4.1.32.4 Flowchart
See Figure 3.2.2-49 for the BHISH5 flowchart.
- 3.2.2.4.1.33 Submodule XXXIII - BHC (Task)
- 3.2.2.4.1.33.1 Description
- a. Language used - FORTRAN IV
 - b. How invoked - invoked by FCP following output of commands to the HFCs.
 - c. Constraints and limitations - The task BHC is constrained to send one type of command to each HFC per second. BHC

Figure 3.2.2-48 Flowchart - BHI

Figure 3.2.2-49 Flowchart - BHISH5

will not interrupt an HFC initialization sequence with HC commands until the sequence is finished.

- d. Processing - The BHC task, when activated, shall check to see if any HC commands are ready to be placed in the command buffer for FCP to output. Since only one command can be sent to an HFC, a priority scheme will be used by the BHC task when searching for a HC command to send out. The priority scheme used from high to low priority is as follows:

1. Critical-command bit set with beam-pointing command (Track CULP) or AZ/EL-pointing command (STOW).
2. Critical-command bit set with AZ/EL-pointing command (Directed Position) or HC initialization command.
3. Corridor-walk startup commands.
4. All other HC commands.

For each priority level the BHC task will search the HC command array in global common to determine if a command at that level is present. If a command is present the command buffer is filled with the appropriate command data.

To avoid loop processing when no critical commands are present, there will be two counters, one for each level of critical commands, in global common which are incremented when a critical command is to be output.

When BHC processes a critical command the appropriate counter will be decremented. If the counters are zero, then BHC will not search the HC command array for any critical commands. The BHC task also compresses any HC commands having the same coordinates into an HFC command (see Software/Firmware Functional Requirements Specification). (i.e. If identical HC commands are required for two or more HCs connected to the same HFC, the HC command mask shall be set to reflect this condition. After checking the HC command array, the BHC task will exit.

- e. Error messages and recovery - no error messages are produced by task BHC.

3.2.2.4.1.33.2 Data, Logic and Command Paths

Input data:

- a. HC-command status array - (HCCMDG)
- b. HC status words - (HCST1G, HCST2G, and HCST3G)
- c. Corridor-status flags - (CORRSG)
- d. HC command data (HCDATG)
- e. Current HC elevation - (ELEV G)
- f. Current HC azimuth - (AZIM G)

- g. HFC status - (HFCS2G)
- h. Emergency command counter - (EMCC1G)

Output data:

- a. HC-command status array - (HCCMDG)
- b. Command buffer - (CMDBFG)
- c. HFC status - (HFCS2G)
- d. Corridor-status flags - (CORRSG)
- e. Emergency command counter - (EMCC1G)

Algorithms:

Logic to calculate HC command masks and routine to move specific bytes.

3.2.2.4.1.33.3 Internal Data Description

Miscellaneous variables for temporary storage.

3.2.2.4.1.33.4 Flowchart

See Figure 3.2.2-50 for the BHC flowchart.

3.2.2.5 Interface Description

The software interfaces for module CMDPRC are depicted in the overview diagram (Figure 3.2.2-2). The message format for MMI-to-CMD input communication is contained in Tables 3.22-III and 3.22-IV (HCMAPG and CPPG arrays). The message format for BHC-to-FCP output communication is contained in Tables 3.7-I thru 3.7-IV and Tables 3.7-X thru 3.7-XII.

The hardware interface consists of the set of operational disk files specified in Section 3.2.2.3.2c.

3.2.2.6 Test Requirements

Due to the accelerated development of the MMI task, input commands can be entered at the HAC operator's console. Diagnostic tests of each task within this module are to be verified with output messages to the system console. A utility dump task is to be used to display global common values.

Figure 3.2.2-50 Flowchart - BHC

Figure 3.2.2-50 Flowchart - BHC (continued)

Figure 3.2.2-50 Flowchart - BHC (continued)

Figure 3.2.2-50 Flowchart - BHC (continued)

3.2.3 Sun Vector Module - SUNVEC

3.2.3.1 Purpose

The purpose of this module is to calculate a sun-position unit vector once per second, for transmission to the field of heliostats. The sun-position vector is used to calculate heliostat pointing angles to allow tracking of desired targets with the reflected beam.

3.2.3.2 Requirements

3.2.3.2.1 Design Requirements

The requirements for this software module are given in section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification. The requirements applicable to this module are:

- a. Control of up to 2048 heliostats in all modes required to operate the heliostats. The software system requires the calculation of sun position to be able to operate the heliostats in the Track mode; and
- b. Generate and transmit sun position information (once per second) to the entire field.

3.2.3.2.2 Derived Requirements

The derived requirements for this software module are given in section 3.2.1.3 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification. These requirements are:

- a. Calculate a sun unit vector as a function of universal time, on a once-per-second basis; and
- b. Format the sun-position unit vector into the format required for message packets and store in the data base.

3.2.3.3 Design Approach

The SUNVEC module consists of one task (SUN) which in turn has five subroutines which it calls to perform required calculations. The various subroutines are functionally separated out for ease of coding, checkout, testing, and maintenance.

3.2.3.3.1 Functional Allocations

This module consists of six submodules. The names of these submodules and a brief description of the function performed by each is given below. (See figure 3.2.3-1)

SUNVEC MODULE

Figure 3.2.3-1

- a. SUN - the task submodule which initializes certain common variables used by other routines, maintains the internal month-day-year array, IDATE, converts coordinated-universal time from hour-minute-second format to seconds past midnight and biases time to calculate sun position, and calls routine SUNPOS to calculate sun-position vector. This task converts the double-precision, floating-point, sun vector into a double-precision, integer, sun vector, scaled at binary point four. The task then exits and awaits activation in the next one-second frame.
- b. SUNPOS - a submodule which calculates the sun-position unit vector in facility coordinates, corrected for atmospheric refraction, mean temperature, and mean pressure. The resulting sun vector is a double-precision, floating-point, three-element array.
- c. SUNDJ - a submodule whose function is to calculate the Julian days elapsed since January 1900, using the month-day-year array IDATE.
- d. SUNCON - a submodule whose function is to maintain the month-day-year array, IDATE, from the year since 1900 value (GTMEG(1)) and day-of-year (GTMEG(2)) value.
- e. SUNPOL - a submodule whose function is to calculate the value of a third-order polynomial.
- f. SUNDMA - a submodule which performs a specialized matrix multiplication.

3.2.3.3.2

Resource Budgets

This task will execute as a memory-resident task. The estimated resources are as follows:

- a. Memory required - 4000 words;
- b. Timing - less than one-half of one percent CPU;
- c. Disk files required - none;
- d. Disk accesses required - none;
- e. Magnetic tape access - none ; and
- f. Task priority - 110 (medium-high priority).

3.2.3.4

Design Description

3.2.3.4.1

Module Structure

This module consists of six submodules. The submodule SUN is a stand-alone task, consisting of a main routine which uses the other

five submodules as subroutines. Each of these submodules is described in detail in the following paragraphs.

3.2.3.4.1.1

Submodule I - SUN (Main Routine)

3.2.3.4.1.1.1

Description

- a. Language used - FORTRAN IV
- b. How invoked - activated by the task FCP once each time frame.
- c. Constraints and limitations - none
- d. Processing - The first section of code initializes constants, computes geocentric latitude, and calls SUNCON to update the IDATE array. This section is executed conditionally where the parameter IDAY has changed and, by default, when the system is initialized. The geodetic latitude is obtained from global common and converted to geocentric latitude with an equation that accounts for oblateness effects up to the third order. Time is updated by setting the parameter IDAY to the current day of the year and the third element of the IDATE array to the year value. Submodule SUNCON is called to calculate the month and date from these values, which are stored in the IDATE array. After this update is complete, the universal time parameter (UT) is calculated (seconds since midnight) from the hours-minutes-seconds values of coordinated-universal time maintained in the data base. Submodule SUNPOS is called to calculate the double-precision, floating-point, sun-position, unit vector, stored in the one by three SVEC array. This main routine then converts the array to a double-precision, integer array scaled at binary point four. The main routine then releases processor control until activation in the next "frame" by task FCP.
- e. Error messages and recovery - none.

3.2.3.4.1.1.2

Data, Logic and Command Paths

The input data to this submodule is in the data base. The same is true of the output data.

Input Data:

- GTIMEG(1) - Current year, since 1900 (e.g. 1980: 80)
- GTIMEG(2) - Current day of year
- GTIMEG(3) - Current coordinated-universal time since midnight in hours
- GTIMEG(4) - Current coordinated-universal time in minutes past the hour
- GTIMEG(5) - Current coordinated-universal time in seconds past the minute

Output Data:

- SUNPOG(1) - X-component of sun-position unit vector, in facility coordinates
- SUNPOG(2) - Y-component of sun-position unit vector, in facility coordinates
- SUNPOG(3) - Z-component of sun-position unit vector, in facility coordinates

The only algorithm used in this routine is the conversion from double-precision, floating-point values to double-precision, integer values scaled at binary point four. Since integer values normally have the binary point after the least significant bit, the way to scale the number (a 32-bit number) is to shift the binary point left 28 places. Thus, the floating point value is multiplied by two raised to the 28th power, shifting the binary point, and the result is integerized.

3.2.3.4.1.1.3 Internal Data Description

The following is a description of the data internal to this routine:

- IDATE(1) - Current month of year in coordinated-universal time
- IDATE(2) - Current day of month in coordinated-universal time
- IDATE(3) - Current number of years since 1900 in coordinated-universal time
- IDAY - Current day of year in coordinated-universal time
- DTOR - constant, degree-to-radians conversion
- PI - constant, value of number of radians in circle
- RTOD - constant, radians-to-degrees conversion
- SLAT - site latitude, radians
- SLONG - site longitude, radians
- TO28 - Constant, 2 to the 28th power value
- UT - time since midnight, seconds, coordinated-universal time

3.2.3.4.1.1.4 Flowcharts

See figure 3.2.3-2.

3.2.3.4.1.2 Submodule II - SUNPOS

3.2.3.4.1.2.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by task SUN
- c. Constraints and limitations - none

Figure 3.2.3-2 Flowchart - SUN

d. Processing - When called by SUN, the first step in the submodule is to call submodule SUNDJ to calculate the number of days elapsed since January 1900, using the month-day-year array IDATE. From this, the subroutine calculates the Julian centuries elapsed since January 1900 (DJC). The correction factor due to mean temperature and pressure is calculated as a function of the current month. Next, the ephemeris time (ET) is calculated. This is then calculated as Julian centuries (TOD). Next, a factor is subtracted to account for the light-time from sun to earth. If the current date has changed, the equatorial-to-facility transformation (TEF) is recalculated. Otherwise, the calculation is skipped. The mean obliquity (OBL2) is calculated as a function of time since 1900. The mean longitude of perihelion is calculated as a function of time since 1900 (GAMA). The earth orbit eccentricity is calculated as a function of time since 1900 (ECEN). Then, the mean anomaly of the earth in orbit about the sun (ANOM) is calculated as a function of time since 1900. Using the mean anomaly as a first guess, the eccentric anomaly is calculated, using the Newton-Raphson iterative process. Then the true anomaly (TANOM) is calculated as a function of eccentricity and eccentric anomaly. The sun-position vector in earth-centered, inertial coordinate system is calculated as a function of obliquity, mean longitude of perihelion and true anomaly. Next, the right ascension of the Greenwich meridian (RAM) is calculated. This is used to convert the sun position from earth-centered, inertial coordinates to equatorial meridian coordinates (SVC). In order to correct for atmospheric refraction, the true azimuth (TZA) is calculated as a function of sun position. Note that if the sun elevation angle is less than zero, this is the apparent azimuth angle (AZA). Two separate methods are used to calculate the apparent azimuth angle, if the elevation angle is positive. One method is used for angles between zero and five degrees, and another is used for angles greater than five degrees. The correction factor for apparent azimuth angle is calculated and combined with the previously calculated correction for mean temperature and humidity. Using this apparent azimuth angle, the sun position vector in facility coordinates is calculated and normalized (SVE).

e. Error messages and recovery - none

3.2.3.4.1.2.2

Data, Logic and Command Paths

This submodule uses input data described below:

UT - seconds since midnight, coordinated-universal time
 IDATE(1) - month of year, coordinated-universal time

IDATE(2) - day of month, coordinated-universal time
IDATE(3) - elapsed years since 1900, coordinated-universal time

This submodule generates the following double-precision, floating-point, three-element array as output:

SVEC(1) - X-component of sun position in facility coordinates
SVEC(2) - Y-component of sun position in facility coordinates
SVEC(3) - Z-component of sun position in facility coordinates

The algorithms used in this submodule are a second or third-order polynomial curve fit of certain parameters as a function of time and the Newton-Raphson iterative process for calculation of the implicit function eccentric anomaly.

3.2.3.4.1.2.3

Internal Data Description

Internal data used in this submodule is as follows:

ALTFAC - Correction factor for mean temperature and pressure
ANOM - Mean anomaly of earth in orbit around sun, radians
AZA - Complement of sun's apparent elevation (with refraction), radians
CAT - Normalization factor for final sun vector (with refraction)
DJC - Julian centuries since January 1, 1900 epoch
DPC - constant, days per Julian century
DTOR - constant, degrees-to-radians conversion
EANOM - Eccentric anomaly of earth orbit, radians
ECEN - Earth orbit eccentricity
ET - Ephemeris time, seconds since midnight
GAMA - Mean longitude of perihelion of earth's orbit, radians
DBLQ - Mean obliquity of ecliptic, radians
R - Atmospheric refraction correction factor
RA - R corrected with ALTFAC
RAD - Distance from sun to earth, astronomical units
RTOD - Constant, radians-to-degrees conversion
SLAT - Site latitude, radians
SLONG - Site longitude, radians
SOL - Speed of light, astronomical units per second
SPD - Constant, seconds per day
SVC - Sun vector in facility coordinates - no refraction correction
SVE - Sun vector in equatorial Greenwich meridian coordinates
SVI - Sun vector in earth centered inertial coordinates
TANOM - True anomaly of earth in orbit, radians
TEF - Coordinate conversion matrix from equatorial to facility coordinates
TOD - Julian centuries elapsed since midnight
TZA - 90 degree minus sun true elevation (without refraction), radians

3.2.3.4.1.2.4 Flowcharts

See figure 3.2.3-3.

3.2.3.4.1.3 Submodule III - SUNDJ

3.2.3.4.1.3.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by SUNPOS
- c. Constraints and limitations - none
- d. Processing - The submodule, when called by SUNPOS, calculates the day of the year from current month and date. It then checks for current year being a leap year, and if so, and the month is not January or February, a day is added to correct for the leap day. Then the integer number of Julian days is calculated for years elapsed since January 1900 epoch to this year, and the days elapsed in this year are added to get total Julian days elapsed since the January 1900 epoch.
- e. Error messages and recovery - none

3.2.3.4.1.3.2 Data, Logic and Command Paths

The input data to this routine are as follows:

- IDAYT(1) - Month of current year
- IDAYT(2) - day of current month
- IDAYT(3) - elapsed years since January 1900 epoch

The output data generated by this submodule is:

- DJ1900 - number of Julian days elapsed since January 1900 epoch

3.2.3.4.1.3.3 Internal Data Description

A twelve element array is used in this submodule, initialized to values equal to numbers of days in each of twelve months.

3.2.3.4.1.3.4 Flowcharts

See figure 3.2.3-4.

3.2.3.4.1.4 Submodule IV - SUNCON

3.2.3.4.1.4.1 Description

Figure 3.2.3-3 Flowchart - SUNPOS

Figure 3.2.3-3 (cont.) Flowchart - SUNPOS

Figure 3.2.3-4 Flowchart - SUNDJ

- a. Language used - FORTRAN IV
- b. How invoked - called by task SUN
- c. Constraints and limitations - none
- d. Processing - This submodule determines the month and date from a day-of-year input. To do this, an internal, twelve-element, array is used with the number of days in each month as elements. The subroutine first updates the February value, depending on whether the current year is leap year. Then it loops through, determining whether pointer points to current month, and subtracting days of month from day-of-year value until month is found. The remainder is the day of month.
- e. Error messages and recovery - none

3.2.3.4.1.4.2 Data, Logic and Command Paths

The input parameters to this routine are as follows:

IDAY - day-of-year, coordinated-universal time
 IDATE(3) - elapsed years since January 1900 epoch

The output parameters generated by this routine are:

IDATE(1) - current month of year
 IDATE(2) - current day of month

3.2.3.4.1.4.3 Internal Data Description

The internal data used in this submodule is a twelve element array (NDATE), with values of days contained in each month.

3.2.3.4.1.4.4 Flowcharts

See figure 3.2.3-5

3.2.3.4.1.5 Submodule V - SUNPOL

3.2.3.4.1.5.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by the SUNPOS
- c. Constraints and limitations - none
- d. Processing - SUNPOL is a submodule which calculates the value of a third-order polynomial.
- e. Error messages and recovery - none

Figure 3.2.3-5 Flowchart - SUNCON

3.2.3.4.1.5.2 Data, Logic and Command Paths

The input parameters to this routine are as follows:

TU - Independent variable
A(1) - A(4) - Polynomial coefficients

The output parameter generated by this routine is:

POLY3 - Resultant value of polynomial expression

3.2.3.4.1.5.3 Internal Data Description

There is no data internal to this submodule.

3.2.3.4.1.5.4 Flowcharts

See figure 3.2.3-6.

3.2.3.4.1.6 Submodule VI - SUNDMA

3.2.3.4.1.6.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by subroutine SUNPOS
- c. Constraints and limitations - none
- d. Processing - SUNDMA is a submodule which is used to perform a specialized, double-precision, matrix multiplication. The submodule is called from SUNPOS and performs a double-precision, matrix multiplication of the type:

$$A * B = C$$

Where A is a three-by-three matrix and C is the resultant three-by-one matrix. SUNPOS uses SUNDMA to transform inertial coordinates to facility coordinates.

- e. Error messages and recovery - none

3.2.3.4.1.6.2 Data, Logic and Command Paths

The input parameters are as follows:

A - generalized three-by-three matrix
B - generalized three-by-one matrix

Figure 3.2.3-6 Flowchart - SUNPOL

The output parameter is:

C - Generalized three-by-one matrix

3.2.3.4.1.6.3 Internal Data Description

There is no data internal to this submodule.

3.2.3.4.1.6.4 Flowcharts

See figure 3.2.3-7.

3.2.3.5 Interface Description

This module interfaces with the other modules of the Collector Subsystem software through its input data (coordinated-universal time in the data base), its output data (sun position vector in the data base), and its calling sequency (activated by task FCP).

3.2.3.6 Test Requirements

This module can be tested in a stand-alone manner by inserting known, fixed values of universal time in the data base, activating the task, dumping the resulting values of sun position from the data base after the program is complete, and comparing the results to precalculated values.

Figure 3.2.3-7 Flowchart - SUNDMA

3.2.4 Field Communications Processor Module - FLDCOM

3.2.4.1 Purpose

The Field Communications Processor provides communications to the field of 2048 heliostats. As such it provides the interface for the Command Processor Module to the field via eight communication lines each with eight HFCs and the interfaces for the Alarm, Backup, and Status Display Modules. All interfaces are via the global data base.

The Field Communications Processor Module consists of one task (FCP) operating at the third highest priority in the system which, in turn, utilizes six submodules (FCPOUT for output checking, FCPIN for input checking and HFC status updates, FCPUPD for updating HC status, FCPCHO for byte checksum calculations with checksum storage into output buffers, FCPCHI for checksum calculations without storage and FCPSWH for recording I/O errors, detecting communications failure, and performing communications switchover).

3.2.4.2 Requirements

3.2.4.2.1 Design Requirements

Section 3.2.1.4 of the 10 MWe Software/Firmware Functional Requirements Specification states the following requirements for the FLDCOM module:

- a. Synchronize field operations by transmitting to the HFC computer a sun vector command once per frame;
- b. Generate, at the proper time in the time frame, the polling command for the HFC;
- c. Receive the HC and HFC status in response to each polling command and save same in the data base;
- d. Transmit to the HFC, the operational commands generated by the Command Processor Module;
- e. Detect communications errors and automatically switch over to the redundant communications lines or the "Backup" computer, and report these conditions to the Alarm Processor Module;
- f. Mark (calibrate) heliostats in both azimuth and elevation;
- g. Generate proper timing to accomplish all of the above in conjunction with HFC/HC firmware;
- h. Implement retransmission of HC commands (tracking and AZ/EL only); and
- i. Prevent communications failover upon detection of field power-loss signal.

3.2.4.2.2

Derived Requirements

Based upon the design requirements stated in paragraph 3.2.4.2.1, the following are derived requirements for the FLDCOM module:

- a. The FLDCOM module to insure proper timing within the one-second time frame, will use a delay timer;
- b. To detect the occurrence of a communications error, the FLDCOM module will examine the user file tables (UFTs) and the reported HFC and HC status messages. Communication errors will be indicated to the ALARM module via global common;
- c. In order to receive the HC and HFC Status, the FLDCOM module will accept input from the HFC and update the HFC/HC Status in global common;
- d. Automatically switching to the redundant communications lines implies the changing of the logical device names present in the user file tables;
- e. Requirement "a" of Section 3.2.4.2.1 implies an interface with the SUNVEC module;
- f. Requirements "a," "b," and "d" of Section 3.2.4.2.1 imply that the FLDCOM module has the ability to output data and commands to the HFCs; and
- g. Requirement "e" of Section 3.2.4.2.1 implies that the FLDCOM module has an interface with the BACKUP module.

3.2.4.3

Design Approach

The following is a list of assumptions used in the design of the FLDCOM module:

- a. It is assumed that the equipment configuration defined in the phase II proposal, Section 3, will be used as the operational equipment. This implies a primary and backup HAC each with dual communication lines to the field of heliostats;
- b. There is no requirement to provide the operator with the capability to manually switch the communication lines from normal to alternate or from alternate to normal;
- c. The field of heliostats can be powered up in either sections or in its entirety. The field can be powered up either before or after the HAC is operational;

- d. If all of the field of heliostats loses power, an interrupt will be supplied to both the primary and backup HAC to indicate the loss of power;
- e. The current communication line and field status in the primary HAC shall be transmitted to the backup HAC on a periodic basis once each time frame;
- f. Errors can occur anywhere along the communication lines to the HFCs, and error indications received at the HAC are of minimal value for diagnostic purposes. Therefore, I/O errors indicated by the MAX IV (MAXNET) operating system, in the user file tables (UFTs) which the FLDCOM module uses to do I/O, shall be considered line errors; and
- g. There is no requirement to recover from a failure to the alternate or secondary communications lines.

For purposes of this design discussion various terminology shall be used and is defined below.

- a. Communication errors - Errors can occur at various levels in the communication hierarchy: field, line, HFC, and HC. The definition of these errors follows:
 - 1. Field error - The only error recognized at the field level shall be loss of communication to entire field. This error will occur when all communications to the field is lost and no power loss interrupt has been detected.
 - 2. Line error - Line errors shall be detected by examination of the input and output UFTs which FLDCOM uses to perform I/O to the field.
 - 3. HFC, HC error - These errors are indicated by the status messages and UFT status received by FLDCOM from the field. The UFT status shall indicate input/output time-out conditions. HFC/HAC communications failure and HC command errors shall be detected by examination of the status response message. These HFC/HC errors do not differ from phase I and will be flagged for the ALARM module for operator display.
- b. Communication status - Since communication with the field is of a hierarchical nature and I/O errors can occur at the various levels, status shall be kept at the field, line, HFC, and HC levels. Definitions of the status values follow below:

1. Field status - The status of the field shall be set to one of the following values:

- a) ACTIVE - initial state prior to establishing communications with the field; sun/synchs and status poll messages are being sent, but the field has not yet responded;
- b) ENABLED - communications have been established with the HFCs in the field, (i.e. a status response message has been received from an HFC); and
- c) There shall also be bits in the field status which indicate if a communication failure or power loss interrupt has occurred.

2. Line status - The status of the lines shall be one of the following values:

- a) IDLE - not currently being used to communicate with the field (initial value for the alternate communication lines);
- b) ACTIVE - line being used to attempt establishment of communications with HFCs;
- c) ENABLED - I/O to the field is currently active on this line; and
- d) FAILED - failure criterion for this line has been met and the line has been declared failed and is not to be used for communications with the field.

3. HFC, HC status - This status is the same as that present in phase I design.

- c. Normal/Alternate line - For the purposes of this design discussion, the term "normal line" shall refer to the line initially used to perform I/O to the field. The eight normal lines shall all reside in the same MODCOMP 1930 Universal Communication Chassis. There are four MODCOMP 1931 dual asynchronous interfaces in each 1930, each with two communication lines. The term "alternate line" will refer to the communication lines resident in the second MODCOMP 1930 Universal Communication Chassis and shall serve as the backup communication line to the field.

The following is a discussion of the design present in the FLDCOM module.

When the HAC is initialized, the field and eight normal lines shall be in the active state. The FLDCOM module will send sun/synch and status poll messages to the field using the eight normal communication lines. If the FLDCOM module is executing in the backup HAC, a check shall be made to determine why the backup HAC is being used. If a communication failure occurred to the entire field, FCP shall switch to alternate lines. Otherwise the lines that were in use by the primary HAC will be used by the backup HAC.

Until the HFCs respond with a status response message, the field and lines will be considered in the active state and the ALM task shall not be activated. Once a status response message is received, the status of the field shall be set to enabled and the ALM task shall be scheduled on a once-per-second basis.

As HFCs respond, the lines they are connected to will be set to the enabled state. Communications will then take place with the field normally in the synchronous loop until the occurrence of an I/O error. As I/O errors occur, they may cause FLDCOM to initiate a switch to the alternate communication lines or to the backup HAC. A discussion of these conditions follows:

- a. Line Switchover - A switch to the alternate lines shall be made if one of the following conditions is true:
 1. Three consecutive input errors on a line.
(Error present in the input UFT for that line.)
 2. Three consecutive output errors on the line.
(Error present in output UFT.)
 3. Three consecutive errors (either input or output or both) on the line.
 4. If communication is lost with two or more HFCs on a line (HFC input time-out error or output time-out error).

When one of the above conditions is true the FLDCOM module shall mark the normal line as failed and initiate a switchover to the alternate line. Since a MODCOMP 1931 has two lines, both lines residing in the 1931, both will be switched to the alternate lines. The alternate line status shall be changed from idle to active and the sun/synch and status poll messages shall be transmitted on the alternate lines. When a status response is received by the HAC, the alternate lines shall be set to the enabled state. A line failure on an alternate line shall result in an alarm to the operator, however, I/O to the field shall remain active on the alternate line.

- b. Backup HAC Switchover - When the FLDCOM module detects a loss of communications with all enabled lines in the field, it shall initiate a switch to the backup HAC. The backup HAC shall initiate communications with the field on the alternate lines. If the backup HAC is not active, an alarm shall be raised and the FLDCOM module shall attempt to reestablish communications with the field on the alternate lines.

The switch to the backup HAC shall be indicated by the FLDCOM module setting a bit in global common which the BACKUP module shall detect. Upon detection, the BACKUP module shall initiate an orderly transition to the backup computer.

If a loss of communication is detected and a power loss interrupt has occurred, no switchover to the backup HAC shall be initiated.

3.2.4.3.1 Functional Allocations

To accomplish the required processing the FLDCOM module consists of a single task called FCP. The task FCP consists of four functional parts and utilizes six submodules. The four functional parts of the FCP task perform the following functions:

- a. Sun/synch preparation, output, output check, and activation of the SUNVEC task, which calculates the sun vector for the next second during FCP's idle time;
- b. Status request loop (DO-UNTIL eight lines of eight HFCs each are done) for one-eighth of the field, with output checks, input checks, status updates, and heliostat "marking" (calibrating);
- c. After all the current HC statuses are updated, ALM (ALARM) and STS (STATUS) tasks are activated to determine any new alarms or field status changes. Task BHI of the Command Processor Module is activated to build any HFC initialization commands to be output. FCP suspends itself for 55 msec to give BHI enough time to execute; and
- d. Command output loop (DO-WHILE commands to be sent) with command buffer copying to "private" command buffers, command output retries, and output checking. Command returns (feedback from HCs whether or not commands were received) are monitored the next second along with HFC and HC status. If no commands are to be output or when command output is done, FCP will activate task BHC to build any new commands to be output during the next time frame and suspends itself via REX,SUSPEND.

NOTE: The timing functions necessitated by the field communications lines and the firmware in the HFCs are distributed over "a" through "d" of the above parts.

Called submodules:

- a. Output check routine (FCPOUT);
- b. Input check and HFC status update routine (FCPIN);
- c. HC status update routine (FCPUPD);
- d. Byte checksum routine with storage (FCPCHO);
- e. Byte checksum routine without storage (FCPCHI); and
- F. Communications system switching routine (FCPSWH).

Utilized Executive Requests (REX calls) in FCP and its submodules are:

- a. DELAY - used for timing;
- b. OUTPUT - used to send data on eight HFC communication lines;
- c. ACTIVATE - used to trigger other tasks;
- d. SUSPEND - used to "put FCP to sleep." (Expiration of DELAY timer will wake FCP);
- e. INPUT - used to receive data on eight HFC communication lines;
- f. TERMINATE - used to terminate I/O following error detection; and
- g. EXIT - used to terminate FCP until reactivated by TIK.

All REX calls are documented in the MODCOMP Reference Manual for MAX IV (MAXNET) General Operating System. See the FCP functional overview Figure 3.2.4-1 for an overview.

3.2.4.3.2

Resource Budgets

- a. Memory required: 3K of resident memory plus access to global common COMDAT;
- b. Timing: See HAC/HFC/HC timing diagram (Figure 3.2.4-2);
- c. Mass storage (disk, tape) required: None; and

Figure 3.2.4-1 Flowchart - FCP Functional Overview

Figure 3.2.4-2 FLDCOM One-Second Communications Time Frame

Time From Start of Data Frame, msec	Duration, msec	Data	Path
0	10	Sun position data.	HAC to HFC
20	90	Sun position plus operational commands received in last frame, if any.	HFC to HC
115	113	Response from each HC, in order, to indicate correct/incorrect receipt of commands.	HCS to HFC
228	3	Status request to first of four HCs being polled this frame.	HFC to HC
231	13	Status response.	HC to HFC
244	3	Status request to second of four HCs being polled this frame.	HFC to HC
247	13	Status response.	HC to HFC
260	3	Status requests to third of four HCs being polled this frame.	HFC to HC
263	13	Status response.	HC to HFC
276	3	Status request to fourth of four HCs being polled this frame.	HFC to HC
279	13	Status response.	HC to HF
310	5	Status request to first HFC on data bus.	HAC to HFC
320	20	Status response, including status from four HCs.	HFC to HAC
355	5	Status request to second HFC on data bus.	HAC to HFC
365	20	Status response, including status from four HCs.	HFC to HAC
400	5	Status request to third HFC on data bus.	HAC to HFC
410	20	Status response, including status from four HCs.	HFC to HAC
445	5	Status request to fourth HFC on data bus.	HAC to HFC
455	20	Status response, including status from four HCs.	HFC to HAC
490	5	Status request to fifth HFC on data bus.	HAC to HFC
500	20	Status response, including status from four HCs.	HFC to HAC
535	5	Status request to sixth HFC on data bus.	HAC to HFC
545	20	Status response, including status from four HCs.	HFC to HAC

Figure 3.2.4-2 FLDCOM One-Second Communications Time Frame (con't.)

Time From Start of Data Frame, msec	Duration, msec	Data	Path
580	5	Status request to seventh HFC on data bus.	HAC to HFC
590	20	Status response, including status from four HCs.	HFC to HAC
625	5	Status request to eighth HFC on data bus.	HAC to HFC
635	20	Status response, including status from four HCs.	HFC to HAC
725	10	Operational commands, if any, to first HFC on data bus.	HAC to HFC
745	10	Operational commands, if any, to second HFC on data bus.	HAC to HFC
765	10	Operational commands, if any, to third HFC on data bus.	HAC to HFC
785	10	Operational commands, if any, to fourth HFC on data bus.	HAC to HFC
805	10	Operational commands, if any, to fifth HFC on data bus.	HAC to HFC
825	10	Operational commands, if any, to sixth HFC on data bus.	HAC to HFC
845	10	Operational commands, if any, to seventh HFC on data bus.	HAC to HFC
865	10	Operational commands, if any, to eighth HFC on data bus.	HAC to HFC

Figure 3.2.4-2 FLDCOM One-Second Communications Time Frame (con't.)

- d. Task priority: Highest priority task in the HAC system after TOK and TIK (timer tasks).

3.2.4.4 Design Description

3.2.4.4.1 Module Structure (See Figure 3.2.4-3)

FCP is a stand-alone task which is memory resident. As described under 3.2.4.3.1, there are four major parts to the task and six submodules to do checksum calculations, output checking, input checking, HC status updates, and communications system switching.

3.2.4.4.1.1 Submodule I - FCP

3.2.4.4.1.1.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - Activated by the timer task TIK on a once-per-second basis.
- c. Constraints and limitations - In order to allow the most precise timing possible, and thereby make optimum use of the HAC CPU and I/O System, the FCP task will run on the third-highest priority of the system. Other constraints include being able to do all output and inputs within one second and not doing excessive processing between time delay periods.
- d. Processing

The major parts of processing consist of:

1. Upon activation FCP shall check to see if it resides in the primary or backup HAC. If FCP is in the backup HAC and a communication failure caused the switch, then FCP will switch the UFTs to the alternate communication lines. Otherwise, the lines in use by the primary HAC will also be used by the backup.
2. Then each one second frame, FCP will clear reported line errors in global common array LINESG, build the sun/synch packet, outputting it to all eight HFC lines, reporting any I/O errors to the data base, and switching field communications if necessary. Also, the SUN task is activated to calculate the next time frame's sun vector.
3. Polling each of eight HFCs on all of eight lines for status of four successive HCs such that

Figure 3.2.4-3 FLDCOM Module

one-eighth of the field is updated every second and the whole field every eight seconds. Again, I/O errors are reported to the data base and field communications switched if necessary. DO-UNTIL implementation is utilized.

4. The ALM and STS tasks are activated to operate on the newly arrived status for one-eighth of the field. Task BHI of the Command Processor Module is triggered to fill the command buffer with any HFC initialization commands required to be sent to the field. A 55 msec delay is involved to give BHI enough time.
5. As long as commands to individual HFCs need to be output (as determined by the local retry counter or by the command buffer ready bit in HFCS2G), they are output to the corresponding HFCs. If for a particular HFC, the local command buffer is not tied up with retries and a new buffer is ready to be output, it is copied from the global CMDBFG to the local command buffer, and the command buffer ready bit is reset so that new commands can be filled in the next time FCP triggers the BHI and the BHC tasks. One to eight HFC lines are commanded quasi-simultaneously (in parallel) and one to eight HFCs on each line are commanded in 20 msec steps (in series). Output errors are reported to the data base immediately; failure of HCs to report command returns are reported after three retries. FCP then initiates the BHC task to build HC commands required for the next one-second time frame and suspends itself until the beginning of the next frame.

- e. Error messages and recovery - The FCP task has no error messages.

3.2.4.4.1.1.2 Data, Logic, and Command Paths

Input data for FCP:

- a. Sun position input from data base location SUNPOG;
- b. Input from global common is the command buffer CMDBFG, and the associated bit flag HFCS2G (bit 10) indicating the command buffer is ready to output; and
- c. Input from each HFC into local holding buffer.

Output data for FCP:

- a. Output to each HFC for sun/synch, Status requests, and for commands from local holding buffers;
- b. Output of HC statuses to data base for STS and ALM tasks;
- c. Output of I/O errors to data base for ALM task;
- d. Algorithm for calculating a byte checksum called FCPCHO; and
- e. Command Paths: Activate SUN, ALM, STA, BHI, and BHC tasks.

3.2.4.4.1.1.3 Internal Data Description

- a. 5-word Register Save area;
- b. 2 10-word UFT address tables;
- c. 16 10-word UFTs (input and output);
- d. 5 1-word task names;
- e. 64 1-word retry counters;
- f. 1 8-word buffer for keeping track of command outputs;
- g. 1 8-word buffer for sun/synch;
- h. 8 2-word buffers for polling;
- i. 64 10-word local HFC command buffers;
- j. 8 17-word status input buffers; and
- k. 8 1-word logical device names for alternate lines.

3.2.4.4.1.1.4 Flowchart(s)

See attached Figure 3.2.4-4.

3.2.4.4.1.2 Submodule II - Subroutine FCPOUT

3.2.4.4.1.2.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - It is invoked by FCP after each output completion.

Figure 3.2.4-4 Flowchart - FCP Task

Figure 3.2.4-4 Flowchart - FCP Task (continued)

- c. Constraints and limitations - Each call to FCPOUT will check one UFT for errors being present.
- d. Processing - This routine when called shall check the UFT for output errors and mark the data base with communication errors on an output channel basis.
 - 1. A UFT which did not complete will imply an HFC output time-out condition. All other errors denote a line error.
 - 2. If an error is found, the routine FCPSWH will be called to determine if the failure criterion for the line having the error has been met.
- e. Error messages and recovery - There are no error messages arising from FCPOUT processing. Output errors found are indicated in the global data base and output by the ALARM module.

3.2.4.4.1.2.2 Data, Logic and Command Paths

Input data for FCPOUT:

- a. UFTs (user file tables);
- b. A flag for retries; and
- c. LINE/HFC/HC index.

Output data for FCPOUT:

- a. Global data base bits;
- b. The local retry table; and
- c. Calling of routine FCPSWH.

3.2.4.4.1.2.3 Internal Data Description

15-word register save area.

3.2.4.4.1.2.4 Flowchart

See Figure 3.2.4-5

3.2.4.4.1.3 Submodule III - Subroutine FCPIN

3.2.4.4.1.3.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - It is invoked by FCP after each input completion or time-out of such input.

Figure 3.2.4-5 Flowchart - FCPOUT

c. Constraints and limitations - FCPIN will check one input UFT per invocation.

d. Processing

1. This routine will check the input UFT and the HFC status response message for input errors. The various input errors checked for are the following:
 - a) If a UFT did not complete (i.e. the input buffer was not full) it is considered an HFC input time-out error;
 - b) All other errors indicated in the UFT are considered line errors;
 - c) Not enough bytes transferred, a bad checksum, or if the input header byte was not a normal status indicates an HFC/HAC communication error;
 - d) The last command sent didn't match the last command received; and
 - e) Missing and extra HC command returns are checked for and marked in HC global states.
2. If one of these input errors is detected the routine FCPSWH is called to determine if the failure criterion for the line has been reached.
3. If no errors were found on the line, the line status will be set to enabled (if not already enabled), the number of enabled lines in the field shall be incremented, and the field status set to enabled.
4. If no HFC or line errors are present or command output retries are in progress, then FCPIN will update HC status by calling routine FCPUPD. Before returning, the HFC status will be updated in global common array HFCS1G.

e. Error messages and recovery - None.

3.2.4.4.1.3.2 Data, Logic, and Command Paths

- a. Input data are UFTS (user file tables), input buffers, and the LINE/HFC/HC index; and

- b. Output data are data base bits and HC status words (AZIMG, ELEVG, HCST1G - all indirectly via subroutine FCPUPD) as well as HFC status words (HFCS1G), line status words (LINESG), and field status (FLDSTG).

3.2.4.4.1.3.3 Internal Data Description

- a. 15-word save area for registers 1-15;
- b. Save location for last command;
- c. Various bit masks; and
- d. Various constants for byte-counts and commands.

3.2.4.4.1.3.4 Flowchart

See attached Figure 3.2.4-6.

3.2.4.4.1.4 Submodule IV - Subroutine FCPCHO

3.2.4.4.1.4.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - Called by FCP task to compute checksum for output buffer.
- c. Constraints and limitations - None
- d. Processing - This routine calculates an n-byte checksum and stores the result in byte n+1. It is used for each output to the field.
- e. Error messages and recovery - None

3.2.4.4.1.4.2 Data, Logic, and Command Paths

Input data for FCPCHO are:

- a. Return link address;
- b. 5-word save area;
- c. Byte count;
- d. Buffer address; and
- e. Actual buffer to be checksummed.

Figure 3.2.4-6 Flowchart - FCPIN

Figure 3.2.4-6 Flowchart - FCPIN (continued)

Output data for FCPCHO is the (n+1) byte of the buffer which contains the actual checksum upon exit.

3.2.4.4.1.4.3 Internal Data Description

None

3.2.4.4.1.4.4 Flowchart

See attached Figure 3.2.4-7.

3.2.4.4.1.5 Submodule V - Subroutine FCPCHI

3.2.4.4.1.5.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - It is invoked by FCPIN to compute the checksum.
- c. Constraints and limitations - None
- d. Processing - This routine calculates an n-byte checksum and returns it in R11. It is used to compare against actual checksums after input completions.
- e. Error messages and recovery - None

3.2.4.4.1.5.2 Data, Logic, and Command Paths

Input data for FCPCHI are:

- a. Return link address;
- b. 3-word save area address;
- c. Byte count;
- d. Buffer address; and
- e. Actual buffer to be checksummed.

Output data for FCPCHI is R11 which contains the calculated checksum upon exit.

3.2.4.4.1.5.3 Internal Data Description

None

3.2.4.4.1.5.4 Flowchart

See attached Figure 3.2.4-8.

Figure 3.2.4-7 Flowchart - FCPCHO

3.2.4.4.1.6 Submodule VI - Subroutine FCPUPD

3.2.4.4.1.6.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - Called by FCPIN to update HC status following input of a status response message.
- c. Constraints and limitations - Update status for one HC per invocation.

- d. Processing

This routine updates HC status (HCST1G), Azimuth encoder position (AZIMG), and Elevation encoder position (ELEV G) for a single heliostat as reported by an HC via the HFC to the HAC.

In addition to status updates, FCPUPD shall save the mark encountered bits if the HC is in the "SEEK MARK" mode/submode such that all such bits are available for final evaluation and subsequent mode changes and/or alarms. FCPUPD does not update AZ and EL if mode/submode equal zero.

- e. Error messages and recovery - None

3.2.4.4.1.6.2 Data, Logic, and Command Paths

Input parameters for FCPUPD are:

- a. Return link address;
- b. Buffer pointer; and
- c. HC index (0-2047).

Output parameters for FCPUPD are:

- a. (HCST1G) - HC status array;
- b. (AZIMG) - Heliostat Azimuth Encoder Position array; and
- c. (ELEV G) - Heliostat Elevation Encoder Position array.

3.2.4.4.1.6.3 Internal Data Description

Internal data used by FCPUPD are three masks:

- a. One to define the mode/submode field (#007C-bits 9-13);

- b. A second to define SEEK MARK mode/submode (#0064); and
- c. A third to define the two mark-encountered bits (#0000).

3.2.4.4.1.6.4 Flowchart

See Figure 3.2.4-9.

3.2.4.4.1.7 Submodule VII - Subroutine FCPSWH

3.2.4.4.1.7.1 Description

- a. Language used - MODCOMP Classic Assembler
- b. How invoked - Called by either FCPIN or FCPOUT upon detection of a line or HFC error.
- c. Constraints and limitations - None
- d. Processing - The FCPSWH routine shall be responsible for recording the error in global common (LINESG) and determining if a communications switchover condition is present (see paragraph 3.2.4.3).
 - 1. The FCPSWH routine begins processing by checking if all enabled lines have had an I/O error. If so then either a communication failure to the entire field has occurred or the field has suffered a power loss.
 - 2. If the backup HAC is operational, the FCPSWH routine will set a bit in global common to initiate a switchover. Otherwise a switch to the alternate lines will be made. No switching will be performed for a power loss condition.
 - 3. If a communication failure was not detected, the FCPSWH routine shall record an error in global common and perform checks to determine if a switchover condition is present for the indicated line. If so, the user file table for the communication lines in the same MODCOMP 1931 shall be switched to indicate the alternate lines. The status shall be set to failed for the normal lines and to active for the alternate lines.
- e. Error messages and recovery - No error messages are produced by FCPSWH.

Figure 3.2.4-8 Flowchart - FCPCHI

Figure 3.2.4-9 Flowchart - FCPUPD

3.2.4.4.1.7.2 Data, Logic, and Command Paths

Input data from FCPSWH are:

- a. Line number which had the error;
- b. HFC number which had the error;
- c. Type of error (input or output); and
- d. Global common variables FLDSTG, LINESEG, HFCS2G, status bit for backup HAC in HACSTG.

Output data from FCPSWH are:

- a. Modified global common words LINESEG and FLDSTG;
- b. User file tables (UFTS); and
- c. Global common bit to indicate switch to backup HAC.

3.2.4.4.1.7.3 Internal Data Description

The following are internal data used by FCPSWH:

- a. 15-word save area for registers R1 - R15;
- b. Logical file names associated with the alternate communication system;
- c. A mask used to test if the HFC already had an I/O error present; and
- d. Miscellaneous local variables.

3.2.4.4.1.7.4 Flowchart

See Figure 3.2.4-10.

3.2.4.5 Interface Description

- a. Data Base Input:

SUNPOG - Sun Position Vector
CMDBFG - Command Buffer
HCST1G - HC Status 1
HCST2G - HC Status 2
HFCS2G - HFC Status 2

- b. Data Base Output:

HCST1G - HC Status 1

Figure 3.2.4-10 Flowchart - FCPSWH (continued)

HCST2G - HC Status 2
HFCS1G - HFC Status 1
HFCS2G - HFC Status 2
AZ1MG - Azimuth Position
ELEVG - Elevation Position
CURHSG - Current HC group being statused
TBUSYG - Task Busy Flag
LINESEG - Communication Line Status*
FLDSTG - Field Status*
HACSTG - HAC Status*

*These data items are required by the FLDCOM module to be transferred to the backup HAC on a once-per-second basis.

c. Physical Output:

SUN/SYNCH - Active or enabled to eight HFC lines
STATUS POLL (MODCOMP 1931) Packets as described
COMMANDS in 3.2.1.2 of S/W Functional Requirements Specification.

d. Physical Input:

STATUS - From eight HFC lines (MODCOMP 1931)
Packets as described in 3.2.1.2 of
S/W Functional Requirements Specification.

e. Activation by TIK; and

f. Activation of SUN, ALM, BHI, BHC, and STS tasks.

3.2.4.6 Test Requirements

- a. Verification of FCP's logic will be done using MAX IV DEBUG. This system utility allows selective execution of portions of code, tracing, and modification of memory. The memory modification feature will be used to simulate HFC and HC behavior;
- b. Verification of timing will be done by repeated execution as well as oscilloscope inspection of communication lines; and
- c. Verification of communication performance to a field of 2048 heliostats is implied by "a" and "b" because FCP is designed to communicate with 64 HFCs and 2048 heliostats at all times. If any HFCs or HCs do not exist, error handling logic replaces status updates, but the timing does not change.

3.2.5 Alarm Processor Module - ALARMS

3.2.5.1 Purpose

The purpose of this module is to detect and display error conditions reported by the HCs, HFCs, and other software modules.

3.2.5.2 Requirements

3.2.5.2.1 Design Requirements

Section 3.1 of the 10 MWe Software/Firmware Functional Requirements Specifications states a requirement for control and monitoring of heliostats in all modes. This implies a need for real-time detection and display of abnormal heliostat responses.

3.2.5.2.2 Derived Requirements

Section 3.2.1.5 of the 10 MWe Software/Firmware Functional Requirements Specification imposes the following requirements on the alarms module:

- a. Monitor the heliostat status being returned from the field;
- b. Detect error conditions reported by the HC in that status;
- c. Report the alarms to the HAC operator using the alarms printer and an alarms area of the CS control console;
- d. Send alarm messages to the OCS through the OCS interface;
- e. Display alarms detected by other software modules; and
- f. Maintain ONLINE/OFFLINE status for the heliostats.

3.2.5.3 Design Approach

3.2.5.3.1 Functional Allocations

ALARMS processing decomposes logically into three major functions: alarms monitoring, alarms queueing, and alarms output. Figure 3.2.5-1 provides a system overview relating these three functions to each other and to certain relevant system elements.

The alarms monitoring function satisfies those requirements to periodically examine all heliostat status locations for conditions that are abnormal and demand operator attention. Additionally, the alarms monitoring function includes the capability to set individual heliostats to an offline mode as required by item (f) above.

ALARMS PROCESSING

Figure 3.2.5-1 Alarms Processing Overview

The alarms output function exists to provide the visible result of the alarms monitoring activities. For specific HC problems, it normally provides detailed alarms output but, when necessary, concentrates multiple HC alarms into higher level messages that display essential information in an abbreviated format.

The alarms queueing function provides for interfacing the high-speed activities of the alarms output function. It is designed to minimize the possibility of any alarm data being lost while accommodating the response time of an operator interface via the CRT. Additionally, the stand-alone nature of the alarms queueing function provides for an easy interface to accept alarm data from other system modules as required by item (e) above.

A brief description of the functions of Alarms Detection, Alarms Collection, Alarms Reporting, Alarms Queueing, and Alarms Output is presented in the remainder of this subsection. Figure 3.2.5-2 shows the four "levels" of status tables referred to in the text, as well as related tables which are discussed later in this ALARMS module section.

Alarms Detection - Consists of a main submodule (ALMDTC) that integrates alarms detection between status levels, four specialized submodules (ALMFLD, ALMLNE, ALMHFC, and ALMHC) that perform the alarms detection at each level on an individual block basis, and a support submodule (ALMGET) that determines the table-derived alarm number. The detection process proceeds from the lowest level status blocks to the highest level block, and existence of an unreported alarm anywhere in the system results in a flag eventually being set at the highest level. Thus, HC alarms propagate to HFC alarms, HFC alarms to line alarms, and line alarms to field alarms. The field alarm flag then triggers the alarms collection function for analysis of the situation.

The general logic flow of the four specialized submodules is similar in nature, but the specific error and offline testing is directly related to the structure of the corresponding status words in the common data base. Once the existence of an alarm has been determined, the alarm number is computed by ALMGET using the proper alarm detection table. The error testing is performed in order of alarm significance such that less important alarms never replace more important alarms. The alarm number maintained in the status word is always the most critical alarm currently in existence regardless of whether lesser unreported alarms exist. The detection of any alarm at any level results in a Type One alarm being propagated to next higher level, unless a different alarm already exists at the higher level. The lower-level status block is set with the actual alarm condition number and the reported alarm flag is cleared for all new alarms. The alarms collection function eventually executes and keys on the Type One alarm flags in its collection process.

Figure 3.2.5-2 Alarms Status Levels and Related Tables

Alarms Collection - This function is invoked only if alarms detection has indicated the existence of a new alarm condition. Alarms collection is accomplished by a single submodule (ALMCLT) that collects alarms at a given level, converts them into an alarm at the next higher level, and maintains doubleword memories for multiple error conditions. Alarms collection proceeds in a bottom-up manner through three successive calls to ALMCLT to collect HC alarms to HFC alarms, HFC alarms to line alarms, and line alarms to field alarms. When the collection process terminates, the data base status words are set with all appropriate alarm indicators to be processed by the alarms reporting function.

ALMCLT uses alarm Types One and Two as the key for its processing. Type One means that at least one lower-level alarm exists and a search must be made to determine if multiple alarms exist. Multiple alarms are then flagged with a Type Two alarm. If a Type Two alarm has been previously detected, the lower-level blocks are searched to insure that the condition still exists. The Type Two alarm is cleared if the multi-alarm condition no longer exists. All new alarms are flagged as unreported.

Alarms Reporting - This function executes only if the alarms collection functions have been performed. The alarms reporting function consists of a general submodule (ALMRPT) that executes once and a support submodule (ALMBLK) that is called once for each alarm condition that must be reported. Alarms reporting proceeds in a top-down direction so that low-level alarms reporting is suppressed when higher-level alarms are in existence. The alarms reporting function interfaces with the alarms queueing function and updates the common status flags as alarms are reported.

ALMRPT sets up the processing loops for each level of status and tests the alarm reported bit for each level. If required, a call is made to ALMBLK for processing of the actual alarm. The alarm number is used as an index into the proper alarm definition table, and the input for subroutine ALMQUE is constructed. The reported flag is set only after the ALMQUE submodule returns a flag indicating successful queueing of the alarm. Thus, if queueing is unsuccessful, the alarm report attempt will be retried after succeeding status updates until the queueing is successful or the alarm condition disappears.

Alarms Queueing - This function provides the interface between alarms monitoring and alarms output. It also provides an interface for other modules in the system that wish to output alarm messages. This function consists of the ALMQUE submodule which builds and queues compressed message blocks into a chain of free storage blocks. To prevent storage overflow, the chain is not allowed to exceed an arbitrary length. When the chain is full, the oldest alarm

message block is discarded and the newest message block added. This would normally occur only when one of the output devices has failed or the console operator is ignoring critical alarm messages. A queue-full message (unsuccessful queue) is returned only when the free storage system cannot provide a block for the new alarm message, or the ALMQUE work area is full.

Alarms Output - This function consists of the alarms output task (ALO) and support submodules to build ASCII messages from data blocks (ALOB LD and ALOCVT) and to dequeue expended message blocks (ALODQU). The ALO task is activated by the alarms queueing function when new alarm messages are added to the queue. It can also be activated by the MMI task when the console operator acknowledges the presence of a critical alarm on the screen. ALO executes at a lower priority level than either the alarms monitor task or the MMI task. All alarm formats are stored on disk by an off-line initialization program that is described in the initialization module (DBINIT) documentation. Four formats are stored on each sector, and the records are stored in the order of the associated alarm code numbers. The message formats themselves are defined in the same manner as FORTRAN format statements and are capable of handling H, X, F, E, A, and Z data conversions.

Normally, submodule ALOB LD reads message prototypes from disk, inserts the user parameters into the prototype, appends the time to the message, and writes it to the specified device. However, special processing is provided for the first five message types. Messages one, two, and three include parameters that define which lines, HFCs or HCs have errors in a multiple alarm message. The particular units that are defective are designated by the appropriate bits being set in a doubleword parameter so that the amount of storage space is minimized. ALOB LD calls ALOCVT to decode the compressed format and creates the final message output format. Message Types Four and Five relate to Mark conditions and require a disk read of the Mark biases to complete the message. All alarms are output to the general alarms portion of the operator's screen while only critical alarms are sent to the area of the screen that requires an operator response before the next critical alarm will be displayed.

3.2.5.3.2

Resource Budgets

15,000 bytes of core to keep alarms processing software resident.

8,192 bytes of core for free-storage buffer area.

6,400 bytes of disk space for alarm message formats.

1 percent of CPU time for monitoring function-no alarms processing.

CRT with two 80-character alarms display areas.

Printer logging device.

Priorities:

ALM - relatively high (synchronous)

ALO - relatively low (asynchronous)

3.2.5.4 Design Description

3.2.5.4.1 Module Structure

The software organization of the ALARMS processing module consists of two tasks and thirteen subroutines ("tasks" and "subroutines" take on the meaning defined by MODCOMP). Refer to Figure 3.2.5-3 for an overview of the ALARMS module structure.

Tasks:

- a. ALM - Alarms Monitoring - main routine which initiates all Alarms Processor Module actions; and
- b. ALO - Alarms Output - handles the output of all system alarms to the various output devices.

Subroutines:

- a. ALMDTC - Alarm Detection - Integrates the alarm status for two contiguous levels;
- b. ALMFLD - Field Test - Performs alarms detection at the field level;
- c. ALMLNE - Line Test - Performs alarms detection at the line level;
- d. ALMHFC - Heliostat Field Controllers Test - Performs alarm detection at the HFC level.
- e. ALMHC - Heliostat Controllers Test - Performs alarms detection at the HC level;
- f. ALMGET - Get Alarm - Does the status bit testing to determine which alarm bit is set, and returns an alarm number for that status bit;
- g. ALMCLT - Alarm Collect - Collects alarms reported at a lower status level, sets a higher-level multiple alarm flag if necessary, and maintains memory doublewords of all multiple alarms;
- h. ALMRPT - Alarm Report - Searches all status from the top level to the HC level and reports the highest-level alarms that exist;

Figure 3.2.5-3 Alarms Module Structure

- i. ALMBLK - Alarm Block - Handles the interface between the Alarms Monitor Task (ALM) and the alarms queueing system by organizing the parameters for a call to ALMQUE;
- j. ALMQUE - Alarm Queue - Can be called by Alarms Processor module (or any other system program) to build a compressed message block from passed parameters and to queue up the message block;
- k. ALOBLD - Message Build - Reads the disk to build alarm messages from queued message blocks;
- l. ALODQU - Deque - Handles the alarm message chain and FREES message blocks when all required output has been performed; and
- m. ALOCVT - Convert - Creates a list of items for multiple alarms formats.

3.2.5.4.1.1 Submodule I - ALM

3.2.5.4.1.1.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - REX, ACTIVATE issued once a second by FLDCOM.
- c. Constraints and limitations - None
- d. Processing - The Alarms Monitor submodule (ALM) is the central element in the alarms processing system and executes at a relatively high-priority level in the system task structure. It provides all of the field, line, HFC and HC alarm detection and reporting in the system. It also assumes responsibility for setting individual heliostats offline after errors occur and clears alarm flags when conditions return to normal.
 - 1. ALM accesses CURHSG to determine which one-eighth of the 2048-word HC status arrays is to be monitored for alarm conditions.
 - 2. ALM calls ALMDTC, which calls ALMHC four times, checking four online HC status words and maintaining the highest alarm for each. ALMDTC loops 64 times till 256 HCs are processed.
 - 3. ALM calls ALMDTC which calls ALMHFC eight times, checking eight HFC status words (only if installed) and maintaining the highest alarm for each. ALMDTC loops 8 times till 64 HFCs are processed.

4. ALM calls ALMDTC which calls ALMLNE eight times, checking eight line status words and maintaining the highest alarm for each.
5. ALM calls ALMFLD to test the field status word.
6. If an alarm change has not been detected, ALM terminates; otherwise, ALM continues as follows.
7. ALM calls ALMCLT which steps through 32 words of HC status if required. The alarms are counted to see if a multiple alarm situation exists. The HC alarm bit table, HCDBL, is updated. ALMCLT loops 64 times until all 2048 HCs are processed.
8. ALM calls ALMCLT which steps through eight words of HFC status if required. The alarms are counted to see if a multiple alarm situation exists. The HFC alarm bit table, HFCDBL, is updated. ALMCLT loops eight times until all 64 HFCs are processed.
9. ALM calls ALMCLT which steps through eight words of line status if required. The alarms are counted to see if a multiple alarm situation exists. The line alarm bit table, LNEDBL, is updated.
10. ALM calls ALMRPT to report alarms to the queuing system. ALM then terminates.

To summarize, ALM is activated once each second by the communications module after one-eighth of the heliostat field status has been updated. ALM then scans this updated HC status as well as all HFC, line, and field status and sets any necessary error conditions into global common memory. Alarm detection is the only function performed by ALM when no errors exist, so the task execution time requirement is minimal. Detection of alarm conditions forces execution of the collection and reporting subfunctions, and the execution time increases in proportion to the number of alarms. If an abnormally large number of alarms occur, the ALM task is designed to delay detection processing and catch up as time becomes available.

e. Error messages and recovery - None

3.2.5.4.1.1.2 Data, Logic and Command Paths

- a. Input Description - All input is through global common;
- b. Output Description - No direct output;
- c. Submodules called - ALMDTC, ALMFLD, ALMCLT, and ALMRPT; and

d. Global common usage - CURHSG.

3.2.5.4.1.1.3 Internal Data Description

The doubleword memory tables HCDBL, HFCDBL, and LNEDBL (reference Figure 3.2.5-2) are physically located here. The use of these tables is described in Submodule VIII, ALMCLT (see Section 3.2.5.4.1.8).

3.2.5.4.1.1.4 Flowcharts

See Figure 3.2.5-4.

3.2.5.4.1.2 Submodule II - ALMDTC

3.2.5.4.1.2.1 Description

a. Language used - MODCOMP Assembly

b. How invoked - Calling Sequence:

BLM,9	ALMDTC
DFC	HIPTR
DFC	HICNT
DFC	LOPTR
DFC	LOCNT
DFC	SKPCNT
DFC	TSTSUB

c. Constraints and limitations - None

d. Processing - ALMDTC integrates the alarm status for two continuous status levels. It calls the specified test subroutine for each block at the lower level and sets alarm flags at the higher level when necessary.

1. The passed parameters are accessed.
2. A high (outer) loop is set up to start at HIPTR and loop HICNT times, incrementing the LOPTR by SKPCNT each time through the loop.
3. A low (inner) loop is set up to start at LOPTR and loop LOCNT times, calling submodule TSTSUB each time through the loop.
4. Execution of the loops begins. LOPTR and HIPTR point to global common status arrays, a

Figure 3.2.5-4 Flowchart - ALM

low level and a higher level. If the calls to TSTSUB detect an Alarm change stepping through the low loop, and the corresponding high loop status word has no alarm of its own, the high-level status word is set to alarm one, thus propagating low-level alarms upward.

5. When the inner and outer loops both complete execution, the submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.2.2 Data, Logic and Command Paths

a. Input description

HIPTTR - Pointer to high-level status array
HICNT - Number of high-level blocks
LOPTR - Pointer to low-level status array
LOCNT - Number of low-level blocks tested per high-level block
SKPCNT - Number of low-level blocks not tested per high-level block
TSTSUB - Pointer to low-level status testing submodule

- b. Output description - There is no output in this submodule.
- c. Submodules called - TSTSUB can be ALMLNE, ALMHFC, or ALMHC.
- d. Global common usage

FLDSTG, LINE\$G, HFCS2G, HCST1G, and HCST2G.

3.2.5.4.1.2.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.2.4 Flowcharts

See Figure 3.2.5-5.

3.2.5.4.1.3 Submodule III - ALMFLD

3.2.5.4.1.3.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - FLM,8 ALMFLD
- c. Constraints and limitations - None

Figure 3.2.5-5 Flowcharts - ALMDTC

d. Processing - This submodule performs alarms detection at the field level. It sets an alarm flag for the highest-order existing error and clears the alarm flag when the error condition disappears.

1. The submodule first checks for error bits in FLDSTG. If none are found and the old alarm was greater than three, it is cleared. If the alarm was one (a propagated alarm) it will be propagated higher. The submodule exits.

2. If an alarm was found, it is resolved with a call to ALMGET. The alarm number is stored in FLDSTG but will not be reported if it has already been reported. The submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.3.2 Data, Logic and Command Paths

- a. Input description
This call must pass registers set up in ALM.
- b. Output description
Register 10 is alarm indicator (1=No Alarm; 0=Alarm)
- c. Submodules called
ALMGET
- d. Global common usage
FLDSTG

3.2.5.4.1.3.3 Internal Data Description

FLDALM table - Field alarm detection table; and
FLDTBL table - Field alarm definition table.

3.2.5.4.1.3.4 Flowcharts See Figure 3.2.5-6.

3.2.5.4.1.4 Submodule IV - ALMLNE

3.2.5.4.1.4.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - BLM,8 ALMLNE
- c. Constraints and limitations - None
- d. Processing - This submodule performs alarms detection at the line level. It sets an alarm flag for the

Figure 3.2.5-6 Flowcharts - ALMFLD

highest-order existing error and clears the alarm flag when the error condition disappears.

1. The submodule first checks for error bits in LINESG. If none are found and the old alarm was greater than three, it is cleared. If the alarm was one (a propagated alarm), it will be propagated higher. The submodule exits.
2. If an alarm was found, it is resolved with a call to ALMGET. The alarm number is stored in LINESG but will not be reported if it has already been reported. The submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.4.2 Data, Logic and Command Paths

- a. Input description
This call must pass registers set up in ALM and ALMDTC.
- b. Output description
Register 10 is alarm indicator (1=No alarm; 0=Alarm)
- c. Submodules called
ALMGET
- d. Global common usage
LINESG

3.2.5.4.1.4.3 Internal Data Description

LNEALM - Line alarm detection table; and
LNETBL - Line alarm definition table.

3.2.5.4.1.4.4 Flowcharts

See Figure 3.2.5-7.

3.2.5.4.1.5 Submodule V - ALMHFC

3.2.5.4.1.5.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - BLM,8 ALMHFC
- c. Constraints and limitations - None
- d. Processing - This submodule performs alarms detection at the HFC level. It sets an alarm flag for the highest-order existing error and clears the alarm flag when the error condition disappears. When an

Figure 3.2.5-7 Flowcharts - ALMLNE

HFC communications error is detected, all affected HCs are set offline.

1. This submodule first checks the not-installed bit in HFCS2G and exits if true.
2. The next check is for error bits in HFCS1G. If none are found and the old alarm was greater than three, it is cleared. If the alarm was one (a propagated alarm), it will be propagated higher. The submodule exits.
3. The alarm number is resolved with a call to ALMGET and stored in HFCS2G, but will not be reported if it already has been reported. The submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.5.2 Data, Logic and Command Paths

- a. Input description
This call must pass registers set up in ALM and ALMDTC.
- b. Output description
Register 10 is alarm indicator (1=No alarm; 0=Alarm)
- c. Submodules called
ALMGET
- d. Global common usage
HFCS1G, HFCS2G

3.2.5.4.1.5.3 Internal Data Description

HFCA LM - HFC alarm detection table
HFCTBL - HFC alarm definition table

3.2.5.4.1.5.4 Flowcharts

See Figure 3.2.5-8.

3.2.5.4.1.6 Submodule VI - ALMHC

3.2.5.4.1.6.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - BLM,8 ALMHC
- c. Constraints and limitations - None

Figure 3.2.5-8 Flowchart - ALMHFC

d. Processing - This submodule performs alarms detection at the HC level. It sets an alarm flag for the highest-order existing error and clears the alarm flag when the error condition disappears. It sets the HC offline bits as necessary following alarms detection.

1. This submodule first checks the offline bits in HCST2G and exits if true.
2. The next checks are for error bits in HCST1G (including communication error), then HCST2G, then a special test for UNMARKED status. If no errors are found and the old alarm was greater than three, it is cleared and the submodule exits.
3. If an alarm was found, the alarm number is resolved with a call to ALMGET and stored in HCST2G, but will not be reported if it already has been reported. The submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.6.2 Data, Logic and Command Paths

- a. Input description
This call must pass registers set up in ALM and ALMDTC.
- b. Output description
Register 10 is alarm indicator (1=No alarm; 0=Alarm)
- c. Submodules called
ALMGET
- d. Global common usage
HCST1G, HCST2G

3.2.5.4.1.6.3 Internal Data Description

HCALM - HC alarm detection table
HCTBL - HC alarm definition table

3.2.5.4.1.6.4 Flowcharts

See Figure 3.2.5-9.

3.2.5.4.1.7 Submodule VII - ALMGET

3.2.5.4.1.7.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked -

RLM,14	ALMGET
DFC	ALMTBL
DFC	TBLN

Figure 3.2.5-9 Flowcharts - ALMHC

- c. Constraints and limitations - This submodule is called with a generic parameter, ALMTBL, which can be FLDALM, LNEALM, HFCALM, or HCALM as shown in Figure 3.2.5-2. The contents of these alarm detection tables must be arranged in descending priority order, and a parallel table (FLDTBL, LNETBL, HFCTBL, or HCTBL) must exist. Refer to Table 3.2.5-I.
- d. Processing - This submodule does the status bit testing and translates the highest priority status bit into an alarm number (four through fifteen) which will fit into the four-bit field of the status word. The process is table driven by the contents of ALMTBL, and the output is correlated to the position within the table where the match occurs.
- e. Error messages and recovery - None

3.2.5.4.1.7.2 Data, Logic and Command Paths

a. Input description

ALMTBL - Pointer to table specifying the register and bit to test for each alarm.

TBLEN - Length of ALMTBL

R12 - Current actual status

R13 - Current derived status

NOTE: Each ALMTBL table entry is a two-digit hexadecimal number that specifies the location and bit number for each alarm. If the first digit is "C", the actual status location is to be interrogated, while a "D" means the derived status location is to be used. The second digit specifies the bit number to be tested in either the actual or derived status. Refer to Table 3.2.5-II.

b. Output description

R14 - Alarm number for four-bit field in status word

c. Submodules called

None

d. Global common usage

None

3.2.5.4.1.7.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.7.4 Flowcharts

See Figure 3.2.5-10.

HC ALARMS (HCALM)

#C5	HC Communications Error
#DA	Missing Command Return
#C6	No Motion Error (AZ or EL)
#D7	HC Unavailable (WASH/OFFLINE) to STHIWIND
#D6	HC Cannot Return to SAVE Position
#C4	EL MARK Encountered
#C3	AZ MARK Encountered
#D8	Sequence Command Timed Out
#D9	Extra Command Returned

HFC ALARMS (HFCALM)

#C1	HFC Detected HAC/HFC Communications Error
#C2	Firmware Error
#C5	HAC to HFC Communications Output Timed Out
#C6	HAC to HFC Communications Input Timed Out
#C7	Invalid Data Received from HFC
#C8	HFC Did Not Receive Last Command

LINE ALARMS (LINEALM)

#C0	Line Communications Output Error
#C1	Line Communications Input Error

FIELD ALARMS (FLDALM)

#C3	Field Power Loss
#C4	Communication Failure With Field

Figure 3.2.5-10 Flowcharts - ALMGET

3.2.5.4.1.8 Submodule VIII: ALMCLT

3.2.5.4.1.8.1 Description

a. Language used - MODCOMP Assembly

b. How invoked - Calling Sequence:

BLM,8	ALMCLT
DFC	FLGPTR
DFC	HIPTR
DFC	HICNT
DFC	LOPTR
DFC	LOCNT

c. Constraints and limitations - None

d. Processing - ALMCLT collects all alarms reported at a lower status level and sets a higher-level multiple-alarm flag if necessary.

1. The passed parameters are accessed.
2. A high (outer) loop is set up to start at HIPTR and loop HICNT times.
3. A low (inner) loop is set up to start at LOPTR and loop LOCNT times.
4. Execution of the loops begin. HIPTR and LOPTR point to global common status arrays, a high level and a low level. If the high-level alarm is greater than three, the high-level loop proceeds to the next high-level status word. If the high-level alarm is one or two, the low-level status words (LOCNT of them) are checked for any alarm, and if one is found, it is counted and a corresponding bit is set into the doubleword flag table pointed to by FLGPTR. If the total count exceeds one at the end of the low-level loop, the high-level error field is set to two to indicate a multiple alarm condition; otherwise it is cleared. If the doubleword contents has changed from the last time this subroutine was executed, the high-level status is marked as unreported.
5. When the inner and outer loops both complete execution, the submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.8.2 Data, Logic and Command Paths

a. Input Description:

FLGPTR - Pointer to alarm flag array
HIPTR - Pointer to higher-level status array
HICNT - Number of higher-level status words
LOPTR - Pointer to lower-level status array
LOCNT - Number of lower-level status words

b. Output Description - Output is to the global common status tables;

c. Submodules Called - None; and

d. Global Common Usage - FLDSTG, LINESEG, HFCS2G, HCST2G.

3.2.5.4.1.8.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.8.4 Flowcharts

See Figure 3.2.5-11.

3.2.5.4.1.9 Submodule IX: ALMRPT

3.2.5.4.1.9.1 Description

a. Language used - MODCOMP Assembly

b. How invoked - BLM,1 ALMRPT

c. Constraints and limitations - None

d. Processing - ALMRPT searches through all status from the top level to the HC level and reports the highest-level alarms that exist.

1. ALMRPT starts at the highest level and works down (FLDSTG, LINESEG, HFCS2G, HCST2G), checking for alarms.
2. If a FLDSTG alarm exists and is not reported, ALMBLK is called; ALMRPT then exits.
3. If no FLDSTG alarm exists, the eight words of LINESEG are checked for alarms. If an alarm is found and not reported, ALMBLD is called. Then all eight HFC and all (8 * 32) HC alarms (if any) are skipped for that line, and the next line is checked.

Figure 3.2.5-11 Flowcharts - ALMCLT

5. If the HFCS2G word has no alarm, the 32 HCs associated with the HFC are checked. If an alarm is found in HCST2G and not reported, ALMBLK is called. The next HC is then checked.

6. The submodule exits.

e. Error messages and recovery - None

3.2.5.4.1.9.2 Data, Logic and Command Paths

- a. Input Description
Global common status arrays
- b. Output Description
Global common status arrays
- c. Submodules Called
ALMBLK
- d. Global Common Usage
LINESEG, FLDSTG, HFCS2G, and HCST2G.

3.2.5.4.1.9.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.9.4 Flowcharts

See Figure 3.2.5-12.

3.2.5.4.1.10 Submodule X: ALMBLK

3.2.5.4.1.10.1 Description

- a. Language used - MODCOMP Assembly
- b. How invoked - Calling Sequence:

BLM,8	ALMBLK
DFC	TABLE
DFC	UNIT

- c. Constraints and limitations - None
- d. Processing - This submodule handles the interface between the alarms monitor function and alarms queueing. It sets up the alarm parameters for each type of alarm and calls ALMQUE. It sets the alarm reported flag once the alarm has been successfully queued.

ALMBLK isolates the four-bit error field (error numbers one to fifteen) from the status word and transforms it,

Figure 3.2.5-12 Flowcharts - ALMRPT

using the appropriate Alarm Definition Table, into an actual message code, a parameter count, and level flag. If AZ and EL are required parameters, they are pulled from global common AZIMG and ELEVG. The 32 flag bits of the next lower level are pulled (for multiple alarm reporting). These data values become parameters for a call to ALMQUE.

e. Error messages and recovery

3.2.5.4.1.10.2 Data, Logic and Command Paths

a. Input Description

TABLE	-	Pointer to Alarm Definition Table
UNIT	-	Number of Field, Line, or HFC
Register 2	-	Status word pointer
Register 5	-	HC index
Register 6	-	Multiple alarm doubleword
Register 7	-	

b. Output Description
None

c. Submodules Called
ALMQUE

d. Global Common Usage
FLDSTG, LINESG, HFCS2G, and HCST2G.

3.2.5.4.1.10.3 Internal Data Description

This is the data for the call to ALMQUE:

PARMS	+0	UNIT
	+1	
	+2	
	+3	32 bit doubleword
	+4	HFC No.
	+5	HC No.
	+6	AZ
	+7	EL
MSGCODE	MSG #	
NPARMS	# Parameters	
LEVEL	Level	
QFUL	Flag to be tested (0 = not full; 1 = queue full)	

3.2.5.4.1.10.4 Flowcharts

See Figure 3.2.5-13.

Figure 3.2.5-13 Flowcharts - ALMBLK

3.2.5.4.1.11 Submodule XI - ALMQUE

3.2.5.4.1.11.1 Description

a. Language Used - FORTRAN

b. How Invoked - Calling Sequence

Call ALMQUE (MSGNUM, NPARMS, PARMS, LEVEL, INDIC)

c. Constraints and Limitations - Message formats must be defined on disk. The caller must test INDIC to determine if queueing was successful.

d. Processing - The ALMQUE submodule is the interface program for all system alarm reporting. It can be called by any system module to queue a predefined alarm message to the ALARMS output system.

1. ALMQUE starts building a compressed message block (see Table 3.2.5-III).
2. The caller's parameters, if any, are moved into the block.
3. The ENQUE service is called to put the block into the ALO queue.
4. The caller's indicator (INDIC) is set to reflect the success/failure of the ENQUE.

e. Error messages and recovery - None

3.2.5.4.1.11.2 Data, Logic and Command Paths

a. Input Description

MSGNUM - Message Code Number (INTEGER*2)

NPARMS - Number of Parameters in Message (INTEGER*2)

PARMS - Parameter Array (REAL*4)

LEVEL - Alarm Priority Level (0 = Normal; 1 = Critical) (INTEGER*2)

h. Output Description

INDIC - Success/fail indicator (0 = Success; 1 = Failure) (INTEGER*2)

c. Submodules Called

ENQUE Service

d. Global Common Usage

COMQUE - Common Queue

3.2.5.4.1.11.3 Flowcharts

See Figure 3.2.5-14.

0* 1* 2* 3* 4* 5* 6* 7* 8* 9*10*11*12*13*14*15*			
NEXT			
C*	COUNT*	*NPARMS	MESSAGE CODE NUMBER
TIME			
PARAMETER NUMBER 1			
.			
.			
.			
PARAMETER NUMBER NPARMS			

NEXT = Pointer to Next Alarm (FSB Index)
 NPARMS = Number of Parameters
 C = Critical Alarm Flag
 COUNT = Number of Output Devices
 TIME = Integer Seconds Since Midnight

Table 3.2.5-III Compressed Message Format

3.2.5.4.1.12 Submodule XII - ALO

3.2.5.4.1.12.1 Description

- a. Language Used - FORTRAN
- b. How Invoked - Invoked by ALMQUE or MANMIF
- c. Constraints and Limitations - None
- d. Processing - ALO is a submodule that handles the outputting of all system alarms to the various output devices.
 - 1. ALO and ALMQUE utilize the same queue; ALMQUE enqueues compressed message blocks and ALO dequeues them for further processing.
 - 2. ALO clears the critical alarms screen line after the operator command (!!), then dequeues, builds, and outputs the next critical alarm (if any).
 - 3. ALO always dequeues, builds, and outputs non-critical screen lines until all enqueued blocks have been processed. This is also true of logger/printer alarms.
 - 4. All screen messages are outputted via an ENQUE to the CSO queue; printer messages are outputted via a WRITE statement.
- e. Error Messages and Recovery - None

3.2.5.4.1.12.2 Data, Logic and Command Paths

a. Input Description

Input to ALO are the compressed message blocks enqueued by ALMQUE.

b. Output Description

Output of ALO consists of messages to the output devices.

c. Submodules Called

DEQU
LEAS
FRE
ENQU
ALODQU
ALOBLD

d. Global Common Usage

COMQUE
GTIMEG
PTRSG
FIRSTG
LASTG
COUNTG
ALRMSG
TBUSYG

3.2.5.4.1.12.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.12.4 Flowcharts

See Figure 3.2.5-15.

3.2.5.4.1.13 Submodule XIII - ALOBLD

3.2.5.4.1.13.1 Description

- a. Language Used - FORTRAN
- b. How Invoked - Call ALOBLD (IDEST)
- c. Constraints and Limitations - Must be preceded by a call to ALODQU.
- d. Processing - ALOBLD is a support submodule for ALO that reads the disk to build alarm messages from the compressed format generated by the alarms queueing system (refer to Table 3.2.5-IV). The ASCII alarm is then output to the specified device.
 1. Alarm types one through five require special processing. Messages one, two, and three include parameters that define which LINES, HFCs, or HCs have errors in a multiple alarm message. A doubleword (32 bits) specifies which units have errors; subroutine ALOCVT creates the final message output format from information in the doubleword.

CRITICALFIELD ALARMS

Y HH:MM:SS FIELD POWER LOSS
Y HH:MM:SS COMMUNICATION FAILURE WITH FIELD
Y HH:MM:SS MULTIPLE LINE ERRORS; LINE 1,2,3,4,5,6,7,8

LINE ALARMS

Y HH:MM:SS LINE FAILURE AND SWITCHOVER; LINE N
Y HH:MM:SS LINE COMMUNICATIONS OUTPUT ERROR; LINE N
Y HH:MM:SS LINE COMMUNICATIONS INPUT ERROR; LINE N
Y HH:MM:SS MULTIPLE HFC ERRORS; LINE N; HFC 1,2,3,4,5,6,7,8

HFC ALARMS

Y HH:MM:SS HFC DETECTED HAC/HFC COMMUNICATIONS ERROR; HFC NN
Y HH:MM:SS FIRMWARE ERROR - HFC NN STATUS = XXXX
Y HH:MM:SS HAC TO HFC COMMUNICATIONS OUTPUT TIMED OUT; HFC NN
Y HH:MM:SS HAC TO HFC COMMUNICATIONS INPUT TIMED OUT; HFC NN
Y HH:MM:SS INVALID DATA RECEIVED FROM HFC NN
Y HH:MM:SS HFC DID NOT RECEIVE LAST COMMAND; HFC NN
Y HH:MM:SS HC ERRORS; HFC NN; HC 123456789/0123456789/0123456789/012

HC ALARMS

N HH:MM:SS HC COMMUNICATIONS ERROR; HFC NN; HC NNNN
N HH:MM:SS MISSING COMMAND RETURN; HFC NN; HC NNNN
N HH:MM:SS NO MOTION ERROR (AZ OR EL); HFC NN; HC NNNN
N HH:MM:SS HC UNAVAILABLE (WASH/OFFLINE) TO STHIWIND:HFC NN; HC NNNN
N HH:MM:SS HC CANNOT RETURN TO SAVE POSITION: HFC NN; HC NNNN
N HH:MM:SS EL MARK ENCOUNTERED: HFC NN; HC NNNN; EL=#XXXX; BIAS=#XXXX
N HH:MM:SS AZ MARK ENCOUNTERED: HFC NN; HC NNNN; EL=#XXXX; BIAS=#XXXX
N HH:MM:SS SEQUENCE COMMAND TIMED OUT; HFC NN; HC NNNN
N HH:MM:SS EXTRA COMMAND RETURNED; HFC NN; HC NNNN
N HH:MM:SS HC MARK POSITION OUTSIDE TOLERANCE; HFC NN; HC NNNN

SYSTEM ALARMS

HH:MM:SS OPERATOR CONSOLE MALFUNCTION
HH:MM:SS CRT MALFUNCTION
HH:MM:SS DISK REAK ERROR: TASK AAA FILE AAA
HH:MM:SS DISK WRITE ERROR: TASK AAA FILE AAA
HH:MM:SS RESTORE COMMAND ENCOUNTERED A HELIOSTAT IN THE WRONG MODE
HH:MM:SS CHANGE IN CLOCK ACCURACY STATUS FROM AAAAAAAAAA TO AAAAAAAAAA

Message types four and five relate to MARK conditions and require a disk read of the MARK biases to complete the message.

2. ALOBLD decodes time into HH:MM:SS format.
3. ALOBLD reads the message format from the disk and inserts the caller's parameters into the ASCII string. A check is made for disk read errors.
4. The completed ASCII message is output to one of three devices per call: the critical alarms line, the non-critical alarms line, or the printer. A check is made for output errors.
5. Errors encountered in the execution of this submodule are queued, like any other alarm, via a call to ALMQUE. A flag is maintained to prevent repetitive queueing of a non-changing error condition. Messages destined for the printer are transferred to the system console when the printer is returning error indicators.
6. The submodule exits.

- e. Error messages and recovery - Error messages are queued to ALARMS.

3.2.5.4.1.13.2 Data, Logic and Command Paths

- a. Input Description

IDEST - Output destination: 1 = CR; 2 = OC; and
3 = TY

- b. Output Description

None

- c. Submodules Called

ALMQUE
ALOCVT

- d. Common Usage

MSGCDE
OUTPUT

3.2.5.4.1.13.3 Internal Data Description

Local buffers and arrays.

3.2.5.4.1.13.4 Flowcharts

See Figure 3.2.5-16

3.2.5.4.1.14 Submodule XIV - ALODQU

3.2.5.4.1.14.1 Description

- a. Language used - FORTRAN
- b. How invoked - Call ALODQU (IDEST)
- c. Constraints and limitations - None
- d. Processing - ALODQU is a support submodule for ALO that handles the alarm message chain and frees message blocks when all required output has been performed.
 1. ALODQU copies the compressed message block from free storage to a local buffer.
 2. The FSB queue pointer is updated for DEVICE in preparation for the next call.
 3. The FSB of current interest is dequeued and FREE'd if it has been sent to all devices; otherwise it is retained in FSB with a decremented count field.
 4. The submodule exits.
- e. Error messages and recovery - None

3.2.5.4.1.14.2 Data, Logic and Command Paths

- a. Input Description

IDEST - Output destination: 1 = CR; 2 = OC; and
3 = TY
- b. Output Description

None
- c. Submodules Called

FREE (System Service)
- d. Global Common Usage

FIRSTG, LASTG, COUNTG, and PTRSG

Figure 3.2.5-16 Flowcharts - ALOBLD

Figure 3.2.5-16 Flowcharts - ALOBLD (Continued)

e. Common Usage

MSGCDE and OUTPUT

3.2.5.4.1.14.3 Internal Data Description

There is no data internal to this submodule.

3.2.5.4.1.14.4 Flowcharts

See Figure 3.2.5-17.

3.2.5.4.1.15 Submodule XV - ALOCVT

3.2.5.4.1.15.1 Description

- a. Language used - FORTRAN
- b. How invoked - Call ALOCVT (FLAG, IB, IC, NC, ICOM, ASC)
- c. Constraints and limitations - None
- d. Processing - This submodule converts a doubleword of bits into ASCII integers for each bit that is set and blanks for each zero bit.
- e. Error messages and recovery - None

3.2.5.4.1.15.2 Data, Logic and Command Paths

a. Input Description

FLAG - Array of bits (1-32)
IB - Initial bit to test
IC - Initial character to compute (0-9)
NC - Number of characters (even integer)
ICOM - Flag for inserting commas between each character
1 = insert commas; 2 = don't insert commas

b. Output Description

ASC - Array of output ASCII

c. Submodules Called

TESTB (FORTRAN Library)

d. Global Common Requirements

None

3.2.5.4.1.15.3 Internal Data Description

ASC - Local buffer for ASCII string.

3.2.5.4.1.15.4 Flowchart

See Figure 3.2.5-18.

Figure 3.2.5-17 Flowcharts - ALODQU

Figure 3.2.5-18 Flowcharts - ALOCVT

3.2.6 Status Display Module - STATUS

3.2.6.1 Purpose

The STATUS module decodes global status words to report on the status of the heliostat field. The STATUS module consists of two tasks: STS, the Synchronous Status Processor; and STA, the Asynchronous Status Processor. STS, in conjunction with submodule STSGET, synchronously reports on the status of the entire heliostat field. STA, in conjunction with submodules STAFLD, STAIND, STAMOD, STARNG, and STAGET, gives more detailed status information of varying formats upon request. See Table 3.2.6-I for the heliostat mode definitions.

3.2.6.2 Requirements

3.2.6.2.1 Design Requirements

Section 3.1 of the 10 MWe Software/Firmware Functional Requirements Specification (12 June 1980) lists three requirements involving the STATUS module:

- a. Monitor and display the operational status of all heliostats.

This requirement indicates a need to decode each heliostat's reported status data and format and display this data.

- b. Maintain command/response protocol and data transfer with the OCS.

This requirement indicates a need to format requested status information into the HAC to OCS message formats and send this data to the OCS.

- c. Provide status data to the DAS.

This requirement indicates a need to format requested status information into the HAC to DAS message formats and send this data to the DAS.

3.2.6.2.2 Derived Requirements

Section 3.2.1.6 of the 10 MWe Software/Firmware Functional Requirements Specification lists the following requirements of the STATUS module:

- a. Monitor heliostat status from status data reported by the HCs.

This requirement indicates a need to decode each heliostat's reported status information.

<u>MODE NO.</u>	<u>MODE NAME</u>	<u>DESCRIPTION</u>
1	TRACK	Heliostat tracking the primary target
2	STDBY	(Standby) Heliostat tracking corridor upper limit point
3	BCS	Heliostat tracking the Beam Characterization System Target
4	TRANS	Heliostat moving from one mode to another
5	STOW	Heliostat stowed face down
6	ALT1	Heliostat in mirror vertical STOW position
7	ALT2	Heliostat in mirror face up STOW position
8	MARK	Heliostat successfully positioned by MARK command
9	DIR.POS.	Heliostat in directed position mode for maintenance
10	WASH	Heliostat commanded to WASH mode
11	INIT	Heliostat being powered up, initialized, or communication error
12	OFFLINE	Heliostat set offline by OFFLINE command, timeout or communication error

Table 3.2.6-I. Heliostat Mode Definitions

b. Format field status.

This requirement indicates a need to format the field status into a displayable format.

c. Display field status on the STATUS area of the CS control console, updating display as required.

This requirement indicates a need to synchronously monitor the heliostat field, and detect changes in the data to be displayed.

d. Respond to operator-entered commands for display status as reported from the MANMIF module, and format the status as requested.

This requirement indicates a need for communication with the MANMIF module and format the requested data.

e. Output the formatted status to the status printer.

This requirement indicates a need to write to the status printer when required.

f. Respond to OCS and DAS generated status requests by transmitting the requested status to the requestor.

This requirement indicates a need to communicate with the EXTINF module for data transmission, and a communication with the MANMIF module to indicate the source of the request.

3.2.6.3 Design Approach

3.2.6.3.1 Functional Allocations

The STATUS module is comprised of eight submodules. (See Figure 3.2.6-1 for the STATUS module structure.) The basic purpose of each is described below:

- a. STS (Synchronous Status Processor) - This submodule monitors, on a synchronous basis, the number of heliostats in each operational mode. STS scans one-eighth of the field each second. Any changes found in the data to be displayed cause an update in the data and display. STS also builds data packets for the graphics display units, and synchronously outputs date and time to the HAC operator's console. See Figure 3.2.6-2 for the HAC operator's console synchronous status display;
- b. STSGET (Synchronous Status Decoder) - This submodule is called by STS to decode the HC status words (HCST2G and HCST1G) to determine the mode of a given

Figure 3.2.6-1 STATUS
Module Structure

HAC SYNCHRONOUS STATUS DISPLAY AREA

COLL

1	5	1	1	2	2	3	3	4	4	5	5	6	6	7	7	8
0	5	0	5	0	5	0	5	0	5	0	5	0	5	0	5	0

CRITICAL ALARMS AREA

LATEST ALARM AREA

MM/DD/YY HH:MM:SS

TARGETING MODES

STOW MODES

TRAN

DIR.
POS.

WASH

INIT

OFF-
LINE

TRACK STDBY BCS

STOW ALT1 ALT2 MARK

nnnn nnnn nnnn

nnnn

nnnn nnnn nnnn nnnn

nnnn

nnnn

nnnn

nnnn

CONVERSATIONAL
AREA

Figure 3.2.6-2 HAC Operator's Console Synchronous Status Display

HC. See Table 3.2.6-II for the mapping from actual mode to reported mode;

- c. STA (Asynchronous Status Processor) - This submodule is activated by STS if the Man-Machine Interface module (MANMIF) has indicated an operator-initiated status request. Depending on the type of request ("Field," "Mode," "Individual," or "Ring"), STA calls one of the following four submodules: STAFLD, STAIND, STAMOD, and STARNG;
- D. STAFLD (Field Status Processor) - STAFLD is called by STA to process "Field" status requests. It formats the latest status data created by STS (MODEG) and sends the results to the OCS or DAS consoles, HAC line printer, or, optionally, the HAC operator's console. See Figure 3.2.6-3 for the STAFLD output format, and Table 3.2.6-III for the STAFLD OCS and DAS message format;
- e. STAIND (Individual Status Processor) - STAIND is called by STA to process individual status requests. For the given HC it determines the actual mode, commanded mode, segment, azimuth, and elevation. See Figure 3.2.6-4 for the CS console display and Table 3.2.6-IV for the OCS and DAS message format;
- f. STAMOD (Mode Status Processor) - STAMOD is called by STA to process "Mode" status requests. It determines all the HCs which are in the requested mode, formats this list (see Table 3.2.6-V), and sends it to the DAS or OCS consoles, CS line printer, or optionally, the CS console (see Figure 3.2.6-5);
- g. STARNG (Ring Status Processor) - STARNG is called by STA to process a "Ring" status request. It determines all the segment numbers in the ring, the total number of HCs in each of the segments, and the numbers of HCs in TRACK and STANDBY for each segment in the ring. See Figure 3.2.6-6 for the STARNG CS console display, and Table 3.2.6-VI for the OCS and DAS Segment Track Status Message format; and
- h. STAGET (Asynchronous Status Decoder) - STAGET is called by STAFLD, STAIND, STAMOD, and STARNG to decode the HC status words (HCST2G and HCST1G) to determine the actual mode and the commanded mode of a given HC.

3.2.6.3.2

Resource Budgets

STATUS requires approximately (5K) words of memory. It is the lowest priority foreground module in the heliostat system and is synchronously activated. STATUS requires no disk or magnetic tape access.

10 MWe STATUS (STSGET)

MAPPING FROM ACTUAL STATUS TO REPORTED MODE

<u>ACTUAL MODE</u>	<u>STATUS MODE</u>	<u>NO.</u>
Offline - Not installed	Not reported	-1
Offline - Communication Error	OFFLINE	12
Offline - Serious Alarm	OFFLINE	12
Offline - Operator	OFFLINE	12
Offline - Unmarked	OFFLINE	12
Position, No Compare	TRANSITION	4
Restarted - Power-up or time-out	INIT	11
Restarted - Successive Comm. Errors	INIT	11
Beam Pointing - Track	TRACK	1
Beam Pointing - BCS	BCS	3
Beam Pointing - Standby or CULP	STANDBY	2
Beam Pointing - CLLP	TRANSITION	4
Corridor Walk - Up Corridor A, B, C, or D	TRANSITION	4
Corridor Walk - Down Corridor A, B, C, or D	TRANSITION	4
Az-El Pointing - Stow	STOW	5
Az-El Pointing - Seek Marks	MARK	8
Az-El Pointing - Wash	WASH	10
Az-El Pointing - Maintenance	DIR.POS.	9
Az-El Pointing - Alt1	ALT1	6
Az-El Pointing - Alt2	ALT2	7

Table 3.2.6-II. 10 MWe Status (STSGET)

FIELD STATUS

<u>MODE</u>	<u>TOTAL</u>
TRACK	nnnn
STDBY	nnnn
BCS	.
TRANS	.
STOW	.
ALT1	.
ALT2	.
MARK	.
DIR.POS.	.
WASH	.
INIT	.
OFFLINE	nnnn
TOTAL	tttt

Figure 3.2.6-3 STAFLD Field Status Display

TABLE 3.2.6-III HAC-OCS/DAS ENVIRONMENT STATUS (FIELD) FORMAT

MESSAGE LAYOUT

APPLICATION HAC - OCS/DAS MESSAGE TYPE STATUS - FIELD
PROGRAMMER T. Ladewig DATE 2/8/80

TABLE 3.2.6-III HAC-OCS/DAS ENVIRONMENT STATUS (FIELD) FORMAT (CONTINUED)

MESSAGE LAYOUT

APPLICATION HAC OCS/DAS STATUS-FIELD
MESSAGE TYPE (CONTINUED)

PROGRAMMER T. Ladewig

DATE 2/8/80

32	ALTERNATE 2 STOW	32	ASCII NNNN = HCs in ALT2STOW
35	TRANSITION	35	ASCII NNNN = HCs in Transition
40	WASH	40	ASCII NNNN= HCs In Wash
45	DIRECTED POSITION	45	ASCII NNNN = HCs in directed position
50	OFFLINE	50	ASCII NNNN = HCs in offline
55	MARK	55	ASCII NNNN= HCs in Mark
60	INIT	60	ASCII NNNN = HCs in INIT
60	UNUSED	60	
77		77	
80	CHECKSUM	80	8 bit checksum such that all bytes sum to zero.

INDIVIDUAL STATUS:

HELIOSTAT NUMBER: NNNN

SEGMENT: NNN

AZIMUTH: SNNN.NN

ELEVATION: SNNN.NN

COMMANDED MODE: MMM

ACTUAL MODE: MMM

Figure 3.2.6-4 STAIN Display Format

TABLE 3.2.6-IV HAC-OCS/DAS ENVIRONMENT STATUS (HC) FORMAT

MESSAGE LAYOUT

APPLICATION	HAC	OCS /DAS	MESSAGE TYPE	STATUS INDIVIDUAL HC
-------------	-----	----------	--------------	-------------------------

PROGRAMMER	T. Ladewig	DATE	2/8/80
------------	------------	------	--------

1		1	• ASCII H = HAC Originated
	HEADER		• Message byte count (See note for Table XXI)
	STS		• ASCII STS = Status
5		5	
	R		• ASCII R = Requested
	H		• ASCII H = Individual Status
10		10	
	TIME		
15		15	
	HC#		• ASCII 4 Digit HC Number
20		20	
	AZIMUTH		• ASCII 7 Digit SNNN.NN Azimuth
25		25	
	ELEVATION		• ASCII 7 Digit SNNN.NN Elevation
30		30	
32		32	
	////		

MESSAGE LAYOUT

[illegible]

TABLE 3.2.6-V HAC-OCS/DAS ENVIRONMENT STATUS (MODE) FORMAT
MESSAGE LAYOUT

APPLICATION HAC-OCS/DAS MESSAGE TYPE STATUS--MODE

PROGRAMMER T. Ladewig

DATE 2/8/80

1		1	ASCII H = HAC originated
	HEADER		Message byte count (see Note for Table XXI)
5	STS	5	ASCII STS - STATUS
	CONDITION		ASCII R = Requested
	M		A = Alarmed*
			ASCII M = Mode
10	MODE	10	ASCII TRK = Track
			BCS = BCS
			STB = Standby
			STO = Stow
			AL1 = ALT1STOW
			AL2 = ALT2STOW
			TRN = Transition
			WSH = Wash
15	TIME	15	DPO = Directed Position
			OFF = Offline
			MRK = Mark
			INI = Init
			ASCII hhmmss - Time
	HC#		ASCII 4 digit HC number. Additional
20		20	messages will be used to transmit
			additional HCs.
	HC#		
25		25	
	...		
	UNUSED		
80	CHECKSUM	80	Checksum

*NOTE: Alarmed will be used to report HCs unable to respond to a STHIWIND command. HCs in WASH, OFFLINE, and DIRECTED POSITION will be transmitted

MODE STATUS

HELIOSTATS IN MODE MMM:

NNNN, NNNN, NNNN, --- NNNN

NNNN,

.

.

.

NNNN, NNNN

Figure 3.2.6-5 STAMOD Display Format

SEGMENT TRACK STATUS

RING X

SEGMENT NUMBER	HCs IN SEGMENT	HCs IN TRACK	HCs IN STANDBY
nnn	nnn	nnn	nnn
nnn	nnn	nnn	nnn
.	.	.	.
.	.	.	.
.	.	.	.
.	.	.	.
.	.	.	.
nnn	nnn	nnn	nnn
TOTALS:	ttt	ttt	ttt

Figure 3.2.6-6 STARNG Segment Track Status

TABLE 3.2.6-VI HAC-OCS/DAS ENVIRONMENT STATUS (RING) FORMAT
MESSAGE LAYOUT

APPLICATION HAC-OCS/DAS STATUS
MESSAGE TYPE RING

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	ASCII H = HAC Originated
	HEADER		Message byte count (see note for Table XXI.)
5		5	ASCII STS = STATUS
	R		ASCII R = Requested
	R		ASCII R = Ring
10		10	ASCII Time Plant Local
	TIME		
15		15	ASCII 1-digit Ring number requested
	RING		
	SEGMENT		ASCII 3-digit Segment number
20		20	ASCII 2-digit number of HCs in Segment
	HCS in SEGMENT		
	TRACK		ASCII 2-digit number of HCs in TRACK in Segment
	STANDBY		ASCII 2-digit number of HCs in STANDBY in Segment
	REPEAT		REPEAT as many times as necessary to cover complete ring - multiple messages may be necessary.
80	CHECKSUM	80	

3.2.6.4 Design Description

3.2.6.4.1 Module Structure

STATUS is divided into eight submodules: STS, STSGET, STA, STAFLD, STAIND, STAMOD, STARNG and STAGET. STS and STSGET are synchronously activated by FCP, and STA is activated by STS if there is a pending operator status request. See Figure 3.2.6-1 for the STATUS module structure.

3.2.6.4.1.1 Submodule I - STS

3.2.6.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - Synchronously activated by FCP
- c. Constraints and limitations - None
- d. Processing -
 1. Upon being activated by FCP, STS determines which one-eighth of the field is being monitored and clears the corresponding row of matrix EMODE.
 2. Next a loop is made through the heliostats in the appropriate one-eighth of the field. The mode of each heliostat is determined using submodule STSGET. If the heliostat is installed (mode returned by STSGET is positive), the mode number serves as an index to the columns of EMODE, and the contents of the appropriate row and column of EMODE is incremented by one. Additionally, STS stores the GRSTSG mode numbers in global array for use by the Graphics Module (GRAPHIC). After this loop is complete, this row of EMODE will contain the number of heliostats in each mode for the given one-eighth of the field.
 3. The time and date are output to the STATUS area of the CS console.
 4. After the above loop is complete, the one-eighth of field subtotals in EMODE are summed and compared to the total field sum for each mode and stored in MODEG. If any of the totals are different, the MODEG array is updated from the information in EMODE, and this information is formatted and transmitted to the CS console via the EXTINF module.

5. Next, global words ISTATG (set by MMI) are checked to see if there is a pending operator request for more status information. If so, submode STA is activated.

6. STS then exits.

e. Error messages and recovery - None

3.2.6.4.1.1.2 Data, Logic and Command Paths

Input data:

MODEG - MODEG is a 12-word array, each word containing the total number of heliostats in the corresponding mode (1 to 12). MODEG is updated by STS by calculating the new subtotals in EMODE and comparing; and

ISTATG - ISTATG is a three-word array, set by MMI to indicate a pending operator status request if ISTATG(1) is non-zero.

Output data:

GRSTSG - GRSTSG is a 2048-word array containing the mode number (1 to 12) of the corresponding heliostat. GRSTSG is updated by the corresponding one-eighth of the field.

3.2.6.4.1.1.3 Internal Data Description

EMODE - EMODE is an eight-by-twelve word array, the eight rows corresponding to each one-eighth of the field, and the 12 columns corresponding to the 12 possible modes. Each element contains the number of heliostats in a given one-eighth of the field in a given mode. This, EMODE (2,5) contains the number of heliostats in STOW (mode number five) in the second one-eighth of the field.

3.2.6.4.1.1.4 Flowchart

See Figure 3.2.6-7.

3.2.6.4.1.2 Submodule II - STSGET

3.2.6.4.1.2.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by STS
- c. Constraints and limitations - None

Figure 3.2.6-7 Flowchart - STS

d. Processing - STSGET decodes the global HC status words HCST1G and HCST2G to determine the mode of a given heliostat. See data base section 3.3.1 for a description of HCST1G and HCST2G.

1. Upon being called, STSGET checks the highest-order bit of HCST2G to determine if the heliostat is actually installed (if it is not installed, this bit is set). If this bit is set, the mode number is set to minus one.
2. If the HC is installed, the next three high-order bits of HCST2G are checked, indicating that the HC is set offline, in which case the mode number is returned as 12.
3. If the HC is installed and online, as indicated by HCST2G, HCST1G is logically ANDed with a mask (207C hex) to isolate bits 13 (position compare) and six through two (mode-submode). The result of the ANDing is checked against an array containing values which will match the result if the heliostat is in the mode which is the index to this array. See Table 3.2.6-II for the mapping from mode-submode in HCST1G to the reported mode.

If the result of the ANDing indicates that the mode-submode is "Seek Mark", another ANDing is made to determine if the "Mark Encountered" bits of HCST1G are set, in which case the mode is "Transition."

4. If the result of the ANDing(s) does not indicate a definite mode, the mode is set to "Transition."

e. Error messages and recovery - None.

3.2.6.4.1.2.2 Data, Logic and Command Paths

Input data:

HFCHC - the HFC-HC number (1 to 2148) whose mode is desired

HCST1G - HC status word

HCST2G - HC status word

Output data:

MODE - the resultant mode number (-1 or values from 1 to 12)

3.2.6.4.1.2.3 Internal Data Description

MASK - Value of 207C hex ANDed with HCST1G

MASKR - An array of values, whose index is the heliostat mode if the result of masking HCST1G is equal to one of the array elements.

MASKM - Value of C000 hex ANDed with HCST1G to determine "Mark Encountered."

3.2.6.4.1.2.4 Flowchart

See Figure 3.2.6-8

3.2.6.4.1.3 Submodule III - STA

3.2.6.4.1.3.1 Description

- a. Language used - FORTRAN
- b. How invoked - Activated by STS if there is a pending operator status request.
- c. Constraints and limitations - None
- d. Processing - Upon activation, STA checks the value of ISTATG(1) to determine which type of status request is pending, and calls one of the following subroutines as follows:

If ISTATG(1) = 1 thru 12, STAMOD is called to process a "MODE" status request.

If ISTATG(1) = 13, STAFID is called to process a "FIELD" status request.

If ISTATG(1) = 14, STAIND is called to process an "INDIVIDUAL" status request.

If ISTATG(1) = 15, STARNG is called to process a "RING-SEGMENT" status request.

- e. Error messages and recovery - None

3.2.6.4.1.3.2 Data, Logic and Command Paths

Input data:

ISTATG is used as described above.

3.2.6.4.1.3.3 Internal Data Description

STA has no pertinent internal data.

Figure 3.2.6-8 Flowchart - STSGET

3.2.6.4.1.3.4 Flowchart

See Figure 3.2.6-9.

3.2.6.4.1.4 Submodule IV - STAFLD

3.2.6.4.1.4.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by STA
- c. Constraints and limitations - None
- d. Processing - STAFLD formats global common words MODEG and the local time and date to process a field status request. See Table 3.2.6-III for the OCS and DAS message formats and Figure 3.2.6-2 for the CS console display.
- e. Error messages and recovery - None

3.2.6.4.1.4.2 Data, Logic, and Command Paths

Input data:

Global words MODEG.

3.2.6.4.1.4.3 Internal Data Description

STAFLD has an output buffer to store the output data in.

3.2.6.4.1.4.4 Flowchart

See Figure 3.2.6-10

3.2.6.4.1.5 Submodule V - STAIND

3.2.6.4.1.5.1 Description

- a. Language used - FORTRAN
- b. How invoked - called by STA
- c. Constraints and limitations - None
- d. Processing - STAIND calls STAGET to determine the mode and commanded mode of the desired heliostat and formats this data with the date and time (see Table 3.2.6-VI for the message format and Figure 3.2.6-3 for the display format).
- e. Error messages and recovery - None

Figure 3.2.6-9 Flowchart - STA

Figure 3.2.6-10 Flowchart - STAFLD

3.2.6.4.1.5.2 Data, Logic, and Command Paths

Input data:

ISTATG(2) - contains the desired heliostat number.

ISTATG(3) - contains code number for source of request.

Output data:

Enqueued to EXTINF.

3.2.6.4.1.5.3 Internal Data Description

STAINND has an output buffer.

3.2.6.4.1.5.4 Flowchart

See Figure 3.2.6-11

3.2.6.4.1.6 Submodule VI - STAMOD

3.2.6.4.1.6.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by STA
- c. Constraints and limitations - None
- d. Processing -
 1. Local time and date are obtained and local variables initialized.
 2. A loop is made through all the heliostats in the field; STAGET is called for each one to determine the mode, and each heliostat in the desired mode has its MDAC heliostat number (obtained via HC2MDG) loaded into the output buffer (see Table 3.2.6-V.) The output buffer is enqueued to the EXTINF module each time it is filled.
 3. When the loop through the heliostats is completed, the output buffer is sent if partially filled.
- e. Error messages and recovery - None

Figure 3.2.6-11 Flowchart - STAIND

3.2.6.4.1.6.2 Data, Logic, and Command Paths

Input data:

ISTATG(1) - contains the desired mode number

GTIMEG - contains local time and date

Output data:

Enqueued through EXTINF.

3.2.6.4.1.6.3 Internal Data Description

STAMOD contains an output buffer.

3.2.6.4.1.6.4 Flowchart

See Figure 3.2.6-12

3.2.6.4.1.7 Submodule VII - STARNG

3.2.6.4.1.7.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by STA
- c. Constraints and limitations - None
- d. Processing -
 1. STARNG uses global data SEGPTG and SEGMPG to obtain the heliostat numbers in the desired ring.
 2. A loop is made through these heliostat numbers, and the mode of these heliostats is determined by STAGET.
 3. If the mode is Track or Standby, the Track or Standby counter for this segment is incremented.
 4. After looping through all the heliostats in the ring, the response message (see Table 3.2.6-VI) is formatted from the data and enqueued to EXTINF.
- e. Error messages and recovery - None

3.2.6.4.1.7.2 Data, Logic, and Command Paths

Input data:

ISTATG(2) - Ring number.

Figure 3.2.6-12 Flowchart - STAMOD

ISTATG(3) - Code indicating source of request.

SEGPTG - Global array used to obtain HC numbers from ring number, in conjunction with SEGMPG.

SEGMPG - Global array used to obtain HC numbers, in conjunction with SEGPTG.

See the DBINIT write-up for a more complete description of SEGPTG and SEGMPG.

The indices of SEGPTG are obtained using the formula:

$$\text{INDEX}(1) = (\text{RING} - 1) * 12 + I$$

$$I = 1, 12$$

and the segment numbers obtained via

$$\text{SEG} * (I) = \text{RING} * 100 + I$$

$$I = 1, 12$$

Output data:

Enqueued to EXTINF

3.2.6.4.1.7.3 Internal Data Description

STARNG has two 12-word arrays to contain the number of helio-stats in Track and Standby in up to 12 segments in the desired ring.

3.2.6.4.1.7.4 Flowchart

See Figure 3.2.6-13

3.2.6.4.1.8 Submodule VIII - STAGET

3.2.6.4.1.8.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by STAIND, STAMOD, STAFLD, and STARNG.
- c. Constraints and limitations - None
- d. Processing - Processing is similar to that of STSGET with the exception that STAGET determines the command mode of a given HC if its actual mode is Transition.
- e. Error messages and recovery - None

Figure 3.2.6-13 Flowchart - STARNG

3.2.6.4.1.8.2 Data, Logic and Command Paths

Input data:

HFCHC - the HFC-HC number (1 to 2048) whose actual and commanded modes are desired.

HCST1G - HC status word.

HCST2G - HC status word.

Output data:

MODE - the resultant mode number (-1 or 1 to 12).

CMODE - the command mode if MODE is transition.

3.2.6.4.1.8.3 Internal Data Description

The internal data used by STAGET is the same as for STSGET, but with the addition of:

- a. MASKR - a mask used to find the commanded mode: isolates bits six through two of HCST1G (mode-submode only). MASKR = 007C Hex
- b. MASK - similar to MASKR but with the "position compare" bit position set. MASK = 207C Hex

3.2.6.4.1.8.4 Flowchart

See Figure 3.2.6-14

3.2.6.5 Interface Description

STS stores the number of HCs in each mode in global array MODEG and the mode number of each heliostat in global array GRSTSG for use by the graphics display. Communication between MANMIF and STATUS is accomplished via global array ISTATG.

3.2.6.6 Test Requirements

STSGET and STAGET should first be tested to make sure that they perform the correct mapping from the mode representations in HCST1G and HCST2G to the reported mode. The other modules basically format the data decoded by STSGET and STAGET, and the formatted data can be checked by dumping the ASCII message buffer.

Figure 3.2.6-14 Flowchart - STAGET

3.2.7 Data Base Initialization Module - DBINIT

3.2.7.1 Purpose

The purpose of the Data Base Initialization Module (DBINIT) is to initialize the global data base, as well as the disk-resident data base. Additionally, DBINIT initializes the operator's CRT console, graphics console, backup system and system interfaces, and provides initialization and synchronization of the universal and local system time base. Upon establishment of the time base reference, the timekeeping task is established and activated which, through subsequent action, will establish and activate the various tasks which are components of the heliostat system.

3.2.7.2 Requirements

3.2.7.2.1 Design Requirements

Software Requirements listed in Section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980, that apply to the DBINIT module are:

- a. Detect, report, and respond to failures and irregularities;
- b. Maintain a "Prime" and "Backup" system, as well as redundant field communications;
- c. Maintain a stable time base;
- d. Provide graphic displays of the heliostat field or field segments; and
- e. Provide a stable time base utilizing the WWV Trutime input for the "Prime" HAC time and internal time for the "Backup" HAC time. When "Backup" HAC becomes "Prime," the WWV time will automatically be used, if available.

3.2.7.2.2 Derived Requirements

Section 3.2.1.7 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980, states the following requirements for the Data Base Initialization task:

- a. Define the global-common area, accessible to all applications tasks;
- b. Provide an initialization task to initialize the values in the global data base;
- c. Build appropriate data-base files for alarm messages, HC initialization coordinates, HC biases, control group mapping, BCS targets, Stow positions, Wash positions,

corridor coordinates, initialization azimuth and elevation positions, and multiple aim-points;

- d. Read WWV time values from the WWV device, if it is present and operating; and activate the "clock" task to perform time-base maintenance; and
- e. Initiate task execution sequences to the operating system, and allow for specification of "Prime" or "Backup" computer; and if "Prime" computer, make data available for transfer to "Backup," and if "Backup" computer, accept data from "Prime."

Additional derived requirements for DBINIT are:

- a. Perform reasonableness checking of the card-image source data before storing it onto the disk data base;
- b. Write error messages on the operator's console with respect to source data errors; and
- c. Provide a hard-copy listing (offline) of the card-image source upon operator request.

3.2.7.3

Design Approach

The design of the Data Base Initialization Module (DBINIT) is accomplished with a top-down functional allocation approach. This top-down approach facilitates both module and submodule development, implementation, and testing. Figure 3.2.7-1 exhibits the hierarchical allocation of the DBINIT required functions. Figure 3.2.7-1 shows that DBINIT is decomposed into three functional areas. The design structure of each functional area is shown in Figures 3.2.7-2 through 3.2.7-6. This design approach allows for maximum flexibility in requirement fulfillment and software maintainability.

The disk-resident data base is initialized with the offline task DIN utilizing Phase I developed software as much as possible. The card-image data source is error checked and converted from ASCII to internal binary representation and stored on its appropriate file. In total, there are 6 disk files created and filled offline. These files are the HC coordinates, the Wash angles, Stow angles, Alternate 1 Stow angles, the Alternate 2 Stow elevation angle, and the aim-point arrays. The file structures format and types are exhibited in Section 3.3.1. This offline initialization of the above files supports system flexibility, resource management, and timeliness of the initialization process. System flexibility is enhanced by the offline feature which allows the files to be updated in a batch or background process. Resource management of the disk space is improved by not storing the card-image source on the disk, and initialization timeliness is improved by eliminating operator handling of card decks and/or magnetic tapes during real-time initialization.

Figure 3.2.7-1 Hierarchy Diagram of the Data Base Initialization Module (DBINIT)

Figure 3.2.7-2 Functional Diagram of the Disk Initialization Task

Figure 3.2.7-3 Functional Allocation of the HAC Initialization Task

Figure 3.2.7-4 Functional Diagram of the System Interface Initialization Submodule

Figure 3.2.7-5 Functional Diagram of the Data Initialization Control Submodule

Figure 3.2.7-6 Functional Diagram of the HAC Start-up Task

The in-core data base and peripheral initialization is performed by a prescheduled task (DBI) which is activated at system boot via Sysgen. This initial task (DBI) performs the data initialization required then activates a second task (CLK) to initialize the real-time operations tasks. This design feature releases main memory storage required for DBI for establishment of the real-time operations tasks in core.

3.2.7.3.1

Functional Allocations

The offline disk data base initialization task (DIN) consists of ten submodules and utilizes one submodule from the DBI task. The functional allocation of the submodules is shown in Figure 3.2.7-2. A brief description of each submodule follows:

- a. DIN - performs overall control of operator interfacing and processing of the card-image source data for the Heliostat assignments and locations, heliostat Wash and Stow positions, Alternate 1 and Alternate 2 Stow positions, heliostat aim points, BCS target coordinates, and the corridor definition coordinates. The format of these card-image source data are shown in Tables 3.2.7-I through 3.2.7-VI. This submodule presents a menu for operator selection to input the source data and whether a source listing is desired.
- b. DINLOC - processes source data from card-image types 1, 4, 5, and 6 (Tables 3.2.7-I, 3.2.7-IV, 3.2.7-V, and 3.2.7-VI). This submodule verifies the format, limit checks the values, performs coordinate transformation and data packing, inclusion area processing, data base structuring, and disk storage. As each card-image is processed, the card type is compared against the operator-requested data type for error processing. The values of the source data are processed in comparison to the values exhibited in Tables 3.2.7-I, 3.2.7-IV, 3.2.7-V, and 3.2.7-VI. If during the processing of an input source record an error is encountered, the error handling procedure shown in Table 3.2.7-VII is followed, and the source record is listed on the hard-copy device.
- c. DINTRF - performs the coordinate transformation from the California Lambert grid system to the right-handed orthogonal site reference system. Additionally, the X, Y, and Z transformed values are scaled and packed into 24-bit words. Both the transformed and packed values are returned to the calling submodule.
- d. DINSRT - is a sorting algorithm which sorts a subject array in ascending order. The subject array is not disturbed during the sorting procedure, but rather an array of pointers is established that point to the subject array in an ordered manner.

Table 3.2.7-I Data Base Card Format

Card Type 1 - Heliostat Assignments and Locations						
X-Y-Z Coordinates in Lambert California Grid System with Units of Feet						
CT XX	HC XXXX	HFC	X-COORD. XX ±XXXX.XX	Y-COORD. ±XXXX.XX	Z-COORD. XXXX.XX	SEG P B W XXX XX X X
						GEN.TIME XXXXXXXX
Card columns	Format	Description				Units
1 - 2	Integer	Card type designation, 01 for HAA cards.				N.D.
6 - 9	Integer	Heliostat identification number (HC). (row 1-29, position 1-99)				N.D.
12 - 13	Integer	Identification number of heliostat field controller assigned to HC (1-64)				N.D.
15 - 22	F.P.	HC X-coordinate. X is positive north. Zero value is at receiver tower vertical center line. (0 to +/- 1400)				Feet
24 - 31	F.P.	HC Y-coordinate. Y is positive east. Zero value is at receiver tower vertical center line. (0 to +/- 1400)				Feet
33 - 39	F.P.	HC Z-coordinate. Z is positive up. Zero value is at 1849 feet above mean sea level. (0 to + 500)				Feet
42 - 44	Integer	Segment number. First integer designates ring number, second two integers designate the wedge number. (ring 1 to 5, wedge 1 to 12)				N.D.
46 - 47	Integer	Pecking order number assigned to HC (1 - 50)				N.D.
49	Integer	BCS target number assigned to HC (1 - 4)				N.D.
51	Alpha	Corridor-walk letter assigned to HC (A - H)				N.D.
73 - 80	Integer	Generation time of this card.				N.D.
73 - 74	Integer	Month (01 - 12)				N.D.
75 - 76	Integer	Day (01 - 31)				N.D.
77 - 78	Integer	Year of 20th century (79 - 99)				N.D.
79 - 80	Integer	Hour on 24-hour clock. 13 hour at 1 PM. (00 - 23)				N.D.

Table 3.2.7-II Data Base Card Formats

Card type 2 - Heliostat Wash and Stow Positions

CT	HC	WASH		STOW		GEN.TIME
		AZ	EL	AZ	EL	
XX	XXXX	+XXX.XXX	+XXX.XXX	+XXX.XXX	+XXX.XXX	XXXXXXXX

Punched card format description for heliostat wash and stow positions cards

Card Columns	Format	Description	Units
1 - 2	Integer	Card type designation, (02)	N.D.
6 - 9	Integer	Heliostat identification number (row 1 - 29; position 1 - 99)	N.D.
16 - 23	F.P.	Azimuth angle (AZ). AZ is zero east and positive counter-clockwise. AZ specified 0 to +/- 180	Degrees
25 - 32	F.P.	Elevation angle (EL). EL is zero when mirror is vertical and positive with glass up. (0 to +/- 180).	Degrees
39 - 46	F.P.	Azimuth angle. (0 to +/- 180)	Degrees
48 - 55	F.P.	Elevation angle. (0 to +/- 180)	Degrees
73 - 80	Integer	Generation time of this card.	N.D.
73 - 74	Integer	Month (01 - 12)	N.D.
75 - 76	Integer	Day (01 - 31)	N.D.
77 - 78	Integer	Year of 20th century (79 - 99)	N.D.
79 - 80	Integer	Hour on 24-hour clock. 13th hour is 1 PM. (00 - 23)	N.D.

Table 3.2.7-III Data Base Card Format

Card Type 3 - Stow - Alternate 1 and 2 Positions

CT	HC	Stow - Alt 1		Stow - Alt 2		GEN.TIME
XX	XXXX	AZ	EL	AZ	EL	XXXXXXXX
		±XXX.XXX	±XXX.XXX	±XXX.XXX	±XXX.XXX	

Punched card format description for heliostat alternate positions cards.

Card Columns	Format	Description	Units
1 - 2	Integer	Card type designation, (03)	N.D.
6 - 9	Integer	Heliostat identification number (row 1 - 29; position 1 - 99)	N.D.
16 - 23	F.P.	Azimuth angle (AZ). AZ is zero east and positive counter-clockwise. AZ specified 0 to +/- 180.	Degrees
25 - 32	F.P.	Elevation angle (EL). EL is zero when mirror is vertical and positive with glass up. (0 to +/- 180)	Degrees
39 - 46	F.P.	Azimuth angle. (0 to +/- 180)	Degrees
48 - 55	F.P.	Elevation angle. (0 to +/- 180)	Degrees
73 - 80	Integer	Generation time of this card.	N.D.
73 - 74	Integer	Month (01 - 12)	N.D.
75 - 76	Integer	Day (01 - 31)	N.D.
77 - 78	Integer	Year of 20th century (79 - 99)	N.D.
79 - 80	Integer	Hour on 24-hour clock. 13th hour at 1 PM. (00 - 23)	N.D.

Table 3.2.7-IV Data Base Card Formats

Card type 4 - Heliostat Aim Points

CT XX	HC XXXX	AIM PT XX	LOCATIONS (FEET)			AIM POINT IDENTIFIER XXXXXXXXXXXXXXXXXXXXXXXXXXXX	GEN.TIME XXXXXXX
Card Columns	Format		X-COORD ±XXXX.XX	Y-COORD ±XXXX.XX	Z-COORD XXXX.XX	Descriptions	Units
1 - 2	Integer		Card type designation, 04 for HAP cards.				N.D.
6 - 9	Integer		Heliostat identification number (HC) (row 1 - 29; position 1 - 99)				N.D.
12 - 13	Integer		Aim Point number (1 - 20)				N.D.
15 - 22	F.P.		HC X-coordinate. X is positive north. Zero value is at receiver tower vertical center line.				Feet
24 - 31	F.P.		HC Y-coordinate. Y is positive east. Zero value is at receiver tower vertical center line.				Feet
33 - 39	F.P.		HC Z-coordinate. Z is positive up. Zero value is at 1849 feet above mean sea level.				Feet
44 - 70	Alpha- Num		Aim point identifier. Indicates time of year for which aim points were generated and generation data.				N.D.
73 - 80	Integer		Generation time of this card				N.D.
73 - 74	Integer		Month (01 - 12)				N.D.
75 - 76	Integer		Day (01 - 31)				N.D.
77 - 78	Integer		Year of 20th century. (79 - 99)				N.D.
79 - 80	Integer		Hour on 24-hour clock. 13th hour at 1 PM. (00 - 23)				N.D.

Table 3.2.7-V Data Base Card Format

Card Type 5 - BCS Target Coordinates

CT xx	BCS NUM x	LOCATION (feet)		
		X-COORD. +xxxx.xx	Y-COORD. +xxxx.xx	Z-COORD. xxxx.xx
Card Columns	Format	Description		Units
1-2	Integer	Card type designation, 05 for BCS targets		N.D.
9	Integer	BCS target number (1 to 4)		N.D.
15-22	F.P.	BCS target X coordinate. X is positive north. Zero value is at receiver tower vertical center line. (0 to +/- 30)		Feet
24-31	F.P.	BCS target Y coordinate. Y is positive east. Zero value is at receiver tower vertical center line. (0 to +/- 30)		Feet
33-39	F.P.	BCS target Z coordinate. Z is positive up. Zero Zero value is at 1849 feet above mean sea level. (0 to +300)		Feet

Table 3.2.7-VI Data Base Card Format

Card Type 6 - Corridor Coordinates

CT W		CORRIDOR BOTTOM			CORRIDOR TOP			CORRIDOR INCREMENTS		
XX	X	+XXXX.XX	+XXXX.XX	XXXX.XX	+XXXX.XX	+XXXX.XX	XXXX.XX	+X.XXX	+X.XXX	X.XXX
Card Columns	Format	Description								Units
1 - 2	Integer	Card type designation, 06 for corridor coordinates								N.D.
5	Alpha	Corridor number (A to H)								N.D.
8 - 15	F.P.	Corridor bottom X-coordinate. X is positive north. Zero value is at receiver tower vertical center line (0 to +800)								Feet
17 - 24	F.P.	Corridor bottom Y-coordinate. Y is positive east. Zero is at receiver tower vertical center line. (0 to +/- 800)								Feet
26 - 32	F.P.	Corridor bottom Z-coordinate. Z is positive up. Zero value is at 1849 feet above mean sea level (0 to +100)								Feet
35 - 42	F.P.	Corridor top X-coordinate (defined as above).								Feet
44 - 51	F.P.	Corridor top Y-coordinate (defined as above).								Feet
53 - 59	F.P.	Corridor top Z-coordinate (defined as above).								Feet
62 - 67	F.P.	Corridor X-increment (0 to +/- 9.999)								Feet
69 - 74	F.P.	Corridor Y-increment (0 to +/- 9.999)								Feet
76 - 80	F.P.	Corridor Z-increment (0 to +/- 9.999)								Feet

SOURCE DATA ERROR HANDLING PROCEDURE

SOURCE DATA	DEFAULT SUPPLIED		ACTION	
	YES	NO	REJECT RECORD	REJECT FILE
Card type designator		X	X	
Heliostat number		X	X	
HFC assignment		X	X	
Heliostat Coordinates		X	X	
Pecking order assignment		X	X	
BCS target assignment		X	X	
Corridor assignment		X	X	
Wash Angles	X			
Alt 1 Stow angles	X			
Alt 2 Stow angles	X			
Aim-point number		X	X	X
Aim-point coordinates		X	X	X

Table 3.2.7-VII Source Data Error Handling Procedure .

- e. DINITL - outputs descriptive titles to the hard-copy device when source data listings are requested. This submodule ejects a page, prints the requested title, and returns a variable containing the number of lines required to print the title.
- f. DINANG - processes source data from card-image source types 2 and 3 (Tables 3.2.7-II and 3.2.7-III). This submodule verifies the format, limit checks the values, and performs data scaling and packing, data base structuring, and disk storage. As each card image is processed, the card type is compared against the operator-requested data type for error processing. The source data values are processed in comparison to the values exhibited in Tables 3.2.7-II and 3.2.7-III. If during the processing of an input source record an error is encountered, the error-handling procedure shown in Table 3.2.7-VII is followed, and the source record is listed on the hard-copy device.
- g. DINPAC - scales and packs the azimuth and elevation angles into 16-bit integer words.
- h. DINFLG - indicates to the operator the occurrence of errors in source data. This submodule receives an array of flags corresponding to source data columns and a count of the errors. If the error count is zero, no output occurs; otherwise an 80-character buffer is filled with ASCII characters such that blank corresponds to no error in the column or dollar sign (\$) corresponds to an error in the column. As the buffer is filled, the input indicator array is cleared. After the buffer is filled, it is output to the device indicated via an input parameter.
- i. DINGRF - initializes the graphic processors with the heliostat field locations. The locations are sent to the graphics in the format shown in Table 3.2.10-VIII. The heliostat locations are sent twice, first sorted by HFC-HC number and then sorted by segment number, sub-sorted by pecking order. Execution of this submodule requires the concurrent execution of an initializing program in the graphics processors.

The Data Base Initialization (DBI) task is composed of twelve sub-modules, which execute automatically upon operating system start-up. The basic purpose of each submodule is briefly described below:

- a. DBI - is a task that performs overall control of the initial operator and system interfacing, in-core data initialization, disk-resident data verification, and activation of the timing task (CLK) for start-up of the HAC operations tasks.

- b. DBIFAC - functions as a controlling submodule for five submodules. This submodule controls the process of initializing the operator's console, the graphics consoles, system peripheral configuration and receiver trip, and operator notification of errors encountered.
- c. DBICRT - functions as a submodule of DBIFAC. DBICRT requests from the operator a designation of either "Prime" or "Backup." When "Prime" is input, the PCIs are configured to attach the peripherals, and the operator is prompted to designate whether there is a backup or not. The DBICRT clears the color terminal, selects color schemes, subdivides the console screen, and sets up screen protection boundaries. DBICRT notifies the operator that DBINIT is activated with the message:

"DATA BASE INITIALIZATION"

- d. DBIGRF - functions as a submodule of DBIFAC. DBIGRF functions to initialize the Chromatics 1999 Intelligent Terminals. Both graphics terminals are configured to display the entire heliostat field in the color representing heliostat field offline status. If only one graphics terminal is available, the display options only are listed.
- e. DBITRP - functions as a submodule of DBIFAC. The receiver trip initialization submodule connects the interrupt levels to the handlers, enables the interrupts, checks for proper state initialization and reports trip status.
- f. DBIDTA - functions as a submodule of DBI. DBIDTA functions as a controlling submodule for six submodules. It controls the calling of submodules in performing disk verification, global common initialization, bias and aim-point array initialization, data transfer for "Prime-Backup" configuration, and operator interface for initialization and error processing.
- g. DBIDSK - functions as a submodule of DBIDTA. DBIDSK reads the disk-resident data base verifying the existence of the disk-resident data files and performs limit checking of the stored values. The data files read and limit checked are: HC coordinates, Stow angles, Alternate 1 Stow angles, Alternate 2 Stow elevation angle, and Wash angles. An error code is returned to the calling module for processing.
- h. DBICOR - functions as a submodule of DBIDTA. DBICOR initializes the global common data base for intertask coordination and communications. Section 3.3.1 displays the data words and arrays that comprise the global common data base. The data words and arrays are described in Section 3.3.1.4 (Global Common Data Base) as: Variable

Name; Size; Initial value; Description; All Modules (Tasks) that set; All Modules (Tasks) that use; Location; Transfer Frequency; and Format. DBICOR initializes these data to the initial values specified under the Initial Value descriptor. The global common data base is structured into three types of data: 1) data that is transferred to the "Backup" only at initialization; 2) data that is transferred every second; and 3) data that is transferred every eight seconds. Error monitoring is performed on all initialization which requires access to disk-resident initial values. An error code is returned to the calling module for operator notification and processing.

- i. DBIAIM - functions as a submodule of DBIDTA. DBIAIM verifies the disk-resident aim-point files through inclusion area processing, and when an aim-point disk file is verified, its file name is flagged in global common for use by the Man-Machine Interface task for UPAIM processing. After the 20 files are processed and properly flagged, the flagged file with the lowest cardinal number designator is copied into the global common data base for real-time HAC tasks. An error code is returned from this submodule to its calling module for processing.
- j. DBIBCK - functions as a submodule of DBIDTA. DBIBCK initializes the "Backup" HAC computer. All the global common data base and disk-resident data base files are copied from the "Prime" to the "Backup" computer. The word in global common indicating the computer tag ("Prime" or "Backup") requires special handling in that the two global common data bases must contain the opposite configuration.
- k. DBIERR - functions as a submodule of DBIDTA, DBIFAC, and the tasks DIN and CLK. DBIERR processes error codes and produces error messages for the operator. DBIERR processes an error code which is classified into three types: 1) no error; 2) non-fatal informative errors; and 3) fatal errors. An error code of zero results in no error; error codes in the range 1 to 20 are non-fatal errors; while error codes in the range 21 to 40 are fatal errors. Whenever a disk file can not be accessed, or a task can not be established or activated, the condition is considered fatal and the DBINIT module will abort. This submodule writes the error message to the device(s) indicated through an input parameter(s).

The task CLK is composed of four submodules which are activated by the DBI task after DBI has completed its processing. The basic purpose of each submodule is briefly described below:

- a. CLK - is a task that controls start-up of the real-time HAC operations. CLK is defined as a one-shot task, activated by DBI. CLK controls the calling of four submodules which establish the real-time HAC tasks as resident in main memory, activate the TOK task, and activate the other real-time HAC operations tasks for field control. Any errors detected during this process are reported via the error processing submodule DBIERR.
- b. CLKEST - functions as a submodule of CLK. CLKEST establishes the HAC real-time tasks as main memory resident. The task three-character name is converted to "can" code for the REX, Establish service. Once the "can" codes are generated, the REX, Establish service #27 is utilized to process through the list of names. The condition code is monitored after each REX service for error detection, and reported via an error code returned to the calling module, CLK.
- c. CLKONL - functions as a submodule of CLK. CLKONL coordinates the starting of the HAC timing frame with the WWV device and the operator. When the WWV device is active, it is used as the primary timing device, but when WWV time is not available, this submodule accepts an initial time from the operator. When the operator initializes the time manually, the input must be coordinated with real time to within $\pm$ TBD seconds for sun tracking accuracy. An error code is returned to the calling module for processing.
- d. CLKACT - functions as a submodule of CLK. CLKACT activates the HAC real-time tasks. The tasks previously established (CLKEST) are activated with a REX service #16. The condition code is checked for errors and an error code is returned to the calling module through the parameter list. If CLKACT is executing in the prime HAC it will also activate the SWI task in the backup HAC.

3.2.7.3.2

Resource Budgets

- a. Memory requirements (estimated)

1. DIN - 10K words
2. DBI - 15K words
3. CLK - 5K words

b. Timing - there are no timing constraints for DBINIT

c. Priority

1. DIN - Batch overlay
2. DBI - x-5
3. CLK - x

d. Global common and disk file usage

1. Global common described in Section 3.3.1
2. Disk file structure and format in Section 3.3.1

3.2.7.4 Design Description

3.2.7.4.1 Module Structure

DBINIT is composed of three tasks DIN, DBI, and CLK. The task DIN initializes the disk data base, DBI initializes the in-core global common data base and system configuration, and CLK establishes and activates the real-time HAC tasks for system operation. Each of these tasks, at the submodule level, is described below.

3.2.7.4.1.1 Submodule I - Task DIN

3.2.7.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - Offline task activation by an operator.
- c. Constraints and limitations - The heliostat locations (card Type 1) must be processed before the graphics processors can be initialized. Heliostat locations (card Type 1) define a heliostat as being installed. Aim-point arrays must be separated in the input process by end-of-file marks. Errors found in processing an aim-point array cause the file to be rejected. Partial updates of the heliostat locations, Wash and Stow angles, and Alternate 1 and Alternate 2 Stow angles are accepted under operator direction. Aim-point array storage on the disk is performed in totality; all undefined aim points are stored as zeros (not defined).
- d. Processing -
 1. Define the disk files for usage by this task.
 2. Write the operator's options for input type to system console:

OPTION	SELECT ONE DATA TYPE FOR INPUT
1	INPUT HELIOSTAT LOCATIONS
2	INPUT WASH AND STOW ANGLES
3	INPUT ALT1 AND ALT2 STOW ANGLES
4	INPUT AIM-POINT ARRAY
5	INPUT BCS TARGET LOCATIONS
6	INPUT CORRIDOR LOCATIONS
7	INPUT HELIOSTAT BIAS
8	INPUT ALARMS MESSAGES
9	INITIALIZE GRAPHICS WITH HC LOCATIONS
T	TERMINATE TASK

3. Request the operator's response:

ENTER OPTION FROM ABOVE LIST:

Read the operator's response.

4. Test if the response is valid. If it is, go to step (5); if not, go to step (3).
5. Test if the terminate task option was selected. If it was, EXIT the task; if not, go to step (6).
6. Test if the selected option requires input source data. If it does, go to step (7); otherwise, go to step (19).
7. Write operator's options for a full or partial update:

OPTION

1	PARTIAL UPDATE (HC LOCATIONS, WASH, STOW, ALT1, ALT2)
2.	FULL UPDATE
T	TERMINATE TASK

8. Request operator's response::

ENTER OPTION FROM ABOVE LIST:

Read the operator's response.

9. Test if the response is valid. If it is, go to step (10); otherwise go to step (8).
10. Test if the terminate task option was selected. If it was, EXIT the task; if not, go to step (11).
11. Write operator's options for source device:

OPTION SOURCE INPUT DEVICE

1	MAG TAPE
2	CARD READER
T	TERMINATE TASK

12. Request operator's response:

ENTER OPTION FROM ABOVE LIST:

Read the operator's response.

13. Test if the response is valid. If it is, go to step (14); otherwise, go to step (12).
14. Test if the terminate task option was selected. If it was, EXIT the task; if not, go to step (15).
15. Write the operator's options for requesting a source listing:

OPTION SOURCE LISTING

0	NO
1	YES
T	TERMINATE TASK

16. Request operator's response:

ENTER OPTION FROM ABOVE LIST:

Read the operator's response.

17. Test if the response is valid. If it is, go to step (18); otherwise, go to step (16).
18. Test if the terminate task option was selected. If it was, EXIT the task; if not, request from the operator if the source is ready for input:

OPTION IS SOURCE READY FOR INPUT

C	CONTINUE
T	TERMINATE

ENTER OPTION FROM ABOVE LIST:

Read the response and check it for validity. Continue requesting response until a valid entry is made by the operator. When a valid response is received, test if it is the terminate option. If it is, EXIT the task; if not, go to step (19).

19. Branch on the source type selected. If source Type 1, 4, 5 or 6 was selected, go to step (20). If source Type 2 or 3 was selected, go to step (43). If source Type 7 was selected, go to step (62). If source type 8 was selected, go to step (63); and finally if source Type 9 was selected, go to step (50).
20. Zero local common and then test if source Type 1 was selected. If it was, zero out the segment pointer and segment map arrays and go to step (21); otherwise, go to step (24).
21. Test if a full or partial update is being performed on the heliostat locations. If a full update is being performed, go to step (24). If a partial update is being performed, go to step (22).
22. Read the presently defined heliostat locations from the disk and store in local common. Read the heliostats' segment numbers and pecking-order numbers and store in local common.
23. Test if a disk read error occurred. If it did, notify the operator and transfer to step (2); otherwise, go to step (24).
24. Call subroutine DINLOC to process source Type 1, 4, 5 or 6.
25. Test the flag returned by DINLOC to determine if any source was accepted. If the test is true, go to step (26); otherwise, notify the operator all source was rejected and transfer to step (2).
26. Test if source Type 1 is being processed. If it is, go to step (27); otherwise, to to step (36).
27. Initialize the sorting-pointer array to the element numbers that contain segment numbers in local common.
28. Call the subroutine DINSRT to sort the heliostat locations subject to the segment number and relative to the sorting pointer.
29. Determine the number of heliostats in a segment.

30. Store the negative of the number of heliostats in a segment in the segment-mapping array, and store the address of this negative number into the segment-pointer array.
31. Call the subroutine DINSRT to sort the heliostats in the segment into pecking order relative to the sorting pointer.
32. Store the HFC-HC heliostat numbers into the segment-map array immediately after the negative of the number of HCs in the segment.
33. Test if all the segments have been processed. If they have, go to step (34); otherwise, go to step (29).
34. Write the local common arrays containing the X, Y, and Z coordinates and corridor and BCS assignments to the disk.
 - a) Write the MDAC number to HFC-HC number mapping array (MD2HCG) to disk (determined a-priori);
 - b) Write the MDAC number per row array (MDNPRG) to disk (determined a-priori);
 - c) Write the HFC-HC number to MDAC number mapping array (HC2MDG) to disk (determined a-priori);
 - d) Write the segment mapping array (SEGMPG) to disk;
 - e) Write the segment pointer array (SEGPTG) to disk; and
 - f) Write the packed segment numbers and pecking-order numbers to disk.
35. Test if any disk write errors occurred. If they did, notify the operator not to use the disk for initialization, and in either case go to step (2).
36. Test if source Type 4 (aim points) is being processed. If it is, go to step (37); otherwise, go to step (41).
37. Check if all the aim-point numbers in local common are the same. If they are, go to step (38); otherwise, notify the operator the file is rejected and go to step (2).

38. Read one aim-point record from the disk, insert the present aim point into the record relative to the aim-point number and write the record back to disk.
39. Test if a disk read or write error occurred. If it did, notify the operator and go to step (2); otherwise, go to step (40).
40. Test if all the aim-point records have been updated. If they have not go to step (38); otherwise, go to step (2).
41. Test if source Type 5 (BCS target coordinates) is being processed. If it is, write the BCS coordinates in local common to the disk. Otherwise, write the corridor coordinates in local common to the disk.
42. Test if a disk write error occurred. If it did, notify the operator, and in either case go to step (2).
43. Test if a full or partial update was requested. If a full update was requested, zero local common and go to step (46). If a partial update was requested, go to step (44).
44. Test if source Type 2 is being processed. If it is, read the disk to obtain the Wash and Stow angles presently stored and store them into local common. Otherwise, read the Alternate 1 and Alternate 2 Stow angles and store them into local common.
45. If a disk read error occurred, notify the operator and go to step (2); otherwise, go to step (46).
46. Call the subroutine DINANG to process either source Type 2 or 3.
47. Test if any source records were accepted by DINANG. If no records were accepted, notify the operator and go to step (2); otherwise, go to step (48).
48. Test if processing source Type 2. If it is, write the values in local common to the Wash and Stow files on the disk; otherwise, write the values in local common to the Alternate 1 and Alternate 2 Stow files on disk.

49. If a disk write error occurs, notify the operator, and in either case go to step (2).
50. Read the segment map (SEGMPG) and segment pointer (SEGPTG) arrays from disk and store into local common.
51. Read the HC locations from disk and store into local common.
52. If a disk read error occurs, notify the operator and go to step (2); otherwise, go to step (53).
53. Request from the operator which graphics processor to initialize with heliostat locations.

OPTION INITIALIZE

- 1 CS CONTROL ROOM GRAPHICS
- 2 ENGINEERING ROOM GRAPHICS

ENTER OPTION FROM ABOVE LIST:

Read the response and check for validity.
If valid, go to next step; otherwise, request entry again.

54. Request from the operator if the graphics processor is ready to receive data.

OPTION GRAPHICS READY TO RECEIVE

- C CONTINUE
- T TERMINATE

ENTER OPTION FROM ABOVE LIST:

Read the operator's response and check it for validity. Continue requesting an entry until a valid response is made.

55. If a terminate is requested, EXIT the task; otherwise, go to step (56).
56. Construct the graphics initialization message from the non-zero heliostat locations in local common.
57. Send the graphics message under a command/response protocol.
58. Test if the full field of heliostat locations have been sent. If not, go to step (56); otherwise, go to step (59).

59. Send an end-of-file message to the graphics processor under a command/response protocol.
60. Send a heliostat location initialization message relative to a segment pecking-order scheme.
61. Test if all segments are sent. If they are, send an end-of-file message and go to step (2); otherwise, go to step (60).
62. Bias disk file processing; at completion go to step (2).
63. Alarm messages processing to disk; at completion go to step (2).

e. Error messages and recovery - Error messages:

1. DISK WRITE OR READ ERROR
2. DISK DATA BASE INVALID DO NOT USE
3. SOURCE FILE REJECTED
4. NO SOURCE RECORDS ACCEPTED

Error recovery returns control to operator to take action.

3.2.7.4.1.1.2 Data, Logic and Command Paths

Input data:

- a. Operator inputs via the system console;
- b. Source data; and
- c. Disk stored data.

Output data:

- a. Source listings; and
- b. Source data stored on disk.

Algorithms:

Three arrays (Figure 3.2.7-7) are internally created to convert from the MDAC numbering system to the HFC-HC numbering system and vice-versa. The arrays MD2HCG and MDNPRG are used to map from the MDAC number to the HFC-HC number. The MDAC number is composed of two parts: the row number and row-position number. The row number is used to enter the MDNPRG array and get the subtotal of all HCs in the

Figure 3.2.7-7 HC Numbering Scheme Mappings

lower number of rows. This is used as a base to which the row-position number is added for entry into the MD2HCG array. The MD2HCG array contains the HFC-HC number corresponding to the MDAC number. Error checking of the MDAC number is performed by comparing the entry number against contents of the next highest row number of the MDNPRG array. If the entry number is greater, then the MDAC number is invalid. The length of the MD2HCG array is 2048 elements, and the length of the MDNPRG is 30 elements where element one is zero and element 30 the total of all heliostats (i.e., 1818). The third array is the HC2MDG array and is used to map from the HFC-HC number to the MDAC number. The entry number (element index) is the HFC-HC number. The contents of the element is the MDAC number. Elements that have a value of zero are invalid HFC-HC numbers. The length of HC2MDG is 2048 elements.

When the heliostat locations are input, two arrays are created to map the segment numbers into groups of heliostat numbers. These two arrays (Figure 3.2.7-8) are the segment-mapping array (SEGMPC) and the segment-pointer array. The segment-pointer array contains pointers to the segment-mapping array; where the number of heliostats in that segment are stored (negative value) followed by the heliostat numbers of the heliostats in that segment in pecking order. If a zero value is found in the segment-pointer array, it means that there are no heliostats assigned to that segment number. The segment number is decomposed into its component parts of ring number and wedge number to index into the elements of the segment-pointer array. The value one is subtracted from the ring number, and the results are then multiplied by 12. The the wedge number is added. This results in an index number from 1 to 60 (5 rings - 12 wedges).

3.2.7.4.1.1.3 Internal Data Description

a. Internal common areas - DINCOM:

1. 7 arrays of 2048 I*2 words used to process source data to disk files and vice-versa
2. 9 arrays of 8 I*2 words
3. HC2MDG array 2048 I*2 words
4. MD2HCG array 2048 I*2 words
5. MDNPRG array 30 I*2 words

b. Disk file DIN layout:

1. Random access file DIN; record size 128 words.

Figure 3.2.7-8 Segment Map and Segment Pointer Interaction

2. Records 1-16 contain the MDAC to HFC-HC number mapping MD2HCG array (2048 words).
3. Record 17 contains the MDAC number per row MDNPRG array (30 words - word 0 to word 29) and the segment-pointer array SEGPTG (60 words - word 50 to word 109).
4. Records 18-33 contain the HFC-HC to MDAC number mapping array HC2MDG (2048 words).
5. Records 34-50 contain the segment-mapping array SEGMPG (2108 words - Record 50 has the first 60 words used).
6. Record 50 (words 70 to word 93) contains the BCS target locations.
7. Record 51 contains the corridor locations (128 words).
8. Records 52-67 contain the HC segment number and pecking-order number packed together (2048 words).

3.2.7.4.1.1.4 Flowchart

See Figure 3.2.7-9 for DIN flowchart.

3.2.7.4.1.2 Submodule II - DINLOC

3.2.7.4.1.2.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DIN task
- c. Constraints and limitations - Records read from the source must contain an end-of-file indication at the conclusion of the file. Source input records cannot be duplicated. Card-image source types should not be intermixed. Aim-point arrays must be processed one at a time.
- d. Processing -
 1. Initialize:
 - a) End-of-file flag false
 - b) Read error counter to zero
 - c) Number of lines printed to zero
 - d) Number of records accepted to zero

Figure 3.2.7-9 Flowchart - DIN

Figure 3.2.7-9 Flowchart - DIN (continued)

Figure 3.2.7-9 Flowchart - DIN (continued)

Figure 3.2.7-9 Flowchart - DIN (continued)

Figure 3.2.7-9 Flowchart - DIN (continued)

Figure 3.2.7-9 Flowchart - DIN (continued)

- e) Number of records read to zero
 - f) Data accepted flag false
 - g) Reject file flag false
2. Branch on the source type being processed. Set the appropriate syntax masks for checking the source data types. Set the limit check values for the appropriate source data type.
 3. Initialize:
 - a) Error code to zero
 - b) Number of errors to zero
 - c) Column flag counter to zero
 4. Increment the number of records read, and read one record from the source device.
 5. Test if a read error occurred. If it did, set the error code, set the error counter to one, and increment the number of read errors. Then go to step (20). If no read error occurred, go to step (6).
 6. If an end-of-file was read, set the end-of-file flag true, and decrement the number of records read. Then go to step (20); otherwise, go to step (7).
 7. Initialize the syntax checking pointer to zero.
 8. Increment the syntax column pointer and syntax check the column with the syntax masks.
 9. If there is a syntax error, set the syntax error code, set the number of errors to one, set the error indicator flag in the column, and increment the flag counter; otherwise, go to step (10).
 10. Test if all the columns have been syntax checked. If they have, go to step (11); otherwise, go to step (8).
 11. Test if the card type and HC number are acceptable, if not, go to step (20); otherwise go to step (12).
 12. Decode the card type being processed. If a decode error occurs, set the reject-the-error code and increment the error counter. Then go to step (20); otherwise, go to step (13).

13. Set an error flag false. Then branch on the card type being processed. If card Type 1 is being processed, go to step (14). If card Type 4 is being processed go to step (28). If card Type 5 is being processed, go to step (33), and if card Type 6 is being processed go to step (38).
14. Card Type 1, check if the following are in range:
 - a) HC number;
 - b) HFC number;
 - c) Segment number;
 - d) Pecking-order number;
 - e) BCS assignment number;
 - f) Corridor assignment letter; and
 - g) X, Y, Z, coordinate values.

If any of these values are not in range, set the corresponding column indicator flags and set the error flag true.

15. Test if the error flag is set. If it is, set the error code word, increment the error counter and go to step (20). Otherwise, go to step (16).
16. Call the subroutine DINTRF to transform the coordinate values and scale and pack the values into five I*2 words.
17. Add the BCS and corridor assignments to the low-order byte of the fifth word..
18. Increment the number of records accepted and set the accept-file flag true.
19. Store the coordinate value words, pecking order, and segment number into local common arrays relative to the HFC-HC number address.
20. Test if a source listing or an error code was set. If either is true, go to step (21); otherwise, go to step (26).
21. Increment the line number counter.
22. Call the subroutine DINTTL which will produce a title heading if line number one is being printed.
23. Write the source ASCII record to the printer.

24. Call the subroutine DINFLG which will flag any indicated column errors.
25. Call subroutine DINERR which will write any error messages indicated.
26. Test if the end-of-file flag is true. If it is, go to step (27). Otherwise, test if three read errors have occurred. Go to step (3) if they have and set the data-accepted flag false; return to the calling subroutine.
27. Test if source type 4 is being processed (aim points); if false, return to the calling subroutine. Otherwise, test the reject-file flag. If the flag is true, return to the calling subroutine. If the flag is false, set the data-accepted flag true, and then return to the calling subroutine.
28. Card Type 4 - check if the following are in range:
 - a) HC number; and
 - b) Aim-point coordinate values (X,Y,Z).

If any of these values are not in range, set the corresponding column indicator flags and set the error flag true.

29. Test if the error flag is set. If it is, set the error-code number and increment the error counter and flag counter, and go to step (20). otherwise, go to step (30).
30. Call the subroutine DINTRF to transform the aim-point coordinates, and scale and pack the values into five I*2 words.
31. Call the subroutine DININC to test if the aim point is in the inclusion area.
32. Test if the aim point is in the inclusion area. If it is, add the aim-point number to the low-order byte of word five; increment the number of records accepted; store the aim-point coordinate values into the local common arrays relative to the HFC-HC number; and store the aim-point number into a local common array relative to the HFC-HC number. Then go to step (20). If the aim point is not in the inclusion area, set the error code, increment error count, set the column flags and increment their count, and set the reject-file flag true. Then go to step (20).

33. Card Type 5 - check if the following are in range:

- a) BCS target designator; and
- b) BCS target coordinates.

If any of these values are not in range, set the corresponding column-indicator flags and set the error flag true.

- 34. Test if the error flag is set. If it is, set the error code and increment the error counter; then go to step (20). Otherwise, go to step (35).
- 35. Call the subroutine DINTRF to transform the coordinate values; scale and pack the values into five I*2 words.
- 36. Store the scaled and packed values into local common arrays relative to the BCS target designator.
- 37. Increment the number of records stored and set the data-accepted flag true; go to step (20).
- 38. Test if the corridor indicator is valid; if it is, go to step (38). If it is not valid, set the column flags, increment the count, and set the error flag true; then go to step (39).
- 39. Test if the lower-limit point is in range. If it is not in range, set the column flags, increment the count, and set the error flag true.
- 40. Test if the upper-limit point is in range. If it is, call the transformation subroutine DINTRF. If it is not in range, set the column flags, increment the count, and set the error flag true.
- 41. Test if the delta step is in range. If it is, call the transformation subroutine DINTRF. If it is not in range, set the column flags, increment the count, and set the error flag true.
- 42. Test if the error flag is set. If it is, set the error code and increment the error counter; then go to step (20). If it is not set, go to step (43).

43. Store the corridor values into local common relative to the corridor indicator.

44. Increment the number of records accepted and set the data-accepted flag true. Go to step (20).

e. Error messages and recovery -

1. Error messages:

- a) READ ERROR REC: NNNN
- b) SYNTAX ERROR REC: NNNN
- c) DECODE ERROR REC: NNNN
- d) SOURCE VALUE OUT OF RANGE REC: NNNN
- e) AIM POINT NOT IN INCLUSION AREA; FILE REJECTED REC: NNNN

2. Error recovery--

Return to calling subroutine with data-accepted flag false.

3.2.7.4.1.2.2 Data, Logic and Command Paths

Input data:

- a. Source device number;
- b. Source listing requested;
- c. Source type number;
- d. Source data; and
- e. Conversion mappings for MDAC to HFC-HC numbers.

Output data:

- a. Processed source data to local common;
- b. Number of records accepted; and
- c. Data-accepted flag.

3.2.7.4.1.2.3 Internal Data Description

Data processed from the source input is stored in local common area DINCOM. The storage of accepted records is always relative to an indicator on the source record. This storage procedure allows for partial updating of the processed records to disk. The HFC-HC numbering system to MDAC numbering system mapping arrays and vice-versa are contained in local common.

3.2.7.4.1.2.4 Flowchart

See Figure 3.2.7-10 for the DINLOC flowchart.

Figure 3.2.7-10 Flowchart - DINLOC

Figure 3.2.7-10 Flowchart - DINLOC (continued)

Figure 3.2.7-10 Flowchart - DINLOC (continued)

Figure 3.2.7-10 Flowchart - DINLOC (continued)

Figure 3.2.7-10 Flowchart - DINLOC (continued)

Figure 3.2.7-10 Flowchart - DINLOC (continued)

Figure 3.2.7-10 Flowchart - DINLOC (continued)

3.2.7.4.1.3 Submodule III - DINTRF

3.2.7.4.1.3.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by submodule DINLOC.
- c. Constraints and limitations - Coordinate magnitudes input must be less than 3,375 feet. This subroutine requires 32-bit integer words and a bit-shifting function.
- d. Processing -
 1. The processing begins by transforming the input coordinates, expressed in California Lambert grid, to coordinates expressed in site reference (East, North, Up). During the transformation, the coordinate value units are converted from feet to meters. Next the transformed coordinate values are scaled and packed into a 24-bit format.
 2. Each of the three values is scaled B14 and, respectively, stored into 32-bit integers.
 3. Each of the three 32-bit integer words is bit-shifted left eight places. This shift places the 24 bits of interest into the left-most 24 bits and the remaining right-most 8 bits are all zero.
 4. The Y-coordinate value is shifted right 24 bits. This results in 24 leading zeroes and 8 bits of the Y-value. This value is added to the X-coordinate integer word resulting in 32 bits which contain 24 bits of X value and 8 bits of Y.
 5. The Y-coordinate value is shifted left 8 places. The Z-coordinate is right shifted 16 places. The results of these shifts are added together resulting in a 32-bit word containing 16 bits of Y on the left and 16 bits of Z on the right.
 6. The Z-value is shifted left 16 bits resulting in a 32-bit word with 8 bits of Z and 8 bits of zero in the left half.
- e. Error messages and recovery - This submodule produces no error messages.

3.2.7.4.1.3.2 Data, Logic and Command Paths

Input data:

X, Y, and Z coordinate values in a floating-point array.

Output data:

- a. X, Y, and Z coordinates in Heliostat field reference system (units of meters) in a floating-point array; and
- b. X, Y, and Z coordinates in heliostat field reference system scaled B14 and formatted into a 16-bit integer word array.

Algorithms:

To transform from the California Lambert system (L) to the Heliostat field system (H):

$$X_H = X_L \sin a + Y_L \cos a$$

$$Y_H = X_L \cos a - Y_L \sin a$$

$$Z_H = Z_L - Z_B$$

Where: Z_B = offset constant (98) ft.

$$a = 0.6650407436$$

3.2.7.4.1.3.3 Internal Data Description

Equivalence an I*4 integer array of length three to an I*2 integer array of length five to obtain the 24-bit scaled data words in five I*2 integer words.

3.2.7.4.1.3.4 Flowchart

See Figure 3.2.7-11 for the DINTRF flowchart.

3.2.7.4.1.4 Submodule IV - DININC

3.2.7.4.1.4.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DINLOC
- c. Constraints and limitations - The input aim-point vector must be expressed in the heliostat site reference system (East, North, Up).

Figure 3.2.7-11 Flowchart - DINTRF

d. Processing -

1. Compute the difference between the aim-point vector and the receiver center-point vector. The resulting vector components are X (East), Y (North), and Z (Up).
2. Set the aim point in inclusion-area flag true.
3. If the East-North components are within the receiver cylinder, go to step (4). Otherwise, set the aim point in inclusion-area flag false and return to the calling subroutine.
4. If the absolute value of the Up component is less than or equal to half the receiver (cylinder) height, return to the calling subroutine. Otherwise, set the aim point in inclusion-area flag false and return.

e. Error messages and recovery - None.

3.2.7.4.1.4.2 Data, Logic and Command Paths

Input data:

Aim-point vector

Output data:

Indicator flag for aim point being in inclusion area or not.

Algorithm:

Inclusion area check. See Figure 3.2.7-12.

The difference vector is projected onto the X-Y plane and tested to see if it is within the cylinder radius.

The difference vector is projected onto the Z-axis to see if it is within the height of the cylinder.

If either of these tests are not met, the aim point is not within the cylinder.

3.2.7.4.1.4.3 Internal Data Description

The vector to the center point of the receiver, in site reference coordinates, is internally stored. The cylinder dimensions (radius and height) are also internally stored.

3.2.7.4.1.4.4 Flowchart

See Figure 3.2.7-13 for the DININC flowchart.

Figure 3.2.7-12 Inclusion-Area Check Diagram

Figure 3.2.7-13 Flowchart - DINING

3.2.7.4.1.5 Submodule V - DINSRT

3.2.7.4.1.5.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by DINLOC
- c. Constraints and limitations - The pointer array input must be preestablished.
- d. Processing - Shell sorting algorithm:
 1. Store the number of elements to sort into a local variable.
 2. Integer divide the present local array length variable by two.
 3. Test if half of the present local array length is less than or equal to zero. If it is, the sort is complete; otherwise continue on to step (4).
 4. Store the local array length into index "j."
 5. Store the difference of index "j" and the local array length into index "l."
 6. Store the subject array pointer indexed by "j + 1" into temporary location "k."
 7. Test if the subject array value (pointed to by temporary pointer index "k") is greater than or equal to the subject array value (pointed to by the pointer array indexed by "j + 1"). If the test is true, go to step (10), if false, go to step (8).
 8. Store the pointer indexed by "i + 1" into the pointer location indexed by "i - h - 1," and compute a new index "i."
 9. Test if the new index "i" is greater than or equal to zero. If the test is true, go back to step (7). If the test is false, go to step (10).
 10. Store the temporarily stored pointer "k" into pointer location indexed by "i + h + 1."
 11. Test if the index "j" should be incremented or it has reached the end of the array. If "j" is not greater than or equal to the length of the array, increment "j" and go to step (5). If the test is true, go to step (2) to compute a new local array length.

- e. Error messages and recovery - None, but if a zero or negative number is input as the length of the array for sorting, this submodule will return to the calling submodule without attempting any sort.

3.2.7.4.1.5.2 Data, Logic and Command Paths

Input data:

- a. The subject array of integer values to sort into ascending order. The subject array is not disturbed;
- b. The array of pointers that point to the subject array in the order to consider for sorting. This array is rearranged during processing; and
- c. The number of elements in the subject array to sort. This input is not disturbed during processing.

Output data:

The array of pointers sorted so that they point to the subject array in ascending order.

Algorithm:

The algorithm used in DINSRT is the Shell Sort.

3.2.7.4.1.5.3 Internal Data Description

All the arrays and temporary storage are 16-bit integers.

3.2.7.4.1.5.4 Flowchart

See Figure 3.2.7-14 for the DINSRT flowchart.

3.2.7.4.1.6 Submodule VI - DINTTL

3.2.7.4.1.6.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by DINFLG, DBIERR, DINLOC, and DINANG.
- c. Constraints and limitations - None.
- d. Processing -
 - 1. Initialize the write counter to one.
 - 2. Compute if the line number input requires a title (modulo function).

Figure 3.2.7-14 Flowchart - DINSRT

3. Test if writing on line one (from modulo function). If not on line one, return to calling submodule; otherwise enter a CASE construct to write the title.
 4. The input title number causes a branch to the proper title for output. In the event an unassigned title number is requested, the top page default path is taken.
 5. After the title is printed, the line counter is set back to the number of lines in the title plus one.
 6. A test is made to determine if an output error occurred. If no error occurred, a return is made to the calling submodule.
 7. If an output error occurred, the write counter is incremented and the output device number is changed to the other hard-copy device.
 8. A test is made to determine whether there is an output error on the third try. If there is an output error and only the second try, branch back to (4). Otherwise return to the calling submodule.
- e. Error messages and recovery - if one write error occurs this submodule tries to write on the other hard-copy device.

3.2.7.4.1.6.2 Data, Logic and Command Paths

Input data:

- a. The number of the title desired, corresponding to the numbers of the card type source data;
- b. The present line number to write on; and
- c. The device number to write on.

Output data:

- a. If a title is printed, the line number counter is reinitialized for a new page. Otherwise, no changes;
- b. The number of the output device is changed if a primary write attempt fails; and
- c. Title for hard-copy device when output is going to line one.

3.2.7.4.1.6.3 Internal Data Description

The title messages are stored in format statements.

3.2.7.4.1.6.4 Flowchart

See Figure 3.2.7-15 for the DINTTL flowchart.

3.2.7.4.1.7 Submodule VII - DINANG

3.2.7.4.1.7.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call from DIN
- c. Constraints and limitations - None
- d. Processing
 1. Initialize three counters which are routine dependent and the end-of-file false.
 2. Initialize the error code to zero, the number of errors to zero, and the number of syntax error flags to zero. These three variables are record dependent.
 3. Increment the number of records read counter.
 4. Read one record of the source data into a buffer formatted in ASCII characters.
 5. Test if a read error occurred. If the test is true, set the error code and increment the read error counter. Next set the number of error messages counter to one and transfer to step (26). If the test is false, go to step (6).
 6. Test if an end-of-file was read. If the test is true, set the end-of-file flag true and decrement the number of records read counter. Then transfer to step (26). If the test is false, go to step (7).
 7. Initialize the syntax checking column pointer.
 8. Syntax check contents of column presently pointed to.
 9. Test if there is a syntax error; if true, proceed to step (10). Otherwise transfer to step (13).

Figure 3.2.7-15 Flowchart - DINTTL

10. Set the error code indicating a syntax error, increment the number-of-errors counter, set the column indicator flags, and increment the column flag counter.
11. Test if a default value should be supplied. If a default value is needed, place the default in the columns (ASCII representation). Otherwise, go to step (12).
12. Set the pointers to the next column grouping and transfer to step (14).
13. Increment the column pointer.
14. Test if all the columns needing syntax checking are completed. If the test is true, go to step (15). Otherwise, transfer back to step (8).
15. Test if the card type and HC number are acceptable. If the test is true then go to step (16); otherwise go to step (26).
16. Decode the card type number and HC number.
17. Test if a DECODE error occurred. If the test is true, set the reject-record error code, increment the error counter and go to step (26). Otherwise, go to step (18).
18. Decode columns 16 through 32.
19. Test if a DECODE error or the resulting values are out of range. If the test is true, supply a default value(s), set the error code, increment the error counter, set the column indicator flags, and increment the column flag counter. Otherwise take the null false path.
20. Call the subroutine DINPAC to scale and pack the azimuth and elevation angles into a format compatible with the HFC and HC firmware.
21. Store the HC number and azimuth-elevation packed and scaled values into local common relative to the HC number.
22. Decode columns 39 through 55.
23. Test if a DECODE error occurred or the resulting values are out of range. If the test is true, supply a default value(s), set the error

code, increment the error counter, set the column indicator flags, and increment the column flag counter. Otherwise, take the null false path.

24. Call the subroutine DINPAC to scale and pack the azimuth and elevation angles into a format compatible with the HFC-HC firmware.
 25. Store the azimuth and elevation values into local common relative to the HC number.
 26. Test if a source listing was requested or any error codes exist. If the test is true, go to step (27); otherwise transfer to step (32).
 27. Increment the printer line-number counter.
 28. Call the DINTTL subroutine to produce a source listing title when required.
 29. Write the source ASCII to the printer.
 30. Call the subroutine DINFLG to print the error flags.
 31. Call the subroutine DBIERR to print the error messages.
 32. Test if the end-of-file flag is set or three read errors have occurred. If the test is true, return to the calling subroutine; otherwise transfer back to step (2).
- e. Error messages and recovery - Error messages from this submodule are:
1. Error in reading source device Rec: NNNN.
 2. Syntax error in source azimuth or elevation, default supplied Rec: NNNN.
 3. Syntax error in card-type designator Rec: NNNN.
 4. Syntax error in HC number Rec: NNNN.
 5. Decode error in card type or HC number Rec: NNNN.
 6. Decode error in azimuth or elevation, default supplied Rec: NNNN.

3.2.7.4.1.7.2 Data, Logic and Command Paths

Input data:

- a. Card type indicator;
- b. Source device number;
- c. Source listing desired indicator; and
- d. Output device number.

Output data:

- a. End-of-file encountered flag; and
- b. Local common is used to store the azimuth and elevation values for the HC number. These values are stored relative to the HC number.

3.2.7.4.1.7.3 Internal Data Description

An internal array of the ASCII characters "+," "-", blank, "0," "1," "2," "3," ..., "9," and "." are used to syntax check the source record. Default values for the azimuth and elevation are stored both in ASCII and floating-point format.

The local common area is structured so that the first $I*2$ integer array corresponds to the source HC number. The remaining four $I*2$ integer arrays correspond respectively, to the azimuth, elevation, azimuth, and elevation.

3.2.7.4.1.7.4 Flowchart

See Figure 3.2.7-16 for the DINANG flowchart.

3.2.7.4.1.8 Submodule VIII - DINPAC

3.2.7.4.1.8.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by DINANG submodule
- c. Constraints and limitations - the input azimuth and elevation angles are limited in magnitude to less than 360 degrees.
- d. Processing -
 1. The input azimuth angle is divided by 360, then multiplied by the scaling factor 2^{13} . The result of this computation is stored in a 16-bit integer word.
 2. The input elevation angle is divided by 360, then multiplied by the scaling factor 2^{13} . The result of this computation is stored in a 16-bit integer word.

Figure 3.2.7-16 Flowchart - DINANG

Figure 3.2.7-16 Flowchart - DINANG (continued)

Figure 3.2.7-16 Flowchart - DINANG (continued)

3. Shift the contents of each integer word left two bits.

e. Error messages and recovery - None.

3.2.7.4.1.8.2 Data, Logic and Command Paths

Input data:

- a. The azimuth angle, for scaling and bit packing, is input in floating-point format in units of degrees; and
- b. The elevation angle, for scaling and bit packing, is input in floating-point format in units of degrees.

Output data:

A 16-bit integer array of length two. The first word contains the azimuth angle in the left-most 14 bits in units of counts (scaled $360^\circ = 2^{13}$ counts). The second word contains the elevation angle in the left-most 14 bits in units of counts (scaled $360^\circ = 2^{13}$ counts).

Algorithm:

$$a_C = \frac{a_D}{360.0} * 2^{13}$$

Where: a = angle, C = counts, D = degrees

3.2.7.4.1.8.3 Internal Data Description

Two 16-bit integer words are formed that have the format:

Assumed binary point

Where: S = sign, X = angle data bits, and crosshatched are zero.

3.2.7.4.1.8.4 / Flowchart

See Figure 3.2.7-17 for the DINPAC flowchart.

3.2.7.4.1.9 Submodule IX - DINFLG

3.2.7.4.1.9.1 Description

- a. Language used - FORTRAN
- b. How invoked - Call by DINLOC and DINANG

Figure 3.2.7-17 Flowchart - DINPAC

c. Constraints and limitations - None

d. Processing -

1. If there are no error flags to print, this routine returns to the calling submodule. Otherwise the processing continues.
2. A buffer for output to the printer is filled with either an ASCII blank or "\$" depending on the state of an input indicator array.
3. After the output buffer is filled, the line number counter is incremented, and the DINTTL submodule is called to produce a page title if required. Next the ASCII message buffer is written to the output device requested.
4. Test if an output error occurred. If there is not an error, return to the calling submodule. Otherwise, set the output device number to the other device. Call the titles routine, write the ASCII message, and return.

e. Error messages and recovery - If a write error occurs, the other hard-copy device is tried.

3.2.7.4.1.9.2 Data, Logic and Command Paths

Input data:

- a. An array of error flag indicators where zero means no flag and non-zero means flag it;
- b. The requested output device number;
- c. The number of error flags, where zero means no flags required and non-zero means get flag indicators from array;
- d. The line number of the output device; and
- e. The title number.

Output data:

- a. The input array of error flag indicators is cleared (set to zero) during processing; and
- b. The line number counter is incremented by one.

3.2.7.4.1.9.3 Internal Data Description

ASCII characters blank and "\$" are used to fill the message output buffer. The input array of error flag indicators is initialized to zero with a data statement.

3.2.7.4.1.9.4 Flowchart

See Figure 3.2.7-18 for the DINFLG flowchart.

3.2.7.4.1.11 Submodule XI - DBI (Task)

3.2.7.4.1.11.1 Description

- a. Language used - FORTRAN
- b. How invoked - Prescheduled task activated at system boot time.
- c. Constraints and limitations - The disk data base must be established.
- d. Processing -
 1. Call subroutine DBIFAC to initialize the system interfaces and establish the Prime-Backup HAC configuration.
 2. If execution is in the Prime HAC, go to step (3). Otherwise, establish the SWI task and go to step (5).
 3. Call subroutine DBIDTA to initialize the in-core global data base.
 4. If the ABORT flag is returned true by DBIDTA, go to step (9). Otherwise, go to step (5).
 5. Establish the CLK (HAC Startup) task as main-memory resident.
 6. If either of the tasks could not be established, notify the operator, and go to step (9). Otherwise, go to step (7).
 7. Activates task CLK.
 8. If task could not be activated, notify the operator, and go to step (9). Otherwise, go to step (9).
 9. EXIT this task.

Figure 3.2.7-18 Flowchart - DINFLG

- e. Error messages and recovery - If either SWI or CLK can not be established or activated, the operator is notified and the task exits. Also, if the global common data base can not be initialized by subroutine DBIDTA, this task exits.

Error messages are:

1. TASK XXX FAILED TO ESTABLISH, DBI ABORTED
2. TASK XXX FAILED TO ACTIVATE, DBI ABORTED

3.2.7.4.1.11.2 Data, Logic and Command Paths

Three conditions are considered fatal for the DBI task:

- a. Failure to initialize the global common data base;
- b. Failure to establish either SWI or CLK tasks; and
- c. Failure to activate either SWI or CLK tasks.

Input data:

- a. ABORT flag returned by DBIDTA; and
- b. Global common word, CPUSG.

3.2.7.4.1.11.3 Internal Data Description

This task does not use any local data structures.

3.2.7.4.1.11.4 See Figure 3.2.7-19 for the DBI flowchart.

3.2.7.4.1.12 Submodule XII - DBIFAC

3.2.7.4.1.12.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DBI.
- c. Constraints and limitations - None.
- d. Processing -
 1. Call subroutine DBICRT to determine whether execution is in the Prime or Backup HAC.
 2. Call subroutine DBIERR to output any error messages from DBICRT.

Figure 3.2.7-19 Flowchart - DBI

3. Call subroutine DBITRP to initialize the receiver trip communications.
4. Call subroutine DBIERR to output any error messages from DBITRP.
5. If executing in the Prime, go to step (3); otherwise, go to step (8).
6. Call subroutine DBIGRF to initialize the graphics processors.
7. Call subroutine DBIERR to output any error messages from DBIGRF.
8. Return processing control to the calling subroutine DBI.

e. Error messages and recovery - None

3.2.7.4.1.12.2 Data, Logic and Command Paths

Input data:

Prime or Backup indicator in global common word CPUSG.

Output data:

None

3.2.7.4.1.12.3 Internal Data Description

No internal data structures are utilized.

3.2.7.4.1.12.4 Flowchart

See Figure 3.2.7-20 for the DBIFAC flowchart.

3.2.7.4.1.13 Submodule XIII - DBICRT

3.2.7.4.1.13.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call DBIFAC
- c. Constraints and limitations - Requires the operator's designation of either PRIME or BACKUP.

Figure 3.2.7-20 Flowchart - DBIFAC

d. Processing -

1. Clear CPUSG
2. Request from the operator a designation of either Prime or Backup (on the TI-820 system console).
3. Read the operator's response and set PR bit in CPUSG.
4. If the operator's response is Prime, go to step (5). Otherwise, go to step (10).
5. Command the PCIs to connect the peripherals to the Prime.
6. Request from the operator a designation of whether there is a Backup.
7. Read the operator's response, and set BR bit in CPUSG.
8. Initialize the ICS color console.
9. Notify the operator "Data Base Initialization."
10. Return to the calling submodule.

e. Error messages and recovery - None

3.2.7.4.1.13.2 Data, Logic and Command Paths

Input data:

Operator designated Prime or Backup

Output data:

Messages to the operator and sets CPUSG in global common.

3.2.7.4.1.13.3 Internal Data Description

DBICRT sets the global common word CPUSG as a function of whether the CPU is Prime or Backup.

3.2.7.4.1.13.4 Flowchart

See Figure 3.2.7-21 for the DBICRT flowchart.

3.2.7.4.1.14 Submodule XIV - DBIGRF

3.2.7.4.1.14.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DBIFAC
- c. Constraints and limitations - The graphics processors must be in an initial state, waiting to receive the first message - after transmission of the first message (the terminal ID message) the command/response protocol is followed. Receipt of any message from the graphics processor, other than the send-next-message, is considered an error condition during the initialization process.

d. Processing -

- 1. Set the number of errors to zero.
- 2. Set the error code to zero.
- 3. Notify the operator to configure the graphics processors for initialization.

START THE GRAPHICS PROCESSORS

OPTION	INITIALIZE
1	CS GRAPHICS CONSOLE ONLY
2	ENGR ROOM CONSOLE ONLY
3	BOTH CONSOLES
T	TERMINATE

- 4. Request and read the operator's response:

ENTER OPTION FROM ABOVE LIST:

- 5. If the response is valid, go to step (6); otherwise, go to step (4).
- 6. If the operator's response is TERMINATE, set an error code, set the number of errors to one, and return to the calling subroutine. Otherwise, go to step (7).
- 7. Initialize the full-field message buffer with the value 12 (indicating offline heliostat status).

Figure 3.2.7-21 Flowchart - DBICRT

8. Test if the operator's response initialized both graphics processors. If the test is true, set the limit counter to two, and set the output unit to one. Otherwise, set the limit counter to one, and set the unit to write to equal to the OPTION selected.
 9. Initialize the number of graphics processors to initialize to one.
 10. Compose the initialization message for the unit being written to.
 11. Write the initialization message to the graphics processor as a function of unit number.
 12. Initialize a counter for the one-eighth of field to one.
 13. Read the graphics processor's command.
 14. If the graphics processor's command is not "send next message," notify the operator the graphics processor is in error and go to step (3). Otherwise, go to step (15).
 15. Write the one-eighth of field status message to the graphics processor.
 16. If all the one-eighths of the field status messages have been sent, go to step (17). Otherwise, increment to the next one-eighth of the field and go to step (13).
 17. If the number of graphics processors initialized is less than the number to initialize, increment the counter, set the unit number to two, and go to step (10). Otherwise, return to the calling subroutine.
- e. Error messages and recovery - Any errors encountered during reading or writing to/from the graphics processors results in a message to the operator and a transfer to step (3) for an operator's decision.
Error messages:

GRAPHICS NOT INITIALIZED AT OPERATOR'S COMMAND.
I/O ERROR TO/FROM GRAPHICS PROCESSOR.
GRAPHICS PROCESSOR OUT OF SYNC.

3.2.7.4.1.14.2 Data, Logic and Command Paths

Input data:

- a. Command messages from the graphics processors; and
- b. Operator's response.

Output data:

- a. Initialization messages to the graphics processors;
- b. Full-field heliostat offline status messages to the graphics processors;
- c. Error messages for operator decision/response; and
- d. Error code and number of errors.

3.2.7.4.1.14.3 Internal Data Description

Graphics message buffers that are filled with initialization information and heliostat offline status values (-1).

3.2.7.4.1.14.4 Flowchart

See Figure 3.2.7-22 for the DBIGRF flowchart.

3.2.7.4.1.15 Submodule XV - DBITRP (Receiver Trip Initialization)

(For rationale, see Table 3.2.8.III - Receiver Trip Function)

3.2.7.4.1.15.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call from DBI.
- c. Constraints and limitations - The only error undetected by DBITRP is the case of both interrupt levels high. In this case the two interrupt handlers in Receiver Trip will occupy 100 percent of the CPU time, and nothing more will be accomplished.
- d. Processing - Receiver Trip (R/T) initialization consists of establishing and connecting both receiver trip tasks, RTL and RTH, waiting one second, and then sensing the RTOP bit in CPUSG to see if one or the other of the interrupt levels has fired (one should have). If RTOP is set, initialization is successful. If not, there is an error in the receiver trip hardware. A message so stating is issued, and a request is made of the operator to retry or ignore the lack of receiver trip. Receiver trip has been built in such a way that even if initialization fails (i.e., the lack of signal is explicitly ignored) it can be made to initialize itself by providing the proper receiver trip signals at any point during operations. A spurious DEFOCUS command to task MMI (Man-Machine Interface Module) may result from such operation. RTOP will then indicate that R/T is operational.

Note further that RTOP will not indicate that the receiver trip hardware has gone non-operational once it has been initialized.

Figure 3.2.7-22 Flowchart DBIGRF

Figure 3.2.7-22 Flowchart DBIGRF (Continued)

- e. Error messages and recovery - None, except as stated in "d." above.

3.2.7.4.1.15.2 Data, Logic and Command Paths

The bit RTOP is bit five in the global common word CPUSG. If on, it may be interpreted to mean the receiver trip hardware and software was operational at initialization; if off, then the receiver trip is not operational.

3.2.7.4.1.15.3 Internal Data Description

There is no data internal to this function.

3.2.7.4.1.15.4 Flowchart

See Figure 3.2.7- 23 for the DBITRP flowchart.

3.2.7.4.1.16 Submodule XVI - DBIDTA

3.2.7.4.1.16.1 Description

- a. Language used - FORTRAN
- b. How invoked - subroutine call by DBI.
- c. Constraints and limitations - The disk data base must be initialized and accessible.
- d. Processing -
 - 1. Call subroutine DBIDSK to verify the disk-resident data base.
 - 2. Output any errors returned by DBIDSK.
 - 3. If the ABORT flag is returned true by DBIDSK, go to step (13). Otherwise, go to step (4).
 - 4. Call subroutine DBICOR to initialize the global common data base.
 - 5. Call subroutine DBIERR to report any errors returned by DBICOR.
 - 6. If the ABORT flag is returned true by DBICOR, go to step (13). Otherwise, go to step (7).
 - 7. Call DBIAIM to initialize the global common aim-point array.
 - 8. Call subroutine DBIERR to report any errors returned by DBIAIM.

Figure 3.2.7.23 Flowchart - DBITRP

Figure 3.2.7.23 Flowchart - DBITRP (Continued)

9. If the ABORT flag is returned true by DBIATM, go to step (13). Otherwise, go to step (10).
10. If bit 13 of global common word CPUSG is set, go to step (11). Otherwise, go to step (13).
11. Call subroutine DBIBCK to initialize the Backup HAC.
12. Call subroutine DBIERR to report any error returned by DBIBCK.
13. Return to the calling task DBI.

e. Error messages and recovery - None.

3.2.7.4.1.16.2 Data, Logic and Command Paths

Input data:

- a. ABORT flag; and
- b. Global common word CPUSG.

Output data:

ABORT flag.

3.2.7.4.1.16.3 Internal Data Description

DBIDTA does not use any local data structures.

3.2.7.4.1.16.4 Flowchart

See Figure 3.2.7-24 for the DBIDTA flowchart.

3.2.7.4.1.17 Submodule XVII - DBIDSK

3.2.7.4.1.17.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DBIDTA
- c. Constraints and limitations - The segment-mapping array, SEGMPG, and the segment-pointer array, SEGPTG, must be initialized and stored on disk in file DIN (records 17 and 34 to 50).
- d. Processing -
 1. Set the abort flag false, the error code to zero and the number of errors to zero.

Figure 3.2.7-24 Flowchart DBIDTA

2. Read the segment-map array (SEGMPG) and segment-pointer array (SEGPTG) from disk file DIN (SEGPTG - record 17, words 50-109; SEGMPG - records 34-50).
3. If a read error occurs, set the error code, increment the number of errors, set the abort flag true, and go to step (16). Otherwise, go to step (4).
4. For each HC number in the segment-mapping array (SEGMPG), flag the corresponding element in a local array; otherwise, the element is zero.
5. Read two records of the HC locations from disk and store in a local buffer array.
6. Read one record of Wash angles from disk and store in a local buffer array.
7. Read one record of Stow angles from disk and store in a local buffer array.
8. Read one record of Alt1Stow angles from disk and store in a local buffer array.
9. Read one record of Alt2Stow angles from disk and store in a local buffer array.
10. If there are any read errors, set the error code, increment the number of errors, set the abort flag, and go to step (16); otherwise, go to step (11).
11. Limit check the HC location values indexed by the local flag array.
12. If any of the HC location values are out of range, set the abort flag, print out the HC number and its Hex value, and set the error code and count (limit count).
13. Limit check the Wash angles, Stow angles, Alt1Stow angles, and Alt2Stow angles indexed by the local flag array.
14. If any of the angle values are out of range, set the abort flag and print out the HC number angle Hex values, and set the error code and count (limit count).
15. If all the HCs in the segment map are processed, go to step (16); otherwise, go to step (5).
16. Return to the calling subroutine DBIDTA.

- e. Error messages and recovery - If HC locations, Wash angles, Stow angles, Alt1Stow angles, or Alt2Stow angles are found to be out of value range, the disk storage of these values is considered to be invalid. The message:

ERROR HC #NNNN LOCATION XXXXXXXXXXXXXXXXXXXX
and/or
ERROR HC #NNNN WASH: XXXXXXXX STOW XXXXXXXX
ALT1 XXXXXXXX ALT2 XXXXXXXX

is printed out.

3.2.7.4.1.17.2 Data, Logic and Command Paths

Input data:

- a. Segment-map array from disk file DIN (records 34 to 50);
- b. Segment-pointer array from disk file DIN (record 17);
- c. HC-locations disk file;
- d. HC Wash-angles disk file;
- e. HC Stow-angles disk file;
- f. HC Alt1Stow-angles disk file; and
- g. HC Alt2Stow-angles disk file;

Output data:

- a. Abort flag;
- b. Error code; and
- c. Number of errors.

3.2.7.4.1.17.3 Internal Data Description

Local arrays used for checking disk data:

- a. 2048-word flag array;
- b. 320-word HC location array;
- c. 128-word HC Wash-angle array;
- d. 128-word HC Stow-angle array;
- e. 128-word HC Alt1Stow-angle array; and
- f. 128-word HC Alt2Stow-angle array.

Limit values for HC locations, Wash angles, Stow angles, Alt1Stow angles and Alt2Stow angles are set in data statements. The values are transformed and/or scaled and packed.

3.2.7.4.1.17.4 Flowchart

See Figure 3.2.7-25 for DBIDSK flowchart.

3.2.7.4.1.18 Submodule XVIII - DBICOR

3.2.7.4.1.18.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DBIDTA

Figure 3.2.7-25 Flowchart DBIDSK

c. Constraints and limitations - disk file DIN must be initialized prior to executing this subroutine.

d. Processing -

1. Initialize the abort flag false, the error code to zero, and the number of errors to zero. Initialize the message queues.

2. Initialize all of global common (COMDAT) to zero, except CPUSG and the TBUSYG words.

3. Initialize the 2048-word arrays, ELEVG and AZIMG, to:

ELEVG = $-90^{\circ} * 91.02222$

AZIMG = 0.0

4. Initialize the 2048-word array, GRSTSG, to a value of 12 (heliostats offline).

5. Initialize the 16-word array, LINESG, to:

Normal lines = #0800

Alternate lines = #0000

6. Initialize the 16-word array, SEQLSG, to the negative of its index number (i.e., SEQLSG(1) = -1, ..., SEQLSG(16) = -16).

7. Initialize the 64-word array, HFCS2G, to a value of #B000.

8. Initialize the double-precision word, SLATG, to the site latitude.

9. Initialize the double-precision word, SLONGG, to the site longitude.

10. Read disk file, DIN, records 1-16 to obtain the 2048-word array, MD2HCG, and store it in global common.

11. If a read error occurred, go to step (27); otherwise, go to step (12).

12. Read disk file, DIN, record 17 to obtain the 30-word array, MDNPRG, and the 60-word array, SEGPTG. Store both arrays in global common.

13. If a read error occurred go to step (27); otherwise, go to step (14).

14. Read disk file, DIN, records 18 to 33 to obtain the 2048-word array, HC2MDG, and store it in global common.
15. If a read error occurred, go to step (27); otherwise, go to step (16).
16. Read disk file, DIN, records 34 to 50 to obtain the 2108-word array, SEGMPG, and 20-word array, BCSTGG. Store both of these arrays in global common.
17. If a read error occurred, go to step (27); otherwise, go to step (18).
18. Read disk file, DIN, record 51 to obtain the corridor coordinates and store them into the 120-word global common array, CORRCG.
19. If a read error occurred, go to step (27); otherwise, go to step (20).
20. Initialize the 2048-word array, HCST2G, to a value of #8000 (not installed).
21. Using the SEGPTG and SEGMPG arrays, set the indicated HCST2G words to a value of #0800 (installed, not marked).
22. Read one record (one HFC) of HC location from the disk to obtain the HC's corridor and BCS assignments.
23. If a read error occurred, go to step (27); otherwise, go to step (24).
24. Initialize the HCST3G words (one HFC) with the corridor and BCS assignments (up to 32 words).
25. Initialize one word of the global common array, HFCS3G, with the HFC corridor assignments.
26. If all the HFCs are processed, go to step (28); otherwise, go to step (22).
27. Set the abort flag true, set an error code and increment the number of errors.
28. Return to the calling subroutine.

- e. Error messages and recovery -Disk read errors result in an abort flag being set and an error code returned to the calling subroutine, DBIDTA.

3.2.7.4.1.18.2 Data, Logic and Command Paths

Input data:

Data stored on disk file DIN.

Output data:

- a. Abort flag;
- b. Error code;
- c. Number of errors; and
- d. Initial values into the global common area /COMDAT/.

3.2.7.4.1.18.3 Internal Data Description

The initial values for the arrays AZIMG and ELEVG are set in data statements. The initial values for SIATG and SLONGG (site latitude and longitude) are set in data statements.

3.2.7.4.1.18.4 Flowchart

See Figure 3.2.7-26 for DBICOR flowchart.

3.2.7.4.1.19 Submodule XIX - DBIAIM

3.2.7.4.1.19.1 Description

- a. Language used - FORTRAN
- b. How invoked - subroutine call by DBIDTA.
- c. Constraints and limitations - The global common array HCST2G must be initialized to its installed or not-installed state.
- d. Processing -
 - 1. Set the abort flag false, the error code to zero, and the number of errors to zero.
 - 2. Set the global common array AIMOKG equal to one, and set the installed flag false.
 - 3. Initialize a counter to one.
 - 4. If the counter I is greater than 2048, go to step (14); otherwise, go to step (5).

Figure 3.2.7-26 Flowchart DBICOR

Figure 3.2.7-26 Flowchart - DBICOR (Continued)

5. If the HC is installed, go to step (6); otherwise, increment the counter I and go to step (4).
6. Set the installed flag true.
7. Read one record of the aim-point file indexed by the HC number (i.e., I).
8. If a read error occurs, set the abort flag true, set the error code, increment the number of errors, and go to step (16); otherwise, go to step (9).
9. Initialize the aim-point counter to one.
10. If the aim-point counter is greater than 20, increment the counter I and go to step (4).
11. If the aim-point counter equals the last byte of the five-word aim point, go to step (13). Otherwise, go to step (12).
12. Set the AIMOKG element to zero that corresponds to the aim-point counter.
13. Increment the aim-point counter, and go to step (10).
14. If the installed flag is true, go to step (17). Otherwise, go to step (15).
15. Set the abort flag true, set the error code, and increment the error count.
16. Set the AIMOKG global common array to zero.
17. If the AIMOKG array is all zero, set the abort flag true, set the error code, increment the number of errors, and go to step (20). Otherwise, go to step (18).
18. Read the lowest cardinal-numbered aim-point array from disk and store it into the global common array AIMPTG.
19. If a read error occurs, set the abort flag true, set the error code, increment the number of errors, and go to step (20). Otherwise, go to step (20).
20. Return to the calling subroutine.

- e. Error messages and recovery - If the processing finds that no heliostats are installed or that no valid aim-point array exists on the disk, an abort flag and error code are returned to the calling subroutine.

3.2.7.4.1.19.2 Data, Logic and Command Paths

Input data:

- a. HCST2G global common array; and
- b. Aim-point arrays from the disk.

Output data:

- a. Abort flag;
- b. Error code;
- c. Number of errors;
- d. Global common array AIMOKG; and
- e. Global common array AIMPTG.

3.2.7.4.1.19.3 Internal Data Description

A 128-word buffer is utilized to read records from the aim-point disk file.

3.2.7.4.1.19.4 Flowchart

See Figure 3.2.7-27 for the DBIAIM flowchart.

3.2.7.4.1.20 Submodule XX - DBIBCK

3.2.7.4.1.20.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by DBLDTA.
- c. Constraints and limitations - This subroutine should only be executed when there is a Backup processor.
- d. Processing -
 - 1. Set the error code to zero.
 - 2. Write the global common data base (COMDAT) to the Backup processor and exclude the CPU-peculiar status word, CPUSG.
 - 3. If there is a write error, set the error code, and go to step (8). Otherwise, go to step (10).

Figure 3.2.7-27 Flowchart DBIAIM

Figure 3.2.7-27 Flowchart - DBIAIM (Continued)

4. Write the disk data base to the Backup.
5. If there is a write error, set the error code, and go to step (8). Otherwise, go to step (10).
6. Write the global common queue area (CQUEUE) to the Backup processor.
7. If there is a write error, set the error code, and go to step (8). Otherwise, go to step (10).
8. Notify operator of backup initialization failure and request if another try is desired. If so go to step 1. Otherwise, go to step (10).
9. Clear backup bit in CPUSG.
10. Return to the calling subroutine DBIDTA.

- e. Error messages and recovery - If there is an I/O error, this subroutine repeats the complete Backup initialization up to three times. One pass through this subroutine which results in three I/O errors is sufficient to result in not trying again.

3.2.7.4.1.20.2 Data, Logic and Command Paths

Input data:

- a. Global common area, COMDAT (exclude CPUSG);
- b. Disk data base files;
 1. DIN-disk file containing results of offline processing.
 2. HC locations.
 3. HC Wash angles.
 4. HC Stow angles.
 5. HC Alternate 1 Stow angles.
 6. HC Alternate 2 Stow angles.
 7. Field-status save file.

8. HC bias file.

9. HC aim-point file.

- c. Global common area, CQUEUE, which contains the initialized message queue area.

Output data:

All the data input is output to the Backup processor.

3.2.7.4.1.20.3 Internal Data Description

A 160-word local array is used to read the Prime disk data base.

3.2.7.4.1.20.4 Flowchart

See Figure 3.2.7-28 for the DBIBCK flowchart.

3.2.7.4.1.21 Submodule XXI - DBIERR

3.2.7.4.1.21.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call from tasks DIN, DBI and CLK.
- c. Constraints and limitations - This submodule attempts to write messages on the primary output device specified via a formal parameter. If a write error occurs, an alternate output device is selected and tried. If a write error occurs again, this submodule returns to the calling submodule with no output produced.
- d. Processing -
 - 1. Initialize the counter that tracks the number of times an alternate device is tried to one.
 - 2. Test if there are any error messages to output. If there are no error messages, return to the calling submodule. If there are messages to output, go to step (3).
 - 3. Call the subroutine DINTTL to write a heading title when required.
 - 4. Write the error message indicated by the formal-parameter array input, and increment the printer line-number counter.

Figure 3.2.7-28 Flowchart - DBIBCK 478

5. If a write error occurs, go to the next step; otherwise, go to step (10).
 6. Increment the device try counter.
 7. Change the device number to the other device number.
 8. If the device try counter is three, return to the calling subroutine. Otherwise, decrement the printer line-number counter and go to step (3).
 9. If all the error messages are written, return to the calling subroutine. Otherwise, decrement the number of error messages counter, and go to step (3).
- e. Error messages and recovery - If the primary output device indicates an error, a secondary device is tried for the output.

Error messages - See Table 3.2.7-VIII.

3.2.7.4.1.21.2 Data, Logic and Command Paths

Input data:

- a. Number of error messages to print;
- b. Address of error-message codes array;
- c. A number to tag onto an error message when desired;
- d. The output device number;
- e. The current line number to print to; and
- f. The number of the heading title desired.

Output data:

- a. Line number to print to;
- b. Output device number; and
- c. Error messages to output device.

3.2.7.4.1.21.3 Internal Data Description

The error messages are stored in arrays that are stored into a format array for output.

3.2.7.4.1.21.4 Flowchart

See Figure 3.2.7-29 for the DBIERR flowchart.

ERROR: DISK READ/WRITE ERROR
 ERROR: READ IN SOURCE DEVICE REC:NNNN
 ERROR: SYNTAX ERROR REC:NNNN
 ERROR: DECODE ERROR REC:NNNN
 ERROR: SOURCE VALUE OUT OF RANGE REC:NNNN
 ERROR: AIM POINT NOT IN INCLUSION AREA; FILE REJECTED REC:NNNN
 ERROR: SYNTAX ERROR IN SOURCE AZIMUTH OR ELEVATION, DEFAULT SUPPLIED REC:NNNN
 ERROR: SYNTAX FOR CARD-TYPE DESIGNATOR REC:NNNN
 ERROR: SYNTAX FOR HC NUMBER REC:NNNN
 ERROR: DECODE OF CARD TYPE OR HC NUMBER REC:NNNN
 ERROR: DECODE OF AZIMUTH OR ELEVATION, DEFAULT SUPPLIED REC:NNNN
 ERROR: GRAPHICS CONSOLE NOT INITIALIZED AT OPERATOR'S REQUEST
 ERROR: TASK XXX FAILED TO ESTABLISH
 ERROR: TASK XXX FAILED TO ACTIVATE
 ABORT: DISK DATA BASE HC LOCATIONS NOT VALID
 ABORT: CAN NOT READ THE DISK DATA BASE
 ABORT: NO HELIOSTATS ARE INSTALLED

 ABORT: DISK DATA BASE WASH ANGLES NOT VALID
 ABORT: DISK DATA BASE STOW ANGLES NOT VALID
 ABORT: DISK DATA BASE ALT 1 STOW ANGLES NOT VALID
 ABORT: DISK DATA BASE ALT 2 STOW ANGLES NOT VALID

 ABORT: NO AIM-POINT ARRAYS EXIST
 ERROR: CAN NOT WRITE TO BACKUP HAC GLOBAL COMMON
 ERROR: CAN NOT WRITE TO BACKUP HAC DISK DATA BASE

Table 3.2.7-VIII Error Messages

Figure 3.2.7-29 Flowchart - DBIERR

3.2.7.4.1.22 Submodule XXII - CLK (Task)

3.2.7.4.1.22.1 Description

- a. Language used - FORTRAN
- b. How invoked - Established and activated by DBI task.
- c. Constraints and limitations - System configuration must be initialized, the global common data base must be initialized, and the disk data base must be initialized and accessible.
- d. Processing -
 1. Delay in the wait mode for one second to allow DBI to exit main memory.
 2. Call subroutine CLKEST to establish the real-time HAC tasks in main memory.
 3. If a task failed to establish, notify the operator and go to step (8). Otherwise, go to step (4).
 4. If execution is in the Prime HAC, go to step (5). Otherwise, go to step (9).
 5. If 0 backup HAC is present, then enable interrupt level seven to receive the interrupt from the backup during failover.
 6. Call subroutine CLKACT to activate the real-time asynchronous tasks.
 7. If a task failed to activate, notify the operator and go to step (9). Otherwise, go to step (8).
 8. Call subroutine CLKONL to initialize time-keeping and activate the HAC real-time synchronous tasks.
 9. If any errors occurred, go to step (10); otherwise, go to step (13).
 10. Abort all HAC tasks except CLK and SWI.
 11. Request if the operator wants to try again.
 12. If the operator requests to try again, go to step (2). Otherwise, go to step (13).
 13. EXIT this task.

e. Error messages and recovery -

1. Error messages:

- a) TASK XXX FAILED TO ESTABLISH
- b) TASK XXX FAILED TO ACTIVATE
- c) ALL HAC TASKS ABORTED

OPTION	TRY AGAIN
0	NO
1	YES

2. Error recovery:

Error recovery is an operator's option.

3.2.7.4.1.22.2 Data, Logic and Command Paths

Input data:

- a. Global common word CPUSG; and
- b. Operator's response when required.

3.2.7.4.1.22.3 Internal Data Description

Task CLK does not use any local data structures.

3.2.7.4.1.22.4 Flowchart

See Figure 3.2.7-30 for the CLK flowchart.

3.2.7.4.1.23 Submodule XXIII - CLKEST

3.2.7.4.1.23.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by CLK.
- c. Constraints and limitations - The real-time HAC tasks must be cataloged and resident on the disk.
- d. Processing -
 - 1. Set the error flag false, and clear the task name.
 - 2. Convert the task names to "can" code.
 - 3. Establish the HAC tasks: TOK, TIK, FCP, SUN, BHI, ALM, STS, BHC, CSI, GRF, MMI, CFO, DSK, CSO, CMD, GET, SEQ, EXI, STA, and ALO.

Figure 3.2.7-30 Flowchart - CLK

4. If any HAC real-time task fails to establish, go to step (5). Otherwise, go to step (7).
5. Set the error flag true, and set the task name in a parameter word.
6. Deestablish all the HAC tasks that were established.
7. Return to the calling task CLK.

- e. Error messages and recovery - Parameters returned to the calling task (CLK) for processing, and tasks deestablished.

3.2.7.4.1.23.2 Data, Logic and Command Paths

Input data:

None

Output data:

- a. Error flag; and
- b. Task name.

3.2.7.4.1.23.3 Internal Data Description

The HAC real-time task names are initialized in ASCII code via data statements. The task names are: TOK, TIK, FCP, SUN, BHI, ALM, STS, BHC, CSI, GRF, MMI, CFO, DSK, CSO, CMD, GET, SEQ, EXI, STA, and ALO.

3.2.7.4.1.23.4 Flowchart

See Figure 3.2.7-31 for the CLKEST flowchart.

3.2.7.4.1.24 Submodule XXIV - CLKONL (Timekeeping Initialization)

3.2.7.4.1.24.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call from CLK
- c. Constraints and limitations - Time zones are limited to Pacific and Mountain, both daylight and standard times, and Greenwich Mean Time (GMT).
- d. Processing - CLKONL performs all the work required to initially establish and provide continued maintenance of the GTIMEG array (along with the CLOCK function, 3.2.8.1). Operator inputs nominally include the local time zone and the local year. All

Figure 3.2.7-31 Flowchart - CLKEST

other data is taken from the WWV receiver. In the event the receiver is not operational, the local month, day, hour, and minute, as well as a "mark" will be requested. TIK and TOK are activated, pertinent data is logged, GTIMEG is wholly initialized, and return is made to CLK.

- e. Error messages and recovery - None, except as mentioned in "d." above.

3.2.7.4.1.24.2 Data, Logic and Command Paths

Definitions:

GMT - Greenwich Mean Time, functionally identical to UTC, Universal Coordinated Time.

Local Time - Time kept in the time zone of interest, an integer number of hours offset from GMT.

The GTIMEG array contains all the variables used in time computations, as well as being CLKONL's final output:

<u>Offset in GTIMEG</u>	<u>FORTTRAN Array Index</u>	<u>Contents</u>	<u>Range</u>	<u>Mnemonic</u>
0	1	GMT year	1980 - 2100	GYR
1	2	GMT day of year	1-366	GDY
2	3	GMT hour of day	0-23	GHR
3	4	Minute in hour	0-59	MIN
4	5	Second in minute	0-59	SEC
5	6	Local year	1980- 2100	LYR
6	7	Local month	1-12	LMO
7	8	Local day of month	1-31	LDY
8	9	Local hour of day	0-23	LHR
9	10	Time Quality	0-5	---
10	11	Days in GMT year	365-366	NDY
11	12	Days in local month	28-31	NDM
12	13	Hours offset, local to GMT	0-23	OFF
13	14	Days in local year	365-366	NDL

The algorithm converting GMT to local time is shown in Figure 3.2.7-32 and the converse algorithm in Figure 3.2.7-33.

3.2.7.4.1.24.3 Internal Data Structures

The only internal data structure in CLKONL is the formatted data received from the WWV receiver. It has the format:

<CTLA>DDD:HH:MM:SSQ<CR><LF>

Where <CTLA>, <CR>, and <LF> are the hexadecimal values #1, # , and # respectively; DDD, HH, MM, and SS are numbers, and Q is one of the set "?," "#," "-", "1," and "blank."

3.2.7.4.1.24.4 Flowchart

See Figure 3.2.7-34 for the CLKONL flowchart.

3.2.7.4.1.25 Submodule XXV - CLKACT

3.2.7.4.1.25.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by CLK.
- c. Constraints and limitations - Any task that this submodule activates must have been established as main-memory resident.
- d. Processing -
 1. Set the error flag false, and clear the task name word.
 2. Convert the HAC real-time asynchronous task names to "can" code.
 3. Activate the HAC tasks: CSI and EXI.
 4. If all HAC real-time asynchronous tasks are activated, go to step (7). Otherwise, go to step (5).
 5. Abort the HAC real-time asynchronous tasks that were activated.
 6. Set the error flag true, and set the task name in a parameter word.
 7. If a backup HAC is present, then remotely activate the SWI task in the backup HAC.
 8. If remote activate is successful, then set backup list in CPUSG and go to step (10). Otherwise, go to step (9).

Figure 3.2.7-32 Flowchart - Computation of Local Time

Figure 3.2.7-33 Flowchart - Computation of GMT Parameters

Figure 3.2.7.34 Flowchart - CLKONL

9. Set the error flag true and set the task name in parameter word.

10. Return to the calling submodule.

- e. Error messages and recovery - Parameters are returned to the calling task (CLK) for processing, and tasks are aborted.

3.2.7.4.1.25.2 Data, Logic and Command Paths

Input data:

None

Output data:

- a. Error flag; and
- b. Task name.

3.2.7.4.1.25.3 Internal Data Description

The HAC real-time asynchronous task names are initialized in ASCII code via data statements. The task names are: CSI and EXI.

3.2.7.4.1.25.4 Flowcharts

See Figure 3.2.7-35 for the CLKACT flowchart.

3.2.7.5 Interface Description

The task DIN interfaces with the Disk Data Base, source records from either the magnetic tape or card reader, graphics processors, and the operator via the TI-820 console.

The task DBI interfaces with the Disk Data Base, Prime-Backup HAC configuration, OCS and DAS communications, graphics processors, and the operator via the TI-820 console. DBI also establishes and activates the HAC tasks CLK, RTH, and RTL.

The task CLK interfaces with the WWV device, and the operator for time initialization. Further, CLK establishes the real-time tasks in the Prime HAC and backup HAC. The CLK task activates the tasks in the prime HAC and the switchover task SWI in the Backup HAC.

3.2.7.6 Test Requirements

The Disk Data Base is dumped onto the line printer and verified that the source records are properly initialized. The global common data base is dumped onto the line printer and verified that the data is initialized correctly. The ISC initial state is verified by visual inspection, as is the graphics processors. Real-time task establishment and activation is verified through system status requests from the system console. Error reporting is verified by inputting deliberate errors in source data, and/or device state.

Figure 3.2.7-35 Flowchart - CLKACT

3.2.8 Operating System Modifications Module - MAXIVM

3.2.8.1 Buffer Management Function

Module Identification

The identities of the buffer management modules are:

QINIT
LEASE
FREE
ENQUE
DEQUE
QRST
BMFIF

3.2.8.1.1 Purpose

This group of operating system modules provides two primary user services:

- a. The ability to obtain reusable buffers for short-term use; and
- b. The ability to communicate between tasks, allowing some tasks to be asynchronous and event-driven.

QINIT initializes one or more buffer areas (one call per area) for use by the other services.

LEASE will attempt to acquire a buffer from a buffer area.

FREE will return a LEASE'd buffer to the buffer area pool.

ENQUE will LEASE a buffer and store the given message in it, link it into a queue of messages, and activate the task associated with that queue.

DEQUE will remove the highest item from a queue, pass the message to the caller, and FREE the buffer.

QRST will restart all queues in the event of failover to Backup.

BMFIF is a package which provides FORTRAN access to the above services.

3.2.8.1.2 Requirements

3.2.8.1.2.1 Design Requirements

There are no requirements in the Software/Firmware Functional Requirements document applicable to this function.

3.2.8.1.2.2

Derived Requirements

The ALARMS and other modules require a potentially unlimited number of buffers for message management. The dynamic allocation provided by these modules is deemed the most efficient way of approximating that requirement.

CRT management in previous control systems has been shown to be unwieldy in use. A common message enqueing system is needed to support CRT use satisfactorily.

3.2.8.1.3

Design Approach

3.2.8.1.3.1

Functional Allocations

Basic buffer management (i.e., allocation and deallocation of buffers) is provided by the LEASE and FREE modules. The ENQUE and DEQUE modules provide a moderated message dispatching capability from data sources to data sinks, decoupling their dependence upon each other. They, in turn, call LEASE and FREE to allow dynamic management of their queues.

All services require the initialization of the buffer area provided by QINIT.

3.2.8.1.3.2

Resource Budgets:

	QINIT	LEASE	FREE	ENQUE	DEQUE	QRST	BMFIF
Core requirements: (words)	70	60	40	75	55	50	50
Timing*: (μ secs, nominal estimate)	200	50- 500	100	100- 600	250- 500	100	20/call

*plus system overhead for REX call.

3.2.8.1.4

Design Description

3.2.8.1.4.1

Module Structure

The first seven submodules are stand-alone assemblies designed to be included in the resident portion of the operating system during system generation. They require no other subroutines not provided by the standard operating system itself.

BMFIF will reside in the FORTRAN library.

3.2.8.1.4.1.1

Submodule I - QINIT - Buffer Area Initializer

3.2.8.1.4.1.1.1 Description

- a. Language used - M5A Assembly language.
- b. How invoked - REX call.
- c. Constraints and limitations - No limits on the number or size of areas allowed. The entire area must, however, reside within the caller's address space. If more than one task is to use the area, it must be wholly within a particular global common area.
- d. Processing - The area is initialized for use of the other routines. Queue headers are built, and the lease area cleared.
- e. Error messages and recovery - error indications are returned in the event of invalid input parameters.

3.2.8.1.4.1.1.2 Data, Logic and Command Paths

QINIT must be supplied with the buffer area address, length, and a queue task association table (QTAT). The QTAT associates each queue number (zero to number of queues minus one) with a specific task name.

3.2.8.1.4.1.1.3 Internal Data Description

The initial buffer area configuration is shown in Figure 3.2.8.1.1.

3.2.8.1.4.1.1.4 Flowchart

See Figure 3.2.8.1.2 for the QINIT flowchart.

3.2.8.1.4.1.2 Submodule II - LEASE - Lease a Buffer

3.2.8.1.4.1.2.1 Description

- a. Language used - M5A assembly language
- b. How invoked - REX call.
- c. Constraints and limitations - none
- d. Processing - Beginning from the end of the last leased buffer, the area is searched (with end-of-buffer wrap-around) until a sufficiently large area is found or until the entire area has been searched. If an area is found, it is set in use, any extra being left free. The address is returned to the caller.
- e. Error messages and recovery - error indications are returned for the following conditions:
 - 1. Invalid input parameters.
 - 2. No room for requested buffer.

NOTE: ALL POINTERS ARE ABSOLUTE

Figure 3.2.8.1.1 Internal Buffer Structure

Figure 3.2.8.1.2 Flowchart - QINIT

- 3.2.8.1.4.1.2.2 Data, Logic, and Command Paths
- None.
- 3.2.8.1.4.1.2.3 Internal Data Description
- LEASE uses the same structure initialized by QINIT (Section 3.2.8.1.4.1.1).
- 3.2.8.1.4.1.2.4 Flowchart
- See Figure 3.2.8.1.3 for the LEASE flowchart.
- 3.2.8.1.4.1.3 Submodule III - FREE - Return a LEASE'd Buffer.
- 3.2.8.1.4.1.3.1 Description
- a. Language used - M5A assembly language
 - b. How invoked - REX call
 - c. Constraints and limitations - none
 - d. Processing - FREE forcibly sets the returned block not busy and returns, if it was already in that state. If not, FREE will merge it with any adjacent free blocks. The primary requirement is that at no time should the chain of buffers contain two adjacent free blocks.
 - e. Error messages and recovery - errors are indicated to the user in the event of invalid input parameters, specifically an incorrect returned buffer pointer. No error is indicated if the buffer is found to be already free.
- 3.2.8.1.4.1.3.2 Data, Logic and Command Paths
- None.
- 3.2.8.1.4.1.3.3 Internal Data Description
- Same as QINIT (Section 3.2.8.1.4.1.2.2)
- 3.2.8.1.4.1.3.4 Flowchart
- See Figure 3.2.8.1.4 for the FREE flowchart.
- 3.2.8.1.4.1.4 Submodule IV - ENQUE - Enque a Message and Activate the Associated Task
- 3.2.8.1.4.1.4.1 Description
- a. Language used - M5A assembly language
 - b. How invoked - REX call.

Figure 3.2.8.1.3 Flowchart - LEASE

Figure 3.2.8.1.4 Flowchart - FREE

- c. Constraints and limitations - See paragraph 3.2.8.1.4.1.5...
- d. Processing - a buffer of sufficient size to hold the input message and some queue control words is leased. The user's buffer contents are copied, and the leased buffer is enqueued into the desired queue. If the queue was previously empty, the associated task is activated, which will presumably DEQUE the message.
- e. Error messages and recovery - errors are indicated for the following conditions:
 - 1. No room for buffer LEASE.
 - 2. Invalid input parameter.
 - 3. Influence error (from ACTIVATE).
 - 4. Task not found (from ACTIVATE).
 - 5. No TCB available (from ACTIVATE).

3.2.8.1.4.1.4.2 Data, Logic and Command Paths

None.

3.2.8.1.4.1.4.3 Internal Data Description

The leased buffer is set up in the format shown in Figure 3.2.8.1.5. Null links, in queue items or the queue data areas, are maintained as zeros.

3.2.8.1.4.1.4.4 Flowcharts

See Figure 3.2.8.1.6 for the ENQUE flowchart.

3.2.8.1.4.1.5 Submodule V - DEQUE - Get the Oldest Queued Item

3.2.8.1.4.1.5.1 Description

- a. Language used - M5A Assembly code.
- b. How invoked - REX call.
- c. Constraints and limitations - ENQUE and DEQUE work in concert, attempting to empty queues by activating the tasks which use the queued data. Jammed queues are avoided as long as all the queues which address the same associated task are in the same buffer area.
- d. Processing - If the indicated queue is empty, return is made immediately. The foremost item in the queue is unlinked, and its contents transferred to the caller.

Figure 3.2.8.1.5 Message Structure

Figure 3.2.8.1.6 Flowchart - ENQUE

The area is then FREE'd. If the queue is not empty following this removal, an ACTIVATE of the associated task is done and return made. If the queue is empty, a search is made for any other non-empty queues with the same associated task. If any are found, an ACTIVATE is performed.

e. Error messages and recovery - errors are indicated for the following conditions:

1. Queue requested was empty.
2. Input parameter invalid.
3. Influence error (from ACTIVATE).
4. Task not found (from ACTIVATE).
5. No TCB available (from ACTIVATE).

3.2.8.1.4.1.5.2 Data, Logic and Command Paths

None.

3.2.8.1.4.1.5.3 Internal Data Description

The internal structure is the queue, described in 3.2.8.1.4.1.4.3.

3.2.8.1.4.1.5.4 Flowchart

See Figure 3.2.8.1.7 for the DEQUE flowchart.

3.2.8.1.4.1.6 Submodule VI - QRST - Restore Queue Activations

3.2.8.1.4.1.6.1 Description

- a. Language used - M5A assembly language
- b. How invoked - REX call
- c. Constraints and limitations - may cause spurious activations of queues which did not require restart. All tasks which DEQUE items should check for zero length returns, indicating nothing left in the queue, and exit as a result.
- d. Processing - QRST will scan the queues within a buffer area, activating all tasks whose queues are non-empty.
- e. Error messages and recovery - errors returned include invalid input parameters, and the activation errors: no TCB available; influence limit error; and task not found.

Figure 3.2.8.1.7 Flowchart - DEQUE

3.2.8.1.4.1.6.2 Data, Logic and Command Paths

Data structures as discussed in QINIT call.

3.2.8.1.4.1.6.3 Internal Data Description

None

3.2.8.1.4.1.6.4 Flowchart

See Figure 3.2.8.1.8 for the QRST flowchart.

3.2.8.1.4.1.7 Submodule VII - BMFIF - FORTRAN Interface to Buffer Management

3.2.8.1.4.1.7.1 Description

- a. Language used - M5A assembly language
- b. How invoked - FORTRAN calls
- c. Constraints and limitations - None
- d. Processing - For each of the entry points, the parameters are gathered and a REX call to the appropriate function made. Upon return, parameters are passed and return made to the caller.
- e. Error messages and recovery - The FORTRAN routine error package is invoked when unexpected errors occur. These return a "FER" error code, with subcode "QXn", where "n" indicates the error:

- n = 0 - Task not found
- n = 1 - Influence error
- n = 2 - Parameter error
- n = 3 - Buffer area invalid
- n = 4 - No room available
- n = 5 -
- n = 6 -
- n = 7 - No TCB available

3.2.8.1.4.1.7.2 Data, Logic and Command Paths

None

3.2.8.1.4.1.7.3 Internal Data Description

None

3.2.8.1.4.1.7.4 Flowchart

See Figure 3.2.8.1.9 for the BMFIF flowchart.

3.2.8.1.5 Interface Description

3.2.8.1.5.1 QINIT

See Figure 3.2.8.1.10.

Figure 3.2.8.1.8 Flowchart - QRST

Figure 3.2.8.1.9 Flowchart - BMFIF

R15 - LENGTH OF THE COMMON BUFFER AREA IN WORDS (N);
 R14 - ADDRESS OF THE BUFFER AREA;
 R13 - ADDRESS OF THE QUEUE-TASK ASSOCIATION TABLE (SEE BELOW);
 R12 - NUMBER OF QUEUES TO BE SET UP IN THE BUFFER AREA (NQ)

$$N > = (NQ * 4) + 9;$$

LDI,R8 QINIT(#6A)
 REX,MAXIV
 RETURNED CONDITION CODES:

NZOC = '1000 -> NO ERROR, NORMAL RETURN.
 NZOC = '0010 -> PARAMETER ERROR.

THE QUEUE-TASK ASSOCIATION TABLE ASSOCIATES THE QUEUE NUMBERS
 (FROM 0 THROUGH NQ-1) TO SPECIFIC TASKS WHICH WILL BE ACTIVATED
 BY NAME WHEN A MESSAGE IS ENQUEUED IN THE ASSOCIATED QUEUE.
 IT HAS THE FORMAT:

	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
0: 1:	TASK NAME ASSOCIATED WITH QUEUE 0 1-6 CHARS, CAN CODE															
2: 3:	TASK NAME ASSOCIATED WITH QUEUE 1															
.	.															
.	.															
.	.															
(NQ-1)*2: (NQ-1)*2+1:	TASK NAME ASSOCIATED WITH QUEUE N-1															

Figure 3.2.8.1.10 Interface Specification for QINIT

3.2.8.1.5.2 LEASE

See Figure 3.2.8.1.11.

3.2.8.1.5.3 FREE

See Figure 3.2.8.1.12.

3.2.8.1.5.4 ENQUEUE

See Figure 3.2.8.1.13.

3.2.8.1.5.5 DEQUEUE

See Figure 3.2.8.1.14.

3.2.8.1.5.6 QRST

See Figure 3.2.8.1.15.

3.2.8.1.5.7 BMFIF

See Figure 3.2.8.1.16.

3.2.8.1.6 Test Requirements

Testing will be performed with test drivers and by data structure inspection. Since the number of cases to be tested is relatively limited, this is deemed sufficient.

R14 - LOCATION OF THE BUFFER AREA, AS PASSED TO QINIT.

R15 - SIZE OF BUFFER REQUIRED (IN WORDS).

LDI,8 LEASE (#6B)

REX,MAXIV

R14 - ABSOLUTE ADDRESS OF THE BUFFER.

CONDITION CODES AS FOLLOWS:

NZOC = '0010 ->	PARAMETER ERROR.
NZOC = '0100 ->	NO ROOM LEFT IN THE BUFFER AREA.
NZOC = '1000 ->	NO ERROR, NORMAL RETURN.

Figure 3.2.8.1.11 Interface Specification for LEASE

R14 - BUFFER AREA ADDRESS, AS PASSED TO QINIT.

R15 - ADDRESS OF THE BLOCK TO BE FREED (AS GIVEN BY LEASE)

LDI,8 FREE (#6C)

REX,MAXIV,32

RETURNED CONDITION CODES:

NZOC = '1000	->	NO ERROR.
NZOC = '0010	->	PARAMETER ERROR

Figure 3.2.8.1.12 Interface Specification for FREE

R12 - WORD ADDRESS OF BUFFER CONTAINING MESSAGE.

R13 - QUEUE NUMBER (0 - NQ-1) FOR DESIRED QUEUE.

R14 - BUFFER AREA ADDRESS, AS PROVIDED TO QINIT.

R15 - LENGTH OF MESSAGE TO BE ENQUED, IN WORDS.

LDI,8 ENQUE (#6D)

REX,MAXIV

RETURNED CONDITION CODES ARE:

NZOC = '1000	->	NORMAL RETURN.
NZOC = '0100	->	NO ROOM FOR MESSAGE IN BUFFER AREA.
NZOC = '0010	->	PARAMETER ERROR.
NZOC = '0001	->	INFLUENCE ERROR (SEE ACTIVATE).
NZOC = '0000	->	TASK NOT FOUND.
NZOC = '0111	->	NO TCB AVAILABLE.

Figure 3.2.8.1.13 Interface Specification for ENQUE

R13 - QUEUE NUMBER (0 - NQ-1).

R14 - BUFFER AREA ADDRESS, AS PASSED TO QINIT.

R15 - USER'S BUFFER ADDRESS TO RECEIVE MESSAGE.

LDI,8 DEQUE (#68)

REX,MAXIV

R14 - RETURNS LENGTH OF THE MESSAGE (IN WORDS).

CONDITION CODES ON RETURN:

NZOC = '1000	->	NO ERROR, NORMAL RETURN.
NZOC = '0100	->	QUEUE WAS EMPTY.
NZOC = '0010	->	PARAMETER ERROR.
NZOC = '0001	->	INFLUENCE ERROR.
NZOC = '0000	->	TASK NOT FOUND.
NZOC = '0111	->	NO TCB AVAILABLE.

Figure 3.2.8.1.14 Interface Specification for DEQUE

R13 - QUEUE NUMBER (0 - N-1)

R14 - BUFFER AREA ADDRESS, AS PASSED TO QINIT.

LDI,8 QRST (#6F)

REX,MAXIV

CONDITION CODES ON RETURN:

NZOC = '1000	->	NO ERROR, NORMAL RETURN.
NZOC = '0010	->	PARAMETER ERROR.
NZOC = '0001	->	INFLUENCE ERROR.
NZOC = '0000	->	TASK NOT FOUND.
NZOC = '0111	->	NO TCB AVAILABLE.

Figure 3.2.8.1.15 Interface Specification for QRST

CALL QINI (BUFFR,ISIZE,NQ,ITAB)

where:

BUFFR - the area to be used for buffer management;
ISIZE - length (in words) of the area;
NQ - number of queues to be managed;
ITAB - an INTEGER*4 table containing a six-character
task name (in CAN code) in each 4-byte entry.
The length of ITAB is NQ.

LOGICL = LEAS (BUFFR,NEEDSZ,BUFRTD)

where:

BUFFR -- same as above;
NEEDSZ - required buffer size, in words;
BUFRTD - the returned subscript of the buffer leased
within BUFFR;
LOGICL - .TRUE. if lease was successful.

CALL FRE (BUFFR,BUFRTD)

where both are as described in LEAS.

LOGICL = ENQU (BUFFR,LOCBUF,ISIZE,IQ)

where:

BUFFR - as above;
LOCBUF - address of message to be enqueued;
ISIZE - length (in words) of LOCBUF;
IQ - queue number ($0 \leq IQ \leq NQ$) into which to enqueue
the message;
LOGICL - .TRUE. if successful.

CALL DEQU (BUFFR,LOCBUF,KSIZE,IQ)

where:

BUFFR - as above;
LOCBUF - buffer to receive the next message;
KSIZE - returned length of the message passed (zero
if nothing in queue);
IQ - the queue number from which to get the next
message.

Figure 3.2.8.1.16 Interface Specification for BMFIF

3.2.8.2 "Clock" Function

3.2.8.2.1 Purpose

This function will maintain a stable and accurate universal base within the global common area of memory. This (global common) time base may be accessed by any of the various tasks which are components of the heliostat system.

3.2.8.2.2 Requirements

3.2.8.2.2.1 Design Requirements

Section 3.1 of the 10 MWe Software/Firmware Functional Requirements Specification states the following requirement for the "Clock" function:

Maintain a stable time base.

Inasmuch as the apparent position of the sun is an important assumption of other requirements in the Software/Firmware FRS, it is assumed that a "stable time base" means an accurate representation of UTC (Universal Coordinated Time, same as GMT).

3.2.8.2.2.2 Derived Requirements

Section 3.2.1.8 of the 10 MWe Software/Firmware Functional Requirements Specification derives the following requirement:

Universal time maintenance, using the WWVB Clock as a reference standard.

In order to fulfill both of the Software/Firmware Functional Requirements Specification requirements, we derive the following:

- a. The primary requirement is to provide accurate maintenance of the time data base;
- b. This module, in order to assure accuracy, will execute at the highest software priority level allocated to heliostat system tasks;
- c. This module must be capable of detecting and reporting input errors which may be generated by the WWV device or the hardware which interfaces with that device;
- d. In the event of a WWV device error or failure, this module must be capable of maintaining (unassisted) a stable and accurate time base;

- e. In the event of a WWV device error or failure, the module must allow the operator, after correcting the problem, to place the device back on line;
- f. This module is, by nature, time critical and, therefore must be coded as efficiently as possible in order to maintain accuracy and minimize system overhead; and
- g. Local time (i.e., zone time at the operational location) must be maintained.

3.2.8.2.3 Design Approach

3.2.8.2.3.1 Functional Allocations

The "Clock" function consists of two component tasks:

- a. Task TOK, which provides/ensures alignment of system and WWV time; and
- b. Task TIK, which provides maintenance of global common time values and triggers the FCP task into execution each second.

3.2.8.2.3.2 Resource Budget

This program, when executing, will require use of the following system resources:

- a. Software priority levels: TIK - Very high
 TOK - First priority below
 synchronous loop tasks
- b. Core/solid state memory: 400₁₀ words (approximate)
- c. Asynchronous input device: 1 Model 4811 (1 subchannel)
- d. WWV receiver: 1

3.2.8.2.4 Design Description

3.2.8.2.4.1 Module Structure

This function consists of two component tasks; the interaction of which is graphically represented in Figure 3.2.8.2.1

3.2.8.2.4.1.1 TOK - Major Interval Timer

Figure 3.2.8.2.1 Clock Module, Component Task Interaction

3.2.8.2.4.1.1.1 Description

- a. Language used - MODCOMP MAC assembly language with MAX IV REX calls.
- b. How invoked - Activated by CLKONL (in DBINIT module).
- c. Constraints and limitations - NONE
- d. Processing - The major timer synchronizes the data base time to the WWV receiver time. Once a minute, TOK is reactivated, reads the WWV receiver (if it is on line), resumes TIK, updates the data base, and resets itself for execution again in one minute. An alarm is issued in the event that the time quality factor received from the WWV device changes.

TIK & TOK interact in such a way that if the WWV device is operating correctly, the time in GTIMEG at any instant is accurate to within the limits (+10.0, + 150 msec), excluding the WWV device quality error limit (specified below). This accuracy is made possible by the fact the TRU-TIME WWV receiver transmits the time to the CPU on the second. TOK opens a read, then checks 100msec intervals until the IO is complete. It then resumes TIK and communicates that fact to TIK via a bit (TIKTOK) in CPUSG. TIK, immediately reschedules itself one second later, and is now synchronized. A timing diagram of the interaction shows the best/worst case:

worst case = 14 + 99 + 3 = 116msec

best case = 14 + 3 = 17msec

If at anytime the WWV device becomes inoperable, an alarm is issued and timekeeping becomes internal. The device is still read each minute, however, and if the device becomes operable, will revert to normal operation.

- e. Error messages and recovery - None besides internal timekeeping.

3.2.8.2.4.1.1.2 Data, Logic and Command Paths

The useful output of TOK is the global common array GTIMEG. It is an integer array of the form:

<u>Address</u>	<u>Data</u>	<u>System</u>	<u>Range</u>
GTIMEG + 0	Year	GMT	1980 - ∞
+ 1	Day-of-year	GMT	1-366
+ 2	Hour	GMT	0-23
+ 3	Minute	GMT	0-59
+ 4	Second	GMT	0-59
+ 5	Year	Local	1980 - ∞
+ 6	Month	Local	1-12
+ 7	Day-of-Month	Local	1-31
+ 8	Hour	Local	0-23
+ 9	Time Quality	--	0-5*
+10	Days in GMT year	--	365-366
+11	Day in Local Month	--	28-31
+12	Hours offset GMT-local	--	0-23
+13	Spare		

NOTE: GMT is Universal Coordinated Time. Local time is local zone time, offset from GMT by an integer number of hours.

In addition, bit two of TBUSYG is set to one when TOK is executing and reset at exit. The TIKTOK bit (0) in CPUSG facilitates TIK-TOK communications.

*Values of indicator are:

<u>Value</u>	<u>Possible Error</u>
0	.001 sec
1	.001 sec
2	.005 sec
3	.050 sec
4	.500 sec
5	time internal

3.2.8.2.4.1.1.3 Internal Data Description

The only internal data items are a variable which maintains the status (up/down) of the WWV device, and the WWV buffer, which receives the time from the receiver as an ASCII string of the form:

<CTLA> DDD:HH:MM:SSQ <CR><LF>

where <CTLA> is Hex 1, <CR> is Hex D, and <LF> is Hex A.
"Q" is a time quality indication character.

3.2.8.2.4.1.1.4 Flowcharts

See Figure 3.2.8.2.2 for the TOK flowchart.

3.2.8.2.4.1.2 TIK - Minor Interval Timer

3.2.8.2.4.1.2.1 Description

- a. Language used - FORTRAN
- b. How invoked - Activated by CLKONL (in DBINIT module).
- c. Constraints and limitations - None
- d. Processing - TIK is resumed once a second by a MAX IV delay REX. Upon resumption, time in GTIMEG is advanced once second. If FCP is inactive, it is resumed.
- e. Error messages and recovery - None

3.2.8.2.4.1.2.2 Data, Logic and Command Paths

See Section 3.2.8.2.4.2.2 for description of the global data base affected by TIK.

Bit three of TBUSYG is used to indicate TIK activity, bit 0 in CPUSG indicates that TOK forceably resumed TIK.

3.2.8.2.4.1.2.3 Internal Data Description

There is no data internal to this function.

3.2.8.2.4.1.2.4 Flowchart

See Figure 3.2.8.2.3 for the TIK flowchart.

3.2.8.2.5 Interface Description

TIK and TOK have a single hardware interface (the WWV receiver) and several software interfaces (the GTIMEG array, TBUSYG bits, and alarms). All have been detailed above.

Local time accuracy, as reflected in GTIMEG, presumes that GTIMEG has been initialized correctly at some time previous.

Time is maintained to well within ± 1 second as long as the WWV device is available (see processing above). On internal mode timekeeping, system clock drift (guaranteed to within 45 seconds per day, or about .05%) may occur.

Figure 3.2.8.2.2 Flowchart - TOK

Figure 3.2.8.2.3 Flowchart - TIK

Figure 3.2.8.2.3 Flowchart - TIK (Cont'd)

3.2.8.2.6 Test Requirements

A special test program, THACK, will alias as FCP (triggered by TIK) and allow the current values of GTIMEG to be displayed for comparison to the WWV clock.

Testing TIK and TOK should be for an extended period (approximately 12 hours) on both computers, both with and without the WWV receiver in operation.

3.2.8.3 Receiver Trip

3.2.8.3.1 Purpose

The Receiver Trip function will keep a bit in the global data base (herein identified as the receiver trip bit (RTBIT)) updated, reflecting the status of the receiver trip signal. It will also alert MMI whenever the signal is raised.

3.2.8.3.2 Requirements

3.2.8.3.2.1 Design Requirements

Paragraph 3.3.1.1.5 of the Software/Firmware Functional Requirements Specification states:

"The HAC receives two signals (one the inverse of the other) from the Receiver System. One signal causes an emergency Defocus action; its inverse will allow an operator Defocus-Release action."

3.2.8.3.2.2 Derived Requirements

Assume that the signals mentioned are TTL compatible logic levels, one indicating (when high) that the Defocus action is required; the other (when high) that the release is possible.

The Receiver Trip module shall keep the RTBIT bit current, thus allowing the command interface to validate any Defocus Release command. Receiver Trip shall also inform MMI explicitly of the signal transition of receiver trip to high state (force Defocus).

The signals indicating receiver trip and its inverse will probably be noisy and subject to contact bounce; therefore, a signal will not be said to exist unless it is still detected .5 seconds after it is first sensed.

3.2.8.3.3 Design Approach

3.2.8.3.3.1 Functional Allocations

There will be three parts to the receiver trip module : two tasks and an initialization routine. Each of the two signals will be wired to separate external interrupt levels in the MODCOMP CPU (levels #8 & #9). The initialization routine (further described in the DBINIT module) will CONNECT the interrupt levels to the handlers, enable the interrupts, check for proper state initialization, and report trip status.

3.2.8.3.3.2 Resource Budgets

Priority Level - 30 (RTH)
- 30 (RTL)
Memory - 200 words
Timing - less than 500 microseconds/activation
Hardware Interrupts- 2

3.2.8.3.4 Design Description

3.2.8.3.4.1 Module Structure

The Receiver Trip module consists of two interrupt activated submodules. One submodule is activated when the receiver trips and the other is activated when the receiver returns to normal.

3.2.8.3.4.1.1 Submodule I - RTH

3.2.8.3.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - When interrupt occurs on hardware level #8.
- c. Constraints and limitations - The receiver signals that are wired to the MODCOMP interrupt levels must be opposite for tasks RTH and RTL to successfully operate. If they are both high, the system will "hang" in a high priority loop. If they are both low, neither RTH or RTL will be activated.

The R/T signal must persist for at least .5 seconds before it will be recognized.
- d. Processing - Upon activation, the RTH bit in TBUSYG is set, and interrupt level #8 is frozen. The time of day in ticks (5msec each) is computed. The difference between that time and the time saved in RTHTIM is computed, and tested for being greater than 750msec. If it is, a 500msec delay is executed, level #8 thawed again, the time is saved in RTHTIM, and exit taken.

If the time difference was less than 750msec, a valid R/T signal has been detected. RTBIT in CPUSG is set, and the R/T init bit (RTIBIT) is tested. If zero (i.e., we are initializing) it is set to 1. If not, and this is the prime machine, a RTDEFocus command is enqueued to MMI. Level #9 is thawed, time is saved in RTHTIM, the RTH bit in TBUSYG is reset, and exit taken.
- e. Error Messages and Recovery - None

3.2.8.3.4.1.1.2 Data, Logic and Command Paths

Input data:

Global common word CPUSG

Output data:

Global common words CPUSG, TBUSYG

RTBIT - receiver trip state - 0 - receiver trip signal low
 1 - receiver trip signal high

RTIBIT - initialization successful flag - 0 - receiver not operational
 1 - receiver operational

3.2.8.3.4.1.1.3 Internal Data Description

RTHTIM is 32 bit time of day in ticks at last interrupt.

3.2.8.3.4.1.1.4 Flowchart

See Figure 3.2.8.3.1

3.2.8.3.4.1.2 Submodule II - RTL

3.2.8.3.4.1.2.1 Description

- Language Used - FORTRAN
- How Invoked - When interrupt occurs on hardware level #9.
- Constraints and Limitations - Same as RTH
- Processing - Upon activation, the RTL bit in TBUSYG is set, and interrupt level #9 is frozen. The time of day in ticks (5msec each) is computed. The difference between that time and the time saved in RTLTIM is computed, and tested for being greater than .75 sec. If it is, a 500msec delay is executed, level #9 thawed again, the time is saved in RTLTIM, and exit taken.

If the time difference was less than 750msec, a valid R/T -NOT signal has been detected. RTBIT in CPUSG is reset, and RTIBIT is set. Level #9 is thawed, time is saved in RTLTIM, the RTL bit in TBUSYG's reset, and exit taken.

- Error Messages and Recovery - None

3.2.8.3.4.1.2.2 Data, Logic and Command Paths

Input data:

Global common word CPUSG (See 3.2.8.3.4.1.1.2)

Output data:

Global common words CPUSG, TBUSYG

3.2.8.3.4.1.2.3 Internal Data Description

The 32 bit integer RTLTIM is a tick counter to record time of last call to RTL.

3.2.8.3.4.1.2.4 Flowchart

See Figure 3.2.8.3.2

3.2.8.3.5 Interface Description

The CPU connection for all external interrupts is a twelve pin connector, as shown below (receptacle as seen on panel):

An interrupt is activated by connecting one of the add numbered pins to ground (as through a contact closure). The even numbered pins are all grounded. The add pins, and their corresponding interrupt levels, are:

<u>Pin</u>	<u>Level</u>
1	n/c
3	#B
5	#A
7	#9
9	#8
11	#7

Each interrupt's circuitry:

Figure 3.2.8.3.2 Flowchart - RTL

reveals that the interrupts are inverted logic, TTL levels, pulled up into the inactive state internally. If the switch is left closed, the interrupt will fire again every time it is cleared and reenabled. The software interfaces are two: The RTBIT and RTIBIT bits shall reside in global common, accessible to all, and the RTH task shall deliver the ASCII message "DEFOCUS" to the MMI module through the REX service "ENQUE", through queue number 0.

3.2.8.3.6

Test Requirements

Testing shall be performed to test the reaction of the Receiver Trip module in the following cases:

<u>Condition</u>	<u>Expected Results</u>
Both signals low	Error message from initialization
RT high, RTNOT low	DEFOCUS on, command to MMI on transition
RTNOT high, RT low	DEFOCUS off

3.2.8.4 Switching Function

3.2.8.4.1 Purpose

The purpose of the switching function is to prepare and maintain the data bases in the backup machine in the event of switchover. It must monitor switchover criteria and initiate and control switchover when it does occur. The switching function is comprised of one task SWI which in turn utilizes two submodules (SWIR60 for reading the global data base and SWIINT, to initiate and perform switchover processing) and a failover interrupt handler.

3.2.8.4.2 Requirements

3.2.8.4.2.1 Design Requirements

The following paragraph from the 10 MWe Software/Firmware Functional Requirements Specification (FRS) states the basic switching requirement:

"3.1.d. Maintain a "Backup" system by providing redundant field communications and providing data transfer sufficient to allow one-way "Backup" fail-over with minimal degradation;"

3.2.8.4.2.2 Derived Requirements

The FRS further states:

- "3.2.1.8 f. Monitor status between computers to determine if the "Backup" should take over;
- g. Perform peripheral switching when necessary;"

Functionally, these three requirements from the FRS may be restated:

- a. Establish and maintain communications such that the backup system is able to perform the complete HAC task with minimum disruption in the event of switchover;
- b. Sense failure of the prime system and initiate and control CPU and peripheral switchover; and
- c. Prevent interference from a failed prime system.

3.2.8.4.3 Design Approach

3.2.8.4.3.1 Functional Allocations

To accomplish the required processing, the switching function consists of a single task called SWI and a failover interrupt handling routine.

Designation of which HAC is prime and which is backup and initial transfer of the global common data base is done during DBI execution (refer to DBI paragraph 3.2.7-19).

The SWI task executes once each second transferring the global common data base from the primary HAC to the backup HAC and checking for the occurrence of a switchover condition.

The failover interrupt handler will halt the primary HAC once a switchover has been initiated.

3.2.8.4.3.2 Resource Budget

Code - SWI and handler - 2000 words

Timers - SWI will use one.

3.2.8.4.4 Design Description

3.2.8.4.4.1 Module Structure

The SWI task is a standalone task in the backup HAC with two submodules SWIRGD and SWIINT. The failover interrupt handler is loaded as part of the MAXNET operating system.

3.2.8.4.4.1.1 Submodule I - SWI Task

3.2.8.4.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - The SWI task is established by the DBI task in the backup HAC and remotely activated by the submodule CLKACT of the CLK task in the primary HAC after the activating the asynchronous tasks.
- c. Constraints and limitations - The switching task performs switching in only one way; after switchover is performed, no further action is performed.
- d. Processing - The SWI task is a periodic task which executes in the backup HAC once each second to read the global common data base from the primary HAC and update the backup HAC data base.

The global common data base is initially transferred to the backup HAC by the submodule DBIBCK of the DBINET module. The global common data base is divided into three basic types:

- a. Data to be transferred once each second;
- b. Data to be transferred once every 8 seconds; and
- c. Data to be transferred once at initialization.

3.2.8.4.4.1.1.3 Internal Data Description

Miscellaneous pointers and variables

3.2.8.4.4.1.1.4 Flowcharts

See Figure 3.2.8.4.1 for the SWI flowchart.

3.2.8.4.4.1.2 Submodule II - Subroutine SWIRGD

3.2.8.4.4.1.2.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by task SWI once each second
- c. Constraints and limitations - The submodule SWIRGD will send all the one second portion of global common and approximately 1/8 of the 8 second portion of global common.
- d. Processing - When invoked by the SWI task, the SWIRGD module will loop through the one second global common areas and the next portion of the eight second global common and initiate reads to the coredevices in the primary HAC. Each read operation will be timed according to the size of the global common area.

If any read errors occur, an error indicator will be set and returned to the SWI task.

Once the reads are completed, the local buffers that hold the data just read will be transferred to the backup global common data base.

- e. Error messages and recovery - An error condition will exist if any read errors occur during the coredevice reads. No error messages will be output directly from SWIRGD, but an error flag will be set for the SWI task.

3.2.8.4.4.1.2.2 Data, Logic and Command Paths

Input data:

- a. The global common transferred from the primary HAC into SWIRGD's local buffers.
- b. Use file table for I/O operations.

Output data:

- a. The global common data transferred to the backup HAC data base.
- b. Error flag indicator.

Figure 3.2.8.4.1 Flowchart - SWI

3.2.8.4.4.1.2.3 Internal Data Description

- a. The local buffers to hold the global common data base.
- b. Table of coredevice names for reading global common areas.
- c. Miscellaneous pointers and variables.

3.2.8.4.4.1.2.4 Flowcharts

See Figure 3.2.8.4.2 for SWIRGD flowchart.

3.2.8.4.4.1.3 Submodule III - Subroutine SWIINT

3.2.8.4.4.1.3.1 Description

- a. Language used - FORTRAN
- b. How invoked - Called by the SWI task to initiate a HAC switchover.
- c. Constraints and limitations - None
- d. Processing - Upon being called by the SWI task the SWIINT subroutine will initiate the processing required to startup the backup HAC. These processing steps are:
 - 1. Set bit in CPUSG to indicate that a switchover has occurred and that the backup HAC is now prime.
 - 2. Send interrupt to the primary HAC to halt its processing.
 - 3. Command PCIs to gain control of the peripherals.
 - 4. Activate the asynchronous and synchronous tasks in the backup HAC.
 - 5. If all tasks got activated, then go to step (7). Otherwise, go to step (6).
 - 6. Notify operator of the activation error and ask if a retry is desired, if so go to step (4). Otherwise, go to step (8).
 - 7. Check if any sequences were active in the primary HAC. If so then send a notification message (enqueue) to the sequence task and go to step (8).
 - 8. Return to calling task.
- e. Error messages and recovery - An error message will be output if the HAC tasks fail to activate. The operator

Figure 3.2.8.4.2 Flowchart - SWIRGD

will be queued if a retry is desired and if so the activations will be retried. Otherwise, the sub-routine will return to the SWI task.

3.2.8.4.4.1.3.2 Data, Logic and Command Paths

Input data:

SEQNMG in global common to detect if sequences were active at the time of switchover.

Output data:

- a. Interrupt to the primary HAC (interrupt level #7)
- b. Enqueue message to the SEQ task as notification that sequences were active in the primary HAC when the switchover occurred.
- c. Global common word CPUSG.

3.2.8.4.4.1.3.3 Internal Data

Miscellaneous variables and pointers.

3.2.8.4.4.1.3.4 Flowcharts

See Figure 3.2.8.4.3 for SWIINT flowchart.

3.2.8.4.4.1.4 Failover Interrupt Handler

3.2.8.4.4.1.4.1 Description

- a. Language used - M5A Assembly Language
- b. How invoked - Directly Connected Interrupt (Level #7)
- c. Constraints and limitations - None
- d. Processing - The failover interrupt is sent by the SWI task in the backup CPU to the prime CPU to indicate that it has taken over the prime's functions and causes the prime CPU to drop out of the control system.
- e. Error messages and recovery - None

3.2.8.4.4.1.4.2 Data, Logic and Command Paths

None

3.2.8.4.4.1.4.3 Internal Data Description

There is no data internal to this function.

3.2.8.4.4.1.4.4 Flowchart

See Figure 3.2.8.4.4 for the Failure Interrupt Handler flowchart.

Figure 3.2.8.4.3 Flowchart - SWIINT

Figure 3.2.8.4.4 Flowchart - Failover Interrupt Handler

3.2.8.4.5

Interface Description

The primary interface with the other software modules is via bit 15 of the global common word SWOVG which indicates to the SWI task if a switchover is desired by the primary HAC.

Also bits in CPUSG will be used to indicate which HAC is primary or backup and if a switchover has occurred.

Hardware interface for the PCS interrupt handler for demanding control of the peripherals is via the MAXNET operating system.

3.2.8.4.6

Test Requirements

Testing of the SWITCH function shall be performed through failing of various hardware components during integration testing. In particular, correct functioning will be verified in the following cases:

- a. Failed prime CPU;
- b. Failed backup CPU;
- c. Failed 4824 output (from prime CPU);
- d. Failed 4824 input (to prime CPU);
- e. Failed field communications in prime CPU; and
- f. External setting of the prime CPU's FS bit in CPUSG.

3.2.8.5 Field Power Loss

3.2.8.5.1 Purpose

The Field Power Loss (FPL) function will keep a bit in the global data base (herein identified as FPLBIT) updated, reflecting the status of the field power loss signal. It will also alert SEQ whenever the signal is raised, if any sequences are in progress.

3.2.8.5.2 Requirements

3.2.8.5.2.1 Design Requirements

Paragraph 3.2.1.8 of the Software/Firmware Functional Requirements Specification states:

- h. Detect a power loss signal and store this information in the data base for information to all tasks.

3.2.8.5.2.2 Derived Requirements

Assume that the signals mentioned are TTL compatible logic levels, one indicating (when high) that field power loss has occurred; the other (when high) that power is restored.

The Field Power Loss Module shall keep in FPLBIT in CPUSG the current status of the field power loss (FPL) signal, thus allowing all modules to know the field power state at anytime. Field Power Loss shall also explicitly alert the command sequencer task (SEQ) when field power is lost and transfer the contents of HCST1G to PWHC1G.

The signals indicating field power loss and its inverse will probably be noisy and subject to contact bounce; therefore a signal will not be said to exist unless it is still detected .5 seconds after it is first sensed.

3.2.8.5.3 Design Approach

3.2.8.5.3.1 Functional Allocations

There will be three parts to the field power loss module: two tasks and an initialization routine. Each of the two signals will be wired to separate external interrupt levels in the MODCOMP CPU (levels #A & #B). The initialization routine (further described in the DBINIT module) will CONNECT the interrupt levels to the handlers, enable the interrupts, check for proper state initialization, and report FPL status.

3.2.8.5.3.2

Resource Budgets

Priority Levels	- 30 (PLH), 30 (PLL)
Memory	- 200 words
Timing	- less than 500 microseconds/activation
Hardware Interrupts	- 2

3.2.8.5.4

Design Description

3.2.8.5.4.1

Module Structure

The Field Power Loss Module consists of two interrupt activated submodules. One submodule is activated when FPL is detected and the other is activated when the field power returns to normal.

3.2.8.5.4.1.1

Submodule I - PLH

3.2.8.5.4.1.1.1

Description

- a. Language Used - FORTRAN
- b. How Invoked - When interrupt occurs on hardware level #A.
- c. Constraints and Limitations - The FPL signals that are wired to the MODCOMP interrupt levels must be opposite for tasks PLH and PLL to successfully operate. If they are both high, the system will "hang" in a high priority loop. If they are both low neither PLH or PLL will be activated.

The FPL signal must persist for at least .5 seconds before it will be recognized.

- d. Processing - Upon activation, the PLH bit in TBUSYG is set, and interrupt level #A is frozen. The time of day in ticks (5msec each) is computed. The difference between that time and the time saved in OLDTIM is computed, and tested for being greater than 750msec. If it is, a 500msec delay is executed, level #A thawed again, the time is saved in PLHTIM, and exit taken.

If the time difference was less than 750msec, a valid FPL signal has been detected. FPLBIT in CPUSG is set, and the FPL init bit (FPIBIT) is tested. If zero (i.e., we are initializing), it is set to 1. If not, and this is the prime machine, the status array HCST1G is copied to PWHClG, and if sequences are in progress, the Field Power Loss message is enqueued to SEQ. Level #B is thawed, time is saved in PLHTIM, the PLH bit in TBUSYG is reset, and exit taken.

- e. Error Messages and Recovery - None

3.2.8.5.4.1.1.2 Data, Logic and Command Paths

Input data:

Global common words CPUSG, SEQNMG, and array HCST1G.

Output data:

Global common words CPUSG, TBUSYG, and array PWHC1G.

FPIBIT - Initialization

successful flag: 0 - field power sensing not operational

1 - field power sensing operational

FPLBIT - Field power loss state:

0 - power OK;

1 - power down

3.2.8.5.4.1.1.3 Internal Data Description

The 32 bit integer PLHTIM has tick time of last call.

3.2.8.5.4.1.1.4 Flowchart

See Figure 3.2.8.5.1

3.2.8.5.4.1.2 Submodule II - PLL

3.2.8.5.4.1.2.1 Description

a. Language Used - FORTRAN

b. How Invoked - When interrupt occurs on hardware level #B

Figure 3.2.8.5.1 Flowchart - PLH

- c. Constraints and Limitations - Same as PLH
- d. Processing - Upon activation, the PLL bit in TBUSYG is set, and interrupt level #B is frozen. The time of day in ticks (5msec each) is computed. The difference between that time and the time saved in PLLTIM is computed, and tested for being greater than 750msec. If it is, a 500msec delay is executed, level #B thawed again, the time is saved in PLLTIM, and exit taken.

If the time difference was less than 750msec, a valid FPL-NOT signal has been detected. FPLBIT in CPUSG is reset, and the FPL init bit (FPIBIT) is set. Level #B is thawed, time is saved in PLLTIM, and exit taken.

- e. Error Messages and Recovery - None

3.2.8.5.4.1.2.2 Data, Logic and Command Paths

Input data:

Global common word CPUSG (See 3.2.8.5.4.1.1.2)

Output data:

Global common words CPUSG, TBUSYG

3.2.8.5.4.1.2.3 Internal Data Description

The 32 bit integer PLCTIM contains the time in ticks of the last call.

3.2.8.5.4.1.2.4 Flowchart

See Figure 3.2.8.5.2

3.2.8.5.5 Interface Description

The hardware interface consists of connection of the proper TTL signals to the HAC, (see 3.2.8.3.5). The software interfaces are two: The FPLBIT and FPIBIT bits shall reside in global common, accessible to all, and the PLH task shall deliver the power loss message to the SEQ module through the REX service "ENQUE", through queue number 10.

3.2.8.5.6 Test Requirements

Testing shall be performed to test the reaction of the Field Power Loss module in the following cases:

<u>Condition</u>	<u>Expected Results</u>
Both signals low	Error message from initialization
FPL high, FPLNOT low	FPIBIT on, message to SEQ if sequence in progress
FPLNOT high, FPL low	FPLBIT off

Figure 3.2.8.5.2 Flowchart - PLL

3.2.9 Graphics Display Processor Module (GRAPHC)

3.2.9.1 Purpose

The purpose of the Graphics Display Processor Module (GRAPHC) is to provide the functional interface with the Chromatics CG1999 intelligent color graphics systems in a command/response protocol. This module is software structured into one task (GRF) consisting of three submodules. GRAPHC includes the following functions:

- a. Reading requests from the Graphics processor and returning data to support the current display; and
- b. Reading messages from the Graphics requesting a High-Wind Stow or Defocus.

3.2.9.2 Requirements

3.2.9.2.1 Design Requirements

Software Requirements listed in Section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification (FRS) dated 12 June 1980 that apply to the GRAPHC module are:

- a. Control of up to 2048 heliostats in all modes required to operate the heliostats;
- b. Monitor and display the operational status of all heliostats;
- c. Provide graphic displays of the heliostat field or field segments; and
- d. Provide data transfer to the Chromatics Graphics Terminals sufficient for display of a finite number of graphic displays of the heliostat field or field segments and supporting alphanumeric information.

3.2.9.2.2 Derived Requirements

Section 3.2.1.9 of the FRS, states the following requirements for the Graphics Display Processor Module (GRAPHC):

- a. Provide the functional interface with the graphics system in a command/response protocol;
- b. Provide the graphics system with sufficient data for graphics displays;
- c. Accept High-Wind Stow (STHIWIND) and DEFOCUS commands from the CS control room graphics function switches;

- d. Output data to the Chromatics Graphics Terminals only when requested; and
- e. Interface with the Chromatics Graphics Terminals through two distinct Dual Asynchronous Communication Channels (#4811).

3.2.9.3

Design Approach

The Graphics Display Processor (GRAPHC) is composed of one asynchronous task (GRF) which is activated by the External Interface Module (EXTINF) or by self activation (via DEQUE). Figure 3.2.9-1 displays the functional interface diagram of the two Chromatics CG1999 graphic systems, the External Interface Module, the Man-Machine Interface Module, and the subject Graphics Display Processor Module. Command messages originate in the Chromatics CG1999 and are read by the External Interface Module. The External Interface Module checks for an emergency command from the CS control room graphics console and, upon receipt, the emergency command is placed into the Man-Machine Interface emergency command queue. Otherwise, the incoming message is source tagged and queued for the Graphics Display Processor. The command messages received by the Graphics Display Processor are shown in Tables 3.2.9-I through 3.2.9-IV. Detailed discussion of these messages and their resultant action by the Graphics Display Processor is given in the following subsection. Figure 3.2.9-2 exhibits the functional allocation of the graphics task (GRF) into three submodules.

3.2.9.3.1

Functional Allocation

GRAPHC is comprised of three submodules. The basic purpose of each submodule is briefly described in the following paragraphs:

- a. GRF (Graphics Display Processing Task) - dequeues a command message from the graphic's queue, and determines the message's source and type. The message type indicates what action GRF is to perform, and the source indicates where to send the action taken. Listed below are the message types received and the action taken:
 - 1. Message type 1 (Table 3.2.9-I) - Emergency High-Wind Stow (WTHIWIND) or DEFOCUS command from the Engineering Evaluation Room results in establishing an ASCII error message (Table 3.2.9-V) for the requesting source.
 - 2. Message type 2 (Table 3.2.9-II) - Resetting the Chromatics Terminal results in establishing a reset message (Table 3.2.9-VI) for the requesting Chromatics Processor.

Figure 3.2.9-1 GRAPHC Functional Interface Diagram

Table 3.2.9-I GDC-HAC GDC Command

MESSAGE LAYOUT

APPLICATION : GDC-HAC

MESSAGE TYPE : GDC Command

PROGRAMMER : D. Pettit

DATE : June 9, 1980

1	Header Byte	1	1 = High-wind stow or defocus (ASCII)
			ASCII Message byte count = 14 ₁₀
5		5	ASCII
	Emergency		Position 4-13 contain either:
	Message		G10STH1000 or,
			G10DEF0000.
10		10	
			NOTE: Byte positions 4-13 contain
			the emergency message for
			MANMIF in the expected format
15		15	
20		20	
25		25	
30		30	

Table 3.2.9-II GDC-HAC GDC Command
MESSAGE LAYOUT

APPLICATION: GDC - HAC

MESSAGE TYPE: GDC Command

PROGRAMMER: D. Pettit

DATE: June 9, 1980

1	Header Byte	1	→ 2 = Reset
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

Table 3.2.9-III GDC-HAC GDC Command

MESSAGE LAYOUT

APPLICATION: GDC - HAC

MESSAGE TYPE: GDC Command

PROGRAMMER: D. Pettit

DATE: June 9, 1980

1	Header Byte	1	→ 3 = Full field or segment
			→ ASCII Message byte count
5	Segment Number	5	→ Position 4-6 contains segment number being displayed. Segment number 000 implies a full field display.
10		10	
15		15	
20		20	
25		25	
30		30	

Table 3.2.9-IV GDC-HAC Command

MESSAGE LAYOUT

APPLICATION : GDC-HAC

MESSAGE TYPE : GDC Command

PROGRAMMER : D. Pettit

DATE : June 9, 1980

Figure 3.2.9-2 Functional Allocation of the GRF Task

Table 3.2.9-V. HAC-GDC Text Message to GDC

MESSAGE LAYOUT

APPLICATION : HAC-GDC

MESSAGE TYPE : Text message to GDC

PROGRAMMER : D. Pettit

DATE : June 10, 1980

Table 3.2.9-VI HAC-GDC Graphics Initialization

MESSAGE LAYOUT

APPLICATION : HAC-GDC

MESSAGE TYPE : Initialize Graphics

PROGRAMMER : D. Pettit

DATE : June 10, 1980

1	Header byte	1	4 - Set graphics terminal ID
	Terminal ID		Bit 0=1, Bits 1-7 binary 4 ₁₀
			• Bit 0=1, Bits 1-7 binary value where
			0 = CS Control Room
			1 = Engineering Evaluation Room
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

3. Message type 3 (Table 3.2.9-III) - Request status information for either a full-field display or a segment display, results in establishing either a full-field status message (Table 3.2.9-VII) or a segment status message (Table 3.2.9-VIII) - A segment number of zero implies send a full-field status; otherwise the segment number states which segment display is active. Pointers, counters, and source indicators are initialized to support the graphics request.

Note that the above three commands do not result in any direct output to the graphics processors, but they establish the response to be output upon receipt of the next message.

4. Message type 4 (Table 3.2.9-IV) - Send the next data or text stream to the Graphics Display Processor. Receipt of this message results in output being sent to the requesting graphics terminal. If a full-field status was requested, submodule GRFFLD is called to output the one-eighth of field status from the global common array, GRSTSG. If an individual segment status was requested, the submodule GRFSEG is called to output the status information required to support the currently active segment display. Otherwise a text message is output to the graphics.

This submodule dequeues one and only one command per activation. This implies that upon activation only one of the two graphics terminals will receive data, but only when the dequeued message is a type 4 command (send next message).

- b. GRFFLD-submodule supplies status for one-eighth of a full field. Formal parameters indicate for which one-eighth of the field to send status information, and another formal parameter specifies the destination. This submodule extracts status information from the global common array GRSTSG and packs it into the message format shown in Table 3.2.9-VII. After the message is formatted, it is output to the requesting graphics processor.
- c. GRFSEG - submodule supplies status data for the presently active segment display. Inputs, via the formal parameter list, are the total number of heliostats for status-ing, starting pecking-order number, source designator, and the segment number. The total number of heliostats must be positive and less than or equal to 21. The pecking-order number must be positive and less than or

MESSAGE LAYOUT.

MESSAGE TYPE : HAC Full Field Status

DATE : June 9, 1980

equal to 50, and the segment number must be a valid segment designator. This submodule uses the formal parameters to process the segment's heliostats through the segment-to-heliostat mapping arrays, SEGPTG and SEGMPG. Once the heliostat number is obtained from the mapping, the present azimuth angle is obtained from the array AZIMG and the elevation angle is obtained from the array ELEVG. The present aim-point values and designator are obtained from the global array AIMPTG. The present status is obtained from the global common array GRSTSG. After all the information for a heliostat is collected, it is formatted and placed into the message format shown in Table 3.2.9-VIII. This procedure repeats for the total number of heliostats requested. When the entire message is built, it is output to the requesting graphics processor.

3.2.9.3.2 Resource Budgets

GRAPHIC uses approximately 2000 (estimated) words of memory. It is a low-priority module in the HAC system. It requires two Chromatic 1999 intelligent graphics consoles each interfaced to the MODCOMP through individual 4811s. One message queue is required to interface with the External Interface Module.

3.2.9.4.1.1 Submodule I - GRF (task)

3.2.9.4.1.1.1 Description

- a. Language used - FORTRAN
- b. How invoked - Activated by Enque in External Interface Module (EXTINF) or Deque in Graphics Display Module (GRAPHIC).
- c. Constraints and limitations - To support a segment graphics display, this task requires up to three activations to supply the full data stream.
- d. Processing -
 1. Set TBUSYG bit for Graphics and, dequeue a message from the Graphics Processor.
 2. Store the device number N, and store the message type number in local variables.
 3. If the message type number is one, set message code 1 word for device N, and go to step (32). Otherwise, go to step (4).
 4. If the message type number is two, set message

Table 3.2.9-VIII HAC-GDC HAC Segment Status

MESSAGE LAYOUT

APPLICATION: HAC-GDC

MESSAGE TYPE : HAC Segment Status

PROGRAMMER: D. Pettit

DATE June 9, 1980

1	Header Byte	1	2 = Segment updating
	SEGMENT AIM #		bit 0=1, bits 1-7 binary 2 ₁₀
	Pecking Order #		bit 0=1, bits 1-7 binary value
	HC Status		bit 0=1, bits 1-7 binary value
5	High order Az bits	5	bit 0=1, bits 1-7 binary value
	low order Az bits		bit 0=1, bits 1-7 are bits 0-6 of Az word
	High order El bits		bit 0=1, bits 1-7 are bits 7-13 of Az word
	low order El bits		same format as azimuth
10	AIM POINT (NORTH)	10	bit 0=1, bits 1-7 are bits 4-10 of AP bit 0=1, bits 1-7 are bits 11-17 of AP
	AIM POINT (EAST)		same format as North Aim Point
	AIM POINT (UP)		same format as North Aim Point
15	same format as above 12 bytes for the next HC in pecking order (shown in dashed line on left)	15	
20		20	Repeat up to 21 total HCs in pecking order (less than 258 bytes)
25		25	
30		30	

- code 2 word for device N, and go to step (32). Otherwise, go to step (5).
5. If the message type number is three, go to step (6); otherwise, go to step (14).
 6. Get the segment number from types 4 to 6 of the message.
 7. If the segment number is zero, set message code 4 word and clear message code 3 word, both for device N. Set the one-eighth of field counter to one for device N, and go to step (). Otherwise, go to step (8).
 8. Get the number of HCs in the segment from global common.
 9. If the number of HCs is zero or the segment number is invalid, go to step (32). Otherwise, go to step (10).
 10. Set the number of HCs sent to zero for device N.
 11. Set message code 3 word and clear message code 4 word, both for device N.
 12. Retrieve the segment aim-point number from global common.
 13. Store the aim-point number for device N, and go to step (32).
 14. If the message type number is four, go to step (15); otherwise, go to step (32).
 15. If message code word 1 is set for device N, write an error message to device N, clear message code word 1 for device N, and go to step (32). Otherwise, go to step (16).
 16. If message code word 2 is set for device N, write the graphics reset message to device N, clear message code word 2 for device N, and go to step (32). Otherwise, go to step (17).
 17. If message code word 3 is set for device N, go to step (18); otherwise, go to step (29).
 18. Compute the number of HCs to send data for (number of HCs minus the number of HCs data output for), for device N.
 19. If the number of HCs to send data for is greater than 21, go to step (20); otherwise, go to step (24).

20. Compute the starting pecking-order number for device N.
21. Increment the number sent by 21 for device N.
22. Set the number to output to 21 for device N.
23. Set the corresponding HC numbers for device N into a buffer, and go to step (28).
24. Set the number to output equal to the number to send for device N.
25. Set the number sent for device N to zero.
26. Set the HC numbers for device N into a buffer.
27. Compute starting pecking-order number.
28. Call subroutine GRFSEG to output the segment display data for up to 21 HCs, and go to step (32).
29. Call subroutine GRFFLD to output one-eighth of the full-field status to graphics processor device N.
30. Increment the one-eighth of field counter for device N.
31. If the one-eighth of field counter is greater than or equal to eight, set the one-eighth of field counter to one, and go step (32). Otherwise, go to step (32).
32. Clear TBUSYG bit and EXIT this task.

- e. Error messages and recovery - Invalid segment number display requests result in no data output from this task. Receipt of a High-Wind Stow or Defocus command results in the error message:

EMERGENCY COMMAND NOT ALLOWED FROM THIS CONSOLE

An invalid message type from either graphics processor results in no data output to the graphics processor.

3.2.9.4.1.1.2

Data, Logic and Command Paths.

Input data:

Graphic's messages from message queue tagged with a source code.

Output data:

- a. Reset message to a graphics processor; and

- b. ASCII text message to graphics processor.

Global Common:

- a. SEGMPG (segment mapping); and
- b. SEGPTG (segment pointer).

3.2.9.4.1.1.3 Internal Data Description

Two-word arrays are utilized to keep track of the internal command codes, counters, and buffers, and the two words correspond to the two graphics processors. The ASCII test message is initialized in a Data Statement, and most of the reset message is initialized in a Data Statement.

3.2.9.4.1.1.4 Flowchart

See Figure 3.2.9-3 for the GRF flowchart.

3.2.9.4.1.2 Submodule II-GRFSEG

3.2.9.4.1.2.1 Description

- a. Language used - Fortran
- b. How invoked - Subroutine call by GRF
- c. Limitations and constraints - Output buffer can only accommodate segment-display data for up to 21 helio-stats.
- d. Processing -
 - 1. Fill word 1 of the message buffer with the Header byte and aim-point number byte. Set the leading byte bits on.
 - 2. Initialize two counters, I (HC counter) equal to one, and J (message word counter) equal to two.
 - 3. Fill message word J with the pecking-order number and HC status. Set the leading byte bits on.
 - 4. Fill message word J+1 with the high-order azimuth bits and the low-order azimuth bits. Set the leading byte bits on.
 - 5. Fill message word J+2 with the high-order elevation bits and the low-order elevation bits. Set the leading byte bits on.

Figure 3.2.9-3 Flowchart - GRF

Figure 3.2.9-3 Flowchart - GRF (continued)

Figure 3.2.9-3 Flowchart - GRF (continued)

6. Fill message word J+3 with the north aim-point. Set the leading byte bits on.
7. Fill message word J+4 with the east aim-point. Set the leading byte bits on.
8. Fill message word J+5 with the up aim-point. Set the leading byte bits on.
9. Increment the message word counter J by six, and increment the HC counter by one.
10. If the number of HCs is greater than the counter I, go to step (3). Otherwise, go to step (11).
11. Write the message buffer to the graphics processor (device N).
12. Return to the calling submodule.

e. Error messages and recovery - None

3.2.9.4.1.2.2

Data, Logic and Command Paths

Input Data:

- a. Aim-point number;
- b. Pecking-order starting number;
- c. HC numbers in an array;
- d. Number of HCs to supply data for; and
- e. Number of device to write message to.

Output data:

HAC segment status message

Global common used:

- a. AIMPTG (aim points);
- b. AZIMG (azimuth angle);
- c. ELEVG (Elevation angle); and
- d. GRSTSG (heliostat status).

3.2.9.4.1.2.3

Internal Data Description

Bit masks are utilized to extract bits from the aim-points and

azimuth and elevation angles. The UFT array used by the output routine, WRITE, is initialized in Data Statements, except word I, the device-dependent word. A 258-byte message buffer is allocated.

3.2.9.4.1.2.4 Flowcharts

See Figure 3.2.9-4 for the GRFSEG flowchart.

3.2.9.4.1.3 Submodule III-GRFFLD

3.2.9.4.1.3.1 Description

- a. Language used - FORTRAN
- b. How invoked - Subroutine call by GRF
- c. Constraints and limitations - The one-eighth of field requested must be in the range one to eight.
- d. Processing -
 1. Retrieve the status words for the one-eighth of the field and store into a 256-word buffer.
 2. Fill message word one with the header byte and the one-eighth of field value. Set the high-order byte bits on. Initialize two counters I (HC counter) equal to one, and J (message and count) to two.
 3. Set bits 0 and 8 of message word J.
 4. If the i'th word of the status buffer is equal to -1, set the i'th word of the status buffer to HEX 7F00, and go to step (5). Otherwise, go to step (5).
 5. Shift status buffer word I left 8 places to put the value in the high-order byte.
 6. If the i'th+1 word of the status buffer is -1, set the status buffer word to Hex 007F, and go to step (7). Otherwise, go to step (7).
 7. Add status buffer word I and status buffer word I+1 to message word J, and store the results in message word J.
 8. Increment the counter J by one and I by two.
 9. If I is greater than or equal to 257, go to step (10). Otherwise, go to step (3).
 10. Call subroutine WRITE to output the message to graphics processor N.

Figure 3.2.9-4 Flowchart - GRFSEG

11. Return to the calling submodule.

e. Error messages and recovery - None

3.2.9.4.1.3.2 Data, Logic and Command Paths

Input data:

- a. One-eighth of field (range 1 to 8); and
- b. Graphics processor device number.

Output data:

HAC full-field status message

Global common:

GRSTSG (heliostat status)

3.2.9.4.1.3.3 Internal Data Description

Variables for the Hex values 007F, 7F00, and 8080 are initialized in Data Statements. A 256-word buffer and a 129-word are allocated for use. The UFT array is initialized in a Data Statement, except word 1, the device-dependent word.

3.2.9.4.1.3.4 Flowchart

See Figure 3.2.9-5 for the GRFFLD flowchart.

3.2.9.5 Interface Description

The task GRF interfaces with the External Interface Module (EXTINF) (Figure 3.2.9-1) via the task CSI. CSI enqueues messages from the graphics processors and GRF dequeues these messages. GRF outputs directly to the graphics processors with data messages. These message formats are shown in Tables 3.2.9-I to 3.2.9-VIII.

3.2.9.6 Test Requirements

Construct field status arrays, write the data to the graphics processors and visually inspect the color display for verification.

Figure 3.2.9-5 Flowchart - GRFFLD

3.2.10 External Interface Module - EXTINF

3.2.10.1 Purpose

The External Interface Module is responsible for maintaining the communication interface between the HAC computer and various external sources of I/O. These sources include the following:

- a. OCS computer;
- b. DAS computer;
- c. ISC console (CS control console);
- d. Graphics console 1 (CS control room); and
- e. Graphics console 2.

The EXTINF module is divided into the following submodules:

- a. External Interface (EXI) - task which is responsible for communicating with the OCS and DAS computers via the MAXNET operating system;
- b. Console Input (CSI) - task which is responsible for accepting inputs from the ISC and the two graphics terminals and sending these as messages to the responsible tasks; and
- c. Console Output (CSO) - task responsible for outputting to the ISC for the BCSMOD, MANMIF and STATUS modules.

3.2.10.2 Requirements

3.2.10.2.1 Design Requirements

Section 3.1 of the Software/Firmware Functional Requirements Specification states the following requirements for the EXTINF module:

- a. Maintain command/response protocol and data transfer with the OCS;
- b. Provide status data to the DAS; and
- c. Monitor and display the operational status of all heliostats.

3.2.10.2.2 Derived Requirements

Section 3.2.1.10 of the Software/Firmware Functional Requirements Specification states the following derived requirements for the External Interface Module:

- a. Interface with the CS Control Console by:

1. Accepting inputs and passing these inputs to the respective modules.
 2. Regulating the outputs to the CRT so that only one submodule is outputting at a time.
- b. Interface with the Chromatics Terminals by:
1. Pass emergency STHIWIND and DEFOCUS commands to MANMIF module.
 2. Data requests to the GRAPHIC module.
- c. Interface with the OCS computer by accepting commands; and
- d. Interface with the DAS by accepting status requests.

Additional derived requirements include:

- a. The requirement of interfacing with the Chromatics and CS control console implies the need for performing I/O to these devices; and
- b. Outputting to the CS control console implies a need to establish a message interface between the CSO task and the BCSMOD, MANMIF, and STATUS modules.

3.2.10.3

Design Approach

The External Interface module, to facilitate communications with the various external sources, is divided into tasks logically split into MAXNET and non-MAXNET interfaces. These external sources consist of the OCS, DAS and backup HAC computers, the CS control console, and the two Chromatics Graphics Terminals. The MAXNET capabilities are used to communicate with the OCS, DAS and backup HAC computers. The EXI task associated with the OCS/DAS interface is responsible for input messages from those computers. The EXI task processes messages from the OCS/DAS computers at a rate of one message from either computer per second. To maintain status on the backup HAC, the EXI task will request task status information once each second for the SWI task.

There are two tasks associated with communications with the CS consoles and Chromatics Graphic Terminals. The CSI task is responsible for processing input from these consoles and activating the responsible module to process the input. The CSO task is responsible for outputting to the CS control console. User tasks wishing to display information on the CS control console queue messages to the CSO task.

3.2.10.3.1

Functional Allocations

To accomplish the required processing, the External Interface Module consists of submodules EXI, CSI, and CSO (see Figure 3.2.10-1). A brief description of the function performed by each of these submodules is given below.

Figure 3.2.10-1 External Interface Module

- a. EXI - This task performs the processing required to support the communications interface with the OCS DAS and backup HAC computers. The command/response protocol between the computers is supported via the MAXNET operating system. Data transfer between the CS and the OCS, DAS and backup HAC computers is accomplished using the MAXNET capabilities to read and write data between computers.
- b. CSI - The CSI task interfaces with the ISC 8001G color graphic terminal and the two Chromatics Graphics Terminals. This task is responsible for inputting either operator commands from the ISC terminal or data messages from the Chromatic Terminals and queueing the message to the appropriate task for processing.
- c. CSO - The CSO task is responsible for outputting status messages and operator response messages to the ISC console.

3.2.10.3.2 Resource Budgets

- a. Memory required (estimated): 3K of resident memory;
- b. Mass storage (disk, tape) required: None; and
- c. Task Priority: The CSI task shall be of priority just above MANMIF. The CSO task shall be of priority just below MANMIF. The EXI task priority is below CSO.

3.2.10.4 Design Description

3.2.10.4.1 Module Structure

CSI and CSO are tasks associated with inputting and outputting to the CS control console and Chromatics Graphics Terminals. The EXI task communicates with the OCS and DAS computers.

3.2.10.4.1.1 Submodule I - CSI Task (Main Routine)

3.2.10.4.1.1.1 Description

- a. Language used - MODCOMP FORTRAN IV
- b. How invoked - Activated by DBINIT during system initialization. Active throughout the operation of the CS computer.
- c. Constraints and limitations - The CSI task inputs one character at a time from the operator's console.
- d. Processing - When activated, the CSI task opens input

buffers for the CS console and the two Chromatics Graphics Terminals via a REX Read. After initiating the read operations, the CSI task executes a REX I/O Wait, suspending itself until one of the input operations completes.

The MAX IV operating system will resume the CSI task upon completion of one of the input buffers. Upon being resumed, the CSI task examines all the input buffers to see which one has completed. If the ISC console buffer completed, the CSI console will move the first character input to an internal buffer and reinitiate another character-read operation. The character just read is then written back to the CS console to display the character to the operator.

If the character was a carriage return or if 80 characters have been input, signaling the end of an input, the CSI task will examine the internal buffer for an emergency command. An emergency command is queued to the MMI task's emergency queue; others go to the CS operator command queue.

Input buffers received from the Chromatics Graphics Terminals will be given to the GRF task for processing with an indicator of which graphics console sent the input.

A check is made of the input buffer for the Chromatics terminal in the CS control room to determine if the input was an emergency command. If an emergency command was found, the command is queued to the MMI task's emergency queue.

- e. Error messages and recovery - The only errors which occur are I/O errors during communication with the various consoles. When an I/O error is found, a error message is output to the operator indicating which interface is in error and the UFT is output for diagnostic purposes.

3.2.10.4.1.1.2. Data, Logic and Command Paths

- a. The input data from the consoles;
- b. The error status from the MAX IV (MAXNET) operating system; and
- c. CRTWDG word in global common.

Output data:

- a. Input message sent to the responsible task; and
- b. Global common word CRTWDG.

3.2.10.4.1.1.3

Internal Data Description

- a. 3 User File Tables (UFTS) for input buffers;
- b. 2 1-word task names;
- c. 1 40-word internal buffer for building ISC messages;
- d. 4 2-word tables to hold the ASCII representations of the emergency commands; and
- e. Miscellaneous pointers and indices.

3.2.10.4.1.1.4

Flowchart(s)

See Figure 3.2.10-2 for the CSI flowchart.

3.2.10.4.1.2

Submodule II - CSO Task

3.2.10.4.1.2.1

Description

- a. Language used - MODCOMP FORTRAN IV
- b. How invoked - Invoked via an Rex Enque call by either the MMI, BCS, CFO, DSK, or STA tasks when an output to the ISC console is required.
- c. Constraints and limitations - Only one output line (maximum of 80 characters) can be queued at a time. If the first bit in the first word is set on "C," the output message is placed in the conversational area (lines 17 thru 45) of the screen. Otherwise, it is assumed the output buffer contains the appropriate control characters.
- d. Processing - When the CSO task is activated, it will deque the message sent and place it into an internal buffer. A check is made to determine if the output is to be placed into the conversational area on the CS control console.

If the message is to the conversational area, the appropriate control characters are added to the buffer and a write operation performed on the line indicated by the global common CRTWDG. Otherwise, the buffer is output to the ISC console as specified by the enqueueing task.

When the write is complete, CSO will exit and await further activations. Before each write is initiated, a flag is checked in global common to determine if an input operation has been initiated. If the flag is set, the CSO task relinquishes CPU control until the bit is cleared, at which time the output is performed.

Figure 3.2.10-2 Flowchart - CSI

Figure 3.2.10-2 Flowchart - CSI (Continued)

- e. Error message and recovery - When an I/O error is detected for the write operation, an error message will be output. The error message that is typed is:

"CS CONSOLE OUTPUT ERROR:

and the UFT is output for diagnostic purposes.

3.2.10.4.1.2.2 Data, Logic and Command Paths

Input data:

- a. Includes the output message queued by the MMI, STA, CFO, DSK and BCS tasks;
- b. The CS console word in global common for the CRT usage flag, (bit 0 in CRTWDG);
- c. CRT line number, (bits 8 - 15 in CRTWDG); and
- d. BCSLNG (global common indicates the number of lines BCSMOD is using).

Output data:

CRTWDG word in global common.

3.2.10.4.1.2.3 Internal Data Description

- a. 1 User File Table (UFT) for the output buffer to the ISC;
- b. 1 internal buffer for holding the output message; and
- c. Miscellaneous internal pointers.

3.2.10.4.1.2.4 Flowchart(s)

See Figure 3.2.10-3 for the CSO flowchart.

3.2.10.4.1.3 Submodule III - EXI Task

3.2.10.4.1.3.1 Description

- a. Language used - MODCOMP, FORTRAN IV
- b. How invoked - Activated in the prime HAC by CLK upon system startup. In the backup the SWI task activates the EXI task upon HAC failover.
- c. Constraints and limitations - The EXI task will accept and process one message per intercomputer interface per second (i.e. one message from the OCS, one message from the DAS each second, and one interrogation of the backup HAC)

Figure 3.2.10-3 Flowchart - CSO

- d. Processing - When activated the EXI task builds (via calls to the system routine BLOUFT) the user file tables (UFT's) that are required to perform the input operations for the OCS and DAS interfaces. Once this is done, then 80 byte read buffers are opened to each interface.

The core device concept as defined in the MODCOMP MAXNET III/IV User's Guide is used to communicate with the OCS and DAS computers. There are core devices resident in the OCS and DAS computers which contain the 80 byte messages for the HAC. The EXI function will indicate reads to the core devices and the delay one sec for these reads to complete. When resumed the EXI task will check the UFT for indication of I/O completion. Error checking will be done and if none are found, the message is queued to the MMI task into the appropriate (emergency, OCS or DAS) queue.

After the EXI task has completed the OCS/DAS interface processing it will request from the backup HAC task status information for the SWI task. This enables the Prime HAC to maintain the current operability status of the backup HAC. The request is made using the MAXNET special service request REMTFO. If the SWI task is established and active in the backup HAC, the backup bit in CPUS6 is set to one. Otherwise, the backup bit is cleared (set to zero) and an alarm queued to the operator via a call to the ALMQUE submodule of ALM.

- e. Error messages and recovery - Errors detected during the read operations to the OCS or DAS computer result in an error message to the operator indicating which interface has the error and the UFT is output for diagnostic purposes. If a failure is detected in the backup HAC a critical alarm is raised at the CS console.

3.2.10.4.1.3.2 Data, Logic and Command Paths

Input data:

- a. 80 byte commands from the OCS and DAS computers
- b. Task status from backup HAC via MAXNET

Output data:

- a. Commands to MMI
- b. EXI bit in TBUSY6
- c. Remote task information request

3.2.10.4.1.3.3 Internal Data Description

- a. Two user file tables (each 8 words long)
- b. Two 80 byte buffers to accept messages
- c. Various internal pointers
- d. One seven word buffer to hold returned task status

3.2.10.4.1.3.4 Flowchart

See Figure 3.2.10-4 for the EXI flowchart.

3.2.10.5 Interface Description

a. Data Base Input:

CRTUSG-CRT usage flag
CRTLNG-CRT line index
BCSLN6-BCS line usage indicator

b. Data Base Output:

CRTUSG-CRT usage flag
CRTLNG-CRT line index
TBSY6-task active flags

- c. Physical Output - Includes the write operation from the CSO task to the ISC terminal and the single-character buffer written by the CSI task.
- d. Physical Input - The read buffers associated with the ISC console (CS control console), the two Chromatics Graphic Terminals and the OCS, DAS, and backup HAC computers. The input from the ISC terminal is a one-character buffer. The input buffers from the graphics terminals are 10 words in length. (See Section 3.2.9 of the Software Design Specification.) The input from the OCS/DAS computers are a maximum of 80 bytes. The response to the remote task information request is a seven word buffer.
- e. CSI is activated by DBINIT and CSO is activated by MMI, BCS, DSK, CFO, or STA tasks via Rex Enque.
- f. Messages sent from CSI to GRF are appended with a graphics console index either zero or one. This is used to indicate from which console the input came.
- g. Messages sent to the CSO task have the control characters required to place the output line in the desired location. Exception is made when the first bit of the first word is set. Then the output message is placed on the next available line as indicated by the global common word CRTLNG.

Figure 3.2.10-4 Flowchart - EXI

Figure 3.2.10-4 Flowchart - EXI (Continued)

Figure 3.2.10-4 Flowchart - EXI (Continued)

- h. Task CSI activates MMI or GRF.
- i. The interface between the BCSMOD and CSI/CSO tasks consists of the BCSLN6 word which contains the number of lines that the BCSMOD requires when it is active. CSI and CSO will check this word to insure that commands entered and outputs to conversational area of the ISC do not violate the area reserved for BCSMOD.
- j. The EXI task is activated by CLK in the prime HAC or by SWI if a HAC failover occurs. The EXI task will activate the MMI task by sending messages via the REX enqueue.

3.2.10.6

Test Requirements

- a. Verification of the ISC input and output will be done by operator key-in of various commands and observing the output on the CS control console.
- b. Verification of the Chromatics Graphic Terminal will be done by observing the updated screen displays.
- c. Logic of CSO and CSI will be verified by using MAX IV DEBUG. This system utility allows selective execution of code, tracing and memory modification.
- d. The EXI task will be verified by entering commands on one OCS console and observing them displayed on the ISC and implemented accordingly.
- e. The EXI to DAS interface will be verified by observing data transmissions between the DAS and HAC via the DEBUG processor.

3.2.11 BCS Automatic Processing Module - BCSMOD

3.2.11.1 Purpose

The purpose of this module is to implement an automatic method of cycling through heliostats in the field for beam characterization measurements. The results of these measurements can be used to calculate and update heliostat bias values for improving tracking accuracies. This module consists of one task which uses several submodules to control three phases of BCS operation:

- a. Initialization by operator;
- b. Automatic sequencing; and
- c. Updating of biases.

3.2.11.2 Requirements

3.2.11.2.1 Design Requirements

Software Requirements listed in Section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980, that apply to the BCSMOD module are:

- a. Control of up to 2048 heliostats in all modes required to operate the heliostats.

This requirement is only partially applicable to BCSMOD, as only some of the heliostats need to be controlled and only some of the modes (i.e.: TRACK, STANDBY, BCSTRACK, ALT2STOW, and STOW) are to be used.
- b. Detect, report, and respond to failures and irregularities.

Only BCS failures and irregularities are to be detected and reported.
- c. Maintain a "Prime" and "Backup" system, as well as redundant field communications.

For BCSMOD this was interpreted to mean only that it would operate from beginning to end in either computer, but not be capable of switching from "Prime" to "Backup" during BCS operations.
- d. Maintain safe beam control.

Certain restrictions defined further in the CS-MCS and CS Plant Interface Requirements apply to BCS beam pointing.
- e. Respond to receiver trip for emergency defocus.

This requirement only applies to BCSMOD when it is trying to return heliostats to their original mode which might have been TRACK.
- f. Maintain command/response protocol and data transfer with the OCS.

This only applies to "BCS" messages.

- g. Provide automatic control of beam characterization within the HAC.

This is the major BCS requirement.

Additional requirements that apply to the BCSMOD module are listed in Section 3.4 of the CS-MCS and CS-PLANT INTERFACE REQUIREMENTS (RADL ITEM 2-3-1) (dated October 1980) and are summarized below:

- a. Input three files from magnetic tape defining up to 60 heliostats to be measured per file and up to 5 heliostats to be moved out of the reflected beam path of the first heliostat.
- b. Display and select one of the three files and select the range of heliostats to be measured (first and last).
- c. Cycle through the selected heliostats by moving up to four (one per BCS target) at a time and their blocking heliostats as well. For each step in the (sub)-sequences OCS issues a message to BCS and at the completion of that step, BCS responds to OCS.
- d. Results include bias calculation, displays and logging of both.
- e. The BCSMOD module must be able to input manual offset data, calculate new biases, and update them.

3.2.11.2.2 Derived Requirements

Section 3.2.1.11 of the Software/Firmware Functional Requirement Specification (June 12, 1980) lists the following derived requirements for the BCSMOD module:

- a. Give the operator selection flexibility by using three different heliostat lists;

This implies no character online editing is necessary. Range of heliostats in list selection is required.

- b. Provide start capability of the automatic sequence that does not require further operator input;
- c. Execute control of a list of up to 60 heliostats and up to five blocking heliostats associated with each heliostat to be measured;
- d. Execute control over these measurements using up to four BCS targets in parallel;
- e. Communicate with the OCS for BCS measurements and offset values;
- f. Provide operator feedback for error in automatic sequences; and

- g. Calculate azimuth and elevation bias changes using OCS measured centroid offsets from up to three BCS measurements.

Up to three BCS measurements per heliostat can be evaluated.

Additionally, the BCSMOD module must be able to:

- a. Return heliostats to their original modes after measurements have been completed or after an alarm condition has been detected in the subsequence;
- b. Continue sequences that incur alarm conditions, but abort the subsequence causing the alarm;
- c. Store and access three files of BCS heliostat lists in either "Prime" or "Back up" computers;
- d. Execute special operator commands passed along by the MANMIF module. These commands and their parameters are listed in Table 3.2.11-I;
- e. Put heliostats in the standby mode after putting them on the BCS target in response to a BCS-6 message or after a BCS-8 message if DEFOCUS is in progress and the heliostat was in the track mode prior to the subsequence; and
- f. Put heliostats in the track mode upon completion of a subsequence if it was in that mode prior to the subsequence.

3.2.11.3 Design Approach

BCSMOD is designed to operate in the software/hardware environment of the 10 MWe Phase II HAC on a minimal coupling (interfacing with existing modules) basis.

The following is a list of assumptions used in the design of the BCSMOD module:

- a. The major assumption is that BCSMOD is to provide an automatic service to the OCS/BCS operation that requires minimal operator intervention on the collector subsystem side.
- b. Assumption "a" implies, on a more detailed level, that errors and problems will be reported, but the software will not wait for an operator to act. Instead it will go on to the next subsequence, if possible.
- c. Assumption "b" implies that a CS operator cannot "fix" a problem and expect it to be considered again by the software. Such cases would have to be handled by starting new BCS sequences.

COMMAND	PARAMETERS	DESCRIPTION	RESTRICTIONS
<u>BCS</u> START	None	Start (Activate) BCS Task	Valid when BCS task not active.
<u>BCS</u> MTAPE	None	Copy 3 magnetic tape files to disk partition	Valid command after BCS is active and prior to <u>BCS</u> RANGE.
<u>BCS</u> DISP	File Number (1-3) ON or OFF	Display file summary on control console (ISC-CRT). For dynamic feedback during auto-sequencing.	Valid and necessary after <u>BCS</u> MTAPE or <u>BCS</u> START and prior to <u>BCS</u> RANGE.
<u>BCS</u> RANGE	Pair of Line Numbers (1-60, 1-60)	Select Range in current display file.	Valid and necessary after <u>BCS</u> DISP.
<u>BCS</u> GO	None	Go ahead with Auto Sequence using current display file and range.	Valid only after <u>BCS</u> RANGE and OCS response that one or more targets are available.
<u>BCS</u> OFFS	Helio No., Date, Time, Pair of offset values	Input date (month, day, year), time (hours, minutes, seconds), and horizontal and vertical offsets (feet).	Valid after <u>BCS</u> RANGE, after completion of an automatic sequence, after a semi-automatic Bias update sequence, or after one or two previous offsets.
<u>BCS</u> CALC	Helio No. or none, meaning all within range defined by <u>BCS</u> RANGE	Calculate one or all biases in range and display and print results one at a time for those biases that change.	Valid after <u>BCS</u> RANGE, after an automatic sequence, or after 1 or 2 <u>BCS</u> OFFS commands.
<u>BCS</u> BIAS	Helio No. for individual bias update. YES or NO in update mode	Update biases of current heliostat on disk and report to OCS. Display next biases if more in range to be reported.	Valid after a <u>BCS</u> CALC in manual bias update mode or during a semi-automatic update sequence.
<u>BCS</u> END	None	End of BCS processing and Exit.	Valid when BCS task is active.

- d. If OCS/BCS communications do not occur in a timely fashion, as mentioned in the interface document (CS-MCS and CS-Plant Interface Requirements), the BCS task will also self-abort.
- e. All self-aborts will include a return of HCs to normal operation, but will preclude new start-ups until this shutdown has been completed.

For purposes of this design discussion, various terminology shall be used and is defined below:

- a. BCS Utilization - BCS will have priority under normal operational conditions to "grab" heliostats for two reasons:
 - 1. To prevent them from shadowing a heliostat to be calibrated.
 - 2. To allow a heliostat to be calibrated for beam quality and encoder biases.

A bit in HCST3G (Number eight of zero to fifteen) has been defined for this purpose (1 = BCS utilization; 0 = free for normal operation).
- b. BCS Mode - This mode is to be valid only after BCS has been started through MMI by the command BCSSTART. During this mode several other BCS commands can be entered which would normally be flagged as input errors.
- c. BCS Sequence - This is a BCS phase (see definition below) consisting of an automatic sequence that is initiated by the BCSGO command and cycles through up to 60 heliostats worth of BCS measurements in an automatic fashion.
- d. BCS Subsequence - This is the portion of a BCS sequence defined above that deals with one heliostat, its blocking heliostat (up to 5) and all the necessary OCS messages related to that heliostat BCS target. Up to four subsequences may be in operation at one time (one per target).
- e. BCS Phase - BCSMOD has several phases it goes through during its operation: Initialization Automatic Sequencing (see c. above), Manual Bias Updates, Semi-Automatic Bias Updates, and Termination. Some of these phases include active timers when the HAC is waiting for OCS. Other timers are active within phases as described below.
- f. BCS Subsequence State - During a subsequence (see d. above) associated with a BCS target several states are entered, some of which have time-out values attached to it (e.g.: waiting for blocking heliostats, waiting for OCS messages).

During various states only particular messages are allowed to cause transitions to other states. The defined states are:

1. Waiting for blocking heliostats;
2. Waiting for BCS-4;
3. Moving to BCS target;
4. Waiting for BCS-6 or -8;
5. Moving to standby;
6. Returning to old mode; and
7. Waiting for blocking heliostats to return to old mode.

With the above definitions given, the design approach is summarized in some more detail below. As indicated by the phase definition above, the execution of BCSMOD is designed to take place in several phases some of which are further divided into subphases:

a. BCS Initialization - Consists of

1. Activation by MMI due to operator command BCSSTART.
2. Copying magnetic tape files onto the CS computer disk that is currently active for subsequent manipulation (BCSMTAPE command).
3. Selecting of file and displaying its contents on the bottom of the CS console (BCSDISP command).
4. Selecting the range within the file just selected (BCSRANGE command).
5. Sending message BCS-1 to OCS and setting up timer for return message.
6. Receiving BCS-2 message or time-out. If BCS-2 was received, BCSMOD is ready for next phase, otherwise it self-aborts.

b. BCS Automatic Sequencing - Sequencing is activated upon operator command (BCSGO). It is accomplished in nested loops. Up to four subsequences can take place simultaneously (four targets). Timing will be done on a once-per-second basis. Any problems (timeouts of OCS messages, heliostat non-performance or non-availability, etc...) will cause the subsequence to abort, be reported, and not under future consideration during this sequence. OCS data for bias updates will be logged on the CS logger. All subsequences include restoration of all affected heliostats to their old states.

- c. Semi-Automatic BCS Bias Updating - After the BCS initialization phase, after an automatic sequence, or after a manual bias update (see below) BCSMOD can be put into the semi-automatic bias update phase via the BCSCALC command. In this phase, BCSMOD cycles through all the heliostats in the selected range of a selected file, requests historical data from OCS via a BCS-11 message waits for a BCS-12 message containing that data and calculates new biases using that data. If the OCS message does not arrive in time, the BCS task self aborts. If the resulting new biases show no change from old biases, a BCS-13 message is sent to OCS reporting no change in biases and the next heliostat in the list is handled until the list is exhausted. If there is at least a one bit change, the operator must decide whether or not to use the new biases (via BCSBIAS, YES or NO) before the list is processed any further. The operator's response results in a BCS-13 message to report his decision to OCS.
- d. Manual BCS Bias Updating - After the BCS initialization phase, after an automatic sequence, or after another manual bias update, BCSMOD can be put into the manual bias update phase via the BCSOFFS (offset input) command. During this phase, BCS data can be entered (BCSOFFS), biases can be calculated (BCSCALC), and biases can be updated (BCSBIAS). Any updates are reported to OCS, data and calculation results are displayed and logged.
- e. Termination Phase - This phase is entered automatically if no communications with OCS can be established or other serious problems occur during BCS processing. Normally, this phase is entered upon operator input of a BCSEND command. This command terminates any of the above phases, causes a heliostat clean-up in case of an automatic sequence in progress, causes a BCS-10 message to be sent if communications had been established, and causes BCS to exit.

The above design is accomplished by 26 submodules including one task (BCS). This task is the main routine and executes on a once-per-second basis when it is active. Depending on events during the past second, subroutines BCSMES (message/alarm output), BCSOC (operator console inputs), BCSOCS (OCS inputs), and BCSSEQ (BCS sequencing) are called in that order. Other subroutines are called indirectly by two or more of the above subroutines. These are BCSPRP (prepare display), BCSLSQ (bias calculation using Least Squares Fitting), BCSLOG (data + message logging other than alarms and displays), and BCSCRT (CRT display output). Furthermore, BCSOC has seven subroutines for executing the more complicated commands and BCSLSQ has nine subroutines to do all the necessary mathematics. Four other modules are called by the BCSSUN subroutine that actually belong to the SUNVEC module.

3.2.11.3.1 Functional Allocations

BCSMOD consists of 26 submodules as shown in Figure 3.2.11-1. Their basic functions are described below:

- BCS - Main routine for periodic (once per second) checking of events such as operator input commands, OCS inputs, and time sequencing.
- BCSMES - Message (information, errors, and alarms) output routine. This subroutine is called at various levels within BCSMOD and shown at the highest calling level.
- BCSOC - Operator console input command handling routine. This subroutine is called if MMI has enqueued a command to BCS. Seven additional subroutines are called by BCSOC to execute the more complicated commands. These are described in more detail below.
- BCSOCS - OCS input message handling subroutine. This subroutine is called by BCS, if a local read to one of the five BCS core devices has completed. BCSOCS checks these messages, ignores unexpected ones, and sets appropriate flags for expected ones so that BCSSEQ can continue its subsequences.
- BCSSEQ - Sequencing submodule. This subroutine is driven by flags and the active list of heliostats. Three nested loops are used to see if:
 - a. Any heliostats need to be sequenced to or from the BCS targets;
 - b. Any targets have an active subsequence; and
 - c. Any heliostats associated with that target need to change state.Reverse subsequences, abort sequences, and time-outs of messages or heliostat motion are also handled.
- BCSLSQ - Offset data algorithm. This subroutine uses least squares fitting to calculate new biases from one to three sets of offset data points.
- BCSCON - Heliostat number conversion submodule. This subroutine converts a MDAC heliostat number into an MMA number and issues an alarm message when it finds an invalid number.
- BCSLOG - Logging submodule. This subroutine formats all messages that are to be logged by BCS but do not get logged automatically; i.e. it does not log commands and alarms, but does format and print information messages and calculation results.

Figure 3.2.11-1 BCS Submodule Diagram

BCSCRT - CRT display submodule. This subroutine prepares an ISC compatible buffer from the current heliostat states depending on the current phase. If the phase is automatic sequencing, BCSPRP has done most of the buffer preparation. BCSCRT then queues the buffer to CSO for actual screen output. Also a global is set (BCSLNG) to the appropriate number of lines to be blocked for use by BCS at the bottom of the CRT.

BCSMT - Magnetic Tape Input Subroutine. Called by BCSOC to execute the "BCSMTAPE" command during initialization phase.

BCSDIS - Display and select one of three available BCS files for BCS sequencing. Called by BCSOC to execute the "BCSDISP" command during initialization phase.

BCSRNG - Select range of heliostats on BCS file for BCS sequencing. Called by BCSOC to execute the "BCSRANGE" command during initialization phase.

BCSGO - Start automatic BCS sequencing subroutine. This is a simple flag setting after the "normal" procedure of reading in a tape was followed. Called by BCSOC to execute the "BCSGO" command at the end of the initialization phase.

BCSOFF - Subroutine to allow manual input of Offset Values. Called by BCSOC to execute the "BCSOFFS" command during the Bias update/reporting phase.

BCSCAL - Subroutine to calculate new bias values using all available manual or semi-automatic offset data. Called by BCSOC to execute the "BCSCALC" command during the bias update/reporting phase.

BCSBIA - Subroutine to update new bias values that were calculated semi-automatically or manually. Called by BCSOC to execute the "BCSBIAS" command during the bias update/reporting phase.

BCSDSK - Submodule to BCSSLQ and BCSBIA for accessing and updating disk file HCB (heliostat biases).

BCSCOR - Submodule to BCSSLQ for accessing disk file HCC (heliostat coordinates).

BCSGIM - Submodule to BCSSLQ to calculate heliostat vector and gimbal angles.

BCSLIN - Submodule to BCSSLQ to solve linear equations.

BCSLSC - Submodule to BCSSLQ to calculate least squares coefficients.

BCSSUN - Submodule to BCSLSQ to set up call for SUNPOS and reconvert the sun vector to floating point.

BCSNOR - Submodule to BCSLSQ to calculate heliostat normal vector from offsets.

BCSEPD - Submodule to BCSLSC to evaluate partial derivatives.

BCSVEC - Submodule to BCSLSC to calculate vector terms for least squares coefficients.

BCSAL2 - Submodule to BCSOCS to get ALT2STOW data from disk.

3.2.11.3.2

Resource Budgets

- a. BCSMOD has the following memory requirements for its task (BCS) and associated subroutines:
 - 11K 16-bit words
(only while BCS is active)
- b. Disk and magnetic tape utilization:
 1. Magnetic tape input during initial phase.
 2. BCS partition access (read and write) during initial phase. 186 records of 80 bytes = 14880 bytes
 3. BIAS file (HCB) access (read and write) during bias update phase. 32 records of 256 bytes = 8192 bytes.
 4. HC coordinate file (HCC) access (read only) during bias update phase. 64 records of 320 bytes = 20480 bytes.
- c. Timing
 1. BCS will be activated about 3 - 4 times a day during good weather.
 2. BCS will execute once per second to check on any inputs or events while it is active.
- d. Priorities

BCS is a background operation, so its priority requirement is low.
- e. Other
 1. Line printer (logger) to print results.
 2. Bottom of operator's CRT for table display, bias calculation results, and "BCS active" message.

3.2.11.4 Design Description

3.2.11.4.1 Module Structure

BCSMOD consists of 26 submodules (see Figure 3.2.11-1) which are: one (1) controlling task and twenty-four (25) sub-routines which are called at various levels. All 26 sub-modules have been discussed briefly as to their functional allocations above and are further discussed at design detail level below.

3.2.11.4.1.1 Submodule I - BCS Task

3.2.11.4.1.1.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - Activated via REX - activate by MMI task subsequent to operator entry of "BCSSTART".
- c. Constraints and Limitations - BCS can handle sequences for up to 60 heliostats with up to 5 blocking/shadowing heliostats each. Up to four subsequences (one per BCS target) can be handled simultaneously. High Wind Stow causes BCS to self-abort. Defocus prevents active heliostats to return to track.
- d. Processing - BCS task executes initialization code once after activation which consists of setting up of several internal flags and displaying an announcement message on the CRT.

Then BCS enters an infinite timing loop which can be exited by causing High Wind Stow, by entering the "BCSEND" command at the console, or by self-aborts due to serious problems.

This loop contains checks for the High Wind Stow flag LOKSTG and termination phase, for operator input (via DEQUE from MMI), for OCS input on one of five core devices, for automatic sequencing, for CRT display updates during sequencing, and for general times (TIMER(5)) time-outs. Most of the actual processing required if one of the above tests is met is handled by subroutines which are discussed below.

At the end of this loop, BCS suspends itself for one second, releasing the CPU and at the same time insuring reasonable response times and accuracy of timed events.

3.2.11.4.1.1.2 Data, Logic and Command Paths

a. Input Data

1. LOKSTG (High Wind Stow Global)
2. Input Queue from MMI for decoded inputs by operator. (Queue no. = 13)

b. Output Data

1. Global Common

TBUSYG - Task busy bits (BCS uses #29 of 0-31)

BCSLNG - Number of lines at bottom of screen

2. Local Common

PHASE
SPHASE
TIMER

c. Calls

BCSCRT	}	Subroutines
BCSMES		
DEQU		
BCSOC		
BCSOCS		
BCSSEQ		
DELAY	}	MAX IV REX SERVICES
EXIT		

3.2.11.4.1.1.3 Internal Data Description

Local Common - BCSCOM (all data is 16 bit integer unless otherwise noted)

PHASE - BCS Phase

- 1 = Initialization
- 2 = Automatic sequencing (BCS measurements)
- 3 = Semi-automatic sequencing (Bias calculations)
- 4 = Manual offset inputs/bias calculations
- 5 = Termination

SPHASE - BCS Sub-phase

PHASE = 1 (Initialization)

- 1 = Initialization after start
- 2 = Initialization after reading magnetic-tape files
- 3 = Initialization after selecting file
- 4 = Initialization after selecting range
- 5 = Initialization after "hand-shake" with OCS

PHASE = 2 (Auto-sequencing)

- 1 = Sequencing in progress
- 2 = Sequencing terminated by operator
- 3 = Sequencing finished with file

PHASE = 3 (Semi-auto-sequencing)

- 1 = Sequencing in progress
- 2 = Operator input requested

- 3 = Sequencing terminated by operator
- 4 = Sequencing finished with file

PHASE = 4 (Manual offset input)

- 1 = Single offset data set entered
- 2 = Two offset data sets entered
- 3 = Three offset data sets entered
- 4 = Biases are calculated
- 5 = Biases are updated on disk

PHASE = 5 (Termination)

- 1 = Termination started
- 2 = Termination done

R1 - Low limit of range
R2 - High limit of range
TIMER(5) - Target timers + general timer
PTIMER(4) - Partner timers for blocking heliostat
 staggering per target
TSTATE(4) - Target states (see also heliostat states)

4 = Waiting for BCS-4
5 = Waiting for heliostat to go to BCS target
 (+ up to one blocking heliostat)
6, 7, 8, 9 = Waiting for 2, 3, 4, or 5 blocking
 heliostats to go to ALT2STOW
11 = Waiting for BCS-6 or 8
12 = Waiting for heliostat to go to standby
13 = Waiting for heliostat to return to original
 mode (+ up to one blocking heliostat)
14, 15, 16, 17 = Waiting for 2, 3, 4, or 5 blocking
 heliostats to return to original mode
18 = Done with subsequence
19 = Forced termination of subsequence

TLIST(4) = Heliostat index in list per target
TMDAC(4) = Current MDAC heliostat per target
TMMA(4) = Current MMA heliostat per target

MODE(4) - Target mode

-2 = Not available (manual)
-1 = Not available (OCS)
0 = Free
1 = In use
2 = Done

SAVEAR(8, 6, 4) - Save array for previous HCCMDG + HCDATG(1-7)
 (6 heliostats, 4 targets)

WRKARR(6, 60) - Current work-file to be measured or calculated

HSTATE (61) - Heliostat states (60 + 1 for individual bias calculations)
 0 = Initialized or not in file
 1 = In file
 2 = In range
 4-19 = See TSTATE above
 20,21,22 = Waiting for 1st, 2nd, 3rd BCS-12
 23 = Waiting for operator decision (bias)
 24 = Done with bias update

COLOR(7) - Summarized heliostat states on ISC display

White = In file
 Green = In range
 Magenta = Waiting for BCS-4, motion to target, or motion to org. point.
 Cyan = Waiting for BCS-6 or 8
 Blue = Done with subsequence
 Red = Forced termination of subsequence
 Yellow = In bias update sequence

MDHCNO - Current HC number (MDAC helio. number)
 HFCHC - Current HFC/HC number (MMA helio. number)
 TAVAIL - Number of available targets
 NT - Number of current targets
 CMD - Operator command code
 MESNO - OCS message number
 NPT - Number of offset data points
 LISTHC - Heliostat list pointer in semi-automatic sequence
 HOUR(3) - Hour data points*
 DD(3) - Day data points
 MM(3) - Month data points
 YY(3) - Year data points
 U(3) - Horizontal offsets*
 V(3) - Vertical offsets*
 XH,YH,ZH - Heliostat coordinates*
 XS(3),YS(3),ZS(3) - Sun unit vectors*
 XT,YT,ZT - Target center coordinates*
 AT(4),BT(4) - Target azimuth and elevation*
 XN,YN,ZN(3) - Heliostat normal vectors*
 AZ(3),EL(3) - Heliostat azimuths and elevations*
 XNA(3),YNA(3),ZNA(3) - Actual heliostat normals*
 A(2,2),B(2),X(2) - Linear system matrix and vectors*
 HCBPTR,HCCPTR,AL2PTR - Direct access file pointers:

 CRTFL - Flag to display file summary during auto-sequencing
 CNGFL - Flag to update file summary display during auto-sequencing
 MES - Message number
 AZO,ELO - Azimuth & Elevation delta biases*
 Plus miscellaneous pointers, counter, and intermediate variables

* Floating Point Values

3.2.11.4.1.1.4 Flowchart

See Figure 3.2.11-2 for the BCS task flowchart

3.2.11.4.1.2 Submodule II - BCSMES

3.2.11.4.1.2.1 Description

- a. Language Used - FORTRAN IV
- b. How Invoked - called by BCS task and various submodules.
- c. Constraints and Limitations - BCSMES can handle 4 types of messages and up to 38 different messages. BCSMES can be called from any level within the BCS task.
- d. Processing - BCSMES subroutine uses the message number to access the type of message. If the type = 1 (non-critical alarm) or = 2 (critical alarm), the message text and necessary parameters are passed to ALMQUE. Type = 3 is logging device output and type = 4 are error messages that are written to the visible cursor on the CS console (ISC-CRT).

3.2.11.4.1.2.2 Data, Logic and Command Paths

a. Input Data

M (= message no.)

b. Output Data

1. Global common - none
2. Local common - none
3. ASCII strings + parameters to ALMQUE
4. ASCII strings to logger
5. ASCII string to visible cursor on screen

c. Calls

ALMQUE
ENQU

3.2.11.4.1.2.3 Internal Data Description

Array of ASCII messages see Table 3.2.11-II
Array of number of parameters see Table 3.2.11-II
Array of types by message number see Table 3.2.11-II

3.2.11.4.1.2.4 Flowchart

See Figure 3.2.11-3 for the BCSMES flowchart.

Figure 3.2.11-2 Flowchart - BCS

BCS MESSAGES

<u>No.</u>	<u>Text</u>	<u>Parms</u>	<u>Type*</u>
1	BCS ACTIVE	0	3
2	BCS TERMINATED BY OPERATOR	0	1
3	INVALID COMMAND	0	4
4	NO TARGETS AVAILABLE FOR AUTO SEQUENCE	0	4
5	NO OK FROM OCS FOR BCS	0	2
6	TARGET NT NOT AVAILABLE	1	1
7	INVALID MDAC HELIO NO. ENCOUNTERED	0	1
8	HELIO NOT IN LEGAL MODE FOR BCS	0	1
9	BLOCKING HELIO NOT IN LEGAL MODE	0	1
10	ABORT SUBSEQUENCE DUE TO TIME-OUT	0	2
11	AUTO SEQUENCE FINISHED - FILE AAAAAAAAAA	3	1
12	READ ERROR ENC. ON BCS PARTITION	0	4
13	INVALID FILE ON BCS PARTITION	0	4
14	MAGTAPE READ ERROR	0	4
15	WRITE ERROR ON BCS PARTITION	0	4
16	MAGTAPE FILE FORMAT INVALID	0	4
17	ENCOUNTERED ERRONEOUS OCS DATA BY BCS	0	1
18	INVALID MESSAGE RECEIVED FROM OCS BY BCS	0	2
19	UNEXPECTED MESSAGE FROM OCS	0	1
20	READ ERROR ON HCB BY BCS	0	2
21	EOF ENCOUNTERED ON HCB BY BCS	0	2
22	READ ERROR ON HCC BY BCS	0	2
23	EOF ENCOUNTERED ON HCC BY BCS	0	2
24	WRITE ERROR ON HCC BY BCS	0	2
25	EOF ENCOUNTERED (DURING WRITE) ON HCC BY BCS	0	2
26	INVALID PARAMETER KEYED IN	0	4
27	WRITE ERROR ON OCS CHANNEL	0	4
28	SEMI-AUTOMATIC SEQUENCE FINISHED - FILE AAAAAAAAAA	3	1
29	BCS TERMINATED DUE TO LACK OF OCS RESPONSE	0	2
30	CENTROID ALARM; HC MMM, HORIZONTAL $\pm$ NN.NN FT, VERTICAL $\pm$ NN.NN FT	3	1
31	POWER TOO LOW; HC MMM, POWER NN.NN K WATTS	2	1
32	BEAM OFF TARGET M; HC MMM	2	1
33	LOW LEVEL BEAM ON TARGET M; HC MMM	2	1
34	READ ERROR ON FILE AL2 BY BCS	0	1
35	EOF ENCOUNTERED ON FILE AL2 BY BCS	0	1
36	AUTO SEQUENCE STARTED - FILE AAAAAAAAAA - DATE MM/DD/YY - EARLY TIME HH:MM- LATE TIME HH:MM	10	1
37	WRITE ERROR TO REMOTE HCB BY BCS	0	2
38	EOF ENCOUNTERED ON REMOTE HCB BY BCS	0	2

- * Types 1 - Information "ALARM"
2 - Serious Alarm
3 - Logger Output
4 - CRT (Visible Cursor) Output

Table 3.2.11-II BCS Messages

Figure 3.2.11-3 Flowchart - BCSMES

3.2.11.4.1.3 Submodule III - BCSOC

3.2.11.4.1.3.1 Description

- a. Language Used - FORTRAN IV
- b. How Invoked - called by BCS task when an operator input was enqueued by MMI to BCS, preceded by a "BCS...." type of operator input on the CS console.
- c. Constraints and Limitations - BCSOC is limited to handle eight different commands during phases 1 - 4. BCSOC expects MMI to decode and check input parameters for validity and range.
- d. Processing - Depending on the phase or subphase BCS is in, commands are allowed or not. If not, an error message is output to the CS console, otherwise the appropriate subroutine is called to handle the particular command. The two exceptions to this are "BCSEND" and "BCSGO" which are processed directly. All necessary phase and subphase transitions are made in BCSOC.

3.2.11.4.1.3.2 Data, Logic and Command Paths

a. Input Data

1. Command buffers from MMI containing decoded commands

where	1 = BCSMTAPE	7 = BCSBIA
	2 = BCSDISP	8 = BCSSEND
	3 = BCSRANGE	
	4 = BCSGO	Parameters, if
	5 = BCSOFFS	necessary, are
	6 = BCSCALC	decoded into the
		same buffer

2. Global Common - none

3. Local Common

CRTFL
PHASE
SPHASE

b. Output Data

1. Global Common - none

2. Local Common

CRTFL
PHASE
SPHASE

c. Calls

BCSMES	}	Subroutines
BCSBIA		
BCSCAL		
BCSOFF		
BCSRNG		
BCSDIS		
BCSMT		
BCSGO		

3.2.11.4.1.3.3 Internal Data Description

Miscellaneous flags and pointers

3.2.11.4.1.3.4 Flowchart

See Figure 3.2.11-4 for the BCSOC flowchart.

3.2.11.4.1.4 Submodule IV - BCSLSQ

3.2.11.4.1.4.1 Description

- a. Language Used - FORTRAN IV
- b. How Invoked - called by BCSCAL, BCSOFF, or BCSOCS to calculate new biases.
- c. Constraints and Limitations - BCSLSQ is limited to handle 1 - 3 sets of data points. It iterates up to 10 times to find a least sequence linear solution.
- d. Processing - Old biases and heliostat coordinates are obtained via two subroutines. A loop is entered and executed for each set of data points. In this loop the sun vector, heliostat gimbal angles, and heliostat normal vector are determined for a given data point. The resultant data is passed through a least squares coefficient algorithm and a linear equation solver until a solution is found or the maximum number of iterations is exceeded. In the latter case a non-critical alarm is issued.

3.2.11.4.1.4.2 Data, Logic and Command Paths

a. Input Data

1. Parameters - none

2. Local Common

NPT = Number of data points

HFCHC = HFC/HC (MMA) number

3. Global Common

SLATG

SLONGG

BCSTGG

HCST3G

Figure 3.2.11-4 BCSOC Flowchart

Figure 3.2.11-4 BCSOC Flowchart (Continued)

Figure 3.2.11-4 Flowchart - BCSOC (Continued)

b. Output Data

1. Parameters

AZO - Delta AZ bias

ELO - Delta EL bias

2. Local Common

NT, XT, YT, ZT

c. Calls

BCSDSK	} Subroutines
BCSCOR	
BCSSUN	
BCSGIM	
BCSNOR	
BCSLSC	
BCSLIN	
BCSMES	

3.2.11.4.1.4.3 Internal Data Description

ITERNO - Number of iterations

REPAZ - Reference azimuth delta

REFEL - Reference elevation delta

Miscellaneous pointers and
intermediate variables

3.2.11.4.1.4.4 Flowchart

See Figure 3.2.11-5 for the BCSSLQ flowchart.

3.2.11.4.1.5 Submodule V - BCSOCS

3.2.11.4.1.5.1 Description

- a. Language Used - FORTRAN IV
- b. How Invoked - Called by BCS task when one of 5 input core devices is written into by OCS (local read completes) during the previous second.
- c. Constraints and Limitations - BCSOCS is limited to handle input messages 2 and 12 from core device 5 and messages 4, 6, and 8 from core devices 1-4.
- d. Processing - BCSOCS checks all input messages that completed during the previous second for valid preambles. Then it decodes the message number and checks if that message is valid at this time (i.e. expected). A valid BCS-2 message results in a self-abort preceded by ECS-10 if OCS gives no ok, otherwise the number of available targets are counted, the operator is notified of non-available targets and the next sub-phase is initiated.

Figure 3.2.11-5 Flowchart - BCSLSQ

Message 4, if expected, results in a heliostat and its blocking partners to move to the BCS target and ALT2STOW if necessary. Two second staggering is implemented, if more than one blocking heliostat must be moved.

Message 6, if expected, results in movement of the heliostat to be measured to the standby mode.

Message 8, if expected, results in the reversal of the subsequence described above for message 4.

Message 12, if expected, is checked for validity and, if valid, causes data storage in local common. If the expected number of measurements (up to 3) have not been received, another BCS-12 message is prepared for. Otherwise, a least squares solution for new biases is made using subroutine BCSLSQ. The complete data set including the old and new biases is logged on the logging device. If a semi-automatic sequence is in progress, the biases are checked for a change of at least one encoder bit. If so, data is also displayed on the CRT and BCS goes into a wait phase for the operator to decide whether to update the biases on disk or not.

If only one heliostat was acted on, the data is unconditionally displayed on the CRT, but a similar wait subphase is entered if a bias update decision need to be made.

In the semi-automatic case above, the sequence is confirmed if further processing of the list is required and no operator input is needed.

An invalid message by OCS results in a non-critical alarm, but no phase or subphase changes so that processing can continue.

3.2.11.4.1.5.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

N = First device to have read complete during last second

2. Local Common

PHASE, SPHASE, TMDAC, MDHCNO

3. Global Common

HCST3G
BCSBYG

4. Other - OCS core devices 1 - 5
messages 2, 4, 6, 8, and 12

b. Output Data

1. Parameters - none
2. Local Common

TIMER, HSTATE, TSTATE

3. Global Common - none
4. Other - OCS core devices 1 - 5 messages 5 and 11

c. Calls

BCSMES	} Subroutines
BCSCON	
BCSLSQ	
BCSLOG	
BCSCRT	

3.2.11.4.1.5.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous pointers and variables.

3.2.11.4.1.5.4 Flowchart

See Figure 3.2.11-6 for the BCSOCS flowchart.

3.2.11.4.1.6 Submodule VI - BCSSEQ

3.2.11.4.1.6.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCS task once per second if an automatic sequence is in progress.
- c. Constraints and limitations - BCSSEQ is limited to process four simultaneous subsequences (one per BCS target) through a list of up to 60 heliostats with up to 5 blocking heliostats each.
- d. Processing - A loop for four targets is executed. Each target is checked for having a subsequence to execute. If not, the list of heliostats is scanned for new subsequences. If no more are found, that target is released

Figure 3.2.11-6 Flowchart - BCSOCS

Figure 3.2.11-6 Flowchart - BCSOCS (Continued)

Figure 3.2.11-6 Flowchart - BCSOCS (Continued)

for other (e.g. manual) BCS operations. If more are found, a new subsequence is started. If any problems (e.g. heliostat in illegal mode) are encountered, the operator is notified via a non-critical alarm, and the search for additional subsequences is continued, otherwise OCS is notified via a BCS-3 message, effectively starting a subsequence.

A subsequence in progress is controlled via the target state (TSTATE) and target timers (TIMER). If states timeout, (e.g. OCS failed to answer or heliostats failed to arrive), the subsequence is aborted and, if necessary, heliostat motion is recovered. Staggered starting is used if more than one blocking heliostat must be moved to its original mode. In all cases, heliostats are commanded to return to their original positions at the end of a subsequence.

At the end of BCSSEQ processing, all targets are checked for being either not available or done with their heliostats. If all four targets are in one of these modes, the automatic sequence is finished and the operator is alerted to that fact.

3.2.11.4.1.6.2 Data, Logic and Command Paths

a. Input Data

1. Parameters - none

2. Local Common

MODE, TSTATE, TIMER, PTIMER, SAVARR

3. Global Common

HCST2G, HCCMDG, HCDATG

4. Other - none

b. Output Data

1. Parameters - none

2. Local Common

TIMER, PTIMER, TSTATE, MODE, SAVARR

3. Global Common

HCST3G, HCCMDG, HCDATG, BCSBYG

4. Other

OCS core devices 1 - 4 messages 3, 5

c. Calls

BCSMES
BCSAL2

3.2.11.4.1.6.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous pointers and variables

3.2.11.4.1.6.4 Flowchart

See Figure 3.2.11-7 for the BCSSEQ flowchart.

3.2.11.4.1.7 Submodule VII - BCSCON

3.2.11.4.1.7.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by various subroutines at various levels to convert a MDAC heliostat number to the corresponding MMA heliostat number.
- c. Constraints and limitations - Input must be a valid MDAC heliostat number and global common arrays MDNPRG and MD2HCG must be properly initialized.
- d. Processing - The MDAC row is isolated and checked for validity. If valid, the line number within the row is isolated. If the line number does not exceed the difference between the stored sum for this row and the next row, the HFCHC number is found directly in the MD2HCG array. If one of the above tests failed, an invalid MDAC number was input, the operator is notified via a non-critical alarm and HFCHC is not modified.

3.2.11.4.1.7.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

MDHCNO - MDAC heliostat number

2. Local Common - none

3. Global Common

MDNPRG
MD2HCG

b. Output Data

1. Parameters

HFCHC - MMA heliostat number

Figure 3.2.11-7 Flowchart - BCSSEQ (Continued)

Figure 3.2.11-7 Flowchart - BCSSEQ (Continued)

Figure 3.2.11-7 Flowchart - BCSSEQ (Continued)

2. Local Common - none

3. Global Common - none

c. Calls

BCSMES subroutine

3.2.11.4.1.7.3 Internal Data Description

ROW - First two digits of MDAC number

LINE - Last two digits of MDAC number

SUM - Sum in global common for above ROW

3.2.11.4.1.7.4 Flowchart

See Figure 3.2.11-8 for the BCSCON flowchart.

3.2.11.4.1.8 Submodule VIII - BCSLOG

3.2.11.4.1.8.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSOCS, BCSOFF, and BCSCAL to log results of a bias calculation on the logger.

c. Constraints and limitations - up to 3 data sets can be logged.

d. Processing - a header of information including the MDAC heliostat number is written to the logger. As many data points as available (up to three) are written to the logger. Old and new biases are formatted and written to the logger.

3.2.11.4.1.8.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

NPT - Number of data points

2. Local Common

Date, time, horizontal, vertical offsets, old biases, and new biases

3. Global Common - none

b. Output Data

1. Parameters - none

2. Local Common - none

Figure 3.2.11-8 Flowchart - BCSCON

3. Global Common - none

4. Other - Formatted logger output

HH:MM:SS BIAS CALCULATION RESULTS FOR HELIOSTAT MMMM:

DATA SET	DATE	TIME	HOR OFFS.	VERT. OFFS (FEET)	ALARMS	
					CENTROID	POWER
1	MO/DD/YY	HH:MM:SS	+ XX.XX	+ XX.XX	N	N
2	MO/DD/YY	HH:MM:SS	+ XX.XX	+ XX.XX	N	N
3	MO/DD/YY	HH:MM:SS	+ XX.XX	+ XX.XX	N	N

OLD BIASES: AZ = + XXX.XX EL = + XXX.XX (DEGREES)

NEW BIASES: AZ = + XXX.XX EL = + XXX.XX (DEGREES)

OPERATOR COMMAND FOR BIAS UPDATE REQUIRED.

c. Calls

WRITE system call

3.2.11.4.1.8.3 Internal Data Description

a. For local common see BCS task (3.2.11.4.1.1.3)

b. Miscellaneous pointers and local variables

3.2.11.4.1.8.4 Flowchart

See Figure 3.2.11-9 for the BCSLOG flowchart.

3.2.11.4.1.9 Submodule IX - BCSCRT

3.2.11.4.1.9.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by various BCS modules at various levels to output one of three BCS displays at the bottom of the CS console (ISC-CRT) and/or clear previously displayed lines.

c. Constraints and limitations - the different displays are available. Up to 15 lines of output are made. Only the ISC CRT can be output to.

d. Processing - first, BCSCRT checks to see if the current number of lines displayed is different from the requested number. If the requested number is lower, it erases the lines no longer needed on the CRT. Then it sets the BCSLNG flag in global common to the number of lines

Figure 3.2.11-9 Flowchart - BCSLOG

requested. If the visible cursor is in the area to be displayed, two blanks are written to the cursor to effectively move it to the top of the conversational area of the screen.

Finally, depending on the number of lines required, a particular display (one of three) is written to the screen in invisible cursor mode.

For lines = 15 this display consists of a summary of the currently active list of heliostats to be measured. These heliostat numbers are color coded to show their current state in the process. A key to these colors appears on the right hand side of the screen.

For lines = 6 this display consists of the result of a recent bias calculation, including the data points used to calculate that result.

For lines = 2 this display consists only of a "BCS active" message.

Any other input for lines causes the screen to be released for other (conversational) purposes.

3.2.11.4.1.9.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

 LINES = Number of lines to display
 (effectively = number of display)

2. Local Common

 WRKARR, HSTATE, COLOR, Bias data

3. Global Common

 BCSLNG
 CRTWRG

b. Output Data

1. Parameters - none

2. Local Common

 CRTFL

3. Global Common

 BCSLNG

4. Other

Control File Display:

16 Lines of Alarm and Status Information									
17 Lines Conversational Area (command entry and feedback)									
*** ****									
BCS FILE: AAAAAAAAAA									
DATE: DD/MM/YY EARLY TIME: HH:MM LATE TIME: HH:MM									
1	NNNN	11		51	NNNN				
2				.				Color	
.				.				Keys	
.				.					
10	NNNN	20		60	NNNN				

15 lines

Bias Calculation Display:

16 Lines of Alarm and Status Information									
26 Lines Conversational Area									
BCS Heliostat No: MMMM *** ***									
1.	DATE	-	TIME	-	H-OFFS	-	V-OFFS	-	CENTR - POWR
2.	"	"	"	"	"	"	"	"	"
3.	"	"	"	"	"	"	"	"	"
RESULTS: NEW BIAS: AZ = + XXX.XX EL = + XXX.XX									
OLD BIAS: AZ = + XXX.XX EL = + XXX.XX									

6 lines

BCS Active Display:

16 Lines of Alarm and Status Information									
30 Lines Conversational Area									
***** . . . *****									
BCS ACTIVE - PHASE = N; SPHASE = M									

2 lines

c. Calls

ENQUE subroutine

3.2.11.4.1.9.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous pointers and local variables

3.2.11.4.1.9.4 Flowchart

See Figure 3.2.11-10 for the BCSCRT flowchart.

3.2.11.4.1.10 Submodule X - BCSMT

3.2.11.4.1.10.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a "BCSMTAPE" command that was entered by the operator during the previous second with BCS in the INIT Part 1 Phase.
- c. Constraints and limitations - BCSMT is limited to reading three files at one time.
- d. Processing - BCSMT reads three files from one magnetic 9 track tape and writes them on the BCS disk partition in the currently active HAC computer. All errors are reported via BCSMES.

3.2.11.4.1.10.2 Data, Logic and Command Paths

a. Input Data

1. Parameters - none
2. Local common - none
3. Global common - none
4. Other - 3 magnetic tape files with up to 62 records of 80 bytes each - BCS disk partition

b. Output Data

1. Parameters - none
2. Local common
SPHASE
3. Global common - none
4. Other - BCS disk partition

c. Calls

BCSMES subroutine

Figure 3.2.11-10 Flowchart - BCS CRT

3.2.11.4.1.10.3 Internal Data Description

Holding buffer for 80 byte records. Miscellaneous constants and local variables.

3.2.11.4.1.10.4 Flowchart

See Figure 3.2.11-11 for the BCSMT flowchart.

3.2.11.4.1.11 Submodule XI - BCSDIS

3.2.11.4.1.11.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a "BCSDISP" command that was entered by the operator during the previous second with BCS in the INIT Part 1, 2 or 3 Phase.
- c. Constraints and limitations - BCSDIS is limited to displaying one partial file (no blocking heliostats) at one time.
- d. Processing - BCSDIS first checks the input parameter. If 4 (= "ON") it sets CRTFL, if 0 (= "OFF") it clears CRTFL, thereby enabling or disabling the file display updates during automatic sequencing.

Inputs 1, 2, or 3 cause WRKARR and HSTATE to be initialized, one of 3 files on the BCS partition to be accessed and loaded into header variables and WRKARR. HSTATE is initialized for each heliostat in the list. File integrity is checked and BCSCRT is called to do the file displaying.

3.2.11.4.1.11.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

One OC input parameter

2. Local Common - none

3. Global Common - none

4. Other - BCS disk partition files 1, 2, or 3

b. Output Data

1. Parameters - none

2. Local Common

WRKARR
HSTATE
R2

Figure 3.2.11-11 Flowchart - BCSMT
639

3. Global Common - none

c. Calls

BCSMES
BCSCRT

3.2.11.4.1.11.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous constants and local variables

3.2.11.4.1.11.4 Flowchart

See Figure 3.2.11-12 for the BCSDIS flowchart.

3.2.11.4.1.12 Submodule XII - BCSRNG

3.2.11.4.1.12.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a "BCSRANGE" command that was entered by the operator during the previous second with BCS in the INIT Part 3 Phase.
- c. Constraints and limitations - BCSRNG is limited to two input parameters - both being less than 61.
- d. Processing - BCSRNG checks its two input parameters for validity and if valid, sets the range values R1 for lower and R2 for upper limits within the display (control) file. It then initializes HSTATE and causes the CRT display to be updated. After setting up a read with quick return from OCS core device 5, it sends a BCS-1 message to OCS to establish communications.

3.2.11.4.1.12.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

N1 = Desired lower limit
N2 = Desired upper limit

2. Local Common

R2

3. Global Common - none

4. Other - Read from OCS core device 5

Figure 3.2.11-12 Flowchart - BCSDIS

b. Output Data

1. Parameters - none

2. Local Common

HSTATE

SPHASE

R1, R2

3. Global Common - none

4. Other - Write BCS-1 to core device 5

c. Calls

BCSCRT } Subroutines
BCSMES }

3.2.11.4.1.12.3 Internal Data Description

a. For a local common definition see BCS task
(3.2.11.4.1.1.3)

h. Miscellaneous constants and local variables

3.2.11.4.1.12.4 Flowchart

See Figure 3.2.11-13 for the BCSRNG flowchart.

3.2.11.4.1.13 Submodule XIII - BCSGO

3.2.11.4.1.13.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSOC to execute a "BCSGO" command that was entered by the operator during the previous second with BCS in the INIT Part 4 Phase.

c. Constraints and limitations - BCSGO can only be executed at the end of initialization (after handshake with OCS) and if at least one BCS target is available.

d. Processing - BCSGO assumes that the sequence to be started contains no sub-sequences and then searches the range of heliostats for up to four sub-sequences to start when it finds a match with an available target and the target assigned to a heliostat in the list, it checks the heliostat and its blocking partners to be in proper modes for sub-sequencing. If so, a subsequence is started setting up the appropriate local common values and sending a BCS-3 message to OCS. When the number of active targets

Figure 3.2.11-13 Flowchart - BCSRNG

is equal to the number of available targets or the range of heliostats has been checked, the original assumption is checked and if correct, the sequence is finished, otherwise the sequence (containing 1-60 sub-sequences) is marked as being active.

3.2.11.4.1.13.2 Data, Logic and Command Paths

a. Input Data

1. Parameters - none
2. Local Common
R1, R2, WRKARR
3. Global Common
HCST3G
4. Other - Read of 1-4 core devices from OCS

b. Output Data

1. Parameters - none
2. Local Common
MDHCNO, HFCHC, TLIST, TMDAC, TMMA, TSTATE
HSTATE, PHASE, SPHASE, MODE, TIMER, NT
3. Global Common - HCST3G, BCSBYG
4. Other - Write to OCS core devices 1-6

c. Calls

BCSCON	} Subroutines
BCSMES	
BCSCRT	

3.2.11.4.1.13.3 Internal Data Description

- a. For local common definitions see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous constants and local variables

3.2.11.4.1.13.4 Flowchart

See Figure 3.2.11-14 for the BCSGO flowchart.

Figure 3.2.11-14 Flowchart - BCSGO
645

3.2.11.4.1.14 Submodule XIV - BCSOFF

3.2.11.4.1.14.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a valid "BCSOFFS" command that was entered at the CS console during the previous record.
- c. Constraints and limitations - BCSOFF can only be called after initialization, after completion of an automatic sequence, after a semi-automatic sequence, or as part of one or more manual bias calculations.
- d. Processing - BCSOFF checks to see if the current input data belongs to the same heliostat as previously entered data. If not it checks for validity and enters data in local common data set one. Otherwise, it enters data set two or three. If the third set has been entered, new biases are calculated, logged with the data and displayed on the bottom of the CS console. The sub-phase is then set to allow for bias updates on disk or further calculations.

3.2.11.4.1.14.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

MDHCNO - MDAC heliostat number
M,D,Y - Date of reading
H,M,S - Time of reading
HO,VU - Offsets

2. Local Common

OLDHC, HFCHC, SPHASE

3. Global Common - None

b. Output Data

1. Parameters - none

2. Local Common

SPHASE
OLDHC
HFCHC

3. Global Common - none

c. Calls

BCSCON	}	Subroutines
BCSLSQ		
BCSLOG		
BCSCRT		

3.2.11.4.1.14.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous constants and local variables

3.2.11.4.1.14.4 Flowchart

See Figure 3.2.11-15 for the BCSOFF flowchart.

3.2.11.4.1.15 Submodule XV - BCSCAL

3.2.11.4.1.15.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a valid "BCSCALC" command that was entered during the previous second.
- c. Constraints and limitations - BCSCAL can only be called after initialization, after an automatic sequence, after a semi-automatic sequence for an individual heliostat, or after 1 - 2 BCSOFFS commands.
- d. Processing - BCSCAL tests if a manual data entry phase is in progress and if so calculates new biases logs them and displays them on the console both with the associated data points. Otherwise, it starts a semi-automatic sequence. If an individual heliostat was specified, sequence is a misnomer, but the same logic is invoked and terminated later when data for that one heliostat has been acted upon. In either case, after local common is set up, a read for OCS core device No. 5 is issued and a BCS-11 message is sent to OCS core device No. 5.

3.2.11.4.1.15.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

MDAC Heliostat number or none

2. Local Common

PHASE, SPHASE, WRKARR

Figure 3.2.11-15 Flowchart - BCSOFF

- 3. Global Common - none
- 4. Other - Read from OCS core device No. 5
- b. Output Data
 - 1. Parameters - none
 - 2. Local Common
 - PHASE, SPHASE, TIMER, MDHCNO, LISTHC
 - 3. Global Common - none
 - 4. Other - Write BCS-11 to OCS core device No. 5
- c. Calls
 - BCSLSQ
 - BCSMES

3.2.11.4.1.15.3 Internal Data Description

- a. For local common refer to BCS task (3.2.11.4.1.1.3)
- b. Miscellaneous constants and local variables

3.2.11.4.1.15.4 Flowchart

See Figure 3.2.11-16 for the BCSCAL flowchart.

3.2.11.4.1.16 Submodule XVI - BCSBIA

3.2.11.4.1.16.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSOC to execute a valid "BCSBIAS" command that was entered during the previous second.
- c. Constraints and limitations - BCSBIA can only be called after biases have been calculated during the manual bias update phase or during a semi-automatic update sequence requiring operator decisions.
- d. Processing - first, the phase and subphase of operation is tested. If data was entered manually, biases are reported to OCS via a BCS-13 message and written to disk, otherwise the parameter is checked. If it was "YES", biases are updated on disk. In both cases (YES or NO) a BCS-13 message is sent to OCS core device No. 5. If further processing is required by the semi-automatic sequence, local common is set up,

Figure 3.2.11-16 Flowchart - BCSCAL

a read with quick return from OCS core device No. 5 is executed and a BCS-11 message is sent to OCS core device No. 5.

3.2.11.4.1.16.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

One Parameter - YES or NO or heliostat number

2. Local Common

PHASE, SPHASE, HFCHC

3. Global Common - none

4. Other - Read from core device No. 5

b. Output Data

1. Parameters - none

2. Local Common

PHASE, SPHASE, TIMER

3. Global Common - none

4. Other - BCS-11 & 13 to OCS core device No. 5

c. Calls

BCSDSK Subroutines
BCSMES

3.2.11.4.1.16.3 Internal Data Description

a. For local common see BCS task (3.2.11.4.1.1.3)

b. Miscellaneous constants and local variables.

3.2.11.4.1.16.4 Flowchart

See Figure 3.2.11-17 for the BCSBIA flowchart.

3.2.11.4.1.17 Submodule XVII - BCSDSK

3.2.11.4.1.17.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSSLQ or BCSBIA to obtain or replace HC biases.

Figure 3.2.11-17 Flowchart - BCSBIA

- c. Constraints and limitations - direct disk access to partition HCB only.
- d. Processing - BCSDSK calculates the appropriate disk record number and reads the complete record into a holding buffer. Read errors and EOF's are reported to the operator. Next a pointer into the holding buffer is calculated. If a replacement was not desired, AZ and EL are loaded from the buffer. Otherwise, they are loaded into the buffer and the record is written back to disk.

3.2.11.4.1.17.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

HFC HC - HFC/HC number
 REP - Replacement flag
 (If set, AZIM and ELEV are bias inputs)

2. Local Common - HCBPTR

3. Global Common - none

4. Other - HCB partition direct read

b. Output Data

1. Parameters

If REP (above) is false, AZIM and ELEV are bias outputs

2. Local Common - HCBPTR

3. Global Common - none

4. Other - HCB partition direct write

c. Calls

BCSMES subroutine

3.2.11.4.1.17.3 Internal Data Description

- a. For local common refer to paragraph 3.2.11.4.1.1.3 in BCS task.
- b. Miscellaneous constants and local variables.

3.2.11.4.1.17.4 Flowchart

See Figure 3.2.11-18 for the BCSDSK flowchart.

Figure 3.2.11-18 Flowchart - BCS DSK

3.2.11.4.1.18 Submodule XVIII - BCSCOR

3.2.11.4.1.18.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSLSQ to obtain HC coordinates.
- c. Constraints and limitations - BCSCOR can only read partition HCC and can only interpret 24 bit coordinates a binary point 14.
- d. Processing - BCSCOR calculates the appropriate record to be read and sets the partition pointer. Then it does a direct read of that record into a holding buffer. Read errors and EOF's are reported as non-critical alarms.

Next BCSCOR calculates a pointer within the buffer and converts packed 24 bit data at binary point 14 into X, Y, and Z coordinates.

3.2.11.4.1.18.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

HFCHC = MMA HFC/HC number

2. Local Common

HCCPTR = Partition pointer

3. Global Common - none

4. Other - HCC partition direct read

b. Output Data

1. Parameters

XCOR

YCOR MMA facility coordinates of HC in meters

ZCOR

2. Local Common - none

3. Global Common - none

c. Calls

BCSMES subroutine

3.2.11.4.1.18.3 Internal Data Description

- a. For local common definitions refer to paragraph 3.2.11.4.1.1.3 of BCS task
- b. Miscellaneous constants and local variables.

3.2.11.4.1.18.4 Flowchart

See Figure 3.2.11-19 for the BCSCOR flowchart.

3.2.11.4.1.19 Submodule XIX - BCSGIM

3.2.11.4.1.19.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSSLQ to compute the commanded gimbal angles and heliostat normal for a particular set of data.
- c. Constraints and limitations - limited to 3 data sets and 4 targets.
- d. Processing - First the heliostat to target vector elements are calculated and normalized. Then these elements are added to the sun vector elements and normalized, resulting in the heliostat normal vector. From that the azimuth and elevation angles are calculated.

3.2.11.4.1.19.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

I = Number of data point (1-3)
NT = Number of BCS target (1-4)

2. Local Common

XT, YT, ZT - Target coordinates
XH, YH, ZH - Heliostat coordinates
XS, HS, ZS - Sun vector elements

3. Global Common - none

b. Output Data

1. Parameters - none

Figure 3.2.11-19 Flowchart - BCSQOR

2. Local Common

AZ, EL - Heliostat gimbal angles
XN, YN, ZN - Heliostat normal vector

3. Global Common - none

c. Calls

ATAN2 } System library routines
ARSIN }

3.2.11.4.1.19.3 Internal Data Description

- a. For local common see BCS task (3.2.11.4.1.1.3)
- b. XTH, YTH, ZTH - Heliostat to target vector elements
XTN, YTN, ZTN - Normalized HC to target vector
XST, YST, ZST - Heliostat to sun vector
NORMT, NORMN - Normalizing of sums squared

3.2.11.4.1.19.4 Flowchart

See Figure 3.2.11-20 for the BCSGIM flowchart.

3.2.11.4.1.20 Submodule XX - BCSLIN

3.2.11.4.1.20.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSLSQ to solve the system of linear equations $AX = B$ for X.
- c. Constraints and limitations - A is a 2 x 2 matrix; X and B are 2 dimensional vectors.
- d. Processing - the three determinants of the two equations are calculated and X(1) and X(2) are the quotients of these determinants.

3.2.11.4.1.20.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

A - Matrix
B - Vector

2. Local Common - none

3. Global Common - none

Figure 3.2.11-20 Flowchart - BCSGIM

b. Output Data

1. Parameters

X - Vector

2. Local Common - none

3. Global Common - none

c. Calls - none

3.2.11.4.1.20.3 Internal Data Description

DET0 - Determinant of matrix A

DET1 - First solution determinant

DET2 - Second solution determinant

3.2.11.4.1.20.4 Flowchart

See Figure 3.2.11-21 for the BCSLIN flowchart.

3.2.11.4.1.21 Submodule XXI - BCSLSC

3.2.11.4.1.21.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSLSQ to calculate the least squares linear system (normal equations) from measurement of the actual and commanded heliostat normal.

c. Constraints and limitations - up to 3 data sets can be operated on.

d. Processing - after initialization of the system of linear equation coefficients, BCSLSC enters a loop for the number of data points available. First BCSEPD is called to evaluate the partial derivatives; then BCSVEC calculates the vector components. Lambdas and deltas are added to find X, Y, and Z deltas. Then the B vector and A matrix are calculated and the loop is repeated if more data points are available.

3.2.11.4.1.21.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

N = Number of data points

2. Local Common - none

3. Global Common - none

Figure 3.2.11-21 Flowchart - BCSLIN

b. Output Data

1. Parameters - none

2. Local Common

DELTA_X, DELTA_Y, DELTA_Z
A and B

3. Global Common - none

c. Calls

BCSEPD Subroutines
BCSVEC

3.2.11.4.1.21.3 Internal Data Description

a. For local common definitions refer to paragraph
3.2.11.4.1.1.3 of BCS task.

b. Miscellaneous constants and local variables

3.2.11.4.1.21.4 Flowchart

See Figure 3.2.11-22 for the BCSLSC flowchart.

3.2.11.4.1.22 Submodule XXII - BCSSUN

3.2.11.4.1.22.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSSLQ to obtain the sun
unit vector for the current data point (date and time).

c. Constraints and limitations - local longitude and
latitude must be initialized. Up to three sets of
data can be processed. Existing interface to SUNPOS
subroutine in SUNVEC module must not be altered.

d. Processing - BCSSUN first initializes local common
constants. Then it computes geosentric latitude
in radians and converts longitude to radians. Before
calling SUNPOS, it converts values in local common
(BCSCOM) to date and time for that call and executes
SUNPOS. Finally BCSSUN places the returned sun unit
vector in local common.

3.2.11.4.1.22.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

I = Number of data point

Figure 3.2.11-22 Flowchart - BCSLSC 663

2. Local Common

Date, time of data point

3. Global Common

SLATG, SLONGG

b. Output Data

1. Parameters - none

2. Local Common

SX, SY, SZ - Sun vector for data point

3. Global Common - none

c. Calls

SUNPOJ subroutine (of SUNVEC module)

3.2.11.4.1.22.3 Internal Data Description

a. For local common definitions refer to paragraph 3.2.11.4.1.1.3 of BCS task.

b. Miscellaneous constants and local variables.

3.2.11.4.1.22.4 Flowchart

See Figure 3.2.11-23 for the BCSSUN flowchart.

3.2.11.4.1.23 Submodule XXIII - BCSNOR

3.2.11.4.1.23.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSLSQ to calculate the actual heliostat normal vector from given offset values.

c. Constraints and limitations - BCSNOR can handle 3 data points and 4 BCS targets.

d. Processing - first BCSNOR calculates the target to heliostat vector. Then it converts target angles to radians and calculates horizontal and vertical offset unit vectors. Then it takes the actual offsets into account and calculates the target normal. With simple vector addition to the sun unit vector, the heliostat normal vector is determined.

Figure 3.2.11-23 Flowchart - BCSSUN

3.2.11.4.1.23.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

I = Number of data point

NT = Number of BCS target

2. Local Common

XH, YH, ZH

XT, YT, ZT, AT, BT

U, V

3. Global Common - none

b. Output Data

1. Parameters - none

2. Local Common

XNA, YNA, ZNA

3. Global Common - none

c. Calls

COS

SIN Systems library routines

SQRT

3.2.11.4.1.23.3 Internal Data Description

a. For local common see paragraph 3.2.11.4.1.1.3 of BCS task

b. Miscellaneous constants and local variables

3.2.11.4.1.23.4 Flowchart

See Figure 3.2.11-24 for the BCSNOR flowchart.

3.2.11.4.1.24 Submodule XXIV - BCSEPD

3.2.11.4.1.24.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSLSC to evaluate partial derivatives.

c. Constraints and limitations - BCSLSC can handle up to 3 data points and calculates a 3 x 2 matrix for each data point.

Figure 3.2.11-24 Flowchart - BCSNOR

- d. Processing - lines and cosines are calculated for heliostat azimuth and elevation. From that the 6 elements of the 3 x 2 Jacobian matrix are calculated.

3.2.11.4.1.24.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

I = Number of data point

2. Local Common

AZ and EL

3. Global Common - none

b. Output Data

1. Parameters

P = Jacobian 3 x 2 matrix

2. Local Common - none

3. Global Common - none

c. Calls

SIN } System library routines
COS }

3.2.11.4.1.24.3 Internal Data Description

- a. For a description of local common refer to paragraph 3.2.11.4.1.1.3 of BCS task.
- b. Miscellaneous constants and local variables.

3.2.11.4.1.24.4 Flowchart

See Figure 3.2.11-25 for the BCSEPD flowchart.

3.2.11.4.1.25 Submodule XXV - BCSVEC

3.2.11.4.1.25.1 Description

- a. Language used - FORTRAN IV
- b. How invoked - called by BCSLSC to calculate individual vector terms in encoder bias vector.
- c. Constraints and limitations - BCSVEC can handle up to 3 data points.
- d. Processing - first the sines and cosines of the

Figure 3.2.11-25 Flowchart - BCSEPD

heliostat gimbal angles are calculated then the 3 x 3 set of Lambdas. Finally the delta vector is initialized to zero.

3.2.11.4.1.25.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

I = Number of data point

2. Local Common

AZ, EL - heliostat gimbal angles

XNA, YNA, ZNA - heliostat actual normal vector

3. Global Common - none

b. Output Data

1. Parameters - none

2. Local Common

LAMBDO, LAMBD1, LAMBD2

DELTA

3. Global Common - none

c. Calls

COS System library routines
SIN

3.2.11.4.1.25.3 Internal Data Description

a. For a description of local common refer to paragraph 3.2.11.4.1.1.3 of BCS task.

b. Miscellaneous constants and local variables.

3.2.11.4.1.25.4 Flowchart

See Figure 3.2.11-26 for the BCSVEC flowchart.

3.2.11.4.1.26 Submodule XXVI - BCSAL2

3.2.11.4.1.26.1 Description

a. Language used - FORTRAN IV

b. How invoked - called by BCSSEQ and BCSOCS to obtain alternate 2 stow gimbal positions.

Figure 3.2.11-26 Flowchart - BCSVEC

- c. Constraints and limitations - BCSAL2 can only read disk partition AL2 for one set of values at one time.
- d. Processing - first BCSAL2 calculates which record to read and reads that record into a holding buffer. Any cursors or EOFs are reported as a non-critical alarm. Then BCSAL2 sets up a buffer pointer and finally sets the azimuth and elevation gimbal angles via this pointer.

3.2.11.4.1.26.2 Data, Logic and Command Paths

a. Input Data

1. Parameters

HFCHC = MMA HFC/HC number

2. Local Common - AL2PTR

3. Global Common - AZIMG

b. Output Data

1. Parameters

AZIM ALT2STOW gimbal angles
ELEV

2. Local Common

AL2PTR

3. Global Common - none

c. Calls

BCSMES subroutine

3.2.11.4.1.26.3 Internal Data Description

- a. For a local common description, refer to BCS task paragraph 3.2.11.4.1.1.3
- b. Miscellaneous constants and local variables.

3.2.11.4.1.26.4 Flowchart

See Figure 3.2.11-27 for the BCSAL2 flowchart.

Figure 3.2.11-27 Flowchart - BCSAL2

3.2.11.5

Interface Description

- a. Input from the CS console via MMI and ENQUE/DEQUE.
- b. Input from OCS via local reads of core devices 1-5.
- c. Output to OCS via remake write to core devices 1-5.
- d. Output to CS console via CSO to visible cursor (error messages).
- e. Output to CS console via CSO to invisible cursor (file display, bias calculation results, and BCS active message).
- f. Output to CS console via ALMQUE for critical and non-critical alarms.
- g. Output to logger for bias calculation results.
- h. Disk access (read and write) to BCS and HCB partitions.
- i. Disk access (read only) to HCC and AL2 partitions.
- j. Magnetic tape read.
- k. Interface with MANMIF via TBUSYG global common.
- l. Interface with CSO via BCSLNG and CRTWRG global common.
- m. Interface with CMD via HCST3C and BCSBYG.

Some of the interfaces and the overall flow of the BCS task are depicted in Figure 3.2.11-28. An interface diagram within the HAC is shown in Figure 3.2.11-29.

3.2.11.6

Test Requirements

Verification of BCS's logic will be done by preparing a sample magnetic tape using SED. OCS responses will be simulated. BCS behavior will be observed using CRT displays, memory displays and real-time behavior of real or simulated heliostats.

Figure 3.2.11-28 CS-BCS Operational & Message Flow Diagram

- NOTES:
- 1 - Transition via BCSRANGE
 - 2 - Transition via BCSGO
 - 3 - Transition via BCSOFFJ
 - 4 - Transition via BCSCALC
 - 5 - Transition via BCSEND

MARTIN MARIETTA

Figure 3.2.11-29 BCS Interfaces Within HAC 676

3.3.1 Data Base Design

3.3.1.1 Purpose

The data base, consists of in-core global common areas and disk-resident data files.

The in-core global common COMDAT serves as a means of communication between individual stand-alone tasks and between tasks and their associated support submodules. A number of status words, maintained by various external interface tasks, provide communication of real-time conditions describing the field of heliostats, devices, and software statuses. Further, data base tables of aim points, sun position, and corridor assignments are kept in global common to support command construction. Status words for the prime-backup HAC configuration are maintained for system integrity, and field address mapping schemes are maintained.

The global common area COMQUE supports communication processing with the OCS, DAS, CS, graphics, receiver trip and alarms interfaces.

The disk data base contains tables of:

- a. Heliostat location coordinates;
- b. Wash angles;
- c. Stow angles;
- d. ALT1 stow angles;
- e. ALT2 stow; angles;
- f. Heliostat corridor assignments;
- g. BCS assignments;
- h. Aim-point coordinate arrays;
- i. Bias angles;
- j. Field status snap-shot;
- k. Corridor coordinates;
- l. BCS coordinates;
- m. Field address mappings;
- n. Alarm messages (ASCII);
- o. Alarm messages packed; and
- p. Segment numbers and pecking order.

3.3.1.2 Requirements

3.3.1.2.1 Design Requirement

Software Requirements listed in Section 3.1 of the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification, 12 June 1980, that apply to the data base are:

- a. Control of up to 2048 heliostats in all modes required to operate the heliostats;
- b. Monitor and display the operational status of all heliostats;
- c. Detect, report, and respond to failures and irregularities;
- d. Maintain a "Prime" and "Backup" system, as well as redundant field communications;
- e. Maintain a stable time base;
- f. Provide graphic displays of the heliostat field or field segments;
- g. Maintain safe beam control;
- h. Respond to receiver trip for emergency defocus;
- i. Provide the capability following power loss where the field may be commanded again within 60 seconds after power restoration;
- j. Maintain command/response protocol and data transfer with the OCS;
- k. Provide status data to the DAS; and
- l. Provide automatic control of beam characterization within the HAC.

In order to meet these requirements, the software in the HAC shall meet the following requirements supported in the data base:

- a. Control operational-phase sequences as required for integrated control of a field of up to 2048 heliostats;
- b. Generate and transmit heliostat mode commands (by HC, HFC, Segment, Wedge, Ring, Arc, Field) as required by the phase sequences during either operational or maintenance phases while maintaining safe beam control;
- c. Monitor the operational status of the heliostats as reported by the HFCs and report this status and detected irregularities in the form of displays and alarms;

- d. Maintain a "Backup" system by providing redundant field communications and providing data transfer sufficient to allow one-way "Backup" fail-over with minimal degradation;
- e. Provide a stable time base utilizing the WWV Trutime input for the "Prime" HAC time and internal time for the "Backup" HAC time. When the "Backup" HAC becomes "Prime", the WWV time will automatically be used, if available;
- f. Provide data transfer to the Chromatics Graphics Terminals sufficient for display of a finite number of graphic displays of the heliostat field or field segments and supporting alphanumeric information;
- g. Generate and transmit sun position information (once per frame) to the entire field;
- h. Maintain safety through controlled beam movement and inclusion area processing;
- i. Transmit emergency defocus command upon receiver trip;
- j. Provide automatic HFC initialization and the capability to command heliostats away from the receiver following initialization within 60 seconds after power restoration;
- k. Accept commands and transmit responses to the OCS including status and alarms;
- l. Respond to the STATUS command from the DAS by transmitting back the status message; and
- m. Provide automatic control of Beam Characterization upon operator request and establish communications and message transfer with the BCS task within the OCS.

3.3.1.2.2 Derived Requirements

The following derived requirements of individual modules have introduced the derived requirements of a data base:

Man-Machine Interface Module (MANMIF)

- a. Accept commands from the CS control console, OCS, DAS, CS graphics console, and read command files from disk;

- b. Decode command addresses for the Command Processor Module and convert commands to internal computer format;
- c. Check all commands for valid syntax;
- d. Generate error messages and route them to the appropriate output devices;
- e. Pass valid status commands to the Status Display Processor Module;
- f. Pass valid operational commands to the Command Processor Module;
- g. Log all commands on the console/printer with appropriate time stamps;
- h. Update a heliostat's bias disk file upon operator request; and
- i. Update aim-point array and perform inclusion-area checking.

Command Processor Module (CMDPRC)

- a. Check command arguments for reasonableness;
- b. Check heliostat's state for ability to execute commands;
- c. Translate operational commands and command sequences into individual HFC and HC commands;
- d. Maintain commanded heliostat mode table;
- e. Maintain sequence status arrays.

Sun Vector Module (SUNVEC)

- a. Calculate a unit sun vector as a function of universal time, on a once-per-second basis; and
- b. Format the sun-position unit vector into the format required for message packets and store in the data base.

Field Communications Processor Module (FLDCOM)

- a. Synchronize field operations by transmitting to the HFC computer a sun vector command once per frame;
- b. Generate, at the proper time in the time frame, the polling command for the HFC;

- c. Recieve the HC and HFC status in response to each polling command and save same in the data base;
- d. Transmit to the HFC, the operational commands generated by the Command Processor Module;
- e. Detect communications errors and automatically switch over to the redundant communications lines or the "Backup" computer and report these conditions to the Alarm Processor Module;
- f. Mark (calibrate) heliostats in both azimuth and elevation;
- g. Generate proper timing to accomplish all of the above in conjunction with HFC/HC firmware;
- h. Implement retransmission of HC commands (tracking and AZ/EL only; and
- i. Prevent communications failover upon detection of field power loss signal.

Alarm Processor Module (ALARMS)

- a. Monitor the heliostat status being returned from the field;
- b. Detect error conditions reported by the HC in that status;
- c. Report the alarms to the HAC operator using the alarms printer and an alarms area of the CS control console;
- d. Send alarm messages to the OCS through the interface;
- e. Display alarms detected by other software modules; and
- f. Maintain ONLINE/OFFLINE status for the heliostats.

Status Display Module (STATUS)

- a. Monitor heliostat status from status data reported by the HCs;
- b. Format field status;
- c. Display same on the STATUS area of the CS control console, updating display as required (see Figure 4);
- d. Respond to operator-entered commands for display status as reported from the MMI module, and format the status requested;
- e. Output the formatted status to the status printer; and

- f. Respond to OCS and DAS generated status requests by transmitting the requested status to the requestor.

Data Base Module (DBINIT)

- a. Define the global-common area, accessible to all applications tasks;
- b. Provide an initialization task to initialize the values in the global data base;
- c. Build appropriate data-base files for alarm messages, HC initialization coordinates, HC biases, control group mapping, BCS targets, STOW positions, WASH positions, corridor coordinates, initialization azimuth and elevation positions, and multiple aim-points;
- d. Read WWV time values from the WWV device if it is present and operating; and activate the "clock" task to perform time-base maintenance; and
- e. Initiate task execution sequences to the operating system; and allow for specification of "Prime" or "Bscup" computer and if "Prime" computer, make data available for transfer to "Backup", and if "Backup" computer, accept data from "Prime".

Operating System Modifications Module (MAXIVM)

- a. Generation of an operating system compatible with the peripheral equipment on the computer system;
- b. Universal time maintenance, using the WWVB Clock as a reference standard;
- c. Power fail/auto-restart capability;
- d. The HAC receives two signals (one the inverse of the other) from the Receiver System. One signal causes an emergency Defocus action--its inverse will allow an operator Defocus-Release action and a return to normal operations;
- e. Monitor status between computers to determine if the "Backup" should take over;
- f. Perform peripheral switching when necessary; and
- g. Detect a power loss signal and store this information in the data base for information to all tasks.

Graphics Display Processor Module (GRAPHC)

- a. Provide the functional interface with the graphics system in a command/response protocol;
- b. Provide the graphics system with sufficient data for graphics displays;
- c. Accept STHIWIND and DEFOCUS commands from the CS control room graphics function switches;
- d. Output data to the Chromatics Graphics Terminals only when requested; and
- e. Interface with the Chromatics Graphics Terminals through two distinct Dual Asynchronous Communications Channels (#4811).

External Interface Module (EXTINF)

- a. Interface with the CS Control Console by:
 - 1. Accepting inputs and passing these inputs to the respective modules; and
 - 2. Regulating the outputs to the CRT so that only one submodule is outputting at a time;
- b. Interface with the Chromatics Terminals by:
 - 1. Pass emergency STHIWIND and DEFOCUS commands to MANMIF module; and
 - 2. Data requests to the GRAPHC module.
- c. Interface with the OCS computer via a command/response and alarm-message protocol; and
- d. Interface with the DAS by accepting a STATUS request and transmitting a STATUS response.

BCS Automatic Processing Module (BCSMOD)

- a. Give the operator selection flexibility by using three different heliostat lists;
- b. Provide start capability of the automatic sequence that does not require further operator input;
- c. Execute control of a list of up to 60 heliostats and up to five blocking heliostats associated with each heliostat to be measured.

- d. Execute control over these measurements using up to four BCS targets in parallel;
- e. Communicate with the OCS for BCS measurements and offset values;
- f. Provide operator feedback for errors in automatic sequences; and
- g. Calculate azimuth and elevation bias changes using OCS measured centroid offsets from up to three BCS measurements.

In each case, inter-task communication is facilitated through global common storage of parameters, status, or flags. In cases where the data base is not specifically mentioned, its (data base) inclusion is designed to accent modular structure.

3.3.1.3 Design Approach

3.3.1.3.1 Functional Allocations

The in-core global common data base is designed to maintain the communications and temporary buffer storage for the software for support of a field of up to 2048 heliostats. As such, specific limitations exist on the data base and on certain variables within it. These constraints are outlined following each variable definition.

The general global common area COMDAT is subdivided into fourteen specific global commons, namely COM1S1, COM1S2, COM1S3, COM1S4, COM1S5, COM1S6, COM8S1, COM8S2, COM8S3, COM8S4, COMIN1, COMIN2, COMIN3, and COMIN4. A detailed description of each of these global common areas is given in Section 3.3.1.4. Table 3.3.1-I provides a cross reference for all the variables within the general global common area COMDAT and the related tasks. Table 3.3.1-II provides a cross reference between the global common areas and their associated tasks.

COMQUE is maintained as a communications global common as it must operate as a dynamic buffer. Its function is a message buffer for inter-processor communications, and for alarms awaiting output. Table 3.3.1-III provides a cross reference for all the message queues within global common area COMQUE.

The disk data base is used to maintain:

- 1. Externally supplied data for in-core global common initialization;
- 2. Heliostat locations for field initialization;
- 3. Corridor coordinates;
- 4. BCS coordinates;

5. Aim-point coordinates;
6. Stow angles;
7. Wash angles;
8. Alternate 1 stow angles;
9. Alternate 2 stow angles;
10. Heliostat bias angles;
11. Heliostat field status;
12. Alarm messages; and
13. BCS HC measurement files.

Tables 3.3.1-IV provides a cross reference for all the disk data base files and user tasks.

3.3.1.3.2 Resource Budgets

The global common data bases COMDAT and COMQUE require a total of 59,136 words of main memory at all times (COMDAT - 203 pages; COMQUE - 16 pages; COMQU2 - 16 pages). The disk data base requires 295,168 words.

3.3.1.4 Design Description

3.3.1.4.1 Structure

The following sections individually define variable and array structure. Variable and array contents are specifically defined and where applicable, individual bit settings are defined.

3.3.1.4.1.1 Global Common Area COM1S1

COM1S1 utilizes 16 pages of global common and is transferred to the backup HAC every second. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
a. AZIMG	2048	DBI, FCP	ALM, BHC, CMD, GET, BCS

Bit 0 Bit 15

Resolution - 0.043945 degrees
Initial value: 0

b. ELEVG 2048 DBI, FCP ALM, BHC, CMD

Bit 0 Bit 15

Initial value: #E000 (-90.0 deg)

3.3.1.4.1.2 Global Common Area COMIS2

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
a. <u>HCCMDG</u>	2048	BCS, BHC, CMD, SEQ. DBI, GET	BCS, BHC, SEQ

Bit 0

Constraints and limitations - HCCMDG is designed to maintain control for up to 2048 heliostats. Further, four modes and eight submodes are allowed.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
b. <u>HCDATG</u>	14336 (7 x 2048)	BCS, CMD, GET, SEQ, DBI	BCS, BHC

Description - HCDATG is the most recent data buffer sent to HC

Initial value: 0

Constraints and limitation - HCDATG is designed to maintain commands for up to 2048 heliostats.

3.3.1.4.1.3

Global Common Area COM1S3

COM1S3 utilizes 8 pages of global common and is transferred to the backup HAC every second. Unless otherwise noted, variable type is INTEGER * 2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASKS</u>
<u>GRSTG</u>	2048	DBI, STS	GRF

Description - Mode description for the graphics display, where:

- 0 = Not Installed
- 1 = Track
- 2 = Standby
- 3 = BCS
- 4 = Transition
- 5 = Stow
- 6 = Alternate 1 Stow
- 7 = Alternate 2 Stow
- 8 = Mark
- 9 = Directed Position
- 10 = Wash
- 11 = Initialized
- 12 = Offline

Initial value: 0 for those not installed, otherwise 12.687

3.3.1.4.1.4 Global Common Area COM1S4

COM1S4 utilizes 4 pages of global common and is transferred to the backup HAC every second. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
a. <u>BCSBYG</u>	1	BCS, CMD, DBI	BCS, CMD

Description - BCS targets busy status word.

Initial value: 0

Constraints and limitations - BCSBYG is designed to maintain the status for up to four BCS targets.

b. <u>BCSLNG</u>	1	BCS, DBI	BCS, CSO
------------------	---	----------	----------

Description - No. of lines used at bottom of screen (CS console) by BCS task.

Initial value: 0

Constraints and limitations - 14 lines will be used if the BCS file is being displayed; 5 lines will be used if BIAS data is being displayed; and 2 lines will be used to display the BCS mode if the other displays are not active.

c. <u>BCSHLG</u>	180	BCS, DBI	BCS
------------------	-----	----------	-----

Description - BCS heliostat list, including blocking heliostats.

Initial value: 0

Constraints and limitations - BCSHLG is designed to maintain up to 180 heliostats in the BCS procedure. Bit allocation for the heliostat number allows for 4096 heliostats.

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
d.	<u>BCSHSG</u>	192 (8x6x4).	BCS, DBI	BCS

Description - BCS active heliostat status.

Initial value: 0

Constraints and limitations - BCSHSG is designed to maintain BCS control for up to four BCS targets with six heliostats associated with each target during a BCS subsequence.

* Copy of HCCMDG (heliostat)

** Copy of HCDATG (heliostat, 1 to 7)

e.	<u>BCSTAG</u>	4	BCS, DBI	BCS
----	---------------	---	----------	-----

Description - Automatic BCS target status

Word 0

Word 3

Bit 0 Bit 15

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Operational
Mode

0 = Non-Operational
1 = Operational
2 = In Use

Constraints and limitations - BCSTAG is designed to maintain up to four BCS targets.

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
f.	<u>CMDBFG</u>	640 (10x64)	BHC, BHI, DBI	FCP

Description - Command buffer, command information to HFC/HC. Each 10 word buffer corresponds to a 20 byte command for each of the 64 HFCs. Command formats can be found in the Software/Firmware Functional Requirements Specification.

Constraints and limitations - None

g. There are six spare words in this common.

Constraints and limitations -

3.3.1.4.1.5 Global common area COM1S5

COM1S5 utilizes 1 page of global common and is transferred to the backup HAC every second. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
a. <u>AIMBSG</u>	1	DBI, DSK, MMI	MMI

Description - Aimpoint array busy word used when the aim-point is being updated on the disk data base. Values in the word have the meaning:

0 = Not in use
1-20 = Aim-point array (1-20) being updated (do not access)

Initial value: 0

b. <u>ALRMSG</u>	1	ALM, ALO, DBI	ALO
------------------	---	---------------	-----

Description - Alarm message response word that has the meaning:

0 = Tells ALO to clear critical alarms line (i.e. acknowledge)
1 = Tells ALO to display next critical message, if any
2 = Tells ALO to wait for operator acknowledgement of the last critical alarm.

Initial value: 0

c. <u>CORRSG</u>	8	BHC, SEQ, DBI	BHC, SEQ
------------------	---	---------------	----------

Description - Corridor status array; used to initiate corridor "walks" and mark corridors in use.

Word 0

Word 7

1	2	3	4	5	6	7	8

Corridors

Where each word has the meaning:

	<u>Going up</u>	<u>Going down</u>
0 = Free	16 = A	17 = A
1 = Ready for up	18 = B	19 = B
2 = Ready for down	20 = C	21 = C
	22 = D	23 = D

Initial value: 0

Constraints and limitations - CORRSG is designed to maintain corridor status for up to eight corridors.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
d. <u>CORSQG</u>	8	SEQ, DBI	SEQ

Description - Sequence number using corridor, where there are eight corridors corresponding to the eight words. The content of the words is the sequence number (1-16).

Initial value: 0

Constraints and limitations - CORSQG is designed to maintain sequence corridor usage for up to eight corridors.

e. <u>COUNTG</u>	1	ALM, ALO, DBI	ALM
------------------	---	---------------	-----

Description - Number of alarm messages in queue.

Initial value: 0

f. <u>CRTWRG</u>	1	CSI, CSO, DBI MMI, STS	CSI, CSO, BCS
------------------	---	---------------------------	---------------

Description - HAC operator's console visible line count and input/output use flag.

Bit 0 Bit 15

Operator input in progress, hold outputs to ISC conversational area

CRT line number

Initial value: 17

g. <u>CURHSG</u>	1	FCP, DBI	ALM, FCP
------------------	---	----------	----------

Description - Current HC being statused by FCP. CURHSG refers to the first HC and is incremented in steps of 4 up to 28.

Initial value: 0

h. <u>EMCC1G</u>	2	BHC, CMD, GET, SEQ, DBI	BHC
------------------	---	----------------------------	-----

Description - EMCC1G(1) is the emergency command counter (type 1); and represents a dynamic count of critical commands caused by either DEFOCUS or HI-WIND-STOW. EMCC1G(2) is the emergency command counter (type 2); it represents a dynamic count of critical commands caused by either HOLD or LOAD.

Initial value: 0

i. <u>EMSEQG</u>	1	CMD, SEQ, DBI	BCS, CMD, CFO, DSK, MMI
------------------	---	---------------	----------------------------

Description - Emergency sequence flag, where:

0 = No emergency sequence active

1 = Emergency sequence active, do not allow another HI-WIND-STOW command.

Initial value: 0

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
j.	<u>FIRSTG</u>	1	ALM, ALO, DBI	ALM, ALO

Description - Free storage index of first alarm in queue.
Initial value: 0

k.	<u>FLDSTG</u>	1	ALM, DBI, FCP	ALM, FCP
----	---------------	---	---------------	----------

Description - Field status (communications, power, and error).

0 = Field is in active state

1 = Field communications are enabled (a HFC has responded with a status response message)

Constraints and limitations - FLDSTG is designed to maintain up to eight communication lines and up to 16 error numbers.
Initial value: 0

l.	<u>GTIMEG</u>	14	TIK, TOK	ALO, BCS, MMI, STA, STS, SUN
----	---------------	----	----------	------------------------------

Description - Time keeping array, where the words contain:

Word 0: Year (GMT), (1980-00)
 Word 1: Day of year (GMT), (1-366)
 Word 2: Hour in day (GMT), (0-23)
 Word 3: Minutes in hour (GMT), (0-59)
 Word 4: Second in minute (GMT), (0-59)
 Word 5: Local year, (1980-0)
 Word 6: Local month number, (1-12)
 Word 7: Local day of month, (1-31)
 Word 8: Local hour, (0-23)
 Word 9: Time quality: (probable error)

0 - less than 1 msec
 1 - 1 msec
 2 - 5 msec
 3 - 50 msec
 4 - 500 msec
 5 - internal time

Word 10: Number of days in GMT year, (365-366)
 Word 11: Number of days in local month, (28-31)
 Word 12: GMT - Local hours offset, (6-8)
 Word 13: SPARE

Initial value: 0

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
m.	<u>LASTG</u>	1	ALM, ALO, DBI	ALM, ALO

Description - Free storage index of last alarm in queue.

Initial value: 0

n.	<u>LINESG</u>	16	ALM, DBI, FCP	ALM, FCP
----	---------------	----	---------------	----------

Description - Communication line status.

Initial value: #0800 for first 8 lines, 0 for remaining 8 lines.

Constraints and limitations - LINESG is designed for a maximum of sixteen communication lines.

o.	<u>LOKDEG</u>	1	MMI, DBI	BCS, CFO, DSK, MMI
----	---------------	---	----------	--------------------

Description - Defocus lock flag, which has the meaning:

ZERO = Defocus release command given
 NON-ZERO = Defocus command given

Initial value: 0

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
p.	<u>LOKSTG</u>	1	DBI, MMI	BCS, CFO, DSK, MMI

Description - STOW-HI-WIND lock flag, which has the meaning:

ZERO = STOW-HI-WIND release command given
 NON-ZERO = STOW-HI-WIND command given

Initial value: 0

q.	<u>PTRSG</u>	3	ALM, ALO, DBI	ALM, ALO
----	--------------	---	---------------	----------

Description - Free storage index for the next critical, non-critical, and system console output messages.

Initial value: 0

r.	<u>SUNPOG</u>	6	DBI, SUN	FCP
----	---------------	---	----------	-----

Variable type - INTEGER*4

Description: Sun position unit vector, where the double precision words have the meaning:

SUNPOG(1) = X component;

SUNPOG(2) = Y component;

SUNPOG(3) = Z component;

and each component is scaled B4.

Initial value: 0

s.	<u>SWOVG</u>	1	DBI, SWI, GET	SWI
----	--------------	---	---------------	-----

Description - Switchover to Backup HAC command word. If bit 15 is set, command the Backup HAC to initiate switchover.

aa.	<u>ALMOKG</u>	20	DBI, DSK	CMD, DSK
-----	---------------	----	----------	----------

Description - Array of 20 words corresponding to the 20 aim-point arrays, indicating whether the array can be used or not. The contents of the array words mean:

0 = disk data base aim-point array is not valid

1 = disk data base aim-point array is valid

Initial value: Determined from aimpoints that are loaded

bb.	<u>HFCS1G</u>	64	DBI, FCP	ALM, BHI
-----	---------------	----	----------	----------

Description - HFC status returned from the HFC's once per second.

Initial value: 0

cc. HFC2G

64

ALM, BHC, BHI,
DBI, FCP

ALM, BHC, BHI,
FCP

Description - HFC derived status

Initial value: #8000 not installed, otherwise 0

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
dd.	<u>MODEG</u>	12	DBI, STS	CMD, MMI, STA, STS

Description - Number of heliostats in each of the 12 modes.

Where the contents of MODEG have the Meaning.

WORD 0: Number of HCs in TRACK
WORD 1: Number of HCs in STANDBY
WORD 2: Number of HCs in BCS
WORD 3: Number of HCs in TRANSITION
WORD 4: Number of HCs in STOW
WORD 5: Number of HCs in ALT1STOW
WORD 6: Number of HCs in ALT2STOW
WORD 7: Number of HCs in MARK
WORD 8: Number of HCs in DIRECTED POSITION
WORD 9: Number of HCs in WASH
WORD 10: Number of HCs in INITIALIZATION
WORD 11: Number of HCs in OFFLINE

Initial value: 0

ee.	<u>SEQLSG</u>	16	CMD, DBI, SEQ	CMD, SEQ
-----	---------------	----	---------------	----------

Description - Sequence usage pool; unused entries are negative integers corresponding to the element number. While used entries are positive values corresponding to the element number.

Initial value: -1, -2,...,-16

ff.	<u>SEQNMG</u>	1	CMD, SEQ, DBI	SEQ, SWI
-----	---------------	---	---------------	----------

Description - Active sequences counter; it reflects the number of positive numbers in the SEQLSG array.

gg. Ten spare words of global common COM1S5 remain.

3.3.1.4.1.6 Global common area COM1S6

COM1S6 utilizes 4 pages of global common and is transferred to the backup HAC every second. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

a.	<u>SEQTPG</u>	1	DBI, SEQ	SEQ
----	---------------	---	----------	-----

Description - Time-link pointer for active sequences controlled by SEQ. It points to that cell (29 words) in the ACTVSG array which is to be visited next for sequence processing. Range is 1-16.

Initial value: 0

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
b. SEQAVG	1	DBI, SEQ	SEQ

Description - Next available cell in array ACTVSG for adding active sequences. Range is 1-16.

Initial value: 1

c. WAITSG	345 (15x23)	DBI, SEQ	SEQ
-----------	----------------	----------	-----

Description - Array used to store sequences waiting for all corridors to become free. A cell is 23 words long. See Figure 3.2.2-38 for format.

Initial value: 0

d. ACTVSG	464 (16x29)	DBI, SEQ	SEQ
-----------	----------------	----------	-----

Description - Array used to store active sequences (heliostats are moving). A cell is 29 words long. See Table 3.2.2-VII for format.

Initial value: 0 except the 4th word of Ith cell contains value I + 1 for cells 1-15; 4th word of cell 16 is 0.

e. There are 213 spare words of global common COM1S6.

3.3.1.4.1.7 Global common area COM8S1

COM8S1 utilizes 40 pages of global common and is transferred to the Backup HAC every eight seconds. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>AIMPTG</u>	10240 (5x2048)	DBI, GET	CMD
---------------	-------------------	----------	-----

Description - Aim-point array currently in use, and the order is based on ascending HC order (five words/HC)

WORD 0

WORD 4

X		Y		Z		ARRAY #

Initial value: 1st valid aim-point array from disk file AIM

Constraints and limitations - AIMPTG is designed to maintain aim-point coordinates for up to 2048 heliostats.

3.3.1.4.1.8 Global common area COM8S2

COM8S2 utilizes 16 pages of global common and is transferred to the Backup HAC every eight seconds. Unless otherwise noted, variable type is INTEGER*2, and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
a. HCST1G	2048	DBI, FCP	ALM, BHC, CMD, GET, SEQ, STA, STS

Description - HC status

Initial value: 0

Constraints and limitations - HCST1G is designed to maintain status for a maximum of 2048 heliostats.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
b. <u>HCST2G</u>	2048	ALM, CMD, DBI, FCP	ALM, BHC, CMD, STA, STS

Description - HC derived status

Initial value: #8000 if not installed otherwise #0800
 unmarked

Constraints and limitations - HCST2G is designed to maintain the derived status for a maximum of 2048 heliostats.

3.3.1.4.1.9 Global common area COM8S3

COM8S3 utilizes 8 pages of global common and is transferred to the Backup HAC every eight seconds. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

HCST3G

2048

BCS, CMD, SEQ, DBI

BCS, BHC, CMD, SEQ

Description - Corridor, BCS, and sequence assignments

BIT 0

BIT 15

CORRIDOR ASSIGNMENT

0: NOT ASSIGNED

1-8: ASSIGNMENT

9-15: UNDEFINED

SEQUENCE # (DYNAMIC)

0: HC NOT ASSIGNED

1-16: ASSIGNMENT

BCS TARGET ASSIGNMENT

0: SOUTH

1: WEST

2: NORTH

3: EAST

HC INVOLVED IN AUTO BCS OPERATIONS

HC IN STOW SEQUENCE

Initial value: corridor and BCS assignments

Constraints and limitations - HCST3G is designed to maintain HC assignments for a maximum of 2048 heliostats. Bit assignments for the BCS target limit the total to a maximum of four. Bit assignments for the corridor assignment limit the total to a maximum of 16.

3.3.1.4.1.10 Global common area COM8S4

COM8S4 utilizes eight pages of global common and is transferred to the Backup HAC every eight seconds. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
<u>PWHC1G</u>	2048	DBI	CMD

Description - Last-reported heliostat status (HCST1G) when field power loss processing occurs.

Initial value: 0

Constraints and limitations - PWHC1G is designed to maintain power lost status for a maximum of 2048 heliostats.

3.3.1.4.1.11 Global common area COMIN1

COMIN1 utilizes eight pages of global common and is transferred to the Backup HAC only at initialization time. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
<u>HC2MDG</u>	2048	DBI	ALO, BCS

Description - Mapping array to convert from the HAC internal numbering scheme to the MDAC external numbering scheme. The HAC array element number contains the MDAC number.

Initial value: HAC/MDAC number correspondence

Constraints and limitations - HC2MDG is designed to maintain a maximum of 2048 heliostat numbers.

3.3.1.4.1.12 Global common area COMIN2

COMIN2 utilizes eight pages of global common and is transferred to the Backup HAC only at initialization time. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
<u>MD2HCG</u>	2048	DBI	BCS, MMI

Description - HAC heliostat numbers indexed through the array MDNPRG (MDAC number per row) resulting in a mapping from the MDAC numbering scheme to the HAC numbering scheme.

Initial value: MDAC/HAC number correspondence

Constraints and limitations - MD2HCG is designed to maintain a maximum of 2048 heliostat numbers.

3.3.1.4.1.13 Global common area COMIN3

COMIN3 utilizes seventeen pages of global common and is transferred to the Backup HAC only at initialization time. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
a. <u>HCMAPG</u>	2109	CMD, DBI, MMI	CMD, MMI

Description - MMI - CMD interface buffer for heliostats involved in a command. MMI passes CMD heliostat numbers for the command and CMD returns HCMAPG with the success rate from processing the command. This array is used in conjunction with CPPG.

Format: 2 types:

1. Multiple blocks

```

HMAPG (1):  -N1          #HC's in first block
            (2):  HC#      N1 HC's in pecking order
                ⋮
            (N1+2): -N2          #HC's in second block
                HC#      N2 HC's in pecking order
                ⋮
NB
( Ni + NB+1): -999910      End of Data
i=1

```

where NB = # of blocks inherent in command addressing

2. Single block addressing:

```

HMAPG (1):  -Nt          Total #HC's in block
            (2):  HC#      Nt HC's
                ⋮
            (Nt+1):
                ⋮
            (Nt+2): -999910      End of Data

```

Initial value: 0

Constraints and limitations - HMAPG is designed to maintain command control over a maximum of 2048 heliostats broken into a maximum of 60 subsets.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
b. <u>MDNPRG</u>	30	DBI	BGS, DBI, MMI

Description - Each element contains the subtotal of the number of heliostats in each successive row of the field. MDNPRG is used to convert MDAC heliostats numbers into HAC heliostat numbers. The MDAC row number is the index into this array and the array element's content plus the MDAC row position is the index into the array MD2HCG.

Initial value: input from record 17 of disk file DIN

Constraints and limitations - MDNPRG is designed to maintain a heliostat field with a maximum of 29 rows.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
c. <u>SEGMPG</u>	2108	DBI	DBI, GRF, MMI

Description - HAC HC numbers ordered by segment number and subordered by pecking order. Each segment is preceded by the negative of the number of HCs in that segment. SEGMPG contains information only on segments that have installed heliostats. This array is used in conjunction with SEGPTG.

Initial value: input from records 34-50 of disk file DIN

Constraints and limitations - SEGMPG is designed to maintain a field of 2048 heliostats subdivided into a maximum of 60 segments

d. <u>SEGPTG</u>	60	DBI	DBI, GRF, MMI
------------------	----	-----	---------------

Description - Pointers to the array SEGMPG indicating the start of the number of HCs in a desired segment. When the contents of an element in SEGPTG is zero, it means that segment does not have any heliostats installed.

Initial value: input from record 17 of disk file DIN

Constraints and limitations - SEGPTG is designed to maintain a field subdivided into a maximum of 60 segments.

e. SPARI3 contains 45 words of spare for COMIN3

3.3.1.4.1.14 Global common area COMIN4

COMIN4 utilizes one page of global common and is transferred to the Backup HAC only at initialization time. Unless otherwise noted, variable type is INTEGER*2 and the size is in words.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
a. <u>CPUSG</u>	1	DBI, SWI	CLK, DBI, TIK, TOK

Description - CPU peculiar status

Initial value: determined from operator inputs to questions on system console

Constraints and limitations - The CPU peculiar status word CPUSG must never be transferred to the Backup HAC.

b. <u>BCSTGG</u>	20 (5x4)	DBI	BCS, CMD
------------------	-------------	-----	----------

Type - 24 bit fixed point, scaled B14

Description - BCS target in site reference orthogonal system

Initial value: input from record 50 of disk file DIN

Constraints and limitations - BCSTGG is designed to maintain BCS target coordinates for a maximum of four targets.

VARIABLE	SIZE	SET BY TASK(S)	USED BY TASK(S)
c. <u>CFABOG</u>	1	CFO, DBI, MMI	CFO

Description - Command file abort flag.

Initial value: 0

d. <u>CFWATG</u>	1	CFO, DBI, MMI	CFO
------------------	---	---------------	-----

Description - Delay execution of command file execution flag.

Initial value: 0

e. <u>CORRCG</u>	120 (5x3x8)	DBI	BHI, CMD, SEQ
------------------	----------------	-----	---------------

Type - 24 bit fixed point, scaled B14

Description - Corridor coordinates in site reference orthogonal system.

Initial value: input from record 51 of disk file DIN

Constraints and limitations - CORRCG is designed to maintain corridor coordinates for a maximum of eight corridors.

f. <u>CPPG</u>	4	DBI, MMI	CMO
----------------	---	----------	-----

Description - MMI - CMD interface command buffer

Initial value: 0

VARIABLE	SIZE	SET BY TASK(S)	USED BY TASK(S)
g. <u>CPPRTG</u>	1	CMD, DBI	MMI

Description - Command processor error return word.
Initial value: 0

h. <u>DISKRG</u>	4	DBI, MMI	DSK
------------------	---	----------	-----

Description - Command buffer for MMI - DSK interface

i. <u>HFCS3G</u>	64	DBI	BHC, BHI
------------------	----	-----	----------

Description - HFC corridor assignments

Initial value: corridor assignments for respective HFCs

Constraints and limitations - HFCS3G is designed to maintain corridor assignments for a maximum of 64 HFCs, and four corridors per HFC.

j. <u>ISTATG</u>	3	DBI, MMI	STA, STS
------------------	---	----------	----------

Description - MMI - STS interface status request indicator.

Initial value: 0

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
k.	<u>SLATG</u>	4	DBI	SUN

Type - Double precision real

Description - Latitude of facility in degrees (38.4 degree north)

Initial value: 38.4 degrees

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
l.	<u>SLONGG</u>	4	DBI	SUN

Type - Double precision real

Description - Longitude of facility in degrees (-117.0 degrees west)

Initial Value: -117.0 degrees

	<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USED BY TASK(s)</u>
m.	<u>TBUSYG</u>	2	All	-

Variable type - INTEGER*4

Description - Tasks active word (1 = active, 0 = inactive)

Module	ALARMS			BCS MOD	CMDPRC					DBINIT		EXTINF			FLD GRA	COM PHC
Task	ALM	ALO	BCS	BHC	BHI	CMD	GET	SEQ	CLK	DBI	CSI	CSO	EXI	FCP	GRF	
Bit	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15

Module	MANMIF				MAXIVM					STATUS	SUN VEC	MAXIVM				
Task	CFO	DSK	MMI	RTL	RTH	SWI	TOK	TIK	STA	STS	SUN	PLH	PLL			
Bit	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

The remaining variables in global common area COM1S5 are transferred to the Backup HAC every eight seconds.

Initial value: 0

n. SPRIN4 contains 27 spare words for COMIN4

3.3.1.4.1.15 Free Storage (COMQUE)

COMQUE is a dynamic buffer, initialized by task DBI (via QINIT), and used to queue and dequeue messages for output. It is 4096 words in size, with a set of internal pointers monitored by submodules LEASE, FREE, ENQU, and DEQU.

The COMQUE global common area consists of the single COMQUE array IQUEUE.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(s)</u>	<u>USE BY TASK(s)</u>	<u>LOCATION</u>
<u>IQUEUE</u>	4096	EXI, CSI, MMI DBI, ALM, ALO CMO, GET, SEQ BCS	GRF, CSO, CFO ALM, ALO, GET SEQ, BCS	Global common COMQUE

Description - Free storage area for messages awaiting output.

3.3.1.4.1.16 Free Storage COMQU2

COMQU2 is a dynamic buffer, initialized by task DBI (via QINIT), and used to queue and dequeue command messages for the Command Processor Module. It is 4096 words in size (16 pages), with a set of internal pointers monitored by submodules LEASE, FREE, ENQU and DEQU

The layout of COMQU2 is similar to COMQUE in Section 3.3.1.4.1.14.

<u>VARIABLE</u>	<u>SIZE</u>	<u>SET BY TASK(S)</u>	<u>USED BY TASK(S)</u>
CMDQUE	4096	CMD, GET, SEQ	GET, SEQ

3.3.1.4.1.17 Disk Data Base

The Disk Data Base is composed of thirteen files residing on the fixed disk. A description of each file is given in the following:

- a. Disk File AIM - The AIM file contains the 20 aim-point arrays for the heliostat field. This file has 2048 records and each record is 100 words. Figure 3.3.1.4-1 provides a record layout description of the AIM file.
- b. Disk File All - The All file contains the Alternate 1 Stow azimuth and elevation angles. This file has 32 records and each record is 128 words. Figure 3.3.1.4-2 provides a record layout description of the All file.

Figure 3.3.1.4-1 Format and Structure of the Aim-Point File (AIM)

Figure 3.3.1.4-2 Format and Structure of the HC ALT1STOW Angles Disk File (AL1)

- c. Disk File AL2 - The AL2 file contains the Alternate 2 Stow azimuth and elevation angles. This file has 32 records and each record is 128 words. Figure 3.3.1.4-3 provides a record layout description of the AL2 file.
- d. Disk File BAM - The BAM file contains the alarm messages. This file has 255 records and each record is 64 bytes. Each sector contains four alarm messages (records).
- e. Disk File DIN - The DIN file contains five mapping arrays, the corridor coordinates, and the BCS coordinates. This file has 67 records and each record is 128 words. Figure 3.3.1.4-4 provides a record layout description of the DIN file.
- f. Disk File HCC - The HCC file contains the heliostat locations. This file has 64 records and each record is 160 words. Figure 3.3.1.4-5 provides a record layout description of the HCC file.
- g. Disk File HCB - The HCB file contains the heliostat bias azimuth and elevation angles. This file has 32 records and each record is 128 words. Figure 3.3.1.4-6 provides a record layout description of the HCB file.
- h. Disk File SAM - The SAM file contains the source alarm messages. This file has 255 records and each record is 128 words. The record contents are provided in Figure 3.3.1.4-7.
- i. Disk File AIM - The AIM file (words 123-128 for each record) contains the real-time status, tracking configuration status, perserving the HC, that are in Track or Standby. This file has 2048 records and each uses 6 words per record. Figure 3.3.1.4-8 provides the record layout of disk file AIM.
- j. Disk File STO - The STO file contains the stow, azimuth and elevation angles. This file has 32 records and each record is 128 words. Figure 3.3.1.4-9 provides the record layout description of the STO file.
- k. Disk File WSH - The WSH file contains the Wash, azimuth and elevation angles. This file has 32 records and each record is 128 words. Figure 3.3.1.4-10 provides the record layout description of the WSH file.
- l. Disk File CFM - The CFM file contains command files in a SED directoried compressed source format. There may be up to 100 command files on this disk file.
- m. Disk File BCS - The BCS file contains up to three lists of HCs that are to be measured using the BCS automatic processing.

3.3.1.5 Interface Description

The global common data bases COMDAT, COMQU2, and COMQUE interface with tasks and submodules through FORTRAN INCLUDE statements and simple reference to those variables. Tables 3.3.1-I and 3.3.1-II shows cross-reference of all global common variables/arrays and the tasks which utilize them. Table 3.3.1-III cross-reference of all Disk Data Base files and the tasks which utilize them.

Figure 3.3.1.4-3 Format and Structure of ALT2STOW Angles Disk File (AL2)

Records 1-16

These records are used to store the MDAC to HFCHC number mapping (MD2HCG), used in conjunction with the MDNPRG array. This file is filled from a-priori values whenever card Type 1 is input through task DIN, and is read from the disk to fill the global common array. The array is stored in sequential fashion with element 1 of the array in record 1, word zero, and element 2048 stored in record 16, word 127.

Record 17 contains the MDAC number per row (MDNPRG) array using the first 30 words.

Record 17

Records 18-33 contain the HC2MDG array. Each record contains 128 words of the HC2MDG array in ascending order

Record 34-50 contain the SEGMPG array stored in ascending elements manner. Record 50 contains the last 60 words of the 2108 word array.

Record 50

Figure 3.3.1.4-4 Format and Structure of File DIN

Record 51

In all, 8 corridor definitions are stored in Record 51, using all 128 words in the record.

Records 52-67, pecking order and segment number packed.

Figure 3.3.1.4-4 (continued)

Figure 3.3.1.4-5 Format and Structure of the HC Locations Disk File (HCC)

Figure 3.3.1.4-6 Format and Structure of the Bias Disk File (HCB)

LINE	ALARM NO.	MESSAGE
1	ALARMDATA	REV.002 10/02/80
2	1	'MULTIPLE LINE ERRORS',A2,'LINE',4A4
3	2	'MULTIPLE HFC ERRORS; LINE',A2,'; HFC',4A4
4	3	'HC ERRORS; HFC',A2,'; HC',3(A4,A4,A1,'/',A1),A2
5	4	'EL MARK ENCOUNTERED: HFC'A2,'; HC'A4,'; EL=#'Z4,'BIAS=#'Z4
6	5	'AZ MARK ENCOUNTERED: HFC'A2,'; HC'A4,'; AZ=#'Z4,'BIAS=#Z4
7	10	'MISSING COMMAND RETURN; HFC'A2,'; HC'A4
8	11	'NO MOTION ERROR (AZ OR EL); HFC'A2,'; HC'A4
9	12	'HC UNAVAILABLE (WASH/OFFLINE) TO STHIWIND: HFC'A2,'; HC'A4
10	13	'HC CANNOT RETURN TO SAVE POSITION: HFC'A2,'; HC'A4
11	14	'SEQUENCE COMMAND TIMED OUT; HFC'A2,'; HC'A4
12	15	'EXTRA COMMAND RETURNED; HFC'A2,'; HC'A4
13	16	'HC MARK POSITION OUTSIDE TOLERANCE; HFC'A2,'; HC'A4
14	17	'HFC DETECTED HC/HFC COMM ERR--NO RESPONSE: HFC',A2,'; HC',A4
15	18	'HC LOST POWER - NEEDS LOADED: HFC',A2,'; HC',A4
16	19	'HC DETECTED HFC/HFC COMM ERROR: HFC',A2,'; HC',A4
17	20	'HFC DETECTED HAC/HFC COMMUNICATIONS ERROR; HFC',A2
18	22	'HAC TO HFC COMMUNICATIONS OUTPUT TIMED OUT; HFC',A2
19	23	'HAC TO HFC COMMUNICATIONS INPUT TIMED OUT; HFC',A2
20	24	'INVALID DATA RECEIVED FROM HFC',A2
21	25	'HFC DID NOT RECEIVE LAST COMMAND; HFC',A2
22	26	'FIRMWARE ERROR - HFC',A2,'STATUS=',Z4
23	30	'LINE COMMUNICATIONS OUTPUT ERROR; LINE'A2
24	31	'LINE COMMUNICATIONS INPUT ERROR; LINE'A2
25	32	'LINE FAILURE AND SWITCHOVER; LINE',A2
26	40	'FIELD POWER LOSS'
27	41	'COMMUNICATION FAILURE WITH FIELD'
28	50	'OPERATOR CONSOLE MALFUNCTION'
29	51	'CRT MALFUNCTION'
30	56	'DISK READ ERROR: TASK',A4,'; FILE',A4
31	57	'DISK WRITE ERROR: TASK',A4,'; FILE',A4
32	89	'RESTORE COMMAND ENCOUNTERED A HELIOSTAT IN THE WRONG MODE'
33	90	'CHANGE IN CLOCK ACCURACY STATUS FROM',2A4,'TO',2A4
34		

Figure 3.3.1.4-7 Alarm Messages Stored in File SAM/DBI

Where Save Mode = 0 : other
 > 0 : HC was at Track and its Aim point is in words 1-5
 < 0 : HC was at Stand by

Figure 3.3.1.4-8 Tracking Configuration Save File (AIM)

Figure 3.3.1.4-9 Format and Structure of HC Stow Angles Disk File (STO)

Figure 3.3.1.4-10 Format and Structure of the Wash Angles Disk File (WSH)

COMDAT VARIABLE	ALM	ALO	BCS	BHC	BHI	CMD	GET	SEQ	CLK	DBI	DIN	CSI	CSO	EXI	FCP	GRF	CFO	DSK	MMI	RTL	RTH	SWI	TOK	T1K	STA	STS	SUN
AIMBSG										S								S	S/U								
ALRMSG	U/S	S _U								S																	
AZIMG	U			U		U	U			S					S												
BCSBYG			S _U			S _U				S																	
BCSHLG			S _U							S																	
BCSHSG			S _U							S																	
BCSTAG			S _U							S																	
CMDBFG				S	S					S					U												
CORRSG				S _U				S _U		S																	
CORSQG								S _U		S																	
COUNTG	S _U	S								S																	
723 CRTWRG										S		S _U	S _U						S							S	
CURHSG	U									S					S _U												
ELEV G	U		U	U		U				S					S												
EMCC1G				S _U		S	S	S		S																	
EMSEQG			U			S _U		S		S							U	U	U								
FIRSTG	S _U	S _U								S																	
FLDSTG	S _U									S					S _U												
GRSTSG										S						U										S	
GTIMEG		U	U															U					S	S	U	U	U
HCCMDG			S _U	S _U		S	S	S _U		S																	
HCDATG			S _U	U		S	S	S		S																	
LASTG	S _U	S _U								S																	

S = Set
U = Used

Table 3.3.1-I Task Utilization of Global Common COMDAT
(1 Sec Transfer Frequency to Backup HAC)

3.3.1.6

Test Requirements

Verification of global common data bases COMDAT and COMQUE and Disk shall be achieved through utilization of "snapshot" techniques, indicating global common contents. Modification of global common through independent test routine simulation shall be accomplished to insure proper design and efficient use.

S = Set
U = Used

Table 3.3.1-I Task Utilization of Global Common COMDAT (con't.)
(1 Sec Transfer frequency to Backup HAC)

[illegible]

S = Set
U = Used

U = Used

Table 3.3.1-I Task Utilization of Global Common COMDAT (con't.)
(8 Sec Transfer Frequency to Backup HAC)

Table 3.3.1-I Task Utilization of Global Common COMDAT (con't.)
(Never Transferred to Backup HAC)

Table 3.3.1-II Global Common to Task Assignments

E = Enqueue
D = Dequeue

**Table 3.3.1-III Task Utilization of Message Queue Global Common COMQUE
(Transfer frequency to Backup, Every Second)**

[illegible]

I = Initialized
U = Used
S = Set

**Table 3.3.1-IV Task Utilization of Data Base Disk Files
(Transferred to Backup HAC only at Initialization)**

3.4 HFC Firmware Design

3.4.1 HFC Firmware Module - HFCMOD

3.4.1.1 Purpose

HFCMOD is the firmware which performs all HFC functions. These functions are:

- a. HAC I/O interfacing;
- b. HC I/O interfacing;
- c. HAC command processing;
- d. HC operations;
- e. Corridor walk calculations;
- f. Emergency corridor walk operations; and
- g. HFC timer maintenance.

HFCMOD is composed of nine major submodules which perform the seven HFC functions. These submodules are:

- a. HACIN which interfaces to the HAC/HFC input port;
- b. HACOUT which interfaces to the HAC/HFC output port;
- c. HCIN which interfaces to the HFC/HC input port;
- d. HCOU which interfaces to the HFC/HC output port;
- e. CMDI which processes HAC inputs and sun vector time-outs;
- f. HCOPS which sequences and performs all HC operations;
- g. CWCALC which handles corridor walking sequences;
- h. ECWOPS which controls emergency corridor walk-down sequencing in the event of HAC communications loss; and
- i. HFCTMR which generates two HFC system timers from the HFC hardware timer.

3.4.1.2 Requirements

3.4.1.2.1 Design Requirements

Section 3.1 of the Software/Firmware Functional Requirements requires the following of the HFC:

- a. Transmit commands to the HCs;
- b. Transmit status and data to the HAC;
- c. Initiate safe stowage commands to the HCs upon loss of HAC communication; and
- d. Control groups of HCs.

3.4.1.2.2

Derived Requirements

The following are the derived requirements for this module:

- a. Maintain communications with the HAC computer;
- b. Transmit the received commands for up to 32 HCs connected on the HFC and store the parameters for four corridors;
- c. Poll the specified four HCs in response to a polling command from the HAC;
- d. Transmit the status received from the four HCs to the HAC, upon request from the HAC;
- e. Detect communications errors in messages from HAC and HC; and
- f. On loss of communications with HAC computer, control stow of up to 32 heliostats using an approximate corridor walk (using last received sun vector).

3.4.1.3

Design Approach

3.4.1.3.1

Functional Allocations

HFCMOD is composed of nine submodules which are briefly described below:

- a. HACIN - collects message bytes received from the HAC, detects the start and end of each message, performs checksum calculation, and activates CMDI when a complete message is collected;
- b. HACOUT - transmits messages a byte at a time to the HAC, calculates the checksum, and appends the checksum to the end of the output message;
- c. HCIN - collects message bytes received from the HC, detects the start and end of each message, performs checksum calculation, and reactivates the calling submodule when a complete message is detected;

- d. HCOUNT - transmits messages a byte at a time to the HC, calculates the checksum and appends the checksum to the end of the output message;
- e. CMDI - controls the mode switching of the HC and associated processing according to current mode and current input, processes all HAC commands, and invokes CWCALC, HCOPS, and ECWOPS;
- f. HCOPS - performs all operations to the HCs including sun/command output, command response receipt, HC status polling and receipt, and status reformatting;
- g. CWCALC - performs the once-per-second updating of the corridor coordinates and handles corridor and points;
- h. ECWOPS - generates heliostat mode masks from the normal heliostat status buffer, sequences the emergency corridor walk when HAC communications is lost, and generates HC commands to accomplish the emergency corridor walk; and
- i. HFCTMR - maintains an 833 usec and a 50 msec timer for use by the other HFC submodules. The 833 usec timer is used for timing I/O intervals. The 50 msec timer is used to detect HAC communications failure and to provide a one second time base during emergency corridor-walk operations.

3.4.1.3.2

Resource Budgets

The HFC is limited to 4096 bytes of read-only memory (1080 of which are to be unused spare), 1152 bytes of read/write memory (732 of which are to be unused spare), 1.2288 MHz cycle time, and one counter/timer. The HFC firmware must fit in the available memory and execute within a one second cycle time.

HFCMOD is estimated to require 3016 bytes of read-only memory and 420 bytes of read/write memory.

3.4.1.4

Design Description

3.4.1.4.1

Module Structure (See figure 3.4.1-1)

HFCMOD consists of nine submodules. Five are interrupt driven and the remaining four are activated serially under software control. CMDI is the main controller of the four ground-level tasks (analogous to an executive or taskmaster in a large computer). Interrupt routines and ground level routines communicate through flag settings. Whenever the HFC is waiting for something to do (HAC input or sun vector time-out), CMDI loops and tests the HAC input flag and sun vector time-out flag. CWCALC, HCOPS, and ECWOPS are

Figure 3.4.1-1 HFC Module Structure

activated by CMDI when the sun vector is received from the HAC or each second by sun vector time-out when in the emergency corridor-walk mode. HACIN, HACOUT, HCIN, and HCOU are I/O interrupt service routines which perform byte oriented I/O and checksum calculations. In addition, the input routines detect message end by byte time-out when there is a gap in transmission. HFCTMR services the timer interrupts and provides task timers for the remainder of the HFC submodules.

3.4.1.4.2 Submodule I - Command Interpreter (CMDI)

3.4.1.4.2.1 Main Routine

3.4.1.4.2.1.1 Description

CMDI has three major functions: taskmaster, HFC mode determination, and HAC command processing. CMDI determines what processing is to be performed and what mode the HFC should be in according to the current HFC mode and the type of input stimulus. The HFC may be in the following modes:

- a. RESTART - this mode is entered on initial power-up and after completion of emergency corridor walk. During this mode the HFC switches between the primary and secondary communications lines at a 13-second rate until HAC communications is established. The HFC remains on the established line either primary or secondary until communications is lost;
- b. NORMAL - normal mode of HFC;
- c. ~~PRE-EMERGENCY~~ CORRIDOR WALK - this mode is entered when the sun vector times out (loss of HAC communications) to allow ten seconds for HAC recovery; and
- d. EMERGENCY CORRIDOR WALK - after eight seconds, emergency corridor walk begins and the HFC turns off all HAC I/O.

The input stimuli are:

- a. SUN VECTOR TIME-OUT - this is also used as a one-second time base when no sun vector is received from the HAC;
- b. SUN VECTOR RECEIVED;
- c. HC COMMAND RECEIVED - these are allowed only in the normal mode and the HFC must have been initialized;
- d. HFC INITIALIZATION RECEIVED - allowed only in normal mode, and they must occur in order (A & B

CULPs, A & B CLLPs, A & B DELTAs, C & D CULPs, C & D CLLPs, C & D DELTAs, and CORRIDOR-ASSIGNS); and

- e. HAC STATUS POLL RECEIVED - only allowed in normal mode.

Table 3.4.1-I is a state table describing the processes and mode changes of the HFC based on current mode and stimulus.

When in the normal mode, CMDI will process all commands from the HAC. HC commands are formatted into the HC command buffer for HCOPS, except corridor-walk commands which are channeled to CWCALC. Status commands are processed and completed in CMDI. A normal HAC status poll only requires output to the HAC since HCOPS has precollected and formatted the status buffer. HFC initialization commands are checked for correct order, and then the parameters (CULPs, CLLPs, etc...) are stored in the HFC data base. Receipt of a sun/sync packet from the HAC causes CMDI to act as a taskmaster, invoking HCOPS, CWCALC, and ECWOPS in that order. During normal and emergency corridor-walk modes, this happens once every second.

3.4.1.4.2.1.2 Data, Logic, and Command Paths

CMDI input are commands from the HAC. See section 3.4.1.5 for HAC/HFC communications description. CMDI's output is task activations, sun vector and HC command data to the HC command buffer, corridor-walk data to CWCALC, and HFC initialization data to the HFC data base. CMDI's logic and command paths are described above and in the flowcharts.

3.4.1.4.2.1.3 Internal Data Description

CMDI has no internal tables or data structures.

3.4.1.4.2.1.4 Flowcharts (See figures 3.4.1-2 and 3.4.1-3)

3.4.1.4.2.2 CMDI Subroutine I - CMDCMD

3.4.1.4.2.2.1 Description

CMDCMD is called by CMDI when the HAC is in the normal mode, a HAC command has been received, and the HFC is fully initialized. CMDCMD copies the data from the HAC message into the HC command buffer if the command is AZ/EL pointing, beam pointing, or HC initialization. Also, the selected HCs are removed from the corridor-walk command masks. If CMDCMD decodes a corridor-walk start command, CMDCMD generates the first corridor-walk command and sets up CWCALC to continue the corridor-walk operation. In all cases, CMDCMD sets the command return field in the HFC status.

Table 3.4.1-1 HFC State Transition Matrix
738

	POWER-UP	SUN-VECTOR TIME-OUT	SUN-VECTOR RECEIVED	HFC COMMAND RECEIVED	HFC INIT RECEIVED	HFC STAT POLL RECEIVED	ECW DONE
RESTART MODE		SWAP HAC LINES, RESET THE TIMER AND SET THE INIT PHASE BACK TO ZERO	RESET TIMER, GO NORMAL, THEN	IGNORE	IGNORE	IGNORE	
NORMAL MODE		GO TO ECW MODE	RESET TIMER, DO C.W. CALC THEN HCOPS AND STATUS REFORMAT	PROCESS IT IF INITIALIZED	PROCESS IT, BUT IF WRONG ORDER, SET INIT PHASE BACK TO ZERO	OUTPUT IF STAT & HC's	
PRE-EMERG. CW HOLD MODE 0-10 SECS.		SWAP HAC LINES, RESET TIMER, DO C.W. CALC THEN HCOPS AND STATUS REFORMAT	RESET TIMER, GO TO NORMAL MODE BUT WAIT FOR NEXT INPUT	IGNORE	IGNORE	IGNORE	
* EMERG. CW AFTER 10 SECS.		RESET TIMER, DO C.W. CALC THEN HCOPS AND STATUS REFORMAT	IGNORE	IGNORE	IGNORE	IGNORE	

* When emergency CW is all done, HFC goes to the restart mode.

FLOW CHART & BLOCK DIAGRAM

Figure 3.4.1-2

Flowcharts - CMDI

Figure 3.4.1-2

Flowcharts - CMDI (Cont.)

Figure 3.4.1-3

Flowcharts - NRMHI

3.4.1.4.2.2.2 Data, Logic and Command Paths

CMDCMD's input data is the HAC message from the HAC input buffer. CMDCMD outputs data to the HC command buffer and to CWCALC as described above.

3.4.1.4.2.2.3 Internal Data Description

CMDCMD has no internal tables or data structures.

3.4.1.4.2.2.4 Flowcharts (See figure 3.4.1-4)

3.4.1.4.2.3 CMDI Subroutine II - CMDINI

3.4.1.4.2.3.1 Description

CMDINI is called by CMDI when the HFC is in the normal mode and an HFC initialization command has been received. Because there are seven initialization message packets (A & B CULPs, A & B CLLPs, A & B Corridor Deltas, C & D CULPs, C & D CLLPs, C & D Deltas, and Corridor Assignments) which must be received to fully initialize the HFC, CMDINI insures they are all received by requiring them to be sent in sequence. Corridor assignments are the exception because they are allowed any time. If the current packet is received in sequence, the data is stored in the HFC data base and the initialization phase is advanced so the CMDINI expects the next packet in sequence. However, the corridor assignments being last, cause no phase update, and the initialization flags are reset. If the received packet is out of order, the initialization phase is reset to the start to force reinitialization. Finally, CMDINI sets the command return in the HFC status.

3.4.1.4.2.3.2 Data, Logic, and Command Paths

CMDINI's input data is the HAC message from the HAC input buffer. CMDINI outputs data to the HFC data base.

3.4.1.4.2.3.3 Internal Data Description

CMDINI's only internal data is the initialization phase, IPHASE.

3.4.1.4.2.3.4 Flowcharts (See figure 3.4.1-5)

3.4.1.4.2.4 CMDI Subroutine III - CMDS4

3.4.1.4.2.4.1 Description

CMDS4 is called by CMDI when the HAC requests the normal status for four heliostats. CMDS4 starts the HAC output of the status buffer and waits in a loop until it is complete.

Figure 3.4.1-4

Flowcharts - CMDCMD

Figure 3.4.1-5

Flowcharts - CMDINI

- 3.4.1.4.2.4.2 Data, Logic and Command Paths
- CMDS4's input is the four HC status buffer which was collected by HCOPS. CMDS4's output is to the HAC via HACOUT.
- 3.4.1.4.2.4.3 Internal Data Description
- CMDS4 has no internal data.
- 3.4.1.4.2.4.4 Flowcharts (see figure 3.4.1-6)
- 3.4.1.4.2.5 CMDI Subroutine IV - POL1HC
- 3.4.1.4.2.5.1 Description
- POL1HC status polls a single HC, specified by input argument, when called by either CMDI or HCOPS. POL1HC first sends out a status poll command via HCOU to the requested HC and then waits in a loop for it to complete. POL1HC then sets up a read via HCIN and a deadman timer via HFCTMR and waits for the event to occur. If HCIN received a byte before the timer times out, it will be reset for each byte until end-of-message. When POL1HC continues in response to timer time-out, it returns either one HC's status or a no-response code depending on the received byte count.
- 3.4.1.4.2.5.2 Data, Logic and Command Paths
- POL1HC receives the desired HC number as an argument and returns one HC's status to the calling routine.
- 3.4.1.4.2.5.3 Internal Data Description
- POL1HC contains a skeleton copy of the HC polling command.
- 3.4.1.4.2.5.4 Flowcharts (See figure 3.4.1-7)
- 3.4.1.4.3 Submodule II - Corridor-Walk Calculation (CWCALC)
- 3.4.1.4.3.1 Main Routine
- 3.4.1.4.3.1.1 Description
- CWCALC performs the corridor-walking operations in the HFC. CWCALC processes in two distinct steps. First, corridor coordinates are incremented (or decremented) and updated in the HC command buffer. The second step of CWCALC is corridor end-point detection. If, after the corridor coordinates are updated, the corridor Z-coordinate is greater than (less than) the Corridor Upper (Lower) Limit Point. For a walk-up (down)

CMDI Return 4 HC's Status

Figure 3.4.1-6

Flowcharts - CMDI4

Figure 3.4.1-7

Flowcharts -POLLHC

operation, CWCALC generates a final corridor-walk command to the Corridor Upper (Lower) Limit Point. One second later, CWCALC sets the corridor status as "not in use" and reenables the HC command response for walking the HCs to the HAC.

CWCALC utilizes two subroutines, CKDELTAB and CKDELTCD, to determine if a delta add or a delta subtract is required to update the current corridor vector. Endpoint detection is also a function of these subroutines.

The flowchart for CKDELTAB is detailed in figure 3.4.1-9. The CKDELTCD is identical in function to CKDELTAB which controls the corridor delta updates and endpoint detection for corridors C and D.

3.4.1.4.3.1.2 Data, Logic and Command Paths

CWCALC's input consists of CULP's, CLLPs, DELTAs from the HFC data base and corridor-walk start-up information from CMDI. CWCALC's output is corridor-walk commands to the HC command buffer and corridor status to the HFC status buffer.

3.4.1.4.3.1.3 Internal Data Description

CWCALC has no internal tables or data structures because it operates directly on the HC command buffer.

3.4.1.4.3.1.4 Flowcharts (See figures 3.4.1-8 and 3.4.1-9)

3.4.1.4.4 Submodule III - HC Operations (HCOPS)

3.4.1.4.4.1 Main Routine

3.4.1.4.4.1.1 Description

HCOPS performs all normal operations to the HCs except special, single-HC status polls. HCOPS has three subfunctions: HC sun/sync/command message output, command-response reception and formatting, and HC status polling and formatting. These three subfunctions are performed by subroutines HCOSSC, HCOCRR and HCOPOL, respectively. HCOPS calls these three subroutines in order.

3.4.1.4.4.1.2 Data, Logic and Command Paths

HCOPS calls the three subroutines once each, in order: HCOSSC, HCOCRR, HCOPOL. HCOPS input is the HC sun/sync/command buffer, the number of the first HC to be status polled, and HC inputs. HCOPS outputs commands to the HCs and updates the HFC/HC status buffer.

3.4.1.4.4.1.3 Internal Data Description

HCOPS has no internal tables or data structures because it operates on the HC input and output buffers directly.

Figure 3.4.1-8

Flowchart - CWCALC

Figure 3.4.1-9

Flowchart - CKDELTAB

- 3.4.1.4.4.1.4 Flowcharts (See figure 3.4.1-10)
- 3.4.1.4.4.2 HCOPS Subroutine I - HCOSSC
 - 3.4.1.4.4.2.1 Description

HCOSSC outputs the sun/sync/command message to the HCs when called by HCOPS in response to a HAC sun vector message or emergency Corridor-walk sun vector time-out. HCOSSC starts the output operation (carried on by HCOU) and waits in a loop until it completes. HCOSSC then clears the command mask and returns to HCOPS.
 - 3.4.1.4.4.2.2 Data, Logic and Command Paths

HCOSSC's input command is the sun/sync/command HC output buffer.
 - 3.4.1.4.4.2.3 Internal Data Description

HCOSSC has no internal data.
 - 3.4.1.4.4.2.4 Flowcharts (See figure 3.4.1-11)
- 3.4.1.4.4.3 HCOPS Subroutine II - HCOCRR
 - 3.4.1.4.4.3.1 Description

HCOCRR sets up the input of the command responses from the HCs, and reformats them into a 32-bit mask in the HFC output status. HCOCRR first sets up a 112 msec deadman timer and starts an HC input. HCOCRR then waits in a loop until the 112 msec timer times out. HCOCRR next decodes the HC number from each byte of command response input to know which bits in the command response mask to set. HCOCRR then returns to HCOPS.
 - 3.4.1.4.4.3.2 Data, Logic and Command Paths

HCOCRR's input is the command response bytes from the HCs via HCIN. HCOCRR's output is the HC command response mask.
 - 3.4.1.4.4.3.3 Internal Data Description

HCOCRR has no internal data.
 - 3.4.1.4.4.3.4 Flowcharts (See figure 3.4.1-12)
- 3.4.1.4.4.4 HCOPS Subroutine III - HCOPOL
 - 3.4.1.4.4.4.1 Description

HCOPOL collects and formats for HAC output from HC's status. HCOPOL performs the following sequence four times and then

HC Operations

{ Output Sun/sync/command to the HC's.

{ Read command response & format the C.R.
mask in status.

{ Poll 4 HC's for status and format for HAC
output.

{ to CMDI

Flowchart - HCOPS
Figure 3.4.1-10

HCOPS Sun/sync/command Output Subroutine

{ Send the sun/sync/command message via HCOU

{ Flag set by HCOU

{ But don't clear CW command masks

{ to HCOPS

Flowchart - HCOSSC
Figure 3.4.1-11

Flowchart - HCOCRR

Figure 3.4.1-12

returns to HCOPS:

- a. Delay five msec to allow message dead space on the HFC/HC line;
- b. Call POL1HC to get the status for the next HC; and
- c. Reformat the status into the status output buffer (destined for the HAC). If no response from HC, set the "HFC detected HC command error" bit in the output status.

HCOPOL receives from the HAC sun message the starting HC number (0, 4, 8, 12, 16, 20, 24, 28) and increments it at the end of the loop.

3.4.1.4.4.4.2 Data, Logic and Command Paths

HCOPOL's input is the HC number to be polled and the HC status from POL1HC. HCOPOL outputs reformatted HC status to the HAC output buffer.

3.4.1.4.4.4.3 Internal Data Description

HCOPOL operates directly on the HC input buffer and HAC output buffer.

3.4.1.4.4.4.4 Flowcharts (See figure 3.4.1-13)

3.4.1.4.5 Submodule IV - Emergency Corridor-Walk Operations (ECWOPS)

3.4.1.4.5.1 Main Routine

3.4.1.4.5.1.1 Description

ECWOPS is activated every second by CMDI either in response to a received sun vector from the HAC or to a sun vector time-out during emergency corridor-walk mode. During ECW mode, the sun vector time-out is the one-second time base. Normally, ECWOPS returns to CMDI, but when enabled in the ECW mode, ECWOPS sequences the emergency corridor-walk operations. ECWOPS calls two subroutines to perform the ECW operations. ECWMG generates, from the HC status collected by HCOPS, five mode masks used by the second subroutine, ECWSEQ, which does the actual step-by-step sequencing. ECWOPS calls ECWMG then ECWSEQ once each second and returns to CMDI.

3.4.1.4.5.1.2 Data, Logic and Command Paths

ECWOPS uses the HC status from HCOPS to generate the mode masks. ECWOPS' output is commands to the HC sun/sync/command output buffer.

Flowchart - HCOPOL
Figure 3.4.1-13

3.4.1.4.5.1.3 Internal Data Description

ECWOPS main routine has four masks generated by ECWMG for ECWSEQ. See ECWMG, section 3.4.1.4.5.2.

3.4.1.4.5.1.4 Flowcharts (See figure 3.4.1-14)

3.4.1.4.5.2 ECWOPS Subroutine I - ECWMG

3.4.1.4.5.2.1 Description

ECWMG is called by ECWOPS once-per-second during ECW mode. ECWMG generates six mode masks which are used by ECWSEQ to perform ECW operations. These masks are:

- a. UPHCS - 32-bit mask, one bit per HC, which indicates which heliostats are pointing on receiver or at stand-by;
- b. WRUPHCS - 32-bit mask, one bit per HC, which indicates which heliostats are walking up the corridor;
- c. WRDNHCS - 32-bit mask, one bit per HC, which indicates which heliostats are walking down the corridor;
- d. DNHCS - 32-bit mask, one bit per HC, which indicates which heliostats are at any of the lower limit points (CLLPs);
- e. HCPCS - 32-bit mask, one bit per HC, which indicates which heliostats have "position compare" status bit set; and
- f. BADHCS - 32-bit mask, one bit per HC, which indicates which heliostats do not respond to commands.

These mode masks have four HCs updated per second from the normal HC status buffer.

3.4.1.4.5.2.2 Data, Logic and Command Paths

ECWMG generates the five masks according to the following formulae:

UPHCS	(CMD + CR)	.	(RCVR + CULP + BCS)
WRUPHCS	(CMD + CR)	.	(UPWIREA + UPWIREB + UPWIREC + UPWIRED)
WRDNHCS	(CMD + CR)	.	(DNWIREA + DNWIREB + DNWIREC + DNWIRED)
DNHCS	A-CLLP + B-CLLP + C-CLLP + D-CLLP		
HCPCS	PC		

Where:

Flowchart - ECWOPS
Figure 3.4.1-14

- a. CMD is the bit mask of all heliostats commanded in the past second;
- b. CR is the command response mask generated by HCOPS;
- c. CULP, RCVR, BCS, CORRIDOR-A, CORRIDOR-B, CORRIDOR-C, CORRIDOR-D, and CLLP are heliostat submodes;
- d. PC is the collection of the position compare bits from the HCs;
- e. $\oplus$ is logical EXCLUSIVE-NOR;
- f. $\cdot$ is logical AND; and
- g. $+$ is logical OR.

Each second a four-bit slice of each command mask is updated for the four HCs that were just polled. (CMD + CR) is used full 32 bits each second so that failing heliostats will be removed from the masks.

ECWMG's input consists of the command response mask from HCOPS, four HC status from HCOPS, and the command mask for the previous second from ECWSEQ.

3.4.1.4.5.2.3 Internal Data Description

ECWMG's only internal data is used as temporary storage during calculation.

3.4.1.4.5.2.4 Flowcharts (See figures 3.4.1-15 and 3.4.1-16)

3.4.1.4.5.3 ECWOPS Subroutine II - ECWSEQ

3.4.1.4.5.3.1 Description

ECWSEQ is called once-per-second by ECWOPS during emergency corridor-walk mode. ECWSEQ used the mode masks generated by ECWMG and MG1HC to command HCs from all points at or above the CLLPs to stow. Eight seconds after ECWSEQ is first called, it inhibits all HAC I/O until the emergency walk is completed.

ECWSEQ then commands all HCs at or above the CULP to their respective CULPs, commands all HCs at the CLLP to stow, and continues any corridor walks in progress.

Two minutes later ECWSEQ commands any HCs at the top of the corridor to track their respective CULPs.

Ten seconds later ECWSEQ commands all HCs tracking the CULP to walk down their corridors.

Emergency Corridor Walk Mode
Generation Subroutine

Delete HC's which didn't respond
to a command

Mask out the 4 HC's polled this

Do for four HC's polled this second

Set correct mode & state bit in masks

to ECWOFS

Flowchart - ECWMG

Figure 3.4.1-15

Flowchart - MGLHC

Figure 3.4.1-16

ECWSEQ then commands all HCs at the bottom of the corridor to stow.

Two minutes later, after any corridor walk-downs are complete, ECWSEQ commands all HCs at the bottom of the corridor to stow.

ECWSEQ then initiates an eleven minute wait to verify all HCs have achieved the stow position. ECWSEQ then disables its internal clocks and the HFC hardware initiates a power-on restart.

3.4.1.4.5.3.2 Data, Logic and Command Paths

ECWSEQ sequences through nineteen steps or phases during the course of emergency corridor walking. The phases and their descriptions follow:

- a. PHASE 1 - Wait eight seconds to get full mode status from ECWMC, inhibit HAC I/O, advance phase, and command UPHCS on Corridor-A to A-CULP;
- b. PHASE 2 - Command UPHCS on Corridor-B to B-CULP and advance phase;
- c. PHASE 3 - Command UPHCS on Corridor-C to C-CULP and advance phase;
- d. PHASE 4 - Command UPHCS on Corridor-D to D-CULP and advance phase;
- e. PHASE 5 - command DNHCS to stow and advance phase;
- f. PHASE 6 - Initiate two-minute delay to allow HCs going up the corridor to complete and advance phase;
- g. PHASE 7 - If delay has expired, command WRUPHCS on Corridor-A to A-CULP and advance the phase; if not, return;
- h. PHASE 8 - Command WRUPHCS on Corridor-B to B-CULP and advance phase;
- i. PHASE 9 - Command WRUPHCS on Corridor-C to C-CULP and advance phase;
- j. PHASE 10 - Command WRUPHCS on Corridor-D to D-CULP advance phase, and initiate a ten-second wait to allow HCs to reach their respective CULPs;
- k. PHASE 11 - Command UPHCS on Corridor-A to walk down Corridor-A and advance phase;

- l. PHASE 12 - Command UPHCS on Corridor-B to walk down Corridor-B and advance phase.
- m. PHASE 13 - Command UPHCS on Corridor-C to walk down Corridor-C and advance phase.
- n. PHASE 14 - Command UPHCS on Corridor-D to walk down Corridor-D, advance phase, and initiate a ten-second wait.
- o. PHASE 15 - Command HCs at CLLP to STOW and advance phase.
- p. PHASE 16 - Initiate two-minute delay to allow HCs going down the corridor to complete and advance phase.
- q. PHASE 17 - Command HCs at CLLP to STOW, initiate an eleven-minute wait and advance phase.
- r. PHASE 18 - Wait until delay is complete and advance phase.
- s. PHASE 19 - Force restart of HFC by disabling all clocks.

3.4.1.4.5.3.3 Internal Data Description

ECWSEQ creates, each second, a mask for use by ECWMG which is the logical OR of those heliostats commanded on CORRIDOR-A, CORRIDOR-B, CORRIDOR-C, CORRIDOR-D, and either to beam or AZ/EL point. ECWPHZ is the phase index which controls the ECW sequence.

3.4.1.4.5.3.4 Flowcharts (see Figure 3.4.1-17)

3.4.1.4.6 Submodule V - HFC Timer Interrupt Handlers (HFCTMR)

3.4.1.4.6.1 Main Routine

3.4.1.4.6.1.1 Description

HFCTMR consists of two interrelated interrupt routines, HFCTOC and HFCTOF, which handle the MC6803's TOC and TOF timer interrupts. These routines maintain 833 usec and 50 msec granularity delay timers, respectively, for use by the HFC tasks. The routines count down the timers if active, and trigger the associated task when the count expires. HFCTMR is not a physical body of code but a logical grouping of two related functions.

Figure 3.4.1-17

Flowchart - ECWSEQ

3.4.1.4.6.1.2 Data, Logic and Command Paths

See HFCTOC (3.4.1.4.6.2.2) and HFCTOF (3.4.1.4.6.3.2).

3.4.1.4.6.1.3 Internal Data Description

See HFCTOC (3.4.1.4.6.2.3) and HFCTOF (3.4.1.4.6.3.3).

3.4.1.4.6.1.4 Flowcharts (see Figures 3.4.1-18 and 3.4.1-19).

3.4.1.4.6.2 HFCTMR Subroutine I - HFCTOC

3.4.1.4.6.2.1 Description

HFCTOC receives the MC6803's TOC (Timer Output Compare) interrupt when the TOC register contents matches the value of the MC6803's free running counter. HFCTOC adds 0400_{16} ($833 \mu\text{sec}$ at 1.2288 MHz) to the TOC register, subtracts one from all active timers, and triggers any tasks whose timers have just expired. HFCTOC then exits the interrupt level. HFCTOC's timers are used as I/O byte timers and I/O delay timers.

3.4.1.4.6.2.2 Data Logic and Command Paths

HFCTOC's input is the TOC interrupt and delay timer cell settings. HFCTOC's output is task triggers.

3.4.1.4.6.2.3 Internal Data Description

HFCTOC's timers are each one byte. A positive number indicates the timer is counting down. Zero means a task is to be triggered. Negative indicates an inactive timer.

3.4.1.4.6.2.4 Flowcharts (see Figure 3.4.1-18)

3.4.1.4.6.3 HFCTMR Subroutine II - HFCTOF

3.4.1.4.6.3.1 Description

HFCTOF receives the MC6803's TOF (Timer Over Flow) interrupt when the free running MC6803 counter goes from $FFFF_{16}$ to 0000_{16} . HFCTOF adds 1000_{16} to the counter to generate the 50 msec TOF interrupt (1000_{16} is an up count of 61440_{10} which at 1.2288 MHz is 50 msec). HFCTOF also adds 1000_{16} to the TOC register to resynchronize the TOC interrupt. Because the TOC is started out at 1200_{16} , this results in an adjustment from $\text{TOC} = 0200_{16}$ to $\text{TOC} = 1200_{16}$. HFCTOF then subtracts one from the sum vector timer and triggers CMDI if it has expired. HFCTOF then exits the interrupt level.

Flow Chart - HFC7OC

Figure 3.4.1-18

3.4.1.4.6.3.2 Data, Logic and Command Paths

HFCTOF's input consists of the MC6803 TOF interrupt, the TOC register, and the sun vector timer cell. HFCTOF's output is the trigger of CMDI.

3.4.1.4.6.3.3 Internal Data Description

HFCTOF's sun vector timer is a one-byte down counter. Positive indicates counting down, zero means task is to be triggered, and negative is past trigger until reset by CMDI.

3.4.1.4.6.3.4 Flowcharts (see Figure 3.4.1-19).

3.4.1.4.7 Submodule VI - HAC Input Interrupt Handler (HACIN)

3.4.1.4.7.1 Main Routine

3.4.1.4.7.1.1 Description

HACIN receives bytes from the HFC's ACIA device (essentially a UART) and stores them in the HAC input buffer until the HAC I/O byte timer expires indicating no byte received in approximately two I/O byte times. HACIND, a subroutine executed when I/O timer expires, HACIN also accumulates a checksum while receiving the message. HACIN resets the byte timer each time a new byte is received. HAC input start-up is accomplished by setting HACIN's I/O byte count positive. HACIN stores message bytes until its byte count goes negative, zeroing the checksum and resetting the store address. Reading bytes and accumulating checksum will continue until I/O byte time-out, even though no bytes are stored.

3.4.1.4.7.1.2 Logic, Data and Command Path

HACIN's input is message bytes, one byte per interrupt and the I/O byte timer. HACIN's output is the received message, byte-count and checksum accumulation.

3.4.1.4.7.1.3 Internal Data Description

HACIN's internal data consists of a byte-count, transfer address, and checksum accumulator.

3.4.1.4.7.1.4 Flowcharts (see Figure 3.4.1-20 and Figure 3.4.1-21).

Timer Overflow Interrupt

{ 61440₁₀ up count is 50 ms @ 1.2288 MHz

{ Timer is reset positive by CMDI

{ zero?

{ by a flag settling

{ the interrupt level

Flowchart - HFCTOF

Figure 3.4.1-19

(CONTINUED)

Flowchart - HACIN

Figure 3.4.1-20

HAC Input Timer Time-Out

{ Clean up any end conditions on the channel

{ To HFCTOC

Flowchart - HACIND

Figure 3.4.1-21

- 3.4.1.4.8 Submodule VII - HAC Output Interrupt Handler (HACOUT)
 - 3.4.1.4.8.1 Main Routine
 - 3.4.1.4.8.1.1 Description

HACOUT takes a message buffer created by another HFC task and outputs a byte at a time to the HFC's ACIA device (essentially a UART) when the "transmitter buffer empty" interrupt is received. HACOUT accumulates a checksum and outputs it as the last message byte. HACOUT retriggers the user task after the checksum has been output. HAC output startup is accomplished by setting HACOUT's byte count, transfer address, and checksum and then writing the first byte to the ACIA.
 - 3.4.1.4.8.1.2 Logic, Data and Command Paths

HACOUT's input is the message buffer from the user task. HACOUT's output is a byte at a time to the ACIA.
 - 3.4.1.4.8.1.3 Internal Data Description

HACOUT's internal data is the byte count, transfer address and checksum.
 - 3.4.1.4.8.1.4 Flowcharts (see Figure 3.4.1-22).
 - 3.4.1.4.9 Submodule VIII - HC Input Interrupt Handler (HCIN)
 - 3.4.1.4.9.1 Main Routine
 - 3.4.1.4.9.1.1 Description

HCIN receives bytes from the MC6803's internal UART and stores them in the HC input buffer until the HC I/O byte timer expires indicating no byte received in two I/O byte times. HCIND, a subroutine executed when I/O timer expires, then retriggers the user task. HCIN also accumulates a checksum while receiving the message. HCIN resets the byte timer each time a byte is received. HC input start-up is accomplished by setting HCIN's I/O byte count positive, zeroing the checksum, and resetting the store address. HCIN stores message bytes until the byte count goes negative. Reading bytes and accumulating checksum continues until I/O byte time-out even though no bytes are stored.
 - 3.4.1.4.9.1.2 Logic, Data and Command Paths

HCIN's input is a message byte per interrupt and the I/O byte timer. HCIN's output is the received message, byte count, and checksum accumulation.

HACOUT

HAC Output Interrupt

READ &
SAVE ACIA
STATUS

TC
= 0

YES

NO

TC
< 0

YES

NO

OUTPUT
NEXT BYTE
TO ACIA

SHUT-DOWN
THE ACIA

OUTPUT THE
CHECK
SUM

TA ← TA + 1
TC ← TC - 1
ADD BYTE TO
CHECK
SUM

SET FLAG
TO
TRIGGER
OMDI

TC ← TC - 1

Update Transfer
byte count

EXIT

{ The interrupt level

Flowchart - HACOUT

Figure 3.4.1-22

3.4.1.4.9.1.3 Internal Data Description

HCIN's internal data consists of a byte count, transfer address, and checksum accumulator.

3.4.1.4.9.1.4 Flowcharts (see Figures 3.4.1-23 and 3.4.1-24).

3.4.1.4.10 Submodule IX - HC Output Interrupt Handler (HCOUT)

3.4.1.4.10.1 Main Routine

3.4.1.4.10.1.1 Description

HCOUT takes a message buffer created by another HFC task and outputs a byte at a time to the MC6803's internal UART when the "transmitter buffer empty" interrupt is received. HCOUT accumulates a checksum and outputs it as the last message byte, and then retriggers the user task. HC output startup is accomplished by setting HCOUT's bytes count, transfer address, and checksum and then writing the first byte to the internal UART.

3.4.1.4.10.1.2 Logic, Data and Command Paths

HCOUT's input is the message buffer from the user task. HCOUT's output is a byte at a time to the MC6803's internal UART.

3.4.1.4.10.1.3 Internal Data Description

HCOUT's internal data is the byte count, checksum, and transfer address.

3.4.1.4.10.1.4 Flowcharts (see Figure 3.4.1-25).

(CONTINUED)

Flowchart - HCIN

Figure 3.4.1-23

HC Input Timer Time-out

{ Clean up any end conditions on the channel

→ To HFCTOC

Flowchart - HCIND

Figure 3.4.1-24

HCOUT

HC Output Interrupt

Flowchart - HCOUT
Figure 3.4.1-25

3.5 HC Firmware Design

3.5.1 HC Firmware Module - HCMOD

3.5.1.1 Purpose

The following is a description of the Operation of the Heliostat Controller Firmware, hereafter referred to as HCMOD. HCMOD consists of the following submodules:

- a. INIT - System initialization;
- b. SYSCLK - System clock and task activation control;
- c. POINT - Encoder data acquisition and motor control;
- d. SCIO - Serial communications handler; and
- e. CALC - Control Algorithm.

3.5.1.2 Requirements

3.5.1.2.1 Design Requirements

Section 3.1 of the Software/Firmware Functional Requirements requires the following of the HC:

- a. Determine heliostat azimuth and elevation position requirements;
- b. Control gimbal drive motors;
- c. Check gimbal axis sensors; and
- d. Provide gimbal axis position data to HAC.

3.5.1.2.2 Derived Requirements

HC firmware derived requirements are as follows:

- a. Maintain communications with the HFC, detecting communications errors;
- b. Calculate the desired azimuth and elevation angles based on sun vector and operational commands from the HFC;
- c. Control the azimuth and elevation motors to achieve the desired position;
- d. Maintain the azimuth and elevation encoder interfaces to provide gimbal angle information;
- e. Provide HC status information to the HFC upon a poll command;

- f. Execute an automatic reset upon detection of major errors; and
- g. Detect errors of heliostat operation (i.e., in-operative motors).

3.5.1.3

Design Approach

The following is intended to show the relationship of the various HCMOD submodules to system requirements (see Figure 3.5.1-1).

3.5.1.3.1

Functional Allocation

INIT - This submodule, activated by SYSTEM RESET, initiates system restart operations. System operating configuration is set, and internal registers and system memory locations are initialized (see Figure 3.5.1-2).

SYSCLK - This submodule, activated by a real-time clock, controls the time-critical functions of the HC. Time critical functions include the following:

- a. HC to HFC command response;
- b. Motor direction switching delays;
- c. Data acquisition; and
- d. Communications time-outs.

Non time-critical functions, such as command decoding, are enabled for activation by this submodule (see Figure 3.5.1-3 and Figure 3.5.1-4).

POINT - This submodule, activated by SYSCLK, is responsible for the real-time data acquisition of the gimbal angle incremental encoders.

Motor control is also a function of this submodule. Motor speed control is accomplished by comparison of commanded or calculated position and actual gimbal position error. If this error is significant (greater than eight bits), Hi speed operation is initiated. If the opposite condition exists, Lo speed operation is then initiated (see Figures 3.5.1-5, 3.5.1-6, and 3.5.1-7).

SCIO - This submodule, enabled by SYSCLK, handles serial communication with the HFC. Activation of this submodule is accomplished by receiver and transmitter interrupts. These interrupts, if enabled by SYSCLK, are vectored into SCIO directly.

HC SYSTEM MEMORY MAP

Figure 3.5.1-1

BACKGROUND TASKS

Figure 3.5.1-2 Flowcharts - INIT

Figure 3.5.1-3 SYSCLK

Figure 3.5.1-4 Flowchart - DECODE

Figure 3.5.1-5 Flowchart - POINT

Figure 3.5.1-6 Flowchart - READE

Figure 3.5.1-7 Flowchart - AZMOTR, ELMOTR, POWER

Data checksum and communication error detection (framing and overrun errors) are also handled in this submodule. Communication line turnaround is also a function of this submodule (see Figure 3.5.1-8).

CALC - This submodule, activated by SCIO, is a Background Task enabled for operation when a new sun vector is received from the HFC. This submodule contains the Cordic Positioning Algorithm (see Figure 3.5.1-9).

3.5.1.3.2

Resource Budgets

INIT	—	91 Bytes
SYSCLK	—	469 Bytes
POINT	—	457 Bytes
SCIO	—	263 Bytes
CALC	—	752 Bytes
VECTORS	—	<u>16 Bytes</u>

Total 2,048 Bytes Read-Only Program Memory

SYSTEM STACK	—	35 Bytes
SYSTEM VARIABLES	—	44 Bytes
CONTROL ALGORITHM	—	49 Bytes
COMMAND AND RESPONSE BUFFERS	—	<u>121 Bytes</u>

249 Bytes Read/Write Data Memory

3.5.1.3.2.1

Submodule Priority

Basic operating priority is as follows:

INIT
SYSCLK

SCIO
POINT
CALC

3.5.1.3.3

Operating System Variables

See Table 3.5.1-I.

3.5.1.4

Design Description

The HCMOD is a complete, stand-alone, firmware package designed to reside in 2048 bytes of mask programmed read-only memory.

HCMOD is essentially a foreground - background system designed to take advantage of the vectored interrupt capability of the MCM6803 microcomputer.

Figure 3.5.1-8 SCIO

POSITION CALCULATIONS

Figure 3.5.1-9 Flowcharts - CALC

HC SYSTEM OPERATING VARIABLES

VARIABLE	HEX LOCATION	SIZE IN BYTES
ENABLE	00A3	1

BIT BREAKDOWN

LSB	BIT 0 -	1 = New Sun Vector Received and Queued
	BIT 1 -	1 = Message Length Timer Enabled
	BIT 2 -	1 = Comm Loss (ISEL) Timer Enabled
	BIT 3 -	1 = Status Response Enabled
	BIT 4 -	1 = System Requests Initialization
	BIT 5 -	Spare
	BIT 6 -	1 = Control Algorithm Enabled
MSB	BIT 7 -	1 = Motor Control Enabled

TRXOK	00A4	1
-------	------	---

Loaded with calculated value that determines when HC responds with Command Response or Status -- when "0" transmitter is enabled.

SLOSS	00A5	1
-------	------	---

Loaded at receipt of incoming byte, also loaded at time of outgoing byte -- when "0" Command Decode is initiated or transmitter operation is disabled.

CLOSS	00A6	2
-------	------	---

Loaded at Sun Vector Receipt Time - when "0" HFC Comm Loss has been detected -- HC loads current position into Az and El Buffers and indicates Comm Loss Via Status Bits - Motor Control still active.

NEXVEC	00A8	2
--------	------	---

Used by SCIO Routine to control entry point of Receiver Buffer Full Interrupt.

IOVEC	00AA	
-------	------	--

Used by SCIO Routine in conjunction with "NEXVEC" to determine entry point for Receiver Buffer Full and Transmitter Buffer Empty Interrupts.

Table 3.5.1-I

HC SYSTEM OPERATING VARIABLES (Cont'd.)

VARIABLE	HEX LOCATION	SIZE IN BYTES
BYTECT	00AC	1
Used by SCIO Routine to count bytes of incoming and outgoing messages used with "CHARS".		
CHARS	00AD	1
Used by SCIO Routine to count actual message bytes received and sent (including Checksum).		
CKSM	00AE	1
Accumulates bytes for message checking - compared with received Checksum byte to determine message validity.		
MASK	00AF	1
8 Bit MASK with 1 bit set - used to determine if received beam pointing, Az, El, or Corridor Walk Command is valid for HC - Set bit position determined by Heliostat Address.		
MCOUNT	00B0	1
Counter loaded at motor control time - used to determine sample time of Encoders and Motor Control operation - Value currently loaded equals 2.5 ms.		
ACOUNT	00B1	(Azimuth) 2
ECOUNT	00B3	(Elevation) 2
Counters loaded at motor power time - Various counts appear in these locations based on delay time, required for Relay Switching, Motor Const, Direction Change.		

Table 3.5.1-I (continued)

HC SYSTEM OPERATING VARIABLES (Cont'd.)

VARIABLE	HEX LOCATION	SIZE IN BYTES
OLDAZ	00BB	1
Contains old 2 Bit Reading used to determine Direction of Count for Azimuth Encoder.		
ASTUCK	00BC	2
Used to determine length of time Heliostat is not moving - Not necessarily an error condition.		
AZABS	00BE	2
Actual absolute Azimuth Encoder position - Updated during read of Azimuth Encoder.		
AZBAZ	00C0	2
Downloaded Heliostat Azimuth Encoder Bias.		
FRZAZ	00C2	1
Set to non-zero value by Index Mark Interrupt Handler - Indicates AZ Mark Encountered. Moves Bias Value (AZBZ) to Position Buffer (AZABS).		
AZNC	C3	1
AZCP	C4	1
Variables used in Compare/No Compare Logic.		
OLDEL	00C5	1
ESTUCK	00C6	2
ELABS	00C8	2
ELBAZ	00CA	2
FRZEL	00CC	1
ELNC	00CD	1
Similar to above variables - for Elevation Motor Control.		
ELCP	00CE	1

HC SYSTEM OPERATING VARIABLES (Cont'd.)

VARIABLE	HEX LOCATIONS	SIZE IN BYTES
MOTWD	00B5	1
Bit positions in this memory word correspond directly to bit positions in Motor Controller Output Register. This motor word is built by point routine before actually powering motors.		
MCODE	00B6	1
Parameter used by point routines to determine which motor is being acted upon.		
ADDR	00B7	1
Used to store Heliostat Address.		
MSAVE	00B8	1
Temporary location to store current Motor On/Off Dir Status while altering.		
FREEZE	00B9	1
Indicates Status Poll has not yet been received. Disables update of returned Heliostat position.		
SYNC	00BA	1
Indicates a new Sun Vector has been received - Initiates Control Algorithm activation in background.		
Locations 00CF - 00FF are variables used by Control Algorithm.		

Table 3.5.1-I (continued)

HC SYSTEM OPERATING VARIABLES (Cont'd.)

VARIABLE	HEX LOCATION	SIZE IN BYTES
SUNX	2000	3
SUNY	2003	3
SUNZ	2006	3
Contain Downloaded Sun Vector Information.		
CMDT	2012	1
Contains first byte of last message command type and/or HC address.		
CMD5	2013	9
Latest Sun Vector sent from HFC.		
CMDW1M	2013	4
Latest Corridor-Walk 1 Mask.		
CMDW1V	2020	9
Latest Corridor-Walk 1 Vector.		
CMDW2M	2029	4
Latest Corridor-Walk 2 Mask.		
CMDW2V	202D	9
Latest Corridor-Walk 2 Vector.		
CMDW3M	2036	4
Latest Corridor-Walk 3 Mask.		
CMDW3V	203A	9
Latest Corridor-Walk 3 Vector.		
CMDW4M	2043	4
Latest Corridor-Walk 4 Mask.		
CMDW4V	2047	9
Latest Corridor-Walk 4 Vector.		
CMD	2050	
Latest Beam Point Mask if Beam Pointing.		
Latest AZ-EL Mask if being positioned. Azimuth and Elevation Commanded position.		
VECTOR	2058	9
Beam Pointing Vector if command was Point, Heliostat Vector if command was Initialization.		

The above variables are referred to as the Incoming Command Buffer.

Table 3.5.1-I (continued)

HC SYSTEM OPERATING VARIABLES (Cont'd.)

VARIABLE	HEX LOCATIONS	SIZE IN BYTES
HEADER	2061	1
Contains Heliostat Address and Mode Bits.		
STATUS	2062	2
Contains Heliostat Status Information.		
HZPOS	2064	2
ELPOS	2066	2
Contains Azimuth and Elevation Position data Freeze is set, contains position at marks.		
The above variables are referred to as Response Buffer.		
AZB2	2068	2
ELB2	206A	2
Bias Values.		
HELIX	2066	3
HELIY	206F	3
HELI2	2072	3
Current Heliostat Vector if system is Initialized.		
CMDAZ	2075	2
CMDEL	2077	2

These locations are loaded by Azimuth-Elevation Commands or by the Control Algorithm upon completion of its calculation (if Enabled). The Point Routine uses this information to position the Heliostat.

These locations are loaded with the current Heliostat position if loss of communications occurs.

Table 3.5.1-I (continued)

3.5.1.4.1

Model Structure

Refer to Figure 3.5.1-10, System Block Diagram and Figure 3.5.1-11, System State Diagram.

On power up, initiated by the RESET interrupt, the system sets parameters, I/O devices, and system status tables. The system watchdog timer and system clock interrupts are enabled. At this time the HC will accept HC initialization and status commands.

Once the initialization command has been decoded and accepted by the serial I/O handler (SCIO), motor control (POINT) activation is enabled. Motor power, direction, and speed are determined from the comparison of calculated or commanded positions and actual gimbal positions. Previous encoder readings are stored in memory to determine the existence of motor or encoder error conditions. Activation is accomplished during the servicing of the system clock interrupt (SYSCLK).

During the command checking process, performed by the serial communications handler, command response data is queued and the proper HC response window is calculated. Transmitter operation is initiated when the system clock routine determines that the proper delay period has elapsed.

Upon the receipt of a valid beam pointing or corridor walk command, HC target vectors are updated and the control algorithm (CALC) is enabled for activation.

The following system state diagram shows the interrelationships of the firmware system.

System State Table

State Number	State Description
1	Waiting to be initialized
2	Initialized, no action
3	Timer happens
4	Motor control started
5	Motor control running
6	Serial character out
7	Serial character in
8	Command decoded
9	Control algorithm

Figure 3.5.1-10

System Block Diagram

SYSTEM STATE DIAGRAM

Figure 3.5.1-11 System State Diagram

3.5.1.5

Interface Description

A complete interface description is detailed in Section 3.6.2.

3.5.1.6

Test Requirements

- a. Verification of HCMOD position algorithm will be accomplished by the use of the SIGMA 5 M6801 Software Simulator.
- b. Verification of HFCMOD and HCMOD communication timing will be accomplished by logic analyzer and oscilloscope inspection.
- c. Verification of HFCMOD and HCMOD logic will be accomplished by the use of the Heliosat Simulator P/N 40E5005132775.
- d. A complete functional test will be performed to determine pointing accuracy, motor speed control, timing, communication protocol, and error detecting capability.

3.6 Graphic Display Console (GDC) Software

3.6.1 Purpose

The primary purpose of the Graphic Display Console (GDC) is to provide graphical and alphanumeric displays which enhance operator understanding of the heliostat field operations. The secondary purpose of the GDC is to provide field commanding capabilities complementary to those of the CSS operator console.

The GDC-resident software system implements controls and displays which support these functions, and maintains necessary communications with the HAC. The allocation of processing functions between the HAC and GDC is designed to minimize risk to the time-critical functions of the HAC without unduly penalizing performance of the GDC.

3.6.2 Requirements

3.6.2.1 Design Requirements

Section 3.1 of the Software/Firmware Functional Requirements Specification (12 June 1980) requires:

- a. Control of up to 2048 heliostats in all modes;
- b. Display of the operational status of all heliostats; and
- c. Graphic displays of the heliostat field or field segments.

Section 3.2.1.9 of the Software/Firmware Functional Requirements Specification requires that the GDC module:

- a. Minimize the workload for the HAC to support graphic displays;
- b. Interface with the HAC using a command/response protocol;
- c. Provide full field and segment displays on operator demand. Figure 3.6.2-1 depicts the format planned for the full-field display. The shape and color encoding of the 12 different heliostat status symbols for the full-field display are shown in Figure 3.6.2-2. Figure 3.6.2-3 depicts the format planned for the segment displays. The shape and color encoding of the 12 different heliostat status symbols for the segment displays are shown in Figure 3.6.2-4.

The eight rectangles in the lower left portion of the screen are labeled and color coded to match the functions of the BLACK, BLUE, GREEN, CYAN, RED, MAGENTA, YELLOW, and WHITE function keys. The "Command>" line reflects the

Figure 3.6.2-1 Full Field Display
800

Command> Display Full Field

(hit RETURN to enter command)

Message>

	Display full field	Display segment		Defocus		High Wind Stow	Help
--	-----------------------	--------------------	--	---------	--	-------------------	------

T STOW

L OFFLINE

TRACK

ALT1STOW

INITIAL

STANDBY

ALT2STOW

MARK

BCS

WASH

DIR POS

TRANSIT

STOW
(green)

OFFLINE
(blue)

TRACK
(red)

ALT1STOW
(green)

INITIAL
(blue)

STANDBY
(yellow)

ALT2STOW
(green)

MARK
(green)

BCS
(cyan)

WASH
(green)

DIR POS
(magenta)

TRANSIT
(white)

Figure 3.6.2-2 - 3 X 5 Symbol/Color Encoding for Full Field Display

Command> Display segment 405
Message>

(hit RETURN to enter command)

I STOW	LOFFLINE	TRACK
ALT1STOW	INITIAL	STANDBY
ALT2STOW	MARK	BCS
WASH	DIR POS	TRANSIT

display full-field display segment defocus high wind help

STOW
(green)

OFFLINE
(blue)

TRACK
(red)

ALT1STOW
(green)

INITIAL
(blue)

STANDBY
(yellow)

ALT2STOW
(green)

MARK
(green)

BCS
(cyan)

WASH
(green)

DIR POS
(magenta)

TRANSIT
(white)

Figure 3.6.2-4 - 5 X 10 Symbol/Color Encoding for Segment Displays

current command being entered by operator function key and/or keyboard entries, while the "Message>" line displays prompting or error messages to the operator; and

- d. Transmit function switch STHWIND and DEFOCUS commands to the HAC.

3.6.2.2

Derived Requirements

The following requirements are derived from the explicit requirements listed in Section 3.6.2.1:

- a. The GDC module shall be capable of formatting and transmitting operator-entered emergency commands to the HAC;
- b. The GDC module shall be capable of receiving field status information from the HAC and formatting it into displays requested by the operator;
- c. The time delay for status information received from the HAC shall appear on the display and shall be invariant with respect to elapsed system run time; and
- d. Failure of the GDC or the need to restart shall not adversely impact operation of the HAC.

3.6.3

Design Approach

3.6.3.1

Functional Allocations

GDC software is comprised of the following modules:

- a. DIALOG - a background task activated by availability of inputs from the operator.

The inputs which are awaited at any given time depend on the particular operation being carried out. This task implements the operator interface, including:

1. Displaying, prompting and feedback messages.
 2. Processing display requests, including initiation of display maintenance tasks and sending requests to HAC.
 3. Processing (emergency) commands including sending command to HAC.
- b. FFDISP and SEGDISP - sets of three each background sub-tasks which initialize displays of full-field or segments, update the current display to reflect new information received from the HAC, and delete displays when they are no longer needed.

- c. FFPREP and SEGPREP - offline modules which preprocess field configuration data into formats convenient for rapid generation of run-time displays.
- d. EXEC - a set of executive service routines which provide for task synchronization and switching.
- e. PROHAC - a background task activated by receipt of a message from the HAC. This task checks validity of the message and then activates the appropriate task to update the display with the new data received from the HAC.
- f. RCV - an interrupt handler activated by receipt of data on the HAC/GDC serial communication line. This module assembles incoming bytes into message packets which are passed on to other tasks for processing.
- g. KBD - an interrupt handler activated by the keyboard/function-key console strobe interrupt. This module signals availability of input data from the keyboard/function-key input port to an application task waiting for that data.
- h. SEND - a module which formats and transmits message packets to the HAC.
- i. HELP - a module which displays explanatory material on the GDC screen.

3.6.3.2

Resource Budgets

Resource utilization of the GDC module is estimated as follows:

	number bytes of <u>code</u>	number bytes of <u>data</u>	number of disk <u>files</u>	total number of disk <u>sectors</u>
DIALOG				
FFDISP		12K	1	64
SEGDISP		2K	120	500
FFPREP				
SEGPREP				
EXEC				
PROHAC				
RCV				
KBD				
SEND				
HELP				

3.6.4 Design Description

3.6.4.1 Module Structure

The GDC software module consists of foreground (interrupt driven) submodules, background (real time) processing submodules, and offline (non-real time) preprocessing submodules.

The offline preprocessors (FFPREP and SEGPREP) are run whenever the field configuration data base on the HAC is updated. They manage transfer of formatted data from the HAC and conversion of that data into run-time efficient, unformatted, disk-resident files.

GDC online software includes foreground submodules which handle interrupts from the SIO link (RCV) and keyboard (KBD). These submodules provide data buffering and signal availability of data to the EXEC, which invokes appropriate background tasks to process the data. These background tasks include the interactive user/GDC dialogue controller (DIALOG), and real-time display updating tasks (FFDISP and SEGDISP). A collection of utility functions (UTIL) provides application-oriented numeric and character-handling capabilities to both offline and online processes.

Figure 3.6.4-1 shows the GDC module structure.

3.6.4.1.1 Submodule I - EXEC (Main Routine)

3.6.4.1.1.1 Description

The EXEC module will activate the background tasks as data is received from the HAC and operator keyboard. The interrupt handler, RCV, will set a flag when a complete message packet is received from the HAC. This flag is used by the EXEC to cause the background module PROHAC to be run. PROHAC checks that the message packet received is correct for the current state of the GDC and either issues an error message or sets a flag to activate the appropriate screen update task.

Similarly, when the KBD interrupt handler receives a keyboard/function-key interrupt, it will set a flag which causes the EXEC to activate the DIALOG task. The DIALOG task will echo keystrokes to the display, and then activate the appropriate tasks for updating the display or sending commands to the HAC.

3.6.4.1.1.2 Data, Logic and Command Paths

The EXEC routine is both the idle loop and task dispatcher for the GDC. It is initiated at system start-up and runs indefinitely.

3.6.4.1.1.3 Internal Data Description

There is no data internal to this submodule.

Figure 3.6.4-1 GDC Module Structure

3.6.4.1.1.4 Flowchart

See Figure 3.6.4-2 for the EXEC flowchart.

3.6.4.1.2 Submodule II - RCV

This module is the device driver for the receiving side of the serial I/O (SIO) link to the HAC. This module follows the standard Chromatics conventions for device drivers and thus includes three entry points:

- a. RCVISR - the interrupt service routine;
- b. HACAVAIL - tests for availability of data in the receive buffer; and
- c. HACDATA - returns the next character from the buffer.

This module is modified from the standard device driver in PROM as follows:

- a. A circular buffer of twice the maximum HAC message length (258 bytes) is used instead of a 2K-byte buffer;
- b. All characters prior to an STX character are discarded;
- c. All characters following an ETX character are discarded;
- d. Eight-bit binary data is stored in the buffer instead of masking off the high-order bit; and
- e. The flag HWAIT is cleared to indicate that the GDC is no longer waiting for a HAC.

3.6.4.1.2.1 Subroutine 1 - RCVISR

3.6.4.1.2.1.1 Description

This routine stores messages from the HAC in the receive buffer.

3.6.4.1.2.1.2 Data, Logic and Command Paths

This routine is activated at the interrupt level on receipt of a character on the asynchronous communication line from the HAC. This routine maintains the IN pointer to the circular buffer, BUF. It looks for an STX character and then stores all subsequent characters up to an ETX character in BUF. When an ETX is received, the HWAIT flag is cleared to indicate that a complete message packet has been received.

3.6.4.1.2.1.3 Internal Data Description

This routine maintains an internal flag indicating whether an STX character has been received.

Figure 3.6.4-2 Flowchart - EXEC

- 3.6.4.1.2.1.4 Flowchart
- See Figure 3.6.4-3 for RCVISR flowchart.
- 3.6.4.1.2.2 Subroutine 2 - HACAVAIL
- 3.6.4.1.2.2.1 Description
- This routine is used to check for data in the SIO receiver buffer.
- 3.6.4.1.2.2.2 Data, Logic and Command Paths
- This routine is called by EXEC to test for the availability of a HAC message. It returns a non-zero value if a message is available. It tests the HWAIT flag, which is set by SEND when a clear-to-send message is sent to the HAC, and is cleared by RCVISR when a complete message packet has been received from the HAC.
- 3.6.4.1.2.2.3 Internal Data Description
- There is no data internal to this subroutine.
- 3.6.4.1.2.2.4 Flowchart
- See Figure 3.6.4-4 for the HACAVAIL flowchart.
- 3.6.4.1.2.3 Subroutine 3 - HACDATA
- 3.6.4.1.2.3.1 Description
- This routine returns the next character from the SIO receive buffer.
- 3.6.4.1.2.3.2 Data, Logic and Command Paths
- This routine is called by all the HAC message-processing modules to access the HAC message. This routine maintains the OUT pointer to the circular buffer, BUF.
- 3.6.4.1.2.3.3 Internal Data Description
- There is no data internal to this subroutine.
- 3.6.4.1.2.3.4 Flowchart
- See Figure 3.6.4-5 for the HACDATA flowchart.
- 3.6.4.1.3 Submodule III - KBD
- This module is the device driver for the alphanumeric keyboard and function keys. This module follows the standard Chromatics conventions for device drivers and thus includes three entry points:

Figure 3.6.4-3 Flowchart - RCVISR

Figure 3.6.4-4 Flowchart - HACAVAIL

- a. KBDISR - the interrupt service routine;
- b. KBDATA - test for availability of data in the keyboard buffer; and
- c. KBDDATA - returns the next character from the buffer.

This module is modified from the standard device driver in PROM as follows:

- a. All keystrokes are passed directly to the keyboard buffer without expansion into escape sequences; and
- b. An output to ring the bell is made if the keyboard buffer overflows.

3.6.4.1.3.1 Subroutine 1 - KBDISR

3.6.4.1.3.1.1 Description

This routine stores input characters in the keyboard buffer.

3.6.4.1.3.1.2 Data, Logic and Command Paths

This routine is activated at the interrupt level on receipt of a keyboard input interrupt. This routine maintains the KIN pointer to the circular buffer, KBUF. It stores the incoming characters in KBUF. If KBUF is full, a keyboard output is done to ring the bell.

3.6.4.1.3.1.3 Internal Data Description

There is no data internal to this subroutine.

3.6.4.1.3.1.4 Flowchart

See Figure 3.6.4-6 for the KBDISR flowchart.

3.6.4.1.3.2 Subroutine 2 - KBDATA

3.6.4.1.3.2.1 Description

This routine is used to check for data in the keyboard buffer.

3.6.4.1.3.2.2 Data, Logic and Command Paths

This routine is called by EXEC to test for availability of keyboard input. It returns a non-zero value if one or more keystrokes have been stored in the keyboard buffer. The presence of data in the buffer is detected by comparing the KIN and KOUT pointers.

3.6.4.1.3.2.3 Internal Data Description

There is no data internal to this subroutine.

Figure 3.6.4-6 Flowchart - KBDISR

- 3.6.4.1.3.2.4 Flowchart
- See Figure 3.6.4-7 for the KBDVAAIL flowchart.
- 3.6.4.1.3.3 Subroutine 3 - KBDDATA
- 3.6.4.1.3.3.1 Description
- This routine returns the next character from the keyboard buffer.
- 3.6.4.1.3.3.2 Data, Logic and Command Paths
- This routine is called by the DIALOG module to access the operator inputs. This routine maintains the KOUT pointer to the circular buffer, KOUT.
- 3.6.4.1.3.3.3 Internal Data Description.
- There is no data internal to this subroutine.
- 3.6.4.1.3.3.4 Flowchart
- See Figure 3.6.4-8 for the KBDDATA flowchart.
- 3.6.4.1.4 Submodule IV - SEND (Main Routine)
- 3.6.4.1.4.1 Description
- The SEND module is called to transmit a message packet from the GDC to the HAC. Since the Chromatics does not support SIO transmit interrupts, the calling task is suspended until transmission is complete. The SEND module checks each message sent to the HAC, and if the message being sent is a clear-to-send (CTS, message ID = 4), it will set the HWAIT flag to indicate that the GDC is waiting for a HAC message.
- 3.6.4.1.4.2 Data, Logic and Command Paths
- The SEND module is called by PROHAC to send a CTS message to the HAC. The SEND module is called by DIALOG to send emergency commands to the HAC, and to notify the HAC of which status information is required for the current display.
- 3.6.4.1.4.3 Internal Data Description
- There is no data internal to this submodule.
- 3.6.4.1.4.4 Flowchart
- See Figure 3.6.4-9 for the SEND flowchart.

Figure 3.6.4-7 Flowchart - KBDVAIL

Figure 3.6.4-8 Flowchart - KBDDATA

Figure 3.6.4-9 Flowchart - SEND

3.6.4.1.5

Submodule V - DIALOG

3.6.4.1.5.1

Description

This section describes software modules responsible for implementing the GDC/operator interface. Specifically, it covers the handling of keyboard/function-key input, echoing of operator inputs, and interpretation of commands, as detailed below:

a. Keyboard Input

1. Keyboard Interrupt Service Routine
2. Return Keyboard Buffer Data

- b. Input Processing - This section describes the protocol for echoing and interpreting keyboard/function-key inputs. Due to the very limited number of commands available to the operator, a dialogue format which, though operator initiated, is relatively constraining with respect to errors the operator can make, seems desirable. Thus, it should be impossible for the operator to construct syntactically illegal commands. The following commands are available as function keys:

1. (Display) Full field
2. (Display) Segment
3. (Command) High-Wind Stow (STHWIND)
4. (Command) DEFOCUS
5. (Display) Help

When a function-key is pressed, the COMMAND line echo will reflect that command. Pressing another key causes the new selection to replace the previous. Commands are only acted upon when the RETURN key is pressed. In general, parameters to commands will be entered via the keyboard. The command key echo will include prompting information illustrating the type of parameter required. Parameter echos will replace the appropriate prompting field as they are entered. Among these commands, only the segment display requires any kind of amplifying information, namely the segment to be displayed. When this command is selected, the user will be prompted to enter the numeric designator for a segment as RNN, where R is a decimal digit (1:5) giving the Ring and NN is a decimal number (1:12) giving the wedge. Only decimal digits will be accepted as inputs to these fields.

A "menu" of color and position-encoded labeled function-keys will be displayed at the bottom of the screen during normal system operations.

- c. Command Execution - Recognition of commands and arguments will be communicated to other modules for execution via global variables and flags. In particular, display

commands will invoke the (FULL-FIELD) or (SEGMENT) display modules, emergency field commands will invoke the (COMMAND-HAC) module, and help requests will invoke the (HELP) module.

Emergency field commands will only be accepted at the control-room GDC.

3.6.4.1.5.2 Data, Logic and Command Paths

DIALOG is invoked by EXEC whenever KBIN signals availability of input. It interprets keyboard and function-key input according to programmed dialog specifications and signals actions to be taken to EXEC. Display echoing is handled via calls to utility routines. Passing of command input is controlled by a table-driven finite-state recognizer.

3.6.4.1.5.3 Internal Data Description

DIALOG maintains internal state information pertaining to commands and command arguments entered by the operator and the status of the command-echo display.

3.6.4.1.5.4 Flowchart

See Figure 3.6.4-10 for the DIALOG flowchart.

3.6.4.1.6 Submodule VI - FFDISP

The FFDISP module provides initialization and real-time updating of the full-field display. It includes the following functions:

- a. FFDISPI - full-field display initiation;
- b. FFDISPU - full-field display update; and
- c. FFDISPD - full-field display delete.

3.6.4.1.6.1 Subroutine 1 - FFDISPI (Full-Field Display Initialization)

3.6.4.1.6.1.1 Description

Disk-resident files generated by the full-field preprocessor module are read in to provide screen position information. Symbol sets constructed with the utility CHARDEF are read in. Precomputed display lists for symbol keys and titles are read in and executed. Non-resident assembly language utilities are rolled into memory from the disk.

3.6.4.1.6.1.2 Data, Logic and Command Paths

FFDISPI is invoked by EXEC whenever the full-field display is selected by the operator via DIALOG. After initializing memory-resident data structures from disk, FFDISPI schedules FFDISPU (update) and deletes itself.

Figure 3.6.4-10 Flowchart - DIALOG

3.6.4.1.6.1.3 Internal Data Description

FFDISPI allocates and initializes FFDISPU local status data base to "unknown."

3.6.4.1.6.1.4 Flowchart

See Figure 3.6.4-11 for the FFDISPI flowchart.

3.6.4.1.6.2 Subroutine 2 - FFDISPU (Full-Field Display Update)

3.6.4.1.6.2.1 Description

As full-field status messages are received from the HAC (via the communications processing task, HACREAD) this task is resumed to update the screen display to reflect status changes. This involves comparing new status information to previously-displayed data and updating the color and symbol for changed heliostats.

3.6.4.1.6.2.2 Data, Logic and Command Paths

FFDISPU is invoked by EXEC whenever it is active and data is available for it from SIOIN.

The FFDISPU module uses data from two principle sources:

- a. Memory-resident copy of disk data base generated by offline procedure FFPREP; gives screen location of each heliostat in full-field display; and
- b. Incoming real-time status messages, received via SIOIN.

This information is used to update the full-field display. Symbols for heliostats are redrawn only when a change from most-recently drawn status is detected.

The assembly language subroutine FULFLD performs the actual checking and updating operation.

3.6.4.1.6.2.3 Internal Data Description

FFDISPU maintains a local data base containing the status of each heliostat as most recently drawn on the display. This is used and maintained by subroutine FULFLD to eliminate redundant display updating.

3.6.4.1.6.2.4 Flowchart

See Figure 3.6.4-12 for the FFDISPU flowchart.

Figure 3.6.4-11 Flowchart - FFDISPI

Figure 3.6.4-12 Flowchart - FFDISPU

- 3.6.4.1.6.3 Subroutine 3 - FFDISPD (Full-Field Display Delete)
- 3.6.4.1.6.3.1 Description
- When the full-field display is no longer requested, the module clears the viewport(s) assigned to it, releases storage, and exits.
- 3.6.4.1.6.3.2 Data, Logic and Command Paths
- FFDISPD is scheduled by DIALOG whenever the full-field display is active and another display is selected.
- It deletes FFDISPU and itself to complete the shutdown operation.
- 3.6.4.1.6.3.3 Internal Data Description
- Local data base storage used by FFDISP is deallocated.
- 3.6.4.1.6.3.4 Flowchart
- See Figure 3.6.4-13 for the FFDISPD flowchart.
- 3.6.4.1.7 Submodule VII - SEGDISP
- The SEGDISP module provides initialization and real-time updating of the segment-level display. It includes the following functions:
- a. SEGDISPI - Segment display initialization;
 - b. SEGDISPU - Segment display update; and
 - c. SEGDISP D - Delete segment display.
- 3.6.4.1.7.1 Subroutine 1 - SEGDISPI (Segment Display Initialization)
- 3.6.4.1.7.1.1 Description
- Disk-resident files generated by the full-field preprocessor module are read in to provide screen position information for both graphical symbols and A/N table information. Precomputed display lists for heliostat (HFC) connection lines, labels, symbol keys, and table headers are read in and executed. Symbol sets constructed with the utility CHARDEF are read in. Non-resident assembly language utilities are rolled into memory from the disk.
- 3.6.4.1.7.1.2 Data, Logic and Command Paths
- SEGDISPI is invoked by EXEC whenever a segment-level display is selected by the operator via DIALOG.
- After initializing memory-resident data structures from disk, SEGDISPI schedules SEGDISPU (update) and deletes itself. Data includes heliostat screen locations (in pecking order) from SEGnnn.ARY and background display from SEGnnn.BUF.

Figure 3.6.4-13 Flowchart - FFDISPD

3.6.4.1.7.1.3 Internal Data Description

SEGDISP allocates and initializes SEGDISPU local status data base to "unknown."

3.6.4.1.7.1.4 Flowchart

See Figure 3.6.4-14 for the SEGDISPI flowchart.

3.6.4.1.7.2 Subroutine 2 - SEGDISPU (Segment Display Update)

3.6.4.1.7.2.1 Description

As full-field status messages are received from the HAC (via the communications processing task HACREAD), this task is resumed to update the screen display to reflect status changes. This involves comparing new status information to previously-displayed data and updating the color and symbol for changed heliostats. The A/N table is updated to reflect received information.

3.6.4.1.7.2.2 Data, Logic and Command Paths

SEGDISP is invoked by EXEC whenever it is active and data is available from SIOIN. The SEGDISP module uses data from two principle sources:

- a. Memory-resident copy of local disk data base prepared by SEGPREP: file SEGnnn.ARY contains screen location of each heliostat in given segments, and screen location of A/N table entry for each heliostat; file SEGnnn.BUF contains a display-list which draws the display background for the given segment; and
- b. Real-time heliostat status update messages from HAC via SIOIN: contain mode, azimuth/elevation, and target information.

SEGDISP updates both the graphical and A/N tabular displays to reflect changes in heliostat status.

3.6.4.1.7.2.3 Internal Data Description

SEGDISP maintains a local data base containing the status of each heliostat as most recently drawn on the graphic display and A/N table. This is used to eliminate redundant display updating.

3.6.4.1.7.2.4 Flowchart

See Figure 3.6.4-15 for the SEGDISPU flowchart.

Figure 3.6.4-14 Flowchart - SEGDISPI

Figure 3.6.4-15 Flowchart - SEGDISPU

- 3.6.4.1.7.3 Subroutine 3 - SEGDISPD (Delete Segment Display)
- 3.6.4.1.7.3.1 Description
- When the segment display is no longer requested, the module clears the viewport(s) assigned to it, releases storage, and exits.
- 3.6.4.1.7.3.2 Data, Logic and Command Paths
- SEGDISPD is invoked by EXEC whenever SEGDISPU is active and a different display is selected by the operator via DIALOG. It deletes SEGDISPU and itself to complete the shutdown process.
- 3.6.4.1.7.3.3 Internal Data Description
- Local data base storage used by SEGDISP is deallocated.
- 3.6.4.1.7.3.4 Flowchart
- See Figure 3.6.4-16 for the SEGDISPD flowchart.
- 3.6.4.1.8 Submodule VIII - HELP
- The HELP module displays explanatory material on the GDC screen. It includes the following functions:
- a. HELPI - Initialize HELP display; and
 - b. HELPD - Delete HELP display.
- 3.6.4.1.8.1 Subroutine 1 - HELPI (Initialize HELP Display)
- 3.6.4.1.8.1.1 Description
- This routine reads in a file of explanatory text material and writes it to the GDC main-display area. The text explains the overall operating scheme of the GDC.
- 3.6.4.1.8.1.2 Data, Logic and Command Paths
- The HELPI module is invoked by DIALOG when requested by the operator. It displays the (single page) HELP file and returns.
- 3.6.4.1.8.1.3 Internal Data Description
- HELPI reads in the display buffer file, HELP, and redraws it.
- 3.6.4.1.8.1.4 Flowchart
- See Figure 3.6.4-17 for the HELPI flowchart.

Figure 3.6.4-16 Flowchart - SEGDISPD

- 3.6.4.1.8.2 Subroutine 2 - HELPD (Delete HELP Display)
- 3.6.4.1.8.2.1 Description
- This routine clears the screen area used by the HELP display.
- 3.6.4.1.8.2.2 Data, Logic and Command Paths
- This routine is invoked by DIALOG when the HELP display is the current display and another display is selected.
- 3.6.4.1.8.2.3 Internal Data Description
- There is no data internal to this subroutine.
- 3.6.4.1.8.2.4 Flowchart
- See Figure 3.6.4-18 for the HELPD flowchart.
- 3.6.4.1.9 Submodule IX - PROHAC
- 3.6.4.1.9.1 Description
- This module processes HAC messages and is called by EXEC whenever a complete message packet is received from the HAC.
- The main routine verifies that the message received is valid for the current state of the GDC and either issues an error message, displays the error message packet received from the HAC, or causes the appropriate screen-update program to be invoked.
- 3.6.4.1.9.2 Data, Logic and Command Paths
- This module is invoked by EXEC whenever a HAC message is received. This module maintains the TERMID variable and tests the DISP variable which indicates which display is currently on the screen. The formats of the HAC messages are described in Section .
- 3.6.4.1.9.3 Internal Data Description
- This module extracts MSGID from the first byte of the current HAC message.
- 3.6.4.1.9.4 Flowchart
- See Figure 3.6.4-19 for the PROHAC flowchart.
- 3.6.4.1.10 Submodule X - FFPREP
- 3.6.4.1.10.1 Description
- This section describes the offline processing required to acquire non-dynamic data from the HAC and convert it into forms suitable

Figure 3.6.4-19 Flowchart - PROHAC

for use by the real-time dynamic full-field display module.
FFPREPROC includes the following functions:

- a. Data Acquisition - Data for this operation is sent from the HAC in formatted ASCII decimal. Each record has the format described in Table 3.6.4-I and is terminated by a CR. The records are sorted by (HFC,HC), or equivalently, by MMC heliostat number. The full complement of records (2048 nominal) will be sent even if some heliostats are not installed.
- b. Data Processing - The principle processing required for the full-field display is the mapping of heliostat positions from the real-world coordinate system to the screen space used by this display. This module will accept window (real world) and viewport (screen) limits to be used. The screen x,y pairs thus generated will be saved as a BASIC array file. Since HFC/HC numbering is implicit in this file, it is not stored. The segment assignment of each heliostat in this ordering will be saved to allow generation of a segment assignment display of the full field.

3.6.4.1.10.2 Data, Logic and Command Paths

This routine controls data communication, processing, and storage during full-field preprocessing. Data is obtained from the HAC via a (software) handshaking protocol controlled by the GDC. In response to each REQ to SEND, the HAC sends one ASCII record ended by a CR.

FFPREP creates files on the GDC local floppy disk which supports real-time processing by FFDISP.

3.6.4.1.10.3 Internal Data Description

- RECORD\$ - string containing ASCII data record from HAC
- NUM\$ - string containing ASCII representation of numeric field
- HXY% - integer array (2,2048) containing screen x,y coordinates of heliostats in MMC (HFC,HC) order
- WL - real array containing limits of user space window i.e., geographic coordinate boundaries of field
- VL - real array containing limits of display VIEWPORT, scaled to same proportions as WINDOW.

3.6.4.1.10.4 Flowchart

See Figure 3.6.4-20 for the FFPREP flowchart.

X	Y	H# (MDAC)	HFC/HC# (MMC)

836

Figure 3.6.4-20 Flowchart = FFPREP

3.6.4.1.11 Submodule XI - SEGPREP

3.6.4.1.11.1 Description

This section describes acquisition and processing of data needed to support real-time generation of individual segment level displays. SEGPREPROC includes the following functions:

- a. Data Acquisition - Data for this operation is sent from the HAC in formatted ASCII decimal. Each record is formatted as per Table 3.6.4-I and is terminated by a CR. The records are sorted by segment and pecking order. Since segment number information is present on each record, the identification of segment boundaries in the data stream is no problem. The order within each segment will be the basis for the identification information sent with real-time status messages.
- b. Data Processing - For each segment, the maximum and minimum north and east coordinate values over all heliostats in that segment must be determined to allow scaling of the segment geometry to optimally fit the screen viewport.

The alphanumeric tabular data accompanying each display will be sorted on MDAC heliostat number; i.e., the RRNN = row, position designation. Thus, each segment must be sorted on this field to compute the A/N table line assigned to each heliostat. Additionally, this ordering is needed to construct the HFC line connections which are displayed at the segment level.

For each segment, a display buffer file containing HFC connection lines, HFC labeling, and HC labels (in both the graphic and A/N table areas) will be constructed to minimize the time required to bring up displays at run time. A BASIC array file will be constructed for each segment. It will contain the (x,y) screen position of each heliostat symbol and its A/N table position (y).

3.6.4.1.11.2 Data, Logic and Command Paths

This routine controls data communication, processing and storage during segment-display preprocessing. Data is obtained from the HAC via a (software) handshaking protocol controlled by the GDC. In response to each REQ to SEND, the HAC sends one ASCII record ended by a CR.

SEGPREP creates files on the GDC local floppy disk which support real-time processing by SEGDISP.

3.6.4.1.11.3 Internal Data Description

- RECORD\$ - string containing ASCII data record from HAC
- NUM\$ - string containing ASCII representation of numeric field
- XYYN% - integer array (4,50) containing screen (x,y), MDAC HC number, and A/N table (y) per heliostat. in pecking order
- WL - real array containing geographic limits of segment
- VL - real array containing screen viewport limits
- HFCHC% - integer array (50) containing MMC number per heliostat
- IN% - sort index array (50) used to sort segment by HC number (MDAC) = row, position for HFC connection lines
- ROW% - index table pointing to IN% indicating start of each row; integer array (15)

3.6.4.1.11.4 Flowchart

See Figure 3.6.4-21 for the SEGPREP flowchart.

Figure 3.6.4-21 Flowchart - SEGPREP

3.7 System Interfaces

The major system interfaces within the Collector Subsystem are as follows: HAC/HFC interface, HFC/HC interface, HAC/OCS-DAS interface, HAC/GDC interface, HAC/Receiver interface, and the Man-Machine interface. Each of these interfaces is detailed in the following sections.

3.7.1 HAC/HFC Interface Description

This interface is a computer-to-computer interface over which the HAC computer transmits to the HFC computer sun position information, operational commands, and a status poll request. The HFC computer transmits to the HAC computer the HFC/HC status information. The transmissions are on one-second cycles, and the timing of the cycle is shown in Figure 3.7-1. The data is transmitted at a rate of 19.2 kilobaud. The format of the message packets are shown in Tables 3.7-I through 3.7-XII.

3.7.2 HFC/HC Interface Description

This interface is a computer-to-computer interface over which the HFC computer transmits to the HC computer sun position information, operational commands, and a status request. The HC computer transmits to the HFC computer its command response information and status information. These transmissions are cyclic in nature and are made on one-second intervals. The data is transmitted at a rate of 9.6 kilobaud. The format of the message packets is shown in Tables 3.7-XIII through 3.7-XVIII.

3.7.3 HAC/OCS-DAS Interface Description

This interface is a computer-to-computer interface over which the OCS computer transmits commands, status requests and BCS requests. The HAC computer responds with command responses, error messages, status information and BCS messages. The DAS computer transmits over a separate line status requests to which the HAC computer responds with the appropriate status data. These transmissions are of a stimulus/response nature and are transmitted at a 19.2 kilobaud rate. The OCS and DAS have separate lines to the HAC and to the backup HAC. The format of the message packets is shown in Tables 3.7-XIX through 3.7-XXXVII.

3.7.4 HAC/GDC Interface Description

This interface is a computer-to-Intelligent Terminal interface over which the HAC transmits field initialization data, status information and text messages. The GDC transmits to the HAC emergency commands, status requests, send-next-message and a reset command. These transmissions are of a stimulus/response nature and are transmitted at a 9.6 kilobaud rate. The format of the message packets is shown in Tables 3.7-XXXVII through 3.7-XLVI.

3.7.5

HAC/Receiver Interface Description

This interface is a physical four-wire interface with TTL-type signal levels. Each of the two pairs shall have the opposite signal of the other. The receiver will transmit a trip signal and it will remain on the line from the receiver until it has returned to normal. The HAC will respond to the trip signal by automatically creating a DEFOCUS command. A set of four wires will be provided to both the HAC and its backup with the wires grounded at the HAC. The Trip Logic is shown in Table 3.7-XLVII.

3.7.6

Man-Machine Interface Description

The man-machine interfaces to the Collector Subsystem can best be described in five parts: 1) the command input mode; 2) the command file execute mode; 3) the command logging mode; 4) the alarms response mode; and 5) the status display mode. All of these modes exist in the system simultaneously.

3.7.6.1

Command Input Mode

Commands may be input to the system from the CS Control Console, Control Room Graphics Console, and the OCS via a data link or from a command file on disk (see Section 3.7.6.2). The list of commands available to the operator is shown in Tables 3.2.1-I, and 3.2.1-II, along with the valid sources, addressing formats, mode constraints, and command descriptions. All commands must be entered with at least four characters of the command, and may be entered with up to as many characters as the command has. The operator may enter the two emergency commands via function keys on the Control Room Graphics Console. This input involves pressing the appropriate function key rather than typing in a particular command. Commands coming from the OCS will be in the same format as those entered from the CS Control Console. Incorrectly entered commands will result in error messages transmitted to the inputting source. Table 3.2.1-III shows the error messages which may be displayed.

3.7.6.2

Command File Execute Mode

This mode allows a sequence of commands and their respective execute times to be prestored on disk for subsequent automatic execution. The execute times are relative to the command file start time, which requires an operator input.

3.7.6.3

Command Logging Mode

All commands input to the system are echo printed on the CS Control Room line printer (logger) with appropriate time stamps. This includes commands input from the CS Control Console, command

files, CS Control Graphics emergency commands, OCS commands and DAS status requests.

3.7.6.4

Alarm Response Mode

Alarms for irregular Collector Subsystem operation are generated automatically and reported to the operator. Two modes of reporting are employed. A fixed, protected portion of the CS Control console's screen is dedicated to alarm reporting. Two types of alarms are reported on this console. The first class of alarm is the system critical alarm, which requires an operator response, or acknowledgement, through the keyboard before another critical message may be displayed. The second class of alarms is the system non-critical alarm, which requires no response and is overwritten automatically by the next non-critical alarm. A historical record of critical and non-critical alarms is also maintained on the CS Control Room line printer. Table 3.2.5-IV shows a sample of the types of alarm messages which will be generated.

3.7.6.5

Status Display Mode

The status of the Collector Subsystem is displayed in two ways. A fixed, protected portion of the CS Control console's screen is reserved for a continuously generated display of field status. This display shows date and time, and gives a title of the twelve modes which the heliostats can be in at any time. Beneath each of the mode titles is the total number of heliostats in that mode. (See Figure 3.2.6-2.) This field status is updated on a once-per-second basis, using the one-eighth of field status which was received in that second. In addition to the continuous status displayed on the CS Control console, additional status may be requested by the operator through the keyboard. This demand status may be in one of four formats, at the option of the operator. If the argument entered with the STATUS command is ALL, the format is a snapshot of the display on the CS Control console printed on the line printer. (See Figure 3.2.6-2 for format.) If the argument entered is an "H/NNNN," where the "NNNN" indicates the HC number whose status is being requested, then the HC number, its segment number, its azimuth and elevation angles, and the commanded mode and actual mode are printed on the line printer. (See Figure 3.2.6-3 for format.) If the argument entered with the STATUS command is "M/AAA", where "AAA" is the mode whose status is requested, then all HC numbers that are in the requested mode will be listed on the line printer. (See Figure 3.2.6-4 for format.) If the argument entered is "R/N," where "N" is the ring number whose status is requested, then all segments within that ring will be printed on the line printer. Associated with each segment printed will be the number of HCs in that segment, the number of HCs in the TRACK mode and the number of HCs in the STANDBY mode. In addition, totals will be summarized for the whole ring. (See Figure 3.2.6-5 for format.)

NOTE: For M, R or ALL status requests, the status can also be displayed on the CS Control Console by optionally typing "CRT" after the command argument.

Figure 3.7-1 FLDCOM One-Second Communications Time Frame

TABLE 3.7-I HC INITIALIZATION COMMAND FORMAT
MESSAGE LAYOUT

APPLICATION HAC HFC HC
INITIALIZATION
MESSAGE TYPE COMMAND

PROGRAMMER D. POWELL DATE 2/8/80

1	HEADER BYTE	1	06 ₁₆
	#		3 bits HFC #; 5 bits HC#
	CAZ		HC current azimuth
5	CEL	5	HC current elevation
	BAZ		HC bias azimuth
	BEL		HC bias elevation
10		10	
	HX		Heliostat field x-coord. (scaled binary point 14.)
15	HY	15	Heliostat field y-coord. (scaled binary point 14.)
	HZ		Heliostat field z-coord. (scaled binary point 14.)
20	CHECKSUM	20	8 bit checksum such that <u>all</u> message bytes sum to zero.
25		25	
30		30	

TABLE 3.7-II BEAM POINTING COMMAND FORMAT
MESSAGE LAYOUT

APPLICATION HAC HFC MESSAGE TYPE COMMAND BEAM POINTING

PROGRAMMER D. POWELL DATE 2/8/80

1	HEADER BYTE	1	
	#		08 TRACK RECEIVER
			0B TRACK BCS
			0C TRACK CULP
			0D TRACK CLLP
	HC		
5	SELECT MASK	5	3 BITS HFC#
			5 BITS o's
			32 BIT HC SELECT MASK FOR THIS COMMAND
			1=SELECT THIS HC
	BPX		Beam Pointing Target x-coord. (scaled at binary point 14.)
10	BPY	10	Beam Pointing Target y-coord. (scaled at binary point 14.)
	BPZ		Beam Pointing Target z-coord. (scaled at binary point 14.)
15		15	don't care
20	CHECKSUM	20	8 bit checksum such that <u>all</u> message bytes sum to zero.
25		25	
30		30	

TABLE 3.7-III. CORRIDOR WALK START-UP COMMAND FORMAT
MESSAGE LAYOUT

TABLE 3.7-IV AZIMUTH/ELEVATION POINTING COMMAND FORMAT

MESSAGE LAYOUT

APPLICATION			HAC	HFC	MESSAGE TYPE	AZ/EL POINTING COMMAND
PROGRAMMER			D. POWELL			DATE 2/8/80
1	HEADER BYTE		1			
	#					
	HC					
5	SELECT MASK		5			
	AZ					
10	EL		10			
15			15			
20	CHECKSUM		20			
25			25			
30			30			

3 bits HFC#

5 bits o's

18 AZ/EL STOW

19 AZ/EL SEEK MARKS

1A AZ/EL WASH

1B AZ/EL DIR POSITION

1C AZ/EL ALT1STOW

1D AZ/EL ALT2STOW

32 bit HC select mask for this command.

1=select this HC

Command azimuth

Command elevation

don't care

8 bit checksum such that all bytes of the message sum to zero.

TABLE 3.7-V STATUS POLL COMMAND FORMAT
MESSAGE LAYOUT

APPLICATION HAC HFC MESSAGE TYPE STATUS POLL

PROGRAMMER D. POWELL DATE 2/8/80

1	HEADER BYTE	1	<div> 3 bits HFC#; 5 bits HC# if single HC poll don't care <u>all</u> message bytes sum to zero. </div>
	#		
	CHECKSUM		
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-VI FOUR HELIOSTAT STATUS RESPONSE FORMAT

MESSAGE LAYOUT

APPLICATION HFC HAC			4-HC STATUS MESSAGE TYPE RESPONSE
PROGRAMMER D. POWELL			DATE 2/8/80
1	HEADER BYTE	1	50 ₁₆
	#		3 bit HFC#;
			5 bit HC# of the first HC in the group
5	COMMAND RECEIVED MASK	5	32 bits of command received mask 0=this HC did not receive a command 1=HC received a command OK
	HC STATUS		See breakdown of HC status-- HC status for HC#n
10	CAZ	10	Current azimuth for HC#n
	CEL		Current elevation for HC#n
	HC STATUS		See breakdown of HC status-- HC status for HC# n+1
15	CAZ	15	Current azimuth for HC# n+1
	CEL		Current elevation for HC# n+1
	HC STATUS		See breakdown of HC status-- HC status for HC# n+2
20	CAZ	20	Current azimuth for HC# n+2
	CEL		Current elevation for HC# n+2
25	HC STATUS	25	See breakdown of HC status-- HC status for HC# n+3
	CAZ		Current azimuth for HC# n+3
	CEL		Current elevation for HC# n+3
30	HFC STATUS	30	See breakdown of HFC status-- HFC status this HFC

MESSAGE LAYOUT

STATUS

MESSAGE TYPE RESPONSE

DATE 2/8/80

[illegible]

MESSAGE LAYOUT

APPLICATION HC STATUS BYTES MESSAGE TYPE HC STATUS BIT BREAKDOWN

PROGRAMMER D. Powell

DATE 2/8/80

TABLE 3.7-VII HELIOSTAT CONTROLLER STATUS BIT BREAKDOWN

MESSAGE LAYOUT

TABLE 3.7-VIII HFC STATUS BREAKDOWN

MESSAGE LAYOUT

APPLICATION HAC HFC MESSAGE TYPE SUN/SYNC

PROGRAMMER D. A. Powell DATE 2/8/80

1	HEADER BYTE	1	80 ₁₆ Means SUN/SYNC.
	SPN		HC number of first of four consecutive HCs to be status polled this second.
	SX		Sun unit vecor x-coordinate (scaled at binary point 4).
5		5	don't care
	SY		Sun unit vector y-coordinate (scaled at binary point 4).
10		10	don't care
	SZ		Sun unit vector z-coordinates (scaled at binary point 4).
			don't care
15	CHECKSUM	15	8-bit Checksum such that all message bytes, including the Checksum, sum to zero.
20		20	
25		25	
30		30	

TABLE 3.7-IX SUN POSITION COMMAND FORMAT

MESSAGE LAYOUT

APPLICATION HAC HFC MESSAGE TYPE HFC INIT. COMMAND SUBTYPES 0,1,2
 PROGRAMMER D. A. Powell DATE 2/8/80

TABLE 3.7-X HFC INITIALIZATION COMMAND FORMAT (SUBTYPES 0,1,2)

MESSAGE LAYOUT

COMMAND

MESSAGE TYPE SUBTYPES 3.4.5

DATE 2/8/80

Corridor-C
X-parameter at
binary point 14.

9X₁₆ = CULPs
AX₁₆ = CLLPs
BX₁₆ = DELTAs
(X if HFC#)

Corridor-C
Y-parameter at
binary point 14.

Corridor-C
Z-parameter
at binary point 14.

Corridor-D
X-parameter at
binary point 14

Corridor-D
Y-parameter at
binary point 14.

Corridor-D
Z-parameter at
binary point 14.

8 bit checksum such that all message bytes sum to zero.

TABLE 3.7-XII HFC INITIALIZATION COMMAND FORMAT (SUBTYPE 6)
MESSAGE LAYOUT

APPLICATION HAC HFC MESSAGE TYPE HFC INIT. COMMAND SUBTYPE 6
PROGRAMMER E. Madigan DATE 7/8/80

1	HEADER BYTE	1	FX ₁₆ = Corridor Assignments (X = HFC#)
			don't care
5	CORRIDOR-A ASSIGNMENT MASK	5	32 bits of Corridor assignments 0 = not selected 1 = selected
10	CORRIDOR-B ASSIGNMENT MASK	10	32 bits of Corridor assignments 0 = not selected 1 = selected
15	CORRIDOR-C ASSIGNMENT MASK	15	32 bits of Corridor assignments 0 = not selected 1 = selected
20	CORRIDOR-D ASSIGNMENT MASK	20	32 bits of Corridor assignments 0 = not selected 1 = selected
			don't care
20	CHECKSUM	20	8 bit checksum such that <u>all</u> message bytes sum to zero.
25		25	
30		30	

TABLE 3.7-XIII HC SUN/SYNCHRONIZATION COMMAND FORMAT (BEAM POINTING)
MESSAGE LAYOUT

APPLICATION HFC HC			SUN/SYNC/CMD
			MESSAGE TYPE BEAM POINTING
PROGRAMMER D. Powell			DATE 2/8/80
1	HEADER BYTE	1	28 ₁₆ Receiver 2B ₁₆ BCS 2C ₁₆ CULP (standby) 2D ₁₆ CLLP
	SX		
5	SY	5	
	SZ		
10	CORRIDOR-A SELECT MASK	10	
15	WAX	15	
	WAY		
20	WAZ	20	
25	CORRIDOR-B SELECT MASK	25	
	WBX		
30	WBY	30	

TABLE 3.7-XIII HC SUN/SYNCHRONIZATION COMMAND FORMAT (BEAM POINTING) (con't.)
MESSAGE LAYOUT

APPLICATION HFC HC			SUN/SYNC/CMD BEAM POINTING MESSAGE TYPE (CONTINUED)
PROGRAMMER D. Powell			DATE 2/8/80
35	WBZ	35	Corridor-B z-coord. at binary point 14.
	CORRIDOR-C SELECT MASK		32 bit HC select mask of HCs to point at Corridor-C
40		40	
	WCX		Corridor-C x-coord. at binary point 14.
45	WCY	45	Corridor-C y-coord. at binary point 14.
	WCZ		Corridor-C z-coord. at binary point 14.
50	CORRIDOR-D SELECT MASK	50	32 bit select mask of HCs to point at Corridor-D
55	WDX	55	Corridor-D x-coord. at binary point 14.
	WDY		Corridor-D y-coord. at binary point 14.
60	WDZ	60	Corridor-D z-coord. at binary point 14.
	BEAM POINTING SELECT MASK		32 bit select mask of HCs to beam point
65		65	

TABLE 3.7-XIII HC SUN/SUN SYNCHRONIZATION COMMAND FORMAT (BEAM POINTING) (con't.)

MESSAGE LAYOUT

SUN/SYNC/CMD
BEAM POINTING
(CONTINUED)

APPLICATION	HFC	HC
-------------	-----	----

MESSAGE TYPE (CONTINUED)

PROGRAMMER D. Powell

DATE 2/8/80

		don't care
70		70
	BPX	Beam pointing x-coord. at binary point 14.
75	BPY	75 Beam pointing y-coord. at binary point 14.
	BPZ	Beam pointing z-coord at binary point 14.
80	CHECKSUM	80 8-bit checksum such that <u>all</u> message bytes sum to zero.

TABLE 3.7-XIV HC SUN/SYNCHRONIZATION COMMAND FORMAT (AZIMUTH/ELEVATION POINTING)

MESSAGE LAYOUT

APPLICATION HFC HC			SUN/SYNC/CMD MESSAGE TYPE AZ/EL POINTING	
PROGRAMMER D. Powell			DATE 2/8/80	
1	HEADER BYTE	1	{ 78 ₁₆ Stow 79 ₁₆ Seek Marks 7A ₁₆ Wash 7B ₁₆ DIR POSITION 7C ₁₆ ALT1STOW 7D ₁₆ ALT2STOW	
	SX			
5	SY	5	Sun unit vector y-coord at binary point 4.	
	SZ		Sun unit vector z-coord at binary point 4.	
10		10		
	CORRIDOR-A SELECT MASK		32 bit HC select mask of HCs to point at corridor-A.	
15	WAX	15	Corridor-A x-coord. at binary point 14.	
	WAY		Corridor-A y-coord at binary point 14.	
20		20	Corridor-A z-coord. at binary point 14.	
	WAZ			
	CORRIDOR-B SELECT MASK		32 bit HC select mask of HCs to point at Corridor-B.	
25		25	Corridor-B x-coord at binary point 14.	
	WBX			
30		30	Corridor-B y-coord at binary point 14.	
	WBY			

TABLE 3.7-XIV HC SUN/SYNCHRONIZATION COMMAND FORMAT (AZIMUTH/ELEVATION POINTING) (con't.)

MESSAGE LAYOUT

APPLICATION HFC HC			SUN/SYNC/CMD AZ/EL POINTING MESSAGE TYPE (CONTINUED)
PROGRAMMER D. Powell.			DATE 2/8/80
35	WBZ	35	Corridor-B z-coord at binary point 14.
	CORRIDOR-C SELECT MASK		32 bit HC select mask of HCs to point at Corridor-C
40		40	
	WCX		Corridor-C x-coord at binary point 14.
45	WCY	45	Corridor-C y-coord. at binary point 14.
	WCZ		Corridor-C z-coord. at binary point 14
50	CORRIDOR-D SELECT MASK	50	32 bit HC select mask of HCs to point at Corridor-D
55	WDX	55	Corridor-D x-coord at binary point 14.
	WDY		Corridor-D y-coord at binary point 14.
60	WDZ	60	Corridor-D z-coord at binary point 14.
	AZ/EL POINTING SELECT MASK		32 bit select mask of HCs to AZ/EL point.
65		65	

TABLE 3.7-XIV HC SUN/SYNCHRONIZATION COMMAND FORMAT (AZIMUTH/ELEVATION POINTING) (con't)

MESSAGE LAYOUT

APPLICATION HFC HC SUN/SYNC/CMD
AZ/EL POINTING
MESSAGE TYPE (CONTINUED)

PROGRAMMER D. Powell

DATE 2/8/80

	CAZ	Command azimuth
70	CEL	Command elevation
75		don't care
80	CHECKSUM	8 bit checksum such that <u>all</u> message bytes sum to zero.

TABLE 3.7-XV SUN/SYNCHRONIZATION COMMAND FORMAT (HC INITIALIZATION)
MESSAGE LAYOUT

APPLICATION HFC HC SUN/SYNC/CMD
MESSAGE TYPE HC INITIALIZATION

PROGRAMMER D. Powell

DATE 2/8/80

1	HEADER BYTE	1	3 bits = zero 5 bits HC#
	SX		Sun unit vector x-coord at binary point 4.
5	SY	5	Sun unit vector y-coord at binary point 4.
	SZ		Sun unit vector z-coord at binary point 4.
10	CORRIDOR-A SELECT MASK	10	32 bit HC select mask of HCs to point at Corridor-A
15	WAX	15	Corridor-A x-coord at binary point 14.
	WAY		Corridor-A y-coord. at binary point 14.
20	WAZ	20	Corridor-A z-coord. at binary point 14.
	CORRIDOR-B SELECT MASK		32 bit HC select mask of HCs to point at Corridor-B.
25	WBX	25	Corridor-B x-coord at binary point 14.
30	WBY	30	Corridor-B y-coord at binary point 14.

TABLE 3.7-XV SUN/SYNCHRONIZATION COMMAND FORMAT (HC INITIALIZATION) (con't.)

MESSAGE LAYOUT

SUN/SYNC/CMD
HC INITIALIZATION

APPLICATION HFC HC MESSAGE TYPE (CONTINUED)

PROGRAMMER D. Powell DATE 2/8/80

35	WBZ	35	Corridor-B z-coord at binary point 14.
	CORRIDOR-C SELECT MASK		32 bit HC select mask of HCs to point at Corridor-C
40	WCX	40	Corridor-C x-coord at binary point 14.
	WCY		Corridor-C y-coord at binary point 14.
45	WCZ	45	Corridor-C z-coord at binary point 14.
	CORRIDOR-D SELECT MASK		32 bit HC select mask of HCs to point at Corridor-D
50	WDX	50	Corridor-D x-coord at binary point 14.
	WDY		Corridor-D y-coord at binary point 14.
55	WDZ	55	Corridor-D z-coord at binary point 14.
	CAZ		Current azimuth
60	CEL	60	Current elevation

TABLE 3.7-XV SUN/SYNCHRONIZATION COMMAND FORMAT (HC INITIALIZATION) (con't.)

MESSAGE LAYOUT

APPLICATION		MESSAGE TYPE	
HFC	HC	SUN/SYNC/CMD	HC INITIALIZATION
			(CONTINUED)

PROGRAMMER D. Powell

DATE 2/8/80

	BAZ		• Bias azimuth
79	BEL	70	• Bias elevation
	HX		• Heliostat x-coord at binary point 14.
75	HY	75	• Heliostat y-coord at binary point 14.
	HZ		• Heliostat z-coord at binary point 14.
80	CHECKSUM	80	• 8 bit checksum such that all message bytes sum to zero.

TABLE 3.7-XVI. HC COMMAND RESPONSE FORMAT

MESSAGE LAYOUT

APPLICATION	HC	HFC	MESSAGE TYPE	COMMAND RESPONSE
-------------	----	-----	--------------	---------------------

PROGRAMMER D. Powell

DATE 2/8/80

1	C. R. BYTE	1	3 bits = 6_{16} 5 bits HC#
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-XVII HC STATUS POLL COMMAND FORMAT

MESSAGE LAYOUT

APPLICATION HFC HC STATUS
MESSAGE TYPE POLL

PROGRAMMER D. Powell DATE 2/8/80

TABLE 3.7-XVIII HC STATUS RESPONSE FORMAT

MESSAGE LAYOUT

APPLICATION	HC	HFC	MESSAGE TYPE	STATUS RESPONSE
-------------	----	-----	--------------	--------------------

PROGRAMMER D. Powell

DATE 2/8/80

1	HEADER BYTE	1	3 bits = 5 ₁₆ 5 bits HC#
	HC STATUS		
			See HC status bit breakdown for HFC HAC status response
	CAZ		Current azimuth
5		5	
	CEL		Current elevation
	CHECKSUM		8 bit checksum such that <u>all</u> message bytes sum to zero.
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-XIX OCS/DAS-HAC COMMANDS FORMAT

MESSAGE LAYOUT

APPLICATION OCS/DAS - HAC MESSAGE TYPE OCS / DAS
COMMANDS

PROGRAMMER T. Ladewig DATE 2/8/80

TABLE 3.7-XXI HAC-OCS/DAS ENVIRONMENT STATUS (FIELD) FORMAT

MESSAGE LAYOUT

APPLICATION HAC - OCS/DAS

MESSAGE TYPE STATUS - FIELD

PROGRAMMER T. Ladewig

DATE 2/8/80

TABLE 3.7-XXI HAC-OCS/DAS ENVIRONMENT STATUS (FIELD) FORMAT (CONTINUED)

MESSAGE LAYOUT

APPLICATION HAC OCS/DAS STATUS-FIELD
MESSAGE TYPE (CONTINUED)

PROGRAMMER T. Ladewig

DATE 2/8/80

32	ALTERNATE ? STOW	32	ASCII NNNN = HCs in ALT?STOW
35	TRANSITION	35	ASCII NNNN = HCs in Transition
40	WASH	40	ASCII NNNN = HCs In Wash
45	DIRECTED POSITION	45	ASCII NNNN = HCs in directed position
50	OFFLINE	50	ASCII NNNN = HCs in offline
55	MARK	55	ASCII NNNN = HCs in Mark
	INIT		ASCII NNNN = HCs in INIT
60	UNUSED	60	
77		77	
80	CHECKSUM	80	8 bit checksum such that all bytes sum to zero.

TABLE 3.7-XXII HAC-OCS/DAS ENVIRONMENT STATUS (MODE) FORMAT
MESSAGE LAYOUT

APPLICATION		HAC-OCS/DAS	MESSAGE TYPE	STATUS--MODE
PROGRAMMER		T. Ladewig	DATE 2/8/80	
1	HEADER	1	ASCII H = HAC originated	
			Message byte count (see Note for Table XXI)	
5	STS	5	ASCII STS - STATUS	
	CONDITION		ASCII R = Requested	
	M		A = Alarmed*	
			ASCII M = Mode	
10	MODE	10	ASCII TRK = Track	
			BCS = BCS	
			STB = Standby	
			STO = Stow	
			AL1 = ALT1STOW	
			AL2 = ALT2STOW	
			TRN = Transition	
			WSH = Wash	
			DPO = Directed Position	
			OFF = Offline	
			MRK = Mark	
			INI = Init	
15	TIME	15	ASCII hhhmmss - Time	
	HC#		ASCII 4 digit HC number. Additional messages will be used to transmit additional HCs.	
20		20		
	HC#			
25		25		
	...			
	UNUSED			
80	CHECKSUM	80	Checksum	

*NOTE: Alarmed will be used to report HCs unable to respond to a STHIWIND command. HCs in WASH, OFFLINE, and DIRECTED POSITION will be transmitted

TABLE 3.7-XXIII HAC-OCS/DAS ENVIRONMENT STATUS (HC) FORMAT

MESSAGE LAYOUT

APPLICATION HAC OCS /DAS MESSAGE TYPE STATUS
INDIVIDUAL HC

PROGRAMMER T. Ladewig DATE 2/8/80

1		1	• ASCII H = HAC Originated
	HEADER		• Message byte count (See note for Table XXI)
	STS		• ASCII STS = Status
5		5	
	R		• ASCII R = Requested
	H		• ASCII H = Individual Status
10		10	
	TIME		
15		15	
	HC#		• ASCII 4 Digit HC Number
20		20	
	AZIMUTH		• ASCII 7 Digit SNNN.NN Azimuth
25		25	
	ELEVATION		• ASCII 7 Digit SNNN.NN Elevation
30		30	
32		32	
	////		

TABLE 3.7-XXIV HAC-OCS/DAS ENVIRONMENT STATUS (RING) FORMAT
MESSAGE LAYOUT

APPLICATION		HAC-OCS/DAS	MESSAGE TYPE		RING	STATUS
PROGRAMMER		T. Ladewig		DATE		5/12/80
1	HEADER	1	ASCII H = HAC Originated			
			Message byte count (see note for Table XXI.)			
5	STS	5	ASCII STS = STATUS			
	R		ASCII R = Requested			
	R		ASCII R = Ring			
10	TIME	10	ASCII Time Plant Local			
15	RING	15	ASCII 1-digit Ring number requested			
	SEGMENT		ASCII 3-digit Segment number			
	HCS in SEGMENT		ASCII 2-digit number of HCS in Segment			
20	TRACK	20	ASCII 2-digit number of HCS in TRACK in Segment			
	STANDBY		ASCII 2-digit number of HCS in STANDBY in Segment			
	REPEAT		REPEAT as many times as necessary to cover complete ring - multiple messages may be necessary.			
80	CHECKSUM	80				

TABLE 3.7-XXV HAC/BCS BCS INITIATION REQUEST MESSAGE FORMAT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1	HEADER	1	ASCII H - HAC originated
			Message Byte Count (See note for Table XXI.)
5	B C S	5	ASCII BCS = BCS message
			Message number = 1
10	0 1	10	
	TIME		ASCII hhmmss = Time
15		15	
	BCS FILE TITLE		ASCII BCS file title
20		20	
25		25	
30		30	
80	CHECKSUM		CHECKSUM

TABLE 3.7-XXVI BCS/HAC BCS INITIATION RESPONSE MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION BCS/HAC MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	ASCII 0 - OCS originated
	HEADER		Message Byte Count (See note for Table XXI)
5	B C S	5	ASCII BCS = BCS Message
	0 2		Message number = 2
10		10	
	BCS FILE TITLE		ASCII BCS file title from BCS-1 title
15		15	
	SOUTH		
20	WEST	20	
	NORTH		BCS targets status: 1 = operational 0 = non-operational
	EAST		
	GO/STOP		BCS initiation permission: 1 = go 2 = no-go
25		25	
30		30	
80	CHECKSUM		checksum

TABLE 3.7-XXVII HAC/BCS BCS MEASUREMENT INITIATION REQUEST MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	ASCII H - HAC originated
	HEADER		Message byte count (see note for Table XXI)
5	B C S	5	ASCII BCS = BCS message
	0 3		Message number = 3
10	HELIOSTAT	10	Heliostat number
	BCS TARGET		BCS Target: 1 = South 2 = West 3 = North 4 = East
15	MODE	15	Mode that heliostat is presently in (for coding see byte 9-11, Table XXIV.)
20		20	
25		25	
30		30	
30	CHECKSUM		Checksum

TABLE 3.7-XXVIII BCS/HAC BCS MEASUREMENT INITIATION RESPONSE MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION BCS/HAC MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	• ASCII 0 - OCS originated
	HEADER		• Message byte count (See note for Table XXI)
5	B C S	5	• ASCII BCS = BCS Message
	0 4		• Message number = 4
10	HELIOSTAT	10	• Heliostat number
	BCS TARGET		• BCS TARGET: (see byte 13, Table XXIX)
15		15	
20		20	
25		25	
30		30	
80	CHECKSUM		Checksum

TABLE 3.7-XXIX HAC/BCS HELIOSTAT ON BCS TARGET MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION HAC/BCS **MESSAGE TYPE** BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	• ASCII H - HAC originated
	HEADER		• Message Byte Count (see note for Table XXI)
5	B C S	5	• ASCII BCS = BCS Message
	0 5		• Message number = 5
10	HELIOSTAT	10	• Heliostat number
	BCS TARGET		• BCS Target (see byte 13, Table XXIX)
15	HELIOSTAT	15	• Blocking/shadowing heliostat numbers (up to 5)
20	HELIOSTAT	20	
25	HELIOSTAT	25	
30	HELIOSTAT	30	

TABLE 3.7-XXIX BCS/HAC HELIOSTAT ON BCS TARGET MESSAGE FORMAT (continued)
MESSAGE LAYOUT

APPLICATION BCS/HAC MESSAGE TYPE BCS MEASUREMENT

PROGRAMMER T. Ladewig DATE 5/12/80

35		35	
	TIME		ASCII hhhmmss = Time For Current Sun Vector (GMT)
40		40	
	X		X-coordinate of sun unit vector (East)
45		45	
	Y		Y-coordinate of sun unit vector (North)
50		50	
	Z		Z-coordinate of sun unit vector (Up)
55		55	
60		60	
77		77	
80	CHECKSUM	80	Checksum

TABLE 3.7-XXX BCS/HAC HELIOSTAT BCS REMOVAL REQUEST MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION BCS/HAC

MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	ASCII 0 - OCS Originated
	HEADER		Message Byte Count (See Note for Table XXI)
5	B C S	5	ASCII BCS = BCS Message
	0 6		Message number = 6
10	HELIOSTAT	10	Heliostat number
	BCS TARGET		BCS Target (See byte 13, Table XXIX)
15		15	
20		20	
25		25	
30		30	
80	CHECKSUM	80	Checksum

TABLE 3.7-XXXI HELIOSTAT BCS REMOVAL RESPONSE MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	• ASCII H - HAC originated
	HEADER		• Message Byte Count (See note for Table XXI)
5	B C S	5	• ASCII BCS = BCS Message
	0 7		• Message number = 7
10	HELIOSTAT	10	• Heliostat number
	BCS TARGET		• BCS Target (see byte 13, Table XXIX)
15	MODE	15	• Mode that heliostat was removed to (for coding see byte 9-11, Table XXIV)
20		20	
25		25	
30		30	
80	CHECKSUM		Checksum

TABLE 3.7-XXXII BCS/HAC - BCS MEASUREMENT RESULTS

MESSAGE LAYOUT

APPLICATION BCS/HAC

MESSAGE TYPE BCS MEASUREMENT

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	→ ASCII 0 - OCS originated
	HEADER		→ Message Byte Count (see note for Table XXI)
	B		
5	C	5	→ ASCII BCS = BCS Message
	S		
	0		→ Message Number = 8
	8		
10	HELIOSTAT	10	→ Heliostat Number
	BCS TARGET		→ BCS TARGET (see byte 13, Table XXIX)
	MEASUREMENTS		→ Number of BCS scans taken
15		15	
	CENTROID ALARM		→ Centroid Alarm Flag (1=Alarm)
	POWER ALARM		→ Power Alarm Flag (1=Alarm)
	SUCCESS FLAG		→ Measurement Success Flag
			0 = good measurement
20		20	1 = spilling target
	TIME		2 = off target
			3 = inconsistent measurements
			→ ASCII hhmmss = Time of day of BCS measurement
25	CENTROID OFFSET	25	
			→ ASCII Horizontal average centroid offset (±99.99 ft.)
30		30	
	CENTROID OFFSET		→ ASCII Vertical average centroid offset (±99.99 ft.)

MESSAGE LAYOUT

MESSAGE TYPE BCS MEASUREMENT

DATE 5/12/80

[illegible]

TABLE 3.7-XXXIII HAC/BCS BCS MEASUREMENT RESULTS RESPONSE
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	→ ASCII H - HAC originated
	HEADER		→ Message Byte Count (see note for Table XXI)
5	B C S	5	→ ASCII BCS = BCS Message
	0 9		→ Message number = 9
10	HELIOSTAT	10	→ Heliostat number
	BCS TARGET		→ BCS Target (see byte 13, Table XXIX)
15	TIME	15	→ ASCII hhmmss = Time of day of BCS measurement (from bytes 19-24, Table XXXIV)
20	CENTROID OFFSET HORIZONTAL	20	→ ASCII Horizontal centroid offset (from bytes 25-30, Table XXXIV)
25	CENTROID OFFSET VERTICAL	25	→ ASCII Vertical centroid offset (from bytes 31-36, Table XXXIV)
30	AZIMUTH	30	→ ASCII Azimuth Bias from measurement data

TABLE 3.7-XXXIII HAC/BCS - BCS MEASUREMENT RESULTS RESPONSE (CONTINUED)

MESSAGE LAYOUT

APPLICATION HAC/BCS

MESSAGE TYPE BCS MEASUREMENT

PROGRAMMER T. Ladewig

DATE 5/12/80

34		34	
35	AZIMUTH	35	• ASCII $\pm$ NNN.NN
	(continued)		
40	ELEVATION	40	
			• ASCII $\pm$ NNN.NN Heliostat
	BIAS		Elevation Bias from Measurement Data
45		45	
	CURRENT		
	AZIMUTH		• ASCII $\pm$ NNN.NN Current
			Heliostat Azimuth BIAS
50	BIAS	50	
	CURRENT		
55	ELEVATION	55	• ASCII $\pm$ NNN.NN Current
			Heliostat Elevation BIAS
	BIAS		
59		59	
80	CHECKSUM	80	

TABLE 3.7-XXXIV HAC/BCS BCS TERMINATION MESSAGE FORMAT

MESSAGE LAYOUT

APPLICATION HAC/BCS

MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	•ASCII H - HAC originated
	HEADER		•Message Byte Count (see note for Table XXI.)
	B		
5	C	5	•ASCII BCS = BCS message
	S		
	1		•Message number = 10
	0		
10		10	
	TIME		•ASCII hhmmss = Time of termination (all heliostats are back to original mode)
15		15	
	BCS		
	FILE		•ASCII BCS file title (see bytes 15-24, Table XXVII.)
20	TITLE	20	
25		25	
30		30	
80	CHECKSUM	80	

TABLE 3.7-XXXV HAC/BCS HELIOSTAT MEASUREMENT HISTORICAL DATA REQUEST
MESSAGE FORMAT
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1	HEADER	1	ASCII H - HAC originated
			Message Byte Count (See note for Table XXI.)
5	B C S	5	ASCII BCS = BCS message
	1 1		Message number = 11
10	HELIOSTAT	10	Heliostat number
15		15	
20		20	
25		25	
30		30	
80	CHECKSUM	80	Checksum

TABLE 3.7-XXXVI HAC/BCS HELIOSTAT MEASUREMENT HISTORICAL DATA RESPONSE
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig DATE 5/12/80

1		1	ASCII H - HAC Originated
	HEADER		Message Byte Count (See note for Table XXI.)
	B		
5	C	5	ASCII BCS = BCS Message
	S		
	1		ASCII Message Number = 12
	2		
10	HELIOSTAT	10	ASCII Heliostat Number
	BCS TARGET		BCS Target (see byte 13, Table XXIX).
	MEASUREMENT		Measurement
15		15	1 = 1st
			2 = 2nd
			3 = 3rd
	DATE		ASCII yymmdd = Date of measurement
20		20	
			ASCII hhmmss = Time of measurement
25	TIME	25	
	CENTROID		
	OFFSET		
	HORIZONTAL		ASCII $\pm$ 99.99 Horizontal Centroid Offset
30		30	
32		32	
	////////////////		

TABLE 3.7-XXXVII HAC/BCS HELIOSTAT BIAS RESULTS
MESSAGE LAYOUT

APPLICATION HAC/BCS MESSAGE TYPE BCS Measurement

PROGRAMMER T. Ladewig

DATE 5/12/80

1		1	• ASCII H - HAC Originated
	HEADER		• Message Byte Count (see note for Table XXI).
	B		
5	C	5	• ASCII BCS - BCS Message
	S		
	1		• Message Number = 13
	3		
10	HELIOSTAT	10	• Heliostat Number
15	DATE	15	• ASCII yymmdd = Date of bias update (if applicable)
20	NEW AZIMUTH BIAS	20	• ASCII $\pm$ 999.99 New Heliostat Azimuth Bias
25	NEW ELEVATION BIAS	25	• ASCII $\pm$ 999.00 New Heliostat Elevation Bias
30		30	
32		32	
	////		

MESSAGE LAYOUT

PROGRAMMER T. Ladewig DATE 5/12/80

33	OLD	33	
35	AZIMUTH	35	
	BIAS		→ ASCII ± 999.99 OLD AZIMUTH BIAS
40	OLD	40	
	ELEVATION		
	BIAS		→ ASCII ± 999.99 OLD ELEVATION BIAS
45		45	
	STATUS		→ STATUS of BIAS update:
			0 = bias update not executed
			1 = bias updated
			2 = decision pending
80	CHECKSUM	80	

TABLE 3.7-XXXVIII HAC-GDC Field Position Initialization

MESSAGE LAYOUT

APPLICATION : HAC-GDC

MESSAGE TYPE: Initialize field position
(1 of 2)

PROGRAMMER : D. Pettit

DATE : June 10, 1980

1	Blank	1	All ASCII
	Mac Dac		
	Heliostat number		Number composed of row number and row position number
5		5	
	Blank		
	HFC-HC		HFC * 32+1+HC = (HFC-HC number) range 1-2048
	number		
10		10	
	Blank		
	+/-		
	x		
	x		
15	x	15	Site reference x-coordinate (East)
	x		
	.		
	x		
	x		
20	Blank	20	
	+/-		
	x		
	x		
	x		Site reference y-coordinate (North)
25	x	25	
	.		
	x		
	x		
	Blank		
30	Segment	30	Segment number assignment
	Number		
	Blank		

MESSAGE LAYOUT

MESSAGE TYPE: Initialize field positio
(2 of 2)

DATE: June 10, 1980

[illegible]

MESSAGE LAYOUT

MESSAGE TYPE : HAC Full Field Status

DATE : June 9, 1980

TABLE 3.7-XL HAC-GDC Segment Status

MESSAGE LAYOUT

APPLICATION: HAC-GDC

MESSAGE TYPE : HAC Segment Status

PROGRAMMER: D. Pettit

DATE June 9, 1980

1	Header Byte	1	2 = Segment updating
	SEGMENT AIM #		bit 0=1, bits 1-7 binary 2 ₁₀
	Pecking Order #		bit 0=1, bits 1-7 binary value
	HC Status		bit 0=1, bits 1-7 binary value
5	High order Az bits	5	bit 0=1, bits 1-7 binary value
	low order Az bits		bit 0=1, bits 1-7 are bits 0-6 of Az word
	High order El bits		bit 0=1, bits 1-7 are bits 7-13 of Az word
	low order El bits		same format as azimuth
	AIM POINT		bit 0=1, bits 1-7 are bits 4-10 of AP
10	(NORTH)	10	bit 0=1, bits 1-7 are bits 11-17 of AP
	AIM POINT		same format as North Aim Point
	(EAST)		
	AIM POINT		same format as North Aim Point
	(UP)		
15	same format	15	
	as above 12 bytes		
	for the next HC		
	in pecking order		
	(shown in dashed		
	line on left)		Repeat up to 21 total HCs in pecking
20		20	order (less than 258 bytes)
25		25	
30		30	

TABLE 3.7-XLI HAC-GDC Text Message to GDC

MESSAGE LAYOUT

APPLICATION : HAC-GDC

MESSAGE TYPE : Text message to GDC

PROGRAMMER : D. Pettit

DATE : June 10, 1980

TABLE 3.7-XLII HAC-GDC Graphics Initialization

MESSAGE LAYOUT

APPLICATION : HAC-GDC

MESSAGE TYPE : Initialize Graphics

PROGRAMMER : D. Pettit

DATE : June 10, 1980

1	Header byte	1	• 4 - Set graphics terminal ID
	Terminal ID		Bit 0=1, Bits 1-7 binary 4_{10}
			• Bit 0=1, Bits 1-7 binary value where
			0 = CS Control Room
			1 = Engineering Evaluation Room
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-XLIII GDC-HAC GDC Command

MESSAGE LAYOUT

APPLICATION: GDC - HAC

MESSAGE TYPE: GDC Command

PROGRAMMER: D. Pettit

DATE: June 9, 1980

1	Header Byte	1	2 = Reset
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-XLIV GDC - HAC GDC Command

MESSAGE LAYOUT

APPLICATION: GDC - HAC

MESSAGE TYPE: GDC Command

PROGRAMMER: D. Pettit

DATE: June 9, 1980

1	Header Byte	1	3 = Full field or segment
			ASCII Message byte count
5	Segment Number	5	Position 5-7 contains segment number being displayed. Segment number 000 implies a full field display.
10		10	
15		15	
20		20	
25		25	
30		30	

MESSAGE LAYOUT

MESSAGE TYPE : GDC Command

DATE : June 9, 1980

1	Header Byte	1	4 = Send next message
5		5	
10		10	
15		15	
20		20	
25		25	
30		30	

TABLE 3.7-XLVI GDC-HAC GDC Command

MESSAGE LAYOUT

APPLICATION : GDC-HAC

MESSAGE TYPE : GDC Command

PROGRAMMER : D. Pettit

DATE : June 9, 1980

1	Header Byte	1	1 = High wind stow or defocus (ASCII)
			ASCII Message byte count = 14 ₁₀
5		5	ASCII
	Emergency		Position 5-14 contain either:
	Message		G10STHIØØØ or,
			G10DEFOØØØ.
10		10	
15		15	
20		20	
25		25	
30		30	

Receiver-to-HAC Trip Signal Logic

Computer/twisted pair *	Trip	Operational
HAC A - pair 1	< +2 VDC	+5 VDC
HAC A - pair 2	+5 VDC	< +2 VDC
HAC B - pair 1	< +2 VDC	+5 VDC
HAC B - pair 2	+5 VDC	< +2 VDC

* All signals TTL Level, 300 ma

TABLE 3.7-XLVII

4.0

SOFTWARE/FIRMWARE SYSTEM VALIDATION

The validation that the software/firmware developed for the Collector Subsystem meets the requirements imposed by the 10 MWe Collector Subsystem Software/Firmware Functional Requirements Specification and this design specification shall be accomplished by a tiered level of testing. Each element of a level of testing which leads to the next higher level of testing will be completed to the satisfaction of the responsible engineer for that level before commencing to the next higher level. At the completion of each level of testing, a memo will be generated by the responsible engineer for that level detailing the tests performed, the results of the test, and listing any special software or tools used in the test.

4.1

Test Phases

All software and firmware developed for the 10 MWe Collector Subsystem project will be subjected to four levels of testing:

- a. Function (or unit) testing;
- b. Integration testing;
- c. Breadboard level testing; and
- d. System level testing.

4.2

Functional Testing

Functional testing will be accomplished by the engineer responsible for the development of the software or firmware module, as each submodule becomes available. Each submodule will be tested against the Software/Firmware Design Specification. Testing at this level will be conducted informally and to the satisfaction of the responsible engineer. All hard-copy test results generated at this level will be filed in the Module Development Folder. Software modules developed for the HAC will be tested in the HAC computer. Firmware modules developed for the HFC and HC may be tested on the Motorola 6801 simulator running in the Sigma V computer system, the Motorola MEK6800D2 development kits, or breadboard models of the HFC, HC, or Stimulator.

4.3

Integration Testing

Integration testing will be accomplished under the cognizance of the HAC Lead Engineer for software to run in the HAC computer, and the HFC/HC Lead Engineer for firmware to operate in the HFC and HC microcomputers. The software and firmware modules will be integrated into the software system and firmware system, as the modules become available, and will be tested for compliance with interface definitions and functions, as defined in the Software/Firmware Design Specification and Software/Firmware Functional Requirements Specifications documents. Integration

testing will be informal and to the satisfaction of the HAC Lead Engineer and HFC/HC Lead Engineer. Hard-copy results and notes generated from this testing will be filed in a file kept in close proximity to the module development folders and will be used in preparation of the "as-built" Software/Firmware Design Specification.

4.4.

Breadboard Integration Testing

Breadboard Integration testing will be accomplished under the cognizance of the Controls Manager. The software and firmware systems will be tested with the HAC computer connected to and communicating with a breadboard version of the HFC and HC microprocessors, with HFC and HC firmware systems operating, respectively. The software and firmware modules will be tested for compliance with the interface definitions, the software and firmware functions, and overall system performance. This testing will be informal and to the satisfaction of the Controls Manager. Any hard-copy results and notes generated from this testing will be filed in a Breadboard Test File and will be used in the preparation of the "as-built" Software/Firmware Design Specification. Upon completion of this testing, the software and firmware systems will be placed under configuration control.

4.5

System Level Testing

System Level testing will be accomplished under the cognizance of the Collector Subsystem Operations Manager. This level of testing will be accomplished under formal controls against the Collector Subsystem Functional Test Plan. The test will verify that the code satisfies the functional objectives and requirements specifications. Discrepancy reports will be filed for each failure detected. Any discrepancies will be corrected by the responsible engineers. Retesting will be performed to verify that the discrepancies have been corrected. System Level Test will be run at the Martin Marietta Plant in Denver, Colorado, by use of a heliostat located in the solar test area and using the HAC installed at the Space Physics Laboratory. After successful completion of the System Level Test in Denver, the HAC will be moved to the 10 MWe Solar One plant site and used for heliostat installation procedures. The HAC will undergo Acceptance Testing with the field as part of the Collector Subsystem Acceptance Test.

ACRONYMS

The following is a list of acronyms used with this project:

ASCII	- American Standard Code for Information Interchange
AZ	- Azimuth
BCS	- Beam Characterization Subsystem
CLLP	- Corridor Lower Limit Point
CPU	- Central Processor Unit - CPU-CPU Link - 4824/4824 link between Prime and Backup HAC
CRT	- Cathode Ray Tube
CS	- Collector Subsystem
CULP	- Corridor Upper Limit Point
DAS	- Data Acquisition System
DOE	- Department of Energy
EL	- Elevation
EPGS	- Electrical Power Generation System
GFE	- Government Furnished Equipment
HAC	- Heliostat Array Controller
HC	- Heliostat Controller
HFC	- Heliostat Field Controller
ICD	- Interface Control Document
I/F	- Interface
I/O	- Input/Output
ISC	- Intelligent Systems Corporation
JCL	- Job Control Language
MDAC	- McDonnell Douglas Corporation
MAX IV	- MODCOMP Operating System
MAXNET	- MODCOMP Net Working System Superset of MAX IV

ACRONYMS (Cont'd)

MCS - Master Control System

MMC - Martin Marietta Corporation

MODCOMP - Modular Computer Corporation

O&M - Operation and Maintenance

OCS - Operational Control System

OPDD - Overall Plant Design Description

PCS - Peripheral Control Switch

QA - Quality Assurance

REX - Request Executive Services

RFP - Request for Proposal

RS - Receiver System

SCE - Southern California Edison

SDP - Software Development Plan

SED - Source Editor

SFDI - Solar Facility Design Integrator

SFRS - Software/Firmware Functional Requirements Specification

STMPO - Solar Ten Megawatt Project Office

S/W - Software

TBD - To be determined

TBS - To be supplied

TCB - Task Control Block

TI - Texas Instruments

TSS - Thermal Storage System

UFT - User File Table

UPS - Uninterruptable Power Supply

WWV - National Bureau of Standards Universal Time
broadcasting station at Fort Collins, CO