19-92 85 (2)

ANL-92/5

Materials and Components
Technology Division
Materials and Components
Technology Division
Materials and Components
Technology Division

Detection and Location of Leaks in District Heating Steam Systems: Survey and Review of Current Technology and Practices

by D. S. Kupperman, A. C. Raptis,
and R. L. Lanham

Argonne National Laboratory, Argonne, Illinois 60439
operated by The University of Chicago
for the United States Department of Energy under Contract W-31-109-Eng-38

Argonne National Laboratory, with facilities in the states of Illinois and Idaho, is owned by the United States government, and operated by The University of Chicago under the provisions of a contract with the Department of Energy.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Reproduced from the best available copy.

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information
P.O. Box 62

Oak Ridge, TN 37831

Prices available from (615) 576-3401, FTS 6-6-8401

Available to the public from the
National Technical Information Service

U.S. Department of Commerce

5285 Port Royal Road

Springfield, VA 22161

Distribution
Category:
Energy Conservation
in Buildings and
Community Systems
(UC-350)

ARGONNE NATIONAL LABORATORY
9700 South Cass Avenue, Argonne, Illinois 60439

ANL-92/5

ANL--92/5

DE92 013740

**Detection and Location of Leaks in District Heating Steam Systems:
Survey and Review of Current Technology and Practices**

by

D. S. Kupperman, A. C. Raptis,
and R. N. Lanham

Materials and Components Technology Division

March 1992

Work supported by the
U.S. DEPARTMENT OF ENERGY,
Assistant Secretary for Conservation and Renewable Energy,
Utilities Systems Division

MASTER

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

Contents

Executive Summary	1
Abstract	3
1 Introduction	3
2 Background	4
2.1 Existing Techniques for Leak Detection and Location	5
2.1.1 Acoustic Emission.....	5
2.1.2 Infrared Spectroscopy	6
2.1.3 Tracer Gas.....	7
2.1.4 Electrical.....	8
2.1.5 Summary of Existing Techniques.....	8
2.2 In-Stream Acoustic Monitoring of Leaks	9
3 Review of Literature Related to Acoustic Leak Detection in District Heating Systems	10
4 Survey of District Heating Leak Detection and Location Practices	12
4.1 Survey Method	13
4.2 Results	13
4.2.1 Leak Detection Practices	20
4.2.2 Interest in ANL Acoustic Technology	26
4.2.3 European Experience.....	30
4.3 Conclusions from Survey.....	33
5 Acoustic Leak Location by Cross-Correlation Analysis	35
5.1 Leak Location with a Commercially Available Correlator at the ANL Steam Leak Facility	36
5.2 Leak Location with a Commercially Available Correlator under Field Conditions	36
5.3 Leak Location with a Research-Quality Correlator under Laboratory and Field Conditions	38
5.4 Leak Location with an In-Stream Sensor	38
6 Conclusions	39
Acknowledgments	40
References	41

Appendix A: Survey Form and Introductory Remarks for Acoustic Leak Detection and Location.....	43
Appendix B: Notes from Survey	49

Figures

1 Basic Piping Designs.....	19
-----------------------------	----

Tables

1 Utilities Surveyed.....	14
2 Basic System Data	15
3 Summary of Pipe Installations and Expansion Devices.....	17
4 Other System Details.....	18
5 Location of Leaks.....	21
6 Leak Detection Methods	22
7 Leak Location Methods.....	23
8 General Interest in ANL Technology.....	27
9 Specific Interest in ANL Technology.....	31

Detection and Location of Leaks in District Heating Steam Systems: Survey and Review of Current Technology and Practices

by

D. S. Kupperman, A. C. Raptis, and R. N. Lanham

Executive Summary

This report presents the results of a survey undertaken to identify and characterize current practices for detecting and locating leaks in district heating (DH) systems, in particular steam systems. Currently used technology and practices are also reviewed. In addition, the survey was used to gather information of potential importance in the application of acoustic leak detection. Discussion is included of a few examples of attempts to locate leaks in steam and hot water pipes by correlation of acoustic signals generated by the leaks.

Several leak detection techniques are currently available. The application and effectiveness of each technique depend on the design and installation method of the DH piping, location of the leak (in the jacket or the carrier pipe), system operating parameters, and knowledge of system layout and components. The most common systems used today are classified according to their principle of operation, i.e., acoustic emission, infrared spectroscopy, tracer gas, and electrical.

Acoustic leak detection is potentially the most effective method for locating leaks. However, sensors placed directly on the pipe outer wall may not be effective enough to locate steam leaks by acoustic techniques in long runs of DH piping. One way to circumvent the general problem of steam leak detection in buried pipe is to insert an acoustic transducer inside the pipe to directly detect steam-propagated sound waves. This concept is the focus of a program at Argonne National Laboratory (ANL) cofunded by Consolidated Edison of New York and NRG Thermal (a subsidiary of Northern States Power).

The conclusions from the survey are presented below.

1. The extent to which leak detection is considered important varies significantly from utility to utility. At least three of the larger utilities spend \$1 million or more each year locating and repairing leaks. One-half of the respondents do not consider leaks to be a problem and/or are satisfied with current leak location methods.

2. The most common leak location method is to feel the pavement to determine hot spots and/or to focus on specific trouble-spot components using as-built drawings.

3. Almost one-quarter (23%) of the respondents have found an acoustic technology useful to some extent in leak location, while 18% have tried an acoustic technology without success. The effectiveness of various acoustic or vibration-sensing devices appears to depend on several factors, including the device used, staff expertise and experience, soil type, and pipe depth. One-half of the respondents who indicated that they found an existing acoustic technology useful also stated that they are interested in the ANL technology because they feel that current methods are not as effective as the respondents would like.

4. Most utilities are reluctant to do hot taps, and this presents a significant potential barrier to the use of the proposed ANL leak detection and location technology. (In a hot tap, a valve is attached to the pipe and a microphone is inserted through the valve. The microphone need not remain in the pipe because the valve permits removal of the microphone and isolation of the insertion hole.) Concern about hot taps appears to be based on prior experience with large (several-inch) hot taps. However, the microphone under development at ANL will employ a much smaller tap and may relieve much of the present concern.

Abstract

This report presents the results of a survey undertaken to identify and characterize current practices for detecting and locating leaks in district heating systems, particular steam systems. Currently used technology and practices are reviewed. In addition, the survey was used to gather information that may be important for the application of acoustic leak detection. A few examples of attempts to locate leaks in steam and hot water pipes by correlation of acoustic signals generated by the leaks are also discussed.

1 Introduction

The cost of building and maintaining thermal distribution systems contributes substantially to the cost of energy delivered to end users. To improve the competitiveness of existing DH systems, the capital, operating, and maintenance costs must be reduced. Thermal-distribution piping systems installed underground in densely populated areas are subject to a variety of internal and external conditions that reduce their performance. In particular, pipe leaks are a major cause of energy loss and maintenance cost over the life of a DH system. To minimize these losses and costs, leaks must be detected, located, and repaired promptly.

This report presents the results of a survey undertaken to identify and characterize current practices for detecting and locating leaks in district heating systems, in particular steam systems. The survey was used to gather information on (a) characteristics of the distribution system that may be important for acoustic leak detection, (b) currently used technology and practices, and (c) possible interest in acoustic leak detection technology such as that under development at Argonne National Laboratory (ANL). In addition, a review of leak detection technology and available literature on acoustic leak detection is presented. A few examples of attempts to locate leaks in steam and hot water pipes by correlation of acoustic signals generated by the leaks are discussed.

2 Background

Leak detection and location techniques are currently available for several configurations of heat distribution systems carrying water.¹ The performance of these techniques has not been well documented by the industry. Most of the existing data are in the possession of individual system operators and have not been collected and disseminated to the industry. In this report, the results of a survey of utilities is presented, eliminating this previous gap in information. Until now, the only readily available data on leak detection techniques and their application and performance are those documented by an evaluation study conducted by the Construction Engineering Research Laboratory (CERL) of the U.S. Army Corps of Engineers.² The conclusions of the CERL study were that every available leak-detection technique is limited in application to a specific conduit configuration and installation technique. With regard to acoustic leak detection in particular, several researchers have investigated the application of acoustic leak detection to other systems, including nuclear reactors, with some success.³⁻⁷

The major elements of an underground thermal distribution system are distribution piping, thermal insulation, pipe supports, anchors, expansion/contraction devices, conduit/envelope structures, protective outer coverings, joint sealants, external drains, and manholes. Among the factors that influence the design, materials selection, and installation methods for thermal distribution systems are initial cost, service life, maintenance costs, thermal and economic efficiency, and safety. In the past, performance improvements in thermal distribution systems have been minor.

Underground piping systems are installed and operated in very harsh environments and their long-term reliability is highly dependent on corrosion protection, installation technique, site hydrology, and proper maintenance. After a few years of operation, most underground piping systems are likely to incur leaks in the carrier pipe. If not detected and repaired promptly, these leaks can cause major damage to a whole section of a piping system and neighboring utilities, as well as substantial energy losses. Most of the historical data on the causes of piping leaks in the United States have been derived from steam distribution facilities of the federal government. These data indicate that leaks in underground piping systems are often caused by corrosion, mechanical rupture due to soil

subsidence and pipe expansion, or construction deficiencies. In a study conducted by a Swedish national laboratory on the failure of Swedish DH hot-water distribution pipes from 1968 to 1982, several key causes of pipe leaks were identified.¹

Although steam leaks in underground pipes of DH systems may not have the safety significance of a leak in a nuclear reactor, they can be hazardous to the public and costly in terms of energy loss. In St. Paul, Minnesota, for example, one energy system lost 50% of its steam output through leakage before the system was repaired. The U.S. Department of Defense maintains about 6000 miles of heat distribution lines, mainly underground, and energy loss has become a concern.² A reliable leak detection and location system for underground piping could reduce the costs of operating a DH system and minimize the general liability of the company providing the service. However, the task of finding leaks is complex because of the configuration of the distribution systems. Insulated heat-carrying pipe, for example, can be supported inside a protective buried conduit with an air space between the pipe insulation and the conduit's inner wall. Supply and return lines can be in common or separate conduits. Alternatively, a concrete trench with removable covers can contain insulated supply and return lines.

2.1 Existing Techniques for Leak Detection and Location

Various leak detection techniques are currently available. The application and effectiveness of each technique depend on the design and installation method of the DH piping, location of the leak (in the jacket or the carrier pipe), system operating parameters, and knowledge of system layout and components. The most common systems today are classified according to principle of operation as follows: acoustic emission, infrared spectroscopy, tracer gas, and electrical.

2.1.1 Acoustic Emission

When a leak occurs in a pipe carrying pressurized hot water or steam, the turbulent flow of the fluid passing through the crack or hole generates sound waves. These waves are omnidirectional and their intensity decreases inversely with distance from the leak. Commercially available acoustic leak detection and location systems incorporate acoustic sensors to detect and measure the intensity of the noise signal generated by a leak. Acoustic

signals can be detected by placing a sensing microphone in direct contact with a carrier pipe at an accessible point. This method is more effective for water-filled pipe because the sound in the water is coupled to the pipe wall due to the relatively small difference in acoustic impedances. For a steam-filled pipe, the acoustic impedance mismatch is much greater and the sound propagating in the steam is not transferred readily to the pipe wall; thus, sensors that detect leak noise by being placed on the pipe wall would be less efficient than a sensor that could be inserted into the pipe.

Another approach to measuring the intensity of the acoustic leak signal is bar-holing, in which a metal rod is driven into the ground to establish metal-to-metal contact with the carrier pipe. The metal rod acts as a waveguide and the acoustic signal is measured at the upper end of the rod. To locate the leak, multiple acoustic wave measurements are taken. The location is then found by comparing the measured intensities of the leak signal at various locations and identifying the point where it is highest. Another method is to move a microphone, in contact with the ground, along a path following the pipe and use the maximum-amplitude noise signal to locate a leak. The success of this method depends on the skill of the operator and the configuration of the underground piping.

A more sophisticated and potentially cost-effective acoustic leak detection/location technique requires only two measurements of the leak-noise signal and uses an advanced computerized system to analyze the signals and locate the leak via a cross-correlation function. This function is a mathematical concept that can be represented by a graph that plots amplitude over time. In the absence of a leak, the graph is generally a series of small bumps caused by background noise. The appearance of a large peak indicates a leak. Time (how long it takes the signal to travel from the source to one of the two sensors) is easily converted to distance. By comparing the time delays in signals received by the two sensors, we can accurately pinpoint the leak.

2.1.2 Infrared Spectroscopy

A leaking steam pipe could increase the temperature of the ground and surface area above the leak. If the ambient temperature, depth of the leaking pipe, and variations in ground-surface temperature are within certain limits, leaks can be detected by infrared spectroscopy. A temperature profile of the surface above the pipeline, taken with a camera

mounted on a motor vehicle or helicopter, is compared to a reference temperature profile taken when there were no leaks in the pipeline. Also, temperature-reading devices can be used to identify variations in ground temperature and hot spots on the ground surface along the pipeline route. Hot spots identified by infrared spectroscopy are likely to be the locations of pipe leaks.

Infrared spectroscopy is most effective when a leak occurs in both the carrier pipe and its jacket at the same location. Soil condition, pipe system design, installation technique, and leak type are critical factors in the application and effectiveness of this method. With certain ground soil conditions and installation techniques, leaking hot water may spread into the surrounding soil and blur the leak source or it may be absorbed by the soil and limit the effectiveness of the method. Accuracy is also limited when a leak occurs only in the carrier pipe or the jacket, and when there are multiple leaks in the pipe system. In general, this method is not applicable in many commonly occurring leak situations and it is expensive.

2.1.3 Tracer Gas

The tracer gas method can be used to detect and locate leaks in underground heat distribution systems that employ a double wall with an annular space between the carrier and the casing pipes. Heat distribution based on this pipe design is found mostly in federal government installations. Leaks can be detected and located in both the carrier and casing pipes. Gas is injected into the pipe system and its concentration is measured at the surface or in shallow bar-holes made at intervals about equal to the average depth of the conduit along the entire length of the pipe system. The hole with the highest gas concentration will usually indicate the location of the leak. Sulfur hexafluoride (SF_6) is the most frequently used tracer gas because it does not occur naturally. Although this technique is feasible for detecting leaks in double-walled piping systems, it is not widely used. A major disadvantage is the need to shut down the heat distribution system when the carrier pipe is tested. Calculations to determine diffusion time and leak location are often difficult. In testing for casing leaks, a scan of the surface to detect the tracer gas and locate the leak is not always reliable because, depending on soil conditions, the leaking gas may either travel vertically or follow the path of least resistance.

2.1.4 Electrical

Most of the recently built DH hot water piping systems in the United States and Europe have factory-made insulated pipes that incorporate electrical devices for detecting and locating leaks. To detect leaks in the carrier pipe and casing, an exposed wire is installed in the pipe insulation; the electrical resistance between this electrical conductor and the metal carrier pipe can then be measured and monitored. Leaks can be detected by comparing the measured resistance with a minimum reference value. Another electrical method for locating leaks is based on time-domain reflectometry. When the outer braid of a coaxial cable, installed in the pipe insulation, is infiltrated by a leaking fluid (groundwater from a leak in the casing or hot water from a carrier pipe leak), it undergoes a change in characteristic impedance at the leak. This change converts outgoing electrical signals from the plant into reflected pulses or standing waves. To locate the leak, the signals are detected and analyzed at the plant with signal-processing equipment.

The currently available electrical techniques for detecting and locating leaks are used with preinsulated pipe systems. These techniques have only been used in the last 10-15 years in hot-water piping systems, and existing heat distribution installations cannot be retrofitted cost-effectively. The long-term reliability of electrical techniques has not been proved. Corrosion, the most common problem with underground piping systems, is likely to limit the life of the signal wires and reduce the long-term effectiveness of this system.

2.1.5 Summary of Existing Techniques

All of the commonly used leak detection techniques have limitations. The infrared method is limited by high cost and "blurring" of the hot spot as heated water spreads into the surroundings or is directed away from the source of the leak. Accuracy of the tracer gas method is limited by variations in gas diffusion rates and preferential migration. Another disadvantage of the tracer gas method is that the DH system must be shut down when the pipes are tested. Electrical methods pose reliability problems and cannot be used in older systems. The acoustic method, though somewhat of an "art" in practice, currently has the greatest potential for detecting leaks in underground pipes.²

2.2 In-Stream Acoustic Monitoring of Leaks

Transducers or transducer/waveguide systems placed directly on the pipe outer wall may not be effective enough to locate leaks acoustically in long runs of DH piping. Two factors contribute to the problem with steam-filled pipes. The first is that acoustic impedance mismatch between the pipe wall and the steam is so great that the amount of sound energy coupled into the pipe from the steam is limited. (Sound traveling inside a water-filled pipe is efficiently coupled to the pipe wall and can be detected by externally mounted transducers.) The effectiveness of cross-correlation analysis for leak location in steam-filled pipes is further reduced by the numerous modes of acoustic wave propagation present in the pipe wall. These modes are not normally present in water-filled pipes because of the damping effect of the water.

One way to circumvent the general problem of steam leak detection in buried pipe is to insert an acoustic transducer inside the pipe for direct detection of steam-propagated sound waves. We briefly evaluated a capacitance-microphone-type transducer (Knowles Electronics, Inc., Model BT-1834) that can be inserted into a pipe through a small hole. The transducer was inserted into the ANL test pipe through a hole used for artificial leaks. An Endevco 2224C accelerometer was placed on the outer wall of the pipe at the same location. The pipe was filled with gas at ≈ 6 psi pressure. The transducer showed superior signal-to-noise ratios over most of the examined frequency range.¹ For example, near 4 kHz, the signal-to-noise ratio for the capacitance microphone transducer is about 10 dB higher than for the accelerometer. This advantage is reduced by a few decibels at higher frequencies (e.g., 10-12 kHz). Cross-correlation analysis of signals from a gas leak also suggests that these small transducers can be significantly more effective than transducers mounted on the outside of the pipe. A well-defined correlation peak for a leak could not be obtained with externally mounted accelerometers, whereas it could be with in-stream transducers.

A potential problem with this concept is that, for continuous monitoring, the transducer must be protected from the erosive and corrosive effects of the fluid stream, as well as from the elevated temperatures. Furthermore, the sensor must be inserted so that the fluid does not create high levels of acoustic noise as it flows past the sensor. These problems can be overcome, and the advantage of not having to analyze

propagation modes in the pipe wall makes the pursuit of an intrusive sensor particularly attractive for correlation analysis. A goal of the current program at ANL is the development of an in-stream acoustic sensor for steam leak location.

3 Review of Literature Related to Acoustic Leak Detection in District Heating Systems

Several papers on the detection and location of leaks are briefly reviewed below. In general, attempts to locate leaks acoustically have concentrated primarily on water filled pipes. No papers dedicated to detection and location of steam leaks have been found. In general, location of leaks in water-filled pipes have been successful. Other references are presented at the end of this report.

Ref. 8 "Acoustic leak location in district heating pipes."

Fuchs, H.V., Frommhold, W., Poggemann, R., and Zenker, P.

(Correlation analysis)

Source: HLH, Heizung, Lüftung, Klimatechnik, Haustechnik, v. 42:1; Fraunhofer-Institut für Bauphysik, Stuttgart, and Energieversorgung Oberhausen AG (West Germany),

Language: German

Leaks were found using LOKAL ("leak location through correlation analysis"). Only water leaks were detected. Leaks were detected with frequencies less than 1 kHz and sensors placed on the pipe outer wall. Location was by cross-correlation analysis. Leak rates of 0.05 to 3.5 m³/hr. were detected at distances up to 260 m.

Ref. 9 "Computer-aided measuring system for automatic monitoring of pipe networks and leak detection." Schwarze, H.

(Noise-correlation technique)

Source: Technisches Messen, v. 55, no. 7-8, 1988, pp. 279-285; Fachhochschule Bielefeld, Bielefeld, West Germany.

Language: German

Location of pipe leaks is determined by employing an LSI chip TDC1028 and three radio links to calculate the cross-correlation function. This work involves detection of water leaks only. The

frequencies of interest are 20 Hz to 10 kHz. Microphones are attached to hydrants. Electronic filters provide flexibility in selection of frequencies (100 Hz to 5 kHz).

- Ref. 10 "Leakage monitoring in synthetic jacket pipes for district heating supply." Micheel, H. J. (Impulse echo measurement)
Source: Fernwarme International, v. 16, no. 6, Nov.-Dec. 1987, pp. 380-385;
Salzgitter Elektronik GmbH, Kiel, West Germany.
Language: German

With a network of moisture indicators and wire leads, the location of leaks is determined by insulation resistance measurement and impulse echo measurement.

- Ref. 11 "Environmental monitoring technologies". Chang, D. B., Pierce, B. M., and Shih, I. Source: SAE Technical Paper Series 910190, International Congress and Exposition, Detroit, Michigan, Feb. 25-March 1, 1991
Language: English

This paper discusses a fiber-optic liquid level sensor that may provide an accurate measurement of leakage from underground storage tanks. Leaks are detected by measuring the change in light intensity transmitted along a special fiber-optic cable. When the cable is in contact with the liquid (as it could be if it were buried and in contact with a leaking fluid), the transmitted light is attenuated.

- Ref. 12 "Leak location in district heating networks using acoustical correlation techniques." Turtiainen, H.
(Acoustic correlation techniques)
Source: Valtion Teknillinen Tutkimuskeskus, Espoo, Finland.
Language: Finnish

The theoretical and applied sides of leak location through acoustic correlation are based on experience with 17 real leaks.

- Ref. 13 "In situ control of district heating networks." Gransell, H. and Ljungquist, John.
(Damage analysis and on-site measurements)

Source: Annual Conference of the Int'l District Heating Assn., v. 76;
 Studsvik Energiteknik AB,
 Language: English

Reports on damage analysis and on-site measurements, and describes methods for leak detection.

- Ref. 14 "Active acoustic detection of leaks in underground natural gas distribution lines." Jette, A. N., Morris, M. S.; Murphy, J. C.; and Parker, J. G.

(Field measurements, theoretical elastic waves, optical vibration sensor)

Source: Materials Evaluation, v. 35, no. 10, Oct. 1977, pp. 90-96, 99;
 Johns Hopkins University, Baltimore, Maryland, USA.
 Language: English

Describes research program aimed at understanding the acoustic detection of leaks in pipes.

- Ref. 15 "Pipeline leak location using radiotracer technique." Eapen, A.C., Ajmera, R.I., and Agashe, S.M.
 (Radiotracer technique)
 Source: Bhabha Atomic Research Centre, Bombay, India - Isotope Div.
 Language: English

Compares new radiotracer technique to other leak detection techniques.

4 Survey of District Heating Leak Detection and Location Practices

This survey was undertaken as part of a joint program between the U.S. Department of Energy and utilities that operate district heating and cooling systems. The objective of the joint program is the development of an in-stream acoustic sensor to locate steam leaks. The survey itself was aimed at identifying and characterizing current practices for detecting and locating leaks in district heating systems, specifically steam systems. This

information reflects the conditions, needs, and requirements of the DH industry in developing acoustic leak detection technology

4.1 Survey Method

The survey was conducted through telephone contacts with utility members of the International District Heating and Cooling Association (IDHA). Introductory remarks used in the survey, and the form used to record the information obtained, are included in Appendix A.

The survey was designed to gather information in three major areas: (a) characteristics of the distribution system that may be relevant to design and implementation of the acoustic leak detection technology, (b) technologies and practices currently used by the utility to detect and locate leaks, and (c) interest in utilizing the acoustic leak detection technology developed by ANL.

Results of the survey are summarized below, and detailed notes are provided in Appendix B.

4.2 Results

There are 59 companies listed as "utility" members of the IDHA. Of these, 3 are European, 4 are Japanese, 5 are planning systems that are not operational yet, and 3 are holding companies that own a number of operating district heating and cooling systems. All 44 of the operational North American district heating and/or cooling system companies were surveyed. Table 1 shows the names and telephone numbers of the companies and individuals contacted. In addition, investigations of European leak detection practices were made and summarized.

In Table 2, basic system data are summarized. Of the 44 companies contacted, 30 provide steam only, 9 provide steam plus chilled water and/or hot water, 2 provide hot water only, and 2 provide hot water and chilled water.

Some of these systems have had pipe in the ground for many years. Of the 31 systems for which age data were given, 17 were at least 60 years old.

Table 1. Utilities Surveyed

Name of system	Contact person	Phone
Alabama Power Company	Dale Dambach	205-226-1880
Baltimore Thermal	Brian Boor	301-625-2222
Boston Thermal	Alan Murphy	617-482-9550
Central Heat Distribution (Vancouver)	Jim Barnes	604-688-9584
Cleveland Thermal	Rick Pucak	216-241-5980
Cogeneration Management Company	Don Yeaple	617-732-2700
Concord Steam	Mark Saltzman	603-224-1461
Consolidated Edison	Tony Codner	215-576-2440
Dayton Power and Light	Henry Routzohn	513-227-2481
Detroit Edison	Terry Schumaier	313-237-5290
District Energy St. Paul	Ray Schmidt	612-297-8955
Energy Networks Inc.	Jeff Lindberg	203-727-3095
Energy Systems Co. — Omaha	Dave Woods	402-346-9066
Eugene Water and Electric Board	Dennis Daggett	503-484-2411
Fairbanks Municipal Utilities	John P. Stenberg	907-459-6259
Georgia Power Co.	Robert Stewart	404-526-4678
Harrisburg Steam Works	Jan Sockel	717-234-4600
Indianapolis Power and Light	Fred Brasher	317-261-8854
Jamestown Board of Public Utilities	Doug Champ	716-483-7582
Kent County Public Works	Bill Allen	616-774-3694
Lansing Board of Power and Light	Joette Woodard-Yauk	517-371-6780
Mid-America Energy Resources	David Kiesel	317-261-8893
Minneapolis Energy Center	Gary Gustafson	612-349-6072
Nashville Thermal	Roger Beckham	615-244-3150
NRG Thermal	Mark Anderson	612-373-5335
Pacific Energy/Central Plants Inc.	Vic Dilloway	213-725-1139
Pacific Gas and Electric	Rich Mayer	415-973-3828
PACT, Ltd.	Bob Sazio	412-642-7446
Philadelphia Thermal	Steve Smith	215-875-6911
Pittsburgh Thermal	Jim Cummings	412-231-0409
Public Service Co. of Colorado	Dennis Elliot	303-573-4397
Rochester District Heating Cooperative	Howard Cone	716-546-8890
St. Louis Thermal	Art Stanze	314-621-3550
Seattle Steam	Woody Woodard	206-623-6366
Toronto District Heating Corp.	Alex Bystrin	416-392-6838
Trenton District Energy	Don Leibowitz	609-396-1892
Trigen — Tulsa	Ken Adams	918-582-2212
Trigen — London, Ontario	Gary Nickerson	519-434-9194
Trigen — Kansas City	Bob Stevenson	816-556-2821
Trigen — Nassau County	Al Gussler	609-396-7651
United Illuminating	Craig Bradley	203-787-7200
Willmar Public Utilities	Bart Murphy	612-235-4422
Wisconsin Electric	Tom Ventmiglia	414-221-2491
Youngstown Thermal	Rich Burns	216-743-7712

Table 2. Basic System Data

Name of system	Max. age of pipe (yr)	Annual sales (10 ⁶ Btu) ^a	Miles of pipe	Services provided (S = steam; HW = hot water CW = cooling)
Alabama Power Company	70	548,522	6	S
Baltimore Thermal		1,646,400 #	15	S
Boston Thermal	60		22	S
Central Heat Distribution (Vancouver)	22	998,473	5	S
Cleveland Thermal		1,399,648 #	19	S
Cogeneration Management Company	15		1.5	S
Concord Steam	60	300,000	8	S
Consolidated Edison		37,298,000	100	S
Dayton Power and Light	89		15	S
Detroit Edison	85	3,957,353	41	S
District Energy St. Paul	8	824,557	20	HW
Energy Networks Inc.		1,003,932	17	S, HW, CW
Energy Systems Co. — Omaha	24			S, CW
Eugene Water and Electric Board	80	467,881 #	9	S
Fairbanks Municipal Utilities		135,360 #		S, HW
Georgia Power Co. ⁸⁴	84	107,300	28	S
Harrisburg Steam Works		357,700	7	S
Indianapolis Power and Light		5,681,900		S
Jamestown Board of Public Utilities	7		6	S
Kent County Public Works	70	695,568	1.5	S
Lansing Board of Power and Light	83	1,882,858	12	S
Mid-America Energy Resources	1			CW
Minneapolis Energy Center		1,714,208	4	S, HW, CW
Nashville Thermal	17	398,503		S, CW
NRG Thermal	8		5.5	S
Pacific Energy/Central Plants Inc.				S, HW, CW
Pacific Gas and Electric	80	722,646	11	S
PACT, Ltd.	70		7	S
Philadelphia Thermal		4,498,800	33	S
Pittsburgh Thermal		598,882	1	S, CW
Public Service Co. of Colorado	90	1,038,000 #	11	S
Rochester District Heating Cooperative	110		9	S
St. Louis Thermal		999,559	22	S
Seattle Steam	100	986,280	18.5	S
Toronto District Heating Corp.	30	2,586,000	12	S
Trenton District Energy	8	447,000		HW
Trigen — Tulsa	21		2	S, CW
Trigen — London, Ontario		120,000	4	S
Trigen — Kansas City	85		9	S
Trigen — Nassau County	20		9	HW, CW
United Illuminating	3		<1	HW, CW
Willmar Public Utilities	9	55,654	4	HW, S
Wisconsin Electric	86	2,160,274	28	S
Youngstown Thermal	90	496,320	6	S
Total		74,127,578	529	

^aFor 1989 except where marked with # (1988 data).

Two measures of system size are shown: annual energy sales and miles of supply piping. Although these data were not available for all utilities, the total energy sales for the utilities with such data was more than 74×10^{12} Btu, and the total length of supply pipe was 530 miles. This information will be useful in weighting the importance of the responses. For example, the needs of Consolidated Edison, with more than 50% of the total sales and 25% of the supply piping, are extremely significant.

Table 3 summarizes the types of piping installations and expansion devices used. Box conduit, solid pour, and prefabricated pipe conduit types are illustrated in Fig. 1. While 41% of the respondents use prefabricated conduit (pipe-within-pipe), this is often only their newer pipe. A major exception is Consolidated Edison, whose standard design is a pipe-within-pipe with an annular space between the two.

The next most common installation is box conduit (36%), followed by direct bury (32%), solid pour (25%), and tunnels (14%). Although no definite figures are available, box conduit probably represents the greatest number of pipe miles for utilities other than Consolidated Edison.

Slip joints and bellows are by far the most common expansion devices, and many utilities use both types. Slip joints are used by 57% of the respondents, and bellows by 55%, while only 9% use ball joints and 23% use expansion loops.

Typical or average intervals between expansion devices and between manholes are indicated in Table 4. The interval between expansion devices is relevant due to the acoustic attenuation caused by such devices if sensors are placed on the pipe surface. Interval between manholes is important if it is possible that the hot tap required for the ANL acoustic detection device can be done at manholes to minimize costs.

Of the 35 utilities providing steam pressure data, 16 provide high pressure and low pressure steam service (low pressure is defined here as 50 psi or less), 14 provide only high-pressure service, 2 provide only low-pressure service, and 1 distributes 800-psi superheated steam.

Of the 32 systems providing high-pressure service, 15 operated at 150 psi or less. Only 7 systems operated at pressures over 200 psi.

Table 3. Summary of Pipe Installations and Expansion Devices

Name of system	Types of pipe installations ^a					Types of expansion devices ^b			
	BC	SP	T	PC	DB	S	Bel	B	EL
Alabama Power Company	•			•		•	•		
Baltimore Thermal	•					•			
Boston Thermal	•	•					•		
Central Heat Distribution (Vancouver)					•	•	•		
Cleveland Thermal	•	•		•		•	•		
Cogeneration Management Company			•						
Concord Steam					•		•		
Consolidated Edison				•		•	•		•
Dayton Power and Light	•	•				•			
Detroit Edison	•	•				•			•
District Energy St. Paul				•			•		•
Energy Networks Inc.				•		•	•	•	•
Energy Systems Co. — Omaha	•					•	•		
Eugene Water and Electric Board	•	•		•	•	•	•		•
Fairbanks Municipal Utilities	•				•	•	•		•
Georgia Power Co.				•		•	•		
Harrisburg Steam Works				•	•		•		
Indianapolis Power and Light		•				•			
Jamestown Board of Public Utilities				•					•
Kent County Public Works	•			•	•	•			
Lansing Board of Power and Light	•				•	•		•	
Mid-America Energy Resources									
Minneapolis Energy Center			•	•				•	•
Nashville Thermal			•		•	•			
NRG Thermal	•			•		•	•		
Pacific Energy/Central Plants Inc.									
Pacific Gas and Electric		•					•		
PACT, Ltd.	•	•	•			•	•		
Philadelphia Thermal				•	•				
Pittsburgh Thermal		•					•		
Public Service Co. of Colorado				•		•	•		
Rochester District Heating Cooperative	•					•			•
St. Louis Thermal	•			•		•	•		
Seattle Steam		•			•		•		
Toronto District Heating Corp.			•		•	•		•	
Trenton District Energy				•					•
Trigen — Tulsa				•		•	•		
Trigen — London, Ontario									
Trigen — Kansas City					•		•		
Trigen — Nassau County									
United Illuminating									
Willmar Public Utilities									
Wisconsin Electric	•		•		•	•	•		
Youngstown Thermal		•		•	•	•	•		
Totals	16	11	6	18	14	25	24	4	10
% of respondents	36	25	14	41	32	57	55	9	23

^aPipe Installations: BC = Box conduit; SP = Solid pour; T = Tunnel; PC = Prefabricated conduit or other pipe-within-pipe; DB = Direct Bury

^bExpansion Devices: S = Slip; Bel = Bellows; B = Ball; EL = Expansion loop.

Table 4. Other System Details

Name of system	Typical or average intervals ^a		Maximum pressure (psi)		Condensate return	
	Between exp. units	Between manholes	HP	LP	Yes	No
Alabama Power Company	200	400	150			•
Baltimore Thermal	200	200	180	35		•
Boston Thermal	75	460	190			•
Central Heat Distribution (Vancouver)			190		•	
Cleveland Thermal	200	100	150	22		•
Cogeneration Management Company						
Concord Steam			165			•
Consolidated Edison	200	500	200			•
Dayton Power and Light	75	100	190	7		•
Detroit Edison	450	450	125	50		•
District Energy St. Paul		350	180			
Energy Networks Inc.	100	750	150			•
Energy Systems Co. — Omaha		250	125		•	
Eugene Water and Electric Board	750	375	250	15	•	
Fairbanks Municipal Utilities				50		
Georgia Power Co.			90	10		•
Harrisburg Steam Works	150	200	150	30		•
Indianapolis Power and Light	200	200	250	15		•
Jamestown Board of Public Utilities						
Kent County Public Works	450	550	150	15		•
Lansing Board of Power and Light	400	250	265	15		•
Mid-America Energy Resources						
Minneapolis Energy Center	350	350	250		•	
Nashville Thermal	200	200	150		•	
NRG Thermal	300	600	b		•	
Pacific Energy/Central Plants Inc.						
Pacific Gas and Electric			125			•
PACT, Ltd.			150		•	
Philadelphia Thermal			225			•
Pittsburgh Thermal	125	125	230		•	
Public Service Co. of Colorado		225	125	30		•
Rochester District Heating Cooperative		500	200			•
St. Louis Thermal	200	200				•
Seattle Steam		325	140	20		•
Toronto District Heating Corp.			250	25	•	
Trenton District Energy		250				NA
Trigen — Tulsa	150	400	150		•	
Trigen — London, Ontario						
Trigen — Kansas City	100	750	185	15		•
Trigen — Nassau County						NA
United Illuminating						
Willmar Public Utilities				10		
Wisconsin Electric	125	350	160	12		•
Youngstown Thermal	350	350	150	15	•	
Totals					11	22
Average of responses	243	349	176	22		
% of respondents					25%	50%

^aDetails provided in Appendix B. ^bNRG provides superheated steam at 800 psi. Condensate is 150 psi.

Box type concrete conduit

Removable cover on box type conduit

Solid pour conduit

Metal casing, prefabricated conduit

Fig. 1. Basic Piping Designs (from "District Heating Handbook, Fourth Edition," International District Heating and Cooling Association, 1983)

"External sources" was cited as the most common leak problem (Table 5). For example, leaks in city water mains and salt-laden street drainage are two important types of external sources. The specific location of the leak in the distribution system would vary depending on the location of the external source.

Expansion devices are the most common specific locations of leaks; 30% reported that this is a trouble spot. Most of the systems with condensate return indicated that the condensate pipe is their biggest leak problem. Other trouble spots, in descending order of importance, are flanges, welds, valves, steam traps, rollers, and tees.

Eight steam companies indicated that they have condensate return. Of these systems, 44% indicated that the condensate pipe is their biggest leak problem.

4.2.1. Leak Detection Practices

In this report a distinction is made between "detection" (determining that a leak exists) and "location" (establishing the location of the leak).

Almost 75% of the respondents indicated that their primary means of detecting leaks is a report of visible steam from a manhole or customer installation (Table 6). Infrared is used by 11%, while 9% monitor makeup water requirements to detect leaks. In-line electrical leak detection systems were installed in five systems, but only three are being used. The others have been abandoned due to extensive problems with false alarms and other deficiencies.

Several systems with condensate returns will typically replace an entire section of condensate line rather than attempt to locate the leak, because of general deterioration of the line.

Three-quarters of the respondents have found one or more methods effective to some extent in locating leaks (Table 7). Generally, once a leak is detected, its location is isolated between two manholes on the basis of visible steam. Because certain types of system components are weak spots (Table 4), as-built drawings are used to narrow down the possible location. Simply feeling the surface of the pavement for hot spots is used by 34% of the systems. Some type of acoustic technology is used by 23%, while 16% use infrared for locating leaks.

Table 5. Location of Leaks

Name of system	Primary location of leaks ^a								
	ED	Ex	Tr	W	V	F	R	CP	T
Alabama Power Company			•						
Baltimore Thermal							•		•
Boston Thermal	•								
Central Heat Distribution (Vancouver)									
Cleveland Thermal		•							
Cogeneration Management Company									
Concord Steam	•			•					
Consolidated Edison						•			
Dayton Power and Light		•							
Detroit Edison	•	•				•			
District Energy St. Paul									
Energy Networks Inc.	•			•	•				
Energy Systems Co. — Omaha	•							•	
Eugene Water and Electric Board				•				•	
Fairbanks Municipal Utilities									
Georgia Power Co.									
Harrisburg Steam Works	•	•							
Indianapolis Power and Light		•							
Jamestown Board of Public Utilities									
Kent County Public Works		•							
Lansing Board of Power and Light	•					•	•		
Mid-America Energy Resources									
Minneapolis Energy Center	•				•			•	
Nashville Thermal		•						•	
NRG Thermal								•	
Pacific Energy/Central Plants Inc.	•	•				•			
Pacific Gas and Electric									
PACT, Ltd.	•							•	
Philadelphia Thermal		•		•					
Pittsburgh Thermal					•	•		•	
Public Service Co. of Colorado				•	•				
Rochester District Heating Cooperative			•						
St. Louis Thermal		•		•					
Seattle Steam		•							
Toronto District Heating Corp.	•								
Trenton District Energy		•							
Trigen — Tulsa								•	
Trigen — London, Ontario									
Trigen — Kansas City		•							
Trigen — Nassau County									
United Illuminating									
Willmar Public Utilities									
Wisconsin Electric	•	•							
Youngstown Thermal	•	•							
Total	13	15	2	6	4	5	2	8	1
% of respondents	30	34	5	14	9	11	5	18	2

^aED = Expansion devices; Ex = Leaks due to external causes; TR = Traps; W = Welds; V = Valves; F = Flanges; R = Rollers; CP = Condensate pipe; T = Service Tee.

Table 6. Leak Detection Methods

Name of system	Methods used for detecting leaks				Depth of pipe
	Visible steam	Infra-red	Makeup water	Wire in conduit	
Alabama Power Company	•				3-4
Baltimore Thermal	•				
Boston Thermal	•				10
Central Heat Distribution (Vancouver)					
Cleveland Thermal	•				
Cogeneration Management Company	•				
Concord Steam	•				
Consolidated Edison	•				
Dayton Power and Light	•				3-9
Detroit Edison	•				8-10
District Energy St. Paul				•	2-4
Energy Networks Inc.	•				2-8
Energy Systems Co. — Omaha	•				
Eugene Water and Electric Board					2-15
Fairbanks Municipal Utilities	•		•		4-6
Georgia Power Co.	•				
Harrisburg Steam Works	•				3-10
Indianapolis Power and Light	•				2-10
Jamestown Board of Public Utilities				•	
Kent County Public Works	•	•			
Lansing Board of Power and Light	•				
Mid-America Energy Resources					
Minneapolis Energy Center	•				
Nashville Thermal		•			
NRG Thermal	•		•		8
Pacific Energy/Central Plants Inc.	•		•		
Pacific Gas and Electric	•				
PACT, Ltd.	•				
Philadelphia Thermal					
Pittsburgh Thermal	•				
Public Service Co. of Colorado		•			
Rochester District Heating Cooperative	•	•			
St. Louis Thermal	•				
Seattle Steam	•				
Toronto District Heating Corp.	•				
Trenton District Energy					2-9
Trigen — Tulsa		•			
Trigen — London, Ontario	•				
Trigen — Kansas City	•				4-10
Trigen — Nassau County	•		•		
United Illuminating					
Willmar Public Utilities				•	
Wisconsin Electric	•				5-18
Youngstown Thermal	•				3-10
Total	32	5	4	3	
% of respondents	73	11	9	7	

Table 7. Leak Location Methods

Name of system	Methods found useful ^a				Methods tried without success	
	FS	A	IR	Other	A	IR
Alabama Power Company	•				•	
Baltimore Thermal		•				•
Boston Thermal	•				•	•
Central Heat Distribution (Vancouver)				Leaks not a problem		
Cleveland Thermal		•				
Cogeneration Management Company				Leak obvious in tunnel		
Concord Steam		•				
Consolidated Edison	•	•				
Dayton Power and Light			•	Dry spot on rainy day		
Detroit Edison		•				
District Energy St. Paul				Leaks not a problem		
Energy Networks Inc.						•
Energy Systems Co. — Omaha				Use elec. probe if needed		
Eugene Water and Electric Board	•		•		•	
Fairbanks Municipal Utilities	•					
Georgia Power Co.	•					
Harrisburg Steam Works		•				
Indianapolis Power and Light	•				•	
Jamestown Board of Public Utilities			•	In-line elec. system	•	
Kent County Public Works	•					
Lansing Board of Power and Light				Hand-held thermal meter		
Mid-America Energy Resources				Leaks not a problem		
Minneapolis Energy Center	•					
Nashville Thermal			•	Leaks obvious in tunnels		
NRG Thermal				Escape of vapor or water		•
Pacific Energy/Central Plants Inc.				Escape of vapor or water		
Pacific Gas and Electric		•				•
PACT, Ltd.	•					
Philadelphia Thermal				Leaks not a problem		
Pittsburgh Thermal	•				•	
Public Service Co. of Colorado	•					
Rochester District Heating Cooperative			•			
St. Louis Thermal				Drill thru roof of conduit	•	
Seattle Steam		•				
Toronto District Heating Corp.			•	Leaks not a problem		
Trenton District Energy	•					
Trigen — Tulsa			•	Replacing cond. line		
Trigen — London, Ontario ^b				Dry spot on rainy day		
Trigen — Kansas City		•		Heath good on HP, not on LP		
Trigen — Nassau County				Leaks not a problem		
United Illuminating						
Willmar Public Utilities				Leaks not a problem		
Wisconsin Electric	•			Leaks not a problem	•	
Youngstown Thermal	•	•				•
Total	15	10	7		8	6
% of respondents	34	23	16		18	14

^aFS = Feel street or vault surface; A = Acoustic; IR = Infrared.

^bSystem is very old, and operator indicated that no money would be expended on leak repair. Operator hopes to expand system significantly, at which time in-line leak detection system will be installed.

The following is a summary of the experiences of utilities that have used "acoustic" technologies successfully (in several cases, the devices actually measure vibration).

- Baltimore Thermal: Heath system, bought four years ago for about \$1,000. A receptor, of 3-4 in. diameter, is placed on pavement and moved 3-4 in. at a time. Have a staff person who uses the device effectively. Describes accuracy as within 4-5 ft. However, the company is interested in the ANL technology in order to further improve effectiveness.
- Cleveland Thermal: Heath system; price about \$2000. Staff person required time to develop a "good ear." Sandy soils in area; system doesn't work with clay soils. Must use between 2:00-5:00 a.m., when background noise is minimal.
- Concord Steam: Use city water department's acoustic device, a Heath Aquascope. An acoustic sensor is placed directly on the pavement or in contact with a valve. Where only soil is above the pipe, a bar must be driven down to contact the pipe to obtain a good signal.
- Consolidated Edison: Sometimes uses bar-hole method, where bar is driven down to contact the conduit. However, this is not always possible due to obstruction by other utilities (probably 30% of system). Bar-holing is also a safety concern.
- Detroit Edison: Drills hole in pavement and inserts sonic probe to contact the conduit; repeats this every foot or so in area in where the leak is suspected. Describes accuracy as "hit or miss." Company is interested in the ANL technology.
- Harrisburg Steam Works: Use the "STS Water Leak Pinpointing Instrument" made by Paul Michael & Associates, Inc. (814-238-8533). Although Dr. Michael was reluctant to share specifics on this vibration-measuring device, including the frequencies at which it operates, he did provide the information shown in Appendix C. Dr. Michael sells his device mostly to water utilities, but Harrisburg bought one three years ago, and now several other steam systems have bought the instrument or plan to do so.

Harrisburg indicated that it works well but needs a quiet background, so it is used the night. Sets on a steel tripod on the pavement. Dr. Michael prices the device at \$3200.

- Pacific Gas and Electric: Can't remember name of maker of the device, but thinks it might be Heath. Works well except when background noise is significant.
- Seattle Steam: Bought a device from Dr. Michael (see Harrisburg notes) for \$2600 three months ago. Works very well on direct buried pipe, but is tricky with conduit.
- Trigen-Kansas City: Uses Heath Aquascope on high-pressure lines, but it does not work on low-pressure lines. Apparently, sensitivity is too low to detect leaks in the 15-psi low-pressure lines.
- Youngstown Thermal: Borrows Cleveland Thermal's acoustic device. Works well, but requires practice to use effectively. However, the company is interested in the ANL technology in order to further improve effectiveness.

Of these 10 utilities currently using acoustic technologies with some success, five are interested in the ANL technology because they feel that the current methods are not as effective as is desirable..

Acoustic leak location technology has been tried without success by 18% of respondents. Among the potential reasons why some utilities were able to successfully use acoustic devices while others were unsuccessful are these: (a) technology used, (b) soil type, (c) staff experience/expertise, and (d) pipe depth. The influence of these factors on the eight utilities that unsuccessfully tried acoustic devices was not always clear. Generally, if the equipment is no longer used the utility was not able to describe the device in detail. However, the following notes were obtained on these experiences.

- Alabama Power: "Hand-held sonic tester."
- Boston Thermal: Apparently tried Cleveland Thermal's Heath system. They noted that, in contrast to the Cleveland Thermal

area, where the technology is used successfully, the soils in Boston are not sandy. Pipe depth is about 10 ft.

- Eugene Water and Electric Board: Unsuccessfully tried "Geophones" used by city water department, described as a stethoscope placed on the pavement. Pipe is 2-15 ft. deep.
- Indianapolis Power and Light: Tried Heath technology without success 3-4 years ago. Pipe depth varies significantly, from 2 to 10 ft.
- Kent County Public Works: Tried water department acoustic device.
- Pittsburgh Thermal: Tried acoustic leak location contractor.
- St. Louis Thermal: Borrowed and used Cleveland Thermal's equipment, without success. Also tried a leak location contractor.
- Wisconsin Electric: Bought an acoustic device (no details available) about 10 years ago, but was unsuccessful with it. Needed to bar-hole down due to depth of pipe, which ranges from 5 to 18 ft.

While seven systems have successfully used infrared technology, six others have tried this method but found it not effective. Pipe depth may also be a significant factor in these differences.

4.2.2 Interest in ANL Acoustic Technology

Overall, 41% of the respondents indicated interest in using the ANL acoustic technology, while 59% indicated no interest (Table 8). Utilities that were not interested were asked to explain why; some utilities gave more than one reason. Responses are summarized below.

- Leaks are not a significant problem: 58%
- Current methods work well: 43%
- Don't want to consider using hot tap: 15%

Table 8. General Interest in ANL Technology

Name of system	Interested in using ANL technology?		If not, why not?			
	Yes	No	Leaks not a problem	Current method works	Don't want hot tap	Other
Alabama Power Company		•	•	•	•	
Baltimore Thermal	•					
Boston Thermal	•					
Central Heat Distribution (Vancouver)		•	•			
Cleveland Thermal		•		•		
Cogeneration Management Company		•		•		
Concord Steam		•	•	•		
Consolidated Edison	•					
Dayton Power and Light		•		•		
Detroit Edison	•					
District Energy St. Paul		•	•	•		
Energy Networks Inc.	•					
Energy Systems Co. — Omaha		•				
Eugene Water and Electric Board		•	•	•		
Fairbanks Municipal Utilities		•	•			
Georgia Power Co.		•				•
Harrisburg Steam Works		•		•		
Indianapolis Power and Light	•					
Jamestown Board of Public Utilities		•	•			
Kent County Public Works	•					
Lansing Board of Power and Light	•					
Mid-America Energy Resources		•	•			
Minneapolis Energy Center	•					
Nashville Thermal		•		•		
NRG Thermal	•					
Pacific Energy/Central Plants Inc.	•					
Pacific Gas and Electric		•			•	
PACT, Ltd.	•					
Philadelphia Thermal		•	•			
Pittsburgh Thermal	•					
Public Service Co. of Colorado		•			•	
Rochester District Heating Cooperative		•	•		•	
St. Louis Thermal	•					
Seattle Steam		•		•		
Toronto District Heating Corp.		•	•			
Trenton District Energy	•					
Trigen — Tulsa	•					•
Trigen — London, Ontario		•				
Trigen — Kansas City	•					
Trigen — Nassau County		•	•			
United Illuminating		•	•			
Willmar Public Utilities		•	•			
Wisconsin Electric		•	•			
Youngstown Thermal	•					
Total	18	26	15	11	4	2
% of respondents	41	59	58	42	15	8

Although only four respondents who are not interested in the ANL technology noted the hot tap as the reason, reservations about hot taps are pervasive and very significant. Concerns about hot taps focus on safety, cost, and introduction of additional potential leak sites.

Listed below are notes on each utility that expressed interest in the ANL technology, including their thoughts on hot taps:

- Baltimore Thermal's leak problems are in low-pressure (20-35 psi) lines. Key concern is minimizing labor costs.
- Boston Thermal has isolation valves at each manhole, and would shut off a section of line to weld in the tap rather than install a hot tap. On average, the system loses about four bellows every year and develops several other leaks.
- Consolidated Edison is concerned about hot taps from all three standpoints noted above. The company bought hot-tap equipment 10 years ago, and has used it, generally for 3-6 in. taps. The equipment is too large to fit into a manhole. Based on experience, a hot tap costs about \$4000 (\$3000 for the excavation plus \$1000 for the tap, assuming two men for one day at \$30/hr).
- Detroit Edison stated that cost-effective, quick hot-tap service from a contractor would be essential. The company does not allow its staff to do hot taps. About 40 leaks are repaired annually, at a cost of \$10,000-15,000 per excavation. Annual budget for leak work is about \$1 million.
- Energy Networks Inc. noted that although leaks are not a particular problem, some of its older steam pipe is almost 30 years old; the company is interested in the ANL technology if it proves to be cost-effective.
- Indianapolis Power and Light noted that its leak problems are almost all in the low-pressure line (10-15 psi), and that hot taps in a low-pressure line are not a problem. (Of the 11 systems providing both high-and low-pressure service, 5 indicated that the low-pressure system is where their leak problems are. The

company spends about \$1.25 million annually on leak detection and repair.

- Kent County expressed reservations about hot taps. Quick restoration of service is key.
- Lansing Board of Power and Light is concerned about corrosion potential at hot-tap sites. Leaks do not receive a high priority at present.
- Minneapolis Energy Center felt that a hot tap could be done in a manhole if the leak is small enough.
- NRG Thermal's leak problems are unusual: they generally occur in a 150-psi condensate line. Because a portion of the line is located along railroad tracks, shoring requirements make excavation very expensive (perhaps \$25,000 per hole). Hot taps of less than 1/2 in. do not appear to be a problem and could be done in vaults, but cost is estimated at about \$1000 per tap.
- Pacific Energy Co./Central Plants Inc. is interested in the ANL technology, but needs are unusual because most of its systems are chilled water or high-temperature hot water; only a small amount of steam service is provided.
- PACT, Ltd. is fairly successful in locating leaks, but is interested in improvement. The company is concerned about hot taps, particularly in confined spaces.
- Pittsburgh Thermal's primary concern is leaks in its condensate lines.
- St. Louis Thermal would not buy the ANL acoustic equipment but would be interested in contracting with a company that owns the equipment.

- Toronto District Heating Corp. has problems in locating leaks in its low-pressure (15 psi) line. As a result, the company is interested in the ANL technology if the hot taps can be done in manholes, so excavation would not be necessary.
- Trenton District Energy and Trigen-Tulsa are interested for the long term, although leaks are currently not a major problem for either company.

Most of the companies that expressed interest are looking for a mobile system to be implemented as needed (Table 9). Only two expressed interest in a permanent leak detection and location system.

All of the companies expressing overall interest in the ANL technology would consider hosting a field test, depending on specifics (particularly cost).

4.2.3 European Experience

The following descriptions of European leak location practices are based on discussions with these individuals:

- Dr. Hans Mortensen, President of the Metropolitan Copenhagen Heating Transmission Co. In addition to managing the Copenhagen system, which has 30 miles of twin pipe, Dr. Mortensen is very active in the International Energy Agency on district heating matters.
- Sture Andersson, who has served as Production Manager of the Malmö Energy Authority in Malmö, Sweden, and as Chairman of District Heating Technology at Värmeforsk, the Swedish Thermal Energy Research Institute. He is currently responsible for Research and Development at Malmö Energy, and is Professor in district heating at the Institute of Technology in Lund.
- Eric Peterson of A/S Bjeld & Lauridsen, a Danish company that provides infrared leak detection and location services throughout Europe.

Table 9. Specific Interest in ANL Technology

Name of system	Types of system of interest		Interested in field test?	
	Permanent system	Mobile system	Yes	No
Alabama Power Company				
Baltimore Thermal	•	•	•	
Boston Thermal		•	•	
Central Heat Distribution (Vancouver)				
Cleveland Thermal				
Cogeneration Management Company				
Concord Steam				
Consolidated Edison		•	•	
Dayton Power and Light				
Detroit Edison		•	•	
District Energy St. Paul				
Energy Networks Inc.			•	
Energy Systems Co. — Omaha				
Eugene Water and Electric Board				
Fairbanks Municipal Utilities				
Georgia Power Co.				
Harrisburg Steam Works				
Indianapolis Power and Light			•	
Jamestown Board of Public Utilities				
Kent County Public Works	•		•	
Lansing Board of Power and Light		•	•	
Mid-America Energy Resources				
Minneapolis Energy Center			•	
Nashville Thermal				
NRG Thermal		•	•	
Pacific Energy/Central Plants Inc.		•	•	
Pacific Gas and Electric				
PACT, Ltd.		•	•	
Philadelphia Thermal				
Pittsburgh Thermal		•	•	
Public Service Co. of Colorado				
Rochester District Heating Cooperative				
St. Louis Thermal		•	•	
Seattle Steam				
Toronto District Heating Corp.				
Trenton District Energy			•	
Trigen — Tulsa			•	
Trigen — London, Ontario				
Trigen — Kansas City			•	
Trigen — Nassau County				
United Illuminating				
Willmar Public Utilities				
Wisconsin Electric				
Youngstown Thermal			•	
Total	2	10	18	
% of respondents	5	23	41	

Electric Alarm Systems: In-line electric alarm systems generally were installed during construction of European district heating systems after approximately 1975. Initially, many of these systems had significant problems with false alarms and other malfunctions, due to poor quality control during the manufacture of prefabricated pipe sections, as well as to bad connections between pipe sections in the field. (Notably, these same types of problems have been visible in North American installations. This has resulted in considerable efforts to "debug" these systems and, in two cases, abandonment of the alarm system.) These problems have apparently been solved in Europe through attention to proper workmanship, both in the factory and in the field.

Infrared Imaging: The electric alarm systems are sometimes augmented with infrared techniques; in older systems, infrared is the primary leak detection and location method. Infrared images can be taken with a camera mounted on the roof of a car or on an airplane flying at a altitude of no more than 300 m.

Infrared imaging is best done at night when it is not raining and when there is no snow on the ground. Fog is also problematic. The best images are generally obtained in spring or fall.

The use of infrared is much more widespread in Europe than in North America, at least in part because hot water, rather than steam, is the primary medium of heat transmission in European DH systems. The higher temperatures in steam piping apparently result in more blurring of the infrared image, thereby reducing its value in pinpointing the location of leaks.

Another factor is pipe depth. Bjeld & Lauridsen has stated that the infrared technology is useful in examining pipes no more than 2 m deep. Danish district heating pipes, for example, are normally about 1 m deep.

At the Studsvik Research Institute in Sweden, thermography is now being further developed so that it can not only detect and locate leaks but also quantify the extent of heat loss.

Acoustic Technologies: Almost two-thirds of the district heating piping in what was formerly West Germany were installed without in-line

electric alarm systems. To address the needs of these systems, work has been done to develop an acoustic leak location technology called "Lokal." This technique is similar to that being pursued by ANL, i.e., correlation analysis of acoustic signals from sensors placed on each side of the suspected leak area. However, the sensors are placed on the pipe rather than in-stream, as has become necessary to provide accuracy in location of leaks in steam pipes. The German work is directed toward hot water pipes. The development of "Lokal" was undertaken under the auspices of the IEA during 1984-87, and an IEA report was published.

Dyes: One more technique being developed for leak detection is the introduction of a dye into DH water. Although the purposes of this technique (detecting leaks into building domestic hot water or into the building substation) are different than that of the leak detection technology being developed by ANL, it is described here as a matter of interest.

In Sweden, only a single-wall heat exchanger separates district hot water from the domestic hot water supply for the buildings served. As a result, considerable attention is paid to preventing leaks from the district system into the domestic hot water supply. To address this issue, tests were conducted with a dye called pyranine. The results were encouraging, and even small leaks could be detected.

4.3 Conclusions from Survey

1. The extent to which leak detection is important varies considerably from utility to utility.
 - At least three of the larger utilities spend \$1 million or more each year locating and repairing leaks.
 - One-half of the respondents do not consider leaks to be a problem and/or are satisfied with current leak location methods.
 - More than one-third (34%) of the respondents do not consider leaks a significant problem.
 - One quarter of the respondents are satisfied with their current methods for locating leaks. Within this group, 9% also indicated that leaks are not a problem.

2. The most common leak location method is decidedly "low-tech": feeling the pavement to see where it is hottest and/or zeroing in on specific trouble-spot components using as-built drawings.

3. Almost one-quarter (23%) of the respondents have found an acoustic technology useful to some extent in leak location, while 18% have tried an acoustic technology without success.

- A particular acoustic technology that has been used with good success by one utility may be totally ineffective for another.
- The effectiveness of various acoustic or vibration-sensing devices appears to depend on a variety of factors, including the particular acoustic device used, staff expertise/experience, soil type, and pipe depth.
- Existing acoustic technologies are relatively inexpensive (several thousands of dollars).
- One-half of the respondents that found an existing acoustic technology useful also stated that they are interested in the ANL technology because their current methods are not as effective as desirable.

4. There is significant interest in the ANL technology, particularly among the larger steam utilities.

- More than 40% of the utilities surveyed are interested in using the acoustic leak detection and location technology being developed by ANL.
- The utilities interested in the ANL technology represent 76% of the total thermal energy sales by the surveyed utilities for which sales data were available.
- Of the utilities that expressed an interest in the ANL technology, 28% do not feel that leak detection is a high-priority problem.

- Of the utilities expressing no interest in the ANL technology, the following reasons were cited: leaks are not a problem (58%); current methods work well (42%); don't want to do hot taps (15%).

5. The market for the ANL technology is likely to be limited to a relatively few large steam systems.

- The likely capital cost of the ANL technology (\$40,000-50,000, according to ANL) is very high relative to other leak location technologies.
- However, this cost could be quickly recouped (due to the high cost of excavation) by utilities with a significant number of leaks and for whom the existing acoustic or other technologies do not work.

6. Most utilities are reluctant to do hot taps, and this presents a significant potential barrier to the use of the ANL technology.

- Concern about hot taps appears to be based on prior experience with large (several-inch) hot taps.
- Concerns about hot taps include safety, cost, and introduction of additional potential leak sites.
- To minimize overall operational costs of the ANL technology, it is important that the hot tap be performed in a manhole.
- The safety and cost problems with the size of tap likely required with the ANL technology (1/2 in. or less) should be considerably reduced compared to larger hot taps; this must be confirmed, quantified, and demonstrated.

5 Acoustic Leak Location by Cross-Correlation Analysis

A few examples of leak location by cross-correlation analysis of acoustic signals generated by a leak are presented to illustrate the potential for success and also the problems associated with this technology.

5.1 Leak Location with a Commercially Available Correlator at the ANL Steam Leak Facility

Using leaks generated in the ANL steam leak facility,¹ we evaluated a Metravib leak locator. In the Metravib system, accelerometers transmit signals to a central processing unit via radio waves. The Metravib unit has fixed-frequency windows; those evaluated were 400-1450, 400-2200, and 400-3000 Hz. Correlation peaks from the Metravib unit were observed with sensors located 6.4 and 12.8 m from the leak. Steam pressures in the range of 40-70 psi were used. The window of 400-3000 Hz was optimal for the Metravib system. With the two lower-frequency windows, no correlation peak associated with the leak was observed. One observed peak was due to noise in the system, which is easily filtered by using a frequency window whose lower limit is higher. While such filtering is not possible with the Metravib system, it is with the ANL instrumentation. Another correlation peak showed a 9-ms differential, indicating a leak-to-sensor spacing of about 10 m, if the empirically determined velocity of sound of 1100 m/s is used. This result is consistent with the actual 12.8-m sensor-to-leak spacing, but the error is large (about 30%).

The commercially available Metravib system is comparable in some respects to the ANL system but has limitations in several areas when used to locate steam leaks. The low- and high-frequency ranges should be more flexible to allow use of frequency windows such as 1-2, 2-4, and 3-6 kHz. The current Metravib system does not filter noise that the ANL system can; moreover, it requires a higher sampling rate and more sampling points. The Metravib system should also present the frequency spectrum for better characterization of noise sources, and it should have sensors that can tolerate steam pipe temperatures to allow direct contact with hot pipes.

5.2 Leak Location with a Commercially Available Correlator under Field Conditions

On September 20, 1991, personnel from Earl Ruble and Associates (Duluth, Minnesota) used a cross-correlation technique in attempting to locate three leaks in a Northern States Power (NPS) district heating system. These leaks were in pipes filled with hot water (condensate return line, 240°F, 150-200 psi). In the technique used, an acoustic sensor (with frequency response ranging from 100 Hz-2 kHz) was placed on one end of

each of two waveguides. The other ends of the waveguides are put in contact with the pipe in two different manholes on either side of the suspected leak. Cables carried the electrical signals to the instrumentation for the location analysis. The first leak could be heard at two manholes 391 ft apart. However, no correlation peaks were evident that could be used to accurately locate the leak.

In past field studies, Ruble and Associates have discovered that pipelines in air (not buried), such as those suspended on wall brackets in a below-ground room, tend to "ring." They believe that this is because a sound wave traveling along the water causes the pipe to vibrate in an extremely minute manner, creating sound waves that are in the same frequency ranges as true leaks. In this case, the leak sound was extremely strong and it could have induced the pipe vibration that is described as ringing. This ringing could overwhelm the leak sound and prevent a successful cross-correlation analysis. Without the damping effect of surrounding soil or sand, ringing can occur in varying degrees, depending on all the factors at a particular location. In the case of the NSP condensate return line, the pipe is encased in a very-low-density insulating material designed to prevent heat loss but not to support a pipe securely. In such a situation, there is no known method of correlating a leak if the conditions are adequate to cause the ringing.

The second field trial was at a location said to be between transducer locations 600 ft apart. The second pipeline is constructed just like the one described above. A weak leak sound was detected, but the correlation was virtually ideal. The signal-to-noise ratio was good and the leak location was specific. However it placed the leak at the "east" transducer. This means the leak was at that point or at a location farther away along the pipeline. From previous experience with this situation, the leak was either at the transducer location or was out of span (not between sensors) somewhere farther east of the "east" transducer location because there is no branch off the condensate line. The test equipment was rearranged so that the presumed leak would lie between the old east transducer and the new transducer farther east. Again, an excellent leak pattern was obtained on the monitor. In this case, the leak was indicated to be 19 ft west of what is now referred to as the new east transducer location. This was perplexing because that is where an excavation had been made a week earlier to repair a leak. Excavation later revealed that the source of the noise was indeed a

leak from a temporary clamp about 19 ft from the transducer location, as predicted. The leak rate was very small, also as predicted.

A question that must be answered is why it was possible to obtain a good correlator pattern on the monitor screen in the second case and not in the first. At present, we believe that the insulation in contact with the pipe provides enough damping to reduce the ringing and permit the leak sound to predominate in the second case (smaller leak). It is possible that the high pressures are important factors here as well.

At the third location, a strong leak was detected. However, pumps from a paper mill about 1200 ft away caused interfering sounds and a correlation analysis was not possible.

5.3 Leak Location with a Research-Quality Correlator under Laboratory and Field Conditions

Laboratory tests were carried out at ANL with artificial leaks under conditions that simulate the temperature and pressure of a steam distribution system (180 psi, 350°F). Laboratory-quality instrumentation (Spectral Dynamics Signal Analyzer SD375, Khrono-Hite filters, and Tektronix AM502 amplifiers) were employed. Laboratory testing was successful when sensors were placed directly on the pipe outer wall. Field tests with this system indicated that, in many situations, steam leaks in underground piping system can be located by acoustic techniques. However, application of the tested technology to underground piping is subject to limitations, chief of which is the presence of bellows that severely attenuate the acoustic wave generated by the leak. Where two acoustic sensors can be placed on bare pipe on either side of a leak, with no bellows intervening, it is possible to detect and locate a leak by cross-correlation analysis. Where manholes are separated 200 ft or more, it should be possible to detect steam leaks with sensors placed on the pipe outer wall if the leak is large (i.e., significant vapor is visible at one or both manholes).

5.4 Leak Location with an In-Stream Sensor

Transducers or transducer/waveguide systems placed directly on the steam pipe outer wall may not be effective enough to locate leaks in long runs of DH piping or in runs with bellows between sensors. One possibility

for circumventing the general problem of steam leak detection with externally mounted sensors is to insert an acoustic transducer inside the pipe to detect steam-propagated sound waves directly. The main purpose of the program being carried out at ANL in collaboration with NRG Thermal and Consolidated Edison is to develop an in-stream sensor for steam leak location.

We have carried out a brief evaluation of in-stream monitoring using a capacitance microphone to illustrate the potential for improvements in location capability. Cross-correlation analysis of signals from a gas leak in the ANL piping system suggests that in-stream monitors are more effective than sensors mounted on the pipe outer surface. The use of commercially available capacitance microphones or miniature hydrophones (e.g., Bruel and Kjaer model 8103) may not be viable for detection of steam-propagated sound because of the elevated temperature of the steam. Special high-temperature microphones (e.g., Endevco models 2510 or 8521-5M1) are designed for high-intensity applications (e.g., jet engine noise) and may not be sensitive enough for detection and location of steam leaks. The most promising sensor is one made of a piezoelectric material fixed in a tube about 1/2 in. in diameter and able to tolerate the elevated temperatures and pressures of a steam system. Such high-temperature microphones can be inserted without disturbing service, by means of a hot tap.

6 Conclusions

Several leak detection techniques are currently available for district heating and cooling systems. Application and effectiveness of each technique depend on the design and installation method of the DHC piping, location of the leak (in the jacket or the carrier pipe), system operating parameters, and knowledge of system layout and components. The most common systems used today are classified according to their principle of operation as follows: acoustic emission, infrared spectroscopy, tracer gas, and electrical.

While all of these techniques have been tried in one form or another, only acoustic leak detection has the potential for being the most effective for locating leaks. However, sensors placed directly on the pipe outer wall may not be effective enough for acoustical location of steam leaks in long runs of DHC piping. One way to circumvent the general problem of steam leak

detection in buried pipe is to insert an acoustic transducer inside the pipe to detect steam-propagated sound waves directly.

A survey was undertaken as part of a joint program between the U.S. Department of Energy and utilities involved with district heating and cooling. The purpose of the survey is to identify and characterize current practices for detecting and locating leaks in district heating systems; specifically steam systems. This information reflects district heating industry conditions, needs, and requirements and will assist ANL in the development of acoustic leak detection technology

Acknowledgments

The authors wish to thank M. Spurr for the survey data and W. Lawrence, R. Popper, and R. Carlson for their contributions to this project.

References

1. D. S. Kupperman and D. E. Karvelas, *Acoustic Leak Detection for District Heating Systems*, Argonne National Laboratory Report ANL-87-60 (Feb. 1988).
2. K. E. Cooper, C. Marsh, and E. G. Segan, *Evaluation of Techniques for Locating Leaks in Underground Heat Distribution Systems*, U.S. Army Corps of Engineers, Construction Engineering Research Laboratory Technical Report M-86/16 (Aug. 1986).
3. D. S. Kupperman, T. N. Claytor, T. Mathieson, and D. Prine, *Leak Detection Technology for Reactor Primary Systems*, Nucl. Safety, 28:191 (April-June 1987).
4. J. Reason, *Acoustic Leak Detection Provides Early Warning of Piping Failure*, Power, 63 (Sept. 1987).
5. J. E. Coulter, T. P. Sherlock, and D. M. Stevens, *Acoustic Emission Monitoring of Cracks in Fossil Fuel Boilers*, Electric Power Research Institute Report EPRI CS-5264 (July 1987).
6. J. G. Dimmick and J. M. Cobb, *Ultrasonic Detection Cuts Valve Maintenance Costs*, Power Eng. 35 (Aug. 1986).
7. D. O. Harris, R. G. Brown, D. Dedhis, and D. E. Leaver, *Acoustic Emission Leak Detection and Location Systems Technology Review*, Electric Power Research Institute Report EPRI NP-80-7-LD (Dec. 1980).
8. H. V. Fuchs, W. Frommhold, R. Poggemann, R. and P. Zenker, *Acoustic Leak Location on District Heating Pipes*, HLH, Heizung, Lüftung, Klimatechnik, Haustechnik, 42:1; Fraunhofer-Institut für Bauphysik, Stuttgart, and Energieversorgung Oberhausen AG, West Germany.
9. H. Schwarze, *Computer-aided Measuring System for Automatic Monitoring of Pipe Networks and Leak Detection*, Technisches Messen, 55(7-8): 279-285; Fachhochschule Bielfeld, Bielfeld, West Germany (1988).

10. H. J. Micheel, *Leakage Monitoring in Synthetic Jacket Pipes for District Heating Supply*, Fernwaerme International, 16(6): 380-385, Salzgitter Elektronik GmbH, Kiel, West Germany (Nov-Dec 1987).
11. D. B. Chang, B. M. Pierce and I. Shih, *Environmental Monitoring Technologies*, SAE Technical Paper Series 910190, International Congress and Exposition, Detroit, Feb. 25-March 1, 1991.
12. H. Turtiainen, *Leak Location in District Heating Networks Using Acoustical Correlation Techniques*, Valtion Teknillinen Tutkimuskeskus, Espoo, Finland (1982).
13. H. Gransell and J. Ljungquist, *In Situ Control of District Heating Networks*, Annual Conference of the Int'l District Heating Assoc., (1985).
14. A. Jette, M. Norman, S. Michael, J. C. Murphy, and J. G. Parker, *Active Acoustic Detection of Leaks in Underground Natural Gas Distribution Lines*, Materials Evaluation, 35(10): 90-96, 99 (Oct. 1977).
15. A. C. Eapen, R. L. Ajmera, S. M. Agashe, *Pipeline Leak Location Using Radiotracer Technique*, Bhabha Atomic Research Centre, Isotope Div., Bombay, India (1983).

Appendix A:

**Survey Form and Introductory Remarks for
Acoustic Leak Detection and Location**

Introduction to Survey

Argonne National Laboratory, under contract to the U.S. Department of Energy and several district heating utilities, is developing a system for detecting and locating district steam piping leaks using acoustic technology.

The objective of the project is to develop a highly accurate acoustic leak detection and location system so that excavation for repairs can be minimized. Based on previous work, it appears that for steam district heating an in-stream sensor, probably using a hot tap, will be required to achieve the desired accuracy (within several meters).

The system would involve the insertion of two transducers into the hot taps, without disrupting steam service. Transducers could be attached permanently, to be periodically monitored, or a pair of transducers, as part of a mobile unit, could be placed as needed at sites of interest. Signals from the transducers would be transmitted by wire or radio waves and would be processed by mobile computer equipment.

Argonne is now performing research necessary for development of a field-implementable prototype system. On behalf of Argonne, I'd like to talk with you about leak detection and location practices and experiences in your system so that the prototype system is developed with a full understanding of district heating industry needs and requirements.

LEAK DETECTION SURVEY

Name of System _____

Contact Name _____

Phone _____

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____

3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints _____
 Bellows _____
 Ball joint _____
 Exp. loop _____
 Other _____

5. Intervals between expansion devices _____ feet

6. Condensate return? _____ yes _____ no

7. Intervals between manholes _____ feet

8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____ Rollers Welds _____
 Flanges Expansion devices _____ External corrosion _____
 Other _____

2. How are leaks detected now?

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? _____ yes _____ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system? _____ yes _____ no

Appendix B:
Notes From Survey

LEAK DETECTION SURVEY

Name of System Alabama Power
 Contact Name Dale Damball
 Phone 205-226-1880

A. Distribution System

1. Year oldest pipe installed 1920 2. Miles of pipe 6
 → direct burial wood log
 3. Type of pipe installation 4. Expansion devices
 (concrete)
 Box conduit ✓ 1/2 Slip joints ✓
 Solid pour conduit _____ Bellows ✓ VARIATORS
 Tunnel _____ Ball joint _____
 Prefab conduit ✓ 1/2 (Ricwil) Exp. loop _____
 Direct Burial _____ Other _____
 Other _____

Concrete box conduit - 2-2 1/2' by 2-2 1/2'
 Welded steel pipe, on steel pedestal. Ca Silicate bonded
 to pipe. Terra-cotta half round on top.
 Corrugated slip expansion joint. Adco type.
 In Ricwil pipe - ATS slips.

3-4' deep.

5. Intervals between expansion devices 200 feet average
 6. Condensate return? _____ yes ✓ no
 7. Intervals between manholes 400 feet
 8. Temperature and pressure 366-370 F 150 psi (HP steam)
 Saturated _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other - Traps	<u>✓</u>		

Very few leaks in trams. Occasionally, leaks at
 exp. joints, especially corrugated ones.

Most of the leaks are at the threaded
~~trap~~ trap fittings.

2. How are leaks detected now?

Visible steam

3. How are leaks located?

*Usually at manhole (where all fittings are)
If not, feel street to locate. Dig for fittings
Tried a hand held sonic locator - No luck.*

4. What is the accuracy of your location methods?

*Works pretty well. Hit it on 1st try 75-80%
of time. Hit on 2nd hole 20-25% of time.*

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

*Hot tap introduces 2 more leak opportunities.
Leakage isn't that big a problem.*

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☒ no

8/13

LEAK DETECTION SURVEY

Name of System Baltimore Thermal
 Contact Name Brian Boor, Mgr. of Disinfection
 Phone 301-625-2222

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe 15
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit concrete ☒
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints ☒ (most)
 Bellows ☒
 Ball joint _____
 Exp. loop ☒
 Other _____

welded steel

5. Intervals between expansion devices ~200 feet
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes 225 feet *average*
 350 manholes 150 traps
 8. Temperature and pressure 375 F 160-180 psi (HP steam)
 270 F 20-35 psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other *Service T* ☒

Rollers ☒
 Flanges _____
 External corrosion _____

Leak problem to w/ LP system

2. How are leaks detected now?

Usually, a report of heat & vapor entering building.
Infrared thermometers didn't work well, especially when
there's a crack in conduit.

3. How are leaks located? Heath Acoustic system. Bought 4

years ago for ~ \$1000. 3-4" diameter receptor
placed on pavement. Move receptor 2-4" at a time.
Have a staff person who's good at this. Works pretty
well, but always looking to improve.

4. What is the accuracy of your location methods?

within 4-5'

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

Minimize labor cost.

4. Are you interested in:

- ☒ Ongoing system for monitoring, detection and location
☒ A system for use as necessary to locate leaks detected
through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

LEAK DETECTION SURVEY

Name of System Alabama Power
 Contact Name Dale Dambach
 Phone 205-226-1880

A. Distribution System

1. Year oldest pipe installed 1920 2. Miles of pipe 6
 3. Type of pipe installation direct burial wood log 4. Expansion devices

Box conduit (concrete) ✓ 1/2
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit ✓ 1/2 (Ricwil)
 Direct Burial _____
 Other _____

Slip joints ✓
 Bellows ✓ VARIATORS
 Ball joint _____
 Exp. loop _____
 Other _____

Concrete box conduit - 2-2 1/2' by 2-2 1/2'
 Welded steel pipe, on steel pedestals. Ca Silicate bonded
 to pipe. Terra-cotta half round on top.
 Corrugated slip expansion joint. Adco type.
 In Ricwil pipe - ATS slip.

3-4' deep.

5. Intervals between expansion devices 200 feet average
 6. Condensate return? _____ yes ✓ no
 7. Intervals between manholes 400 feet
 8. Temperature and pressure 366-370 F 150 psi (HP steam)
Saturated _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other - Traps	<u>✓</u>		

Very few leaks in trams. Occasionally, leaks at
 exp. joints, especially corrugated ones.

Most of the leaks are at the threaded
~~trap~~ trap fittings.

2. How are leaks detected now?

Visible steam

3. How are leaks located?

*Usually at manhole (where all fittings are)
If not, feel street to locate. Dig for fittings
Tried a hand held sonic decoder - No luck.*

4. What is the accuracy of your location methods?

*Works pretty well. Hit it on 1st dig 75-80%
of time. Hit on 2nd hole 20-25% of time.*

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

*Hot tap introduces 2 more leak opportunities.
Leakage isn't that big a problem.*

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☒ no

LEAK DETECTION SURVEY

Name of System Boston Thermal
 Contact Name Alan Murphy - U.P. of Operations
 Phone 617-482-9550

A. Distribution System

1. Year oldest pipe installed ^{most} 1930's 2. Miles of pipe 22
^{earliest 1900's}
 3. Type of pipe installation 4. Expansion devices
 (Concrete)
 Box conduit ✓ Slip joints _____
 Solid pour conduit ✓ Bellows ✓
 Tunnel _____ Ball joint _____
 Prefab conduit _____ Exp. loop _____
 Direct Burial _____ Other _____
 Other _____

Carbon Steel pipe 6-24"

~ 10' deep

1150 Bellows - direct burial

5. Intervals between expansion devices 75 feet
 6. Condensate return? _____ yes ✓ no
 7. Intervals between manholes 465 feet range
 250 man holes 180-190 at plant wall
 8. Temperature and pressure _____ F 120 psi (HP steam) to customer
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	<u>✓</u> (by far)	External corrosion	_____
Other	_____		

Loose about 4 bellows each year, plus several other leaks. Very few leaks in pipe itself.

2. How are leaks detected now? *Visible vapor. However, there is a high water table, so vapor doesn't always mean a leak. Have an acoustic device - tried for 2 years. Not very effective. Soil not sandy. Tried infra-red - not very effective*
3. How are leaks located?
*Use drawings, plus the above, to locate.
 For further info, call Matt Fuller - Manager of Distribution 617-269-3320*
4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no
2. If not, why not? *"perhaps"*
wouldn't want to do hot taps. Have isolation valves at each manhole, so can shut off section to well in tap.
3. What would increase this system's usefulness to you?
4. Are you interested in:
- a. Ongoing system for monitoring, detection and location
 - ☒ b. A system for use as necessary to locate leaks detected through other means
5. Would you be interested in field testing a prototype system?
☒ yes ☐ no
-

LEAK DETECTION SURVEY

Name of System Central Heat Distribution - Vancouver, B.C.Contact Name Jim Barnes, PresidentPhone 604-688-9584A. Distribution System1. Year oldest pipe installed 1969 2. Miles of pipe _____

3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial ✓ _____
 Other _____

Slip joints ✓ larger pipes
 Bellows ✓ smaller pipes
 Ball joint _____
 Exp. loop _____
 Other _____
located in vaults.

welded steel, with calcium silicate & fiberglass jacket.

5. Intervals between expansion devices _____ feet

6. Condensate return? ✓ yes _____ no

7. Intervals between manholes _____ feet

8. Temperature and pressure 350 F 185-190 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other _____

Rollers _____
 Flanges _____
 External corrosion _____

Leakage is not a problem. Getting no corrosion. Attribute this to good water treatment (amias) and making sure their pipes are located above the water utilize

2. How are leaks detected now?

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Leaks aren't a problem

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Cleveland Thermal
 Contact Name Rick Puck (Poo kack) - Dir. of Operations
 Phone 216-241-5980 ext. 130

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe 19
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit concrete ☒
 Solid pour conduit ☒
 Tunnel _____
 Prefab conduit ✓ Rivet - narrow pipe
 Direct Burial _____
 Other _____

welded steel

Slip joints ☒ HP
 Bellows ☒ "Variators"
 Ball joint _____
 Exp. loop _____
 Other _____

Also externally pressurized bellows. (new design for LP system)

5. Intervals between expansion devices 50' variators 200 feet EP bellows
300-700' Slips
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes ~100 feet and wherever there's a valve.
450 manholes
 8. Temperature and pressure 365 F 150 psi (HP steam)
260 F 20-22 psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	☒
Other	_____		

(90%)

LP system is the problem. HP OK.

2. How are leaks detected now?

Visible steam or hot pavement or hot wall.

Bought better Acoustic device (\$2000), Paul Lucas (241-5489) is train specialist on staff. Had to work with it to develop "good ear." Now works very well.

3. How are leaks located? *Sandy soils - sand transmits well. With clays it doesn't work. Didn't work in Boston - possibly due to soils. Must use 2-5 AM.*

4. What is the accuracy of your location methods?

90% accuracy

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Happy with current system.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☒ no

LEAK DETECTION SURVEY

Name of System Cogeneration Management Co.

Contact Name Don Yeaple

Phone 617-732-2700

A. Distribution System

1. Year oldest pipe installed 1976 2. Miles of pipe 1 1/2

3. Type of pipe installation

Box conduit _____
Solid pour conduit _____
Tunnel _____
Prefab conduit _____
Direct Burial _____
Other _____

Slip joints _____
Bellows _____
Ball joint _____
Exp. loop _____
Other _____

With pipe in tunnels, leaks are obvious.

All customers are hospitals. 900,000 lbs/hr steam cap.

Tri-gen plant 5 boilers. 2 are heat recovery
boilers (use diesel exhaust)

Chiller water 24,000 tons, 5 underlegal, 2 absorbers

5. Intervals between expansion devices feet

6. Condensate return? yes no

7. Intervals between manholes feet

8. Temperature and pressure _____ F 125 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

125 CW-Supply
80 CW-Return

1. What types/locations of leaks are your biggest problem?

Valves _____
Welds _____
Expansion devices _____
Other _____

Rollers _____
Flanges _____
External corrosion _____

2. How are leaks detected now?

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

8/16

LEAK DETECTION SURVEY

Name of System Concord Steam
 Contact Name Mark Saltzman - General Mgr
 Phone 603-224-1461

A. Distribution System

1. Year oldest pipe installed 1930's 2. Miles of pipe ~8
 3. Type of pipe installation 4. Expansion devices

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial ✓
 Other _____

Slip joints _____
 Bellows ✓ Hi-Span
 Ball joint _____
 Exp. loop _____
 Other _____

*Welded steel. "Wickalite" powdered pour insulation -
 hardens like concrete*

2-6' depth, 4' average.

Fairly sandy soil.

5. Intervals between expansion devices _____ feet *not sure*
 6. Condensate return? ✓ yes _____ no
 ↳ on one line
 7. Intervals between manholes _____ feet *no set spacing*
 8. Temperature and pressure 370 F 165 psi (HP steam)
 Saturated _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds ✓
 Expansion devices ✓
 Other _____

Rollers _____
 Flanges _____
 External corrosion _____

2. How are leaks detected now?

Visible steam or water in manhole, or hot spot on ground. Leak tends to run between pipe and insulation - runs out into manhole.

Leaks aren't a big problem.

3. How are leaks located?

Bob Young
- with Dept.
603-225-8693

With Dept. brings their acoustic device - works well. Heath Aquascope. Direct contact on pavement or on valves. Bought 10 years ago. Price now about \$2000. New filters to filter out background noise.

4. What is the accuracy of your location methods?

Good. Below

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

~~Heath~~ device not useful on plastic pipe (as is used in water utilities) and doesn't work well on soil (compared to pavement). Sometimes use a bar to contact the pipe.

cms\leaksurv

LEAK DETECTION SURVEY

Name of System Consolidated Edison
 Contact Name Tony Ladna
 Phone 212-576-2440

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
~~Prefab~~ ^{Pipe} conduit ✓
 Direct Burial _____
 Other _____

Slip joints (2)
 Bellows (1) primarily
 Ball joint a few
 Exp. loop (3)
 Other _____

→ Type of outer pipe varies

Before 1945 - flanged pipe. (~50% of total)
 After 1945 - welded steel. (~50% of total)

5. Intervals between expansion devices 30-200-400 feet ^{→ slip joints} Varies depending
 6. Condensate return? on subsurface conditions yes _____ no _____
 7. Intervals between manholes ~500 feet one per block
 8. Temperature and pressure _____ F 200 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other _____

Rollers _____
 Flanges ✓
 External corrosion _____

2. How are leaks detected now? - Visible steam
 - Hot pavement
 - Customer complaint
3. How are leaks located?
 1. Narrow location is between manholes
 2. Feel where hotter
 3. Check records re location of fittings
 4. (Sometimes) use bar-hole method. However, this is not always possible due to other utilities in the way. (Probably ~3% of system). Also, bar-holing is a safety concern.
4. What is the accuracy of your location methods?
 Not as good as he wants.
 Probably ~90%

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no
2. If not, why not? Concerned re need for hot tap. Dangerous & expensive. Bought hot tap equipment from T.O. Williams in Texas about 10 years ago. Generally used for 3-6" taps. Equipment is too large to fit in manhole. Perhaps there is smaller -
3. What would increase this system's usefulness to you?
 Minimize # of hot taps required. Best - no hot taps. Excavating for tap defects purpose. Tap introduces a new
4. Are you interested in: leak potential.
 a. Ongoing system for monitoring, detection and location
 b. A system for use as necessary to locate leaks detected through other means
5. Would you be interested in field testing a prototype system?
☒ yes ☐ no

→ equipment available now for small hot taps,

Figures about \$4000 per hot tap based on their

expenditure: excavation \$3000 + \$1000 labor for tap (2 men for 1 day at \$30/hour)

cms\leaksurvey

LEAK DETECTION SURVEY

Name of System Dayton Power & Light
 Contact Name Henry Rutzoba
 Phone 513-227 2481

A. Distribution System

1. Year oldest pipe installed 1902 2. Miles of pipe 15
 3. Type of pipe installation 4. Expansion devices
Box conduit	<u>✓</u> 10-15%	Slip joints	<u>✓</u>
Solid pour conduit	<u>✓</u> 60%	Bellows	<u> </u>
Tunnel	<u> </u>	Ball joint	<u> </u>
Prefab conduit	<u> </u>	Exp. loop	<u> </u>
Direct Burial	<u> </u>	Other	<u> </u>
Other work log	<u>✓</u> 25-30%		

Pipes 3-9' deep. Average 5 1/2'

5. Intervals between expansion devices 50-100 feet
 6. Condensate return? yes ✓ no
 7. Intervals between manholes 100 feet *average*
 8. Temperature and pressure
<u>338</u>	<u>100</u> psi	(MP steam)
<u>384</u> F	<u>190</u> psi	(HP steam)
<u>232</u> F	<u>7</u> psi	(LP steam) ← <i>most service</i>
<u> </u> F	<u> </u> psi	(hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	<u> </u>	Rollers	<u> </u>
Welds	<u> </u>	Flanges	<u> </u>
Expansion devices	<u> </u>	External corrosion	<u>✓</u>
Other	<u> </u>		

When a LP line crosses another utility - increases leak potential.

Have a 4-man crew whose full-time job is locating & fixing leaks

2. How are leaks detected now?

Regular inspection, visible steam.

3. How are leaks located?

*Generally, use infra-red gun (bought 5-6 years ago)
Sometimes use a temp. probe.*

Also, on rainy day, can see dry spot.

See additional information in Appendix.

4. What is the accuracy of your location methods?

Fairly good

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Satisfied with current approach

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Detroit Edison
 Contact Name Terry Schumier
 Phone 313-237 5290

A. Distribution System

1. Year oldest pipe installed 1905 2. Miles of pipe 50
 3. Type of pipe installation 4. Expansion devices

older
newer

Box conduit	<u>✓</u>
Solid pour conduit	<u>✓</u>
Tunnel	<u> </u>
Prefab conduit	<u> </u>
Direct Burial	<u> </u>
Other	<u> </u>

Slip joints	<u>✓</u> (in manholes)
Bellows	<u> </u>
Ball joint	<u> </u>
Exp. loop	<u>✓</u>
Other	<u> </u>

→ corrugated steel w/ concrete on top

8-10' generally

5. Intervals between expansion devices 400-500 feet generally
 6. Condensate return? yes ✓ no except about 5 miles of tunnel
 7. Intervals between manholes 400-500 feet average
 8. Temperature and pressure 338-352 F 100-125 psi (HP steam)
 Saturated 287-298 F 40-50 psi (LP steam)
 F psi (hot water)
 210 psi (from Resource Recovery Plant)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	<u> </u>
Welds	<u> </u>
Expansion devices	<u>✓</u>
Other	<u> </u>

Rollers	<u> </u>
Flanges	<u>✓</u>
External corrosion	<u>✓</u> (worst)

Fix about 40 leaks / year.

Spend \$10-15K per excavation

⊗ Spend about \$1 million / year on leaks.

2. How are leaks detected now? *Visible steam*

3. How are leaks located?

Sonic locator. Drill hole in pavement. Put probe down to top of concrete conduit. Grey foot or so.

4. What is the accuracy of your location methods?

Hit or miss

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

Cost-effective, quick hot tap service. Would have this out. They staff won't do them.

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- ☒ b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

LEAK DETECTION SURVEY

Name of System District Energy, St. Paul Inc.
Contact Name Ray Schmidt, Distribution Superintendent
Phone 612-292-8955

A. Distribution System

1. Year oldest pipe installed 1983 2. Miles of pipe 20
3. Type of pipe installation 4. Expansion devices

Box conduit _____
Solid pour conduit _____
Tunnel _____
Prefab conduit _____
Direct Burial _____
Other _____

Slip joints _____
Bellows ☒ _____
Ball joint _____
Exp. loop ☒ _____
Other _____

2-4' depth

5. Intervals between expansion devices _____ feet *varies*
6. Condensate return? _____ yes _____ no
7. Intervals between manholes ~ 350 feet *varies*

8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
 peak winter 250 → 160 F 180 → 150 psi (hot water)

B. Current Leak Detection

Supply $\Rightarrow$ demand

1. What types/locations of leaks are your biggest problem?

Valves	_____
Welds	_____
Expansion devices	_____
Other	_____

Rollers _____
Flanges _____
External corrosion _____

No. 6280

2. How are leaks detected now?

*In-line alarm wires - see attached chapter
from final design report. (in Appendix)*

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Existing system adequate - no leaks to date.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Energy Networks Inc. - Hartford
 Contact Name Jeff Lindberg, Manager of Operations
 Phone 203-727-3045

A. Distribution System

1. Year oldest pipe installed 1962

3. Type of pipe installation

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit ✓ hot water
 Direct Burial _____
 Other _____

2. Miles of pipe 3.5-4.0 miles
 4. Expansion devices 6-8 miles chilled water

Slip joints ✓ in manholes
 Bellows ✓ direct bury
 Ball joint ✓ (A.P.S.)
 Exp. loop ✓ hot water &
 Other Never steam

Steam is pipe within pipe w/ annular space.

Some of the chilled water & steam pipe is
 30 years old.

2-8' deep, 3-4' average.

5. Intervals between expansion devices 100 feet6. Condensate return? _____ yes ✓ no7. Intervals between manholes 500-1000 feet

8. Temperature and pressure _____ F 125-150 psi (HP steam)
 _____ F _____ psi (LP steam)
150-250 F 30 psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves ② _____ Rollers _____
 Welds ④ _____ Flanges _____
 Expansion devices ① slip joints External corrosion _____
 Other Drip legs ③ _____

No major leaks in 10 years.

2. How are leaks detected now?

Steam - visible steam

Hot water - built with in-line system. Not activated, due to improper installation. Connection between wires is critical. No leak problem in hot water or chilled water lines.

3. How are leaks located?

Steam pipe leak location is a problem.

Have tried infra-red gun, but accuracy is not good.

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not? Although leaks are a big problem.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no if they had leaks to deal with.

8/13

77

LEAK DETECTION SURVEY

Name of System Energy Systems Company - Omaha
 Contact Name Dave Woods
 Phone 402-346-9066

A. Distribution System

1. Year oldest pipe installed 1967 2. Miles of pipe _____
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit ✓ Concrete
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints ✓ ATS
 Bellows ✓ replacing w/
 Ball joint _____ ATS
 Exp. loop _____
 Other _____

Steam pipe welded A53 Grade B seamless ~~steel~~ steel pipe. Some flanges
 Rock wool and perlite insulation w/ Fiberglass over top.

Condensate 304 stainless steel. Lots of stress cracks & corrosion.
 pipe:

Drain pipe installed in conduit. 3/8" diameter.

5. Intervals between expansion devices _____ feet
 6. Condensate return? ✓ yes _____ no
 7. Intervals between manholes 200-300 feet

8. Temperature and pressure 400 F 125 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

also chilled water

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	<u>✓</u>	External corrosion	_____
Other	<u>✓</u> (Condensate pipe)		

Have not had a steam pipe leak except in manholes.
 But have had leaks in condensate line. Generally, put in a whole
 new sleeve inside the existing condensate pipe.
 Have a chilled water system - but is not a leak problem.

2. How are leaks detected now?

- Water in manholes
- vapor in manholes once water hits bottom of steam pipe

3. How are leaks located? As noted above, usually just replace whole section of condensate line, so location (precise) is not important. If precise location is needed, they shut down section of pipe, insert electronic probe into drainage pipe. When steam again enters pipe and condensate begins leaking, contractors close upon.

4. What is the accuracy of your location methods? Encountering water.

Fairly good, when necessary. Usually not needed.

C. Use of Acoustic System

Due to sleeving of whole section.

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not? Leaks really aren't a problem. If new condensate lines begin to leak, he feels that existing acoustic technology will work well.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☒ no

cms\leaksurv

LEAK DETECTION SURVEY

Name of System Eugene Water & Electric Board
 Contact Name Dennis Duggan
 Phone 503-484-2411

A. Distribution System

1. Year oldest pipe installed 1911 2. Miles of pipe 8.5
 3. Type of pipe installation 4. Expansion devices

Box conduit ✓
 Solid pour conduit ✓
 Tunnel ✓
 Prefab conduit ✓
 Direct Burial ✓
 Other ✓
 (Above ground)

Slip joints ✓
 Bellows ✓
 Ball joint ✓
 Exp. loop ✓
 Other ✓

350-400 million lbs/year sales

Pipes 2-15' deep

5. Intervals between expansion devices 500-1000 feet
 6. Condensate return? ✓ yes no For 20% of system
(one big customer)
 7. Intervals between manholes 300-400 feet
1/2 block
 8. Temperature and pressure 500 F 250 psi (HP steam)
360 F 15 psi (LP steam)
 F psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	<u>✓</u>	Rollers	<u> </u>
Welds	<u>✓</u>	Flanges	<u> </u>
Expansion devices	<u> </u>	External corrosion	<u> </u>
Other fittings	<u>✓</u>		
Condensate line	<u>✓</u>		

Condensate line vacuum system is overworked
 due to leaks.

No particular difference in leak frequency LP vs. HP.

2. How are leaks detected now?

- Can't maintain vacuum on condensate line
- In conduit installations, put pressure on condensate line, then leak runs into manholes

3. How are leaks located?

- Tried "Geophones" from water utility ("stethoscope on pavement") unsuccessfully.
- For steam leaks, feel pavement or watch for steam in vac
- Have IR sensor which works well except in conduit installa

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

- Haven't had leaks in 2 years
- Borrowed Seattle's equipment - made by Dr. Michael - worked very well, and plans to buy one.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

2. How are leaks detected now?

Hot water - make up water requirements
Steam - visible steam or snow melt.

3. How are leaks located?

Snow melt / ground heat

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Leakage aren't a big problem.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Georgia Power
 Contact Name Robert Schmitt - Distrib. Superintendent
 Phone 404-526-4678

A. Distribution System

1. Year oldest pipe installed 1907 2. Miles of pipe 25-30
 3. Type of pipe installation 4. Expansion devices

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab ^{metal} conduit ✓ _____
 Direct Burial _____
 Other _____

Slip joints ✓
 Bellows ✓
 Ball joint _____
 Exp. loop _____
 Other _____

Schedule 80 steel - welded.

5. Intervals between expansion devices 100 + feet
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes _____ feet Usually wherever there's a joint. No set interval.
 8. Temperature and pressure 330 F 90 psi (HP steam)
 240 F 10 psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other _____

Rollers _____
 Flanges _____
 External corrosion _____

No particular pattern

2. How are leaks detected now?

Vapor in manhole.

3. How are leaks located?

Dig!

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? yes ✓ no

2. If not, why not?

"Based on experience, nothing works."

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

 yes ✓ no

LEAK DETECTION SURVEY

Name of System Harrisburg Steam Works

Contact Name Jan Sorkel

Phone 717-234-4600

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____

3. Type of pipe installation 4. Expansion devices

Box conduit	_____
Solid pour conduit	_____
Tunnel	_____
Prefab conduit	_____
Direct Burial	_____
Other	_____

Slip joints _____
Bellows ☒ _____
Ball joint _____
Exp. loop _____
Other _____

Mostly welded steel (A53 or 106) in a split & 2
Some direct bury.

3-10' depth

5. Intervals between expansion devices ¹⁰⁰⁻²⁰⁰ feet

6. Condensate return? yes no

7. Intervals between manholes 200 feet

about 65% of system is reduced to 30 psi

8. Temperature and pressure _____ F 150 psi (HP steam) *out of plant*
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
Welds _____
Expansion devices (1)
Other _____

Rollers _____
Flanges _____
External corrosion (2)

2. How are leaks detected now? Vibration measuring device invented by Dr. Paul Michael of Penn State Univ. (814-238-8533). He sells it mostly to Water Depts. Harrisburg bought one 3 years ago for ~ \$3000. Jim Copen is their technician who works with the device. Works great but needs a quiet background. (use in middle of night). Steel tripod - sets on pavement.
3. How are leaks located?
4. What is the accuracy of your location methods? *Good.*

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no
2. If not, why not?
3. What would increase this system's usefulness to you?
4. Are you interested in:
- a. Ongoing system for monitoring, detection and location
 - b. A system for use as necessary to locate leaks detected through other means
5. Would you be interested in field testing a prototype system?
- ☐ yes ☐ no
-

LEAK DETECTION SURVEY

Name of System Indianapolis Power & Light
 Contact Name Fred Brasden, Supervisor of Steam Distribution
 Phone 317-261-8854

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit	_____	Slip joints	<u>✓</u>
Solid pour conduit	<u>✓</u> (most) Since 1962	Bellows	_____
Tunnel	_____	Ball joint	_____
Prefab conduit	_____	Exp. loop	_____
Direct Burial	_____	Other	_____
Other	_____		

2-10' depth. Solid pipe

5. Intervals between expansion devices 100-300 feet usually in manholes
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes 100-300 feet
 800 manholes in system
 8. Temperature and pressure 400 F 250 psi (HP steam)
 270-250 F 10-15 psi (LP steam)
 _____ F _____ psi (hot water)
 400 psi HP steam - Super heater

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	<u>✓</u>
Other	_____		

Almost all in LP lines

Spend \$1.25 million for leak detection & repair.

2. How are leaks detected now?

Visible steam

3. How are leaks located?

*Isolate between manholes. Locate by feeling pavement.
Tried Hatz acoustic system 3-4 years ago - didn't work.*

4. What is the accuracy of your location methods?

"Pretty good."

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. ~~If not, why not?~~ *Hot taps no problem w/ LP lines, because not much room is needed. Need lots of room to do tap on HP system.*

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

A. Distribution System

- Slip joints _____
Bellows _____
Ball joint _____
Exp. loop _____
Other _____

5. Intervals between expansion devices _____ feet

6. Condensate return? _____ yes _____ no

7. Intervals between manholes _____ feet

8. Temperature and pressure _____ F _____ psi (HP steam)
_____ F _____ psi (LP steam)
160-250 F 100-140 psi (hot water)

Valves	_____
Welds	_____
Expansion devices	_____
Other	_____

Rollers _____
Flanges _____
External corrosion _____

2. How are leaks detected now?

Tin Wire in conduit shows moisture. Wire surrounded by felt.
 Sometimes indicate leak when it is just an air leak.
 Confirmed w/ make-up water.
 Not much leak activity. Not entirely happy w/
 leak detection system.

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Kent County Dept. of Public Works
 Contact Name B.H. Olsen
 Phone 616-774-3694

A. Distribution System

1. Year oldest pipe installed 1920's 2. Miles of pipe 1 1/2

3. Type of pipe installation

4. Expansion devices

Brick or block Box conduit ✓
 Solid pour conduit
 Tunnel
 Prefab conduit ✓
 Direct Burial ✓
 Other

Slip joints ✓
 Bellows
 Ball joint
 Exp. loop
 Other

Mostly steel. Some old cast iron.

Asbestos insulation. Some of the expansion devices are direct bury.

5. Intervals between expansion devices 300-600 feet varies

6. Condensate return? yes ✓ no

7. Intervals between manholes 500-600 feet varies

18 manholes

8. Temperature and pressure 352-366 F 125-150 psi (HP steam)
227-250 F 5-15 psi (LP steam)
 F psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves
 Welds
 Expansion devices
 Other

Rollers
 Flanges
 External corrosion ✓

Portions of LP system shut down during summer.
 City water dept. leaks lead to steam pipe leaks.

2. How are leaks detected now?

- Complaints
- Infra-Red
- Tap & Line Maintenance
- Fuel/Gas ratio

3. How are leaks located?

Steam will follow conduit - exits away from leak.

Trick acoustic listening from Water Dept. - didn't work
 Do infra-red once a year. Pretty good success, although blurring
 can be a problem. Good broad brush inventory. More exact
 \$700-800/survey.

4. What is the accuracy of your location methods? location based on
feeling pavement & review of drawings.C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ✓ yes no

2. If not, why not?

Quick service restoration is key.

At the same time, not excited about hot taps.

3. What would increase this system's usefulness to you?

No hot tap

4. Are you interested in:

- if cost effective this is preferable
- a. Ongoing system for monitoring, detection and location
 - b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

✓ yes no

LEAK DETECTION SURVEY

Name of System Minneapolis Energy Center
 Contact Name Gary Gustafson
 Phone 612-349-6072

A. Distribution System

1. Year oldest pipe installed _____	2. Miles of pipe _____
3. Type of pipe installation	4. Expansion devices
Box conduit _____	Slip joints _____
Solid pour conduit _____	Bellows _____
Tunnel <u>✓</u>	Ball joint <u>✓</u>
Prefab conduit <u>✓</u>	Exp. loop <u>✓</u>
Direct Burial _____	Other _____
Other _____	

Welded steel for steam & chilled water.

5. Intervals between expansion devices 300-400 feet
6. Condensate return? ✓ yes _____ no
7. Intervals between manholes 300-400 feet *Sometimes on both sides of intersection*
8. Temperature and pressure 406 F 250 psi (HP steam)
365 F 150 psi (LP steam) → 1/4 - 1/3 of system
 _____ F _____ psi (hot water) *system*
- B. Current Leak Detection *"Baker Block"*

1. What types/locations of leaks are your biggest problem?

Valves <u>✓</u>	Rollers _____
Welds _____	Flanges _____
Expansion devices <u>✓</u> <i>Ball joints</i>	External corrosion _____
Other (condensate) <u>✓</u>	

Not much of a problem. Usually condensate line

2. How are leaks detected now?

Visible steam

3. How are leaks located?

*Dig, based on situation.
Only 2-3 times.*

4. What is the accuracy of your location methods? *OK, not much experience.*

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no
 2. If not, why not? *if cost-effective*
Feels hot tap could be done in
manhole if hole is small.
 3. What would increase this system's usefulness to you?
Be able to hire a contractor who owns
the equipment - rather than buy it.
 4. Are you interested in:
 - a. Ongoing system for monitoring, detection and location
 - b. A system for use as necessary to locate leaks detected through other means
 5. Would you be interested in field testing a prototype system?
☒ yes ☐ no
-

LEAK DETECTION SURVEY

Name of System Learning Board of Water & Light
 Contact Name Joette Woodward-Yank
 Phone 517-371-6780

A. Distribution System

1. Year oldest pipe installed 1908 2. Miles of pipe _____
 3. Type of pipe installation 4. Expansion devices

Box conduit ✓ (most)
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial ✓
 Other _____

Slip joints ✓
 Bellows _____
 Ball joint ✓ (one 18"
 Exp. loop transmission
 Other _____ line)

Mostly welded carbon steel. Original pipes are
 "Universal pipes" - flanged to deflect slightly.
 Also Duplex pipes - HP pipe inside LP pipe. (~1424)
 Replacing Duplex and Universal pipe.

5. Intervals between expansion devices 400 feet most commonly
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes 200-300 feet
 8. Temperature and pressure 410 F 265 psi (HP steam)
 325 F 80 psi (LP steam)
 225-250 F 5-15 psi (hot water)
 LP steam

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices ✓
 Other _____

Rollers ✓
 Flanges ✓
 External corrosion _____

2. How are leaks detected now?

Visible steam

3. How are leaks located?

*Have used for ~ 1 year.
Hand-held thermal meter - held wasn't high.
Good success in many locations. In other locations,
didn't work well (due to varying depths,
other utilities).*

4. What is the accuracy of your location methods?

Sometimes good, sometimes need to dig 3 holes.

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not? *Although other problems are currently more pressing than leaks. Solve these 1st.
Concern with corrosion potential at hot tap.*

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
☒ A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

LEAK DETECTION SURVEY

Name of System Mid-America Energy Resources

Contact Name David Kiesel, Project Engineer,

Phone 317-261-8893

A. Distribution System

1. Year oldest pipe installed 1990 2. Miles of pipe

3. Type of pipe installation

Box conduit	_____
Solid pour conduit.	_____
Tunnel	_____
Prefab conduit	_____
Direct Burial	_____
Other	_____

Slip joints _____
Bellows _____
Ball joint _____
Exp. loop _____
Other _____

Chilled water system. Ductile iron pipe,
uninsulated. No built-in leak detection.
No leaks to date.

5. Intervals between expansion devices feet

6. Condensate return? yes no

7. Intervals between manholes feet

8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
Welds _____
Expansion devices _____
Other _____

Rollers _____
Flanges _____
External corrosion _____

2. How are leaks detected now?

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Nashville ThermalContact Name Roger BeckhamPhone 615-244-3150Serve 37 bldgs with
steam & ~~hot water~~
chilled water

A. Distribution System

1. Year oldest pipe installed 1974 2. Miles of pipe
1986 - big expansion (pipe in tunnel)
3. Type of pipe installation 4. Expansion devices

Box conduit
 Solid pour conduit
 Tunnel ✓ (25-35%) - newer parts
 Prefab conduit
 Direct Burial ✓
 Other

Slip joints ✓
 Bellows
 Ball joint
 Exp. loop
 Other

welded steel - steam

Ductile iron w/ flanges - chilled water

In limestone rock (tunnels)

13,000 tons peak cooling
 22 - 150 mibs flow peak heat
 4 chillers - steam turbine
 drive. Waste to Energy

5. Intervals between expansion devices 200 feet → all in manhole
 or tunnel
6. Condensate return? ✓ yes no
7. Intervals between manholes 200 feet
8. Temperature and pressure 365 F 150 psi (HP steam)
 F psi (LP steam)
 F psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves
 Welds
 Expansion devices
 Other Condensate ✓

Rollers
 Flanges
 External corrosion ✓

→ steam & condensate

2. How are leaks detected now?

Annual thermographic surveys.

3. How are leaks located?

In tunnel - no problem.

Thermographic photos pretty good.

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Happens with existing methods.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

8/13/91

LEAK DETECTION SURVEY

Name of System Pacific Energy Co./Central Plants Inc.
 Contact Name Vic Dilloway
 Phone 213-725-1139

A. Distribution System

1. Year oldest pipe installed _____	2. Miles of pipe _____
3. Type of pipe installation	4. Expansion devices
Box conduit _____	Slip joints _____
Solid pour conduit _____	Bellows _____
Tunnel _____	Ball joint _____
Prefab conduit _____	Exp. loop _____
Direct Burial _____	Other _____
Other _____	

*Welded carbon steel chilled water pipes
 Asbestos covered steam pipes
 Steel hot water pipes*

5. Intervals between expansion devices _____ feet
6. Condensate return? _____ yes _____ no
7. Intervals between manholes _____ feet
8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
375 F 230-250 psi (hot water)

B. Current Leak Detection

*Also chilled water
 and a little steam service*

1. What types/locations of leaks are your biggest problem?

Valves _____	Rollers _____
Welds _____	Flanges _____
Expansion devices <u>✓</u>	External corrosion <u>✓</u>
Other _____	

2. How are leaks detected now?

- Visible steam
- Make-up water
- damage to surrounding vegetation

3. How are leaks located? 6-10 gpm detection threshold.

"Start digging"! "Been lucky so far."

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system? *Initially. Perhaps a. if cost-effective*

☒ yes ☐ no

8/16/91

LEAK DETECTION SURVEY

Name of System NRG Thermal - Waldorf line
 Contact Name Mark Brindley - ES
 Phone 612-373-5235

A. Distribution System

1. Year oldest pipe installed 1983 2. Miles of pipe 5 1/2
 3. Type of pipe installation 5' line buried 4. Expansion devices
 Box conduit (concrete) 90% of line (steam) Slip joints ✓ (steam)
 Solid pour conduit _____ Bellows ✓ (condensate)
 Tunnel _____ Ball joint _____
 Prefab conduit ✓ condensate Exp. loop _____
 Direct Burial _____ Other _____
 Other _____

Condensate line is the leak problem. PVC conduit
 w/ polyurethane foam.
 Foam glass on steam line.
 8' average depth.

5. Intervals between expansion devices 300 feet Anchor to slip
 6. Condensate return? ✓ yes _____ no
 7. Intervals between manholes 600 feet
 8. Temperature and pressure _____ F 800 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)
 B. Current Leak Detection 235 150 (condensate)

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other Condensate	<u>✓</u>		

Usually near an anchor or vault.

2. How are leaks detected now? *Discrepancy between meters of flow into & out of the pipe.*

Thermal video doesn't work for them.

3. How are leaks located? *Look for vapor out of vault.*
If nothing at vaults, look at ground - water bubbling out.

4. What is the accuracy of your location methods?

Not as good as test like. Very expensive shoring up (next to train tracks) when doing excavation. Could be \$25K/line.

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☐ no

2. If not, why not?

Perhaps an alternative system needs to be set up for condensation applications

3. What would increase this system's usefulness to you?

would want to apply to condensation conditions

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
 b. ☒ A system for use as necessary to locate leaks detected through other means

has put in a few permanent transducers at trouble spots.

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

test steps 1/4 - 1/2" not well, not well, expensive (maybe \$1000). Can do in vaults.

LEAK DETECTION SURVEY

Name of System Philadelphia Thermal
 Contact Name Steve Smith - General Mgr.
 Phone 215-875-6911

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____

3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab ^{Pipe} Conduit ✓
 Direct Burial ✓
 Other _____

Slip joints _____
 Bellows _____
 Ball joint _____
 Exp. loop _____
 Other _____

5. Intervals between expansion devices _____ feet

6. Condensate return? _____ yes _____ no

7. Intervals between manholes _____ feet

8. Temperature and pressure 365 150
395 F 225 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other _____

Rollers _____
 Flanges _____
 External corrosion _____

Leaks aren't much of a problem.

2 leaks in 3 years

1. Bad weld

2. Major line rupture

*external corrosion
 on pipe legs cold
 10 years*

2. How are leaks detected now?

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Leaks not a significant problem.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

_____ yes _____ no

LEAK DETECTION SURVEY

Name of System Pacific Gas & Electric - San Francisco
 Contact Name Rich Mayer - Manager
 Phone 415-973-3828

A. Distribution System

1. Year oldest pipe installed 1911 2. Miles of pipe 11 of main
 3. Type of pipe installation 4. Expansion devices

Box conduit _____
 Solid pour conduit ☒ _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints _____
 Bellows ☒ _____
 Ball joint _____
 Exp. loop _____
 Other _____

Combination of 5 original systems.

Older pipe has 1" annular space around pipe.

Generally welded steel. A few screwed fittings.

Traps and valves in manholes.

5. Intervals between expansion devices _____ feet *Varies*
 6. Condensate return? _____ yes ☒ no
 7. Intervals between manholes _____ feet *Varies.*
 8. Temperature and pressure 350 F 125 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other	_____		

Max. 8-10 leaks/year that require excavation to repair. For a while there was no water treatment. As a result, there is a groove in the bottom of the pipe.

2. How are leaks detected now?

- Patrol system
 - Visit customers
 - Complaints from other utilities
- Tried infra red - hasn't worked well.

3. How are leaks located? Use an acoustic system (can't remember name - might be Heath). A problem if there is a lot of background noise. Otherwise, works well.

4. What is the accuracy of your location methods?

Pretty good.

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Don't want to do hot taps.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Pittsburgh (PACT, Ltd)
 Contact Name Bob Szabo
 Phone 412-642-7445

A. Distribution System

1. Year oldest pipe installed 1920's 2. Miles of pipe ~7

3. Type of pipe installation 4. Expansion devices

Box conduit ✓
 Solid pour conduit ✓
 Tunnel 7' high, 5' wide ✓ large portion
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints ✓ATS
 Bellows ✓
 Ball joint _____
 Exp. loop _____
 Other _____

Welded steel

5. Intervals between expansion devices _____ feet *varies*

6. Condensate return? ✓ yes _____ no

7. Intervals between manholes _____ feet *varies*

8. Temperature and pressure _____ F 150 psi (HP steam)
plant 150 psi sdr. _____ F _____ psi (LP steam)
_____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices ✓
 Other _____

Rollers _____
 Flanges _____
 External corrosion _____
 Drips ✓

→ speaking with shop most leaks

Condensate ②

Solid pour conduit - difficult to repair.

2. How are leaks detected now? *In tunnels - easy (visual).
Otherwise, water/steam in vault.*

3. How are leaks located?

*- Feel pavement.
- Vapor escaping thru street.*

4. What is the accuracy of your location methods?

Generally good results

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not? *depends on cost.*

Concern re doing hot tap, especially in confined space.

3. What would increase this system's usefulness to you?

4. Are you interested in:

a. Ongoing system for monitoring, detection and location
☒ b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no *Depends on the circumstances,*

costs, trouble

8/16/91

LEAK DETECTION SURVEY

Name of System Pittsburgh Thermal
 Contact Name Jim Cummings - Gen. Mgr.
 Phone 412-234 0409

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe 1
 3. Type of pipe installation _____ 4. Expansion devices _____

Box conduit _____
 Solid pour conduit ✓
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints _____
 Bellows ✓
 Ball joint _____
 Exp. loop _____
 Other _____

*Welded steel steam & condensate pipe in solid pour.
 Also have chilled water service.*

5. Intervals between expansion devices 100-150 feet
 6. Condensate return? ✓ yes _____ no
 7. Intervals between manholes 100-150 feet

8. Temperature and pressure 406 F 230 psi (HP steam)
 Saturated _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection 150-160 15-20 (condensate)

1. What types/locations of leaks are your biggest problem?

Valves ③
 Welds _____
 Expansion devices _____
 Other *Condensate* ①

Rollers _____
 Flanges ②
 External corrosion _____

2. How are leaks detected now?

- Visible steam or condensate in venthole
- Complaint

Condensate line is the problem.

3. How are leaks located? *Tried acoustic contractor several times, without much success. Can't remember name of company or type of equipment. Generally, start digging, based on as-built drawings.*

4. What is the accuracy of your location methods?

Not very good

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

Oriented to condensate line conditions.

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- ☒ b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

LEAK DETECTION SURVEY

Name of System Public Service Co. of Colorado (Denver)
Contact Name Dennis Elliot - Thermal Operations Supervisor
Phone 303-573-4342

A. Distribution System

1. Year oldest pipe installed 1900's 2. Miles of pipe 11
3. Type of pipe installation 4. Expansion devices

Box conduit	
Solid pour conduit	
Tunnel	
Prefab conduit	V Riser
Direct Burial	
Other	

Slip joints ✓ ATS - mast
Bellows ✓ Ext. Pressure
Ball joint _____
Exp. loop _____
Other _____

welded steel

A1) valves, joints are in vanes

5. Intervals between expansion devices feet *not sure*
6. Condensate return? yes ✓ no
7. Intervals between manholes 200-250 feet *500' / block 2 vaults / block
1 trap per block*
8. Temperature and pressure 350 F 125 psi (HP steam)
260-270 F 20-30 psi (LP steam)
F psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	1
Welds	1
Expansion devices	
Other	

Rollers _____
Flanges _____
External corrosion _____

Not many leaks that are unlocated..

~~Maybe~~ Maybe 2-3 / summary.

2. How are leaks detected now?

Use Thermography w/ mixed results.
 Recently hired a local company who has a very
 sensitive ~~new~~ infrared camera - seems to be promising.

3. How are leaks located?

Narrow down to between 2 vaults.
 Check records; dig.

4. What is the accuracy of your location methods?

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? yes ✓ no

2. If not, why not?

Maybe - depends on cost and
 necessity of hot tap

Won't do hot taps

3. What would increase this system's usefulness to you?

- Find a way to introduce transducer at traps.

- Cost is an issue - would rather ~~hire~~ hire contractor
 who owns equipment.

4. Are you interested in:

- Ongoing system for monitoring, detection and location
- A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

 ✓ yes no

LEAK DETECTION SURVEY

Name of System Rochester District Heating Cooperative
 Contact Name Howard Lane
 Phone 716-546-8890

A. Distribution System

- 1880's - oldest possible
 1. Year oldest pipe installed 1960's 2. Miles of pipe 9
 3. Type of pipe installation ↳ most of pipe 4. Expansion devices

Box conduit concrete ☒
 Solid pour conduit ☐
 Tunnel ☐
 Prefab conduit ☐
 Direct Burial ☐
 Other ☐

Slip joints ☒
 Bellows ☐
 Ball joint ☐
 Exp. loop ☒
 Other ☐

Information from R & E.

Welded steel pipe

47 exp. joints

260,000 lbs sold
 last year

5. Intervals between expansion devices feet Varies
 6. Condensate return? yes ☒ no
 7. Intervals between manholes feet 86 manholes
↳ leaves boiler
 8. Temperature and pressure 554 F 200 psi (HP steam)
 F psi (LP steam)
 F psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves ☐
 Welds ☐
 Expansion devices ☐
 Other ☐

Rollers ☐
 Flanges ☐
 External corrosion ☐

Fairly tight system. Few leaks.

One at a weld and another at thrust block. (6 years)

Traps are a bigger problem.

2. How are leaks detected now?

Visible steam.

Do infrared (trick w/ telescoping boom)
every year. Not great from engineering
viewpoint but great from PR & insurance
stand point.

3. How are leaks located?

Infrared has been some help. Do some digging.
Not hard to find HP steam leaks. (\$3000/leak)

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Leak is a big problem. Also, don't want
hot taps

Except to prove that
vapor is not internal steam
escape.

3. What would increase this system's usefulness to you?

Due to external
water boiling,
off the steam
pipes.

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Seattle Sealm
Contact Name "Woody" (Bill) Woodard - Mgr. Distribution & Customer Service
Phone 206-623-6366

A. Distribution System

1. Year oldest pipe installed 1890's 2. Miles of pipe 18.5
3. Type of pipe installation 4. Expansion devices

Box conduit _____
Solid pour conduit ☒ _____
Tunnel _____
Prefab conduit _____
Direct Burial ☒ _____
Other _____

Slip joints _____
Bellows ✓
Ball joint _____
Exp. loop _____
Other _____

LP - mag blocks w/ redwood or cedar log
- lower - from glass or 2 - into

Black Gift —

46' depth

60' variations on LP system

5. Intervals between expansion devices _____ feet
6. Condensate return? _____ yes _____ no
7. Intervals between manholes 20-350 feet every block
8. Temperature and pressure _____ F 140 psi (HP steam)
_____ F 15-20 psi (LP steam)
_____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
Welds _____
Expansion devices _____
Other _____

Rollers _____
Flanges _____
External corrosion ☒ LP

Acoustic - Paul Michael system (like Harris bug)

Bought 3 months ago - works great.

\$2600

118

2. How are leaks detected now?

Sensor on pavement.

Limitations - tricky w/ conduit,
he suspects. Works great
w/ direct buried pipe.

Many different types
of soils.

3. How are leaks located?

4. What is the accuracy of your location methods?

Have not missed yet.

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Happy w/ current system.

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System St. Louis Thermal
(Stans' zee)
Contact Name Art Stanze - Director of Operations
Phone 314-621-3550

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe _____
3. Type of pipe installation _____ 4. Expansion devices _____

Old	Box conduit	☒	Masonry w/ concrete	Slip joints	☒ (most)
	Solid pour conduit	☐	Slab on top m	Bellows	☒ (a few)
	Tunnel	☐	Corrugated metal	Ball joint	☐
New	Prefab conduit	☒		Exp. loop	☐
	Direct Burial	☐		Other	☐
	Other	☐			☐

Welded schedule 80 steel

API slips, drips and valves are in vaults.

5. Intervals between expansion devices 200 feet
6. Condensate return? _____ yes _____ no
7. Intervals between manholes 200 feet
8. Temperature and pressure _____ F _____ psi (HP steam)
_____ F _____ psi (LP steam)
_____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	<u> / </u>
Other	_____		

Very few internal leaks; usually after a low pressure event. Maybe 1-3 leaks/year.

2. How are leaks detected now?

Check each vault on a 6 week rotation.

Note hot spots on wall of vault at conduit, or visible steam. Tried Cleveland Thermal's acoustic device, without much luck. Also tried a leak detection contract (can't remember name).

3. How are leaks located? *Figure which vault is hottest. Drill to top of conduit. Listen & look for escaping steam. Generally at welds. Up to 5 welds per vault.*

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not? *although leaks aren't a big problem.*

3. What would increase this system's usefulness to you?

Would hire a contractor w/ specialized equipment. wouldn't buy the system themselves.

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
☒ b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

LEAK DETECTION SURVEY

Name of System Toronto District Heating Corp.

Contact Name Alex Bystro

Phone 416-342-6838

A. Distribution System

1. Year oldest pipe installed early 1960s 2. Miles of pipe 1.2

3. Type of pipe installation

Box conduit _____
Solid pour conduit _____
Tunnel ✓ *render pipe*
Prefab conduit _____
Direct Burial ✓ _____
Other _____

Direct burial
Other
w/ another species

slip joints ✓ Mar 11/13
Bellows _____
Ball joint ✓ _____
Exp. loop _____
Other _____

2 billion lbs/year

5. Intervals between expansion devices feet *varies*

6. Condensate return? ✓ yes no in hands only

7. Intervals between manholes _____ feet *varies*

8. Temperature and pressure _____ F 250 psi (HP steam)
 _____ F 25 psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other	_____		_____

Never had a main line leak.

Biggest problem is flooding of manhole from a city water line
seen boots off the steam line.

2. How are leaks detected now?

- Steam in a manhole
- Regular inspection of slip joints (all in vaults)

3. How are leaks located?

Tried IR once - worked well

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☒ no

2. If not, why not?

Leaks are not a problem

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Trenton District Energy Corp.
 Contact Name Don Leibowitz - President
 Phone 609-396-1892

A. Distribution System

1. Year oldest pipe installed 1983 2. Miles of pipe _____

3. Type of pipe installation 4. Expansion devices

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints _____
 Bellows _____
 Ball joint _____
 Exp. loop ✓
 Other _____

*Polyethylene over fiberglass.
 welded steel.*

2-9' depth

5. Intervals between expansion devices _____ feet

6. Condensate return? _____ yes _____ no

7. Intervals between manholes 250+ feet

8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
220-400 F 345 psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves _____
 Welds _____
 Expansion devices _____
 Other _____

Rollers _____
 Flanges _____
 External corrosion ✓

Leaks are not a big problem.

2. How are leaks detected now?

Original leak detection (in-line) system never worked well. No longer use.

3. How are leaks located?

Touch pavement.

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no

8/13/91

125

LEAK DETECTION SURVEY

Name of System Trigen - London, Ontario
 Contact Name Gary Nickerson
 Phone 519-434-9194

A. Distribution System

1. Year oldest pipe installed _____ 2. Miles of pipe 4
 3. Type of pipe installation _____ 4. Expansion devices _____
 Box conduit _____ Slip joints _____
 Solid pour conduit _____ Bellows _____
 Tunnel _____ Ball joint _____
 Prefab conduit _____ Exp. loop _____
 Direct Burial _____ Other _____
 Other _____

*System very old and small. Wouldn't want to sink
 any money into leak detection. Hope to quadruple
 size of system. Would then put in in-line
 leak detection.*

5. Intervals between expansion devices _____ feet
 6. Condensate return? _____ yes _____ no
 7. Intervals between manholes _____ feet
 8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	_____
Other	_____		

2. How are leaks detected now?

- Visible steam
- Dry spot on rainy day

3. How are leaks located?

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☐ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☐ yes ☐ no

LEAK DETECTION SURVEY

Name of System Trigon - Kansas City
 Contact Name Bob Stevenson, Director of Operations
 Phone 816-556-2821

A. Distribution System

1. Year oldest pipe installed ~1905 2. Miles of pipe 9
 3. Type of pipe installation 4. Expansion devices
Box conduit	_____	Slip joints	_____
Solid pour conduit	_____	Bellows	☒
Tunnel	_____	Ball joint	_____
Prefab conduit	_____	Exp. loop	_____
Direct Burial	☒	Other	_____
Other	_____		
- some old variators*

4-10' pipe depth.

5. Intervals between expansion devices <100 feet
 6. Condensate return? _____ yes ☒ no
 7. Intervals between manholes 500-1000 feet
 8. Temperature and pressure 380 F 185 psi (HP steam)
 250 F 15 psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____	Rollers	_____
Welds	_____	Flanges	_____
Expansion devices	_____	External corrosion	☒
Other	_____		

LP line is the problem.

*Usually at a tee, elbow
or variator*

Don't have many leaks.

2. How are leaks detected now?

- Visible steam
- Complaint

3. How are leaks located?

HP line - use Heath Aquascope. Works well for HP but not for LP. End up having to dig exploratory holes, and/or feel the pavement.

4. What is the accuracy of your location methods?

Good on HP, OK on LP

C. Use of Acoustic System1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no2. ~~If not, why not?~~ *If taps can be done w/in manholes.*

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no "a possibility"

LEAK DETECTION SURVEY

Name of System Tripp - Nassau County

Contact Name Al Gussler, Plant Manager

Phone 609-396-7651

A. Distribution System

1. Year oldest pipe installed 1971 2. Miles of pipe 8-9

3. Type of pipe installation

Box conduit	_____
Solid pour conduit	_____
Tunnel	_____
Prefab conduit	_____
Direct Burial	_____
Other	_____

Slip joints _____
Bellows _____
Ball joint _____
Exp. loop _____
Other _____

5. Intervals between expansion devices _____ feet

6. Condensate return? yes no

7. Intervals between manholes feet

8. Temperature and pressure _____ F _____ psi (HP steam)
 _____ F _____ psi (LP steam)
350 F _____ psi (hot water)
 _____ F _____ psi (chilled water)

B. Current Leak Detection

1. What types/locations of leaks are your biggest problem?

Valves	_____
Welds	_____
Expansion devices	_____
Other	_____

Rollers _____
Flanges _____
External corrosion _____

Since running the system over the last 8 years,
had only 1 leak.

2. How are leaks detected now?

The only one was detected because it flashed
to steam, condenser, and water leaks out.

Also - can monitor make-up water reads.

3. How are leaks located?

4. What is the accuracy of your location methods?

w/in 5-10'

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as
described earlier? _____ yes _____ ☒ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected
through other means

5. Would you be interested in field testing a prototype system?

_____ yes _____ no

LEAK DETECTION SURVEY

Name of System Trigon - Tulsa, OK
 Contact Name Ken Adams - Dir. of Operations
 Phone 918-582-2212

A. Distribution System

1. Year oldest pipe installed 1970 2. Miles of pipe 2
 3. Type of pipe installation 4. Expansion devices

Box conduit _____
 Solid pour conduit _____
 Tunnel _____
 Prefab conduit _____
 Direct Burial _____
 Other _____

Slip joints ✓ in manholes
 Bellows ✓ _____
 Ball joint _____
 Exp. loop _____
 Other _____

Chilled water - welded steel - coated & wrapped.

Steam - carrier pipe in steel conduit w/ insulation.

Condensate - Fiberglass (replacing this w/ epoxy-coated steel)

5. Intervals between expansion devices ~150 feet average
 Cathodic Protection on CW and Condensate lines

6. Condensate return? ✓ yes _____ no

7. Intervals between manholes 400 feet average - varies 30-1200'

8. Temperature and pressure 425 F 150 psi (HP steam)
 _____ F _____ psi (LP steam)
 _____ F _____ psi (hot water)

B. Current Leak Detection

40 135-140 CW - supply
43-54 110 CW - return

1. What types/locations of leaks are your biggest problem?

Valves _____ Rollers _____
 Welds _____ Flanges _____
 Expansion devices ✓ (a few) External corrosion _____
 Other Condensate _____

↳ most leaks

Only a few leaks in CW system

2. How are leaks detected now.

~~Probe~~ Probe - rod - hand held or drive - thru
- works reasonably well.

Condensate tanks difficult to find

3. How are leaks located?

When the condensate line is the old fiberglass,
usually just replace from manhole to manhole
rather than try to locate leak.

4. What is the accuracy of your location methods?

C. Use of Acoustic System

1. Would you be interested in using an acoustic system as described earlier? ☒ yes ☐ no

2. If not, why not?

3. What would increase this system's usefulness to you?

4. Are you interested in:

- a. Ongoing system for monitoring, detection and location
- b. A system for use as necessary to locate leaks detected through other means

5. Would you be interested in field testing a prototype system?

☒ yes ☐ no "possibly"

Distribution for ANL-92/5

Internal:

W. E. Brewer	W. P. Lawrence	R. W. Weeks
H. Drucker	C. A. Malefyt (2)	ANL Patent Dept.
N. Heeg	A. C. Raptis	ANL Contract File
D. E. Karvelas	S. H. Sheen	TIS Files (3)
D. S. Kupperman (50)	C. E. Till	
R. Lanham	R. A. Valentin	

External:

DOE-OSTI, for distribution per UC-350 (331)

ANL Libraries (3)

DOE Chicago Operations Office:

Manager

F. Herbaty

Materials and Components Technology Division Review Committee:

H. Berger, Industrial Quality, Inc., Gaithersburg, MD

M. S. Dresselhaus, Massachusetts Institute of Technology, Cambridge, MA

S. J. Green, Electric Power Research Institute, Palo Alto, CA

R. A. Greenkorn, Purdue University, West Lafayette, IN

C.-Y. Li, Cornell University, Ithaca, NY

P. G. Shewmon, Ohio State University, Columbus

R. E. Smith, Electric Power Research Institute, NDE Ctr., Charlotte, NC

Elaine K. Allen, Green & Associates, Dallas

Mr. Mark Anderson, NRG Thermal, Minneapolis

Carl E. Avers, Catalyst Thermal Energy Corp., Youngstown, OH

Mark Avers, Baltimore Steam Co., Baltimore

Arturo F. Barcena, Medina, NY

Jeffrey P. Bees, Youngstown Thermal Corp., Youngstown, OH

Leif Bergquist, Trigen Energy Corp., New York

Iver Blackberg, Blackberg Assoc., Arlington Heights, IL

Timothy Block, Detroit Edison Co., Detroit

David Bonkovich, Heath Consultants, Inc., Belle Vernon, PA

James R. Brooks, Baltimore Steam Co., Baltimore

Rudy Brynolfson, St. Paul, Inc, St. Paul

Frederick Callowhill, Exec. Dir., IDHCA, Sanford, NC

John M. Casey, Univ. of Georgia, Athens

Wyndham Clarke, U.S. Dept. of Housing & Urban Dev., Washington

Lewis C. Cohen, Philadelphia Thermal Corp., Philadelphia

Floyd Collins, DOE, Washington

Robert O. Couch, RPSI, Inc., Brecksville, OH

Mr. M. Danbo, J.C. Hempel's Handelssus A/S, Copenhagen K, Denmark

Glen H. Fukuda, Fukuda Intl., Lafayette, CA

Jack Gleason, Washington
 Bill Goodwin, Harrisburg SW, Ltd., Harrisburg, PA
 Gary Gustafson, MEC, Minneapolis
 James F. Harley, Intergy, Inc., Brecksville, OH
 Gene Hess, Wisconsin Elec. Power Co., Milwaukee
 David F. Hobson, IDHCA, Washington
 Jay Holmes, USDOE, Washington
 Leslie J. Jardine, Bechtel National, Inc., San Francisco
 Loraine Kasprzak, Consolidated Edison Co. of New York, Inc., New York
 Jack Kattner, MEC, 1060 IDS Center, Minneapolis, MN
 P.G. Kemp, GAP Technologies, Menlo Park, 0102, South Africa
 Brian Kirk, Consolidated Edison, New York
 Y. Kitaura, Sumitomo Chemical America, Inc., New York
 John Kuhns, Catalyst Energy Dev. Corp., New York
 William Mariutto, KAFA Intl., Rivera Beach, FL
 Richard Mayer, PG&E Co. San Francisco
 Michael E. McKay, Princeton Univ., Princeton
 Dr. William Messner, Consolidated Edison R&D, New York
 Anthony C. Mirabella, Energy Networks Inc., Hartford, CT
 Michael J. Nagel, Univ. of Minnesota Plant, Minneapolis
 E. W. Ng, Consolidated Edison, New York
 Hans Nyman, St. Paul, Inc., St. Paul
 Yousuf H. Al Omar, United Gulf Construction Co. WLL, Safat, Kuwait
 Ishai Olikier, Burns and Roe, Ordell, NJ
 Seth J. Perkinson, III, The Perkinson Co., Charlotte, NC
 Robert J. Perry, Heath Consultants, Inc., Stoughton, MA
 Eugene Peters, 301 N. Amin Ave., Scranton, PA
 Sigrid H. Pilgrim, Intercon Research Associates, Ltd., Evanston, IL
 Christopher Pioli, Dept. of Utilities-Gas Division, Colorado Springs, CO
 Dean Price, Georgetown University, Washington
 W.L. Puckering, W.L. Puckering Consulting, Inc., Vancouver, B.C.
 Hermine Randall, Univ. of Mass./Amherst, Amherst, MA
 Zeph Regnier, 140 Promenade du Portage Phase IV Lv2, Hull, Quebec K1A 0M3
 Anders Rydaker, District Energy Systems, Roseville, MN
 Paul J. Sausville, Bulk Storage Section, Div. of Water, Albany
 Roger E. Scholl, URS/John A. Blume & Associates, San Francisco
 Beth Schumake, Neotronics North America, Inc., Gainesville, GA
 Mark Spurr, Resource Efficiency, Inc., St. Paul
 Darrell D. Stalzer, Iowa EL & P Co., Cedar Rapids, IA
 Fred Strnisa, NY State Energy R&D Auth., Albany
 David W. Wade, Resource Dev. Assoc., Inc., Atlanta, GA
 Galen Young, Fisher Research Lab., Los Banos, CA

END

**DATE
FILMED
6 / 9 / 92**