348
5/5/80

LD. 1140

DOE/NASA CONTRACTOR
REPORT

MASTER DOE/NASA CR-161413

SOLAR HEATING AND COOLING DEMONSTRATION PROJECT AT THE FLORIDA SOLAR ENERGY CENTER

Prepared by

Florida Solar Energy Center
University of Central Florida
300 State Road 401
Cape Canaveral, Florida

Under DOE Contract EG-77-A-01-4074

Monitored by

George C. Marshall Space Flight Center, Alabama
National Aeronautics and Space Administration

For the U. S. Department of Energy

U.S. Department of Energy

Solar Energy

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NOTICE

This report was prepared to document work sponsored by the United States Government. Neither the United States nor its agents the United States Department of Energy, the United States National Aeronautics and Space Administration, nor any federal employees, nor any of their contractors, subcontractors or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represent that its use would not infringe privately owned rights.

1. REPORT NO. DOE/NASA 161413	2. GOVERNMENT ACCESSION NO.	3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Solar Heating and Cooling Demonstration Project at the Florida Solar Energy Center		5. REPORT DATE February 1980	6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S)		8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Florida Solar Energy Center/University of Central Florida 300 State Road 401 Cape Canaveral, Florida		10. WORK UNIT NO.	11. CONTRACT OR GRANT NO. EG-77-A-01-4074
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, DC 20546		13. TYPE OF REPORT & PERIOD COVERED Contractor Report Final	
		14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical management of Mr. James D. Hankins, George C. Marshall Space Flight Center, Alabama.			
16. ABSTRACT This final report describes in considerable detail the retrofitted solar heating and cooling system installed at the Florida Solar Energy Center. Information is provided on the system's test, operation, controls, hardware and installation, including detailed drawings. The Center's office building, approximately 5,000 square feet of space, with solar air conditioning and heating as a demonstration of the technical feasibility is located just north of Port Canaveral, Florida. The system was designed to supply approximately 70 percent of the annual cooling and 100 percent of the heating load. The project provides unique high-temperature, non-imaging, non-tracking, evacuated-tube collectors. The design of the system was kept simple and employs five hydronic loops. They are energy collection, chilled water production, space cooling, space heating and energy rejection. This project was partially funded by the U. S. Department of Energy through its Second Program Opportunity Notice and was administered by the National Aeronautics and Space Administration. The Contractor/System Designer/User is the Florida Solar Energy Center. Mr. Omar G. Hancock, Jr., was the Principal Investigator.			
17. KEY WORDS		18. DISTRIBUTION STATEMENT UC-59a Unclassified-Unlimited WILLIAM A. BROOKSBANK, JR. Mgr, Solar Energy Applications Projects	
19. SECURITY CLASSIF. (of this report) Unclassified	20. SECURITY CLASSIF. (of this page) Unclassified	21. NO. OF PAGES 164	22. PRICE NTIS

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

Table of Contents

Final Report	1
System Acceptance Test Data	17
Sequence of Operation	39
Circulating Pumps and Motors	47
Solar Collectors	83
Automatic Control System	89
Absorption Chiller	121
Cooling Tower	122
Filters, Valves and Miscellaneous	128
Drawings	152

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Final Report

INTRODUCTION

The Florida Solar Energy Center (FSEC) has retrofitted one of the Center's office buildings, approximately 5,000 square feet of space, with solar air conditioning and heating as a demonstration of the technical feasibility to the many visitors to the Center and the residents of East-Central Florida. The project provides a unique opportunity to compare high-temperature, non-imaging, non-tracking, evacuated-tube collectors with the imaging and tracking collectors used in the Disney World and the Florida Welcome Station solar heating and cooling (SHAC) demonstration projects, since the three projects are similar in environmental conditions, size and configuration. The project is part of the Department of Energy's Solar Heating and Cooling Demonstration Program Second Program Opportunity Notice (PON-2).

The project is situated just north of Port Canaveral and south of the Cape Canaveral Air Force Station and is visible to the hundreds of persons entering and leaving the Air Force Station each day. Percentage of available sunshine is nearly uniform at 60 to 70 percent throughout the year. Daytime temperatures average 86F in the summer and 65F in the winter, with overnight freezing extremely rare.

The building which is serviced by the SHAC project provides space for electronic data processing equipment and offices for 20 persons and also includes a small mechanical shop for prototype and maintenance functions and an electronics shop. The building is of single-story cement block construction on a concrete slab, with a flat roof of built-up tar and gravel on an insulating roof deck. Ceilings are fiberglass tiles suspended one or more feet below the roof. Building dimensions are approximately 50 feet by 100 feet by 12 feet high, with the length of the building oriented east-west. The roof has 6 foot overhangs on east, west and south sides. There is very little window area in the building.

DESIGN PHILOSOPHY

The system was originally designed to supply approximately 70 percent

of the annual cooling load for one building and 50 percent of the annual heating load for three buildings. This latter objective of providing 50 percent of the heating requirements for three buildings was changed to provide 100 percent of the heating load for one building (the one which is also cooled) as an economy measure.

The solar energy system for the Research, Development and Demonstration Division (RD&D) building is shown schematically in Figure 1. The design of the system was kept simple and employs five hydronic loops:

- Energy collection loop
- Chilled water production loop
- Space cooling loop
- Space heating loop
- Energy rejection loop

Use of both hot water storage and chilled water storage effectively decouples the loops, facilitating analysis and operating controls. Since cooling is the major energy consuming mode in Florida, the collectors are tilted to the south at 15 degrees (latitude minus $13\frac{1}{2}^{\circ}$), to maximize summer-time collection. Pump head and pipe sizes were optimized (consistent with construction cost) to minimize parasitic power. Tank insulation was applied to limit unwanted thermal losses and gains to approximately 6 percent of the collected heat.

Collector

Absorption chillers available for use in SHAC systems typically require high temperature (180F to 200F) water, and all such devices which may become available are expected to require relatively high-temperature water. Florida skies are frequently subject to intermittent cloud cover, so it was felt that an evacuated collector making use of diffuse insolation would be more effective than a concentrating collector for producing high-temperature water in the Florida environment. General Electric's TC-100 was the collector chosen. The collectors each have 10 evacuated tubes and employ a single "sawtooth" Coilzak reflector underneath the tubes. Total collector area was sized to match the building's normal maximum cooling load, 216,000 Btu/hr.

Figure 1. Simplified Hydronic Schematic of the Solar System

Chiller

The water chiller is the Arkla model WFB-300 which has a nominal rating of 25 tons. It is supplied with hot water from storage and delivers its chilled water to storage. The controls are arranged so that, for the chiller to turn on, there is sufficient thermal energy in hot water storage for approximately one hour's operation of the chiller and enough chilled water storage capacity to receive the chiller output for one hour. These operating conditions were chosen to prevent short-cycling of the chiller and the resulting lower COP.

Storage

In specifying storage it is important to consider the relationship between storage size and area of collectors, energy available for operation at night and on cloudy days, system thermal inertia, and cost. Considering these factors, design was established at 3,000 gallons for hot water storage and 6,000 gallons for chilled water storage. The energy budget allowed for 6 percent loss of heat collected from storage and piping. Comparative energy capacities of the system are shown in Table 1.

Table 1. Energy Capacities of SHAC System

Quantity	Capacity	
	<u>Millions of Btu's per day</u>	
	<u>Summer</u>	<u>Winter</u>
Solar thermal energy collection	up to 1.9	up to 1.3
Hot water storage (ref. 165F)	up to 1.4	up to 1.4
Hot water demand	up to 2.6	up to 1.0
Chilled water production	up to 1.3	up to 0.8
Chilled water storage (ref. 53F)	up to 0.75	up to 0.75
Chilled water demand	up to 1.6	up to 0.5

Note that the maximum energy that can be stored as hot and chilled water combined is almost exactly that required for a day's cooling.

Controls

System controls are standard pneumatic devices. Exceptions are the solar intensity controller, the temperature differential controller and two time-out relays, which are all part of the collector pump controls. Figures 2 through 9 show each mode of operation and the logic statements by which the system is controlled for each mode.

Piping

All outdoor piping, except the small diameter tubing connecting the collectors to the headers, is copper pre-insulated with polyurethane foam and having an overall 60-mil white PVC jacket. It provides very good insulation, is well protected from weather and physical damage, is attractive in appearance, and seems to be cost-effective in its application.

PROBLEMS ENCOUNTERED AND THE SOLUTIONS

During evolution of the design, two significant details were changed. We were concerned about a high likelihood of air entrainment and/or entrapment in high points in the collectors. The General Electric TC-100 collector uses a continuous copper tube waterway which GE refers to as a serpentine and which contains, in each collector, 12 non-ventable high points (see Figure 10) when the collector is normally mounted tilted to the south from horizontal and the tubes and reflectors are oriented north-south as recommended by GE. It was concluded there was insufficient data to justify ignoring widely proven good engineering design practices by designing a system having 1,200 known non-ventable high points. This system, therefore, has the tubes oriented east-west to minimize the potential risk. (It should be noted that the risk cannot be eliminated, as the GE TC-100 uses a 360° loop in the copper tubing at each inlet and outlet.) Also, thermal performance data later supplied by GE suggest performance may be improved when mounted with the tubes east-west.

FIGURE 2. Solar Energy Collection / Conversion

- Insolation ≥ 50 Btu/hr - ft² - °F incident on photocell PC-1 energizes cycle timers.
 - Cycle timer CT-1 turns on P1 to establish flow.
 - Cycle timer CT-2 turns off P1 after 3 minutes and resets CT-1 to turn on again after 30 minutes.
- OF
- T1-T2 $\geq 10^\circ\text{F}$, a ΔT controller maintains P1 in operation. (This is usually established during the 3 minutes of P1 operation thru the cycle timers.)
 - T1-T2 $\leq 4^\circ\text{F}$ deenergizes ΔT controller.

FIGURE 3. Chilled Water Production From Solar Energy

- Selector switch in "COOL" opens CV 4, closes CV1 and 2 to the flow of solar hot water, enables chiller controls.
 - $T_4 \geq 185F$ AND $T_5 \geq 50F$ turns on P2, P3, and P5.
 - $T_4 \leq 175F$ OR $T_{evap} = 38F$ turns off P2, P3, and P5.
 - $T_{sump} \geq 85F$ turns on tower fan
 - $T_{sump} \leq 80F$ turns off tower fan
- (Note - T_{evap} and CV3 are supplied with and are part of the Arkla Chiller.)

Figure 10
View of GE TC-100 Collector
Showing "Hair Pin" Waterways

Cost was the project's biggest problem. The proposal was submitted on November 17, 1976, and the signed contract was received in late September 1977. During that interval, construction activity greatly increased in Brevard County, and construction costs rose 20 to 25 percent. Steps taken to offset cost increases included:

- Eliminating a separate heat exchanger for rejecting thermal energy off the collectors when surplus heat is collected. Instead, excess heat is absorbed by chilled water from storage, which eventually rejects the excess heat through the absorption chiller and then through the water tower (see Figure 8).
- Equipment building was re-designed and reduced in size.
- FSEC constructed the building and concrete pads for storage tanks and water cooling tower.
- FSEC purchased and mounted the collectors, the chiller, and the cooling tower.

To be sure, the FSEC accepted greater risk than had a turn key construction contract been awarded, but the result was financially satisfying. The project met its re-estimated cost at completion of \$220,800, compared with the negotiated estimated cost of \$215,602 and an estimated cost without the cost reduction effort of more than \$270,000.

Other problems encountered during construction and start-up included numerous late receipt of parts and a controls problem. Careful planning to assure solar-heated hot water to operate the chiller went for naught because of a misunderstanding between the detail design engineer and the contractor regarding operational controls on the chiller. The contractor believed he was following the engineer's instructions when he (a) disconnected the motor-operator of the hot water input diverting valve, (b) replaced the electric motor with a vacuum-operator, and (c) connected the vacuum-operator to the system controls. The chiller was not designed to operate in this way, and, in fact, will not operate when so disconnected. Consequently, the contractor had to reinstall the chiller controls and interface system controls and the chiller differently.

During installation, in early May, only three glass collector tubes were broken. An additional 36 tubes self-destructed by June 28, 1979. Since June 28, however, only one tube has self-destructed.

SUMMARY

The system has operated well, as planned, and without problems since the chiller was turned on May 24, 1979. It is not instrumented, so a quantitative performance evaluation is not possible. However, a count of the number of hours of space cooling from solar and a count of the total number of hours of space cooling indicates a solar fraction of about 50 to 60 percent during the summer cooling season.

Experience so far has been good with the collector tubes mounted in the east-west orientation, with both flow and performance seeming to be normal at all times. The reflector troughs have remained clean and clear, any dirt or debris being removed by rain. We think we made a good choice.

The problems encountered are considered to be typical in magnitude and were easily handled. System activation date of May 24, 1979, was 32 days late, primarily due to late parts delivery. Cost performance turned out well, too, as final project cost was just over the re-estimated figure of \$220,800.

PROJECT COST SUMMARY

<u>Cost Element</u>	<u>Materials</u>	<u>Labor</u>	<u>Total</u>
Design	-	\$14,438	\$14,438
Construction & Installation			
Frames	\$11,960	10,540	22,500
Collectors	38,688	720	39,408
Tanks	12,600	720	13,320
Chiller	18,595	-	18,595
Water Tower	1,794	62	1,856
Plumbing	32,880	21,795	54,675
Controls	6,690	6,585	13,275
Insulation	4,471	6,710	11,181
Pumps	4,200	1,200	5,400
Masonry	3,407	5,507	8,914
Other	6,710	4,540	11,250
Project Management	-	6,032	6,032
Total Project Cost	\$142,307	\$78,537	\$220,844

PROJECT CHRONOLOGY

76 Nov 17 Technical Proposal submitted to Energy Research and Development Administration in response to PON DSE-76-2.

77 Mar 11 Cost Proposal submitted to ERDA.

77 June 22 Cooperative Agreement negotiated with ERDA.

77 Sept 20 Cooperative Agreement signed by the Contracting Officer.

77 Nov 14 Contract awarded to Stottler-Stagg and Associates to perform detailed construction drawings and specifications for the system.

78 June 16 Final design review with the government's Project Manager.

78 June 27 Construction drawings approved subject to the incorporation of comments.

78 Aug 24 Construction bids opening. Island Mechanical Contractor apparent successful (low) bidder. (Island Mechanical Contractor later changed name to S.I. Goldman Company.)

78 Sept 24 Contractor notified to proceed.

78 Nov 28 Chiller delivered.

79 Mar 8 Storage tanks delivered.

79 Mar 19-21 Collector frames installed.

79 Apr 30 -
May 2 Evacuated glass tubes installed on collectors and energy collection begun.

Project Chronology

Page 2

- 79 May 24 Chiller activated with solar-heated water. Scheduled date was missed due to chiller controls being inadvertently disabled by contractor.
- 79 June 29 Dedication by DOE's Omi Walden, State Senator John Vogt and State Senator Clark Maxwell.
- 79 Aug 16 Acceptance Test complete.

SYSTEM ACCEPTANCE TEST DATA

LEGEND

T-1	:	SOLAR MANIFOLD OUTLET TEMPERATURE	
T-2	:	HOT WATER STORAGE TANK TEMPERATURE	(12" From Bottom of Tank)
T-3	:	HOT WATER SUPPLY TANK TEMPERATURE	(15" Below Top of Tank)
T-4	:	CHILLED WATER STORAGE TANK TEMPERATURE	(18" Below Top of Tank)
T-5	:	CHILLED WATER OUTLET FROM CHILLER TEMPERATURE	
T-6	:	COLD DECK TEMPERATURE	
T-7	:	CHILLED WATER TANK SUPPLY OUTLET TEMPERATURE	(Adjacent to Inlet, Pump P-4)
T-8	:	CONDENSING WATER SUPPLY TEMPERATURE	
P-1	:	COLLECTOR - HOT WATER TANK PUMP	
P-2	:	HOT WATER TO CHILLER PUMP	
P-3	:	CHILLED WATER FROM CHILLER PUMP	
P-4	:	CHILLED WATER TO AHU PUMP	
P-5	:	CONDENSING WATER PUMP	
P-6	:	HEAT REJECTION PUMP	

TEMPERATURE READINGS - FAHRENHEIT

<u>TIME</u>	<u>T-1</u>	<u>T-2</u>	<u>T-3</u>	<u>T-4</u>	<u>T-5</u>	<u>T-6</u>	<u>T-7</u>	<u>T-8</u>
9:45	190	165	175	52	68	66	68	83
10:15	192	165	177	52	69	66	68	84
10:45	195	165	185	52	58	70	58	85
11:15	200	170	180	51	46	63	47	85
11:45	194	170	176	51	46	68	47	86
12:15	194	170	176	51	47	70	48	86
12:45	195	172	178	51	47	70	48	86
1:15	195	172	176	51	47	70	48	86
1:45	195	172	176	51	47	71	48	86
2:15	195	175	176	51	46	71	48	86
2:45	195	175	176	52	52	76	53	86
3:15	194	178	174	52	47	78	48	86
3:45	192	177	175	52	47	79	48	86
4:15	190	178	172	52	47	80	48	86
4:45	186	175	172	52	47	80	48	86
5:15	180	174	170	52	52	77	52	87
5:45	180	170	170	52	55	77	53	87

PUMP ACTUATION

TIME	P-1	P-2	P-3	P-4	P-5	P-6	CT-FAN	CHILLER
9:45	ON	-	-	-	-	-	- - -	- - -
10:15	ON	-	-	-	-	-	- - -	- - -
10:45	ON	ON	ON	-	ON	-	ON	ON
11:15	ON	ON	ON	ON	ON	-	ON	ON
11:45	ON	ON	ON	ON	ON	-	ON	ON
12:15	ON	ON	ON	ON	ON	-	ON	ON
12:45	ON	ON	ON	ON	ON	-	ON	ON
1:15	ON	ON	ON	ON	ON	-	ON	ON
1:45	ON	ON	ON	ON	ON	-	ON	ON
2:15	ON	ON	ON	ON	ON	-	ON	ON
2:45	ON	ON	ON	-	ON	-	ON	ON
3:15	ON	ON	ON	-	ON	-	ON	ON
3:45	ON	ON	ON	-	ON	-	ON	ON
4:15	ON	ON	ON	-	ON	-	ON	ON
4:45	ON	ON	ON	-	ON	-	ON	ON
5:15	-	-	-	-	-	-	- - -	- - -
5:45	-	-	-	-	-	-	- - -	- - -

CONTROL SYSTEMS CHECKOUT AND CALIBRATION

A. Solar Energy Collection, Conversion and Storage Subsystem

<u>STEP</u>		<u>ACTION/RESPONSE</u>
1.	Establish following conditions:	
1.1	PE-1 actuated (R and B contacts OPEN) because temperature at solar array supply (outlet)(T-1) not below 38°F. PE-1 purpose (array freeze protection) will be tested in Step <u>5</u> .	PE-1 ACTUATED <u>ok</u>
1.2	R8 actuated (1 and 3 contacts CLOSED because water in HW storage tank is above low water level. HW low water level switch will be tested in Step _____. (Omega Mod. 2176A, W/'T' thermocouple digital thermometer used as standard at all dial thermometer locations.)	R8 ACTUATED <u>P-1</u> <u>running ok</u>
1.3	Place hand-off-auto- switch on P-1 starter and P-1 on-off-auto switch on control panel in AUTO positions.	Switches in AUTO position <u>yes</u>
2.	Test <u>timer control</u> of subsystem:	
2.1	Turn solar controller OFF. NOTE - Step <u>2</u> accepted without test, timer having already proven itself.	R9 DEACTIVATED <u>-</u> Solar controller light OFF <u>-</u>
2.2	Check to see that R1 is deactivated (1 and 4 contacts CLOSED) because daylight is being detected by photocell (unless we are doing this at night). Photocell control will be tested in Step <u>4</u> .	R1 DEACTIVATED <u>-</u>
2.3	Time operation of timer-1 and timer-2:	

- 2.3.1 Wait until P-1 is running. Then measure time between when P-1 STOPS and P-1 STARTS again.

Time between P-1 STOPPING and P-1 STARTING is -.

NOTE - P-1 red and green indicating lights on control panel can be used as indicators of P-1 operation for this step and steps following for this subsystem.

Should be time set on timer-1 dial

- 2.3.2 Then measure time between when P-1 STARTS and P-1 STOPS again. (See 2.3.1 NOTE)

Time between P-1 STARTING and P-1 STOPPING -.

Should be time set on timer-2 dial.

3. Test solar controller control of subsystem:

- 3.1 Calibrate T-1 transmitter, RC-1 receiver controller and T-1 temperature readout on control panel using dial thermometer near T-1 transmitter as standard:

- 3.1.1 Note the input temperature to PORT #1 of receiver controller.

Input temperature 185 °F at dial thermometer location

NOTE - Input temperature to PORT #1 of receiver controller is to be taken as temperature being read on dial thermometer near T-1 transmitter.

- 3.1.2 Note temperature indicated on T-1 temperature readout on control panel. It should be same as input temperature to PORT #1 in Step 3.1.1.

Temperature on T-1 control panel readout 185 °F

NOTE - If temperatures are not the same, remove cover from T-1 transmitter and turn adjustment screw until T-1 temperature readout on control panel is the same as the input temperature to PORT #1.

3.1.3 Set the desired throttling range of
RC-1 which is 21%.

TR at 21 %

3.1.4 Turn the control point adjustment screw
on receiver controller CLOCKWISE until
PE switch clicks or temperature scale
rotates 1 1/2 revolution. Then turn con-
trol point adjustment screw COUNTER-
CLOCKWISE until PE switch clicks.

CW until click _____

-or-

CW until 1 1/2 rev. _____

CCW until click _____

3.1.5 Lift the control point scale on receiver
controller to disengage the gear teeth
and set the scale to the temperature
noted at PORT #1 in Step 3.1.1. Release
the control point scale so that it will
reengage the gear teeth.

Control point scale
reads 185 °F

3.1.6 Turn the control point adjustment screw
on the receiver controller until the
scale indicates the desired receiver con-
troller set point. RC set point is 45°F.

Control point scale
indicates 45 °F

3.2 Calibrate T-2 transmitter and T-2 tem-
perature readout on control panel by
repeating Step 3.1.2 substituting T-2 for
T-1.

Temperature on dial
thermometer near T-2
176.2 °F

Temperature on T-2
control panel readout
176 °F

NOTE - No receiver controller is used
with T-2. Temperature to PORT #1 is
taken to be temperature on dial thermo-
meter near T-2 transmitter.

3.3 Turn solar controller ON

Solar controller lights
ON -

3.4 Wait for or cause solar controller to
sense $T\Delta \geq 15^\circ\text{F}$. Solar controller will
cause P-1 to run by actuating R9 when
 Δ of 15°F is reached. P-1 will con-
tinue to run until $T\Delta \geq 5^\circ\text{F}$. (See 2.3.1
NOTE)

T1 when P-1 STARTS - °F
T2 when P-1 STARTS - °F
T1/T2 Δ - °F

T1 when P-1 STOPS - °F
T2 when P-1 STOPS - °F
T1/T2 Δ - °F

NOTE - Steps 3.3 and 3.4 accepted
without test, as solar controller was
proven already through daily operation.

4. Test photocell control of subsystem:

- 4.1 Repeat Step 2.3.2 and while P-1 is running place tape over photocell. P-1 should stop running after time delay. Removing tape from over photocell should cause P-1 to start running again after time delay.

P-1 STOPS with tape over photocell yes

P-1 STARTS after tape is removed from photocell yes

NOTE - Some delay in P-1 starting may occur due to timer actions.

5. Test freeze protection of solar array:

- 5.1 Turn OFF solar controller.

Solar controller lights OFF yes

- 5.1a PULL R-9.

R-9 OUT yes

- 5.2 Remove T-1 transmitter from well.

T-1 transmitter removed yes

HOLD transmitter until reading on T-1 control panel readout settles.

T-1 control panel readout while T-1 air out of well not read °F

- 5.3 Place T-1 transmitter sensing element into an ice bath with a test electronic thermometer. Note that P-1 starts at 38°F and remains running as temperature drops further. If P-1 does not start at 38°F recalibrate RC-1 control point using test thermometer as standard. Set RC-1 control point dial at 38°F.

T-1 in ice bath test x
thermometer in bath x

P-1 STARTS:

38 °F on test thermometer

P-1 STOPS:

45 °F on test thermometer

- 5.4 SLOWLY add tap water to ice bath and note that P-1 STOPS at 45°F and remains stopped as temperature rises.

- 5.5 Remove T-1 from ice bath, reinstall T-1 in well, turn ON solar controller.

Install T-1 in well x
Solar controller lights ON yes

- 5.6 Check calibration of T-1 transmitter, and T-1 temperature readout on control panel by repeating Step 3.1.1 and 3.1.2.

Input temperature 194 °F
(ref. 3.1.1)
Temperature on T-1 control panel readout 194 °F
(ref. 3.1.2)

Figure 1. Solar Energy Collection, Conversion and Storage Subsystem

B. Excess Heat Rejection Subsystem

<u>STEP</u>		<u>ACTION/RESPONSE</u>
6.	Establish following conditions:	
6.1	R7 actuated (1 and 3 contacts CLOSED) because water in chilled water (CW) storage tank is above low water level. CW low water level switch will be tested in Step_____.	R7 ACTUATED <u>yes</u>
6.2	Place hand-off-auto switch on P-6 starter and P-6 on-off-auto switch on control panel in AUTO positions.	Switches in AUTO position <u>yes</u>
7.	Calibrate T-3 transmitter: RC-3A, RC-3B, RC-3C, RC-3D receiver controllers and T-3 temperature readout on control panel using dial thermometer near T-3 transmitter as standard:	
7.1	Note the input temperature to PORT #1 of receiver controllers.	Input temperature <u>181.6 °F</u>
	NOTE - Input temperature to PORT #1 of receiver controllers is to be taken as temperature being read on dial thermometer near T-3 transmitter.	
7.2	Note temperature indicated on T-3 temperature readout on control panel. It should be same as input temperature to PORT #1 of receiver controllers in Step 7.1.	Temperature on T-3 control panel readout <u>182 °F</u>
	NOTE - If temperatures are not the same remove cover from T-3 transmitter and turn adjustment screw until T-3 temperature readout on control panel is the same as the input temperature to PORT #1 of receiver controllers.	

- 7.3 Set the desired throttling range of RC-3A which is 15%. RC-3A TR at 15 %
- 7.4 Set the desired throttling range of RC-3B which is 15%. RC-3B TR at 15 %
- 7.5 Set the desired throttling range of RC-3C which is 15%. RC-3C TR at 15 %
- 7.6 Set the desired throttling range of RC-3D which is 15%. RC-3D TR at 30 %
- 7.7 Turn the control point adjustment screw on RC-3A CLOCKWISE until PE-3A clicks or temperature scale rotates 1 1/2 revolution. Then turn control point adjustment screw COUNTERCLOCKWISE until PE-3A clicks. CW until click x
-or-
CW until 1 1/2 rev. x
CCW until click x
- NOTE - Control point scale turns in opposite direction from control point adjustment screw.
- 7.7.1 Lift the control point scale on the receiver controller to disengage the gear teeth and set the scale to the temperature noted at PORT #1 in Step 7.1. Release the control point scale so that it will reengage the gear teeth. Control point scale reads 184 °F
- 7.7.2 Turn the control point adjustment screw on receiver controller until scale indicates a 230°F set point. Control point scale indicates 230 °F
- 7.8 Adjust RC-3B using click of PE-3B by repeating Steps 7.7, 7.7.1 and 7.7.2. In Step 7.7.2 set point is 205°F. Ref. Step 7.7
CW until click _____
-or-
CW until 1 1/2 rev. x
CCW until click x
- Ref. Step 7.7.1
Control point scale reads 183 °F
- Ref. Step 7.7.2
Control point scale indicates 205 °F

- 7.9 Adjust RC-3C using click of PE-3C by repeating Steps 7.7, 7.7.1 and 7.7.2. In Step 7.7.2 set point is 125°F.

Ref. Step 7.7

CW until click _____

-or-

CW until 1 1/2 rev. x

CCW until click x

Ref. Step 7.7.1

Control point scale

reads 183 °F

Ref. Step 7.7.2

Control point scale

indicates 125 °F

- 7.10 Adjust RC-3D using click of PE-3D by repeating Steps 7.7, 7.7.1 and 7.7.2. In Step 7.7.2 set point is 180°F.

Ref. Step 7.7

CW until click _____

-or-

CW until 1 1/2 rev. x

CCW until click x

Ref. Step 7.7.1

Control point scale

reads 183 °F

Ref. Step 7.7.2

Control point scale

indicates 180 °F

NOTE - RC-3A, RC-3B and RC-3D are not used in this subsystem but are now adjusted for other tests of other subsystems.

8. Test T-3 control of P-6 and CV-6:

NOTE - The approach to be used to demonstrate this control is that instead of the T-3 transmitter sensing the set point temperature, the set point of the receiver controller will be adjusted to the temperature being sensed by T-3 transmitter to prove that when T-3 transmitter temperature matches set point of receiver controller PE-3B will actuate.

8.1	Note temperature on T-3 temperature readout on control panel.	T-3 temperature on control panel <u>182</u> °F
8.2	Adjust RC-3B receiver controller control point by turning control point adjustment screw to indicate temperature read in Step 8.1. This simulates T-3 temperature moving to set point. PE-3B should actuate starting P-6 and opening CV-6.	Control point scale indicates <u>184</u> °F
PE-3B ACTUATED <u>yes</u>
P-6 RUNNING <u>yes</u>
CV-6 OPEN <u>yes</u>
8.3	Increase RC-3B control point by 5°F simulating T-3 temperature decreasing 50°F. PE-3B should deactuate stopping P-6 and closing CV-6.	PE-3B DEACTUATED <u>191</u> °F
P-6 STOPPED <u>yes</u>
CV-6 CLOSED <u>yes</u>
8.4	Return RC-3B control point dial to RC-3B set point of 205°F.	RC-3B control point dial at <u>205</u> °F

C. Cooling From Chilled Water Subsystem

STEP

ACTION/RESPONSE

9.	Establish following conditions:	
9.1	Place heat-cool switch on control panel in COOL position.	Heat-cool switch in COOL position <u>yes</u>
9.2	Place hand-off-auto switch on P-4 starter and P-4 on-off-auto switch on control panel in AUTO position	In AUTO positions <u>yes</u>
10.	Calibrate T-7 transmitter, RC-7 receiver controller and T-7 temperature readout on control panel by repeating Steps 3.1, 3.1.1, 3.1.2, 3.1.3, 3.1.4, 3.1.5 and 3.1.6 substituting T-7 for <u>T-1</u> .	<u>Ref. 3.1.1</u>
Input temperature <u>153.4</u> °F
<u>Ref. 3.1.2</u>
Temperature on T-7 control panel readout <u>152.9</u> °F
	NOTES -
<u>Ref. Step 3.1.3</u> throttling range for RC-7 is 30%.	<u>Ref. 3.1.3</u>
TR at <u>30</u> %
	<u>Ref. Step 3.1.6</u> set point for RC-7 is 55°F.	<u>Ref. 3.1.4</u>
CW until click _____
-or-
CW until 1 1/2 rev. <u>x</u>
CCW until click <u>x</u>

Ref. 3.1.5
Control point scale
reads 53 °F

Ref. 3.1.6
Control point scale
indicates 55 °F

11. Calibrate T-6 transmitter, RC-6 receiver controller and T-6 temperature readout on control panel using a test thermometer (remove dial thermometer near T-4 and use as test thermometer) as standard:

- 11.1 Insert test thermometer into AHU plenum adjacent to T-6 transmitter sensing element. Allow time for test thermometer to stabilize.

Test thermometer
inserted yes

- 11.2 Repeat Steps 3.1, 3.1.1, 3.1.2, 3.1.3, 3.1.4, 3.1.5 and 3.1.6 substituting T-6 for T-1 and test thermometer for dial thermometer.

Ref. 3.1.1
Input temperature 61 °F

Ref. 3.1.2
Temperature on T-6
control panel readout
61 °F

NOTES -

Ref. Step 3.1.3 throttling range for
RC-6 is 10%.

Ref. 3.1.3
TR at 10 %

Ref. Step 3.1.4 Responsive item is
CV-5 positioning to mid (approx.) position.

Ref. Step 3.1.6 set point for RC-6 is
55 °F.

Ref. 3.1.6
Control point scale
indicates 55 °F test
thermometer out yes

- 11.3 Remove test thermometer.

12. Test T-7 control of chilled water circulation to cold deck and automatic change-over to existing backup DX system:

12.1 Note temperature on T-7 temperature at RC-7 set point by adjusting RC-7 control point dial to T-7 temperature read in Step 12.1. PE-7 should actuate STOPPING P-4 and STARTING backup DX airconditioning system compressor.

T-7 temperature read-
out on control panel
52 °F

*12.2 Simulate T-7 temperature at RC-7 set point by adjusting RC-7 control point dial to T-7 temperature read in Step 12.1. PE-7 should actuate STOPPING P-4 and STARTING backup DX airconditioning system compressor.

RC-7 control point dial
at 56 1/2 °F

PE-7 DEACTUATES yes
P-4 STARTED yes
Backup DX system
STOPPED yes

NOTE - Backup DX system t'stat must be calling for COOLING for DX system to start during this test.

*NOTE - In Steps 12.2, 12.3, 15.2, 15.3, 20.3, 20.5, 21.3 and 21.4, if the PE switch is already actuated, the simulated adjustment is equal to the PE switch differential from the activation set point. This results in actual "action/response" being opposite to that originally indicated.

12.3 Decrease RC-7 control point by 5°F simulating T-7 temperature decreasing 5°F. PE-7 should deactivate STARTING P-4 and STOPPING backup DX airconditioning system compressor.

RC-7 control point
dial at 51 1/2 °F

PE-7 ACTUATES yes
P-4 STOPPED yes
Backup DX system
STARTED yes

12.4 Return RC-7 control point dial to RC-7 set point of 55°F.

RC-7 control point
dial at 55 °F

13. Test T-6 control of CV-5
CV-5 NOT TESTED

D. Heating From Solar Energy and Heating From Backup System Subsystem

<u>STEP</u>		<u>ACTION/RESPONSE</u>
14.	Establish following conditions:	
14.1	Place heat-cool switch on control panel in HEAT position.	In HEAT position <u>yes</u>
14.2	Turn set point on RC-4 "UP" to STOP chiller.	Chiller STOPPED <u>yes</u>
14.3	Place hand-off-auto switch on P-2 starter and P-2 on-off-auto switch on control panel in AUTO positions.	Switches in AUTO <u>yes</u>
14.4	R8 actuated (6 and 8 contacts CLOSED) because water in HW storage tank is above low water level. HE low water level switch will be tested in Step_____.	R8 ACTUATED <u>yes</u>
14.5	NOTE - T-3 transmitter, RC-3C receiver controller, PE-3C and T-3 temperature readout on control panel have been calibrated in Steps 7., 7.1, 7.2, 7.5, and 7.9.	
15.	Test T-3 control of P-2, CV-1A, CV-1B and CV-2 in this subsystem:	
15.1	Note T-3 temperature on T-3 temperature readout on control panel.	T-3 temperature on control panel <u>181</u> °F
15.2	Set RC-3C control point dial to T-3 temperature from Step 15.1 (simulating T-3 transmitter sensor moving to RC-3C set point). When RC-3C control point dial indicates T-3 temperature P-2 will start and CV-1A, CV-1B, CV-2 actuators will move full distance towards valve bodys.	RC-3C control point dial at <u>186</u> °F P-2 STOPPED <u>yes</u> CV-1A actuator full towards diaphragm <u>yes</u> CV-1B actuator full towards diaphragm <u>yes</u> CV-2 actuator full towards diaphragm <u>yes</u>
	See NOTE after 12.2	

NOTE - Subsystem is now in heating from solar energy mode. These valve actuator positions will result in:

CV-1A CLOSING stopping HW from coil returning to existing HW boiler return.

CV-1B OPENING allowing HW from coil to return to hot water storage tank.

CV-2 OPENING between NC and C ports allowing supply hot water from hot water storage tank to flow to coil.

CV-2 CLOSING between NO and C ports stopping supply hot water from HW boiler supply to flow to coil.

- 15.3 Increase RC-3C control point dial 5°F (simulating T-3 temperature decreasing 5°F) causing a switchover to HEATING from backup system mode. When this happens P-2 will stop and CV-1A, CV-1B, CV-2 actuators will move full distance towards diaphragm.

P-2 STARTED yes
CV-1A actuator full
towards body yes
CV-1B actuator full
towards body yes
CV-2 actuator full
towards body yes

See NOTE after 12.2.

NOTE - These valve actuator positions will result in:

CV-1A OPENING allowing HW from coil to return to existing HW boiler return.

CV-1B CLOSING stopping HW from coil to return to hot water storage tank.

CV-2 CLOSING between NC and C ports stopping supply hot water from hot water storage tank to flow to coil.

CV-2 OPENING between NO and C ports allowing supply hot water from HW boiler supply to flow to coil.

15.4	Return RC-3C control point dial to 125°F set point.	RC-3C control point scale reads <u>125</u> °F
15.5	RE-SET RC-4 set point to 50°F.	Set point <u>50</u> °F
15.6	Place heat-cool switch on control panel in COOL position.	In COOL position <u>yes</u>

E. Chilled Water Production From Solar Energy

STEP

ACTION/RESPONSE

16.	Establish following conditions:	
16.1	R8 actuated (6 and 8 contacts CLOSED) because water in IIW storage tank is above low water level. HW low water level switch will be tested in Step_____.	R8 ACTUATED <u>yes</u>
16.2	R7 actuated (6 and 8 contacts CLOSED) because water in CW storage tank is above low water level. CW low water level switch will be tested in Step_____.	R7 ACTUATED <u>yes</u>
16.3	Place hand-off-auto switches on P-2, P-3, P-5 and CT-FAN starters in AUTO positions.	P-2 in AUTO <u>yes</u>
P-3 in AUTO <u>yes</u>
P-5 in AUTO <u>yes</u>
CT-FAN in AUTO <u>yes</u>
16.4	Place P-2, P-3, P-5 and CT-FAN on-off-auto switches on control panel in AUTO position.	P-2 in AUTO <u>yes</u>
P-3 in AUTO <u>yes</u>
P-5 in AUTO <u>yes</u>
CT-FAN in AUTO <u>yes</u>
16.5	Place chiller off-auto switch on control panel in AUTO position. Status of chiller indicating lights on control panel will depend on T-3 and T-4 temperatures disregard at this time.	Chiller switch in AUTO position <u>yes</u>
16.6	Place switch in "COOL" position	In "COOL" position? <u>yes</u>
16.7	Disregard flow switch FS-3. Contacts have been shorted out.	Ok <u>ok</u>

17. Calibrate T-4 transmitter, RC-4 receiver controller and T-4 temperature readout on control panel by REPEATING.

Steps 3.1, 3.1.1, 3.1.2, 3.1.3, 3.1.4, 3.1.5 and 3.1.6 substituting T-4 for T-1 and RC-4 for RC-1.

NOTES -

Ref. Step 3.1.3 RC-4 throttling range is set at 30%.

Ref. Step 3.1.6 RC-4 set point is 50°F.

Ref. Step 3.1.1
Input temperature 53 °F

Ref. Step 3.1.2
Temperature on T-4 control panel readout 53.7 °F

Ref. Step 3.1.3
TR at 30 %

Ref. Step 3.1.4
CW until click x

-or-

CW until 1 1/2 rev. _____
CCW until click _____

Ref. Step 3.1.5
Control point scale reads 54 °F

Ref. Step 3.1.6
Control point scale indicates 50 °F

18. Calibrate T-8 transmitter, RC-8 receiver controller and T-8 temperature readout on control panel by REPEATING Steps 3.1, 3.1.1, 3.1.2, 3.1.3, 3.1.4, 3.1.5 and 3.1.6 substituting T-8 for T-1 and RC-8 for RC-1.

NOTES -

Ref. Step 3.1.3 RC-8 throttling range is set at 30%.

Ref. Step 3.1.6 RC-8 set point is 85°F

Ref. Step 3.1.1
Input temperature 84.5 °F

Ref. 3.1.2
Temperature on T-8 control panel readout 84.2 °F

Ref. Step 3.1.3
TR at 30 %

Ref. Step 3.1.4
CW until click x

-or-

CW until 1 1/2 rev. _____
CCW until click x

Ref. Step 3.1.5
Control point scale reads 84 °F

Ref. Step 3.1.6
Control point scale indicates 85 °F

18a. Calibrate T-5

Temperature gauge on
control panel 49.6 °F
Temperature at dial
thermometer 49.2 °F

19. NOTE - T-3 transmitter, RC-3D receiver controller, PE-3D and T-3 temperature readout on control panel have been calibrated in Steps 7., 7.1, 7.2, 7.6 and 7.10.

20. Test T-3 control of this subsystem:

20.1 Set RC-4 control point dial to T-4 temperature on readout on control panel. This will actuate PE-4 so that PE-3D can be monitored.

RC-4 control point dial
reads 53 1/2 °F
PE-4 ACTUATED yes

NOTE - Maintain PE-4 actuation by
RESETTING RC-4 control point dial as
required.

20.2 Note T-3 temperature on T-3 temperature readout on control panel.

T-3 temperature on
control panel 177 °F

20.3 Set RC-3D control point dial to T-3 temperature from Step 19.2 (simulating T-3 transmitter sensor moving to RC-3D set point). Note when RC-3D control point dial indicates T-3 temperature; P-2 will start, CV-4 actuator will move full distance towards valve body opening valve to allow HW to circulate between HW storage tank and chiller which will be detected by flow switch FS-1 CLOSING its contacts. FS-1 closing will start P-3. Chiller is enabled by R5 actuating.

RC-3D control point
reads 187 °F

P-2 STOPPED yes
CV-4 actuator full
CLOSED yes
P-3 STOPPED yes
R5 DEACTUATES yes

See NOTE after 12.2

Green chiller indicating light on control panel will come ON. Red indicating light will be OFF.

Green light OFF yes
Red light ON yes

- 20.4 Test T-8 control of CT-FAN at this point:
- 20.4.1 Set RC-8 control point dial to T-8 temperature readout on control panel (simulating T-8 transmitter sensor moving to RC-8 set point). RC-8 control point dial reads 84 °F
- When RC-8 control point dial indicates T-8 temperature CT-FAN will START. CT-FAN STARTS yes
- 20.4.2 Increase RC-8 control point dial 5°F (simulating T-8 temperature decreasing 5°F) causing CT-FAN to STOP. RC-8 control point dial reads 89 °F
- CT-FAN STOPS yes
- 20.4.3 Return RC-8 control point dial to 85°F set point RC-8 control point dial reads 85 °F
- 20.5 Decrease RC-3D control point dial 10°F (simulating T-3 temperature decreasing 10°F) causing PE-3D to deactuate. When PE-3D deactuates P-2 will stop, CV-4 actuator will move full distance towards diaphragm closing valve stopping HW circulation between HW storage tank and chiller which will be detected by FS-1 OPENING its contacts. FS-1 opening will stop P-3. Chiller will become disabled by R5 deactivating as chiller red indicating light on control panel will come ON and green go OFF.
- RC-3D control point dial reads 177 °F
- P-2 STARTS yes
- CV-4 actuator full towards body yes
- P-3 STARTS yes
- R5 ACTIVATES yes
- Green light ON yes
- Red light OFF yes
- 20.6 Return RC-3D control point dial to 180°F set point. RC-3D control point dial indicates 180 °F
- 20.7 Return RC-4 control point dial to 50°F set point. RC-4 control point dial indicates 50 °F
21. Test T-4 control of this subsystem:
- 21.1 Set RC-3D control point dial to T-3 temperature on readout on control panel. This will actuate PE-3D so that PE-4 can be monitored. RC-3D control point dial reads °F
- PE-3D ACTUATED yes

NOTE - Maintain PE-3D actuation by RE-SETTING RC-3D control point dial as required.

21.2	Note T-4 temperature on T-4 temperature readout on control panel.	T-4 temperature on control panel <u>54</u> °F
21.3	Set RC-4 control point dial to T-4 temperature from Step 21.2 (simulating T-4 transmitter sensor moving to RC-4 set point).

See Step 20.3 note for response.

See NOTE after 12.2 | RC-4 control point reads <u>59</u> °F

P-2 STOPPED <u>yes</u>
CV-4 actuator full
CLOSED <u>yes</u>
P-3 STOPPED <u>yes</u>
R5 DEACTUATES <u>yes</u>
Green light OFF <u>yes</u>
Red light ON <u>yes</u> |
| 21.4 | Decrease RC-4 control point dial 5° F (simulating T-4 temperature decreasing 5° F) causing PE-4 to deactuate. | RC-4 control point reads <u>54</u> °F

PC-2 STARTS <u>yes</u>
CV-4 actuator full
OPEN <u>yes</u>
P-3 STARTED <u>yes</u>
R5 ACTIVATES <u>yes</u>
Green light ON <u>yes</u>
Red light OFF <u>yes</u> |
21.5	Return RC-4 control point dial to 50° F set point.	RC-4 control point dial indicates <u>50</u> °F
21.6	Return RC-3D control point dial to 180° F set point.	RC-3D control point dial indicates <u>180</u> °F
21.7	NOTE - P-5 started through 'CT' contacts in and under control ARKLA chiller.	P-5 cycling <u>yes</u>

SEQUENCE OF OPERATION

FTU Solar Demonstration Project

SEQUENCE OF OPERATION

(1) SOLAR ENERGY COLLECTION, CONVERSION AND STORAGE

WHEN TEMPERATURE (T-1) AT THE SOLAR COLLECTORS EXCEEDS THE TEMPERATURE (T-2) AT THE HOT WATER STORAGE TANK BY 15°F, PNEUMATIC-ELECTRIC SWITCH (PE-2) WILL MAKE, ALLOWING PUMP (P-1) TO OPERATE. PUMP (P-1) WILL CONTINUE TO RUN UNTIL THE DIFFERENCE IN TEMPERATURES (T-1) AND (T-2) DROPS TO 5°F. WHEN (PE-2) BREAKS, TIMER 1 ACTIVATES. WHEN TIMER 1 TIMES OUT TIMER 2 IS ACTIVATED AND TIMER 1 IS RESET, RE-STARTING TIMING SEQUENCE. TIMER 2 OVERRIDES (PE-2) TO ACTIVATE PUMP (P-1) FOR SELECTED RUN TIME. (TIMER 2 SELECTS RUNNING TIME OF P-1; TIMER 1 SELECTS TIME BETWEEN RUNS) DURING NIGHT HOURS PHOTOCELL ENERGIZES RELAY (R-1) WHICH DE-ENERGIZES TIMERS. UPON RISE IN HOT WATER TEMPERATURE (T-3) ABOVE 230°F, PE SWITCH (PE-3A) WILL MAKE, OVERRIDING PE-2 AND TIMERS AND SHUTTING DOWN PUMP (P-1) UNTIL FALL IN (T-3) BELOW 225°F.

(2) EXCESS HEAT REJECTION

UPON RISE IN HOT WATER TEMPERATURE (T-3) ABOVE 235°F PE SWITCH (PE-3B) WILL CLOSE ENERGIZING PUMP (P-6) AND VALVE (CV-6) FOR EXCESS HEAT REJECTION UNTIL FALL IN (T-3) BELOW 230°F.

(3) ABSORPTION CHILLER, COOLING TOWER AND CHILLED WATER STORAGE

WITH THE CHILLER SELECTION SWITCH IN THE "AUTO" POSITION AND THE SYSTEM SELECTION SWITCH IN THE COOL POSITION THE FOLLOWING SEQUENCE IS ACTIVATED: UPON RISE IN HOT WATER TEMPERATURE (T-3) ABOVE 180°F AND RISE IN CHILLED WATER TEMPERATURE (T-4) ABOVE 50°F, PE SWITCHES (PE-3D) AND (PE-4) MAKE, OPENING VALVE (CV-4) TO ALLOW HOT WATER FLOW TO CHILLER AND ENERGIZING RELAY (R-4) WHICH ACTIVATES HOT WATER PUMP (P-2). THREE WAY CONTROL VALVE (CV-3) REGULATES THE FLOW OF

HOT WATER AS REQUIRED FOR CHILLER OPERATION TO PROVIDE A MINIMUM CHILLED WATER SUPPLY TEMPERATURE (T-5) OF 40°F. UPON RISE IN CONDENSER WATER TEMPERATURE (T-8) ABOVE 85°F PE SWITCH (PE-8) MAKES, ENERGIZING COOLING TOWER FAN UNTIL FALL IN (T-8) BELOW 80°F. UPON FALL IN HOT WATER TEMPERATURE (T-3) BELOW 170°F OR FALL IN CHILLED WATER TEMPERATURE (T-4) BELOW 45°F, PUMPS (P-2), (P-3), (P-5), CHILLER AND COOLING TOWER FAN ARE SHUT DOWN.

(4) AIR CONDITIONING SYSTEM CONTROL

WHEN SYSTEM SELECTION SWITCH IS IN COOL POSITION, UPON RISE IN CHILLED WATER TEMPERATURE (T-7) ABOVE 52°F, PE SWITCH (PE-7) WILL MAKE, ACTIVATING RELAY (R-2) WHICH ENABLES BACK-UP CHILLER TO OPERATE AND WHICH DE-ACTIVATES CHILLED WATER PUMP (P-4), STOPPING FLOW TO THE AHU. (PE-7), UPON RISE IN (T-7) ABOVE 52°F, ALSO DE-ACTIVATES PUMP (P-6) AND VALVE (CV-6) UNTIL FALL IN (T-7) BELOW 47°F. CONTROL VALVE (CV-5) IS MODULATED TO MAINTAIN A COLD DECK TEMPERATURE (T-6) OF 55°F.

(5) HEATING SYSTEM CONTROL

WHEN SYSTEM SELECTION SWITCH IS IN HEAT POSITION, UPON RISE IN HOT WATER TEMPERATURE (T-3) ABOVE 125°F, PE SWITCH (PE-3C) MAKES, ENERGIZING VALVES (CV-1A), (CV-1B), (CV-2) WHICH SWITCH THE AHU HOT WATER SOURCE FROM BOILER TO SOLAR HW STORAGE TANK. (PE-3C) ALSO ENERGIZES RELAY (R-3) WHICH ACTIVATES HW PUMP (P-2). (PE-3C) REMAINS ENERGIZED UNTIL FALL IN HOT WATER TEMPERATURE (T-3) BELOW 120°F. CONTROL VALVES (CV-1A), (CV-1B) AND (CV-2) ARE NORMALLY OPEN FOR FLOW OF HOT WATER THROUGH THE EXISTING BOILER SYSTEM.

(6) FREEZE PROTECTION CYCLE

WHEN COLLECTOR TEMPERATURE (T-1) FALLS BELOW 38°F PE SWITCH (PE-1) WILL BREAK, ENERGIZING PUMP (P-1) FOR FREEZE PROTECTION CYCLE UNTIL RISE IN (T-1) ABOVE 45°F.

(7) LOW WATER CUT-OFF SWITCHES

TWO MCDONNELL MILLER MODEL 150 LOW-WATER CUT-OFFS ARE PROVIDED AS INDICATED. ONE LOW WATER CUT-OFF SHALL PREVENT PUMP (P-1) AND (P-2) FROM OPERATING WHEN THE WATER LEVEL IN THE SOLAR HOT WATER STORAGE TANK IS BELOW THE CUT-OFF POINT. THE OTHER LOW WATER CUT-OFF WILL PREVENT PUMP (P-3), (P-4), AND (P-6) FROM OPERATING WHEN THE WATER IN THE CHILLED WATER TANK IS BELOW ITS CUT-OFF POINT.

P1	P2	P3	P4
ON ☐ AUTO	ON ☐ AUTO	ON ☐ AUTO	ON ☐ AUTO
OFF	OFF	OFF	OFF

RED ALARM
LIGHT (TYP)

GREEN RUN
LIGHT (TYP)

P5	P6	COOLING TOWER	CHILLER
ON ☐ AUTO	ON ☐ AUTO	ON ☐ AUTO	ON ☐ AUTO
OFF	OFF	OFF	OFF

HEATO COOL
OFF

CONTROL PANEL

TERMINAL BOARD

CONTROL PANEL
INTERIOR

AIR COMPRESSOR SIZING INFORMATION

In order to properly select an air compressor for use in our temperature control work, it is necessary to consider a number of factors prior to making your final decision. You must make sure that the compressor has the capacity required to provide the operation desired. The speed of the compressor to be selected is an important factor since there is a tendency of the compressors to heat up and you will encounter oil carryover problems at faster compressor speeds. This can be detrimental to the temperature controls unless you provide additional oil removal devices downstream from the compressor. You also must consider the electrical power available in order to provide the proper motor. This knowledge of electrical power available also is necessary if you are to provide starters, contactors or alternators.

Your selection should be based upon three main factors as follows:

1. Total system air requirement.
2. Percent of operating time of the compressor.
3. Size of air receiver.

In order to determine the total air requirement, it is necessary to add up the total air usage of all devices within the system. This air usage of each device is listed in Table 1. You will note that the air usage is listed in two ways. The first and most accurate method is to use the CIM (cubic inches per minute) figures listed for each device. By using these figures and determining the total CIM, you will be able to accurately calculate the required free CFM using the formula shown below Table 1. This free CFM is the actual quantity of air available from a given compressor and should not be confused with higher piston displacement CFM listed by some manufacturers.

QUANTITY	UNI-LINE NUMBER	FACTORY MODEL	CIM	TOTAL
	TP2210-015	T15	17	
	TP2210-016	T16	17	
	TP2212-018, -118	T18	15	
	TP2212-019, -119	T19	15	
	TP2214	T21	30	
	TP2216	T26	30	
	TP2218-031	T31	35	
	TP2218-032, -132 (16 PSI)	T32	17	
	TP2218-032, -132 (25 PSI)	T32	30	
	TP2220-053	T63	30	
	HP2230-010	H10	17	
	HP2230-018 (RA @ 20 PSIG)	H18	30	
	HP2230-018 (RA @ 20 PSIG)	H18	17	
	HP2232-052	H52	30	
	TP2232-053	H53	30	
	HP2234	H100	78	
	TP2240	T100	35	
	TP2242	T101	35	
	TP2244	T110	35	
	TP2246	T130	35	
	TP2248	T131	35	
	TP2250	T140	35	
8	TP2252	T150	40	240
	TP2254	T151	30	
	TP2260	T201	35	
	TP2262	T210	35	
	TP2264-701	T221	35	
	TP2264-711	T231	40	
	TP2298-060 (25 PSI)	T460	35	
	TP2298-060 (16 PSI)	T460	17	

SEE ADDITIONAL MODELS ON OTHER SIDE
PRINTED IN U.S.A.

TOTAL 240 CIM
240 (20 PSI)

QUANTITY	UNI-LINE NUMBER	FACTORY MODEL	CFM	TOTAL
1	TP2298-061	T461	75	
	TP2298-062 (20 PSI)	T462	75	
	PP2300	P300	35	
	PP2305	P305	35	
	PP2310	P310	35	35
	PP2315	P315	35	
	PP2321	PJ21	17	
8	PP2323	P323	30	
	PP2341	PJ41	35	280
	HP2353-001, 002, 003	H403	20	
	RP2354-051	H404-101	0	
	RP2354-052	H404-201	0	
	RP2356	H405	35	
	RP2360	H416	35	
	RP2364-211	H471	0	
	RP2372 (USED AS VOLUME BOOSTER)	H432-1	10	
	RP2372-351	H432-1	5	
	RP2372-352	H432-2	5	
	RP2372-001	H433	30	
	RP2374	H435	30	
	RP2376	H440	35	
	RP2380	H450	0	
	RP2386	H470	0	
	SP2390	S10	34	
	SP2392	S20	0	
	SP2394	S30	0	
	SP2396	S40	0	
	MP2452 (W/P2 POSITIONER)	M652	85	
	MP2453 (W/P2 POSITIONER)	M653	85	
	MP2454 (W/P2 POSITIONER)	M654	85	
	MP2453 (W/P2 POSITIONER)	M553	85	
	MP2454 (W/P2 POSITIONER)	M554	85	
	MP2455-011 (W/POSITIONER)	M555	85	
	VALVES		0	0
7	VALVES WITH P20-372 POSITIONER		85	
	FULTON SLYPHON DIVISION SINGLE PEN RECORDER		85	
	FULTON SLYPHON DIVISION - 2-PEN RECORDER		140	
	ASPIRATING BOX P20-695 & P20-696		10	
	DAMPER ACTUATOR WITHOUT POSITIONER		0	

TOTAL THIS PAGE 315

TOTAL PREVIOUS PAGE 240

TOTAL 555 CFM

CFM TOTAL CIM 0.32 CFM
% OPERATION = 1728

NOTE: PE Switches take 0 CFM

ROBERTSHAW CONTROLS CO. · UNI-LINE DIVISION · P.O. BOX 2000, 4190 TEMESCAL ST., CORONA, CA 91720

46

CIRCULATING PUMPS AND MOTORS

PUMP MOTOR DATA

	MODEL	FRAME	MANUF.	TYPE	SHAFT BEARING	CODE	OP BEARING	PHASE	HZ
P-1	M3558T	145T	Baldor	---	-----	K	----	3	60
P-2	HVJ145TTDR 7026CC-F1W	145T	Marathon	TDR-BE	77505	J	77503	3	60
P-3	HVN143TTDR 7026CC-F1W	143T	Marathon	TDR-b	205	K	203	3	60
P-4	HVN143TTDR 7026CC-F1W	143T	Marathon	TDR-B	205	K	203	3	60
P-5	6-322464-02	S182T	Gould	SC	206	J	204	3	60
P-6	5XBU019-E	---	G.E.	---	---	T	---	1	60
				DATA CON'T					
	V	A	RPM	S.F.	SERIAL	MAX AMB	INS	DUTY	HP
P-1	460	3.1	1725	1.15	35A01-872	^c 40 °C	B	Cont.	2
P-2	460	3	1735	1.15	1494989	^o 40 °C	B	Cont.	2
P-3	460	1.8	1735	1.15	1543225	^o 40 °C	B	Cont	1
P-4	460	1.8	1735	1.15	1543269	^o 40 °C	B	Cont	1
P-5	460	5	1745	1.15	U-9	^o 40 °C	B	Cont	3
P-6	115	3	1725	1.4	4385	^o 40 °C	A	Cont	1/8

PUMP DATA

	MODEL	FRAME	DATE	CAP (GPM)	FT. HEAD	M.H.P.	RPM	MFG
P-1	BB2008-7.9 B5BZCZTLO	B-5	3-79	30	65	--	1750	TACO
P-2	BB2008-73 B5B202TLO	B-5	3-79	90	45	2	1750	TACO
P-3	BB2006-5.5 A5B2B2TLO	A-5	3-79	60	25	1	1750	TACO
P-4	BB2006-5.8 5B2B2TLO	A-5	3-79	38	34	1	1750	TACO
P-5	BB2508-7.7 B5B2D2TLO	B-5	3-79	90	65	3	1750	TACO
P-6	---	---	---	---	---	---	---	TACO

WATER BALANCING DATA

	RATED GPM	MEASURED GPM	VALVE SETTING	DIFF. PRES. FEET WATER	VALVE SIZE	DIFF. PRES. FEET WATER	HEAD	MOTOR AMPS	RATED AMPS
P-1	3Ø	30	3½	22	2.5"	27		2.4	3.1
P-2	3Ø	35 (30 thru AHU)	6	5	3"	18		2.6	3.0
P-3	6Ø	54	6½	5	2.5"	10.5		1.4	1.8
P-4	4Ø	41	6½	17	2"	14		1.4	1.8
P-5	9Ø	90	4½	32	3"	27.5		4.4	5.0
P-6	--	--	--	--	--	--		2.7	3.0
Chiller (North)	9Ø	80	8	23	2"	--		--	--
Collector 1	5.Ø	5.0	2½	28	1"				
Collector 2	5.Ø	5.0	2½	28	1"				
Collector 3	5.Ø	5.1	2 3/4	25	1"				
Collector 4	5.Ø	5.0	2½	28	1"				
Collector 5 (South)	5.Ø	5.1	2¼	30	1"				
Collector 6	5.Ø	5.0	2 3/4	23	1"				

TACO

BASE MOUNTED CLOSE COUPLED PUMPS

**2008
1750-3450 RPM**

**SUBMITTAL
DATA**

SD 300-3-8

EFFECTIVE: JULY 31, 1974 SUPERSEDES: SD 300-3-8 dated 10/31/72

JOB: FLORIDA SOLAR ENERGY CENTER

CENT. CANAL, FLORIDA

DATE SUBMITTED: Dec. 12, 1974 BY: BLUMENAUER & ASS.

Location	Model No.	Pumpsiz	Impeller Size	GPM	Head	Voltage	Phase
P-1	BB2008	2"	7.90	30	65	480/3/0	?
P-2	BB2008	2"	7.90	90	45	480/3/0	?

SPECIFICATIONS

	STANDARD CONSTRUCTION			OPTIONS
Description	Ball Bearing	Sleeve Bearing	Close Coupled	
Frame	Ball Bearing	Sleeve Brng.	_____	_____
Coupler	4 Way Flex	4 Way Flex	_____	_____
Baseplate	Structural Steel	Structural Steel	_____	_____
Shaft-Pump	Alloy Stl	Alloy Stl	Alloy Stl (Mtr. Shaft)	☐ Stainless Steel
Mech. Seal	Permalife 1 (250F)	Permalife 1 (250F)	Permalife 1 (250F)	Permalite 2° (300F)
Stuffing Box	250F	_____	250F	☐ Yes
Bronze Gland w/ S.S. Studs & Nuts	with Stuff Box	with Stuff Box	with Stuff Box	_____
Shaft Sleeve	Cupro Nickle	Cupro Nickle	Cupro Nickle	☐ St. Steel w/ Stuff Box
Impeller	Cast Iron	Cast Iron	Cast Iron	☐ Cast Brz.
Special Imp. Cut	_____	_____	_____	☐ Yes
Motor, O.D.P. 60 cycle, 3 phase 230/460	☐ 1750 BB ☐ 3450 BB	1750 SB	☐ 1750 BB ☐ 3450 BB	☐
Purocell Filter	_____	_____	_____	☐ YES*
Coupler Guard	_____	_____	_____	☐ YES*
Brz. Const.	_____	_____	_____	☐ YES*
Comp. Flanges ASA	_____	_____	_____	_____
Bronze Wear Ring	_____	_____	_____	_____
Working Pressure	175PSI**	175PSI	175PSI	_____
Test Pressure	250 PSI	250 PSI	250 PSI	_____

*Not included in Standard Cost

**In accordance with ASA B16.1

SIZES AND DIMENSIONS

For Larger Performance Curves See Catalog No. 300-3-1

	Product No.	Motor RPM	Motor HP	Section & Dis. Conn.	G	C	K	F	B	J	H	A	D	X	N	M	E
Base Mounted	SB 2008	1750	1 1/2	2	12	27 3/4	9 1/2	4 3/4	26 3/4	3	5/8	6 3/4	4 1/8	8 1/2	6 1/8	12 1/8	33 3/4
	BB 2008		2 3/4														
Base Mounted	BB2008	3450	10	2	13	35 3/8	10 1/2	5 1/4	33 3/8	4	5/8	6 3/4	4 1/8	8 1/2	8 1/2	15	46 1/2
			15														
Base Mounted			20														
Close Coupled	CC2008	1750	1 1/2	2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	5/8	7	4 1/8	8 1/2	6	11 1/8	22 3/4
			2 3/4														
Close Coupled			10	2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	5/8	7	4 1/8	8 1/2	6	11 1/8	22 3/4
			15														
Close Coupled			20														
Close Coupled	CC2008	3450	10	2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	5/8	7	4 1/8	8 1/2	8 1/8	14 1/4	25 3/4
			15														
Close Coupled			20														

BASE MOUNTED AND CLOSE COUPLED PUMPS

2006
1750-3450 RPM

EFFECTIVE: JULY 31, 1974 SUPERSEDES: SD 300-3-7 dated 10/31/72

SD 300-3-7

JOB: FLORIDA SOLAR ENERGY CENTER

CANE CREEK VALLEY, FLORIDA

DATE SUBMITTED: Dec. 12, 1970 BY: BLUMENACHT & ASS.

SPECIFICATIONS

STANDARD CONSTRUCTION				OPTIONS
Description	Ball Bearing	Sleeve Bearing	Close Coupled	
Frame	Ball Bearing	Sleeve Brg.		
Coupler	4 Way Flex	4 Way Flex		
Baseplate	Structural Steel	Structural Steel		
Shaft-Pump	Alloy Stl	Alloy Stl	Alloy Stl (Mtr. Shaft)	☐ Stainless Steel
Mech. Seal	Permalife 1 (250F)	Permalife 1 (250F)	Permalife 1 (250F)	☐ Permalite 2* (300F)
Stuffing Box	250F	250F	250F	☐ Yes
Bronze Gland w/ 3.8. Studs & Nuts	with Stuff Box	with Stuff Box	with Stuff Box	
Shaft Sleeve	Cupro Nickel	Cupro Nickel	Cupro Nickel	☐ St. Steel w/ Stuff Box
Impeller	Cast Iron	Cast Iron	Cast Iron	☐ Cast Brz.
Special Imp. Cut				☐ Yes
Motor, O.D.P. 60 cycle, 3 phase 230/460	☐ 1750 DD ☐ 3450 DD	1750 SB	☐ 1750 BB ☐ 3450 BB	
Purecoll Filter				☐ YES
Coupler Guard				☐ YES
Brz. Const.				☐ YES
Comp. Flanges ASA				☐ YES
Bronze Wear Ring				☐ YES
Working Pressure	175PSI**	175PSI**	175PSI**	
Test Pressure	250 PSI	250 PSI	250 PSI	

*Not included in Standard Cost

**In accordance with ASA B16.1

SIZES AND DIMENSIONS

Location	Model No.	Pumpsize	Impeller Size	GPM	Head	Voltage	Phase
P-3	BB2006	2"	5.50	60	25	480/3/60	3/4 HP
P-4	BB2006	2"	5.90	38	34	480/3/60	1 HP

For Larger Performance Curves See Catalog No. 300-3-1

	Product No.	Motor RPM	Motor HP	Section & Dis. Conn.	G	C	K	F	B	J	H	A	D	X	N	M	E
BASE MOUNTED	SB2006	1750	1 1/2	2	12	27 3/4	8 1/4	4 3/4	26 1/2	3	3/4	6 3/4	4	7 1/2	6 1/4	12 1/4	33 5/8
	BB2006		3 5/8	2	12	27 3/4	8 1/4	4 3/4	26 1/2	3	3/4	6 3/4	4	7 1/2	6 1/4	12 1/4	35 5/8
	BB2006	3450	3 5/8	2	12	27 3/4	8 1/4	4 3/4	26 1/2	3	3/4	6 3/4	4	7 1/2	6 1/4	12 1/4	35 5/8
CLOSE COUPLED	CC2006	1750	1 1/2	2	10	6 1/4	5 1/4	4 1/4	4 1/2	1	3/4	6 3/8	4	7 1/2	6	10 3/4	21
	CC2006	3450	3 5/8	2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	3/4	6 3/8	4	7 1/2	7	11 1/4	22 23/24

TACO

BASE MOUNTED CLOSE COUPLED PUMPS

**2508
1750-3450 RPM**

EFFECTIVE: JULY 31, 1974 SUPERSEDES: SD 300-3-12 dated 10/31/72

**SUBMITTAL
DATA**

SD 300-3-12

JOB: FLORIDA SOLAR ENERGY CENTER

CORAL GABLES, FLORIDA

DATE SUBMITTED: DEC. 12, 1974 BY: BLUMENAU, J. S.

Location	Model No.	Pumpsize	Impeller Size	GPM	Head	Voltage	Phase
1-5	BB2508	2"	7.90	90	65	480/3/60	?

SPECIFICATIONS

Description	STANDARD CONSTRUCTION			OPTIONS
	Ball Bearing	Sleeve Bearing	Close Coupled	
Frame	Ball Bearing	Sleeve Brng.		
Coupler	4 Way Flex	4 Way Flex		
Baseplate	Structural Steel	Structural Steel		
Shaft-Pump	Alloy Stl	Alloy Stl	Alloy Stl (Mtr. Shaft)	☐ Stainless Steel
Mech. Seal	Permalife 1 (250F)	Permalife 1 (250F)	Permalife 1 (250F)	☐ Permalite 2* (300F)
Stuffing Box	250F		250F	☐ Yes
Bronze Gland w/ S.S. Studs & Nuts	with Stuff Box	with Stuff Box	with Stuff Box	
Shaft Sleeve	Cupro Nickle	Cupro Nickle	Cupro Nickle	☐ St. Steel w/ Stuff Box
Impeller	Cast Iron	Cast Iron	Cast Iron	☐ Cast Br.
Special Imp. Cut				☐ Yes checked below, fabrication MAY be undertaken. Approval does not authorize changes to Contract data unless stated in separate letter or change order.
Motor, O.D.P. 60 cycle, 3 phase 230/460	☐ 1750 BB ☐ 3450 BB	1750 SB	☐ 1750 BB ☐ 3450 BB	☐ YES* Approved/No Exceptions Taken ☐ YES* Approved As Is ☐ YES*
Purocell Filter				☐ YES*
Coupler Guard				☐ YES*
Brz. Const.				☐ YES*
Comp. Flanges ASA				☐ YES*
Bronze Wear Ring				☐ YES*
Working Pressure	175PSI**	175PSI**	175PSI**	
Test Pressure	250 PSI	250 PSI	250 PSI	

*Not Included in Standard Cost

**In accordance with ASA B16.1

SIZES AND DIMENSIONS

For Larger Performance Curves See Catalog No. 300-3-1

	Product No.	Motor RPM	Motor HP	Suction & Dis. Conn.	G	C	K	F	B	J	H	A	D	X	N	M	E
Base Mounted	SB 2508	1750	2	2 1/2	12	27 3/4	9 1/2	4 3/4	26 1/2	3	5/8	7 1/4	4 3/4	8	6 1/8	12 1/8	34 1/4
	BB 2508		3												7 1/2	13 1/8	34 3/8
			5												7 1/2	13 1/8	35 1/8
CLOSE COUPLED	BB2508	3450	15	2 1/2	13	35 3/8	10 1/2	5 1/4	33 3/8	4	5/8	7 1/4	4 3/4	8	8 1/8	15	41 1/8
			20												10 1/8	16 1/8	41 1/8
			25												10 1/8	16 1/8	43 3/8
CLOSE COUPLED	CC2508	1750	2	2 1/2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	5/8	7 1/8	4 3/4	8	6	11 7/8	27 3/8
			3												7	12 1/8	23 3/8
			5												7	12 1/8	24 3/8
CLOSE COUPLED	CC2508	3450	15	2 1/2	12	6 1/4	6 1/2	5 1/4	4 1/2	1	5/8	7 1/8	4 3/4	8	8 1/8	14 3/8	27 3/8
			20		14	13	10	6	10 3/4	1 1/4	3/4	7 1/8	4 3/4	8	10 1/8	16 3/8	30 3/8
			25		14	13	10	6	10 3/4	1 1/4	3/4	7 1/8	4 3/4	8	10 1/8	16 3/8	31 3/8

Job: **SOLAR HEATING & COOLING DEMONSTRATION PROJECT, FLA. SOLAR ENERGY CENTER**

Submittal Date: **BLUMENAUER AND ASSOCIATES**

By: **DECEMBER 12, 1973**

NUMBER

SD 100-15

Effective: March 15, 1978

Supersedes: SD 100-15

Dated 1/31/73

Location Pump Size Model Number GPM Head
P-6 1" 113B 20 8

110 RED BARON SERIES

ALL BRONZE, 115/1/60

110, 111, 112, 113, 117B, 120

CURVES

SPECIFICATIONS

- Motor — Resilient mounted, split phase Built-in overload protector.
- Body — Cast iron or bronze
- Impeller — One piece, dynamically balanced, non-ferrous
- Coupler — One piece, spring
- Shaft — Stainless steel
- Bearings — Bronze sleeve type
- Seal — Two piece, carbon/ceramic
- Standard flanges — Cast iron or bronze
- Shut-off flanges — Cast iron, bronze ball

SHOP DRAWING REVIEW

If checked below, fabrication MAY be undertaken. Approval does not authorize changes to Contract Specifications. Any changes shall be limited to those stated in separate letter or on Order.

DIMENSIONS

- () Approved/No Exceptions
() Approved As Noted/Comments

PRODUCT NUMBER	FLANGE SIZE	MOTOR	MAXIMUM TEMP.	PRESSURE RATING	DIMENSIONS								APPROX. SHIPPING WEIGHT	
					A		B		C		D			
					IN.	MM	IN.	MM	IN.	MM	IN.	MM	LBS	KG
110	1 1/2"	115V 60C 1 Ph	240° F	125 psi	14 1/4	371.5	12 1/2	320.7	7 1/4	200	6 1/2	162.0	20	9.1
111	1 1/2"	115V 60C 1 Ph	240° F	125 psi	16 1/4	412.8	13 3/4	352.4	10 1/4	260.4	8 1/4	222.3	26	11.8
112	1 1/2"	115V 60C 1 Ph	240° F	125 psi	16 1/4	419.1	14 1/4	368.3	7 1/4	200	6 1/2	162.0	20	9.1
113	1 1/2"	115V 60C 1 Ph	240° F	125 psi	16 1/4	412.8	14	355.6	10 1/4	257.2	8 1/4	215.9	27	12.2
117B	1" Sweat	115V 60C 1 Ph	240° F	125 psi	14	355.6	12 1/2	323.8	17 1/4	450.9	4 1/2	109.5	22	10
120	2"	115V 60C 1 Ph	240° F	125 psi	16 1/4	428.6	14 1/4	362	13 1/2	342.9	11	279.4	46	20.9

1. When specifying all bronze construction add letter "B" after product number, ie: 110B.
2. Motors are available with other electrical characteristics — consult your Taco representative.
3. 240° Intermittant; 200° Continuous.

Taco, Inc. 1160 Cranston Street, Cranston, RI 02905

Taco (Canada), Ltd. 3090 Lenworth Drive, Scarborough, Ontario M1S 1S1

ct'o Diffuser

TACO

C A T A L O G

400-5

EFFECTIVE: JUNE 15, 1973

SUPERSEDES: 400-5

Dated: January 15, 1973

SHOP DRAWING REVIEW

If checked below, fabrication MAY be undertaken. Approval does not authorize changes to Contract Sum unless stated in separate letter or Change Order.

() Approved/No Exceptions Taken

☒ Approved As Shown/Confirm

If checked below, fabrication MAY NOT be undertaken. Submit new or corrected drawings for review and approval. Correction shall be limited to items marked.

☒ Revise & Resubmit/Note Marking

() Rejected/Comments Attached

Reviewing is only for general conformance with the design concept of the Project and compliance with the information given in the Contract Documents. Markings or comments shall not be construed as relieving the Contractor from compliance with the project drawings and specifications or departures thereof. The Contractor is responsible for quantities and dimensions to be confirmed and correlated at the site; for details and accuracy; for information that pertains to the fabrication processes or to the means, methods, techniques, sequence, and order of construction; for coordination of the work of all trades and for the performance of all work in a safe manner.

STUTTER STAGE & ASSOCIATES, ARCHITECTS, ENGINEERS, PLANNERS, INC.

By

[Signature]

Date

[Signature]

TACO, INC.

CRANSTON, RHODE ISLAND 02920

TACO HEATERS OF CANADA, LTD.

MISSISSAUGA, ONTARIO, CANADA

SPACE SAVING

INCREASED PUMP EFFICIENCY from

Taco Suction Diffuser

Saves Space For optimum pump efficiency, provision for straight pipe or straightening vanes ahead of the pump is required. The Suction Diffuser is an elbow with integral straightening vanes.

Good design practice dictates a strainer ahead of each pump. An integral strainer is included.

Flexibility Suction Diffusers are available with equal or reduced flange sizes.

Start Up Protection A fine mesh throw away start up strainer is provided with the Suction Diffuser.

Permanent Strainer The permanent strainer provided has more free area than conventional strainers.

Serviceability Water flows from inside of the strainer to the outside, thus simplifying the cleaning and removal of the strainer.

The Suction Diffuser eliminates the need for:

1. Long entrance pipe
2. An elbow
3. Two Flanges
4. A conventional strainer
5. Three weld's
6. Gaskets and Bolting
7. Pipe Saddle
8. Pipe thread
9. Floor Flange

SPECIFICATIONS

BODY	Cast Iron
STRAIGHTENING VANES	Cast Iron
STARTUP STRAINER	Bronze
PERMANENT STRAINER	Stainless Steel
PRESSURE	up to 175 PSI in accordance with ASA B16.1
TEMPERATURE	up to 250°F

TYPICAL SPECIFICATIONS

Provide at each pump a Suction Diffuser Taco Model(s) of size and type shown on drawings. Units shall consist of an angle type body with inlet vanes and a combination Diffuser strainer with $\frac{3}{16}$ " diameter openings for pump protection. (Unit shall be equipped with a disposable fine mesh start up strainer which shall be removable after 30 days). FLOW DIRECTION SHALL BE FROM INSIDE THE STRAINER TO OUTSIDE FOR EASE OF SERVICE AND CLEANING. The body shall fit the pump and connecting pipe size. The unit shall be provided with an adjustable support foot to relieve piping strains from the pump suction. The contractor shall provide valved gauge connections at diffuser inlet and pump suction to indicate when cleaning is needed.

Dimensions

P-1, P-2, P-3, P-4 #350

P-5 #351

MODEL	SYSTEM	PUMP	C.V. Factor	Free Area Sq. In.	DIMENSIONS						Ship. Wgt. Lbs.
					A	B	C	D	H	J	
350	3 Flg.	2 Flg.	110	40	7 $\frac{1}{16}$ "	7 $\frac{3}{8}$ "	8 $\frac{1}{4}$ "	$\frac{3}{4}$ "	2 $\frac{3}{8}$ "	4 $\frac{5}{8}$ "	45
351	3 Flg.	2 $\frac{1}{2}$ Flg.	110	40	7 $\frac{1}{16}$ "	7 $\frac{3}{8}$ "	8 $\frac{3}{4}$ "	$\frac{3}{4}$ "	2 $\frac{3}{8}$ "	4 $\frac{5}{8}$ "	45
352	3 Flg.	3 Flg.	200	50	7 $\frac{1}{8}$ "	7 $\frac{3}{8}$ "	8 $\frac{1}{4}$ "	1	2 $\frac{5}{16}$ "	4 $\frac{1}{8}$ "	57
353	4 Flg.	3 Flg.	200	50	7 $\frac{1}{8}$ "	7 $\frac{3}{8}$ "	8 $\frac{1}{4}$ "	1	2 $\frac{5}{16}$ "	4 $\frac{1}{8}$ "	62
354	4 Flg.	4 Flg.	350	80	9 $\frac{9}{16}$ "	7 $\frac{1}{4}$ "	9 $\frac{1}{2}$ "	1	3 $\frac{1}{2}$ "	5 $\frac{3}{8}$ "	95
348	5 Flg.	4 Flg.	350	80	9 $\frac{9}{16}$ "	7 $\frac{1}{4}$ "	9 $\frac{1}{2}$ "	1	3 $\frac{1}{2}$ "	5 $\frac{3}{8}$ "	112
349	5 Flg.	5 Flg.	520	125	10	9 $\frac{1}{16}$ "	11 $\frac{7}{8}$ "	1	3	5 $\frac{3}{8}$ "	150
355	6 Flg.	4 Flg.	350	80	9 $\frac{9}{16}$ "	7 $\frac{1}{4}$ "	9 $\frac{1}{2}$ "	1	3 $\frac{1}{2}$ "	5 $\frac{3}{8}$ "	125
356	6 Flg.	5 Flg.	520	125	10	9 $\frac{1}{16}$ "	11 $\frac{7}{8}$ "	1	3	5 $\frac{3}{8}$ "	160
357	6 Flg.	6 Flg.	760	150	11	8 $\frac{3}{4}$ "	11 $\frac{7}{8}$ "	1	3	5 $\frac{5}{16}$ "	180
358	8 Flg.	6 Flg.	760	150	11	8 $\frac{3}{4}$ "	11 $\frac{7}{8}$ "	1	3	5 $\frac{5}{16}$ "	205
359	8 Flg.	8 Flg.	1000	275	11 $\frac{3}{4}$ "	13 $\frac{1}{16}$ "	16	1 $\frac{1}{4}$ "	2 $\frac{3}{4}$ "	5 $\frac{1}{4}$ "	280
370	10 Flg.	8 Flg.	1000	275	11 $\frac{3}{4}$ "	13 $\frac{1}{16}$ "	16	1 $\frac{1}{4}$ "	2 $\frac{3}{4}$ "	5 $\frac{1}{4}$ "	298

PRESSURE DROP CURVE

Pressure - up to 175 PSI in accordance with ASA B16.1

Temperature - up to 250° F.

FLOW RATE - GPM

NUMBER IS100-21

HORIZONTAL & VERTICAL CIRCULATORS

Nos. 110 thru 120 and all Vertical Models

EFFECTIVE: JULY 1, 1968

SUPERSEDES: IS100-21 DATED 10/1/65 AND
IS300-7 & 471503A

INSTRUCTION
SHEET

Blumenauer and Associates
Mechanical Equipment
207 E. Lancaster Road
Orlando, Fl. 32809
Phone-305-855-2111

TO REPLACE MOTOR

- 1— Disconnect wiring.
- 2— Loosen the two set screws at pump end of spring coupling, remove bolts between bracket and motor and separate.
- 3— Loosen other set screw of coupling and remove coupling from old motor.
- 4— Slide coupler with single set screw over new motor shaft and tighten against flat surface of shaft.
- 5— Place new motor assembly into bracket and replace bolts (also springs on Vertical Models).
- 6— Extend pump end of spring coupling over impeller shaft 3/16" Horizontal Models or 5/16" on Vertical Models and tighten both set screws. If impeller and shaft move into body during this operation, water will flow from weep hole in bracket. If this does occur, extend spring coupler a little more or until water stops flowing. CAUTION: UNDER NO CIRCUMSTANCES SHOULD THE WEEP HOLE BE PLUGGED.
- 7— Rewire motor.

TO REPLACE SPRING COUPLING

Follow same procedure outlined above.

REPLACING SEALS

Water flowing from weep hole in bracket normally indicates dirt on the seat or seal needs replacement. Before taking pump apart extend spring coupling and impeller shaft into body as far as it will go. This will separate the seal halves and permit a greater flow thru the weep hole and wash any foreign matter off the seats. Release and if flow stops, it indicates that the seals do not require replacement. If the flow does not stop, loosen the two set screws on the coupling and extend as far as it will go. If leak stops it means there was insufficient tension on the coupling. If leak continues, indications are that the seal needs replacement. Proceed as follows: —

- 1— Disconnect wiring.
- 2— Valve off or drain system.
- 3— Remove body bolts and pull entire assembly out of body.
- 4— Loosen the two set screws at pump end of spring coupler, file off any burrs on shaft and pull impeller and shaft from bracket.
- 5— Pry out old seal seat from bracket with a screwdriver and old part from impeller shaft with a pair of pliers.
- 6— Clean shaft and seal bearing surfaces thoroughly with clean cloth.
- 7— Dip CARBON part of seal in water to lubricate, place on top of impeller shaft with carbon facing up. Push down on shaft with palm of hand as far as it will go. Then with both thumbs push all the way down making certain that prongs engage the two holes in the impeller. If there are no holes in the impeller, break off the prongs with a pair of pliers and smooth burrs with a file.
- 8— Separate rubber from ceramic part, wet it and set into recess in bracket. Set ceramic seal into rubber with seat facing out by starting at a slight angle first, then pushing away and down simultaneously. The rubber ring should not be folded over during this operation. Make certain that both the rubber and ceramic are "bottomed" squarely.
- 9— Clean both seal surfaces with a clean lintless cloth.
- 10— Place a few drops of oil along the impeller shaft and push slowly with a twisting motion through ceramic part into bracket and spring coupling.
- 11— While holding impeller and shaft with seal faces mating, insert an Allen wrench into one of the set screws in the coupling, extend spring — 3/16" for Horizontal Models or 5/16" for Vertical Models and tighten set screw. Then tighten the second set screw.
- 12— Remove old body gasket, clean surfaces and replace with new gasket.
- 13— Place entire assembly into body, replace and tighten bolts gradually and evenly all around.
- 14— Refill system. If water leaks from weep hole in bracket increase tension on spring coupling slightly more or until leak stops.
- 15— Rewire motor.

*CAUTION: The addition of certain chemical additives to systems utilizing TACO Equipment, voids the warranty.

Taco Heaters of Canada, Ltd.
3090 Lenworth Drive
Cooksville, Ontario

TACO, INC. 1160 Cranston Street, Cranston, Rhode Island 02920

Printed in U.S.A.

A-INSTALLATION

A1-LOCATION

Locate pump in an easily accessible place with sufficient space around it for maintenance and servicing. On larger pumps allow head room for the use of hoists or overhead cranes. Locate pump on a dry and clean place so that motor will be protected from moisture and dust.

On closed heating systems place compression tank at the suction side of the pump. When pump head is less than 20 feet, it is permissible to connect compression tank to discharge side of pump.

On open systems, install pump close to liquid supply and make suction piping as short and as straight as possible.

A2-FOUNDATION

The foundation serves to carry the pump weight and to absorb vibration. Normally, the foundation is made of concrete block, preferably tied in with the floor or ground. Make the foundation block about 4" longer and 4" wider than the base of the frame. Height of the block may vary from $\frac{2}{3}$ to 1 times the width of the foundation (Fig. 1). When foundation is poured, provide a hole near each of the four (4) corners. To simplify installation and maintenance use lead Anchors. Place the front Anchor about 2" from the edge of the foundation to clear overhanging casings (Fig. 2).

Fig. 1—Foundation Block

Fig. 2—Foundation Bolt

A3-PIPING

Correct piping is of prime importance for the proper operation and long life of the pump. Stresses induced by piping will cause excessive wear of seals, bearings, and couplings that could ultimately destroy these elements.

Both suction and discharge piping should be suspended close to the pump connections, so that no pipe weight rests on the pump. Pipe flanges and pump flanges should align perfectly before connections are made, piping should never be drawn by force into place.

Thermal expansion of piping requires special attention on heating installations. If no room is provided for pipe expansion, stresses are induced in the piping that will exert a load on the pump. Forces created by pipe stresses can exceed by far the load exerted through pipe and water weight. Stress forces can distort pump, bend shafts, wear out seals, and impeller wear rings, and ultimately burn out bearings. To protect pump from thermal pipe stresses, provide spring hangers and flexible connectors that are suitable to compensate for pipe expansion. (See Fig. 3).

Install gate valves on both suction and discharge side of the pump to allow servicing without draining the system. Also provide a flanged nipple (spool) between gate valve and suction end of the pump to enable you to take the pump apart without disturbing piping (Fig. 3). In order to have them easily accessible, the pump and flange nipples should not be covered with insulation.

On open pumping systems drawing water from a level below the pump (suction lift) install a foot valve with strainer. On open systems where the pump is located below the suction water level (suction head) install a check valve in the discharge line close to the pump.

Fig. 3—Typical Installation—Vertical Piping

A—INSTALLATION—Continued

Fig. 3—Typical Installation—Horizontal Piping

A4-PUMP SETTING

When pump is set on its foundation, make sure to have it properly levelled. Place baseplate over foundation bolts provided for it, place shims at corners of baseplate when required and level with a spirit gauge. Tighten baseplate firmly to its foundations. Check also level of suction and discharge flanges.

A5-COUPLING ALIGNMENT

Proper alignment of pump and driver will assure trouble-free operation and long life of the pump. Misalignment will cause rapid wear of seals, couplings, and bearings. All pumps are carefully aligned before leaving the factory. However, experience indicates that alignment invariably changes in shipping and handling. Therefore, it is of utmost importance that alignment be checked at various steps of the installation process. i. e., after leveling, after piping, and after first few weeks of operation.

Check alignment by placing a slotted straight edge across the coupling halves at top, bottom, and at the sides. If any light is seen between the straight edge and one of the coupling flanges, it means the unit is out of alignment. (Fig. 4)

If light is seen at top and bottom position of the straight edge, alignment is out of height. Usually shims are placed under the motor feet. Loosen the four motor bolts, remove or add shims as required to correct proper height. Tighten the motor bolts and check to make sure alignment was corrected properly.

If alignment is out on the sides of the coupling, loosen the four motor bolts and lightly tap the motor in the direction required. Tighten the four motor bolts and check to make sure alignment was corrected properly.

As alignment in one direction may alter the alignment in another, be sure to check all alignments made.

Fig. 4—Coupling Alignment

A6-CONNECTING PIPING

Piping may now be connected to pump. Make sure that pump and pipe flanges are strictly parallel and properly spaced for the gasket that will be used. Also check that pipes are supported properly and do not rest on pump flanges. Never draw pipes by force to pump flanges. Re-check alignment after piping connections are made. If misalignment was caused by piping, it is a sign that pipe stresses distorted the pump. Correct piping to relieve stresses.

B—PUMP START-UP & OPERATION

Before starting up pump for the first time several items are to be checked to avoid damaging pump.

B1-LUBRICATION

Sleeve Bearing pumps are filled with oil at the factory but some oil might be lost during shipment. As a matter of precaution, check oil level before starting up pump. Proper level is at the center of the sight glass. If oil level is too low, remove top cover (Fig. 5) and refill.

Drain and refill oil well once a year. Initial filling is Socony Mobil DTE Heavy Medium Oil, but any premi-

Ball Bearing pumps are greased at the factory. Grease will not flow out during shipment, so no checking will be required at startup.

Regrease ball bearings every two years or 3,000 hours of operation. Initial filling is LUBRIKO-grease, Density M31, manufactured by Master Lubricants Company, Philadelphia.

Any general purpose ball bearing grease No. 3 NLGI (National Lubricating Grease Institute) hardness may be used.

To grease bearings open side covers (Fig. 5), slide

um SAE Grade 20 Non-Detergent Motor Oil can be used.

Motor bearings also might lose oil during shipment. Check oil level as indicated on motor instruction. Electric motors have either an oil cup or a pipe plug for filling. An overflow is located at the side of the bearing area. Before starting unit, fill motor bearing with an oil can until oil flows out of overflow.

them about 1/2" to the side and introduce grease through the opening with a putty knife. Fill grease chamber 2/3 high. Excessive grease causes unnecessary friction and will overheat bearing. If bearings run hot after regreasing, stop pump, open side cover, and wipe out excessive grease. Overheating will then cease.

Motor ball bearings also are greased at the factory. Grease should be replaced as indicated by motor manufacturer's instruction. Normally greasing is required every two years. On electric motors grease is usually introduced through a grease fitting with a grease gun.

B-PUMP START-UP & OPERATION-Continued

Fig. 5-Lubrication Points

B2-MOTOR WIRING & SENSE OF ROTATION

Check wiring of motor before starting to make sure that connections are wired properly for the voltage in use. Overvoltage can burn out motor windings. Check heater element in magnetic starter to see that it is rated the same as the motor.

Motor HP	AMP RATING FOR 3 PHASE SQUIRREL CAGE INDUCTION MOTORS			
	220 Volt		440 Volt	
	1750 RPM	3450 RPM	1750 RPM	3450 RPM
1/4	1.0	—	.5	—
1/3	1.4	—	.7	—
1/2	1.8	—	.9	—
3/4	2.4	2.2	1.2	1.1
1	3.6	3.4	1.8	1.7
1 1/2	4.8	4.6	2.4	2.3
2	6.2	5.6	3.1	2.8
3	9.0	8.0	4.5	4.0
5	14.4	13.4	7.2	6.7
7 1/2	20.0	19.2	10.0	9.6
10	26.4	25.6	13.2	12.8
15	39.0	38.0	19.5	19.0
20	51.0	50.0	25.5	25.0
25	62.0	60.0	31.0	30.0
30	74.0	72.0	37.0	36.0
40	96.0	—	48.0	—
50	120.0	—	60.0	—

Before attempting to check out sense of rotation of pump, fill pump with water to provide lubrication of the seal. Do not operate pump dry for motor checkout.

Next throw the switch and see if direction of rotation corresponds with arrows on frame of pump. The direction of rotation is counterclockwise facing the suction end of pump. Direction of rotation of three phase motors can be easily reversed by interchanging two of the three wires at the terminal board of the motor. Reversing of single phase motors is done by interchanging some internal wires or clamps. Instructions for reversing are found either on the motor nameplate or inside the motor terminal cover.

B3-PUMP START-UP

After you have checked lubrication and wiring you are ready to start the pump.

Open the gate valve in the suction side and close the valve on the discharge side. Start motor, wait until unit has come to full speed and then open discharge valve slowly. Do not run pump for more than a few minutes with completely shut valves. If system conditions call for part-time operation against shut valves, install a bypass line from discharge to suction.

B4-MECHANICAL SEAL

AND STUFFING BOX CARE

Mechanical Seal (See caution below)*

Mechanical seals are the most delicate component of the pump. Special care has to be given to them to assure trouble-free operation.

The sealing element of a mechanical seal consists of a carbon washer rotating against a stationary ceramic ring.

Surfaces of both are highly lapped to assure sealing.

Any dirt that penetrates between the two mating parts will cause a rapid wear of the seal faces and will ultimately result in seal leakage.

New heating systems are usually contaminated by various materials such as construction debris, weldingslugs, pipe joint compound, mill scale, etc. It is of utmost importance that such systems be cleaned out thoroughly before putting pump into continuous operation.

Cleaning of a heating system is simple and easy. First flush out system with cold water at city pressure to remove all loose foreign matter that penetrated into the system. Afterwards boil out system with chemicals to remove dirt adhering to pipes.

Chemicals most commonly used for this procedure are sodium triphosphate, sodium carbonate, or caustic soda, but any nonfoaming detergents as used in dishwashers can be applied.

Fill system with clean water, add cleaning chemicals (1 lb. for every 40 to 50 gallons of water, (or Mfrs. Instruction) start pump and heat up system. Let system run for a few hours, then drain and refill with fresh water. Your pumps are now ready for continuous duty. (See caution below).*

Stuffing boxes are less delicate in operation than mechanical seals. No chemical cleaning is necessary as on mechanical seal pumps, but flushing out with cold water is beneficial on this type of pump too.

After pump is started up adjust gland of stuffing box evenly so that it drips from one to three drops of water per minute. This drip is absolutely essential to prevent damage to packing and shaft sleeve. It also prevents overloading of motor. Excessive dripping may cause air to enter pump under certain conditions.

Sump of pump should be piped to any convenient sewer or drain. A pipe tapping is provided for this purpose at the side of the sump. Never plug this drain tapping.

*CAUTION: The addition of certain chemical additives to systems utilizing TACO Equipment, voids the warranty.

INSTALLATION OF EXTERNAL CIRCULATION TUBE

**Blumenauer and Associates
Mechanical Equipment
207 E. Lancaster Road
Orlando, Fl. 32809
Phone-305-855-2111**

IMPORTANT

Before filling system with water, assemble external circulation tube to pump casing as follows:

1. Screw nut into body until hand tight.
2. With a wrench continue tightening for about one and one-half full additional turns. (It is not necessary to tighten nut all the way down)

INSTALLATION OF PUROCELL FILTER

IMPORTANT

1. Attach Filter to the pump by loosening the top bolt on the frame and casing and slip bracket under bolt and tighten.
2. If Recirculating line is installed — remove from frame and insert this end into inlet of Filter.
3. Attach line from outlet of the filter to seal retainer cap.

TACO, INC.

1160 Cranston Street, Cranston, Rhode Island 02920

Printed in U.S.A.

NUMBER

IS 300-3-1

TACO "LP" SERIES

**BALL & SLEEVE BEARING BASEMOUNTED
AND CLOSE COUPLED**

EFFECTIVE: 2/1/73
SUPERSEDES: IS 300-3-1
dtd. 3/31/68

MAINTENANCE AND SERVICING

Plant I.D. No. 001-359

C1-GENERAL

Before undertaking any service work on the pump, read these instructions carefully to be readily prepared for the job. For your convenience TACO encloses with these instructions a list of replacement parts for each pump. Order parts required for maintenance work by listing item number, number required, description, and part number. Before taking pump apart, flange gaskets for pipe connections and a pump gasket kit should be available.

A step by step procedure of the most common maintenance jobs is given below. Follow it on the exploded views in the replacement parts list. In the description and on the drawings all parts are referred to by item numbers. To start any maintenance work stop pump and close suction and discharge lines. To gain access to internal parts of pump remove flanged nipple (spool piece) that has been provided on suction side of the pump.

If no freely removable piece is provided on suction side of pump, you can service the pump by disconnecting both suction and discharge flanges and removing the frame hold down bolts. The whole pump can now be moved for convenient servicing.

C2-REPLACING IMPELLER

Required replacement parts

Item No. 6	Impeller
Item No. 3	Suction Cover "O" Ring
1 Pair of	Pipe flange gaskets

DISASSEMBLY

Disconnect suction cover (1) by removing suction cover bolts (2).

Remove impeller bolt (4) with a socket or offset box wrench. Bolt has right hand thread. Place wrench over bolt head, hold wrench handle horizontally and hit handle end sharply with a plastic hammer. This should loosen bolt (Fig. 2). If this method is unsuccessful hold exposed section of motor shaft with a pipe wrench.

Remove Belleville Washer (66), impeller washer (5) and impeller spacer (18) (where used) together with impeller bolt (4).

Pull out impeller (6) and impeller key (7). The use of a wheel puller may be helpful in removing the impeller. If no wheel puller is available, insert impeller bolt (4) in shaft (42) and bring bolt head down on it. Hold a drift against the bolt head and hit it 2 or 3 times sharply with a hammer. This will normally loosen impeller from shaft (Fig. 3). Next insert two screwdrivers, one on each side in the grooving of the impeller wear rings and pry out, taking care not to damage the wear rings (Fig. 4). If any burrs develop smooth out with emery cloth.

Fig. 1 — Disassembly

Reassembly

Fig. 2 - Removing and Replacing Impeller Bolt

Fig. 3—Hitting on Drift—Impeller Bolt

Fig. 4 — Prying Out of Impeller

C2-REPLACING IMPELLER -Continued

REASSEMBLY

Clean shaft end (42) and key slot. Apply some grease or oil and insert key in key way.

Apply grease to wear rings on both sides of replacement impeller (6) and slide over shaft end.

Apply grease or oil to the threads of impeller bolt (4), slide Belleville washer (66), impeller washer (5) and spacer (18) (where used) over it. Insert bolt (4) into shaft (42) and tighten firmly down by hitting sharply with a hammer on wrench handle end (Fig. 2).

Replace suction cover "O" ring (3) on suction cover (1).

Reassemble suction cover (1) to casing (8) and tighten cover bolts (2) evenly.

C3-REPLACING SEAL

Required replacement parts

Item No. 29	Waterseal
Item No. 90	Gasket Kit
Item No. 9	Impeller Spacer (if badly worn)
Item No. 35	Sleeve (if badly worn)
1 pair of	Pipe flange gaskets
Item No. 26	Cooling jacket "O" ring (where applicable)
Item No. 33	Casing "O" ring (where applicable)

It is difficult to determine which concealed parts are worn so it is recommended that if the pump has been in operation for some length of time that these concealed parts (item 9 & item 35) are also available before dismantling pump.

DISASSEMBLY

Follow disassembling steps of impeller replacement, paragraph C 2. Disconnect (where applicable) cooling jacket (27) pipe connections. Remove seal retainer cap bolts (30) with a ratchet type socket wrench. On larger models a 12 point box wrench may also be used. Tap seal retainer cap (32) to loosen it and slide it back on the shaft.

Remove casing (8) from frame (15) by taking casing bolts (16) out. Cooling jacket (27) (where used) will slide out with casing (8). Pry cooling jacket (27) off casing (8) by inserting screwdrivers in the casing "O" ring (33) slot. Slide impeller spacer (9), sleeve (35) with waterseal (29) on it, sleeve gasket (67) and seal retainer cap (32) off the shaft (42).

Remove spring retainer ring and spring of the seal from sleeve (35). To remove rotating seal part from sleeve, place sleeve (35) chamfered side down on a horizontal surface, slide seal retainer cap (32) over top of sleeve (35) and push down with both hands (Fig. 5).

Remove stationary seal seat from seal retainer cap (32). cap (32).

Discard old seal parts (29), sleeve gasket (67) and paper cap gasket (28). Discard also impeller spacer (9) and sleeve (35) if badly worn. Where cooling jacket is used, replace casing—and cooling jacket "O" rings (26,33).

REASSEMBLY

Clean, if necessary, with fine emery cloth, exposed shaft end (42), sleeve (35), impeller spacer (9) and seal retainer cap (32). Clean also portions of casing (8) which came in contact with seal (29) and throttle bushing (10) which is pressed into casing.

Place new seal seat in seal retainer cap (32). For ease of assembly, wet O.D. of seat with water. Hold the seal retainer cap (32) with both hands and press down on the seat with thumbs. Push alternately left and right hand side (Fig.6). Another method of placing the seat is to put the cardboard disc of the seal packaging on the top of the seal seat and then push down on it with a hammer handle (Fig.7). After the seat is placed on the seal retainer cap (32), check on the back side to see that the seal seat is properly seated against the seal retainer cap shoulder.

Apply some grease or oil to exposed shaft end (42). Slide sleeve gasket (67) and sleeve (35) over shaft. Chamfered side of sleeve should point toward impeller end (Fig.8). Place cap gasket (28) on seal retainer cap (32) and accurately line up bolt holes. Two drops of oil or grease on the contact face of the cap and gasket will hold these parts temporarily together. Slide seal retainer cap (32) with seal seat and cap gasket (28) over the sleeve (35) as far as it will go. Be careful not to damage seal seat.

Wet I.D. of rotating seal part (29 rubber) with water. Slide it, carbon washer facing seal seat, over sleeve. (35) Push seal (29) all the way back until it gently touches the seat. Slide the seal spring over the sleeve followed by the spring retainer ring with the raised portion toward the spring (Fig.8).

Clean—where applicable—cooling jacket (27) and replace "O" rings (26 & 33). Place cooling jacket over back of casing (8).

Assemble casing (8) to frame (15) and firmly tighten casing bolts (16) alternately.

Fig. 5 — PRESSING SEAL OFF SLEEVE

Fig. 6 — PRESSING IN SEAL SEAT

Fig. 7 — PRESSING IN SEAL SEAT WITH HAMMER HANDLE

MAINTENANCE AND SERVICING

Fig. 8—Seal Arrangement on Shaft

C3—REPLACING SEAL—Continued

Place impeller spacer (9) on shaft (42) it will fit the space between throttle bushing (10) and shaft.

Next follow reassembly directions for impeller.

Before reassembling suction cover (1) insert the two side cap bolts (30) through seal retainer cap (32) and cap gasket (28) and slide them towards rear end of casing (8) (Fig. 9). Start bolts in threaded holes and take up cap evenly by turning bolt (30) alternately on each side. Do this operation very carefully in order not to break seal.

When cap reaches casing (8) insert also top and bottom bolt (30) and tighten all four alternately and evenly.

Reconnect (where applicable) cooling jacket (27) pipe connections.

Fig. 9 — Reassembling Seal Ret. Cap

C4—REPLACING PACKING

Remove packing gland nuts (24) and slide gland (23) back as far as it will go.

Remove all old packing rings (20) with a flexible packing hook or one made from a piano wire with a short sharp hook.

Replace with graphite impregnated asbestos rings by a reliable packing manufacturer. Packing ring sizes are as follows:

PUMP SIZE	NO. OF RINGS	RING SIZE		
		I.D.	O.D.	Thickness
1 1/4-5, 1 1/4-6, 1 1/2-5 1 1/2-6, 1 1/2-8, 2-5, 2-6 2 1/2-5, 2 1/2-6, 3-5, 3-6	4	1 1/4"	1 3/4"	3/8"
2-8, 2 1/2-8, 2 1/2-10, 3-8 4-6	5	1 1/4"	2"	3/8"
3-10, 4-8, 4-10, 4-12, 5-8 5-10, 5-12, 6-10	6	1 1/2"	2 1/4"	3/8"
6-12	5	2"	3"	1/2"

Solid rings should be split diagonally on one side. If a length of spiral packing is used, rings should be cut to ID's as shown above. Butts at joints should be made diagonally.

After rings (20) are ready to use, open first ring sufficiently to place around shaft (42) with opening at bottom and push into stuffing box chamber with the packing gland (23). Next, pull gland (23) back and insert next ring (20) with opening on top and again push into place with gland (23). Repeat this operation, alternating cuts in rings for the required number.

Slide gland (23) squarely up to the last packing ring (20) and hand tighten nuts (24) (Do not use a wrench at this time). Open discharge and suction valves. If packing does not leak or leaks slightly, pump may be started. If packing leaks excessively, tighten nuts (24) with a short wrench one or two turns, before starting pump. Permit more than normal (1 to 3 drops, per minute) leakage while pump is running for approximately 30 to 60 minutes. During this running in period, take up on the nuts (24) equally about one half (1/2) turn every five (5) minutes or so until at the end of the period you are getting a normal leak of 1 to 3 drops per minute. While pulling up on the nuts (24), make certain the gland (23) is being pulled up evenly.

INSTALLATION OF EXTERNAL CIRCULATION TUBE

IMPORTANT

Before filling system with water, assemble external circulation tube to pump casing as follows:

1. Screw nut into body until hand tight.
2. With a wrench continue tightening for about one and one-half full additional turns. (It is not necessary to tighten nut all the way down)

INSTALLATION OF PUROCELL FILTER

IMPORTANT

1. Attach Filter to the pump by loosening the top bolt on the frame and casing and slip bracket under bolt and tighten.
2. If Recirculating line is installed — remove from frame and insert this end into inlet of Filter.
3. Attach line from outlet of the filter to seal retainer cap.

TACO, INC.

1160 Cranston Street, Cranston, Rhode Island 02920

Printed in U.S.A.

REPLACEMENT PARTS LIST

REPLACEMENT PARTS FOR 110 through 120 CIRCULATORS 007, 195, and 102B

NUMBER

100PL-7

Effective: December 1, 1976
Supersedes: 100PL-7-775
dated 7/30/75

Lancaster and Associates
Mechanical Equipment
207 E. Lancaster Road
Orlando, Fl. 32809
Phone-305-855-2111

110 - 111 - 112 - 113 - 117B - 120

REFER TO 100RL-7 for LIST PRICES

PARTS FOR 110 to 120 CIRCULATORS

NAMEPLATE MODEL NO.	ITEM 8 BODY	ITEM 25 IMPELLER & SHAFT	ITEM 31 MOTOR	ITEM 74 BEARING BRACKET	ITEM 161 GASKETS
------------------------	----------------	--------------------------------	------------------	-------------------------------	---------------------

HC, 110, 110C	110-226RP ⁽¹⁾	110-207RP	110-223RP	110-361RP	110-127RP
HDH, 111, 111C	111-004RP	111-053RP	110-185RP	111-058RP	110-127RP
112	110-226RP	112-043RP	112-074RP	112-120RP	110-127RP
113	113-001RP	113-003RP	110-185RP	113-011RP	110-127RP
120-1 to 120-5	120-083RP	120-056RP	120-105RP	120-076RP	120-073RP
120-6 to 120-12	120-083RP	120-038RP	120-105RP	120-067RP	120-073RP

Replacement Parts Kits
Listed on this sheet fit
all models, 110 - 120
Circulators except as
noted.

112C	110-226RP	112-055RP	112-074RP	112-103BRP	110-127RP
113C	113-001RP	113-009RP	110-185RP	113-013RP	110-127RP
120C-1 to 120C-5	120-083RP	120-060RP	120-105RP	120-078RP	120-073RP
120C-6 to 120C-12	120-083RP	120-054RP	120-105RP	120-069RP	120-073RP

ITEM 29 -
Water Seal 110-275RP

ITEM 56 -
Coupler 110-008RP

ITEM -
Flange Set
K" 1" 1 1/4" 1 1/2"
Interchangeable.
Refer to Price Sheets
100-T or 100-W. For
120 models with 2 holes,
specify 1600-032BRP
for Bronze, 1600-032RP
for Cast Iron.
For 120 models with 4
holes, specify 120-044RP
for Cast Iron, 120-044BRP
for Bronze.

HCB, 110B	110-226BRP	110-207RP	110-223RP	110-362BRP	110-127RP
111B	111-044BRP	111-053RP	110-185RP	111-059RP	110-127RP
112B	110-226BRP	112-055RP	112-074RP	112-103BRP	110-127RP
113B	113-001BRP	113-009RP	110-185RP	113-012RP	110-127RP
117B	117-001BRP	110-207RP	110-223RP	110-362BRP	110-127RP
117B-S2, -S3	117-002BRP	110-207RP	110-223RP	110-262BRP	110-127RP
120B-1 to 120B-5	120-083BRP	120-060RP	120-105RP	120-077RP	120-073RP
120B-6 to 120B-12	120-083BRP	120-054RP	120-105RP	120-068RP	120-073RP

(1) For Model 110-JP, Part No. is 110-285RP Body Assembly

PARTS FOR 007 and 195 CIRCULATORS [1] FOR THREADED BODY, SPECIFY PART NO. 007-005RP
FOR FLANGED BODY, SPECIFY PART NO. 007-006RP

PART NO.	DESCRIPTION	PART NO. 007	PART NO. 195
3	Body Gasket Only	007-003RP	151-009RP
8	Body with Gasket	[1]	152-012RP
25	Impeller	152-071RP	152-071RP
31	Motor & Impeller	007-004RP	195-001RP
36	Flange Sets — Same as 110-113	Refer to 100-T or 100-W Price Sheet	
119	Capacitor Cover	007-001RP	152-041RP
120	Capacitor Only	007-002RP	Consult Factory
161	"O" Ring Gasket Kit	Not Available	152-111RP

PARTS FOR NO. 102 B CIRCULATOR

PART NUMBER	REPLACEMENT PART NUMBER	DESCRIPTION
8	102-001 RP	Body
29	100-059 RP	Seal Assembly
161	100-060 RP	Gasket Kit
31	102-002 RP	Motor Assembly
25	100-029 RP	Impeller Assembly

REPLACEMENT PARTS LIST

NUMBER
300PL2

Effective: December 1, 1976
Supersedes: 300PL2, 7/30/75

FOR FOLLOWING MODEL NOS.

BM or CC: 2-5 2-6 2½-5 2½-6 3-5 and 3-6

BM or CC: 2005 2006 2505 2506 3005 and 3006

SB or BB: 2005 2006 2505 2506 3005 and 3006

REPLACEMENT PARTS FOR:

Close Coupled (CC) Pumps • Base Mounted (BM) Pumps
Sleeve Bearing (SB) Pumps • Ball Bearing (BB) Pumps

WHEN SELECTING AND ORDERING PARTS, ALWAYS REFER TO SERIAL NUMBER ON NAME PLATE

—Example—

Item No.	No. Reqd.	DESCRIPTION	PART NO. PER PUMP SIZE						REMARKS
			2-5 2005	2-6 2006	2½-5 2505	2½-6 2506	3-5 3005	3-6 3006	
1	1	Suction Cover	917-003*	918-003	925-003*	926-003	930-003*	932-003	Add "B" after No. for Bronze
2		Suction Cover Bolt	10-230(4)	10-230(8)	10-230(4)	10-230(8)	10-230(4)	10-230(8)	3/8 - 16 x 1
3	1	Suction Cover 'O' Ring	903-005	918-005	903-005	918-005	903-005	918-005	
4	1	Impeller Bolt (SS)	10-258A	10-258A	N/A	N/A	N/A	N/A	3/8 - 16 x 5/8 St. Steel
4	1	Impeller Bolt (SS)	N/A	N/A	10-254A	10-254A	10-254A	10-254A	3/8 - 16 x 7/8 St. Steel
5	1	Impeller Washer	900-008	900-008	926-004	926-004	926-004	926-004	
6	1	Impeller	917-002*	918-002	925-002*	926-002	930-002*	932-002	Add "B" after No. for Bronze
7	1	Impeller Key (SS)	13-107A	13-107A	N/A	N/A	N/A	N/A	3/16 x 3/16 x 3/4 St. Steel
7	1	Impeller Key (SS)	N/A	N/A	13-105A	13-105A	13-105A	13-105A	3/16 x 3/16 x 1-1/8 St. Steel
8	1	Casing (1)	917-001*	918-001	925-001*	926-001	930-001*	932-001	Add "B" after No. for Bronze
16	4	Casing Bolt	10-201	10-201	10-201	10-201	10-201	10-201	3/8 - 16 x 1-1/8
17	1	Drain Plug	16-102	16-102	16-102	16-102	16-102	16-102	3/8 NPT Steel
18	1	Spacer	900-007	900-007	N/A	N/A	N/A	N/A	
34	1	Slinger Ring	900-040	900-040	900-040	900-040	900-040	900-040	For Close Coupled Only
34	1	Slinger Ring	900-044	900-044	900-044	900-044	900-044	900-044	For Base Mounted Only
66	1	Belleville Washer	900-053	900-053	900-053	900-053	900-053	900-053	
222	1	Fitting	900-566	900-566	900-566	900-566	900-566	900-566	
275	2	Fitting	900-798	900-798	900-798	900-798	900-798	900-798	
276	1	Tube	900-728	900-728	900-728	900-728	900-728	900-728	

(1) Throttle Bushing (Item 10) found in Seal Section must be ordered with each casing.

* No longer available, consult factory for replacement

TACO, Inc., 1160 Cranston Street, Cranston, Rhode Island 02920 U.S.A. Tel: (401) 942-8000 Telex: 92-7627

Taco Heaters of Canada, Ltd., 3090 Lenworth Drive, Mississauga, Ontario Tel: (416) 625-2160 Telex: 06-961179

FRAME SIZE & STYLE — 0000-00-XX00

- A1 BALL BEARING DESIGN:** Update pump with 820-795RP Complete frame assembly. Please furnish all nameplate data to insure proper updated nameplate.
- A2 SLEEVE BEARING DESIGN:** Update pump with 820-797RP Complete frame assembly. Please furnish all nameplate data to insure proper updated nameplate.
- A3 SLEEVE BEARING DESIGN:** Update pump with 820-797RP Complete frame assembly. Please furnish all nameplate data to insure proper updated nameplate.

A5 BALL BEARING DESIGN:

Item No.	No. Req.	DESCRIPTION	PART NO.	REMARKS
74	1	Frame Assembly (complete)	820-795RP	
15	1	Frame	820-786	
42	1	Shaft	820-785	Add SS for Stainless Steel
50	1	Bearing Plate Gasket	820-791	
52	4	Bearing Plate Bolt	10-230	3/8 - 16 x 1
59	2	Drain Plug	16-111C	1/8 NPT Brass
63	1	Ball Bearing	820-784	
82	1	Ball Bearing	820-067	
191	1	Retainer Ring	15-103	
289	1	Bearing Cover Plate Assy.	820-788	
290	2	Lubrication Fitting	15-200	

A6 SLEEVE BEARING DESIGN:

Item No.	No. Req.	DESCRIPTION	PART NO.	REMARKS
74	1	Frame Assembly (complete)	820-797RP	
14	1	Pipe Plug	16-102	3/8 NPT Steel
42	1	Shaft	820-048	
44	1	Cone Point Set Screw	10-310	5/16 - 18 x 3/8 Steel
45	1	Cup Point Set Screw	10-301	5/16 - 18 x 5/16 Steel
46	1	Thrust Collar	820-423	
50	1	Bearing Plate Gasket	820-791	
54	1	Oil Seal	840-129	
59	1	Drain Plug	16-111C	1/8 NPT Brass
84	1	Frame Sub Assembly	820-798	
85	2	Thrust Washers	820-052	
86	1	Bearing Support Assembly	820-058	

MECHANICAL SEAL

PACKING

TYPE B STANDARD. TYPE D HI-TEMP. TYPE P PACKED. TYPE E CERAMIC.

Item No.	No. Reqd.	DESCRIPTION	SEAL OR PACKING DESIGN			REMARKS
			Type "B"	Type "D"	Type "P"	
3	1	Suction Cover 'O' Ring	See Page 1			
9	1	Impeller Spacer	900-026	900-026	Not Used	
10	1	Throttle Bushing	900-009	900-009	903-009	
20	1	Packing Set			900-240	
22	1	Filler Ring (Not shown)	Not Used	Not Used	905-007	
23	1	Gland			903-008	Add Suffix 'B' for Bronze
24	2	Hex Nuts			12-129	3/8 - 16
28	1	Retainer Cap Gasket	900-011	900-011		
29	1	Water Seal (1)	900-024	900-087		
91	1	WATER SEAL KIT (1)	840-128BRP	840-128DRP	Not Used	Incl. Items 28, 29, 35 & 67
30	4	Retainer Cap Bolts	10-208	10-208		3/8 - 16 x 7/8
32	1	Seal Retainer Cap	900-025	900-025		
35	1	Sleeve	900-027B	900-027B	920-006	
67	1	Sleeve Gasket	920-007	920-007	920-007	
21	2	Stud	Not Used	Not Used	900-029	

(1) For Ceramic Seal, order 900-215 or 840-128 ERP Kit.

CLOSE COUPLED (CC)

CC FRAMES ----- A4

NEMA FRAME Size "T"	NEMA FRAME Size "U"	ITEM 13 FR. BOLT Part No.	ITEM 13 FRAME BOLT Size	ITEM 15 PUMP FRAME
	48	10-201	(4) 3/8 - 16 x 1-1/8	900-001
	56	10-201	(4) 3/8 - 16 x 1-1/8	900-001
143	182	10-201	(4) 3/8 - 16 x 1-1/8	900-001
145	184	10-201	(4) 3/8 - 16 x 1-1/8	900-001
182	213	10-201	(4) 3/8 - 16 x 1-1/8	900-001
184	215	10-201	(4) 3/8 - 16 x 1-1/8	900-001
213	254	10-201	(4) 3/8 - 16 x 1-1/8	900-001
215	256	10-201	(4) 3/8 - 16 x 1-1/8	900-001

MOTOR PARTS — NOT PART OF SERIAL NUMBER
—Motor Frame Sizes Must be Specified When Ordering Parts Shown Below—

Blumenauer and Associates
Mechanical Equipment
 207 E. Lancaster Road
 Orlando, Fl. 32809
 Phone-305-855-2111

Item No.	No. Reqd.	DESCRIPTION	MOTOR FRAME SIZE (NEMA STD.) 'T'						REMARKS
			143-145	182	184	213-215	254	256	
65	1	Base Plate (1.)	820-090	820-090	820-090	820-109	820-109	820-109	Steel
77	2	Spacer	820-098	820-003	820-004	N/A	N/A	N/A	
78	2	Frame Spacer	N/A	N/A	N/A	N/A	N/A	N/A	
56	1	Coupler	900-193	900-206	900-206	900-195	900-197	900-197	
38	4	Motor Lock Washer	14-104	N/A	N/A	N/A	N/A	N/A	5/16
38	4	Motor Lock Washer	N/A	14-101	14-101	14-101	N/A	N/A	3/8
38	4	Motor Lock Washer	N/A	N/A	N/A	N/A	14-100	14-100	7/16
62	4	Frame Lock Washer	14-102	14-102	14-102	14-102	14-102	14-102	1/2
13	4	Motor Hex. Hd. Bolt	10-251	N/A	N/A	N/A	N/A	N/A	5/16 - 18 x 1 1/4
13	4	Motor Hex. Hd. Bolt	N/A	10-221	10-221	10-221	N/A	N/A	3/8 - 16 x 1 1/4
13	4	Motor Hex. Hd. Bolt	N/A	N/A	N/A	N/A	10-202	10-202	7/16 - 14 x 1 1/4
61	4	Frame Hex. Hd. Bolt	10-238	10-238	10-238	10-238	N/A	N/A	1/2 - 13 x 1-5/8
61	4	Frame Hex. Hd. Bolt	N/A	N/A	N/A	N/A	10-217	10-217	1/2 - 13 x 2 1/4
79	4	Spacer Hex. Hd. Bolt	10-230	10-230	10-230	N/A	N/A	N/A	3/8 - 16 x 1
55	1	Coupler Key	13-100	13-100	13-100	13-100	13-100	13-100	1/4 x 1/4 x 1 1/2
47	1	Coupler Guard	820-796	820-796	820-796	820-796	820-796	820-796	
48	4	C.G. Rd. Hd. Screw	10-400	10-400	10-400	10-400	10-400	10-400	1/4 - 20 x 3/8
111	1	Coupler Insert	900-512	900-512	900-512	900-513	900-514	900-514	

(1) Add "A" to base plate number when coupler guard is to be used

Item No.	No. Reqd.	DESCRIPTION	MOTOR FRAME SIZE (NEMA STD.) 'U'						REMARKS
			56	182	184	213-215	254	256	
65	1	Base Plate (1.)	820-090	820-090	820-090	820-109	820-109	820-109	Steel
77	2	Spacer	820-103	820-003	820-004	N/A	N/A	N/A	
78	2	Frame Spacer	N/A	N/A	N/A	N/A	N/A	N/A	
56	1	Coupler	900-192	900-193	900-193	900-206	900-195	900-195	
38	4	Motor Lock Washer	14-104	N/A	N/A	N/A	N/A	N/A	5/16
38	4	Motor Lock Washer	N/A	14-101	14-101	14-101	N/A	N/A	3/8
38	4	Motor Lock Washer	N/A	N/A	N/A	N/A	14-100	14-100	7/16
62	4	Frame Lock Washer	14-102	14-102	14-102	14-102	14-102	14-102	1/2
13	4	Motor Hex. Hd. Bolt	10-251	N/A	N/A	N/A	N/A	N/A	5/16 - 18 x 1 1/4
13	4	Motor Hex. Hd. Bolt	N/A	10-221	10-221	10-221	N/A	N/A	3/8 - 16 x 1 1/4
13	4	Motor Hex. Hd. Bolt	N/A	N/A	N/A	N/A	10-202	10-202	7/16 - 14 x 1 1/4
61	4	Frame Hex. Hd. Bolt	10-238	10-238	10-238	10-238	N/A	N/A	1/2 - 13 x 1-5/8
61	4	Frame Hex. Hd. Bolt	N/A	N/A	N/A	N/A	10-217	10-217	1/2 - 13 x 2 1/4
79	4	Spacer Hex. Hd. Bolt	10-230	10-230	10-230	N/A	N/A	N/A	3/8 - 16 x 1
55	1	Coupler Key	13-100	13-100	13-100	13-100	13-100	13-100	1/4 x 1/4 x 1 1/2
47	1	Coupler Guard	820-796	820-796	820-796	820-796	820-796	820-796	
48	4	C.G. Rd. Hd. Screw	10-400	10-400	10-400	10-400	10-400	10-400	1/4 - 20 x 3/8
111	1	Coupler Insert	900-512	900-512	900-512	900-512	900-513	900-513	

(1) Add "A" to Base Plate Number when Coupler Guard is to be used.

REPLACEMENT PARTS LIST

Effective: December 1, 1976
Supersedes: 300PL3, 7/30/75

FOR FOLLOWING MODEL NUMBERS:

BM or CC: 2-8 2½-8 2½-10 3-8 & 4-6
BM or CC: 2008 2010 2012 2508 2510 3008 & 4006
SB or BB: 2008 2010 2012 2508 2510 3008 & 4006

WHEN SELECTING AND ORDERING PARTS, ALWAYS REFER TO SERIAL NUMBER ON NAME PLATE

—Example—

BASIC PARTS

Item No.	No. Reqd.	DESCRIPTION	PART NO. PER PUMP SIZE						
			2-8 2008	2-10 2010	2-12 2012	2½-8 2508	2½-10 2510	3-8 3008	4-6 4006
1	1	Suction Cover (1)	920-003	883-003	884-003	928-003	922-003	934-003	938-003
2	8	Suction Cover Bolts	10-216	10-211	10-211	10-216	10-211	10-216	10-230
3	1	Suction Cover 'O' Ring	912-005	862-005	868-004	912-005	862-005	912-005	918-005
4	1	Impeller Bolt (SS)	10-257A	10-259A	10-259A	10-257A	10-257A	10-257A	10-257A
5	1	Impeller Washer	926-004	926-004	926-004	926-004	926-004	926-004	926-004
6	1	Impeller (1)	920-002	883-002	884-002	928-002	922-002	934-005	938-002
7	1	Impeller Key (SS)	13-104A	13-105A	13-105A	13-104A	13-104A	13-104A	13-104A
8	1	Casing (1) (2)	920-001	883-001	884-001	928-001	922-001	934-001	938-001
16	4	Casing Bolt	10-201	10-201	10-201	10-201	10-201	10-201	10-201
17	1	Drain Plug	16-102	16-104	16-104	16-102	16-102	16-102	16-102
34	1	Slinger Ring (3)	900-040	N/A	N/A	900-040	900-040	900-040	900-040
34	1	Slinger Ring (4)	900-044	900-044	900-044	900-044	900-044	900-044	900-044
66	1	Belleville Washer	900-053	900-053	900-053	900-053	900-053	900-053	900-053
222	1	Fitting	900-566	900-566	900-566	900-566	900-566	900-566	900-566
275	2	Fitting	900-798	900-798	900-798	900-798	900-798	900-798	900-798
276	1	Tube	900-728	900-728	900-728	900-728	900-728	900-728	900-728

(1) Add "B" after No. for Bronze.

(2) Throttle Bushing (Item 10), found in Seal Section, must be ordered with each casing.

(3) For Close Coupled Only.

(4) For Base Mounted Only.

FRAME SIZE & STYLE – 0000-00-XX00

- B1 BALL BEARING DESIGN:** Update pump with 840-124RP Complete Frame Assembly. Please furnish all nameplate data to insure proper updated nameplate.
- B2 SLEEVE BEARING DESIGN:** Update pump with 840-110RP Complete Frame Assembly. Please furnish all nameplate data to insure proper updated nameplate.
- B3 SLEEVE BEARING DESIGN:** *Same as B2 design.*

B5 BALL BEARING DESIGN:

Item No.	No. Req.	DESCRIPTION	PART NO.	REMARKS
74	1	Frame Assembly (complete)	840-124RP	
15	1	Frame	840-111	
42	1	Shaft	840-113	Add SS for Stainless Steel
50	1	Bearing Plate Gasket	840-123	
52	4	Bearing Plate Bolt	10-230	3/8 - 16 x 1
59	2	Drain Plug	16-111C	1/8 NPT Brass
63	1	Ball Bearing	840-114	
82	1	Ball Bearing	840-071	
191	1	Retainer Ring	15-105	
289	1	Bearing Cover Plate Assembly	840-120	
290	2	Lubrication Fitting	15-200	

B6 SLEEVE BEARING DESIGN:

Item No.	No. Req.	DESCRIPTION	PART NO.	REMARKS
74	1	Frame Assembly (complete)	840-110RP	
14	1	Pipe Plug	16-102	3/8 NPT Steel
42	1	Shaft	820-048	Add SS for Stainless Steel
44	1	Cone Point Set Screw	10-310	5/16 - 18 x 3/8 Steel
45	1	Cup Point Set Screw	10-301	5/16 - 18 x 5/16 Steel
46	1	Thrust Collar	820-423	
50	1	Bearing Plate Gasket	840-123	
54	1	Oil Seal	840-129	
59	1	Drain Plug	16-111C	1/8 NPT Brass
84	1	Frame Sub Assembly	840-126	
85	2	Thrust Washers	820-052	
86	1	Bearing Sub Assembly	840-069	

MECHANICAL SEAL

PACKING

TYPE B STANDARD. TYPE D HI-TEMP. TYPE P PACKED. TYPE E CERAMIC.

Item No.	No. Req'd.	DESCRIPTION	SEAL OR PACKING DESIGN			REMARKS
			Type 'B'	Type 'D'	Type 'P'	
3	1	'O' Ring	See Page 1			
9	1	Impeller Spacer	900-026	900-026	Not Used	
10	1	Throttle Bushing	920-016	920-016	920-008	
20	1	Packing Set			900-241	
21	2	Studs			900-029	
22	1	Filler Ring (Not shown)	Not Used	Not Used	900-030	
23	1	Gland			920 015	Add "B" after No. for Bronze
24	2	Hex Nuts			12-129	3/8 - 16
28	1	Retainer Cap Gasket	920-014	920-014		
29	1	Water Seal (1)	900-024	900-087		
91	1	WATER SEAL KIT (1)	830-128BRP	840-128DRP	Not Used	Includes Items 28, 29, 35 & 67
30	4	Retainer Cap Bolts	10-208	10-208		3/8 - 16 x 7/8
32	1	Seal Retainer Cap	920-020	920-020		
35	1	Sleeve	900-027B	900-027B	920-006	
67	1	Sleeve Gasket	920-007	920-007	920-007	

(1) For Ceramic Seal, order 900-215 or 840-128 ERP Kit.

CLOSE COUPLED (CC) FRAMES ----- B4

NEMA FRAME Size "T"	NEMA FRAME Size "U"	ITEM 13 FR. BOLT Part No.	ITEM 13 FRAME BOLT Size	ITEM 15 PUMP FRAME
	48	10-223	(4) 1/2 - 13 x 1 1/4	920-004
	56	10-223	(4) 1/2 - 13 x 1 1/4	920-004
143	182	10-223	(4) 1/2 - 13 x 1 1/4	920-004
145	184	10-223	(4) 1/2 - 13 x 1 1/4	920-004
182	213	10-223	(4) 1/2 - 13 x 1 1/4	928-004
184	215	10-223	(4) 1/2 - 13 x 1 1/4	928-004
213	254	10-223	(4) 1/2 - 13 x 1 1/4	928-004
215	256	10-223	(4) 1/2 - 13 x 1 1/4	928-004
254	285	10-223	(4) 1/2 - 13 x 1 1/4	928-004T 900-126U
256	286	10-223	(4) 1/2 - 13 x 1 1/4	928-004T 900-126U
284		10-223	(4) 1/2 - 13 x 1 1/4	900-126

MOTOR PARTS — NOT PART OF SERIAL NUMBER
—Motor Frame Sizes Must be Specified When Ordering Parts Shown Below —

Blumenauer and Associates
Mechanical Equipment
207 E. Lancaster Road
Orlando, Fl. 32809
Phone-305-855-2111

Item No.	No. Reqd.	DESCRIPTION	MOTOR FRAME SIZE (NEMA STD.) 'T'										REMARKS
			143-145T	182T	184T	213T	215T	254T	256T	284T	284TS	286TS	
65	1	Base Plate (1)	820-090	820-090	820-090	820-109	820-109	820-109	820-109	820-790	820-790	820-790	
77	2	Spacer	840-098	840-003	840-004	840-005	840-006	840-041	840-040	N/A	N/A	N/A	
78	2	Frame Spacer	N/A	N/A	N/A	N/A	N/A	N/A	N/A	840-106	840-106	840-106	
56	1	Coupler	900-193	900-206	900-206	900-195	900-195	900-197	900-197	900-538	900-197	900-199	
38	4	Mtr. Lck. Wshr.	14-104	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5/16
38	4	Mtr. Lck. Wshr.	N/A	14-101	14-101	14-101	14-101	N/A	N/A	N/A	N/A	N/A	3/8
38	4	Mtr. Lck. Wshr.	N/A	N/A	N/A	N/A	N/A	14-100	14-100	14-100	14-100	14-100	7/16
62	4	Frm. Lck. Wshr.	14-102	14-102	14-102	14-102	14-102	14-102	14-102	14-102	14-102	14-102	1/2
13	4	Mtr. Hx. Hd. Blt.	10-254	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5/16-18x1 1/4
13	4	Mtr. Hx. Hd. Blt.	N/A	10-221	10-221	10-221	10-221	N/A	N/A	N/A	N/A	N/A	3/8-16x1 1/4
13	4	Mtr. Hx. Hd. Blt.	N/A	N/A	N/A	N/A	N/A	10-209	N/A	N/A	N/A	N/A	7/16-14x1 1/2
13	4	Mtr. Hx. Hd. Blt.	N/A	N/A	N/A	N/A	N/A	N/A	10-202	10-202	10-202	10-202	7/16-14x1 1/4
61	4	Fr. Hex. Hd. Blt.	10-238	10-238	10-238	10-238	10-238	10-238	10-238	N/A	N/A	N/A	1/2-13x1 5/8
61	4	Fr. Hex. Hd. Blt.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10-217	10-217	10-217	1/2-13x2 1/2
79	4	Spr. Hx. Hd. Blt.	10-230	10-230	10-230	10-230	10-230	N/A	N/A	N/A	N/A	N/A	3/8-16x1
55	1	Coupler Key	13-100	13-100	13-100	13-100	13-100	13-100	13-100	13-100	13-100	13-100	1/4x1/4x1 1/2
47	1	Coupler Guard	820-796	820-796	820-796	820-796	820-796	820-796	820-796	820-796	820-796	820-796	
48	4	CG. RdHd. Scw.	10-400	10-400	10-400	10-400	10-400	10-400	10-400	10-400	10-400	10-400	1/4-20x3/8
111		Coup. Insert	900-512	900-512	900-512	900-513	900-513	900-514	900-514	900-515	900-514	900-515	

(1) Add "A" to base plate number when coupler guard is to be used.

Item No.	No. Reqd.	DESCRIPTION	MOTOR FRAME SIZE (NEMA STD.) 'U'						REMARKS
			182U	184U	213U	215U	254U	256U	
65	1	Base Plate (1)	820-090	820-090	820-109	820-109	820-109	820-109	
77	2	Spacer	840-003	840-004	840-005	840-006	840-041	840-040	
78	2	Frame Spacer	N/A	N/A	N/A	N/A	N/A	N/A	
56	1	Coupler	900-193	900-193	900-206	900-206	900-195	900-195	
38	4	Motor Lock Wshr.	14-101	14-101	14-101	14-101	N/A	N/A	3/8
38	4	Motor Lock Wshr.	N/A	N/A	N/A	N/A	14-100	14-100	7/16
62	4	Frame Lock Wshr.	14-102	14-102	14-102	14-102	14-102	14-102	1/2
13	4	Mtr. Hx. Hd. Bolt	10-221	10-221	10-221	10-221	N/A	N/A	3/8 - 16 x 1 1/4
13	4	Mtr. Hx. Hd. Bolt	N/A	N/A	N/A	N/A	10-209	10-209	7/16 - 14 x 1 1/2
61	4	Frm. Hx. Hd. Bolt	10-238	10-238	10-238	10-238	10-238	10-238	1/2 - 13 x 1 5/8
79	4	Spr. Hx. Hd. Bolt	10-230	10-230	10-230	10-230	N/A	N/A	3/8 - 16 x 1
55	1	Coupler Key	13-100	13-100	13-100	13-100	13-100	13-100	1/4 x 1/4 x 1 1/2
47	1	Coupler Guard	820-796	820-796	820-796	820-796	820-796	820-796	
48	4	C.G. Rd. Hd. Scrw.	10-400	10-400	10-400	10-400	10-400	10-400	1/4 - 20 x 3/8
111	1	Coupler Insert	900-512	900-512	900-513	900-513	900-514	900-514	

(1) Add "A" to base plate number when coupler guard is to be used.

Fig. A

TYPICAL "CB" VALVE

Fig. B

TYPICAL "RDB" VALVE

Fig. C Flow rate in GPM

TYPICAL CAPACITY CURVE

TYPE "CB" CIRCUIT BALANCING VALVE

- "CB" Valves may be installed in any direction. Install valve in a location allowing easy access to (a) Adjustment Handle, and (b) Disconnects.
Caution: If drain connection is going to be used, the valve must be installed with drain on the downstream side.
- Be sure the two disconnects are in a shut-off position by turning the 3/16" square knob on each fitting clockwise.
- Be sure drain shut-off is in shut-off position by turning 5/16" square knob clockwise.
- Connect meter quick-disconnect hoses to valve disconnects as follows:
Green hose is connected to the downstream fitting
Red hose is connected to the upstream fitting
- Open disconnect shut-off valves by turning 3/16" square knob on each fitting counter clockwise.
- Adjust the valve setting from 1 to 8 on the inner scale (not outer scale). Valve is in shut-off position when handwheel pointer is on "O" on the inner scale.
- Read pressure drop of valve on CBM-60 meter. Locate meter reading on left side of capacity curve. Follow across chart to junction of valve setting indicator lines (diagonal lines). Then read GPM at bottom of curve, see Fig. "C". By using the capacity curve, adjust valve setting by turning handle of valve until desired flow rate is obtained.
- Memory feature if desired
Loosen lock nut which holds scale in position. Turn scale clockwise until stop rests against handle wheel pointer, then tighten locknut to secure scale. Now, if valve is closed, it can be opened to correct setting by just turning handle until pointer rests against stop. A small hole is provided in the stop to enable the handwheel pointer to be secured to the collar.
- Close disconnect shut off valves. Remove meter quick-disconnect hoses and drain meter.

TYPE "RDB" CIRCUIT BALANCING VALVE

- Install with arrow on valve body in same direction of flow in the pipe line and in a location allowing easy access to (a) Adjustment, and (b) Disconnects.
- Be sure the two disconnects are in a shut off position by turning the 3/16" square knob on each fitting clockwise.
- Connect meter quick-disconnect hoses to valve disconnects as follows:
Green hose is connected to the downstream fitting
Red hose is connected to the upstream fitting
- Open disconnect shut off valves by turning 3/16" square knob on each fitting counter clockwise.
- Adjust the valve setting from 2 thru 8 with special handle wrench. An arrow on the spindle indicates the setting.
- Read pressure drop of valve on CBM-60 meter. Locate meter reading on left side of capacity curve. Follow across chart to junction of valve setting indicator lines (diagonal lines), then read GPM at bottom of curve (See Fig. 'C'). By using the capacity curve, adjust valve setting with special wrench until desired flow rate is obtained.
- Remove handle.
- Close disconnect shut off valves. Remove meter quick disconnect hoses and drain meter.

MODEL "CB" CIRCUIT BALANCING VALVES

MODEL "CB" CIRCUIT BALANCING VALVES

ARMSTRONG PERFORMANCE CURVES

FILE NO: 5098.938
DATE: Mar. 30, 1977
SUPERSEDES: New
DATE:

CIRCUIT BALANCING VALVES

MODELS RDB-2½ TO RDB-6

Form No. 6585
Litho in Canada

MODEL "RDB" CIRCUIT BALANCING VALVES

SOLAR COLLECTORS

GENERAL ELECTRIC

VACUUM TUBE SOLAR COLLECTOR SPECIFICATION DATA SHEET SOLARTRON® MODEL TC-100

PHYSICAL WEIGHTS

	British	SI
Frame Only	35 lbs.	16 kg
Glass Installed		
Dry	57 lbs.	26 kg
Wet	59 lbs.	27 kg

OPERATIONAL

	British	SI
Insolation	0 to 400 BTU/ft ² /hr	0 to 108 langleys
Fluid		
Operating Temperature	100 to 300°F	38 to 149°C
Composition	1. "Good" water with 35/50% Prestone II TM	

COMPOSITION

Frame	18 Ga aluminized steel (51.6 mil)
Reflector	Alglas TM
Insulation	Fiberglass
Fluid Lines	1/4" type L copper
Glass Tubes	008 soda lime

CONNECTIONS

Hydraulic	Brass 1/4" 45° Flare Nut
Structural Attachments	Stainless Steel or aluminum

EQUIPMENT SIZING GUIDELINES

Heat exchanger area		
Heating	.17 ft ² /module	.016 m ² /module
Cooling & Heating	.35 ft ² /module	.033 m ² /module
Storage Volume		
Heating Only	15 gallons/ module	56.8 liters/ module
Cooling & Heating	22 gallons/ module	83.3 liters/ module

MODULE DESIGN CONDITIONS

Pressure Drop-Design	7.0 psi @ 180°F	48.2 kPa @ 82°C
Minimum	5.0 psi	34.5 kPa
Flow Rate	0.22 gpm @ 180°F	0.83 l/m @ 82°C
Wind Velocity (Max)	100 mph	161 km/hr
Ice Load (Max)	13 psf	63.5 kg/m ²
Snow Load (Max)	20 psf	97.6 kg/m ²
Combined Load (Max)	33 psf	161.1 kg/m ²
Minimum Array Pressure	45 psig	310 kPa

MODULE AREA

Gross (Frame)	17.4 ft ²	1.62/m ²
Net (Active)	14.8 ft ²	1.38/m ²

1. "Good" Quality Water:	
Chlorides	< 100 ppm
Sulfates	< 100 ppm
Bicarbonates	< 100 ppm
Total Hardness	< 250 ppm

TYPICAL DESIGN CONSIDERATION

COLLECTOR LOOP SCHEMATIC

SINGLE ROW PLUMBING CONFIGURATION

DUAL ROW PLUMBING CONFIGURATION

PRELIMINARY SOLAR ARRAY SIZING

MODULE PRESSURE DROP (@ 180°F)

FLUID	ΔP (PSI)
100% water	5.3
35% glycol/water	6.2
50% glycol/water	7.0

HEADER

TUBE SIZE	TYPE COPPER	MAXIMUM NUMBER OF PANELS/ROW
3/4"	L	18
1"	L	36

OPTIONAL ACCESSORY HARDWARE

HEADER KIT
MOUNTING KIT
SOLAR CONTROLLER
LEXAN OR ACRYLIC WINDOW

For Further Information Contact:
Manager, Solar Heating and Cooling Marketing
General Electric Company,
P.O. Box 13601,
Philadelphia, PA. 19101
Phone - (215) 962-2112/2113

GENERAL ELECTRIC

SPECIFICATION

EVACUATED TUBE HYDRONIC SOLAR COLLECTOR

GENERAL

The solar collector shall be an evacuated tube liquid type designed for efficient operation at fluid temperatures ranging from 100 to 300° Fahrenheit (66 to 149° Celsius). The collector module shall be furnished with all the necessary components, excluding support attachments, ready for field attachment to support and piping systems. Specifications and requirements stated herein shall not supersede applicable Federal, State, or Local Codes and Regulations.

SOLAR COLLECTOR MODULE

General Construction

The solar collector shall be composed of standard manufactured modules which are designed for simple attachment to the support structure and piping system. The modular unit shall have a gross dimensions of approximately 4 feet by 4 feet (1.2 by 1.2 meters) with an active-to-gross area ratio greater than 0.85. The active (effective) area, as defined by the manufacturer, is the planar area onto which incident energy is directed to the absorber surface (s). The gross operating weight of the solar collector shall not exceed 4.0 pounds per square foot (19.5 kg/m²) of gross area. The collector assembly shall be capable of withstanding wind velocities of up to 100 mph (161 km/hr) with an ice and snow load of 20 lb/ft² (97 kg/m²) without structural damage.

Glass Tubes

The module shall consist of evacuated glass tubes which are composed of two concentric glass tubes separated by a vacuum of less than 10⁻⁴ Torr. The glass construction shall contain the vacuum without the usage of mechanical seals. The vacuum shall be maintained for the life of the tube at temperatures up to 650°F (343°C) with an active getter.

The outer radial surface of the inner glass tube shall have a coating with an average hemispherical emittance less than 0.05 at 212°F (100°C) and an absorptivity greater than 0.85. The solar absorptance of the glass shall be greater than 87 percent of the visible light spectrum.

Long-term degradation of coating and glass properties shall have a combined effect of less than 10 percent of the total absorbed energy.

Fluid Passages

The collector unit shall be suitable for use with water or a mixture of water and anti-freeze solution (up to 50 percent by volume) as the heat transfer fluid.

Fluid passages shall not be restricted, when the specified fluid quality is maintained, to the point that collection efficiency (as a function of fluid flow) is decreased by more than 5 percent over the design life of the collector.

Fluid passages shall be designed to withstand, without degradation, the effects of no fluid flow and high insolation condition. Fluid passages shall be designed for operational pressures up to 80 psi (551 kPa) and fluid temperatures up to 300°F (149°C).

Insulation

There shall be at least 1.5 inches (3.80 cm) of 3 lb/ft³ fiberglass (48 kg/m³) or equivalent insulation surrounding all fluid-carrying components which are not thermally protected by the vacuum from the ambient environment. The insulation will be properly protected from the ambient environment to preclude significant insulation performance degradation resulting from ambient conditions. Fluid temperatures up to 650°F (343°C) shall not affect the performance or integrity of the insulation.

PERFORMANCE

Collector performance shall be defined by its instantaneous efficiency based on active collector area in graphical (Figure 1) and equation form as

$$\eta = A - B\psi$$

where

η = instantaneous collection efficiency (active area)

ψ = $(T_{col} - T_{amb}) / Q_i$ °F-hr-ft²/BTU

T_{col} = average collector temperature, °F

T_{amb} = ambient temperature, °F

Q_i = insolation on the plane of the collector
BTU/hr-ft²)

Figure 1. Instantaneous Collector Efficiency

The constants A and B are obtained by placing a least squared straight line through the data points located between $\psi = 0.0$ and $\psi = 1.0$. Certified test data from a recognized independent testing agency, along with manufacturer's test data, shall be identified on Figure 1 and utilized to define the constants A and B. Collector efficiency shall be determined in accordance with ASHRAE 93-77 test procedures.

The solar collector shall have an efficiency plot which is greater than the minimum performance line of Figure 1. The constant A shall be greater than 0.58 and B shall be less than $0.37 \text{ BTU/hr-ft}^2\text{-}^\circ\text{F}$.

QUALITY ASSURANCE

Manufacturer

The manufacturer of the solar energy collector shall be a recognized producer of said equipment and shall submit documentation demonstrating a high capability in design engineering, testing, fabrication, installation and maintenance of equipment the same as or similar to that called for on the drawings and in the specification(s).

All Other

All materials, assemblies, coatings, thermal bond connection, fluid connections, vacuum seals, structural members and hous-

ing configurations shall be of the highest quality and shall fully meet those standards called for and required in the "Interim Performance Criteria for Solar Heating and Cooling Systems in Commercial Buildings" (NBSIR 76-1187-1976). Any change and/or deviation from these criteria must be fully clarified. Standards and work of a higher quality than in the above cited, called for in these specifications and/or on the drawings, shall be met by the manufacturer.

OPERATIONAL DOCUMENTS

The manufacturer shall provide, within one (1) week of collector delivery, installation documentation for the collector. These manuals shall describe preventive maintenance, general maintenance, fluid quality control and replacement requirements and material replacement and control instructions.

WARRANTY

The manufacturer shall warrant that at time of delivery, the solar collector will be free from defects in material and manufacture and will be of good quality and workmanship. This warranty shall provide for the replacement or repair, at the manufacturer's election, of the collector or parts thereof, provided that written notice of the defect shall be given to the manufacturer within one (1) year after collector delivery.

Mounting and Interconnection Interfaces for TC-100 Collector

AUTOMATIC CONTROL SYSTEM

KRP Series continued

KR11-E and KR14-E SERIES Hermetically sealed in a metal can. Has octal-type plug and gold-flashed silver contacts rated 5 amps @ 120V AC, 80% P.F., or 28V DC, resistive. Suffix "G" denotes silver cadmium oxide contacts rated 10 amps @ 120V AC, 80% P.F., or 28V DC, resistive.

KRP SERIES Versatile multi-contact arrangement. Enclosed in a clear polycarbonate dust cover. Standard 8-pin octal-type plug for KRP5 and KRP11, 11-pin for KRP14. Weight: Approx 3 ozs. Contacts 5 amp. Gold flashed silver, 10 amp silver-cadmium oxide. See KCP-KRP hold-down spring for special mounting applications. See KRP-N indicator lamp relay for current monitoring applications.

KRP-N INDICATOR

LAMP RELAY A general purpose relay incorporating a lamp to indicate current or voltage availability in power circuit. Contacts Silver-cadmium oxide rated 10 amps. Enclosures: Clear, polycarbonate dust cover. Mounting: Standard octal plug. Weight: Approximately 3 ozs. Hold-down spring (Please see Page 4).

"P" Case is a clear polycarbonate case for mounting rectifiers, capacitors, resistors or other components. Octal type termination. 8 pin, 35D017 11 pin, 35D072. Comes with four screws. Weight, 0.5 oz.

35D070 LIST \$.80
35D072 LIST \$.96

Hold-down spring for "P" Case, and KRP series relays will accommodate machine screws or rivets.

20C176 LIST \$.20

OCTAL-STYLE SOCKETS

For KRP, KRP3-H, KAP, KBP, KCP, EBT, and EBA relays, CD-21, CD-38, CH, CK, and CR time delays; and CS sensor.

Molded polycarbonate, 8-pin screw terminal socket, rated 10 amperes

27E122 LIST \$2.83

Molded polycarbonate, 11-pin screw terminal socket, rated 10 amperes.

27E123 LIST \$4.24

TRACK MOUNT SYSTEM FOR SOCKETS

Extruded aluminum, three-foot section with slotted holes on 6" centers for #8 screws.

24A064 NET \$2.22

Plastic clip for mounting sockets 27E122 and 27E123, above, and socket 27E166, page 4. Two clips required per socket.

24A072 NET \$1.11

Aluminum retainer with #6-40 tapped hole for mounting sockets 27E121 (page 7), 27E122, 27E123, and 27E166. Includes one #6-40 x 1/2" screw. Two retainers and screws required per socket.

24A071 NET \$.07

Plastic twist clip requires no screws, will mount 27E121 only. Two required per socket.

24A067 NET \$.10

Stainless steel hold-down clip restricts movement of relay mounted in socket 27E121. Two clips required per socket.

20C253 NET \$.09

TRACK MOUNT SYSTEM

GENERAL PURPOSE RELAYS

TYPE	COILS			CONTACTS		SUGG. RE. SALE PRICE
	Input	Res. in Ohms	Nom. Power	Arrang.	Amp. Rating	
KRP5A\$	6V	6	2VA	SPDT	5	\$ 2.50
	12V	21				2.50
	24V	85				2.50
	120V	2,250				7.50
KRP5AG\$	6V	6	2VA	SPDT	10	7.80
	12V	21				7.80
	24V	85				7.80
	120V	2,250				7.80
KRP5D\$	6V	3.1	12W	SPDT	5	7.45
	12V	120				7.45
	24V	472				7.45
	110V	10,000				8.35
KRP5DG\$	6V	3.1	12W	SPDT	10	7.70
	12V	120				7.70
	24V	472				7.70
	110V	10,000				8.55
KRP11A\$	6V	6	2VA	DPDT	5	8.40
	12V	21				8.40
	24V	85				8.40
	120V	2,250				8.10
KRP11AG\$	6V	6	2VA	DPDT	10	8.70
	12V	21				8.70
	24V	85				8.70
	120V	2,250				9.25
KRP11D\$	6V	3.1	12W	DPDT	5	8.35
	12V	120				8.35
	24V	472				8.35
	110V	10,000				9.20
KRP11DG\$	6V	3.1	12W	DPDT	10	8.65
	12V	120				8.65
	24V	472				8.65
	110V	10,000				9.50
KRP14A\$	6V	6	2VA	3PDT	5	10.15
	12V	21				10.45
	24V	85				10.45
	120V	2,250				10.45
KRP14AG\$	6V	6	2VA	3PDT	10	10.80
	12V	21				10.80
	24V	85				10.80
	120V	2,250				11.40
KRP14D\$	6V	3.1	12W	3PDT	5	10.35
	12V	120				10.35
	24V	472				10.35
	110V	10,000				11.10
KRP14DG\$	6V	3.1	12W	3PDT	10	10.70
	12V	120				10.70
	24V	472				10.70
	110V	10,000				11.50
KRP11AN\$	6V	6	2VA	DPDT	10	9.95
	12V	21				9.95
	24V	85				9.95
	120V	2,250				10.50
KRP11DN\$	6V	3.1	12W	DPDT	10	9.80
	12V	120				9.80
	24V	472				9.80
	110V	10,000				10.70
KRP14AN\$	6V	6	2VA	3PDT	10	12.10
	12V	21				12.10
	24V	85				12.10
	120V	2,250				12.10
KRP14DN\$	6V	3.1	12W	3PDT	10	11.95
	12V	120				11.95
	24V	472				11.95
	110V	10,000				12.65

DO NOT ORDER RELAYS TO BE DELIVERED WITH NO ORDERING

A Alternating Current, e.g. PRD3A
D Direct Current, e.g. PRD3D

\$ Enclosed Relay I Sealed Relay

Pump Controllers and High Pressure Low Water Cut-offs

McDonnell Pump Controllers are float actuated electrical switches used to control boiler feed pumps as they should ideally be controlled—directly from the boiler water level. They represent the proven best method of keeping the boiler water level within the close limits recommended for maximum steaming efficiency and fuel economy. These controls also include a second switch, operating at a lower level which provides a circuit for stopping the automatic burner and sounding an alarm—the final safeguard for emergency conditions such as electrical current interruption to the pump or failure of make-up water supply.

McDonnell Pump Controllers can also be used on storage tanks and pressure vessels to start or stop pumps, or provide alarm or automatic cut-off, at high level and/or low level.

All McDonnell Pump Controllers have completely packless construction. Electrical operating parts are sealed from the float chamber. The controls have been designed for high pressure, high temperature service.

In addition to controllers listed in the table, the liquid level controls shown on page 12 can also be used on high pressure boilers—Model PCH and PCL for low water cut-off, and Model VFC for pump control and cut-off.

HOW TO SELECT

McDonnell Pump Controllers serve boilers of any size. Selection of proper control depends upon boiler operating pressure and method of installation.

Product No.	Maximum Pressure	Switches	Characteristics
No. 42	50 psi	Mercury tube	For boilers with separate water columns
No. 42-A	50 psi	Mercury tube	"Quick Hook-up" fittings
150 Series	150 psi	Mercury tube	For boilers with separate water columns
157 Series	150 psi	Mercury tube	Water column type body, with all tapings for steam trim
No. 93*	150 psi	Magnetic—open contact	Permits wider adjustment of operating levels
No. 193A*	150 psi	Magnetic—open contact	Water column type
No. 94*	250 psi	Magnetic—open contact	Similar to No. 93, but for higher pressure
No. 194*	250 psi	Magnetic—open contact	Water column type body

*These controls have 1/4" NPT opening in body and 1/2" NPT opening in head castings, for float blocking.

ELECTRICAL RATINGS (Underwriters Listed)

For 150 Series, 157 Series, and 42 Series
Ampere Rating for Pump and Cut-off Circuits

Motor Duty	120VAC	240VAC	120VDC	240VDC
Full load	7.4	3.7	2.4	1.2
Locked Rotor	44.4	22.2	24.0	12.0

Pilot Duty Service: 345VA, 120 and 240VAC

Ampere Rating for Alarm Circuit

120VAC	240VAC	120VDC	240VDC
1	1/2	1/2	1/4

For 93 Series and 94 Series

Pilot Duty Service: 120 or 240VAC, 345 VA

Note: For supply connections of 94 Series, use wire suitable for at least 75 C.

No. 150

The most widely used control of its kind. Packless construction utilizes Monel bellows. Has mercury tube type switches. Can also be used as a cut-off and alarm on many higher pressure hot water space heating boilers. Available with manual reset on cut-off switch; order No. 150-M.

For boilers of any size.
Maximum boiler pressure, 150 psi.

157 Series

No. 157 is basically the same as the No. 150, but has integral water column type of float chamber that simplifies installation and includes all necessary tapings for gauge glass and tricocks.

No. 157-A is same as No. 157 but with larger tapings for equalizing piping and steam trim (see table below).

No. 157R and No. 157RL—Gauge glass tapings in side of body. No. 157RL recommended for boilers where higher visible water line is required, or for boilers with both a feed pump and a combination water feeder cut-off.

All 157 Series also available with manual reset on cut-off switch: order No. 157-M, 157A-M, 157R-M or 157RL-M.

Product No.	No. 157	No. 157A	No. 157R or No. 157RL
Equalizing Tapings "A"	1" NPT	1 1/4" NPT	1 1/4" NPT
Gauge Glass and Tricock Tapings "B"	1/2" NPT	3/4" NPT	1/2" NPT

Maximum boiler pressure, 150 psi.

Flow Switches

No. FS4-3 and No. FS4-3D

Compact, moderately priced flow switch for service on water lines principally. Has single pole, double throw switch—can be wired to make one circuit, break a second, when flow or no-flow occurs. All parts in contact with liquid in pipe are of brass, solder and Monel. Features include completely packless construction, and easy adjustment of switch sensitivity. Individual paddles are adaptable for pipe 1" to 3" NPT; an extended paddle for larger pipe also included. Installs in tee or welding neck in horizontal pipe; has 1" NPT threaded connection.

No. FS4-3 has one SPDT switch. No. FS4-3D has two SPDT switches to handle two separate circuits. Electrical ratings page 15.

These flow switches are also available with time delay relays, to eliminate false signals caused by turbulence (see page 19). Order No. FS4-3-5R for 5-second delay on break, No. FS4-3-20 for 20-second delay on make.

Maximum pressure, 150 psi.

Maximum temperature, 300 F.

Flow Rates Required to Actuate No. FS4-3 and No. FS4-3D

Water flow rates in gallons per minute (GPM) shown in black.
Velocity in feet per second (FPS) shown in color.

Pipe Size	Factory or Minimum Adjustment				Maximum Adjustment			
	FLOW		NO FLOW		FLOW		NO FLOW	
	GPM	FPS	GPM	FPS	GPM	FPS	GPM	FPS
1"	6.0	2.24	3.6	1.34	10.2	3.91	9.2	3.43
1¼"	9.8	2.11	5.6	1.21	16.8	3.62	15.0	3.23
1½"	12.7	2.00	7.0	1.10	23.0	3.62	19.5	3.07
2"	18.8	1.80	9.4	0.90	32.8	3.14	24.0	2.29
2½"	24.3	1.63	11.6	0.78	42.4	2.74	37.5	2.51
3"	30.0	1.30	12.0	0.52	52.1	2.25	46.1	2.00
4"	39.7	1.00	19.8	0.50	73.5	1.86	64.2	1.52
5"	58.7	0.94	29.3	0.47	115.0	1.85	92.0	1.48
6"	79.2	0.88	39.6	0.44	166.0	1.84	123.0	1.37

*Equipped with extended paddle (cut for 4" and 5" pipe).
Flow rates are averages which may vary $\pm 10\%$ from tabulated values.

No. FS8V

Provides vapor-proof construction in an economically priced, compact-size flow switch. Particularly suited for use in areas of high humidity, and for out-of-doors installation. Has adjustment for sensitivity to flow, packless construction, wetted parts of brass, solder and Monel. Individual paddles are adaptable for pipe 1" to 3"; extended paddle for larger pipe is also included. Installs in tee or welding neck in horizontal pipe; 1" threaded connection.

Electrical ratings shown on page 15.

Time delay relays are available to eliminate false signals caused by turbulence; see page 19.

Maximum pressure, 150 psi.

Maximum temperature, 225 F.

Flow Rates Required to Actuate No. FS8V

Water flow rates in gallons per minute (GPM) shown in black.
Velocity in feet per second (FPS) shown in color.

Pipe Size	Factory or Minimum Adjustment				Maximum Adjustment			
	FLOW		NO FLOW		FLOW		NO FLOW	
	GPM	FPS	GPM	FPS	GPM	FPS	GPM	FPS
1"	4.9	1.82	3.4	1.25	17.6	6.53	15.0	5.56
1¼"	7.5	1.60	5.3	1.14	29.0	6.23	24.6	5.28
1½"	9.4	1.48	6.7	1.05	37.8	5.95	32.2	5.07
2"	13.7	1.31	9.4	0.90	56.4	5.39	47.4	4.53
2½"	17.9	1.20	12.1	0.81	71.3	4.78	59.2	3.97
3"	24.2	1.05	16.4	0.71	89.0	3.87	72.5	3.15
4"	35.3	0.89	27.0	0.68	118.0	2.98	105.0	2.64
5"	48.6	0.78	37.4	0.60	178.0	2.86	160.0	2.57
6"	60.3	0.67	46.8	0.52	245.0	2.72	225.0	2.50

*Equipped with extended paddle (cut for 4" and 5" pipe).
Flow rates are averages which may vary $\pm 10\%$ from tabulated values.

No. FS4-3F and No. FS7-4F Waterflow Indicators

Listed by Underwriters Laboratories for service as a waterflow indicator on branch piping of fire sprinkler systems. Used to pinpoint location of open sprinkler heads—to speed fire fighting and minimize water damage. Construction dimensions and electrical ratings same as for No. FS4-3 (page 15) and No. FS7-4 (page 18).

No. FS4-3F can be furnished with time delay relay (see page 19); order No. FS4-3F-20. Time delay relay is also available for use with No. FS7-4F (see page 19).

Minimum Flow Rates Required to Actuate Waterflow Indicators

No. FS4-3F—For 1", 1¼" and 1½" branch piping.

No. FS7-4F—For 1¼", 1½", 2" and 2½" branch piping.

Both Waterflow Indicators are actuated by a flow rate of 4 to 10 gallons per minute (GPM) in all pipe sizes listed above.

Maximum pressure: No. FS4-3F, 150 psi.

No. FS7-4F, 300 psi.

Maximum temperature, 300 F.

DATA SHEET

VP2567 & VP2568

DIAPHRAGM CONTROL VALVES

These valves are especially designed for the control of hot water, low pressure steam, or chilled water. The VP2567 series is a normally closed control valve and the VP2568 series is a normally open control valve. Sizes from 1/4" to 2" are available with equal percentage flow characteristics.

Two Rubber U-Cups plus two Teflon® spacers provide a positive self adjusting seal around the valve stem.

These valves are operated by pneumatic actuators, which include a die-cast aluminum yoke and case and a molded rubber diaphragm.

SPECIFICATIONS

VALVE ASSEMBLY

Action VP2567 — normally closed
 VP2568 — normally open
 Flow characteristics equal percentage
 Rating 300 psi., 35 to 250° F water or 15 psi steam
 on 1" thru 2" sizes. 250 psi., 35 to 250° F water
 or 15 psi steam on 1/4" and 1/2" sizes.

BODY

Pattern straight through
 Sizes 1/2" thru 2" NPT
 Connections female NPT inlet and outlet
 Material brass
 Seat brass, integral with body
 Packing two Teflon® spacers plus two rubber U-cups

VALVE TRIM

Plug brass
 Disc renewable EP rubber
 Stem silicon brass
 Back seat rubber O-ring

ACTUATOR ASSEMBLY

Action direct acting
 Size 10 sq. in. effective area
 Actuator ranges 4 — 8 psi
 2 — 13 psi
 8 — 13 psi
 2 — 6 psi (VP2568 only)
 Maximum air pressure 30 psi
 Ambient temperature rating 250° F max.
 Diaphragm molded rubber
 Case & yoke die-cast aluminum
 Spring alloy steel; cadmium plated

CLOSE OFF RATINGS

Pressure drop acting against the unbalanced area of the valve produces a thrust. This thrust must be overcome by the actuator through the application of additional signal pressure above the top end of the signal range for normally open control valves, or by reducing the signal pressure below the bottom end of the range for normally closed control valves. In either case, the actuator span is increased.

For tight close off, the valve must not be operated at pressure drops greater than those designated by the intersections of the valve size curves with the appropriate line selected from Table I (See Fig. 1). Maximum allowable pressure drop for any valve (including other actuator ranges) is 40 psi.

Figure 1 — CLOSE OFF RATINGS, VP2567 & VP2568 VALVES

TABLE I — CLOSE OFF LINES

ACTUATOR RANGE	VP2567	VP2568
4 - 8	LINE B	LINE C
2 - 13	LINE A	LINE A
8 - 13	LINE C	LINE A
2 - 6	—	LINE C

ORDERING INFORMATION

Refer to page 2

This valve is especially designed for the control of either hot water or chilled water, and is available in sizes 1/2" through 2" with linear flow characteristics.

Two Rubber U-Cups plus two Teflon® Spacers provide a positive self-adjusting seal around the valve stem. Service life of the seal is greatly extended by the use of a stem made of anti-fouling silicon brass.

The valve is operated by a pneumatic actuator, which includes a die-cast aluminum yoke and case and a molded rubber diaphragm.

SPECIFICATIONS

VALVE ASSEMBLY

Action top port normally-closed
bottom port normally-open
Flow characteristic linear (constant total flow)
Rating 300 psi, 35 to 250° F water — 1" through 2" sizes.
250 psi, 35 to 250° F water — 1/2" and 3/4" sizes.

BODY

Pattern 3-way (integral bonnet on 1/2" and 3/4" sizes)
Sizes 1/2" through 2" NPT
Connections female NPT
Material brass
Seat brass
Packing two rubber U-cups plus two Teflon® spacers

VALVE TRIM

Plug brass
Stem silicon brass

ACTUATOR ASSEMBLY

Size 10 sq. in. effective area
Spring ranges 1 — 5 psi
4 — 8 psi
2 — 13 psi
8 — 13 psi
5 — 9 psi (1/2", 3/4" & 1" sizes only — also supplied
on valves with positive positioners;
Maximum air pressure 30 psi
Ambient temperature rating 225° F max.
Diaphragm molded rubber
Case and yoke die-cast aluminum
Spring alloy steel, cadmium plated

CLOSE OFF RATINGS

Pressure drop acting against the unbalanced area of the valve produces a thrust. When the pressure in the normally-open port is greater than the pressure in the normally-closed port, the additional thrust must be compensated for by additional signal pressure applied at the top limit of the actuator range.

Conversely, when the pressure in the normally-closed port is greater than the pressure in the normally-open port, the additional thrust must be compensated for by a decrease in signal pressure at the low limit of the actuator range. (See Fig. 1)

For tight close off the valve must not be operated at pressure drops greater than those designated by the intersections of the valve size curves with the appropriate line selected from Table I (See Fig. 1). Maximum allowable pressure drop for any valve (including other actuator ranges) is 40 psi.

Figure 1 — CLOSE OFF RATING, VP2566 VALVE

TABLE I — CLOSE OFF LINES

ACTUATOR RANGE (PSI)	NORMALLY-OPEN PORT	NORMALLY-CLOSED PORT
1 - 5	LINE C	LINE D
4 - 8	LINE C	LINE B
8 - 13	LINE A	LINE C
2 - 13	LINE A	LINE A
5 - 9	LINE E	LINE E

ORDERING INFORMATION

Refer to page 2

ORDERING INFORMATION

VP2566 THREE-WAY MIXING VALVES

UNI-LINE NUMBER	FACTORY MODEL	REPLACES	SIZE (NPT) SCREWED	Cv	ACTUATOR	
					EFFECTIVE AREA (□")	SPRING RANGE (p.s.i.)
VP2566-001	V6600-04301	V6693-01	1/2"	2.2	10"	1 - 5
VP2566-002	V6600-04302	V6693-02				4 - 8
VP2566-003	V6600-04306	V6693-06				2 - 13
VP2566-004	V6600-04307	V6693-07				8 - 13
VP2566-005	V6600-04309	V6693-09				5 - 9
VP2566-006	V6600-04319	V6693-19				POSITIONER
VP2566-007	V6600-15301	V6607-01	3/4"	4.6		1 - 5
VP2566-008	V6600-15302	V6607-02				4 - 8
VP2566-009	V6600-15306	V6607-06				2 - 13
VP2566-010	V6600-15307	V6607-07				8 - 13
VP2566-011	V6600-15309	V6607-09				5 - 9
VP2566-012	V6600-15319	V6607-19				POSITIONER
VP2566-013	V6600-25301	V6610-01	1"	9.0		1 - 5
VP2566-014	V6600-25302	V6610-02				4 - 8
VP2566-015	V6600-25306	V6610-06				2 - 13
VP2566-016	V6600-25307	V6610-07				8 - 13
VP2566-017	V6600-253-09	V6610-09				5 - 9
VP2566-018	V6600-25319	V6610-19				POSITIONER
VP2566-019	V6600-30301	V6612-01	1-1/4"	18.0		1 - 5
VP2566-020	V6600-30302	V6612-02				4 - 8
VP2566-021	V6600-30306	V6612-06				2 - 13
VP2566-022	V6600-30307	V6612-07				8 - 13
VP2566-023	V6600-30319	V6612-19				POSITIONER
VP2566-024	V6600-35301	V6615-01	1-1/2"	25.0		1 - 5
VP2566-025	V6600-35302	V6615-02				4 - 8
VP2566-026	V6600-35306	V6615-06				2 - 13
VP2566-027	V6600-35307	V6615-07				8 - 13
VP2566-028	V6600-35319	V6615-19				POSITIONER
VP2566-029	V6600-40301	V6620-01	2"	40.0		1 - 5
VP2566-030	V6600-40302	V6620-02				4 - 8
VP2566-031	V6600-40306	V6620-06				2 - 13
VP2566-032	V6600-40307	V6620-07				8 - 13
VP2566-033	V6600-40319	V6620-19				POSITIONER

A. H. UNIT HEATING AND COOLING COIL CONTROL

INSTALLATION

Control valves are sized to the demand of the system to be controlled and are frequently smaller than supply lines. They should be installed as close as possible to the coil being controlled. Preferably, a control valve should be installed in the vertical position so the actuator will be over the valve, but can be installed in any position if necessary.

When installing a valve, these simple precautions should be taken:

1. Install a pipeline strainer just ahead of the valve.
2. Allow sufficient clearance that the valve may be easily serviced if necessary.
3. A minimum clearance of 3½" must be allowed between the extreme top of the actuator and the nearest obstruction. This permits removal of actuator yoke and parts required to replace packing.

TABLE II - VP2566 DIMENSIONS AND WEIGHTS

SIZE	DIMENSIONS IN INCHES						WEIGHT (LBS)
	A	B	C	D	E	F	
1/2	4-9/16	1-15/16	4-5/16	1-3/8	1-3/8	2-3/4	3.1
3/4	4-23/32	2-7/32	4-5/16	1-19/32	1-19/32	3-3/16	3.4
1	5-29/32	3-3/8	4-5/16	2-1/2	2-1/2	5	6.9
1-1/4	5-29/32	3-3/8	4-5/16	2-9/16	2-9/16	5-1/8	8.0
1-1/2	5-29/32	3-3/8	4-5/16	2-9/16	2-9/16	5-1/8	8.0
2	6-5/16	3-25/32	4-5/16	3-3/8	3-3/8	6-3/4	16.3

MAINTENANCE AND REPAIR

The VP2566 requires very little maintenance after proper installation. It is recommended that field repairs be limited to the

following: (No Special Tools Required)

Figure 2 - VP2566 VALVE ASSEMBLY

PACKING REPLACEMENT

If valve stem leakage is encountered, replace the U-Cup Packing (12) as follows:

1. Remove Clamp Nut (13) and lift Yoke (9) and Assembled Parts (2, 3 and 4) off valve.
2. Measure dimension "A" from the end of Stem and Plug Assembly (8) to top of Spring Adjustor (5) and record. During reassembly of the valve, this dimension must be reset $\pm 1/64$ " so as not to change the actuator range.
3. Remove Spring Adjustor (5), Spring Seat (6) and Spring (7).
4. Remove Packing Nut (10), Spacer (11), U-Cup Packing (12) and Spacer (14). Be sure the packing cavity in the integral bonnet and the valve stem are clean.
5. Drop Spacer (14) over stem into bottom of packing cavity. Apply a bead of valve seal lubricant, Accessory Number N6-3, around the valve stem and push one U-Cup Packing (12) over stem and into packing cavity, thereby lubricating the inside diameter of the packing and filling the annular groove in the packing with lubricant. Repeat this procedure with a second U-Cup Packing (12), taking care with each U-Cup packing not to damage the sealing lip.
Drop Spacer (11) over stem, and screw on Packing Nut (10) to a positive stop.

6. Reassemble Spring (7), Spring Seat (6) and Spring Adjustor (5). Reset dimension "A" as recorded in Step 2 above.
7. Replace Yoke (9) and Assembled Parts (2, 3 and 4) on Valve Body (15) and lock in place with Clamp Nut (13). Make sure that end of stem is engaged in shaped hole in center of Diaphragm Shoe (4) during this operation.

VALVE PLUG REPLACEMENT

If indications of excessive valve seat leakage are encountered, the Stem and Plug Assembly (8) may be replaced. The packing should be replaced any time the stem and plug assembly is replaced. Replacement of parts is accomplished as follows:

1. Perform Steps 1 through 4 as shown in "Packing Replacement" above.
2. Remove Adapter (16) from Valve Body (15). Remove old Stem and Plug Assembly (8).
3. Insert new stem and plug assembly into Valve Body (15) and replace Adapter (16).
4. Perform Steps 5, 6 and 7 as listed under "Packing Replacement".

DATA SHEET

VP2510 & VP2511

DIAPHRAGM CONTROL VALVES SINGLE SEATED

These Control Valves are especially designed for the control of hot water, low pressure steam or chilled water.

The valves are single seated with renewable discs. Sizes from 1-1/2" to 4" are available on the VP2510 Series, while the VP2511 Series is available in 2-1/2", 3" and 4" sizes.

On sizes through 2", the characterized plug is stem guide and mounted by an antitorque swivel arrangement. The sizes 2-1/2", 3" and 4" are double guided. These features provide accurate seating alignment and quiet operation under high flow conditions. On sizes through 2" the valve body and bonnet are provided with conical seating surfaces to insure accurate alignment and to provide a leak-tight joint which can be readily loosened for servicing. On larger sizes the bonnet is bolted to the valve body. A locating boss on the bonnet insures accurate alignment.

The valve is operated either by a 30 square inch or an 80 square inch actuator assembly depending on valve size and type of service. The deeply convoluted molded diaphragm provides constant area characteristics throughout the stroke for excellent linearity.

The actuator assembly can be easily detached from the valve without affecting the valve body or its components.

All parts can be replaced without the use of special tools.

SPECIFICATIONS

VALVE ASSEMBLY

Valve action VP2510 — direct acting (N.O.)
VP2511 — reverse acting (N.C.)

Nominal size	1-1/2"—2"	2-1/2"—4"
Connection	NPT	Flanged
Service rating	300 psi for 250° F Water or 80 psi steam	125 psi for 250° F Water or 80 psi steam
Disc material	Renewable composition	Renewable hard rubber
Body material	Brass	Cast iron
Seat material	Brass (integral)	Brass
Valve stem material	Stainless steel	Stainless steel
Flow characteristics	Equal percent	Equal percent

STEM PACKING

Steam Teflon, spring loaded
Water Rubber U-Cup
Close off rating see next page

ORDERING INFORMATION

Refer to pages 3 and 4

MODEL VP2510

ACTUATOR ASSEMBLY VP2510

ACTION ON SIZES

For use on VP2510
Direct acting 30 and 80 sq. in. effective area.
Reverse acting 30 sq. in. effective area.
For use on VP2511
Direct acting 80 sq. in. effective area.

VP2510 and VP2511 are available with positive positioning relays.

ACTUATOR RANGES

30 in. ² size	80 in. ² size
2-13 psi	3-12 psi
2-7 psi	3-7 psi
8-13 psi	8-12 psi

Maximum air pressure 35 psi
Ambient temperature rating 200°F Max.
Diaphragm Molded rubber, nylon reinforced
Case Die cast aluminum on 30 sq. inch size
Pressed steel on 80 sq. inch size
Yoke Cast iron
Spring Alloy steel, Cadmium plated

CLOSE OFF RATINGS AND ACTUATOR SPRING ADJUSTMENT

Pressure drop acting against the unbalanced area of the valve produces a thrust which must overcome the actuator as follows:

Normally-Open Control Valves: The thrust must be compensated for by additional signal pressure applied at the top limit of the actuator range.

Normally-Closed Control Valves: The thrust must be applied by additional spring load at the low limit of the actuator range.

Either of these conditions increases the actuator span when the valve is operating under a pressure differential. Figure 1 illustrates

For tight close-off, the valves must not be operated at pressure drops greater than those designated by the intersections of the valve size curves with Line A for an 11 psi or 9 psi actuator span or Line B for a 5 psi or 4 psi actuator span.

Normally-Open Control Valves require an increase in signal above the top end of range to compensate for pressure drop across valve. Pressure drop across normally-closed control valves requires a decrease in signal below the low end of range, or an adjustment in spring loading.

TABLE I — ACTUATOR SPRING ADJUSTMENT DATA

ACTUATOR NOMINAL AREA (in. ²)	ALLOWABLE ADJUSTMENT OF STROKE STARTING POINT					
	2-13	2-7	8-13	3-12	3-7	8-12
30	0 to 4	0 to 8	0 to 10	—	—	—
80	—	—	—	0 to 6	0 to 4	0 to 11

Figure 1 — CLOSE OFF RATINGS OF VP2510 & VP2511 VALVES

ORDERING INFORMATION

VP2510 SINGLE SEATED CONTROL VALVES – EQUAL PERCENTAGE FLOW CHARACTERISTICS

UNI-LINE NUMBER	FACTORY MODEL	SIZE (NPT)	Cv	ACTION	ACTUATOR		TYPE PACKING		
					EFFECTIVE AREA	SPRING RANGE OR POS. POSITIONER			
VP2510-001 VP2510-002 VP2510-003 VP2510-004	V1002-35406 V1002-35404 V1002-35407 V1002-35419	1-1/2"	25	AIR TO CLOSE	30	2 - 13 2 - 7 8 - 13 POSITIONER	TEFLON		
VP2510-005 VP2510-006 VP2510-007 VP2510-008	V1002-35606 V1002-35604 V1002-35607 V1002-35619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-009 VP2510-010 VP2510-011 VP2510-012	V1000-35406 V1000-35404 V1000-35407 V1000-35419			AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	U-CUP		
VP2510-013 VP2510-014 VP2510-015 VP2510-016	V1000-35606 V1000-35604 V1000-35607 V1000-35619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-017 VP2510-018 VP2510-019 VP2510-020	V1002-40406 V1002-40404 V1002-40407 V1002-40419			AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	TEFLON		
VP2510-021 VP2510-022 VP2510-023 VP2510-024	V1002-40606 V1002-40604 V1002-40607 V1002-40619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-025 VP2510-026 VP2510-027 VP2510-028	V1000-40406 V1000-40404 V1000-40407 V1000-40419			AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	U-CUP		
VP2510-029 VP2510-030 VP2510-031 VP2510-032	V1000-40606 V1000-40604 V1000-40607 V1000-40619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-033 VP2510-034 VP2510-035 VP2510-036	V1002-45406 V1002-45404 V1002-45407 V1002-45419	2-1/2" FLNGD.	72	AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	TEFLON		
VP2510-037 VP2510-038 VP2510-039 VP2510-040	V1002-45606 V1002-45604 V1002-45607 V1002-45619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-041 VP2510-042 VP2510-043 VP2510-044	V1000-45406 V1000-45404 V1000-45407 V1000-45419			AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	U-CUP		
VP2510-045 VP2510-046 VP2510-047 VP2510-048	V1000-45606 V1000-45604 V1000-45607 V1000-45619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER			
VP2510-049 VP2510-050 VP2510-051 VP2510-052	V1002-45515 V1002-45503 V1002-45517 V1002-45519			AIR TO CLOSE	80	3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON		
VP2510-053 VP2510-054 VP2510-055 VP2510-056	V1000-45515 V1000-45503 V1000-45517 V1000-45519			AIR TO CLOSE		3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP		
VP2510-057 VP2510-058 VP2510-059 VP2510-060	V1002-51406 V1002-51404 V1002-51407 V1002-51419			3"	102	AIR TO CLOSE	30	2 - 13 2 - 7 8 - 13 POSITIONER	TEFLON
VP2510-061 VP2510-062 VP2510-063 VP2510-064	V1002-51606 V1002-51604 V1002-51607 V1002-51619					AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER	
VP2510-065 VP2510-066 VP2510-067 VP2510-068	V1000-51406 V1000-51404 V1000-51407 V1000-51419	AIR TO CLOSE	2 - 13 2 - 7 8 - 13 POSITIONER			U-CUP			
VP2510-069 VP2510-070 VP2510-071 VP2510-072	V1000-51606 V1000-51604 V1000-51607 V1000-51619	AIR TO OPEN	2 - 13 2 - 7 8 - 13 POSITIONER						

ORDERING INFORMATION (Cont'd)

UNI-LINE NUMBER	FACTORY MODEL	SIZE FLNGD.	Cv	ACTION	ACTUATOR		
					EFFECTIVE AREA	SPRING RANGE OR POS. POSITIONER	TYPE PACKING
VP2510-073 VP2510-074 VP2510-075 VP2510-076	V1002-51515 V1002-51503 V1002-51517 V1002-51519	3"	102	AIR TO CLOSE	80	3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON
VP2510-077 VP2510-078 VP2510-079 VP2510-080	V1000-51515 V1000-51503 V1000-51517 V1000-51519			AIR TO CLOSE		3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP
VP2510-081 VP2510-082 VP2510-083 VP2510-084	V1002-55406 V1002-55404 V1002-55407 V1002-55419			AIR TO CLOSE		2 - 13 2 - 7 8 - 13 POSITIONER	TEFLON
VP2510-085 VP2510-086 VP2510-087 VP2510-088	V1002-55606 V1002-55604 V1002-55607 V1002-55619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER	
VP2510-089 VP2510-090 VP2510-091 VP2510-092	V1000-55406 V1000-55404 V1000-55407 V1000-55419	4"	164	AIR TO CLOSE	30	2 - 13 2 - 7 8 - 13 POSITIONER	U-CUP
VP2510-093 VP2510-094 VP2510-095 VP2510-096	V1000-55606 V1000-55604 V1000-55607 V1000-55619			AIR TO OPEN		2 - 13 2 - 7 8 - 13 POSITIONER	
VP2510-097 VP2510-098 VP2510-099 VP2510-100	V1002-55515 V1002-55503 V1002-55517 V1002-55519			AIR TO CLOSE	80	3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON
VP2510-101 VP2510-102 VP2510-103 VP2510-104	V1000-55515 V1000-55503 V1000-55517 V1000-55519			AIR TO CLOSE		3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP

VP2511 SINGLE SEATED CONTROL VALVES – EQUAL PERCENT FLOW CHARACTERISTICS DIRECT ACTING ACTUATORS NORMALLY CLOSED

VP2511-001 VP2511-002 VP2511-003 VP2511-004	V1102-45515 V1102-45503 V1102-45517 V1102-45519	2-1/2"	72	AIR TO OPEN	80	3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON		
VP2511-005 VP2511-006 VP2511-007 VP2511-008	V1100-45515 V1100-45503 V1100-45517 V1100-45519					3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP		
VP2511-009 VP2511-010 VP2511-011 VP2511-012	V1102-51515 V1102-51503 V1102-51517 V1102-51519					3"	102	3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON
VP2511-013 VP2511-014 VP2511-015 VP2511-016	V1100-51515 V1100-51503 V1100-51517 V1100-51519							3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP
VP2511-017 VP2511-018 VP2511-019 VP2511-020	V1102-55515 V1102-55503 V1102-55517 V1102-55519	4"	164			3 - 12 3 - 7 8 - 12 POSITIONER	TEFLON		
VP2511-021 VP2511-022 VP2511-023 VP2511-024	V1100-55515 V1100-55503 V1100-55517 V1100-55519					3 - 12 3 - 7 8 - 12 POSITIONER	U-CUP		

INSTALLATION

Control valves are sized to the demand of the system to be controlled and are frequently smaller than supply line sizes. They should be installed as close as possible to the coil being controlled. Preferably a control valve should be installed in the vertical position so the actuator will be over the valve, but can be installed in any position if necessary.

When installing a valve, these simple precautions should be taken:

1. Install a pipeline strainer just ahead of the valve.
2. Install the valve so it closes against the flow.
3. Allow sufficient clearance so that the valve may be easily serviced.

For a VP2510 Series Control Valve, clearance is required only above the actuator. With sufficient clearance above the actuator, both the actuator and valve plug can be easily removed. See Table II for required clearances (dimension E).

For a VP2511 Series Control Valve, the same clearance is required above the actuator as is required for VP2510 normally-open control valves. However, due to the fact that the valve plug assembly must be removed from the bottom of the valve body, clearance must be allowed for this purpose. See Table III for clearance (dimension F).

AUXILIARY VIEW

ACTUATOR SIZE (in. ²)	NPT (Inches)
30	1/8
80	1/8

Figure 2 - DIMENSIONS

DIMENSIONS AND WEIGHTS FOR VP2510 VALVES WITH ACTUATORS TABLE II

SIZE	ACT. AREA	ACT. ACTION	DIMENSIONS IN INCHES										WT. (LBS.)
			A	B	C	D	E	F	G	H	J	K	
1-1/2	30	DA	17-7/16	1-7/8	5-1/8	9	3	1	—	—	—	—	21
1-1/2	30	RA	18-3/32	1-7/8	5-1/8	9	3	1	—	—	—	—	21
2	30	DA	17-3/4	2-1/8	6-3/4	9	3	1	—	—	—	—	28
2	30	RA	18-13/32	2-1/8	6-3/4	9	3	1	—	—	—	—	28
2-1/2	30	DA	23-13/32	3-5/8	10-7/8	9	0	1	7	4	3/4	5-1/2	51
2-1/2	30	RA	24-1/16	3-5/8	10-7/8	9	6	1	7	4	3/4	5-1/2	51
2-1/2	80	DA	24-25/32	3-5/8	10-7/8	13-5/8	6	1	7	4	3/4	5-1/2	96
3	30	DA	24-3/4	3-15/16	11-3/4	9	6	1	7-1/2	4	3/4	6	59
3	30	RA	25-13/32	3-15/16	11-3/4	9	6	1	7-1/2	4	3/4	6	59
3	80	DA	26-1/8	3-15/16	11-3/4	13-5/8	6	1	7-1/2	4	3/4	6	104
4	30	DA	25-31/32	4-23/32	13-7/8	9	6	1	9	8	3/4	7-1/2	83
4	30	RA	26-5/8	4-23/32	13-7/8	9	6	1	9	8	3/4	7-1/2	83
4	80	DA	27-11/32	4-23/32	13-7/8	13-5/8	6	1	9	8	3/4	7-1/2	128

DIMENSIONS AND WEIGHTS FOR VP2511 VALVES WITH ACTUATORS TABLE III

SIZE	ACT. AREA	ACT. ACTION	DIMENSIONS IN INCHES										WT. (LBS.)
			A	B	C	D	E	F	G	H	J	K	
2-1/2	80	DA	24-31/32	4-21/32	10-7/8	13-5/8	6	13	7	4	3/4	5-1/2	96
3	80	DA	26-13/32	5-25/32	11-3/4	13-5/8	6	14	7-1/2	4	3/4	6	104
4	80	DA	27-11/16	6-7/32	13-7/8	13-5/8	6	15	9	8	3/4	7-1/2	128

- NOTES: 1. Add 3/4" to dimension "A" when a Positive Positioning Relay is used.
2. Add 3-3/4" to dimensions "A" when 8-12 psi spring is used with 80 in.² Actuator.

ADJUSTMENTS

Because of pressure conditions in the system, it may be necessary to adjust the actuator stroke starting point. To raise the start point,

turn the Spring Adjustor clockwise, looking at the top of a DA actuator and counterclockwise on an RA actuator.

MAINTENANCE AND REPAIR

The VP2510 and VP2511 Series Valves require little maintenance after proper installation and adjustment. It is recommended that

field repairs be limited to replacement of Packing and Valve Discs.

ACTUATOR REMOVAL (See Fig. 3)

To service the valve, remove the actuator as follows:

1. Disconnect Valve Stem (2) from Actuator Stem Assembly (F). On normally-closed valve-actuator assemblies, apply sufficient air pressure to move valve disc off seat. Remove Pin Connector (1) or Split Nut (K).
2. Where applicable remove Indicator (W). Remove Clamp Nut (17) or Adapter and Bolts (32), and disengage actuator assembly.

1-1/2" Through 2" Size

2-1/2" Through 4" Size

Figure 3 – ACTUATOR REPLACEMENT

1-1/2" Through 2" Size
TEFLON® V-RING PACKING

2-1/2" Through 4" Size
TEFLON® V-RING PACKING

1-1/2" Through 2" Size
U-CUP PACKING

2-1/2" Through 4" Size
U-CUP PACKING

Figure 4 – PACKING REPLACEMENT

PACKING REPLACEMENT (See Fig. 4)

If valve stem leakage is encountered, Packing (5) should be replaced as follows:

1. Remove actuator as outlined under "Actuator Removal."
2. Remove Packing Nut (3).
3. Remove all parts from packing cavity.
4. Be sure packing cavity in Bonnet and Valve Stem is clean.
5. Installation of new packing:

a. Teflon V-Ring Packing:

Install Packing Spring (8) and Spring Plate (7). Install new Packing (5), Packing Follower (4) and Washer (9). Before installing new Packing (5) apply a small amount of valve seal lubricant to valve stem under each V-Ring. When sliding

Packing (5) over Valve Stem (2) DO NOT DAMAGE SEALING LIP. Install Packing Nut (3).

b. Rubber U-Cup Packing:

Install Spacer (6). Apply a bead of valve seal lubricant around valve stem and push a rubber U-Cup Packing (5) over stem and into packing cavity, thereby lubricating the inside diameter of the U-Cup and filling the annular groove in the U-Cup with lubricant.

Repeat this procedure with a second U-Cup Packing (5), taking care with each U-Cup not to damage the sealing lip. Install Packing Follower (4) and Packing Nut (3).

6. Tighten Packing Nut (3) to positive stop.

VALVE DISC REPLACEMENT

If indications of valve seat leakage are encountered, the Valve Disc (12) should be replaced as outlined below.

*NOTE: While handling the Valve Plug Assembly, care should be exercised to prevent damage to the highly finished packing and bearing surfaces.

A. VP2510 Valves (See Fig. 5):

1. Remove Actuator as outlined under Actuator Removal and remove Bonnet (9) with Valve Plug Assembly.
2. Loosen Packing Nut (3) to free Packing on Valve Stem (2).

3. Disengage Valve Plug Assembly from Bonnet (9).
4. Disassemble Valve Plug Assembly* and replace Valve Disc (12).
5. Reassemble all parts in reverse order using care not to damage sealing lip of Packing.
6. Tighten Packing Nut (3).
7. Check operation to be sure actuator will operate valve properly.

Figure 5 – VALVE DISC REPLACEMENT, VP2510 VALVES

B. VP2511 Valves (See Fig. 6)

NOTE: Actuator need not be removed from valve body.

1. Apply sufficient air pressure to actuator to move Valve Disc (12) off seat, and remove Split Nut Connector.
2. With no pressure on actuator, loosen Packing Nut (3) to free Packing on Valve Stem (2).
3. Remove Bonnet (9).
4. Remove Valve Plug Assembly.*

5. Disassemble Valve Plug Assembly* and replace Valve Disc (12).
6. Reassemble all parts in reverse order, taking care not to damage sealing lip of Packing.
7. Tighten Packing Nut (3).
8. Check operation to be sure actuator will operate valve properly.

Figure 6 – VALVE DISC REPLACEMENT, VP2511 VALVES

VALVE STROKE ADJUSTMENT

If, because of parts replacement, valve travel adjustment is required, it can be accomplished as follows:

A. VP2510 Valves

1. For sizes through 2" with 30 sq. inch DA actuator. (Fig. 7A)
 - a. With no pressure on the actuator remove Pin Connector (1) and adjust position of Travel Indicator Scale (L) so the valve open mark is aligned with Travel Indicator (W).
 - b. Raise Valve Stem (2) through rated stroke. When this is done, adjust Stem Connector to align holes in Stem (2) and Stem Connector. Replace Pin Connector (1).
2. For sizes through 2" with 30 sq. inch RA actuator. (Fig. 7A)
 - a. Apply air pressure to the actuator until the Valve Plug moves off seat.
 - b. Remove Pin Connector (1).
 - c. With no pressure on actuator, move Valve Plug against seat. Adjust Stem Connector so that the hole through it is approximately 1/16" below hole in Valve Stem (2).
 - d. Apply air pressure until the two holes are aligned and replace Pin Connector (1).
 - e. Exhaust air from actuator and adjust position of Travel Indicator Scale (L) so "Valve Closed" mark is aligned with Travel Indicator (W).
3. For sizes 2-1/2"—4" with 30 sq. inch DA actuator or 80 sq. inch actuator (Fig. 7B)
 - a. With no pressure on the actuator, disconnect Split Nut (K) and place Valve Plug Assembly on seat.
 - b. Adjust the Travel Indicator (W) so it aligns with the "valve closed" mark on Travel Indicator Scale (L).
 - c. Lift Valve Plug Assembly the rated lift (to valve open mark) and secure it to the Actuator Stem (F) with Split Nut (K). Fine stroke adjustment may be obtained by loosening the Split Nut (K) slightly and screwing the

Figure 7A – VALVE STEM ATTACHMENT
(Sizes Through 2" with 30 Sq. In.)

Valve Stem (2) in or out of the Split Nut as required and then retightening the Split Nut (K).

4. For sizes 2-1/2"—4" with 30 sq. inch RA actuator (Fig. 7B)
 - a. Apply air to actuator until valve plug assembly lifts off seat.
 - b. Disconnect Split Nut (K).
 - c. Allow Valve Plug Assembly to rest on seat.
 - d. Reduce air on actuator until actuator is approximately 1/16" off stop.
 - e. Secure Valve Stem (2) to Actuator Stem (F) with Split Nut (K).
 - f. Adjust Travel Indicator (W) so it aligns with "valve closed" mark on Travel Indicator Scale (L).

B. VP2511 Valves

1. For sizes 2-1/2"—4" with 80 sq. inch actuator only (Fig. 7B)
 - a. Apply air pressure to the actuator until Valve Plug Assembly moves off seat.
 - b. Disconnect Split Nut (K).
 - c. With no pressure on the actuator, raise Valve Stem (2) until Valve Plug Assembly touches seat.
 - d. Adjust Travel Indicator (W) so it aligns with "valve closed" mark on Indicator Scale (2).
 - e. Apply air to move actuator about 1/16" off stop and secure Valve Stem (2) to Actuator Stem (F) with Split Nut (K).
 - f. Exhaust air from actuator and readjust Indicator (W) if necessary.

NOTE: To be sure the above adjustments have not changed the intended operating ranges, recheck the operating pressures and readjust actuator range as necessary.

Figure 7B – VALVE STEM ATTACHMENT
(2-1/2" Through 4" with 30 Sq. In. or 80 Sq. In.)

REPLACEMENT PARTS

Actuator Assemblies (See Figures 8 through 10):

Should it become necessary to replace any part of the actuator, release the actuator spring load by turning the Spring Adjustor (J) counterclockwise (looking at the top of the actuator) for direct

acting actuators and clockwise for reverse acting actuators. All parts may now be removed.

Figure 8 — 30 SQ. INCH DA ACTUATOR. ACTUATOR FOR VALVE SIZES 1-1/2" THRU 2" SHOWN. FOR SIZES 2-1/2" THRU 4" THIS ACTUATOR HAS SPLIT NUT CONNECTOR.

Figure 9 — 30 SQ. INCH RA ACTUATOR. ACTUATOR FOR VALVE SIZES 2-1/2" THRU 4" SHOWN. FOR SIZES 1-1/2" THRU 2" THIS ACTUATOR HAS PIN CONNECTOR.

80 SQ. IN. W/POSITIONER

Figure 10 — 80 SQ. INCH ACTUATOR

SPACER IS REQUIRED FOR 80" W/8-12 PSI ACTUATOR

VALVE BODY ASSEMBLIES (1-1/2" Through 2" Size)

Figure 11 – MODEL VP2510 DIRECT ACTING

VALVE BODY ASSEMBLIES (2-1/2" Through 4" Size)

Figure 12 – MODEL VP2510, DIRECT ACTING

Figure 13 – MODEL VP2511 REVERSE ACTING
(For 80 Sq. In. Actuator Only)

TP2252 pneumatic temperature transmitters are designed to measure air or fluid temperatures in pneumatic control systems and transmit a fixed-span, 3 to 15 psig signal to controlling and indicating devices, such as receiver controllers, receiver gauges and sensitive pressure switches. These transmitters are available with several types of sensing elements (rigid stem, averaging, remote bulb or a rigid coil for fast response) and various temperature ranges to meet most control system application requirements.

TP2252 transmitters are "one-pipe" devices requiring an externally restricted source of constant pressure control air. Their design features pneumatic feedback to assure accuracy and stability over a wide temperature span.

External mounting ears are provided for strain-free mounting on ducts or other flat surfaces. Separable wells are available for rigid stem elements for immersion sensing in fluid systems.

SPECIFICATIONS

Action	direct — proportional
Adjustments	none
Supply pressure	20 psig ± 0.5 psi
Output pressure	3 to 15 psi
Maximum safe pressure	30 psi
Air connection	1/8" — 27 female NPT
Maximum ambient temperature	140° F
Material	copper element, cast aluminum base, cadmium plated steel cover
Weight	15 oz.
Air use	0.017 CFM

ORDERING INFORMATION

Specify:

1. Model number.
2. Accessories (as required)

TRANSMITTERS — RIGID ELEMENTS

UNI-LINE NUMBER	FACTORY MODEL	DESCRIPTION	
		RANGE	THERMAL ELEMENT
TP2252-510	T150-1011	40 to 140° F	1/4" DIA. x 9-1/4"
TP2252-250	T150-1021	0 to 100° F	1/4" DIA. x 9-1/4"
TP2252-610	T150-1031	40 to 240° F	1/4" DIA. x 7-1/4"
TP2252-110	T150-1041	-40 to 160° F	1/4" DIA. x 7-1/4"

TRANSMITTERS — FLEXIBLE ELEMENTS

TP2252-501	T150-1012	40 to 140° F	20' AVERAGING
TP2252-251	T150-1022	0 to 100° F	20' AVERAGING
TP2252-502	T150-1013	40 to 140° F	COILED ELEMENT, APPROX. 12" L
TP2252-252	T150-1023	0 to 100° F	COILED ELEMENT, APPROX. 12" L
TP2252-151	T150-1054	-25 to 125° F	4" x 1/4" BULB W/3' CAPILLARY

ACCESSORIES

UNI-LINE NUMBER	FACTORY MODEL	DESCRIPTION
P20-782	100-25	WELL (COPPER) FOR TP2252 WITH RIGID ELEMENT
P20-803	100-47	ADAPTER FOR MOUNTING TP2252 IN STANDARD WELL
P20-805	100-49	WELL (ST. STEEL) FOR TP2252 WITH RIGID ELEMENT
P20-938	N4-31	RESTRICTOR TEE FOR USE WITH 1/4" O.D. POLY. TUBING ONLY
P20-944	N4-32	RESTRICTOR TEE — COMPRESSION FOR USE WITH 1/4" O.D. COPPER OR POLY. TUBING

DIMENSIONS

MAINTENANCE AND REPAIR

TP2252 transmitters feature design simplicity which insures continued efficient operation without special maintenance requirements. In the event of a malfunction that is determined not to be caused by a clogged filter or restrictor in the air supply line, replace the defective unit with a new device.

TYPICAL APPLICATION

Figure 3 - TP2252 IMMERSION WELLS FOR RIGID STEM ELEMENTS

DATA SHEET

PP2341

PNEUMATIC RECEIVER CONTROLLER (SINGLE AND DUAL INPUT)

Model PP2341 Receiver Controllers are used with remote pneumatic transmitters to provide proportional control of air conditioning systems. They are designed primarily for use with Robertshaw pneumatic temperature transmitters; however, they can be used with any pneumatic device having a calibrated output of 3 to 15 psig, such as relative humidity or pressure transmitters, thermostats or humidistats.

The PP2341 design incorporates the pilot-bleed relay and pneumatic feedback principles usually found in industrial type instruments. These assure accuracy and stability over the entire operating range. The instrument can be used for both single and dual input requirements. When used as a single input instrument, simply connect air line from primary transmitter to port #1 and leave ports #2 and #3 open to atmosphere.

The throttling range and the submaster effect of the secondary input (dual input applications) are fully adjustable.

ORDERING INFORMATION

Specify:

1. Model number
2. Accessories if required

CONTROLLER

UNI-LINE NUMBER	FACTORY MODEL	INPUT	COMMENTS
PP2341-001	P341	DUAL W/REMOTE SET- POINT ADJUSTMENT CAN BE USED AS SINGLE INPUT OR DUAL INPUT W/RE- MOTE SETPOINT ADJUSTMENT	COVER IN- CLUDED

ACCESSORIES

UNI-LINE NUMBER	FACTORY MODEL	DESCRIPTION
P20-983	N4-517	HEX HEAD 1/8" MPT FOR PLUG- GING UNUSED GAUGE PORTS

SPECIFICATIONS

Action	direct or reverse*
Setpoint	adjustable; graduated dial with 0.25 psi divisions
Throttling range	adjustable 4 to 40% (.5 to 5.0 psi)
Authority	adjustable 20 to 200% of primary transmitter effect (submaster effect of secondary transmitter on setpoint)
Remote adjustment effect on setpoint	±15% of primary transmitter span. Direct acting
Input signals	port #1 — 3-15 psig port #2 — 3-15 psig port #3 — 3-15 psig
Supply air pressure	20 psig
Maximum air pressure	30 psig
Air connections	3/16" dia nipples for 1/4" OD polyethylene tubing. P20-884 spring clips (included) must be used
Air use	36 scfm
Ambient temperature limits	40 to 140° F
Dimensions	see figure 1
Finish	base — natural, cover — gray Lexan®
Mounting	#8 screws

*For reverse action use RP2360-151 reversing relay in branch line.

DIMENSIONS

DIFFERENTIAL PRESSURE CONTROLLER

The Model PP2310 Differential Pressure Controller is a pneumatic instrument designed for applications where a constant pressure difference is to be maintained between two points. This unit incorporates the pilot-bleed relay and pneumatic feedback principles, usually found in industrial type instruments, to assure accuracy and stability over the entire operating range.

This device is normally used on forced circulation water systems having two-way valve control at the terminal units, to maintain a constant pressure difference across the supply and return mains. Final control is a throttling valve, located either in a pump bypass or directly in the pump discharge line.

The differential element is a diaphragm assembly with opposing movements. When two pressures are applied, the resultant force is transmitted to the instrument as positive linear movements, thus allowing the dial graduations to be uniform over the operating range.

This unit can be field adjusted to perform either proportional or two-position control, with either direct or reverse action. Throttling range or differential is also field adjustable. All adjustments are set on large, easy-to-read, calibrated dials that are concealed when the cover is attached. The cover and baseplate are die-castings, component parts are aluminum and stainless steel and the diaphragms are Buna N on nylon to insure long operating life. The alternate piping connections permit the unit to be panel mounted with all pipe fittings concealed, thus providing a neat front-of-board appearance.

ORDERING INFORMATION

Specify:

1. Model number
2. Accessories if required (see below)

The versatility designed into the PP2310 makes it adaptable for use as a:

- Controller with proportional output signal.
- Controller with two-position output signal.
- Differential Pressure transmitter in pneumatic transmission systems.

CONTROLLER

UNI-LINE NUMBER	FACTORY MODEL	RANGE	MAXIMUM PRESSURE	FINISH
PP2310-301	P310-03	0.5 - 50 psi	85 psi	SATIN CHROME ENAMEL

SPECIFICATIONS

Temperature limit of element	20 to 220° F
Action	proportional — direct or reverse two-position — direct or reverse
Throttling range	adjustable 1 to 50 psi
Differential	adjustable 1 to 8 psi
Adjustment means	graduated dials changeover lever for adjusting direct or reverse action
Operating pressures	main air — 15 to 20 psi standard branch pressure — 3 to 15 psi maximum — 25 psi
Connections	1/8" NPTF
Air use	0.020 CFM
Weight	2.1 lbs.

ACCESSORIES

UNI-LINE NUMBER	FACTORY MODEL	DESCRIPTION
P20 781	100 21	SET POINT STOP KIT
P20-969	N4-4	HAND VALVE — 1/4" NPT
P20-973	N4-5	HAND VALVE — 1/2" NPT

GENERAL INSTRUCTIONS

1. Do not exceed pressure and temperature limitations.
2. Controller should be mounted on a surface that is free from excessive vibration.
3. This device is to be used ONLY ON WATER AND AIR SYSTEMS. DO NOT USE ON ANY OTHER MEDIA.

INSTALLATION

Figure 1 - INSTALLATION DIMENSIONS

MOUNTING

The PP2310 should be located near the point of differential pressure measurement to keep the sensing lines as short as possible. IF LOCAL CODES APPLY, THEY MUST BE OBSERVED.

Central control panel mounting IS NOT RECOMMENDED if the sensing lines must exceed 50 feet. Pneumatic transmission is recommended for this type of application. Panel mounting is described below for the installations meeting the above requirements.

Always mount Controller in the vertical position with the pressure connections (H) and (L) on the bottom.

PANEL MOUNTING — Controller should be located BELOW other devices as a precaution against damage due to possible sensing line leaks. Provide a panel cutout, two mounting holes and two pressure connection access holes as shown in Fig. 1.

Remove the pipe plugs from the connections in the back of the base plate, using a 3/16\" Allen wrench. Install these plugs in the connections on the top of the base plate. Install the protective plastic plugs in the open connections.

Remove the Cover by loosening the Cover Screw and lifting the cover out and up.

Remove the plastic plugs from connections (H) and (L). Install 1/8\" street elbows in these connections and face them through the two access holes.

Attach the Controller securely to the panel with two #8 round-head machine screws.

Replace the Cover.

WALL MOUNTING — Select a location that is free from excessive vibration and where the Controller will be accessible for calibration, inspection and servicing.

Remove the Cover. Hold the Controller in place and mark the mounting hole locations. Drill mounting holes as required by the type of surface. Attach the Controller securely to the mounting surface using #8 round-head machine screws, wood screws, or toggle bolts (as required by the application) in the slotted holes in the baseplate. Replace the Cover.

Figure 2 - TYPICAL INSTALLATION ON A WATER SYSTEM

CONTROLLED PRESSURE PIPING

Piping to the PP2310 should not be smaller than 1/4" I.D. Always provide gauges, or gauge tees, and shut-off valves to facilitate

calibration and servicing. Fine mesh strainers should be installed to protect the instrument (Fig. 2).

PNEUMATIC PIPING

Remove the plastic plugs from the piping connections. Inspect each connection to be sure Filters are in place. Replace any that are missing.

Connect main air (15 psi) to the center port (M). Connect branch line serving the controlled device to the left-hand port (B). The right-hand port (R) is not used on the PP2310; however, it **NEED NOT BE PLUGGED**.

When the Controller is wall mounted, a gauge tee and gauge should be installed in the branch line. If a main air gauge is required, install a 1/8" x 1" brass pipe nipple and coupling between the "M" port

and gauge tee, as shown in Fig. 3, to provide the proper gauge clearance. Gauge tees **MUST BE INSTALLED PRIOR** to mounting the controller since clearance is not sufficient to permit installation **AFTER** mounting.

A panel mounted Controller will be back connected and indicating gauges will be flush mounted on the panel.

Ream control air piping or tubing and keep it free of dirt, chips and excess pipe compound. When installing fittings, apply pipe compound sparingly to the male threads only, leaving the first two threads clean.

ADJUSTMENTS

Figure 3 — PP2310 WITH COVER REMOVED

ADJUSTMENTS (Continued)

The PP2310 may be adjusted to perform the control functions outlined under "General Description". After the device has been mounted and piped, apply 15-20 psi main air in port "M", remove the Cover and adjust as follows:

STEP 1: Set the action, Direct or Reverse.

STEP 2: Set the Throttling Range or Differential.

STEP 3: Calibrate and set the Control Range. Tighten Set Point Lock Screw (12).

The following outlines the above steps in detail:

ACTION — Determine the action (DA or RA) required by the application. The unit is shipped from the factory set for Direct Acting; the Changeover Lever (5) is on the right hand side of the Set Point Scale (2) in CONTACT WITH THE STOP MARKED "D". The Set Point Scale (2) is marked "DA".

The controller may be changed to Reverse Action by moving the Changeover Lever (5) from the right hand side to the left hand side of the Set Point Scale (2) and in CONTACT WITH THE STOP MARKED "R". Loosen Set Point Lock Screw (12) and remove Set Point Lock Tab (13). Remove the two Dial Screws (10) and turn the Set Point Scale over to the side marked "RA". Replace the Dial Screws (10) and Set Point Lock Tab (13).

THROTTLING RANGE — The correct TR setting will be determined by the requirements of each individual installation. If the setting is too wide, there may be wide deviations from control point. If the setting is too narrow, there will be a tendency to "hunt" or cycle. In general the TR setting should be as narrow as possible without producing a "hunting" condition.

Using a screw driver, turn the Throttling Range Dial (7) to the required setting. The TR is equally divided on either side of the Set Point. For example, assume the set point is 20 psi and the TR setting is 10 psi. The branch line pressure will then gradually increase from 3 to 15 psi as the differential pressure changes from 15 psi to 25 psi if the PP2310 is DA, and vice versa for RA.

DIFFERENTIAL — Turn the Throttling Range Dial (7) counter-clockwise past zero to the portion of the scale marked "DIFF." and make the required setting. The Differential is equally divided on either side of the Set Point. For example, assume the set point is 20 psi and Differential setting is 10 psi. The branch line pressure will be 0 psi at 15 psi (D/P) and 15 psi at 25 psi (D/P) if the PP2310 is DA, and vice versa for RA.

CALIBRATION AND CONTROL POINT — Check the existing differential pressure on the D/P element. This MUST BE WITHIN THE RANGE of the controller and remain stationary. If this cannot be accomplished, "bench calibration" using air pressure will be necessary. Loosen Dial Screws (10) and Set Point Lock Screw (12) so the Set Point Scale (2) will rotate freely. Turn the Set Point Adjustment Screw (1) until the branch line gauge indicates 9 psi (Midpoint of the 3-15 psi range). This is the normal calibration point; however, if the controlled device operates on some other range, the calibration point should be the MIDPOINT of that range. Turn the Set Point Scale (2) until the dial marking corresponding to the measured differential pressure value is lined up with the Indicator Tab (14). Tighten the Dial Screws (10).

Using a screw driver in the Set Point Adjusting Screw (1), turn the Set Point Scale (2) to the desired control point setting. Insert the Set Point Lock Tab (13) into the slot provided on the Indicator Tab (14) and tighten the Set Point Lock Screw (12) to secure. Two slots are provided on Indicator Tab (14) in the event the tab on the Set Point Scale (2) falls at the point where Set Point Lock Tab (13) is shown in Fig. 3.

ADJUSTMENT WHEN USED AS A DIFFERENTIAL PRESSURE TRANSMITTER — The Throttling Range setting must be IDENTICAL to the scale range of the pneumatic receiver gauge. The range of the gauge and/or the Receiver Controller must be 3-15 psi. The PP2310 Set Point must be identical to the mid-point of the gauge scale range. Calibration is the same as described above.

OPERATION CHECK-OUT — When the control system is placed in operation and the controlled media has been balanced, the PP2310 should be checked to insure its correct operation in the system. Re-adjust as necessary (See Adjustments). Control Point settings may be changed without re-calibration but changes in Action, Throttling Range or Differential require re-calibration.

Covers should be securely attached after adjustments have been completed.

Figure 4 - SCHEMATIC DIAGRAM

DIRECT ACTING - Changeover Lever (6) in the "D" position. On an increase in differential pressure the sensing element imparts an upward force on the Input Lever (8), causing it to pivot on axis 1-1. This movement is received by the Set Point Lever (7) at point "A" and it pivots on axis B-C. Point "D" moves down and the RA-DA Lever (4) moves down, pivoting on axis 2-2. This movement is received by the Output Lever (13) at point "X". Point "X" moves down (point "Y" is fixed), thus permitting the Leakport Lever (1) to move down (pivoting on axis 3-3) and close the Leakport (2). The branch line pressure increases.

Branch line pressure is connected to the Feedback Diaphragm (9). Pre-load Spring (11) is factory set so the feedback is not effective until the branch line pressure is 3 psi. The feedback mechanism provides a true proportional relationship between the sensing element movement and the branch pressure. In addition it provides TR and DIFF. adjustment. Throttling Range Dial (12) is used to adjust the position of Point "N" on the Feedback Assembly Lever (10).

Moving the position of Point "N" to the left of axis 5-5 varies the effect of the feedback from minimum to maximum, giving an adjustable throttling range.

With the Point "N" to the left of axis 5-5, as the branch line pressure increases, Point "N" is moved up, pivoting on axis 4-4. This movement is received by the Output Lever (13) at Point "Z", moving the Output Lever (13) up, thus raising the Leakport Lever (1) to open the Leakport (2) and balance the Relay (3) at the correct branch line pressure.

Moving the position of Point "N" to the right of axis 5-5 results in negative feedback, which, in turn, changes the action to two-position control with an adjustable differential.

With Point "N" to the right of axis 5-5, as the branch line pressure increases, Point "N" is moved down. This movement is received by Output Lever (13) at Point "Z", moving Output Lever (13) down, thus lowering the Leakport Lever (1), closing the Leakport (2), and the Relay (3) cannot balance at an intermediate branch line pressure.

Decreasing differential pressure at the sensing element causes reverse lever movements from those above described.

REVERSE ACTING - Changeover Lever (6) in the "R" position. On an increase in differential pressure the sensing element imparts an upward force on the Input Lever (8), causing it to pivot on axis 1-1. This movement is received by the Set Point Lever (7) at point "A" and it pivots on axis B-C. Point "R" moves up and the RA-DA Lever (4) moves up, pivoting on axis 2-2. This movement is received by the Output Lever (13) at point "X". Point "X" moves up (point "Y" is fixed), thus lifting the Leakport Lever (1) and opening the Leakport (2). The branch line pressure decreases.

The feedback mechanism operates as described under Direct Acting.

RELAY UNIT - The relay unit is a 2:1 ratio, pilot-bleed type. The effective area of the Pilot Diaphragm (19) is twice that of the Operating Diaphragm (20). With the Leakport (2) open, the Pilot Chamber (15) pressure cannot open the Main Valve (18) due to the Balance Spring (16). As the Leakport (2) is gradually closed by the Leakport Lever (1), the pressure in the Pilot Chamber (15) increases. The downward force on the Pilot Diaphragm (19) overcomes the Balance Spring (16), closes the exhaust port and opens the Main Valve (18). Main air enters the branch chamber, branch line and Feedback Diaphragm (9) until the upward force on the Operating Diaphragm (20) plus the Balance Spring (16) exceeds the downward force on the Pilot Diaphragm (19). When this occurs, the Main Valve (18) is closed by the Valve Spring (17) and the relay is in balance.

When the Leakport Lever (1) moves away from the Leakport (2) the Pilot Chamber (15) pressure is reduced. The excess upward force on the Operating Diaphragm (20) opens the exhaust port to atmosphere. The branch line is exhausted until the forces are again in balance, at which time the exhaust port closes.

The Main Valve (18) is non-bleed and only uses air when increasing the branch line pressure. Leakport Lever (1) movements are very small and it is never necessary that the Leakport (2) be completely closed.

MAINTENANCE AND REPAIRS

The PP2310 requires very little maintenance due to the simplified design, material of the components and small movements of the operating parts.

The unit should be inspected yearly to insure correct system operation, as follows (See Fig. 3):

1. Remove Cover.
2. Dirt or dust accumulations should be removed with a soft brush or a low pressure air stream.
3. Make sure pressure sensing lines are not restricted.
4. Check Throttling Range by turning the Set Point Adjusting Screw (1) until the branch line gauge reading is 3 psi. Note the Set Point and turn Set Point Adjusting Screw (1) until the branch line is 15 psi. Note the Set Point. The difference between the two Set Point readings is the actual TR of the Controller. If necessary, re-adjust the TR and recalibrate (see Adjustments).
5. Check calibration by measuring the differential pressure with accurate gauges. Divide 12 psi by the TR setting to obtain branch pressure change per 1 psi differential pressure change. Multiply this value by the difference between the set point and the measured differential pressure. Add this value to 9 psi if measured differential pressure is above Set Point, subtract if below Set Point. Totals will be within the 0-15 psi range if the measured differential pressure is within the TR setting. This is reversed for a "Reverse Acting" controller. If the original calibration point was not 9 psi, compute values based on the original point.

If the above indicates a need for re-calibration, refer to "Adjustments".

Field Repairs should be limited to:

1. Replacement of the Filter, Leakport, and Restrictor.

If more extensive repairs are necessary, replace the PP2310 with a new or factory reconditioned unit and return the defective unit to the factory.

CORRECT OPERATION OF THE RELAY UNIT may be determined as follows (see Fig. 3):

Loosen Set Point Lock Screw (12) and turn Set Point Adjusting Screw (1) until the Leakport is closed. Branch line pressure should

increase quickly to 15 psi. Then lift Leakport Lever (9) to open the Leakport. Branch line pressure should decrease quickly to 0 psi. Release Leakport Lever (9) gradually SO IT DOES NOT HIT the Leakport.

If the branch line pressure WILL NOT INCREASE to 15 psi, or the increase is slow, a partially clogged Filter and/or Restrictor is indicated. If the branch line pressure will not decrease to 0 psi, or if the decrease is slow, a restricted Leakport is indicated.

If the above test indicates the Filter, Restrictor and Leakport should be replaced, proceed as follows:

1. Disconnect main air line and plug it to prevent loss of air.
2. Remove Filter Cap (3) and remove Filter with a pair of tweezers. Install new Filter and replace Filter Cap (3).
3. Remove Restrictor Cover Screw (4). Remove Fixed Restrictor, using a 1/16" Allen wrench. Install replacement Restrictor, making sure it is screwed in until it bottoms in the opening. THIS IS VERY IMPORTANT. Replace Restrictor Cover Screw (4).
4. Remove Set Point Lock Tab (13), Dial Screws (10) and Set Point Scale (2). Remove Set Point Adjusting Screw (1), turning counter-clockwise. Lift Leakport Lever (9) off its pivot points and turn it to the right until the Leakport is exposed. Remove Leakport, using a 1/4" socket or box wrench.
5. Install replacement Leakport securely. Reposition Leakport Lever (9) on its pivot points and over the Leakport.
6. Reconnect main air to the Controller.
7. Measure differential pressure with accurate gauges.
8. Replace Set Point Adjusting Screw (1) and turn it clockwise until the branch line gauge reads 9 psi. Replace Set Point Scale (2) and Dial Screws (10). Turn Set Point Scale (2) until the dial marking corresponding to the differential pressure gauge reading (Step 7) is lined up with the pointer. Tighten Dial Screws (10). Replace Set Point Lock Tab (13) and secure in place. The PP2310 is now in calibration.
9. Replace Cover and tighten Cover Screw.

Robertshaw

CONTROLS COMPANY
Uni-Line Division

GP2422 RECEIVER GAUGES UNI-KITS®

The GP2422 RECEIVER GAUGE UNI-KITS now include eleven range scale overlays, see list below for ranges. No more ordering the scales and gauges separately — they are packaged together.

Uni-Kit Receiver Gauges are available in 2", 2-1/2" and 3-1/2" sizes. The GP2422-003 (2") Receiver Gauges are stem mounting, back connected type gauges and are used on those applications not requiring flush mounting on a panel. The case is a gray Lexan® and these gauges also use a bourdon tube to actuate a brass gear movement.

The GP2422-001 (2-1/2") and GP2422-002 (3-1/2") gauges are a flush mounting type. These gauges have zinc plated stell cases with chrome plated snap out rings. They are activated by a bourdon tube through sturdy brass gears. A U-clamp mounting arrangement is standard for use in mounting these gauges on a panel. An adjustable pointer allows accurate zero adjustment on both models.

Range scale overlays included:

-40 to 160°F.
-25 to 125°F.
0 to 100°F.
40 to 100°F.
40 to 140°F.
40 to 240°F.
50 to 90°F.
62.5 to 92.5°F.
0 to 2.0" W.C.
0 to 7.0" W.C.
30 to 80% RH
Blank

UNI-KIT MODEL NUMBER	FACTORY NUMBER	GAUGE SIZE	SIGNAL (PSI)	MOUNTING
GP2422-001	A251	2-1/2" DIA.	3 TO 15	PANEL TYPE WITH 1/4" BARB CON- NECTION STEM TYPE 1/8" PIPE.
GP2422-002	A252	3-1/2" DIA.		
GP2422-003	A253-11	2" DIA.		

MOUNTING DIMENSIONS

DIMENSIONS IN INCHES

MODEL	A	B	C	D	E	F	G	H	J
GP2422-001	2-29/32	1-3/16	3/4	1	1-7/8	1-3/8	2-9/32	2-19/32	1/16
GP2422-002	4	1-3/16	3/4	1	2-15/16	1-11/32	3-15/64	3-23/32	1/16

MODEL GP2422-001

MODEL GP2422-002

MODEL GP2422 2" FIXED SCALE MODELS

ST3990 SERIES

SOLAR COMMANDER

P.O. BOX 2000, 4190 TEMESCAL ST.
CORONA, CA 91720

28 1980

The ST3990 Solar Commander provides sensitive temperature response and solid state switching to effectively operate a circulating pump in a liquid filled solar heat storage system.

The ST3990 Solar Commander provides pump circulation cut-in when the collector panel temperature is higher than the storage tank. The Solar Commander cut-in temperature differential is adjustable from 8 to 20°F. Temperature differentials of 5° or less between these points will signal the Solar Commander to turn the circulating pump off. The pump switch action is accomplished with solid state components, capable of handling loads up to 3.8 amp inductive, eliminating the need for any moving parts in the controller circuit.

The Solar Commander circuit incorporates electrical isolation protection for both input and output signal. The entire electrical circuit is protected by space age encapsulation.

The Solar Commander comes equipped with an easy access terminal strip for the low voltage sensor circuit and line leads hook-up. The case-frame is equipped with line lead conduit adapter access.

Solid State Thermistor Sensors, of special design, are utilized to accurately signal temperature differential to the control circuit from the solar collector and the storage tank with maximum accuracy from extended distances if necessary.

The Solar Commander sensors are conveniently encapsulated in 5/16" x 1-1/4" copper tubing and come with 6" lead lengths.

ORDERING INFORMATION

All models have the features listed under specifications except as noted under comments below.

ORDER NUMBER	FACTORY NUMBER	COMMENTS
ST3990-101*	SD10-2601	Standard device
ST3990-103*	SD10-3201	Includes freeze protection
ST3990-104*	SD10-3601	Without hi-limit feature
P30-098	SS10-1001	Replacement sensor (1)†

*Includes (2) P30-098 sensors

†Sensors are interchangeable

SPECIFICATIONS

Cut-in differential	adjustable 8 to 20°F
Cut-out differential	fixed 5° ± 3°F
Sensor	300°F rated thermistor (interchangeable)
Sensor size	5/16" dia x 1-1/4" long with 6" leads
Recycling upper limit	190°F
Three position switch	on-off-auto
Pilot lights	power on pump on
Freeze protection	cut-in 37°F. (Model ST3990-103 only) cut-out 41°F.
Ambient temperature	32° to 150°F

ELECTRICAL RATING

80 to 130 VAC, 50 or 60 Hz (cycles)

3.8 amps full load inductive, 29 amps locked rotor

SENSOR INSTALLATION INSTRUCTIONS

Good thermal transfer from the controlled medium is important. A heat sensitive compound such as GE Insulgrease #640 or Dow Corning #340 Heat Sink Compound may be used between the sensors and the surfaces to which they are being applied.

The Solar Commander Sensors are designed for surface mounting. To facilitate this, two mounting clips are included with each Solar Commander. Usually the collector sensor should be mounted on a part of the collector panel which will be directly exposed to solar input. It should also be near the collector outlet so the sensor is also reading outlet water temperature.

Sensors are rated at 300°F. maximum. Excessive time exposed to temperatures over 300°F. will degrade the sensor affecting its

calibration. (For conditions above 300°F, an optional 400°F, rated sensor is available.) Figure 1 shows a set of representative resistance values to use in checking the sensors. If a faulty sensor is suspected, disconnect the sensors from the controller and measure the resistance of the sensor with an ohmmeter. This resistance should be compared to the temperature measured at the sensor using the chart in Figure 1 as a guide. An open or short circuit would indicate that the sensor should be replaced using a P30-098. These values may be used as a guide to the operation of the control but should not be used as a calibration check.

To wire the sensors, #18 wire may be used. If the sensor leads parallel the line voltage wiring for any distance, shielded cable or twisted wire must be used to minimize interference.

°F	RESISTANCE	°F	RESISTANCE
40°	83,164	140°	6,777
50°	62,354	150°	5,485
60°	47,211	160°	4,465
70°	36,057	170°	3,656
80°	27,776	180°	3,010
90°	21,558	190°	2,490
100°	16,860	200°	2,070
110°	13,291	210°	1,731
120°	10,545	220°	1,453
130°	8,430	230°	1,225

NOTE: All wiring must conform to all local electrical codes or ordinances.

- NOTE:** Before wiring the Solar Commander to the circulating pump, be sure to check the pump circuit for dead short circuit or ground faults. Do not test pump motor by jumping common and load terminals. Permanent damage to the Triac will result and void warranty.

- The ST3990 Series Controls come factory set at 20°F. cut-in differential. If adjustment is necessary, it is made on the cut-in adjustment pot located in approximately the center of the control. Rotating the adjustment counter-clockwise decreases the cut-in differential.

THIS DEVICE SHOULD BE INSTALLED BY A QUALIFIED PERSON WITH DUE REGARD FOR SAFETY AS IMPROPER INSTALLATION COULD RESULT IN A HAZARDOUS CONDITION.

P10 SERIES LOW PRESSURE CONTROL

SINGLE OR TWO-STAGE

P10BC-7
With Bracket No. BKT16A-600

P10FC-4

These SPDT pressure controls open or close an electrical circuit from a change in operating pressure.

Typical applications include: Pneumatic systems, control of pumps or small air compressors and pressure-electric interlock of fluid flow systems.

R to Y terminals make (cut-in) on pressure rise.

ELECTRICAL RATINGS — (For each Pennswitch)
P10BC, P10FC

Motor Rating	120 V.	208 V.	240 V.	277 V.
A.C. Full Load Amps.	16.0	9.2	8.0	7.0
A.C. Locked Rotor Amps.	96.0	55.2	48.0	42.0
Non-Inductive Amps.	16.0	9.2	8.0	7.2

Pilot Duty — 125 VA. at 24 to 277 V. A.C.

NOTE: On 2-stage models, the maximum connected load shall not exceed 2000 VA.

Controls have a visible calibrated scale and adjustable range. A universal mounting bracket No. BKT16A-600 is supplied as standard. Model P10FC-4 has a jumper installed on the common terminals. Model P10BJ-1 is rated for 24 amps. non-inductive. (See electrical ratings).

Maximum Allowable Pressure: 150 psig.

TO ORDER: Specify Catalog Number only.

P10BJ

Motor Rating	120 V.	208 V.	240 V.	277 V.	600 V.
A.C. Full Load Amps.	16.0	9.2	8.0	—	—
A.C. Locked Rotor Amps.	96.0	55.2	48.0	—	—
Non-Inductive Amps.	16.0	9.2	8.0	7.2	—
Double Throw	16.0	16.0	16.0	16.0	16.0
Single Throw	24.0	24.0	24.0	24.0	24.0

Pilot Duty — 125 VA. at 24 to 600 V. A.C.

Catalog Number	Number of Stages	Contact Action	Range (psig)	Factory Setting				Pressure Connector FNPTF	Shipping Wt. Lbs.
				(psig)	Switch Diff. (psi)				
P10BC-7	1	SPDT	3 to 20	12 R to Y Cut-in)	2			1/8"	1.0
P10BJ-1	1	SPDT	3 to 20	12 R to Y Cut-in)	2			1/8"	1.0
P10FC-4	2	SPDT	3 to 20	(R-Y Cut-in) High Stage	(R-Y Cutout) Low Stage	High Stage	Low Stage	1/8"	1.5
				12	8	2	2		

P11 SERIES HEAVY DUTY AIR COMPRESSOR SWITCHES

PRESSURE RANGES TO 250 PSIG

P11BA-1

Heavy duty pressure switches for air compressor service. Contacts OPEN on rising pressure. Available with 2-way pressure release valve for compressor systems equipped with auxiliary tank or bleeding chamber.

TO ORDER: Specify Catalog Number only.

ELECTRICAL RATINGS

Volts	Single Phase A.C.	Polyphase A.C.	D.C. (120 240 V.)
120	2 H.P.	—	1 H.P.
240-550	3 H.P.	5 H.P.	1 H.P.

A.C. NON INDUCTIVE — 25 Amps. 120 V., 1Ph.

Catalog Number	Range Min. Cut-in to Max. Cutout (psig)	Differential Adj. (psi)		Factory Setting		No. of Poles	Pressure Connector FNPTF	Shipping Wt. Lbs.
		Min.	Max.	Open	Close			

NO VALVE

P11BA-1	10 to 250	26	56	150	120	2	1/4"	4.6
---------	-----------	----	----	-----	-----	---	------	-----

2-WAY VALVE

P11BB-1	10 to 250	26	56	150	120	2	1/4"	4.8
---------	-----------	----	----	-----	-----	---	------	-----

P11BB-1

For Optional Ranges and Connectors, write 'Customer Service.'

ABSORPTION CHILLER

Refer to manuals provided by the chiller manufacturer, Arkla Industries, for its model WFB-300 chiller.

COOLING TOWER

INSTALLATION & MAINTENANCE INSTRUCTIONS

Goodfellow
COOLING TOWERS

JOMAC

OF ORLANDO, INC.

ROSEMONT BLDG. SUITE 117
5104 N. ORANGE BLOSSOM TRAIL
PH. (305) 293-8405
ORLANDO, FL 32804

E. D. Goodfellow Co., Inc.

SUBSIDIARY OF

Technology, inc.

123

415 BROOKS ROAD / P.O. BOX 2119 / MEMPHIS, TENNESSEE 38101 / (901) 398-9257

GOODFELLOW Induced Draft Cooling Towers have been designed to give the utmost in performance, long life and trouble free service. The successful operation of this type cooling tower depends mainly upon its installation. It is desired that the installer follow the instructions contained herein as closely as conditions will permit.

SETTING TOWER

The tower should be set on as firm a foundation as possible and preferably anchored. This is a **MUST** where high winds are expected. The tower should be set level in all directions, otherwise there will be an improper distribution of water over the wetted deck surfaces. Should the tower be tilted, the water will run to the low side, thus bypassing a portion of the surfaces. This will greatly impair the tower efficiency. After the tower has been placed in operation, recheck and make certain that the water is falling evenly through the entire wetted deck area. Towers equipped with spray nozzles do not require the leveling as do those which depend upon gravity fall for water distribution.

INDOOR INSTALLATION

Make certain that there is more than ample fresh air available near the air inlet of the tower. Restricted amounts of fresh air will cause unnecessary overloading of the fan and make for poor performance. It will be necessary to attach a discharge duct to the fan discharge to convey the hot humid air to the outside. This duct should be kept as short and straight as possible. **DO NOT** decrease duct size smaller than the fan opening. For very quiet operation connect the duct to the tower with a canvas or other flexible material. Cover the outlet with a very coarse screen or small size chicken wire to prevent foreign objects from entering. Do not restrict the air flow any more than is necessary. Should prevailing winds blow into the discharge, it is suggested that a suitable windbreak be installed several feet away. If this is not possible, an elbow directed downward should be installed. In all cases where the tower is equipped with a fan guard, this should be removed.

OUTDOOR INSTALLATION

Place tower so that prevailing winds blow into the inlet end and not the discharge. If this is not possible, protect the discharge as outlined above. Install weather-proof housing over motor. All towers have their supports drilled for anchoring bolts.

PIPING CONNECTIONS

If at all possible, new galvanized pipe should be used. Run all lines as short and straight as possible. (It is well to remember that one ell will cause as much friction loss as several feet of straight pipe.) In order to minimize friction loss, use as large a size pipe as possible. The gpm requirements of the system will dictate the smallest pipe size that can be used. Consult a pipe capacity-friction chart, if in doubt.

In cases where the tower is installed lower than the condensers, siphoning will take place. This may be prevented by several methods; however, one of the best and easiest is to install a good quality swing-type check valve in the pump discharge line.

It will be desirable to install a gate valve in the pump discharge line. Should the pumping head of the installation be less than that calculated, or should the pump have more capacity than required it will be necessary to control the amount of water over the tower. This is desirable for two important reasons: the more water that is pumped, the more the horsepower requirement; consequently, unnecessary current would be used. Also, in many cases too much water over the tower will not give proper operating temperatures. With all **GOODFELLOW** cooling towers with open distribution pans the water level should be at least 1- $\frac{1}{2}$ inches from the top of the distribution pan.

Towers equipped with spray nozzles should have a water pressure of 5 pounds at the tower header. This pressure indicates 3 gpm per ton is flowing through the system.

MAKE-UP

Check the float ball and valve for freedom of movement. When properly adjusted the float valve should close off when the basin is approximately half full of water. In some instances some siphoning action may take place in the line, causing the tower to overflow on the off cycle, and it may be necessary to reset the float ball. At no time should the float ball be so set as to permit cavitation to take place at the suction. A separate shutoff valve should be installed in the make-up line.

ELECTRICAL

Check motor nameplate and make certain that the power source is suitable as to voltage, phase and

frequency. Furnish and connect pump starter and controls. Towers equipped with belt driven fans should have the motor checked for proper rotation with the belt, or belts, removed. The fans on all propeller type towers should pull the air through the tower and discharge from the front.

TOWER OPERATION

After checking all electrical connections, tower basin should be filled with water. Before doing this, remove any debris that may have accumulated in the tower basin. Check suction screen, making certain it is securely in place. Purge all air from the pump volute. Start the pump and adjust the make-up valve, remembering that the water level rises when the pump shuts off due to the amount of water in the distribution pan and deck falling into the basin. After making certain that all pipe connections are good, the system should be put in operation and the float valve rechecked.

SHUTTING DOWN. If the tower is to be shut down, during the winter, or for any lengthy period of time, the cold water basin should be completely drained. At this time it is desirable to flush the tower with clear water. Should the tower be shut down for a considerable period of time, fan belts should be removed and stored in a dry place. Grooves in the sheaves should be cleaned and painted to prevent rust.

REMOTE OPERATION. In many cases where a tower is to be operated during the winter months in cold climates, it will be necessary to install a water collecting basin within the building. This collecting basin should consist of a make-up and float ball valve, screened suction, overflow and drain connections. With this type of installation, no float or overflow should be in the tower basin. These fittings should be plugged. It will be desirable to leave the suction screen in the tower basin and install an additional suction screen in the inside catch basin. The catch basin should be of sufficient capacity to contain all the water used in the system. If this is done, the tendency to overflow will be minimized.

MAINTENANCE

Totally enclosed motors with direct driven fans are permanently lubricated for their total life. Motors equipped with ball bearings are factory lubricated for at least two years of normal operation. Motors with

sleeve bearings are generally shipped without oil. It is recommended that the proper grade of oil should be S.A.E. 10 that has no additives. In any case, check the lubrication instructions supplied by the Manufacturer which are attached to each motor.

Fan shafts with ball bearings should have grease added once a month during normal operation. A high grade waterproof ball-bearing grease should be used. This grease should have Lithium or Strontium base of NLGI No. 2 consistency. DO NOT overgrease. Bronze or graphited bronze bearings should be lubricated as follows; temperature range of 70°-120°, SAE No. 50. Range of 40°-70°, SAE No. 30. High grade nondetergent oil should be used. Oil cups should be filled at least every two months of operation and at start up or after a prolonged shut down.

Gear reducers should be serviced and lubricated in strict accordance with manufacturer's recommendations, which are attached to each unit.

Belt tension should be checked after the first week of operation and twice a month thereafter. Should any apparent stretch be noticed the motor base should be adjusted for proper belt tension. On towers that have two or more belts, never replace a single belt. Replace with a MATCHED set of belts of the same size and type.

BLOW DOWN

The operation of a cooling tower causes a certain amount of evaporation of the water circulated. This evaporation does not remove any of the dissolved solids that are present in the water. Continual buildup of these solids will eventually cause a buildup of scale within the piping and condenser unit. In order to minimize this effect it is often desirable to waste a small amount of the water circulated. In most cases, a waste of .25% to .5% of the water circulated will materially alleviate this situation. The blow down, or bleed line, may be connected in any part of the system. However, it has been found most desirable that this be done by making the connection in the hot water line at the tower or from a connection from the distribution pan. In this manner, minimum waste would be obtained. It is recommended that a wrench operated valve be installed in the blow down line for proper control. It is also desirable that all water be drained from the system at periodic intervals and replaced with fresh water.

ALGAE. Under certain operating conditions a green moss, or algae, may make its appearance in the tower. Chemicals such as potassium permanganate, copper sulphate, or chlorine, may be added in small quantities. Should copper sulphate be used, do not add more than *one* ounce for each 800 gallons of water in the system as this chemical, while effective, is very corrosive. Other factors also cause algae, and, should treatment with the above chemicals not suffice, a competent Water Treatment Engineer should be consulted. The use of tower cleaning chemicals and scale removers is not recommended unless the composition of the scale is known and the proper chemicals used. The services of a competent Water Treatment Engineer should be obtained and his advice followed. Certain chemicals have strong acid content that is injurious to both wood and metal. In this regard any treatment that adds sodium carbonate such as the Zeolite process, should be avoided. Great care should be taken in the selection of cleaning compounds. Avoid those that have an acid content that will attack zinc. This is most important as

most cooling towers manufactured today have hot dipped galvanized casings, basins and other components.

CLEANING AND PAINTING

After the tower has been shut down all dirt and trash which may have collected in the water basin should be removed. The entire tower should be flushed with clean water. If any abrasions are noticed on the tower exterior, they should be sanded and primed with a coat of Zinc Chromate. After allowing sufficient time for drying, finish color should then be applied. Should it be necessary to remove the deck filling for any reason whatsoever, it should be replaced in the opposite manner from which it was removed. When replacing the deck filling make certain that all parts fit properly so that the deck filling will assemble in an even and level manner.

Should any problem arise not covered in these instructions, please communicate with our nearest representative or the factory direct.

E. D. Goodfellow Co., Inc.

SUBSIDIARY OF **therma technology, inc.**

126

415 BROOKS ROAD / P.O. BOX 2119 / MEMPHIS, TENNESSEE 38101 / (901) 398-9257

For larger capacities, these two-fan units provide the advantage of doubling single fan performance in a single tower. Flexibility of operation is apparent as close control of water temperature is possible by fan(s) control. When so ordered, a partition would be installed in the tower center, thus making the tower a two cell unit. All models are normally shipped completely assembled, to permit fast, economical installations.

FREIGHT CLASSIFICATION: All cooling towers of steel 20 gauge and thicker, or steel and wood combined, are now classified as Class 100.

Model	DIMENSIONS (in inches)																	FAN		WEIGHTS			
No.	L	W	H	A	B	C	D	E	F	G	I	J	K	M	N	P	Q	R	S	hp	slip	opr	
P100	41	144	80	10	1	17	66	19	12	4	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	140	2-1/2	3875	2125
P125	41	144	82	10	1	17	66	19	12	4	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	150	2-2	4175	2300
P15	41	160	100	10	1	17	75	19	12	4	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	1mm	160	2-1/2	4500	2400

PERFORMANCE DATA

Refrigeration capacity table, based on design conditions: 100°F inlet water, 70°F outlet water, 50% relative humidity, 1000 ft/min air velocity.

TONS OF REFRIGERATION WHEN CIRCULATING 3 GPM PER TON													
Hot Water	90	87	95	92	95	96	95	97	95	96	96	96	98
Cold Water	80	77	85	82	85	86	85	87	85	86	86	86	88
Wet Bulb	65	70	70	72	72	73	75	75	78	78	79	80	82
P3	5.0	2.6	5.0	3.6	1.5	1.5	1.5	1.5	3.1	3.1	3.1	2.9	2.6
P5	8.1	4.1	4.1	6.6	2.8	2.8	2.8	2.8	5.3	5.3	5.3	4.9	4.2
P8	11.3	5.7	5.7	9.7	4.1	4.1	4.1	4.1	7.7	7.7	7.7	7.0	5.9
P11	15.0	7.7	7.7	13.1	5.7	5.7	5.7	5.7	10.2	10.2	10.2	9.2	7.6
P15	22.4	12.2	12.2	18.1	8.1	8.1	8.1	8.1	15.6	15.6	15.6	14.2	11.9
P20	30.1	17.2	17.2	24.2	11.2	11.2	11.2	11.2	20.9	20.9	20.9	19.0	15.7
P25	38.1	21.7	21.7	30.4	14.2	14.2	14.2	14.2	25.7	25.7	25.7	23.3	19.3
P30	44.7	25.4	25.4	35.7	16.7	16.7	16.7	16.7	29.7	29.7	29.7	26.7	21.7
P40	59.4	33.7	33.7	47.7	22.2	22.2	22.2	22.2	39.7	39.7	39.7	35.7	28.7
P50	74.1	42.1	42.1	59.3	28.2	28.2	28.2	28.2	49.7	49.7	49.7	44.7	36.7
P60	89.4	50.8	50.8	71.1	34.2	34.2	34.2	34.2	59.7	59.7	59.7	53.7	43.7
P75	111.2	63.2	63.2	88.9	42.2	42.2	42.2	42.2	74.7	74.7	74.7	67.7	54.7
P100	148.2	84.2	84.2	118.6	56.2	56.2	56.2	56.2	99.7	99.7	99.7	90.7	73.7
P125	182.0	105.0	105.0	146.3	70.2	70.2	70.2	70.2	124.7	124.7	124.7	113.7	92.7
P150	222.3	126.3	126.3	177.9	85.2	85.2	85.2	85.2	154.7	154.7	154.7	140.7	114.7

For 40°F to 70°F range, 95°F inlet water, add 10% to capacities shown.

FILTERS, VALVES, AND MISCELLANEOUS

Models SS-1 and SS-2 Heavy Duty Filters for point-of-use and small systems

Almost everyone reacts negatively to water that tastes and smells bad . . . or looks cloudy from "un-identified" particles. It creates a poor impression, destroys good will, hurts business. The world leader in solving bad water problems is AMF Cuno. This bulletin describes heavy duty filtration units which can be installed at the point of use or manifolded in groups as small systems. Filters can be installed to clean up all the water in an establishment, or just the water in certain areas. Kitchens, dining rooms, guest rooms, special facilities in hospitals, dishwashers, ice makers, laundries, the list includes every facility and every use where clean, clear, good tasting water is a must.

AMF Cuno Aqua-Pure Taste/Odor and Dirt/Rust filters are the low-cost, high-efficiency answer to removing dirt, algae, sediment, rust, silt, bad taste and odors from water — either from well or municipal supply. You get rid of deposits that clog pipes, filters, shower heads, toilets, dishwashers and other types of water-fed equipment. The Model SS-1 and SS-2 can be used singly or in systems for removing either dirt and rust or bad tastes and odors, depending on the filter cartridges used.

Good filtration saves money, and Aqua-Pure Filters offer the best protection available. With Aqua-Pure, there's no fuss or messy collapsed filters or loose carbon to contend with. Rugged, self-contained cartridges are changed in minutes. Disposal is quick and easy. Your water system is back in service immediately. And an Aqua-Pure Heavy Duty Filter System can provide high flow rates. For instance, with a multiple filter installation involving four SS-2 filters and an AMF Cuno Model M1-4 Manifold, you can get up to 24 GPM. Other arrangements can deliver even more.

National Sanitation Foundation Testing Laboratory Seal. Aqua-Pure® products with this seal are listed with official health departments throughout the United States.

Aqua-Pure® Commercial Duty Water Filters

There's an Aqua-Pure long-life filter cartridge to make water sweet, clean and clear under almost any set of conditions.

For Dirt/Rust Removal

A selection of Aqua-Pure Dirt/Rust Filters is available to remove dirt and rust you cannot see from water; particles as fine as a single grain of talcum powder. They trap sand, silt, dust, algae, worms and other particles, assuring clear, clean, safe, sparkling fresh filtered water. Results: clear, pure, drinking water, brighter laundry, clean and unclogged water appliances, stain-free sink and toilet bowl water. Aqua-Pure Dirt/Rust Filters are available in models for both cold and hot water service. Their use before water softeners removes dirt and rust and extends the life of the salts.

HOW AQUA-PURE LONG-LIFE FILTERS SCRUB DIRT/RUST OUT OF WATER.

Aqua-Pure Dirt/Rust filter cartridges are made by an exclusive, scientific process in which pure white cellulose fibers are locked permanently in the form of a porous, rigid cylinder with spaces between fibers gradually growing smaller toward the center hole. As water passes through the body of the cylinder, solid matter is removed, water then flows up through center hole and into faucets and appliances. The annular grooved cylinder provides 60% more surface area than ordinary filters. Section views show how water flows through cellulose filter and is scrubbed clean.

COLD WATER SERVICE

Rated for 100° F maximum water temperature. Aqua-Pure AP110 Standard Duty Cold Water Dirt/Rust Filter Cartridge has filtration capability of 5 microns and larger. For heavy dirt loads, use Aqua-Pure AP124 Heavy Duty Dirt/Rust Filter Cartridges with filtration capability of 50 microns and larger.

HOT WATER SERVICE

Rated for 210° F maximum water temperature. Aqua-Pure AP112 Standard Duty Hot Water Dirt/Rust Filter Cartridge has filtration capability of 5 microns and larger.

FILTER CARTRIDGE SPECIFICATIONS.

All AP110, AP124 and AP112 Dirt/Rust Filter Cartridges are 9¾" high x 2½" diameter x 1" center hole. Dirt/Rust Filter cartridges have a maximum flow rate of 6 GPM. Filter cartridges are packed two cartridges in a box, twelve boxes in a master carton. Shipping weight approximately 12 lbs. Also bulk packed 36 cartridges to a carton. Shipping weight 20 lbs.

SPECIFICATIONS — Aqua-Pure Models SS-1 and SS-2 Housings

Model SS-1.

This is a single filter cartridge housing with brushed stainless steel sump and nickel-plated cast brass head and threaded ring unit. Because of their rugged construction, they are recommended for commercial application or large residences. They are designed for high water pressure applications.

Model No.	Pipe Size	Dimensions Height Diameter		Flow GPM		Max. Pressure
				DIRT/ RUST	TASTE/ ODOR	
SS-1	3/8"	12"	4 3/8"	6	3	300 PSI
SS-2	3/8"	22"	4 3/8"	*6	6	300 PSI

*Flow rate is limited by a maximum velocity of 8 ft./Sec. as required by National Standard Plumbing Code for water piping systems. At a velocity of 10 ft./Sec. these valves can be increased by 25%. Filter life increases by the addition of cartridges: for example an SS-2 has twice the life of the SS-1.

Model SS-2.

This housing is identical to the SS-1 but contains two filter cartridges to provide higher flow rates and greater dirt storage capacity. Model SS-2 is equipped with a stainless steel centering guide that automatically aligns filter cartridges end-to-end for single unit removal and replacement.

PACKAGING AND SHIPPING

SS-1 Housings are individually boxed, includes mounting bracket and installation instructions. Packed four filters to a master carton. Shipping weight approximately 20 lbs. Housings are packed without filter cartridges.

SS-2 Housings are individually boxed, includes mounting bracket, centering guide and installation instructions. Packed one filter to a master carton. Shipping weight approximately 5 3/4 lbs. Housings are packed without filter cartridges.

For Taste/Odor Removal

The new long-life AP117 Taste/Odor Filter Cartridge eliminates the taste and odor of chlorine, sulphur, musty, stale and metallic tastes and odors from drinking and cooking water. This unique cartridge contains hundreds of thousands of activated charcoal granules that soak up taste-spoiling contaminants and delivers fresh-tasting, sparkling clear water. As a result, the flavor of everything prepared with water is delightfully improved.

HOW AQUA-PURE TASTE/ODOR FILTERS RESTORE SPRING-FRESH TASTE TO DRINKING AND COOKING WATER.

Water enters the new filter cartridge through holes near both ends where dirt and rust particles and other sediments are trapped. The clean water then passes through a deep bed of premium activated charcoal where tastes, odors, and color are removed, and then out the middle of the cartridge through a pure white post-filter disk before flowing up and out of the filter. Section view shows how water flows through the filter.

COLD WATER SERVICE ONLY.

Aqua-Pure AP117 Taste/Odor Filter Cartridge rated for 100°F maximum water temperature.

FILTER CARTRIDGE SPECIFICATIONS.

The AP117 Taste/Odor Filter Cartridge is 9 3/4" high x 3" diameter x 1" center hole. Taste/Odor filter cartridges have a maximum flow rate of 3 GPM of intermittent use. Filter cartridges are packed two cartridges in a box, twelve boxes in a master carton. Shipping weight approximately 30 lbs. Also bulk packed, 36 cartridges to a carton. Shipping weight 46 lbs.

AP117

INSTALLATION AND OPERATING INSTRUCTIONS AQUA-PURE® STAINLESS STEEL FILTERS

CAUTION NOTE:

Do **NOT** use Water Pressure exceeding 300 lbs. or temperature as indicated on Filter and Cartridge Labels.

Allow Minimum of 2" clear space under Filter to facilitate cartridge change.

PROCEDURE FOR INSTALLING DIRT/RUST FILTER

ON HOT OR COLD WATER LINE (DEPENDING ON FILTER CARTRIDGE USED)

Required Materials:

- Tube Cutter
- Teflon Tape
- 3/4" SW Gate Valve
- 3/4" x M ST Adapter Wrot
- 3/4" CXM Cast Union
(Valve at Main Water Meter or Hot Water Heater May Be Used As Second Valve)

Note: Filter can be adapted to various pipe sizes by using reducing adapters on either end. Installation fittings can be sweated or threaded. Use galvanized fittings for installation on galvanized pipe. Be sure to leave suitable space under Filter to allow cartridge

change. Filter can be installed on Hot or Cold Water line depending upon Filter cartridge used.

Installation Procedure: See diagrams for corresponding steps. First read "Caution Note" on page one.

BEFORE STARTING, SHUT OFF MAIN WATER SUPPLY AND DRAIN PIPES

Step 1: Snug fit all component parts and calculate length of tubing to be removed.

Step 2: Cut tubing.

Step 3: Install sweat side of CXM Cast Union onto tube.

Step 4: Sweat SW Gate Valve onto line backward so drain can later be used to release pressure when changing Filter cartridge.

Step 5: Cover threads of M ST Adapter with Teflon Tape and screw firmly into Filter head making tight connection.

Step 6: Sweat M ST Adaptor with filter head attached to Valve making sure that filter head is vertical. (It may be necessary to temporarily support weight of filter until Filter Bracket is permanently installed. See Step 9.)

Step 7: Screw CM part of Union into Filter. It may be necessary to slightly spring tubing temporarily out of alignment in order for tubing to enter Union.

Step 8: Connect two halves of Union and tighten, making sure Filter is in straight vertical position.

Step 9: Mount Filter Bracket to wall or suitable support.

PROCEDURE FOR INSTALLING TASTE/ODOR FILTER UNDER KITCHEN SINK ON COLD WATER LINE

Required Materials:

- Tube Cutter
- Teflon Tape
- (2) $\frac{3}{4}$ " CM Adapters (Cast or Wrot)
- $\frac{3}{4}$ " SW Gate Valve
- (4) $\frac{3}{4}$ " SW Ells
- 2 Ft. piece $\frac{3}{4}$ " Copper Tubing

Note: Filter can be adapted to various pipe sizes by using reducing adapters, on either end. Installation fittings can be sweated or threaded. Use galvanized fittings for installation on galvanized pipe.

Installation Procedure: Filter can be installed on Cold Water Line. If space under sink does not permit installation there, then Filter should be installed back on cold water line just as close to sink as possible. Gate Valve should be installed backwards so drain can later be used to release pressure when changing Filter cartridge.

BEFORE STARTING, SHUT OFF MAIN WATER SUPPLY AND DRAIN PIPES

Step 1: Cut out approximately 8" section of pipe starting 12" off the floor.

Step 2: Sweat SW Gate Valve onto water line.

Step 3: Sweat SW Ell onto piece of copper tubing and sweat tubing to Valve.

Step 4: Sweat SW Ell (Step 3) to one Adapter using piece of copper tubing.

Step 5: Cover threads of both adapters with Teflon tape and screw one adapter into "IN" side of Filter.

Step 6: Mount Filter bracket to wall or suitable support.

Step 7: Screw remaining adapter into "OUT" side of Filter and then sweat a piece of tubing to the adapter.

Step 8: Sweat Ell to tube connected to (Right) Adapter.

Step 9: Loose fit (A) Ell to water line coming down from sink. Measure (B) and cut tubing to go across Filter. Loose fit (C) Ell at end of tubing. Measure (D) and cut tubing to fit to Ell Sweated to (Right) adapter on Filter.

Step 10: Now proceed to sweat remaining fittings.

OPERATING INSTRUCTIONS:

Cartridge Replacement: Original cartridge may have shorter than normal life due to disturbing pipes on installation.

Replace cartridge when there is a decided drop in water flow at faucet or tap.

To Replace Cartridge:

1. Shut off inlet and outlet valves. Open drain on Gate Valve, installed backwards at Filter, to relieve pressure in Filter.
2. Insert wrench (see drawings below) into hole provided in ring nut and unscrew to remove nut.
3. Remove sump and empty water.
4. Lubricate gasket with Vaseline.
5. Place new Aqua-Pure cartridge* on seal plate in sump. Bring ring nut over sump and hand tighten to head.
6. Turn on inlet valve and bleed air through Gate Valve drain until water appears. Then close drain, and open outlet valve.
7. If Filter should leak, tighten ring nut with wrench until leak stops. Do not overtighten.

* Double cartridge filters have cartridges slipped over centering guide provided.

BY-PASS SECTION can be installed around unit if desired using either threaded or sweated fittings.

**AMF
Cuno**

400 Research Parkway
Meriden, Conn. 06450

AMF CUNO DIVISION • AMF INCORPORATED
400 Research Parkway, Meriden, Conn. 06450, U.S.A.

Part No. 69632-31
Effective Jan. 1, 1977

LIMITED ONE-YEAR WARRANTY

AMF CUNO DIVISION warrants to the original purchaser-consumer of its Product that it is free of defects in materials and workmanship. Any defect, malfunction, or other failure of the product to conform to this Warranty will be remedied by AMF Cuno in the manner provided below.

This Warranty, together with any and all warranties implied by law, shall be limited to a duration of one (1) year from the date of original purchase by the consumer.

This Warranty does not apply to defects that result from abuse, misuse, alteration or damage not caused by AMF Cuno.

IMPORTANT: To file a claim under this Warranty, you must complete and mail the Warranty registration card supplied with this Product to AMF Cuno at the address below within ten (10) days of original retail purchase.

THIS WARRANTY DOES NOT COVER, AND IS INTENDED TO EXCLUDE, ANY LIABILITY ON THE PART OF AMF CUNO, WHETHER UNDER THIS WARRANTY OR UNDER ANY WARRANTY IMPLIED BY LAW, FOR ANY INDIRECT OR CONSEQUENTIAL DAMAGES FOR BREACH HEREOF OR THEREOF.

Note: Some states prohibit limitations on the duration of implied warranties and on the exclusion of indirect or consequential damages; and so the above limitation on implied warranties and on incidental and consequential damages may not be applicable to you.

RESPONSIBILITY OF AMF CUNO

AMF Cuno's responsibility under this warranty shall be to repair at its expense, at no charge to the original purchaser-consumer, any Product that is actually defective, malfunctioning, or otherwise in violation of this Warranty.

If AMF Cuno for any reason cannot repair a Product covered hereby within two (2) weeks after receipt of the original purchaser-consumer's notification of a Warranty claim, then AMF Cuno's responsibility shall be, at its option, either to replace the defective Product with a comparable new unit at no charge to the consumer or to refund the full purchase price. AMF Cuno's obligations of repair, replacement, or refund are conditioned upon the consumer's return of the defective Product to AMF Cuno.

If any Product covered hereby is actually defective within the terms of this Warranty, then AMF Cuno will bear all the reasonable and proper shipping or mailing charges actually incurred in the consumer's return of the Product as set forth herein. If the Product proves not to be defective within the terms of this Warranty, then all costs and expenses in connection with processing of the consumer's claim hereunder shall be borne by the consumer.

RESPONSIBILITY OF THE CONSUMER

The original purchaser-consumer's sole responsibility in the instance of a warranty claim shall be to notify AMF Cuno of the defect, malfunction, or other manner in which the terms of this Warranty are violated. You may secure performance of obligations hereunder by (in writing):

1. Identifying the Product involved (by model or serial number or other sufficient description that will allow AMF Cuno to determine which product is defective).
2. Specifying where, when, and from whom the Product was purchased.
3. Describing the nature of the defect, malfunction, or other violation of this Warranty.
4. Sending such notification together with the defective Product to:

AMF Cuno Division
47 Main Street
Talcottville, Connecticut 06066

THIS WARRANTY GIVES YOU SPECIFIC LEGAL RIGHTS, AND YOU MAY ALSO HAVE OTHER RIGHTS, WHICH VARY FROM STATE TO STATE.

BRANCHEMCO
INC. Water Treatment Division

8286 Western Way Circle
Jacksonville, Florida 32216
(904) 737 0984

ENGINEERING AND PRODUCT DATA

CORROSION INHIBITORS FOR CLOSED WATER SYSTEMS

General

To provide a corrosion inhibitor for total corrosion protection in a hot or chilled water closed system, the selection depends on water quality, type of seals, and component metals in the system. The product recommended for your system is circled.

Branchemco 266: A liquid buffered chromate. Use at 150 ppm where mechanical seals are present.

Branchemco 241: A non-chromate liquid type inhibitor for closed hot and chilled water systems. This is primarily a blend of sodium nitrite, sodium borate, 2-MBT, and solublizing materials. Use at 6 pints per 100 gallons, or/and 8 gallons per M gallons.

Chemical Balances:

800 - 1000 ppm: NO₂
80 - 100 ppm: 2-MBT

Branchemco 243: Powdered phosphate based corrosion inhibitor for closed systems. Control at 4000/6000 ppm T-PO₄. Prefer to use soft water for make-up, but if not available then system will require periodic manual blow-down for removal of sludge. This product is manufactured from only food codex grade materials, and should be used in all closed water systems where there is potential for a leak into food.

This treatment is compatible with glycol systems. In all food related systems propylene glycol is used.

The ingredient in No. 243 is approved for use in food plant cooling systems by FDA.

Start at 5 pounds per 100 gallons water capacity.

A powder version of 241 is available as Branchemco 240. This material should be dissolved in water or glycol mixture before application to the system.

Revised 3/17/78.

Laboratory Procedure

NITRITE (NO₂)

Control Range: 800 - 1000

1. Measure a 50ml sample with a clean 50ml graduated cylinder.
2. Pour into a clean casserole.
3. Add one drop Nitrite indicator, swirl to mix.
4. Add Cerric Sulfate from the buret until the color changes from orangish red to light blue or clear, and remains light blue or clear for 15 seconds.
5. Read the buret.
6. The nitrite (NO₂) in the sample in ppm (mg/L) is equal to the buret reading times 50.

EXAMPLE:

For a 50ml sample: The buret reading is 10.6ml then the nitrite (NO₂) is:
 $10.6\text{ml} \times 50 = 530 \text{ ppm}$

ACTION:

- A. If Nitrite value is less than 800 ppm (mg/L) then add Branchemco No. _____ to the systems.
- B. If Nitrite value is greater than 1000 ppm (mg/L) then do not add any Branchemco No. _____ to the system.

REAGENTS & APPARATUS:

10037	Nitrite Reagent
10036	Cerric Sulfate Titrating Solution
P-130	Graduated Cylinder, 50ml
10131	Casserole
P-516	Stirring Rod
10075	Buret Automatic 25ml

OPTIONS:

10086	Stirring Plate
P-517-0006	Stirring Bar

BRANCHEMCO, INC.
8286 Western Way Circle D-9
Jacksonville, Florida 32216

WATTS

*The name
that protects
your name*

103 Years Of Leadership 1874 - 1977

Series 700

**DOUBLE CHECK
VALVE ASSEMBLY**

SIZES $\frac{3}{4}$ ", 1", 1 $\frac{1}{2}$ ", 2"

Approved by: I.A.P.M.O.

CROSS CONNECTION CONTROL

- **INSTALLATION**
- **FIELD TESTING**
- **MAINTENANCE**

WATTS REGULATOR COMPANY
TORONTO, CANADA

● LAWRENCE, MASS., U.S.A.
GLOUCESTERSHIRE, ENGLAND

Manufacturers of the largest and most complete line of plumbing and heating safety valves and controls.

Basic Installation Instructions

A. WATTS Series 700 Double Check Valve may be installed in either a vertical or horizontal position. If installed vertically, the direction of flow must be vertically "down".

B. They should always be installed in an accessible location to facilitate testing and servicing.

C. Pipe lines should be thoroughly flushed to remove foreign material before installing the unit. A strainer should be installed as shown, ahead of backflow preventers to protect discs from unnecessary fouling.

CAUTION: Do not install with strainer when backflow preventer is used on seldom-used water lines which are called upon only during emergencies, such as fire sprinkler lines, etc.

D. It is important that Series 700 be tested periodically in compliance with local codes, but at least once a year or more often depending upon system conditions.

E. For indoor installations, it is important that the device be easily accessible to facilitate testing and servicing. Fig. 1.

F. In an area where freezing conditions do not occur, Series 700 can be installed outside of a building. The most satisfactory installation is above ground and should be installed in this manner whenever possible. Fig. 2.

It is generally recommended that backflow preventers never be placed in pits unless absolutely necessary and then only when approved by local codes. In such cases, a modified pit installation is preferred.

G. An optional installation of Series 700 is the use of two or more smaller size devices piped in parallel to serve a larger supply pipe main. This type of installation is employed whenever it is vital to maintain a continuous supply of water and where interruptions for testing and servicing would be unacceptable. It also has the advantage of providing increased capacity where needed beyond that provided by a single valve and permits testing or servicing of an individual valve without shutting down the complete line.

For a two-valve installation as shown, the total capacity of the devices should equal or exceed that required by the system. See table 1.

TABLE 1

Table shows number of smaller size devices of same size required to meet capacity of a single large valve.

CAPACITY REQUIRED FOR SYSTEM

50 G.P.M.	100 G.P.M.	150 G.P.M.	200 G.P.M.	250 G.P.M.	300 G.P.M.
Two ¾" Devices	Two 1" Devices	Two 1½" Devices	Two 1½" Devices	Two 1½" Devices	Two 1½" Devices

Figure 2

Figure 3

Field Testing Procedure

Series 700 DOUBLE CHECK VALVE ASSEMBLY

NOTE: Leaky shut-off valves will give erroneous test results and should be verified before testing the check valves.

A. Test of Check Valve No. 1

PURPOSE:

To test check valve No. 1 for tightness against reverse flow.

REQUIREMENT:

Valve must be tight against reverse flow under all pressure differentials.

STEPS:

1. Install sight tube in Test Cock 3. Open Test Cock 3 and allow water to fill the tube to the top. Use a tube length of at least 42 inches. This will provide a head of 1½ PSI. Close Test Cock 3.
2. Close Shut-off Valve No. 2.
3. Close Shut-off Valve No. 1.
4. Open Test Cock 3.
5. Open Test Cock 2. The water should maintain its position in the sight tube. If it slowly drops and runs out through Test Cock 2, the check valve No. 1 is leaking and must be serviced.

B. Test of Check Valve No. 2

PURPOSE:

To test check valve No. 2 for tightness against reverse flow.

REQUIREMENT:

Valve must be tight against reverse flow under all pressure differentials.

STEPS:

1. Install sight tube in Test Cock 4 and fill with water as before.
2. Open Test Cock 4.
3. Open Test Cock 3. The water should maintain its position in the sight tube. If it slowly drops and runs out through Test Cock 3, check valve No. 2 is leaking and must be serviced.

Service, Replacement Parts and Maintenance

DISASSEMBLY OF No. 700:

1. Remove the No. 700 head from the line (union nuts and adapters remain in the line).
2. Remove inlet adapter bolts.
3. Remove the adapter and "O" ring. Lift out the first check module and "O" ring.
4. Disc can be exposed for cleaning by maintaining pressure on disc holder stem to overcome spring preload.
5. To remove the outlet adapter and second check assembly, repeat steps 2 and 3.
6. The check module can be disassembled by removing lock nut while maintaining pressure on the disc holder stem. Disc can now be cleaned, or replaced.

NOTE: First check module and second check module are identical and can be interchanged. Inlet and outlet adapters and "O" rings are also identical and can be interchanged.

REASSEMBLY OF No. 700:

7. Place the check valve washer and spring over the stem, and place the seat casting over the stem. Push down to compress the spring until stem projects beyond the seat ring.
8. With stem projecting out, place the disc washer on the stem. Place the disc holder with the rubber disc on the stem. Thread on the lock nut, tighten the lock nut securely while holding the head of the stem.
9. Repeat steps 7 - 8 for assembling the other check module. To assemble the inlet side of the valve, place the "O" ring in the body, take either check module and align the tabs of the check module with the slots in the body. (**Note:** Tabs on check module prevent misassembly of the check module with relation to the direction of flow). The spring end of the module will be out of the body on the inlet end.
10. In assembling the outlet side of the valve, repeat above procedure. However the spring end of the module will be in the body.
11. Place "O" ring on check module. Place the adapter on the check valve module, insert bolts and tighten.

WATTS

*The name
that protects
your name*

WATTS REGULATOR COMPANY
TORONTO, CANADA

LAWRENCE, MASS., U.S.A.
GLOUCESTERSHIRE, ENGLAND

Manufacturers of the largest and most complete line of plumbing and heating safety valves and controls.

LIMITED WARRANTY: Watts Regulator Company warrants each product against defects in material and workmanship for a period of one year from the date of original shipment. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge. This shall constitute the exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental or consequential damages, including, without limitation, damages from other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water/air conditions, chemicals, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication or improper installation of the product. THE COMPANY MAKES NO OTHER WARRANTIES EXPRESS OR IMPLIED EXCEPT AS PROVIDED IN THIS LIMITED WARRANTY.

INSTRUCTIONS

PUSH BUTTON
& SELECTOR SWITCH KITS

File No	50-HD54688
Cat. No. or Class Series	14 & 40 OPEN & NEMA 1
Size	00-0.1-1P-1 $\frac{3}{4}$
Date	DECEMBER 1972

WIRING DIAGRAM

Fig. 2

Fig. 3

SELECTOR SWITCH

PUSH BUTTON

Fig. 1

CAUTION — Be sure power is disconnected before removing the enclosure cover.

- Mount pilot controls on starter as shown in Fig. 1, using the two captive self-tapping screws.
- Use red wire in kit and make connections as shown in wiring diagram.

PUSH BUTTON KIT 50D54688 START-STOP (Fig. 2).

- Connect push button terminal 1 to starter terminal 1 with long jumper.
- Connect push button terminal 2 to starter terminal 2 with short jumper.
- Connect push button terminal 3 to starter terminal 3 with long jumper.

SELECTOR SWITCH KIT 50D25168 2 position.

- Connect selector switch to starter terminal 1 and 3 as required for application.

SELECTOR SWITCH KIT 50D54773 3 position. (Fig. 3).

- Connect selector switch terminal H to starter terminal 1.
- Connect selector switch terminal C to starter terminal 3.
- Connect one terminal of the pilot control switch (pressure switch, thermostat, etc.) to terminal 1.
- Connect the other side of the pilot control switch to selector switch terminal A.

NOTE: When using a NEMA 1 enclosure, remove the knock-out in the cover.

REPLACEMENT PARTS**MAGNETIC CONTROLS**File No. **14-GCF**

Cat. No. or Class Series

**14BF, 14CF, 14DF, 14EF
40BF, 40CF, 40DF, 40EF**Size **00, 0, 1, 1P, & 1¾****SEPTEMBER 1975**

ITEM	PART NAME	PART NUMBER			
		14BF Size 00	14CF Size 0	14DF Size 1	14EF Size 1P & 1¾
A	Contacts & Spring, One complete pole — Power Pole Interlock Pole	75BF14 75AF14	75CF14 75AF14	75DF14 75AF14	75EF14 75AF14
B	Cross Arm (less contacts)	D54670-001	D54670-001	D54670-001	D54670-001
C	Cross Arm Base	D54073-001	D54873-001	D54873-001	D54873-001
D	Cross Arm Springs	D24826-001	D24826-001	D24826-001	D24826-001
E	Cross Arm Screw	D25013-001	D25013-001	D25013-001	D25013-001
F	Contact Board Cover	D73062-001	D73062-001	D73062-001	D73062-001
G	Contact Board (less contacts)	D73116-022	D73116-021	D73116-021	D73116-021
H	Armature Spring Clip	D24817-001	D24817-001	D24317-001	D24817-001
J	Magnet and Armature	D25551-001	D25551-001	D25551-001	D25551-001
K	Contact Board Screw	D24827-001	D24827-001	D24827-001	D24827-001
L	Base	D73060-001	D73060-001	D73060-001	D73060-001
M	Coil 60 Hz. 110-120/208-240 Volts 50 Hz. 110 Volts 208 240/440-480 Volts 220 Volts 550-600 Volts 550 Volts	75D73070A 75D73070C 75D73070E	75D73070A 75D73070C 75D73070E	75D73070A 75D73070C 75D73070E	75D73070A 75D73070C 75D73070E
N	Coil Spring Clip				
P	Overload Relays	Melting alloy (std.) Standard Bimetal Amb. Compensated Bimetal	1 Pole 3 Pole 1 Pole 3 Pole 1 Pole 3 Pole	48DC11A2	48EC11A2
				48DC31A2	48EC31A2
				48DC17AA2	48EC17AA2
				48DC37A2	48EC37A2
				48DC18AA2	48EC18AA2
				48DC38A2	48EC38A2

NOTE: When ordering replacement parts, give catalog number of control and part name and number.

OPERATING INSTRUCTIONS & PARTS LIST

AC MAGNETIC MOTOR STARTERS SIZES 00-2 MODELS 5X150-5X151-5X152-5X153A 5X154A-5X155A-5X156A-5X245A

FORM
551627

DAYTON ELECTRIC MANUFACTURING CO. CHICAGO 60648

SEPT., 1975

**REPLACEMENT
CONTACT KIT**

MAGNET COIL

RENEWAL PARTS AND ACCESSORY KITS

MAGNET COIL - 60 Hz	NEMA SIZE 00 5X153A	NEMA SIZE 0 5X150 5X154A	NEMA SIZE 1 5X151 5X155A	NEMA SIZE 1½ 5X152	NEMA SIZE 1¾ 5X245A	NEMA SIZE 2 5X156A
115/208 - 230 VOLTS			5X171			—
208 - 230/440 - 460 VOLTS			5X172			5X173
24 VOLTS			5X175			5X176
120 VOLTS			5X178			5X179
600 VOLTS			6X224			6X225
CONTACT KIT (3 POLE SET)	5X161	5X162	5X163			5X164
OVERLOAD RELAY (HAND-AUTOMATIC RESET TYPE)	5X167			5X168	5X167	5X169

NOTE: FOR OTHER ACCESSORY KITS, SUCH AS COVER MOUNTED PUSHBUTTONS, SELECTOR SWITCHES OR REMOTE START-STOP STATIONS, CONTACT YOUR DAYTON DEALER.

MAINTENANCE INSTRUCTIONS

Before connecting to power supply, manually operate movable contact carrier assembly (by pushing on the contact carrier end posts) to assure free movement.

MAIN CONTACTS

Disconnect all power before removing cover and working on starter.

Inspection: Push cover clips outward and remove contact cover. All portions of all contacts are now visible.

Replacement: Remove cover. Slide out movable contacts. Loosen stationary contact screws and lift out contacts. Replace in reverse order.

ALL STATIONARY CONTACT SCREWS MUST BE TIGHTENED, COVER AND COVER CLIPS MUST BE IN PLACE BEFORE MAGNET COIL IS ENERGIZED. COIL FAILURE MAY OCCUR IF STARTER IS ENERGIZED WITH CONTACT COVER REMOVED.

MAGNET COIL REPLACEMENT

Remove cover. Loosen six (6) stationary contact screws. Pull out carrier assembly (all contacts and screws will remain captive in assembly). Disconnect coil jumper wires from terminals and pull out coil. To replace with dual voltage coil, feed jumper wires through hole in base assembly and plug in coil, connect long jumper wire to terminal "Y" and short jumper wire to terminal "Z" for low voltage control, or connect both jumper wires to terminal "K" for high voltage control (see pictures on front of this sheet). To replace with single voltage coil, simply plug coil in, no jumper wires are necessary.

OVERLOAD RELAY

Removal: Remove single screw attaching overload relay to the power circuit and merely unplug the relay. To replace the relay, reverse the procedure.

The overload relay is supplied with control terminals which are plugged into a pre-wired base. No control wire connections are required.

The overload relays are normally shipped without heaters. Remove heater screws, insert heaters in pockets and re-tighten heater screws. If a center heater is being added to an existing installation, original heaters may require replacement - refer to heater chart.

Reset positions: The normal position of the reset slide is "hand reset". Overload relays can be converted to "automatic reset" in the following manner. Lift the reset selector and place it in the "auto" slot.

Trip current adjustment: The normal position of the adjustment knob is 100%. The trip current can be lowered by turning the adjustment toward the 85% setting and raised by turning the adjustment knob toward the 115% setting.

GENERAL MAINTENANCE

Dayton starters are thoroughly tested and carefully inspected prior to shipment from the factory. The dual voltage coils are factory connected for operation on 208 - 230 volts. Changing this coil connection, if necessary, is the only adjustment that might be required before placing the starter in service. Under normal operating conditions the only maintenance precaution recommended is to keep parts free from excessive amounts of dirt, oil or grease, paying particular attention to contacts and magnet faces for safe, quiet operation. Terminals should be checked for tight connection. When contacts become worn or pitted more than half-way through, they should be replaced. Silver cadmium oxide contacts should not be filed. A silver contact, even though badly oxidized, will still be a good conductor.

NON-JOB — ORDER INFORMATION SHEET

ARCH.						JOB NO. <u>H3</u> <small>-NO JOB</small>					
GR.											
B NAME Solar Energy Center											
JOB LOCATION FTU			SHADED AREAS — FACTORY USE ONLY								
JOB COORDINATOR—SALES OFFICE—SALESMAN NAME, CODE			DATE SHIPPED		BILL OF LADING NO.		INVOICE DATE		ORDER/INVOICE NO.		
CUSTOMER P.O. NUMBER 7813-002			CUSTOMER ACCOUNT NO. H3-15-6710-6		TERMS-NET 30 Net		KH3-E122				
BILLING METHOD ☒ LUMP SUM ☐ NET EACH ☐ LIST DISC			INVOICE TYPE ☒ REG. ☐ PROGRESS		INVOICE DAY		SHIP WITH Lexington, F/A		ORDER DATE 11/30/78		
JOB/ORDER CLASS A4GLE			PROPOSAL NO.		PROPOSAL ISSUE DATE		INVOICE COPIES 2		SHIP VIA Truck		
SOLD TO S. I. Goldman Company P. O. Box 1156 Maitland, FL 32751							SHIP TO S. I. Goldman 132 Candace Drive Maitland, FL 32751		PREPAID ☒ COLLECT ☐		
SPECIAL INSTRUCTIONS			MARK PACKAGES Solar Energy Center								

MARK B/L: — CALL NO.: 305 830 5000 ATTN: Dave Altman 24 HRS. BEFORE DELIVERY

ITEM	QTY	DESCRIPTION	PRODUCT CODE
A	1	Cooling Coil	

SHOP DRAWING REVIEW

If checked below, fabrication MAY be undertaken. Approval does not authorize changes to Contract Sum unless stated in separate letter or Change Order.

☒ Approved/No Exceptions Taken
☐ Approved As Noted/Confirm

If checked below, fabrication MAY NOT be undertaken. Submit new or corrected drawings for review and approval. Correction shall be limited to items marked.

☐ Devise & Resubmit/Note Markings
☐ Rejected/Comments Attached

Reviewing is only for general conformance with the design concept of the Project and compliance with the information given in the Contract Documents. Markings or comments shall not be construed as approval of the Contractor from compliance with the project drawings or as a release of the Contractor from compliance with the project drawings or as a release of the Contractor from compliance with the project drawings or as a release of the Contractor from compliance with the project drawings.

STOTTLESTAGG ASSOCIATES, ARCHITECTS, ENGINEERS, PLUMBERS, ETC.

[Signature] **12/22/78**

ARCHITECT:		<p>SHOP DRAWING REVIEW</p> <p>APPROVAL STAMP</p> <p>If checked below, fabrication MAY be undertaken. Approver does not authorize changes to Contract Shop Drawings. Submit new or revised drawings for review and approval. Approval shall be limited to the scope of the project.</p> <p>☒ Approved/No Exceptions Taken ☐ Not Approved/Exceptions Taken</p> <p>Submit/Note Markings</p> <p>Comments Attached</p>										<p>STANDARD COILS</p> <p>Cooling</p> <p>Serpentine Water Coils</p> <p>1 - Std., Single Row Serp.</p> <p>2 - Drainable, Single Row Serp.</p> <p>3 - Drainable, Double Row Serp.</p> <p>4 - Cleanable, Single Row Serp.</p> <p>5 - 2-2 Tube Serpentine</p> <p>6 - 4-4 Tube Serpentine</p> <p>7 - 8-8 Tube Serpentine</p>							
ENGINEER:		<p>ORDER DATE: _____ CUSTOMER ORDER NUMBER: _____ CUSTOMER ACCOUNT NO.: _____</p> <p>SOLD TO: _____</p> <p>Include ZIP Code</p>										<p>REFRIGERANT COILS</p> <p>1 - 2-(R-22) - Direct Expansion</p> <p>2 - 1-(R-12) - Direct Expansion</p>							
PROJECT:												<p>HEATING</p> <p>STEAM COILS</p> <p>1 - Single Pass, Opp. End Conn.</p> <p>2 - Non Freeze, Opp. End Conn.</p> <p>3 - Non Freeze, Same End Conn.</p> <p>4 - T & ST - Single Tube Serp., Same End Conn. 1 and 2 row.</p>							
ORDER DATE:		CUSTOMER ORDER NUMBER:		CUSTOMER ACCOUNT NO.:		<p>☒ COOLING COILS ☐ HEATING COILS ☐ PROCESS COILS</p>													
SOLD TO:		QUANTITY:		ORDERING NO. Submittal Dwg.		TAGGING INSTRUCTIONS		COIL TYPE (1)		FINNED FACE		TUBES		AIR FLOW		TUBES		CHANNEL HOLES	
ITEM		A 1						W		33 60 18		A 4 A		HR		T		YES ☒ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	
																		YES ☐ NO ☐	

DIFFERENTIAL GAUGES

4½" 1685

These gauges are used extensively in industrial, transportation and marine applications where a direct indication of the pressure differential between two pressures is desired.

Such differential indications are exemplified by: inlet and outlet pressure in a filter system; pressure at different points in a brake system; oil pressure at the intake and discharge ports of a pump; boiler and back pressure on marine or locomotive boilers.

SPECIFICATIONS

DIAL SIZE: 4½"

CASE: Phenolic, black

RING: Brass, snap, black finish

WINDOW: Acrylic

POINTER: Micrometer adjustable, with positive lock and white finish

DIAL: Steel, black background with white markings

MOVEMENT: Made of dissimilar materials to reduce friction and wear. Overpressure stops

BOURDON TUBES: Phosphor bronze. 7½-0-7½ psi or 0-15 psi; 15-0-15 or 0-30 psi; 30-0-30 or 0-60 psi; soft soldered. Higher pressure ranges utilize silver brazing. Bourdons linked in opposition to each other through movement mechanism to provide differential reading between two variables

CONNECTION: ¼" ANPT, brass, side by side

ACCURACY: ±2% of span

REPRESENTED BY:
CONTROL CENTER, INC.
1013 E. Montana Street
Orlando, Florida 32803
Phone: (305) 896-6831

FIGURE 1685

FIGURE 1685

DIAL SIZE	A	B	C	F	G	H	J	R	W	X	Y	Z
4½"	5.06	2.58	1.00	.56	5.81	.219	5.375	2.62	.78	1.25	.63	.25

MAXIMUM DIAL INDICATION		DIAL GRADUATIONS		Max. Press. Limits* PSI
Split Scale PSI	Straight Scale PSI	Fig. Intervals PSI	Minor Intervals PSI	
7½-0-7½	0-15	1	¼	30
15-0-15	0-30	5	½	60
30-0-30	0-60	5	1	120
50-0-50	0-100	10	1	175
100-0-100	0-200	20	2	225
200-0-200	0-400	40	5	400

*This is maximum pressure that can be applied to either bourdon tube regardless of pressure in other bourdon tube.

MODEL 820 FLOW TEST KIT

**2 1/2 DIAL GAUGE
0-2 TO 0-100 PSID RANGE,
600 PSI S.W.P.**

**COMPACT, LOW COST
DIFFERENTIAL PRESSURE
FLOW TEST KIT**

The Model 820 is a compact, low cost flow test kit for monitoring and setting flow rates thru orifices, venturis, adjustable restrictions, pitot tubes or other flow devices--or anywhere differential pressure measurements may be required in the field. The pressure gauge is a Mid-West Model 120, with a 2-1/2 inch dial. Pressure Ranges are available from 0-2 to 0-100 psid [0-0.14 to 0-7.0 Kg/cm²].

The gauge is installed in a compact, rugged carrying case of tough plastic material and is supplied complete with five foot long flexible hoses for connecting to the flow device. The Model 120 gauge is a free floating piston gauge and has a very small but continuous purge flow across the piston, and separate bleed-drain valves normal for flow test kits are not required.

Mid-West
Instrument *(The Innovators)*

P.O. Drawer 939 • Troy, Michigan 48099 • Ph. (313) 585-0900
286 Executive Dr. • Troy, Michigan 48084 • Telex No. 23-5798

MODEL 820 FLOW TEST KIT

SPECIFICATIONS:

- Pressure Range - See Table
- Working Pressure - 500 psi maximum
- Working Temperature - 200 F maximum
- Hose Connections - Very Flexible, Buna N Liner, Neoprene Jacket, with Knurled Swivel End (Quick Connect) Fittings for 1/4 Male Flare Tube Connections--5 foot length.
- Fluid Media - Gases or Liquids Compatible with: Nylon; Buna N Rubber; Brass; Aluminum; Stainless Steel.

STANDARD DIAL RANGE

RANGE	ACCURACY
0 - 2 PSID	± 0.1
0 - 5 PSID	± 0.2
0 - 10 PSID	± 0.3
0 - 15 PSID	± 0.4
0 - 20 PSID	± 0.5
0 - 25 PSID	± 0.7
0 - 30 PSID	± 1.0
0 - 50 PSID	± 1.5
0 - 75 PSID	± 2.0
0 - 100 PSID	± 2.5
0 - 60 H ₂ O	± 3.0
0 - 135 H ₂ O	± 6.0

Square Root and Metric Scales available

Note - Most Ranges available in dual scale (English & Metric Equivalent) at no additional charge.

REPRESENTED BY

Mid-West
Instrument (The Innovators)

P.O. Drawer 939 • Troy, Michigan 48099 • Ph. (313) 585-0900
286 Executive Dr. • Troy, Michigan 48084 • Telex No. 23-5798

DRAWINGS

SOLAR HEATING & COOLING DEMONSTRATION PROJECT

FLORIDA SOLAR ENERGY CENTER FLORIDA TECHNOLOGICAL UNIVERSITY

CAPE CANAVERAL, FLORIDA PROJECT NO. BR-421

BEING CONSTRUCTED BY :
DEPARTMENT OF GENERAL SERVICES
THOMAS R. BROWN - EXECUTIVE DIRECTOR.

LOCATION MAP
SCALE: 1" = 400'

SHEET INDEX		
sht.no.	title	drwg.no.
1 of 6	TITLE SHEET, INDEX & LOCATION MAP	SI-1
2 of 6	SITE PLAN, LEGEND & DETAILS	SI-2
3 of 6	PIPING & EQUIPMENT PLAN	M-1
4 of 6	SOLAR COLLECTOR FIELD PLAN & DETAILS	M-2
5 of 6	FLOW SCHEMATIC, & CONTROL PANEL	M-3
6 of 6	ELECTRICAL	E-1

stottler stagg & associates
architects engineers planners, inc.
brevard engineering company

REVISIONS

ISSUE DATE
7/24/79
PRINT DATE
7/24/79
APPROVED BY
J. HICKER
APPROVAL DATE
7/24/79

SCALE
AS SHOWN
DRAWN BY
K. Stagg
CHECKED BY
J. HICKER
DATE
7/24/79

TITLE SHEET, INDEX & LOCATION MAP

SOLAR HEATING & COOLING DEMONSTRATION PROJECT
FLORIDA SOLAR ENERGY CENTER
FLORIDA TECHNOLOGICAL UNIVERSITY
CAPE CANAVERAL, FLORIDA - PROJECT NO BR-421

DWG. NO. **SI-1**
SHT. 1 OF 6
JOB NO. 77/37-1
FILE NO.

HOT WATER RISER ②

DOMESTIC WATER RISER ①

LEGEND

DOMESTIC COLD WATER	CHS
CHILLED WATER SUPPLY	CHR
CHILLED WATER RETURN	CWS
CONDENSER WATER SUPPLY	CWR
CONDENSER WATER RETURN	SHWS
SOLAR HOT WATER SUPPLY	SHWR
SOLAR HOT WATER RETURN	HWS
HOT WATER SUPPLY	HWR
HOT WATER RETURN	
GATE VALVE	
CHECK VALVE	
BALANCING VALVE	B.V.
UNION	
ELBOW (UP, DOWN, PLAN)	
TEE (UP, DOWN, PLAN)	
AUTOMATIC AIR VENT	A.A.V.
RELIEF VALVE	
THERMOMETER	T-1
THERMOMETER WELL	
CONTROL VALVE (1 WAY)	
CONTROL VALVE (3 WAY)	
MANUAL AIR VENT	MAV
TANK GAUGE GLASS ASSEMBLY	
PRESSURE REDUCING VALVE	
FLOW SWITCH	
RISER NUMBER	①

SITE PLAN

stottler stagg & associates
architects engineers planners, inc.
brevard engineering company

REVISIONS		ISSUE DATE 7/24/78	SCALE 1"=30'-0"	SITE PLAN, LEGEND & DETAILS	DWG. NO. SI-2 SHT. 2 OF 6
▲	MOVED COLLECTOR FIELD 8/15/78	PRINT DATE 7/24/78	DRAWN BY <i>K. Shae</i>	SOLAR HEATING & COOLING DEMONSTRATION PROJECT FLORIDA SOLAR ENERGY CENTER FLORIDA TECHNOLOGICAL UNIVERSITY CAPE CANAVERAL, FLORIDA - PROJECT NO. BR-421	JOB NO. 77/57-1 FILE NO.
▲	MOVED COOLING TOWER 8/15/78	APPROVED BY J. HACKER	CHECKED BY <i>J. HACKER</i>		
		APPROVAL DATE 7/24/78	DATE 7/24/78

PIPING & EQUIPMENT PLAN
SCALE: 1/4" = 1'-0"

COOLING COIL PIPING DETAIL
SCALE: NONE

PIPE SUPPORT
SCALE: NONE

NOTE: PROVIDE 24 GA. GALV. SHEET METAL COVER TO PROTECT PUMP P-1 FROM WEATHER.

- NOTES:**
1. EXTEND ALL TAPPINGS & BOSSSES 3/4" MIN. PAST TANK SURFACE SEE INSULATION DETAILS
 2. TANKS TO BE CONSTRUCTED & TESTED FOR MAX. WORKING PRESSURE OF 75 PSIG.
 3. SEE SPECIFICATION FOR INSULATION

SOLAR & CHILLED WATER TANK DETAIL
SCALE: NONE

	L	S	DIA.
3000 GAL.	8'-0"	24"	8'-0"
6000 GAL.	16'-0"	32"	8'-0"

LOW WATER CUT-OFF DETAIL
SCALE: NONE

HOT WATER TANK
SCALE: 1/4" = 1'-0"

CHILLED WATER TANK
SCALE: 1/4" = 1'-0"

TYPICAL PUMP MOUNTING DETAIL
SCALE: NONE

SOLAR COLLECTOR FIELD - PLAN
SCALE: 3/16" = 1'-0"

- NOTES**
1. USE CRUISE HINDS PVC FSC1 J-BOX W/BLANK COVER. PROVIDE COMPRESSION TYPE CORD CONNECTOR FOR SENSOR LEAD.
 2. USE FSCC2 J-BOX W/CORD CONNECTOR.
 3. PULL IN #14 GREEN GND CONDUCTOR W/CONTROL WIRES.

SOLAR COLLECTOR SUPPORT DETAIL
SCALE: 1-1/2" = 1'-0"

TYPICAL SOLAR COLLECTOR PIPING DETAIL
NO SCALE

stottler stagg & associates
architects engineers planners, inc.
brevard engineering company

REVISIONS			ISSUE DATE	SCALE	SOLAR COLLECTOR FIELD - PLAN & DETAILS		DWG. NO. M-2
1. CHANGE LOCATION OF PIPE	8/16/78		7/24/78	AS SHOWN	SOLAR HEATING & COOLING DEMONSTRATION PROJECT		SHT. 4 OF 6
2. CHANGE PIPE SIZE & ROUTING	8/16/78		7/24/78		FLORIDA SOLAR ENERGY CENTER		JOB NO. 77137-1
3. CHANGE SUPPORT DETAIL	8/16/78				FLORIDA TECHNOLOGICAL UNIVERSITY		FILE NO.
			APPROVAL DATE	DATE	CAPE CANAVERAL, FLORIDA - PROJECT NO. BR-421		
			7/24/78	7/24/78			

PUMP SCHEDULE									
MARK	SERVICE	MANUFACT.	MODEL & SIZE	FLOW (G.P.M.)	T.D.H. (FT. H ₂ O)	MOTOR			
						RPM	H.P.	VOLT	PHASE
P-1	SOLAR H.W.	BELL & GOSSETT	1510-1 1/4" A.B.	30	65	1750	2	480	3
P-2	H.W. HEATING	"	1510-1 1/4" A.B.	90	45	1750	2	480	3
P-3	PRIMARY CHILLED WTR	"	1510-1 1/4" A.B.	60	25	1750	1	480	3
P-4	CHILLED WATER	"	1510-1 1/4" A.B.	30	34	1750	1	480	3
P-5	CONDENSING WATER	"	1510-1 1/4" A.B.	70	65	1750	3	480	3
P-6	HEAT REJECTION PUMP	"	1 1/2" ALL BRONZE BOOSTER	20	8	1750	1/6	115	1

WATER TREATMENT INJECTION FITTING

NOTE: THE HOT & COLD WATER STORAGE TANKS SHALL BE PRESSURIZED WITH COMPRESSED AIR TO A PRESSURE OF 20 P.S.I.G. PRIOR TO FILLING.

FLOW SCHEMATIC

CONTROL PANEL

stottler stagg & associates
architects engineers planners, inc.
brevard engineering company

REVISIONS

ISSUE DATE
7/24/75
PRINT DATE
7/24/75
APPROVED BY
J. HACKER
APPROVAL DATE
7/24/75

SCALE
NONE
DRAWN BY
JAVIER MATOS
CHECKED BY
J. HACKER
DATE
7/24/75

FLOW SCHEMATIC, CONTROL PANEL & SEQUENCE OF OPERATION
SOLAR HEATING & COOLING DEMONSTRATION PROJECT
FLORIDA SOLAR ENERGY CENTER
FLORIDA TECHNOLOGICAL UNIVERSITY
CAPE CANAVERAL, FLORIDA - PROJECT NO. BR-421

DWG. NO. **M-3**
SHT. 5 OF 6
JOB NO. 77137-1
FILE NO.

LEFT SIDE ELEVATION
1/8" = 1'-0"

FRONT ELEVATION
1/8" = 1'-0"

RIGHT SIDE ELEVATION
1/8" = 1'-0"

FOUNDATION PLAN
1/8" = 1'-0"

FRAMING PLAN
1/8" = 1'-0"

FLOOR PLAN
1/4" = 1'-0"

JAMB AT OVERHEAD DOOR
1 1/2" = 1'-0"

JAMB AT ENTRANCE
1 1/2" = 1'-0"

(A) FOOTING AT MASONRY COLUMN
1" = 1'-0"

(C) FOOTING AT CMU WALL
1" = 1'-0"

(D) ROOF SECTION AT CENTER COLUMN
1 1/2" = 1'-0"

(E) SECTION AT ROOF OVERHANG
1 1/2" = 1'-0"

CROSS SECTION
1/2" = 1'-0"

(F) FLASHING DETAIL
3" = 1'-0"

- NOTES**
- 1- PRESSURE TREATED WOOD USED WHERE CONCRETE OR MASONRY IS CONTACTED.
 2. FOOTINGS & SLAB TERMITE TREATED.
 3. SOIL UNDER FOOTING & SLAB COMPACTED AS REQ'D TO PROVIDE 2000 P.S.F. BEARING CAPACITY.

AS BUILT

STOTTLER STAGG & ASSOCIATES
BREVARD ENGINEERING COMPANY
PROJECT NO. BR-421

ARCHITECTURAL PLANS & DETAILS	DWG NO. A1A
SOLAR HEATING & COOLING DEMONSTRATION PROJECT	SHT. - 1 OF 1
FLORIDA SOLAR ENERGY CENTER	DATE - 8/20/79
UNIVERSITY OF CENTRAL FLORIDA	DWN BY - D. SMITHFIELD
CAPE CANAVERAL, FLA.	APP'D - [Signature]

BILL OF MATERIALS

- FLOW SWITCHES - McDONNELL FS4-3
 LEVEL SWITCHES - McDONNELL 150
 RELAYS - POTTER & BRUMFIELD
 KRPIAG SERIES 10 A CONTACTS
 PHOTOCELL - TORK MODEL 2100
 CV-1A - 1 1/2" 2-WAY N.O. VP 2567-031
 CV-1B - 1 1/2" 2-WAY N.C. VP 2568-033
 CV-2 - 1 1/2" 3-WAY VP 2566-027
 CV-4 - 3" 2-WAY N.C. VP 2510-071
 CV-6 - 1 1/4" 2-WAY N.C. VP 2568-028
 TIMER-1 - EAGLE SIGNAL BR10A6 (60 MIN)
 TIMER-2 - EAGLE SIGNAL BR19A6 (20 MIN)

AS BUILT	7-1-9
ADD FLOW & LEVEL SW.	4-23-9
REDRAWN	
REV	DESCRIPTION
	DATE

SOLAR HEATING AND COOLING
 DEMONSTRATION PROJECT
 TEMPERATURE CONTROL DIAGRAM
 S.I. GOLDMAN COMPANY
 MECHANICAL CONTRACTOR
 P.O. BOX 1156 MAITLAND, FL
 DRAWING NO. 1001 1 OF 3

	N.O. CONTACTS		N.C. CONTACTS	
	CLOSE	OPEN	OPEN	CLOSE
PE-1			45°	38°
PE-3A			230°	225°
PE-3B	205°	200°		
PE-3C	125°	120°		
PE-3D	180°	170°		
PE-4	50°	45°		
PE-7	55°	50°		
PE-8	85°	80°		

NOTES:
 1. ALL TEMPERATURES GIVEN IN DEGREES °F.
 2. ALL PE RELAYS ARE SPDT

BILL OF MATERIALS

T1, T2, T3 TEMP TRANSMITTER TP2252-610
 RANGE: 40° - 240°
 T4, T5, T6, T7, T8 - TEMP TRANSMITTER TP2252-250
 RANGE: 0° - 100°
 P1-P8 - RECEIVER GAUGE GP2422-001
 RC-1, RC-3 - RECEIVER CONTROLLER,
 -RC-5 PP2341-001
 R1-R8 - RESTRICTOR P20-938
 PE-1, PE-3 - PNEUMATIC-ELECTRIC
 -PE-8 RELAY * POTTER &
 BRUMFIELD P10BC-7
 CV-5 - 1 1/2" 3-WAY PNEUMATIC VALVE
 VP2566-027

NOTES:
 1. ALL PARTS ROBERTSHAW UNLESS
 OTHERWISE NOTED *.
 2. ALL TEMPERATURE TRANSMITTERS
 USE P20-782 COPPER WELLS,
 EXCEPT T6.

AS BUILT	7-1-9
CHANGED CV-3 TO PNEU.	4-23-9
ADDED SCHEDULE	
REV	DESCRIPTION
	DATE

SOLAR HEATING AND COOLING
 DEMONSTRATION PROJECT
 TEMPERATURE CONTROL DIAGRAM
 S. I. GOLDMAN COMPANY
 MECHANICAL CONTRACTOR
 P.O. BOX 1156 MAITLAND, FL
 DRAWING NO. 1001 2 OF 3