TECHNICAL PROGRESS
JANUARY 1, 1990 - DECEMBER 30, 1991

MAR 30 1992

Project Title: Exposure to Radon and Radon Progeny
in the
Indoor Environment

Organization: Center for Energy and Environmental Studies
Princeton University
Princeton, NJ 08544
609 258-5446

Principal Investigator: Robert H. Socolow

Research Objective: The objective of this work is to measure experimentally the activity-weighted particle size distribution in conjunction with other relevant house parameters in occupied houses in order to improve the estimate of exposure to radon and radon progeny indoors.

Method: Our methodology requires that building construction and operation be studied and understood both experimentally and theoretically in a small number of buildings and that results of wide applicability be inferred from the particular case studies.

To meet these objectives, research houses are instrumented as follows:

1. Pressure differentials across the building shell and between the basement and upstairs are measured with differential pressure transducers.
2. Basement, living area, attic, and outdoor temperatures are monitored with thermistors.
3. Basement, living area, subslab and basement wall radon concentrations are monitored with passive radon detectors or pumped continuous radon monitors.
4. Basement relative humidity and air handler activity are also recorded.
5. A PFT (perfluorocarbon tracer) system is used to measure building air exchange rates and interzonal flows.

In addition, a weather station monitors temperature, rainfall, relative humidity, barometric pressure, and wind speed and direction.

Instrumentation to measure the activity-weighted particle size distribution is located in the actual living area of the occupied research house; the large pump associated with this instrument is placed in the basement or outdoors. We are very fortunate to have found homeowners who are interested in our work and extremely tolerant of these rather intrusive experiments.

Scientific Accomplishments:

- Activity-weighted particle size distribution measurements have been completed over three five day intervals in two different normally occupied Princeton research houses. This represents the largest collection of this type of data. These data have already been used to estimate more precisely the range of exposure and dose to individuals from radon and radon progeny.
- Field intercomparisons of activity-weighted particle size distribution measurements between manual graded screen arrays (EML) and an automated semi-continuous system (Clarkson University) have been made twice in Princeton research houses. Although overall agreement between the two systems is reasonable (total working level estimates), there are some discrepancies between the two systems in different parts of the particle size distribution spectrum. Efforts to resolve these differences are continuing.
- A detailed examination of radon entry rates and working level as a function of basement depressurization and ventilation rates has been completed. Ventilation has been found to be much more effective in reducing indoor radon concentration than was previously believed. We have clearly demonstrated that ventilation can reduce radon concentrations both by dilution and by the reduction of building depressurization.
- Measurement of radon entry rate as a function of basement depressurization has shown that the flow of soil gas into our research house is laminar. This is the first time such measurements have been made in an actual house.
- Measurements of radon entry rate as a function of basement depressurization before and after mitigation measures were performed have demonstrated a new and precise methodology for the evaluation of mitigation schemes.
- Systematic measurements of airflow in gravel and crushed stone have been made in a specially designed laboratory apparatus at Princeton. These are (astonishingly) the first measurements of this kind to be made. Permeabilities for crushed stone (0.5" and 0.75") were found to be 10-20 times as large as our previously reported values for these sizes of river run gravel. This data has been used in a model and compared to field results. The design of subslab depressurization systems will be substantially impacted by these findings.

Radon entry rate ($S1Rn$) as a function of basement depressurization (ΔP) for research house PU31, with both stack effect and forced ventilation used to depressurize the basement.

That $S1Rn$ is linear as a function of ΔP indicates that the soil gas flow into the basement is laminar, as has been postulated theoretically. This is the first experimental verification of this theory.

The upper line is a fit to data taken before the basement sump was sealed, while the lower line is a fit to data taken after the sump was sealed. This allows a precise comparison of the two house conditions. Previous work compared radon levels before and after mitigation measures were done; since radon concentration depends both on radon entry rate and ventilation rate, it is not a very scientific approach.

Resulting Publications:

1. Sachs, H.M., Hernandez, T.L., and Ring, J.W., Regional Geology and Radon Variability in Buildings, Environmental International 8, 97 (1982)
2. Harrje, D.T., Hubbard, L.M., Gadsby, K.J., Bolker, B.M., Bohac, D.L., The Effect of Radon Mitigation Systems on Ventilation in Buildings, submitted to ASHRAE Transactions, 1988.
3. Harrje, D.T., Hubbard, L.M., Sanchez, D., Diagnostic Approaches to Better Solutions of Radon Indoor Air Quality Problems, presented at Healthy Buildings '88, Stockholm, August 1988, and to be published in Environment International, 1988.
4. Gadsby, K.J., Hubbard, L.M., Harrje, D.T., Sanchez, D., Rapid Diagnostics: Subslab and Wall Depressurization Systems for Control of Indoor Radon, Presented at the USEPA 1988 Symposium on Radon and Radon Reduction Technology, Denver, Colorado October 1988.
5. Hubbard, L.M., Gadsby, K.J., Bohac, D.L., Lovell, A.M., Harrje, D.T., Socolow, R.H., Matthews, T., Sanchez, D., Radon Entry into Detached Dwellings: House Dynamics and Mitigation Techniques, presented at the Fourth International Symposium on Radiation in the Natural Environment, Lisbon, Portugal, December 1987, and accepted for publication in Radiation Protection Dosimetry, 1988
6. Hubbard, L.M., Bohac, D.L., Gadsby, K.J., Harrje, D.T., Lovell, A.M., Socolow, R.H., Research on Radon Movement in Buildings in Pursuit of Optimal Mitigation, Proceedings on the 1988 Summer Study on Energy Efficiency in Buildings, Asilomar, CA 1988
7. Hubbard, L.M., Bolker, B., Socolow, R., Dickerhoff, D., Mosley, R.B., Radon Dynamics in a House Heated Alternately by Forced Air and Electric Resistance, presented at The USEPA 1988 Symposium on Radon and Radon Reduction Technology, Denver, CO, Oct 1988.
9. Cavallo, A., Berkner, C., Gadsby, K., Use of Ventilation to Control Radon in Single Family Dwellings, presented at the Fifth International Conference on Indoor Air Quality and Climate, Toronto, Canada, August 1990.
Submitted for publication in Atmospheric Environment.
10. Reddy, T.A., Molineaux, F.B., and Socolow, R.H., Statistical Analysis of Weekly Averaged Radon Levels in Three Residences Over a Complete Year, presented at the Fifth International Conference on Indoor Air Quality and Climate, Toronto, Canada, August 1990.
11. Gadsby, K., Harrje, D., Durability of Subslab Radon Mitigation System Performance, presented at the Fifth International Conference on Indoor Air Quality and Climate, Toronto, Canada, August 1990.

12. Socolow, R.H., Reddy, R.H., and Hull, D.A., Insights Into the Time Dependent Behavior of Indoor Radon Levels From Continuous Measurements, Proceedings, American Council for an Energy Efficient Society (ACEEE) Summer Study on Energy Efficiency in Buildings, Asilomar, CA, August, 1991.

13. Goble, R., Socolow, R., High Radon Houses: Implications for Epidemiology and Risk Assessment, presented at The 1990 International Symposium on Radon and Radon Reduction Technology, Atlanta, GA, Feb 19-23, 1990.

14. Hull, D.A., Reddy, T.A., Study on the Reliability of Short Term Measurements to Predict Long Term Basement Radon Levels in a Residence, presented at The 1990 International Symposium on Radon and Radon Reduction Technology, Atlanta, GA, Feb 19-23, 1990.

15. Hull, D.A., Time Series Linear Regression of Half-hourly Radon Levels in a Residence, presented at The 1990 International Symposium on Radon and Radon Reduction Technologies, Atlanta, GA, Feb 19-23, 1990.

16. Gadsby, K., A Simplified Modeling Approach and Field Verification of Airflow Dynamics in Subslab Depressurization Systems, presented at The 1990 International Symposium on Radon and Radon Reduction Technologies, Atlanta, GA, Feb 19-23, 1990.

17. Reddy, T.A., Cavallo, A., and Socolow, R., Predicting Long-Term Indoor Radon Levels from Short-Term Measurements: Evaluation of a Method using Temperature Correction", presented at The 1991 International Symposium on Radon and Radon Reduction Technology, Philadelphia, PA., April 1991.

18. Cavallo, A., Reddy, T.A., and Socolow, R., Natural Basement Ventilation as a Radon Reduction Technique, presented at The 1991 International Symposium on Radon and Radon Reduction Technology, Philadelphia, PA., April 1991.

19. Cavallo, A., Reddy, T.A., and Socolow, R.H., The Effect of Natural Ventilation on Radon and Radon Progeny Levels in Houses", accepted for presentation at 5th International Symposium on the Natural Radiation Environment, Salzburg, Austria, September 1991.

20. Hopke, P., Wasiolek, P., Knutson, E.O., Tu, K.W., Gogolak, C., Cavallo, A., Gadsby, K., and Van Cleef, D., Intercomparison of Activity Size Distribution Measurements With Manual and Automated Diffusion Batteries-Field Test, presented at The 1991 International Symposium on Radon and Radon Reduction Technology, Philadelphia, PA., April 1991.

21. Wasiolek, P., Hopke, P., Montassier, N., Cavallo, A., Gadsby, K., Socolow, R.H., The Field Measurement of Activity-Weighted Size Distributions of Radon Decay Products, presented at the International Symposium "Measurement of Toxic and Related Air Pollutants, Durham, NC, May 6-10, 1991.

22. Hopke, P., Wasiolek, P., Montassier, N., Cavallo, A., Gadsby, K., Socolow, R.H., Measurement of Activity-Weighted Size Distributions of Radon Decay Products in Normally Occupied Homes, accepted for presentation at 5th International Symposium on the Natural Radiation Environment, Salzburg, Austria, September 1991.

23. Gadsby, K., Reddy, T.A., Anderson, D.F., Gafgen, R., The Effect of Aggregate Size on Pressure Field Extension, presented at The 1991 International Symposium on Radon and Radon Reduction Technology, Philadelphia, PA., April 1991.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

END

**DATE
FILMED
5107192**