17
3-28-80
246 NT 15

MASTER

UCRL-52835

PELE-IC test problems

**E. Y. Gong
E. E. Alexander
W. H. McMaster
D. F. Quiñones**

October 1, 1979

**Lawrence
Livermore
Laboratory**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This work was supported by the United States Nuclear Regulatory Commission under a Memorandum of Understanding with the United States Department of Energy.

PELE-IC test problems

E. Y. Gong
E. E. Alexander
W. H. McMaster
D. F. Quiñones

Manuscript date: October 1, 1979

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors endorsed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

LAWRENCE LIVERMORE LABORATORY
University of California • Livermore, California • 94550

Available from: National Technical Information Service • U.S. Department of Commerce
5285 Port Royal Road • Springfield, VA 22161 • \$7.00 per copy • (Microfiche \$3.50)

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CONTENTS

Abstract	vii
Executive Summary	viii
Introduction	1
Test Problems	3
Draining Tanks	3
Spherical Bubble Growth	3
MIT Tank Air-Blowdown	6
LLL One-Fifth Scale Torus Calculations	12
References	17
Appendix A: Control Card and Input Listings	A-1
Cylindrical Draining Tank	A-2
Funnel-Shaped Draining Tank	A-3
Spherical Bubble Growth	A-4
MIT Tank Air-Blowdown--Rigid Bottom	A-5
MIT Tank Air-Blowdown--Flexible Bottom	A-7
LLL One-Fifth Scale Torus	A-8
Appendix B: Sample Numbers Computed from Test Problems	B-1
Appendix C: Timing Information	C-1
Appendix D: Geometric Plots of Test Problems and Miscellaneous Notes	D-1
Appendix E: Test Problem Data (see microfiche inside back cover)	

LIST OF ILLUSTRATIONS

1.	Calculation of a cylindrical draining tank with PELE-IC:	
	(a) comparison of average calculated and theoretical water level;	
	(b) comparison of outlet velocity vs time	4
2.	Calculation of a funnel-shaped draining tank with PELE-IC:	
	(a) comparison of average calculated and theoretical water level;	
	(b) comparison of outlet velocity vs time	4
3.	Comparison of PELE-IC calculations and analytical solutions for spherical bubble growth as a function of time	5
4.	Apparatus for the MIT tank blowdown experiments	6
5.	Comparison of measured downcomer pressure and PELE-IC calculated bubble pressure with an orifice-flow computer model	8
6.	PELE-IC calculated bubble shapes at different times for the rigid-bottom MIT tank	8
7.	Comparison of PELE-IC calculations and measured wetwell pressure for the rigid-bottom MIT tank	9
8.	Fluid pressure as function of time at three locations in the rigid-bottom MIT tank	9
9.	Fluid pressure as a function of time at three locations for the flexible-bottom MIT tank with the 1-mm-thick bottom plate	10
10.	PELE-IC calculated pressure distribution at 28 ms (vent clearing time) for the 1-mm-thick plate at time of peak pressure with a 2.5 kPa interval between pressure contours	11
11.	PELE-IC calculated displacement of the center of the 1-mm-thick bottom plate for the MIT tank	12
12.	Computer model of the LLL 1/5-scale torus	13
13.	PELE-IC calculated uploads and downloads during vent clearing in the LLL 1/5-scale torus: (a) rigid structure and support; (b) flexible structure and support; (c) flexible structure with 1/16 the support stiffness of (b); (d) superposition of three previous cases	14
14.	Pressure profiles of 1/5-scale torus at three times during blowdown	16

LIST OF ILLUSTRATIONS (Continued)

D-1	Cylindrical draining tank with and without grid	D-2
D-2	Draining funnel with and without grid	D-2
D-3	Spherical bubble with and without grid	D-3
D-4	MIT tank air-blowdown--rigid bottom with and without grid	D-4
D-5	MIT tank air-blowdown--flexible bottom with and without grid . . .	D-4
D-6	LLL 1/5-scale torus with and without grid	D-5

LIST OF TABLES

B-1. Cylindrical draining tank	B-2
B-2. Funnel-shaped draining tank	B-3
B-3. Spherical bubble growth	B-3
B-4. MIT tank air-blowdown--rigid bottom	B-4
B-5. MIT tank air-blowdown--flexible bottom	B-4
B-6. LLL 1/5-scale torus calculation	B-5
C-1. Timing information	C-2

ABSTRACT

This report provides prospective users of the Lawrence Livermore Laboratory (LLL) fluid-structure interaction computer code, PELE-IC, a variety of test problems for verifying the code on CDC 7600 computer systems at facilities external to the LLL environment. The test problems have been successfully run on CDC 7600 computers at the LLL and Lawrence Berkeley Laboratory (LBL) computer centers.

EXECUTIVE SUMMARY

This report is a result of Nuclear Regulatory Commission (NRC) sponsored research* relating to boiling water reactor (BWR) pressure-suppression systems. The Lawrence Livermore Laboratory (LLL) PELE-IC computer code was developed in order to calculate fluid-structure interactions and bubble dynamics occurring in a pressure-suppression system following a loss-of-coolant accident (LOCA).

Documentation of the PELE-IC code is given in a previously published physics writeup and in a computer code user's manual. In November of 1979, a standard FORTRAN IV version of PELE-IC was released to the National Energy Software Center at Brookhaven National Laboratory. This document, which accompanies the PELE-IC code release, provides a series of check (test) problems for the code once it has been implemented on the user's CDC and Cray systems.

The six test problems chosen are cylindrical draining tank, a funnel-shaped draining tank, spherical bubble growth, and air-blowdown calculation for a rigid-bottom tank, an air-blowdown calculation for a flexible-bottom tank, and an air-blowdown calculation in a flexible-torus sector. Each of the six test problems is accompanied by input decks, computer output, time plots, geometry plots, and contour plots. It is the user's responsibility to match their PELE-IC calculated results against those in this report.

*NRC Office of Nuclear Regulatory Research, Task 189.

PELE-IC TEST PROBLEMS

INTRODUCTION

In loss-of-coolant accidents the steam in the reactor vessel is forced through downcomer pipes into a water pool contained in an adjacent steel or concrete structure. Loads occur on the containment structure both during the air and steam jetting into the water and later during oscillatory condensation of the steam bubbles at lower mass-flow rates. The PELE-IC computer code predicts fluid-structure interaction in boiling-water-reactor pressure-suppression systems. The resultant calculations give the load and the responses of the containment structure. These calculations serve as test problems for prospective PELE-IC users. This report provides the verification and application calculations performed within the Lawrence Livermore Laboratory (LLL) and Lawrence Berkeley Laboratory (LBL) computer centers for the PELE-IC computer code. The complete test results are provided at the end of this report in the form of microfiche.

To make the PELE-IC source code available to other computer centers, we switched from the LLL specialized compiler, CHAT, to the standard FORTRAN FTN compiler* and then computed the test problems on the LBL CDC 7600 computer; problem run times were from 5 to 40 minutes. The LBL version of the PELE-IC code required software modifications to replace POINTER and STRUCTURE words, so in this respect it is slightly different than the LLL version; however, the two codes are equivalent for purposes of calculation. For every test problem the results obtained were in excellent agreement. As a result, our level of confidence in the software is very high. The LLL version of PELE-IC is the

*The major differences between the CHAT compiler and the standard FORTRAN FTN compilers are in dynamic storage allocation (POINTER) and in partitioning words of memory into smaller pieces so that they may be referenced directly (STRUCTURE words). These features make the CHAT compiler more efficient. Consequently, the PELE-IC code runs about twice as fast on the CDC 7600 with the CHAT compiler as with the standard FORTRAN FTN compiler. The code also runs on the LLL Cray machine at about 2 to 2.5 times as fast as the LLL CDC 7600.

base code from which updates are made. The current LLL version of the standard PELE-IC FTN code can be obtained upon request.

The foundation of the PELE-IC code is the SOLA Eulerian finite-difference fluid algorithm of Hirt et al.¹ derived from the MAC (Marker and Cell) code.² The structure, which is modeled with a small-displacement finite-element shell developed by Goudreau,³ is strongly coupled to the fluid in an iteration loop in the SOLA algorithm with normal velocity compatibility between the shell and the fluid. A new free-surface algorithm⁴ tracks the air-water interface (as the suppression pool rises) and the interface between the water and the growing bubble at the end of the pipe downcomer. The PELE-IC code contains the boundary conditions necessary for modeling containment suppression applications, an orifice flow model for calculating driving pressure, and marker particles for tracing flow paths. A code generator facilitates the zoning required for axisymmetric and plane containment applications, and a post processor is available for computer graphics (currently available only at LLL). Further code description is given by McMaster et al.,⁴ Norris et al.,⁵ and McMaster et al.⁶ A user's manual has been written by McMaster and Gong.⁷

TEST PROBLEMS

In selecting verification problems for the PELE-IC code, we were guided by future applications of the code and the need to test the new coupling and free-surface algorithms.⁴⁻⁶ We calculated examples from the literature that had analytical solutions and computed small-scale test problems that modeled, to some degree, the steam-air blowdown phenomenon. These test problems were then used to verify the calculations performed at LLL. Appendix A gives the control cards and input listing for each test problem considered. Information such as grid size, time step, and convergence criteria are identified in the input listing using Ref. 7. Appendix E lists a sample table of the actual numbers computed from each test problem. The tables aid the user in checking the code against our results. Appendix C compares timing information for the problems run at LLL and LBL. The 0813 (Aug. 13, 1979) version of the code was used to run all test problems presented here. Appendix D shows rectangular Eulerian grid and geometric plots for each of the six test problems.

DRAINING TANKS

We simulated water draining from cylindrical and funnel-shaped tanks with gravitational and overpressure loads. These calculations checked mass conservation associated with moving free surfaces and randomly oriented boundaries. The tanks were modeled with rigid walls and bottoms and with an outlet pipe that was opened at the start of the calculation. These calculations simulated the initial transient response and the later quasi-steady flow. We obtained comparison solutions for these problems using a one-dimensional control volume approach.⁸ The calculated water level and exit velocity is compared with the analytical results for the cylindrical tank in Fig. 1. These calculations used two zones in the pipe and 20 zones across the tank diameter. Excellent agreement was obtained with a funnel-shaped tank (Fig. 2) also.

SPHERICAL BUBBLE GROWTH

Simulation of air and steam blowdown requires accurate calculation of bubble growth to correctly calculate pressure loads on the structure containing the

FIG. 1. Calculation of a cylindrical draining tank with PELE-IC
(a) Comparison of average calculated and theoretical water level,
(b) Comparison of outlet velocity vs time.

FIG. 2. Calculation of a funnel-shaped draining tank with PELE-IC
(a) Comparison of average calculated and theoretical water level,
(b) Comparison of outlet velocity vs time.

suppression pool. The solution for an expanding spherical bubble with constant driving pressure in an infinite inviscid fluid has been given by Parker et al.⁹ The radius as a function of time is given by

$$R \ddot{R} + \frac{3}{2} \dot{R}^2 = \frac{\delta P}{\rho} , \quad (1)$$

where δP is the driving overpressure and ρ is the density of the liquid.

Our calculation used a 40-mm-diam bubble and a grid with continuative boundary conditions with a radius of 200 mm. The driving pressure was 20 kPa. A comparison with the analytical solution is shown in Fig. 3 for an over four-fold increase in volume. The bubble maintained sphericity to within 4%.

This spherical geometry was meshed in cylindrical coordinates using square Eulerian cells.

FIG. 3. Comparison of calculated and analytical solutions for spherical bubble growth as a function of time.

MIT TANK AIR-BLOWDOWN

The Javadi and Huber¹⁰ experiments used a rigid cylindrical tank with a central pipe downcomer with the exit submerged below the water surface. A quick-opening solenoid valve releases air from a pressurized drywell that flows through an orifice and down the pipe into the water. The flow is initially choked by the orifice but the dynamic pressure rises in a few milliseconds to that of the drywell. This pressure is applied to the water surface pushing the water out of the pipe in about 20 ms. The peak dynamic pressure occurs at the center of the bottom plate at about this time. The drywell pressure in the downcomer is maintained until vent clearing, and then it is suddenly released by the growing bubble. As the bubble reaches the water surface the pressure rises to that of the drywell. The apparatus is shown in Fig. 4.

FIG. 4. Apparatus for the MIT blowdown experiments.

Tests were made with rigid and flexible bottom plates. Pressure is recorded in the downcomer, in the wetwell air space above the water surface, and in the water. The air in the wetwell was pressurized to 5.7 kPa (absolute) initially, and the pressure was balanced on the flexible plate so that it saw only the weight of the water. The drywell pressure was 17.1 kPa. The water was cooled to just above freezing to lower the vapor pressure and a surfactant was added to remove trapped air bubbles.

We found that computer simulations using the experimental downcomer pressure pulse predicted much smaller bubble volumes than those given by Javadi and Huber.¹⁰ We replaced their pressure pulse with a computer model of the orifice flow that is used in all the calculations reported here (see Landram et al.⁵). This computer model couples the bubble growth volume to the bubble pressure by the equation

$$p = p_d \left(\frac{V_0}{V} \right)^\gamma \left[1 + \frac{\gamma}{\rho_d V_0^\gamma} \int_0^t \dot{m} V^{\gamma-1} dt \right], \quad (2)$$

where p_d is the ullage pressure, ρ_d is the ullage air density, V_0 is the air volume of the downcomer at the initial pressure p_d , γ is the specific heat ratio for air, and $\dot{m}$ is the flow rate through the orifice (see Vennard¹¹).

The differences between the downcomer pressure gage and the pressure prediction of the computer model are shown in Fig. 5. The calculation shows that a strong coupling exists between the start of bubble growth and the driving pressure decay and that incompatibilities here introduce instabilities in the calculation. Our calculation predicts a later vent clearing time than that of the experiment and, as predicted by the computer flow model, requires the driving pressure to hold up longer.

Bubble growth is shown in Fig. 6. Figure 7 compares the increase of wetwell pressure from pool swell with the Javadi and Huber data. The calculated pressure was shifted 5 ms to agree with the earlier vent-clearing time of the experiment and start of bubble growth. The good agreement shows that the

FIG. 5. Comparison of measured downcomer pressure and that calculated with an orifice-flow computer model.

FIG. 6. Fluid pressure as function of time at three locations in the rigid bottom tank.

FIG. 7. MIT calculated bubble shapes at different times.

calculated bubble volumes are correct. Results for the rigid bottom calculation are given in Fig. 8, the pressure in the fluid vs time. Calculated pressures at three different locations are given with the Javadi and Huber data from the pressure transducer. These calculated traces are almost identical except for the vertical shift caused by the static head. In Figs. 8 and 9 the vent clearing times have not been normalized (by 5 ms) for the experiment and calculation.

FIG. 8. Comparison of calculated and measured wetwell pressure.

FIG. 9. Fluid pressure as a function of time at three locations for the flexible tank with the 1-mm-thick bottom plate.

A flexible-bottom calculation using a 1-mm-thick aluminum plate (see Fig. 9) shows the strong effect of the fluid-structure interaction. We found that the pressure at three different locations in the water varies considerably in contrast to that of the rigid bottom (Fig. 8). The peak response shows a dynamic amplification of 68% above the drywell pressure. These calculations and the experiments show that the phasing of the structural response and the driving pressure can cause large dynamic amplifications. The measured pressure is also plotted on this figure and agrees well both in amplitude and frequency with the calculation. This spatial dependence of pressure may also be seen in the pressure contours of Fig. 10.

Calculated bottom plate displacement vs time is shown in Fig. 11. We calculate a peak displacement of 0.75 mm for this 1-mm-thick plate. This displacement is large compared to the plate thickness and results in substantial deviations from the linear theory (see Timoshenko et al.¹²). The membrane strain stiffens the plate and increases the natural frequency reduced by the fluid-structure interaction. We calculated a peak strain of 364 microstrain compared with 300 microstrain obtained by Javadi and Huber.¹⁰

FIG. 10. Calculated pressure distribution at 28 ms for the 1-mm-thick plate. This is the time of peak pressure.

We have given considerable attention to the differences in vent clearing times between the calculations and the experiments. Kang et al.¹³ show that for a constant pressure differential the vent clearing time is given by

$$t \approx L \sqrt{\frac{\pi \rho}{2 \Delta P}} \quad (3)$$

Assuming a constant backpressure equal to that of the wetwell plus the static head at the end of the downcomer in Eq. (3) gives 19.4 ms. Javadi and Huber give 21 ms and we calculate about 24 ms. The PELE-IC calculation shows that considerable dynamic backpressure develops at the bottom of the vent, which is not accounted for in Eq. (3), and makes the calculation a lower bound to the actual vent clearing time. We have been unable to resolve the time difference between experiment and calculation.

FIG. 11. Calculated displacement of the center of the 1-mm-thick plate.

LLL ONE-FIFTH SCALE TORUS CALCULATIONS

A one-fifth scale model of the pressure suppression system of the Mark I boiling water reactor was constructed and tested at the Lawrence Livermore Laboratory (see Collins et al.¹⁴). The focus of these tests was to determine downloads and uploads on 90- and 7.5-deg sectors. The downloads are produced by the momentum of the water at vent clearing. As the bubble expands and the water surface rises, the net load on the torus shifts upward until it reaches a peak before returning to static conditions. Computer simulations of these tests are under way to understand the experimental phenomenology and the unexpected higher uploads in the 90-deg segment.

We simulated tests done on both the 90- and 7.5-deg sectors. A plain strain model was used with a vertical axis of symmetry containing the torus center line. The torus was supported as shown in Fig. 12. Calculations were made to investigate the influence of torus stiffness and flexible supports on uploads. Three typical vertical load histories computed from integration of the pressure distributions are shown in Fig. 13.

FIG. 12. Computer model of the 1/5-scale torus.

FIG. 13. Calculated uploads and downloads during vent clearing in the 1/5-scale torus; (a) rigid structure and support, (b) flexible structure and support, (c) flexible structure with 1/16 the support stiffness of (b), (d) superposition of three previous cones.

The results of Fig. 13a are for a rigid structure and support. There is a low frequency response showing download and upload following the initial static deflection. In Fig. 13b and 13c the flexibility of the structure and support was modeled with support motion allowed only in the vertical direction. We obtained the same low frequency response with a high frequency component superimposed. (The input deck in Appendix A is for the problem associated with Fig. 13b.) This frequency corresponds to that of a simple spring mass system with a spring constant equal to the support stiffness and mass of the structure plus a calculated effective water mass (about 1/2 the total water mass). This mass remains approximately constant for the hard and soft spring support. The support spring constant for Fig. 13b is a factor of 16 larger than that for Fig. 13c with the calculated frequency differing by a factor of four as expected. The superposition of the three calculations, shown in Fig. 13d, indicates that the response of the rigid case represents the mean of the flexible structure with spring supports. The force due to the mass of the shell is not included in this version of the work.

Figure 14 shows the interrelation between bubble dynamics and upload and the pressure contours at different periods of bubble growth. Important to the understanding of this phenomenon is the phasing between the bubble and pool pressure and the ullage pressure. In Fig. 14a the pressure contours show a net downward force. The dynamics are still driven by the force of the water pushing down as vent clearing occurs and the bubble starts to grow. As it expands, the path of least resistance is towards the surface. A net upward force is clearly shown in Fig. 14b. A high pressure region is located in the upper portion of the torus because of ullage compression with the lower section of the torus now at a lower pressure. During later time the phase difference disappears and the force equilibrates as shown in Fig. 14c.

The above calculations explain the upload phenomenon. Uploads are caused by bubble growth toward the free surface with a higher pressure region in the upper part of the torus. The movement of the structure and support contribute a relatively small high frequency component to this main load profile. The pressure contours of Fig. 14 show that the geometry of the structure plays an important role in the magnitude of these loads and careful design can reduce them.

Note: Pressure on contours in bars

FIG. 14. Pressure profiles at three times during blowdown.

The two-dimensional nature of these calculations limits the conclusions that can be drawn. Extrapolating the computer results to a full 90-deg torus, for example, gives downloads and uploads much larger than the experimental results. Such an extrapolation implies much more water displacement than is actually the case. The downcomers are circular and discretely placed but in the plane-strain analysis the downcomer is a continuous channel. The bubbles cannot expand and interact in three dimensions. To investigate these effects, additional plane strain and axisymmetric simulations were done;⁴ however, the calculations reported here are sufficient to describe the general upload phenomenology.

REFERENCES

1. C. W. Hirt, B. D. Nichols and N. C. Romero, SOLA--A Numerical Solution Algorithm for Transient Fluid Flow, Los Alamos Scientific Laboratory, Los Alamos, N. Mex., LA-5852 (1975).
2. F. H. Harlow and J. E. Welch, "Numerical Calculation of Time-Dependent Viscous Incompressible Flow," Phys. Fluids **8**, 2182 (1965).
3. G. L. Goudreau, A Computer Module for One Step Dynamic Response of an Axisymmetric or Plane Linear Elastic Thin Shell, Lawrence Livermore Laboratory, Livermore, Calif., UCID-17730 (1978).
4. W. H. McMaster, D. F. Quiñones, C. S. Landram, D. M. Norris, Jr., E. Y. Gong, N. A. Macken, and R. E. Nickell, Coupled Fluid-Structure Method for Pressure Suppression Analysis, 2nd Annual Report to the U.S. Nuclear Regulatory Commission, Lawrence Livermore Laboratory, Livermore, Calif., Contract A0116, to be published 1980.
5. D. M. Norris, Jr., W. H. McMaster, C. S. Landram, D. F. Quiñones, E. Y. Gong, and N. A. Macken, Computer Calculations of Air-Steam Blowdown Suppression, Lawrence Livermore Laboratory, Livermore, Calif., UCRL-83915 (1979).
6. W. H. McMaster, D. M. Norris, Jr., G. L. Goudreau, D. F. Quiñones, E. Y. Gong, B. Moran and N. A. Macken, Coupled Fluid-Structure Method for Pressure Suppression Analysis, U.S. Nuclear Regulatory Commission NUREG/CR-0607 (1979).
7. W. H. McMaster and E. Y. Gong, PELE-IC Users Manual, Lawrence Livermore Laboratory, Livermore, Calif., UCRL-52609 (1979).
8. A. G. Hansen, Fluid Mechanics (John Wiley & Sons, Inc., New York, 1967), pp. 134-138.
9. J. D. Parker, J. H. Boggs and E. F. Blick, Introduction to Fluid Mechanics and Heat Transfer (Addison-Wesley Publishing Company, Inc., Reading, Mass., 1969), p. 345.
10. Y. Javadi and P. W. Huber, Tests of Fluid-Structure Interactions in a Small Scale "Pool Swell" System, Fluid Mechanics Laboratory, Department of Mechanical Engineering Technology, Massachusetts Institute of Technology, Cambridge, Mass. (1979).
11. J. K. Vennard, Elementary Fluid Mechanics (John Wiley, New York, 1954), 3rd ed., pp. 110-111 and 301-305.

12. S. Timoshenko and S. Woinowsky-Krieger, Theory of Plates and Shells (McGraw Hill, New York, 1959), 2nd ed., pp. 404-408.
13. S. W. Kang, "Analytic Studies of Vent Clearing and Jet-Slug Dynamics," in Reactor Containment Analysis for BWR Suppression Systems, L. L. Edwards, Ed., Lawrence Livermore Laboratory, Livermore, Calif., UCRL-50045-77-2 (1977).
14. E. K. Collins and W. Lai, Final Air Test Results for the 1/5 Scale Mark I Boiling Water Reactor Pressure Suppression Experiment, Lawrence Livermore Laboratory, Livermore, Calif., UCRL-52371 (1977).

EHB

LLL:1980/2

APPENDIX A

CONTROL CARD AND INPUT LISTINGS

The input deck can be interpreted by using the PELE-IC user's guide (see Ref. 7). The computer input file is divided into two sections. The input records on line terminating with a \$ sign are generally used for problem generation. All others are control cards used to run the computer code.

CYLINDRICAL DRAINING TANK

PELEIC,16,10000.638191,ALEXANDERE
 SID=ALEX
 STAGE,EV,34651,MT.
 LIBRITE,ALEXANDERE,EV,ALEX2,400,G=PELEICDC,W=ALEXANDER.
 FTN4,I=EV,L=0,PL=999999999.
 COPY,INPUT,1R,TAPE59/RR.
 COPY,INPUT,1R,TAPE7/RR.
 LINK,X,CS=ZERO.
 EXIT.
 DUMP,0.
 GRUMP,P=LIST.
 FIN.
 DISPOSE,OUTPUT=MF.
 7/8/9 CARD

G

TANK0813

7/8/9 CARD

TANK0813

	10	30							
	1	10.	10.	0.					
	2	30.	30.	0.					
0									
-1									
	6	1	3						
	9	1	1						
0									
+1									
	3	1	.3						
	6	1	1.E-7						
	9	1	-9.81E-4						
	5	1	1.						
	16	3	300.	30.	30.				
0									
+2									
	1								
	-1	0	20.0						
0									
+3									
	1								
	-1	0	0.0						
0									
+4									
	1	1	10	10	20	0	0	0	0
	100000.		1.						
0									
+5									
	1	1	1	10	1				
	2	10	10	10	10				
	0	1	0	0	0				
	2	10	11	11					
	0	0	0	1					
	2	2	10	10					
	0	1	1	0					
	1	1	1	1					
	1	0	0	0					
0									
+6									
	1	10	1	10					
	4	1.							
	0								
	1	1	1	10					
	4	0.							
0									
0									
+10									
	2	4	4	0.5	10.5	9.5	13.5	G	
	2	3	3	0.5	0.5	0.5	9.5	Y	
0									
0									
0									
0									

6/7/8/9 CARD OR EOJ CARD

FUNNEL-SHAPED DRAINING TANK

FUNNEL.16,10000.638191,ALEXANDERE

SID=ALEX

LIBCOPY,ALEXANDERE,EV,ALEX2.

FTN4,I=EV,L=LIST,PL=999999999.

COPY,INPUT,1R,TAPE59/RR.

COPY,INPUT,1R,TAPE9/RR.

LINK,X,CS=ZERO.

EXIT.

DUMP,0.

GRUMP,P=LIST.

FIN.

DISPOSE.OUTPUT=MF.

7/8/9/ CARD

G

FUNNEL 0813

7/8/9/ CARD

FUN0816 VER0813 BKV

10	30		
1	10.	10.	0.
2	30.	30.	0.

0

-1

6	1	3
9	1	1

0

+1

3	1	.3		
6	1	1.E-7		
9	1	-9.81E-4		
5	1	1.		
16	3	300.	30.	30.

0

+2

1		
-1	0	20.

0

+3

1	1	1
-1	0	0.00

0

+4

1	1	10	11	20	0	0	0	0
5000.	1.							

0

+5

1	1	1	10	1
---	---	---	----	---

0

+6

1	1	1	10
4	0		
0			

0

+10

2	4	4	0.5	10.5	9.5	13.5	G
2	3	3	0.5	0.5	0.5	9.5	Y

0

+11

1	10	10	22	1
0.				
1	1.	10.		
3	10.	20.		
1	10.	22.		
4	0.	22.		
-1				

0

0

0

0

6/7/8/9/ CARD OR E0J CARD

MIT TANK AIR-BLOWDOWN--RIGID BOTTOM

MITRIG,16,10000.638191,ALEXANDERE

SID=ALEX

LIBCOPY,ALEXANDERE,EV,ALEX2.

FTN4,I=EV,L=LIST,PL=999999999.

COPY,INPUT,IR,TAPE59/RR.

COPY,INPUT,IR,TAPE9/RR.

LINK,X,CS=ZENO.

EXIT.

DUMP,0.

GRUMP,P=LIST.

END.

D.SPOSE,OUTPUT=MF.

7/8/9 CARD

0

MITR0013

7/8/9 CARD

MITRIG VER0013

000000

1 16.0 16. 0

2 12.11 52. 0

0

-1 IZBLOCK

9 1 1

16 1 2

33 1 1

100 2 16 13

27 2 1 2

29 2 16 2

31 2 3 2

44 1 8

0

+1 ZZBLOCK

1 2 0.05 0.25

3 1 .05

4 1 13.0E-4

5 1 1.

6 1 1.E-4

9 1 -9.81E-4

11 1 -.1

15 1 1.3

16 3 1000. 100. 100.

32 1 .057

40 2 .05 .25

0

+2 TOP SURFACE

1

-1 1 15.83

0

+4 BOUNDARY SOURCES ABSOLUTE PRESSURES & ULLAGE HEAD

8 1 3

0.171 300. 0. 0.

1.275 0.625 1.275

0.057 273. 123.5 15.83

0.98 0.62 0. 0.

+5 PIPE

3 3 26 52 1

0

+8

.1 .29 .69E6 2.7 .01 0 0 2

1 1 1 1 1 1

MIT TANK AIR-BLOWDOWN--RIGID BOTTOM (continued)

1	1.E20	1.E20	1.E20	\$
2	1.E20	1.E20	1.E20	\$
3	1.E20	1.E20	1.E20	\$
4	1.E20	1.E20	1.E20	\$
5	1.E20	1.E20	1.E20	\$
6	1.E20	1.E20	1.E20	\$
7	1.E20	1.E20	1.E20	\$
8	1.E20	1.E20	1.E20	\$
9	1.E20	1.E20	1.E20	\$
10	1.E20	1.E20	1.E20	\$
11	1.E20	1.E20	1.E20	\$
12	1.E20	1.E20	1.E20	\$
13	1.E20	1.E20	1.E20	\$
14	1.E20	1.E20	1.E20	\$
15	1.E20	1.E20	1.E20	\$
16	1.E20	1.E20	1.E20	\$
17	1.E20	1.E20	1.E20	\$
0				\$
+9	ULLAGE			\$
	203.4	.057	1.4	\$
0				\$
0				\$
0				\$
6/7/8/9	CARD OR EOJ CARD			\$

MIT TANK AIR-BLOWDOWN--FLEXIBLE BOTTOM

MITFLX,16,10000.638191,ALEXANDERE

SID=ALEX

LIBCOPY,ALEXANDERE,EV,ALEX2.

FTN4,I=EV,L=LIST,PL=999999999.

COPY,INPUT,1R,TAPE59/RR.

COPY,INPUT,1R,TAPE9/RR.

LINK,X,CS=ZERO.

EXIT.

DUMP,0.

GRUMP,P=LIST.

FIN.

DISPOSE,OUTPUT=MF.

7/8/9 CARD

G

MITF0813

7/8/9 CARD

MITFLX VER0813

16 52

1 6.8 16. 0

2 22.11 52. 0

0

-1 IZBLOCK

9 1 1

16 1 2

33 1 1

18 2 16 13

27 2 1 2

29 2 16 2

31 2 8 2

44 1 8

0

+1 ZZBLOCK

1 2 0.05 0.25

3 1 .05

4 1 13.0E-4

5 1 1.

6 1 1.E-4

9 1 -9.81E-4

11 1 -.1

15 1 1.3

16 3 1000. 100. 100.

32 1 .057

40 2 .05 .25

0

+2 TOP SURFACE

1

-1 1 15.83

0

+4 BOUNDARY SOURCES ABSOLUTE PRESSURES & ULLAGE HEAD

8 1 3

0.171 300. 0. 0.

1.275 0.525 1.275

0.057 273. 123.5 15.83

0.98 0.62 0. 0.

+5 PIPE

3 3 26 52 1

0

+8

.1 .29 .69E6 2.7 .01 0 0 2

1 1 0 1 1 1 1

0

+9 ULLAGE

203.4 .057 1.4

0

0

0

6/7/8/9 CARD OR E0J CARD

LLL 1/5-SCALE TORUS

FIFTHS,16,10000.638191,ALEXANDERE

SID=ALEX

LIBCOPY,ALEXANDERE,EV,ALEX2.

FTN4,I=EV,L=LIST,PL=3999999999.

COPY,INPUT,IR,TAPE9/RR.

COPY,INPUT,IR,TAPE9/RR.

LINK,N.CS=ZEFO.

EXIT.

DUMP,0.

GRUMP,P=LIST.

FIN.

DISPOSE,OUTPUT=MF.

7/8/9 CARD

G

FIFTH

7/8/9 CARD

FIF0816 V-0813 FLEX

18 36

1 108. 18. 0.

2 216. 36. 0

0

-1

9 1 1

16 1 5

18 2 1 3

27 2 15 13

29 2 5 1

31 2 15 1

33 1 14

44 1 1

0

+1

3 1 .1

4 1 1.E-5

9 1 -9.81E-4

16 3 3400. 200. 200.

11 1 -.2

6 1 1.E-6

5 1 0.

0

+2

1

-1 0 102.67

0

+4

2 4 5 0 0 0 0 0

0. .2

115. .427

135. .427

165. .345

195. .23

240. .287

265. .320

290. .361

315. .374

340. .308

0

+5

3 3 14 36 -1

doi:10.1371/journal.pone.0141040.g002

1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100
 101
 102
 103
 104
 105
 106
 107
 108
 109
 110
 111
 112
 113
 114
 115
 116
 117
 118
 119
 120
 121
 122
 123
 124
 125
 126
 127
 128
 129
 130
 131
 132
 133
 134
 135
 136
 137
 138
 139
 140
 141
 142
 143
 144
 145
 146
 147
 148
 149
 150
 151
 152
 153
 154
 155
 156
 157
 158
 159
 160
 161
 162
 163
 164
 165
 166
 167
 168
 169
 170
 171
 172
 173
 174
 175
 176
 177
 178
 179
 180
 181
 182
 183
 184
 185
 186
 187
 188
 189
 190
 191
 192
 193
 194
 195
 196
 197
 198
 199
 200
 201
 202
 203
 204
 205
 206
 207
 208
 209
 210
 211
 212
 213
 214
 215
 216
 217
 218
 219
 220
 221
 222
 223
 224
 225
 226
 227
 228
 229
 230
 231
 232
 233
 234
 235
 236
 237
 238
 239
 240
 241
 242
 243
 244
 245
 246
 247
 248
 249
 250
 251
 252
 253
 254
 255
 256
 257
 258
 259
 260
 261
 262
 263
 264
 265
 266
 267
 268
 269
 270
 271
 272
 273
 274
 275
 276
 277
 278
 279
 280
 281
 282
 283
 284
 285
 286
 287
 288
 289
 290
 291
 292
 293
 294
 295
 296
 297
 298
 299
 300
 301
 302
 303
 304
 305
 306
 307
 308
 309
 310
 311
 312
 313
 314
 315
 316
 317
 318
 319
 320
 321
 322
 323
 324
 325
 326
 327
 328
 329
 330
 331
 332
 333
 334
 335
 336
 337
 338
 339
 340
 341
 342
 343
 344
 345
 346
 347
 348
 349
 350
 351
 352
 353
 354
 355
 356
 357
 358
 359
 360
 361
 362
 363
 364
 365
 366
 367
 368
 369
 370
 371
 372
 373
 374
 375
 376
 377
 378
 379
 380
 381
 382
 383
 384
 385
 386
 387
 388
 389
 390
 391
 392
 393
 394
 395
 396
 397
 398
 399
 400
 401
 402
 403
 404
 405
 406
 407
 408
 409
 410
 411
 412
 413
 414
 415
 416
 417
 418
 419
 420
 421
 422
 423
 424
 425
 426
 427
 428
 429
 430
 431
 432
 433
 434
 435
 436
 437
 438
 439
 440
 441
 442
 443
 444
 445
 446
 447
 448
 449
 450
 451
 452
 453
 454
 455
 456
 457
 458
 459
 460
 461
 462
 463
 464
 465
 466
 467
 468
 469
 470
 471
 472
 473
 474
 475
 476
 477
 478
 479
 480
 481
 482
 483
 484
 485
 486
 487
 488
 489
 490
 491
 492
 493
 494
 495
 496
 497
 498
 499
 500
 501
 502
 503
 504
 505
 506
 507
 508
 509
 510
 511
 512
 513
 514
 515
 516
 517
 518
 519
 520
 521
 522
 523
 524
 525

APPENDIX B

SAMPLE NUMBERS COMPUTED FROM TEST PROBLEMS

(Note: The complete set of test problem results is on microfiche inside the back cover.)

TABLE B-1. Cylindrical draining tank.^a

Time, ms	Tank center water level height, cm
0	20.00
9	19.95
18	19.83
27	19.67
36	19.50
45	19.33
54	19.15
63	18.98
72	18.82
81	18.66
90	18.52

^aSee microfiche 1 and 2 for the complete test problem results.

TABLE B-2. Funnel-shaped draining tank.^a

Time, ms	Funnel center water height, cm
0	20.00
9	19.93
8	19.76
27	19.53
36	19.27
45	19.01
54	18.74
63	18.48
72	18.22
81	17.97
90	17.73

^aSee microfiche 3 and 4 for the complete test problem results.

TABLE B-3. Spherical bubble growth.^a

Time, ms	Radius, ^b cm
2.0	0
2.09	2.0
2.67	4.0
3.43	6.0
4.25	8.0

^aSee microfiche 5 for the complete test problem results.

^bRadius of bubble on horizontal plane as determined from void fraction.

TABLE B-4. MIT tank air-blowdown--rigid bottom.^a

Time, ms	Pressure, ^b 10 ⁻¹ bars
0	0.7190
5	0.7598
10	0.7740
15	0.8052
20	0.8926
25	1.655
30	1.893
35	1.608
40	1.417
45	1.504
50	1.478

^aSee microfiche 6 and 7 for the complete test problem results.

^bBottom center pressure-cell (1,2).

TABLE B-5. MIT tank air-blowdown--flexible bottom.^a

Time, ms	Pressure, ^b 10 ⁻¹ bars
0	0.7190
5	0.7608
10	0.7758
15	0.7835
20	0.8942
25	1.448
30	0.9525
35	1.784
37.25	0.5703

^aSee microfiche 8 and 9 for the complete test problem results.

^bBottom center pressure-cell (1,2).

TABLE B-6. LLL 1/5-scale torus calculation.^a

Time, ms	Pressure, ^b 10 ⁻¹ bars
0	2.838
40	3.152
80	3.220
120	4.081
160	4.660
200	3.658
240	3.065
280	4.010
318.1	5.214

^aSee microfiche 10, 11, and 12 for the complete test results.

^bBottom center pressure-cell (1,3).

APPENDIX C

TIMING INFORMATION

TABLE C-1. Timing information.

Test problem	Total cycles	Problem final time, ms	Computer	Computer run time, s
Cylindrical draining tank	300	90.0	Cray (LLL) CDC-7600 (LBL)	112.5 ^a 295.8 ^b
Funnel-shaped draining tank	300	90.0	Cray (LLL) CDC-7600 (LBL)	64.1 305.3
Spherical bubble	100	8.0	CDC-7600 (LLL) CDC-7600 (LBL)	40.9 75.7
MIT tank rigid bottom	1000	50.0	Cray (LLL) CDC-7600 (LBL)	222.4 882.4
MIT tank flexible bottom	745	37.25	Cray (LLL) CDC-7600 (LBL)	159.1 629.7
1/5-scale torus	3181	318.1	Cray (LLL) CDC-7600 (LBL)	511.5 2520.3

^aConvergence criteria of 1.E-7 was used on the CRAY run while the LBL CDC-7600 used a value of 1.E-6. The answers were the same except the CRAY run took more iterations.

^bAll LBL CDC-7600 times include compile and load time as well as run time. The CRAY and LLL CDC-7600 include only run time.

MISCELLANEOUS NOTES

A number of minor considerations and changes are required in order to run PELE-IC outside of the LLL computer system. They are as follows:

1. The '1' and '2' character to define the direction of the grid setup is specified instead by an 'x' or 'y' character, respectively. This is usually the third or fourth line of the input deck.
2. Each card input line must end with a \$.
3. There is no restart capability at this time.
4. The PELE-IC code is normally run in an interactive environment. When the code is initialized it requests information from the user before the problem is generated and run. Two lines of additional information must be given to the code before the problem input deck is processed. The first record must have the character 'G' in column 1. The 'G' informs the code to generate the problem. The second line should contain a dummy input file name (not used). These two records must be space delimited from the input deck by 7/8/9 control cards.

APPENDIX D

GEOMETRIC PLOTS OF TEST PROBLEMS AND MISCELLANEOUS NOTES

FIG. D-1 Cylindrical draining tank with and without grid

FIG. D-2 Draining funnel with and without grid

FIG. D-3 Spherical bubble with and without grid

FIG. D-4 MIT tank air-blowdown--rigid bottom with and without grid

FIG. D-5 MIT tank air-blowdown--flexible bottom with and without grid

FIG. D-6 LLL 1/5-scale torus with and without grid

MISCELLANEOUS NOTES

A number of minor considerations and changes are required in order to run PELE-IC outside of the LLL computer system. They are as follows:

1. The '1' and '2' character to define the direction of the grid setup is specified instead by an 'x' or 'y' character, respectively. This is usually the third or fourth line of the input deck.
2. Each card input line must end with a \$.
3. There is no restart capability at this time.
4. The PELE-IC code is normally run in an interactive environment. When the code is initialized it requests information from the user before the problem is generated and run. Two lines of additional information must be given to the code before the problem input deck is processed. The first record must have the character 'G' in column 1. The 'G' informs the code to generate the problem. The second line should contain a dummy input file name (not used). These two records must be delimited from the input deck by 7/8/9 control cards.
5. The bubble chugging model is not available in the 08/13/79 released PELE-IC version.