MFR 10769

DOE/SF/10763--

SOLAR ENERGY SYSTEMS SIMULATION
AND ANALYSIS

1st Quarterly Progress Report
Sept. 30 - Dec. 30, 1979

- Date Prepared -
January 20, 1980

FILE 8-1

Reporting Organization

1.2

Solar Thermal Program Division
Energy Laboratory
University of Houston

Submitted Through
The Energy Foundation of Texas

DOE/SF/10763--T14

DE82 005404

Author

Lorin L. Vant-Hull

Contract Number
AC03-79-SF10763

- Notice -

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use of the results of such use of any information, apparatus, product, or process disclosed in this report or represents that its use by such third party would not infringe privately owned rights.

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

[Handwritten signature]

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

PROJECT DESCRIPTION

Over the past 6 years a powerful array of computer codes have been developed at the University of Houston for Solar Central Receiver systems optimization and performance analysis. The main objective of this project is to produce User's Guides and user's versions of the NS (cellwise performance) and RC (cellwise optimization) codes. In addition, for the IH (individual heliostat layout and performance) code, a capabilities description will be written, and theory and programmer's guides for the RC code will be generated.

Modifications to the code to enhance its useability and coherence will also be made prior to archiving a set of user codes. Finally we will make certain applications of the codes to studies of special interest. A graduate student will continue work on development and verification of our insolation model.

ABSTRACT

The primary objective of this contract is to generate User's Guides for several University of Houston developed codes relating to the performance and optimization of Solar Power Tower or Solar Central Receiver systems. Although certain planned generalizations of our codes for a User's version have been delayed until the second quarter, an acceptable outline of the User's Guide has been produced, and documentation is underway.

During the second quarter a draft of this User's Guide will be prepared, the code generalizations carried to a logical conclusion and preliminary steps in documenting other components of our code library initiated.

TABLE OF CONTENTS

Title Page.....	i
Abstract.....	ii
Table of Contents.....	iii
Summary.....	1-3
Future Activities.....	4

DISTRIBUTION LIST

Large Power Systems Section
Energy Technology - Solar
DOE, Washington, D.C. 20545

Solar Energy Division; Attn Fred Corona
Department of Energy
1333 Broadway
Oakland, CA 94612

Large Power Systems Division
Sandia Laboratories (8452)
Attn: Lee Griffith
Livermore, CA 94550

SUMMARY OF ACTIVITIES

The primary goal of this contract is the preparation of User's Guides for several of our codes relating to performance (NS code) and optimization (RC code) of Solar Power Tower, or central receiver systems. During the first quarter of this contract reasonable progress was made towards this goal. For the NS performance code a topical outline has been generated and filled out with sketches, a list of definitions, etc. This outline has been discussed with and approved by the technical monitor as a viable basis for the development of a suitable User's guide. Work on preparation of the User's Guide itself is now initiated and we see no particular difficulty in delivering a first typed draft to the technical monitor for review and discussion by the end of the second quarter.

Several improvements to the NS performance code have been incorporated but several other anticipated improvements have turned out to be more troublesome than anticipated and so have been delayed until the second quarter when solid blocks of time can be devoted to them. Two improvements have been incorporated and are currently in use. The first involved modifying several computational loops and output formats so that both the insolation model and the performance code would deliver 12 monthly values rather than 7 values (monthly from solstice to solstice). Thus, values for both vernal and autumnal equinox are displayed rather than either an average or one of them. When weather effects were put in as annual average quantities (precipitable water, atmospheric turbidity and cloud cover) the single outputs were adequate but with recent modifications (last 2 years) to allow the use of monthly means rather than annual means for each of these quantities in the insolation model, this revision has become significant. The new insolation values are output as hourly values and daily integrals on typical clear days for each month. A cloud cover factor also generates the monthly average daily insolation. In development of the shading and blocking data base, the weighting factors for each instant of time are taken as the average insolation on the two symmetric days (such as the two equinoxes) each reduced by its appropriate cloud factor. In addition, the annual receiver loss (radiation and convection) is reduced by the fraction of "cloudy" days (cloud cover of eight tenths or more).

The second improvement consisted of merging into the general NS

performance code a special study of cloud effects on the receiver flux distribution. This study was carried out with SFDI funding for use in final receiver design studies for the Central Receiver Pilot Plant at Barstow. A cloud field defined by a data base can be passed over the field from any direction. As the cloud field is stepped across the heliostat field, a local atmospheric transmission factor is interpolated from the data base for each reference point in the field. The flux delivered to the receiver from each cell is modified accordingly and the total power delivered to each (of 24) receiver panels is computed. The cloud field is advanced across the field in steps; typically 50 to 100 steps of 50 meters each give a reasonable set of data for a receiver control study. Several cloud fields observed at Barstow by the Aerospace Corporation are available. As the time interval between steps is arbitrary the receiver designer can use the actual interval for the "real" cloud velocity, or can vary it to modify the cloud velocity at will. The direction of cloud motion can also be selected.

Several generalizations of the NS performance code relating to the heliostat/receiver interaction have had to be delayed. It was our original intention to prepare a single version of code equipped with switches to allow selection of each of our possible options for receiver, heliostat, image generator, and operating mode. A more careful analysis of the structure of the various codes involved has shown that the resulting code would be exceedingly cumbersome. It appears that it will be more reasonable to maintain one separate code for those image generators such as HCOFF (Hermite coefficient approximation) and FLASH (Analytic integrator with degraded sun) which generate images by evaluating the flux at each node point from an analytic function. A second code will be maintained for those image generators such as BUBBLE (a heliostat inside a plastic dome) or ROMBER (image generation by Romberg approximation integrals), both of which generate quite large 3 or 4 dimensional arrays and produce images by interpolating on these data bases. As these codes are infrequently used it does not seem wise to burden the input structure of the general code with the switches and parameter statements necessary to control these codes.

A third item we wish to generate and incorporate into our codes is the ability to generate annual average images. Assuming an approach such as has been incorporated in DELSOL can be shown to be valid, a set of loops over time are required for each representative heliostat to avoid storing an immense

amount of data. For all other purposes these time loops are outside the image generator. Thus, it appears the structure required might be exceedingly ungainly. The alternative of generating a small data base containing solar positions and intensities for all relevant times has recently been suggested as a viable alternative. Should this approach work, a simple loop over this data base within the field loops would be adequate. Further work on this has been delayed pending receipt of a revision of Dellin's paper on the approach used in DELSOL. This entire subject will be re-addressed later in the 2nd quarter of this study when a block of 4-5 weeks of time can be devoted to it without excessive external demands from other contracts .

Completion of the small effort proposed in this quarter to revise the programmers guide written last year, and to modify the RC optimization code to respond implicitly to power dependent cost components has been delayed. These tasks can also easily be accomplished in the next quarter without any impact on the balance of the work.

No work on the IH performance code was anticipated in this quarter, as is also the case for "additional studies."

The insolation modeling effort has been devoted to obtaining data sources for quantities required in our models, such as atmospheric precipitable water, atmospheric turbidity and cloud cover. The insolation model recently developed by Watt (HCP/T2552-01) has been studied and several features incorporated in our model, such as the separation of turbidity into a separate high level (a constant 0.02) and a variable low level component. Further, the plot of sunshine switch readings of percent possible sunshine (pps) versus cloud cover observation of sky cover (recorded in tenths as TSC) presented by Watt is observed to be fit very well by the function

$$\text{pps} = 100 \cos \left(\frac{\pi}{20} \cdot \text{TSC} \right)$$

Thus, pps, pps(computed), or their average can be used to modify clear day insolation values to obtain useful estimates of mean monthly insolation for optimization studies.

A comparison of our insolation model with a long term data base evaluated by Aerospace has shown very good correlation at Albuquerque. In contrast, Watt found a correction factor of 0.85 was required to achieve agreement

between his model and Albuquerque data. The reason for this difference will be investigated in the future months.

PLANNED FUTURE ACTIVITIES

1) A single receiver subroutine incorporating most of our image generating codes will be incorporated into the User's version of the NS cellwise performance code. If practical, annual average interception will also be incorporated. The bulk of documentation of this code will be completed and a draft typescript prepared for delivery to the technical monitor.

2) The programmer's guide for the RC optimization code will be revised and prepared for dissemination to those currently using the code. A first draft outline of the RC User's Guide will be submitted to the technical monitor for discussion.

3) The IH individual heliostat code will be equipped with an upgraded layout processor.

4) Watt's model for insolation will be compared to the U of H model carefully with an eye toward determining the origin of the factor of 0.85 required by Watt but apparently not required by the U of H model in matching Albuquerque data.