rec'd 3/31/89

Nitrogen Oxide Abatement by Distributed Fuel Addition

Contract DE-AC22-87PC79850

DOE/PC/79850--6

DE92 005208

Received by OSTI
DEC 30 1991

Quarterly Report No. 6

for Period

November 1, 1988 through January 31, 1989

Prepared by

J. O. L. Wendt and J. B. Mereb
Department of Chemical Engineering
University of Arizona
Tucson, Arizona 85721

Submitted to

Diane Revay Madden, Project Officer
Environmental Control Technology Division
Pittsburgh Energy Technology Center
Department of Energy

February 28, 1989

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOTED

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ABSTRACT

A screening study was performed on a laboratory scale downfired combustor to determine the effect of various variables on the effectiveness of the reburning process as a technique for NO_x abatement. The objective was to define optimum conditions under which reburning can be used and to be able to compare the reburning performance of our combustor to those reported by others. For this purpose, a statistically designed parametric investigation was conducted to determine how a set of controlled variables (primary and secondary stoichiometric ratios, location and length of the reburn zone and primary fuel load) would affect the reduction in NO emissions due to reburning. Also, the effects of other variables (NO in the primary zone, temperatures in the primary, reburn and burnout zones and the residence time in the reburn zone) were also investigated.

Three different types of reburning were investigated:

1. classical reburning, in which the primary zone was fuel lean and the reburn zone was fuel rich;
2. fuel lean reburning, in which both the primary zone and the reburn zone were fuel lean;
3. fuel rich primary zone reburning, in which both the primary zone and the reburn zone were fuel rich;

For each case, empirical correlations relating reburning effectiveness to various parameters were derived. These correlations were used to investigate the effect of each individual parameter on reburning effectiveness. An optimum reburn zone stoichiometric ratio was identified at 0.8. At this stoichiometry, a high level of NO reduction (up to 80%) can be achieved beyond which little or

no improvement could be easily achieved.

Different multistage reburning configurations were tested in which the reburn fuel was split into more than one stream in the reburn zone. No improvement in NO reduction over classical reburning was observed.

INTRODUCTION

The purpose of this research is to achieve a better understanding of the reburning process and to investigate the effect of multiple reburn fuel addition on reburning effectiveness. This requires an understanding of the individual contributions to NO abatement of each of the various variables that are associated with reburning. In order to compare our data to those of others, it is necessary to examine the effects of each variable separately. An efficient way to do this is to employ a statistically correct design of experiments, as described in a previous quarterly report.

The study was expanded to include, in addition to classical reburning, fuel lean reburning and reburning in the post flame of a rich primary zone. These processes would occur under multistaged reburning conditions. The completed screening study would provide insight into the reduction of NO that would occur at different stages of distributed reburn fuel addition. Also, additional tests were conducted in which different configurations of reburn fuel introduction into the reburn zone were compared. Those included tests in which the reburn fuel was divided into two streams and thus the effect of introducing the reburn fuel over a longer time span was investigated.

In this study, the primary fuel was Utah Bituminous coal and natural gas was used as reburn fuel. In all cases, the reburn zone was more fuel rich than the primary zone. Also, burnout air was added to produce an overall stoichiometry of 1.1, with the exception of tests in which the reburn zone was leaner than 1.1.

METHODOLOGY

As discussed in the previous report, correlations derived from the original test matrix of 44 tests (Quarterly Report no. 4), failed to predict an optimum reburn zone stoichiometry. Subsequent experiments allowed for greater variation in the reburn zone stoichiometry and less emphasis was placed on the variation in primary fuel load because of its minor significance. Furthermore, the primary zone and reburn zone stoichiometries were allowed to vary over the fuel rich region as well as the fuel lean region. Thus, both limits of reburning were expanded to include fuel lean reburning and reburning within a fuel rich primary zone. Reburning in the post flame of a fuel rich primary zone would be referred to as rich reburning.

The results of all the tests are shown in Table 1. The variables, defined in Table 2, were coded based on the low and high limits of the classical reburning tests. Thus, in classical reburning tests, a variable would vary from low to high limits denoted as -1 and +1, respectively. The same coding equations were also used for fuel lean reburning tests and rich reburning tests. In such cases, the variables could vary beyond the (-1 , +1) range.

Empirical correlations were fitted to the data using SPSS multiple regression procedure. Table 3 shows the SPSS code utilized for this purpose. Table 4 shows the final results of the analysis. Only the variables that were included by the regression are shown. Also, the method of analysis and the number of tests used are also listed. For each type of reburning, two correlations (herein denoted as Model 1 and Model 2) were produced:

1. Model 1, in terms of controlled variables: primary and secondary

stoichiometric ratios, location and length of the reburn zone and primary fuel load.

2. Model 2, in terms of primary and secondary stoichiometric ratios and two dependent variables: reburn zone residence time and temperature

For classical reburning, it was shown in a previous study (Quarterly Report No. 5) that variations in primary zone NO, and temperatures in the primary zone and the burnout zone had little statistical significance (within the range examined). Consequently, these variables were assumed to have minor contributions in the reburning process in the experimental domain that was tested here. In this study, this assumption was extended to include fuel lean reburning. In rich reburning, the number of tests (a total of 28) was not large enough to allow for a reasonable variation in the above mentioned variables. Thus, those variables were not included in the analysis.

Figure 1, showing the scatter of the predicted response for the derived correlations for each type of reburning, depicts a visual representation of how accurate these empirical models really are. Figure 2 shows the results of all the tests and where they fit in the experimental domain. The empirical correlations were then used to study the variation of reburning effectiveness with each fundamental variable.

DISCUSSION

Using the derived correlations, plots were generated to show the effect of each individual variable on reburning effectiveness. Furthermore, the results of this study were compared to those published by other researchers. This was done by focusing on the measured effects of one variable at a time, namely primary stoichiometric ratio, primary fuel (Utah Bituminous #2 coal) load, reburn zone stoichiometric ratio, primary NO level, reburn zone temperature and reburn zone residence time. Finally, the effects of mixing and the method of introducing the reburn fuel into the reburn zone were also discussed. Unless specified, the discussion below will refer to classical reburning, which constitutes the main bulk of this work.

1. Primary Stoichiometric Ratio:

A number of researchers have shown that the variation in primary stoichiometric ratio has only a small effect on reburning effectiveness with slightly better reduction in NO at lower primary stoichiometric ratios (Kelly et al., 1983, Mulholland and Hall, 1986 and Overmoe et al., 1986). Figure 3a shows a similar trend for fuel rich reburn zones (classical reburning) investigated here. That is because at the same fuel load, reducing primary stoichiometric ratio is accompanied by an increase in reburn zone residence time which is beneficial in reducing NO.

Greene et al. (1985) studied the effect of varying the primary stoichiometric ratios at constant residence times and constant primary NO levels. No significant changes in reburning effectiveness were detected. Figure 3c shows the effect of primary stoichiometric ratio at constant reburn zone temperature

and reburn zone residence time. Greater reduction in NO is observed at higher primary stoichiometric ratios, especially as the reburn zone becomes more fuel lean. A possible explanation is that as primary stoichiometric ratio is increased, the amount of reburn fuel must also be increased proportionally to maintain a constant reburn zone stoichiometric ratio. This may result in more fuel rich pockets around the reburn fuel jet. Consequently, increasing primary stoichiometric ratio may improve the reburning effectiveness especially when the reburn zone is less fuel rich, where this effect is more significant. This may also explain the increased reduction in NO at higher primary zone stoichiometric ratios in the case of fuel lean reburning as seen in Figures 3a, b and c. A similar observation was reported by Greene et al. (1985).

Furthermore, for reburning to be effective, a high degree of primary fuel burnout is necessary and enough residence time should be allowed in the primary zone (Chen et al., 1986, LaFond and Chen, 1987 and Overmoe et al., 1986). Chen et al. (1986) suggested a residence time requirement of at least 0.3 seconds in the primary zone. Otherwise, oxygen carryover into the reburn zone would result in an actual reburn zone stoichiometric ratio that is leaner than expected, which may result in less NO reduction. This effect is greater at higher levels of primary stoichiometric ratio because of shorter residence times in the primary zone. Thus, in practice, lower primary stoichiometric ratios may appear to improve reburning effectiveness. However, this is a minor factor in this study, since primary zone residence times greater than 0.25 seconds were used for all the tests and this should have allowed sufficient time for primary fuel burnout.

Figure 3X shows the effect of primary zone stoichiometric ratio in rich reburning, i.e where the reburn fuel is added in the first stage of a staged combustion process. No clear trend is obvious, considering the small number of data that was used (a total of 28) and the limited range of the experimental variables (see Figure b).

In the region where primary stoichiometric ratio has little impact on reburning effectiveness (reburn zone stoichiometric ratios less than 0.85), it would be more desirable to operate the primary zone under low excess air level. This would reduce the amount of reburn fuel required to reach the desired stoichiometric ratio in the reburn zone. On the other hand, a certain amount of oxygen in the reburn zone is necessary for the formation of hydrocarbon radicals from the reburn fuel and to promote the conversion of HCN and NH₃. A primary stoichiometric ratio of 1.1 has been recommended by LaFond and Chen (1987).

2. Primary Fuel Load

The dependence of reburning effectiveness on the primary fuel (coal) load (Figure 3d) is of minor practical significance since often it is not desirable to vary the fuel load in combustors. Varying the fuel load would affect the temperature profile and residence times. Figure 3d shows that the reburning effectiveness dependence on fuel load diminishes in the vicinity of reburn zone stoichiometric ratio of 0.8. Also, the shape of the curves raises the possibility that at higher temperatures (increased fuel load), the location of the optimum might shift to the more fuel rich region. A reburn zone stoichiometric ratio of 0.8 was identified as an optimum in this study.

3. Reburn Zone Stoichiometric Ratio

Reburn zone stoichiometric ratio is a critical parameter in reburning.

Literature data on an optimum reburn zone stoichiometry are conflicting and sometimes misleading because other significant effects, such as mixing and temperature need also be considered. Optimum reburn zone stoichiometric ratios ranging from 0.8 to 0.95 were reported in the literature. La Fond and Chen (1987) presented a discussion of the effect of variation in reburn zone stoichiometry and a review of the results of many researchers. Detailed N-species measurements at various reburn zone stoichiometric ratios (Chen et al., 1986, Greene et al., 1985 and Kolb et al., 1988) showed that an optimum would exist as a result of a tradeoff between the destruction of NO from the primary zone and the formation of HCN and NH₃ as reburn zone stoichiometric ratio decreases. The N-species that are formed in the reburn zone are partially converted to NO in the burnout zone. Other studies showed no clear optimum as the reburn zone became more fuel rich (Kelly et al., 1983, Lanier et al., 1986 and Miyamae et al., 1986). It has been suggested by LaFond and Chen (1987) that exceedingly long residence times or lower temperatures could cause a shift in the optimum reburn zone stoichiometric ratio. Results by a number of researchers suggest that a higher reburn zone temperature can produce an optimum reburning effectiveness at a more fuel rich reburn zone stoichiometric ratio (Brown and Kuby, 1986, Greene et al., 1985 and Miyamae et al., 1986). A trend of this nature was observed at greater fuel loads which were accompanied by higher temperatures (Figure 3d). The effect of temperature is discussed in a separate section.

Reburn fuel mixing with primary zone effluent is another factor which may have an effect on the optimum reburn zone stoichiometric ratio and reburning

effectiveness. Miyamae et al. (1986) suggested that this may be due to the effect of local distribution of O₂, NO and reburn fuel. Furthermore, LaFond and Chen (1987), hypothesized that improved mixing might result in sharper reburn zone stoichiometric ratio optima. In short, the method by which the reburn fuel is introduced may have an effect on the location of an optimum reburn zone stoichiometry. The effect of mixing will be discussed later.

In this study, none of the derived correlations could predict an optimum reburn zone stoichiometric ratio. Detailed experiments were performed to investigate the effect of reburn zone stoichiometric ratio on reburning effectiveness and the results are presented in Figures 4a, 4b and 4c. Figures 4b and 4c show an optimum reburn zone stoichiometric ratio at about 0.8. As reburn zone stoichiometric ratio is reduced below this value, little or no further improvement in reburning effectiveness is detected. The predicted responses (percentage in NO reduction by reburning) from model 1 and model 2 were plotted and compared to the data presented in Figures 4a, 4b and 4c and reasonable fits were obtained. The discrepancy between data and the model is due to the fact that the model results from a least squared fit through these, and other data, and does not attempt to draw a line through any specific data points. In this case, the maximum was so shallow that regression analysis did not pick it up, when all the other data are also considered. This demonstrates a weakness in statistical experimentation, and suggests that such an approach should be complemented by detailed tests in which one variable is varied at a time.

Figure 5 shows the results of a fuel lean reburning experiment. It shows that NO reductions as large as 35% can be achieved through fuel lean reburning, that

is, using secondary fuel injection without forming an overall fuel rich environment.

Figures 6a and 6b show the results of reburning in the post flame of a fuel rich primary zone, here referred to as rich reburning. Care must be taken in interpreting the results of rich reburning. That is because the primary zone contains, in addition to NO, other N-species. These N-species will be converted to either NO or N₂ upon the introduction of burnout air. In addition, some of the NO in the primary zone would decompose with time regardless of the reburn fuel or the burnout air. If the effects of air staging are ruled out, reductions of the order of 30% can be attributed to reburning action.

To summarize, reburn zone temperatures and residence times, and mixing of the reburn fuel with the effluent of the primary zone are all factors which may have an effect on the location of an optimum reburn zone stoichiometry. A value of 0.8 was found from our experiments, although this could not be predicted from empirical models that best fit the data. Significant reductions can be obtained at the extreme limits of reburning (fuel lean reburning and reburning in the post flame of a fuel rich reburn zone). In other words, reburning can be applied over a wide range of stoichiometries.

4. Primary NO Level

As discussed in the previous report, reburning effectiveness is not expected to have a significant dependence on primary NO levels greater than initial levels of 600 ppm. In this study, the effect of the primary NO level shows weak statistical significance in the tested range (900-1200 ppm) and can be neglected.

5. Reburn Zone Temperature

Reburn zone temperature is a parameter which has a significant effect on reburning effectiveness. In previous studies, reburning has been investigated within temperature ranges that are applicable to large scale boilers (1100-1400 C). In this work, reburn zone temperatures lie within a range of 1000 C to 1400 C. Figure 7a shows the predicted NO reduction at different reburn zone temperatures and residence times. The data points that are shown denote experimental results for all the tests, not those representing the lines drawn. The map of data points merely identifies the domain within which the predictive curves are based. This serves as a reminder that the predictive curves should not be used for extrapolation, but only for interpolation. At lower reburn zone temperatures, the curves are less steep which indicates that an optimum configuration can be identified at less fuel rich reburn zone stoichiometric ratios, as mentioned above.

There is a minimum reburn zone stoichiometric ratio of about 0.9 that is required for an increase in reburn zone temperature to be beneficial in increasing reburning effectiveness. (Figure 7a). This is to be expected since a higher reburn zone temperature promotes the decay of NO in the reburn zone according to the path

which is favored in a fuel rich environment (LaFond and Chen 1987). This is in agreement with the results of various studies (Brown and Kuby, 1986, Greene et al., 1985 and Miyamae et al., 1986). These studies suggest that higher reburn zone temperature would improve reburning effectiveness and might cause a shift

in the optimum reburn zone stoichiometric ratio to the more fuel rich side because of larger reductions in the total fuel nitrogen in the reburn zone (less HCN).

On the other hand, Figure 7a also shows that cooler reburn zone temperatures might be more beneficial if the reburn zone is close to being fuel lean (SR2 greater than 0.9). That is always the case for fuel lean reburning, regardless of the reburn zone residence time. Similar trends were shown by Greene et al. (1985). In short, the effect of a change in reburn zone temperature on reburning effectiveness would depend on reburn zone stoichiometric ratio and the residence time that is allowed in the reburn zone.

Figure 7b shows the predicted NO reduction at different reburn zone temperatures and residence times for the case of rich reburning. At longer reburn zone residence times, the effect of temperature is less significant, whereas, at lower reburn zone temperatures, the effect of residence time dominates.

Figure 7a is significant, since it shows that certain directional trends (with respect to reburn zone temperature, for example) depend strongly on other variables, such as reburn zone stoichiometric ratio and residence time. This complexity has made it difficult to compare results from various authors in the past, and demonstrates the need for a comprehensive study such as the one performed here.

6. Reburn Zone Residence Time

There are two residence times that are important to the reburning process: residence time in the primary zone and that in the reburn zone. The significance of the residence time in the primary zone was discussed in a previous section. Figure 8 shows the effect of reburn zone residence time at different reburn zone temperatures for all three types of reburning. In general, longer reburn zone residence time improve reburning effectiveness and the effect of residence time is significantly greater at higher reburn zone temperatures. An exception is fuel lean reburning where the trend is reversed which indicates NO formation with time. This behavior cannot be explained and requires further tests to verify. Figure 8 shows that there is a temperature dependent limiting time beyond which no further improvement in reburning effectiveness is possible. In the reburn zone, longer residence times are accompanied by greater decay of N-species before they enter the burncut zone (Lanier et al., 1986 and Miyamae et al., 1986). Furthermore, at higher primary NO levels, longer residence times may be necessary for hydrocarbon-NO interaction in the reburn zone. Therefore, as reburn zone residence time is increased, the reburning effectiveness also increases (except for fuel lean reburning). However, there exists a temperature dependent asymptotic value beyond which no increase in residence time is beneficial.

As discussed earlier, reburn zone temperature and reburn zone residence time interactions have a significant impact on reburning effectiveness. Figure 9 shows contour plots for the three types of reburning. These plots show the variation of reburning effectiveness in terms of reburn zone temperature and reburn zone residence time. The data points shown on the plots show the domain of the experimental results.

For classical reburning, the contour plots (Figure 9a) show that each level of NO reduction has a minimum residence time requirement and a minimum temperature requirement, both of which increase at higher levels of reburning effectiveness. At lower reburn zone residence time (less than 0.4 seconds), time is the dominant factor. While at higher reburn zone residence time, (greater than 0.5 seconds), temperatures become the dominant factor. Thus, the effects of reburn zone temperature and residence time are interdependent and their effects cannot be treated separately.

For fuel lean reburning, the contour plots (Figure 9b) show that lower temperatures and lower residence times are more favorable for NO reduction. As mentioned earlier, the variation of reburning effectiveness with residence time cannot be explained. Nevertheless, lower reburn zone temperatures would be more favorable for NO reduction in fuel lean reburning.

For rich reburning, the contour plots (Figure 9c) show that at high temperature, residence time is the dominant factor, while at low temperatures, temperature is the dominant factor. The latter observation is based on extrapolation since no experimental data were available below the 1400 K temperature range. It is obvious that reburn zone residence time is a more significant variable than reburn zone temperature, especially as temperature increases.

7. Mixing and Reburn Fuel Configuration

Reburn fuel mixing with primary zone effluent is another important factor in the reburning process. Several researchers suggested that improved mixing would result in increased NO reduction by reburning (Kolb et al., 1988, LaFond and

Chen, 1987, Miyamae et al., 1986 and Overmoe et al., 1986).

Overmoe et al., (1986) tested different fuel jet velocities and suggested that reburning effectiveness would increase with jet penetration and mixing. This effect became more important at higher NO_x concentrations entering the reburn zone. That would be due to increased N-species decay and faster fuel oxidation under better mixing conditions.

Greene et al. (1985) argued that improved mixing was beneficial to the reburning process because it allowed more HC/NO interaction before the reburn fuel is consumed. Consequently, less fuel rich pockets are formed in the reburn zone, less N-species and thus, less NO in the exhaust. In addition, higher temperatures were obtained because of improved fuel/oxygen contact.

Higher reburning effectiveness and a sharper dependence on reburn zone stoichiometric ratio might be achieved in small scale furnaces because of better mixing conditions. Miyamae et al. (1986) suggested that this might be due to the effect of local distribution of O₂, NO and reburn fuel. Chen et al. (1986) reported that slow mixing might shift the optimum reburn zone stoichiometry to the more fuel rich region.

In short, improved mixing may result in an improved reburning effectiveness. Since, oxygen and NO compete for CH radicals, reburn fuel distribution may result in better exposure of NO to CH radicals. In other words, injecting reburn fuel over a longer time span may slow the consumption of the fuel and increase the exposure of CH to NO. Experiments were conducted to test this hypothesis.

A set of experiments was performed in which different configurations of reburn fuel injection into the reburn zone were compared. These tests are labeled RH 1 through 18 as seen in Table 1. The results are shown graphically in Figure 10 and comparison of the results to those predicted by the empirical models are shown in Figure 11. Figure 10 shows that ^{re}dividing the reburn fuel into more than one stream resulted in no improvement in NO reduction over classical reburning with one reburn fuel stream. A possible explanation is that splitting the reburn fuel improved NO/CH interaction as well as CH/O₂ interaction. Consequently, the advantage of better NO/CH interaction is countered by increased reburn fuel consumption.

In short, multistaged reburning did not improve reburning effectiveness beyond the classical reburning level. It seems that the optimum configuration for reburn fuel introduction is a single stream injected as close to the primary flame as possible while allowing sufficient time for primary fuel burnout before entering the reburn zone.

CONCLUSIONS

A comprehensive screening study for classical reburning was performed and the effects of various variables that are associated with reburning were analyzed. Empirical models correlating reburning effectiveness with the various variables were derived. These models were used to show the effect of each individual variable on reburning effectiveness. A weak optimum was identified at a reburn zone stoichiometric ratio of 0.8 at which reburning can be performed under conditions that would minimize the contributions of primary stoichiometric ratio and primary fuel load and thus allow greater control of the reburning process. Extreme reburning conditions (fuel lean reburning and reburning in the post flame of a fuel rich primary zone) were tested and were shown to be successful in reducing NO emissions. In general, the results of this study agreed with those of other investigators.

Splitting the reburn fuel into more than one stream did not improve the reburning effectiveness over that of classical reburning. At a reburn zone stoichiometric ratio of 0.8, up to 80% of NO reduction can be achieved by classical reburning, beyond which little or no improvement was possible in this study.

REFERENCES

- Brown, R. A. and W. C. Kuby, "Application of Reburning for NO_x Control in Cogeneration", p. 26-1, Proceedings of the 1985 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-4360, January 1986.
- Chen, S. L., W. C. Clark, M. P. Heap, D. W. Pershing and W. R. Seeker, "NO_x Reduction by Reburning with Gas and Coal - Bench Scale Studies", Proceedings of the 1982 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-3182, July 1983.
- Chen, S. L., J. M. McCarthy, W. D. Clark, M. P. Heap, W. R. Seeker and D. W. Pershing, "Bench and Pilot Scale Process Evaluation of Reburning for In-Furnace NO_x Reduction", Twenty-first Symposium (International) on Combustion, p. 1159, The Combustion Institute, Pittsburgh, Pennsylvania (1986).
- Greene, S. B., S. L. Chen, W. D. Clark, M. P. Heap, D. W. Pershing and W. R. Seeker, "Bench-Scale Process Evaluation of Reburning and Sorbent Injection for In-Furnace NO_x/SO_x Reduction", U.S. EPA Report EPA-600/7-85-012, March 1985.
- Kelly, J. T., R. L. Pam and S. T. Suttman, "Fuel Staging for Pulverized Coal Furnace NO_x Control", p. 17-1, Proceedings of the 1982 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-3182, July 1983.
- Kolb, T., P. Jansohn and W. Leuckel, "Reduction of NO_x Emission in Turbulent Combustion by Fuel-Staging / Effects of Mixing and Stoichiometry in the Reduction Zone", paper presented at the Twenty-second Symposium (International) on Combustion, The Combustion Institute, Seattle, Washington (1988).
- La Fond, J. F. and S. L. Chen, "An Investigation to Define the Physical/Chemical Constraints which Limit NO_x Emission Reduction Achievable by Reburning", U.S. DOE Quarterly Report DE-AC22-86PC91025, May 1987.
- Lanier, W. S., J. A. Mulholland and J. T. Beard, "Reburning Thermal and Chemical Processes in a Two-Dimensional Pilot-Scale System", Twenty-first Symposium (International) on Combustion, p. 1171, The Combustion Institute, Pittsburgh, Pennsylvania (1986).
- Miyamae, S., H. Ikebe, K. Makino, K. Suzuki and J. Mogi, "Evaluation of In-Furnace NO_x Reduction", p. 24-1, Proceedings of the 1985 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-4360, January 1986.
- Miyamae, S., T. Kiga, H. Ikebe and K. Suzuki, "Experimental Study on NO_x Destruction Characteristics by Reburning of Pulverized Coal", paper presented at the 1986 Fall Meeting of Western State Section/ The Combustion Institute, Tucson, Arizona, October 1986.
- Mulholland, J. A. and R. E. Hall, "The Effect of Fuel Nitrogen in Reburning Application to a Firetube Package Boiler," p. 22-1, Proceedings of the 1985 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-4360, January 1986.

Overmoe, B. J., J. M. McCarthy, S. L. Chen, W. R. Seeker, G. D. Silcox and D. W. Pershing, "Pilot Scale Evaluation of NO_x Control from Pulverized Coal Combustion by Reburning", p. 21-1, Proceedings of the 1985 Joint Symposium on Stationary Combustion NO_x Control, Volume 1, EPRI Report CS-4360, January 1986.

TABLE 1

UNCODED DATA

VAR.	I N D E P E N D E N T					D E P E N D E N T			R E S P O N S E		
	X0	X1	SR1	SR2	X4	NOp	RT	TEM	NO	REDU	CTION
RUN	P O R T S					R E B . Z O N E			P E R C E N T A G E		
	DIST	WIDTH	PZ	RZ	COAL	NO, in	TIME	TEMP	IV	DV	
	RP, m	RZ, m	SRONE	SRTWO	kg/hr	ppmv	sec	DEG K	EXP.	M1	M2
---	---	---	---	---	---	---	---	---	---	---	---
RS# 0A	0.534	0.762	1.349	0.768	2.100	1206	0.251	1645	78.6	75.1	74.7
RS# 0B	0.991	0.305	1.349	0.768	2.100	1196	0.095	1581	54.4	53.7	54.0
RS# 1A	0.534	0.762	1.349	0.732	2.100	1146	0.245		79.4	78.3	
RS# 1B	0.991	0.305	1.349	0.732	2.100	1146	0.084		57.1	55.5	
RS# 2A	0.534	0.762	1.199	0.856	2.100	977	0.316	1677	64.4	64.6	63.9
RS# 2B	0.991	0.305	1.199	0.856	2.100	977	0.115	1588	36.6	43.3	42.3
RS# 3A	0.534	0.762	1.349	0.732	2.100	1098	0.249	1622	80.3	78.3	76.4
RS# 3B	0.991	0.305	1.349	0.732	2.100	1098	0.084	1562	60.6	55.5	53.8
RS# 4A	0.534	0.762	1.349	0.981	2.100	1093	0.325	1637	43.3	34.9	39.0
RS# 4B	0.991	0.305	1.349	0.981	2.100	1093	0.121	1529	30.3	21.5	23.1
RS# 6A	0.534	0.762	1.224	0.856	1.980	1101	0.343	1621	65.7	65.2	64.9
RS# 6B	0.991	0.305	1.224	0.856	1.980	1101	0.124	1539	38.5	44.4	42.7
RS# 7A	0.534	0.762	1.099	0.731	1.980	1137	0.328	1617	77.8	83.2	80.8
RS# 7B	0.991	0.305	1.099	0.731	1.980	1137	0.113	1576	56.4	55.0	57.0
RS# 8A	0.534	0.762	1.099	0.980	1.980	1025	0.430	1635	30.7	37.4	35.1
RS# 8B	0.991	0.305	1.099	0.980	1.980	1025	0.161	1550	22.4	18.6	16.8
RS# 9A	0.534	0.762	1.224	0.731	1.590	982	0.386	1534	76.2	77.5	78.4
RS# 9B	0.991	0.305	1.224	0.731	1.590	982	0.131	1491	57.1	52.0	52.9
RS#10A	0.534	0.762	1.224	0.981	1.590	989	0.489	1569	47.7	45.9	44.5
RS#10B	0.991	0.305	1.224	0.981	1.590	989	0.185	1501	31.9	29.8	25.8
RS#11A	0.534	0.762	1.224	0.856	1.590	1039	0.430	1570	66.1	68.1	68.6
RS#11B	0.991	0.305	1.224	0.856	1.590	1039	0.157	1508	43.8	47.3	45.6
RS#12A	0.534	0.762	1.224	0.981	1.554	1021	0.552	1453	43.3	46.7	49.7
RS#12B	0.991	0.305	1.224	0.981	1.554	1021	0.207	1362	33.3	30.6	32.2
RS#13A	0.534	0.762	1.224	0.856	1.554	1039	0.474	1495	67.5	68.3	68.5
RS#13B	0.991	0.305	1.224	0.856	1.554	1039	0.174	1406	44.7	47.5	44.8
RS#14A	0.534	0.762	1.349	0.856	1.554	1048	0.427	1500	62.1	67.0	69.6
RS#14B	0.991	0.305	1.349	0.856	1.554	1048	0.153	1434	43.8	48.9	46.3
RS#15A	0.534	0.762	1.099	0.856	1.554	956	0.521	1505	73.1	69.7	67.3
RS#15B	0.991	0.305	1.099	0.856	1.554	956	0.191	1458	36.1	46.2	44.9
RS#16A	0.534	0.762	1.349	0.732	1.074	971	0.567	1411	65.7	70.8	75.7
RS#16B	0.991	0.305	1.349	0.732	1.074	971	0.196	1319	49.5	48.1	46.5
RS#17A	0.534	0.762	1.349	0.981	1.074	1011	0.736	1427	62.8	57.4	55.7
RS#17B	0.991	0.305	1.349	0.981	1.074	1011	0.277	1327	42.2	44.1	44.8
RS#18A	0.534	0.762	1.349	0.732	1.164	1072	0.519	1425	69.7	71.5	75.8
RS#18B	0.991	0.305	1.349	0.732	1.164	1072	0.180	1345	55.1	48.7	47.0
RS#19A	0.534	0.762	1.349	0.981	1.164	1108	0.681	1429	55.4	55.5	56.4
RS#19B	0.991	0.305	1.349	0.981	1.164	1108	0.254	1338	49.4	42.1	42.5
RS#20A	0.534	0.762	1.224	0.856	1.164	1099	0.652	1443	73.5	71.2	70.3
RS#20B	0.991	0.305	1.224	0.856	1.164	1099	0.239	1337	48.5	50.4	49.3
RS#21A	0.534	0.762	1.099	0.731	1.170	1006	0.631	1439	69.6	77.3	77.1

RS#21B	0.991	0.305	1.099	0.731	1.170	1006	0.224	1335	58.5	49.1	49.0
RS#22A	0.534	0.762	1.099	0.980	1.170	1001	0.848	1435	45.3	55.1	41.3
RS#22B	0.991	0.305	1.099	0.980	1.170	1001	0.329	1313	40.5	36.3	38.8
MR# 9	0.534	0.762	1.194	0.815	1.437	1035	0.485		74.1	73.4	
MR#10	0.686	0.610	1.194	0.815	1.437	1035	0.384		70.3	65.7	
MR#11	0.991	0.305	1.194	0.815	1.437	1035	0.174		46.8	50.4	
MR#12	0.534	0.762	1.194	1.050	1.449	1115	0.676	1442	24.7	33.0	29.2
MR#13	0.991	0.305	1.194	1.050	1.449	1115	0.286	1271	40.2	32.5	33.1
MR#14	0.991	0.305	1.194	1.000	1.449	1133	0.269		17.0	34.3	
MR#15	0.534	0.762	1.194	0.951	1.449	1129	0.595	1457	57.4	55.0	55.0
MR#16	0.991	0.305	1.194	0.951	1.449	1129	0.232	1299	35.2	37.2	39.1
MR#17	0.534	0.762	1.194	0.901	1.449	1126	0.554	1488	66.4	63.5	63.1
MR#18	0.991	0.305	1.194	0.901	1.449	1126	0.213	1357	40.4	43.8	42.6
MR#19	0.534	0.762	1.194	0.851	1.449	1111	0.514		71.5	70.0	
MR#20	0.991	0.305	1.194	0.851	1.449	1111	0.192	1381	42.4	48.3	45.7
MR#21	0.534	0.762	1.194	0.811	1.449	1123	0.492	1498	75.4	73.7	74.0
MR#22	0.686	0.610	1.194	0.811	1.449	1123	0.389	1475	68.4	66.0	68.3
MR#23	0.991	0.305	1.194	0.811	1.449	1123	0.179	1382	48.1	50.5	47.1
MR#27	0.534	0.762	1.194	0.811	1.437	1192	0.542	1524	73.5	73.7	76.6
MR#28	0.534	0.457	1.194	0.811	1.437	1141	0.316		59.9	58.2	
MR#29	0.686	0.610	1.194	0.811	1.437	1192	0.420	1495	71.7	66.0	70.9
MR#30	0.991	0.305	1.194	0.811	1.437	1215	0.183	1443	47.5	50.6	50.3
UB#3A	0.534	0.457	1.099	0.902	0.978	913	0.605	1411	57.9	55.4	60.4
RV# 1	0.991	0.305	1.069	0.998	1.948	984	0.193	1444	17.4	19.0	30.5
RV# 2	0.991	0.305	1.069	0.948	1.948	984	0.176	1454	23.7	26.1	26.9
RV# 3	0.534	0.762	1.069	0.948	1.948	984	0.460	1580	35.9	46.7	45.6
RV# 4	0.534	0.457	1.069	0.948	1.948	984	0.283	1588	32.2	32.9	34.7
RV# 5	0.686	0.305	1.069	0.948	1.948	984	0.189	1523	32.2	26.1	27.1
RV# 6	0.686	0.610	1.069	0.948	1.948	984	0.368	1549	37.1	39.9	41.4
RV# 7	0.686	0.610	1.069	0.899	1.948	944	0.342	1561	52.3	51.0	51.0
RV# 8	0.534	0.762	1.069	0.899	1.948	944	0.431	1589	56.4	58.4	56.3
RV# 9	0.991	0.305	1.069	0.899	1.948	944	0.161	1487	31.7	35.9	34.6
RV#10	0.686	0.610	1.069	0.716	1.948	923	0.274	1546	74.1	75.0	71.8
RV#11	0.991	0.305	1.069	0.716	1.948	923	0.121	1517	50.9	55.4	54.0
RV#12	0.534	0.762	1.069	0.716	1.948	923	0.350	1576	77.5	84.8	80.1
RV#13	0.991	0.305	1.069	0.750	1.948	980	0.126	1520	54.6	53.9	52.2
RV#14	0.534	0.762	1.069	0.750	1.948	980	0.356	1577	80.4	82.0	77.1
RV#15	0.686	0.610	1.069	0.750	1.948	980	0.284	1549	74.2	72.6	69.9
RV#16	0.686	0.610	1.069	0.809	1.948	933	0.298	1573	74.0	66.2	64.8
RV#17	0.991	0.305	1.069	0.809	1.948	933	0.135	1542	48.1	48.9	47.8
RV#18	0.534	0.762	1.069	0.809	1.948	933	0.373	1569	79.4	74.8	69.8
RV#19	0.534	0.457	1.069	0.809	1.948	933	0.243	1619	69.5	57.6	62.4
RV#20	0.534	0.152	1.069	0.809	1.948	933	0.087	1608	32.9	40.3	45.2
RA# 1	0.991	0.610	1.324	1.250	1.800	1045	0.358	1492	0.0	0.6	2.3
RA# 2	0.991	0.610	1.324	1.200	1.800	1045	0.352	1508	6.32	10.1	8.7
RA# 3	0.686	0.915	1.324	1.200	1.800	1043	0.532	1563	0.35	0.0	0.0
RA# 4	0.534	1.067	1.324	1.200	1.800	1045	0.631	1570	1.7	0.0	0.0
RA# 5	0.534	1.067	1.324	1.150	1.800	1012	0.621	1595	8.6	5.5	7.6
RA# 6	0.686	0.915	1.324	1.150	1.800	1012	0.521	1579	6.5	9.6	9.8
RA# 7	0.991	0.610	1.324	1.150	1.800	1012	0.340	1536	18.3	17.9	14.5
RA# 8	0.991	0.610	1.324	1.100	1.800	1012	0.332	1566	26.8	24.1	20.4
RA# 9	0.534	1.067	1.324	1.100	1.800	1012	0.605	1620	15.2	18.1	19.0
RA#16	0.686	0.915	1.324	1.100	1.800	1012	0.518	1532	17.6	20.1	21.8
RA#17	0.686	0.610	1.324	1.100	1.800	1012	0.348	1552	14.2	20.1	21.1

RA#18	0.686	0.305	1.324	1.100	1.800	1012	0.175	1552	11.2	20.1	20.5
RA#20	0.991	0.305	1.324	1.071	1.800	1034	0.166	1476	27.9	26.9	26.1
RA#21	0.686	0.610	1.324	1.071	1.800	1034	0.332	1572	35.4	25.4	24.5
RA#22	0.534	0.762	1.324	1.071	1.800	1034	0.423	1591	25.8	24.7	25.0
RA#24	0.991	0.305	1.324	0.985	1.800	1006	0.151	1500	22.1	26.7	25.5
RA#26	0.686	0.610	1.324	0.985	1.800	1006	0.314	1562	30.2	35.9	38.5
RA#27	0.534	0.762	1.324	0.985	1.800	1006	0.399	1583	36.7	40.5	43.3
RB#1	0.686	0.610	1.093	1.054	1.824	894	0.422	1542	5.25	15.9	17.9
RB#2	0.686	0.610	1.093	1.004	1.824	894	0.399	1547	25.4	26.3	29.2
RB#3	0.686	0.610	1.093	0.951	1.824	894	0.366	1592	36.9	41.6	40.7
RB#4	0.686	0.610	1.093	0.901	1.824	894	0.343	1602	58.7	52.1	51.6
RB#5	0.686	0.610	1.093	0.865	1.824	894	0.327	1590	65.1	58.5	58.1
RB#6	0.686	0.610	1.093	0.801	1.824	894	0.307	1595	68.8	67.1	68.3
RB#7	0.686	0.610	1.093	0.751	1.824	894	0.287	1603	65.0	71.6	74.2
RC#1	0.534	0.762	1.117	1.047	1.732	985	0.543	1575	22.0	21.6	19.4
RC#2	0.686	0.610	1.117	1.047	1.732	985	0.421	1570	18.3	21.3	19.8
RC#3	0.991	0.305	1.117	1.047	1.732	987	0.208	1498	31.0	20.7	22.7
RC#4	0.991	0.305	1.117	1.009	1.732	988	0.196	1509	38.9	24.5	27.8
RC#5	0.686	0.610	1.117	1.009	1.732	975	0.403	1575	34.8	28.4	28.3
RC#6	0.686	0.305	1.117	1.009	1.732	987	0.205	1550	29.5	28.4	26.7
RC#7	0.534	0.457	1.117	1.009	1.732	987	0.307	1623	32.6	30.3	25.8
RC#8	0.534	0.762	1.117	1.009	1.732	987	0.512	1627	34.9	30.3	28.0
RD#1	0.534	1.067	1.184	1.095	1.737	1026	0.721	1608	7.63	13.0	7.94
RD#4	0.686	0.610	1.184	1.095	1.737	1026	0.605		7.69	14.8	
RE# 1	0.991	0.305	0.872	0.830	1.902	569	0.201	1405	52.6	49.8	51.0
RE# 2	0.686	0.610	0.872	0.830	1.902	569	0.406	1504	57.6	54.7	59.8
RE# 3	0.534	0.762	0.872	0.830	1.902	569	0.514	1535	58.6	57.1	60.3
RE# 4	0.534	0.457	0.872	0.830	1.902	569	0.327	1538	55.5	57.1	52.2
RE# 5	0.534	0.457	0.872	0.800	1.902	585	0.315	1540	55.3	58.7	55.2
RE# 6	0.534	0.762	0.872	0.800	1.902	585	0.492	1539	62.4	58.7	62.2
RE# 7	0.686	0.610	0.872	0.800	1.902	600	0.393	1504	60.4	56.3	62.7
RE# 8	0.686	0.305	0.872	0.800	1.902	600	0.211	1519	55.4	56.3	51.8
RE# 9	0.991	0.305	0.872	0.800	1.902	568	0.187	1463	51.9	51.5	51.8
RE#10	0.991	0.305	0.872	0.750	1.902	568	0.176		54.5	54.1	
RE#11	0.686	0.610	0.872	0.750	1.902	568	0.372		61.2	59.0	
RE#12	0.534	0.762	0.872	0.750	1.902	568	0.466		60.1	61.4	
RF# 1	0.991	0.305	0.947	0.850	1.890	552	0.181	1486	38.5	45.1	40.9
RF# 2	0.686	0.610	0.947	0.850	1.890	551	0.381	1515	59.4	56.0	55.7
RF# 3	0.534	0.762	0.947	0.850	1.890	551	0.477	1552	60.5	61.4	60.9
RF# 4	0.534	0.762	0.947	0.801	1.890	592	0.445	1555	64.4	63.5	64.7
RF# 5	0.534	0.457	0.947	0.801	1.890	592	0.290	1549	63.2	63.5	59.2
RF# 6	0.686	0.305	0.947	0.801	1.890	592	0.193	1528	54.6	58.0	52.8
RF# 7	0.686	0.610	0.947	0.801	1.890	592	0.351	1544	60.0	58.0	61.0
RF# 8	0.991	0.305	0.947	0.801	1.890	566	0.166	1525	43.4	47.1	51.1
RF# 9	0.991	0.305	0.947	0.750	1.890	598	0.153	1534	49.9	49.3	49.9
RF#10	0.686	0.610	0.947	0.750	1.890	598	0.325	1554	60.2	60.2	58.7
RF#11	0.534	0.762	0.947	0.750	1.890	598	0.411	1574	61.2	65.6	62.3
RG#1	0.991	0.305	0.992	0.815	1.824	707	0.167	1523	50.8	48.3	51.3
RG#2	0.686	0.610	0.992	0.815	1.824	727	0.349	1538	63.4	62.8	62.6
RG#3	0.686	0.305	0.992	0.815	1.824	717	0.189	1572	62.9	62.8	64.8
RG#4	0.534	0.762	0.992	0.815	1.824	717	0.430	1571	68.4	70.0	70.2
RG#5	0.534	0.457	0.992	0.815	1.824	717	0.281	1575	70.3	70.0	67.5
RH# 1	0.991	0.305	1.099	0.851	1.782	963	0.155	1574	43.2	45.1	45.0
RH# 2	0.686	0.610	1.099	0.851	1.782	937	0.326	1595	69.0	60.9	61.1

RH# 3	0.534	0.762	1.099	0.851	1.782	937	0.411	1606	75.6	68.8	66.6
RH# 4	0.534	0.762	1.099	0.801	1.782	994	0.386	1608	76.3	75.6	74.3
RH# 5	0.686	0.610	1.099	0.801	1.782	994	0.307	1597	74.1	67.1	68.5
RH# 6	0.991	0.305	1.099	0.801	1.782	1000	0.143	1583	44.7	50.1	52.4
RH# 7	0.991	0.305	1.099	0.751	1.782	1011	0.133	1597	53.5	53.0	58.9
RH# 8	0.686	0.610	1.099	0.751	1.782	932	0.290	1591	71.5	71.3	73.6
RH# 9	0.534	0.762	1.099	0.751	1.782	932	0.368	1605	75.7	80.4	80.1

MULTI-STAGE (2) REBURNING

RH#12A	PORTS 3 & 4	1.099	0.959	1.782	1011	0.094	1569	76.1	71.5	62.4
RH#13A		1.099	0.927	1.782	1006	0.092	1573	75.8	74.8	66.9
RH#18A		1.099	0.892	1.782	1002	0.089	1564	71.0	78.1	67.7
RH#11A	PORTS 3 & 5	1.099	0.959	1.782	1011	0.263	1590	63.5	68.4	66.1
RH#15A		1.099	0.927	1.782	1006	0.252	1587	64.1	74.0	71.3
RH#16A		1.099	0.892	1.782	1002	0.242	1588	68.8	79.4	72.5
RH#10A	PORTS 4 & 5	1.099	0.959	1.782	1011	0.175	1572	63.4	65.2	62.2
RH#14A		1.099	0.927	1.782	1006	0.169	1569	64.5	71.0	67.6
RH#17A		1.099	0.892	1.782	1002	0.162	1570	64.7	76.5	68.6

TABLE 2

VARIABLES

Controlled Variables

1. location of reburn fuel injection, distance from burner in meters
2. length of reburn zone in meters
3. primary zone stoichiometric ratio
4. reburn zone stoichiometric ratio
5. primary fuel load (Utah Bituminous #2 coal) in kg/hr

<u>Variable</u>	<u>Code</u>	<u>Low Limit</u>	<u>High Limit</u>	<u>Coding Equation</u>
1	X0	0.991 (P5)	0.534 (P3)	$X0 = (0.7625 - \text{var}) / 0.2285$
2	X1	0.305 (P5)	0.762 (P3)	$X1 = (\text{var} - 0.5335) / 0.2285$
3	SR1	0.87	1.35	$SR1 = (\text{var} - 1.225) / 0.125$
4	SR2	0.72	1.2	$SR2 = (\text{var} - 0.855) / 0.125$
5	X4	1.07	2.1	$X4 = (\text{var} - 1.5876) / 0.4536$

Uncontrolled Variables

1. NO in primary zone (dry, corrected) in ppmv
2. residence time in the reburn zone in seconds
3. temperature in the reburn zone in degrees Kelvin

<u>Variable</u>	<u>Code</u>	<u>Low Limit</u>	<u>High Limit</u>	<u>Coding Equation</u>
1	NO _p	900	1200	$NO_p = (\text{var} - 1050) / 150$
2	RT	0.1	0.7	$RT = (\text{var} - 0.4) / 0.3$
3	TEM	1350	1650	$TEM = (\text{var} - 1500) / 150$

Y = reburning effectiveness

= response as percentage of NO reduced due to reburning:

$$Y = 100 - 100 * (NO_{ex} / NO_p)$$

NO_{ex} = ppmv NO (dry, corrected) in exhaust

NO_p = ppmv NO (dry, corrected) in primary zone
before reburn fuel introduction

NO corrected = NO measured * $\frac{\text{actual moles/h flue gas at measured point}}{\text{moles/h flue gas for coal only at SR1=1}}$

TABLE 3

SPSS MULTIPLE REGRESSION CODE

```

FILE HANDLE FEB/NAME='FEB.DAT'
DATA LIST FILE=FEB/RUN 5-10(A) DIST 13-17(3) WIDTH 19-23(3)
SRONE 25-29(3) SRTWO 31-35(3) COAL 37-41(3) NOIN 44-47
TIME 49-53(3) TEMP 55-58 Y 61-65(2)

COMPUTE X0=(0.7625-DIST)/0.2285
COMPUTE X1=(WIDTH-0.5335)/0.2285
COMPUTE SR1=(SRONE-1.225)/0.125
COMPUTE SR2=(SRTWO-0.855)/0.125
COMPUTE X4=(COAL-1.5876)/0.4536
COMPUTE NOp=(NOIN-1050.0)/150.0
COMPUTE RT=(TIME-0.4)/0.3
COMPUTE TEM=(TEMP-1500.0)/150.0

COMPUTE X0X1=X0*X1
COMPUTE X0SR1=X0*SR1
COMPUTE X0SR2=X0*SR2
COMPUTE X0X4=X0*X4
COMPUTE X1SR1=X1*SR1
COMPUTE X1SR2=X1*SR2
COMPUTE X1X4=X1*X4
COMPUTE SR1SR1=SR1*SR1
COMPUTE SR1SR2=SR1*SR2
COMPUTE SR1X4=SR1*X4
COMPUTE SR1NOp=SR1*NOp
COMPUTE SR1RT=SR1*RT
COMPUTE SR1TEM=SR1*TEM
COMPUTE SR2SR2=SR2*SR2
COMPUTE SR23=SR2*SR2*SR2
COMPUTE SR2X4=SR2*X4
COMPUTE SR2NOp=SR2*NOp
COMPUTE SR2RT=SR2*RT
COMPUTE SR2TEM=SR2*TEM
COMPUTE X4X4=X4*X4
COMPUTE NOpNOp=NOp*NOp
COMPUTE NOpRT=NOp*RT
COMPUTE NOpTEM=NOp*TEM
COMPUTE RTRT=RT*RT
COMPUTE RTTEM=RT*TEM
COMPUTE TEMTEM=TEM*TEM
LIST VARIABLES=RUN DIST WIDTH SRONE SRTWO COAL NOIN TIME TEMP Y
LIST VARIABLES=RUN X0 X1 SR1 SR2 X4 NOp RT TEM Y

```

```
REGRESSION SELECT SRONE LT 1.0
/VARIABLES=X0 X1 SR1 SR2 X4 Y
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
X4X4 SR1SR1 SR2SR2
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=STEPWISE X0 X1 SR1 SR2 X4
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
X4X4 SR1SR1 SR2SR2
  REGRESSION SELECT SRONE LT 1.0
/VARIABLES=Y SR1 SR2 RT TEM
SR1SR1 SR2SR2
SR1SR2 SR1RT SR1TEM
SR2RT SR2TEM RTTEM
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=BACKWARD SR1 SR2 RT TEM
SR1SR1 SR2SR2
SR1SR2 SR1RT SR1TEM
SR2RT SR2TEM RTTEM
```

SELECT IF SRONE GT 1.0

REGRESSION SELECT SRTWO GT 0.97
/VARIABLES=X0 X1 SR1 SR2 X4 Y
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
SR1SR1 SR2SR2 X4X4
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=BACKWARD X0 X1 SR1 SR2 X4
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
SR1SR1 SR2SR2 X4X4
REGRESSION SELECT SRTWO GT 0.97
/VARIABLES=Y SR1 SR2 RT TEM
SR1SR1 SR2SR2
SR1SR2 SR1RT SR1TEM
SR2RT SR2TEM RTTEM
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=STEPWISE SR1 SR2 RT TEM
SR1SR1 SR2SR2
SR1SR2 SR1RT SR1TEM
SR2RT SR2TEM RTTEM

REGRESSION SELECT SRTWO LT 1.0
/VARIABLES=X0 X1 SR1 SR2 X4 Y
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
SR1SR1 SR2SR2 X4X4
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=STEPWISE X0 X1 SR1 SR2 X4
XOX1 XOSR1 XOSR2 XOX4
X1SR1 X1SR2 X1X4 SR1SR2 SR1X4 SR2X4
SR1SR1 SR2SR2 X4X4
REGRESSION SELECT SRTWO LT 1.0
/VARIABLES=Y SR1 SR2 NOp RT TEM
SR1SR1 SR2SR2 NOpNOp RTRT TEMTEM
SR1SR2 SR1NOp SR1RT SR1TEM
SR2NOp SR2RT SR2TEM
NOpRT NOpTEM RTTEM
/CRITERIA=PIN(0.0499) POUT(0.05)
/STATISTICS=DEFAULTS CI F
/DEPENDENT=Y
/METHOD=STEPWISE SR1 SR2 NOp RT TEM
SR1SR1 SR2SR2 NOpNOp RTRT TEMTEM
SR1SR2 SR1NOp SR1RT SR1TEM
SR2NOp SR2RT SR2TEM
NOpRT NOpTEM RTTEM

TABLE 4

CORRELATION COEFFICIENTS

SR1>1, SR2<1 CLASSICAL REBURNING

MODEL 1

R Square=0.918 :STEPWISE METHOD (0.05), 98 DATA POINTS

SR2 -13.286

X1 10.396

SR2*X4 -6.662

SR2*SR2 -6.384

X4 -3.261

X1*SR2 -2.356

X1*SR1 -1.355

SR1*SR2 1.554

(Constant) 57.837

MODEL 2

R Square=0.907 :STEPWISE METHOD (0.05), 91 DATA POINTS

SR2 -16.754

RT 16.280

RT*RT -10.126

SR2*TEM -8.461

TEM 3.979

SR1 2.988

SR2*SR2 -5.729

SR1*SR2 2.244

(Constant) 65.454

SR2>1 FUEL LEAN REBURNING

MODEL 1

R Square=0.833 :BACKWARD METHOD (0.05), 48 DATA POINTS

SR1*SR2 3.964

X0 12.916

SR2*SR2 -5.242

X0*SR2 -8.118

SR2*X4 -8.607

(Constant) 43.019

MODEL 2

R Square=0.845 :STEPWISE METHOD (0.05), 46 DATA POINTS

SR2 -23.187

SR1*SR2 3.908

SR2*TEM -3.516

RT 22.940

SR2*RT -12.855

SR1*RT 4.304

(Constant) 63.156

SR1<1 REBURNING IN THE POST FLAME OF A FUEL
RICH PRIMARY ZONE (RICH REBURNING)

MODEL 1

R Square=0.854 :STEPWISE METHOD (0.05), 28 DATA POINTS

X0 24.915

X0*SR1 7.531

X4 -32.464

SR1*SR2 2.373

(Constant) 74.700

MODEL 2

R Square=0.874 :BACKWARD METHOD (0.05), 25 DATA POINTS

RT*TEM -22.345

SR1*SR2 10.247

SR1*TEM 43.142

SR2*SR2 -22.063

RT 17.653

TEM 102.725

(Constant) 55.148

FIGURE 1. Prediction of NO Reduction

a)

b)

FIGURE 2. Domain of the Experimental Data

FIGURE 3. Effects of Primary Fuel Load and Primary Stoichiometric Ratio on NO Reduction by Reburning

RICH REBURNING
SR1 smaller than 1.0

FIGURE 3X: Effects of Primary Stoichiometric Ratio on NO Reduction by Reburning

FIGURE 4a. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run MR

FIGURE 4b. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run RV

NO REDUCTION BY REBURNING

SR1=1.09, 1.824 kg/hr UTAH BITUMINOUS #2

FIGURE 4c. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run RB

FUEL LEAN REBURNING

SR1=1.324, 1.8 kg/hr UTAH BITUMINOUS #2

FIGURE 5. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run RA

RICH REBURNING

FIGURE 6a. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run RE

RICH REBURNING

FIGURE 6b. Variation of NO Reduction with Reburn Zone Stoichiometric Ratio - Run RF

SR1 greater than 1.0

FIGURE 7 a. Predicted NO Reduction at Different Reburn Zone Temperatures and Residence Times

RICH REBURNING

SR1 smaller than 1.0

FIGURE 7b. Predicted NO Reduction at Different Reburn Zone Temperatures and Residence Times

a)

b)

c)

FIGURE 8. Effect of Reburn Zone Residence Time on NO Reduction

CONTOUR PLOTS FOR % NO REDUCTION

a)

b)

c)

FIGURE 9. Contour Plots for NO Reduction in Terms of Reburn Zone Temperature and Residence Time

REBURNING: MODE OF INJECTION

SR1=1.1, 1.782 kg/hr UTAH BITUMINOUS #2

FIGURE 10. Mode of Injection of Reburn Fuel

FIGURE 11. Comparing Predicted and Measured Reductions in NO at Different Reburn Fuel Injection Modes

END

DATE
FILMED
2/07/92

I