CONF-850310--64

Paper presented at the 6th Topical Meeting on the Technology of Fusion Energy, San Francisco, CA, March 3-7, 1985; also for publication in Fusion Technology.

M85010503

CONF-850310--64

DE85 010503

TFCX SHIELDING OPTIMIZATION*

S. Yang and Y. Gohar

Fusion Power Program
Argonne National Laboratory
Argonne, IL 60439

The submitted manuscript has been authored by a contractor of the U. S. Government under contract No. W-31-109-ENG-38. Accordingly, the U. S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or allow others to do so, for U. S. Government purposes.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

---

* Work supported by the U.S. Department of Energy.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JH

TFCX SHIELDING OPTIMIZATION

S. Yang and Y. Gohar
Fusion Power Program, Argonne National Laboratory
9700 South Cass Avenue, Argonne, IL 60439 U.S.A.
(312) 972-4816

ABSTRACT

Design analyses and tradeoff studies for the bulk shield of the Tokamak Fusion Core Experiment (TFCX) were performed. Several shielding options were considered to lower the capital cost of the shielding system. Optimization analyses were carried out to reduce the nuclear responses in the TF coils and the dose equivalent in the reactor hall one day after shutdown. Two TFCX designs with different toroidal field (TF) coil configurations were considered during this work. The materials for the shield were selected based upon tradeoff studies and the results from the previous design studies. The main shielding materials are water, concrete, and steel balls (Fe1422 or Nitronic 33). Small amounts of boron carbide and lead are employed to reduce activation, nuclear heating in the TF coils, and dose equivalent after shutdown.

I. INTRODUCTION

Design analyses and tradeoff studies for TFCX bulk shield are presented in this paper. Several shielding options were analyzed to lower the capital cost of the shielding system. Also, optimization analyses were performed for each option to reduce the nuclear heating in the TF coils and dose equivalent in the reactor hall one day after shutdown. This study was performed for two TFCX designs with different toroidal field coil configurations. The first design has superconductor coils to provide the required field-on-axis, designated superconducting design. The second design utilizes superconductor coils and normal copper insert coils located in the shield to produce the required field, designated hybrid design.

The bulk shield system for both configurations was designed to reduce the radiation leakage from the outer shield surface to an acceptable level. This reduction ensures that a) the different reactor components are protected from radiation damage and excessive nuclear heating, b) the neutron reaction rates in the reactor components outside the shield

system are reduced to avoid high biological dose in the reactor hall after shutdown, and c) the workers and the public are protected from radiation exposure. Also, the bulk shield attenuates the decay gamma rays in the reactor hall to permit personnel access one day after shutdown with all shields in place. This access reduces the reactor downtime and the capital cost of the remote equipment required for maintenance. Also, it is a design criterion for TFCX.¹

The shielding materials were selected based upon tradeoff studies and the results from the previous design studies.^{2,3} Cost, resource, and performance were considered in the selection process. The main shielding materials are water, concrete, and steel balls with low nickel concentration (Fe1422 or Nitronic 33). A small amount of boron carbide with low density is used as a neutron absorber to reduce the activation and nuclear heating in the reactor components. Also, a thin lead layer is used as a gamma ray attenuator at the outermost shield surface to reduce the biological dose in the reactor building and the gamma heating in the reactor components. The low nickel concentration in Fe1422 and Nitronic-33 steel alloys reduces the production of long-lived isotopes, the biological dose after shutdown in the reactor hall, and the steel cost.⁴ A description of the shielding system including the design methodology, as well as analyses and tradeoff studies for each shielding component are presented.

II. DESIGN METHODOLOGY

The TFCX coils were designed to last the lifetime of the reactor without change in their performance. Therefore, the shielding system must provide adequate protection for the different coil components from radiation damage and excessive nuclear heating.

For TFCX, the nuclear heating in the superconductor coils is the dominant design criterion for the inboard shield because of the low D-T neutron fluence. This nuclear heating impacts the refrigeration power

required since about 500 watts of electrical power are consumed to remove one watt from the coils at 4°K. This removal efficiency calls for minimizing the nuclear energy deposition in the coils. Two values for the maximum nuclear heating in the TF coil winding, 0.3 and 1.0 mW/cm³, were considered during the TFCX design process to assure cryogenic stability and design simplicity for these coils.¹

The personnel access to the reactor hall within one day after shutdown requires the satisfaction of regulations pertaining to occupational exposure. The regulations^{5,6} limit the occupational dose to 5 rem/y with a maximum of 3 rem/quarter. Occupational exposure based on working 8 h per day and 40 h per week is 2.5 mrem/h. However, the current practice in the nuclear industry, the exposure policy of the Department of Energy (DOE), and the national laboratories regulations are to reduce radiation exposures as low as reasonably achievable (ALARA). Specifically for facilities being designed, DOE-5480.1 limits onsite workers to less than 1 rem/y (0.5 mrem/h) as a design objective.

Each shielding material has certain physical constraints that must be taken into consideration during the design process. For example, water shielding material requires careful design for the shield system (pipelines, pumps, manifolds, etc.) so that the formation of gas pockets from radiolysis is not possible. In addition, special attention must be given to the PH-value and corrosion products during operation. Concrete shield requires protective measures to avoid change in the performance over the lifetime of the reactor. The following design recommendations⁵ adequately protect concrete against loss of water, temperature effects, radiation absorption effects, and stress conditions: a) maximum heat deposition, 1 mW/cm³, b) maximum temperature gradient, 1°C/cm, c) maximum internal temperature, 80°C, and d) maximum ambient temperature, 71°C. The temperature limitations may be achieved, if it is required, by lining the concrete with a steel jacket and adequately ventilating the shield or cooling the jacket to be independent from the ventilation system for removing the nuclear heat load.

The transport calculations were performed using the discrete ordinate code ANISN⁷ with S₈ symmetric angular quadrature set and P₃ legendre expansion for the scattering cross sections. A 67-multigroup cross section set (46-neutrons and 21-photons) collapsed from the CTR library⁸ was used for ANISN calculations. The MACKLIB⁹ was employed to calculate the nuclear response functions (nuclear heating, radiation damage, gas production, etc.). For radioactivity and dose equivalent after shutdown, the calculations follow the

ANISN-RACC¹⁰-ANISN path. The ANISN code was first used to obtain the steady state neutron fluxes in each interval of the geometry. These fluxes, after normalization for the proper wall loading, were used by the RACC code to generate the decay gamma source distributions for various operating and decay times. Decay gamma transport calculations were then performed with the ANISN code to obtain the dose equivalent for specific operating and decay time intervals.

III. INBOARD SHIELD FOR THE HYBRID DESIGN

For the hybrid design, a parametric study was performed for the inboard shield of TFCX. The thicknesses, the compositions, and the geometry model used in the analysis are listed in Table 1. The total thickness of the inboard shield (t), thickness of the boron carbide zone (x), thickness of the lead zone (y), and water concentration in the steel zone (z) were varied in this study. The main objective of this study is to determine the best combination of values for x, y, and z such that the maximum and the total nuclear heating in the inboard portion of the TF coils are minimum for different t values. Other important design criteria, such as maximum doses in the insulator material and the maximum fast neutron fluences in the superconducting material will not be the contrasting requirements in this study because of the short operating time of 2×10^5 seconds. A small sample of the results will be given here due to the limitation on the paper length. For example, Table 2 gives the maximum nuclear heating in the TF coil winding as a function of the total shield thickness with three lead zone thicknesses of 0, 1, and 2 cm. The boron carbide zone thickness is 3 cm and the water concentration in the steel shield is 10% by volume. The results show that for fixed values of x, y, and z, the maximum nuclear heating in the TF coil winding reduces by about a factor of two every 5 cm of the shield thickness in the steel zone.

Figure 1 gives the maximum nuclear heating in the TF coil winding as a function of the water fraction in the steel shield with the lead zone thicknesses of 0, 1, and 2 cm. The boron carbide zone thickness is 3 cm and the total shield thickness is 70 cm. The maximum nuclear heating in the TF coil winding is at a minimum for a water concentration of around 20% in the steel zone by volume. This minimum also decreases as the lead zone thickness increases from 0 to 2 cm.

The maximum nuclear heating values in the TF coil winding as a function of the lead zone thickness with the boron carbide zone thickness of 0, 1, 2, 3, and 4 cm were calculated. The results show that the maximum nuclear heating in the TF winding is the lowest when

TABLE 1. GEOMETRY AND COMPOSITIONS FOR THE TFCK HYBRID INBOARD SHIELD STUDY

Zone Description	Radius (cm)		Thickness (cm)	Composition Volume Percentage
	From	To		
TF coil case	197.5 - t ^a	202.5 - t	5.0	100% type 304 steel
TF coil winding	202.5 - t	262.5 - t	60.0	5% NbTi, 23% Cu, 45% type 304 steel, 8% insulator
TF coil case	262.5 - t	267.5 - t	5.0	100% type 304 steel
Gap	267.5 - t	272.5 - t	5.0	Vacuum
Shield jacket	272.5 - t	274.5 - t	2.0	100% Fe1422
Lead shield	274.5 - t	274.5 - t + y	y ^a	100% Pb
Boron carbide shield	274.5 - t + y	274.5 - t + x + y	x ^a	100% B ₄ C ^b
Inner steel shield	274.5 - t + x + y	237.5	t - (37 + x + y)	z% H ₂ O, (100 - z)% Fe1422
Copper coil	237.5	257.5	20.0	73.7% Cu, 17.4% Fe1422
Outer steel shield	257.5	271.5	14.0	4% H ₂ O, 4.9% insulator
First wall	271.5	272.5	1.0	z% H ₂ O, (100 - z)% Fe1422
Scrape-off	272.5	280.0	7.5	50% H ₂ O, 50% Fe1422
Plasma	280.0	440.0	160.0	Vacuum
Scrape-off	440.0	447.5	7.5	Vacuum
First wall	447.5	448.5	1.0	50% H ₂ O, 50% Fe1422
Outboard shield	448.5	578.5	130.0	10% H ₂ O, 10% B ₄ C, 80% Fe1-22

^a x, y, z, t are variables.^b A 0.7 density factor is assumed.

Fig. 1. Maximum nuclear heating in the TF coil winding as a function of the water concentration in the steel shield for different lead zone thicknesses, 70 cm total shield thickness and 3-cm boron carbide zone thickness normalized to 1.8 MW/m² DT neutron wall loading at the first wall.

TABLE 2. MAXIMUM NUCLEAR HEATING IN THE TF COIL WINDING AS A FUNCTION OF THE TOTAL SHIELD THICKNESS AND THE LEAD ZONE THICKNESS WITH 3 cm BORON CARBIDE ZONE THICKNESS AND 10% H₂O IN THE STEEL SHIELD NORMALIZED TO 1.8 MW/m² DT NEUTRON WALL LOADING AT THE FIRST WALL

Shield Thickness (cm)	Lead Zone Thickness (cm)	Neutron Heating (W/cm³)	Gamma Heating (W/cm³)	Total Heating (W/cm³)
60	0	5.28-4 ^a	5.23-3	5.76-3
60	1	5.77-4	4.96-3	5.54-3
60	2	6.31-4	4.99-3	5.62-3
65	0	2.62-4	2.68-3	2.95-3
65	1	2.87-4	2.54-3	2.82-3
65	2	3.14-4	2.54-3	2.86-3
70	0	1.70-4	1.37-3	1.50-3
70	1	1.42-4	1.29-3	1.43-3
70	2	1.56-4	1.29-3	1.44-3
75	0	6.42-5	6.94-4	7.58-4
75	1	7.03-5	6.52-4	7.22-4
75	2	7.72-5	6.50-4	7.27-4

^a 5.28-4 reads 5.28 × 10⁻⁴.

the boron carbide zone thicknesses is about 1 to 2 cm. Also, the lowest value for the maximum nuclear heating in the TF coil winding occurs with 2 cm lead zone thickness. Combining all the above results, it is evident that the lowest value for the maximum nuclear heating in the TF coil winding for a specific shield thickness in the range of 50 to 80 cm occurs with about 20% water concentration in the steel zone by volume, 1 to 2 cm of B_4C , and 2 cm of lead.

The nuclear heating in the winding of the TF coils per unit length of the inboard section as a function of the total shield thickness, the water fraction in the steel zone, the lead zone thickness, and the boron carbide zone thickness, are also investigated. Same conclusions about the optimum water fraction in the steel zone and the boron carbide zone thickness can be made from the obtained results. However, the lowest nuclear heating in the winding of the TF coils per unit length of the inboard section is obtained without lead zone as shown in Fig. 2. For the total nuclear heating in the TF coils, winding and case, the use of 2 cm lead zone produces the lowest nuclear heating load. This result is important if two separate coolants with different operating temperature are used to cool the winding and the case separately.

Based on the above study for 0.3 mW/cm^3 maximum nuclear heating in the TF coil winding, the inboard shield for the TFCX hybrid design requires a total shield thickness of 80 cm with 20% water in the steel zone by volume, 1 cm layer of B_4C , and 2 cm layer of Pb at the back of the shield. The maximum nuclear heating in the TF coil winding with this shield is 0.22 mW/cm^3 as shown in Table 3. Other pertinent results for this shield are also given in Table 3. The use of 1.0 mW/cm^3 design criterion reduces the shield thickness by 11 cm and increases the nuclear responses in Table 3 by a factor of 5.

For the superconductor design, two shield concepts were considered for the inboard section of TFCX. The first concept is steel type shield which consists of 80% type 316 steel, 20% H_2O with 2 cm layer of boron carbide behind it based on the optimization studies from previous designs.^{3,11} For this concept, the total shield thickness is varied from 60 to 80 cm to analyze the radiation response parameters in the TF coils. Also, the impact of moving the boron carbide layer from the back of the shield to the position between the TF coil case and the vacuum vessel was considered. Table 4 gives the geometrical model and the composition of each zone used in this analysis.

The maximum nuclear heating in the TF coil winding, TF coil case, and the vacuum

Fig. 2. Nuclear heating in the winding of the TF coils per unit length of the inboard section as a function of the B_4C zone thickness for different lead zone thicknesses with 20% H_2O in the steel shield and 70 cm total shield thickness normalized to 1.8 MW/m^2 DT neutron wall loading at the first wall.

TABLE 3. RADIATION RESPONSE PARAMETERS IN THE TF COIL BASED ON 1.8 MW/m^2 DT NEUTRON WALL LOADING AT THE FIRST WALL AND 2×10^5 SECONDS OF OPERATION

Shield parameters	
Total shield thickness, cm	80
Water concentration in the steel zone, %	20
Lead zone thickness, cm	2
Boron carbide zone thickness, cm	1
Maximum nuclear heating, mW/cm^3	
the TF coil winding	0.22
the TF coil case	0.43
Total nuclear heating, W/cm	
the TF coil winding	3.50
the TF coil case	2.03
Maximum insulator dose, rads	
the TF coil	2.34×5
the normal copper coil	1.68×9
Maximum neutron fluences in the TF coil winding, n/cm^2	
$E > 0.1 \text{ MeV}$	2.29×15
$E > 0.0 \text{ MeV}$	3.84×15

TABLE 4. INBOARD SHIELD PARAMETERS USED IN THE ANALYSIS FOR THE SUPERCONDUCTOR DESIGN

Zone Description	Radius (cm)		Width (cm)	Composition Volume Percentage
	From	To		
TF case	121	126	5	100% type 316 steel
TF coil	126	191	65	5% NbTi, 23% Cu, 8% insulator, 45% type 316 steel
TF case	191	196	5	100% type 316 steel
Thermal insulator	196	203	7	1% insulator
Vacuum vessel	203	213	10	100% type 316 steel
Gap	213	216	3	Vacuum
Shield jacket	216	218	2	100% type 316 steel
Boron carbide shield	218	220	2	100% B ₄ C (0.7 density factor)
Steel shield	220	274	54	80% type 316 steel, 20% H ₂ O
First wall	274	276	2	50% type 316 steel, 50% H ₂ O
Graphite armor	276	281	5	100% C
Scrape-off	281	294	13	Vacuum
Plasma	294	506	212	Vacuum
Scrape-off	506	513	7	Vacuum
First wall	513	515	2	50% H ₂ O, 50% type 316 steel
Outboard shield	515	645	130	80% type 316 steel, 10% H ₂ O, 10% B ₄ C (0.7 density factor)

vessel are given in Table 5. Case 2 in this table is similar to Case 1 except the boron carbide layer is located between the TF coil case and the vacuum vessel as mentioned before. Comparisons between these two cases, one and two, show that moving the boron carbide layer near the TF coil reduces the nuclear heating in the TF coil winding by 15 to 17%, due to the neutron absorption increase in the boron carbide layer. On the contrary, the nuclear heating in the shield jacket and the vacuum vessel are increased by ~ 50%. The decrease in the nuclear heating of the TF coil winding is considered not sufficient to compensate for the difficulty and the complexity in the design with the boron carbide layer integrated with the vacuum vessel.

The second concept uses single diameter steel balls in a water tank to eliminate the fabrication cost associated with the steel type shield. The geometry and compositions used for this analysis is the same as that of the first concept listed in Table 4. The steel concentration in the shield was varied from 60 to 90% by volume. Figure 3 shows the maximum nuclear heating in the different components of the inboard section based on 1.8 MW/m² DT neutron wall loading at the first wall with 60 cm of shield. The optimal water fraction based on this analysis is around 20% which is consistent with the previous results for the hybrid design. The increase in the water concentration from 20 to 40% by volume causes about 35% increase in the total nuclear heating in the TF coils and the maximum nuclear heating in the TF coils winding materials. Also, the radiation dose in the insu-

lator materials increases by ~ 40% for the same change in the water concentration. The atomic displacement in the copper stabilizer shows similar behavior to the dose in the insulator materials. These effects result from the increase in the slowing down of the neutrons with energy less than 7 MeV, the increase in the neutron absorption in the boron carbide zone, the neutron spectra hardening in the vacuum vessel and the TF coils.

IV. OUTBOARD SHIELD DESIGN

The outboard shield design is driven by the biological dose requirements after shutdown and the radiation responses in the outboard section of the TF coils. Several shield options were analyzed with emphasis on reducing the cost of the shield system by using low cost materials.

First, the performance of the optimized steel type shield¹¹⁻¹⁴ was analyzed as a function of the shield thickness and the operating time. The thickness of the steel zone is varied and the dose equivalent one day after shutdown with type 304 steel for the TF coil case was calculated assuming 1.0 MW/m² DT neutron wall loading and 1 MW·y/m² DT neutron fluence at the first wall. The results show that the dose equivalent one day after shutdown decreases by a factor of two for each 5 cm increase in the shield thickness. Figure 4 shows the dose equivalent as a function of the operating time and the time after shutdown with a 130 cm shield thickness. The dose equivalent is 0.3 mrem/h one day after shutdown from the 2 x 10⁵ seconds of operation

Fig. 3. Maximum nuclear heating in the different components of the inboard section normalized to 1.8 MW/m^2 DT neutron wall loading at the first wall with 60 cm total shield thickness.

TABLE 5. MAXIMUM NUCLEAR HEATING IN THE VARIOUS COMPONENTS BASED ON A 1.8 MW/m^2 DT NEUTRON WALL LOADING AT THE FIRST WALL

Case	Shield Thickness (cm)	Neutron Heating (W/cm^3)	Gamma Heating (W/cm^3)	Total Heating (W/cm^3)
Maximum Nuclear Heating in the TF Coil Winding				
1	60	2.00-4	1.40-3	1.60-3
2	60	1.74-4	1.15-3	1.32-3
3	70	5.15-5	3.65-4	4.17-4
4	80	1.32-5	9.44-5	1.08-4
Maximum Nuclear Heating in the TF Coil Case				
1	60	2.21-4	2.22-3	2.44-3
2	60	1.95-4	2.43-3	2.62-3
3	70	5.63-5	5.85-4	6.41-4
4	80	1.43-5	1.52-4	1.67-4
Maximum Nuclear Heating in the Vacuum Vessel				
1	60	7.16-4	9.64-3	1.04-2
2	60	9.26-4	1.49-2	1.59-2
3	70	1.81-4	2.61-3	2.79-3
4	80	4.57-5	6.93-4	7.38-4

with 1.8 MW/m^2 DT neutron wall loading. However, the cost of this type of shield is relatively high.

Fig. 4. Dose equivalent one day, one week, and one month after shutdown as a function of the operating time based on 1.8 MW/m^2 DT neutron wall loading and 1.3 m of shielding materials.

The use of low cost materials (water, concrete, etc.) require thicker shield to compensate for the difference in the attenuation characteristics, relative to the steel shield. This leads to larger TF coils which increase the cost of the magnetic system. In order to avoid such a case, the outboard shield is divided to two sections. The first section is designed to protect the TF coils from radiation damage and excessive nuclear heating. The second section is located between and outside the TF coils to satisfy the dose criterion.

The steel balls concept is used for the first section of the outboard shield to protect the TF coils based on the previous analysis of the inboard shield. Table 6 gives the geometry and composition for each zone used to perform the analysis for the first section of the outboard shield. The maximum nuclear heating in the outer section of the TF coils was calculated as a function of the shield thickness. About 70 cm shield thickness is required to achieve $\sim 1 \text{ mW/cm}^3$ maximum nuclear heating in the TF coils.

For the second section of the outboard shield, three options are considered: a) water option (95% H_2O , 5% type 316 steel), b) concrete option, and c) steel balls option (60% type 316 steel, 40% H_2O). The analyses for these options were carried out to determine the dose equivalent as a function of the shield thickness. Table 7 gives the shield parameters used in the analyses. Figure 5 shows the dose equivalents at the outer surface of the shield one day after shutdown assuming type 316 steel liner for the reactor building and 1 MW/y/m^2 D-T neutron fluence at

TABLE 6. GEOMETRY AND COMPOSITIONS FOR THE FIRST SECTION OF THE OUTBOARD SHIELD

Zone Description	Radius (cm)		Width (cm)	Composition Percentage Volume
	From	To		
TF Case	121	126	5	100% type 316 steel
TF Coil	126	191	65	5% NbTi, 23% Cu, 45% type 316 steel, 8% insulator
TF Case	191	196	5	100% type 316 steel
Thermal Insulator	196	203	7	1% insulator
Vacuum Vessel	203	213	10	100% type 316 steel
Gap	213	216	3	Vacuum
Shield Jacket	216	216	2	100% type 316 steel
Boron Carbide Shield	218	220	2	100% B ₄ C (0.7 density factor)
Steel Balls Shield	220	274	54	60% type 316 steel, 40% H ₂ O
First Wall	274	276	2	50% type 316 steel, 50% H ₂ O
Graphite Armor	276	281	5	100% graphite
Scrape-off	281	294	13	Vacuum
Plasma	294	506	212	Vacuum
Scrape-off	506	513	7	Vacuum
First Wall	513	515	2	50% H ₂ O, 50% type 316 steel
Steel Balls Shield	515	565	50	60% type 316 steel, 40% H ₂ O
Boron Carbide Shield	565	568	3	100% B ₄ C (0.7 density factor)
Lead Shield	568	573	5	100% Pb
Gap	573	583	10	Vacuum
Vacuum Vessel	583	593	10	100% type 316 steel
Thermal Insulator	593	600	7	1% insulator
TF Case	600	605	5	100% type 316 steel
TF Coil	605	665	60	5% NbTi, 23% Cu, 45% type 316 steel, 8% insulator
TF Case	665	670	5	100% type 316 steel

the first wall. For water shield, the second shield thickness required to limit the dose equivalent one day after shutdown to 2.5 mrem/h is 120 cm, which makes the total outboard shield 190 cm thick. For a limit of 0.5 mrem/h, the required thickness is 138 cm. For the concrete shield, the required thicknesses are 131 and 151 cm, for the limits of 2.5 and 0.5 mrem/h, respectively. The corresponding numbers for the steel balls option are 86 and 98 cm, respectively. Table 8 summarizes these results. For 2×10^5 seconds of operation with 1.8 MW/m² DT neutron wall loading, the required shield thicknesses in Table 8 are reduced by 17, 24, and 27 cm for the steel balls, water, and concrete option, respectively.

V. CONCLUSIONS

Several low cost shielding options were developed for the two TFCX designs, the hybrid and the superconductor.

For the inboard section, the use of 80 vol% steel - 20 vol% water shield composition with 1-cm boron carbide layer at the back of the shield results in the lowest value for the total nuclear heating in the winding of TF coils. Increasing the water concentration to 40 vol% for reducing the shield cost (steel

balls in a water tank) results in about 35% increase in the total nuclear heating in the winding of the TF coils and the maximum nuclear heating in the winding materials of the TF coils.

For the outboard section, the shield is divided to two regions. The first region uses the 60 vol% steel-40 vol% water mixture to protect the outboard portion of the TF coils. The second region is located between and outside the TF coils to achieve the 0.5 mrem/hr dose equivalent in the reactor hall one day after shutdown. Water or ordinary concrete is the main material for the second region of the shield. The use of any combination of the low cost shield options studied in this paper for TFCX reduces the cost of the shield to less than 4% of the total direct cost¹⁵ compared to 8 to 16% for other fusion reactor design studies.^{3,4}

REFERENCES

1. Princeton Plasma Physics Laboratory Report No. F-Axxx-8407-006, "Preconceptual Design Report - Vol. 1 Overview," Revisions 2 (1984).
2. Y. COHAR, "Low Cost Shield for Tokamak Fusion Reactors," Journal of Nuclear Technology/Fusion 4, 373 (1983).

TABLE 7. GEOMETRY AND COMPOSITION FOR THE OUTBOARD SHIELD

Zone Description	Thickness, cm	Composition Percentage Volume
First Wall	2	50% H ₂ O, 50% Type 316 Steel
Steel Balls Shield	60	40% H ₂ O, 60% Type 316 Steel
Boron Carbide Shield	3	100% B ₄ C (0.7 DF)
Lead Shield	5	100% Pb
Biological Shield	Variable	95% H ₂ O, 5% Type 316 Steel, or 100% Concrete, or 40% H ₂ O, 60% Type 316 Steel
Boron Carbide Shield	3	100% B ₄ C (0.7 DF)
Lead Shield	5	100% Pb

Fig. 6. Dose equivalent one day after shut-down based on 1 MW·y/m² DT fluence at the first wall.

TABLE 8. TOTAL OUTBOARD SHIELD THICKNESS AS A FUNCTION OF THE DOSE CRITERION FOR THE DIFFERENT SHIELD OPTIONS CALCULATED FOR 1 MW·y/m² D-T NEUTRON FLUENCE AT THE FIRST WALL

Shield Option	Shield Thickness for 2.5 mrem/h, cm	Shield Thickness for 0.5 mrem/h, cm
Steel Balls	156	168
Steel Balls - Water	190	208
Steel Balls - Concrete	201	221

3. Y. GOHAR and M. A. ABDU, "U.S. INTOR Radiation Shield Design," Proc. of the 6th International Conference on Radiation Shielding, Tokyo, Japan (May 16-20, 1983).

4. C. C. BAKER, et al., "STARFIRE - A Commercial Tokamak Fusion Power Plant Study," Argonne National Laboratory, ANL/FPP/80-1 (1980).

5. A. E. PROFIO, "Radiation Shielding and Dosimetry," A. Wiley - Interscience Publication, John Wiley & Sons, New York (1979).

6. U.S. Nuclear Regulatory Commission, "Standard for Protection Against Radiation," US NRC Rules and Regulations, Title 10, Chapter 1, Part 20 (1977).

7. W. W. ENGLE, Jr., "A User's Manual for ANISN, A One Dimensional Discrete Ordinates Code with Anisotropic Scattering," Oak Ridge Gaseous Diffusion Plant, ORGDP-K-1963 (1967).

8. R. W. ROUSSIN, et al., "The CTR Processed Multigroup Cross Section Library for Neutronics Studies," Oak Ridge National Laboratory ORNL/RCSIC-37.

9. Y. GOHAR and M. A. ABDU, MACKLIB-IV: A Library of Nuclear Response Functions Generated with MACK-IV Computer Program from ENDF/B-IV," Argonne National Laboratory, ANL/FPP/TM-106 (1978).

10. J. JUNG, "Theory and Use of Radioactivity Code RACC," Argonne National Laboratory, ANL/FPP/TM-122 (1979).

11. Y. GOHAR and M. A. ABDU, "INTOR Radiation Shielding for Personnel Access," Ninth Symposium on Engineering Problems of Fusion Research, Chicago, IL (October 26-29, 1981).

12. Y. GOHAR, "FED/INTOR Activation and Biological Dose," Transaction of American Nuclear Society 43 (1982).

13. Y. GOHAR and M. ABDU, "INTOR Radiation Shielding System," Transaction of American Nuclear Society 40 (1981).

14. Y. SEKI, et al., "Radioactivation of Structural Material of the Superconducting Magnet for a Fusion Reactor," J. of Fusion Energy, Vol. 3. No. 4 (1983).

15. Princeton Plasma Physics Laboratory Report No. F-Axxx-8406-012, "TFX Cost Estimates and Summary Tables," (1984).