12
3/24/92
M.Y.F. ①

Overall U-Values and Heating/Cooling Loads - Manufactured Homes

C. C. Conner
Z. T. Taylor

February 1992

Prepared for the U.S. Department
of Housing and Urban Development
under a Related Services Agreement
with the U.S. Department of Energy
Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any **warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

Printed in the United States of America

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831;
prices available from (615) 576-8401. FTS 626-8401.

Available to the public from the National Technical Information Service,
U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

PNL--8006

DE92 009560

OVERALL U-VALUES AND HEATING/COOLING
LOADS - MANUFACTURED HOMES

C. C. Conner
Z. T. Taylor

February 1992

Prepared for the U.S. Department of
Housing and Urban Development
under a Related Services Agreement
with the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

SP

SUMMARY

This manual specifies a method for calculating the overall thermal transmittance (also referred to as the overall U-value or U_o), heating load, and cooling load of a manufactured (mobile) home. Rules, examples, and data required by the method are also presented. Compliance with the Department of Housing and Urban Development's (HUD) U_o and load calculation regulations contained in Sections 3280.506, 3280.510 and 3280.511 of the Manufactured Home Construction and Safety Standards must be demonstrated through the application of the method provided herein.

ACKNOWLEDGEMENTS

The authors are indebted to Mr. William Freeborne and Mr. Donald Fairman of HUD for their patience and support in producing this manual. Mr. Freeborne's careful technical reviews and suggestions helped ensure the quality of the method defined in this manual.

A number of individuals contributed suggestions and reviews of this manual. Technical reviews and guiding comments were provided Thomas Ekman of the Northwest Power Planning Council and Merle McBride of Owens-Corning Fiberglass. The review and practical advice of David Conover, formerly of the National Conference of States on Buildings Codes and Standards and now with the Pacific Northwest Laboratory, was appreciated.

CONTENTS

SUMMARY	iii
ACKNOWLEDGEMENTS	v
1.0 INTRODUCTION	1.1
1.1 OVERALL U-VALUE (U_o)	1.2
1.2 HEATING LOAD	1.6
1.3 COOLING LOAD	1.6
1.4 MANUAL CONTENT	1.9
2.0 THE OVERALL U-VALUE (U_o) CALCULATION	2.1
2.1 EXAMPLE OF OVERALL U-VALUE WORKSHEET	2.1
3.0 GENERAL RULES FOR COMPONENT U-VALUE CALCULATIONS	3.1
3.1 CALCULATION PROCEDURE FOR CEILING, WALL, AND FLOOR U-VALUES .	3.1
3.2 DEFINING CONDITIONED AND UNCONDITIONED SPACES	3.4
3.3 AREAS AND DIMENSIONS	3.6
3.4 CONSTITUENTS OF COMPONENTS	3.7
3.5 FRAMING FRACTIONS	3.8
3.6 VENTED SPACES	3.8
3.7 RESTRICTED AND PARTIALLY-INSULATED SPACES	3.9
3.8 INSULATION COMPRESSION OR RESTRICTION	3.9
3.9 SOURCES OF MATERIAL R-VALUES AND U-VALUES	3.13
3.10 FRAMING MEMBER R-VALUE NOT SURROUNDED BY INSULATION	3.14
4.0 COMPONENT-SPECIFIC RULES	4.1
4.1 CEILING	4.1
4.1.1 Loose-Fill Insulation Distribution	4.1
4.1.2 Batt Insulation Coverage of Bottom Chord	4.1
4.1.3 Treatment of Webbing Members in Ceiling Trusses . . .	4.2

4.1.4	Recessed Lighting	4.2
4.1.5	Skylights	4.3
4.1.6	Example Ceiling Worksheet	4.3
4.2	WALLS	4.8
4.2.1	Window U-values	4.8
4.2.2	Doors	4.9
4.2.3	Example Wall Worksheet	4.10
4.3	FLOORS	4.12
4.3.1	Floor Insulation Compression	4.12
4.3.2	Bandjoist	4.13
4.3.3	Example Floor Component Worksheet	4.15
4.4	DUCTS AND INFILTRATION	4.18
5.0	HEATING AND COOLING LOAD CALCULATION	5.1
6.0	U-VALUE AND LOAD CALCULATION SPREADSHEET	6.1
6.1	GENERAL GUIDELINES	6.2
6.2	U_o ESTIMATION	6.3
6.3	CITY SELECTION	6.4
6.4	U_o CALCULATION	6.5
6.5	LOADS CALCULATION	6.7
6.6	SUMMARY OF KEY VALUES	6.8
6.7	PRINTING AND SAVING	6.8
7.0	REFERENCES	7.1
	APPENDIX A - DEFINITIONS	A.1
	APPENDIX B - MATERIAL R-VALUES	B.1
	APPENDIX C - LOAD CALCULATION TABLES AND WEATHER DATA FOR LOAD CALCULATION	C.1

FIGURES

1.2	(A) Elements of the U_o Calculation: Components	1.2
1.1	Maximum U_o by Zone	1.3
1.2	(B) Elements of the U_o Calculation: Paths	1.4
1.2	(C) Elements of the U_o Calculation: Materials	1.5
1.3	Heating Load Elements	1.7
1.4	Cooling Load Elements	1.8
2.1	Overall U-value Worksheet	2.2
2.2	Example Overall of an U-value Worksheet Using Input from Example Component Worksheets	2.3
3.1	Component Worksheet for Ceiling, Walls, and Floor	3.2
3.2	Example of Wall Paths With Framing and Wall Paths Without Framing	3.3
3.3	Example of Ceiling Paths With Insulation Restricted and Ceiling Paths With No Insulation Restriction	3.3
3.4	Example of Conditioned and Unconditioned Floor Cavities	3.5
3.5	Example of Boundary Between Conditioned and Unconditioned Spaces	3.6
3.6	Example of Area Measurement for Vaulted Ceiling Area	3.7
3.7	Example of Paths for Ceiling Vented Attic Cavity	3.9
3.8	Example of Paths with Insulation Restricted	3.10
3.9	R-value Reduction from Restricted Insulation Thickness	3.13
3.10	Examples of Framing R-value with Partial Insulation Coverage	3.14
4.1	Examples of Batt Insulation Coverage of Bottom Chords	4.2
4.2	Ceiling Example	4.4
4.3	Example of Ceiling Component Worksheet	4.5
4.4	Wall Example	4.11

4.5	Example Wall Component Worksheet	4.12
4.6	Example of Insulation Compression Under Floor Assembly	4.13
4.7	Bandjoist Examples	4.14
4.8	Floor Example	4.15
4.9	Example Component Worksheet for a Floor	4.16
6.1	Estimated Overall U-value (U_o) Screen	6.3
6.2	Wall Worksheet Screen	6.5
6.3	Overall Home U-value Calculation Summary Screen	6.6
6.4	Heating and Cooling Load Screen	6.7
6.5	Spreadsheet Summary Screen	6.8

TABLES

3.1	Framing Fractions	3.8
3.2	Effect of Insulation Restriction on R-value	3.11
4.1	Default Glazing U-values	4.9
4.2	Default Door U-values	4.9
B.1	Building Materials R-values	B.1
C.1	Cooling Load Temperature Difference (CLTD) Values	C.1
C.2	Window Glass Load Factors (GLF)	C.2
C.3	Summer Air Exchange Rates (ACH)	C.2
C.4	Winter Air Exchange Rates (ACH)	C.2
C.5	House Tightness Factors	C.3
C.6	Design Weather Parameters	C.4

1.0 INTRODUCTION

The Manufactured Home Construction and Safety Standards (MHCSS) (24 CFR 3280) require the calculation of the overall thermal transmittance value (U_o), heating load, and cooling load for manufactured (mobile) homes. The U_o calculation is required because the MHCSS limit the U_o of the external shell (roof/ceiling, walls, and floor) of manufactured homes. The MHCSS require calculation of heating load to determine the outdoor design temperature at which an indoor temperature of 70°F can be maintained. In addition, other MHCSS requirements will necessitate a cooling load calculation unless the home is not designed or equipped to be air conditioned.

This manual is intended to define the method by which manufactured home U_o , heating load and cooling load are calculated.^{(a)(b)} The method prescribed herein is adapted from the ASHRAE Handbook, 1989 Fundamentals. In cases where the ASHRAE Handbook gives a range of choices or describes general options, this manual specifies particular required assumptions or methods appropriate to manufactured homes.^(c)

-
- (a) The U.S. Department of Housing and Urban Development (HUD) brought the Pacific Northwest Laboratory (PNL) under contract to develop a method for calculation of manufactured home U_o , heating load, and cooling load. PNL is operated by Battelle Memorial Institute for the U.S. Department of Energy under Contract DE-AC06-76RLO 1830.
 - (b) To the degree that modular homes are constructed like manufactured homes, this manual would also be applicable to one- and two-family modular homes.
 - (c) The ASHRAE Handbook, 1989 Fundamentals defines methods for use in all types of buildings; therefore, it is necessarily more general than this manual. The Handbook leaves many application-specific choices to the professional applying its methods. The Handbook does not contain (or claim to contain) methods specifically for manufactured homes. This manual clarifies ambiguities and specifies calculations that must be used for determining compliance with HUD's requirements related to manufactured home U_o , heating load, and cooling load. Unless otherwise noted, specifications presented in this manual must be followed even if alternatives are listed in the Handbook.

1.1 OVERALL U-VALUE (U_o)

The MHCSS (Section 3280.506) limits the overall U-value (U_o) of the exterior envelope of a manufactured home. The U_o limits are shown on the next page in Figure 1.1 for the climate zones defined in the MHCSS. This manual (or a method that gives equivalent results) provides the required method for determination of the U_o for a manufactured home. The prescribed U_o calculation is presented as a series of worksheets that functionally follow the steps summarized below. The U_o calculation produces the area-weighted average overall U-value (the U_o) for a home based on the thermal qualities and areas of the material assemblies used in the home's construction. The U_o represents the heat-flow potential per unit area for the building's exterior envelope.

The U_o calculation is illustrated conceptually in Figures 1.2 A, B, and C. To calculate the U_o , the exterior envelope is divided into components. The components are the roof/ceiling, walls, and floor; as shown in Figure 1.2(A). The heat flow potential (UA) of each component is computed

A home is made
up of components.

FIGURE 1.2(A). Elements of the U_o Calculation: Components

Zone	(d) Maximum U_0
1	0.132
2	0.109
3	0.096
4	0.079

FIGURE 1.1. Maximum U_0 by Zone

(a) Hawaii is in zone 1. Alaska is in zone 4.

separately. The U_o for the home is the area-weighted average of the heat flow potentials for each of the components:

$$U_o \text{ home} = \frac{UA_{\text{ceiling}} + UA_{\text{walls}} + UA_{\text{floor}}}{\text{Area}_{\text{ceiling}} + \text{Area}_{\text{walls}} + \text{Area}_{\text{floor}}}$$

To compute each component's heat-flow potential, the component is divided into several different heat-flow paths, with the heat-flow potential in each path computed separately. Each different series of materials separating the conditioned and unconditioned portions of a home is treated as a separate path. For example, the materials composing a wall's framing path are different from the materials composing a wall's insulation path, as shown in Figure 1.2(B), and are represented as separate paths. Therefore, the wall heat-flow potential is comprised of the wall cavity path, and wall framing path, as well as other wall paths not shown, such as the windows and doors.

A component is made up of several paths.

FIGURE 1.2(B). Elements of the U_o Calculation: Paths

The component's contribution to a home's heat-flow potential is the sum of the heat-flow potential of the paths in the component:

$$UA_{\text{component}} = UA_{\text{path 1}} + UA_{\text{path 2}} + \dots + UA_{\text{path n}}$$

The heat flow potential (UA) for each path is calculated as the path's U-value (1/R-value) multiplied by the path area:

$$UA_{\text{path}} = U\text{-value}_{\text{path}} \times \text{Area}_{\text{path}} = \frac{1}{R_{\text{path}}} \times \text{Area}_{\text{path}}$$

Each heat-flow path is made up of a series of materials that separate the interior conditioned home from the exterior. For example, Figure 1.2(C) shows the materials in the insulation path in a wall. Each material has a different thermal resistance (R-value). The R-value for each heat-flow path is the sum of the R-values for the layers of materials that make up the path:

$$R_{\text{path}} = R_{\text{material 1}} + R_{\text{material 2}} + \dots + R_{\text{material n}}$$

A path is made up of a series of different material layers, each of which has different thermal properties.

Side View of Wall Insulation Path

FIGURE 1.2(C). Elements of the U_o Calculation: **Materials**

The U_o calculation provided in this manual follows the model just presented. The calculation proceeds from the detailed description of the home in terms of each path of a component, then each component of the home, leading to the home's U_o . Therefore, in practice the calculation proceeds in the reverse of the order just presented. In practice, the individual path's heat-flow potential is calculated for each separate path making up a component, then all the heat-flow potentials for all the individual paths making up a component are aggregated into the component's heat-flow potential, and finally the components heat-flow potentials are aggregated into the home's heat flow potential and divided by the area to give the U_o .

1.2 HEATING LOAD

The MHCSS (Section 3280.510) require that a label be placed on each home identifying the lowest outdoor temperature at which the heating system can maintain an indoor temperature of 70°F. The heating load calculation used to determine this temperature is provided in this manual. Like the U_o calculation, the heating load calculation is presented as a required worksheet. The heating load for a home is the sum of the shell heat loss potential (the U_o times the home's area), the heat loss from the external ducts, and the air movement between the inside and outside (infiltration and ventilation), as shown in Figure 1.3. The heating load is computed based on the location and characteristics of the specific home.

$$\text{Heating Load} = \text{Load}_{\text{home UA}} + \text{Load}_{\text{ducts}} + \text{Load}_{\text{air}}$$

1.3 COOLING LOAD

The MHCSS (Section 3280.511) requires that a label with cooling information be placed in each home. The label identifies information based on one of the following conditions: 1) when the home is equipped with central cooling, it lists the equipment capacity and identifies the outdoor dry bulb and wet bulb temperatures at which the cooling system can maintain an indoor temperature of 75°F; 2) when the home is designed for central cooling, it lists the cooling equipment capacity that the air distribution system can accommodate; or 3) when not designed for central cooling, it indicates that

FIGURE 1.3. Heating Load Elements

the home was not designed for central air conditioning. The cooling load calculation for use in determining the outdoor temperature and capacity (number 1 above) is provided in this manual. Cooling load calculations for number 2 above can be derived from this manual but would be done by a local contractor or manufactured home dealer rather than the home manufacturer.

Computation of the cooling load is similar to computation of the heating load, but includes more elements. The cooling load includes the heat flow through each component of the structure (ceiling, walls, and floor) as well as loads associated with the ducts, infiltration, ventilation, occupants, appliances, and humidity reduction, as shown in Figure 1.4. The computation of the cooling load for walls and windows is orientation-specific to account for differences in solar gains associated with different orientations.

$$\begin{aligned}
 \text{Cooling Load} = & \text{Load}_{\text{ceiling}} + \text{Load}_{\text{floor}} \\
 & + \Sigma \text{Load}_{\text{walls by orientation}} \\
 & + \Sigma \text{Load}_{\text{windows by orientation}} \\
 & + \text{Load}_{\text{ducts}} + \text{Load}_{\text{infiltration}} + \text{Load}_{\text{ventilation}} \\
 & + \text{Load}_{\text{people}} + \text{Load}_{\text{appliances}} + \text{Load}_{\text{dehumidification}}
 \end{aligned}$$

FIGURE 1.4. Cooling Load Elements

1.4 MANUAL CONTENT

Section 2 presents the U_o Worksheet that is used to calculate a home's U_o . Inputs to the U_o Worksheet come from data generated in the Component Worksheets; with separate worksheets produced for the ceiling, walls, and floor. General rules governing the calculation of component U-value calculation are given in Section 3. The rules specific to the calculation of each component are discussed in Section 4. Section 5 details the heating and cooling load calculations.

A personal computer based spreadsheet is available for use in calculating the U_o , heating load, and cooling load of a home and may simplify these calculations. The spreadsheet may be used as an alternative method of calculating U_o and loads. For most manufacturers, use of the spreadsheet will probably simplify the U_o and loads calculations. The use of the spreadsheet is described in Section 6.

Supplemental information including definitions of thermal terms, material R-values, load calculation tables, and load calculation weather data are provided in Appendixes A, B, and C.

2.0 THE OVERALL U-VALUE (U_o) CALCULATION

The U_o Worksheet is shown in Figure 2.1 and is used to calculate the U_o for a home. Even though it is filled out last, the U_o Worksheet is presented first in this manual to show where the results of the Component U-value Worksheets are used. The U_o Worksheet requires input from the three Component U-value Worksheets produced for a home; one worksheet each for the ceiling, walls, and floor. The Component U-value Worksheets are described in Sections 3 and 4. The procedure for using the U_o Worksheet is outlined below:

- Step 1. Enter the area and UA for each component from the individual Component U-value Worksheets.
- Step 2. Sum the areas.
- Step 3. Sum the UAs.
- Step 4. Calculate the home U_o by dividing the total UA by the total area.

2.1 EXAMPLE OF OVERALL U-VALUE WORKSHEET

Figure 2.2 shows an example of a completed Overall U-value Worksheet using the inputs from the example Component U-value Worksheets included in this manual.

U_o Worksheet

Component	Component Area	Component UA
Ceiling		
Walls		
Floor		

Total Area

Total UA

÷

Home U_o

Model: _____

Date: _____

FIGURE 2.1 Overall U-value Worksheet

U_o Worksheet

Component	Component Area	Component UA
Ceiling	1508	87.65
Walls	1200	193.04
Floor	1344	101.74
	4052	382.43

Total Area Total UA

Model: Example from Manual

Date: _____

FIGURE 2.2. Example of an Overall U-value Worksheet Using Input from Example Component U-value Worksheets

3.0 GENERAL RULES FOR COMPONENT U-VALUE CALCULATIONS

Most of the rules for calculating U-values for the different building components (ceiling, walls, floor) are similar, and, therefore, are presented in this section.^(a) Rules specific to one component are given in Section 4.

3.1 CALCULATION PROCEDURE FOR CEILING, WALL, AND FLOOR U-VALUES

Figure 3.1 shows the Component U-value Worksheet. This worksheet must be used to calculate the U-values of the ceiling, walls, and floor. Each step of the calculation is recorded on the Component U-value Worksheet. The procedure for calculating ceiling, walls, and floor U-values is:

Step 1. **Separate the heat-flow paths for each component.** Enter the name of each heat-flow path at the top of a column. A separate U-value must be computed for each heat-flow path of a component. (Use additional worksheets if needed, carrying forward the areas and UAs of the paths to be included in the final component totals.) At a minimum, the following types of heat-flow paths must be separated:

- **Paths with framing and paths without framing.** For example, paths with 2x4 framing and paths without 2x4 framing in a wall are computed separately, as shown in Figure 3.2.^(b)
- **Paths with compressed or restricted insulation and paths without compressed or restricted insulation.** For example, ceiling paths where the insulation thickness is restricted by the slope of the roof are computed separately from the paths where the insulation is at full thickness, as shown in Figure 3.3.
- **Glazing and door assembly U-values.** These should be determined from manufacturers data as discussed in Sections 4.2.1 and 4.2.2.
- **Paths with different kinds of construction.** For example, in a house with both vaulted and flat ceilings, U-values for the two types of ceiling assemblies would usually be calculated separately.

(a) The examples in this section apply to a specific component but are intended to be generalized to the other components.

(b) The exception is in areas where the framing does not contribute to the U-value, such as areas where the framing does not abut the insulation.

FIGURE 3.1. Component Worksheet for Ceiling, Walls, and Floor

FIGURE 3.2. Example of Wall Paths With Framing and Wall Paths Without Framing

FIGURE 3.3. Example of Ceiling Paths With Insulation Restricted and Ceiling Paths With No Insulation Restriction

- Step 2. List the different materials separating the inside of the structure from the outside in the left column.
- Step 3. Write the R-value for each material of each path.
- Step 4. Sum each path's material R-values to produce the path's R-value.
- Step 5. Convert each path's R-value to a U-value ($U\text{-value} = \frac{1}{R\text{-value}}$).
- Step 6. Enter the area of each path that separates the inside and outside of the structure.
- Step 7. Multiply each path's U-value by its area, producing the path's UA.
- Step 8. Sum the path areas to produce the component area.
- Step 9. Sum the path UA values to produce the component UA.
- Step 10. Calculate the "Component U-value" by dividing the "Total UA" by the "Total Area".

When defining a path with a measured U-value (like a window, door, or a tested assembly), enter the U-value directly on the form, noting the source of the data also. When a path U-value is entered directly, steps 2 through 5 are eliminated for that path.

3.2 DEFINING CONDITIONED AND UNCONDITIONED SPACES

The U_o of the home is calculated at the boundary between the conditioned and unconditioned space. A space is considered conditioned if:

- the space is mechanically heated and/or cooled, or
- the space contains an uninsulated heating or cooling duct.

For example, if a floor contains an uninsulated duct, the cavity in the floor that "sees" the uninsulated duct is conditioned. Examples of conditioned and unconditioned spaces under floors are shown in Figure 3.4.

Example 1.
Uninsulated duct, therefore cavity is a conditioned space.
Path does not include floor.

Example 2.
Insulated duct, therefore cavity is an unconditioned space.
Path does include floor.

FIGURE 3.4. Example of Conditioned and Unconditioned Floor Cavities

Vented utility spaces such as the small spaces enclosing a furnace or water heater are considered unconditioned. Therefore, the U-value for a vented utility space is calculated for the wall between the home interior and the utility space rather than for the wall between the utility space and the home exterior wall. This situation is shown in Figure 3.5. Note that the MHCSS require either direct vent equipment or a separation of the furnace and water heater from the conditioned space of the home. In the latter, outside air is introduced into the furnace room for combustion and ventilation, rendering the room unconditioned. In the former, the air is brought directly into the equipment rendering the room conditioned. Stated another way, the materials that make up each path and form the thermal envelope of the home begin at the interior of the conditioned spaces in the home and end when they reach the outdoors, unconditioned indoor spaces, or spaces open to the outdoors.

FIGURE 3.5. Example of Boundary Between Conditioned and Unconditioned Spaces

3.3 AREAS AND DIMENSIONS

Inside dimensions must be used for all building components (ceiling, walls, and floor).

Glazing and doors are separate paths, each having the area of its rough opening. Like any other path, the glazing or door paths' areas are included in the area of the component where it is located. For example, the ceiling component area includes skylights.

A component's area should reflect the actual surface area of the component. For vaulted ceilings, the area is the actual ceiling surface area, rather than the horizontal projection of the ceiling area, as shown in Figure 3.6. The window area for a bay window must be the actual surface area of the window assembly, including the sash and frame, that separates the conditioned and unconditioned spaces.

The area for vaulted ceilings is the actual ceiling surface area rather than the horizontal projection of the ceiling on floor. A vaulted ceiling's area will be larger than a flat ceiling's area if both cover the same floor area. Note the inclusion of the transition wall area as well in the ceiling area.

FIGURE 3.6. Example of Area Measurement for Vaulted Ceiling Area

3.4 CONSTITUENTS OF COMPONENTS

Elements of the home are assigned to the component in which they are physically located. For example, the ceiling component includes knee walls, transition walls, skylight shafts, and skylights. If a bandjoist U-value calculation is required, the bandjoist path is included as part of the floor calculation. (a)

Low-R-value heat-flow paths are included in the component in which they reside. For example, a vertical, uninsulated space behind kitchen cabinets would be included as a path in the wall component.

Glazing is listed as a separate path in the component in which it physically resides. If an assembly's U-value was based on tests that included the glazing (such as a door with glazing), the entire assembly is treated as a path with one U-value.

(a) The bandjoist path will sometimes include both vertical elements (the bandjoist) and horizontal elements (the floor).

3.5 FRAMING FRACTIONS

Framing fractions define the fraction of the opaque (non-glazed) component that is assumed to be framing. The use of framing fractions is a convenient way to avoid calculation of the area of each individual framing and cavity path. The framing fractions specified in Table 3.1 are to be used in calculating ceiling, wall, and floor U-values. Other framing fractions may be used, if calculated by the manufacturer based on the construction of the home. If other framing fractions are used, the calculations and drawings supporting those fractions must be included with the worksheets.

For example, the opaque area of a ceiling might be 1000 ft^2 in a ceiling with framing 24 inches on-center. Table 3.1 shows the fraction of the opaque ceiling that is framing to be $1000 \text{ ft}^2 \times 0.07$, or 70 ft^2 . The remaining area, or $1000 \text{ ft}^2 - 70 \text{ ft}^2 = 930 \text{ ft}^2$, would be the cavity area.

TABLE 3.1. Framing Fractions

<u>Component</u>	<u>Framing Placement</u>	<u>Fraction of Non-Glazed Area</u>
Ceiling	16 in. on-center	0.10
Ceiling	24 in. on-center	0.07
Wall	16 in. on-center	0.15
Wall	24 in. on-center	0.12
Floor	16 in. on-center	0.10
Floor	24 in. on-center	0.07

3.6 VENTED SPACES

Any ceiling, wall, or floor cavity that is mechanically ventilated or has any open area must be considered vented. For purposes of determining the R-value of a path, the point at which a vented space is encountered must be considered outside air. Any remaining materials separating the vented space and the exterior are not counted towards the path R-value. For example, when an attic is ventilated, the attic path U-values include only those material layers beneath the vented space, as shown in Figure 3.7. The appropriate air film for the material layer bordering a vented air space and above the attic insulation is the interior (still) air film. Similarly, the thermal

For vented cavities (such as the vented attic above) the path includes only the materials on the conditioned side of the vented cavity. Therefore the heat-flow path includes the ceiling materials, but not the roof materials.

FIGURE 3.7. Example of Paths for Ceiling Vented Attic Cavity

resistance of a vented wall only include the materials up to the air film of the vented space. Any materials beyond this, such as the sheathing or the vented space, are not included in computing the wall U-value.

3.7 RESTRICTED AND PARTIALLY-INSULATED SPACES

Some portions of the building's components are very difficult or impossible to fully insulate. These are sometimes called "low-R-value heat-flow paths" or "thermal shorts". These areas must be identified and included on the component worksheet.^(a) This requirement does not include calculating areas in the shell where the insulation is compressed by piping, wiring, electrical boxes, or light switches.

3.8 INSULATION COMPRESSION OR RESTRICTION

If insulation is compressed or restricted, the insulation R-value must be reduced to compensate for the insulation's reduced effectiveness. Common examples of insulation restrictions are shown in Figure 3.8. Computation of the reduction in R-value is done using the values in Table 3.2. To use Table 3.2, first compute the restricted insulation thickness as a fraction of the uncompressed (full) insulation thickness, then look up the R-value remaining

(a) While this may appear overly burdensome, it should be recalled that even small low-R-value heat-flow paths can be very important to the integrity of the thermal envelope. In particular, small areas that entirely lack insulation can contribute significantly to a home's heat loss.

Example 1. Batt insulation compressed between two parallel planes, use column 4 of Table 3.2.

Example 2. Batt insulation compressed between two non-parallel planes, use column 2 of Table 3.2.

Example 3. Loose-fill insulation restricted by two non-parallel planes, use column 3 of Table 3.2.

FIGURE 3.8. Example of Paths with Insulation Restricted

TABLE 3.2. Effect of Insulation Restriction on R-value

% of Original Thickness	Non-uniform (i) Restriction		Uniform (j) Compression	% of Original Thickness	Non-uniform Restriction		Uniform Compression
	Batt	Blown			Batt	Blown	
0%	20%	18%	0%	51%	81%	73%	62%
1%	26%	21%	1%	52%	81%	73%	63%
2%	32%	25%	2%	53%	82%	74%	64%
3%	36%	28%	4%	54%	82%	75%	65%
4%	38%	30%	5%	55%	83%	75%	66%
5%	41%	32%	7%	56%	83%	76%	66%
6%	43%	33%	8%	57%	84%	76%	67%
7%	45%	35%	10%	58%	84%	77%	68%
8%	46%	36%	11%	59%	84%	78%	69%
9%	48%	38%	13%	60%	85%	78%	70%
10%	49%	39%	14%	61%	85%	79%	71%
11%	51%	40%	15%	62%	86%	79%	72%
12%	52%	42%	17%	63%	86%	80%	73%
13%	53%	43%	18%	64%	87%	81%	74%
14%	54%	44%	20%	65%	87%	81%	74%
15%	55%	45%	21%	66%	88%	82%	75%
16%	57%	46%	22%	67%	88%	82%	76%
17%	58%	47%	24%	68%	88%	83%	77%
18%	59%	48%	25%	69%	89%	84%	78%
19%	59%	49%	26%	70%	89%	84%	78%
20%	60%	50%	28%	71%	90%	85%	79%
21%	61%	51%	29%	72%	90%	85%	80%
22%	62%	52%	30%	73%	90%	86%	81%
23%	63%	52%	31%	74%	91%	86%	82%
24%	64%	53%	33%	75%	91%	87%	82%
25%	65%	54%	34%	76%	92%	87%	83%
26%	65%	55%	35%	77%	92%	88%	84%
27%	66%	56%	36%	78%	92%	89%	85%
28%	67%	57%	37%	79%	93%	89%	85%
29%	68%	57%	39%	80%	93%	90%	86%
30%	68%	58%	40%	81%	93%	90%	87%
31%	69%	59%	41%	82%	94%	91%	88%
32%	70%	60%	42%	83%	94%	91%	88%
33%	70%	60%	43%	84%	95%	92%	89%
34%	71%	61%	44%	85%	95%	92%	90%
35%	72%	62%	45%	86%	95%	93%	91%
36%	72%	63%	47%	87%	96%	93%	91%
37%	73%	63%	48%	88%	96%	94%	92%
38%	74%	64%	49%	89%	96%	94%	93%
39%	74%	65%	50%	90%	97%	95%	93%
40%	75%	65%	51%	91%	97%	95%	94%
41%	76%	66%	52%	92%	97%	96%	95%
42%	76%	67%	53%	93%	98%	96%	95%
43%	78%	68%	54%	94%	98%	97%	96%
44%	77%	68%	55%	95%	98%	97%	97%
45%	78%	69%	56%	96%	99%	98%	97%
46%	78%	70%	57%	97%	99%	98%	98%
47%	79%	70%	58%	98%	99%	99%	99%
48%	79%	71%	59%	99%	100%	99%	99%
49%	80%	71%	60%	100%	100%	100%	100%
50%	80%	72%	61%				

- (a) Non-uniform restriction is that which occurs between non-parallel planes, such as in the ceiling near the eaves. For areas where the insulation thickness is irregular (non-uniform blown insulation in ceilings or batt insulation in some highly compressed floors), divide the component into separate paths with approximately equal insulation thickness.
- (b) Uniform compression is compression between parallel planes, such as that which occurs in a wall.

from the figure. For example, assume R-13 batt insulation that was nominally 3.5-in. thick was compressed to 1.4 inches in a portion of the wall. This is a reduction to 40% of the unrestricted insulation thickness (1.4 divided by 3.5). Table 3.2 (column 4), shows that a reduction to 40% of the full thickness reduces the R-value to 0.51 (51%) of the original R-value. The new R-value would be

$$R-13 \times 0.51 = R-6.63$$

For batt insulation that is compressed by a sloped surface or loose-fill (blown) insulation that is restricted by a sloped surface (see examples 2 and 3, Figure 3.8), use columns 2 and 3, respectively, from Table 3.2 to determine the effective R-value of the area of reduced thickness. First compute the ratio of minimum thickness to the unrestricted (full) thickness. Then, using Table 3.2, use that ratio to look up the fraction of the R-value remaining. Note that batt insulation and loose-fill insulation have separate columns. For example, assume a section of loose-fill ceiling insulation went from R-25 insulation at a height of 10 in. to a minimum height of 2 in. at the edge of a ceiling. The ratio of the minimum and full thicknesses would be

$$T_{\text{minimum}}/T_{\text{full}} = 2/10 = 0.2 \text{ or } 20\%$$

Looking up 0.2 (20%) in column 3 of Table 3.2 shows that the R-value would be reduced to 0.50 (50%) of the insulation's nominal R-value. Therefore, the R-value of loose-fill insulation over the restricted area would be

$$R-25 \times 0.50 = R-12.5^{(a)}$$

The use of the batt insulation compression (column 2) in Table 3.2 is similar to the loose-fill insulation example just given. The values in Table 3.2 are illustrated in Figure 3.9. Figure 3.9 plots the reduction of the R-value resulting from restriction in insulation using the values in Table 3.2.

(a) Note that this is not the same as the R-value of the average insulation height, which would be R-15.

FIGURE 3.9. R-value Reduction Caused by Restricted Insulation Thickness

3.9 SOURCES OF MATERIAL R-VALUES AND U-VALUES

Several sources may be used to determine the insulating value of most materials.

- Appendix B of this manual
- the ASHRAE Handbook, 1989 Fundamentals
- reports of tests by the material's manufacturer
- module or materials tests using one of the following:
 - the guarded hot box (ASTM C-236, 1987)
 - the calibrated hot box (ASTM C-976, 1990)
 - the guarded hot plate (ASTM C-177, 1985)
 - the heat flowmeter (ASTM C-518, 1985).

R-values of insulation materials, windows, skylights, and air films have specific sources. Insulation R-values must be based on insulation

manufacturer's ratings as provided with the insulation. The calculation of insulation R-values in a home must be based on how the installation is actually installed in that home. Window U-values must be based on the specified tests or the defaults specified in Section 4.2.1 of this manual. Air-film coefficient R-values must be taken from Appendix B of this document.

3.10 FRAMING MEMBER R-VALUE NOT SURROUNDED BY INSULATION

If the full thickness of a framing member is not covered by insulation or bounded on its sides, the insulating value of the wood that extends beyond the insulation into an external or vented locations cannot be included in the framing R-value calculations. The value of the air film (or air space) is still included in calculating the heat-flow path through the framing element. Examples (shown as Figure 3.10) would be a floor where the insulation covered only part of the floor joists or a wall stud that is only partly covered by insulation. Note that by this rule a framing member that is not in contact with insulation, such as the top chord of a ceiling truss, has no R-value.

Example Floor. In this floor only 3 inches of the 2x6 floor joist is covered by insulation, therefore only 3 inches of the 2x6 would be counted towards the framing R-value.

Vented Wall Cavity. In this vented wall cavity only 2.5 inches of the 2x4 wall stud is covered by insulation, therefore only 2.5 inches of the 2x4 is included in the path R-value.

FIGURE 3.10. Examples of Framing R-values with Partial Insulation Coverage

4.0 COMPONENT-SPECIFIC RULES

This section includes calculation rules that are specific to a particular building component (ceiling, walls, or floor). A completed Component Worksheet for an example of each building component is also included in this section.

4.1 CEILING

4.1.1 Loose-Fill Insulation Distribution

Loose-fill (blown) insulation should be distributed uniformly in the ceiling cavity. Uniform insulation distribution (as opposed to non-uniform insulation distribution) will produce the lowest ceiling U-value for a given amount of blown insulation.

If the loose-fill insulation is not distributed evenly, the actual distribution must be accounted for in the heat-flow path calculation. Non-uniform coverage of the ceiling must be accounted for by using separate heat-flow paths for insulation of different depths. When calculating the ceiling characteristics for a ceiling with non-uniform insulation coverage, separate heat-flow paths should be created for each ceiling cavity and framing area associated with different insulation thicknesses.

4.1.2 Batt Insulation Coverage of Bottom Chord

Depending on the width of batt insulation used, the ceiling bottom chord may be covered or not covered by the batts. Batt insulation that is manufactured to fit in the space between the bottom chords of the ceiling must not be assumed to cover any portion of the bottom chords of the ceiling. This is shown in Figure 4.1, example 1. If "full width" (also called "oversized") batts are installed such that the batts cover the bottom chord, the bottom chord may be assumed to be fully covered by insulation. This situation is shown in Figure 4.1, example 2.

When high levels of batt insulation are used in the ceiling, uncovered bottom chords can represent a significant fraction of the ceiling's heat-flow potential. For that reason, full-width batts are recommended.

Example 1.

Batts do not cover framing, therefore insulation is not included in framing path U-value calculation.

Example 2.

"Oversize" batts do cover framing, therefore insulation is included in framing path U-value calculation.

FIGURE 4.1. Examples of Batt Insulation Coverage of Bottom Chords

4.1.3 Treatment of Webbing Members in Ceiling Trusses

The effects of webbing members need not be included in calculating ceiling U-values.

4.1.4 Recessed Lighting

Recessed lighting fixtures ("zero clearance" light fixtures) that are covered with insulation to a depth level with the surrounding insulation can

be assumed to be insulated to the level of the surrounding insulation, and should not be treated as a separate heat-flow path. Recessed lighting fixtures that are not covered by insulation and/or have insulation other than "zero clearance" conditions must be considered a separate heat-flow path with an overall R-value of 1 and an area equal to the area of the lighting fixture plus the uninsulated area retained for the proper clearance.

4.1.5 Skylights

Because they are in the ceiling, skylights are a ceiling heat-flow path. The rough opening in the roof for the skylight is used as the skylight area. The U-value of the skylight must be based on manufacturer's test data or defaulted to the values given in Section 4.2.1 of this manual.

4.1.6 Example Ceiling Worksheet

The example ceiling is shown in Figure 4.2. A completed ceiling Component Worksheet using this example is shown in Figure 4.3. The example assumes a ceiling with R-22 loose-fill blown-in insulation. At full height, the R-22 insulation is 6 inches thick. The ceiling cavity is 26 inches tall at the center, with a heel height of 2.5 inches and a 1-inch ventilation spacer between the top of the insulation and the underside of the ceiling. The bottom chords of the ceiling truss are 2x2s, placed 16 inch on-center. The total area of the ceiling is 1508 ft². The ceiling has two skylights, both flush with the ceiling. Each skylight is 4 ft² and single-glazed. There are no measured U-values available for the skylights. The lighting fixtures are all "zero clearance" fixtures covered with insulation.

The following comments are keyed to the letters on the example ceiling Component Worksheet (Figure 4.3).

Note A: definition of heat-flow paths. The four heat-flow paths shown in Figure 4.2 plus the skylight path were defined for the ceiling. The ceiling paths are: 1) the cavity area with insulation at full thickness, 2) the cavity area at the eaves where the insulation thickness is restricted by the roof (including the ventilation spacer), 3) the bottom chord area where the insulation height is not restricted, 4) the bottom chord area where the insulation height is restricted, and 5) the skylights.

Ceiling example.

R-22 blown insulation, average thickness 6 inches.

Total Ceiling Area = 1508 sq. ft.

Bottom chord 2x2s, 16 inches on center.

Ceiling height is 26 inches at center.

Ventilation spacer is 1 inch.

Heel height is 2.5 inches.

2 single-glazed skylights, 4 sq ft each,
unknown U-values.

Ceiling is divided into four areas for
calculation, as shown above.

FIGURE 4.2. Ceiling Example

Note B: the U-value of the insulation in the restricted area of the cavity. The maximum insulation height is 6 inches. The minimum insulation height is

$$\begin{array}{rcl} 2.5 \text{ in.} & - & 1 \text{ in.} \\ \text{heel height} & \text{ventilation spacer} & \\ & = & 1.5 \text{ in.} \\ & & \text{minimum height} \end{array}$$

The percentage reduction in insulation height from maximum to minimum is

$$\begin{array}{rcl} 1.5 \text{ in.} & / & 6.0 \text{ in.} \\ \text{minimum height} & \text{maximum height} & \\ & = & 0.25 \text{ or } 25\% \\ & & \text{of original thickness} \end{array}$$

Circle Component:		Ceiling		Walls		Floor		
Layer Description	Path Names→Cavity, not Restricted	Cavity ^A Restricted	Frame, not Restricted	Frame, not Restricted	Frame ^A , Restricted	Skylight		
Inside Air Film	0.61	0.61	0.61	0.61	0.61			
Gypsum Board	0.27	0.27	0.27	0.27	0.27			
Frame	0	0	1.88	1.88	1.88 ^D			
Insulation	22.00	11.88 ^B	16.50 ^C	16.50 ^C	2.64 ^D			
Outside Air Film	0.61	0.61	0.61	0.61	0.61			
Total R-value (R_t)	23.49	13.37	19.87	19.87	6.01			
U-value ($1/R_t$)	0.043	0.075	0.050	0.050	0.166	1.31 ^F		
Area	1092 ^E	258 ^E	121 ^E	121 ^E	29 ^E	8 ^E		
UA (U-value x Area)	46.96	19.35	6.05	6.05	4.81	10.48		

Model: _____

÷

1508

Total Area

÷

87.65

Total UA

Date: _____

0.058

Component U-value

FIGURE 4.3. Example of Ceiling Component Worksheet

Table 3.2 gives the reduction of R-value for non-uniform compression of batt insulation to 25% of the full original thickness as 54%. Therefore, the effective average R-value is

$$R_{\text{effective}} = R-22 \times 0.54 = R-11.88$$

Note C: the R-value of the insulation over the bottom chord in the unrestricted area. The average height of the loose-fill insulation above the bottom chord in the area where the insulation height is not restricted is

$$\begin{array}{rcl} 6 \text{ in.} & - & 1.5 \text{ in.} \\ \text{loose-fill on ceiling} & & \text{bottom chord} \end{array} = 4.5 \text{ in.} \text{ height on bottom chord}$$

which has an R-value of

$$\begin{array}{rcl} R-22 & \times & \frac{4.5}{6.0} \\ \text{R at cavity height} & & \end{array} = R-16.50 \text{ R at chord height}$$

Note D: effective insulation R-value over framing in area of restricted height. At the very edge of the eaves the combination of the bottom chord (1.5 inch) and the insulation ventilation spacer (1 inch) fill all the space resulting from the 2.5 inch heel height. Therefore, in the most restricted area of the framing path, there is no insulation. Looking up the impact of going from full height to no insulation in column 3 of Table 3.2, there is a reduction to 16% (0.16) of the original R-value. Therefore, the effective path insulation R-value is

$$R_{\text{effective}} = R-16.50 \times 0.16 = R-2.64$$

Note that the height of the insulation abutting the bottom chord is really 1 inch (2 inch - 1 inch ventilation spacer). However, this does not occur in an appreciable area and the full chord height is used in the framing path.

Note E: the areas for each heat-flow path. Because the framing is 16 inches-on-center, the framing paths are 10% of the total area (from Table 3.1); therefore, the framing area is

$$\begin{array}{rcl} (1508 \text{ ft}^2 - 8 \text{ ft}^2) & \times & 0.10 \\ \text{total area} & \text{skylight multiplier} & \\ = & & 150 \text{ ft}^2 \\ & & \text{framing area} \end{array}$$

and the cavity is the rest of the ceiling area:

$$\begin{array}{rcl} 1500 \text{ ft}^2 & - & 150 \text{ ft}^2 \\ \text{opaque ceiling} & \text{framing area} & \\ = & & 1350 \text{ ft}^2 \\ & & \text{cavity area} \end{array}$$

The cavity area must be divided into two areas, the area where the insulation is at full height and the area where the insulation is restricted by the roof at the eaves and therefore at partial height. To compute the width of the area of partial insulation, first compute the slope of the cavity that holds the insulation. The slope of the insulation cavity is the same as the slope of the roof. Recall that "Slope = Rise/Run". The run of the roof is half the width of the home or

$$28 \text{ ft}/2 = 14 \text{ ft} = 14 \times 12 = 168 \text{ in.}$$

The rise is the height of the roof, less the heel height; $26 - 2.5 = 23.5$ inches. Therefore, the slope of the roof is

$$\text{Slope Roof} = \text{Rise Roof}/\text{Run Roof} = 23.5/168 = 0.140$$

Now we can use the slope of the insulation cavity, which is equal to the slope of the roof, and the rise in the insulation height to compute the width of the insulation at partial height. The height of the insulation at full height is 6 inches. The rise in insulation height in the insulation cavity is the full height less the insulation height at the eaves. The insulation height at the eaves is the heel height less the ventilation spacer; $2.5 - 1 = 1.5$ inches. Therefore the rise in the insulation is $6 - 1.5 = 4.5$ inches. The slope of the insulation cavity is the same as the slope of the roof, therefore

$$\text{Slope Insul} = \text{Rise Insul}/\text{Run Insul} = 0.140 = 4.5/\text{Run Insul}$$

Therefore: $\text{Run Insul} = 4.5/0.140 = 32.1 \text{ in.}$

The fraction of the ceiling area with partial insulation is therefore

$$\text{Width of Partial Insul/Width of Ceiling} = 32.1/168 = 0.191 = 19.1\%$$

If 19.1% of the ceiling has insulation at a restricted height, then the rest of the area, $100\% - 19.1\% = 80.9\%$, would be at full height. All areas are shown below.

	<u>Total Area, ft²</u>	<u>80.9% at at Full Height Area, ft²</u>	<u>19.1% at Restricted Height Area, ft²</u>
Cavity	1350	1092	258
Framing	150	121	29

Note F: the skylights. The skylights did not have measured U-values; therefore, the U-values for the skylights were defaulted to the U-value for single glazing, U-1.31, from Table 4.1.

Note G: lighting fixtures. All lighting fixtures are "zero clearance" fixtures covered by insulation to the level of the surrounding ceiling; therefore, they are not calculated as a separate heat flow path and do not appear on the worksheet.

4.2 WALLS

4.2.1 Window U-values

U-values for windows or any other glazing (windows, skylights, and the glazing on a door) shall be based on tests using American Architectural Manufacturers Association (AAMA) 1503.1-1988. In the absence of tested window U-values, window U-values must be taken from Table 4.1. In using the default values, storm windows^(a) are treated as an additional pane of glass.

Glazing air film R-values are included in the standard U-value tests and the default values. Therefore, window air film R-values are not to be listed as a separate value on the Component U-value Worksheet for windows.

(a) Interior self-storing storm windows do not count as an extra pane.

TABLE 4.1. Default Glazing U-values

<u>Glazing Type</u>	<u>U-value^(a)</u>
single-pane glazing	1.31
double-pane glazing	0.92
triple-pane glazing	0.79
single-pane sliding glass doors	1.23
double-pane sliding glass doors	0.78
triple-pane sliding glass doors	0.64

4.2.2 Doors

Doors are listed as a separate heat-flow path in the walls component. Door U-values may be either 1) based on tested values using the tests specified in Section 3.9, 2) taken from the ASHRAE Handbook, 1989 Fundamentals, or 3) taken from Table 4.2. Note that air films are already included in ASHRAE U-values and in Table 4.2.

TABLE 4.2. Default Door U-values

<u>U-value</u>	<u>Door</u>
0.19	metal with thermal break and solid urethane foam core
0.17	metal with thermal break, solid urethane foam core and storm
0.57	wood panel door
0.47	wood with hollow core
0.37	wood panel door and storm
0.32	wood with hollow core and storm
0.60	any other door (default)

(a) The default window U-values are from the ASHRAE Handbook, 1989 Fundamentals. These represent the highest single-, double-, and triple-pane windows from the ASHRAE tables. Glazing U-values other than the six defaults in this manual must be based on tests. Measured window U-values will vary around these defaults, with most measured values below these default values.

4.2.3 Example Wall Worksheet

The example wall is an unvented R-14 wall and is shown as Figure 4.5. The example wall Component Worksheet is shown in Figure 4.4. In the example the wall insulation fills the space between the metal exterior and the interior gypsum board without compression of the insulation. The notes below are keyed to the example wall worksheet (Figure 4.4).

Note A: Areas. The gross wall area is

$$\begin{array}{ccccccc} 7.5 & \times & (56 & + & 24) & \times & 2 & = & 1200 \text{ ft}^2 \\ \text{height} & & \text{length} & & \text{width} & & & & \text{gross wall area} \end{array}$$

The opaque wall area is

$$\begin{array}{ccccccc} 1200 \text{ ft}^2 & - & (32 \text{ ft}^2 + 120 \text{ ft}^2) & - & 36 \text{ ft}^2 & = & 1012 \text{ ft}^2 \\ \text{gross wall} & & \text{windows} & & \text{door} & & \text{opaque wall} \end{array}$$

The framing is 16 inches-on-center. Table 3.1 gives the framing fraction as 15% of the opaque wall area. Therefore, the framing area of the wall is

$$\begin{array}{ccccccc} 1012 \text{ ft}^2 & & \times & 0.15 & & = & 151.8 \text{ ft}^2 \\ \text{opaque wall area} & & & \text{framing fraction} & & & \text{framing area} \end{array}$$

The cavity portion of the wall is

$$\begin{array}{ccccccc} 1012 \text{ ft}^2 & - & 151.8 \text{ ft}^2 & = & 860.2 \text{ ft}^2 \\ \text{opaque wall area} & & \text{framing area} & & \text{cavity area} \end{array}$$

Note B: Windows. The example home has two types of windows: 32 ft² of window with a U-value of 0.92, and 120 ft² of window with a U-value of 0.54. The window U-values are taken from window manufacturer test results, with the manufacturer's U-value used directly on the worksheet. Note that each of the two different types of windows is included separately on the worksheet. Note also that the source of the window and door U-values, as well as the window and door model numbers, are listed on the worksheet. (Window and door model names are made up for the example.)

Circle Component:		Ceiling	Walls		Floor
Path Names→ Layer Descriptions	Cavity	Framing	Window ^B Model VD-3	Window ^B Model VT-2M	Doors Model IM-b2
Inside Air Film	0.68	0.68			
Gypsum Board	0.27	0.27			
Insulation	14.00	0			
Framing	0	4.38			
Metal Exterior	0	0			
			Note:		
			Window and door U-values taken from		
Outside Air Film	0.17	0.17	manufacturer tests by XXX Windows and Doors Inc.		
Total R-value (R_t)	15.12	5.50			
U-value ($1/R_t$)	0.066	0.182	0.92	0.54	0.40
Area	860.2 ^A	151.8 ^A	32.	120.	36.
UA (U-value x Area)	56.77	27.63	29.44	64.80	14.40

Model: _____

Total UA
 193.04

Total Area
 1200

÷

Component U-value
 0.161

FIGURE 4.4. Example Wall Component Worksheet

FIGURE 4.5. Wall Example

4.3 FLOORS

4.3.1 Floor Insulation Compression

When blanket insulation is placed under a floor assembly, the joists compress the insulation, as shown in Figure 4.6. The insulation R-value reduction from this compression in the area between the floor joists may be estimated as 12.5% for framing 16 inches-on-center, 8.5% for insulation 24 inches-on-center, and 4% for framing 48 inches-on-center. The R-value of the insulation compressed over the framing members shall be zero (0). Other

values for R-value reductions for blanket insulation compressed against floor joists may be used if based on test data certified by an approved testing agency. If values other than the defaults are used, documentation for measurements of actual compression values must be included with the floor Component Worksheet.

4.3.2 Bandjoist

If the entire bandjoist (rim joist) is separated from the conditioned space by insulation, the bandjoist may be ignored as a heat-flow path. Otherwise, the uninsulated portion of a bandjoist must be treated as a separate heat-flow path. The area of the bandjoist path is the actual uninsulated area of the bandjoist. Examples are shown in Figure 4.7. The bandjoist heat-flow path includes the bandjoist wood thickness and the two (internal and external) bandjoist air films (air films total $R=0.85$). If the subfloor is not a heated space, the bandjoist heat-flow path also includes the floor material R-values and an air space in the floor cavity.

FIGURE 4.6. Example of Insulation Compression Under Floor Assembly

Example.

Bandjoist not separated from conditioned space by insulation. Portion of bandjoist not separated from conditioned space by insulation is treated as a separate heat-flow path.

Examples.

Bandjoist is separated from conditioned space by insulation. Therefore, the bandjoist is not included as a separate heat-flow path in the floor calculations.

FIGURE 4.7 Bandjoist Examples

4.3.3 Example Floor Component Worksheet

This section contains an example floor calculation for the floor illustrated in Figure 4.8. An example Component Worksheet for the floor is shown as Figure 4.9. The example floor is insulated with R-11 blanket insulation, which is cut to fit between the joists in the outrigger portion of the home. The insulation is held in place by a thin, flexible, rodent-proof barrier ("bottom board"). The floor is equally divided between the part that abuts the framing and the part in the center of the home that hangs below the framing. The floor joists are 2x6s, 16 inches-on-center. The duct in the floor is uninsulated; therefore, the space under the floor is a conditioned space. The predominate floor covering in the home is a carpet with a rubber pad. An explanation of the notes on the worksheet example follows.

Example Floor

R-11 blanket insulation cut to fit between joists in outrigger area

Insulation is 3 inches thick

2x6 floor joists, 16 in. on center

Uninsulated duct in the floor cavity

Floor equally divided between cavity and outrigger areas

All of bandjoist seperated from floor by insulation

Interior floor covering is predominately carpet with a rubber pad

Home is 56 feet long and 24 feet wide

FIGURE 4.8. Floor Example

Circle Component:		Ceiling	Walls		Floor
Layer Description	Path Names→	Outside Cavity	Outside ^A Framing	Interior ^A Area	
Inside Air Film		0.92	0.92	0.92 ^B	
Floor Covering		1.23	1.23	0	
Particle Board		0.82	0.82		
Insulation		11.	0	11.	
Framing		0	3.75	0 ^C	
Outside Air Film		0.92	0.92	0.92	
Total R-value (R_t)		14.89	7.64	12.84	
U-value ($1/R_t$)		0.067	0.131	0.078	
Area		604.8 ^D	67.2 ^D	672. ^D	
UA (U-value x Area)		40.52	8.8	52.42	

Total UA
101.74

Total Area
1344
÷

Component U-value
0.076

Model: _____

Date: _____

FIGURE 4.9. Example Component Worksheet for a Floor

Note A: the heat-flow paths. The floor is divided into three heat-flow paths, as shown in Figure 4.8: the outside edge ("outrigger" area where the floor insulation is attached to the underside of the floor between the floor joists); the outside edge framing; and the interior area where the insulation drops below the floor joists. Because the insulation is applied to the underside of the floor, the bandjoists are not exposed, do not make a separate heat-transfer path, and are not calculated as a separate heat-flow path.

Note B: large floor cavity air space R-value. The floor cavity air space has no R-value because the floor cavity is considered to be heated by the ducts and is therefore a conditioned space. The interior air-film R-value is included in the heat-flow path of the interior floor cavity. (Note this also implies that no R-value credit is given for the flooring materials in the cavity area of the home.)

Note C: framing R-value. The insulation abuts 3-inch deep portion of the floor joists in the outer portion of the floor; therefore, 3 inches of the joist wood is included in the framing path of the outer portion of the home. In the interior area the framing does not abut the insulation and is within the heated floor cavity space; therefore, the floor joist's R-value on the interior floor cavity area is zero (0).

Note D: path areas. The total floor area is

$$\begin{array}{rcl} 56 \text{ ft}^2 & \times & 24 \text{ ft}^2 \\ \text{length} & & \text{width} \end{array} = \begin{array}{r} 1344 \text{ ft}^2 \\ \text{floor area} \end{array}$$

The floor was split equally between the interior and outside areas, each with an area of $1344/2$ or 672 ft^2 . The outrigger area is further divided into framing and cavity areas, with 10% (from Table 3.1) being framing and 90% being cavity. Therefore, the areas are

672 ft^2 for the central floor cavity

$672 \text{ ft}^2 \times 0.10 = 67.2 \text{ ft}^2$ for the outrigger framing

$672 \text{ ft}^2 \times 0.90 = 604.8 \text{ ft}^2$ for the outrigger cavity.

4.4 DUCTS AND INFILTRATION

Duct U-value is not included in the calculation of the home U_o . Any space that contains an uninsulated duct must be considered conditioned for purposes of calculating U-values. Uninsulated ducts are not allowed in unconditioned spaces or outside the home's shell.

Infiltration is not included in the calculation of the home U_o . Likewise, vapor barriers are not considered to affect the home's U_o . Infiltration and ventilation are considered in the load calculation in Section 5.

5.0 HEATING AND COOLING LOAD CALCULATION^(a)

This section defines the heating and cooling load calculations. These calculations are used to size heating and cooling equipment for manufactured homes. These calculations also provide information necessary for the Heating Certificate and Comfort Cooling Certificate required for manufactured homes.

The heating and cooling load calculations require four worksheets, which are shown on pages 5.2 through 5.5. The general calculation process was described in Section 1.2. The heating and cooling load calculation worksheets require information on the home and parameters from Appendix C. Each load worksheet contains directions for performing the required calculations.

Because some of the worksheets use parameters from other worksheets, the worksheets should be completed in the following order:

1. Heating Load Worksheet
2. Input section of the Cooling Load Summary Worksheet
3. Cooling Load Worksheet #1
4. Cooling Load Worksheet #2
5. Summary section of the Cooling Load Summary Worksheet

(a) The design load calculation worksheets in this document are adapted from the methods recommended by the ASHRAE Handbook, 1989 Fundamentals. Heating load calculations are taken from the standard procedures outlined in Chapter 25, while cooling load procedures are from the residential cooling load calculation methodology in Chapter 26.

Although the ASHRAE calculations are the basis of this manual, the ASHRAE calculations have been adapted for manufactured homes. Many features are fairly uniform across all models of manufactured homes, which allows the ASHRAE design load calculation methodologies to be simplified, especially with respect to cooling loads. For example, the ASHRAE multifamily load calculation tables were eliminated because all manufactured homes are single family structures. In some cases ASHRAE defines the general approach(s), which this manual resolves to a specific method.

HEATING LOAD WORKSHEET

(This worksheet should be filled out before the cooling worksheets)

Select a city for the heating and load calculations. (see Table C.6)

City _____

Precalculate Duct Loss Factor (DLF):

$$DLF = 1 + \left[\frac{\text{outside duct fraction}^a}{1} \times 0.1 \right] = \boxed{}$$

Calculate heating load:

$$\text{Conduction} = \frac{\text{Home UA (U}_o \text{ Worksheet)}}{1} \times [70 - \frac{\text{Winter Outdoor Design Temperature (WDB, Table C.6)}}{1}] \times \frac{DLF}{1} = \boxed{} \text{ (Btu/hr)}$$

$$\text{Infiltration} = 0.0183 \times \frac{\text{House Volume}^b \text{ (ft}^3\text{)}}{1} \times \frac{\text{ACH (Table C.4)}}{1} \times [70 - \frac{\text{Winter Outdoor Design Temperature (WDB, Table C.6)}}{1}] \times \frac{DLF}{1} = \boxed{} \text{ (Btu/hr)}$$

$$\text{Total Heating Load (sum of conduction and infiltration) -----> } \boxed{} \text{ (Btu/hr)}$$

Notes:

- (a) Enter the fraction of the total duct length that is outside the insulated envelope.
- (b) Compute house volume by multiplying the floor area by the average floor-to-ceiling height.

COOLING LOAD SUMMARY WORKSHEET

INPUT SUMMARY

Outdoor Summer Design Dry Bulb Temperature (SDB, Table C.6): _____ (°F)

Outdoor Design Humidity Ratio (HUM, Table C.6): _____ (lb H₂O/lb dry air)

Mean Daily Range Category (circle one) (MDR, Table C.6): L M H
L = low, M = medium, H = high.

COOLING LOAD SUMMARY

Component

Windows (from Worksheet 1)		<input type="text"/>
Opaque Surfaces (from Worksheet 2)		<input type="text"/>
Infiltration (from Worksheet 2)		<input type="text"/>
People = 468 ÷ 238 × [<input type="text"/> - 1] = # bedrooms		<input type="text"/>
Appliances & Lights	+	<input type="text" value="1800"/>
<hr/>		
Subtotal Sensible Load		<input type="text"/>
Duct Loss Factor (DLF from heating worksheet)	x	<input type="text"/>
<hr/>		
Total Sensible Load		<input type="text"/>
Latent Load Factor (from Worksheet 2)	x	<input type="text"/>
<hr/>		
Total Cooling Load		<input type="text"/>

Note: Select cooling equipment to meet both sensible and total loads. Equipment capacities, typically rated at standard conditions of 80°F dry bulb and 67°F wet bulb, must be adjusted for design temperatures. See equipment manufacturer's literature for assistance.

COOLING LOAD WORKSHEET 1 (WINDOWS)

Southern Exposure Factor for S, SE, & SW orientations (SEF, Table C.6) ==>

Exposure Factor for all other orientations =====>

1.00

< OR >

From Table C.6

Orientation^a

Shading
Coefficient^b

From
Table C.2

See Note c

(ft²)

<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				
<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				
<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				
<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				
<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				
<input type="text"/>	:	<input type="text"/>	x	[	<input type="text"/>	-	<input type="text"/>	]	+	[	<input type="text"/>	x	<input type="text"/>	]	=	<input type="text"/>	x	<input type="text"/>	x	<input type="text"/>	=	<input type="text"/>
		SC			GLF		TAF			U-value		TAF				EF		Area				

Total Window Load-->
(Btu/hr)

Notes:

- (a) Enter orientation: N (North), NE (Northeast), NW (Northwest), E (East), W (West), SE (Southeast), SW (Southwest), S (South), H (Horizontal) or U (Unknown). Use the predominant orientation. For example, a surface that faced 15° off South would be called South. Any surface that is nearer to horizontal than vertical is treated as horizontal.
- (b) If tested shading coefficient is unavailable, assume SC = 1.00 for single-pane, 0.80 for double-pane, 0.80 for triple-pane, and 0.58 for heat absorbing glazings.
- (c) If tested U-value (Btu/hr-ft²-F) is unavailable, assume defaults of U = 1.31 for single-pane, 0.92 for double-pane, and 0.79 for triple-pane glazings. For sliding glass doors use defaults of 1.23 for single-pane, 0.78 for double pane, and 0.64 for triple pane.

COOLING LOAD WORKSHEET 2 (Ceiling, Walls, Floor, Infiltration, Ventilation, Latent)

Opaque Surfaces (ceiling, walls, floor, and doors):

Surface	Orientation ^a	(Note b)	(Note c)	From Table C.1	
Ceiling	<NA>				<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Floor	<NA>				<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Wall		area frac.	Wall UA	CLTD	<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Wall		area frac.	Wall UA	CLTD	<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Wall		area frac.	Wall UA	CLTD	<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Wall		area frac.	Wall UA	CLTD	<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
Total Opaque Load -->					<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div> (Btu/hr)

Infiltration and Ventilation Load:

Infiltration (ACH, Table C.3)	+	Ventilation (Note d)	=	<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
				Total ACH
Load = 0.0183 x	House Volume ^e (ft ³)	x	Total ACH	x [Summer Outdoor Design Temperature (SDB, Table C.6) - 75] =
				<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div> (Btu/hr)

Latent Load Factor (LLF):

LLF = 1.0 +	Tightness Factor (Table C.5)	x	Design Humidity Ratio (HUM, Table C.6)	- 0.01	=
					<div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div> <div style="border: 1px solid black; width: 60px; height: 20px; display: inline-block;"></div>
					Enter the larger of 1.0 or the calculated LLF.

Notes:

- (a) Enter N, NE, NW, E, W, SE, SW, H (Horizontal) or U (for Unknown orientation).
- (b) For each wall, enter the fraction of the total wall area facing the given orientation.
- (c) Obtain ceiling, floor, and wall UA values from the Component U-value Worksheets. The same total wall UA (from the Wall Component U-value Worksheet) should be entered in all "Wall UA" boxes.
- (d) Enter the ACH rate for intentional ventilation of home, if any.
- (e) Compute house volume by multiplying the floor area by the average floor-to-ceiling height.

6.0 U_o AND LOAD CALCULATION SPREADSHEET

The U_o and loads calculations have been automated into a Lotus 1-2-3^(a) spreadsheet. This spreadsheet will run on versions 2.01 or later of Lotus 1-2-3 or any program that is fully compatible with the Lotus spreadsheet.

The use of the spreadsheet instead of the hand calculation may simplify the calculations required by this manual. Generally the user will still have to define the inputs, but the spreadsheet will perform the calculations. For example, the calculation of the cooling loads requires only one screen of input because most of the required table lookups can be done automatically by the spreadsheet. Some inputs to the spreadsheets will still have to be calculated outside the spreadsheet: for example, all heat-flow path areas must be derived for input to the spreadsheet.

The software performs the following functions:

- Estimate the U_o for a home based on limited information on insulation R-values, windows, and areas.
- Select a city for the heating and cooling loads calculations.
- Calculate the home U_o based on the materials and assemblies used in a specific home.
- Compute the heating and cooling loads based on the specific home and location selected.
- Summarize the key values from all the screens.
- Print the screens summarizing the calculations.
- Save the spreadsheet for later use.

(a) Lotus and 1-2-3 are registered trademarks of the Lotus Development Corporation.

There are four menus in the spreadsheet as shown below.

MAIN MENU choices:

Summary Estimate_Uo City U_Calc Loads Print File_Save Quit

U CALCULATION MENU choices:

Summary_U Ceiling_U Wall_U Floor_U Main_Menu Print_Menu

PRINT MENU choices:

Summary Estimate_Uo All_U_Calculations Loads Main_Menu U_Calc_Menu

HELP MENU topics:

Estimate_Uo City U_Calculation Loads_Calculation Menus

To get MENUs (anytime) type: MAIN MENU: Alt-M
U-VALUE CALC: Alt-U
PRINT MENU: Alt-P
HELP MENU: Alt-H

6.1 GENERAL GUIDELINES

The spreadsheet implements the calculations described in this manual. All the rules in this manual also apply to the calculations done with a spreadsheet. The major advantage of the spreadsheet is that it will speed the calculation for most people.

The answers obtained from the spreadsheet may differ slightly from those obtained from the hand calculations. This difference is caused by rounding, with the spreadsheet holding more significant figures in intermediate values than most hand calculations. The differences will be small; that is at most a change of 0.001 in the computed U_o . U_o s calculated by hand and by the spreadsheet are both valid for complying with the MHCSS U_o requirements.

Most of the fields on the spreadsheet are "protected", meaning the protected fields will not allow input. This protection should be left on so that the spreadsheet calculations are not modified. On a color terminal the fields allowing input will appear in color. Other fields are for you information and cannot be changed. Users with a black and white terminal should look for the asterisks "****", which appear below the fields that allow input.

6.2 U_o ESTIMATION

The U_o estimation screen ESTIMATES the home's U_o based on a limited description of the home. This screen can be used to quickly identify the constructions that may comply with the maximum U_o requirement. Because the estimated U_o may vary from the calculated U_o by 5 to 10%, calculation of the home's U_o based on actual construction is still required. Compliance cannot be shown with an estimated U_o . An example screen is shown in Figure 6.1 below. The bold characters in the screen indicate fields that the user may enter data into.

The low-R-value paths in the U_o estimation screen can be used to represent any number of small paths that have low-R-values. These could include uninsulated bandjoist paths, large uninsulated areas behind kitchen cabinets, uninsulated portions of walls bounding conditioned and unconditioned space, etc.

The estimated U_o screen is a choice on the main menu (type Alt-M to get the main menu).

Estimated Overall U-value (U_o)					
Ceilings	Area	R-value	Windows.....		
	1508	22	Area	U-value	
	****	**	#1	120	0.54
Walls (gross)	1200	14	#2	32	0.92
	****	**	#3	8	1.31
Floors	1344	11	***	****	
	****	**	Door	36	0.4
			***	****	
Estimated Home U_o			Low R-value Paths		
0.104			Area	R-value	
			#1	0	0
Zone 2 Maximum = 0.109			#2	0	0
			***	**	
This screen only ESTIMATES U_o . U_o calculation based on actual construction is still required to demonstrate U_o compliance.					
(For Main Menu type Alt-M, For U Calc Menu type Alt-U)					

FIGURE 6.1. Estimated Overall U-value (U_o) Screen

6.3 CITY SELECTION

The selection of a city affects the load calculation. The city chosen must be in the zone for which the home is built, preferably near the likely location of the home.

The selection of a city is a choice on the main menu. To get to the city selection, call the main menu (type Alt-M) and select the "City" option. The next screen will show a list of states like that below.

- Alabama
- Alaska
- Arizona
- Arkansas
- California
- Colorado
- Connecticut
- Delaware
- Dist. of Col.
- Florida
- Georgia
- Hawaii
- Idaho
- Illinois

Select a state, by moving the curser to that state with the "arrow" keys and hitting the "Return" key. A list of cities in that state will follow, like the partial list for Texas below.

- Abilene
- Alice
- Amarillo
- Austin
- Bay City
- Beaumont
- Beeville
- Big Spring
- Brownsville
- Brownwood
- Bryan
- Corpus Christi

To select a city, move the curser to that city and hit the "Return" key. A new city can be selected at any time; the load calculations will be automatically adjusted for the new city.

6.4. U_o CALCULATION

The U_o calculation proceeds in several steps. First the calculations must be done for each component. Each component has its own screen, such as the wall component screen (Figure 6.2) shown below. A description of the assemblies and materials used to make the home is entered for each component. The **bold** areas represent input from the user.

The paths making up each component are described as material layers (air film, insulation,...), each of which has an R-value. Each path must have an area. Short, descriptive names should be put at the top of each path. Do not neglect low-R-value heat-flow paths and insulation compression when defining the component.

Path U-values may be used for glazing, doors, or tested components. Enter a U-value in the row marked "U-value". Do not enter both R-values and U-values for the same path.

-----Wall Worksheet----- (Type Alt-U for U Calc Menu)-----						
..Layer..	Cavity	Framing	Window Type 1	Window Type 2	Door	
*****	*****	*****	*****	*****	*****	*****
In Film	0.68	0.68				
Gypsum Bd	0.27	0.27				
Insulat	14	0				
Frame	0	4.38				
Metal Ext	0	0				
Out Film	0.17	0.17				
*****	*****	*****	*****	*****	*****	*****
U-Value			0.92	0.54	0.4	
-----	*****	*****	*****	*****	*****	*****
Total R	15.12	5.5	0	0	0	0
Area	860.2	151.8	32	120	36	0
-----	*****	*****	*****	*****	*****	*****
UA	56.89	27.60	29.44	64.80	14.40	0.00
Wall U=0.161		Total UA	193.13		Tot Area	1200

FIGURE 6.2. Wall Worksheet Screen

The "U-value Summary" screen (Figure 6.3), shown below, summarizes all the component calculations. This screen does not allow input.

----- Overall Home U = 0.094 -----			
Component	Area	UA	U-value
Ceiling	1508	87	0.058
Walls	1200	193	0.161
Floor	1344	102	0.076

Overall	4052	382	

This screen summarizes UA, Area and U-value by component.
No input is allowed to this screen.
To compute home's U_o use ceiling, wall, and floor screens.

FIGURE 6.3. Overall Home U-value Calculation Summary Screen

6.5 LOADS CALCULATION

The loads calculation utilizes the U_o computed from the component screens, the location, and the input to the loads screen to calculate heating and cooling loads for the home. A sample loads screen (Figure 6.4) is shown below. The **bold** fields represent input by the user. All required user input to the loads calculations is contained on this screen.

HEATING AND COOLING LOAD					(For Main Menu type Alt-M)	
Walls	Orient	% of Wall			2 Number of bedrooms	
#1	ne	35.0%			9.0% ducts outside	
#2	nw	15.0%			10080 House volume	
#3	sw	35.0%			N	Air Infil Barrier? (Y/N)
#4	se	15.0%			0.15 Mechanical Vent (ACH)	
	**	*****			*****	
Glazing	Orient	SC	U-value	Area		
#1	ne	0.88	0.92	32	LOADS: HEATING 20624	
#2	ne	0.8	0.54	40	COOLING 27622	
#3	nw	0.8	0.54	20		
#4	sw	0.8	0.54	40	CITY: Beaumont	
#5	se	0.8	0.54	20	Texas	
#6	h	1	1.31	8	ZONE 2	
	**	*****	*****	***		

Orientations: N, S, E, W, NW, NE, SW, SE, H (Horizontal) or U (Unknown).
 Shading Coefficient (SC) and U-value must be based on testing or default.
 SC defaults: single=1.00, double=0.88, triple=0.80, heat abs=0.58
 U-value defaults: single=1.31, double=0.92, triple=0.79

FIGURE 6.4. Heating and Cooling Load Screen

6.6 SUMMARY OF KEY VALUES

The "summary" screen (available from the main menu) shows a summary of the key values in the spreadsheet. No input is allowed to this screen, except for the 2 title lines. An example of this screen is shown below in Figure 6.5.

```
.....SPREADSHEET SUMMARY.....
Title, Model or Home Description (2 lines below)
Example home, same as is in the U-value manual

*****

      This home's computed Uo = 0.094
      Zone 2 Maximum is    0.109
      Home COMPLIES with Zone 2

      LOCATION              LOADS
      Beaumont             20624 Heating
      Texas                27622 Cooling
.....
```

FIGURE 6.5. Spreadsheet Summary Screen

6.7 PRINTING AND SAVING

The information you generate may be printed or saved in a spreadsheet file. All the screens displaying information on the home may be printed out. Screen printing is done with the print menu (Alt-P). The print command will print all the screens shown in this manual.

Files that you want to use again must be saved as a spreadsheet file. The save command is on the main menu. Preserving the calculations for a number of different homes will require saving several copies of the spreadsheet. To help you recall the purpose of a spreadsheet at a future date, it is suggested that you assign meaningful, unique names to your spreadsheets. Remember that saving two spreadsheets with the same name will overwrite (destroy) the older spreadsheet. If you try to overwrite an existing spreadsheet, you will be warned.

7.0 REFERENCES

American Architectural Manufacturers Association. 1988.

American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc. (ASHRAE). 1989. ASHRAE Handbook, 1989 Fundamentals. Atlanta, Georgia.

24 CFR 3280. 1987. U.S. Department of Housing and Urban Development, "Manufactured Home Construction and Safety Standards." U.S. Code of Federal Regulations.

APPENDIX A

DEFINITIONS

APPENDIX A

DEFINITIONS

"Thermal Transmittance" or "U-value" means the overall coefficient of heat transfer from air to air. It is the time rate of heat flow per unit area under steady conditions from the air on the warm side of the barrier to the air on the cold side, per unit temperature difference, $\text{Btu/h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$. The smaller the U-value, the greater the insulating value.

"Overall Thermal Transmittance" or " U_o " means the gross overall (area weighted average) coefficient of heat transfer from air to air for a gross area of the building envelope, $\text{Btu/h} \times \text{ft}^2 \times ^\circ\text{F}$. The thermal transmittance combines the effect of the time rate of heat flow through the various parallel paths, such as windows, doors, and opaque construction areas, comprising the gross area of one or more building envelope components, such as walls, floors, or roof/ceiling. For the purposes of this manual and the computation of the U_o , the Overall Thermal Transmittance does not include infiltration, ventilation, or ducts.

"Thermal Resistance" or "R-value" is the reciprocal of the thermal conductance $\text{h} \times \text{ft}^2 \times ^\circ\text{F}/\text{Btu}$. It is a measure of a material's resistance to heat flow.

"Building Thermal Envelope" means the collection of all elements of a building that enclose conditioned spaces through which thermal energy may be transferred between the conditioned spaces and the exterior and/or unconditioned spaces.

"Ceiling" means those portions of the building envelope included in and associated with the roof/ceiling assembly; including any fenestration, vertical elements, skylights, skylight shafts, transitions, and recessed entries.

"Walls" mean those portions of the building envelope included in and associated with the wall assembly; including fenestration, doors, and internal partitions separating the conditioned space from the unconditioned space.

"Floor" means those portions of the building envelope included in and associated with the floor assembly. Bandjoists are considered to be elements of the floor.

"Window" or "Glazing" means any light-transmitting section in a building wall or roof.

"Ceiling Area" means the total interior surface of the ceiling assembly, including all roof/ceiling and skylight components.

"Wall Area" means the total interior surface of the wall assembly enclosing the conditioned space, including any windows and doors that are a part of this assembly.

"Floor Area" means the area of the conditioned space measured at floor level from the interior surfaces of the walls.

"Conditioned Space" means the volume within a building that is designed to be heated and/or cooled, directly or indirectly, or any space containing an uninsulated heating or cooling duct.

"Unconditioned Space" means a volume within a building that is not designed to be directly or indirectly heated and/or cooled. Included as unconditioned space are spaces with exterior ventilation, such as vented utility spaces and vented roof cavities.

"Infiltration" means the uncontrolled inward or outward air leakage through cracks and crevices in any building element and around windows and doors of a building.

"Ventilation" means the process of supplying or removing air by natural or mechanical means to or from any space. Such air may or may not have been conditioned.

"Orientation" means the directional placement with reference to the building's longest horizontal axis, or, if none, with reference to the designated main entrance. For a window or wall the orientation is with reference to a line perpendicular to the predominate plane pointing outward from the conditioned space.

"Heating Load" means the rate at which heat must be added to a space to maintain a specified constant air temperature. A heating load exists when the exterior temperature is sufficiently low so as to require additional heat input specifically to maintain the space at a specified temperature.

"Cooling Load" means the rate at which heat must be removed from the space to maintain a specified constant air temperature. A cooling load exists when the combination of heat inputs (through the exterior surface, through windows, and from various interior sources) to the interior space is sufficiently high such that it requires the extraction of heat to maintain the specified constant temperature.

APPENDIX B

MATERIAL R-VALUES

APPENDIX B

MATERIAL R-VALUES

The following material R-values must be used in the U-value calculations.

TABLE B.1. Building Materials R-values ($h \times ft^2 \times ^\circ F/Btu$)

	<u>R-value</u>	<u>Material Description</u>
Framing members	1.88	2x2 (or lateral heat flow through nominal 2in.)
	3.13	2x3
	4.38	2x4
	6.88	2x6
	9.38	2x8
	11.88	2x10
Air films ^(a)	0.17	exterior wall or roof
	0.61	ceiling, interior
	0.68	wall, interior
	0.92	floor, interior or exterior
Air spaces ^(b)	0.00	for all vented air spaces
	0.75	ceiling, 0.5-in. space or smaller
	0.77	ceiling, 0.75-in. space
	0.80	ceiling, 1.5-in. space
	0.84	ceiling, 3.5-in. space or larger

(a) The inside surfaces resistances all assume winter conditions of heat flow, with heat flow up in ceiling and down in floor. An emissivity of 0.9 was assumed. R-values for surfaces with other emittances may be taken from the 1989 ASHRAE Fundamentals Handbook, Table 1, page 22.2, or interpreted within the range of the table. However, material emittances other than 0.9 must be based on documented tests.

(b) These values come from the 1989 ASHRAE Fundamentals Handbook, Table 2, pages 22.2 and 22.3. All values assume a mean temperature of 50°F, a temperature difference of 30°F, and an emissivity of 0.82. Other values may be extrapolated from the same table. Extrapolated values should always assume a mean temperature of 50°F and a temperature difference of 30°F. Interpolations of air space R-values for emittances and air space thickness within the range presented in the tables are permitted. Emittances other than 0.82 must be supported by a documented test of the materials.

TABLE B.1. contd

	<u>R-value</u>	<u>Material Description</u>
Air spaces (contd)	0.90	wall, 0.5-in. space or smaller
	0.94	wall, 0.75-in. space
	0.90	wall, 1.5-in. space
	0.91	wall, 3.5-in. space or larger
	0.91	floor, 0.5-in. space or smaller
	1.02	floor, 0.75-in. space
	1.14	floor, 1.5-in. space
	1.22	floor, 3.5-in. space or larger
Boards/siding	0.28	gypsum board, 5/16 in.
	0.32	gypsum board, 3/8 in.
	0.45	gypsum board, 1/2 in.
	0.82	particle board, 5/8 in.
	0.67	sheathing, 7/16-in. hardboard siding
	0.00	bottom board (thin material holding insulation in place)
	1.25	R-value per in. for unknown wood
	0.00	metal siding or roofing
Floor coverings	0.05	vinyl
	1.23	carpet with rubber pad
	2.08	carpet with fibrous pad
typical Insulation ^(a)	2.8-3.7/in.	mineral fiber batt
	5.0/in.	expanded polystyrene, extruded
	3.8-4.4/in.	expanded polystyrene, molded beads
	3.1-3.7/in.	cellulosic loose-fill (paper or wood)
	2.2-2.9/in.	mineral fiber loose-fill

(a) These are representative values for insulation. Insulation manufacturer's values for the insulation installed in the home should be used in the calculations for a specific home.

APPENDIX C

LOAD CALCULATION TABLES AND WEATHER DATA FOR LOAD CALCULATION

APPENDIX C

LOAD CALCULATION TABLES AND WEATHER DATA FOR LOAD CALCULATION

This appendix contains tables for use in the heating and cooling load calculations.

TABLE C.1. Cooling Load Temperature Difference (CLTD) Values

Mean Daily Temp Range (MDR) ^b	Summer Design Temperature (°F) ^a											
	85		90			95			100		105	110
	L	M	L	M	H	L	M	H	M	H	H	H
<i>All walls and doors</i>												
North	8	3	13	8	3	18	13	8	18	13	18	23
Northeast or Northwest	14	9	19	14	9	24	19	14	24	19	24	29
East or West	18	13	23	18	13	28	23	18	28	23	28	33
Southeast or Southwest	16	11	21	16	11	26	21	16	26	21	26	31
South	11	6	16	11	6	21	16	11	21	16	21	26
Unknown	13	8	18	13	8	23	18	13	23	18	23	28
<i>Roofs and ceiling</i>												
Attic or flat built up	42	37	47	42	37	51	47	42	51	47	51	56
<i>Floor, ceiling, partitions</i>												
Under conditioned space, over unconditioned room, over crawl space. Includes partitions to unconditioned spaces or shaded partitions.	9	4	12	9	4	14	12	9	14	12	14	19

Notes:

- (a) Take summer design temperature from column labelled 'SDB' in Table C.6.
- (b) These designate a Low, Medium, or High mean daily temperature range (MDR). Find the MDR column on Table C.6.

TABLE C.2. Window Glass Load Factors (GLF)

	Summer Design Temperature (°F) ^a					
	<u>85</u>	<u>90</u>	<u>95</u>	<u>100</u>	<u>105</u>	<u>110</u>
North	26	28	32	37	39	42
Northeast or Northwest	48	49	54	59	60	65
East or West	67	68	73	77	79	83
Southeast or Southwest	60	61	66	70	72	77
South	40	42	47	51	53	57
Horizontal	17	118	122	126	127	131
Unknown	48	50	54	59	61	65

TABLE C.3. Summer Air Exchange Rates (ACH)

<u>Construction</u> ^b	Outdoor Design Temperature (°F) ^a					
	<u>85</u>	<u>90</u>	<u>95</u>	<u>100</u>	<u>105</u>	<u>110</u>
Medium	0.46	0.48	0.50	0.52	0.54	0.56
Tight	0.33	0.34	0.35	0.36	0.37	0.38

TABLE C.4. Winter Air Exchange Rates (ACH)

<u>Construction</u> ^b	Outdoor Design Temperature (°F) ^c									
	<u>50</u>	<u>40</u>	<u>30</u>	<u>20</u>	<u>10</u>	<u>0</u>	<u>-10</u>	<u>-20</u>	<u>-30</u>	<u>-40</u>
Medium	0.69	0.73	0.77	0.81	0.85	0.89	0.93	0.97	1.00	1.05
Tight	0.41	0.43	0.45	0.47	0.49	0.51	0.53	0.55	0.57	0.59

Notes:

- (a) From column labelled 'SDB' in Table C.6.
- (b) All houses are of medium construction unless an air infiltration barrier is installed. If detailed engineering estimates of design air exchange rates are available, they may be used in lieu of those in Tables C.3 and C.4.
- (c) From column labelled 'WDB' in Table C.6.

TABLE C.5. House Tightness Factors

<u>Construction^a</u>	<u>Tightness Factor</u>
Medium	42
Tight	35

Notes:

- (a) All houses are of medium construction unless an air infiltration barrier is installed. If detailed engineering estimates of design air exchange rates are available, they may be used in lieu of those in Tables C.3 and C.4.

TABLE C.6 DESIGN WEATHER PARAMETERS

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
ALABAMA							CALIFORNIA, continued.						
Alexander City	22	93	0.016	M	0.74	8	Burbank	39	91	0.010	M	0.78	4
Anniston	22	94	0.016	M	0.76	9	Chico	30	101	0.008	H	0.99	8
Auburn	22	93	0.016	M	0.72	8	Concord	27	97	0.009	H	0.92	6
Birmingham	21	94	0.015	M	0.78	9	Covina	35	95	0.009	H	0.78	5
Decatur	16	93	0.014	M	0.80	7	Crescent City	33	65	0.009	M	1.07	-19
Dothan	27	92	0.016	M	0.67	7	Downey	40	89	0.012	M	0.77	3
Florence	21	94	0.014	M	0.81	8	El Cajon	44	80	0.013	H	0.73	-10
Gadsden	20	94	0.015	M	0.78	8	El Cerrito	38	110	0.011	H	0.73	18
Huntsville	16	93	0.014	M	0.80	7	Escondido	41	85	0.011	H	0.74	-5
Mobile AP	29	93	0.017	M	0.65	9	Eureka/Arcata	33	65	0.009	L	1.04	-16
Mobile Co	29	93	0.017	M	0.65	10	Fairfield-Travis AFB	32	95	0.008	H	0.94	3
Montgomery	25	95	0.016	M	0.71	10	Fresno	30	100	0.009	H	0.88	8
Seale-Craig AFB	26	95	0.016	M	0.71	10	Hamilton AFB	32	84	0.010	H	0.93	-5
Talladega	22	94	0.016	M	0.75	9	Laguna Beach	43	80	0.012	M	0.76	-4
Tuscaloosa	23	96	0.015	M	0.75	10	Livermore	27	97	0.009	M	0.91	10
ALASKA							Lompoc, Vandenberg AFB	38	70	0.010	M	0.80	-15
Anchorage	-18	88	0.008	L	1.79	-15	Long Beach	43	80	0.012	M	0.77	-6
Barrow	-41	53	0.007	L	2.17	-28	Los Angeles AP	43	80	0.012	L	0.77	-3
Fairbanks	-47	78	0.007	M	1.93	-9	Los Angeles CO	40	89	0.012	M	0.78	4
Juneau	1	70	0.008	L	1.69	-13	Merced-Castle AFB	31	99	0.009	H	0.90	6
Kodiak	13	65	0.008	L	1.67	-15	Modesto	30	98	0.008	H	0.91	5
Nome	-27	62	0.008	L	1.92	-18	Monterey	38	71	0.009	M	0.87	-14
ARIZONA							Napa	32	96	0.009	H	0.93	6
Douglas	31	95	0.006	H	0.68	5	Needles	33	110	0.008	H	0.80	22
Flagstaff	4	83	0.010	L	0.82	2	Oakland	36	80	0.009	M	0.92	-5
Fort Huachuca	28	92	0.006	H	0.68	4	Oceanside	43	80	0.012	L	0.75	-2
Kingman	25	100	0.005	H	0.82	10	Ontario	33	99	0.009	H	0.78	6
Nogales	32	96	0.006	H	0.68	6	Oxnard	36	80	0.009	M	0.78	-5
Phoenix	34	107	0.009	H	0.75	19	Palmdale	22	101	0.006	H	0.80	9
Prescott	9	94	0.004	H	0.80	4	Pala Springs	35	110	0.007	H	0.77	18
Tucson	32	102	0.006	H	0.70	14	Pasadena	35	95	0.009	H	0.78	6
Winslow	10	95	0.004	H	0.81	4	Petaluma	29	90	0.009	H	0.93	-1
Yuma	39	109	0.009	H	0.72	21	Pomona Co	30	99	0.009	H	0.78	6
ARKANSAS							Redding	31	102	0.007	H	1.02	11
Blytheville AFB	15	94	0.017	M	0.85	9	Redlands	33	99	0.009	H	0.78	8
Camden	23	96	0.015	M	0.76	11	Richmond	36	80	0.009	M	0.92	-4
El Dorado	23	96	0.015	M	0.75	11	Riverside-March AFB	32	98	0.008	H	0.77	5
Fayetteville	12	94	0.013	M	0.85	8	Sacramento	32	98	0.010	H	0.94	5
Fort Smith	17	98	0.015	M	0.82	11	Salinas	32	70	0.009	M	0.88	-17
Hot Springs	23	97	0.013	M	0.79	11	San Bernardino, Norton AFB	33	99	0.009	H	0.78	5
Jonesboro	15	94	0.017	M	0.84	9	San Diego	44	80	0.013	L	0.73	-1
Little Rock	20	94	0.017	M	0.80	8	San Fernando	39	91	0.010	H	0.79	-3
Pine Bluff	22	97	0.016	M	0.79	11	San Francisco AP	38	77	0.009	M	0.91	-8
Texarkana	23	96	0.016	M	0.75	11	San Francisco Co	40	71	0.010	L	0.92	-11
CALIFORNIA							San Jose	36	81	0.010	H	0.90	-7
Bakersfield	32	101	0.008	H	0.83	10	San Luis Obispo	35	88	0.012	H	0.82	0
Barstow	29	104	0.007	H	0.81	11	Santa Ana	39	85	0.011	H	0.77	-4
Blythe	33	110	0.008	H	0.76	21	Santa Barbara MAP	36	77	0.011	M	0.79	-10
Column Legend:							Santa Cruz	38	71	0.009	H	0.89	-18
WDB = Winter Dry Bulb design temperature (°F)							Santa Maria	33	76	0.010	M	0.81	-11
SDB = Summer Dry Bulb design temperature (°F)							Santa Monica CIC	43	80	0.012	M	0.78	-3
HUM = design HUMidity ratio (lb H ₂ O/lb dry air)							Santa Paula	35	86	0.010	H	0.79	-7
MDR = Mean Daily temperature Range (°F)							Santa Rosa	29	95	0.008	H	0.94	3
SEF = Southern Exposure Factor							Stockton	30	97	0.009	H	0.92	4
TAF = Temperature Adjustment Factor							Ukiah	29	95	0.009	H	0.97	0
Location Legend:							Visalia	30	100	0.009	H	0.86	6
AP = AirPort							Yreka	17	92	0.007	H	1.06	-2
AFB = Air Force Base							Yuba City	31	101	0.007	H	0.97	8
Co = office locations in urban area							COLORADO						
							Alamosa	-16	72	0.007	H	0.90	-21
							Boulder	8	91	0.004	H	1.00	3
							Colorado Springs	2	88	0.003	H	0.96	-2
							Denver	1	91	0.004	H	0.99	2
							Durango	4	87	0.005	H	0.90	-3
							Fort Collins	-4	91	0.004	M	1.03	4
							Grand Junction	7	94	0.003	H	0.97	5

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
COLORADO, continued.							HAWAII						
Greeley	-5	94	0.004	H	1.02	5	Hilo	62	83	0.015	L	0.24	1
Lajunta	3	98	0.008	H	0.93	8	Honolulu	63	86	0.015	L	0.30	5
Leadville	-4	81	0.002	H	0.97	-9	Kaneohe Bay MCAS	66	84	0.018	L	0.30	3
Pueblo	0	95	0.004	H	0.94	5	Wahiawa	59	85	0.014	L	0.29	3
Sterling	-2	93	0.005	H	1.02	3	IDAHO						
Trinidad	3	91	0.005	H	0.90	0	Boise	10	94	0.008	H	1.13	4
CONNECTICUT							Burley	2	95	0.004	H	1.10	3
Bridgeport	9	84	0.014	M	1.04	0	Coeur D'Alene	-1	86	0.008	H	1.29	-5
Hartford, Brainard Field	7	88	0.014	M	1.07	2	Idaho Falls	-6	87	0.008	H	1.13	-7
New Haven	7	84	0.015	M	1.05	1	Lewiston	6	93	0.007	H	1.24	2
New London	9	85	0.014	M	1.05	2	Moscow	0	87	0.007	H	1.25	-4
Norwalk	9	84	0.014	M	1.04	-1	Mountain Home AFB	12	97	0.005	H	1.11	4
Norwick	7	86	0.015	M	1.06	2	Pocatello	-1	91	0.004	H	1.11	-2
Waterbury	2	85	0.013	M	1.06	-1	Twin Falls	2	95	0.004	H	1.09	3
Windsor Locks, Bradley Fld	4	88	0.014	M	1.07	2	ILLINOIS						
DELAWARE							Aurora	-1	91	0.018	M	1.07	6
Dover	15	90	0.018	M	0.97	6	Belleville, Scott AFB	6	92	0.018	M	0.95	7
Wilmington	14	89	0.015	M	0.99	4	Bloomington	-2	90	0.015	M	1.02	5
DISTRICT OF COLUMBIA							Carbondale	7	93	0.017	M	0.92	8
Andrews AFB	14	90	0.015	M	0.93	6	Champaign/Urbana	2	92	0.014	M	1.00	7
Washington, National	17	91	0.015	M	0.96	7	Chicago, Midway AP	0	91	0.014	M	1.07	6
FLORIDA							Chicago, O'Hare AP	-4	89	0.015	M	1.07	4
Belle Glade	44	91	0.018	M	0.50	8	Chicago Co	2	91	0.015	L	1.07	9
Cape Kennedy	38	88	0.019	L	0.57	6	Danville	1	90	0.015	M	1.01	5
Daytona Beach	35	90	0.017	L	0.59	8	Decatur	2	91	0.015	M	0.99	6
E Fort Lauderdale	46	91	0.018	L	0.48	9	Dixon	-2	90	0.015	M	1.07	4
Fort Myers	44	92	0.018	M	0.50	8	Elgin	-2	88	0.015	M	1.08	3
Fort Pierce	42	90	0.018	L	0.53	8	Freeport	-4	89	0.014	M	1.09	2
Gainesville	31	93	0.017	M	0.61	9	Galesburg	-2	91	0.015	M	1.04	5
Jacksonville	32	94	0.017	M	0.64	10	Greenville	4	92	0.015	M	0.98	7
Key West	57	90	0.018	L	0.42	11	Joliet	0	90	0.015	M	1.06	5
Lakeland Co	41	91	0.018	M	0.55	8	Kankakee	1	90	0.015	M	1.04	5
Miami AP	47	90	0.017	L	0.47	8	La Salle/Peru	-2	91	0.015	M	1.05	5
Miami Beach Co	48	89	0.018	L	0.47	9	Macomb	0	92	0.018	M	1.02	6
Ocala	34	93	0.017	M	0.59	9	Moline	-4	91	0.015	M	1.05	5
Orlando	38	93	0.018	M	0.57	10	Mt Vernon	5	92	0.015	M	0.94	7
Panama City, Tyndall AFB	33	90	0.017	L	0.63	8	Peoria	-4	89	0.015	M	1.03	3
Pensacola Co	29	93	0.017	L	0.64	11	Quincy	3	93	0.018	M	1.00	7
St. Augustine	35	89	0.019	M	0.62	6	Rantoul, Chanute AFB	1	91	0.015	M	1.01	6
St. Petersburg	40	91	0.017	M	0.54	8	Rockford	-4	89	0.014	M	1.09	2
Stanford	38	93	0.018	M	0.58	10	Springfield	2	92	0.014	M	0.99	7
Sarasota	42	92	0.017	M	0.53	9	Waukegan	-3	89	0.015	M	1.09	4
Tallahassee	30	92	0.018	M	0.64	8	INDIANA						
Tampa	40	91	0.017	M	0.55	8	Anderson	6	92	0.015	M	1.00	6
West Palm Beach	45	91	0.018	M	0.50	8	Bedford	5	92	0.015	M	0.98	6
GEORGIA							Bloomington	5	92	0.015	M	0.97	6
Albany, Turner AFB	29	95	0.018	M	0.69	10	Columbus, Bakalar AFB	7	92	0.015	M	0.97	6
Americus	25	94	0.018	M	0.70	9	Crawfordsville	3	91	0.015	M	1.00	5
Athens	22	92	0.014	M	0.77	7	Evanville	9	93	0.015	M	0.93	7
Atlanta	22	92	0.014	M	0.76	8	Fort Wayne	1	89	0.013	M	1.04	2
Augusta	23	95	0.018	M	0.75	11	Goshen	1	89	0.014	M	1.06	3
Brunswick	32	89	0.019	M	0.67	5	Hobart	2	88	0.014	M	1.06	3
Columbus, Lawson AFB	24	93	0.018	M	0.72	8	Huntington	1	89	0.013	M	1.03	3
Dalton	22	93	0.018	M	0.66	7	Indianapolis	2	90	0.015	M	0.99	4
Dublin	25	93	0.018	M	0.71	8	Jeffersonville	10	93	0.014	M	0.94	7
Gainesville	27	93	0.017	M	0.78	8	Kokomo	0	90	0.014	M	1.02	4
Griffin	22	90	0.018	M	0.75	5	Lafayette	3	91	0.014	M	1.00	5
LaGrange	23	91	0.015	M	0.74	6	La Porte	3	90	0.015	M	1.06	4
Macon	25	93	0.018	M	0.73	7	Marion	0	90	0.014	M	1.02	4
Marietta, Dobbins AFB	21	92	0.014	M	0.77	7	Muncie	2	90	0.014	M	1.01	4
Savannah	27	93	0.017	M	0.71	8	Peru, Grissom AFB	-1	88	0.014	M	1.02	2
Valdosta-Moody AFB	31	94	0.017	M	0.66	9	Richmond	2	90	0.015	M	0.99	4
Waycross	29	94	0.017	M	0.67	9	Shelbyville	3	91	0.015	M	0.98	5
							South Bend	1	89	0.014	M	1.06	3
							Terre Haute	4	92	0.014	M	0.98	6

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
INDIANA, continued.							MAINE						
Valparaiso	3	90	0.015	M	1.00	4	Augusta	-3	85	0.013	M	1.16	-1
Vincennes	6	92	0.014	M	0.95	6	Bangor, Dow AFB	-6	83	0.012	M	1.18	-3
IOWA							Caribou	-13	81	0.011	M	1.26	-6
Ames	-6	90	0.015	M	1.00	4	Lewiston	-2	85	0.013	M	1.15	-1
Burlington	-3	91	0.015	M	1.03	5	Millinocket	-9	83	0.012	M	1.21	-3
Cedar Rapids	-5	88	0.018	M	1.07	2	Portland	-1	84	0.014	M	1.14	-2
Clinton	-3	90	0.018	M	1.07	4	Waterville	-4	84	0.012	M	1.17	-2
Council Bluffs	-3	91	0.015	M	1.05	5	MARYLAND						
Des Moines	-5	91	0.015	M	1.06	5	Baltimore AP	13	91	0.015	M	0.97	6
Dubuque	-7	88	0.014	M	1.09	2	Baltimore Co	17	89	0.017	M	0.98	6
Fort Dodge	-7	88	0.015	M	1.10	2	Cumberland	10	89	0.015	M	0.99	3
Iowa City	-6	89	0.017	M	1.00	3	Frederick	12	91	0.015	M	0.98	5
Keokuk	0	92	0.015	M	1.02	6	Hagerstown	12	91	0.015	M	0.99	5
Marshalltown	-7	90	0.018	M	1.08	4	Salisbury	18	91	0.015	M	0.94	7
Mason City	-11	88	0.015	M	1.12	1	MASSACHUSETTS						
Newton	-5	91	0.015	M	1.00	5	Boston	9	88	0.013	M	1.09	5
Ottumwa	-4	91	0.015	M	1.04	5	Clinton	2	87	0.013	M	1.09	4
Sioux City	-7	92	0.014	M	1.09	5	Fall River	9	84	0.014	M	1.08	0
Waterloo	-10	89	0.018	M	1.10	3	Framingham	8	88	0.013	M	1.09	3
KANSAS							Gloucester	5	86	0.013	L	1.10	4
Atchison	2	93	0.018	M	0.98	7	Greenfield	-2	85	0.013	M	1.08	-2
Chanute	7	97	0.013	M	0.91	11	Lawrence	0	87	0.014	M	1.10	1
Dodge City	5	97	0.009	M	0.92	10	Lowell	1	88	0.014	M	1.10	3
El Dorado	7	98	0.012	M	0.92	11	New Bedford	9	82	0.014	M	1.06	-3
Emporia	5	97	0.013	M	0.94	10	Pittsfield	-3	84	0.013	M	1.09	-3
Garden City	4	96	0.018	H	0.92	7	Springfield, Westover AFB	0	87	0.013	M	1.08	3
Goodland	0	96	0.007	H	0.90	6	Taunton	9	86	0.014	M	1.07	2
Great Bend	4	98	0.012	H	0.94	9	Worcester	4	84	0.013	M	1.09	0
Hutchinson	8	99	0.011	H	0.93	10	MICHIGAN						
Liberal	7	96	0.009	H	0.89	7	Adrian	3	88	0.014	M	1.07	2
Manhattan, Ft Riley	3	95	0.015	M	0.96	8	Alpena	-6	85	0.013	H	1.19	-4
Parsons	9	97	0.013	M	0.90	11	Battle Creek	5	88	0.014	M	1.09	2
Russell	4	98	0.012	H	0.90	9	Benton Harbor	5	88	0.014	M	1.08	3
Salina	5	100	0.013	H	0.95	12	Detroit	6	58	0.014	M	1.09	3
Topeka	4	96	0.014	M	0.97	9	Escanaba	-7	83	0.012	M	1.22	-1
Wichita	7	98	0.012	M	0.91	12	Flint	1	87	0.014	M	1.11	-1
KENTUCKY							Grand Rapids	5	88	0.014	M	1.11	1
Ashland	10	91	0.015	M	0.95	5	Holland	NA	86	0.013	M	1.10	0
Bowling Green	10	92	0.015	M	0.85	7	Jackson	5	88	0.014	M	1.09	2
Corbin	9	92	0.014	M	0.89	6	Kalamazoo	5	88	0.014	M	1.09	2
Covington	6	90	0.013	M	0.90	4	Lansing	1	87	0.014	M	1.10	0
Hopkinsville, Ft Campbell	10	92	0.015	M	0.88	7	Marquette Co	-8	81	0.013	M	1.25	-3
Lexington	8	91	0.014	M	0.93	5	Mt Pleasant	4	87	0.014	M	1.13	0
Louisville	10	93	0.014	M	0.93	7	Muskegon	6	84	0.013	M	1.12	-2
Madisonville	10	93	0.015	M	0.90	7	Pontiac	4	87	0.014	M	1.10	2
Owensboro	10	94	0.015	M	0.92	8	Port Huron	4	87	0.014	M	1.11	0
Paducah	12	95	0.015	M	0.89	10	Saginaw	4	87	0.014	M	1.13	1
LOUISIANA							Sault Ste. Marie	-8	81	0.013	M	1.24	-6
Alexandria	27	94	0.017	M	0.88	9	Traverse City	1	86	0.013	M	1.18	0
Baton Rouge	29	93	0.017	M	0.84	9	Ypsilanti	5	89	0.013	M	1.08	3
Bogalusa	28	93	0.017	M	0.85	9	MINNESOTA						
Houma	35	93	0.018	L	0.81	11	Albert Lea	-12	87	0.014	M	1.14	0
Lafayette	30	94	0.018	M	0.83	10	Alexandria	-18	88	0.014	M	1.22	1
Lake Charles	31	93	0.017	M	0.83	10	Benidji	-26	85	0.012	M	1.28	-2
Minden	25	96	0.015	M	0.72	11	Brainerd	-18	87	0.013	M	1.24	0
Monroe	25	96	0.015	M	0.72	11	Duluth	-18	82	0.012	M	1.26	-4
Natchitoches	26	95	0.018	M	0.89	10	Faribault	-12	88	0.014	M	1.16	1
New Orleans	33	92	0.018	M	0.82	9	Fergus Falls	-17	88	0.014	M	1.24	1
Shreveport	25	96	0.015	M	0.72	11	International Falls	-25	83	0.012	H	1.32	-5
							Mankato	-12	88	0.014	M	1.16	1
							Minneapolis/St. Paul	-12	89	0.014	M	1.18	3

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
MINNESOTA, continued.							NEBRASKA, continued.						
Rochester	-12	87	0.014	M	1.15	0	McCook	-2	95	0.010	H	1.01	6
St. Cloud	-11	88	0.014	M	1.21	1	Norfolk	-4	93	0.014	H	1.07	3
Virginia	-21	83	0.012	M	1.28	-4	North Platte	-4	94	0.010	H	1.04	5
Willmar	-11	88	0.014	M	1.19	1	Omaha	-3	91	0.015	M	1.05	5
Winona	-10	88	0.014	M	1.15	1	Scottsbluff	-3	92	0.008	H	1.07	2
MISSISSIPPI							Sidney	-3	92	0.008	H	1.05	2
Biloxi, Keesler AFB	31	92	0.019	M	0.64	9	NEVADA						
Clarksdale	19	94	0.017	M	0.78	9	Carson City	9	91	0.004	H	0.97	-5
Columbus AFB	20	93	0.017	M	0.76	7	Elko	-2	92	0.004	H	1.03	-4
Greenville AFB	20	93	0.017	M	0.76	8	Ely	-4	87	0.003	H	0.97	-8
Greenwood	20	93	0.017	M	0.76	8	Las Vegas	20	100	0.005	H	0.85	16
Hattiesburg	27	94	0.017	M	0.67	9	Lovelock	12	96	0.005	H	1.00	0
Jackson	25	95	0.016	M	0.71	10	Reno AP	10	92	0.004	H	0.98	-6
Laurel	27	94	0.017	M	0.69	9	Reno Co	11	93	0.004	H	0.98	-5
McComb	26	94	0.016	M	0.67	10	Tonopah	10	92	0.004	H	0.93	-3
Meridian	23	95	0.016	M	0.71	9	Winnemucca	3	94	0.004	H	1.03	-2
Natchez	27	94	0.018	M	0.68	9	NEW HAMPSHIRE						
Tupelo	19	94	0.017	M	0.79	8	Berlin	-9	84	0.012	M	1.15	-2
Vicksburg Co	26	95	0.017	M	0.72	10	Claremont	-4	86	0.012	M	1.11	-1
MISSOURI							Concord	-3	87	0.012	H	1.12	-1
Cape Girardeau	13	95	0.015	M	0.90	10	Keene	-7	87	0.012	M	1.11	0
Columbia	4	94	0.014	M	0.96	8	Laconia	-5	86	0.012	M	1.11	-2
Farmington AP	8	93	0.015	M	0.92	7	Manchester, Grenier AFB	-3	88	0.013	M	1.11	1
Hannibal	3	93	0.016	M	0.99	7	Portsmouth, Pease AFB	2	85	0.013	M	1.12	-1
Jefferson City	7	95	0.014	M	0.95	9	NEW JERSEY						
Joplin	10	97	0.013	M	0.89	10	Atlantic City CO	13	89	0.015	M	0.98	5
Kansas City	6	96	0.014	M	0.97	11	Long Branch	13	90	0.014	M	1.01	6
Kirkaville	0	93	0.014	M	1.00	6	Newark	14	91	0.014	M	1.03	6
Mexico	4	94	0.014	M	0.97	8	New Brunswick	10	89	0.014	M	1.02	5
Moberly	3	94	0.014	M	0.98	8	Paterson	10	91	0.014	M	1.03	6
Poplar Bluff	16	95	0.016	M	0.88	9	Phillipsburg	6	89	0.013	M	1.03	4
Rolla	9	91	0.015	M	0.92	5	Trenton Co	14	88	0.015	M	1.01	4
St. Joseph	2	93	0.016	M	0.99	7	Vineland	11	89	0.015	M	0.98	5
St. Louis AP	6	94	0.015	M	0.95	9	NEW MEXICO						
St. Louis CO	8	94	0.015	M	0.95	10	Alamogordo, Holloman AFB	19	96	0.006	H	0.73	6
Sedalia, Whiteman AFB	4	92	0.016	M	0.95	0	Albuquerque	16	94	0.004	H	0.81	6
Sikeston	15	95	0.016	M	0.88	10	Artesia	19	100	0.007	H	0.73	-10
Springfield	9	93	0.014	M	0.90	7	Carlsbad	19	100	0.007	H	0.71	11
MONTANA							Clovis	13	93	0.007	H	0.79	4
Billings	-10	91	0.007	H	1.22	1	Farmington	6	93	0.005	H	0.88	3
Bozeman	-14	87	0.005	H	1.22	-4	Gallup	5	89	0.004	H	0.83	-2
Butte	-17	83	0.004	H	1.22	-10	Grants	4	88	0.004	H	0.82	-3
Cut Bank	-20	85	0.006	H	1.32	-8	Hobbs	18	90	0.007	H	0.73	10
Glasgow	-18	89	0.007	H	1.32	-1	Las Cruces	20	96	0.006	H	0.71	6
Glendive	-13	92	0.007	H	1.27	3	Los Alamos	9	87	0.005	H	0.84	-4
Great Falls	-15	88	0.005	H	1.28	-1	Raton	1	89	0.005	H	0.88	-3
Havre	-11	90	0.007	H	1.32	-2	Roswell, Walker AFB	10	98	0.007	H	0.75	7
Helena	-16	88	0.005	H	1.25	-3	Santa Fe CO	10	88	0.006	H	0.84	-1
Kalispell	-7	87	0.006	H	1.31	-5	Silver City	10	94	0.004	H	0.72	4
Lewiston	-16	87	0.006	H	1.26	-3	Socorro	17	95	0.005	H	0.78	5
Livingston	-14	87	0.005	H	1.21	-4	Tucumcari	13	97	0.007	H	0.82	8
Miles City	-15	95	0.008	H	1.24	5	NEW YORK						
Missoula	-6	88	0.006	H	1.26	-5	Albany AP	-1	88	0.014	M	1.10	2
NEBRASKA							Albany Co	1	88	0.014	M	1.10	3
Beatrice	-2	95	0.014	M	1.01	8	Auburn	2	87	0.014	M	1.11	1
Chadron	-3	94	0.007	M	1.11	4	Batavia	5	87	0.013	M	1.11	1
Columbus	-2	95	0.013	M	1.06	8	Binghamton	1	83	0.012	M	1.08	-2
Fremont	-2	95	0.014	M	1.05	9	Buffalo	6	85	0.013	M	1.11	-1
Grand Island	-3	94	0.012	H	1.04	5	Cortland	0	85	0.013	M	1.10	-2
Hastings	-3	94	0.012	H	1.02	6	Dunkirk	9	85	0.014	M	1.09	1
Kearney	-4	93	0.011	H	1.03	4	Elmira	1	86	0.013	M	1.08	-1
Lincoln Co	-2	95	0.014	M	1.03	8							

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
NEW YORK, continued.							OHIO, continued.						
Geneva	2	87	0.013	M	1.10	1	Defiance	4	91	0.014	M	1.05	4
Glens Falls	-5	85	0.013	M	1.13	-2	Findlay	3	90	0.014	M	1.04	3
Gloversville	-2	86	0.013	M	1.11	-1	Fresno	1	88	0.014	M	1.05	1
Hornell	0	85	0.013	M	1.09	-2	Hamilton	5	90	0.013	M	0.98	4
Ithaca	0	85	0.013	M	1.09	-2	Lancaster	5	91	0.014	M	0.99	5
Jamestown	3	86	0.012	M	1.08	1	Lima	4	91	0.014	M	1.03	4
Kingston	2	88	0.014	M	1.07	2	Mansfield	5	87	0.014	M	1.03	1
Lockport	7	86	0.014	M	1.12	1	Marion	5	91	0.014	M	1.02	5
Massena	-8	83	0.012	M	1.19	-2	Middletown	5	90	0.013	M	0.98	4
Newburgh, Stewart AFB	4	88	0.014	M	1.06	3	Newark	5	92	0.014	M	1.00	6
NYC-Central Park	15	89	0.014	M	1.03	6	Norwalk	1	88	0.014	M	1.05	2
NYC-Kennedy AP	15	87	0.014	M	1.02	4	Portsmouth	10	92	0.014	M	0.95	6
NYC-La Guardia AP	15	89	0.014	M	1.03	6	Sandusky Co	6	91	0.013	M	1.05	6
Niagara Falls	7	86	0.014	M	1.12	1	Springfield	3	89	0.014	M	0.99	4
Olean	2	84	0.014	M	1.08	-3	Staubenville	5	86	0.013	M	1.01	0
Oneonta	-4	83	0.012	M	1.09	-4	Toledo	1	88	0.014	M	1.06	1
Oswego Co	7	83	0.014	M	1.13	-2	Warren	5	87	0.013	M	1.05	1
Plattsburg AFB	-8	83	0.012	M	1.17	-3	Wooster	6	86	0.013	M	1.03	0
Poughkeepsie	6	89	0.015	M	1.06	4	Youngstown	4	86	0.013	M	1.05	-1
Rochester	5	88	0.013	M	1.12	2	Zanesville	7	90	0.015	M	1.00	4
Rome, Griffiss AFB	-5	85	0.013	M	1.12	-1	OKLAHOMA						
Schenectady	1	87	0.014	M	1.11	1	Ada	14	97	0.013	M	0.80	11
Suffolk County AFB	10	83	0.014	M	1.03	0	Altus AFB	16	100	0.012	M	0.80	13
Syracuse	2	87	0.013	M	1.12	2	Ardmore	17	98	0.013	M	0.79	12
Utica	-6	85	0.013	M	1.12	-1	Bartlesville	10	98	0.013	M	0.88	12
Watertown	-6	83	0.014	M	1.15	-2	Chickasha	14	98	0.013	M	0.81	11
NORTH CAROLINA							Enid, Vance AFB	13	100	0.013	M	0.86	13
Asheville	14	87	0.014	M	0.83	2	Lawton	16	99	0.013	M	0.86	12
Charlotte	22	93	0.014	M	0.82	8	McAlester	19	96	0.014	M	0.81	10
Durham	20	92	0.015	M	0.84	7	Muskogee	15	98	0.014	M	0.84	12
Elizabeth City	19	91	0.017	M	0.86	7	Norman	13	96	0.014	M	0.82	9
Fayetteville, Pope AFB	20	92	0.016	M	0.82	7	Oklahoma City	13	97	0.013	M	0.83	11
Goldsboro, Seymour-Johnson	21	91	0.016	M	0.82	7	Ponca City	9	97	0.013	M	0.88	10
Greensboro	18	91	0.014	M	0.85	6	Seminole	15	96	0.014	M	0.82	10
Greenville	21	91	0.016	M	0.84	7	Stillwater	13	96	0.014	M	0.86	9
Henderson	15	92	0.016	M	0.86	7	Tulsa	13	98	0.014	M	0.86	12
Hickory	18	90	0.013	M	0.84	5	Woodward	10	97	0.013	H	0.87	9
Jacksonville	24	90	0.016	M	0.81	6	OREGON						
Lumberton	21	92	0.016	M	0.80	7	Albany	22	89	0.009	H	1.17	-2
New Bern	24	90	0.016	M	0.82	6	Astoria	29	71	0.010	M	1.23	-12
Raleigh/Durham	20	92	0.015	M	0.84	7	Baker	6	89	0.006	H	1.18	-1
Rocky Mount	21	91	0.016	M	0.85	7	Bend	4	87	0.005	H	1.15	-5
Wilmington	26	91	0.018	M	0.79	7	Corvallis	22	89	0.009	H	1.17	-2
Winston-Salem	20	91	0.014	M	0.86	6	Eugene	22	89	0.009	H	1.15	-2
NORTH DAKOTA							Grants Pass	24	96	0.009	H	1.09	5
Bismarck	-19	91	0.010	H	1.25	3	Klamath Falls	9	87	0.005	H	1.08	-6
Devils Lake	-21	88	0.011	M	1.30	1	Medford	23	94	0.009	H	1.09	2
Dickinson	-17	90	0.009	M	1.26	3	Pendleton	5	93	0.007	H	1.21	4
Fargo	-18	89	0.013	M	1.26	2	Portland AP	23	85	0.010	M	1.21	-2
Grand Forks	-22	87	0.012	M	1.30	-1	Portland Co	24	86	0.010	M	1.21	1
Jamestown	-18	90	0.011	H	1.26	2	Roseburg	23	90	0.009	H	1.12	0
Minot	-20	89	0.010	M	1.32	2	Salem	23	88	0.009	H	1.18	-3
Williston	-21	88	0.010	M	1.31	1	The Dalles	19	89	0.010	H	1.21	0
OHIO							PENNSYLVANIA						
Akron-Canton	6	86	0.013	M	1.03	1	Allentown	9	88	0.014	M	1.02	2
Ashtabula	9	85	0.014	M	1.07	1	Altoona Co	5	87	0.013	M	1.01	1
Athens	6	92	0.014	M	0.98	6	Butler	6	87	0.014	M	1.03	1
Bowling Green	2	89	0.014	M	1.05	3	Chambersburg	8	90	0.015	M	1.00	4
Cambridge	7	90	0.015	M	1.00	4	Erie	9	85	0.014	M	1.00	1
Chillicothe	6	92	0.014	M	0.98	6	Harrisburg	11	91	0.015	M	1.01	6
Cincinnati Co	6	90	0.013	M	0.97	5	Johnstown	2	83	0.013	M	1.01	-4
Cleveland	5	88	0.014	M	1.05	2	Lancaster	8	90	0.015	M	1.00	4
Columbus	5	90	0.014	M	1.00	3	Meadville	4	85	0.013	M	1.06	-1
Dayton	4	89	0.013	M	1.00	4	New Castle	7	88	0.014	M	1.04	2

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF		WDB	SDB	HUM	MDR	SEF	TAF
PENNSYLVANIA, continued.							TEXAS, continued.						
Philadelphia	14	90	0.015	M	1.00	5	Brownsville	39	93	0.017	M	0.47	9
Pittsburgh AP	5	86	0.013	M	1.02	0	Brownwood	22	99	0.012	M	0.69	13
Pittsburgh Co	7	88	0.013	M	1.02	4	Bryan	29	96	0.015	M	0.65	11
Reading Co	13	89	0.013	M	1.01	5	Corpus Christi	35	94	0.018	M	0.54	10
Scranton/Wilkes-Barre	5	87	0.013	M	1.05	3	Corsicana	25	98	0.014	M	0.70	13
State College	7	87	0.013	M	1.03	1	Dallas	22	100	0.014	M	0.73	15
Sunbury	7	89	0.013	M	1.03	3	Del Rio, Laughlin AFB	31	98	0.012	M	0.60	11
Uniontown	9	88	0.014	M	1.00	2	Denton	22	99	0.013	M	0.75	13
Warren	4	86	0.013	M	1.07	-1	Eagle Pass	32	99	0.012	M	0.58	12
West Chester	13	89	0.015	M	1.00	4	El Paso	24	98	0.006	H	0.69	10
Williamsport	7	89	0.013	M	1.05	3	Fort Worth	22	99	0.013	M	0.73	13
York	12	91	0.015	M	1.00	5	Galveston	36	89	0.020	L	0.60	9
RHODE ISLAND							Greenville	22	99	0.013	M	0.74	14
Newport	9	85	0.014	M	1.06	2	Harlingen	39	94	0.017	M	0.48	10
Providence	9	86	0.014	M	1.07	2	Houston AP	32	94	0.017	M	0.62	10
SOUTH CAROLINA							Houston Co	33	95	0.016	M	0.62	11
Anderson	23	92	0.014	M	0.79	7	Huntsville	27	98	0.014	M	0.65	13
Charleston AFB	27	91	0.018	M	0.73	7	Killeen, Robert Gray AAF	25	97	0.013	M	0.67	11
Charleston Co	28	92	0.018	L	3.73	11	Lamesa	17	96	0.010	H	0.73	8
Columbia	24	95	0.015	M	0.77	9	Laredo AFB	38	101	0.012	M	0.53	15
Florence	25	92	0.017	M	0.78	7	Longview	24	97	0.015	M	0.72	12
Georgetown	26	90	0.018	M	0.75	6	Lubbock	15	96	0.010	H	0.76	8
Greenville	22	91	0.015	M	0.81	6	Lufkin	29	97	0.015	M	0.68	12
Greenwood	22	93	0.014	M	0.78	8	McAllen	39	95	0.016	M	0.48	10
Orangeburg	24	95	0.015	M	0.76	10	Midland	21	98	0.009	H	0.70	10
Rock Hill	23	94	0.014	M	0.81	9	Mineral Wells	22	99	0.013	M	0.73	13
Spartanburg	22	91	0.015	M	0.81	6	Palestine Co	27	98	0.015	M	0.69	13
Sumter, Shaw AFB	25	92	0.016	M	0.77	7	Pampa	12	96	0.008	H	0.83	8
SOUTH DAKOTA							Pecos	21	98	0.009	H	0.68	10
Aberdeen	-15	91	0.013	H	1.20	3	Plainview	13	96	0.009	H	0.78	8
Brookings	-13	92	0.013	M	1.16	5	Port Arthur	31	93	0.018	M	0.62	9
Huron	-14	93	0.013	H	1.16	4	San Angelo, Goodfellow AFB	22	99	0.010	M	0.68	12
Mitchell	-10	93	0.012	H	1.14	4	San Antonio	30	97	0.013	M	0.61	13
Pierre	-10	95	0.011	H	1.16	6	Sherman, Perrin AFB	20	98	0.014	M	0.76	12
Rapid City	-7	92	0.008	H	1.15	3	Snyder	18	98	0.010	H	0.73	10
Sioux Falls	-11	91	0.013	M	1.13	4	Temple	27	99	0.013	M	0.67	13
Watertown	-15	91	0.013	H	1.18	3	Tyler	24	97	0.015	M	0.71	12
Yankton	-7	91	0.013	M	1.11	4	Vernon	17	100	0.012	M	0.78	13
TENNESSEE							Victoria	32	96	0.016	M	0.58	12
Athens	18	92	0.014	M	0.83	8	Waco	26	99	0.014	M	0.69	13
Bristol-Tri City	14	89	0.013	M	0.87	3	Wichita Falls	18	101	0.012	M	0.77	14
Chattanooga	18	93	0.014	M	0.81	7	UTAH						
Clarksville	12	93	0.014	M	0.87	8	Cedar City	5	91	0.004	H	0.91	0
Columbia	15	94	0.014	M	0.84	9	Logan	2	91	0.005	H	1.07	-1
Dyersburg	15	94	0.017	M	0.85	9	Moab	11	98	0.003	H	0.95	8
Greenville	16	90	0.013	M	0.85	4	Ogden	5	91	0.005	H	1.05	-1
Jackson	16	95	0.015	M	0.84	10	Price	5	91	0.004	H	0.99	-1
Knoxville	19	92	0.014	M	0.84	7	Provo	6	96	0.005	H	1.01	5
Memphis	18	95	0.016	M	0.81	10	Richfield	5	91	0.004	H	0.95	-1
Murfreesboro	14	94	0.014	M	0.81	8	St George Co	21	101	0.006	H	0.89	10
Nashville	14	94	0.014	M	0.85	9	Salt Lake City	8	95	0.005	H	1.03	4
Tullahoma	13	93	0.013	M	0.83	7	Vernal	0	89	0.005	H	1.02	-2
TEXAS							VERMONT						
Abilene	20	99	0.010	M	0.72	13	Barre	-11	81	0.013	M	1.16	-6
Alice	34	98	0.016	M	0.54	13	Burlington	-7	85	0.013	M	1.17	-2
Amarillo	11	95	0.008	H	0.82	7	Rutland	-8	84	0.013	M	1.13	-3
Austin	28	98	0.013	M	0.64	12	VIRGINIA						
Bay City		33	94	0.017	M	0.59	Charlottesville	18	91	0.015	M	0.93	5
Beaumont	31	93	0.018	M	0.62	9	Danville	16	92	0.014	M	0.87	7
Beeville	33	97	0.016	M	0.56	13	Fredericksburg	14	93	0.015	M	0.94	8
Big Spring		20	97	0.009	H	0.71	Harrisonburg	16	91	0.013	M	0.94	5
	9						Lynchburg	16	90	0.015	M	0.90	5
							Norfolk	22	91	0.016	M	0.88	7

TABLE C.6. contd

	WDB	SDB	HUM	MDR	SEF	TAF
VIRGINIA, continued.						
Petersburg	17	92	0.016	M	0.89	7
Richmond	17	92	0.016	M	0.91	7
Roanoke	16	91	0.013	M	0.90	5
Staunton	16	91	0.013	M	0.94	5
Winchester	18	90	0.015	M	0.97	5
WASHINGTON						
Aberdeen	28	77	0.009	M	1.26	-8
Bellingham	15	77	0.011	M	1.33	-8
Bremerton	25	78	0.010	M	1.28	-7
Ellensburg	6	91	0.007	H	1.26	-1
Everett, Paine AFB	25	76	0.010	M	1.30	-9
Kennewick	11	96	0.008	H	1.23	6
Longview	24	85	0.010	H	1.23	-5
Moses Lake, Larson AFB	7	94	0.007	H	1.27	3
Olympia	22	83	0.009	H	1.26	-8
Port Angeles	27	69	0.010	M	1.30	-15
Seattle-Boeing Field	26	81	0.011	M	1.28	-6
Seattle Co	27	82	0.010	M	1.29	-3
Seattle-Tacoma AP	26	80	0.009	M	1.28	-6
Spokane	2	90	0.007	H	1.29	1
Tacoma, McChord AFB	24	82	0.010	M	1.27	-4
Walla Walla	7	94	0.008	H	1.23	6
Wenatchee	11	96	0.007	H	1.28	5
Yakima	5	93	0.007	H	1.25	0
WEST VIRGINIA						
Beckley	4	81	0.013	M	0.92	-5
Bluefield	4	81	0.013	M	0.90	-5
Charleston	11	90	0.014	M	0.94	5
Clarksburg	13	90	0.014	M	0.97	5
Elkins	6	84	0.013	M	0.96	-2
Huntington Co	10	91	0.015	M	0.94	5
Martinsburg	10	90	0.015	M	0.98	5
Morgantown	8	87	0.015	M	0.99	1
Parkersburg Co	11	90	0.015	M	0.97	5
Wheeling	5	86	0.013	M	1.00	1
WISCONSIN						
Appleton	-9	86	0.014	M	1.16	-1
Ashland	-10	62	0.012	M	1.25	-5
Beloit	-3	90	0.016	M	1.09	3
Eau Claire	-11	89	0.014	M	1.18	3
Fond Du Lac	-8	86	0.014	M	1.14	-1
Green Bay	-9	85	0.014	M	1.17	-2
La Crosse	-9	88	0.014	M	1.14	2
Madison	-7	88	0.014	M	1.12	2
Manitowoc	-7	86	0.014	M	1.15	1
Marinette	-11	84	0.014	M	1.19	-1
Milwaukee	-4	87	0.015	M	1.11	2
Racine	-2	88	0.014	M	1.10	3
Sheboygan	-6	86	0.015	M	1.14	1
Stevens Point	-11	89	0.014	M	1.17	3
Waukesha	-5	87	0.015	M	1.11	1
Wausau	-12	88	0.014	M	1.18	2
WYOMING						
Casper	-5	90	0.003	H	1.11	-1
Cheyenne	-1	86	0.004	H	1.04	-4
Cody	-13	86	0.006	H	1.17	-5
Evanston	-3	84	0.003	H	1.05	-7
Lander	-11	88	0.006	H	1.11	-3
Laramie	-6	81	0.004	H	1.05	-8
Newcastle	-12	87	0.007	H	1.14	-3
Rawlins	-4	83	0.004	H	1.07	-12
Rock Springs	-3	84	0.003	H	1.06	-7
Sheridan	-8	91	0.006	H	1.18	0
Torrington	-8	91	0.006	H	1.08	1

END

**DATE
FILMED**

4 / 16 / 92

11/11/2020

(