**DEVELOPMENT OF ADVANCED NO_x CONTROL CONCEPTS
FOR COAL-FIRED UTILITY BOILERS**

DOE Contract No. DE-AC22-90PC90363

Period of Performance: September 26, 1990 to October 26, 1992

Quarterly Technical Progress Report No. 3

Period Covered by Report: April 1 to June 30, 1991

prepared by:

J. Newhall
G. England
W.R. Seeker

Energy and Environmental Research Corporation
18 Mason
Irvine, California 92718

Date Submitted: January 16, 1992

prepared for:

Mr. Charles E. Schmidt
U. S. Department of Energy
Pittsburgh Energy Technology Center
P. O. Box 10940
Pittsburgh, Pennsylvania 15236-0940

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	1-1
2.0 PILOT-SCALE STUDIES	2-1
2.1 Overview of Advanced Reburning	2-1
2.1.1 Reburning	2-1
2.1.2 Selective Non-Catalytic Reduction	2-3
2.2 Boiler Simulation Furnace Results	2-5
2.2.1 Side Chamber Results	2-5
2.2.2 Advanced Reburning Results	2-13
2.3 Modeling Results	2-16
3.0 LABORATORY-SCALE STUDIES	3-1

LIST OF FIGURES

Figure		Page
1-1	Application of CombiNO _x to a wall-fired utility boiler	1-2
2-1	The Boiler Simulation Furnace	2-6
2-2	Schematic of side chamber and advanced reburning approaches	2-7
2-3	Effect of CO promotion of NO reduction for SR = 1.20	2-9
2-4	Effect of CO promotion on NO reduction for SR = 1.02	2-11
2-5	Effect of distribution and quantity of CO on NO reduction performance	2-12
2-6	Effect of initial stoichiometry on NO reduction for advanced reburning approach ...	2-14
2-7	Effect of radical concentration on performance	2-15
2-8	NO removal modeling predictions as a function of CO concentration	2-17
2-9	Ammonia slip modeling predictions as a function of CO concentration	2-19
2-10	Cmparison of modeling results to side chamber approach results	2-20
3-1	Laboratory-scale scrubbing studies experimental setup	3-2
3-2	NO ₂ scrubbing efficiencies in laboratory-scale bubbling bath	3-3

1.0

INTRODUCTION

Hybrid technologies for reduction of NO_x emissions from coal fired utility boilers may offer greater levels of NO_x control than the sum of the individual technologies, leading to more cost effective emissions control strategies. Energy and Environmental Research Corporation (EER) has developed a hybrid NO_x control strategy involving two proprietary concepts which has the potential to meet the U.S. Department of Energy's goal at a significant reduction in cost compared to existing technology. The process has been named CombiNOx.

CombiNOx is an integration of modified reburning, promoted selective non-catalytic reduction (SNCR) and methanol injection to reduce NO_x emissions from coal fired flue gas. The first two steps, modified reburning and promoted SNCR are linked. It was shown previously that oxidation of CO in the presence of a SNCR agent enhances the NO reduction performance. Less reburning than is typically done is required to generate the optimum amount of CO to promote the SNCR agent. If the reburn fuel is natural gas this may result in a significant cost savings over typical reburning. Injection of methanol into the flue gas has been shown at laboratory scale to convert NO to NO_2 which may subsequently be removed in a wet scrubber. Figure 1-1 illustrates how CombiNOx may be applied to a wall fired boiler.

The overall objective of this program is to demonstrate the effectiveness of the CombiNOx process at a large enough scale and over a sufficiently broad range of conditions to provide all of the information needed to conduct a full-scale demonstration in a coal fired utility boiler. The specific technical goals of this program are:

- 70% NO_x reduction at 20% of the cost of selective catalytic reduction;
- NO_x levels at the stack of 60 ppm for ozone non-attainment areas;
- Demonstrate coal reburning;
- Identify all undesirable by-products of the process and their controlling parameters;
- Demonstrate 95% NO_2 removal in a wet scrubber.

To achieve these goals, the program was broken down into two experimental phases. The first phase is referred to as the Fundamental Studies Test Program. In this phase, each of the CombiNOx steps will be analyzed individually at laboratory and pilot scales. In addition, the

Figure 1-1. Application of CombiNOx to a wall-fired utility boiler.

potential synergism between the three processes will be studied at pilot scale. Phase 2 is termed Process Studies. It is in this stage that scale-up questions will be addressed. Testing of the complete CombiNOx process will be performed in a 10 MMBtu/hr furnace which has been shown in the past to accurately simulate full scale boilers.

During this reporting period, experimental work was initiated at both the laboratory and pilot scale in the Fundamental Studies phase of the program. The laboratory scale work focussed on determining whether or not the NO₂ formed by the methanol injection step can be removed in an SO₂ scrubber. The pilot scale studies considered the difference between advanced reburning and co-injection of a SNCR agent with CO. Kinetic modeling was done to help interpret the experimental results.

2.0 PILOT-SCALE STUDIES

The pilot-scale fundamental studies are currently being performed at the Boiler Simulation Furnace (BSF). During this reporting period, effort was focussed on understanding the advanced gas reburning and promoted SNCR processes. This section provides a review of the advanced reburning chemistry, the BSF test results, and a comparison of these data to one dimensional kinetic modeling results.

2.1 Overview of Advanced Reburning Fundamentals

Advanced reburning is a combination of basic reburning and selective non-catalytic reduction (SNCR), and is an integral part of the CombiNOx process. The chemistry underlying reburning, SNCR and advanced reburning is briefly explained in the following paragraphs.

2.1.1 Reburning

The reduction of NO_x by reburning is a relatively well developed concept. The reburning fuel is injected into the radiant furnace at an elevation above the last row of burners to create a moderately fuel-rich zone (the "reburn" zone). Overfire air is injected at the end of the reburning zone to provide a fuel-lean final stoichiometry (the "burnout" zone). Fixed nitrogen is reduced in both zones by somewhat different chemistry.

Reburning Zone

Once it is injected into the furnace, the reburning fuel undergoes oxidative pyrolysis to yield hydrocarbon fragments. Assuming that the fuel is natural gas, the key initial reaction is

The CH₃ radical can lose hydrogen through abstraction reactions to yield CH, the key radical. The CH next reduces NO through

Once formed, several possible fates await the HCN. It can remain as HCN or it can react with

various radicals to form NH_3 which is subsequently reduced to NH_2 . If NH_2 is formed, thermal de- NO_x type reactions will occur:

Reaction 1 is generally minimized but not altogether stopped under the rich conditions of the reburning zone.

Burnout Zone

Two general observations concerning behavior in the burnout zone are:

- 1) A reduced burnout zone temperature promotes lower final NO_x emissions, and
- 2) NO_x reduction is enhanced if NH_3 dominates over HCN as the most important reduced nitrogen species in the rich zone.

The species that are likely to react at the burnout point fall into two classes, the first being the fuel fragments (H_2 and CO) whose combustion at the burnout point will provide the chemical environment for nitrogen reactions. The second class is the active nitrogen species (HCN , NH_3 , and NO) whose interaction will determine the ultimate nitrogen reduction. The gas entering the burnout zone is free of hydrocarbons.

The introduction of burnout air initiates the wet CO oxidation reactions:

This chain branching sequence generates more radicals than it consumes, so long as the CO and H_2 supply hold out. It is this free radical level that determines whether the HCN and NH_3 are oxidized to NO or reduced at the burnout point. They do this in two ways. First, the excess radicals initiate the decomposition of NH_3 and HCN to NH_2 :

Once these compounds have been reduced to NH_2 , the thermal de- NO_x type reactions mentioned above may occur:

In contrast to the reburn zone, high O-atom concentrations in the burnout zone may limit NO removal by removing the NH_2 that is needed for the first NO reduction reaction. Worse yet, elevated radical levels may oxidize the NH , forming NO. In summary, some radicals are needed to initiate HCN and NH_3 destruction, but too many will lead to rapid oxidation of the critical intermediates to NO. Since burnout air injection temperature governs the amount of radicals present, this is a key to optimizing reburning performance.

2.1.2 Selective Non-Catalytic Reduction

SNCR attempts to produce an environment within the furnace similar to that of the burnout zone. Nitrogenous species easily reduced to NH_2 are injected into the flue gas, and the same reactions seen with NH_2 in both the reburn and burnout zones occur:

The key to creating a self-sustaining reaction is for Reaction 3 to generate just enough radicals to drive Reaction 1. The following limitations apply:

- *High Agent Injection Temperature:* Too many radicals are present, and reaction 4 competes well with Reactions 2 and 3, thus reducing NO conversion.
- *Low Agent Injection Temperature:* Insufficient radicals are present in the flue gas, and the initial NH_3 reaction slows, reducing NO removal.

Although SNCR has operational advantages over typical reburning, there are a few disadvantages. At the optimum injection temperature, NO removals greater than 60% are difficult to achieve with Thermal de- NO_x . In addition, the temperature window defining the hot and cold limits described above is very narrow.

EER has discovered that improved NO removal performance can be obtained if the SNCR agent is injected into a region where CO is oxidizing. Initially, the CO reacts according to the wet CO mechanism listed earlier. This sequence proceeds to a lower temperature than Thermal de- NO_x chemistry, and it is chain branching. Thus, it can supply the radicals needed by the $\text{NH}_3 + \text{OH}$ reaction at lower temperatures than would be possible with NH_3 decomposition alone. If done correctly, this acts to enlarge (not just shift) the performance window to lower temperatures. Also, the lower temperatures reduce the $[\text{O}] / [\text{OH}]$ ratio, which may reduce the importance of Reaction 4; this improves efficiency by channeling all the NH_3 into the productive $\text{NH}_2 + \text{NO}$ pathway. Thus, the oxidation of CO in close proximity to the SNCR agent serves to both broaden the window and improve performance.

It is expected that controlling the amount of CO carefully will be necessary to avoid underpowering the reaction by providing insufficient CO to generate the needed OH or overpowering the reaction by flooding the arena with radicals which promote NH_2 conversion to NO. In addition, it is expected that low free stream oxygen concentrations will be favored, since an elevated $[\text{O}] / [\text{OH}]$ ratio harms performance. Whether the CO is supplied by performing reburning upstream and supplying the burnout air in the vicinity of the SNCR or by CO co-injection with the SNCR agent into a fuel lean flue gas is something that was considered during this reporting period in the BSF testing.

2.2 Boiler Simulation Furnace Results

All of the pilot scale fundamental studies are being performed at the BSF shown schematically in Figure 2-1. The BSF is a down-fired 1 MMBtu/hr furnace, capable of firing coal, oil, and natural gas. The vertical section is generally referred to as the radiant furnace, while the horizontal section represents the convective pass since there are fouling probes simulating superheater tubes. The many ports available for insertion of cooling surfaces and probes allow the quench rate to be adjusted to simulate most utility boilers.

Previous lab-scale data suggest that advanced reburning (injection of the SNCR agent into the reburning zone) widens the injection temperature window and improves performance. The purpose of the test series initiated and completed in this reporting period at the BSF was to better understand the role of CO in enhancing and altering the performance of SNCR. In particular, two different methods of CO promoted SNCR agent injection were studied. The first method is the so-called side chamber method in which the CO is co-injected with the SNCR agent into the furnace. The second method employs reburning to generate CO, and the agent is injected with the burnout air – this is essentially advanced reburning. Figure 2-2 shows schematically the fundamental difference between the two methods. The question of interest is whether it matters on what side of the reaction zone the CO and O₂ are.

2.2.1 Side Chamber Results

In the side chamber tests, NO reduction performance was evaluated as a function of furnace stoichiometry and amount of CO co-injected with the SNCR agent. The agent was injected through a 180° Spraying Systems twin fluid nozzle. The test matrix was as follows:

	Atomizing Agent
SR = 1.20	N ₂ , 500 ppm CO, 4000 ppm CO
SR = 1.02	N ₂ , 4000 ppm CO

Figure 2-1. The Boiler Simulation Furnace.

Method 1: Side Chamber Approach

Method 2: Advanced Reburning Approach

Figure 2-2. Schematic of Side Chamber and Advanced Reburning Approaches.

The primary fluid is gaseous ammonia, and the atomizing agent is either N_2 for the baseline case or different levels of CO for the test cases. The atomizing fluid flow rate was the same for each test to maintain constant dispersion of the ammonia. The notation "500 ppm CO" means that enough CO was injected with the SNCR agent to yield this concentration of CO in the furnace. For $SR = 1.02$, the CO level at the injection point is approximately 500 ppm since combustion is less complete at lower air flow rates.

Figure 2-3 presents the side chamber experiments for $SR = 1.20$. For this stoichiometry, there is a negligible amount of CO present in the flue gas. Nitrogen was used as the atomization fluid for the baseline case, and two levels of CO co-injection were tested. The baseline case is typical of thermal de-NOx. The governing reactions are:

In simple de-NOx, the high temperature end of the window is governed by the concentration of radicals. If too many radicals are present, the NH_2 will undergo radical attack rather than combine with NO. At the low temperature end, the window is set by the decomposition of NH_3 to NH_2 . As the injection temperature is reduced, less radicals are available to cause NH_3 to convert to NH_2 . For optimum performance, a fine balance of radical concentration is required – enough to reduce NH_3 to NH_2 , but not too much to oxidize the NH_2 .

One of the more important things demonstrated by Figure 2-3 is that as the amount of CO injected is increased, the performance is decreased. Thinking about the physical situation provides some insight into this phenomena. In the side chamber configuration, a concentrated amount of CO is injected into the hot, oxygen rich flue gas. Since the CO will oxidize and generate radicals according to:

more radicals will be locally concentrated around the ammonia as the CO level is increased. Because of the elevated radical concentrations, the ammonia will easily be reduced to NH_2 . On the

Figure 2-3. Effect of CO promotion on NO reduction for SR = 1.20.

other hand, this radical pool supplies competition for the $\text{NH}_2 + \text{NO}$ reaction. As a result, higher levels of CO result in poorer performance at this stoichiometry.

Another concept presented by Figure 2-3 is that the optimum agent injection temperature shifts to a lower level as the amount of CO added increases. This is because OH radicals are available at temperatures lower than they normally would be due to CO oxidation, continuing to convert NH_3 to NH_2 . As a result, the de- NO_x chemistry is able to work at a lower temperature.

One might expect that the temperature window would broaden, not just shift as the data show. In fact, the previous lab-scale advanced reburning data show a broadening as does the BSF advanced reburning data that are presented in the next section. However, the side chamber configuration differs from the advanced reburning configuration in the high concentration of radicals local to the SNCR agent. As mentioned above, these radicals compete with NO to react with NH_2 , resulting in poorer performance as the radical concentration increases. Since the high temperature end of the window is limited by high radical concentrations the temperature window does not broaden, but shifts.

Figure 2-4 shows the side chamber data for $\text{SR} = 1.02$. As may be seen, the 4000 ppm case performs much better in a less oxygenated environment than it did at $\text{SR} = 1.20$. This is probably due to slower combustion yielding lower concentrations of radicals local to the SNCR agent even at the higher injection temperatures. This may be why the temperature window is wider at lower stoichiometries than at higher ones. Again we see that elevated levels of CO local to the agent reduces performance.

Figure 2-5 compares two 500 ppm CO cases to the thermal de- NO_x case at $\text{SR} = 1.20$. The two 500 ppm CO cases are: 1) CO co-injected with the ammonia and 2) $\text{SR} = 1.02$. The difference being that in the first case, the CO (and therefore radicals) is concentrated around the ammonia, and in the second, it is distributed across the furnace cross section. The best performance is achieved when radicals are not generated by the presence of oxidizing CO, so this also corresponds to the condition with the highest optimum injection temperature. As more CO is brought near the agent, the optimum injection temperature shifts to a lower level because radicals are available to reduce NH_3 to NH_2 . In addition, the performance is degraded as CO oxidation in

Figure 2-4. Effect of CO promotion on NO reduction for SR = 1.02.

Figure 2-5. Effect of distribution and quantity of CO on NO reduction performance.

the presence of the agent is increased, presumably due to an overabundance of radicals competing with the NO to react with NH_2 .

In summary, the side chamber experiments have shown that as local concentrations of *oxidizing* CO increase, performance suffers and the optimum injection temperature shifts to a lower level. To a certain extent, lower excess oxygen concentrations can be used to widen the temperature window.

2.2.2 Advanced Reburning Results

In advanced reburning, the furnace is typically fired at an initial SR of 1.1, and injection of the reburning fuel reduces the stoichiometry to slightly fuel rich. In these tests, we are using natural gas as both the main and reburn fuels, so for simplicity, the initial stoichiometry fired simulates the reburn zone. This stoichiometry is referred to in the following section as SR_1 .

In Figure 2-6, a comparison is made between an initial stoichiometry of 0.99 and 1.02. The approximate CO concentrations at the ammonia injection point for these two conditions are 8000 ppm and 500 ppm, respectively. Recall that the placement of the high temperature side of the window is determined by the radical concentration. For temperatures above 1800 °F, the NO removal performance is essentially the same for $\text{SR}_1 = 1.02$, and $\text{SR}_1 = 0.99$. This is probably because small changes in stoichiometry are less important at higher temperatures (which inherently have more radicals) than at lower temperatures. At 1800 °F however, the importance of stoichiometry becomes more important, and the extra OH radicals available in the $\text{SR}_1 = 0.99$ case serve to continue to improve performance until the ammonia injection temperature reaches 1600 °F. At this point, the CO oxidation reactions begin to fall off, and making the de-NO_x reactions slow down. Therefore, for the advanced reburning configuration, it is possible to both broaden and deepen the NO reduction window. The difference between this and the side chamber configuration is that the radicals due to oxidation of the CO are much less concentrated around the agent, so they don't have such a large impact on the higher temperature limit of the window.

Figure 2-7 presents a comparison between the 500 ppm side chamber configuration and the 500 ppm advanced reburning configuration. Both conditions have a final stoichiometry of 1.20. As a basis for comparison, the thermal de-NO_x curve for $\text{SR} = 1.02$ (500 ppm) is plotted also.

Figure 2-6. Effect of initial stoichiometry on NO reduction for advanced reburning approach.

Figure 2-7. Effect of radical concentration on performance.

The difference between the de-NO_x and advanced reburning cases is that instead of atomizing the ammonia with nitrogen, the advanced reburning case is atomized with oxygen to bring the final stoichiometry up to 1.20. Although the temperature window is not significantly affected, the performance is dramatically reduced when oxygen is injected with the ammonia. This is most likely due to the creation of oxygen radicals that will combine with NH₂ instead of allowing it to combine with NO. The temperature window is not shifted in this case presumably because the level of OH radicals remains unchanged, therefore no low temperature decomposition of NH₃ is possible.

The difference between the side chamber case and the de-NO_x curve for SR = 1.02 is that the side chamber configuration has more OH radicals in close proximity to the ammonia, providing the expected shift in the temperature window and slight decrease in performance. This plot is important in that it effectively separates out the effects of the O and OH radicals. It may be surmised that the role of the O radical is mainly to react with NH₂ and thereby worsen NO reduction performance – the temperature window is not altered. The role of the OH radical is mainly to encourage the de-NO_x reactions at lower temperatures, and in high local concentrations to reduce performance. Apparently, concentrations of each are easier to optimize in the advanced reburning configuration than in the side chamber configuration.

2.3 Modeling Results

To help interpret the BSF test results, some one dimensional modeling was performed. Given a temperature profile and initial concentrations of the species of interest, the model predicts the concentrations of various product species as time (temperature) marches on. Figure 2-8 shows final NO divided by initial NO as a function of ammonia injection temperature and CO concentration. The ratio of moles of ammonia added to moles of NO present in the flue gas is referred to as the nitrogen stoichiometric ratio (NSR) and was maintained at 1.5 to simulate the BSF test conditions. The furnace stoichiometry was set at 1.2. The model duplicates the temperature effect seen in the side chamber tests – as CO is added, the optimum injection temperature shifts to a lower level.

At a given temperature, the model determines statistically which reactions will occur based upon the reactant concentrations. It assumes that all species are instantaneously and uniformly mixed across the flue gas. This is assumed to be the reason why the removal efficiencies predicted

Figure 2-8. NO removal modeling predictions as a function of CO concentration.

by the model are so good. At the optimum injection temperature, virtually all of the NO is removed.

Figure 2-9 demonstrates ammonia slip as a function of ammonia injection temperature. By comparing this to Figure 2-8, it is clear that as the NO reduction begins to fall off, the ammonia emissions spike. This is because the low temperature end is governed by reaction of NH_3 with OH to form NH_2 . Without this initial reaction, NO_x reduction will not occur, and ammonia slip levels will be equal to the amount of ammonia injected.

Figure 2-10 compares the modeling results to the side chamber BSF results. As mentioned above, the levels of NO removal are not accurate because of the model's ideal mixing. However, the optimum injection temperatures predicted by the model are the same as those measured at the BSF for the thermal de- NO_x case and the 500 ppm side chamber case. The optimum injection temperature for the advanced reburning 500 ppm CO configuration approximately 150 °F higher than the side chamber case. This is probable a mixing effect – the OH in the reburning configuration is fairly diluted and as a result not as available for reaction with NH_3 as in the side chamber case. Since the model assumes perfect mixing, it agrees with the side chamber result, which has a higher concentration of OH close to the ammonia. It is important to note that the model only agrees with the side chamber data at relatively low levels of CO injection. At higher CO co-injection levels at the BSF, there are so many radicals near the NH_2 , it can't see the NO. On the other hand, the model allows the NH_2 to react with the NO and for this reason, higher CO concentration cases are not adequately represented by the model.

Figure 2-9. Ammonia slip modeling predictions as a function of CO concentration.

Figure 2-10. Comparison of modeling results to side chamber approach results.

3.0

LABORATORY-SCALE STUDIES

An integral part of the CombiNOx process is the methanol injection step which serves to convert NO to NO₂. The NO₂ is removed from the stack gas with an SO₂ scrubber. As part of the overall program, extensive large pilot scale scrubbing studies are planned. However, it was desirable to first check the chemistry at a smaller scale to make sure that it is possible to remove NO₂ in the presence of SO₂ without deleterious effects to the SO₂ scrubbing performance.

The reactor used in the laboratory-scale studies is shown in Figure 3-1. Known amounts of N₂, O₂, SO₂ and NO₂ are blended together and delivered to a bubbler where it makes contact with the scrubbing solution. The wet gas passes through a water knock-out trap and to the NO_x and SO₂ analyzers.

Several different scrubbing solutions were tested. The results from the best scrubbing solution (sodium sulfite + calcium carbonate + small amount of sodium thiosulfate) are shown in Figure 3-2. NO₂ capture of 95% was sustained for 145 minutes with simultaneous SO₂ removal of 99+% for the same period of time. Calcium hydroxide, a typical scrubbing solution was also tested. As shown in the figure, 50% NO₂ removal was achieved but was only sustained for only 10 minutes.

Figure 3-1. Lab-scale scrubbing studies experimental setup.

Figure 3-2. NO₂ scrubbing efficiencies in lab-scale bubbling bath.

END

**DATE
FILMED**

4 / 01 / 92