

DOE/MC/21098-2247-Vol.2  
DOE/MC/21098--2247-Vol.2 (DE87001074)

DE87 001074

**Summary and Assessment of METC  
Zinc Ferrite Hot Coal Gas  
Desulfurization Test Program,  
Volume II: Appendices**

Received by O<sup>c</sup>-1

AUG 29 1991

**Final Report**

**V.S. Underkoffler**

December 1986 (Revised June 1991)

Work Performed Under Contract No.: DE-AC21-84MC21098

For  
U.S. Department of Energy  
Office of Fossil Energy  
Morgantown Energy Technology Center  
Morgantown, West Virginia

By  
Gilbert/Commonwealth  
Reading, Pennsylvania

MASTER

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

## **DISCLAIMER**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

(DE87001074)

**Summary and Assessment of METC  
Zinc Ferrite Hot Coal Gas  
Desulfurization Test Program,  
Volume II: Appendices**

**Final Report**

**V.S. Underkoffler**

**Work Performed Under Contract No.: DE-AC21-84MC21098**

**For  
U.S. Department of Energy  
Office of Fossil Energy  
Morgantown Energy Technology Center  
P.O. Box 880  
Morgantown, West Virginia 26507-0880**

**By  
Gilbert/Commonwealth  
P.O. Box 1498  
Reading, Pennsylvania 19603**

**December 1986 (Revised June 1991)**

## ABSTRACT

The Morgantown Energy Technology Center (METC) has conducted a test program to develop a zinc ferrite-based high temperature desulfurization process which could be applied to fuel gas entering downstream components such as molten carbonate fuel cells or gas turbines. As a result of prior METC work with iron oxide and zinc oxide sorbents, zinc ferrite evolved as a candidate with the potential for high capacity, low equilibrium levels of H<sub>2</sub>S, and structural stability after multiple regenerations. The program consisted of laboratory-scale testing with a two-inch diameter reactor and simulated fixed-bed gasifier gas; bench-scale testing with a six-inch diameter reactor and actual gas from the METC 42-inch fixed bed gasifier; as well as laboratory-scale testing of zinc ferrite with simulated fluidized bed gasifier gas. Optimum operating parameters for zinc ferrite such as temperatures, gas compositions, and space velocities are discussed. From the test results, salient features of zinc ferrite were derived and discussed in regard to system implications, issues raised, and technical requirements.

An assessment of the technical and economic implications of the zinc ferrite process is presented as well as suggested programs for potential commercialization.

#### **ACKNOWLEDGMENTS**

This report was prepared under Contract No. DE-AC21-84MC21098, Department of Energy, Morgantown Energy Technology Center.

We acknowledge the interest and constructive suggestions of Dr. Vijendra P. Kothari and Dr. Thomas Grindley of Morgantown Energy Technology Center.

## TABLE OF CONTENTS

### VOLUME I

	<u>Page</u>
<b>EXECUTIVE SUMMARY .....</b>	<b>1</b>
<b>1.0 INTRODUCTION .....</b>	<b>10</b>
1.1 Background of Sorbent Development .....	11
1.2 Development and Testing of Zinc Ferrite at METC .....	14
<b>2.0 SUMMARY OF TESTING .....</b>	<b>18</b>
2.1 Laboratory-Scale Testing with Simulated Lurgi Gasifier Gas .....	18
2.1.1 Investigation of Regeneration Conditions of Iron Oxide/Silica .....	19
2.1.2 Preliminary Sorbent Comparisons .....	28
2.1.3 Effect of Temperature on H <sub>2</sub> S Absorption .....	38
2.1.4 Effect of Steam on H <sub>2</sub> S Absorption .....	50
2.1.5 Effect of Steam/Air Ratio on Regeneration .....	56
2.1.6 Absorption of H <sub>2</sub> S by Vanadium Compounds .....	56
2.1.7 Absorption of H <sub>2</sub> S by Franklinite Ore .....	63
2.1.8 Evaluation of IFP Zinc Oxide .....	66
2.1.9 Effect of Zinc Content in Zinc Ferrite .....	73
2.1.10 Evaluation of UCI Zinc Ferrite .....	76
2.1.11 Absorption of H <sub>2</sub> S by Nickel .....	84
2.1.12 Sulfur Pickup by Empty Reactor .....	85
2.1.13 Parametric Studies of Zinc Ferrite for Computer Simulation .....	88
2.1.14 Evaluation of UCI Zinc Ferrite Sorbent to be Used in Sidestream Tests .....	98
2.2 Bench Scale Sidestream Testing Using METC Fixed Bed Gas .....	107
2.2.1 Gasifier Run No. 101 .....	111
2.2.2 Gasifier Run No. 102 .....	121
2.2.3 Gasifier Run No. 103 .....	132
2.2.4 Gasifier Run No. 104 .....	143
2.3 Laboratory-Scale Testing Using Simulated KRW Fluidized-Bed Gas .....	153
2.3.1 Introduction .....	153
2.3.2 Test Results .....	154
2.3.3 Conclusions .....	163

**TABLE OF CONTENTS**  
(Continued)

	<u>Page</u>
3.0 DISCUSSION OF SALIENT FEATURES AND ISSUES .....	164
3.1 Sorbent Capacity .....	164
3.2 Absorption Temperature .....	165
3.3 Absorption Space Velocity .....	166
3.4 Purity Level of Exit Gas .....	167
3.5 Regeneration Temperature .....	167
3.6 Regeneration Gas Composition .....	168
3.7 Regeneration Space Velocity .....	169
3.8 Regeneration Products .....	169
3.9 Change of Sorbent Properties with Regeneration Cycles .....	170
4.0 OVERALL ASSESSMENT OF ZINC FERRITE TEST PROGRAM .....	171
4.1 Accomplishments of Test Program .....	171
4.2 Limitations of Zinc Ferrite .....	173
4.3 Suggested Programs .....	175
5.0 REFERENCES .....	176

**VOLUME II**

<u>Appendix</u>		<u>Page</u>
A	Method for Preparing Zinc Ferrite Sorbent .....	183
B	Process Modeling and Equilibrium Calculations ...	184
C	Laboratory-Scale Reactor Drawings .....	214
D	Laboratory-Scale Test Summary Sheets and Data Curves .....	216
E	Sidestream Testing -- Gasifier Run 101 .....	419
F	Sidestream Testing -- Gasifier Run 102 .....	478
G	Sidestream Testing -- Gasifier Run 103 .....	566
H	Sidestream Testing -- Gasifier Run 104 .....	677
I	Laboratory-Scale Testing -- Simulated KRW Gas ...	738
J	Feasible Gasifiers Gas Stream Compositions .....	787

## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
ES-1	Iron-Carbon-Oxygen Equilibrium Diagram at Atmospheric Pressure .....	5
1-1	METC Simulated Gas Test Results .....	16
2-1	Iron Oxide Sulfidation, Tests 001, 003, and 005 .....	26
2-2	Zinc Ferrite Sulfidation, Tests 007, 009, and 011B (Three cycles on same sorbent) .....	30
2-3	Zinc Ferrite Regeneration, Test 008 .....	31
2-4	Zinc Oxide Sulfidation, Tests 013 and 015 (Harshaw ZN-0401) .....	36
2-5	Sorbent Regeneration, Zinc Oxide and Zinc Ferrite .....	37
2-6	Zinc Ferrite Regeneration, Test 017 .....	41
2-7	Zinc Ferrite Sulfidation, Tests 021, 023, 024, 026, and 028 .....	43
2-8	Zinc Oxide Sulfidation, Tests 038, 033, 034, and 032 (Harshaw ZN-0401) .....	47
2-9	Sulfur Loading, Zinc Ferrite and Zinc Oxide .....	48
2-10	Zinc Ferrite Sulfidation, Tests AVG (16, 21, 47) 043, 051, and 053 .....	53
2-11	Zinc Oxide Sulfidation, Tests 042R, 046, and 034 (Harshaw ZN-0401) .....	55
2-12	Zinc Ferrite Sulfidation, Test 047 and 049 .....	58
2-13	IFP Zinc Oxide Sulfidation, Tests 067, 065, 063, and 061 (IFP MEP 682) .....	69
2-14	IFP Zinc Oxide Sulfidation, Tests 067, 069, and 071 (IFP MEP 682) .....	70
2-15	Zinc Oxide Sulfidation, Tests 067 and 034 .....	71
2-16	Zinc Oxide Sulfidation, Tests 032, 034, and 036 (Harshaw ZN-0401) .....	72
2-17	Zinc Ferrite Sulfidation Tests 021, 023, and 024 .....	74

**LIST OF FIGURES**  
(Continued)

<u>Figure</u>		<u>Page</u>
2-18	Zinc Ferrite Sulfidation (T080 and T082) United Catalysts L-1442 .....	80
2-19	Zinc Ferrite Sulfidation (T084, T086, and T088) United Catalysts L-1442 .....	81
2-20	Zinc Ferrite Sulfidation, T092 Empty Reactor Sulfidation .....	87
2-21	Zinc Ferrite Sulfidation, Test T093 H <sub>2</sub> S Leaching from Empty Sulfided Reactor .....	89
2-22	Zinc Ferrite Sulfidation, Test 096 .....	93
2-23	Zinc Ferrite Sulfidation, Tests 103 and 105, United Catalysts L-1443 .....	94
2-24	Zinc Ferrite Sulfidation, Tests 105, 107, and 113, United Catalysts L-1443 .....	96
2-25	Zinc Ferrite Sulfidation, Tests 115, 117, and 119, United Catalysts L-1443 .....	97
2-26	Zinc Ferrite Sulfidation, Tests 121, 123, and 125, United Catalysts L-1443 .....	99
2-27	Zinc Ferrite Sulfidation, Tests 105, 115, and 121, United Catalysts L-1443 .....	100
2-28	Zinc Ferrite Sulfidation, Tests 107, 117, and 123, United Catalysts L-1443 .....	101
2-29	Zinc Ferrite Sulfidation, Tests 113, 119, and 125, United Catalysts L-1443 .....	102
2-30	Zinc Ferrite Sulfidation, Tests 128, 129, and 131, United Catalysts L-1504 .....	106
2-31	Process Flow-Sheet for Hot Gas Desulfurization Bench-Scale Test Unit .....	110
2-32	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 01 .....	114
2-33	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 03 .....	115
2-34	Zinc Ferrite Sulfidation, Sidestream Test Unit, Tests 001 and 003 .....	116

**LIST OF FIGURES**  
(Continued)

<u>Figure</u>		<u>Page</u>
2-35	Zinc Ferrite Sulfidation, Initial H <sub>2</sub> S and SO <sub>2</sub> Concentration .....	117
2-36	Sorbent Pellet Analysis, Gasifier Run 101 -- Three Sulfidations .....	120
2-37	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 06 .....	124
2-38	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 08 .....	125
2-39	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 09 .....	127
2-40	Hydrogen Sulfide and Sulfur Dioxide Plot HGD -- Sulfidation Test # 11 .....	128
2-41	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 13 .....	136
2-42	Hydrogen Sulfide and Sulfur Dioxide Plot HGD -- Sulfidation Test # 15 .....	137
2-43	Hydrogen Sulfide and Sulfur Dioxide Plot HGD -- Sulfidation Test # 17 .....	138
2-44	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 19 .....	139
2-45	Particulate Analysis Sulfidation Tests 013, 015, 017, and 019 .....	144
2-46	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 20 .....	148
2-47	Hydrogen Sulfide Breakthrough Plot HGD -- Sulfidation Test # 22 .....	149
2-48	Zinc Ferrite Sulfidation Lab Scale Test Unit; Tests 003, 004, 005, and 006 .....	157
2-49	Zinc Ferrite Sulfidation Lab Scale Tests 007, 008, 009 and 010R .....	158
2-50	Sulfur Absorption Capacity of Zinc Ferrite .....	159

## LIST OF TABLES

<u>Table</u>		<u>Page</u>
2-1	Summary of Laboratory Scale Testing .....	20
2-2	Investigation of Regeneration Conditions of Iron Oxide/Silica .....	24
2-3	Hydrogen Sulfide/Zinc Oxide Equilibrium Values .....	27
2-4	Preliminary Zinc Ferrite Test Runs .....	29
2-5	Preliminary Zinc Oxide Test Runs .....	35
2-6	Effect of Temperature on Zinc Ferrite Performance .....	39
2-7	Effect of Temperature on Zinc Oxide Performance .....	46
2-8	Effect of Steam on Zinc Ferrite Performance .....	51
2-9	Effect of Steam on Zinc Oxide Performance .....	54
2-10	Effect of Steam/Air Ratio on Regeneration .....	57
2-11	Absorption of H <sub>2</sub> S by Vanadium Compounds .....	59
2-12	Percent Total Integrated Intensity of Various Sorbents .....	60
2-13	Structural Changes in Various Sorbents .....	62
2-14	Analysis of Fresh and Sulfidized Sorbents .....	64
2-15	Analysis of Enriched Franklinite Ore .....	65
2-16	Investigation of IFP Zinc Oxide .....	67
2-17	Test Runs to Determine Effect of Zinc Content ...	75
2-18	Properties of Initial Zinc Ferrite Samples .....	77
2-19	Summary of L1442 Zinc Ferrite Sorbent Tests Conditions and Results .....	79
2-20	Analysis of L1442 Zinc Ferrite Sorbent Before and After Testing .....	82
2-21	Analysis of G-72D and G-65 RS Sorbents .....	86

**LIST OF TABLES**  
(Continued)

<u>Table</u>		<u>Page</u>
2-22	Matrix of Conditions for Sulfidation Testing of L1443 Zinc Ferrite for Dynamic Simulation Study .....	91
2-23	Analysis of L1443 Zinc Ferrite Sorbent in Certain Sulfidation Runs .....	92
2-24	Properties of Final Zinc Ferrite Samples .....	103
2-25	Summary of L1504 Zinc Ferrite Sorbent Tests .....	105
2-26	Condensate Analysis During Test 129 .....	107
2-27	Operating Conditions of Lab-Scale and Sidestream Test Unit .....	108
2-28	Hot Gas Desulfurization Tests -- Gasifier Run 101 .....	112
2-29	Sorbent Analysis After Test 005, Zinc Ferrite L-1504, United Catalysts .....	119
2-30	Hot Gas Desulfurization Tests -- Gasifier Run 102 .....	122
2-31	Analysis of Minerals by X-Ray Diffraction in Sulfided Zinc Ferrite Gasifier Run 102, Test 008 .....	130
2-32	Sorbent Analysis of Sulfided Zinc Ferrite Gasifier Run 102, Test 008 .....	131
2-33	Hot Gas Desulfurization Tests -- Gasifier Run 103 .....	133
2-34	Analysis of Minerals by X-Ray Diffraction in Sulfided Zinc Ferrite Gasifier Run 103 .....	140
2-35	Sorbent Analysis of Sulfided Zinc Ferrite Gasifier Run 103, Test 019 .....	141
2-36	Hot Gas Desulfurization Tests Gasifier Run 104 .....	146
2-37	Analysis of Minerals by X-Ray Diffraction in Sulfided Zinc Ferrite Gasifier Run 104 .....	150
2-38	Sorbent Analysis of Sulfided Zinc Ferrite Gasifier Run 104, Test 022 .....	151

**LIST OF TABLES**  
(Continued)

<u>Table</u>		<u>Page</u>
2-39	Compositions of Gases to be Treated by the Zinc Ferrite Process Development Unit .....	155
2-40	Sorbent Characterization: Physical and Chemical Properties Air Blown Tests .....	161
2-41	Sorbent Characterization: Physical and Chemical Properties Oxygen Blown Tests .....	162

## APPENDIX A

### Method for Preparing Zinc Ferrite Sorbent

Screened (-60 mesh, 250 micron) equimolar amounts of Fisher "Certified" ferric oxide and Sherwin-Williams "High Surface Area" zinc oxide were mixed dry with 1 percent of Fisher "Laboratory Grade" bentonite powder in a split sleeve mixer for 30 minutes. The dry mixture was placed in a small cement mixer and sprayed with water from an atomizer until the "plastic" state was reached. The wet mixture was extruded through a pipe with a die face plate using a ram rod pushed with a hydraulic jack. The resulting sorbents were dried at 200°F for several hours then baked at 1,500°F for 3 hours.

## APPENDIX B

### Process Modeling and Equilibrium Calculations

Process modeling consisted primarily of the calculation of equilibrium H<sub>2</sub>S levels for various sorbents at high temperatures. This can be done either by minimization of the GIBBS free energy function for a group of reactants, or by direct calculation of the equilibrium constant for a specified reaction. The former method is more complex and allows for the interaction of all possible reactions among the specified components, whereas the latter is simpler and requires that a reaction be specified in terms of products and reactants. The ASPEN system, using the RGIBBS routine, was utilized for the more complex GIBBS free energy minimization calculations. A code (THERMOG) was written for the simpler equilibrium constant method of calculation.

#### A. ASPEN - RGIBBS

The RGIBBS routine computes the phase and/or chemical equilibrium compositions at a user specified temperature and pressure when any number of feed streams are mixed. The output consists of one vapor phase and any number of liquid and solid phases. The method of calculation is minimization of GIBBS free energy using an extension of the Rand algorithm (Gautram and Seider, Part I 1979). After the equilibrium compositions are computed, an overall energy balance is performed to compute the heat duty. Since the sulfidation reaction was the primary area of interest, and it is expected that this reaction is essentially isothermal, heat effects were not considered at this point. Heat effects will be an important parameter, however, when regeneration reactions are studied. Sulfidation reactions of zinc oxide with a Lurgi-type gas were simulated and the results compared with other sources. In addition, the effect of equilibrium at ambient pressure on major components was simulated. Of primary interest at this point was the level of H<sub>2</sub> and CO, since these make up the Molten Carbonate Fuel Cell (MCFC) useable fuel.

Equilibrium values of H<sub>2</sub>S were obtained for the reaction of H<sub>2</sub>S with ZnO. A Lurgi air-blown gasifier gas was used in the input file, and one atmosphere pressure specified. Runs were made for temperatures of 500 to 650°C in 50°C increments, and for a feed gas with 25 percent steam and no steam (H<sub>2</sub>S at 2.7 percent).

Attempts were made to run ASPEN on the METC DEC/VAX-11 without success. Due to time limitations, the runs were not repeated and reliance was placed in calculations from equilibrium constants.

B. THERMOG - A code that calculates equilibrium values of the components of the sulfidation reaction of any metal oxide

As mentioned previously, the simpler method of calculating equilibrium values of a reaction of known components is by the equilibrium constant method. The equilibrium constant of any reaction can be calculated from the thermodynamic properties of the reactants and products of the reaction with proper accounting of the stoichiometry of the reaction. Once the equilibrium constant is calculated at a given temperature, equilibrium values of the components of the reaction can be readily calculated in terms of known values of the remaining components of the reaction.

A Fortran code written to carry out this calculation on the METC VAX-11 is currently operational. Input requirements include the thermodynamic properties of all components in the reaction, and the reaction itself has to be specified. The output is displayed in tabular form as in Table 1.

Initially, the code was used to determine the effects of various sources of thermodynamic data on the equilibrium constant for the zinc oxide reaction. Figure 1 shows the equilibrium constants obtained using various sources of data. It was generally found that small discrepancies in thermodynamic data affected the results: however, results remained within a reasonable range. The user can choose input

GENERAL GAS-SOLID EQUILIBRIUM CODE (ZnO)

THERMODYNAMIC DATA

ZnS HEAT OF FORMATION (25 C) •	-48.589	KCAL MOL-1	CRC HANDBOOK
H <sub>2</sub> O HEAT OF FORMATION (25 C) •	-57.869	KCAL MOL-1	CRC HANDBOOK
ZnO HEAT OF FORMATION (25 C) •	-83.170	KCAL MOL-1	CRC HANDBOOK
H <sub>2</sub> S HEAT OF FORMATION (25 C) •	-4.815	KCAL MOL-1	CRC HANDBOOK
ZnS ENTROPY (25 C) •	13.899	CAL K-1 MOL-1	CRC HANDBOOK
H <sub>2</sub> O ENTROPY (25 C) •	45.110	CAL K-1 MOL-1	CRC HANDBOOK
ZnO ENTROPY (25 C) •	10.569	CAL K-1 MOL-1	CRC HANDBOOK
H <sub>2</sub> S ENTROPY (25 C) •	40.150	CAL K-1 MOL-1	CRC HANDBOOK

DATA SOURCE

HEAT CAPACITY EQUATION IS

$$CP = A + BT + CT^2 + DT^3 + ET^{-2}$$

CAL K-1 MOL-1

HEAT CAPACITY COEFFICIENTS

	A	B	C	D	E	SOURCE
ZnO	11.49	0.00145800	0.000006003	0.000008080	-182400.00	PERRY'S P-3-
H <sub>2</sub> S	7.81	0.00296000	0.000003000	0.000003000	-46000.00	MILLS
ZnS	12.81	0.02095380	0.000002200	0.002666000	-194689.00	PERRY'S P3-1
H <sub>2</sub> O	7.17	0.02856600	0.000006000	0.000003000	8000.00	KUBASCHEWSKI


TEMPERATURE DEGREES C	DELTA Q CAL/GMOLE	EQUILIBRIUM CONSTANT	EQUILIBRIUM H <sub>2</sub> S LEVEL IN PPM PERCENT STEAM					
			5%	10%	15%	20%	25%	30%
200.	-17999.88	80.73E+07	24.1E-05	48.2E-05	72.3E-05	96.5E-05	12.1E-04	14.5E-04
250.	-17981.13	32.64E+06	15.3E-04	39.6E-04	46.0E-04	61.3E-04	76.6E-04	91.9E-04
300.	-17964.58	71.09E+05	70.3E-04	14.1E-03	21.1E-03	28.1E-03	35.2E-03	42.2E-03
350.	-17949.70	19.89E+05	25.3E-03	50.5E-03	76.8E-03	0.10	0.13	0.15
400.	-17938.09	66.75E+04	74.9E-03	0.15	0.22	0.30	0.37	0.45
450.	-17923.45	26.17E+04	0.19	0.38	0.57	0.76	0.96	1.1
500.	-17911.49	11.59E+04	0.43	0.86	1.3	1.7	2.2	2.6
550.	-17900.91	56.66E+03	0.88	1.8	8.6	3.5	4.4	5.3
600.	-17888.80	38.08E+03	1.7	3.3	5.0	6.6	8.3	10.
650.	-17877.71	17.10E+03	2.9	5.8	8.8	12.	15.	18.
700.	-17866.69	10.30E+03	4.0	9.7	15.	19.	24.	29.
750.	-17855.31	65.83E+02	7.7	15.	23.	31.	38.	46.
800.	-17843.76	43.09E+02	18.	83.	35.	46.	58.	70.
850.	-17831.84	28.53E+02	37.	34.	51.	68.	85.	10.2E+01

FORTRAN STOP

6

TABLE 1

## ZNO EQUILIBRIUM CONSTANT



17-NOV-82 10:54:07

FIGURE 1


data felt to be most accurate and obtain equilibrium values based on this chosen input data.

The effect of steam on the H<sub>2</sub>S equilibrium level is shown in Figure 2. This plot indicates that sufficiently low levels of H<sub>2</sub>S (below 1 ppm) can be obtained at up to approximately 7 percent steam at 1,000°F. As temperature increases, the equilibrium H<sub>2</sub>S level increases. Additional calculations using two different sets of data were made to determine the effect of small variations in the thermodynamic properties of zinc oxide and zinc sulfide on H<sub>2</sub>S equilibrium values. The results, shown in Tables 1 and 2 indicate differences in the H<sub>2</sub>S levels obtained, with larger discrepancies at higher temperature and steam levels.

The equilibrium code for calculating equilibrium levels of H<sub>2</sub>S with zinc oxide was generalized to allow equilibrium calculations for any gas-solid reaction. This was done primarily to determine equilibrium levels of H<sub>2</sub>S with V<sub>2</sub>O<sub>3</sub>. Tables 3 and 4 show the results of equilibrium calculations using two different values for the heat of formation of V<sub>2</sub>S<sub>3</sub>. Using the National Bureau of Standards' heat of formation value for V<sub>2</sub>S<sub>3</sub>, of 230 Kcal/mol, equilibrium calculations indicate that H<sub>2</sub>S levels far below 1 ppm can be achieved. However, if a correlation by Mills is used to obtain the heat of formation of V<sub>2</sub>S<sub>3</sub> of 125 Kcal/mol, the results indicate that no desulfurization will take place. This discrepancy makes it difficult to draw conclusions as to the capabilities of V<sub>2</sub>S<sub>3</sub> in low level desulfurization. This must be determined experimentally.

In conclusion, two methods have been used to calculate the equilibrium H<sub>2</sub>S values expected at Hot Gas Desulfurization conditions. Results are reasonable for the most part and come reasonably close to experimental data obtained in this project and others. Additional calculations for simultaneous shift/methanation equilibrium calculations based on equilibrium constants were conducted for various temperatures. These are included in the third section of Appendix B.

H<sub>2</sub>S EQUILIBRIUM VALUES  
ZINC OXIDE SYSTEM



17-NOV-82 10:58:17

FIGURE 2

## GENERAL GAS-SOLID EQUILIBRIUM CODE

(ZnO)

## THERMODYNAMIC DATA

## DATA SOURCE

ZHS HEAT OF FORMATION (25 C) •	-40.000	KCAL MOL-1	MILLS
H2O HEAT OF FORMATION (25 C) •	-57.795	KCAL MOL-1	KUBASCHEWSKI
ZHO HEAT OF FORMATION (25 C) •	-83.820	KCAL MOL-1	KUBASCHEWSKI
H2S HEAT OF FORMATION (25 C) •	-4.020	KCAL MOL-1	MILLS
ZHS ENTROPY (25 C) •	13.800	CAL K-1 MOL-1	MILLS
H2O ENTROPY (25 C) •	45.160	CAL K-1 MOL-1	KUBASCHEWSKI
ZHO ENTROPY (25 C) •	10.430	CAL K-1 MOL-1	KUBASCHEWSKI
H2S ENTROPY (25 C) •	40.160	CAL K-1 MOL-1	MILLS

HEAT CAPACITY EQUATION IS

$$CP = A + BT + CT^2 + DT^3 + ET^{-2}$$

CAL K-1 MOL-1

HEAT CAPACITY COEFFICIENTS

A              B              C              D              E              SOURCE

ZNO	11.71	0.00122690	0.000000000	0.000000000	-218630.00	KUBASCHEWSKI
H2S	7.81	0.00205000	0.000000063	0.000000020	-46039.00	MILLS
ZHS	11.77	0.00126030	0.000000020	0.000000020	-116630.00	MILLS
H2O	7.17	0.00256000	0.000000000	0.000000000	8600.00	KUBASCHEWSKI

TEMPERATURE DEGREES C	DELTA G CAL/CHOLE	EQUILIBRIUM CONSTANT	EQUILIBRIUM H2S LEVEL IN PPM PERCENT STEAM					
			5%	10%	15%	20%	25%	30%
200.	-17862.21	16.80E+07	29.8E-05	59.5E-05	89.3E-05	11.8E-04	14.9E-04	17.9E-04
250.	-17778.15	20.05E+06	18.6E-04	37.2E-04	55.0E-04	74.5E-04	93.1E-04	11.2E-03
300.	-17753.17	59.04E+05	84.7E-04	16.9E-03	25.4E-03	33.9E-03	42.3E-03	50.8E-03
350.	-17726.84	16.54E+05	30.2E-03	60.5E-03	90.7E-03	0.12	0.15	0.18
400.	-17698.01	55.90E+04	89.4E-03	0.18	0.27	0.36	0.45	0.54
450.	-17669.21	21.93E+04	0.23	0.48	0.68	0.91	1.1	1.4
500.	-17637.63	96.96E+03	0.52	1.0	1.5	2.1	2.6	3.1
550.	-17604.13	47.20E+03	1.1	2.1	3.8	4.2	5.3	6.3
600.	-17580.67	25.01E+03	2.0	4.0	6.0	8.0	10.	12.
650.	-17631.23	14.16E+03	3.5	7.1	11.	14.	18.	21.
700.	-17491.03	84.80E+02	5.0	12.	18.	24.	29.	36.
750.	-17450.44	53.45E+02	0.4	1.0	2.0	3.7	4.7	5.6
800.	-17407.11	35.11E+02	14.	88.	43.	57.	71.	85.
850.	-17361.84	23.98E+02	81.	42.	63.	84.	10.5E+01	18.5E+01

FORTRAN STOP

8

TABLE 2

## GENERAL GAS-SOLID EQUILIBRIUM CODE

(V<sub>2</sub>O<sub>3</sub>)

## THERMODYNAMIC DATA

## DATA SOURCE

U23HEAT OF FORMATION (25 C) = -839.000 KCAL MOL-1 NB9  
 H2O HEAT OF FORMATION (25 C) = -57.705 KCAL MOL-1 KUBASCHEWSKI  
 U203HEAT OF FORMATION (85 C) = -891.380 KCAL MOL-1 KUBASCHEWSKI-JANAF 1976  
 H2S HEAT OF FORMATION (85 C) = -4.860 KCAL MOL-1 MILLS

U23ENTROPY (25 C) = 31.889 CAL K-1 MOL-1 MILLS  
 H2O ENTROPY (25 C) = 45.166 CAL K-1 MOL-1 KUBASCHEWSKI  
 U203ENTROPY (85 C) = 83.449 CAL K-1 MOL-1 KUBASCHEWSKI-JANAF 1976  
 H2S ENTROPY (85 C) = 49.160 CAL K-1 MOL-1 MILLS

## HEAT CAPACITY EQUATION IS

$$CP = A + BT + CT^2 + DT^3 + ET^4$$

CAL K-1 MOL-1

## HEAT CAPACITY COEFFICIENTS

	A	B	C	D	E	SOURCE
U203	29.35	8.004700000	8.000000000	8.000000000	-542000.00	B. OF MINES
H2S	7.81	8.002500000	8.000000000	8.000000000	-46000.00	MILLS
U253	28.60	8.016000000	8.000000000	8.000000000	0.00	MILLS(AUG)
H2O	7.17	8.022560000	8.000000000	8.000000000	8000.00	KUBASCHEWSKI

TEMPERATURE DEGREES C	DELTA Q CAL/GMOLE	EQUILIBRIUM CONSTANT	EQUILIBRIUM H2S LEVEL IN PPM PERCENT STEAM					
			5%	10%	15%	20%	25%	30%
200.	-85398.86	11.07E+43	10.1E-11	20.3E-11	30.4E-11	40.6E-11	50.7E-11	60.8E-11
250.	-85252.88	83.58E+38	27.0E-10	54.0E-10	81.0E-10	10.8E-09	13.5E-09	18.2E-09
300.	-85114.52	18.94E+35	40.4E-09	80.8E-09	12.1E-08	16.2E-08	20.2E-08	24.2E-08
350.	-84981.42	20.85E+32	39.1E-08	78.3E-08	11.7E-07	15.7E-07	19.6E-07	23.5E-07
400.	-84852.61	63.37E+29	27.0E-07	54.0E-07	81.1E-07	10.8E-06	13.5E-06	16.2E-06
450.	-84727.65	43.04E+27	14.3E-06	20.5E-06	42.0E-06	57.1E-06	71.3E-06	85.6E-06
500.	-84606.95	56.99E+25	60.7E-06	12.1E-05	18.2E-05	24.3E-05	30.3E-05	36.4E-05
550.	-84487.69	12.33E+24	21.6E-05	43.3E-05	64.0E-05	86.0E-05	10.8E-04	13.0E-04
600.	-84372.78	42.19E+22	60.7E-05	13.3E-04	20.0E-04	26.7E-04	33.3E-04	40.0E-04
650.	-84261.22	89.84E+21	18.0E-04	38.3E-04	54.6E-04	73.7E-04	90.8E-04	10.9E-03
700.	-84153.16	14.05E+20	44.6E-04	89.3E-04	13.4E-03	17.0E-03	23.3E-03	26.8E-03
750.	-84048.71	12.38E+19	10.0E-03	80.1E-03	30.1E-03	40.2E-03	50.2E-03	60.2E-03
800.	-83948.02	13.80E+18	89.0E-03	41.8E-03	68.8E-03	83.7E-03	0.10	0.13
850.	-83851.83	18.38E+17	40.8E-03	81.6E-03	0.18	0.18	0.20	0.24

FORTRAN STOP

GENERAL GAS-SOLID EQUILIBRIUM CODE (V<sub>2</sub>O<sub>3</sub>)

THERMODYNAMIC DATA

DATA SOURCE

U0S HEAT OF FORMATION (25 C)	-105.089	KCAL MOL-1	MILLS (CORRELATION)
H2O HEAT OF FORMATION (25 C)	-67.705	KCAL MOL-1	KUBASCHEWSKI
U2O3 HEAT OF FORMATION (25 C)	-291.368	KCAL MOL-1	KUBASCHEWSKI-JAHAF 1975
H2S HEAT OF FORMATION (25 C)	-4.888	KCAL MOL-1	MILLS
U0S ENTROPY (25 C)	31.000	CAL K-1 MOL-1	MILLS
H2O ENTHROPY (25 C)	45.105	CAL K-1 MOL-1	KUBASCHEWSKI
U2O3 ENTHROPY (25 C)	83.449	CAL K-1 MOL-1	KUBASCHEWSKI-JAHAF 1975
H2S ENTHROPY (25 C)	49.150	CAL K-1 MOL-1	MILLS

HEAT CAPACITY EQUATION IS

$$CP = A + BT + CT^2 + DT^3 + ET^{-2}$$

$$CAL K-1 MOL-1$$

HEAT CAPACITY COEFFICIENTS

	A	B	C	D	E	SOURCE
U2O3	29.35	0.0047E009	0.002000000	0.000880000	-542000.00	B. OF MINES
H2S	7.81	0.00296630	0.000000000	0.000600300	-4000.00	MILLS
U2S3	28.08	0.01666300	0.000000000	0.000500000	0.00	MILLS(AVG)
H2O	7.17	0.06266630	0.000000000	0.002666800	8000.00	KUBASCHEWSKI

TEMPERATURE DEGREES C	DELTA Q CAL/GMOLE	EQUILIBRIUM CONSTANT	EQUILIBRIUM H2S LEVEL IN PPM PERCENT STEAR					
			5%	10%	15%	20%	25%	30%
200.	9601.94	36.60E-06	15.1E+05	30.1E+05	45.2E+05	60.2E+05	75.3E+05	90.4E+05
250.	9747.14	84.52E-06	11.4E+05	22.0E+05	34.2E+05	45.6E+05	57.0E+05	68.4E+05
300.	9885.48	16.97E-05	90.3E+04	18.1E+05	27.1E+05	36.1E+05	45.2E+05	54.2E+05
350.	10018.58	39.59E-05	74.2E+04	14.8E+05	22.3E+05	29.7E+05	37.1E+05	44.5E+05
400.	10147.39	50.60E-05	62.7E+04	12.5E+05	18.8E+05	25.1E+05	31.4E+05	37.6E+05
450.	10272.45	78.50E-05	54.2E+04	10.8E+05	16.3E+05	21.7E+05	27.1E+05	32.5E+05
500.	10304.05	11.52E-04	47.7E+04	95.4E+04	14.3E+05	19.1E+05	23.9E+05	28.6E+05
550.	10512.31	16.16E-04	42.6E+04	85.2E+04	12.8E+05	17.0E+05	21.3E+05	25.6E+05
600.	10827.24	21.80E-04	38.6E+04	77.1E+04	11.6E+05	15.4E+05	19.3E+05	23.1E+05
650.	10738.78	28.60E-04	35.2E+04	70.4E+04	10.6E+05	14.1E+05	17.6E+05	21.1E+05
700.	10846.84	36.02E-04	32.4E+04	64.9E+04	97.3E+04	13.8E+05	16.2E+05	19.5E+05
750.	10951.29	45.76E-04	30.1E+04	60.2E+04	90.4E+04	12.8E+05	15.1E+05	18.1E+05
800.	11051.98	56.10E-04	28.1E+04	56.3E+04	84.4E+04	11.3E+05	14.1E+05	16.0E+05
850.	11143.77	67.66E-04	28.4E+04	58.0E+04	70.3E+04	10.6E+05	13.2E+05	15.0E+05


FORTRAN STOP

3

TABLE 4

EVALUATION OF EQUILIBRIUM CONSTANTS AS A FUNCTION OF TEMPERATURE  
FROM BASIC THERMODYNAMIC PRINCIPLES FOR THE ZINC OXIDE SYSTEM

The reaction is:



The equilibrium constant can be expressed in terms of the free energy change (Hougen, Watson and Ragatz part II p. 983) as follows:

$$K_{eQ} = e^{-\frac{\Delta G^\circ}{RT}}$$

The equilibrium constant can therefore be calculated by finding the value of  $\Delta G^\circ$ , the standard free energy change for the above reaction. The standard free energy change for the above reaction is the difference between the sum of the  $\Delta G^\circ$  for the products and the reactants, at a specified temperature.

$$\Delta G_{25^\circ\text{C}} = \sum \Delta G_{\text{PRODUCTS}}^\circ - \sum \Delta G_{\text{REACTANTS}}^\circ$$

The standard free energy change for the products and reactants have been taken from the CRC Handbook of Chemistry and Physics 61<sup>st</sup> edition 1980-81 pages D-71, D-76, and D-78. The values quoted in the CRC Handbook are from circular of the National Bureau of Standards 500, "Selected Values of Chemical Thermodynamic Properties", issued February 1, 1952.

Products		Reactants	
	$\Delta G_{25^\circ\text{C}}$ Kilocal/gmole		$\Delta G_{25^\circ\text{C}}$ Kilocal/gmole
ZnS	-47.4	ZnO	-76.05
H <sub>2</sub> O	-54.64	H <sub>2</sub> S	-7.892
	-102.04		-83.942

$$\Delta G_{25^{\circ}C} = -102.04 - (-83.942) = -18.1 \frac{\text{Kilocal}}{\text{gmole}}$$

This is the standard free energy change for the above reaction at 25°C. In order to get the  $\Delta G^{\circ}$  at higher temperatures the procedure in Hougen, Watson and Ragatz part II p 986-987 is used. This procedure utilizes the heat capacities, heats of formations, and entropies of the reactants and products at a known temperature to calculate two integration constants. Once these are known  $\Delta G^{\circ}$  can be calculated at any temperature using the following equation (HWR pt II p. 986 equation 14).

$$\frac{\Delta G^{\circ}}{T} = \frac{I_H}{T} + (\Delta a - I_s) - \Delta a \ln T - \frac{\Delta b T^2}{2} - \frac{\Delta c T^3}{6} - \frac{\Delta d T^4}{12} - \frac{\Delta e}{2 T^2} \quad (1)$$


where  $I_H$  and  $I_s$  are the integration constants to be calculated.  $I_H$  is calculated from the following equation (HWR part II p 986 equation 12)

$$\Delta H_T^{\circ} = I_H + \Delta a T + \frac{1}{2} \frac{\Delta b T^2}{3} + \frac{1}{3} \frac{\Delta c T^3}{4} + \frac{1}{4} \frac{\Delta d T^4}{T} - \frac{\Delta e}{T} \quad (2)$$

where a, b, c are the coefficient "deltas" in the empirical expression for heat capacities of products less reactants.

$$c_p^{\circ} + a + bT + cT^2 + dT^3 + \frac{e}{T^2}$$

these coefficients are required for each of the products and reactants in the reaction, and are listed in Table 1.



$$\Delta H_{25^{\circ}C}^{\circ} = \Sigma \Delta H_{\text{PRODUCTS}}^{\circ} - \Sigma \Delta H_{\text{REACTANTS}}^{\circ}$$

The standard heat of formation for products and reactants was obtained from the CRC Handbook of Chemistry and Physics 61<sup>st</sup> edition 1980-81 pag D-71, D-76 and D-78.

Table 1

Source		a	b	c	Range
ZnO	Bulletin 324 U.S. Bureau of Mines p. 39	6.63	$11.26 \times 10^{-3}$	$-47.22 \times 10^{-7}$	0-1300°C
ZnS		7.05	$15.15 \times 10^{-3}$	$-9.17 \times 10^{-7}$	0-1000°C
H <sub>2</sub> S	Hougen Watson & Ragatz pt II Table D Appendix	7.07	$0.3128 \times 10^{-2}$	$0.1364 \times 10^{-5}$	0-1527°C
H <sub>2</sub> O		7.700	$0.04594 \times 10^{-2}$	$0.2521 \times 10^{-5}$	0-1527°C
$\Delta a = 14.75 - 13.7 = 1.05$ $\Delta b = 1.56 \times 10^{-2} - 1.4388 \times 10^{-2} = 1.2214 \times 10^{-3}$ $\Delta c = 1.604 \times 10^{-6} - (-3.358 \times 10^{-6}) = 4.962 \times 10^{-6}$					

Products		Reactants	
$\Delta H_{25}^{\circ}\text{C}$ Kilocal/gmole		$\Delta H_{25}^{\circ}\text{C}$ kilocal/gmole	
ZnS	-48.5	ZnO	-83.17
H <sub>2</sub> O	-57.8	H <sub>2</sub> S	-4.815
	-106.3		-87.985

$$\Delta H_{25}^{\circ}\text{C} = -106.3 + 87.985 = -18.315 \frac{\text{Kilocal}}{\text{gmole}}$$

This value can now be used in equation (2) to find the integration constant I<sub>H</sub>.

$$I_H = -(-18,315) + 1.05(298.16) + 1.2214 \times 10^{-3}(298.16)^2 + 4.962 \times 10^{-6}(298.16)^3 +$$

$$\frac{1}{4} \frac{\Delta dT^4}{T} - \frac{\Delta e}{T}$$

$$I_H = -18,726$$

The second integration constant comes from the entropy equation (HWR pt. II p. 986 equation 13)

$$\Delta S_T^{\circ} = I_S + \Delta a \ln T + \Delta b T + \frac{1}{2} \Delta c T^2 + \frac{1}{3} \Delta d T^3 - \frac{\Delta e}{2T^2} \quad (3)$$

$$\Delta S_{25}^{\circ}\text{C} = \sum S_{\text{PRODUCTS}}^{\circ} - \sum S_{\text{REACTANTS}}^{\circ}$$

The entropy of the products and reactants of the reaction are from the CRC Handbook of Chemistry and Physics 61<sup>st</sup> edition 1980-81 pages D-71, D-76 and D-78.

Products		Reactants	
$S_{25}^{\circ}\text{C}$ cal/degmole		$S_{25}^{\circ}\text{C}$ cal/degmole	
ZnS	13.8	ZnO	10.5
H <sub>2</sub> O	45.11	H <sub>2</sub> S	49.15
	58.91		59.65

$$\Delta S_{25}^{\circ}\text{C} = 58.91 - 59.65 = -0.74 \text{ cal/degmole}$$

using equation (3) above

$$-I_S = -(-0.74) + 1.05 \ln(298.16) + 1.2214 \times 10^{-3} (298.16) + \frac{4.962 \times 10^{-6} \times (298.16)^2}{2}$$

$$I_S = -7.3072$$

Having calculated the two integration constants:

$$I_H = -18,726$$

$$I_S = -7.3072$$

The free energy change at any temperature can now be calculated using equation (1)

$$\frac{\Delta G^0}{T} = \frac{I_H}{T} + (\Delta a - I_S) - \Delta a \ln T - \frac{\Delta b T^2}{2} - \frac{\Delta c T^3}{6} - \frac{\Delta d T^4}{12} - \frac{\Delta e}{2 T^2}$$

multiply by T

$$\Delta G^0 = I_H + (\Delta a - I_S)T - \Delta a T \ln T - \frac{\Delta b T^2}{2} - \frac{\Delta c T^3}{6} - \frac{\Delta d T^4}{12} - \frac{\Delta e}{2 T}$$

$$\Delta G_T^0 = -18,726 + 8.3572T - 1.05 T \ln T - 6.107 \times 10^{-4} T^2 - 8.27 \times 10^{-7} T^3 \quad (4)$$

Using equation (4) the free energy change of the reaction can be calculated for any temperature within the valid range of the heat capacity values. Table 2 lists the  $\Delta G_T^0$  calculated in this way.

A comparison was then made of this data with other published data to compare equilibrium constants. Table 3 shows the data calculated here, the data calculated by Gibson (Louisiana State University, Ph.D. thesis 1977, "Kinetics of the reactions of hydrogen sulfide and carbonyl sulfide with spherical zinc oxide particles"), and data from ICI published in the catalyst Handbook (1970).

Table 2

$^{\circ}\text{C}$	$^{\circ}\text{K}$	$\Delta G^{\circ}$ cal/gmole	$K_{eq}$
200	473	-18,056	$2.20 \times 10^8$
250	523	-18,078	$3.58 \times 10^7$
300	573	-18,114	$8.10 \times 10^6$
350	623	-18,166	$2.36 \times 10^6$
400	673	-18,232	$8.31 \times 10^5$
450	723	-18,313	$3.43 \times 10^5$
500	773	-18,410	$1.60 \times 10^5$
550	823	-18,524	$8.29 \times 10^4$
600	873	-18,653	$4.67 \times 10^4$
650	923	-18,800	$2.83 \times 10^4$
700	973	-18,964	$1.82 \times 10^4$
750	1023	-19,145	$1.23 \times 10^4$
800	1073	-19,346	$8.71 \times 10^3$
850	1123	-19,564	$6.41 \times 10^3$

Table 3

<sup>o</sup> C	SAI K <sub>eq</sub>	GIBSON K <sub>eq</sub>	ICI K <sub>eq</sub>
200	$2.20 \times 10^8$		$2.08 \times 10^8$
250	$3.58 \times 10^7$	$5.77 \times 10^7$	$3.48 \times 10^7$
300	$8.10 \times 10^6$	$1.20 \times 10^7$	$7.12 \times 10^6$
350	$2.36 \times 10^6$	$3.21 \times 10^6$	$2.04 \times 10^6$
400	$8.31 \times 10^5$	$1.04 \times 10^6$	$6.65 \times 10^5$
450	$3.43 \times 10^5$	$3.97 \times 10^5$	$2.64 \times 10^5$
500	$1.60 \times 10^5$	$1.71 \times 10^5$	$1.15 \times 10^5$
550	$8.29 \times 10^4$	$8.18 \times 10^4$	
600	$4.67 \times 10^4$	$4.25 \times 10^4$	
650	$2.82 \times 10^4$	$2.37 \times 10^4$	
700	$1.82 \times 10^4$	$1.40 \times 10^4$	
750	$1.23 \times 10^4$	$8.72 \times 10^3$	
800	$8.72 \times 10^3$	$5.67 \times 10^3$	
850	$6.42 \times 10^3$	$3.82 \times 10^3$	

Table 3 indicates some small differences in the equilibrium constants calculated by the three sources. These are probably due to different heat capacity values used in the calculations. Heat capacities can be found in the literature from various sources, and some differences do exist in the numbers obtained and the form of the empirical equation used. Figure 1 is a plot of the three sources of equilibrium constants in the form of an arrhenius plot. The relative differences of the equilibrium constants can be seen in the plot by the differences in the slope of the curves and their absolute values. The Gibson data appears to have a larger slope than either the SAI data or the ICI data, however it coincides with the SAI data at about 550°C. The ICI values almost match the SAI values at low temperatures (200-250°C) but deviate from both the Gibson and SAI values at higher temperatures.

Since it is difficult to assess the impact of these discrepancies in equilibrium values on the actual H<sub>2</sub>S level to be expected without actually calculating these values this was done in Table 4.

Table 4 shows that the largest discrepancies between the SAI values and Gibsons values are at the higher temperatures and at higher steam levels. In the temperatures range of interest for Hot Gas Desulfurization (approximately 550-650°C), the largest discrepancy is 2.02 ppm. The ICI values, which are not available above 500°C, would indicate larger discrepancies if extrapolated to higher temperatures.

Since experimental data at METC have verified the levels predicted by Gibson and SAI, it is felt that these values are valid, and can be used in experimental data analysis and process simulation. The calculation sequence outlined here provides a means of calculating equilibrium constants at any temperature based on heat capacity, free energy, heat of reaction, and entropy data, using basic thermodynamic principles. The accuracy of the results obtained are therefore directly related to the accuracy of the data used. The source of the data used here was specified, and is believed to be accurate.

In order to represent the H<sub>2</sub>S equilibrium values at varying temperatures and steam levels graphically, figure 2 was drawn. This plot was drawn using the equilibrium constants calculated here. It can be seen in the plot that at

Table 4

Equilibrium H <sub>2</sub> S Values in PPM									
°C	SAI Steam			Gibson Steam			ICI Steam		
	5%	15%	30%	5%	15%	30%	5%	15%	30%
250	.0014	.004	.008	.0008	.0026	.005	.0014	.0043	.0086
350	.0212	.063	.127	.0155	.0467	.093	.0245	.0735	.1470
450	.1457	.437	.875	.1259	.3778	.755	.1892	.5675	1.135
550	.6031	1.809	3.618	.6112	1.83	3.667			
650	1.773	5.319	10.63	2.10	6.33	12.65			
750	4.064	12.19	24.39	5.73	17.20	34.40			
850	7.79	23.36	46.72	13.08	39.26	78.53			

temperatures up to 450<sup>0</sup>C equilibrium H<sub>2</sub>S levels are below 1 ppm for all steam levels up to 30%. As temperatures increase above 450<sup>0</sup>C there is an accelerated increase of H<sub>2</sub>S with temperature, with a large increase between 550<sup>0</sup>C-650<sup>0</sup> at the high steam level. This plot can be used to determine the tradeoff between steam level and temperature in order to stay below 1 ppm H<sub>2</sub>S.

A computer code has been written to carry out the calculations outlined here and to produce a table containing the information shown in Table 2 and 4. The required input includes the following:

- o Heat of formation of products and reactants at 25<sup>0</sup>C
- o Entropy of products and reactants at 25<sup>0</sup>C
- o Heat capacity coefficients for products and reactants


Using this input data the code calculates the free energy change at various temperatures, the equilibrium constant, and equilibrium H<sub>2</sub>S levels at various steam levels. This code can now be used to test the effect of various sources and values of thermodynamics data and their effect on the equilibrium H<sub>2</sub>S levels calculated. A sample output is shown in Table 5.

FIGURE 1

P1

# ZNO EQUILIBRIUM CONSTANT

10-Nov-81 11:35:58




10-NOV-8: 15:15:17

-207-

FIGURE 2

H<sub>2</sub>S EQUILIBRIUM VALUES  
ZINC OXIDE SYSTEM



THERMCG CODE

C THIS PROGRAM CALCULATES THE EQUILIBRIUM CONSTANT FOR THE  
 C REACTION: ARSOLID + BRGAS GOING TO CPSOLID + DPGAS  
 C AT ANY TEMPERATURE WHERE A, B, C, D, ARE STOICHIOMETRIC  
 C COEFFICIENTS. RSOLID IS REACTANT SOLID, RGAS IS REACTANT  
 C GAS,PSOLID IS PRODUCT SOLID, AND PGAS IS PRODUCT GAS.

C READ STOICHIOMETRIC COEFFICIENTS A,B,C,D

C READ HEAT OF FORMATION OF PRODUCTS AND REACTANTS IN UNITS OF  
 C CALORIES/GMOLE AT 25 DEGREES CENTIGRADE.

C READ ENTROPY OF PRODUCTS AND REACTANTS IN UNITS OF CAL/DEGMOLE  
 C AT 25 DEGREES CENTIGRADE.

```

C IMPLICIT REAL*8(A-H,O-Z)
CHARACTER*80 SRCHPSOLID,SRCHPGAS,SRCHRSOLID,SRCHRGAS
CHARACTER*80 SRCSPSOLID,SRCSPGAS,SRCSRSOLID,SRCSRGA
CHARACTER*80 RSLD,PSLD
CHARACTER*80 SRC1,SRC2,SRC3,SRC4
REAL DELTAH,DELTA S,IH,IS,DELA,DELB,DELC,DELD,DELE
REAL*8 KEQ
EXTERNAL LIB$EMULATE
DIMENSION TEMP(20),DELG(20),POWER(20),KEQ(20)
DIMENSION H2S5(20),H2S10(20),H2S15(20),H2S20(20),H2S25(20),H2S30(20)
CALL LIB$ESTABLISH(LIB$EMULATE)
READ(9,*) A,B,C,D
READ(9,*) HPSOLID,HPGAS,HRSOLID,HRGAS
READ(9,*) SPSOLID,SPGAS,SRSOLID,SRGAS
C SPECIFY SOURCE OF THIS DATA
READ(9,5) SRCHPSOLID,SRCHPGAS,SRCHRSOLID,SRCHRGAS
READ(9,5) SRCSPSOLID,SRCSPGAS,SRCSRSOLID,SRCSRGA
5 FORMAT(A80)
READ(9,6) RSLD,PSLD
6 FORMAT(A80)
WRITE(6,500)
500 FORMAT(T40,'GENERAL GAS-SOLID EQUILIBRIUM CODE',//,
1 T10,'THERMODYNAMIC DATA',T80,'DATA SOURCE',/)
1 WRITE(6,50) PSLD,HPSOLID,SRCHPSOLID,HPGAS,SRCHPGAS,RSLD,HRSOLID,
1 SRCHRSOLID,HRGAS,SRCHRGAS
50 FORMAT(5X,A5,T10,'HEAT OF FORMATION (25 C) = ',1X,F8.3,3X,
1 'KCAL MOL-1',T65,A60,/,.5X,'H2O HEAT OF FORMATION (25 C) = '
1 ,1X,F8.3,3X,'KCAL MOL-1',T65,A60/,.5X,A5,T10,
1 'HEAT OF FORMATION (25 C) = ',1X,F8.3,3X,'KCAL MOL-1',T65,A60/.,
1 5X,'H2S HEAT OF FORMATION (25 C) = ',1X,F8.3,3X,'KCAL MOL-1',T65
1 ,A60)
1 WRITE(6,60) PSLD,SPSOLID,SRCSPSOLID,SPGAS,SRCSRGA,RSLD,SRSOLID,
1 SRCSRSOLID,SRGAS,SRCSRGA
60 FORMAT(//,5X,A5,T10,'ENTROPY (25 C) = ',F7.3,3X,'CAL K-1 MOL-1',
1 T65,A60/,.5X,'H2O ENTROPY (25 C) = ',F7.3,3X,'CAL K-1 MOL-1',
1 T65,A60/,.5X,A5,T10,'ENTROPY (25 C) = ',F7.3,3X,'CAL K-1 MOL-1',
1 T65,A60/,.5X,'H2S ENTROPY (25 C) = ',F7.3,3X,'CAL K-1 MOL-1',
1 T65,A60)
```

```

C
C      READ HEAT CAPACITY COEFFICIENTS FOR PRODUCTS AND REACTANTS
C      USING THE FOLLOWING CORRELATION:  CP = A+BT+CT2+DT3+E/T2
C      ASSIGN SUBSCRIPTS AS FOLLOWS:
C
C      RSOLID   A1    B1    C1    D1    E1
C      H2S       A2    B2    C2    D2    E2
C
C      PSOLID   A3    B3    C3    D3    E3
C      H2O       A4    B4    C4    D4    E4
C
C      READ(9,*)  A1,B1,C1,D1,E1
C      READ(9,*)  A2,B2,C2,D2,E2
C      READ(9,*)  A3,B3,C3,D3,E3
C      READ(9,*)  A4,B4,C4,D4,E4
C      READ SOURCE FOR HEAT CAPACITY COEFFICIENTS
C      READ(9,69)  SRC1
C      READ(9,69)  SRC2
C      READ(9,69)  SRC3
C      READ(9,69)  SRC4
69     FORMAT(A80)
      WRITE(6,70)
70     FORMAT(//,5X,'HEAT CAPACITY EQUATION IS
1      CP = A + BT + CT2 + DT3 + ET-2',10X,'CAL K-1 MOL-1')
      WRITE(6,80)
80     FORMAT(//,5X,'HEAT CAPACITY COEFFICIENTS',12X,'A',13X,'B',13X
1      , 'C',13X,'D',13X,'E',15X,'SOURCE')
      WRITE(6,90)  RSLD,A1,B1,C1,D1,E1,SRC1,A2,B2,C2,D2,E2,
1      SRC2,PSLD,A3,B3,C3,D3,E3,SRC3,A4,B4,C4,D4,E4,SRC4
90     FORMAT(//,15X,A5,T41,F5.2,5X,F10.8,5X,F11.9,5X,F11.9,5X,F11.2,5X,A12
1      ,/,15X,'H2S ',21X,F5.2,5X,F10.8,5X,F11.9,5X,F11.9,5X,F11.2,5X,A12
1      ,/,15X,A5,T41,F5.2,5X,F10.8,5X,F11.9,5X,F11.9,5X,F11.2,5X,A12,/,
1      15X,'H2O ',21X,F5.2,5X,F10.8,5X,F11.9,5X,F11.9,5X,F11.2,5X,A12)
C
C      CALCULATE DELTA A ,DELTA B DELTA C, DELTA D,DELTA E
C      PRODUCTS MINUS REACTANTS
C
      DELA = ((C*A3)+(D*A4))-((A*A1)+(B*B2))
      DELB = ((C*B3)+(D*B4))-((A*B1)+(B*B2))
      DELC = ((C*C3)+(D*C4))-((A*C1)+(B*C2))
      DELD = ((C*D3)+(D*D4))-((A*D1)+(B*D2))
      DELE = ((C*E3)+(D*E4))-((A*E1)+(B*E2))
C
C      CALCULATE DELTA H FOR THE REACTION FROM INPUT DATA
C
      DELTAH = (((C*HPSOLID)+(D*HPGAS))-((A*HRSOLID)+(B*HRGAS)))*1000.
C
C      CALCULATE INTEGRATION CONSTANT IH USING EQUATION 12 IN
C      HOUGEN WATSON AND RAGATZ PART II P. 986
C
      IH = DELTAH - DELA*(298.16) - (DELB/2.)*(298.16**2) - (DELC/3.)*
1      (298.16**3) - (DELD/4.)*(298.16**4) + DELE/298.16

```

```

C
C      CALCULATE DELTA S FOR THE REACTION FROM INPUT DATA
C
C      DELTAS = ((C*SPSOLID) + (D*SPGAS)) - ((A*SRSOLID) + (B*SRGAS))
C
C      CALCULATE INTEGRATION CONSTANT IS USING EQUATION 13 IN
C      HOUGEN WATSON AND RAGAZZ PART II P. 986
C
C      IS = DELTAS - DELA*LOG(298.16) - DELB*(298.16) - (DELC/2.)*
1    (298.16**2) - (DELD/3.)*(298.16**3) + DELE/(2.*(298.16**2))
C
C      HAVING CALCULATED INTEGRATION CONSTANTS IH AND IS
C      CALCULATE DELTA G FOR THE DESIRED TEMPERATURE RANGE
C      200 TO 850 CENTIGRADE
C
C      DO 10 I=1,14
C      TEMP(I) = 473 + (I-1)*50
C      DELG(I) = IH + (DELA - IS)*TEMP(I)-DELA*TEMP(I)*LOG(TEMP(I))
1    -DELB*((TEMP(I)**2)/2.) - DELC*((TEMP(I)**3)/6.)
1    -DELD*((TEMP(I)**4)/12.)-DELE/(2.*TEMP(I))
10   CONTINUE
C
C      CALCULATE EQUILIBRIUM CONSTANT
C
C      DO 20 I=1,14
C      POWER(I) = -DELG(I)/(1.9872*TEMP(I))
C      KEQ(I) = EXP(POWER(I))
20   CONTINUE
C
C      CALCULATE EQUILIBRIUM H2S COMPOSITIONS WITH VARIOUS STEAM LEVELS
C
C      DO 25 I=1,14
C      H2S5(I) = (((0.05**D)/KEQ(I))**((1/B)))*(1E6)
C      H2S10(I)= (((0.10**D)/KEQ(I))**((1/B)))*(1E6)
C      H2S15(I)= (((0.15**D)/KEQ(I))**((1/B)))*(1E6)
C      H2S20(I)= (((0.20**D)/KEQ(I))**((1/B)))*(1E6)
C      H2S25(I)= (((0.25**D)/KEQ(I))**((1/B)))*(1E6)
C      H2S30(I)= (((0.30**D)/KEQ(I))**((1/B)))*(1E6)
25   CONTINUE
C
C      CONVERT TEMPERATURE FROM KELVIN TO CENTIGRADE
C
C      DO 30 I=1,14
C      TEMP(I) = TEMP(I) -273.
30   CONTINUE
C
C      PRINTOUT TABLE OF DELTA G AND EQUILIBRIUM CONSTANTS GENERATED
C
C      WRITE(6,200)
200   FORMAT(1H,//,T4,11HTEMPERATURE,T20,7HDELTA G,T37,11HEQUILIBRIUM,
1    1 T73,28HEQUILIBRIUM H2S LEVEL IN PPM/1H,T4,9HDEGREES C,T20,
1    1 9HCAL/GMOLE,T37,8HCONSTANT,T80,13HPERCENT STEAM//1H,T62,2H5%,
1    1 T70,3H10%,T80,3H15%,T90,3H20%,T100,3H25%,T110,3H30%/)

```

```
DO 40 I=1,14
      WRITE(6,300) TEMP(I),DELG(I),KEQ(I),H2S5(I),H2S10(I),H2S15(I),
1    H2S20(I),H2S25(I),H2S30(I)
300  FORMAT(1H,T8,F4.0,T20,F10.2,T37,2PG10.3,T57,6(2PG10.2),/)
40   CONTINUE
      STOP
      END
```

## **Simultaneous Shift/Methanation Equilibrium Calculations**

### **Reference:**

**H.P. Meissner, C. L. Kusik, W. H. Dalzell  
Equilibrium Compositions with Multiple Reactions**

**Note: The following are results obtained from a computer code used to calculate simultaneous shift/methanation equilibria**

RUN

RGEQ

3-AUG-1982 08:54

? .5029  
? 2.527  
? .0001  
? 1112

GAS COMPOSITIONS 1112 F

INLET            OUTLET

MOL %            MOL %

H2S =	2.700	0.0
H2O =	25.00	20.19
CO2 =	9.79	14.73
CO =	11.69	7.59
H2 =	17.13	26.27
CH4 =	2.91	1.35
N2 =	30.78	29.87

Ready

RUN

RGEQ

3-AUG-1982 08:55

? 2.486  
? 1.923  
? .001  
? 1202

GAS COMPOSITIONS 1202 F

INLET            OUTLET

MOL %            MOL %

H2S =	2.700	0.0
H2O =	25.00	19.97
CO2 =	9.79	13.32
CO =	11.69	9.53
H2 =	17.13	27.50
CH4 =	2.91	0.37
N2 =	30.78	29.30

Ready

RUN  
RGEQ

3-AUG-1982 08:52

? .009442  
? 4.878  
? .000001  
? 932

GAS COMPOSITIONS 932 F

	INLET	OUTLET
	MOL %	MOL %
H2S =	2.700	0.0
H2O =	25.00	24.60
CO2 =	9.79	17.46
CO =	11.69	2.52
H2 =	17.13	17.35
CH4 =	2.91	5.68
N2 =	30.78	32.39

Ready

RUN  
RGEQ

3-AUG-1982 08:53

? .07741  
? 3.434  
? .00001  
? 1022

GAS COMPOSITIONS 1022 F

	INLET	OUTLET
	MOL %	MOL %
H2S =	2.700	0.0
H2O =	25.00	21.84
CO2 =	9.79	16.34
CO =	11.69	4.91
H2 =	17.13	22.55
CH4 =	2.91	3.33
N2 =	30.78	31.02

Ready

RUN  
RGEQ

3-AUG-1982 08:57

? .009442  
? 4.878  
? .000001  
? 932

GAS COMPOSITIONS 932 F

	INLET	OUTLET
	MOL %	MOL %
H <sub>2</sub> S =	2.70	0.0
H <sub>2</sub> O =	0.0	4.38
CO <sub>2</sub> =	9.79	13.62
CO =	11.69	5.34
H <sub>2</sub> =	17.13	8.37
CH <sub>4</sub> =	2.91	7.58
N <sub>2</sub> =	55.78	60.70

Ready

RUN  
RGEQ

3-AUG-1982 08:57

? .07741  
? 3.434  
? .00001  
? 1022

GAS COMPOSITIONS 1022 F

	INLET	OUTLET
	MOL %	MOL %
H <sub>2</sub> S =	2.70	0.0
H <sub>2</sub> O =	0.0	4.20
CO <sub>2</sub> =	9.79	10.97
CO =	11.69	9.28
H <sub>2</sub> =	17.13	12.19
CH <sub>4</sub> =	2.91	5.18
N <sub>2</sub> =	55.78	58.17

Ready

RUN  
RGEQ

3-AUG-1982 09:00

? .5029  
? 2.527  
? .0001  
? 1112

GAS COMPOSITIONS 1112 F

	INLET	OUTLET
	MOL %	MOL %
H2S =	2.70	0.0
H2O =	0.0	3.99
CO2 =	9.79	8.31
CO =	11.69	13.26
H2 =	17.13	16.08
CH4 =	2.91	2.75
N2 =	55.78	55.61

Ready

RUN  
RGEQ

3-AUG-1982 09:01

? 2.686  
? 1.923  
? .001  
? 1202


GAS COMPOSITIONS 1202 F

	INLET	OUTLET
	MOL %	MOL %
H2S =	2.70	0.0
H2O =	0.0	3.88
CO2 =	9.79	6.39
CO =	11.69	14.11
H2 =	17.13	18.80
CH4 =	2.91	1.03
N2 =	55.78	53.80

Ready


## HOT GAS CLEANUP FLOW SCHEMATIC

Laboratory-Scale Reactor Drawings





Schematic Drawing of Test Unit

Safety Fins



SECTION AA



DESIGN CONDITIONS  
HYDROSTATIC TEST:  
DESIGN: 100°F - 100 PSIG  
TEST: 100°F - 250 PSIG

SHEET NUMBER & REVISION NUMBER		REVISION DATE	
MATERIALS TESTER, R.V.A.		REVISION DATE	
DATE	REVISED BY	REVISION DATE	REVISION NUMBER
10/12/73	REVISOR	10/12/73	1
10/12/73	REVISOR	10/12/73	2
10/12/73	REVISOR	10/12/73	3
10/12/73	REVISOR	10/12/73	4
10/12/73	REVISOR	10/12/73	5
10/12/73	REVISOR	10/12/73	6
10/12/73	REVISOR	10/12/73	7
10/12/73	REVISOR	10/12/73	8
10/12/73	REVISOR	10/12/73	9
10/12/73	REVISOR	10/12/73	10
10/12/73	REVISOR	10/12/73	11
10/12/73	REVISOR	10/12/73	12
10/12/73	REVISOR	10/12/73	13
10/12/73	REVISOR	10/12/73	14
10/12/73	REVISOR	10/12/73	15
10/12/73	REVISOR	10/12/73	16
10/12/73	REVISOR	10/12/73	17
10/12/73	REVISOR	10/12/73	18
10/12/73	REVISOR	10/12/73	19
10/12/73	REVISOR	10/12/73	20
10/12/73	REVISOR	10/12/73	21
10/12/73	REVISOR	10/12/73	22
10/12/73	REVISOR	10/12/73	23
10/12/73	REVISOR	10/12/73	24
10/12/73	REVISOR	10/12/73	25
10/12/73	REVISOR	10/12/73	26
10/12/73	REVISOR	10/12/73	27
10/12/73	REVISOR	10/12/73	28
10/12/73	REVISOR	10/12/73	29
10/12/73	REVISOR	10/12/73	30
10/12/73	REVISOR	10/12/73	31
10/12/73	REVISOR	10/12/73	32
10/12/73	REVISOR	10/12/73	33
10/12/73	REVISOR	10/12/73	34
10/12/73	REVISOR	10/12/73	35
10/12/73	REVISOR	10/12/73	36
10/12/73	REVISOR	10/12/73	37
10/12/73	REVISOR	10/12/73	38
10/12/73	REVISOR	10/12/73	39
10/12/73	REVISOR	10/12/73	40
10/12/73	REVISOR	10/12/73	41
10/12/73	REVISOR	10/12/73	42
10/12/73	REVISOR	10/12/73	43
10/12/73	REVISOR	10/12/73	44
10/12/73	REVISOR	10/12/73	45
10/12/73	REVISOR	10/12/73	46
10/12/73	REVISOR	10/12/73	47
10/12/73	REVISOR	10/12/73	48
10/12/73	REVISOR	10/12/73	49
10/12/73	REVISOR	10/12/73	50
10/12/73	REVISOR	10/12/73	51
10/12/73	REVISOR	10/12/73	52
10/12/73	REVISOR	10/12/73	53
10/12/73	REVISOR	10/12/73	54
10/12/73	REVISOR	10/12/73	55
10/12/73	REVISOR	10/12/73	56
10/12/73	REVISOR	10/12/73	57
10/12/73	REVISOR	10/12/73	58
10/12/73	REVISOR	10/12/73	59
10/12/73	REVISOR	10/12/73	60
10/12/73	REVISOR	10/12/73	61
10/12/73	REVISOR	10/12/73	62
10/12/73	REVISOR	10/12/73	63
10/12/73	REVISOR	10/12/73	64
10/12/73	REVISOR	10/12/73	65
10/12/73	REVISOR	10/12/73	66
10/12/73	REVISOR	10/12/73	67
10/12/73	REVISOR	10/12/73	68
10/12/73	REVISOR	10/12/73	69
10/12/73	REVISOR	10/12/73	70
10/12/73	REVISOR	10/12/73	71
10/12/73	REVISOR	10/12/73	72
10/12/73	REVISOR	10/12/73	73
10/12/73	REVISOR	10/12/73	74
10/12/73	REVISOR	10/12/73	75
10/12/73	REVISOR	10/12/73	76
10/12/73	REVISOR	10/12/73	77
10/12/73	REVISOR	10/12/73	78
10/12/73	REVISOR	10/12/73	79
10/12/73	REVISOR	10/12/73	80
10/12/73	REVISOR	10/12/73	81
10/12/73	REVISOR	10/12/73	82
10/12/73	REVISOR	10/12/73	83
10/12/73	REVISOR	10/12/73	84
10/12/73	REVISOR	10/12/73	85
10/12/73	REVISOR	10/12/73	86
10/12/73	REVISOR	10/12/73	87
10/12/73	REVISOR	10/12/73	88
10/12/73	REVISOR	10/12/73	89
10/12/73	REVISOR	10/12/73	90
10/12/73	REVISOR	10/12/73	91
10/12/73	REVISOR	10/12/73	92
10/12/73	REVISOR	10/12/73	93
10/12/73	REVISOR	10/12/73	94
10/12/73	REVISOR	10/12/73	95
10/12/73	REVISOR	10/12/73	96
10/12/73	REVISOR	10/12/73	97
10/12/73	REVISOR	10/12/73	98
10/12/73	REVISOR	10/12/73	99
10/12/73	REVISOR	10/12/73	100

334-891

SECTION BB

334-891

APPENDIX D  
Laboratory-Scale Test Summary Sheets and Data Curves

TEST SUMMARY SHEET

TEST NO. : 001  
 DATE STARTED : 7/30/80  
 DATE ENDED : 7/31/80  
 TOTAL HOURS : 28  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IRON OXIDE EXTRUSIONS FOR  
 REGENERATION TESTS TO VERIFY AIR PRODUCTS  
 TEST RESULTS IN WHICH ELEMENTAL SULFUR WAS  
 PRODUCED DURING REGENERATION

SORBENT TYPE/WEIGHT: IRON OXIDE/936 G  
 SORBENT NO. : 811X3-1X1  
 SORBENT COMPOSITION: 42% IRON OXIDE (YOUNGSTOWN SHEET & TUBE)  
 ON SILICA  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 FRETREATMENT : NONE  
 SULFUR LOADING : 4.7 X (GM SULFUR/GM FRESH SORBENT)  
 TO 400 PPM BREAKTHROUGH

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):	0.05	6.42 (EXIT)
SURFACE AREA (M <sup>2</sup> /G):	0.75	1.07
DENSITY (G/CM <sup>3</sup> ):	3.15	3.37
PORE VOLUME (MM <sup>3</sup> /G):	0.4	2.5
MINERAL ANALYSIS :	SEE APPENDIX	
ELEMENTAL ANALYSIS :	SEE APPENDIX	

Note: Please disregard  
 references to Appendix  
 for all Test Summary  
 Sheets included herein.

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 800 HOURLY

DATA: ( DETECTOR TUBE )

EXIT H2S: 200-400 PPM PLATEAU  
 3000 PPM AT BREAKTHROUGH  
 EXIT SO2:  
 EXIT S2:  
 EXIT H2:

REMARKS

1. SULFUR LOADING CORRESPONDS TO BREAKTHROUGH FROM PLATEAU.
2. REACTOR TEMPERATURE PROFILE WAS NOT MAINTAINED WITHIN 50 DEGREES OF 1000 F.
3. THIS TEST SERVED TO SHAKEDOWN THE TEST EQUIPMENT. ONLY ONE MALFUNCTION WAS EXPERIENCED (H2S REGULATOR REPLACED).

CONCLUSIONS

1. IRON OXIDE CAN REDUCE THE SULFUR LEVEL IN A HOT GAS STREAM FROM 7000 PPM TO 200-400 PPM IN THE PRESENCE OF 7X WATER.
2. SULFIDED IRON OXIDE IS READY FOR REGENERATION.

## TEST SUMMARY SHEET

TEST NO.	:	002
DATE STARTED	:	10/16/80
DATE ENDED	:	10/24/80
TOTAL HOURS	:	39
TYPE	:	REGENERATION

## PURPOSE

VERIFICATION OF AIR PRODUCTS TEST RESULTS  
IN WHICH ELEMENTAL SULFUR WAS PRODUCED  
DURING REGENERATION.

SORBENT TYPE/WEIGHT: IRON OXIDE/936 G  
 SORBENT NO.: 811X3-1X1  
 SORBENT COMPOSITION: 42% IRON OXIDE (YOUNGSTOWN SHEET & TUBE)  
 ON SILICA  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR REMOVED :

## ANALYSIS

	BEFORE	AFTER
TOTAL SULFUR (%U/U)	6.42 (EXIT)	0.16 (EXIT)
SURFACE AREA (M <sup>2</sup> /G)	1.07	
DENSITY (G/CM <sup>3</sup> )	3.371	
PORE VOLUME (MM <sup>3</sup> /G)	2.5	
MINERAL ANALYSIS	SEE APPENDIX	
ELEMENTAL ANALYSIS	SEE APPENDIX	

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538C)

PRESSURE : AMBIENT

SPACE VELOCITY: 600 HOURLY

## DATA (TUTUILER METHOD)

EXIT H2S: 7.2 %

EXIT SO<sub>2</sub>: NONE BY TUTUILER (AVG)  
 EXCEPT AT END OF RUN

EXIT S<sub>2</sub>: 122.1 G

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	4.24 CM <sup>3</sup> /MIN	95 %
AIR (0.28 DM <sup>3</sup> /MIN) 0.588 SCF/HR		5 %
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		

## REMARKS

1. DESIRED TEMPERATURE WAS NOT MAINTAINED
2. ESSENTIALLY COMPLETE REGENERATION WAS ACHIEVED AS CALCULATED BY MATERIAL BALANCE, AND SHOWN BY ANALYSIS.

## CONCLUSIONS

1. HIGH ELEMENTAL SULFUR YIELDS ARE ACHIEVABLE WITH STEAM/AIR REGENERATION (95 %/ 5 %).
2. 76.8 % OF THE SULFUR REMOVED WAS IN THE FORM OF ELEMENTAL SULFUR.

TEST SUMMARY SHEET

TEST NO. : 063  
 DATE STARTED : 11/3/80  
 DATE ENDED : 11/3/80  
 TOTAL HOURS : 8.5  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IRON OXIDE EXTRUSIONS FOR  
 SUBSEQUENT REGENERATION TESTS USING 90%  
 STEAM AND 10% AIR.

SORBENT TYPE/WEIGHT: IRON OXIDE/936 G  
 SORBENT NO. : 811X3-1X1  
 SORBENT COMPOSITION: 42% IRON OXIDE(VYDUNGSTOWN SHEET & TUBE)  
 ON SILICA  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : 4.47% (GM SULFUR/GM FRESH SORBENT)  
 TO 400 PPM BREAKTHROUGH

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):		
DENSITY (GM/CM <sup>3</sup> ):		
PORE VOLUME (MM <sup>3</sup> /G):		
MINERAL ANALYSIS :		
ELEMENTAL ANALYSIS :		

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1013 HOURLY

DATA: (DETECTOR TUBE)

EXIT H25: UP TO 1900 PPM PLATEAU  
 EXIT SO2: 11000 PPM AT BREAKTHROUGH  
 EXIT S2:  
 EXIT H2:

FLOW RATE	MOLE
H2S (0.26 DM <sup>3</sup> /MIN) 0.545 SCFH	2.7%
H2O	0.52 CM <sup>3</sup> /MIN 6.9%
AIR	
CO <sub>2</sub>	
CO	
H2 (1.38 DM <sup>3</sup> /MIN) 2.92 SCFH	14.6%
CH4	
H2 (7.13 DM <sup>3</sup> /MIN) 15.11 SCFH	75.8%

REMARKS

1. REACTOR INLET TEMP LOW BY 75-100 F DURING RUN.

CONCLUSIONS

1. AT SV-1013 AND 2.7% H2S INLET CONCENTRATION  
 IN THE PRESENCE OF 6.9% WATER, STEADY STATES  
 DESULFURIZATION WAS MAINTAINED FOR 5 HRS.
2. SULFIDATION CAN BE COMPLETED IN ONE DAY.

TEST SUMMARY SHEET

TEST NO.	:	904
DATE STARTED	:	11/05/80
DATE ENDED	:	11/06/80
TOTAL HOURS	:	20.5
TYPE	:	REGENERATION

PURPOSE  
REGENERATION OF IRON OXIDE EXTRUSIONS USING 90% STEAM AND 10% AIR.

SORBENT TYPE/WEIGHT:	IRON OXIDE/936 G	
SORBENT NO.:	811X3-1X1	
SORBENT COMPOSITION:	42% IRON OXIDE (YOUNGSTOWN SHEET & TUBE) ON SILICA	
SORBENT SIZE	:	1/4 INCH DIAMETER EXTRUSIONS
PRETREATMENT	:	NONE
SULFUR REMOVED	:	

ANALYSIS

	BEFORE	AFTER
TOTAL SULFUR (XU/U)		
SURFACE AREA (M <sup>2</sup> /G)		
DENSITY (G/CM <sup>3</sup> )		
PORE VOLUME (MM <sup>3</sup> /G)		
MINERAL ANALYSIS		
ELEMENTAL ANALYSIS		

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 622 HOURLY

DATA: (TUTUILER METHOD)

EXIT H<sub>2</sub>S: 5000-6000 PPM (BY DETECTOR TUBES)

EXIT SO<sub>2</sub>: GREATER THAN 3000 PPM (BY TUTUILER)

EXIT S<sub>2</sub>: 19.41 G

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	4.2 CM <sup>3</sup> /MIN	59 %
AIR (0.56 DM <sup>3</sup> /MIN) 1.18 SCF/HR		19 %
CO <sub>2</sub>		
CO		
N <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub> O		

REMARKS

- 1.
- 2.

CONCLUSIONS

1. ELEMENTAL SULFUR YIELDS ARE SIGNIFICANTLY LOWER WITH 90%/10% STEAM-AIR REGENERATION.
- 2.

TEST SUMMARY SHEET

TEST NO.	:	605
DATE STARTED	:	1/28/81
DATE ENDED	:	1/28/81
TOTAL HOURS	:	8.5
TYPE	:	SULFIDATION

PURPOSE

SULFIDATION OF IRON OXIDE EXTRUSIONS FOR  
SUBSEQUENT REGENERATION TESTS USING 50%  
STEAM AND 50% AIR.

SORBENT TYPE/WEIG WT:	IRON OXIDE/1000 G
SORBENT NO.:	811X3-1X1
SORBENT COMPOSITION:	42% IRON OXIDE(YOUNGSTOWN SHEET & TUBE) ON SILICA
SORBENT SIZE	: 1/4 INCH DIAMETER EXTRUSIONS
PRETREATMENT	: NONE
SULFUR LOADING	: 10.4 % (GM SULFUR/GM FRESH SORBENT.) TO 400 PPM BREAKTHROUGH

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR(XU/U):		
SURFACE AREA(M2/G):		
DENSITY (G/CM3):		
PORE VOLUME (MM3/G):		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

OPERATING CONDITIONS

TEMPERATURE:	1000 F (538 C)
PRESSURE :	AMBIENT
SPACE VELOCITY:	900 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:	6 PPM PLATEAU FOR 3 HOURS
EXIT SO2:	BREAKTHROUGH AT 4 HOURS WITH 160 PPM
EXIT S2:	
EXIT H2:	

FLOW RATE	MOLE
H2S (0.26 DM3/MIN) 0.545 SCFH	2.7%
H2O	0.52 CM3/MIN 6.9%
AIR	
CO2	
CO	
H2 (1.38 DM3/MIN) 2.92 SCFH	14.6%
CH4	
H2 (7.13 DM3/MIN) 15.11 SCFH	75.8%

REMARKS

1. TEMPERATURE CONTROL WITHIN 40 F OF ABSORBER OPERATING TEMPERATURE.

CONCLUSIONS

1. AT TEST CONDITIONS IRON OXIDE CAN REDUCE EXIT H2S TO BELOW 10 PPM FOR 3 HOURS AND BELOW 1000 PPM FOR 6 HOURS.

TEST SUMMARY SHEET

TEST NO. : 806  
 DATE STARTED : 1/29/81  
 DATE ENDED : 1/29/81  
 TOTAL HOURS : 7.5  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF IRON OXIDE EXTRUSIONS  
 USING 50% STEAM AND 50% AIR.

SORBENT TYPE/WEIGHT: IRON OXIDE/1000 G  
 SORBENT NO.: 811X3-1X1  
 SORBENT COMPOSITION: 42% IRON OXIDE(YOUNGSTOWN SHEET & TUBE)  
 ON SILICA  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR REMOVED :

ANALYSIS:  
 BEFORE AFTER  
 TOTAL SULFUR (%W/W): 0.7  
 SURFACE AREA (M<sup>2</sup>/G): 0.94  
 DENSITY (GM/CM<sup>3</sup>): 3.18  
 PORE VOLUME (MM<sup>3</sup>/G): 1.8  
 MINERAL ANALYSIS : SEE APPENDIX  
 ELEMENTAL ANALYSIS : SEE APPENDIX

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S: 1000-1200 PPM  
 EXIT SO<sub>2</sub>: 4-7 %  
 EXIT S<sub>2</sub>: 2.514 G  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.49 CM <sup>3</sup> /MIN	50%
AIR (3.11 DM <sup>3</sup> /MIN) 6.58 SCFM		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		

REMARKS

1. TEMPERATURE WAVE REACHING APPROX. 1500 F WAS OBSERVED.

CONCLUSIONS


1. ELEMENTAL SULFUR PRODUCED IS GREATLY DECREASED WITH STEAM LEVEL REDUCED TO 50 %.

19-MAY-81 15:40:06

P:

# IRON OXIDE SULFIDATION

TEST 001



-222-


19-MAY-81 10:21:32

-E77-

P:

# IRON OXIDE SULFIDATION


TEST 003



# IRON OXIDE SULFIDATION

TEST 005

19-MAY-81 10:20:00




19-MAR-81 10:18:34

P:

# IRON OXIDE SULFIDATION


TEST 005



P:

# IRON OXIDE SULFIDATION

TEST 005




19-MAY-81 10:17:14

22-MAY-81 14:13:27

-227-


IRON OXIDE SULFIDATION  
TESTS 001,003,005



IRON OXIDE REGENERATION  
TEST 006

-228-

23-SEP-81 16:18:58



TEST SUMMARY SHEET

TEST NO.	807
DATE STARTED	1/30/81
DATE ENDED	1/30/81
TOTAL HOURS	12.5
TYPE	SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
REGENERATION CHARACTERISTICS.

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/800 G
SORBENT NO.:	BATCH 81/1
SORBENT COMPOSITION:	50 MOLEX IRON OXIDE (FISHER CERTIFIED) 50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)
SORBENT SIZE:	1/4 INCH DIAMETER EXTRUSIONS
PRETREATMENT:	DRIED IN OVEN AT 200 F OVERNIGHT
SULFUR LOADING:	21.3 % (GM SULFUR/GM FRESH SORBENT) TO 10 PPM BREAKTHROUGH

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):	5.84	
DENSITY (G/CM <sup>3</sup> ):	5.19	
PORE VOLUME (MM <sup>3</sup> /G):		
MINERAL ANALYSIS:	SEE APPENDIX	
ELEMENTAL ANALYSIS:		12.2

OPERATING CONDITIONS

TEMPERATURE:	1000 F (538 C)
PRESSURE:	AMBIENT
SPACE VELOCITY:	1000 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:	2 PPM PLATEAU FOR 7 HRS BREAKTHROUGH AT 8 HRS WITH 10 PPM
EXIT SO2:	
EXIT S2:	
EXIT H2:	

FLOW RATE	MOLE
H2S (0.25 DM <sup>3</sup> /MIN) 0.529 SCFH	2.7%
H2O	0.513 CM <sup>3</sup> /MIN 6.9%
AIR	
CO <sub>2</sub>	
CO	
H <sub>2</sub> (1.35 DM <sup>3</sup> /MIN) 2.86 SCFH	14.6%
CH <sub>4</sub>	
N <sub>2</sub> (7.02 DM <sup>3</sup> /MIN) 14.87 SCFH	75.8%

REMARKS

1. ABSORBER TEMPERATURES CONTROLLED WITHIN 50 F.
2. PREHEATER GRADUALLY PLUGGED DURING RUN.
3. ANALYSIS OF PLUG MATERIAL BY X-RAY DIFFRACTION SHOWS THAT THE PREHEATER TUBING (304 S/S) WAS CORRODING DUE TO H<sub>2</sub>S AND HIGH TEMP.

CONCLUSIONS

1. ZINC FERRITE AS TESTED CAN REDUCE A GAS STREAM CONTAINING 2.7% H<sub>2</sub>S TO 2 PPM H<sub>2</sub>S IN THE PRESENCE OF 6.9 % WATER AT 1000 F.
2. ZINC FERRITE AS TESTED CAN REDUCE A GAS STREAM CONTAINING 2.7% H<sub>2</sub>S TO LOWER LEVELS THAN POSSIBLE WITH IRON OXIDE AND WILL TAKE APPROXIMATELY TWICE AS LONG TO REACH BREAKTHROUGH.

TEST SUMMARY SHEET

TEST NO. : 608  
 DATE STARTED : 1/31/81  
 DATE ENDED : 2/1/81  
 TOTAL HOURS : 12.5  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE EXTRUSIONS  
 FROM TEST 607 USING 50% AIR AND 50% STEAM.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/800 G  
 SORBENT NO. : BATCH 81/1  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
 50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED IN OVEN AT 200 F OVERNIGHT(BEFORE T607)  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR (%W/W): BEFORE AFTER  
 SURFACE AREA (M<sup>2</sup>/G): 0.37 (AUG)  
 DENSITY (G/CM<sup>3</sup>): 2.65 (AUG)  
 PORE VOLUME (MM<sup>3</sup>/G): 5.22 (AUG)  
 MINERAL ANALYSIS: SEE APPENDIX  
 ELEMENTAL ANALYSIS: SEE APPENDIX

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT N<sub>2</sub>S: 2000 PPM  
 EXIT SO<sub>2</sub>: 4-9 %  
 EXIT S<sub>2</sub>: 7.88 G  
 EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	2.23 CM <sup>3</sup> /MIN	50%
AIR (2.78 DM <sup>3</sup> /MIN) 5.88 SCFH		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		
S		

REMARKS

1. TEMPERATURE WAVE UP TO 1780 F OBSERVED.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

CONCLUSIONS

1. REGENERATION TIME APPROXIMATELY THE SAME AS FOR IRON OXIDE.

TEST SUMMARY SHEET

TEST NO.	:	009
DATE STARTED	:	2/03/81
DATE ENDED	:	2/03/81
TOTAL HOURS	:	12.75
TYPE	:	SULFIDATION

## **PURPOSE**

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
REGENERATION CHARACTERISTICS. THIS IS THE SECOND  
SULFIDATION CYCLE OF THIS BATCH OF SORBENT.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/800 G  
 SORBENT NO.: BATCH 81/1  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
                       50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS MSA)  
  
 SORBENT SIZE: 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT: DRIED IN OVEN AT 200 F OVERNIGHT(BEFORE TEST)  
 SULFUR LOADING: 18.7 % (GM SULFUR/GM FRESH SORBENT)  
  
                       TO 13 PPM BREAKTHROUGH

**ANALYSES:**  
**TOTAL SULFUR(XS/U):**  
**SURFACE AREA(M<sup>2</sup>/G):**  
**DENSITY(G./CM<sup>3</sup>):** 3  
**PORE VOLUME (MM<sup>3</sup>/G):**  
**MINERAL ANALYSIS:**  
**ELEMENTAL ANALYSIS:**

### **BEFORE**

## **OPERATING CONDITIONS**

TEMPERATURE: 1000 F (538C)

DATASPECTOR TUBE

#### PRESSURE      |      AMBIENT

更多資訊請上網查詢：[www.sohu.com](http://www.sohu.com) 或撥打電話：400-810-1000

**SPACE VELOCITY: 1000 HOURLY**

BREAKTHROUGH AT 3 HOURS WITH 13 PPM

	FLOW RATE	POLE
H2S (0.25 DM3/MIN)	0.529 SCFH	2.7%
H2O	0.513 CM3/MIN	6.9%
AIR		
C		
CO		
H2 (1.35 DM3/MIN)	2.86 SCFH	14.6%
CH4		
N2 (7.92 DM3/MIN)	14.87 SCFH	75.8%

**REMARKS**

1. PREHEATER TUBE WAS REPLACED PRIOR TO THIS RUN  
WITH ANOTHER 304 S/S TUBE.

#### **CONCLUSIONS**

1. DESULFURIZATION WAS ACHIEVED TO THE SAME LEVEL AS DURING THE FIRST CYCLE ON THIS SORBENT.
  2. BREAKTHROUGH OCCURRED ONE HOUR SOONER DURING THE SECOND CYCLE.

## TEST SUMMARY SHEET

TEST NO. : 010  
 DATE STARTED : 2/3/81  
 DATE ENDED : 2/3/81  
 TOTAL HOURS : 12.5  
 TYPE : REGENERATION

## PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS  
 FROM TEST 009 USING 50% AIR AND 50% STEAM.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/800 G  
 SORBENT NO. : BATCH 81/1  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
                       50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED IN OVEN AT 200 F OVERNIGHT (BEFORE T007)  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR(%)  
 SURFACE AREA(m<sup>2</sup>/G)  
 DENSITY (G/CM<sup>3</sup>)  
 PORE VOLUME(MM<sup>3</sup>/G)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

## DATA: (DETECTOR TUBE)

EXIT H2S: 2000-3000 PPM

PRESSURE : AMBIENT

EXIT SO2: 4-10 %

SPACE VELOCITY: 600 HOURLY

EXIT S2: 4.4796 G

EXIT H2:

## FLOW RATE      MOLE

H2S

H2O      2.23 CM<sup>3</sup>/MIN 50%

AIR (2.78 DM<sup>3</sup>/MIN) 5.88 SCFM      50%

CO<sub>2</sub>

CO

H2

CH<sub>4</sub>

N<sub>2</sub>

## REMARKS

1. TEMPERATURE WAVE UP TO 1730 F OBSERVED.

2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER  
 TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. THIS WAS THE SECOND REGENERATION OF THE SAME  
 BATCH OF SORBENT. REGENERATION APPEARS NORMAL.

2. WIDE SCATTER IN SO<sub>2</sub> DATA DURING REGENERATION

# TEST SUMMARY SHEET

TEST NO. : 011A  
 DATE STARTED : 2/05/81  
 DATE ENDED : 2/05/81  
 TOTAL HOURS : 0.5  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
 REGENERATION CHARACTERISTICS. THIS IS THE THIRD  
 SULFIDATION CYCLE OF THIS BATCH OF SORBENT.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/800 G  
 SORBENT NO. : BATCH #1/1  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
                   50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE: 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT: DRIED IN OVEN AT 200 F OVERNIGHT(BEFORE TEST)  
 SULFUR LOADING:

ANALYSIS:  
 TOTAL SULFUR(XU/U);  
 SURFACE AREA(M<sup>2</sup>/G);  
 DENSITY(G/CM<sup>3</sup>);  
 PORE VOLUME(MM<sup>3</sup>/G);  
 MINERAL ANALYSIS;  
 ELEMENTAL ANALYSIS;

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1000 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2:  
 EXIT S2:  
 EXIT H2:

FLOW RATE	MOLE
H2S (0.25 DM <sup>3</sup> /MIN) 0.529 SCFH	2.7%
H2O	0.513 CM <sup>3</sup> /MIN 6.9%
AIR	
CO <sub>2</sub>	
CO	
H2 (1.35 DM <sup>3</sup> /MIN) 2.86 SCFH	14.6%
CH4	
N2 (7.08 DM <sup>3</sup> /MIN) 14.87 SCFH	75.8%

## REMARKS

1. DURING HEAT UP FOR THIS RUN THE ABSORBER WAS INADVERTENTLY EXPOSED TO APPROXIMATELY 30% H2S FOR 30 MINUTES. THIS OCCURRED AT APPROX. 1000 F.
2. THE RUN WAS ABORTED AFTER IT WAS DETERMINED THAT THE H2S HAS BROKEN THROUGH, AND REGENERATION INITIATED.

## CONCLUSIONS

- 1.

TEST SUMMARY SHEET

TEST NO. : 011B  
 DATE STARTED : 2/06/81  
 DATE ENDED : 2/06/81  
 TOTAL HOURS : 12.75  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
 REGENERATION CHARACTERISTICS. THIS IS THE THIRD  
 SULFIDATION CYCLE OF THIS BATCH OF SORBENT.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/800 G  
 SORBENT NO. : BATCH #1/1  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 1/4 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED IN OVEN AT 200 F OVERNIGHT(BEFORE T007)  
 SULFUR LOADING : 21.38 % (GM SULFUR/GM FRESH SORBENT)  
 TO 11 PPM BREAKTHROUGH

ANALYSIS:

	BEFORE	AFTER	
TOTAL SULFUR (XU/U):	26.42	(AUG)	
SURFACE AREA (M2/G):	1.4	(AUG)	
DENSITY (G/CM3):	4.42	(AUG)	
PORE VOLUME (MH3/G):	2.9	(AUG)	

MINERAL ANALYSIS: SEE APPENDIX  
 ELEMENTAL ANALYSIS: SEE APPENDIX

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1000 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S: 2-6 PPM PLATEAU FOR 7 HOURS  
 EXIT SO2: BREAKTHROUGH AT 8 HOURS WITH 11 PPM  
 EXIT S2:  
 EXIT H2:

FLOW RATE	MOLE
H2S (0.25 DM3/MIN) 0.529 SCFH	2.7%
H2O	0.513 CM3/MIN 6.9%
AIR	
CO2	
CO	
H2 (1.35 DM3/MIN) 2.86 SCFH	14.6%
CH4	
N2 (7.62 DM3/MIN) 14.87 SCFH	75.8%

REMARKS

- PRIOR TO THIS RUN (RUN 011A), THE SORBENT WAS INADVERTENTLY EXPOSED TO APPROXIMATELY 30% H2S FOR 30 MINUTES AND THEN IMMEDIATELY REGENERATED.
- AFTER REGENERATION THE SORBENT SEEMS TO HAVE RECOVERED ITS ACTIVITY AS SEEN BY THE TEST DATA.

CONCLUSIONS

- SORBENT DESULFURIZATION ACTIVITY APPEARS TO DUPLICATE THE ACTIVITY OF RUN 007 ( FIRST CYCLE) AFTER A SLIGHT DECLINE IN ACTIVITY IN RUN 009 (SECOND CYCLE).
- ZINC FERRITE APPEARS TO BE A GOOD REGENERABLE SORBENT FOR H2S AT 1000 F. THIS TEST CONCLUDES THE THIRD SULFIDATION IN THIS SERIES.

TEST SUMMARY SHEET

TEST NO.	:	012A
DATE STARTED	:	2/5/81
DATE ENDED	:	2/5/81
TOTAL HOURS	:	12.5
TYPE	:	REGENERATION

PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS  
FROM TEST 011A USING 50% AIR AND 50% STEAM.  
THIS REGENERATION IS CARRIED OUT TO REMOVE THE HIGH  
LEVEL OF H<sub>2</sub>S INADVERTENTLY ABSORBED IN RUN 011A.

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/800 G
SORBENT NO.	BATCH 81/1
SORBENT COMPOSITION:	50 MOLEX IRON OXIDE (FISHER CERTIFIED) 50 MOLEX ZINC OXIDE (SHERRIN WILLIAMS HSA)
SORBENT SIZE	: 1/4 INCH DIAMETER EXTRUSIONS
PRETREATMENT	: DRIED IN OVEN AT 200 F OVERNIGHT (BEFORE TEST)
SULFUR REMOVED	: 32.9 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR(XU/U):		
SURFACE AREA(M <sup>2</sup> /G):		
DENSITY(G/CM <sup>3</sup> ):		
PORE VOLUME(MM <sup>3</sup> /G):		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

OPERATING CONDITIONS

TEMPERATURE:	1000 F (538 C)
PRESSURE	: AMBIENT
SPACE VELOCITY:	600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H <sub>2</sub> S:	2000-3000 PPM
EXIT SO <sub>2</sub> :	4-10 %
EXIT S <sub>2</sub> :	
EXIT H <sub>2</sub> :	

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	2.23 CM <sup>3</sup> /MIN	50%
AIR (2.78 DM <sup>3</sup> /MIN) 5.88 SCFH		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		


REMARKS

1. TEMPERATURE WAVE UP TO 1730 F OBSERVED.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

CONCLUSIONS

1. THIS WAS THE SECOND REGENERATION OF THE SAME BATCH OF SORBENT. REGENERATION APPEARS NORMAL.
2. WIDE SCATTER IN SO<sub>2</sub> DATA DURING REGENERATION POSSIBLY DUE TO H<sub>2</sub>S INTERFERENCE IN DETECTOR TUBE READING.

ZINC FERRITE SULFIDATION  
TEST 007




19-MAY-81 10:13:28

-236-

P:

# ZINC FERRITE SULFIDATION

TEST 007




19-MAY-81 10:11:13

P1

# ZINC FERRITE SULFIDATION

TEST 007



19-MAY-81 10:09:30


-238-

19-MAY-81 10:02:17

-239-


# ZINC FERRITE REGENERATION

TEST 008



# ZINC FERRITE SULFIDATION


TEST 009 (SECOND CYCLE ON SAME SORBENT)



19-MAY-81 08:57:37

-241-


P1  
ZINC FERRITE SULFIDATION  
TEST 009 (SECOND CYCLE ON SAME SORBENT)



P1

# ZINC FERRITE REGENERATION

TEST 010 (SECOND CYCLE ON SAME SORBENT)




19-MAY-81 08:55:24

-242-

F:


# ZINC FERRITE REGENERATION

AVERAGE OF TESTS 009 AND 010



ZINC FERRITE SULFIDATION

TEST 0118 (THIRD CYCLE ON SAME SORBENT)




19-MAY-81 09:53:47

-244-

P1

# ZINC FERRITE SULFIDATION

TEST 0118 (THIRD CYCLE ON SAME SORBENT)




-245-

19-MAY-81 09:52:13

P:


# ZINC FERRITE SULFIDATION

TEST 011B (THIRD CYCLE ON SAME SORBENT)



# ZINC FERRITE SULFIDATION

TESTS 007,009,011B (THREE CYCLES ON SAME SORBENT)



## TEST SUMMARY SHEET

TEST NO. : 013  
 DATE STARTED : 3/05/81  
 DATE ENDED : 3/06/81  
 TOTAL HOURS : 13  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: ZINC OXIDE/1000 G  
 SORBENT NO. : MARSHAU ZN8401-E3/16 (SAMPLE)  
 SORBENT COMPOSITION: 100 % ZNO  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED AT 320 F FOR 2.5 HOURS  
 SULFUR LOADINGS : 18.7 % (GM SULFUR/GM FRESH SORBENT)  
                   TO 9 PPM BEFORE BREAKTHROUGH

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 1000 HOURLY

FLOW RATE	MOLE
H <sub>2</sub> S (0.24 DM <sup>3</sup> /MIN) 0.516 SCFM	2.7%
H <sub>2</sub> O	0.500 CM <sup>3</sup> /MIN 6.9%
AIR	
CO <sub>2</sub>	
CO	
H <sub>2</sub> (1.32 DM <sup>3</sup> /MIN) 2.79 SCFM	14.6%
CH <sub>4</sub>	
N <sub>2</sub> (6.84 DM <sup>3</sup> /MIN) 14.50 SCFM	75.8%

## PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
 REGENERATION CHARACTERISTICS.

## ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):	3.2	
DENSITY (G/CM <sup>3</sup> ):		6.39
PORE VOLUME (MM <sup>3</sup> /G):		6.5
MINERAL ANALYSIS: SEE APPENDIX		
ELEMENTAL ANALYSIS: SEE APPENDIX		

## DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S: 5-9 PPM PLATEAU FOR 9 HOURS

BREAKTHROUGH AT 10 HOURS WITH 960 PPM

EXIT SO<sub>2</sub>:EXIT S<sub>2</sub>:EXIT H<sub>2</sub>:

## REMARKS

1. H<sub>2</sub>S LEVEL REDUCED TO APPROXIMATELY THE LEVEL  
 OBTAINED WITH ZINC FERRITE.

2.

## CONCLUSIONS

- ZNO IS A GOOD SORBENT AT HIGH TEMPERATURES WITH 6.9% WATER.
- THIS TEST DATA VERIFIES THERMODYNAMIC CALCULATIONS INDICATING APPROXIMATELY 1 PPM H<sub>2</sub>S ACHIEVABLE WITH 6.9 % WATER AT 1000 F.

TEST SUMMARY SHEET

TEST NO.	:	014
DATE STARTED	:	3/06/81
DATE ENDED	:	3/06/81
TOTAL HOURS	:	12
TYPE	:	REGENERATION

PURPOSE

REGENERATION OF ZINC OXIDE EXTRUSIONS  
TO DETERMINE REGENERATION CHARACTERISTICS.

SORBENT TYPE/WEIGHT: ZINC OXIDE/1000 G  
SORBENT NO.: MARSHAU ZH0401-E3/16 (SAMPLE)  
SORBENT COMPOSITION: 100 % ZNO

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
PRETREATMENT : DRIED AT 320 F FOR 2.5 HOURS (BEFORE T013)  
SULFUR REMOVED :

ANALYSIS:

TOTAL SULFUR(XU/U);  
SURFACE AREA(M<sup>2</sup>/G);  
DENSITY(G/CM<sup>3</sup>);  
PORE VOLUME(MM<sup>3</sup>/G);  
MINERAL ANALYSIS;  
ELEMENTAL ANALYSIS;

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S: UNABLE TO READ DUE TO SO<sub>2</sub> INTERFERENCE

EXIT SO<sub>2</sub>: 0-14%

EXIT S<sub>2</sub>: 0.1687 G

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	2.17 CM <sup>3</sup> /MIN	50%
AIR (2.71 DM <sup>3</sup> /MIN) 5.735 SCFH		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		

REMARKS

1. TEMPERATURE WAVE REACHED 1700 F.

2. SO<sub>2</sub> LEVELS ARE HIGHER COMPARED TO ZINC FERRITE  
MUCH LESS ELEMENTAL SULFUR PRODUCED.

CONCLUSIONS

1. IT APPEARS THAT ZNO REGENERATES IN THE SAME WAY THAT  
IRON OXIDE AND ZINC FERRITE DO. A SIMILAR  
TEMPERATURE WAVE IS OBSERVED, AS EXPECTED.

2. IN SPITE OF A 50% STEAM LEVEL IN THE FEED, THE  
REGENERATION REACTION IS SUFFICIENTLY EXOTHERMIC TO  
PRODUCE A 700 F RISE IN PROCESS GAS TEMPERATURE.

## TEST SUMMARY SHEET

TEST NO. : 015  
 DATE STARTED : 3/10/81  
 DATE ENDED : 3/11/81  
 TOTAL HOURS : 14  
 TYPE : SULFIDATION

PURPOSE  
 SECOND SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE SORPTION EFFICIENCY.

SORBENT TYPE/WEIGHT: ZINC OXIDE/1000 G  
 SORBENT NO. : MARSHAU ZNO401-E3/16 (SAMPLE)  
 SORBENT COMPOSITION: 100 % ZNO

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED AT 320 F FOR 2.5 HOURS  
 SULFUR LOADINGS : 18.8 (GM SULFUR/GM FRESH SORBENT)  
                   TO 14 PPM BEFORE BREAKTHROUGH

ANALYSIS:  
 TOTAL SULFUR (%W/W): BEFORE      AFTER  
 SURFACE AREA (B2/G): 1.1  
 DENSITY (G/CM3): 3.82  
 PORE VOLUME (MM3/G): 2.0  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

DATA: (DETECTOR TUBE)

EXIT H2S: 2-7 PPM PLATEAU FOR 9 HOURS  
 BREAKTHROUGH AT 10 HOURS WITH 14 PPM

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: 1000 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE	MOLE
H2S (0.24 DM3/MIN) 0.516 SCFH	2.7%
H2O	0.500 CM3/MIN 6.9%
AIR	
CO2	
CO	
H2 (1.32 DM3/MIN) 2.79 SCFH	14.6%
CH4	
N2 (6.84 DM3/MIN) 14.50 SCFH	75.8%

## REMARKS


1. THIS IS THE SECOND SULFIDATION OF THIS SORBENT.
2. EXIT H2S WAS SLIGHTLY LOWER THAN THE FIRST SULFIDATION.

## CONCLUSIONS

1. ZNO IS REGENERABLE AT THESE CONDITIONS.
2. NO LOSS IN ACTIVITY CAN BE DETECTED. A SLIGHT IMPROVEMENT IN SULFUR ABSORPTION IS OBSERVED.

ZINC OXIDE SULFIDATION

TEST 013 (HARSHAW ZN-0401)



19-MAY-81 09:47:13

TEST SUMMARY SHEET

TEST NO.	916
DATE STARTED	3/20/81
DATE ENDED	3/20/81
TOTAL HOURS	3.5
TYPE	SULFIDATION

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/643 G
SORBENT NO.	BATCH 82/1
SORBENT COMPOSITION:	50 MOLE% IRON OXIDE (FISHER CERTIFIED) 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)
SORBENT SIZE	3/16 INCH DIAMETER EXTRUSIONS
PRETREATMENT	DRIED IN OVEN AT 200 F OVERNIGHT
SINTERING	3 HOURS AT 1500 F
SULFUR LOADING	14.1 % (GM SULFUR/GM FRESH SORBENT) TO 10 PPM BEFORE BREAKTHROUGH

OPERATING CONDITIONS

TEMPERATURE:	1000 F (538 C)
PRESSURE	AMBIENT
SPACE VELOCITY:	2000 HOURLY

	FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN)	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN	27.66%
AIR		
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN)	3.6 SCFH	9.68%
CO (2.03 DM <sup>3</sup> /MIN)	4.3 SCFH	11.91%
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN)	6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN)	1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN)	10.34 SCFH	33.09%
TOTAL DRY GAS FLOW RATE		= 26.60 SCFH
TOTAL WET GAS FLOW RATE		= 37.70 SCFH

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
REGENERATION CHARACTERISTICS, USING LURGI AIR/H<sub>2</sub>O  
GAS COMPOSITIONS AND INCREASED SPACE VELOCITIES.

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):	5.1	
DENSITY (G/CM <sup>3</sup> ):	5.58	
PORE VOLUME (MM <sup>3</sup> /G):	10.9	
MINERAL ANALYSIS:	SEE APPENDIX	
ELEMENTAL ANALYSIS:		

DATA: (DETECTOR TUBE)

EXIT H <sub>2</sub> S:	9-13 PPM PLATEAU FOR 2.25 HRS BREAKTHROUGH AT 3.25 HRS WITH 925 PPM
EXIT SO <sub>2</sub> :	
EXIT S <sub>2</sub> :	
EXIT H <sub>2</sub> :	

REMARKS

1. LURGI GAS COMPOSITION DOES NOT APPEAR TO PRODUCE A DIFFERENT RESULT IN THIS SULFIDATION.
- 2.

CONCLUSIONS

1. ACCELERATED TEST CONDITION OF SU=2000 REDUCED TIME TO BREAKTHROUGH ABOUT AS EXPECTED. TESTS CAN NOW BE COMPLETED IN ONE SHIFT.
2. H<sub>2</sub>S LEVEL AT EXIT ONLY SLIGHTLY HIGHER THAN THAT OBTAINED AT SU = 1000.

TEST SUMMARY SHEET

TEST NO.	817
DATE STARTED	3/24/81
DATE ENDED	3/24/81
TOTAL HOURS	5
TYPE	REGENERATION

PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS  
FROM TEST 816 USING 50% AIR AND 50% STEAM,  
AND ACCELERATED SPACE VELOCITY OF 1200 HOURLY.

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/643 G
SORBENT NO.:	BATCH 82/1
SORBENT COMPOSITION:	50 MOLES IRON OXIDE (FISHER CERTIFIED) 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)
SORBENT SIZE:	3/16 INCH DIAMETER EXTRUSIONS
PRETREATMENT:	
SULFUR REMOVED:	

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):	1.4	
DENSITY (G/CR3):	4.8	
PORE VOLUME (MM <sup>3</sup> /G):	3.7	
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:	SEE APPENDIX	

OPERATING CONDITIONS

TEMPERATURE:	1000 F (538C)
PRESSURE:	AMBIENT
SPACE VELOCITY:	1200 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:	
EXIT SO2:	8-13 %
EXIT S2:	7.7081 G
EXIT H2:	

	FLOW RATE	MOLE
H2S		
H2O	4.19 CM <sup>3</sup> /MIN	50%
AIR (5.23 L13/MIN) 11.07 SCFH		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		

REMARKS

1. TEMPERATURE WAVE UP TO 1910 F OBSERVED AT INLET.  
1400-1560 THROUGHOUT THE REACTOR.
2. AFTER REMOVING THE EXTRUSIONS IT WAS OBSERVED THAT SOME AGGLOMERATION (SINTERING) HAD OCCURRED. A COATING OF HEMATITE AND ZNO WAS DETECTED ON SOME OF THE EXTRUSIONS.

CONCLUSIONS

1. SV-1200 MAY BE TOO HIGH A SPACE VELOCITY FOR REGENERATION. IT IS SUSPECTED THAT IT CAUSED SINTERING IN THIS RUN, REDUCING SORPTION ACTIVITY.

TEST SUMMARY SHEET

TEST NO.	:	018
DATE STARTED	:	3/27/81
DATE ENDED	:	3/28/81
TOTAL HOURS	:	6
TYPE	:	SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS AT 600 F  
TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
REGENERATION CHARACTERISTICS, USING LURGI AIR/H<sub>2</sub>O  
GAS COMPOSITIONS AND INCREASED SPACE VELOCITIES.

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/643 G
SORBENT NO.:	BATCH 82/1
SORBENT COMPOSITION:	50 MOLE% IRON OXIDE (FISHER CERTIFIED) 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)
SORBENT SIZE	: 3/16 INCH DIAMETER EXTRUSIONS
PRETREATMENT	: DRIED IN OVEN AT 200 F OVERNIGHT
SULFUR LOADING	: X (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

TOTAL SULFUR(XU/U):	BEFORE	AFTER
SURFACE AREA(M <sup>2</sup> /G):		
DENSITY(G/CM <sup>3</sup> ):		
PORE VOLUME(M <sup>3</sup> /G):		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

OPERATING CONDITIONS

TEMPERATURE:	600 F (316 C)
PRESSURE:	AMBIENT
SPACE VELOCITY:	2000 HOURLY

DATA: ( DETECTOR TUBE )

EXIT H <sub>2</sub> S:	6000 PPM IMMEDIATELY
EXIT SO <sub>2</sub> :	
EXIT S <sub>2</sub> :	
EXIT H <sub>2</sub> :	

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.74
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68%
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91%
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.61 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09%

REMARKS

1. AFTER IMMEDIATE BREAKTHROUGH WAS OBSERVED, TEMP. WAS INCREASED TO 1000. AT THIS TEMP. 100 PPM WAS DETECTED. REGENERATION WAS CARRIED OUT & RUN MADE AT 1000 F. BREAKTHROUGH OCCURRED AFTER 50 MIN.

CONCLUSIONS

1. SULFIDATION ACTIVITY APPEARS TO BE VERY POOR AT 600 F, HOWEVER, IT IS SUSPECTED THAT THE EXTRUSIONS HAVE BEEN SINTERED IN THE LAST REGENERATION AT SU=1200.
2. THE BREAKTHROUGH OBTAINED AT 1000 F AFTER ONLY 50 MIN. INDICATES THAT SORBENT ACTIVITY HAS BEEN REDUCED.

TEST SUMMARY SHEET

TEST NO. : 619  
 DATE STARTED : 4/7/81  
 DATE ENDED : 4/8/81  
 TOTAL HOURS : 3.75  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE SORPTION EFFICIENCY AND SUBSEQUENT  
 REGENERATION CHARACTERISTICS, USING LURGI AIR/H<sub>2</sub>O  
 GAS COMPOSITIONS AND INCREASED SPACE VELOCITIES.

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 643 G  
 SORBENT NO. : BATCH #2/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED IN OVEN AT 200 F OVERNIGHT  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:  
 BEFORE      AFTER  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G): 4.4  
 DENSITY (G./CM<sup>3</sup>): 5.72  
 PORE VOLUME (MM<sup>3</sup>/G): 8.5  
 MINERAL ANALYSIS: SEE APPENDIX  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 3-10 PPM PLATEAU FOR 2.5 HRS  
 BREAKTHROUGH WITH 60 PPM AFTER 2.5 HOURS  
 EXIT SO<sub>2</sub>:  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68%
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91%
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09%

REMARKS

1. PREHEATER PLUGGED AFTER 1 HOUR INTO THE TEST.  
 TEST WENT ON HOT HOLD OVER NIGHT, AND PREHEATER  
 COIL REPLACED.
2. THIS RUN WAS STARTED WITH A FRESH BATCH OF SORBENT

CONCLUSIONS

1. NORMAL ACCELERATED SULFIDATION TEST IN TERMS  
 OF OUTPUT DATA.

2.

## TEST SUMMARY SHEET

TEST NO. : 020  
 DATE STARTED : 4/10/81  
 DATE ENDED : 4/10/81  
 TOTAL HOURS : 6.75  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE EXTRUSIONS FROM TEST 019  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH 82/2  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
                       50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR: BEFORE      AFTER  
 SURFACE AREA:  
 DENSITY:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)  
 EXIT H2S:  
 EXIT SO2: 8-12 %  
 EXIT S2: 4.1643 G  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN) 5.88 SCFH		50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. TEMPERATURE WAVE UP TO 1000 F OBSERVED AT INLET AND 1000 F THROUGHOUT THE REACTOR.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. NORMAL REGENERATION FOR BASELINE VERIFICATION.

2.

TEST SUMMARY SHEET

TEST NO. : 021  
 DATE STARTED : 4/13/81  
 DATE ENDED : 4/13/81  
 TOTAL HOURS : 3.75  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO REESTABLISH BASELINE AFTER REGENERATION.  
 THIS IS THE SECOND SULFIDATION OF THIS BATCH.

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 643 G  
 SORBENT NO. : BATCH 82/2  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
 50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 12.51 % (GM SULFUR/GM FRESH SORBENT)  
 TO 3 PPM BEFORE BREAKTHROUGH

ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

DATA: ( DETECTOR TUBE)

EXIT H2S: 3-5 PPM PLATEAU FOR 2 HRS  
 BREAKTHROUGH WITH 1100 PPM AFTER 3 HOURS  
 EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLE
H2S (0.47 DM3/MIN)	0.9963 SCFH	2.7%
H2O	3.872 CM3/MIN	27.66%
AIR		
CO2 (1.70 DM3/MIN)	3.6 SCFH	9.68%
CO (2.03 DM3/MIN)	4.3 SCFH	11.91%
H2 (2.87 DM3/MIN)	6.3 SCFH	17.12%
CH4 (0.51 DM3/MIN)	1.07 SCFH	2.91%
N2 (4.88 DM3/MIN)	10.34 SCFH	33.09%

REMARKS

1. SECOND SULFIDATION OF THIS BATCH OF SORBENT
2. LURGI GAS COMPOSITION USED.

CONCLUSIONS

1. NORMAL ACCELERATED SULFIDATION TEST IN TERMS OF OUTPUT DATA.

TEST SUMMARY SHEET

TEST NO. : 022  
 DATE STARTED : 4/14/81  
 DATE ENDED : 4/14/81  
 TOTAL HOURS : 6.75  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS FROM TEST 021  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 643 G  
 SORBENT NO. : BATCH 82/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 3.5-12.8 %  
 EXIT S2I:  
 EXIT H2I:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN)	5.88 SCFM	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

1. ACTUAL FLOWS WERE 12.17 CM3/MIN WATER, 5.735 SCFH AIR.

2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

CONCLUSIONS

1. NORMAL REGENERATION.

## TEST SUMMARY SHEET

TEST NO. : 023  
 DATE STARTED : 4/15/81  
 DATE ENDED : 4/15/81  
 TOTAL HOURS : 6.75  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 800 F (427 C).

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH #2/2  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 1.56 % (GM SULFUR/GM FRESH SORBENT)  
 TO 5 PPM BREAKTHROUGH

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 800 F (427 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

## DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: INITIALLY 5 PPM  
 900 PPM BREAKTHROUGH AFTER 30 MIN.  
 EXIT SO<sub>2</sub>:  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 DM <sup>3</sup> /MIN 27.66%
<b>AIR</b>	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.63%
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91%
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
<b>CH<sub>4</sub></b>	
N <sub>2</sub> (5.76 DM <sup>3</sup> /MIN) 12.20 SCFH	36.00%

## REMARKS

1. AFTER BREAKTHROUGH AT 800 F TEMP. INCREASED TO 900 F.
2. AT 900F BREAKTHROUGH HAD OCCURRED ALSO. (900 PPM READING). REGENERATION FOLLOWED.
3. NO METHANE , N<sub>2</sub> INCREASED TO COMPENSATE.

## CONCLUSIONS

1. SORPTION ACTIVITY OF ZINC FERRITE AT 800 F IS NOT SUFFICIENTLY HIGH FOR FUEL CELL APPLICATION.
2. APPARENTLY THE KINETICS ARE TOO SLOW AT THIS TEMP TO LOWER THE H<sub>2</sub>S TO BELOW 10 PPM.
3. THIRD SULFIDATION OF THIS BATCH OF SORBENT.

## TEST SUMMARY SHEET

TEST NO. : 024  
 DATE STARTED : 4/16/81  
 DATE ENDED : 4/16/81  
 TOTAL HOURS : 3.25  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1200 F (649 C).

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH 82/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 15.6 % (GM SULFUR/GM FRESH SORBENT)  
 TO 15 PPM BREAKTHROUGH

## ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

## DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 9-13 PPM PLATEAU  
 EXIT SO<sub>2</sub>: BREAKTHROUGH WITH 15 PPM AT 2.5 HRS  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68 %
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91 %
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09%

## REMARKS

1.

## CONCLUSIONS

1. H<sub>2</sub>S LEVEL AT 1200 F ABOUT TWICE THE LEVEL OBTAINED  
 AT 1000 F.

## TEST SUMMARY SHEET

TEST NO. : 025  
 DATE STARTED : 4/17/81  
 DATE ENDED : 4/17/81  
 TOTAL HOURS : 5.25  
 TYPE : REGENERATION

## PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS FROM TEST 024  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH #2/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 3.5-12.8 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DR3/MIN)	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. ACTUAL FLOWS WERE 12.17 CM3/MIN WATER, 5.735 SCFH AIR.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. NORMAL REGENERATION.

TEST SUMMARY SHEET

TEST NO. : 026  
 DATE STARTED : 4/20/81  
 DATE ENDED : 4/20/81  
 TOTAL HOURS : 2.5  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1400 F (750 C).

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 640 G  
 SORBENT NO. : BATCH #2/2  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
 50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 9.4 % (GM SULFUR/GM FRESH SORBENT)  
 TO 2 PPM BREAKTHROUGH

ANALYSIS:  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1400 F (750 C)

DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 1-3 PPM PLATEAU

PRESSURE : AMBIENT

BREAKTHROUGH WITH 26 PPM AT 2 HRS

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN)	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN	27.66%
AIR		
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN)	3.6 SCFH	9.68 %
CO (2.03 DM <sup>3</sup> /MIN)	4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN)	6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN)	1.07 SCFH	2.91 %
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN)	10.34 SCFH	33.09 %

REMARKS

1. FOURTH SULFIDATION OF THIS SORBENT.

CONCLUSIONS

1. EXIT H<sub>2</sub>S IS LOWER AT 1400 F THAN AT 1200F, INDICATING BETTER KINETICS AND DIFFUSION AT THIS TEMPERATURE. THIS LEVEL OF ACTIVITY MAY NOT BE REPEATABLE OVER MANY CYCLES DUE TO THE EFFECT OF SINTERING.

2.

TEST SUMMARY SHEET

TEST NO. : 027  
 DATE STARTED : 4/21/81  
 DATE ENDED : 4/21/81  
 TOTAL HOURS : 6.5  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS FROM TEST 026  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH #2/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
                       50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : DRIED IN OVEN AT 200 F OVERNIGHT  
 SULFUR REMOVED :

ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S:  
 EXIT SO<sub>2</sub>: 3.5-12.8 %  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S		
H <sub>2</sub> O	2.23 CM <sup>3</sup> /MIN	50%
AIR (2.78 DM <sup>3</sup> /MIN)5.88 SCFH		50%
CO <sub>2</sub>		
CO		
H <sub>2</sub>		
CH <sub>4</sub>		
N <sub>2</sub>		

REMARKS

1. FOURTH REGENERATION OF THIS SORBENT.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

CONCLUSIONS

- 1.

## TEST SUMMARY SHEET

TEST NO. : 028  
 DATE STARTED : 4/22/81  
 DATE ENDED : 4/23/81  
 TOTAL HOURS : 1.5  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1500 F (816 C).

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH 82/2  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 6.26 % (GM SULFUR/GM FRESH SORBENT)  
 TO 4 PPM BREAKTHROUGH

## ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (XU/U):		
SURFACE AREA (M <sup>2</sup> /G):	0.5	(SEE NOTE)
DENSITY (G/CM <sup>3</sup> ):	4.99	
PORE VOLUME (MM <sup>3</sup> /G):	0.7	
MINERAL ANALYSIS: SEE APPENDIX		
ELEMENTAL ANALYSIS:		

## OPERATING CONDITIONS

TEMPERATURE: 1500 F (816 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.78 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68 %
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.08 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09 %

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 4 PPM PLATEAU FOR 0.5 HR  
 EXIT SO<sub>2</sub>: BREAKTHROUGH AT 1 HR WITH 16,000 PPM  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

## REMARKS

1. FIFTH SULFIDATION OF THIS BATCH.
2. SORBENT OVERHEATED AT REACTOR EXIT TO 1620 F DURING OVERNIGHT HOT HOLD.
3. PELLETS FUSED TOGETHER AT MID BED BETWEEN T/C 5 AND T/C 4 , DUE TO OVERHEATING.

## CONCLUSIONS

1. SINTERING CAUSED REACTOR TO PLUG.
2. SULFIDATION AT 1500 F CAUSES MORE RAPID BREAKTHROUGH PROBABLY DUE TO SINTERING CAUSING LOSS OF ACTIVE SURFACE AREA.
3. INITIAL H<sub>2</sub>S LEVELS AT 1500 F ARE STILL FAIRLY LOW AT 4 PPM.

## TEST SUMMARY SHEET

TEST NO. : 029  
 DATE STARTED : 4/24/81  
 DATE ENDED : 4/24/81  
 TOTAL HOURS : 0.6  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1500 F (816 C).

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH #2/3  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 1.56 % (GM SULFUR/GM FRESH SORBENT)  
 TO 2 PPM BEFORE BREAKTHROUGH

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 POROUS VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1500 F (816 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

DATA: 1 DETECTOR TUBE

EXIT H<sub>2</sub>S: 2 PPM INITIALLY

700 PPM AFTER 30 MINUTES

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68 %
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.00%

## REMARKS

1. THIS TEST IS TO REPEAT TEST 028 IN WHICH OVERHEATING WAS EXPERIENCED WITH EXCESSIVE SINTERING.
2. BREAKTHROUGH IN THIS TEST WAS FASTER THAN IN TEST 028 ALSO AT 1500 F.
3. NEW BATCH OF SORBENT.

## CONCLUSIONS

1. RAPID BREAKTHROUGH INDICATES POSSIBILITY OF SINTERING OF SORBENT AT THIS TEMPERATURE.
2. 1500 F APPEARS TO BE THE UPPER LIMIT OF OPERATION FOR ZINC FERRITE.

## TEST SUMMARY SHEET

TEST NO. : 030  
 DATE STARTED : 4/24/81  
 DATE ENDED : 4/24/81  
 TOTAL HOURS : 1.25  
 TYPE : REGENERATION

## PURPOSE

REGENERATION OF ZINC FERRITE EXTRUSIONS FROM TEST 029  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 643 G  
 SORBENT NO. : BATCH 82/3  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS:  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 4.0-5.0 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN)	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. THIS TEST IS TO REGENERATE THE LAST SULFIDATION AT 1500 F FOR ANOTHER BASELINE TEST AT 1000 F TO DETERMINE IF A PERMANENT LOSS OF ACTIVITY OCCURRED.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. THIS REGENERATION WAS SHORTER DUE TO THE SHORT SULFIDATION DURING TEST 029.

## TEST SUMMARY SHEET

TEST NO. : 031  
 DATE STARTED : 4/24/81  
 DATE ENDED : 4/24/81  
 TOTAL HOURS : 0.5  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1000 F (538 C)

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 G  
 SORBENT NO. : BATCH #2/3  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE (FISHER CERTIFIED)  
 50 MOLEX ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

## ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (%W/W):	2.2	
SURFACE AREA (M <sub>2</sub> /G):	5.23	
DENSITY (G/CM <sup>3</sup> ):	5.2	
PORE VOLUME (MM <sup>3</sup> /G):		
MINERAL ANALYSIS:	SEE APPENDIX	
ELEMENTAL ANALYSIS:		

## OPERATING CONDITIONS

-267-  
 TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H <sub>2</sub> S:	600 PPM IMMEDIATELY
	3600 PPM AFTER 30 MINUTES
EXIT SO <sub>2</sub> :	
EXIT S <sub>2</sub> :	
EXIT H <sub>2</sub> :	

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%

## AIR

CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68 %
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09 %

## REMARKS

1. THIS TEST IS TO DETERMINE IF PERMANENT LOSS OF ACTIVITY OCCURRED AT 1500 F DURING TEST #29.
- 2.


## CONCLUSIONS

1. PERMANENT LOSS OF ACTIVITY HAS OCCURRED AS SEEN BY IMMEDIATE BREAKTHROUGH OF 600 PPM AT THE FIRST READING.
2. 1500 F APPEARS TO BE PAST THE UPPER LIMIT OF OPERATION FOR ZINC FERRITE.

ZINC FERRITE SULFIDATION  
TEST 016

19-MAY-81 09:43:55


-268-



P:

# ZINC FERRITE REGENERATION


TEST 017



P:

# ZINC FERRITE SULFIDATION

TEST 023



19-MAY-84, 09:42:25


-270-

19-MAY-81 09:40:46

P:

# ZINC FERRITE SULFIDATION


TEST 024



P:

# ZINC FERRITE SULFIDATION

TEST 024




19-MAY-81 09:39:17

P1

# ZINC FERRITE SULFIDATION

TEST 026




19-MAY-81 09:37:45

19-MAY-81 09:36:19

P1

# ZINC FERRITE SULFIDATION

TEST 028



TEST SUMMARY SHEET

TEST NO. : 032  
 DATE STARTED : 4/27/81  
 DATE ENDED : 4/27/81  
 TOTAL HOURS : 3  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 800 F (427 C).

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZHO 0401 E3/16 LOT95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 6.84 % (GM SULFUR/GM FRESH SORBENT)  
 TO 7 PPM BREAKTHROUGH

ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 800 F (427 C)

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: 3 PPM PLATEAU FOR 1 HR

SPACE VELOCITY: 2000 HOURLY

EXIT SO<sub>2</sub>: BREAKTHROUGH WITH 7 PPM AT 1.5 HRS

EXIT S<sub>2</sub>I:

EXIT H<sub>2</sub>I:

FLOW RATE                  MOLE

H <sub>2</sub> S (0.47 DM <sub>3</sub> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sub>3</sub> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sub>3</sub> /MIN) 3.6 SCFH	9.63 %
CO (2.03 DM <sub>3</sub> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sub>3</sub> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sub>3</sub> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sub>3</sub> /MIN) 10.34 SCFH	33.89 %

REMARKS

1. THIS IS THE FIRST SULFIDATION OF THIS SORBENT.

2.

CONCLUSIONS

1.

2.

## TEST SUMMARY SHEET

TEST NO. : 033  
 DATE STARTED : 4/30/81  
 DATE ENDED : 4/30/81  
 TOTAL HOURS : 6  
 TYPE : REGENERATION

## PURPOSE

REGENERATION OF ZINC OXIDE EXTRUSIONS FROM TEST 032  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO 0401 E3/16 LOT 95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED : % (GM SULFUR/GM FRESH SORBENT)

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1800 F (938 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 3.5-12.8 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN) 5.88 SCFM		50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. TEMPERATURE WAVE REACHED 1540 F (833 C).
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. THIS IS THE FIRST REGENERATION ON THIS BATCH OF SORBENT.

## TEST SUMMARY SHEET

TEST NO. : 034  
 DATE STARTED : 5/01/81  
 DATE ENDED : 5/01/81  
 TOTAL HOURS : 4  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO #401 E3/16 LOT#5 DRUM A/1  
 SORBENT COMPOSITION: 100 X ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 8.0 % (G M SULFUR/GM FRESH SORBENT)  
 TO 3 PPM BREAKTHROUGH

## PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1000 F (538 C).

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 0-3 PPM PLATEAU FOR 2 HRS

                  BREAKTHROUGH AT 2.5 HRS WITH 23 PPM

EXIT S<sub>2</sub>:  
 EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sub>3</sub> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sub>3</sub> /MIN 27.66%
AIR	
CO <sub>2</sub> (1.70 DM <sub>3</sub> /MIN) 3.6 SCFH	9.68 %
CO (2.03 DM <sub>3</sub> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.07 DM <sub>3</sub> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sub>3</sub> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sub>3</sub> /MIN) 10.34 SCFH	33.89 %

## REMARKS

1. THIS IS THE SECOND SULFIDATION OF THIS BATCH OF SORBENT.
- 2.

## CONCLUSIONS

1. H<sub>2</sub>S CAPACITY AT 1000 F IS BETTER THAN AT 800 F.

2.

## TEST SUMMARY SHEET

TEST NO. : 035  
 DATE STARTED : 5/04/81  
 DATE ENDED : 5/04/81  
 TOTAL HOURS : 7.5  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC OXIDE EXTRUSIONS FROM TEST 034

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO 0401-E3/16 LOT 95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED : X (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 3.7-14.8 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN)	5.88 SCFM	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. THIS IS THE SECOND REGENERATION OF THIS BATCH OF SORBENT.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. NORMAL REGENERATION.

## TEST SUMMARY SHEET

TEST NO. : 036  
 DATE STARTED : 5/05/81  
 DATE ENDED : 5/05/81  
 TOTAL HOURS : 3  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1200 F (649 C).

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO 0401 E3/16 LOT95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 8.0 % (GM SULFUR/GM FRESH SORBENT)  
                   TO 11 PPM BREAKTHROUGH

ANALYSIS:  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 POKE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 6-15 PPM PLATEAU FOR 2 HRS

EXIT SO<sub>2</sub>: BREAKTHROUGH WITH 184 PPM AT 2.5 HRS

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
<b>AIR</b>	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68%
CO (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.89%

## REMARKS

1. THIS IS THE THIRD SULFIDATION OF THIS BATCH OF SORBENT.
- 2.

## CONCLUSIONS

1. H<sub>2</sub>S CAPACITY AT 1200 F IS LOWER THAN AT 1000 F.

## TEST SUMMARY SHEET

TEST NO. : 037  
 DATE STARTED : 5/07/81  
 DATE ENDED : 5/07/81  
 TOTAL HOURS : 6.75  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC OXIDE EXTRUSIONS FROM TEST 036.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO 040L-E3/16 LOT 95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

ANALYSIS:  
 BEFORE      AFTER  
 TOTAL SULFUR  
 SURFACE AREA  
 DENSITY  
 PORE VOLUME  
 MINERAL ANALYSIS  
 ELEMENTAL ANALYSIS

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED : X (GM SULFUR/GM FRESH SORBENT)

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S: 0  
 EXIT SO2: 3.7-14.8 %  
 EXIT S2I: 0  
 EXIT H2I: 0

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DM3/MIN) 5.88 SCFH		50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. THIS IS THE THIRD REGENERATION OF THIS BATCH OF SORBENT.
2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

## CONCLUSIONS

1. NORMAL REGENERATION.

## TEST SUMMARY SHEET

TEST NO. : 638  
 DATE STARTED : 5/08/81  
 DATE ENDED : 5/08/81  
 TOTAL HOURS : 1.5  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1400 F (760 C).

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : HARSIAU ZNO 6401 E3/16 LOT95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 2.0 % (GM SULFUR/GM FRESH SORBENT)  
 TO 2 PPM BREAKTHROUGH

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1400 F (760 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 2-3 PPM PLATEAU FOR 30 MINUTES  
 EXIT SO<sub>2</sub>: BREAKTHROUGH WITH 27 PPM AT 1 HR  
 EXIT S<sub>2</sub>I:  
 EXIT H<sub>2</sub>I:

FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN) 0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN 27.66%
<b>AIR</b>	
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN) 3.6 SCFH	9.68 %
CH <sub>4</sub> (2.03 DM <sup>3</sup> /MIN) 4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN) 6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN) 1.07 SCFH	2.91%
N <sub>2</sub> (4.88 DM <sup>3</sup> /MIN) 10.34 SCFH	33.09 %

## REMARKS

1. THIS IS THE FOURTH SULFIDATION OF THIS BATCH OF SORBENT.
- 2.

## CONCLUSIONS

1. H<sub>2</sub>S CAPACITY AT 1400 F IS LOWER THAN AT 1200 F.

2.

## TEST SUMMARY SHEET

TEST NO. : 039  
 DATE STARTED : 5/15/81  
 DATE ENDED : 5/15/81  
 TOTAL HOURS : 19  
 TYPE: REGENERATION

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : HARSHAU ZNO 0401-E3/16 LOT 95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED : % (GM SULFUR/GM FRESH SORBENT)

## PURPOSE

REGENERATION OF ZINC OXIDE EXTRUSIONS FROM TEST 038.

## ANALYSIS:

TOTAL SULFUR:	BEFORE	AFTER
SURFACE AREA:		
DENSITY:		
PORE VOLUME:		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

## OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2:  
 EXIT S2I:  
 EXIT H2:

	FLOW RATE	MOLE
H2S		
H2O	2.23 CM3/MIN	50%
AIR (2.78 DR3/MIN)	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. THIS IS THE FOURTH REGENERATION OF THIS BATCH OF SORBENT.
2. REGENERATION ABORTED.

## CONCLUSIONS

- 1.

## TEST SUMMARY SHEET

TEST NO. : 040  
 DATE STARTED : 5/14/81  
 DATE ENDED : 5/14/81  
 TOTAL HOURS :  
 TYPE : SULFIDATION

## PURPOSE

SULFIDATION OF ZINC OXIDE EXTRUSIONS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1500 F (816 C).

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 G  
 SORBENT NO. : MARSHAU ZNO 9401 E3/16 LOT95 DRUM A/2  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

SORBENT SIZE : 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 1.0 % (GM SULFUR/GM FRESH SORBENT)  
 TO 2 PPM BREAKTHROUGH

## ANALYSIS:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

## OPERATING CONDITIONS

TEMPERATURE: 1500 F (816 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

## DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 2 PPM INITIALLY

                  BREAKTHROUGH WITH 51 PPM AT 30 MINUTES

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE
H <sub>2</sub> S (0.47 DM <sup>3</sup> /MIN)	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872 CM <sup>3</sup> /MIN	27.66%
AIR		
CO <sub>2</sub> (1.70 DM <sup>3</sup> /MIN)	3.6 SCFH	9.68 %
CH <sub>4</sub> (2.03 DM <sup>3</sup> /MIN)	4.3 SCFH	11.91 %
H <sub>2</sub> (2.97 DM <sup>3</sup> /MIN)	6.3 SCFH	17.12%
CH <sub>4</sub> (0.51 DM <sup>3</sup> /MIN)	1.07 SCFH	2.91%
H <sub>2</sub> (4.88 DM <sup>3</sup> /MIN)	10.34 SCFH	33.09 %

## REMARKS

1. NEW BATCH OF SORBENT.
2. SORBENT.

## CONCLUSIONS

- 1.

- 2.

TEST SUMMARY SHEET

TEST NO.	:	041
DATE STARTED	:	5/20/81
DATE ENDED	:	5/20/81
TOTAL HOURS	:	HRS
TYPE	:	REGENERATION

PURPOSE  
REGENERATION OF ZINC OXIDE PELLETS FROM TEST 040

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 GM  
SORBENT NO.: HARSHAU ZNO 0401-E3/16  
SORBENT COMPOSITION: 100 % ZINC OXIDE

ANALYSIS:  
TOTAL SULFUR:  
SURFACE AREA:  
DENSITY:  
POROSITY:  
X-RAY DIFFRACTION:

BEFORE      AFTER

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
PRETREATMENT:  
SULFUR LOADING : X (GM SULFUR/GM FRESH SORBENT)  
AT THE START OF REGENERATION.

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
PRESSURE : AMBIENT  
SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
EXIT SO2: APPROXIMATELY X  
EXIT S2:  
EXIT H2:

	FLOW RATE	MOLE%
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

1. THIS IS THE FIFTH REGENERATION ON THIS BATCH OF SORBENT.

2.

CONCLUSIONS

1.

TEST SUMMARY SHEET

TEST NO.	042R
DATE STARTED	8/19/81
DATE ENDED	8/19/81
TOTAL HOURS	3.5 HRS
TYPE	SULFIDATION

PURPOSE

SULFIDATION OF ZINC OXIDE PELLETS  
TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
OF 1000 F (537 C) USING DRY (NO WATER) LURGI GAS  
COMPOSITION.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 GM  
SORBENT NO.: HARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
SORBENT COMPOSITION: 100 X ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
PRETREATMENT:  
SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)  
MOLE S/MOLE ZNO

ANALYSIS:

TOTAL SULFUR:	BEFORE	AFTER
SURFACE AREA:	50 M <sup>2</sup> /G	
DENSITY :	G/CC	
POROSITY :	X-RAY DIFFRACTION:	

OPERATING CONDITIONS

TEMPERATURE: 1000 F (537 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 1412 HOURLY

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 1.0 PPM STEADY STATE

EXIT S<sub>02</sub>: BREAKTHRU WITH 3.3 PPM AT 2.5 HOURS

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	0.5963 SCFH	3.7%
H <sub>2</sub> O		
AIR		
CO <sub>2</sub>	3.6 SCFH	13.53 %
CO	4.3 SCFH	16.16 %
H <sub>2</sub>	6.3 SCFH	23.6%
CH <sub>4</sub>	1.07 SCFH	4.0%
N <sub>2</sub>	10.34 SCFH	38.87 %

REMARKS


1. THIS IS THE FIRST SULFIDATION ON THIS LOAD OF SORBENT.
2. COMPOSITION OF EACH OF THE FEED GASES WAS ADJUSTED TO REFLECT REMOVAL OF H<sub>2</sub>O FROM FEED GAS.

CONCLUSIONS

1. H<sub>2</sub>S LEVEL AT EXIT IS LOWER BY 50 % AS COMPARED TO TEST 034 WITH 27.66 % H<sub>2</sub>S.
2. MEASURED EXIT H<sub>2</sub>S OF 1 PPM IS CLOSE TO THE CALCULATED EQUILIBRIUM VALUE OF 0.35 PPM (USING EQZN0).

# ZINC OXIDE SULFIDATION


TESTS 034,042R (HARSHAW ZN-0401)



P:

# ZINC OXIDE SULFIDATION


TEST 034 (HARSHAW ZN-0401)



19-MAY-81 09:30:27

## ZINC OXIDE SULFIDATION


TESTS 034,021 (HARSHAW ZN-0401)



P:

# ZINC OXIDE SULFIDATION

TEST 036 (MARSHAW ZN-0401)



19-MAY-81 09:26:42

TEST SUMMARY SHEET

TEST NO. : 043  
 DATE STARTED : 9/21/81  
 DATE ENDED : 9/21/81  
 TOTAL HOURS : 3.75 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SCRBTION TEMPERATURE  
 OF 1000 F (537 C) USING DRY (NO WATER) LURGI GAS  
 COMPOSITION.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH # 3  
 SORBENT COMPOSITION: 50 MOLE % IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE % ZINC OXIDE (SHERWIN WILLIAMS)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 12.53 % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO  
 (AFTER 2 HOURS OF RUNNING)

ANALYSIS:

BEFORE	AFTER
TOTAL SULFUR:	
SURFACE AREA:	50 M/G
DENSITY :	G/CC

POROSITY :  
 X-RAY DIFFRACTION:

OPERATING CONDITIONS

TEMPERATURE: 1000 F (537 C)

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 0.7 PPM STEADY STATE

PRESSURE : AMBIENT

BREAKTHRU WITH 2 PPM AT 2.5 HOURS

SPACE VELOCITY: 1442 HOURLY

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	3.72
H <sub>2</sub> O		
AIR		
CO <sub>2</sub>	3.6 SCFH	13.53 %
CO	4.3 SCFH	16.16 %
H <sub>2</sub>	6.3 SCFH	23.72
CH <sub>4</sub>	1.07 SCFH	4.02
N <sub>2</sub>	10.34 SCFH	38.87 %

REMARKS

1. THIS IS THE FIRST SULFIDATION ON THIS LOAD OF SORBENT.
2. 5 STROKES USED ON DETECTOR TUBE SAMPLE PUMP.

CONCLUSIONS

1. ZINC FERRITE CAN REDUCE A DRY GAS STREAM TO LESS THAN 1 PPM.
2. ZINC FERRITE REDUCES THE H<sub>2</sub>S LEVEL DOWN TO THE SAME LEVEL AS ZINC OXIDE AT THE SAME CONDITIONS.
3. ZINC FERRITE REDUCES THE H<sub>2</sub>S LEVEL CLOSE TO THE ZINC OXIDE EQUILIBRIUM LEVEL OF 0.25 PPM

TOTAL DRY GAS FLOW RATE = 26.6 SCFH

TEST SUMMARY SHEET

TEST NO. : 044  
 DATE STARTED : 8/14/81  
 DATE ENDED : 8/14/81  
 TOTAL HOURS : 3 HRS.  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE EXTRUSIONS WITH VANADIUM  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1000 F (537 C) LURGI GAS COMPOSITION

SORBENT TYPE/WEIGHT: (ZINC FERRITE + VANADIUM)/619 GM  
 SORBENT NO. :  
 SORBENT COMPOSITION: 49 MOLE % IRON OXIDE (FISHER CERTIFIED)  
                   49 MOLE % ZINC OXIDE (SHERWIN WILLIAMS)  
                   1.36 MOLE % ZNV2O4 (NETC)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)  
                   MOLE S/MOLE ZNO

ANALYSIS:

BEFORE	AFTER
TOTAL SULFUR:	SQ M/G
SURFACE AREA:	G/CC
DENSITY :	
POROSITY :	

X-RAY DIFFRACTION:

OPERATING CONDITIONS

DATA: (BY DETECTOR TUBE)

TEMPERATURE: 1000 F (537 C)

EXIT H<sub>2</sub>S: 1.2 TO 7.0 PPM STEADY STATE FOR 1.5 HRS

PRESSURE : AMBIENT

BREAKTHRU WITH 11.6 PPM AT 2 HOURS

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
	SCFH	CC/MIN
H <sub>2</sub> S	1.0 SCFH	3.78
H <sub>2</sub> O		3.88
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.4 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12 %
CH <sub>4</sub>	1.1 SCFH	2.91 %
N <sub>2</sub>	12.2 SCFH	33.09 %

REMARKS

1. THIS IS THE FIRST SULFIDATION ON THIS LOAD OF SORBENT.

CONCLUSIONS

1. NO DETECTABLE EFFECT OF VANADIUM IN THE SORBENT

TEST SUMMARY SHEET

TEST NO. : 045  
 DATE STARTED : 8/21/81  
 DATE ENDED : 8/25/81  
 TOTAL HOURS : 10 HRS  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF ZINC OXIDE PELLETS FROM TEST 042  
 USING SPACE VELOCITY OF 600.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 GM  
 SORBENT NO. : MARSHAW ZNO U-01 E3/16 LOT 95 DRUM A/1  
 SORBENT COMPOSITION: 100 % ZINC OXIDE

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:

SURFACE AREA:

DENSITY :

PORE VOLUME :

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F (538 C)

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 9.14 % (AVG)

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O            2.23 CC/MIN 50%

1. NORMAL REGENERATION

AIR            5.88 SCFH 50%

2. AFTER COMPLETION OF THIS REGENERATION, ABSORBER  
 TEMPERATURE WAS MAINTAINED AND SULFIDATION REPEATED

CO2

CONCLUSIONS

CO

1. THIS IS THE FIRST REGENERATION ON THIS BATCH OF  
 SORBENT.

H2

CH4

N2

TEST SUMMARY SHEET

TEST NO. : 046  
 DATE STARTED : 8/28/81  
 DATE ENDED : 8/28/81  
 TOTAL HOURS : 4 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC OXIDE PELLETS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1000 F (537 C) USING DRY (NO WATER) LURGI GAS  
 COMPOSITION AT REDUCED SPACE VELOCITY (721 HOURLY)

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/1000 GM  
 SORBENT NO. : HARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
 SORBENT COMPOSITION: 100 % ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 8.09 % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

ANALYSIS:

BEFORE	AFTER
TOTAL SULFUR:	SQ M/G
SURFACE AREA:	G/CC
DENSITY :	
POROSITY :	
X-RAY DIFFRACTION:	

OPERATING CONDITIONS

TEMPERATURE: 1000 F (537 C)

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 0.2 PPM STEADY STATE FOR 4 HOURS

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 721 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.50 SCFH	3.7%
H <sub>2</sub> O		
AIR		
CO <sub>2</sub>	1.8 SCFH	13.53 %
CO	2.2 SCFH	16.16 %
H <sub>2</sub>	3.2 SCFH	23.6%
CH <sub>4</sub>	.53 SCFH	4.0%
N <sub>2</sub>	5.17 SCFH	38.87 %

REMARKS

1. THIS IS THE SECOND SULFIDATION ON THIS LOAD OF SORBENT.
2. DUE TO THE LOWER SV USED, BREAKTHROUGH WAS NOT REACHED WITHIN 4 HOURS. THE STEADY STATE H<sub>2</sub>S LEVEL WAS THE PRIMARY OBJECTIVE.

CONCLUSIONS

1. THE EXIT H<sub>2</sub>S OF 0.2 PPM (AVG) COMPARES WELL WITH THE CALCULATED EQUILIBRIUM VALUE OF 0.35 PPM.
2. THIS SPACE VELOCITY (721 HOURLY) APPEARS TO ACHIEVE EQUILIBRIUM H<sub>2</sub>S AT 1000 F.

TEST SUMMARY SHEET

TEST NO. : 047  
 DATE STARTED : 9/ 1/81  
 DATE ENDED : 9/ 1/81  
 TOTAL HOURS : 4 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS  
 TO PREPARE FOR REGENERATION AT 75% AIR AND 25% STEAM  
 FOR RESOX COMPATIBILITY

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH #2  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 12.53 % (GM SULFUR/GM FRESH SORBENT)  
 (FOR 2 HOURS OF RUNNING)

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR (%W/W):		
SURFACE AREA (M2/G):		
DENSITY (G/CC):		
PORE VOLUME (CM3/G):		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: (DETECTOR TUBE)

EXIT H2S: < 5 PPM FOR 2.5 HOURS

PRESSURE : AMBIENT

55 PPM AFTER 3 HOURS

SPACE VELOCITY: 2000 HOURLY

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872 CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	33.09 %

REMARKS

1. THIS TEST IS TO PREPARE FOR REGENERATION AT 75% AIR  
 25% STEAM FOR RESOX COMPATIBILITY EVALUATION.

CONCLUSIONS

1. STANDARD SULFIDATION COMPLETED.

TOTAL DRY GAS FLOW RATE = 26.6 SCFM

TEST SUMMARY SHEET

TEST NO. : 048  
 DATE STARTED : 9/ 2/81  
 DATE ENDED : 9/ 2/81  
 TOTAL HOURS : 5 HRS  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF ZINC FERRITE PELLETS FROM TEST 047  
 USING 75 % AIR AND 25 % STEAM.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH #2  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 9.4 % (AVG)  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	1.11 CC/MIN	25%
AIR	8.81 SCFH	75%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

1. THIS TEST IS TO REGENERATE USING 75 % AIR 25% STEAM TO TEST COMPATIBILITY WITH RESOX PROCESS
2. TEMPERATURE WAVE AT INLET REACHED 1820 F. SINTERING DAMAGED SOME OF THE PELLETS AS OBSERVED VISUALLY.

CONCLUSIONS

1. 75 % AIR DURING REGENERATION AT SV = 600 HOURLY CAUSES TOO HIGH A TEMPERATURE WAVE.
2. LOWER AIR LEVELS SHOULD BE USED.

TEST SUMMARY SHEET

TEST NO. : 049  
 DATE STARTED : 9/11/81  
 DATE ENDED : 9/11/81  
 TOTAL HOURS : 1 HR  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS TO CHECK FOR ANY LOSS OF ACTIVITY AFTER REGENERATION WITH 75% AIR AND 25% STEAM FOR RESOX COMPATIBILITY

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX # 1 BATCH #2  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 3.13 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M2/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM3/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

BEFORE      AFTER

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

DATA: ( DETECTOR TUBE)

EXIT H2S: 6 PPM FOR 1/2 HOUR STEADY STATE  
 EXIT SO2: 1150 PPM AFTER 1 HOUR  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S	0.9953 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	33.09,%

REMARKS

1. RAPID BREAKTHROUGH OBSERVED WITH HIGH INITIAL H2S CONCENTRATION (6PPM).  
 2.

CONCLUSIONS

1. LOSS OF ACTIVITY OBSERVED IS DUE TO REGENERATION WITH 75 % AIR IN TEST U48 CAUSED BY SINTERING AT EXCESSIVE TEMPERATURES.

**TEST SUMMARY SHEET**

TEST NO. : 050  
 DATE STARTED : 9/22/81  
 DATE ENDED : 9/23/81  
 TOTAL HOURS : 8.25 HRS  
 TYPE : REGENERATION

**PURPOSE**  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 043

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH #3/  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
 50 MOLES ZINC OXIDE (SHERWIN WILLIAMS MSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

**ANALYSIS:** BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

**OPERATING CONDITIONS**

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

**DATA: (DETECTOR TUBE)**

EXIT H2S:  
 EXIT SO2: 10.4 - 16 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

**REMARKS**

1. NORMAL REGENERATION

**CONCLUSIONS**

TEST SUMMARY SHEET

TEST NO. : 051  
 DATE STARTED : 9/30/81  
 DATE ENDED : 9/30/81  
 TOTAL HOURS : 4.0 HRS  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH # 3  
 SORBENT COMPOSITION: 50 MOLE % IRON OXIDE (FISHER CERTIFIED)  
                   50 MOLE % ZINC OXIDE (SHERWIN WILLIAMS)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 7.87 % (GM SULFUR/GM FRESH SORBENT)  
                   MOLE S/MOLE ZNO

OPERATING CONDITIONS

TEMPERATURE: 900 F (482 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 721 HOURLY

	FLOW RATE	MOLES
H2S	0.500 SCFH	3.7%

H2O

AIR

CO2	1.8 SCFH	13.53 %
CO	2.15 SCFH	16.16 %
N2	3.15 SCFH	23.6%
CH4	0.535 SCFH	4.0%
N2	5.17 SCFH	38.87 %

TOTAL DRY GAS FLOW RATE = 13.3 SCFM

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS  
 TO DETERMINE EXIT H2S COMPOSITION AT SORPTION TEMPERATURE  
 OF 900 F (482 C) USING DRY (NO WATER) LURGI GAS  
 COMPOSITION AT REDUCED SPACE VELOCITY OF 721 HR-1.

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR:		
SURFACE AREA:		50 M/G
DENSITY :		G/CC
POROSITY :		
X-RAY DIFFRACTION:		

DATA: (BY DETECTOR TUBE)

EXIT H2S: 0.75 PPM AT STEADY STATE FOR 2.5 HRS

                  BREAKTHRU WITH 53 PPM AT 3.5 HOURS

EXIT SO2:

EXIT S2:

EXIT H2:

REMARKS

1. THIS IS THE SECOND SULFIDATION ON THIS LOAD OF SORBENT.
- 2.

CONCLUSIONS

1. H2S LEVEL APPROACHES ZNO EQUILIBRIUM LEVEL OF 0.1 PPM.
2. H2S LEVEL IS LOWER THAN TEST AT 1000 F, HOWEVER BREAKTHROUGH IS 2 HOURS SOONER.
3. KINETICS APPEAR SLOWER THAN AT 1000F, ALTHOUGH EQUILIBRIUM FAVORS LOWER H2S.

TEST SUMMARY SHEET

TEST NO. : 052  
DATE STARTED : 10/01/81  
DATE ENDED : 10/01/81  
TOTAL HOURS : 9.75 HRS  
TYPE : REGENERATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
SORBENT NO. : MIX #1 BATCH #3/  
SORBENT COMPOSITION: 50 MOLES IRON OXIDE (FISHER CERTIFIED)  
50 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
PRETREATMENT :  
SULFUR REMOVED :

PURPOSE  
REGENERATION OF ZINC FERRITE PELLETS FROM TEST 051

ANALYSIS: BEFORE AFTER  
TOTAL SULFUR:  
SURFACE AREA:  
DENSITY :  
PORE VOLUME:  
MINERAL ANALYSIS:  
ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
PRESSURE : AMBIENT  
SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)  
EXIT H2S:  
EXIT SO2: 10.8-14.4 %  
EXIT S2:  
EXIT H2:

FLOW RATE MOLES

H2S  
H2O 2.23 CC/MIN 50%  
AIR 5.88 SCFM 50%  
CO2  
CO  
H2  
CH4  
N2

REMARKS

CONCLUSIONS

TEST SUMMARY SHEET

TEST NO. : 053  
 DATE STARTED : 10/14/81  
 DATE ENDED : 10/14/81  
 TOTAL HOURS : 5.0 HRS  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #1 BATCH # 3  
 SORBENT COMPOSITION: 50 MOLE % IRON OXIDE (FISHER CERTIFIED)  
 50 MOLE % ZINC OXIDE (SHERWIN WILLIAMS)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 14.16 % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

OPERATING CONDITIONS

TEMPERATURE: 1000 F ( 537C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 721 HOURLY

	FLOW RATE	MOLES
H2S	0.500 SCFH	3.7%
H2O		
AIR		
CO2	1.8 SCFH	13.53 %
CO	2.15 SCFH	16.16 %
H2	3.15 SCFH	23.6%
CH4	0.535 SCFH	4.0%
N2	5.17 SCFH	38.87 %

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS  
 TO DETERMINE EXIT H2S COMPOSITION AT SORPTION TEMPERATURE  
 OF 1000 F (537 C) USING DRY (NO WATER) LURGI GAS  
 COMPOSITION AT REDUCED SPACE VELOCITY OF 721 MR-1.

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 POROSITY :  
 X-RAY DIFFRACTION:

DATA: (BY DETECTOR TUBE)

EXIT H2S: 2.1 PPM AT STEADY STATE FOR 4.5 HRS

EXIT SO2: BREAKTHRU WITH 43 PPM AT 5 HOURS

EXIT S2:

EXIT H2:

REMARKS

1. THIS IS THE THIRD SULFIDATION ON THIS LOAD OF SORBENT.


CONCLUSIONS

1. H2S LEVEL SLIGHTLY HIGHER THAN AT 900 F BUT BREAKTHROUGH IS 2 HOURS LATER.

2. LOWER S.V. INCREASES BREAKTHROUGH TIME BY 2 HOURS AS COMPARED TO S.V. 1442 HOURLY (TO43).


# ZINC FERRITE SULFIDATION

TEST 051,053




22-NOV-82 15:43:37

ZINC FERRITE SULFIDATION  
TEST 043,053




# ZINC FERRITE SULFIDATION

TESTS AVG(16,21,47),043,051,053



# HOT GAS DESULFURIZATION


ZINC FERRITE AND ZINC OXIDE



P:

# SULFIDATION

TESTS 043, 042R




22-NOV-82 15:09:17

-50C-


# ZINC OXIDE SULFIDATION

TESTS 042R, 046 (HARSHAW ZN-D401)



C  
ZINC OXIDE SULFIDATION

TESTS 042R, 046, 034 (HARSHAW ZN-0401)




22-NOV-82 16:01:13

P:

# SULFUR LOADING

ZINC FERRITE AND ZINC OXIDE  
TEMPERATURE (C)



-80E-

TEST SUMMARY SHEET

TEST NO. : 054  
 DATE STARTED : 10/16/81  
 DATE ENDED : 10/16/81  
 TOTAL HOURS : 3.25 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF A VANADIUM CATALYST TO LOWER THE H<sub>2</sub>S LEVEL BELOW 10 PPM AFTER A ZINC OXIDE BED.

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM  
 VANADIUM CATALYST/474 GM  
 SORBENT NO. : HARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
 HARSHAW VANADIUM CATALYST V-0701

SORBENT COMPOSITION:

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : REDUCE VANADIUM CATALYST FOR 1 HOUR  
 SULFUR LOADING : 4.0 % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 POROSITY :  
 X-RAY DIFFRACTION:

OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 100 PPM FOR 2 HRS STEADY STATE

PRESSURE : AMBIENT

BREAKTHRU WITH 126 PPM AT 1.75 HRS

SPACE VELOCITY: 1000 HOURLY

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.500 SCFH	2.7%
H <sub>2</sub> O	1.93 CC/MIN	27.66 %
AIR		
CO <sub>2</sub>	1.8 SCFH	9.79 %
CO	2.15 SCFH	11.69 %
H <sub>2</sub>	3.15 SCFH	17.13%
CH <sub>4</sub>	0.535 SCFH	2.91%
N <sub>2</sub>	5.17 SCFH	28.12 %

REMARKS

1. HALF THE REACTOR IS FILLED WITH ZNO AND HALF WITH VANADIUM CATALYST.
2. REDUCTION WILL BE CARRIED OUT ON THE GASES AND FLOWS SPECIFIED AT LEFT WITHOUT H<sub>2</sub>S.
3. FIRST SULFIDATION

CONCLUSIONS

1. VANADIUM CATALYST DOES NOT REDUCE H<sub>2</sub>S BELOW 10 PPM.

TOTAL DRY GAS FLOW RATE = 13.3 SCFH  
 TOTAL WET GAS FLOW RATE = 18.38 SCFH

TEST SUMMARY SHEET

TEST NO. : 055  
 DATE STARTED : 10/16/81  
 DATE ENDED : 10/18/81  
 TOTAL HOURS : 3.5 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF HALF A ZINC OXIDE BED TO LOWER THE H<sub>2</sub>S LEVEL BELOW 10 PPM

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM

SORBENT NO. : MARSHAL ZNO 0401 E3/16 LOT95 DRUM A

SORBENT COMPOSITION:

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 6.07 % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 POROSITY :  
 X-RAY DIFFRACTION:

OPERATING CONDITIONS

TEMPERATURE: 1200 F ( 649 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 7 PPM FOR 1.5 HRS      STEADY STATE

                  BREAKTHRU WITH 13 PPM AT 1.75 HRS

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.500 SCFH	2.7%
H <sub>2</sub> O	1.93 CC/MIN	27.65 %
AIR		
CO <sub>2</sub>	1.8 SCFH	9.79 %
CO	2.15 SCFH	11.69 %
H <sub>2</sub>	3.15 SCFH	17.13%
CH <sub>4</sub>	0.535 SCFH	2.91%
N <sub>2</sub>	5.17 SCFH	28.12 %

REMARKS

1. HALF THE REACTOR IS FILLED WITH ZNO
2. THIS TEST IS TO VERIFY THE EXIT LEVEL OF H<sub>2</sub>S USING HALF A BED OF ZNO.

CONCLUSIONS

1. ZNO LOWERS H<sub>2</sub>S BELOW 10 PPM FOR 1.5 HRS AT 1200F .

TOTAL DRY GAS FLOW RATE = 13.3 SCFH  
 TOTAL WET GAS FLOW RATE = 18.39 SCFM

TEST SUMMARY SHEET

TEST NO. : 056  
 DATE STARTED : 10/23/81  
 DATE ENDED : 10/23/81  
 TOTAL HOURS : 4.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC OXIDE AND VANADIUM CATALYST  
 PELLETS FROM TEST 056.

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM  
 VANADIUM CATALYST/474 GM  
 SORBENT NO. : MARSHAW ZNO C401 E3/16 LOT95 DRUM A  
 MARSHAW VANADIUM CATALYST V-0701  
 SORBENT COMPOSITION:  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR REMOVED :

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 9.2 - 14.2 %  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

1. FIRST REGENERATION OF VANADIUM CATALYST.

CONCLUSIONS

TEST SUMMARY SHEET

TEST NO. : 057  
 DATE STARTED : 10/26/81  
 DATE ENDED : 10/26/81  
 TOTAL HOURS : 3.5 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF A VANADIUM CATALYST TO LOWER THE H<sub>2</sub>S LEVEL BELOW 10 PPM AFTER A ZINC OXIDE EOD.

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM  
 VANADIUM CATALYST/474 GM  
 SORBENT NO. : HARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
 HARSHAW VANADIUM CATALYST V-0701

SORBENT COMPOSITION:

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : REDUCE VANADIUM CATALYST FOR 1 HOUR  
 SULFUR LOADING : 5.19 % (GM SULFUR/GM FRESH SORBENT)  
 ( MOLE S/MOLE ZNO )

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 POROSITY :

X-RAY DIFFRACTION:

OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 11-23 PPM FOR 2.5 HRS STEADY STATE

BREAKTHRU WITH 30 PPM AT 3 HRS

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 1000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.500 SCFH	2.7%
H <sub>2</sub> O	1.93 CC/MIN	27.66 %
AIR		
CO <sub>2</sub>	1.8 SCFH	9.79 %
CO	2.15 SCFH	11.69 %
H <sub>2</sub>	3.15 SCFH	17.13%
CH <sub>4</sub>	0.535 SCFH	2.91%
N <sub>2</sub>	5.17 SCFH	28.12 %

REMARKS

1. HALF THE REACTOR IS FILLED WITH ZNO AND HALF WITH VANADIUM CATALYST.
2. REDUCTION WILL BE CARRIED OUT ON THE GASES AND FLOWS SPECIFIED AT LEFT WITHOUT H<sub>2</sub>S.
3. BOTH ZNO AND VANADIUM HAVE BEEN REGENERATED.
4. SECOND SULFIDATION.

CONCLUSIONS

1. VANADIUM CATALYST (V-0701) DOES NOT REDUCE H<sub>2</sub>S BELOW 10 PPM.

TOTAL DRY GAS FLOW RATE = 13.3 SCFH  
 TOTAL WET GAS FLOW RATE = 18.33 SCFH

TEST SUMMARY SHEET

TEST NO. : 058  
 DATE STARTED : 10/30/81  
 DATE ENDED : 10/30/81  
 TOTAL HOURS : 6 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC OXIDE AND VANADIUM CATALYST  
 PELLETS FROM TEST 057.

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM  
 VANADIUM CATALYST/474 GM  
 SORBENT NO. : MARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
 MARSHAW VANADIUM CATALYST V-0701  
 SORBENT COMPOSITION:  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR REMOVED :

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:

EXIT SO2: 5 - 12 %

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

I. THIS IS THE SECOND REGENERATION ON THIS SORBENT.

- CONCLUSIONS

TEST SUMMARY SHEET

TEST NO. : 059  
 DATE STARTED : 11/03/81  
 DATE ENDED : 11/03/81  
 TOTAL HOURS : 3 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF A VANADIUM CATALYST  
 TO LOWER THE H<sub>2</sub>S LEVEL BELOW 10 PPM AFTER A ZINC  
 OXIDE EED. (SECOND TIME)

SORBENT TYPE/WEIGHT: ZINC OXIDE/500 GM  
 VANADIUM CATALYST/474 GM  
 SORBENT NO. : MARSHAW ZNO 0401 E3/16 LOT95 DRUM A  
 MARSHAW VANADIUM CATALYST V-0701  
 SORBENT COMPOSITION:  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT : REDUCE VANADIUM CATALYST FOR 3 HOUR  
 SULFUR LOADING : 3 (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 POROSITY :  
 X-RAY DIFFRACTION:

OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1000 HOURLY

DATA: (BY DETECTOR TUBE)

EXIT H<sub>2</sub>S: 1000-2000 PPM DURING REDUCTION  
 EXIT SO<sub>2</sub>:  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.500 SCFH	2.7%
H <sub>2</sub> O	1.93 CC/MIN	27.66 %
AIR		
CO <sub>2</sub>	1.8 SCFH	9.79 %
CO	2.15 SCFH	11.69 %
H <sub>2</sub>	3.15 SCFH	17.13 %
CH <sub>4</sub>	0.535 SCFH	2.91 %
N <sub>2</sub>	5.17 SCFH	28.12 %

TOTAL DRY GAS FLOW RATE = 13.3 SCFH  
 TOTAL WET GAS FLOW RATE = 18.38 SCFH

REMARKS

1. HALF THE REACTOR IS FILLED WITH ZNO AND HALF WITH VANADIUM CATALYST.
2. REDUCTION WILL BE CARRIED OUT ON THE GASES AND FLOWS SPECIFIED AT LEFT WITHOUT H<sub>2</sub>S.
3. BOTH ZNO AND VANADIUM HAVE BEEN REGENERATED.


CONCLUSIONS

1. H<sub>2</sub>S LEVEL TOO HIGH (1000-2000) DURING REDUCTION.
2. TEST ABORTED.

P1


# ZINC FERRITE SULFIDATION

TESTS 044,034,021



# VANADIUM SULFIDATION


TEST 054 (V-0701)



22-NOV-82 16:08:03


## ZINC OXIDE SULFIDATION

TEST 055 (HARSHAW ZN-0401)




# VANADIUM SULFIDATION

TESTS 057, 054 (V-0701)



# VANADIUM SULFIDATION

TEST 057 (V-0701)



TEST SUMMARY SHEET

TEST NO. : 060  
 DATE STARTED : 11/05/81  
 DATE ENDED : 11/05/81  
 TOTAL HOURS : 1.5 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF HALF A BED OF FRANKLINITE ORE TO LOWER THE H<sub>2</sub>S LEVEL BELOW 10 PPM

SORBENT TYPE/WEIGHT: FRANKLINITE ORE/1027 GM

ANALYSIS:

SORBENT NO. : MIX 2 BATCH #1

BEFORE AFTER

SORBENT COMPOSITION: FRANKLINITE ORE SEPARATED MAGNETICALLY FROM ZINC ORE  
 SORBENT PELLET SIZE: SPHERES LESS THAN 1/2 INCH DIAM  
 PRETREATMENT : NONE  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)  
 MOLE S/MOLE ZNO

TOTAL SULFUR: .8583 S2 M/G  
 SURFACE AREA: 5.440 G/CC  
 DENSITY :  
 POROSITY :  
 X-RAY DIFFRACTION:

OPERATING CONDITIONS

DATA: (BY DETECTOR TUBE)

TEMPERATURE: 1000 F (537 C)

EXIT H<sub>2</sub>S: 4020 PPM AT 15 MINUTES STEADY STATE

PRESSURE : AMBIENT

BREAKTHRU IMMEDIATE

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.500 SCFH	2.7%
H <sub>2</sub> O	1.93 CC/MIN	27.66 %
AIR		
CO <sub>2</sub>	1.8 SCFH	9.79 %
CO	2.15 SCFH	11.69 %
H <sub>2</sub>	3.15 SCFH	17.13%
CH <sub>4</sub>	0.535 SCFH	2.91%
N <sub>2</sub>	5.17 SCFH	28.12 %

REMARKS

1. HALF THE REACTOR IS FILLED WITH FRANKLINITE ORE
2. BED HEIGHT IS 9 1/8 INCH.

CONCLUSIONS

1. FRANKLINITE ORE IN THIS FORM IS NOT A GOOD SORBENT.
2. SUSPECT LOW SURFACE AREA A PROBLEM.

TOTAL DRY GAS FLOW RATE = 13.3 SCFH  
 TOTAL WET GAS FLOW RATE = 18.38 SCFH

 national (1) 749.02.14  
international +33 1 749.02.14

Department of Energy  
Morgantown Energy Technology Center  
P.O. Box 880  
Collins Ferry Road  
Morgantown, West Virginia 26505

poste 2974 010812  
N/Réf. AD/fm - 7910

DIRECTION PHYSICO-CHIMIE APPLIQUEE

July 6, 1982

Object : Your letter TG-dp-512h

Dear Mr. GRINDLEY,

Thank you very much for the sample of IFP desulfurization sorbent MEP-682 and the draft report on the tests you have performed on it.

Concerning your tests and the comparison of the performances of our sorbent with those of Harshaw catalyst we have the following comments and questions:

- the IFP sorbent is designed for the removal of the bulk of the H<sub>2</sub>S from a gazifier effluent before using it in a gas turbine for electricity production by combined cycles. It is not intended for the removal of traces of H<sub>2</sub>S. The selection criterion used in our work was the sorbent capability to perform a great number of cycles with a good mechanical strength, a sulfur capacity in the range of 8-15 % weight and a H<sub>2</sub>S concentration level in the treated gas of less than 300 ppm Vol.,

- you said that Harshaw sorbent is not intended for regeneration and contains no strengthening agents. Are the results on Harshaw sorbent presented in figures 5 and 6 obtained with fresh samples or after several regenerations? We would appreciate if you could send us a copy of your report IR-N°1133 in which the results of these tests are related in detail and other reports which could be available on this subject,

- we do not believe that the degradation of IFP sorbent could be attributed to its sulfidation at 649°C. We have performed ourselves several sulfidations up to 800°C without noticing any detrimental effect on the further runs at 500°C or 600°C. We agree that the best results are obtained in the 500°C - 600°C temperature range but we consider that the drop of the sulfur capacity versus temperature given in figure 6 is not representative of the performances of our sorbent when utilized for what it is designed,

- according to our experience the performances and the duration of a regenerable sorbent are closely related to the conditions used for its regeneration. In your test the low inlet temperature of the oxidizing gas (38°C) favorizes the formation of zinc sulfate which is later reduced in the sulfidation step



with emission of  $\text{SO}_2$ . This emission increase with the temperature of the sulfidation step and affects the level of desulfurization.

In addition, the high oxygen content of the oxidizing gaz (10 %) allows the sorbent to reach a temperature far higher than the reported  $816^\circ\text{C}$ , inducing sintering.

In our tests we use an inlet temperature of  $700^\circ\text{C}$  and an oxygen content of 2 % vol. (maximum temperature  $900^\circ\text{C}$ ). With these conditions we observe a rapid decrease of the sulfur capacity during the firsts cycles corresponding to the chemical stabilization of the binder (formation of  $\text{Ca SO}_4$  and  $\text{Zn Al}_2\text{O}_4$ ) and then stable performances over 50 cycles (sulfur capacity about 10 % weight for breakthrough at 200 ppm vol.  $\text{H}_2\text{S}$ , at  $600^\circ\text{C}$  and GHSV 1000).

- the analyses of IFP sorbent presented in table 6 are not consistent with the statement that the IFP sorbent "has been irreversibly damaged during the excursion at  $1200^\circ\text{F}$ ". It is probably a question of level of  $\text{H}_2\text{S}$  concentration at which you consider that there is breakthrough,


- could you specify if the very surprising figures obtained for zinc carry-over are specific to the IFP sorbent or not.

We hope that these comments will lead you to modify some negative aspects of your conclusion on our MEP-682 sorbent.

In fact we do not intend to commercialize this sorbent, mainly for zinc entrainment problems due to  $\text{Zn S}$  and  $\text{Zn}$  vapor pressures. We have recently restarted our researches in this field and we are working on iron and calcium based sorbents with the target of defining the bases of a regenerative hot fuel gas desulfurization process.

In this view we are very interested in keeping in contact with you and exchanging informations.

Sincerely,



A. DESCHAMPS

TEST SUMMARY SHEET

TEST NO. : 061  
 DATE STARTED : 11/9/81  
 DATE ENDED : 11/9/81  
 TOTAL HOURS : 2.5 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1000 F

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP 7/1 PEP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE

ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME :  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : 6.77 % (GM SULFUR/GM FRESH SORBENT)

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S: 30 PPM PLATEAU FOR 1.5 HR

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>: BREAKTHRU WITH 232 PPM AT 2 HRS

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.69 %
	4.3 SCFH	11.91 %
N <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

1. THIS IS THE FIRST SULFIDATION ON THIS SORBENT.
2. 60 F TEMP WAVE RECORDED AT INLET, AT START OF RUN.

CONCLUSIONS

1. H<sub>2</sub>S LEVELS ABOVE EQUILIBRIUM LEVELS.

### TEST SUMMARY SHEET

TEST NO. : 062  
DATE STARTED : 11/11/81  
DATE ENDED : 11/12/81  
TOTAL HOURS : 4.75 HRS  
TYPE : REGENERATION

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM  
SORBENT NO. : IFP ZNO MEP 682  
SORBENT COMPOSITION: 70 % ZINC OXIDE  
SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS  
PRETREATMENT : NONE  
SULFUR REMOVED :

#### OPERATING CONDITIONS

TEMPERATURE: 1000 F  
PRESSURE : AMBIENT  
SPACE VELOCITY: 600 HOURLY

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

#### PURPOSE

REGENERATION OF IFP ZINC OXIDE FROM TEST 061.

#### ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
SURFACE AREA:  
DENSITY :  
PORE VOLUME:  
MINERAL ANALYSIS:  
ELEMENTAL ANALYSIS:

#### DATA: (DETECTOR TUBE)

EXIT H2S:  
EXIT SO2: 8.8 - 14.4 %  
EXIT S2:  
EXIT H2:

#### REMARKS

I. THIS IS THE FIRST REGENERATION ON THIS SORBENT.

#### CONCLUSIONS

II. NORMAL REGENERATION.

TEST SUMMARY SHEET

TEST NO. : 063  
 DATE STARTED : 11/13/81  
 DATE ENDED : 11/13/81  
 TOTAL HOURS : 3.5 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS SECOND TIME  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1000 F

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP ZNO MCP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE  
 SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : 9.04 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:  
 BEFORE      AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME :  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: 5 PPM PLATEAU FOR 2 HRS

SPACE VELOCITY: 2000 HOURLY

EXIT SO<sub>2</sub>: BREAKTHRU WITH 20 PPM AT 2.5 HRS

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

1. THIS IS THE SECOND SULFIDATION ON THIS SORBENT.

CONCLUSIONS

1. LESS THAN 10 PPM H<sub>2</sub>S FOR 2 HRS.

TEST SUMMARY SHEET

TEST NO. : 064  
 DATE STARTED : 11/17/81  
 DATE ENDED : 11/17/81  
 TOTAL HOURS : 7 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF IFP ZINC OXIDE FROM TEST 063.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP 682

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS

PRETREATMENT : NONE

SULFUR REMOVED :

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H2S:

SPACE VELOCITY: 600 HOURLY

EXIT SO2: 5.6 - 11.6 %

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%

REMARKS

AIR 5.88 SCFH 50%

1. THIS IS THE SECOND REGENERATION ON THIS SORBENT.

CO

H2

CH4

N2

CONCLUSIONS

1. NORMAL REGENERATION

TEST SUMMARY SHEET

TEST NO. : 065  
 DATE STARTED : 11/18/81  
 DATE ENDED : 11/18/81  
 TOTAL HOURS : 3 HRS  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP ZNO MEP 692  
 SORBENT COMPOSITION: 70 % ZINC OXIDE  
 SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : 9.03 % (GM SULFUR/GM FRESH SORBENT)

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

PRESSURE : AMBIENT

SPACE VELOCITY: 2000 HOURLY

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	28.1 %

TOTAL DRY GAS FLOW RATE = 26.6 SCFH  
 TOTAL WET GAS FLOW RATE = 36.8 SCFH

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS THIRD TIME  
 TO DETERMINE EXIT H2S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1000 F

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR:		
SURFACE AREA:		
DENSITY :		
PORE VOLUME :		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		

DATA: ( DETECTOR TUBE)

EXIT H2S: 9 PPM PLATEAU FOR 2 HRS  
 BREAKTHRU WITH 200 PPM AT 2.5 HRS  
 EXIT SO2:  
 EXIT S2:  
 EXIT H2:

REMARKS

1. THIS IS THE THIRD SULFIDATION ON THIS SORBENT.

CONCLUSIONS

1. IFP ZNO CAN REDUCE H2S TO BELOW 10 PPM.  
 2. NO APPARENT LOSS OF ACTIVITY AFTER 2 CYCLES.

TEST SUMMARY SHEET

TEST NO. : 066  
 DATE STARTED : 11/20/81  
 DATE ENDED : 11/20/81  
 TOTAL HOURS : 7.0 HRS  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF IFP ZINC OXIDE FROM TEST 065.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP 682

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

11.6

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 7-15%

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

1. THIS IS THE THIRD REGENERATION ON THIS SORBENT.

AIR 5.88 SCFH 50%

CO2

CONCLUSIONS

CO

2. NORMAL REGENERATION.

H2

CH4

N2

TEST SUMMARY SHEET

TEST NO. : 067  
 DATE STARTED : 11/23/81  
 DATE ENDED : 11/23/81  
 TOTAL HOURS : 3 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS FOURTH TIME  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1000 F

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP ZNO MCP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE

SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : 6.78 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: 12 PPM PLATEAU FOR 1.5 HRS

SPACE VELOCITY: 2000 HOURLY

EXIT SO<sub>2</sub>: BREAKTHRU WITH 26 PPM AT 2 HRS

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE MOLES

H <sub>2</sub> S	0.9963 SCFM	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%

REMARKS

AIR		
CO <sub>2</sub>	3.6 SCFM	9.68 %
CO	4.3 SCFM	11.91 %
H <sub>2</sub>	6.3 SCFM	17.12%
CH <sub>4</sub>	1.07 SCFM	2.91%
N <sub>2</sub>	10.34 SCFM	28.1 %

CONCLUSIONS

1. THIS IS THE FOURTH SULFIDATION ON THIS SORBENT.

TEST SUMMARY SHEET

TEST NO. : 068  
 DATE STARTED : 11/30/81  
 DATE ENDED : 11/30/81  
 TOTAL HOURS : 7.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF IFP ZINC OXIDE FROM TEST 057.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP 692

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS

PRETREATMENT :

SULFUR REMOVED :

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 7.5-14%

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

1. THIS IS THE FOURTH REGENERATION ON THIS SORBENT.

AIR 5.88 SCFH 50%

CO2

CONCLUSIONS

CO

1. NORMAL REGENERATION.

H2

CH4

N2

TEST SUMMARY SHEET

TEST NO. : 069  
 DATE STARTED : 12/3/81  
 DATE ENDED : 12/3/81  
 TOTAL HOURS : 2.0 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS FIFTH TIME  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 800 F

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/852 GM  
 SORBENT NO. : IFP ZKO MEP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME :  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 4.515 % (GM SULFUR/GM FRESH SORBENT)

OPERATING CONDITIONS

TEMPERATURE: 800 F (538 C)

DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 16 PPM PLATEAU FOR 0.5 HR

BREAKTHRU WITH 25 PPM AT 1 HR

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.71
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

1. THIS IS THE FIFTH SULFIDATION ON THIS SORBENT.
2. ZINC METAL ANALYSIS OF CONDENSED WATER INDICATES 324 PPM ZINC.

CONCLUSIONS

1. RAPID BREAKTHROUGH AT 800 F INDICATES SLOWER KINETICS AT THE LOWER TEMPERATURE.

TEST SUMMARY SHEET

TEST NO. : 070  
 DATE STARTED : 01/7/82  
 DATE ENDED : 01/8/82  
 TOTAL HOURS : 7.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF IFP ZINC OXIDE FROM TEST 069.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP 682

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

SURFACE AREA:

DENSITY :

PORE VOLUME:

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 9.6-15.2 %

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

AIR 5.68 SCFM 50%

CO2

CO

H2

CH4

CONCLUSIONS

N2

1. NORMAL REGENERATION.

TEST SUMMARY SHEET

TEST NO. : 071  
 DATE STARTED : 01/12/82  
 DATE ENDED : 01/12/82  
 TOTAL HOURS : 1.0 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS SIXTH TIME  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1200 F

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP ZNO MEP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE

SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 1.12 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:  
 BEFORE      AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME :  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1200 F (649 C)

DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S: 15 PPM PLATEAU FOR 0.5 HR

PRESSURE : AMBIENT

BREAKTHRU WITH 590 PPM AT 0.5 HR

SPACE VELOCITY: 2000 HOURLY

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

1. THIS IS THE SIXTH SULFIDATION ON THIS SORBENT.
2. ANALYSIS OF CONDENSED WATER - 92.25 PPM ZINC

CONCLUSIONS

1. LOSS OF ACTIVITY AT HIGHER TEMPERATURE. POSSIBLE SINTERING.

TEST SUMMARY SHEET

TEST NO. : 072  
 DATE STARTED : 01/14/82  
 DATE ENDED : 01/15/82  
 TOTAL HOURS : 7.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF IFP ZINC OXIDE FROM TEST 071.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP 682

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

SURFACE AREA:

DENSITY :

PORE VOLUME:

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 9.0 - 12.4 %

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT N2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

AIR 5.88 SCFH 50%

CO2

CO

H2

CH4

CONCLUSIONS

N2

1. NORMAL REGENERATION.

TEST SUMMARY SHEET

TEST NO. : 073  
 DATE STARTED : 1/21/82  
 DATE ENDED : 1/21/82  
 TOTAL HOURS : 0.25 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF IFP ZINC OXIDE PELLETS SEVENTH TIME  
 TO DETERMINE EXIT H<sub>2</sub>S COMPOSITION AT SORPTION  
 TEMPERATURE OF 1000 F AFTER SULFIDATION AT 1200 F.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/892 GM  
 SORBENT NO. : IFP ZNO MEP 682  
 SORBENT COMPOSITION: 70 % ZINC OXIDE

SORBENT PELLET SIZE: 3 MM DIAMETER EXTRUSIONS  
 PRETREATMENT : NONE  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR:		
SURFACE AREA:	11.6	
DENSITY :		
PORE VOLUME :		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL SULFUR :	34.74	(SAMPLE HAS ZNS & CASO <sub>4</sub> )

OPERATING CONDITIONS

TEMPERATURE: 1000 F (538 C)

DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 28000 PPM AFTER 15 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

3. THIS IS THE SEVENTH SULFIDATION ON THIS SORBENT.

CONCLUSIONS

1. IMMEDIATE BREAKTHROUGH INDICATES SORBENT PROBABLY  
 WAS SINTERED IN THE 1200 F DEGREE RUN (TEST 071).

TEST SUMMARY SHEET

TEST NO. : 074  
 DATE STARTED : 2/8/82  
 DATE ENDED : 2/11/82  
 TOTAL HOURS : 12.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF IFP ZINC OXIDE FROM TEST 073.

SORBENT TYPE/WEIGHT: ZINC OXIDE/892 GM

ANALYSIS:

SORBENT NO. : IFP ZNO MEP-682

BEFORE AFTER

SORBENT COMPOSITION: 70 % ZINC OXIDE

TOTAL SULFUR:

SORBENT PELLET SIZE: 3MM DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

SURFACE AREA:

DENSITY :

PORE VOLUME:

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 14 % - 16 %

SPACE VELOCITY: 600 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

AIR 5.88 SCFH 50%

CO2

CO

H2

CH4

CONCLUSIONS

N2

1. NORMAL REGENERATION

TEST SUMMARY SHEET

TEST NO. : 075  
 DATE STARTED : 4/13/82  
 DATE ENDED : 4/13/82  
 TOTAL HOURS : 4.25 HRS  
 TYPE : SULFIDATION

PURPOSE

SULFIDATION OF ZINC FERRITE PELLETS WITH LOWER ZINC OXIDE CONTENT.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #2 BATCH #1/  
 SORBENT COMPOSITION: 71.4 MOLES IRON OXIDE (FISHER CERTIFIED)  
 28.6 MOLES ZINC OXIDE (SHERWIN WILLIAMS MSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 17.24 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR (%W):  
 SURFACE AREA (M2/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM3/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: ( DETECTOR TUBE)

EXIT H2S: 7 PPM PLATEAU FOR 2.75 HRS.

PRESSURE : AMBIENT

BREAKTHROUGH WITH 32 PPM AT 3.5 HRS.

SPACE VELOCITY: 2000 HOURLY

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

1. LOWERING THE ZINC OXIDE CONTENT OF ZINC FERRITE DOES NOT APPEAR TO AFFECT ITS PERFORMANCE APPRECIABLY

TEST SUMMARY SHEET

TEST NO. :	076	PURPOSE
DATE STARTED :	4/27/82	
DATE ENDED :	4/29/82	REGENERATION OF ZINC FERRITE PELLETS FROM TEST 075
TOTAL HOURS :	HRS	
TYPE :	REGENERATION	

SORBENT TYPE/WEIGHT:	(ZINC FERRITE)/643 GM	ANALYSIS:
SORBENT NO. :	MIX #1 BATCH #1/1	BEFORE      AFTER
SORBENT COMPOSITION:	71.4 MOLE% IRON OXIDE (FISHER CERTIFIED) 28.6 MOLE% ZINC OXIDE (SHERWIN WILLIAMS HSA)	TOTAL SULFUR: SURFACE AREA: DENSITY : PORE VOLUME: MINERAL ANALYSIS: ELEMENTAL ANALYSIS:
SORBENT PELLET SIZE:	3/16 INCH DIAMETER EXTRUSIONS	
PRETREATMENT :		
SULFUR REMOVED :		

OPERATING CONDITIONS

TEMPERATURE: 1000 F

PRESSURE : AMBIENT

SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:

EXIT SO2: 12 - 15 %

EXIT S2:

EXIT H2:

FLOW RATE      MOLES

H2S

H2O            2.23 CC/MIN    50%

AIR            5.88 SCFH    50%

CO2

CO

H2

CH4

N2

REMARKS

CONCLUSIONS

TEST SUMMARY SHEET

TEST NO. : 077  
 DATE STARTED : 5/12/82  
 DATE ENDED : 5/12/82  
 TOTAL HOURS : 1.5 HRS  
 TYPE : SULFIDATION

PURPOSE

SECOND SULFIDATION OF ZINC FERRITE PELLETS WITH LOWER ZINC OXIDE CONTENT.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : MIX #2 BATCH #1/1  
 SORBENT COMPOSITION: 71.4 MOLES IRON OXIDE (FISHER CERTIFIED)  
 28.6 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 1.57 % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR (%W):  
 SURFACE AREA (M2/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM3/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: ( DETECTOR TUBE)

EXIT H2S: 3.0 PPM FOR .25 HOURS

BREAKTHROUGH WITH 30 PPM AT .75 HOURS

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: 2000 HOURLY

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

1. POOR PERFORMANCE ON SECOND SULFIDATION POSSIBLY DUE TO INCOMPLETE REGENERATION.

TEST SUMMARY SHEET

TEST NO. : 078  
 DATE STARTED : 5/19/82  
 DATE ENDED : 5/24/82  
 TOTAL HOURS : 18.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 077

SORBENT TYPE/WEIGHT: ZINC FERRITE/643 GM  
 SORBENT NO. : MIX #1 BATCH #1/1  
 SORBENT COMPOSITION: 71.4 MOLES IRON OXIDE (FISHER CERTIFIED)  
 28.6 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS:  
 BEFORE      AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 13.7 PERCENT MAX 100 PPM AT END OF TEST  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.28 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

1. STEAM WAS SHUT OFF AFTER PASSAGE OF TEMP WAVE.
2. AIR FLOW RATE WAS INCREASED UP TO 32 SCFH, IN ORDER TO ATTEMPT LOWERING EXIT SO2.

CONCLUSIONS

1. SO2 LOWERED TO 100 PPM BY REDUCING STEAM AND INCREASING AIR FLOW RATES.

TEST SUMMARY SHEET

TEST NO. :	079	PURPOSE
DATE STARTED :	5/25/82	
DATE ENDED :	5/25/82	
TOTAL HOURS :	2 HRS	
TYPE :	SULFIDATION	THIRD SULFIDATION OF ZINC FERRITE PELLETS WITH LOWER ZINC OXIDE CONTENT.

SORBENT TYPE/WEIGHT:	ZINC FERRITE/643 GM	ANALYSIS:	
SORBENT NO. :	MIX #2 BATCH #1/1	BEFORE	AFTER
SORBENT COMPOSITION:	71.4 MOLES IRON OXIDE (FISHER CERTIFIED) 28.6 MOLES ZINC OXIDE (SHERWIN WILLIAMS HSA)	TOTAL SULFUR (%W/W):	
SORBENT PELLET SIZE:	3/16 INCH DIAMETER EXTRUSIONS	SURFACE AREA (M2/G):	
PRETREATMENT :		DENSITY (G/CC) :	
SULFUR LOADING :	7.84 % (GM SULFUR/GM FRESH SORBENT)	PORE VOLUME (MM3/G):	
		MINERAL ANALYSIS:	
		ELEMENTAL ANALYSIS:	

OPERATING CONDITIONS

TEMPERATURE:	1000 F	DATA: ( DETECTOR TUBE)
PRESSURE :	AMBIENT	EXIT H2S: 9.9 PPM AVG FOR 1.5 HRS
SPACE VELOCITY:	2000 HOURLY	EXIT SO2: BREAKTHROUGH WITH 1050 PPM AT 2 HRS.
		EXIT S2:
		EXIT H2:

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

- LOSS OF SULFIDATION CAPACITY OBSERVED IN COMPARISON TO FIRST SULFIDATION.

## POROSITY DETERMINATION

XRD 1.  $3\text{m}^2/\text{g}$   $\text{Fe}_2\text{O}_4$  mes  $>200\text{\AA}^\circ$

$6.6\text{m}^2/\text{g}$  Surface Area.

SAMPLE

415 DEPT OF ENERGY EKO 5156

SAMPLE WEIGHT NORMALIZED TO 1 gram

DATE


5/14/82

EQUIVALENT PORE DIAMETER (MICRONS) = 175/PSI

2' at 1500'  
L-1442,  $\% \text{Fe}_2\text{O}_3 = 1$

$65\text{ft}^3/\text{lb}$  Density  
 $2.3\text{t/mm Crush}$

$0.36\text{cc/g}$  Pore Volume  $>29\text{\AA}$   
 $15.20\text{\AA}$  Av Pore Diam.  
(CONTACT ANGLE =  $130^\circ$ )



**XRD**, Zon Te<sub>2</sub>O<sub>4</sub> mes > 2000 Å°

5.9 m<sup>3</sup>/g Surface Area

POROSITY DETERMINATION

SAMPLE USDR EKD 5157


SAMPLE WEIGHT NORMALIZED TO 1 gram

DATE 5/18/82

EQUIVALENT PORE DIAMETER (MICRONS) = 176/PSI

L-1443 300/  $\beta = 1$   
Same as L-1442 except  
fired 2 hrs at 1600°  
66.5 cu ft<sup>3</sup> Density  
2.0 g/mm crushed  
0.37 cu/g pore volume > 29 Å°  
2000 Å° Av Pore Diameter

(CONTACT ANGLE = 130°)



[XRD] 1.  $ZnTe_2O_4$  ( $\sim 67\%$ ) mes  $32/\text{A}^\circ$   
 2.  $\alpha Te_2O_3$  ( $\sim 33\%$ ) mes  $> 2000/\text{A}^\circ$   
 3.  $ZnAl_2O_4$  mes  $80\text{A}^\circ$

$25.8 \text{ m}^2/\text{g}$  Surface Area

POROSITY DETERMINATION


SAMPLE 11.0 ml Penetrant EXP 5158

SAMPLE WEIGHT \_\_\_\_\_ NORMALIZED TO 1 gram

DATE 2/4/62

EQUIVALENT PORE DIAMETER (MICRONS) =  $175/\text{PSI}$

L-1444  $ZnO/\beta$   $\gamma = 1.6$   
 with  $\sim 0\% Al_2O_3$   
 Fired 2 hrs at  $1500^\circ\text{C}$   
 $71.4/\text{ft}^3$  Density  
 $1.72/\text{mm}$  Crush  
 $0.22 \text{ cc/g}$  Por Volume  $> 2.9\text{A}^\circ$   
 $1095\text{A}^\circ$  Av Pore Diameter  
 (CONTACT ANGLE =  $130^\circ$ )



**XRD**

1.  $\beta\text{-Fe}_2\text{O}_4$  ( $\sim 85\%$ ) mes  $776\text{A}^{\circ}$
2.  $\alpha\text{-Fe}_2\text{O}_3$  ( $\sim 5\%$ ) mes  $> 2000\text{A}^{\circ}$
3. ZnO (?) —

$9.6 \text{ m}^2/\text{g}$  Surface Area

POROSITY DETERMINATION

SAMPLE U.S. Penetrometer EKD 559

SAMPLE WEIGHT \_\_\_\_\_ NORMALIZED TO 1 gram


DATE 5/14/82

EQUIVALENT PORE DIAMETER (MICRONS) = 176/PSI

(CONTACT ANGLE =  $130^{\circ}$ )

$1400\text{A}^{\circ}$  Av Pore Diameter

L-1445.  $\beta\text{-Fe}_2\text{O}_3 = 1$   
 Fired 2 hrs at  $1100^{\circ}\text{F}$   
 $66.64/\text{ft}^3$  Density  
 $0.70 \pm \text{mm}$  Cracks  
 $0.32 \text{ cc/g}$  Pore Volume  $> 25$ .



TEST SUMMARY SHEET

TEST NO. : 080  
 DATE STARTED : 6/2/82  
 DATE ENDED : 6/2/82  
 TOTAL HOURS : 2.75 HRS  
 TYPE : SULFIDATION

PURPOSE  
 FIRST SULFIDATION OF UNITED CATALYST L-1442

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE  
 50 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (ML/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S: 330 PPM AT 15 MINUTES, DECREASING TO 74 PPM.

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

1. SUSPECT IRON SULFIDES IN SORBENT DUE TO IMPURITY IN IRON OXIDE USED BY UNITED CATALYSTS.

TEST SUMMARY SHEET

TEST NO. : 081  
 DATE STARTED : 6/04/82  
 DATE ENDED : 6/7/82  
 TOTAL HOURS : 8.25 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 080

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 15.4 PERCENT MAX, 350 PPM AT END OF TEST  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFM	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

CONCLUSIONS

1. SORBENT REGENERATED.

TEST SUMMARY SHEET

TEST NO. : 082  
 DATE STARTED : 6/14/82  
 DATE ENDED : 6/14/82  
 TOTAL HOURS : 3.5 HRS  
 TYPE : SULFIDATION

PURPOSE  
 SECOND SULFIDATION OF UNITED CATALYST L-1442

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE)/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (PFIZER CX-6139)  
                   50 MOLES ZINC OXIDE (FRENCH PROCESS A2065)  
                   AMERICAN SMELTING & REFINING CO.  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR (%):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: (DETECTOR TUBE)

EXIT H2S: 10.25 PPM AVG FOR 2 HOURS.

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>: 200 PPM INITIALLY 0 AFTER 45 MINUTES

SPACE VELOCITY: 2000 HOURLY

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

1. PERFORMANCE SIMILAR TO METC ZINC FERRITE.

TEST SUMMARY SHEET

TEST NO. : DB3  
 DATE STARTED : 6/15/82  
 DATE ENDED : 6/16/82  
 TOTAL HOURS : 6 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST DB2

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE (PFIZER CX-6139)  
 50.0 MOLES ZINC OXIDE (FRENCH PROCESS A2066)  
 AMERICAN SMELTING & REFINING CO.  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 16.4 PERCENT MAX. 8000 PPM AT END OF TEST.  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

REMARKS

CONCLUSIONS

1. SORBENT REGENERATED.

TEST SUMMARY SHEET

TEST NO. : 084  
 DATE STARTED : 6/17/82  
 DATE ENDED : 6/17/82  
 TOTAL HOURS : 3.25 HRS  
 TYPE : SULFIDATION

PURPOSE  
 SULFIDATION OF UNITED CATALYST L-1442  
 AT 1200 F.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 CM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (PFIZER CX-6139)  
 50 MOLES ZINC OXIDE (FRENCH PROCESS A2066)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1200 F

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: 10 PPM AVG FOR 1.75 HOURS!!

SPACE VELOCITY: 2000 HOURLY

BREAKTHROUGH AT 2.25 HOURS WITH 27 PPM

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

1. REASONABLE PERFORMANCE AT 1200 F. SLIGHTLY FASTER BREAKTHROUGH AS COMPARED TO SULFIDATION AT 1000F ( AS EXPECTED).

TEST SUMMARY SHEET

TEST NO. : 085  
 DATE STARTED : 6/18/82  
 DATE ENDED : 6/21/82  
 TOTAL HOURS : 10 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 084

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE (PFIZER CX-6139)  
 50.0 MOLES ZINC OXIDE (FRENCH PROCESS A2066)  
 AMERICAN SMELTING & REFINING CO.  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 8.4 PERCENT MAX ,925 PPM AT END OF TEST  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%  
 AIR 5.88 SCFH 50%

REMARKS

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. SORBENT REGENERATED.

TEST SUMMARY SHEET

TEST NO. : 086  
 DATE STARTED : 6/22/82  
 DATE ENDED : 6/22/82  
 TOTAL HOURS : 3.6 HRS  
 TYPE : SULFIDATION

PURPOSE  
 SECOND SULFIDATION OF UNITED CATALYST L-1442  
 AT 1200 F.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50 MOLES IRON OXIDE (PFIZER CX-5139)  
 50 MOLES ZINC OXIDE (FRENCH PROCESS A2066)  
 AMERICAN SMELTING & REFINING CO.  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : 2 (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M2/G):  
 DENSITY (G/CC):  
 PORE VOLUME (M3/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1200 F

DATA: (DETECTOR TUBE)

EXIT H2S: 9 PPM FOR 1 HOUR

PRESSURE : AMBIENT

BREAKTHROUGH WITH 200 PPM AT 2 HOURS

SPACE VELOCITY: 2000 HOURLY

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	0.9963 SCFH	2.7%
H2O	3.872CC/MIN	27.66%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	10.34 SCFH	28.1 %

REMARKS

CONCLUSIONS

- SECOND SULFIDATION RESULTED IN MORE RAPID BREAKTHROUGH  
 MAY BE AN INDICATION OF SINTERING CAUSING A DROP OFF  
 IN PERFORMANCE.

TEST SUMMARY SHEET

TEST NO. : 087  
 DATE STARTED : 6/23/82  
 DATE ENDED : 6/24/82  
 TOTAL HOURS : 7.25 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST C36

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 600 HOURLY

DATA: (DETECTOR TUBE)  
 EXIT H2S:  
 EXIT SO2: 6.6 % MAX 1200 PPM AT END  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S  
 H2O 2.23 CC/MIN 50%  
 AIR 5.88 SCFH 50%

REMARKS

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. SORBENT REGENERATED.

TEST SUMMARY SHEET

TEST NO. : 088  
 DATE STARTED : 6/25/82  
 DATE ENDED : 6/25/82  
 TOTAL HOURS : 1.75 HRS  
 TYPE : SULFIDATION

PURPOSE

THIRD SULFIDATION OF UNITED CATALYST L-1442  
 AT 1200 F.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/643 GM  
 SORBENT NO. : L-1442  
 SORBENT COMPOSITION: 50 MOLE% IRON OXIDE  
 50 MOLE% ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC) :  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1200 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 2000 HOURLY

DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 10 PPM AT 15 MINUTES

BREAKTHROUGH AT 1.3 HOURS WITH 520 PPM  
 EXIT SO<sub>2</sub>: 100 PPM AT 15 MINUTES DOWN TO 1 PPM AFTER  
 1.5 HRS.

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68%
CO	4.3 SCFH	11.91%
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1%

REMARKS

CONCLUSIONS

1. LOSS OF PERFORMANCE OBSERVED AS COMPARED TO  
 FIRST TWO SULFIDATIONS. SUSPECT LOSS DUE TO  
 SINTERING AT 1200 F.

TEST SUMMARY SHEET

TEST NO. : 089  
 DATE STARTED : 6/29/82  
 DATE ENDED : 6/29/82  
 TOTAL HOURS : 2 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE THE CAPABILITY OF NICKEL TO REDUCE H<sub>2</sub>S LEVEL BELOW 1 PPM.

SORBENT TYPE/WEIGHT: (ZINC OXIDE)/500 GM  
 (HYDROGENATION CATALYST)/333 GM  
 SORBENT NO. : G-72D ZINC OXIDE  
 G-65RS HYDROGENATION CATALYST  
 SORBENT COMPOSITION: 90 WEIGHT % ZNO (G-72D)  
 27 WEIGHT % NI (G65RS)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: ( DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: 16 PPM INITIALLY

SPACE VELOCITY: 1000 HOURLY FOR ZNO AND G-65RS (APPROX)

EXIT SO<sub>2</sub>: UNDETECTABLE

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	0.9963 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

REMARKS

1. BOTH SORBENTS USED ARE MANUFACTURED BY UNITED CATALYSTS.

CONCLUSIONS

1. SULFUR LEVELS WERE NOT REDUCED BELOW 1 PPM.  
 SUSPECT POSSIBILITY OF SULFUR IN THE NICKEL CATALYST AND/OR SULFUR PICKUP FROM REACTOR WALLS.

TEST SUMMARY SHEET

TEST NO. : 090  
 DATE STARTED : 7/2/82  
 DATE ENDED : 7/2/82  
 TOTAL HOURS : 10 HRS  
 TYPE : SULFIDATION

PURPOSE

DETERMINE IF DESULFIDING OF NICKEL CATALYST OCCURS IN A LURG! GAS WITHOUT H<sub>2</sub>S.

SORBENT TYPE/WEIGHT: (ZINC OXIDE )/500 GM  
 (HYDROGENATION CATALYST)/500 GM  
 SORBENT NO. : G-720 ZINC OXIDE  
 G-65RS HYDROGENATION CATALYST  
 SORBENT COMPOSITION: 90 WEIGHT % ZNO (G-720)  
 27 WEIGHT % NI (G65RS)  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : % (GM SULFUR/GM FRESH SORBENT)

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR (%W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC) :  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1000 HOURLY FOR ZNO AND G-65RS (APPROX)

DATA: ( DETECTOR TUBE)

EXIT H<sub>2</sub>S: 30-40 PPM  
 EXIT SO<sub>2</sub>: UNDETECTABLE  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

	FLOW RATE	MOLES%
H <sub>2</sub> S		
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	11.33 SCFH	30.8 %

REMARKS

1. BOTH SORBENTS USED ARE MANUFACTURED BY UNITED CATALYSTS.

CONCLUSIONS

1. DESULFIDING OF NICKEL CATALYST AND/OR REACTOR WALLS OCCURRED. SUB PPM LEVEL TESTING WILL REQUIRE DEDICATED "LOW SULFUR" SYSTEM, OR QUARTZ REACTOR TO ELIMINATE POSSIBILITY OF SULFUR PICK UP FROM REACTOR WALLS

TEST SUMMARY SHEET

TEST NO. : 091  
 DATE STARTED : 7/20/82  
 DATE ENDED : 7/20/82  
 TOTAL HOURS : 5.5 HRS  
 TYPE : REGENERATION

PURPOSE

REGENERATION OF EMPTY REACTOR PRIOR TO EMPTY REACTOR TEST.

SORBENT TYPE/WEIGHT: NONE  
 SORBENT NO.:  
 SORBENT COMPOSITION:

ANALYSIS:

BEFORE AFTER

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: 8000 PPM MAX, 360 PPM AT END OF TEST.

PRESSURE : AMBIENT

EXIT S2:

SPACE VELOCITY:

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%

REMARKS

AIR 5.68 SCFM 50%

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. REACTOR WALLS DESULFIDED.

TEST SUMMARY SHEET

TEST NO. : 092  
 DATE STARTED : 7/21/82  
 DATE ENDED : 7/21/82  
 TOTAL HOURS : 5.5 HRS  
 TYPE : SULFIDATION

PURPOSE  
 SULFIDE EMPTY REACTOR

SORBENT TYPE/WEIGHT: NONE  
 SORBENT NO. :

ANALYSIS:  
 BEFORE      AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 POLE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT :  
 SULFUR LOADING : 3.524 GM S2

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: ( DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H2S: 200 PPM INITIALLY, BREAKTHROUGH

SPACE VELOCITY:

COMPLETED IN 4.5 HOURS.  
 EXIT SO2: 14 PPM INITIALLY, DECREASED TO UNDETECTABLE  
 AFTER 1.5 HOURS.

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	0.036 SCFH	0.1 %
H2O	3.872CC/MIN	27.65%
AIR		
CO2	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	11.3 SCFH	30.7 %

REMARKS

1. 48 % OF INLET H2S PICKED UP BY REACTOR WALL.
2. H2S PICKED UP BY REACTOR WALLS EQUIVALENT TO 3.524 GM S2.

CONCLUSIONS

1. SIGNIFICANT SULFUR PICK-UP BY STAINLESS STEEL REACTOR.

TEST SUMMARY SHEET

TEST NO. : 093  
 DATE STARTED : 7/22/82  
 DATE ENDED : 7/22/82  
 TOTAL HOURS : 4.5 HRS  
 TYPE :

PURPOSE  
 DETERMINE H<sub>2</sub>S LEACHING FROM SULFIDED EMPTY REACTOR

SORBENT TYPE/WEIGHT:  
 SORBENT NO. :

ANALYSIS: BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (CM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H<sub>2</sub>S: 335 PPM AVERAGE

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S		
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	11.3 SCFH	30.7 %

REMARKS

CONCLUSIONS

1. H<sub>2</sub>S LEACHING APPEARS TO BE NEAR EQUILIBRIUM LEVEL  
 335 PPM AVERAGE.

TEST SUMMARY SHEET

TEST NO. : 094  
 DATE STARTED : 7/23/82  
 DATE ENDED : 7/23/82  
 TOTAL HOURS : 5.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF EMPTY REACTOR TEST.

SORBENT TYPE/WEIGHT: NONE  
 SORBENT NO. :  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: UNDETECTABLE

PRESSURE : AMBIENT

EXIT SO2: 7 % MAX, 70 PPM AT END OF TEST

SPACE VELOCITY:

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%

REMARKS

AIR 5.88 SCFH 50%

CO2

CO

H2

CH4

CONCLUSIONS

N2

1. REACTOR DESULFIDED.

TEST SUMMARY SHEET

TEST NO. : 095  
 DATE STARTED : 7/26/82  
 DATE ENDED : 7/26/82  
 TOTAL HOURS : 5.75 HRS  
 TYPE :

PURPOSE  
 DETERMINE H<sub>2</sub>S LEACHING FROM REGENERATED EMPTY REACTOR

SORBENT TYPE/WEIGHT:  
 SORBENT NO. :

ANALYSIS:  
 BEFORE      AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR LOADING :

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H<sub>2</sub>S: 150 - 200 PPM INITIALLY THEN DECREASED TO  
 30 PPM

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE      MOLES

H <sub>2</sub> S		
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68%
CO	4.3 SCFH	11.91%
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	11.3 SCFH	30.7%

REMARKS

CONCLUSIONS

1. H<sub>2</sub>S LEACHES FROM REACTOR WALLS EVEN AFTER REGENERATION.
2. REGENERATION APPARENTLY DOES NOT DESULFIDE REACTOR COMPLETELY.

TEST SUMMARY SHEET

TEST NO. : 096  
 DATE STARTED : 8/3/82  
 DATE ENDED : 8/3/82  
 TOTAL HOURS : 50 HRS  
 TYPE :

PURPOSE

RUN SULFIDATION OF "HALF REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/322 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

SURFACE AREA (M<sup>2</sup>/G):

DENSITY (G/CC) :

PORE VOLUME (MM<sup>3</sup>/G):

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: 0 INITIALLY  
 10 PPM BREAKTHROUGH AFTER 22 HOURS

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 787 HOURLY  
 LINEAR VELOCITY: 5 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE MOLES

H<sub>2</sub>S 0.0505 SCFH 0.5

H<sub>2</sub>O

REMARKS

AIR

1. INLET H<sub>2</sub>S FLOW WAS NOT KEPT CONSTANT.

CO<sub>2</sub> 1.17 SCFH 9.68 :

CO 1.44 SCFH 11.91 :

H<sub>2</sub> 2.07 SCFH 17.12%

CH<sub>4</sub> 0.35 SCFH 2.91%

N<sub>2</sub> 7.00 SCFH 57.88 :

CONCLUSIONS

1. SPACE VELOCITY TOO LOW FOR SHORT TERM TESTING.

TOTAL FLOW RATE: 12.1 SCFH

TEST SUMMARY SHEET

TEST NO. : 097  
 DATE STARTED : 8/17/82  
 DATE ENDED : 8/17/82  
 TOTAL HOURS : 6.5 HRS  
 TYPE :

PURPOSE

RUN SULFIDATION OF "1/4 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROED MOUEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/160 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: 6780 HOURLY FOR 4 INCH BED  
 LINEAR VELOCITY: 25 CM/SEC

EXIT S2:

EXIT H2:

FLOW RATE MOLE%

H2S 0.90 SCFH 1.5

H2O

REMARKS

AIR

CO2 5.8 SCFH 9.68 %

CONCLUSIONS

CO 7.2 SCFH 11.91 %

1. 4 INCH BED IS TOO SHORT. POSSIBLE CHANNELING CAUSING HIGH INITIAL H2S.

H2 10.27 SCFH 17.12%

CH4 1.74 SCFH 2.91%

2. TEST WAS COMPLETED IN ONE SHIFT.

N2 34.120 SCFH 56.88 %

TEST SUMMARY SHEET

TEST NO. : 098  
 DATE STARTED : 8/24/82  
 DATE ENDED : 8/24/82  
 TOTAL HOURS : 12 HRS  
 TYPE : SULFIDATION

PURPOSE

RUN SULFIDATION OF "1/4 REACTOR" FOR COMPLETE BREAKTHROUGH  
 FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/160 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

SURFACE AREA (M2/G):

DENSITY (G/CC) :

PORE VOLUME (MM3/G):

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: 480 PPM AFTER 15 MINUTES

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: HOURLY  
 LINEAR VELOCITY: CM/SEC FOR 4 INCH BED

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S 0.60 SCFH 1.5

H2O

REMARKS

AIR

CO2 3.6 SCFH 9.68 %

CO 4.4 SCFH 11.91 %

H2 6.3 SCFH 17.12 %

CH4 1.07 SCFH 2.91 %

N2 21.0 SCFH 56.88 %

CONCLUSIONS

1. LOWERED SPACE VELOCITY LOWERED INITIAL H2S SLIGHTLY BUT NOT ENOUGH. RUN TIME IS 12 HOURS WHICH IS TOO LONG FOR ONE SHIFT OPERATION. POSSIBLE CHANNELING STILL A PROBLEM.

TOTAL FLOW RATE: SCFH

TEST SUMMARY SHEET

TEST NO. : 099  
 DATE STARTED : 8/26/82  
 DATE ENDED : 8/26/82  
 TOTAL HOURS : 11 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF EMPTY REACTOR

SORBENT TYPE/WEIGHT: L-1443 ZINC FERRITE  
 SORBENT NO.: L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT:  
 SULFUR REMOVED :

OPERATING CONDITIONS

TEMPERATURE: 1000 F

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H2S:

SPACE VELOCITY:

EXIT SO2: 11.5 % MAX , 292 PPM AT END OF TEST

EXIT S2:

EXIT H2:

FLOW RATE MOLES

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%

REMARKS

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. REACTOR DESULFIDED

TEST SUMMARY SHEET

TEST NO. : 100  
 DATE STARTED : 8/30/82  
 DATE ENDED : 8/30/82  
 TOTAL HOURS : 3.6 HRS  
 TYPE : REDUCTION

PURPOSE

RUN REDUCTION OF "1/4 REACTOR" TO DETERMINE LEVEL OF  
 H2S LEACHING FOR SCRUBBING MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/160 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: 4 PPM AVG

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: HOURLY FOR 4 INCH BED  
 LINEAR VELOCITY: CM/SEC

EXIT S2:

FLOW RATE MOLES

EXIT H2:

H2S

H2O

AIR

CO2 3.8 SCFH 10.39 %

REMARKS

CO 4.4 SCFH 12.03 %

CONCLUSIONS

H2 6.3 SCFH 17.22%

1. 4 PPM H2S OBTAINED DURING REDUCTION

CH4 1.07 SCFH 2.92%

N2 21.0 SCFH 57.42 %

TOTAL FLOW RATE: 35.57 SCFH

## TEST SUMMARY SHEET

TEST NO. : 101  
 DATE STARTED : 9/1/82  
 DATE ENDED : 9/1/82  
 TOTAL HOURS : 4.75 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/4 REACTOR" FOR COMPLETE BREAKTHROUGH  
 FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/160 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M2/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM3/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT :

SULFUR LOADING :

## OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S: INITIAL H2S 5750 PPM

PRESSURE : AMBIENT

EXIT SO2:

SPACE VELOCITY: 5500 HOURLY FOR 4 INCH BED  
 LINEAR VELOCITY: 15.5 CM/SEC

EXIT S2:

EXIT H2:

## FLOW RATE MOLES

H2S 1.2 SCFH 3.2

H2O

## REMARKS

AIR

CO2 3.6 SCFH 9.6 %

CO 4.4 SCFH 11.7 %

H2 6.3 SCFH 16.8 %

CH4 1.07 SCFH 2.8 %

N2 21.0 SCFH 55.9 %

## CONCLUSIONS

1. 3.5 INCH BED TOO SHORT. POSSIBLE CHANNELING.

TOTAL FLOW RATE: 37.57 SCFH

TEST SUMMARY SHEET

TEST NO. : 102  
 DATE STARTED : 9/3/82  
 DATE ENDED : 9/3/82  
 TOTAL HOURS : 5.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED :

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 984 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 31200 PPM MAX, 560 PPM AT END OF REGENERATION  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%

REMARKS

AIR 5.88 SCFH 50%

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. REACTOR WALLS DESULFIDEO.

TEST SUMMARY SHEET

TEST NO. : 103  
 DATE STARTED : 9/10/82  
 DATE ENDED : 9/10/82  
 TOTAL HOURS : 4.4 HRS  
 TYPE : SULFIDATION

PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROOT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (M<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H<sub>2</sub>S: 4.5 ppm AFTER 10 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3242 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 16 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

FLOW RATE MOLES

H<sub>2</sub>S 2.4 SCFH 6.2

H<sub>2</sub>O

REMARKS

AIR

CONCLUSIONS

CO<sub>2</sub> 3.6 SCFH 9.3 %

1. COMPLETE BREAKTHROUGH CURVE COMPLETED IN ONE SHIFT WITH LOW INITIAL H<sub>2</sub>S.

CO 4.4 SCFH 11.3 %

H<sub>2</sub> 6.3 SCFH 16.25%

CH<sub>4</sub> 1.07 SCFH 2.75%

N<sub>2</sub> 21.0 SCFH 54.2 %

TOTAL FLOW RATE: 38.77 SCFH

TEST SUMMARY SHEET

TEST NO. : 104  
 DATE STARTED : 9/14/82  
 DATE ENDED : 9/14/82  
 TOTAL HOURS : 5.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 984 HOURLY

EXIT H2S:  
 EXIT SO2: MAX 3.3 PERCENT  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S

REMARKS

H2O 2.23 CC/MIN 50%

AIR 5.89 SCFH 50%

CO2

CO  
H2

CH4

CONCLUSIONS

N2

1. REACTOR DESULFIZED.

TEST SUMMARY SHEET

TEST NO. : 105  
 DATE STARTED : 9/16/82  
 DATE ENDED : 9/16/82  
 TOTAL HOURS : 5.33 HRS  
 TYPE : SULFIDATION

PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):

SURFACE AREA (M<sup>2</sup>/G):

DENSITY (G/CC) :

PORE VOLUME (MM<sup>3</sup>/G):

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE )

TEMPERATURE: 1000 F

EXIT H<sub>2</sub>S: 55 PPM AFTER 20 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED

EXIT S<sub>2</sub>:

LINEAR VELOCITY: 17.8 CM/SEC

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	2.4 SCFH	5.6
H <sub>2</sub> O	1.63 CC/MIN	10.0 %

REMARKS

AIR		
CO <sub>2</sub>	3.6 SCFH	8.4 %
CO	4.4 SCFH	10.2 %
H <sub>2</sub>	6.3 SCFH	14.6 %
CH <sub>4</sub>	1.07 SCFH	2.5 %
N <sub>2</sub>	21.0 SCFH	48.8 %

CONCLUSIONS

1. COMPLETE BREAKTHROUGH CURVE COMPLETED IN ONE SHIFT.  
 H<sub>2</sub>S LEVEL REASONABLY LOW INITIALLY.

TOTAL FLOW RATE: 43.0 SCFH

TEST SUMMARY SHEET

TEST NO. : 106  
 DATE STARTED : 9/20/82  
 DATE ENDED : 9/20/82  
 TOTAL HOURS : 6.0 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 994. HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 2.1 PERCENT MAX, 368 PPM AT D.O OF REGENERATION  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S  
 H2O 2.23 CC/MIN 50%  
 AIR 5.88 SCFH 50%

REMARKS

CO2

CO

H2

CH4

N2

CONCLUSIONS

1. REACTOR WALLS DESULFIDED.

TEST SUMMARY SHEET

TEST NO. : 107  
 DATE STARTED : 9/21/82  
 DATE ENDED : 9/21/82  
 TOTAL HOURS : 2.5 HRS  
 TYPE : SULFIDATION

PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH  
 FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (CM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

TEMPERATURE: 1200 F

DATA: (DETECTOR TUBE)

EXIT H<sub>2</sub>S: 16 PPM AFTER 15 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 17.8 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	2.4 SCFH	5.6
H <sub>2</sub> O	1.63 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	3.6 SCFH	8.4 %
CO	4.4 SCFH	10.2 %
H <sub>2</sub>	6.3 SCFH	14.6%
D <sub>2</sub>	1.07 SCFH	2.5%
N <sub>2</sub>	21.0 SCFH	48.0 %

REMARKS

CONCLUSIONS

1. BREAKTHROUGH CURVE AT 1200 F IS COMPLETED SOONER THAN AT 1000 F AS EXPECTED.

TOTAL FLOW RATE: 43.0 SCFH

TEST SUMMARY SHEET

TEST NO. : 108  
 DATE STARTED : 9/23/82  
 DATE ENDED : 9/23/82  
 TOTAL HOURS : 5.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAM  
 SORBENT NO. : L-1443

ANALYSIS: BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED:

OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 2.7 % MAX 560 PPM AT END OF RUN

SPACE VELOCITY: 984 HOURLY

EXIT S2:

EXIT H2:

FLOW RATE MOLE%

H2S

H2O 2.23 CC/MIN 50%

REMARKS

AIR 5.88 SCFH 50%

CO2 1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.

CO

CONCLUSIONS

H2

1. REACTOR WALLS DESULFIDED.

CH4

N2

TEST SUMMARY SHEET

TEST NO. : 109  
 DATE STARTED : 9/24/82  
 DATE ENDED : 9/24/82  
 TOTAL HOURS : 1.3 HRS  
 TYPE : SULFIDATION

PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROOT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC) :  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1200 F

EXIT H<sub>2</sub>S: 17.5 PPM INITIALLY, DECREASING TO 5.0 PPM AT 23 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3244 HOURLY FOR 7.1 INCH BED  
 LINEAR VELOCITY: 16 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	2.4 SCFH	6.2

H<sub>2</sub>O

AIR

REMARKS

CO <sub>2</sub>	3.6 SCFH	9.3 %
CO	4.4 SCFH	11.3 %
H <sub>2</sub>	6.3 SCFH	16.25%
CH <sub>4</sub>	1.07 SCFH	2.75%
N <sub>2</sub>	21.0 SCFH	54.2 %

CONCLUSIONS

1. SUSPECT SORBENT REDUCED TO FE AND CATALYZED METHANATION TO PRODUCE TEMPERATURE WAVE.

TOTAL FLOW RATE: 38.77 SCFH

TEST SUMMARY SHEET

TEST NO. : 110  
 DATE STARTED : 9/29/82  
 DATE ENDED : 9/29/82  
 TOTAL HOURS : 5.0 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF EMPTY REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED:

OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 984 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 2.25 % MAX 380 PPM AT END OF REGENERATION  
 EXIT S2:  
 EXIT H2:

FLOW RATE MOLES

H2S  
 H2O 2.23 CC/MIN 50%  
 AIR 5.88 SCFM 50%

REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS  
 TO DESULFIDE REACTOR WALLS.

CO  
 H2  
 CH4  
 N2

CONCLUSIONS

1. REACTOR WALLS DESULFIDED.

## TEST SUMMARY SHEET

TEST NO. : 111  
 DATE STARTED : 0/30/82  
 DATE ENDED : 0/30/82  
 TOTAL HOURS : 0.6 HRS  
 TYPE : SULFIDATION

## PURPOSE

REPEAT TEST FOR SULFIDATION OF " 1/2 REACTOR " TO OBTAIN COMPLETE BREAKTHROUGH CURVE FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

## ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR (W/W);  
 SURFACE AREA (M2/G);  
 DENSITY (G/CC);  
 PORE VOLUME (MM3/G);  
 MINERAL ANALYSIS;  
 ELEMENTAL ANALYSIS;

## OPERATING CONDITIONS

TEMPERATURE: 1200 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 3244 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 16 CM/SEC

## DATA: ( DETECTOR TUBE)

EXIT H2S: 075 PPM  
 EXIT SO2:  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLEX
H2S	2.4 SCFH	6.4
H2O		
AIR		
CO2	3.6 SCFH	0.68 %
CO	4.4 SCFH	11.01 %
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.91%
N2	21.0 SCFH	56.89 %

REMARKS  
 CHECK GAS COMPOSITIONS AT LEFT  
 TEMPERATURE WAVE DETECTED DURING SULFIDATION  
 TEST ABORTED.

## CONCLUSIONS

I. TEST ABORTED.

TOTAL FLOW RATE: 38.77 SCFH

## TEST SUMMARY SHEET

TEST NO. : 112  
 DATE STARTED : 10/7/82  
 DATE ENDED : 10/7/82  
 TOTAL HOURS : 5 HRS  
 TYPE : REGENERATION

SORBENT TYPE/WEIGHT: L-1443 ZINC FERRITE/320 GRAMS  
 SORBENT NO.: L-1443  
 SORBENT COMPOSITION:

SORBENT PELL T SIZE  
 PRETREATMENT  
 SULFUR REMOVED :

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY:

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: UP TO 9600 PPM  
 EXIT S2I:  
 EXIT H2:

## FLOW RATE MOLES

H2S  
 H2O 2.3 CC/MIN 50%  
 A 5. SCFH 50%

CO

H2

L 14

N2

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETE

## TEST SUMMARY SHEET

TEST NO. : 113  
 DATE STARTED : 10/8/82  
 DATE ENDED : 10/9/82  
 TOTAL HOURS : 0.41 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE      AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT :  
 SULFUR LOADING :

## OPERATING CONDITIONS

DATA: (DETECTOR TUBE)

TEMPERATURE: 1400 F

EXIT H<sub>2</sub>S: 0 PPM AFTER 5 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 17.0 CM/SEC

EXIT S<sub>2</sub>I

EXIT H<sub>2</sub>I

	FLOW RATE	MOLE%
H <sub>2</sub> S	2.4 SCFH	5.6
H <sub>2</sub> O	1.63 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	3.6 SCFH	8.4 %
CO	4.4 SCFH	10.2 %
H <sub>2</sub>	6.3 SCFH	14.6 %
CH <sub>4</sub>	1.87 SCFH	2.5 %
N <sub>2</sub>	21.8 SCFH	48.8 %

## REMARKS

## CONCLUSIONS

1. SHORTER BREAKTHROUGH CURVE AS EXPECTED.

TOTAL FLOW RATE: 43.0 SCFH

## TEST SUMMARY SHEET

TEST NO. : 114  
 DATE STARTED : 10/13/82  
 DATE ENDED : 10/13/82  
 TOTAL HOURS : 6.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED :

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.84 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 10 22,500 PPM  
 EXIT S2:  
 EXIT H2:

-380-

## FLOW RATE MOLE%

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.00 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. : 115  
 DATE STARTED : 10/14/82  
 DATE ENDED : 10/14/82  
 TOTAL HOURS : 5.73 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE, WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W);  
 SURFACE AREA (M<sup>2</sup>/G);  
 DENSITY (G/CC);  
 PORE VOLUME (MM<sup>3</sup>/G);  
 MINERAL ANALYSIS;  
 ELEMENTAL ANALYSIS;

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

## OPERATING CONDITIONS

DATA: ( DETECTOR TUBE )

TEMPERATURE: 1620 F

EXIT H<sub>2</sub>S: UNDETECTABLE INITIALLY, 16 PPM AFTER 14 MINUTES.

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2026 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 10.0 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	1.34 SCFH	5.6
H <sub>2</sub> O	0.02 CC/MIN	10.8 X
AIR		
CO <sub>2</sub>	2.02 SCFH	8.4 X
CO	2.5 SCFH	18.2 X
H <sub>2</sub>	3.5 SCFH	14.6 X
CH <sub>4</sub>	0.60 SCFH	2.5 X
N <sub>2</sub>	11.8 SCFH	48.8 X

## REMARKS

I. EXPECTED COMPLETION OF BREAKTHROUGH CURVE IS 7 HRS.

## CONCLUSIONS

I. COMPLETED BREAKTHROUGH CURVE AT 1620 F .

TOTAL FLOW RATE: 24.2 SCFH

## TEST SUMMARY SHEET

TEST NO. : 116  
 DATE STARTED : 10/10/82  
 DATE ENDED : 10/10/82  
 TOTAL HOURS : 6.16 HRS  
 TYPE : REGENERATION

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRE TREATMENT :  
 SULFUR REMOVED :

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.84 HOURLY

DATA: (DETECTOR TUBE)  
 EXIT H2S:  
 EXIT SO2: TO 10230 PPM  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLE%
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.00 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. : 117  
 DATE STARTED : 10/26/82  
 DATE ENDED : 10/26/82  
 TOTAL HOURS : 2.25 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHROEDER MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/328 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT :  
 SULFUR LOADING :

## OPERATING CONDITIONS

TEMPERATURE: 1200 F

DATA: (DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: UNDETECTABLE INITIALLY, 13 PPM AFTER 25 MINUTES.

SPACE VELOCITY: 2026 HOURLY FOR 7 INCH BED

EXIT SO<sub>2</sub>:

LINEAR VELOCITY: 10.0 CM/SEC.

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	1.34 SCFH	5.6
H <sub>2</sub> O	0.02 CC/MIN	10.0 *
AIR		
CO <sub>2</sub>	2.02 SCFH	8.4 *
CO	2.5 SCFH	10.2 *
H <sub>2</sub>	3.5 SCFH	14.6%
CH <sub>4</sub>	0.60 SCFH	2.5%
N <sub>2</sub>	11.8 SCFH	49.8 *

## REMARKS

1. EXPECTED COMPLETION OF BREAKTHROUGH CURVE IS 7 HRS.

## CONCLUSIONS

1. COMPLETED BREAKTHROUGH CURVE AT 1200 F.

TOTAL FLOW RATE: 1.2 SCFH

## TEST SUMMARY SHEET

TEST NO. : 118  
 DATE STARTED : 10/22/62  
 DATE ENDED : 10/22/62  
 TOTAL HOURS : 5.5 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.84 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: TO 10,000 PPM  
 EXIT S2:  
 EXIT H2:

	FL	RATE	MOLES
H2			
H2O	2.23	CC/MIN	50%
AIR	5.88	SCFH	50%
CO2			
CO			
H2			
CH4			
N2			

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. :  
 DATE STARTED : 10/26/82  
 DATE ENDED : 10/25/82  
 TOTAL HOURS : 0.4 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO.: L-1443

## ANALYSIS:

BEFORE      AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLE SIZE:  
 PRETREATMENT:  
 SULFUR LOADIN :

## OPERATING CONDITIONS

TEMPERATURE: 1400 F

DATA: ( DETECTOR TUBE)

EXIT H2S: UNDETECTABLE INITIALLY, 23 PPM AFTER 10 MINUTES.

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2026 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 18.0 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
H <sub>2</sub> S	1.34 SCFH	5.6
H <sub>2</sub> O	0.02 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	2.82 SCFH	8.4 %
CO	2.5 SCFH	10.2 %
H <sub>2</sub>	3.5 SCFH	14.6%
CH <sub>4</sub>	0.68 SCFH	2.5%
N <sub>2</sub>	11.8 SCFH	48.8 %

## REMARKS

- EXPECTED COMPLETION OF BREAKTHROUGH CURVE IS LESS THAN 3 HOURS.

## CONCLUSIONS

- COMPLETED BREAKTHROUGH CURVE AT 1400 F.

TOTAL FLOW RATE: 24.2 SCFH

## TEST SUMMARY SHEET

TEST NO. : 128  
 DATE STARTED : 10/25/82  
 DATE ENDED : 10/25/82  
 TOTAL HOURS : 3.25 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1029 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.04 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: TO 14,000 PPM  
 EXIT S2I:  
 EXIT H2:

## FLOW RATE MOLES

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.08 SCFH	50%

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. : 121  
 DATE STARTED : 10/28/82  
 DATE ENDED : 10/28/82  
 TOTAL HOURS : 2.36 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SOLVENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

## SORBENT COMPOSITION:

TOTAL SULFUR (W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC) :  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## SORBENT PELLET SIZE:

PRETREATMENT :  
 SULFUR LOADING :

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 17.8 CM/SEC

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 1100 PPM INITIALLY

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	1.34 SCFH	3.1
H <sub>2</sub> O	1.63 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	3.6 SCFH	8.4 %
CO	4.4 SCFH	10.2 %
H <sub>2</sub>	6.3 SCFH	14.6%
CH <sub>4</sub>	1.07 SCFH	2.5%
N <sub>2</sub>	22.0 SCFH	48.8 %

## REMARKS

## CONCLUSIONS

1. COMPLETE BREAKTHROUGH CURVE COMPLETED IN ONE SHIFT.  
 H<sub>2</sub>S LEVEL ABOVE EQUILIBRIUM AT THIS LINEAR VELOCITY.

TOTAL FLOW RATE: 43.0 SCFH

## TEST SUMMARY SHEET

TEST NO. : 122  
 DATE STARTED : 11/03/82  
 DATE ENDED : 11/03/82  
 TOTAL HOURS : 3.75 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED :

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.84 HOURLY

DATA: (DETECTOR TUBE)  
 EXIT H2S:  
 EXIT SO2: TO 17000 PPM  
 EXIT S2:  
 EXIT H2:

## FLOW RATE MOLES

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.08 SCFM	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. : 123  
 DATE STARTED : 11/2/82  
 DATE ENDED : 11/2/82  
 TOTAL HOURS : 2.3 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH  
 FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:

PRETREATMENT :

SULFUR LOADING :

## OPERATING CONDITIONS

TEMPERATURE: 1200 F

DATA: ( DETECTOR TUBE)

PRESSURE : AMBIENT

EXIT H<sub>2</sub>S: UNDETECTABLE INITIALLY, 4 PPM AFTER 25 MINUTES

SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 17.0 CM/SEC

EXIT SO<sub>2</sub>:

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

	FLOW RATE	MOLES
--	-----------	-------

H <sub>2</sub> S	1.34 SCFH	3.1
------------------	-----------	-----

H <sub>2</sub> O	1.63 CC/MIN	10.0 %
------------------	-------------	--------

AIR

CO <sub>2</sub>	3.1 SCFH	8.4 %
-----------------	----------	-------

CO	4.4 SCFH	10.2 %
----	----------	--------

H <sub>2</sub>	6.3 SCFH	14.6 %
----------------	----------	--------

CH <sub>4</sub>	1.87 SCFH	2.5 %
-----------------	-----------	-------

N <sub>2</sub>	22.0 SCFH	48.8 %
----------------	-----------	--------

## REMARKS

## CONCLUSIONS

1. BREAKTHROUGH CURVE AT 1200 F COMPLETED.

TOTAL FLOW RATE: 43.0 SCFH

## TEST SUMMARY SHEET

TEST NO. : 124  
 DATE STARTED : 11/08/82  
 DATE ENDED : 11/08/82  
 TOTAL HOURS : 4.28 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO. : L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 984 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: TO 36,000 PPM  
 EXIT S2:  
 EXIT H2I

## FLOW RATE MOLE%

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.00 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

## CONCLUSIONS

1. REGENERATION COMP\_ETED.

## TEST SUMMARY SHEET

TEST NO. : 126  
 DATE STARTED : 11/8/82  
 DATE ENDED : 11/9/82  
 TOTAL HOURS : 8.29 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" FOR COMPLETE BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W);  
 SURFACE AREA (M<sup>2</sup>/G);  
 DENSITY (G/CC);  
 PORE VOLUME (MM<sup>3</sup>/G);  
 MINERAL ANALYSIS;  
 ELEMENTAL ANALYSIS;

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

## OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 1400 F

EXIT H<sub>2</sub>S: UNDETECTABLE INITIALLY, 10 PPM AFTER 7 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 3600 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 17.0 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

-391-

	FLOW RATE	MOLE%
H <sub>2</sub> S	1.34 SCFH	3.1
H <sub>2</sub> O	1.63 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	3.6 SCFH	8.4 %
CO	4.4 SCFH	10.2 %
H <sub>2</sub>	6.3 SCFH	14.6%
CH <sub>4</sub>	1.87 SCFH	2.5%
N <sub>2</sub>	22.0 SCFH	48.8 %

## REMARKS

## CONCLUSIONS

1. BREAKTHROUGH CURVE AT 1400 F COMPLETED.

TOTAL FLOW RATE: 43.0 SCFH

## TEST SUMMARY SHEET

TEST NO. : 126  
 DATE STARTED : 11/18/82  
 DATE ENDED : 11/18/82  
 TOTAL HOURS : 4 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF FRESHLY LOADED REACTOR

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GRAMS  
 SORBENT NO.: L-1443  
 SORBENT COMPOSITION:

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR REMOVED :

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 0.84 HOURLY

DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: TO 17,000 PPM  
 EXIT S2:  
 EXIT H2:

-392-

## FLOW RATE MOLES

H2S		
H2O	2.23 CC/MIN	50%
AIR	5.88 SCFH	50%
CO2		
CO		

## REMARKS

1. FRESH BATCH OF SORBENT LOADED. REGENERATION IS TO DESULFIDE REACTOR WALLS.
- 2.

CH4  
 N2

## CONCLUSIONS

1. REGENERATION COMPLETED.

## TEST SUMMARY SHEET

TEST NO. : 127  
 DATE STARTED : 11/22/82  
 DATE ENDED : 11/22/82  
 TOTAL HOURS : 1.08 HRS  
 TYPE : SULFIDATION

## PURPOSE

RUN SULFIDATION OF "1/2 REACTOR" UNTIL BEGINNING OF BREAKTHROUGH FOR SCHRODT MODEL.

SORBENT TYPE/WEIGHT: UNITED CATALYSTS ZINC FERRITE/320 GM  
 SORBENT NO. : L-1443

## ANALYSIS:

BEFORE      AFTER

SORBENT COMPOSITION:

TOTAL SULFUR (%W/W):  
 SURFACE AREA (M<sup>2</sup>/G):  
 DENSITY (G/CC):  
 PORE VOLUME (MM<sup>3</sup>/G):  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR LOADINGS:

## OPERATING CONDITIONS

DATA: ( DETECTOR TUBE)

TEMPERATURE: 100° F

EXIT H<sub>2</sub>S: UNDETECTABLE INITIALLY, 12 PPM AFTER 18 MINUTES

PRESSURE : AMBIENT

EXIT SO<sub>2</sub>:

SPACE VELOCITY: 2026 HOURLY FOR 7 INCH BED  
 LINEAR VELOCITY: 10.0 CM/SEC

EXIT S<sub>2</sub>:

EXIT H<sub>2</sub>:

-393-

	FLOW RATE	MOLES
H <sub>2</sub> S	1.34 SCFH	5.6
H <sub>2</sub> O	0.02 CC/MIN	10.0 %
AIR		
CO <sub>2</sub>	2.02 SCFH	8.4 %
CO	2.5 SCFH	10.2 %
H <sub>2</sub>	3.0 SCFH	14.6 %
CH <sub>4</sub>	0.60 SCFH	2.5 %
N <sub>2</sub>	11.0 SCFH	48.8 %

## REMARKS

1. RUN UNTIL EXIT H<sub>2</sub>S REACHES 50 PPM
2. AT END OF RUN SAMPLE SORBENT PELLETS AT FOUR LOCATIONS ALONG THE LENGTH OF THE REACTOR. LABEL EACH SAMPLE AND SEND A PORTION OF EACH SAMPLE TO :
  1. SEM/EDAX (JIM KING)
  3. SURFACE AREA/POROSITY (CHIDESTER)
  2. TOTAL SULFUR (ROMANOSKY)

## CONCLUSIONS

1. SAMPLES OF PELLETS TAKEN AT FOUR LOCATIONS IN THE BED AFTER 50 PPM BREAKTHROUGH AND ANALYZED FOR TOTAL SULFUR.

TOTAL FLOW RATE: 24.2 SCFH

# ZINC FERRITE SULFIDATION

TEST 105 L-1443 UNITED CATALYSTS





FIG. 117


# ZINC FERRITE SULFIDATION

TEST 107 L-1443 UNITED CATALYSTS



# ZINC FERRITE SULFIDATION


TEST 113 L-1443 UNITED CATALYSTS



P:

# ZINC FERRITE SULFIDATION

TEST 115 L-1443 UNITED CATALYSTS




PI

# ZINC FERRITE SULFIDATION

TESTS 105, 107, 113 L-1443 UNITED CATALYSTS


23-NOV-82 10:10:35




-866

# ZINC FERRITE SULFIDATION

TESTS 103, 105 L-1443 UNITED CATALYSTS




ZINC FERRITE SULFIDATION  
TEST 103 L-1443 UNITED CATALYSTS



P111-701

# ZINC FERRITE SULFIDATION


TESTS 103, 105 L-1443 UNITED CATALYSTS



P1

# ZINC FERRITE SULFIDATION


TESTS 105, 107 L-1443 UNITED CATALYSTS



P1


# ZINC FERRITE SULFIDATION

TESTS 105, 107, 113 L-1443 UNITED CATALYSTS



# ZINC FERRITE SULFIDATION

TEST 117 L-1443 UNITED CATALYSTS




# ZINC FERRITE SULFIDATION

TESTS 121, 123, 125 L-1443 UNITED CATALYSTS


18 - JAN - 84 10:14:50

-405-




# ZINC FERRITE SULFIDATION

TESTS 115, 117, 119 L-1443 UNITED CATALYSTS



ZINC FERRITE SULFIDATION  
TEST 127




18-JAN-84 10:22:42

-407-

16-JAN-84 10:24:47

-807-

## ZINC FERRITE SULFUR LOADING TEST 127




## POROSITY DETERMINATION

SAMPLE 415DF EKAGB3CSAMPLE WEIGHT NORMALIZED TO 1 gramDATE 7/15/78

L-1508

1.  $\text{ZnFe}_2\text{O}_4$  ( $\approx 92\%$ )  $\approx 2$
  2.  $\text{LaFe}_3$  ( $\approx 4\%$ )  $\approx 20$
  3.  $\text{ZnO}$  ( $\approx 4\%$ )  $\approx 2000$
- $6.1 \text{ m}^2/\text{g}$

(CONTACT ANGLE = 130)

EQUIVALENT PORE DIAMETER (MICRONS) =  $175/\text{PSI}$ 

## POROSITY DETERMINATION

SAMPLE UIDE EKD 5281SAMPLE WEIGHT NORMALIZED TO 1 gramDATE 7/26/62

L-1505


1.  $\gamma_{\text{Hg}} \text{Fe}_2\text{O}_4$  (96%)  $> 20000 \text{ psi}$
2.  $\gamma \text{Fe}_2\text{O}_3$  (~2%)  $> 20000 \text{ psi}$
3.  $\gamma \text{Hg} \cdot \text{Fe}_2\text{O}_3$  (2%)  $> 20000 \text{ psi}$

$$3.9 \text{ m}^2/\text{g}$$

(CONTACT ANGLE =  $130^\circ$ )

EQUIVALENT PORE DIAMETER (MICRONS) = 175/PSI

-410-



## POROSITY DETERMINATION

SAMPLE G64 Type C15DE EKO 7442


SAMPLE WEIGHT NORMALIZED TO 1 gram

DATE 11/23/82

SR-1C 189 (5 ft<sup>3</sup>)U.S.D.E.  
Morgantown W.Va.  
L-1504

(CONTACT ANGLE = 130°)

EQUIVALENT PORE DIAMETER (MICRONS) = 176/PSI



**TEST SUMMARY SHEET**

TEST NO.	128
DATE STARTED	2/23/83
DATE ENDED	2/23/83
TOTAL HOURS	2.25
TYPE	SULFIDATION HRS

**PURPOSE**  
SULFIDATION OF UNITED CATALYST L-1604  
AT 1200 F.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/1000 GM  
 SORBENT NO.: L-1584  
 SORBENT COMPOSITION:  
     50 MOLEX IRON OXIDE  
     50 MOLEX ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT:  
 SULFUR LOADING: % (GM SULFUR/GM FRESH SORBENT)

## OPERATING CONDITIONS

TEMPERATURE: 1200 F

PRESSURE : AMBIENT

SPACE VELOCITY: 1286 HOURLY

DATA: (DETECTOR TYPE)

EXIT H2S: 1-5-5 PPM FOR 1-75 HOURS

EXIT SD2: UNDETECTABLE

EXIT S2:

EXIT H2:

	FLOW RATE	MOLES
H2S	8.9963 SCFH	2.7%
H2O	3.8720E/MIN	27.66%
AIR		
CO2	3.6 SCFH	0.68
CO	4.3 SCFH	11.91
H2	6.3 SCFH	17.12%
CH4	1.07 SCFH	2.01%
N2	12.34 SCFH	28.1%

**REMARKS**

1. BAD TEMPERATURE CONTROLLER CAUSED OVERTEMPERATING OF SORBENT. TEST RUN ABORTED.
  - 2.

## CONCLUSIONS

- 1. RUN WILL HAVE TO BE REPEATED.**

## TEST SUMMARY SHEET

TEST NO. : 120  
 DATE STARTED : 3/1/83  
 DATE ENDED : 3/1/83  
 TOTAL HOURS : 6.25 HRS  
 TYPE : SULFIDATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/1800 GM  
 SORBENT NO. : L-1504  
 SORBENT COMPOSITION: 50 MOLEX IRON OXIDE  
                   50 MOLEX ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR LOADING : X (GM SULFUR/GM FRESH SORBENT)

## PURPOSE

SULFIDATION OF UNITED CATALYST L-1504  
 AT 1200 F.

## ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR (%V/V)  
 SURFACE AREA (M<sup>2</sup>/G)  
 DENSITY (G/CC)  
 PORE VOLUME (MM<sup>3</sup>/G)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS

## OPERATING CONDITIONS

TEMPERATURE: 1200 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 1286 HOURLY

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 0.5 - 1.6 PPM FOR 1.5 HRS  
 EXIT SO<sub>2</sub>: 0 PPM  
 EXIT S<sub>2</sub>:  
 EXIT H<sub>2</sub>:

	FLOW RATE	MOLE%
H <sub>2</sub> S	0.0063 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.91 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.91%
N <sub>2</sub>	10.34 SCFH	28.1 %

## REMARKS

1. SAMPLE CONDENSATE FOR ZINC IRON AND SULFATE ANALYSIS
2. THIS IS A REPEAT OF TEST 128. FRESH SORBENT LOADED.

## CONCLUSIONS

- 1.

## TEST SUMMARY SHEET

TEST NO. : 130  
 DATE STARTED : 3/04/83  
 DATE ENDED : 3/04/83  
 TOTAL HOURS : 16 HRS  
 TYPE : REGENERATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/1600 GM  
 SORBENT NO. : L-1504  
 SORBENT COMPOSITION: 50.0 MOLEX IRON OXIDE  
                   50.0 MOLEX ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 129

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY :  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 385 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: MAX OF 7.6 PERCENT 610 PPM AT END  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLEX
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.00 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS

1. AIR FLOW RATE INCREASED TO +6.6 SCFH AT 4.75 HRS.
2. DID NOT OBTAIN TYPICAL TEMP WAVE AT 5.00 AIR FLOW .

## CONCLUSIONS

1. REGENERATION COMPLETE.

## TEST SUMMARY SHEET

TEST NO.	131
DATE STARTED	3/11/83
DATE ENDED	3/11/83
TOTAL HOURS	6 HRS
TYPE	SULFIDATION

## PURPOSE

SULFIDATION OF UNITED CATALYST L-1504  
AT 1200 F A SECOND TIME.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/1800 GM  
SORBENT NO.: L-1504  
SORBENT COMPOSITION: 50 MOLEX IRON OXIDE  
50 MOLEX ZINC OXIDE  
SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
PRETREATMENT:  
SULFUR LOADING : 1 (GM SULFUR/GM FRESH SORBENT)

ANALYSIS: BEFORE AFTER  
TOTAL SULFUR (%W/W)  
SURFACE AREA (M<sup>2</sup>/G)  
DENSITY (G/CC)  
PORE VOLUME (MM<sup>3</sup>/G)  
MINERAL ANALYSIS  
ELEMENTAL ANALYSIS

## OPERATING CONDITIONS

TEMPERATURE: 1200 F  
PRESSURE : AMBIENT  
SPACE VELOCITY: 1266 HOURLY

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 5-13 PPM FOR 4.5 HOURS  
EXIT SO<sub>2</sub>: 17-2 PPM FOR 2.5 HOURS  
EXIT S<sub>2</sub>:  
EXIT H<sub>2</sub>:

	FLOW RATE	MOLEX
H <sub>2</sub> S	0.0063 SCFH	2.7%
H <sub>2</sub> O	3.872CC/MIN	27.66%
AIR		
CO <sub>2</sub>	3.6 SCFH	9.68 %
CO	4.3 SCFH	11.01 %
H <sub>2</sub>	6.3 SCFH	17.12%
CH <sub>4</sub>	1.07 SCFH	2.01%
N <sub>2</sub>	10.34 SCFH	28.1 %

## REMARKS

1. SAMPLE CONDENSATE FOR ZINC IRON AND SULFATE ANALYSIS
2. SECOND SULFIDATION ON THIS BATCH.

## CONCLUSIONS

1. EXIT H<sub>2</sub>S COMPOSITIONS SLIGHTLY ABOVE THOSE OF THE FIRST SULFIDATION, BUT BREAKTHROUGH TIME IS SIMILAR.

## TEST SUMMARY SHEET

TEST NO. : 132  
 DATE STARTED : 3/16/83  
 DATE ENDED : 3/15/83  
 TOTAL HOURS : 1.75 HRS  
 TYPE : REGENERATION

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/1020 GM  
 SORBENT NO. : L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
                   50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 PRETREATMENT :  
 SULFUR REMOVED :

PURPOSE  
 REGENERATION OF ZINC FERRITE PELLETS FROM TEST 131

ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR:  
 SURFACE AREA:  
 DENSITY:  
 PORE VOLUME:  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

TEMPERATURE: 1000 F  
 PRESSURE : AMBIENT  
 SPACE VELOCITY: 385 HOURLY

## DATA: (DETECTOR TUBE)

EXIT H2S:  
 EXIT SO2: 0 % MAX  
 EXIT S2:  
 EXIT H2:

	FLOW RATE	MOLES
H2S		
H2O	2.23 CC/MIN	50%
AIR	5.00 SCFH	50%
CO2		
CO		
H2		
CH4		
N2		

## REMARKS


1. STOP REGENERATION WHEN TEMP WAVE IS AT MID BED.
2. SAMPLE PELLETS BEFORE, AT, AND AFTER TEMP WAVE AND SEND TO JIM KING FOR ELECTRON MICROSCOPE ANALYSIS.

## CONCLUSIONS

1. REGENERATION STOPPED WHEN TEMP WAVE WAS AT MID-BED.


## ZINC FERRITE SULFIDATION

TESTS 129,131 ( L1504 )



## ZINC FERRITE SULFIDATION

TEST 129 ( L1504 )



## APPENDIX E

### Sidestream Testing - Gasifier Run 101

Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run 101

#### Introduction

Starting in 1980, laboratory-scale evaluation of developmental, regenerable solid sorbents to remove sulfur compounds from cool gas at high temperatures has been carried on at METC (1,2,3,4,5,6). Tests were performed, utilizing simulated gases, for sorbent screening and development, with the long-range objective of testing the most promising sorbents in a bench-size test unit at a somewhat larger scale in sidestreams of METC coal gasifiers. Initially, this would be in a sidestream of METC's 24 t/d fixed-bed gasifier and later, the ~ 2 t/d advanced fluid-bed gasifier.

The test unit was designed, and procurement of components practically completed during FY 82. During FY 83, the unit was assembled and installed in a location where it could be connected to either gasifier. Skid-mounting of the unit gives it portability should it be desired to remove it to another test site.

The design throughput of the sidestream test unit is an order of magnitude larger than that of the laboratory-scale unit. The bigger size of the sidestream test unit and the treating by it of an actual hot raw coal gas were expected to establish with much greater confidence the capability of sorbents under test to achieve the desired goal of removing sulfur compounds to low levels (1-10 ppm) of withstanding the effects of other contaminants and of being regenerable.

In particular, the sorbent, zinc ferrite, which showed promise in the laboratory-scale tests, was singled out for evaluation.

#### Design of Sidestream Test Unit

The process and instrument drawing of the sidestream test unit is shown in Figure 1. Figures 2 and 3 are perspective schematics which illustrate the operation of the unit in absorption and regeneration modes. Figure 4 is a photograph of the unit and its control panel installed at its test location. The detailed design basis was by Science Applications Inc. (4). Detailed mechanical engineering design was by Tech Engineering and Design of Morgantown and assembly, fabrication of subsidiary components and installation was by METC staff.

The principal component is a 6-inch diameter, 6-foot long reactor fabricated from Incoloy 800H by National Annealing Box Company and treated internally with aluminum (alvanized) by Alon Processing, Inc. It is designed for operation up to a pressure of 300 psig and a temperature of 1,800°F. The reactor, which has six thermocouples inserted along its length, is enclosed by a four-zone, clamshell type electrically heated furnace made by Mellen Company.

Coal gas and regeneration gas entering the reactor are heated by passage through helical coils located in two electrically heated cylindrical furnaces made by Thermcraft, Inc. Gases leaving the reactor are cooled by water-cooled condensers in two stages: the first to condense the higher boiling tars and the second to condense steam and remaining tars. On-off valves for the hot gases are of the sliding disc type made by Everlasting Valve Company. The valves and piping are of 316 stainless steel except for the 1½-inch diameter line from the fixed-bed gasifier which is of 309 stainless steel. A 1½-inch line of alonized 304 stainless steel from METC's advanced fluid-bed gasifier is presently at the engineering stage. The piping is electrically heated by Chromolox tubular heaters.

Cooled exiting gas can be continuously sampled and analyzed by a Bendix Corporation on-line chromatograph for major species and by a Baseline Industries on-line chromatograph for H<sub>2</sub>S, COS, and SO<sub>2</sub>. The inlet hot coal gas can also be continuously analyzed by the Bendix chromatograph after passage through an apparatus which condenses out steam and tars.

Additional provision is made to sample hot coal gas at the reactor inlet and outlet for particulate characterization.

Condensates can be drained via holding vessels into drums so that periodic sampling and weighing can be carried out.

Process data are logged by means of an automatic data acquisition and control system (ADACS) and can be displayed on a local terminal.

#### Operation of Sidestream Test Unit

The sidestream desulfurization unit was operated for the first time during Run 101 of METC's 42-inch, fixed-bed gasifier (7,8,9). This run took place from June 22 to July 1. During this 9-day period while Arkwright coal was fed to the gasifier, the unit was operated in the absorption mode with upward flow for three spells with two intermediate spells in the regeneration mode with downward flow. The schedule of operation is shown in Figure 5. The first two absorptions were with air-blown (low-Btu) gas and the third with intermittently air-blown and oxygen-blown (medium-Btu) gas.

Reactor furnace temperatures were adjusted to give a temperature profile along the reactor as close as possible to 1,000°F.

The reactor contained an approximately 4-foot deep layer of zinc ferrite extrusions weighing 20.4 kg, supplied by United Catalysts, Inc., with 6-inch layers of ½-inch ceramic spheres above and below, the whole held in place by support and cover plates.

Average pressures, temperatures and flow rates of the various streams for the three sulfidation runs are shown on ADACS process flow schematics in Figures 6A, 6B, 7, and 8.

During sulfidation Runs 001 and 003, approximate reactor conditions were: pressure 150 psig, temperature 1,000°F, and space velocity 2,000 hr<sup>-1</sup>, based

on condenser exit gas. In sulfidation Run 005 for air-blown operation, conditions were the same except for a lower pressure of about 90 psig. For oxygen-blown operation, owing to the large steam content of the gas, the space velocity was considerably greater since the exit gas flow rate was maintained constant. The duration of Run 001 was about 29 hours, interrupted by a few hours when the gasifier was off stream. Run 003 was about 25 hours long. The length of Run 005 is not comparable because of the intermittent operation with air- and oxygen-blown gas. But, taking into account the differing rates of mass flow of sulfur compounds into the reactor, the equivalent run length is estimated to be roughly the same as that of Runs 001 and 003.

Reactor exit gases were cooled to about 600°F by the first water-cooled condenser and then to about 130°F by the second water-cooled condenser except during oxygen-blown operation when the temperature was somewhat higher because of the greatly increased heat load. The pressure drop across the reactor was initially less than 1 psi at the beginnings of the first two sulfidations increasing to about 5 psi towards the ends. Regeneration restored the pressure drop approximately to its original level. The pressure drop at the beginning of the third sulfidation was somewhat greater than that of the first two because of the greater flow rate and only increased to about 2 psi at the end because of the shorter run length. The increases in pressure drop are attributed mainly to particulate deposition. Coke, resulting from pyrolysis of tars and/or from carbon monoxide by the Boudouard reaction:  $2\text{CO} \rightarrow \text{C} + \text{CO}_2$ , is probably also a contributory factor.

The pressure drop across the small secondary cyclone gradually increased from 0.2 to 0.4 psi during Runs 001 and 003 and then rapidly increased during the oxygen-blown intervals of Run 005 so that, at the end of this run, the combined pressure drops across the cyclone and the inlet gas line were about 30 psi. This blockage is attributed mainly to deposition of coke from tars in the gas. When the run was over, the blockage was cleared by blowing an air-steam mixture through the line.

The zinc ferrite sorbent was regenerated twice in Runs 002 and 004 with a regeneration gas typically consisting of an about 80/20 vol. percent steam/air mixture at a temperature of 1,000°F. Space velocity was usually 500-1,000 hr<sup>-1</sup> based on reactor flow. Some difficulty was experienced in controlling the air and steam flows, so that the sorbent temperature occasionally exceeded the design maximum of about 1,600°F. Figures 9 and 10 are ADACS plots of the sorbent temperature along the reactor throughout the regenerations. A somewhat lower air flow rate during Run 004 resulted in a rather longer regeneration time of 19 hours compared to 15 hours for Run 002.

The Baseline Industries gas chromatograph became fouled towards the end of the first sulfidation by oil droplets in the exit gas from the final condenser. For future tests a special Permapure Filter System was subsequently acquired.

During the sulfidation and regeneration runs, hydrogen sulfide and/or sulfur dioxide concentrations of exit gas were measured hourly by detector tubes. Grab samples of exit gas and condensates were taken generally at 4-hour intervals for laboratory analysis. Major species in the exit gas during the sulfidations were measured continuously by the Bendix chromatograph. Also, during the sulfidation runs, occasional samples of hot gas at the reactor inlet and

outlet were taken via 1-inch Kamyr valves through a particle sampling system to determine particle loadings and sizes. Liquids, which were condensed from these samples, were analyzed (10).

At the conclusion of the last sulfidation run, which was continued well beyond breakthrough, the sulfidized sorbent was removed, samples being taken at points along its length. Fines were removed by screening. A lump of agglomerated sorbent extrusions about 4 inches deep was found near the top of the bed. This appeared to be caused by coke deposition.

### Results

- Data Summary

The various process conditions and data collected in Runs 001 to 005 are summarized in Figures 11 to 15.

- Absorption of Sulfur Compounds

Figure 16 is a plot of the hydrogen sulfide concentration of exit gas, after condensation of tar and water, against on-stream time for Run 001. Measurements were made with both on-line gas chromatograph and detector tube which agreed quite well. Until breakthrough after about 28 hours, H<sub>2</sub>S levels were below 5 ppm averaging about 2 ppm. After Run 001, the gas chromatograph became fouled with tar droplets and was subsequently inoperative for this series of runs.

Figure 17 compares H<sub>2</sub>S concentrations for Runs 001 and 003 as measured by detector tube. The levels are very similar except at the beginning of Run 003 in which the H<sub>2</sub>S is initially high, presumably because of residual sulfur compounds left in the sorbent bed after regeneration. The on-stream time before breakthrough for Run 003 is about 5 hours less than for Run 001, accounted for by the higher inlet gas H<sub>2</sub>S concentrations. The sulfur loadings of the sorbent in Runs 001 and 003, computed from the mass flow and H<sub>2</sub>S concentration of the inlet gas, were 14.4 and 17.9 wt percent respectively (see Figures 11 and 13). Because other sulfur compounds including COS were neglected, the actual values would be somewhat greater. Also neglected was sulfur pick-up by the stainless steel delivery line.

Figure 18 plots H<sub>2</sub>S concentration in exit gas against time on stream for Run 005. H<sub>2</sub>S levels while desulfurizing air-blown gas are comparable to those in Runs 001 and 003. With oxygen-blown gas, the H<sub>2</sub>S level is about 20 ppm corresponding to the greater quantity of steam in the gas. As in Run 003, H<sub>2</sub>S is initially high which is attributed to residual sulfur compounds in the sorbent bed. Some sulfur dioxide was also detected in the initial stages of Runs 003 and 005 but fell off more rapidly than the initially high H<sub>2</sub>S. This is shown in Figures 19 and 20.

The H<sub>2</sub>S levels were corroborated through analysis of grab samples by laboratory gas chromatograph which also measured COS, CH<sub>3</sub>SH, CS<sub>2</sub>, and thiophene. These are shown in Table 1 which also includes major gas species. COS, CH<sub>3</sub>SH, and CS<sub>2</sub> are much less than H<sub>2</sub>S, but significant

quantities of thiophene were detected. This is plotted in Figure 21 for Runs 001, 003, and 005 and varies from about 5 to 10 ppm which is not much less than the about 10 ppm typically found in raw coal gas. Table 2 shows the analysis of grab samples of gas taken at the exit of the gasifier primary cyclone for mostly the same species as in Table 1.

- Regeneration

As described above, it was attempted to carry out regeneration Runs 002 and 004 in such a way that the reaction zone temperature was generally between 1,500 and 1,600°F and the SO<sub>2</sub> concentration on termination less than about 0.5 vol. percent. The sample-gas analyses in Table 1 suggest that, during the first half of the regenerations, coke deposited in the sorbent due to cracking of tar was gasified and the gasification products reacted with the products of oxidation of zinc and iron sulfides. Thus, in the early stages, hydrogen exceeded 8 vol. percent and carbon dioxide 16 vol. percent (on a dry gas basis). An alternative explanation may be that magnetite was reduced to wustite, iron, and cementite to some extent by the coal gas which, being produced at a low steam/air ratio of 0.2 wt./wt., had high reducing power. Under these conditions, sulfur in the gas appeared to be mostly in the form of H<sub>2</sub>S and elemental sulfur. When most of the coke had been burned from the sorbent and/or iron was oxidized, sulfur dioxide predominated, as shown by the detector tube readings in Figure 22, the concentration attaining about 6 vol. percent in gas exiting the unit.

- Carbon Monoxide Conversion (Shift) Reaction

It was generally found that the carbon monoxide shift reaction proceeded during the sulfidation runs as was expected, since the sorbent under the prevailing conditions was initially predominantly magnetite, a well-known shift reaction catalyst. Thus, Table 1 and Table 2 indicate for Runs 001 and 003 that CO in the early stages was lowered to about 14 vol. percent from about 22 vol. percent. In the latest stages, CO shift was significantly less, perhaps owing to coke deposition, and the CO concentration was about 20 vol. percent. Consumption of CO in reducing the sorbent to iron may also be a factor. Corresponding changes in H<sub>2</sub> and CO<sub>2</sub> concentrations occurred. The results were corroborated by on-line gas chromatograph analysis as shown in Figures 23, 24, and 25 for Run 003.

It would be expected that the sum of the CO and H<sub>2</sub> concentrations at the unit inlet and outlet respectively would be the same. In the early stages of Runs 001 and 003 outlet CO + H<sub>2</sub> was significantly lower than inlet CO + H<sub>2</sub>, suggesting that it was being consumed in sorbent reduction.

- Sorbent Characterization

Characterizations of the sorbent, on removal from the reactor, at seven points along the reactor length are shown in Tables 3 and 4. From Table 3, it can be seen that, at the bottom of the sorbent bed, virtually all the zinc and 80 to 90 percent of the iron has been converted to

sulfide; whereas at the top of the bed, the zinc is partially converted to sulfide, but no iron sulfide has been formed. It is apparent also from the data at the top of the bed that the original zinc ferrite has been first converted to magnetite and zinc oxide owing to reduction by the coal gas. There is a sharp transition between points where iron sulfide is formed and where it is absent. At the bottom of the bed, zinc sulfide is mostly in the form of beta-ZnS (cubic sphalerite); whereas at the top, there is more alpha-ZnS (hexagonal wurtzite).

Table 4 shows that at the bottom of the bed the sorbent sulfur loading is about 30 wt. percent, not much less than the value of about 35 percent for complete sulfidation. The sorbent can be seen to contain 2 to 4 wt. percent of carbon, there being slightly more at the top of the bed than at the bottom. The higher concentration of 7 wt. percent carbon in the 2.4 kg of fines, which were screened through a No. 8 (2.38 mm) screen from the total sorbent removed from the reactor, demonstrates that coke deposition occurs preferentially at the sorbent pellet surfaces. Although the amount of fines exceeds 10 percent of the sorbent, it is difficult to differentiate between that originally in the reactor and that formed during sorbent removal by suction with a vacuum hose.

The sorbent surface area and pore volume at the bottom of the bed are about half the values at the top, which are about the same as those for fresh sorbent. Thus, after three sulfidations and two regenerations, there is not a marked change in these parameters.

The fully sulfidized sorbent at the bottom of the bed has about twice the crush strength of that at the top of the bed which itself is significantly, though not a lot, less than the crush strength of fresh sorbent.

Since the sorbent prior to removal had been in contact with oxygen-blown gas it should not be inferred that its characterization after Runs 001 and 003 with air-blown gas is the same.

- Particulate Analysis

In the course of the operation of the hot gas desulfurization unit, a sample of particulates knocked out in the secondary cyclone during the first two sulfidations was taken and its particle size distribution determined. Details of the findings are shown in Table 5. Also included is a chemical analysis in terms of carbon, sulfur, and ash. Particle size varied from 4 to 100 microns with a median of about 30 microns. The carbon content of more than 80 wt. percent is typical for fixed-bed gasifiers.

Other particulate samples were taken at the inlet and outlet of the desulfurization unit by means of alundum extraction thimbles (8). A summary of the measurements made of these samples are given in Table 6. The particle loading is of the order of 1 g/Nm<sup>3</sup> being somewhat greater at the exit. Mean particle size is generally higher at the inlet (3 to 15 microns) than at the outlet (~ 3 microns). Chemical analysis indicates that the inlet particles contain about 15 wt. percent carbon suggesting that most of the particulate carbon leaving the gasifier is

gasified in the ~ 100-ft line between the secondary cyclone and the desulfurization unit. Analysis of the outlet particles is very similar to that of sorbent fines suggesting that inlet particles are mostly trapped in the reactor and sorbent fines are entrained in the gas leaving the reactor. Particulate size distributions are given in Tables 7. to 13.

- Condensate Analysis

Liquor was collected periodically from the condenser through which the continuous sample of gases at the exit of the gasifier primary cyclone (sampling point S-4) was passed at gasifier pressure. This condensate, as collected, was in two fractions, one mainly water and the other tars. The water fraction was analyzed for inorganic ions of interest as shown in Table 14. An ultimate analysis of the tars was carried out and is shown in Table 15.

As previously described, gases leaving the hot-gas desulfurization reactor pass through condenser CIC immediately before exiting the unit. The liquor which condenses out drains into a collection vessel and is dumped, generally every 4 hours, into steel drums. During sulfidations the liquor separates into water and tar layers. In a few cases, the liquor from the collection vessel before dumping was sampled and the aqueous layer analyzed for the same constituents as the corresponding liquor from S-4 sample point. The analyses are shown in Table 16.

The dumped condensate from CIC was collected in three batches: that during air-blown operation from Runs 001, 003, and 005; that during oxygen-blown operation from Run 005; and that during regeneration from Runs 002 and 004. The first two batches were separated into water and tar layers, weighed, and sampled. The third batch, which consisted only of an aqueous phase, was also weighed and sampled.

The aqueous samples were analyzed for inorganic ions as above and are shown in Table 17 and 18, respectively. The first sample was also analyzed for comparison by IHI-KEMRON, who measured for the additional ions, sulfide, sulfite, cyanide, thiocyanate, antimony, and lead, but did not include nickel, chromium, aluminum, selenium, mercury, nitrate, phosphate, and bromide. This analysis is also shown in Table 17. Included in Table 18 is a corresponding analysis of the steam used for regeneration. Ultimate analyses of the two tar samples are shown in Table 19.

Perusal of Tables 14, 16, 17, and 18 permits some tentative deductions to be made concerning the absorption of certain elements and ions by the sorbent during sulfidation and their subsequent release during regeneration, bearing in mind that the amount of aqueous condensate collected from sulfidation Runs 001 and 003 was about 122 lbs and that from regeneration Runs 002 and 004 about 250 lbs (see Figures 11 to 14).

The halides  $F^-$ ,  $Cl^-$ , and  $Br^-$  appear to be removed by as much as 70 percent from the air-blown gas, virtually all of this being extracted from

the sorbent during regeneration. A similar proportion of the alkali metals Na and K also appears to be removed during sulfidation and is subsequently released into the regeneration condensate.

Additionally, the regeneration condensate, as analyzed, was enriched in vanadium, calcium, aluminum, mercury, and ammonium ion indicating that these may also have been removed from the coal-gas stream to some extent.

Zinc ion measured in both sulfidation and regeneration condensates was encouragingly low at less than about 2 ppm.

Iron ion in the sulfidation condensate was quite low at about 20 ppm, indicating relatively little carry-over from the sorbent. The high value in the regeneration condensate in Table 11 does not agree with that in Table 16, suggesting possible pickup from the steel collection drum.

There is some evidence that selenium and sulfate ion were removed from the coal gas to a large extent but virtually no arsenic. The fairly large amount of sulfate ion in the regeneration condensate was, of course, expected. A small quantity of inorganic ash was contained in the tar condensates (see Table 19) translating to about 10 ppm in the gas.

- Sulfur in Condensate

In addition to the sulfur compounds,  $H_2S$ , etc., measured by gas chromatograph in the exit gas from the hot-gas desulfurization unit, sulfur compounds were found in the exit gas condensate, both in the water and tar components. Table 17 indicates that the water condensate contained as much as 350 ppm of sulfur translating to nearly 20 ppm in the gas. From Table 19 it can be seen that the tar condensate contained about 2 wt percent of sulfur translating to about 100 ppm in the gas. Thus, taking this sulfur into account, the hot gas leaving the hot-gas desulfurization reactor contained about 100 ppm above that measured by gas chromatograph. Most of this appears to be organically bound sulfur. It is of interest to note that the sulfur concentration in the tar condensate at the unit exit does not appear to be less than at the inlet (see Table 15) contrary to expectations if the sorbent possessed hydrodesulfurization activity.

- Composition of Reactor Exit Gas

In Tables 20 and 21 the components found in the aqueous condensate, Tables 16 and 17, are expressed as a concentration of the reactor exit gas. Components from the tar condensate are not included. The chloride level of the coal gas considerably exceeds the expected tolerable level of about 1 ppm for molten carbonate fuel cells; the arsenic level may be acceptable. Little is known about the effect of the other components, except for sulfur compounds.

The levels of sodium, potassium, and vanadium may be acceptable should the coal gas be used as gas turbine fuel.

## Conclusions

The first series of tests to evaluate the performance of zinc ferrite, hot-gas desulfurization sorbent in a side-stream of METC's 24 t/d, fixed-bed coal gasifier was carried out successfully with only minor difficulties. The concentration of sulfur compounds in the exit gas from the hot-gas desulfurization unit was generally less than 10 ppm. However, this disregards sulfur compounds condensing out in the tar and aqueous condensates which, expressed as equivalent gas concentration, amounts to about 100 ppm.

Detailed data were obtained characterizing the sorbent performance at various stages in the adsorption/regeneration cycles. Generally, the sorbent behaved as anticipated, based on the previous laboratory-scale investigation. The main difference was due to the presence of tars in the coal gas which appeared to crack in the sorbent, forming coke. An additional complication may have been reduction of magnetite iron to lower valence states. The apparent gradual buildup of particulates and coke caused the pressure drop across the reactor of the hot-gas desulfurization unit to increase but it was of manageable proportions and mostly decreased during regeneration. The coke appeared to act as a reducing agent partially reducing sulfur oxides liberated during regeneration to hydrogen sulfide, sulfur, etc., and thus could be of advantage in a scheme for sulfur recovery. However, part of this effect may have been the result of reduction of magnetite to iron and the consequent formation of hydrogen by the steam-iron reaction.

The tests established that desulfurization performance of the sorbent was satisfactory in the temperature range 1,000 to 1,100°F, at pressures up to 150 psig, and at a space velocity of 2,000 h<sup>-1</sup>.

On removal from the reactor, the sorbent contained about 10 percent of fines but most of this may be the result of breakage in the removal process. The strength of the sorbent extrusions appeared to be unimpaired.

The sorbent was active in promoting the carbon monoxide "shift" conversion reaction to hydrogen. It also absorbed alkali metals and halides to a large extent, subsequently releasing them during regeneration. There was some evidence that vanadium, calcium, and mercury were similarly removed to some extent.

Particulate loading at the reactor exit was measured at about 1 g/Nm<sup>3</sup>, the particles typically having a mean size of about 3 µm.

## References


1. Grindley, T., "Development and Testing of Regenerable Hot Coal Gas Desulfurization Sorbents for Molten Carbonate Fuel Cell Application," METC, IR No. 1133 (1981).
2. Grindley, T., "Report on Testing of Institut Francais DuPetrole (IFP) Desulfurization Sorbent MEP-682," METC, IR No. 1328 (1982).

3. Grindley, T., "Development and Testing of Regenerable Hot Coal Gas Desulfurization Sorbents for Molten Carbonate Fuel Cell Application (Continuation)," METC, IR No. 1386 (1982).
4. Grindley, T., "Development and Testing of Regenerable Hot Coal Gas Desulfurization Sorbents for Molten Carbonate Fuel Cell Application (Phase 3)," METC, IR No. 1906 (1984).
5. Steinfeld, G., "Hot Gas Desulfurization," Science Applications, Inc., for METC, Final Report Nos. 1-443-13-710-00 (1981) and 1-457-04-369-00 (1982). (DOE/MC/16545-TI[DE83004283][1982]).
6. Steinfeld, G., "Status of METC Investigations of Coal Gas Desulfurization at High Temperature," Science Application, Inc., for METC. Report No. DOE/MC/16545-1553(DE84003084) (1984).
7. Pater, K., "Run No. 101 Test Plan," IR 1648, METC, August 1983.
8. Pater, K., Preliminary Summary for Run No. 101. IR 1644 August 1983, METC.
9. Romanosky, R. R., J. J. Kovach, Analytical Data Producer Run No. 101. METC, IR No. 1861 (1984).
10. Bagnell, R. D., C. K. McCurry, and E. E. Childers, "Process Stream Characterization for the Hot Gas Desulfurization Unit During Gasification Run 101." METC, IR No. 1764 (1984).

ADDENDUM TO APPENDIX E

The Baseline G.C. on-line H<sub>2</sub>S, COS, and SO<sub>2</sub> readings as plotted are correct only for the points: H<sub>2</sub>S: 3 ppm; COS: 1.7 ppm; and SO<sub>2</sub>: 5.1 ppm. Calibration curves are available for correction. Corrected plots are given in Volume 1.

Refer to letter to T. Grindley from E. E. Gorski and P. Johnson, EG&G Washington Analytical Services Center, Inc. January 30, 1986. Subject: DOE-METC/EG&G Contract No. DE-AC21-85MC21353; WBS No. 9KEX-10. HGD Project: Baseline GC/Integrator Conversion Curves.



**FIGURE 1: PROCESS AND INSTRUMENT DRAWING OF SKID-MOUNTED,  
SIDE-STREAM, HIGH-TEMPERATURE, COAL-GAS  
DESULFURIZATION UNIT**






FIGURE 2:  
**HOT GAS DESULFURIZATION  
 SIDESTREAM TEST UNIT  
ABSORPTION**

LEGEND

- HOT PRODUCER GAS WITH SULFUR
- HOT PRODUCER GAS WITHOUT SULFUR
- COOLER PRODUCER GAS WITHOUT SULFUR
- COLD PRODUCER GAS WITHOUT SULFUR






**FIGURE 3:**  
**HOT GAS DESULFURIZATION**  
**SIDESTREAM TEST UNIT**  
**REGENERATION**


LEGEND


- REGENERATION GAS
- REGENERATION GAS WITH SO<sub>2</sub>



*What is the main topic?*

**FIGURE 4: HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
AT TEST LOCATION**






SCHEDULE OF EVENTS

FIGURE 5: HOT GAS DESULFURIZATION SIDESTREAM TESTING 1983


**RUN 001A**  
**AVERAGE OPERATING PARAMETERS**



AVERAGE(S) FOR PERIOD FROM: 10:15:17 0/23/1983 TO 7:48:4 8/24/1983

**FIGURE 6A**


RUL J01B  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 10/30/87      8/24/1983 TO 8/31/1983      8/25/1983

FIGURE 6B


RUN J3  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 13:30:15    6/26/1983 TO 14:00:22    6/27/1983

FIGURE 7


RUN 005A  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 11:01:18 6/29/1983 TO 8:24:11 6/29/1983

FIGURE 8A


RUI 05B  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 12:45:11 6/26/1983 TO 17:29:11 6/26/1983

FIGURE 8B


SLOT	UNITS	DESCRIPTION
O	851	DEGF ABSORBER 5° FROM BOTTOM
U	852	DEGF ABSORBER 15° FROM BOTTOM
C	853	DEGF ABSORBER 25° FROM BOTTOM
A	854	DEGF ABSORBER 35° FROM BOTTOM
V	855	DEGF ABSORBER 45° FROM BOTTOM



START TIME OF PLOT      17:30± 0      6/25/1983  
 STOP TIME OF PLOT      8:55± 0      6/26/1983

Figure 9 Run 002 Regeneration Reactor Temperatures

SLOT	UNITS	DESCRIPTION
O 851	DEGF	ABSORBER 5° FROM BOTTOM
□ 852	DEGF	ABSORBER 15° FROM BOTTOM
◊ 853	DEGF	ABSORBER 25° FROM BOTTOM
△ 854	DEGF	ABSORBER 35° FROM BOTTOM
▽ 855	DEGF	ABSORBER 45° FROM BOTTOM



START TIME OF PLOT      0:12: 0      6/28/1983  
 STOP. TIME OF PLOT      18:50: 0      6/28/1983

Figure 10 Run 004 Regeneration Reactor Temperatures

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 001  
DATE STARTED : 16:15 6/23/83  
DATE ENDED : 08:35 6/25/83

TOTAL HOURS : 29.68  
TYPE : SULFIDATION  
SULFUR REMOVED: 6.49 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 45 LBS  
SORBENT NO. : UNITED CATALYSTS L-1504  
SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
50.0 MOLES ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED WELLMAN CALUSHA  
COAL TYPE : ARKURIGHT  
STEAM/COAL RATIO: 0.526  
STEAM/AIR RATIO : 0.20

HGD OPERATING CONDITIONS

TEMPERATURE: 1025 F  
PRESSURE : 160 PSIG (AVERAGE)

SPACE VELOCITY: 2020 HOURLY

	INLET MOLES DRY BASIS (OIL FREE)	INLET MOLES WET BASIS (OIL FREE)	EXIT MOLES DRY BASIS (OIL FREE)	EXIT MOLES WET BASIS (OIL FREE)
H <sub>2</sub> S	0.23		2 PPM	
H <sub>2</sub> O			4.71	
C <sub>0</sub> <sub>2</sub>	7.02			
C <sub>0</sub>	22.04			
H <sub>2</sub>	15.03			
C <sub>1</sub> H <sub>4</sub>	2.58			
N <sub>2</sub>	47.34			
O <sub>2</sub>	0.63			
C <sub>2</sub> H <sub>6</sub>	0.83			

TOTAL FLOW: 33,515 SCF

TOTAL LB MOLES: 88.43

FLOW RATE: 1130 SCFH

35,010 SCF

92.38

1180 SCFH

PURPOSE

FIRST TEST OF SCALED-UP TEST UNIT ON SIDESTREAM  
OF FIXED BED GASIFIER.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (WT%)	0.13	
SURFACE AREA: (SQ M/G)	3.13	
DENSITY : (G/CC)	6.16	
PORE VOLUME: (CC/G)	0.004316	
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (WT%)	0.0	

EXIT SULFUR DATA:

	PPM
H <sub>2</sub> S	2 PPM
C <sub>4</sub> H <sub>10</sub>	5 PPM

CONDENSATE	:	71.2 LBS	(ESTIMATED)
AQUEOUS	:	8 LBS	(ESTIMATED)
HYDROCARBON	:	79.2 LBS	(MEASURED)
TOTAL	:		

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6. INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH 58 7/8 INCHES
3. FIRST TEST ON FRESH SORBENT
4. EXIT GC NOT OPERATING DURING THIS TEST.
5. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED AND EXIT GAS SATURATION LEVEL BY STEAM TABLES.
6. GAS COMPOSITION AT INLET IS AVERAGE OF DATA OBTAINED BY BENDIX GC 7000 84 SAMPLING AT S4 GASIFIER CYCLONE EXIT.

CONCLUSIONS:

1. SORBENT CAN DESULFURIZE GASIFIER GAS CONTAINING TARS AND OILS DOWN TO LESS THAN 10 PPM TOTAL SULFUR.

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 008  
 DATE AND TIME STARTED : 17:30 6/25/83  
 DATE AND TIME ENDED : 08:55 6/28/83  
 TOTAL HOURS : 14.4  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO.: UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 1000 F  
 PRESSURE : 152 INCHES OF WATER (AVERAGE)  
 SPACE VELOCITY: 961 HOURLY

	INLET MOLES WET BASIS	EXIT MOLES DRY BASIS
AIR	10	
H <sub>2</sub> O	81	

TOTAL LB MOLES:  
 FLOW RATE :  
 \$

543 SCFH

PURPOSE

FIRST REGENERATION OF SULFIDED SORBENT ON SIDESTREAM TEST UNIT.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (WT%)		
SURFACE AREA: (SQ M/Q)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (WT%)		

EXIT SULFUR DATA:

H<sub>2</sub>S :  
 SO<sub>2</sub> : 14 % INITIALLY

CONDENSATE AQUEOUS	:	151.1 LBS
HYDROCARBON	:	
TOTAL	:	151.1 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES C9-346 1/2 S SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH 58 7/8 INCHES
3. FIRST REGENERATION ON SULFIDED SORBENT
4. THERE WERE SOME DIFFICULTIES CONTROLLING THE STEAM AND AIR FLOWS. MANUAL ADJUSTMENTS IN STEAM AND AIR FLOWS WERE MADE TO PREVENT EXCEEDING 1700 F IN THE BED.
5. STEAM AND AIR FLOWS WERE ERRATIC DURING THE LAST 7 HOURS DUE TO OPERATOR ADJUSTMENTS.

CONCLUSIONS

1. REGENERATION COMPLETED.
2. IMPROVED FLOW CONTROL FOR STEAM AND AIR ARE REQUIRED.
3. HIGHER STEAM CONTENT OR LOWER SPACE VELOCITY ARE REQUIRED TO PREVENT OVERTEMPERATURING THE SORBENT.

Figure 12

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 003  
 DATE STARTED : 13130 6/26/83  
 DATE ENDED : 15100 6/27/83  
 TOTAL HOURS : 84.58  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 8.06 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED WELLMAN CALUSHA  
 COAL TYPE : ARKURIGHT  
 STEAM/COAL RATIO: 0.480  
 STEAM/AIR RATIO : 0.19

HGD OPERATING CONDITIONS

TEMPERATURE: 1018 F (AVERAGE)

PRESSURE : 143 PSIG (AVERAGE)

SPACE VELOCITY: 1925 HOURLY

	INLET MOLES DRY BASIS (OIL FREE)	INLET MOLES WET BASIS (OIL FREE)	EXIT MOLES DRY BASIS (OIL FREE)	EXIT MOLES WET BASIS (OIL FREE)
H2S	0.36		1.6 PPM	1.5 PPM
H2O				4.40
CO2	6.93		10.35	9.91
CO	22.06		17.61	16.85
H2	14.84		16.30	15.60
CH4	2.68		2.62	2.50
N2	47.03		49.83	47.70
O2	0.46		0.81	0.58
C2H6	0.25		0.03	0.03
TOTAL FLOW:	26,473 SCF		26,473 SCF	27,553 SCF
TOTAL LB MOLES:	69.84		69.84	72.69
FLOW RATE:	1077 SCFH		1077 SCFH	1181 SCFH

PURPOSE

SECOND SULFIDATION ON SAME BATCH OF SORBENT USING FIXED BED GASIFIER.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (WT%)		
SURFACE AREA: (SQ M/Q)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (WT%)		

EXIT SULFUR DATA:

H2S :	1.6 PPM
C4H4S:	6.7 PPM

CONDENSATE

AQUEOUS :	51.35 LBS	(ESTIMATED)
HYDROCARBON :	5.74 LBS	(ESTIMATED)
TOTAL :	57.1 LBS	(MEASURED)

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-348 1/2 S SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH 58 7/8 INCHES
3. SECOND SULFIDATION ON SAME SORBENT
4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED AND EXIT GAS SATURATION LEVEL BY STEAM TABLES.
5. GAS COMPOSITION AT INLET IS AVERAGE OF DATA OBTAINED BY BENDIX GC 7000 #4 SAMPLING AT S4 GASIFIER CYCLONE EXIT.
6. GAS COMPOSITION AT EXIT (DRY BASIS) IS AVERAGE OF DATA OBTAINED BY BENDIX GC 6000 #2 SAMPLING A HGD EXIT.
7. GAS COMPOSITION AT EXIT (WET BASIS) IS CALCULATED FROM DRY BASIS DATA AND WATER OBTAINED AS IN ITEM 4 .

CONCLUSIONS:

1. SORBENT CAN DESULFURIZE GASIFIER GAS CONTAINING TARS AND OILS DOWN TO LESS THAN 10 PPM TOTAL SULFUR.
2. PERFORMANCE IS REASONABLY GOOD AFTER A REGENERATION. BREAKTHROUGH TIME DECREASED FROM 29 HOURS TO 23 HOURS.
3. H2S WAS INITIALLY HIGH AND DROPPED DOWN TO LOW LEVELS AFTER 4 HOURS.
4. SO2 WAS DETECTED INITIALLY AND DROPPED DOWN TO 1 PPM AFTER FORTY MINUTES.

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 004  
 DATE AND TIME STARTED : 09:18 8/28/83  
 DATE AND TIME ENDED : 18:50 8/28/83  
 TOTAL HOURS : 18.8  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO.: LIMITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

PURPOSE

SECOND REGENERATION OF SULFIDED SORBENT ON SIDESTREAM TEST UNIT.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (WT%)		
SURFACE AREA: (SQ M/G)		
DENSITY: (G/CC)		
PORE VOLUME: (CC/G)		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (WT%)		

HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 968 F  
 PRESSURE : 139 INCHES OF WATER (AVERAGE)  
 SPACE VELOCITY: 657 HOURLY

EXIT SULFUR DATA:

H<sub>2</sub>S :  
 SO<sub>2</sub> : 16 PPM INITIALLY . HIGH OF 4 % AFTER TEN HOURS

	INLET MOLES WET BASIS	EXIT MOLES DRY BASIS
AIR	37.5 SCFH	10.2
H <sub>2</sub> O	14.3 B/HR	82
N <sub>2</sub>	28.8 SCFH	7.8

CONDENSATE	:	
AQUEOUS	:	100.7 LBS
HYDROCARBON	:	
TOTAL	:	100.7 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1 1/8 S SR-10789 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. SECOND REGENERATION ON SULFIDED SORBENT
4. THERE WERE SOME DIFFICULTIES CONTROLLING THE STEAM AND AIR FLOWS.
5. MAXIMUM TEMPERATURE REACHED WAS 1687 F.

CONCLUSIONS

1. REGENERATION COMPLETED.
2. IMPROVED FLOW CONTROL FOR STEAM AND AIR ARE REQUIRED.

TOTAL LB MOLES  
 FLOW RATE : 367 SCFH

Figure 14

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 805  
 DATE STARTED : 11:00 6/29/83  
 DATE ENDED : 17:30 6/30/83  
 TOTAL HOURS : 83.15  
 TYPE : SULFIDATION  
 SULFUR REMOVED: LB 58

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED WELLMAN GALUsha  
 COAL TYPE : ARKWRIGHT  
 STEAM/COAL RATIO: 0.500 ON AIR BLOUM 2.344 ON OXYGEN BLOUM  
 STEAM/AIR RATIO : 0.193  
 STEAM/OXYGEN RATIO: 3.366  
 HGD OPERATING CONDITIONS  
 TEMPERATURE: 1012 F (AVERAGE)  
 PRESSURE : 91 PSIG (AVERAGE)  
 SPACE VELOCITY: 1046 HOURLY FIRST PORTION  
 347 HOURLY SECOND PORTION

	INLET AIR BLOUM MOLES (OIL FREE) DRY WET	INLET O2 BLOUM MOLES (OIL FREE) DRY WET	EXIT AIR BLOUM MOLES (OIL FREE) DRY WET	EXIT O2 BLOUM MOLES (OIL FREE) DRY WET	
H2S	0.38	0.66	3 PPM	2.85 PPM	
H2O				4.28	53
CO2	7.16	18.88	12.59	12.13	
CO	24.81	24.92	16.33	15.73	
H2	15.06	29.50	17.86	17.21	
CH4	3.14	6.36	2.84	2.73	
N2	51.12	1.01	47.20	45.49	
O2	0.54	0.01	0.50	0.48	
C2H6	0.40	0.62	0.04	0.03	
TOTAL FLOW (SCFM)	6405	5447 11423	6405	6845	5447 11423
LB MOLE RATE	16.9	14.37 30.14	16.9	17.63	14.37 30.14
FLOW RATE (SCFH)	949	340 714	949	984	340 714

PURPOSE

THIRD SULFIDATION ON SAME BATCH OF SORBENT USING FIXED BED GASIFIER.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (SUT)	8.6-31.41	(22.83 AVG)
SURFACE AREA: (SQ M/G)	2.18 (AVG)	
DENSITY : (G/CC)	4.55 (AVG)	
PORE VOLUME: (CC/G)	0.0039 (AVG)	
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (SUT)	2.63 (AVG)	

EXIT SULFUR DATA:  
 H2S : 3 PPM ON AIR BLOUM GAS  
 C4H10: 4 PPM ON AIR BLOUM GAS

CONDENSATE	AIR BLOUM (7.15 HRS) O2 BLOUM (16 HRS)
AQUEOUS	11.42 LBS
HYDROCARBON	1.28 LBS
TOTAL	12.7 LBS
	284 LBS
	10 LBS
	294 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S SR-10789 UNITED CATALYSTS.
2. OVERALL PACKED LENGTH IS 58 7/8 INCHES.
3. THIRD SULFIDATION ON THE SAME SORBENT.
4. PORTIONS OF THE RUN WERE AIR BLOUM, PORTIONS O2 BLOUM.
5. WATER IN EXIT GAS DETERMINED BY CONDENSATE COLLECTED AND EXIT GAS SATURATION LEVEL BY STEAM TABLES.
6. AIR BLOUM GAS COMPOSITION AT INLET IS AVERAGE OF DATA OBTAINED BY BENDIX GC 6000 81 SAMPLING AT HGD INLET.
7. OXYGEN BLOUM GAS COMPOSITION AT INLET IS AVERAGE OF DATA OBTAINED BY BENDIX GC 6000 81 SAMPLING AT HGD INLET.
8. AIR BLOUM DRY GAS COMPOSITION AT EXIT IS AVERAGE OF DATA OBTAINED BY BENDIX GC 6000 82 SAMPLING AT HGD EXIT.
9. AIR BLOUM WET GAS COMPOSITION AT EXIT IS CALCULATED FROM DRY GAS COMPOSITION AND WATER AS DETERMINED IN ITEM 5.

CONCLUSIONS:

1. SORBENT CAN DESULFURIZE GASIFIER GAS CONTAINING TARS AND OILS DOWN TO LESS THAN 10 PPM TOTAL SULFUR.
2. PERFORMANCE ON AIR BLOUM GAS IS REASONABLY GOOD AFTER TWO REGENERATIONS, BUT POOR ON OXYGEN BLOUM GAS.
3. H2S WAS INITIALLY HIGH AND DROPPED DOWN TO LOW LEVELS AFTER 3 HOURS.
4. SO2 WAS DETECTED INITIALLY AND DROPPED DOWN TO 1 PPM AFTER FORTY MINUTES.

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 001





Figure 16

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TESTS 001 AND 003



ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 005




Figure 18

19-JUN-84 10:55:07

P1

# ZINC FERRITE SULFIDATION

INITIAL H<sub>2</sub>S AND SO<sub>2</sub> CONCENTRATIONS




Figure 19

ZINC FERRITE SULFIDATION  
INITIAL H<sub>2</sub>S AND SO<sub>2</sub> CONCENTRATION




Figure 20

ZINC FERRITE SULFIDATION  
THIOPHENE CONCENTRATIONS




Figure 21

ZINC FERRITE REGENERATION  
SULFUR DIOXIDE CONCENTRATION IN EXIT GAS





Figure 22

TEST 003  
SHIFT CONVERSION



PERCENT CO  
BENDIX CHROMATOGRAPH  
START TIME 13:30:00 06/26/1983  
STOP TIME 15:00:00 06/27/1983

Figure 23

TEST 003  
SHIFT CONVERSION





Figure 24



PERCENT H<sub>2</sub>  
BENDIX CHROMATOGRAPH  
START TIME 13:30:00 06/26/1983  
STOP TIME 15:00:00 06/27/1983

Figure 25

TABLE I  
HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS  
TESTS 001 to 005

Sample No.	Location	Date Time	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	IC <sub>4</sub>	nC <sub>4</sub>	ppm H <sub>2</sub> S †	ppm COS	ppm CH <sub>3</sub> H	ppm CS <sub>2</sub>	ppm thio	ppm SO <sub>2</sub> *
SULFIDATION	T001	HG-1 Exit 6/23/83 1700	15.02	2.13	50.99	2.91	12.96	0.32	14.91	0.14	0.12	ND	ND	ND	ND	ND	ND	4.2	-
		HG-2 Exit 6/23/83 2230	16.24	2.89	50.12	2.62	15.51	0.28	11.65	0.1	0.09	ND	ND	ND	ND	ND	ND	4.5	-
		HG-3 Exit 6/24/83 0230	18.33	0.85	46.74	2.96	20.04	0.33	9.99	0.14	0.12	ND	ND	ND	ND	ND	ND	4.8	-
		HG-4 Exit 6/24/83 0630	18.76	0.97	46.20	2.90	20.98	0.32	9.13	0.12	0.11	ND	ND	ND	ND	ND	ND	4.2	-
		HG-5 Exit 6/24/83 0845	19.30	0.76	45.63	2.94	20.70	0.32	9.63	0.11	0.10	ND	ND	ND	ND	ND	ND	3.3	-
		HG-6 Exit 6/24/83 2330	14.48	2.38	52.44	2.49	18.00	0.30	9.24	0.08	0.08	ND	ND	.08	ND	ND	ND	5.4	-
		HG-7 Exit 6/25/83 0330	17.82	1.06	48.81	2.86	19.00	0.27	9.52	0.09	0.07	ND	ND	ND	0.2	ND	ND	6.8	-
		HG-8 Exit 6/25/83 0730	17.93	0.76	49.19	2.69	18.68	0.28	9.78	0.11	0.08	ND	ND	4.5	9.3	ND	ND	12.2	-
REGENERATION	T002	HG-9 Exit 6/25/83 2145	8.21	2.16	72.19	ND	0.53	ND	16.38	ND	0.02	ND	ND	-	-	-	-	-	4.35
		HG-10 Exit 6/26/83 0130	0.87	2.02	91.92	ND	0.02	ND	4.67	ND	ND	ND	ND	-	-	-	-	-	-
		HG-11 Exit 6/26/83 0530	ND	3.54	92.75	ND	0.11	ND	3.11	ND	ND	ND	ND	-	-	-	-	-	-
SULFIDATION	T003	HG-12 Exit 6/26/83 1515	17.39	1.65	47.72	2.99	16.21	0.31	13.00	0.14	0.09	ND	ND	16.2	2.3	2.5	ND	9.7	ND
		HG-13 Exit 6/26/83 1915	21.16	0.64	44.54	3.21	17.55	0.35	11.76	0.16	0.14	ND	ND	1.7	0.2	ND	ND	5.9	-
		HG-14 Exit 6/27/83 0130	17.53	1.35	48.53	2.75	18.79	0.32	9.95	0.15	0.14	ND	ND	ND	0.2	ND	ND	5.5	-
		HG-15 Exit 6/27/83 0530	18.98	0.86	46.28	2.88	21.56	0.32	8.34	0.14	0.14	ND	ND	ND	ND	ND	ND	6.9	-
		HG-16 Exit 6/27/83 0930	19.41	0.75	45.60	3.21	20.95	0.34	8.94	0.17	0.14	ND	ND	ND	0.7	ND	ND	8.7	-
		HG-17 Exit 6/27/83 1330	18.55	0.64	45.64	3.45	22.18	0.39	8.36	0.15	0.14	ND	ND	22.5	10.9	ND	ND	6.6	-
		HG-18 Exit 6/28/83 0145	5.93	1.91	83.61	ND	0.21	ND	7.83	ND	ND	ND	ND	2994.9	5.5	ND	6.5	ND	10.0
REGENERATION	T004	HG-19 Exit 6/28/83 0430	3.53	1.26	89.07	ND	0.17	ND	5.48	ND	ND	ND	ND	-	488.7	ND	150.0	ND	329.5
		HG-20 Exit 6/29/83 0830	ND	0.45	95.88	ND	ND	ND	3.17	ND	ND	ND	ND	-	360.8	ND	150.0	ND	4000.0
		HG-21 Exit	-	-	-	-	-	-	-	-	-	-	-	-	1350	ND	295.0	ND	1812.0
		HG-22 Exit 6/28/83 1630	0.31	1.02	98.17	ND	ND	ND	ND	ND	ND	ND	ND	-	-	-	-	-	-
		HG-23 Exit 6/29/83 1400	19.60	0.65	45.03	3.38	18.65	0.37	11.52	0.16	0.14	ND	ND	16.0	7.0	ND	ND	7.4	-
		HG-24 Exit 6/29/83 1545	48.96	0.08	1.44	5.34	13.22	0.49	29.59	0.14	0.24	ND	ND	29.6	6.2	ND	ND	4.2	-
		HG-25 Exit 6/30/83 1915	18.95	0.83	45.94	2.51	21.71	0.23	9.06	0.16	0.11	ND	ND	4.0	1.0	ND	ND	7.0	-
SULFIDATION	T005	HG-26 Exit 6/30/83 0015	37.53	1.82	7.84	5.71	15.42	0.57	30.10	0.24	0.26	ND	ND	4.0	2.0	ND	0.1	9.91	0.2
		HG-27 Exit 6/30/83 0415	42.44	1.00	4.48	5.32	15.26	0.50	30.13	0.17	0.21	ND	ND	56.8	5.4	ND	3.7	11.2	-

ND = Not Detectable

- = Analysis not taken

\* = SO<sub>2</sub> is suspect due to possible solubility in condensed water† = H<sub>2</sub>S Detectable level 0.2 ppm

NOTE: All analysis other than sulfur analysis is in units of % by volume on a dry gas basis. Sulfur analysis is in units of ppm by volume.

Table 2  
HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS, TESTS 001 to 005

	Sample No.	Date	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	IC <sub>4</sub>	nC <sub>4</sub>	PPM H <sub>2</sub> S	PPM COS	PPM CH <sub>3</sub> SH	PPM CS <sub>2</sub>	PPM thio	PPM NH <sub>3</sub>	PPM H <sub>2</sub> O	
	FN5	S-4 6/24/83	16.57%	.77%	47.91%	3.17%	22.66%	.32%	7.79%	.15%	.15%	ND	ND	3,001.8	282.1	ND	6.1	NO	NO	555.3	
	FN10	S-4 6/24/83	16.57%	.76%	47.35%	3.22%	23.79%	.31%	7.18%	.16%	.15%	ND	ND	3,106.5	260.5	ND	3.8	NO	NO	864.0	
	FN15	S-4 6/25/83	16.88%	.73%	48.81%	3.00%	22.90%	.29%	6.64%	.16%	.10%	ND	ND	2,855.0	296.8	ND	6.5	NO	NO	1,793.9	
	FN18	S-4 6/25/83	17.44%	.76%	47.92%	3.21%	24.96%	.31%	4.66%	.15%	.10%	ND	ND	3,162.9	301.3	1.4	36.0	21.0	ND	1,955.9	
COLLIDATION TEST 1001	FN49	S-4 6/26/83	13.5	16.67%	.61%	47.90%	3.09%	23.25%	.30%	7.39%	.15%	.14%	ND	ND	3,496.1	245.8	ND	14.7	3.0	ND	1,483.0
COLLIDATION TEST 1002	FN54	S-4 6/27/83	15.94%	.61%	48.63%	3.06%	23.44%	.32%	7.19%	.17%	.14%	ND	ND	4,187.3	335.1	ND	15.5	2.0	ND	1,956.7	
COLLIDATION TEST 1003	FN57	S-4 6/27/83	16.33%	.65%	47.94%	3.15%	23.84%	.32%	6.92%	.18%	.16%	ND	ND	4,221.8	286.8	ND	16.2	ND	ND	1,931.6	
COLLIDATION TEST 1004	FN61	S-4 6/27/83	1045	16.44%	.70%	48.00%	3.08%	23.48%	.31%	7.19%	.17%	.15%	ND	ND	4,180.2	269.0	ND	16.7	3.0	ND	1,961.0
COLLIDATION TEST 1005	FN65	S-4 5/27/83	1255	16.16%	.58%	48.36%	2.99%	23.55%	.31%	7.25%	.16%	.14%	ND	ND	3,867.4	274.0	1.5	13.9	2.8	ND	1,818.0
COLLIDATION TEST 1006	FN69	S-4 6/27/83	1445	16.44%	.64%	48.10%	2.79%	24.25%	.29%	6.73%	.15%	.13%	ND	ND	3,357.9	280.4	ND	13.0	2.0	ND	1,803.0
	FN99	S-4 6/29/83	1530	18.66%	.58%	43.80%	3.69%	24.91%	.37%	7.13%	.16%	.25%	ND	ND	3,104.2	413.2	1.5	13.7	3.0	ND	1,932.0
	FN101	S-4 6/30/83	1635	40.82%	.12%	1.52%	6.05%	23.46%	.51%	26.56%	.21%	.25%	ND	ND	5,369.1	302.1	2.6	7.9	58.0	ND	2,109.0
	FN104	S-4 6/30/83	0618	41.05%	.08%	1.58%	5.96%	23.21%	.53%	26.37%	.21%	.24%	ND	ND	5,453.3	283.4	6.3	15.6	5.9	ND	2,478.5
	FN108	S-4 6/30/83	0905	41.20%	.10%	1.34%	6.22%	24.34%	.55%	25.24%	.23%	.25%	ND	ND	5,244.0	256.1	3.3	11.7	2.6	ND	2,301.0
	FN112	S-4 6/30/83	1110	40.63%	.17%	1.08%	6.08%	24.33%	.58%	26.19%	.20%	.27%	ND	ND	5,218.9	240.4	3.1	9.3	5.0	ND	2,356.0
	FN116	S-4 6/30/83	1300	40.89%	.18%	1.19%	5.74%	26.81%	.51%	23.75%	.18%	.24%	ND	ND	5,273.4	283.8	4.4	5.5	5.1	ND	2,195.6

NOTES:

ND = Not Detectable

All analysis other than sulfur is in units of % by volume on a dry gas basis. Sulfur analysis is in units of ppm by volume.

Table 3  
MINERAL ANALYSIS AFTER TEST 005  
ZINC FERRITE L-1504 - UNITED CATALYSTS

BED HEIGHT (INCHES)	HEMATITE $\text{Fe}_2\text{O}_3$	FRANKLINITE $\text{ZnFe}_2\text{O}_4$ AND/OR MAGNETITE $\text{Fe}_3\text{O}_4$ (4)	ZINCITE $\text{ZnO}$	ALPHA $\text{ZnS}$	BETA $\text{ZnS}$	PYRRHOTITE $\text{FeS}$
PERCENT TII (3)						
0 (1)	-	10	Trace	13	51	25
6	-	4	-	12	54	29
16	-	18	Trace	19	36	27
23	-	10	-	19	42	28
26	-	19	Trace	24	25	32
36	-	68	14	10	7	-
46 (2)	-	70	18	9	4	-
Fresh Sorbent	4	89	6	-	-	-

NOTES:

- (1) Bottom/Inlet during sulfidation -- Outlet during regeneration.
- (2) Top/Outlet during sulfidation — Inlet during regeneration.
- (3) Percent TII = Percent Total Integrated Intensity: Directly proportional to the concentration of the crystalline phase. Amorphous is not accounted for.
- (4) Franklinit and magnetite have the same crystal structure and, therefore, cannot be readily distinguished by the diffraction pattern.

TABLE 4

SORBENT ANALYSIS AFTER TEST 005, ZINC FERRITE L-1504, UNITED CATALYSTS

Bed Height (Inches)	Total Carbon (% Wt)	Total Sulfur (% Wt)	BET Surface Area (Sq M/G)	Skeletal Density (G/CC)(3)	Porosity % (5)	Crush Strength (Kg DWL) ± S.D.(7)	Skeletal Density (G/CC)(8)	Porosity % (9)
0(1)	1.97	29.88	1.43	4.37	0.93	7.0±3.3	-	-
6	1.88	31.41	1.49	4.55	0.93	8.4±3.5	-	-
16	2.58	27.78	2.09	4.26	1.68	7.3±3.5	3.84	27.9
23	2.89	25.92	2.43	4.33	1.96	8.1±3.1	-	-
26	3.48	28.97	2.24	4.34	2.26	4.4±2.1	3.84	36.1
36	2.37	7.29	2.30	4.86	1.76	4.2±2.6	-	-
46(2)	3.27	8.60	3.11	5.14	2.75	2.4±1.8	4.57	50.2
--METC FRESH SORBENT --UCI	0	0.13	3.13	6.16	2.59	6.3±2.8	-	-
ABSORBER FINES	6.93	26.29		85(4)	-	7.2	-	60.6(6)


## NOTES:

1. Bottom/Inlet during sulfidation - Outlet during regeneration
2. Top/Outlet during sulfidation - Inlet during regeneration
3. Skeletal Density by Helium Pycnometry
4. Bulk Density (Lbs/Cu Ft)
5. Porosity by Nitrogen Adsorption for pores up to 600Å diameter
6. Porosity by Mercury Porosimetry for pores down to 30Å diameter
7. Crush strength data are average and standard deviation of 15 measurements
8. Skeletal density by mercury porosimetry
9. Porosity by mercury porosimetry for pores down to 120Å diameter.

Table 5

DATE: 8/27/83  
 SAMPLE: CYCLONE #2 GRINDLEY 83-654  
 ELECTROLYTE: ISOTON  
 DISPERSANT: LOMAR D  
 EQUIPMENT: TH 11  
 APERTURES: 280  
 OPERATOR: REC

CH.#	SIZE	DIFF	CUR
		VOL %	VOL %
1	4	0	100
2	5.04	1.7	100
3	6.35	2.6	99.3
4	8	4.3	95.7
5	10.08	7	91.4
6	12.7	9.4	84.4
7	16	10.5	75
8	20.16	9.9	64.5
9	25.4	14.1	54.6
10	32	13.7	48.5
11	40.32	13.3	26.8
12	50.8	9.7	13.6
13	64	2.7	4.6
14	80.63	1.4	2.1
15	101.59	.8	.7
16	128	0	0



Total Carbon 83.12 ZWT  
 Ash 10.23 ZWT  
 Sulfur 1.00 ZWT

## \*\*\*\*\* VOLUME % STATISTICS \*\*\*\*\*

MEAN:	25.52 UM
MEDIAN:	27.37 UM
MODE:	31.32 UM
STANDARD DEVIATION:	1.89 UM
SKEWNESS:	.94 NEGATIVE
KURTOSIS:	1.51 PLATYKURTIC

Table 6  
PARTICULATE SAMPLING DATA  
HOT GAS DESULFURIZATION TEST UNIT

Run #	Time	Sample Duration Minutes	Sampling Flow Rate liters/min.	Particle loading		Mean particle size	
				Inlet	Exit	Inlet	Exit
T001	22:00 Hours 6/23/83	1	13	-	-	10.4	-
T003	16:52 Hours 6/26/83	30	13	1.6	-	15.3	-
T003	18:04 Hours 6/26/83	30	13	-	3.9	-	2.7
T003	12:40 Hours 6/27/83	30	13	-	4.6	-	2.3
T003	14:25 Hours 6/27/83	30	13	0.3 <sup>(1)</sup>	-	6.0	-
T005	11:22 Hours 6/29/83	30	13	0.3	-	2.9	-
T005	16:06 Hours 6/29/83	30	11	-	2.8 <sup>(2)</sup>	-	3.8

(1) Carbon 15.5% Ash 82.79%

(2) Carbon 2.79% Ash 97.19%

e 7  
Particle Distribution

DATE: 7/27/83

SAMPLE: DESULFUR BAGNELL DE#2 83-696

ELECTROLYTE: ISOTON

DISPERSANT: LOMAR D

EQUIPMENT: TA 11

APERTURES: 280

OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
1	.5	0	100
2	.63	3.1	100
3	.79	2.8	96.9
4	1	2	94.1
5	1.26	3.6	91.1
6	1.59	3.8	87.5
7	2	3.9	83.7
8	2.52	4.3	79.8
9	3.17	4.7	75.5
10	4	5.3	70.8
11	5.04	5.4	65.5
12	6.35	4.3	60.1
13	8	4.9	55.8
14	10.08	6.1	50.9
15	12.7	6.6	44.8
16	16	7.4	38.2
17	20.16	7.1	30.8
18	25.4	8.2	23.7
19	32	6.2	15.5
20	40.32	3.9	9.3
21	50.8	7	6.1
22	64	6	5.4
23	80.63	1	4.8
24	101.59	3.5	4.7
25	128	1.3	1.2

T001 INLET

22.00 HOURS

6/23/83

\*\*\*\*\* VOLUME % STATISTICS \*\*\*\*\*

MEAN:	8.91 UM
MEDIAN:	10.43 UM
MODE:	27.54 UM
STANDARD DEVIATION:	3.7 UM
SKEWNESS:	.79 NEGATIVE
KURTOSIS:	783.48 LEPTOKURTIC




Table 8  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #3 BAGNELL 83-697  
ELECTROLYTE: ISOTON  
DISPERSANT: LONAR D  
EQUIPMENT: TA 11  
APERTURES: 280  
OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
*****			
1	4	0	100
2	5.04	.9	100
3	6.35	1.8	99.1
4	8	5	97.3
5	10.08	14.7	92.3
6	12.7	34.8	77.8
7	16	32.2	42.8
8	20.16	7.9	16.8
9	25.4	1.8	2.7
10	32	.8	.9
11	40.32	.3	.3
12	50.8	.1	0
13	64	0	0
14	80.63	0	0
15	101.59	0	0
16	128	0	0

T003 INLET  
16.52 HOURS  
6/26/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 15.09 UM  
MEDIAN: 15.27 UM  
MODE: 15.58 UM  
STANDARD DEVIATION: 1.34 UM  
SKEWNESS: 1 NEGATIVE  
KURTOSIS: 1.04 PLATYKURTIC




Table 3  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #4 BAGNELL 280 83-698  
ELECTROLYTE: ISOTON  
DISPERSANT: LOMAR D  
EQUIPMENT: TA 11  
APERTURES: 280  
OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %

1	.5	0	100
2	.63	0	100
3	.79	3.7	100
4	1	6.9	96.3
5	1.26	11.4	89.4
6	1.59	12.5	78
7	2	12.6	65.5
8	2.52	10.3	52.9
9	3.17	12	42.6
10	4	9.9	30.6
11	5.04	5.4	20.7
12	6.35	2.5	15.3
13	8	4.6	12.8
14	10.08	2.4	8.2
15	12.7	.8	5.8
16	16	.5	5
17	20.16	.6	4.5
18	25.4	.9	3.9
19	32	.9	3
20	40.32	1.1	2.1
21	50.8	.3	1
22	64	.2	.7
23	80.63	0	.5
24	101.59	0	.5
25	128	.5	.5

T003 OUTLET

18.04 HOURS

6/26/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 3.12 UM  
MEDIAN: 2.7 UM  
MODE: 2.02 UM  
STANDARD DEVIATION: 2.4 UM  
SKENNESS: 2.49 POSITIVE  
KURTOSIS: 26.75 LEPTOKURTIC




Table 10  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #5 BAGNELL 280 83-699  
ELECTROLYTE: ISORON  
DISPERSANT: LOMAR D  
EQUIPMENT: TA 11  
APERTURES: 280  
OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
*****			
1	.5	0	100
2	.63	0	100
3	.79	1.8	100
4	1	4.2	98.2
5	1.26	12.3	94
6	1.59	19.5	81.7
7	2	21.1	62.2
8	2.52	16.1	41.1
9	3.17	13	25
10	4	6.2	12
11	5.04	1.9	5.8
12	6.35	.9	3.9
13	8	1.3	3
14	10.08	.4	1.7
15	12.7	.3	1.3
16	16	.2	1
17	20.16	.2	.8
18	25.4	.2	.6
19	32	.1	.4
20	40.32	.1	.3
21	50.8	0	.2
22	64	0	.2
23	80.63	0	.2
24	101.59	0	.2
25	128	0	.2

T003 OUTLET  
12.40 HOURS  
6/27/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN:	2.42 UM
MEDIAN:	2.29 UM
MODE:	2.12 UM
STANDARD DEVIATION:	1.68 UM
SKEWNESS:	1.23 POSITIVE
KURTOSIS:	1.83 PLATYKURTIC




Table 11  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #6 BASHNELL 50 83-700  
ELECTROLYTE: ISOTON  
DISPERSANT: LOMAR D  
EQUIPMENT: TA 11  
APERTURES: 50  
OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
*****			
1	.5	0	100
2	.63	0	100
3	.79	.9	100
4	1	1.2	99.1
5	1.26	2.2	97.9
6	1.59	3.1	95.7
7	2	4.6	92.6
8	2.52	5.5	88
9	3.17	9.9	82.5
10	4	13.1	72.6
11	5.04	13.2	59.5
12	6.35	14.1	46.3
13	8	15.6	32.2
14	10.08	9.6	16.6
15	12.7	4.1	7
16	16	2.9	2.9

T003 INLET

14.25 HOURS

6/27/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 5.57 UM  
MEDIAN: 5.96 UM  
MODE: 8.38 UM  
STANDARD DEVIATION: 1.88 UM  
SKEWNESS: .87 NEGATIVE  
KURTOSIS: 1.61 PLATYKURTIC




Table 12  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #7 BAGNELL 50 83-701  
ELECTROLYTE: ISOTON  
DISPERSANT: LOMAR D  
EQUIPMENT: TA 11  
APERTURES: 50  
OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
1	.5	0	100
2	.63	0	100
3	.79	.2	100
4	1	.4	99.8
5	1.26	3.4	99.4
6	1.59	9.6	96
7	2	21.1	86.4
8	2.52	29.2	65.3
9	3.17	16.8	36.1
10	4	14.3	19.3
11	5.04	4	5
12	6.35	.6	1
13	8	.4	.4
14	10.08	0	0
15	12.7	0	0
16	16	0	0

T005 INLET  
11.22 HOURS  
6/29/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 2.89 UM  
MEDIAN: 2.84 UM  
MODE: 2.76 UM  
STANDARD DEVIATION: 1.42 UM  
SKEWNESS: 1 POSITIVE  
KURTOSIS: 1.05 PLATYKURTIC




Table 13  
Particle Distribution

DATE: 7/27/83  
SAMPLE: DE #8 BAGNELL 50 83-702  
ELECTROLYTE: ISOTON  
DISPERSANT: LOHAR D  
EQUIPMENT: TA 11  
APERTURES: 50  
OPERATOR: REC

CH. #	SIZE	DIFF	CUM
		VOL %	VOL %
1	.5	0	100
2	.63	0	100
3	.79	1.9	100
4	1	3.7	98.1
5	1.26	7.6	94.4
6	1.59	9.4	86.8
7	2	9.4	77.4
8	2.52	8.4	68
9	3.17	11.9	59.6
10	4	13.5	47.7
11	5.04	13	34.2
12	6.35	10.2	21.2
13	8	7.9	11
14	10.08	1.7	3.1
15	12.7	1.5	1.4
16	16	0	0

T005 OUTLET  
16.06 HOURS  
6/29/83

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 3.59 UM  
MEDIAN: 3.83 UM  
MODE: 4.78 UM  
STANDARD DEVIATION: 1.92 UM  
SKEWNESS: .96 NEGATIVE  
KURTOSIS: 1.48 PLATYKURTIC




Table 14

## AQUEDUS PHASE AT HOT GAS DESULFURIZATION INLET, TESTS 001 - 005

TEST TYPE AND NUMBER	LAB SAMPLE NO.	LOCATION	DATE TIME	ANIONS, CATIONS AND METALS																
				Zn ppm	Hg ppm	Cr ppm	As ppm	Se ppm	Fe ppm	Al ppm	Ni ppm	K ppm	Na ppm	NH <sub>4</sub> ppm	F ppm	Cl ppm	PO <sub>4</sub> ppm	Br ppm	NO <sub>3</sub> ppm	SO <sub>4</sub> ppm
T001	27496	S-4	6/24/83 0400	<0.1	< 0.2	0.989	3.18	2.47	13.9	6.12	8.62									
T002	27501	S-4	6/25/83 1200	<0.1	< 0.2	1.42	0.75	2.35	12.0	2.62	5.01	15.6	35.8	7439	168	5259	13.9	67.7	< 2	857
T004	27524	S-4	6/28/83 1800	<0.1	< 0.2	0.110	0.442	<1.0	8.14	10.6	0.322	12.1	28.6	6277	73.3	3541	<3	41.7	< 2	257
	27525	S-4	6/28/83 1800	<0.1	0.94	0.093	1.33	2.11	7.62	10.35	0.370	13.8	54.2	6596	74.9	3393	<3	42.7	< 2	255
	27528	S-4	6/29/83 0200	<0.1	2.17	<0.007	0.551	1.62	4.57	1.50	0.497	8.34	1.0	6384	34.9	1294	<3	20.8	< 2	324
T005	27534	S-4	6/29/83 2330	<0.1	< 0.2	<0.007	2.08	2.22	5.03	5.32	0.164	16.3	8.5	3173	99	2552	10.7	28.5	299	2065
	27539	S-4	6/30/83 1100	<0.1	< 0.2	<0.007	0.504	1.69	3.55	2.80	< 0.002	9.48	57.1	7872	27.8	1000	<3	13.5	< 2	151
	27540	S-4	6/30/83 1500	<0.1	< 0.2	<0.007	0.466	4.29	3.09	1.66	< 0.02	9.28	4.8	2538	28.8	620	<3	12.4	28.6	360
	27543	S-4	6/30/83 2100	<0.1	< 0.2	<0.007	1.01	1.19	3.00	3.23	0.225	15.3	56.6	6626	41.1	2296	<3	17.2	< 2	152

NOTES:

1. Above analysis was made on samples taken at the sidestream inlet, whether gas was flowing to the test unit or not (i.e., during regeneration).
2. Sampling location S-4 is after gastifier cyclone and before humidifier.
3. Metals determined by atomic absorption/atomic emission spectroscopy at DOE/METC.
4. Anions and cations determined by ion chromatography at DOE/METC.

Table 15  
TAR ULTIMATE ANALYSIS  
AT HOT GAS DESULFURIZATION INLET

TEST TYPE	TEST NO.	SAMPLE LOCATION	LAB SAMPLE NO.	TIME/ DATE	ASH	S	H	T.C.	N	O	BTU
Sulfidation	T001	S-4	27943	0400 6/24/83	0.26	1.15	7.35	70.85	1.92	18.47	13060
Sulfidation	T003	S-4	28193	1300-1400 6/27/83	0.16	1.11	7.34	75.56	2.53	13.3	14467
Sulfidation	T005	S-4	27948	1100 6/30/83	0.61	1.04	7.65	65.36	1.74	23.60	14202
Sulfidation	T005	S-4	27949	1500 6/30/83	0.45	1.44	8.33	61.81	1.52	26.45	13836

NOTES:

1. Sampling location S-4 is after gasifier cyclone and before humidifier.
2. Oxygen obtained by difference and includes oxygen in the moisture present.
3. Total sulfur analysis obtained by ASTM D-3177-75 at DOE/METC.
4. Carbon and hydrogen analysis by ASTM D-3178-73 at DOE/METC.
5. Nitrogen analysis by ASTM D-3179-73 at DOE/METC.
6. Ash analysis by ASTM D-3174 at DOE/METC.
7. BTU content analysis by ASTM D-2015 at DOE/METC.

Table 16

## AQUEOUS PHASE CONDENSATE AT HOT GAS DESULFURIZATION E11T, TESTS 001-005

TEST TYPE AND NUMBER		HGD SAMPLE NO.	DATE TIME	ANIONS, CATIONS AND METALS															
				Zn ppm	Hg ppm	Cr ppm	As ppm	Se ppm	Fe ppm	Al ppm	NH ppm	K ppm	Mg. ppm	NH <sub>4</sub> ppm	F ppm	Cl ppm	PO <sub>4</sub> ppm	Br ppm	NO <sub>3</sub> ppm
SULFUR- ATION	T001	LC1 0825	6/24/83 10.73	<0.2	0.632	0.429	<1.0	5.20	0.258	0.248	1.69	53.0	16383	48.7	1847	<3	4.5	<2	34.5
		LC2 0230	6/25/83 0.590	<0.2	2.10	0.578	<1.0	9.42	1.71	4.40	29.12	54.0	7573	418	13289	5.6	42.7	<2	44.6
REGENER- ATION	T002	LC3 2130	6/25/83 9.42	<0.2	0.048	0.524	<1.0	1.60	0.824	0.284	9.72	19.1	4055	106	4121	<3	32.3	6.2	101
		LC4 0130	6/26/83 0.77	<0.2	0.880	0.69	1.99	36.8	0.49	2.70	4.50	6.1	268	38.5	496	<3	20.8	1067	521
REGENERATION	T004	LC5 0530	6/26/83 1.48	8.56	11.56	0.661	<1.0	157.4	0.792	4.88	4.59	21.1	488	33.4	641	<3	29	1740	1053
		LC6 0515	6/28/83 0.48	<0.2	0.20	0.96	2.73	1.66	<0.02	0.10	-	13.6	1019	26.8	223	<3	<4	34	187
		LC7 0830	6/28/83 6.15	<0.2	>10.0	0.79	3.55	209	1.69	12.8	-	15.5	798	20.0	2300	<3	45.7	<4	593
		LC8 1230	6/28/83 1.75	<0.2	16.5	0.53	3.36	>10.0	1.51	4.58	-	13.6	663	50.7	2080	<3	62.4	200	1978
		LC9 1630	6/28/83 0.694	1.60	9.88	0.665	<1.0	7.35	0.695	2.76	1.11	12.7	273	12.9	488	<3	37.9	96.2	1275

## NOTES:

1. Sampling location is at condenser CIC knockout.
2. Metals determined by atomic absorption/atomic emission spectroscopy at DOE/METC
3. Anions and cations determined by ion chromatography at DOE/METC.

Table 17  
COMPOSITE ANALYSIS OF EXIT AQUEOUS CONDENSATE DURING SULFIDATION

COMPONENT	AIR BLOWN (RUNS 001, 003, and 005)	OXYGEN BLOWN (RUN 005)	
	IHI KEMRON (mg/l)	DOE/METC (ppm)	DOE/METC (ppm)
Chloride, dissolved (Cl)	1000	1382	545
Cyanide, total (CN)	23		
Nitrogen, Ammonia, total (N)	17,000	10,709	6209
Phenolics, total (Phenol)	33		
Sulfate ( $\text{SO}_4$ )	200	264	81.0
Sulfide (S)	96		
Sulfite ( $\text{SO}_3$ )	230		
Fluoride (F)	50	47.5	30.3
Thiocyanate (SCN)	180		
Antimony, total (Sb)	-		
Arsenic, total (As)	6.75	1.45	0.191
Iron, total (Fe)	16	24.64	6.51
Lead, total (Pb)	<0.05		
Calcium, total (Ca)	7.5		
Potassium, total (K)	5.0	7.57	1.13
Vanadium, total (V)	<0.4	<0.05	0.048
Zinc, total (Zn)	1.1	1.84	0.046
Sodium, total (Na)	3.0	11.0	2.33
Chromium (Cr)		3.13	0.305
Nickel (Ni)		0.629	0.101
Phosphate ( $\text{PO}_4$ )		<3	<3
Bromine (Br)		<4	<4
Nitrate ( $\text{NO}_3$ )		18.6	<2
Aluminum (Al)		0.155	<0.02
Selenium (Se)		0.215	0.056
Mercury (Hg)		7.31	1.73

NOTES:

1. Sampling location is at condenser CIC knockout.
2. DOE/METC metals analysis was by atomic absorption/atomic emission spectroscopy.
3. DOE/METC anions and cations determined by ion chromatography.

Table 18

COMPOSITE ANALYSIS OF EXIT AQUEOUS CONDENSATE FROM  
REGENERATION RUNS 002 AND 004

COMPONENT	DOE/METC RUN 002 & 004 (ppm)	DOE/METC PLANT STEAM (ppm)
Zinc (Zn)	0.889	0.582
Chromium (Cr)	0.297	<0.02
Iron (Fe)	6817	0.351
Nickel (Ni)	0.861	<0.8
Potassium (K)	7.83	0.150
Sodium (Na)	10.79	0.293
Calcium (Ca)	34.56	0.873
Vanadium (V)	0.360	<0.05
Ammonia (NH <sub>4</sub> )	458	0.54
Fluoride (F)	29.4	0.11
Chloride (Cl)	1030	1.02
Phosphate (PO <sub>4</sub> )	<3	<0.03
Bromine (Br)	21.5	<0.03
Nitrate (NO <sub>3</sub> )	<2	1.12
Sulphate (SO <sub>4</sub> )	829	2.38
Aluminum (Al)	1.79	0.169
Selenium (Se)	<0.01	<0.01
Mercury (Hg)	86.3	<0.2
Arsenic (As)	<0.01	<0.01

## NOTES:

1. Sampling location is at condenser CIC knockout.
2. DOE/METC metals analysis was by atomic absorption/atomic emission spectroscopy.
3. DOE/METC anions and cations determined by ion chromatography.

Table 19  
COMPOSITE ULTIMATE ANALYSIS OF EXIT TAR CONDENSATE  
DURING SULFIDATION (GASIFIER RUN 101)

COMPONENT	AIR-BLOWN ARKWRIGHT COAL (RUNS 001, 003, 005)	OXYGEN-BLOWN ARKWRIGHT COAL (RUN 005)	
	IHI KEMRON WT %	DOE/METC WT %	DOE/METC WT %
Ash	0.023	0.29	0.12
S	2.11	2.11	3.20
H	6.64	7.63	7.23
N	1.87	1.08	1.00
O	5.87	15.51	11.77
Total Carbon	83.49	73.38	76.68
BTU/lb	15,289	15,111	15,717

NOTES:

1. Oxygen obtained by difference and includes oxygen in moisture.

Table 20  
TRACE COMPONENTS IN EXIT GAS DURING SULFIDATION

COMPONENT	AIR BLOWN (RUNS 001, 003, and 005)		OXYGEN BLOWN (RUN 005)
	IHI KEMRON ppmw	DOE/METC ppmw	DOE/METC ppmw
Chloride (Cl)	45	62	289
Cyanide, total (CN)	1		
Nitrogen, Ammonia, total (N)	758	478	329
Phenolics, total (Phenol)	1.5		
Sulfate (SO <sub>4</sub> )	8.9	12	43
Sulfide (S)	4		
Sulfite (SO <sub>3</sub> )	10		
Fluoride (F)	2.2	2	16
Thiocyanate (SCN)	8		
Antimony, total (Sb)	-		
Arsenic, total (As)	.3	.06	0.10
Iron, total (Fe)	.7	1	3.5
Lead, total (Pb)	<.002		
Calcium, total (Ca)	.3		
Potassium, total (K)	.2	.3	0.6
Vanadium, total (V)	<.02	<.002	0.03
Zinc, total (Zn)	.05	.08	0.02
Sodium, total (Na)	.13	.5	1.23
Chromium (Cr)		.1	0.16
Nickel (Ni)		.03	0.05
Phosphate (PO <sub>4</sub> )		<.1	<1.6
Bromine (Br)		<.2	<2.1
Nitrate (NO <sub>3</sub> )		.8	<1.1
Aluminum (Al)		.007	<0.011
Selenium (Se)		.01	0.03
Mercury (Hg)		.33	0.92

NOTES:

1. Sampling location is at condenser CIC knockout.
2. DOE/METC metals analysis was by atomic absorption/atomic emission spectroscopy.
3. DOE/METC anions and cations determined by ion chromatography.
4. Concentration in gas phase calculated based on analysis in aqueous phase.

Table 21  
TRACE COMPONENTS IN EXIT GAS DURING REGENERATION

COMPONENT	DOE/METC RUN 002 & 004	DOE/METC PLANT STEAM
	ppmw	ppmw
Zinc (Zn)	0.72	0.582
Chromium (Cr)	0.24	<0.02
Iron (Fe)	5556	0.351
Nickel (Ni)	0.70	<0.8
Potassium (K)	6.38	0.150
Sodium (Na)	8.79	0.293
Calcium (Ca)	28.2	0.873
Vanadium (V)	0.3	<0.05
Ammonia (NH <sub>4</sub> )	373	0.54
Fluoride (F)	24	0.11
Chloride (Cl)	839	1.02
Phosphate (PO <sub>4</sub> )	<2.4	<0.03
Bromine (Br)	17.5	<0.03
Nitrate (NO <sub>3</sub> )	<1.6	1.12
Sulphate (SO <sub>4</sub> )	675	2.38
Aluminum (Al)	1.45	0.169
Selenium (Se)	<0.008	<0.01
Mercury (Hg)	70.3	<0.2
Arsenic (As)	<0.008	<0.01

NOTES:

1. Sampling location is at condenser CIC knockout.
2. DOE/METC metals analysis was by atomic absorption/atomic emission spectroscopy.
3. DOE/METC anions and cations determined by ion chromatography.
4. Concentration in gas phase calculated based on analysis in aqueous phase.

## APPENDIX F

### Sidestream Testing - Gasifier Run 102

Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 102

#### Introduction

The high-temperature, sidestream desulfurization unit (1) was operated for a second series of tests, during fixed-bed gasifier Run No. 102 (2,3), between September 20 and October 2.

The principal purpose of these tests was to provide hot desulfurized gas to a combustion test unit to investigate the feasibility of using it as a fuel for heat engines (4).

#### Operation of Sidestream Test Unit

The sidestream unit was operated in two periods with different batches of the zinc ferrite sorbent. During the first period the gasifier was fed with Arkwright coal, and during the second, with Blacksville coal briquettes. The gasifier was operated in the air-blown mode. The operational schedule is shown in Figure 1.

- First Period

The reactor contained the customary 20.4 kg of sorbent but, contrary to the first test series, reactor furnace temperatures were set at 1,100°F, compared to 1,000°F previously, which, it was hoped, would increase the sulfur absorption rate and result in longer times to breakthrough. Gasifier pressure was about 150 psig.

The unit was operated for two short absorption spells (Test Nos. 006 and 008), with an intermediate regeneration (Test No. 007). Average operating parameters are shown on the ADACS flow schematics in Figures 2, 3, 4A, 4B, and 4C.

In Test No. 006, gas was passed through the unit at a space velocity of  $2,000 \text{ h}^{-1}$  for about an hour, which was then increased to  $8,000 \text{ h}^{-1}$ , the additional gas going to the combustor. After a further 2 hours,  $\text{H}_2\text{S}$  breakthrough began and gas to the combustor was cut off. A renewed breakthrough occurred after 2 more hours at a space velocity of  $2,000 \text{ h}^{-1}$ . Reactor temperatures, pressure drop, and gas flow rates are shown in Figures 5, 6, and 7, respectively. Initially there was a temperature rise in the reactor of about 100°F, falling to about 50°F later, attributed to the exothermic partial reduction of the sorbent and the "shift" reaction. The reactor pressure drop gradually increased and exceeded the maximum instrument reading of about 160 inches of water at the higher space velocity, well above the bed lifting pressure.

The sorbent was regenerated in Test No. 007 for about 10 hours. Because of the low sulfur loading it was found necessary to increase the air/steam ratio above normal. Nonetheless, temperatures barely reached

1,300°F and pressure drop on completion still exceeded the instrument maximum. Reactor temperatures, pressure drop and flow rates are shown in Figures 8, 9, and 10, respectively.

In Test No. 008, gas was immediately supplied to the combustor at the same conditions as in Test No. 006. H<sub>2</sub>S breakthrough again occurred after about 2 hours. Gas to the combustor was cut off and the unit continued on-stream at the lower space velocity of 2,000 h<sup>-1</sup> for a further 4 hours until a renewed breakthrough occurred. At this point the reactor pressure drop exceeded 50 psig, based on unit inlet and outlet pressure indicators, and it was decided to replace the sorbent before carrying out further tests. The sorbent was found to have agglomerated to a great extent, especially at the reactor exit, apparently because of coke formation and the high differential pressures. Reactor temperatures, pressure drop (inlet and outlet pressures) and flow rates are shown in Figures 11, 12, and 13, respectively.

- Second Period

For this period the reactor was refilled with fresh sorbent. Reactor furnace temperatures were set at 1,000°F, a temperature which had given lower reactor pressure drops previously. Gasifier pressure was about 100 psig.

Two absorption spells (Test Nos. 009 and 011) and two regenerations (Test Nos. 010 and 012) were carried out. Average operating parameters are shown on the ADACS flow schematics in Figures 14, 15, 16, and 17.

In Test No. 009, after an initial short time at 2,000 h<sup>-1</sup>, the space velocity was stepped up to 5,000 h<sup>-1</sup>; the additional gas flowed to the combustor. This flow was half that in Test Nos. 006 and 008, to provide a longer on-stream time to breakthrough and a more acceptable reactor pressure drop. Breakthrough of H<sub>2</sub>S occurred after about 6 hours, when the pressure drop was about 6 psig. Upon cutting off the flow to the combustor, reactor pressure drop fell to 1.5 psig. A renewed breakthrough occurred after a further hour, when the pressure drop had increased to 1.75 psig. Reactor temperatures, pressure drop, and flow rates are shown in Figures 18, 19, and 20.

The sorbent was regenerated in Test No. 010 by the regular procedure and reactor pressure drop returned to approximately its original level. Reactor temperatures, pressure drop, and flow rates are shown in Figures 21, 22, and 23.

In Test No. 011 no gas was supplied to the combustor, gas flow through the reactor being at a space velocity of 2,000 h<sup>-1</sup> throughout. H<sub>2</sub>S breakthrough occurred after about 19 hours. Reactor pressure drop rose from 0.5 psi to 1 psi after 10 hours and then more rapidly to about 6 psi finally, exceeding the bed lifting pressure. Reactor temperatures, pressure drop, and flow rate are shown in Figures 24, 25, and 26.

A second regeneration was carried out in Test No. 012 and the sorbent removed. No agglomeration was found. Reactor temperatures, pressure drop, and flow rates are shown in Figures 27, 28, and 29.

## Results

- Data Summary

The various process conditions and data collected in Test Nos. 006 to 012 are summarized in Figures 30 to 36.

- Absorption of Sulfur Compounds

The hydrogen sulfide concentrations in exit gas from the unit during Test Nos. 006, 008, 009, and 011, measured by both detector tube and baseline gas chromatograph, are plotted in Figures 37 to 40; SO<sub>2</sub> levels, measured by detector tube, are also shown occasionally. H<sub>2</sub>S levels before breakthrough are generally less than about 5 ppm. Because of the higher space velocities through the reactor, the amount of sulfur absorbed in Test Nos. 006 and 008 is less than half that found previously at a space velocity of ~ 2,000 h<sup>-1</sup>, albeit at the lower temperature of ~ 1,000°F. This indicates that resistance to diffusion of H<sub>2</sub>S into the sorbent is very significant at these conditions.

In Test Nos. 009 and 011, gas from Blacksville coal containing more H<sub>2</sub>S than that from Arkwright coal was desulfurized; breakthrough times were correspondingly shorter.

In order to provide gas to the combustion test unit for a longer time in Test No. 009 than in Test Nos. 006 and 008, the space velocity was set at ~ 5,000 h<sup>-1</sup> instead of ~ 8,000 h<sup>-1</sup>, and desulfurized gas was supplied for about 6 hours instead of for about 2 hours previously. The amount of this absorbed in Test No. 009 is about three quarters of that in Test No. 011, in which the space velocity was 2,000 h<sup>-1</sup> throughout, again showing that resistance to diffusion of H<sub>2</sub>S into the sorbent is a significant factor. In Test No. 011, H<sub>2</sub>S and SO<sub>2</sub> are initially high, as expected after a preceding regeneration. Figures 41 to 44 give baseline gas chromatograph readings for H<sub>2</sub>S, SO<sub>2</sub>, and COS in Test Nos. 006, 008, 009, and 011. H<sub>2</sub>S and SO<sub>2</sub> measurements are generally in agreement with detector tube measurements (see Figures 37 to 40) in the vicinity of the calibration points: H<sub>2</sub>S -- 3 ppm, COS -- 5 ppm, SO<sub>2</sub> -- 8 ppm. Nonlinearities in the gas chromatograph give rise to considerable departures between actual and measured values away from the calibration points. Calibration curves were constructed to make corrections in future tests.

Breakthrough of COS was found to occur roughly at the same time as H<sub>2</sub>S breakthrough. The H<sub>2</sub>S, COS, and SO<sub>2</sub> levels were corroborated at a few points by laboratory gas chromatograph analysis of grab samples of exit gas. These, together with values for methyl mercaptan, carbon disulfide and thiophene are shown in Table 1A. Thiophene was generally less than about 5 ppm.

Grab samples were also taken at the exit of the gasifier primary cyclone. The corresponding analyses of these are shown in Table 1B (5).

- Gas Analysis for Major Species

In sulfidation Test Nos. 006, 008, 009, and 011, gas to and from the desulfurization unit was analyzed in most cases for major species by Bendix on-line gas chromatographs. The measurements were averaged by ADACS statistical analysis and are tabulated in Tables 2, 3A, 3B, 3C, 4, and 5. Inlet gas was usually sampled at two points, one at the exit of the gasifier cyclone and the other at the immediate inlet to the desulfurization unit.

Exit gas was also analyzed during regeneration Test No. 010 and 012. These measurements are shown in Tables 6 and 7.

The above analyses for the unit exit gas were corroborated by laboratory gas chromatograph analysis of grab samples. These are shown in Table 8A. Corresponding analyses of grab samples taken at the exit of the gasifier primary cyclone are shown in Table 8B. Some of these samples are seen to contain excessive quantities of oxygen, which should not be more than about 1 vol. percent. An explanation may be that air in the sample bottles was not properly displaced.

Perusal of the gas analyses in the sulfidation tests indicate that the carbon monoxide shift conversion reaction is taking place. However, there is a substantial deficiency of total carbon oxides in the exit gas in relation to the inlet gas. This is presumably the result of being converted to carbon through the Boudouard reaction:  $2\text{CO} \rightarrow \text{CO}_2 + \text{C}$ .

This conclusion is substantiated by the analyses of the exit gas in the regeneration tests. It is seen to contain substantial quantities of  $\text{CO}_2$  and CO which must have been formed from carbon remaining in the sorbent after the preceding sulfidation tests.

- Sorbent Regeneration

The two batches of zinc ferrite sorbent were regenerated in Test No. 007 and Test Nos. 010 and 012, respectively, using the same procedure as previously with a steam/air volume ratio of about 80/20 in the regeneration gas. Because the amount of sulfur which had been absorbed was relatively small, the temperature of the hot regeneration zone in Test No. 007 was initially too low (see Figure 8) and it was necessary to boost the air flow some two-fold (see Figure 9).

Regeneration Test Nos. 010 and 012 were normal, the temperature of the regeneration zone reaching about 1,500°F (see Figures 21 and 27). The reactor pressure drop during Test No. 007 (Figure 9) is uncertain because of apparent malfunctioning of the differential pressure gauge. The inlet pressure exceeded the instrument limit throughout except for a short initial period, indicating that the pressure drop was still high after the regeneration was over. Figures 22 and 28 show that the reactor pressure drop in the course of regeneration Tests Nos. 010 and

012 falls to a low value, comparable to that for fresh sorbent. All the regenerations were continued until the SO<sub>2</sub> content of the dry exit gas contained less than about 0.5 vol. percent. (see Figures 31, 34, and 36).

- Reactor Pressure Drop

In contrast to the series of tests during gasifier Run No. 101, the differential pressure across the reactor was directly measured in this series of tests. Figure 6 is a plot of this pressure drop during Test No. 006. The pressure is initially low, corresponding to a space velocity of about 2,000 h<sup>-1</sup>. On increasing the space velocity to about 8,000 h<sup>-1</sup>, after about an hour, the pressure rises to about 80 inches of water and, thereafter, gradually increases until it reaches and passes the limit of the indicator. On lowering the space velocity to ~ 2,000 h<sup>-1</sup> again, pressure falls to ~ 30 inches of H<sub>2</sub>O and then gradually increases to ~ 60 inches of H<sub>2</sub>O at the end of the test. The gradual rise of pressure drop, is attributed to the combined effect of particulate deposition and coke formation in the sorbent. Gas flow rates to the combustor and flare are plotted in Figure 7.

Possibly because of an inadequate regeneration in Test No. 007, the pressure drop in Test No. 008 (see Figure 12) was very high throughout at a level of 80 psi, corresponding to a space velocity of ~ 8,000 h<sup>-1</sup>, and about 10 psi for a space velocity of ~ 2,000 h<sup>-1</sup>. Gas flow rates to the combustor and flare are shown in Figure 13.

The pressure drops during Test Nos. 009 and 011 (see Figures 19 and 25) follow the same pattern as in Test No. 006 and 008. The fluctuations during Test No. 011, which lasted for a longer time, were caused by gas surges through the reactor when dumping condensate from the exit gas condenser.

- Reactor Temperatures

In Test Nos. 006 and 008, the average reactor temperatures exceed the furnace setting of 1,100°F by up to 100°F. This is attributed mainly to the exothermic "shift" reaction (see Figures 5 and 11). In the initial stages a mildly hot zone passes through the reactor which is thought to be caused by the rapid reduction of zinc ferrite to magnetite and zinc oxide.

Test Nos. 009 and 011 (see Figures 18 and 24) follow the same pattern though the furnace setting in this case was 1,000°F.

- Sorbent Characterization

The sulfidized sorbent after Test No. 008 was sampled on removal at points along the reactor length. The results are shown in Tables 9 and 10. At the reactor inlet most of the zinc oxide has been converted to sulfide, but a significant amount remains, probably as a result of the diffusional limitations discussed above. A substantial part of the sorbent's iron content is found to be in the form of cementite (iron

carbide). At the reactor outlet the sorbent's zinc content is predominantly in the form of zinc oxide, as expected. All of the iron appears in the form of iron carbide and no magnetite is detected (see Table 9). The values in Table 9 represent total integrated intensities and, because of nonlinearities in their proportional relation to weight fraction, they should only be construed as showing rough amounts. These results from X-ray diffraction analyses are supported by the total sulfur and carbon analyses (see Table 10). Sulfur content is seen to fall from about 25 wt. percent at the reactor inlet to near zero at the reactor outlet. Carbon content varies from about 5 wt. percent at the inlet to about 8 wt. percent at the outlet. This can be explained by the fact that, at the inlet, a good part of the iron in the sorbent is in the form of pyrrhotite ( $FeS_x$ ), whereas at the outlet, no pyrrhotite is detected.

The surface area and pore volume of the sorbent, particularly towards the outlet, are significantly greater than for the fresh material (see Table 10). This is attributed to the increased porosity resulting from reduction of magnetite in the sorbent to iron and iron carbide. The increased porosity is accompanied by a significantly lower crush strength, which may be the main reason for the large amount of fines formed in the removed sorbent. The fines which passed through a No. 12 screen amounted to about a third of the total sorbent.

Characterization of the sorbent, after regeneration in Test No. 012, is shown in Tables 11 and 12. The mineral analysis (see Table 11) indicates that the sorbent is now predominantly in the form of franklinite and magnetite with minor amounts of hematite and zincite present. There appears to be some enrichment of zincite towards the top of the reactor. Analysis for total carbon and sulfur (see Table 12) shows that virtually all of the carbon, presumed to be present before the regeneration, has been burned out. However, some residual sulfur still remains, reaching up to about 2 wt. percent at the bottom of the reactor, which was the inlet during sulfidation. Most of this residual sulfur is seen to be in the form of sulfate.

The surface area and pore volume of the regenerated sorbent a little less than for fresh material. Crush strength, on average, is much the same as for fresh sorbent, though there is a significant variation with bed depth, being less at the top of the reactor where the sorbent had undergone a smaller conversion to sulfide. In contrast to Test No. 008, only about 2.5 wt. percent of fines, passing through a No. 12 screen, were found in the removed sorbent.

- Particulate Analysis

Samples of inlet and outlet gas were taken during the series of tests to characterize the particulate content (6) as described previously. The results are summarized in Table 13. Because of the short test durations it did not prove possible to sample both inlet and outlet gas in a given test. However, one inlet sample was taken in each of Test Nos. 006 and 008 (Tables 14 and 15), and one outlet sample in each of Test Nos. 009 and 011 (Tables 16 and 17). It should be recalled that during Test Nos. 006 and 008 Arkwright coal was fed to the gasifier. Table 18 shows

the size distribution of a random sample of particles removed by the primary gasifier cyclone at this time. Table 19 shows the size distribution of a similar particle sample taken when the gasifier was fed with Blacksville coal briquettes at the time of Test Nos. 009 and 011. It is noteworthy that the median particle diameter of the Arkwright dust is substantially greater than that of the Blacksville briquette dust, 64  $\mu\text{m}$  compared to 38  $\mu\text{m}$ . Ultimate analyses of the coals are given in Table 20.

The particle loadings in the hot gas stream passing through the hot gas desulfurization unit are seen to be in the range 0.3 to 0.8 g/Nm<sup>3</sup> with a smaller loading found in exit gas. Median particle size falls in the range 20  $\mu\text{m}$  to 27  $\mu\text{m}$ . It is not possible to say whether exit particle size is significantly different from entering particle size when taking into account the differing coal feeds to the gasifier. Chemical analyses (ultimate) of the particulate loadings (see Table 13) show that, though exiting particles contain a large amount of carbon, indicating that they are mostly the same as the entering particles, their larger ash content suggests that they contain some attrited sorbent bed particulate.

- Condensate Analysis

In another attempt to characterize the hot gas passing through the desulfurization unit for minor trace constituents, a number of condensate samples were taken and analyzed (5). Table 21 shows the analysis of a composite sample of water condensate from Test Nos. 006 and 008. The corresponding exit gas composition is calculated from a knowledge of the gas flow through the unit (see Figures 30 and 32).

Table 22 gives the ultimate analysis of a composite sample of the associated tar condensate. A number of samples of the tar condensate were taken from the S4 sample point at the gasifier exit. The analyses of these are shown in Table 23.

Condensate was collected during Test Nos. 006 and 008 at the inlet of the unit as part of the particulate sampling. Analyses of the water fractions of these condensates are shown in Table 24. These are averaged and translated to a gas composition for comparison with the analysis of the composite sample from Test Nos. 006 and 008 in Table 25. The comparison shows that roughly half of the halides and a fifth of the ammonia in the gas are removed, which accords with previous results. The molar proportions of ammonia and halide are approximately the same suggesting that the mechanism of ammonia removal may be through the intermediate formation of an ammoniochloride. The other metals and ions are present in relatively small amounts so that it is not possible to say with certainty to what extent their concentrations have changed. However, it seems that as much as three quarters of the alkali and alkaline earth metals are removed by the hot gas desulfurization process.

The above conclusions are corroborated by the analysis of a composite sample of condensate from regeneration Test No. 007 shown in Table 26. Corresponding analyses of condensate from regeneration Test Nos. 010

and 012 are shown in Table 27. These also exhibit an enrichment in the same constituents. The analyses of the aqueous condensates from the sulfidation tests are supported by additional analyses by IHI Kemron of spot samples taken during Test Nos. 006 and 011. These are shown in Table 28. The constituents measured vary somewhat from the ones measured at METC.

### Conclusions

A second series of tests to evaluate the performance of zinc ferrite, hot gas desulfurization sorbent in a sidestream of METC's 24 t/d fixed-bed gasifier was carried out during Run No. 102. The general performance of the sorbent was similar to that in the previous series of tests during gasifier Run No. 101 with low molecular weight sulfur compounds removed to less than about 10 ppm.

It was found that, at the higher space velocities necessary to provide gas to the METC combustion test unit, diffusional resistance resulted in the sorbent picking up less than half the anticipated amount of sulfur. This diffusional resistance may be accentuated by the conversion of magnetite in the sorbent to iron carbides.

The formation of iron carbides, resulting from the high CO/CO<sub>2</sub> ratio in the gas which was desulfurized, appears to weaken the sorbent considerably and, upon removal in the sulfidized form, it contained a large quantity of fines.

On these grounds, it appears advisable to operate the desulfurization process at conditions of gas composition and temperature such that iron in the sorbent is not reduced from magnetite to iron and iron carbide.

Regeneration of sorbent containing iron carbides produced a tail gas containing reduced sulfur compounds, such as H<sub>2</sub>S and COS, and also hydrogen and carbon monoxide. Treatment of this stream to fix the sulfur compounds would probably require its incineration.

The particulate loading of the gas stream to the desulfurization unit was again of the order of 1 g/Nm<sup>3</sup> and median particle diameter in the range 20 µm to 25 µm. This combination of particulate loading and size resulted in an unacceptable reactor pressure drop, high enough to lift the sorbent bed (operation was in an upward flow mode.)

Future tests were planned to investigate the reactor pressure drop more closely, including the effects on it of space velocity, particle loading and size, and iron carbide and coke formation.

As in previous tests, the sorbent was found to remove significant amounts of other minor and trace constituents from the hot gas, in addition to sulfur. The most noticeable of these were halides, ammonia, and alkali and alkaline earth metals. The mechanism by which ammonia is removed is not clear at present.

## References

1. Grindley, T., "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 101," METC, IR No. 1846 (1984).
2. "Integrated Test Plan for METC Fixed-Bed Gasifier and Cleanup System Test Run No. 102," EG&G, Morgantown, September 1983. DOE/MC/14521-1467.
3. Pater, K., Preliminary Test Summary -- Run No. 102 (FN), IR No. 1808, March 1984, METC; Process Summary Report Test Run 102 METC Fixed-Bed Gasifier and Full-Flow Cleanup System, IR No. 1983, September 1984, METC.
4. Waltermire, D. D., "METC In-House Combustion Studies on Alternate Fuels for Heat Engines Applications," First Annual Heat Engines Contractors' Meeting (1984), METC.
5. Romanosky, R. R., and J. J. Kovach, "Analytical Data -- Producer Run No. 102," IR No. 1970, August 1984, METC.
6. Bagnell, R. D., "Particle Sampling in the Hot Gas Stream During Gasifier Run No. 102," IR No. 1757, December 1983, METC.

**ADDENDUM" TO "APPENDIXES**

The Baseline G.C. on-line H<sub>2</sub>S, COS, and SO<sub>2</sub> readings as plotted are correct only for the points: H<sub>2</sub>S: 3 ppm; COS: 1.7 ppm; and SO<sub>2</sub>: 5.1 ppm. Calibration curves are available for correction. Corrected plots are given in Volume 1.

Refer to letter to T. Grindley from E. E. Gorski and P. Johnson, EG&G Washington Analytical Services Center, Inc. January 30, 1986. Subject: DOE-METC/EG&G Contract No. DE-AC21-85MC21353; WBS No. 9KEX-10. HGD Project: Baseline GC/Integrator Conversion Curves.

FIGURE 1





FIGURE 2

TEST 006

## AVERAGE OPERATING PARAMETERS




AVERAGE(S) FOR PERIOD FROM: 12/ 2012

2/29/1813 TO 161 8138

8/20/1913


FIGURE 3  
TEST 007  
AVERAGE OPERATING PARAMETERS



AVERAGE(0) FOR PERIOD FROM: 10:30:14 8/20/1983 TO 8:49:53 8/21/1983

FIGURE 4A

**TEST 008 A**  
**AVERAGE OPERATING PARAMETERS**



AVERAGE(S) FOR PERIOD FROM: 18:17:25 9/21/1983 TO 141:01:24 9/21/1983

FIGURE 4B  
TEST 008 B  
AVERAGE OPERATING PARAMETERS





FIGURE 4C

## TEST 008 C

## AVERAGE OPERATING PARAMETERS



-693-


AVERAGE(S) FOR PERIOD FROM: 18:20:33

8/21/1983 TO 20:28:07

8/21/1983

FIGURE 5

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O B51	DEGF	ABSORBER 5° FROM BOTTOM	498	1101.	22.21	1050.	1 1134.
□ B52	DEGF	ABSORBER 15° FROM BOTTOM	498	1131.	34.00	1045.	1 1238.
◊ B53	DEGF	ABSORBER 25° FROM BOTTOM	496	1153.	38.08	1049.	2 1247.
A B54	DEGF	ABSORBER 35° FROM BOTTOM	496	1167.	33.97	1050.	2 1220.
▼ B55	DEGF	ABSORBER 45° FROM BOTTOM	496	1174.	32.04	1068.	2 1210.




START TIME OF PLOT  
STOP TIME OF PLOT

12:21:0 16:10:0  
9/20/1983 9/20/1983

TEST 006  
REACTOR TEMPERATURES

FIGURE 6

SLOT UNITS                    DESCRIPTION  
804 "HBO            ABSORBER DIFFERENCE PRESSURE



START TIME OF PLOT  
STOP TIME OF PLOT


12:21:0            9/20/1983  
16:10:0            9/20/1983

TEST 006

REACTOR PRESSURE DROP

FIGURE 7


SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ	
0 4017	SCFH	PRODUCER GAS FLOW TO COMBUSTOR	463	3138.	459.5	0.0000E+00	8	3974.
0 3750	SCFH	PROD. GAS OUT OF SYSTEM	496	1015.	93.39	878.0	1	1527.



TEST 006  
EXIT FLOWS

FIGURE 8

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	BS1	DEGF ABSORBER 5° FROM BOTTOM	1505	1126.	76.06	1027.	11 1273. 2
D	BS2	DEGF ABSORBER 10° FROM BOTTOM	1505	1114.	100.8	1023.	1 1365. 1
D	BS3	DEGF ABSORBER 25° FROM BOTTOM	1505	1076.	92.93	970.5	2 1322. 1
A	BS4	DEGF ABSORBER 35° FROM BOTTOM	1505	1041.	75.51	984.5	1 1243. 5
V	BS5	DEGF ABSORBER 45° FROM BOTTOM	1505	1003.	44.50	975.4	5 1151. 1



START TIME OF PLOT

19:30: 0

STOP TIME OF PLOT

9/20/1983

8:50: 0


9/21/1983

TEST 007

REACTOR TEMPERATURES

FIGURE 9

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
0	"H2O	ABSORBER INLET TOP PRESSURE	1377	131.0	20.99	89.14	1
0	"H2O	ABSORBER DIFFERENCE PRESSURE	1595	-1.457	0.3722	-1.631	1
						161.0	1
						1.383	1




TEST 007

REGENERATION

REACTOR PRESSURE DROP AND REACTOR INLET PRESSURE

FIGURE 10

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
0 3756	SCFH	AIR FLOW LOW RANGE	1595	55.84	10.84	38.88	1
0 3754	BTU/HR	STEAM FLOW	1596	10.54	0.6721	8.977	1




499-  
 START TIME OF PLOT 19:30: 0 9/20/1983  
 STOP TIME OF PLOT 8:50: 0 9/21/1983

TEST 007

STEAM AND AIR FLOWS

FIGURE 11

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	BS1	ABSORBER 6° FROM BOTTOM	748	1081.	32.00	940.7	1 1116.
□	BS2	ABSORBER 15° FROM BOTTOM	753	1126.	28.16	1023.	1 1168.
○	BS3	ABSORBER 25° FROM BOTTOM	753	1153.	22.16	1067.	1 1185.
△	BS4	ABSORBER 35° FROM BOTTOM	751	1159.	17.85	1067.	1 1170.
▼	BS5	ABSORBER 45° FROM BOTTOM	749	1162.	21.12	1065.	1 1188.




START TIME OF PLOT 12:17: 0 9/21/1983  
STOP TIME OF PLOT 21:30: 0 9/21/1983

TEST 0D8  
REACTOR TEMPERATURES

FIGURE 12

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
0	PSIG	GAS OUT OF SYSTEM	618	105.5	29.39	50.00	1
0	PSIG	ABSORBER INLET BOTTOM	665	143.8	8.219	124.0	1




START TIME OF PLOT  
STOP TIME OF PLOT

12:17: 0      9/21/1983  
21:30: 0      9/21/1983

TEST 008  
INLET AND EXIT PRESSURES

FIGURE 13

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
0	SCFH	PROD. GAS OUT OF SYSTEM	708	1000.	181.2	336.4	1
0	SCFH	PRODUCER GAS FLOW TO COMBUSTOR	192	3610.	124.6	2818.	1




START TIME OF PLOT  
STOP TIME OF PLOT

12:17: 0      9/21/1983  
21:30: 0      9/21/1983


TEST 008  
EXIT FLOWS

FIGURE 14  
TEST 009  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 11:45:29 9/29/1983 TO 19:48:37 9/29/1983

**FIGURE 15**  
**TEST 010**  
**AVERAGE OPERATING PARAMETERS**




AVERAGE(S) FOR PERIOD FROM 21:40:11 9/29/1983 TO 16:29:59 9/30/1983

FIGURE 16

## TEST 011

## AVERAGE OPERATING PARAMETERS




AVERAGE(S) FOR PERIOD FROM: 18:49:17

9/30/1983 TO 11:49:58 10/ 1/1983

FIGURE 17


TEST 012  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 13:20:81    10/ 1/1983 TO 5:19:30    10/ 8/1983

FIGURE 18

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
○	B51	DEGF ABSORBER 5° FROM BOTTOM	970	1005.	6.915	979.7	1 1026.
□	B52	DEGF ABSORBER 15° FROM BOTTOM	970	1012.	18.67	963.1	1 1099.
◊	B53	DEGF ABSORBER 25° FROM BOTTOM	970	1037.	18.99	979.7	2 1106.
△	B54	DEGF ABSORBER 35° FROM BOTTOM	970	1059.	19.32	991.2	2 1113.
▼	B55	DEGF ABSORBER 45° FROM BOTTOM	970	1077.	19.23	1001.	1 1112. 5




START TIME OF PLOT  
STOP TIME OF PLOT

11:45: 0      9/29/1983  
19:50: 0      9/29/1983

TEST 009  
REACTOR TEMPERATURES

FIGURE 19

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"HBO	ABSORBER DIFFERENCE PRESSURE	970	62.68	42.27	2.984 1	163.8 1




START TIME OF PLOT	11:45: 0	9/29/1983
STOP TIME OF PLOT	19:50: 0	9/29/1983

TEST 009

REACTOR PRESSURE DROP

FIGURE 20

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
0 3750	SCFH	PROD. GAS OUT OF SYSTEM	970	401.1	307.3	0.0000E+00	5	1216.	1
0 4017	SCFH	PRODUCER GAS FLOW TO COMBUSTOR	755	8010.	651.4	0.0000E+00	8	2770.	1




TEST 009

EXIT FLOWS

FIGURE 21

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	B51	DEGF ABSORBER 5° FROM BOTTOM	2100	1154.	82.39	1030.	2 1339.
D	B52	DEGF ABSORBER 15° FROM BOTTOM	2020	1182.	125.8	1034.	1 1412.
O	B53	DEGF ABSORBER 25° FROM BOTTOM	2116	1124.	130.7	1019.	2 1421.
A	B54	DEGF ABSORBER 35° FROM BOTTOM	2116	1048.	128.8	983.1	1 1453.
V	B55	DEGF ABSORBER 45° FROM BOTTOM	2116	989.2	85.68	961.4	1 1525.




START TIME OF PLOT  
STOP TIME OF PLOT

21:40: 0      9/29/1983  
15:30: 0      9/30/1983

TEST 010  
REACTOR TEMPERATURES

FIGURE 22

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
0	"H2O	ABSORBER INLET TOP PRESSURE	1930	41.44	35.36	-81.39	8	159.6	1
II	"H2O	ABSORBER DIFFERENCE PRESSURE	2124	5.769	2.703	-28.72	8	31.48	1



START TIME OF PLOT      21:40: 0      9/29/1983  
 STOP TIME OF PLOT      15:30: 0      9/30/1983


TEST 010

REGENERATION

REACTOR PRESSURE DROP AND REACTOR INLET PRESSURE

FIGURE 23

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ	
0	SCFH	AIR FLOW LOU RANGE	2108	41.05	5.928	0.0000E+00	24	87.36
0	8/HR	STEAM FLOW	2114	11.30	1.645	0.0000E+00	3	14.74




START TIME OF PLOT      21:40: 0      9/29/1983  
 STOP TIME OF PLOT      15:30: 0      9/30/1983

TEST 010

STEAM AND AIR FLOWS

FIGURE 24

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O 851	DEGF	ABSORBER 5° FROM BOTTOM	2262	998.6	13.25	915.8	1 1050.
O 858	DEGF	ABSORBER 15° FROM BOTTOM	2262	985.3	22.91	900.3	1 1077.
O 853	DEGF	ABSORBER 25° FROM BOTTOM	2262	995.8	26.72	942.4	1 1089.
A 854	DEGF	ABSORBER 35° FROM BOTTOM	2262	1017.	24.85	950.7	2 1098.
V 855	DEGF	ABSORBER 45° FROM BOTTOM	2262	1024.	16.78	971.3	3 1072.




START TIME OF PLOT 16:40: 0 9/30/1983  
STOP TIME OF PLOT 11:30: 0 10/ 1/1983

TEST 011

REACTOR TEMPERATURES

FIGURE 25

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
204	'H2O	ABSORBER DIFFERENCE PRESSURE	2250	50.77	68.33	3.068	1	164.7	1




START TIME OF PLOT 16:40: 0 9/30/1983  
STOP TIME OF PLOT 11:30: 0 10/ 1/1983

TEST 011

REACTOR PRESSURE DROP

FIGURE 26

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
0 3750	SCFH	PROD. GAS OUT OF SYSTEM	2262	1100.	43.10	846.1	1
0 4017	SCFH	PRODUCER GAS FLCU TO COMBUSTOR	1954	3388.	53.78	3244.	1
						1860.	1
						3879.	1



START TIME OF PLOT  
STOP TIME OF PLOT


16:40: 0      9/30/1983  
11:30: 0      10/ 1/1983

TEST 011

EXIT FLOWS

FIGURE 27

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	851	DEGF ABSORBER 5° FROM BOTTOM	1900	1173.	95.81	972.3	1 1340.
□	858	DEGF ABSORBER 15° FROM BOTTOM	1900	1207.	108.9	1036.	3 1375.
○	853	DEGF ABSORBER 25° FROM BOTTOM	1900	1129.	99.89	1038.	1 1276.
△	854	DEGF ABSORBER 35° FROM BOTTOM	1900	1058.	131.3	986.8	2 1438.
▼	855	DEGF ABSORBER 45° FROM BOTTOM	1900	995.5	83.29	969.8	2 1530.



START TIME OF PLOT

13:20: 0

10/ 1/1983

STOP TIME OF PLOT

16:20: 0


10/ 2/1983

TEST 012

REACTOR TEMPERATURES

FIGURE 28

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	RIM - FREQ	MAX - FREQ
0 302	"H2O	ABSORBER INLET TOP PRESSURE	1497	110.2	38.99	23.99	1
0 294	"H2O	ABSORBER DIFFERENCE PRESSURE	1873	4.095	9.347	-28.72	34



START TIME OF PLOT      13:20: 0      10/ 1/1983  
 STOP TIME OF PLOT        16:20: 0      10/ 2/1983


TEST 012

REGENERATION

REACTOR PRESSURE DROP AND REACTOR INLET PRESSURE

FIGURE 29

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	RIN - FREQ	MAX - FREQ
O 3756	SCFH	AIR FLOW LOW RANGE	1946	43.86	4.294	0.0000E+00 14	82.66 1
D 3754	8/HR	STEAM FLOW	1944	11.12	1.970	0.0000E+00 3	22.85 1



START TIME OF PLOT: 13:20: 0 10/ 1/1983  
 STOP TIME OF PLOT: 16:20: 0 10/ 2/1983

TEST 012

STEAM AND AIR FLOWS

Figure 30

**TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT**

TEST NO.: 006  
DATE STARTED: 12:00 9/20/83  
DATE ENDED: 16:10 9/20/83

TOTAL HOURS: 4.13  
TYPE: SULFIDATION  
SULFUR REMOVED: 2.84 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
SCREEN NO.: UNITED CATALYSTS L-1504  
SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
50.0 MOLE% ZINC OXIDE  
SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
GASIFIER OPERATING CONDITIONS

GASIFIER TYPE: DOE/METC FIXED BED  
COAL TYPE: ARKWRIGHT  
STEAM/COAL MASS RATIO: 0.468  
STEAM/AIR MASS RATIO: 0.19

HGS OPERATING CONDITIONS

TEMPERATURE: 1143 F (AVERAGE)  
PRESSURE: 101 PSIG (AVERAGE)  
SPACE VELOCITY: 2028 (0.87 HRS), 7270 (2.13 HRS), 1908 (1.13 HRS)

INLET MOLE%	INLET WET BASIS (OIL FREE)	EXIT MOLE%	EXIT MOLE%
DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)

H<sub>2</sub>S 0.314

H<sub>2</sub>O 7.3

CO<sub>2</sub> 14.7

NO EXIT GC DATA

CO 24.0

H<sub>2</sub> 15.5

CH<sub>4</sub> 3.1

N<sub>2</sub> 44.3

O<sub>2</sub> 1.0

C<sub>2</sub>H<sub>6</sub> 0.25

TOTAL  
FLOW:

TOTAL  
LB MOLES:

FLOW  
RATE: 1173 SCFH (0.87 HRS)  
4068 SCFH (2.13 HRS)  
1068 SCFH (1.13 HRS)

PURPOSE

DETERMINE EFFECT OF TEMPERATURE ON DEBULFURIZATION  
EFFICIENCY  
DETERMINE EFFECT OF HIGH SPACE VELOCITY ON OPERATING  
PERFORMANCE.  
PROVIDE DEBULFURIZED GAS TO SLURRY COMBUSTION UNIT.

SORBENT ANALYSIS:

	BETWEEN	AFTER
TOTAL SULFUR: (WT%)	0.13	
SURFACE AREA: (SQ M/G)	3.13	
DENSITY: (G/CC)	6.16	
PORE VOLUME: (CC/G)	0.004316	
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (WT%)	0.0	

DATA ABOVE FROM T001

EXIT SULFUR DATA:

HGS: 1.5 PPB INITIALLY  
CER48: 7 PPB

CONDENSATE

RECEIVED	15.7	LBS	(ESTIMATED)
HYDROCARBON	2.0	LBS	(ESTIMATED)
TOTAL	15.7	LBS	(MEASURED)

REMARKS

1. TOTAL LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 3 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-146 1/2 S SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH IS 58 7/8 INCHES
3. FIRST TEST IN FRESH SORBENT GASIFIER RUN 102
4. BENIX 60 AT 1000 F. NO HOT SPOT OBSERVED.
5. WATER IN EXIT GGS WAS DETERMINED BY CONDENSATE COLLECTED
6. OVERALL H2O AT 1000 F. WAS LESS THAN 0.1% AS DETERMINED BY BENIX 60-6000 #1.
7. AN AVERAGE 1143 SCFH DEBULFURIZED GAS WAS PROVIDED TO THE SLURRY COMBUSTION UNIT FOR THREE HOURS.
8. REACTOR TEMP. F. WAS OBSERVED TO INCREASE RAPIDLY.
9. HOT GAS PIPELINE APPEARS TO HAVE PULSED US SOLELY FOR THE FIRST TWO HOURS OF THE RUN. THIS APPEARS LIKELY SINCE THE HOT GAS DELIVERY PIPELINE WAS "REGENERATED" WITH STEAM AND AIR PRIOR TO THIS TEST.
10. GAS COMPOSITION AT INLET IS AVERAGE OF DATA OBTAINED BY BENIX 60-7000 #4 SAMPLING AT 64 GASIFIER CYCLONE EXIT

CONCLUSIONS:

1. 0.87 HRS THROUGH AT 1143 F AND SPACE VELOCITY OF 7270 IS 25 % OF TIME TO BREAKTHROUGH AT 1000 F AND S.V. OF 2000 WHEN NORMALIZED.

Figure 31

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 007  
 DATE AND TIME STARTED : 19:30 9/20/83  
 DATE AND TIME ENDED : 08:50 9/21/83  
 TOTAL HOURS : 13.5  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
                       50.0 MOLE% ZINC OXIDE -  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

**PURPOSE**

FIRST REGENERATION OF SULFIDED SORBENT, GASIFIER RUN 102.

**SORBENT ANALYSIS:**

BEFORE      AFTER

TOTAL SULFUR: (%WT)  
 SURFACE AREA: (SQ M/G)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/G)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (%WT)

**TEST OPERATING CONDITIONS**

INITIAL TEMPERATURE: 935 F  
 PRESSURE : 129 INCHES OF WATER (AVERAGE)  
 SPACE VELOCITY: 512 HOURLY

**EXIT SULFUR DATA:**

H2S :  
 SO2 : HIGH SO2 (> 20 %) INITIALLY.  
       0.1% SO2 AT END OF REGENERATION.

	INLET MOLE%	EXIT MOLE%	
	WET BASIS	DRY BASIS	
AIR	55 SCFH	19 %	NO EC DATA AT EXIT
H <sub>2</sub> O	11 %/HR	81 %	
N <sub>2</sub>	0 SCFH		

CONDENSATE  
 AROMATICS : 409 LBS  
 HYDROCARBON :  
 TOTAL : 409 LBS

**REMARKS**

1. FACED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE  
 BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES

2. SORBENT FACED VOLUME = 0.559 CUBIC FOOT
3. FIRST REGENERATION ON SULFIDED SORBENT

4. MAXIMUM TEMPERATURE REACHED WAS 1364 F.

**CONCLUSIONS**

1. REGENERATION COMPLETED.

TOTAL LB MOLES:  
 FLOW RATE : 287 SCFH

Figure 32

**TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT**

TEST NO.: 100B  
 DATE STARTED: 8/17 8/21/83  
 DATE ENDED: 20/18 9/21/83  
 TOTAL HOURS: 6.95  
 TYPE: SULFIDATION  
 SULFUR REMOVED: 4.64 LB SE

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 45 LBS  
 SORBENT NO.: UNITED CATALYSTS L-1074  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
                       50.0 MOLE% ZINC OXIDE  
 SORBENT FELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE: DOE/METC FIXED BED  
 COAL TYPE: ARKWRIGHT  
 STEAM/COAL RATIO: 0.356  
 STEAM/AIR RATIO: 0.19

POD OPERATING CONDITIONS

TEMPERATURE: 1467 F (AVERAGE)  
 PRESSURE: 143 PSIG (AVERAGE)

SPACE VELOCITY: 4507 HOURLY FOR 3 HOURS, 1803 HOURLY FOR 4 HRS

	INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%	CONDENSATE
	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	AQUEOUS
					HYDROCARBON : 4.1 LBS (ESTIMATED)
					TOTAL : 32.4 LBS (MEASURED)

H<sub>2</sub>O 0.355

H<sub>2</sub>O 7.8

CO<sub>2</sub> 14.14 NO GC DATA AT EXIT

CO 24.44

H<sub>2</sub> 15.37

CH<sub>4</sub> 2.92

N<sub>2</sub> 42.45

O<sub>2</sub> 1.00

SO<sub>2</sub> 0.27

TOTAL  
FLOW:

FLOW  
RATE: 3809 SCFH WITH FLOW TO SLURRY 1009 SCFH WITHOUT  
COMBUSTION.  
APPROXIMATELY 3 HOURS

FLOW TO COMBUSTOR  
APPROXIMATELY 4 HOURS

PURPOSE

DETERMINE EFFECT OF TEMPERATURE ON DESULFURIZATION EFFICIENCY  
 DETERMINE EFFECT OF HIGH SPACE VELOCITY ON OPERATING  
 PERFORMANCE.  
 PROVIDE DESULFURIZED GAS TO SLURRY COMBUSTION UNIT.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (%WT)		
SURFACE AREA: (SQ M/S)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (%WT)		

EXIT SULFUR DATA:

H<sub>2</sub>S : 5 PPM INITIALLY  
 C<sub>2</sub>H<sub>6</sub>S:

	CONDENSATE AQUEOUS	CONDENSATE HYDROCARBON	CONDENSATE TOTAL
	: 29.3 LBS	: 4.1 LBS	: 32.4 LBS
	(ESTIMATED)	(ESTIMATED)	(MEASURED)

REMARKS

1. REACTOR LENGTH IS 47 5/8 INCHES ZINC FERRITE  
 BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES  
 CS-746 1/2 S SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH IS 7 1/8 INCHES
3. SECOND TEST ON FRESH SORBENT, GASIFIER RUN 102
4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
5. SORBENT WAS REMOVED AFTER THIS TEST. TOP 30 INCHES  
 WERE FUSED, WITH ANOTHER 4 INCH SECTION AT THE END FUSED.
6. REACTOR FELT P WAS HIGH FROM THE BEGINNING OF TEST AT  
 MAX READING OF 160 INCHES OF WATER.
7. FLOW TO SLURRY COMBUSTION FROM H<sub>2</sub>O EXIT AT 2300 SCFH  
 AVERAGE FOR APPROXIMATELY 3 HOURS, AFTER WHICH A PLUG  
 DEVELOPED AND FLOW WAS SHUT OFF.

CONCLUSIONS

1. SULFUR REMOVAL BETTER DURING THIS SECOND SULFIDATION  
 COMPARED WITH THE FIRST SULFIDATION, TEST 106.
2. APPARENTLY CARBON AND PARTICULATES WERE NOT BURNED  
 OUT DURING THE LAST REGENERATION. HOWEVER, THIS DOES  
 NOT APPEAR TO AFFECT THE DESULFURIZATION CAPACITY  
 NEGATIVELY.

Figure 33

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO.: 209  
 DATE STARTED : 11:45 9/29/63  
 DATE ENDED : 19:50 9/29/63  
 TOTAL HOURS : 8.08  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 7.76 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE) 45 LBS  
 SORBENT NO.: UNITED CATALYSTS U-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
                       50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS  
 GASIFIER TYPE : CO/EMTC FIXED BED  
 COAL TYPE : BRICKETTES (BLACKSVILLE + TAR)  
 STEAM/COAL RATIO: 0.557  
 STEAM/AIR RATIO : 0.22

H2S OPERATING CONDITIONS

TEMPERATURE: 1044 F (AVERAGE)  
 PRESSURE : 94 PSIG (AVERAGE)

SPACE VELOCITY: 4179 HOURLY (5.75 HRS), 1314 HOURLY (2.32 HRS)

	INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%	CONDENSATE
	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	AQUEOUS : 10.6 LBS (ESTIMATED)
H <sub>2</sub> S	0.583			1 FPM	HYDROCARBON : 1.6 LBS (ESTIMATED)
H <sub>2</sub> O				6.5 %	TOTAL : 12.2 LBS (MEASURED)
CO <sub>2</sub>	10.03		11.79		
CO	22.25		15.83		
H <sub>2</sub>	17.14		21.34		
CH <sub>4</sub>	2.40		2.09		
N <sub>2</sub>	47.06		47.53		
O <sub>2</sub>	0.65		0.66		
O <sub>2</sub> H <sub>2</sub>	0.16		0.00		
TOTAL FLOW:					
TOTAL LB MOLES:					
FLOW RATE:	2776 SCFH (5.75 HRS)				
	1015 SCFH (2.32 HRS)				

PURPOSE

DETERMINE EFFECT OF HIGH SPACE VELOCITY ON OPERATING PERFORMANCE.  
 PROVIDE DESULFURIZED GAS TO SLURRY COMBUSTION UNIT.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (%WT)	0.13	
SURFACE AREA: (SQ M/G)	3.13	
DENSITY : (G/CC)	6.16	
PORE VOLUME: (CC/G)	0.004316	
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (%WT)	0.0	
	DATA ABOVE FROM T001	

EXIT SULFUR DATA:

H<sub>2</sub>S : 1 PPM INITIALLY, BREAKTHROUGH AT 9 HOURS  
 CH<sub>4</sub>S:

	CONDENSATE
AQUEOUS	: 10.6 LBS (ESTIMATED)
HYDROCARBON	: 1.6 LBS (ESTIMATED)
TOTAL	: 12.2 LBS (MEASURED)

REMARKS

1. PACKED LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 5 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-34 1/2 S SR-10769 UNITED CATALYSTS
2. OVERALL PACKED LENGTH IS 7 1/2 INCHES
3. GASIFIER RUN 102. FRESH SORBENT LOADED FOR T009.
4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
5. AN AVERAGE OF 2193 SCFH DESULFURIZED GAS WAS PROVIDED TO THE SLURRY COMBUSTION UNIT FOR 8PPCY. 5.75 HOURS.
6. REACTOR FELT P WAS OBSERVED TO INCREASE RAPIDLY UP TO A MAX OF 1 1/4 INCHES OF WATER.
7. INLET DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC 7000 #4 DATA FOR THE DURATION OF THE RUN.
8. EXIT DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC 6000 #2 DATA FOR THE DURATION OF THE RUN.

CONCLUSIONS:

1. TIME TO BREAKTHROUGH AT SV OF 4179 IS LESS THAN HALF OF TIME TO BREAKTHROUGH AT SV 2000.
2. SPACE VELOCITIES AS HIGH AS 4000 DO NOT APPEAR TO LOAD THE SORBENT AS WELL AS LOWER SPACE VELOCITIES.
3. CO<sub>2</sub> BREAKTHROUGH APPEARS TO LEAD H<sub>2</sub>S BREAKTHROUGH BY ABOUT 1 1/2 HOURS.

Figure 34

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 010  
 DATE AND TIME STARTED : 21:40 9/29/83  
 DATE AND TIME ENDED : 15:30 9/30/83  
 TOTAL HOURS : 17.8  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
                       50.0 MOLE% ZINC OXIDE  
 SORBENT FELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

## PURPOSE

REGENERATION OF SULFIDED SORBENT FROM T009 GASIFIER RUN 102.

## SORBENT ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR: (%WT)  
 SURFACE AREA: (SB M/G)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/G)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (%WT)

## HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 1058 F

PRESSURE : 41.8 INCHES OF WATER (AVERAGE)

SPACE VELOCITY: 496 HOURLY

## EXIT SULFUR DATA:

H2S :

SO2 : 4.5 % INITIALLY . HIGH OF >16% AFTER 2.5 HOURS  
 0.5 % AT END OF RUN .

	INLET MOLE%	EXIT MOLE%	CONDENSATE
	WET BASIS	DRY BASIS	AQUEOUS
			HYDROCARBON
			TOTAL : 220 LBS

AIR 40.86 SCFH      21 %

H2O 11.25 #/HR      79 %

N2 0 SCFH

## REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-746 1/2 S SR-10769 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. FIRST REGENERATION ON SULFIDED SORBENT (SECOND BATCH)
4. MAXIMUM TEMPERATURE REACHED WAS 1524 F.

## CONCLUSIONS

1. REGENERATION COMPLETED.

TOTAL LB MOLES:  
 FLOW RATE : 278 SCFH

Figure 35

**TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT**

TEST NO.: 011  
 DATE STARTED: 16:40 9/30/83  
 DATE ENDED: 11:30 10/1/83  
 TOTAL HOURS: 15.8  
 TYPE: SULFIDATION  
 SULFUR REMOVED: 6.27 LB SS

PURPOSE

SECOND SULFIDATION ON SORBENT

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO.: UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE

SORBENT ANALYSIS: BEFORE AFTER

TOTAL SULFUR: (WWT)  
 SURFACE AREA: (SQ M/G)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/G)  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (WWT)

SORBENT FELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE: BOE/METCO FIXED BED  
 COAL TYPE: BRICKETTES (BLACKSVILLE + TARY) AND BLACKSVILLE  
 RUN OF MINE  
 STEAM/COAL RATIO: 0.556  
 STEAM/AIR RATIO: 0.223

WET OPERATING CONDITIONS  
 TEMPERATURE: 1365 °F (AVERAGE)

EXIT SULFUR DATA:  
 H<sub>2</sub>S : 50 PPB INITIALLY GRADUALLY DOWN TO 2 PPB

PRESSURE : 122 PSIG (AVERAGE)  
 SPACE VELOCITY: 1866 HOURLY

C<sub>1</sub>H<sub>2</sub>S:  
 SO<sub>2</sub> : 10 PPB INITIALLY

	INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%	CONDENSATE
	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	AQUEOUS
					HYDROCARBON : 11.4 LBS (ESTIMATED)
					TOTAL : 86.8 LBS (MEASURED)

H<sub>2</sub>S 0.351H<sub>2</sub>O 7.1 %CO<sub>2</sub> 2.9REMARKS

1. PACKED LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-746 1/2 S SF-10789 UNITED CATALYSTS

2. OVERALL PACKED LENGTH IS 53 7/8 INCHES

3. SECOND SULFIDATION ON FRESH SORBENT. GASIFIER RUN 1A. SORBENT REMOVED AFTER RUN 1A AND FRESH SORBENT LOADED.

4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED

5. EXIT DRY GAS ANALYSIS TOTAL IS 107 % .

6. REACTOR DELTA P WAS OBSERVED TO INCREASE RAPIDLY UP TO A MAX OF 184 INCHES OF WATER.

7. INLET DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC-6000 #1 DATA.

8. EXIT DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC-6000 #2 DATA.

TOTAL  
FLOW:TOTAL  
LB MOLES:FLOW  
RATE: 1100 SCFMCONCLUSIONS:

1. SULFIDATION AT SV 1866 RESULTED IN LONGER TIME TO BREAKTHROUGH APPROACHING THE TIMES PREVIOUSLY OBSERVED.

Figure 36

**TEST SUMMARY SHEET**  
**SIDESTREAM TEST UNIT**

TEST NO. : 012  
 DATE AND TIME STARTED : 13:20 10/01/83  
 DATE AND TIME ENDED : 16:20 10/02/83

TOTAL HOURS : 27  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
                       50.0 MOLE% ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

**PURPOSE**

REGENERATION OF SULFIDED SORBENT FROM T011 GASIFIER RUN 101

**SORBENT ANALYSIS:**

BEFORE      AFTER

TOTAL SULFUR: (ZWT)  
 SURFACE AREA: (SQ M/6)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/6)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (ZWT)

**HGD OPERATING CONDITIONS**

INITIAL TEMPERATURE: 1006 F

PRESSURE : 112.3 INCHES OF WATER (AVERAGE)

SPACE VELOCITY: 496 HOURLY

**EXIT SULFUR DATA:**

H2S :

SO2 : 6% INITIALLY, HIGH OF 10% AFTER 4.2 HOURS  
300 PPM AT END OF RUN.

	INLET MOLE%	EXIT MOLE%	CONDENSATE
	WET BASIS	DRY BASIS	AQUEOUS : LBS
AIR	44.22 SCFH	22.7 %	
H2O	11.12 #/HR	77.3 %	
N2	0 SCFH		

**REMARKS**

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 5 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-746 1/2 S SR-10789 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. SECOND REGENERATION ON SULFIDED SORBENT (SECOND BATCH)
4. MAXIMUM TEMPERATURE REACHED WAS 1530 F.
5. LAST TEST DURING GASIFIER RUN 102. REACTOR COOLED AND SORBENT SAMPLED AND REMOVED.
6. 118 GRAMS OF GRAY/BLACK DUST COLLECTED ON BOTTOM FLANGE OF THE REACTOR. THIS HAS ACCUMULATED SINCE RUN T001.

TOTAL LB MOLES:  
 FLOW RATE : 278 SCFH

CONCLUSIONS:  
 1. REGENERATION COMPLETED.

Figure 37

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 006




Figure 38

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 008




Figure 39

# ZINC FERRITE SULFIDATION

SIDESREAM TEST UNIT #ST 009




Figure 40

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 011




Figure 41

# ZINC FERRITE SULFIDATION

SIDESTREAM TEST UNIT TEST 006





Figure 42

# ZINC FERRITE SULFIDATION

SIDESTREAM TEST UNIT TEST 008



# ZINC FERRITE SULFIDATION

SIDESTREAM TEST UNIT TEST 009




Figure 44

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 011




Table 1A

**HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS AT EXIT  
GASIFIER RUN 102  
TRACE COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	COS	CH <sub>3</sub> SH	CS <sub>2</sub> PPM	Thio	NH <sub>3</sub>	SO <sub>2</sub>	H <sub>2</sub> O
T006 SULFI- DATION	H6 1	9/20/83 14:30	3.84	12.4	ND	ND	6.77	70.4	ND	-
T008 SULFI- DATION	H6 2	9/21/83 13:10	ND	0.51	ND	0.39	1.50	112.2	ND	5560.9
	H6 3	9/21/83 14:10	ND	4.71	ND	0.46	1.27	432.9	ND	7771.59
	H6 4	9/21/83 21:00	<.2	14.7	ND	0.24	0.96	260.4	ND	WATER IN SAMPLE
T009 SULFI- DATION	H6 5	9/29/83 13:15	TRACE	ND	ND	TRACE	4.70	13.0	ND	2887.8
	H6 6	9/29/83 14:15	ND	TRACE	ND	1.18	3.51	ND	ND	2433
	H6 7	9/29/83 16:45	ND	5.71	0.06	1.42	3.34	ND	ND	1816.6
T010 REGENER- ATION	H6 8	9/30/83 01:45							ND	
	H6 9	9/30/83 03:15	3743	51.4	ND	59.6	ND	ND	~7550	11,769
	H6 10	9/29/83 23:45	>4000	62.7	10.9	36.4	3.0	99.3	116.2	6169

**NOTES:**

1. ND = Not Detectable.
2. Detectable level for H<sub>2</sub>S, COS, CH<sub>3</sub>SH, Thiophene, SO<sub>2</sub> is 0.2 ppm.

Table 1B

**HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS AT INLET  
GASIFIER RUN 102  
TRACE COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	CO <sub>2</sub>	CH <sub>3</sub> SH	CS <sub>2</sub> PPM	THIOL	NH <sub>3</sub>	SO <sub>2</sub>	H <sub>2</sub> O
TO06	FN-15	9/20/83 12:00	--	--	--	--	--	--	--	1083
SULFI- CATION	FN-17	9/20/83 14:00	3736	358	ND	6	ND	ND	--	732
TO08	FN-41	9/21/83 13:35	4651	326	ND	5	ND	ND	--	510.7
SULFI- CATION	FN-92	9/27/83 13:45	4502	367	15	11	ND	--	--	550
SULFI- CATION	FN-97	9/27/83 15:15	4409	359	13	11	ND	--	--	555
TO11	FN-111	10/1/83 06:35	4362	378	3	12	ND	--	--	1050
SULFI- CATION	FN-116	10/1/83 10:23	4554	466	10	10	3	--	--	912

## NOTES:

1. ND = Not Detectable
2. Detectable level for H<sub>2</sub>S, CO<sub>2</sub>, CH<sub>3</sub>SH, Thiophene, SO<sub>2</sub> is 0.2 ppm.

Table 2

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 006

AVERAGE GC READINGS

DURATION

FROM	TO
12: 2: 0      9/20/1983	16:10: 0      9/20/1983

GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	S BTU	N BTU
-----	--	--	--	--	--	--	--	--	-----	-----	-----	-----	-----	-----
25	15.573	14.709	0.256	0.314	0.993	44.366	3.110	28.531	107.642	28.21	1.261	0.975	180.58	169.14

HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	S BTU	N BTU
-----	--	--	--	--	--	--	--	--	-----	-----	-----	-----	-----	-----
22	16.141	12.450	0.238	0.094	0.970	44.806	2.592	34.007	111.396	28.74	1.284	0.993	193.09	182.02

Table 3A

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 008A  
AVERAGE GC READINGS

**DURATION**

FROM \_\_\_\_\_ TO \_\_\_\_\_  
12:17: 0      9/21/1987      14: 0: 0      9/21/1987

### GASIFIER CYCLONE EXIT

BENDIX 7000 II CHROMATOGRAPH

# READ	H2	C02	CCH4	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	6 STU	N STU
10	15.509	14.450	0.250	0.496	0.996	44.890	2.992	24.642	104.174	27.16	1.214	0.739	167.16	155.87

H60 INLET

ВЕНТИЛ АССО № 1 СЧЕМОЗАДАЧА

# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg BTU	Avg SG	G BTU	N BTU
9	--	--	--	--	--	--	--	--	96.408	25.20	1.126	0.671	108.67	101.63

Table 3B

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 008B

## AVERAGE GC READINGS

## DURATION

FROM		TO
14:34: 0	9/21/1983	15:52: 0      9/21/1983

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	----	--	--	--	---	--	-----	-----	-----	-----	-----	-----
6	15.448	14.509	0.246	0.389	0.998	44.384	3.104	24.569	104.147	27.18	1.215	0.940	167.69	156.29

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	----	--	--	--	---	--	-----	-----	-----	-----	-----	-----
6	16.208	6.636	0.309	0.220	0.608	47.068	3.079	24.908	99.036	24.27	1.034	0.836	171.03	159.27

Table 3C

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 008C  
AVERAGE GC READINGS

## DURATION

FROM	TO
19:29: 0	9/21/1983
	20:27: 0
	9/21/1983

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	---	---	---	---	---	---	---	---	-----	-----	-----	-----	-----	-----
11	15.080	13.299	0.207	0.303	0.798	41.743	2.774	24.966	99.370	25.77	1.152	0.691	163.17	150.39

## H2O INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	---	---	---	---	---	---	---	---	-----	-----	-----	-----	-----	-----
5	9.220	1.114	0.104	0.113	0.273	69.347	1.267	13.240	93.710	22.90	1.067	0.825	88.00	62.11

Table 4

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 009

### AVERAGE GC READINGS

**DURATION**

FROM TO  
11:45: 0 9/29/1983 19:50: 0 9/29/1983

HSD EXIT BENDIX 6000 II CHROMATOGRAPH

# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	6 BTU	N BTU	
36	--	21.367	11.794	-0.005	-0.001	0.864	47.598	2.089	15.822	99.524	24.00	1.073	0.830	141.49	138.72

BASIFIER CYCLONE EXIT BENDIX 7000 #4 CHROMATOGRAPH

# READ	H2	CO2	CH4	HC6	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--
	17.141	10.030	0.160	0.583	0.655	47.052	2.396	22.247	100.273	25.02	1.118	0.865	158.25	146.75

HGD INLET BENDIX 5000 #1 CHROMATOGRAPH

# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	S BTU	N BTU
-----	--	---	----	--	--	--	---	--	-----	-----	-----	-----	-----	-----
41	16.479	9.658	0.194	0.378	0.610	48.060	2.078	0.731	99.189	24.85	1.110	0.859	150.51	139.70

Table 5

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 011

## AVERAGE GC READINGS

## DURATION

FROM	TO
16:40: 0      9/30/1983	11:30: 0      10/ 1/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	---	--	--	--	---	--	-----	-----	-----	-----	-----	-----
113	26.374	11.378	0.143	0.000	0.725	50.819	2.366	15.464	107.269	24.76	1.107	0.856	162.04	146.27

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	---	--	--	--	---	--	-----	-----	-----	-----	-----	-----
109	17.512	9.272	0.191	0.586	0.634	45.892	2.543	23.162	99.930	24.66	1.102	0.852	164.53	152.64

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	---	--	--	--	---	--	-----	-----	-----	-----	-----	-----
112	16.072	8.912	0.201	0.361	0.621	47.959	2.196	23.262	99.593	24.93	1.114	0.862	155.31	144.59

Table 6

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 010

## AVERAGE GC READINGS

## DURATION

FROM

TO

21:40: 0 9/29/1983

15:30: 0 9/30/1983

HED EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# RECD	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY	Avg SG	S BTU	N BTU
57	3.055	11.754	0.339	-0.001	0.273	78.366	0.116	1.165	95.088	27.73	1.239	0.959	20.92	18.76

Table 7

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 012

## AVERAGE GC READINGS

DURATION

FROM	TO
13:20: 0    10/ 1/1983	16:20: 0    10/ 2/1983

HCD EXIT

GENOIX 6000 #2 CHROMATOGRAPH

% READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
-----	--	---	----	--	--	--	---	--	-----	-----	-----	-----	-----	-----
1	-0.150	0.160	0.418	-0.005	0.038	76.296	0.317	9.144	86.219	24.17	1.080	0.875	39.63	38.76

TABLE 8A

HOT GAS DESULFURIZATION  
 GRAB SAMPLE GAS ANALYSIS AT EXIT  
 GASIFIER RUN 102  
 MAJOR COMPONENTS

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub> VOLUME %	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	iC <sub>4</sub>	nC <sub>4</sub>
T008	HG 2	9/21/83 13:10	8.58	7.62	59.14	1.65	13.75	0.33	8.29	0.09	0.05	ND	ND
SULFI- DATION	HG 3	9/21/83 14:10	5.18	8.89	61.96	2.27	14.13	0.24	6.68	0.06	0.09	ND	ND
	HG 4	9/21/83 21:00	5.77	8.99	61.41	1.94	14.60	0.15	6.44	0.09	0.10	ND	ND
T009	HG 5	9/29/83 13:15	1.55	10.3	68.7	1.12	8.21	.13	9.36	.05	0.07	ND	ND
SULFI- DATION	HG 6	9/29/83 14:15	6.05	5.87	62.59	1.95	10.56	.19	12.12	.10	.08	ND	ND
	HG 7	9/29/83 16:45	20.99	.60	45.77	2.44	16.75	.19	12.56	.13	.08	ND	ND
REGENER- ATION	HG 9	9/30/83 03:45	ND	7.05	89.36	ND	ND	3.0	ND	ND	ND	ND	ND
	HG 10	9/29/83 23:45	1.91	7.15	75.91	.01	ND	ND	14.02	ND	ND	ND	ND

## NOTES:

1. ND = Not Detectable.

Table 8B

HOT GAS DESULFURIZATION  
 GRAB SAMPLE GAS ANALYSIS AT INLET  
 GASIFIER RUN 102  
 MAJOR COMPONENTS

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub> VOLUME %	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>6</sub>	C <sub>3</sub> H <sub>8</sub>	C <sub>4</sub>	N <sub>2</sub> O
7006 SULFI- CATION	FN-15	9/20/83 12:00	16.15	0.70	48.02	3.13	24.67	0.32	6.30	0.15	0.02	ND	ND	
	FN-19	9/20/83 14:00	16.77	0.67	46.77	3.22	24.56	0.26	6.51	0.17	0.53	ND	ND	
7008 SULFI- CATION	FN-41	9/21/83 13:35	17.30	0.63	47.26	3.10	24.33	0.23	6.42	0.05	0.13	ND	ND	
7009 SULFI- CATION	FN-97	9/29/83 13:45	17.27	0.63	47.54	2.42	22.47	0.21	9.67	0.12	0.13	ND	ND	
	FN-97	9/29/83 15:15	17.06	0.62	48.24	1.80	22.13	0.17	9.28	0.07	0.12	ND	ND	
7011 SULFI- CATION	FN-111	10/1/83 06:35	15.71	0.68	50.05	2.57	21.97	0.17	9.10	0.13	0.11	ND	ND	
	FN-116	10/1/83 10:25	15.19	0.71	49.67	2.57	22.27	0.09	8.60	0.15	0.10	ND	ND	

## NOTES:

.. ND = Not Detectable.

TABLE 9

ANALYSIS OF MINERALS BY X-RAY DIFFRACTION  
IN SULFIDED ZINC FERRITE  
GASIFIER RUN 102

BED HEIGHT (INCHES)	FRANKLINITE $ZnFe_2O_4$ OR HEMATITE $Fe_2O_3$						
	MAGNETITE $Fe_3O_4$ <sup>(4)</sup>	ZINCITE $ZnO$	ALPHA $ZnS$	BETA $ZnS$	PYRROHITE $FeS$	CEMENTITE $Fe_3C$	
PERCENT TII (3)							
0(1)		10.7	29.1	38.1	10.1	11.9	
6		11.5	32.6	33.4	8.7	13.9	
16		15.9	28.6	27.4	5.3	22.7	
23		27.6	18.0	19.1	1.3	34.0	
26		39.5	10.3	9.8	-	40.4	
36		38.4	12.2	9.8	-	39.6	
46(2)		58.6	-	1.1	-	40.3	
FRESH SORBENT	4.	89.	6.0	-	-	-	

## NOTES:

- (1) Bottom/Inlet.
- (2) Top/Outlet.
- (3) Percent TII = Percent Total Integrated Intensity; Directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
- (4) Franklinite and Magnetite have the same crystal structure and, therefore, cannot be readily distinguished by the diffraction pattern.

TABLE 10  
SORBENT ANALYSIS OF SULFIDED ZINC  
FERRITE GASIFIER RUN 102  
TEST 008

Bed Height (Inches)	Total Carbon (% Wt)	Total Sulfur (% Wt)	BET Surface Area (SO M/G)	Skeletal Density (G/CC)(3)	Porosity % <sup>(4)</sup>	Crush Strength (Kg DWL) ± S.D. <sup>(5)</sup>	Skeletal Density (G/CC)(6)	Porosity % <sup>(7)</sup>
0(1)	4.88	24.61		4.39		3.1 ± 0.9	-	-
6	5.86	24.41					-	-
16	7.51	19.67	4.68	4.57	4.22	1.7 ± 1.6	4.50	46.9
23	7.65	13.15					-	-
26	7.67	7.11	4.72	5.58	6.45	1.6 ± 1.6	4.31	53.2
36	8.18	7.22	6.53	5.72	6.36	1.6 ± 1.3	-	-
46(2)	7.98	0.28	4.46	6.20	7.73	1.2 ± 0.9	5.61	69.4
-								
Fresh Sorbent	0	0.13	3.13	6.16	2.59	6.3 ± 2.8	6.16	60.6(8)

NOTES:

1. Bottom/Inlet during sulfidation - Outlet during regeneration.
2. Top/Outlet during sulfidation - Inlet during regeneration.
3. Skeletal Density by Helium Pycnometry.
4. Porosity by Nitrogen Adsorption for pores up to 600Å diameter.
5. Average and standard deviation of 15 measurements.
6. Skeletal density by mercury porosimetry.
7. Porosity by mercury porosimetry for pores down to 120Å diameter.
8. Porosity by mercury porosimetry for pores down to 30Å diameter.

TABLE 11

ANALYSIS OF MINERALS BY X-RAY DIFFRACTION  
IN REGENERATED ZINC FERRITE  
GASIFIER RUN 102

BED HEIGHT (INCHES)	HEMATITE $\text{Fe}_2\text{O}_3$	FRANKLINITE $\text{ZnFe}_2\text{O}_4$ OR			
		MAGNETITE $\text{Fe}_3\text{O}_4$ <sup>(4)</sup>	ZINCITE $\text{ZnO}$	ALPHA $\text{ZnS}$	BETA $\text{ZnS}$
PERCENT TII (3)					
0(1)	4.9	93.3	1.9		
6	4.4	93.0	2.6		
16	3.8	93.7	2.5		
23	3.9	93.7	2.5		
26	3.1	94.0	2.9		
36	2.7	93.4	3.9		
46(2)	2.0	92.3	5.8		
FRESH SORBENT	4.	89.	6.0		

## NOTES:

- (1) Bottom/Inlet during sulfidation - exit during regeneration.
- (2) Top/Outlet during sulfidation - inlet during regeneration.
- (3) Percent TII = Percent Total Integrated Density; Directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
- (4) Franklinite and Magnetite have the same crystal structure and, therefore, cannot be readily distinguished by the diffraction pattern.

TABLE 12

**SORBENT ANALYSIS OF  
REGENERATED ZINC FERRITE  
GASIFIER RUN 102**

BED HEIGHT (INCHES)	TOTAL CARBON (% WT)	TOTAL SULFUR (% WT)	%SULFUR AS SULFATE SO <sub>4</sub>	%SULFUR AS SULFIDE S	BET SURFACE AREA (SQ M/6)	DENSITY (G/CC) <sup>3</sup>	PORE VOLUME (CC/G) <sup>(4)</sup>	CRUSH STRENGTH (Kg DWL) ± S.D. (5)
0(1)	0.01	1.99						
0-6			1.21	0.0006	1.9591	5.582	0.003666	7.45 ± 3.41
6	0.08	1.43		0.66	0.0033	1.9756	5.645	0.002679
6-16				0.71	0.0012	2.0393	5.567	5.66 ± 2.99
16	0.02	1.33						
23	0.01	1.36		0.42	0.0008	1.6614	5.572	0.003835
26	0.01	0.97						5.42 ± 3.50
26-36				0.20	0.0096	1.5306	5.769	0.002274
36	0.02	0.59						4.20 ± 4.21
36-46								
46(2)	0.03	0.14						3.88 ± 3.68
FRESH SORBENT	0	0.13			3.1305	6.159	0.004316	6.3 ± 2.8

## NOTES:

- (1) Bottom/Inlet during sulfidation - Exit during regeneration.
- (2) Top/Outlet during sulfidation - Inlet during regeneration.
- (3) Helium Density.
- (4) Nitrogen Adsorption.
- (5) Average and standard deviation of 15 measurements.

TABLE 13

PARTICULATE SAMPLING DATA  
 HOT GAS DESULFURIZATION TEST UNIT  
 GASIFIER RUN 102

TEST #	HOURS FROM START OF TEST	PARTICLE LOADING		MEDIAN PARTICLE SIZE		CHEMICAL ANALYSIS				
		g/m³		um (microns)		C	H	N	S	ASH
		INLET	EXIT	INLET	EXIT					WT %
006	1.18	0.74		21.5		77.1	4.5	2.2	2.0	2.5
008	0.16	0.72		25.5		85.7	4.6	2.1	2.2	5.9
009	1.25		0.53		26.6	NM	NM	NM	NM	NM
011	6.33		0.34		20.9	58.5	3.2	1.4	1.5	33.8

## NOTES:

1. NM = Not Measured due to insufficient sample size. Particles embedded in ceramic filter.

Table 14

DATE: 10/27/83  
 SAMPLE: DE BAGNELL 619201 83-872  
 ELECTROLYTE: ISOTON  
 DISPERSANT: LOHAR D  
 EQUIPMENT: TA II  
 APERTURES: 280  
 OPERATOR: RDB

CH. #	SIZE	DIFF	CUM
		VOL %	VOL %
*****			
1	4	.1	100
2	5.04	2.1	99.9
3	6.35	2.3	97.8
4	8	3.4	95.5
5	10.08	7	92.1
6	12.7	13.5	85.1
7	16	17.3	71.6
8	20.16	16.6	54.3
9	25.4	13.9	37.7
10	32	9.3	23.6
11	40.32	7.1	14.5
12	50.8	2.8	7.4
13	64	2.8	4.6
14	80.63	.1	1.8
15	101.59	1.8	1.7
16	128	.1	0

PARTICULATE SIZE DISTRIBUTION  
 TEST 006 INLET

\*\*\*\*\*  
 VOLUME % STATISTICS  
 \*\*\*\*\*

MEAN:	22.1 UM
MEDIAN:	21.45 UM
MODE:	19.48 UM
STANDARD DEVIATION:	1.8 UM
SKEWNESS:	1.05 POSITIVE
KURTOSIS:	1.5 PLATYKURTIC




Table 15

DATE: 10/27/83  
 SAMPLE: DE BAGNELL 200 T2 83-881  
 ELECTROLYTE: ISOTON  
 DISPERSANT: LOMAR D  
 EQUIPMENT: TA II  
 APERTURES: 200  
 OPERATOR: ROB

CH.#	SIZE	DIFF	CUM VOL %	CUM VOL %
1	2.50	0	100	
2	3.18	2.7	100	
3	4	1.9	97.3	
4	5.04	2.1	95.4	
5	6.35	2.6	93.3	
6	8	3.5	90.7	
7	10.08	6.1	87.2	
8	12.7	8.5	81.1	
9	16	11.1	72.6	
10	20.16	11.3	61.5	
11	25.4	6.2	50.2	
12	32	6.7	42	
13	40.32	6.2	33.3	
14	50.8	7.6	27.1	
15	64	1.6	19.7	
16	80.64	1.6	18.1	
17	101.6	4.0	16.6	
18	128.01	4.0	12.3	
19	161.28	4.0	7.6	
20	203.2	3.6	3.4	
21	256.02	.1	.1	
22	322.56	.1	0	

## PARTICULATE SIZE DISTRIBUTION TEST 008 INLET

### VOLUME % STATISTICS

MEAN: 29.14 UM  
 MEDIAN: 25.54 UM  
 MODE: 20.44 UM  
 STANDARD DEVIATION: 2.77 UM  
 SKEWNESS: 1.26 POSITIVE  
 KURTOSIS: 16.07 LEPTOKURTIC




Table 16

DATE: 10/31/83  
 SAMPLE: CHI BAGNELL 609-29-3 83-873  
 ELECTROLYTE: ISOTON  
 DISPERSANT: LOMAR D  
 EQUIPMENT: TR II  
 APERTURES: 280  
 OPERATOR: REC

CH.#	SIZE	DIFF	CUM
		VOL %	VOL %
1	4	0	100
2	5.04	3.1	100
3	6.35	3.5	96.9
4	8	4.6	93.4
5	10.08	7.1	88.8
6	12.7	9.2	81.7
7	16	10.7	72.5
8	20.16	9.4	61.8
9	25.4	11.6	52.4
10	32	10.7	40.8
11	40.32	7.1	30.1
12	50.8	5.6	23
13	64	3.4	17.4
14	80.63	4.3	14
15	101.59	4.1	9.7
16	128	5.6	5.6

-53-

## PARTICULATE SIZE DISTRIBUTION

### TEST 009 EXIT

\*\*\*\*\*  
 VOLUME % STATISTICS  
 \*\*\*\*\*

MEAN: 27.72 UM  
 MEDIAN: 26.62 UM  
 MODE: 29.93 UM  
 STANDARD DEVIATION: 2.31 UM  
 SKEWNESS: 1.14 NEGATIVE  
 KURTOSIS: 3.2 LEPTOKURTIC




Table 17

SAMPLE: DE BRISBELL 280 609304 83-874

ELECTROLYTE: ISOTON

DISPERSANT: LOMAR D

EQUIPMENT: TA II

APERTURES: 280

OPERATOR: RDB

CH. #	SIZE	DIFF	CUM VOL %
		VOL %	VOL %
1	4	.1	100
2	5.04	5.4	99.9
3	6.35	6	94.5
4	8	7	88.5
5	10.03	9	81.5
6	12.7	10.9	72.5
7	16	10.3	61.6
8	20.16	7.3	51.3
9	25.4	7.7	44
10	32	8.6	36.3
11	40.32	6.8	27.7
12	50.8	8.6	20.9
13	64	5.5	14.3
14	80.63	3.3	8.3
15	101.59	5.2	5.5
16	128	.1	.3

**PARTICULATE SIZE DISTRIBUTION**  
**TEST 011 EXIT**

\*\*\*\*\*  
**VOLUME % STATISTICS**  
\*\*\*\*\*

MEAN: 22.93 UM  
 MEDIAN: 20.91 UM  
 MODE: 15.16 UM  
 STANDARD DEVIATION: 2.32 UM  
 SKEWNESS: 1.12 POSITIVE  
 KURTOSIS: 2.83 PLATYKURTIC




Table 18

DATE: 11/1/83

SAMPLE: HGDS BAGNELL ARKWRIGHT DUST 83-876

ELECTROLYTE: ISOTON

DISPERSANT: LONAR D

EQUIPMENT: TA II

APERTURES: 560

OPERATOR: REC

\*\*\*\*\*

CH. # SIZE DIFF CUM

VOL % VOL %

\*\*\*\*\*

1	8	0	100
2	10.08	2.6	100
3	12.7	3.1	97.4
4	16	2.3	94.3
5	20.16	2.9	92
6	25.4	4.7	89.1
7	32	7.6	84.4
8	40.32	10.4	76.8
9	50.8	16.3	66.4
10	64	19.9	50.1
11	80.63	16.1	30.2
12	101.59	8.7	14.1
13	128	3.6	5.4
14	161.27	.7	1.8
15	203.19	1.1	1.1
16	256	0	0

**PARTICULATE SIZE DISTRIBUTION  
ARKWRIGHT DUST**

\*\*\*\*\*  
 VOLUME % STATISTICS  
 \*\*\*\*\*

MEAN: 57.5 UM  
 MEDIAN: 84.13 UM  
 MODE: 71.66 UM  
 STANDARD DEVIATION: 1.34 UM  
 SKEWNESS: .85 NEGATIVE  
 KURTOSIS: 1.62 PLATYKURTIC




Table 19

DATE: 11/1/83

SAMPLE: HGDS BAGNELL BRIQUETTE DUST 83-878

ELECTROLYTE: ISOTON

DISPERSANT: LOHAR D

EQUIPMENT: TA II

APERTURES: 560

OPERATOR: REC

CH. #	SIZE	DIFF	RUN
		VOL. %	VOL. %
1	8	0	100
2	10.08	2.8	100
3	12.7	6.4	97.2
4	16	6	99.8
5	20.16	8.7	84.8
6	25.4	13.2	78.1
7	32	16.5	62.9
8	40.32	16	46.4
9	50.8	14.6	30.4
10	64	9.5	15.8
11	80.63	4.5	6.3
12	101.59	1.1	1.8
13	128	.4	.7
14	161.27	.1	.3
15	203.19	.1	.2
16	256	.1	.1

-556-

## PARTICULATE SIZE DISTRIBUTION BRIQUETTE DUST

### VOLUME % STATISTICS

MEAN: 37.06 UM  
 MEDIAN: 38.35 UM  
 MODE: 39.17 UM  
 STANDARD DEVIATION: 1.73 UM  
 SKEWNESS: .93 NEGATIVE  
 KURTOSIS: 1.28 PLATYKURTIC




Table 20

ULTIMATE ANALYSIS OF COALS  
USED DURING GASIFIER RUN 102

COMPONENT	WT %		
	PITTSBURGH SEAM COAL		BLACKSVILLE BRIQUETTES
	ARKWRIGHT	BLACKSVILLE	
Moisture	0.39	1.1	0.96
Ash	7.15	10.55	15.33
S	1.82	3.20	2.39
H	5.12	5.58	1.72
N	3.05	1.30	1.29
Total Carbon	77.10	73.17	70.49
Volatile	38.35	38.25	34.14
Btu/lb	13715	13310	12615

Table 21

TRACE COMPONENTS IN EXIT GAS  
DURING SULFIDATION  
GASIFIER RUN 102

COMPONENT	TESTS 006 AND 008	
	AQUEOUS CONDENSATE ANALYSIS ppmw	CALCULATED GAS PHASE COMPOSITION ppmw
Ni	4.15	0.221
V	<0.05	<0.003
Cr	1.21	0.064
K	3.73	0.199
Na	3.06	0.064
Fe	11.68	0.622
Zn	4.89	0.260
Ca	1.77	0.094
Al	0.382	0.020
Se	0.005	0.0002
As	1.52	0.081
Hg	<0.2	<0.011
F	64	3.40
Cl	1899	101.02
Br	10.8	0.574
NO <sub>3</sub>	13.2	0.702
SO <sub>4</sub>	332	17.662
NO <sub>4</sub>	<3	<0.159
NH <sub>4</sub>	10074	535.93
Cu	<0.02	<0.001

## NOTES:

1. Aqueous condensate analysis from Sample # 100011.
2. Sampling location is at condenser CIC knockout.
3. Sample is a composite sample of HGD tests 006 and 008.
4. Metals determined by atomic absorption/atomic emission spectroscopy.
5. Anions and cations determined by ion chromatography.

Table 22

COMPOSITE ULTIMATE ANALYSIS  
OF EXIT TAR CONDENSATE  
DURING SULFIDATION  
GASIFIER RUN 102

COMPONENT	TESTS 6 AND 8
	WT %
Ash	0.13
S	3.13
H	7.36
N	1.25
Total Carbon	72.94

NOTES:

1. Sample Number 28244
2. Sample Location is at Condenser CIC Knockout.

Table 23

**TAR ULTIMATE ANALYSIS  
AT HOT GAS DESULFURIZATION INLET**

TEST # TYPE	SAMPLE NO.	DATE TIME	ASH	S	H	T.C.	N
Shortly after Test 008 Sulfidation	28338	9/22/83 04:00	0.10	0.98	8.45	66.12	1.05
Between Tests 009 and 011 Sulfidation	28340	9/30/83 14:30	0.09	1.08	7.67	66.32	1.14

## NOTES:

1. Sampling location is S-4 after gasifier cyclone.
2. Sample No. 28338 obtained during operation on Oxygen Blown Arkwright coal.
3. Sample No. 28340 obtained during operation on Air-Blown Blacksville Briquettes.

TABLE 24

TRACE COMPONENTS IN INLET GAS  
DURING SULFIDATION  
GASIFIER RUN 102

COMPONENT	AQUEOUS CONDENSATE			CALCULATED GAS PHASE COMPOSITION
	TEST 006	TEST 008	AVERAGE TEST 006 & 008	
	PPMW	PPMW	PPMW	PPMW
Ni	0.71	0.24	0.475	0.022
V	<0.05	<0.05	<0.05	<0.0023
Cr	4.3	2.3	3.3	0.155
K	1.5	0.79	1.9	0.087
Na	10.9	6.6	8.75	0.411
Fe	6.8	4.0	5.4	0.254
Zn	<0.1	<0.1	<0.1	<0.005
Ca	6.1	6.6	6.35	0.298
Al	1.4	2.5	1.95	0.092
Se	0.348	0.03	0.189	0.009
As	0.35	0.23	0.29	0.014
Hg	<0.2	0.23	0.215	0.010
Cu	<0.02	<0.02	<0.02	<0.0009
F	140	124	132	6.204
Cl	3445	4659	4052	190
Br	26	42	34	1.598
SO <sub>4</sub>	155	23	89	4.183
PO <sub>4</sub>	<3	<3	<3	<0.141
NO <sub>3</sub>	<2	<2	<2	<0.094
NH <sub>4</sub>	13,763	14,072	13,917	654

## NOTES:

1. Gas phase composition is calculated from average of Test 006 and Test 008 aqueous condensate data and gas flow rate from which the condensate was obtained.
2. Aqueous condensate data obtained from HGD inlet particulate sampling system.
3. Test 006 aqueous condensate data from sample #GI-9-20-1.
4. Test 008 aqueous condensate data from sample #GI-9-21-2.

TABLE 25

TRACE COMPONENTS DURING SULFIDATION  
 GASIFIER RUN 102  
 HGD TESTS 006 AND 008

COMPONENT	CALCULATED GAS PHASE COMPOSITIONS		CHANGE
	INLET	EXIT	
	PPMW	PPMW	PPMW
Ni	0.022	0.221	+0.199
V	<0.0023	0.003	+0.0007
Cr	0.155	0.064	-0.091
K	0.089	0.199	+0.11
Na	0.411	0.163	-0.240
Fe	0.254	0.622	+0.368
Zn	<0.005	0.260	+0.255
Ca	0.298	0.094	-0.204
Al	0.092	0.020	-0.072
Se	0.009	0.0002	-0.008
As	0.014	0.081	+0.067
Hg	0.010	0.011	+0.001
Cu	<0.0009	0.001	+0.0001
F	6.204	3.4	-2.8
Cl	190	101.02	-89
Br	1.598	0.574	-1.024
SO <sub>4</sub>	4.183	17.662	+13.48
PO <sub>4</sub>	<0.141	0.159	+0.018
NO <sub>3</sub>	<0.094	0.702	+0.608
NH <sub>4</sub>	654	535.93	-118

## NOTES:

1. Inlet data calculated from aqueous condensate obtained at HGD inlet at particulate sampling tap. Average of samples GI-9-20-1 and GI 9-21-2 used.
2. Exit data calculated from aqueous condensate obtained on condenser CIC knockout. A composit of tests 006 and 008 was used. Sample #100011.

Table 26  
 TRACE COMPONENTS IN EXIT GAS CONDENSATE  
 DURING REGENERATION  
 GASIFIER RUN 102

COMPONENT	AQUEOUS CONDENSATE TEST 007		
	SAMPLE # 100004 ppmw	SAMPLE # 100008 ppmw	AVERAGE ppmw
Ni	1.41	1.37	1.39
V	<0.05	<0.05	<0.05
Cr	1.39	1.33	1.36
K	0.66	0.600	0.63
Na	0.71	0.641	0.67
Fe	82.4	79.0	80.2
Zn	1.83	1.77	1.8
Ca	1.54	1.43	1.48
Al	1.68	1.67	1.68
Se	0.039	<0.5 ppb	<0.02
As	0.538	1.14	0.84
Hg	<0.2	<0.2	<0.2
F	9.3	8.7	9
Cl	404	322	363
Br	<1	108	54.5
NO <sub>3</sub>	270	<2	136
SO <sub>4</sub>	281	259	270
PO <sub>4</sub>	0.55	<3	<1.8
NH <sub>4</sub>	270	200	235
Cu	0.025	<0.02	<0.022

NOTES:

1. Metals determined by atomic absorption/atomic emission spectroscopy.
2. Anions and cations determined by ion chromatography.
3. Sampling location is at condenser CIC knockout.

Table 27 (revision)

**TRACE COMPONENTS IN EXIT GAS CONDENSATE  
DURING REGENERATION  
GASIFIER RUN 102**

COMPONENT	AQUEOUS CONDENSATE			
	TEST 010		TEST 012	
	PPMW	PPMW	PPMW	PPMW
	SAMPLE #100009	SAMPLE #100288	SAMPLE #100010	SAMPLE #100289
Ni	0.750	0.56	1.41	1.90
V	0.197	<0.05	<0.05	<0.05
Cr	1.56	1.1	3.33	3.61
K	no.sample	1.08	0.743	0.887
Na	no.sample	0.959	1.51	0.831
Fe	272.8	240.8	110.8	118.9
Zn	no.sample	6.90	2.98	3.14
Ca	no.sample	8.30	3.02	1.11
Al	no.sample	0.999	0.77	0.739
Se	<0.120	0.040	0.121	0.021
As	0.298	0.30	4.401	5.72
Hg	no.sample	0.255	<0.2	<0.2
F	26.1	25	28.9	45
Cl	695	688	545	688
Br	19.9	<4	526	415
NC <sub>3</sub>	<2	492	<2	<2
SO <sub>4</sub>	3059	1043	393	1469
PO <sub>4</sub>	<3	<3	<3	<3
NH <sub>4</sub>	226	200	281	266
Cu	<0.02	<0.02	0.022	0.031

**NOTES:**

1. Duplicate aqueous condensate analysis for Test 010 from sample #100009 and #100288.
2. Duplicate aqueous condensate analysis for Test 012 from sample #100010 and #100289.
3. Metals determined by atomic absorption/atomic emission spectroscopy.
4. Anions and cations determined by ion chromatography.
5. Sampling location is at condenser C1C knockout.

TABLE 28

HGD EXIT CONDENSATE  
GASIFIER RUN 102

COMPONENT	IHI-KEMRON SAMPLE # HG2-2A-102 HGD TEST 011	AQUEOUS mg/l	IHI-KEMRON SAMPLE # HG2-1A-102 HGD TEST 006	HYDROCARBON mg/l
Chloride, Dissolved (Cl)	1600		300	
Cyanide, Total (Cn)	12		88	
Nitrogen, Ammonia, Total (N)	14,000		2,500	
Phenolics, Total (Phenol)	3,200		32,000	
Sulfate, Dissolved (SO <sub>4</sub> )	240		<100	
Sulfide (s)	530		200	
Sulfite (SO <sub>3</sub> )	220		49	
Fluoride, Total (F)	120		85	
Thiocyanate, Total (SCN)	220		510	
Arsenic, Total (As)	0.37		0.77	
Iron, Total (Fe)	- 5.0		12.2	
Lead, Total (Pb)	<0.05		<0.05	
Calcium, Total (Ca)	0.8		5.9	
Potassium, Total (K)	0.32		14.5	
Vanadium, Total (V)	<0.2		<0.2	
Zinc, Total (Zn)	2.1		4.2	
Sodium, Total (Na)	-		13	

## NOTES:

1. Sampling location is at condenser C1C knockout.

## APPENDIX G

### Sidestream Testing - Gasifier Run No. 103

Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 103

#### Introduction

A third series of tests with the high-temperature, sidestream desulfurization unit (1,2) was carried out during fixed-bed gasifier Run No. 103 (3,4,5) between November 7 and 18.

The purpose of the tests was to characterize further the behavior of zinc ferrite sorbent in coal gas from various coals. A particular interest was to investigate more closely the magnitude and cause of the increase in reactor differential pressure during sulfur absorption periods.

#### Operation of Sidestream Test Unit

The sidestream unit was operated with a single batch of sorbent in the reactor for four sulfidation periods and three intermediate regeneration periods. The gasifier was operated in the air-blown mode and fed with Blacksville, Arkwright, and Kittanning coals. The operational schedule is shown in Figure 1.

As usual, the reactor contained 20.4 kg of zinc ferrite extrusions. Reactor furnace temperatures were set at 1,000°F throughout all the sulfidation and regeneration periods. A lower minimum space velocity than previously of 1,000 h<sup>-1</sup> for the sulfidation was thought to give a more acceptable reactor pressure drop. The space velocity during the regenerations was about 500 h<sup>-1</sup>.

Average operating parameters for the tests are shown on the ADACS flow schematics in Figures 2 to 13. Because of interruptions in the gasifier operation, Tests 017 and 019 are broken down into parts when the sidestream unit was on stream.

In Test No. 013, with the gasifier providing gas from Blacksville coal at about 120 psig, breakthrough of hydrogen sulfide occurred after about 46 hours during which time the H<sub>2</sub>S level was about 5 ppm initially, but drifted to about 20 ppm later. The reactor pressure drop gradually rose from about 2 inches to more than 100 inches of water, slowly at first, but more rapidly later. Pressure drop fluctuations occurred when condensate was dumped from the reactor exit condenser. These were caused by surges of gas through the reactor and consequent movement of the sorbent extrusions. This bed movement may have caused some channeling and accounted for the higher than expected H<sub>2</sub>S levels towards the end of the test before breakthrough. As before, an increase in reactor temperatures approaching 100°F, occurred through partial sorbent reduction and the shift reaction. Reactor temperatures, pressure drop, and gas flow rates are shown in Figures 14, 15, and 16.

Regeneration of the sorbent in Test No. 014 required about 24 hours, the steam to air volume ratio being about 85/15. Except for the reactor inlet temperature, which peaked sharply up to about 1,700°F, the reaction zone temperature

reached about 1,300°F, some 100°F lower than desired. Reactor pressure drop gradually fell, more rapidly at first from about 20 to 2 inches of water. Reactor temperatures, pressure drop, and flow rates are shown in Figures 17, 18, and 19.

Test 015, the second sulfidation in which the gasifier provided gas from Arkwright coal at about 120 psig, lasted 40 hours and was terminated prematurely because of an excessive pressure drop increase from about 2 inches, initially to about 160 inches of water, finally. H<sub>2</sub>S levels were similar to those in the first sulfidation, except initially when both H<sub>2</sub>S and SO<sub>2</sub> were high because of sulfur compounds left in the sorbent after regeneration. Reactor exit condensate was dumped more frequently than in the previous sulfidation so that the resulting gas surges caused movement of the extrusions (presumably) with consequent pressure drop decrease, thus extending the test longer before an unacceptable pressure drop was reached. As in previous sulfidations, there was a small temperature rise along the reactor length. Reactor temperatures, pressure drop, and flow rate are shown in Figures 20, 21, and 22.

Test 016 was the second regeneration of the sorbent. In this case, the steam to air ratio was decreased stepwise from 85/15 initially to 75/25 during the first few hours to ensure that the temperature in the reaction zone reached the desired level of about 1,500°F. The duration was consequently rather shorter, about 20 hours. Pressure drop was about 70 inches of water for the first few hours and then rapidly fell to about 5 inches of water at the same time that the steam/air ratio was decreased, i.e., the air flow was increased. Reactor temperatures, pressure drop, and flow rates are shown in Figures 23, 24, and 25.

In Test 017, the third sulfidation of the series, gas was provided from Kittanning coal at 120 psig for about 43 hours until this coal was used up. Then, for a further 13 hours until H<sub>2</sub>S breakthrough, the gas came from Arkwright coal at about 240 psig. H<sub>2</sub>S levels were less than 10 ppm for the Kittanning coal gas except for a short initial period when the values were again high, resulting from residual sulfate in the sorbent; for the Arkwright coal gas H<sub>2</sub>S levels slowly drifted up to the 20 ppm level. Very surprisingly, the reactor pressure drop remained at the low level of about 5 inches of water for the entire duration of the test. As in previous sulfidations, there was a moderate temperature increase along the reactor length because of the shift reaction. Reactor temperatures, pressure drop, and flow rate are shown in Figures 26, 27, and 28.

In Test 018, the third regeneration, the steam/air ratio was again decreased stepwise from 85/15 to 75/25 but more rapidly than before, resulting in a shorter duration of about 12 hours. The reactor pressure drop gradually fell as before but not as far and was finally about 10 inches of water compared to 5 inches previously. Reactor temperatures peaked at about 1,500°F, the design level. Reactor temperatures, pressure drop, and flow rates are shown in Figures 29, 30, and 31.

Test 019 was the fourth and final sulfidation of the test series. Gas was again derived from Arkwright coal but, in contrast to Test 015, the gasifier pressure was twice as high, at 240 psig. Because the gasifier was shut down

prematurely, H<sub>2</sub>S breakthrough did not occur and the test lasted about 24 hours. The reactor pressure drop, initially about 4 inches of water, increased at a much lower pace than in Test 015 even accounting for the lower pressure drop resulting from the higher operating pressure. H<sub>2</sub>S levels were less than about 10 ppm. Reactor temperatures, as usual, showed a moderate increase of less than 100°F along the reactor length. Reactor temperatures, pressure drop, and flow rate are shown in Figures 32, 33, and 34.

## Results

- Data Summary

The various process conditions and data collected in Test Nos. 013 to 019 are summarized in Figures 35 to 41.

- Absorption of Sulfur Compounds

Table 1 gives laboratory gas chromatographic analyses, including major and trace components, of grab samples of gas exiting the hot gas desulfurization unit condenser (6). Corresponding analyses for grab samples of inlet gas from the gasifier cyclone exit are given in Tables 2 and 3, covering the sulfidation tests only. The values for H<sub>2</sub>S, COS, CS<sub>2</sub>, and thiophene (C<sub>4</sub>H<sub>4</sub>S) respectively at both unit inlet and outlet during the sulfidation tests are plotted on semilog plots in Figures 42 to 45. On the average, H<sub>2</sub>S is reduced from a few thousand ppm to a few ppm, COS from a few hundred ppm to a few ppm, and CS<sub>2</sub> and thiophene from a few tens of ppm to a few ppm, so that the total average level of these low molecular weight sulfur compounds is lowered to less than about 10 ppm.

The hydrogen sulfide concentration in exit gas from the unit was also measured during the sulfidation tests by the Baseline Industries on-line gas chromatograph and by detector tubes. The values obtained are plotted against on-stream time in Figures 46 to 49, together with some values for sulfur dioxide measured by detector tubes. There is generally satisfactory agreement between the H<sub>2</sub>S values measured by the two techniques except when they depart widely from the gas chromatograph calibration point of 3 ppm H<sub>2</sub>S. As found previously, the H<sub>2</sub>S and SO<sub>2</sub> levels in gas from regenerated sorbent are initially high but fall off fairly rapidly. The Baseline gas chromatograph values for H<sub>2</sub>S, COS, and SO<sub>2</sub> are compared in Figures 50 to 53. The COS levels can be seen to be less than the H<sub>2</sub>S levels. SO<sub>2</sub> levels generally are comparable with the detector tube values in Figures 46 to 49.

The amount of sulfur absorbed before breakthrough was considerably greater than in the previous tests at higher space velocities. As a weight percentage of fresh sorbent, the amount is: Test 013, ~ 29; Test 015, ~ 23; and Test 017, ~ 14, indicating a decline of sorption efficiency with cycling. It is difficult to attribute a trend to this, however, because of the variation in sulfur content of gas from the different coals.

- Gas Analysis for Major Species

In addition to the laboratory gas chromatographic analysis of major species in inlet and exit gas given in Tables 1 and 2, gas to and from the unit was analyzed by Bendix on-line chromatographs. The measurements, averaged by ADACS statistical analysis, are shown in Tables 4 to 16. The gas line to chromatograph 6,000 # 1 became partially blocked during the tests so that the readings from chromatograph 6,000 # 2 give a more reliable indication of the inlet gas composition.

Some of the sulfidation exit samples in Table 1 indicate an excessive oxygen content, which should not exceed about 1 vol. percent. This may be because air was not completely displaced from the grab sample bottles.

As before, it can be seen that the carbon monoxide shift reaction proceeds to a large extent, illustrated by Figures 54 to 56, based on Tables 1 and 2. There is an apparent small loss of total carbon oxides, presumably because of carbon formation.

- Analysis of Regeneration Exit Gas

The regeneration exit gas (see Tables 1, 5, 7, and 13) in the first part of the regenerations contains substantial quantities of hydrogen, carbon oxides, and reduced sulfur compounds, predominantly hydrogen sulfide but with some carbonyl sulfide and carbon disulfide.

This may be explained by the reaction of the regeneration gas with iron/iron carbide/carbon in the sorbent. Towards the end of the regeneration, sulfur in the regeneration exit gas is mainly in the form of sulfur dioxide with no hydrogen and carbon monoxide and little carbon dioxide present.

ADACS plots of CO<sub>2</sub>, H<sub>2</sub>S, O<sub>2</sub>, CO, and H<sub>2</sub> in the regeneration gas from the reactor exit condenser are shown in Figures 57 to 61 (Test No. 014) and Figures 62 to 66 (Test No. 018).

- Sorbent Characterization

The sulfidized sorbent after Test No. 019 was sampled, on removal, at points along the reactor length and characterized by various techniques. The results are shown in Tables 17 and 18. As found previously (2), at similar gas conditions, the sorbent is seen to contain large amounts of cementite, particularly towards the reactor outlet. Pyrrhotite is only found near the reactor inlet where there is also some unsulfidized magnetite. The bulk of the zinc oxide at the reactor inlet has been converted to sulfide (see Table 17).

Table 18 shows that the sorbent contains up to 25 wt. percent sulfur at the reactor inlet. Carbon content, lower at the inlet, exceeds 7 wt. percent towards the outlet. Values of surface area and pore volume at the reactor inlet are comparable to those of fresh sorbent. Values towards the reactor outlet significantly exceed those for fresh sorbent which may be accounted for by the reduction of the sorbent to cementite.

Similarly, sorbent crush strength is comparable to that for fresh sorbent at the reactor inlet, but is significantly lower at the outlet (see Table 18). About a third of the sorbent passed through a No. 12 screen as fines. This disintegration is mostly ascribed to the formation of cementite and its weakening effect.

- Particulate Analysis

During Test Nos. 013, 015, and 017, samples of inlet and outlet gas were taken to characterize the particulate content (7). In this series, both inlet and outlet samples were obtained for each test (though not at the same time) to get some idea of the change in particulate loading and size distribution for the gas in passing through the reactor. The results are summarized in Table 19. Details of particulate size distribution are given in Tables 20 to 25.

The particulate loading of the inlet gas was similar for the three tests, approximately 1 to 2 g/Nm<sup>3</sup>. The median particle size was highest for Arkwright coal gas, ~ 26 µm (Test No. 015), somewhat less for Blacksville coal gas, ~ 21 µm (Test No. 013), and least for Kittanning coal gas, ~ 13 µm (Test No. 017). For each test, a significant proportion of the particulate appeared to be removed by the sorbent bed, reaching about 80 wt. percent in Test No. 017.

Larger particles appear to be removed preferentially, so that the median particle size at the outlet is significantly less than at the inlet, ~ 22 µm for Arkwright coal gas, ~ 14 µm for Blacksville coal gas, and ~ 5 µm for Kittanning coal gas.

There appears to be a positive correlation between the median particulate size in the inlet gas and the rate of increase of reactor pressure drop in a given sulfidation test, which was highest for Arkwright coal gas, somewhat less for Blacksville coal gas, and much less for Kittanning coal gas. Smoothed out pressure drop plots for the sulfidation tests are shown in Figure 67. The chemical analysis of the particulate samples, see Table 19, indicates that there is little difference between inlet and outlet particles, leading to the conclusion that little attrition was being experienced.

- Condensate Analysis

Reactor exit gas condensates were collected from all the tests and composite samples analyzed for minor and trace constituents (6). Values for the sulfidation tests are shown in Table 26 and for the regeneration tests in Table 27. A check analysis taken several months later for certain constituents is also included.

The analyses are similar to those obtained in previous test series. The regeneration condensate is enriched in most of the constituents but particularly in halides, ammonia, and alkali metals. Assuming that the constituents in the regeneration condensate derive from the gas flowing through the reactor in the preceding sulfidation test, it is possible to estimate the proportion removed by the sorbent based on the quantities

of condensate collected (see Figures 35 to 41) and the condensate analysis.

Thus, 7 to 21 percent of NH<sub>4</sub>, 27 to 59 percent of Cl, and 40 to 74 percent of Na are calculated to be removed from the gas by the sorbent and released into the regeneration gas.

Table 28 shows the analyses of the tar condensate collected from the sulfidation tests at the unit exit. These tars are seen to constitute up to 0.8 wt. percent of the exit gas and contain up to 3.8 wt. percent of sulfur. For comparison, analyses of tar condensates collected at the unit inlet (S4 sample point at gasifier primary cyclone exit) are shown in Table 29. The sulfur levels in these are significantly less than in the exit tars suggesting that the sulfur compounds in them are notably refractory to cracking and hydrodesulfurization. Ultimate analyses of the coals used in the test series are shown in Table 30.

Condensate was also collected in the course of taking particulate samples (7). The analyses of the aqueous parts are shown in Table 31. These have been translated into calculated gas phase compositions for sulfidation Test Nos. 013, 015, and 017 in Tables 32, 33, and 34 respectively. The outlet gas phase compositions calculated from the composite aqueous condensates in Table 26 are also included. Comparison between calculated inlet and outlet compositions generally substantiates the conclusion that a number of the gas components, particularly halides, ammonia, and alkali metals are removed by the desulfurization sorbent to some extent.

Inlet and outlet tar condensates from sulfidation Test No. 013 were analyzed by gas chromatograph/mass spectrometer for certain components as shown in Table 35. The principal sulfur compound, benzothiophene appears to be virtually unaffected. An apparently surprising result is that benzene, toluene, and xylenes are removed to a large extent; whereas, the concentrations of phenol and cresols are not changed much. This contrasts with previous test experience (8).

### Conclusions

A third series of tests of the hot gas desulfurization unit in a sidestream of the METC 24 t/d fixed-bed gasifier was successfully concluded. The zinc ferrite sorbent underwent three cycles of sulfidation and regeneration, gas being provided from three different bituminous coals.

The amount of sulfur absorbed at the lower space velocity of 1,000 h<sup>-1</sup> was comparable to that found at 2,000 h<sup>-1</sup> in previous tests. A substantial amount of the sorbent was again converted to iron carbide, which appears to resist sulfidation and also markedly reduces the crush strength and attrition resistance of the sorbent. In spite of this, low molecular weight sulfur compounds were removed to a level of less than about 10 ppm and the sorbent recovered virtually all its absorption capacity on regeneration. A greater number of cycles will of course be necessary to demonstrate the sorbent's long-term effectiveness.

Reactor pressure drop was studied more closely in this test series and it was found that there was a positive correlation between the median particulate size in gas to the unit and the rate of pressure drop increase. Very little pressure drop increase was evident during a sulfidation test for an inlet gas median particulate size of 13  $\mu\text{m}$ . Particulate gas loading was of the order of 1 g/Nm<sup>3</sup>. Carbon deposition may also affect the pressure drop, so the correlation should be regarded with caution.

Again, it was found that minor constituents of the gas, in addition to sulfur, are absorbed, particularly halides, alkali and alkaline earth metals and ammonia.

#### References

1. Grindley, T., "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 101," IR No. 1846, March 1984, METC.
2. Grindley, T., "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 102," IR No. 1984, September 1984, METC.
3. Pater, K., "Test Plan -- Run No. 103," IR No. 1821, March 1984, METC.
4. Pater, K., "Preliminary Test Summary -- Run No. 103," IR No. 1810 May 1984, METC.
5. Pater, K., "Process Summary Report -- Run No. 103," IR No. 2021, October 1984, METC.
6. Lamey, S. C., R. R. Romanosky, and J. J. Kovach, "Analytical Data -- Producer Run No. 103," IR No. 2069, November 1984, METC.
7. Bagnell, R. D., and R. J. Anderson, "Particulate Sampling and Analysis in Support of Hot Gas Desulfurization Tests and Minimally Clean, Low-Btu Gas Combustion Tests During Gasifier Run No. 103," IR No. 1865, November 1984, METC.
8. Green, D. A., K. E. Leese, and W. J. McMichael, "Pollution Control in Coal Gasification: Testing of Zinc Ferrite Catalyst," Research Triangle Institute for METC, Report No. DOE/MC/16441-1406 (1983).

ADDENDUM TO APPENDIX G

The Baseline G.C. on-line H<sub>2</sub>S, COS, and SO<sub>2</sub> readings as plotted are correct only for the points: H<sub>2</sub>S: 3 ppm; COS: 1.7 ppm; and SO<sub>2</sub>: 5.1 ppm. Calibration curves are available for correction. Corrected plots are given in Volume 1.

Refer to letter to T. Grindley from E. E. Gorski and P. Johnson, EG&G Washington Analytical Services Center, Inc. January 30, 1986. Subject: DOE-METC/EG&G Contract No. DE-AC21-85MC21353; WBS No. 9KEX-10. HGD Project: Baseline GC/Integrator Conversion Curves.

FIGURE 1

-574

013 SULFIDATION	<input type="checkbox"/> TEST 013 SULFIDATION TEMP 1000°F 8V 1000												
014 REGENERATION	<input type="checkbox"/> TEST 014 REGENERATION 15% AIR 85% STEAM												
015 SULFIDATION	<input type="checkbox"/> TEST 015 SULFIDATION TEMP 1000°F 8V 1000												
016 REGENERATION	<input type="checkbox"/> TEST 016 REGENERATION 15% AIR 85% STEAM												
017 SULFIDATION	<input type="checkbox"/> TEST 017 SULFIDATION TEMP 1000°F 8V 1000												
018 REGENERATION	<input type="checkbox"/> TEST 018 REGENERATION 15% AIR 85% STEAM												
019 SULFIDATION	<input type="checkbox"/> TEST 019 SULFIDATION TEMP 1000°F 8V 1000												
COAL TYPE	BLACKSVILLE	ARKWRIGHT	KITTANNING	ARKWRIGHT									
OXIDANT	AIR	AIR	AIR	AIR									
0 DAYS	11/7	11/8	11/9	11/10	11/11	11/12	11/13	11/14	11/15	11/16	11/17	11/18	12

SCHEDULE OF EVENTS  
HOT GAS DESULFURIZATION SIDESTREAM TESTING 1983  
GASIFIER RUN 103

FIGURE 2  
TEST  
AVERAGE OPERATING PARAMETERS






FIGURE 3  
TEST '14  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 17:30: 2 11/ 9/1983 TO 18:39:48 11/10/1983


FIGURE 4  
TEST 015

AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 101 6117    11/10/1983 TO 111 9134    11/18/1983

FIGURE 5  
TEST C  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 12:15:00 11/12/1983 TO 8:29:38 11/13/1983

FIGURE 6  
TEST O  
AVERAGE OPERATING PARAMETERS






FIGURE 7  
TEST O 3  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 201 01 1 11/14/1983 TO 3169155 11/18/1983

FIGURE 8  
TEST C  
AVERAGE OPERATING PARAMETERS




AVERAGE(S) FOR PERIOD FROM: 71 0110 11/16/1983 TO 81 4145 11/16/1983

FIGURE 9

## TEST C D

## AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM 12:10:4 11/16/1983 TO 16: 9:41 11/16/1983

FIGURE 10  
TEST O  
AVERAGE OPERATING PARAMETERS






FIGURE 11

TEST 9A  
AVERAGE OPERATING PARAMETERS




AVERAGE(8) FOR PERIOD FROM: 7:15:00 11/17/1983 TO 11:18:30 11/17/1983

FIGURE 12  
TEST O.  
AVERAGE OPERATING PARAMETERS



AVERAGE(0) FOR PERIOD FROM: 20:10:16 11/17/1983 TO 0:14:48 11/18/1983


FIGURE 13  
TEST 019C  
AVERAGE OPERATING PARAMETERS



AVERAGE(S) FOR PERIOD FROM: 14/10/84 11/10/1983 TO 23/09/86 11/10/1983

FIGURE 14

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O 851	DEGF	ABSORBER 5° FROM BOTTOM	5322	1011.	10.90	956.8	1 1050.
□ 852	DEGF	ABSORBER 15° FROM BOTTOM	5322	1017.	10.99	979.1	1 1081.
◊ 853	DEGF	ABSORBER 25° FROM BOTTOM	5322	1026.	20.91	987.8	2 1073.
△ 853	DEGF	ABSORBER 25° FROM BOTTOM	5322	1026.	20.91	987.8	2 1073.
▽ 854	DEGF	ABSORBER 35° FROM BOTTOM	5322	1054.	20.33	1016.	8 1081.




START TIME OF PLOT 17:10: 0 11/ 7/1983  
STOP TIME OF PLOT 15: 0: 0 11/ 9/1983

TEST 013

REACTOR TEMPERATURES

FIGURE 15

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
294	"H2O	ABSORBER DIFFERENCE PRESSURE	5322	28.78	25.63	-8.220	1	164.0	1




START TIME OF PLOT 17:10: 0 11/ 7/1983  
 STOP TIME OF PLOT 15: 0: 0 11/ 9/1983

TEST G13

REACTOR PRESSURE DROP

FIGURE 16

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
3750	SCFH	PROD. GAS OUT OF SYSTEM	5084	583.5	21.65	462.0	1	835.0	1




START TIME OF PLOT 17:10: 0 11/ 7/1983  
STOP TIME OF PLOT 15: 01: 0 11/ 9/1983

TEST 013

EXIT FLOW

FIGURE 17

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	851	DEGF ABSORBER 5° FROM BOTTOM	3022	1158.	86.25	1036.	2 1315.
D	852	DEGF ABSORBER 15° FROM BOTTOM	3022	1131.	74.64	1039.	12 1363.
O	853	DEGF ABSORBER 25° FROM BOTTOM	3022	1092.	61.96	1033.	3 1211.
A	854	DEGF ABSORBER 36° FROM BOTTOM	3022	1020.	144.3	955.0	1 1367.
V	855	DEGF ABSORBER 45° FROM BOTTOM	3022	946.6	61.42	904.6	4 1699. 1




START TIME OF PLOT 17:30: 0 11/ 9/1983  
STOP TIME OF PLOT 18:40: 0 11/10/1983

TEST 014

REACTOR TEMPERATURES

FIGURE 18

SLOT	UNITS	DESCRIPTION	# SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"H2O	• ABSORBER DIFFERENCE PRESSURE	2768	-9.591	5.513	-29.86	1
						4.118	1




START TIME OF PLOT      17:30: 0      11/ 9/1983  
STOP TIME OF PLOT        18:40: 0      11/10/1983

TEST 014

REACTOR PRESSURE DROP

FIGURE 19

SLOT	UNITS	DESCRIPTION	8 SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ	
O 3756	SCFH	AIR FLOW LOW RANGE	2843 2948	41.29 40.56	4.104 0.8868	0.0000E+00 5.179	3 1	82.82 15.31
D 3754	0/HR	STEAM FLOW						




START TIME OF PLOT      17:30: 0      11/ 9/1983  
 STOP TIME OF PLOT      18:40: 0      11/10/1983

TEST 014

STEAM AND AIR FLOWS

FIGURE 20

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O 851	DEGF	ABSORBER 5° FROM BOTTOM	4811	1015.	4.157	1007.	31 1040.
D 852	DEGF	ABSORBER 15° FROM BOTTOM	4811	1017.	17.59	998.8	1 1235.
◊ 853	DEGF	ABSORBER 25° FROM BOTTOM	4811	1035.	18.60	1003.	1 1176.
▲ 854	DEGF	ABSORBER 35° FROM BOTTOM	4811	1065.	12.95	1018.	1 1167.
▼ 855	DEGF	ABSORBER 45° FROM BOTTOM	4811	1053.	14.05	1001.	1 1101.




START TIME OF PLOT 19: 51: 0 11/10/1983  
STOP TIME OF PLOT 11:10: 0 11/12/1983

TEST 015

REACTOR TEMPERATURES

FIGURE 21

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ		MAX - FREQ	
894	"H2O	ABSORBER DIFFERENCE PRESSURE	4811	46.58	44.03	-0.9800	1	226.1	1




START TIME OF PLOT      19: 5: 0      11/10/1983  
 STOP TIME OF PLOT      11:10: 0      11/12/1983

TEST 015

REACTOR PRESSURE DROP

FIGURE 22

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
3750	SCFH	PROD. GAS OUT OF SYSTEM	4662	658.9	24.01	0.0000E+00 2	679.0 1




START TIME OF PLOT      19: 51: 0      11/10/1983  
STOP TIME OF PLOT      11:10: 0      11/12/1983

TEST 015

EXIT FLOW

FIGURE 23

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	851	ABSORBER 5° FROM BOTTOM	2430	1181.	161.8	989.7	1 1488.
O	852	ABSORBER 15° FROM BOTTOM	2430	1167.	136.5	1029.	10 1501.
O	853	ABSORBER 25° FROM BOTTOM	2430	1099.	71.40	1022.	1 1334.
A	854	ABSORBER 35° FROM BOTTOM	2430	1088.	89.32	985.6	1 1396.
V	855	ABSORBER 45° FROM BOTTOM	2430	1032.	74.90	924.5	1 1465.




START TIME OF PLOT  
STOP TIME OF PLOT

12:15: 0      11/12/1983  
8:30: 0      11/13/1983

TEST 016  
REACTOR TEMPERATURES

FIGURE 24

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	'H2O	ABSORBER DIFFERENCE PRESSURE	2098	-83.36	24.09	-85.32	1 -1.895




START TIME OF PLOT      12:15: 0      11/12/1983  
STOP TIME OF PLOT        8:30: 0      11/13/1983

TEST 016

REACTOR PRESSURE DROP

FIGURE 25

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O 3756	SCFH	AIR FLOW LOW RANGE	2430	66.91	16.11	0.0000E+00	4 85.19
D 3754	8/HR	STEAM FLOW	2430	9.926	0.6845	6.307	1 11.72




TEST 016

STEAM AND AIR FLOWS

FIGURE 26

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	BS1	ABSORBER 5° FROM BOTTOM	6761	949.6	10.88	931.2	1 971.6
D	BS8	ABSORBER 15° FROM BOTTOM	6769	989.2	13.17	963.0	1 1037.
C	BS3	ABSORBER 25° FROM BOTTOM	6524	1033.	7.510	1009.	1 1056.
A	BS4	ABSORBER 35° FROM BOTTOM	6766	1051.	15.15	998.7	1 1105.
V	BS5	ABSORBER 45° FROM BOTTOM	6758	1046.	12.53	1003.	4 1086.




START TIME OF PLOT 17:25: 0 11/13/1983  
STOP TIME OF PLOT 16:10: 0 11/16/1983

TEST 017

REACTOR TEMPERATURES

FIGURE 27

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"H20	ABSORBER DIFFERENCE PRESSURE	6940	6.004	1.298	-3.054	1 16.31




START TIME OF PLOT 17:25: 0 11/13/1983  
STOP TIME OF PLOT 16:10: 0 11/16/1983

TEST 017  
REACTOR PRESSURE DROP

FIGURE 28

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
3750	SCFH	PROD. GAS OUT OF SYSTEM	6418	553.9	39.23	354.3	1	943.2	1



TIME (HOURS)

START TIME OF PLOT  
STOP TIME OF PLOT


17:25: 0      11/13/1983  
16:10: 0      11/16/1983

TEST 017

EXIT FLOWS

FIGURE 29

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	851	INCF ABSORBER 5° FROM BOTTOM	1481	1291.	153.1	1091.	2 1480.
U	852	INCF ABSORBER 15° FROM BOTTOM	1481	1147.	143.7	1044.	2 1488.
O	853	INCF ABSORBER 25° FROM BOTTOM	1481	1085.	67.32	1043.	12 1396.
A	854	INCF ABSORBER 35° FROM BOTTOM	1481	1044.	98.67	999.6	3 1551.
V	855	INCF ABSORBER 45° FROM BOTTOM	1481	1028.	86.37	986.4	2 1486.




START TIME OF PLOT 17:40: 0 11/16/1983  
STOP TIME OF PLOT 6: 0: 0 11/17/1983

TEST 018

REACTOR TEMPERATURES

FIGURE 30

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"H2O	ABSORBER DIFFERENCE PRESSURE	1336	-16.43	3.380	-30.82	1
						-3.394	2




START TIME OF PLOT      17:40: 0      11/16/1983  
STOP TIME OF PLOT        6: 0: 0      11/17/1983

TEST 016

REACTOR PRESSURE DROP

FIGURE 31

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
0 3756	SCFM	AIR FLOW LOW RANGE	1475	63.00	12.11	0.0000E+00	9	94.84	1
11 3754	SCFM	STEAM FLOW	1410	11.50	1.410	0.0000E+00	5	42.58	1




START TIME OF PLOT      17:40: 0      11/16/1983  
 STOP TIME OF PLOT      6: 0: 0      11/17/1983

TEST 018

STEAM AND AIR FLOWS

FIGURE 32

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O 851	DEGF	ABSORBER 5° FROM BOTTOM	2717	975.1	5.760	964.2	1 997.1
H 852	DEGF	ABSORBER 15° FROM BOTTOM	2795	994.0	17.99	974.9	14 1070.
G 853	DEGF	ABSORBER 25° FROM BOTTOM	2854	1033.	12.66	1010.	3 1079.
A 854	DEGF	ABSORBER 35° FROM BOTTOM	2836	1052.	19.42	1011.	1 1144.
V 855	DEGF	ABSORBER 45° FROM BOTTOM	2862	1050.	19.43	1009.	3 1112.




START TIME OF PLOT      7:15: 0      11/17/1983  
 STOP TIME OF PLOT      23:30: 0      11/18/1983

TEST 019

REACTOR TEMPERATURES

FIGURE 33

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	'H2O	ABSORBER DIFFERENCE PRESSURE	2854	9.875	4.107	-27.17	1




START TIME OF PLOT      7:15: 0      11/17/1983  
STOP TIME OF PLOT      23:30: 0      11/18/1983

TEST 019

REACTOR PRESSURE DROP

FIGURE 34

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
3750	SCFH	PROD. GAS OUT OF SYSTEM	2775	570.0	40.05	263.6	1
						795.8	1



START TIME OF PLOT      7:15: 0      11/17/1983  
STOP TIME OF PLOT      23:30: 0      11/18/1983

TEST 019

EXIT FLOW

FIGURE 35

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION SIDESTREAM TEST UNIT**

TEST NO. : 013  
 DATE STARTED : 17:10 11/07/83  
 DATE ENDED : 15:00 11/09/83  
 TOTAL HOURS : 45.8 HOURS  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 13.03 LB SB

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLEX IRON OXIDE  
 50.0 MOLEX ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED  
 COAL TYPE : BLACKSVILLE  
 STEAM/COAL MASS RATIO: 0.494  
 STEAM/AIR MASS RATIO : 0.196

HGD OPERATING CONDITIONS

TEMPERATURE: 1027 °  
 PRESSURE : 117 PSIG

SPACE VELOCITY: 1006 HOURLY

	INLET MOLEX DRY BASIS (OIL FREE)	INLET MOLEX WET BASIS (OIL FREE)	EXIT MOLEX DRY BASIS (OIL FREE)	EXIT MOLEX WET BASIS (OIL FREE)	CONDENSATE
H <sub>2</sub> S	0.598				AQUEOUS : 87.5 LBS (ESTIMATED)
H <sub>2</sub> O			6.66 %		HYDROCARBON : 11.4 LBS (ESTIMATED)
CO <sub>2</sub>	10.52		15.61		TOTAL : 98.9 LBS (MEASURED)
CO	19.38		12.33		
H <sub>2</sub>	16.25		21.01		
CH <sub>4</sub>	2.93		2.94		
N <sub>2</sub>	48.58		46.30		
O <sub>2</sub>	0.66		0.68		
C <sub>2</sub> H <sub>6</sub>	0.25		1.17		

## FLOW:

TOTAL  
LB MOLES:

FLOW  
RATE: 563.9 SCFH

563.9 SCFH 604.1 SCFH

PURPOSE  
 SULFIDATION AT LOWER SPACE VELOCITY OF 1000 HOURLY  
 AT TEMPERATURE OF 1000 F.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (ZWT)	0.13	
SURFACE AREA: (SQ M/G)	3.13	
DENSITY : (G/CC)	6.16	
PORE VOLUME: (CC/G)	0.004316	
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (ZWT)	0.0	

DATA ABOVE FROM T001

EXIT SULFUR DATA:  
 SO<sub>2</sub> : 5.1 PPM INITIALLY  
 CIH<sub>4</sub>S: 3.1 PPM  
 SO<sub>2</sub>:

AQUEOUS	: 87.5 LBS	(ESTIMATED)	
HYDROCARBON	: 11.4 LBS	(ESTIMATED)	
TOTAL	: 98.9 LBS	(MEASURED)	

REMARKS

1. PACKED LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 G SR-10789 UNITED CATALYSTS
2. OVERALL PACKED LENGTH 53 7/8 INCHES
3. FLOW TO COMBUSTOR BY-PASSING HGD.
4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
5. INLET DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC 7000 #4 DATA SAMPLING AT GASIFIER CYCLONE EXIT.
6. REACTOR PRESSURE DROP INCREASED TO 108 INCHES OF WATER BY THE END OF THE RUN.

7. EXIT DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX GC 6000 #2 DATA.

CONCLUSIONS:

1. OPERATION AT LOWER SPACE VELOCITY OF 500 HOURLY EXTENDED THE TIME TO BREAKTHROUGH BY ALMOST A FACTOR OF TWO, COMPARED TO OPERATION AT SPACE VELOCITY OF 1000 HOURLY.
2. PRESSURE DROP INCREASED MORE GRADUALLY AS EXPECTED FOR LOWER FLOW, BUT STILL INDICATES CARBON BUILDUP.
3. SULFUR LOADING INCREASES TO 28.9 % AT LOWER SPACE VELOCITY.

FIGURE 36

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 014  
 DATE AND TIME STARTED : 17:30 11/9/83  
 DATE AND TIME ENDED : 18:40 11/10/83  
 TOTAL HOURS : 25.16  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

PURPOSE

FIRST REGENERATION OF SULFIDED SORBENT FROM TEST 013.  
 GASIFIER RUN 103.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (%WT)		
SURFACE AREA: (SQ M/6)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/6)		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (%WT)		

HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 1029 F  
 PRESSURE : 78.34 INCHES OF WATER (AVERAGE)  
 SPACE VELOCITY: 468 HOURLY

EXIT SULFUR DATA:

H<sub>2</sub>S : UP TO 3 % AT MID RUN (BY BENDIX GC)  
 SO<sub>2</sub> : HIGH SO<sub>2</sub> (> 16 %) INITIALLY.  
 0.3 % SO<sub>2</sub> AT END OF REGENERATION.

	INLET MOLE%	EXIT MOLE%
	WET BASIS	DRY BASIS
AIR	41.31 SCFH	15.8 %
H <sub>2</sub> O	10.47 %/HR	34.2 %
N <sub>2</sub>	0.0 SCFH	

BENDIX GC  
DATA AVAILABLE  
AT EXIT

	CONDENSATE
LIQUID	: 272.2 LBS
HYDROCARBON	: 272.2 LBS
TOTAL	: 272.2 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S SR-10769 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. FIRST REGENERATION ON SULFIDED SORBENT
4. UP TO 3 % H<sub>2</sub>S WAS OBSERVED AT EXIT BETWEEN 5-12 HOURS INTO THE REGENERATION AS MEASURED BY BENDIX GC 6000 #2.
5. MAXIMUM TEMPERATURE REACHED WAS 1699 F.

CONCLUSIONS

1. REGENERATION COMPLETED.
2. CARBON APPEARS TO BE BURNED/GASIFIED OFF WITHIN THE FIRST 11 HOURS AS OBSERVED BY CO<sub>2</sub> CONCENTRATION AT EXIT.

TOTAL LB MOLES:  
 FLOW RATE : 261.6 SCFH

FIGURE 37

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION SIDESTREAM TEST UNIT**

TEST NO. : 015  
 DATE STARTED : 19:05 11/10/83  
 DATE ENDED : 11:10 11/12/83  
 TOTAL HOURS : 40.08 HOURS  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 10.51 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO.: UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED  
 COAL TYPE : ARKWRIGHT

STEAM/COAL MASS RATIO: 0.481  
 STEAM/AIR MASS RATIO : 0.195

HGD OPERATING CONDITIONS  
 TEMPERATURE: 1950 F (AVERAGE)

PRESSURE : 119.5 PSIG (AVERAGE)

VELOCITY: 925 HOURLY

	INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%	CONDENSATE	ARKWRIGHT COAL
	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	RECOVERED HYDROCARBON TOTAL	83.9 LBS (ESTIMATED) 10.2 LBS (ESTIMATED) 94.1 LBS (MEASURED)

H<sub>2</sub>S 0.559

H<sub>2</sub>O 7.3 %

CO<sub>2</sub> 9.78

CO 20.57

He 15.31

CH<sub>4</sub> 1.02

N<sub>2</sub> 45.63

O<sub>2</sub> 0.63

C<sub>2</sub>H<sub>6</sub> 0.29

FLOW:

TOTAL  
VOL SEC3:

FLOW  
RATE: 557 SCFH

601 SCFH

PURPOSE  
 SECOND SULFIDATION AT LOWER SPACE VELOCITY OF 1000 HOURLY  
 AND TEMPERATURE OF 1900 F.

SORBENT ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR: (W/T)  
 SURFACE AREA: (SQ M/S)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/G)  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (W/T)

EXIT SULFUR DATA:  
 H<sub>2</sub>S : 25 PPM INITIALLY GRADUALLY DOWN TO 3 PPM

C<sub>4</sub>H<sub>10</sub>:  
 SO<sub>2</sub> : 30 PPM INITIALLY, DOWN TO UNDETECTABLE WITHIN  
 5 HOURS

- REMARKS
1. REACTOR LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES 23-746 1/2 S SR-10739 UNITED CATALYSTS
  2. OVERALL PACKED LENGTH IS 59 7/8 INCHES
  3. FLOW TO CONSUMTOR BY-PASSING HGD REACTOR.
  4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
  5. INLET DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX 60 5000 #2 DATA, SAMPLING AT GASIFIER CYCLONE EXIT.
  6. REACTOR PRESSURE DROP INCREASED GRADUALLY TO ABOVE 160 INCHES OF WATER.

7. EXIT DRY BASIS GAS ANALYSIS IS AVERAGE OF BENDIX 60 5000 #2 DATA, SAMPLING AT HGD EXIT.

CONCLUSIONS:

1. SECOND SULFIDATION AT LOWER SPACE VELOCITY RESULTED IN TIME TO BREAKTHROUGH SLIGHTLY SHORTER THAN THE FIRST SULFIDATION.
2. SULFUR REMOVED IS 19 % LOWER THAN DURING TEST 013, THE FIRST SULFIDATION.

FIGURE 38  
TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 016  
 DATE AND TIME STARTED : 12:15 11/12/83  
 DATE AND TIME ENDED : 08:30 11/13/83  
 TOTAL HOURS : 20.25  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
                   50.0 MOLE% ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

PURPOSE

SECOND REGENERATION OF SULFIDED SORBENT, GASIFIER RUN 103.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (ZWT)		
SURFACE AREA: (SQ M/S)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (ZWT)		

HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 1005 F (AVERAGE)  
 PRESSURE : 3.9 PSIG (AVERAGE AT REACTOR INLET)  
 SPACE VELOCITY: 494 HOURLY

EXIT SULFUR DATA:

H<sub>2</sub>S :  
 SO<sub>2</sub> : HIGH SO<sub>2</sub> (> 10 %) INITIALLY.  
           0.05 % SO<sub>2</sub> AT END OF REGENERATION.

	INLET MOLE% WET BASIS	EXIT MOLE% DRY BASIS	BENDIX GC DATA AVAILABLE AT EXIT
AIR	66.91 SCFH	24.3 %	
H <sub>2</sub> O	9.93 %/HR	75.7 %	
N <sub>2</sub>	0 SCFH		

CONDENSATE	:	
AQUEOUS	:	271.5 LBS (MEASURED)
HYDROCARBON	:	
TOTAL	:	271.5 LBS (MEASURED)

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S SR-10789 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. SECOND REGENERATION ON SULFIDED SORBENT

4. MAXIMUM TEMPERATURE REACHED WAS 1501 F.

CONCLUSIONS

1. REGENERATION COMPLETED.

TOTAL LB MOLES:  
 FLOW RATE : 276 SCFH

FIGURE 39

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION SIDESTREAM TEST UNIT**

TEST NO. : 017  
 DATE STARTED : 17:25 11/13/83  
 DATE ENDED : 16:10 11/16/83 (WITH INTERRUPTIONS)  
 TOTAL HOURS : 55.6 (42.6 HRS ON KITTANNING, 13 HRS ON ARKWRIGHT)  
 TYPE : SULFIDATION  
 SULFUR REMOVED: (2.35 LB SB ON KITT) (3.83 LB SB ON ARK)  
 6.18 LB SB TOTAL

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED  
 COAL TYPE : KITTANNING ARKWRIGHT  
 START TO 20 00 11/15 20 00 11/15 TO END  
 STEAM/COAL MASS RATIO: 0.47 0.48  
 STEAM/AIR MASS RATIO : 0.20 0.20

GAS OPERATING CONDITIONS  
 TEMPERATURE: 1017 °F (WEIGHTED AVERAGE)

PRESSURE : 168 PSIG (WEIGHTED AVERAGE)

SPACE VELOCITY: 999 HOURLY

	INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%
DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	KITT ARK
KITT	ARK	KITT	ARK	

H<sub>2</sub>S 0.118 0.627

H<sub>2</sub>O 5.7 %

CO<sub>2</sub> 8.83 8.33

CO 21.92 22.06

H<sub>2</sub> 16.59 16.02

CH<sub>4</sub> 2.99 3.31

N<sub>2</sub> 46.08 46.52

O<sub>2</sub> 0.59 0.63

CO<sub>4</sub>: 0.27 0.30

NO<sub>x</sub>: 0.00 0.00

TOTAL LS MOLES:

FLOW RATE: 559 SCFH

PURPOSE  
 THIRD SULFIDATION AT LOWER SPACE VELOCITY OF 1000 HOURLY  
 AND TEMPERATURE OF 1000 F.

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (ZWT)		
SURFACE AREA: (SQ M/G)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (ZWT)		

EXIT SULFUR DATA:  
 H<sub>2</sub>S : 10 PPM INITIALLY GRADUALLY DOWN TO 3.2 PPM

C<sub>4</sub>H<sub>8</sub>:  
 SO<sub>2</sub> : 12 PPM INITIALLY, GRADUALLY DOWN TO 2 PPM

	KITTANNING COAL	ARKWRIGHT COAL
CONDENSATE AQUEOUS	69 LBS (MEASURED)	
HYDROCARBON	4 LBS (MEASURED)	
TOTAL	72.3 LBS (MEASURED)	21.2

- REMARKS
- Packed length in reactor is 47 5/8 inches zinc ferrite bottom and top 6 inches are 1/2 inch ceramic spheres CS-346 1/2 S SR-10789 UNITED CATALYSTS
  - Overall packed length 58 7/8 inches
  - No flow to combustor.
  - Water in exit gas was determined by condensate collected.
  - Inlet dry basis gas analysis is average of Bendix 357000 #4 data, sampled at S4, gasifier cyclone exit.
  - Reactor delta p remained essentially constant at 6 inches of water.
  - Exit dry basis gas analysis is average of Bendix GC 6000 #2 data.

CONCLUSIONS:

- Third sulfidation at lower space velocity resulted in 41 % less sulfur removed compared to second sulfidation.
- Reactor pressure drop did not increase. This is attributed to smaller particle size of incoming particulates.

FIGURE 40

**TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT**

TEST NO. : 018  
 DATE AND TIME STARTED : 17:40 11/16/83  
 DATE AND TIME ENDED : 06:00 11/17/83  
 TOTAL HOURS : 12.33  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLEX IRON OXIDE  
 50.0 MOLEX ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

PURPOSE

REGENERATION OF SULFIDED SORBENT FROM T017 GASIFIER RUN 103.

SORBENT ANALYSIS:

BEFORE      AFTER

TOTAL SULFUR: (%WT)  
 SURFACE AREA: (SB M/S)  
 DENSITY : (G/CC)  
 PORE VOLUME: (CC/G)  
 MINERAL ANALYSIS:  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (%WT)

HED OPERATING CONDITIONS

INITIAL TEMPERATURE: 999.6 F  
 PRESSURE : INCHES OF WATER (AVERAGE)  
 AIR VELOCITY: 540 HOURLY

	INLET MOLES WET BASIS	EXIT MOLES DRY BASIS
AIR	63.02 SCFH	20.8 %
H <sub>2</sub> O	11.40 #/HR	79.2 %
N <sub>2</sub>	0 SCFH	

EXIT SULFUR DATA:H<sub>2</sub>S :SO<sub>2</sub> : >10 % INITIALLY, HIGH OF >16 % AFTER 3.8 HOURS  
 2320 PPM AT END OF RUN.

CONDENSATE  
 AQUEOUS : 148.4 LBS  
 HYDROCARBON :  
 TOTAL : 148.4 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S ER-10769 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. SECOND REGENERATION ON SULFIDED SORBENT (SECOND PATCH)
4. MAXIMUM TEMPERATURE REACHED WAS 1551 F.
5. EXIT BENDIX GC WAS OPERATING AND PROVIDED O<sub>2</sub> BREAKTHROUGH CURVE, AND H<sub>2</sub>, CO, CO<sub>2</sub>, H<sub>2</sub>S COMPOSITIONS AT EXIT.

TOTAL LB MOLES:  
 FLOW RATE : 303 SCFH

CONCLUSIONS:  
 1. REGENERATION COMPLETED.

FIGURE 41

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION SIDESTREAM TEST UNIT**

TEST NO. : 019  
 DATE STARTED : 07:15 11/17/63  
 DATE ENDED : 23:30 11/18/63 (WITH INTERRUPTIONS)  
 TOTAL HOURS : 23.49  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 4.33 LB SS

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO.: UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLES IRON OXIDE  
 50.0 MOLES ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : COAL/NETCO FIXED BED  
 COAL TYPE : ARKWRIGHT

STEAM/COAL MASS RATIO: 0.474 (WEIGHTED AVERAGE)  
 STEAM/AIR MASS RATIO : 0.192 (WEIGHTED AVERAGE)

GAS OPERATING CONDITIONS  
 PRESSURE : 200 PSIG (WEIGHTED AVERAGE)  
 SPACE VELOCITY: 1012 HOURLY

	INLET MOLES DRY BASIS (OIL FREE)	INLET MOLES WET BASIS (OIL FREE)	EXIT MOLES DRY BASIS (OIL FREE)	EXIT MOLES NET BASIS (OIL FREE)	CONDENSATE	ARKWRIGHT COAL	
H <sub>2</sub> S	0.36				HELIUM	: 56.7 LBS	(ESTIMATED)
H <sub>2</sub> O			8.5		HYDROCARBON	: 7.5 LBS	(ESTIMATED)
CO <sub>2</sub>	8.71		12.44		TOTAL	: 66.2 LBS	(MEASURED)
CH <sub>4</sub>	23.81		15.21				
H <sub>2</sub>	16.11		19.46				
CH <sub>3</sub> H	3.78		3.33				
N <sub>2</sub>	50.49		47.48				
O <sub>2</sub>	.68		.67				
CO <sub>2</sub> H	.76		.51				
TOTAL MOLES:							
DATE:	566 SCFH				418 SCFH		

PURPOSE  
 FOURTH SULFIDATION AT LOWER SPACE VELOCITY OF 1000 HOURLY  
 AT TEMPERATURE OF 1000 F.

SORBENT ANALYSIS: BEFORE AFTER  
 TOTAL SULFUR: (WT%)  
 SURFACE AREA: (SQ M/S)  
 DENSITY : (G/CC)  
 POROUS VOLUME: (CC/G)  
 ELEMENTAL ANALYSIS:  
 TOTAL CARBON: (WT%)

EXIT SULFUR DATA:  
 SO<sub>2</sub> : 0 PPM INITIALLY  
 CH<sub>4</sub>S : 0 PPM INITIALLY  
 SO<sub>2</sub> : 3 PPM INITIALLY

- REMARKS
1. PACKED LENGTH IN REACTOR IS 47 5/8 INCHES. ZINC FERRITE BOTTOM 3 AND TOP 8 INCHES ARE 1/2 INCH CERAMIC SPHERES
  2. OVERALL PACKED LENGTH 59 7/8 INCHES
  3. NO FLOW TO COMBUSTOR.
  4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
  5. GAS COMPOSITIONS AT INLET OBTAINED BY WEIGHTED AVERAGE OF BENIX BC 7000 & 44 DATA SAMPLING AT S-4 GASIFIER CYCLONE EXIT
  6. GAS COMPOSITIONS AT EXIT OBTAINED BY WEIGHTED AVERAGE OF BENIX BC 5000 & 42 DATA SAMPLING AT 460 EXIT.
  7. REACTOR PRESSURE DROP REACHED A MAXIMUM OF 13 INCHES OF WATER.

CONCLUSIONS:

1. SULFUR REMOVED IS 30% LESS THAN PREVIOUS SULFIDATION.

FIGURE 42  
REMOVAL OF HYDROGEN SULFIDE  
FROM COAL GAS BY ZINC FERRITE




FIGURE 43

# REMOVAL OF CARBONYL SULFIDE FROM COAL GAS BY ZINC FERRITE





FIGURE 44  
REMOVAL OF CARBON DISULFIDE  
FROM COAL GAS BY ZINC FERRITE



**FIGURE 45**  
**REMOVAL OF THIOPHENE**  
**FROM COAL GAS BY ZINC FERRITE**




Figure 46

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 013

P1

21-SEP-84 13:25:35




Figure 47

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 015

28-SEP-64 15:38:56




Figure 48

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 017




Figure 49

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 019

P1

28-SEP-84 10:56:02




FIGURE 50

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 013






FIGURE 51

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 015



P1  
ZINC FERRITE SULFIDATION  
SIDESTREAM TEST 017



27-SE-8-48-5:12:25

P1

# ZINC FERRITE SULFIDATION

SIDESTREAM TEST 019





FIGURE 54

SHIFT REACTION ON ZINC FERRITE SORBENT  
SIDESTREAM TEST UNIT TEST 017



9-AUG-84 10:31:21

FIGURE 55

SHIFT REACTION ON ZINC FERRITE SORBENT  
SIDESTREAM TEST UNIT TEST 017




FIGURE 56

# SHIFT REACTION ON ZINC FERRITE SORBENT

SIDESTREAM TEST UNIT TEST 017





FIGURE 57

TEST 014

REGENERATION

CARBON BURNOFF AS CO<sub>2</sub>




PERCENT CO<sub>2</sub>  
BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 17:30:00 11/09/1983  
STOP TIME 18:40:00 11/10/1983

FIGURE 58

TEST 014

REGENERATION

H<sub>2</sub>S EFFLUENT




PERCENT H<sub>2</sub>S

BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 17:30:00 11/09/1983  
STOP TIME 18:40:00 11/10/1983

FIGURE 59

TEST 014  
REGENERATION  
OXYGEN BREAKTHROUGH CURVE




PERCENT O<sub>2</sub>  
BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 17:30:00 11/09/1983  
STOP TIME 18:40:00 11/10/1983

FIGURE 60

TEST 014

REGENERATION

CARBON BURNOFF AS CO



PERCENT CO

BENDIX 6000 82 CHROMATOGRAPH

START TIME 17130100 11/09/1983


STOP TIME 18140100 11/10/1983

FIGURE 61

TEST 014

REGENERATION

HYDROGEN GENERATION




PERCENT H<sub>2</sub>  
BENDIX 6000 82 CHROMATOGRAPH  
START TIME 17:30:00 11/09/1983  
STOP TIME 18:40:00 11/10/1983

FIGURE 62

TEST 018  
REGENERATION


CARBON BURNOFF AS CO<sub>2</sub>



PERCENT CO<sub>2</sub>  
BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 17:40:00 11/16/1983  
STOP TIME 06:00:00 11/17/1983

FIGURE 63


TEST 018  
REGENERATION  
H<sub>2</sub>S EFFLUENT



PERCENT H<sub>2</sub>S  
BENDIX 6000 \$2 CHROMATOGRAPH  
START TIME 17:40:00 11/16/1983  
STOP TIME 06:00:00 11/17/1983

FIGURE 64

TEST 018  
REGENERATION  
OXYGEN BREAKTHROUGH CURVE



PERCENT O<sub>2</sub>

BENDIX 6000 #2 CHROMATOGRAPH

START TIME 17:40:00 11/16/1983


STOP TIME 06:00:00 11/17/1983

FIGURE 65

TEST 018

REGENERATION

CARBON BURNOFF AS CO



PERCENT CO

BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 17:40:00 11/16/1983  
STOP TIME 06:00:00 11/17/1983

FIGURE 66

TEST 018  
REGENERATION  
HYDROGEN GENERATION




FIGURE 67

-019-  
PRESSURE DROP ACROSS REACTOR




TABLE 1

HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS  
TEST Q13 to Q19

SAMPLE NO.		DATE	HOT GAS DESULFURIZATION GRAB SAMPLE GAS ANALYSIS TEST Q13 to Q19																		
	LOCATION	TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	1 C <sub>4</sub>	n C <sub>4</sub>	DOPP H <sub>2</sub> S	DOPP COS	DOPP CH <sub>3</sub> SH	DOPP CS <sub>2</sub>	DOPP Thio	DOPP NH <sub>3</sub>	DOPP H <sub>2</sub> O	DOPP SO <sub>2</sub>
SULFIDATION TO13	MG-1	Exit 2110 11/8/83	21.63	1.33	46.86	2.67	10.74	0.19	16.00	ND	0.08	ND	ND	4.45	0.32	ND	0.15	3.10	ND	1755.8	ND
	MG-2	Exit 0110 11/8/83	20.66	1.82	47.04	2.73	11.34	0.20	15.51	0.09	0.10	ND	ND	0.41	ND	ND	ND	ND	ND	5408.8	ND
	MG-3	Exit 0910 11/8/83	22.63	0.78	44.89	2.39	11.33	0.24	16.44	0.10	0.10	ND	ND	10.24	2.38	ND	2.66	1.83	ND	1716.9	ND
	MG-4	Exit 0910 11/8/83	22.48	0.66	45.18	1.09	11.36	0.33	15.68	0.10	0.12	ND	ND	3.53	ND	ND	0.28	2.25	ND	1428.7	ND
	MG-5	Exit 1310 11/8/83	18.40	1.22	49.61	2.99	9.88	0.35	16.78	0.17	0.11	ND	ND	7.11	3.20	ND	3.11	1.07	ND	2068.2	ND
	MG-6	Exit 1710 11/8/83	20.13	0.66	48.85	2.94	8.98	0.41	17.17	0.49	0.06	ND	ND	5.49	1.20	ND	0.22	1.13	ND	1831.0	ND
	MG-7	Exit 2110 11/8/83	18.70	1.23	50.00	2.85	10.10	0.29	16.17	0.09	0.06	ND	ND	4.65	2.13	ND	0.55	1.85	ND	2682.5	ND
	MG-8	Exit 11/9/83 0510	NO DATA												NO DATA						
	MG-9	Exit 0910 11/9/83	19.87	0.99	47.52	2.73	13.04	0.35	14.80	0.11	0.08	ND	ND	22.34	5.23	ND	4.85	1.87	ND	2593.0	ND
	MG-10	Exit 0910 11/9/83	20.35	0.65	46.47	2.92	13.54	0.37	14.79	0.14	0.26	ND	ND	12.11	4.35	ND	1.94	1.51	ND	2116.0	ND
	MG-11	Exit 1310 11/9/83	19.40	0.92	47.28	2.91	14.29	0.28	14.02	0.11	0.32	ND	ND	17.48	5.78	ND	13.77	2.53	ND	2364.4	883
REGENERATION TO14	MG-12	Exit 1810 11/9/83	21.86	1.84	53.88	ND	0.60	ND	17.48	ND	ND	ND	ND	--	--	4.8	23.4	1.5	ND	2054.0	7.6
	MG-13	Exit 2010 11/9/83	2.75	2.21	73.17	ND	0.03	ND	12.38	ND	0.02	ND	ND							4218.0	32.8
	MG-14	Exit 2210 11/10/83	0.88	1.91	73.97	ND	0.02	ND	12.19	ND	0.02	ND	ND	4.27%	444.7	ND	152.1	0.92	ND	3938.0	34.7
	MG-15	Exit 0010 11/10/83	1.04	1.30	79.97	ND	ND	ND	9.27	ND	ND	ND	ND	4.27%	444.7	ND	152.3	0.92	ND	4510	1.01%
	MG-16	Exit 0210 11/10/83	ND	1.87	82.12	ND	ND	ND	4.07	ND	2.73	ND	ND	2.75%	236.4	ND	57.2	ND	ND	4594	4.61%
	MG-17	Exit 0410 11/10/83	ND	4.05	83.15	ND	ND	ND	2.64	ND	3.24	ND	ND	2.51%	273.2	ND	50.7	ND	ND	5838	5.28%
	MG-18	Exit 0610 11/10/83	ND	1.31	84.12	ND	ND	ND	2.30	ND	4.33	ND	ND	2.42%	251.1	ND	63.9	ND	ND	5230	9.38%
	MG-19	Exit 0810 11/10/83	ND	1.99	85.00	ND	ND	ND	1.45	ND	3.87	ND	ND	1.63%	183	ND	60.3	ND	ND	4464	8.80%
	MG-20	Exit 1010 11/10/83	ND	1.30	85.11	ND	ND	ND	1.18	ND	5.75	ND	ND	9768	108	ND	67.9	ND	ND	3784	10.14%
	MG-21	Exit 1210 11/10/83																			
	MG-22	Exit 1410 11/10/83																			
	MG-23	Exit 1610 11/10/83	ND	15.09	79.98	ND	ND	ND	1.06	ND	2.28	ND	ND	ND	17.6	ND	6.8	ND	ND	3024	3.09%
SULFIDATION TO15	MG-24	Exit 2000 11/10/83	14.75	3.50	50.59	2.51	12.29	0.29	15.30	0.14	0.14	ND	ND	13.4	2.7	ND	7.2	ND	ND	2266	ND
	MG-25	Exit 2115 11/11/83	16.29	1.12	51.86	2.78	9.32	0.26	15.10	0.14	0.11	ND	ND	7.9	1.1	ND	4.3	14.9	ND	1618	ND
	MG-26	Exit 0130 11/11/83	22.68	0.96	45.99	2.58	11.60	0.26	15.19	0.12	0.12	ND	ND	2.7	1.5	ND	2.8	3.0	ND	1558.0	12.0
	MG-27	Exit 0530 11/11/83	23.77	0.70	42.82	2.74	14.53	0.30	14.39	0.10	0.15	ND	ND	2.6	0.3	ND	2.7	10.2	ND	1289.2	ND
	MG-28	Exit 0930 11/11/83	16.18	3.39	50.72	2.23	11.92	0.25	14.58	0.11	0.11	ND	ND	2.5	0.8	ND	1.6	4.2	ND	1314.7	ND
	MG-29	Exit 1330 11/11/83	18.86	0.81	48.09	2.69	14.44	0.32	14.04	0.13	0.14	ND	ND	1.5	1.8	ND	1.0	5.2	ND	1302.6	451
	MG-30	Exit 11/11/83 2130																			
	MG-31	Exit 11/12/83 0130	13.88	6.10	55.61	1.80	11.55	0.25	10.12	0.09	0.10	ND	ND	13.6	3.3	ND	2.3	10.7	ND	1429.0	ND
	MG-32	Exit 0530 11/12/83	10.45	5.42	56.09	2.47	12.32	0.29	12.22	0.12	0.12	ND	ND	8.7	0.2	ND	ND	10.2	ND	1570.9	ND
	MG-33	Exit 0930 11/12/83	16.47	3.11	50.11	2.88	15.24	0.35	11.08	0.14	0.13	ND	ND	13.9	1.7	ND	ND	11.6	ND	1561.2	ND
REGENERATION TO16	MG-34	Exit 0930 11/12/83	17.48	1.87	48.66	2.58	15.11	0.31	13.11	0.13	0.15	ND	ND	14.1	0.9	ND	11.9	16.7	ND	3245.6	101.8
	MG-35	Exit 1400 11/12/83	17.95	3.47	59.33	0.09	0.71	ND	17.94	ND	ND	ND	ND	1.29%	435.7	11.2	46.0	2.9	ND	3644	21.9
	MG-36	Exit 1800 11/12/83	4.82	3.43	67.91	ND	ND	ND	14.79	ND	ND	ND	ND	4.98%	481.1	9.5	116.5	2.0	ND	4072.0	30.0
	MG-37	Exit 1800 11/12/83	ND	2.28	68.10	ND	0.39	ND	13.86	ND	ND	ND	ND	4.58%	504.7	2.4	122.8	1.3	ND	4018.0	20.7
	MG-38	Exit 2000 11/12/83	2.15	2.23	77.80	ND	ND	ND	11.03	ND	ND	ND	ND	3.54%	128.9	ND	136.4	ND	ND	3936.0	4294
	MG-39	Exit 2200 11/13/83	ND	1.21	81.87	ND	ND	ND	5.08	ND	ND	ND	ND	1.72%	336.3	ND	191.4	ND	ND	4572	9.07%
	MG-40	Exit 0000 11/13/83	ND	2.33	81.43	ND	ND	ND	2.50	ND	ND	ND	ND	9835.0	164.2	ND	199.9	ND	ND	4520	12.3%
	MG-41	Exit 0200 11/13/83	ND	8.07	80.17	ND	ND	ND	1.29	ND	ND	ND	ND	1.32	39.3	ND	200.9	ND	ND	3066	8.1%
	MG-42	Exit 0400 11/13/83	ND	17.2	76.52	ND	ND	ND	0.76	ND	ND	ND	ND	ND	2.9	ND	18.8	ND	ND	3406	1.32%
SULFIDATION TO17	MG-43	Exit 1755 11/13/83	17.23	1.74	48.18	2.99	13.10	0.41	15.74	0.09	0.13	ND	ND	ND	3.52	ND	16.2	ND	ND	1652.8	25.0
	MG-44	Exit 1825 11/13/83	15.95	2.66	48.84	2.89	13.29	0.38	15.26	0.08	0.15	ND	ND	5.2	4.5	ND	2.9	0.6	ND	1764.7	ND
	MG-45	Exit 2225 11/13/83	17.84	1.57	49.07	2.67	11.99	0.38	15.77	0.09	0.13	ND	ND	21.7	4.3	ND	4.9	0.7	ND	1832.4	429.2
	MG-46	Exit 0225 11/14/83	20.93	0.97	44.66	3.07	14.21	0.41	15.03	0.09	0.15	ND	ND	7.2	3.8	ND	ND	1.4	ND	1425.9	72.9
	MG-47	Exit 0625 11/14/83	20.01	1.26	45.27	2.85	14.65	0.39	14.81	0.10	0.15	ND	ND	7.3	2.7	ND	ND	1.8	ND	1491.2	ND
	MG-48	Exit 1025 11/14/83	12.48	4.01	52.91	2.68	15.38	0.37	11.42	0.10	0.13	ND	ND	0.9	0.9	ND	0.9	1.0	ND	1490	ND
	MG-49	Exit 2225 11/15/83	17.45	1.48	47.17	3.01	17.21	0.40	12.54	0.09	0.15	ND	ND	0.5	0.9	ND	0.5	1.2	ND	1228	ND
	MG-50	Exit 0225 11/15/83	20.22	1.29	44.46	3.2	15.18	0.42	14.48	0.06	0.19	ND	ND	ND	ND	ND	ND	ND	ND	1268.4	ND
	MG-51	Exit 0625 11/15/83	20.67	0.95	45.42	2.89	14.8	0.43	14.15	0.08	0.13	ND	ND	ND	ND	ND	ND	ND	ND	959	ND

Table 1 (Continued)

HOT GAS DESULFURIZATION  
GRAS SAMPLE GAS ANALYSIS

TEST 013 to 019

SAMPLE NO.	DATE	LOCATION	TIME	TEST 013 to 019										TEST 013 to 019									
				H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	1 C <sub>4</sub>	n C <sub>4</sub>	DMM <sup>a</sup> H <sub>2</sub> S	DMM COS	DMM CH <sub>3</sub> SH	DMM CS <sub>2</sub>	DMM THIO	DMM NH <sub>3</sub>	DMM H <sub>2</sub> O	DMM SO <sub>2</sub>	
SULFIDATION TO17	11/15/83	Exit	1025	15.9	5.67	48.56	2.49	12.92	0.32	13.46	0.05	0.13	ND	ND	0.3	ND	ND	ND	0.1	ND	616.5	ND	
	11/15/83		1425	16.73	1.35	47.47	3.05	15.78	0.42	14.46	0.08	0.16	ND	ND	1.5	ND	ND	0.1	0.8	ND	1600.4	ND	
	11/15/83	Exit	1825	17.79	4.51	46.07	2.79	14.42	0.40	13.32	0.05	0.15	ND	ND	3.5						ND	1644.1	ND
	11/15/83		2225	18.01	3.01	45.81	3.22	15.20	0.41	13.71	ND	0.13	ND	ND	3.9	1.9	ND	ND	0.9	ND	1531	ND	
	11/16/83	Exit	0225	17.52	1.05	47.09	4.05	14.35	0.49	14.81	0.03	0.12	ND	ND	13.1						1290.0	ND	
	11/16/83		1300	19.97	1.68	45.15	3.60	14.92	0.40	13.62	0.05	0.11	ND	ND	6.7	3.5	ND	3.7	2.1	ND	1457	21.6	
	11/16/83	Exit	2025	20.23	1.45	44.96	3.49	15.53	0.38	13.23	0.07	0.11	ND	ND	13.1	2.4	ND	0.7	1.8	ND	1529	ND	
	11/16/83		2140	20.08	2.72	55.49	ND	ND	ND	21.21	ND	ND	ND	ND	247.9							2.3	
REGENERATION TO18	11/16/83	Exit	0445	10.47	1.39	62.45	ND	ND	ND	19.66	ND	ND	ND	ND	3.73%	ND	ND	7.5	0.4	ND	3568	ND	
	11/16/83		2340	0.95	1.71	85.58	ND	ND	ND	4.37	ND	ND	ND	ND	37.9	64.0	ND	92.2	ND	ND	3784	4.965	
	11/17/83	Exit	0140	ND	6.28	81.44	ND	ND	ND	1.75	ND	ND	ND	ND	3.3	20.8	8.0	240.0	ND	ND	2854	16.32%	
	11/17/83		0340	ND	15.8	78.0	ND	ND	ND	1.77	ND	ND	ND	ND	ND	13.0	5.2	47.1	ND	ND	2852	8.725	
	11/17/83	Exit	2540	ND	21.45	75.78	ND	ND	ND	1.35	ND	ND	ND	ND	0.58	ND	ND	31.2	ND	ND	4008	17.92	
	11/17/83		2200	14.58	2.19	51.94	2.72	12.43	0.36	19.13	0.06	0.09	ND	ND	7.7	6.7	1.1	2.7	4.1	ND	3632	132.5	
SULFIDATION TO19	11/17/83	Exit	0845	14.79	2.40	50.83	3.63	12.03	0.41	19.22	0.08	0.10	ND	ND	ND	4.9	ND	5.8	3.0	ND	2820	60.9	
	11/17/83		0940	17.73	1.36	49.61	3.08	11.60	0.38	15.60	0.06	0.08	ND	ND	3.5	ND	ND	8.6	5.7	ND	2232	4.9	
	11/17/83	Exit	1045	17.27	1.76	43.68	3.47	12.47	0.43	15.25	0.06	0.10	ND	ND	0.2	ND	ND	ND	6.7	ND	2174	ND	
	11/17/83		2200	17.68	1.43	48.49	3.00	12.82	0.35	15.57	0.07	0.10	ND	ND	5.4	ND	ND	2.5	6.1	ND	2238	ND	
	11/18/83	Exit	0200	18.43	0.99	47.89	3.21	13.35	0.35	15.15	0.05	0.07	ND	ND	ND	1.1	ND	1.1	ND	ND	2158	ND	
	11/18/83		0600	17.73	0.77	47.99	3.51	15.85	0.41	13.17	0.07	0.10	ND	ND	1.8	1.0	ND	0.4	0.6	ND	1540	ND	
	11/18/83	Exit	1810	ND	15.04	71.01	1.16	6.39	0.15	5.70	ND	0.05	ND	ND	8.3						2114	ND	
	11/18/83		2210	ND	15.91	72.01	0.90	5.25	0.13	5.3	ND	ND	ND	ND	2.6	2.9	ND	0.4	0.5	ND	2148	ND	

ND = Not Detectable

\* = M/S Detectable Limit 0.2 ppm

NOTE: All analysis other than Sulfur, Ammonia, and Water is in units of % by volume on a dry gas basis. The remaining items are as indicated in units of ppm by volume, except where noted in percent.

TABLE 2  
 HOT GAS DESULFURIZATION  
 GRAB SAMPLE GAS ANALYSIS AT INLET  
 GASIFIER RUN 103  
 MAJOR COMPONENTS

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub> VOLUME %	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	IC <sub>4</sub>	nC <sub>4</sub>
SULFI- CATION T013	FN 5	11/8/83 06:30-07:00	15.517	0.644	49.904	2.808	19.588	0.357	10.522	0.129	ND	ND	ND
	FN 9	11/8/83 09:30-10:15	17.238	0.645	48.334	2.902	19.305	0.190	10.314	0.050	0.101	ND	ND
	FN 13	11/8/83 13:35-14:09	16.951	0.742	49.381	3.139	18.723	0.315	9.940	0.178	0.133	ND	ND
	FN 17	11/8/83 06:10-06:43	16.951	0.592	49.058	2.771	19.140	0.272	10.494	0.105	0.117	ND	ND
	FN 21	11/8/83 09:23-09:52	16.791	0.573	50.031	2.976	18.386	0.324	10.164	0.139	0.115	ND	ND
	FN 25	11/8/83 12:20-12:49	16.622	0.943	49.677	2.853	17.747	0.297	11.124	0.120	0.118	ND	ND
SULFI- CATION T015	FN 59	11/11/83 06:15-07:16	17.54	2.64	47.36	2.90	19.91	0.29	8.06	0.13	0.16	ND	ND
	FN 72	11/11/83 15:20-15:40	17.05	0.77	50.18	3.07	19.82	0.31	7.92	0.18	0.15	ND	ND
SULFI- CATION T017	FN 100	11/14/83 06:10-06:53	18.30	0.56	46.29	2.82	22.06	0.33	8.74	0.17	0.14	ND	ND
	FN 105	11/14/83 09:20-09:55	18.41	0.63	45.64	2.82	22.84	0.35	8.50	0.17	0.15	ND	ND
	FN 110	11/15/83 06:25-07:10	16.63	0.67	47.68	2.74	20.71	0.33	9.85	0.27	0.42	ND	ND
	FN 114	11/15/83 09:40-10:15	17.92	0.64	45.89	2.76	20.39	1.98	9.30	0.17	0.44	ND	ND
	FN 120	11/15/83 12:30-13:05	18.66	0.61	46.28	2.74	20.75	0.07	9.75	0.15	0.48	ND	ND
	FN 125	11/15/83 15:20-15:55	17.18	1.43	44.95	3.18	22.90	0.36	8.57	0.15	0.15	ND	ND
	FN 130	11/16/83 12:30-13:00	15.11	0.64	48.00	3.46	23.36	0.34	8.01	0.20	0.37	ND	ND
	FN 135	11/16/83 15:15-15:45	14.69	0.64	49.39	3.68	21.70	0.37	8.51	0.16	0.36	ND	ND
	FN 140	11/17/83 06:20	15.30	0.73	49.27	3.66	21.10	0.33	8.82	0.13	0.13	ND	ND
	FN 145	11/17/83 09:25-10:00	15.83	0.71	49.77	3.49	20.55	0.35	8.54	0.13	0.13	ND	ND
SULFI- CATION T019	FN 150	11/18/83 15:20-16:35	15.94	0.93	47.81	3.42	22.55	0.36	8.32	0.13	0.15	ND	ND

NOTES:

1. ND = Not Detectable.

TABLE 3  
 HOT GAS DESULFURIZATION  
 GRAB SAMPLE GAS ANALYSIS AT INLET  
 GASIFIER RUN 103  
 TRACE COMPONENTS

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	COS	CH <sub>3</sub> SH	CS <sub>2</sub> PPM	THIO	NH <sub>3</sub>
SULFI- DATION TO13	FN 5	11/8/83 06:30-07:00	4528	358.9	7.9	13.1	2.9	ND
	FN 9	11/8/83 09:30-10:15	4339	350.0	ND	9.2	ND	ND
	FN 13	11/8/83 13:35-14:07	4217	410.6	2.0	15.2	3.2	ND
	FN 17	11/9/83 06:10-06:43	4628	390.2	ND	12.7	50.6	ND
	FN 21	11/9/83 09:23-09:52	4311	413.3	ND	11.0	2.0	ND
	FN 25	11/9/83 12:20-12:49	4831	398	ND	13.6	ND	ND
SULFI- DATION TO15	FN 59	11/11/83 06:15-07:10	3951	259	6.1	11.0	19.0	ND
	FN 72	11/11/83 15:20-15:40	1960	254.0	ND	10.8	14.7	ND
	FN 100	11/14/83 06:10-06:55	2084	138.9	ND	3.0	4.7	ND
SULFI- DATION TO17	FN 105	11/14/83 09:20-09:55	2133	137.7	ND	3.6	22.7	ND
	FN 110	11/15/83 06:25-07:10	2161	135.7	ND	2.2	11.0	ND
	FN 114	11/15/83 09:40-10:15	2036	122.2	ND	ND	15.6	ND
	FN 120	11/15/83 12:30-13:05	1754	135.8	ND	2.4	1.9	ND
	FN 125	11/15/83 13:20-13:55	1787	124.3	ND	1.1	18.2	ND
	FN 130	11/16/83 12:30-13:00	3864	323.6	7.0	10.0	10.4	ND
	FN 135	11/16/83 13:15-13:45	3877	391.9	2.3	11.3	16.3	ND
	FN 145	11/17/83 09:25-10:00	4898	621.5	1.7	18.0	6.9	ND
DATION 019	FN 150	11/18/83 15:20-16:35	4311	459.8	2.3	18.0	8.3	ND

NOTES:

1. ND = Not Detectable.

TABLE 4

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 013  
AVERAGE GC READINGS

**DURATION**

FROM TO  
17:10: 0 11/ 7/1983 15: 0: 0 11/ 7/1983

HGD EXIT BENDIX 6000 32 CHROMATOGRAPH

# READ	H2	CO2	CH46	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
174	21.014	15.608	1.163	-0.001	0.677	46.303	2.943	12.331	100.043	24.76	1.107	0.856	158.74	143.52

GASIFIER CYCLONE EXIT BENDIX 7900 44 CHROMATOGRAPH

PERIOD	H2	CO2	CH46	H2S	O2	N2	CH4	CO	TOTAL	Avg Mw	Avg DTY	Avg SG	G_STU	N_STU
251	16.251	10.522	0.252	0.598	0.659	48.583	2.734	13.330	99.179	24.96	1.115	0.863	153.03	141.58

# READ	H2	CO2	CH4	H2S	O2	N2	CH4	CO	TOTAL	Avg Mn	Avg Dty	Avg SG	G BTU	N BTU
153	--	--	--	0.612	0.768	47.875	3.136	18.914	98.104	24.67	1.102	0.953	154.23	142.29

TABLE 5

HOT GAS DESULFURIZATION  
 SIDESTREAM TEST UNIT  
 TEST 014  
 AVERAGE GC READINGS

DURATION

FROM	TO
17:30: 0    11/ 9/1983	18:40: 0    11/10/1983

H2O EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg S6	G BTU	N BTU	
99	--	3.241	7.430	0.142	1.014	1.677	73.554	-0.014	-0.078	88.968	25.40	1.135	0.378	19.25	16.32

TABLE 6

**HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 015  
AVERAGE GC READINGS**

**DURATION**

FROM TO  
19: 5: 0 11/10/1983 11:19: 0 11/12/1983

HGD EXIT BENDIX 6000 #2 CHROMATOGRAPH

# READ	H2	CO2	CH4	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	6 BTU	N BTU
237	--	--	--	--	--	--	--	--	95.190	23.29	1.041	0.805	143.62	130.19

GASIFIER CYCLONE EXIT                          BENDIX 7000 44 CHROMATOGRAPH

READ	H2	C92	C9H6	H2S	O2	N2	CH4	CO	TOTAL	Avg Mn	Avg DTY	Avg SS	G STU	N BTU
228	16.309	9.736	0.296	0.559	0.625	45.650	3.016	30.574	95.304	23.71	1.059	0.819	158.54	146.66

HSD INLET BENDIX 6000 AL CHROMATOGRAPH

# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY.	Avg SG	G BTU	N BTU
238	16.542	9.020	0.327	0.571	0.752	46.521	3.268	20.995	98.096	24.30	1.086	0.840	164.02	151.70

TABLE 7

HOT GAS DESULFURIZATION  
 SIDESTREAM TEST UNIT  
 TEST 016  
 AVERAGE GC READINGS

## DURATION

FROM	TO
12:15: 0    11/12/1983	8:30: 0    11/13/1983

HED EXIT

BENDIX 6000 #2 CHROMATOGRAPH

* READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
83	14.375	14.910	0.095	0.049	0.867	81.915	0.345	2.028	94.585	25.14	1.124	0.370	58.78	51.08

TABLE 8

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 017A  
AVERAGE GC READINGS

												DURATION		
												FROM	TO	
17:25: 0      11/13/1983												12: 0: 0      11/14/1983		
<u>HGD EXIT</u>														
<u>BENDIX 6000 #2 CHROMATOGRAPH</u>														
# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
24	19.782	12.863	0.294	0.086	0.769	45.686	2.829	15.723	98.036	24.08	1.077	0.833	149.41	136.21
<u>GASIFIER CYCLONE EXIT</u>														
<u>BENDIX 7000 #4 CHROMATOGRAPH</u>														
# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
106	16.488	8.938	0.270	0.104	0.593	46.432	2.949	21.659	97.404	24.12	1.079	0.834	158.71	147.06
<u>HGD INLET</u>														
<u>BENDIX 6000 #1 CHROMATOGRAPH</u>														
# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
112	17.752	9.174	0.382	0.205	0.753	47.551	3.406	22.826	102.049	23.08	1.121	0.867	173.37	160.90

TABLE 9

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 017B1  
AVERAGE GC READINGS

## DURATION

FROM

TO

20: 0: 0 11/14/1983

20: 0: 0 11/13/1983

HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
143	20.787	13.412	0.353	-0.003	0.551	43.749	3.069	15.325	97.517	23.72	1.061	0.620	154.61	140.51

GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
141	16.696	8.721	0.279	0.153	0.592	45.736	3.035	22.164	97.376	24.01	1.073	0.830	162.30	150.40

HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
140	16.786	8.723	0.333	0.153	0.730	44.910	3.313	21.753	96.766	23.79	1.063	0.822	166.74	154.27

TABLE 10

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 017B2  
AVERAGE GC READINGS

## DURATION

FROM	TO
20: 0: 0    11/15/1983	4: 0: 0    11/16/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
47	20.358	14.015	0.420	-0.002	0.565	43.246	3.448	14.653	96.703	23.66	1.053	0.818	155.78	141.52

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
47	16.364	8.531	0.301	0.608	0.602	45.975	3.279	22.284	97.805	24.19	1.081	0.836	167.09	154.90

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
48	16.456	8.830	0.417	0.391	0.734	44.644	3.513	21.862	96.848	23.91	1.068	0.826	169.47	156.60

TABLE 11

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 017C  
AVERAGE GC READINGS

**DURATION**

FROM TO  
7: 0: 0 11/16/1983 8: 5: 0 11/16/1993

H6D EXIT BENDIX 6000 #2 CHROMATOGRAPH

# READ	H2	CO2	C2H6	H2S	O2	N2	CH4	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
7	5.977	3.433	0.102	-0.002	0.118	77.354	0.729	3.368	91.600	24.58	1.097	0.349	41.15	77.27

GASIFIER CYCLONE EXIT BENDIX 7000 #4 CHROMATOGRAPH

<u># READ</u>	<u>H2</u>	<u>CO2</u>	<u>C2H6</u>	<u>H2S</u>	<u>O2</u>	<u>N2</u>	<u>CH4</u>	<u>CO</u>	<u>TOTAL</u>	<u>Avg MW</u>	<u>Avg DTY</u>	<u>Avg SG</u>	<u>G BTU</u>	<u>N BTU</u>
7	16.084	8.282	0.293	0.567	0.614	46.869	3.271	21.862	97.961	24.27	1.084	0.839	165.50	157.39

H6D INLET BENDIX 5000 II CHROMATOGRAPH

<u># READ</u>	<u>H2</u>	<u>CO2</u>	<u>CH4</u>	<u>H2S</u>	<u>O2</u>	<u>N2</u>	<u>CH4</u>	<u>CO</u>	<u>TOTAL</u>	<u>Avg Mn</u>	<u>Avg Dty</u>	<u>Avg SG</u>	<u>G BTU</u>	<u>N BTU</u>
7	7.567	6.162	0.223	0.373	0.492	66.583	1.993	9.919	92.313	24.69	1.103	0.653	79.34	73.64

TABLE 12

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 017D  
AVERAGE GC READINGS

## DURATION

FROM		TO	
12:10: 0	11/16/1983	16:10: 0	11/16/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
17	19.463	13.045	0.443	0.000	0.584	45.196	3.567	15.127	97.425	23.92	1.070	0.627	156.03	142.06

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
23	15.632	8.187	0.296	0.586	0.627	47.126	3.428	22.042	97.923	24.03	1.087	0.641	165.59	153.60

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
22	15.370	7.952	0.364	0.370	0.746	47.323	3.605	21.391	97.125	24.11	1.077	0.633	164.26	152.04

TABLE. 13

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 01B  
AVERAGE GC READINGS

## DURATION

**FROM**

TO

171101 9 11/16/1983

6:0:0 11/17/1983

HGD EXIT

BENDIX 6000 \$2 CHROMATOGRAPH

#	<u>READ</u>	<u>H<sub>2</sub></u>	<u>CO<sub>2</sub></u>	<u>C<sub>2</sub>H<sub>6</sub></u>	<u>H<sub>2</sub>S</u>	<u>O<sub>2</sub></u>	<u>N<sub>2</sub></u>	<u>CH<sub>4</sub></u>	<u>CO</u>	<u>TOTAL</u>	<u>Avg MM</u>	<u>Avg DTY</u>	<u>Avg SG</u>	<u>G BTU</u>	<u>NBTU</u>
58		8.609	10.194	0.129	0.638	1.722	67.172	0.039	0.381	88.385	24.40	1.091	0.843	36.05	31.18

TABLE 14

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 019A

## AVERAGE GC READINGS

## DURATION

FROM	TO
7:15: 0      11/17/1983	11:20: 0      11/17/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
15	17.157	11.789	0.443	0.049	0.937	48.835	2.642	13.659	95.514	23.92	1.069	0.827	134.77	122.86

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
17	15.229	9.544	0.334	0.432	0.633	48.144	3.628	21.528	98.472	24.62	1.100	0.851	164.35	152.37

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
14	14.616	8.552	0.374	0.395	0.746	49.096	3.539	20.529	97.947	24.52	1.100	0.851	159.72	147.10

TABLE 15

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 019B

## AVERAGE GC READINGS

DURATION

FROM

TO

20:10: 0 11/17/1983

6:15: 0 11/18/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
59	19.385	13.720	0.529	0.000	0.610	46.790	3.576	14.622	99.200	24.56	1.098	0.849	155.38	141.06

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
61	17.058	9.323	0.382	0.370	0.734	54.126	4.072	26.101	112.168	28.05	1.233	0.969	189.97	176.61

## HGD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
59	15.830	8.421	0.396	0.433	0.771	51.625	3.858	23.297	104.611	26.14	1.168	0.903	175.23	162.66

TABLE 16

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 019C

## AVERAGE GC READINGS

## DURATION

FROM		TO
14:10: 0	11/18/1983	23:30: 0
		11/19/1983

## HSD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
55	18.068	11.383	0.550	0.002	0.602	47.563	3.426	16.560	98.275	24.27	1.063	0.339	156.26	143.00

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
54	15.493	8.147	0.358	0.397	0.641	47.610	3.549	22.354	98.518	24.51	1.095	0.347	156.34	154.34

## HSD INLET

BENDIX 6000 #1 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	G BTU	N BTU
36	12.770	6.439	0.333	0.313	0.923	46.824	3.203	19.319	90.654	22.78	1.018	0.787	146.06	135.73

TABLE 17

ANALYSIS OF MINERALS BY X-RAY DIFFRACTION  
IN SULFIDED ZINC FERRITE  
GASIFIER RUN 103

BED HEIGHT (INCHES)	FRANKLINITE $ZnFe_2O_4$ OR							
	HEMATIC $Fe_2O_3$	MAGNETITE $Fe_3O_4$ <sup>(4)</sup>	ZINCITE $ZnO$	ALPHA $ZnS$	BETA $ZnS$	PYRROHOTITE $FeS$	CEMENTITE $Fe_3C$	
PERCENT TII (3)								
0(1)		33.9	6.8	12.8	37.3	9.2	-	
6		23.7	6.9	18.6	33.4	11.7	1.7	
16		14.6	15.9	21.0	25.9	9.4	13.3	
23		2.8	52.9	6.5	2.5	-	35.2	
26		-	45.0	<0.5	<0.5-	-	35.0	
36		-	64.8	-	0.4	-	34.8	
46(2)		-	62.7	-	1.1	-	36.2	
FRESH SORBENT	4.	89.	6.0	-	-	-	-	

## NOTES:

- (1) Bottom/Inlet.
- (2) Top/Outlet.
- (3) Percent TII = Percent Total Integrated Intensity; Directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
- (4) Franklinite and Magnetite have the same crystal structure and, therefore, cannot be readily distinguished by the diffraction pattern.

TABLE 18

SORBENT ANALYSIS OF  
SULFIDED ZINC FERRITE  
GASIFIER RUN 103  
TEST 019

Bed Height (Inches)	Total Carbon (% Wt)	Total Sulfur (% Wt)	BET Surface Area (Sq M/G)	Skeletal Density (G/CC) <sup>3</sup>	Porosity % (4)	Crush Strength (Kg DWL) ± S.D. (5)	Skeletal Density (G/CC) <sup>6</sup>	Porosity % (7)
0 <sup>(1)</sup>	1.45	23.87						
0-6			2.06	4.59	2.01	9.0 ± 1.8		
6	2.33	25.64						
6-16			2.07	4.56	1.76	4.1 ± 2.2	4.62	35.0
16	7.62	19.75						
23	6.39	3.40	4.89	5.38	5.50	1.2 ± 0.9	4.88	61.8
26	6.35	0.58						
26-36			5.72	6.69	7.67	1.1 ± 0.7		
36	5.06	0.28						
36-46			6.22	6.66	7.89	1.0 ± 0.5		
46(2)	6.12	0.61					6.21	74.6
Fresh Sorbent	0	0.13	3.13	6.16	2.59	6.3 ± 2.8	-	60.6(8)

## NOTES:

1. Bottom/Inlet during sulfidation - Outlet during regeneration.
2. Top/Outlet during sulfidation - Inlet during regeneration.
3. Skeletal Density by Helium Pycnometry.
4. Porosity by Nitrogen Adsorption for pores up to 600Å diameter.
5. Average and standard deviation of 15 measurements.
6. Skeletal density by mercury porosimetry.
7. Porosity by mercury porosimetry for pores down to 120Å diameter.
8. Porosity by mercury porosimetry for pores down to 30Å diameter.

TABLE 19

**PARTICULATE SAMPLING DATA  
HOT GAS DESULFURIZATION TEST UNIT  
GASIFIER RUN 103**

TEST #	HOURS FROM START OF TEST	PARTICLE LOADING g/m³	MEDIAN PARTICLE SIZE μm (microns)		CHEMICAL ANALYSIS						
			INLET	EXIT	INLET	EXIT	C	H	N		
013	16.6 HRS	2.12		21.3			81.1	3.8	2.4	0.1	4.4
013	21.1 HRS		1.36		14.5		67.9	4.0	3.5	NM	10.2
013	42.5 HRS		0.469		13.1		73.8	4.9	4.3	NM	3.3
015	18.3 HRS	1.52		26.0			79.1	1.4	1.7	0.3	9.5
015	15.6 HRS		0.381		21.6		72.4	4.8	2.8	NM	7.3
017	16.6 HRS	2.09		13.0			75.9	4.6	3.2	0.9	2.9
017	27.7 HRS		0.381		5.3		76.5	2.1	1.4	1.1	12.9

## NOTES:

NM= Not Measured due to insufficient sample size.

DATE: 12/2/83

SAMPLE: HGOS BAGHELL 611181 83-957

ELECTROLYTE: ISOTON LOMAR D

DISPERSANT: LOMAR D

EQUIPMENT: TAI

APERTURES: 140

OPERATOR: BAGS


CH.#	SIZE	DIFF VOL %	CUM VOL %
1	2	0	100
2	2.52	2.6	100
3	3.17	1.6	97.4
4	4	1.6	95.3
5	5.04	2.2	94.2
6	6.35	6.1	82
7	8	8.1	85.9
8	10.08	9.1	77.8
9	12.7	8.2	68.7
10	16	8.5	60.5
11	20.16	8	52
12	25.4	9.6	44
13	32	10.5	34.4
14	40.32	11.8	23.9
15	50.8	6.6	12.1
16	64	3.5	3.5

TABLE 20

PARTICULATE SIZE DISTRIBUTION  
TEST 013 INLET

VOLUME % STATISTICS

MEAN: 19.76 UM  
MEDIAN: 21.3 UM  
MODE: 43.02 UM  
STANDARD DEVIATION: 2.25 UM  
SKENNESS: .8 NEGATIVE  
KURTOSIS: 2.78 PLATYKURTIC



DATE: 12/2/83  
 SAMPLE: HGO BAGHELL 601182 83-359  
 ELECTROLYTE: ISOTON  
 DISPERSANT: LOMARD  
 EQUIPMENT: TAI  
 APERTURES: 140  
 OPERATOR: BAGS

CH.#	SIZE	DIFF VOL %	CUM VOL %
1	2	0	100
2	2.52	4.4	100
3	3.17	3.7	95.6
4	4	4.5	91.9
5	5.04	6.5	87.4
6	6.35	9	80.9
7	8	9.6	71.9
8	10.03	8	62.3
9	12.7	7.4	54.3
10	16	10.4	46.9
11	20.16	14.7	36.5
12	25.4	9	21.8
13	32	5.5	12.8
14	40.32	2	7.3
15	50.8	5.2	5.3
16	64	0	.1

TABLE 21


## PARTICULATE SIZE DISTRIBUTION

### TEST 013 EXIT

#### 21.1 HOURS FROM START OF TEST

##### VOLUME % STATISTICS

MEAN: 13.42 UM  
 MEDIAN: 14.47 UM  
 MODE: 22.24 UM  
 STANDARD DEVIATION: 2.2 UM  
 SKEWNESS: .93 NEGATIVE  
 KURTOSIS: 2.35 PLATYKURTIC



DATE: 12-30-83  
 SAMPLE: 83-854  
 ELECTROLYTE: ISOTONIC  
 DISPERSANT: LIQUID D  
 EQUIPMENT: TA 11  
 APERTURES: 280  
 OPERATOR: JK

CH. #	SIZE	DIFF	CUM
		VOL %	VOL %
1	4	0	100
2	5.04	1.3	100
3	6.35	2.8	98.2
4	8	4	95.6
5	10.08	5.9	91.6
6	12.7	9.1	85.7
7	16	12.4	76.6
8	20.16	12.7	64.2
9	25.4	16.7	51.5
10	32	15.3	34.8
11	40.32	9.5	19.5
12	50.3	4.7	10
13	64	2.9	5.3
14	80.63	1.3	2.4
15	101.59	1.2	1.1
16	128	0	0


-663-

TABLE 22

PARTICULATE SIZE DISTRIBUTION  
TEST 015 INLET

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 24.67 UM  
 MEDIAN: 25.97 UM  
 MODE: 30.15 UM  
 STANDARD DEVIATION: 1.84 UM  
 SKEWNESS: .97 NEGATIVE  
 KURTOSIS: 1.48 PLATYKURTIC



DATE: 12/2/83

SAMPLE: HGDSU BAGNELL G011114 83-960

ELECTROLYTE: ISOTON

DISPERSANT: LOMAR D

EQUIPMENT: TAII

APERTURES: 140

OPERATOR: BAGS


CH.#	SIZE	DIFF VOL %	CUM VOL %
1	2	0	100
2	2.52	1.5	100
3	3.17	1	98.5
4	4	1	97.5
5	5.04	1.3	96.5
6	6.35	1.5	95.2
7	8	2.4	93.7
8	10.08	5.3	91.3
9	12.7	12.2	86
10	16	18.4	73.8
11	20.16	18.3	55.4
12	25.4	12.3	37.1
13	32	8.5	24.8
14	40.32	7.4	16.3
15	50.8	7.1	8.9
16	64	1.8	1.8

TABLE 23

PARTICULATE SIZE DISTRIBUTION  
TEST 015 EXIT

VOLUME % STATISTICS

MEAN: 21.46 UM  
MEDIAN: 21.6 UM  
MODE: 20.12 UM  
STANDARD DEVIATION: 1.87 UM  
SKEWNESS: .85 POSITIVE  
KURTOSIS: 1.89 PLATYKURTIC



DATE 12-30-82  
 SAMPLE 83-506  
 ELECTROLYTE: ISOTONII  
 DISPERSANT: TYIIIA  
 EQUIPMENT: TAI  
 APERTURES: 140  
 OPERATOR: JK


CH.#	SIZE	DIFF VOL %	CUM VOL %
1	2	0	100
2	2.52	.4	100
3	3.17	.6	99.6
4	4	1.2	98
5	5.04	4.2	97.8
6	6.35	9.9	93.6
7	8	17	83.7
8	10.03	16	66.7
9	12.7	9	50.7
10	16	16	41.7
11	20.16	17.8	25.7
12	25.4	7.4	7.9
13	32	.2	.5
14	40.32	.1	.3
15	50.8	.3	.2
16	64	0	0

TABLE 24

PARTICULATE SIZE DISTRIBUTION  
 TEST 017 INLET

VOLUME % STATISTICS

MEAN: 13.24 UM  
 MEDIAN: 12.95 UM  
 MODE: 20.84 UM  
 STANDARD DEVIATION: 1.65 UM  
 SKEWNESS: .98 NEGATIVE  
 KURTOSIS: 1.17 PLATYKURTIC



DATE: 12-30-83  
SAMPLE: 83-955  
ELECTROLYTE: ISOTONIC  
DISPERCANT: TYIIIA  
EQUIPMENT: TAI  
APERTURES: 140  
OPERATOR: JK

CH.#	SIZE	DIFF VOL %	CUM VOL %
1	2	6	100
2	2.52	8.5	100
3	3.17	15.5	91.5
4	4	23.5	78
5	5.04	13.9	52.5
6	6.35	16.8	36.6
7	8	11	21.8
8	10.08	6.8	10.8
9	12.7	2.2	4
10	16	.8	1.8
11	20.16	.3	1
12	25.4	.3	.7
13	32	.1	.4
14	40.32	.1	.3
15	50.8	.1	.2
16	64	.1	.1

TABLE 25

PARTICULATE SIZE DISTRIBUTION  
TEST 017 EXIT

\*\*\*\*\*  
VOLUME % STATISTICS  
\*\*\*\*\*

MEAN: 5.65 UM  
MEDIAN: 5.25 UM  
MODE: 4.44 UM  
STANDARD DEVIATION: 1.59 UM



TABLE 26  
TRACE COMPONENTS IN EXIT GAS CONDENSATE  
DURING SULFIDATION  
GASIFIER RUN 103

Component	AQUEOUS CONDENSATE							
	Test 013 Lab #100101		Test 015 Lab #100104		Test 017 Lab #100106		Test 019 Lab #100109	
	PPMW*	PPMW	PPMW*	PPMW	PPMW*	PPMW	PPMW*	PPMW
Ni	--	0.98	--	1.32	--	1.0	--	3.1
V	--	0.05	--	<0.05	--	<0.05	--	0.05
Cr	--	1.46	--	1.41	--	1.2	--	0.75
K	0.15	0.67	0.55	1.65	4.24	11.4	11.8	7.8
Na	0.57	7.4	1.63	3.06	22.9	49.6	20.6	49.6
Fe	--	1.6	--	7.04	--	15.0	--	14.1
Zn	--	0.87	--	1.66	--	3.5	--	13.0
Ca	--	3.5	--	3.15	--	13.1	--	27.2
Al	--	0.09	--	0.360	--	0.57	--	0.3
Se	--	0.614	--	0.080	--	0.046	--	0.008
As	--	2.38	--	3.58	--	0.62	--	0.32
Hg	--	<0.2	--	<0.2	--	<0.2	--	<0.2
Cu	--	<0.02	--	<0.02	--	<0.02	--	<0.02
F	93	72.4	73	49.0	56	37.9	47	43.7
C1	1000	965	1460	2155	2040	1659	1840	2065
Br	4	6.2	6	9.7	12	6.7	24	25.6
SO <sub>4</sub>	388	145	610	420	600	459	1180	785
PO <sub>4</sub>	<1	<3	3	<3	<1	<3	<1	<3
NO <sub>3</sub>	<1	<2	3	<2	6	<2	4	<2
NH <sub>4</sub>	3780	10130	4710	12468	4830	16000	4320	14500

NOTES:

1. Sampling location is at condenser C1C Knockout.
2. Metals determined by Atomic Absorption/Atomic Emission spectroscopy.
3. Anions and cations determined by ion chromatography.

\* Second analysis taken 8 months later.

TABLE 27

TRACE COMPONENTS IN EXIT GAS CONDENSATE  
DURING REGENERATION  
GASIFIER RUN 103

Component	AQUEOUS CONDENSATE					
	Test 014 Lab #100103		Test 016 Lab #100105		Test 018 Lab #100108	
	PPMW*	PPMW	PPMW*	PPMW	PPMW*	PPMW
Ni	--	0.82	--	0.32	--	2.7
V	--	< 0.05	--	0.07	--	0.06
Cr	--	1.6	--	0.70	--	4.3
K	0.8	< 0.2	0.51	0.28	4.4	5.3
Na	2.6	< 0.04	1.88	2.8	20.6	17.7
Fe	--	15.2	--	3.42	--	75.2
Zn	--	0.91	--	0.60	--	28.1
Ca	--	0.81	--	0.66	--	54.4
Al	--	0.56	--	0.60	--	20.6
Se	--	0.04	--	0.016	--	
As	--	1.88	--	2.76	--	2.28
Hg	--	< 0.2	--	< 0.2	--	0.27
Cu	--	0.03	--	< 0.02	--	< 0.02
F	38	28.2	35	25.7	41	40.1
Cl	440	400	610	251	1100	1148
Br	9	< 4	< 1	< 4	< 1	20.5
SO <sub>4</sub>	3100	552	2030	378	1730	733
PO <sub>4</sub>	< 1	< 3	< 1	< 3	< 1	< 3
NO <sub>3</sub>	2	< 2	< 1	< 2	< 1	< 2
NH <sub>4</sub> <sup>3</sup>	220	255	600	650	990	2052

## NOTES:

1. Sampling location is at condenser C1C Knockout.
  2. Metals determined by Atomic Absorption/Atomic Emission spectroscopy.
  3. Anions and cations determined by ion chromatography.
- \* Second Analysis taken 8 months later.

TABLE 28

ULTIMATE ANALYSIS AND CONCENTRATION OF TARS LEAVING HGD TEST UNIT				
COMPONENT	WT%			
	TEST 013	TEST 015	TEST 017	TEST 019
ASH	0.02	0.09	0.07	2.34
S	2.76	3.78	2.28	3.16
H	7.14	6.89	7.44	8.14
N	0.88	1.02	1.41	1.17
TOTAL CARBON	72.20	79.77	67.28	57.94
CONCENTRATION OF TARS IN EXIT GAS OF HGD TEST UNIT	0.63	0.65	0.50	0.80

TABLE 29

**TAR ULTIMATE ANALYSIS  
AT HOT GAS DESULFURIZATION INLET**

TEST # TYPE	SAMPLE #	DATE TIME	ASH	S	H WT. %	T.C.	N
Test 013 Sulfidation	28344	11/09/83 0500	0.25	1.15	7.46	65.63	1.14
Test 017 Sulfidation	28346	11/14/83 0500	0.40	0.94	8.07	58.76	1.33
Test 017 Sulfidation	28355*	11/14/83 2100	—	0.77	7.29	74.29	2.19
Test 019 Sulfidation	28348	11/17/83 1400	0.20	1.08	7.12	78.80	1.33
Test 019 Sulfidation	28349	11/18/83 0330	0.11	1.23	7.00	76.13	1.32
Test 019 Sulfidation	28358*	11/18/83 2100	0.14	1.38	6.37	83.79	2.04

\* Limited sample available, sample ran on microsystem.

NOTES:

1. Sampling location is S-4 after gasifier cyclone
2. Sample No. 28344 obtained during operation on Air-blown Blacksville coal.
3. Sample No. 28346 and 28355 obtained during operation on Air-blown Kittanning coal.
4. Sample No. 28348, 28349 and 28358 obtained during operation on Air-blown Arkwright coal.

TABLE 30

ULTIMATE ANALYSIS OF COALS  
USED DURING GASIFIER RUN 103

COMPONENT			WT %
	PITTSBURGH SEAM COAL ARKWRIGHT	BLACKSVILLE	KITTANNING SEAM COAL KITTANNING
Moisture	0.39	1.1	0.82
Ash	7.15	10.55	6.43
S	1.82	3.20	0.98
H	5.12	5.58	5.55
N	3.05	1.30	1.61
Total Carbon	77.10	73.17	78.23
Volatiles	38.35	38.25	34.79
Btu/lb	13715	13308	14008

TABLE 31

 TRACE COMPONENTS IN INLET AND EXIT GAS AQUEOUS CONDENSATE  
 DURING SULFIDATION GASIFIER RUN #103

TEST #	013	013	013	015	015	017
LOCATION	INLET	OUTLET	OUTLET	INLET	OUTLET	INLET
DATE	11/08/83	11/08/83	11/09/83	11/11/83	11/11/83	11/14/83
TIME	0950	1315	1140	1325	1040	1005
DURATION	160 Min	137 Min	145 Min	150 Min	120 Min	115 Min
LAB #	100303	100304	100305	100309	100308	100310
SAMPLE #	GI-11-8-1	GO-11-8-2	GO-11-9-3	GI-11-11-5	GO-11-11-4	GI-11-14-7
COMPONENT	PPMW	PPMW	PPMW	PPMW	PPMW	PPMW
Ni	0.14	3.8	0.04	0.23	1.7	0.056
V	<0.05	<0.05	<0.05	<0.05	<0.05	0.099
Cr	2.3	0.12	0.10	3.0	0.37	1.32
K	0.80	3.31	0.82	1.2	4.4	2.63
Na	6.1	12.2	3.7	0.18	8.2	11.5
Fe	14.1	2.8	2.2	5.4	4.0	20.32
Zn	<0.1	93.2	17.2	<0.1	19.8	<0.1
Ca	4.5	8.7	3.3	15.8	9.0	11.96
Al	0.19	<0.02	<0.02	0.94	0.50	0.136
Se	0.103	0.004	<0.005	0.636	0.005	0.285
As	3.22	0.30	0.07	1.66	0.25	1.66
Hg	<0.2	0.78	<0.2	<0.2	<0.2	<0.2
Cu	0.041	0.151	<0.02	<0.02	NS	NS
F	142	17	24	53	NS	NS
Cl	2058	8414	965	2012	NS	NS
Ba	32	13	<4	26	NS	NS
NO <sub>3</sub>	<2	<2	<2	<2	NS	NS
SO <sub>4</sub>	465	700	495	470	NS	NS
PO <sub>4</sub>	<3	<3	<3	<3	NS	NS
NH <sub>4</sub>	7916	13196	11959	13402	NS	NS

## NOTES:

1. Aqueous condensate data obtained from HGD inlet and outlet particulate sampling systems.
2. NS indicates that the component was not measured.

TABLE 32

TRACE COMPONENTS IN INLET AND EXIT GAS  
 DURING SULFIDATION GASIFIER RUN #103  
 TEST #013

LOCATION	INLET	OUTLET	OUTLET	OUTLET
LAB #	100303	100304	100305	100101
SAMPLE #	GI-11-8-1	GO-11-8-2	GO-11-9-3	---
CALCULATED GAS PHASE COMPOSITIONS				
COMPONENT	PPMW	PPMW	PPMW	PPMW
Ni	0.014	0.410	0.004	0.048
V	<0.005	<0.005	<0.005	0.002
Cr	0.228	0.013	0.009	0.071
K	0.079	0.357	0.076	0.032
Na	0.604	1.318	0.344	0.359
Fe	1.394	0.302	0.205	0.078
Zn	<0.01	10.07	1.60	0.042
Ca	0.446	0.940	0.307	0.170
Al	0.019	<0.002	<0.002	0.004
Se	0.010	0.0004	<0.0005	0.030
As	0.319	0.032	0.007	0.115
Hg	<0.02	0.084	<0.019	<0.010
Cu	0.004	0.016	<0.002	<0.001
F	14.1	1.84	2.23	3.51
Cl	204	909	90	47
Br	3.17	1.404	1.21	0.301
NO <sub>3</sub>	<0.198	<0.216	<0.186	<0.097
SO <sub>4</sub>	46	76	46	7
PO <sub>4</sub>	<0.297	<0.324	<0.279	<0.146
NH <sub>4</sub>	784	1425	1112	491

TABLE 33

TRACE COMPONENTS IN INLET AND EXIT GAS  
 DURING SULFIDATION GASIFIER RUN #103  
 TEST #015

LOCATION	INLET	OUTLET	OUTLET
LAB #	100309	100308	100104
SAMPLE #	GI-11-11-5	GO-11-11-4	—
CALCULATED GAS PHASE COMPOSITION			
COMPONENT	PPMW	PPMW	PPMW
Ni	0.022	0.054	0.075
V	<0.005	<0.002	<0.003
Cr	0.288	0.012	0.080
K	0.115	0.141	0.093
Na	0.017	0.262	0.173
Fe	0.518	0.128	0.398
Zn	<0.01	0.634	0.094
Ca	1.517	0.288	0.178
Al	0.090	0.016	0.020
Se	0.061	0.0002	0.005
As	0.159	0.008	0.202
Hg	<0.019	<0.006	<0.011
Cu	<0.002	NS	<0.001
F	5.1	NS	2.77
Cl	193	NS	122
Br	2.5	NS	0.548
NO <sub>3</sub>	<0.19	NS	<0.11
SO <sub>4</sub>	45	NS	24
PO <sub>4</sub>	<0.29	NS	<0.17
NH <sub>4</sub>	1287	NS	704

NS indicates that the component was not measured.

TABLE 34

TRACE COMPONENTS IN INLET AND EXIT GAS  
 DURING SULFIDATION GASIFIER RUN #103  
 TEST #017

LOCATION	INLET	OUTLET
LAB #	100310	100106
SAMPLE #	GI-11-14-7	—
COMPONENT	CALCULATED GAS PPMW	PHASE COMPOSITION PPMW
Ni	0.003	0.043
V	0.005	<0.002
Cr	0.061	0.052
K	0.121	0.490
Na	0.529	2.133
Fe	0.935	0.645
Zn	<0.005	0.151
Ca	0.550	0.563
Al	0.006	0.025
Se	0.013	0.002
As	0.076	0.027
Hg	<0.009	<0.009
Cu	NS	<0.001
F	NS	1.63
Cl	NS	71
Br	NS	0.288
NO <sub>3</sub>	NS	<0.086
SO <sub>4</sub>	NS	19.7
PO <sub>4</sub>	NS	<0.129
NH <sub>4</sub>	NS	688

NS indicates that the component was not measured.

TABLE 35

ANALYSIS OF INLET AND OUTLET TARS DURING GASIFIER RUN #103  
TEST #013

LOCATION	INLET	OUTLET
LAB SAMPLE #	28307	28308
PARTICULATE SAMPLE #	GI-11-8-1	GO-11-8-2
COMPONENT		
	WEIGHT % OF TAR SAMPLE	
BENZENE	0.486	0.025
TOLUENE	1.36	0.032
ETHYL-BENZENE	0.317	0.183
PYRIDINE	0.015	0.037
PICOLINE	0.018	0.094
M & P XYLENE	1.43	0.351
STYRENE	0.230	0.006
O-XYLENE	0.454	0.161
PHENOL	1.32	1.71
INDANE	0.379	0.418
INDENE	1.81	1.07
O-CRESOL	1.15	1.22
M & P CRESOL	2.34	2.44
NAPHTHALENE	4.49	4.59
BENZOTHIOPHENE	0.354	0.362
2-METHYL NAPHTHALENE	2.09	2.00
1-METHYL NAPHTHALENE	1.25	1.09
ACENAPHTHACENE	0.600	0.294
ACENAPHTHENE	0.606	0.794
DIBENZOFURAN	0.456	0.422
FLUORENE	0.772	0.767
PHENANTHRENE	1.21	1.54
ANTHRACENE	0.534	0.738
CARBAZOLE	0.252	0.315
FLUORANTHENE	0.621	1.32
PYRENE	0.645	1.47
MW 216	0.376	0.848
MW 228	0.310	0.804
CHRYSENE	0.269	0.731
BENZO (A) PYRENE	0.113	0.365

## NOTES:

1. Only the lighter fractions of the tar were analyzed. Numbers reported are weight % of the total sample.
2. Analysis was conducted using a gas chromatograph coupled with a mass spectrometer.
3. Analysis was performed by Weston Laboratories, Weston Way, West Chester, PA

## APPENDIX H

### Sidestream Testing - Gasifier Run 104

Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 104

#### Introduction

The high-temperature, sidestream desulfurization unit (1,2,3) was operated for a fourth and final series of tests during fixed-bed gasifier Run No. 104 (4,5,6) between December 8 and 13.

In these tests the main objective was to investigate the desulfurization of lignite gas.

#### Operation of Sidestream Test Unit

With a single batch of the same zinc ferrite sorbent used in all the previous tests, the unit was operated for two sulfidation periods with an intervening regeneration. The gasifier was operated in the air-blown mode, being fed with North Dakota lignite during the first sulfidation and Arkwright coal during the second. The operational schedule is shown in Figure 1.

The reactor was filled with the usual 20.4 kg of sorbent extrusions. Furnace temperatures were set at 1,000°F for the first sulfidation and 1,200°F for the second. In both cases the nominal space velocity was 2,000 h<sup>-1</sup>. For the regeneration the furnace temperatures were set at the usual 1,000°F and nominal space velocity was 500 h<sup>-1</sup>.

Average operating parameters for the tests are shown on the ADACS flow schematics in Figures 2 to 7. Test No. 020 is separated into four on-stream parts because of gas supply interruptions.

In Test No. 020, with the gasifier providing gas from lignite at 160 to 200 psig, breakthrough of hydrogen sulfide occurred after about 45 hours on-stream time. The H<sub>2</sub>S level was generally less than 5 ppm. Reactor pressure drop increased only slightly from about 0.15 to 0.5 psi. There was an increase of reactor temperatures approaching 100°F. Reactor temperatures, pressure drop, and gas flow rate are shown in Figures 8, 9, and 10.

In the regeneration Test No. 021, the steam/air ratio, initially 85/15, was decreased stepwise during the first few hours to 80/20 in order to achieve reaction zone temperatures of about 1,500°F. The reactor pressure drop was very low throughout, about 0.15 psi. Reactor temperatures, pressure drop, and flow rates are shown in Figures 11, 12, and 13.

Test No. 022, lasting about 16 hours, was the final sulfidation of the test series. In this case, with the gasifier providing gas from Arkwright coal at about 130 psig, the aim was to study the effect of the higher temperature on sorbent behavior.

The hydrogen sulfide level in the exit gas initially exceeded 100 ppm, gradually falling to 15 ppm after 8 hours and then resuming an upward trend shortly

thereafter. The reactor pressure drop behaved similarly to that in previous tests with Arkwright coal at similar conditions, exceeding bed-lifting pressure after about 12 hours on-stream. The pressure drop, initially about 0.2 psi, was about 4 psi at the termination of the test. The temperature rise was about 50°F, somewhat less than usual, and attributed to the lesser extent of the shift reaction at the higher temperature. Reactor temperatures, pressure drop, and gas flow rate are shown in Figures 14, 15, and 16.

## Results

- Data Summary

The various process conditions and data collected in Test Nos. 020, 021, and 022 are summarized in Figures 17, 18, and 19.

- Absorption of Sulfur Compounds

Laboratory gas chromatograph analyses of grab samples of gas exiting the hot gas desulfurization unit condenser are shown in Table 1 (7). Corresponding analyses of grab samples of inlet gas from the gasifier cyclone exit are given in Table 2 during the sulfidation tests only. The concentrations of H<sub>2</sub>S, COS, CS<sub>2</sub>, and thiophene (C<sub>4</sub>H<sub>4</sub>S), respectively at both unit inlet and outlet for Test No. 020, are plotted on the semilog plots in Figures 20 to 23. The exit levels of these low molecular weight sulfur compounds are similar to those found in previous tests, the average total level being less than about 10 ppm. H<sub>2</sub>S and COS levels during Test No. 022, in which the sorbent was at a temperature of 1,200° to 1,300°F, were anomalously high throughout their sum never falling below about 45 ppm. Possible reasons for this are discussed later.

The hydrogen sulfide concentration in exit gas from the unit was also measured during the sulfidation tests by the Baseline Industries on-line gas chromatograph and by detector tubes. The values obtained are plotted against on-stream time in Figures 24 and 25, together with some values for sulfur dioxide measured by detector tubes during the second sulfidation. Agreement between on-line chromatograph and detector tube values can be seen to be fairly good with the former somewhat higher the further the values are above the chromatograph calibration point of 3 ppm (see Figure 24). For much higher H<sub>2</sub>S values (see Figure 25), the order seems to be reversed.

Carbonyl sulfide and sulfur dioxide concentrations were also measured by the Baseline chromatograph during the sulfidations. The values, together with those for hydrogen sulfide, are plotted in Figures 26 and 27. COS was not detectable in Test No. 020. In Test No. 022, however, where the H<sub>2</sub>S concentration was much higher, the measured COS level was approximately one-third of the measured H<sub>2</sub>S level. As found previously with regenerated sorbent, some sulfur dioxide can be seen in the early stages of the test.

The amount of sulfur contained in the sorbent at breakthrough approached 20 wt. percent of the fresh sorbent weight in both the sulfidations.

- Gas Analysis for Major Species

Laboratory gas chromatographic analyses, for major species of grab samples of exit and inlets gas, are shown in Tables 3 and 4 respectively.

In contrast to Table 4, the oxygen levels in Table 3 during the sulfidations are inordinately high. This is probably caused by incomplete displacement of air from the sample bottles. Oxygen also appears to be excessively high during the regeneration. Most of the same species were also measured by Bendix on-line gas chromatographs in the exit and inlet gas streams. The measurements, averaged by ADACS statistical analysis, are shown in Tables 5 to 10. Because of the larger water content of the lignite gas, the CO shift reaction proceeded to a larger extent in Test No. 020, occurring to as much as 8 vol. percent of the gas on a dry basis. The extent of the shift reaction in Test No. 022 with Arkwright coal gas was significantly less, about 4 vol. percent. As in previous tests, there is an apparent loss of total carbon oxides between inlet and outlet gas, attributed to carbon deposition.

- Analysis of Regeneration Exit Gas

The regeneration exit gas (see Tables 1, 3, and 9) in the early stages of regeneration, Test No. 021, contained substantial quantities of hydrogen, carbon dioxide, and reduced sulfur compounds which is attributed to the presence of iron carbide/carbon in the sorbent. More of these compounds, i.e., H<sub>2</sub>, CO<sub>2</sub>, H<sub>2</sub>S, COS, and CS<sub>2</sub>, were present than expected. The higher water content of the lignite coal gas, it was thought, should inhibit the formation of iron carbide. After the first few hours of the regeneration, the sulfur content of the exit gas was predominantly in the form of sulfur dioxide.

ADACS plots of CO<sub>2</sub>, H<sub>2</sub>S, O<sub>2</sub>, CO, and H<sub>2</sub> in the regeneration gas from the reactor exit condenser are shown in Figures 28 to 32.

- Sorbent Characterization

After Test No. 022, the sulfidized sorbent was removed from the reactor and sampled for analysis and characterization at a number of points along the reactor length. The results are detailed in Tables 11 and 12. The mineral analysis (see Table 11) differs markedly from that in previous tests with Arkwright coal gas in that the sorbent contains large quantities of wustite, FeO. The amount of wustite is larger at the reactor exit where there is no pyrrhotite. At the reactor inlet a good part of the sorbent's iron content has been converted to pyrrhotite. Remarkably, there is a significant amount of unsulfidized zinc oxide at the reactor inlet, suggesting that it is somewhat inaccessible to hydrogen sulfide which may explain why the sorbent was unable to remove it to its equilibrium level. Only a small amount of magnetite/zinc ferrite remains.

The presence of wustite is undoubtedly due to the high operating temperature of the sorbent, 1,200° to 1,300°F, and the relatively small water concentration in the coal gas undergoing desulfurization.

Table 12 shows that the sorbent contains about 22 wt. percent of sulfur at the reactor inlet, which is rather less than found in prior comparable tests. The carbon content is quite large and comparable to previous tests where iron carbide was found (none was detected in this case). Surface areas and pore volumes were similar throughout and not much different from those of fresh sorbent. Another remarkable result is that the crush strength of the sorbent significantly exceeded that for fresh sorbent at all the sample points. Less than 5 wt. percent of the removed sorbent passed through a No. 12 screen. This relatively small amount of disintegration is associated with the sorbent's preserved crush strength, in marked contrast to previous tests when the sorbent contained substantial amounts of iron carbide.

- Particulate Analysis

In this test series, in Test No. 020, only a single sample of exit gas was taken for characterization of its particulate content (8). The results are summarized in Table 13. The particulate loading of nearly 2 g/Nm<sup>3</sup> is similar in magnitude to the inlet gas loadings in previous tests. The median particle size of about 6 microns is comparable to that found in Test No. 017 (3) with Kittanning coal gas; though in the latter case, the exit gas loading was a few times less. In both cases, a very low reactor pressure drop increase occurred for about 50 hours on-stream time which provides further evidence of a positive correlation between rate of increase of pressure drop and median particle size. Chemical analysis of the particulate indicates that it consists mostly of fly ash from the coal gas. The detailed size distribution for the particulate sample is shown in Table 14.

#### Condensate Analysis

Reactor exit gas condensates were collected from Test Nos. 020 and 021. Analyses of composite samples are shown in Tables 15 and 16, respectively. For Test No. 020, the calculated gas composition is also included. The sulfidation condensate contains significantly greater amounts of Na, K, and Ca, but less Cl and F. The regeneration condensate is also enriched in these elements and, assuming they derive from the previous sulfidation, it is estimated that about 32 percent of Na and 20 percent of Cl are absorbed by the sorbent. In contrast to previous tests with bituminous coal gas, where up to 20 percent of NH<sub>4</sub> was absorbed, less than 1 percent appears to be absorbed in this case. This may be the result of the lower chloride and higher water contents of the lignite gas.

Samples of inlet and outlet condensate during sulfidation Test No. 020 were also obtained in the course of obtaining particulate samples. Their analyses are shown in Table 17. Comparing this analysis of the outlet condensate with that of the composite outlet condensate (see Table 15), the concentrations of Na, K, and Ca are much less in the former. A possible reason for this could be that these constituents have leached out from the relatively large amount of particulate which is not removed before condensation occurs in this case. The significant discrepancy between the chloride concentrations in the two cases is not clear.

The tar layer amounting to about 4 wt. percent was separated from the total exit gas condensate from sulfidation Test No. 020. The ultimate analysis of a

sample of this is shown in Table 18. It appears that the sample contained a large amount of water which could not be separated. Corresponding analyses of tar condensate from the unit inlet for both sulfidation tests are shown in Table 19. Regrettably, the sulfur concentrations are missing for the lignite tar. Ultimate analyses of the lignite and Arkwright coals gasified are shown in Table 20.

### Conclusions

The fourth and final series of tests of the hot gas desulfurization unit in a sidestream of the METC 24 t/d fixed-bed gasifier was successfully concluded. Two sulfidations and an intermediate regeneration of the same zinc ferrite sorbent tested in the previous three series were carried out. North Dakota lignite and Arkwright bituminous coal, respectively, were gasified in the air-blown mode for the two sulfidation tests.

The amount of sulfur absorbed before breakthrough was similar to that in previous tests, about 20 wt. percent of fresh sorbent. In the final sulfidation test, the only one in the test series in the higher temperature range of 1,200° to 1,300°F, much of the sorbent iron content was converted to wustite, FeO. This appeared to slow down the rate at which sulfur compounds reacted with the sorbent, and the hydrogen sulfide level attained before breakthrough was significantly higher than the equilibrium level predicted.

A smaller amount of refractory sulfur compounds in the case of lignite gas than in the case of bituminous coal gas appears to be carried through the desulfurization sorbent in the vaporized tars.

The particulate loading of the desulfurization unit exit gas was rather high in the lignite test, about 2 g/Nm<sup>3</sup>. The median particulate size, however, was low, about 5 µm and the pressure drop across the reactor remained very low throughout. This reinforces the conclusion previously reached that there is a strong positive correlation between rate of pressure drop increase and median particle size. A particulate loading of about 1 g/Nm<sup>3</sup> and a median particle size of about 10 µm appear to be an acceptable specification for inlet gas to the hot gas desulfurization unit.

Halides and alkali and alkaline earth metals were absorbed from the lignite gas by the sorbent and released during regeneration in the proportions of about 32 percent of sodium and 20 percent of chloride for example. Very little ammonia was absorbed in contrast to previous experience.

REFERENCES

1. Grindley, T., "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 101," IR No. 1846, March 1984, METC.
2. Grindley, T. "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 102," IR No. 1984, September 1984, METC.
3. Grindley, T., "Hot Gas Desulfurization Sidestream Test Unit, Fixed-Bed Gasifier Run No. 103," IR No. 2051, November 1984, METC.
4. Pater, K., "Test Plan -- Run No. 104," IR No. 1812, March 1984, METC.
5. Pater, K., "Preliminary Test Summary -- Run No. 104," IR No. 1811, March 1984, METC.
6. Pater, K. "Process Summary Report -- Run No. 104," IR No. 2033, November 1984, METC.
7. Lamey, S. C., R. R. Romanosky, and J. J. Kovach, "Analytical Data -- Producer Run No. 104," IR No. 2059, November 1984, METC.
8. Data provided by R. D. Bagnell, Analytical Sciences Branch, METC.


**ADDENDUM TO APPENDIX H**  
~~ADDENDUM TO APPENDIX I~~

The Baseline G.C. on-line H<sub>2</sub>S, COS, and SO<sub>2</sub> readings as plotted are correct only for the points: H<sub>2</sub>S: 3 ppm; COS: 1.7 ppm; and SO<sub>2</sub>: 5.1 ppm.

Calibration curves are available for correction. Corrected plots are given in Volume 1.

Refer to letter to T. Grindley from E. E. Gorski and P. Johnson, EG&G Washington Analytical Services Center, Inc. January 30, 1986. Subject: DOE-METC/EG&G Contract No. DE-AC21-85MC21353; WBS No. 9KEX-10. HGD Project: Baseline GC/Integrator Conversion Curves.

FIGURE 1



SCHEDULE OF EVENTS


HOT GAS DESULFURIZATION SIDESTREAM TESTING 1983

GASIFIER RUN 104

FIGURE 2

## TEST 020 A

## AVERAGE OPERATING PARAMETERS



**FIGURE 3**  
**TEST 02 B**  
**AVERAGE OPERATING PARAMETERS**





FIGURE 4

**TES. 020 C**  
**AVERAGE OPERATING PARAMETERS**



AVERAGE(S) FOR PERIOD FROM: 17:00: 0 18/ 5/1983 TO 18: 41:33 18/ 5/1983

FIGURE 5  
TES. 020 D  
AVERAGE OPERATING PARAMETERS




FIGURE 6

TE 021

## AVERAGE OPERATING PARAMETERS




FIGURE 7  
TES. 022  
AVERAGE OPERATING PARAMETERS





FIGURE 8

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
○	051	DEGF ABSORBER 5° FROM BOTTOM	5587	977.8	3.895	947.8	8 989.4
○	058	DEGF ABSORBER 15° FROM BOTTOM	5587	1014.	10.78	975.0	8 1061.
○	053	DEGF ABSORBER 25° FROM BOTTOM	5587	1048.	7.836	1016.	1 1068.
▲	054	DEGF ABSORBER 35° FROM BOTTOM	5587	1078.	10.95	1048.	3 1090.
▼	056	DEGF ABSORBER 45° FROM BOTTOM	5587	1089.	8.988	1005.	1 1026.




START TIME OF PLOT      21:39: 0      12/ 8/1983  
STOP TIME OF PLOT        20:15: 0      12/10/1983

TEST 020

REACTOR TEMPERATURES

FIGURE 9

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"H2O	ABSORBER DIFFERENCE PRESSURE	5613	-0.301	5.898	-37.61	1
						8.851	1




START TIME OF PLOT      21:39: 0      12/ 8/1983  
STOP TIME OF PLOT      20:15: 0      12/10/1983

TEST 020  
REACTOR PRESSURE DROP

FIGURE 10

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
3750	SCFH	PROD. GAS OUT OF SYSTEM	5318	1186.	14.98	1088.	1 1187.




START TIME OF PLOT 21:39:99 12/ 8/1983  
STOP TIME OF PLOT 20:15: 0 12/10/1983

TEST 020

EXIT FLOW

FIGURE 11

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	851	DEGF ABSORBER 0° FROM BOTTOM	2489	1189.	118.4	1039.	3 1436.
D	852	DEGF ABSORBER 15° FROM BOTTOM	2489	1159.	103.8	1050.	8 1418.
O	853	DEGF ABSORBER 30° FROM BOTTOM	2489	1104.	67.81	1047.	11 1267.
A	854	DEGF ABSORBER 35° FROM BOTTOM	2489	1073.	129.5	1095.	1 1511.
V	855	DEGF ABSORBER 45° FROM BOTTOM	2489	1014.	78.48	981.5	1 1406.




START TIME OF PLOT 0:15: 0 12/11/1983  
STOP TIME OF PLOT 20:50: 0 12/11/1983

TEST 021

REACTOR TEMPERATURES

FIGURE 12

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ		
294	'H2O	ABSORBER DIFFERENCE PRESSURE	8117	8.495	3.017	-8.518	3	18.10	1




TEST 021

REACTOR PRESSURE DROP

FIGURE 13

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	RIN - FREQ	RMAX - FREQ
O 3758	SCFM	AIR FLOW LOW RANGE	8390	60.78	4.663	40.83	1
D 3754	SCFM	STEAM FLOW	8097	18.47	0.7569	0.650	1
						69.31	15.34
							1




START TIME OF PLOT      01:15: 0      12/11/1983  
 STOP TIME OF PLOT      20:50: 0      12/11/1983

TEST 021

STEAM AND AIR FLOWS

FIGURE 14

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
O	B61	DEGF ABSORBER 8° FROM BOTTOM	1851	1164.	3.748	1157.	84
□	B62	DEGF ABSORBER 15° FROM BOTTOM	1851	1211.	5.877	1195.	8
◊	B63	DEGF ABSORBER 22° FROM BOTTOM	1851	1216.	83.04	1193.	1
▲	B64	DEGF ABSORBER 35° FROM BOTTOM	1851	1238.	16.10	1193.	4
▼	B65	DEGF ABSORBER 48° FROM BOTTOM	1851	1200.	16.36	1170.	1




START TIME OF PLOT 16:40: 0 12/12/1983  
STOP TIME OF PLOT 8: 5: 0 12/13/1983

TEST 022

REACTOR TEMPERATURES

FIGURE 15

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
294	"HBO	ABSORBER DIFFERENCE PRESSURE	1848	-34.94	30.94	-189.3	1
						-0.1454	1




START TIME OF PLOT      16:40: 0      12/12/1983  
STOP TIME OF PLOT        8: 5: 0      12/13/1983

TEST 022

REACTOR PRESSURE DROP

FIGURE 16

SLOT	UNITS	DESCRIPTION	N SAMPLES	MEAN	ST DEV	MIN - FREQ	MAX - FREQ
3750	SCFH	PROD. GAS OUT OF SYSTEM	1827	1116.	15.40	1057.	1 1200.



START TIME OF PLOT 16:40: 0 12/12/1983  
STOP TIME OF PLOT 8: 5: 0 12/13/1983

TEST 022

EXIT FLOW



FIGURE 18

TEST SUMMARY SHEET  
SIDESTREAM TEST UNIT

TEST NO. : 021  
 DATE AND TIME STARTED : 00 15 12/11/83  
 DATE AND TIME ENDED : 20 50 12/11/83  
 TOTAL HOURS : 20.33  
 TYPE : REGENERATION  
 SULFUR REMOVED:

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE  
 SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS

PURPOSE

REGENERATION OF SULFIDED SORBENT FROM T020 GASIFIER RUN :

SORBENT ANALYSIS:

	BEFORE	AFTER
TOTAL SULFUR: (%WT)		
SURFACE AREA: (SQ M/6)		
DENSITY : (G/CC)		
PORE VOLUME: (CC/G)		
MINERAL ANALYSIS:		
ELEMENTAL ANALYSIS:		
TOTAL CARBON: (%WT)		

HGD OPERATING CONDITIONS

INITIAL TEMPERATURE: 1024.2 F  
 PRESSURE : 3.4 PSIG (AVERAGE)  
 SPACE VELOCITY: 573 HOURLY

EXIT SULFUR DATA:

H<sub>2</sub>S :  
 SO<sub>2</sub> : HIGH OF 7.2 % AFTER 18.6 HOURS BY SO<sub>2</sub> MONITOR  
 0.6 % PPM AT END OF RUN .

	INLET MOLE%	EXIT MOLE%	
	WET BASIS	DRY BASIS	
AIR	59.51 SCFH	18.55 %	
H <sub>2</sub> O	12.41 %/HR	81.45 %	
N <sub>2</sub>	0. SCFH		

	CONDENSATE
AQUEOUS	: 246 LBS
HYDROCARBON	: 246 LBS
TOTAL	: 246 LBS

REMARKS

1. PACKED LENGTH IN REACTOR IS 46 7/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERES CS-346 1/2 S SR-10799 UNITED CATALYSTS
2. SORBENT PACKED VOLUME = 0.559 CUBIC FOOT
3. NO CHANGE IN PRESSURE DROP. POSSIBLE INDICATION THAT LITTLE CARBON WAS DEPOSITED DURING LIGNITE SULFIDATION.
4. MAXIMUM TEMPERATURE REACHED WAS 1511 F.
5. EXIT BENDIX GC WAS OPERATING AND PROVIDED O<sub>2</sub> BREAKTHROUGH CURVE, AND H<sub>2</sub>, CO, CO<sub>2</sub>, H<sub>2</sub>S COMPOSITIONS AT EXIT.
6. 15 MINUTE INTERRUPTION IN REGENERATION.
7. AIR FLOW INCREASED FROM 42 TO 60 SCFH AFTER 2 HOURS TO ACCELERATE THE REGENERATION.

CONCLUSIONS:

1. REGENERATION COMPLETED.

TOTAL LB MOLES:  
 FLOW RATE : 321 SCFH

FIGURE 19

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION SIDESTREAM TEST UNIT

TEST NO. : 022  
 DATE STARTED : 16 40 12/12/83  
 DATE ENDED : 08 05 12/13/83  
 TOTAL HOURS : 15.41  
 TYPE : SULFIDATION  
 SULFUR REMOVED: 8.01 LB SB

PURPOSE  
SULFIDATION AT 1200 F.

SORBENT TYPE/WEIGHT: (ZINC FERRITE)/45 LBS  
 SORBENT NO. : UNITED CATALYSTS L-1504  
 SORBENT COMPOSITION: 50.0 MOLE% IRON OXIDE  
 50.0 MOLE% ZINC OXIDE

SORBENT PELLET SIZE: 3/16 INCH DIAMETER EXTRUSIONS  
 GASIFIER OPERATING CONDITIONS

GASIFIER TYPE : DOE/METC FIXED BED  
 COAL TYPE : ARKWRIGHT

STEAM/COAL MASS RATIO: 0.507 ( AVERAGE)  
 STEAM/AIR MASS RATIO : 0.210 ( AVERAGE)

HGD OPERATING CONDITIONS

TEMPERATURE: 1213 F ( AVERAGE)  
 PRESSURE : 124.1 PSIG ( AVERAGE)

SPACE VELOCITY: 2000 HOURLY

INLET MOLE%	INLET MOLE%	EXIT MOLE%	EXIT MOLE%	CONDENSATE	ARKWRIGHT	COAL
DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	DRY BASIS (OIL FREE)	WET BASIS (OIL FREE)	AQUEDUS	: 63.5 LBS	(ESTIMATED)
				HYDROCARBON	: 9.3 LBS	(ESTIMATED)
				TOTAL	: 72.8 LBS	(MEASURED)

H<sub>2</sub>S 0.577

H<sub>2</sub>O 7.2 %

CO<sub>2</sub> 9.95

13.62

CO 19.55

15.06

H<sub>2</sub> 20.82

24.90

CH<sub>4</sub> 3.16

3.06

N<sub>2</sub> 47.10

47.34

O<sub>2</sub> 0.28

1.00

C<sub>2</sub>H<sub>6</sub> 0.29

0.39

## FLOW:

TOTAL  
LB MOLES:

FLOW  
RATE: 1112 SCFH

1198 SCFH

REMARKS

- 1. PACKED LENGTH IN REACTOR IS 47 5/8 INCHES ZINC FERRITE BOTTOM AND TOP 6 INCHES ARE 1/2 INCH CERAMIC SPHERE CS-346 1/2 S SR-10789 UNITED CATALYSTS
- 2. OVERALL PACKED LENGTH 58 7/8 INCHES
- 3. NO FLOW TO COMBUSTOR.
- 4. WATER IN EXIT GAS WAS DETERMINED BY CONDENSATE COLLECTED
- 5. GAS COMPOSITIONS AT INLET OBTAINED BY AVERAGE OF BENDIX GC 7000 #4 DATA SAMPLING AT S-4 GASIFIER CYCLE EXIT.
- 6. GAS COMPOSITIONS AT EXIT OBTAINED BY AVERAGE OF BENDIX GC 6000 #2 DATA, SAMPLING AT HGD EXIT.
- 7. REACTOR PRESSURE DROP REACHED A MAXIMUM OF 128 INCHES OF WATER.

CONCLUSIONS:

- 1. SULFIDATION AT 1200 F RESULTED IN MUCH HIGHER H<sub>2</sub>S LEVEL THAN EXPECTED.
- 2. TIME TO BREAKTHROUGH MUCH SHORTER AT 1200 F COMPARED TO 1000 F.
- 3. AVERAGE SULFUR LOADING IS 17.8 %. NOT MUCH LOWER THAN ON PREVIOUS SULFIDATION ON LIGNITE AT 1000 F.

FIGURE 20

REMOVAL OF HYDROGEN SULFIDE  
FROM COAL GAS BY ZINC FERRITE




FIGURE 21

REMOVAL OF CARBONYL SULFIDE  
FROM COAL GAS BY ZINC FERRITE




FIGURE 22

REMOVAL OF CARBON DISULFIDE  
FROM COAL GAS BY ZINC FERRITE




FIGURE 23  
REMOVAL OF THIOPHENE FROM COAL GAS  
BY ZINC FERRITE





FIGURE 24

# SULFIDATION ON LIGNITE DERIVED GAS

ZINC FERRITE SIDESTREAM TEST UNIT- TEST 020




16-AUG-84 10:25:13

-70-

FIGURE 25

# ZINC FERRITE SULFIDATION

SIDESREAM TEST UNIT- TEST 022



16-AUG-84 13:43:38

FIGURE 26

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 020






FIGURE 27

ZINC FERRITE SULFIDATION  
SIDESTREAM TEST UNIT TEST 022



16-AUG-84 14:47:21


FIGURE 28



PERCENT CO<sub>2</sub>  
BENDIX 6000 \$2 CHROMATOGRAPH  
START TIME 00:15:00 12/11/1983  
STOP TIME 20:50:00 12/11/1983

TEST 021  
REGENERATION  
CARBON BURNOFF AS CO<sub>2</sub>

FIGURE 29




PERCENT H<sub>2</sub>S  
BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 00:15:00 12/11/1983  
STOP TIME 20:50:00 12/11/1983

TEST 021

REGENERATION

H<sub>2</sub>S EFFLUENT


FIGURE 30



PERCENT O<sub>2</sub>  
BENDIX 6000 \$2 CHROMATOGRAPH  
START TIME 00:15:00 12/11/1983  
STOP TIME 20:50:00 12/11/1983

TEST 021  
REGENERATION  
OXYGEN BREAKTHROUGH CURVE


FIGURE 31



PERCENT CO  
BENDIX 6000 \$2 CHROMATOGRAPH  
START TIME 00:15:00 12/11/1983  
STOP TIME 20:50:00 12/11/1983

TEST 021  
REGENERATION  
CARBON BURNOFF AS CO

FIGURE 32



PERCENT H<sub>2</sub>  
BENDIX 6000 #2 CHROMATOGRAPH  
START TIME 00:15:00 12/11/1983  
STOP TIME 20:50:00 12/11/1983

TEST 021

REGENERATION

HYDROGEN GENERATION

TABLE 1

**HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS AT HGD EXIT  
GASIFIER RUN 104  
TRACE COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	COS	CH <sub>3</sub> SH	CS <sub>2</sub> PPM	Thio	NH <sub>3</sub>	H <sub>2</sub> O	SO <sub>2</sub>
SULFI- DATION	HG 1	12/8/83 22:00	ND	0.34	ND	2.76	2.11	ND	4066	ND
	HG 2	12/9/83 00:00	0.12	0.33	ND	2.72	1.98	-	3918	ND
	HG 3	12/9/83 02:00	2.70	0.24	ND	2.90	0.34	ND	3814	ND
	HG 4	12/9/83 04:00	4.12	0.34	ND	2.23	0.33	-	3848	ND
	HG 5	12/9/83 06:00	4.50	ND	ND	2.71	0.33	ND	3529	ND
	HG 6	12/9/83 08:00	0.18	0.40	ND	1.54	-	-	3638	ND
	HG 7	12/9/83 10:30	2.38	ND	ND	4.23	1.52	ND	3176	0.49
	HG 8	12/9/83 12:30	0.60	0.20	ND	3.32	1.85	-	3406	ND
	HG 9	12/9/83 14:30	ND	0.18	ND	2.69	0.28	ND	2606	ND
	HG 10	12/9/83 15:45	1.79	ND	ND	2.00	1.01	-	3330	ND
	HG 11	12/9/83 16:30	0.21	1.07	ND	6.01	0.62	ND	2916	ND
	HG 12	12/9/83 18:45	4.27	1.20	ND	4.11	0.35	-	2550	ND
	HG 13	12/9/83 20:30	2.49	1.15	ND	3.31	0.46	ND	3126	ND
	HG 14	12/9/83 22:30	0.10	0.67	ND	1.98	1.27	-	2980	6.14
	HG 15	12/10/83 00:30	ND	0.10	ND	2.97	0.09	ND	2980	ND
	HG 16	12/10/83 02:30	ND	0.10	ND	0.98	0.07	-	2272	ND
	HG 17	12/10/83 04:30	ND	ND	ND	2.69	1.54	ND	3208	ND
	HG 18	12/10/83 06:30	0.16	ND	ND	2.97	1.35	-	2422	ND

Table 1 (Continued)

**HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS AT HGD EXIT  
GASIFIER RUN 104  
TRACE COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	COS	CH <sub>3</sub> SH	CS <sub>2</sub> PPM	Thio	NH <sub>3</sub>	H <sub>2</sub> O	SO <sub>2</sub>
SULFI- DATION	H6 19	12/10/83 08:30	ND	ND	ND	3.17	0.31	ND	2748	ND
	H6 20	12/10/83 10:30	0.62	0.89	ND	3.22	0.28	-	2812	2.56
T020	H6 21	12/10/83 14:30	ND	ND	ND	3.51	158?	ND	-	0.87
	H6 22	12/10/83 18:30	0.54	ND	ND	ND	4.84	-	-	ND
RESENER	H6 23	12/11/83 02:20	ND	27.56	ND	18.61	3.51	ND	-	ND
ATION	H6 24	12/11/83 06:20	2.40%	56.95	ND	16.53	ND	-	-	3.00%
T021	H6 25	12/11/83 10:20	4118	41.96	ND	10.06	ND	ND	-	10.04
	H6 26	12/11/83 14:20	687	36.64	ND	7.41	ND	-	-	18.52%
	H6 27	12/11/83 18:20	ND	3.81	ND	4.43	ND	ND	-	12.31%
SULFI- DATION	H6 28	12/12/83 17:15	116.5	40.44	0.37	2.51	1.76	-	-	ND
	H6 29	12/12/83 17:40	113.1	34.98	0.26	2.19	2.34	ND	-	ND
T022	H6 30	12/12/83 21:00	69.82	23.39	ND	1.37	1.98	-	-	ND
	H6 31	12/13/83 01:00	15.12	30.30	ND	0.45	1.50	ND	-	ND
	H6 32	12/13/83 05:00	155.7	50.08	ND	1.98	3.50	-	-	ND
	H6 33	12/13/83 08:00	562.9	108.34	1.31	5.55	4.11	ND	-	ND

**NOTES:**

(1) ND = Not Detectables. Detectable levels for H<sub>2</sub>S, COS, CH<sub>3</sub>SH, CS<sub>2</sub>, Thiophene are 0.2 ppm.

(2) - = Analysis not taken.

TABLE 2

HOT GAS DESULFURIZATION  
 GRAB SAMPLE GAS ANALYSIS AT GASIFIER CYCLONE EXIT  
 GASIFIER RUN 104  
 TRACE COMPONENTS

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub> S	COS	CH <sub>3</sub> SH PPM	CS <sub>2</sub>	Thio	NH <sub>3</sub>	H <sub>2</sub> O	SO <sub>2</sub>
SULFI- DATION T020	FN 61	12/9/83 07:00	2188	38.13	61.6	ND	ND	ND	36099	-
	FN 66	12/9/83 09:53	1987.8	33.21	44.22	1.20	ND	ND	7840	-
	FN 71	12/9/83 12:55	1900.8	33.29	36.48	1.15	ND	ND	1396	-
	FN 76	12/9/83 15:45	2398.4	57.24	23.2	1.57	ND	ND	734	-
	FN 81	12/10/83 07:00	2365.2	47.32	28.29	3.68	2.71	ND	1092	-
	FN 89	12/10/83 12:50	2341.0	70.60	67.76	5.69	10.98	ND	1264	-
SULFI- DATION T022	FN 93	12/10/83 15:35	2349.5	64.48	41.41	1.92	3.31	ND	679	-
	FN 125	12/13/83 07:05	4558.0	259.39	8.75	5.38	4.37	ND	692	-
	FN 128	12/13/83 10:35	4349.6	308.28	12.68	8.87	11.48	ND	780	-
	FN 131	12/13/83 13:05	4351.9	341.56	7.84	12.40	10.04	ND	959	-

TABLE 3

**HOT GAS DESULFURIZATION**  
**GRAB SAMPLE GAS ANALYSIS AT HGD EXIT**  
**GASIFIER RUN 104**  
**MAJOR COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub> VOLUME %	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	iC <sub>4</sub>	nC <sub>4</sub>
SULFI-	HG 1	12/8/83 22:00	11.26	7.51	57.68	1.32	5.27	ND	16.46	ND	ND	ND	ND
DATION	HG 2	12/9/83 00:00	15.03	4.15	52.64	1.72	6.00	0.06	19.87	0.04	ND	ND	ND
T020	HG 3	12/9/83 02:00	13.83	5.13	53.39	1.80	6.76	0.09	18.21	0.04	0.06	ND	ND
	HG 4	12/9/83 04:00	13.86	3.73	53.78	1.73	5.64	0.13	20.49	0.05	0.06	ND	ND
	HG 5	12/9/83 06:00	16.23	3.61	50.62	1.73	8.45	0.06	18.79	ND	ND	ND	ND
	HG 6	12/9/83 08:00	20.42	2.00	45.72	2.23	8.15	0.12	20.79	0.06	ND	ND	ND
	HG 7	12/9/83 10:30	11.99	3.23	56.16	1.88	5.31	0.10	20.76	ND	0.07	ND	ND
	HG 8	12/9/83 12:30	12.88	4.86	54.01	2.02	6.28	0.12	19.23	0.03	0.06	ND	ND
	HG 9	12/9/83 14:30	12.37	4.57	52.91	1.97	11.50	0.09	16.04	ND	0.06	ND	ND
	HG 10	12/9/83 15:45	ND	19.32	77.81	0.16	0.22	ND	2.00	ND	ND	ND	ND
	HG 11	12/9/83 16:30	12.22	3.68	53.83	1.87	6.90	0.10	20.84	ND	0.07	ND	ND
	HG 12	12/9/83 18:43	9.87	6.12	57.64	1.76	6.30	0.11	17.64	ND	0.06	ND	ND
	HG 13	12/9/83 20:30	9.93	5.76	58.99	1.51	4.67	0.07	18.52	ND	0.06	ND	ND
	HG 14	12/9/83 22:30	8.23	6.28	59.84	1.61	5.14	0.09	18.25	ND	0.06	ND	ND
	HG 15	12/10/83 00:30	9.69	6.29	56.94	1.98	6.07	0.15	18.24	0.05	0.08	ND	ND
SULFI-	HG 16	12/10/83 02:30	5.57	57.50	1.70	5.65	0.12	18.78	0.03	0.08	ND	ND	ND
DATION	HG 17	12/10/83 04:30	13.47	3.30	52.66	1.90	6.32	0.14	21.53	0.04	0.07	ND	ND
T020	HG 18	12/10/83 06:30	11.13	5.04	56.57	1.96	5.42	0.10	19.20	ND	0.07	ND	ND

Table 3 (Continued)

**HOT GAS DESULFURIZATION**  
**GRAB SAMPLE GAS ANALYSIS AT HGD EXIT**  
**GASIFIER RUN 104**  
**MAJOR COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub> VOLUME %	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	iC <sub>4</sub>	nC <sub>4</sub>
SULFI- DATION TO20	HG 19	12/10/83 08:30	7.24	8.56	60.60	1.56	4.61	0.10	16.78	ND	0.06	ND	ND
	HG 20	12/10/82 10:30	4.84	9.87	62.67	1.64	5.89	0.10	14.44	ND	0.06	ND	ND
	HG 21	12/10/82 14:30	9.52	6.91	57.89	1.71	4.84	0.14	18.33	0.07	0.07	ND	ND
	HG 22	12/10/82 18:30	6.07	7.87	61.32	1.30	5.73	0.08	17.08	ND	0.05	ND	ND
REGENER- ATION TO21	HG 23	12/11/83 02:20	0.98	8.48	78.87	ND	ND	ND	9.43	ND	ND	ND	ND
	HG 24	12/11/83 06:20	ND	8.70	83.16	ND	ND	ND	5.16	ND	ND	ND	ND
	HG 25	12/11/83 10:20	ND	9.61	84.15	ND	ND	ND	2.06	ND	ND	ND	ND
	HG 26	12/11/83 14:20	ND	8.51	83.58	ND	ND	ND	1.16	ND	ND	ND	ND
	HG 27	12/11/83 18:20	ND	16.00	78.81	ND	ND	ND	1.61	ND	ND	ND	ND
SULFI- DATION TO22	HG 28	12/12/83 17:15	10.62	4.29	56.53	2.85	11.83	0.35	12.96	0.12	0.14	ND	ND
	HG 29	12/12/83 17:40	11.87	3.73	55.54	2.81	12.24	0.34	12.70	0.12	0.14	ND	ND
	HG 30	12/12/83 21:00	12.75	3.76	55.76	2.58	12.04	0.31	12.06	0.10	0.13	ND	ND
	HG 31	12/13/83 01:00	5.86	6.95	60.59	2.12	13.52	0.31	9.89	0.09	0.17	ND	ND
	HG 32	12/13/83 05:00	6.77	5.74	60.33	2.37	11.69	0.32	12.00	0.11	0.17	ND	ND
	HG 33	12/13/83 08:00	10.17	4.00	55.30	2.72	15.50	0.37	11.14	0.12	0.18	ND	ND

## NOTES:

- (1) ND = Not Detectable. Detectable levels for H<sub>2</sub>S, COS, CH<sub>3</sub>SH, CS<sub>2</sub>, Thiophene are 0.2 ppm.  
(2) - = Analysis not taken.

TABLE 4

**HOT GAS DESULFURIZATION  
GRAB SAMPLE GAS ANALYSIS AT GASIFIER CYCLONE EXIT  
GASIFIER RUN 104  
MAJOR COMPONENTS**

TEST # TYPE	SAMPLE NO.	DATE TIME	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	C <sub>2</sub> H <sub>6</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>3</sub> H <sub>8</sub>	IC <sub>4</sub>	nC <sub>4</sub>
VOLUME %													
	FN 61	12/9/83 07:00	18.33	0.70	47.43	2.12	15.02	0.13	14.47	0.11	0.06	ND	ND
SULFI- DATION	FN 66	12/9/83 09:53	14.62	0.75	49.05	2.48	13.90	0.14	12.51	0.08	0.36	ND	ND
TG20	FN 71	12/9/83 12:55	17.30	0.88	47.61	2.35	16.52	0.49	13.57	0.38	0.31	ND	ND
	FN 76	12/9/83 15:45	16.50	1.05	50.22	2.16	14.43	0.13	14.89	0.06	0.06	ND	ND
	FN 81	12/10/83 07:00	18.19	0.89	47.59	2.33	14.34	0.40	15.03	0.36	0.37	ND	ND
	FN 89	12/10/83 12:50	18.78	0.71	46.25	2.36	16.41	0.12	14.38	0.13	0.36	ND	ND
	FN 93	12/10/83 15:35	19.42	0.74	45.19	2.69	16.34	0.17	14.79	0.09	0.09	ND	ND
SULFI- DATION 022	FN 125	12/13/83 07:05	16.20	0.78	50.50	2.62	16.53	0.63	16.06	0.08	0.50	ND	ND
	FN 126	12/13/83 10:35	15.76	0.84	50.20	2.79	16.96	0.23	16.13	0.11	0.47	ND	ND
	FN 131	12/13/83 13:05	15.26	0.90	51.31	3.31	16.99	0.25	16.79	0.16	0.49	ND	ND

TABLE 5

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 020A  
AVERAGE SC READINGS

**DURATION**

FROM TO  
21:39: 0 12/ 9/1983 9:40: 0 12/ 9/1983

HGD EXIT BENDIX 6000 #2 CHROMATOGRAPH

READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg BTU	Avg SG	6 BTU	N BTU
12	29.287	22.318	0.140	-0.002	0.652	45.679	2.126	6.222	106.620	25.60	1.145	0.586	139.24	122.26

GASIFIER CYCLONE EXIT BENDIX 7900 LC CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MW	Avg DTY	Avg SG	6 BTU	N BTU
69	22.634	13.887	0.110	0.184	0.279	46.055	2.569	17.140	102.838	24.87	1.112	0.860	157.93	143.78

TABLE 6

**HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 020B  
AVERAGE GC READINGS**

**DURATION**

**FROM**

۱۰

19:23: 0 12/ 9/1983

17: 0: 0 12/ 9/1983

463 EXIT

## **BENDIX 6000 \$2 CHROMATOGRAPH**

\* READ H<sub>2</sub> CO<sub>2</sub> C<sub>2</sub>H<sub>6</sub> H<sub>2</sub>S O<sub>2</sub> N<sub>2</sub> CH<sub>4</sub> CO TOTAL AVG MW AVG DTY AVG %S G BTU N BTU  
 79 26.261 20.451 0.144 -0.001 0.615 46.794 2.076 7.001 103.341 23.17 1.126 0.871 131.50 116.07

### SASIFIER CYCLONE EXIT

**BENDIX 7000 14 CHROMATOGRAPH**

READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	G BTU	N BTU
38	22.464	13.549	0.122	0.163	0.278	43.626	2.733	17.523	102.559	24.73	1.197	0.836	160.68	146.45

TABLE 7

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 020C  
AVERAGE GC READINGS

## DURATION

FROM

17:20: 0 12/ 9/1983

TO:

18: 5: 0 12/ 9/1983

HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg Mn	Avg DTY	Avg SG	6 BTU	M BTU
5	24.010	19.041	0.144	-0.001	0.595	51.070	1.950	3.755	102.564	25.33	1.133	0.976	119.90	104.72

GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

# READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg Mn	Avg DTY	Avg SG	6 BTU	M BTU
5	22.130	14.230	0.124	0.213	0.278	46.450	2.661	16.579	102.664	24.99	1.117	0.364	155.87	141.85

TABLE 8.

**HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 020D  
AVERAGE GC READINGS**

**DURATION**

FROM TO  
19:29: 0 12/ 9/1983 20:15: 0 12/10/1983

HSD EXIT

## BENDIX 6000 II CHROMATOGRAPHY

* READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg DTY	Avg SG	6 BTU	N BTU
154	27.063	21.481	0.161	-0.001	0.650	45.303	2.179	6.441	103.477	25.16	1.126	0.871	133.65	117.79

GAS TETER CYCLONE EXIT

BENETTI 7000 II CHROMATOGRAPH

<u># READ</u>	<u>H<sub>2</sub></u>	<u>CO<sub>2</sub></u>	<u>C<sub>2</sub>H<sub>6</sub></u>	<u>H<sub>2</sub>S</u>	<u>O<sub>2</sub></u>	<u>N<sub>2</sub></u>	<u>CH<sub>4</sub></u>	<u>CO</u>	<u>TOTAL</u>	<u>Avg MM</u>	<u>Avg DTY</u>	<u>Avg 56</u>	<u>6 BTU</u>	<u>N BTU</u>
154	23.363	14.672	0.136	0.221	0.278	45.478	2.758	16.014	102.921	24.80	1.109	0.858	159.30	144.54

TABLE 9

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 021  
AVERAGE GC READINGS

**DURATION**

FROM TO  
0:15: 0 12/11/1983 20:50: 0 12/11/1983

H&D EXIT BENDIX 6000 GC CHROMATOGRAPH

<u>* READ</u>	<u>H<sub>2</sub></u>	<u>CO<sub>2</sub></u>	<u>C<sub>2</sub>H<sub>6</sub></u>	<u>H<sub>2</sub>S</u>	<u>O<sub>2</sub></u>	<u>N<sub>2</sub></u>	<u>CH<sub>4</sub></u>	<u>CO</u>	<u>TOTAL</u>	<u>Avg MM</u>	<u>Avg DTY</u>	<u>Avg S6</u>	<u>G BTU</u>	<u>N BTU</u>
119	1.617	5.079	0.045	0.852	4.048	78.234	-0.015	-0.109	89.753	23.75	1.150	0.890	11.07	9.78

TABLE 10

HOT GAS DESULFURIZATION  
SIDESTREAM TEST UNIT  
TEST 022  
AVERAGE GC READINGS

## DURATION

FROM	TO
16:40: 0 12/12/1983	8: 5: 0 12/13/1983

## HGD EXIT

BENDIX 6000 #2 CHROMATOGRAPH

READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg QTY	Avg SG G BTU	N BTU
92	24.904	13.622	0.385	0.004	1.002	47.342	3.057	15.061	105.377	24.91	1.113	0.861	167.33
													151.33

## GASIFIER CYCLONE EXIT

BENDIX 7000 #4 CHROMATOGRAPH

READ	H <sub>2</sub>	CO <sub>2</sub>	C <sub>2</sub> H <sub>6</sub>	H <sub>2</sub> S	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	TOTAL	Avg MM	Avg QTY	Avg SG G BTU	N BTU
92	20.813	9.949	0.287	0.577	0.280	47.100	3.162	19.554	101.724	24.35	1.088	0.842	171.53
													157.23

TABLE 11

**ANALYSIS OF MINERALS BY X-RAY DIFFRACTION  
IN SULFIDED ZINC FERRITE  
GASIFIER RUN 104**

BED HEIGHT (INCHES)	FRANKLINITE $ZnFe_2O_4$ OR MAGNETITE $Fe_3O_4^{(4)}$						
	HEMATITE $Fe_2O_3$	ZINCITE $ZnO$	MUSTITE $FeO$	ALPHA $ZnS$	BETA $ZnS$	PYRRHOTITE $FeS$	
PERCENT TII (%)							
0 <sup>(1)</sup>	2.8	5.9	23.4	19.6	35.0	13.3	
6	1.0	7.2	30.1	18.7	29.5	13.5	
16	1.4	7.1	29.2	16.2	32.3	13.9	
23	1.6	6.8	30.4	16.7	31.1	13.3	
26	3.2	9.8	36.2	13.3	27.5	9.9	
36	5.3	15.8	50.7	7.0	18.4	2.8	
46 <sup>(2)</sup>	4.9	22.9	58.6	2.8	10.8	-	
FRESH SORBENT	4	89	6				

## NOTES:

1. Bottom/Inlet
2. Top/Outlet
3. Percent TII = Percent Total Integrated Intensity; Directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
4. Franklinit and Magnetite have the same crystal structure and therefore, cannot be readily distinguished by the diffraction pattern.

TABLE 12

SORBENT ANALYSIS OF  
SULFIDED ZINC FERRITE  
GASIFIER RUN 104  
TEST 022

Bed Height (Inches)	Total Carbon (% Wt)	Total Sulfur (% Wt)	BET Surface Area (SQ M/G)	Skeletal Density (G/CC)(3)	Porosity %(4)	Crush Strength (Kg DWL) ± 3.D.(5)	Skeletal Density (G/CC)(6)	Porosity %(7)
0(1)	4.92	21.55	2.28	4.17	1.91	10.1 ± 1.8	3.99	36.5
6	6.89	19.11	1.89	3.87	1.49	9.6 ± 2.4		
16	7.51	18.85	1.64	4.18	1.02	10.6 ± 1.4		
23	7.66	18.75	1.89	3.99	1.54	9.3 ± 2.5	3.49	30.5
26	8.40	15.76	1.65	4.31	0.88	9.8 ± 2.1		
36	7.73	5.98	3.64	6.56	3.79	10.0 ± 2.3		
46(2)	7.95	4.14	2.60	7.55	2.86	9.4 ± 2.3	4.41	43.9
Fresh Sorbent	0	0.13	3.13	6.16	2.59	6.3 ± 2.8	-	60.6(8)

## NOTES:

1. Bottom/Inlet during sulfidation - Outlet during regeneration.
2. Top/Outlet during sulfidation - Inlet during regeneration.
3. Skeletal Density by Helium Pycnometry.
4. Porosity by Nitrogen adsorption for pores up to 600Å diameter.
5. Average and standard deviation of 15 measurements.
6. Skeletal density by mercury porosimetry.
7. Porosity by mercury porosimetry for pores down to 120Å diameter.
8. Porosity by mercury porosimetry for pores down to 30Å diameter.

TABLE 13

**PARTICULATE SAMPLING DATA  
HOT GAS DESULFURIZATION TEST UNIT  
GASIFIER RUN 104**

TEST #	HOURS FROM START OF TEST	PARTICLE LOADING		MEDIAN PARTICLE SIZE $\mu$ m (microns)		CHEMICAL ANALYSIS				
		INLET	EXIT	INLET	EXIT	C	H	N	S	ASH
020	13.9		1.89		5.8	78.0	2.7	2.1	-	15.7

TABLE 14

DATE: 5/14/84

SAMPLE: HGDSU BAGNELL G01291 84-113

ELECTROLYTE: ISOTON

DISPERSANT: LOMAR D

EQUIPMENT: TA II

APERTURES: 70

OPERATOR: ARG

CH.#	SIZE	DIFF VOL %	CUM VOL %
1	.79	0	100
2	1	0	100
3	1.26	3.6	100
4	1.59	5.7	96.4
5	2	7.8	90.7
6	2.52	7.9	82.9
7	3.18	9.7	75
8	4	9.6	65.3
9	5.04	11.3	55.7
10	6.35	7.9	44.4
11	8	8	36.5
12	10.03	10.2	28.5
13	12.7	7.9	18.3
14	16.01	5.3	10.4
15	20.17	.7	5.1
16	25.41	4.4	4.4

\* NOTE THAT PARTICLE SIZE  
DISTRIBUTION IS very BROAD  
AND ~ 4.4% of the  
PARTICLES ARE LARGER THAN  
 $25 \mu m$

## PARTICULATE SIZE DISTRIBUTION TEST 020 EXIT

### VOLUME % STATISTICS

MEAN: 5.84 UM  
MEDIAN: 5.67 UM  
MODE: 5.45 UM  
STANDARD DEVIATION: 3.18 UM  
SKENNESS: 1.05 POSITIVE  
KURTOSIS: 2.24 PLATYKURTIC




TABLE 15

TRACE COMPONENTS IN EXIT GAS  
DURING SULFIDATION  
GASIFIER RUN 104

COMPONENT	TEST 020	
	Aqueous Condensate Analysis	Calculated Gas Phase Composition
	PPMW	PPMW
Ni	0.33	0.046
V	0.18	0.025
Cr	0.25	0.033
K	36.55	5.102
Na	102.5	14.31
Fe	18.7	2.61
In	0.247	0.034
Ca	20.59	2.87
Al	1.20	0.17
Se	0.215	0.030
As	0.18	0.025
Hg	<0.2	<0.028
Cu	0.16	0.022
F	10	1.40
Cl	119	16.61
Br <sup>-</sup>	<4.	0.558
SO <sub>4</sub>	215	30.01
PO <sub>4</sub>	<3	0.42
NO <sub>3</sub>	<2	0.28
NH <sub>4</sub>	7898	1102.

## NOTES:

1. Aqueous condensate analysis from sample # 1000290
2. Sample location is at condenser CIC Knockout.
3. Metals determined by Atomic Absorption/Atomic Emission spectroscopy.
4. Anions and cations determined by ion chromatography.

TABLE 16

**TRACE COMPONENTS IN EXIT GAS AQUEOUS CONDENSATE  
DURING REGENERATION  
GASIFIER RUN 104**

COMPONENT	TEST 021 Aqueous Condensate Analysis PPHM
Ni	0.30
V	0.61
Cr	0.44
K	52.71
Na	113.6
Fe	149.2
Zn	15.6
Ca	115.2
Al	83.2
Se	0.044
As	1.14
Hg	0.383
Cu	<0.02
F	<1
Cl	66
Br	296
SO <sub>4</sub>	590
PO <sub>4</sub>	<3
NO <sub>3</sub>	<2
NH <sub>4</sub>	79

## NOTES:

1. Aqueous condensate analysis from samples # 1000292.
2. Sample location is at condenser CIC Knockout.
3. Metals determined by atomic absorption/atomic emission spectroscopy.
4. Anions and cations determined by ion chromatography.

TABLE 17

TRACE COMPONENTS IN INLET AND EXIT GAS AQUEOUS CONDENSATE  
 DURING SULFIDATION GASIFIER RUN #104  
 TEST #020

LOCATION	INLET	OUTLET
DATE	12-09-83	12-09-83
TIME		
LAB #	100307	100306
SAMPLE #	GI-12-9-2	GO-12-9-1
COMPONENT	PPMW	PPMW
Ni	0.11	0.20
V	<0.05	<0.05
Cr	4.9	0.22
K	2.6	0.52
Na	16.3	2.6
Fe	11.7	1.5
Zn	0.24	2.5
Ca	15.6	3.4
Al	0.18	<0.02
Se	0.496	<0.005
As	2.29	0.04
Hg	<0.2	<0.2
Cu	0.103	<0.02
F	NS	34
Cl	NS	1041
Br	NS	<4
NO <sub>3</sub>	NS	<2
SO <sub>4</sub>	NS	32
PO <sub>4</sub>	NS	<3
NH <sub>4</sub>	NS	9281

## NOTES:

1. Aqueous condensate data obtained from HGD inlet and outlet particulate sampling systems.
2. NS indicates that the component was not measured.

TABLE 18

ULTIMATE ANALYSIS AND CONCENTRATION  
OF TARS LEAVING HGD TEST UNIT  
GASIFIER RUN 104

COMPONENT	TEST 020
	WT %
ASH	0.40
S	0.44
H	10.53
N	0.8
TOTAL CARBON	6.11
CONCENTRATION OF TARS IN EXIT GAS OF HGD TEST UNIT	0.68

## NOTES:

1. Sample number 28250
2. Sample location is at Condenser CIC Knockout
3. Sample contained water, Resulting in low Carbon value.

TABLE 19

**ULTIMATE ANALYSIS OF TARS  
LEAVING GASIFIER CYCLONE  
GASIFIER RUN 104**

HGD TEST #	TEST 020	TEST 020	TEST 020	TEST 022	TEST 022
DATE	12/9/83	12/9/83	12/9/83	12/12/83	12/13/83
TIME	06:00 HRS	10:00 HRS	22:00 HRS	21:00 HRS	03:00 HRS
LAB #	28362	28363	28364	28368	28370
COMPONENT	WT %				
S	NM	NM	NM	1.04	1.14
H	8.03	7.94	8.88	7.29	7.20
N	1.86	1.59	1.58	1.81	1.92
TOTAL CARBON	82.75	82.95	56.45	77.69	80.72

## NOTES:

1. Analysis Obtained from limited samples which were run on microsystems.
2. Samples collected from S-4 precipitator.
3. NM = Not Measured.

TABLE 2C

ULTIMATE ANALYSIS OF COALS  
USED DURING GASIFIER RUN 104

COMPONENT	WT%	
	PITTSBURGH SEAM COAL AKRWRIGTH	NORTH DAKOTA LIGNITE INDIAN HEAD
Moisture	0.39	0.52
Ash	7.15	10.28
S	1.82	1.66
H	5.12	4.76
N	3.05	1.27
Total Carbon	77.10	67.54
Volatile	38.35	40.33
Btu/lb	13715	11956

## APPENDIX I

### Laboratory-Scale Testing - Simulated KRW Gas

#### Performance of Zinc Ferrite Sorbent in Simulated Hot Coal Gas From the KRW Process Development Unit

##### Introduction

In connection with the conceptual design of a zinc ferrite hot gas desulfurization unit by Westinghouse Electric Corporation Synthetic Fuels Division (now KRW Energy Systems, Inc.) as part of the Waltz Mill Coal Gasification Program (1), a program of experiments was designed for the METC, newly revamped, laboratory-scale, high-temperature desulfurization unit to investigate the performance of zinc ferrite sorbent in simulated coal gas corresponding to that anticipated from the KRW process development unit. The experiments were carried out from March to May 1984.

##### Laboratory-Scale Unit

Details of the laboratory-scale unit are given in contractor reports (2,3). The flow schematic is shown in Figure 1. The unit is a redesigned version of that employed in previous test series (4).

The new reactor component, which is 60 inches long by 2 inches diameter, is also made from 316 stainless steel but contains an integral preheater and after cooler and is aluminized internally to minimize hydrogen sulfide reaction with the reactor insides. The reactor is located within a 3-zone clamshell electrically heated furnace. A 12-inch section at the middle of the reactor length is available for the desulfurization sorbent. Temperatures at six points along the center line are measured by means of thermocouples situated in a stainless steel thermowell. The system is maintained at a positive pressure of 25 psig primarily to ensure flow through the on-line gas chromatograph, which measures  $H_2O$ , COS, and  $SO_2$  concentrations in the exit gas. Process conditions can be recorded by an automatic data acquisition and control system (ADACS) (5).

##### Gas Conditions

It is planned to operate the KRW process development unit in both oxygen-blown and air-blown modes. Estimated compositions of the water-quenched gases entering the zinc ferrite unit are shown in Table 1 (6). Gas compositions approximating these were employed at the laboratory scale in a total of eight sulfidation tests: four oxygen blown and four air blown. Carbonyl sulfide and ammonia were excluded as being of minor consequence, and the hydrogen sulfide concentration was elevated so that breakthrough could occur within a day's operation at the space velocity of  $2,000\text{ h}^{-1}$  employed—corresponding to a linear velocity of 15 cm/s through the reactor. The tests were conducted at 4 reactor furnace temperature settings: 1,000, 1,100, 1,200, and 1,300°F.

### Operation of Laboratory-Scale Unit

The operating conditions for the series of tests are summarized in Figures 2 to 13. The first two tests, Nos. 001 and 002, were designed to verify that hydrogen sulfide in simulated coal gas reacts to a negligible extent with the inside of the aluminized reactor. In Test No. 001, simulated Lurgi air-blown gas containing 0.267 vol. percent H<sub>2</sub>S was passed through the empty reactor for about 3 hours. Figure 14, which is a plot of H<sub>2</sub>S concentration in the reactor condenser exit gas, measured by detector tube, shows that the H<sub>2</sub>S level rapidly reached a plateau corresponding to the inlet H<sub>2</sub>S concentration. When H<sub>2</sub>S into the reactor inlet gas was shut off, during a further hour, the H<sub>2</sub>S level in exit gas quickly fell to a few ppm indicating that very little sulfidation of the reactor had taken place. This conclusion was confirmed in Test No. 002, in which a typical regeneration gas consisting of 50 vol. percent each of air and steam was passed through the reactor for 2 hours. Only a few ppm of SO<sub>2</sub>, measured by detector tube, was detected in the reactor condenser exit gas. For a further short period, simulated Lurgi air-blown coal gas was passed through the reactor. H<sub>2</sub>S in the exit gas amounted to only a few ppm.

Test Nos. 003, 004, 005, and 006 were carried out with simulated oxygen-blown gas, containing 1 vol. percent H<sub>2</sub>S, at furnace temperature settings of 1,000, 1,100, 1,200, and 1,300°F, respectively. The reactor contained 715 g of fresh United Catalysts L-1504 3/16-inch zinc ferrite extrusions in each test except for Test No. 003, where the amount was 593 g. Figures 15, 16, 17, and 18 show plots of the H<sub>2</sub>S concentration in reactor condenser exit gas against time on stream for the four tests. Discontinuities in the plots are caused by overnight breaks in the tests. The plots are superimposed in Figure 19. The H<sub>2</sub>S levels before breakthrough are a few ppm as predicted by thermodynamic chemical equilibrium computations. However, the prediction that the level should increase with temperature is not borne out for the 1,200 and 1,300°F tests. In both of these, the H<sub>2</sub>S level is lower than in the 1,100°F test and comparable to the 1,000°F test.

The amounts of sulfur absorbed by the sorbent, computed from the total gas flow through the reactor and the inlet H<sub>2</sub>S concentration in the four tests, are shown in Figure 20, expressed as weight percent of the fresh sorbent. The amount is greatest at 1,200°F but falls off at higher temperatures in accordance with previous experience with the sorbent.

Test No. 003 was repeated in Test No. 003R with 715 g of sorbent instead of 593 g to make it more comparable with the other tests. However, because of a malfunction related to water and hydrogen sulfide admission, the results are not fully valid.

Test Nos. 007, 008, 009, and 010 were carried out with simulated air-blown gas, containing 1 vol. percent H<sub>2</sub>S, at furnace settings of 1,000, 1,100, 1,200, and 1,300°F, respectively. The reactor contained 715 g of fresh United Catalysts L-1504 3/16-inch zinc ferrite extrusions in each test. Test No. 010 was repeated in Test No. 010R because of poor temperature control in the former test. Figures 21, 22, 23, and 24 show plots of the H<sub>2</sub>S concentration in reactor condenser exit gas against time on stream for the four temperatures. The plots are superimposed in Figure 25. The H<sub>2</sub>S concentration levels attained are remarkably similar to those previously obtained

for the oxygen-blown gas tests. Again, the H<sub>2</sub>S levels above 1,100°F were unaccountably lower than expected.

The amounts of sulfur absorbed by the sorbent, computed from the total gas flow through the reactor and the inlet H<sub>2</sub>S concentration in the four tests, are shown in Figure 20 together with the corresponding values for the oxygen-blown gas tests for comparison. The fall-off in sulfur absorbed above 1,200°F appears to be somewhat sharper for the air-blown gas case.

#### Reactor Pressure Drop

The differential pressure across the combined reactor and integral quartz wool packed preheater was measured throughout the desulfurization tests. This pressure drop was initially about 2 inches of water gauge in all cases. In the course of a test, this measured pressure drop increased somewhat, which is attributed to the formation of a water leg at the bottom of the reactor, resulting from unanticipated condensation of water from the reactor inlet gas stream. There is strong evidence, supported by a later test, that the actual reactor pressure drop remained virtually constant in each test.

#### Reactor Temperatures

Tables 2 and 3 show the average temperatures at 2-inch intervals along the reactor axis for Test Nos. 003, 004, 005 and 006 and 007, 008, 009, and 010R, respectively. These temperatures generally do not differ from the furnace settings of 1,000, 1,100, 1,200, and 1,300°F by more than about 25°F.

#### Sorbent Analysis

After breakthrough of H<sub>2</sub>S in each test, the sorbent was cooled under nitrogen and removed from the reactor. Samples were taken from the top (gas outlet) and bottom (gas inlet) of the sorbent bed and analyzed for total sulfur, total carbon, surface area, pore volume, "helium" density, and mineral content. The mineral content, determined by X-ray diffraction, is shown in Tables 4 and 5 for Test Nos. 003, 004, 005, and 006 and 007, 008, 009, and 010R, respectively. The other analyses are given in Figures 4 to 13.

The total sulfur measured in the sorbent at the reactor inlet is generally in accord with that calculated from the flow of H<sub>2</sub>S through the sorbent (see Figure 20). In Test Nos. 003, 004, 005, and 006, the values are 25.5, 27.2, 27.8, and 21.0 wt. percent, respectively, and in Tests Nos. 007, 008, 009, and 010R, they are 21.1, 30.1, 28.6, and 18.4 wt. percent, respectively. Total sulfur at the reactor outlet is usually about 1 wt. percent.

The total carbon measured in the sorbent at both reactor inlet and outlet is less than 0.1 wt. percent, being rather more at the outlet.

The sorbent surface areas at both reactor inlet and outlet are lower at the higher operating temperatures, falling from about 2 to 3 m<sup>2</sup>/g at 1,000°F to 0.5 to 1.5 m<sup>2</sup>/g at 1,300°F. Pore volumes are also correspondingly lower. Surface areas at the reactor inlet, where the sorbent is predominantly in the sulfide form, are generally somewhat lower, up to about two times, than at the outlet, where only a small amount of the sorbent is sulfidized.

The mineral analyses (see Tables 4 and 5) for all the tests indicate that most of the sorbent at the reactor inlet is converted to zinc and iron sulfide whereas at the reactor outlet, the sorbent is predominantly in the form of franklinite (and/or magnetite) and zincite. At 1,200 and 1,300°F, a substantial amount of wustite is present, generally more at the outlet than at the inlet. Cementite is only found in one case, that of air-blown gas at 1,300°F. However, this is not corroborated by the total carbon content, which is less than 0.1 wt. percent.

#### Crush Strength

Fifteen (15) extrusions from fresh sorbent and from each sample, approximately 1 cm long, were crushed between parallel flat surfaces and the crushing force was measured. The results are given in Table 6 (fresh sorbent) and Tables 7 to 14 (Test Nos. 003, 004, 005, 006, 007, 008, 009, and 010R).

Compared with the fresh sorbent, which has an average crush strength of about 8 kg/cm, the crush strength of the sorbent from the reactor inlet is generally rather higher, up to about two times, though this falls off with temperature and, at 1,300°F, the crush strength is about the same as that of fresh sorbent. The crush strength of sorbent from the reactor outlet tends to be slightly less than that of fresh sorbent at all temperatures but, because of the size of the standard deviation, this is not very significant.

#### Gas Analysis

During all the tests, grab samples of gas exiting the reactor outlet condenser were taken every 2 hours and analyzed for H<sub>2</sub>, O<sub>2</sub>, N<sub>2</sub>, CO, CO<sub>2</sub>, and CH<sub>4</sub> for comparison with the metered gas constituents fed to the reactor.

The analyses for the oxygen-blown case, i.e., Test Nos. 003 to 006, are shown in Table 15 and those for the air-blown case, i.e., Test Nos. 007, 008, 009, and 010R, in Table 16.

It is evident that the shift reaction, CO + H<sub>2</sub>O → CO<sub>2</sub> + H<sub>2</sub>, has proceeded to a large extent. This is more so at the lower temperature of 1,000°F than at 1,300°F as expected by thermodynamic equilibrium calculation.

In Table 15, some of the samples can be seen to contain amounts of oxygen and nitrogen which should be absent. This is attributed to incomplete displacement of air from the grab sample bottles.

A small amount of water condensed from reactor inlet gases so that the actual composition entering the sorbent bed differs somewhat from the compositions given in Figures 1 to 12. The corrected compositions are given in Table 17.

#### Condensate Analysis

The water condensing out from the gases exiting the reactor was sampled and analyzed for zinc, iron, and sulfate. The results for Test Nos. 003 to 010 are given in Table 18. The concentration of zinc is generally less than 5 ppmw which, translated to gas concentration, is less than 1 ppm. Though not conclusive (see Test No. 6), there appears to be more zinc in the condensate

at higher temperatures. The amount of sulfate in the condensate, when translated to gas concentration, is of the order of only about 1 ppmw of sulfur. Iron in the condensate is very low, suggesting very little carry over of sorbent into the condenser.

#### Summary and Conclusions

The series of tests carried out, in which simulated oxygen- and air-blown coal gas from the KRW process development unit was passed through zinc ferrite sorbent in a laboratory-scale unit, has demonstrated that the sorbent can function in the regime of gas composition and temperature planned for pilot-scale tests, lowering H<sub>2</sub>S concentration to a few ppmw.

There is evidence that at 1,200°F and above, wustite is formed in both oxygen- and air-blown cases, resulting in a lower sorbent conversion to sulfide before hydrogen sulfide breakthrough. Thus, operation above 1,200°F and at lower steam concentrations in the gases than those employed in these tests is not recommended.

The amount of zinc carry over, less than 1 ppm in the gas, is thought to be acceptable. This level would be an order of magnitude smaller (based on zinc vapor equilibrium) at the higher pressure of operation of the process development unit.

There is a relatively small drop in sorbent surface area at the temperatures investigated but, in the absence of long-term cumulative effects, this will probably be tolerable. Also, sorbent crush strength is not altered markedly by the sulfidation process. In fact, sulfidized sorbent generally has a higher crush strength than fresh sorbent.

Virtually no carbon deposition occurred during the tests and the reactor differential pressure remained constant at a low level.

#### References

1. "Conceptual Design Report of PDU-Scale Hot Gas Desulfurization," submitted to Morgantown Energy Technology Center by KRW Energy Systems, Inc., May 1984.
2. Steinfeld, G., "Status of METC Investigations of Coal Gas Desulfurization at High Temperature," Science Applications, Inc., for Morgantown Energy Technology Center, Report No. DOE/MC/16545-1553, 1984.
3. Steinfeld, G., "Status of METC Investigations of Coal Gas Desulfurization at High Temperature," Science Applications, Inc., for Morgantown Energy Technology Center, 1985.
4. Grindley, T., "Development and Testing of Regenerable Hot Coal Gas Desulfurization Sorbents for Molten Carbonate Fuel Cell Application," IR No. 1133, Morgantown Energy Technology Center, October 1981.
5. Goff, D. R., and D. Armstrong, "System Design of the METC Automatic Data Acquisition and Control System," Report No. DOE/MC/16050-1120, 1982.

6. Verbal Communication from D. K. Schmidt, KRW Energy Systems, Inc., to R. J. Belt, METC, April 16, 1984.

1:910320ds.2jj

TABLE 1  
 Compositions of Gases to be Treated by  
 the Zinc Ferrite Process Development Unit

<u>Component</u>	<u>Oxygen-Blown Gas (Vol.%)</u>	<u>Air-Blown Gas (Vol.%)</u>
CH <sub>4</sub>	1.2	0.63
CO	29.43	12.47
CO <sub>2</sub>	26.12	10.96
H <sub>2</sub>	11.23	13.76
H <sub>2</sub> O	30.99	20.0
H <sub>2</sub> S	0.59	0.301
COS	--	0.016
N <sub>2</sub>	0.44	41.74
NH <sub>3</sub>	--	0.11

TABLE 2

Average Reactor Temperature Profile  
Laboratory-Scale Test Nos. 003 to 006

Test No.	Height Above Bottom	Duration of Test Hours	Average Temperature °F	Standard Deviation °F
003	2 inch	8.0	1,009	20
003	4 inch	8.0	1,035	19
003	6 inch	8.0	1,042	22
003	8 inch	8.0	1,034	17
004	2 inch	9.0	1,102	17
004	4 inch	9.0	1,118	18
004	6 inch	9.0	1,123	19
004	8 inch	9.0	1,122	15
005	2 inch	12.3	1,182	6
005	4 inch	12.3	1,175	16
005	6 inch	12.3	1,238	17
005	8 inch	12.3	1,253	20
006	2 inch	10.0	1,203	13
006	4 inch	10.0	1,273	4
006	6 inch	10.0	1,290	2
006	8 inch	10.0	1,301	2

Notes:

1. Height above bottom is the height above the reactor bottom/inlet.
2. Temperatures were recorded every 1/2 hour. The average temperature and standard deviation were determined from these recorded temperatures.

TABLE 3

Average Reactor Temperature Profile  
Laboratory-Scale Test Nos. 007 to 010R

Test No.	Height Above Bottom	Duration of Test Hours	Average Temperature °F	Standard Deviation °F
007	2 inch	9.5	816	5
007	4 inch	9.5	966	2
007	6 inch	9.5	557*	5
007	8 inch	9.5	1,040	13
008	2 inch	12.0	908	9
008	4 inch	12.0	1,090	9
008	6 inch	12.0	659*	19
008	8 inch	12.0	1,119	9
009	2 inch	12.5	1,005	7
009	4 inch	12.5	1,199	17
009	6 inch	12.5	679*	28
009	8 inch	12.5	1,236	18
010R	2 inch	5.0	1,314	13
010R	4 inch	5.0	1,327	13
010R	6 inch	5.0	1,337	13
010R	8 inch	5.0	1,345	13

\* Thermocouple functioned intermittently during Test Nos. 007, 008, and 009. A break in the thermocouple lead wire was discovered and repaired prior to Test No. 010R.

Notes:

1. Height above bottom is the height above the reactor bottom/inlet.
2. Temperatures were recorded every 1/2 hour. The average temperature and standard deviation were determined from these recorded temperatures.

TABLE 4

Analysis of Minerals by X-Ray Diffraction  
in Sulfidized Zinc Ferrite Laboratory-Scale  
Test Nos. 003 to 006

Test No. Sample Point	003 Top	003 Bottom	004 Top	004 Bottom
Franklinite	77.8	34.2	78.9	27.7
Zincite, ZnO	21.3	3.4	19.1	3.7
alpha-ZnS	0.0	13.7	0.8	13.7
beta-ZnS	0.9	36.8	1.2	40.5
Wustite, FeO	0.0	0.0	0.0	0.0
Pyrrhotite, FeS	0.0	11.8	0.0	12.0
Cementite, Fe <sub>3</sub> C	0.0	0.0	0.0	0.0
Total % TII	100.0	99.9	100.0	97.6
Test No. Sample Point	005 Top	005 Bottom	006 Top	006 Bottom
Franklinite	66.2	14.9	72.1	13.6
Zincite, ZnO	24.2	2.1	17.8	7.3
alpha-ZnS	0.9	2.3	3.1	2.6
beta-ZnS	3.0	70.1	2.7	60.5
Wustite, FeO	5.6	0.8	2.5	11.8
Pyrrhotite, FeS	0.0	9.8	1.7	4.3
Cementite, Fe <sub>3</sub> C	0.0	0.0	0.0	0.0
Total % TII	99.9	100.0	99.9	100.1

Notes:

1. Simulated oxygen-blown gas was used for Test Nos. 003 to 006.
2. Bottom is equivalent to absorber inlet.
3. Top is equivalent to absorber outlet.
4. % TII = Percent Total Integrated Intensity; directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
5. Franklinite (ZnFe2O4) and Magnetite (Fe3O4) have the same crystal structure and cannot be readily distinguished by diffraction pattern. % TII reported for Franklinite could be Franklinite and/or Magnetite.

TABLE 5

Analysis of Minerals by X-Ray Diffraction  
in Sulfidized Zinc Ferrite Laboratory-Scale  
Test Nos. 007 to 010R

Test No. Sample Point	007 Top	007 Bottom	008 Top	008 Bottom
Franklinite	76.4	46.5	76.7	20.9
Zincite, ZnO	21.2	11.8	19.7	3.0
alpha-ZnS	0.8	12.2	1.1	13.3
beta-ZnS	1.6	16.2	2.5	44.3
Wustite, FeO	0.0	0.0	0.0	0.5
Pyrrhotite, FeS	0.0	13.2	0.0	18.0
Cementite, Fe <sub>3</sub> C	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
Total % TII	100.0	99.9	100.0	100.0
Test No. Sample Point	009 Top	009 Bottom	010R Top	010R Bottom
Franklinite	41.9	3.9	25.8	33.7
Zincite, ZnO	25.9	2.4	24.9	8.5
alpha-ZnS	0.9	3.8	0.7	4.7
beta-ZnS	6.7	72.4	9.4	40.7
Wustite, FeO	19.3	3.0	30.4	4.6
Pyrrhotite, FeS	5.2	14.5	0.0	7.7
Cementite, Fe <sub>3</sub> C	<u>0.0</u>	<u>0.0</u>	<u>8.9</u>	<u>0.0</u>
Total % TII	99.9	100.0	100.1	99.9

Notes:

1. Simulated air-blown gas was used for Test Nos. 007 to 010R.
2. Bottom is equivalent to absorber inlet.
3. Top is equivalent to absorber outlet.
4. % TII = Percent Total Integrated Intensity; directly proportional to the concentration of the crystalline phase. Amorphous phase is not accounted for.
5. Franklinite ( $ZnFe_2O_4$ ) and Magnetite ( $Fe_3O_4$ ) have the same crystal structure and cannot be readily distinguished by diffraction pattern. % TII reported for Franklinite could be Franklinite and/or Magnetite.

TABLE 6  
Fresh Zinc Ferrite Sorbent Crush Strength

<u>Sorbent Crush Strength Test No.</u>	<u>Fresh Sorbent Extrusion Length (cm)</u>	<u>Fresh Sorbent Normalized Force (kgf/cm)</u>
1	1.41	15
2	0.59	5
3	1.13	4
4	0.91	13
5	1.04	10
6	1.09	4
7	0.90	5
8	0.87	4
9	0.67	10
10	0.68	4
11	1.18	8
12	0.80	5
13	1.22	10
14	1.02	7
15	1.00	5
Average	0.97	8
Standard Deviation	0.23	3.50

7-25-68  
12-08-68  
9

TABLE 7

Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 003

Sorbent Crush Strength Test No.	T 003 Bottom Extrusion Length (cm)	T 003 Bottom Normalized Force (kgf/cm)	T 003 Top Extrusion Length (cm)	T 003 Top Normalized Force (kgf/cm)
1	0.82	18	1.23	8
2	0.73	12	0.96	9
3	1.10	17	0.80	5
4	1.06	14	1.19	12
5	1.37	11	0.96	4
6	0.70	8	1.02	2
7	0.85	19	0.73	2
8	0.91	17	0.88	16
9	0.95	14	0.81	19
10	1.00	11	1.17	5
11	0.91	20	0.80	2
12	0.73	9	0.69	4
13	1.24	8	0.77	11
14	1.03	20	0.95	2
15	1.00	7	0.86	8
Average	0.96	14	0.92	7
Standard Deviation	0.19	5	0.17	5

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 8  
Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 004

Sorbent Crush Strength Test No.	T 004 Bottom Extrusion Length (cm)	T 004 Bottom Normalized Force (kgf/cm)	T 004 Top Extrusion Length (cm)	T 004 Top Normalized Force (kgf/cm)
1	1.19	11	0.91	4
2	1.04	15	0.82	1
3	0.78	12	1.04	2
4	0.99	14	1.12	11
5	0.98	19	1.18	2
6	1.07	6	0.68	2
7	0.68	6	1.13	4
8	1.01	17	1.20	2
9	1.18	9	1.11	4
10	0.72	9	1.01	3
11	0.87	19	0.73	4
12	0.85	19	1.20	5
13	1.18	7	1.15	1
14	1.25	14	0.73	2
15	0.73	10	0.88	1
Average	0.97	12	0.99	3
Standard Deviation	0.19	5	0.19	3

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 9

Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 005

Sorbent Crush Strength Test No.	T 005 Bottom Extrusion Length (cm)	T 005 Bottom Normalized Force (kgf/cm)	T 005 Top Extrusion Length (cm)	T 005 Top Normalized Force (kgf/cm)
1	0.90	9	1.16	3
2	1.13	7	0.91	3
3	0.93	10	0.87	4
4	0.71	12	0.96	8
5	0.96	7	1.20	2
6	1.09	10	0.71	2
7	0.93	16	0.99	6
8	0.72	12	0.55	1
9	0.71	13	0.94	2
10	0.81	10	0.91	1
11	0.91	11	0.82	3
12	0.80	11	0.92	3
13	1.21	12	0.88	2
14	1.15	15	1.08	2
15	0.65	6	0.85	2
Average	0.91	11	0.92	3
Standard Deviation	0.18	3	0.16	2

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

MR. 7006 -  
02-06-65  
Page 16

TABLE 10

Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 006

Sorbent Crush Strength Test No.	T 006 Bottom Extrusion Length (cm)	T 006 Bottom Normalized Force (kgf/cm)	T 006 Top Extrusion Length (cm)	T 006 Top Normalized Force (kgf/cm)
1	0.91	6	1.12	10
2	0.73	19	1.31	9
3	1.17	11	0.55	3
4	1.35	4	0.98	3
5	1.18	4	0.82	2
6	1.01	8	0.97	6
7	0.82	7	1.14	5
8	0.99	17	1.00	2
9	0.72	11	0.77	3
10	0.69	7	1.02	6
11	0.76	6	1.10	5
12	1.19	5	1.05	3
13	1.21	6	1.42	7
14	1.10	9	0.91	2
15	0.98	6	0.80	1
Average	0.99	8	1.00	5
Standard Deviation	0.21	4	0.22	3

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 11

**Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 007**

Sorbent Crush Strength Test No.	T 007 Bottom Extrusion Length (cm)	T 007 Bottom Normalized Force (kgf/cm)	T 007 Top Extrusion Length (cm)	T 007 Top Normalized Force (kgf/cm)
1	0.95	5	1.27	7
2	1.31	5	1.36	4
3	0.67	11	0.82	8
4	1.11	16	1.25	2
5	1.00	9	1.01	7
6	1.08	4	1.04	4
7	0.96	5	0.91	17
8	0.72	8	0.81	7
9	1.10	16	1.19	10
10	0.85	10	1.20	18
11	0.73	7	1.05	3
12	0.89	8	0.73	10
13	1.07	5	1.05	10
14	0.85	5	0.90	3
15	0.68	22	0.92	5
Average	0.93	9	1.03	8
Standard Deviation	0.19	5	0.19	5

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 12

Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 008

Sorbent Crush Strength Test No.	T 008 Bottom Extrusion Length (cm)	T 008 Bottom Normalized Force (kgf/cm)	T 008 Top Extrusion Length (cm)	T 008 Top Normalized Force (kgf/cm)
1	1.30	11	0.85	2
2	1.04	14	0.74	2
3	0.67	9	1.00	6
4	1.03	13	0.99	5
5	1.09	9	1.03	3
6	0.75	10	1.07	2
7	0.86	17	0.88	3
8	0.96	10	0.68	3
9	1.01	19	0.91	2
10	1.21	18	0.93	2
11	1.11	12	0.92	22
12	1.01	14	0.87	6
13	1.09	18	1.44	6
14	1.05	12	0.82	4
15	1.40	10	0.67	4
Average	1.04	13	0.92	5
Standard Deviation	0.19	4	0.19	5

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 13  
Sulfidized Zinc Ferrite Sorbent Crush  
Strength After Test No. 009

Sorbent Crush Strength Test No.	T 009 Bottom Extrusion Length (cm)	T 009 Bottom Normalized Force (kgf/cm)	T 009 Top Extrusion Length (cm)	T 009 Top Normalized Force (kgf/cm)
1	1.23	6	1.00	5
2	0.81	5	1.28	4
3	1.31	5	1.11	7
4	0.94	5	1.00	9
5	1.09	8	0.81	5
6	0.99	4	1.17	8
7	1.06	5	0.66	3
8	0.86	13	0.70	17
9	1.11	18	0.97	13
10	1.40	6	1.03	10
11	0.89	7	0.95	8
12	0.97	8	0.52	3
13	1.20	14	1.32	4
14	0.97	7	0.88	4
15	1.02	12	0.74	10
Average	1.06	8	0.94	7
Standard Deviation	0.17	4	0.23	4

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 14  
 Sulfidized Zinc Ferrite Sorbent Crush  
 Strength After Test No. 010R

Sorbent Crush Strength Test No.	T 010R Bottom Extrusion Length (cm)	T 010R Bottom Normalized Force (kgf/cm)	T 010R Top Extrusion Length (cm)	T 010R Top Normalized Force (kgf/cm)
1	1.05	5	0.72	4
2	1.66	2	1.00	8
3	0.97	3	1.13	2
4	0.73	3	1.03	4
5	0.85	6	1.06	4
6	1.24	4	1.34	9
7	0.81	12	0.82	9
8	0.89	3	0.93	16
9	1.03	4	0.81	4
10	1.17	2	1.07	3
11	0.93	4	1.05	3
12	1.19	4	1.10	3
13	1.20	16	1.95	9
14	1.02	10	0.93	4
15	0.98	19	0.90	2
Average	1.05	7	0.99	6
Standard Deviation	0.23	5	0.15	4

Notes:

1. Bottom is equivalent to absorber inlet.
2. Top is equivalent to absorber outlet.

TABLE 15

Grab Sample Gas Analysis for Major Components at Condenser  
Exit Laboratory-Scale Test Nos. 003 to 006

Sample No.	Lab No.	Sample Date	Time	H <sub>2</sub> %	O <sub>2</sub> %	N <sub>2</sub> %	CO %	CO <sub>2</sub> %	CH <sub>4</sub> %	Total %
<b>Test No. 003</b>										
HG-003-1 HG No. 1 04/04/84 1100 26.34 0.13 1.30 26.16 44.33 1.23 99.49										
HG-003-2	HG No. 2	04/04/84	1300	32.65	0.07	0.96	23.15	41.46	1.21	99.50
HG-003-3	HG No. 3	04/04/84	1500	20.05	0.94	7.89	24.03	45.32	1.27	99.50
HG-003-4	HG No. 4	04/05/84	1100	25.60	0.05	1.13	25.64	45.76	1.33	99.51
<b>Test No. 004</b>										
HG-004-1	HG No. 5	04/10/84	1100	18.24	1.33	10.34	26.90	41.52	1.17	99.50
HG-004-2	HG No. 6	04/10/84	1300	15.34	2.21	16.68	24.46	39.64	1.16	99.49
HG-004-3	HG No. 7	04/10/84	1500	12.28	3.26	23.94	20.62	38.40	1.01	99.51
HG-004-4	HG No. 8	04/11/84	0930	20.20	1.07	8.53	25.74	42.71	1.25	99.50
<b>Test No. 005</b>										
HG-005-1	HG No. 9	04/13/84	1000	4.05	8.40	32.88	23.57	29.65	0.94	99.49
HG-005-2	HG No. 10	04/13/84	1200	2.06	10.16	44.14	18.09	24.33	0.72	99.50
HG-005-3	HG No. 11	04/13/84	1400	5.56	7.10	28.28	24.63	33.02	0.98	99.57
HG-005-4	HG No. 12	04/16/84	0900	8.18	4.65	18.88	30.07	36.63	1.09	99.50
HG-005-5	HG No. 13	04/16/84	1100	25.06	3.72	8.46	23.61	37.07	1.58	99.50
HG-005-6	HG No. 14	04/16/84	1515	23.10	0.07	0.65	30.99	43.34	1.34	99.49
<b>Test No. 006</b>										
HG-006-1	HG No. 15	04/18/84	1030	18.04	0.33	1.45	33.40	44.64	1.65	99.51
HG-006-2	HG No. 16	04/18/84	1230	19.35	0.29	1.37	35.32	41.74	1.42	99.49
HG-006-3	HG No. 17	04/18/84	1430	26.55	0.13	1.09	30.68	39.75	1.30	99.50
HG-006-4	HG No. 18	04/18/84	1630	24.57	0.69	5.19	26.41	41.32	1.32	99.50
HG-006-5	HG No. 19	04/18/84	1820	19.98	1.51	11.28	20.22	44.51	2.00	99.50

TABLE 16

**Grab Sample Gas Analysis for Major Components at Condenser  
Exit Laboratory-Scale Test Nos. 007 to 010R**

Sample No.	Lab No.	Sample Date	Time	H <sub>2</sub> %	O <sub>2</sub> %	N <sub>2</sub> %	CO %	CO <sub>2</sub> %	CH <sub>4</sub> %	Total %
<b>Test No. 007</b>										
HG-007-1 HG No. 20 04/25/84 1000 23.64 0.08 47.67 9.86 17.20 1.04 99.49										
HG-007-2	HG No. 21	04/25/84	1200	16.72	2.66	54.69	8.64	15.70	1.09	99.50
HG-007-3	HG No. 22	04/25/84	1400	19.21	0.85	51.86	9.66	16.74	1.20	99.52
HG-007-4	HG No. 23	04/25/84	1600	22.51	0.11	49.74	9.10	16.83	1.16	99.45
<b>Test No. 008</b>										
HG-008-1	HG No. 24	05/02/84	1030	26.24	0.45	46.98	10.56	14.09	1.17	99.49
HG-008-2	HG No. 25	05/02/84	1230	19.00	1.20	52.02	11.07	15.06	1.15	99.50
HG-008-3	HG No. 26	05/02/84	1430	17.40	1.62	53.13	10.96	15.20	1.19	99.50
HG-008-4	HG No. 27	05/02/84	1630	21.32	0.23	49.47	11.02	16.25	1.20	99.49
HG-008-5	HG No. 28	05/02/84	1830	16.36	1.87	54.36	10.48	15.22	1.21	99.50
HG-008-6	HG No. 29	05/02/84	2025	18.47	1.03	52.27	10.94	15.50	1.29	99.50
<b>Test No. 009</b>										
HG-009-1	HG No. 30	05/09/84	1000	13.47	2.12	56.69	14.62	11.29	1.30	99.49
HG-009-2	HG No. 31	05/09/84	1200	20.08	0.30	49.28	13.54	15.11	1.18	99.49
HG-009-3	HG No. 32	05/09/84	1400	21.20	0.25	49.01	13.26	14.44	1.33	99.49
HG-009-4	HG No. 33	05/09/84	1600	13.96	2.34	56.13	11.39	14.41	1.27	99.50
HG-009-5	HG No. 34	05/09/84	1800	19.99	0.10	49.80	12.63	15.82	1.17	99.51
HG-009-6	HG No. 35	05/09/84	2000	16.18	1.08	53.81	11.81	15.48	1.13	99.49
<b>Test No. 010R</b>										
HG-010R-1	HG No. 38	06/12/84	1045	17.00	0.10	53.64	12.06	15.52	1.16	99.48
HG-010R-2	HG No. 39	06/12/84	1245	16.47	0.23	54.48	11.41	15.69	1.23	99.51
HG-010R-3	HG No. 40	06/12/84	1405	16.31	0.28	61.77	7.03	12.85	1.26	99.50

LA 2096  
03-08-85  
Page 10

TABLE 17

Calculated Compositions of Gas Entering the Zinc Ferrite Sorbent Bed  
Lab Scale Tests No. 001 through 010R

Test Number	Volume %								Total
	H <sub>2</sub> S	H <sub>2</sub> O	CO <sub>2</sub>	CO	H <sub>2</sub>	CH <sub>4</sub>	N <sub>2</sub>	Air	
001	0.3	28.8	9.6	11.5	16.8	2.8	30.2		100.0
002		50.0						50.0	100.0
003	1.0	32.0	25.0	30.0	11.0	1.0			100.0
003R	1.0	30.7	25.5	30.6	11.2	1.0			100.0
004	1.0	32.0	25.0	30.0	11.0	1.0			100.0
005	1.0	29.8	25.8	31.0	11.3	1.0			100.0
006	1.0	28.8	26.2	31.4	11.5	1.0			100.0
007	1.0	16.9	11.3	12.9	14.4	0.7	42.8		100.0
008	1.0	17.2	11.3	12.9	14.3	0.7	42.6		100.0
009	1.0	17.4	11.3	12.8	14.3	0.7	42.5		100.0
010	1.0	19.9	10.9	12.4	13.8	0.6	41.2		100.0
010R	1.0	19.9	10.9	12.4	13.8	0.6	41.2		100.0

14-2016  
22-08-15  
7-150-14

TABLE 18

Analysis of Exit Gas Knockout Condensate  
Laboratory-Scale Test Nos. 003 to 010

Test No.	Sample No.	Lab No.	Zn ppm	Fe ppm	Sulfate ppm
003	HG-003	100315	3.98	0.342	47.9
004	HG-004	100316	1.40	0.293	32.4
005	HG-005	100317	4.65	0.067	8.2
006	HG-006	100318	1.50	0.067	8.1
007	HG-007	100319	1.71	< 0.050	8.9
008	HG-008	100320	1.31	0.104	10.9
009	HG-009	100321	4.86	0.151	4.5
010	HG-010	100322	18.75	2.020	45.8

Notes:

1. Sample date was May 29, 1984.
2. Simulated oxygen-blown gas was used in Test Nos. 003 to 006.
3. Simulated air-blown gas was used in Test Nos. 007 to 010.

FIGURE 1




FIGURE 2

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION LAB SCALE TEST UNIT**

TEST NO.	001
DATE STARTED	11100 3/27/84
DATE ENDED	14140 3/27/84
TOTAL HOURS	3.6 HRS
TYPE	SULFIDATION

**PURPOSE**

SULFIDE EMPTY ALONIZED METAL REACTOR  
SHAKEDOWN HEULY BUILT QUARTZ/METAL TEST UNIT

SORBENT TYPE/WEIGHT: NONE  
SORBENT NO. :

**ANALYSIS:**

BEFORE      AFTER

**SORBENT COMPOSITION:**

TOTAL SULFUR (%W/W)  
SURFACE AREA (M<sup>2</sup>/G)  
DENSITY (G/CC)  
PORE VOLUME (CC/G)  
MINERAL ANALYSIS:  
ELEMENTAL ANALYSIS:

SORBENT PELLET SIZE:  
PRETREATMENT  
SULFUR LOADING :

**OPERATING CONDITIONS**

DATA: ( DETECTOR TUBE )

TEMPERATURE: 1900 F

EXIT H2S: 2000 - 8000 PPM

PRESSURE : 30 PSIG

EXIT SO2:

SPACE VELOCITY:

EXIT S2:

	FLOW RATE	MOLES	MOLES
	WET BASIS	DRY BASIS	
H2S	0.100 SCFH	0.267 %	0.375 %
H2O (10.77 SCFH)	3.872CC/MIN	28.76 %	
AIR			
CO2	3.6 SCFH	9.61 %	13.5 %
CO	4.3 SCFH	11.48 %	16.12 %
H2	6.3 SCFH	16.82 %	23.62 %
CH4	1.07 SCFH	2.85 %	4.01 %
N2	11.3 SCFH	30.17 %	42.36 %
TOTAL FLOW :	37.44 SCFH		

**REMARKS**

1. SULFUR GAS SHUT OFF AT 1400 HOURS.
2. EXIT SULFUR DOES NOT MATCH INLET SULFUR AS CALCULATED.

**CONCLUSIONS**

1. SULFIDING OF REACTOR APPEARS MINIMAL.

FIGURE 3

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 002  
 DATE STARTED : 11:00 3/28/84  
 DATE ENDED : 13:00 3/28/84  
 TOTAL HOURS : 2 HRS  
 TYPE : REGENERATION

PURPOSE  
 REGENERATION OF EMPTY REACTOR  
 TEST.

SORBENT TYPE/WEIGHT: NONE  
 SORBENT NO. :

## ANALYSIS:

BEFORE AFTER

SORBENT COMPOSITION:

TOTAL SULFUR:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR REMOVED:

SURFACE AREA:

DENSITY:

PORE VOLUME:

MINERAL ANALYSIS:

ELEMENTAL ANALYSIS:

## OPERATING CONDITIONS

## DATA: (DETECTOR TUBE)

TEMPERATURE: 1000 F

EXIT H2S:

PRESSURE : AMBIENT

EXIT SO2: 2.5 - 7.5 PPM

SPACE VELOCITY:

EXIT S2:

EXIT H2:

## FLOW RATE MOLES

H2S

H2O 2.23 CC/MIN 50%

H2R

5.88 SCFM 50%

CO2

CO

H2

CH4

N2

## REMARKS

1. AT 13:00 HOURS SUITCHED TO SULFIDATION GASES WITHOUT H2S.
2. 2 - 15 PPM H2S MEASURED ON SULFIDATION GASES MINUS H2S.

## CONCLUSIONS

1. SULFUR DETECTED DURING REGENERATION WAS MINIMAL, INDICATING AGAIN THAT SULFUR PICKUP BY ALONIZED METAL WALLS IS VERY SMALL.




FIGURE 4

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 803  
 DATE STARTED : 09100 4/04/84  
 DATE ENDED : 11130 4/5/84 WITH INTERRUPTION  
 TOTAL HOURS : 8.5 HRS  
 TYPE : SULFIDATION

PURPOSE  
 SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE  
 OXYGEN BLOUN GAS COMPOSITION

SORBENT TYPE/WEIGHT: ZINC FERRITE/593 GRAMS  
 SORBENT NO.: L-1504

SORBENT COMPOSITION:

SORBENT PELLET SIZE:

PRETREATMENT

SULFUR LOADING

ANALYSIS:

	BEFORE (FRESH)	AFTER INLET	AFTER EXIT
TOTAL SULFUR (XW/U):	0.13	25.5	1.08
SURFACE AREA (M2/G):	3.13	2.419	1.985
SCELESTAL DENSITY (G/CC):	6.16	4.648	6.467
PORE VOLUME (CC/G):	.00432	.004395	.003237
Porosity, %	2.6	2.0	2.1
MINERAL ANALYSIS:			
ELEMENTAL ANALYSIS:			
TOTAL CARBON (XW/U):	0.00	0.05	0.06

OPERATING CONDITIONS

TEMPERATURE: 1000 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

DATA: ( DETECTOR TUBE )

EXIT H2S: 3-5 PPM

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE SCFH	MOLES WET BASIS	MOLES DRY BASIS
H2S	0.31 SCFH	1.0 X	1.5 X
H2O ( 9.94 SCFH)	3.67 CC/MIN	32.0 X	
AIR			
CO2	7.77 SCFH	25.0 X	36.8 X
CO	9.32 SCFH	30.0 X	44.1 X
H2	3.4 SCFH	11.0 X	16.1 X
CH4	0.31 SCFH	1.0 X	1.5 X
N2			
TOTAL FLOW :	31.07 SCFH		

REMARKS

1. H2 WAS SHIFTED FROM 16.1% TO 26.16% AVG.
2. CO WAS SHIFTED FROM 44.1% TO 24.70% AVG
3. CO2 WAS SHIFTED FROM 36.8% TO 44.21% AVG
4. REACTOR WAS ON N2 HOT HOLD OVERNIGHT.
5. CONDENSATE COLLECTED IS 419 CC , ONLY 23 X OF H2O FED AT INLET.

CONCLUSIONS

1. GOOD PERFORMANCE OBTAINED WITH THE HIGH H2O CONTENT OF OXYGEN BLOUN GAS.

FIGURE 5

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO.	003R
DATE STARTED	08:45 6/19/84
DATE ENDED	17:00 6/20/84
TOTAL HOURS	21 HRS
TYPE	SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE OXYGEN BLOWN GAS COMPOSITION. REPEAT OF T003 WITH 715 GM SORBENT LOADING INSTEAD OF 593 GM.

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
SORBENT NO.: L-1504

## SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
PRETREATMENT:  
SULFUR LOADING:

## ANALYSIS:

	BEFORE (FRESH)	AFTER INLET	EXIT
TOTAL SULFUR (%W/W):	0.13	33.36	4.26
SURFACE AREA (M <sup>2</sup> /G):	3.13	2.9168	1.8811
SCAFER DENSITY (G/CC):	6.16	3.911	5.086
PORE VOLUME (CC/G):	.00432	.005017	.003243
MINERAL ANALYSIS:	2.6	1.9	1.6
ELEMENTAL ANALYSIS:			
TOTAL CARBON (%W/W):	0.00	0.06	0.06

## OPERATING CONDITIONS

TEMPERATURE: 1000 F

PRESSURE: 25 PSIG

SPACE VELOCITY: 2000

	FLOW RATE SCFH	MOLES WET BASIS	MOLES DRY BASIS
H <sub>2</sub> S	0.31 SCFH	1.0 %	1.5 %
H <sub>2</sub> O ( 9.94 SCFH)	3.57 CC/MIN	32.0 %	
AIR			
C <sub>0</sub> 2	7.77 SCFH	25.0 %	36.8 %
CO	9.32 SCFH	30.0 %	44.1 %
H <sub>2</sub>	3.4 SCFH	11.0 %	16.1 %
CH <sub>4</sub>	0.31 SCFH	1.0 %	1.5 %
N <sub>2</sub>			
TOTAL FLOW:	31.07 SCFH		

## DATA: ( DETECTOR TUBE )

EXIT H<sub>2</sub>S: 1 PPM FOR 6.75 HOURS, GRADUAL RISE THEREAFTEREXIT SO<sub>2</sub>:EXIT S<sub>2</sub>:EXIT H<sub>2</sub>I:

## REMARKS

- CONDENSATE DRAINED FROM KNOCKOUT POT @ TEST END: 1800 CC H<sub>2</sub>O
- CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 270 CC H<sub>2</sub>O. THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR SORBENT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT. ACTUAL H<sub>2</sub>O FLOW RATE ENTERING SORBENT BED WAS 3.36 CC/MIN.
- ONE HOUR INTERRUPTION 1430-1530 HOURS 6/20/84 DUE TO CHANGING OF CO CYLINDER AND GETTING WATER OUT OF H<sub>2</sub>S ROTAMETER.
- WATER PRESSURE APPARENTLY OVERCOMES H<sub>2</sub>S PRESSURE AND CAUSES WATER TO BACK UP INTO H<sub>2</sub>S FLOUMETER.
- REACTOR PRESSURE DROP INCREASES FROM 3 - 12 INCHES OF WATER.
- TEST INTERRUPTED FOR N<sub>2</sub> HOT HOLD OVERNIGHT.

## CONCLUSIONS:

- GOOD PERFORMANCE MEASURED, BUT WATER IN H<sub>2</sub>S ROTAMETER TOWARDS LATTER PART OF TEST RAISES QUESTION AS TO ACCURACY TO DATA.

FIGURE 6

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 004  
 DATE STARTED : 09:00 4/10/84  
 DATE ENDED : 10:45 4/11/84  
 TOTAL HOURS : 8.75 HRS  
 TYPE : SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE  
OXYGEN BLOWN GAS COMPOSITION

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO. : L-1504

## SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

## ANALYSIS:

	BEFORE	AFTER	INLET	EXIT
TOTAL SULFUR (XU/U):	0.13	2.82		
SURFACE AREA (M <sup>2</sup> /G):	3.13	.2019	2.299	
DENSITY (G/CC):	6.16	4.26	5.49	
PORE VOLUME (CC/G):	.00132	.001595	.003192	
MINERAL ANALYSIS:	2.6	0.7	1.7	
ELEMENTAL ANALYSIS:				
TOTAL CARBON (XU/U):	0.00	0.07		

## OPERATING CONDITIONS

TEMPERATURE: 1100 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

DATA: ( DETECTOR TUBE )

EXIT H2S: 3 - 6 PPM

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLE%	MOLE%
	SCFH	WET BASIS	DRY BASIS
H2S	0.31 SCFH	1.0 %	1.5 %
H2O ( 9.94 SCFH)	3.57 CC/MIN	32.0 %	
AIR			
CO2	7.77 SCFH	25.0 %	36.8 %
CO	9.32 SCFH	30.0 %	44.1 %
H2	3.4 SCFH	11.0 %	16.1 %
CH4	0.31 SCFH	1.0 %	1.5 %
N2			
TOTAL FLOW :	31.07 SCFH		

## REMARKS

1. CONDENSATE COLLECTED: 836 CC, 45% OF H2O FED AT INLET.
2. GRAB SAMPLES FOR MAJORS CONTAINED 8-23% N2, INDICATING THAT SAMPLE BOTTLES WERE NOT PURGED LONG ENOUGH.
3. TEST WAS INTERRUPTED WITH N2 HOT HOLD OVERNIGHT AND CONTINUED THE NEXT DAY.
4. REACTOR PRESSURE DROP INCREASED FROM 2.3-10 INCHES OF WATER, AND DROPPED SLIGHTLY AFTER N2 HOT HOLD.

## CONCLUSIONS

1. REASONABLY GOOD PERFORMANCE WITH HIGH H2O CONTENT ON OXYGEN BLOWN GAS.

FIGURE 7

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 005  
 DATE STARTED : 08100 4/13/84  
 DATE ENDED : 16100 4/16/84 WITH INTERRUPTION  
 TOTAL HOURS : 12.25 HRS  
 TYPE : SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE OXYGEN  
 BLOWN GAS COMPOSITION AT 1200 F.

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO. : L-1504

## SORBENT COMPOSITION:

## SORBENT PELLET SIZE:

## PRETREATMENT:

## SULFUR LOADING :

## ANALYSIS:

	BEFORE (FRESH)	AFTER INLET	EXIT
TOTAL SULFUR (XU/U):	0.13	27.8	1.76
SURFACE AREA (M2/G):	3.13	0.548	1.018
DENSITY (G/CC):	6.16	4.15	6.50
PORE VOLUME (CC/G):	.00432	.000370	.001324
MINERAL ANALYSIS:	2.6	0.7	0.9
ELEMENTAL ANALYSIS:			
TOTAL CARBON (XU/U):	0.00	0.03	0.08

## OPERATING CONDITIONS

TEMPERATURE: 1200 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

## DATA: ( DETECTOR TUBE )

EXIT H2S: 1 - 6 PPM FOR 12 HOURS

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE SCFH	MOLES WET BASIS	MOLES DRY BASIS
H2S	0.31 SCFH	1.0 %	1.5 %
H2O ( 9.94 SCFH)	3.57 CC/MIN	32.0 %	
AIR			
CO2	7.77 SCFH	25.0 %	36.8 %
CO	9.32 SCFH	30.0 %	44.1 %
H2	3.4 SCFH	11.0 %	16.1 %
CH4	0.31 SCFH	1.0 %	1.5 %
H2			
TOTAL FLOW :	31.07 SCFH		

## REMARKS

- CONDENSATE DRAINED FROM KNOCKOUT POT @ TEST END: 980 CC H2O.
- CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 260 CC H2O.  
THE THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR  
SORBENT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT.  
ACTUAL H2O FLOW RATE ENTERING SORBENT BED WAS 3.22 CC/MIN.
- REACTOR BED HEIGHT IS 8 INCHES.
- GRAB SAMPLES FOR MAJOR COMPONENTS CONTAINED UP TO  
44 % NITROGEN, INDICATING THAT SAMPLE BOTTLES WERE  
NOT PURGED LONG ENOUGH DURING SAMPLING.
- UP TO 0.4 PPM CO2 DETECTED AT BEGINNING OF RUN.
- TEST INTERRUPTED ON H2 HOT HOLD OVER THE WEEK END.
- REACTOR PRESSURE DROP INCREASED FROM 1.8 - 0.4 INCHES  
BUT DROPPED DOWN TO 2.2 AFTER HOT HOLD.

## CONCLUSIONS

- GOOD PERFORMANCE AT 1200 F AND HIGH H2O CONTENT OF  
OXYGEN BLOWN COMPOSITION.




FIGURE 8

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 006  
 DATE STARTED : 08:30 4/18/84  
 DATE ENDED : 18:30 4/18/84 (NO INTERRUPTIONS)  
 TOTAL HOURS : 10 HRS  
 TYPE : SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE OXYGEN  
 BLOWN GAS COMPOSITION AT 1300 F.

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO.: L-1504

SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR LOADING:

## ANALYSIS:

	BEFORE (FRESH)	AFTER INLET	EXIT
TOTAL SULFUR (XU/U)	0.13	21.0	5.43
SURFACE AREA (M2/G)	3.13	0.57	1.56
SPHERICAL DENSITY (G/CC)	6.16	4.50	5.27
PORE VOLUME (CC/G)	.00432	.000436	.002071
POROSITY %	MINERAL ANALYSIS:	0.2	/
ELEMENTAL ANALYSIS:	2.6	0.2	/
TOTAL CARBON (XU/U)	0.00	0.05	0.05

## OPERATING CONDITIONS

TEMPERATURE: 1300 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

## DATA: ( DETECTOR TUBE)

EXIT H2S: 1 - 3 PPM FOR 7 HOURS

EXIT SO2:

EXIT S2:

EXIT H2:

## REMARKS

- CONDENSATE DRAINED FROM KNOCKOUT POT @ TEST END: 550 CC H2O.
- CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 300 CC H2O.  
 THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR  
 SORBENT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT.  
 ACTUAL H2O FLOW RATE ENTERING SORBENT BED WAS 3.07 CC/MIN.
- REACTOR BED HEIGHT IS 8 INCHES.
- REACTOR PRESSURE DROP INCREASED FROM 3.4 TO 11.4 INCHES  
 OF WATER.
- H2 SHIFT FROM 16.1% TO 21.3% AVG.  
 CO SHIFT FROM 44.1% TO 33.1 AVG.  
 CO2 SHIFT FROM 36.8% TO 42.04% AVG

## CONCLUSIONS:

- GOOD PERFORMANCE AT 1300 F ON HIGH H2O CONTENT  
 OXYGEN BLOWN GAS COMPOSITION.

	FLOW RATE SCFH	MOLE%	MOLE%
		WET BASIS	DRY BASIS
H2S	0.31 SCFH	1.0 %	1.5 %
H2O ( 9.94 SCFH)	3.57 CC/MIN	32.0 %	
AIR			
CO2	7.77 SCFH	25.0 %	36.8 %
CO	9.32 SCFH	30.0 %	44.1 %
H2	3.4 SCFH	11.0 %	16.8 %
CH4	0.31 SCFH	1.0 %	1.5 %
N2			
TOTAL FLOW :	31.07 SCFH		

FIGURE 9

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION LAB SCALE TEST UNIT**

TEST NO.	907
DATE STARTED	08:00 4/25/84
DATE ENDED	17:30 4/25/84
TOTAL HOURS	9.5 HRS
TYPE	SULFIDATION

## PURPOSE

## SULFIDE ZINC FERRITE (L1S04) USING WESTINGHOUSE AIR BLOUM GAS COMPOSITION

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
SORBENT NO.: L-1504

## ANALYSIS

BEFORE (FRESH)	AFTER	
INLET		EXIT
0.13	21.69	1.79
3.13	1.38	2.13
6.16	4.25	5.65
.00432	.002007	.003018
2.6	0.8	1.7
0.00	0.08	0.08

#### SORBENT COMPOSITIONS

### **SORBENT PELLET SIZE:**

## **PRETREATMENT**

## SULFUR LOADING

## OPERATING CONDITIONS

TEMPERATURE: 1899 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

DATA: { DETECTOR-TUBE }

EXIT M2S: 1 - 1 PPM FOR 8 HOURS

EXIT 502:

EXIT S2:

EXIT H2I

	FLOW RATE	MOLES WET BASIS	MOLES DRY BASIS
H2S	0.31 SCFH	1.0 %	1.2 %
H2O ( 6.2 SCFH)	2.22 CC/MIN	20.0 %	
AIR			
CO2	3.4 SCFH	11.0 %	13.7 %
CO	3.87 SCFH	12.5 %	15.5 %
H2	4.3 SCFH	13.8 %	17.2 %
CH4	0.20 SCFH	0.63 %	0.78 %
N2	12.82 SCFH	41.7 %	51.6 %
TOTAL FLOW :	31.07 SCFH		

## REMARKS

- CONDENSATE DRAINED FROM KNOCKOUT POT @ TEST END: 490 CC H<sub>2</sub>O.
  - CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 230 CC H<sub>2</sub>O.  
THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR  
SORBEIT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT.  
ACTUAL H<sub>2</sub>O FLOW RATE ENTERING SORBENT BED WAS 1.82 CC/MIN.
  - REACTOR BED HEIGHT IS 8 INCHES.
  - H<sub>2</sub> WAS SHIFTED FROM 17.2 % TO 20.52 % AUG.  
CO WAS SHIFTED FROM 15.5 % TO 9.3 % AUG.  
CO<sub>2</sub> WAS SHIFTED FROM 13.7 % TO 16.6 % AUG.

## **CONCLUSIONS**

- ## I. GOOD PERFORMANCE ON AIR BLOWN GAS COMPOSITION AT 1000 F

FIGURE 10

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION LAB SCALE TEST UNIT**

TEST NO. : 008  
 DATE STARTED : 08:30 5/2/84  
 DATE ENDED : 20:30 5/2/84  
 TOTAL HOURS : 12 HRS  
 TYPE : SULFIDATION

**PURPOSE**

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE AIR BLOWN GAS COMPOSITION

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO. : L-1504

**SORBENT COMPOSITION:**

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR LOADING:

**ANALYSIS:**

	BEFORE (FRESH)	AFTER INLET	EXIT
TOTAL SULFUR (XU/U):	0.13	30.14	2.90
SURFACE AREA (M2/G):	3.13	1.24	1.72
SPECIFIC DENSITY (G/CC):	6.16	4.22	5.27
PORE VOLUME (CC/G):	.00432	.001918	.002435
MINERAL ANALYSIS:	2.4%	0.8	1.3
ELEMENTAL ANALYSIS:			
TOTAL CARBON (XU/U):	0.00	0.03	0.05

**OPERATING CONDITIONS**

TEMPERATURE: 1100 F  
 PRESSURE : 25 PSIG  
 SPACE VELOCITY: 2000

**DATA: ( DETECTOR TUBE )**

EXIT H2S: 5 PPM FOR 11.5 HOURS

EXIT SO2:

EXIT S2:

EXIT H2:

**REMARKS**

- CONDENSATE DRAINED FROM KNOCKOUT POT AT TEST END: 680 CC H2O.
- CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 260 CC H2O.  
THE THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR  
SORBENT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT.  
ACTUAL H2O FLOW RATE ENTERING SORBENT BED WAS 1.86 CC/MIN.
- REACTOR BED HEIGHT 8 INCHES.
- H2 SHIFTED FROM 17.2 % TO 19.8 % AVG.  
CO SHIFTED FROM 15.5 % TO 19.8 % AVG.  
CO2 SHIFTED FROM 13.7 % TO 15.2 % AVG.
- REACTOR PRESSURE DROP INCREASED FROM 3.1 TO 11.0 INCHES

**CONCLUSIONS**

- GOOD PERFORMANCE ON AIR BLOWN GAS COMPOSITION AT 1100 F.
- H2S AT EXIT HIGHER THAN AT 1000 F. AS EXPECTED BY EQUILIBRIUM CONSIDERATIONS.

	FLOW RATE SCFH	MOLE%	MOLE%
		WET BASIS	DRY BASIS
H2S	0.31 SCFH	1.0 %	1.2 %
H2O ( 6.2 SCFH)	2.22 CC/MIN	20.0 %	
AIR			
CO2	3.4 SCFH	11.0 %	13.7 %
CO	3.87 SCFH	12.5 %	15.5 %
H2	4.3 SCFH	13.8 %	17.2
CH4	0.20 SCFH	0.63 %	0.78 %
N2	12.82 SCFH	41.7 %	51.6 %
TOTAL FLOW :	31.07 SCFH		

REC'D 20/10/84  
 FILED 20/10/84  
 INDEXED 20/10/84  
 SERIALIZED 20/10/84  
 FILED 20/10/84

FIGURE 11

**TEST SUMMARY SHEET**  
**HOT GAS DESULFURIZATION LAB SCALE TEST UNIT**

TEST NO. : 009  
 DATE STARTED : 08100 5/09/84  
 DATE ENDED : 20140 5/09/84  
 TOTAL HOURS : 12.5 HRS  
 TYPE : SULFIDATION

**PURPOSE**

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE AIR BLOWN GAS COMPOSITION

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO. : L-1504

SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT  
 SULFUR LOADING :

**ANALYSIS:**

	BEFORE (FRESH)	INLET	EXIT
TOTAL SULFUR (W/W/U):	0.13	28.63	1.84
SURFACE AREA (M2/G):	3.13	0.74	1.17
DENSITY (G/CC):	6.16	4.18	5.33
PORE VOLUME (CC/G):	.00432	.000748	.001714
MINERAL ANALYSIS:	2.6	0.3	0.7
ELEMENTAL ANALYSIS:			
TOTAL CARBON (W/W/U):	0.00	0.03	0.04

**OPERATING CONDITIONS**

TEMPERATURE: 1200 F  
 PRESSURE : 25 PSIG  
 SPACE VELOCITY: 2000

**DATA: ( DETECTOR TUBE )**

EXIT H2S: 1 PPM FOR 11.5 HOURS  
 EXIT SO2:  
 EXIT S2I:  
 EXIT H2I:

	FLOW RATE	MOLEX WET BASIS	MOLEX DRY BASIS
H2S	0.31 SCFH	1.0 %	1.2 %
H2O ( 6.2 SCFH)	2.22 CC/MIN	20.0 %	
AIR			
CO2	3.4 SCFH	11.0 %	13.7 %
CO	3.87 SCFH	12.5 %	15.5 %
H2	4.3 SCFH	13.8 %	17.2 %
CH4	0.29 SCFH	0.63 %	0.78 %
N2	12.82 SCFH	41.7 %	51.6 %
TOTAL FLOW :	31.07 SCFH		

**REMARKS**

- CONDENSATE DRAINED FROM KNOCKOUT POT @ TEST END: 670 CC H2O.
- CONDENSATE DRAINED FROM REACTOR AT END OF TEST: 250 CC H2O. THEREFORE, ACTUAL COMPOSITION OF GAS ENTERING REACTOR SORBENT BED WAS DIFFERENT THAN COMPOSITION SHOWN AT LEFT. ACTUAL H2O FLOW RATE ENTERING SORBENT BED WAS 1.89 CC/MIN.
- REACTOR BED HEIGHT 8 INCHES.
- H2 SHIFTED FROM 17.2 % TO 17.5 % AVG.  
 CO SHIFTED FROM 15.5 % TO 12.9 % AVG.  
 CO2 SHIFTED FROM 13.7 % TO 14.42 % AVG.
- REACTOR PRESSURE DROP INCREASED FROM 2.6 TO 8.2 INCHES.

**CONCLUSIONS**

- GOOD PERFORMANCE ON AIR BLOWN GAS COMPOSITION AT 1200 F.
- NOT MUCH SHIFT CONVERSION AT THIS TEMPERATURE.

FIGURE 12

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 010  
 DATE STARTED : 08100 5/15/84  
 DATE ENDED : 08140 5/15/84  
 TOTAL HOURS : 2.67 HRS  
 TYPE : SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE AIR  
BLOWN GAS COMPOSITION

SORBENT TYPE/WEIGHTS : ZINC FERRITE/.715 GRAMS  
 SORBENT NO. : L-1504

## SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT :  
 SULFUR LOADING :

## ANALYSIS:

	BEFORE (FRESH)	AFTER INLET	EXIT
TOTAL SULFUR (W/W)	0.13	8.44	1.40
SURFACE AREA (M2/G)	3.13	1.16	1.35
DENSITY (G/CC)	6.16	4.91	5.25
PORE VOLUME (CC/G)	.00432	.00157	.001762
MINERAL ANALYSIS	2.6	0.8	0.7
ELEMENTAL ANALYSIS			
TOTAL CARBON (W/W)	0.00	0.04	0.04

## OPERATING CONDITIONS

TEMPERATURE : 1380 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

## DATA: ( DETECTOR TUBE )

EXIT H2S: 1 PPM FOR 1.5 HOURS

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLEX WET BASIS	MOLEX DRY BASIS
H2S	0.31 SCFH	1.0 %	1.2 %
H2O ( 6.2 SCFH)	2.22 CC/MIN	20.0 %	
AIR			
CO2	3.4 SCFH	11.0 %	13.7 %
CO	3.87 SCFH	12.5 %	15.5 %
H2	4.3 SCFH	13.8 %	17.2 %
CH4	0.20 SCFH	0.63 %	0.78 %
N2	12.82 SCFH	41.7 %	51.6 %
TOTAL FLOW :	31.07 SCFH		

## REMARKS

1. REACTOR BED HEIGHT 8 INCHES.
2. PROBLEM WITH T/C AT 6 INCHES FROM INLET READING TOO LOW.
3. CONDENSATE COLLECTED: 220 CC, 62% OF H2O FED AT INLET.

## CONCLUSIONS

1. PROBLEMS WITH TEMPERATURE CONTROL.
2. TEST TO BE REPEATED.

FIGURE 13

TEST SUMMARY SHEET  
HOT GAS DESULFURIZATION LAB SCALE TEST UNIT

TEST NO. : 010R  
 DATE STARTED : 08:45 6/12/84  
 DATE ENDED : 14:05 6/12/84  
 TOTAL HOURS : 5.33 HRS  
 TYPE : SULFIDATION

## PURPOSE

SULFIDE ZINC FERRITE (L1504) USING WESTINGHOUSE AIR BLOWN GAS COMPOSITION. THIS IS A REPEAT OF TEST 010 DUE TO THERMOCOUPLE PROBLEMS IN THAT TEST.

SORBENT TYPE/WEIGHT: ZINC FERRITE/715 GRAMS  
 SORBENT NO. : L-1504

SORBENT COMPOSITION:

SORBENT PELLET SIZE:  
 PRETREATMENT:  
 SULFUR LOADING :

## ANALYSIS:

	BEFORE (FRESH)	AFTER	INLET	EXIT
TOTAL SULFUR (XU/U):	0.31 / 3	18.42	1.00	
SURFACE AREA (M2/G):	3.13	0.9079	1.3030	
DENSITY (G/CC):	6.16	4.603	5.384	
PORE VOLUME (CC/G):	0.00432	0.001355	0.001891	
MINERAL ANALYSIS:		2.6	0.6	/
ELEMENTAL ANALYSIS:				
TOTAL CARBON (XU/U):	0.00	0.03	0.04	

## OPERATING CONDITIONS

TEMPERATURE: 1300 F

PRESSURE : 25 PSIG

SPACE VELOCITY: 2000

## DATA: ( DETECTOR TUBE )

EXIT H2S: 2 - 3 PPM FOR 5 HOURS.

EXIT SO2:

EXIT S2:

EXIT H2:

	FLOW RATE	MOLE%	MOLE%
		WET BASIS	DRY BASIS
H2S	0.31 SCFH	1.0 %	1.2 %
H2O ( 6.2 SCFH)	2.22 CC/MIN	20.0 %	
AIR			
CO2	3.4 SCFH	11.0 %	13.7 %
CO	3.87 SCFH	12.5 %	15.5 %
H2	4.3 SCFH	13.8 %	17.2 %
CH4	0.20 SCFH	0.63 %	0.78 %
N2	12.82 SCFH	41.7 %	51.6 %
TOTAL FLOW :	31.07 SCFH		

## REMARKS

1. REACTOR BED HEIGHT 8 INCHES.
2. REACTOR PRESSURE DROP INCREASED FROM 3.5 TO 5.9 INCHES.
3. H2 SHIFTED FROM 17.2 % TO 16.6 % AVG.
4. CO SHIFTED FROM 15.5 % TO 18.2 % AVG.
5. CO2 SHIFTED FROM 13.7 % TO 14.7 % AVG.
6. CONDENSATE COLLECTED: 485 CC, 69% OF H2O FED TO REACTOR.

## CONCLUSIONS

1. TIME TO BREAKTHROUGH IS SHORTER, AS EXPECTED.
2. NOT MUCH SHIFT CONVERSION.

FIGURE 14

ZINC FERRITE SULFIDATION  
LAB SCALE TEST UNIT TEST 001





FIGURE 15

# ZINC FERKITE SULFIDATION

LAB SCALE TEST UNIT TEST 003




14-SEP-84 14:55:28

Scanned  
09-09-2018  
9625

FIGURE 16

# ZINC FERRITE SULFIDATION

LAB SCALE TEST UNIT TEST 004




14-SEP-84 14:56:42

14-SEP-84  
14:56:42

FIGURE 17

# ZINC FERHITE SULFIDATION

LAB SCALE TEST UNIT TEST 005




14-SEP-84 14:35:04

02-03-84  
TEST 005  
ZFS

FIGURE 18

ZINC FERRITE SULFIDATION  
LAB SCALE TEST UNIT TEST 008




13-SEP-84 11:56:40

-6LL-

FIGURE 19

# ZINC FE RITE SULFIDATION

LAB SCALE TEST UNIT TESTS 003, 004, 005, 006



13-SEP-84 11:58:43

-08L-

FIGURE 20

## SULFUR ABSORPTION CAPACITY OF ZINC FERRITE





FIGURE 21

# ZINC FERITE SULFIDATION

LAB SCALE TEST UNIT TEST 007



-782-

14-SEP-84 14:58:28

FIGURE 22

# ZINC FERRITE SULFIDATION

LAB SCALE TEST UNIT TEST 008





FIGURE 23

# ZINC FERITE SULFIDATION

LAB SCALE TEST UNIT TEST 009



14-SEP-84 10:10:19

314

FIGURE 24

# ZINC FERRITE SULFIDATION

LAB SCALE TEST UNIT TEST 010R





FIGURE 25

# ZINC FERRITE SULFIDATION

LAB SCALE TESTS 007, 008, 009, 010R



## APPENDIX J

### Feasible Gasifiers Gas Stream Compositions for Use With METC's Zinc Ferrite Sulfur Removal Process in a Minimally Cleaned Gas, Combined-Cycle Plant Configuration

#### Objective/Summary

This report summarizes available information on the above topic, specifically with regard to the effect of fuel gas composition and temperature on the composition of the sorbent. The major species content of the fuel gas, i.e., carbon monoxide (CO), carbon dioxide, and water ( $H_2O$ ), affects sorbent composition and this fact may have significant implications on the operability of the zinc ferrite ( $ZnFe_2O_4$ ) hot-gas desulfurization process in the configuration used in the METC research program. However, there are uncertainties in much of the data leading to these conclusions. Design options exist which can address the operability concerns and which, as far as is known, do not lead to significant changes in the overall performance or cost of a minimally cleaned gas power generation plant. Both the system effects and the design options require further study.

This report (a) describes METC's research which led to identification of gas composition as a potential concern in zinc ferrite system operation; (b) examines the fuel gas from commercial or near-commercial gasifiers and gives an estimate of the degree of concern for these gasifiers; (c) describes potential changes in either the sorbent system design or the gasifier/fuel gas system to address the concern; and (d) enumerates the remaining uncertainties.


#### Problem Definition

In the zinc ferrite hot-gas desulfurization process, both the fuel gas composition and the process operating temperature affect sorbent composition. On the basis of results from the zinc ferrite research program currently underway at METC, i.e., a program conducted using 3/16-inch extruded pellets in a packed-bed configuration, the zinc ferrite process should operate at fuel gas stream conditions where magnetite ( $Fe_3O_4$ ) is the stable iron species. This stability region is shown in Figure 1, which is an iron/carbon/oxygen equilibrium diagram computed for atmospheric pressure. The figure is plotted in terms of temperature and the ratio of CO to  $CO_2$ , expressed as the equilibrium concentration of  $CO/(CO + CO_2)$ . At 1,000°F, a  $CO/(CO + CO_2)$  ratio of less than about 0.5 is required for the sorbent to be in the magnetite stable region of the equilibrium diagram. If the zinc ferrite system operates outside this region, species other than magnetite will be present in the absorption bed. These "other" iron species, i.e., iron/iron carbides and wustite ( $FeO$ ), have deleterious effects on the performance of the zinc ferrite process as tested in the METC configuration, i.e., an extruded sorbent in a packed bed.

Two possible options are available to overcome these problems. One option is to operate the gasification/fuel gas system in a way which will circumvent the formation of iron/iron carbides or wustite in the sorbent bed. A second option is to develop an alternate sorbent or sorbent system to negate the deleterious effects. A process development activity is needed to choose the best approach. METC will sponsor work with a FY 84 procurement now "on the

street" to address the research needed to better define the problem and provide a basis for further process development. Definitive phase equilibrium diagrams are one aspect of this research effort.

The unquenched fuel gas from an oxygen-blown dry ash Lurgi gasifier has a CO/(CO + CO<sub>2</sub>) ratio such that the zinc ferrite system will operate in the magnetite region of the equilibrium diagram. The unquenched fuel gas projected for the oxygen-blown commercial version of the Kellogg/Rust Westinghouse (KRW) gasifier is such that a zinc ferrite system which operates at 1,000°F and uses the METC process configuration will be on the borderline of the magnetite stable region. However, when treating unquenched fuel gas from either the BGC/Slagger or the oxygen-blown Texaco gasifier in a zinc ferrite process with the METC configuration, it will be necessary to increase the steam content of the fuel gas stream in order to move the system into the magnetite stable region. Increasing the steam content of the fuel gas reduces the amount of CO because of the CO shift conversion reaction,



The shift reaction is catalyzed by zinc ferrite so that equilibrium, or near equilibrium, should be achieved in the bed.

The following are possible options for increasing the steam content of the fuel gas:

1. Water quenching a high-temperature fuel gas stream (e.g., fuel gas from a KRW or Texaco gasifier).
2. Adding high-temperature steam to a lower temperature fuel gas stream (e.g., fuel gas from a BGC/Slagger).
3. Operating the gasifier at a higher steam-to-air ratio.

#### Effect of Increasing the Moisture Content of the Fuel Gas on System Performance

Although sulfur absorption is affected by the moisture content in the fuel gas, increasing the moisture content to the desired level would result in only a very slight decrease in the sulfur removal levels achievable in the zinc ferrite process. Sulfur concentrations as low as 5 ppm could be obtained in a fuel gas stream with the moisture content contemplated.

It was estimated that adding moisture to the fuel gas of a minimally cleaned gas system would have only a very small effect on overall cycle efficiency or system cost. However, the mass and energy balances for a process design in which moisture was added to the fuel gas would be different from those of a nonmoisturized design.

The addition of steam to the fuel gas would have some effect on the performance of the turbine combustor in a gasification combined-cycle plant. The additional steam would tend to reduce the thermal NO<sub>x</sub> formation in the gas turbine combustor but probably will have no effect on fuel-bound nitrogen NO<sub>x</sub> production (which apparently is the greater concern in minimally cleaned gas

systems). The additional steam would also affect the flammability characteristics of the gas. The steam reduces the heating value of the gas on a Btu/scf wet basis. This may be a concern with gasification systems which already produce a relatively low-heating value gas, e.g., air-blown fluidized-bed or entrained flow gasifiers. The CO shift reaction further reduces the lower heating value of the fuel gas, but the reaction also increases the hydrogen content of the gas. The General Electric water-cooled test program showed that the flammability characteristics of low-Btu fuel gas are sensitive to the hydrogen content of the gas, being improved by a higher hydrogen content.

#### Phase Equilibrium Diagram Data

Iron/carbon/oxygen phase equilibrium diagrams are widely available due to their connection with the steel making industry. Equilibrium diagrams are also used in connection with iron catalysts which are used in various chemical processes. Most of the diagrams for iron chemistry have been generated for atmospheric pressure, but similar effects are expected for zinc ferrite systems operating at pressure.

It is noted that the phase equilibrium diagram shown in Figure 1 does not take into account the presence of sulfur nor does it include the effect of reaction kinetics. The relative importance of omitting sulfur is unknown. However, one opinion is that it is minimal since, under gas compositions favoring iron/iron carbides formation, the sulfur would be absorbed in the reaction zone with the remainder of the bed converted to iron/iron carbides before the reaction zone approaches it.

Therefore, while there is some certainty as to the general trends shown in Figure 1, the application of the diagram should not be considered definitive in this early stage of the process design. There may be uncertainty as to the absolute location of specific phase separation boundaries, particularly when operating at pressure. More definitive phase equilibrium diagrams for the zinc ferrite system at the operating pressures of gasifiers/gas stream cleanup systems should be available within approximately one year. Responses to an RFP on this topic are currently being assessed at METC.

#### Validation of Phase Diagram Data at METC

Two data points on the phase diagram were confirmed for pressure operation during the zinc ferrite research program conducted using a side stream of METC's 42-inch fixed-bed gasifier. The first data point confirms that, for temperatures in the 1,000 to 1,100°F range, the METC zinc ferrite process typically operated in the iron/iron carbides stable region of the phase diagram. The presence of iron/iron carbides in the sorbent bed was first suspected during gasifier Run 102 (September 1983), and this was confirmed in post-test mineral analysis of the sorbent material. It is noted that even though the METC process was operating in the iron/iron carbides region, gas-phase sulfur levels on the order of 5 ppm were routinely achieved. The problem encountered was physical sorbent disintegration (discussed below).


An additional data point on the phase diagram was confirmed following gasifier Run 104 (December 1983). The zinc ferrite bed operated in the 1,200 to 1,300°F temperature range during this run, and wustite was found in the

sorbent material following the test. The phase diagram predicts wustite formation at this operating temperature.


The sorbent phase equilibrium results from the METC gasifier are not applicable to dry ash Lurgi gasifiers. The METC gasifier was operated at low steam-to-air ratios (approximately 0.2 wt./wt.), a large fraction of the heat liberated during the gasification process being removed from the gasifier by a water wall. A dry ash Lurgi has a significantly lower water wall surface-to-bed volume ratio. Thus the oxygen-blown Lurgi, which typically operates at a steam-to-air ratio of 0.5 wt./wt., produces a fuel gas with a higher steam content. With this fuel gas composition, the zinc ferrite process would operate in the magnetite stable region of the phase diagram.

#### Process Chemistry Specifics


When the zinc ferrite process operates in the magnetite region of the iron-carbon-oxygen equilibrium diagram, the chemical reactions taking place during sulfidation and regeneration may be represented as follows.



In the iron/iron carbides region of the phase diagram, the zinc chemistry is thought to be identical to that shown above. The overall iron chemistry during the sulfidation process may be represented as follows.



In the wustite stable region, the following iron reactions are thought to occur during the sulfidation process.



#### Concerns Over Operating Outside the Magnetite Stable Region

The data collected on the METC packed-bed zinc ferrite reactor indicate that the iron/iron carbides and the wustite stable regions should be avoided for the following reasons:

1. Reducing the iron oxide to elemental iron results in a porous sorbent pellet which is more prone to physical disintegration.

Based on experience with high-temperature shift catalysts (which are iron oxides and, therefore, similar to the zinc ferrite sorbent material), a life in excess of one year could reasonably be projected for the zinc ferrite sorbent. Circumstantial evidence during METC's zinc ferrite test program indicates that physical disintegration of the sorbent could lead to a significantly shorter sorbent lifetime under the adverse circumstances of excessive sorbent reduction and coke formation discussed in Item No. 2, below.

The following data gives some feel for the degree of sorbent disintegration experienced at METC. Following two separate zinc ferrite tests conducted during METC gasifier Run 102, the sorbent material was removed from the bed with a vacuum hose and screened. (These processes obviously involve the potential for generating additional fines.) The sorbent material from one test was subjected to two complete absorption and regeneration cycles prior to vacuuming/screening and was found to contain 2 percent fines. The sorbent from another test was subjected to one and one-half cycles (i.e., absorption, regeneration, and absorption). This second sorbent, which was vacuumed/screened in the sulfidized form, was found to contain 30 percent fines. Since the bed was operating in the iron/iron carbides stable region of the phase diagram in both these tests, it may be inferred that the presence of iron/iron carbides diminished the physical strength of the sorbent, leading to increased sorbent attrition. A substantially smaller amount of fines (about 10 percent) was generated in a third test during gasifier Run 101. In this case, the sorbent was in a sulfidized form and had been operating in the magnetite stable region immediately prior to removal from the reactor. Sorbent durability data will be obtained as a result of an RFP currently being assessed at METC. The aim of this project is to identify techniques to enhance zinc oxide based sorbent durability and to demonstrate sorbent durability for 100 absorption/regeneration cycles.

Problems associated with physical disintegration might be circumvented by using an inert solid material as a support for the active sorbent. The Institute Francais du Petrole has carried out extensive research along these lines for zinc oxide based sorbents. During the earlier iron oxide research, METC found supported sorbents to be as effective as pure iron oxide when normalized for iron content, and to have durability advantages over nonsupported sorbents. For a packed-bed zinc ferrite process, the use of a supported sorbent would be a tradeoff between the benefits of a more durable sorbent and the penalties associated with an increased reactor volume. (Sorbent utilization would be expected to be fairly high in a zinc ferrite process which operated in the magnetite stable region. In laboratory scale tests conducted at METC using simulated fuel gas containing sufficient steam to be in the magnetite stable region, the zinc ferrite bed absorbed on the order of 30 percent sulfur by weight or, very roughly, 90 percent of the theoretical amount of sulfur.) For a continuous zinc ferrite process design which used moving or fluidized-bed reactors, it may be that supported sorbents are a practical and/or necessary solution to the problems associated with sorbent

disintegration. However, it is too early in the zinc ferrite testing program to make definitive statements about either the optimum reactor configuration or sorbent form.

2. The presence of iron catalyzes the formation of coke both through the cracking of any tar that might be present in the fuel gas stream and through the Boudouard reaction:



Coke formation is undesirable because it reduces the heating value of the fuel gas stream and can contribute to sorbent disintegration.

Coke buildup may also contribute to increased pressure drops through a packed-bed absorber which could result in lifting of the sorbent in an upwards-flow reactor. (A fluidized-bed reactor design would obviate the pressure buildup problem.)

3. The presence of iron also catalyzes the very exothermic methanation reaction,



which could cause excessive temperatures in the sorbent bed.

In the METC tests, temperature excursions in the absorption bed were not a problem. The system operated with a gas composition which contained sufficient steam that significant methane formation would not be expected, even if the methanation reaction went to equilibrium. Also, the small scale of the reactor offered the opportunity for heat dissipation through the reactor walls.

4. Elemental iron further reacts to form iron carbides which are less reactive than magnetite. This limits the absorptive capabilities of the sorbent bed and  $\text{H}_2\text{S}$  breakthrough occurs earlier than it would if the bed were operating in the magnetite stable region. As a specific example, examination of sulfidized sorbent following one test conducted during METC gasifier Run 102 indicated that, at the inlet to the bed, approximately 1/2 of the iron was in the form of iron carbides. Proceeding into the bed, greater amounts of iron had been converted to iron carbides. From the middle of the bed to the outlet, virtually all of the iron was in the form of iron carbides. This indicates that, once the iron is converted to iron carbides, there is a significant fall in the rate of sulfur pickup. The overall sulfur loading of the sorbent was approximately 10 percent during this test.

During regeneration, the iron carbides participate in the steam-iron reaction with the consequent formation of hydrogen. This reaction results in a regeneration tail gas containing a variety of species:  $\text{H}_2$ ,  $\text{H}_2\text{S}$ ,  $\text{SO}_2$ , elemental sulfur, etc. Such a tail gas would need to be incinerated when using a sulfur recovery process which is designed to remove oxidized sulfur compounds. In the absence of iron/iron carbides,

the predominant species in the regeneration tail gas is expected to be sulfur dioxide ( $\text{SO}_2$ ) with minor amounts of sulfur trioxide ( $\text{SO}_3$ ).

A possible option is to treat the mixed composition tail gas stream by incinerating it and removing its sulfur content in a fluidized bed containing a throwaway, calcium-based sorbent material.

5. The wustite stable region of the phase diagram should also be avoided if very high sulfur removal is required. The absorptive powers of wustite are significantly lower than those of magnetite. For example, in a zinc ferrite test conducted during METC gasifier Run 104,  $\text{H}_2\text{S}$  levels in excess of roughly 100 ppm were observed almost immediately following the initiation of the absorption cycle. This test was conducted with bed temperatures of 1,200 to 1,300°F, and, therefore, the process was operating in the wustite stable region of the phase diagram. It is possible that the presence of wustite in the sorbent structure makes the zinc oxide less accessible.

#### System Implications for the BGC/Slagger/Zinc Ferrite System

The BGC/Slagger exit gas composition is well into the iron/iron carbides stable region of the phase diagram. Therefore, some modification to the fuel gas is required when operating with the METC zinc ferrite configuration. It was calculated that adding 20 vol. percent (based on the total gas flow) of steam to the fuel gas would move the phase equilibrium to the boundary of the magnetite stable region. Reference 1 was used as a source for the raw fuel gas composition for these calculations. The  $\text{CO}/(\text{CO} + \text{CO}_2)$  ratio was determined at shift equilibrium. The shift equilibrium was recalculated following the injection of the additional steam. Adding an additional 5 vol. percent of steam would increase the margin of safety and move the system away from the uncertain boundary area.

Steam to moisturize the fuel gas could be obtained from the heat recovery steam generator. Adding steam to the gasifier exit gas (typically at temperatures in the 800 to 850°F range) would raise the gas stream temperature through the heat released in the exothermic CO shift conversion reaction. Each 1 percent of CO converted would raise the gas stream temperature roughly 18°F. Therefore, adding 20 mole percent of 640°F steam to the fuel gas could be used to increase the gas stream temperature to approximately 1,000°F. This temperature increase for the fuel gas stream is desirable because it diminishes the possibility of tar condensation in the cleanup system.

The presence of a catalyst is apparently required for the shift reaction to proceed at temperatures below 1,200°F. While detailed homogeneous kinetic rate data for the shift reaction have not been located, Reference 2 indicates that the extent of conversion is not significant without catalysis at temperatures below 1,200°F. The CO shift conversion reaction is expected to go to virtual equilibrium in the relatively low-temperature BGC/Slagger fuel gas stream because of catalysis by the sorbent.

It appears more feasible to add steam to the fuel gas at the gasifier exit than to perturb the gasifier operation. Increasing the steam-to-air ratio in the gasifier could be used to increase the moisture level in the fuel gas but

it would have significant effects on the operation of the gasifier. Specifically, it might cause the gasifier to operate in a dry ash mode. Increasing the steam feed to the gasifier would also increase the superficial velocity through the gasifier. Higher velocities may not be acceptable from an operational standpoint since they could lead to channeling in the bed and/or greater fine carryover. The additional steam may also negate the greater throughput advantage of the BGC/Slagger over the dry ash Lurgi. These comments are speculations on which opinions should be sought from industrial sources.

#### System Implications for the KRW Gasifier/Zinc Ferrite System

The fuel gas produced in the KRW process demonstration unit (PDU) is such that the equilibrium is well into the magnetite region of the phase diagram. (In the PDU, KRW partially quenches the gas to avoid deposition problems in the cyclones.) With the fuel gas composition projected for a commercial oxygen-blown version of the KRW gasifier (Reference 1), the CO/CO<sub>2</sub> ratio is such that the system would be on the boundary of the magnetite stable region at 1,000°F if the gas were cooled from gasifier operating temperatures without the addition of water. Thus, a conservative design would inject a small amount, 5 vol. percent of total gas flow, of water into the fuel gas stream.

Adding a small amount of water to the approximately 1,800 to 1,900°F fuel gas stream should not present any major design problems. However, there may be some difficulty in controlling the water quench flow rate, such that the desired fuel gas temperature is obtained. In a commercial design, either of two methods could be used to cool and add the required moisture to the fuel gas. In one method, all the high-temperature heat exchangers would be eliminated, and the fuel-gas stream temperature would be lowered from the 1,800 to 1,900°F range to the operating temperature of the zinc ferrite system, by using a water quench. (This approach would significantly increase the steam content of the fuel gas above the requirements of the zinc ferrite process.) Alternatively, a partial quench to achieve the desired fuel-gas moisture content could be employed at some point in the temperature reduction process. Radiant and/or convective heat exchangers would be used to complete the temperature reduction.

#### System Implications for a Texaco Gasifier/Zinc Ferrite System

The fuel gas from a Texaco gasifier (Reference 1) would require injection of approximately 10 vol. percent of water for the system to reach the boundary of the magnetite stable region on the phase diagram at 1,000°F. A 15 percent water injection rate would be a conservative design. The considerations in adding water to the Texaco gasifier are similar to those discussed above for the KRW gasifier.

#### Inlet Particulate Limitations for the Zinc Ferrite Process

The METC zinc ferrite reactor operates with acceptable reactor pressure drops, with an inlet particulate loading of 1 g/Nm<sup>3</sup>, and a median particle size of approximately 13 microns. Zinc ferrite systems which use packed-bed reactors to treat fuel gases which have particulate loadings with parameters exceeding

to treat fuel gases which have particulate loadings with parameters exceeding these values may require the use of some particulate removal device prior to the absorption bed.

Zinc ferrite pellets larger than the 3/16-inch diameter extrusion size presently used in the METC test program may be helpful in avoiding bed blinding problems in packed-bed reactors by providing larger interstitial spaces. Granular-bed filter theory predicts that larger spaces would increase the allowable particle size in the inlet stream to the bed. A pellet diameter of 5/16 inch may be the maximum size that would still allow adequate sulfur diffusion into the sorbent.

Other reactor designs, e.g., a fluidized-bed reactor, could bypass any problems of blinding by particulates. Alternatively, sulfur capture and particulate control could be combined in a granular-bed filter arrangement. Improvements in sorbent strength beyond that of the METC extrudate would be needed to go these routes. Development of sorbents to address such reactor design considerations has not been part of the research program at METC.

#### Conclusion

On the basis of experimental results and economic assessments completed to date, the METC configuration of the zinc ferrite process appears to be an attractive process for hot gas cleanup. Fuel gas composition requirements do not seem to present roadblocks to its systems applications. However, the process is in its early stages of development. Other hot-gas desulfurization sorbents, pellet forms, and/or reactor configurations may also be viable options for the desulfurization of fuel gas in minimally cleaned gas, combined-cycle plants.


#### Acknowledgements

L. C. Headley, J. S. Halow, V. P. Kothari, J. M. Thames, J. E. Notestein, and L. E. Graham participated in discussions, contributed information, and provided reviews of draft versions of this report. Their contributions are gratefully acknowledged.

#### References

1. Synthetic Fuels Associates, Inc., "Coal Gasification Systems: A Guide to Status, Applications, and Economics," EPRI AP-3109, June 1983.
2. Johnson, J. L., "Kinetics of Coal Gasification," Wiley-Interscience Publications, 1979.
3. Gieger, G. H., "Iron Blast Furnace," paper in Metallurgical Treatises, presentations at the USA-China Bilateral Conference sponsored by the Metallurgical Society of AIME, American Society for Metals, and the Chinese Society for Metals, Beijing, China, November 1981.

June 1950  
100-02-37



adapted from Geiger

A-84-717-01

FIGURE 1. Iron-Carbon-Oxygen Equilibrium Diagram at Atmospheric Pressure