FOSSIL POWER SYSTEMS

RESEARCH & DEVELOPMENT

COMBUSTION ENGINEERING

DOE/PC/90275--T18

DE92 004972

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY

COAL COMBUSTOR FOR BOILER RETROFIT

TASK 3: DEMONSTRATION SCALE TESTING

AT 50×10^6 BTU/HR

FINAL REPORT

Received by OSTI
OCT 09 1990

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY
COAL COMBUSTOR FOR BOILER RETROFIT

TASK 3: DEMONSTRATION SCALE TESTING AT 50×10^6 BTU/HR
FINAL REPORT

Prepared by

COMBUSTION ENGINEERING, INC.
WINDSOR, CONNECTICUT 06095

APRIL 1989

Project Manager

Michael J. Rini

Principal Investigators

R.C. LaFlesh
M.J. Rini
J.G. McGowan

Prepared for

U.S. DEPARTMENT OF ENERGY
PITTSBURGH TECHNOLOGY CENTER

UNDER CONTRACT NO. DE-AC 22-86PC 90275

DISCLAIMER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PATENT STATUS

This technical report is being transmitted in advance of DOE patent clearance and no further dissemination or publication shall be made of the report without prior approval of the DOE Patent counsel.

TECHNICAL STATUS

This technical report is being transmitted in advance of DOE review and no further dissemination or publication shall be made of the report without prior approval of the DOE Project/Program Manager.

EXECUTIVE SUMMARY

Since the oil embargo of 1974, there has been a major effort to develop energy systems that are not dependent on petroleum-based fuels. The Pittsburgh Energy Technology Center (PETC) of the U.S. Department of Energy (DOE) has directed a number of programs toward increasing both coal usage in existing markets and introducing new premium quality coal-based fuels to markets currently dependent on oil or natural gas. In the American industrial sector, a significant portion of the total boiler capacity in operation in the year 2000 is expected to be composed largely of pre-1980 units. Any substantial near term increase in the use of coal for raising industrial steam will, therefore, have to be accomplished through conversion of existing boilers currently fired by natural gas or oil.

The application of coal or coal-based fuels to industrial boilers originally designed for gas or oil firing presents several technical challenges to the combustion engineer. Specifically, constraints such as carbon conversion efficiency, emissions control, and coal and ash handling must be addressed and resolved. To enable these conversions, significant effort has been made in the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (CE) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE later awarded a contract to the CE/MIT team to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program.

The objective of the program was to develop an advanced coal combustion system for firing beneficiated coal fuels (BCFs) capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. A systematic development program was then conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve these goals. Under Task 1.0,

innovative burner components were developed and integrated into an advanced design burner system for the Pilot-Scale Testing (Task 2.0) and Demonstration-Scale Testing (Task 3.0). Separate reports have been issued for both Tasks 1.0 and 2.0. This report details the work carried out under Task 3.0, "Demonstration-Scale Testing at 50×10^6 Btu/hr" conducted at CE's Kreisinger Development Laboratory in Windsor, CT.

The Demonstration-Scale tests were conducted in two major test series. The first utilized coal-water fuels (CWFs) in three forms: a microfine grind (9μ MMD), a fine grind (21μ MMD), and a fine grind with two different alkali sorbents (calcium hydroxide and calcium acetate) added for SO_2 capture. The second series of tests utilized a fine grind, dry pulverized coal of 21 micron MMD. This coal was prepulverized, stored in a coal silo, and pneumatically injected into the HEACC via a dense phase transport system.

The results of the CWF tests showed:

- The furnace opening required for the HEACC matched that of a comparable industrial oil burner- this would facilitate boiler retrofit.
- High carbon conversion efficiencies ($> 98.0\%$) could be achieved at excess air levels of 30-35%.
- NO_x could be reduced from over 700 ppm to below 475 ppm, but at the expense of reduced carbon conversion.
- Sulfur capture rates with the sorbent-containing CWFs were lower by a factor of approximately two than those measured in the Pilot-Scale tests.

The results of the pulverized coal tests showed :

- Carbon conversion efficiencies of greater than 98.5% could be obtained at excess air levels of 15 to 25%.
- NO_x emissions could be controlled to below 390 ppm while maintaining high carbon conversion efficiencies of generally greater than 98.5%.
- The use of stored pulverized coal and dense phase pneumatic transport to the burner was successfully demonstrated. This could be an important method of implementing BCF use in industrial oil replacement applications.

In summary, this program produced an advanced coal firing system that was capable of firing both water-based and dry pulverized forms of BCFs in an industrial boiler environment. The HEACC could be adapted to a long term field program in a commercially operating unit. The optimum configuration for this would employ the HEACC firing either a dry beneficiated coal product using a dense phase storage and transport system or a beneficiated CWF. This long term operation would clearly be another important step in the Department of Energy's stated goal of energy independence for our nation.

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction	12
2.0 Task 3.1 Test Facility Preparation	15
2.1 Test Facility	15
2.2 Fuel Supply	15
2.2.1 Coal/ Water Fuels	15
2.2.2 Pulverized Coal Fuels	22
3.0 Task 3.2 Combustion Testing	24
3.1 CWF Firing	29
3.1.1 Scope of Experimental Tests	29
3.1.2 Detailed Experimental Results	36
3.2 Pulverized Coal Firing	64
3.2.1 Scope of Experimental Results	64
3.2.2 Detailed Experimental Results	71
4.0 Summary/ Conclusions	83
5.0 References	85

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
1.1 Program Outline- "Development of a High Efficiency Advanced Coal Combustor"	13
2.1 Summary of CWF Test Fuel Analysis	21
2.2 Analysis of Pulverized Test Coal	23
3.1 Test Matrix No. 1	30
3.2 Test Matrix No. 2	31
3.3 Test Matrix No. 3	32
3.4 Summary of CWF Tests	38
3.5 Summary of Test Operating Conditions	39
3.6 Summary of CWF Test Results	44
3.7 Results of Sorbent Injection Tests	59
3.8 PC Firing Test: Free Vortex Swirler- Matrix No. 1	65
3.9 PC Firing Test: Forced Vortex Swirler- Matrix No. 2	66
3.10 Summary of PC Firing Tests- Free Vortex Swirler- Matrix No. 1	72
3.11 Summary of PC Firing Tests- Forced Vortex Swirler- Matrix No. 2	73

LIST OF FIGURES

<u>FIGURE</u>	<u>PAGE</u>
2.1 Schematic of ISBF	16
2.2 Particle Size Distribution of Fine Grind CWF	18
2.3 Particle Size Distribution of Ultrafine CWF	19
2.4 Schematic of Sorbent Injection System	20
3.1 Schematic of HEACC Demonstration- Scale Burner	25
3.2 HEACC Prior to Installation in Test Facility	26
3.3 HEACC Prior to Installation in Test Facility	26
3.4 HEACC Burner Installation with CWF Gun in Place	27
3.5 Swirler Tangential Velocity Profiles	28
3.6 Schematic of Y- Jet Atomizer Design	33
3.7 CWF Atomizer and Forced Vortex Swirler Installed in HEACC	35
3.8 Carbon Conversion Efficiency vs. Excess Air, Comparison of 4 Atomizers (Test Points 1- 8A), Forced Vortex Swirler, Baseline Fine CWF	48
3.9 Carbon Conversion vs. Excess Air, 8 Cell Atomizer (Test Points 9-13), Unstabilized Fine Grind CWF	48

3.10	NO _x Emissions vs. Excess Air, 8 Cell Atomizer (Test Points 9-13), Unstabilized Fine Grind	49
3.11	NO _x Emissions vs. PAF, 8 Cell Atomizer, Forced Vortex Swirler(Test Points 9- 13), Unstabilized Fine Grind	49
3.12	Carbon Conversion vs. PAF (Test Points 15-19) 8 Cell Atomizer, 30% Excess Air, Diluted Baseline Ultrafine	51
3.13	NO _x vs. PAF (Test Points 15-19), 8 Cell Atomizer, 30% Excess Air, Diluted Baseline Ultrafine	51
3.14	Effect of Solids Content on Carbon Conversion Efficiency 8 Cell Atomizer, Forced Vortex Swirler, 34% Excess Air, Diluted Baseline Ultrafine, PAF = 0.5 (Test Points 19 & 20)	52
3.15	Carbon Conversion vs. Primary Air Fraction, 25° Tip, Forced Vortex Swirler, 25% Excess Air, Slightly Stabilized Fine Grind (Test Points 21-23)	52
3.16	Carbon Conversion vs. Primary Air Fraction, 8 Cell Tip, Forced Vortex Swirler, 35% Excess Air, Slightly Stabilized Fine Grind (Test Points 24-27)	53
3.17	Carbon Conversion vs. Excess Air, Effect of Fuel Type, Forced Vortex Swirler, PAF = 0.35	53
3.18	Carbon Conversion Efficiency vs. Excess Air, Comparison of CWF Fuels, 8 Cell Tip, Forced Vortex Swirler	55
3.19	Carbon Conversion Efficiency vs Excess Air, 8 Cell Tip, Forced Vortex Swirler, Unstabilized Ultrafine (Test Points 36-38)	55

3.20	Carbon Conversion vs. Excess Air, Fine Grind (Test Points 39-51)	57
3.21	NO _x Emissions vs Excess Air, Fine Grind (Test Points 39-51)	57
3.22	Carbon Conversion Efficiency vs. PAF, 8 Cell Tip, Forced Vortex Swirler, 22% Excess Air, Fine Grind (Test Points 52-56)	58
3.23	NO _x Emissions vs. Primary Air Fraction, 8 Cell Tip, Forced Vortex Swirler, 22% Excess Air, Fine Grind (Test Points 52-56)	58
3.24	Schematic of Sorbent Injection System	61
3.25	Sulfur Capture Efficiency vs. Ca/S Ratio, CE Test Points 58-63	62
3.26	Schematic of Fuel Injectors	67
3.27	Staggered Burner Configuration	69
3.28	Telescoped Burner Configuration	69
3.29	Carbon Conversion vs. Excess Air, PC Firing Tests- No. 101-120, Free Vortex Swirler- 100% Load	74
3.30	Carbon Conversion vs. Excess Air, PC Firing Tests- No. 201-215, Forced Vortex Swirler- 100% Load	74
3.31	NO _x Emissions vs. Excess Air, Primary Air Fraction = 0.3	75

3.31A Swirler Pressure Drop vs. Airflow	77
3.32 NO _x Emissions vs Primary Air Fraction, Excess Air = 20%, Free Vortex Swirler, I-Jet Injector	78
3.33 NO _x Emissions vs. Primary Air Fraction, Excess Air = 15%, Forced Vortex Swirler, I-Jet Injector	78
3.34 NO _x Emissions vs. Primary Air Fraction, Excess Air = 20%, Forced Vortex Swirler, I-Jet Injector	79
3.35 NO _x Emissions vs. Excess Air, Free Vortex Swirler, 30 Deg. Cone Injector, Varying Primary Air Fraction	80
3.36 NO _x Emissions vs. Excess Air, Free Vortex Swirler, 30 Deg. Conical Injector, PAF = 0.30, Effect of Telescoped Geometry	80
3.37 Carbon Conversion vs. Excess Air, 60% Load, Forced Vortex Swirler, I-Jet Injector	82
3.38 NO _x Emissions vs Excess Air, 60% Load, Forced Vortex Swirler, I-Jet Injector	82

1.0 INTRODUCTION

Since the Oil embargo of 1974, there has been a major effort to develop energy systems that are not dependent on petroleum-based fuels. In the United States, with the world's most abundant coal resources, much of this effort has been focused on the expanded use of coal-based fuels by the industrial and utility sectors. The United States Department of Energy has been the leader in fostering this work. Significant progress has been made during the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced coal combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (C-E) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE awarded to C-E and MIT a contract to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program.

The objective of this program is to develop an advanced coal-combustion system capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. Through the use of beneficiated coal fuel and advanced combustion technology, the program was to produce a combustion system which is reliable, simple to operate, and incorporates significant reductions in NO_x , SO_x , and particulate emissions over a base coal case.

A systematic program was conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve this goal. An outline of the program conducted is given in Table 1.1. Task 1.0 was completed and developed the components needed for Tasks 2.0 and 3.0. Separate reports have been issued for both Tasks 1.0 and 2.0 (Rini (1989) and Toqan (1989)). This report details the work carried out under Task 3.0, "Demonstration- Scale Testing at 50×10^6 Btu/hr."

TASK 1.0 COLD FLOW BURNER DEVELOPMENT

- 1.1 Program Planning
- 1.2 Cold Flow Swirler Development
- 1.3 Scale Up Criteria Development
- 1.4 Task 1 Report

TASK 2.0 PILOT SCALE TESTING AT MIT

- 2.1 Test Facility Preparation
- 2.2 Atomization Testing
- 2.3 Combustion Testing at 5×10^6 Btu/hr
- 2.4 Clean Up and Waste Disposal
- 2.5 Task 2 Report

TASK 3.0 DEMONSTRATION TESTING AT C-E

- 3.1 Test Facility Preparation
- 3.2 Combustion Testing at 50×10^6 Btu/hr
- 3.3 Clean Up and Waste Disposal
- 3.4 Task 3 Report

TASK 4.0 PROJECT FINAL REPORT

- 4.1 Data Analysis
- 4.2 Final Report

TASK 5.0 OVERALL PROJECT MANAGEMENT

- 5.1 Project Management

Table 1.1 Program Outline
"Development of a High Efficiency Advanced Coal Combustor"

The objective of this task was to demonstrate the operation of a combustion system at a scale representative of a typical industrial boiler retrofit. A scale of 50×10^6 Btu/hr was selected to meet this requirement. As will be described in detail in the following sections, the testing was carried out in Combustion Engineering's Industrial-Scale Burner Facility (ISBF) located at the Kriesinger Development Laboratory (KDL) in Windsor, Connecticut.

2.0 TASK 3.1 TEST FACILITY PREPARATION

2.1 TEST FACILITY

Under this subtask, the burner system designed under subtask 1.4 was fabricated at a scale of 50×10^6 Btu/hr and installed in the Industrial-Scale Burner Facility (ISBF). It should be noted that this experimental facility is the same one used for previous Department of Energy sponsored research on Coal/Water fuels (LaFlesh, et al., 1985).

The Industrial Scale Burner Facility accurately models the time- temperature history of a typical industrial boiler. The ISBF is shown in cross section in Figure 2.1. At the demonstration-scale firing rate of 50×10^6 the volumetric heat release rate is approximately $30,000 \text{ Btu/hr-ft}^3$ which is representative of a large scale industrial waterwall steam generator. For the work carried out during this test program, furnace refractory blanket insulation was installed to maintain representative furnace outlet temperatures as well as to attempt to duplicate the time-temperature profiles in an operational boiler.

2.2 FUEL SUPPLY

For the series of experiments carried out under this test program, both CWF and pulverized coal fuels were used. The coal used for both forms of the fuel supply was an Elkhorn Seam (Westmoreland Coal Co.) coal provided via Energy International. The coal had an inherently low ash level and, with washing, exhibited 2.5 to 3.0% ash. The same coal was used both for producing the coal- water fuels and the pulverized coals to provide directly comparable data. Details of the preparation are described in the work of Maxwell, et al. (1989). Summary details of the different fuels follow:

2.2.1 Coal-Water Fuels

Three types of CWFs were used during the CWF test series. These fuels were

FIGURE 2.1 SCHEMATIC OF ISBF

supplied by the OXCE Fuel Company via Energy International. They included:

1) Fine grind CWF

The size composition of this fuel is typical of CWF that OXCE has supplied to several DOE programs and several commercial demonstrations (LaFlesh, et al., 1985 and Whaley, et al., 1986). With a MMD of 21 microns, this fuel represents a CWF that could potentially be used in the more generously sized furnaces of industrial and small scale utility boilers. This CWF is a considerably finer grind than standard pulverized coal which has a MMD of 55- 60 microns. Figure 2.2 gives the particle size distribution of this fuel.

2) Ultrafine CWF

With a MMD of 9 microns, this CWF represents a potential fuel for boilers with limited residence time such as tightly designed oil-fired boilers and all natural gas fired units. The key to exploiting the ultrafine CWF lies in achieving very high quality atomization in order to complete fuel burnout within a small furnace volume. Figure 2.3 presents the particle size distribution of the ultrafine CWF fuel.

3) Sorbent CWF

In an effort to reduce SO_2 emissions, two CWFs were used which contained a sulfur sorbent. Two classes of sorbent were used: solid particles of calcium hydroxide $[\text{Ca}(\text{OH})_2]$ and water soluble calcium acetate $[\text{Ca}(\text{C}_2\text{H}_3\text{O}_2)_2]$.

These sorbents were first premixed with water and then admixed with the fine grind CWF in the fuel piping just prior to combustion. This system is shown schematically in Figure 2.4. The nature of the sorbent (soluble vs. insoluble) proved to be of significance in sulfur capture ability, as will be discussed in Section 3.1.2.

Table 2.1 gives a summary of the fuel analysis for the CWFs used during the tests.

FIGURE 2.2 PARTICLE SIZE DISTRIBUTION OF FINE GRIND CWF

FIGURE 2.3 PARTICLE SIZE DISTRIBUTION OF ULTRAFINE CWF

FIGURE 2.4 SCHEMATIC OF SORBENT INJECTION SYSTEM

TEST NUMBERS	MOISTURE	% BY WEIGHT AS FIRED				NITROGEN	OXYGEN	ASH	HHV (BTU/LB)
		HYDROGEN	CARBON	SULFUR					
1-14	36.20	3.30	52.20	0.50		1.00	5.10	1.70	9135
15-19	39.53	3.10	49.40	0.48		1.03	4.83	1.63	8653
20	40.95	3.10	48.20	0.47		1.00	5.32	0.96	8450
21-27	36.10	3.30	52.20	0.50		1.10	5.10	1.70	9144
28-34	40.40	3.10	48.70	0.50		1.00	4.70	1.60	8529
35-38	41.80	3.00	47.50	0.50		1.00	4.60	1.60	8328
39-57	34.50	3.40	53.50	0.50		1.10	5.20	1.80	9373
58	40.80	3.10	48.50	0.50		1.10	4.30	1.70	8490
59	36.50	3.30	52.00	0.51		1.08	4.81	1.80	9106
60	36.10	3.30	52.30	0.51		1.08	4.92	1.79	9163
61	40.80	3.10	48.50	0.50		1.10	4.30	1.70	8490
62	38.20	3.20	50.60	0.50		1.05	4.73	1.73	8862
63	36.80	3.20	51.80	0.51		1.07	4.75	1.77	9063
64-65	34.50	3.40	53.50	0.50		1.10	5.20	1.80	9373

TABLE 2.1 SUMMARY OF CWF TEST FUEL ANALYSES

2.2.2 Pulverized Coal Fuels

The coal used for the pulverized coal portion of the tests was the same Elkhorn Seam as was used for the CWFs. The coal was pulverized to a MMD of 21 microns in a standard Combustion Engineering bowl mill. This level of fineness duplicated the size distribution of the "fine grind" CWF utilized in this task and at MIT in Task 2.0. This was done to facilitate comparisons between wet and dry fuels. This grind is considerably finer than conventional pulverized coal (MMD = 55-60 microns), but was achieved using standard grind milling equipment. This is significant because it demonstrated that "semi-micronized" coal fineness could be obtained without the use of special equipment.

The as-fired analysis of the pulverized coal is shown in Table 2.2.

COAL: Elkhorn Seam- Westmoreland Coal Company

As- Fired Sample

PROXIMATE ANALYSIS (WT. PERCENT)

MOISTURE (TOTAL)	1.1
VOLATILE MATTER	35.2
FIXED CARBON (DIFF)	60.2
ASH	<u>3.5</u>
TOTAL	100.0

HHV, BTU/ LB 14,315

LB ASH/ MM BTU 2.4

ULTIMATE ANALYSIS (WT. PERCENT)

MOISTURE (TOTAL)	1.1
HYDROGEN	5.1
CARBON	81.8
SULFUR	0.5
NITROGEN	1.4
OXYGEN (DIFF)	6.6
ASH	<u>3.5</u>
TOTAL	100.0

TABLE 2.2 ANALYSIS OF PULVERIZED TEST COAL

3.0 TASK 3.2 COMBUSTION TESTING

As a result of the findings of the Cold Flow Burner Development (Task 1.0) and the Pilot-Scale Testing at MIT (Task 2.0), a demonstration-scale HEACC was designed by Combustion Engineering. A schematic of the burner is shown in Figure 3.1. This burner incorporates the following design features:

- 1) Measured and controllable primary airflow.
- 2) Coaxial construction with 2 axially adjustable secondary air rings.
- 3) Distributed secondary air via perforated plate.
- 4) Adjustable direction tertiary air swirler.
- 5) Non-refractory burner exit nozzle (quarl).
- 6) Ability to install either a CWF gun or pulverized coal nozzle without burner modification.
- 7) Burner envelope to match a standard oil burner opening.

The HEACC was constructed under Combustion Engineering's supervision and is shown in Figures 3.2 and 3.3 just prior to installation in the test facility. Figure 3.4 shows the burner installation with a CWF gun in place. The primary air venturi tube is located in the insulated duct on the right side of the photograph.

A key component of the combustor is the primary air swirler developed under the work of Task 1.0. Two groups of swirlers were developed each producing a different vortex, either free or forced vortex types (shown schematically in Figure 3.5). The free vortex type is characterized by a maximum velocity at the swirler hub and the forced vortex is characterized by a maximum velocity at the outer diameter of the swirler. As previously reported in the Task 1.0 work, the most efficient examples of each type were determined, and then selected for the Task 3.0 work.

Under this subtask, for each of the fuels selected, a similar matrix of tests were conducted to quantify the performance of each fuel in the commercial firing system. Details of the two test series follow.

FIGURE 3.1 SCHEMATIC OF HEACC DEMONSTRATION-SCALE BURNER

FIGURE 3.2, FIGURE 3.3 HEACC PRIOR TO INSTALLATION IN TEST FACILITY

FIGURE 3.4 HEACC BURNER INSTALLATION WITH CWF GUN IN PLACE

FREE VORTEX

$$W = \frac{\text{CONSTANT}}{R}$$

FORCED VORTEX

$$W = (\text{CONSTANT}) R$$

FIGURE 3.5 SWIRLER TANGENTIAL VELOCITY PROFILES

3.1 CWF FIRING

3.1.1 Scope of Experimental Tests

Under the original scope of the experimental test program, three combustion test matrices were developed for the CWF portion of the HEACC Demonstration Scale tests. The scope of this series of tests is summarized in Tables 3.1 to 3.3. The objective of this program was to systematically optimize and document the combustion performance of the HEACC (using CWF fuels). As shown in Table 3.1, in Matrix 1, an evaluation of the performance of four different atomizer configurations was planned. This approach was used to determine the best atomizer for further testing.

The four styles of atomizers were variations of Combustion Engineering's commercial CWF multi-cell "Y" Jet atomizer. The development of this atomizer was initiated in 1982 to support an EPRI funded program to develop CWF burner technology (Borio, et al., 1984). C-E chose a Y-jet, twin fluid atomizer for CWF applications. The reasons for this choice included extensive experience with this atomizer design when applied to fuel oils, acceptable performance under turndown conditions, and the relatively simple fuel flow path in a Y-jet. It was concluded that a simple, non-tortuous path would result in longer atomizer life and lower atomizer fuel and atomizing pressure requirements. Figure 3.6 presents a schematic of a CE Y-jet atomizer design. Based on the success of the initial CE/ EPRI CWF program, Combustion Engineering has further refined the design of the Y-jet CWF atomizer through extensive laboratory development and testing.

Atomizer life was one of the early concerns that faced the initial designers of CWF firing systems. That is, using prototype Y-jet atomizers made from carbon steel often resulted in severe atomizer wear after four to eight hours of operation. The relative simplicity of the Y-jet atomizer has facilitated the strategic use of tungsten carbide inserts in the normally high wear areas, namely the mixing chambers and outlet orifices. This design advantage is also shown in Figure 3.6.

TEST MATRIX 1- PARAMETRIC TEST MATRIX

OBJECTIVE: DETERMINE THE PERFORMANCE OF THE FOUR ATOMIZER DESIGNS SELECTED FOR TESTING AGAINST TWO DIFFERENT SWIRLER DESIGNS

ATOMIZERS:

- a) 7 - 7 MBtu cells, 25° Spray angle
- b) 7 - 7 MBtu cells, 45° Spray angle
- c) 8 - 7 MBtu cells, 4 on 55° Spray angle
4 on 30° Spray angle
- d) 10 cells: 5 - 3.5 MBtu cells on 50° Spray angle
5 - 7 MBtu cells on 30° Spray angle

SWIRLERS:

- a) Forced Vortex
- b) Free Vortex

COMBUSTION AIR TEMPERATURE - 500 °F

<u>% LOAD</u>	<u>% EXCESS AIR</u>	<u>PRIMARY AIR</u> (% Stoichiometric)	<u>ATOMIZER</u>	<u>SWIRLER</u>
100	25	35	a	Forced
100	25	35	b	Forced
100	25	35	c	Forced
100	25	35	d	Forced
100	25	35	a	Free
100	25	35	b	Free
100	25	35	c	Free
100	25	35	d	Free

TABLE 3.1 TEST MATRIX NO. 1

TEST MATRIX 2- BURNER PERFORMANCE CHARACTERIZATION

(Combustion Air Temperature- 500 °F)

NO.	%LOAD	<u>EXCESS</u>	<u>PRIMARY</u>	<u>ATOMIZER</u>	<u>SWIRLER</u>	<u>GAS</u>	<u>FOT</u>	<u>HEAT</u>	<u>STAGING</u>
		<u>AIR. %</u>	<u>AIR</u>			<u>ANALYSIS</u>		<u>FLUX</u>	
1	100	30	A	OPT	OPT	YES	YES	YES	NO
2	100	20	A	OPT	OPT	YES	YES	YES	NO
3	100	MIN	A	OPT	OPT	YES	YES	YES	NO
4	100	20	B	OPT	OPT	YES	YES	YES	NO
5	100	20	C	OPT	OPT	YES	YES	YES	NO
6	50	OPT	D	OPT	OPT	YES	YES	YES	NO
7	50	OPT	D	OPT	OPT	YES	YES	YES	NO
8	50	OPT	E	OPT	OPT	YES	YES	YES	NO
9	50	OPT	E	OPT	OPT	YES	YES	YES	NO
10	MIN	OPT	F	OPT	OPT	YES	YES	YES	NO
11	MIN	OPT	F	OPT	OPT	YES	YES	YES	NO
12	100	30	OPT	OPT	OPT	YES	YES	YES	YES-G
13	100	20	OPT	OPT	OPT	YES	YES	YES	YES-G
14	100	MIN	OPT	OPT	OPT	YES	YES	YES	YES-G
15	100	30	OPT	OPT	OPT	YES	YES	YES	YES-H
16	100	20	OPT	OPT	OPT	YES	YES	YES	YES-H
17	100	MIN	OPT	OPT	OPT	YES	YES	YES	YES-H

A = Design Primary Air

B = Design Primary Air + 10%

C = Design Primary Air - 10%

D,E,F = To be Determined

G = Staging Configuration 1

H = Staging Configuration 2

TABLE 3.2 TEST MATRIX NO. 2

TEST MATRIX 3- OPTIMUM BURNER PERFORMANCE WITH SORBENT INJECTION

(Combustion Air Temperature- 500 °F)

<u>NO.</u>	<u>%LOAD</u>	<u>EXCESS</u>	<u>PRIMARY</u>	<u>ATOMIZER</u>	<u>SWIRLER</u>	<u>GAS</u>	<u>STAGING</u>	<u>SORBENT</u>
		<u>AIR.%</u>	<u>AIR</u>			<u>ANALYSIS</u>		<u>(Ca/S)</u>
1	100	OPT	OPT	OPT	OPT	YES	NO	A (1/1)
2	100	OPT	OPT	OPT	OPT	YES	NO	A (2/1)
3	100	OPT	OPT	OPT	OPT	YES	NO	A (3/1)
4	100	OPT	OPT	OPT	OPT	YES	YES	A (1/1)
5	100	OPT	OPT	OPT	OPT	YES	YES	A (2/1)
6	100	OPT	OPT	OPT	OPT	YES	YES	A (3/1)
7	100	OPT	OPT	OPT	OPT	YES	NO	B (1/1)
8	100	OPT	OPT	OPT	OPT	YES	NO	B (1.5/1)
9	100	OPT	OPT	OPT	OPT	YES	NO	B (2/1)
10	100	OPT	OPT	OPT	OPT	YES	YES	B (1/1)
11	100	OPT	OPT	OPT	OPT	YES	YES	B (1.5/1)
12	100	OPT	OPT	OPT	OPT	YES	YES	B (2/1)

A = Calcium Hydroxide

B = Calcium Acetate

TABLE 3.3 TEST MATRIX NO. 3

FIGURE 3.6 SCHEMATIC OF Y-JET ATOMIZER DESIGN

C-E received an opportunity in 1983 for a long-term test of one of its burners in a wall-fired industrial boiler located in Sundbyberg, Sweden that was being converted to burn CWF (Smith and LaFlesh, 1984). Two 25 MBtu/hr burners capable of firing either fuel oil or CWF were designed by C-E and installed in a 20 MW (thermal) oil-fired boiler used to supply domestic steam heat to the town of Sundbyberg. This program was initiated by the Swedish Thermal Engineering Research Institute, with Uppsala Kraftvarme AB acting as the project manager. The initial goal of this program was to operate the boiler on CWF for a minimum of 1000 hours to demonstrate the technical feasibility of firing CWF. After two heating seasons and more than 2000 hours of operation on the original atomizer tips, there was no significant wear in the atomizers. To verify that the performance of the original tips had not deteriorated, new tips were installed near the end of the 1984-85 heating season; the performance was identical to that obtained with the original tips after the 2000 hours of operation. This style of atomizer has also been successfully utilized in a utility-scale demonstration in Chatham, New Brunswick, Canada (Rini, et al., 1986). Also, in late 1989, C-E's CWF atomizer will enter commercial operation in a utility boiler in Novosibirsk, USSR.

The four variations of the CWF atomizer that were tested during the course of this program were:

- A) 7 - 7 MBtu cells, 25° Spray angle
- B) 7 - 7 MBtu cells, 45° Spray angle
- C) 8 - 7 MBtu cells: 4 on 55° Spray angle
4 on 30° Spray angle
- D) 10 cells: 5 - 3.5 MBtu cells on 50° Spray angle
5 - 7 MBtu cells on 30° Spray angle

Atomizers A and B feature a constant spray angle designed to match the burner's aerodynamic flow field. Atomizers C and D feature dual spray angles in an attempt to generate a highly fuel-rich primary zone. Atomizer C is shown installed in the HEACC in Figure 3.7 (with the forced vortex swirler).

Each of the atomizers was fired independently in combination with the two best free

FIGURE 3.7 CWF ATOMIZER AND FORCED VORTEX SWIRLER
INSTALLED IN HEACC

and forced vortex swirlers developed in Task 1.0. Based on the results of these tests (Matrix 1), a best atomizer configuration and swirler type were chosen for a detailed burner performance characterization series (Matrix 2). This matrix, as shown in Table 3.2, included testing over the full load range, total excess air variation, and three levels of primary air flow. While the HEACC was designed as an internally staged burner, this test matrix evaluated the use of physically separated staged air for NO_x control.

Matrix 3, given in Table 3.3, addressed the use of an in-fuel sorbent for SO_2 control. This series of tests was conducted using two sorbents, hydrated lime (calcium hydroxide) and calcium acetate. Also, Matrix 3 was conducted using optimized burner settings as determined in Matrix 2.

3.1.2 Detailed Experimental Results

1) Overview

In this section the details of the series of experimental combustion tests (Test Numbers 1 to 65) for the CWF fuels will be presented. The combustion tests were conducted in two major series: Following an expanded version of Matrix 1, tests were used to evaluate four different configurations of the C-E CWF atomizer and a variety of operating conditions to optimize the HEACC's performance. Next, a series of matrix tests (following Matrix 2 and 3) were conducted to document the burner's performance in a systematic manner.

During the Matrix 1 testing, based on previous experience with other CWF fuels, it became evident that the additive package contained in the CWF was exerting a strong influence over the combustion test results. Specifically, it was determined that the stabilizer material greatly affected the fuel spray breakup into the fine droplets required for high combustion efficiency.

The type of material commonly used to stabilize CWF is xanthan gum. When xanthan gum is dispersed in a CWF, its long chain polymers act to keep the slurry's coal particles in suspension by physically separating the particles and preventing the formation of agglomerates which have a high tendency to settle. This principle has been widely described in the literature (Miller and Hoyt,1988). While the long chain polymers are of great benefit to the fuel's shipping and storage stability, they increase the fuels's viscosity (Rakitsky, et al., 1986) and the ability to achieve high quality atomization. Since CWFs prepared for experimental programs are typically shipped long distances and can be stored for several months prior to use, significant dosages of stabilizers are required to avoid settling and hardpacking (Berggren and Swanson (1987), and Miller and Hoyt (1988)). Decoupling the effects of stabilizer additive from the performance of the HEACC proved to be a complex task, and extended the duration of the prematrix testing.

An overview of the total test series is given in Table 3.4. Test Numbers 1 to 38 are the Prematrix tests, during which several variations of CWF formulation were combusted. It is important to note that much valuable and useful data was generated during the course of the prematrix testing.

The Matrix Tests are numbered Test 39 to 63. Based on the screening work of Tests 1 to 38, a fine grind (21 micron MMD) CWF of commercially viable stability was prepared and utilized for these tests.

Table 3.5 presents a summary of the test input conditions, including atomizer and swirler types, for Test Numbers 1 to 65. A summary of the test results is given in Table 3.6. In addition to the emissions of NO_x , SO_2 , and CO , this table includes the actual excess air used for each test, the carbon conversion efficiency, and the primary air fraction, PAF. The PAF is defined as the measured air flow ducted through the primary swirler divided by the measured total air flow. The PAF parameter is similar to the parameter η_p (Primary zone stoichiometry) discussed in the Task 1 report and is intended to serve as a measure of the primary zone fuel to air ratio. As will be discussed, this is an important parameter influencing both NO_x and carbon conversion

TEST NOS.	DATES	DESCRIPTION OF TEST	% SOLIDS
1 - 8A	6/21-22/88	Fine Grind	63.8
9 - 13A	6/24/88	Fine Grid Unstabilized	63.8
14	6/24/88	Baseline Fuel- Cool Fuel Test	63.8
15 - 19	6/27/88	Baseline Ultrafine	60.5
20	6/27/88	Diluted Ultrafine	59.1
21 - 27	6/28/88	Slightly Stabilized Fine Grind	62.4
28 - 34	6/28-29/88	20% Regular Grind/ 80% Ultrafine	59.6
35	6/29/88	New Process- Fine Grind	63.8
36 - 38	6/29/88	Unstabilized Ultrafine	58.2
39 - 41	7/11-13/88	Fine Grind, 8-cell, Forced Vortex, Baseline Conditions	65.2
42 - 44	7/13/88	Fine Grind, 8-cell, Free Vortex	65.2
45 - 48	7/13/88	Fine Grind, 25°, Free Vortex	65.2
49 - 51	7/13/88	Fine Grind, 2" Primary ΔP , 8 cell, Forced Vortex	65.2
52	7/13/88	Fine Grind, 3.6" Primary ΔP , 8 cell, Forced Vortex	65.2
53	7/13/88	Fine Grind, 0.45" Primary ΔP , 8 cell, Forced Vortex	65.2
54 - 55	7/13/88	Fine Grind, External Staging, 0.45" Primary ΔP , 8 cell, Forced Vortex	65.2
56	7/13/88	Fine Grind, External Staging, 4.3" Primary ΔP , 8 cell, Forced Vortex	65.2
57	7/13/88	Fine Grind, 50% Load, 8 cell, Forced Vortex	65.2
58	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	59.2
59	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.5
60	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.9
61	7/14/88	Fine Grind, Calcium Acetate Inj., 2" Primary ΔP , 8 cell, Forced Vortex	61.8
62 - 63	7/14/88	Fine Grind, Calcium Hyd. Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.2
64 - 65	7/14/88	Fine Grind, 2.0" Primary ΔP , 8 cell, Forced Vortex	63.2

TABLE 3.4 SUMMARY OF CWF TESTS

TEST NUMBER	1	2	3	4	5	6	7	8	8A	9	10	11	12	13
DATE	6/21/88	6/21/88	6/21/88	6/21/88	6/21/88	6/22/88	6/22/88	6/22/88	6/22/88	6/24/88	6/24/88	6/24/88	6/24/88	6/24/88
TIME	14:57	16:15	17:06	18:08	19:05	11:18	11:40	12:45	13:05	10:30	10:58	11:25	12:15	12:40
LOAD (%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100
TARGET EXCESS AIR (%)	30	30	25	25	25	30	22	22	22	20	30	30	25	22
FUEL FLOW RATE (L B/MIN)	90	90	90	90	90	90	92	90	90	90	90	90	90	90
ATOMIZER	45 deg	45 deg	8 cell	10 cell	25 deg	25 deg	25 deg	25 deg	25 deg	8 cell	8 cell	8 cell	8 cell	8 cell
SWIRLER TYPE	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced
FUEL PRESSURE AT GUN (PSIG)	160	160	175	156	184	218	218	222	220	200	205	205	205	210
FUEL TEMP AT GUN (°F)	108	108	107	108	108	108	108	108	108	91	92	93	93	92
AIR PRESSURE AT GUN (PSIG)	182	183	183	176	190	234	235	235	231	216	233	235	236	236
COMBUSTION AIR TEMP (°F)	505	500	505	502	501	501	503	503	503	497	502	492	493	495

TABLE 3.5: SUMMARY OF TEST OPERATING CONDITIONS

TEST NUMBER	14	15	16	17	18	19	20	21	22	23	24	25	26
DATE	6/24/88	6/24/88	6/27/88	6/27/88	6/27/88	6/27/88	6/27/88	6/28/88	6/28/88	6/28/88	6/28/88	6/28/88	6/28/88
TIME	13:25	13:52	10:54	11:26	12:49	18:04	18:40	10:32	11:06	11:45	2:00	2:35	2:55
LOAD (%)	100	100	100	100	100	100	100	100	100	100	100	100	100
TARGET EXCESS AIR (%)	30	45	30	25	30	30	30	20	20	20	22	30	30
FUEL FLOW RATE (LB/MIN)	90	90	97	97	97	97	99.5	90	90	90	90	90	90
ATOMIZER	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	25 deg	25 deg	25 deg	8 cell	8 cell	8 cell
SWIRLER TYPE	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced
FUEL PRESSURE AT GUN (PSIG)	210	190	200	198	195	190	190	205	207	220	203	203	202
FUEL TEMP AT GUN (°F)	87	84	77	77	77	80	84	89	89	90	90	91	91
AIR PRESSURE AT GUN (PSIG)	220	231	230	230	220	230	231	232	240	240	230	232	233
COMBUSTION AIR TEMP (°F)	497	497	503	499	502	503	503	500	500	501	500	508	500

TABLE 3.5: SUMMARY OF TEST OPERATING CONDITIONS

TEST NUMBER	27	28	29	30	31	32	33	34	35	36	37	38	39
DATE	6/28/88	6/28/88	6/28/88	6/28/88	6/28/88	6/28/88	6/29/88	6/29/88	6/29/88	6/29/88	6/29/88	6/29/88	7/11/88
TIME	15:17	17:06	17:30	18:02	18:30	18:55	9:37	11:21	13:41	14:08	15:19	15:40	13:15
LOAD (%)	100	100	100	100	100	100	100	100	100	100	100	100	100
TARGET EXCESS AIR (%)	30	30	30	40	40	30	30	22	30	22	30	30	20
FUEL FLOW RATE (LB/MIN)	90	96	96	96	96	96	98	98	98	98	99	99	90
ATOMIZER	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell	8 cell
SWIRLER TYPE	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced
FUEL PRESSURE AT GUN (PSIG)	202	190	187	189	185	185	200	200	180	180	185	185	166
FUEL TEMP AT GUN (°F)	91	86	86	86	86	86	87	87	96	96	90	91	110
AIR PRESSURE AT GUN (PSIG)	233	232	230	231	232	240	240	230	232	233	233	232	230
COMBUSTION AIR TEMP (°F)	510	507	509	505	502	503	503	503	505	505	500	506	504

TABLE 3.5: SUMMARY OF TEST OPERATING CONDITIONS

TEST NUMBER	40	41	42	43	44	45	46	47	48	49	50	51	52
DATE	7/11/88	7/11/88	7/11/88	7/11/88	7/11/88	7/11/88	7/11/88	7/11/88	7/11/88	7/13/88	7/13/88	7/13/88	7/13/88
TIME	13:35	14:05	18:28	18:50	19:21	20:07	20:20	20:47	21:14	13:11	14:36	16:38	17:54
LOAD (%)	100	100	100	100	100	100	100	100	100	100	100	100	100
TARGET EXCESS AIR (%)	22	33	22	22	33	22	30	33	22	35	25	20	25
FUEL FLOW RATE (LB/MIN)	90	90	90	90	90	90	90	90	90	90	90	90	90
ATOMIZER	8 cell	8 cell	8 cell	8 cell	8 cell	25 deg	25 deg	25 deg	25 deg	8 cell	8 cell	8 cell	8 cell
SWIRLER TYPE	Forced	Forced	Free	Free	Free	Free	Free	Free	Free	Forced	Forced	Forced	Forced
FUEL PRESSURE AT GUN (PSIG)	166	165	165	165	164	165	165	185	184	170	165	168	170
FUEL TEMP AT GUN (°F)	110	110	111	111	111	111	112	111	111	113	113	113	113
AIR PRESSURE AT GUN (PSIG)	222	222	222	210	221	223	230	227	228	226	218	226	226
COMBUSTION AIR TEMP (°F)	502	505	502	498	502	502	504	500	500	500	495	498	500

TABLE 3.5: SUMMARY OF TEST OPERATING CONDITIONS

TEST NUMBER	53	54	55	56	57	58	59	60	61	62	63	64	65
DATE	7/13/88	7/13/88	7/13/88	7/13/88	7/13/88	7/13/88	7/14/88	7/14/88	7/14/88	7/14/88	7/14/88	7/14/88	7/14/88
TIME	18:35	19:42	20:20	20:54	21:15	0:25	0:49	2:34	3:15	4:24	4:52	5:43	6:27
LOAD (%)	100	100	100	100	50	100	100	100	100	100	100	100	100
TARGET EXCESS AIR (%)	25	25	25	25	60	25	25	25	25	25	25	25	35
FUEL FLOW RATE (LB/MIN)	90	90	90	90	45	108	104	99.2	108	98	95.4	90	90
ATOMIZER	8 cell	8cell	8 cell	8 cell	8cell	8 cell	8 cell	8cell	8 cell	8 cell	8cell	8 cell	8 cell
SWIRLER TYPE	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced	Forced
FUEL PRESSURE AT GUN (PSIG)	172	175	175	173	116	180	175	180	185	180	182	193	195
FUEL TEMP AT GUN (°F)	113	113	113	113	111	106	107	109	105	108	108	89	88
AIR PRESSURE AT GUN (PSIG)	226	230	230	226	208	228	228	227	230	226	226	224	224
COMBUSTION AIR TEMP (°F)	503	506	499	499	500	501	501	501	501	500	500	500	499

TABLE 3.5: SUMMARY OF TEST OPERATING CONDITIONS

TEST	EMISSIONS CORRECTED TO 3% O ₂ , PPM			% EXCESS AIR	% CARBON CONVERSION	PAF
	NOX	SO ₂	CO			
1	719	*	54	25.7	95.0	0.36
2	734	*	54	25.0	93.2	0.37
3	666	*	62	23.1	94.3	0.34
4	737	*	65	22.4	93.6	0.33
5	781	*	64	22.4	95.2	0.35
6	737	*	77	23.8	86.7	0.35
7	755	*	74	21.7	90.5	0.32
8	699	*	75	22.6	86.8	0.34
8A	693	*	80	22.6	86.9	0.35
9	672	*	61	28.7	99.9	0.37
10	604	*	52	34.0	98.3	0.34
11	525	*	56	33.6	97.2	0.25
12	470	*	62	27.9	96.6	0.18
13	423	*	71	22.9	93.6	0.12
14	714	*	95	35.6	92.2	0.34
15	704	*	79	46.5	99.4	0.33
16	717	*	74	30.7	99.3	0.34
17	754	272	56	29.3	97.7	0.48
18	745	278	73	32.4	98.0	0.50
19	696	254	49	34.0	95.8	0.50
20	695	262	41	33.9	97.0	0.50
21	712	278	44	26.6	93.6	0.36
22	605	342	68	25.8	93.6	0.25
23	627	368	101	25.1	96.0	0.21
24	743	324	121	29.4	94.0	0.36
25	715	323	125	34.0	93.4	0.33
26	715	323	127	34.4	93.7	0.25
27	773	320	88	34.2	92.7	0.44
28	650	317	164	31.3	94.0	0.32
29	725	313	127	33.3	94.7	0.43
30	716	304	83	42.8	95.6	0.43
31	700	296	92	41.2	90.6	0.46
32	722	296	63	36.1	89.3	0.56
33	626	326	125	32.6	95.2	0.42
34	476	333	48	24.1	96.9	0.14
35	658	332	56	33.7	96.9	0.32
36	472	342	62	22.8	95.3	0.07
37	664	322	36	31.5	99.9	0.32
38	689	319	35	33.4	99.9	0.41
39	816	363	51	17.1	92.1	0.48
40	734	370	50	18.9	91.4	0.36
41	743	358	54	27.7	93.7	0.35
42	735	*	52	20.4	96.9	0.44
43	732	*	61	18.0	95.0	0.34
44	740	*	50	27.5	96.6	0.33
45	509	*	58	22.4	94.2	0.40
46	521	*	56	31.4	94.9	0.41
47	496	*	52	33.7	97.4	0.12
48	494	*	53	21.3	97.0	0.15
49	577	268	41	33.8	97.4	0.34
50	552	295	48	24.5	94.9	0.33

(* Analyzer not Functioning)

TABLE 3.6 SUMMARY OF CWF TEST RESULTS

TEST	EMISSIONS CORRECTED TO 3% O2, PPM			% EXCESS AIR	% CARBON CONVERSION	PAF
	NOX	SO2	CO			
51	586	295	47	18.6	94.5	0.33
52	749	287	32	22.2	96.0	0.44
53	437	293	48	20.9	94.7	0.15
54	708	285	39	23.8	96.7	0.16
55	736	292	42	22.7	97.2	0.15
56	695	292	48	24.3	97.1	0.48
57	444	236	13	80.1	99.9	0.80
58	767	215	24	18.9	96.7	0.21
59	745	222	28	24.1	99.9	0.22
60	648	278	31	20.1	96.6	0.23
61	729	252	26	26.5	99.9	0.27
62	728	239	2	25.9	99.9	0.23
63	537	258	0	25.7	99.3	0.24
64	600	313	26	26.0	99.9	0.33
65	611	303	20	40.5	99.9	0.34

TABLE 3.6 (CONTINUED) SUMMARY OF CWF TEST RESULTS

efficiency levels.

A complete summary of the individual experimental tests using the CWF fuel follows. It should be noted that since low NO_x emissions was a key goal, a decision was made to run at relatively low excess air conditions to minimize NO_x emissions. In many cases, this resulted in lower than otherwise achievable carbon conversion efficiencies. Later in the test series it was demonstrated that the HEACC was fully capable of achieving high combustion efficiencies at excess air levels more typical of CWF combustion.

2) Matrix 1 Tests

The first tests (Test Numbers 1- 8A), using the fine grind CWF, were carried out to evaluate the 4 candidate nozzle types that were previously described . Figure 3.8 gives a summary of the experimental results for carbon conversion efficiency as a function of excess air for the four types of atomizers. On the basis of these tests, the 25 degree and 8 cell types were selected for further testing.

A concern over the relatively low carbon conversion efficiency observed in Tests Numbers 1 to 8 lead to the decision to test a batch of unstabilized fine grind CWF in order to determine if the stabilizer package was responsible for the low carbon conversion efficiency. The results of this series of tests showing the carbon conversion efficiency as a function of excess air for different primary air fraction (PAF) ratios are summarized in Figure 3.9. For this relatively narrow range of excess air levels, the carbon conversion efficiency was acceptably high (97.2 to 99.9%) for values of PAF between 0.25 and 0.35. The carbon conversion efficiency fell off sharply as the PAF and excess air were decreased. As shown in Figures 3.10 and 3.11 where NO_x emissions are given as a function of excess air or PAF, the NO_x emissions were relatively high. As shown in Figure 3.11, the lower PAF ratios between 0.18 and 0.25 lowered the NO_x emissions to 470 to 525 ppm, but also resulted in lower carbon conversion efficiencies of 96.6 to 97.2% (See Figure 3.9). Furthermore, a PAF value of 0.12 lowered NO_x emissions to 423 ppm; however, carbon conversion efficiency was reduced significantly to 93.6%.

These tests did show that at PAFs comparable to those used in Tests 1 to 8 (PAF = 0.32- 0.37) the unstabilized CWF produced improved carbon conversion efficiency (98.3 to 99.9% vs 94.3%) thus demonstrating the adverse effect of the stabilizer. Further tests were carried out to define an acceptable level of stabilizer to meet both storage and atomization requirements.

For the testing sequence consisting of Test Numbers 15 to 19, ultrafine CWF fuel was

**CARBON CONVERSION EFFICIENCY VS EXCESS AIR
COMPARISON OF 4 ATOMIZERS (TEST POINTS 1- 8A)
FORCED VORTEX SWIRLER, BASELINE FINE CWF**

FIGURE 3.8

**CARBON CONVERSION VS EXCESS AIR
8 CELL ATOMIZER (TEST POINTS 9-13)
UNSTABILIZED FINE GRIND CWF**

FIGURE 3.9

used with PAF values ranging from 0.33 to 0.50. Figure 3.12 presents the results of these tests showing the carbon conversion efficiency as a function of PAF. These results showed that the carbon conversion efficiency decreases as the PAF ratio was increased beyond the design value of 0.35. These results suggested that too much air was allowed into the primary zone, decreasing flame zone temperature, thus resulting in low carbon conversion. The effect of varying PAF on the NO_x emissions is shown in Figure 3.13. The values of NO_x emissions were still high and, with the exception of the data point at the highest value of PAF, the results follow an expected trend of decreasing NO_x with decreasing PAF. Data from test 15 is excluded from these figures, since its excess air value was much higher (46% compared to about 30%).

For Test Number 20, the CWF fuel was diluted by an additional 1.4% resulting in a solids concentration of 59.1%. As shown in Figure 3.14, carbon conversion efficiency improved from 95.8 to 97.0 %, and NO_x emissions were unchanged.

The next series of tests (Test Numbers 21 to 27) were carried out with fine grind CWF containing a moderate amount of stabilizer. Results of this series of experiments showing carbon conversion efficiency as a function of the primary air fraction, PAF, are given in Figures 3.15 (25 degree atomizer tip) and 3.16 (8 cell atomizer tip). As can be seen, the carbon conversion efficiency was low, and the values of NO_x emissions that were measured were still high. This demonstrated the influence that the CWF additive package was exerting on the combustibility of the fuel. Figure 3.17 presents a comparison of the carbon conversion efficiency of this series of tests using the slightly stabilized fine grind with the previous results obtained for the unstabilized fine grind CWF fuel (for a PAF value of approximately 0.35). The relatively low values for carbon conversion efficiency show the negative impact of the additive package used in the stabilized CWF.

For the next series of tests, Test Numbers 28 to 34, it was theorized that a mixture of a 20% fine grind CWF with an 80% ultrafine CWF fuel would provide larger particles to aid in the breakup of atomization ligaments, thus providing better atomization and

**CARBON CONVERSION VS PAF (TEST POINTS 15-19)
8 CELL ATOMIZER, ~ 30% EXCESS AIR
DILUTED BASELINE ULTRAFINE**

FIGURE 3.12

**NO_x EMISSIONS VS PAF (TEST POINTS 15-19)
8 CELL ATOMIZER, ~ 30% EXCESS AIR
DILUTED BASELINE ULTRAFINE**

FIGURE 3.13

EFFECT OF SOLIDS CONTENT ON CARBON CONVERSION EFFICIENCY
8 CELL ATOMIZER, FORCED VORTEX SWIRLER, 34 % EXCESS AIR
DILUTED BASELINE ULTRAFINE, PAF = 0.5 (TEST POINTS 19 & 20)

FIGURE 3.14

CARBON CONVERSION VS PRIMARY AIR FRACTION
25° TIP, FORCED VORTEX SWIRLER, ~ 25% EXCESS AIR
SLIGHTLY STABILIZED FINE GRIND (TEST POINTS 21-23)

FIGURE 3.15

**CARBON CONVERSION VS PRIMARY AIR FRACTION
8 CELL TIP, FORCED VORTEX SWIRLER, ~ 35% EXCESS AIR
SLIGHTLY STABILIZED FINE GRIND (TEST POINTS 24-27)**

FIGURE 3.16

**CARBON CONVERSION VS EXCESS AIR
EFFECT OF FUEL TYPE
FORCED VORTEX SWIRLER, PAF ~ 0.35**

FIGURE 3.17

improving combustion. A summary of the carbon conversion efficiency vs excess air for directly comparable test points in this series using the baseline ultrafine CWF fuel (Test Numbers 16 - 19) is given in Figure 3.18. As can be seen, the mixing of the CWF fuels did not provide the means for the improvement of the carbon conversion efficiency performance of the HEACC system. These fuels both contained the baseline amount of stabilizer.

Test 35 evaluated a variation of both additive quantity and the fuel mixing process. It exhibited reasonably good carbon conversion (approximately 97%) when fired at a PAF of 0.32 and an excess air level of 33.7%. This was a valuable point in the refinement of the fuel.

The next series of tests, Test Numbers 36 to 38, were carried out using an unstabilized ultrafine CWF with a solids content of 58.2%. As shown in Figure 3.19, higher carbon conversion efficiencies at excess air levels between 31.5 and 33.4% excess air were attained with relatively high NO_x emissions. Lower excess air operation, in an attempt to reduce NO_x emissions, caused the carbon conversion efficiency to diminish to less than 96%, however, NO_x emissions were reduced to 475 ppm.

As previously stated, the Prematrix testing (Tests 1- 38) served to optimize the performance of the HEACC and to formulate a CWF which balanced storage and atomization requirements. A 30,000- gallon batch of this fine grind (21 micron MMD) CWF was prepared by OXCE and utilized for the Matrix Tests. The Prematrix operation (Tests 1- 14) of the HEACC was optimized with a 63.8% (or less) solids CWF. The production batch of CWF was produced at 65.2% solids. Previous experiments have noted the adverse impact of increased solids content upon carbon conversion efficiency. However, excess air level and PAF were found to be the dominant factors in influencing carbon conversion efficiency.

FIGURE 3.18

3) Matrix 2 and 3 Tests

Test Numbers 39 to 51 were carried out varying the atomizer (8 cell vs. 25 degree) and swirler (forced vs free vortex) types. The results of this test series, giving carbon conversion efficiency and NO_x emissions as a function of excess air are shown in Figures 3.20 and 3.21. These test results demonstrate the ability of the both the 8 cell atomizer with the forced vortex swirler and the 25 degree spray nozzle tip with the free vortex swirler to obtain carbon conversion efficiencies of over 97% with excess air levels greater than 30%. The two fuel nozzles used for this test case were selected from a field of 4 fuel nozzles during the prematrix testing. Figure 3.21 shows that both these nozzle-swirler combinations could yield NO_x emissions as low as approximately 500 ppm, when the excess air levels were sufficiently low.

Based on these experimental results and the cold flowing modeling results of Task 1.0 (which showed the forced vortex type swirlers to produce a larger and stronger recirculation pattern), the next series of experimental runs (Test Nos. 52 to 57) were all carried out using a forced vortex swirler and 8 cell tip atomizer configuration.

In an attempt to control NO_x emissions, Test Numbers 52 to 56 were run at lower values of excess air (approximately 22%). In this test series, Test Numbers 54 to 56 were carried out with external staging- accomplished by introducing air externally along the side of the furnace through four 6-inch ports approximately 12 to 14 ft downstream of the burner. The results of these tests showing carbon conversion efficiency and NO_x emissions as a function of the primary air fraction, PAF, are given in Figures 3.22 and 3.23. These show that the use of external staging increased the carbon conversion efficiency, but gave little reduction in NO_x emissions. This is contrary to previous investigations by Combustion Engineering (Donzis, et al., 1989) and others (Lisauskas, et al., 1989). The lack of reduction of NO_x emissions with external staging may have been caused by the low velocity (and jet penetration) of the externally staged air jets. This was due to limitations in the available fan head at the test facility.

CARBON CONVERSION VS EXCESS AIR FINE GRIND (TEST POINTS 39-51)

FIGURE 3.20

NO_x EMISSIONS VS EXCESS AIR FINE GRIND (TEST POINTS 39-51)

FIGURE 3.21

CARBON CONVERSION EFFICIENCY VS PAF
8 CELL TIP, FORCED VORTEX SWIRLER, ~ 22% EXCESS AIR
FINE GRIND (TEST POINTS 52-56)

FIGURE 3.22

NO_x EMISSIONS VS PRIMARY AIR FRACTION
8 CELL TIP, FORCED VORTEX SWIRLER, ~ 22% EXCESS AIR
FINE GRIND (TEST POINTS 52-56)

FIGURE 3.23

Figure 3.23 shows a dramatic drop in NO_x levels when the PAF was reduced from 0.44 to 0.15; however, the carbon conversion efficiency decreased to 94.7%.

Test Number 57 was a 50% load test and yielded a carbon conversion efficiency of 99.9% and NO_x emissions of 444 ppm. The high carbon conversion efficiency was realized due to the increased residence time inside the furnace at the lower load, and the lower NO_x emissions were primarily due to the effectively lower value of volumetric heat release in the combustion chamber at low load.

The last experiments in this test series (Test Numbers 58 to 63) were performed with sorbents added to the CWF fuel. Two types of sorbents were used- either Calcium Hydroxide ($\text{Ca}(\text{OH})_2$) or Calcium Acetate ($\text{Ca}(\text{C}_2\text{H}_3\text{O}_2)_2$). The results for this series of experiments are summarized in Table 3.7. It should be noted that the tests reported all used the 8 cell atomizer tip, with the forced vortex swirler, and a primary air fraction of about 0.23. The sulfur capture efficiency is defined as the percentage reduction in SO_2 emissions from an averaged baseline value (in this case 300 ppm).

For these tests, the sorbents were premixed with water to provide an initial dispersion of the sorbent powders. As shown schematically in Figure 3.24, the sorbent mixture was held in a separate tank. The sorbent mixture flowrate was independently measured using a small Micromotion mass flow meter. This sorbent flow was injected into the CWF flow between the transfer pump below the CWF storage tank and the high pressure burner fuel pump. This method was designed to provide good mixing between the components. Fuel line residence time of the sorbent/ CWF mixture was limited to about 2 minutes.

A graphical summary of these results showing the sulfur capture efficiency as a function of the Ca/S mole ratio is given in Figure 3.25. For comparison, the results from the MIT testing, summarized in the Task 2.0 report (Toqan, et al., 1989) are also given. It should be noted that the sulfur capture efficiency values for this series of tests are considerably below those reported in the MIT testing. Careful examination of the

TEST NO.	SORBENT	Ca/S DESIRED	Ca/S ACTUAL	SO2 Emissions, ppm	Sulfur Capture Eff, %
58	Calcium Acetate	2/ 1	1.49/ 1	215	28.3
59	Calcium Acetate	1.5/ 1	1.03/ 1	222	26
60	Calcium Acetate	1/ 1	0.73/ 1	278	7.3
62	Calcium Hydroxide	2/ 1	2.03/ 1	239	20.3
63	Calcium Hydroxide	1/ 1	0.9/ 1	258	14

TABLE 3.7 RESULTS OF SORBENT INJECTION TESTS

FIGURE 3.24 SCHEMATIC OF SORBENT INJECTION SYSTEM

SULFUR CAPTURE EFFICIENCY VS. Ca/S RATIO
CE TEST POINTS NO. 58-63

Demonstration Scale data has not provided a full explanation for the substantial differences between the two test series. MIT has attributed the successful sorbent performance to the several days that sorbent and CWF mixture spent in storage barrels prior to firing. They (Toqan, et al., 1989) concluded that the ability to disperse the calcium uniformly among the coal particles resulted in a higher sulfur removal efficiency. This explanation, or potentially significant differences in the aerodynamic flow field or temperature field between the Pilot and Demonstration scale HEACC tests merit further investigation since the Pilot scale results show such a significant SO₂ reduction by fuel mixed sorbent injection.

3.2 PULVERIZED COAL FIRING

3.2.1 Scope of Experimental Tests

Under the scope of the pulverized coal portion of the experimental plan, two combustion matrices were planned for the pulverized coal (PC) portion of the HEACC Demonstration Scale testing. The scope of this test series is summarized in Tables 3.8 (Free vortex swirler) and 3.9 (Forced vortex swirler). The general objective of this test program was to systematically test and document the combustion performance of the HEACC using PC fuels. As shown in these tables, this series of tests involved evaluating the following design variables:

- 1) Swirler type
- 2) Fuel Injector type
- 3) Burner configuration
- 4) Secondary swirl direction
- 5) Firing rate
- 6) Excess air
- 7) Primary Air Fraction (PAF)

A discussion of each of these variables follows:

1) Swirler type: PC Matrix 1 (Test Numbers 101- 120) was conducted using the free vortex swirler. PC Matrix 2 (Test Numbers 201- 219) was conducted using the forced vortex swirler. These were the two most efficient swirlers developed under Task 1 and are described in detail in the Task 1 final report. They were also the same ones used in the CWF test matrices.

2) Fuel Injector: Two types of fuel injectors were used in PC Matrix 1. The conical injector (Figure 3.26A) features a 30° cone mounted on the end of a dense phase fuel pipe. Its purpose was to provide a hollow cone fuel "spray" with a relatively narrow angular distribution. The Impinging Jet (or I-Jet) injector (Figure 3.26B) was derived from a small scale International Flame Research Foundation (IFRF) design (Smart

TEST NO.	FUEL INJECTOR	SWIRLER TYPE	BURNER CONFIG.	SECONDARY SWIRL DIRECTION	LOAD, %	TARGET EXCESS AIR, %
101	I - JET	FREE	STAGGERED	CO-ROTATIONAL	100	25
102	"	"	"	CO-ROTATIONAL	"	25
103	"	"	"	ZERO	"	25
104	"	"	"	CO-ROTATIONAL	"	20
105	"	"	"	CO-ROTATIONAL	"	20
106	"	"	"	CO-ROTATIONAL	"	20
107	"	"	"	CO-ROTATIONAL	"	20
108	"	"	"	ZERO	"	20
109	"	"	"	CO-ROTATIONAL	"	20
110	"	"	"	COUNTER-ROTATIONAL	"	20
111	"	"	"	CO-ROTATIONAL	"	30
112	30 DEG CONE	"	"	CO-ROTATIONAL	"	20
113	"	"	"	CO-ROTATIONAL	"	20
114	"	"	"	CO-ROTATIONAL	"	15
115	"	"	"	CO-ROTATIONAL	"	15
116	"	"	"	CO-ROTATIONAL	"	20
117	"	"	"	CO-ROTATIONAL	"	15
118	"	"	TELESCOPED	CO-ROTATIONAL	"	15
119	"	"	"	CO-ROTATIONAL	"	15
120	"	"	"	CO-ROTATIONAL	"	20

TABLE 3.8 PC FIRING TEST: FREE VORTEX SWIRLER- MATRIX NO. 1

TEST NO	FUEL INJECTOR	SWIRLER	BURNER CONFIG.	SECONDARY SWIRL DIRECTION	LOAD, %	TARGET EXCESS AIR, %
201	I- JET	FORCED	STAGGERED	CO-ROTATIONAL	100	25
202	"	"	"	CO-ROTATIONAL	100	20
203	"	"	"	ZERO	100	20
204	"	"	"	CO-ROTATIONAL	100	15
205	"	"	"	"	100	20
206	"	"	"	"	100	20
207	"	"	"	"	100	20
208	"	"	"	"	100	20
209	"	"	"	"	100	20
210	"	"	"	"	100	15
211	"	"	"	"	100	15
212	"	"	"	"	100	12
213	"	"	"	"	100	15
214	"	"	"	"	100	15
215	"	"	"	"	60	25
216	"	"	"	"	60	25
217	"	"	"	"	60	25
218	"	"	"	"	60	25
219	"	"	"	"	60	40

TABLE 3.9 PC FIRING TEST: FORCED VORTEX SWIRLER- MATRIX NO. 2

1 1/4 SCH 40 FUEL PIPE

A: 30° CONICAL INJECTOR

1 1/4 SCH 40 FUEL PIPE

B: IMPINGING JET INJECTOR

FIGURE 3.26 SCHEMATIC OF FUEL INJECTORS

and Weber, 1989). The Combustion Engineering design featured 8 jets angled in upon each other to impinge approximately 10 inches downstream of the burner face. This impinging design lowers the momentum of the fuel particles and produces a highly fuel-rich zone at the heart of the burner's internal recirculation zone. In general, this proved highly beneficial to NO_x control. Based on the success of the I-Jet design in the Matrix 1 testing, this design was used exclusively for the Matrix 2 test series.

3) Burner Configuration: The HEACC was designed to allow for substantial "internal" air staging by employing axially adjustable secondary air sleeves. Two configurations that looked promising during the cold flow model testing were used during the pulverized coal matrix test series (Rini, et al., 1989). A "staggered" configuration (Figure 3.27) was predominately tested. The staggered arrangement was found to provide good flame stability while approximating the desired levels of burner stoichiometry distribution. The "telescoped" configuration (Figure 3.28) was also tested because it would minimize the entrainment of secondary air into the burner's internal recirculation zone. This would allow primary zone stoichiometric control (ϕ_p) mainly via the primary airflow (PAF).

4) Secondary Swirl Direction: The direction of rotation of the swirl of the burner's secondary air stream controls the rate of mixing with the primary air stream. This rate of mixing is known to have a strong influence on NO_x emissions and combustion efficiency. A co-rotational secondary air swirl would produce relatively slow mixing while a counter-rotational secondary air swirl would produce much faster mixing with the fuel and primary air streams. Tests were conducted in both pulverized coal matrices using secondary air swirls co-rotational, counter-rotational, and at zero rotation relative to the direction of the primary air stream.

5) Firing Rate (Load): The majority of tests were carried out at the HEACC's design firing rate of 50×10^6 Btu/hr, and this was the area of primary interest. Several tests were conducted at 60% of full load in order to characterize reduced load operation.

FIGURE 3.27 STAGGERED BURNER CONFIGURATION

FIGURE 3.28 TELESCOPED BURNER CONFIGURATION

6) Excess Air: Excess air levels for the test matrices were varied over the range of 12-30%. This represents the normal operating range for industrial boilers. Efforts were made to optimize the HEACC's performance at 15- 20% excess air- as this is conducive to efficient boiler performance and low NO_x production.

7) Primary Air Fraction (PAF): Control of a burner's primary zone stoichiometry (η_p) represents a key factor in NO_x control. In the HEACC the primary zone stoichiometry is composed of two main components: 1) the amount of combustion air admitted directly through the primary air swirler- this is called the primary air fraction (PAF) and is measured using a precision venturi tube. 2) Entrained secondary air and furnace gases also contribute to η_p . For the HEACC, an η_p of 0.6- 0.7 was desired and a PAF of 0.35 was used at the design point. With entrainment of other combustor air flow and furnace gases this value would correspond to a primary zone stoichiometry (η_p) of 0.6 to 1.0. Both pulverized coal matrices varied PAF over a wide range to assess the effect of this important parameter on NO_x emissions and combustion efficiency.

3.2.2 Detailed Experimental Results

The following discussion summarizes the series of experimental tests that were conducted with the PC fuels using both the free and forced vortex swirlers. A summary of the test results for the free vortex swirler (Test Nos. 101- 120) is presented in Table 3.10 and a summary of the test results for the forced vortex swirler (Test Nos. 201- 219) is shown in Table 3.11.

An overall summary of the carbon conversion efficiency as a function of the excess air supplied to the burner for the 100% load test points is given in Figures 3.29 and 3.30. Figure 3.29 gives the results for the free vortex swirler (Test Points Numbers 101- 120) and Figure 3.30 shows the results for the forced vortex swirler (Test Points Numbers 201- 219). As shown in these figures, the HEACC produced excellent carbon conversion values (98% to 99.9%) over a wide range of excess air values for both types of swirlers. In comparison to the previous tests of the HEACC system using a CWF, the results of this test series shows the advantage of using coal as a dry product as opposed to a CWF.

Based on the favorable carbon conversion efficiency of the HEACC system using micronized dense phase pulverized coal, the focus of the experiments became the reduction of NO_x emissions to minimal levels.

Figure 3.31 shows the NO_x emissions as a function of excess air for a number of the HEACC tests with a fixed primary air fraction (PAF) averaging 0.30. During these tests, both the swirler type (free vs. forced vortex) and the fuel injection method (I-Jet vs 30 degree cone) were varied. These results clearly demonstrate the positive effect that low excess air has on the NO_x emissions as well as the superiority of the I-Jet fuel injector design over the 30 degree conical injector. As is shown in Figure 3.31, there appears to be no NO_x emissions difference (within data scatter) between the free and forced vortex swirlers when used with the I-Jet injectors. Specifically, NO_x emission levels below 365 ppm were demonstrated at several test points, while high carbon conversion was maintained.

TEST NUMBER	LOAD, %	EXCESS AIR, %	FUEL INJECTOR	PAF	CARBON CONVERSION EFF., %	NOx (CORR. TO 3% O2), PPM
101	100	26.0	I - JET	30.3	99.7	367
102	100	26.5	"	30.3	99.6	434
103	100	27.5	"	30.3	97.9	394
104	100	20.5	"	30.3	97.9	377
105	100	20.2	"	24.0	97.9	397
106	100	20.0	"	20.5	98.1	442
107	100	20.5	"	35.4	98.1	424
108	100	21.0	"	35.4	98.9	385
109	100	20.5	"	44.2	98.3	434
110	100	20.5	"	30.3	99.5	486
111	100	28.5	"	31.7	99.8	464
113	100	20.0	30 DEG CONE	43.1	99.8	617
114	100	20.2	"	30.3	99.1	578
115	100	15.0	"	30.3	99.0	547
116	100	15.5	"	16.0	98.8	524
117	100	20.0	"	16.0	99.2	555
118*	100	15.5	"	38.3	99.7	578
119*	100	9.0	"	30.3	99.4	520
120*	100	20.0	"	30.3	99.6	596

* Telescoped Burner Configuration

TABLE 3.10 SUMMARY OF PC FIRING TESTS- FREE VORTEX SUPPLIER- MATRIX NO. 1

TEST NUMBER	EXCESS AIR, %	LOAD, %	FUEL INJECTOR	PAF	CARBON CONVERSION EFF, %	NOx (CORR. TO 3% O2), PPM
201	24.5	100	I - JET	30.3	99.9	426
202	21.0	100	"	30.3	99.6	406
203	20.5	100	"	30.3	99.4	434
204	16.0	100	"	29.0	99	358
205	20.5	100	"	25.8	99.4	398
206	21.0	100	"	21.6	99.4	390
207	20.0	100	"	17.0	99.4	386
208	19.0	100	"	8.2	99.4	388
209	20.0	100	"	35.4	99.3	370
210	21.0	100	"	41.0	97.8	390
211	15.5	100	"	34.3	98.7	356
212	14.5	100	"	36.7	99.2	364
213	8.5	100	"	27.1	98.5	340
214	16.0	100	"	20.5	99	383
215	12.0	100	"	30.3	97.8	337
216	24.5	60	"	29.0	99.3	351
217	24.5	60	"	24.0	99.3	346
218	22.0	60	"	34.3	99.2	345
219	42.0	60	"	39.4	99.7	462

TABLE 3.11 SUMMARY OF PC FIRING TESTS- FORCED VORTEX SWIRLER- MATRIX NO. 2

CARBON CONVERSION EFFICIENCY, %

FIGURE 3.29

CARBON CONVERSION EFFICIENCY, %

FIGURE 3.30

**NO_x EMISSIONS VS EXCESS AIR
PRIMARY AIR FRACTION ~ 0.3**

A comparison of the pressure drop through the free and forced vortex swirlers is shown in Figure 3.31A. As can be seen in the figure, the forced vortex swirler exhibits a pressure drop of approximately one half of that of the free vortex swirler at the same airflow. Since both swirlers have a design swirl of 1.0, this represents essentially identical amounts of swirl imparted to the primary air. Since the NO_x levels are also the same, this means that the forced vortex swirler would allow the burner to operate with a lower consumption of fan power, thus contributing to improved operating economics for the boiler.

Figures 3.32 through 3.34 present the NO_x emissions as a function of primary air fraction (PAF) for the I-Jet fuel injector for both the forced and free vortex swirler designs. The first two figures show that the optimum value (lowest NO_x emissions) for the primary air fraction was about 0.30. These trends confirm the validity of the design PAF value of 0.35. Figure 3.34 (Forced vortex swirler, 20% excess air) does not show this trend as clearly, but the minimum NO_x emissions do occur in Figure 3.34 near a PAF of 0.30.

As shown in Figure 3.35, the 30 degree conical injector exhibited NO_x emissions trends that differed from the I-jet injector. Based on a more limited series of test points, the lowest NO_x emissions occurred at a primary air fraction of 0.16. The fuel and air mixing patterns produced by the conical injector probably differ significantly from the I-jet. It is most important to note that the minimum NO_x level obtained for the conical injector is significantly higher than with the I-jet injector; thus, further development of the HEACC would focus on the I-jet concept for the coal injector.

Figure 3.36 shows that (for a PAF of 0.30 with the 30 degree conical injector, and a free vortex swirler) the telescoping HEACC configuration (Test points 119 and 120) did not give a reduction in NO_x emissions. However, it should be pointed out the degree of telescoping was limited with the conical injector because of fuel impingement limitations.

FIGURE 3.31A SWIRLER PRESSURE DROP VS. AIRFLOW

FIGURE 3.34

Figures 3.37 and 3.38 summarize the results of the testing for the HEACC system operated at a partial load of 60%, using the forced vortex swirler and the I-Jet fuel injector. As shown in Figure 3.37, the carbon conversion efficiency held at high values over a wide range of excess air. Figure 3.38 shows the NO_x emissions performance at partial load of the HEACC system and, as for the full load tests, shows the advantage of operation at low excess air levels and of the I-jet injector. Partial load operation was fuel supply system limited and it is expected that the HEACC could operate satisfactorily at a turndown ratio of from 3:1 to 4:1.

4.0 SUMMARY/ CONCLUSIONS

The overall objective of this program was to develop a firing system for coal-based fuels to enable the replacement of oil and natural gas in boilers and other fuel firing equipment currently using these premium fuels. The Demonstration Scale Tests described in this report show that the HEACC met this objective. The HEACC was successfully able to fire several forms of CWFs, as well as dry pulverized coal. Some goals, such as burner physical envelope and carbon conversion, were fully met. Others, such as NO_x emissions, were more difficult to achieve, but generally were met. The test results are summarized below.

The results of the CWF tests showed:

- The furnace opening required for the HEACC matched that of a comparable industrial oil burner- this would facilitate boiler retrofit.
- High carbon conversion efficiencies (> 98.0%) could be achieved at excess air levels of 30-35%.
- NO_x emissions could be reduced from over 700 ppm to below 475 ppm, but at the expense of reduced carbon conversion.
- Sulfur capture rates with the sorbent containing CWFs were lower than those measured in the Pilot-Scale tests.

The results of the pulverized coal tests showed :

- High carbon conversion efficiencies of greater than 98.5% could be obtained at excess air levels of 15 to 25%.
- NO_x emissions could be controlled to below 390 ppm while maintaining high

carbon conversion efficiencies.

- The I-jet fuel injector showed excellent results. This type of fuel injector merits further development and application.
- The use of stored pulverized coal and dense phase pneumatic transport to the burner was successfully demonstrated. This could be an important method of implementing BCF use in industrial oil replacement applications.

The overall results of the combustion tests showed:

- The HEACC PAF design value of 0.30 to 0.35 produced the minimum NO_x levels. This design value should be maintained in future applications.
- Both the free and forced vortex swirlers produced satisfactory operation; however, the forced vortex swirler required approximately one half of the pressure drop to achieve these results. From a plant efficiency viewpoint, the forced vortex swirler is superior.
- A commercial application of the HEACC should employ the staggered burner configuration. The telescoped configuration showed no significant benefits.

In summary, this program produced an advanced coal firing system that was capable of combusting both water-based and dry pulverized forms of BCFs in an industrial boiler environment. The HEACC could be adapted to a long term field program in a commercially operating unit. The optimum configuration for this would employ the HEACC firing either a dry beneficiated coal product using a dense phase storage and transport system or a beneficiated CWF. This long term usage would clearly be another important step in the Department of Energy's stated goal of energy independence for our nation.

5.0 REFERENCES

Borio, R. W., et al. (1984) "Coal- Water- Slurry Technology Development, Volume 1: Burner Technology," EPRI Report CS-3374.

Berggren, M. H. and Swanson, W. W. (1987) "Development of Dispersing Additives for Ultra-Clean Coal-Water Slurry Fuels," Proc. of 12th Int. Conf. on Slurry Technology.

Donais, R. E., et al. (1989) "1989 Update on NO_x Emission Control Technologies at Combustion Engineering," Proc. 1989 Joint Symposium on Stationary Combustion NO_x Control, EPA/EPRI, March.

LaFlesh, R. C., et al. (1985) "Comparison of the Performance of a Cross- Section of Commercial CWF Burners," Proc. of the 7th Int. Symposium on Coal Slurry Fuels Preparation and Utilization.

Lisauskas, R. A., et al. (1989) "Status of NO_x Control at Riley Stoker," Proc. 1989 Joint Symposium on Stationary Combustion NO_x Control, EPA/EPRI, March.

Maxwell, R. C., et al. (1989) "Supplying Premium Quality Coal-Based Fuels for the Development of Clean Coal Combustion," Proc. 14th Int. Conf. on Coal and Slurry Technology, Coal and Slurry Technology Association, April.

Miller, J. W. and Hoyt, H. L. (1988) "Evaluation of Polymers as Suspending Aids for Coal Water Slurries," Proc. 13th Int. Conf. on Coal and Slurry Technology.

Rakitsky, W. G., et al. (1986) "Rheological Properties Significant for the Atomization of Coal-Water Fuels," Proc. of 11th Int. Conf. on Slurry Technology.

Rini, M. J., et al. (1989) "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit- Task 1: Cold Flow Burner Development," U.S. DOE Report- Contract DE-AC 22-86PC90275.

Rini, M. J., et al. (1986) "Commercial CWF Burner Development at Combustion Engineering," Proc. of 11th Int. Conf. on Slurry Technology.

Smart, J. P., and Weber, R. (1989) "NO_x Reduction and Burnout Optimisation using an Aerodynamically Air Staged Burner and an Air Staged Precombustor Burner," Proc. AFRC Spring Meeting.

Smith, D. A. and LaFlesh, R. C. (1984) "Review of Sundbyberg CWM Firing Tests in a Wall Fired Industrial Boiler," Proc. American Power Conf.

Togan, M. A., et al. (1989) "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit- Task 2: Pilot Scale Combustion Tests," U.S. DOE Report- Contract DE-AC 22-86PC90275.

Whaley, H., et al. (1986) "Progress in CWF Technology Development for Utility Boilers in Eastern Canada," Proc. 8th Int. Symposium on Coal Slurry Fuels Preparation and Utilization, U.S. DOE, May.

EXECUTIVE SUMMARY

Since the oil embargo of 1974, there has been a major effort to develop energy systems that are not dependent on petroleum-based fuels. The Pittsburgh Energy Technology Center (PETC) of the U.S. Department of Energy (DOE) has directed a number of programs toward increasing both coal usage in existing markets and introducing new premium quality coal-based fuels to markets currently dependent on oil or natural gas. In the American industrial sector, a significant portion of the total boiler capacity in operation in the year 2000 is expected to be composed largely of pre-1980 units. Any substantial near term increase in the use of coal for raising industrial steam will, therefore, have to be accomplished through conversion of existing boilers currently fired by natural gas or oil.

The application of coal or coal-based fuels to industrial boilers originally designed for gas or oil firing presents several technical challenges to the combustion engineer. Specifically, constraints such as carbon conversion efficiency, emissions control, and coal and ash handling must be addressed and resolved. To enable these conversions, significant effort has been made in the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (CE) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE later awarded a contract to the CE/MIT team to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program.

The objective of the program was to develop an advanced coal combustion system for firing beneficiated coal fuels (BCFs) capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. A systematic development program was then conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve these goals. Under Task 1.0,

END

**DATE
FILMED**

2 / 11 / 92