FINAL REPORT
September 1975 - September 1978:

**Radiation Dose to Construction
Workers at Operating Nuclear
Power Plant Sites**
Appendices A - F

G. W. R. Endres
D. B. Shipler

December 1978

Prepared for
the U.S. Nuclear Regulatory Commission
under Contract EY-76-C-06-1830

Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Nuclear Regulatory Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE
for the
UNITED STATES DEPARTMENT OF ENERGY
Under Contract EY-76-C-06-1830

Printed in the United States of America
Available from
National Technical Information Service
United States Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22151

Price: Printed Copy \$ ____*; Microfiche \$3.00

*Pages	NTIS Selling Price
001-025	\$4.00
025-050	\$4.50
051-075	\$5.25
076-100	\$6.00
101-125	\$6.50
126-150	\$7.25
151-175	\$8.00
176-200	\$9.00
201-225	\$9.25
226-250	\$9.50
251-275	\$10.75
276-300	\$11.00

3 3679 00049 2993

FINAL REPORT
SEPTEMBER 1975 - SEPTEMBER 1978:

RADIATION DOSE TO CONSTRUCTION
WORKERS AT OPERATING NUCLEAR
POWER PLANT SITES
APPENDICES A - F

G. W. R. Endres
D. B. Shipler

DECEMBER 1978

Prepared for
Division of Safeguards, Fuel Cycle
and Environmental Research
Environmental Effects Research Branch
U.S. Nuclear Regulatory Commission
Washington, DC 20555
Under DOE Contract EY-76-C-06-1830
NRC Fin No. B2073

PACIFIC NORTHWEST LABORATORY
RICHLAND, WASHINGTON 99352

SECRET

SECRET

UNITED STATES DEPARTMENT OF THE ARMY
HEADQUARTERS, ARMY
WASHINGTON, D. C. 20315

100-100000

100-100000

100-100000

100-100000

INTRODUCTION TO APPENDICES A-F

These appendices contain the dosimetry procedures and details of the personnel and environmental dosimeters used for the Radiation Dose to Construction Workers at Operating Nuclear Power Plant Sites Study. A printout of the computer codes used to analyze dosimeter data is included along with all the raw data obtained. Appendices C through F contain computer output and log-normal plots of dosimetry data for environmental location and construction worker groups.

TABLE OF CONTENTS

APPENDIX A - EQUATIONS AND CALIBRATIONS.	1
APPENDIX B - COMPUTER PROGRAM AND RAW DATA	22
GENERAL INFORMATION FOR APPENDICES C-F	81
APPENDIX C - SITE A EXPOSURE AND DOSE EQUIVALENT DATA.	83
APPENDIX D - SITE B EXPOSURE AND DOSE EQUIVALENT DATA.	114
APPENDIX E - SITE C EXPOSURE AND DOSE EQUIVALENT DATA.	142
APPENDIX F - SITE D EXPOSURE AND DOSE EQUIVALENT DATA.	174

APPENDIX A
EQUATIONS AND CALIBRATIONS

Appendix A contains drawings of the environmental and personnel dosimeters and procedures followed in determining dose equivalent and exposure from the dosimeter readout. Also included are calibration procedures and TLD reader and handling procedures.

ENVIRONMENTAL DOSIMETER

POINT NUMBER	DESCRIPTION
1	ACCESS CAP BLUE BUTYRATE PLASTIC
2	5/8 in. x 3 5/8 in. BLACK BUTYRAE PLASTIC PIPE
3	THIN WALL PLASTIC VIAL
4	UNFILTERED TLD-600 VIAL
5	UNFILTERED TLD-700 VIAL
6	0.010 in. THICK x 3/8 in. DIA x 1 1/2 in. TANTALUM FILTER (SEPARATE DRAWING)
7	SHIELDED TLD-400, TLD-600 AND TLD-700
8	END CAP BLACK BUTYRATE PLASTIC, CEMENT TO SECURE
9	TLD-600, 1/8 in. x 1/8 in. x 0.035 in. LIF RIBBON
10	TLD-700, 1/8 in. x 1/8 in. x 0.035 in. LIF RIBBON
11	TLD-400, 1/8 in. x 1/8 in. x 0.035 in. CaF ₂ : Mn RIBBON
12	PAPER SEPARATOR, ~0.03" THICK
13	POLYURETHANE FOAM TLD HCLDER

PERSONNEL DOSIMETER

PERSONNEL DOSIMETER FILTER DATA

Filter System - Physical Characteristics

Filter: No.	Shield	Diameter in cm	Thickness in cm	Total mg/cm ²
1	Open Window	0.95	0.0	0
2	Cyclac	1.27	0.089	93
	Aluminum		0.064	173
	Mylar		0.007	7
3	Cyclac	1.27	0.051	53
	Tin		0.051	375
	Cadmium		0.051	440
	Mylar		0.007	7
5	Cyclac	1.27	0.051	53
	Tin		0.102	750
	Mylar		0.007	7

DOSE CALCULATION PROCEDURES

The net response, R , of each chip is determined from:

$$R(\text{net}) = R(\text{gross}) - R(\text{background})$$

The response is referred to in counts and is measured in units of charge.

The dose calculations are carried out as follows:

DOSE CALCULATIONS FOR ENVIRONMENTAL DOSIMETERS

TLD-700 - Bare

$$\text{Dose } \gamma = \frac{R(700B)}{K_1}$$

TLD-600 - Bare

$$\text{Dose } N_{th} = \frac{R(600B) - K_2 P_{\gamma} B}{K_3}$$

TLD-700 - Filtered

$$\text{Dose } \gamma = \frac{R_1 (700F)}{K_4}$$

TLD-600 - Filtered

$$\text{Dose } N_{th} = \frac{R(600F) - K_5 D_{\gamma} F}{K_6}$$

TLD-400 - Filtered

$$\text{Dose} = \frac{R(400) - K_7 (D_{N_{th}} R_{400})}{K_8}$$

K_1 , K_4 , and K_8 derived from penetrating gamma exposure.

K_2 , K_5 , TLD-600 gamma response.

K_3 , K_6 , K_7 derived from thermal neutron exposure.

R is the net response of a chip.

R_1 , R_2 , . . . is the response of a chip in position 1, 2, . . . of a dosimeter.

B refers to a bare chip.

F refers to a chip behind or enclosed in a filter.

DOSE CALCULATIONS FOR PERSONNEL DOSIMETERS

$$PEN = \frac{R_2}{K_1}$$

$$NONPEN = PEN + \frac{R_1 - K_2 R_2}{K_3}$$

$$N_{th} = \frac{R_3 - R_4}{K_4}$$

$$N_F = \frac{R_4 - K_6 R_5 - K_5 (R_3 - R_4)}{K_7}$$

K_1 = derived from penetrating photon calibration. Ra gamma.

$K_2 = \frac{R_1}{R_2}$ for penetrating photons.

K_3 = derived from nonpenetrating photon calibration. Uranium or Sr-90.

K_4 = derived from thermal neutron exposure.

$K_5 = R_4/R_3 - R_4$ corrects for back-scattered thermal neutrons.

$K_6 = R_4/R_5$ from penetrating gamma calibration corrects for different photon responses.

K_7 = derived from known fast neutron exposure.

$R_1, R_2, \dots$ is the response of a chip in position 1, 2, . . . of a dosimeter.

DOSIMETER ASSEMBLY, HANDLING,
WEARING, AND EXCHANGE PROCEDURES

- Step 1 - Annealed TLD chips are placed in dosimeters using clean forceps.
NOTE: Work under subdued light.
- Step 2 - Dosimeter cards or capsules (depending on whether they are personnel or environmental dosimeters) are placed in corresponding holders for shipment to a site.
- Step 3 - Appropriate numbers of personnel and environmental dosimeters are logged into notebooks and packaged in a cardboard container for shipment. Ten to twelve dosimeters of the same batch are retained in the lab for calibration and background determinations.
- Step 4 - The packaged dosimeters are shipped to the site via U.S. Air Mail or UPS.
- Step 5 - Upon receipt of the dosimeters on site, 2 personnel and 1 environmental dosimeters are placed in a shield, 3 others are placed in a selected background location on site and 3 others are placed in a background location off site.
- Step 6 - The remaining dosimeters are individually exchanged with corresponding dosimeters on personnel and in the environs of the construction project in accordance with the site monitoring program.
- Step 7 - The exposed dosimeters are packaged along with the background dosimeters of the same batch and mailed or shipped to PNL. Pertinent information shipped with the dosimeters includes: reactor operation history, dosimeter assignments, history of where and when the dosimeters were worn or placed, unusual occurrences or activities during the period and changes in facilities or procedures.
- Step 8 - Personnel dosimeters are to be worn between the waist and shoulder on the front of the body with the identification card facing out. They should be worn only while on the site and stored at a central background location when not being worn.
- Step 9 - Environmental dosimeters are placed at predesignated locations with little or no shielding. They should be placed between 3 and 6 feet above the ground or floor.

- Step 10 - Upon receipt at PNL, place exposed TLDs in a shielded container and hold for 24 hours to allow low energy peak fading to occur.
- Step 11 - Clean TLD chips, if visibly dirty, with trichloroethane. Then rinse with ethyl alcohol and air dry.
- Step 12 - Read out TLD chips.
- NOTE: Work under subdued light as in Step 1.
- Step 13 - Read out background TLD chips (TLDs from the same anneal and batch but not exposed).
- Step 14 - Read out calibration chips for that batch.
- Step 15 - Inspect the TLD chips, discard any that are chipped, cracked or damaged.
- Step 16 - Place TLD chips in clean annealing dishes, making sure the chips are not lying one on top of the other.
- Step 17 - "Pre-exposure" anneal TLD chips at 400°C for one (1) hour in a furnace equipped with a nitrogen gas atmosphere.
- Step 18 - Remove TLD chips from 400°C oven and place directly into an oven pre-heated to 100°C and hold for two (2) hours.
- Step 19 - Remove TLD chips from 100°C oven and place in a shielded container. Cool to room temperature for several hours (usually overnight).
- Step 20 - Store dosimeters in a shielded container or lead cave until ready to expose.
- NOTE: Keep storage time as short as possible to minimize cosmic ray dose accumulation while in storage.

TLD READER PROCEDURES

Readout of TLD Chips

- Step 1 - With drawer closed (heater on), time set at 30 sec, push read button, this is to heat planchet (heating tray). After unit turns off, open drawer.
- Step 2 - When temperature drops to less than 100°C , place TLD chip (using forceps) on planchet in the middle of square pocket.
- Step 3 - Close drawer (softly so as to not dislodge TLD chip from placement).
- Step 4 - When temperature drops to 60°C , push read switch. Temperature should rise, observe monitor scope and temperature meter. As TLD is read out, the response will be shown as a curve tracing on the scope (see attached traces) and the numerical integration of light output will be recorded on the number display of unit B.
- Step 5 - Record all pertinent information of the TLD chip and the total integrated number from the display, record as nC or uC. The scope display is for verification of complete and proper readout. Pertinent information includes TLD batch number, type, position in dosimeter, identification of dosimeter, dates of exposure, date of reading and comments about dosimeter condition or history.
- Step 6 - After readout, open drawer, cool to 100°C , remove TLD chip and repeat steps 2 through 5 for each TLD chip to be read.

TLD READER INSPECTION AND TEST PROCEDURES

This technique is designed around the use of the "HARSHAW" TLD system using the model 2000A and 2000B detector and integrating units. The TLD "chips" ($1/8" \times 1/8" \times 0.035"$) used in this program are also developed by the Harshaw Company.

The procedure is as follows:

A. Reader Set Up

- Step 1 - Set range selector to X0.1 (unit B) in automatic position. Meter reading should be 3-5%. If high or low, readjust current suppression on back of unit B as required.
- Step 2 - Set range selector to X1 position.
- Step 3 - Set time period to 60 sec.
- Step 4 - With drawer closed (unit A) (heater on), push read button (unit B). Observe temperature meter, set heater temperature control (unit A) to hold temperature at 400°C .
- Step 5 - Check controls T1 and T2. For TLD-700 LiF and 600 LiF, T1 should be at 110°C and T2 should be at 260°C . TLD-400 - T1 should be at 110° and T2 should be at 360° .
- Step 6 - Repeat Step 4. When temperature is adjusted and heater shuts off, scale display should read 0.008 to 0.015 nC.
- Step 7 - Pull drawer on Unit A all the way open (heater off).
- Step 8 - Push read switch (unit B), after 60 sec time period, scale display should read the desired light source number (built in source indicated on tag above display). If not, readjust high voltage (unit B) to obtain correct light source number.
- Step 9 - After correct light source reading is obtained, set time period (Unit B) to 30 sec.
- Step 10 - Close drawer (unit A) heater is on, push read button (unit B) Let run through a heat cycle.
- Step 11 - Turn power on to storage monitor scope, store and erase buttons out. Now push STORE button in, scope will light up. Next push ERASE button, scope will turn dark.

Step 12 - Push read button again (unit B). A green dot and tracing should appear on the scope showing the temperature and read-out response of the TLD reader.

Step 13 - The system should now be calibrated and ready to start reading TLD "chips".

PROCEDURE FOR
CALIBRATING GAMMA SPECTROMETER

- 1) The spectrometer is to be used with a high quality electronics system, low noise, wide gain range, and adjustable electronic time constant.
- 2) When calibrating the detector, one really is calibrating the whole system.
- 3) Connect detector to bias supply and pre-amplifier. Carefully raise bias level to that specified by the manufacturer.
- 4) Select standard photon sources with energies that cover the range of interest. These sources have very accurately determined activities of radionuclides.
- 5) The linearity and energy calibration is set by adjusting coarse and fine gain and coarse and fine zero controls on the multichannel analyzer and amplifier until the energy per channel is essentially constant over the range of interest. Typical standard sources used for this procedure are: ^{60}Co , ^{24}Na , ^{137}Cs , ^{203}Hg , ^{241}Am , ^{56}Co . There are many others which could be used.
- 6) The same standard sources can also be used to determine the efficiency of the spectrometer with the sources placed at specified distances away from the detector. At a known distance the number of photons intersecting the cross sectional area of the detector can be determined from the activity of the source and the geometry. The numbers of photons emitted at various energies can be determined from the decay scheme of the particular radionuclide.
- 7) The net number of counts in each photo peak is determined from the measured spectrum after subtracting the background. The efficiency is calculated by dividing the net counts in the photo peak by the number of photons which entered the detector.

PROCEDURE FOR TLD AND
RATEMETER CALIBRATION

Step 1 - A random selection of ten (10) personnel dosimeters and three (3) environmental dosimeters are taken from each set to be sent to a site. This selection is then divided into the following groups and exposed:

Personnel dosimeters:

- 2 ea for 1-R ^{226}Ra gamma
- 2 ea for 2-Rad ^{90}Sr - ^{90}Y beta
- 2 ea for 50-m Rem $^{239}\text{PuBe}$ thermal neutron
- 2 ea for 1-Rem ^{252}Cf fast neutron
- 2 ea for calibration background

Environmental dosimeters:

- 1 ea for 1-R ^{226}Ra gamma
- 1 ea for 50-m Rem $^{239}\text{PuBe}$ thermal neutron
- 1 ea for calibration background

Step 2 - Calibration exposures are as follows:

- A. $^{226}\text{Radium}$ gamma - 1-R exposure
1. two (2) personnel and one (1) environmental dosimeter are labeled as to type and amount of exposure to be given, the site to which sent and the date exposed.
 2. the dosimeters are then fixed to a thin aluminum stand to be held vertically.
 3. the dosimeters are then placed on a low-scatter styrofoam table constructed one (1) meter above the concrete floor.
 4. the dosimeters are arranged in an arc precisely one (1) meter from the center of the radium source holder.
 5. at the same distance from the source, an NBS cross calibrated Victoreen model 555 Radacon ionization chamber is placed.
 6. The exposure time is set to two (2) hours and thirty-seven (37) minutes. Zero and set Radacon for exposure measurement.
 7. start exposure. At this point, the one-half (1/2) gm ^{226}Ra source (ID No. 602L) is vacuum lifted from the cask to a preset location in the source holder then held for the exact preset time of exposure.

8. At the conclusion of the exposure, the radium source is lowered to the nesting cask.
9. The Radacon is then checked to verify the exposure given to the dosimeters.

B. ^{90}Sr - ^{90}Y Beta 2-Rad exposures

Steps 1, 2, and 3 are the same as for radium gamma exposure.

4. Place the dosimeters at precisely 50 cm from the source holder.

NOTE: The dose rate was originally determined with the extrapolation chamber and given periodic decay correction. As of 9/21/76, the dose rate was calculated to be 129 mrad/hr at the surface of the .010 aluminum filter.

5. Expose for 15.5 hours.

C. $^{239}\text{PuBe}$ Thermal Neutrons - 50 m-Rem exposure

1. Same as for radium exposure.
2. This exposure is made in the sigma pile, in which a 80 gm $^{239}\text{PuBe}$ source #M1221 is mounted with 85 cm of graphite between source and the dosimeters. Calibration of the pile at 85 cm was done via NBS calibrated gold foils and a long counter.
3. Place the dosimeters at the 85 cm location for 8 hours and 20 minutes for a 50 mRem exposure.

D. ^{252}Cf fast neutrons - 1 Rem exposure

1. Same as for radium exposure.
2. This exposure is made using a 500 ugm ^{252}Cf source. This source was calibrated by comparison with the NBS calibrated $^{239}\text{PuBe}$ source #M1221 using the long counter.
3. The dosimeters are mounted on a 18 cm thick polyethelene phantom backing at 150 cm from the ^{252}Cf source.

E. Calibration Background

1. Same as for radium exposure

2. These dosimeters are made and carried through the calibration process except no exposure is given so when readout will connect for any extraneous exposure received to the to the set.

Step 3 - Following the calibration exposure, the dosimeters are placed in a low background lead shielded cave to be held for one (1) month.

Step 4 - As in the TLD reading procedure, the dosimeters are then readout in the Harshaw 2000A and B reader for the dose calculation procedure with the TLD readings from the sample site.

PHOTON SOURCES

BETA SOURCES

THERMAL NEUTRON SOURCES

FAST NEUTRON SOURCES

PACKAGING, SHIPPING, RECEIVING,
STORING AND MARKING DOSIMETERS

1. Packaging

All dosimeters are packaged for shipment in sturdy cardboard boxes that will not be crushed by normal handling. Filler material is used to keep the dosimeters from moving against one another and the packages are taped to preclude coming apart.

2. Shipping

Packages containing dosimeters are shipped via U.S. mail or United Parcel Service. Once packages are shipped, the receiver is notified by letter or telephone that the package is in transit. Follow up telephone calls are made to confirm delivery of the dosimeters. All shipping dates and confirmation contacts are logged to assure continuity in the program.

3. Receiving

All dosimeters received at PNL are logged in and placed in shielded containers for processing. The sender is notified of receipt. The dosimeters are inventoried and pertinent information concerning their use and exposure is recorded.

4. Storing

All dosimeters are stored in a clean, darkened place in an orderly manner between handlings. Dosimeters which have been annealed for use on sites or exposed for calibration are stored in shielded containers between processing.

5. Marking

Though all of the TLD chips are the same size, the TLD 400s are opaque white while the TLD 600s and 700s are translucent clear. To distinguish the latter two kinds of chips, the TLD 600s are marked on one edge with a red dye.

All personnel dosimeters are exactly alike and prior to assignment at a site, no distinction is necessary. Once assigned, each dosimeter is marked for identification and that marking follows the dosimeter through processing to annealing for reuse. The same is true for all environmental dosimeters.

APPENDIX B

COMPUTER PROGRAM AND RAW DATA

This appendix contains a listing of the computer programs used to analyze both the personnel dosimeter and environmental dosimeter data. Raw data from all four sites for all the dosimeter exchange cycles are also included. Calibration constants are shown at the top of each set of data in sequential order - K_1 , K_2 , . . . , etc.

For the environmental dosimeters the readings of the five thermoluminescent chips in each dosimeter section are averaged before entering the data into the computer. Thus, for each environmental dosimeter, there are five numbers for computer input corresponding to the five equations given in Appendix A.

For the environmental dosimeter, the data sequence is: TLD-700(bare), TLD-600(bare), TLD-700(filtered), TLD-600(filtered), and TLD-400(filtered). The eight calibration constants required for analysis of environmental data are listed on the first line under the heading.

For the personnel dosimeters, all readings on individual TLDs are given. The seven required calibration constants are listed under the heading line for each data set. Two TLDs were placed under each filter. For computer analysis, the sequence of data listing is: 1, 2, 5, 3, 4.

SITE A

ENVIRONMENTAL DOSIMETERS - 5/19 TO 7/14/76

7.989	7.496	434	9.141	8.923	417	27.3	92.3
25							
STA#2	.209	.253	.213	.266	2.527		
STA#3	.184	.212	.195	.208	2.251		
STA#4	.174	.201	.181	.203	2.252		
STA#5	.447	.472	.492	.508	5.422		
STA#6	.163	.189	.174	.196	2.099		
STA#8	.244	.262	.340	.360	3.750		
STA#9	.226	.249	.245	.262	2.872		
STA#10	.152	.172	.163	.189	1.981		
STA#11	.210	.242	.227	.262	2.672		
STA#12	.121	.147	.121	.151	1.478		
STA#13	.214	.264	.248	.279	2.771		
STA#14	3.981	4.203	4.568	4.738	51.8		
STA#15	.184	.198	.199	.216	2.213		
STA#16	.148	.169	.154	.174	1.813		
STA#17	.148	.172	.164	.174	1.880		
STA#18	.164	.187	.168	.199	1.861		
STA#19	1.326	1.857	1.002	1.511	13.0		
STA#20	.232	.208	.185	.211	1.930		
STA#21	.661	.822	.555	.779	7.374		
STA#22	2.316	2.432	2.704	2.721	31.5		
STA#23	.280	.342	.321	.355	3.64		
STA#24	.197	.221	.183	.247	2.039		
STA#25	.201	.234	.196	.210	2.333		
BKG#37	.213	.236	.236	.254	2.666		
BKG#92	.211	.235	.235	.260	2.523		

SITE A

ENVIRONMENTAL DOSIMETERS - 7/14 TO 9/25/76

7.154	7.414	435	8.428	8.439	373	21.0	22.2
20							
STA#2	.325	.385	.349	.401	4.134		
STA#4	.303	.332	.322	.353	3.320		
STA#5	.614	.628	.654	.656	8.075		
STA#6	.289	.278	.260	.288	3.012		
STA#8	.372	.403	.416	.440	5.039		
STA#9	.354	.371	.375	.407	4.736		
STA#10	.259	.301	.273	.309	3.271		
STA#11	.211	.233	.230	.266	2.622		
STA#12	.335	.386	.382	.425	4.575		
STA#13	.362	.430	.409	.473	5.200		
STA#14	5.821	6.424	6.249	7.168	85.0		
STA#16	.242	.268	.269	.290	3.166		
STA#17	.255	.274	.259	.282	3.117		
STA#18	.262	.291	.273	.279	3.146		
STA#19	2.198	3.340	1.877	2.695	26.5		
STA#21	1.081	1.462	1.003	1.413	14.8		
STA#22	1.066	1.103	1.152	1.263	15.6		
STA#23	.414	.451	.485	.521	5.673		
STA#24	.324	.341	.352	.375	4.397		
STA#25	.400	.386	.342	.377	4.003		

SITE A
ENVIRONMENTAL DOSIMETERS - 9/25 TO 12/1/76

7.651	7.501	456	8.733	8.151	370	24.8	92.8
24							
STA#2	.252	.324	.263	.314	2.966		
STA#3	.241	.265	.255	.269	2.644		
STA#4	.238	.293	.261	.279	2.754		
STA#5	.221	.241	.254	.252	2.681		
STA#6	.198	.219	.218	.224	2.274		
STA#8	.310	.330	.330	.328	3.470		
STA#9	.496	.508	.489	.494	6.173		
STA#10	.197	.222	.204	.224	2.265		
STA#11	.292	.325	.305	.314	3.337		
STA#12	.140	.170	.149	.167	1.595		
STA#13	.294	.338	.332	.361	3.888		
STA#14	9.633	10.1	10.0	10.0	124.6		
STA#15	.227	.261	.233	.252	2.757		
STA#16	.174	.200	.185	.203	1.995		
STA#17	.180	.198	.202	.203	2.030		
STA#18	.214	.238	.237	.239	2.467		
STA#19	2.046	3.316	1.473	2.293	21.8		
STA#20	.227	.271	.235	.259	2.699		
STA#21	1.027	1.502	.856	1.121	12.5		
STA#22	1.118	1.185	1.182	1.213	15.3		
STA#23	.569	.599	.596	.613	7.364		
STA#24	.193	.217	.206	.218	2.279		
STA#25	.296	.313	.294	.316	3.537		
STA#26	.418	.460	.319	.328	3.552		

SITE A
ENVIRONMENTAL DOSIMETERS - 12/1/76 TO 3/2/77

7.196	6.700	393	7.982	7.798	362	29	86.2
23							
STA#2	.370	.437	.353	.383	3.422		
STA#3	.317	.323	.277	.309	2.647		
STA#4	.317	.351	.333	.368	2.909		
STA#5	1.656	1.750	1.776	1.792	16.2		
STA#6	.329	.353	.315	.348	2.892		
STA#8	.434	.425	.412	.427	3.691		
STA#9	.675	.671	.627	.673	6.277		
STA#10	.263	.267	.262	.231	2.330		
STA#11	.193	.195	.177	.204	1.831		
STA#12	.257	.267	.262	.270	2.346		
STA#13	.374	.396	.396	.434	3.554		
STA#14	23.4	23.8	24.5	25.3	237.0		
STA#15	.282	.308	.297	.321	2.601		
STA#16	.225	.242	.216	.248	1.931		
STA#17	.230	.252	.230	.238	1.977		
STA#18	.269	.272	.268	.301	2.263		
STA#20	.287	.331	.320	.344	2.822		
STA#21	1.372	1.740	1.246	1.536	11.5		
STA#23	11.8	11.2	12.6	12.0	77.1		
STA#24	.476	.401	.512	.422	4.332		
STA#25	.619	.540	.509	.476	4.404		
STA#26	.413	.388	.417	.401	3.653		
STA#27	.344	.312	.357	.347	3.272		

SITE A

ENVIRONMENTAL DOSIMETERS - 3/2/77 TO 6/22/77

7.457	7.539	452	8.424	8.455	400	17	72.2
24							
STA#1	.433	.472	.446	.441	3.683		
STA#4	.330	.345	.390	.352	3.007		
STA#5	4.308	4.315	4.430	4.293	38.500		
STA#6	.501	.514	.517	.507	4.293		
STA#6	.470	.492	.508	.489	4.017		
STA#9	10.800	10.800	9.694	9.120	90.500		
STA#10	.266	.311	.326	.307	2.372		
STA#11	.411	.425	.428	.447	3.269		
STA#12	.188	.220	.220	.231	1.621		
STA#13	.445	.478	.499	.465	3.726		
STA#14	33.500	33.400	36.100	35.200	295.000		
STA#15	.349	.345	.373	.356	2.749		
STA#16	.271	.297	.292	.296	2.154		
STA#17	.287	.332	.298	.292	2.089		
STA#19	1.685	2.384	1.334	1.324	11.500		
STA#20	.338	.334	.362	.341	2.930		
STA#21	.927	1.199	.823	1.015	6.612		
STA#22	11.700	12.100	12.700	12.700	94.200		
STA#23	19.600	19.400	23.000	20.300	184.400		
STA#24	.263	.282	.259	.290	2.137		
STA#25	.392	.330	.329	.354	2.139		
STA#26	.447	.475	.445	.442	3.335		
STA#27	.298	.337	.325	.353	2.344		
STA#28	.541	.540	.551	.534	4.068		

SITE A

ENVIRONMENTAL DOSIMETERS - 6/20 TO 8/15/77

7.723	7.837	499	7.649	8.267	455	11	53.6
22							
#2	.390	.561	.391	.533	2.993		
#3	.301	.365	.311	.377	2.174		
#5	.194	.248	.201	.266	1.340		
#6	1.149	1.159	1.095	1.095	8.062		
#7	.358	.567	.389	.568	4.350		
#10	.279	.367	.313	.375	3.306		
#11	.406	.485	.404	.485	2.627		
#12	10.637	10.480	12.120	12.220	73.900		
#13	.497	.389	.511	.606	3.037		
#14	45.320	46.840	45.720	51.960	347.500		
#15	.375	.445	.389	.462	2.714		
#17	.280	.364	.302	.360	2.128		
#18	.293	.355	.305	.379	2.242		
#19	4.604	7.826	3.165	5.987	26.880		
#20	.319	.375	.347	.411	2.326		
#21	2.592	3.775	2.078	3.281	17.000		
#22	4.993	5.312	5.686	3.105	25.140		
#23	56.400	62.200	63.860	70.420	429.300		
#24	.333	.392	.364	.403	2.407		
#26	.564	.607	.600	.575	0.000		
#27	.304	.377	.331	.379	2.807		
#28	.299	.359	.307	.382	2.371		

SITE A

ENVIRONMENTAL DOSIMETERS - 8/15 TO 12/20/77

7.926 7.112 378 8.755 8.184 315 13 51.6
23

#1	.460	.503	.475	.472	2.690
#2	.285	.320	.311	.322	2.081
#3	4.174	4.054	4.422	4.350	30.660
#4	.115	.160	.129	.164	.801
#5	.384	.400	.399	.431	2.745
#6	1.443	1.499	1.239	1.246	10.375
#7	.304	.348	.298	.340	1.969
#8	.384	.413	.392	.408	2.660
#9	.245	.278	.244	.286	1.657
#10	.398	.441	.418	.453	2.322
#11	19.600	19.260	20.380	20.160	153.460
#12	.307	.344	.324	.349	2.224
#13	.262	.294	.268	.289	1.772
#14	.246	.298	.268	.289	1.693
#15	.262	.327	.286	.296	1.976
#16	2.490	3.513	1.685	2.654	13.080
#17	1.212	1.524	1.007	1.367	8.260
#18	3.631	3.598	3.930	3.671	26.980
#19	30.660	30.400	32.900	31.400	235.380
#20	.295	.322	.291	.309	1.954
#21	.294	.328	.324	.343	1.999
#22	.309	.330	.327	.337	2.088
#23	.383	.422	.414	.436	2.605

SITE B

ENVIRONMENTAL DOSIMETERS - 7/15 TO 9/17/76

7.154 7.414 435 8.428 8.439 373 21 82.2

23

E-130028 .197 .222 .201 .222 2.375

E-132029 .236 .239 .218 .232 2.437

E-129051 .252 .252 .218 .237 2.586

E-115052 .227 .230 .200 .224 2.472

E-118055 .251 .239 .333 .268 2.711

E-135053 .195 .213 .198 .227 2.393

E-131056 .415 .438 .425 .447 5.554

E-119057 .228 .247 .221 .240 2.662

E-121060 .311 .335 .328 .342 3.933

E-119061 .229 .252 .217 .247 2.729

E-114000 .879 .957 .761 1.038 12.6

E-116000 .197 .224 .202 .224 2.444

E-120000 .231 .252 .232 .261 2.876

E-123000 .217 .225 .211 .228 2.637

E-124000 .213 .237 .211 .241 2.468

E-127000 .213 .234 .207 .245 2.728

E-128000 .366 .402 .356 .417 4.900

E-133000 .409 .435 .422 .449 5.652

E-117200 .208 .237 .220 .255 2.687

E-122200 .220 .233 .213 .254 2.543

E-125200 .239 .240 .219 .237 2.641

E-126200 .233 .250 .207 .227 2.622

E-136200 .225 .244 .213 .241 2.640

SITE B

ENVIRONMENTAL DOSIMETERS - 9/18 TO 11/29/76

8.103 7.932 532 9.055 8.912 478 21 39.3

21

#58 .211 .273 .251 .266 3.680

#66 .252 .270 .244 .253 2.651

#68 .333 .378 .343 .346 3.657

#69 .172 .219 .213 .226 2.317

#70 .269 .287 .273 .271 3.331

#77 .213 .271 .228 .236 2.556

#79 .222 .274 .223 .242 3.477

#82 .206 .242 .224 .232 2.454

#87 1.942 2.123 1.940 1.921 24.3

#90 .323 .396 .321 .326 3.872

#95 .242 .288 .265 .263 2.925

#96 .313 .358 .252 .263 3.030

#97 .200 .234 .221 .227 2.516

#103 .498 .553 .490 .493 6.232

#134 5.752 6.277 6.654 7.236 92.5

#170 .243 .271 .259 .273 3.033

#171 .221 .248 .233 .219 2.532

#173 .276 .318 .277 .285 3.014

#175 .237 .266 .257 .249 2.888

#32 .219 .277 .267 .271 2.795

#52 .220 .281 .246 .277 2.610

-SITE B

ENVIRONMENTAL DOSIMETERS - 11/29/76 TO 2/14/77

7.168 7.379 403 9.025 8.669 340 13 71.8

21

#58 .239 .228 .226 .232 1.617

#66 .239 .233 .252 .239 1.684

#68 .364 .369 .386 .360 2.992

#69 .187 .158 .193 .191 1.399

#95 .275 .280 .362 .345 2.084

#79 .187 .199 .205 .217 1.561

#82 .228 .196 .247 .206 1.634

#87 3.495 3.239 3.563 3.546 28.5

#90 .538 .538 .538 .481 4.290

#96 .185 .179 .197 .183 1.381

#97 .180 .183 .205 .201 1.415

#103 .311 .311 .331 .336 2.686

#134 6.632 6.947 6.359 5.575 53.9

#170 .250 .241 .280 .268 1.936

#171 .235 .249 .220 .207 1.456

#173 .219 .219 .258 .238 1.619

#175 .196 .193 .216 .214 1.630

#201 .232 .228 .225 .223 1.815

#77 .227 .213 .208 .220 1.486

#38 .206 .216 .242 .219 1.500

#52 .223 .212 .230 .225 1.472

5180 SITE B

5190 ENVIRONMENTAL DOSIMETERS - 2/14 TO 4/8/77

5195 3.042 7.173 458 5.932 7.791 384 20 75.0

520021

5210170HH .173 .191 .186 .197 1.476

522003257 .177 .195 .196 .190 1.505

523008760 .301 .292 .310 .293 2.349

524007928 .155 .165 .166 .171 1.201

525009581 .215 .229 .220 .212 1.703

526013429 .184 .200 .218 .203 1.549

527010555 .167 .176 .176 .175 1.339

528003837 3.033 2.733 3.033 2.733 23.521

529007705 .283 .317 .284 .277 2.156

530009732 .137 .168 .163 .167 1.321

531000854 .131 .171 .170 .190 1.367

532000356 .413 .422 .421 .313 3.237

533017122 4.666 4.700 4.817 4.456 38.900

534006981 .204 .221 .224 .213 1.808

5350173AR .175 .196 .186 .191 1.453

536000207 .190 .202 .206 .208 1.620

537009653 .175 .176 .186 .177 1.377

538006851 .181 .183 .202 .184 1.431

539008252 .194 .213 .189 .196 1.651

540005301 .172 .190 .181 .196 1.357

541006602 .177 .191 .189 .193 1.380

SITE B

ENVIRONMENTAL DOSIMETERS - 4/4 TO 6/8/77

6.952	7.592	424	7.556	7.349	345	21	56.6
22							
#3	3.961	4.393	3.868	4.436	321.020		
#4	.200	.210	.202	.215	1.435		
#5	.231	.247	.229	.245	1.753		
#6	.226	.236	.223	.244	1.621		
#7	.206	.219	.219	.221	1.751		
#8	.212	.233	.234	.242	1.875		
#9	.230	.242	.256	.253	2.009		
#10	.208	.244	.238	.243	2.018		
#11	.420	.463	.423	.456	3.746		
#12	.233	.255	.254	.259	2.076		
#13	1.341	1.467	1.376	1.290	12.500		
#14	.309	.334	.338	.343	2.785		
#15	.230	.273	.262	.261	2.161		
#16	.234	.260	.301	.278	2.418		
#17	.348	.380	.299	.310	2.644		
#18	.265	.285	.272	.277	2.354		
#19	.239	.259	.236	.246	1.876		
#20	.209	.254	.236	.233	2.010		
#21	.214	.249	.243	.240	1.674		
#CON1	.223	.255	.252	.250	2.086		
#CON2	.226	.265	.239	.257	1.971		
#CON3	.237	.267	.245	.246	1.967		

SITE B

ENVIRONMENTAL DOSIMETERS - 6/4 TO 6/8/77 TO 9/1 TO 9/10/77

6.955	6.401	435	8.102	8.166	377	19	48.9
20							
#3	4.207	4.581	4.244	4.930	33.150		
#4	.192	.255	.209	.264	1.737		
#5	.236	.301	.250	.315	2.003		
#6	.229	.279	.241	.296	1.950		
#7	.206	.275	.222	.274	1.521		
#8	.213	.263	.230	.297	1.802		
#9	.213	.267	.224	.286	1.877		
#10	.218	.278	.237	.292	1.861		
#11	.455	.500	.451	.534	3.636		
#12	.215	.289	.238	.297	1.862		
#13	1.754	1.785	1.734	1.866	12.100		
#14	.369	.420	.401	.444	3.118		
#15	.267	.330	.273	.319	2.147		
#17	.295	.364	.308	.346	2.362		
#18	.285	.332	.276	.352	2.301		
#19	.228	.282	.235	.285	1.924		
#20	.246	.308	.250	.323	1.926		
#21	.220	.282	.241	.299	1.814		
#22	.238	.287	.247	.301	1.965		
#23	.236	.258	.219	.293	1.893		

SITE 8

ENVIRONMENTAL DOSIMETERS - 9-1 TO 9-10-77 TO 11-1-77

7.593 7.655 516 8.802 8.592 440 16 52.9

18

#3 3.000 3.461 3.071 3.551 21.520

#4 .134 .185 .141 .185 1.095

#5 .182 .230 .186 .249 1.440

#7 .145 .186 .154 .177 1.224

#8 .155 .195 .163 .198 1.194

#9 .156 .213 .167 .214 1.341

#10 .151 .197 .159 .206 1.264

#11 .295 .371 .307 .382 2.186

#12 .154 .219 .166 .221 1.305

#13 .484 .551 .463 .541 3.512

#14 .203 .251 .204 .261 1.579

#15 .188 .244 .195 .243 1.525

#16 .183 .224 .168 .232 1.662

#18 .204 .262 .206 .259 1.620

#19 .190 .223 .176 .230 1.383

#20 .167 .231 .180 .232 1.319

#21 .159 .212 .174 .268 1.521

UNUSE .164 .224 .162 .222 1.406

SITE C
 ENVIRONMENTAL DOSIMETERS - 6/2 TO 10/20/76
 7.154 7.414 435 8.428 8.439 373 21 82.2
 12
 STA#1 .536 .622 .507 .591 5.590
 STA#16 .543 .602 .533 .591 5.380
 STA#4 4.012 4.333 4.061 4.136 45.1
 STA#13 .566 .617 .561 .607 6.085
 STA#2 .610 .666 .621 .647 6.482
 STA#17 .509 .527 .494 .477 4.998
 STA#14 .480 .559 .495 .498 5.171
 STA#10 .677 .773 .679 .794 7.676
 STA#7 .503 .575 .693 .739 7.127
 STA#15 .384 .488 .470 .398 3.863
 STA#24 .224 .270 .252 .274 2.729
 STA#23 .233 .271 .263 .261 2.652

SITE C
 ENVIRONMENTAL DOSIMETERS - 10/20/76 TO 1/21/77
 7.702 6.733 413 3.992 8.442 359 24 79.9
 22
 STA#1 .262 .275 .253 .295 2.425
 STA#3 .252 .261 .264 .262 2.356
 STA#4 2.060 1.881 1.992 1.964 18.9
 STA#5 .221 .230 .231 .237 2.144
 STA#6 .240 .246 .276 .258 2.197
 STA#7 .342 .341 .374 .379 3.323
 STA#9 .191 .237 .261 .209 1.795
 STA#10 .367 .424 .375 .397 3.436
 STA#12 .211 .237 .227 .233 2.010
 STA#13 .210 .225 .218 .221 2.013
 STA#14 .214 .230 .224 .234 1.998
 STA#15 .201 .210 .203 .228 1.731
 STA#16 .254 .296 .249 .285 2.514
 STA#17 .225 .226 .233 .271 2.244
 STA#18 .251 .271 .260 .248 2.324
 STA#19 .323 .373 .343 .369 3.095
 STA#20 .223 .242 .247 .249 2.171
 STA#21 .219 .230 .227 .235 2.140
 STA#22 .196 .222 .211 .215 1.915
 STA#23 .161 .197 .169 .237 1.612
 STA#24 .222 .233 .242 .251 2.307
 UNUSED .179 .225 .183 .272 1.771

SITE C
ENVIRONMENTAL DOSIMETERS - 1/21 TO 4/12/77
7.019 7.026 456 8.216 8.084 387 19 74.3
20

STA#1	.316	.402	.311	.371	2.511
STA#2	.317	.307	.317	.440	2.278
STA#3	.308	.370	.316	.367	2.464
STA#5	.279	.335	.292	.347	2.289
STA#6	.292	.358	.292	.339	2.181
STA#7	.382	.430	.396	.455	2.996
STA#8	.310	.342	.309	.369	2.267
STA#9	.269	.347	.291	.362	2.157
STA11	.326	.378	.315	.359	2.359
STA12	.262	.337	.272	.347	2.019
STA13	.282	.344	.281	.340	2.144
STA14	.252	.310	.273	.325	1.969
STA15	.263	.339	.266	.326	2.018
STA16	.296	.371	.302	.380	2.234
STA17	.323	.353	.321	.361	2.134
CON-1	.247	.318	.252	.324	1.858
CON-2	.283	.284	.302	.357	2.254
UNU-3	.135	.180	.152	.180	1.025
UNU-4	.144	.174	.154	.192	1.042

SITE C
ENVIRONMENTAL DOSIMETERS - 4/12 TO 7/12/77
7.996 7.759 502 8.924 8.264 439 14 72.7
21

#1	.315	.389	.319	.383	2.310
#2	.380	.453	.340	.392	2.616
#3	.325	.370	.333	.393	2.273
#4	3.363	3.530	3.836	3.626	26.3
#6	.290	.364	.312	.344	2.117
#7	.413	.488	.439	.478	3.053
#8	.279	.351	.299	.337	2.158
#9	.272	.346	.283	.337	1.986
#10	.370	.433	.415	.475	2.898
#11	.303	.376	.305	.391	2.283
#12	.267	.344	.349	.331	2.043
#13	.288	.376	.311	.378	2.241
#14	.274	.356	.292	.338	2.031
#15	.275	.347	.294	.346	2.115
#16	.323	.400	.327	.379	2.403
#17	.286	.372	.303	.359	2.112
#18	.318	.401	.331	.393	2.412
#19	.241	.307	.243	.306	1.791
#20	.300	.363	.298	.363	2.130

SITE C
ENVIRONMENTAL DOSIMETERS - 7/12 TO 10/20/77

	7.518	7.838	413	9.273	9.103	329	16	54.3
20								
#1	.375	.436	.389	.475	2.589			
#2	.534	.605	.400	.437	3.023			
#3	.401	.446	.401	.440	2.618			
#4	3.837	4.442	3.957	4.289	26.206			
#5	.371	.455	.376	.422	2.369			
#6	.357	.387	.386	.418	2.510			
#7	.383	.422	.378	.403	2.466			
#8	.346	.396	.363	.421	2.383			
#9	.334	.408	.345	.466	2.252			
#10	.422	.472	.406	.464	2.795			
#11	.404	.430	.464	.431	2.632			
#12	.349	.453	.382	.455	2.330			
#13	.345	.410	.381	.422	2.267			
#14	.340	.372	.364	.423	2.406			
#15	.353	.387	.337	.388	2.202			
#16	.384	.471	.393	.466	2.353			
#17	.335	.385	.363	.390	2.286			
#18	.373	.436	.385	.423	2.523			
#19	.217	.290	.280	.293	1.410			
#N20	.279	.325	.302	.352	2.036			

SITE C
ENVIRONMENTAL DOSIMETERS - 10/20/77 TO 1/12/78

	7.752	7.194	452	9.430	5.646	302	14	47.1
18								
#1	.316	.364	.323	.376	1.902			
#2	.543	.606	.256	.323	2.273			
#3	.308	.369	.297	.348	1.567			
#4	5.736	5.590	5.559	5.797	35.480			
#5	.293	.344	.268	.335	1.672			
#6	.357	.519	.332	.484	1.756			
#7	.406	.458	.436	.494	2.711			
#9	.406	.332	.280	.322	1.603			
#10	.381	.469	.407	.474	2.517			
#11	.297	.332	.296	.357	1.692			
#12	.255	.307	.279	.306	1.622			
#13	.267	.346	.289	.308	1.704			
#14	.258	.296	.287	.331	1.632			
#15	.260	.311	.261	.315	1.657			
#16	.293	.384	.336	.366	1.857			
#17	.289	.356	.301	.333	1.760			
#18	.285	.349	.312	.342	1.682			
#19	.204	.282	.214	.276	1.375			

SITE D
ENVIRONMENTAL DOSIMETERS - 9/1 TO 11/23/76

8.103	7.932	532	9.085	3.912	478	21	89.6
17							
1-199	.387	.770	.393	.694	4.841		
2-194	.322	.598	.339	.662	3.846		
3-198	.261	.555	.280	.517	3.315		
4-192	.270	.567	.292	.513	3.175		
5-195	.300	.599	.318	.537	3.862		
6-189	.282	.622	.304	.545	3.661		
7-193	.273	.555	.293	.526	3.698		
8-196	.238	.518	.258	.471	3.170		
9-197	.279	.581	.289	.504	3.409		
10190	.248	.531	.277	.485	3.499		
11188	.470	.841	.466	.755	5.213		
12191	.269	.693	.305	.652	3.506		
13185	.544	1.668	.549	1.314	7.044		
14132	.530	1.563	.568	1.314	6.792		
15179	.705	1.963	.649	1.590	9.283		
C-166	.138	.7330	.160	.6720	1.655		
C-164	.140	.694	.170	.682	1.700		

SITE D
ENVIRONMENTAL DOSIMETERS - 2/15/77 TO 3/30/77

7.787	7.414	440	3.552	5.976	400	22	76.4
25							
078	.282	.429	.294	.405	2.472		
161	.236	.277	.247	.311	2.132		
101	.195	.240	.228	.260	1.800		
191	.202	.232	.214	.246	1.729		
198	.239	.291	.242	.285	2.046		
196	.220	.284	.246	.335	1.932		
199	.205	.254	.204	.240	1.660		
190	.196	.227	.200	.241	1.573		
195	.206	.242	.212	.248	1.671		
182	.210	.249	.223	.261	1.670		
192	.305	.315	.472	.442	2.282		
164	.213	.261	.238	.275	1.766		
185	.210	.261	.224	.263	1.701		
188	.433	.489	.412	.428	3.477		
166	.382	.433	.407	.427	3.281		
179	.723	.787	.677	.745	6.357		
194	.821	1.059	.717	.982	7.244		
109	2.132	2.129	2.335	2.220	20.400		
107	.788	.858	.767	.832	7.007		
102	.442	.567	.439	.568	3.682		
189	.816	.924	.920	1.035	7.958		
193	.819	1.008	.958	1.094	8.518		
226	.707	1.162	.711	1.132	8.349		
197	.241	.380	.269	.209	2.219		
106	.199	.238	.219	.248	1.786		

SITE D
ENVIRONMENTAL DOSIMETERS - 3/30 TO 5/26/77

6.824	7.656	423	7.932	7.933	344	14	52.9
24							
#1	.339	.483	.345	.425	3.389		
#2	.277	.354	.307	.316	5.097		
#3	.234	.273	.251	.272	2.597		
#4	.225	.265	.238	.257	2.165		
#5	.265	.306	.275	.287	2.496		
#6	.250	.310	.292	.307	2.486		
#7	.229	.274	.248	.268	2.408		
#8	.209	.236	.221	.242	1.913		
#9	.232	.275	.252	.260	2.116		
#10	.229	.270	.256	.267	2.223		
#11	.389	.370	.427	.475	3.891		
#12-A	.247	.290	.270	.277	2.211		
#12-B	.236	.295	.260	.269	2.144		
#14	.392	.487	.370	.413	3.256		
#15	.666	.820	.560	.616	5.562		
#16-M	1.392	1.722	1.226	1.471	12.700		
#17-M	1.700	2.203	1.941	1.991	17.530		
#18-M	.745	.874	.731	.760	7.073		
#19-M	.421	.575	.424	.540	3.711		
#15-M	.951	1.183	1.095	1.224	9.361		
#14-M	.956	1.239	1.125	1.222	9.421		
#13-M	.733	1.372	.677	1.111	6.529		
CONT.	.203	.227	.231	.218	1.753		
CONT.	.201	.241	.210	.223	1.720		

SITE O
ENVIRONMENTAL DOSIMETERS - 5/26 TO 7/22/77

7.182	7.165	416	7.689	7.794	366	17	64.4
21							
#1	.304	.370	.276	.352	2.124		
#2	.275	.276	.291	.298	1.934		
#3	.196	.219	.213	.226	2.599		
#4	.188	.211	.199	.214	1.503		
#5	.235	.253	.253	.277	2.044		
#6	.240	.290	.233	.273	1.749		
#7	.199	.223	.217	.249	1.312		
#8	.200	.218	.198	.229	1.615		
#9	.210	.231	.216	.233	1.675		
#10	.205	.234	.212	.240	1.732		
#11	.416	.496	.397	.463	2.751		
#13	.425	.452	.331	.370	2.396		
#14M	1.031	1.147	1.222	1.359	9.593		
#15M	.855	.743	.952	1.056	7.900		
#16M	1.074	1.200	.906	.991	7.971		
#17M	.938	.793	1.066	1.122	3.720		
#18M	.792	.826	.833	.908	7.004		
#19M	.458	.553	.433	.523	3.740		
#CON1	.232	.265	.242	.256	1.742		
#CON2	.223	.255	.237	.257	1.846		

SITE D
ENVIRONMENTAL DOSIMETERS - 7/22 TO 10/6/77

8.212 8.135 492 10.194 9.720 452 26 64.1
22

#1	.554	.730	.549	.644	3.673
#2	.425	.457	.511	.479	3.052
#3	.324	.385	.373	.415	2.431
#4	.359	.399	.355	.402	2.308
#5	.417	.449	.439	.475	2.973
#6	.421	.497	.441	.480	2.965
#7	.381	.444	.393	.427	2.693
#8	.354	.416	.372	.423	2.452
#9	.376	.390	.407	.442	2.663
#10	.379	.426	.787	.430	2.574
#11	.668	.902	.708	.912	4.618
#13	.694	.736	.597	.626	3.962
#13	.636	1.237	.637	1.215	4.544
#14	.609	.672	.603	.680	4.095
#14	1.641	1.999	1.935	2.080	12.420
#15	1.414	1.617	1.336	1.741	10.720
#16	1.620	2.067	1.351	1.830	10.640
#17	1.216	1.498	1.207	1.297	8.437
#18	1.193	1.292	1.242	1.233	8.344
#19	.628	.825	.656	.771	4.769
#20	.483	.524	.503	.559	3.349
#21	.493	.592	.510	.556	3.253

SITE D
ENVIRONMENTAL DOSIMETERS - 10/6/77 TO 12/2/77

8.692 8.303 543 9.006 9.299 511 16 47.9
22

#1	.789	.921	.771	.974	4.319
#2	.662	.701	.715	.779	4.654
#3	.591	.647	.631	.733	4.025
#4	.603	.716	.653	.707	4.023
#5	.677	.736	.741	.814	5.018
#6	.690	.717	.723	.791	3.937
#7	.704	.801	.740	.827	4.602
#8	.680	.736	.723	.812	4.502
#9	.633	.727	.690	.741	4.139
#10	.633	.726	.742	.770	4.496
#11	.815	.997	.663	1.074	5.325
#13	.861	.947	.804	.935	5.614
#14	.825	.933	.870	.949	5.594
#13-M	.830	1.328	.652	1.315	5.264
#14-M	1.325	1.802	1.674	1.707	10.572
#15-M	1.332	1.732	1.506	1.723	9.239
#16-M	1.521	2.123	1.661	1.920	8.442
#17-M	1.413	1.480	1.538	1.628	10.052
#19-M	.911	1.124	.866	1.130	5.781
#10N	.803	.869	.853	.993	5.409
#20N	.715	.794	.801	.868	5.041
#30N	.737	.863	.804	.875	4.734

20140 SITE A

20150 PERSONNEL DOSIMETERS - 5/14 TO 7/14/76

20155 7.549 1.197 3.890 273 1.212 1.365 5.642

20160 100

20170 STA#1 .156 .163 .188 .333 .298 .166 .159 .206 .351 .271

20180 STA#7 .137 .133 .176 .275 .228 .145 .134 .172 .289 .245

20190 STRC1 .262 .240 .292 .417 .344 .263 .267 .279 .400 .362

20200 STRC2 .205 .202 .231 .360 .312 .215 .205 .218 .375 .218

20210 SSF01 1.119 1.181 1.390 2.100 2.051 1.111 1.137 1.394 2.001 1.949

20220 SP001 1.144 1.246 1.482 2.130 2.062 1.165 1.187 1.448 2.204 2.032

20230 SAP01 1.827 1.976 2.296 3.158 3.385 1.903 1.964 2.517 3.356 3.558

20240 SAP02 .239 .240 .290 .421 .375 .238 .226 .271 .402 .370

20250 SPE01 2.038 1.957 2.398 3.587 3.390 2.107 1.962 2.406 3.665 3.781

20260 SPE02 1.668 1.693 2.173 2.935 2.890 1.838 1.806 2.045 2.934 2.864

20270 SHP01 2.405 2.502 2.791 4.700 4.576 2.449 2.730 3.054 4.973 4.851

20280 SHP02 .640 .611 .655 .988 .978 .605 .575 .648 1.037 .940

20290 SCH01 .563 .542 .557 .894 .837 .549 .566 .555 .841 .739

20300 SCH02 .492 .481 .510 .811 .706 .496 .488 .509 .728 .697

20310 SP1G1 .113 .115 .157 .253 .195 .114 .115 .145 .248 .202

20320 SP1G2 .112 .112 .154 .231 .196 .110 .118 .139 .257 .196

20330 SAFT1 .146 .140 .192 .304 .247 .151 .162 .188 .035 .272

20340 SAFT2 .153 .171 .205 .325 .274 .165 .177 .194 .319 .283

20350 CIRCW .180 .168 .190 .305 .259 .176 .171 .181 .305 .273

20360 SF01 .152 .146 .181 .266 .261 .159 .156 .185 .305 .261

20370 SF02 .153 .154 .196 .301 .253 .148 .158 .184 .304 .266

20380 SF03 .154 .154 .197 .306 .261 .168 .165 .201 .308 .256

20390 SF04 .144 .144 .182 .293 .252 .140 .164 .171 .300 .244

20400 SF05 .153 .162 .180 .299 .247 .151 .159 .194 .280 .263

20410 SF06 .146 .157 .169 .305 .243 .152 .171 .195 .288 .245

20420 SF07 .159 .160 .197 .279 .236 .145 .164 .197 .309 .260

20430 SF08 .169 .160 .199 .303 .251 .158 .165 .181 .316 .243

20440 SF09 .157 .157 .193 .292 .232 .165 .156 .201 .288 .260

20450 SF10 .155 .160 .194 .310 .276 .160 .166 .195 .304 .255

20460 SP01 .164 .152 .179 .295 .231 .163 .158 .191 .296 .254

20470 SP02 .147 .152 .193 .312 .247 .147 .155 .196 .291 .275

20480 SP03 .185 .164 .202 .292 .234 .163 .180 .202 .326 .263

20490 SP04 .159 .155 .197 .298 .261 .150 .149 .198 .288 .267

20500 SP05 .147 .146 .188 .290 .253 .148 .155 .179 .293 .265

20510 SP06 .143 .161 .190 .295 .266 .147 .155 .181 .294 .252

20520 SP07 .139 .147 .175 .285 .245 .138 .140 .177 .279 .239

20530 SP08 .153 .162 .182 .287 .249 .151 .154 .196 .283 .258

20540 SP09 .148 .153 .194 .294 .246 .141 .153 .181 .298 .248

20550 SP10 .155 .152 .202 .302 .264 .161 .168 .203 .304 .241

20560 5001 .151 .160 .186 .288 .249 .149 .159 .192 .299 .257

20570 5002 .149 .165 .185 .290 .253 .154 .174 .187 .301 .237

20580 5003 .143 .150 .169 .291 .261 .145 .163 .192 .302 .252

20590 5004 .146 .156 .179 .302 .242 .146 .146 .188 .302 .251

20600 5005 .151 .156 .180 .296 .254 .144 .147 .177 .294 .256

20610 5006 .144 .144 .180 .251 .241 .145 .148 .194 .276 .244

20620 5007 .139 .153 .175 .276 .250 .153 .141 .192 .294 .252

20630 5008 .157 .167 .205 .290 .241 .163 .150 .199 .300 .252

20640 5009 .145 .158 .186 .303 .246 .157 .143 .180 .290 .238

SITE A - PERSONNEL DOSIMETERS - 5/14 TO 7/14/76 (cont'd)

20650	5I010	.157	.152	.184	.272	.274	.152	.150	.180	.302	.245
20660	5I01	.164	.167	.196	.304	.267	.162	.160	.187	.300	.270
20670	5I02	.169	.163	.206	.300	.244	.154	.171	.206	.312	.251
20680	5I03	.158	.152	.186	.299	.252	.157	.161	.200	.305	.257
20690	5I04	.156	.164	.199	.317	.263	.163	.163	.203	.302	.272
20700	5I05	.153	.163	.312	.323	.273	.156	.146	.296	.313	.256
20710	5I06	.152	.164	.189	.302	.260	.153	.160	.199	.297	.261
20720	5I07	.163	.177	.195	.317	.262	.175	.175	.204	.293	.264
20730	5I08	.167	.171	.195	.312	.267	.162	.167	.197	.325	.273
20740	5I09	.152	.177	.198	.332	.271	.165	.167	.198	.313	.273
20750	5I10	.145	.168	.197	.298	.267	.170	.174	.209	.309	.252
20760	5S01	.152	.160	.191	.310	.248	.157	.164	.192	.298	.252
20770	5S02	.148	.166	.193	.287	.262	.159	.161	.191	.297	.273
20780	5S04	.162	.166	.216	.317	.267	.161	.169	.219	.318	.251
20790	5S05	.148	.176	.195	.294	.270	.159	.164	.205	.285	.276
20800	5S06	.145	.167	.194	.276	.237	.148	.161	.189	.314	.268
20810	5S07	.160	.153	.199	.275	.255	.156	.176	.190	.332	.287
20820	5S08	.159	.194	.192	.320	.269	.159	.175	.199	.305	.265
20830	5S09	.157	.166	.194	.327	.270	.169	.154	.193	.285	.269
20840	5S10	.158	.157	.194	.317	.257	.159	.158	.183	.308	.272
20850	5E01	.156	.157	.191	.287	.241	.156	.168	.189	.289	.263
20860	5E02	.151	.146	.165	.280	.201	.153	.146	.173	.233	.241
20870	5E03	.153	.143	.171	.258	.249	.141	.133	.166	.284	.229
20880	5E04	.121	.149	.163	.268	.247	.138	.138	.167	.281	.246
20890	5E05	.143	.156	.180	.263	.228	.139	.142	.167	.281	.246
20900	5E06	.134	.150	.183	.290	.246	.146	.144	.194	.266	.248
20910	5E07	.137	.134	.167	.298	.235	.148	.146	.163	.274	.235
20920	5E08	.142	.146	.170	.280	.229	.142	.143	.175	.284	.248
20930	5E09	.138	.126	.155	.282	.232	.145	.138	.168	.262	.228
20940	5E10	.140	.145	.161	.265	.222	.150	.151	.180	.256	.241
20950	5C01	.160	.163	.186	.295	.266	.158	.174	.206	.312	.270
20960	5C02	.155	.164	.184	.308	.246	.165	.164	.188	.308	.254
20970	5C03	.159	.154	.203	.309	.267	.160	.150	.217	.326	.266
20980	5C04	.164	.165	.186	.281	.261	.163	.164	.203	.311	.247
20990	5C05	.156	.157	.194	.301	.244	.146	.168	.178	.292	.261
21000	5C06	.159	.164	.200	.306	.296	.148	.165	.211	.325	.290
21010	5C07	.172	.171	.193	.276	.265	.154	.164	.213	.304	.262
21020	5C08	.271	.293	.205	.341	.308	.270	.287	.208	.312	.310
21030	5C09	.152	.168	.183	.292	.273	.155	.166	.187	.317	.257
21040	5C10	.156	.163	.187	.300	.255	.165	.160	.187	.309	.248
21050	5M01	.160	.159	.204	.325	.278	.161	.164	.194	.321	.271
21060	5M02	.154	.174	.187	.317	.277	.155	.167	.185	.299	.268
21070	5M03	.168	.162	.202	.283	.266	.169	.165	.194	.319	.286
21080	5M04	.159	.162	.185	.292	.265	.156	.160	.193	.300	.259
21090	5M05	.147	.165	.191	.303	.268	.158	.166	.185	.316	.242
21100	5M06	.163	.161	.199	.296	.270	.171	.167	.199	.325	.278
21110	5M07	.160	.172	.190	.313	.263	.166	.172	.199	.333	.278
21120	5M08	.160	.178	.204	.290	.260	.175	.169	.194	.294	.261
21130	5M09	.150	.171	.192	.308	.266	.171	.159	.185	.314	.259
21140	5M10	.164	.161	.198	.306	.262	.155	.176	.197	.306	.248
21150	BKG	.200	.210	.236	.371	.335	.198	.233	.254	.369	.344

18820 SITE A

18830 PERSONNEL DOSIMETERS - 7/14 TO 9/28/76

18835 6.968 1.194 3.708 260 1.077 1.388 5.345

18840 96

18850 STA#1 .297 .303 .320 .509 .456 .319 .299 .317 .508 .437

18860 STA#7 .269 .284 .299 .418 .349 .258 .270 .298 .425 .342

18870 STA#20 .309 .307 .373 .433 .406 .311 .315 .354 .469 .405

18880 7TRC1 .400 .434 .430 .611 .520 .383 .378 .447 .617 .541

18890 7TRC2 .378 .389 .439 .556 .500 .354 .401 .418 .544 .493

18900 7AF01 1.825 1.701 2.104 3.105 2.956 1.644 1.714 2.211 2.879 3.084

18910 7AF02 .402 .385 .428 .573 .508 .410 .414 .409 .560 .532

18920 7SF01 1.726 1.716 2.095 2.893 2.964 1.672 1.603 2.148 3.040 2.973

18930 7F001 1.530 1.447 1.801 2.470 2.587 1.486 1.490 1.918 2.509 2.506

18940 7PE01 .449 .440 .468 .613 .587 .460 .435 .487 .608 .552

18950 7PE02 2.245 2.199 2.624 3.779 3.782 2.147 2.246 2.674 3.571 3.538

18960 7HP01 4.004 4.038 5.135 6.923 7.404 4.302 4.316 4.985 7.022 7.235

18970 7HP02 .685 .689 .720 .969 .959 .688 .668 .686 .992 .931

18980 7CH01 .361 .357 .413 .545 .520 .370 .386 .377 .524 .499

18990 7CH02 .504 .518 .525 .756 .677 .474 .497 .533 .716 .672

19000 7FIG1 .200 .218 .244 .312 .252 .207 .221 .234 .299 .269

19010 7FIG2 .227 .229 .260 .323 .282 .230 .218 .250 .348 .282

19020 SAOFF .287 .271 .327 .444 .376 .291 .277 .303 .423 .371

19030 SAOFF .267 .267 .300 .389 .346 .258 .292 .313 .403 .327

19040 7F01 .256 .255 .288 .372 .331 .250 .236 .279 .379 .334

19050 7F02 .264 .259 .285 .386 .341 .245 .241 .313 .365 .327

19060 7F03 .241 .259 .296 .368 .360 .249 .263 .292 .396 .334

19070 7F04 .250 .234 .285 .339 .326 .237 .251 .264 .356 .311

19080 7F05 .270 .253 .310 .364 .350 .240 .248 .307 .373 .327

19090 7F06 .237 .243 .282 .374 .321 .244 .240 .287 .382 .315

19100 7F07 .253 .247 .281 .382 .342 .261 .236 .292 .388 .335

19110 7F08 .254 .251 .317 .383 .338 .260 .249 .279 .374 .347

19120 7F09 .236 .265 .251 .358 .308 .234 .241 .295 .374 .314

19130 7F10 .257 .267 .280 .384 .336 .249 .279 .295 .373 .346

19140 7F01 .243 .265 .308 .390 .348 .250 .263 .263 .394 .337

19150 7F02 .238 .247 .283 .390 .335 .244 .263 .286 .377 .323

19160 7F03 .291 .270 .313 .408 .354 .255 .241 .296 .396 .334

19170 7F04 .260 .268 .293 .405 .340 .259 .257 .299 .405 .344

19180 7F05 .260 .266 .304 .362 .351 .241 .255 .295 .391 .327

19190 7F06 .253 .253 .289 .393 .350 .257 .244 .306 .392 .334

19200 7F07 .247 .240 .281 .385 .338 .246 .243 .286 .398 .320

19210 7F08 .256 .239 .305 .394 .327 .255 .250 .312 .369 .322

19220 7F09 .253 .249 .275 .373 .328 .224 .255 .296 .374 .346

19230 7F10 .231 .232 .292 .359 .314 .249 .250 .279 .383 .324

19240 7001 .238 .241 .282 .361 .326 .231 .252 .281 .361 .315

19250 7002 .231 .247 .271 .373 .321 .246 .256 .280 .372 .324

19260 7003 .239 .250 .297 .367 .336 .226 .243 .271 .390 .318

19270 7004 .245 .240 .281 .371 .331 .257 .241 .274 .352 .302

19280 7005 .253 .244 .315 .383 .329 .243 .254 .273 .354 .318

19290 7006 .231 .246 .274 .360 .327 .240 .241 .264 .377 .318

19300 7007 .246 .230 .277 .371 .331 .251 .233 .265 .379 .330

19310 7008 .240 .231 .303 .366 .302 .227 .264 .281 .357 .324

SITE A - PERSONNEL DOSIMETERS - 7/14 TO 9/28/76 (cont'd)

19320	7009	.304	.309	.351	.483	.429	.316	.311	.365	.478	.413
19330	7010	.243	.239	.281	.371	.321	.224	.237	.271	.355	.308
19340	7101	.246	.261	.280	.382	.359	.258	.268	.306	.374	.349
19350	7102	.266	.267	.290	.393	.341	.258	.255	.295	.388	.322
19360	7103	.256	.235	.267	.349	.328	.228	.249	.358	.389	.298
19370	7104	.267	.238	.287	.358	.349	.251	.245	.267	.375	.333
19380	7105	.235	.259	.297	.384	.321	.245	.258	.271	.401	.315
19390	7106	.193	.214	.253	.318	.280	.206	.223	.240	.339	.287
19400	7107	.246	.243	.269	.376	.359	.250	.258	.293	.372	.319
19410	7108	.240	.242	.276	.383	.330	.260	.259	.281	.386	.342
19420	7109	.249	.251	.292	.392	.327	.253	.246	.303	.411	.334
19430	7110	.254	.270	.300	.393	.357	.241	.259	.287	.377	.343
19440	7501	.230	.260	.277	.371	.326	.244	.232	.297	.384	.340
19450	7502	.259	.238	.278	.385	.356	.272	.252	.276	.383	.350
19460	7503	.251	.246	.301	.352	.351	.251	.250	.294	.370	.343
19470	7504	.264	.270	.300	.383	.358	.264	.263	.296	.387	.337
19480	7505	.260	.251	.290	.375	.333	.248	.250	.282	.377	.335
19490	7506	.247	.258	.289	.372	.357	.258	.240	.288	.365	.348
19500	7507	.276	.289	.301	.385	.345	.258	.269	.314	.426	.348
19510	7508	.260	.246	.306	.370	.330	.239	.255	.302	.399	.326
19520	7509	.242	.259	.293	.404	.342	.243	.285	.280	.406	.335
19530	7510	.224	.265	.286	.396	.366	.275	.258	.303	.379	.343
19540	7E01	.260	.258	.279	.379	.337	.250	.263	.286	.390	.358
19550	7E02	.247	.248	.288	.381	.333	.248	.248	.287	.380	.349
19560	7E03	.249	.244	.277	.367	.325	.255	.262	.293	.376	.312
19570	7E04	.255	.248	.284	.360	.319	.236	.253	.271	.346	.317
19580	7E05	.232	.251	.280	.389	.332	.260	.251	.278	.378	.336
19590	7E06	.234	.264	.273	.389	.362	.251	.263	.285	.383	.326
19600	7E07	.234	.266	.268	.355	.330	.253	.256	.272	.343	.314
19610	7E08	.253	.257	.289	.381	.346	.241	.253	.305	.395	.350
19620	7E09	.236	.246	.277	.376	.326	.243	.234	.290	.370	.336
19630	7E10	.253	.241	.289	.370	.320	.248	.241	.281	.380	.324
19640	5C01	.220	.237	.272	.354	.310	.234	.226	.268	.346	.310
19650	5C02	.218	.236	.280	.322	.295	.222	.232	.265	.338	.313
19660	7C03	.220	.229	.256	.341	.318	.231	.231	.269	.381	.326
19670	7C04	.237	.246	.252	.334	.304	.221	.276	.266	.359	.306
19680	7C05	.237	.225	.291	.343	.308	.229	.258	.272	.325	.323
19690	7C06	.254	.244	.288	.365	.334	.242	.237	.276	.369	.333
19700	7C08	.240	.255	.300	.363	.324	.230	.251	.283	.375	.320
19710	7C09	.242	.254	.275	.357	.344	.241	.231	.285	.359	.335
19720	7C10	.235	.251	.281	.346	.330	.255	.235	.267	.369	.312
19730	7M02	.264	.260	.283	.390	.345	.251	.274	.300	.368	.342
19740	7M03	.256	.252	.283	.365	.342	.255	.240	.286	.370	.334
19750	7M04	.254	.254	.294	.353	.335	.262	.258	.300	.391	.339
19760	7M05	.226	.247	.284	.353	.318	.232	.242	.276	.356	.314
19770	7M06	.240	.248	.273	.364	.318	.236	.251	.287	.365	.307
19780	7M07	.226	.217	.281	.352	.294	.244	.254	.275	.347	.309
19790	7M08	.232	.232	.258	.334	.319	.229	.249	.259	.362	.317
19800	7M10	.252	.255	.332	.368	.333	.249	.244	.306	.343	.341

16860 PERSONNEL DOSIMETERS - 9/25 TO 11/30/76

16870 101

16890	ST#10	.215	.230	.255	.349	.312	.223	.210	.262	.336	.311
-------	-------	------	------	------	------	------	------	------	------	------	------

16910	ST#11	.298	.287	.318	.446	.432	.302	.296	.312	.445	.440
-------	-------	------	------	------	------	------	------	------	------	------	------

16930	ST#12	.169	.147	.198	.281	.243	.155	.162	.187	.267	.241
-------	-------	------	------	------	------	------	------	------	------	------	------

16950 ST#18 .204 .203 .213 .371 .338 .219 .210 .230 .378 .328

16970	9AP01	3.269	3.561	4.271	5.796	5.485	3.576	3.265	4.070	5.408	5.311
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

16990	9AF03	.993	1.043	1.125	1.623	1.386	.961	1.014	1.105	1.571	1.613
-------	-------	------	-------	-------	-------	-------	------	-------	-------	-------	-------

17010	99F01	1.584	1.896	2.340	3.254	3.055	1.859	1.886	2.375	3.135	3.186
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

17010	9CH02	.393	.393	.402	.544	.519	.369	.367	.429	.551	.501
-------	-------	------	------	------	------	------	------	------	------	------	------

17049	9CE02	1.775	1.788	1.788	1.788	1.788	1.788	1.788	1.788	1.788	1.788
17050	9CE01	1.304	1.373	1.452	2.410	7.767	1.338	1.299	1.428	9.379	7.501

17080	ETEL 1	210	214	254	354	318	212	308	247	340	300
-------	--------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

17100	INTER3	-143	-143	-143	222	218	150	148	138	240	234
-------	--------	------	------	------	-----	-----	-----	-----	-----	-----	-----

17120 9F01 +217 +224 +263 +357 +320 +224 +218 +261 +360 +335

17140	9F03	.230	.230	.281	.404	.342	.216	.212	.265	.414	.337
-------	------	------	------	------	------	------	------	------	------	------	------

17155	9E04	215	224	230	343	334	303	330	345	343	313
-------	------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

17170	9F05	2210	2221	2271	2414	2545	2525	2525	2534	2410	2554
17180	9F07	2223	2243	2275	2385	2349	2235	2245	2244	2384	2359

17170	9F00	1220	1217	1200	1300	1340	1200	1200	1277	1372	1342
17200	9F09	1200	1207	1252	1338	1307	1217	1201	1255	1344	1308

17220	9E02	216	211	256	258	284	287	317	251	245	315
-------	------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

17240	9F04	+221	+224	+262	+361	+323	+211	+220	+262	+359	+288
-------	------	------	------	------	------	------	------	------	------	------	------

17360	9F06	.217	.213	.252	.347	.323	.204	.222	.264	.370	.304
-------	------	------	------	------	------	------	------	------	------	------	------

17280	9F09	.200	.207	.262	.398	.326	.202	.211	.261	.381	.335
-------	------	------	------	------	------	------	------	------	------	------	------

17300	9001	+212	+209	+255	+360	+319	+200	+212	+247	+343	+301
-------	------	------	------	------	------	------	------	------	------	------	------

17310	8002	228	232	236	238	240	242	244	246	248	250
17320	8003	229	233	237	240	243	245	248	251	254	257

17330	9004	202	214	234	334	323	207	177	233	382	312
17340	9005	212	213	250	357	314	213	218	246	351	314

17330	7000	.212	.244	.287	.331	.318	.204	.222	.278	.374	.318
17340	8003	.221	.243	.288	.357	.340	.278	.273	.274	.340	.370

17370	9008	.232	.244	.272	.337	.343	.248	.283	.280	.361	.338
17380	9009	.213	.214	.279	.358	.388	.320	.237	.242	.391	.379

17380	7007	.215	.218	.278	.338	.288	.220	.227	.282	.391	.337
17390	9010	.218	.224	.245	.384	.335	.213	.231	.252	.342	.372

SITE A - PERSONNEL DOSIMETERS - 9/25 TO 11/30/76 (cont'd)

17400 9I01	.223	.215	.277	.369	.318	.216	.225	.281	.375	.326
17410 9I02	.227	.238	.273	.332	.322	.237	.239	.253	.367	.313
17420 9I03	.216	.227	.263	.332	.313	.220	.200	.263	.319	.300
17430 9I04	.220	.213	.273	.366	.338	.227	.226	.271	.326	.319
17440 9I05	.230	.217	.267	.360	.321	.225	.226	.262	.360	.339
17450 9I06	.203	.207	.241	.327	.315	.204	.199	.260	.344	.305
17460 9I07	.209	.231	.279	.389	.360	.224	.237	.263	.393	.365
17470 9I08	.211	.220	.263	.356	.323	.220	.213	.270	.355	.345
17480 9I09	.217	.248	.262	.373	.319	.207	.241	.289	.388	.336
17490 9I10	.222	.242	.265	.376	.337	.228	.213	.250	.368	.324
17500 9S01	.237	.218	.266	.387	.338	.225	.232	.258	.368	.340
17510 9S02	.208	.221	.274	.386	.326	.214	.222	.264	.356	.315
17520 9S03	.236	.243	.279	.412	.362	.229	.239	.286	.436	.383
17530 9S04	.224	.229	.250	.407	.346	.229	.228	.249	.442	.341
17540 9S05	.226	.220	.273	.371	.336	.234	.230	.267	.370	.338
17550 9S06	.228	.222	.270	.375	.345	.222	.217	.283	.361	.332
17560 9S07	.236	.217	.270	.367	.322	.220	.225	.252	.345	.325
17570 9S08	.219	.220	.246	.357	.341	.220	.209	.245	.398	.330
17580 9S09	.244	.233	.291	.391	.329	.228	.259	.271	.383	.335
17590 9S10	.222	.258	.288	.396	.333	.221	.257	.280	.398	.342
17600 9E01	.247	.241	.273	.364	.340	.239	.242	.261	.380	.316
17610 9E02	.237	.206	.243	.376	.321	.224	.212	.250	.373	.326
17620 9E03	.246	.229	.313	.405	.358	.227	.242	.309	.398	.347
17630 9E04	.217	.242	.276	.362	.312	.222	.255	.268	.358	.332
17640 9E05	.218	.241	.278	.384	.353	.216	.230	.272	.379	.356
17650 9E06	.213	.218	.260	.370	.324	.233	.227	.263	.363	.334
17660 9E07	.203	.206	.252	.361	.341	.216	.223	.247	.360	.327
17670 9E08	.228	.228	.266	.371	.335	.216	.229	.259	.367	.330
17680 9E09	.217	.214	.251	.360	.323	.218	.213	.261	.363	.308
17690 9E10	.216	.205	.271	.356	.312	.220	.216	.257	.361	.295
17700 9C01	.215	.230	.257	.338	.322	.218	.222	.259	.354	.312
17710 9C02	.210	.210	.254	.344	.305	.213	.211	.254	.350	.300
17720 9C03	.199	.220	.261	.347	.278	.197	.227	.244	.390	.322
17730 9C04	.203	.231	.275	.367	.333	.218	.228	.270	.355	.333
17740 9C05	.208	.203	.239	.340	.304	.205	.186	.232	.226	.280
17750 9C06	.208	.210	.251	.370	.299	.216	.222	.272	.343	.325
17760 9C07	.218	.223	.273	.339	.304	.212	.223	.244	.346	.307
17770 9C08	.209	.216	.242	.365	.304	.200	.219	.252	.348	.290
17780 9C09	.203	.222	.255	.349	.332	.221	.222	.264	.248	.317
17790 9C10	.200	.198	.240	.334	.297	.192	.192	.238	.359	.308
17800 9M01	.260	.235	.268	.350	.339	.246	.245	.275	.365	.340
17810 9M02	.234	.283	.266	.363	.340	.244	.281	.302	.378	.328
17820 9M03	.243	.271	.296	.393	.366	.237	.257	.277	.399	.360
17830 9M04	.300	.311	.330	.449	.422	.304	.338	.337	.477	.435
17840 9M05	.219	.237	.249	.352	.343	.217	.233	.258	.368	.315
17850 9M06	.221	.226	.254	.355	.287	.200	.219	.270	.332	.327
17860 9M08	.203	.212	.258	.338	.296	.202	.220	.260	.355	.301
17870 9M09	.194	.233	.292	.401	.338	.234	.245	.318	.399	.331
17880 9M10	.231	.225	.257	.353	.309	.223	.219	.250	.370	.326

14180	SITE A											
14190	PERSONNEL DOSIMETERS - 12/1/76 TO 3/2/77											
14195	7.035	1.116	3.983	262	1.069	1.278	5.453					
14200	94											
14210	ST#10	.267	.273	.264	.352	.369	.276	.282	.268	.329	.376	
14220	ST#10	.254	.238	.288	.405	.364	.247	.255	.293	.394	.364	
14230	ST#11	.265	.247	.255	.357	.363	.282	.279	.291	.353	.358	
14240	ST#11	.261	.241	.283	.425	.377	.263	.253	.289	.393	.380	
14250	ST#12	.172	.174	.158	.250	.257	.168	.176	.161	.248	.257	
14260	ST#12	.170	.193	.173	.274	.225	.181	.191	.176	.257	.251	
14270	PUMPS	.294	.317	.349	.496	.461	.321	.303	.368	.501	.440	
14280	VC-1	.329	.322	.382	.532	.462	.330	.325	.384	.519	.463	
14290	AP001	1.315	1.315	1.418	1.904	1.749	1.289	1.413	1.339	1.803	1.712	
14300	AP002	.399	.413	.424	.559	.558	.392	.408	.438	.595	.501	
14310	AP003	2.030	1.940	1.955	2.748	2.679	1.937	2.039	2.090	2.685	2.769	
14320	HP01	2.141	2.126	2.382	3.235	3.000	2.077	2.157	2.244	3.279	3.034	
14330	SF01	.814	.837	.942	1.313	1.198	.925	.839	.919	1.313	1.248	
14340	CH01	.375	.390	.406	.556	.533	.395	.425	.395	.541	.530	
14350	CH02	.752	.779	.877	1.211	1.128	.800	.805	.875	1.267	1.086	
14360	CR01	.460	.457	.435	.697	.673	.432	.422	.502	.721	.681	
14370	RX228	.324	.311	.372	.499	.434	.347	.326	.397	.508	.480	
14380	T-164	.366	.373	.388	.565	.522	.361	.386	.385	.566	.496	
14390	F01	.284	.251	.285	.396	.359	.263	.254	.328	.410	.379	
14400	F02	.261	.277	.264	.352	.345	.257	.275	.264	.340	.352	
14410	F03	.254	.262	.292	.417	.386	.253	.278	.300	.398	.394	
14420	F04	.265	.266	.253	.378	.331	.267	.256	.252	.358	.353	
14430	F05	.262	.270	.321	.418	.396	.281	.282	.318	.413	.410	
14440	F06	.258	.267	.319	.441	.409	.257	.253	.331	.443	.382	
14450	F07	.236	.259	.311	.426	.381	.236	.260	.294	.418	.382	
14460	F08	.373	.369	.455	.294	.284	.395	.385	.414	.296	.301	
14470	F09	.254	.275	.265	.382	.359	.284	.275	.264	.369	.376	
14480	F10	.278	.255	.297	.408	.368	.229	.268	.304	.390	.347	
14490	P01	.249	.257	.297	.431	.384	.261	.263	.296	.433	.373	
14500	P02	.262	.275	.316	.419	.384	.275	.249	.322	.398	.393	
14510	P03	.254	.259	.265	.347	.359	.258	.265	.247	.369	.307	
14520	P04	.306	.275	.342	.451	.404	.276	.278	.309	.472	.392	
14530	P05	.248	.279	.356	.423	.390	.259	.281	.320	.416	.355	
14540	P06	.253	.257	.269	.365	.352	.273	.265	.269	.379	.362	
14550	P07	.251	.265	.253	.367	.352	.277	.266	.243	.342	.342	
14560	P08	.266	.259	.311	.458	.375	.255	.267	.293	.447	.373	
14570	P10	.241	.225	.265	.352	.311	.257	.256	.250	.372	.355	
14580	001	.243	.249	.300	.419	.361	.239	.266	.285	.415	.356	
14590	002	.246	.252	.313	.426	.356	.373	.279	.293	.414	.372	
14600	003	.243	.269	.248	.357	.353	.245	.252	.256	.370	.343	
14610	004	.240	.253	.263	.362	.341	.239	.242	.258	.320	.319	
14620	005	.253	.267	.317	.466	.375	.272	.266	.331	.423	.358	
14630	006	.250	.250	.300	.387	.375	.248	.248	.310	.423	.384	
14640	007	.244	.256	.260	.358	.349	.252	.247	.243	.365	.360	
14650	008	.258	.278	.269	.386	.367	.266	.247	.262	.369	.345	
14660	009	.247	.251	.240	.344	.328	.261	.241	.244	.330	.360	
14670	010	.247	.251	.249	.352	.324	.241	.247	.248	.353	.319	

SITE A PERSONNEL DOSIMETERS - 12/1/76 TO 3/2/77 (cont'd)

14680	I01	.272	.255	.308	.404	.381	.290	.240	.327	.398	.387
14690	I02	.265	.263	.309	.415	.383	.250	.249	.284	.429	.363
14700	I03	.255	.265	.308	.414	.376	.255	.268	.292	.390	.380
14710	I04	.273	.263	.313	.447	.388	.268	.270	.303	.415	.413
14720	I07	.253	.266	.259	.327	.319	.240	.261	.254	.378	.338
14730	I08	.248	.245	.288	.410	.366	.243	.261	.294	.425	.394
14740	I09	.249	.255	.296	.390	.343	.249	.263	.293	.404	.360
14750	I10	.270	.267	.239	.389	.340	.253	.287	.250	.369	.358
14760	S01	.254	.265	.295	.438	.359	.249	.251	.301	.421	.332
14770	S02	.257	.260	.246	.364	.367	.242	.250	.249	.366	.337
14780	S03	.249	.257	.300	.408	.378	.251	.259	.313	.416	.373
14790	S04	.262	.276	.319	.399	.393	.243	.264	.302	.448	.365
14800	S05	.271	.278	.318	.449	.391	.263	.289	.351	.430	.374
14810	S06	.241	.245	.252	.341	.332	.261	.257	.258	.358	.357
14820	S07	.240	.272	.272	.459	.361	.256	.264	.278	.413	.384
14830	S08	.237	.239	.290	.414	.401	.247	.239	.307	.425	.329
14840	S09	.263	.272	.343	.429	.382	.260	.271	.332	.452	.371
14850	S10	.259	.266	.314	.441	.403	.292	.278	.308	.427	.405
14860	E01	.294	.318	.286	.415	.396	.290	.300	.264	.373	.400
14870	E02	.292	.279	.325	.442	.389	.280	.293	.322	.465	.421
14880	E03	.263	.285	.302	.440	.388	.264	.266	.300	.441	.388
14890	E04	.261	.271	.297	.402	.367	.249	.265	.297	.373	.364
14900	E05	.278	.287	.270	.408	.362	.275	.274	.267	.411	.375
14910	E06	.242	.253	.258	.343	.362	.254	.244	.258	.399	.316
14920	E08	.258	.291	.286	.351	.377	.265	.282	.274	.394	.382
14930	E09	.234	.267	.308	.423	.369	.252	.232	.276	.414	.368
14940	E10	.252	.263	.276	.396	.379	.236	.260	.260	.371	.366
14950	C01	.250	.242	.285	.391	.327	.245	.280	.309	.434	.362
14960	C02	.228	.239	.256	.377	.333	.249	.234	.254	.377	.379
14970	C03	.299	.305	.323	.448	.416	.311	.285	.340	.453	.368
14980	C04	.243	.263	.299	.399	.369	.247	.255	.312	.364	.346
14990	C05	.231	.232	.228	.330	.333	.222	.236	.230	.341	.285
15000	C06	.343	.373	.377	.502	.495	.341	.334	.386	.516	.477
15010	C07	.256	.270	.274	.382	.350	.260	.273	.255	.347	.344
15020	C08	.274	.266	.308	.422	.385	.264	.280	.316	.441	.387
15030	C09	.256	.250	.293	.430	.342	.260	.251	.301	.452	.371
15040	C10	.347	.347	.385	.505	.491	.351	.334	.399	.540	.490
15050	M01	.323	.304	.368	.500	.490	.333	.297	.367	.474	.514
15060	M02	.311	.301	.326	.502	.463	.299	.296	.314	.474	.453
15070	M03	.366	.335	.366	.521	.505	.340	.351	.391	.467	.492
15080	M05	.241	.261	.298	.408	.361	.246	.252	.291	.400	.358
15090	M06	.254	.252	.289	.437	.366	.247	.259	.301	.437	.382
15100	M07	.261	.248	.303	.419	.365	.248	.278	.309	.410	.347
1558	M08	.386	.342	.380	.476	.492	.369	.344	.380	.470	.511
1559	M10	.247	.267	.270	.425	.399	.251	.269	.290	.413	.369
1661	F001	.262	.279	.324	.473	.418	.292	.277	.340	.461	.425

100	SITE A											
110	PERSONNEL DOSIMETERS - 3/2 TO 6/22/77											
115	7.356	1.096	3.652	307	1.046	1.324	7.490					
120	98											
130	3C01	.269	.284	.338	.450	.407	.300	.272	.327	.454	.422	
140	3C02	.273	.288	.309	.440	.392	.252	.258	.303	.430	.380	
150	3C03	.286	.276	.340	.407	.388	.284	.262	.326	.425	.365	
160	3C04	.277	.278	.325	.447	.435	.279	.293	.330	.464	.414	
170	3C05	.254	.244	.309	.414	.362	.245	.253	.298	.437	.387	
180	3C06	.279	.287	.339	.419	.383	.267	.282	.328	.421	.402	
200	3C08	.286	.296	.325	.487	.393	.286	.277	.326	.443	.410	
210	3C09	.291	.284	.332	.467	.434	.275	.297	.331	.455	.427	
220	3C10	.288	.294	.318	.446	.433	.303	.306	.312	.468	.437	
230	3E01	.297	.285	.466	.476	.425	.296	.299	.342	.461	.408	
240	3E02	.296	.292	.361	.459	.419	.306	.305	.335	.510	.433	
250	3E03	.298	.301	.342	.460	.375	.302	.284	.348	.476	.427	
260	3E04	.271	.286	.283	.412	.394	.275	.271	.275	.403	.392	
270	3E05	.302	.286	.325	.459	.425	.287	.297	.343	.445	.418	
280	3E06	.268	.273	.320	.439	.386	.269	.270	.341	.450	.386	
290	3E07	.305	.285	.337	.482	.443	.294	.299	.352	.494	.442	
300	3E08	.285	.280	.338	.466	.412	.290	.303	.325	.464	.413	
310	3E09	.288	.295	.365	.449	.408	.313	.309	.340	.452	.417	
320	3E10	.270	.277	.326	.458	.419	.263	.289	.325	.486	.443	
330	3I01	.291	.297	.335	.449	.421	.266	.308	.339	.419	.444	
340	3I02	.270	.285	.313	.446	.413	.293	.274	.326	.456	.407	
350	3I04	.278	.277	.337	.455	.431	.285	.289	.344	.427	.439	
360	3I05	.266	.285	.322	.449	.422	.276	.282	.331	.459	.403	
370	3I06	.278	.293	.341	.434	.417	.264	.293	.329	.423	.402	
380	3I07	.276	.293	.336	.493	.431	.284	.293	.322	.459	.435	
390	3I08	.266	.315	.320	.485	.422	.300	.350	.340	.465	.422	
400	3I09	.300	.291	.324	.476	.418	.284	.277	.303	.491	.439	
410	3I10	.265	.271	.304	.428	.419	.276	.268	.322	.427	.394	
420	3F01	.271	.289	.314	.440	.390	.276	.290	.338	.450	.412	
430	3F02	.306	.315	.357	.491	.443	.321	.315	.342	.502	.443	
440	3F03	.270	.271	.323	.475	.446	.288	.296	.348	.468	.370	
450	3F04	.274	.280	.328	.463	.420	.286	.273	.340	.474	.454	
460	3F06	.270	.298	.344	.442	.402	.275	.285	.322	.429	.429	
470	3F08	.272	.273	.332	.436	.395	.266	.284	.322	.470	.396	
480	3F09	.303	.290	.354	.483	.475	.305	.302	.349	.497	.364	
490	3F10	.291	.283	.297	.407	.376	.276	.278	.269	.391	.371	
500	2M01	.293	.305	.350	.478	.418	.312	.308	.364	.496	.446	
510	3M02	.306	.318	.360	.528	.440	.325	.302	.354	.496	.438	
520	3M03	.305	.316	.355	.440	.423	.303	.325	.352	.458	.448	
530	3M05	.294	.301	.355	.514	.435	.304	.295	.371	.467	.432	
540	3M06	.311	.301	.354	.489	.433	.299	.311	.372	.476	.426	
550	3M07	.296	.301	.351	.448	.409	.293	.306	.370	.438	.414	
560	3M08	.307	.315	.357	.515	.435	.316	.327	.388	.495	.456	
570	3M09	.305	.322	.387	.475	.435	.300	.307	.365	.495	.449	
580	3M10	.328	.338	.310	.438	.409	.309	.364	.311	.424	.427	
590	3001	.327	.329	.317	.414	.427	.327	.338	.317	.424	.412	

SITE A PERSONNEL DOSIMETERS - 3/2 TO 6/22/77 (cont'd)

600	3002	.294	.346	.376	.482	.414	.307	.365	.419	.503	.455
610	3003	.316	.306	.418	.490	.451	.306	.314	.344	.505	.448
620	3004	.295	.308	.348	.466	.405	.299	.309	.351	.487	.432
630	3005	.298	.350	.382	.467	.427	.292	.323	.372	.441	.452
640	3006	.301	.322	.332	.477	.397	.289	.293	.370	.469	.405
650	3007	.297	.286	.346	.450	.396	.305	.277	.346	.450	.408
660	3008	.310	.324	.344	.482	.450	.300	.319	.374	.505	.435
670	3009	.280	.301	.337	.431	.410	.282	.289	.323	.464	.417
680	3010	.385	.381	.441	.541	.511	.375	.387	.413	.569	.517
690	3P01	.321	.321	.380	.481	.414	.305	.311	.354	.454	.431
700	3P02	.339	.333	.386	.485	.504	.340	.330	.399	.359	.481
710	3P03	.318	.317	.362	.476	.434	.299	.283	.358	.449	.440
720	3P04	.391	.343	.402	.499	.517	.393	.354	.457	.501	.493
730	3P05	.333	.328	.377	.473	.434	.325	.315	.382	.497	.436
740	3P06	.310	.334	.362	.505	.440	.317	.316	.352	.500	.409
750	3P08	.256	.304	.341	.484	.438	.326	.313	.327	.483	.450
760	3P09	.309	.305	.359	.459	.416	.289	.293	.351	.428	.442
770	3P10	.292	.286	.342	.469	.399	.291	.305	.346	.483	.364
780	3S01	.286	.362	.370	.499	.430	.310	.340	.366	.483	.440
790	3S02	.361	.413	.448	.578	.494	.330	.364	.452	.533	.501
800	3S03	.320	.335	.393	.525	.449	.328	.341	.365	.497	.447
810	3S04	.516	.477	.540	.414	.390	.501	.485	.528	.389	.392
820	3S05	.363	.357	.393	.511	.458	.325	.351	.387	.493	.430
830	3S06	.335	.316	.383	.497	.447	.335	.317	.373	.486	.428
840	3S07	.394	.410	.463	.581	.526	.421	.413	.499	.613	.547
850	3S08	.363	.392	.436	.527	.472	.364	.364	.427	.523	.529
860	3S09	.346	.368	.405	.513	.473	.321	.332	.385	.491	.454
870	3S10	.392	.488	.539	.600	.563	.425	.527	.550	.625	.567
880	3S001	.290	.286	.333	.455	.416	.292	.269	.352	.481	.411
890	3S002	.308	.342	.356	.493	.469	.300	.327	.368	.506	.453
900	3P101	.187	.207	.249	.360	.299	.200	.203	.237	.351	.315
910	3P102	.211	.206	.252	.364	.327	.201	.211	.259	.372	.301
920	3TR01	.402	.350	.459	.587	.526	.399	.404	.424	.608	.541
930	3TR02	.397	.387	.438	.577	.540	.397	.396	.436	.531	.533
940	3CWP1	.406	.366	.376	.573	.489	.391	.381	.373	.543	.498
950	UNMRK	.420	.377	.432	.591	.553	.404	.413	.433	.592	.540
960	3AP01	1.823	1.715	1.913	2.402	2.543	1.802	1.693	1.839	2.468	2.253
970	3AP02	.423	.430	.472	.603	.604	.431	.423	.477	.575	.609
980	3AP03	6.369	5.792	5.874	7.580	8.110	6.386	5.418	5.989	7.621	7.724
990	3CH01	1.163	1.212	1.191	1.613	1.540	1.197	1.136	1.159	1.673	1.517
1000	3CH02	.994	.999	1.065	1.575	1.282	.969	1.043	1.053	1.475	1.385
1010	3CR01	.917	.889	1.000	1.501	1.280	.906	.885	1.097	1.460	1.349
1020	3HP01	1.252	1.078	1.392	1.841	1.936	1.191	1.105	1.608	1.815	1.970
1030	3HP02	3.564	3.184	3.403	4.532	4.371	3.254	3.161	3.525	4.428	4.512
1040	3P001	2.8772	3.092	3.071	4.440	4.225	3.232	3.164	3.351	4.469	4.510
1050	3SP01	1.430	1.370	1.686	2.304	2.040	1.413	1.307	1.615	2.035	2.186

5250	SITE A											
5260	PERSONNEL DOSIMETERS - 6/20 TO 8/15/77											
5265	7.670	1.067	3.681	232	1.119	1.244	5.776					
5270	99											
5280	6C01	.280	.300	.327	.461	.415	.287	.311	.350	.450	.373	
5290	6C02	.266	.267	.299	.415	.362	.253	.271	.314	.429	.362	
5300	6C04	.234	.267	.286	.403	.359	.248	.282	.305	.373	.376	
5310	6C04	.234	.267	.286	.403	.359	.248	.283	.305	.373	.376	
5320	6C05	.263	.269	.314	.466	.367	.255	.287	.290	.459	.407	
5330	6C06	.422	.405	.442	.574	.550	.405	.415	.471	.558	.541	
5340	6C07	.313	.310	.311	.445	.377	.313	.325	.306	.423	.426	
5350	6C08	.332	.332	.371	.551	.476	.314	.324	.334	.519	.453	
5360	6C09	.264	.285	.262	.378	.365	.269	.264	.271	.397	.358	
5370	6C10	.345	.327	.331	.440	.469	.322	.331	.313	.415	.463	
5380	6P001	.369	.391	.435	.572	.557	.384	.384	.424	.577	.546	
5390	6P01	.266	.272	.314	.419	.366	.262	.252	.323	.438	.342	
5400	6002	.248	.270	.288	.285	.367	.260	.263	.268	.421	.350	
5410	6003	.256	.270	.260	.352	.353	.238	.254	.257	.391	.336	
5420	6004	.256	.280	.331	.458	.410	.263	.274	.316	.461	.380	
5430	6005	.263	.276	.304	.446	.368	.272	.272	.323	.445	.358	
5440	6006	.249	.273	.327	.479	.361	.249	.273	.308	.410	.398	
5450	6007	.275	.260	.301	.403	.374	.251	.262	.305	.405	.374	
5460	6008	.267	.278	.289	.430	.403	.272	.273	.294	.446	.413	
5470	6009	.274	.273	.271	.353	.352	.273	.275	.284	.373	.377	
5480	6010	.245	.271	.325	.446	.351	.249	.258	.314	.468	.357	
5490	6E01	.270	.275	.275	.331	.394	.289	.260	.242	.408	.352	
5500	6E02	.258	.277	.264	.392	.381	.266	.274	.262	.271	.368	
5510	6E03	.286	.299	.305	.486	.431	.292	.301	.336	.499	.412	
5520	6E04	.270	.300	.279	.401	.326	.271	.252	.284	.395	.366	
5530	6E05	.257	.272	.257	.391	.383	.254	.268	.255	.363	.346	
5540	6E06	.269	.272	.313	.397	.394	.272	.273	.310	.399	.405	
5550	6E07	.273	.285	.344	.419	.426	.283	.280	.347	.471	.420	
5560	6E08	.271	.274	.281	.358	.360	.279	.307	.277	.408	.404	
5570	6E09	.306	.346	.353	.482	.430	.286	.290	.364	.442	.433	
5580	6E10	.269	.276	.269	.380	.394	.260	.275	.297	.371	.385	
5590	6I01	.290	.319	.336	.435	.411	.293	.298	.322	.458	.424	
5600	6I02	.281	.281	.325	.425	.374	.262	.277	.326	.445	.412	
5610	6I03	.274	.275	.354	.471	.395	.255	.268	.345	.460	.420	
5620	6I04	.269	.274	.267	.403	.399	.289	.287	.279	.409	.379	
5630	6I05	.254	.253	.261	.391	.361	.257	.273	.281	.382	.357	
5640	6I06	.263	.282	.316	.457	.387	.263	.270	.308	.442	.386	
5650	6I07	.210	.263	.336	.481	.407	.272	.269	.307	.449	.383	
5660	6I08	.276	.270	.285	.390	.353	.262	.293	.257	.342	.351	
5670	6I09	.392	.399	.456	.416	.408	.367	.416	.450	.440	.392	
5680	6I10	.296	.315	.315	.429	.351	.302	.317	.307	.414	.392	
5690	6PI001	.211	.211	.226	.301	.287	.222	.223	.215	.323	.313	
5700	6PI002	.228	.251	.281	.387	.364	.229	.242	.275	.380	.356	
5710	6HF01	.599	.620	.639	.604	.768	.617	.581	.631	.871	.787	
5720	6HF02	1.296	1.416	1.374	1.884	1.699	1.284	1.361	1.334	1.915	1.567	
5730	6CH01	.510	.540	.561	.768	.702	.509	.546	.566	.730	.695	
5740	6CH02	.541	.398	.406	.566	.559	.385	.407	.393	.520	.505	

SITE A PERSONNEL DOSIMETERS - 6/20 TO 8/15/77

5750	6TRC01	.321	.319	.403	.522	.432	.316	.330	.368	.499	.469
5760	6TRC02	.325	.330	.404	.541	.478	.332	.339	.394	.529	.494
5770	65F01	1.551	1.580	1.947	2.432	2.543	1.576	1.735	2.033	2.527	2.572
5780	6P01	.307	.318	.307	.440	.400	.312	.350	.310	.396	.439
5790	6P02	.281	.320	.310	.421	.405	.287	.301	.313	.427	.381
5800	6P03	.273	.263	.327	.465	.385	.258	.286	.308	.447	.381
5810	6P04	.285	.297	.324	.462	.389	.274	.282	.326	.404	.401
5820	6P05	.266	.285	.348	.468	.417	.271	.281	.329	.452	.424
5830	6P06	.289	.274	.338	.459	.382	.281	.269	.308	.474	.396
5840	6P07	.252	.269	.269	.409	.376	.256	.276	.261	.379	.374
5850	6P08	.282	.282	.334	.433	.397	.271	.283	.321	.481	.358
5860	6P09	.260	.261	.265	.413	.362	.258	.265	.274	.399	.373
5870	6P10	.259	.261	.250	.394	.322	.244	.248	.250	.374	.334
5880	6AP001	.368	.364	.403	.527	.534	.374	.348	.389	.506	.489
5890	6AP002	.829	.786	.892	1.291	1.150	.805	.793	.884	1.126	1.150
5900	6AP003	.359	.361	.417	.554	.546	.383	.383	.392	.575	.549
5910	6CR01	.503	.448	.533	.632	.635	.519	.461	.520	.654	.610
5920	6PE002	.875	.828	.999	1.229	1.276	.855	.811	1.003	1.405	1.211
5930	3S001	.272	.310	.303	.445	.388	.268	.270	.330	.447	.414
5940	3S002	.310	.309	.285	.399	.382	.292	.286	.285	.386	.389
5950	1B164'	.368	.401	.402	.605	.533	.369	.383	.429	.551	.534
5960	6F01	.286	.277	.353	.433	.450	.297	.294	.340	.476	.432
5970	6F02	.305	.302	.380	.440	.397	.306	.320	.353	.449	.413
5980	6F03	.293	.287	.320	.472	.451	.287	.284	.326	.478	.434
5990	6F04	.266	.300	.345	.493	.430	.274	.307	.345	.420	.421
6000	6F05	.293	.285	.310	.410	.385	.273	.265	.309	.407	.414
6010	6F05	.392	.387	.450	.563	.564	.399	.394	.422	.611	.558
6020	6F06	.274	.288	.261	.406	.370	.269	.303	.276	.385	.355
6030	6F07	.297	.300	.324	.470	.419	.297	.298	.327	.475	.414
6040	6F08	.278	.296	.315	.441	.412	.274	.293	.321	.435	.409
6050	6F09	.254	.275	.334	.458	.394	.269	.288	.328	.459	.413
6060	6F10	.285	.287	.313	.508	.408	.291	.293	.300	.488	.411
6070	6M01	.285	.266	.329	.458	.377	.275	.298	.321	.462	.384
6080	6M02	.283	.279	.352	.454	.403	.277	.278	.310	.424	.374
6090	6M03	.260	.283	.315	.499	.411	.250	.277	.333	.411	.418
6100	6M04	.260	.278	.274	.416	.394	.274	.294	.272	.378	.360
6110	6M05	.289	.303	.378	.436	.449	.307	.302	.359	.464	.436
6120	6M06	.299	.310	.341	.453	.387	.295	.298	.332	.469	.405
6130	6M07	.237	.259	.245	.387	.362	.255	.276	.257	.345	.360
6140	6M08	.300	.285	.335	.427	.412	.278	.296	.325	.392	.410
6150	6M09	.304	.289	.340	.491	.380	.297	.267	.358	.490	.425
6160	6M10	.278	.278	.270	.383	.360	.282	.277	.291	.380	.372
6170	6S01	.294	.276	.331	.434	.436	.302	.279	.368	.489	.423
6180	6S02	.298	.304	.334	.492	.443	.281	.293	.344	.421	.423
6190	6S03	.299	.294	.311	.441	.406	.276	.281	.333	.453	.438
6200	6S04	.412	.380	.395	.578	.499	.392	.379	.385	.486	.530
6210	6S05	.305	.307	.325	.389	.403	.313	.290	.286	.404	.389
6220	6S06	.274	.279	.313	.419	.370	.260	.300	.329	.429	.386
6230	6S07	.317	.340	.346	.531	.488	.298	.327	.343	.463	.457
6240	6S08	.402	.416	.396	.495	.531	.398	.417	.402	.542	.502
6250	6S09	.340	.360	.339	.542	.524	.328	.364	.380	.546	.496
6260	6S10	.386	.368	.422	.555	.530	.371	.391	.405	.549	.511

2640 SITE A
 2650 PERSONNEL DOSIMETERS - 8/15 TO 12/20/77
 2655 8.107 1.101 3.698 306 1.088 1.221 5.458

2670	8C01	.331	.339	.380	.571	.513	.341	.340	.389	.534	.490
2680	8C03	.342	.377	.359	.617	.517	.348	.348	.359	.527	.527
2690	8C04	.331	.332	.396	.567	.458	.334	.329	.409	.503	.493
2700	8C05	.300	.321	.357	.519	.460	.300	.324	.400	.496	.460
2710	8C06	.314	.340	.372	.512	.485	.311	.355	.377	.538	.470
2720	8C07	.327	.311	.366	.513	.465	.316	.323	.356	.486	.432
2730	8C08	.447	.373	.442	.588	.537	.475	.367	.437	.573	.546
2740	8C09	.339	.373	.404	.574	.509	.352	.361	.387	.571	.490
2750	8C10	.310	.337	.405	.555	.505	.321	.323	.399	.546	.506
2760	9E01	.375	.349	.410	.614	.561	.397	.349	.446	.575	.559
2770	9E02	.340	.365	.420	.605	.495	.352	.351	.410	.605	.506
2780	9E03	.324	.324	.392	.539	.492	.301	.365	.376	.564	.485
2790	9E04	.330	.366	.403	.558	.500	.345	.336	.434	.547	.462
2800	9E05	.326	.320	.376	.480	.482	.298	.301	.347	.485	.463
2810	9E06	1.047	.558	.659	.646	.799	1.153	.522	.642	.668	.812
2820	9E07	.494	.392	.484	.621	.591	.477	.395	.441	.616	.583
2830	9E08	.327	.328	.410	.561	.494	.339	.338	.385	.549	.477
2840	9E09	.340	.352	.421	.478	.490	.339	.328	.404	.471	.481
2850	9E10	.316	.312	.394	.508	.478	.312	.333	.368	.505	.448
2860	9F01	.292	.305	.289	.465	.443	.295	.298	.273	.433	.423
2870	9F02	.381	.370	.419	.477	.512	.359	.361	.426	.533	.500
2880	9F03	.312	.298	.374	.554	.472	.309	.306	.379	.528	.502
2890	9F04	.303	.314	.363	.508	.495	.306	.301	.378	.519	.470
2900	9F05	.349	.319	.370	.544	.475	.323	.323	.345	.520	.482
2910	9F06	.318	.324	.379	.595	.501	.295	.309	.373	.600	.496
2920	9F07	.319	.325	.342	.520	.486	.326	.309	.324	.531	.429
2930	9F08	.310	.325	.357	.533	.500	.304	.311	.371	.532	.491
2940	9F09	.328	.320	.394	.546	.499	.313	.300	.376	.525	.474
2950	9F10	.311	.346	.361	.509	.493	.307	.322	.408	.536	.493
2960	9I01	.298	.308	.399	.563	.504	.317	.327	.402	.542	.485
2970	9I02	.328	.333	.375	.551	.484	.339	.366	.360	.566	.509
2980	9I03	.329	.369	.361	.568	.488	.344	.338	.369	.568	.514
2990	9I04	.304	.315	.366	.518	.472	.315	.324	.346	.528	.479
3000	9I05	.329	.310	.378	.570	.498	.325	.325	.368	.529	.495
3010	9I06	.321	.344	.377	.558	.495	.319	.318	.380	.551	.513
3020	9I07	.324	.309	.390	.555	.498	.322	.348	.374	.544	.502
3030	9I08	.310	.349	.357	.542	.485	.308	.332	.390	.527	.480
3040	9I09	.325	.305	.376	.503	.495	.337	.315	.378	.505	.483
3050	9I10	.312	.323	.409	.509	.511	.329	.352	.393	.529	.480
3060	9M01	.296	.329	.349	.582	.492	.347	.369	.349	.560	.502
3070	9M02	.324	.354	.386	.557	.510	.319	.329	.384	.533	.506
3080	9M03	.320	.325	.383	.553	.524	.325	.351	.388	.531	.484
3090	9M04	.324	.329	.389	.560	.506	.334	.360	.385	.539	.503
3100	9M05	.309	.320	.377	.531	.482	.323	.331	.393	.543	.475
3110	9M06	.314	.331	.404	.538	.489	.303	.314	.353	.574	.500
3120	9M07	.337	.341	.375	.528	.496	.321	.335	.366	.549	.518

SITE A PERSONNEL DOSIMETERS - 8/15 TO 12/20/77 (cont'd)

3130	8M08	.322	.329	.409	.525	.521	.314	.329	.393	.545	.503
3140	8M09	.310	.320	.383	.544	.481	.299	.331	.371	.549	.501
3150	8M10	.309	.327	.370	.531	.477	.337	.330	.379	.537	.506
3160	8001	.310	.355	.423	.540	.509	.320	.321	.393	.550	.517
3170	8002	.294	.313	.353	.519	.485	.296	.319	.352	.512	.439
3180	8003	.327	.348	.387	.565	.481	.321	.348	.392	.552	.418
3190	8004	.308	.299	.364	.516	.481	.294	.299	.348	.503	.421
3200	8005	.308	.328	.358	.520	.489	.293	.310	.369	.532	.460
3210	8007	.268	.283	.340	.525	.450	.327	.312	.385	.550	.481
3220	8008	.342	.328	.386	.539	.532	.331	.316	.355	.550	.520
3230	8009	.329	.351	.367	.510	.503	.328	.341	.402	.546	.495
3240	8010	.276	.314	.353	.506	.476	.296	.320	.362	.534	.473
3250	8P01	.330	.323	.377	.523	.503	.337	.312	.370	.552	.530
3260	8P02	.329	.319	.368	.526	.489	.309	.325	.400	.560	.494
3270	8P03	.322	.325	.382	.525	.485	.315	.332	.381	.541	.512
3280	8P04	.298	.327	.322	.484	.481	.305	.321	.295	.462	.447
3290	8P06	.322	.312	.381	.510	.519	.308	.313	.361	.516	.493
3300	8P07	.233	.253	.239	.364	.373	.239	.266	.243	.356	.356
3310	8P08	.362	.358	.405	.579	.486	.370	.340	.412	.585	.523
3320	8P09	.305	.300	.357	.527	.454	.291	.293	.362	.526	.434
3330	8P10	.286	.307	.347	.521	.443	.283	.297	.355	.511	.447
3340	8S01	.309	.335	.373	.534	.499	.292	.298	.367	.531	.489
3350	8S02	.337	.309	.368	.523	.527	.332	.301	.355	.534	.511
3360	8S05	.333	.340	.359	.547	.509	.326	.323	.392	.540	.520
3370	8S07	.325	.320	.331	.506	.444	.325	.317	.325	.461	.480
3380	8S08	.340	.378	.405	.563	.522	.339	.338	.389	.574	.495
3390	8S09	.331	.321	.403	.564	.515	.341	.320	.391	.526	.498
3400	8S10	.320	.333	.380	.583	.509	.324	.340	.394	.555	.505
3410	11I06	1.029	1.139	1.043	1.563	1.548	1.118	1.094	1.062	1.546	1.553
3420	8SF01	3.147	3.153	3.762	5.188	5.533	3.031	3.066	3.777	5.255	5.542
3430	8CH01	1.087	1.074	1.267	1.512	1.564	1.129	1.097	1.279	1.815	1.622
3440	8CH02	.520	.503	.589	.825	.799	.539	.556	.583	.838	.847
3450	8HP01	2.645	2.732	3.135	4.466	4.409	2.576	2.816	3.246	4.414	4.415
3460	8HP03	1.215	1.078	1.322	1.768	1.659	1.109	1.105	1.306	1.702	1.767
3470	TRC01	.415	.420	.470	.667	.553	.424	.395	.495	.667	.537
3480	TRC02	.458	.414	.483	.693	.527	.487	.414	.459	.672	.533
3490	8P001	.404	.383	.453	.638	.569	.384	.370	.457	.675	.569
3500	8P002	1.151	1.254	1.419	1.968	1.754	1.214	1.297	1.342	1.787	1.699
3510	AP001	.444	.433	.504	.711	.658	.442	.443	.481	.731	.660
3520	PE002	1.965	2.036	2.163	3.088	2.967	1.980	2.059	2.042	3.053	3.070
3530	AP003	.395	.434	.476	.719	.632	.417	.446	.457	.716	.642
3540	8HP02	1.414	1.419	1.697	2.470	2.266	1.347	1.437	1.682	2.542	2.377
3550	CH20P	.327	.327	.324	.495	.483	.324	.355	.343	.504	.473
3560	2T164	.484	.480	.484	.812	.743	.477	.481	.477	.845	.754
3570	8S001	.315	.332	.373	.554	.456	.299	.312	.380	.559	.459
3580	8S002	.357	.332	.416	.519	.497	.340	.364	.391	.571	.500
3590	PIG01	.189	.196	.256	.395	.334	.186	.187	.260	.407	.337
3600	PIG02	.189	.185	.240	.407	.321	.190	.196	.238	.395	.321

21170 SITE B

21180 PERSONNEL DOSIMETERS - 7/10 TO 9/17/76

21185	6.968	1.194	3.708	260	1.077	1.388	5.345				
21190	86										
21200	A-1	.254	.261	.274	.436	.408	.259	.254	.274	.440	.389
21210	A-2	.246	.243	.300	.424	.361	.247	.233	.282	.419	.364
21220	B-1	.270	.260	.294	.425	.426	.265	.276	.286	.458	.399
21230	B-2	.248	.247	.277	.411	.381	.247	.260	.275	.422	.392
21240	B-3	.364	.371	.381	.528	.529	.355	.372	.378	.558	.521
21250	B-4	.314	.292	.313	.472	.441	.272	.306	.323	.475	.441
21260	B-5	.310	.322	.362	.515	.515	.350	.322	.349	.537	.490
21270	C-1	.255	.222	.283	.365	.357	.244	.275	.270	.396	.383
21280	C-2	.299	.282	.314	.424	.435	.266	.292	.285	.465	.392
21290	C-3	.297	.302	.339	.471	.456	.299	.310	.328	.475	.447
21300	C-4	.249	.236	.266	.389	.344	.226	.243	.247	.385	.330
21310	D-1	.287	.270	.322	.421	.405	.284	.290	.323	.435	.413
21320	D-2	.261	.259	.303	.442	.390	.265	.244	.289	.432	.384
21330	D-3	.573	.582	.602	.867	.851	.572	.617	.586	.869	.792
21340	D-4	.700	.710	.678	1.046	.960	.726	.742	.708	.994	.982
21350	D-5	.516	.535	.496	.544	.494	.506	.528	.536	.538	.490
21360	D-6	.267	.278	.279	.451	.394	.240	.284	.290	.401	.387
21370	E-1	.388	.398	.389	.626	.533	.429	.403	.429	.595	.515
21380	G-1	.264	.234	.298	.421	.365	.244	.260	.273	.420	.376
21390	G-2	.519	.562	.550	.763	.762	.540	.538	.552	.743	.703
21400	G-3	.270	.262	.287	.447	.391	.285	.266	.297	.424	.399
21410	H-1	.289	.287	.297	.406	.420	.265	.262	.311	.444	.388
21420	H-2	.320	.308	.341	.444	.467	.312	.304	.325	.519	.396
21430	H-3	.310	.298	.337	.452	.474	.308	.314	.336	.492	.446
21440	H-4	.273	.289	.292	.450	.402	.270	.275	.296	.463	.415
21450	J-1	.289	.266	.312	.443	.380	.274	.269	.292	.423	.371
21460	J-2	.279	.288	.313	.449	.407	.280	.264	.309	.477	.440
21470	K-1	.353	.339	.353	.542	.510	.348	.338	.343	.558	.468
21480	K-2	.286	.288	.334	.429	.442	.278	.284	.310	.434	.406
21490	K-3	.309	.327	.358	.503	.473	.309	.322	.342	.522	.470
21500	K-4	.270	.277	.294	.462	.410	.267	.281	.297	.464	.385
21510	K-5	.303	.306	.356	.520	.475	.314	.312	.338	.515	.461
21520	L-1	.704	.671	.649	.948	.913	.693	.643	.635	.961	.930
21530	L-2	.311	.327	.345	.498	.499	.336	.336	.341	.499	.461
21540	L-3	.218	.225	.255	.380	.347	.228	.234	.249	.373	.328
21550	L-4	.320	.288	.311	.467	.415	.291	.294	.368	.497	.438
21560	L-5	.247	.282	.298	.425	.385	.266	.268	.303	.431	.359
21570	M-1	.349	.375	.397	.524	.507	.351	.344	.390	.559	.489
21580	M-2	.333	.337	.337	.501	.451	.314	.317	.336	.492	.442
21590	M-3	.270	.299	.309	.445	.401	.320	.297	.302	.441	.397
21600	M-4	.259	.248	.292	.429	.333	.245	.247	.284	.416	.377
21610	P-1	.511	.527	.526	.729	.749	.492	.515	.563	.765	.746
21620	P-2	.264	.274	.283	.429	.407	.261	.267	.312	.454	.413
21630	P-3	.257	.232	.270	.351	.335	.236	.232	.242	.366	.336
21640	R-1	.794	.813	.778	1.201	1.095	.764	.745	.749	1.088	1.153
21650	R-2	.316	.321	.329	.540	.464	.329	.356	.348	.513	.477

SITE B PERSONNEL DOSIMETERS - 7/10 TO 9/17/76 (cont'd)

21660	S-1	.305	.318	.364	.513	.463	.319	.326	.351	.512	.461
21670	S-2	.269	.268	.301	.419	.393	.276	.270	.342	.426	.401
21680	S-3	.217	.216	.240	.369	.334	.206	.225	.242	.360	.333
21690	T-1	.372	.397	.392	.554	.553	.383	.403	.400	.545	.520
21700	T-2	.358	.354	.395	.538	.522	.365	.342	.366	.560	.505
21710	W-1	.277	.284	.306	.461	.372	.274	.289	.317	.448	.414
21720	W-2	.270	.280	.338	.447	.431	.278	.289	.303	.479	.397
21730	505-1	.906	.828	.912	1.186	1.265	.968	.866	.925	1.382	1.359
21740	507-1	2.077	1.955	2.137	32.600	24.100	1.976	2.034	2.152	40.600	25.000
21750	510-1	.510	.521	.529	.693	.711	.523	.505	.512	.775	.700
21760	518-1	2.530	2.398	2.314	60.000	37.500	2.399	2.412	2.483	61.000	36.500
21770	519-1	.556	.583	.598	.883	.828	.566	.543	.601	.890	.860
21780	609-1	2.849	2.578	2.957	47.600	31.800	3.001	3.055	2.995	49.400	30.600
21790	616-1	3.176	2.940	3.054	4.201	4.318	3.177	2.985	2.966	4.372	4.410
21800	616-2	.137	.140	.162	.232	.207	.139	.148	.169	.230	.208
21810	643-1	1.429	1.447	1.414	1.859	1.974	1.452	1.489	1.292	1.907	2.009
21820	645-1	1.235	1.306	1.163	1.628	1.657	1.249	1.162	1.199	1.670	1.504
21830	646-1	2.304	2.243	2.186	3.170	2.780	2.125	2.161	2.263	3.141	2.923
21840	PC-1	.212	.217	.242	.328	.310	.214	.208	.246	.351	.322
21850	PC-2	.198	.217	.250	.355	.307	.206	.199	.237	.361	.321
21860	CO-1	.237	.203	.255	.376	.341	.217	.231	.267	.359	.310
21870	CO-2	.215	.224	.224	.345	.332	.210	.209	.261	.381	.347
21880	CH-1	.242	.225	.255	.372	.341	.214	.221	.249	.327	.340
21890	CH-2	.218	.229	.265	.388	.318	.205	.222	.249	.355	.316
21900	Z-01	.188	.187	.219	.351	.312	.194	.193	.234	.344	.314
21910	Z-02	.189	.189	.224	.296	.321	.187	.195	.230	.344	.304
21920	Z-03	.202	.181	.222	.298	.298	.189	.188	.221	.363	.293
21930	Z-04	.191	.196	.229	.348	.320	.191	.187	.231	.347	.333
21940	Z-1	.520	.479	.560	9.344	5.616	.527	.519	.548	8.984	5.303
21950	Z-2	.433	.457	.500	9.035	5.723	.428	.448	.504	9.246	5.350
21960	Z-3	.522	.554	.650	8.792	5.465	.523	.564	.544	9.222	5.908
21970	Z-4	1.347	1.205	1.561	107.700	58.400	1.314	1.237	1.418	108.800	61.100
21980	Z-5	.465	.461	.523	8.680	5.279	.501	.488	.508	8.409	5.324
21990	Z-6	.272	.290	.324	.474	.426	.297	.262	.325	.434	.435
22000	Z-7	.460	.457	.520	7.400	4.961	.459	.456	.508	9.056	5.727
22010	Z-8	.488	.488	.508	7.374	5.356	.457	.513	.508	8.397	5.465
22020	Z-9	.526	.556	.569	9.713	5.659	.544	.518	.589	9.190	5.795
22030	Z-10	.518	.502	.542	9.181	8.542	.553	.523	.541	9.282	9.190
22040	Z-11	1.276	1.841	1.427	109.500	56.400	1.255	1.229	1.454	106.00	56.000

17890 SITE B
17900 PERSONNEL DOSIMETERS - 9/18 TO 11/29/76

17905	8.312	1.112	4.084	360	1.128	1.295	7.008				
17910	71										
17920	A-1	.282	.278	.341	.485	.426	.273	.283	.340	.445	.447
17930	B-1	.273	.281	.313	.459	.416	.284	.268	.300	.471	.413
17940	B-2	.213	.228	.274	.416	.375	.230	.226	.263	.427	.341
17950	B-4	.239	.217	.274	.385	.367	.233	.243	.270	.354	.349
17960	B-5	.289	.274	.306	.472	.435	.260	.291	.309	.480	.421
17970	B-6	.258	.274	.297	.443	.379	.248	.276	.287	.374	.383
17980	C-1	.260	.262	.306	.448	.380	.241	.273	.297	.454	.396
17990	C-2	.284	.258	.288	.468	.409	.279	.285	.317	.467	.390
18000	C-3	.309	.305	.340	.501	.456	.291	.307	.341	.494	.452
18010	C-4	.254	.274	.297	.408	.385	.264	.256	.303	.428	.377
18020	D-1	.220	.249	.257	.402	.370	.222	.242	.277	.417	.349
18030	D-2	.252	.245	.301	.436	.378	.262	.271	.290	.447	.362
18040	D-3	.478	.489	.518	.720	.672	.466	.536	.574	.771	.690
18050	D-4	.475	.486	.489	.728	.689	.466	.490	.498	.736	.651
18060	D-5	.315	.332	.343	.476	.468	.337	.329	.352	.534	.465
18070	D-6	.241	.265	.285	.412	.385	.266	.242	.277	.397	.356
18080	E-1	.382	.403	.412	.593	.541	.382	.418	.432	.585	.543
18090	F-1	.315	.315	.359	.519	.455	.317	.306	.334	.496	.454
18100	G-2	.228	.240	.270	.411	.350	.244	.261	.257	.403	.360
18110	G-3	.266	.236	.262	.397	.364	.240	.221	.258	.415	.348
18120	H-2	.261	.281	.310	.439	.399	.280	.282	.318	.465	.403
18130	H-3	.298	.299	.322	.478	.442	.305	.311	.327	.494	.429
18140	H-4	.252	.268	.313	.403	.411	.269	.266	.297	.432	.372
18150	H-5	.270	.268	.307	.423	.395	.254	.268	.301	.459	.391
18160	J-1	.258	.295	.308	.436	.402	.262	.270	.291	.400	.402
18170	J-2	.271	.272	.293	.436	.406	.267	.243	.291	.439	.388
18180	K-1	.397	.405	.417	.573	.547	.413	.411	.439	.613	.512
18190	K-2	.240	.243	.270	.416	.368	.242	.244	.274	.408	.362
18200	K-3	.300	.314	.336	.483	.433	.302	.297	.330	.490	.443
18210	K-4	.250	.269	.269	.448	.385	.259	.267	.282	.434	.341
18220	L-1	.455	.458	.471	.680	.612	.454	.445	.473	.686	.628
18230	L-2	.311	.344	.375	.524	.434	.310	.336	.378	.523	.438
18240	L-3	.237	.237	.275	.425	.392	.236	.278	.279	.417	.403
18250	L-4	.288	.267	.295	.505	.419	.298	.282	.314	.497	.426
18260	L-5	.238	.242	.290	.445	.377	.244	.255	.283	.384	.373
18270	L-6	.286	.305	.320	.483	.429	.289	.303	.322	.452	.425
18280	M-1	.322	.310	.346	.479	.465	.291	.313	.313	.499	.449
18290	M-2	.275	.287	.314	.465	.411	.277	.281	.321	.474	.415
18300	M-3	.257	.230	.291	.431	.353	.249	.251	.269	.429	.355
18310	M-4	.313	.293	.365	.476	.441	.296	.293	.347	.455	.441
18320	M-5	.285	.273	.318	.444	.399	.267	.260	.304	.443	.421
18330	P-2	.267	.271	.283	.439	.401	.269	.260	.307	.442	.405
18340	R-1	.543	.592	.635	.816	.756	.588	.554	.586	.799	.771
18350	R-2	.310	.317	.339	.503	.444	.302	.300	.342	.515	.471
18360	S-1	.251	.267	.284	.420	.380	.269	.271	.306	.419	.413
18370	S-2	.251	.265	.282	.455	.336	.231	.258	.285	.434	.337

SITE B PERSONNEL DOSIMETERS - 9/18 TO 11/29/76 (cont'd)

18380	S-3	.207	.211	.266	.356	.314	.200	.218	.258	.367	.314
18390	S-4	.345	.360	.373	.531	.489	.338	.349	.374	.525	.486
18400	W-1	.273	.272	.276	.414	.397	.272	.272	.285	.448	.377
18410	W-2	.285	.298	.329	.477	.443	.297	.281	.333	.468	.377
18420	505-1	1.407	1.340	1.450	1.992	1.916	1.530	1.462	1.441	1.971	1.955
18430	507-1	3.759	3.595	3.459	10.3	8.052	3.826	3.517	3.397	10.8	8.196
18440	510-1	1.066	1.129	1.164	1.516	1.442	1.152	1.194	1.207	1.555	1.433
18450	516-1	12.4	13.4	12.7	96.5	60.5	12.1	13.0	12.7	83.8	52.9
18460	518-1	3.354	3.384	3.278	5.949	5.604	3.190	3.269	3.030	6.036	6.071
18470	519-1	.698	.670	.744	1.031	.975	.689	.701	.791	1.016	.962
18480	520-1	4.711	4.785	4.497	6.184	6.124	4.577	4.618	4.502	6.015	5.686
18490	609-1	1.978	2.045	2.016	2.690	2.735	1.907	1.989	1.977	2.593	2.615
18500	616-1	3.324	3.258	3.176	4.325	4.454	3.325	3.328	3.190	4.453	4.389
18510	643-1	.752	.718	.719	1.036	.942	.667	.688	.680	.997	.924
18520	645-1	.854	.810	.844	1.157	1.206	.899	.804	.885	1.122	1.140
18530	646-1	1.530	1.537	1.492	2.052	2.076	1.607	1.426	1.445	1.983	1.938
18540	TLD-1	.230	.220	.260	.381	.347	.211	.239	.275	.372	.341
18550	CO-1	.209	.219	.259	.376	.319	.201	.204	.261	.356	.313
18560	CO-2	.201	.212	.258	.365	.343	.207	.207	.242	.384	.346
18570	CH-1	.246	.263	.281	.438	.366	.243	.257	.270	.420	.378
18580	CH-2	.231	.232	.280	.416	.335	.225	.243	.270	.439	.350
18590	CNTRL	.367	.360	.396	.600	.517	.361	.360	.384	.618	.586
18600	CNTRL	.199	.217	.273	.378	.327	.212	.203	.234	.363	.320
18610	CNTRL	.207	.212	.245	.381	.329	.196	.209	.257	.354	.322
18620	CNTRL	.206	.204	.251	.378	.339	.216	.211	.287	.379	.339

15150 SITE B

15160 PERSONNEL DOSIMETERS - 11/29/76 TO 2/14/77

15165 7.676 1.084 4.077 290 1.021 1.268 6.148

15170 69

15180	A-1	.233	.231	.272	.378	.312	.229	.239	.238	.349	.300
15190	A-2	.309	.311	.359	.527	.472	.308	.304	.351	.528	.451
15200	B-1	.228	.229	.268	.334	.306	.233	.222	.250	.355	.304
15210	B-3	.242	.233	.248	.324	.312	.223	.221	.245	.336	.295
15220	B-5	.227	.206	.249	.329	.298	.224	.220	.278	.361	.302
15230	C-1	.212	.219	.249	.336	.286	.192	.222	.254	.326	.285
15240	C-2	.234	.224	.266	.329	.294	.203	.237	.248	.357	.287
15250	C-3	.183	.208	.240	.324	.268	.186	.298	.247	.303	.299
15260	C-4	.217	.209	.244	.346	.298	.211	.217	.235	.348	.288
15270	D-3	.298	.305	.314	.404	.407	.295	.309	.333	.431	.391
15280	D-4	.372	.359	.364	.481	.429	.347	.371	.371	.513	.413
15290	D-5	.240	.244	.262	.360	.332	.243	.228	.266	.367	.322
15300	D-6	.206	.207	.224	.315	.273	.207	.316	.231	.307	.267
15310	E-1	.221	.226	.237	.355	.308	.232	.221	.263	.338	.312
15320	F-1	.208	.236	.253	.335	.287	.218	.215	.236	.354	.286
15330	G-1	.210	.236	.249	.365	.312	.229	.227	.284	.352	.293
15340	G-3	.221	.232	.257	.360	.313	.228	.230	.249	.372	.322
15350	H-2	.206	.204	.259	.318	.307	.217	.201	.243	.334	.294
15360	H-3	.220	.222	.239	.377	.289	.229	.226	.242	.327	.289
15370	H-4	.187	.198	.227	.308	.305	.196	.207	.227	.319	.274
15380	H-5	.213	.233	.269	.343	.340	.208	.232	.260	.347	.317
15390	J-1	.204	.193	.231	.329	.274	.209	.200	.244	.320	.268
15400	J-2	.206	.187	.217	.308	.285	.213	.215	.229	.354	.272
15410	K-1	.288	.260	.301	.394	.359	.286	.271	.302	.400	.375
15420	K-3	.204	.218	.253	.321	.302	.199	.207	.231	.337	.287
15430	K-4	.253	.241	.247	.367	.334	.231	.231	.255	.380	.323
15440	K-5	.347	.369	.431	.535	.532	.389	.376	.420	.519	.498
15450	L-1	.274	.267	.299	.375	.365	.267	.281	.308	.358	.358
15460	L-2	.269	.266	.292	.397	.349	.256	.278	.304	.396	.351
15470	L-3	.215	.210	.242	.313	.289	.215	.224	.230	.305	.281
15480	L-4	.234	.240	.251	.350	.314	.213	.223	.224	.319	.288
15490	L-6	.216	.222	.251	.352	.309	.216	.220	.237	.325	.294
15500	M-1	.242	.246	.275	.352	.315	.259	.241	.265	.351	.313
15510	M-2	.195	.193	.221	.298	.288	.208	.189	.225	.313	.270
15520	M-3	.411	.456	.407	.549	.459	.408	.463	.486	.540	.529
15530	M-4	.196	.209	.239	.300	.266	.191	.196	.229	.301	.293
15540	M-5	.200	.220	.214	.319	.269	.193	.211	.219	.306	.284
15550	P-1	.257	.264	.286	.403	.346	.267	.267	.297	.384	.392
15560	P-2	.218	.210	.237	.328	.300	.203	.227	.230	.322	.273
15580	P-3	.224	.220	.240	.294	.265	.204	.208	.234	.293	.288
15590	R-1	.403	.402	.400	.527	.549	.403	.372	.428	.531	.511
15600	R-2	.219	.216	.263	.316	.293	.220	.225	.251	.319	.288
15610	S-1	.207	.220	.226	.359	.309	.213	.230	.231	.336	.293
15620	S-2	.203	.223	.235	.370	.284	.211	.216	.247	.331	.290

SITE B PERSONNEL DOSIMETERS - 11/29/76 TO 2/14/77 (cont'd)

15630	S-3	.218	.213	.243	.299	.277	.203	.214	.240	.309	.275
15640	S-4	.227	.232	.250	.364	.296	.211	.244	.257	.349	.286
15650	T-2	.424	.463	.469	.675	.639	.418	.510	.506	.694	.626
15660	W-1	.185	.200	.226	.317	.280	.190	.205	.217	.302	.269
15670	W-2	.285	.263	.298	.419	.366	.289	.274	.302	.385	.348
15680	505	1.405	1.362	1.325	1.652	1.668	1.507	1.408	1.356	1.755	1.683
15690	507	.951	1.005	.956	12.9	8.978	.964	.971	.997	13.4	8.386
15700	518	1.347	1.291	1.264	5.892	4.845	1.337	1.359	1.318	6.368	4.674
15710	519	.715	.697	.749	1.349	1.136	.708	.682	.695	1.383	1.190
15720	520	3.800	3.530	3.579	4.856	4.711	3.182	3.757	3.494	4.617	4.441
15730	516	4.812	4.620	4.617	7.871	7.000	4.470	4.187	4.617	7.834	7.819
15740	609	1.866	1.767	1.683	2.281	2.213	1.871	1.912	1.888	2.293	2.229
15750	616	1.941	2.202	2.131	2.758	2.761	2.127	2.078	2.182	2.791	2.783
15760	643	1.481	1.387	1.282	1.727	1.687	1.417	1.341	1.475	1.871	1.688
15770	645	1.754	1.590	1.558	2.161	2.048	1.731	1.623	1.692	2.249	2.130
15780	646	1.903	1.823	1.709	2.276	2.496	1.942	1.712	1.959	2.140	2.511
15790	CONT1	.161	.169	.198	.291	.254	.179	.172	.196	.293	.254
15800	CONT2	.162	.175	.321	.285	.258	.173	.179	.213	.262	.236
15810	CONT3	.176	.182	.217	.301	.258	.175	.179	.216	.287	.246
15820	CONT4	.182	.193	.198	.274	.263	.171	.190	.212	.279	.281
15830	TLD-1	.187	.187	.212	.288	.265	.189	.190	.218	.315	.249
15840	TLD-2	.188	.180	.222	.287	.260	.185	.182	.199	.282	.243
15850	CH-1	.188	.184	.221	.297	.298	.173	.191	.209	.298	.261
15860	CH-2	.177	.187	.228	.313	.265	.192	.184	.206	.303	.268

12690	SITE B										
12700	PERSONNEL DOSIMETERS - 2/14 TO 4/8/77										
12705	6.987	1.090	4.138	292	1.116	1.335	5.752				
12710	66										
12720	A-1	.247	.268	.276	.393	.385	.249	.273	.268	.375	.345
12730	B-1	.200	.202	.207	.297	.291	.207	.190	.208	.327	.289
12740	B-3	.436	.444	.484	.698	.638	.444	.429	.470	.728	.626
12750	B-5	.221	.225	.235	.351	.311	.218	.225	.233	.353	.332
12760	C-1	.183	.199	.219	.318	.271	.188	.203	.198	.305	.279
12770	C-2	.189	.204	.217	.295	.294	.198	.197	.200	.323	.293
12780	C-3	.197	.179	.218	.320	.293	.198	.197	.211	.307	.286
12790	C-4	.223	.224	.235	.304	.318	.224	.225	.240	.322	.329
12800	D-3	.447	.427	.430	.549	.539	.408	.441	.436	.580	.540
12810	D-4	.502	.498	.540	.619	.691	.489	.498	.505	.639	.650
12820	D-5	.270	.255	.276	.403	.348	.260	.274	.270	.428	.358
12830	D-6	.229	.216	.265	.338	.300	.219	.228	.256	.347	.308
12840	E-1	.313	.295	.316	.456	.384	.286	.314	.311	.452	.402
12850	F-1	.262	.272	.285	.388	.344	.278	.273	.299	.382	.335
12860	G-3	.293	.242	.250	.359	.284	.284	.240	.259	.366	.321
12870	H-2	.253	.251	.277	.384	.356	.248	.249	.286	.374	.353
12880	H-3	.271	.272	.287	.388	.358	.277	.268	.294	.393	.376
12890	H-4	.232	.239	.252	.377	.329	.240	.254	.262	.371	.355
12900	H-5	.295	.294	.313	.396	.421	.282	.286	.317	.415	.408
12910	J-1	.248	.255	.279	.368	.373	.245	.251	.269	.394	.374
12920	K-1	.405	.403	.449	.549	.526	.422	.395	.435	.528	.535
12930	K-3	.269	.276	.275	.369	.370	.264	.256	.292	.411	.380
12940	K-4	.226	.242	.261	.368	.314	.223	.235	.268	.361	.338
12950	K-5	.215	.228	.250	.368	.255	.216	.241	.240	.361	.275
12960	L-1	.200	.205	.235	.337	.311	.194	.206	.226	.340	.321
12970	L-2	.230	.246	.252	.366	.352	.217	.244	.247	.368	.341
12980	L-3	.170	.175	.176	.267	.244	.180	.178	.184	.292	.250
12990	L-4	.197	.186	.208	.299	.273	.181	.197	.202	.277	.284
13000	L-6	.203	.222	.233	.349	.301	.226	.227	.244	.349	.304
13010	M-1	.243	.242	.246	.372	.342	.250	.246	.262	.371	.360
13020	M-2	.218	.233	.233	.312	.332	.226	.227	.250	.337	.320
13030	M-3	.175	.184	.200	.293	.238	.173	.179	.198	.303	.253
13040	M-4	.194	.215	.225	.322	.298	.204	.213	.235	.317	.311
13050	M-5	.190	.199	.224	.326	.293	.205	.209	.228	.327	.299
13060	P-1	.307	.306	.323	.416	.406	.291	.290	.331	.472	.385
13070	P-1	.525	.490	.533	.827	.666	.513	.532	.531	.810	.748
13080	P-2	.212	.221	.234	.343	.312	.208	.203	.227	.342	.324
13090	P-3	.165	.163	.189	.279	.244	.168	.177	.201	.268	.215
13100	R-1	.393	.413	.427	.577	.574	.392	.403	.391	.600	.538
13110	R-2	.228	.239	.259	.373	.324	.236	.225	.257	.361	.347
13120	S-1	.233	.231	.255	.363	.332	.223	.239	.254	.367	.333
13130	S-2	.206	.216	.230	.326	.295	.210	.216	.227	.352	.311
13140	S-3	.162	.162	.189	.264	.230	.160	.166	.189	.269	.233
13150W	-1	.190	.200	.218	.310	.280	.187	.207	.209	.313	.284

SITE B PERSONNEL DOSIMETERS - 2/14 TO 4/8/77 (cont'd)

13160W-2	.204	.209	.220	.322	.296	.198	.210	.209	.305	.309		
13170 505	3.493	3.283	3.258	4.307	4.386	3.355	3.295	3.245	4.294	4.017		
13180 507	1.390	1.414	1.449	1.941	1.929	1.406	1.437	1.468	1.998	1.829		
13190 516	6.775	6.372	6.720	8.600	9.493	6.391	6.847	6.684	9.720	8.810		
13200 518	3.892	3.958	3.706	5.180	5.375	3.837	3.918	3.509	5.465	5.209		
13210 519	.613	.626	.614	.930	.798	.624	.625	.626	.952	.855		
13220 520	6.442	6.454	6.120	9.875	8.530	6.168	6.791	5.997	8.285	7.672		
13230 609	2.348	2.403	2.412	3.142	3.200	2.436	2.358	2.466	3.184	3.046		
13240 616	3.114	3.096	3.208	4.136	4.422	3.395	3.396	3.181	4.541	4.345		
13250 643	8.640	8.488	9.226	10.700	11.900	9.178	8.921	8.881	12.100	12.400		
13260 645	3.208	2.898	2.969	4.105	4.164	3.359	3.014	3.051	4.113	3.910		
13270 646	2.591	2.385	2.423	3.122	3.128	2.547	2.332	2.256	3.225	3.135		
13280 TLD-1	.154	.162	.186	.279	.242	.161	.151	.186	.274	.251		
13290 TLD-2	.154	.170	.191	.280	.229	.148	.168	.192	.273	.235		
13300 RGC-1	.146	.153	.189	.272	.236	.149	.159	.182	.293	.237		
13310 RGC-2	.149	.159	.193	.265	.229	.150	.157	.188	.275	.232		
13320 HP-1	.200	.194	.255	.312	.289	.210	.185	.255	.328	.294		
13330 HP-2	.187	.204	.237	.330	.295	.204	.202	.251	.325	.296		
13340 C-1	.160	.161	.185	.263	.247	.148	.158	.190	.277	.231		
13350 C-2	.160	.153	.174	.249	.242	.150	.156	.188	.287	.238		
13360 C-3	.152	.164	.187	.259	.278	.160	.156	.181	.293	.221		
13370 C-4	.159	.161	.195	.281	.235	.147	.152	.189	.273	.249		

8280	SITE B											
8290	PERSONNEL DOSIMETERS - 4/4 TO 6/8/77											
8295	7.100	1.078	3.607	250	1.010	1.181	6.113					
8300	64											
8310	#A1	.298	.308	.349	.474	.411	.308	.325	.344	.426	.408	
8320	#B1	.312	.316	.347	.477	.443	.320	.314	.349	.486	.432	
8330	#B2	.282	.277	.320	.417	.370	.270	.286	.306	.385	.388	
8340	#B3	.234	.246	.272	.361	.350	.230	.243	.267	.390	.319	
8350	#C1	1.580	1.529	1.623	2.119	1.974	1.638	1.642	1.569	2.052	1.953	
8360	#C2	.311	.315	.340	.448	.397	.309	.327	.341	.501	.419	
8370	#C2	.234	.234	.293	.393	.354	.227	.236	.272	.376	.343	
8380	#C3	.276	.259	.302	.298	.334	.241	.249	.303	.416	.343	
8390	#C4	.281	.295	.314	.439	.415	.296	.285	.317	.455	.425	
8400	#D1	.303	.323	.344	.448	.403	.297	.331	.339	.449	.420	
8410	#D2	.312	.297	.350	.461	.422	.290	.310	.347	.507	.425	
8440	#D5	.434	.310	.428	.631	.538	.405	.415	.453	.583	.588	
8450	#D6	.505	.488	.518	.610	.681	.501	.500	.504	.697	.610	
8460	#D7	.324	.339	.345	.472	.395	.323	.340	.350	.494	.430	
8470	#E1	.316	.361	.356	.441	.463	.320	.319	.338	.451	.419	
8480	#F1	.320	.316	.361	.453	.461	.316	.336	.356	.470	.435	
8490	#F2	1.480	1.498	1.531	5.687	2.139	1.574	1.496	1.536	5.724	4.089	
8500	#F3	.943	1.002	1.007	1.210	1.255	.966	1.014	1.038	1.243	1.227	
8510	#G1	.495	.502	.581	2.461	1.619	.392	.573	.544	2.547	1.636	
8520	#G2	.250	.258	.293	.431	.376	.240	.244	.291	.289	.267	
8530	#H1	.305	.327	.359	.461	.405	.308	.321	.338	.486	.440	
8540	#H2	.267	.261	.305	.415	.416	.268	.268	.322	.400	.399	
8550	#J1	.261	.248	.284	.405	.357	.233	.247	.284	.277	.334	
8560	#K1	.380	.368	.406	.545	.525	.379	.362	.393	.539	.529	
8570	#K2	.286	.304	.346	.459	.442	.301	.311	.332	.454	.428	
8580	#K3	.234	.250	.258	.397	.327	.237	.223	.264	.364	.322	
8590	#L1	.324	.324	.352	.442	.443	.315	.303	.365	.524	.408	
8600	#L2	.273	.283	.320	.430	.364	.275	.286	.345	.455	.409	
8610	#L3	.217	.236	.273	.381	.358	.240	.251	.271	.391	.337	
8620	#L4	.303	.284	.313	.474	.425	.287	.288	.319	.473	.279	
8630	#M1	.270	.285	.293	.385	.345	.267	.255	.313	.424	.392	
8640	#M2	.310	.309	.350	.425	.403	.292	.310	.322	.462	.455	
8650	#M3	.455	.408	.491	3.528	2.143	.458	.459	.470	3.395	2.068	
8660	#M4	.333	.335	.357	.472	.436	.323	.317	.356	.485	.445	
8670	#M5	.270	.308	.313	.438	.385	.291	.280	.313	.465	.363	
8680	#M6	.264	.288	.318	.432	.431	.287	.291	.330	.454	.380	
8690	#M7	4.791	5.306	5.048	6.181	6.192	4.812	5.023	4.697	7.096	6.126	
8700	#N1	1.303	1.226	1.256	1.679	1.534	1.168	1.262	1.268	1.710	1.530	
8710	#P1	.283	.278	.333	.464	.423	.278	.290	.333	.455	.402	
8720	#P2	.265	.275	.308	.460	.394	.283	.253	.319	.443	.486	
8730	#R1	.276	.264	.308	.427	.396	.274	.262	.310	.286	.370	
8740	#S1	.322	.326	.384	.463	.476	.338	.323	.358	.509	.464	
8750	#S2	.346	.357	.376	.533	.504	.343	.354	.373	.535	.489	
8760	#S3	.288	.298	.339	.440	.414	.274	.299	.322	.453	.403	

SITE B PERSONNEL DOSIMETERS - 4/4 TO 6/8/77 (cont'd)

8770	#S4	.921	.866	.854	1.160	1.021	.956	.845	.834	1.114	1.190
8780	#S5	.757	.786	.797	1.031	.914	.746	.743	.813	1.026	1.030
8790	#S6	.272	.272	.314	.452	.354	.263	.288	.294	.420	.378
8800	#T1	.232	.233	.278	.368	.326	.245	.249	.270	.397	.344
8820	#T3	1.122	1.097	1.115	1.407	1.381	1.136	1.100	1.139	1.438	1.349
8830	#RC*	.216	.220	.244	.344	.329	.215	.218	.268	.369	.314
8840	#RC2*	.216	.215	.251	.368	.300	.205	.212	.253	.343	.329
8850	#W1	.282	.281	.325	.395	.400	.262	.281	.298	.408	.364
8860	#W2	.268	.285	.304	.465	.375	.269	.285	.322	.441	.408
8870	#Z1	.851	.845	.933	1.308	1.236	.910	.890	.929	1.189	1.112
8880	#T01	.209	.207	.240	.337	.287	.200	.202	.251	.353	.297
8890	#T02	.205	.204	.248	.361	.286	.207	.200	.249	.358	.326
8900	#HP1	.177	.191	.229	.330	.272	.195	.183	.237	.312	.268
8910	#HP2	.180	.193	.219	.310	.268	.193	.185	.230	.310	.279
8940	#NU1	.210	.192	.235	.329	.301	.213	.202	.239	.332	.329
8950	#NU2	.206	.216	.234	.364	.290	.193	.209	.254	.359	.292
8960	#NU3	.211	.211	.255	.374	.298	.212	.209	.278	.362	.311

6400	SITE B											
6410	PERSONNEL DOSIMETERS - 6/8 TO 9/1/77											
6415	7.441	1.054	4.010	319	.996	1.288	7.543					
6420	64											
6430	A-1	.269	.289	.307	.483	.434	.268	.281	.317	.416	.499	
6440	B-1	.272	.272	.323	.441	.391	.262	.261	.305	.472	.407	
6450	B-3	.268	.269	.317	.461	.385	.254	.280	.322	.454	.434	
6460	B-5	.254	.273	.324	.469	.402	.273	.273	.293	.482	.432	
6470	C-1	.284	.267	.306	.460	.402	.256	.275	.290	.432	.409	
6480	C-2	.231	.254	.309	.451	.384	.252	.267	.300	.452	.387	
6490	C-3	.351	.348	.367	.565	.504	.346	.344	.388	.522	.511	
6500	C-4	.283	.259	.291	.459	.409	.264	.281	.297	.430	.403	
6510	C-5	1.900	1.929	1.910	3.194	3.178	1.970	1.806	1.849	3.475	3.051	
6520	D-2	.290	.308	.357	.473	.468	.282	.316	.351	.510	.449	
6530	D-4	.423	.454	.492	.570	.614	.416	.452	.463	.736	.624	
6540	D-5	.350	.346	.376	.577	.496	.344	.348	.369	.571	.473	
6550	D-6	.298	.304	.343	.531	.451	.298	.288	.340	.542	.440	
6560	E-1	.304	.304	.339	.508	.471	.306	.292	.358	.528	.435	
6570	F-1	.313	.296	.339	.513	.437	.305	.304	.380	.520	.439	
6580	G-3	.305	.292	.354	.500	.468	.282	.305	.347	.474	.449	
6590	H-2	.378	.376	.408	.568	.530	.344	.348	.401	.573	.496	
6600	K-1	.392	.376	.455	.637	.578	.415	.409	.433	.628	.567	
6610	K-3	.311	.328	.357	.556	.442	.321	.301	.358	.545	.468	
6620	L-1	.276	.287	.333	.454	.430	.281	.291	.327	.508	.443	
6630	L-4	.322	.310	.378	.527	.451	.298	.317	.351	.543	.464	
6640	L-6	.311	.321	.372	.510	.465	.291	.288	.367	.538	.451	
6650	M-1	.296	.312	.328	.509	.421	.302	.286	.357	.512	.452	
6660	M-2	.301	.310	.370	.543	.491	.317	.334	.350	.575	.464	
6670	M-5	.278	.262	.312	.487	.440	.262	.250	.322	.499	.423	
6680	F-2	.301	.306	.369	.543	.462	.310	.317	.369	.545	.483	
6690	F-3	.340	.324	.399	.558	.506	.346	.315	.373	.530	.505	
6700	R-1	.301	.302	.364	.502	.456	.286	.312	.322	.502	.465	
6710	R-2	.300	.304	.339	.497	.417	.288	.311	.353	.490	.387	
6720	S-1	.374	.341	.421	.507	.477	.332	.351	.415	.603	.513	
6730	S-2	.149	.164	.189	.283	.197	.152	.158	.197	.303	.242	
6740	S-3	.390	.412	.444	.638	.579	.391	.393	.409	.657	.575	
6750	S-4	.318	.359	.408	.574	.512	.324	.333	.391	.503	.476	
6760	T-2	.298	.307	.371	.504	.447	.291	.314	.370	.523	.442	
6770	W-1	.274	.278	.340	.497	.415	.286	.294	.336	.499	.420	
6780	W-2	.306	.323	.363	.550	.446	.342	.320	.345	.551	.477	
6790	505	1.265	1.216	1.140	1.597	1.452	1.313	1.238	1.149	1.631	1.472	
6800	507	1.015	1.082	1.146	41.400	24.100	1.055	1.036	1.157	39.900	28.800	
6810	516	1.026	1.028	1.048	2.735	2.342	1.040	1.042	1.136	2.799	2.235	
6820	518	.982	.930	1.191	40.900	21.300	.969	1.141	1.141	40.400	24.300	
6830	519	1.886	1.803	2.091	117.900	64.700	1.180	1.797	1.880	123.600	64.200	
6840	520	3.179	3.309	3.367	35.200	19.700	3.242	3.402	3.324	35.100	20.500	
6850	609	1.030	1.013	1.073	1.520	1.357	.998	1.007	1.083	1.448	1.348	
6860	643	.997	.968	1.031	1.316	1.191	1.006	.987	1.013	1.472	1.283	
6870	645	1.061	1.092	1.130	1.449	1.307	1.101	1.033	1.112	1.328	1.430	
6880	646	2.746	2.729	2.499	3.532	3.169	2.590	2.632	2.585	3.403	3.297	
6890	X-1	.281	.301	.359	.504	.477	.285	.290	.343	.499	.446	

SITE B PERSONNEL DOSIMETERS - 6/8 TO 9/1/77 (cont'd)

6900	X-2	.271	.273	.317	.465	.434	.263	.261	.322	.480	.435
6910	X-3	.289	.302	.359	.470	.448	.297	.295	.360	.513	.455
6920	X-4	.258	.260	.321	.439	.408	.254	.274	.324	.461	.406
6930	X-5	.296	.303	.384	.525	.461	.288	.311	.351	.543	.445
6940	RGC-1	.251	.256	.311	.448	.406	.236	.256	.300	.462	.364
6950	RGC-2	.241	.259	.321	.471	.418	.254	.248	.308	.469	.392
6960	RGC-4	.242	.257	.314	.502	.388	.264	.261	.321	.474	.366
6970	HP-1	.133	.133	.167	.282	.212	.133	.139	.165	.301	.219
6980	HP-2	.132	.127	.176	.300	.213	.128	.130	.154	.288	.182
6990	TLD-R	.226	.238	.282	.456	.393	.221	.233	.295	.443	.362
7000	TLD-R	.222	.232	.287	.441	.368	.222	.234	.287	.468	.402
7040	CONT6	.249	.254	.309	.477	.424	.259	.262	.331	.470	.409
7050	CONT6	.239	.237	.304	.451	.374	.239	.230	.304	.446	.352
7060	CONT6	.240	.249	.309	.415	.410	.228	.234	.288	.473	.396

3620 SITE B
3630 PERSONNEL DOSIMETERS - 9/1 TO 9/10 TO 11/1/77

3635	7.355	1.133	3.710	337	.912	1.262	8.340						
3640	50												
3650	A-1	.261	.257	.288	.455	.442	.248	.250	.296	.425	.409		
3660	A-2	.133	.167	.203	.324	.275	.164	.169	.202	.324	.272		
3670	B-1	.207	.218	.215	.418	.342	.218	.213	.248	.403	.369		
3680	B-2	.254	.253	.299	.474	.397	.264	.260	.293	.501	.402		
3690	B-3	.190	.233	.231	.413	.330	.189	.207	.229	.378	.321		
3700	C-1	.980	1.007	1.096	1.398	1.355	.992	1.007	1.014	1.247	1.226		
3710	C-2	.199	.190	.239	.393	.320	.217	.207	.240	.388	.324		
3720	C-3	.198	.215	.237	.377	.329	.203	.212	.234	.363	.336		
3730	C-4	.229	.217	.246	.376	.329	.225	.216	.253	.373	.330		
3740	D-1	.227	.224	.265	.414	.331	.206	.236	.248	.393	.356		
3750	D-2	.194	.204	.248	.416	.338	.195	.201	.243	.384	.340		
3760	D-3	.328	.322	.388	.596	.495	.354	.302	.385	.531	.453		
3770	D-4	.220	.220	.294	.387	.332	.215	.214	.258	.398	.370		
3780	E-1	.235	.236	.268	.424	.355	.252	.233	.268	.424	.367		
3790	F-1	.251	.238	.253	.405	.366	.250	.244	.267	.383	.369		
3800	F-2	.242	.290	.286	.586	.504	.251	.259	.308	.649	.524		
3810	G-1	.697	.737	.790	1.207	1.071	.666	.703	.800	1.156	1.121		
3820	G-3	.201	.192	.232	.372	.309	.195	.200	.224	.373	.317		
3830	K-1	.283	.286	.323	.480	.413	.289	.298	.331	.488	.439		
3840	K-2	.219	.240	.275	.448	.381	.245	.226	.264	.407	.367		
3850	L-1	.228	.208	.267	.427	.355	.227	.224	.265	.386	.397		
3860	L-4	.230	.249	.268	.335	.364	.228	.239	.270	.408	.347		
3870	L-6	.208	.198	.248	.385	.361	.216	.203	.236	.410	.356		
3880	M-1	.215	.236	.245	.312	.387	.229	.206	.255	.405	.357		
3890	M-2	.221	.218	.259	.449	.355	.217	.219	.260	.431	.333		
3900	M-3	.216	.205	.251	.411	.340	.224	.214	.263	.403	.347		
3910	P-3	.262	.271	.324	.461	.387	.277	.275	.332	.473	.438		
3920	R-1	.212	.222	.250	.406	.343	.215	.226	.263	.399	.307		
3930	R-2	.217	.220	.256	.393	.339	.209	.213	.272	.414	.357		
3940	S-3	.366	.373	.401	.555	.514	.352	.381	.411	.538	.505		
3950	S-4	.261	.262	.288	.427	.420	.264	.280	.275	.456	.417		
3960	T-2-1	.241	.229	.255	.419	.355	.222	.229	.281	.466	.348		
3980	W-1	.202	.203	.235	.393	.406	.193	.221	.260	.406	.342		
3990	W-2	.243	.242	.280	.457	.391	.241	.233	.277	.456	.383		
4000	505	.693	.641	.640	.960	.874	.752	.613	.650	.966	.898		
4010	507	.252	.226	.276	.680	.530	.245	.237	.278	.659	.544		
4020	519	1.021	.953	.921	28.000	17.400	1.098	.944	.921	27.900	17.100		
4030	520	1.685	1.850	2.450	2.786	1.697	1.695	1.850	1.630	2.886	2.303		
4040	609	.557	.572	.607	.817	.789	.580	.559	.606	.844	.802		
4050	643	.382	.392	.426	.583	.569	.408	.395	.446	.651	.570		
4060	645	.444	.473	.466	.670	.566	.454	.427	.468	.724	.576		
4070	646	1.891	1.878	1.756	1.781	2.294	1.787	1.841	1.747	2.266	2.195		
4080	HPSO	.151	.192	.228	.362	.295	.182	.184	.238	.375	.306		
4090	HPSO	.188	.184	.233	.379	.300	.194	.187	.230	.388	.298		
4100	HPSH	.190	.186	.232	.360	.335	.195	.185	.224	.375	.314		
4110	HPSH	.184	.192	.219	.349	.332	.189	.184	.222	.370	.326		
4120	EXTRA	.181	.184	.223	.341	.292	.176	.182	.231	.333	.320		
4130	EXTRA	.183	.176	.234	.375	.303	.164	.176	.227	.389	.282		
4140	EXTRA	.174	.171	.208	.328	.302	.184	.179	.215	.350	.279		

19810 SITE C

19820 PERSONNEL DOSIMETERS - 6/2 TO 10/20/76

19825	6.968	1.194	3.708	260	1.077	1.388	5.345					
19830	30											
19840	002-6	.371	.411	.457	.688	.600	.385	.386	.440	.629	.578	
19850	003-6	.293	.289	.354	.517	.472	.299	.293	.355	.521	.509	
19860	004-6	.313	.324	.363	.499	.481	.322	.319	.363	.536	.508	
19870	005-6	.332	.583	.391	.591	.533	.338	.502	.369	.612	.544	
19880	006-6	.360	.417	.417	.660	.542	.331	.358	.404	.616	.537	
19890	007-6	.289	.290	.323	.542	.468	.284	.304	.338	.509	.470	
19900	008-6	.313	.342	.389	.576	.514	.348	.337	.388	.629	.526	
19910	009-6	.260	.254	.297	.465	.352	.269	.251	.295	.486	.387	
19920	010-6	.289	.287	.328	.477	.488	.303	.289	.320	.559	.470	
19930	012-6	.298	.301	.352	.573	.487	.303	.324	.345	.577	.492	
19940	013-6	.306	.297	.348	.594	.502	.288	.290	.346	.558	.497	
19950	014-6	.289	.298	.329	.518	.484	.300	.321	.333	.490	.456	
19960	015-6	.307	.295	.329	.523	.478	.284	.301	.344	.502	.478	
19970	016-6	.327	.317	.379	.537	.485	.310	.341	.345	.522	.480	
19980	017-6	.320	.299	.370	.547	.491	.318	.334	.350	.577	.491	
19990	019-6	.327	.360	.394	.593	.549	.337	.331	.420	.635	.543	
20000	020-6	.340	.321	.385	.533	.536	.327	.331	.387	.547	.551	
20010	021-6	.333	.340	.356	.602	.518	.336	.352	.401	.586	.545	
20020	022-6	.345	.341	.389	.638	.581	.359	.353	.372	.618	.547	
20030	023-6	.301	.293	.336	.533	.443	.295	.269	.321	.509	.450	
20040	024-6	.317	.333	.339	.579	.506	.323	.331	.342	.594	.503	
20050	025-6	.285	.277	.322	.463	.371	.275	.286	.296	.491	.376	
20060	026-6	.299	.321	.352	.542	.488	.304	.292	.343	.544	.512	
20070	027-6	.368	.344	.392	.618	.540	.338	.334	.397	.606	.510	
20080	028-6	.356	.349	.376	.592	.493	.349	.361	.405	.574	.510	
20090	029-6	.257	.265	.316	.512	.428	.254	.284	.321	.505	.446	
20100	030-6	.256	.284	.332	.502	.468	.278	.276	.347	.513	.464	
20110	BKG#1	.311	.348	.394	.588	.531	.326	.321	.375	.547	.510	
20120	BKG#2	.256	.239	.291	.391	.314	.246	.247	.288	.390	.310	
20130	BKG#3	.233	.224	.253	.355	.357	.246	.255	.249	.338	.314	

16120	SITE C											
16130	PERSONNEL DOSIMETERS - 10/20 TO 1/29/77											
16135	7.838	1.131	4.090	310	1.026	1.273	5.219					
16140	70											
16150	CS-1	.214	.198	.229	.370	.308	.212	.197	.240	.358	.330	
16160	CS-2	.206	.216	.266	.331	.311	.208	.194	.247	.369	.342	
16170	CS-3	.204	.219	.228	.352	.320	.204	.218	.228	.318	.321	
16180	CS-4	.210	.235	.222	.322	.315	.233	.228	.236	.328	.311	
16190	CS-5	.213	.212	.263	.368	.333	.221	.198	.244	.366	.303	
16200	CS-6	.198	.199	.206	.298	.292	.208	.198	.189	.306	.294	
16210	LTA-1	.255	.245	.266	.372	.339	.233	.219	.265	.388	.306	
16220	LTA-2	.241	.212	.255	.404	.339	.219	.207	.256	.406	.322	
16230	CE-1	.219	.215	.255	.347	.302	.209	.204	.239	.351	.297	
16240	CTA-1	.211	.213	.246	.389	.332	.212	.217	.250	.368	.308	
16250	CTA-2	.203	.197	.256	.342	.313	.196	.206	.238	.336	.309	
16260	CTA-3	.228	.207	.207	.320	.305	.221	.217	.205	.326	.319	
16270	CTA-4	.203	.223	.250	.377	.327	.215	.227	.246	.368	.324	
16280	CTA-5	.210	.215	.246	.369	.323	.203	.209	.254	.364	.315	
16290	CTA-6	.232	.212	.253	.368	.330	.201	.201	.246	.376	.311	
16300	CTA-7	.207	.219	.204	.302	.294	.205	.219	.210	.304	.312	
16310	CTA-8	.171	.194	.237	.365	.298	.182	.200	.226	.336	.303	
16320	CTA-9	.225	.229	.261	.372	.345	.209	.211	.253	.394	.306	
16330	CTA10	.351	.327	.399	.377	.326	.340	.340	.394	.423	.354	
16340	O-1	.234	.227	.285	.397	.360	.236	.228	.266	.405	.361	
16350	O-2	.233	.228	.271	.367	.344	.222	.229	.270	.404	.355	
16360	O-3	.215	.222	.271	.386	.319	.213	.223	.273	.385	.313	
16370	O-4	.414	.283	.318	.433	.385	.393	.276	.305	.431	.374	
16380	O-5	.238	.235	.290	.397	.377	.236	.246	.288	.407	.372	
16390	O-6	.211	.219	.271	.369	.352	.223	.236	.277	.405	.367	
16400	T-1	.236	.228	.296	.392	.335	.233	.222	.294	.393	.380	
16410	T-2	.256	.259	.288	.414	.374	.261	.259	.301	.403	.380	
16420	T-3	1.152	2.905	1.373	4.256	3.600	1.303	3.329	1.692	4.845	3.439	
16430	T-4	.230	.241	.288	.416	.365	.238	.237	.280	.397	.329	
16440	T-5	.220	.210	.204	.310	.313	.211	.223	.219	.332	.300	
16450	T-6	.244	.234	.280	.410	.363	.248	.236	.304	.432	.371	
16460	MO-1	.207	.217	.266	.376	.355	.213	.222	.264	.379	.340	
16470	MO-2	.210	.214	.277	.378	.332	.206	.226	.265	.389	.333	
16480	MO-3	.202	.208	.257	.370	.318	.196	.218	.256	.372	.311	
16490	MO-4	.212	.222	.217	.327	.302	.222	.219	.228	.342	.318	
16500	MO-5	.206	.217	.213	.336	.324	.218	.205	.229	.291	.318	
16510	MO-6	.229	.226	.274	.391	.373	.230	.224	.273	.389	.361	
16520	MO-7	.214	.235	.270	.357	.342	.221	.229	.281	.377	.340	
16530	MO-8	.207	.205	.214	.330	.308	.228	.232	.234	.321	.312	
16540	MO-9	.308	.283	.323	.487	.465	.323	.263	.348	.467	.474	
16550	MO-10	.232	.218	.239	.338	.334	.214	.219	.226	.344	.317	
16560	AO-1	.231	.242	.240	.360	.343	.236	.235	.254	.345	.347	
16570	AO-2	.245	.235	.268	.397	.365	.242	.245	.285	.396	.356	
16580	AO-3	.222	.242	.239	.363	.335	.246	.246	.237	.368	.337	
16590	AO-4	.242	.225	.298	.426	.348	.239	.241	.294	.428	.359	
16600	AO-5	.237	.253	.291	.416	.354	.232	.249	.297	.421	.355	
16610	AO-6	.228	.235	.298	.410	.328	.235	.238	.284	.415	.338	
16620	AO-7	.220	.228	.280	.400	.367	.228	.235	.283	.422	.342	

SITE C - PERSONNEL DOSIMETERS - 10/20 TO 1/29/77

16630	AD-8	.245	.253	.295	.359	.361	.235	.243	.299	.413	.379
16640	AF-1	.223	.220	.262	.355	.332	.229	.223	.260	.333	.294
16650	AF-2	.215	.218	.271	.388	.321	.219	.221	.256	.386	.343
16660	AF-3	.235	.225	.269	.405	.344	.230	.223	.265	.375	.348
16670	AF-4	.214	.215	.225	.328	.308	.211	.231	.209	.330	.308
16680	AF-5	.245	.260	.278	.423	.338	.257	.244	.263	.408	.318
16690	AF-6	.235	.242	.267	.402	.355	.232	.239	.280	.380	.360
16700	AF-7	.217	.207	.258	.344	.310	.209	.213	.252	.396	.307
16710	AF-8	.220	.229	.302	.418	.351	.224	.238	.278	.388	.368
16720	QCF-1	.237	.227	.216	.319	.313	.221	.226	.219	.305	.291
16730	QCF-2	.226	.213	.247	.397	.324	.229	.224	.255	.380	.324
16740	QCF-3	.219	.233	.253	.394	.334	.237	.242	.265	.406	.347
16750	QCF-4	.226	.241	.274	.427	.356	.234	.239	.287	.403	.349
16760	QCF-5	.206	.204	.255	.369	.325	.204	.206	.248	.330	.321
16770	QCF-6	.214	.211	.268	.369	.325	.211	.219	.259	.361	.337
16780	QCF-7	.237	.230	.230	.344	.333	.222	.225	.238	.360	.328
16790	QCF-8	.242	.237	.284	.393	.363	.218	.229	.275	.402	.367
16800	FE-1	.226	.210	.245	.363	.303	.216	.206	.235	.347	.286
16810	FE-2	.196	.205	.250	.385	.334	.217	.208	.262	.387	.330
16820	CON-1	.139	.131	.187	.318	.257	.141	.139	.195	.313	.272
16830	CON-2	.228	.243	.240	.354	.351	.252	.228	.241	.369	.338
16840	CON-3	.222	.218	.228	.322	.316	.210	.215	.224	.315	.309

11850 SITE C

11860 PERSONNEL DOSIMETERS - 1/29 TO 4/12/77

11865	7.232	1.021	4.294	259	1.073	1.293	5.297				
1187081											
11880CS-1	.279	.296	.337	.474	.453	.300	.283	.347	.513	.416	
11890CS-2	.305	.301	.373	.499	.454	.289	.284	.360	.527	.475	
11900CS-3	.301	.294	.331	.522	.448	.290	.325	.343	.523	.451	
11910CS-4	.299	.291	.360	.533	.466	.287	.294	.350	.524	.438	
11920CS-5	.303	.285	.327	.489	.443	.282	.290	.331	.506	.408	
11930CS-6	.318	.312	.355	.545	.457	.313	.322	.367	.548	.482	
11940LTA-1	.286	.280	.332	.501	.431	.286	.298	.318	.490	.396	
11950LTA-2	.303	.327	.362	.534	.447	.320	.304	.360	.565	.522	
11960LTA-3	.282	.267	.345	.310	.443	.284	.298	.339	.468	.421	
11970LTA-4	.298	.294	.341	.508	.417	.304	.278	.339	.491	.454	
11980LTA-5	.296	.275	.344	.480	.457	.298	.285	.309	.472	.444	
11990LTA-6	.294	.299	.358	.485	.449	.299	.300	.348	.494	.447	
12000CE-1	.280	.295	.345	.490	.394	.290	.287	.343	.471	.399	
12010CTA-1	.276	.295	.326	.502	.430	.264	.288	.342	.494	.454	
12020CTA-2	.293	.301	.341	.504	.442	.327	.301	.347	.529	.467	
12030CTA-3	.300	.304	.341	.524	.453	.299	.302	.353	.507	.439	
12040CTA-4	.311	.290	.316	.499	.429	.319	.319	.351	.500	.428	
12050CTA-5	.289	.291	.313	.511	.412	.297	.303	.359	.481	.432	
12060CTA-6	.300	.287	.356	.507	.418	.299	.288	.315	.503	.401	
12070CTA-7	.282	.297	.354	.447	.424	.279	.286	.336	.492	.465	
12080CTA-8	.319	.332	.356	.547	.469	.327	.305	.356	.534	.463	
120900-1	.295	.278	.317	.474	.416	.297	.271	.363	.496	.413	
121000-2	.279	.275	.324	.520	.441	.295	.294	.304	.494	.430	
121100-3	.281	.301	.338	.490	.424	.301	.311	.337	.493	.438	
121200-4	.284	.258	.330	.470	.401	.262	.281	.335	.478	.410	
121300-5	.295	.295	.342	.503	.430	.290	.321	.376	.517	.460	
121400-6	.308	.296	.371	.513	.447	.324	.329	.324	.552	.456	
121500-7	.777	.642	.723	.961	.942	.715	.716	.741	.926	.960	
12160T-1	.273	.286	.328	.516	.431	.298	.292	.341	.475	.470	
12170T-2	.299	.299	.348	.494	.449	.301	.323	.359	.525	.419	
12180T-3	.295	.306	.370	.513	.446	.296	.278	.349	.526	.431	
12190T-4	.290	.290	.309	.501	.429	.296	.285	.344	.485	.450	
12200T-5	.288	.291	.336	.483	.451	.290	.284	.317	.479	.431	
12210T-6	.403	.383	.317	.483	.358	.403	.420	.320	.467	.398	
12220T-7	.284	.309	.340	.499	.406	.290	.299	.357	.527	.424	
12230MO-1	.268	.314	.347	.525	.445	.290	.289	.351	.517	.453	
12240MO-2	.290	.298	.354	.534	.469	.266	.316	.359	.509	.448	
12250MO-3	.293	.299	.352	.506	.444	.282	.292	.324	.494	.445	
12260MO-4	.303	.273	.349	.523	.437	.294	.302	.352	.522	.424	
12270MO-5	.296	.291	.322	.506	.434	.314	.292	.322	.475	.411	
12280MO-6	.309	.328	.331	.508	.445	.313	.303	.362	.539	.464	
12290MO-7	.309	.279	.340	.504	.450	.286	.294	.342	.506	.451	
12300MO-8	.295	.280	.359	.490	.431	.288	.303	.333	.530	.449	
12310MO-9	.405	.426	.455	.605	.574	.298	.409	.443	.581	.541	
12320MO-10	.299	.293	.339	.516	.410	.311	.297	.343	.524	.468	
12330AO-1	.289	.311	.349	.553	.450	.313	.293	.357	.516	.465	

SITE C PERSONNEL DOSIMETERS - 1/29 TO 4/12/77 (cont'd)

12340AU-2	.281	.269	.339	.466	.413	.283	.292	.334	.484	.420
12350AU-3	.296	.298	.370	.537	.471	.299	.300	.368	.489	.471
12360AU-4	.291	.325	.369	.497	.449	.304	.304	.363	.504	.481
12370AU-5	.311	.318	.368	.492	.457	.317	.301	.368	.532	.451
12380AF-1	.266	.279	.322	.436	.407	.290	.251	.327	.470	.418
12390AF-2	.303	.288	.331	.460	.451	.281	.285	.328	.465	.455
12400AF-3	.287	.317	.365	.465	.447	.296	.298	.366	.533	.424
12410AF-4	.285	.287	.339	.500	.421	.284	.291	.345	.462	.429
12420AF-5	.302	.293	.342	.513	.426	.300	.312	.348	.506	.451
12430AF-6	.314	.310	.348	.522	.455	.288	.322	.356	.527	.474
12440AF-7	.271	.278	.334	.494	.419	.283	.273	.336	.492	.431
12450AF-8	.316	.284	.364	.506	.464	.296	.300	.347	.523	.468
12460AF-9	.277	.285	.338	.505	.430	.293	.311	.336	.512	.435
12470AF-10	.271	.278	.339	.464	.394	.271	.264	.348	.478	.417
12480QCF-1	.293	.290	.349	.516	.432	.302	.291	.340	.483	.439
12490QCF-3	.315	.288	.356	.517	.434	.312	.288	.370	.501	.458
12500QCF-4	.278	.309	.349	.478	.425	.279	.309	.353	.507	.430
12510QCF-5	.275	.281	.343	.521	.410	.279	.292	.342	.492	.431
12520QCF-6	.300	.291	.337	.488	.409	.286	.276	.351	.458	.415
12530QCF-7	.303	.295	.353	.474	.438	.289	.304	.344	.517	.440
12540QCF-8	.288	.296	.355	.482	.446	.284	.301	.341	.477	.444
12550IWA-1	.301	.308	.395	.531	.455	.313	.326	.369	.549	.486
12560IWA-2	.422	.377	.404	.550	.511	.417	.340	.379	.529	.529
12570IWA-3	.311	.331	.366	.584	.501	.324	.336	.398	.543	.501
12580IWA-4	.290	.283	.339	.473	.443	.297	.290	.351	.537	.473
12590ANK-1	.308	.304	.367	.511	.453	.302	.317	.365	.491	.464
12600ANK-2	.297	.319	.364	.518	.411	.299	.291	.365	.494	.435
12610FE-1	.270	.270	.325	.498	.411	.284	.263	.341	.470	.386
12620CCF-2	.276	.304	.344	.487	.421	.286	.291	.339	.465	.420
12630FE-2	.320	.298	.329	.493	.443	.319	.312	.356	.478	.469
12640UK-1	.297	.304	.391	.494	.612	.285	.299	.382	.553	.519
12650UK-2	.301	.309	.368	.508	.455	.303	.302	.362	.526	.462
12660CON-3	.274	.288	.356	.504	.422	.281	.291	.360	.499	.429
12670 CON-4	.291	.299	.352	.515	.462	.295	.298	.342	.543	.437
12680CON-5	.228	.228	.261	.444	.380	.231	.235	.282	.429	.352

7420 SITE C

7430 PERSONNEL DOSIMETERS - 4/12 TO 7/12/77

7435 7.509 1.102 3.638 273 1.027 1.304 5.234

7440 83

7450 CON-1 .308 .322 .296 .485 .460 .303 .306 .296 .466 .450

7480 C-1 .299 .324 .372 .538 .469 .330 .317 .369 .531 .453

7490 C-2 .298 .309 .358 .548 .456 .308 .270 .368 .523 .454

7500 C-3 .300 .310 .358 .521 .485 .329 .303 .359 .548 .490

7510 C-4 .310 .321 .310 .494 .413 .301 .310 .299 .481 .400

7520 C-5 .310 .298 .346 .514 .436 .314 .306 .376 .475 .487

7530 C-6 .324 .323 .392 .538 .450 .313 .312 .388 .523 .472

7540 C-7 .271 .289 .329 .488 .408 .278 .281 .365 .462 .415

7550 C-8 .307 .314 .370 .531 .471 .302 .300 .367 .552 .467

7560 C-9 .300 .305 .352 .531 .477 .295 .329 .357 .526 .433

7570 IW-1 .302 .299 .342 .541 .492 .305 .301 .350 .536 .450

7580 IW-2 .315 .347 .335 .497 .429 .329 .352 .330 .498 .489

7590 IW-3 .316 .335 .378 .552 .464 .315 .321 .389 .562 .501

7600 IW-4 .322 .326 .376 .560 .435 .307 .321 .382 .571 .487

7630 L-1 .286 .303 .362 .503 .497 .287 .326 .355 .545 .478

7640 L-2 .288 .283 .352 .530 .484 .279 .281 .323 .534 .460

7650 L-3 .288 .297 .363 .515 .468 .319 .315 .355 .523 .430

7660 L-4 .284 .303 .350 .519 .456 .296 .295 .345 .533 .443

7670 L-5 .301 .308 .361 .509 .441 .296 .305 .360 .527 .504

7680 L-6 .382 .388 .430 .585 .527 .359 .397 .424 .597 .537

7690 MO-1 .305 .302 .307 .477 .456 .319 .291 .309 .457 .451

7700 MO-2 .297 .287 .340 .541 .480 .299 .311 .331 .525 .448

7710 MO-3 .297 .301 .354 .517 .448 .293 .326 .357 .516 .474

7720 MO-4 .311 .314 .371 .526 .478 .295 .312 .368 .516 .494

7730 MO-5 .303 .300 .363 .539 .499 .298 .298 .376 .544 .497

7740 MO-6 .319 .321 .378 .542 .508 .298 .297 .373 .539 .434

7750 MO-7 .292 .298 .364 .528 .475 .305 .316 .338 .530 .464

7760 MO-8 .304 .299 .322 .435 .429 .283 .321 .323 .444 .450

7770 MO-9 .471 .389 .373 .531 .524 .482 .394 .376 .571 .560

7780 MO-10 .305 .300 .354 .544 .482 .304 .320 .357 .509 .482

7790 AO-1 .302 .325 .311 .479 .467 .295 .314 .327 .487 .429

7800 AO-2 .307 .315 .311 .454 .463 .285 .309 .331 .490 .457

7810 AO-3 .377 .341 .382 .588 .540 .323 .354 .399 .587 .480

7820 AO-4 .319 .322 .363 .522 .479 .306 .344 .367 .556 .483

7830 AO-5 .309 .341 .385 .552 .457 .320 .322 .373 .507 .514

7840 AO-6 .311 .310 .391 .534 .494 .304 .329 .372 .561 .518

7850 AO-7 .328 .328 .367 .522 .483 .308 .326 .360 .538 .497

7860 AO-8 .295 .297 .402 .521 .483 .294 .292 .381 .538 .449

7870 OPE-1 .302 .319 .363 .508 .457 .306 .326 .373 .471 .463

7880 OPE-2 .296 .305 .362 .485 .495 .297 .320 .371 .525 .491

7890 OPE-3 .307 .319 .356 .534 .453 .333 .309 .372 .542 .490

7900 OPE-4 .306 .311 .332 .521 .473 .309 .317 .341 .528 .466

7910 OPE-5 .296 .291 .305 .456 .446 .298 .309 .300 .455 .444

7920 OPE-6 .344 .364 .390 .585 .512 .352 .366 .407 .590 .536

7930 OPE-7 .321 .294 .355 .541 .451 .298 .312 .342 .518 .504

7940 OPE-8 .294 .309 .341 .521 .476 .303 .279 .349 .508 .468

7950 AF-1 .299 .293 .326 .494 .463 .284 .295 .349 .545 .460

7960 AF-2 .294 .296 .358 .533 .468 .309 .295 .346 .491 .480

SITE C - PERSONNEL DOSIMETERS - 4/12 TO 7/12/77

7970	AF-3	.307	.314	.365	.547	.475	.300	.299	.347	.544	.469
7980	AF-4	.294	.255	.340	.521	.449	.294	.298	.327	.521	.452
7990	AF-5	.305	.319	.312	.513	.466	.314	.317	.318	.483	.430
8000	AF-6	.316	.313	.368	.573	.513	.307	.315	.376	.537	.489
8010	AF-7	.302	.300	.296	.463	.450	.319	.299	.298	.493	.434
8020	AF-8	.308	.322	.363	.516	.445	.321	.309	.347	.543	.480
8030	AF-9	.307	.297	.370	.501	.459	.275	.297	.373	.510	.454
8040	QCF-1	.316	.326	.386	.594	.504	.298	.325	.388	.553	.506
8050	QCF-2	.310	.309	.356	.558	.517	.306	.320	.354	.542	.489
8060	QCF-3	.275	.280	.275	.462	.432	.285	.285	.272	.456	.438
8070	QCF-4	.298	.310	.367	.554	.476	.295	.307	.371	.561	.469
8080	QCF-5	.316	.306	.308	.497	.445	.308	.297	.306	.478	.415
8090	QCF-6	.298	.311	.383	.459	.496	.319	.329	.369	.496	.504
8100	QCF-8	.319	.310	.375	.573	.468	.316	.291	.373	.552	.456
8110	QCF-9	.311	.309	.349	.549	.509	.290	.324	.358	.557	.499
8120	QCF-10	.304	.307	.368	.542	.523	.312	.323	.384	.525	.522
8130	CS-1	.294	.317	.345	.566	.486	.306	.297	.354	.537	.465
8140	CS-2	.499	.475	.368	.556	.491	.477	.483	.361	.541	.485
8150	CS-3	.292	.300	.291	.464	.435	.305	.303	.296	.454	.440
8160	CS-4	.311	.312	.310	.462	.432	.301	.297	.298	.480	.456
8170	CS-5	.293	.302	.366	.516	.449	.298	.298	.365	.531	.472
8180	CS-6	.321	.326	.314	.490	.456	.320	.335	.301	.499	.458
8190	CS-7	.293	.317	.376	.533	.485	.316	.302	.364	.520	.465
8200	T-1	.298	.301	.359	.549	.483	.310	.301	.387	.541	.511
8210	T-2	.305	.307	.368	.544	.495	.330	.336	.353	.522	.480
8220	T-3	.322	.312	.366	.550	.463	.301	.310	.365	.540	.503
8230	T-4	.303	.312	.374	.505	.450	.304	.325	.373	.543	.509
8240	T-5	.317	.319	.350	.538	.469	.298	.305	.351	.530	.492
8250	T-6	.313	.318	.328	.467	.458	.318	.309	.313	.506	.466
8260	T-7	.291	.303	.290	.481	.422	.295	.303	.275	.473	.427
7400	WATER	.291	.302	.363	.537	.448	.295	.296	.316	.512	.437
7410	NMP-1	.220	.226	.212	.372	.345	.213	.230	.216	.377	.326

4360	SITE C										
4370	PERSONNEL DOSIMETERS - 7/12 TO 11/9/77										
4375	8.267	1.076	3.918	259	1.210	1.220	5.204				
4380	86										
4390	CE-1	.355	.352	.378	.477	.491	.336	.358	.405	.499	.468
4400	ADX-1	.552	.599	.671	.964	.827	.544	.552	.698	.935	.863
4410	ADX-2	.556	.568	.680	1.003	.859	.570	.593	.645	.908	.839
4420	ADX-3	.577	.572	.674	1.081	.908	.556	.587	.658	1.002	.881
4430	ADX-4	.631	.662	.75Z	1.186	.975	.651	.639	.699	1.164	.956
4440	ADX-5	.648	.636	.783	1.050	.985	.629	.605	.783	1.066	1.016
4450	AF-1	.311	.296	.365	.449	.423	.310	.296	.373	.466	.437
4460	AF-8	.278	.322	.355	.469	.445	.305	.303	.354	.465	.434
4470	CCF-2	.324	.340	.388	.489	.442	.297	.336	.386	.493	.463
4480	CS-2	.312	.333	.390	.501	.469	.311	.322	.377	.490	.449
4490	CS-3	.331	.329	.378	.515	.454	.371	.312	.368	.537	.448
4500	CS-6	.297	.341	.395	.522	.441	.305	.296	.368	.484	.443
4510	FE-1	.311	.327	.378	.500	.419	.332	.321	.386	.485	.461
4520	MO-1	.332	.343	.377	.497	.480	.329	.315	.380	.499	.448
4530	MO-2	.410	.289	.373	.488	.451	.333	.311	.382	.479	.432
4540	MO-3	.300	.319	.397	.485	.446	.312	.326	.390	.522	.457
4550	MO-5	.337	.322	.395	.520	.456	.320	.333	.374	.474	.437
4560	MO-7	.325	.321	.382	.507	.446	.319	.327	.367	.468	.478
4570	MO-8	.320	.333	.375	.476	.463	.313	.311	.362	.512	.470
4580	MO-9	.295	.317	.372	.476	.466	.294	.290	.354	.480	.462
4590	MO-10	.308	.452	.382	.460	.430	.316	.329	.419	.481	.440
4600	QCF-1	.304	.305	.388	.475	.444	.310	.339	.373	.514	.466
4610	QCF-3	.328	.327	.373	.494	.440	.315	.349	.372	.525	.425
4620	QCF-4	.325	.331	.373	.465	.458	.322	.337	.377	.485	.464
4630	QCF-5	.332	.325	.376	.453	.476	.315	.307	.374	.484	.467
4640	QCF-7	.341	.321	.385	.472	.466	.315	.326	.397	.489	.474
4650	QCF-8	.309	.344	.373	.480	.456	.320	.325	.376	.474	.474
4660	QCF-9	.335	.349	.360	.502	.449	.332	.337	.397	.519	.464
4670	X-1	.327	.333	.388	.513	.430	.307	.306	.376	.460	.439
4680	X-2	.296	.314	.352	.468	.465	.310	.277	.362	.479	.423
4690	X-3	.418	.412	.504	.793	.667	.406	.405	.495	.758	.646
4700	X-4	.308	.324	.417	.492	.444	.335	.337	.397	.507	.419
4710	X-5	.388	.378	.393	.633	.536	.386	.397	.412	.641	.573
4720	CON-3	.303	.312	.369	.551	.473	.301	.325	.368	.505	.458
4730	NAN-1	.441	.401	.490	.623	.494	.435	.444	.469	.552	.509
4740	NAN-2	.440	.408	.522	.586	.639	.433	.408	.504	.652	.617
4750	NAN-3	.542	.420	.494	.610	.583	.440	.475	.480	.610	.528
4760	NAN-4	.455	.410	.500	.627	.584	.472	.451	.500	.593	.571
4770	NAN-5	.402	.434	.491	.575	.522	.421	.430	.516	.610	.533
4780	NAN-6	.416	.447	.487	.576	.544	.387	.433	.463	.592	.537
4790	NAN-7	.441	.412	.477	.613	.546	.399	.396	.457	.592	.573
4800	NAN-8	.439	.389	.483	.641	.513	.428	.472	.452	.611	.530
4810	NAN-9	.343	.331	.409	.563	.461	.329	.340	.385	.477	.445
4820	NAN-10	.376	.361	.420	.561	.464	.356	.352	.417	.569	.507
4830	NAN-11	.323	.336	.414	.503	.491	.333	.334	.386	.487	.458
4840	NAN-12	.335	.325	.405	.484	.487	.313	.345	.383	.529	.461
4850	NAN-13	.381	.390	.416	.569	.450	.377	.362	.439	.581	.483

SITE C PERSONNEL DOSIMETERS - 7/12 TO 11/9/77 (cont'd)

4860	NAN-14	.407	.405	.428	.589	.525	.403	.413	.439	.520	.613
4870	NAN-15	.305	.320	.346	.457	.450	.334	.331	.369	.468	.435
4880	NAN-16	.339	.349	.421	.528	.461	.341	.345	.572	.540	.471
4890	NAN-17	.360	.344	.403	.522	.458	.336	.337	.379	.537	.483
4900	NAN-18	.327	.311	.329	.492	.462	.327	.343	.325	.480	.457
4910	NAN-19	.317	.335	.387	.488	.469	.345	.335	.390	.481	.479
4920	NAN-20	.314	.323	.413	.504	.458	.336	.337	.373	.482	.458
4930	NAN-21	.452	.456	.489	.702	.615	.459	.427	.484	.697	.622
4940	NAN-22	.333	.339	.381	.550	.508	.352	.344	.401	.545	.470
4950	NAN-23	.335	.332	.384	.501	.475	.301	.338	.396	.516	.477
4960	NAN-24	.354	.347	.437	.502	.482	.326	.339	.413	.528	.446
4970	NAN-25	.436	.427	.482	.695	.666	.425	.442	.520	.768	.671
4980	NAN-26	.346	.326	.414	.511	.478	.315	.330	.357	.533	.445
4990	NAN-27	.341	.343	.415	.535	.470	.351	.361	.451	.556	.444
5000	NAN-28	.346	.356	.405	.532	.486	.352	.371	.407	.546	.526
5010	NAN-29	.302	.318	.356	.493	.429	.306	.313	.381	.495	.441
5020	NAN-30	.344	.336	.387	.527	.465	.320	.343	.396	.517	.469
5030	NAN-31	.360	.328	.401	.504	.453	.328	.338	.388	.540	.477
5040	NAN-32	.394	.399	.410	.514	.524	.359	.362	.404	.529	.479
5050	NAN-33	.326	.324	.336	.467	.410	.314	.367	.311	.463	.452
5060	NAN-34	.370	.351	.399	.508	.472	.332	.349	.403	.480	.493
5070	NAN-35	.326	.346	.424	.489	.462	.321	.351	.397	.530	.493
5080	NAN-36	.370	.322	.426	.518	.499	.376	.346	.382	.474	.493
5090	NAN-37	.317	.302	.362	.453	.419	.331	.308	.363	.477	.464
5100	NAN-38	.328	.332	.385	.493	.443	.321	.323	.385	.488	.444
5110	NAN-39	.333	.313	.358	.477	.470	.303	.308	.396	.491	.448
5120	NAN-40	.340	.374	.403	.518	.458	.370	.359	.385	.550	.448
5130	NAN-41	.322	.336	.419	.600	.477	.328	.359	.397	.572	.488
5140	NAN-42	.402	.372	.430	.559	.509	.394	.399	.439	.598	.525
5150	NAN-43	.317	.315	.350	.499	.433	.305	.320	.392	.515	.421
5160	NAN-44	.318	.322	.386	.502	.450	.311	.333	.393	.501	.477
5170	NAN-45	.340	.370	.384	.527	.440	.353	.389	.402	.556	.445
5180	NAN-46	.307	.322	.382	.483	.450	.324	.314	.360	.477	.439
5190	NAN-47	.305	.325	.400	.491	.432	.315	.338	.390	.527	.454
5200	NAN-48	.374	.362	.421	.569	.484	.361	.350	.395	.566	.491
5210	NAN-49	.342	.355	.383	.560	.457	.320	.376	.398	.547	.452
5220	NAN-50	.370	.343	.399	.548	.491	.358	.324	.372	.496	.473
5230	NAN-51	.132	.144	.133	.213	.205	.137	.141	.132	.237	.199
5240	NAN-52	.143	.137	.146	.222	.195	.136	.130	.149	.237	.196

1620	SITE C											
1630	PERSONNEL DOSIMETERS - 11/9/77 TO 2/10/78											
1635	8.280	1.063	4.429	300	1.008	1.309	6.414					
1640	83											
1650	MOP-1	.274	.273	.280	.418	.376	.273	.280	.260	.424	.383	
1660	MOP-2	.315	.303	.370	.456	.428	.298	.321	.373	.471	.438	
1670	MOP-3	.299	.297	.315	.459	.431	.299	.301	.310	.445	.452	
1680	MOP-4	.304	.301	.307	.407	.375	.282	.302	.299	.421	.431	
1690	MOP-5	.303	.309	.388	.352	.328	.318	.354	.378	.381	.338	
1700	MOP-6	.295	.277	.277	.431	.397	.304	.296	.306	.386	.418	
1710	MOP-7	.311	.290	.368	.472	.463	.299	.290	.344	.485	.411	
1720	MOP-8	.305	.302	.351	.449	.428	.281	.294	.381	.482	.418	
1730	SGS-1	.302	.293	.357	.476	.445	.301	.304	.354	.507	.457	
1740	SGS-2	.283	.306	.357	.511	.472	.289	.300	.359	.456	.464	
1750	SGS-3	.273	.303	.345	.476	.415	.286	.284	.380	.471	.422	
1760	SGS-4	.266	.281	.337	.423	.370	.267	.291	.347	.440	.423	
1770	SGS-5	.289	.282	.274	.427	.414	.292	.286	.288	.383	.386	
1780	SGS-6	.276	.266	.281	.390	.369	.268	.267	.282	.388	.360	
1790	SGS-7	.293	.295	.353	.511	.461	.297	.300	.336	.505	.465	
1800	SGS-8	.287	.294	.358	.478	.426	.276	.299	.361	.466	.433	
1810	SGS-9	.280	.284	.326	.497	.430	.278	.292	.346	.485	.438	
1820	QCF-1	.298	.321	.384	.496	.471	.300	.285	.359	.480	.452	
1830	QCF-2	.254	.256	.339	.456	.431	.277	.266	.330	.488	.385	
1840	QCF-3	.276	.276	.333	.481	.427	.285	.300	.367	.483	.439	
1850	QCF-4	.295	.280	.346	.474	.444	.288	.285	.322	.382	.439	
1860	QCF-5	.273	.296	.292	.450	.417	.290	.300	.295	.469	.414	
1870	QCF-6	.309	.325	.350	.568	.520	.326	.318	.373	.653	.524	
1880	QCF-7	.287	.320	.309	.483	.428	.275	.312	.304	.449	.442	
1890	QCF-8	.228	.280	.353	.491	.409	.263	.303	.355	.489	.431	
1900	AF-1	.303	.350	.277	.430	.420	.298	.304	.281	.457	.417	
1910	AF-2	.301	.279	.341	.481	.412	.300	.297	.356	.481	.441	
1920	AF-3	.301	.301	.349	.482	.445	.293	.303	.358	.484	.440	
1930	AF-4	.327	.274	.337	.483	.445	.277	.303	.353	.413	.432	
1940	AF-5	.290	.287	.346	.494	.431	.296	.299	.501	.481	.437	
1950	AF-6	.316	.307	.355	.495	.431	.288	.309	.350	.485	.456	
1960	AF-7	.284	.300	.333	.452	.413	.264	.279	.321	.479	.327	
1970	A1&2-1	.281	.283	.326	.468	.450	.280	.285	.337	.483	.427	
1980	A1&2-2	.294	.291	.345	.501	.464	.295	.288	.341	.479	.446	
1990	A1&2-3	.307	.296	.366	.492	.447	.304	.304	.365	.474	.436	
2000	A1&2-4	.276	.274	.332	.422	.362	.268	.270	.328	.454	.429	
2010	A1&2-5	.306	.308	.290	.427	.385	.293	.304	.301	.434	.417	
2020	CTA-1	.487	.480	.580	.736	.714	.446	.463	.581	.727	.665	
2030	CTA-2	.299	.270	.281	.423	.469	.313	.292	.292	.419	.410	
2040	CTA-3	.453	.498	.585	.853	.699	.484	.487	.545	.850	.693	
2050	CTA-4	.280	.287	.349	.510	.438	.281	.288	.332	.452	.422	
2060	CTA-5	.280	.288	.341	.494	.413	.291	.283	.353	.459	.438	
2070	CTA-6	.265	.275	.317	.460	.407	.249	.265	.326	.463	.378	
2080	CTA-7	.318	.304	.348	.444	.418	.288	.283	.360	.460	.452	
2090	CTA-8	.541	.553	.611	.943	.831	.546	.593	.671	1.031	.886	
2100	CTA-9	.296	.291	.329	.494	.432	.310	.308	.358	.475	.435	
2110	CTA-10	.595	.572	.563	.878	.795	.580	.547	.601	.834	.789	
2120	T-1	.310	.275	.374	.495	.447	.309	.296	.355	.496	.447	

SITE C PERSONNEL DOSIMETERS - 11/9/77 TO 2/10/78

2130	T-2	.331	.346	.333	.496	.459	.326	.329	.321	.488	.481
2140	T-3	.465	.500	.568	.748	.646	.465	.479	.543	.769	.673
2150	T-4	.287	.296	.307	.471	.426	.294	.290	.295	.484	.413
2160	T-5	.413	.324	.289	.441	.427	.307	.313	.315	.449	.458
2170	T-6	.293	.271	.334	.480	.425	.280	.280	.312	.483	.392
2180	T-7	.643	.648	.824	1.194	.993	.570	.636	.811	1.123	.955
2190	T-8	.294	.293	.377	.512	.420	.301	.298	.364	.387	.476
2200	T-9	.295	.301	.380	.518	.496	.280	.307	.380	.493	.443
2210	OE-1	.286	.299	.297	.461	.410	.294	.294	.281	.413	.444
2220	OE-2	.294	.280	.297	.389	.390	.274	.274	.293	.417	.380
2230	OE-3	.481	.447	.541	.740	.623	.484	.454	.542	.750	.698
2240	OE-4	.291	.288	.315	.479	.469	.294	.288	.312	.471	.449
2250	OE-5	.276	.297	.369	.471	.417	.304	.265	.352	.472	.451
2260	OE-6	.310	.311	.347	.502	.451	.312	.284	.330	.492	.429
2270	OE-7	.287	.272	.290	.409	.378	.288	.295	.287	.404	.379
2280	OE-8	.606	.658	.734	.743	.599	.657	.566	.744	.773	.654
2290	OE-9	.282	.276	.341	.456	.425	.289	.270	.317	.476	.405
2300	L-1	.440	.435	.571	.697	.675	.434	.472	.552	.737	.687
2310	L-2	.449	.466	.553	.736	.624	.440	.447	.518	.734	.633
2320	L-3	.268	.273	.322	.456	.382	.276	.283	.324	.468	.371
2330	L-4	.305	.344	.371	.513	.442	.312	.346	.357	.476	.441
2340	L-5	.467	.453	.517	.684	.674	.420	.490	.545	.697	.635
2350	L-6	.549	.581	.578	.904	.803	.560	.597	.614	.892	.812
2360	L-7	.308	.309	.382	.468	.481	.302	.309	.364	.477	.472
2370	L-8	.314	.267	.299	.450	.444	.255	.294	.289	.453	.413
2380	IW-1	.326	.336	.398	.524	.469	.316	.316	.372	.513	.471
2390	IW-2	.302	.299	.274	.459	.427	.305	.296	.293	.419	.417
2400	IW-3	.292	.305	.362	.477	.428	.302	.315	.363	.483	.431
2410	IW-4	.714	.713	.809	1.203	1.105	.659	.709	.875	1.173	1.020
2420	IW-5	.535	.690	.598	.868	.794	.564	.539	.521	.874	.857
2430	IW-6	.272	.300	.382	.479	.351	.279	.292	.335	.474	.425
2440	IW-7	.730	.781	.924	1.295	1.167	.743	.758	.866	1.338	1.224
2450	IW-8	.299	.300	.333	.494	.437	.305	.292	.352	.476	.419
2460	IW-9	.268	.285	.322	.484	.402	.245	.273	.329	.456	.410
2470	CON-1	.206	.198	.213	.348	.312	.212	.209	.199	.345	.319

18630 SITE D
18640 PERSONNEL DOSIMETERS - 9/1 TO 11/23/76

18645	8.312	1.112	4.084	360	1.128	1.285	7.008				
18650	16										
18660	CNTRL	.143	.149	.161	1.005	.728	.142	.140	.163	1.090	.671
18670	CNTRL	.136	.139	.161	1.167	.702	.135	.132	.159	1.053	.705
18680	CNTRL	.132	.137	.158	1.110	.716	.134	.133	.148	.972	.723
18690	CNTRL	.144	.141	.163	1.060	.713	.144	.143	.167	1.060	.698
18700	00002	.303	.313	.323	2.004	1.227	.302	.308	.332	1.915	1.240
18710	00003	.263	.251	.306	1.664	1.068	.256	.262	.289	1.634	1.098
18720	00004	.240	.247	.302	1.723	1.023	.251	.274	.313	1.675	1.126
18730	00005	.309	.329	.351	1.992	1.310	.319	.341	.337	1.794	1.234
18740	00006	.256	.242	.283	1.858	1.146	.262	.246	.287	1.679	1.194
18750	00007	.277	.272	.294	1.488	1.094	.261	.252	.275	1.422	1.098
18760	00008	.256	.246	.279	1.735	1.073	.237	.255	.298	1.563	1.162
18770	00010	.284	.272	.280	1.597	1.050	.280	.258	.326	1.703	1.129
18780	00011	.348	.373	.351	2.141	1.296	.343	.375	.389	1.996	1.260
18790	00012	.264	.274	.297	1.055	.806	.261	.275	.312	1.102	.788
18800	CNTRL	.151	.151	.160	.918	.676	.135	.147	.161	.956	.638
18810	CNTRL	.146	.149	.154	.953	.642	.149	.151	.159	.924	.659

15870 SITE D
15880 PERSONNEL DOSIMETERS - 11/23/76 TO 2/14/77

15885	8.383	1.094	4.433	341	.982	1.141	7.496				
15890	14										
15900	00002	.314	.352	.342	1.226	.814	.306	.315	.358	1.230	.802
15910	00003	.256	.251	.296	1.136	.732	.270	.265	.303	1.086	.795
15920	00004	.268	.277	.299	1.064	.788	.269	.279	.309	1.073	.665
15930	00005	.337	.335	.346	1.199	.813	.328	.322	.352	1.178	.861
15940	00006	.255	.247	.283	1.080	.730	.276	.279	.299	1.069	.785
15950	00007	.281	.301	.307	1.113	.735	.307	.308	.326	1.080	.747
15960	00008	.248	.256	.304	1.049	.760	.265	.274	.313	1.143	.812
15970	00010	.274	.276	.311	1.143	.765	.287	.272	.313	1.079	.798
15980	00011	.296	.333	.354	1.205	.852	.299	.347	.377	1.289	.898
15990	00012	.268	.266	.318	1.553	1.028	.272	.263	.337	1.623	1.061
16000	CONT	.346	.350	.385	4.276	2.892	.363	.340	.422	4.270	2.807
16010	CONT	.339	.344	.451	4.389	2.735	.357	.343	.429	4.429	2.831
16020	CONT	.373	.343	.446	4.414	2.841	.365	.352	.421	4.452	2.535
16030	CONT	.342	.365	.432	4.417	2.840	.357	.349	.454	4.513	2.869

13920 SITE D
13930 PERSONNEL DOSIMETERS - 2/15/77 TO 3/30/77

13935 7.295 1.173 4.687 288 1.167 1.248 7.703

13940 15

13950	0002	.249	.249	.247	.399	.357	.237	.239	.271	.384	.359
13960	0003	.216	.199	.231	.355	.325	.220	.208	.244	.356	.309
13970	0004	.205	.204	.201	.324	.283	.212	.210	.213	.328	.293
13980	0005	.256	.284	.276	.462	.360	.250	.269	.274	.432	.375
13990	0006	.207	.215	.230	.373	.284	.210	.215	.236	.365	.314
14000	0007	.202	.205	.224	.361	.316	.203	.195	.228	.343	.323
14010	0008	.184	.192	.239	.348	.312	.207	.207	.238	.351	.315
14020	0010	.224	.219	.238	.367	.346	.224	.201	.230	.373	.312
14030	0011	.273	.320	.235	.563	.508	.282	.295	.318	.594	.519
14040	0012	.232	.217	.261	.360	.334	.216	.210	.232	.389	.313
14050	0012	.230	.210	.254	.363	.323	.231	.231	.248	.397	.328
14060	CONT	.188	.188	.175	.285	.281	.194	.189	.223	.290	.275
14070	CONT	.208	.206	.227	.345	.309	.188	.195	.217	.348	.297
14080	CONT	.192	.217	.207	.336	.286	.186	.190	.224	.321	.301
14090	CONT	.184	.195	.220	.320	.303	.193	.189	.213	.351	.304

11490 SITE D

11500 PERSONNEL DOSIMETERS - 3/30 TO 5/26/77

11505 7.042 1.140 3.404 283 1.773 1.230 7.698

11510 25

11520 #1 .134 .172 .205 .278 .252 .179 .174 .206 .282 .262

11530 #2 .259 .242 .249 .383 .306 .250 .255 .254 .411 .321

11540 #3 .190 .197 .218 .293 .280 .191 .187 .208 .322 .258

11550 #4 .209 .191 .222 .295 .262 .200 .197 .216 .303 .281

11560 #5 .297 .288 .269 .401 .336 .277 .306 .276 .410 .371

11570 #6 .242 .212 .240 .349 .323 .228 .218 .240 .338 .342

11580 #7 .208 .198 .212 .282 .273 .196 .197 .209 .291 .275

11590 #8 .193 .193 .229 .310 .279 .198 .189 .223 .306 .277

11600 #9 .182 .171 .206 .286 .231 .185 .165 .190 .275 .231

11610 #10 .214 .204 .231 .341 .278 .209 .197 .232 .340 .267

11620 #11 .333 .347 .333 .562 .503 .341 .371 .319 .556 .482

11630 #12 .247 .233 .245 .326 .275 .258 .220 .252 .326 .307

11640 #13 .223 .213 .255 .330 .302 .220 .217 .241 .342 .295

11650 #14 .178 .172 .200 .258 .217 .190 .169 .183 .276 .225

11660 #15 .180 .168 .188 .276 .231 .173 .174 .190 .253 .244

11670 #16 .180 .182 .200 .289 .245 .177 .176 .209 .274 .241

11680 #17 .186 .170 .202 .242 .235 .182 .174 .195 .252 .238

11690 #18 .170 .184 .206 .291 .245 .170 .187 .194 .275 .241

11700 #19 .168 .172 .205 .260 .243 .165 .168 .208 .294 .242

11710 #20 .160 .154 .212 .286 .239 .162 .181 .202 .261 .251

11720 #21 .181 .173 .196 .285 .225 .174 .173 .197 .261 .246

11730 #22 .185 .172 .202 .288 .249 .173 .164 .201 .258 .258

11740 #23 .182 .172 .195 .275 .228 .159 .166 .198 .286 .252

11750 #24 .174 .169 .167 .252 .236 .179 .179 .162 .226 .224

11760 #25 .176 .177 .200 .266 .252 .165 .176 .208 .275 .241

8970 SITE D

8980 PERSONNEL DOSIMETERS - 5/26/77-7/22/77

8985 7.534 1.082 4.085 270 1.038 1.343 7.476

8990 25

9000 #1 .196 .202 .219 .313 .260 .206 .200 .223 .318 .275

9010 #2 .226 .246 .232 .349 .283 .231 .231 .213 .349 .290

9020 #3 .184 .180 .197 .327 .255 .182 .185 .202 .295 .255

9030 #4 .181 .175 .199 .328 .263 .174 .174 .217 .306 .271

9040 #5 .241 .255 .246 .362 .328 .240 .241 .260 .352 .332

9050 #6 .229 .229 .232 .348 .300 .223 .207 .244 .336 .313

9060 #7 .192 .197 .216 .305 .268 .194 .192 .199 .300 .267

9070 #8 .175 .179 .167 .272 .259 .183 .190 .170 .290 .245

9080 #9 .184 .191 .207 .310 .281 .198 .189 .204 .307 .260

9090 #10 .192 .178 .215 .322 .274 .186 .190 .215 .297 .282

9100 #11 .359 .377 .384 .574 .526 .383 .367 .373 .614 .511

9110 #12 .198 .190 .189 .278 .236 .198 .187 .180 .288 .254

9120 #13 .192 .191 .205 .319 .288 .195 .202 .207 .306 .280

9130 #14 .186 .182 .219 .334 .285 .200 .193 .230 .328 .270

9140 #15 .190 .181 .216 .315 .279 .186 .184 .220 .321 .279

9150 #16 .196 .182 .213 .322 .283 .189 .196 .220 .290 .281

9160 #17 .199 .257 .292 .381 .313 .230 .230 .268 .335 .310

9170 #18 .218 .222 .276 .348 .305 .223 .235 .257 .335 .295

9180 #19 .258 .246 .256 .351 .331 .252 .239 .258 .351 .326

9190 #20 .235 .240 .234 .338 .300 .242 .221 .247 .340 .297

9200 #21 .205 .206 .254 .354 .323 .231 .206 .223 .346 .289

9210 #22 .195 .208 .226 .320 .286 .199 .193 .216 .308 .278

9220 #23 .182 .178 .222 .339 .270 .188 .187 .208 .343 .265

9230 #24 .206 .201 .188 .292 .282 .205 .210 .187 .271 .255

9240 #25 .187 .187 .201 .303 .302 .178 .197 .199 .306 .263

6270 SITE D

6280 PERSONNEL DOSIMETERS - 7/22 TO 10/6/77

6285 7.713 1.120 4.157 308 1.218 1.224 7.476

6290 10

6300 #2 .447 .456 .453 .753 .582 .457 .458 .473 .767 .577

6310 #3 .364 .367 .407 .537 .537 .375 .380 .446 .645 .565

6320 #4 .383 .349 .406 .563 .521 .367 .354 .626 .423 .511

6330 #5 .466 .468 .511 .659 .612 .456 .458 .483 .655 .640

6340 #6 .418 .448 .444 .659 .572 .439 .426 .440 .593 .618

6350 #7 .394 .394 .450 .597 .564 .387 .410 .422 .626 .543

6360 #8 .368 .363 .417 .641 .436 .395 .372 .425 .634 .491

6370 #10 .402 .358 .440 .573 .412 .340 .338 .391 .442 .517

6380 #11 .711 .726 .667 1.135 .997 .698 .706 .707 1.164 1.091

1190 SITE D

1200 PERSONNEL DOSIMETERS - 10/9 TO 12/2/77

1205 7.839 1.107 4.163 281 1.254 1.192 5.523

1210 12

1220 #2 .627 .634 .682 .941 .867 .659 .651 .697 .949 .878

1230 #3 .650 .637 .703 .889 .913 .627 .678 .711 .913 .904

1240 #4 .760 .587 .663 .948 .906 .605 .595 .654 .890 .866

1250 #5 .603 .695 .729 .983 .862 .632 .643 .751 1.020 .842

1260 #6 .642 .683 .642 .993 .885 .616 .618 .682 .908 .865

1270 #7 .545 .581 .666 .892 .791 .564 .611 .545 .844 .801

1280 #8 .627 .655 .593 .807 .795 .625 .637 .615 .811 .789

1290 #10 .544 .582 .638 .861 .817 .580 .609 .667 .935 .859

1300 #11 .720 .776 .794 1.259 1.056 .758 .750 .832 1.188 1.063

1310 #1UN .735 .728 .767 1.063 .963 .716 .726 .751 1.033 1.034

1320 #9UN .686 .695 .836 .990 .967 .689 .679 .799 1.021 1.054

1330 #12UN .723 .703 .740 .992 .908 .683 .698 .802 .993 .903

LIST ENVDDDS

ENVDDDS 17:07 06/08/78

```

100' FOR THE EVALUATION OF ENVIRONMENTAL DOSIMETERS
110 FILE #1=AMYIN,SCRATCH#3=AMYOUT
120 DIM $(132),T(200)$(10)
130 '**GET REACTOR NAME
140 PRINT 'REACTOR NAME';
150 GET R$
160 IF R$="" GOTO 690
170 '**POSITION 'REL' TO REACTOR
180 IF END#1 GOTO 690
190 GET#1, T$ 'TRY TO MATCH THIS LINE OF 'REL' WITH REACTOR NAME
200 IF LEN(T$)<1+LEN(R$) GOTO 180
210 IF T$(2,LEN(R$))<>R$ GOTO 180
220 PRINT
230 GET #1,I$
240 IF END#1 GOTO 670
250 OUTPUT#3
260 OUTPUT#3,TAB(10)I$
270 PRINT#3
280 OUTPUT#3,"      I.D.#          700B          600B          700F          600F          400F"
290 FOR I=1 TO 8
300 INPUT#1, C(I)
310 NEXT I
320' BACKGROUND DATA STATEMENT
330 FOR I=1 TO 5
340 READ A(I)
350 NEXT I
360 DATA 0,0,0,0,0
370' INPUT RAW TLD DATA
380 INPUT #1,N 'GET # OF ENVIRONMENTAL DOSIMETERS
390 FOR I=1 TO N
400 INPUT #1,T$,B7,B6,F7,F6,F4
410 IF END#1 GOTO 670
420' CALCULATE TLD DOSE
430 E1=(B7)-A(1)
440 E2=(B6)-A(2)
450 E3=(F7)-A(3)
460 E4=(F6)-A(4)
470 E5=(F4)-A(5)
480 G1=E1/C(1)
490 IF G1*C(2)>E2 THEN 520
500 G2=(E2-G1*C(2))/C(3)
510 GOTO 530
520 G2=0
530 G3=E3/C(4)
540 IF C(5)*G3>E4 THEN 570
550 G4=(E4-C(5)*G3)/C(6)
560 GOTO 580
570 G4=0
580 IF C(7)*G4>E5 THEN 610
590 G5=(E5-C(7)*G4)/C(8)
600 GOTO 630
610 G5=0
620' OUTPUT TLD DOSES
630 OUTPUT#3 USING 640,T$,1000*G1,1000*G2,1000*G3,1000*G4,1000*G5
640:  *****  *.**!!!!  *.**!!!!  *.**!!!!  *.**!!!!  *.**!!!!  *.**!!!!
650 IF I=N GOTO 670
660 NEXT I
670 FILE
680 LIST NN AMYOUT
690 END
READY

```

FLD01L 10105 06/14/78

```

10 FOR THE EVALUATION OF PERSONNEL DOSIMETERS
20 FILE #1=BILIN,SCRATCH#3=BILOUT
30 DIM #*(132),T(200)**(5)
40 **GET REACTOR NAME
50 PRINT "REACTOR NAME:"
60 GET R#
70 IF R#="" GOTO 600
80 **POSITION 'BILIN' TO REACTOR
90 IF END#1 GOTO 600
100 GET#1, T# 'TRY TO MATCH THIS LINE OF 'BILIN' WITH REACTOR NAME
110 IF LEN(T#)<1*LEN(R#) GOTO 90
120 IF T#(2,LEN(R#))<>R# GOTO 90
130 PRINT
140 GET #1,I#
150 IF END#1 GOTO 590
160 OUTPUT#3
170 OUTPUT#3,TAB(36)ZS
180 PRINT #3
190 OUTPUT#3,"          T.T. # PENETRATING NON-PENETRATING NEUTRON-THERMAL NEUTRON-FAST DOSE - REM"
200 FOR I=1 TO 7 'READ IN CALIBRATION CONSTANTS FOR THIS SET OF TLD'S
210 INPUT#1, K(I)
220 NEXT I
230 ' BACKGROUND DATA STATEMENT
240 FOR I=1 TO 5
250 READ B(I)
260 NEXT I
270 DATA 0,0,0,0,0,0
280 INPUT #1,N 'GET # OF PERSONNEL DOSIMETERS
290 'INPUT ID AND RAW TLD DATA
300 FOR I=1 TO N
310 INPUT #1,T#,R1,R2,R3,R3,R4,S1,S2,S5,S4,S4
320 'CALCULATE DOSE
330 R1=((R1+S1)/2)-B(1)
340 R2=((R2+S2)/2)-B(2)
350 R3=((R3+S3)/2)-B(3)
360 R4=((R4+S4)/2)-B(4)
370 R5=((R5+S5)/2)-B(5)
380 P1=R2/K(1)
390 IF K(2)*R2>R1 THEN 420
400 P2=P1+((R1-K(2)*R2)/K(3))
410 GOTO 430
420 P2=P1
430 N1=((R3-R4)/K(4))
440 N2=((R4-(K(6)*R5)-(K(5)*(R3-R4)))/K(7))
450 IF P1>0 THEN 470
460 P1=0
470 IF P2>0 THEN 490
480 P2=0
490 IF N1>0 THEN 510
500 N1=0
510 IF N2>0 THEN 530
520 N2=0
530 T1=P1+N1+N2
540 'OUTPUT TLD DOSES
550 OUTPUT#3 USING #66,T1,1000*P1,1000*P2,1000*N1,1000*N2,1000*T1
5601          ###  #.###  #.###  #.###  #.###  #.###
570 IF I=N GOTO 590
580 NEXT I
590 FILE
600 END

```

APPENDICES C - F
EXPOSURE AND DOSE EQUIVALENT DATA
FOR SITES A THROUGH D

APPENDICES C-F - GENERAL

These appendices contain the exposure and dose equivalent data as calculated by the computer. Environmental data is given in terms of mR for the 700 bare, 700 filtered and 400 filtered TLDs. Data for the 600 bare and 600 filtered TLDs is in terms of mrem thermal neutrons. These results were determined for each cycle and later converted to mR or mrem per month for further data analysis.

Data for the personnel dosimeters is given in terms of penetrating, nonpenetrating, thermal neutron, and fast neutron dose equivalent in mrem per cycle. Each dosimeter is coded and cross-referenced in data logbooks for determining job codes. For data analysis only penetrating dose equivalent was used.

Log normal graphs are included for environmental and personnel data for each site. The mean, median and standard deviations are given for the data from all the dosimetry exchange cycles.

APPENDIX C - SITE A DATA

SITE A - ENVIRONMENTAL DOSIMETERS, OFFSITE CONTROLS
CYCLES 1-7 (LiF - Bare)

SITE A - ENVIRONMENTAL DOSIMETERS, ONSITE CONTROLS
CYCLES 1-7 (LiF - Bare)

SITE A - STATION 2, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 3, CYCLES 1-7 (LiF - Bare)

· SITE A - STATION 5, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 9, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 12, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 14, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 17, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 19, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 21, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 23, CYCLES 1-7 (LiF - Bare)

SITE A - STATION 26, CYCLES 1-7 (LiF - Bare)

SITE A - SAFETY OFFICE - CYCLES 1-7

SITE A - OFFSITE CONTROL, CYCLES 1-7

SITE A - ONSITE CONTROLS, CYCLES 1-7

SITE A - ELECTRICIANS, CYCLES 1-7

SITE A - SHEETMETAL WORKERS, CYCLES 1-7

SITE A - PIPEFITTERS, CYCLES 1-7

SITE A - CARPENTERS, CYCLES 1-7

SITE A - MILLWRIGHTS, CYCLES 1-7

SITE A - IRON WORKERS, CYCLES 1-7

SITE A - OPERATORS, CYCLES 1-7

SITE A - PAINTERS, CYCLES 1-7

SITE A ENVIRONMENTAL DOSIMETERS 5/19 TO 7/14/76

I.D.#	700B	600B	700F	600F	400F
STA#2	2.62E+01	1.31E-01	2.33E+01	1.39E-01	2.73E+01
STA#3	2.30E+01	9.07E-02	2.13E+01	4.22E-02	2.44E+01
STA#4	2.18E+01	8.70E-02	1.98E+01	6.30E-02	2.44E+01
STA#5	5.60E+01	1.21E-01	5.38E+01	6.61E-02	5.87E+01
STA#6	2.10E+01	7.23E-02	1.90E+01	6.26E-02	2.27E+01
STA#8	3.05E+01	7.62E-02	3.72E+01	6.71E-02	4.06E+01
STA#9	2.83E+01	8.51E-02	2.68E+01	5.46E-02	3.11E+01
STA#10	1.90E+01	6.77E-02	1.78E+01	7.15E-02	2.14E+01
STA#11	2.63E+01	1.04E-01	2.48E+01	9.67E-02	2.89E+01
STA#12	1.51E+01	7.71E-02	1.32E+01	7.88E-02	1.60E+01
STA#13	2.68E+01	1.46E-01	2.71E+01	8.83E-02	3.00E+01
STA#14	4.98E+02	1.08E+00	5.00E+02	6.65E-01	5.61E+02
STA#15	2.30E+01	5.84E-02	2.18E+01	5.20E-02	2.40E+01
STA#16	1.85E+01	6.94E-02	1.68E+01	5.66E-02	1.96E+01
STA#17	1.85E+01	7.63E-02	1.79E+01	3.32E-02	2.04E+01
STA#18	2.05E+01	7.63E-02	1.84E+01	8.38E-02	2.01E+01
STA#19	1.66E+02	1.41E+00	1.10E+02	1.28E+00	1.40E+02
STA#20	2.90E+01	.00E+00	2.02E+01	7.28E-02	2.09E+01
STA#21	8.27E+01	4.65E-01	6.07E+01	5.68E-01	7.97E+01
STA#22	2.90E+02	5.97E-01	2.96E+02	1.93E-01	3.41E+02
STA#23	3.50E+01	1.83E-01	3.51E+01	9.96E-02	3.94E+01
STA#24	2.47E+01	8.33E-02	2.00E+01	1.64E-01	2.20E+01
STA#25	2.52E+01	1.05E-01	2.14E+01	4.46E-02	2.53E+01
BKG#37	2.67E+01	8.33E-02	2.58E+01	5.65E-02	2.89E+01
BKG#92	2.64E+01	8.53E-02	2.57E+01	7.32E-02	2.73E+01

SITE A ENVIRONMENTAL DOSIMETERS 7/14 TO 9/25/76

I.D.#	700B	600B	700F	600F	400F
STA#2	4.54E+01	1.11E-01	4.14E+01	1.38E-01	5.09E+01
STA#4	4.24E+01	4.14E-02	3.82E+01	8.20E-02	4.65E+01
STA#5	8.58E+01	.00E+00	7.76E+01	8.44E-03	9.82E+01
STA#6	4.04E+01	.00E+00	3.08E+01	7.42E-02	3.66E+01
STA#8	5.20E+01	4.02E-02	4.94E+01	6.29E-02	6.13E+01
STA#9	4.95E+01	9.50E-03	4.45E+01	8.45E-02	5.76E+01
STA#10	3.62E+01	7.49E-02	3.24E+01	9.56E-02	3.98E+01
STA#11	2.95E+01	3.29E-02	2.82E+01	7.42E-02	3.19E+01
STA#12	4.68E+01	8.93E-02	4.53E+01	1.14E-01	5.56E+01
STA#13	5.34E+01	7.84E-02	4.85E+01	1.70E-01	6.32E+01
STA#14	8.14E+02	9.00E-01	7.41E+02	2.44E+00	1.03E+03
STA#16	3.38E+01	3.96E-02	3.19E+01	5.54E-02	3.85E+01
STA#17	3.56E+01	2.24E-02	3.07E+01	.00E+00	3.79E+01
STA#18	3.66E+01	4.48E-02	3.24E+01	1.51E-02	3.83E+01
STA#19	3.07E+02	2.44E+00	1.99E+02	2.72E+00	3.22E+02
STA#21	1.51E+02	8.32E-01	1.19E+02	1.10E+00	1.80E+02
STA#22	1.49E+02	.00E+00	1.37E+02	3.07E-01	1.90E+02
STA#23	5.79E+01	5.05E-02	5.75E+01	9.48E-02	7.14E+01
STA#24	4.53E+01	1.20E-02	4.18E+01	6.85E-02	5.35E+01
STA#25	5.59E+01	.00E+00	4.06E+01	.00E+00	4.87E+01

SITE A ENVIRONMENTAL DOSIMETERS 9/25 TO 12/1/76

I.D.#	700B	600B	700F	600F	400F
STA#2	3.29E+01	1.69E-01	3.03E+01	1.80E-01	3.19E+01
STA#3	3.15E+01	6.30E-02	2.92E+01	8.39E-02	2.85E+01
STA#4	3.11E+01	1.31E-01	2.99E+01	9.58E-02	2.97E+01
STA#5	2.89E+01	5.34E-02	2.91E+01	4.05E-02	2.89E+01
STA#6	2.59E+01	5.46E-02	2.50E+01	5.56E-02	2.45E+01
STA#8	4.05E+01	5.72E-02	3.78E+01	5.42E-02	3.74E+01
STA#9	6.46E+01	4.76E-02	5.60E+01	1.02E-01	6.65E+01
STA#10	2.57E+01	6.33E-02	2.34E+01	9.09E-02	2.44E+01
STA#11	3.82E+01	8.49E-02	3.49E+01	7.94E-02	3.59E+01
STA#12	1.83E+01	7.18E-02	1.71E+01	8.10E-02	1.72E+01
STA#13	3.84E+01	1.09E-01	3.80E+01	1.38E-01	4.19E+01
STA#14	1.26E+03	1.44E+00	1.14E+03	1.81E+00	1.34E+03
STA#15	2.97E+01	8.43E-02	2.67E+01	9.35E-02	2.97E+01
STA#16	2.27E+01	6.45E-02	2.13E+01	7.96E-02	2.15E+01
STA#17	2.35E+01	4.72E-02	2.31E+01	3.92E-02	2.19E+01
STA#18	2.80E+01	6.18E-02	2.74E+01	4.32E-02	2.66E+01
STA#19	2.67E+02	2.87E+00	1.69E+02	2.46E+00	2.34E+02
STA#20	2.97E+01	1.06E-01	2.69E+01	1.07E-01	3.12E+01
STA#21	1.34E+02	1.09E+00	9.80E+01	8.71E-01	1.34E+02
STA#22	1.46E+02	1.95E-01	1.35E+02	2.97E-01	1.65E+02
STA#23	7.44E+01	9.03E-02	6.82E+01	1.59E-01	8.15E+01
STA#24	2.52E+01	6.09E-02	2.36E+01	6.97E-02	2.45E+01
STA#25	3.87E+01	5.66E-02	3.37E+01	1.13E-01	3.81E+01
STA#26	5.46E+01	1.10E-01	3.65E+01	8.20E-02	3.83E+01

NO DATA AT 400

SITE A ENVIRONMENTAL DOSIMETERS 12/1/76 TO 3/2/77

I.D.#	700B	600B	700F	600F	400F
STA#2	5.14E+01	2.35E-01	4.42E+01	1.19E-01	3.97E+01
STA#3	4.41E+01	7.09E-02	3.47E+01	1.06E-01	3.07E+01
STA#4	4.41E+01	1.42E-01	4.17E+01	1.18E-01	3.37E+01
STA#5	2.30E+02	5.30E-01	2.23E+02	1.57E-01	1.88E+02
STA#6	4.57E+01	1.19E-01	3.95E+01	1.11E-01	3.36E+01
STA#8	6.03E+01	4.91E-02	5.16E+01	6.77E-02	4.28E+01
STA#9	9.66E+01	6.08E-02	7.88E+01	1.70E-01	7.28E+01
STA#10	3.68E+01	5.67E-02	3.28E+01	6.92E-02	2.64E+01
STA#11	2.54E+01	6.52E-02	2.22E+01	8.59E-02	1.81E+01
STA#12	3.57E+01	7.05E-02	3.28E+01	3.88E-02	2.72E+01
STA#13	5.20E+01	1.22E-01	4.96E+01	1.30E-01	4.12E+01
STA#14	3.25E+03	5.12E+00	3.07E+03	3.77E+00	2.75E+03
STA#15	3.92E+01	1.16E-01	3.72E+01	8.52E-02	3.01E+01
STA#16	3.13E+01	8.27E-02	2.71E+01	1.02E-01	2.26E+01
STA#17	3.20E+01	9.63E-02	2.86E+01	3.67E-02	2.29E+01
STA#18	3.74E+01	1.06E-01	3.36E+01	1.08E-01	2.62E+01
STA#20	3.99E+01	1.62E-01	4.01E+01	8.67E-02	3.05E+01
STA#21	1.91E+02	1.23E+00	1.56E+02	9.63E-01	1.33E+02
STA#23	1.64E+03	5.43E-01	1.58E+03	.00E+00	1.13E+03
STA#24	6.61E+01	.00E+00	6.41E+01	.00E+00	5.03E+01
STA#25	8.60E+01	.00E+00	6.38E+01	.00E+00	5.11E+01
STA#26	5.74E+01	8.82E-03	5.22E+01	.00E+00	4.01E+01
STA#27	4.78E+01	.00E+00	4.47E+01	.00E+00	3.80E+01

SITE A ENVIRONMENTAL DOSIMETERS 3/2/77 TO 6/22/77

I.D.#	700B	600B	700F	600F	400F
STA#1	5.78E+01	7.96E-02	5.29E+01	.00E+00	5.10E+01
STA#4	4.41E+01	2.81E-02	4.63E+01	.00E+00	4.16E+01
STA#5	5.75E+02	.00E+00	5.26E+02	.00E+00	5.30E+02
STA#6	6.69E+01	2.11E-02	6.14E+01	.00E+00	5.95E+01
STA#8	6.28E+01	4.15E-02	6.03E+01	.00E+00	5.56E+01
STA#9	1.44E+03	.00E+00	1.15E+03	.00E+00	1.25E+03
STA#10	3.82E+01	5.09E-02	3.87E+01	.00E+00	3.29E+01
STA#11	5.49E+01	2.47E-02	5.08E+01	4.36E-02	4.53E+01
STA#12	2.51E+01	6.79E-02	2.61E+01	2.55E-02	2.24E+01
STA#13	5.94E+01	6.62E-02	5.92E+01	.00E+00	5.16E+01
STA#14	4.47E+03	.00E+00	4.29E+03	.00E+00	4.09E+03
STA#15	4.66E+01	3.00E-02	4.43E+01	.00E+00	3.81E+01
STA#16	3.62E+01	5.34E-02	3.47E+01	.00E+00	3.02E+01
STA#17	3.83E+01	1.39E-01	3.54E+01	.00E+00	2.89E+01
STA#19	2.25E+02	1.52E+00	1.58E+02	1.21E+00	1.60E+02
STA#20	4.51E+01	9.66E-02	4.30E+01	.00E+00	4.06E+01
STA#21	1.24E+02	5.88E-01	9.77E+01	4.72E-01	9.15E+01
STA#22	1.56E+03	7.05E-01	1.51E+03	.00E+00	1.30E+03
STA#23	2.62E+03	.00E+00	2.73E+03	.00E+00	2.55E+03
STA#24	3.58E+01	2.69E-02	3.07E+01	7.51E-02	3.03E+01
STA#25	5.24E+01	.00E+00	3.91E+01	5.95E-02	2.99E+01
STA#26	5.97E+01	5.51E-02	5.26E+01	.00E+00	4.62E+01
STA#27	3.98E+01	8.17E-02	3.86E+01	6.70E-02	3.24E+01
STA#28	7.23E+01	.00E+00	6.54E+01	.00E+00	5.55E+01

SITE A ENVIRONMENTAL DOSIMETERS 6/20 TO 8/15/77

I.D.#	700B	600B	700F	600F	400F
#1	5.80E+01	2.39E-01	5.43E+01	8.88E-02	5.21E+01
#2	3.60E+01	1.70E-01	3.55E+01	9.93E-02	4.03E+01
#3	5.27E+02	8.17E-01	5.05E+02	6.87E-01	5.94E+02
#5	4.84E+01	1.47E-01	4.56E+01	1.84E-01	5.32E+01
#6	1.82E+02	5.40E-01	1.42E+02	2.79E-01	2.01E+02
#7	3.84E+01	1.99E-01	3.40E+01	1.95E-01	3.81E+01
#8	4.84E+01	1.81E-01	4.48E+01	1.32E-01	5.15E+01
#9	3.09E+01	1.54E-01	2.79E+01	1.64E-01	3.21E+01
#10	5.02E+01	2.22E-01	4.77E+01	1.98E-01	5.46E+01
#11	2.47E+03	4.43E+00	2.33E+03	3.52E+00	2.97E+03
#12	3.87E+01	1.81E-01	3.70E+01	1.46E-01	4.31E+01
#13	3.31E+01	1.56E-01	3.06E+01	1.22E-01	3.43E+01
#14	3.10E+01	1.78E-01	3.06E+01	1.22E-01	3.28E+01
#15	3.56E+01	1.96E-01	3.29E+01	8.50E-02	3.83E+01
#16	3.14E+02	3.38E+00	1.92E+02	3.43E+00	2.53E+02
#17	1.53E+02	1.15E+00	1.15E+02	1.35E+00	1.60E+02
#18	4.58E+02	8.99E-01	4.49E+02	.00E+00	5.23E+02
#19	3.87E+03	7.64E+00	3.76E+03	2.05E+00	4.56E+03
#20	3.72E+01	1.52E-01	3.32E+01	1.17E-01	3.78E+01
#21	3.71E+01	1.70E-01	3.70E+01	1.27E-01	3.87E+01
#22	3.90E+01	1.40E-01	3.74E+01	1.06E-01	4.04E+01
#23	4.83E+01	2.07E-01	4.73E+01	1.56E-01	5.04E+01

SITE A ENVIRONMENTAL DOSIMETERS 8/15 TO 12/20/77

I.D.#	700B	600B	700F	600F	400F
#2	5.05E+01	3.31E-01	5.11E+01	2.43E-01	5.10E+01
#3	3.90E+01	1.19E-01	4.07E+01	8.98E-02	3.71E+01
#5	2.51E+01	1.02E-01	2.63E+01	1.07E-01	2.28E+01
#6	1.49E+02	.00E+00	1.43E+02	.00E+00	1.38E+02
#7	7.23E+01	1.53E-03	7.70E+01	.00E+00	7.42E+01
#10	3.87E+01	1.27E-01	4.12E+01	7.59E-02	3.93E+01
#11	5.26E+01	1.46E-01	5.28E+01	1.06E-01	4.83E+01
#12	1.40E+03	.00E+00	1.58E+03	.00E+00	1.26E+03
#13	6.31E+01	1.90E-01	6.68E+01	1.18E-01	6.58E+01
#14	5.87E+03	5.71E+00	5.99E+03	5.50E+00	5.93E+03
#95	4.86E+01	1.29E-01	5.09E+01	9.14E-02	4.63E+01
#17	3.63E+01	1.60E-01	3.95E+01	7.38E-02	3.73E+01
#18	3.79E+01	1.16E-01	3.99E+01	1.08E-01	3.83E+01
#19	5.96E+02	6.32E+00	4.13E+02	5.65E+00	4.58E+02
#20	4.13E+01	1.49E-01	4.54E+01	7.90E-02	4.02E+01
#21	3.36E+02	2.29E+00	2.72E+02	2.23E+00	2.90E+02
#22	6.47E+02	4.92E-01	7.43E+02	.00E+00	6.68E+02
#23	7.30E+03	9.95E+00	8.61E+03	.00E+08	7.33E+03
#24	4.31E+01	1.08E-01	4.76E+01	2.11E-02	4.11E+01
#26	7.30E+01	6.95E-02			
#27	3.94E+01	1.37E-01	4.20E+01	7.05E-02	3.93E+01
#28	3.86E+01	1.13E-01	4.01E+01	1.10E-01	4.04E+01

SITE A PERSONNEL DOSIMETERS 5/19 TO 7/14/76

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MR
STA#1	2.13E+01	2.13E+01	2.11E-01	.00E+00	21.5
STA#7	1.77E+01	1.77E+01	1.67E-01	.00E+00	17.9
STRC1	3.36E+01	3.36E+01	2.03E-01	.00E+00	33.8
STRC2	2.70E+01	2.70E+01	3.75E-01	.00E+00	27.3
SSF01	1.54E+02	1.54E+02	1.85E-01	6.86E+00	160.6
SP001	1.61E+02	1.61E+02	4.40E-01	.00E+00	161.6
SAP01	2.61E+02	2.61E+02	.00E+00	7.92E+01	340.1
SAP02	3.09E+01	3.09E+01	1.43E-01	.00E+00	31.0
SPE01	2.60E+02	2.60E+02	1.48E-01	4.57E+01	305.4
SPE02	2.19E+02	2.19E+02	2.66E-01	.00E+00	218.8
SHF01	3.47E+02	3.47E+02	4.51E-01	1.02E+02	448.9
SHF02	7.86E+01	7.86E+01	1.96E-01	.00E+00	78.7
SCH01	7.34E+01	7.34E+01	2.91E-01	.00E+00	73.7
SCH02	6.42E+01	6.42E+01	2.45E-01	.00E+00	64.4
SPIG1	1.52E+01	1.52E+01	1.90E-01	.00E+00	15.4
SPIG2	1.52E+01	1.52E+01	1.76E-01	.00E+00	15.4
SAFT1	2.00E+01	2.00E+01	.00E+00	1.94E+01	39.4
SAFT2	2.30E+01	2.30E+01	1.59E-01	.00E+00	23.2
CIRCW	2.25E+01	2.25E+01	1.43E-01	.00E+00	22.6
5F01	2.00E+01	2.00E+01	8.97E-02	.00E+00	20.1
5F02	2.07E+01	2.07E+01	1.58E-01	.00E+00	20.8
5F03	2.11E+01	2.11E+01	1.78E-01	.00E+00	21.3
5F04	2.04E+01	2.04E+01	1.78E-01	.00E+00	20.6
5F05	2.13E+01	2.13E+01	1.26E-01	.00E+00	21.4
5F06	2.17E+01	2.17E+01	1.92E-01	.00E+00	21.9
5F07	2.15E+01	2.15E+01	1.68E-01	.00E+00	21.6
5F08	2.15E+01	2.15E+01	2.29E-01	.00E+00	21.8
5F09	2.07E+01	2.07E+01	1.06E-01	.00E+00	20.8
5F10	2.16E+01	2.16E+01	1.52E-01	.00E+00	21.7
5P01	2.05E+01	2.05E+01	1.94E-01	.00E+00	20.7
5P02	2.03E+01	2.03E+01	1.48E-01	.00E+00	20.5
5P03	2.28E+01	2.28E+01	2.22E-01	.00E+00	23.0
5P04	2.01E+01	2.01E+01	8.79E-02	.00E+00	20.2
5P05	1.99E+01	1.99E+01	1.19E-01	.00E+00	20.1
5P06	2.09E+01	2.09E+01	1.12E-01	.00E+00	21.0
5P07	1.90E+01	1.90E+01	1.47E-01	.00E+00	19.2
5P08	2.09E+01	2.09E+01	1.15E-01	.00E+00	21.0
5P09	2.03E+01	2.03E+01	1.79E-01	.00E+00	20.4
5P10	2.12E+01	2.12E+01	1.85E-01	.00E+00	21.4
5001	2.11E+01	2.11E+01	1.48E-01	.00E+00	21.3
5002	2.25E+01	2.25E+01	1.85E-01	.00E+00	22.6
5003	2.07E+01	2.07E+01	1.47E-01	.00E+00	20.8
5004	2.00E+01	2.00E+01	2.03E-01	.00E+00	20.3
5005	2.01E+01	2.01E+01	1.47E-01	.00E+00	20.3
5006	1.93E+01	1.93E+01	7.69E-02	.00E+00	19.4
5007	1.95E+01	1.95E+01	1.25E-01	.00E+00	19.7
5008	2.10E+01	2.10E+01	1.78E-01	.00E+00	21.2
5009	1.99E+01	1.99E+01	2.00E-01	.00E+00	20.1

SITE A PERSONNEL DOSIMETERS 5/19 TO 7/14/76 (cont'd)

5010	2.00E+01	2.00E+01	1.01E-01	.00E+00	20.1
5101	2.17E+01	2.17E+01	1.23E-01	.00E+00	21.8
5102	2.21E+01	2.21E+01	2.14E-01	.00E+00	22.3
5103	2.07E+01	2.07E+01	1.74E-01	.00E+00	20.9
5104	2.17E+01	2.17E+01	1.54E-01	.00E+00	21.8
5105	2.05E+01	2.05E+01	1.96E-01	.00E+00	20.7
5106	2.15E+01	2.15E+01	1.43E-01	.00E+00	21.6
5107	2.33E+01	2.33E+01	1.54E-01	.00E+00	23.5
5108	2.24E+01	2.24E+01	1.78E-01	.00E+00	22.6
5109	2.28E+01	2.28E+01	1.85E-01	.00E+00	23.0
5110	2.27E+01	2.27E+01	1.61E-01	.00E+00	22.8
5501	2.15E+01	2.15E+01	1.98E-01	.00E+00	21.7
5502	2.17E+01	2.17E+01	8.97E-02	.00E+00	21.7
5504	2.22E+01	2.22E+01	2.14E-01	.00E+00	22.4
5505	2.25E+01	2.25E+01	6.04E-02	.00E+00	22.6
5506	2.17E+01	2.17E+01	1.56E-01	.00E+00	21.9
5507	2.18E+01	2.18E+01	1.19E-01	.00E+00	21.9
5508	2.44E+01	2.44E+01	1.67E-01	.00E+00	24.6
5509	2.12E+01	2.12E+01	1.34E-01	.00E+00	21.3
5510	2.09E+01	2.09E+01	1.76E-01	.00E+00	21.0
5E01	2.15E+01	2.15E+01	1.32E-01	.00E+00	21.7
5E02	1.93E+01	1.93E+01	1.30E-01	.00E+00	19.5
5E03	1.83E+01	1.83E+01	1.17E-01	.00E+00	18.4
5E04	1.90E+01	1.90E+01	1.03E-01	.00E+00	19.1
5E05	1.97E+01	1.97E+01	1.28E-01	.00E+00	19
5E06	1.95E+01	1.95E+01	1.14E-01	.00E+00	19.6
5E07	1.85E+01	1.85E+01	1.87E-01	.00E+00	18.7
5E08	1.91E+01	1.91E+01	1.59E-01	.00E+00	19.3
5E09	1.75E+01	1.75E+01	1.54E-01	.00E+00	17.6
5E10	1.96E+01	1.96E+01	1.06E-01	.00E+00	19.7
5C01	2.23E+01	2.23E+01	1.30E-01	.00E+00	22.5
5C02	2.17E+01	2.17E+01	2.12E-01	.00E+00	21.9
5C03	2.01E+01	2.01E+01	1.87E-01	.00E+00	20.3
5C04	2.18E+01	2.18E+01	1.54E-01	.00E+00	21.9
5C05	2.15E+01	2.15E+01	1.61E-01	.00E+00	21.7
5C06	2.18E+01	2.18E+01	8.24E-02	.00E+00	21.9
5C07	2.22E+01	2.22E+01	9.71E-02	.00E+00	22.3
5C08	3.84E+01	3.84E+01	6.41E-02	1.05E+00	39.5
5C09	2.21E+01	2.21E+01	1.45E-01	.00E+00	22.3
5C10	2.14E+01	2.14E+01	1.94E-01	.00E+00	21.6
5M01	2.14E+01	2.14E+01	1.78E-01	.00E+00	21.6
5M02	2.26E+01	2.26E+01	1.30E-01	.00E+00	22.7
5M03	2.17E+01	2.17E+01	9.16E-02	.00E+00	21.8
5M04	2.13E+01	2.13E+01	1.25E-01	.00E+00	21.5
5M05	2.19E+01	2.19E+01	2.00E-01	.00E+00	22.1
5M06	2.17E+01	2.17E+01	1.34E-01	.00E+00	21.9
5M07	2.28E+01	2.28E+01	1.92E-01	.00E+00	23.0
5M08	2.30E+01	2.30E+01	1.15E-01	.00E+00	23.1
5M09	2.19E+01	2.19E+01	1.78E-01	.00E+00	22.0
5M10	2.23E+01	2.23E+01	1.87E-01	.00E+00	22
BKG	2.93E+01	2.93E+01	1.12E-01	.00E+00	29.5

SITE A PERSONNEL DOSIMETERS 7/14 TO 9/28/76

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
STA#1	4.32E+01	4.32E+01	2.38E-01	.00E+00	43.4
STA#7	3.98E+01	3.98E+01	2.92E-01	.00E+00	40.0
STA#20	4.46E+01	4.46E+01	1.75E-01	.00E+00	44.8
7TRC1	5.83E+01	5.83E+01	3.21E-01	.00E+00	58.6
7TRC2	5.67E+01	5.67E+01	2.06E-01	.00E+00	56.9
7AP01	2.45E+02	2.45E+02	.00E+00	1.04E+01	255.4
7AP02	5.73E+01	5.73E+01	1.79E-01	.00E+00	57.5
7SF01	2.38E+02	2.38E+02	.00E+00	4.87E+00	243.0
7P001	2.11E+02	2.11E+02	.00E+00	5.03E+00	215.6
7PE01	6.28E+01	6.28E+01	1.58E-01	.00E+00	62.9
7PE02	3.19E+02	3.19E+02	5.77E-02	.00E+00	319.0
7HP01	5.99E+02	5.99E+02	.00E+00	1.25E+02	724.8
7HP02	9.74E+01	9.74E+01	1.37E-01	.00E+00	97.5
7CH01	5.33E+01	5.33E+01	9.62E-02	.00E+00	53.4
7CH02	7.28E+01	7.28E+01	2.37E-01	.00E+00	73.1
7PIG1	3.15E+01	3.15E+01	1.73E-01	.00E+00	31.7
7PIG2	3.21E+01	3.21E+01	2.06E-01	.00E+00	32.3
SAOFF	3.93E+01	3.93E+01	2.31E-01	.00E+00	39.6
SAOFF	4.01E+01	4.01E+01	2.29E-01	.00E+00	40.3
7F01	3.52E+01	3.52E+01	1.65E-01	.00E+00	35.4
7F02	3.59E+01	3.59E+01	1.60E-01	.00E+00	36.0
7F03	3.75E+01	3.75E+01	1.35E-01	.00E+00	37.3
7F04	3.48E+01	3.48E+01	1.12E-01	.00E+00	34.9
7F05	3.60E+01	3.60E+01	1.15E-01	.00E+00	36.1
7F06	3.47E+01	3.47E+01	2.31E-01	.00E+00	34.7
7F07	3.47E+01	3.47E+01	1.79E-01	.00E+00	34.6
7F08	3.59E+01	3.59E+01	1.38E-01	.00E+00	36.0
7F09	3.63E+01	3.63E+01	2.12E-01	.00E+00	36.5
7F10	3.92E+01	3.92E+01	1.44E-01	.00E+00	39.3
7P01	3.79E+01	3.79E+01	1.90E-01	.00E+00	38.1
7P02	3.66E+01	3.66E+01	2.10E-01	.00E+00	36.6
7P03	3.67E+01	3.67E+01	2.23E-01	.00E+00	36.9
7P04	3.77E+01	3.77E+01	2.42E-01	.00E+00	37.9
7P05	3.74E+01	3.74E+01	1.44E-01	.00E+00	37.3
7P06	3.57E+01	3.57E+01	1.94E-01	.00E+00	35.9
7P07	3.47E+01	3.47E+01	2.40E-01	.00E+00	34.9
7P08	3.51E+01	3.51E+01	2.19E-01	.00E+00	35.3
7P09	3.62E+01	3.62E+01	1.40E-01	.00E+00	36.3
7P10	3.46E+01	3.46E+01	2.00E-01	.00E+00	34.8
7001	3.54E+01	3.54E+01	1.56E-01	.00E+00	35.5
7002	3.61E+01	3.61E+01	1.92E-01	.00E+00	36.3
7003	3.54E+01	3.54E+01	1.98E-01	.00E+00	35.6
7004	3.45E+01	3.45E+01	1.73E-01	.00E+00	34.7
7005	3.57E+01	3.57E+01	1.73E-01	.00E+00	35.9
7006	3.49E+01	3.49E+01	1.77E-01	.00E+00	35.1
7007	3.32E+01	3.32E+01	1.71E-01	.00E+00	33.4
7008	3.55E+01	3.55E+01	1.87E-01	.00E+00	35.7
7009	4.45E+01	4.45E+01	2.29E-01	.00E+00	44.7

SITE A PERSONNEL DOSIMETERS - 7/14 TO 9/28/76 (cont'd)

7010	3.42E+01	3.42E+01	1.87E-01	.00E+00	34.3
7101	3.80E+01	3.80E+01	9.23E-02	.00E+00	38.1
7102	3.75E+01	3.75E+01	2.27E-01	.00E+00	37.7
7103	3.47E+01	3.47E+01	2.15E-01	.00E+00	34.9
7104	3.47E+01	3.47E+01	9.81E-02	.00E+00	34.8
7105	3.71E+01	3.71E+01	2.37E-01	.00E+00	37.4
7106	3.14E+01	3.14E+01	1.73E-01	.00E+00	31.5
7107	3.60E+01	3.60E+01	1.35E-01	.00E+00	36.1
7108	3.60E+01	3.60E+01	1.87E-01	.00E+00	36.1
7109	3.57E+01	3.57E+01	2.73E-01	.00E+00	35.9
7110	3.80E+01	3.80E+01	1.35E-01	.00E+00	38.1
7S01	3.53E+01	3.53E+01	1.71E-01	.00E+00	35.5
7S02	3.52E+01	3.52E+01	1.19E-01	.00E+00	35.3
7S03	3.56E+01	3.56E+01	5.38E-02	.00E+00	35.6
7S04	3.82E+01	3.82E+01	1.44E-01	.00E+00	38.4
7S05	3.60E+01	3.60E+01	1.62E-01	.00E+00	36.1
7S06	3.57E+01	3.57E+01	6.15E-02	.00E+00	35.8
7S07	4.00E+01	4.00E+01	2.27E-01	.00E+00	40.3
7S08	3.60E+01	3.60E+01	2.17E-01	.00E+00	36.2
7S09	3.90E+01	3.90E+01	2.56E-01	.00E+00	39.3
7S10	3.75E+01	3.75E+01	1.27E-01	.00E+00	37.7
7E01	3.74E+01	3.74E+01	1.42E-01	.00E+00	37.5
7E02	3.56E+01	3.56E+01	1.52E-01	.00E+00	35.7
7E03	3.63E+01	3.63E+01	2.04E-01	.00E+00	36.5
7E04	3.60E+01	3.60E+01	1.35E-01	.00E+00	36.1
7E05	3.60E+01	3.60E+01	1.90E-01	.00E+00	36.2
7E06	3.78E+01	3.78E+01	1.62E-01	.00E+00	38.0
7E07	3.75E+01	3.75E+01	1.04E-01	.00E+00	37.6
7E08	3.66E+01	3.66E+01	1.54E-01	.00E+00	36.7
7E09	3.44E+01	3.44E+01	1.62E-01	.00E+00	34.6
7E10	3.46E+01	3.46E+01	2.04E-01	.00E+00	34.8
5C01	3.32E+01	3.32E+01	1.54E-01	.00E+00	33.4
5C02	3.36E+01	3.36E+01	1.00E-01	.00E+00	33.7
7C03	3.30E+01	3.30E+01	1.50E-01	.00E+00	33.2
7C04	3.75E+01	3.75E+01	1.60E-01	.00E+00	37.6
7C05	3.47E+01	3.47E+01	7.12E-02	.00E+00	34.7
7C06	3.45E+01	3.45E+01	1.29E-01	.00E+00	34.6
7C08	3.63E+01	3.63E+01	1.81E-01	.00E+00	36.5
7C09	3.48E+01	3.48E+01	7.12E-02	.00E+00	34.9
7C10	3.49E+01	3.49E+01	1.40E-01	.00E+00	35.0
7M02	3.83E+01	3.83E+01	1.37E-01	.00E+00	38.5
7M03	3.53E+01	3.53E+01	1.13E-01	.00E+00	35.4
7M04	3.67E+01	3.67E+01	1.35E-01	.00E+00	36.9
7M05	3.51E+01	3.51E+01	1.48E-01	.00E+00	35.2
7M06	3.58E+01	3.58E+01	2.00E-01	.00E+00	36.0
7M07	3.38E+01	3.38E+01	1.65E-01	.00E+00	34.0
7M08	3.45E+01	3.45E+01	1.15E-01	.00E+00	34.6
7M10	3.58E+01	3.58E+01	7.12E-02	.00E+00	35.9

SITE A PERSONNEL DOSIMETERS 9/25 TO 11/30/76

..D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
ST#1	3.04E+01	3.04E+01	2.53E-01	.00E+00	30.6
ST#10	2.87E+01	2.87E+01	1.07E-01	.00E+00	28.9
ST#10	2.64E+01	2.64E+01	1.95E-01	.00E+00	26.6
ST#11	3.81E+01	3.81E+01	3.28E-02	2.20E+00	40.3
ST#11	4.44E+01	4.44E+01	8.97E-02	.00E+00	44.5
ST#12	2.02E+01	2.02E+01	1.10E-01	.00E+00	20.3
ST#12	2.33E+01	2.33E+01	5.69E-02	.00E+00	23.4
ST#18	2.70E+01	2.70E+01	1.43E-01	.00E+00	27.1
PUMPS	3.42E+01	3.42E+01	1.69E-01	.00E+00	34.4
9AP01	4.46E+02	4.46E+02	7.03E-01	.00E+00	446.6
9AP02	5.48E+01	5.48E+01	1.50E-01	.00E+00	55.0
9AP03	1.34E+02	1.34E+02	3.36E-01	.00E+00	134.7
9HP01	2.93E+02	2.93E+02	4.52E-01	2.66E+01	320.1
9SF01	2.47E+02	2.47E+02	2.55E-01	.00E+00	247.3
9CH02	6.06E+01	6.06E+01	1.91E-01	.00E+00	60.7
9CH01	4.97E+01	4.97E+01	1.64E-01	.00E+00	49.9
9PE02	1.34E+02	1.34E+02	2.05E-01	.00E+00	134.3
9CR01	1.68E+02	1.68E+02	6.07E+00	5.33E+02	707.1
9P001	1.74E+02	1.74E+02	2.98E-01	.00E+00	174.7
CTRL1	2.77E+01	2.77E+01	1.66E-01	.00E+00	27.9
CTRL2	2.91E+01	2.91E+01	1.91E-01	.00E+00	29.3
CTRL3	1.90E+01	1.90E+01	3.10E-02	.00E+00	19.0
CTRL4	2.52E+01	2.52E+01	4.48E-02	2.71E+00	28.0
9F01	2.89E+01	2.89E+01	1.07E-01	.00E+00	29.0
9F02	2.89E+01	2.89E+01	1.79E-01	.00E+00	29.1
9F03	2.92E+01	2.92E+01	2.40E-01	.00E+00	29.4
9F04	2.76E+01	2.76E+01	2.17E-01	.00E+00	27.8
9F05	2.90E+01	2.90E+01	1.38E-01	.00E+00	29.1
9F06	2.88E+01	2.88E+01	2.10E-01	.00E+00	29.0
9F07	3.19E+01	3.19E+01	1.05E-01	.00E+00	31.0
9F08	2.97E+01	2.97E+01	6.90E-02	.00E+00	29.8
9F09	2.67E+01	2.67E+01	1.17E-01	.00E+00	26.8
9F10	2.77E+01	2.77E+01	3.97E-02	.00E+00	27.7
9F02	2.77E+01	2.77E+01	1.97E-01	.00E+00	27.9
9F03	2.96E+01	2.96E+01	8.28E-02	.00E+00	29.7
9F04	2.90E+01	2.90E+01	1.88E-01	.00E+00	29.2
9F05	2.78E+01	2.78E+01	1.34E-01	.00E+00	28.0
9F06	2.84E+01	2.84E+01	1.55E-01	.00E+00	28.6
9F08	2.77E+01	2.77E+01	1.88E-01	.00E+00	27.9
9F09	2.73E+01	2.73E+01	2.03E-01	.00E+00	27.5
9F10	2.82E+01	2.82E+01	2.33E-01	.00E+00	28.4
9001	2.75E+01	2.75E+01	1.78E-01	.00E+00	27.7
9002	2.80E+01	2.80E+01	1.33E-01	.00E+00	28.1
9003	3.08E+01	3.08E+01	1.97E-01	.00E+00	31.0
9004	2.70E+01	2.70E+01	1.40E-01	.00E+00	27.1
9005	2.82E+01	2.82E+01	1.34E-01	.00E+00	28.3
9006	3.04E+01	3.04E+01	1.57E-01	.00E+00	30.6
9007	3.14E+01	3.14E+01	.00E+00	.00E+00	31.4
9008	3.31E+01	3.31E+01	7.76E-02	.00E+00	33.2

SITE A PERSONNEL DOSIMETERS - 9/25 TO 11/30/76 (cont'd)

9009	2.89E+01	2.89E+01	2.10E-01	.00E+00	29.1
9010	3.00E+01	3.00E+01	1.36E-01	.00E+00	30.2
9I01	2.87E+01	2.87E+01	1.72E-01	.00E+00	28.9
9I02	3.12E+01	3.12E+01	1.10E-01	.00E+00	31.3
9I03	2.79E+01	2.79E+01	6.55E-02	.00E+00	28.0
9I04	2.87E+01	2.87E+01	6.03E-02	.00E+00	28.7
9I05	2.89E+01	2.89E+01	1.03E-01	.00E+00	29.0
9I06	2.65E+01	2.65E+01	8.79E-02	.00E+00	26.6
9I07	3.06E+01	3.06E+01	9.83E-02	.00E+00	30.7
9I08	2.83E+01	2.83E+01	7.41E-02	.00E+00	28.4
9I09	3.19E+01	3.19E+01	1.83E-01	.00E+00	32.1
9I10	2.97E+01	2.97E+01	1.43E-01	.00E+00	29.9
9S01	2.94E+01	2.94E+01	1.33E-01	.00E+00	29.5
9S02	2.89E+01	2.89E+01	1.74E-01	.00E+00	29.1
9S03	3.15E+01	3.15E+01	1.78E-01	.00E+00	31.7
9S04	2.99E+01	2.99E+01	2.79E-01	.00E+00	30.1
9S05	2.94E+01	2.94E+01	1.16E-01	.00E+00	29.5
9S06	2.87E+01	2.87E+01	1.02E-01	.00E+00	28.8
9S07	2.89E+01	2.89E+01	1.12E-01	.00E+00	29.0
9S08	2.80E+01	2.80E+01	1.28E-01	.00E+00	28.2
9S09	3.21E+01	3.21E+01	1.90E-01	.00E+00	32.3
9S10	3.36E+01	3.36E+01	2.05E-01	.00E+00	33.8
9E01	3.16E+01	3.16E+01	1.52E-01	.00E+00	31.7
9E02	2.73E+01	2.73E+01	1.76E-01	.00E+00	27.4
9E03	3.08E+01	3.08E+01	1.69E-01	.00E+00	30.4
9E04	3.25E+01	3.25E+01	1.31E-01	.00E+00	32.6
9E05	3.08E+01	3.08E+01	9.31E-02	.00E+00	30.9
9E06	2.91E+01	2.91E+01	1.29E-01	.00E+00	29.2
9E07	2.80E+01	2.80E+01	9.14E-02	.00E+00	28.1
9E08	2.99E+01	2.99E+01	1.26E-01	.00E+00	30.0
9E09	2.79E+01	2.79E+01	1.59E-01	.00E+00	28.1
9E10	2.75E+01	2.75E+01	1.90E-01	.00E+00	27.7
9C01	2.95E+01	2.95E+01	1.00E-01	.00E+00	29.6
9C02	2.75E+01	2.75E+01	1.53E-01	.00E+00	27.7
9C03	2.92E+01	2.92E+01	2.36E-01	.00E+00	29.4
9C04	3.00E+01	3.00E+01	9.66E-02	.00E+00	30.1
9C05	2.54E+01	2.54E+01	.00E+00	.00E+00	25.4
9C06	2.82E+01	2.82E+01	1.53E-01	.00E+00	28.4
9C07	2.91E+01	2.91E+01	1.28E-01	.00E+00	29.3
9C08	2.84E+01	2.84E+01	2.05E-01	.00E+00	28.6
9C09	2.90E+01	2.90E+01	.00E+00	2.08E+00	31.1
9C10	2.55E+01	2.55E+01	1.52E-01	.00E+00	25.6
9M01	3.14E+01	3.14E+01	6.21E-02	.00E+00	31.4
9M02	3.68E+01	3.68E+01	1.26E-01	.00E+00	37.0
9M03	3.45E+01	3.45E+01	1.14E-01	.00E+00	34.6
9M04	4.24E+01	4.24E+01	1.19E-01	.00E+00	42.5
9M05	3.07E+01	3.07E+01	1.07E-01	.00E+00	30.8
9M06	2.91E+01	2.91E+01	1.26E-01	.00E+00	29.2
9M08	2.82E+01	2.82E+01	1.66E-01	.00E+00	28.4
9M09	3.12E+01	3.12E+01	2.26E-01	.00E+00	31
9M10	2.90E+01	2.90E+01	1.52E-01	.00E+00	29.2

SITE A PERSONNEL DOSIMETERS 12/1/76 TO 3/2/77

L.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MRE
ST#10	3.94E+01	3.94E+01	.00E+00	1.22E+01	51.7
ST#10	3.50E+01	3.50E+01	1.35E-01	.00E+00	35.2
ST#11	3.74E+01	3.74E+01	.00E+00	3.21E+00	40.6
SP#11	3.51E+01	3.51E+01	1.16E-01	.00E+00	35.2
ST#12	2.49E+01	2.49E+01	.00E+00	1.13E+01	36.2
ST#12	2.66E+01	2.66E+01	1.05E-01	.00E+00	26.7
PUMPS	4.41E+01	4.41E+01	1.83E-01	.00E+00	44.2
VC-1	4.60E+01	4.60E+01	2.40E-01	.00E+00	46.2
AP001	1.94E+02	1.94E+02	4.69E-01	.00E+00	194.4
AP002	5.84E+01	5.84E+01	1.81E-01	.00E+00	58.5
AP003	2.83E+02	2.83E+02	.00E+00	2.70E+01	309.8
HP01	3.04E+02	3.04E+02	9.16E-01	.00E+00	305.3
SF01	1.19E+02	1.19E+02	3.44E-01	.00E+00	119.5
CH01	5.79E+01	5.79E+01	6.49E-02	2.73E-01	58.3
CH02	1.13E+02	1.13E+02	5.04E-01	.00E+00	113.1
CR01	6.25E+01	6.25E+01	1.22E-01	8.08E+00	70.7
RX228	4.53E+01	4.53E+01	1.77E-01	.00E+00	45.5
T-164	5.39E+01	5.39E+01	2.16E-01	.00E+00	54.2
F01	3.59E+01	3.59E+01	1.30E-01	.00E+00	36.0
F02	3.92E+01	3.92E+01	.00E+00	2.53E+00	41.8
F03	3.84E+01	3.84E+01	6.68E-02	.00E+00	38.4
F04	3.71E+01	3.71E+01	9.92E-02	.00E+00	37.2
F05	3.92E+01	3.92E+01	4.77E-02	.00E+00	39.3
F06	3.70E+01	3.70E+01	1.77E-01	.00E+00	37.1
F07	3.69E+01	3.69E+01	1.55E-01	.00E+00	37.0
F08	5.36E+01	5.36E+01	9.54E-03	.00E+00	53.6
F09	3.91E+01	3.91E+01	3.05E-02	3.84E+00	43.0
F10	3.72E+01	3.72E+01	1.58E-01	.00E+00	37.3
P01	3.70E+01	3.70E+01	2.04E-01	.00E+00	37.2
P02	3.72E+01	3.72E+01	7.63E-02	.00E+00	37.3
P03	3.72E+01	3.72E+01	9.54E-02	.00E+00	37.3
P04	3.93E+01	3.93E+01	2.42E-01	.00E+00	39.5
P05	3.98E+01	3.98E+01	1.79E-01	.00E+00	40.0
P06	3.71E+01	3.71E+01	5.73E-02	.00E+00	37.2
P07	3.77E+01	3.77E+01	2.86E-02	4.04E+00	41.8
P08	3.74E+01	3.74E+01	3.00E-01	.00E+00	37.7
P10	3.42E+01	3.42E+01	1.11E-01	.00E+00	34.3
001	3.66E+01	3.66E+01	2.23E-01	.00E+00	36.8
002	3.77E+01	4.11E+01	2.14E-01	.00E+00	38.0
003	3.70E+01	3.70E+01	5.92E-02	1.72E+00	38.8
004	3.52E+01	3.52E+01	4.20E-02	.00E+00	35.2
005	3.79E+01	3.79E+01	2.98E-01	.00E+00	38.2
006	3.54E+01	3.54E+01	9.73E-02	.00E+00	35.5
007	3.57E+01	3.57E+01	2.67E-02	4.69E+00	40.5
008	3.73E+01	3.73E+01	8.21E-02	.00E+00	37.4
009	3.50E+01	3.50E+01	.00E+00	7.74E+00	42.7
010	3.54E+01	3.54E+01	1.18E-01	.00E+00	35.5
I01	3.52E+01	3.69E+01	6.49E-02	.00E+00	35.2
I02	3.64E+01	3.64E+01	1.87E-01	.00E+00	36.6

SITE A PERSONNEL DOSIMETERS - 12/1/76 TO 3/2/77 (cont'd)

I03	3.79E+01	3.79E+01	9.16E-02	.00E+00	38.0
I04	3.79E+01	3.79E+01	1.16E-01	.00E+00	38.0
I07	3.75E+01	3.75E+01	9.16E-02	.00E+00	37.5
I08	3.60E+01	3.60E+01	1.43E-01	.00E+00	36.1
I09	3.68E+01	3.68E+01	1.74E-01	.00E+00	37.0
I10	3.94E+01	3.94E+01	1.15E-01	8.18E-01	40.3
S01	3.67E+01	3.67E+01	3.21E-01	.00E+00	37.0
S02	3.62E+01	3.62E+01	4.96E-02	4.00E+00	40.3
S03	3.67E+01	3.67E+01	1.39E-01	.00E+00	36.8
S04	3.84E+01	3.84E+01	1.70E-01	.00E+00	38.5
S05	4.03E+01	4.03E+01	2.18E-01	.00E+00	40.5
S06	3.57E+01	3.57E+01	1.91E-02	2.43E+00	38.1
S07	3.81E+01	3.81E+01	2.42E-01	.00E+00	38.3
S08	3.40E+01	3.40E+01	2.08E-01	.00E+00	34.2
S09	3.86E+01	3.86E+01	2.44E-01	.00E+00	38.8
S10	3.87E+01	3.87E+01	1.15E-01	.00E+00	38.8
E01	4.39E+01	4.39E+01	.00E+00	9.32E+00	53.2
E02	4.07E+01	4.07E+01	1.85E-01	.00E+00	40.8
E03	3.92E+01	3.92E+01	2.00E-01	.00E+00	39.4
E04	3.81E+01	3.81E+01	8.40E-02	.00E+00	38.2
E05	3.99E+01	3.99E+01	1.56E-01	.00E+00	40.0
E06	3.53E+01	3.53E+01	1.22E-01	.00E+00	35.4
E08	4.07E+01	4.07E+01	.00E+00	5.34E+00	46.1
E09	3.55E+01	3.55E+01	1.91E-01	.00E+00	35.1
E10	3.72E+01	3.72E+01	4.20E-02	3.34E+00	40.6
C01	3.71E+01	3.71E+01	2.60E-01	.00E+00	37.4
C02	3.36E+01	3.36E+01	8.02E-02	1.40E+00	35.1
C03	4.19E+01	4.19E+01	2.23E-01	.00E+00	42.2
C04	3.68E+01	3.68E+01	9.16E-02	.00E+00	36.9
C05	3.33E+01	3.33E+01	1.01E-01	.00E+00	33.4
C06	5.02E+01	5.02E+01	8.78E-02	.00E+00	50.3
C07	3.86E+01	3.86E+01	6.68E-02	.00E+00	38.7
C08	3.88E+01	3.88E+01	1.74E-01	.00E+00	39.0
C09	3.53E+01	3.53E+01	3.23E-01	.00E+00	35.9
C10	4.84E+01	4.84E+01	1.22E-01	.00E+00	48.5
M01	4.27E+01	4.27E+01	.00E+00	8.87E+00	51.6
M02	4.24E+01	4.24E+01	1.15E-01	3.11E+00	45.7
M03	4.88E+01	4.88E+01	.00E+00	3.59E+00	52.3
M05	3.65E+01	3.65E+01	1.70E-01	.00E+00	36.6
M06	3.63E+01	3.63E+01	2.40E-01	.00E+00	36.6
M07	3.74E+01	3.74E+01	2.23E-01	.00E+00	37.6
M08	4.88E+01	4.88E+01	.00E+00	8.50E+00	57.3
M10	3.81E+01	3.81E+01	1.34E-01	.00E+00	38.2
P001	3.95E+01	3.95E+01	1.74E-01	.00E+00	39.7

SITE A PERSONNEL DOSIMETERS 3/2 TO 6/22/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MR
3C01	3.78E+01	3.78E+01	1.22E-01	.00E+00	37.9
3C02	3.71E+01	3.71E+01	1.60E-01	.00E+00	37.3
3C03	3.66E+01	3.66E+01	1.29E-01	.00E+00	36.7
3C04	3.88E+01	3.88E+01	1.01E-01	.00E+00	38.9
3C05	3.38E+01	3.38E+01	1.66E-01	.00E+00	33.9
3C06	3.87E+01	3.87E+01	8.96E-02	.00E+00	38.8
3C08	3.89E+01	3.89E+01	2.07E-01	.00E+00	39.2
3C09	3.95E+01	3.95E+01	9.93E-02	.00E+00	39.6
3C10	4.01E+01	4.01E+01	7.17E-02	.00E+00	40.2
3E01	3.97E+01	3.97E+01	1.69E-01	.00E+00	39.9
3E02	4.06E+01	4.06E+01	1.91E-01	.00E+00	40.8
3E03	3.98E+01	3.98E+01	2.21E-01	.00E+00	40.0
3E04	3.79E+01	3.79E+01	4.72E-02	1.13E+00	39.0
3E05	3.96E+01	3.96E+01	9.93E-02	.00E+00	39.7
3E06	3.69E+01	3.69E+01	1.91E-01	.00E+00	37.1
3E07	3.97E+01	3.97E+01	1.48E-01	.00E+00	39.8
3E08	3.96E+01	3.96E+01	1.71E-01	.00E+00	39.8
3E09	4.11E+01	4.11E+01	1.24E-01	.00E+00	41.2
3E10	3.85E+01	3.85E+01	1.34E-01	.00E+00	38.6
3I01	4.11E+01	4.11E+01	4.89E-03	.00E+00	41.1
3I02	3.80E+01	3.80E+01	1.34E-01	.00E+00	38.1
3I04	3.85E+01	3.85E+01	1.95E-02	.00E+00	38.5
3I05	3.85E+01	3.85E+01	1.35E-01	.00E+00	38.7
3I06	3.98E+01	3.98E+01	6.19E-02	.00E+00	39.9
3I07	3.98E+01	3.98E+01	1.40E-01	.00E+00	40.0
3I08	4.52E+01	4.52E+01	1.73E-01	.00E+00	45.4
3I09	3.86E+01	3.86E+01	1.79E-01	.00E+00	38.8
3I10	3.66E+01	3.66E+01	6.84E-02	.00E+00	36.7
3F01	3.94E+01	3.94E+01	1.43E-01	.00E+00	39.5
3F02	4.28E+01	4.28E+01	1.74E-01	.00E+00	43.0
3F03	3.85E+01	3.85E+01	2.07E-01	.00E+00	38.7
3F04	3.76E+01	3.76E+01	1.03E-01	.00E+00	37.7
3F06	3.96E+01	3.96E+01	6.51E-02	.00E+00	39.7
3F08	3.79E+01	3.79E+01	1.87E-01	.00E+00	38.0
3F09	4.02E+01	4.02E+01	2.28E-01	.00E+00	40.5
3F10	3.81E+01	3.81E+01	8.31E-02	.00E+00	38.2
2M01	4.17E+01	4.17E+01	1.79E-01	.00E+00	41.8
3M02	4.21E+01	4.21E+01	2.38E-01	.00E+00	42.4
3M03	4.36E+01	4.36E+01	4.40E-02	.00E+00	43.6
3M05	4.05E+01	4.05E+01	1.86E-01	.00E+00	40.7
3M06	4.16E+01	4.16E+01	2.02E-01	.00E+00	41.8
3M07	4.13E+01	4.13E+01	1.03E-01	.00E+00	41.4
3M08	4.36E+01	4.36E+01	1.94E-01	.00E+00	43.8
3M09	4.28E+01	4.28E+01	1.40E-01	.00E+00	42.9
3M10	4.77E+01	4.77E+01	4.23E-02	.00E+00	47.8
3001	4.53E+01	4.53E+01	.00E+00	4.21E-02	45.4
3002	4.83E+01	4.83E+01	1.89E-01	.00E+00	48.5

SITE A PERSONNEL DOSIMETERS - 3/2 TO 6/22/77 (Cont'd)

3003	4.21E+01	4.21E+01	1.56E-01	.00E+00	42.3
3004	4.19E+01	4.19E+01	1.89E-01	.00E+00	42.1
3005	4.57E+01	4.57E+01	4.72E-02	.00E+00	45.8
3006	4.18E+01	4.18E+01	2.35E-01	.00E+00	42.0
3007	3.83E+01	3.83E+01	1.56E-01	.00E+00	38.4
3008	4.37E+01	4.37E+01	1.66E-01	.00E+00	43.9
3009	4.01E+01	4.01E+01	1.11E-01	.00E+00	40.2
3010	5.22E+01	5.22E+01	1.34E-01	.00E+00	52.3
3P01	4.30E+01	4.30E+01	1.47E-01	.00E+00	43.1
3P02	4.51E+01	4.51E+01	9.61E-02	.00E+00	45.2
3P03	4.08E+01	4.08E+01	8.31E-02	.00E+00	40.9
3P04	4.74E+01	5.01E+01	.00E+00	.00E+00	47.4
3P05	4.37E+01	4.37E+01	1.63E-01	.00E+00	43.9
3P06	4.42E+01	4.42E+01	2.54E-01	.00E+00	44.4
3P08	4.19E+01	4.19E+01	1.29E-01	.00E+00	42.1
3P09	4.06E+01	4.06E+01	4.72E-02	.00E+00	40.7
3P10	4.02E+01	4.02E+01	3.08E-01	.00E+00	40.5
3S01	4.77E+01	4.77E+01	1.82E-01	.00E+00	47.9
3S02	5.28E+01	5.28E+01	1.89E-01	.00E+00	53.0
3S03	4.59E+01	4.59E+01	2.05E-01	.00E+00	46.2
3S04	6.54E+01	6.54E+01	3.42E-02	.00E+00	65.4
3S05	4.81E+01	4.81E+01	1.89E-01	.00E+00	48.3
3S06	4.30E+01	4.30E+01	1.76E-01	.00E+00	43.2
3S07	5.59E+01	5.59E+01	1.97E-01	.00E+00	55.9
3S08	5.14E+01	5.14E+01	7.98E-02	.00E+00	51.5
3S09	4.76E+01	4.76E+01	1.25E-01	.00E+00	47.7
3S10	6.90E+01	6.90E+01	1.55E-01	.00E+00	69.1
3S001	3.77E+01	3.77E+01	1.78E-01	.00E+00	37.9
3S002	4.55E+01	4.55E+01	1.25E-01	.00E+00	45.6
3PI01	2.79E+01	2.79E+01	1.58E-01	.00E+00	28.0
3PI02	2.83E+01	2.83E+01	1.76E-01	.00E+00	28.5
3TR01	5.13E+01	5.13E+01	2.08E-01	.00E+00	51.5
3TR02	5.32E+01	5.32E+01	5.70E-02	.00E+00	53.3
3CUP1	5.08E+01	5.08E+01	2.10E-01	.00E+00	51.0
UNMRK	5.51E+01	5.51E+01	1.47E-01	.00E+00	55.2
3AP01	2.32E+02	2.32E+02	1.21E-01	.00E+00	231.8
3AP02	5.80E+01	5.80E+01	.00E+00	.00E+00	58.0
3AP03	7.62E+02	8.26E+02	.00E+00	3.87E+01	800.7
3CH01	1.60E+02	1.60E+02	3.73E-01	.00E+00	160.0
3CH02	1.39E+02	1.39E+02	6.24E-01	.00E+00	139.4
3CR01	1.21E+02	1.21E+02	5.41E-01	.00E+00	121.1
3HP01	1.48E+02	1.55E+02	.00E+00	1.57E+01	164.1
3HP02	4.31E+02	4.31E+02	1.25E-01	.00E+00	431.4
3P001	4.25E+02	4.25E+02	2.83E-01	3.36E+00	428.9
3SF01	1.82E+02	1.82E+02	1.84E-01	.00E+00	182.1

SITE A PERSONNEL DOSIMETERS 6/20 TO 6/15/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
6C01	3.98E+01	3.98E+01	2.65E-01	.00E+00	40.1
6C02	3.51E+01	3.51E+01	2.59E-01	.00E+00	35.3
6C03	3.58E+01	3.58E+01	8.84E-02	.00E+00	35.9
6C04	3.59E+01	3.59E+01	8.64E-02	.00E+00	35.9
6C05	3.62E+01	3.62E+01	3.25E-01	.00E+00	36.6
6C06	5.35E+01	5.35E+01	8.84E-02	.00E+00	53.5
6C07	4.14E+01	4.14E+01	1.40E-01	.00E+00	41.5
6C08	4.28E+01	4.28E+01	3.04E-01	.00E+00	43.1
6C09	3.58E+01	3.58E+01	1.12E-01	1.47E-01	36.0
6C10	4.29E+01	4.29E+01	.00E+00	1.82E+01	61.1
6P001	5.05E+01	5.05E+01	9.91E-02	.00E+00	50.5
6001	3.42E+01	3.42E+01	2.78E-01	.00E+00	34.4
6002	3.47E+01	3.47E+01	.00E+00	3.15E+00	37.9
6003	3.42E+01	3.42E+01	9.48E-02	.00E+00	34.3
6004	3.61E+01	3.61E+01	2.78E-01	.00E+00	36.4
6005	3.57E+01	3.57E+01	3.56E-01	.00E+00	36.1
6006	3.56E+01	3.56E+01	2.80E-01	.00E+00	35.9
6007	3.40E+01	3.40E+01	1.29E-01	.00E+00	34.2
6008	3.59E+01	3.59E+01	1.29E-01	1.98E+00	38.0
6009	3.57E+01	3.57E+01	.00E+00	3.51E+00	39.2
6010	3.45E+01	3.45E+01	4.44E-01	.00E+00	34.9
6E01	3.49E+01	3.49E+01	6.47E-03	7.49E+00	42.4
6E02	3.59E+01	3.59E+01	.00E+00	1.60E+01	51.9
6E03	3.91E+01	3.91E+01	3.06E-01	.00E+00	39.4
6E04	3.60E+01	3.60E+01	2.24E-01	.00E+00	36.2
6E05	3.52E+01	3.52E+01	5.39E-02	5.36E+00	40.6
6E06	3.55E+01	3.55E+01	.00E+00	2.29E+00	37.8
6E07	3.68E+01	3.68E+01	9.46E-02	.00E+00	36.9
6E08	3.79E+01	3.79E+01	4.31E-03	5.66E+00	43.5
6E09	4.15E+01	4.15E+01	1.31E-01	.00E+00	41.6
6E10	3.59E+01	3.59E+01	.00E+00	8.39E+00	44.6
6I01	4.02E+01	4.02E+01	1.25E-01	.00E+00	40.3
6I02	3.64E+01	3.64E+01	1.61E-01	.00E+00	36.6
6I03	3.54E+01	3.54E+01	2.30E-01	.00E+00	35.6
6I04	3.66E+01	3.66E+01	7.33E-02	5.08E+00	41.7
6I05	3.49E+01	3.49E+01	1.19E-01	.00E+00	35.1
6I06	3.60E+01	3.60E+01	2.72E-01	.00E+00	36.3
6I07	3.47E+01	3.47E+01	3.02E-01	.00E+00	35.0
6I08	3.60E+01	3.60E+01	6.03E-02	.00E+00	36.1
6I09	5.31E+01	5.31E+01	1.21E-01	.00E+00	53.2
6I10	4.12E+01	4.12E+01	2.16E-01	.00E+00	41.4
6PIG01	2.83E+01	2.83E+01	5.17E-02	2.05E+00	30.4
6PIG02	3.21E+01	3.21E+01	1.01E-01	.00E+00	32.2
6HP01	7.83E+01	7.83E+01	.00E+00	5.41E+00	63.7
6HP02	1.81E+02	1.81E+02	1.15E+00	.00E+00	182.2
6CH01	7.08E+01	7.08E+01	2.18E-01	.00E+00	71.0
6CH02	5.25E+01	5.16E+01	4.74E-02	5.80E+00	56.3
6TRC01	4.23E+01	4.23E+01	2.59E-01	.00E+00	42.6
6C02	4.36E+01	4.36E+01	2.11E-01	.00E+00	43.6

SITE A PERSONNEL DOSIMETERS - 6/20 TO 8/15/77 (cont'd)

65F01	2.16E+02	2.16E+02	.00E+00	2.83E+01	244.4
6F01	4.33E+01	4.33E+01	.00E+00	6.26E+00	49.8
6F02	4.05E+01	4.05E+01	1.34E-01	.00E+00	40.6
6F03	3.58E+01	3.58E+01	3.15E-01	.00E+00	35.1
6F04	3.77E+01	3.77E+01	1.64E-01	.00E+00	37.9
6F05	3.69E+01	3.69E+01	1.70E-01	.00E+00	37.1
6F06	3.54E+01	3.54E+01	3.24E-01	.00E+00	33.7
6F07	3.55E+01	3.55E+01	6.19E-02	4.03E+00	39.6
6F08	3.68E+01	3.68E+01	3.43E-01	.00E+00	37.2
6F09	3.43E+01	3.43E+01	1.66E-01	.00E+00	34.5
6F10	3.32E+01	3.32E+01	2.41E-01	.00E+00	33.4
6AP001	4.64E+01	4.64E+01	2.16E-02	2.22E+00	46.7
6AP002	1.03E+02	1.03E+02	2.32E-01	.00E+00	103.2
6AP003	4.63E+01	4.63E+01	7.53E-02	4.23E+00	32.6
6CR01	6.93E+01	6.93E+01	3.84E-02	.00E+00	59.3
6FE002	1.07E+02	1.07E+02	3.17E-01	.00E+00	107.2
3S001	3.78E+01	3.78E+01	1.74E-01	.00E+00	38.0
3S002	3.68E+01	3.68E+01	3.02E-02	3.67E+00	42.7
73164	5.11E+01	5.11E+01	1.92E-01	.00E+00	51.8
6F01	3.72E+01	3.72E+01	3.82E-02	.00E+00	37.5
6F02	4.05E+01	4.05E+01	1.70E-01	.00E+00	40.7
6F03	3.72E+01	3.72E+01	1.40E-01	7.23E-01	36.1
6F04	3.96E+01	3.96E+01	1.34E-01	.00E+00	39.7
6F05	3.59E+01	3.59E+01	3.68E-02	7.38E-01	36.7
6F06	3.09E+01	3.09E+01	1.12E-01	.00E+00	31.1
6F06	3.85E+01	3.85E+01	1.42E-01	.00E+00	38.7
6F07	3.90E+01	3.90E+01	2.41E-01	.00E+00	39.2
6F08	3.84E+01	3.84E+01	1.17E-01	.00E+00	38.6
6F09	3.67E+01	3.67E+01	2.37E-01	.00E+00	36.9
6F10	3.78E+01	3.78E+01	3.81E-01	.00E+00	38.2
6M01	3.68E+01	3.68E+01	3.43E-01	.00E+00	37.1
6M02	3.63E+01	3.63E+01	2.16E-01	.00E+00	36.3
6M03	3.65E+01	3.65E+01	1.73E-01	.00E+00	36.7
6M04	3.73E+01	3.73E+01	3.62E-02	2.51E+00	37.9
6M05	3.94E+01	3.94E+01	5.02E-02	.00E+00	39.3
6M06	3.96E+01	3.96E+01	1.80E-01	.00E+00	39.7
6M07	3.47E+01	3.47E+01	1.16E-02	7.22E+00	42.1
6M08	3.79E+01	3.79E+01	.00E+00	3.61E-01	38.2
6M09	3.62E+01	3.73E+01	3.77E-01	.00E+00	36.6
6M10	3.62E+01	3.62E+01	3.68E-02	.00E+00	36.2
6801	3.62E+01	3.67E+01	1.38E-01	.00E+00	36.8
6802	3.69E+01	3.89E+01	1.01E-01	.00E+00	39.0
6803	3.75E+01	3.75E+01	1.03E-01	.00E+00	37.6
6804	4.95E+01	4.95E+01	7.54E-02	1.63E+00	51.1
6805	3.69E+01	3.69E+01	2.16E-03	2.38E+00	42.6
6806	3.77E+01	3.77E+01	1.78E-01	.00E+00	37.7
6807	4.33E+01	4.33E+01	1.06E-01	2.77E+00	46.1
6808	3.43E+01	3.43E+01	3.62E-03	3.00E+00	37.3
6809	4.72E+01	4.72E+01	1.47E-01	4.14E+00	56.1
6810	4.95E+01	4.95E+01	1.03E-01	.00E+00	49.5

SITE A PERSONNEL DOSIMETERS 8/15 TO 12/20/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
8C01	4.19E+01	4.19E+01	1.67E-01	.00E+00	42.0
8C03	4.47E+01	4.47E+01	1.63E-01	5.36E+00	50.2
8C04	4.08E+01	4.08E+01	1.94E-01	.00E+00	41.0
8C05	3.98E+01	3.98E+01	1.55E-01	.00E+00	39.9
8C06	4.29E+01	4.29E+01	1.55E-01	.00E+00	43.0
8C07	3.91E+01	3.91E+01	1.67E-01	.00E+00	39.3
8C08	4.56E+01	6.01E+01	1.27E-01	.00E+00	45.8
8C09	4.53E+01	4.53E+01	2.39E-01	.00E+00	45.5
8C10	4.07E+01	4.07E+01	1.45E-01	.00E+00	40.9
8E01	4.30E+01	4.35E+01	1.13E-01	.00E+00	43.2
8E02	4.42E+01	4.42E+01	3.42E-01	.00E+00	44.5
8E03	4.25E+01	4.25E+01	2.06E-01	.00E+00	42.7
8E04	4.33E+01	4.33E+01	2.34E-01	.00E+00	43.5
8E05	3.83E+01	3.83E+01	3.27E-02	3.71E+00	42.0
8E06	6.46E+01	2.03E+02	.00E+00	3.17E+01	98.3
8E07	4.65E+01	6.27E+01	1.03E-01	.00E+00	46.6
8E08	4.11E+01	4.11E+01	2.21E-01	.00E+00	41.3
8E09	4.19E+01	4.19E+01	.00E+00	.00E+00	41.9
8E10	3.98E+01	3.98E+01	1.42E-01	.00E+00	39.9
8F01	3.72E+01	3.72E+01	5.07E-02	1.34E+01	50.6
8F02	4.51E+01	4.51E+01	.00E+00	.00E+00	45.1
8F03	3.73E+01	3.73E+01	1.76E-01	.00E+00	37.4
8F04	3.79E+01	3.79E+01	1.01E-01	.00E+00	38.0
8F05	3.96E+01	3.96E+01	1.75E-01	.00E+00	39.6
8F06	3.90E+01	3.90E+01	3.24E-01	.00E+00	39.4
8F07	3.91E+01	3.91E+01	2.22E-01	.00E+00	39.3
8F08	3.92E+01	3.92E+01	1.21E-01	1.98E+00	41.3
8F09	3.82E+01	3.82E+01	1.60E-01	.00E+00	38.4
8F10	4.12E+01	4.12E+01	9.15E-02	.00E+00	41.3
8I01	3.92E+01	3.92E+01	1.90E-01	.00E+00	39.4
8I02	3.82E+01	3.82E+01	2.03E-01	.00E+00	38.4
8I03	4.18E+01	4.18E+01	2.19E-01	.00E+00	42.0
8I04	3.94E+01	3.94E+01	1.55E-01	.00E+00	39.6
8I05	3.92E+01	3.92E+01	1.73E-01	.00E+00	39.3
8I06	4.08E+01	4.08E+01	1.61E-01	.00E+00	41.0
8I07	4.05E+01	4.05E+01	1.62E-01	.00E+00	40.7
8I08	4.20E+01	4.20E+01	1.68E-01	.00E+00	42.2
8I09	3.82E+01	3.82E+01	4.90E-02	2.27E+00	40.6
8I10	4.16E+01	4.16E+01	9.31E-02	.00E+00	41.7
8M01	4.12E+01	4.12E+01	2.42E-01	.00E+00	41.4
8M02	4.21E+01	4.21E+01	1.37E-01	.00E+00	42.3
8M03	4.17E+01	4.17E+01	1.24E-01	.00E+00	41.6
8M04	4.06E+01	4.06E+01	1.80E-01	.00E+00	40.8
8M05	4.02E+01	4.02E+01	1.90E-01	.00E+00	40.3
8M06	3.98E+01	3.98E+01	2.01E-01	.00E+00	40.0
8M07	4.18E+01	4.18E+01	1.03E-01	3.73E+00	45.6
8M08	4.06E+01	4.06E+01	7.52E-02	.00E+00	40.7
8M09	4.02E+01	4.02E+01	1.61E-01	.00E+00	40.3

SITE A PERSONNEL DOSIMETERS - 8/15 TO 12/20/77

8M10	4.05E+01	4.05E+01	1.39E-01	.00E+00	40.7
8001	4.17E+01	4.17E+01	1.05E-01	.00E+00	41.8
8002	3.90E+01	3.90E+01	1.75E-01	.00E+00	39.2
8003	4.29E+01	4.29E+01	3.56E-01	.00E+00	43.3
8004	3.69E+01	3.69E+01	1.91E-01	.00E+00	37.1
8005	3.93E+01	3.93E+01	1.66E-01	.00E+00	39.3
8007	3.67E+01	3.67E+01	2.35E-01	.00E+00	36.9
8008	3.97E+01	3.97E+01	6.05E-02	9.80E+00	49.6
8009	4.27E+01	4.27E+01	9.48E-02	.00E+00	42.8
8010	3.91E+01	3.91E+01	1.49E-01	.00E+00	37.3
8P01	3.92E+01	3.92E+01	5.56E-02	6.57E+00	43.1
8P02	3.97E+01	3.97E+01	1.66E-01	.00E+00	37.9
8P03	4.05E+01	4.05E+01	1.13E-01	.00E+00	40.6
8P04	4.00E+01	4.00E+01	2.94E-02	1.42E+01	54.2
8P06	3.85E+01	3.85E+01	2.29E-02	8.32E+00	46.9
8P07	3.20E+01	3.20E+01	.00E+00	1.36E+01	43.8
8P08	4.30E+01	4.30E+01	2.53E-01	.00E+00	43.3
8P09	3.66E+01	3.66E+01	2.70E-01	.00E+00	36.3
8P10	3.73E+01	3.73E+01	2.32E-01	.00E+00	37.5
8S01	3.90E+01	3.90E+01	1.26E-01	6.27E-02	39.2
8S02	3.76E+01	3.76E+01	3.10E-02	1.23E+01	50.0
8S03	4.07E+01	4.07E+01	7.48E-02	4.43E+00	43.3
8S07	3.93E+01	3.93E+01	7.03E-02	6.76E+00	41.7
8S08	4.42E+01	4.42E+01	1.93E-01	.00E+00	44.4
8S09	3.95E+01	3.95E+01	1.26E-01	.00E+00	37.7
8S10	4.15E+01	4.15E+01	2.03E-01	.00E+00	41.7
8SF01	3.84E+02	3.84E+02	.00E+00	2.34E+02	617.3
8CH01	1.34E+02	1.34E+02	.00E+00	1.30E+01	146.9
8CH02	6.53E+01	6.53E+01	2.73E-02	1.80E+01	63.3
8HP01	3.42E+02	3.42E+02	9.13E-02	8.90E+01	431.3
8HP03	1.35E+02	1.35E+02	2.19E-01	8.13E+00	142.9
TRC01	5.03E+01	5.03E+01	3.94E-01	.00E+00	50.7
TRC02	5.11E+01	5.11E+01	4.55E-01	.00E+00	51.3
SPC01	4.64E+01	4.64E+01	2.56E-01	.00E+00	46.7
SPC02	1.57E+02	1.57E+02	4.93E-01	.00E+00	157.2
APC01	5.40E+01	5.40E+01	3.03E-01	.00E+00	54.2
PEC02	2.53E+02	2.53E+02	1.70E-01	7.23E+01	325.1
APC03	5.43E+01	5.43E+01	2.63E-01	.00E+00	54.5
8HP02	1.77E+02	1.77E+02	6.03E-01	1.06E+01	168.3
CH20P	4.21E+01	4.21E+01	7.50E-02	2.57E+00	30.3
2T16A	5.93E+01	5.93E+01	2.61E-01	1.37E+01	73.2
8SD01	3.97E+01	3.97E+01	3.24E-01	.00E+00	40.0
8SD02	4.29E+01	4.29E+01	1.52E-01	.00E+00	43.1
PIG01	2.36E+01	2.36E+01	2.14E-01	.00E+00	23.6
PIG02	2.35E+01	2.35E+01	2.61E-01	.00E+00	23.6

APPENDIX D - SITE 8 DATA

SITE B - OFFSITE CONTROL, CYCLES 1-7 (LiF - Bare)

SITE B - ONSITE CONTROLS, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 3, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 4, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 10, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 11, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 12, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 14, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 16, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 17, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 15, CYCLES 1-7 (LiF - Bare)

SITE B - STATION 20, CYCLES 1-7 (LiF - Bare)

SITE B.- OFFSITE CONTROLS, CYCLES 1-7

SITE B - ONSITE CONTROLS, CYCLES 1-7

SITE B - ELECTRICAL ENGINEERS, CYCLES 1-7

SITE B - SAFETY ENGINEERS, CYCLES 1-7

SITE B - WELDERS, CYCLES 1-7

SITE B - TIME KEEPERS, CYCLES 1-7

SITE B - SUPERVISORS, CYCLES 1-7

SITE B - FIELD ENGINEERS, CYCLES 1-7

SITE B ENVIRONMENTAL DOSIMETERS 7/15 TO 9/17/76

I.D.#	700B	600B	700F	600F	400F
E-130028	2.75E+01	4.10E-02	2.38E+01	5.56E-02	2.89E+01
E-132029	3.30E+01	.00E+00	2.59E+01	3.68E-02	2.96E+01
E-129051	3.52E+01	.00E+00	2.59E+01	5.02E-02	3.14E+01
E-115052	3.17E+01	.00E+00	2.37E+01	6.36E-02	3.01E+01
E-118055	3.51E+01	.00E+00	3.95E+01	.00E+00	3.30E+01
E-135053	2.73E+01	2.51E-02	2.35E+01	7.71E-02	2.91E+01
E-131056	5.80E+01	1.82E-02	5.04E+01	5.75E-02	6.76E+01
E-119057	3.19E+01	2.46E-02	2.62E+01	5.02E-02	3.26E+01
E-121060	4.35E+01	2.92E-02	3.89E+01	3.64E-02	4.78E+01
E-119061	3.20E+01	3.37E-02	2.57E+01	7.97E-02	3.32E+01
E-114000	1.23E+02	1.06E-01	1.14E+02	2.03E-01	1.53E+02
E-116000	2.75E+01	4.56E-02	2.40E+01	5.83E-02	2.97E+01
E-120000	3.23E+01	2.90E-02	2.75E+01	7.69E-02	3.50E+01
E-123000	3.03E+01	2.61E-04	2.50E+01	4.48E-02	3.27E+01
E-124000	2.98E+01	3.74E-02	2.50E+01	7.97E-02	3.00E+01
E-127000	3.02E+01	2.33E-02	2.46E+01	1.01E-01	3.32E+01
E-128000	5.12E+01	5.22E-02	4.25E+01	1.57E-01	5.96E+01
E-133000	5.72E+01	2.56E-02	5.01E+01	7.09E-02	6.87E+01
E-117200	2.91E+01	4.93E-02	2.61E+01	9.31E-02	3.27E+01
E-122700	3.08E+01	1.15E-02	2.53E+01	1.09E-01	3.09E+01
E-125700	2.92E+01	5.38E-02	2.60E+01	5.29E-02	3.21E+01
E-126700	3.26E+01	1.96E-02	2.46E+01	5.29E-02	3.19E+01
E-136700	3.15E+01	2.49E-02	2.55E+01	6.90E-02	3.21E+01

SITE B ENVIRONMENTAL DOSIMETERS 9/18 TO 11/29/76

I.D.#	700B	600B	700F	600F	400F
#58	2.60E+01	1.25E-01	2.76E+01	4.14E-02	2.98E+01
#66	3.11E+01	4.38E-02	2.69E+01	2.85E-02	2.95E+01
#68	4.17E+01	8.86E-02	3.81E+01	1.38E-02	4.29E+01
#69	2.37E+01	7.72E-02	2.38E+01	2.95E-02	2.47E+01
#75	3.32E+01	4.45E-02	3.04E+01	5.35E-04	3.16E+01
#77	2.69E+01	1.08E-01	2.51E+01	2.58E-02	2.78E+01
#79	2.74E+01	1.07E-01	2.45E+01	4.86E-02	2.76E+01
#82	2.54E+01	7.58E-02	2.47E+01	2.57E-02	2.74E+01
#87	2.40E+02	4.21E-01	2.14E+02	3.75E-02	2.74E+02
#90	3.99E+01	1.50E-01	3.53E+01	2.32E-02	4.31E+01
#95	2.99E+01	9.61E-02	2.92E+01	6.37E-03	3.26E+01
#96	3.86E+01	9.70E-02	2.77E+01	3.31E-02	3.38E+01
#97	2.47E+01	7.18E-02	2.43E+01	2.14E-02	2.80E+01
#103	6.15E+01	1.23E-01	5.39E+01	2.58E-02	6.94E+01
#134	7.10E+02	1.22E+00	7.32E+02	1.48E+00	1.03E+03
#170	3.00E+01	9.99E-02	2.85E+01	4.59E-02	3.40E+01
#171	2.73E+01	9.71E-02	2.56E+01	4.28E-02	2.93E+01
#173	3.41E+01	8.99E-02	3.05E+01	2.78E-02	3.36E+01
#175	2.92E+01	6.39E-02	2.83E+01	.00E+00	3.22E+01
#38	2.70E+01	1.18E-01	2.83E+01	3.95E-02	3.11E+01
#52	2.72E+01	1.23E-01	2.71E+01	3.28E-02	2.91E+01

SITE B ENVIRONMENTAL DOSIMETERS 11/29/76 TO 2/14/77

I.D.#	700B	600B	700F	600F	400F
#58	3.33E+01	.00E+00	2.50E+01	4.39E-02	2.25E+01
#66	3.33E+01	.00E+00	2.79E+01	.00E+00	2.35E+01
#68	5.08E+01	.00E+00	4.28E+01	2.71E-02	4.17E+01
#69	2.61E+01	.00E+00	2.14E+01	.00E+00	1.95E+01
#95	3.84E+01	.00E+00	4.01E+01	.00E+00	2.90E+01
#79	2.61E+01	1.60E-02	2.27E+01	5.91E-02	2.17E+01
#82	3.18E+01	.00E+00	2.74E+01	.00E+00	2.28E+01
#87	4.88E+02	.00E+00	3.95E+02	3.63E-01	3.97E+02
#90	7.51E+01	.00E+00	5.96E+01	.00E+00	5.97E+01
#96	2.58E+01	.00E+00	2.18E+01	.00E+00	1.92E+01
#97	2.51E+01	.00E+00	2.27E+01	1.20E-02	1.97E+01
#103	4.34E+01	.00E+00	3.67E+01	5.31E-02	3.74E+01
#134	9.25E+02	2.95E-01	7.05E+02	1.37E+00	7.50E+02
#170	3.49E+01	.00E+00	3.10E+01	.00E+00	2.70E+01
#171	3.28E+01	1.74E-02	2.44E+01	.00E+00	2.03E+01
#173	3.06E+01	.00E+00	2.86E+01	.00E+00	2.25E+01
#175	2.73E+01	.00E+00	2.39E+01	1.92E-02	2.27E+01
#201	3.24E+01	.00E+00	2.49E+01	2.02E-02	2.53E+01
#77	3.17E+01	.00E+00	2.30E+01	5.94E-02	2.07E+01
#38	2.87E+01	1.46E-02	2.68E+01	.00E+00	2.09E+01
#52	3.11E+01	.00E+00	2.55E+01	1.20E-02	2.05E+01

SITE B ENVIRONMENTAL DOSIMETERS 2/14 TO 4/8/77

I.D.#	700B	600B	700F	600F	400F
170HH	2.15E+01	7.92E-02	2.08E+01	7.97E-02	1.92E+01
05257	2.45E+01	4.76E-02	2.19E+01	5.90E-02	2.01E+01
08760	3.74E+01	4.97E-02	3.47E+01	4.08E-02	3.13E+01
07928	1.96E+01	5.17E-02	1.86E+01	5.86E-02	1.60E+01
09581	2.67E+01	8.01E-02	2.46E+01	3.95E-02	2.28E+01
13429	2.29E+01	7.73E-02	2.44E+01	2.07E-02	2.06E+01
10555	2.10E+01	5.42E-02	1.97E+01	5.35E-02	1.86E+01
03859	3.80E+02	1.13E-03	3.45E+02	3.74E-01	3.40E+02
07708	3.52E+01	1.39E-01	3.18E+01	5.97E-02	2.67E+01
09752	1.95E+01	6.02E-02	1.83E+01	4.33E-02	1.76E+01
00854	2.00E+01	5.89E-02	2.13E+01	5.21E-02	1.82E+01
00356	5.14E+01	1.15E-01	4.71E+01	.00E+00	4.32E+01
17122	5.80E+02	1.15E+00	5.39E+02	4.86E-01	5.19E+02
06961	2.54E+01	8.41E-02	2.51E+01	3.28E-02	2.14E+01
173RR	2.42E+01	4.71E-02	2.10E+01	5.94E-02	1.94E+01
002CT	2.36E+01	7.00E-02	2.31E+01	5.65E-02	2.15E+01
09653	2.16E+01	4.25E-02	2.08E+01	2.76E-02	1.86E+01
06851	2.25E+01	4.61E-02	2.26E+01	8.54E-03	1.91E+01
08292	2.41E+01	8.62E-02	2.12E+01	7.01E-02	2.20E+01
05301	2.14E+01	7.89E-02	2.14E+01	6.54E-02	1.81E+01
06602	2.20E+01	7.14E-02	2.12E+01	6.25E-02	1.81E+01

SITE B ENVIRONMENTAL DOSIMETERS 4/4 TO 6/8/77

I.D.#	700B	600B	700F	600F	400F
#3	5.70E+02	1.59E-01	5.15E+02	1.60E+00	5.67E+03
#4	2.88E+01	.00E+00	2.67E+01	3.82E-02	2.53E+01
#5	3.32E+01	.00E+00	3.03E+01	4.70E-02	3.10E+01
#6	3.25E+01	.00E+00	2.95E+01	6.15E-02	2.86E+01
#7	2.96E+01	.00E+00	2.90E+01	6.39E-03	3.09E+01
#8	3.05E+01	3.50E-03	3.10E+01	2.38E-02	3.31E+01
#9	3.31E+01	.00E+00	3.39E+01	.00E+00	3.55E+01
#10	2.99E+01	3.97E-02	3.15E+01	1.51E-02	3.56E+01
#11	6.04E+01	1.02E-02	5.60E+01	9.68E-02	6.61E+01
#12	3.35E+01	1.30E-03	3.36E+01	1.52E-02	3.67E+01
#13	1.93E+02	6.01E-03	1.82E+02	.00E+00	2.21E+02
#14	4.44E+01	.00E+00	4.47E+01	1.54E-02	4.92E+01
#15	3.31E+01	5.15E-02	3.47E+01	.00E+00	3.82E+01
#16	3.37E+01	1.05E-02	3.98E+01	.00E+00	4.27E+01
#17	5.01E+01	.00E+00	3.96E+01	3.27E-02	4.67E+01
#18	3.81E+01	.00E+00	3.60E+01	1.52E-02	4.16E+01
#19	3.44E+01	1.89E-02	3.11E+01	3.83E-02	3.31E+01
#20	3.01E+01	6.08E-02	3.12E+01	4.99E-02	3.55E+01
#21	3.08E+01	3.61E-02	3.22E+01	.00E+00	3.49E+01
#CON1	3.21E+01	2.71E-02	3.34E+01	.00E+00	3.69E+01
#CON2	3.25E+01	4.29E-02	3.16E+01	5.28E-02	3.48E+01
#CON3	3.41E+01	1.93E-02	3.24E+01	3.56E-03	3.48E+01

SITE B ENVIRONMENTAL DOSIMETERS 6/4 TO 6/8/77 TO 9/1 TO 9/10/77

I.D.#	700B	600B	700F	600F	400F
#3	6.05E+02	1.63E+00	5.24E+02	1.73E+00	6.78E+02
#4	2.76E+01	1.80E-01	2.58E+01	1.42E-01	3.55E+01
#5	3.39E+01	1.93E-01	3.09E+01	1.67E-01	4.09E+01
#6	3.29E+01	1.57E-01	2.97E+01	1.14E-01	3.98E+01
#7	2.96E+01	1.96E-01	2.74E+01	1.33E-01	3.11E+01
#8	3.06E+01	1.54E-01	2.84E+01	1.73E-01	3.68E+01
#9	3.11E+01	1.57E-01	2.76E+01	1.44E-01	3.83E+01
#10	3.13E+01	1.80E-01	2.93E+01	1.41E-01	3.80E+01
#11	6.56E+01	1.25E-01	5.60E+01	1.76E-01	7.43E+01
#12	3.09E+01	2.09E-01	2.94E+01	1.52E-01	3.80E+01
#13	2.52E+02	3.92E-01	2.14E+02	3.14E-01	2.47E+02
#14	5.31E+01	1.85E-01	4.95E+01	1.06E-01	6.37E+01
#15	3.84E+01	1.94E-01	3.37E+01	1.43E-01	4.39E+01
#17	4.24E+01	2.13E-01	3.80E+01	9.43E-02	4.87E+01
#18	4.10E+01	2.06E-01	3.65E+01	1.42E-01	4.70E+01
#19	3.28E+01	1.66E-01	2.90E+01	1.28E-01	3.93E+01
#20	3.54E+01	1.88E-01	3.09E+01	1.88E-01	3.93E+01
#21	3.16E+01	1.83E-01	2.97E+01	1.49E-01	3.70E+01
#22	3.28E+01	1.77E-01	3.05E+01	1.38E-01	4.06E+01
#23	3.39E+01	1.79E-01	2.70E+01	1.92E-01	3.87E+01

SITE B ENVIRONMENTAL DOSIMETERS 9-1 TO 9-10-77 TO 11-1-77

I.D.#	700B	600B	700F	600F	400F
#3	3.95E+02	8.46E-01	3.49E+02	1.26E+00	4.06E+02
#4	1.76E+01	9.67E-02	1.60E+01	1.08E-01	2.07E+01
#5	2.40E+01	9.01E-02	2.11E+01	1.53E-01	2.72E+01
#7	1.91E+01	7.72E-02	1.75E+01	1.06E-01	2.31E+01
#8	2.04E+01	7.51E-02	1.85E+01	8.84E-02	2.24E+01
#9	2.08E+01	1.04E-01	1.90E+01	1.16E-01	2.53E+01
#10	1.99E+01	8.68E-02	1.81E+01	1.15E-01	2.39E+01
#11	3.89E+01	1.43E-01	3.49E+01	1.87E-01	4.13E+01
#12	2.03E+01	1.24E-01	1.89E+01	1.34E-01	2.46E+01
#13	6.37E+01	1.22E-01	5.26E+01	2.02E-01	1.04E+02
#14	2.67E+01	8.98E-02	2.32E+01	1.41E-01	2.98E+01
#15	2.48E+01	1.06E-01	2.22E+01	1.20E-01	2.88E+01
#16	2.41E+01	7.66E-02	2.14E+01	1.10E-01	3.14E+01
#18	2.69E+01	1.09E-01	2.34E+01	1.32E-01	3.06E+01
#19	2.37E+01	8.05E-02	2.06E+01	1.32E-01	2.61E+01
#20	2.20E+01	1.21E-01	2.04E+01	1.28E-01	2.49E+01
#21	2.09E+01	1.00E-01	1.98E+01	2.23E-01	2.87E+01
UNUSE	2.16E+01	1.14E-01	1.84E+01	1.45E-01	2.63E+01

SITE B PERSONNEL DOSIMETERS 7/10 TO 9/17/76

J. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
A-1	3.70E+01	3.70E+01	1.52E-01	.00E+00	37.1
A-2	3.42E+01	3.42E+01	2.27E-01	.00E+00	34.4
B-1	3.85E+01	3.85E+01	1.12E-01	.00E+00	38.6
B-2	3.64E+01	3.64E+01	1.15E-01	.00E+00	36.5
B-3	5.33E+01	5.33E+01	6.92E-02	.00E+00	53.4
B-4	4.29E+01	4.29E+01	1.25E-01	.00E+00	43.0
B-5	4.62E+01	4.62E+01	9.04E-02	.00E+00	46.3
C-1	3.57E+01	3.57E+01	4.04E-02	.00E+00	35.7
C-2	4.12E+01	4.12E+01	1.19E-01	.00E+00	41.3
C-3	4.39E+01	4.39E+01	8.27E-02	.00E+00	44.0
C-4	3.44E+01	3.44E+01	1.92E-01	.00E+00	34.6
D-1	4.02E+01	4.02E+01	7.31E-02	.00E+00	40.3
D-2	3.61E+01	3.61E+01	1.92E-01	.00E+00	36.3
D-3	8.60E+01	8.60E+01	1.79E-01	.00E+00	86.2
D-4	1.04E+02	1.04E+02	1.88E-01	.00E+00	104.4
D-5	7.63E+01	7.63E+01	1.88E-01	.00E+00	76.5
D-6	4.03E+01	4.03E+01	1.37E-01	.00E+00	40.5
E-1	5.75E+01	5.75E+01	3.33E-01	.00E+00	57.8
G-1	3.54E+01	3.54E+01	1.92E-01	.00E+00	35.6
G-2	7.89E+01	7.89E+01	7.88E-02	.00E+00	79.0
G-3	3.79E+01	3.79E+01	1.56E-01	.00E+00	38.0
H-1	3.94E+01	3.94E+01	8.08E-02	.00E+00	39.5
H-2	4.39E+01	4.39E+01	1.92E-01	.00E+00	44.1
H-3	4.39E+01	4.39E+01	4.62E-02	.00E+00	44.0
I	4.05E+01	4.05E+01	1.85E-01	.00E+00	40.7
J-1	3.84E+01	3.84E+01	2.21E-01	.00E+00	38.6
J-2	3.96E+01	3.96E+01	1.52E-01	.00E+00	39.8
K-1	4.86E+01	4.86E+01	2.35E-01	.00E+00	48.8
K-2	4.10E+01	4.10E+01	2.88E-02	.00E+00	41.1
K-3	4.66E+01	4.66E+01	1.58E-01	.00E+00	46.7
K-4	4.00E+01	4.00E+01	2.52E-01	.00E+00	40.3
K-5	4.43E+01	4.43E+01	1.90E-01	.00E+00	44.5
L-1	9.43E+01	9.43E+01	1.27E-01	.00E+00	94.4
L-2	4.76E+01	4.76E+01	7.12E-02	.00E+00	47.6
L-3	3.29E+01	3.29E+01	1.50E-01	.00E+00	33.1
L-4	4.18E+01	4.18E+01	2.13E-01	.00E+00	42.0
L-5	3.95E+01	3.95E+01	2.15E-01	.00E+00	39.7
M-1	5.16E+01	5.16E+01	1.67E-01	.00E+00	51.6
M-2	4.69E+01	4.69E+01	1.92E-01	.00E+00	47.1
M-3	4.28E+01	4.28E+01	1.69E-01	.00E+00	42.9
M-4	3.55E+01	3.55E+01	2.60E-01	.00E+00	35.8
P-1	7.48E+01	7.48E+01	.00E+00	.00E+00	74.8
P-2	3.88E+01	3.88E+01	1.21E-01	.00E+00	38.9
P-3	3.33E+01	3.33E+01	8.85E-02	.00E+00	33.4
R-1	1.12E+02	1.12E+02	7.88E-02	7.89E+00	119.8
R-2	4.86E+01	4.86E+01	2.15E-01	.00E+00	48.8
S-1	4.62E+01	4.62E+01	1.94E-01	.00E+00	46.4
S-2	3.86E+01	3.86E+01	9.81E-02	.00E+00	38.7
S-3	3.16E+01	3.16E+01	1.19E-01	.00E+00	31.8

SITE B PERSONNEL DOSIMETERS - 7/10 TO 9/17/76

T-1	5.74E+01	5.74E+01	5.00E-02	.00E+00	57.5
T-2	4.99E+01	4.99E+01	1.37E-01	.00E+00	50.1
W-1	4.11E+01	4.11E+01	2.37E-01	.00E+00	41.4
W-2	4.08E+01	4.08E+01	1.88E-01	.00E+00	41.0
505-1	1.22E+02	1.22E+02	.00E+00	1.26E+01	134.1
507-1	2.86E+02	2.86E+02	4.63E+01	1.61E+03	1940.7
510-1	7.36E+01	7.36E+01	1.10E-01	.00E+00	73.7
518-1	3.45E+02	3.45E+02	9.04E+01	1.56E+03	1999.9
519-1	8.08E+01	8.08E+01	1.63E-01	.00E+00	81.0
609-1	4.04E+02	4.04E+02	6.35E+01	1.58E+03	2049.3
616-1	4.25E+02	4.25E+02	.00E+00	5.04E+01	475.6
616-2	2.07E+01	2.07E+01	9.04E-02	.00E+00	20.6
643-1	2.11E+02	2.11E+02	.00E+00	4.44E+01	255.1
645-1	1.77E+02	1.77E+02	2.63E-01	.00E+00	177.4
646-1	3.16E+02	3.16E+02	1.17E+00	.00E+00	317.2
PC-1	3.05E+01	3.05E+01	9.04E-02	.00E+00	30.6
PC-2	2.99E+01	2.99E+01	1.69E-01	.00E+00	30.0
CO-1	3.11E+01	3.11E+01	1.62E-01	.00E+00	31.3
CO-2	3.11E+01	3.11E+01	9.04E-02	.00E+00	31.2
CH-1	3.20E+01	3.20E+01	3.46E-02	.00E+00	32.0
CH-2	3.24E+01	3.24E+01	2.10E-01	.00E+00	32.6
Z-01	2.73E+01	2.73E+01	1.33E-01	.00E+00	27.4
Z-02	2.76E+01	2.76E+01	2.86E-02	.00E+00	27.6
Z-03	2.65E+01	2.65E+01	1.35E-01	.00E+00	26.5
Z-04	2.75E+01	2.75E+01	8.08E-02	.00E+00	27.6
Z-1	7.16E+01	7.16E+01	1.42E+01	1.31E+02	217.0
Z-2	6.49E+01	6.49E+01	1.39E+01	1.79E+02	258.1
Z-3	8.02E+01	8.02E+01	1.28E+01	2.40E+02	332.8
Z-4	1.75E+02	1.75E+02	1.67E+02	1.02E+03	1381.1
Z-5	6.81E+01	6.81E+01	1.25E+01	2.05E+02	285.1
Z-6	3.96E+01	3.96E+01	9.04E-02	.00E+00	39.7
Z-7	6.55E+01	6.55E+01	1.11E+01	2.85E+02	361.8
Z-8	7.18E+01	7.18E+01	9.52E+00	3.82E+02	463.0
Z-9	7.71E+01	7.71E+01	1.43E+01	1.71E+02	262.0
Z-10	7.36E+01	7.36E+01	1.41E+00	1.44E+03	1519.4
Z-11	2.20E+02	2.20E+02	1.98E+02	.00E+00	418.6

SITE B PERSONNEL DOSIMETERS 9/18 TO 11/29/76

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MR
A-1	3.37E+01	3.37E+01	7.92E-02	.00E+00	33.8
B-1	3.30E+01	3.30E+01	1.40E-01	.00E+00	33.2
B-2	2.73E+01	2.73E+01	1.76E-01	.00E+00	27.5
B-4	2.77E+01	2.77E+01	3.19E-02	.00E+00	27.7
B-5	3.40E+01	3.40E+01	1.33E-01	.00E+00	34.1
B-6	3.31E+01	3.31E+01	7.64E-02	.00E+00	33.2
C-1	3.22E+01	3.22E+01	1.75E-01	.00E+00	32.4
C-2	3.27E+01	3.27E+01	1.89E-01	.00E+00	32.9
C-3	3.68E+01	3.68E+01	1.21E-01	.00E+00	36.9
C-4	3.19E+01	3.19E+01	1.03E-01	.00E+00	32.0
D-1	2.95E+01	2.95E+01	1.39E-01	.00E+00	29.7
D-2	3.10E+01	3.10E+01	1.99E-01	.00E+00	31.2
D-3	6.17E+01	6.17E+01	1.79E-01	.00E+00	61.8
D-4	5.87E+01	5.87E+01	1.72E-01	.00E+00	58.9
D-5	3.98E+01	3.98E+01	1.07E-01	.00E+00	39.9
D-6	3.05E+01	3.05E+01	9.44E-02	.00E+00	30.6
E-1	4.94E+01	4.94E+01	1.31E-01	.00E+00	49.5
F-1	3.74E+01	3.74E+01	1.47E-01	.00E+00	37.5
G-2	3.01E+01	3.01E+01	1.44E-01	.00E+00	30.3
G-3	2.75E+01	2.75E+01	1.39E-01	.00E+00	27.6
H-2	3.39E+01	3.39E+01	1.42E-01	.00E+00	34.0
H-3	3.67E+01	3.67E+01	1.40E-01	.00E+00	36.8
H-4	3.21E+01	3.21E+01	7.22E-02	.00E+00	32.2
H-5	3.22E+01	3.22E+01	1.33E-01	.00E+00	32.4
J	3.40E+01	3.40E+01	4.44E-02	.00E+00	34.0
J-1	3.10E+01	3.10E+01	1.12E-01	.00E+00	31.1
K-1	4.91E+01	4.91E+01	1.76E-01	.00E+00	49.3
K-2	2.93E+01	2.93E+01	1.31E-01	.00E+00	29.4
K-3	3.68E+01	3.68E+01	1.35E-01	.00E+00	36.9
K-4	3.22E+01	3.22E+01	2.17E-01	.00E+00	32.5
L-1	5.43E+01	5.43E+01	1.75E-01	.00E+00	54.5
L-2	4.09E+01	4.09E+01	2.43E-01	.00E+00	41.1
L-3	3.10E+01	3.10E+01	6.53E-02	2.15E+00	33.2
L-4	3.30E+01	3.30E+01	2.18E-01	.00E+00	33.2
L-5	2.99E+01	2.99E+01	1.10E-01	.00E+00	30.0
L-6	3.66E+01	3.66E+01	1.12E-01	.00E+00	36.7
M-1	3.75E+01	3.75E+01	8.89E-02	.00E+00	37.6
M-2	3.42E+01	3.42E+01	1.57E-01	.00E+00	34.3
M-3	2.89E+01	2.89E+01	2.11E-01	.00E+00	29.1
M-4	3.53E+01	3.53E+01	6.81E-02	.00E+00	35.3
M-5	3.21E+01	3.21E+01	9.31E-02	.00E+00	32.2
P-2	3.19E+01	3.19E+01	1.04E-01	.00E+00	32.0
R-1	6.89E+01	6.89E+01	1.22E-01	.00E+00	69.1
R-2	3.71E+01	3.71E+01	1.43E-01	.00E+00	37.3
S-1	3.24E+01	3.24E+01	6.39E-02	.00E+00	32.4
S-2	3.15E+01	3.15E+01	3.00E-01	.00E+00	31.8
S-3	2.58E+01	2.58E+01	1.32E-01	.00E+00	25.9

SITE B PERSONNEL DOSIMETERS - 9/18 TO 11/29/76

S-4	4.26E+01	4.26E+01	1.12E-01	.00E+00	42.8
W-1	3.27E+01	3.27E+01	1.22E-01	.00E+00	32.8
W-2	3.48E+01	3.48E+01	1.74E-01	.00E+00	35.0
505-1	1.69E+02	1.69E+02	1.28E-01	3.73E+00	172.4
507-1	4.28E+02	4.28E+02	6.74E+00	1.40E+02	574.7
510-1	1.40E+02	1.40E+02	2.72E-01	.00E+00	140.0
516-1	1.59E+03	1.59E+03	9.29E+01	3.78E+02	2059.0
518-1	4.00E+02	4.00E+02	4.31E-01	2.30E+02	630.3
519-1	8.25E+01	8.25E+01	1.53E-01	.00E+00	82.6
520-1	5.66E+02	5.66E+02	5.40E-01	.00E+00	566.2
609-1	2.43E+02	2.43E+02	.00E+00	2.10E+01	263.7
616-1	3.96E+02	3.96E+02	.00E+00	5.25E+01	443.7
643-1	8.46E+01	8.46E+01	2.32E-01	.00E+00	84.6
645-1	9.71E+01	9.71E+01	.00E+00	1.43E+01	111.3
646-1	1.78E+02	1.78E+02	2.92E-02	1.54E+01	193.7
TLD-1	2.76E+01	2.76E+01	9.03E-02	.00E+00	27.7
CO-1	2.54E+01	2.54E+01	1.39E-01	.00E+00	25.6
CO-2	2.52E+01	2.52E+01	8.33E-02	.00E+00	25.3
CH-1	3.13E+01	3.13E+01	1.58E-01	.00E+00	31.4
CH-2	2.86E+01	2.86E+01	2.36E-01	.00E+00	28.3
CNTRL	2.53E+01	2.53E+01	1.31E-01	.00E+00	25.4
CNTRL	2.53E+01	2.53E+01	1.17E-01	.00E+00	25.4
CNTRL	2.50E+01	2.50E+01	1.10E-01	.00E+00	25.

SITE B PERSONNEL DOSIMETERS 11/29/76 TO 2/14/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
A-1	3.06E+01	3.06E+01	1.98E-01	.00E+00	30.8
A-2	4.01E+01	4.01E+01	2.28E-01	.00E+00	40.3
B-1	2.94E+01	2.94E+01	1.36E-01	.00E+00	29.5
B-3	2.96E+01	2.96E+01	9.14E-02	.00E+00	29.7
B-5	2.77E+01	2.77E+01	1.55E-01	.00E+00	27.9
C-1	2.87E+01	2.87E+01	1.57E-01	.00E+00	28.9
C-2	3.00E+01	3.00E+01	1.81E-01	.00E+00	30.2
C-3	3.30E+01	3.30E+01	1.03E-01	.00E+00	33.1
C-4	2.77E+01	2.77E+01	1.86E-01	.00E+00	27.9
D-3	4.00E+01	4.00E+01	6.38E-02	.00E+00	40.1
D-4	4.76E+01	4.76E+01	2.62E-01	.00E+00	47.8
D-5	3.07E+01	3.07E+01	1.26E-01	.00E+00	30.9
D-6	3.41E+01	3.41E+01	1.41E-01	.00E+00	34.2
E-1	2.91E+01	2.91E+01	1.26E-01	.00E+00	29.2
F-1	2.94E+01	2.94E+01	2.00E-01	.00E+00	29.6
G-1	3.02E+01	3.02E+01	1.93E-01	.00E+00	30.4
G-3	3.01E+01	3.01E+01	1.67E-01	.00E+00	30.3
H-2	2.64E+01	2.64E+01	8.79E-02	.00E+00	26.5
H-3	2.92E+01	2.92E+01	2.17E-01	.00E+00	29.4
H-4	2.64E+01	2.64E+01	8.28E-02	.00E+00	26.5
H-5	3.03E+01	3.03E+01	5.69E-02	.00E+00	30.3
J-1	2.56E+01	2.56E+01	1.84E-01	.00E+00	25.8
J-2	2.62E+01	2.62E+01	1.81E-01	.00E+00	26.4
K-1	3.46E+01	3.46E+01	1.03E-01	.00E+00	34.7
K-3	2.77E+01	2.77E+01	1.19E-01	.00E+00	27.8
K-4	3.07E+01	3.07E+01	1.55E-01	.00E+00	30.9
K-5	4.85E+01	4.85E+01	4.14E-02	.00E+00	48.6
L-1	3.57E+01	3.57E+01	1.72E-02	.00E+00	35.7
L-2	3.54E+01	3.54E+01	1.60E-01	.00E+00	35.6
L-3	2.83E+01	2.83E+01	8.28E-02	.00E+00	28.4
L-4	3.02E+01	3.02E+01	1.16E-01	.00E+00	30.3
L-6	2.88E+01	2.88E+01	1.38E-01	.00E+00	28.9
M-1	3.17E+01	3.17E+01	1.29E-01	.00E+00	31.9
M-2	2.49E+01	2.49E+01	9.14E-02	.00E+00	25.0
M-3	5.99E+01	5.99E+01	1.74E-01	.00E+00	60.0
M-4	2.64E+01	2.64E+01	7.24E-02	.00E+00	26.5
M-5	2.81E+01	2.81E+01	1.24E-01	.00E+00	28.2
P-1	3.59E+01	3.59E+01	8.45E-02	.00E+00	36.0
P-2	2.85E+01	2.85E+01	1.33E-01	.00E+00	28.6

SITE B PERSONNEL DOSIMETERS - 11/29/76 TO 2/14/77

P-3'	2.79E+01	2.79E+01	5.86E-02	.00E+00	27.7
R-1	5.04E+01	5.04E+01	.00E+00	9.87E-01	51.4
R-2	2.87E+01	2.87E+01	9.31E-02	.00E+00	28.8
S-1	2.93E+01	2.93E+01	1.60E-01	.00E+00	29.5
S-2	2.86E+01	2.86E+01	2.19E-01	.00E+00	28.8
S-3	2.78E+01	2.78E+01	9.66E-02	.00E+00	27.9
S-4	3.10E+01	3.10E+01	2.26E-01	.00E+00	31.2
T-2	6.34E+01	6.34E+01	1.79E-01	.00E+00	63.6
W-1	2.64E+01	2.64E+01	1.21E-01	.00E+00	26.5
W-2	3.50E+01	3.50E+01	1.55E-01	.00E+00	35.1
505	1.80E+02	1.80E+02	9.66E-02	.00E+00	180.5
507	1.29E+02	1.29E+02	1.56E+01	4.52E+02	596.6
518	1.73E+02	1.73E+02	4.73E+00	2.30E+02	457.6
519	8.98E+01	8.98E+01	7.00E-01	8.55E+00	97.1
520	4.75E+02	4.75E+02	5.53E-01	.00E+00	475.2
516	5.74E+02	5.74E+02	1.53E+00	1.79E+02	754.6
609	2.40E+02	2.40E+02	2.29E-01	.00E+00	239.7
616	2.79E+02	2.79E+02	8.62E-03	5.69E+00	284.5
643	1.78E+02	1.78E+02	3.64E-01	.00E+00	178.1
645	2.09E+02	2.10E+02	4.00E-01	.00E+00	209.7
646	2.30E+02	2.32E+02	.00E+00	7.80E+01	308.3
CONT1	2.22E+01	2.22E+01	1.31E-01	.00E+00	22.3
CONT2	2.31E+01	2.31E+01	9.14E-02	.00E+00	23.2
CONT3	2.35E+01	2.35E+01	1.45E-01	.00E+00	23.5
CONT4	2.49E+01	2.49E+01	1.55E-02	1.21E+00	26.2
TLD-1	2.46E+01	2.46E+01	1.53E-01	.00E+00	24.7
TLD-2	2.36E+01	2.36E+01	1.14E-01	.00E+00	23.7
CH-1	2.44E+01	2.44E+01	6.21E-02	.00E+00	24.5
CH-2	2.42E+01	2.42E+01	1.43E-01	.00E+00	24.3

SITE B PERSONNEL DOSIMETERS 2-14 TO 4-8-77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
A-1	3.87E+01	3.87E+01	6.51E-02	.00E+00	38.8
B-1	2.81E+01	2.81E+01	7.53E-02	.00E+00	28.1
B-3	6.25E+01	6.25E+01	2.77E-01	.00E+00	62.8
B-5	3.22E+01	3.22E+01	1.04E-01	.00E+00	32.3
C-1	2.88E+01	2.88E+01	1.25E-01	.00E+00	28.9
C-2	2.87E+01	2.87E+01	5.31E-02	.00E+00	28.7
C-3	2.69E+01	2.69E+01	8.22E-02	.00E+00	27.0
C-4	3.21E+01	3.21E+01	.00E+00	3.16E+00	35.3
D-3	6.21E+01	6.21E+01	8.56E-02	.00E+00	62.2
D-4	7.13E+01	7.13E+01	.00E+00	3.35E+00	74.6
D-5	3.79E+01	3.79E+01	2.14E-01	.00E+00	38.1
D-6	3.18E+01	3.18E+01	1.32E-01	.00E+00	31.9
E-1	4.36E+01	4.36E+01	2.09E-01	.00E+00	43.8
F-1	3.90E+01	3.90E+01	1.56E-01	.00E+00	39.2
G-3	3.45E+01	4.07E+01	2.05E-01	.00E+00	34.7
H-2	3.58E+01	3.58E+01	8.39E-02	.00E+00	35.9
H-3	3.86E+01	3.86E+01	8.05E-02	.00E+00	38.7
H-4	3.53E+01	3.53E+01	1.10E-01	.00E+00	35.4
H-5	4.15E+01	4.15E+01	.00E+00	6.99E-01	42.2
J-1	3.62E+01	3.62E+01	2.57E-02	.00E+00	36.2
K-1	5.71E+01	5.71E+01	2.74E-02	.00E+00	57.1
K-3	3.81E+01	3.81E+01	5.14E-02	.00E+00	38.1
K-4	3.41E+01	3.41E+01	1.32E-01	.00E+00	34.3
K-5	3.36E+01	3.36E+01	3.41E-01	.00E+00	33.9
L-1	2.94E+01	2.94E+01	7.71E-02	.00E+00	29.5
L-2	3.51E+01	3.51E+01	7.02E-02	.00E+00	35.1
L-3	2.53E+01	2.53E+01	1.11E-01	.00E+00	25.4
L-4	2.74E+01	2.74E+01	3.25E-02	.00E+00	27.4
L-6	3.21E+01	3.21E+01	1.59E-01	.00E+00	32.3
M-1	3.49E+01	3.49E+01	7.02E-02	.00E+00	35.0
M-2	3.29E+01	3.29E+01	.00E+00	9.16E-01	33.8
M-3	2.60E+01	2.60E+01	1.80E-01	.00E+00	26.2
M-4	3.06E+01	3.06E+01	5.14E-02	.00E+00	30.7
M-5	2.92E+01	2.92E+01	1.04E-01	.00E+00	29.3
P-1	4.27E+01	4.27E+01	1.66E-01	.00E+00	42.8

SITE B PERSONNEL DOSIMETERS - 2/14 TO 4/8/77

P-2	3.03E+01	3.03E+01	8.39E-02	.00E+00	30.4
P-3	2.43E+01	2.43E+01	1.51E-01	.00E+00	24.5
R-1	5.84E+01	5.84E+01	1.11E-01	.00E+00	58.5
R-2	3.32E+01	3.32E+01	1.08E-01	.00E+00	33.3
S-1	3.36E+01	3.36E+01	1.11E-01	.00E+00	33.7
S-2	3.09E+01	3.09E+01	1.23E-01	.00E+00	31.0
S-3	2.35E+01	2.35E+01	1.20E-01	.00E+00	23.6
W-1	2.91E+01	2.91E+01	1.01E-01	.00E+00	29.2
W-2	3.00E+01	3.00E+01	3.77E-02	6.72E-01	30.7
505	4.71E+02	4.71E+02	3.39E-01	.00E+00	471.1
507	2.04E+02	2.04E+02	3.10E-01	.00E+00	204.3
516	9.46E+02	9.46E+02	2.91E-02	3.39E+01	979.9
518	5.64E+02	5.64E+02	1.04E-01	7.68E+01	640.6
519	8.95E+01	8.95E+01	3.92E-01	.00E+00	89.9
520	9.48E+02	9.48E+02	1.64E+00	.00E+00	949.5
609	3.41E+02	3.41E+02	1.37E-01	.00E+00	340.8
616	4.65E+02	4.65E+02	.00E+00	2.94E+01	494.0
643	1.25E+03	1.25E+03	.00E+00	1.57E+02	1402.4
645	4.23E+02	4.38E+02	2.47E-01	.00E+00	423.3
646	3.38E+02	3.38E+02	1.44E-01	.00E+00	337.7
TLD-1	2.24E+01	2.24E+01	1.03E-01	.00E+00	22.5
TLD-2	2.42E+01	2.42E+01	1.52E-01	.00E+00	24.3
RGC-1	2.23E+01	2.23E+01	1.58E-01	.00E+00	22.3
RGC-2	2.26E+01	2.26E+01	1.35E-01	.00E+00	22.6
HP-1	2.71E+01	2.71E+01	9.76E-02	.00E+00	27.2
HP-2	2.91E+01	2.91E+01	1.10E-01	.00E+00	29.2
C-1	2.28E+01	2.28E+01	1.06E-01	.00E+00	22.9
C-2	2.21E+01	2.21E+01	9.59E-02	.00E+00	22.2
C-3	2.29E+01	2.29E+01	9.08E-02	.00E+00	23.0
C-4	2.24E+01	2.24E+01	1.20E-01	.00E+00	22.5

SITE B, PERSONNEL DOSIMETERS 4/4 TO 6/8/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
#A1	4.46E+01	4.46E+01	1.62E-01	.00E+00	44.7
#B1	4.44E+01	4.44E+01	1.76E-01	.00E+00	44.5
#B2	3.96E+01	3.96E+01	8.80E-02	.00E+00	39.7
#B3	3.44E+01	3.44E+01	1.64E-01	.00E+00	34.6
#C1	2.23E+02	2.23E+02	4.88E-01	.00E+00	223.8
#C2	4.52E+01	4.52E+01	2.66E-01	.00E+00	45.5
#C2	3.31E+01	3.31E+01	1.44E-01	.00E+00	33.2
#C3	3.58E+01	3.58E+01	7.40E-02	.00E+00	35.8
#C4	4.08E+01	4.08E+01	1.08E-01	3.29E+00	44.2
#D1	4.61E+01	4.61E+01	1.48E-01	.00E+00	46.2
#D2	4.27E+01	4.27E+01	2.42E-01	.00E+00	43.0
#D5	5.11E+01	5.90E+01	1.76E-01	.00E+00	51.2
#D6	6.96E+01	6.96E+01	3.20E-02	5.55E+00	75.2
#D7	4.78E+01	4.78E+01	2.82E-01	.00E+00	48.1
#E1	4.79E+01	4.79E+01	2.00E-02	4.28E+00	52.2
#F1	4.59E+01	4.59E+01	5.40E-02	1.80E+00	47.8
#F2	2.11E+02	2.11E+02	1.04E+01	.00E+00	221.2
#F3	1.42E+02	1.42E+02	.00E+00	7.86E+00	149.8
#G1	7.57E+01	7.57E+01	3.51E+00	1.27E+01	92.0
#G2	3.54E+01	3.54E+01	1.54E-01	.00E+00	35.5
#H1	4.56E+01	4.56E+01	2.04E-01	.00E+00	45.8
#H2	3.73E+01	3.73E+01	.00E+00	6.09E+00	43.3
#J1	3.49E+01	3.49E+01	.00E+00	2.40E+00	37.3
#J	5.14E+01	5.14E+01	6.00E-02	6.55E+00	58.0
#K2	4.33E+01	4.33E+01	8.60E-02	2.11E+00	45.5
#K3	3.33E+01	3.33E+01	2.24E-01	.00E+00	33.5
#L1	4.42E+01	4.42E+01	2.30E-01	.00E+00	44.4
#L2	4.01E+01	4.01E+01	2.24E-01	.00E+00	40.3
#L3	3.43E+01	3.43E+01	1.54E-01	.00E+00	34.4
#L4	4.03E+01	4.03E+01	4.86E-01	.00E+00	40.8
#M1	3.80E+01	3.80E+01	1.44E-01	.00E+00	38.2
#M2	4.36E+01	4.36E+01	5.80E-02	2.87E+00	46.5
#N	6.11E+01	6.11E+01	5.42E+00	2.76E+01	94.0
#M4	4.59E+01	4.59E+01	1.52E-01	.00E+00	46.1
#M5	4.14E+01	4.14E+01	3.10E-01	.00E+00	41.7
#M6	4.08E+01	4.08E+01	1.50E-01	.00E+00	40.9
#M7	7.27E+02	7.27E+02	1.92E+00	.00E+00	729.3
#N1	1.75E+02	1.75E+02	6.50E-01	.00E+00	175.9
#P1	4.00E+01	4.00E+01	1.88E-01	.00E+00	40.2
#P2	3.72E+01	3.72E+01	4.60E-02	9.51E+00	46.7
#R1	3.70E+01	3.70E+01	.00E+00	7.33E+00	44.4
#S1	4.57E+01	4.57E+01	6.40E-02	2.57E+00	48.3
#S2	5.01E+01	5.01E+01	1.50E-01	2.67E+00	52.9
#S3	4.20E+01	4.20E+01	1.52E-01	.00E+00	42.2
#S4	1.20E+02	1.25E+02	1.26E-01	1.26E+01	133.2
#S5	1.08E+02	1.08E+02	2.26E-01	.00E+00	107.9
#S6	3.94E+01	3.94E+01	2.80E-01	.00E+00	39.7
#T1	3.39E+01	3.39E+01	1.90E-01	.00E+00	34.1

SITE B PERSONNEL DOSIMETERS - 4/4 TO 6/8/77 (cont'd)

#T3	1.55E+02	1.55E+02	2.30E-01	.00E+00	154.9
#RC*	3.08E+01	3.08E+01	1.40E-01	.00E+00	31.0
#RC2*	3.01E+01	3.01E+01	1.34E-01	.00E+00	30.2
#W1	3.96E+01	3.96E+01	7.80E-02	.00E+00	39.7
#W2	4.01E+01	4.01E+01	2.46E-01	.00E+00	40.4
#Z1	1.22E+02	1.22E+02	2.98E-01	.00E+00	122.5
#T01	2.88E+01	2.88E+01	2.12E-01	.00E+00	29.0
#T02	2.85E+01	2.85E+01	2.14E-01	.00E+00	28.7
#HP1	2.63E+01	2.63E+01	2.04E-01	.00E+00	26.5
#HP2	2.66E+01	2.66E+01	1.46E-01	.00E+00	26.8
#NU1	2.77E+01	2.77E+01	6.20E-02	3.18E+00	31.0
#NU2	2.99E+01	2.99E+01	2.82E-01	.00E+00	30.2
#NU3	2.96E+01	2.96E+01	2.34E-01	.00E+00	29.8

SITE B PERSONNEL DOSIMETERS 6/8 TO 9/1/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
A-1	3.83E+01	3.83E+01	.00E+00	1.08E+01	49.1
B-1	3.58E+01	3.58E+01	1.80E-01	.00E+00	36.0
B-3	3.69E+01	3.69E+01	1.50E-01	.00E+00	37.0
B-5	3.67E+01	3.67E+01	1.83E-01	.00E+00	36.9
C-1	3.64E+01	3.64E+01	1.27E-01	.00E+00	36.5
C-2	3.50E+01	3.50E+01	2.07E-01	.00E+00	35.2
C-3	4.65E+01	4.65E+01	1.13E-01	.00E+00	46.6
C-4	3.63E+01	3.63E+01	1.21E-01	.00E+00	36.4
C-5	2.51E+02	2.51E+02	6.90E-01	6.29E+01	314.6
D-2	4.19E+01	4.19E+01	1.03E-01	.00E+00	42.0
D-4	6.09E+01	6.09E+01	1.07E-01	.00E+00	61.0
D-5	4.66E+01	4.66E+01	2.81E-01	.00E+00	46.9
D-6	3.98E+01	3.98E+01	2.85E-01	.00E+00	40.1
E-1	4.00E+01	4.00E+01	2.04E-01	.00E+00	40.3
F-1	4.03E+01	4.03E+01	2.46E-01	.00E+00	40.6
G-3	4.01E+01	4.01E+01	8.93E-02	.00E+00	40.2
H-2	4.86E+01	4.86E+01	1.80E-01	.00E+00	48.8
K-1	5.27E+01	5.27E+01	1.88E-01	.00E+00	52.9
K-3	4.23E+01	4.23E+01	2.99E-01	.00E+00	42.6
L-1	3.88E+01	3.88E+01	1.59E-01	.00E+00	39.0
L-4	4.21E+01	4.21E+01	2.43E-01	.00E+00	42.4
L-6	4.09E+01	4.09E+01	2.07E-01	.00E+00	41.1
M-1	4.02E+01	4.02E+01	2.32E-01	.00E+00	40.4
M-3	4.33E+01	4.33E+01	2.55E-01	.00E+00	43.5
M-5	3.44E+01	3.44E+01	1.93E-01	.00E+00	34.8
P-2	4.19E+01	4.19E+01	2.24E-01	.00E+00	42.1
P-3	4.29E+01	4.45E+01	1.21E-01	.00E+00	43.1
R-1	4.13E+01	4.13E+01	1.30E-01	.00E+00	41.4
R-2	4.13E+01	4.13E+01	2.87E-01	.00E+00	41.6
S-1	4.65E+01	4.65E+01	1.88E-01	.00E+00	46.7
S-2	2.16E+01	2.16E+01	2.30E-01	.00E+00	21.9
S-3	5.41E+01	5.41E+01	2.21E-01	.00E+00	54.3
T-1	4.65E+01	4.65E+01	1.39E-01	.00E+00	46.6
T-2	4.17E+01	4.17E+01	2.16E-01	.00E+00	41.9
W-1	3.84E+01	3.84E+01	2.52E-01	.00E+00	38.7
W-2	4.32E+01	4.32E+01	2.79E-01	.00E+00	43.5
506	1.65E+02	1.65E+02	4.73E-01	.00E+00	165.4
507	1.42E+02	1.42E+02	4.45E+01	1.43E+03	1621.8
516	1.39E+02	1.39E+02	1.50E+00	5.37E+01	194.3
518	1.39E+02	1.39E+02	5.60E+01	4.67E+02	661.7
519	2.42E+02	2.42E+02	1.76E+02	7.71E+02	1189.7
520	4.51E+02	4.51E+02	4.72E+01	1.06E+02	604.3

SITE B PERSONNEL DOSIMETERS - 6/8 TO 9/1/77 (cont'd)

609	1.36E+02	1.36E+02	4.12E-01	.00E+00	136.1
643	1.31E+02	1.31E+02	4.92E-01	.00E+00	131.9
645	1.43E+02	1.43E+02	6.27E-02	.00E+00	142.9
646	3.60E+02	3.60E+02	7.35E-01	.00E+00	361.0
X-1	3.97E+01	3.97E+01	1.25E-01	.00E+00	39.8
X-2	3.59E+01	3.59E+01	1.19E-01	.00E+00	36.0
X-3	4.01E+01	4.01E+01	1.25E-01	.00E+00	40.2
X-4	3.59E+01	3.59E+01	1.35E-01	.00E+00	36.0
X-5	4.13E+01	4.13E+01	2.54E-01	.00E+00	41.5
RGC-1	3.44E+01	3.44E+01	2.19E-01	.00E+00	34.3
RGC-2	3.41E+01	3.41E+01	2.04E-01	.00E+00	34.3
RGC-4	3.48E+01	3.48E+01	3.48E-01	.00E+00	35.2
HP-1	1.83E+01	1.83E+01	2.38E-01	.00E+00	18.5
HP-2	1.73E+01	1.73E+01	3.03E-01	.00E+00	17.6
TLD-R	3.16E+01	3.16E+01	2.26E-01	.00E+00	31.9
TLD-R	3.13E+01	3.13E+01	2.18E-01	.00E+00	31.5
CONT6	3.47E+01	3.47E+01	1.79E-01	.00E+00	34.9
CONT6	3.14E+01	3.14E+01	2.68E-01	.00E+00	31.6
CONT6	3.25E+01	3.25E+01	1.29E-01	.00E+00	32.6

SITE B PERSONNEL DOSIMETERS 9/1 TO 9/10 TO 11/1/77

L.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MRE
A-1	3.45E+01	3.45E+01	4.30E-02	5.25E+00	39.6
A-2	2.28E+01	2.28E+01	1.50E-01	.00E+00	23.0
B-1	2.94E+01	2.94E+01	1.63E-01	1.58E+00	31.2
B-2	3.49E+01	3.49E+01	2.61E-01	.00E+00	33.1
B-3	2.99E+01	2.99E+01	2.08E-01	.00E+00	30.1
C-1	1.37E+02	1.37E+02	9.50E-02	.00E+00	137.0
C-2	2.70E+01	2.70E+01	2.03E-01	.00E+00	27.2
C-3	2.90E+01	2.90E+01	1.11E-01	1.32E-01	29.3
C-4	2.94E+01	2.94E+01	1.34E-01	.00E+00	29.6
D-1	3.13E+01	3.13E+01	1.78E-01	.00E+00	31.4
D-2	2.75E+01	2.75E+01	1.61E-01	.00E+00	27.7
D-3	4.24E+01	4.24E+01	2.66E-01	.00E+00	42.7
D-4	2.95E+01	2.95E+01	1.23E-01	.00E+00	29.6
E-1	3.19E+01	3.19E+01	1.87E-01	.00E+00	32.1
F-1	3.28E+01	3.28E+01	7.86E-02	1.32E+00	34.7
F-2	3.73E+01	3.73E+01	3.07E-01	5.37E+00	43.0
G-1	9.79E+01	9.79E+01	2.54E-01	1.77E+00	99.9
G-3	2.66E+01	2.66E+01	1.77E-01	.00E+00	26.6
K-1	3.97E+01	3.97E+01	1.72E-01	.00E+00	39.9
K-3	3.17E+01	3.17E+01	1.59E-01	.00E+00	31.8
L-1	2.94E+01	2.94E+01	9.05E-02	1.50E+00	31.0
L-4	3.32E+01	3.32E+01	4.75E-02	1.71E-01	33.1
L-6	2.73E+01	2.73E+01	1.16E-01	2.10E+00	29.6
M-1	3.00E+01	3.00E+01	.00E+00	8.25E+00	38.3
M-2	2.97E+01	2.97E+01	2.33E-01	.00E+00	30.0
M-5	2.85E+01	2.85E+01	1.68E-01	.00E+00	28.7
P-3	3.71E+01	3.71E+01	1.32E-01	.00E+00	37.3
R-1	3.05E+01	3.05E+01	2.30E-01	.00E+00	30.7
R-2	2.94E+01	2.94E+01	1.72E-01	.00E+00	29.6
S-3	5.13E+01	5.13E+01	1.10E-01	.00E+00	51.4
S-4	3.68E+01	3.68E+01	6.82E-02	5.07E+00	42.0
T-2-1	3.11E+01	3.11E+01	2.26E-01	.00E+00	31.4
U-1	2.66E+01	2.66E+01	7.37E-02	4.30E+00	35.6
W-2	3.23E+01	3.23E+01	2.06E-01	.00E+00	32.3
505	8.52E+01	8.52E+01	2.28E-01	2.19E-01	85.7
507	3.15E+01	3.15E+01	3.93E-01	7.96E+00	39.9
519	1.29E+02	1.29E+02	3.13E+01	7.59E+02	919.6
520	2.52E+02	2.52E+02	2.43E+00	.00E+00	254.0
609	7.69E+01	7.69E+01	1.04E-01	.00E+00	77.0
643	5.35E+01	5.35E+01	1.41E-01	.00E+00	53.6
645	6.12E+01	6.12E+01	3.74E-01	.00E+00	61.3
646	2.53E+02	2.53E+02	.00E+00	2.63E+01	231.1
HPSO	2.56E+01	2.56E+01	2.02E-01	.00E+00	25.6
HPSO	2.52E+01	2.52E+01	2.51E-01	.00E+00	25.2
HPSH	2.52E+01	2.52E+01	1.26E-01	.00E+00	25.2
HPSH	2.56E+01	2.56E+01	9.05E-02	2.75E+00	26.4
EXTRA	2.49E+01	2.49E+01	9.20E-02	.00E+00	25.0
EXTRA	2.39E+01	2.39E+01	2.66E-01	.00E+00	24.2
EXTRA	2.38E+01	2.38E+01	1.44E-01	.00E+00	23.9

APPENIIX E - SITE C DATA

SITE C - OFFSITE CONTROL, CYCLES 1-6 (LiF - Bare)

SITE C - ONSITE CONTROL, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 1, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 2, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 3, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 4, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 5, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 6, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 7, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 9, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 10, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 11, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 12, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 13, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 12, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 13, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 14, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 15, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 16, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 17, CYCLES 1-6 (LiF - Bare)

SITE C - STATION 18, CYCLES 1-6 (LiF - Bare)

SITE C - OFFSITE CONTROLS, CYCLES 1-6

SITE C - ONSITE CONTROLS, CYCLES 1-6

SITE C - MAIN OFFICE, CYCLES 1-6

SITE C - LABORERS - CYCLES 1-6

SITE C - CARPENTERS - CYCLES 1-6

SITE C - OPERATORS - CYCLES 1-6

SITE C - AREA 1&2 OFFICE - CYCLES 1-6

SITE C - TEAMSTERS, CYCLES 1-6

SITE C - IRONWORKERS, CYCLES 1-6

SITE C - SUPERVISORS, CYCLES 1-6

SITE C - AREA FIELD, CYCLES 1-6

SITE C - QC FIELD, CYCLES 1-6

SITE C ENVIRONMENTAL DOSIMETERS 4/12 TO 7/12/77

I.D.#	700B	800B	700F	800F	400F
#1	3.94E+01	1.66E-01	3.57E+01	2.00E-01	3.17E+01
#2	4.73E+01	1.68E-01	3.81E+01	1.76E-01	3.59E+01
#3	4.08E+01	1.49E-01	3.73E+01	1.93E-01	3.12E+01
#4	4.21E+02	5.31E-01	4.30E+02	1.68E-01	3.62E+02
#6	3.63E+01	1.65E-01	3.50E+01	1.25E-01	2.91E+01
#7	5.17E+01	1.74E-01	4.92E+01	1.63E-01	4.20E+01
#8	3.49E+01	1.60E-01	3.35E+01	1.37E-01	2.97E+01
#9	3.40E+01	1.63E-01	3.17E+01	1.71E-01	2.73E+01
#10	4.83E+01	1.97E-01	4.59E+01	2.17E-01	3.98E+01
#11	3.79E+01	1.63E-01	3.42E+01	2.54E-01	3.19E+01
#12	3.34E+01	1.69E-01	3.91E+01	1.78E-02	2.51E+01
#13	3.60E+01	1.92E-01	3.48E+01	2.00E-01	3.08E+01
#14	3.43E+01	1.80E-01	3.27E+01	1.54E-01	2.79E+01
#15	3.44E+01	1.60E-01	3.29E+01	1.73E-01	2.91E+01
#16	4.04E+01	1.72E-01	3.66E+01	1.79E-01	3.30E+01
#17	3.58E+01	1.88E-01	3.45E+01	1.68E-01	2.90E+01
#18	3.98E+01	1.84E-01	3.71E+01	1.77E-01	3.31E+01
#19	3.01E+01	1.46E-01	2.78E+01	1.74E-01	2.43E+01
#20	3.75E+01	1.43E-01	3.34E+01	1.98E-01	2.93E+01

SITE C ENVIRONMENTAL DOSIMETERS 7/12 TO 10/20/77

I.D.#	700B	800B	700F	800F	400F
#1	4.99E+01	1.09E-01	4.19E+01	2.48E-01	4.75E+01
#2	7.10E+01	1.17E-01	4.31E+01	1.14E-01	5.36E+01
#3	5.33E+01	6.76E-02	4.32E+01	1.19E-01	4.62E+01
#4	5.10E+02	1.07E+00	4.28E+02	1.02E+00	4.62E+02
#5	4.93E+01	1.10E+03	4.05E+01	1.36E-01	4.36E+01
#6	4.75E+01	3.58E-02	4.16E+01	1.01E-01	4.62E+01
#7	5.05E+01	7.92E-02	4.08E+01	7.32E-02	4.34E+01
#8	4.60E+01	8.34E-02	3.91E+01	1.67E-01	4.36E+01
#9	4.44E+01	1.45E-01	3.72E+01	3.38E-01	4.14E+01
#10	5.61E+01	7.73E-02	4.38E+01	1.39E-01	5.14E+01
#11	5.37E+01	2.13E-02	5.00E+01	.00E+00	4.85E+01
#12	4.64E+01	2.16E-01	3.90E+01	2.37E-01	4.28E+01
#13	4.59E+01	1.22E-01	4.11E+01	1.24E-01	4.17E+01
#14	4.52E+01	9.09E-02	3.93E+01	1.77E-01	4.45E+01
#15	4.43E+01	4.30E-02	3.48E+01	1.40E-01	4.25E+01
#16	5.11E+01	1.71E-01	4.24E+01	2.07E-01	4.70E+01
#17	4.46E+01	8.63E-02	3.91E+01	8.67E-02	4.21E+01
#18	4.96E+01	1.19E-01	4.15E+01	1.16E-01	4.64E+01
#19	2.89E+01	1.34E-01	2.37E+01	1.99E-01	2.59E+01
#20	3.71E+01	8.50E-02	3.26E+01	1.43E-01	3.75E+01

SITE C ENVIRONMENTAL DOSIMETERS 6/2 TO 10/20/76

I.D.#	700B	600B	700F	600F	400F
STA#1	7.49E+01	1.53E-01	6.02E+01	2.23E-01	6.79E+01
STA#16	7.62E+01	8.55E-02	6.32E+01	1.54E-01	6.54E+01
STA#4	5.61E+02	1.14E+00	4.82E+02	1.87E-01	5.49E+02
STA#3	7.91E+01	7.00E-02	6.66E+01	1.21E-01	7.40E+01
STA#2	8.53E+01	7.76E-02	7.37E+01	6.75E-02	7.85E+01
STA#17	7.11E+01	.00E+00	5.88E+01	6.31E-03	6.08E+01
STA#14	6.71E+01	1.42E-01	5.87E+01	6.31E-03	6.29E+01
STA#10	9.46E+01	1.71E-01	8.06E+01	5.06E-01	9.33E+01
STA#7	8.50E+01	1.10E-01	6.22E+01	1.21E-01	8.67E+01
STA#15	5.37E+01	2.07E-01	5.32E+01	.00E+00	4.71E+01
STA#24	3.13E+01	1.05E-01	2.97E+01	3.31E-02	3.32E+01
STA#23	3.23E+01	6.79E-02	3.12E+01	4.73E-02	3.23E+01

SITE C ENVIRONMENTAL DOSIMETERS 10/20/77 TO 1/12/78

I.D.#	700B	600B	700F	600F	400F
#1	4.08E+01	1.57E-01	3.43E+01	1.83E-01	3.85E+01
#2	7.00E+01	2.26E-01	5.03E+01	1.37E-01	4.80E+01
#3	3.97E+01	1.84E-01	3.15E+01	1.74E-01	3.77E+01
#4	7.40E+02	4.80E-01	6.24E+02	6.85E-01	7.16E+02
#5	3.78E+01	1.59E-01	2.84E+01	2.10E-01	3.39E+01
#6	4.63E+01	4.11E-01	3.53E+01	4.31E-01	3.77E+01
#7	5.24E+01	1.80E-01	4.62E+01	1.66E-01	5.48E+01
#9	5.24E+01	.00E+00	2.97E+01	1.49E-01	5.24E+01
#10	4.91E+01	2.53E-01	4.32E+01	3.32E-01	3.30E+01
#11	3.83E+01	1.69E-01	3.16E+01	3.93E-01	3.32E+01
#12	3.29E+01	1.36E-01	2.96E+01	1.11E-01	3.28E+01
#13	3.44E+01	2.17E-01	3.06E+01	9.27E-02	3.43E+01
#14	3.33E+01	1.25E-01	3.04E+01	1.55E-01	3.30E+01
#15	3.35E+01	1.54E-01	2.77E+01	1.76E-01	3.35E+01
#16	3.78E+01	2.48E-01	3.27E+01	1.94E-01	3.75E+01
#17	3.73E+01	1.94E-01	3.19E+01	1.77E-01	3.15E+01
#18	3.68E+01	1.67E-01	3.31E+01	1.24E-01	3.40E+01
#19	2.63E+01	2.05E-01	2.27E+01	1.89E-01	2.78E+01

SITE C ENVIRONMENTAL DOSIMETERS 10/20/76 TO 1/21/77

I.D.#	700B	600B	700F	600F	400F
STA#1	3.40E+01	1.11E-01	2.81E+01	1.56E-01	3.03E+01
STA#3	3.27E+01	9.86E-02	2.94E+01	3.83E-02	2.95E+01
STA#4	2.67E+02	1.94E-01	2.22E+02	2.54E-01	2.36E+02
STA#5	2.87E+01	8.91E-02	2.57E+01	5.46E-02	2.68E+01
STA#6	3.12E+01	9.25E-02	3.07E+01	.00E+00	2.75E+01
STA#7	4.44E+01	1.02E-01	4.16E+01	7.55E-02	4.16E+01
STA#9	2.48E+01	9.69E-02	2.24E+01	5.50E-02	2.24E+01
STA#10	4.76E+01	2.50E-01	4.20E+01	8.70E-02	4.30E+01
STA#12	2.74E+01	1.27E-01	2.52E+01	5.39E-02	2.51E+01
STA#13	2.73E+01	1.00E-01	2.42E+01	7.14E-02	2.56E+01
STA#14	2.78E+01	1.04E-01	2.49E+01	6.42E-02	2.50E+01
STA#15	2.61E+01	5.30E-02	2.31E+01	3.03E-02	2.41E+01
STA#16	3.30E+01	1.79E-01	2.77E+01	1.37E-01	2.93E+01
STA#17	2.92E+01	7.58E-02	2.39E+01	1.42E-01	2.80E+01
STA#18	3.26E+01	1.25E-01	2.89E+01	1.06E-02	2.91E+01
STA#19	4.33E+01	2.13E-01	3.81E+01	1.27E-01	3.87E+01
STA#20	2.90E+01	1.14E-01	2.75E+01	4.64E-02	2.74E+01
STA#21	2.84E+01	9.33E-02	2.52E+01	3.95E-02	2.68E+01
STA#22	2.54E+01	1.23E-01	2.35E+01	4.56E-02	2.40E+01
STA#23	2.09E+01	1.36E-01	1.88E+01	2.12E-01	2.01E+01
STA#24	2.88E+01	1.06E-01	2.69E+01	7.26E-02	2.88E+01
UNUSED	2.32E+01	1.73E-01	2.09E+01	1.78E-01	2.21E+01

SITE C ENVIRONMENTAL DOSIMETERS 1/21 TO 4/12/77

I.D.#	700B	600B	700F	600F	400F
STA#1	4.50E+01	1.88E-01	3.79E+01	1.68E-01	3.38E+01
STA#2	4.52E+01	.00E+00	3.86E+01	3.31E-01	3.06E+01
STA#3	4.39E+01	1.35E-01	3.83E+01	1.45E-01	3.31E+01
STA#5	3.97E+01	1.22E-01	3.35E+01	1.54E-01	3.08E+01
STA#6	4.16E+01	1.44E-01	3.55E+01	1.34E-01	2.93E+01
STA#7	5.44E+01	1.04E-01	4.82E+01	1.69E-01	4.03E+01
STA#8	4.42E+01	6.95E-02	3.76E+01	1.68E-01	3.05E+01
STA#9	3.83E+01	1.70E-01	3.54E+01	1.76E-01	2.90E+01
STA11	4.64E+01	1.13E-01	3.83E+01	1.27E-01	3.17E+01
STA12	3.73E+01	1.64E-01	3.31E+01	2.05E-01	2.71E+01
STA13	4.02E+01	1.35E-01	3.42E+01	1.64E-01	2.88E+01
STA14	3.59E+01	1.27E-01	3.32E+01	1.46E-01	2.85E+01
STA15	3.75E+01	1.66E-01	3.24E+01	1.66E-01	2.71E+01
STA16	4.22E+01	1.64E-01	3.66E+01	2.19E-01	3.00E+01
STA17	4.60E+01	6.51E-02	3.91E+01	1.17E-01	2.87E+01
CON-1	3.52E+01	1.53E-01	3.07E+01	1.97E-01	2.50E+01
CON-2	4.03E+01	1.57E-03	3.66E+01	1.55E-01	3.03E+01
UNU-3	1.92E+01	9.84E-02	1.85E+01	7.87E-02	1.37E+01
UNU-4	2.05E+01	6.55E-02	1.87E+01	1.05E-01	1.40E+01

SITE C PERSONNEL DOSIMETERS 6/2 TO 10/20/76

T.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
002-6	5.72E+01	5.72E+01	2.67E-01	.00E+00	57.5
003-6	4.18E+01	4.18E+01	1.10E-01	.00E+00	41.7
004-6	4.61E+01	4.61E+01	8.85E-02	.00E+00	46.2
005-6	7.79E+01	7.79E+01	2.42E-01	.00E+00	78.1
006-6	5.56E+01	5.56E+01	3.79E-01	.00E+00	56.0
007-6	4.26E+01	4.26E+01	2.17E-01	.00E+00	42.5
008-6	4.87E+01	4.87E+01	3.17E-01	.00E+00	49.0
009-6	3.62E+01	3.62E+01	4.08E-01	.00E+00	36.6
010-6	4.13E+01	4.13E+01	1.50E-01	.00E+00	41.3
012-6	4.48E+01	4.48E+01	3.29E-01	.00E+00	45.2
013-6	4.21E+01	4.21E+01	2.74E-01	.00E+00	42.4
014-6	4.44E+01	4.44E+01	1.31E-01	.00E+00	44.5
015-6	4.28E+01	4.28E+01	1.33E-01	.00E+00	42.9
016-6	4.72E+01	4.72E+01	1.91E-01	.00E+00	47.4
017-6	4.54E+01	4.54E+01	2.73E-01	.00E+00	45.7
019-6	4.96E+01	4.96E+01	2.62E-01	.00E+00	49.6
020-6	4.68E+01	4.68E+01	.00E+00	2.15E+00	46.9
021-6	4.97E+01	4.97E+01	2.40E-01	.00E+00	49.7
022-6	4.98E+01	4.98E+01	2.46E-01	.00E+00	50.0
023-6	4.03E+01	4.03E+01	2.87E-01	.00E+00	40.6
024-6	4.76E+01	4.76E+01	3.15E-01	.00E+00	48.0
025-6	4.04E+01	4.04E+01	3.98E-01	.00E+00	40.6
026-6	4.40E+01	4.40E+01	1.65E-01	.00E+00	44.2
027-6	4.87E+01	4.87E+01	3.35E-01	.00E+00	49.0
028-6	5.09E+01	5.09E+01	3.13E-01	.00E+00	51.7
029-6	3.94E+01	3.94E+01	2.75E-01	.00E+00	39.7
030-6	4.02E+01	4.02E+01	1.60E-01	.00E+00	40.3
BKG#1	4.80E+01	4.80E+01	1.81E-01	.00E+00	48.2
BKG#2	3.49E+01	3.49E+01	3.02E-01	.00E+00	35.2
BKG#3	3.44E+01	3.44E+01	4.23E-02	.00E+00	34.4

SITE C PERSONNEL DOSIMETERS 10/20 TO 1/29/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
CS-1	2.52E+01	2.52E+01	1.45E-01	.00E+00	25.3
CS-2	2.62E+01	2.62E+01	7.58E-02	.00E+00	26.2
CS-3	2.79E+01	2.79E+01	4.68E-02	2.95E+00	30.9
CS-4	2.95E+01	2.95E+01	3.87E-02	1.76E+00	31.3
CS-5	2.62E+01	2.62E+01	1.58E-01	.00E+00	26.3
CS-6	2.53E+01	2.53E+01	2.90E-02	6.20E+00	31.6
LTA-1	2.97E+01	2.97E+01	1.85E-01	.00E+00	29.8
LTA-2	2.67E+01	2.67E+01	2.40E-01	.00E+00	27.0
CE-1	2.67E+01	2.67E+01	1.60E-01	.00E+00	26.9
CTA-1	2.74E+01	2.74E+01	1.89E-01	.00E+00	27.6
CTA-2	2.57E+01	2.57E+01	9.03E-02	.00E+00	25.8
CTA-3	2.70E+01	2.70E+01	3.55E-02	7.37E+00	34.5
CTA-4	2.87E+01	2.87E+01	1.52E-01	.00E+00	28.9
CTA-5	2.70E+01	2.70E+01	1.53E-01	.00E+00	27.2
CTA-6	2.63E+01	2.63E+01	1.66E-01	.00E+00	26.5
CTA-7	2.79E+01	2.79E+01	.00E+00	7.57E+00	35.3
CTA-8	2.51E+01	2.51E+01	1.61E-01	.00E+00	25.3
CTA-9	2.81E+01	2.81E+01	1.85E-01	.00E+00	28.3
CTA-10	4.25E+01	4.25E+01	1.94E-01	.00E+00	42.7
O-1	2.90E+01	2.90E+01	1.31E-01	.00E+00	29.2
O-2	2.92E+01	2.92E+01	1.16E-01	.00E+00	29.3
O-3	2.84E+01	2.84E+01	2.24E-01	.00E+00	28.6
O-4	3.57E+01	5.70E+01	1.69E-01	.00E+00	37.7
O-5	3.07E+01	3.07E+01	6.87E-02	.00E+00	30.6
O-6	2.90E+01	2.90E+01	9.87E-02	.00E+00	29.1
T-1	2.87E+01	2.87E+01	1.13E-01	.00E+00	28.6
T-2	3.30E+01	3.30E+01	1.02E-01	.00E+00	33.1
T-3	3.98E+02	3.98E+02	3.33E+00	9.79E+01	498.9
T-4	3.05E+01	3.05E+01	1.92E-01	.00E+00	30.7
T-5	2.76E+01	2.76E+01	4.68E-02	4.29E+00	32.0
T-6	3.00E+01	3.00E+01	1.74E-01	.00E+00	30.2
MO-1	2.80E+01	2.80E+01	9.68E-02	.00E+00	29.1
MO-2	2.81E+01	2.81E+01	1.65E-01	.00E+00	28.2
MO-3	2.72E+01	2.72E+01	1.82E-01	.00E+00	27.4
MO-4	2.81E+01	2.81E+01	7.90E-02	3.11E-01	28.8
MO-5	2.69E+01	2.69E+01	.00E+00	9.07E+00	36.0
MO-6	2.87E+01	2.87E+01	7.42E-02	.00E+00	28.6
MO-7	2.96E+01	2.96E+01	8.39E-02	.00E+00	29.7
MO-8	2.79E+01	2.79E+01	5.00E-02	1.71E+00	29.6
MO-9	3.48E+01	3.65E+01	2.42E-02	6.65E+00	41.5
MO-10	2.79E+01	2.79E+01	5.00E-02	2.61E+00	30.3
AO-1	3.04E+01	3.04E+01	2.42E-02	4.38E+00	34.6
AO-2	3.06E+01	3.06E+01	1.16E-01	.00E+00	30.7
AO-3	3.11E+01	3.11E+01	9.52E-02	5.29E-01	31.8
AO-4	2.97E+01	2.97E+01	2.37E-01	.00E+00	30.0
AO-5	3.20E+01	3.20E+01	2.06E-01	.00E+00	32.2

SITE C - PERSONNEL DOSIMETERS - 10/20 TO 1/29/77 (cont'd)

AD-6	3.02E+01	3.02E+01	2.36E-01	.00E+00	30.4
AD-7	2.95E+01	2.95E+01	1.82E-01	.00E+00	29.7
AD-8	3.16E+01	3.16E+01	5.16E-02	.00E+00	31.7
AF-1	2.83E+01	2.83E+01	1.00E-01	.00E+00	28.4
AF-2	2.80E+01	2.80E+01	1.77E-01	.00E+00	28.2
AF-3	2.86E+01	2.86E+01	1.42E-01	.00E+00	28.7
AF-4	2.85E+01	2.85E+01	6.77E-02	1.93E+00	30.5
AF-5	3.22E+01	3.22E+01	2.82E-01	.00E+00	32.4
AF-6	3.07E+01	3.07E+01	1.08E-01	.00E+00	30.8
AF-7	2.68E+01	2.68E+01	1.98E-01	.00E+00	27.0
AF-8	2.98E+01	2.98E+01	1.40E-01	.00E+00	29.7
QCF-1	2.89E+01	2.89E+01	3.06E-02	2.95E+00	31.7
QCF-2	2.79E+01	2.79E+01	2.08E-01	.00E+00	28.1
QCF-3	3.03E+01	3.03E+01	1.72E-01	.00E+00	30.5
QCF-4	3.06E+01	3.06E+01	2.02E-01	.00E+00	30.8
QCF-5	2.62E+01	2.62E+01	8.53E-02	.00E+00	26.2
QCF-6	2.74E+01	2.74E+01	1.10E-01	.00E+00	27.5
QCF-7	2.90E+01	2.90E+01	6.94E-02	2.02E+00	31.1
QCF-8	2.97E+01	2.97E+01	1.33E-01	.00E+00	29.8
FE-1	2.65E+01	2.65E+01	1.75E-01	.00E+00	26.7
FE-2	2.63E+01	2.63E+01	1.74E-01	.00E+00	26.5
CON-1	1.72E+01	1.72E+01	1.35E-01	.00E+00	17.4
CON-2	3.00E+01	3.00E+01	5.18E-02	4.00E+00	34.1
CON-3	2.76E+01	2.76E+01	1.94E-02	3.57E+00	31.2

SITE C PERSONNEL DOSIMETERS 11/9/77 TO 2/10/78

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
MOP-1	3.34E+01	3.34E+01	1.38E-01	.00E+00	33.5
MOP-2	3.77E+01	3.77E+01	1.02E-01	.00E+00	37.8
MOP-3	3.61E+01	3.61E+01	3.50E-02	3.41E+00	39.6
MOP-4	3.64E+01	3.64E+01	4.00E-02	.00E+00	36.5
MOP-5	4.00E+01	4.00E+01	1.62E-01	.00E+00	40.2
MOP-6	3.46E+01	3.46E+01	3.33E-03	3.89E+00	38.5
MOP-7	3.50E+01	3.50E+01	1.38E-01	.00E+00	35.2
MOP-8	3.60E+01	3.60E+01	1.42E-01	.00E+00	36.1
SGS-1	3.61E+01	3.61E+01	1.35E-01	.00E+00	36.2
SGS-2	3.66E+01	3.66E+01	5.17E-02	.00E+00	36.6
SGS-3	3.54E+01	3.54E+01	1.78E-01	.00E+00	35.6
SGS-4	3.45E+01	3.45E+01	1.17E-01	.00E+00	34.7
SGS-5	3.43E+01	3.43E+01	1.67E-02	4.23E+00	38.5
SGS-6	3.22E+01	3.22E+01	8.17E-02	.00E+00	32.3
SGS-7	3.59E+01	3.59E+01	1.50E-01	.00E+00	36.1
SGS-8	3.58E+01	3.58E+01	1.42E-01	.00E+00	36.0
SGS-9	3.48E+01	3.48E+01	1.90E-01	.00E+00	35.0
QCF-1	3.66E+01	3.66E+01	2.83E-02	.00E+00	36.7
QCF-2	3.15E+01	3.15E+01	2.13E-01	.00E+00	31.7
QCF-3	3.48E+01	3.48E+01	1.63E-01	.00E+00	34.9
QCF-4	3.41E+01	3.41E+01	.00E+00	2.79E+00	36.9
QCF-5	3.60E+01	3.60E+01	1.47E-01	.00E+00	36.1
QCF-6	3.88E+01	3.88E+01	2.95E-01	.00E+00	38.7
QCF-7	3.82E+01	3.82E+01	1.03E-01	3.97E-01	38.2
QCF-8	3.52E+01	3.52E+01	2.33E-01	.00E+00	35.4
AF-1	3.95E+01	3.95E+01	6.35E-02	4.38E+00	44.0
AF-2	3.48E+01	3.48E+01	1.82E-01	.00E+00	35.0
AF-3	3.65E+01	3.65E+01	1.35E-01	.00E+00	36.6
AF-4	3.48E+01	3.48E+01	3.17E-02	.00E+00	34.9
AF-5	3.54E+01	3.54E+01	1.78E-01	.00E+00	35.6
AF-6	3.72E+01	3.72E+01	1.55E-01	.00E+00	37.4
AF-7	3.50E+01	3.50E+01	3.18E-01	.00E+00	35.3
A182-1	3.43E+01	3.43E+01	1.23E-01	.00E+00	34.4
A182-2	3.50E+01	3.50E+01	1.17E-01	.00E+00	35.1
A182-3	3.62E+01	3.62E+01	1.38E-01	.00E+00	36.4
A182-4	3.29E+01	3.29E+01	1.42E-01	.00E+00	33.0
A182-5	3.70E+01	3.70E+01	9.83E-02	.00E+00	37.1
CTA-1	5.69E+01	5.69E+01	1.40E-01	.00E+00	57.1
CTA-2	3.39E+01	3.56E+01	.00E+00	1.30E+01	46.2
CTA-3	5.95E+01	5.95E+01	5.35E-01	.00E+00	60.0
CTA-4	3.47E+01	3.47E+01	1.70E-01	.00E+00	34.9
CTA-5	3.45E+01	3.45E+01	1.70E-01	.00E+00	34.7
CTA-6	3.26E+01	3.26E+01	2.30E-01	.00E+00	32.8
CTA-7	3.54E+01	3.54E+01	5.67E-02	.00E+00	35.3
CTA-8	6.92E+01	6.92E+01	4.28E-01	.00E+00	69.6
CTA-9	3.62E+01	3.62E+01	1.70E-01	.00E+00	36.3
CTA-10	6.76E+01	6.76E+01	2.13E-01	.00E+00	67.3
T-1	3.39E+01	3.64E+01	1.62E-01	.00E+00	34.0
T-2	4.08E+01	4.08E+01	7.33E-02	3.08E+00	40.1

SITE C - PERSONNEL DOSIMETERS - 11/9/77 TO 2/10/78 (cont'd)

T-3	5.91E+01	5.91E+01	3.30E-01	.00E+00	59.4
T-4	3.54E+01	3.54E+01	1.93E-01	.00E+00	35.6
T-5	3.85E+01	4.33E+01	8.33E-03	6.96E+00	45.4
T-6	3.33E+01	3.33E+01	2.43E-01	.00E+00	33.5
T-7	7.75E+01	7.75E+01	6.15E-01	.00E+00	78.2
T-8	3.57E+01	3.57E+01	5.00E-03	.00E+00	35.7
T-9	3.67E+01	3.67E+01	1.20E-01	.00E+00	36.8
OE-1	3.58E+01	3.58E+01	3.33E-02	6.02E+00	41.2
OE-2	3.35E+01	3.35E+01	6.00E-02	.00E+00	33.5
OE-3	5.44E+01	5.52E+01	2.82E-01	.00E+00	54.7
OE-4	3.48E+01	3.48E+01	5.33E-02	5.07E+00	39.9
OE-5	3.39E+01	3.39E+01	1.25E-01	.00E+00	33.1
OE-6	3.59E+01	3.59E+01	1.90E-01	.00E+00	35.1
OE-7	3.42E+01	3.42E+01	9.33E-02	.00E+00	34.3
OE-8	7.39E+01	7.39E+01	4.38E-01	.00E+00	74.4
OE-9	3.30E+01	3.30E+01	1.70E-01	.00E+00	33.1
L-1	5.48E+01	5.48E+01	1.20E-01	.00E+00	54.2
L-2	5.51E+01	5.51E+01	3.55E-01	.00E+00	55.5
L-3	3.36E+01	3.36E+01	2.85E-01	.00E+00	33.2
L-4	4.17E+01	4.17E+01	1.77E-01	.00E+00	41.8
L-5	5.69E+01	5.69E+01	1.20E-01	.00E+00	57.1
L-6	7.11E+01	7.11E+01	3.02E-01	.00E+00	71.4
L-7	3.73E+01	3.73E+01	.00E+00	.00E+00	37.3
L-8	3.39E+01	3.39E+01	7.67E-02	3.12E+00	37.1
IW-1	3.94E+01	3.94E+01	1.82E-01	.00E+00	39.3
IW-2	3.59E+01	3.59E+01	5.67E-02	5.26E+00	41.5
IW-3	3.74E+01	3.74E+01	1.68E-01	.00E+00	37.6
IW-4	8.59E+01	8.59E+01	4.10E-01	.00E+00	85.5
IW-5	7.42E+01	7.42E+01	1.52E-01	7.37E+00	81.7
IW-6	3.57E+01	3.57E+01	2.95E-01	.00E+00	35.0
IW-7	9.29E+01	9.29E+01	4.03E-01	.00E+00	93.3
IW-8	3.57E+01	3.57E+01	1.90E-01	.00E+00	35.0
IW-9	3.37E+01	3.37E+01	3.15E-01	.00E+00	33.2
CON-1	2.46E+01	2.46E+01	1.03E-01	2.29E+00	27.5

SITE C PERSONNEL DOSIMETERS 7/12 TO 11/9/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE -- mREM
CE-1	4.29E+01	4.29E+01	.00E+00	2.63E+00	45.6
ADX-1	5.96E+01	6.96E+01	4.03E-01	.00E+00	70.0
ADX-2	7.02E+01	7.02E+01	4.11E-01	.00E+00	70.6
ADX-3	7.01E+01	7.01E+01	5.68E-01	.00E+00	70.7
ADX-4	7.87E+01	7.87E+01	8.09E-01	.00E+00	79.5
ADX-5	7.51E+01	7.51E+01	2.22E-01	.00E+00	75.3
AF-1	3.58E+01	3.58E+01	1.06E-01	.00E+00	35.9
AF-8	3.78E+01	3.78E+01	1.06E-01	.00E+00	37.9
CCF-2	4.09E+01	4.09E+01	1.49E-01	.00E+00	41.0
CS-2	3.96E+01	3.96E+01	1.41E-01	.00E+00	39.6
CS-3	3.88E+01	4.03E+01	2.90E-01	.00E+00	39.1
CS-6	3.85E+01	3.85E+01	2.36E-01	.00E+00	38.8
FE-1	3.92E+01	3.92E+01	2.03E-01	.00E+00	39.4
MO-1	3.98E+01	3.98E+01	1.31E-01	.00E+00	39.7
MO-2	3.63E+01	4.87E+01	1.62E-01	.00E+00	36.5
MO-3	3.90E+01	3.90E+01	2.01E-01	.00E+00	39.2
MO-5	3.96E+01	3.96E+01	1.95E-01	.00E+00	39.6
MO-7	3.92E+01	3.92E+01	9.85E-02	.00E+00	39.3
MO-8	3.90E+01	3.90E+01	1.02E-01	.00E+00	39.1
MO-9	3.67E+01	3.67E+01	5.41E-02	8.07E-01	37.6
MO-10	4.72E+01	4.72E+01	1.37E-01	.00E+00	47.4
QCF-1	3.90E+01	3.90E+01	1.53E-01	.00E+00	39.1
QCF-3	4.09E+01	4.09E+01	2.97E-01	.00E+00	41.2
QCF-4	4.04E+01	4.04E+01	5.41E-02	.00E+00	40.7
QCF-5	3.82E+01	3.82E+01	.00E+00	3.39E+00	41.5
QCF-7	3.91E+01	3.91E+01	4.05E-02	.00E+00	39.2
QCF-8	4.05E+01	4.05E+01	4.63E-02	.00E+00	40.5
QCF-9	4.15E+01	4.15E+01	2.08E-01	.00E+00	41.7
X-1	3.86E+01	3.86E+01	2.01E-01	.00E+00	38.6
X-2	3.57E+01	3.57E+01	1.14E-01	.00E+00	35.9
X-3	4.94E+01	4.94E+01	4.59E-01	.00E+00	49.7
X-4	4.00E+01	4.00E+01	2.63E-01	.00E+00	40.2
X-5	4.69E+01	4.69E+01	3.19E-01	.00E+00	47.2
CCN-3	3.85E+01	3.85E+01	2.61E-01	.00E+00	38.6
NAN-1	5.11E+01	5.11E+01	3.32E-01	.00E+00	51.4
NAN-2	4.94E+01	4.94E+01	.00E+00	2.50E+00	51.9
NAN-3	5.41E+01	5.66E+01	2.10E-01	.00E+00	54.3
NAN-4	5.21E+01	5.21E+01	1.25E-01	.00E+00	52.2
NAN-5	5.23E+01	5.23E+01	2.51E-01	.00E+00	52.5
NAN-6	5.32E+01	5.32E+01	1.68E-01	.00E+00	53.4
NAN-7	4.89E+01	4.89E+01	1.63E-01	.00E+00	49.0
NAN-8	5.21E+01	5.21E+01	3.46E-01	.00E+00	52.4
NAN-9	4.06E+01	4.06E+01	2.59E-01	.00E+00	40.8
NAN-10	4.31E+01	4.31E+01	3.07E-01	.00E+00	43.4
NAN-11	4.05E+01	4.05E+01	7.92E-02	.00E+00	40.6
NAN-12	4.05E+01	4.05E+01	1.25E-01	.00E+00	40.6
NAN-13	4.55E+01	4.55E+01	4.19E-01	.00E+00	45.7
NAN-14	4.95E+01	4.95E+01	.00E+00	1.11E+01	60.6
NAN-15	3.94E+01	3.94E+01	7.72E-02	.00E+00	39.7

SITE C PERSONNEL DOSIMETERS 7/12 TO 11/9/77 (cont'd)

NAN-16	4.20E+01	4.20E+01	2.63E-01	.00E+00	42.2
NAN-17	4.12E+01	4.12E+01	2.28E-01	.00E+00	41.4
NAN-18	3.96E+01	3.96E+01	1.02E-01	5.48E+00	45.1
NAN-19	4.05E+01	4.05E+01	4.05E-02	.00E+00	40.6
NAN-20	3.99E+01	3.99E+01	1.35E-01	.00E+00	40.1
NAN-21	5.34E+01	5.34E+01	3.13E-01	.00E+00	53.7
NAN-22	4.13E+01	4.13E+01	2.28E-01	.00E+00	41.3
NAN-23	4.05E+01	4.05E+01	1.25E-01	.00E+00	40.6
NAN-24	4.15E+01	4.15E+01	1.97E-01	.00E+00	41.7
NAN-25	5.26E+01	5.26E+01	2.43E-01	.00E+00	52.6
NAN-26	3.97E+01	3.97E+01	2.39E-01	.00E+00	39.9
NAN-27	4.26E+01	4.26E+01	3.42E-01	.00E+00	42.9
NAN-28	4.40E+01	4.40E+01	1.27E-01	.00E+00	44.1
NAN-29	3.82E+01	3.82E+01	2.28E-01	.00E+00	38.4
NAN-30	4.11E+01	4.11E+01	2.12E-01	.00E+00	41.3
NAN-31	4.03E+01	4.03E+01	2.20E-01	.00E+00	40.5
NAN-32	4.60E+01	4.60E+01	7.72E-02	.00E+00	46.1
NAN-33	4.18E+01	4.18E+01	1.31E-01	.00E+00	41.9
NAN-34	4.23E+01	4.23E+01	4.44E-02	.00E+00	42.4
NAN-35	4.22E+01	4.22E+01	1.81E-01	.00E+00	42.3
NAN-36	4.04E+01	4.39E+01	.00E+00	6.00E-01	41.0
NAN-37	3.69E+01	3.69E+01	9.07E-02	.00E+00	37.0
NAN-38	3.96E+01	3.96E+01	1.81E-01	.00E+00	39.8
NAN-39	3.76E+01	3.76E+01	9.65E-02	.00E+00	37.7
NAN-40	4.43E+01	4.43E+01	3.13E-01	.00E+00	44.3
NAN-41	4.20E+01	4.20E+01	4.00E-01	.00E+00	42.4
NAN-42	4.66E+01	4.66E+01	2.37E-01	.00E+00	46.9
NAN-43	3.84E+01	3.84E+01	3.09E-01	.00E+00	38.7
NAN-44	3.96E+01	3.96E+01	1.47E-01	.00E+00	39.8
NAN-45	4.59E+01	4.59E+01	3.82E-01	.00E+00	46.3
NAN-46	3.85E+01	3.85E+01	1.37E-01	.00E+00	38.6
NAN-47	4.01E+01	4.01E+01	2.55E-01	.00E+00	40.4
NAN-48	4.31E+01	4.31E+01	3.09E-01	.00E+00	43.4
NAN-49	4.42E+01	4.42E+01	3.82E-01	.00E+00	44.6
NAN-50	4.03E+01	4.17E+01	1.54E-01	.00E+00	40.8
NAN-51	1.72E+01	1.72E+01	9.86E-02	2.41E+00	17.7
NAN-52	1.61E+01	1.61E+01	1.31E-01	.00E+00	16.3

SITE C PERSONNEL DOSIMETERS 1/29 TO 4/12/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MRE
CS-1	4.00E+01	4.00E+01	2.18E-01	.00E+00	40.2
CS-2	4.04E+01	4.04E+01	1.87E-01	.00E+00	40.6
CS-3	4.28E+01	4.28E+01	2.82E-01	.00E+00	43.1
CS-4	4.04E+01	4.04E+01	2.95E-01	.00E+00	40.7
CS-5	3.98E+01	3.98E+01	2.78E-01	.00E+00	40.0
CS-6	4.38E+01	4.38E+01	2.97E-01	.00E+00	44.1
LTA-1	4.00E+01	4.00E+01	3.17E-01	.00E+00	40.3
LTA-2	4.36E+01	4.36E+01	2.51E-01	.00E+00	43.9
LTA-3	3.84E+01	3.84E+01	.00E+00	6.78E+00	42.2
LTA-4	3.95E+01	4.16E+01	2.47E-01	.00E+00	39.8
LTA-5	3.87E+01	4.13E+01	9.35E-02	1.34E-01	39.0
LTA-6	4.14E+01	4.14E+01	1.30E-01	.00E+00	41.6
CE-1	4.02E+01	4.02E+01	3.24E-01	.00E+00	40.6
CTA-1	4.03E+01	4.03E+01	2.16E-01	.00E+00	40.5
CTA-2	4.16E+01	4.22E+01	2.37E-01	.00E+00	41.9
CTA-3	4.19E+01	4.19E+01	2.68E-01	.00E+00	42.2
CTA-4	4.21E+01	4.31E+01	2.74E-01	.00E+00	42.4
CTA-5	4.11E+01	4.11E+01	2.36E-01	.00E+00	41.4
CTA-6	3.98E+01	4.00E+01	3.69E-01	.00E+00	40.1
CTA-7	4.03E+01	4.03E+01	2.12E-01	.00E+00	40.5
CTA-8	4.40E+01	4.40E+01	2.88E-01	.00E+00	44.3
O-1	3.80E+01	4.05E+01	2.72E-01	.00E+00	39.2
O-2	3.93E+01	3.93E+01	2.76E-01	.00E+00	39.6
O-3	4.23E+01	4.23E+01	2.34E-01	.00E+00	42.5
O-4	3.73E+01	3.73E+01	2.64E-01	.00E+00	37.5
O-5	4.26E+01	4.26E+01	2.51E-01	.00E+00	42.8
O-6	4.74E+01	4.74E+01	3.13E-01	.00E+00	47.7
O-7	9.39E+01	1.06E+02	.00E+00	6.29E+00	100.2
T-1	4.00E+01	4.00E+01	1.74E-01	.00E+00	40.1
T-2	4.30E+01	4.30E+01	2.93E-01	.00E+00	43.3
T-3	4.04E+01	4.04E+01	3.13E-01	.00E+00	40.7
T-4	3.98E+01	3.98E+01	2.27E-01	.00E+00	40.0
T-5	3.98E+01	3.98E+01	1.54E-01	.00E+00	39.7
T-6	5.55E+01	5.55E+01	3.75E-01	.00E+00	55.9
T-7	4.20E+01	4.20E+01	3.90E-01	.00E+00	42.4
MO-1	4.17E+01	4.17E+01	2.73E-01	.00E+00	42.0
MO-2	4.25E+01	4.25E+01	2.43E-01	.00E+00	42.7
MO-3	4.09E+01	4.09E+01	2.14E-01	.00E+00	41.1
MO-4	3.98E+01	4.09E+01	3.55E-01	.00E+00	40.1
MO-5	4.03E+01	4.20E+01	2.63E-01	.00E+00	40.6
MO-6	4.36E+01	4.36E+01	2.66E-01	.00E+00	43.9
MO-7	3.96E+01	4.08E+01	2.10E-01	.00E+00	39.6
MO-8	4.03E+01	4.03E+01	2.70E-01	.00E+00	40.6
MO-9	5.77E+01	5.77E+01	1.37E-01	.00E+00	57.7
MO-10	4.08E+01	4.17E+01	3.13E-01	.00E+00	41.1
AO-1	4.21E+01	4.21E+01	2.97E-01	.00E+00	42.6
AO-2	3.88E+01	3.88E+01	2.26E-01	.00E+00	38.0

SITE C PERSONNEL DOSIMETERS - 1/29 TO 4/12/77 (cont'd)

AO-3	4.13E+01	4.13E+01	1.62E-01	.00E+00	41.3
AO-4	4.35E+01	4.35E+01	1.37E-01	.00E+00	43.6
AO-5	4.28E+01	4.28E+01	2.24E-01	.00E+00	43.0
AF-1	3.66E+01	3.84E+01	1.56E-01	.00E+00	36.8
AF-2	3.96E+01	3.96E+01	3.67E-02	3.16E+00	42.8
AF-3	4.25E+01	4.25E+01	2.45E-01	.00E+00	42.6
AF-4	4.00E+01	4.00E+01	2.10E-01	.00E+00	40.2
AF-5	4.18E+01	4.18E+01	2.74E-01	.00E+00	42.1
AF-6	4.37E+01	4.37E+01	2.32E-01	.00E+00	43.7
AF-7	3.81E+01	3.81E+01	2.63E-01	.00E+00	38.4
AF-8	4.04E+01	4.22E+01	1.87E-01	.00E+00	40.6
AF-9	4.12E+01	4.12E+01	2.93E-01	.00E+00	41.5
AF-10	3.75E+01	3.75E+01	2.55E-01	.00E+00	37.7
QCF-1	4.02E+01	4.04E+01	2.47E-01	.00E+00	40.4
QCF-3	3.98E+01	4.44E+01	2.45E-01	.00E+00	40.1
QCF-4	4.27E+01	4.27E+01	2.51E-01	.00E+00	43.0
QCF-5	3.96E+01	3.96E+01	3.32E-01	.00E+00	39.9
QCF-6	3.92E+01	4.00E+01	2.36E-01	.00E+00	39.4
QCF-7	4.14E+01	4.14E+01	2.18E-01	.00E+00	41.6
QCF-8	4.13E+01	4.13E+01	1.33E-01	.00E+00	41.4
IWA-1	4.38E+01	4.38E+01	2.68E-01	.00E+00	44.1
IWA-2	4.96E+01	6.20E+01	7.53E-02	.00E+00	49.6
IWA-3	4.61E+01	4.61E+01	2.41E-01	.00E+00	46.4
IWA-4	3.96E+01	3.95E+01	1.81E-01	.00E+00	39.6
ANK-1	4.29E+01	4.29E+01	1.84E-01	.00E+00	43.1
ANK-2	4.22E+01	4.22E+01	3.20E-01	.00E+00	42.5
FE-1	3.69E+01	3.80E+01	3.30E-01	.00E+00	37.2
CCF-2	4.11E+01	4.11E+01	2.14E-01	.00E+00	41.4
FE-2	4.22E+01	4.41E+01	1.14E-01	.00E+00	42.3
UK-1	4.17E+01	4.17E+01	.00E+00	2.09E+01	62.6
UK-2	4.22E+01	4.22E+01	2.26E-01	.00E+00	42.3
CCN-3	4.00E+01	4.00E+01	2.90E-01	.00E+00	40.3
CCN-4	4.13E+01	4.13E+01	3.67E-01	.00E+00	41.4
CCN-5	3.20E+01	3.20E+01	2.72E-01	.00E+00	32.3

SITE C PERSONNEL DOSIMETERS 4/12 TO 7/12/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
CON-1	4.18E+01	4.18E+01	7.51E-02	9.16E+00	51.1
C-1	4.27E+01	4.27E+01	2.69E-01	.00E+00	43.6
C-2	3.86E+01	3.86E+01	2.95E-01	.00E+00	38.8
C-3	4.08E+01	4.08E+01	1.72E-01	.00E+00	41.0
C-4	4.20E+01	4.20E+01	2.97E-01	.00E+00	42.3
C-5	4.02E+01	4.02E+01	1.21E-01	.00E+00	40.3
C-6	4.23E+01	4.23E+01	2.55E-01	.00E+00	42.5
C-7	3.80E+01	3.80E+01	2.33E-01	.00E+00	38.2
C-8	4.09E+01	4.09E+01	2.66E-01	.00E+00	41.1
C-9	4.22E+01	4.22E+01	2.69E-01	.00E+00	42.5
IW-1	4.00E+01	4.00E+01	2.47E-01	.00E+00	40.2
IW-2	4.65E+01	4.65E+01	1.41E-01	.00E+00	46.7
IW-3	4.37E+01	4.37E+01	2.73E-01	.00E+00	44.0
IW-4	4.31E+01	4.31E+01	3.83E-01	.00E+00	43.5
L-1	4.19E+01	4.19E+01	1.34E-01	.00E+00	42.0
L-2	3.76E+01	3.76E+01	2.20E-01	.00E+00	37.8
L-3	4.08E+01	4.08E+01	2.56E-01	.00E+00	41.0
L-4	3.98E+01	3.98E+01	2.80E-01	.00E+00	40.1
L-5	4.08E+01	4.08E+01	1.67E-01	.00E+00	41.0
L-6	5.23E+01	5.23E+01	2.16E-01	.00E+00	52.5
MO-1	3.95E+01	3.95E+01	4.95E-02	7.26E+00	46.8
MO-2	3.98E+01	3.98E+01	2.53E-01	.00E+00	40.1
MO-3	4.17E+01	4.17E+01	2.03E-01	.00E+00	42.0
MO-4	4.17E+01	4.17E+01	1.28E-01	.00E+00	41.7
MO-5	3.98E+01	3.98E+01	1.59E-01	.00E+00	40.7
MO-6	4.12E+01	4.12E+01	2.55E-01	.00E+00	41.4
MO-7	4.09E+01	4.09E+01	2.12E-01	.00E+00	41.1
MO-8	4.13E+01	4.13E+01	.00E+00	3.62E+00	44.9
MO-9	5.21E+01	6.45E+01	3.30E-02	8.46E+00	60.7
MO-10	4.13E+01	4.13E+01	1.63E-01	.00E+00	41.4
AO-1	4.25E+01	4.25E+01	1.28E-01	.00E+00	42.7
AO-2	4.16E+01	4.16E+01	3.48E-02	6.53E+00	48.1
AO-3	4.63E+01	4.63E+01	2.34E-01	.00E+00	46.6
AO-4	4.43E+01	4.43E+01	2.12E-01	.00E+00	44.6
AO-5	4.41E+01	4.41E+01	1.61E-01	.00E+00	44.3
AO-6	4.25E+01	4.25E+01	1.52E-01	.00E+00	42.7
AO-7	4.35E+01	4.35E+01	1.47E-01	.00E+00	43.7
AO-8	3.92E+01	3.92E+01	2.33E-01	.00E+00	39.5
OPE-1	4.29E+01	4.29E+01	1.08E-01	.00E+00	43.1
OPE-2	4.16E+01	4.16E+01	4.40E-02	5.27E-01	42.2
OPE-3	4.18E+01	4.18E+01	2.44E-01	.00E+00	42.1
OPE-4	4.18E+01	4.18E+01	2.01E-01	.00E+00	42.0
OPE-5	4.00E+01	4.00E+01	3.65E-02	7.60E+00	47.6
OPE-6	4.86E+01	4.86E+01	2.33E-01	.00E+00	48.6
OPE-7	4.04E+01	4.04E+01	1.70E-01	.00E+00	40.5
OPE-8	3.92E+01	3.92E+01	1.56E-01	.00E+00	39.3
AF-1	3.92E+01	3.92E+01	2.12E-01	.00E+00	39.4
AF-2	3.94E+01	3.94E+01	1.39E-01	.00E+00	39.5
AF-3	4.08E+01	4.08E+01	2.69E-01	.00E+00	41.1
AF-4	3.68E+01	3.68E+01	2.58E-01	.00E+00	37.1

SITE C PERSONNEL DOSIMETERS - 4/12 TO 7/12/77 (cont'd)

AF-5	4.23E+01	4.23E+01	1.83E-01	.00E+00	42.5
AF-6	4.18E+01	4.18E+01	1.98E-01	.00E+00	42.0
AF-7	3.99E+01	3.99E+01	1.32E-01	3.39E+00	43.6
AF-8	4.20E+01	4.20E+01	2.45E-01	.00E+00	42.3
AF-9	3.96E+01	3.96E+01	1.79E-01	.00E+00	37.7
QCF-1	4.33E+01	4.33E+01	2.51E-01	.00E+00	43.6
QCF-2	4.19E+01	4.19E+01	1.72E-01	.00E+00	42.1
QCF-3	3.76E+01	3.76E+01	8.79E-02	1.03E+01	43.0
QCF-4	4.11E+01	4.11E+01	3.11E-01	.00E+00	41.4
QCF-5	4.02E+01	4.02E+01	2.11E-01	.00E+00	40.4
QCF-6	4.26E+01	4.26E+01	.00E+00	5.69E+00	43.3
QCF-8	4.00E+01	4.00E+01	3.68E-01	.00E+00	40.4
QCF-9	4.21E+01	4.21E+01	1.79E-01	.00E+00	42.3
QCF-10	4.19E+01	4.19E+01	4.03E-02	3.99E+00	43.0
CS-1	4.09E+01	4.09E+01	2.78E-01	.00E+00	41.2
CS-2	5.38E+01	5.38E+01	2.25E-01	.00E+00	54.7
CS-3	4.02E+01	4.02E+01	7.88E-02	6.25E+00	46.3
CS-4	4.06E+01	4.06E+01	9.89E-02	3.79E+00	44.4
CS-5	4.00E+01	4.00E+01	2.31E-01	.00E+00	40.3
CS-6	4.40E+01	4.40E+01	1.37E-01	3.34E+00	47.3
CS-7	4.12E+01	4.12E+01	1.89E-01	.00E+00	41.4
T-1	4.01E+01	4.01E+01	1.76E-01	.00E+00	40.3
T-2	4.28E+01	4.28E+01	1.67E-01	.00E+00	43.0
T-3	4.14E+01	4.14E+01	2.27E-01	.00E+00	41.6
T-4	4.24E+01	4.24E+01	1.63E-01	.00E+00	42.3
T-5	4.16E+01	4.16E+01	2.51E-01	.00E+00	41.3
T-6	4.17E+01	4.17E+01	8.97E-02	3.61E+00	45.3
T-7	4.04E+01	4.04E+01	1.92E-01	4.21E-01	41.0
WATER	3.96E+01	3.98E+01	3.00E-01	.00E+00	40.1
NMP-1	3.04E+01	3.04E+01	1.43E-01	3.13E+00	33.6

APPENDIX F - SITE D DATA

SITE D - OFFSITE CONTROLS, CYCLES 1-7
PERSONNEL DOSIMETERS

SITE D - ONSITE CONTROLS, CYCLES 1-7
PERSONNEL DOSIMETERS

SITE D - STATION 2, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 3, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 4, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 5, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 6, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D, STATION 7, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 8, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 10, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - STATION 11, CYCLES 1-7, PERSONNEL DOSIMETERS

SITE D - ONSITE CONTROL, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - OFFSITE CONTROL, CYCLES 1-7 (LiF - Bare).
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 1, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 2, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 3, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 4, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 5, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 6, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS.

SITE D - STATION 7, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 8, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 9, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 10, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 11, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 13, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D - STATION 14, CYCLES 1-7 (LiF - Bare)
ENVIRONMENTAL DOSIMETERS

SITE D PERSONNEL DOSIMETERS 9/1 TO 11/23/76

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MRE
CNTRL	1.74E+01	1.74E+01	9.67E-01	1.41E+01	32.4
CNTRL	1.63E+01	1.63E+01	1.13E+00	5.62E+00	2.0
CNTRL	1.62E+01	1.62E+01	8.93E-01	2.29E+01	40.0
CNTRL	1.71E+01	1.71E+01	9.85E-01	1.34E+01	31.4
00002	3.74E+01	3.74E+01	2.02E+00	.00E+00	39.4
00003	3.09E+01	3.09E+01	1.57E+00	8.88E+00	41.3
00004	3.13E+01	3.13E+01	1.73E+00	.00E+00	33.1
00005	4.03E+01	4.03E+01	1.72E+00	1.85E+01	60.5
00006	2.94E+01	2.94E+01	1.66E+00	1.84E+01	49.4
00007	3.15E+01	3.15E+01	9.97E-01	4.64E+01	79.0
00008	3.01E+01	3.01E+01	1.48E+00	2.10E+01	52.6
00010	3.19E+01	3.19E+01	1.56E+00	9.69E+00	43.1
00011	4.50E+01	4.50E+01	2.20E+00	.00E+00	47.2
00012	3.30E+01	3.30E+01	7.82E-01	1.26E+01	46.4
CNTRL	1.79E+01	1.79E+01	7.78E-01	1.93E+01	38.0
CNTRL	1.80E+01	1.80E+01	8.00E-01	1.78E+01	36.6

SITE D PERSONNEL DOSIMETERS 11/23/76 TO 2/14/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
00002	3.98E+01	3.98E+01	1.23E+00	.00E+00	41.0
00003	3.08E+01	3.08E+01	1.02E+00	1.07E+01	42.5
00004	3.32E+01	3.32E+01	1.00E+00	5.84E+00	40.0
00005	3.92E+01	3.92E+01	1.03E+00	1.25E+01	52.7
00006	3.14E+01	3.14E+01	9.30E-01	1.52E+01	47.5
00007	3.63E+01	3.63E+01	1.04E+00	4.11E+00	41
00008	3.16E+01	3.16E+01	9.09E-01	1.73E+01	49.5
00010	3.27E+01	3.27E+01	9.66E-01	1.36E+01	47.3
00011	4.06E+01	4.06E+01	1.09E+00	1.24E+01	54.0
00012	3.16E+01	3.16E+01	1.59E+00	1.83E+01	51.4
CONT	4.12E+01	4.12E+01	4.17E+00	1.32E+02	177.6
CONT	4.10E+01	4.10E+01	4.77E+00	9.13E+01	137.0
CONT	4.15E+01	4.15E+01	5.12E+00	6.40E+01	110.6
CONT	4.26E+01	4.26E+01	4.72E+00	1.02E+02	149.7

SITE D PERSONNEL DOSIMETERS 2/15/77 TO 3/30/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
0002	3.34E+01	3.34E+01	1.16E-01	.00E+00	33.6
0003	2.79E+01	2.79E+01	1.34E-01	.00E+00	28.0
0004	2.84E+01	2.84E+01	1.32E-01	.00E+00	28.5
0005	3.79E+01	3.79E+01	2.76E-01	.00E+00	38.2
0006	2.95E+01	2.95E+01	2.43E-01	.00E+00	29.7
0007	2.74E+01	2.74E+01	1.13E-01	.00E+00	27.5
0008	2.73E+01	2.73E+01	1.25E-01	.00E+00	27.5
0010	2.88E+01	2.88E+01	1.42E-01	.00E+00	28.9
0011	4.22E+01	4.22E+01	2.26E-01	1.20E+01	54.4
0012	2.93E+01	2.93E+01	1.77E-01	.00E+00	29.4
0112	3.02E+01	3.02E+01	1.87E-01	.00E+00	30.4
CONT	2.58E+01	2.58E+01	3.30E-02	2.41E+00	28.1
CONT	2.75E+01	2.75E+01	1.51E-01	.00E+00	27.6
CONT	2.79E+01	2.79E+01	1.22E-01	.00E+00	28.0
CONT	2.63E+01	2.63E+01	1.11E-01	.00E+00	26.4

SITE D PERSONNEL DOSIMETERS 3/30 TO 5/26/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
#1	2.46E+01	2.46E+01	8.13E-02	.00E+00	24.6
#2	3.53E+01	3.53E+01	2.95E-01	.00E+00	35.6
#3	2.73E+01	2.73E+01	1.38E-01	.00E+00	27.4
#4	2.75E+01	2.75E+01	9.72E-02	.00E+00	27.6
#5	4.22E+01	4.22E+01	1.84E-01	.00E+00	42.4
#6	3.05E+01	3.05E+01	3.89E-02	2.31E+00	32.9
#7	2.80E+01	2.80E+01	4.42E-02	.00E+00	28.1
#8	2.71E+01	2.71E+01	1.06E-01	.00E+00	27.2
#9	2.39E+01	2.39E+01	1.75E-01	.00E+00	24.0
#10	2.85E+01	2.85E+01	2.40E-01	.00E+00	28.7
#11	5.10E+01	5.10E+01	2.35E-01	.00E+00	51.2
#12	3.22E+01	3.22E+01	1.24E-01	.00E+00	32.3
#13	3.05E+01	3.05E+01	1.33E-01	.00E+00	30.7
#14	2.42E+01	2.42E+01	1.63E-01	.00E+00	24.4
#15	2.43E+01	2.43E+01	9.54E-02	.00E+00	24.4
#16	2.54E+01	2.54E+01	1.36E-01	.00E+00	25.6
#17	2.44E+01	2.44E+01	3.71E-02	.00E+00	24.5
#18	2.63E+01	2.63E+01	1.41E-01	.00E+00	26.5
#19	2.41E+01	2.41E+01	1.22E-01	.00E+00	24.3
#20	2.38E+01	2.38E+01	1.01E-01	.00E+00	23.9
#21	2.43E+01	2.43E+01	1.33E-01	.00E+00	24.7
#22	2.39E+01	2.39E+01	6.89E-02	.00E+00	23.9
#23	2.40E+01	2.40E+01	1.43E-01	.00E+00	24.1
#24	2.47E+01	2.47E+01	3.18E-02	1.52E+00	26.3
#25	2.51E+01	2.51E+01	8.48E-02	.00E+00	25.1

SITE D PERSONNEL DOSIMETERS - 5 5/26/77-7/22/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
#1	2.67E+01	2.67E+01	1.78E-01	.00E+00	26.9
#2	3.17E+01	3.17E+01	2.31E-01	.00E+00	31.9
#3	2.42E+01	2.42E+01	2.07E-01	.00E+00	24.4
#4	2.32E+01	2.32E+01	1.85E-01	.00E+00	23.3
#5	3.29E+01	3.29E+01	1.00E-01	.00E+00	33.0
#6	2.89E+01	2.89E+01	1.31E-01	.00E+00	29.1
#7	2.58E+01	2.58E+01	1.30E-01	.00E+00	25.9
#8	2.45E+01	2.45E+01	1.07E-01	.00E+00	24.6
#9	2.52E+01	2.52E+01	1.41E-01	.00E+00	25.4
#10	2.44E+01	2.44E+01	1.17E-01	.00E+00	24.5
#11	4.94E+01	4.94E+01	2.80E-01	.00E+00	49.7
#12	2.50E+01	2.50E+01	1.41E-01	.00E+00	25.2
#13	2.61E+01	2.61E+01	1.06E-01	.00E+00	26.2
#14	2.49E+01	2.49E+01	1.98E-01	.00E+00	25.1
#15	2.42E+01	2.42E+01	1.44E-01	.00E+00	24.4
#16	2.51E+01	2.51E+01	8.89E-02	.00E+00	25.2
#17	3.23E+01	3.23E+01	1.72E-01	.00E+00	32.5
#18	3.03E+01	3.03E+01	1.54E-01	.00E+00	30.3
#19	3.22E+01	3.22E+01	8.33E-02	.00E+00	32.3
#20	3.06E+01	3.06E+01	1.50E-01	.00E+00	30.7
#21	2.73E+01	2.73E+01	1.63E-01	.00E+00	27.3
#22	2.66E+01	2.66E+01	1.19E-01	.00E+00	26.7
#23	2.42E+01	2.42E+01	2.72E-01	.00E+00	24.5
#24	2.73E+01	2.73E+01	4.81E-02	4.27E-01	27.6
#25	2.55E+01	2.55E+01	8.15E-02	.00E+00	25.6

SITE D PERSONNEL DOSIMETERS 10/6 TO 12/2/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - MREM
#2	8.20E+01	8.20E+01	2.58E-01	.00E+00	82.2
#3	8.39E+01	8.39E+01	.00E+00	1.36E+01	97.5
#4	7.54E+01	8.22E+01	1.17E-01	1.08E+01	86.3
#5	8.53E+01	8.53E+01	5.32E-01	.00E+00	85.9
#6	8.30E+01	8.30E+01	2.69E-01	.00E+00	83.3
#7	7.60E+01	7.60E+01	2.56E-01	.00E+00	76.3
#8	8.24E+01	8.24E+01	6.05E-02	9.18E+00	91.7
#10	7.60E+01	7.60E+01	2.14E-01	.00E+00	76.2
#11	9.73E+01	9.73E+01	5.84E-01	.00E+00	97.9
#1UN	9.27E+01	9.27E+01	1.76E-01	5.74E+00	98.7
#9UN	8.76E+01	8.76E+01	.00E+00	7.66E+00	95.3
#12UN	8.94E+01	8.94E+01	3.10E-01	.00E+00	89.7

SITE D PERSONNEL DOSIMETERS 7/22 TO 10/6/77

I.D. #	PENETRATING	NON-PENETRATING	NEUTRON-THERMAL	NEUTRON-FAST	DOSE - M
#2	5.93E+01	5.93E+01	5.86E-01	.00E+00	59.6
#3	4.84E+01	4.84E+01	1.30E-01	.00E+00	48.6
#4	4.56E+01	4.56E+01	.00E+00	.00E+00	45.6
#5	6.00E+01	6.00E+01	1.01E-01	.00E+00	60.1
#6	5.67E+01	5.67E+01	1.01E-01	2.17E+00	58.9
#7	5.21E+01	5.21E+01	1.88E-01	.00E+00	52.3
#8	4.76E+01	4.76E+01	5.65E-01	.00E+00	48.2
#10	4.51E+01	4.51E+01	1.40E-01	.00E+00	45.3
#11	9.28E+01	9.28E+01	3.43E-01	9.98E+00	103.2

SITE D ENVIRONMENTAL DOSIMETERS 9/1 TO 11/23/76

I.D.#	700B	600B	700F	600F	400F
1-199	4.78E+01	7.35E-01	4.22E+01	6.68E-01	5.38E+01
2-194	3.97E+01	5.32E-01	3.73E+01	5.22E-01	4.27E+01
3-198	3.22E+01	5.63E-01	3.08E+01	5.07E-01	3.68E+01
4-192	3.33E+01	5.69E-01	3.21E+01	4.74E-01	3.52E+01
5-195	3.70E+01	5.74E-01	3.50E+01	4.71E-01	4.29E+01
6-189	3.48E+01	6.50E-01	3.35E+01	5.16E-01	4.06E+01
7-193	3.37E+01	5.41E-01	3.23E+01	4.99E-01	4.11E+01
8-196	2.94E+01	5.36E-01	2.84E+01	4.56E-01	3.52E+01
9-197	3.44E+01	5.79E-01	3.18E+01	4.61E-01	3.79E+01
10-190	3.06E+01	5.42E-01	3.05E+01	4.46E-01	3.89E+01
11-188	5.80E+01	7.16E-01	5.13E+01	6.23E-01	6.57E+01
12-191	3.32E+01	8.08E-01	3.36E+01	7.38E-01	3.89E+01
13-185	6.71E+01	2.13E+00	6.04E+01	1.62E+00	7.81E+01
14-182	6.54E+01	1.96E+00	6.25E+01	1.58E+00	7.53E+01
15-179	8.70E+01	2.39E+00	7.14E+01	1.99E+00	1.03E+02
C-166	1.70E+01	1.12E+00	1.76E+01	1.08E+00	1.82E+01
C-164	1.73E+01	1.05E+00	1.87E+01	1.08E+00	1.87E+01

SITE D ENVIRONMENTAL DOSIMETERS 2/15/77 TO 3/30/77

I.D.#	700B	600B	700F	600F	400F
078	3.62E+01	3.65E-01	3.44E+01	2.41E-01	3.23E+01
161	3.03E+01	1.19E-01	2.89E+01	1.29E-01	2.79E+01
101	2.50E+01	1.24E-01	2.67E+01	5.17E-02	2.35E+01
191	2.59E+01	9.02E-02	2.50E+01	5.35E-02	2.26E+01
198	3.07E+01	1.44E-01	2.83E+01	8.00E-02	2.68E+01
196	2.83E+01	1.69E-01	2.86E+01	1.92E-01	2.52E+01
199	2.63E+01	1.34E-01	2.39E+01	8.47E-02	2.17E+01
190	2.52E+01	9.18E-02	2.34E+01	7.77E-02	2.06E+01
195	2.65E+01	1.04E-01	2.48E+01	6.37E-02	2.17E+01
182	2.70E+01	1.11E-01	2.61E+01	6.71E-02	2.10E+01
192	3.92E+01	5.59E-02	3.75E+01	.00E+00	2.99E+01
144	2.74E+01	1.32E-01	2.78E+01	6.30E-02	2.31E+01
185	2.70E+01	1.39E-01	2.62E+01	6.97E-02	2.20E+01
188	5.59E+01	1.70E-01	4.82E+01	.00E+00	4.55E+01
166	4.91E+01	1.57E-01	4.76E+01	.00E+00	4.26E+01
179	9.28E+01	2.24E-01	7.92E+01	8.61E-02	2.32E+01
194	1.05E+02	6.30E-01	9.38E+01	3.24E-01	9.47E+01
189	2.74E+02	2.25E-01	2.73E+02	.00E+00	2.67E+02
107	1.01E+02	2.45E-01	8.97E+01	6.74E-02	9.17E+01
102	5.68E+01	3.32E-01	5.13E+01	2.61E-01	4.78E+01
189	1.05E+02	3.34E-01	1.08E+02	1.73E-01	1.04E+02
193	1.05E+02	5.19E-01	1.12E+02	2.21E-01	1.11E+02
224	9.08E+01	1.11E+00	8.31E+01	9.64E-01	8.88E+01
197	3.09E+01	1.15E-01	3.15E+01	1.67E-02	2.70E+01
106	2.56E+01	1.10E-01	2.56E+01	4.54E-02	2.34E+01

SITE D ENVIRONMENTAL DOSIMETERS 3/30 TO 5/26/77

I.D.#	700B	600B	700F	600F	400F
#1	4.97E+01	2.43E-01	4.34E+01	2.35E-01	6.40E+01
#2	4.06E+01	1.02E-01	3.86E+01	2.83E-02	5.85E+01
#3	3.43E+01	2.48E-02	3.16E+01	6.28E-02	4.91E+01
#4	3.30E+01	2.97E-02	2.99E+01	5.69E-02	4.09E+01
#5	3.88E+01	2.05E-02	3.46E+01	3.68E-02	4.72E+01
#6	3.66E+01	6.98E-02	3.67E+01	4.56E-02	4.70E+01
#7	3.36E+01	4.04E-02	3.12E+01	5.99E-02	3.79E+01
#8	3.06E+01	5.09E-02	2.78E+01	6.26E-02	3.61E+01
#9	3.40E+01	3.71E-02	3.17E+01	2.50E-02	4.00E+01
#10	3.36E+01	3.09E-02	3.22E+01	3.38E-02	4.20E+01
#11	5.70E+01	.00E+00	5.37E+01	2.09E-01	7.36E+01
#12-A	3.62E+01	3.05E-02	3.40E+01	2.22E-02	4.18E+01
#12-B	3.78E+01	1.31E-02	3.27E+01	2.80E-02	4.05E+01
#14	5.74E+01	6.43E-02	4.98E+01	5.22E-02	6.18E+01
#15	9.76E+01	1.72E-01	7.04E+01	1.67E-01	1.05E+02
#16-M	2.04E+02	3.79E-01	1.54E+02	7.21E-01	2.40E+02
#17-M	2.78E+02	1.69E-01	2.47E+02	1.01E-01	3.31E+02
#18-M	1.09E+02	9.02E-02	9.19E+01	8.94E-02	1.34E+02
#19-M	6.17E+01	2.43E-01	5.33E+01	3.40E-01	7.01E+01
#15-M	1.39E+02	2.74E-01	1.38E+02	3.83E-01	1.81E+02
#14-M	1.40E+02	3.93E-01	1.41E+02	2.96E-01	1.82E+02
#13-M	1.10E+02	1.25E+00	8.51E+01	1.27E+00	1.24E+02
CONT.	2.93E+01	6.18E-03	2.53E+01	5.08E-02	3.31E+01
CONT.	2.95E+01	3.66E-02	2.64E+01	3.92E-02	3.25E+01

SITE D ENVIRONMENTAL DOSIMETERS 5/26 TO 7/22/77

I.D.#	700B	600B	700F	600F	400F
#1	4.23E+01	1.60E-01	3.50E+01	2.17E-01	3.29E+01
#2	3.83E+01	3.97E-03	3.69E+01	2.87E-02	3.00E+01
#3	2.73E+01	5.64E-02	2.70E+01	2.06E-01	4.50E+01
#4	2.62E+01	5.64E-02	2.52E+01	4.75E-02	2.33E+01
#5	3.27E+01	4.46E-02	3.21E+01	7.39E-02	3.17E+01
#6	3.34E+01	1.22E-01	2.95E+01	1.31E-01	2.71E+01
#7	2.77E+01	7.08E-02	2.75E+01	9.46E-02	2.35E+01
#8	2.78E+01	4.44E-02	2.51E+01	9.12E-02	2.51E+01
#9	2.92E+01	5.17E-02	2.74E+01	5.90E-02	2.60E+01
#10	2.85E+01	7.09E-02	2.69E+01	8.35E-02	2.69E+01
#11	5.79E+01	1.95E-01	5.03E+01	1.66E-01	4.27E+01
#13	5.92E+01	6.73E-02	4.20E+01	1.17E-01	3.72E+01
#14M	1.44E+02	2.85E-01	1.55E+02	4.15E-01	1.49E+02
#15M	1.19E+02	2.16E-01	1.21E+02	3.15E-01	1.23E+02
#16M	1.50E+02	3.09E-01	1.15E+02	2.62E-01	1.24E+02
#17M	1.31E+02	1.38E-01	1.35E+02	1.88E-01	1.35E+02
#18M	1.10E+02	8.62E-02	1.08E+02	1.78E-01	1.09E+02
#19M	6.38E+01	3.03E-01	5.49E+01	2.60E-01	5.80E+01
#CON1	3.23E+01	8.06E-02	3.07E+01	5.17E-02	2.70E+01
#CON2	3.10E+01	7.82E-02	3.00E+01	6.24E-02	2.86E+01

SITE D ENVIRONMENTAL DOSIMETERS 7/22 TO 10/6/77

I.D.#	700B	600B	700F	600F	400F
#1	6.75E+01	3.68E-01	5.39E+01	2.67E-01	5.72E+01
#2	5.18E+01	7.31E-02	5.01E+01	.00E+00	4.76E+01
#3	3.95E+01	1.30E-01	3.66E+01	1.31E-01	3.79E+01
#4	4.37E+01	9.81E-02	3.48E+01	1.41E-01	3.59E+01
#5	5.08E+01	7.30E-02	4.31E+01	1.25E-01	4.63E+01
#6	5.13E+01	1.62E-01	4.33E+01	1.32E-01	4.62E+01
#7	4.64E+01	1.35E-01	3.86E+01	1.16E-01	4.20E+01
#8	4.31E+01	1.33E-01	3.65E+01	1.51E-01	3.82E+01
#9	4.58E+01	3.66E-02	3.99E+01	1.19E-01	4.15E+01
#10	4.62E+01	1.03E-01	7.72E+01	.00E+00	4.02E+01
#11	8.13E+01	4.88E-01	6.95E+01	5.24E-01	7.18E+01
#12	8.45E+01	9.93E-02	5.83E+01	2.58E-01	6.01E+01
#13	7.74E+01	1.23E+00	6.25E+01	1.34E+00	7.03E+01
#14	7.42E+01	1.40E-01	5.92E+01	2.32E-01	6.38E+01
#15	2.00E+02	7.59E-01	1.90E+02	5.20E-01	1.94E+02
#16	1.72E+02	4.40E-01	1.53E+02	5.69E-01	1.67E+02
#17	1.97E+02	9.39E-01	1.52E+02	7.77E-01	1.69E+02
#18	1.48E+02	5.92E-01	1.18E+02	3.23E-01	1.31E+02
#19	1.45E+02	2.24E-01	1.22E+02	2.18E-01	1.30E+02
#20	7.65E+01	4.12E-01	6.44E+01	3.22E-01	7.43E+01
#21	5.88E+01	9.25E-02	4.93E+01	1.76E-01	5.22E+01
#22	6.00E+01	2.11E-01	5.00E+01	1.54E-01	5.07E+01

SITE D ENVIRONMENTAL DOSIMETERS 10/7/77 TO 12/1/77

I.D.#	700B	600B	700F	600F	400F
#1	9.03E+01	2.23E-01	8.36E+01	3.48E-01	1.00E+02
#2	7.62E+01	3.53E-02	7.94E+01	7.97E-02	5.75E+01
#3	6.60E+01	8.32E-02	7.01E+01	1.37E-01	3.40E+01
#4	1.44E+01	1.91E-01	7.66E+01	7.80E-02	3.21E+01
#5	7.70E+01	1.20E-01	6.18E+01	7.07E-02	1.18E+01
#6	7.74E+01	3.43E-01	7.05E+01	0.21E-02	1.00E+01
#7	6.10E+01	1.30E-01	5.22E+01	1.20E-01	1.00E+01
#8	7.62E+01	8.61E-02	6.12E+01	1.22E-01	5.17E+01
#9	7.20E+01	1.00E-01	7.07E+01	0.07E-01	1.00E+01
#10	7.34E+01	1.31E-01	6.21E+01	1.03E-01	5.55E+01
#11	9.33E+01	3.13E-01	7.57E+01	2.44E-01	1.11E+01
#12	9.91E+01	1.07E-01	8.73E+01	1.42E-01	1.17E+01
#13	9.17E+01	1.73E-01	7.62E+01	7.12E-02	1.27E+01
#14	9.33E+01	7.97E-01	7.71E+01	3.82E-01	1.07E+01
#15	1.73E+02	4.37E-01	1.18E+02	3.45E-01	1.11E+01
#16	1.36E+02	1.71E-01	1.03E+02	3.17E-01	1.07E+01
#17	2.10E+02	3.77E-01	1.03E+02	1.01E-01	1.16E+02
#18	1.12E+02	7.73E-02	1.71E+02	1.40E-01	1.00E+01
#19	1.05E+02	3.37E-01	9.62E+01	3.01E-01	1.21E+02
#20	9.27E+01	9.38E-02	7.87E+01	2.14E-01	1.14E+01
#21	8.33E+01	4.27E-01	8.57E+01	2.11E-01	1.00E+01
#22	8.71E+01	1.70E-01	8.71E+01	2.11E-01	1.00E+01

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

OFFSITE

171	U.S. Nuclear Regulatory Commission Division of Technical Information and Document Control 7920 Norfolk Avenue Bethesda, MD 20014 Lake Barrett Division of Operating Reactors U.S. Nuclear Regulatory Commission Washington, DC 20555 S. Block Division of Operating Reactors U.S. Nuclear Regulatory Commission Washington, DC 20555	2	F. Swanberg, Jr., Chief Environmental Effects Research Division of Safeguards, Fuel Cycle and Environmental Research U.S. Nuclear Regulatory Commission Washington, DC 20555 A. A. Churm Chicago Patent Office U.S. Department of Energy 9800 South Cass Avenue Argonne, IL 60439
		2	DOE Technical Information Center Oak Ridge, TN 37830
2	J. Foulke Division of Safeguards, Fuel Cycle and Environmental Research Environmental Effects Research U.S. Nuclear Regulatory Commission Washington, DC 20555 W. E. Kreger, Chief Radiological Assessment Branch Division of Site Safety and Environmental Analysis U.S. Nuclear Regulatory Commission Washington, DC 20555 T. D. Murphy Office of Inspection and Enforcement U.S. Nuclear Regulatory Commission Washington, DC 20555 Stephen McGuire Office of Standards Development U.S. Nuclear Regulatory Commission Washington, DC 20555	2	Ray Carroll Arkansas Power & Light Arkansas Nuclear One P. O. Box 608 Russellville, AR 72801 2 M. Hedrick Niagara Mohawk Power Corp. Nine-Mile Point Nuclear Station P. O. Box 32 Lycoming, NY 13093 2 D. Stans Millstone Point Co. P. O. Box 12B Waterford, CT 06385 2 Howard Rogers Georgia Power Co. Plant E. I. Hatch P. O. Box 442 Baxley, GA 31513 D. B. Shipler Office of Waste Isolation Battelle Memorial Institute Columbus, Ohio 43201

No. of
Copies

ONSITE

25 Pacific Northwest Laboratory
 G. W. R. Endres (10)
 L. G. Faust (5)
 H. V. Larson
 C. M. Unruh
 Technical Information (5)
 Publishing Coordination (2)