REDUCING RESIDENTIAL ENERGY GROWTH WITH MORE EFFICIENT SPACE
HEATING EQUIPMENT*

Dennis L. O'Neal
Eric Hirst

Energy Division

MASTER

Oak Ridge National Laboratory
Oak Ridge, Tennessee 37830

ABSTRACT

Several energy-saving design changes in residential space heating systems were examined to determine their energy conservation potential and cost effectiveness. Changes in conventional and advanced systems (such as gas heat pumps) were considered. Energy savings as large as 26, 20, and 57% were estimated for design changes in conventional gas, oil, and electric space heating systems, respectively. These changes increased capital cost of the three systems by 27, 16, and 26%. For advanced gas and electric systems, energy savings up to 45 and 67%, respectively, were calculated. The design changes needed to produce these energy savings increased capital costs 80 and 35%.

The energy use and cost relationships developed for the space heating systems were used as input to the ORNL residential energy use simulation model to evaluate the effect of space heating improvements on national energy use to the year 2000. Results indicated a large reduction in energy use if improved conventional and advanced systems were made available to consumers and if consumers minimized lifecycle costs when purchasing these systems.

* Research sponsored by the Office of Conservation and Solar Applications, and the Energy Information Administration, U. S. Department of Energy under contract W-7405-eng-26 with the Union Carbide Corporation.

By acceptance of this article, the publisher or recipient acknowledges the U.S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering the article.

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

REDUCING RESIDENTIAL ENERGY GROWTH WITH MORE EFFICIENT SPACE HEATING EQUIPMENT

Dennis L. O'Neal
Eric Hirst

INTRODUCTION

From 1960 to 1975, energy use for residential space heating grew from 5.1 EJ* to 9.1 EJ.^{1,2} The energy used for space heating accounted for over half the total energy used in the residential sector during this time. Because space heating accounts for such a large share of residential energy use, improvements in new space heating systems could have significant long-term energy conservation effects.

The HVAC (Heating, Ventilating and Air-Conditioning) industry is currently developing and marketing more efficient gas, oil, and electric space heating systems that use less energy than systems currently in use. Some of the new systems incorporate conventional design changes (such as the flue damper or electric ignition for gas furnaces), while others are advanced technology systems (such as the gas heat pump and the ACES [Annual Cycle Energy System]). This paper examines the energy saving and increased capital cost expected with these more efficient systems (both conventional and advanced) compared to representative systems currently in use.³

The potential impact these more efficient systems might have in reducing growth of residential energy use is also examined. The energy and cost estimates are used as inputs to the Oak Ridge National Laboratory (ORNL) engineering-economic model of residential energy use.⁴ Estimates of the distribution of new space heating equipment and residential energy use are provided for selected years from 1978 to 2000.

* 1 EJ = 10^{18} J.

MARKET TRENDS

Table 1 shows the number of space heating systems in use for the years 1950 to 1975.⁵ During this period, the percentage of homes heated by gas grew from 26% to 56%. In 1975, oil and electric heating systems accounted for 23% and 13%, respectively, of all residential heating systems. However, in the five years from 1970 to 1975, the number of homes heated by electricity increased 86%. Much of this growth is attributable to the large percentage of new single family homes with electric heating. Forty nine percent of single family homes built in 1976 had electric heating,^{6,7} up from 31% in 1971.

Table 2 shows a breakdown of the eight most common heating systems in existing single-family residences for the years 1970, 1973, 1974, and 1975.⁵ For both gas and oil, the central forced-air system was the most common system for each of the four years. The forced-air central furnace was chosen as the representative system for analysis of gas and oil heating.

Built-in electric systems (which include baseboard and ceiling cable) were the most common electric systems in existing homes from 1970 to 1975. However, the number of homes heated with central electric furnaces increased by 255% during this time compared to 50% for built-in electric systems. In 1975, electric furnaces accounted for 52% of new electrically heated residences compared to 26% for built-in systems.⁸ Because of its rapid growth and large share of the electric heating market in recent years, the central forced-air furnace was chosen as the representative electric heating system.

Table 1. Household space heating systems ownership: 1955-1975^a
(millions)

Year	Electricity	Gas	Oil	Other	None	Total
1950	0.3	11.1	9.5	20.6	0.6	42.1
1960	1.0	22.9	17.2	11.6	0.5	53.0
1970	4.9	35.0	16.5	6.7	0.4	63.4
1973	7.2	38.5	17.3	6.0	0.5	69.3
1974	8.4	39.4	16.9	5.6	0.5	70.8
1975	9.1	40.9	16.3	5.7	0.4	72.5

^aDeveloped from refs. 5 and 6.

Table 2. Breakdown (by percent) of eight popular heating systems
in existing single-family homes^a

System	Year				% Change from 1970 to 1975
	1970	1973	1974	1975	
Gas central forced-air	33.0	36.5	32.2	32.8	-1
Oil central forced-air	10.8	10.9	12.0	11.8	9
Oil boiler	7.7	7.9	7.5	7.4	-4
Gas floor or wall furnace	7.9	8.7	7.2	7.0	-11
Built-in electric	4.4	4.9	6.4	6.6	50
Electric central forced- air furnace ^b	0.9	2.0	2.6	3.2	255
Gas boiler	5.0	4.6	4.2	4.0	-20
Electric heat pump ^b	0.8	1.1	1.2	1.3	63
Other	29.5	23.4	26.7	25.9	-12

^aDeveloped from ref. 5.

^bDeveloped from estimates given by Edison Electric Institute and ref. 5.

GAS SYSTEMS

The annual energy requirements and capital costs of several advanced gas heating systems and energy conserving design options for a representative gas furnace are examined in this section. The energy usage data were developed from recent literature,⁹⁻¹⁴ while cost data were obtained from manufacturers and dealers of gas heating equipment and available literature.^{9,14} Complete details are given in ref. 3.

The reported energy saving (and capital cost) of each of the energy conserving design options varied widely in the above references. The Appendix gives the range of energy savings and capital cost increases reported in these references.

The base house used in this analysis is located in Philadelphia. It has a design heating load of 43 MJ/hr and an annual heating load of 52.3 GJ. The base furnace is an atmospheric unit, located within the conditioned space and double oversized.* Reference 15 suggests that double oversizing of residential gas furnaces is "typical" practice. Characteristics of the reference gas heating system are listed in Table 3.

Seasonal performance factors (SPF) from available literature are averaged to determine the SPF and annual energy consumption for particular energy conservation design options. (See Appendix for SPFs and details on calculations.) The SPF is defined as:

$$\text{SPF} = \frac{\text{Total annual heat energy provided by the heating system}}{\text{Total annual fuel energy used by the heating system}}$$

Total energy used by the system includes the fuel used for heating plus auxiliary energy such as electricity used for air distribution.

*. A heating system is properly sized when its output matches the design heating load of the house. A double oversized system has a rated output twice the design heating load of the house.

Table 3. Characteristics of the reference gas heating system

Furnace system	Ductwork
Location: within living area	Insulation: 2.5cm fiberglass
Size: input - 116 MJ/hr output - 89 MJ/hr	Heat loss 3.4 GJ/yr
Type: Atmospheric combustion with standing pilot	Total cost (1975-\$) - \$1310
Efficiency: steady state - 77% seasonal - 61%	
Annual fuel consumption: 89.6 GJ	Gas price: \$1.78 per GJ

Energy savings and installed cost increases are evaluated for several energy saving design modifications to the base furnace (see Fig. 1). These include:

Properly sizing the unit - With the reference furnace properly sized, the calculated annual energy saving is 4.2 GJ.^{10,12} For a natural gas price of \$1.78 per GJ (the 1975 national average price), the annual saving is \$6.70. The saving in capital cost with the properly sized unit is \$150.

Adjusting the bonnet thermostat to 2.8°C above room temperature - Gas furnaces have a thermostat that senses and controls the bonnet air temperature at which the circulating air fan comes on and off. Typically, the fan is set to come on between 52 and 60°C and turn off at 38°C.¹⁰ Adjusting the thermostat so the fan comes on and off at 2.8°C above room temperature reduces annual energy use by 5.5 GJ, decreases fuel cost by \$9, and incurs no increase in capital cost.^{10,12,14}

Installing an automatic flue damper - During the off cycle, heat escapes up the flue of the standard atmospheric combustion furnace. An automatic flue damper closes the flue during the off cycle to prevent heat from escaping. Adding a flue damper to a furnace increases the installed cost \$85. The calculated annual energy reduction is 10.3 GJ; this yields an annual saving in fuel cost of \$17 and a payback period of 5 years.^{11,12,14}

Installing 5.1 cm of fiberglass duct insulation instead of 2.5 cm - Installing 5.1 cm of insulation adds \$20 to the capital cost, decreases annual energy use 2.2 GJ and saves \$3.50 in fuel costs. The payback period is 5 years.

Switching to a sealed combustion unit - A sealed combustion furnace has its combustion chamber separated from the conditioned air in the house. Its combustion air is drawn directly from the outside and, in many cases, is preheated by the hot combustion products in the flue. A sealed combustion

unit costs about \$140 more than a comparable atmospheric combustion unit.

The annual fuel and cost savings are 11.5 GJ and \$18, respectively.^{10,11,12,14}

Increasing the steady state efficiency to 84% - The theoretical upper limit of the steady state efficiency before water starts to condense on the heat exchanger or flue is about 84%.¹²

To approach this limit, several furnace modifications must be made: redesigning the heat exchanger, constructing the heat exchanger from rust resistant materials such as aluminized steel, and adding an induced draft fan.^{12,14} The cost of the unit increases \$115. The calculated annual energy and cost savings are 14.7 GJ and \$24, respectively. The payback period is 5 years.

Installing electric ignition - The pilot light in the base furnace operates continuously. When the circulating fan (blower) is not in operation, the pilot heat is not delivered to the living area. The calculated energy loss is 4.2 GJ/yr.^{10,11,12,14} With electric ignition, this loss is eliminated. This adds \$90 to the cost of the furnace and reduces annual fuel costs \$6.70. The payback period is 13 years.

Advanced gas heating systems - There are several advanced gas heating systems being developed for residential applications. These include organic fluid absorption heat pumps, Stirling/Rankine heat pumps, and pulse combustion furnaces. References 9, 14, and 16 give descriptions of these systems.

The projected heating SPF's for the three systems are given in Table 4.⁹

Table 4. Estimates of the SPF for three advanced gas heating systems^a

System	SPF
Organic fluid absorption heat pump	1.10
Stirling/Rankine heat pump	1.41
Pulse combustion furnace	0.93

^a Conventional gas furnace SPF is 0.61.

Only price estimates for the organic fluid absorption heat pump were available. The heat pump* used with the base house has an estimated installed cost of \$3540.⁹

OIL SYSTEMS

The energy use estimates for the oil furnace are developed from refs. 9, 12, 14, 15, and 17 (see Appendix for details). Cost data are obtained from manufacturers and dealers of oil heating equipment. The same house and weather conditions used for the gas furnace are also used for the oil furnace analysis. The furnace is located within the conditioned space and double oversized. The characteristics of the base oil heating system are listed in Table 5.

Energy savings and installed cost increases are evaluated for the same design options listed for the gas furnace with the exception of electric ignition. Oil furnaces already come equipped with electric ignitors.

The effect of design changes to the base furnace is shown in Fig. 5. The energy conservation potential for the oil furnace is smaller than the gas furnace. The energy use of the furnace can be decreased 20% for an added capital cost of \$290, with a payback period of 7 years.

ELECTRICAL SYSTEMS

The energy use and cost data for electrical heating systems are developed from refs. 9 and 18. The base house used for gas and oil systems is also used to evaluate the effects of conservation options for electrical heating systems. However, the house is placed in two cities - Cleveland and

* Because the gas heat pump provides both cooling and heating, while gas furnaces provided only heating, the price of the heat pump was adjusted to account for its cooling capabilities. The price of a central air conditioning system (\$1200) was subtracted from the price of the organic fluid absorption heat pump. This yielded a price of \$2340 for the heat pump for comparison with the furnace.

Table 5. Characteristics of the base oil heating system

Furnace system	Ductwork
Location: within living area	Insulation: 2.5cm fiberglass
Size: input - 116 MJ/hr output - 89 MJ/hr	Heat loss: 3.4 GJ/yr
Type: flame retention headburner	
Efficiency: steady state - 77% seasonal - 66%	
Annual fuel consumption: 82.8 GJ	
Total Cost of System (1975-\$) - 1840	Fuel oil price: \$2.95 per GJ

Atlanta. The two cities are used to provide sufficient climatic variation to realistically evaluate annual heat pump performance, which is very climate dependent. The characteristics of the base house for the two cities are listed in Table 6.⁹ A central, forced-air electric furnace was used as the reference heating system. The base furnace in the Cleveland house is rated at 55.4 MJ/hr,^{*} while the one in the Atlanta house is rated at 38.2 MJ/hr.⁹

Table 6. Characteristics of the base house with electric heating

Item	Location	
	Cleveland	Atlanta
Living area (ft ²)	1850	1850
Design heating load (MJ/hr)	44.3	35.1
Annual heating load (GJ)	74.6	26.8

The installed costs of the central electric furnaces (plus air conditioning) are \$2800 and \$2490 for Cleveland and Atlanta, respectively.⁹ The ductwork and duct insulation, and their associated prices are the same as those used previously. The electricity price is \$0.032 per kWhr (1975 national average).

Conventional heat pumps save significant amounts of energy compared to the base heating system. Even a representative 1975 heat pump with a coefficient of performance (COP)[†] of 1.6 at -8°C and 2.6 at 8°C ambient temperature has a seasonal performance factor of 1.68 and 1.97 in Cleveland and Atlanta, respectively.⁹ For Cleveland, this yields an annual reduction

^{*} All electrical energy figures in this section are end use energy.

[†] Coefficient of performance is defined as:¹⁹

$$\text{COP} = \frac{\text{Heat delivered by the heat pump}}{\text{Electric energy used by the heat pump}}$$

of \$250 in fuel bills over the central electric furnace. For Atlanta, a \$130 reduction is calculated. The payback period is one year in Cleveland and two years in Atlanta.

The energy conserving options are from refs. 9 and 18. The options from ref. 9 were primarily heat pump designs already on the market (labeled as "high efficiency" heat pumps). *

Various optimized heat pump designs were considered in ref. 18 using a heat pump computer simulation program. The primary changes in component design dealt with the compressor: placing the compressor indoors, using a two speed compressor motor, and using two equally sized compressors. The heat pump systems were optimized for these three design changes at different design (or balance) temperatures. † Other design changes in the optimization included: indoor and outdoor coil effective size and air flow rates, fin spacing, number of rows of tubes, fraction of indoor coil devoted to liquid subcooling, and indoor duct system effective size.

By placing the heat pump compressor indoors, heat loss from the compressor shell is utilized inside the house. This modification can provide a gain of up to 20 percent in cold day capacity and COP.¹⁸ Using either a two speed compressor motor or two equally-sized compressors allows the heat pump to better match the heating load, thus reducing the on-off cycling at lower heating loads and saving energy.

* Very little information was given in ref. 9 on the physical characteristics of the "high efficiency", I, II, and III heat pumps.

† Balance temperature is the temperature below which resistance heating is first needed to augment the heat pump.

The annual energy use and capital cost of the energy conservation design options for electric heating systems are shown in Figs. 3 and 4 for Cleveland and Atlanta, respectively. Even though the percentage energy saved for a particular option is larger in Atlanta than Cleveland, the energy saved is larger in Cleveland because of the larger heating load and longer heating season.* The payback period for a particular design option is also shorter in Cleveland than in Atlanta.

NATIONAL IMPACTS OF IMPROVED SPACE HEATING SYSTEMS

The ORNL residential energy use simulation model⁴ is used to evaluate the effects on national energy use and household economics of adopting combinations of the previously discussed space heating design options. Four cases are run with the simulation model. In the first (baseline), the market for purchasing new heating systems is allowed to operate under free market conditions and improvements in conventional systems are available during the projection period (1977-2000). The input data for this case are developed from the energy use versus capital cost curves for improvements in conventional heating systems (Figs. 1-4). For the baseline, space heating energy grows from 8.9 EJ per year in 1977 to 12.5 EJ per year in 2000, an average growth of 1.8%/year (see Fig. 5).

* No SPF's for the advanced systems in Atlanta were available since ref. 19 considered only heat pump performance in Northern climates (Cleveland). To estimate SPF's of the advanced systems in Atlanta, SPF improvement information was adapted from ref. 9. The average improvement in seasonal performance for the conventional heat pumps in moving from Cleveland to Atlanta was first calculated. This improvement was 18%. Each of the seasonal performance factors of the advanced heat pumps were then increased by this same amount to obtain an estimate of their SPF values in Atlanta.

The second case assumes that advanced heating systems become available to consumers in 1980. These advanced systems include gas heat pumps and advanced electric heat pumps. Space heating energy use grows at an average annual rate of 1.6%. The cumulative energy use (1977-2000) is 3.9 EJ below the baseline (see Table 7). The net economic benefit is \$3.4 billion.*

The third case is the same as the second case except it assumes consumers minimize life-cycle costs when purchasing new heating systems beginning in 1980.† (The previous cases assume consumers would respond to fuel and capital cost increases as they have in the past under free market conditions.) The average annual space heating energy growth rate is cut to 1.1%. The resulting economic benefit to consumers from purchasing equipment on a life cycle cost basis is \$3.7 billion for the 1977-2000 period.

The ratio of economic benefits (reduced fuel bills) to economic costs (higher equipment costs) for cases 2 and 3 are 9.5 and 1.5, respectively. These results indicate that improvements in space heating performance can yield large energy and economic benefits to the nation.

If no improvements (i.e., constant equipment SPF) are made in space heating equipment through the year 2000, how would this affect energy use and fuel bills in the residential sector? This option is explored in the fourth case. Space heating energy use grows at an average annual rate of 2.5%. This is a 39% higher growth rate than the baseline and over 100% higher than the third case. Cumulative energy use is 16.1 EJ greater than in the baseline. There is a net economic loss of \$13.6 billion because of larger fuel expenditures. This case provides an estimate of the upper limit of residential space heating energy use through the end of this century.

* Present worth at 8% real interest rate

† Life-cycle cost is defined as the sum of the capital cost of the heating system plus the present worth of yearly operating costs discounted at 8%.

Table 7. Cumulative (1977-2000) effects of reducing residential space heating energy use

Case	Description	Space heating energy savings (EJ) 1977-2000	Present worth at 8% real interest (billion 1975-\$)			Benefit/cost
			Increased equipment expenditures (cost)	Fuel expenditures savings (benefit)	Net economic benefit	
1	Baseline (Free market)					
2	Baseline plus introduce advanced systems in 1981	3.9	0.4	3.8	3.4	9.5
3	Baseline plus advanced systems plus consumer minimizes life cycle costs	15.0	7.2	10.9	3.7	1.5
4	No space heating Equipment improvement	16.1	-2.4	-16.0	-13.6	0.2

CONCLUSION

A variety of technological improvements are available to reduce energy use in residential space heating systems. The energy saving possible through implementation of these improvements is surprisingly large (over 50% on some systems). At today's fuel prices, many of these design changes are cost effective with payback periods less than five years. As fuel prices increase, the economic attractiveness of these changes will increase.

The results presented suggest that these technological improvements can potentially reduce growth of residential space heating energy use to 1.0% per year compared to the historical 4% per year from 1950 to 1973.

REFERENCES

1. E. Hirst and J. Jackson, "Historical Patterns of Residential and Commercial Energy Use," *Energy*, 2(2), pp. 131-140, Great Britain, 1977.
2. S. H. Dole, *Energy Use and Conservation in the Residential Sector: A Regional Analysis*, R-1641-NSF, June 1975, Rand Corporation, Santa Monica, CA.
3. D. L. O'Neal, *Energy and Cost Analysis of Residential Heating Systems*, Oak Ridge National Laboratory, ORNL/CON-25, July 1978.
4. E. Hirst and J. Carney, *The ORNL Engineering-Economic Model of Residential Energy Use*, Oak Ridge National Laboratory, ORNL/CON-24, July 1978.
5. Bureau of the Census, *Census of Housing and Annual Housing Survey*, Tapes for 1970, 1973, 1974, and 1975, Department of Commerce, Washington, D. C.
6. Bureau of the Census, *Construction Report*, Series C25, "Characteristics of New Housing: 1976," Department of Commerce, Washington, D. C., 1977.
7. NAHB Research Foundation, Inc., *Thermal Characteristics of Single-Family Detached, Single-Family Attached, Low-Rise Multi-Family, Mobile Homes*, prepared for the Office of Technology Assessment, Congress of the United States, Washington, D. C., October 1977.
8. NAHB Research Foundation, Inc., "Housing Statistics and Housing Characteristics Related to Energy Conservation in Tract and Non-Tract Homes Built in the 1950-1964 Time Period," prepared for the Federal Energy Administration, September 1974.
9. Gordian Associates, Inc., *Heat Pumps Technology: A Survey of Technical Developments and Market Prospects*, CONS/2127-d (draft), prepared for the Energy Research and Development Administration, Washington, D. C., July 1977.
10. E. C. Hise and A. S. Holman, *Heat Balance and Efficiency Measurements of Central, Forced-Air, Residential Gas Furnaces*, ORNL-NSF-EP-88, October 1975.
11. J. Chi, G. Kelly, and D. Didion, "Use of Computer Model to Evaluate Energy Savings Potentials for Gas-Fired Furnaces," Presented at the *Sixth International Heat Transfer Conference*, 1977.
12. Hittman Associates, *Development of Residential Buildings Energy Conservation Research, Development and Demonstration Strategies*, HIT-681, Prepared for the Energy Research and Development Administration, Washington, D. C., August 1977.

13. G. K. Gable and K. Koeing, "Seasonal Operating Performance of Gas Heating Systems with Certain Energy-Saving Features," *1977 Transactions of the American Society of Heating, Refrigerating and Air Conditioning Engineers*, Vol. 83, Part I, pp. 850-864, New York, 1977.
14. Booz, Allen, and Hamilton, Inc. and the Institute of Gas Technology, "Energy Efficiency Program For Appliances, Furnaces, Home Heating Equipment, and Humidifiers," Prepared for the Federal Energy Administration, Washington, October 1977.
15. U. Bonne, J. F. Janssen, and R. H. Tonborg, "Efficiency and Relative Operating Cost of Central Combustion Heating Systems: IV. Oil-Fired Residential Systems," *1977 Transactions of the American Society of Heating, Refrigerating and Air Conditioning Engineers*, Vol. 83, Part I, pp. 893-904, New York, 1977.
16. L. A. Sarkes, J. A. Nicholls, M. S. Menzer, "Gas Fired Heat Pumps: An Emerging Technology," *ASHRAE Journal*, pp. 36-41, March 1977.
17. J. E. Janssen and U. Bonne, "Improvement of Seasonal Efficiency of Residential Heating Systems," *Journal of Engineering for Power*, Transactions of the ASME, pp. 329-334, July 1977.
18. H. S. Kirschbaum, S. E. Veyo, et al., *An Investigation of Methods to Improve Heat Pump Performance and Reliability in a Northern Climate*, Vol. I, II, and III, EPRI EM-319, Institute, Palo Alto, CA, January 1977.
19. G. E. Kelly and J. Bean, "Dynamic Performance of an Air-to-Air Heat Pump," *Proceeding of the 2nd Annual Heat Pump Technology Conference*, Oklahoma State University, Stillwater, OK, October 1976.
20. G. T. Hollowell, "Pulse Combustion - An Efficient, Forced Air, Space Heating Systems," Paper J.4., *Proceedings of the Conference on Improving Efficiency and Performance of HVAC Equipment and Systems II*, Purdue University, West Lafayette, Indiana, April 1976.
21. D. W. Turner, R. E. Holmes, J. J. Kraus, and J. F. Coburn, "Efficiency Factors for Domestic Oil Heating Units," Paper 1c, *Proceedings of the Conference on Improving Efficiency and Performance of HVAC Equipment and Systems*, Purdue University, West Lafayette, Indiana, Oct. 1974.
22. G. Peoples, "Sealed Oil Furnace Combustion System Reduces Fuel Consumption," Paper 5a, *Proceedings of the Conference on Improving Efficiency and Performance of HVAC Equipment and Components*, Purdue University, West Lafayette, Indiana, Oct. 1974.

APPENDIX

COST AND SPF INFORMATION FOR SPACE HEATING SYSTEMS CALCULATIONS

This appendix provides details on the variation in energy use and capital cost values for gas and oil heating systems. Tables A-1 and A-2 summarize the performance and cost information for gas and oil systems, respectively. The reported ranges in values for the percent reduction in seasonal fuel use and increase in capital cost (in 1975-\$) for conservation options are given in these tables. The source for these values are footnoted in the tables.

The SPF for each option is calculated by averaging the SPF from available references. For the base gas furnace, SPFs of 0.517, 0.64, 0.639, and 0.627 were reported from refs. 10, 11, 12, and 14, respectively. The value used in this report is 0.61. The reported range in SPF is 0.517 to 0.64. For an example of calculating the reduction in energy use for an option, consider the switch to sealed combustion for the gas furnace. The reported SPFs are 0.696, 0.677, 0.668, and 0.759 from refs. 10, 11, 12, and 14, respectively. The average SPF is 0.670 which provides a reduction in fuel use of 14%. The reported reduction in these references ranged from 4% (ref. 12) to 26% (ref. 10).

The SPF for the oil furnace is 0.66. This was calculated from values of 0.674, 0.703, 0.64, and 0.615 in refs. 12, 14, 15, and 17, respectively.

The range in capital costs increases was developed from values given in the literature and phone conversations with manufacturers and dealers. In general, costs varied widely. For instance, installation cost on a gas furnace ranged from \$115 to \$216. Other cost variations are shown in Tables A-1 and A-2.

Table A-1. Seasonal performance and capital cost information for gas heating systems

Option	SPF ^a used	Percent reduction in seasonal fuel use		Capital cost increase for option (1975 \$)	
		This report	Reported range in values	This report	Reported range in values
Base	0.61 ^{b,c,d,e}	—	—	—	—
1) Properly sized furnace	0.64 ^{b,d}	5	4 to 14 ^{b,d}	-150	60 to 240 ^f
2) Bonnet thermostat set 5°F above room temp.	0.65 ^{b,d,e}	6	2 to 21 ^{b,d,e}	0	0
3) Automatic flue damper	0.69 ^{c,d,e}	11	4 to 17 ^{c,d,e,g}	85 ^f	70 to 110 ^{e,f}
4) Duct insulation increased to 2"	0.61 ^{b,d}	2	0 to 3 ^{b,d,i}	20 ^f	0 to 90 ^f
5) Sealed combustion	0.70 ^{b,c,d,e}	13	4 to 26 ^{b,c,d,e}	140 ^{e,h}	65 to 218 ^{e,h}
6) Increase steady state efficiency to 84%	0.73	16	6 to 25 ^{c,d,e}	115 ^{e,f}	100 to 130 ^{e,f}
7) Electric ignition	0.64 ^{b,c,d,e}	5	2 to 10 ^{b,c,d,e}	90 ^f	52 to 123 ^{e,f}
8) Organic fluid absorption heat pump	1.10 ⁱ	45	N.A. ^k	1040 ⁱ	N.A. ^k
9) 3,7	0.74 ^{c,e}	17	14 to 20 ^{c,e,f}	180 ^f	134 to 233 ^{e,f}
10) 6,7	0.78 ^{c,d,e}	22	11 to 28 ^{c,d,e}	210 ^{e,f}	152 to 253 ^{e,f}
11) 2,6	0.75 ^d	19	N.A. ^k	115 ^f	100 to 130 ^{e,f}
12) 3,6,7	0.80 ^{c,d,l}	24	20 to 24 ^{c,d,l}	295 ^{e,f}	222 to 363 ^{e,f}
13) 5,6,7	0.82 ^{d,e}	26	17 to 28 ^{d,e}	350 ^{e,f,h}	217 to 471 ^{e,f,h}
14) 2,5,6,7	0.82 ^d	26	N.A. ^k	350 ^{e,f,h}	217 to 471 ^{e,f,h}

^a SPF values used in this report were developed by averaging SPF values from each reference for a particular option.

^b Reference 10.

^c Reference 11.

^d Reference 12.

^e Reference 14.

^f Survey of dealers and manufacturers.

^g Reference 22.

^h Estimated from sealed combustion units on the market.

ⁱ Reference 9.

^j Reference 20.

^k No range available, only one value.

^l Reference 13.

Table A-2. Seasonal performance and capital cost information for oil furnaces

Option	SPF ^a used	Percent reduction in seasonal fuel use		Capital cost increase for option (1975 \$)	
		This report	Reported range in values	This report	Reported range in values
Base	0.66 ^{b,c,d,e}	--	--	--	--
1) Properly sized furnace	0.69 ^{b,d}	4	1 to 9 ^{b,d}	250 ⁱ	140 to 360 ⁱ
2) Bonnet thermostat set 5°F above room temp.	0.70 ^{b,c}	6	1 to 3 ^{b,c}	0	0
3) Automatic flue damper	0.72 ^{b,c,d}	8	5 to 15 ^{b,c,d,f}	85 ^{c,i}	70 to 110 ^{c,i}
4) Duct insulation increased to 2"	0.66	2	0 to 3 ^{b,k}	20 ⁱ	0 to 90 ⁱ
5) Sealed combustion	0.74 ^{b,c,d,g}	11	4 to 18 ^{b,c,d,g}	150 ^{c,j}	93 to 222 ^{c,j}
6) Increase steady state efficiency to 84%	0.80 ^{b,c}	18	12 to 17 ^{b,c}	140 ^{c,i}	100 to 206 ^{c,i}
7) 5,6	0.79 ^b	16	N.A. ^h	290 ^{c,i,j}	193 to 428 ^{c,i,j}
8) 2,5	0.71 ^b	7	N.A. ^h	150 ^{c,j}	93 to 222 ^{c,j}
9) 2,6	0.79 ^b	16	N.A. ^h	140 ^{c,i}	100 to 206 ^{c,i}
10) 3,6	0.80 ^b	18	N.A. ^h	225 ^{c,i,j}	170 to 316 ^{c,i,j}
11) 2,5,6	0.82 ^b	20	N.A. ^h	290 ^{c,i,j}	193 to 428 ^{c,i,j}

^aSPF values used in this report were developed by averaging SPF values from each reference for a particular option.

^bReference 12.

^cReference 14.

^dReference 15.

^eReference 17.

^fReference 21.

^gReference 22.

^hNo reporting range available.

ⁱSurvey of dealers and manufacturers.

^jEstimated from sealed combustion units on the market.

^kReference 10.

Fig. 1. Annual space heating energy use vs installed cost for design changes in a gas heating system in Philadelphia. The price of a central air conditioner was subtracted from the price of the organic fluid absorption heat pump.

Fig. 2. Annual space heating energy use vs installed cost for design changes in an oil heating system in Philadelphia.

Fig. 3. Annual space heating energy use vs installed cost for design changes in an electric heating system in Cleveland. The base system included central electric furnace and air conditioner.

Fig. 4. Annual space heating energy use vs installed cost for design changes in an electric heating system in Atlanta. The base system included central electric furnace and air conditioner.

ORNL-DWG 78-3554

Fig. 5. Alternative projections of residential space heating energy use to the year 2000.

KEY WORDS

Conservation

Furnace

Gas-Fired

Heat-Pump

Oil-Fired

Residential

Space-Heating