


12
11/25/91 *Jim* ①

PNL-7763

UC-350

Fort Lewis Electric Energy Baseline and Efficiency Resource Assessment



October 1991

Prepared for the U.S. Department of Energy
Federal Energy Management Program
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute



DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

Printed in the United States of America

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831;
prices available from (615) 576-8401. FTS 626-8401.

Available to the public from the National Technical Information Service,
U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

PNL--7763

DE92 003342

FORT LEWIS ELECTRIC ENERGY BASELINE
AND EFFICIENCY RESOURCE ASSESSMENT

T. J. Secrest
J. W. Currie
J. G. DeSteeze
J. A. Dirks

T. J. Marseille
G. B. Parker
E. E. Richman
S. A. Shankle

October 1991

Prepared for
the U.S. Department of Energy
Federal Energy Management Program
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

ABSTRACT

In support of the U.S. Department of Energy Federal Energy Management Program, the Pacific Northwest Laboratory is developing a fuel-neutral approach for identifying, evaluating, and acquiring all cost-effective energy projects at federal installations. Fort Lewis, a U.S. Army installation near Tacoma, Washington, was selected as the pilot site for developing this approach. This site was chosen in conjunction with the interests of the Bonneville Power Administration to develop programs for its federal sector customers and the Army Forces Command to develop an in-house program to upgrade the energy efficiency of its installations.

This report documents the electricity assessment portion of the approach, providing an estimate of the electricity use baseline and efficiency improvement potential for major sectors and end uses at the Fort. Although the assessment did not identify all possible efficiency improvement opportunities, it is estimated that electricity use can be reduced by at least 20% cost-effectively at the \$0.045/kWh marginal cost of electricity in the Pacific Northwest.

SUMMARY

The mission of the U.S. Department of Energy (DOE) Federal Energy Management Program (FEMP) is to lead the improvement of energy efficiency and fuel flexibility within the federal sector. Through Pacific Northwest Laboratory, FEMP is developing a fuel-neutral approach for identifying, evaluating, and acquiring all cost-effective energy projects at federal installations. FEMP believes that the Bonneville Power Administration (Bonneville), as part of the federal sector and DOE, can actively support the identification, characterization, and procurement of electric energy efficiency resources from federal customers within the Bonneville service territory. For this reason, FEMP approached Bonneville with the proposal to develop a pilot program with a large federal customer in Bonneville's service territory. The purposes of that program would be to identify and acquire all cost-effective electric energy efficiency resources within the customer's infrastructure. FEMP emphasized that, to the extent possible, the pilot program should not require the federal customer to either procure an energy services contractor or provide capital funds. FEMP has identified these two requirements as major obstacles in the path of federal agencies/installations attempting to aggressively pursue energy efficiency programs. Bonneville agreed that significant energy efficiency resources existed within the federal customer base, that a pilot program was warranted, and that it should be designed to overcome these obstacles. FEMP and Bonneville agreed to fund the Pacific Northwest Laboratory (PNL), FEMP's lead laboratory, to identify and recruit a federal customer and to conduct a fuel-neutral efficiency assessment at the federal facility.

It was agreed that the pilot program should be designed to be transferable to other federal customers within the Bonneville service territory. To have maximum impact, the program should also be transferable to federal customers outside of Bonneville's service territory. This condition meant that the program would likely have greater transferability if the federal customer were not served directly by Bonneville but by a utility that purchased power from Bonneville. This would give the program maximum credibility when FEMP/PNL transfer the "lessons learned" to other utility service territories and other states.

The conditions just described dictated the criteria that PNL used to identify the most appropriate federal customer to participate in the program. First, we knew from our experiences at over 20 large federal installations that a necessary condition for the program to be successful was that the federal customer be thoroughly committed to working through the process. We also knew that the federal customer needed to be served by a utility committed to innovative approaches in demand-side management programs--ideally, a utility that had demonstrated commitment to the fundamental principles of least-cost planning.

Fortunately, all conditions were quickly met. FEMP has a cooperative program with the Army Forces Command (FORSCOM) for providing technical assistance to FORSCOM installations. FEMP and FORSCOM have agreed to cost-share activities in developing innovative approaches to energy efficiency at the latter's installations. One of those installations is Fort Lewis (near Tacoma, Washington), with whose key staff PNL had already developed a working relationship. In addition, Fort Lewis is served by Tacoma Public Utilities (TPU), which has demonstrated a commitment to energy efficiency programs over the years and enthusiastically embraced the concept. All these parties became involved in the pilot program.

The overall goals of the pilot program are

- to demonstrate a model approach for identifying and characterizing all cost-effective energy efficiency at Fort Lewis such that the approach can be transferred to other federal installations
- to acquire all cost-effective energy efficiency identified and characterized at Fort Lewis
- to acquire all cost-effective electric energy efficiency at Fort Lewis through a TPU/Bonneville agreement that would not require the Fort to either procure energy service contractors or provide any up-front capital.

The latter goal can be accomplished through the Targeted Resources Acquisition Program offered by Bonneville. This program enables utilities that purchase power from Bonneville to identify and buy electric energy efficiency resources from the utilities' customers, then sell those resources back to Bonneville for use elsewhere in its service area. However, to take full

advantage of this program, utilities such as TPU must prepare a proposal to Bonneville that tells the agency where and what the potential resources are, and how the utility plans to evaluate those estimated resources to determine their actual extent. The federal installation whose potential resources are being estimated also needs this information so it can decide whether or not to commit its share of the cost of the recommended retrofits.

In this report, we describe PNL's assessment of the electric energy efficiency resource potential at Fort Lewis. Through this assessment, we developed an estimate of the electricity use baseline and efficiency improvement potential for major sectors and end uses at the Fort. Developing the baseline was essential to segment the end uses that are targets for broad-based efficiency improvement programs and to provide TPU with the basis for its proposal to Bonneville. An estimate of the efficiency resource is presented to reflect the available quantity of resource for three electricity price ranges. The baseline and efficiency resource estimates did not identify all possible areas of opportunity, but instead identified the majority of the resource; areas of additional opportunity are noted, to encourage further effort.

BASELINE ELECTRICITY USE

Fort Lewis houses approximately 25,000 full-time residents. The Fort has a daytime population of approximately 35,000 persons. The annual fuel consumption is about 2.5 trillion Btu, of which 26% is in the form of electricity (annual average of 195,000 MWh). The annual cost of energy supplied to the Fort is over \$12 million, of which about \$4.5 million is for electricity.

In developing the baseline electricity use, we segmented the Fort into sectors, subsectors, and end uses to reflect major areas of consumption and efficiency potential. The four sectors identified were buildings, pumps/motors, distribution, and exterior lights. The sectors were further segmented into subsectors and, in the case of buildings, end uses (interior lighting, domestic hot water [DHW], refrigeration, and other).

An estimated 4457 buildings with floorspace of 23.9 million ft² are on the installation. We segmented the buildings sector into 16 subsectors (building types) based upon function and uniqueness of operation. Nine of the

building types account for over 90% of the total floorspace. Principal contributions are family housing at nearly 25%, barracks at nearly 20%, office/administration and warehouse each at over 12%, other at nearly 9%, the New Madigan Hospital at over 8%, and motor pools with 8% of the total floorspace.

End uses identified in the buildings sector include five lighting type categories, domestic hot water supplied by residential-type water heaters, refrigeration supplied by residential-type refrigerators, and all other uses. The other category contains heating, ventilating, and air-conditioning (HVAC) energy end uses that are specific to each building type. HVAC energy use was not separated because almost all heating energy is supplied by fossil fuel and few buildings are cooled; electricity use for HVAC is primarily for fans and pumps.

The pumps/motors sector reflects electricity use for large pumps and motors (10 to 250 horsepower) used for the water supply and sewage treatment subsectors. The distribution sector accounts for the losses incurred for electricity distribution through the transformer and feeder subsectors. We segmented the exterior lights sector into three subsectors: residential, non-residential (building exterior and parking lot lighting), and street lighting.

The limited availability of metered data created a challenge in developing the baseline electricity use. The Fort is served by three substations, designated as Madigan, South, and Central. Each is metered separately by TPU for both demand and power use. Aside from the commercial (nonappropriated) buildings on the Fort, these are the only sites where electricity use for the installation is metered. Seventeen feeder lines from these three substations provide all electrical power to the Fort.

We metered each of the substations and feeders separately and collected time-series data for 4 consecutive months. The primary purpose of the metering was to measure the electric demand profile of the Fort and determine the relative contributions to that demand of each of the three substations and 17 feeders. The secondary purpose was to provide the only metered data for an accurate assessment of the electrical energy use intensities of the building stock.

We used the metered data to ascertain and pinpoint the potential for energy efficiency opportunities in the various sectors of the site served by the 17 feeders, for both demand and baseload savings. The data were also used to more accurately determine the estimated energy use and energy use intensities of each of the major building and facility types at the Fort. Without these feeder-level metered data, we would have had to perform the analysis using TPU's billing data from the three substations. Thus, much more uncertainty would have been associated with this foundational analysis.

The metering results showed that the Fort has an annual baseload demand of 15,000 to 17,000 kW, and that the peak demand of 27,000 to 30,000 kW usually occurs before noon, depending upon the season. The Central substation accounted for nearly 50% of the total Fort demand. From the data, we also determined that most of the 16^(a) feeder loads were not temperature-dependent; therefore, opportunities for electrical energy savings (kilowatt-hours) exceed the opportunities for demand savings (kilowatts).

The baseline electricity use displayed in Table S.1 was developed for the buildings sector end uses and estimated subsector consumption or losses for the other three sectors. The estimates were developed using limited primary energy use data for the Fort, other studies conducted to identify efficiency improvements at the Fort, input from installation staff, and other published studies. The estimated annual energy use of 197,000 MWh was not adjusted to match the average actual of 195,000 MWh from billing data.

The buildings sector accounts for over 85% of the electricity use. Four of the building types account for over 46% of the total; these were single-family at 12.9%, multifamily at 10.7%, concrete barracks at 11.4%, and office/administration at 11.5%. Pumps/motors consume an estimated 2.4% of the total, distribution losses 7.6%, and exterior lighting nearly 4%.

(a) One of the feeders was a switching alternate and no load was measured during the monitoring period.

TABLE S.1. Estimated Baseline Electricity Use Per Year by Sector, Subsector, and End Use

Sector	Estimated Baseline Electricity Use (MWh)				
	Lighting	DHW	Ref	Other	Total
Building					
Single-Family	4,210	9,287	2,477	9,339	25,313
Multifamily	3,713	7,650	2,040	7,707	21,110
Concrete Barracks	10,431			12,064	22,495
Wood Barracks	1,088			982	2,071
Office/Administration	10,368	1,817		10,478	22,663
Warehouse	6,025	26		4,990	11,041
Motor Pool	5,122	1,140		3,682	9,944
Hangar	1,084	92		912	2,088
Dining Halls	1,252			5,955	7,207
Clubs	1,154			2,410	3,565
Old Madigan Hospital	4,502			8,807	13,309
New Madigan Hospital	5,959			2,023	7,982
Commissary	735			4,515	5,250
Computer Center	118			376	494
Simulators	230	3		4,564	4,797
Other	4,873	637		4,249	9,759
Subtotal	60,867	20,653	4,517	83,053	169,088
Pumps/Motors					
Water Supply				3,600	3,600
Sewage Treatment				1,160	1,160
Subtotal				4,760	4,760
Distribution					
Transformer Loss				13,000	13,000
Line Loss				2,000	2,000
Subtotal				15,000	15,000
Exterior Lights					
Residential	1,290				1,290
Other Building	2,453				2,453
Street	4,000				4,000
Subtotal	7,744				7,744
Total	68,611	20,653	4,517	102,813	196,591
% of Total	34.9	10.5	2.3	52.3	100.00

Of the total consumption, nearly 35% is accounted for by lighting, over 10% by domestic hot water, over 2% by refrigeration, and the balance of 52% by other uses. Within the lighting end use, approximately 22% of total electricity is fluorescent lighting energy, of which most is consumed in fixtures with 4-ft F-40 type tubes. Incandescent and high-intensity-discharge (HID) lighting account for 8.7% and 4.4%, respectively, of the remainder of total electricity consumption.

ELECTRIC EFFICIENCY RESOURCE SUPPLY

The supply of the electric efficiency resource was estimated for all subsectors and end uses except the other category in the building subsectors. The quantity of energy resource available was estimated for three electricity price ranges: \$0 through \$0.023/kilowatt-hour (kWh), \$0.024 through \$0.045/kWh, and \$0.046 through \$0.075/kWh. The endpoint of the first price range chosen is the approximate price that Fort Lewis currently pays for electricity (including demand charges), the endpoint of the second price range is the approximate avoided cost for new electricity generation in the Pacific Northwest, and the endpoint of the last cost range is chosen as an arbitrary point beyond which there is clearly no cost-effective technology options.

The potential menu of efficiency measures considered by sector and end use was as follows:

Buildings

Interior Lighting

- Replace incandescent bulbs with compact fluorescent in 15% of the indoor residential fixtures, 75% of the indoor fixtures in other buildings, and 100% of the exterior fixtures.
- Replace standard magnetic ballasts with energy-efficient magnetic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace standard magnetic ballasts with electronic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace standard magnetic ballasts with tunable electronic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.

- Add parabolic reflectors to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes with new fixtures with reflectors and electronic ballasts.
- Replace two-tube fluorescent fixtures using 75-W tubes with 150-W high-pressure sodium lamps.
- Replace two-tube fluorescent fixtures using 75-W tubes with single-tube 75-W very-high-output (VHO) fixtures.
- Replace two-tube fluorescent fixtures using 34- and 40-W tubes with F-30 T-8 fixtures.

Lighting replacements were made on a constant level of service basis. That is, if a replacement put out twice the level of light (measured in lumens), a one-for-two replacement was used.

Domestic Hot Water

- Increase the insulation level of the tanks by wrapping all of the water heaters with insulation.
- Wrap only new water heaters (less than 2 years old) with insulation.
- Replace 100% of existing water heaters with high-efficiency water heaters with nonmetallic or lined tanks. Information from the Fort Lewis staff indicates that life expectancy for water heaters is less than 5 years due to tank corrosion caused by carbonic acid. In addition, TPU staff encouraged consideration of a water heater replacement program with high-efficiency models, as that utility has experienced greater success with a replacement program than with wrap programs.
- Replace water heaters upon failure with high-efficiency water heaters with nonmetallic or lined tanks.

Refrigeration

- Replace 100% of existing residential-type refrigerators.

Replacing refrigerators with high-efficiency models as they wear out rather than implementing a straight replacement program as above was not considered because it is understood that all models now available are of the "efficient" variety. Consequently, there is little differential between replacement options.

Pumps/Motors

Water Supply

- Totally replace well pump motors with high-efficiency motors.
- Replace well pump motors with high-efficiency motors upon failure.

Sewage Treatment

- Totally replace sewage treatment pump motors with high-efficiency motors.
- Replace sewage treatment pump motors with high-efficiency motors upon failure.

For both the water supply and sewage treatment subsectors, existing motors were assessed individually for replacement because the number of operating hours varied significantly, which has a large effect on the levelized energy cost. The cost and efficiency improvement also varies with motor size.

Distribution

Transformer Loss

- Replace existing transformers with high-efficiency units. Existing transformers were assessed by size category for replacement.

Line Loss

- Regulate the voltage of the distribution system so that the most distant point on individual feeders meets minimum voltage requirements under all load conditions. Although insufficient information to quantify the resource is available for this measure, it is estimated to provide a reduction of 1% to 3.5% in total baseload at a very low cost (up to \$0.01/kWh).

Exterior Lighting

Residential

- Replace 100% of incandescent bulbs with compact fluorescent bulbs.

The levelized energy cost (LEC), net present value (NPV), and annual efficiency resource availability of each measure considered are displayed in

Table S.2. The regional power planning perspective using LEC shows the cost of the measures ranging from \$0.0056 to over \$0.158/kWh. The federal sector perspective using NPV is shown for the Fort paying 15% of the capital cost and 100% of the operations and maintenance (O&M) cost.

The data developed and displayed in Table S.2 will allow the utility and Fort to choose the electric energy efficiency measures to install in the site-wide retrofit. The choices will hinge on the final cost-sharing agreement as well as the agreement on the LEC ceiling value and NPV criteria. A federal agency is required to select energy efficiency options based on the NPV. The option with the highest NPV is selected. The decision criteria for a utility to choose among energy efficiency measures is based on the LEC.

Using the LEC values, efficiency measures up to the cost of the marginal supply resource for Bonneville (\$0.045/kWh) may be considered cost-effective. Using the NPV approach, measures with the highest NPV may be considered cost-effective by the Fort. The choice is generally options that are below the utility's avoided cost (long-run marginal cost) of supplying electricity.

All options that are not part of mutually exclusive sets that have an LEC less than the avoided cost should be selected. Options that are part of mutually exclusive sets should be chosen if they have the LEC closest to the avoided cost of energy, but not exceeding it.

For example, based on NPV, the best choice for retrofitting fluorescent lighting fixtures having 40-W tubes was determined to be a total new fixture with electronic ballast and reflector (the choice shown in Table S.2). This choice also shows a LEC of \$0.0166/kWh which will also be acceptable to the utility. Another viable choice for fixture replacement may be retrofitting with a higher efficiency type T-8 fixture. The NPV (shown in Table S.2) is near that of the high efficiency fixture and the LEC is \$0.0245/kWh, below the Bonneville avoided cost. However, the marginal LEC for this retrofit is \$3.7801/kWh which is well above the long-term avoided cost. Based on these data, this technology may not be selected.

Other choices analyzed included ballast replacement (only) or adding reflectors for replacement (not shown in Table S.2). These had a lower NPV, a

TABLE S.2. Levelized Energy Cost, Net Present Value, and Resource Availability by Efficiency Measure

Efficiency Measure	Levelized Energy Cost (\$/kWh)	Marginal Levelized Energy Cost (\$/kWh)	Net Present Value (1991 \$ thousands)	Marginal Annual Resource Availability (kWh)	Marginal Initial Capital Cost (1991 \$ thousands)
DIW: ROF (a)	0.0056	0.0056	1,935	2,427,754	1,439
WS: ROF - Well #18	0.0066	0.0066	4	13,810	1
DIW: Complete replacement (a)	0.0057	0.0081	2,126	2,595,185	1,572
FI-75-W: New fix. w/refl., ballast	0.0098	0.0098	410	1,318,273	220
FI-40-W: New fix. w/refl., ballast (b)	0.0166	0.0166	7,453	25,915,995	6,662
FI-34-W: New fix. w/refl., ballast (c)	0.0167	0.0167	278	957,498	250
ST: ROF - Effluent pumps	0.0181	0.0181	9	30,747	8
Inc.: Replace w/compact fl	0.0203	0.0203	981	6,199,405	754
TRANS: 50 kVA Transformers	0.0210	0.0210	518	1,500,308	619
TRANS: 37.5 kVA Transformers	0.0228	0.0228	238	699,314	313
WS: ROF - Well #19	0.0251	0.0251	1	5,522	2
WS: ROF - Well #15	0.0263	0.0263	2	6,955	3
TRANS: 25 kVA Transformers	0.0275	0.0275	198	606,455	327
TRANS: 75 kVA Transformers	0.0335	0.0335	267	865,947	569
WS: ROF - Well #10	0.0357	0.0357	(d)	32	(d)
TRANS: 100 kVA Transformers	0.0373	0.0373	36	120,387	88
WS: ROF - Sequal spring	0.0562	0.0562	5	24,573	21
WS: ROF - Well #13	0.0567	0.0567	(d)	2,869	2
TRANS: 200 kVA Transformers	0.0605	0.0605	86	374,132	443
WS: ROF - Well #14	0.0613	0.0613	(d)	3,528	3
WS: ROF - Well #12	0.0613	0.0613	1	7,498	7
TRANS: 15 kVA Transformers	0.0771	0.0771	37	205,211	310
TRANS: 300 kVA Transformers	0.0800	0.0800	35	206,202	324
FI-40-W: Install F30 T-8 fixtures (b)	0.0245	0.1061	7,059	28,399,233	9,690
Refrigerators: Replace	0.1113	0.1113	80	1,387,167	1,843
WS: ROF - Well #9	0.1165	0.1165	(d)	494	(d)
TRANS: 500 kVA Transformers	0.1180	0.1180	13	208,314	482
TRANS: 750 kVA Transformers	0.1333	0.1333	3	176,512	461
TRANS: 1000 kVA Transformers	0.1410	0.1410	(d)	53,305	147
TRANS: 1500 kVA Transformers	0.1419	0.1419	(c)	92,446	257
TRANS: 5 kVA Transformers	0.1564	0.1564	(d)	6,398	20
TRANS: 2500 kVA Transformers	0.1582	0.1582	(d)	15,074	47
WS: ROF - Well #17	0.2615	0.2615	(d)	878	3
FI-34-W: Install F30 T-8 fixtures (c)	0.0245	3,7801	246	959,483	340

(a) These measures are mutually exclusive and only one will be selected.

(b) These measures are mutually exclusive and only one will be selected.

(c) These measures are mutually exclusive and only one will be selected.

(d) NPV is negative and therefore not considered as a viable measure.

negative marginal energy savings compared to complete fixture replacement. These technologies also had higher LECs compared to the complete fixture replacement.

Examination of the results of the analysis with the estimated cost-sharing split in Table S.2 shows that the choice of criteria (LEC or NPV) will not significantly affect the ultimate choice of energy efficiency measures to be installed at the Fort. The most desirable measures, in terms of both overall energy savings and in terms of NPV, could be selected and implemented using either criteria.

The LEC and resource availability are displayed in Figure S.1 in the form of a supply curve. This shows availability of about 43,000 average annual MWh of electric efficiency at a cost of less than \$0.037/kWh. Above \$0.037/kWh, less than an additional 1,500 MWh are available.

Figure S.2 shows the resource availability by end use for LEC cost ranges of \$0 to \$0.023/kWh, \$0.024 to \$0.045/kWh, and \$0.046 to \$0.075/kWh. In the lowest cost range, over 37,000 average annual MWh (equivalent to over 4 average annual MW of capacity) are provided by efficiency improvements to water heaters, water supply pumps, interior lighting, exterior lighting, water treatment pumps, and voltage regulation at an estimated initial capital cost of about \$9 million. Other transformer and water supply pump replacements, in addition to a different set of lighting and water heating improvements, contribute another 5,907 MWh to the resource potential for the mid-range cost. The upper cost range contains another 412 MWh provided by additional water supply pump and transformer replacements. Lighting measures account for over 90% of the efficiency resource available in the lowest cost range and nearly 85% of the resource of the total available up to a cost of \$0.075/kWh.

ADDITIONAL RESOURCE OPPORTUNITIES

A number of additional resource opportunities were identified in the assessment. Their potential contribution was not quantified because they are




FIGURE S.1. Electric Efficiency Supply Curve




FIGURE S.2. Electric Efficiency Resource by End Use and Cost Category

addressable only through more focused data collection efforts, which are beyond the scope of this initial effort. A listing of these resource opportunities by sector follows.

Buildings

- incandescent lighting - Replace those fixtures currently unable to accommodate compact fluorescent lamps to increase the penetration levels in addition to replacing bulbs in fixtures that will accept them.
- lighting controls - Implement controls to adjust for daylighting and/or occupancy. Daylighting controls are reportedly in operation in Building 3670.
- HVAC - Improve heating and/or cooling efficiencies in buildings having electric heating and/or cooling equipment through a combination of higher-efficiency equipment, improving the building envelope thermal integrity, and/or improving operation and maintenance practices.
- heat recovery - Recover heat from exhaust airstreams in building types such as dining halls and clubs.
- low-flow shower heads - This measure is reported to be in place in most, if not all, applications.

Pumps/Motors

- replacement of motors less than 10 horsepower - This option would likely have high potential for motors that operate nearly continuously. However, an inventory of the stock and operating schedules of small motors was not available, nor was an estimate developed.
- modification of related systems - One example would be to increase pipe size to reduce horsepower required to maintain pressure.
- implementation of operation and control practices - This provides for automated operation of the water supply system.

Distribution

- replacement of existing transformers as they fail with high-efficiency units, which may improve the cost-effectiveness of this measure
- the value of other distribution improvements, such as reconductoring feeders and adding capacitors, will reduce line losses and improve power factors.

Exterior Lighting

- installation of new, and replacement of faulty, photocells to reduce or eliminate exterior lighting during daylight hours
- replacement of existing low-efficiency HID lighting with high-efficiency units
- replacement of incandescent lamps that are greater than 200 W with HID or other suitable high-efficiency alternative.

RECOMMENDATION

Our analysis indicates that significant cost-effective energy efficiency potential exists at Fort Lewis. At \$0.023/kWh, about 37,000 annual MWh of energy efficiency are available at an estimated capital cost of \$9 million. The Fort's electrical utility, TPU, has available several demand-side program options through its supplier, Bonneville. The most likely option appears to be the Bonneville Targeted Acquisition Program under which TPU purchases the efficiency from Fort Lewis and sells it to Bonneville at Bonneville's avoided cost of electricity, which is about \$0.045/kWh. The terms of the arrangement being discussed would have Fort Lewis contribute 15% of the capital investment, with the balance funded by TPU and Bonneville. Provided that there are no unresolvable contractual and technical issues, the potential exists for Fort Lewis to enter into an agreement with TPU for the approximately 37,000 annual MWh (4 annual average MW) of cost-effective energy efficiency resources identified.

The PNL assessment is a first cut at estimating the electrical energy efficiency potential at Fort Lewis. As such, the results should be useful to the Fort in determining if an aggressive energy efficiency program is warranted and, if so, which options should be implemented. Our results should not be used to draw conclusions regarding the cost-effectiveness of marginal technologies or specific end-use products. These refinements require more detailed analyses.

CONTENTS

ABSTRACT	iii
SUMMARY	v
ABBREVIATIONS AND ACRONYMS	xxiii
1.0 INTRODUCTION	1.1
1.1 ASSESSMENT SCOPE	1.1
1.2 REPORT ORGANIZATION	1.3
1.3 REFERENCES	1.3
2.0 APPROACH	2.1
2.1 BASELINE DEVELOPMENT	2.1
2.1.1 Sector Segmentation	2.1
2.1.2 End-Use Intensity and Baseline Development	2.4
2.2 ANALYSIS APPROACHES	2.5
2.2.1 Supply Curve	2.5
2.2.2 Life Cycle Cost and Net Present Value	2.6
2.3 SUPPLY CURVE DEVELOPMENT	2.7
2.3.1 Process	2.7
2.3.2 Efficiency Measures	2.8
2.4 REFERENCE	2.12
3.0 BASELINE AND EFFICIENCY ESTIMATES	3.1
3.1 BUILDINGS SECTOR PROFILE	3.1
3.2 ELECTRICITY USE BASELINE	3.2
3.3 ELECTRIC EFFICIENCY SUPPLY CURVE	3.6
3.4 NET PRESENT VALUE	3.11
3.5 CHOOSING ENERGY EFFICIENCY MEASURES	3.11

3.5.1 Criteria	3.11
3.5.2 Example	3.14
APPENDIX A - DATA SOURCES	A.1
APPENDIX B - BUILDINGS SECTOR BASELINE AND EFFICIENCY ASSESSMENT . .	B.1
APPENDIX C - MOTOR BASELINE AND EFFICIENCY ASSESSMENT	C.1
APPENDIX D - TRANSFORMER LOSS AND VOLTAGE REGULATION EFFICIENCY ASSESSMENT	D.1
APPENDIX E - EXTERIOR LIGHTING SECTOR BASELINE AND EFFICIENCY ASSESSMENT	E.1

FIGURES

S.1	Electric Efficiency Supply Curve	xvii
S.2	Electric Efficiency Resource by End Use and Cost Category . . .	xvii
3.1	Electric Efficiency Supply Curve	3.9

TABLES

S.1	Estimated Baseline Electricity Use Per Year by Sector, Subsector, and End Use	x
S.2	Levelized Energy Cost, Net Present Value, and Resource Availability by Efficiency Measure	xv
3.1	Fort Lewis Building Stock Description	3.2
3.2	Substations and Feeders Serving Fort Lewis	3.4
3.3	Buildings Sector Electricity End-Use Intensities	3.5
3.4	Estimated Electric Baseline by Sector, Subsector, and End Use .	3.7
3.5	Levelized Energy Cost and Efficiency Resource by Measure and Cumulative Efficiency Resources	3.8
3.6	Electric Efficiency Resource Availability by End Use and Cost Range	3.10
3.7	Net Present Value of Efficiency Measures by End Use for Measures with Highest NPV	3.12

ABBREVIATIONS AND ACRONYMS

AACE	American Association of Cost Engineers
Bonneville	Bonneville Power Administration
CAD	computer-aided design
CVR	conservation voltage regulation
DHW	domestic hot water
DOE	U.S. Department of Energy
DSM	demand-side management
ECO	energy conservation opportunity
eff	efficient
EIA	Energy Information Administration
ELCAP	End-Use Load and Consumer Assessment Program
EMCS	emergency management control system
EPA	U.S. Environmental Protection Agency
EUI	end-use intensity
FEDS	Facility Energy Decision Screening
FEMP	Federal Energy Management Program
fl	fluorescent
FORSCOM	Army Forces Command
HID	high-intensity discharge
hp	horsepower
HPS	high-pressure sodium
HVAC	heating, ventilating, and air conditioning
inc	incandescent
kVA	kilovolt-ampere
kW	kilowatt
kWh	kilowatt-hour
LCC	life cycle cost
LEC	levelized energy cost
MW	megawatt
MWh	megawatt-hour
N/A	not applicable
NIST	National Institute of Standards and Technology
NPV	net present value

NWPPC	Northwest Power Planning Council
O&M	operations and maintenance
PNL	Pacific Northwest Laboratory
ref	refrigeration
ROF	replace on failure
SES	shared energy savings
TPU	Tacoma Public Utilities
trans	transformer
VHO	very-high-output
W	watt
WS	water supply

1.0 INTRODUCTION

Under the National Energy Conservation Policy Act (as amended 1988), the federal government is required to reduce energy use in its facilities 10% per square foot from 1985 levels by 1995. A new Executive Order on federal energy management (56 FR 12759) was signed in April 1991, which sets a goal of 20% reduction in federal facility energy use, and 20% industrial process efficiency improvements by the year 2000 (from 1985 levels). These goals are to be achieved by the implementation of life cycle cost-effective energy end-use technologies, utilizing utility demand-side management (DSM) programs, and shared energy savings (SES), to provide a significant portion of the funding for efficiency improvements.

A major obstacle to reducing energy use in large federal installations is the current inability to characterize energy consumption by major sector and end use in detail sufficient to enable more than limited efficiency acquisition efforts. These installations are typically the size of small cities, and, for the most part, energy use is not metered except at the installation level. The Fort Lewis Electric Energy Baseline and Efficiency Resource Assessment is being conducted by the Pacific Northwest Laboratory (PNL)^(a) under the direction of the Department of Energy (DOE) Federal Energy Management Program (FEMP), the Bonneville Power Administration (Bonneville), and the Army Forces Command (FORSCOM) to develop a systematic approach with which to identify energy efficiency potential in large federal installations. This approach will be used to support energy efficiency acquisition programs in other major federal sector installations in the United States and abroad.

1.1 ASSESSMENT SCOPE

The Fort Lewis Electric Energy Baseline and Efficiency Resource Assessment characterizes baseline energy use at Fort Lewis by major sector and end use and develops an estimate of the major areas of electric energy efficiency potential. The purposes of this assessment are to support the development of

(a) Operated by Battelle Memorial Institute for the U.S. Department of Energy under Contract DE-AC06-76RLO 1830.

a methodology that will enable replication of the process at other installations with less effort and to provide baseline information in support of electric efficiency acquisition activities at the Fort Lewis installation. Specific recommendations and technologies for improving facility electricity-use efficiency are not within the scope of this effort.

Two objectives are supported in this multiagency effort:

- to demonstrate the Facility Energy Decision Screening (FEDS) approach for identifying and characterizing the cost-effective energy efficiency resource at a large federal installation, which can be transferred to other installations
- to support the acquisition of the Fort Lewis electric energy efficiency resource by Tacoma Public Utilities (TPU) and Bonneville.

FEMP and other federal agencies are cofunding the development of the FEDS methodology, which will enable federal installation energy managers to define the baseline facility energy use and identify the combination of energy supply and efficiency resources that meet installation mission requirements at least cost. The electricity resource assessment contained in this report supports that aspect of the FEDS methodology development. A separate but similar assessment is under way for energy supplied to Fort Lewis by natural gas and fuel oil.

FORSCOM and Bonneville have cofunded the assessment of baseline electricity use at Fort Lewis and of major areas for electric energy efficiency improvement. This assessment is to support the acquisition of electric energy efficiency through a financial partnership among Fort Lewis, Bonneville, and TPU. This utility is the Fort's supplier of electricity. Under the terms of this partnership, Fort Lewis will contribute 15% of the capital investment for the efficiency improvements. The balance will be funded by TPU and Bonneville through Bonneville's Targeted Acquisition Program. This program enables electric utilities to identify and buy energy efficiency resources from the utilities' customers and then sell those resources back to Bonneville for use elsewhere. Bonneville may also use the assessment process in implementing efficiency resource acquisition programs at other major federal facilities within its service area in the Pacific Northwest.

The product of this assessment is a characterization of electric energy consumption at Fort Lewis by major use sector and major end use within each sector where significant efficiency potential can be accessed with a broad-based efficiency acquisition program. End-use consumption within a sector is not characterized in sufficient detail to identify the efficiency potential that may be obtainable through more focused acquisition activities. However, PNL has identified those additional opportunities where focused activities may provide for the acquisition of efficiency beyond that identified in the major end uses.

1.2 REPORT ORGANIZATION

The text of this report provides an overview of the assessment. In Section 2.0, the approach used to develop the baseline electricity use characterization for Fort Lewis and the levelized cost methodology to develop the efficiency resource supply curve are described. Section 3.0 presents the electricity use baseline and efficiency resource supply curve.

The appendixes provide a detailed discussion of the derivation of the electricity use baseline and efficiency resource. Appendix A presents the data sources used to support the assessment. The buildings sector baseline and efficiency assessment are contained in Appendix B. The motors sector, covered in Appendix C, addresses water supply and sewage treatment. Appendix D provides the treatment of transformers and voltage regulation for the distribution system. The exterior lighting energy baseline and efficiency resource are presented in Appendix E.

1.3 REFERENCES

56 FR 12759. April 19, 1991. "Federal Energy Management." Federal Register. National Energy Conservation Policy Act, Public Law 95-619, 42 USC 8253.

2.0 APPROACH

This section explains the approach we used to characterize the baseline electric energy use at Fort Lewis and to develop a bottom-line estimate of the efficiency resource available. The approach is similar to those used by many electric utilities for developing load forecasts and assessing the energy efficiency potential available through various acquisition programs.

The first step is to identify the major energy-using sectors, subsectors, and end uses and to develop an energy consumption baseline. The second step develops two cost measures for depicting the financial attractiveness of the efficiency resources. Utilities typically use a levelized cost measure to express the cost of supply- and demand-side resources on a dollars per kilowatt-hour basis to develop a supply curve relating the quantity of resource available at a schedule of prices. Federal agencies are required by 10 CFR 436 to evaluate cost-effectiveness using a life cycle cost (LCC), net present value (NPV) measure.

The approach used to develop the Fort Lewis electricity use baseline is described in Section 2.1. This discussion contains the breakdown of sectors, subsectors, and end uses, and the development of the end-use intensities (EUIs). The two cost approaches and supply curve concept are presented in Section 2.2. Additional detail for each of the identified sectors is contained in its corresponding appendix.

2.1 BASELINE DEVELOPMENT

We developed the electricity baseline through a two-step process. In the first step, the energy use was segmented into identifiable sectors, subsectors, and end uses. The second step entailed estimating baseline consumption through the development of subsector consumption and EUIs for subsectors in which end uses are identified.

2.1.1 Sector Segmentation

Our review of the stock of electricity-using facilities at Fort Lewis led to the identification of four principal sectors for the assessment:

- buildings
- pumps/motors
- distribution
- exterior lighting.

Each of these sectors was further segmented into subsectors; a discussion of each follows.

Buildings

The buildings sector was segmented into 16 building subsector categories based upon identifiable function or uniqueness in terms of size or energy use.

The residential building stock was segmented into

- single-family - detached housing
- multifamily - ranging from duplexes to eight-unit complexes.

The stock of barracks was segmented into

- concrete - typically three-story barracks constructed of concrete, brick, or masonry, and housing unaccompanied enlisted personnel
- wood - typically one- or two-story barracks constructed of wood and housing unaccompanied enlisted personnel.

The remaining stock of buildings was segmented into the following categories:

- motor pool - all maintenance and production facilities for vehicles and stationary equipment
- hangar - aircraft maintenance
- office/administration - houses administrative, headquarters, training, traffic control, and airfield communications functions
- warehouse - dry and refrigerated storage facilities, including fuel storage
- dining hall - unaccompanied personnel dining facilities
- clubs - officer, enlisted, and noncommissioned officer dining facilities
- Old Madigan Hospital - all hospital, clinic, dental, and other medical facilities contained primarily in the Old Madigan complex, excluding the New Madigan Hospital

- New Madigan Hospital - new hospital and health care facility scheduled to be in operation by mid-1993
- commissary - grocery
- computer center - housing central mainframe computer equipment
- simulators - helicopter simulator
- other - all other buildings such as private food service (e.g., commercial restaurant, bowling), base personnel support (e.g., craft shop, laundry), golf course, and boat docks.

The end uses selected for the buildings sector were identifiable areas of energy efficiency potential where broad-based acquisition programs would apply. The end uses identified are

- interior lighting - segmented into five categories by fluorescent (F-34, F-40, and F-96 tube fixtures), incandescent lighting (bulb size less than 200 W), and high-intensity-discharge (HID) lighting
- hot water - domestic hot water supplied by residential-type water heaters
- refrigeration - food and other refrigeration supplied by residential-type refrigerators
- other - all other end uses not specified above, such as HVAC energy and specialized energy requirements of specific building types, such as office equipment, booster heaters for the dining hall hot water supply, and refrigeration for walk-in refrigerator/freezers.

It is recognized that efficiency potential may exist in the other category in specific building types. However, that potential is not quantifiable without significant additional information and effort.

Pumps/Motors

Electricity use for pumps and motors was segmented into two subsectors:

- water supply - pumps used for drawing water from wells and providing water distribution
- sewage treatment - effluent pumps used at the central sewage treatment plant.

The pumps and motors analyzed in this category tend to be large, with horsepower ranging from 10 to 250. No attempt was made to estimate the number

of smaller motors distributed around Fort Lewis that provide a range of services from air-handling to machine work, although Fort Lewis staff estimate the number of smaller motors to be in the thousands.

The end uses for the pumps/motors sector are identical to the two identified subsectors.

Distribution

Electricity "use" for distribution was segmented into two subsectors:

- transformer - load and no-load losses of all transformers used to step down voltage for energy-using equipment
- voltage regulation - potential reduction in end-use energy consumption provided by regulation of feeder voltage so that the most distant load from the substation is maintained at the minimum acceptable voltage under all load conditions on the circuit.

The end uses for the distribution sector are identical to the two identified subsectors.

Exterior Lighting

Exterior lighting was segmented into three subsectors as follows:

- residential - porch and other residential exterior lighting served primarily by incandescent bulbs
- other building - all other building exterior lighting served by a mixture of incandescent and HID fixtures
- street - all street lighting served by HID fixtures.

The end uses in the exterior lighting category are identical to the three subsectors identified.

2.1.2 End-Use Intensity and Baseline Development

The estimated baseline electricity consumption was developed through a combination of EUIs developed for the buildings sector end uses and estimated subsector consumption for the other three sectors. The EUIs developed provide the intensity of energy use measured in kilowatt-hours per square foot per year for a specific end use and building type. EUIs are a commonly used

measure to enable aggregate estimates of energy use to be developed using estimates of the total floorspace for their respective building types.

These estimates were developed using primary data for energy use at Fort Lewis, other studies conducted to identify efficiency improvements at Fort Lewis, input from Fort Lewis staff, and secondary information from other studies conducted for the Pacific Northwest region.

The major focus of the development of the EUI and baseline development is the buildings sector, because it is the major energy-consuming sector of the four. We used an iterative process to develop the baseline and refine the buildings sector EUIs as follows:

- Buildings sector EUIs were estimated using the available primary and secondary data by each of the four end uses expressed in kilowatt-hours per square foot per year ($\text{kWh}/\text{ft}^2\text{-yr}$).
- Electricity consumption (or loss) was estimated by subsector within each of the other three sectors.
- Metered data from each of 17 electricity distribution (feeder) points aggregated to 7 points was used to provide control totals to check the estimated load developed from the buildings sector EUIs and subsector consumption associated with that feeder. In cases where the estimated load deviated by more than 20% from the control total, adjustments were made to the buildings sector EUIs.

2.2 ANALYSIS APPROACHES

Two distinct analysis approaches are used to evaluate the desirability of the efficiency alternatives.

2.2.1 Supply Curve

The concept of the supply curve is employed to evaluate options from the point of view of the utility and the energy planners in the Pacific Northwest region. This is discussed in detail in the Section 2.3, but, in brief, the supply curve approach allows the costs and availability of the potential efficiency alternatives to be compared with other electricity resources (either other efficiency resources or generating resource), based on the real levelized energy cost (LEC) of the resource. The LEC is the cost per unit of energy saved and is expressed in dollars per kilowatt-hour (\$/kWh). The LEC

of an efficiency resource is calculated as the annualized total cost divided by the annual energy savings and allows comparison with the cost of a generating resource calculated in the same manner.

2.2.2 Life Cycle Cost and Net Present Value

The second analysis approach required by federal agencies to screen investments is the determination of the LCC and NPV of each alternative. Federal agencies are required by 10 CFR 436 to select alternatives with the lowest LCC and maximum positive NPV. Each alternative has an associated initial capital cost, as well as a stream of costs over the term of analysis. In addition, each alternative saves some amount of energy, which translates into savings on the Fort's utility bill. The NPV employs the concept of the present value of a stream of savings or costs that will be enjoyed or incurred in the future. The present value of a stream is the amount that could be invested now at a given interest rate that could generate the stream.

For all energy efficiency options that are not part of a mutually exclusive set, one should choose those that have positive NPVs. A positive NPV implies that the LCC is less than the alternative of no action. For alternatives that are part of a mutually exclusive set, the efficiency alternative with the highest NPV should be selected.

This analysis is complicated somewhat by three factors 1) the cost-sharing between Fort Lewis and TPU, 2) the interest (or discount) rate to use in the analysis, and 3) assumptions about future electricity prices.

Currently, it is expected that Fort Lewis will pay 15% of the initial capital costs of an energy efficiency measure alternative and pay 100% of the operations and maintenance (O&M) cost from the start of the project.

The discount rate is a complicating issue because regional power planners typically use the rate developed by the Northwest Power Planning Council (NWPPC) (3% real), while Fort Lewis is required to use the rate established by DOE for federal energy conservation (4.7% real). For this reason, the LEC calculations for the supply curve construction (discussed in the following section) use the 3% rate, while the NPV calculations use the 4.7% rate.

In a similar vein, NWPPC forecasts in its medium-high scenario that electricity prices will increase 0.3% annually over the next 20 years. The Energy Information Administration (EIA) of DOE makes forecasts of real energy price changes that must be used with the National Institute of Standards and Technology (NIST) energy conservation project evaluation methodology. These forecasts vary year to year and show a significantly greater rate of fuel price escalation than the NWPPC forecast. Fuel price does not enter directly into the LEC calculation and, hence, does not directly influence the supply curve construction. The NIST escalation rate used in the NPV calculations ranges from 0.9% to 1.24% annually over the 20-year analysis period. The NPV analysis results are discussed in detail in Section 3.4.

2.3 SUPPLY CURVE DEVELOPMENT

The concept of supply curves for comparing the cost-effectiveness of efficiency resources with energy supply alternatives is described, as are the efficiency measures that were and were not considered within this assessment. Section 2.3.1 details the concept and the assumptions used to derive the supply curves. The efficiency measures that were and were not considered are provided in Section 2.3.2.

2.3.1 Process

Supply curves are developed to relate the quantity of a resource available at a schedule of prices. In this assessment, the efficiency resource is expressed in terms of real LEC. This provides a dollars-per-kilowatt-hour equivalent that enables comparison with electricity prices to provide an estimate of the quantity of cost-effective electric energy efficiency available at Fort Lewis, from the perspective of the regional energy planners.

The process for developing the total supply curve starts with estimating the energy-efficiency improvements that can be obtained by applying specific measures to each of the identified sector and subsector end uses (see Section 2.3.2). Given each measure's cost, operating life, and capital recovery factors given earlier, the quantity of energy efficiency is translated into a LEC basis.

Each of the measures is then sorted in ascending order by LEC. Those measures that are mutually exclusive, such as adding reflectors to all 40-W fixtures versus adding reflectors and electronic ballasts to all 40-W fixtures versus replacing all 40-W fixtures with high efficiency T-8 fixtures are identified. These mutually exclusive options are then incorporated into the supply curve as follows:

- re-sort all LEC measures of the mutually exclusive set (lowest to highest LEC)
- calculate the additional energy (kWh) savings obtained by implementing the next lowest LEC in the list instead of the minimum LEC measure (the measure above), i.e., calculate the marginal energy savings
- delete the next lowest LEC from the list and supply curve development if the marginal savings are negative. (Note--a negative marginal savings indicates that the measure is dominated by lower LEC option - it saves less energy at a higher cost per unit.)
- calculate the incremental (marginal) annualized total cost of implementing each of the remaining measures
- calculate the marginal LEC as: marginal annualized total cost/marginal savings
- sort all measures in ascending order by marginal LEC
- calculate the cumulative savings as the sum of the marginal savings
- plot the cumulative savings on the x-axis versus the marginal LEC on the y-axis for all the measures.

Breakpoints in the price schedule that were considered important are at \$0.023/kWh, \$0.045/kWh, and \$0.075/kWh. The lower breakpoint is the approximate price that Fort Lewis currently pays for electricity. The middle breakpoint is the approximate avoided cost for new electricity generating facilities in the Pacific Northwest, and the upper breakpoint is chosen arbitrarily as clearly not cost-effective for resources above that level.

2.3.2 Efficiency Measures

The classes of potential electrical efficiency measures were jointly developed by PNL and TPU. These classes were then segmented into two categories for each of the major sectors 1) those that were most likely to be

implemented and 2) those that were not considered in the analysis, but may add to the efficiency resource potential. The cost performance (energy use) data for each of the measures was developed by PNL.

Buildings Sector

Measures considered for the buildings sector were in the areas of lighting, hot water, and refrigeration.

Lighting

- replacing incandescent bulbs with compact fluorescent in 15% of the indoor residential fixtures, 75% of the indoor fixtures in other buildings, and 100% of the exterior fixtures
- adding energy-efficient magnetic ballasts to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes
- adding electronic ballasts to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes
- adding tunable electronic ballasts to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes
- adding parabolic reflectors to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes
- replacing two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes with new fixtures with reflectors and electronic ballasts
- replacing two-tube fluorescent fixtures using 75-W tubes with 150-W high-pressure sodium lamps
- replacing two-tube fluorescent fixtures using 75-W tubes with single-tube 75-W very-high-output (VHO) fixtures
- replacing two-tube fluorescent fixtures using 34- and 40-W tubes with F-30 T-8 fixtures.

Lighting replacements were made on a constant level of service basis. That is, if a replacement put out twice the level of light (measured in lumens), a one-for-two replacement was used.

Hot Water

- increasing the insulation level of the tanks by wrapping all of the water heaters with insulation
- wrapping only new water heaters with insulation
- replacing 100% of the water heaters with high-efficiency water heaters with nonmetallic or lined tanks - Information from the Ft. Lewis staff indicates that life expectancy for water heaters is less than 5 years because of tank corrosion caused by carbonic acid. In addition, TPU staff encouraged consideration of a water heater replacement program with high-efficiency models, as that utility has experienced greater success with a replacement program than with wrap programs.
- replacing water heaters upon failure with high-efficiency water heaters with nonmetallic or lined tanks.

Refrigeration

- Replacing 100% of existing residential-type refrigerators.

Replacing refrigerators with high-efficiency models as they wear out rather than implementing a straight replacement program as above was not considered because it is understood that all models now available are of the "efficient" variety. Consequently, there is little to no differential between replacement options.

Items not considered in the buildings sector that may add to the efficiency resource potential are

- incandescent lighting - Replace fixtures to accommodate compact fluorescent to increase the penetration levels in addition to replacing bulbs in fixtures that will accept them.
- lighting controls - Implement controls to adjust for daylighting and/or occupancy. Daylighting controls are reportedly in operation in Building 3670.
- HVAC - Improve heating and/or cooling efficiencies in buildings having electric heating and/or cooling equipment through a combination of higher-efficiency equipment, improving the building envelope thermal integrity, and/or improving operation practices.
- heat recovery - Recover heat from exhaust airstreams in building types such as dining halls and clubs.

- low-flow shower heads - This measure is reported to be in place in most, if not all, applications.

Pumps/Motors

Measures considered for the pumps/motors sector were motor replacements, as follows:

- water supply - Replace well pump motors with high-efficiency motors.
- water supply - Replace well pump motors with high-efficiency motors upon failure.
- sewage treatment - Replace sewage treatment effluent pump motors with high-efficiency motors.
- sewage treatment - Replace sewage treatment effluent pump motors with high-efficiency motors upon failure.

For both water supply and sewage treatment subsectors, existing motors were assessed individually for replacement because the number of operating hours varied significantly, which has a large effect on the LEC. Also, given the range of costs and efficiency improvement by motor size, the reader is referred to Appendix C for additional detail.

Items that were not considered in the pumps/motors sector that may add to the efficiency resource potential are

- replacement of motors less than 10 horsepower - This option would likely have high potential for motors that operate nearly continuously. However, an inventory of the stock and operating schedules was not available, nor was an estimate developed.
- modification of related systems - One example would be to increase pipe size to reduce horsepower required to maintain pressure.
- implementation of operation and control practices - This option provides for automated operation of the water supply system.

Distribution

Measures considered for the distribution sector were transformer replacement and voltage regulation:

- Replace existing transformers with high-efficiency units. Existing transformers were assessed by size category for replacement. Given

that the cost and efficiency improvement vary by size category, the reader is referred to Appendix D for additional detail.

- Regulate the voltage of the distribution system so that the most distant point on individual feeders meets minimum voltage requirements under all loading conditions of the feeder. Although insufficient information is available to quantify this resource, it is estimated to provide a reduction of 1% to 3.5% in total baseload at a cost up to \$0.01/kWh.

Items that were not considered in the distribution sector that may add to the efficiency resource potential are

- replacement of existing transformers as they fail with high-efficiency units, which may improve the cost-effectiveness of this measure
- the value of other distribution improvements, such as reconductoring feeders and adding capacitors to reduce line losses and improve power factors.

Exterior Lighting

The only measure considered for this sector was the replacement of 100% of the existing incandescent lighting that is less than 200 W in residential applications with compact fluorescent.

Items that were not considered in the exterior lighting sector that may add to the efficiency resource potential are

- installation of new, and replacement of faulty, photocells to reduce or eliminate exterior lighting during daylight hours
- replacement of existing low-efficiency HID with lighting with high-efficiency units
- replacement of incandescent lighting that is greater than 200 W with HID or other suitable high-efficiency alternative.

2.4 REFERENCE

10 CFR 436. November 20, 1990, "Federal Energy Management and Planning Program; Life Cycle Cost Methodologies and Procedures." Code of Federal Regulations.

3.0 BASELINE AND EFFICIENCY ESTIMATES

The estimated electricity use baseline and the supply curve relating the efficiency resource potential are discussed in this section. Section 3.1 provides an overview of the building stock to show numbers of buildings and amount of floorspace by building type. The estimated energy use baselines by sector, subsector, and end use are presented in Section 3.2. The supply curve of estimated electric energy efficiency is contained in Section 3.3, the net present value is discussed in Section 3.4, and the criteria for choosing efficiency measures are given in Section 3.5.

For background, Fort Lewis houses approximately 25,000 full-time residents, which include military personnel and dependents, and has a daytime population of approximately 35,000 persons. In 1989, total facility energy consumption was approximately 2.5 trillion Btu, of which 43% was provided by natural gas, 31% by oil, and 26% by electricity. The fuel cost of over \$12 million comprised 37% electricity, 37% natural gas, and 26% oil.

During the period 1986 through 1987, annual electricity consumption ranged from 181,000 MWh to 197,000 MWh at a cost ranging from \$3.5 to \$4.5 million. In 1989, electricity consumption was approximately 193,000 MWh and cost \$4.5 million, at an average price of \$0.023/kWh (including demand charges).

3.1 BUILDINGS SECTOR PROFILE

The estimated 4457 buildings on the post have approximately 23.9 million square feet of floorspace. Table 3.1 summarizes the buildings sector in terms of floorspace, number of buildings, and average floorspace by building type.

Nine of the 16 identified building types account for over 90% of the total square footage. Family housing comprises the largest share of floorspace, accounting for nearly 25% of the total. This is followed by barracks housing for unaccompanied personnel, accounting for nearly 20% of the total.

TABLE 3.1. Fort Lewis Building Stock Description

<u>Building Type</u>	<u>Floorspace (ft²)</u>	<u>Percentage of Total Floorspace</u>	<u>Number of Buildings</u>	<u>Average Floorspace (ft²)</u>
Single-Family	3,207,801	13.4	1,811	1,721
Multifamily	2,675,095	11.2	394 ^(a)	1,579 ^(b)
Concrete Barracks	3,209,566	13.4	79	40,627
Wood Barracks	1,461,523	6.1	291	5,022
Office/Administration	2,892,262	12.1	715	4,045
Warehouse	2,933,673	12.3	446	6,578
Motor Pool	1,926,594	8.0	252	7,645
Hangar	366,005	1.5	8	45,751
Dining Halls	124,377	0.5	24	5,182
Clubs	112,168	0.5	8	14,021
Old Madigan Hospital	736,651	3.1	79	9,325
New Madigan Hospital	2,000,000	8.4	1	2,000,000
Commissary	105,000	0.4	1	105,000
Computer Center	15,398	0.1	1	15,398
Simulators	54,200	0.2	2	27,100
Other	<u>2,116,933</u>	8.8	<u>345</u>	6,136
Total	23,937,246		4,457	

(a) Contains 1694 living units.

(b) Average floorspace per living unit.

Office/administration buildings and warehouses comprise the next largest shares with over 12% each. These are followed by other with nearly 9%, the New Madigan Hospital with over 8%, and motor pools with 8% of the total floorspace.

3.2 ELECTRICITY USE BASELINE

The limited availability of metered data created a challenge in developing the baseline electricity use. The Fort is served by three substations, designated as Madigan, South, and Central. Each substation is metered

separately by TPU for both demand and power use. Aside from the commercial (nonappropriated) buildings on the Fort, these are the only sites where electricity use for the installation is metered. A total of 17 feeder lines from these three substations provide all electrical power to the Fort.

We metered each substation and feeder separately and collected time-series data for 4 consecutive months. The metering was done primarily to measure the electric demand profile for the Fort and to determine the relative contributions to that demand of each of the three substations and 17 feeders. The secondary purpose was to provide the only metered data for an accurate assessment of the electrical energy use intensities of the building stock.

The areas and primary buildings at the Fort serviced by each of the feeders is given in Table 3.2. The percentage of the total load served by each substation and the percentage of the substation load served by each feeder are shown. The areas or primary buildings served are also displayed in descending order of electrical load on the feeder.

We used this information to ascertain and pinpoint the potential for energy efficiency opportunities in the various sectors of the Fort served by the 17 feeders, for both demand and baseload savings. The data were also used to more accurately determine the estimated energy use and energy use intensities of each of the defined building types at the Fort. Without this metered information, we would have performed the analysis using billing data from the three substations; thus, much more uncertainty would be associated with this foundational analysis. The feeder-level metered data give a more reliable, accurate indicator of the electrical energy use for individual facilities and groups of facilities and more accurately portray the efficiency potential at the Fort.

The results of the metering study showed that the Fort has a daily base-load of 15,000 to 17,000 kW, and that the peak demand of 27,000 to 30,000 kW usually occurs before noon, depending upon the season. The data revealed that the Central substation accounted for nearly 50% of the total Fort demand.

TABLE 3.2. Substations and Feeders Serving Fort Lewis

<u>Substation</u>	<u>% Total Load</u>	<u>Feeder No. (% Substation Load)</u>	<u>Areas/Building Served</u>
Madigan	13	M1 (3)	Residential/Warehouse
		M2 (32)	New Madigan Hospital
		M3 (65)	Warehouse/Motor Pool/Office
South	34	S2 (14)	Residential/Warehouse/Office/Dining
		S3 (17)	Barracks/Office/Motor Pool/Warehouse
		S4 (32)	Residential/Clubs
		S5 (37)	Office/Barracks/Motor Pool/Hangar
Central	53	A1 (5)	Switching Alternate
		A2 (14)	Barracks/Office/Warehouse
		A3 (10)	Clubs/Warehouse
		A4 (16)	Office/Barracks
		A5 (18)	Barracks/Motor Pool/Office/Hangar
		A6 (18)	Office/Motor Pool/Warehouse
		A7 (<1)	Switching Alternate
		A8 (2)	New Madigan Hospital
		A9 (12)	School/Logistics Center
		A10 (5)	Old Madigan/Office/Barracks/Resid.
Total	100		

From the data, we also determined that most of the 16^(a) feeder loads were not temperature-dependent; therefore, opportunities for electrical energy savings (kilowatt-hours) exceed the opportunities for demand savings (kilowatts).

These data are pivotal for pointing out the areas of the Fort served by the feeders for further detailed evaluation of electrical use reduction potential. For example, it was evident that the Central substation load would have the most potential for reducing both demand and energy use. Feeders A5, A6, and A9 all showed significant peak demand of greater than 2500 kW during

(a) One of the feeders was a switching alternate and no load was measured during the monitoring period.

the monitoring period. These feeders serve barracks, offices, motor pools, warehouses, and the logistics center, facilities where both demand and energy savings potential are greatest.

Estimates indicate that the buildings sector accounts for over 80% of the electricity use at Fort Lewis. Given this, and the number of building types that comprise the buildings sector use, the estimated EUIs developed for the sector by building type are discussed before the baseline profile; these are displayed in Table 3.3. The estimated EUIs provide the intensity of energy use by the four end uses (lighting, domestic hot water, refrigeration, and other) and for the building total. Detail on the development of the buildings sector EUIs is contained in Appendix B; the baseline development for the other three sectors is discussed in their respective appendixes.

TABLE 3.3. Buildings Sector Electricity End-Use Intensities

<u>Building Type</u>	<u>EUI (kWh/ft²-yr)</u>				<u>Total</u>
	<u>Lighting</u>	<u>DHW</u>	<u>Refrigeration</u>	<u>Other</u>	
Single Family	1.31	2.90	0.77	2.91	7.89
Multifamily	1.39	2.86	0.76	2.88	7.89
Concrete Barracks	3.25			3.75	7.00
Wood Barracks	0.74			0.67	1.41
Office/Admin.	3.58	0.54		3.71	7.83
Warehouse	2.05	0.01		1.70	3.76
Motor Pool	2.66	0.60		1.91	5.17
Hangar	2.97	0.25		2.50	5.72
Dining Halls	10.00			48.00	58.00
Clubs	10.29			21.50	31.79
Old Madigan Hospital	6.11			11.95	18.06
New Madigan Hospital	3.00			1.00	4.00
Commissary	7.00			43.00	50.00
Computer Center	7.64			24.43	32.07
Simulators	4.24	0.06		84.20	88.50
Other	2.30	0.30		2.00	4.60

Other than family housing, most domestic hot water was supplied through an onsite fossil-fueled boiler or through a district heating system, which results in a low or no electrical EUI for that end use. Similarly, residential types of refrigerators were not present in most building types other than family housing. A significant note is the low EUIs for the New Madigan Hospital; these are expected to increase markedly once the hospital is commissioned and in full operation in mid-1993.

The estimated baseline by sector, subsector, and end use is shown in Table 3.4.

The estimated total consumption of 197,000 MWh compares well with actual levels of approximately 195,000 MWh. Therefore, it is felt that the estimated consumption provides a reasonable approximation of the actual. Within this total, the buildings sector accounts for 86%, pumps/motors for over 2%, distribution for nearly 8%, and exterior lighting for nearly 4%.

From an end-use standpoint, total lighting energy is estimated to account for nearly 35% of the total, hot water for over 10%, refrigeration for over 2%, and the remaining 52% by all other uses. Fluorescent lighting is estimated to comprise about two-thirds of the total lighting energy.

Four building types (single-family, multifamily, concrete barracks, and office/administration) each account for over 10% of total consumption and, combined, are estimated to account for over 45% of total annual electricity consumption. Only three other building types (warehouse, motor pool, and the Old Madigan Hospital) are estimated to consume more than 5% of the total, although the New Madigan Hospital share of the total is expected to increase significantly when it is in full operation.

3.3 ELECTRIC EFFICIENCY SUPPLY CURVE

The LEC and efficiency resource by each of the measures considered (see Section 2.3.2) and the cumulative efficiency resource are shown in Table 3.5. The levelized cost ranges from \$0.0022/kWh for replacing domestic hot water heaters on failure with high-efficiency nonmetallic units to over \$0.26/kWh for replacing a seldom-used well pump on failure with a high-efficiency unit.

TABLE 3.4. Estimated Electric Baseline (MWhs) by Sector, Subsector, and End Use

Sector	Lighting						Ref.	Other	Total	% of Total
	34-W	Fluorescent 40-W	96-W	Inc	HID	Total				
Building										
Single-Family				4,210		4,210	9,287	2,477	9,339	25,313
Multifamily				3,713		3,713	7,650	2,040	7,707	21,110
Concrete Barracks		8,496		1,935		10,431			12,064	22,495
Wood Barracks		557		531		1,088			982	2,071
Office/Admin.		8,804		1,564		10,368	1,817		10,478	22,663
Warehouse		3,581	2,388	56		6,025	26		4,990	11,041
Motor Pool	1,209	2,508		5	1,400	5,122	1,140		3,682	9,944
Hangar	460	147		17	460	1,084	92		912	2,088
Dining Halls		879		374		1,252			5,955	7,207
Clubs		231		923		1,154			2,410	3,565
Old Madigan		4,502				4,502			8,807	13,309
New Madigan		5,959				5,959			2,023	7,982
Commissary					735	735			4,515	5,250
Computer Center		118				118			376	494
Simulators		230				230	3		4,564	4,797
Other		2,967		1,906		4,873	637		4,249	9,759
Subtotal	1,669	38,980	2,388	15,235	2,595	60,867	20,653	4,517	83,053	169,088
Pumps/Motors										
Water Supply									3,600	3,600
Sewage Treatment									1,160	1,160
Subtotal									4,760	4,760
Distribution										
Transformer									13,000	13,000
Line Loss									2,000	2,000
Subtotal									15,000	15,000
Exterior Lights										
Residential				1,290		1,290			1,290	0.7
Other Building				491	1,962	2,453			2,453	1.2
Street					4,000	4,000			4,000	2.0
Subtotal				1,782	5,962	7,744			7,743	3.9
Total	1,669	38,980	2,388	17,016	8,558	68,611	20,653	4,517	102,813	196,591
% of Total	0.8	19.8	1.2	8.7	4.4	34.9	10.5	2.3	52.3	100.0

TABLE 3.5. Levelized Energy Cost and Efficiency Resource by Measure and Cumulative Efficiency Resources

Measure	Marginal Levelized Real Cost (\$/kWh)	Marginal Annual Energy Use Decrease (kWh)	Cumulative Annual Energy Use Decrease (kWh)	Initial Capital Cost (1991 \$ thousands)
DHW: ROF ^(a)	0.0056	2,427,754	2,427,754	1,439
WS: ROF - Well #18	0.0066	13,810	2,441,564	1
DHW: Complete replacement ^(a)	0.0081	167,431	2,608,995	1,572
F1-75-W: New fix. w/refl., ballast	0.0098	1,318,273	3,927,268	220
F1-40-W: New fix. w/refl., ballast ^(b)	0.0166	25,915,995	29,843,263	6,662
F1-34-W: New fix. w/refl., ballast ^(c)	0.0167	957,498	30,800,761	250
ST: ROF - Effluent pumps	0.0181	30,747	30,831,508	8
Inc.: Replace w/compact fl	0.0203	6,199,405	37,030,913	754
TRANS: 50 kVA Transformers	0.0210	1,500,308	38,531,221	619
TRANS: 37.5 kVA Transformers	0.0228	699,314	39,230,535	313
WS: ROF - Well #19	0.0251	5,522	39,236,057	2
WS: ROF - Well #15	0.0263	6,955	39,243,012	3
TRANS: 25 kVA Transformers	0.0275	606,455	39,849,467	327
TRANS: 75 kVA Transformers	0.0335	865,947	40,715,414	569
WS: ROF - Well #10	0.0357	32	40,715,446	<1
TRANS: 100 kVA Transformers	0.0373	120,387	40,835,833	88
WS: ROF - Sequal spring	0.0562	24,573	40,860,406	21
WS: ROF - Well #13	0.0567	2,869	40,863,275	2
TRANS: 200 kVA Transformers	0.0605	374,132	41,237,407	443
WS: ROF - Well #14	0.0613	3,528	41,240,935	3
WS: ROF - Well #12	0.0613	7,498	41,248,433	7
TRANS: 15 kVA Transformers	0.0771	205,211	41,453,644	310
TRANS: 300 kVA Transformers	0.0800	206,202	41,659,846	324
F1-40-W: Install F30 T-8 fixtures ^(b)	0.1061	2,483,238	44,143,084	9,690
Refrigerators: Replace	0.1113	1,387,167	45,530,251	1,843
WS: ROF - Well #9	0.1165	494	45,530,745	<1
TRANS: 500 kVA Transformers	0.1180	208,314	45,739,059	482
TRANS: 750 kVA Transformers	0.1333	176,512	45,915,571	461
TRANS: 1000 kVA Transformers	0.1410	53,305	45,968,876	147
TRANS: 1500 kVA Transformers	0.1419	92,446	46,061,322	257
TRANS: 5 kVA Transformers	0.1564	6,398	46,067,720	20
TRANS: 2500 kVA Transformers	0.1582	15,074	46,082,794	47
WS: ROF - Well #17	0.2615	878	46,083,672	3
F1-34-W: Install F30 T-8 fixtures ^(c)	3.7801	1,985	46,085,657	340

(a,b,c) These measures are mutually exclusive and only one will be selected.

The cumulative efficiency resource column provides the total resource available as successive measures are considered, adding in the marginal contribution by measure. In cases where the measures are not mutually exclusive, such as transformer and motor replacement on failure, the annual resource is added to the cumulative total. In cases where the measures are mutually exclusive, such as lighting and water heater measures, only the marginal increment provided by the successive measure is added to the cumulative total. For example, in the case of retrofitting fluorescent fixtures having 40-W tubes with reflectors and ballasts that provide 25,916 MWh of resource or replacing these fixtures with T-8 fixtures having 30-W tubes that provide 28,399 MWh of resource, the additional resource provided by the latter measure is 2,483 MWh.

The levelized cost and annual efficiency resource columns are displayed graphically in Figure 3.1. The supply curve is relatively flat through a levelized cost of about \$0.026/kWh, providing over 42,000 MWh of efficiency resource. At costs above \$0.026/kWh, the slope increases significantly and the additional resource available becomes negligible by comparison.




FIGURE 3.1. Electric Efficiency Supply Curve

For the efficiency measures selected, the estimated electric efficiency resource by sector and end use are presented in Table 3.6 for the three cost categories.

The total estimated electric efficiency resource available at a cost of \$0.075/kWh and less is 43,733 average annual MWh, representing 4.99 average annual MW of capacity. Of this, 86% is available at less than \$0.023/kWh, with another 13% available at between \$0.024 and \$0.045/kWh, and the remaining 1% at a cost of \$0.046 to \$0.075/kWh.

In the lower cost range, over 37,000 average annual MWh are provided by efficiency improvements to water heaters, water supply pumps, interior lighting, exterior lighting, water treatment pumps, and voltage regulation. This represents over 4 average annual MW of capacity. Additional transformer and water supply pump replacements, in addition to a different set of lighting and water heating improvements, contribute another 5,907 MWh (0.7 average MW capacity) to the resource potential for the mid-range cost. The upper cost range contains another 412 MWh provided by additional replacements of water supply pumps and transformers. Lighting measures account for over 90% of the efficiency resource available in the lower cost range and nearly 85% of the resource of the total resource available up to a cost of \$0.075/kWh.

TABLE 3.6. Electric Efficiency Resource Availability by End Use and Cost Range

End Use	Cost Range			Total MWh
	\$0.00 to \$0.023/kWh	\$0.024 to \$0.045/kWh	\$0.046 to \$0.075/kWh	
Refrigeration	0	0	0	0
Water Heating	778	1,817	0	2,595
Lighting	34,391	2,485	0	36,876
Pumps/Motors	45	12	38	95
Transformers	<u>2,200</u>	<u>1,593</u>	<u>374</u>	<u>4,167</u>
Total	37,414	5,907	412	43,733

3.4 NET PRESENT VALUE

As discussed in Section 2.0, in addition to the supply curve methodology, the NPV of each energy efficiency measure alternative was calculated. The results are given in Table 3.7. This approach, required of federal agencies, is designed to allow evaluation of each alternative as an investment. A positive NPV indicates that the benefits of an alternative outweigh its costs, and the higher the NPV of an alternative, the more attractive it is. In the absence of subsidies (cost-sharing or rebates), and real energy price escalation, the maximum NPV option from a set of mutually exclusive options will be the one that has a marginal LEC closest to the federal facility's cost of energy without exceeding the cost.

3.5 CHOOSING ENERGY EFFICIENCY MEASURES

The information developed in Section 3.0 will allow the utility and Fort to choose the electric energy efficiency measures to install in the site-wide retrofit. The choices will hinge on the final cost-sharing agreement as well as agreement on the LEC "cutoff" and NPV criteria. These are discussed below.

3.5.1 Criteria

Using the LEC values, efficiency measures up to the cost of the marginal supply resource for Bonneville (\$0.045/kWh) may be considered cost-effective. All options that are not part of mutually exclusive sets that have LECs less than the avoided cost should be selected. Options that are part of mutually exclusive sets should be chosen if they have the LEC closest to the avoided cost of energy, while not exceeding the avoided cost. A federal agency is required to select energy efficiency options based on the NPV. Therefore, the option with the highest NPV should be considered cost-effective by the Fort.

These two criteria can lead to identical choices of options under the following conditions:

1. The installation bears the full cost of installing the measure.
2. There is no real energy price escalation.
3. The price the utility charges the installation is equal to the utility's avoided cost.

TABLE 3.7. Net Present Value of Efficiency Measures by End Use for Measures with Highest NPV^(a)

<u>End Use</u>	<u>Option</u>	<u>NPV (1991 \$)</u>	<u>Marginal Annual Energy Decrease (MWh)</u>
Refrigeration	Replace with high efficiency models	80,358	1,387
Water heating	Immediate replacement with high efficiency models	2,125,959	2,595,185
Lighting Incandescent	Replace with compact fluorescent	927,856	6,199
34-W fl	Replace with new fixt. with standard electronic ballast	277,917	957
40-W fl	Replace with new fixt. with standard electronic ballast and parabolic reflector	7,454,913	25,916
75-W fl	Replace with new fixt. with standard electronic ballast and parabolic reflector	410,348	1,318
Water Supply Pumps Sequal Spring	Replace upon failure	4,739	25
Well #9	Replace upon failure	29	0.50
Well #10	Replace upon failure	8	0.03
Well #12	Replace upon failure	1,362	7
Well #13	Replace upon failure	550	3
Well #14	Replace upon failure	641	4
Well #15	Replace upon failure	1,806	7
Well #18	Replace upon failure	4,192	14
Well #19	Replace upon failure	1,448	6
Water Treatment Pumps Effluent Pumps	Replace upon failure	8,544	31

TABLE 3.7. (contd)

End Use	Option	NPV (1991 \$)	Marginal Annual Energy Decrease (MWh)
Transformers			
15 kVA	Replace with high efficiency	37,004	205
25 kVA	Replace with high efficiency	197,780	606
37.5 kVA	Replace with high efficiency	237,665	699
50 kVA	Replace with high efficiency	517,748	1,500
75 kVA	Replace with high efficiency	267,148	866
100 kVA	Replace with high efficiency	35,792	120
200 kVA	Replace with high efficiency	85,771	374
300 kVA	Replace with high efficiency	35,395	206
500 kVA	Replace with high efficiency	12,517	208
750 kVA	Replace with high efficiency	2,672	177

- (a) Discount Rate: 4.7%.
 Fuel Escalation: NIST.
 Fort pays 15% of capital costs.
 Fort pays all O&M costs for all years.

If the capital cost of a measure is cost-shared, the measure may be selected on the NPV basis even though its LEC is above the installation's cost of energy. This occurs because the LEC is intended to reflect the true cost of the energy conserved, and therefore includes the entire cost of the measure, regardless of who pays for it. The NPV, on the other hand, is a measure of the attractiveness of an investment from the installation's point of view, and hence only includes the installation's portion of the cost (capital cost).

If the installation pays for only 15% of the cost of the measure (85% utility cost-share), measures with marginal LECs many times higher than cost

of electricity have positive NPVs. Most of the measures that would be chosen on the basis of a positive NPV (those shown in Table 3.7) would not be chosen on the basis of LEC assuming an avoided cost equal to the price of electricity paid by the installation.

3.5.2 Example

For example, based on NPV data, the best choice for retrofitting fluorescent lighting fixtures having 40-W tubes is a new fixture with electronic ballast and reflector. This choice also shows a LEC of \$0.0166/kWh which will also be acceptable to the utility. Another viable choice for fixture replacement may be retrofitting with a higher efficiency type T-8 fixture. The NPV is near that of the high-efficiency fixture and the LEC is \$0.0245/kWh, below the Bonneville avoided cost. However, the marginal LEC for this retrofit is \$0.0378/kWh which is well above long-term avoided cost. Based on these data, this technology may not be selected.

Other choices analyzed (shown in Appendix B) included ballast replacement (only) or adding reflectors for replacement. These choices had a lower NPV, a negative marginal energy savings compared to complete fixture replacement. These technologies also had higher LECs compared to the complete fixture replacement.

In conclusion, examination of the results of the analysis conducted in this assessment (with the above cost-sharing split) show that the choice of criteria (LEC or NPV) will not significantly affect the ultimate choice of energy efficiency measures to be installed at the Fort. The most desirable measures, in terms of both overall energy savings and in terms of NPV could be selected and implemented using either criteria. If all positive NPV measures less than the Bonneville avoided cost were implemented, the combined NPV would be in excess of \$10 million.

APPENDIX A

DATA SOURCES

APPENDIX A

DATA SOURCES

Data sources used to characterize the baseline and electric energy efficiency resource include databases maintained by the Fort, energy studies conducted previously for the Fort, and information available from other sources. These sources are described in this appendix.

A.1 DATABASES

A.1.1 Building/Facility Database - Base Format (Fort Lewis - Electronic File)

The database file provided by Fort Lewis contains information on 3399 non-family housing structures located on the main post, including all permanent and temporary buildings, and nonbuildings (e.g., sheds and shade covers, which are typically unconditioned). Virtually all of the buildings are a part of the regular Army and civilian contingent. A few (10 to 20) are a part of the Army Reserve function. Not included in this database are family housing units.

The database contains the following five columns of information for each structure:

- building number
- building use description by original function
- number of floors - Those with "0" floors are meant to be primarily nonbuilding structures (e.g., boat ramps, shade covers, latrines, other similar nonconditioned items). Some miscoding has occurred (e.g., "fire station" is "0," while several "overhead covers" are "1").
- "official" square footage of structure - This includes conditioned and unconditioned areas of structure and may include external areas (e.g., carports, shade roofs). Again, some miscoding is present in the form of enclosed structures with a "0" area.
- code indicating current use of structure - This is a five-digit category code; see Section A.1.2 below.

A.1.2 Building Type Coding List (Fort Lewis - Paper Copy)

This list contains three-digit category codes used by the Army to categorize all buildings and facilities by their type (e.g., hangar, barracks) or area of use (e.g., airfield, shipyard).

A.1.3 Building/Facility Database (IFS) (Fort Lewis - Paper Copy)

This printout contains information on the breakdown of housing areas (e.g., size, number of units, age, location, construction type). This print-out also appears to contain the same information on all other buildings on the post. No electronic copy was available at the time.

A.1.4 Real Property Housing List (Fort Lewis - Paper Copy)

This document includes a breakdown of single-family residential housing by area and quantity. It provides information not available elsewhere.

A.1.5 Energy Use Spreadsheet (Fort Lewis - Electronic File)

This spreadsheet presents various compilations of energy use for the post from 1986 to 1989. It includes monthly energy use for electricity, natural gas, and #2 and #6 fuel oil. The use is displayed according to user: primary post, housing, and National Guard.

A.1.6 Energy and Demand by Substation Feeder Spreadsheet (Fort Lewis - Electronic File)

These spreadsheets provide monthly metered energy and demand levels for several years for the post.

A.1.7 Housing and Water Pump Meter Reading Spreadsheet (Fort Lewis - Electronic File)

This spreadsheet contains monthly meter reading values from the Fort-owned meters in place at various housing areas and certain water pumping stations. Also included are similar readings for the various substation feeders throughout the Fort.

A.1.8 Post Maps (Fort Lewis)

One set of maps includes building numbers for all identifiable buildings on the post. A second electric line feeder map was color-coded during a site

visit to identify groups of buildings and facilities with their respective substation feeders.

A.1.9 Computer-Aided Design (CAD) Drawings of Representative Post Buildings (Fort Lewis)

The post CAD drawings provided no connected load, construction type, or occupancy information. Printouts of the CAD layouts were available for use in additional data-gathering by walk-through audits.

A.1.10 Post Transformer Spreadsheet (Fort Lewis - Electronic File)

The database file provided by Fort Lewis contains information on the 2059 pole and pad mount transformers, switches, and capacitors located on the main post. Approximately 2029 are actual transformers. According to Fort Lewis personnel, this file was very recently upgraded based on a survey required by the U.S. Environmental Protection Agency (EPA).

The following 14 columns of data are included in the database:

- item number (primarily sequential)
- manufacturer
- number of cycles
- impedance value (sometimes "0")
- cooling medium (e.g., oil, air)
- manufacturer's serial number
- number of phases
- kVA rating (sometimes "0")
- style (not usually indicated)
- type (not usually indicated)
- primary (high side) voltage
- secondary (low side) voltage
- service type (e.g., pole mount, pad mount)
- unit location (usually building number).

A.2 FORT LEWIS ENERGY STUDIES

A.2.1 Energy Resources Management Plan 1987 (Fort Lewis - Report)

The Energy Resources Management Plan completed in January 1987 includes economic analyses of various building conservation projects involving insulation, infiltration, controls, reduced water flows, lighting, and storm windows. This study considered only nonfamily housing buildings on the post. Reevaluations of other Fort-wide energy projects are also included. Packaged projects that include floor, ceiling, and wall insulation, as well as infiltration sealing, controls, and other measures are estimated to save over \$3 million at a simple payback of less than 5 years. The report evaluated the consolidation of two central distribution plants along with a waste incinerator. The distribution plant consolidation is already in progress. The feasibility of an emergency management control system (EMCS) for the post was studied and found to be practical in only the North Fort area. The report provides only minimal information on the building stock on the post.

A.2.2. Fort Lewis Energy Savings Opportunity Survey 1987 (Fort Lewis - Report)

In this two-volume report with appendixes, potential energy conservation opportunities (ECOs) in the building stock are examined and other ECOs studied previously are reviewed. For the building stock, 91 buildings were surveyed to estimate the energy conservation potential in approximately 1400 buildings on the post from a list of 49 energy conservation measures.

A.2.3 Energy Survey of Army Dining Facilities at Fort Lewis, Washington (United Industries Corporation - Report UIC-8601)

This 1986 survey reports on an energy audit and analysis of 38 dining facilities on the post to identify retrofit and operation opportunities for improving energy efficiency.

A.2.4 Electric Substation Monitoring 1990 (Fort Lewis - Report)

This test report describes monitoring conducted to measure the electric demand profile of the Fort and to determine the contribution to the total demand by each of the three substations and associated feeder lines.

A.2.5 Commissary Electric Profile 1990 (Fort Lewis - Report)

This test report documents measurements of the total energy consumption in the commissary to determine energy use and demand per square foot and to determine whether energy conservation opportunities exist in the commissary.

A.3 SECONDARY INFORMATION

Secondary sources of information were also useful in characterizing the baseline and energy efficiency resource of the Fort. These included the following documents:

A.3.1 Conservation Resources Supply Document, Draft 1990 (Bonneville)

Report providing technical documentation of information used to develop the Bonneville Draft 1990 Conservation Supply Document.

A.3.2 Technical Appendix to Conservation Supply for the 1990 Power Plan 1989 (Northwest Power Planning Council)

Report providing technical documentation of information used to develop the Northwest Power Planning Council (NWPPC) estimate of electric energy efficiency resources in the Pacific Northwest.

A.3.3 Description of Electric Energy Use in Single-Family Residences in the Pacific Northwest, July 1989 (Bonneville, DOE/BP-13795-21)

Report providing summary information on end-use metered consumption of electricity in 499 residences in the Pacific Northwest during the period September 1984 through May 1988.

A.3.4 Description of Electric Energy Use in Commercial Buildings in the Pacific Northwest, December 1989 (Bonneville, DOE/BP-13795-22)

Report providing summary information on end-use metered consumption of electricity in nearly 100 commercial buildings in the Pacific Northwest during the period September 1984 through October 1988.

APPENDIX B

BUILDINGS SECTOR BASELINE AND EFFICIENCY ASSESSMENT

APPENDIX B

BUILDINGS SECTOR BASELINE AND EFFICIENCY ASSESSMENT

To assess total building energy use and conservation potential at Fort Lewis, a complete picture of the Fort's building stock and typical energy use was developed through a three-step process. The entire post building stock was categorized by basic building type or function, and total square footages of conditioned space for each type were derived. End-use intensities (EUI) (kWh/ft² yr) for the various energy uses (end uses) for each building type were estimated and applied to the square footage of each building type to arrive at a total energy use value for each end use for all buildings on the post. These values were then used in assessing potential post-wide energy savings for specific conservation measures.

B.1 BUILDING STOCK CATEGORIZATION

The building database provided by Fort Lewis contained information on all Fort nonresidential facilities. This includes all nonbuilding facilities (e.g., sheds, bus stop shelters, flagpoles, walkways). The database is generally set up to use a "number of floors" value of "0" to identify nonbuilding-type structures. Therefore, the original sorts (by three-digit code) of the database were based on all buildings with one or more floors. This led to the omission of many obvious conditioned buildings (apparently miscoded with "0" floor). In addition, many facilities are coded under specific operational categories, e.g., "airfield" or "maintenance," rather than categories that closely match the chosen prototypes.

For these reasons, the remainder of the database was manually searched, and additional five-digit categories were identified as fitting with the prototypes. These buildings, as well as any obvious conditioned facilities with "0" floor codings, were added to the original database sort totals. Still remaining was a small subset of buildings with one or more floors but "0" square footage. For these buildings, the square footage was obtained from Fort personnel and added to the appropriate category totals.

For residential buildings not included in the above database, different data sources were used. The Real Property Housing List and Resources Management Plan were used to arrive at total unit numbers for each housing area, as well as associated building numbers. The Building/Facility Database - (IFS) type contained square footage values for each unit and an indication of building age and type, e.g., single, duplex. Because these data existed only in paper form, they were manually transferred from the printout to arrive at square footage totals for each type and vintage (year of construction) of housing units.

The building type values derived from the various sources are summarized in Table B.1.

TABLE B.1. Fort Lewis Building Stock Summary

<u>Building Type</u>	<u>Total Area (ft²)</u>	<u>Building Count</u>	<u>Average Size/Unit (ft²)</u>
Single Residence	3,207,801	1,811	1,771
Multiple Residence	2,675,095	394	1,579 ^(a)
TOTAL	5,882,896	2,205	N/A

The vintage of all the residential units ranges from the early 1940s to the 1980s; most were constructed in the 1950s to 1960s.

Barracks

Three-story concrete	3,209,566	79	40,627
----------------------	-----------	----	--------

Includes all three-story facilities in Army code groups 721, 724 (none), and 725 (none): unaccompanied enlisted personnel barracks-type structures with or without dining areas and associated latrine and other facilities (construction type not identified in database, but virtually all three-story units are known to be concrete/brick/masonry).

Barracks

Two-story wood	1,461,532	29	15,022
----------------	-----------	----	--------

Includes all two-story or less facilities in Army code groups 721, 74032, 724 (none), and 725 (none): unaccompanied enlisted personnel barracks-type structures with or without dining areas and associated latrine and other facilities (construction type not identified in database, but virtually all two- and fewer-story units are known to be wood frame).

TABLE B.1. (contd)

<u>Building Type</u>	<u>Total Area (ft²)</u>	<u>Building Count</u>	<u>Average Size/Unit (ft²)</u>
Motor Pool	1,926,594	252	7,645
Includes all facilities in Army code groups 210 through 229, plus 123 and 1212: all maintenance and production facilities for vehicles and stationary equipment of all kinds.			
Dining Hall	124,377	24	5,182
Includes <u>all</u> facilities in Army code group 722 and 74062: unaccompanied personnel dining facilities.			
Office/Administration	2,892,262	715	4,045
Includes <u>all</u> facilities in Army code groups 131, 133, 171, 610, 620, 730 (none), 14131, 14182, 14183, 14185, 72330, 72360, and 73072: airfield communications, traffic control, training, headquarters, and administrative.			
Warehouse	2,933,673	446	6,577
Includes <u>all</u> facilities in Army code groups 124 (none), 143 (none), and 410 through 442: all supply and storage facilities including fuel, dry, and refrigerated.			
Old Madigan	736,651	79	9,324
Includes <u>all</u> facilities in Army code groups 510 through 550 and 73045 - all hospital, clinic, dental, and other medical facilities (not including the New Madigan Hospital). This includes facilities at the Old Madigan area and elsewhere on the post.			
Hangar	333,005	8	45,750
New Madigan Hospital (approximate)	2,000,000	1	2,000,000
Commissary	105,000	1	105,000
Computer Center	15,398	1	15,398
Simulator(s)	54,200	2	27,100
Club(s)	112,168	8	14,021

These values are based on information from site personnel and manual searches in the building database.

TABLE B.1. (contd)

<u>Building Type</u>	<u>Total Area (ft²)</u>	<u>Building Count</u>	<u>Average Size/Unit (ft²)</u>
Other	2,116,933	345 ^(b)	6,136 ^(b)
FORT LEWIS GRAND TOTAL	23,937,346 ^(b)	4,457 ^(b)	N/A

- (a) These 394 multiple residence buildings contain a total of 1694 units and vary from duplexes to eight-unit complexes.
- (b) Grand total includes all buildings with number of floors greater than "0," plus major facilities not yet in database and buildings with "0" floors identified as valid conditioned facilities. This value and "other" may be high or low due to database errors, as some buildings have incorrectly identified numbers of floors and missing square footages.

General Notes: It appears that many facilities are coded under specific operational categories, e.g., "airfield" or "maintenance," rather than the building types that we are used to. The accuracy of matches of these Army building categories to identified building prototypes will vary. The use of some five-digit categories provided additional detail. Sorting based on the more detailed building descriptions may be more useful. This would, however, require much more effort in scanning the entire database to identify the various building acronyms used for each type and may still be widely inaccurate.

B.2 END-USE INTENSITY AND BASELINE ESTIMATION

B.2.1 End-Use Intensity Development

EUIs can be very specific to certain buildings in any area. However, for large groups of similarly operated buildings, an average EUI can be used to estimate energy consumption for a specific end use. Several sources were consulted in estimating EUIs for the various end uses and building types represented. In some cases, an established EUI from regional forecasting documents (Bonneville and NWPPC) and actual measurements (collected in the End-Use Load and Consumer Assessment Program [ELCAP]) was used and/or modified if the building type and use was a good match. Other EUIs were derived by applying rated equipment capacities to an estimated operation schedule. Still others were derived based on a combination of the two methods.

The EUIs were developed with the focus on identifying electricity consumption within major end uses with significant efficiency improvement potential; they were not developed to provide a detailed accounting of end-use electricity consumption. The major end uses identified within the buildings sector are

- interior lighting provided by incandescent lighting, fluorescent lighting by fixtures with F-96 tubes, F-40 tubes and F-34 tubes, and high-intensity-discharge (HID) lighting
- hot water provided by residential-type electric water heaters
- refrigeration provided by residential-type and -sized units.

All other electricity consumption is combined into the other category. The composition of the consumption in this category is determined by the stock of electricity-using equipment in each of the building types and the use intensity. Although efficiency potential likely exists within this category, it is building-type dependent and is not amenable to capture in a facility-wide efficiency improvement program supported by this assessment.

Electricity used for heating, ventilating, and air conditioning (HVAC) was not identified separately because few buildings have air-conditioning equipment. In addition, most HVAC electricity use is for pumps and fans, which are not believed to have the level of efficiency resource potential sought in this assessment.

The development of the EUIs is described on the worksheets included in this section of the appendix. The worksheets provide the EUI development notes for each building type on the post.

Residential Attached/Detached
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						17-25
NWPPC	0.5	-3.0	-0.8		2.8	7.1
ELCAP	2.4 ^(a)	2.7	0.7	5.3	1.7	12.8
Fort Lewis						8.3

(a) Includes mixed lights and convenience.

Assumed						
Fluorescent-40-W						
Fluorescent-34-W						
Incandescent	1.31					
HID						
Total	<u>1.31</u>	<u>2.90</u>	<u>0.77</u>	—	<u>2.91</u>	<u>7.89</u>

End-use intensities were developed using information on the amount of electricity delivered to family housing combined with secondary information. During the period July 1989 through June 1990, 48,484,626 kWh of electricity were delivered to family housing. This was reduced by 2% to reflect assumed street lighting requirements and by 1,291,000 kWh for assumed exterior lighting energy to provide energy used directly to serve occupant needs. This adjusted total provides an annual per square foot consumption of 7.89 kWh, which serves as the control total for applying the secondary information in allocating among end uses.

NWPPC End-Use Estimates (excludes heating and cooling)

	<u>kWh/yr</u>	<u>kWh/ft²-yr</u>
Lighting		
Internal	620	0.45
External	70	0.05
Hot Water	5000	3.0
Refrigeration	1156	0.83
Dryer	950	0.68
Television	200	0.14
Other	2730	1.95

Fort Lewis Consumption Data by Housing Area

The following data are for the period July 1989 - June 1990.

	<u>kWh/ft²-yr</u>
Beachwood	12.2
Madigan	9.3
Clarksdale	10.0
Davis Hill/Parkway	5.9
Evergreen	3.9
Broadmoor	4.0
Greenwood	3.1
Hillside	12.6
Average	8.3

Other Assumptions

Water heat 90% electric, 10% gas

Cooking 100% electric

100% occupancy year round

Space heat 100% gas

Residential Multi-Unit
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						10-12
NWPPC	0.5	~3.0	~0.8		2.8	7.1
ELCAP	2.4 ^(a)	2.7	0.7	5.3	1.7	12.8
Fort Lewis						8.5

(a) Includes mixed lights and convenience.

Assumed						
Fluorescent-40-W						
Fluorescent-34-W						
Incandescent	1.39					
HID						
Total	<u>1.39</u>	<u>2.86</u>	<u>0.76</u>	<u>—</u>	<u>2.88</u>	<u>7.89</u>

See notes for Single Family Attached/Detached worksheet. Slight differences in assumed EUIs result from adjustments made for square footage and remainders.

Simulator
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						10-12
NWPPC	0.5	-3.0	-0.8		2.8	7.1
ELCAP	2.4 ^(a)	2.7	0.7	5.3	1.7	12.8
Fort Lewis						8.5
=====						
Assumed						
Fluorescent-40-W	4.24					
Fluorescent-34-W						
Incandescent						
HID						
Total	<u>4.24</u>	<u>0.06</u>	<u>—</u>	<u>—</u>	<u>84.20</u>	<u>88.50</u>

No secondary data were available for this category. The total EUI of 88.50 kWh was based upon an annualized estimate of simulator electricity consumption from metering of the helicopter simulator for a 2-week period. Lighting energy consumption is assumed to be about the same as the new administration category and one electric hot water heater per simulator is assumed. Energy use in the other category would be accounted for primarily by the simulator equipment, along with cooling energy and office and miscellaneous equipment.

Clubs
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						30-105
NWPPC						38
ELCAP	12.8 ^(a)	2.5	11.5 ^(b)	8.5 ^(c)	5.9	43.4
Fort Lewis	8.6				18.2	26.8

(a) Includes exterior lighting of 2.5.

(b) Includes food preparation.

(c) Heating and cooling energy of 4.4 and fans and auxiliaries of 4.1.

=====						
Assumed						
Fluorescent-40-W	2.06					
Fluorescent-34-W						
Incandescent	8.23					
HID						
Total	<u>10.29</u>	<u> </u>	<u> </u>	<u> </u>	<u>21.50</u>	<u>31.79</u>

EUIs were developed using the NWPPC and ELCAP data and the portion of the dining hall survey conducted for Fort Lewis that dealt with the clubs. The total EUI is assumed to be an average of the ELCAP and Fort Lewis totals, with the ELCAP total reduced by its exterior lighting and heating and cooling energy requirements (36.78 kWh). The interior lighting EUI was assumed to be similar to the ELCAP estimate and shared between fluorescent and incandescent by 20% and 80%, respectively.

Computer Center
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						
=====						
Assumed						
Fluorescent-40-W	7.64					
Fluorescent-34-W						
Incandescent	8.23					
HID						
Total	<u>7.64</u>	<u> </u>	<u> </u>	<u>1.70</u>	<u>22.73</u>	<u>32.07</u>

The EUI for the new administration category is assumed as the baseline, with the following adjustments:

- Lighting is assumed to be about 50% higher than that of the new administration category.
- An air-conditioning EUI of 1.7 kWh is based on the ELCAP Office EUI (this may be low) in place of the new administration HVAC EUI.
- The other category is assumed to be largely computer loads, which may range from 5 to 40 kWh/ft²-yr, so a value of 20 kWh was assumed in addition to the new administration other category EUI.

Old Madigan Hospital
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (health care)	4.8				14.0	11.3
NWPPC						
ELCAP						
Fort Lewis						18
Other DOE-EIA						21
=====						
Assumed						
Fluorescent-40-W	6.11					
Fluorescent-34-W						
Incandescent						
HID						
Total	<u>6.11</u>	<u> </u>	<u> </u>	<u> </u>	<u>11.95</u>	<u>18.06</u>

The total EUI of 18.06 kWh is developed based upon actual consumption of 10,158,600 kWh from October 1989 through October 1990. Lighting is assumed to be slightly higher than the new administration category because of extended operation hours in parts of the building. The other category contains cooling for approximately 10% to 15% of the floorspace. No attempt was made to identify refrigeration or electricity-fueled hot water within the other category.

New Madigan Hospital
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (health care)	8.9				53.6	11.3
NWPPC						
ELCAP						
Fort Lewis						18
Other DOE-EIA						21
=====						
Assumed						
Fluorescent-40-W	3.00					
Fluorescent-34-W						
Incandescent						
HID						
Total	<u>3.00</u>	<u> </u>	<u> </u>	<u> </u>	<u>1.00</u>	<u>4.00</u>

The total EUI of 4 kWh is based upon actual reported consumption of about 8 million kWh. Current consumption is assumed to be lighting-dominated; minimal other equipment is operating. It is expected that consumption will increase to at least 25 kWh/ft²-yr when the hospital is in full operation because of several factors including extended hours of operation, hospital equipment, operation of four chillers to supply cooling, and use of office and other miscellaneous equipment.

Other
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville	5.2				18.5	
NWPPC						
ELCAP						
Fort Lewis						18
=====						
Assumed						
Fluorescent-40-W	1.4					
Fluorescent-34-W						
Incandescent	0.9					
HID						
Total	<u>2.3</u>	<u>0.3</u>	<u>—</u>	<u>—</u>	<u>2.0</u>	<u>4.6</u>

In the other category it is assumed that 50% have

- fluorescent lighting with an EUI of 2.8 and high-wattage (>200 W) incandescent with an EUI of 1.8
- hot water heating with an EUI of 0.6
- other equipment with an EUI of 4.0.

The EUIs shown are adjusted for the 50% shares of floorspace.

Concrete Barracks
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (hotel/motel)	3.6				14-21	
NWPPC (hotel/motel)						21
ELCAP						
Fort Lewis						18
=====						
Assumed						
Fluorescent-40-W	2.65					
Fluorescent-34-W						
Incandescent	0.60					
HID						
Total	<u>3.25</u>	<u> </u>	<u> </u>	<u> </u>	<u>3.75</u>	<u>7.00</u>

The EUIs were constructed from a survey of connected load and assumed operating schedules. The concrete barracks are also assumed to operate year round at 100% occupancy:

The other category includes these end uses:

- Water cooler
- Room refrigerator
- Washer and dryer
- Stereo and television
- Central heat control
- Room space heater
- Other miscellaneous.

Wood Barracks -- Not Upgraded
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (hotel/motel)	3.6				14-21	
NWPPC (hotel/motel)						21
ELCAP						
Fort Lewis						18
=====						
Assumed						
Fluorescent-40-W						
Fluorescent-34-W						
Incandescent	0.36					
HID		—	—	—		
Total	<u>0.36</u>				<u>0.43</u>	<u>0.79</u>

The EUI was based upon a survey of connected load and assumed operating schedules. The wood barracks -- not upgraded subcategory is assumed to be 30% occupied during the year. The not upgraded subcategory is assumed to account for 70% of wood barracks floorspace.

The other end-use category includes

Washer and dryer
Stereo and television
Heat controls.

The connected load for this subcategory is assumed to be lower than other barracks as these have an open bay plan and serve primarily transient personnel.

Wood Barracks -- Not Upgraded With Dayroom
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (hotel/motel)	3.6				14-21	
NWPPC (hotel/motel)						21
ELCAP						
Fort Lewis						18
=====						
Assumed						
Fluorescent-40-W	0.44					
Fluorescent-34-W						
Incandescent	0.26					
HID						
Total	<u>0.70</u>	<u> </u>	<u> </u>	<u> </u>	<u>0.61</u>	<u>1.31</u>

The EUIs were developed from a survey of connected load and assumed operating schedules. This subcategory is assumed to be 30% occupied during the year; it also is assumed to account for 10% of wood barracks floorspace. The EUI for lighting is higher than it is for the not upgraded subcategory because of extended operating hours.

Other includes

- Washer and dryer
- Stereo and television
- Heat controls
- Other miscellaneous.

Wood Barracks -- Upgraded
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville (hotel/motel)	3.6				14-21	
NWPPC (hotel/motel)						21
ELCAP						
Fort Lewis						18
=====						
Assumed						
Fluorescent-40-W	1.69					
Fluorescent-34-W						
Incandescent	0.43					
HID						
Total	<u>2.12</u>	—	—	—	<u>1.56</u>	<u>3.68</u>

The EUIs are based on a survey of connected load and assumed operating schedules. The wood barracks -- upgraded subcategory is assumed to be 50% occupied all year. This subcategory has higher installed lighting capacity than the other wood barracks. This subcategory is assumed to account for 20% of wood barracks floorspace.

Other includes

Washer and dryer
Water cooler
Room refrigerator
Stereo and television
Heat controls.

The connected load in the other category is higher than for the other wood barracks because the rooms are enclosed and house more permanent staff.

New Administration
Electricity Baseline Development Notes

	EUI Development (kWh/ft ² -yr)					
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville	7-8.7				16.6	
NWPPC (small office)	5.17	0.50		13.5		
ELCAP	9.7 ^(a)	0.4		8.5 ^(b)	2.4	21
Fort Lewis						18

(a) 7.6 interior, 2.1 exterior.

(b) 3.9 heating and cooling, 4.6 fans and auxiliaries.

Assumed						
Fluorescent-40-W	4.24					
Fluorescent-34-W						
Incandescent	0.18					
HID						
Total	<u>4.42</u>	<u>—</u>	<u>—</u>	<u>3.48</u>	<u>1.95</u>	<u>9.85</u>

The EUI is based upon a connected load survey and assumed operating schedules. HVAC energy is for fans and auxiliary equipment; no cooling energy is assumed for this category. The other EUI is lower than for the old administration category because of observed equipment loadings and the presence of nonoffice floorspace such as lobby, hallway, and auditorium. The new administration subcategory is assumed to account for 10% of overall administration floorspace.

Old Administration
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						

Assumed						
Fluorescent-40-W	2.91					
Fluorescent-34-W						
Incandescent	0.58					
HID						
Total	<u>3.49</u>	<u>0.60</u>	<u>—</u>	<u>0.23</u>	<u>3.29</u>	<u>7.61</u>

The EUI is based upon a connected load survey and assumed operating schedules. HVAC energy is for fans and auxiliary equipment; no cooling energy is assumed for this category. The other EUI is higher than for the new administration category because of observed equipment loadings. The space comprises hallway and offices, with no lobby, auditorium, or other nonoffice functional use areas. The old administration subcategory is assumed to account for 90% of overall administration floorspace.

New Motor Pool
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						
=====						
Assumed						
Fluorescent-40-W						
Fluorescent-34-W	1.57					
Incandescent						
HID	1.14					
Total	2.71	—	—	—	3.86	6.57

The EUIs are based on a connected load survey and assumed operating schedules. The new motor pool subcategory is assumed to account for 40% of total motor pool floorspace.

Other includes

HVAC

fan coil
2 x air handler
furnace combustion motor

Hot Water

boiler control
dhw circulation

Shop Equipment

compressor
air dryer
door opener
crane
grinder
welder
exhaust fan
vehicle exhaust

Other Miscellaneous
microfiche
water cooler
soft drink machine
vending machine
radio.

Old Motor Pool -- Upgraded
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						
=====						
Assumed						
Fluorescent-40-W	0.15					
Fluorescent-34-W						
Incandescent	0.01					
HID	<u>2.70</u>					
Total	2.86	<u>0.99</u>			<u>0.61</u>	<u>4.46</u>

The EUIs are based on a connected load survey and assumed operating schedules. The old motor pool -- upgraded subcategory is assumed to account for 10% of the total motor pool floorspace.

Other includes
 HVAC
 distribution fan
 boiler combustion motor
 Exhaust fan.

Old Motor Pool -- Not Upgraded
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						

Assumed						
Fluorescent-40-W	2.57					
Fluorescent-34-W						
Incandescent	0.01					
HID						
Total	<u>2.58</u>	<u>0.99</u>	<u>—</u>	<u>—</u>	<u>0.61</u>	<u>4.18</u>

The EUIs are based on a connected load survey and assumed operating schedules. The old motor pool -- not upgraded subcategory is assumed to account for 50% of the total motor pool floorspace.

Other -- same as old motor pool -- upgraded.

Dining Hall
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis (audit)	10.2				48.3	58.5
Other (AF Study)	15				79	94
=====						
Assumed						
Fluorescent-40-W	7.00					
Fluorescent-34-W						
Incandescent	3.00					
HID						
Total	<u>10.00</u>	<u> </u>	<u> </u>	<u> </u>	<u>48.00</u>	<u>58.00</u>

The dining hall EUIs are based on a connected load survey, a dining hall audit conducted for Fort Lewis, and a dining hall study conducted for the Air Force by PNL.

Hangar -- Full Service
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						
=====						
Assumed						
Fluorescent-40-W	0.40					
Fluorescent-34-W	1.26					
Incandescent	0.05					
HID	<u>1.26</u>					
Total	2.97	<u>0.25</u>	—	—	<u>4.79</u>	<u>8.01</u>

The hangar -- full service EUI is based on a connected load survey and an assumed operating schedule.

Hangar -- All Other
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP						
Fort Lewis						
=====						
Assumed						
Fluorescent-40-W	0.40					
Fluorescent-34-W	1.26					
Incandescent	0.05					
HID	<u>1.26</u>					
Total	2.97	<u>0.25</u>	—	—	<u>2.21</u>	<u>5.43</u>

The bases for the EUIs for hangar -- all other are the same as those for the hangar -- full service, except for less shop equipment in the other category.

Warehouse
Electricity Baseline Development Notes

EUI Development (kWh/ft ² -yr)						
	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville						
NWPPC						
ELCAP	2.7 ^(a)	0.14		3.35 ^(b)	0.91	7.1
Fort Lewis						

(a) 2.4 interior lighting, 0.34 exterior lighting.

(b) 2.8 heating and cooling, 0.55 ventilation and auxiliaries.

=====						
Assumed						
Fluorescent-96-W	0.81					
Fluorescent-40-W	1.22					
Fluorescent-34-W						
Incandescent	0.02					
HID						
Total	<u>2.05</u>	<u>0.01</u>	<u>—</u>	<u>—</u>	<u>1.70</u>	<u>3.76</u>

The warehouse EUIs are based on a connected load survey and the assumed operating schedules. ELCAP interior lighting and hot water data are judged to be high for this category because of observed operation and because this building category is not electrically heated or cooled.

Commissary
Electricity Baseline Development Notes

EUI Development (kWh/ft²-yr)

	<u>Lighting</u>	<u>Hot Water</u>	<u>Refrigeration</u>	<u>HVAC</u>	<u>Other</u>	<u>Total</u>
Bonneville	16-17				41-50	
NWPPC						
ELCAP	13.5 ^(a)	3.8	51.3 ^(b)	7.9	1.94	78.4
Fort Lewis						

(a) 10.7 interior and 2.8 exterior lighting.

(b) 4.1 heating and cooling, 3.8 ventilation and auxiliaries.

=====

Assumed						
Fluorescent-96-W						
Fluorescent-40-W						
Fluorescent-34-W						
Incandescent						
HID	<u>7.0</u>	—	—	—	—	—
Total	7.0				43.0	50

The total EUI is an annualized estimate based upon a 2-week period of metering. The interior lighting is of the HID type and is reportedly underlit, so the lighting EUI is assumed to be lower than the ELCAP grocery category reduced for exterior lighting. Energy consumption in the commissary is low compared to the ELCAP data because the commissary is a new facility that is felt to be energy-efficient and has shorter operating hours than a typical grocery.

B.2.2 Baseline Development

The EUIs developed for each Fort Lewis sector were applied to their respective building type square footages to provide the estimated baseline energy use summarized in Table B.2.

B.2.3 Electricity Distribution Point Aggregation

In the process of developing the EUIs, the baseline estimates were compared to control points to identify areas for making adjustments to the EUIs and to lessen the likelihood of gross misestimation. Seventeen feeders exist that serve as electricity distribution points and for which meter readings were available. Given the distribution of buildings among the 17 feeders and potential for the feeders to be interconnected, these feeders were aggregated to nine points for checking the sector totals and building sector EUIs. The EUI adjustment process required inventorying the building stock and other subsectors by each of the nine checkpoints. The estimated building sector consumption was developed by building type for each checkpoint as the product of the building type total EUI multiplied by the square footage for respective checkpoints. The pumps/motors total sector estimate was added in on feeder A4, even though some water supply motors are located on other feeders, because the major water supply pumping station and sewage treatment plants are located on that feeder. Distribution sector losses of 7.5% of the estimated feeder total were added in, and exterior lighting sector losses were estimated based upon the stock of buildings by type and estimated total electricity using the assumptions described in Appendix E. The estimated total electricity consumption for each feeder was then compared to the metered data to identify major discrepancies, and additional adjustments to the EUIs were made. The outcome of this process is displayed in Table B.3.

Overall, the estimated electricity consumption is 5% higher than the metered consumption for the feeders, with all but two of the estimated consumption levels being within 20% of the respective checkpoint. It is felt that estimates within 20% of the metered level are reasonable, given the uncertainties that exist in developing the estimates. For feeders A2 and A4, where the estimates are more than 40% higher than the metered total, it is felt that the lower building utilization in the North Fort area led to the

TABLE B.2. Estimated Electric Baseline (MWhs) by Sector, Subsector, and End Use

Sector	Lighting						Ref.	Other	Total	% of Total	
	Fluorescent			Inc	HID	Total					
	34-W	40-W	96-W								
Building											
Single-Family				4,210		4,210	9,287	2,477	9,339	25,313	12.9
Multifamily				3,713		3,713	7,650	2,040	7,707	21,110	10.7
Concrete Barracks		8,496		1,935		10,431			12,064	22,495	11.4
Wood Barracks		557		531		1,088			982	2,071	1.1
Office/Admin.		8,804		1,564		10,368	1,817		10,478	22,663	11.5
Warehouse		3,581	2,388	56		6,025	26		4,990	11,041	5.6
Motor Pool	1,209	2,508		5	1,400	5,122	1,140		3,682	9,944	5.1
Hangar	460	147		17	460	1,084	92		912	2,088	1.1
Dining Halls		879		374		1,252			5,955	7,207	3.7
Clubs		231		923		1,154			2,410	3,565	1.8
Old Madigan		4,502				4,502			8,807	13,309	6.8
New Madigan		5,959				5,959			2,023	7,982	4.1
Commissary					735	735			4,515	5,250	2.7
Computer Center		118				118			376	494	0.3
Simulators		230				230	3		4,564	4,797	2.4
Other		2,967		1,906		4,873	637		4,249	9,759	5.0
Subtotal	1,669	38,980	2,388	15,235	2,595	60,867	20,653	4,517	83,053	169,088	86.1
Pumps/Motors											
Water Supply									3,600	3,600	1.8
Sewage Treatment									1,160	1,160	0.6
Subtotal									4,760	4,760	2.4
Distribution											
Transformer									13,000	13,000	6.6
Line Loss									2,000	2,000	1.0
Subtotal									15,000	15,000	7.6
Exterior Lights											
Residential				1,290		1,290				1,290	0.7
Other Building				491	1,962	2,453				2,453	1.2
Street					4,000	4,000				4,000	2.0
Subtotal				1,782	5,962	7,744				7,743	3.9
Total	1,669	38,980	2,388	17,016	8,558	68,611	20,653	4,517	102,813	196,591	
% of Total	0.8	19.8	1.2	8.7	4.4	34.9	10.5	2.3	52.3	100.0	100.0

TABLE B.3. Estimated Electricity Consumption as a Percentage of Total by Nine Electricity Distribution Points

Checkpoint by Feeder	Estimated Electricity Consumption (MWh)				Metered Total	Estimated as Percentage of Metered Total
	Buildings	Pumps/Motors	Distribution	Exterior Lighting		
A2	5,730		430	230	6,390	4,406 +45
A3	10,434		783	411	11,628	9,908 +17
A4	16,152	4,760	1,211	646	22,769	16,117 +41
A5	20,751		1,556	830	23,137	19,899 +16
A6	23,799		1,785	923	26,507	22,816 +16
A10+M3+A9	26,052		1,954	1,052	29,058	30,266 -4
M2+A8	8,000		600	320	8,920	8,334 +7
M1+A7	639		48	54	741	738 0
A1+S2+S3+S4+S5	<u>61,904</u>	—	<u>4,643</u>	<u>2,766</u>	<u>69,313</u>	<u>76,168</u> -9
Totals ^(a)	173,461	4,760	13,010	7,232	198,463	188,652 +5

(a) The estimated totals may not be identical to other estimates in the report because of rounding and calculation differences.

overestimate by using the average EUI. The converse of this is seen in the checkpoint consisting of feeder A1+S2+S3+S4+S5, which supplies the Main Fort area where building utilization levels are higher, providing for the estimated total to be lower than the metered total using the average EUI.

B.3 EFFICIENCY ASSESSMENT

B.3.1 Hot Water Heater

The efficiency potential, levelized cost, and net present value of wrapping water heaters and of replacing water heaters with high-efficiency models having nonmetallic tanks was examined. Two water heater wrap options and two water heater replacement options were examined:

- Option 1: Wrap all water heaters with R-11 insulating wrap.
- Option 2: Wrap the newest 30% of all water heaters.
- Option 3: Replace all water heaters with more efficient models.
- Option 4: Replace all water heaters upon failure.

One wrapping option is to wrap all existing heaters. The other is to wrap only the newest 30% of heaters. The second wrapping option is considerably more attractive because the existing domestic electric hot water heaters suffer from corrosion problems at Fort Lewis, significantly shortening the life of units with steel tanks. The replacement options are to replace all heaters at once with high-efficiency versions or to replace them with high-efficiency versions as they fail.

An estimate of the total number of electric water heaters at Fort Lewis was derived by using the baseline data, dividing the total sector water heater kilowatt-hours of a given building type by the total kilowatt-hours per water heater for that sector. No differentiation between 3000-W and 4500-W heaters was made here or in subsequent cost and energy savings calculations. Because only the total annual use in kilowatt-hours was available in the baseline data, the number and size of electric heaters in the other building category was estimated by using an average heater size of 4250 W and the operating schedule used for residential buildings.

Standby loss reductions as the result of an R-11 wrap were estimated by the Northwest Power Planning Council (NWPPC 1986) at 817 kWh/yr for an electric water heater. However, more recent PNL metered data for actual electric water heaters being used in the Northwest for residential applications indicate that standby losses are reduced an average of 611-kWh/yr. This more recent data was used for the analysis. The 611-kWh/yr figure was used as the annual savings from either wrapping an existing heater or replacing it with a high-efficiency heater.

The estimated installed cost of applying R-11 insulation wrap to electric water heaters used for this analysis is \$45.00/unit. This was taken from the NWPPC report cited above. The cost of replacing an existing heater with a high-efficiency version was assumed to be \$370, which was derived from a recent price list from the Marathon Water Heater Company for fiberglass water heaters (fiberglass is being used to overcome the corrosion problems mentioned previously). The cost of replacing a heater with a high-efficiency version upon failure was assumed to be \$22.78, the difference between the price of the \$370 efficient Marathon and the \$347.22 standard fiberglass version.

The time periods used for the levelized cost calculations vary over the options. The wrap of all existing heaters is assumed to have the life of the median Fort Lewis water heater, roughly 3 years. The 30% of the newest heaters wrapped in the second wrapping option are assumed to have 5-year lives. The option that consists of replacing all heaters immediately uses a 20-year term (the assumed life of a new, noncorroding water heater), while the option that replaces the heaters upon failure has a 24-year term, to allow the replacement and failure of all water heaters.

Using the data and assumptions described, a total of approximately 4247 domestic electric water heaters are located at Fort Lewis, two-thirds of which are located in the detached or multi-unit residential buildings. The results of the analysis are presented in Table B.4. The levelized energy cost is calculated using the NWPPC discount rate of 3%, and the net present values are calculated using the Fort's share of the capital (15%) and operations and maintenance (O&M) costs (100%).

TABLE B.4. Hot Water Heater Option Analysis: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Cost (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
R-11 Wrap All Heaters	2,595,185	0.0260	133,732	191,135
Wrap 30% of Newest	778,555	0.0161	69,538	57,340
Replace All Heaters	2,595,185	0.0057	2,125,959	1,571,552
Replace on Failure	2,427,754	0.0056	1,935,369	1,439,450

B.3.2 Refrigerators

The efficiency potential and levelized cost were estimated for replacing existing refrigerators at Fort Lewis with DOE 1990 Standard efficiency units (as defined by the National Appliance Energy Conservation Act of 1987, Public Law 100-12). Domestic-type refrigerators were identified in the baseline data in residential (detached and multifamily) and administration (old and new) building types. An estimate of the total number of refrigerators in these buildings was derived by dividing the total refrigeration consumption for each building type by the estimated individual refrigerator consumption of 1314 kWh. The estimated number of refrigerators is 3780 units.

As calculated by the baseline data, the average annual energy use for each refrigerator at Fort Lewis is 1314 kWh. It has been estimated that the 1990 DOE Standard would lower average annual energy consumption of new 18-ft³ refrigerators to 947 kWh, a savings of 367 kWh annually.

Average costs of new 18-ft³ refrigerators used for this analysis were \$488.00/unit, or \$1.8 million total for all units. This price was obtained from a local retail store, with a 0.75 multiplier applied to help account for the discount generally afforded a volume purchase. For the levelized cost calculation, an appliance lifetime of 15 years was used. The results of the analysis are presented in Table B.5.

B.3.3 Lighting

Nine lighting efficiency improvements for Fort Lewis were examined using the baseline electricity consumption data. These include

- Replace incandescent bulbs with compact fluorescent in 15% of the indoor residential fixtures, 75% of the indoor fixtures in other buildings, and 100% of the exterior fixtures.
- Replace standard magnetic ballasts with energy-efficient magnetic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace standard magnetic ballasts with electronic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace standard magnetic ballasts with tunable electronic ballasts in two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Add parabolic reflectors to two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes.
- Replace two-tube fluorescent fixtures using 34-, 40-, and 75-W tubes with new fixtures with reflectors and electronic ballasts.
- Replace two-tube fluorescent fixtures using 75-W tubes with 150-W high-pressure sodium lamps.
- Replace two-tube fluorescent fixtures using 75-W tubes with single-tube 75-W very-high-output (VHO) fixtures.
- Replace two-tube fluorescent fixtures using 34- and 40-W tubes with F-30 T-8 fixtures.

The assumptions, methodology, and analysis results for each of these improvements is described in the following subsections.

TABLE B.5. Refrigeration Option Analysis: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
Replace All Refrigerators	1,387,167	0.0113	80,358	1,842,627

B.3.3.1 Fluorescent-Incandescent Replacement

Many different types and styles of screw-in fluorescent replacements for existing incandescent are available. For this analysis, the desirability of replacing standard incandescent bulbs with "generic" integral fluorescent units^(a) was examined.

To simplify the analysis and because of a lack of more detailed data, all incandescent lighting at Fort Lewis was assumed to be 75-W bulbs. Using this assumption, an estimate of the total number of incandescent light fixtures for each building sector could be obtained using the baseline data. This was accomplished by multiplying the total number of buildings in that sector (total kWh/prototype kWh) by the baseline estimated incandescent watts per prototype building and then dividing by 75. Summing these totals across each building sector, the Fort-wide total number of equivalent 75-W incandescent fixtures was estimated to be 135,266.

The lighting output of a 20-W integral fluorescent unit is about equal to that of a 75-W incandescent. This size was, therefore, considered the "equivalent" replacement for the entire Fort. Thus, a complete replacement would decrease what is now incandescent baseline energy usage by over 73%, or approximately 12.4 million kWh annual savings. Penetration rates assumed are 15% for residential interior applications, 75% in nonresidential interior applications, and 100% for exterior applications. An additional option of replacing fixtures to accommodate compact fluorescent bulbs to increase the penetration was not considered.

PNL-collected lighting data indicate that 20-W integral fluorescent units may be purchased in quantity for about \$14 each. Whereas the average life of 75-W incandescent bulbs is 750 hours, integral fluorescent units can last from 9 to 13 times as long. Thus, for the levelized energy cost analysis, a 7500-hour lamp-life was used for these units.

The results of the analysis for replacing 53,890 incandescent with fluorescent fixtures are presented in Table B.6.

(a) Integral fluorescent units are a combined lamp, ballast, and adapter that is discarded when the lamp burns out and must be replaced.

TABLE B.6. Incandescent Lamp Replacement Analysis: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
Replace Incandescent w/Fluorescent	6,199,405	0.0203	927,856	754,454

The financial calculations do not include O&M savings that would result from reduced ordering, storing, replacing and disposing requirements associated with incandescent lamps. If these savings were factored into the analysis, the replacement of incandescents with compact fluorescents would become more attractive. An alternative to screw-in compact fluorescents would be to use fixtures with permanently installed ballasts that use plug-in fluorescent lamps to prevent reversion to use of incandescents and thereby increase the probability of energy savings over the long term. It is expected that this alternative would also be comparable financially to the strategy examined because, in addition to the lower O&M costs, a ballast replacement would not be necessary every time a lamp failed.

B.3.3.2 Fluorescent Lighting Ballast Replacements

The second set of lighting conservation options examined (Options 2, 3, and 4) looked at replacing standard magnetic core ballasts with efficient magnetic ballasts, electronic ballasts, or tunable electronic ballasts.

Cost estimates for the selected ballast options vary considerably. Table B.7 provides the ballast cost, including installation, chosen for this analysis.

TABLE B.7. Estimated Cost for Fluorescent Fixture Ballast Replacement

<u>Ballast Option</u>	<u>34-Watt</u>	<u>40-Watt</u>	<u>75-Watt</u>
Efficient Magnetic	\$12.50	\$12.50	\$17.50
Electronic	\$32.50	\$32.50	\$40.00
Tunable Electronic	\$40.00	\$40.00	\$47.50

The number of fixtures involved in each option, as well as the initial capital cost of each, are displayed in Table B.8.

The Fort-wide total number of ballasts was estimated using a process similar to that used for computing the number of incandescent fixtures. First, each building sector's 34-W, 40-W, or 75-W fluorescent lighting total annual energy usage (kWh) was divided by the total 34-W, 40-W, or 75-W fluorescent lighting consumption (kWh) for the prototype building in that sector to determine the equivalent number of prototype buildings in the sector. This number was then multiplied by the total installed watts of fluorescent lighting for the prototype and divided by the watt rating for a two-lamp fluorescent fixture. Four building sectors (Other, Clubs, Old Madigan, and Commissary) had no prototypical installed wattages, just total annual use in kilowatt-hours for the whole sector. For these building sectors, daily and yearly operation schedules were used to back out an approximate total kilowatt rating for the sector. This number could then be divided by the watt rating for a two-lamp fluorescent fixture to obtain an estimate of the number of ballasts for that sector.

Although electronic ballasts produce a higher quality light than their core counterparts, the reportedly poor existing quality lighting currently afforded by the fluorescent fixtures in these building sectors suggested that delamping opportunities are limited for this conservation option, as is the potential of dimmable (tunable) electronic ballasts. Thus, the estimated

TABLE B.8. Fluorescent Lighting Ballast Replacement Analysis: Number of Replacement Fixtures and Initial Capital Cost

<u>Ballast Option</u>	<u>Number of Replacement Fixtures</u>			<u>Initial Capital Cost (1991 \$)</u>		
	<u>34-Watt</u>	<u>40-Watt</u>	<u>75-Watt</u>	<u>34-Watt</u>	<u>40-Watt</u>	<u>75-Watt</u>
Efficient Magnetic	7,252	192,397	5,606	90,644	2,404,960	98,111
Electronic	7,252	192,397	5,606	235,674	6,252,895	224,255
Tunable Electronic	7,252	192,397	5,606	290,060	7,695,871	266,303

energy savings that could be achieved by use of electronic ballasts is based solely on the lower operating power requirements on the ballast and the reduced energy use by the tubes.

Tunable electronic ballasts were included for completeness; however, the benefits of reduced energy consumption resulting from dimming (to keep the lighting level constant) were not considered. Thus, because tunable ballasts cost more than their nontunable counterparts, tunable ballasts will have higher levelized energy costs. A more detailed analysis could very likely show that tunable ballasts are the preferred technology in rooms with significant daylighting. The results of the analysis are provided in Table B.9.

B.3.3.3 Fluorescent Lighting Reflectors

The fifth lighting conservation measure that was analyzed using the Fort Lewis baseline data was to install parabolic reflectors on 34-W, 40-W, and 75-W fixtures. The population of replacement fixtures is shown in Table B.10. Although the reflectors do not reduce energy consumption, they do cause each fixture to produce more usable light, allowing the total number of fixtures in use to be reduced. This option was analyzed on a lumen-equivalent

TABLE B.9. Fluorescent Lighting Fixture Ballast Options Analysis: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Ballast Option</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>
34-W Eff. Magnetic	158,917	0.0383	36,992
40-W Eff. Magnetic	3,944,494	0.0410	894,926
75-W Eff. Magnetic	209,903	0.0314	52,103
34-W Electronic	536,344	0.0295	135,386
40-W Electronic	13,312,666	0.0316	3,299,950
75-W Electronic	682,183	0.0221	183,524
34-W Tunable	536,344	0.0364	127,228
40-W Tunable	13,312,666	0.0389	3,083,504
75-W Tunable	682,183	0.0262	177,217

TABLE B.10. Number of Fixtures with Reflector Addition

<u>Existing Fixture Type</u>	<u>Reflectors Added</u>
40-W	121,123
34-W	4,554
75-W	3,515

basis. In the analysis, it is implicitly assumed that delamping and removal of fixtures can be accomplished on a perfectly continuous basis, to allow the final level of light to be equal to the current level. In practice this would be more difficult, as there would be locations where delamping/removal would not be feasible. An informal survey of suppliers gave a cost of \$57.50 per reflector, including installation. The results of the analysis are shown in Table B.11.

B.3.3.4 Fluorescent Lighting Fixture Upgrade

The sixth lighting conservation measure involves combining ballast replacement with parabolic reflector installation through complete replacement of the fixtures. The population of fixtures involved is the same as shown in Table B.10. The costs associated with this option are displayed in Table B.12. The results of the analysis are provided in Table B.13.

B.3.3.5 Other Lighting Technologies

Three more lighting technologies were considered in addition to the ballast replacements and reflector installations. One option was to replace fluorescent fixtures containing two 75-W lamps with 150-W high-pressure sodium (HPS) fixtures. Another option was to replace fluorescent fixtures containing

TABLE B.11. Fluorescent Lighting Fixture Reflector Analysis: Annual Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
Add 34-W Reflector	620,648	0.0270	168,978	261,872
Add 40-W Reflector	17,535,067	0.0257	4,740,160	6,964,545
Add 75-W Reflector	890,526	0.0131	276,817	202,132

TABLE B.12. Fluorescent Lighting Fixture Costs

<u>Replacement Fixture</u>	<u>Cost (1991 \$)</u>		
	<u>Replacement</u>	<u>Existing</u>	<u>Differential</u>
Two-tube 34-W	90.00	35.00	55.00
Two-tube 40-W	90.00	35.00	55.00
Two-tube 75-W	105.00	42.50	62.50

TABLE B.13. Fluorescent Lighting Fixture Replacement Option: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
34-W Fixture Replace	957,409	0.0167	277,917	250,486
40-W Fixture Replace	25,915,995	0.0166	7,454,913	6,661,738
75-W Fixture Replace	1,318,273	0.0098	410,348	219,709

34-W and 40-W lamps with F-30 T-8 fixtures. The final option was to replace fluorescent fixtures containing two 75-W lamps with single-lamp, 8-ft, very-high-output (VHO) fixtures. The population of fixtures involved is shown in Table B.14. This last option actually resulted in increased energy consumption. For this reason, the reported levelized cost is negative; this indicates that a positive payment must be made to obtain a negative savings. Needless to say, this option does not compare well with the others. The costs of replacement with other lighting technologies are shown in Table B.15. The results of the analysis are provided in Table B.16.

The calculated financial values of replacing the 8-ft fluorescent fixtures with HPS lamps are felt to be high, because lower expected O&M costs are not included. The lower O&M costs would result from reduced labor requirements to change bulbs, because the HPS bulbs have a longer life.

TABLE B.14. Number of Replacement Fixtures

<u>Replacement Fixture Type</u>	<u>Replacement Fixtures</u>
150-W HPS	4,065
34-W F-30 T-8	4,244
40-W F-30 T-8	121,123
VHO	5,419

TABLE B.15. Other Lighting Technology Replacement Options and Cost

<u>Existing Fixture</u>	<u>Replacement Fixture</u>	<u>Cost (1991 \$)</u>		
		<u>Replacement</u>	<u>Existing</u>	<u>Differential</u>
Two-tube 75-W	150-W HPS	142.00	42.50	99.50
Two-tube 34-W	34-W F-30 F-8	115.00	35.00	80.00
Two-tube 40-W	40-W F-30 T-8	115.00	35.00	80.00
Two-tube 75-W	VHO	120.00	42.50	77.50

TABLE B.16. Other Lighting Technology Options: Energy Savings, Levelized Energy Cost, and Net Present Value

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>	<u>Initial Capital Cost (1991 \$)</u>
150-W HPS	770,736	0.0527	208,862	404,430
34-W F-30 T-8	959,482	0.0245	246,431	339,502
40-W F-30 T-8	28,399,233	0.0245	7,059,222	9,689,801
VHO	-529,129	-0.0542	-240,089	420,011

B.4 REFERENCES

National Appliance Energy Conservation Act of 1987. Public Law 100-12.

Northwest Power Planning Council. 1986. 1986 Northwest Conservation and Electric Power Plan. Portland, Oregon.

APPENDIX C

MOTOR BASELINE AND EFFICIENCY ASSESSMENT

APPENDIX C

MOTOR BASELINE AND EFFICIENCY ASSESSMENT

The baseline electricity use and the efficiency improvement potential for motors used in the water supply and sewage treatment plants are described in this appendix. Section C.1 provides the assumptions used to estimate baseline energy use for water pump motors in the water supply system, along with results. Section C.2 presents the efficiency potential and levelized cost of replacing existing water pump motors in the supply system with high-efficiency models of similar horsepower. Sections C.3 and C.4 are similar to Sections C.1 and C.2, respectively, but are for the effluent pump motors used in the water treatment plant.

C.1 WATER SUPPLY BASELINE ENERGY USE

No metered electrical data were available for the water pump motors used in the water supply system at Fort Lewis. However, the following data were available from the Fort:

- average hours of operation per day for each well for each month of the year spanning October 1989 through September 1990
- total monthly pumping capacity in gallons of water for each well
- actual gallons per minute flow capacity for each of the one or more pump motors used at each well
- motor horsepower (except for the irrigation pump motors used at Well 15, which were estimated based on flow capacities relative to others).

To estimate baseline electricity use for the water pump motors from the limited data, it was necessary to make several assumptions. First, because cycling schedules of water pump motors were unknown--as were the number of days per month that they were operated--all motors associated with a given well/pumping station were assumed to be in operation simultaneously at 75% of design load for the calculation of total monthly operating hours. Motor efficiencies used for the energy calculations were based on data for

Siemens-Allis standard efficiency totally enclosed, fan-cooled (TEFC) motors operating at 75% of rated horsepower (see Table C.1, Column 1).

From the above assumptions and data, total baseline electricity use for all of the water pump motors was estimated to be about 3.6 million kWh annually. Baseline energy use for each well/pumping station in the water supply system at Fort Lewis is summarized in Table C.2.

C.2 WATER SUPPLY EFFICIENCY POTENTIAL AND COST

The energy conservation strategy chosen for the analysis of the water supply system was replacement of all existing (assumed) standard efficiency water pump motors with high-efficiency models and replacement of all pump motors upon failure. The upon-failure analysis makes no attempt to predict when the pump motors will fail: rather, it is assumed that they all fail at the start of the analysis. The only difference between the strategies, therefore, is that in the replacement option, the entire cost of a new efficient pump motor is used, while in the replace-upon-failure option the difference in cost between an efficient pump motor and a standard one is used. High-efficiency motor data were again obtained from Siemens-Allis. The installation/replacement cost estimate was based on data from the 1990 version of Richardson's Process Plant Construction Estimating Standards - Volume 4. Unit pricing in this reference is for Reliance Motors. Other costs considered when preparing this estimate include the following:

- Handling and Placing Labor - Richardson presents handling and placing man-hour estimates as a function of motor horsepower.
- Installation Materials and Labor - This category includes the materials and labor associated with foundations, structural steel, buildings, piping, instrumentation, insulation, electrical, and painting. For replacement electric motors, any foundations, structural steel, or buildings (enclosures) are presumed to already exist. Some replacement wiring and/or instrumentation may be required, however. Average values in the American Association of Cost Engineers (AACE) Recommended Practice are as follows:

TABLE C.1. Motor Pricing/Efficiency Data, Seimens-Allis Efficiency Pricing for Reliance Motors^(a)

Size, hp	Standard Efficiency	High- Efficiency	High List \$	List Price Adjustment Factor	Price Total \$	(\$16/man-hr) Labor (hr)	\$	Electrical Installation	Instru- mentation	Indirect Administration	General Administration	Total \$
0.75	0.6	0.7	334	0.823	274.88	3	48	10.99	8.24	67.24	36.13	397.50
1	0.685	0.81	342	0.823	281.46	6	96	11.25	8.44	115.70	41.68	458.55
2	0.755	0.823	412	0.823	339.07	6	96	13.56	10.17	119.73	48.25	530.80
5	0.805	0.896	478	1.161	554.95	6	96	22.19	16.64	134.84	72.86	801.51
10	0.865	0.913	795	1.161	922.99	6	96	36.9	27.68	160.60	114.82	1,263.03
15	0.85	0.928	1,042	1.161	1,209.76	8	128	48.39	36.29	212.68	150.71	1,657.84
20	0.875	0.934	1,345	1.161	1,561.54	8	128	62.46	46.84	237.30	190.81	2,098.97
25	0.87	0.932	1,608	1.161	1,866.88	10	160	74.67	56.00	290.68	228.82	2,517.07
30	0.885	0.941	1,905	1.161	2,211.70	10	160	88.46	66.35	314.81	268.13	2,949.47
60	0.895	0.943	4,489	1.161	5,211.72	18	288	208.46	156.35	652.92	522.93	6,852.30
65	0.915	0.954	5,820	1.161	6,756.0	22	352	270.28	202.71	824.99	805.50	8,860.50
100	0.928	0.952	7,140	1.161	8,289.54	26	416	331.58	248.68	996.26	966.60	10,852.68
125	0.934	0.952	9,275	1.161	10,768.77	30	480	430.73	323.04	1,233.7	1,275.58	14,031.41
150	0.945	0.958	10,942	1.161	12,703.66	36	576	508.14	381.10	1,465.2	1,505.81	16,563.99
200	0.945	0.959	12,961	1.161	15,047.72	38	608	601.90	451.43	1,661.34	1,776.24	19,538.64
250	0.95	0.96	16,652	1.161	19,332.97	44	704	773.31	579.98	2,057.30	3,374.35	25,017.94

(a) Source: Richardson's Process Plant Construction Estimating Standards - Volume 4: (TEFC 1800 rpm [1200 rpm for 3/4], 3-phase, 460V, 3/x load ratings).

TABLE C.2. Summary of Water Supply Baseline Energy Use and Conservation Potential

<u>Well/Pumping Station</u>	<u>Annual kWh Baseline</u>	<u>Annual kWh Savings</u>
Sequal Spring (3@250hp)	2,174,463	24,573
Well #9 (1@25, 1@5hp)	7,361	494
Well #10 (1@2hp)	383	32
Well #12 (2@150hp)	552,549	7,498
Well #13 (1@100hp)	113,798	2,869
Well #14 (1@125hp)	186,618	3,528
Well #15 (2@60hp ?)	136,645	6,955
Well #17 (1@150hp)	64,732	878
Well #18 (1@60hp)	271,314	13,810
Well #19 (1@30, 1@60hp)	102,652	5,522

- Electrical Material 8% of purchased equipment cost
- Electrical Material Labor 4% of purchased equipment cost
- Instrumentation Material 6% of purchased equipment cost
- Instrumentation Material Labor 3% of purchased equipment cost

- Much of the wiring and instrumentation already in place may not need to be replaced. On the other hand, there is probably more wiring associated with electric motors than with process equipment in general. The above factors should, therefore, result in a conservative estimate.

- Indirect Field Costs - This cost category includes charges for indirect labor (e.g., supervision, engineering), craft labor fringe benefits, and miscellaneous construction supplies, tools, and equipment. Per AACE Recommended Practice, this was roughly estimated as 100% of the sum of handling, placing, and material installation labor (direct labor).

- General and Administrative (Overheads) - Based on AACE recommendations, 10% of the sum of all direct and indirect costs (the sum of all cost categories noted above) was included.

- Project Contingency - In general, project contingency covers the cost of additional equipment requirements that are typically identified when more detailed designs are prepared. Because the estimate assumed replacement of all motors in the water supply system and Richardson's guidelines are based on only a single motor, the uncertainty in equipment specification and installation material requirements that would normally call for a contingency was assumed to be offset. Thus, a contingency was not included.

The results of the analysis are displayed in Table C.3.

TABLE C.3. Water Supply Analysis Results

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>
Complete Replacement			
Sequal Spring	24,573	0.2587	-6,366
Well #9	494	0.4516	-341
Well #10	32	1.1263	-70
Well #12	7,498	0.2970	-2,582
Well #13	2,869	0.2543	-715
Well #14	3,528	0.2673	-981
Well #15	6,955	0.1324	158
Well #17	878	1.2675	-2,205
Well #18	13,810	0.0334	3,368
Well #19	5,522	0.1193	288
Replace on Failure			
Sequal Spring	24,573	0.0562	4,739
Well #9	494	0.1165	29
Well #10	32	0.0363	8
Well #12	7,498	0.0613	1,362
Well #13	2,869	0.0567	550
Well #14	3,528	0.0612	641
Well #15	6,955	0.0263	1,806
Well #17	878	0.2614	-233
Well #18	13,810	0.0066	4,192
Well #19	5,522	0.0251	1,448

C.3 WATER TREATMENT BASELINE ENERGY USE

The available data for the three water treatment effluent pumps (two at 125 hp, one at 75 hp) were both more and less complete than that available for the water supply pump motors. Operation schedules and water capacities were unavailable. However, a set of metered electrical demand data (in kilowatts) for the time period between July 5 and July 13, 1990, was taken by PNL for FORSCOM. From these data it was inferred that 24-hour-a-day operation of one of the 125-hp pumps and the 75-hp pump occurred, at about 80% of full-rated

horsepower. Because no additional data were available for the effluent pumps, these data was extrapolated for 365 days/year to get a yearly total baseline energy consumption of 1.16 million kWh.

No other breakdowns on baseline energy use were available for the water treatment plant, though it is known that a large number of small motors (3/4, 1, 5, and 10 hp) are also used in the facilities for various purposes.

C.4 WATER TREATMENT EFFICIENCY POTENTIAL AND COST

The assumptions to calculate capital and installation costs of the standard efficiency effluent pump motors with high-efficiency motors are essentially the same as those presented in Section C.3 for the water supply well pumps and thus are not repeated here.

The results of the analysis are shown in Table C.4.

TABLE C.4. Water Treatment Analysis Results

<u>Action</u>	<u>Annual Energy Savings (kWh)</u>	<u>Levelized Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>
Complete Replacement	30,747	0.0807	4,249
Replace on Failure	30,747	0.0181	8,544

C.5 REFERENCE

Richardson Engineering Services, Inc. 1990. Process Plant Construction Estimating Standards - Volume 4. Mesa, Arizona.

APPENDIX D

TRANSFORMER LOSS AND VOLTAGE REGULATION EFFICIENCY ASSESSMENT

APPENDIX D

TRANSFORMER LOSS AND VOLTAGE REGULATION EFFICIENCY ASSESSMENT

The conservation potential (loss reduction) achievable by replacing the Fort Lewis transformer stock with more efficient units and regulating the voltage for the electricity distribution system was assessed. Section D.1 describes the estimation of the magnitude of the conservation resource (annual kilowatt-hour savings) and the levelized energy cost (\$/kWh) that would result from improving transformer efficiencies. Section D.2 describes the potential that may exist through improved regulation of the distribution system voltage.

D.1 TRANSFORMER EFFICIENCY IMPROVEMENT

The overall approach involved assessing the losses of the existing Fort Lewis transformer stock and a hypothetical replacement stock of more efficient transformers. The difference in the aggregate losses of these two transformer stocks represents the loss reduction potential provided by the replacement units. The value of the resource was then developed by associating a levelized annual cost of replacing transformers with the annual loss reduction that would result.

D.1.1 Approach

An inventory list supplied by Fort Lewis was used to sort the existing transformer stock by number of units at each rated capacity (in kilovolt-amperes [kVA]). This classification accounted for 2051 transformers from the current stock of 2080 units on the inventory list. The balance of 29 units was shown with a 0-kVA rating and could not be evaluated without more information.

Because no firm data were available on transformer losses in the Fort Lewis inventory, estimates were made using values found in the literature for typical transformer no-load (also called core or iron) losses and load (or copper) losses (Goenen 1986; Tepel, Callaway, and DeSteele 1987). Using a spreadsheet format, these estimated losses were associated with the existing

transformer stock at each rated capacity. Units were assigned to the nearest capacity rating for which loss data were available. For example, as no specific loss information was found for 20-kVA or 28-kVA transformers, units of these sizes were grouped with and assigned the estimated losses of 25-kVA units. No data were found for typical losses of units between 750 kVA and 7500 kVA. As a result, losses for Fort Lewis transformers in the 1000-, 1500-, and 2500-kVA classes were extrapolated from data for smaller units.

A particularly valuable set of loss and cost data was obtained from Bonneville for transformers ranging in capacity from 25 kVA to 100 kVA. These data, traceable to experience of the General Electric Company, included loss and cost information for high-loss, medium-loss, and amorphous-core transformers. Consequently, estimated loss reduction potential and costs for transformers in this capacity range are considered to be the most reliable.

Corresponding load and no-load losses taken from the above sources were entered into the spreadsheet for replacement transformers at each capacity level. Loss data for amorphous-core units were used for transformers in the 25- to 100-kVA capacity range. Replacements at other rated capacities were assumed to have the loss characteristics of the higher-efficiency replacement transformers considered by Tepel, Callaway, and DeSteele (1987).

The loss reduction potential has two components: 1) the difference between the no-load losses of the existing and replacement stocks and 2) the corresponding difference in load losses. As transformer load losses are generally reported at rated capacity, the loss reduction represented by the difference in load losses was reduced, in each case, by a loss factor of 0.62 to account for losses under actual operating conditions. The loss factor (LF) was derived from the expression given by Goenen (1986):

$$LF = 0.3 LD + 0.7 LD^2 \quad (D.1)$$

where LD is the load factor. In the absence of information on Fort Lewis load factors, a load factor of 0.75 was assumed for all transformers. Actual load

factors may vary from unit to unit. Transformers with substantially lower load factors will have lower total losses, which would tend to increase the levelized energy cost of any loss reduction achieved.

The annual loss reduction (ALR) was calculated from the expression

$$ALR = N(NLL + 0.62LL) \times 8.76 \text{ (kWh)} \quad (D.2)$$

where N is number of units in each transformer class

NLL is no-load reduction in watts/unit

LL is the load loss reduction in watts/unit.

Replacement capital costs were obtained from Bonneville for transformers in the 25- to 100-kVA capacity range and from other sources for all other capacities (Tepel, Callaway, and DeSteele 1987; Westinghouse Electric Corporation 1986, 1987). The costs for transformers in the 1000- to 2500-kVA range were extrapolated and are, therefore, the most tentative. Representative transformer installation costs were provided by a utility engineer.

The total investment for replacing transformers in each capacity grouping was estimated by multiplying the sum of the unit capital and installation cost by the number of units in each group.

D.1.2 Loss Reduction Potential

The levelized energy cost (LEC) of replacement transformers was calculated as described in Section 2.0. The life of replacement transformers was taken as 30 years for all units. No salvage value of the replaced stock was considered in the assessment, and all capital investments were assumed to occur in the first year. Operation and maintenance costs for the new transformer stock were considered to be the same as those of the replaced stock and, therefore, can be neglected in the estimation of annual levelized cost.

Summary results of the transformer loss reduction analysis are shown in Table D.1. The results include considerable uncertainty because of the lack of information on the loss characteristics of the existing transformer stock and the cost of replacement units. However, an important indication of this analysis is that an annual loss reduction of about 2.2 million kWh may be

realized at Fort Lewis by replacing existing transformers in the 37.5- to 50-kVA range with amorphous-core units at a cost of less than \$0.023/kWh. An additional annual savings of about 1.6 million kWh (for a total of 3.8 million kWh) may be realized by replacing existing transformers in the 25- to 100-kVA range with amorphous-core units at a cost of less than \$0.045/kWh. Increasing the allowable LEC to \$0.075/kWh makes 200-kVA high-efficiency transformers economically viable and increases the annual savings by 0.37 million kWh.

The results in Table D.1 show the expected trend: that it is uneconomic, as a conservation measure alone, to replace units at the low and high ends of the capacity range. Although most units below 25 kVA may have fairly high losses per unit, the unit cost of replacement is essentially the same as that of a 25-kVA unit. The smaller aggregate loss reduction potential of these units divided into a disproportionately higher cost results in a higher LEC than that of 25-kVA units. At the upper end of the capacity range (200- to 750-kVA), unit costs increase steeply while the efficiency improvement potential of the replacement stock decreases with size. This tendency results in higher LECs for this group also.

TABLE D.1. Transformer Loss Reduction and Cost

<u>Number of Units</u>	<u>Capacity (kVA)</u>	<u>Energy Savings (kWh)</u>	<u>Energy Cost (\$/kWh)</u>	<u>Net Present Value (1991 \$)</u>
21	5	6,398	0.1564	-338
332	15	205,211	0.0771	37,004
350	25	606,455	0.0275	197,780
247	37.5	699,314	0.0228	237,665
470	50	1,500,308	0.0210	517,748
339	75	865,947	0.0335	267,148
43	100	120,387	0.0373	35,792
97	200	374,132	0.0605	85,771
50	300	206,202	0.0800	35,395
47	500	208,314	0.1180	12,517
30	750	176,512	0.1333	2,672
9	1000	196,785	0.1410	-405
14	1500	522,937	0.1419	-953
2	2500	123,621	0.1582	-876

The LEC estimates for transformers larger than 1000 kVA are the least believable because of the need for extensive extrapolation to estimate losses and replacement costs. For a more accurate assessment, the economic replacement potential of these units should be considered separately on a case-by-case basis. However, in light of the general trend discussed above, it is unlikely that replacement of these units would prove to be cost-effective.

D.2 CONSERVATION VOLTAGE REGULATION

Conservation voltage regulation (CVR) is, in principle, the regulation of distribution feeder voltages so that the line loss is reduced and thus, the load farthest from the substation is maintained at the minimum acceptable voltage under all load conditions on the circuit. This practice can have the effect of reducing the average feeder voltage by several percent without any significant reduction in end-use load or appliance performance. Already required in several states, CVR is a cost-effective conservation and load management option applicable to many of the circuits in a typical utility distribution system. Energy conservation results because the energy consumption of many loads and appliances is reduced in some proportion to the reduction in voltage. Many CVR evaluations by U.S. utilities show, on average, that end-use energy consumption is reduced by approximately 0.7% for each 1% reduction in voltage. Similar reductions in peak loads have been demonstrated using CVR as a load management measure.

A study performed by PNL for Bonneville on the CVR potential of Pacific Northwest utilities showed cost-effective conservation between 170 average MW and 270 average MW at costs up to \$0.05/kWh, for the region as a whole (DeSteele et al. 1987). The best opportunities for CVR were shown to exist in densely-populated urban areas where distribution feeders are less than 3 to 12 miles long. The Fort Lewis distribution system appears similar in layout to systems that showed the best CVR potential in the PNL study. Therefore, Fort Lewis is expected to be an ideal candidate for some level of CVR application.

The general indication of the PNL study for Bonneville showed that short, densely loaded feeders can be regulated to reduce average feeder

voltages up to 5%. This translates into an end-use energy savings potential between 1% and 3.5%. On systems with automatic regulation already in place, the implementation of CVR is generally a matter of relatively simple adjustments to existing equipment. In such cases, CVR can be implemented for a few hundred to a few thousand dollars per circuit. The PNL study showed that CVR achieved by simple system adjustment usually resulted in energy conservation costs less than \$0.01/kWh. In other cases, the study showed cost-effective CVR could be achieved with higher-cost measures such as capacitor and regulator additions.

In this analysis, CVR applied to the Fort Lewis system is projected to provide a 1% reduction in total energy use at a cost of \$0.01/kWh. However, the value and practicality of CVR is highly system-specific; further study of the Fort Lewis distribution system would be necessary to evaluate its CVR potential in detail.

D.3 REFERENCES

DeSteeze, J. G., S. B. Merrick, R. C. Tepel, and J. W. Callaway. 1987. Assessment of Conservation Voltage Reduction Applicable in the Bonneville Power Administration Service Area. DOE/BP 14031-1, Prepared by Pacific Northwest Laboratory for the Bonneville Power Administration, Portland, Oregon.

Goenen, T. 1986. Electric Power Distribution System Engineering. McGraw-Hill Book Company. New York.

Northwest Power Planning Council. 1986. 1986 Northwest Conservation and Electric Power Plan. Portland, Oregon.

Tepel, R. C., J. W. Callaway, and J. G. DeSteeze. 1987. Customer System Efficiency Improvement Assessment: Supply Curves for Transmission and Distribution Conservation Options. PNL-6076, Pacific Northwest Laboratory. Richland, Washington.

Westinghouse Electric Corporation. 1986. "Unit Substation Transformers." Price List 47-400. WEC Small Power Transformer Division, South Boston, Virginia.

Westinghouse Electric Corporation. 1987. "Substation Transformers." Price List 43-300. WEC Small Power Transformers Division, South Boston, Virginia.

APPENDIX E

EXTERIOR LIGHTING SECTOR BASELINE AND EFFICIENCY ASSESSMENT

APPENDIX E

EXTERIOR LIGHTING SECTOR BASELINE AND EFFICIENCY ASSESSMENT

E.1 ASSUMPTIONS

The assumptions used to develop the baseline amount of exterior lighting energy are described in the following subsections.

E.1.1 Residential Sector

Each residential unit is served by two 60-W incandescent bulbs, of which 70% are operated 12 hours/day, 365 days/year. This provides for about 368 kWh per residential living unit per year. When multiplied by 3505 living units, the total estimated annual consumption is 1290 MWh.

No HID lighting is assumed in this sector.

E.1.2 All Other Building

Building exterior and parking lot lighting is assumed equal to 2% of nonresidential building electricity usage of 122,666 MWh, providing an estimated annual consumption of 2453 MWh. This is shared between HID and incandescent by 80% and 20%, respectively.

E.1.3 Street Lighting

Street lighting is assumed to be equal to 2% of total energy consumption of 200,000 MWh and to be 100% HID.

E.2 ESTIMATED EXTERIOR LIGHTING BASELINE

The exterior lighting baseline estimates are shown in Table E.1.

TABLE E.1. Estimated Exterior Lighting Baseline

<u>Sector</u>	<u>Incandescent</u>	<u>HID</u>	<u>Total</u>
Residential	1,290	--	1,290
Other Building Exterior	491	1,962	2,453
Street	--	4,000	4,000
Total	1,781	5,962	7,743

E.4 EFFICIENCY ASSESSMENT

The only measure considered for this sector was the replacement of 100% of the existing incandescent lighting that is less than 200 W in residential applications with compact fluorescents. This assessment is contained in Appendix B, in the discussion on installing compact fluorescent lamps in place of incandescent bulbs.

Items that were not considered in the exterior lighting sector that may add to the efficiency resource potential are

- installation of new and replacement of faulty, photocells to reduce or eliminate exterior lighting during daylight hours
- replacement of existing low-efficiency HID with lighting with high-efficiency units
- replacement of incandescent lighting that is greater than 200 W with HID or other suitable high-efficiency alternative.

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

OFFSITE

12 DOE/Office of Scientific and
Technical Communication

2 H. Goradia
Engineering & Housing Support
Center
CEHSC-FUM, Kingman Blvd.
Ft. Belvoir, VA 22060-5516

5 A. Gillespie
FORSCOM
Attn: FCEN-RDF
Fort McPherson, GA
30330-6000

2 A. Fanning
Army COE - Huntsville Division
Attn: ZEHND-ED-ME
P.O. Box 1600
Huntsville, AL 35807-4301

5 L. Harris, CE-44
U.S. Department of Energy
Federal Energy Management
Administration
1000 Independence Avenue
Washington, DC 20585

J. Richmond
Energy Management Coordinator
Alameda Bureau of Electricity
2000 Grand Street
Alameda, CA 94501

5 D. Moore
Tacoma Public Utilities
P.O. Box 11007
Tacoma, WA 98411

ONSITE

5 N. G. Flood
I Corps & Fort Lewis
Attn: AFZH-DEU
Fort Lewis, WA 98433-5000

DOE Field Office, Richland

D. R. Segna

5 R. W. Jamieson
Bonneville Power
Administration
MS: RCMB
P.O. Box 3621
Portland, OR 97208

110 Pacific Northwest Laboratory

2 G. W. Schanche
U.S. Army Corps of Engineers
Construction Engineering
Research Laboratory
P.O. Box 4005
Champaign, IL 61820-1305

J. W. Currie
J. G. DeSteeze
J. A. Dirks
T. J. Marseille
B. L. Mohler
G. B. Parker (75)
R. W. Reilly
E. E. Richman
T. J. Secrest (20)
S. A. Shankle
J. L. Stoops
Publishing Coordination
Technical Report Files (5)

END

**DATE
FILMED**

12/13/191