**SCHOOL
OF
NUCLEAR ENGINEERING**

Received by OST
DEC 13 1991

Purdue University
West Lafayette, Indiana 47907

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DOE/ER/12812--T1

DOE/ER/12812--T1

DE92 004435

Final Report

DOE Grant 8607-88ER12812

ADVANCED DEPLETION PERTURBATION METHODS

and

WASTE TRANSMUTATION IN THE IFR

Principal Investigator:

Thomas J. Downar

School of Nuclear Engineering
Purdue University

December, 1991

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

yes

The work performed under DOE research grant DE-8607-88ER12812 concerned the investigation of transmutation as a high level waste management alternative for the Integral Fast Reactor. A secondary objective of this work is to develop Sensitivity Theory for the closed nuclear fuel cycle in support of transmutation analysis.

The following report will summarize work performed under this grant. The first section will report on the work in Waste Transmutation and the second section on the work in Sensitivity Theory.

I. THE DESIGN OF AN LMR FOR BURNING MINOR ACTINIDES

The transmutation of long-lived minor actinides has received renewed interest as a means of mitigating the high level waste disposal problem resulting from the commercial production of electricity by the Light Water Reactor.¹⁻³ The prospect of metal fuel as a practical alternative for liquid metal cooled fast reactors has rekindled interest in the ability of the Liquid Metal Reactor (LMR) to burn the long lived actinide and fission product waste. Several recent studies have indicated that the hard neutron spectrum of the metal-fueled LMR designs is particularly well suited for the consumption of the fissionable transuranics. The principal problem in designing such a reactor has been to maintain acceptable safety performance of these designs while maximizing their transuranic consumption capability.

During the past two years, we have investigated various Liquid Metal Reactor designs for the primary purpose of burning the minor actinide waste from commercial Light Water Reactors (LWR). We constrained our designs to maintain acceptable safety performance as measured by the burnup reactivity swing, the doppler coefficient, and the sodium void worth. One of the principal innovations in our final LMR design was the use of two core regions, with a fissile plutonium outer core and an inner core consisting only of minor actinides. Our physics studies indicate that a 1200 MWth core is able to transmute the annual minor actinide inventory of about 26 LWRs and still exhibit reasonable safety characteristics. This represents a significant step towards mitigating

the high level waste problem, since the deployment of only four 1200 MWth actinide burners would consume all the long-lived actinide waste generated by existing Light Water Reactors in the United States.

The details of our minor actinide design are contained in a journal article that was prepared for Nuclear Technology. A copy of the article is provided as Appendix A of this report.

II. DEVELOPMENT OF ADVANCED DEPLETION PERTURBATION METHODS

Our study on the actinide burner, however, also exposed deficiencies in the current nuclear data base that significantly restrict our ability to design and analyze a reactor containing large amounts of minor actinides. Sensitivity and uncertainty analysis of our final core design indicated deficiencies in the minor actinide nuclear data can introduce uncertainties of as much as 200% in the prediction of some of the key core safety performance parameters. In order to perform this uncertainty analysis it was necessary to undertake a methods development project as part of our research.

The uncertainty analysis of a power reactor burnup performance is a fairly straightforward calculation, provided the burnup sensitivities are available for the core being designed. Depletion Perturbation methods have been developed over the years for the nonequilibrium cycle and for the equilibrium cycle without fuel reprocessing. Since fuel reprocessing is an important part of the minor actinide burner fuel cycle, it was necessary that we extend sensitivity theory to the closed nuclear fuel cycle.

The details of this work are described in a journal article that has been accepted for publication in Nuclear Science and Engineering. A copy of the article is provided in Appendix B of this report.

APPENDIX A

**THE NEUTRONICS DESIGN AND ANALYSIS OF A
LIQUID METAL REACTOR FOR BURNING MINOR ACTINIDES**

H. B. Choi and T. J. Downar

School of Nuclear Engineering
Purdue University
West Lafayette, Ind.

THE NEUTRONICS DESIGN AND ANALYSIS OF A LIQUID METAL REACTOR FOR BURNING MINOR ACTINIDES

H. B. Choi and T. J. Downar

School of Nuclear Engineering
Purdue University
West Lafayette, Ind.

ABSTRACT

A Liquid Metal Reactor was designed for the primary purpose of burning the minor actinide waste from commercial Light Water Reactors (LWR). The design was constrained to maintain acceptable safety performance as measured by the burnup reactivity swing, the doppler coefficient, and the sodium void worth. One of the principal innovations was the use of two core regions, with a fissile plutonium outer core and an inner core consisting only of minor actinides. The physics studies performed here indicate that a 1200 MWth core is able to transmute the annual minor actinide inventory of about 26 LWRs and still exhibit reasonable safety characteristics. Sensitivity analysis of the final core design indicates deficiencies in the minor actinide nuclear data can introduce large uncertainties in the prediction of the core safety performance parameters.

I. INTRODUCTION

The transmutation of long-lived minor actinides has received renewed interest as a means of mitigating the high level waste disposal problem.¹⁻³ One of the attractive features of advanced liquid metal reactors is their potential to consume a large fraction of the minor actinides generated in the production of commercial nuclear power. Several recent studies have indicated that the hard neutron spectrum of the metal-fueled LMR designs is particularly well suited for this purpose. The principal design problem has been to maintain acceptable safety performance of these designs while maximizing their transuranic consumption capability.

Because of physics related safety considerations and the many unresolved materials and chemistry issues, most recent research in LMRs for minor actinide burning has focused on designs containing a relatively low minor actinide inventory.* Recent cores designed by U.S.,¹ German,² and Japanese³ researchers have contained 5-15% minor actinides and, depending on power rating, can accommodate the annual minor actinide inventory from 2-7 LWRs.

The purpose of our work was to perform physics studies of LMR designs with a minor actinide inventory much greater than would be considered practical with current nuclear fuels technology. We wished to determine if there is sufficient motivation for pursuing further engineering research in high actinide content fuel designs. The principal objective of our work was to develop an LMR minor actinide burner that can have a significant impact on the accumulated LWR minor actinide inventory and still exhibit acceptable safety performance characteristics. Specifically, we examined three of the most important safety performance parameters of an LMR, the burnup reactivity swing, the sodium void worth, and the doppler coefficient. A secondary objective was to perform a detailed sensitivity analysis and identify some of the physics issues requiring further study. The following paper will first discuss the guidelines used in our design study and then present our minor actinide burner design. Finally,

* A notable exception to this is the ANL study of a fast reactor fueled only with minor actinides.¹ However, this design was not optimized and was not given a thorough safety analysis.

we present the results of our sensitivity study and provide some recommendations for further work on actinide transmutation.

II. ASSUMPTIONS AND PHYSICS METHODS

One of the principal assumptions in our work is that the oxide wastes in the LWR discharged fuel can be converted to the metal fuel form. We also assume that the technology exists to extract all the minor actinides from the plutonium discharge of the minor actinide burner. For purposes of the fuel cycle calculations we've assumed 100% recovery of all isotopes except americium and the fission products which we assigned 4% recovery factors based on ANL reports.⁴

All depletion calculations were performed using REBUS-3⁵ which searches for the equilibrium cycle condition of the core.* We performed our depletion calculations with 9 energy groups. The void worth and Doppler coefficient were evaluated using 21 energy groups and the isotopic number densities obtained from the depletion calculation. The 1DX⁶ code was used to generate the cross section sets from the LIB-IV⁷ nuclear data library.

In our actinide burner design we employed some of the characteristics of the Integral Fast Reactor (IFR),^{8,9} which has been thoroughly discussed in the literature. However, because the fuel material in our core is composed primarily of actinides, our final design is substantially different from the IFR or any other conventional liquid metal reactor. In the following section, we provide the details of our minor actinide core design.

III. THE MINOR ACTINIDE BURNER DESIGN

The presence of a substantial minor actinide inventory in the fuel poses some challenging core design problems. For example, the buildup of the highly reactive Pu-238 from neutron capture in Np-237 makes it difficult to maintain both a low burnup reactivity swing and a low

* The equilibrium cycle is defined as the reactor condition that is invariant for fixed fuel management and core operating conditions.

sodium void worth. In the following section we discuss first some of the basic innovations used in the core design and then the results of our fuel cycle calculations. We then analyze some of the core safety performance characteristics.

III.A Reactor Core Model

One of the most basic design goals of a minor actinide burner is to minimize the buildup of more transuranic isotopes during core operation. This discourages the use of fertile materials such as U-238 and leads to homogeneous core layouts. However, the void worth of homogeneous cores become unacceptably large (positive) as the minor actinide inventory is increased because of the fast fission effect of the minor actinides (e.g. Np-237). On the other hand, if the fuel volume fraction is reduced in order to increase the core leakage and reduce the void worth, the reactivity burnup swing becomes unacceptably large and the minor actinide inventory is reduced.

One of the principal innovations used in our design is to maintain a homogeneous core layout but to employ two core zones; an inner core consisting of minor actinide fuel and an outer core containing standard plutonium fuel. The plutonium outer core offsets much of the poor core safety performance caused by the presence of minor actinides in the inner core. We also chose to employ B_4C blocks in the center of the core, as suggested by several studies as a means of further reducing the sodium void worth.¹⁰

The core consists of 114 inner core assemblies (minor actinide assemblies), 138 outer core assemblies (plutonium assemblies), and 66 control rod sites. Both the inner and outer boundaries are surrounded with stainless steel reflector and shielded with B_4C blocks. The control rod sites are filled with HT-9 rods when control rods are out in order to reduce the spectrum hardening in the event of coolant voiding. The horizontal and vertical configurations of the core are shown in Figs 1 and 2.

The minor actinide and plutonium fuel assemblies have 271 and 169 fuel pins, respectively. The fuel has 25% zirconium and the theoretical density was assumed to be 75% to allow for fuel expansion and high discharge burnup. The isotopic compositions of the inner and outer core

assemblies were determined using the equilibrium cycle capability of the REBUS-3 code. The inner core fuel is composed of 70% Np-237 and the outer core fuel is enriched to 50% with fissile plutonium. The plutonium fuel pin diameter is smaller to keep the peak linear power less than 12.0 kw/ft. Because the outer core fuel is highly enriched and the inner core contains fertile Np-237, the power shifts from the outer to the inner core during the cycle. The general core characteristics and fuel assembly data are summarized in Tables 1 and 2 and the equilibrium cycle performance parameters are given in Table 3.

III.B Fuel Cycle Model

We chose to operate our minor actinide burner using three fuel batches and a 10 month cycle length. The relatively short cycle length is used to maintain an acceptable burnup reactivity swing. We assume the feed material for the minor actinide burner is provided by a typical 1000 MWe LWR after cooling for 3 years. At the completion of each burnup cycle, the discharged fuel is recovered and fabricated with the external feed material in the fabrication plant. The external feed material is assumed to be provided as separate plutonium and minor actinide streams with the isotopic distributions shown in Table 4.

The actinide burner accepts 689 kg of minor actinides and 557 kg of plutonium per year. The minor actinides are continuously recycled in the core, however 70% of the fissile plutonium is surplus material and is assumed to be used as fissile makeup in another reactor. The mass flow of the important isotopes is summarized in Table 5. Assuming the typical 1000 MWe LWR generates about 26 kgs of minor actinides each year, the core design here can transmute the annual minor actinide inventory from about 26 LWRs.

III.C Safety Performance

The reactivity of the inner core will increase substantially with burnup, since the minor actinides fuel consists mostly of Np-237 ($\eta = 0.94$) which results in Pu-238 ($\eta = 2.46$) after a neutron capture. As the core depletes, this reactivity gain is compensated by the decrease in the fissile plutonium in the outer core resulting in a small positive reactivity burnup swing for the core (1.19 % Δk).

The dominant contribution to the sodium void worth is spectral hardening (see Figs. 3 and 4) which we mitigate to some extent by using the HT-9 rods in the control rod sites. The isotope most responsible for the increase in reactivity upon coolant voiding is Np-237 for which η changes from 0.94 to 1.09 as the power level increases in the inner core. However, as the coolant voids in the outer core the neutron leakage increases because of the spectral hardening and the power level decreases. Because the outer core is predominantly fissile material, a reduction in the power reduces neutron production more than absorption which provides a negative coolant void worth in this region. Because the positive reactivity effect of the inner core dominates, the net effect is still a small positive void worth, however it is comparable to void worths allowed in conventional LMR designs. We tabulated the power and reaction rates by region for the voided and flooded cores in Figure 5 and Table 6 for the EOEC core. The void worth is smaller at the BOEC state because the outer core contains more fissile material and the negative reactivity contribution from this region is greater at BOEC.

Because the actinide burner does not contain U-238, the Doppler effect is smaller than a conventional LMR, but remains negative ($-0.32 \times 10^{-3} \delta T/T$). At EOEC the core contains about 50% Np-237 and therefore the largest contribution to the doppler is from Np-237 even though its highest resolved resonance is at 130 eV. The Pu-240 and Pu-242 have their strong resolved resonances at about 2.4 and 0.9 keV, respectively, but their contribution to the doppler reactivity is small since they comprise only 6.8 and 1.4 % of the EOEC loading, respectively. The safety parameters are summarized in Table 7 for both the BOEC and the EOEC core conditions.

IV. SENSITIVITY AND UNCERTAINTY ANALYSIS

Studies³ that report the potential benefits of the LMR for actinide burning have noted the potential shortcomings in the existing ability to analyze the fuel cycle of such a design. In particular the lack of credible nuclear data for the minor actinides can lead to large uncertainties in the predicted core performance. In our study we performed a detailed sensitivity and uncertainty analysis in order to provide both confidence in the predicted performance of our design itself as well as guidance in setting priorities for future experimental cross section

measurements. In this section we report the results of our study of the uncertainties in several core performance parameters attributable to nuclear data uncertainties. The methods used here are similar to those discussed in Reference [11].

The prediction error due to nuclear data can be evaluated using the data covariances and sensitivity coefficients:

$$V = S M S'$$

where V , S and M are the prediction error, the sensitivity coefficient vector, and the covariance matrix, respectively.

The covariance data were taken from ENDF/B-V for U-235, U-238, Np-237, Pu-239, Pu-240, Pu-241, Pu-242 and Am-241. We performed this study using 9 energy groups and evaluated the covariance data using the NJOY system.¹² The covariance data not contained in ENDF was taken from other published results.¹³⁻¹⁸

The sensitivity coefficient with respect to the group cross section in region k , σ_{kg} , is given as:^{19,20}

$$S_{\sigma_{kg}}^R = \frac{\delta R}{R} / \frac{\delta \sigma_{kg}}{\sigma_{kg}}$$

where R is the response to be evaluated. The sensitivity coefficients to the group-wise cross sections of the capture, fission, $\bar{\nu}$, and scattering reactions were computed using depletion perturbation theory.^{21,22} Because the actinide burner is operated in the closed fuel cycle, these sensitivities were formulated as constrained sensitivities using the recently developed methods which are reported elsewhere at this conference.²³

Our estimates of the uncertainty (1σ) in the burnup reactivity swing, the EOEC void worth, and the EOEC doppler coefficient are shown in Table 8. We emphasize that these values account only for the uncertainty due to data covariance and utilize only the covariance data that is available in the open literature. Some data, such as the neutron yield per fission, $\bar{\nu}$, of Np-237, have relatively large sensitivities but were not included in the uncertainty estimate because there

was no published covariance data. The largest contribution to the uncertainty in the burnup reactivity swing, the sodium void worth, and the doppler coefficient comes from the fast fission (0.183 - 1.35 MeV) of Np-237, which is the most abundant isotope in the reactor.

Despite the limited data base used to compute these uncertainties, we feel the uncertainty values shown in Table 8 are the correct order of magnitude and serve the purpose of identifying the important isotopes and reactions which require further study.

V. CONCLUSION

We have designed a Liquid Metal Reactor which can burn the annual minor actinide waste from about 26 commercial Light Water Reactors (LWR). One of the principal innovations of our Minor Actinide Burner (MAB) design was to employ a two region core where the actinides are burned only in the innermost region. Primarily because of this design innovation, we were able to maintain acceptable safety performance as indicated by the small burnup reactivity swing, the low sodium void worth, and the negative doppler coefficient. Sensitivity analysis of the final core design indicates deficiencies in the minor actinide nuclear data can introduce large uncertainties in prediction of the minor actinide burner performance.

VI. REFERENCES

1. R.N. Hill and et al., "Physics Studies of Higher Actinide Consumption in an LMR", International Conference on the Physics of Reactors: Operation, Design and Consumption, Vol.I, April 23-27, 1990, Marseille, France.
2. W. Balz and et al., "Core Design and Safety Aspects of Large LMFBRs with Minor Actinide Recycling", International Fast Reactor Safety Meeting, 1990.
3. T. Mukaiyama and et al., "Higher Actinides Transmutation using Higher Actinide Burner Reactors", International Conference on the Physics of Reactors: Operation, Design and Consumption, Vol.I, April 23-27, 1990, Marseille, France.
4. D.C. Wade and Y.I. Chang, "The Integral Fast Reactor Concept : Physics of Operation and Safety", *Nucl. Sci. Eng.*, 100, p507, 1988.
5. B. Toppel, 'A Users Guide for the REBUS-3 Fuel Cycle Analysis Capability,' ANL-83-2, Argonne National Laboratory, Argonne, Ill., 1983.

6. R.W. Hardie and W.W. Little, Jr., "1DX, A One-Dimensional Diffusion Code for Generating Effective Nuclear Cross Sections", BNWL-954, UC-32, March, 1969.
7. R.B. Kidman and R.E. MacFarlane, "LIB-IV, A Library of Group Constants for Nuclear Reactor Calculations", LA-6260-MS, 1976.
8. H. Khalil and et al., "Fuel Management Studies of Small Metal and Oxide LMR's," Proc. of the Topical Meeting on Advances in Fuel Management, Pinehurst, North Carolina, U.S.A., March 2-5, 1986.
9. Y. Orechwa and et al., "Core Design and Performance of Small Inherently Safe LMR's," Proc. of the Topical Meeting on Advances in Fuel Management, Pinehurst, North Carolina, U.S.A., March 2-5, 1986.
10. R.N. Hill and H. Khalil, "An Evaluation of LMR Design Options for Reduction of Sodium Void Worth", International Conference on the Physics of Reactors: Operation, Design and Consumption, Vol.I, April 23-27, 1990, Marseille, France.
11. T. J. Downar and H. Khalil, "Uncertainty in the Burnup Reactivity Swing of a Liquid Metal Fast Reactor," *Nucl.Sci.Eng.* Nov., 1991.
12. D.W. Muir and R.E. MacFarlane, "The NJOY Nuclear Data Processing System Vol.IV: The ERRORR and COVR Modules", LA-9303-M, Vol.IV(ENDF-324), 1985.
13. C.K. Paulson, *Nucl. Sci. Eng.* : 55, p24, 1974.
14. J. Frehaut and et al., *Nucl. Sci. Eng.* : 74, p29, 1980.
15. R.L. Macklin and C.W. Alexander, *Nucl. Sci. Eng.* : 104, p258, 1990.
16. B. Alam and et al., *Nucl. Sci. Eng.* : 99, p267, 1988.
17. J.W. Behrens and J.C. Browne, *Nucl. Sci. Eng.* : 77, p444, 1981.
18. H.T. Maguire, Jr. and et al., *Nucl. Sci. Eng.* : 89, p293, 1985.
19. M.L. Williams, "Perturbation Theory for Nuclear Reactor Analysis," *Handbook of Nuclear Reactor Calculations*, CRC Press, Boca Raton, FL., 1986.
20. C.R. Weisbin, R.W. Peelle, J.H. Marable, G. DeSaussure, P.J. Collins, E. Kujawski, and E. Greenspan, "Sensitivity and Uncertainty Analysis of Reactor Performance Parameters," *Advances in Nuclear Science and Technology*, Vol. 14, Plenum Press, New York, NY, 1982.
21. W.S. Yang and T.J. Downar, "Generalized Perturbation Theory for Constant Power Core Depletion", *Nucl. Sci. Eng.* : 99, p.353, 1988.
22. T.J. Downar, 'DPT: A Code to Generate Depletion Sensitivities', Argonne National Laboratory, Argonne, Ill., 1990.
23. H.B. Choi and T.J. Downar, "Sensitivity Theory for the Closed Nuclear Fuel Cycle", presented at this conference.

Acknowledgement

This work was sponsored by the U.S. Department of Energy Contract #FG07-88ER12812

Table.1 General Actinide Burner Specification

Reactor power(MWt)	1200
Core concept	Decoupled annular
Fuel height (inch)	36
Number of assemblies	
Inner core	114
Outer core	138
Number of control rods	66
Control rod parking material	HT-9
Structual material	HT-9
Capacity factor (%)	80
Cycle length (days)	304
Fuel residence time (cycle)	3

Table.2 Fuel Assembly Design Parameter

	Inner core	Outer core
Fuel composition	U/Np/Am/Cm + 25% Zr	U/Pu/Np/Cm + 25% Zr
	5/71/15/9	1/90/8/1
Volume ratio(Fuel/coolant/strucure)	38/36/26	13/72/15
Nurnber of pins per assembly	271	169
Fuel pin diameter (inch)	0.285	0.209
Cladding thickness (inch)	0.022	0.016
Pitch/diameter ratio	1.18	2.01
Fuel smear density (% T.D.)	75	75
Assembly lattice pitch (inch)	6.09	6.09

Table.3 Equilibrium Cycle Performance Parameter

	Inner core	Outer core
Power fraction (%)		
BOEC	45.64	52.31
EOEC	54.18	43.77
Peak linear power (kw/ft)		
BOEC	10.15	11.78
EOEC	10.33	9.94
Power peaking factor		
BOEC	1.72	1.31
EOEC	1.47	1.32
Peak flux ($10^{15}/\text{cm}^2\text{sec}$)		
BOEC	3.33	3.43
EOEC	3.33	3.36
Breeding ratio	0.03	0.12
Discharge burnup (MWD/kg)	82.08	198.70

Table.4 Isotopic Distribution of External Feed Material

Class 1		Class 2	
Pu236	1.26×10^{-7}	Np237	0.491
Pu238	1.14×10^{-2}	Am241	0.227
Pu239	0.571	Am242 ^m	1.00×10^{-3}
Pu240	0.224	Am243	0.225
Pu241	0.151	Cm242	8.81×10^{-5}
Pu242	4.36×10^{-2}	Cm243	7.12×10^{-4}
		Cm244	5.00×10^{-2}
		Cm245	4.60×10^{-3}
		Cm246	5.72×10^{-4}

Table.5 Mass Flow of Closed Fuel Cycle (kg/yr)

Nuclide	External feed	External discharge	Ratio ($\frac{Discharge}{Feed}$)
Pu238	6	185	30.8
Pu239	314	199	0.6
Pu241	83	38	0.5
Pu(Total)	552	596	1.1
Np237	337	0	0.0
Am241	159	131	0.8
Am243	158	133	0.8
Cm(Total)	40	0	0.0
Np-chain*	579	169	0.3

* Np-chain = Np237 + Pu241 + Am241

Table.6 Reaction Rates and Individual Void Worth (% Δk) at EOEC

Reaction	Region	Flooded core	Voided core	% Δk
Absorption	Inner core	7.85×10^{18}	7.87×10^{18}	-0.07
	Outer core	3.98×10^{18}	3.22×10^{18}	4.56
	Reactor total	1.77×10^{19}	1.76×10^{19}	0.62
Production	Inner core	1.00×10^{19}	1.11×10^{19}	6.11
	Outer core	8.12×10^{18}	7.15×10^{18}	-5.45
	Reactor total	1.81×10^{19}	1.83×10^{19}	0.66
Leakage	Reactor total	8.84×10^{16}	1.09×10^{17}	-0.12

Table.7 Reactivity Worth

	BOEC	EOEC
Burnup swing ($\% \Delta k$)		1.19
Void worth ($\% \Delta k$)	0.74	1.17
Doppler coefficient ($10^{-3} \delta T/T$)	-0.35	-0.32

Table.8 Uncertainty in Core Performance Parameter

Parameter	Reactivity Worth*	Relative Uncertainty(%)	Absolute Uncertainty(σ)*
Burnup swing	1.19	220	2.60
Void worth(EOEC)	1.17	63	0.74
Doppler coefficient(EOEC)	-0.032	35	0.011

* $\% \Delta k$

- Inner/Outer Core ▨ Reflector
- Control Rod Sites ■ B_4C Blocks

Figure 1. Horizontal View of the MAB

Figure 2. Vertical View of the MAB

Figure 3. Spectrum Hardening in the Inner Core

Figure 4. Spectrum Hardening in the Outer Core

Figure 5. Assembly Power Distribution

APPENDIX B

**SENSITIVITY THEORY FOR THE
CLOSED NUCLEAR FUEL CYCLE**

H.B. Choi and T.J. Downar

School of Nuclear Engineering
Purdue University
West Lafayette, Ind.

I. INTRODUCTION

Reactor depletion analysis constitutes one of the largest computational investments in the evaluation of new reactor concepts. This has motivated the development of methods for depletion sensitivity analysis such as Depletion Perturbation Theory (DPT), which do not require costly repetitive forward calculations.

Several authors¹⁻⁵ have made important contributions to DPT during the last several years. Gandini¹ first formally presented adjoint equations for the nuclear transmutation equations, which were later modified by Kallfelz et al.² to include the effects of flux field perturbations. Williams³ and Greenspan et al.⁴ developed a comprehensive methodology for treating perturbations to the coupled neutron/nuclide field. White⁵ extended Williams' work to the multicycle problem by incorporating a fuel shuffling operator. A general overview of Depletion Perturbation Theory as well as some of its applications to reactor analysis is provided in references [10], [11], and [13].

The recent contribution to Depletion Perturbation Theory by Yang and Downar⁶ is of particular importance to the work discussed here. In their work, they extended DPT to the constrained equilibrium cycle and explicitly accounted for the effect of practical core operating constraints such as criticality on the depletion sensitivities. However, they did not fully consider the external fuel cycle and the reprocessing and refabrication of some fraction of the discharged fuel. Since many of the current advanced reactor designs employ fissile self-sufficient fuel cycles, the accurate treatment of the external fuel cycle is an important aspect of advanced reactor analysis. Later in this paper we demonstrate the methods developed here using a closed

fuel cycle model of the Integral Fast Reactor (IFR),⁷ which is one of the most promising advanced reactor concepts currently under consideration in the United States.

The objective of our work is to extend DPT to the closed nuclear fuel cycle and to explicitly consider the effect of fuel reprocessing and refabrication on the constrained equilibrium cycle sensitivities. In the following section we discuss the mass flow in the closed fuel cycle and the equations describing the constrained equilibrium fuel cycle. In section III, we develop our method for incorporating the closed fuel cycle into the depletion perturbation equations and in section IV we demonstrate our methods with practical examples.

II. THE CLOSED NUCLEAR FUEL CYCLE

At the completion of a burnup cycle for a multi-batch core some portion of the fuel is shuffled and reloaded for the subsequent cycle. The remainder is discharged and sent to waste (the open cycle) or reprocessed for subsequent reirradiation (the closed cycle). The mass flow in the external cycle is depicted in Fig. 1. The portion of the fuel discharged at the end of the cycle has a discharge density, $\vec{N}_d$. This material is fed into the reprocessing plant where the portion sent to the fabrication facility has a density $\vec{N}_R$, and the remainder is sent to waste. If makeup material is required at the fabrication facility, the reprocessed material is combined with external feed having a density $\vec{N}_F$, otherwise some portion of the reprocessed material is sold having a sold density of $\vec{N}_S$. The fabricated fuel having a charge density $\vec{N}_C$ constitutes the fresh fuel material for the next cycle.

The fuel cycle model used in this work is based on the REBUS-3⁸ fuel cycle analysis code

which solves the nuclide transmutation equations for the in-reactor cycle and models the various operations of the ex-reactor cycle. In REBUS the shuffling and refueling operations can be represented by a discontinuity in the nuclide field at the end of the cycle, T . If $\vec{N}(r, T^+)$ represents the nuclide density vector at the beginning of the next cycle, this discontinuity condition due to the shuffling and refueling can be written in operator notation;

$$\vec{N}(r, T^+) = S_d(T) \vec{N}(r, T) + \vec{N}_C(r, T) \quad (1)$$

where $S_d(T)$ denotes the shuffling/discharge operator at T and $\vec{N}_C(r, T)$ represents the nuclide density vector of the fresh fuel loaded at T . In the REBUS model, the equilibrium fuel cycle is defined as the reactor condition that is invariant for successive operating cycles under a fixed fuel management scheme.⁹ Therefore the shuffle operator and charge density for the equilibrium cycle are fixed and the discontinuity condition in the nuclide field at the end of each cycle given by Eq.(1) is replaced by the two-point boundary condition:

$$\vec{N}(r, 0) = S_d(T) \vec{N}(r, T) + \vec{N}_C(r, T) \quad (2)$$

in which $\vec{N}(r, 0)$ is the nuclide field density vector at the beginning of the equilibrium cycle.

For practical problems, the fresh fuel composition is selected subject to some constraint on core criticality. This is usually implemented by requiring the unpoisoned reactor multiplication factor be unity at a specified time (usually at the end of a burn cycle). If k_0 is the desired value for the unpoisoned multiplication factor at the end of a burn cycle time, T , this constraint can be written as;

$$k[T, \vec{N}_C, \alpha] = k_0 \quad (3)$$

where k represents the functional for the unpoisoned multiplication factor. In the REBUS code, an iterative search is performed in which the fresh fuel enrichment is adjusted in order to satisfy the criticality constraint.

A change in some data will effect not just the equilibrium condition of the core, but will also perturb the desired value of the multiplication factor in Eq. (3). In practice, any perturbation of the core will be accommodated such that the constraint is still satisfied and therefore the core model and sensitivity method must reflect this practice. In the work here we assume the charge density, $\vec{N}_C$, is adjusted such that the k-effective at time T is "reset" to the desired value k_0 .^{10,11}

III. SENSITIVITY THEORY FOR THE CLOSED FUEL CYCLE

In depletion sensitivity theory, we are interested in estimating the first order effect of some data variation on a core depletion performance response. This response can be written as a functional of the cycle length, T , the core data, α , and the fresh fuel charge density, $\vec{N}_C$;

$$R = R(T, \alpha, \vec{N}_C) \quad (4)$$

The effect of a perturbation in some nuclear data α on the response R can be written:

$$\frac{dR}{d\alpha} = \frac{\partial R}{\partial \alpha} + \frac{\partial R}{\partial \vec{N}_C} \cdot \frac{\partial \vec{N}_C}{\partial \alpha} \quad (5)$$

where the variation of T is neglected because we will assume the cycle time is fixed. The first term on the right hand side of Eq. (5) describes the variation of R as if no constraints exist and

can be evaluated using unconstrained sensitivity methods.¹² The second term on the right hand side of Eq. (5) accounts for the change in R due to the constraint and is the focus of the work here.

Since the charge density $\vec{N}_C$ will change in order to satisfy the multiplication factor constraint, the variation of Eq. (3) must vanish such that;

$$\frac{dk}{d\alpha} = \frac{\partial k}{\partial \alpha} + \frac{\partial k}{\partial \vec{N}_C} \cdot \frac{\partial \vec{N}_C}{\partial \alpha} = 0 \quad (6)$$

where, similar to Eq.(5), the unconstrained contributions to the k variation are represented by the first term on the right hand side of the equation. The sensitivity coefficient of response R to a parameter α is defined as $S_\alpha^R = \frac{\delta R}{R} / \frac{\delta \alpha}{\alpha}$.¹³ Therefore Eqs. (5) and (6) can be written in terms of sensitivity coefficients (where $\hat{\cdot}$ is used to connote the constrained sensitivity);

$$\hat{S}_\alpha^R = S_\alpha^R + S_{N_C}^R \cdot \hat{S}_\alpha^{N_C} \quad (7)$$

$$\hat{S}_\alpha^k = S_\alpha^k + S_{N_C}^k \cdot \hat{S}_\alpha^{N_C} = 0 \quad (8)$$

The practical problem encountered in constrained sensitivity theory is how to evaluate the sensitivity of the charge density, $\hat{S}_\alpha^{N_C}$ in Eq. (7), using only the unconstrained sensitivities.

For the open or "once-through" fuel cycle, Yang and Downar¹² developed analytic expressions for $\frac{\partial \vec{N}_C}{\partial u}$ by noting that the charge density is a simple algebraic function of the fuel enrichment, in which case;

$$\frac{\partial \vec{N}_C}{\partial \alpha} = \frac{\partial \vec{N}_C}{\partial e} \frac{\partial e}{\partial \alpha} \quad (9)$$

Their expression for the constrained sensitivity, $\hat{S}_\alpha^R$, can be found by combining Eqs. (7), (8), and (9);

$$\hat{S}_\alpha^R = S_\alpha^R - \frac{S_{N_c}^R \cdot \frac{1}{\vec{N}_C} \frac{\partial \vec{N}_C}{\partial e}}{S_{N_c}^k \cdot \frac{1}{\vec{N}_C} \frac{\partial \vec{N}_C}{\partial e}} S_\alpha^k \quad (10)$$

However, in the case of the closed fuel cycle with reprocessing, the charge density is comprised of both external feed, $\vec{N}_F$, and fuel that is reprocessed from previous cycles, $\vec{N}_R$, and simple analytic expressions for $\frac{\partial \vec{N}_C}{\partial \alpha}$ are not possible. In the following sections, we develop the sensitivities for the closed fuel cycle.

III.A Sensitivity of the Charge Density

As noted in Section II, the charge density is the sum of reprocessed and feed material densities if the volume of reprocessed material, V_R , is less than the volume of the charge material, V_C . Otherwise, the charge density is the difference in the reprocessed and sold material densities. Therefore the charge density can be written as,

$$\vec{N}_C = \vec{N}_R + \vec{N}_F \quad (\text{if } V_C > V_R) \quad (11)$$

$$\vec{N}_C = \vec{N}_R - \vec{N}_S \quad (\text{if } V_C < V_R) \quad (12)$$

or in terms of sensitivity coefficients;

$$\hat{S}_\alpha^{N_C} = \frac{N_R}{N_C} \hat{S}_\alpha^{N_R} + \frac{N_F}{N_C} \hat{S}_\alpha^{N_F} \quad (\text{if } V_C > V_R) \quad (13)$$

$$\hat{S}_\alpha^{N_C} = \frac{N_R}{N_C} \hat{S}_\alpha^{N_R} - \frac{N_S}{N_C} \hat{S}_\alpha^{N_S} \quad (\text{if } V_C < V_R) \quad (14)$$

In the following sections we develop equations for the sensitivities of the reprocessed density, $\hat{S}_\alpha^{N_R}$, the feed density, $\hat{S}_\alpha^{N_F}$, and the sold density, $\hat{S}_\alpha^{N_S}$.

III.B Sensitivity of the Reprocessed Density

First we seek an expression for the constrained sensitivity of reprocessed density, $\vec{N}_R$. We assume the discharged fuel is recovered during reprocessing with an efficiency of q^i for each fuel isotope i . The reprocessed density of isotope i can then be written as the product of the recovery factor and the discharged density, $N_R^i = q^i N_d^i$. The sensitivity of the reprocessed density can be expressed as;

$$\hat{S}_\alpha^{N_R^i} = \frac{\alpha}{N_R^i} \frac{\partial N_R^i}{\partial \alpha} = \frac{\alpha}{q^i N_d^i} \frac{\partial (q^i N_d^i)}{\partial \alpha} = \hat{S}_\alpha^{N_d^i} = \hat{S}_\alpha^R \quad (15)$$

where the response R is the discharge density of isotope i , N_d^i . Eq. (15) indicates that the sensitivity of the reprocessed density is independent of the recovery factor and can be evaluated as the constrained sensitivity of the discharge density using Eq. (7).

III.C Sensitivity of the Feed Density

If the reprocessed density is not sufficient to meet the charge enrichment, additional feed material is provided by an external source. The convention used in the REBUS-3 code is to separate the feed material into two classes of material; class 1 is generally the more highly reactive fuel and class 2 is the less reactive. The isotopic ratios or splits of the feed material is assumed to be constant and is specified as a part of the problem input data.

Since the total amount of feed material required is essentially the amount of material that can not be provided from the reprocessing plant, the feed density is written as $\vec{N}_F = \vec{\mu} A$ (or $N_F^i = \mu^i A$ for isotope i) where A represents the amount of feed material and $\vec{\mu}$ a vector of the isotopic fractions. Each class of fuel is assigned a separate mass and isotopic distribution, $\vec{\mu}_1$ and A_1 for class 1 and $\vec{\mu}_2$ and A_2 for class 2.

Because the nuclear fuel cycle is closed, a variation in the nuclear data, α , will perturb the amount of fuel that is reprocessed. This perturbation is compensated by adjusting the external feed such that the physical volume of fuel and all the reactor operating constraints are still satisfied. We can express the sensitivity of the feed density as;

$$\hat{S}_{\alpha}^{N_F^i} = \frac{\alpha}{N_F^i} \frac{\partial N_F^i}{\partial \alpha} = \frac{\alpha}{\mu_1^i A_1} \frac{\partial (\mu_1^i A_1)}{\partial \alpha} = \hat{S}_{\alpha}^{A_1} \quad \text{for class 1 fuel} \quad (16)$$

$$\hat{S}_{\alpha}^{N_F^i} = \frac{\alpha}{N_F^i} \frac{\partial N_F^i}{\partial \alpha} = \frac{\alpha}{\mu_2^i A_2} \frac{\partial (\mu_2^i A_2)}{\partial \alpha} = \hat{S}_{\alpha}^{A_2} \quad \text{for class 2 fuel.} \quad (17)$$

Because the isotopic distribution is a fixed quantity for each class type, the sensitivity of the feed

density depends only on the class type and is the same for isotopes in each class type. In section III.E we will formulate the conditions necessary to solve Eqs. (16) and (17) for the feed density sensitivities.

III.D Sensitivity of the Sold Density

If the reprocessed density is larger than the charge density, some of the reprocessed fuel will be sold in the refabrication plant. The sold fraction depends only on fuel type (class 1 or 2) and therefore the isotopic ratios in both the reprocessed and sold material are the same. The sensitivity of the sold density can be written:

$$\hat{S}_{\alpha}^{N_s^i} = \frac{\alpha}{N_s^i} \frac{\partial N_s^i}{\partial \alpha} = \frac{\alpha}{\beta_1 N_R^i} \frac{\partial (\beta_1 N_R^i)}{\partial \alpha} = \frac{\alpha}{\beta_1 N_R^i} \left[\frac{\partial N_R^i}{\partial \alpha} \beta_1 + \frac{\partial \beta_1}{\partial \alpha} N_R^i \right] = \hat{S}_{\alpha}^{N_R^i} + \hat{S}_{\alpha}^{\beta_1} \quad (18)$$

where $\hat{S}_{\alpha}^{\beta_1}$ is the sensitivity of volume fraction, β_1 , for class 1 sold density to a perturbation in α . Eq. (18) indicates that the sensitivity of sold density is the sum of sensitivity of the reprocessed density and its volume fraction change. A similar equation can be written for class 2 material with a volume fraction of sold material, β_2 .

III.E Solution of the Closed Fuel Cycle Sensitivity Equations

There are two conditions for the constrained equilibrium fuel cycle that provide the equations necessary to solve for the feed and sold density sensitivities. Depending on whether the reprocessed density is greater or less than the charge enrichment requirements, we will solve either Eqs. (16) and (17) for the feed density sensitivities, $\hat{S}_{\alpha}^{A_1}$ and $\hat{S}_{\alpha}^{A_2}$ or Eq. (18) and its corresponding equation for class 2 material for the volume fraction sensitivities, $\hat{S}_{\alpha}^{\beta_1}$ and $\hat{S}_{\alpha}^{\beta_2}$.

First the total variation of the charged volume must be zero ($\delta V_C = 0$) for any perturbation because the physical fuel volume is a fixed quantity. The variation of the charged volume can be expressed in terms of charged density, N_C , and fabrication density, ρ , as

$$\delta V_C = \sum_i^I \frac{\delta N_C^i V_C}{\rho_i} \quad (19)$$

where the summation is done for all 'I' isotopes. Therefore the sensitivity of charged volume can be written as

$$S_{\alpha}^{V_C} = \frac{\alpha}{V_C} \frac{\delta V_C}{\delta \alpha} = \frac{\alpha}{\delta \alpha} \sum_i^I \frac{\delta N_C^i}{\rho_i} = 0 \quad (20)$$

If the reprocessed volume is less than the charged volume, Eq. (20) can be rewritten using Eqs. (13), (15), (16), and (17) as

$$0 = \sum_i^I \left[\frac{N_R^i}{\rho_i} \right] \hat{S}_{\alpha}^{N_R^i} + \sum_i^{class 1} \left[\frac{N_F^i}{\rho_i} \right] \hat{S}_{\alpha}^{A_1} + \sum_i^{class 2} \left[\frac{N_F^i}{\rho_i} \right] \hat{S}_{\alpha}^{A_2} \quad (21)$$

Conversely, if the reprocessed volume is larger than the charged volume, Eq. (20) can be rewritten using Eqs. (14), (15), and (18) as

$$0 = \sum_i^I \left[\frac{N_R^i}{\rho_i} \right] \hat{S}_{\alpha}^{N_R^i} - \sum_i^{class 1} \left[\frac{N_S^i}{\rho_i} \right] \hat{S}_{\alpha}^{\beta_1} - \sum_i^{class 2} \left[\frac{N_S^i}{\rho_i} \right] \hat{S}_{\alpha}^{\beta_2} \quad (22)$$

The second condition necessary to solve Eqs. (16) and (17) is provided by Eq. (8) which is always satisfied in the constrained equilibrium cycle. Again there are two possibilities; if the reprocessed volume is less than the charged volume, then

$$0 = S_{\alpha}^k + S_{N_c}^k \cdot \hat{S}_{\alpha}^{N_c} = S_{\alpha}^k + S_{N_c}^k \cdot \left[\frac{N_R}{N_C} \hat{S}_{\alpha}^{N_R} + \frac{N_F}{N_C} \hat{S}_{\alpha}^{N_F} \right]$$

which can be written in terms of $\hat{S}_{\alpha}^A$ sensitivities using Eqs. (16) and (17);

$$0 = S_{\alpha}^k + \sum_i \frac{N_R^i}{N_C^i} S_{N_c}^k \hat{S}_{\alpha}^{N_R^i} + \left[\sum_i \frac{N_F^i}{N_C^i} S_{N_c}^k \right] \hat{S}_{\alpha}^{A_1} + \left[\sum_i \frac{N_F^i}{N_C^i} S_{N_c}^k \right] \hat{S}_{\alpha}^{A_2} . \quad (23)$$

or, if the reprocessed volume is larger than the charged volume, then

$$0 = S_{\alpha}^k + \sum_i S_{N_c}^k \hat{S}_{\alpha}^{N_R^i} - \left[\sum_i \frac{N_S^i}{N_C^i} S_{N_c}^k \right] \hat{S}_{\alpha}^{\beta_1} - \left[\sum_i \frac{N_S^i}{N_C^i} S_{N_c}^k \right] \hat{S}_{\alpha}^{\beta_2} . \quad (24)$$

Eqs. (21) and (23) or (22) and (24) can be solved simultaneously for the two unknown sensitivities, $\hat{S}_{\alpha}^{A_1}$ and $\hat{S}_{\alpha}^{A_2}$ or $\hat{S}_{\alpha}^{\beta_1}$ and $\hat{S}_{\alpha}^{\beta_2}$. The sensitivities of the feed or sold densities, $\hat{S}_{\alpha}^{N_F}$ or $\hat{S}_{\alpha}^{N_S}$, for each class of material can then be found using Eq. (16), (17), and (18).

However, these equations can not be solved directly since they require the sensitivity of the reprocessed density, $\hat{S}_{\alpha}^{N_R}$, from Eq. (15), which must be evaluated as a constrained sensitivity of the discharge density using Eq. (7). This assumes the sensitivity of the charge density, $\hat{S}_{\alpha}^{N_c}$, is known, when this must be solved using the sensitivities of reprocessed and feed densities in Eq. (13) or (14). We developed an iterative method for solving Eqs. (7), (15), (21), (22), (23), and (24).

The algorithm used in this work is shown in Figure 2. We begin by assuming the reprocessed density, $\hat{S}_{\alpha}^{N_R}$, is given by the unconstrained sensitivity of the discharge density which neglects the second term on the right hand side of Eq. (7). We then compute the sensitivity $\hat{S}_{\alpha}^A$ or $\hat{S}_{\alpha}^B$

using Eqs. (21) and (23) or (22) and (24), which enables us to find the sensitivities of the feed or sold densities, $\hat{S}_\alpha^{N_F}$ or $\hat{S}_\alpha^{N_S}$, using Eqs. (16), (17), and (18). Finally, we compute the sensitivity of the charge density using Eq. (13) or (14), which then permits us to evaluate the constrained discharge density using Eq. (7). We update the sensitivity of the reprocessed density using Eq. (15) and continue the sequence until convergence is achieved.

This algorithm can be written for the sensitivity $\hat{S}_\alpha^A$ as

$$\hat{S}_\alpha^{R^{(n+1)}} = S_\alpha^R + S_{N_C}^R \cdot \left[\frac{N_R}{N_C} \hat{S}_\alpha^{R^{(n)}} + \frac{N_F}{N_C} \hat{S}_\alpha^A \right] \quad (25)$$

or for the sensitivities of the sold fraction, $\hat{S}_\alpha^\beta$ as

$$\hat{S}_\alpha^{R^{(n+1)}} = S_\alpha^R + S_{N_C}^R \cdot \left[\frac{N_R}{N_C} \hat{S}_\alpha^{R^{(n)}} - \frac{N_S}{N_C} \hat{S}_\alpha^\beta \right]. \quad (26)$$

The program CONEX was written to process the unconstrained sensitivities from the code DPT¹⁴ and to implement these algorithms. For all the sample problems we studied in this work, convergence was achieved after a moderate number of iterations. In the following section we will discuss the results of applying these methods to the closed fuel cycle of the Integral Fast Reactor.

IV. NUMERICAL EXAMPLE

The Integral Fast Reactor (IFR) is an innovative liquid metal reactor concept being developed at Argonne National Laboratory.⁷ One of the key features of the IFR is the closed fuel cycle in which fuel reprocessing and fabrication are an integral part of plant operation.

Sensitivity analysis can play an important role in tracking the isotopic masses throughout the fuel cycle. In this example problem we used the methods developed here to find the sensitivity of various isotopic masses to the nuclear data used in the model.

We performed our analysis of the 900 MWth Integral Fast Reactor (IFR) using the ANL code REBUS-3.⁸ The IFR uses a heterogeneous core layout with 3 core and 4 blanket regions as depicted in Figure 3. Some of the IFR core design parameters are provided in Table 1. For the external fuel cycle we assumed a period of 365 days for fuel reprocessing and fabrication. We also assumed all isotopes were recycled with 100% recovery except for uranium, americium, and fission products which were recovered at 1%. Because the core breeding ratio is greater than one and the fuel cycle is closed, the IFR is fissile self-sufficient and only class 2 feed material (depleted uranium) is provided to the fabrication plant. The excess fissile material is assumed to be sold from the reprocessing plant. More details of the IFR design are provided in references [15] and [16].

The depletion calculation was performed using 9 energy groups. The burnup chain used for the depletion model is depicted in Figure 4. The responses considered in this example were the discharge masses of the various heavy metal isotopes. The unconstrained equilibrium cycle sensitivities to the group-wise microscopic cross sections were computed using the computer code DPT.¹⁴ The constrained sensitivities were then computed using the methods described in the previous section. These sensitivities were compared to the results obtained from the direct subtraction of calculations using unperturbed and a 1% perturbation in the cross section of interest. The results are shown in Tables 2 and 3 for two of the most important reaction cross

sections, σ_C^{U238} and σ_f^{Pu239} .

In general, there is good agreement between the sensitivities computed using the methods developed here and the results of direct subtraction. In the few cases where the error is more than a few percent, such as the Curium isotopes, it does not appear the error is due to our sensitivity method. Rather, the error can be attributed to the relatively large perturbation used in the direct subtraction and to the fact that the mass of these isotopes is a highly nonlinear function of σ_C^{U238} and σ_f^{Pu239} . It is impractical to use a smaller perturbation in the direct subtraction since the difference in the already small discharge masses of these isotopes would exceed the limits of precision used in the depletion calculation.

In order to more fully understand the closed fuel cycle sensitivities we found it worthwhile to compute sensitivities for the same core model without fuel reprocessing. In Table 4, we compare the sensitivities to σ_C^{U238} for the cases with and without reprocessing. In general, we found the closed fuel cycle sensitivities are considerably larger, particularly for the isotopes higher up the burnup chain. Our explanation provides some insight as to the nature of closed fuel cycle sensitivities.

In Eq. (7), the constrained sensitivity is expressed as the sum of the unconstrained sensitivity and the effect of the charged density variation. The unconstrained sensitivity describes the effect of a nuclear data change on the response without consideration of the constraints. The effect of the constraint is expressed through a variation in the charge density which is the product of the sensitivity of the response to the charged density, $S_{N_c}^R$, and the sensitivity of the charged density, $\hat{S}_\alpha^{N_c}$, to the nuclear data. The difference between the sensitivity of the open and closed

fuel cycle appears in the sensitivity of the charge density to the nuclear data. For the open fuel cycle without reprocessing this sensitivity consists only of the sensitivity of the feed material, whereas for the closed fuel cycle it is a combination of the sensitivity of the feed and of the reprocessed density for the closed fuel cycle.

In the example here, increasing $\sigma_C^{U^{238}}$ increases the breeding of fissile plutonium. In order to satisfy the k - eo c constraint, the feed density of plutonium is reduced while that of uranium is increased to maintain the charged volume. Because a capture in U^{238} produces Pu^{239} , the sensitivity of the Pu^{239} discharged density is positive. However, the sensitivity of an isotope further up the burnup chain, such as Cm^{246} , is negative because of the reduction in the class 1 feed density.* In the case of the open fuel cycle, the sensitivity of the feed density is small (0.114) and the same for all the class 1 isotopes. Similarly, the effect of the charged density variation is small and relatively uniform for the discharged density of each of the class 1 isotopes.

For the closed fuel cycle in the example used here, the sensitivity of the charged density is the sum of sensitivity of sold and reprocessed (or discharged) density. Because 100% of the class 1 material is recycled, not only the discharged densities but also their sensitivities are propagated through the burnup chain. Therefore the effect of a variation in the charged density is greatest for the isotopes which are higher up the burnup chain such as Cm^{246} , and for these isotopes the difference between the sensitivity of open and closed fuel cycle will be the largest.

* In the problem here, uranium is defined as class 2 feed material and all other heavy metal, to include fissile plutonium, is defined as class 1 feed material.

V. CONCLUSIONS

We have extended Depletion Perturbation Theory to the closed nuclear fuel cycle and have developed methods for computing the constrained sensitivities which account for fuel reprocessing and fabrication. We formulated an iterative method to solve the resulting equations for the sensitivities and applied these methods to the closed fuel cycle of the Integral Fast Reactor. We found the sensitivities generated using the methods here to be in good agreement with sensitivities from direct subtraction of perturbed and unperturbed depletion calculations. We also compared our results for the closed fuel cycle to the sensitivities for the open fuel cycle without reprocessing. We found the closed cycle sensitivities to be larger, particularly for isotopes higher up the burnup chain.

The results here indicate this work would have particular importance for the analysis of advanced reactor designs with closed fuel cycles, such as the Integral Fast Reactor. Sensitivity studies of such reactors can be performed accurately and efficiently using the methods developed in this work.

REFERENCES

1. A. Gandini, "Time-Dependent Generalized Perturbation Methods for Burnup Analysis," RT/FI(75) 4, Comitato Nazionale per l'Energia Nucleare, Rome (1975).
2. J. Kallfelz, et.al., "Burnup Calculations with Time-Dependent Generalized Perturbation Theory," *Nucl. Sci. Eng.*, 62, 304 (1977).
3. M. L. Williams, "Development of Depletion Perturbation Theory for Coupled Neutron/Nuclide Fields," *Nucl. Sci. Eng.*, 70, 20 (1979).
4. E. Greenspan, M.L. Williams, and J.H. Marable, "Time-Dependent Generalized Perturbation Theory for Coupled Neutron-Nuclide Fields," *Nucl. Sci. Eng.*, 73, 210 (1980).
5. J.R. White, "On the Implementation, Verification and Application of Multicycle Depletion Perturbation Theory," Proc. American Nuclear Society Topical Meeting, 1980 Advances in Reactor Physics and Shielding, Sun Valley, Idaho, American Nuclear Society, La Grange Park, Ill. (1980).
6. W.S. Yang and T.J. Downar, "Generalized Perturbation Theory for Constant Power Core Depletion", *Nucl. Sci. Eng.* : 99, p.353 (1988).
7. D.C. Wade and Y.I. Chang, "The Integral Fast Reactor (IFR) Concept: Physics of Operation and Safety," Proc. Inter. Topical Meeting on Advances in Reactor Physics, Mathematics and Computation, Paris, France, April 27-30 (1987).
8. B. Toppel, 'A Users Guide for the REBUS-3 Fuel Cycle Analysis Capability,' ANL-83-2, Argonne National Laboratory, Argonne, Ill. (1983).
9. R. P. Hosteny, 'The ARC System Fuel Cycle Analysis Capability, REBUS-2,' ANL-7721, Argonne National Laboratory, Argonne, Ill. (1978)
10. J.H. Marable, C.R. Weisbin, and G. DeSaussure, "Uncertainty in the Breeding Ratio of a Large Liquid Metal Fast Breeder Reactor," *Nucl. Sci. Eng.* : 75, 30 (1980).
11. M.L. Williams, "Perturbation Theory for Nuclear Reactor Analysis," *Handbook of Nuclear Reactor Calculations*, CRC Press, Boca Raton, FL (1986).
12. W. Yang and T. Downar, "Generalized Perturbation Theory for the Constrained Nuclear Fuel Cycle," *Nuc. Sci. Eng.*, Vol.102, p.365-389 (1989).
13. C.R. Weisbin, R.W. Peelle, J.H. Marable, G. DeSaussure, P.J. Collins, E. Kujawski, and E. Greenspan, "Sensitivity and Uncertainty Analysis of Reactor Performance Parameters," *Advances in Nuclear Science and Technology*, Vol. 14, Plenum Press, New York, NY (1982).
14. T. Downar, 'DPT: A Code to Generate Depletion Sensitivities', Argonne National Laboratory, Argonne, Ill. (1990).

15. H. Khalil and et al., "Fuel Management Studies of Small Metal and Oxide LMR's," Proc. of the Topical Meeting on Advances in Fuel Management, Pinehurst, North Carolina, U.S.A., March 2-5 (1986).
16. Y. Orechwa and et al., "Core Design and Performance of Small Inherently Safe LMR's," Proc. of the Topical Meeting on Advances in Fuel Management, Pinehurst, North Carolina, U.S.A., March 2-5 (1986).

Table 1. 900 MWt IFR Core Design Parameters

Reactor power [MW(thermal)]	900
Core concept	Heterogeneous
Fuel material	
Driver	U-Pu-10% Zr
Blanket	U-10% Zr
Clad and duct material	HT-9
Fuel smear density (% theoretical density)	
Driver	75
Blanket	85
Active fuel height (in.)	
Driver	36
Blanket	44
Number of pins per assembly	
Driver	271
Blanket	169
Fuel pin diameter (in.)	
Driver	0.285
Blanket	0.392
Pin pitch/diameter ratio	
Driver	1.18
Blanket	1.09
Fuel residence time (cycles)	
Driver	4
Blanket	4
Cycle length (full-power days)	292
Recovery factors (reprocessing plant)	
Uranium, americium and fission products	0.01
Others	1.00

Table 2. Constrained Sensitivity to U^{238} Capture (Total)

Response	Exact	CONEX ⁽¹⁾	Error(%) ⁽²⁾
U^{234}	-0.907	-0.900	0.77
U^{235}	0.247	0.245	0.81
U^{236}	-0.417	-0.412	1.20
U^{238}	-0.023	-0.023	0.00
Pu^{236}	-0.014	-0.018	28.57
Pu^{238}	-0.830	-0.852	2.65
Pu^{239}	0.526	0.530	0.76
Pu^{240}	-0.613	-0.615	0.33
Pu^{241}	-1.083	-1.089	0.55
Pu^{242}	-2.286	-2.331	1.97
Am^{241}	-1.107	-1.116	0.81
Am^{242m}	-1.499	-1.515	1.07
Am^{243}	-2.829	-2.887	2.05
Cm^{242}	-1.597	-1.610	0.81
Cm^{243}	-2.224	-2.192	1.44
Cm^{244}	-3.532	-3.629	2.75
Cm^{245}	-3.972	-4.096	3.12
Cm^{246}	-5.425	-5.661	4.35

(1) Program used to compute closed fuel cycle sensitivities

(2) Percent error between exact and CONEX results

Table 3. Sensitivity to Pu^{239} Fission (Total)

Response	Exact	CONEX	Error(%)
U^{234}	-0.663	-0.522	21.27
U^{235}	0.078	0.084	7.69
U^{236}	0.073	0.078	6.85
U^{238}	0.111	0.113	1.80
Pu^{236}	-0.309	-0.317	2.59
Pu^{238}	-0.579	-0.570	1.55
Pu^{239}	-0.778	-0.782	0.51
Pu^{240}	-1.245	-1.249	0.32
Pu^{241}	-1.364	-1.368	0.29
Pu^{242}	-1.979	-1.993	0.71
Am^{241}	-1.463	-1.467	0.27
Am^{242m}	-1.454	-1.446	0.55
Am^{243}	-2.004	-2.021	0.85
Cm^{242}	-1.420	-1.428	0.56
Cm^{243}	-2.091	-2.196	5.02
Cm^{244}	-2.162	-2.185	1.06
Cm^{245}	-2.331	-2.356	1.07
Cm^{246}	-3.064	-3.115	1.66

Table 4. Comparison of Sensitivities for Open and Closed Fuel Cycle to U^{238} Capture (Total)

Response	Open	Closed	Ratio ⁽¹⁾
U^{234}	0.086	-0.900	10.5
U^{235}	0.230	0.245	1.1
U^{236}	-0.395	-0.412	1.0
U^{238}	-0.041	-0.023	0.6
Pu^{236}	0.275	-0.018	0.1
Pu^{238}	0.006	-0.852	142.0
Pu^{239}	0.441	0.530	1.2
Pu^{240}	0.063	-0.615	9.8
Pu^{241}	-0.082	-1.089	13.3
Pu^{242}	0.023	-2.331	101.3
Am^{241}	0.107	-1.116	10.4
Am^{242m}	-0.214	-1.515	7.1
Am^{243}	-0.379	-2.887	7.6
Cm^{242}	-0.359	-1.610	4.5
Cm^{243}	-0.418	-2.192	5.2
Cm^{244}	-0.290	-3.629	12.5
Cm^{245}	-0.113	-4.096	36.2
Cm^{246}	0.022	-5.661	257.3

$$(1) \text{ Ratio} = \left| \frac{\text{Closed}}{\text{Open}} \right|$$

Figure 1. Mass Flow in the External Fuel Cycle

Figure 2. Iterative Method for Solving Closed Fuel Cycle Sensitivity Equations

Figure 3. 900 MWth IFR Core Configuration

END

**DATE
FILMED**

2 / 03 / 92