A major purpose of the Technical Information Center is to provide the broadest dissemination possible of information contained in DOE's Research and Development Reports to business, industry, the academic community, and federal, state and local governments.

Although a small portion of this report is not reproducible, it is being made available to expedite the availability of information on the research discussed herein.

LA-UR -83-954

LA-UR--83-954

DE83 009906

CONF-830811--32

Los Alamos National Laboratory is operated by the University of California for the United States Department of Energy under contract W-7405-ENG-36

TITLE WATER-COOLED TARGET-BOX DESIGN AT LAMPF

AUTHOR(S) D. Grisham and J. Lambert

NOTICE
PORTIONS OF THIS REPORT ARE ILLEGIBLE.
It has been reproduced from the best available copy to permit the broadest possible availability.

SUBMITTED TO Particle Accelerator Conference, Santa Fe, NM,
March 21-23, 1983.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

By acceptance of this article the publisher agrees that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes.

The Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy.

Los Alamos Los Alamos National Laboratory
Los Alamos, New Mexico 87545

ELAB

FORM NO 836 RM
ST NO 0029 5/81

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

WATER-COOLED TARGET-BOX DESIGN AT LAMPF

D. Grisham and J. Lambert
Los Alamos National Laboratory

Summary

The target boxes in the main experimental beam line (Line A) at the Clinton P. Anderson Meson Physics Facility (LAMPF) have operated since 1976. A program of replacing the boxes is underway. This paper will present past history, design considerations, calculational results and the final box design.

Introduction

The target boxes in Line A were originally installed in 1974 and 1975. They are stainless steel vacuum chambers with copper tubes brazed to the exterior to dissipate the heat deposition from secondary scattering from the targets. The copper tubes were then flame-sprayed with copper to increase the heat transfer area. The original copper tubes have a high failure rate due to thermal cycling and built-in stresses from the original brazing. Reference 1 outlines the evolution of target chamber cooling schemes from that era to the present day.

Another persistent problem has been the leakage of the vacuum joints close to the targets due to thermal cycling.

Design Considerations

The present target box design scheme involves the use of double-walled water-cooled chambers which optimize the heat transfer to the coolant, eliminate erosion and corrosion problems and provide the highest possible integrity and reliability. The extra expense of this scheme (a factor of 3 to 7) is fully justified by also considering the expense of the remote repair and replacement of the earlier less expensive schemes.

Additional considerations are elimination of vacuum joints near the target. As opposed to earlier schemes, each joint is now shielded by the copper collimators in each of the lines. Figure 1 shows the relationship of the target to joints in each of the beam lines. The water-cooled copper collimators provide sufficient shielding to reduce the heat deposition to such a point that the temperature cycling of the joints is trivial.

In addition the copper collimators provide shielding for surrounding components from the scattered particles from the target. The collimators also provide a limiting beam aperture for the proton beam downstream as well as the pions in the secondary beam lines.

Figure 1

Calculational Results

The potential target box design was analyzed using two Los Alamos authored finite element codes. These are Ayer and TSAAS, which provide temperature and stress distributions respectively.

The results of a portion of these calculations are presented below.

Figure 2, 3 and 4 show the finite element mesh, the temperature distribution and the principal stresses in the main shell of the target box.

Figure 2

Finite Element Grid For Main Box Shell

Figure 3

Temperature Distributions in Main Box Shell

Figure 4

Stress Distributions in Main Box Shell

Figures 5, 6, and 7 show the finite element grid, the temperature distribution on the face nearest the target, and a temperature profile across the front face of the downstream - P³ copper collimator. Only temperatures are shown since the stresses in the thick-walled copper pieces are insignificant.

Figure 5

Finite Element Grid For Downstream - P³ Collimator Face

Figure 6
Temperature Distribution The Downstream -
 p^3 Collimator Face

Figure 8
Horizontal Slice Through Downstream -
 p^3 Collimator

Figure 7
Temperature Profile On The Downstream
Collimator Front Face

Although three-dimensional finite element codes exist, the programming and computer times are prohibitive except for extremely critical areas where space or weight are severely limited. For less critical applications two-dimensional codes are used on three-dimensional objects by taking cuts through the object in various places.

Figures 8 and 9 are the results of such an analysis in a different direction; in this case a slice through the horizontal centerline of the downstream - p^3 collimator as well as the temperatures of the front face.

Figure 9
Temperature Distribution

Conclusion

The seven years of experience and the use of modern calculational techniques provide an assurance that the new Line A target boxes at LAMPF will operate without significant deterioration and need for repair for several years.

References

1. D. L. Grisham and J. E. Lambert, "Water-Cooled Beam Line Components at LAMPF," Particle Accelerator Conference, Accelerator Engineering and Technology, Washington, D. C. (March 1981).