DOE/BP--1706

DE92 003499

DRAFT ENVIRONMENTAL IMPACT STATEMENT
PUGET SOUND AREA ELECTRIC RELIABILITY PLAN
Appendix D
Conservation, Load Management and Fuel Switching Analysis

Bonneville Power Administration
U.S. Department of Energy

Prepared as part of a coordinated plan to address a power system problem in the Puget Sound Area. Utilities participating in planning include: Bonneville Power Administration, Puget Sound Power and Light, Seattle City Light, Snohomish County Public Utility District No. 1, and Tacoma City Light.

September 1991

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED
MASTER

APPENDIX D
CONSERVATION, LOAD MANAGEMENT, AND FUEL SWITCHING

D.1.0 ANALYSIS OVERVIEW

- D.1.1 Programs
- D.1.2 Hourly Models
- D.1.3 Data Requirements
- D.1.4 System Impacts
- D.1.5 Deleted Options

D.2.0 BASE CASE

- D.2.1 System Load Shapes
- D.2.2 End-Use Breakdown
- D.2.3 End-Use Detail

D.3.0 CONSERVATION

- D.3.1 Overview
- D.3.2 Accelerated Weatherization
- D.3.3 Accelerated Industrial Conservation
- D.3.4 Commercial Retrofit
- D.3.5 Low Flow Shower Heads

D.4.0 LOAD MANAGEMENT

- D.4.1 Water Heat Control
- D.4.2 Time-of-Use Rates

D.5.0 FUEL SWITCHING

- D.5.1 Overview
- D.5.2 Summary of Results
- D.5.3 Market Segments
- D.5.4 Costs
- D.5.5 Results

D.6.0 PROGRAM INTERACTIONS

- D.6.1 Program Ordering
- D.6.2 Size of Interactive Effects

D.7.0 HIGH AND LOW LOAD GROWTH

- D.7.1 Assumptions by Sector
- D.7.2 Tables

D.8.0 REFERENCES

LIST OF FIGURES

Figure D-1a	Water Heat Load Shapes
Figure D-1b	System Load Shapes
Figure D-2a	System Impacts, Normal Peak Day
Figure D-2b	System Impacts, Extreme Peak Day
Figure D-3a	Annual System Peaks, Normal Peak Day
Figure D-3b	Annual System Peaks, Extreme Peak Day
Figure D-4a	Residential Sector, Normal Peak Day
Figure D-4b	Residential Sector, Extreme Peak Day
Figure D-5a	Commercial Sector, Normal Peak Day
Figure D-5b	Commercial Sector, Extreme Peak Day
Figure D-6a	Space Heat Load Shapes, Existing Homes
Figure D-6b	Space Heat Load Shapes, New Homes
Figure D-7a	Residential Water Heat Load Shapes
Figure D-7b	Residential Other Load Shapes
Figure D-8a	Office HVAC Load Shapes
Figure D-8b	Office Lighting Load Shapes
Figure D-8c	Office Other Load Shapes
Figure D-9a	Energy Targets, Residential Weatherization
Figure D-9b	Peak Savings, Residential Weatherization
Figure D-10a	Energy Targets, Industrial Conservation
Figure D-10b	Peak Savings, Industrial Conservation
Figure D-10c	Industrial Conservation Load Shapes
Figure D-11a	Energy Targets, Commercial Retrofit
Figure D-11b	Peak Savings, Commercial Retrofit
Figure D-11c	Office Lighting Conservation
Figure D-12a	Low Flow Shower Heads, Program Penetration
Figure D-12b	Peak Savings, Low Flow Shower Heads
Figure D-13a	Water Heat Control Penetration Rates, Existing Homes
Figure D-13b	Water Heat Control Penetration Rates, New Homes
Figure D-14a	Peak Savings, Water Heat Control
Figure D-14b	Water Heat Control Load Shapes
Figure D-15a	Time-of-Use Rates, Program Penetration
Figure D-15b	Peak Savings, Time-of-Use Rates
Figure D-15c	Time-of-Use Rates Load Shapes

LIST OF TABLES

Table D.2.1	Difference Between Morning and Evening Peaks
Table D.2.2	Difference Between Morning Peak and Daily Average
Table D.2.3	End-Use Labels
Table D.2.4	Market Shares of Electricity
Table D.2.5	Number of Households
Table D.2.6	Commercial Floor Space
Table D.2.7	Industrial Sector Consumption
Table D.2.8	Energy Benchmarks
Table D.2.9	Ratio of Peak Day to Average Day Energy Consumption
Table D.3.1	Summary Worksheet, Single Family Weatherization
Table D.3.2	Energy Targets for Weatherization of Residential Buildings
Table D.3.3	Summary Worksheet, Multi-Family Weatherization
Table D.3.4	Summary Worksheet, Industrial Conservation
Table D.3.5	Commercial Retrofit Program Energy Targets
Table D.3.6	Summary Worksheet, Commercial Retrofit
Table D.3.7	Summary Worksheet, Low Flow Shower Heads
Table D.4.1	Water Heat Control Penetration Rates
Table D.4.2	Summary Worksheet, Water Heat Control (Single Family)
Table D.4.3	Summary Worksheet, Water Heat Control (Multi-Family)
Table D.4.4	Summary Worksheet, Water Heat Control (Manufactured Homes)
Table D.4.5	Summary Worksheet, Time-of-Use Rates
Table D.5.1	Households (in Fuel Switching Program)
Table D.5.2	Cost per Household
Table D.5.3	Summary of Fuel Switching Potential
Table D.6.1	Fuel Switching Impact on Other Programs
Table D.7.1	Residential Scale Factors
Table D.7.2	Commercial Scale Factors
Table D.7.3	Industrial Scale Factors
Table D.7.4	Residential Sector Growth Scenarios
Table D.7.5	Commercial Sector Growth Scenarios
Table D.7.6	Low Growth by Building Type
Table D.7.7	Medium Growth by Building Type
Table D.7.8	High Growth by Building Type

D.1.0 ANALYSIS OVERVIEW

Various conservation, load management, and fuel switching programs were considered as ways to reduce or shift system peak load. These programs operate at the end-use level, such as residential water heat. Figure D-1a shows what electricity consumption for water heat looks like on normal and extreme peak days. Load management programs, such as water heat control, are designed to reduce electricity consumption at the time of system peak.

On the coldest day in an average winter, system load peaks near 8:00 a.m. In a winter with extremely cold weather, electricity consumption increases for all hours, and the system peak shifts to later in the morning. System load shapes in the Puget Sound area are shown in Figure D-1b for a normal winter peak day (February 2, 1988) and an extreme peak day (February 3, 1989).

Peak savings from any program are calculated to be the reduction in loads on the entire system at the hour of system peak. Peak savings for all programs are measured at 8:00 a.m. on a normal peak day and 9:00 a.m. on an extreme peak day. On an extremely cold day, some water heat load shifts to much later in the morning, with less load available for shedding at the time of system peak.

Models of hourly end-use consumption were constructed to simulate the impact of conservation, load management, and fuel switching programs on electricity consumption. Javelin, a time-series simulation package for personal computers, was chosen for the hourly analysis.¹ Both a base case and a program case were simulated.

D.1.1 PROGRAMS

Three groups of proposed programs were analyzed for this study: conservation, load management, and fuel switching. Conservation programs are discussed in more detail in Section 3. Some of the conservation programs are an acceleration of programs already in place in the Puget Sound area. Load management programs, discussed in Section 4, are designed to shift load away from the time of system peak.

Conservation Programs

- Residential Weatherization (Single Family)
- Residential Weatherization (Multi-Family)
- Industrial Conservation
- Commercial Retrofit
- Low Flow Shower Heads

¹ Javelin is a trademark of Information Resources, Inc., Waltham, Massachusetts.

Figure D-1a. Water Heat Load Shapes

Figure D-1b. System Load Shapes

Load Management Programs

Water Heat Control (Single Family)
Water Heat Control (Multi-Family)
Water Heat Control (Manufactured Homes)
Time-of-Use Rates (Residential Single Family)

A fuel switching scenario with seven market segments was constructed for the residential sector. With a fuel switching program in place, some electricity consumption for space and water heat is shifted to natural gas. Fuel switching is covered in detail in Section 5.

D.1.2 HOURLY MODELS

Electricity consumption is simulated at an hourly level for each end-use beginning in 1990 and ending in 2010. To avoid providing space for all 8760 hours for each year, only certain day types are simulated. Three day types were chosen to capture the response of hourly load shapes to cold weather.

Average Winter Day
1 in 2 Peak Day (Normal Peak Day)
1 in 20 Peak Day (Extreme Peak Day)

A Normal Peak Day is the coldest day to occur once every two years, representing the coldest day during a typical winter. An Extreme Peak Day is the coldest day to occur once every 20 years.

Load shapes used in the simulation, at least for the residential and commercial sectors, are based on actual metered load shape data obtained from the End-Use Load and Consumer Assessment Program (ELCAP). Residential load shapes are an average across a sample of single family homes west of the Cascades in Washington and Oregon. Commercial load shapes are based on a sample of commercial buildings in the Seattle area.

Electricity consumption in the Puget Sound area is modeled as the sum of 19 end-uses. Residential electricity consumption consists of space heat, water heat, and other for three housing types. The commercial sector is broken into HVAC, lighting, refrigeration, and other for two building types. A list of end-uses is provided in Section 2.2.

Hourly models were constructed for all 19 end-uses. Conservation and load management programs were simulated as a change in load shape for one or more end-uses. Fuel switching in the residential sector was simulated by reducing the number of households using electricity for the affected end-use.

D.1.3 DATA REQUIREMENTS

Each end-use model starts with an average load shape and multiplies each hour's value of electricity consumption by the number of units or appliances present during each year. This is done for both a program case and a base

case, with the difference being hourly savings due to the conservation or load management program.

Load Shapes - A load shape is a set of 24 numbers showing the pattern of energy consumption over the hours in a day. Both base case and program case load shapes are required for each end-use and day type. For the residential and commercial sectors, base case load shapes are derived by averaging load shapes across a sample of homes or businesses in western Washington and western Oregon. Program case load shapes are constructed from the base case shapes using assumptions about how the conservation or load management program operates.

Energy Data - Annual energy consumption, in kilowatt-hours, is required for each end-use. This is then broken down into energy for January, and further for an average day in January. Also required are the ratios of energy consumed on peak days to energy consumed on an average winter day. Most of the energy data is derived from ELCAP.

Number of Households - Numbers of households, amount of commercial floor space, and megawatts of industrial electricity consumption are taken from a long term forecast of the Puget Sound area prepared by the Long Term Forecasting Section at Bonneville. A detailed end-use forecast was prepared for the medium growth case.

Market Share of Electricity - Each end-use has its own market share of electricity, somewhere between zero and 100%.

Program Penetration Rate - Each conservation, load management, or fuel switching program increases from zero to a maximum penetration rate.

D.1.4 SYSTEM IMPACTS

Each program affects one or more end-uses. For example, the low flow shower head program affects water heat in single family, multi-family, and manufactured homes. End-use models are set up to simulate both a base case and a program case. Hourly savings at the end-use level are subtracted from system load shapes to derive a system program case.

	System Base Case
-	Base Case for Affected End-Use(s)
+	Program Case for Affected End-Use(s)

=	System Program Case

This calculation is done for 24 hours on each of the three day types for 21 years. Figures D-2a and D-2b show the combined effect on system load of all conservation and load management programs for normal and extreme peak days in 2003. Figures D-3a and D-3b show annual peak impacts of conservation and load management.

Figure D-2a. System Impact of Conservation and Load Management
Normal Peak Day in 2003

Figure D-2b. System Impact of Conservation and Load Management
Extreme Peak Day in 2003

Figure D-3a. Annual System Peaks
Normal Peak Days

Figure D-3b. Annual System Peaks
Extreme Peak Days

Worksheets were created to summarize each program's impact at the peak hour, for each year from 1990 to 2010. Sample worksheets are provided in the sections containing program descriptions. Normal peak day (1 in 2 day) savings correspond to hour 8, while extreme peak day (1 in 20 day) savings correspond to hour 9. The summary worksheets show peak savings, in megawatts, on a normal peak day and an extreme peak day. A column is included on each worksheet for any associated energy savings, in annual average megawatts.

D.1.5 DELETED OPTIONS

Options included in this analysis are listed in Section D.1.1. Many other conservation and load management options were considered but did not make the final list for formal analysis. Deleted options are summarized below.

Residential Space Heat Set-Back Controls - Clock thermostats were eliminated from further consideration because they may increase peak instead of decrease it. This could happen if heating was reduced during the night or midday and scheduled to recover during peak load hours when the occupants rise in the morning (6 a.m. - 7 a.m.) and arrive home in the evening (5 p.m. - 6 p.m.). Since the recovery period coincides with peak demand, this would adversely affect the problem in the Puget Sound area.

New Commercial Conservation Programs - It is assumed that planned Bonneville and Puget Power programs will capture all energy savings available from new construction in this sector and that no savings above this baseline are possible.

Lighting Efficiency Controls - Lighting efficiency controls also have limited potential for peak reduction. Residential lighting is a minor part of the peak demand. Improved lighting efficiency saves energy over time, but does not do much to reduce peak demand. Some lighting conservation measures will be implemented as part of the retrofit program for existing commercial buildings.

Solar Augmentation for Water Heaters - This conservation measure appears unreliable. The Puget Sound area is often cloudy, and the morning peak period frequently occurs before daylight hours. This measure would be unavailable when it is needed most.

Diesel/Gasoline Generators - Portable gas or diesel generators can create air and noise pollution. They are expensive, and utilities would either require a communication system to start this generation or rely on customers to ensure their use. Customers may object to this measure. There are air quality and noise pollution concerns associated with diesel and/or gasoline generators.

Gas Back-Up for Electric Heat Pumps - Gas back-up for residential electric heat is expensive. It requires replacing furnaces for customers with central electric furnaces and installing gas furnaces and duct work for customers with zonal electric heat.

Street Lighting Efficiency and Controls - Street lighting controls turn off some street lights during periods of extreme peak demand. Street lighting efficiency creates savings from lighting demand, but does not affect peak load, and creates safety impacts. It was eliminated from further study.

Dual-Fuel Boilers - This proposal would install dual-fuel capability in electric boilers so load could be shifted to natural gas during peak load. The potential from this is limited because most industrial users who have a choice already use natural gas due to its lower cost.

Commercial and Industrial Time-of-Use Rates - Different rates for electricity tied to peak and off-peak hours are used to encourage customers to shift usage to off-peak. Commercial and industrial time-of-use rates can increase energy use overall when the price difference is large enough to entice peak reduction.

Space Heat Controls - This program would allow direct utility control of residential electric space heat during peak demand periods. Participants' heating systems are cycled on and off by the utility. A typical cycle would be 15 minutes off, 45 minutes on each hour.

Savings for this program were not estimated because there was insufficient data on how space heaters cycle on and off during extremely cold weather. It is difficult to estimate the savings from altering these cycles.

Storage Water Heating - This program is similar to hot water control, except that an additional 52 gallon tank is installed. Due to high capital costs, this measure did not meet the cost screening criterion.

Whole House Demand Control - In this measure, utilities or their customers limit residential peak demand. They use a device called a demand controller. This device monitors electric use in a house and turns off some use when the demand exceeds a certain level. Typically, only larger loads such as resistance heating, hot water heaters, and clothes dryers are controlled.

Thermal Heat Storage - Thermal heat storage systems use off-peak electricity to supply on-peak heating requirements. The units store heat in ceramic bricks or crushed rock during periods of low electrical demand, and use that heat during high demand periods. These units would be installed instead of a new furnace in a new home, or as part of a package when a furnace is replaced in an existing home. Time-of-use rates or a separate storage rate are used as an incentive to encourage consumer participation. This measure may increase energy consumption and does not meet the cost screening criterion.

D.2.0 BASE CASE

The base case scenario is an hourly simulation at the end-use level, which can then be aggregated to sector and system levels. Figures D-4a and D-4b show how the residential sector breaks down into its major end-uses. Note that electricity consumption remains high during the late morning hours on extreme peak days. Figures D-5a and D-5b show a corresponding breakdown for the commercial sector.

D.2.1 SYSTEM LOAD SHAPES

Two sets of system load shapes were considered for this analysis. The first set is the sum of forecasted end-use load shapes from 1990 through 2010. The other system shapes, the sum-of-utility load shapes, start with a historical system shape built up from hourly utility data in the Puget Sound area. The load shapes are then scaled proportionally to simulate load growth over 20 years.

Each conservation, load management, or fuel switching program will have some impact on the system load shape. Therefore, knowing what the system shape looks like is critical to a peak load study. It was decided to use the sum-of-utility load shape as the base case system shape. System load shapes shown in Figure D-1b are sum-of-utility load shapes for February 2, 1988, and February 3, 1989.

Potential Savings

All of the conservation and load management programs will reduce load at the time of system peak, which occurs in the morning.

<u>Day Type</u>	<u>Time of System Peak</u>
Average Winter Day	8:00 a.m.
1 in 2 Peak Day	8:00 a.m.
1 in 20 Peak Day	9:00 a.m.

All hourly data on electricity consumption is actually an average of electricity use over the previous hour. It is not an instantaneous measure of power. When the peak load is said to occur at 8:00 a.m., it really means that the hour from 7:00 to 8:00 has the highest average electricity consumption over 24 hours. Note that the morning peak occurs later on an extremely cold day.

Each of the three day types also has an evening peak occurring at 7:00 p.m. or hour 19. One way to get a quick idea of peak savings potential is to look at the difference between morning and evening peaks. This shows how much the morning peak can be reduced before it equals the evening peak. Table D.2.1 shows this difference in the year 2010.

Figure D-4a. Residential Sector Breakdown - Normal Peak Day

Figure D-4b. Residential Sector Breakdown - Extreme Peak Day

Figure D-5a. Commercial Sector Breakdown - Normal Peak Day

Figure D-5b. Commercial Sector Breakdown - Extreme Peak Day

Table D.2.1 Difference Between Morning and Evening Peaks
Simulation for 2010

	<u>Morning Peak (MW)</u>	<u>Evening Peak (MW)</u>	<u>Difference (MW)</u>
1 in 2 Peak Day	13,856	12,720	1,136
1 in 20 Peak Day	15,185	14,578	607

Note that the difference between morning and evening peaks is smaller on an extreme peak day. Another view of potential savings is provided by the difference between peak and average load for a day shown in Table D.2.2. This is the theoretical maximum amount of savings that a load management program could provide.

Table D.2.2 Difference Between Morning Peak and Daily Average
Simulation for 2010

	<u>Morning Peak (MW)</u>	<u>Daily Average (MW)</u>	<u>Difference (MW)</u>
1 in 2 Peak Day	13,856	11,278	2,578
1 in 20 Peak Day	15,185	13,322	1,863

D.2.2 END-USE BREAKDOWN

Electrical load in the Puget Sound area is modeled as the sum of 19 end-uses. There are three residential building types with three end-uses each for a total of nine. There are two commercial building types, office and non-office. File names for the 19 end-uses are listed in Table D.2.3.

Table D.2.3 End-Use Labels

RSFSH	Residential Single Family	Space Heat
RSFWH		Water Heat
RSFOT		Other
RMFSH	Residential Multi-Family	Space Heat
RMFWH		Water Heat
RMFOT		Other
RMHSH	Manufactured Homes	Space Heat
RMHWH		Water Heat
RMHOT		Other
COFHV	Commercial Office	HVAC
COFLT		Lighting
COFOT		Other
CNOHV	Commercial Non-Office	HVAC
CNOLT		Lighting
CNORF		Refrigeration
CNOOT		Other
DIS	Direct Service Industries	
IND	Other Industrial	
OTH	Miscellaneous	

ELCAP data provided load shapes for residential and commercial buildings. Derivation of the shapes is discussed in Gillman, Sands, and Lucas (1990). Figures D-6 through D-8 provide plots of end-use load shapes for an average winter day, a normal peak day, and an extreme peak day. The normal peak day was February 2, 1988 and the extreme peak day was February 3, 1989.

Figure D-6a. Space Heat Load Shapes - Existing Homes

Figure D-6b. Space Heat Load Shapes - New Homes

Figure D-7a. Residential Water Heat Load Shapes

Figure D-7b. Residential Other Load Shapes

Figure D-8a. Office HVAC Load Shapes

Figure D-8b. Office Lighting Load Shapes

Figure D-8c. Office Other Load Shapes

D.2.3 END-USE DETAIL

Tables D.2.4 through D.2.9 contain input assumptions for end-use simulations. Existing and new buildings are treated separately in some of the end-use models. Bonneville's Long Term Forecasting Section constructed a 20 year forecast by summing forecasts from utilities in the Puget Sound area.

Table D.2.4 Market Shares of Electricity

	<u>1990</u>	<u>2000</u>	<u>2010</u>
RSFSH Existing	0.39	0.38	0.38
RSFSH New	0.34	0.32	0.30
RSFWH Existing	0.72	0.69	0.66
RSFWH New	0.36	0.36	0.36
RSFOT	1.00	1.00	1.00
RMFSH Existing	0.84	0.86	0.87
RMFSH New	0.98	0.98	0.98
RMFWH Existing	0.85	0.87	0.88
RMFWH New	0.98	0.98	0.98
RMFOT	1.00	1.00	1.00
RMHSH Existing	0.81	0.80	0.80
RMHSH New	0.80	0.79	0.79
RMHWH Existing	0.82	0.81	0.80
RMHWH New	0.80	0.80	0.80
RMHOT	1.00	1.00	1.00
COFHV Existing	0.70	0.75	0.80
COFHV New	0.85	0.85	0.85
COFLT	1.00	1.00	1.00
COFOT	1.00	1.00	1.00
CNOHV Existing	0.41	0.46	0.50
CNOHV New	0.50	0.52	0.54
CNOLT	1.00	1.00	1.00
CNORF	0.65	0.65	0.65
CNOOT	1.00	1.00	1.00
DSI	1.00	1.00	1.00
IND	1.00	1.00	1.00
OTH	1.00	1.00	1.00

1.00 = 100 percent

Table D.2.5 Number of Households, Medium Growth Case

	Single Family Households		Multi-Family Households		Manuf. Home Households	
	Existing	New	Existing	New	Existing	New
1990	1,097,667	0	431,144	0	106,106	0
1991	1,092,656	23,729	429,197	19,797	105,608	3,783
1992	1,087,669	47,927	427,258	40,134	105,112	8,127
1993	1,082,703	69,780	425,329	57,652	104,618	12,252
1994	1,078,515	89,847	423,704	74,689	104,199	16,279
1995	1,073,591	108,810	421,790	90,564	103,710	19,284
1996	1,068,689	127,932	419,885	105,720	103,223	22,431
1997	1,063,809	147,150	417,988	121,791	102,738	25,729
1998	1,059,695	166,555	416,392	137,994	102,327	29,204
1999	1,054,114	185,871	414,219	154,109	101,774	32,805
2000	1,049,299	205,988	412,347	170,238	101,296	36,603
2001	1,044,505	225,013	410,484	186,106	100,820	40,211
2002	1,039,733	244,024	408,628	202,778	100,346	43,828
2003	1,034,982	263,242	406,781	218,792	99,874	47,456
2004	1,029,526	282,175	404,656	235,520	99,334	51,056
2005	1,024,820	301,545	402,827	252,383	98,867	54,700
2006	1,020,136	321,183	401,005	269,746	98,402	58,355
2007	1,015,472	340,891	399,191	287,310	97,939	62,020
2008	1,010,829	361,171	397,386	305,238	97,478	65,695
2009	1,006,207	381,414	395,588	323,758	97,019	69,382
2010	1,001,606	401,683	393,798	342,741	96,563	73,081

Table D.2.6 Commercial Floor Space in
Thousands of Square Feet, Medium Growth

	Office Floor Space		Non Office Floor Space	
	Existing	New	Existing	New
1990	182,835	1,847	621,585	6,279
1991	180,988	12,763	615,307	32,837
1992	179,142	23,680	609,028	59,396
1993	177,295	34,597	602,749	85,954
1994	175,448	45,513	596,471	112,512
1995	173,601	56,430	590,192	139,071
1996	171,754	65,049	583,914	162,429
1997	169,907	73,668	577,635	185,788
1998	168,061	82,286	571,356	209,147
1999	166,214	90,905	565,078	232,505
2000	164,367	99,524	558,799	255,864
2001	162,520	111,094	552,520	282,657
2002	160,673	122,664	546,242	309,449
2003	158,827	134,234	539,963	336,242
2004	156,980	145,804	533,684	363,034
2005	155,133	157,374	527,406	389,827
2006	153,286	168,944	521,127	416,619
2007	151,439	180,514	514,848	443,412
2008	149,592	192,084	508,570	470,204
2009	147,746	203,654	502,291	496,997
2010	145,899	215,224	496,013	523,789

Table D.2.7 Industrial Sector Consumption in
Average Megawatts, Medium Growth Case

	<u>Industrial (aMW)</u>	
	<u>Existing</u>	<u>New</u>
1990	1,142	0
1991	1,142	27
1992	1,142	54
1993	1,142	109
1994	1,142	164
1995	1,142	219
1996	1,142	246
1997	1,142	273
1998	1,142	300
1999	1,142	328
2000	1,142	355
2001	1,142	373
2002	1,142	391
2003	1,142	409
2004	1,142	428
2005	1,142	446
2006	1,142	480
2007	1,142	514
2008	1,142	549
2009	1,142	583
2010	1,142	617

Table D.2.8 Energy Benchmarks,
Annual Electricity Consumption in the Year 2000

Annual kWh per household for the residential sector:

	<u>Existing</u>	<u>New</u>
RSFSH	9,650	5,050
RSFWH	4,400	3,850
RSFOT	6,450	6,500
RMFSH	3,925	1,800
RMFWH	2,700	2,350
RMFOT	3,500	3,550
RMHSH	6,050	5,000
RMHWH	3,160	2,450
RMHOT	5,000	4,130

Annual kWh per 1,000 square feet for the commercial sector:

	<u>Existing</u>	<u>New</u>
COFHV	11,750	11,500
COFLT	6,800	6,650
COFOT	3,600	3,700
CNOHV	11,500	10,750
CNOLT	6,000	5,250
CNORF	1,800	1,650
CNOOT	2,200	2,200

Table D.2.9 Ratio of Peak Day to Average Day
Energy Consumption

	<u>1 in 2</u> <u>Peak Day</u>	<u>1 in 20</u> <u>Peak Day</u>
RSFSH Existing	1.35	2.20
RSFSH New	1.25	1.90
RSFWH	1.02	1.10
RSFOT	1.15	1.20
RMFSH Existing	1.35	2.20
RMFSH New	1.25	1.90
RMFWH	1.02	1.10
RMFOT	1.15	1.20
RMHSH Existing	1.35	2.20
RMHSH New	1.25	1.90
RMHWH	1.02	1.10
RMHOT	1.15	1.20
COFHV	1.40	1.95
COFLT	1.00	1.00
COFOT	1.00	1.00
CNOHV	1.45	1.95
CNOLT	1.00	0.98
CNORF	1.00	1.00
CNOOT	1.00	0.98

D.3.0 CONSERVATION

Some of the conservation programs described here are accelerated versions of programs that Bonneville currently operates or may operate in the future. These programs were designed to provide annual energy savings and did not emphasize peak savings. This analysis of conservation programs was developed to answer the question, "What peak savings could realistically be achieved through the acceleration and creation of programs designed to meet regional energy needs?"

D.3.1 OVERVIEW

Conservation programs fall into three categories. The first is an acceleration of existing or planned programs that will capture all of the available conservation potential by 2010. These include residential weatherization and industrial conservation programs. Peak savings for these programs are obtained sooner than previously planned. The second is the acceleration of a program for which the baseline, or planned savings, is not projected to capture all of the potential conservation savings by 2010. Commercial retrofit is such a program. The third is the low flow shower head program for which there is no existing or planned program. Methods used to calculate savings and costs are different for each type of program.

Programs in the first category have a baseline of activity that would occur regardless of decisions made to resolve the voltage stability problem in this area. This analysis only counts savings that can be achieved by accelerating these programs above the baseline. Figure D-9a illustrates this type of program with residential weatherization. The solid line shows the cumulative energy savings that would be achieved in the base case. The dotted line shows the cumulative savings to be accomplished with the accelerated program. A corresponding plot of peak savings is shown in Figure D-9b. The difference between these lines is the savings in each year due to acceleration. The difference between accelerated and baseline savings reaches a maximum in the year 2000 and drops back to zero by 2010. In 2010 there are no additional savings because the baseline would have accomplished the same level of savings without an acceleration. Savings attributed to the accelerated programs are transitory, first increasing and then declining over the planning horizon.

The cost per kilowatt for accelerated programs is stated as an annual finance charge in place of the initial capital cost. Since the cost of installation would have been incurred anyway, the real social cost of acceleration is only the time value of money because money is spent earlier than previously planned. Annual finance costs shown in worksheets for accelerated weatherization and industrial conservation are equal to 3% of capital cost. A real interest rate of 3% is assumed for all cost calculations.

The second category of program is represented by commercial sector conservation. There is a baseline which is not forecasted to capture all of the available conservation potential. Savings from program acceleration are cumulative savings above the baseline. Costs for this type of program count

Figure D-9a. Energy Targets - Residential Weatherization

Figure D-9b. Peak Savings - Residential Weatherization
Normal Peak Days

the full capital costs of all conservation measures installed that acquire savings above the baseline. This is appropriate because the program acceleration is assumed to be installing measures that would not have otherwise been installed.

The third type of program is represented by low flow shower heads. No program was previously planned so there is no baseline acquisition level. For this reason, full capital cost is used to calculate cost per kilowatt of peak savings for this program.

Conservation Potential in the Puget Sound Area

Conservation potential for each sector in the Puget Sound area is the sum of conservation potentials for the public utilities and for Puget Sound Power and Light. Puget Power provided estimates of the conservation potential for its commercial, residential, and industrial sectors. Bonneville calculated the conservation potential for the public utilities by estimating the share of conservation potential within the entire Bonneville service area that will occur in the Puget Sound area. The conservation savings for each sector are assumed to be proportional to the Puget Sound area loads for each sector. For example, 47% of the residential load in the Bonneville service area is located in the Puget Sound area so it is assumed that 47% of the conservation potential is also located in the Puget Sound area.

Estimates of conservation potential for the entire Bonneville service area were taken from the 1990 Resource Program documents. These are based on conservation supply estimates developed by Bonneville and summarized in the Draft 1990 Conservation Resources Supply Document.

Conservation potential is a function of the load forecast. Higher load forecasts mean more units that can be weatherized, insulated or otherwise fixed up and a higher conservation or load management potential. All estimates presented in this section are based on a medium load growth forecast.

Conservation Program Baselines and Accelerated Program Levels

Conservation baselines for the public utility areas were derived from Bonneville's 1990 Resource Program documents. The Resource Program presented budget and savings forecasts through fiscal year 1997. These were used to develop conservation baselines for the public utilities. Baseline energy targets for 1998 through 2010 were derived by consensus of the Conservation and Load Management Team, which included representatives from utilities in the Puget Sound area. The conservation baseline for the entire Puget Sound area is the sum of the projected savings by Puget Power and the projected savings from Bonneville programs to be operated by the public utilities.

Program targets were specified in terms of the average annual energy savings that could be achieved by a new or accelerated program. Peak savings were calculated using an hourly simulation model. Plant factors, or annual load

factors, were derived from the energy and peak numbers. A plant factor is the ratio of mean hourly energy savings over the entire year to the savings that occur during the system peak hour.

The first program analyses, completed in July 1990, scheduled programs to start up or accelerate in 1992. Energy targets were initially set up for 1995, 2000, 2005, and 2010. However, the start year was later delayed to 1994. Part of the delay was due to the fact that peak savings lag program spending. Money spent in fiscal year 1993 (October 1992 through September 1993) will provide little or no peak savings during the winter of 1992-1993. Peak savings cannot be counted on until fiscal year 1994. Penetration ramps show 1994 as the first year with additional peak savings.

Forecasted program levels were developed by the Conservation and Load Management Team and are the result of group judgement rather than any analytical procedure. The team came up with estimates of the percentage of total conservation potential that could be achieved by 1995, 2000, 2005, and 2010 (some of these targets were later delayed by two years). Energy targets for intermediate years were derived by interpolation.

Programs that persuade consumers to switch from electricity to natural gas could reduce the conservation potential from some conservation programs. Fewer houses would be heated with electricity or have electric water heaters so the energy and peak savings from conservation programs would be somewhat reduced. The tables in this section present savings potential in the absence of fuel switching programs. Please see Section 6 for a discussion of the consequences to the conservation programs of the proposed fuel switching programs.

Summary Worksheets

A summary worksheet is provided for each conservation and load management program. For example, see the single family weatherization summary in Table D.3.1. The worksheets provide a quick overview of assumptions, costs, and savings for each program.

Each worksheet was printed directly from an hourly end-use simulation model created for this study. At the top of each worksheet are cost assumptions, including initial and maintenance costs. Just below the cost numbers are energy and peak savings per household. Costs are then converted from a per household basis to a per kW basis.

The bottom half of each summary worksheet contains the number of participating households, average energy savings, peak savings on a 1 in 2 day, and peak savings on a 1 in 20 day. Model output is provided for all years from 1990 through 2010.

Table D.3.1 Summary Worksheet of Accelerated
Weatherization (Single Family)

Per Unit Data:

Initial Cost	\$2,550
Maint. Cost	\$0
Energy Savings	2,700 kWh per year
1 in 2 Peak Savings	1.342 kW @ 2000
1 in 20 Peak Savings	1.788 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs @ 2000:		
Finance per Year	\$57	\$43

Plant Factor	0.230	0.172
--------------	-------	-------

	<u>Program Units (Households)</u>	<u>Energy Savings (aMW)</u>	<u>Peak Savings 1 in 2 (MW)</u>	<u>Peak Savings 1 in 20 (MW)</u>
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	5,058	1.6	6.8	9.0
1995	10,044	3.1	13.5	18.0
1996	15,594	4.8	20.9	27.9
1997	21,065	6.5	28.3	37.7
1998	26,474	8.2	35.5	47.3
1999	31,768	9.8	42.6	56.8
2000	37,002	11.4	49.7	66.2
2001	32,706	10.1	43.9	58.5
2002	28,447	8.8	38.2	50.9
2003	24,227	7.5	32.5	43.3
2004	20,030	6.2	26.9	35.8
2005	15,889	4.9	21.3	28.4
2006	12,653	3.9	17.0	22.6
2007	9,446	2.9	12.7	16.9
2008	6,269	1.9	8.4	11.2
2009	3,120	1.0	4.2	5.6
2010	0	0.0	0.0	0.0

D.3.2 ACCELERATED WEATHERIZATION

This is an acceleration of the existing weatherization program. This program reduces energy consumption for residential space heating in single and multi-family dwellings. These housing types are modeled separately because costs and savings vary by dwelling type. Targeted savings in average megawatts are shown in Table D.3.2.

In the baseline the remaining homes in the area would all have been weatherized by 2010. Accelerated weatherization is assumed to be complete by 2000. Energy and peak savings first increase and then decline back to zero because the accelerated program accomplishes by 2000 what the baseline would accomplish by 2010.

Costs

Costs for this program are the sum of equipment costs plus a 20% adder for administrative costs. Costs are reported as annual finance costs, based on a 3% real interest rate, because this program only accelerates spending that is scheduled to occur anyway. Cost estimates and energy savings estimates are taken from the residential weatherization supply curve as developed for Bonneville's 1990 Resource Program.

Finance costs, reported in Tables D.3.1 and D.3.3, are derived by multiplying the initial cost of weatherizing a home by 3%. Then an adjustment is made to convert costs from a per household basis to a per kilowatt basis. For example, 3% of the \$2,550 it costs to weatherize a single family home is \$76.50. This is divided by 1.342 kW to obtain \$57, the annual cost per kW on a 1 in 2 peak day.

Impacts

Energy savings for a weatherized single family home are assumed to be 2,700 kWh per year and are distributed in the same way as a space heating load shape. The program case load shape is therefore proportional to the base case load shape. Annual energy savings for multi-family homes are 1363 kWh per year.

Energy targets, for single family and multi-family homes combined, are displayed graphically in Figure D-9a. The corresponding peak savings are shown in Figure D-9b.

Issues

The major issue regarding this program is that conservation case load shapes were derived by simply scaling hourly space heat load shapes. Another method would be to translate the base case load shape, or shift the load shape down by the same amount each hour. The two methods together would provide a range of estimates for peak savings.

Table D.3.2 Energy Targets for Weatherization of Residential Buildings

Single Family Weatherization Annual Energy Savings (aMW)			
	<u>Already Planned</u>	<u>Accelerated Conservation</u>	<u>Total Conservation</u>
1995	15.8	3.1	18.9
2000	26.1	11.4	37.5
2005	32.7	4.9	37.6
2010	37.6	0.0	37.6

Multi-Family Weatherization Annual Energy Savings (aMW)			
	<u>Already Planned</u>	<u>Accelerated Conservation</u>	<u>Total Conservation</u>
1995	6.8	1.3	8.1
2000	11.5	5.0	16.5
2005	14.3	2.1	16.5
2010	16.4	0.0	16.4

Savings reported in Tables D.3.1 and D.3.3 are for the accelerated portion only. Both peak and energy savings reach a maximum in 2000 and then decline to zero by 2010. Note that peak savings are much larger than average energy savings.

Table D.3.3 Summary Worksheet of Accelerated
Weatherization (Multi-Family)

Per Unit Data:	
Initial Cost	\$1,625
Maint. Cost	\$0
Energy Savings	1,363 kWh per year
1 in 2 Peak Savings	0.678 kW @ 2000
1 in 20 Peak Savings	0.903 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs @ 2000:		
Finance per Year	\$72	\$54

Plant Factor	0.230	0.172
--------------	-------	-------

	Program Units (Households)	Energy Savings (aMW)	Peak Savings 1 in 2 (MW)	Peak Savings 1 in 20 (MW)
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	4,186	0.7	2.8	3.8
1995	8,354	1.3	5.7	7.5
1996	13,151	2.0	8.9	11.9
1997	17,927	2.8	12.1	16.2
1998	22,698	3.5	15.4	20.5
1999	27,416	4.3	18.6	24.7
2000	32,128	5.0	21.8	29.0
2001	28,352	4.4	19.2	25.6
2002	24,600	3.8	16.7	22.2
2003	20,874	3.2	14.1	18.8
2004	17,160	2.7	11.6	15.5
2005	13,485	2.1	9.1	12.2
2006	10,751	1.7	7.3	9.7
2007	8,036	1.3	5.4	7.3
2008	5,340	0.8	3.6	4.8
2009	2,661	0.4	1.8	2.4
2010	0	0.0	0.0	0.0

D.3.3 ACCELERATED INDUSTRIAL CONSERVATION

This is an acceleration of the existing industrial conservation Energy Savings Program (ESP) which seeks out conservation projects in all industrial firms in the Standard Industrial Classifications (SIC) 20 - 39 except for aluminum smelters. These industrial classifications includes food processing, wood products, paper, and chemicals. Since this is an acceleration of an existing program that would capture all potential by 2010, incremental savings due to acceleration increase to 2002 and decline back to zero in 2010.

Load shapes for the industrial sector were developed by Bonneville's industrial load forecasters. These load shapes are quite flat over the months of the year and hours of the day. Conservation program shapes are assumed to be scaled versions of load shapes prior to conservation. Industrial loads are not temperature-sensitive so they do not peak when the system loads peak.

Impacts

The baseline assumes the entire conservation potential would be acquired by 2010 and the program case acquires this amount by 2002. The incremental conservation shown in Table D.3.4 is the difference between this program case and the baseline which was taken from the 1990 Resource Program. Figures D-10a and D-10b show the energy and peak savings for the baseline and program cases.

Industrial conservation is modeled as a 5% reduction in electrical load at all hours of the day because the industrial supply curves indicate that the conservation potential for industries in this area is equal to about 5% of the industrial loads (see Figure D-10c). Program penetration rates were chosen to meet energy targets in Figure D-10a.

Costs

The industrial supply curve report states that an kW of electricity savings has an average cost of \$1,606. Adding 20% for administrative costs brings this to \$1,926 per kW.

As with residential weatherization, costs are reported as the finance cost of installing conservation measures sooner than otherwise planned. This is done by multiplying \$1,926 by 3%, the real interest rate, to obtain an annual finance charge of \$57.78 per kW saved. Finally, the finance charge is divided by peak savings in kW to derive the \$56 annual finance cost per kW.

Figure D-10a. Energy Targets - Industrial Conservation

Figure D-10b. Peak Savings - Industrial Conservation
Normal Peak Days

Figure D-10c. Industrial Conservation Load Shapes - All Day Types

Table D.3.4 Summary Worksheet of
Accelerated Industrial Conservation at
Medium Load Growth

Per Unit Data:

(units are average kW of savings)

Initial Cost	\$1,926
Maint. Cost	\$0
Energy Savings	8,760 kWh per year
1 in 2 Peak Savings	1.024 kW @ 2000
1 in 20 Peak Savings	1.034 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Finance per Year	\$56	\$56

Plant Factor	0.977	0.967
--------------	-------	-------

	<u>Program Eligible (aMW)</u>	<u>Energy Savings (aMW)</u>	<u>Peak Savings 1 in 2 (MW)</u>	<u>Peak Savings 1 in 20 (MW)</u>
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	79	3.9	4.0	4.1
1995	164	8.2	8.4	8.5
1996	222	11.1	11.4	11.5
1997	282	14.1	14.5	14.6
1998	345	17.2	17.6	17.8
1999	409	20.5	21.0	21.2
2000	476	23.8	24.4	24.6
2001	542	27.1	27.7	28.0
2002	609	30.4	31.2	31.5
2003	495	24.8	25.4	25.6
2004	379	19.0	19.4	19.6
2005	260	13.0	13.3	13.5
2006	213	10.6	10.9	11.0
2007	163	8.1	8.3	8.4
2008	111	5.5	5.7	5.7
2009	57	2.8	2.9	2.9
2010	0	0.0	0.0	0.0

D.3.4 COMMERCIAL RETROFIT

This program is an acceleration of the long term commercial acquisition program currently under development at Bonneville. This program will provide a package of retrofit measures for buildings in the commercial sector. The commercial sector includes four end-uses: HVAC, lighting, refrigeration, and other equipment (mostly equipment that plugs into an outlet).

Costs and estimates of the commercial conservation potential are taken from the existing commercial supply curve used in the 1990 Resource program. This program accelerates the existing program. However, the commercial conservation baseline does not capture all of the commercial conservation by 2010. For this reason, it is assumed that all savings from the accelerated program are from measures that otherwise would not be installed at all within the study period.

Impacts

The commercial retrofit program was modeled as a 10% reduction in load for a portion of commercial buildings in the Puget Sound area. Penetration rates were chosen to meet the energy targets shown in Table D.3.5. Energy targets are shown graphically in Figure D-11a with corresponding peak savings in Figure D-11b. The effect of conservation on a typical office lighting load shape is shown in Figure D-11c. Table D.3.6 summarizes energy and peak savings for each year.

Table D.3.5 Commercial Retrofit Program
Energy Targets (aMW)

	<u>Already Planned</u>	<u>Additional Conservation</u>	<u>Total Conservation</u>
1995	24	5	29
2000	46	38	84
2005	66	60	126
2010	81	87	168

The conservation and load management team estimated that about 7% of conservation potential could be acquired by 1995, 20% by 2000, 33% by 2005 and the remaining 40% by 2010. A delay in the start of the acceleration from 1992 to 1994 reduces the forecasted accomplishments in the early years. Penetration paths shown in Figures D-11a and D-11b were derived by linear interpolation.

Costs

A cost of \$2,212 per average kilowatt saved, with no maintenance or incentive costs, was assumed. This cost, in terms of average kilowatts, is then

converted to a cost per peak kilowatt. For a 1 in 2 peak day, each average kilowatt of savings has a corresponding peak savings of 1.557 kW. This increases to 1.759 kW on a 1 in 20 day. A summary of cost per kilowatt calculations is provided in Table D.3.6.

Issues

Conservation in the commercial sector is not broken down into separate programs, as has been done in the residential sector. Conservation case load shapes are simply scaled versions of base case load shapes, with all end-uses treated in the same way. A more detailed study would model each commercial program separately, with savings targeted to specific end-uses. Interactions between end-uses would also need to be simulated. For example, a commercial lighting program will decrease electricity consumption for lights, but increase demand for electric space heat.

Figure D-11a. Energy Targets - Commercial Retrofit

Figure D-11b. Peak Savings - Commercial Retrofit
Normal Peak Days

Figure D-11c. Office Lighting Load Shapes - Extreme Peak Day

Table D.3.6 Summary Worksheet of
Commercial Retrofit

Per Unit Data:

(units are average kW of savings)

Initial Cost	\$2,212
Maint. Cost	\$0
Energy Savings	8,760 kWh per year
1 in 2 Peak Savings	1.557 kW @ 2000
1 in 20 Peak Savings	1.759 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$1,420	\$1,257
Maint. per year	\$0	\$0
Plant Factor	0.642	0.568

	<u>Program Eligible (aMW)</u>	<u>Energy Savings (aMW)</u>	<u>Peak Savings 1 in 2 (MW)</u>	<u>Peak Savings 1 in 20 (MW)</u>
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	24	2.4	3.7	4.2
1995	48	4.8	7.4	8.4
1996	118	11.8	18.2	20.5
1997	186	18.6	28.7	32.4
1998	252	25.2	39.1	44.1
1999	317	31.7	49.2	55.6
2000	380	38.0	59.1	66.8
2001	426	42.6	66.5	75.2
2002	472	47.2	73.8	83.4
2003	516	51.6	80.8	91.4
2004	559	55.9	87.7	99.2
2005	600	60.0	94.4	106.8
2006	658	65.8	103.7	117.3
2007	713	71.3	112.7	127.5
2008	767	76.7	121.5	137.4
2009	820	82.0	130.0	147.1
2010	870	87.0	138.3	156.5

D.3.5 LOW FLOW SHOWER HEADS

This program will distribute low flow shower heads free of charge to residences with electric water heaters. Low flow shower heads reduce the amount of hot water required per shower so the hot water heater operates for less time for each shower. Implementation of the program reduces demand for electricity by reducing the number of hot water heaters operating at any given time. The shower heads will be distributed to existing single family, multi-family, and manufactured houses.

Impacts

Since there is no low flow shower head program in place, the baseline assumes that no shower heads will be installed in the absence of this program. The maximum potential for this program is assumed to be 60% of shower heads that use electrically heated hot water. The conservation and load management team estimated that 50% of this potential can be achieved within three years of the program start year and that the remainder can be completed within the succeeding five years. The penetration schedule is shown in Figure D-12a.

Each shower head will save an estimated 231 kWh per year and have a measure life of seven years. Peak savings per shower head are 0.060 kW on a 1 in 2 peak day and 0.043 kW on a 1 in 20 peak day. As with the water heat control program, peak savings are lower on extremely cold days. Estimated savings for all homes combined are shown in Figure D-12b and Table D.3.7.

Costs

Equipment, installation, and administrative costs are estimated to total \$20 per shower head. Cost calculations are summarized in Table D.3.7.

Issues

There has been no empirical testing of the extent to which low flow shower heads themselves reduce peak. It is assumed that the savings from this program will be distributed over hours in the same way as electricity consumption for hot water. Customer acceptance and installation of the shower heads are still uncertain.

Figure D-12a. Low Flow Shower Heads
Program Penetration

Figure D-12b. Peak Savings - Low Flow Shower Heads
Existing Homes Only

Table D.3.7 Summary Worksheet for
Low Flow Shower Heads

Per Unit Data:

Initial Cost	\$20
Maint. Cost	0
Energy Savings	231 kWh per year
1 in 2 Peak Savings	0.060 kW @ 2000
1 in 20 Peak Savings	0.043 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$335	\$464
Maint. per Year	\$0	\$0
Plant Factor	0.441	0.612

	<u>Program Units (Households)</u>	<u>Energy Savings (aMW)</u>	<u>Peak Savings 1 in 2 (MW)</u>	<u>Peak Savings 1 in 20 (MW)</u>
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	0	0.0	0.0	0.0
1995	120,415	3.2	7.2	5.2
1996	239,237	6.3	14.3	10.3
1997	356,481	9.4	21.3	15.4
1998	425,244	11.2	25.4	18.3
1999	492,484	13.0	29.4	21.2
2000	559,108	14.7	33.4	24.1
2001	624,601	16.5	37.3	26.9
2002	689,148	18.2	41.2	29.7
2003	684,325	18.0	40.9	29.5
2004	679,051	17.9	40.6	29.3
2005	674,289	17.8	40.3	29.1
2006	669,556	17.7	40.0	28.9
2007	664,852	17.5	39.7	28.7
2008	660,177	17.4	39.4	28.5
2009	655,530	17.3	39.2	28.3
2010	650,912	17.2	38.9	28.1

D.4.0 LOAD MANAGEMENT

Load management programs are designed to shift load away from the time of system peak. A water heat control program would shut off electricity to water heaters during morning and evening hours. This load is shifted to afternoon or late evening. A time-of-use rate program provides different prices for electricity during peak and off-peak hours.

D.4.1 WATER HEAT CONTROL

This program will install radio-controlled switches on electric water heaters that will allow the electric utility to centrally unplug water heaters at the utility's discretion. The utility will bear the full cost of the equipment and pay the homeowners \$5 per month for the privilege of being able to curtail water heater load as needed. The agreement, which provides the equipment and the incentive, will specify that an interruption can occur approximately three to five times per month during the four winter months for which an incentive will be paid. The program will also provide larger, high efficiency tanks for single family dwellings.

The maximum program penetration rate is 60% for single family homes and 20% for multi-family and manufactured homes. The Conservation and Load Management Team felt that a 60% penetration rate was justified when larger tanks were part of the program. Water heaters are assumed to be shut off from 7:00 a.m. until at least 11:00 a.m. and from 5:00 p.m. to 9:00 p.m. They are shut off in the evening so that the evening peak goes down along with the morning peak. Some of the water heaters would not come on until several hours after 11:00 a.m. or 9:00 p.m. It is important to stagger the times at which water heaters come back on so that a new system peak is not created. Some water heat load could be delayed until very late at night to fill the lowest point of the system load shape.

Figure D-13a shows the estimated fraction of existing single family and multi-family homes that would participate in a water heat control program. The program penetration rates increase steadily as old water heaters wear out and are replaced. Penetration rates for manufactured homes are the same as for multi-family homes, as shown in Table D.5.1. Corresponding penetration rates for new homes are shown in Figure D-13b.

Table D.4.1 Water Heat Control Penetration Rates
Estimated for Existing Homes

	<u>Single Family</u>	<u>Multi- Family</u>	<u>Manufactured Homes</u>
1998	0.200	0.067	0.067
2002	0.400	0.133	0.133
2006	0.600	0.200	0.200
2010	0.600	0.200	0.200

Figure D-13a. Water Heat Control Penetration Rates
Existing Homes

Figure D-13b. Water Heat Control Penetration Rates
New Homes

Impacts

Coincident peak savings for single family homes, or savings at the time of system peak, are 1.09 kW on a normal peak day and 0.79 kW on an extreme peak day. On an extremely cold day some water heat load shifts to later in the morning, with less load available for shedding at the time of system peak. Peak savings are shown, in megawatts, in Figure D-14a.

Base case load shapes for water heat control were derived from a sample of single family homes in Washington and Oregon. The same load shapes were used to simulate water heat consumption in multi-family and manufactured homes. Base case load shapes for an average winter day, a 1 in 2 peak day, and a 1 in 20 peak day were derived from ELCAP data. Water heat load shapes, with and without water heater control by the utility, are shown in Figure D-14b.

The program will also provide larger highly insulated tanks to single family homes along with the water heat controls. The new tanks provide energy savings of 251 kWh per year. A larger tank provides extra storage of hot water for times when electricity is shut off to the water heater.

Costs

The controls are estimated to cost \$228 for each house. The incremental cost of a larger tank for a single family home is \$120. The incentive cost is \$5 per month for the 4 months for which the program operates. An additional \$8 per year covers administrative costs.

Issues

The major issue is customer acceptance: allowing someone else to control their access to hot water is something many customers will not consider, at least not at the level of incentive that would be cost-effective for the utility.

Another issue is the effectiveness of the delivery mechanism. In order to capture a significant share of the replacement market, the programs must have the cooperation of the contractors who replace the old tanks and the builders who install tanks in new construction. This may require some type of dealer incentive.

A third issue is the utility's load management communication system. Radio broadcasting systems are the most common choice, and licenses may be difficult and time-consuming to obtain.

A fourth issue that may impact assumptions about market penetration rate is that smaller single family homes may not have room for larger water heater tanks.

Figure D-14a. Peak Savings - Water Heat Control
Single Family Homes

Figure D-14b. Water Heat Control Load Shapes

A final issue is whether it is necessary to limit program participation to a tank replacement strategy. Many other utilities operate successful hot water heater control programs with only a monthly incentive. This type of program would have a greater peak load reduction potential because it wouldn't be limited to the new or replacement market.

Summary Worksheets

Summary worksheets are provided for single family, multi-family, and manufactured homes in Tables D.4.2, D.4.3, and D.4.4. Each worksheet combines data for new and existing homes. Single family homes have some energy savings due to replacement with more efficient tanks. Multi-family and manufactured homes have no energy savings.

Note that peak savings on a 1 in 20 day are lower than on a 1 in 2 day. During extremely cold weather, water heat load shifts to later in the morning. This is shown clearly in Figures D-1a and D-7a. This behavior, which may be due to work or school closures, helps to reduce peak loads. The result is that, on a 1 in 20 day at the time of system peak, there is less load available to shed.

Table D.4.2 Summary Worksheet for Single Family
Water Heat Control, Medium Load Growth

Per Unit Data:

Initial Cost	\$348
Maint. Cost	\$28
Energy Savings	251 kWh per year
1 in 2 Peak Savings	1.090 kW @ 2000
1 in 20 Peak Savings	0.786 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$319	\$443
Maint. per year	\$26	\$36
Plant Factor	0.026	0.036

	Program Units (Households)	Energy Savings (aMW)	Peak Savings 1 in 2 (MW)	Peak Savings 1 in 20 (MW)
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	21,067	0.4	23.0	16.6
1995	55,471	1.1	60.7	43.8
1996	102,655	2.1	112.5	81.2
1997	143,325	3.2	157.1	113.4
1998	183,485	4.2	201.0	145.0
1999	222,773	5.2	243.5	175.7
2000	261,698	6.2	285.2	205.8
2001	299,754	7.2	325.4	234.8
2002	337,180	8.2	364.4	263.0
2003	374,031	9.1	403.6	291.2
2004	409,959	10.0	441.5	318.6
2005	445,598	10.9	479.0	345.6
2006	480,694	11.8	515.7	372.1
2007	481,243	11.7	514.8	371.4
2008	481,940	11.6	514.0	370.9
2009	482,655	11.5	513.3	370.4
2010	483,400	11.4	512.6	369.9

Table D.4.3 Summary Worksheet for Multi-Family
Water Heat Control, Medium Load Growth

Per Unit Data:

Initial Cost	\$228
Maint. Cost	\$28
Energy Savings	0 kWh per year
1 in 2 Peak Savings	0.646 kW @ 2000
1 in 20 Peak Savings	0.466 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$353	\$489
Maint. per year	\$43	\$60
Plant Factor	0.000	0.000

	Program Units (Households)	Energy Savings (aMW)	Peak Savings 1 in 2 (MW)	Peak Savings 1 in 20 (MW)
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	9,491	0.0	6.3	4.5
1995	24,195	0.0	16.0	11.6
1996	38,818	0.0	25.6	18.4
1997	50,957	0.0	33.5	24.2
1998	63,106	0.0	41.3	29.8
1999	75,148	0.0	48.9	35.3
2000	87,178	0.0	56.3	40.6
2001	99,045	0.0	63.5	45.8
2002	111,009	0.0	70.6	50.9
2003	113,907	0.0	72.0	51.9
2004	116,896	0.0	73.4	53.0
2005	119,962	0.0	74.8	54.0
2006	123,126	0.0	76.3	55.1
2007	126,331	0.0	77.9	56.2
2008	129,608	0.0	79.4	57.3
2009	133,001	0.0	81.1	58.5
2010	136,486	0.0	82.7	59.7

Table D.4.4 Summary Worksheet for Manufactured Homes
Water Heat Control, Medium Load Growth

Per Unit Data:

Initial Cost	\$228
Maint. Cost	\$28
Energy Savings	0 kWh per year
1 in 2 Peak Savings	0.739 kW @ 2000
1 in 20 Peak Savings	0.533 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$309	\$428
Maint. per year	\$38	\$53
Plant Factor	0.000	0.000

	Program Units (Households)	Energy Savings (aMW)	Peak Savings 1 in 2 (MW)	Peak Savings 1 in 20 (MW)
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	1,892	0.0	1.4	1.0
1995	4,850	0.0	3.6	2.6
1996	7,790	0.0	5.7	4.1
1997	10,381	0.0	7.7	5.5
1998	12,982	0.0	9.6	6.9
1999	15,566	0.0	11.5	8.3
2000	18,164	0.0	13.4	9.7
2001	20,707	0.0	15.3	11.0
2002	23,228	0.0	17.1	12.3
2003	23,713	0.0	17.3	12.5
2004	24,182	0.0	17.6	12.7
2005	24,670	0.0	17.9	12.9
2006	25,160	0.0	18.1	13.1
2007	25,652	0.0	18.4	13.3
2008	26,147	0.0	18.7	13.5
2009	26,644	0.0	18.9	13.7
2010	27,143	0.0	19.2	13.8

D.4.2 TIME-OF-USE RATES

This voluntary program offers an opportunity for electric bill savings to retail single family residential customers that sign up for time-of-use (TOU) rates. The conservation and load management team felt that a voluntary program could be constructed to draw 20% of single family households (see Figure D-15a). The utility installs a TOU meter on participating houses and sets retail energy rates so that peak rates are twice as high as off-peak rates. Participants that do an average amount of load deferral to the off-peak period can expect to reduce their monthly bills by \$5. The TOU rates are in effect for four months each winter. Peak hours are 7:00 a.m. to 11:00 a.m.

Impacts

The TOU rate program assumes that electrical load is reduced by 15% at the time of system peak in single family homes that participate (see Figure D-15b). With 20% of homes participating, electrical demand averaged across all single family homes would be reduced by 3% at the time of system peak.

The 15% load reduction applies from 7:00 a.m. until 11:00 a.m., with a six-hour payback period following. Energy payback is equal to energy saved from 7:00 to 11:00, so there is no net energy benefit. Figure D-15c shows the assumed hourly pattern of residential electricity consumption with and without TOU rates. The plot is for a typical single family home with electric space heat and water heat.

Because electricity consumption for different residential end-uses is forecasted to grow at different rates, peak savings per household are not constant over time. Electric space heat becomes a smaller share of residential electricity consumption due to new construction and loss of market share to natural gas. Over time, residential electricity consumption becomes less weather sensitive, and average peak savings per household declines.

Costs

The TOU meters cost \$115 per household. The program will expect to provide bill savings of about \$5 per month for active program participants. Non participants will end up paying higher bills to offset the lower bills paid by program participants. In addition, it is assumed that administrative costs will come to \$2 per unit per year. This covers the costs of additional meter readers as well as the costs of program administration and evaluation. Cost calculations are summarized in Table D.4.5.

Issues

1. This proposal is based on a Snohomish PUD pilot program. Although Snohomish PUD realized an overall net peak reduction for their TOU pilot program, during the cold weather months the peak demand of the evening test group (TOU customers) frequently exceeded that of the evening control group (normal electric rate customers). This included the system peak day of February 3, 1989. In addition, the evening group increased total energy consumption in comparison with the control group. The reasons for these increases need to be studied further.

There is not enough data from Snohomish PUD's TOU pilot program to confidently predict the impacts from a region-wide, long-term program. The load shape impacts from a long-term program may be very different than those from a small, short-term experiment. With a long-term program, customers would be much more likely to make investments in load shifting devices such as clock thermostats and hot water heater timers.

2. A second issue is whether or not a TOU rate program should be aimed toward, or limited to, a specific group of residential customers. A TOU rate program would be more effective if targeted at high electrical consumers: larger, all-electric homes. A larger average peak kW reduction, at a lower cost, would be realized with this type of home in comparison to smaller homes, or homes with gas heat and gas appliances.
3. Another issue is reliability. The voluntary basis of the program reduces the reliability for peak load reduction, in comparison to programs that employ direct load control.
4. Finally, utilities that adopt TOU rates will have to modify their billing procedures. This may be easy for some utilities, but difficult and costly for others.

Figure D-15a. Time-of-Use Rates
Program Penetration

Figure D-15b. Peak Savings - Time-of-Use Rates
Single Family Homes

Figure D-15c. Time-of-Use Rates Load Shapes

Table D.4.5 Summary Worksheet for
Time-of-Use Rates, Medium Load Growth

Per Unit Data:

Initial Cost	\$115
Maint. Cost	\$22
Energy Savings	0 kWh per year
1 in 2 Peak Savings	0.461 kW @ 2000
1 in 20 Peak Savings	0.514 kW @ 2000

	<u>1 in 2</u>	<u>1 in 20</u>
Per kW Costs:		
Initial Cost	\$249	\$224
Maint. per Year	\$48	\$43
Plant Factor	0.000	0.000

	<u>Program Units (Households)</u>	<u>Energy Savings (aMW)</u>	<u>Peak Savings 1 in 2 (MW)</u>	<u>Peak Savings 1 in 20 (MW)</u>
1990	0	0.0	0.0	0.0
1991	0	0.0	0.0	0.0
1992	0	0.0	0.0	0.0
1993	0	0.0	0.0	0.0
1994	35,051	0.0	18.5	20.2
1995	82,768	0.0	42.8	46.8
1996	131,628	0.0	66.4	72.9
1997	181,644	0.0	89.5	98.7
1998	196,200	0.0	94.6	104.7
1999	210,797	0.0	99.4	110.4
2000	225,952	0.0	104.2	116.2
2001	241,208	0.0	109.4	122.5
2002	256,751	0.0	114.6	128.9
2003	259,645	0.0	114.1	128.8
2004	262,340	0.0	113.6	128.7
2005	265,273	0.0	113.1	128.7
2006	268,264	0.0	112.7	128.7
2007	271,273	0.0	113.4	129.6
2008	274,400	0.0	114.1	130.4
2009	277,524	0.0	114.9	131.2
2010	280,658	0.0	115.6	132.1

D.5.0 FUEL SWITCHING

The Puget Sound Area Electric Reliability Plan (PSAERP) is examining a number of alternatives for reducing peak load on the transmission system serving the Puget Sound Area. Because the problem addressed by the PSAERP is a transmission constraint, the load relevant to the fuel switching analysis is annual peak kW.

Switching consumer electric loads to natural gas (fuel switching) is a part of the solution packages being analyzed. The analysis of fuel switching was a joint effort of the Conservation and Load Management and the Load Forecasting Teams.

D.5.1 OVERVIEW

The fuel switching analysis was based on separating buildings into market segments. Market segments are categories where the response of buildings to a fuel switching program is relatively homogeneous. A preliminary analysis screened out market segments with buildings where fuel switching would be prohibitively expensive. The screening assumptions are described later in this paper.

For market segments analyzed in detail, the number of buildings and the kW per building (under both normal winter and extreme cold weather conditions) were estimated in the PSAERP load forecast. The product of the number of buildings and kW per building gave the total electric load or "technical potential" for fuel switching. The Conservation and Load Management Team estimated a program participation rate and the costs of switching per building for each market segment. The technical potential multiplied by the participation rate gives the "achievable potential." This achievable load is matched with costs to determine the cost per kW for programmatic fuel switching. The cost per kW is used to compare fuel switching with other PSAERP alternative solutions.

D.5.2 SUMMARY OF RESULTS

Some fuel switching is expected to occur as a result of market forces alone because the price of natural gas is less than electricity throughout the PSAERP planning horizon (this difference is forecasted to narrow between 1990 and 2010). Approximately 200 MW of fuel switching is forecast to occur in response to market forces by the year 2000. After market induced fuel switching is accounted for, approximately 4,200 MW of load remains in market segments considered available for fuel switching. This is the technical potential for fuel switching. Of this amount, 250 MW of achievable potential is estimated to exist.

D.5.3 MARKET SEGMENTS

For analytical purposes, buildings were categorized into relatively homogeneous groups. Preliminary analysis screened out some categories as unrealistic or prohibitively expensive targets for programmatic fuel switching. Seven market segments were analyzed in detail. In each of these segments the number of buildings and peak load per building were derived from the PSAERP load forecast. The percentage of eligible buildings that would participate in a fuel switching program was estimated by the Conservation and Load Management Team. The product of eligible buildings or total peak load in a market segment and that market segment's participation rate gives the number of achievable households or peak load available for fuel switching in the market segment. The assumptions used to develop the seven market segments are discussed in the following sections.

Screening Assumptions

Industrial and commercial sectors were screened out due to high costs of switching, limited potential, and institutional barriers. Multi-family units and all existing homes with zonal space heat were also screened out due to cost and institutional barriers. Homes currently using gas were screened out. Although some of these homes do have electric space or water heat, switching was assumed to occur from market forces alone.

Segmentation Criteria

From the remaining housing stock, market segments are developed by separating the stock by housing type (single family or manufactured housing), housing vintage (new units built in 1990 or later versus existing units built before 1990), and gas availability. Gas availability groups households depending on the requirements of connecting the household to natural gas service. The four categories of gas availability are: 1) household already receiving natural gas; 2) not receiving gas, but requiring only a service drop (also defined as within 1/4 mile of a gas main; 3) household requiring both a main extension and service drop; 4) more than main extension required, or significant distribution system expansion.

Housing type and vintage are available directly from the PSAERP forecast. Gas availability was estimated as the percentage of homes in each gas availability category for both new and existing homes by county. The initial estimates were developed by Bonneville from population densities and natural gas service territories. These estimates were then revised to incorporate comments and improved data from Washington Natural Gas, Cascade Natural Gas, Seattle City Light, Tacoma Public Utilities, Snohomish County PUD, Puget Sound Power and Light, the Washington State Energy Office, and the Washington Utilities and Transportation Commission.

The gas availability ratios represent a midpoint in the time period of the PSAERP planning horizon. The ratios can be expected to change in time due to geographic changes in population density and the expected expansion of natural gas distribution systems. The direction of the changes are uncertain. A rapid expansion and filling in of natural gas distribution systems could place a large part of the population in either the gas-in-home or service-drop-only category, and consequently reduce the proportion of homes in the main-

extension and not-available categories. Another possibility would be for the gas companies to expand their territories into areas not currently served which would increase the amount of homes in the main extension category and reduce the proportion in other categories. Even if an unambiguous scenario were assumed for population density changes and gas expansion in the future, no data currently exists to estimate the magnitude of these changes. Therefore, the most appropriate planning assumption is to rely on midpoint estimates based on the available data.

The electric equipment to be switched was specified for each market segment. For most market segments, the most cost effective program is to switch both the space and water heat equipment so that hook-up costs are spread over a larger amount of load. However, for households with low hook-up costs (service drop only), switching only the water heater was also analyzed. In new homes, the space heating equipment is not yet installed and is undetermined. The costs and load associated with space heat in these homes is a weighted average of the current proportions of central forced air and resistance.

Participation Rates

Experience with conservation programs indicates that only a portion of eligible homes will participate in a program. Program participation rates were assigned to each market segment to indicate this percentage. The rates were developed by the Conservation and Load Management Team of the PSAERP.

The Pacific Northwest gas and electric utilities are forecasting that most new homes built within 1/4 mile of gas mains will choose gas from market forces alone. We assume for the PSAERP that new electric homes within 1/4 mile of existing gas mains have chosen electric space and water heat for reasons that would not be overcome with a fuel switching program. Therefore, the program participation rate for new homes within 1/4 mile of a gas main is set to zero.

The above assumptions yield the following market segments:

Housing Type	Housing Vintage	Gas Availability	Electric Equipment
1) Single Family	Existing	Service Drop	Central Forced Air + Water
2) Single Family	Existing	Main Extension	Central Forced Air + Water
3) Single Family	Existing	Service Drop	Water Heat Only
4) Single Family	New	Main Extension	Space + Water
5) Manuf. Homes	Existing	Service Drop	Central Forced Air + Water
6) Manuf. Homes	Existing	Main Extension	Central Forced Air + Water
7) Manuf. Homes	New	Main Extension	Space + Water

D.5.4 COSTS

The major cost categories are equipment, administrative, hook-up and operating. These costs vary between market segments, but not within a market segment. The cost data was gathered from several different reports by regional energy concerns and a survey of Puget Sound area contractors conducted by Branch Richards Anderson Company (BRACO). All costs are expressed in 1990 dollars unless otherwise noted. For purposes of the PSAERP, it was assumed that nominal nonoperating costs increase at the rate of inflation.

Capital costs (operating costs not included) by market segment are detailed in Table D.5.2. This table shows costs calculated from the social and utility perspective. Cost perspectives are detailed in a later section. Operating costs are forecast annually and detailed in a different section.

Equipment Costs

Equipment costs include the furnace or water heater, flue, venting, piping, other installation expenses, ductwork, and shell improvements required to meet the housing code. An additional cost in this category is the depreciated value of electric equipment not used after the home is switched to gas. Equipment cost data were collected from two sources: a Northwest Power Planning Council report, Heating New Homes: A Comparison of Heating with Electric, Natural Gas and Fuel Oil Heating Systems, and the BRACO survey.

Administrative Costs

Administrative costs are those costs associated with design, implementation and oversight of fuel switching program or policies. The methods that may be used to implement fuel switching have not yet been determined. For purposes of the PSAERP Environmental Impact Statement, fuel switching is implemented similar to a conservation program. This requires inclusion of administrative costs. Program administrative costs are set equal to twenty percent of total equipment costs. This is roughly equal to experience in Bonneville's conservation program.

Hook-up Costs

Hook-up costs are the costs of connecting a household to natural gas. A cost was estimated for the gas availability categories of service drop and main extension. The cost of service drop only (gas availability category #2) is \$550 based on a Washington State Energy Office report, Analysis of Consumer and Marginal Costs for Electric and Natural Gas Space and Water Heat in Single Family Residences in Puget Sound Power and Light Company Service Territory. The cost of a main extension only is \$900 based on a report from the Association of Northwest Gas Utilities, Coordinated Energy Development in the Pacific Northwest. Therefore the cost of main extension plus service drop (gas availability category #3) is \$1,450 (\$550 + \$900).

Operating Costs

The operating cost for both gas and electric equipment equals the annual energy expense. This is calculated as the product of annual energy consumption multiplied by the price. For electric equipment, energy consumption is taken directly from the PSAERP forecast. Energy consumption

for gas equipment equals electric kWh divided by an efficiency factor 0.75 for space heat and 0.53 for water heat.

The price for both fuels is the wholesale marginal cost of the fuel. Retail costs were not used because they may include other costs which are already counted in this analysis as explicitly cost categories, such as hook-up and administration. For electricity, the wholesale marginal cost is that used by the PSAERP evaluation team which is Bonneville's marginal cost for resource planning. The wholesale marginal cost of natural gas is equal to the city gate price as forecast in the Joint Council/Bonneville Long Term Forecast shown in Table D.5.3.

Cost Perspective

Costs may be calculated from several perspectives. The end-user and society are two common viewpoints. In addition, programmatic costs of fuel switching may be calculated on the basis of a retail gas or electric company, a cooperative effort of energy interests, or Bonneville, a federal wholesale utility. The PSAERP analyzes fuel switching costs from two perspectives, social costs and utility costs. Social costs are used as a resource selection criteria. Utility costs are for a theoretical electric utility choosing to encourage fuel switching.

Social costs are set equal to the incremental costs (the difference between gas and electric) in all cost categories. The treatment of the utility costs requires a policy decision on how the costs will be divided among various parties. A full cost scenario was used in this analysis to determine the maximum cost a utility may incur. This cost scenario assigns all costs associated with switching equipment, hook-up and administration to the utility. Operating costs are borne by the end-user and therefore not included in utility cost calculations. In this scenario, a distinction must be made in the calculations between new and existing homes.

For existing homes in the full cost scenario, the full costs of hook-up and administration are assigned to the utility. The utility also pays full equipment costs except the depreciated value of unused electric equipment. This is a social cost of foregone useful value, but not an out-of-pocket expense which must be paid. Operating costs are assigned to the end-user, not paid by the utility.

For new homes, the full cost scenario retains the assumption of full hook-up costs and administrative costs, and no operating costs. However, equipment costs are incremental for new homes. A full equipment cost assumption for new homes would imply that the utility pays for the space and water heat system in a home not yet built. The working assumption in determining costs is that the utility pays the costs of switching, not the cost involved in supplying the end-use. Therefore, incremental equipment costs are used for new homes.

The utility cost scenario used here is a very conservative planning assumption. If any cost sharing occurs with other parties such as gas utilities or consumers, the cost scenario used here will overstate electric utility costs.

Free Riders

It would be difficult, if not impossible, for a fuel switching policy to effectively distinguish between otherwise equal households that will or will not switch due to market forces alone. For the PSAERP it was assumed to be impossible. Therefore, the program is applied both to homes within a market segment that are forecast to remain electric (programmatic fuel switching) and all homes forecast to switch due to the market alone (market induced fuel switching). The homes treated by a program that would have switched without a program are called "free riders." Free riders create an additional cost for a fuel switching program.

The number of homes forecast to switch from market forces was estimated by subtracting the number of electric homes in the base case forecast from the number of homes in a forecast where electric saturation rates were held constant at 1990 stock average levels. The difference is the number of market induced fuel switchers.

The market induced switchers were assumed in the PSAERP to be within 1/4 mile of existing gas mains. Homes requiring a main extension to hook-up to natural gas are not able to readily switch and may incur significant additional expense. As a result, market induced fuel switchers fall in to three categories: existing single family / service drop / CFA + water heat; existing single family / service drop / water heat only; existing manufactured homes / service drop / CFA + water heat. The number of homes in each segment is derived directly from the PSAERP forecast.

From a social cost perspective, free riders increase only the administrative expense. Other costs such as equipment or hook-up would have been incurred anyway because these are the homes forecast to switch in the base case. The only difference is which party incurs the cost, but from society's perspective this is a transfer, not an additional cost. The total social cost is increased by the number of free riders multiplied by the administrative cost per household.

From the utility perspective, the utility is now incurring the full program cost for each free rider. These are the homes the utility must also reach with a program in order to reach those homes which would not switch from market forces. The total utility cost is increased by the number of free riders multiplied by the total program cost per household.

D.5.5 RESULTS

The basic input data and results are summarized in Tables D.5.1, D.5.2 and D.5.3.

Table D.5.1 shows the forecast data used to derive the number of households in each market segment. The data are categorized by housing type and vintage and equipment type. Reading down a column, the total housing stock is decreased

by the ratios for electric saturations, central forced air for space heat and the service drop and main extension gas availability ratios.

Table D.5.2 shows the detail of cost per household by market segment.

Table D.5.3 combines the data from Tables D.5.1 and D.5.2 and includes the kW per household to derive the total load and cost for fuel switching. It is important to note that the costs shown in Table D.5.3 are capital cost only and do not include operating costs.

The cost per kW is an important basis for comparison of resources. The PSAERP analysis will match the achievable load and capital costs documented in this section with operating costs to derive a levelized cost per kW for the entire fuel switching program.

In order for annual operating cost to be incorporated, the costs need to be calculated on a levelized basis. The social costs for the entire fuel switching sector are levelized and detailed elsewhere in this document to compare with other resources.

For all market sectors the levelized cost per kW will be less than the capital cost per kW from the social perspective. This is because levelized costs will include operating costs which are less for gas space and water heat than for electric equipment. Gas equipment is less efficient than electric (ratios given in Operating Cost section), but the loss in efficiency is more than offset by the relatively inexpensive gas prices.

From the utility perspective, the capital cost is a fair approximation of total costs because operating costs do not affect utility costs.

Capital cost per kW do provide a good indication of the results and the ranking among market segments should be roughly equivalent to the levelized cost ranking, because operating costs tend to act in the same direction for all market segments. The capital cost per kW by market segment are detailed in Table D.5.3.

From both the social and utility perspectives, the least expensive market segments (in terms of capital cost per kW) are also the market segments with the most switchable load, the segments with existing single family homes where both central forced air and water heat are switched. The rank of these two segments varies in the different perspectives because of the free rider issue.

The most expensive segment is for an existing single family home where only the water heater is switched. This is a result of two factors. The hook-up cost is spread over a relatively small amount of load per household because no space heat load is switched and there are large number of free riders in this segment because water heat equipment wears out and is turned over relatively quickly, so there is a lot of market induced switching.

TABLE D.5.1
Households

	SPACE HEAT				WATER HEAT			
	Existing	2000	New	2010	Existing	2000	New	2010
Single Family:	1991	2000	2000	2010	1991	2000	2000	2010
Households	1,092,178	1,042,783	212,503	415,389	24,207	212,503	212,503	415,389
Saturation	39%	38%	30%	30%	36%	36%	34%	33%
Electric Units	424,857	396,258	63,751	123,484	8,642	73,117	73,117	138,937
Cent. Forced Air	26%	26%	100%	100%	0%	0%	0%	0%
Electric Units	110,463	103,027	63,751	123,484	0%	0%	0%	0%
Cent. Forced Air	31%	31%	0%	0%	0%	0%	0%	0%
Electric Units	34,244	31,938	0	0	0	0	0	0
Cent. Forced Air	22%	22%	15%	15%	15%	15%	15%	15%
Electric Units	24,302	22,666	9,563	18,523	1,296	10,968	10,968	20,841
Manuf. Housing:								
Households	105,045	95,495	42,403	84,759	4,345	84,885	84,885	84,759
Saturation	81%	79%	75%	75%	75%	76%	76%	76%
Electric Units	84,876	75,441	31,802	63,335	3,259	64,512	64,512	64,379
Cent. Forced Air	92%	92%	92%	92%	92%	92%	92%	92%
Electric Units	78,086	69,406	29,258	58,268	2,998	59,351	59,351	59,351
Cent. Forced Air	31%	31%	0%	0%	0%	0%	0%	0%
Electric Units	24,207	21,516	0	0	0	18,399	18,399	18,399
Cent. Forced Air	22%	22%	15%	15%	15%	22%	22%	22%
Electric Units	17,179	15,269	4,770	9,500	489	13,057	13,057	13,057

CFA - Central Forced Air
SD - Service Drop
ME - Main Extension

TABLE D.5.2
Cost per Household
(1990 \$)

	Electric	Gas	Social	Utility	Capital
1) Exist SF, CFA+WH, Service Drop					
EQUIPMENT					
Water Heat					
Replacement Unit	240	250	10	250	250
Installation	120	150	30	150	150
Flue, venting	0	150	150	150	150
NPV, remaining life, elect. eqpt	0	72	72	0	0
Central Forced Air					
Replacement Unit	575	900	325	900	900
Installation	0	855	855	855	855
Flue, venting	0	400	400	400	400
NPV, remaining life, elect. eqpt	0	177	177	0	0
Subtotal	935	2,954	2,019	2,705	2,705
ADMINISTRATIVE	0	0	541	541	541
HOOK-UP					
Service Drop	0	550	550	550	550
TOTAL	935	3,504	3,110	3,796	3,796
2) Exist SF, CFA+WH, Main Extension					
EQUIPMENT					
Water Heat					
Replacement Unit	240	250	10	250	250
Installation	120	150	30	150	150
Flue, venting	0	150	150	150	150
NPV, remaining life, elect. eqpt	0	72	72	0	0
Central Forced Air					
Replacement Unit	575	900	325	900	900
Installation	0	855	855	855	855
Flue, venting	0	400	400	400	400
NPV, remaining life, elect. eqpt	0	177	177	0	0
Subtotal	935	2,954	2,019	2,705	2,705
ADMINISTRATIVE	0	0	541	541	541
HOOK-UP					
Service Drop	0	550	550	550	550
Main Extension	0	900	900	900	900
TOTAL	935	4,404	4,010	4,696	4,696
3) Exist SF, WH Only, Service Drop					
EQUIPMENT					
Water Heat					
Replacement Unit	240	250	10	250	250
Installation	120	150	30	150	150
Flue, venting	0	150	150	150	150
NPV, remaining life, elect. eqpt	0	72	72	0	0
Subtotal	360	622	262	550	550
ADMINISTRATIVE	0	0	110	110	110
HOOK-UP					
Service Drop	0	550	550	550	550
TOTAL	360	1,172	922	1,210	1,210
4) New SF, SH+WH, Main Extension					
EQUIPMENT					
Space Heat					
Weighted Av. Equipment	2,115	4,100	1,985	1,985	4,100
Envelope effic (1991)	800	420	-380	-380	420
Water heat					
All equipment and installation	400	550	150	150	550
Subtotal	3,315	5,070	1,755	1,755	5,070
ADMINISTRATIVE	0	0	1,014	1,014	1,014
HOOK-UP					
Service Drop	0	550	550	550	550
Main Extension	0	900	900	900	900
TOTAL	3,315	6,520	4,219	4,219	7,534

TABLE D.5.2 (continued)
Cost per Household
(1990 \$)

	Electric	Gas	Social	Utility	Capital
5) Exist MH, CFA+WH, Service Drop					
EQUIPMENT					
Water Heat					
Replacement Unit	240	250	10	250	250
Installation	120	150	30	150	150
Flue, venting	0	100	100	100	100
NPV, remaining life, elect. eqpt	0	72	72	0	0
Central Forced Air					
Replacement Unit	575	1,000	425	1,000	1,000
Installation	0	730	730	730	730
Flue, venting	0	200	200	200	200
NPV, remaining life, elect. eqpt	0	144	144	0	0
Subtotal	935	2,646	1,711	2,430	2,430
ADMINISTRATIVE	0	0	486	486	486
HOOK-UP					
Service Drop	0	550	550	550	550
TOTAL	935	3,196	2,747	3,466	3,466
6) Exist MH, CFA+WH, Main Extension					
EQUIPMENT					
Water Heat					
Replacement Unit	240	250	10	250	250
Installation	120	150	30	150	150
Flue, venting	0	100	100	100	100
NPV, remaining life, elect. eqpt	0	72	72	0	0
Central Forced Air					
Replacement Unit	575	1,000	425	1,000	1,000
Installation	0	730	730	730	730
Flue, venting	0	200	200	200	200
NPV, remaining life, elect. eqpt	0	144	144	0	0
Subtotal	935	2,646	1,711	2,430	2,430
ADMINISTRATIVE	0	0	486	486	486
HOOK-UP					
Service Drop	0	550	550	550	550
Main Extension	0	900	900	900	900
TOTAL	935	4,096	3,647	4,366	4,366
7) New MH,SH+WH, Main Extension					
EQUIPMENT					
Space Heat					
CFA Equipment and Installation	1,500	2,000	500	500	2,000
Water heat					
All equipment and installation	400	500	100	100	500
Subtotal	1,900	2,500	600	600	2,500
ADMINISTRATIVE	0	0	500	500	500
HOOK-UP					
Service Drop	0	550	550	550	550
Mai. Extension	0	900	900	900	900
TOTAL	1,900	9	2,550	2,550	4,450

TABLE D.5.3
Summary of Fuel Switching Potential

Market Segment	Eligible Cumul. Units Part. %	(1)	(2)	(3) (1+2)	Part. Units	Extrem kW/Unit	Part. Ext.	(4) (3+4)	(5) (3+4)	Market Switched	(6)	(7)	(8)	Admn Utility (\$/MS)	Social Total \$	Capital Cost Only Social \$ /HH	Utility Total \$	Utility \$ /HH	Utility \$ /kW
1) Ex SF/CFA+WH/SD																			
1991	34,244	0%		0	0	8.19	0	0	0	0	0	\$3,110	\$541	\$3,796	0	0	0	0	0
1995	33,219	10%		3,322	27	8.16	27	1,952	0	1,952	1,952	0	0	0	11,387	3,428	20,021	6,027	739
2000	31,938	50%		15,969	130	8.12	130	9,385	0	9,385	9,385	0	0	0	54,741	3,428	422	96,244	6,027
2005	30,302	70%		21,211	171	8.08	171	12,466	0	12,466	12,466	0	0	0	72,710	3,428	424	127,837	6,027
2010	28,665	70%		20,066	161	8.05	161	11,793	0	11,793	11,793	0	0	0	68,783	3,428	426	120,933	6,027
2) Ex. SF/CFA+WH/ME																			
1991	24,302	0%		0	0	8.19	0	0	0	0	0	\$4,010	\$541	\$4,696	0	0	0	0	0
1995	23,484	0%		0	0	8.16	0	0	0	0	0	0	0	0	0	0	0	0	0
2000	22,666	20%		4,533	37	8.12	37	0	0	0	0	0	0	0	18,178	4,010	494	21,288	4,696
2005	21,505	50%		10,752	87	8.08	87	0	0	0	0	0	0	0	43,117	4,010	496	50,493	4,696
2010	20,343	70%		14,240	115	8.05	115	0	0	0	0	\$922	\$110	\$1,210	57,103	4,010	498	66,872	4,696
3) Ex. SF/WH/SD																			
1991	242,420	0%		0	0	0.83	0	0	0	0	0	0	0	0	0	0	0	0	0
1995	225,278	5%		11,264	9	0.83	9	10,372	0	10,372	10,372	0	0	0	11,526	1,023	1,240	26,179	2,324
2000	203,850	20%		40,770	33	0.82	33	37,540	0	37,540	37,540	0	0	0	41,719	1,023	1,248	94,755	2,324
2005	186,829	30%		56,049	45	0.81	45	51,608	0	51,608	51,608	0	0	0	57,354	1,023	1,263	130,265	2,324
2010	169,809	30%		50,943	41	0.80	41	46,907	0	46,907	46,907	0	0	0	52,129	1,023	1,279	118,398	2,324
4) New SF/SH+WH/ME																			
1991	1,089	0%		0	0	4.08	0	0	0	0	0	\$4,219	\$1,014	\$4,219	0	0	0	0	0
1995	4,855	3%		146	4	4.05	4	0	0	0	0	0	0	0	615	4,219	1,042	615	4,219
2000	9,563	15%		1,434	6	4.01	6	0	0	0	0	0	0	0	16,053	4,219	1,052	6,053	4,219
2005	14,043	28%		3,932	16	3.99	16	0	0	0	0	0	0	0	16,591	4,219	1,057	16,591	4,219
2010	18,523	41%		7,594	30	3.97	30	0	0	0	0	\$2,747	\$486	\$3,466	32,044	4,219	1,062	32,044	4,219
5) Ex. MH/CFA+WH/SD																			
1991	24,207	0%		0	0	4.86	0	0	0	0	0	0	0	0	0	0	0	0	0
1995	23,011	5%		1,151	6	4.83	6	460	0	460	460	0	0	0	3,384	2,941	609	5,581	4,851
2000	21,516	20%		4,303	21	4.80	21	1,719	0	1,719	1,719	0	0	0	12,656	2,941	613	20,873	4,851
2005	19,958	30%		5,987	29	4.77	29	2,392	0	2,392	2,392	0	0	0	17,609	2,941	617	29,042	4,851
2010	18,399	30%		5,520	26	4.74	26	2,205	0	2,205	2,205	0	0	0	16,234	2,941	620	26,774	4,851
6) Ex. MH/CFA+WH/ME																			
1991	17,179	0%		0	0	4.86	0	0	0	0	0	\$3,647	\$486	\$4,366	0	0	0	0	0
1995	16,330	0%		0	0	4.83	0	0	0	0	0	0	0	0	0	0	0	0	0
2000	15,269	10%		1,527	7	4.80	7	0	0	0	0	0	0	0	5,569	3,647	760	6,666	4,366
2005	14,163	20%		2,833	14	4.77	14	0	0	0	0	0	0	0	10,330	3,647	765	12,367	4,366
2010	13,057	30%		3,917	19	4.74	19	0	0	0	0	\$2,550	\$500	\$2,550	14,286	3,647	769	17,102	4,366
7) New MH/SH+WH/ME																			
1991	489	0%		0	0	3.91	0	0	0	0	0	0	0	0	0	0	0	0	0
1995	2,392	3%		72	3	3.83	3	0	0	0	0	0	0	0	183	2,550	183	2,550	667
2000	4,770	12%		572	2	3.72	2	0	0	0	0	0	0	0	1,460	2,550	685	1,460	2,550
2005	7,135	22%		1,570	6	3.65	6	0	0	0	0	0	0	0	4,003	2,550	699	4,003	2,550
2010	9,500	29%		2,755	10	3.58	10	0	0	0	0	0	0	0	7,025	2,550	712	7,025	2,550
TOTAL																			
1991	343,930	0%		0	0	0.00	0	0	0	0	0	0	0	0	0	0	0	0	0
1995	328,569	5%		15,954	2	68	43	12,783	0	12,783	12,783	0	0	0	27,095	1,598	633	52,578	3,296
2000	309,572	22%		69,109	3	41	236	48,644	0	48,644	48,644	0	0	0	140,375	2,031	595	247,338	3,579
2005	293,934	35%		102,334	367	3.59	367	66,466	0	66,466	66,466	0	0	0	221,714	2,167	604	370,597	3,621
2010	278,296	38%		105,034	402	3.82	402	60,904	0	60,904	60,904	0	0	0	247,604	2,357	617	389,147	3,705

SF = Single Family
MH = Manufactured Housing
SH = Space Heat
WH = Water Heat
CFA = Central Forced Air
SD = Service Drop
ME = Main Extension

D.6.0 PROGRAM INTERACTIONS

Estimated peak savings for the following programs are reduced when a fuel switching program is in place.

Residential Weatherization. Fewer households with electric space heat are available for a weatherization program.

Low-Flow Shower Heads. Fuel switching reduces the number of shower heads with electrically heated water.

Water Heat Control. Fuel switching reduces the number of electric water heaters available for a control program.

Time-of-Use Rates. Time-of-use rates affect all end-uses, including electric space heat and water heat. A fuel switching program reduces the amount of electric space heat and water heat load available for time-of-use rates.

Conservation and load management savings are estimated under two scenarios, one with fuel switching and one without. In the fuel switching scenario, appliances that are planned to be switched away from electricity are not available for any other program. For example, savings for water heat control do not include any water heaters that will later switch over to natural gas.

D.6.1 PROGRAM ORDERING

If two or more programs affect an end-use, then the total savings of all the programs combined is less than the sum of all programs taken separately. Savings from one or more of the programs must be decreased to account for the impact of other programs already in place. Conservation and load management programs are assigned an ordering to reduce the number of possible interactive effects. Fuel switching comes first, conservation is next, and load management is last.

Residential Space Heat Ordering

1. Fuel Switching (when present)
2. Weatherization
3. Time-of-Use Rates

If a fuel switching program is in place, that space heat system is not available for any other program. Energy savings for residential weatherization, in terms of annual kilowatt-hours, are based on consumption data from homes without time-of-use rates. Therefore, weatherization is ordered ahead of time-of-use rates.

Residential Water Heat Ordering

1. Fuel Switching (when present)
2. Low Flow Shower Heads
3. Water Heat Control
4. Time-of-Use Rates

As with space heat, fuel switching of electric water heaters is ordered first. Conservation is next and load management programs are last. Water heat control comes ahead of time-of-use rates because water heat control is a larger program in this study.

D.6.2 SIZE OF INTERACTIVE EFFECTS

For each of the conservation and load management programs affected by fuel switching, peak savings with fuel switching are lower than without fuel switching. Estimated peak savings for water heat control are reduced by 30 megawatts, or 8.4%, in the year 2003 with fuel switching in place. Peak savings for time-of-use rates are reduced by 7.2 megawatts or 5.6%. Savings for residential weatherization and low flow shower heads drop by 3.4 and 2.2 megawatts respectively.

Table D.6.1 Fuel Switching Impact on Other Programs
Peak Savings in MW
Extreme Peak Day

		<u>WZSF</u>	<u>LF</u>	<u>WHSF</u>	<u>WHMH</u>	<u>TOU</u>
1996	no FS	27.9	10.3	81.2	4.1	72.9
	with FS	27.4	10.1	79.0	4.1	71.8
2003	no FS	43.3	29.5	291.2	12.5	128.8
	with FS	39.9	27.3	262.4	11.5	121.6
2010	no FS	0.0	28.1	369.9	13.8	132.1
	with FS	0.0	25.6	326.9	12.5	123.0

FS = Fuel Switching
WZSF = Weatherization, Single Family
LF = Low Flow Shower Heads
WHSF = Water Heat Control, Single Family
WHMH = Water Heat Control, Manufactured Homes
TOU = Time-of-Use Rates

D.7.0 HIGH AND LOW LOAD GROWTH

The Long Term Forecasting Section at Bonneville has provided medium growth forecasts for the Puget Sound area by sector and end-use. The high and low forecasts were derived from the medium forecast by scaling the number of households, square feet, or average megawatts up or down. Scaling factors are based on the 1989 regional long-term forecast. Saturation rates, or market shares of electricity, were not changed.

D.7.1 ASSUMPTIONS BY SECTOR

Residential Sector

The medium forecast has household counts for single family, multi-family, and manufactured homes. Scaling factors were calculated for both the high and low cases, but the factors are the same across housing types. Scaling factors are set to 1.0 in 1990 and increase linearly to the year 2010, as shown in Table D.7.1.

Table D.7.1 Residential Scale Factors

	<u>High</u>	<u>Medium</u>	<u>Low</u>
1990	1.000	1.000	1.000
1995	1.071	1.000	0.940
2000	1.142	1.000	0.881
2005	1.213	1.000	0.821
2010	1.284	1.000	0.761

Key figures are the high and low scale factors in 2010. Other factors are linearly interpolated. Data to calculate residential scale factors in the year 2010 are taken from Table 7 in Forecast of Electricity Use in the Pacific Northwest (Bonneville Power Administration and Northwest Power Planning Council 1989, p.24).

$$1.284 = (2.542 + 3.612)/(1.972 + 2.819)$$

$$0.761 = (1.489 + 2.159)/(1.972 + 2.819)$$

Commercial Sector

The medium forecast has two building types, office and non-office. As in the residential sector, the commercial scale factors are the same for each building type. These are shown in Table D.7.2. Units for the commercial sector are thousands of square feet.

Table D.7.2 Commercial Scale Factors

	<u>High</u>	<u>Medium</u>	<u>Low</u>
1990	1.000	1.000	1.000
1995	1.089	1.000	0.942
2000	1.178	1.000	0.885
2005	1.267	1.000	0.827
2010	1.356	1.000	0.769

Data to calculate commercial scale factors in the year 2010 are taken from Table 10 in Forecast of Electricity Use in the Pacific Northwest (Bonneville Power Administration and Northwest Power Planning Council 1989, p.29).

$$1.356 = (1236.2 + 2603.0)/(901.5 + 1929.2)$$

$$0.769 = (694.4 + 1482.1)/(901.5 + 1929.2)$$

Industrial Sector

Because of the wide variety of industrial electric loads, units are average megawatts. The industrial scale factors are shown in Table D.7.3.

Table D.7.3 Industrial Scale Factors

	<u>High</u>	<u>Medium</u>	<u>Low</u>
1990	1.000	1.000	1.000
1995	1.128	1.000	0.933
2000	1.257	1.000	0.865
2005	1.385	1.000	0.798
2010	1.513	1.000	0.730

D.7.2 TABLES

Numbers of households for low, medium, and high load growth are shown in Table D.7.4. Forecasts of commercial floor space are in Table D.7.5. Breakdowns by building type are shown in Tables D.7.5, D.7.6. and D.7.7.

Table D.7.4 Residential Sector Growth Scenarios

	Number of Households		
	<u>Low</u>	<u>Med</u>	<u>High</u>
1990	1,634,916	1,634,916	1,634,916
1991	1,654,756	1,674,769	1,698,551
1992	1,675,208	1,716,226	1,764,967
1993	1,689,513	1,752,334	1,826,984
1994	1,701,805	1,787,234	1,888,749
1995	1,709,138	1,817,749	1,946,809
1996	1,715,387	1,847,880	2,005,319
1997	1,722,009	1,879,204	2,065,997
1998	1,729,363	1,912,166	2,129,388
1999	1,733,933	1,942,891	2,191,193
2000	1,739,666	1,975,771	2,256,330
2001	1,743,300	2,007,138	2,320,653
2002	1,746,896	2,039,337	2,386,840
2003	1,749,377	2,071,127	2,453,457
2004	1,750,558	2,102,267	2,520,198
2005	1,752,418	2,135,142	2,589,928
2006	1,754,147	2,168,826	2,661,584
2007	1,755,320	2,202,824	2,734,585
2008	1,756,447	2,237,798	2,809,779
2009	1,757,201	2,273,369	2,886,724
2010	1,757,509	2,309,473	2,965,363

Table D.7.5 Commercial Sector Growth Scenarios

Thousands of Square Feet			
	<u>Low</u>	<u>Med</u>	<u>High</u>
1990	812,546	812,546	812,546
1991	832,172	841,896	856,881
1992	851,119	871,245	902,262
1993	869,389	900,595	948,687
1994	886,981	929,944	996,156
1995	903,895	959,294	1,044,671
1996	915,014	983,146	1,088,146
1997	925,582	1,006,998	1,132,470
1998	935,599	1,030,850	1,177,643
1999	945,066	1,054,702	1,223,665
2000	953,981	1,078,554	1,270,537
2001	967,919	1,108,791	1,325,892
2002	981,159	1,139,028	1,382,325
2003	993,700	1,169,265	1,439,833
2004	1,005,543	1,199,502	1,498,418
2005	1,016,687	1,229,740	1,558,080
2006	1,027,133	1,259,977	1,618,818
2007	1,036,880	1,290,214	1,680,632
2008	1,045,929	1,320,451	1,743,523
2009	1,054,279	1,350,688	1,807,491
2010	1,061,931	1,380,925	1,872,534

Table D.7.6 Low Growth by Building Type
Puget Sound Area

	Number of Households			Floor Space (000 sq.ft.)	
	<u>Single-Family</u>	<u>Multi-Family</u>	<u>Manu-factured</u>	<u>Office</u>	<u>Non-Office</u>
1990	1,097,667	431,144	106,106	184,682	627,864
1991	1,103,044	443,629	108,083	191,514	640,658
1992	1,108,454	456,222	110,532	198,136	652,983
1993	1,111,167	465,666	112,680	204,549	664,840
1994	1,112,515	474,570	114,720	210,753	676,228
1995	1,111,752	481,741	115,645	216,747	687,148
1996	1,110,824	487,919	116,644	220,393	694,621
1997	1,109,663	494,626	117,720	223,882	701,700
1998	1,109,020	501,387	118,956	227,215	708,385
1999	1,106,624	507,204	120,105	230,391	714,674
2000	1,105,280	512,966	121,420	233,412	720,569
2001	1,102,640	518,168	122,492	238,852	729,068
2002	1,099,666	523,731	123,499	244,067	737,092
2003	1,096,545	528,390	124,442	249,058	744,643
2004	1,092,253	533,075	125,230	253,824	751,719
2005	1,088,614	537,763	126,040	258,365	758,322
2006	1,084,859	542,503	126,785	262,682	764,451
2007	1,080,818	547,038	127,463	266,774	770,106
2008	1,076,883	551,490	128,075	270,642	775,287
2009	1,072,562	556,019	128,620	274,285	779,994
2010	1,067,903	560,507	129,099	277,704	784,228

Table D.7.7 Medium Growth by Building Type
Puget Sound Area

	Number of Households			Floor Space (000 sq.ft.)	
	<u>Single- Family</u>	<u>Multi- Family</u>	<u>Manu- factured</u>	<u>Office</u>	<u>Non- Office</u>
1990	1,097,667	431,144	106,106	184,682	627,864
1991	1,116,385	448,994	109,390	193,752	648,144
1992	1,135,595	467,392	113,238	202,822	668,424
1993	1,152,483	482,981	116,870	211,891	688,703
1994	1,168,362	498,393	120,479	220,961	708,983
1995	1,182,401	512,354	122,994	230,031	729,263
1996	1,196,621	525,605	125,653	236,803	746,343
1997	1,210,959	539,779	128,466	243,575	763,423
1998	1,226,250	554,386	131,531	250,347	780,503
1999	1,239,984	568,328	134,579	257,119	797,583
2000	1,255,287	582,585	137,899	263,891	814,663
2001	1,269,518	596,589	141,031	273,614	835,177
2002	1,283,757	611,406	144,174	283,337	855,691
2003	1,298,224	625,573	147,329	293,061	876,205
2004	1,311,701	640,176	150,390	302,784	896,719
2005	1,326,365	655,210	153,567	312,507	917,233
2006	1,341,319	670,751	156,757	322,230	937,746
2007	1,356,363	686,501	159,959	331,953	958,260
2008	1,372,000	702,624	163,174	341,677	978,774
2009	1,387,621	719,346	166,402	351,400	999,288
2010	1,403,289	736,540	169,644	361,123	1,019,802

Table D.7.8 High Growth by Building Type
Puget Sound Area

	Number of Households			Floor Space (000 sq.ft.)	
	<u>Single- Family</u>	<u>Multi- Family</u>	<u>Manu- factured</u>	<u>Office</u>	<u>Non- Office</u>
1990	1,097,667	431,144	106,106	184,682	627,864
1991	1,132,238	455,370	110,944	197,201	659,681
1992	1,167,846	480,666	116,454	210,042	692,219
1993	1,201,579	503,556	121,849	223,206	725,480
1994	1,234,725	526,702	127,322	236,694	759,463
1995	1,266,351	548,731	131,726	250,504	794,167
1996	1,298,573	570,387	136,359	262,094	826,052
1997	1,331,329	593,433	141,236	273,924	858,546
1998	1,365,552	617,364	146,472	285,996	891,647
1999	1,398,455	640,960	151,778	298,309	925,356
2000	1,433,537	665,312	157,480	310,864	959,673
2001	1,467,817	689,777	163,059	327,188	998,705
2002	1,502,509	715,590	168,741	343,858	1,038,466
2003	1,537,876	741,054	174,526	360,875	1,078,958
2004	1,572,467	767,443	180,288	378,238	1,120,181
2005	1,608,881	794,769	186,277	395,946	1,162,134
2006	1,646,067	823,145	192,372	414,001	1,204,817
2007	1,683,790	852,223	198,573	432,402	1,248,230
2008	1,722,683	882,215	204,881	451,150	1,292,373
2009	1,762,002	913,426	211,297	470,243	1,337,247
2010	1,801,823	945,717	217,823	489,683	1,382,852

D.8.0 REFERENCES

Bonneville Power Administration and Northwest Power Planning Council. 1989. Forecast of Electricity Use in the Pacific Northwest. Portland, Oregon.

Gillman, R.A., R.D. Sands and R.G. Lucas. 1990. "Observations on Residential and Commercial Load Shapes During a Cold Snap." in proceedings of ACEEE 1990 Summer Study on Energy Efficiency in Buildings. Vol. 10, pp. 81-89. American Council for an Energy Efficient Economy, Washington, D.C.

END

**DATE
FILMED**

01/10/92