ELECTRODEPOSITION PROCESS
CONTROL EQUIPMENT

By J. R. Lembke

Published April 1979

Final Report
J. R. Lembke, Project Leader

Project Team:
C. S. Sterrett
A. L. Tindall

Communications Services

**Kansas City
Division**

fy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

ELECTRODEPOSITION PROCESS CONTROL EQUIPMENT

BDX-613-2160 (Rev.), Final Report, Published April 1979

Prepared by J. R. Lembke

A new X-ray fluorescence analysis system was assembled to perform automatic analysis of element ratios in plated alloys. A level-temperature system was developed to provide integrated control of plating tank temperature, liquid level, and filter pump operation. A second generation electroplating control system was developed which incorporates level temperature control, plating fixture motor control, reference-voltage control, and digital display and recording of plating variables.

TWL-jap

This report was prepared as an account of work sponsored by the United States Government. Neither the United States, nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, expressed or implied or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.

**The Bendix Corporation
Kansas City Division
P. O. Box 1159
Kansas City, Missouri 64141**

A prime contractor with the United States
Department of Energy under Contract Number
DE-AC04-76-DP00613

CONTENTS

Section	Page
SUMMARY.	5
DISCUSSION	6
SCOPE AND PURPOSE.	6
ACTIVITY	6
<u>X-Ray Fluorescence Spectroscopy Development.</u>	6
<u>Level-Temperature Control.</u>	8
<u>Plating Control System</u>	12
<u>Inverter Power Source.</u>	15
ACCOMPLISHMENTS.	15
REFERENCE.	17
DISTRIBUTION	18

ILLUSTRATIONS

Figure		Page
1	X-Ray Fluorescence System (P-102741)	7
2	Block Diagram of X-Ray Fluorescence System . .	8
3	Pulse Height Analyzer Display (P-102742) . . .	9
4	Plot of Digitized X-Ray Spectrum	10
5	Level-Temperature Control, PC1006 (P-99853).	11
6	Plating Control System, PC1007 (P-101745). . .	13
7	Inverter Power Source.	16

SUMMARY

The purpose of this project was to improve the reliability of electronic systems used to control and monitor precision electro-deposition processes.

A new X-ray fluorescence analysis system was assembled to perform automatic analysis of element ratios in plated alloys. Information from this system is used to keep the alloy plating operation under control. A programmable calculator converts raw photon-count data to usable alloy ratios, and makes the system independent of external computer support. Software was developed which facilitates data recording, analysis, and printout, and corrects for minor shifts in photon energy calibration, thus eliminating a possible source of error. The reduction in system complexity has resulted in improved reliability with respect to the previous X-ray analysis system.

An equipment system was developed which accomplishes precise integrated control of plating tank temperature, liquid level, and filter pump operation. The system incorporates solid-state relays and integrated-circuit logic elements to achieve optimum reliability and to permit a high degree of coordination between the various controlled functions. Visual and audible alarms and a capability for functional testing are provided. Prototype systems have demonstrated a high level of reliability.

A second generation electroplating control system was developed. This system incorporates level-temperature control, plating fixture motor control, reference-voltage control of plating power, and digital display and chart recording of plating variables. Each major function is housed in an individual module for ease of repair and to permit replacement of defective modules. The modules are located in a single enclosure at the plating tank to optimize the plating operator's access to controls and data displays. The system is self-sufficient, but plating variables can be monitored by a remote computer. Reliability is expected to be greatly improved over previous equipment.

An existing ac power system, which was intended to provide uninterruptible power for extended plating runs, was improved by providing a clean, sheltered environment for the inverter power source. The shelter provides protection from water damage, which had previously caused two power failures and a loss of product in work.

DISCUSSION

SCOPE AND PURPOSE

The goal of this project was to develop improved electronic systems to control and monitor precision electrodeposition processes.

ACTIVITY

X-Ray Fluorescence Spectroscopy Development

A capability for nondestructive measurement of plated alloy composition using X-ray fluorescence spectroscopy was developed previously.¹ The technique involves irradiation of an alloy sample with gamma rays from a cadmium-109 source, detection of the resulting fluorescent X-radiation from the sample, and analysis of the spectrum of this secondary radiation. The spectrum energy peaks are characteristic of the elements in the sample, and the count rate for each peak is proportional to the weight fraction of the corresponding element. Therefore, the spectrum contains the information necessary to compute alloy composition. A detailed description of the measurement theory is given in a previous Bendix report.¹

X-ray fluorescence was successfully applied to the measurement of gold-copper alloy composition and has proven to be fast and accurate for that application. It was, however, subject to equipment reliability problems which limited its availability. For data analysis, the original system was dependent on a general purpose minicomputer, which was a major source of system complexity and reliability problems. At the time this project was initiated, the X-ray detection and spectrum analysis electronics equipment were obsolescent and maintenance parts were difficult to obtain. The resolution of the detector had begun to deteriorate, and its associated liquid nitrogen dewar had exceeded its expected useful lifetime. For these reasons, the major components of the original system were replaced, and a dedicated desktop calculator was substituted for the minicomputer. System complexity was reduced significantly. The new system is illustrated in Figure 1. A block diagram is shown in Figure 2.

As a result of these changes, a major improvement in system reliability was achieved. In 18 months of operation, only two equipment failures have occurred, and in each case the failure

Figure 1. X-Ray Fluorescence System

was corrected within 3 days. This indicates an equipment availability of 99 percent. Previous availability was approximately 50 percent.

In addition to these improvements, the new detector has a resolution of 32.2 aJ (201 eV) compared to 39.7 aJ (248 eV) for the old detector--a 19 percent improvement. (Resolution was measured at full width half maximum (FWHM) of the gold $L\alpha$ peak.) The new pulse height analyzer (PHA), a major system component, provides direct digital readout of counts in any channel or group of channels. This feature facilitates manual computation of alloy ratio if the calculator interface is defective. Figure 3 is a typical PHA spectrum display showing the digital readout.

Figure 2. Block Diagram of X-Ray Fluorescence System

Calculator software was developed to facilitate data recording, analysis, and printout. The programs also correct for minor shifts in X-ray energy calibration, thus eliminating a possible source of error. The calculator records spectrum data on a tape cartridge, and a plot of the spectrum can be generated later for visual analysis. Figure 4 is a spectrum plot-generated in this manner.

The cadmium-109 source has a 453 day half-life, and its original activity of 925 MBq (25 mCi) has decayed to approximately 148 MBq (4 mCi). Even with this relatively weak source, reliable data is produced with 3-minute counting time. A series of 25 measurements on a part with 4.4 weight percent copper resulted in a total spread of ± 0.13 percent copper, or ± 3.0 percent of the nominal value. This is in good agreement with results reported previously. Calculations indicate that essentially all of the uncertainty is caused by the statistical counting error, which represents the theoretical limit of precision.¹

The PHA is now used in a mode which automatically increases counting time as the source decays. When the counting time becomes excessive, the source will be replaced.

Level-Temperature Control

Electroplating processes commonly require heated solutions, pumped filtration, and solution level control. Safety considerations impose requirements for alarms and automatic heater shutdown if abnormal temperature or level conditions occur.

Figure 3. Pulse Height Analyzer Display

The high cost of parts in process and of certain solutions indicates the importance of reliable tank controls.

A level-temperature control (LTC) was developed which integrates the functions of precision temperature control, liquid level control, and filter pump operation. The new control is designated PC1006 and is shown in Figure 5.

The LTC directly controls two immersion type heaters with a maximum total power rating of 2.8 kW. The temperature control point can be set digitally from room temperature to above 90°C in increments of 0.1°C, and solution temperature will be maintained within $\pm 0.1^\circ\text{C}$ (at the sensor). Power is controlled by solid-state relays, and current is turned on and off only at the zero voltage points to minimize the generation of electromagnetic interference (EMI). Heater control capability is adequate for tanks as large as 300 L and for thermally insulated tanks with much larger capacity.

Figure 4. Plot of Digitized X-Ray Spectrum

Figure 5. Level-Temperature Control, PC1006

Liquid level is sensed by electrical conduction through the solution. Three separate probes (and a fourth common probe) permit the LTC to sense low level, normal level, and high level. When the tank solution falls below the normal level, power is applied to two external solenoid valves to add make-up water.

The LTC provides power for two circulation pump motors, each as large as 250 W (1/3 horsepower) rated output power. Circulation pumps are frequently used with filtration systems, but in any case, pumped circulation is necessary to assure uniform temperature in a heated tank.

A temperature limit probe is used to sense abnormally high tank temperature. This signal is used with the low level and high level signals to provide alarm condition response capability. If the tank liquid level falls below the low limit, or if the tank temperature rises above the high limit, all power to the tank is shut off, and the condition is indicated by visible and audible

signals. The abnormal condition must be corrected before operation can be restored; manual action is required. If the tank liquid level rises above the high limit, the condition is indicated by visible and audible signals; however, power remains on. The high level alarm is automatically reset when the condition is corrected.

Integrated-circuit logic elements and solid-state relays were used extensively in the LTC to optimize reliability. In addition, all alarm conditions can be simulated by using controls on the LTC front panel. This facilitates functional checkout of the device at regular intervals and before periods of unattended operation. The most advanced prototype LTC has been in operation 9 months and has experienced no failures.

Plating Control System

The data acquisition and control system (DACS) for an alloy plating process consists of a central console and several utility outlet panels (UOPs), each located at a plating tank. The system provides temperature and level control, plating fixture rotation control, and reference-voltage control of plating power. It also monitors and records various analog signals and alarm conditions. A minicomputer is used to process digitized data records and can control the plating reference voltage.

The DACS has been used successfully to control and monitor alloy plating operations; however, significant problems with hardware reliability were encountered. Also, repairs were found to be difficult and excessively time-consuming. Calibration of analog control and monitoring circuits proved to be difficult because of instabilities associated with the long analog signal cables from the UOPs to the central console. The extension of this system to a new plating facility would have required the use of even longer cables.

In order to obtain the capabilities of DACS with improved reliability and stability, a new plating control system (PCS) was developed. The PCS is located at a plating tank and occupies the same space as a UOP. However, it provides all of the functions necessary to control and monitor an alloy plating process with no support from external equipment.

The PCS is designated PC1007 and consists of six modules (Figure 6). The following is a brief description of these modules.

Motor Control Unit:	Two independent motor controls regulate the speed and the direction of plating fixture rotation motors.

Figure 6. Plating Control System, PC1007

Plating Power Supply:	A dc power supply provides plating current. This unit is operated in the remote voltage programming mode which allows its output to be controlled by the plating control unit.
Chart Recorder:	Plating current, reference voltage, and tank temperature are recorded on a three-channel strip chart.
Level-Temperature Control:	Liquid level, temperature, and circulation are controlled by a module which is functionally identical to the independent level-temperature control described earlier in this report.
Plating Control Unit:	Reference-voltage control of the plating power supply is used to regulate the plated alloy composition. The plating control unit performs this function, and also provides digital displays of plating current, reference voltage, and tank temperature.
Interconnecting Unit:	All other modules communicate with the plating tank through the interconnecting unit. Light-emitting diodes on this unit indicate the status of heaters, pumps, valves, and fixture motors.

Each module is removable for ease of repair and to permit replacement of defective modules. Fans in the top of the PCS cabinet pull in clean conditioned air from near the laboratory ceiling to cool internal components and provide positive pressure in the cabinet. This minimizes entry of moist air from the plating tanks which has caused corrosion problems in the DACS equipment. Reliability is expected to be greatly improved over previous equipment.

Operational simplicity was improved by providing direct display of plating variables at the tank. The number of manual controls was minimized, and the modular design results in a logical arrangement of functional controls.

Although the PCS is self-sufficient, plating variables and alarms can be monitored by a remote computer through a standard RS-232 digital communication channel. A system of these cables has been built into the plating facility.

Inverter Power Source

Uninterrupted power is required for extended plating runs. The major component of the reliable power system is a 7.5 kVA inverter power source (IPS), consisting of a battery charger, battery, inverter, and static transfer switch. Configuration of the IPS is shown in Figure 7.

The IPS was originally installed in the open, above a special plating area, where it was exposed to temperature extremes, dirt, and water leaks from an overhead steam heating system. Two power failures within 2 months were caused by water damage; in both cases valuable parts in process were ruined. Consequently, it was necessary to protect the IPS from the hostile environment.

The system has been enclosed in a waterproof shelter that is supplied with clean, temperature-controlled air flow. A new remote alarm panel in the plating laboratory indicates the status of the major elements of the power system. Also, an improved routine maintenance program has been established. No additional failures of the IPS have been experienced, and it is expected that long-term reliability will be significantly improved as a result of these changes.

ACCOMPLISHMENTS

The following electronic systems to control and monitor precision electroplating processes were successfully developed.

- A new calculator-based X-ray fluorescence analysis system was developed which measures plated alloy ratios with improved reliability.
- Precise reliable control of tank temperature, liquid level, and circulation pump operation was achieved by a new level-temperature control system.
- An advanced plating control system, which provides all tank maintenance features (level, temperature, and pump control), fixture rotation control, and dc plating power, with no support from external devices was developed. Critical parameters are displayed digitally and recorded on strip chart.

Figure 7. Inverter Power Source

- Reliability of an existing ac power system was improved by protecting the inverter power source from environmental hazards.

REFERENCE

¹D. M. Starks, *Determination of Gold-Copper Alloy Composition by X-Ray Fluorescence Analysis (Final Report)*. Bendix Kansas City: BDX-613-1716 (Rev.), September, 1977. (Available From NTIS.)

DISTRIBUTION

	Copy
R. Bulcock, DOE-KCAO	1
H. N. Meyer, Jr., DOE-ALO	2
R. Caudle, DOE-MA, Washington, DC	3
J. A. Freed, LASL	4
S. J. Buginas, LLL	5
E. A. Thompson, LLL	6
H. M. Brinkmeier, Monsanto	7
R. E. Holm, D/100, 1A33	8
D. Finkelstein, D/131, FC39	9
R. L. Johnson, D/131, FC39	10
W. E. Simes, D/131, FC39	11
J. A. Soames, D/131, FC39	12
A. D. Taylor, D/171, 1A31	13
J. E. Long, D/531, 1A46	14
H. T. Barnes, D/554, BD50	15-16
L. Stratton, D/554, 2C44	17-19
C. R. Beary, D/755, 1A42	20
R. P. Frohmberg, D/800, 2A39	21
D. H. Hax/F. A. Spies, D/800, 2A39	22
A. K. Thoeni, D/800, 2A39	23
W. G. Cooper, D/821, 2A36	24
J. R. Lembke, D/821, 2A36	25-30
G. W. McEachen, D/821, 2A36	31
C. S. Sterrett, D/821, 2A36	32
A. L. Tindall, D/821, 2A36	33
D. R. Wachter, D/821, 2A36	34
E. A. Kroencke, D/862, 2D39	35
R. E. Kessler, D/865, 2C40	36