Volume 8
Focused Feasibility Study

January 16, 1991
(Reissued March 1992)

Prepared for
Wright-Patterson Air Force Base
2750 Air Base Wing
Office of Environmental Management

Prepared by
IT Corporation
Cincinnati, Ohio

for Environmental Management Operations
under a Related Services Agreement
with the U.S. Department of Energy

Environmental Management Operations
Richland, Washington 99352

ABSTRACT

The Phase I, Task 5, Focused Feasibility Study (FFS) has been prepared as part of the Environmental Investigation of Ground Water Contamination Project being conducted by Wright-Patterson Air Force Base (WPAFB). The primary objective of this FFS was to select a cost-effective method of preventing migration of contaminated ground water across the southwestern boundary of Area C of the Base. The FFS presented in this document is a portion of a much larger effort being conducted at WPAFB.

The philosophy of this removal action is to take an "observational" approach emphasizing timely implementation of the removal action with the understanding that additional design and modification of the action could be implemented. The collection and analysis of performance data following implementation will facilitate this observational approach.

The removal action objective is to prevent, to the extent practicable, the off-site migration of contaminated ground water from WPAFB across the southwest boundary of Area C. For the purpose of facilitating analysis of the Proposed Removal Action Alternatives (PRAAs) in this FFS, ground water was assumed to require capture if any one of the detected contaminants exceeded its respective drinking water standard (maximum contaminant levels [MCLs]).

The detailed analysis of alternatives for the extraction, treatment, and discharge of contaminated ground water migrating across the southwest boundary of Area C at WPAFB led to the selection of a preferred removal action alternative. Specifically, this alternative is that ground water be extracted utilizing a three well array pumping at a total of 400 to 800 gpm, removed water be treated via air stripping to achieve appropriate effluent concentrations, and treated water be discharged to the Mad River in accordance with a National Pollution Discharge Elimination System (NPDES) permit and other relevant permits.

EXECUTIVE SUMMARY

The Phase I, Task 5, Focused Feasibility Study (FFS) has been prepared as part of the Environmental Investigation of Ground Water Contamination Project being conducted by Wright-Patterson Air Force Base (WPAFB). The primary objective of this FFS was to select a cost-effective method of preventing migration of contaminated ground water across the southwestern boundary of Area C of the Base. The FFS presented in this document is a portion of a much larger effort being conducted at WPAFB.

The philosophy of this removal action is to take an "observational" approach emphasizing timely implementation of the removal action with the understanding that additional design and modification of the action could be implemented. The collection and analysis of performance data following implementation will facilitate this observational approach.

This FFS is Volume 8 in a series prepared for the Investigation and is preceded by a Field Investigation Report (FIR, Volume 5), a Proposed Removal Action Alternatives (PRAAs) Report (Volume 6), and a Technology Plan (Volume 7). This FFS describes the detailed analysis of removal action alternatives (RAAs) and presents the recommended alternative.

NATURE AND EXTENT OF CONTAMINATION

The Mad River Valley aquifer has been designated by the U.S. Environmental Protection Agency (EPA) as a sole-source aquifer for the Base, the cities of Dayton and Fairborn, and area industrial and commercial users. Contaminants (volatile organic compounds [VOCs]) have been detected in water supply wells in Areas B and C of the Base, several water supply wells at Rohrer's Island Well Field (RIWF), and in a well that provides drinking water for the caretaker's cottage near Huffman Dam, west of the Area C boundary of the Base.

The field investigation conducted as part of this study indicates that ground water containing chlorinated solvents is moving across the Area C boundary. Some chlorinated solvents are present in ground water concen-

trations above applicable drinking water standards (maximum contaminant levels [MCLs]).

REMOVAL ACTION OBJECTIVE

The removal action objective is to prevent, to the extent practicable, the off-site migration of contaminated ground water from WPAFB across the southwest boundary of Area C. For the purpose of facilitating analysis of the PRAAs in this FFS, ground water was assumed to require capture if any one of the detected contaminants exceeded its respective drinking water standard (MCLs).

Any removal actions considered must also be compatible with other remedial action objectives under the Base-wide Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) action; be consistent with Ohio and federal laws and regulations; be protective of the health of workers and residents at the Base; and minimize adverse environmental impacts from implementation of the action.

During development of the PRAAs, these removal objectives were addressed through a screening process to identify 23 alternatives. These alternatives included the collection, treatment, and discharge of contaminated ground water. Details of the screening are included in Volume 6.

DETAILED ANALYSIS OF REMOVAL ACTION ALTERNATIVES

Extraction

Hydrogeologic conditions and contaminant distribution dictate that only extraction using wells is an acceptable removal alternative. Several well configuration schemes are feasible, however, to achieve the desired objective.

A numerical model was developed to aid evaluation of alternative extraction schemes. The modeling assessment determined that effective locations for wells to intercept ground water flow from Area C are at the Base fence line west of Landfill Number 5. An effective alternative involves utilization of three extraction wells located in a linear array along the Base boundary.

The anticipated pumping rate is nominally a total of 600 gallons per minute (gpm) and may range between 400 and 800 gpm.

The actual concentration of chlorinated solvents in the extracted ground water cannot be determined at this time. Available data suggest that total concentrations will be a couple hundred micrograms per liter ($\mu\text{g/l}$).

Discharge

Four basic alternatives for discharge were evaluated including 1) aquifer recharge; 2) on-Base nonconsumptive use; 3) off-Base publicly owned treatment works (POTW); and 4) discharge to surface waters. Each alternative was evaluated considering technical feasibility, regulatory requirements, hydrogeologic impacts, institutional/public acceptance, and availability/time to implement. Cost was considered as a secondary factor.

The detailed analysis resulted in elimination of all candidate discharge options except for surface water. On-Base use was technically infeasible. Discharge to a POTW would not be allowed under city ordinance and would represent an unwanted hydraulic load on the system. Aquifer recharge would take too long to implement due to the data collection and analysis required to determine the movement of the contaminants and ground water through the aquifer and also to determine the potential adverse effects that injection of the treated water could have on the aquifer.

Treatment

The treatment goals, or primary effectiveness performance criteria, are to achieve effluent discharge criteria and to meet regulatory BAT requirements. To achieve these goals, five basic treatment technologies were evaluated, including: 1) air stripping, 2) carbon adsorption, 3) air stripping plus carbon adsorption, 4) fixed-film biological treatment, and 5) ultraviolet (UV)/chemical oxidation.

Each treatment alternative was evaluated for effectiveness, implementability, reliability, safety requirements, and cost. Potential pretreatment of the ground water was also considered an important criterion for evaluation of treatment alternatives.

As a result of the comparative evaluation of the technologies, air stripping was identified as the preferred treatment alternative. Air stripping was clearly superior to UV/chemical oxidation and fixed-film biological treatment. The air stripping alternative and carbon adsorption alternative are comparable in most respects except for cost. The closest alternative to air stripping was air stripping plus carbon adsorption. These two alternatives were evaluated essentially as equal except that air stripping plus carbon adsorption is rated higher for reliability and flexibility to changing conditions of flow rate and influent concentrations but is rated lower due to the estimated cost being twice the cost of air stripping alone.

Recommended Removal Action

The detailed analysis of alternatives for the extraction, treatment, and discharge of contaminated ground water migrating across the southwest boundary of Area C at WPAFB led to the selection of a preferred removal action alternative. Specifically, this alternative is that ground water be extracted utilizing a three well array pumping at a total of 400 to 800 gpm, removed water be treated via air stripping to achieve appropriate effluent concentrations, and treated water be discharged to the Mad River in accordance with a National Pollution Discharge Elimination System (NPDES) permit and other relevant permits.

ACRONYMS

<u>Acronym</u>	<u>Definition</u>
AFLC	Air Force Logistics Command
AFSC	Air Force Systems Command
BAT	best available technology
CERCLA	Comprehensive Environmental Response, Compensation, and Liability Act
COI	contaminants of interest
CWA	Clean Water Act
EMO	Battelle Environmental Management Operations
EPA	U.S. Environmental Protection Agency
FFS	focused feasibility study
FIR	Field Investigation Report
GAC	granular activated carbon
gpd/ft ²	gallons per day per square foot
gpm	gallons per minute
IRP	Installation Restoration Program
IT	IT Corporation
L	Liter
MCL	maximum contaminant level
mg	milligram
mgd	million gallons per day
mg/L	milligrams per liter
NPDES	National Pollution Discharge Elimination System

ACRONYMS (cont.)

<u>Acronym</u>	<u>Definition</u>
OEM	Office of Environmental Management
OEPA	Ohio Environmental Protection Agency
PCE	perchloroethylene
POL	petroleum, oils, and lubricants
POTW	publicly owned treatment works
PRAA	proposed removal action alternative
RAA	removal action alternative
RCRA	Resource Conservation and Recovery Act
RI/FS	Remedial Investigation/Feasibility Study
RIWF	Rohrer's Island Well Field
TCE	trichloroethylene
TOC	total organic carbon
TSS	total suspended solids
UIC	Underground Injection Control
UV	ultraviolet
VOC	volatile organic compound
WPAFB	Wright-Patterson Air Force Base
μg/L	micrograms per liter

CONTENTS

SIGNATURE PAGE	ii
ABSTRACT	iii
EXECUTIVE SUMMARY	iv
ACRONYMS	viii
1.0 INTRODUCTION AND SUMMARY OF BACKGROUND INFORMATION	1.1
1.1 PURPOSE AND ORGANIZATION OF REPORT	1.1
1.2 BACKGROUND INFORMATION	1.2
1.2.1 Site Description	1.2
1.2.2 Nature and Extent of Contamination	1.5
2.0 REMOVAL ACTION OBJECTIVE	2.1
2.1 DETECTED VOCs	2.3
2.2 VOLUME OF GROUND WATER REQUIRING REMOVAL	2.3
3.0 IDENTIFICATION AND SCREENING OF TECHNOLOGIES AND ALTERNATIVES	3.1
3.1 SCREENING OF GENERAL RESPONSE ACTIONS	3.1
3.2 IDENTIFICATION AND SCREENING OF TECHNOLOGY TYPES	3.2
3.3 SUMMARY OF DEVELOPMENT OF ALTERNATIVES FOR DETAILED ANALYSIS	3.3
4.0 ANALYSIS OF EXTRACTION ALTERNATIVES	4.1
4.1 NUMERICAL MODELING	4.2
4.2 ANALYSIS OF SELECTED EXTRACTION WELL CONFIGURATIONS	4.5
4.2.1 Single Extraction Well	4.6
4.2.2 Multiple Extraction Wells	4.6

CONTENTS (cont.)

4.3	RECOMMENDED EXTRACTION WELL CONFIGURATION	4.9
4.4	PROJECTED COMPOSITION OF EXTRACTED GROUND WATER	4.10
5.0	ANALYSIS OF DISCHARGE ALTERNATIVES	5.1
5.1	TECHNICAL FEASIBILITY	5.1
5.2	REGULATORY REQUIREMENTS	5.2
5.3	IMPACT ON LOCAL HYDROGEOLOGY	5.3
5.4	INSTITUTIONAL/PUBLIC ACCEPTANCE	5.6
5.5	AVAILABILITY/TIME TO IMPLEMENT	5.6
5.6	SELECTION OF THE PREFERRED DISCHARGE ALTERNATIVE	5.7
6.0	DETAILED ANALYSIS OF TREATMENT ALTERNATIVES	6.1
6.1	BASIS FOR TECHNOLOGY EVALUATION	6.1
6.2	EVALUATION APPROACH	6.2
6.3	PROCESS DESCRIPTIONS	6.4
6.3.1	Pretreatment System	6.4
6.3.2	Treatment Systems	6.6
6.3.2.1	Air Stripper	6.6
6.3.2.2	Carbon Adsorption	6.8
6.3.2.3	Air Stripping and Carbon Adsorption	6.10
6.3.2.4	Fixed-Film Biological Treatment	6.12
6.3.2.5	UV/Chemical Oxidation	6.14
6.4	COMPARATIVE ANALYSIS	6.16
6.4.1	Effectiveness	6.16
6.4.1.1	Likelihood Technology Will Meet Expected Effluent Discharge Criteria	6.16
6.4.1.2	Wastes Produced	6.20
6.4.1.3	Total Degree of Contaminant Destruction	6.21

CONTENTS (cont.)

6.4.2	Implementability	6.21
6.4.2.1	Degree of Availability of Equipment and Technology	6.21
6.4.2.2	Relative Time to Implement	6.22
6.4.2.3	Importance of Conducting Pilot or Laboratory Tests	6.23
6.4.2.4	Degree of Normal Operation and Maintenance Requirements	6.24
6.4.2.5	Special Requirements	6.25
6.4.2.6	Temporary Storage Requirements	6.25
6.4.3	Reliability	6.26
6.4.3.1	Degree of Flexibility Under Changes in Ground Water Characteristics	6.26
6.4.3.2	System Reliability	6.27
6.4.3.3	Monitoring Requirements	6.28
6.4.3.4	Off-Site Disposal or Treatment Requirements	6.29
6.4.4	Safety Requirements	6.29
6.4.4.1	Risk to Workers	6.29
6.4.4.2	Risk to Community	6.30
6.4.5	Cost Comparison	6.30
6.5	SELECTION OF THE PREFERRED TREATMENT ALTERNATIVE	6.31
7.0	PRESENTATION OF RECOMMENDED ALTERNATIVE	7.1
	REFERENCES	R.1
	APPENDIX A - TREATMENT SYSTEM DESIGN DETAILS	A.1
	APPENDIX B - GROUND WATER MODELING DISCUSSION AND RESULTS	B.1

FIGURES

1.1	Area Location Map	1.3
1.2	Wright-Patterson Air Force Base	1.4
4.1	Calibrated Ground Water Model of Area C	4.3
4.2	Calibrated Ground Water Model of Undisturbed Site within Area C	4.4
4.3	Predicted Drawdown for a Single Extraction Well Located Near Monitor Well CW5	4.7
4.4	Predicted Drawdown for Multiple Extraction Wells Located Between Monitor Wells CW4 and CW6	4.8
5.1	Predicted Effects of Multiple Extraction Wells With Discharge of Treated Ground Water to the Mad River	5.4
5.2	Predicted Effects of Multiple Extraction Wells With Distributed Discharge of Treated Ground Water to Twin and Gravel Lakes	5.5
6.1	Pretreatment System Block Flow Diagram	6.5
6.2	Air Stripping Treatment System Block Flow Diagram	6.7
6.3	Carbon Adsorption Treatment System Block Flow Diagram	6.9
6.4	Air Stripping and Carbon Adsorption Treatment System Block Flow Diagram	6.11
6.5	Fixed-Film Biological Treatment System Block Flow Diagram	6.13
6.6	UV/Chemical Oxidation Treatment System Block Flow Diagram	6.15

TABLES

2.1	Volatile Chlorinated Hydrocarbons Above MCLs at WPAFB and Their Respective MCLs	2.2
3.1	List of Proposed Removal Action Alternatives	3.5
4.1	Projected Composition of Extracted Ground Water	4.11
5.1	Comparative Evaluation of Alternatives	6.17
7.1	Recommended Removal Action Alternative	7.2

1.0 INTRODUCTION AND SUMMARY OF BACKGROUND INFORMATION

1.1 PURPOSE AND ORGANIZATION OF REPORT

This Phase 1, Task 5, Focused Feasibility Study (FFS) Report has been prepared for the Office of Environmental Management (OEM) at Wright-Patterson Air Force Base (WPAFB) as part of the Environmental Investigation of Ground Water Contamination Project being conducted at WPAFB. This effort is being performed as part of the Installation Restoration Program (IRP) in accordance with the Administrative Orders on Consent between WPAFB and the Ohio Environmental Protection Agency (OEPA) (OEPA, February 1988). Environmental Management Operations (EMO)^(a) and its principal subcontractor, IT Corporation (IT), were retained by WPAFB to conduct these activities.

The primary objective of Phase I, Task 5 is to select and design a cost-effective method to prevent, to the extent practicable, the migration of contaminated ground water across the southwestern boundary of Area C at WPAFB. This will be achieved by conducting a time-critical removal action. Earlier efforts conducted under Task 5 (Volumes 6 and 7) included development and screening of potential removal action alternatives (PRAAs) and development of a Technology Plan, which provide general background and specific information about established as well as innovative ground water treatment technologies that could be relevant to the removal action objectives. The final effort under Task 5 will be to provide a detailed design and cost analysis for the recommended removal alternative.

The philosophy of this removal action is to take an "observational" approach emphasizing timely implementation of the removal action with the understanding that additional design and modification of the action could be implemented. The collection and analysis of performance data following implementation will facilitate this observational approach.

The purpose of this document is to summarize the results of the detailed analysis of removal action alternatives (RAAs) and to present the recommended alternative. The detailed analysis was performed only for those alternatives

(a) EMO is operated for the U.S. Department of Energy by Battelle Memorial Institute.

remaining after the screening process described in Volume 6. This document provides only a brief summary of the work that preceded the detailed analysis; therefore, the reader is encouraged to review prior volumes to gain a thorough understanding of the events that led to preparation of this volume.

This FFS Report is organized as follows:

- Section 1.0 - Introduction and Summary of Background Information
- Section 2.0 - Removal Action Objective
- Section 3.0 - Identification and Screening of Technologies and Alternatives
- Section 4.0 - Analysis of Extraction Alternatives
- Section 5.0 - Analysis of Discharge Alternatives
- Section 6.0 - Detailed Analysis of Treatment Alternatives
- Section 7.0 - Presentation of Recommended Alternative
- References
- Appendix A - Treatment Systems Design Details
- Appendix B - Ground Water Modeling Discussion and Results

1.2 BACKGROUND INFORMATION

1.2.1 Site Description

WPAFB is located in the southwestern portion of Ohio, 3 miles east of the City of Dayton (Figure 1.1). WPAFB consists of approximately 8,500 acres of land, which contains both an active air field (Patterson Field) and an inactive air field (Wright Field). WPAFB (Figure 1.2) is divided into four areas: 1) Area A, containing the Air Force Logistics Command (AFLC) Headquarters, the Foreign Technology Division of Air Force Systems Command (AFSC), and a number of other administrative and warehouse facilities; 2) Area B, containing the Aeronautical Systems Division of AFSC, the Air Force Institute of Technology, various AFSC laboratories, and the Air Force Museum; 3) Area C, containing the 4950th Test Wing (AFSC); the 906th Tactical Fighter Wing (Ohio Air National Guard); the main petroleum, oils, and lubricants (POL)

FIGURE 1.1. Area Location Map

FIGURE 1.2. Wright-Patterson Air Force Base

storage areas; and other facilities related to the operation of aircraft and the administration of WPAFB personnel; and 4) Kittyhawk Center, containing the Commissary, Main Exchange, WPAFB theater, and other recreational facilities. All four areas are maintained and supported by the 2750th Air Base Wing (AFLC). WPAFB has been in operation since before World War II and has been the site of numerous activities, including flight operations and maintenance, research and development, prototype fabrication, and other industrial operations. Specific site characteristics can be found in the Remedial Investigation/Feasibility Study (RI/FS) Work Plan (Engineering Science, 1989).

1.2.2 Nature and Extent of Contamination

The primary ground water resource at WPAFB is the Mad River Valley aquifer, which underlies most of the site. The Mad River Valley aquifer is designated as a sole source aquifer by the U.S. Environmental Protection Agency (EPA) and is a source of water for WPAFB, the cities of Dayton and Fairborn, and numerous industrial and commercial concerns. Contaminants (primarily volatile organic compounds [VOCs]) have been detected in ground water samples collected from water supply wells in Area C of WPAFB and in a well that provides drinking water for the caretaker's cottage near Huffman Dam, west of the Area C boundary of WPAFB. Ground water samples collected from production wells in Area B and at the northeast corner of the Rohrer's Island Well Field (RIWF) have also contained detectable concentrations of chlorinated solvents.

In September 1990, a limited scope investigation of the hydrogeology and ground water quality of the area along the southwestern boundary of Area C was initiated by WPAFB. The results of this effort, which are documented in Volume 5, indicated that ground water containing elevated levels of VOCs is moving across this boundary. Analyses of water samples collected during the investigation reveal that some of the chlorinated solvents are present in ground water at concentrations above applicable maximum contaminant levels (MCLs) as defined by OEPA and EPA for ground water.

2.0 REMOVAL ACTION OBJECTIVE

The removal action objective is to prevent, to the extent practicable, the off-site migration of contaminated ground water from WPAFB across the southwest boundary of Area C.

This objective was developed by WPAFB in conjunction with the OEPA and is part of the overall goal of the Environmental Investigation of Ground Water Contamination Project. For the purpose of facilitating analysis of the PRAAs in this FFS, ground water is considered to require capture if the concentration of any one of the detected VOCs exceeds its respective MCL (Table 2.1). A detailed discussion of ground water quality near the southwest boundary of Area C is provided in Volume 5.

Any removal actions considered must also meet the following objectives:

- The removal action must be compatible with the eventual Area C remedial action objectives to abate contamination or threats of contamination that adversely affect human health or the environment under the Base-wide Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) action. Contaminants in addition to those listed in Table 2.1 will be addressed during the RI/FS for the Base.
- The removal action must be consistent with current federal and state laws and regulations and the Administrative Orders on Consent between the OEPA and WPAFB, including:
 - The treatment technology must constitute best available technology (BAT).
 - The removal action must meet effluent discharge criteria that would be established by a National Pollutant Discharge Elimination System (NPDES) permit if discharge to surface water is the selected method of discharge.
- The health of workers and residents at and in the vicinity of WPAFB must be protected.
- Adverse environmental impacts resulting from implementation of the removal action must be minimal.

The scope of the FFS is limited to analysis of extraction, treatment, and discharge options for contaminated ground water at the southwest boundary of Area C only. The FFS does not address the identification, elimination, or

**TABLE 2.1. Volatile Chlorinated Hydrocarbons Above MCLs at WPAFB
and Their Respective MCLs**

Parameter	OEPA MCL ^(a) ($\mu\text{g/L}$)	EPA MCL ^(b) ($\mu\text{g/L}$)	Proposed EPA MCL ^(c) ($\mu\text{g/L}$)
Perchloroethylene (PCE)	--	--	5
Trichloroethylene (TCE)	5	5	--
Vinyl chloride (VC)	2	2	--
1,2-Dichloroethylene (DCE)	--	--	7 ^(d)

(a) OAC, Rule 3745-81-12.

(b) 40 CFR 141.

(c) Federal Register 54 FR 22062; May 22, 1989.

(d) Proposed MCL is for cis-1,2-DCE.

control of potential sources that might be contributing to the contamination, nor does it address remediation of contaminated soil. These factors will be addressed during the RI/FS.

2.1 DETECTED VOCs

Based on information in Volume 5, the following nine VOCs were quantified in ground water in the immediate vicinity of or within the capture zone:

- Bromodichloromethane
- 1,1,1-Trichloroethane
- Chloroform
- Chlorobenzene
- 1,2-Dichloroethane
- Trichloroethylene
- Perchloroethylene (tetrachloroethylene)
- Vinyl chloride
- 1,2-Dichloroethylene

Of those nine, the first five were detected at concentrations below their respective MCLs. They will be extracted and treated, but were not considered in performing the detailed analysis or in selecting the suggested RAA. The last four compounds--perchloroethylene (PCE), trichloroethylene (TCE), vinyl chloride (VC), and 1,2-dichloroethylene (DCE)--were detected above their respective MCLs and were used as the basis for the detailed analysis and selection of the suggested RAA. These four compounds are presented in Table 2.1 along with their respective MCLs. For further details on the ground water quality at WPAFB, the reader is directed to Volume 5.

2.2 VOLUME OF GROUND WATER REQUIRING REMOVAL

To prevent ground water with contaminant concentrations above MCLs from migrating across the southwest boundary of Area C, it is estimated that approximately 400 to 800 gallons per minute (gpm) or approximately 0.58 to 1.15 million gallons per day (mgd) of ground water must be extracted. Section 4.0 of this report provides a discussion of the methodology used to estimate the required extraction flow rates.

3.0 IDENTIFICATION AND SCREENING OF TECHNOLOGIES AND ALTERNATIVES

This section summarizes the screening of collection (extraction), treatment, and discharge technology types and process options, as well as residuals management options, performed in Volume 6 that was used to arrive at the list of PRAAs. Prior to that screening, overall screening of general response actions was also done. The results of that screening are also summarized in this section.

3.1 SCREENING OF GENERAL RESPONSE ACTIONS

General response actions that were considered as part of the initial alternative screening process during development of the PRAAs included:

- No action
- Institutional action
- Containment
- Collection (Extraction) and discharge without treatment
- Collection, treatment, and discharge
- In situ treatment.

The apparent ground water flow pattern in the area includes flow from Area C toward the nearby RIWF. This condition, coupled with the fact that contaminant concentrations above MCLs have been detected in ground water in Area C, led to the elimination of the no action alternative.

Institutional actions such as developing an alternative drinking water supply or monitoring the extent of off-Base migration were eliminated as alternatives. EPA has designated the Mad River Valley aquifer as a sole-source aquifer for the cities of Dayton and Fairborn, WPAFB, and Wright State University. This water source cannot be substituted because alternative drinking water supplies are not practically available. Also, simply monitoring ground water quality or migration would not reduce the levels of contamination already detected in the drinking water wells.

Containment was eliminated based on a number of technical factors. The irregularities in the base of the aquifer and the heterogeneous lithology of the aquifer would make successful emplacement of a barrier very difficult. In addition, the effect that stopping all ground water flow from Area C (required

for effective long-term containment) would have on the availability and quality of water being pumped at RIWF cannot be estimated.

The remaining options - collection (extraction) and discharge with and without treatment and in situ treatment - are aimed at reducing the migration of contaminants off the Base property. During the screening process in Volume 6, in situ treatment was eliminated as a viable removal alternative because of the site characteristics and the need for timely implementation. Extraction and discharge with and without treatment were retained for development of PRAAs.

If the reader wishes to have a further explanation of the screening process, Volumes 6 and 7 explain and support the selection of the RAAs that were included in the detailed analysis.

3.2 IDENTIFICATION AND SCREENING OF TECHNOLOGY TYPES

The collection technologies that were considered for ground water removal included extraction wells and subsurface drains. Extraction wells were retained for developing the PRAAs.

Relevant treatment technology types described in Volume 6 were evaluated and screened in two steps. The principal criteria used for retaining treatment options included proven ability to achieve anticipated effluent discharge criteria and availability for timely implementation. The treatment alternatives retained for detailed analysis included:

- Air Stripping
- Carbon Adsorption
- Air Stripping/Carbon Adsorption
- Ultraviolet (UV)/Chemical Oxidation
- Aerobic Fixed-Film Biological Treatment

Potential effluent discharge options were screened in Volume 6. The four remaining options - aquifer recharge, on-Base use, discharge to publicly owned treatment works (POTW), and discharge to surface water - are discussed in Section 5.0.

Implementation of a removal action for contaminated ground water could result in the generation of wastes, including solid residues, liquid residues, and/or emissions. The proper management of these residuals must be considered

when evaluating remedial alternatives. Residuals management options that are potentially applicable for the candidate treatment technologies were determined through a preliminary screening. Secondary treatment operations that could be utilized for management of residuals with the PRAAs include:

- Various physical and chemical treatment technologies to remove iron and other metals from the ground water prior to removal of the contaminants, including:
 - Coagulation/flocculation
 - Media filtration
 - Sedimentation/settling
 - Neutralization
 - Precipitation
 - Chelation
 - Ion exchange.
- Vapor-phase carbon treatment of air stripper off-gas (with or without in situ steam regeneration of the spent carbon)
- Distillation or UV/chemical oxidation to treat any concentrated liquid wastes resulting from on-site regeneration of vapor- or liquid-phase carbon
- Vapor-phase carbon treatment of process vent emissions from chemical oxidation or biological treatment.
- Incineration (thermal or catalytic) of air stripper off-gas.

These options were evaluated during the detailed analysis, and the results are included in Section 6.0.

3.3 SUMMARY OF DEVELOPMENT OF ALTERNATIVES FOR DETAILED ANALYSIS

The results of the screening process summarized in Section 3.2 were used to develop the PRAAs that were subjected to detailed analysis. The selected technologies for the collection, treatment, and discharge components of the selected general response actions are summarized below:

- Collection
 - Extraction (wells)
- Primary treatment
 - Carbon adsorption

- Air stripping
- Combination of air stripping and carbon adsorption
- UV/chemical oxidation
- Biological treatment (aerobic fixed-film reactor)
- Discharge
 - Aquifer recharge
 - On-Base use (nonconsumptive)
 - Surface water
 - Off-Base POTW

These components were compiled into the list of PRAAs shown in Table 3.1. Each treatment technology was combined with each discharge option resulting in the first 20 alternatives. The remaining three alternatives involve only collection and discharge. The alternative of extraction and aquifer recharge without treatment was not included because it would not effectively change the current situation.

The approach used in this FFS to perform the detailed analysis of the above alternatives was to consider each of the three components - extraction, discharge, and treatment - separately in the next three sections. There is only one viable extraction option (i.e., extraction wells) as described in Section 4.0. The discharge alternatives were analyzed in Section 5.0. The various treatment alternatives were subjected to detailed analysis in Section 6.0. After all independent analysis, the three components were recombined in Section 7.0 for the presentation of the preferred RAA.

TABLE 3.1. List of Proposed Removal Action Alternatives

Alternative	Collection	Removal	Discharge
1	Extraction (Wells)	Carbon Adsorption	Aquifer Recharge
2	Extraction (Wells)	Biological Treatment	Aquifer Recharge
3	Extraction (Wells)	Air Stripping	Aquifer Recharge
4	Extraction (Wells)	UV/Chemical Oxidation	Aquifer Recharge
5	Extraction (Wells)	Stripping, Adsorption	Aquifer Recharge
6	Extraction (Wells)	Carbon Adsorption	On-Base Use
7	Extraction (Wells)	Biological Treatment	On-Base Use
8	Extraction (Wells)	Air Stripping	On-Base Use
9	Extraction (Wells)	UV/Chemical Oxidation	On-Base Use
10	Extraction (Wells)	Stripping, Adsorption	On-Base Use
11	Extraction (Wells)	Carbon Adsorption	Surface Water
12	Extraction (Wells)	Biological Treatment	Surface Water
13	Extraction (Wells)	Air Stripping	Surface Water
14	Extraction (Wells)	UV/Chemical Oxidation	Surface Water
15	Extraction (Wells)	Stripping, Adsorption	Surface Water
16	Extraction (Wells)	Carbon Adsorption	Off-Base POTW
17	Extraction (Wells)	Biological Treatment	Off-Base POTW
18	Extraction (Wells)	Air Stripping	Off-Base POTW
19	Extraction (Wells)	UV/Chemical Oxidation	Off-Base POTW
20	Extraction (Wells)	Stripping, Adsorption	Off-Base POTW
21	Extraction (Wells)	None	On-Base Use
22	Extraction (Wells)	None	Surface Water
23	Extraction (Wells)	None	Off-Base POTW

4.0 ANALYSIS OF EXTRACTION ALTERNATIVES

The development and analysis of extraction alternatives was based on the removal action objective of preventing contaminated ground water along the southwestern boundary of Area C from migrating off WPAFB property. The analysis was supported with numerical computer simulations as documented in Appendix B (under separate cover as Part II of this volume). Several assumptions were used in proposing a conceptual model of the hydrogeology and establishing modeling goals; they most notably include:

- The regional potentiometric surface map for March 1988 represents the current conditions in the Mad River Valley Aquifer. These data, which were collected prior to the 1988 drought, represent the most recent and comprehensive collection of base-wide potentiometric conditions. (Personal communication, Miami Conservancy District.)
- The Mad River upstream of the Huffman Dam and in the vicinity of WPAFB is a gaining stream. (Personal communication, U.S.G.S.) Regional potentiometric contours in the vicinity of Mad River suggest discharge to the river in this area.
- Porous flow equivalents are valid for characterizing flow in sand and gravel aquifers. The vertical hydraulic conductivity was assumed to be 10 percent of the horizontal hydraulic conductivity for the calculations; however, significant differences in actual versus theoretical drawdown could occur due to the lack of site-specific data.
- Based on the lower hydraulic conductivity of the bedrock relative to the glacial deposits, the bedrock boundaries surrounding the sand and gravel Mad River Valley Aquifer are "no flow" boundaries.
- The subsurface cross sectional area bounding VOC migration off WPAFB property downgradient of Landfill Number 5 adjacent to the southwestern boundary of Area C is essentially contained between Well Clusters CW4 and CW6 (Plate 5-2, Volume 5). This assumption is based on the interpreted horizontal and vertical extent of the VOCs as obtained from ground water sample data for well clusters CW4, CW5, and CW6.
- Interception of ground water flow off WPAFB property should be implemented with a view toward minimizing water level impacts on Twin Lakes and Gravel Lake (to minimize impacting recreational activities), and the Mad River (to limit the amount of water being captured).

4.1 NUMERICAL MODELING

A numerical ground water model was developed using the GWFL3D code (Walton, 1989) to aid in the evaluation of extraction alternatives. The code is an interactive version of PLASM (Prickett and Lonquist, 1971) documented by the Illinois State Water Survey. A more detailed description of the numerical model, including a hard copy of baseline input and output files, is contained in Appendix B. This appendix presents the results of two modeling efforts: a regional (Area C) model and a local (site-specific) model.

The Area C model was initially calibrated to potentiometric contours in the Mad River Valley above Huffman Dam, as shown in Figure 4.1, that were obtained from existing data. Interpreted potentiometric contours based on March 1988 potentiometric data and Area C water level measurements from September 1990 were used to interrelate calibration of the Area C and site-specific models. It was necessary to use two different sets of data to calibrate the site model and the Area C model due to data availability. Only regional potentiometric surfaces interpreted from water level measurements, compiled by Engineering Science (1989), were available for the regional model. Well point data for September 1990 (Volume 5) were available for Area C, so those data formed the basis for calibration of the local model.

The bedrock boundaries surrounding the Mad River Valley Aquifer are shown as no flow boundaries. The Area C model helped to identify boundary conditions for an undisturbed site-specific model within Area C as shown in Figure 4.2. Because of the lack of data on hydraulic properties for the aquifer and lake bottoms and uncertainties on the ground water/surface water interface, the projected water table in the vicinity of the lakes is dashed. Wells CW4 through CW8 and the WPAFB fence line are shown in the figures for reference purposes. Calibration of the ground water model is discussed in Appendix B. The saturated horizontal hydraulic conductivity of the site-specific model in the vicinity of the WPAFB fence line was 700 gallons per day per square foot (gpd/ft²) with a lower hydraulic conductivity zone of 300 gpd/ft² passing through Landfill Number 5.

FIGURE 4.1. Calibrated Ground Water Model of Area C

FIGURE 4.2. Calibrated Ground Water Model of Undisturbed Site Within Area C

A brief sensitivity analysis was performed to observe the effects of major hydraulic conductivity changes on the calibrated potentiometric contours. The sensitivity analysis consisted of two computer runs: in the first run, the hydraulic conductivity beneath the landfill was reduced from 300 to 30 gpd/ft²; in the second run, the hydraulic conductivity near the fence line was reduced from 700 to 100 gpd/ft². For both runs, the lower conductivities extended the drawdown cones projected for the extraction wells. A more complete description of the sensitivity analysis can be found in Appendix B.

4.2 ANALYSIS OF SELECTED EXTRACTION WELL CONFIGURATIONS

The most logical location for wells to intercept subsurface flow in Area C is west of Landfill Number 5 and east of the WPAFB fence line. This location is still within Area C and would provide for interception of the contaminants upgradient of the Base boundary. An interpretation of the vertical distribution of the VOCs in ground water is shown on the north-south section of Plate 6.12 (Volume 5). The highest concentration of VOCs occurs at Well Cluster CW5 with a shallow presence at Well Cluster CW4 and a deep presence at Well Cluster CW6. The maximum horizontal distance between estimated nondetect levels of the VOCs is approximately 1,000 feet, based on inspection of Plate 6.12 in Volume 5 (F.I.R.).

Another computer code, PT1, which is useful for the design and analysis of pumping tests (Walton, 1987), was applied to the calculation of water table drawdown at selected radial distances from the location of the pumping well. The purpose of this analysis was to adjust the pumping rate so that a water table drawdown in excess of 1 foot could be obtained over the approximately 1,000-foot horizontal extent of the postulated VOC plume. Two pumping schemes were evaluated: 1) a single well pumping at a rate of 600 gpm, and 2) three wells pumping at 200 gpm each. An infinite number of pumping scenarios are available; however, the single and three well scenarios are viable and thought to be generally representative of the available scenarios. The selection of these scenarios was based on professional judgement and experience and considered reasonable with respect to cost, time required for implementation, and effectiveness. However, the reader should be cautioned that due to the

lack of hydraulic characterization for the site, actual drawdowns may vary from those predicted by this modeling effort.

4.2.1 Single Extraction Well

Predicted steady-state drawdowns for a single pumping well located near Well Cluster CW5 are shown in Figure 4.3. The well is pumped at 600 gpm with a drawdown of approximately 20 feet at the wellhead. The water table contour at a closed elevation of 777 feet (Figure 4.3) contains the estimated nondetect limits of the VOC plume. The predictions include a uniform consideration of 7.5 inches of yearly recharge (Fidler, 1975).

Modeling this pumping scheme using the calibrated ground water model suggests less than a 1-foot reduction in water table elevation (relative to the undisturbed conditions shown in Figure 4.2) in the vicinity of Twin Lakes and virtually no effect on Gravel Lake. The interconnection of these lakes by surface water channels would tend to further reduce the effects of ground water pumping on lake water levels. Because site-specific data on hydraulic conductivity in the vicinity of the extraction wells and lakes, including information on lake bottom materials and hydraulic connection of the lakes and ground water, is lacking, the uncertainty surrounding these drawdown predictions is high.

The Mad River downstream of Landfill Number 5 and upstream of Huffman Dam is believed to be a gaining stream receiving ground water discharge from the aquifer. The extraction well(s) would intercept ground water flow contributing to the average annual flow of the Mad River. If approximately 1 mgd were intercepted by the well(s) and the ground water was not returned to the natural system (i.e., injected into the aquifer or discharged to the Mad River), a simple water balance calculation suggests that the average annual river flow would be reduced by approximately 1 mgd. This reduction in flow is less than 1 percent of the average annual flow of the Mad River and would not be detectable.

4.2.2 Multiple Extraction Wells

Predicted steady-state drawdowns for three fully penetrating pumping wells located between Monitor Well Clusters CW4 and CW6 are shown in Figure 4.4. The three-well configuration is placed to intercept the interpreted

FIGURE 4.3. Predicted Drawdown for a Single Extraction Well Located Near Monitor Well CW5

FIGURE 4.4. Predicted Drawdown for Multiple Extraction Wells Located Between Monitor Wells CW4 and CW6

vertical distribution of VOCs. In modelling the steady-state drawdowns, the hydraulic conductivity was assumed to vary spatially in the horizontal direction from 300 gpd/ft² to 1,500 gpd/ft², and in the vertical direction at a value of at least 10 percent of the horizontal value. A sensitivity analysis was also run as discussed in Appendix B. Each well is pumped at 200 gpm with drawdown ranging from 6 to 25 feet at the wellheads, depending on hydraulic conductivity and well diameter. The cone of depression surrounding the three pumping wells is elongated for more effective interception of subsurface flow from the WPAFB property. The three wells contribute additive drawdown (interference) at each wellhead.

Based on the predicted steady-state drawdown, multiple extraction wells at a total pumping rate of 600 gpm will have minimal reduction in water table elevations in the vicinity of Twin Lakes. As with the single well, a potential reduction of less than 1 mgd in an average river flow rate of 440 mgd would not be detectable (i.e., less than 1 percent of the average annual Mad River flow).

4.3 RECOMMENDED EXTRACTION WELL CONFIGURATION

The cost of multiple extraction wells will be higher than the cost for a single well; however, three extraction wells are recommended for the following reasons:

- To provide more effective control of contaminant migration across the Base boundary
- To provide flexibility in the final design
- To be consistent with a phased installation
- To obtain continued partial operation during periods of pump maintenance or failure.

The anticipated pumping rate is nominally 600 gpm and may range between 400 and 800 gpm. The hydrologic data suggest that the entire aquifer thickness (65 to 70 feet) should be screened, and that the pump intake be set at the bottom of the screen.

The three-well scheme is an installation strategy that allows for a rapid interception of the zone of highest VOC concentration while gathering

additional hydraulic properties for the final design and siting of the other two extraction wells. If the first extraction well was placed near Well Cluster CW5, ground water containing the VOCs could be pumped into a treatment system and the water levels at surrounding monitoring wells could be observed and analyzed to obtain local values for transmissivity, hydraulic conductivity, and storage coefficient. With the improved data base, the location and design of any additional wells necessary to capture the desired amount of ground water would be more consistent with site-specific parameters. This is consistent with the "observational" approach adopted for this removal action.

4.4 PROJECTED COMPOSITION OF EXTRACTED GROUND WATER

Using the water quality data provided in Volume 5 and the anticipated flow interception area, an estimate of the extracted ground water composition was made. This estimate was developed by establishing two-dimensional isoconcentration zones around wells for which the most recent and reliable ground water quality data are available (see Volume 5) and within the anticipated zone of capture of the extraction wells. The concentration values were weighted proportionately with the areas within the zones and the weighted average of all zones was computed. Reflecting the level of precision of this process, the resulting averages in Table 4.1 were developed. This process, which was primarily qualitative, did not include variations in concentration with depth to determine the weighted average because the available data were insufficient to define three-dimensional isoconcentration profiles.

Reference should be made to Volume 5 to understand the range of values that were detected in the subject wells. The actual composition of extracted ground water, particularly the VOCs, cannot be established until the completion of the phased implementation and adjustment of the three-well extraction system.

TABLE 4.1. Projected Composition of Extracted Ground Water

Inorganic and General Parameters	Influent Concentration mg/L
Calcium	150
Iron	30 ^(a)
Magnesium	50
Manganese	0.9
Potassium	3
Sodium	15
Chloride	35
Sulfate	130
Alkalinity	470
pH	7.3
Total Dissolved Solids (TDS)	500
Total Organic Carbon (TOC)	15
Hardness	430
Organic Parameters	Influent Concentrations μg/L
Total VOCs	220
TCE	210
PCE, VC, DCE, and Others ^(b)	10

(a) Single data point from Cluster Well CW8.

(b) Others include 1,1,1-trichloroethane, chloroform, chlorobenzene, 1,2-dichloroethane, and bromodichloromethane.

5.0 ANALYSIS OF DISCHARGE ALTERNATIVES

Discharge alternatives that were subjected to detailed analysis include:

- Aquifer recharge
- On-Base nonconsumptive use
- Off-Base POTW
- Surface water - including four options - Twin and/or Gravel Lakes, Hebble Creek, Trout Run, and the Mad River.

These alternatives are described in Volume 6. The criteria that were considered during this detailed analysis include:

- Technical feasibility
- Regulatory requirements
- Impact on local hydrogeology conditions
- Institutional/public acceptance
- Availability/time to implement.

Cost was also considered as a secondary factor. Each of the four alternatives are discussed relative to these criteria, and the preferred alternative is identified. The last three options were addressed as they might apply to both untreated and treated water because treatment and no treatment were both retained after the initial screening of alternatives summarized in Section 3.0 of this report.

5.1 TECHNICAL FEASIBILITY

All options are technically feasible except on-Base use. According to WPAFB OEM staff, there is insufficient nonconsumptive demand to utilize the nearly 1 mgd of treated ground water, and there is no separate water distribution system for nonconsumptive use. Even if the water could be utilized, significant cost would be incurred to modify the distribution system to separate the nonconsumptive from the consumptive uses and to route the effluent the long distance from the treatment system to the usage point.

There are no technical limitations as to why the water discharge from the treatment system could not be routed to any of the surface water bodies in the area, to a possible reinjection point, or to the POTW sewer. All of these

options appear feasible because of their relative location to the treatment system and the ability to install the transfer piping to them.

5.2 REGULATORY REQUIREMENTS

Based on the VOC ground water concentrations presented in Volume 5 and the projected composition of the extracted ground water described in Section 4.0 of this report, the alternative of discharging without treatment to surface water was eliminated from further consideration because it would not fulfill BAT as required by Section 301(b) of the CWA, for CERCLA sites.

Discharge to the POTW is prohibited under the City of Dayton's Revised Code of General Ordinance, Ordinance No. 27173, Section 5-G. Per this ordinance, no ground water or surface water runoff is allowed to be discharged to the city sewer system. This ordinance does, however, contain a provision (depending on the circumstances) for allowing emergency discharge of ground water or surface water. The potential for employing this provision in the event of failure of the proposed ground water treatment system will be addressed as part of the process design phase of this removal action.

For the remaining discharge options - recharge to the aquifer and surface water discharge - effluent discharge criteria would be established based on the projected impact of the discharge on receiving water quality and use. No attempt was made as part of this FFS to determine acceptable effluent concentrations for the discharge to either the aquifer or surface water. Effluent discharge limits will be determined by the OEPA Division of Wastewater Pollution Control as part of the permitting process for the selected discharge option. The various permits required for a surface water discharge include a NPDES permit, two permits to install (PTI) (for water and air), and an air permit. For aquifer recharge, reinjection into the aquifer would require permitting by OEPA's Underground Injection Control (UIC) program per OAC 3745-34, in lieu of the NPDES permit for surface water discharge.

5.3 IMPACT ON LOCAL HYDROGEOLOGY

The calibrated ground water model for Area C was used to investigate the effects of treated ground water discharge to local surface water bodies. Discharge by reinjection to the aquifer was not modeled because existing water quality data are insufficient to determine the optimal location(s) for the injection well(s). The time necessary to gather the additional data is not consistent with the time-critical nature of the removal action.

Figure 5.1 shows the predicted water table contours for three receptor wells pumping at a total of 600 gpm (200 gpm each) with the treated discharge returned to the Mad River. This option maintains the water balance of the surface and ground water system. Because of the lack of data on hydraulic properties for the aquifer and lake bottoms, the projected water table in the vicinity of the lakes is dashed.

The effects of discharging the treated ground water to the Twin and Gravel Lakes are shown in Figure 5.2. The amount of water distributed to each lake is based on the respective surface area. This option was numerically simulated in the ground water model using multiple injection wells placed at grid nodes associated with the appropriate lake. The projected steady-state effect of the discharge is to raise the level of the lake surface elevations approximately 2 to 4 feet. The effect of increasing lake elevations is to locally recharge the ground water system beneath the lakes. This, in turn, impacts the extraction of ground water by skewing the capture zone of the extraction wells toward the Twin Lakes and lowering the amount of drawdown due to pumping.

A detailed analysis (e.g., numerical modeling) of discharge to Hebble Creek and Trout Run was not conducted because the necessary information, such as surface water elevations and the potential for surface runoff from the lakes, were not available. However, it can be concluded that these options maintain the water balance of the surface and ground water system by returning water to the natural system. Discharge to Hebble Creek and Trout Run, which are small receiving streams, would not be as acceptable as discharge to a larger stream (i.e., Mad River) due to the limited assimilative capacity of

FIGURE 5.1. Predicted Effects of Multiple Extraction Wells with Discharge of Treated Ground Water to the Mad River

FIGURE 5.2. Predicted Effects of Multiple Extraction Wells with Disturbed Discharge of Treated Ground Water to Twin and Gravel Lakes

these smaller streams for the type of contaminants and the flow rate from the treatment system.

The effects of discharging the treated ground water to a POTW would not maintain the water balance of the surface and ground water system. However, the reduction of approximately 1 mgd from the water balance should have impacts detectable only in the immediate vicinity of the extraction wells. The reduction of less than 1 mgd from an average flow rate of 440 mgd in the Mad River would not be detectable.

5.4 INSTITUTIONAL/PUBLIC ACCEPTANCE

Reinjection of contaminated ground water to an aquifer that is used for drinking water, even if effective treatment is employed, may raise concerns by the public who rely on this water supply. However, the degree of acceptability of reinjection cannot be ascertained without additional community relations efforts with the public.

Discharge of treated water to the Twin Lakes or Gravel Lake poses potential advantages and disadvantages. Improvements to overall water quality may result, particularly in the summer, as a result of higher influent flow rate (and resulting turnover and oxygenation) of these water bodies. These lakes are part of a recreational area established by WPAFB for use by current and retired U.S. Air Force personnel. Improvement in the condition of these lakes would be advantageous from this perspective. On the other hand, the use of these lakes and their relatively small volume increases the potential liability posed by discharging effluent that has not been adequately treated, such as could occur from a major system and/or operational failure. The degree of acceptability of discharge to the lakes cannot be ascertained without additional community relations efforts with WPAFB staff and users of the property.

5.5 AVAILABILITY/TIME TO IMPLEMENT

As part of the permitting process for injection wells, data collection and analysis will be necessary to assess the movement of the contaminants and ground water through the aquifer and the potential adverse effects that

reinjection of treated water into the aquifer may have on overall aquifer water quality and movement. The time required to conduct these studies and adequately design this alternative for this time-critical removal action is not available; thus, this discharge option is not considered a viable alternative with low risk.

The time required to implement the various surface water discharge options will depend on obtaining a NPDES permit, as well as confirming the specific discharge and outfall locations. The time to design and install the discharge system (transfer pumps, piping, and outfall structure) could impact the overall implementation schedule of the selected removal action; this time requirement would vary somewhat with the discharge and outfall location.

5.6 SELECTION OF THE PREFERRED DISCHARGE ALTERNATIVE

The detailed analysis resulted in elimination of all the candidate discharge options except for surface water. On-Base use was technically infeasible. Discharge to a POTW is not permitted and would represent an unwanted hydraulic burden. Aquifer recharge would require lengthy pre-implementation studies. Of the four candidate surface water discharge options, the Mad River is considered the preferred option based on institutional/public acceptance and hydraulic capacity considerations, even though costs may be higher for this option depending on outfall location.

6.0 DETAILED ANALYSIS OF TREATMENT ALTERNATIVES

This section analyzes each of the candidate ground water treatment alternatives identified in Section 3.0. Following a definition of the design bases and approach used to conduct this detailed analysis, process descriptions of each candidate treatment alternative are presented. The principal element of this section is the comparative analysis of the treatment alternatives using a comprehensive list of evaluation criteria. This comparative analysis leads to the selection of a preferred treatment alternative.

6.1 BASIS FOR TECHNOLOGY EVALUATION

The projected ground water flow rate and composition to be treated was noted in Section 4.0. The key influent characteristics that were used for the detailed analysis of the treatment alternatives are:

- Flow rate 600 gpm
- TCE influent concentration 210 micrograms per liter ($\mu\text{g/L}$)
- Total influent VOCs 220 $\mu\text{g/L}$
- Total organic carbon (TOC) 15 milligrams per liter (mg/L)
- Total iron 30 mg/L .

Evaluation parameters or criteria used in the detailed analysis are identified and described in Section 6.2. Considering the proposed phased implementation strategy for the extraction system discussed in Section 4.0 and the potential variability in flow rate and composition during the lifetime of this removal action, consideration was given in the analysis to the impact on the treatment alternatives of deviation from the above values. The treatment goal, or primary effectiveness performance criterion, was to achieve the anticipated effluent criteria for the treated water.

6.2 EVALUATION APPROACH

The descriptions and evaluations of treatment alternatives were done using guidance provided in Attachment 12 (Statement of Work, RI/FS) of the Consent Order (OEPA, February 1988). This guidance is intended for the complete RI/FS at WPAFB, and, as such, only the portions that were considered appropriate were used in preparing this FFS. Information was developed to address the specific issues/topics identified under Task 12.a. (Detailed Description), Task 12.c. (Cost Analysis), and Task 13 (Evaluation and Selection of Preferred Alternative) of Attachment 12; Task 12.b. (Environmental Assessment) was not addressed during this FFS.

To address many of these issues/topics, a preliminary process design was defined for each treatment alternative. Each design is based on a particular process that is representative for each technology. This representative process is used for evaluation purposes. The specific process configuration that will be developed during the final process design may not necessarily be the same as the representative process evaluated herein.

For each alternative, a process description including a block flow diagram is included in this section to identify the individual unit operations and the material flows entering and leaving each system. In addition, a preliminary process flow diagram and equipment list with major items defined were developed for each alternative; these are included in Appendix A. This degree of process design was necessary to quantify certain evaluation criteria, such as waste volume produced, as well as to generate reasonable estimates of the relative cost of each alternative.

In defining each treatment alternative, a pretreatment process was included because it was determined early in the detailed analysis (see later portions of this section, in particular 6.4.2.3) that elevated iron concentrations could hinder satisfactory performance of the candidate technologies. The likelihood for such pretreatment was indicated in Volume 6. Removal or other control techniques, such as chelation, for iron is a typical requirement for treatment of contaminated ground water depending on the type of treatment technology and specific process used.

Because the required degree of iron removal was considered similar for the treatment alternatives and associated representative treatment processes, a common pretreatment process was assumed for conducting this detailed analysis. The pretreatment system that was selected for this detailed analysis utilizes conventional technology and is considered appropriate for this ground water application. A description of the pretreatment process is included in Section 6.3.1.

If a treatment process other than the representative process used for this detailed analysis is developed in the process design phase, pretreatment requirements may be different. Additional assessment of the need for and type of pretreatment will be made early in the process design phase and the necessary pretreatment will be incorporated into the process design.

The interfaces between (i.e., physical systems to connect) the treatment system and the extraction wells and discharge points were also considered in the detailed analysis. A major component of each interface system is storage to allow steady-state operation of the treatment system and accommodate upset conditions, equipment failure, or startup. For the purposes of the detailed analysis, interface requirements for the treatment alternatives were considered similar; common systems for extraction and discharge were assumed for conducting the analysis. Preliminary definitions of these interfaces are provided in the process flow diagrams for the extraction and discharge systems included in Appendix A. These systems will be addressed in more detail as part of the process design phase.

The comparative analysis of the treatment alternatives was performed using the following five general evaluation criteria:

- Effectiveness
- Implementability
- Reliability
- Safety Requirements
- Cost.

Specific criteria, factors, or issues were established for each of the general criterion listed above to enable an objective, consistent, and comprehensive examination of the treatment alternatives. Some of these specific criteria were identified in Attachment 12 of the Consent Order, and others were derived

from EPA guidance for conducting the detailed analysis for standard CERCLA feasibility studies. Only those specific criteria that were particularly relevant to the PRAAs were considered. Because the alternatives are similar in that they involve treatment of extracted ground water, certain CERCLA criteria normally used for evaluating general remedial alternatives were considered too broad to result in distinctions between alternatives or were not relevant to this detailed analysis.

6.3 PROCESS DESCRIPTIONS

6.3.1 Pretreatment System

The ground water chemistry data reported in Volume 5 indicate potential adverse effects on the treatment technologies being considered. For purposes of defining pretreatment requirements to remove iron, an iron concentration of 30 mg/l was used. This iron concentration will be refined during the process design through additional sampling and testing. A block flow diagram of the pretreatment system that was used for performing this detailed analysis of treatment alternatives is shown in Figure 6.1. The process flow diagram is included in Appendix A.

The proposed pretreatment system uses conventional oxidation/precipitation technology. Ground water from the extraction system will first pass through an aeration tank. Air sparged into the water serves as an oxidant to convert ferrous iron to ferric iron, resulting in precipitation of the iron as an insoluble hydroxide. Caustic solution may be added to the aeration tank feed stream to enhance oxidation rates. After passing through the water in the aeration tank, the air will be collected and treated, if necessary, via vapor-phase carbon adsorption or fume incineration to remove any volatilized contaminants before the air is discharged to the atmosphere. The aerated water containing precipitated iron particulate will overflow into a flocculation tank. A flocculent such as alum and/or a polymer will be used as necessary to improve solids settling properties. The water and suspended solids will then overflow into a clarifier. The clarifier underflow will be transferred to a separate sludge storage tank that will be emptied by

STARTING DATE: 12/07/90	DRAWN BY: T.HENDRICKSON	PROJECT MGR. J.REGISTER	DRAWING NO. 188514-B04
DATE LAST REV. 06-14-91	INITIATOR T KOVALCSON	PROJECT NO. 188514

Note: Dashed Lines Indicate a Stream/Unit Operation May Be Required.

FIGURE 6.1. Pretreatment System Block Flow Diagram

dewatering the sludge using a filter press. The water removed by the filter press will be recycled to the flocculation tank. The pH of the water overflowing from the clarifier, if necessary, will be adjusted to a neutral value prior to being pumped through polishing filters to remove any residual suspended solids.

The dewatered iron sludge and spent filter media will be containerized and transferred to temporary storage until periodic shipment to off-site disposal. Pretreated water will be collected in a storage tank from which it will be continuously pumped to the treatment system.

6.3.2 Treatment Systems

6.3.2.1 Air Stripper

Air stripping is a commonly used method for removal of VOCs from water. Air stripping is a mass transfer process that promotes the transfer of dissolved VOCs from the bulk liquid into the gas phase. The VOCs in the liquid phase will transfer to the gas phase provided that an adequate supply of uncontaminated air is contacted thoroughly with the liquid. For a detailed description of various process configurations, the reader is referred to Volume 7.

The specific process used in this detailed analysis as representative of air stripping technology was the conventional packed countercurrent stripping column. A block flow diagram of the air stripper system is shown in Figure 6.2 and the process flow diagram is included in Appendix A. The choice of a packed column as a representative process for air stripping was based on its common use and efficiency. Other process options would generally be comparable for the purposes of the detailed analysis and would not affect the selection of the PRAA.

Pretreatment may be necessary to prevent fouling of the stripper column packing. The air stripper system will consist of a packed stripping column and a blower. The water will be pumped to the top of the stripper column and will flow by gravity through the packing (designed to promote gas/liquid contact) to a sump at the bottom of the column. Air from the blower will flow from the bottom of the column to the top, countercurrent to the water flow.

FIGURE 6.2. Air Stripping Treatment System Block Flow Diagram

STARTING DATE: 12/04/80	DATE LAST REV: 06-14-91	INITIATOR: T KOVALCSON	DRAWING NO: 198814-B02
DRAWN BY: T HENDRICKSON	PROJECT MGR: J REGISTER	PROJECT NO: 198814	

The air-to-liquid ratio and the height of the packed column (and corresponding number of vapor-liquid equilibrium stages) determine the performance of the system. These design parameters will be established during the process design phase to meet the required effluent discharge criteria required by a NPDES permit. Treated water from the stripping column sump will be pumped to the discharge system. The off-gas will be processed through a vapor-phase carbon adsorber to remove contaminants before discharge to the atmosphere. Use of an incinerator for emission control was considered, but this option was eliminated at this time due to the small quantity of organic emission and relatively higher capital and operating cost compared with adsorption. Should the design basis change considerably, fume incineration will be reinvestigated.

6.3.2.2 Carbon Adsorption

Carbon adsorption is a treatment process that utilizes surface phenomena involving weak Van der Waals forces to separate materials from a liquid (usually water) or a gas (usually air). Adsorption takes place between activated carbon and an adsorbable species. Activated carbon possesses a very high internal surface area, which provides surface sites for adsorption to take place at the molecular level. High-grade activated carbons have more than 1,000 square meters of internal surface area per gram.

Figure 6.3 is a block flow diagram of the carbon adsorption system. The process flow diagram is provided in Appendix A. The entire treatment system consists of the pretreatment system described in Section 6.3.1 and the carbon adsorption system. Removal of dissolved iron as well as any particulate through pretreatment is necessary to prevent deleterious effects on the removal of the VOCs due to fouling of the carbon or short circuiting in the adsorber. Without pretreatment, the impact of iron fouling the carbon is significant because of the relatively high concentrations of iron, low concentrations of VOCs, and high flow rate of the ground water.

FIGURE 6.3. Carbon Adsorption Treatment System Block Flow Diagram

STARTING DATE: 12/04/90	DATE LAST REV: 06-14-91	DESIGNATOR: T KOVALCSON	DRAWING NO: 199814-B02
DRAWN BY: THEODORICKSON	DRAWN BY: T KOVALCSON	PROJECT MGR: J REGISTER	PROJECT NO: 199814

The process selected as representative of this technology consists of two granular activated carbon (GAC) beds arranged in a series (lead/polish) flow configuration. Because the flow rate is high and the VOC concentration is low, hydraulic loading rather than carbon consumption determines the size of the adsorbers. Virgin carbon, rather than regenerated carbon, should be used to provide the lowest effluent VOC concentrations. After the carbon in the lead bed has been exhausted, it will be taken off line for carbon replacement. The spent carbon will be shipped off-site to a commercial thermal regeneration facility. During carbon replacement, the polish vessel will remain on line. After replacement, the vessel with fresh carbon will be put in polishing service after the other vessel. Alternating in this manner will minimize carbon usage by maximizing loading of contaminant.

6.3.2.3 Air Stripping and Carbon Adsorption

An air stripping and carbon adsorption system is a combination of the two previously described technologies. The block flow diagram for this system is shown in Figure 6.4. Pretreatment may be necessary for removal of dissolved iron for the same reasons given above for each of the technologies. The process flow diagram is provided in Appendix A.

The treatment system will consist of a packed air stripping column, a blower, a vapor-phase carbon adsorber, and a GAC system. The combination of air stripping followed by carbon adsorption is sometimes employed where contaminants are at relatively high concentrations and a very high (e.g., > 99.9 percent) removal efficiency is needed, or where some contaminants are not easily stripped. It is also employed in cases where it is necessary to have a very high reliability for compliance with discharge criteria. The ground water and air flows through the stripper system are similar to those described in Section 6.3.2.1. The GAC system treats the aqueous effluent from the stripper and is sized and configured like the system described in Section 6.3.2.2. The purpose of the GAC system is to remove any residual VOCs that are not removed in the stripper. Also, the GAC system could provide complete treatment for a period of time if the air stripper system was off-line for any reason. The off-gas from the air stripper will be passed through a vapor-phase carbon adsorber to control organic emissions. The spent liquid- and vapor-phase carbon will be thermally regenerated off Base.

FIGURE 6.4. Air Stripping and Carbon Adsorption Treatment System
Block Flow Diagram

STARTING DATE: 12/07/80	DATE LAST REV: 06-14-91	INITIATOR: T KOVALCSON	DRAWING NO: 19814-B04
DRAWN BY: THENDRICKSON	PROJECT MGR: J REGISTER	PROJECT NO: 19814	

6.3.2.4 Fixed-Film Biological Treatment

Aerobic degradation is a biological treatment process that uses bacteria to convert (oxidize or hydrolyze) waste organics by enzymatic action. Aerobic degradation requires oxygen by definition and function. A trickling filter is a simple and well-proven type of fixed-film aerobic biological treatment. A packed bed of stones or synthetic media provides a large surface area for a bacterial film (biofilm) to grow, a large area for intimate contact of the waste stream with the bacterial mass, and a means to aerate the waste stream to provide favorable conditions for biological activity.

Figure 6.5 is a block flow diagram of the fixed-film process; a process flow diagram is included in Appendix A. The fixed-film bioreactor system will receive ground water after pretreatment for the removal of iron. Iron entering the bioreactor would be subject to oxidation and resulting precipitation. If iron is not removed prior to treatment, it would result in additional sludge production during biological treatment and it could eventually foul the bioreactor packing.

The ground water will flow from the extraction system and pretreatment system through a mix tank in which nutrients (e.g., nitrogen and phosphorus compounds) will be supplied using a metering pump. The mix tank effluent will flow continuously to the fixed-film bioreactor consisting of one or several large tanks containing packing or media to provide extensive surface to support the biofilm and to provide the necessary hydraulic retention time. A distributor will be used to apply the ground water evenly over the media. Air will be introduced and distributed throughout the tank using a blower system. To induce the bacterial production of the enzyme methane monooxygenase (required for the aerobic biodegradation of the VOCs), methane will be metered from a storage cylinder to the blower system discharge to maintain a methane concentration of approximately 3 percent in the reactor gas phase. The off-gas from the bioreactor(s) will be treated using a vapor-phase carbon adsorber or a fume incinerator before release to the atmosphere. Aqueous effluent from the bioreactor(s) will be transferred to a clarification unit to remove solids (biological) produced in the bioreactor(s). The settled sludge will be pumped

FIGURE 6.5. Fixed-Film Biological Treatment System Block Flow Diagram

STARTING DATE: 12/8/80	DATE LAST REV: 06-14-91	INITIATOR: T KOVALCSON	DRAWING NO: 19814-B05
DRAWN BY: THEODORICKSON	DRAWN BY: T KOVALCSON	PROJECT MGR: J REGISTER	PROJECT NO: 19814

to a sludge thickener/storage tank. The thickened sludge can be dewatered using the filter press included in the pretreatment system for iron sludge. The sludge will be temporarily stored in drums for transportation to an off-site disposal facility. In the event that the quantity of solids generated in the bioreactor(s) is very small, the reactor effluent could be passed directly through a filter and discharged.

6.3.2.5 UV/Chemical Oxidation

Chemical oxidation uses oxidizing agents to transform compounds in a waste stream to simpler or less toxic components. UV light is used in combination with oxidants such as hydrogen peroxide and/or ozone to enhance the chemical decomposition of waste constituents. The UV-catalyzed oxidation reaction mechanisms are complex and specific to each compound. Chemical oxidation combined with UV photolysis (UV/chemical oxidation) has been proven effective in treating dissolved chlorinated hydrocarbons in ground water.

Figure 6.6 is a block flow diagram of the UV/chemical oxidation system. Pretreatment is necessary to prevent iron from interfering in the oxidation reaction and from fouling the UV lamp surfaces. The process flow diagram is located in Appendix A. There are two commercial applications of this technology that could be considered as representative processes for this analysis. Both use baffled, stainless steel reactors to promote intimate contact between the wastewater containing organics to be oxidized, the oxidant, and the UV light for enough time to give the desired removal. One process uses a small number of high intensity UV lights and hydrogen peroxide. The other process uses a larger number of low intensity lights as a source of UV light and a combination of ozone and hydrogen peroxide as the oxidant. In either process, pretreated water will be pumped to the reactor that will be operated full of liquid. The organic chemicals present will be oxidized by the hydroxyl free radicals created by the interaction of UV light with the hydrogen peroxide and/or ozone. Hydrogen peroxide solution will be transferred from a storage tank with a metering pump. If ozone is used, it will be produced from air in an ozone generator and dissolved in the liquid inside the reactor. For systems using ozone, an ozone decomposition unit is provided by the equipment vendor to prevent ozone emissions. Treated water

NOTE: Items in Dashed Lines are for the UV/Ozone/Peroxide System Only

FIGURE 6.6. UV/Chemical Oxidation Treatment System Block Flow Diagram

STARTING DATE: 12/04/00	DATE LAST REV: 08-14-01	INITIATOR: T KOVALCSON	DRAWING NO: 159A14.R02
DRAWN BY: THEODORICKSON	DRAWN BY: T KOVALCSON	PROJECT MGR: J REGISTER	PROJECT NO: 159814

will overflow from the reactor to a sump from which it will be pumped to the treated effluent tank. No waste products will be generated from the UV/chemical oxidation step of the process, although iron sludge may be produced from the pretreatment step.

6.4 COMPARATIVE ANALYSIS

The five treatment alternatives described in Section 6.3.2 were evaluated against a range of criteria as described in Section 6.2. The results of the evaluation are summarized in tabular form (Table 6.1) for comparison. A discussion of the results for each criterion is presented below along with highlights from Table 6.1 and, where necessary, a definition of the criterion. The table and discussion are complimentary and should be considered together to understand the overall evaluation results. For selected criteria, the pretreatment process is listed separately in the table along with the treatment process to note a particular characteristic of the pretreatment system or to clarify differences between alternatives.

6.4.1 Effectiveness

Generally, the alternative that demonstrates the greatest overall improvement to public health, welfare, and the environment is defined to be the most effective. Specifically, effectiveness for this analysis is measured by the likelihood that the alternative will meet expected effluent discharge criteria, the type and quantity of wastes produced, and the total degree of contaminant destruction.

6.4.1.1 Likelihood Technology Will Meet Expected Effluent Discharge Criteria

Except for fixed-film biological treatment, the technologies considered have been demonstrated at full-scale to treat a wide variety of organic compounds, including the VOCs, in ground water down to very low concentration. Air stripping and carbon adsorption processes have been employed frequently for similar applications. Biological treatment has not been demonstrated to treat the VOCs aerobically in a full-scale system. Laboratory studies have shown that the VOCs will biodegrade if the proper

TABLE 6.1.1. Comparative Evaluation of Alternatives

Evaluation Criteria	Treatment Technology Alternative				
	Air Stripping	Stripping/Adsorption	Carbon Adsorption	Biological Treatment	UV/Chemical Oxidation
1.0 EFFECTIVENESS					
1.1 Likelihood Technology Will Meet Effluent Discharge Criteria	Very Likely	Very Likely	Very Likely	Has Not Yet Been Demonstrated	Very Likely
1.2 Wastes Produced					
- Pretreatment	Iron Sludge, Spent Filter Media, and Spent Vapor-Phase Carbon	Iron Sludge, Spent Filter Media, and Spent Vapor-Phase Carbon	Iron Sludge, Spent Filter Media, and Spent Vapor-Phase Carbon	Iron Sludge, Spent Filter Media, and Spent Vapor-Phase Carbon	Iron Sludge, Spent Filter Media, and Spent Vapor-Phase Carbon
- Treatment	Spent Vapor-Phase Carbon and Stripper Packing	Spent Vapor- and Liquid-Phase Carbon and Stripper Packing	Spent Liquid-Phase Carbon	Biological Sludge and Spent Vapor-Phase Carbon	None
1.3 Total Degree of Contaminant Destruction	Very High	Very High	Very High	High	Very High
2.0 IMPLEMENTABILITY					
2.1 Degree of Availability of Equipment and Technology	Very High	Very High	Very High	Moderate	High
2.2 Relative Time to Implement	Short	Short	Short	Long	Moderate
2.3 Importance of Conducting Pilot or Laboratory Tests					
- Pretreatment	Very Important	Very Important	Very Important	Important	Critical
- Treatment	Not Important	Important	Important	Very Important	Very Important

TABLE 6.1. (cont.)

Evaluation Criteria	Treatment Technology Alternative				
	Air Stripping	Stripping/Adsorption	Carbon Adsorption	Biological Treatment	UV/Chemical Oxidation
2.4 Degree of Normal Operation and Maintenance Requirements					
- Pretreatment	Moderate	Moderate	Moderate	Moderate	Moderate
- Treatment	Low	Low	Low	High	High
2.5 Special Requirements	None	None	None	System Specialist	System Specialist, Building
- Pretreatment	Iron Sludge	Iron Sludge	Iron Sludge	Iron Sludge	Iron Sludge
- Treatment	None	None	None	Biological Sludge	None
3.0 <u>RELIABILITY</u>					
3.1 Degree of Flexibility Under Changes in Ground Water Characteristics					
- Flow Rate	High	High	High	Low	Moderate
- Influent Concentration	Moderate	Very High	Very High	Moderate	Low
3.2 System Reliability	High	High	High	Low	Moderate
3.3 Monitoring Requirements	Low	Low	Low	High	Moderate
3.4 Off-site Disposal or Treatment Requirements	Spent Vapor-Phase Carbon via Thermal Regeneration	Spent Vapor- and Liquid-Phase Carbon Via Thermal Regeneration	Spent Liquid-Phase Carbon via Thermal Regeneration	Biological Sludge via Disposal in Landfill and Spent Vapor-Phase Carbon via Thermal Regeneration	None

TABLE 6.1. (cont.)

Evaluation Criteria	Treatment Technology Alternative				
	Air Stripping	Stripping/Adsorption	Carbon Adsorption	Biological Treatment	UV/Chemical Oxidation
4.0 SAFETY REQUIREMENTS					
4.1 Degree of Risks to Workers					
- Hazardous Material	Low	Low	Low	Moderate	High
- Hazardous Equipment	Low	Low	Low	Low	Moderate
4.2 Risk to Community					
- Release Potential	Low	Low	Low	Low	Low
5.0 COST COMPARISON^(a)					
5.1 Capital Costs	1.0	2.4	1.6	16.6	2.6
5.2 Operation and Maintenance Costs	1.0	1.6	4.3	3.6	3.0
5.3 Net Present Worth	1.0	2.0	3.0	9.3	2.7

(a) Costs are presented as a ratio relative to air stripping, which was assigned a value of 1.0 for each cost category because the estimated costs are lowest of all the alternatives. For example, the capital cost for carbon adsorption is 1.6 times the capital cost for air stripping. Costs related to pretreatment, extraction, and discharge are not included in this comparative analysis of treatment technologies.

environment and suitable co-metabolite are provided, but even under optimum conditions, the ability of the biological treatment system to meet expected effluent discharge criteria has not been determined.

6.4.1.2 Wastes Produced

Wastes are those materials that are produced by the treatment (or pretreatment) systems and require off-site disposal or regeneration.

Preliminary process design calculations indicate that the pretreatment system will generate approximately 200 to 300 tons/year of iron sludge and spent filter media loaded with iron silt and other undissolved particulate. This value will be confirmed through treatability testing and material balances during the process design.

Air stripper off-gas will be collected and directed through a vapor-phase carbon adsorption unit. Approximately 0.3 ton/year of VOCs will be produced by the stripper resulting in a vapor-phase carbon usage of 4 tons/year.

If GAC is used alone, the carbon system is projected to generate 38 tons/year of spent GAC based on a carbon loading of 8.2 milligrams (mg) of TCE per gram of carbon. This loading was derived from EPA isotherm data for TCE (Dobbs & Cohen, 1980). If carbon capacity is consumed by other organic compounds that comprise the 15 mg/L of total organic carbon (TOC), larger quantities of spent carbon will be generated. If air stripping plus carbon is used, approximately 4 tons/year of GAC will be used based on a loading of 0.38 mg of TCE per gram of carbon (Dobbs & Cohen, 1980). It has been assumed that the stripper packing will need to be disposed of every 5 years due to fouling.

The fixed-film bioreactor in the biological treatment system is projected to produce small quantities of biological sludge. Any sludge that must be removed from the bioreactor effluent will be dewatered and temporarily stored prior to transport off site for disposal. Spent vapor-phase carbon from treating the bioreactor off-gas, if necessary, will also require shipment off-site to a regeneration facility.

UV/chemical oxidation (excluding the pretreatment step) are not expected to produce a significant volume of wastes.

6.4.1.3 Total Degree of Contaminant Destruction

The total degree of contaminant destruction is defined as the relative difference between the initial mass of the contaminants in the extracted ground water and the remaining total mass of contaminants contained in any air emission, the treated effluent, and wastes that are generated as a result of treatment, excluding carbon needing off-site disposition via thermal incineration.

Treatment technology options presented herein are able to demonstrate a degree of contaminant destruction. Biological treatment and UV/chemical oxidation degrade contaminants, converting them into water, carbon dioxide and inorganic chloride (and biomass for biotreatment); however, UV/chemical oxidation and biological treatment may produce intermediate by-products as a result of incomplete oxidation. Biological treatment is rated lower than the others because it produces waste products that require disposal or regeneration. Options utilizing liquid- or vapor-phase carbon have the highest level of contaminant destruction as the spent carbon containing the contaminants will be thermally regenerated off-Base, a process that destroys the contaminants.

6.4.2 Implementability

The most implementable alternative is the one that can be most easily engineered, constructed, and operated within the short time period required.

6.4.2.1 Degree of Availability of Equipment and Technology

Air stripping and carbon adsorption are widely used technologies for treating ground water. Packaged standard systems can be ordered directly from vendors and delivered within a reasonable time frame. Custom or specially designed systems would require more time.

Fixed-film biological treatment is rated the lowest for availability because it is not a conventional technology for treating VOC-contaminated ground water to low levels. A full-scale ground water treatment system has never been designed to achieve low VOC effluent concentrations. Treatability studies and pilot-scale testing must be conducted to determine the effectiveness of biological treatment. The time for this testing will be

lengthened because the system's biomass must be enriched and cultivated prior to any testing. Necessary equipment for the biotreatment system is available from wastewater treatment vendors as separate items, but significant design and installation effort and time would be needed. The bioreactor(s) would require field fabrication because of the very large size. A specialist in this technology would be necessary during startup and initial operation. Time would also be necessary for seeding the reactor.

A UV/chemical oxidation system can be bought skid-mounted from several vendors representing somewhat different process configurations. UV/chemical oxidation will require a technology specialist to be present during startup.

6.4.2.2 Relative Time to Implement

The time to implement includes bench- or pilot-scale studies, engineering, construction, and startup. The overall time to implement the removal action will be impacted by the time required for testing, developing, and implementing a pretreatment system.

An air stripper system would take a relatively short time to implement because bench- or pilot-scale studies are not normally required. Limited treatability testing may be required to ascertain the behavior of troublesome ground water constituents such as iron, depending on the specific process being designed.

For carbon and UV/chemical oxidation, time to implement may be extended somewhat because treatability studies are recommended, but the time to engineer, construct, and startup these processes are expected to be comparable to air stripping.

The time to implement biological treatment would be considerably greater than the other technologies because bench- and pilot-scale studies must be performed. An acclimated culture capable of aerobically degrading the VOCs must be isolated from the contaminated aquifer and enriched. After the appropriate microbiological population has been cultivated, it can be used for the bench- and pilot-scale tests. This culture must be used to seed the full-scale system to generate the required biomass. After seeding, acclimation and attachment of the bacteria to the support media of the full-scale system would require a period of 1 to 2 months.

6.4.2.3 Importance of Conducting Pilot or Laboratory Tests

The importance of pilot or laboratory tests can be divided into two groups - importance for pretreatment and importance for treatment.

A pretreatment system should not be designed without treatability studies to determine the proper amount of raw materials necessary for iron removal and to finalize the specific pretreatment process. Optimizing the pretreatment design is important since it can represent a significant cost contribution to the overall treatment system. For UV/chemical oxidation, treatability studies are critical for the iron removal step because of the impact iron can have on system performance and maintenance. Treatability studies of the pretreatment system will also provide increased assurance that the other treatment alternatives, carbon adsorption, air stripping, and biological treatment, will operate cost-effectively. Demonstrating the effectiveness of the iron removal process in bench-scale tests should result in improved design of the pretreatment system.

Treatability studies are not required for the air stripper system if a conventional stripping process is designed and if pretreatment for iron removal is employed. Otherwise, bench-scale testing may be advisable, as noted in Section 6.4.2.2.

A bench-scale treatment study using actual contaminated ground water should be conducted for systems using liquid-phase carbon adsorption. Carbon consumption may increase above the estimated level if dissolved ferrous iron (not removed in the pretreatment system) oxidizes in the bed or if some fraction of any unidentified organic compounds (i.e., other TOC) is adsorbed by the carbon. Accurate estimates of carbon consumption can only be made by conducting laboratory treatability studies designed to establish breakthrough of the VOCs.

Prior to the design and installation of the full-scale biological treatment system, bench- and pilot-scale studies must be performed to confirm the effectiveness of and to determine the design parameters for the proposed system. In addition, an acclimated culture capable of degrading the VOCs must be isolated from the contaminated aquifer and enriched prior to initiating the studies. Initial seeding of the full-scale system will require the operation

of a full-scale fermentation unit in which the enriched VOC-degrading isolates will be cultivated.

A pilot study for UV/chemical oxidation should be conducted to demonstrate that the effluent discharge criteria can be achieved, to measure the values of the key design parameters, and to verify conditions for effective pretreatment.

6.4.2.4 Degree of Normal Operation and Maintenance Requirements

Normal operation and maintenance requirements include all activities necessary to keep the system on line and meeting performance requirements (e.g., effluent discharge criteria). Such requirements do not include ground water quality monitoring.

For the pretreatment system, routine operator attention would be required to ensure chemicals were being added at the correct dosages and that the iron solids were settling properly (i.e., no suspended solids in the clarifier overflow). The system would require unloading of raw material deliveries and periodic addition of raw materials to storage tanks. Labor would be required to operate the sludge filter press and to containerize, temporarily store, and periodically ship the resulting filter cake. The pretreatment system would also require labor to replace and dispose of spent polish filter media.

Operator attention would be minimal (i.e., check once each day or every several days) for the air stripping, carbon adsorption, and air stripping-carbon adsorption systems assuming a reasonable level of automated process control and a communication system to alert Base operations personnel of any system malfunctions. A packed air stripping column would require periodic inspection of the packing for fouling. The packing could require periodic (once every 2 to 5 years) cleaning or changing if fouling does occur. For air stripping, air stripping plus carbon adsorption, or biological treatment, operators will be necessary when vapor-phase carbon is replaced. Carbon would require replacement periodically (i.e., every 2 to 4 months) as described in the process description. Carbon replacement would be less frequent for the air stripping-carbon system. Periodic inspection of the carbon beds and monitoring the pressure drop through the beds would also be required to

determine if solids are depositing on the carbon and decreasing adsorption efficiency. If fouling occurs, the beds would need to be backwashed or the carbon changed, depending on the amount of solids present.

The fixed-film biological treatment is expected to require more frequent operator and maintenance attention. The operator would have to be present to check methane inventory; process sludge accumulated in the filter or clarifier and containerize and store the sludge; prepare batches of nutrients; adjust nutrient, methane, and air feed rates; periodically replace the vapor-phase carbon if emission controls are used on the bioreactor(s) off-gas; and conduct monitoring of effluent from the system.

The UV/chemical oxidation system would require maintenance and periodic replacement of the UV lights and maintenance of the ozone generation and/or hydrogen peroxide delivery systems. Operator attention would be minimal to confirm oxidant flow rates and inventories.

6.4.2.5 Special Requirements

The biological treatment process will require technical specialists to design the process and establish the appropriate microbiological environment for the particular ground water stream. The UV/chemical oxidation system would require a building to be constructed around it for weather protection and a system specialist would be required during startup to train the operator. No special requirements are indicated for the other treatment technologies. However, due to the flooding conditions that occur in Area C near Huffman Dam and Landfill Number 5, provisions must be made in the design of all the technologies to enable continued operation.

6.4.2.6 Temporary Storage Requirements

The only systems that would require temporary storage of waste material are the pretreatment and potentially the biological treatment system, depending on the quantity of biosludge generated. Dewatered iron and biological sludge would have to be stored in drums while awaiting shipment to an off-site disposal facility.

6.4.3 Reliability

6.4.3.1 Degree of Flexibility Under Changes in Ground Water Characteristics

Because the extracted ground water characteristics and flow rate may vary from the projected values during the lifetime of the removal action, the ability of each treatment alternative to adapt to such variations was considered.

The air stripper process can be operated over a relatively wide range of flow rate conditions if provisions are made in the design to ensure that adequate gas-liquid contact is achieved. Likewise, the system can handle a large range of influent concentrations of VOCs, although effluent concentration will increase with higher inlet concentrations at the same removal efficiency. A decrease in the effluent contaminant levels might be achieved through increasing the air flow rate through the stripper. For a packed air stripper column, additional packed column height or addition of another column could increase the removal efficiency incrementally.

Carbon adsorbers can tolerate relatively large variations in hydraulic throughput, influent concentrations, and influent composition without affecting performance. If a conservatively large size (diameter) is selected, a moderate (i.e., 25 to 50 percent) increase in flow rate could be effectively treated; however, increases in flow rate above standard design guidelines (i.e., 8 gpm/ft²) could result in unsatisfactory performance. The impact of higher influent concentrations on carbon use is increased consumption. Carbon consumption may also increase in response to changes in ground water chemistry; if the concentration of compounds with relative sorption characteristics that require more frequent carbon replacement in order to maintain effluent criteria is increased, then carbon consumption will increase.

The air stripping/carbon adsorption system provides great flexibility: it tolerates changes in flow rate and composition as described above for the individual processes, plus it provides two distinct methods of treatment that can collectively deal with significant changes in influent composition while providing a high degree of performance.

The fixed-film biological treatment system must operate within a relatively limited range of flow rates and influent composition because treatment efficiency is directly proportional to residence time. In addition to not maintaining adequate reactor hydraulic retention time for degradation of the VOCs, the clarifier or filter would not provide adequate solids separation if the hydraulic flow rate increases significantly. Finally, the microorganisms cannot tolerate rapid, significant changes in water chemistry, although such changes are not considered likely.

The UV/chemical oxidation process cannot tolerate significantly higher flow rates because treatment efficiency is directly proportional to residence time. If influent concentrations were lower than the design basis, higher flow rates could be treated, and vice versa. The relationship between flow rate, influent concentration, and effluent concentration must be determined from treatability testing to project the flexibility of the system.

6.4.3.2 System Reliability

The five alternatives have varying degrees of operational reliability depending on:

- Type and number of mechanical systems/components
- Potential for fouling or other deterioration of key functional elements
- Complexity and performance of control systems
- Maintainability
- Ability to recover from upset conditions (including influent conditions).

All treatment systems will be vulnerable to shutdown if the potential system fails to perform satisfactorily. The biological treatment system is expected to be most impacted by such a situation. The carbon adsorption system is the simplest, requires minimal maintenance, and would recover easily (by replacement of carbon) from upsets or inadvertent fouling. The air stripper system relies on more mechanical components and is subject to fouling that would result in longer downtime for cleaning than required for replacement of carbon. The UV/chemical oxidation system is more complex and may involve some equipment components that would be more difficult to replace quickly.

Irregardless of technology, a reasonable time period (e.g., several weeks) is expected to be available for converting many potential types of system problems.

6.4.3.3 Monitoring Requirements

The treated ground water discharge from all of the treatment systems will be monitored for all of the VOCs detected in the vicinity, TOC, total suspended solids (TSS), and other parameters as required to remain in compliance with discharge permit requirements. Any additional requirements are described below.

The carbon system will require monitoring of the lead adsorber effluent during the first several months of operation to determine breakthrough of the VOCs and then less frequently for the remaining period of operation. Breakthrough time will vary with changes in VOC influent concentrations.

In addition to monitoring the water effluent from the air stripper, monitoring of the emissions will be required to determine breakthrough in the vapor-phase carbon.

The influent stream of the fixed-film bioreactor will require routine monitoring of the macronutrient concentrations (ammoniacal nitrogen and ortho-phosphate), TSS, TOC concentration, VOC concentrations, and pH. The bioreactor gas phase will need to be monitored for the proper methane and oxygen concentrations. The bioreactor effluent, and potentially the clarifier underflow and sludge thickener underflow, will require routine analysis for suspended solids (TSS). Monitoring for breakthrough will be required for the emission control system (a vapor-phase carbon unit or a fume incinerator) treating the bioreactor off-gas.

During startup, the UV/chemical oxidation system will be tuned to optimize the oxidant dosage needed to achieve the desired effluent concentrations. When this has been done, the reactor will achieve the effluent quality as long as the reactor parameters such as inlet concentration, UV light dosage, and oxidant dosage do not change.

6.4.3.4 Off-Site Disposal or Treatment Requirements

The dewatered iron filter cake and spent filter media generated by the pretreatment system will be disposed of in a landfill or in a Resource Conservation and Recovery Act (RCRA) permitted disposal facility (if it is classified as hazardous waste).

The liquid- and vapor-phase carbon will be thermally regenerated off site at an approved facility, thus providing contaminant destruction and eliminating future liabilities associated with disposal. In addition, the facility will be required to demonstrate destruction of the contaminant, further reducing liability. The biological sludge generated in the bioreactor will be disposed of at an approved facility. It is assumed from preliminary calculations that the biosludge will not be classified as a RCRA hazardous waste.

6.4.4 Safety Requirements

Safety requirements are categorized as the degree of risk to workers and the degree of risk to the community. The degree of risk to workers concerns the materials and equipment handled or used that have the greatest potential to cause injury to the installers or operators. The degree of risk to the community considers the potential of the treatment system or its subsystem to release a harmful quantity or concentration of hazardous material to the surrounding community.

6.4.4.1 Risk to Workers

The pretreatment system will potentially require the use of acid and caustic for pH adjustment, posing chemical hazards to personnel if they are not properly protected.

The carbon and the air stripper systems do not have any unusual safety hazards. Carbon, however, does have the potential for autoignition under conditions of low moisture and when certain types of organics are present, but these conditions will not exist for either the liquid-phase or vapor-phase adsorbers described in this section.

Biological treatment was rated moderate because of the presence of methane on site. UV/chemical oxidation requires safe handling and use of

oxidants (hydrogen peroxide and/or ozone). Safety and emergency equipment and procedures as well as training will be specified in the design to prevent injuries. The UV light can cause eye injuries if the proper operating procedures are not followed.

6.4.4.2 Risk to Community

All of the technologies present a low level of risk to the community given the low risk of a release due to system failure and the low concentrations of contaminants. Also, no toxic materials are used for any of the processes. For the biological alternative, the probable remote location of the treatment facility will minimize any potential risk from a fire or explosion caused by the methane.

6.4.5 Cost Comparison

Budgetary capital and annual operating costs were developed for all treatment alternatives based on the preliminary process definition information presented in Appendix A. For the case of biological treatment, the costs are very preliminary approximations because many design parameters are not well defined for this application. These estimates included only system elements within the physical limits of the treatment facility. The costs for site development and routing of utilities to the site plus the costs for the extraction and discharge systems and pretreatment system were not included because they were considered common costs for all treatment alternatives. The capital and operation and maintenance cost estimates were used to determine a net present worth for each alternative assuming a 20-year project life and 10 percent discount rate. The estimates were converted to ratios for comparison using the values for the lowest cost alternative as a reference value.

As indicated in Table 6.1, the air stripping alternative results in the lowest capital, operating cost, and net present worth. The conclusion that air stripping is the lowest cost treatment alternative is based on the projected ground water composition and on anticipated effluent discharge criteria. Both these parameters will affect cost, as will the flow rate of ground water extracted from the aquifer. Also, site-specific treatability data were not available for any of the technologies, and the assumptions used

to develop the budgetary cost estimated will potentially be effected by having appropriate data.

If the common capital and operating costs were determined and included in the cost analysis, the relative differences between alternatives would be significantly reduced but would not alter the choice of technology. These additional common systems are expected to represent the major portion of total capital costs for all the RAAs except for biological treatment.

6.5 SELECTION OF THE PREFERRED TREATMENT ALTERNATIVE

Considering the design basis and the evaluation criteria used in this analysis, air stripping is the preferred treatment technology. It is believed that this selection is consistent with regulatory BAT requirements. Air stripping was clearly superior in most criteria to UV/chemical oxidation and fixed-film biological treatment. Air stripping and liquid-phase carbon adsorption were comparable for most criteria, but estimated cost was more favorable for air stripping. Air stripping plus liquid-phase carbon adsorption would provide more flexibility under changing conditions; however, with the expected influent concentrations, air stripping alone was evaluated to perform similar to air stripping with liquid-phase carbon adsorption at half the cost. The ratings of all treatment technologies were based on effective pretreatment, and on the representative processes selected for use during the evaluation.

It should be noted that the selection of air stripping as the treatment process option was based on information available at the time this FFS was prepared. Flow rate and influent concentrations, estimated from field data and ground water modeling, may be different for the full-scale system due to uncertainties in the actual geologic subsurface conditions and contaminant locations and levels. In addition, effluent requirements will not be established until the discharge permit is issued - after design of the treatment system is underway or even completed. If the final NPDES discharge effluent requirements are outside the range of the performance flexibility of the designed treatment system, design modifications will be required prior to construction and startup. If influent concentrations or flow rates change, modifications to the installed system may be required. Some flexibility is

inherent in most treatment technologies. The design of this treatment system could include a greater degree of flexibility to allow for potential modifications to be made after startup.

7.0 PRESENTATION OF RECOMMENDED ALTERNATIVE

The detailed analysis of alternatives for the extraction, treatment, and discharge components discussed in Sections 4.0, 5.0, and 6.0 have led to selection of a recommended (preferred) RAA. Table 7.1 indicates the elimination of all alternatives except for the preferred RAA.

The preferred RAA will meet the removal action objective through the use of ground water extraction wells, air stripping, and discharge to surface water. A system of three extraction wells will be implemented in a phased approach to capture contaminated ground water exceeding MCLs and deliver it to a storage tank and transfer system. The transfer system will then deliver the extracted water to the treatment system, consisting of:

- A pretreatment process to remove iron and other metals as necessary to allow satisfactory performance of the air stripping process
- An air stripping process to reduce TCE (and other VOCs) to the required effluent criteria to be established by the NPDES permitting process
- A vapor-phase carbon adsorption unit to control the air stripper off-gas necessary to meet Ohio Air Pollution Rule 3745-21-09(A).

The treated effluent will be collected in a surge tank and pumped continuously through a transfer system and outfall to the Mad River.

The philosophy of this removal action, which is part of a much larger effort at WPAFB, is to take an "observational" approach emphasizing timely implementation of the removal action with the understanding that additional design and modification of the action could be implemented. The collection and analysis of performance data following implementation will facilitate this observational approach.

TABLE 7.1. RECOMMENDED REMOVAL ACTION ALTERNATIVE

Alternative	Collection	Removal	Discharge
1	Extraction (Wells)	Carbon Adsorption	Aquifer Recharge
2	Extraction (Wells)	Biological Treatment	Aquifer Recharge
3	Extraction (Wells)	Air Stripping	Aquifer Recharge
4	Extraction (Wells)	UV/Chemical Oxidation	Aquifer Recharge
5	Extraction (Wells)	Stripping, Adsorption	Aquifer Recharge
6	Extraction (Wells)	Carbon Adsorption	On-Base Use
7	Extraction (Wells)	Biological Treatment	On-Base Use
8	Extraction (Wells)	Air Stripping	On-Base Use
9	Extraction (Wells)	UV/Chemical Oxidation	On-Base Use
10	Extraction (Wells)	Stripping, Adsorption	On-Base Use
11	Extraction (Wells)	Carbon Adsorption	Surface Water
12	Extraction (Wells)	Biological Treatment	Surface Water
13	Extraction (Wells)	Air Stripping	Surface Water
14	Extraction (Wells)	UV/Chemical Oxidation	Surface Water
15	Extraction (Wells)	Stripping, Adsorption	Surface Water
16	Extraction (Wells)	Carbon Adsorption	Off-Base POTW
17	Extraction (Wells)	Biological Treatment	Off-Base POTW
18	Extraction (Wells)	Air Stripping	Off-Base POTW
19	Extraction (Wells)	UV/Chemical Oxidation	Off-Base POTW
20	Extraction (Wells)	Stripping, Adsorption	Off-Base POTW
21	Extraction (Wells)	None	On-Base Use
22	Extraction (Wells)	None	Surface Water
23	Extraction (Wells)	None	Off-Base POTW

REFERENCES

Dobbs, R. A., and Cohen, J. M., 1980, Carbon Adsorption Isotherms for Toxic Organics, US EPA, Municipal Environmental Research Laboratory, Office of Research and Development, Cincinnati, Ohio.

Engineering Science, 1989, Project Work Plan for Remedial Investigations and Feasibility Studies at Wright-Patterson Air Force Base, Ohio, Volumes 1 through 4, Dayton, Ohio.

Fidler, Richard E., 1975, Digital Model Simulation of the Glacial-Outwash Aquifer at Dayton, Ohio, Water Resources Investigations 18-75. U.S. Geological Survey, Columbus, Ohio.

IT Corporation, June 1990, Work Plan for Task 4, Volume 2, Cincinnati, Ohio.

IT Corporation, June 1990, Sampling and Analysis Plan for Task 4, Volume 3, Cincinnati, Ohio.

IT Corporation, June 1990, Health and Safety Plan for Task 4, Volume 4, Cincinnati, Ohio.

IT Corporation, November 1990, Field Investigation Report, Volume 5, Cincinnati, Ohio.

IT Corporation, November 1990, Proposed Removal Action Alternatives, Volume 6, Knoxville, Tennessee.

IT Corporation, November 1990, Technology Plan, Volume 7, Knoxville, Tennessee.

Prickett, T. A., and Lonquist, C. G., 1971, Selected Digital Computer Techniques for Ground Water Resource Evaluation, Bulletin 55. Illinois State Water Survey, Champaign, Illinois.

Walton, William C., 1987, Ground Water Pumping Tests: Design and Analysis, Lewis Publishers, Inc., Chelsea, Michigan.

Walton, William C., 1989, Numerical Ground Water Modeling: Flow and Contaminant Migration, Lewis Publishers, Inc., Chelsea, Michigan.

Weston, Inc., September 1985, Final Report Phase II-Stage 1 Study, Prepared for Wright-Patterson Air Force Base.

Weston, Inc., July 1989, Stage 2 Report - Volumes I, II, and III, Technical Report and Appendices, Prepared for Wright-Patterson Air Force Base.

APPENDIX A

TREATMENT SYSTEMS DESIGN DETAILS

APPENDIX A

CONTENTS

Process Flow Diagram for Extraction and Storage System	A.2
Process Flow Diagram for Pretreatment System	A.3
Process Flow Diagram for Fixed-Film Biological Treatment System	A.4
Process Flow Diagram for Carbon Adsorption Treatment System	A.5
Process Flow Diagram for Air Stripping Treatment System	A.6
Process Flow Diagram for Chemical Oxidation Treatment System	A.7
Process Flow Diagram for Air Stripping and Carbon Adsorption Treatment System	A.8
Process Flow Diagram for Groundwater Discharge System	A.9
Preliminary Equipment List, Area 10 - Extraction and Storage System	A.10
Preliminary Equipment List, Area 20 - Pretreatment System	A.11
Preliminary Equipment List, Area 30 - Biological Treatment System	A.13
Preliminary Equipment List, Area 30 - Carbon Adsorption Treatment System	A.15
Preliminary Equipment List, Area 30 - Air Stripping Treatment System . .	A.16
Preliminary Equipment List, Area 30 - UV/Chemical Oxidation Treatment System	A.17
Preliminary Equipment List, Area 30 - Air Stripping and Carbon Adsorption Treatment System	A-18
Preliminary Equipment List, Area 40 - Ground Water Storage and Discharge System	A.19

PRELIMINARY EQUIPMENT LIST AREA 10 - EXTRACTION AND STORAGE SYSTEM Wright-Patterson Air Force Base			
EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
P-1001 A,B,C	Extraction Well Pumps	200 gpm shaft and turbine	10-F01
P-1002 A,B	Ground Water Transfer Pumps	600 gpm centrifugal	10-F01
T-1001	Ground Water Surge Tank	20,000 gallon	10-F01
T-1002	Emergency Overflow Tank	30,000 gallon	10-F01

PRELIMINARY EQUIPMENT LIST
AREA 20 - PRETREATMENT SYSTEM
Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
A-2001	Floc Tank Agitator		20-F01
A-2002	pH Adjust Agitator		20-F01
C-2001 A,B	Vapor-Phase Carbon Adsorbers		20-F01
B-2001	Aeration Blower		20-F01
P-2001	Caustic Metering Pump		20-F01
P-2002	Polymer and/or Flocculant Metering Pump		20-F01
P-2003	Acid Metering Pump		20-F01
P-2004	Sludge Pump		20-F01
P-2005	Filter Press Feed Pump		20-F01
P-2007	Transfer Pumps	600 gpm centrifugal	20-F01

PRELIMINARY EQUIPMENT LIST
 AREA 20 - PRETREATMENT SYSTEM (Continued)
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
S-2001 A,B	Lead Filters	Bag or cartridge type	20-F01
S-2002 A,B	Polishing Filters	Bag or cartridge type	20-F01
T-2001	Aeration Tank		20-F01
T-2002	Flocculation Tank		20-F01
T-2003	Clarifier	20,000 gallon inclined plate type	20-F01
T-2004	Caustic Tank		20-F01
T-2005	Polymer and/or Flocculant Tank		20-F01
T-2006	pH Adjust Tank	5000 gallon	20-F01
T-2007	Acid Tank		20-F01
T-2008	Sludge Tank	500 gallon	20-F01
T-2009	Pretreated Water Surge Tank	20,000 gallon	20-F01
Y-2001	Filter Press	20-40 cubic feet capacity	20-F01

PRELIMINARY EQUIPMENT LIST
AREA 30 - BIOLOGICAL TREATMENT SYSTEM
Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
A-3001	Mix Agitator		30-F01
B-3001	Air Blower		30-F01
C-3001	Methane Tank		30-F01
C-3002	Fixed-Film Bioreactor	Multiple tanks containing media, estimated 2-3 million gallons total volume	30-F01
C-3003	Vapor-Phase Carbon Adsorber		30-F01
P-3001 A, B	Bioreactor Feed Pumps	600 gpm centrifugal	30-F01
P-3002	Nutrient Metering Pump		30-F01
P-3003 A, B	Bioreactor Effluent Pumps	600 gpm centrifugal	30-F01
P-3004	Sludge Pump		30-F01
P-3005	Clarified Water Pumps	600 gpm centrifugal	30-F01
P-3006	Thickened Sludge Pump		30-F01
P-3007 A, B	Clarified Water Pumps	600 gpm centrifugal	30-F01

PRELIMINARY EQUIPMENT LIST
 AREA 30 - BIOLOGICAL TREATMENT SYSTEM (Continued)
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
T-3001	Mix Tank	5000 gallon	30-F01
T-3002	Nutrient Tank		30-F01
T-3003	Clarifier	20,000 gallon inclined plate type	30-F01
T-3004	Sludge Thickener/Storage Tank		30-F01

PRELIMINARY EQUIPMENT LIST
 AREA 30 - CARBON ADSORPTION TREATMENT SYSTEM
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
C-3001 A,B	Liquid-Phase Carbon Adsorbers	10 feet diameter, 20,000 lb of carbon	30-F02

PRELIMINARY EQUIPMENT LIST
 AREA 30 - AIR STRIPPING TREATMENT SYSTEM
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
B-3001	Air Stripper Blower	1600 cfm	30-F03
C-3001	Air Stripper	7 feet diameter by 25 feet in height with 18 feet of 3½" tri-pack packing	30-F03
C-3002 A,B	Vapor-Phase Carbon Adsorbers (if needed)	3000 lb units	30-F03
P-3001 A,B	Stripper Effluent Pumps	600 gpm centrifugal	30-F03

PRELIMINARY EQUIPMENT LIST
 AREA 30 - UV/CHEMICAL OXIDATION TREATMENT SYSTEM
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
P-3001	Hydrogen Peroxide Metering Pump	4 gph, variable speed drive	30-F04
P-3002 A, B	Effluent Pumps	600 gpm centrifugal	30-F04
R-3001	Oxidation Reactor with UV Lamps	6000 gallon, baffled, with UV lamps and DC power supply	30-F04
T-3001	Hydrogen Peroxide Tank		30-F04
T-3002	Effluent Sump		30-F04
Y-3001	Air Compressor		30-F04
Y-3002	Ozone Generator	120 lbs/day	30-F04
Y-3003	Ozone Decomposer		30-F04

PRELIMINARY EQUIPMENT LIST
 AREA 30 - AIR STRIPPING AND CARBON ADSORPTION TREATMENT SYSTEM
 Wright-Patterson Air Force Base

EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
B-3001	Stripper Blower	1600 cfm	30-F05
C-3001	Air Stripper	7 feet diameter by 25 feet high with 18 feet of 3 1/2" triple packing	30-F05
C-3002 A, B	Vapor-Phase Carbon Adsorber (if needed)	3000 lb units	30-F05
C-3003 A, B	Liquid-Phase Carbon Adsorbers	10 feet diameter, 20,000 lbs of carbon each	30-F05
P-3001 A, B	Stripper Effluent Pumps	600 gpm centrifugal	30-F05

PRELIMINARY EQUIPMENT LIST AREA 40 - GROUND WATER STORAGE AND DISCHARGE SYSTEM Wright-Patterson Air Force Base			
EQUIPMENT NUMBER	EQUIPMENT NAME	DESCRIPTION	LOCATED ON PFD#
P-4001 A, B	Treated Water Discharge Pumps	600 gpm centrifugal	40-F01
P-4002	Backwash Pump	150 gpm centrifugal	40-F01
T-4001	Treated Water Surge Tank	20,000 gallon	40-F01

APPENDIX B

GROUND WATER MODELING DISCUSSION AND RESULTS

APPENDIX B

CONTENTS

MODEL DESCRIPTION	B.2
OUTPUT FOR CALIBRATED AREA C MODEL	B.5
OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR AREA C MODEL WITH DISCHARGE TO RIVER	B.71
OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR AREA C MODEL WITH DISCHARGE TO LAKES	B.73
OUTPUT FILE FOR CALIBRATED SITE MODEL	B.75
OUTPUT FILE FOR THE SINGLE WELL EXTRACTION SYSTEM FOR SITE MODEL	B.101
OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR SITE MODEL	B.102

APPENDIX B

MODEL DESCRIPTION

INTRODUCTION

In order to effectively evaluate extraction and discharge alternatives for Area C of WPAFB, a ground water modeling effort was undertaken. This modeling effort consisted of two models. The first model was a larger scale model of Area C, and the other was a site-specific model of the Landfill 5 area. Both of these models are described in more detail below.

MODELS

Area C

The Area C model is 6650 feet by 6000 feet, oriented with the western edge of the model being centered on the Huffman Dam. The I,J grid nodes begin in the NW corner with the I values increasing to the east and the J values increasing to the south. Constant head boundaries are used around the model except for the NW and SW corners (north and south of the Huffman Dam) where a no flow condition is imposed due to bedrock outcrops. The model considers the Mad River, Twin Lakes, and Gravel Lake as surface water features. In modeling the aquifer, an isopach map was developed from digitized versions of a topographic map of Area C (USGS map DMA 4163 I SE- Series V852) and a bedrock contour map (Walton and Scudder, 1960). The isopachs were used as aquifer thickness for the model.

The hydraulic properties of the system are consistent with measured data as well as previous modeling efforts. The hydraulic conductivities (K) used were 300 to 1500 gpd/ft², which are within the range reported in Volume 5 as well as previously developed data. In general, the hydraulic conductivity used throughout the model is 1500 gpd/ft² with two areas of lower K. The region immediately surrounding Landfill 5 is given a K of 700 gpd/ft² and the area in the center of Landfill 5 is given a K of 300 gpd/ft². All other values used in the model are consistent with previous work by Geraghty and Miller, 1987.

Site Model

The Area C model was used to determine the regional effects of the extraction system and discharge options. However, to allow more detailed analysis of site-specific parameters under current conditions, a smaller site model was developed from within the boundaries of the Area C model. This model was used to support recommended extraction well placement and production volumes.

The site model is 2800 feet by 2750 feet, oriented with the southern boundary located 250 feet south and the western boundary 500 feet west of Twin Lakes. Once again, the I,J grid nodes begin in the NW corner with the I values increasing to the east and the J values increasing to the south. Landfill 5 is located in the center of the model area. The model is completely surrounded by constant head boundaries since the bedrock outcrops do not extend into the site area. The site model considers Gravel Lake and Twin Lakes as surface water features, but does not include the Mad River because it intercepts the model area only in a very small portion of the NW corner. This model is derived directly from the Area C model and as such uses the same basic information on aquifer thickness.

The hydraulic properties used in the site model are consistent with those used in the Area C model as well. The hydraulic conductivities used are either 700 gpd/ft² or 300 gpd/ft². Once again the central section of Landfill 5 is given a K of 300 gpd/ft² with the outer portions being 700 gpd/ft². The other hydraulic properties are the same as those used in the Area C model.

Calibration Data

It was necessary to use two different sets of data to calibrate the site model and the Area C model. Only regional potentiometric surfaces interpreted from water level measurements for March 1988 (compiled by Engineering Science, 1989) were available - not the actual well point data. Generally, well point data are preferred for calibration but they were not available on a regional basis. Well point data for September 1990 (presented in the Field Investigation Report - Volume 5) were available for Area C, so that data formed the basis for calibration of the local model.

SENSITIVITY ANALYSIS

A brief sensitivity analysis was performed on the site model. Two basic sensitivity runs were performed using varied horizontal and vertical hydraulic conductivity (grid size, porosity, and recharge remained constant). The first sensitivity run considered the central section of Landfill 5 to have a horizontal hydraulic conductivity of 30 gpd/ft² (rather than the calibrated value of 300 gpd/ft²), and a vertical hydraulic conductivity of 3 gpd/ft² (instead of 30 gpd/ft²). The effect of this was to increase the gradient in the central portion of the landfill thereby shifting the outer contours towards the landfill; the shifted contours causes the drawdown cone for the three well pumping system to extend further out towards the lakes and into the landfill, but does not cause an excessive drawdown in the wells. The second sensitivity run considered the outer portion of the model to have a hydraulic conductivity of 100 gpd/ft² (vertical hydraulic conductivity of 10 gpd/ft²) rather than the calibrated value of 700 gpd/ft² (vertical hydraulic conductivity of 70 gpd/ft²). Contradictory to the physical situation, the effect of this was to increase the gradient across the landfill in relation to the gradient in the rest of the model. This increased the drawdown at the wells for the three well extraction system, extending the drawdown cone further out from the well; however, this option did not cause an excessive drawdown in the pumping wells. In both cases the capture zones were sufficient to prevent the off-Base migration of the VOCs.

OUTPUT FOR CALIBRATED AREA C MODEL

MODEL DATA BASE SPECIFICATION:

Number of time increments= 20
Time increment number= 1
Time at end of time increment in days= 1.00000
Time increment in days= 1.00000
Time increment number= 2
Time at end of time increment in days= 2.20000
Time increment in days= 1.20000
Time increment number= 3
Time at end of time increment in days= 3.64000
Time increment in days= 1.44000
Time increment number= 4
Time at end of time increment in days= 5.36800
Time increment in days= 1.72800
Time increment number= 5
Time at end of time increment in days= 7.41600
Time increment in days= 2.04800
Time increment number= 6
Time at end of time increment in days= 9.93000
Time increment in days= 2.51400
Time increment number= 7
Time at end of time increment in days= 12.90000
Time increment in days= 2.97000
Time increment number= 8
Time at end of time increment in days= 16.50000
Time increment in days= 3.60000
Time increment number= 9
Time at end of time increment in days= 20.80000
Time increment in days= 4.30000
Time increment number= 10
Time at end of time increment in days= 26.00000
Time increment in days= 5.20000
Time increment number= 11
Time at end of time increment in days= 32.20000
Time increment in days= 6.20000
Time increment number= 12
Time at end of time increment in days= 39.60000
Time increment in days= 7.40000
Time increment number= 13
Time at end of time increment in days= 48.50000
Time increment in days= 8.90000
Time increment number= 14
Time at end of time increment in days= 59.20000

Time increment in days= 10.70000
 Time increment number= 15
 Time at end of time increment in days= 72.00000
 Time increment in days= 12.80000
 Time increment number= 16
 Time at end of time increment in days= 87.40000
 Time increment in days= 15.40000
 Time increment number= 17
 Time at end of time increment in days= 105.90000
 Time increment in days= 18.50000
 Time increment number= 18
 Time at end of time increment in days= 128.10001
 Time increment in days= 22.20000
 Time increment number= 19
 Time at end of time increment in days= 154.70000
 Time increment in days= 26.59999
 Time increment number= 20
 Time at end of time increment in days= 186.00000
 Time increment in days= 31.30000
 Number of grid columns= 20
 Number of grid rows= 20
 Number of units or layers= 1
 Number of production wells= 0
 Number of injection wells= 0
 Number of time-head observation wells= 0

Column Number	Grid Spacing (ft)
1	300.00
2	300.00
3	300.00
4	250.00
5	250.00
6	250.00
7	250.00
8	250.00
9	250.00
10	250.00
11	250.00
12	250.00
13	250.00
14	250.00
15	350.00
16	450.00
17	450.00
18	500.00
19	500.00

20

750.00

Row Number	Grid Spacing (ft)
1	500.00
2	350.00
3	350.00
4	300.00
5	250.00
6	250.00
7	250.00
8	250.00
9	250.00
10	250.00
11	250.00
12	250.00
13	250.00
14	250.00
15	250.00
16	250.00
17	250.00
18	350.00
19	400.00
20	500.00

Aquifer unit or layer number 1

Hydraulic Conductivity in I-Direction
in gpd/sq ft:

	1	2	3	4	5	6	7	8
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1153.85
4*****	1636.36	1636.36	1363.64	1363.64	1363.64	1363.64	1363.64	1363.64
5*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
6*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
7*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
8*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
9*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
10*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
11*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
12*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
13*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
14*****	1800.00	1800.00	1500.00	1500.00	1500.00	1500.00	700.00	700.00
15	0.00	1800.00	1800.00	1500.00	1500.00	1500.00	700.00	700.00
16	0.00	0.00	0.00	1500.00	1500.00	1500.00	1500.00	1500.00
17	0.00	0.00	0.00	0.00	1250.00	1250.00	1250.00	1250.00

18	0.00	0.00	0.00	0.00	0.00	0.00	1000.00	1000.00
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	9	10	11	12	13	14	15	16
1	0.00	0.00	0.00	*****	*****	*****	*****	*****
2	0.00	1071.43	1071.43	1071.43	1071.43	1071.43	1500.00	1928.57
3	1153.85	1153.85	1153.85	1153.85	1153.85	1153.85	1615.38	2076.92
4	1363.64	1363.64	1363.64	1363.64	1363.64	1363.64	1909.09	2454.55
5	700.00	700.00	700.00	700.00	300.00	300.00	980.00	1260.00
6	700.00	700.00	700.00	700.00	300.00	300.00	980.00	1260.00
7	700.00	700.00	700.00	300.00	300.00	300.00	980.00	1260.00
8	700.00	700.00	700.00	300.00	300.00	300.00	980.00	1260.00
9	700.00	700.00	700.00	300.00	300.00	300.00	980.00	1260.00
10	700.00	700.00	300.00	300.00	300.00	300.00	980.00	1260.00
11	700.00	700.00	300.00	300.00	300.00	300.00	980.00	1260.00
12	700.00	700.00	300.00	300.00	300.00	300.00	980.00	1260.00
13	700.00	700.00	700.00	300.00	300.00	300.00	980.00	1260.00
14	700.00	700.00	700.00	700.00	300.00	300.00	980.00	1260.00
15	700.00	700.00	700.00	700.00	300.00	300.00	980.00	1260.00
16	1500.00	1500.00	1500.00	1500.00	1500.00	1500.00	2100.00	2700.00
17	1250.00	1250.00	1250.00	1250.00	1250.00	1250.00	1750.00	2250.00
18	1000.00	1000.00	1000.00	1000.00	1000.00	1000.00	1400.00	1800.00
19	833.33	833.33	833.33	833.33	833.33	833.33	1166.67	1500.00
20	0.00	0.00	*****	*****	*****	*****	*****	*****

	17	18	19	20
1	*****	*****	*****	*****
2	1928.57	2142.86	2142.86	*****
3	2076.92	2307.69	2307.69	*****
4	2454.55	2727.27	2727.27	*****
5	2700.00	3000.00	3000.00	*****
6	2700.00	3000.00	3000.00	*****
7	2700.00	3000.00	3000.00	*****
8	2700.00	3000.00	3000.00	*****
9	2700.00	3000.00	3000.00	*****
10	2700.00	3000.00	3000.00	*****
11	2700.00	3000.00	3000.00	*****
12	2700.00	3000.00	3000.00	*****
13	2700.00	3000.00	3000.00	*****
14	2700.00	3000.00	3000.00	*****
15	2700.00	3000.00	3000.00	*****
16	2700.00	3000.00	3000.00	*****
17	2250.00	2500.00	2500.00	*****
18	1800.00	2000.00	2000.00	*****
19	1500.00	1666.67	1666.67	*****
20	*****	*****	*****	*****

Hydraulic Conductivity in J-Direction
in gpd/sq ft:

	1	2	3	4	5	6	7	8
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2100.00
4*****	1500.00	1636.36	1800.00	1800.00	1800.00	1800.00	1800.00	1800.00
5*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
6*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
7*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
8*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
9*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
10*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
11*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
12*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
13*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
14*****	1250.00	1363.64	1500.00	1500.00	1500.00	1500.00	700.00	700.00
15	0.00	1250.00	1363.64	1500.00	1500.00	1500.00	700.00	700.00
16	0.00	0.00	0.00	1500.00	1500.00	1500.00	1500.00	1500.00
17	0.00	0.00	0.00	0.00	1500.00	1500.00	1500.00	1500.00
18	0.00	0.00	0.00	0.00	0.00	0.00	2100.00	2100.00
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	9	10	11	12	13	14	15	16
1	0.00	0.00	0.00	*****	*****	*****	*****	*****
2	0.00	2100.00	2100.00	2100.00	2100.00	1750.00	1312.50	1166.67
3	2100.00	2100.00	2100.00	2100.00	2100.00	1750.00	1312.50	1166.67
4	1800.00	1800.00	1800.00	1800.00	1800.00	1500.00	1125.00	1000.00
5	700.00	700.00	700.00	700.00	300.00	250.00	437.50	388.89
6	700.00	700.00	700.00	700.00	300.00	250.00	437.50	388.89
7	700.00	700.00	700.00	300.00	300.00	250.00	437.50	388.89
8	700.00	700.00	700.00	300.00	300.00	250.00	437.50	388.89
9	700.00	700.00	700.00	300.00	300.00	250.00	437.50	388.89
10	700.00	700.00	300.00	300.00	300.00	250.00	437.50	388.89
11	700.00	700.00	300.00	300.00	300.00	250.00	437.50	388.89
12	700.00	700.00	300.00	300.00	300.00	250.00	437.50	388.89
13	700.00	700.00	700.00	300.00	300.00	250.00	437.50	388.89
14	700.00	700.00	700.00	700.00	300.00	250.00	437.50	388.89
15	700.00	700.00	700.00	700.00	300.00	250.00	437.50	388.89
16	1500.00	1500.00	1500.00	1500.00	1500.00	1250.00	937.50	833.33
17	1500.00	1500.00	1500.00	1500.00	1500.00	1250.00	937.50	833.33
18	2100.00	2100.00	2100.00	2100.00	2100.00	1750.00	1312.50	1166.67
19	2400.00	2400.00	2400.00	2400.00	2400.00	2000.00	1500.00	1333.33
20	0.00	0.00	*****	*****	*****	*****	*****	*****
	17	18	19	20				
1	*****	*****	*****	*****				

2	1105.26	1050.00	840.00*****
3	1105.26	1050.00	840.00*****
4	947.37	900.00	720.00*****
5	789.47	750.00	600.00*****
6	789.47	750.00	600.00*****
7	789.47	750.00	600.00*****
8	789.47	750.00	600.00*****
9	789.47	750.00	600.00*****
10	789.47	750.00	600.00*****
11	789.47	750.00	600.00*****
12	789.47	750.00	600.00*****
13	789.47	750.00	600.00*****
14	789.47	750.00	600.00*****
15	789.47	750.00	600.00*****
16	789.47	750.00	600.00*****
17	789.47	750.00	600.00*****
18	1105.26	1050.00	840.00*****
19	1263.16	1200.00	960.00*****
20	*****		

Aquifer Thickness in ft:

	1	2	3	4	5	6	7	8
1	150.00	150.00	150.00	150.00	150.00	150.00	150.00	150.00
2	150.00	150.00	150.00	150.00	150.00	150.00	150.00	150.00
3	150.00	150.00	150.00	150.00	150.00	150.00	150.00	59.00
4	27.00	29.00	32.00	36.00	41.00	50.00	59.00	81.00
5	41.00	41.00	45.00	50.00	59.00	68.00	81.00	86.00
6	54.00	59.00	59.00	63.00	77.00	81.00	86.00	90.00
7	63.00	63.00	77.00	81.00	81.00	86.00	90.00	90.00
8	86.00	79.00	81.00	84.00	86.00	86.00	90.00	90.00
9	72.00	81.00	90.00	90.00	90.00	86.00	86.00	86.00
10	63.00	72.00	77.00	72.00	75.00	77.00	79.00	79.00
11	72.00	72.00	77.00	72.00	72.00	72.00	72.00	72.00
12	63.00	72.00	63.00	63.00	63.00	63.00	63.00	68.00
13	50.00	45.00	48.00	50.00	50.00	54.00	54.00	59.00
14	54.00	54.00	54.00	54.00	59.00	59.00	63.00	64.00
15	150.00	54.00	52.00	50.00	48.00	45.00	50.00	54.00
16	150.00	150.00	150.00	54.00	52.00	50.00	48.00	42.00
17	150.00	150.00	150.00	150.00	27.00	38.00	45.00	46.00
18	150.00	150.00	150.00	150.00	150.00	150.00	9.00	9.00
19	150.00	150.00	150.00	150.00	150.00	150.00	150.00	150.00
20	150.00	150.00	150.00	150.00	150.00	150.00	150.00	150.00
	9	10	11	12	13	14	15	16
1	150.00	150.00	150.00	27.00	32.00	35.00	27.00	27.00
2	150.00	54.00	59.00	63.00	59.00	59.00	45.00	39.00
3	63.00	81.00	90.00	95.00	99.00	99.00	99.00	97.00

4	86.00	90.00	99.00	104.00	104.00	108.00	104.00	104.00
5	86.00	95.00	104.00	108.00	108.00	108.00	106.00	106.00
6	95.00	99.00	104.00	108.00	113.00	113.00	117.00	117.00
7	95.00	104.00	104.00	108.00	113.00	117.00	117.00	117.00
8	90.00	90.00	99.00	99.00	104.00	108.00	113.00	117.00
9	86.00	93.00	90.00	90.00	90.00	90.00	90.00	104.00
10	77.00	83.00	86.00	86.00	86.00	86.00	86.00	86.00
11	72.00	72.00	72.00	72.00	72.00	77.00	77.00	81.00
12	72.00	77.00	75.00	77.00	75.00	77.00	81.00	81.00
13	63.00	68.00	68.00	69.00	69.00	70.00	72.00	75.00
14	65.00	66.00	67.00	68.00	68.00	68.00	70.00	72.00
15	59.00	61.00	63.00	65.00	68.00	68.00	70.00	72.00
16	47.00	54.00	57.00	60.00	62.00	63.00	66.00	68.00
17	50.00	52.00	54.00	58.00	60.00	63.00	66.00	68.00
18	45.00	48.00	50.00	54.00	56.00	58.00	59.00	63.00
19	9.00	4.00	45.00	47.00	53.00	59.00	54.00	61.00
20	150.00	150.00	9.00	27.00	45.00	47.00	50.00	54.00

	17	18	19	20
1	27.00	36.00	63.00	81.00
2	56.00	68.00	90.00	95.00
3	95.00	95.00	99.00	108.00
4	106.00	108.00	110.00	113.00
5	104.00	105.00	110.00	113.00
6	117.00	117.00	119.00	123.00
7	117.00	122.00	126.00	126.00
8	122.00	124.00	126.00	135.00
9	117.00	131.00	142.00	144.00
10	88.00	99.00	135.00	149.00
11	82.00	86.00	113.00	135.00
12	86.00	86.00	90.00	122.00
13	79.00	82.00	86.00	108.00
14	75.00	79.00	95.00	99.00
15	77.00	81.00	81.00	90.00
16	72.00	75.00	81.00	86.00
17	72.00	77.00	81.00	86.00
18	68.00	72.00	77.00	86.00
19	68.00	72.00	77.00	86.00
20	59.00	63.00	68.00	81.00

Aquifer top elevation in ft:

	1	2	3	4	5	6	7	8
1	800.00	800.00	800.00	800.00	800.00	800.00	800.00	800.00
2	800.00	800.00	800.00	800.00	800.00	800.00	800.00	800.00
3	800.00	800.00	800.00	800.00	800.00	800.00	800.00	781.00
4	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
5	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00

6	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
7	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
8	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
9	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
10	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
11	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
12	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
13	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
14	777.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
15	800.00	777.00	779.00	780.00	780.00	780.00	781.00	781.00
16	800.00	800.00	800.00	780.00	780.00	780.00	781.00	781.00
17	800.00	800.00	800.00	800.00	780.00	780.00	781.00	781.00
18	800.00	800.00	800.00	800.00	800.00	800.00	781.00	781.00
19	800.00	800.00	800.00	800.00	800.00	800.00	800.00	800.00
20	800.00	800.00	800.00	800.00	800.00	800.00	800.00	800.00

	9	10	11	12	13	14	15	16
1	800.00	800.00	800.00	783.00	784.00	784.00	785.00	785.00
2	800.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
3	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
4	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
5	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
6	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
7	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
8	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
9	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
10	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
11	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
12	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
13	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
14	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
15	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
16	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
17	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
18	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
19	782.00	782.00	783.00	783.00	784.00	784.00	785.00	785.00
20	800.00	800.00	783.00	783.00	784.00	784.00	785.00	785.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	786.00	786.00	787.00	788.00
4	786.00	786.00	787.00	788.00
5	786.00	786.00	787.00	788.00
6	786.00	786.00	787.00	788.00
7	786.00	786.00	787.00	788.00
8	786.00	786.00	787.00	788.00
9	786.00	786.00	787.00	788.00

10	786.00	786.00	787.00	788.00
11	786.00	786.00	787.00	788.00
12	786.00	786.00	787.00	788.00
13	786.00	786.00	787.00	788.00
14	786.00	786.00	787.00	788.00
15	786.00	786.00	787.00	788.00
16	786.00	786.00	787.00	788.00
17	786.00	786.00	787.00	788.00
18	786.00	786.00	787.00	788.00
19	786.00	786.00	787.00	788.00
20	786.00	786.00	787.00	788.00

Aquifer base elevation in ft:

	1	2	3	4	5	6	7	8
1	650.00	650.00	650.00	650.00	650.00	650.00	650.00	650.00
2	650.00	650.00	650.00	650.00	650.00	650.00	650.00	650.00
3	650.00	650.00	650.00	650.00	650.00	650.00	650.00	722.00
4	750.00	748.00	747.00	744.00	739.00	730.00	722.00	700.00
5	736.00	736.00	734.00	730.00	721.00	712.00	700.00	695.00
6	723.00	718.00	720.00	717.00	703.00	699.00	695.00	691.00
7	714.00	714.00	702.00	699.00	699.00	694.00	691.00	691.00
8	691.00	698.00	698.00	696.00	694.00	694.00	691.00	691.00
9	705.00	696.00	689.00	690.00	690.00	694.00	695.00	695.00
10	714.00	705.00	702.00	708.00	705.00	703.00	702.00	702.00
11	705.00	705.00	702.00	708.00	708.00	708.00	709.00	709.00
12	714.00	705.00	716.00	717.00	717.00	717.00	718.00	713.00
13	727.00	732.00	731.00	730.00	730.00	726.00	727.00	722.00
14	723.00	723.00	725.00	726.00	721.00	721.00	718.00	717.00
15	650.00	723.00	727.00	730.00	732.00	735.00	731.00	727.00
16	650.00	650.00	650.00	726.00	728.00	730.00	733.00	739.00
17	650.00	650.00	650.00	650.00	753.00	742.00	736.00	735.00
18	650.00	650.00	650.00	650.00	650.00	650.00	772.00	772.00
19	650.00	650.00	650.00	650.00	650.00	650.00	650.00	650.00
20	650.00	650.00	650.00	650.00	650.00	650.00	650.00	650.00
	9	10	11	12	13	14	15	16
1	650.00	650.00	650.00	756.00	752.00	749.00	758.00	758.00
2	650.00	728.00	724.00	720.00	725.00	725.00	740.00	746.00
3	719.00	701.00	693.00	688.00	685.00	685.00	686.00	688.00
4	696.00	692.00	684.00	679.00	680.00	676.00	681.00	681.00
5	696.00	687.00	679.00	675.00	676.00	676.00	679.00	679.00
6	687.00	683.00	679.00	675.00	671.00	671.00	668.00	668.00
7	687.00	678.00	679.00	675.00	671.00	667.00	668.00	668.00
8	692.00	692.00	684.00	684.00	680.00	676.00	672.00	668.00
9	696.00	689.00	693.00	693.00	694.00	694.00	695.00	681.00
10	705.00	699.00	697.00	697.00	698.00	698.00	699.00	699.00
11	710.00	710.00	711.00	711.00	712.00	707.00	708.00	704.00

12	710.00	705.00	708.00	706.00	709.00	707.00	704.00	704.00
13	719.00	714.00	715.00	714.00	715.00	714.00	713.00	710.00
14	717.00	716.00	716.00	715.00	716.00	716.00	715.00	713.00
15	723.00	721.00	720.00	718.00	716.00	716.00	715.00	713.00
16	735.00	728.00	726.00	723.00	722.00	721.00	719.00	717.00
17	732.00	730.00	729.00	725.00	724.00	721.00	719.00	717.00
18	737.00	734.00	733.00	729.00	728.00	726.00	726.00	722.00
19	773.00	778.00	738.00	736.00	731.00	725.00	731.00	724.00
20	650.00	650.00	774.00	756.00	739.00	737.00	735.00	731.00

	17	18	19	20
1	759.00	750.00	724.00	707.00
2	730.00	718.00	697.00	693.00
3	691.00	691.00	688.00	680.00
4	680.00	678.00	677.00	675.00
5	682.00	681.00	677.00	675.00
6	669.00	669.00	668.00	665.00
7	669.00	664.00	661.00	662.00
8	664.00	662.00	661.00	653.00
9	669.00	655.00	645.00	644.00
10	698.00	687.00	652.00	639.00
11	704.00	700.00	674.00	653.00
12	700.00	700.00	697.00	666.00
13	707.00	704.00	701.00	680.00
14	711.00	707.00	692.00	689.00
15	709.00	705.00	706.00	698.00
16	714.00	711.00	706.00	702.00
17	714.00	709.00	706.00	702.00
18	718.00	714.00	710.00	702.00
19	718.00	714.00	710.00	702.00
20	727.00	723.00	719.00	707.00

Initial head elevation in ft:

	1	2	3	4	5	6	7	8
1	770.00	770.00	770.00	770.00	770.00	770.00	770.00	770.00
2	770.00	770.00	770.00	770.00	770.00	770.00	770.00	770.00
3	770.00	770.00	770.00	770.00	770.00	770.00	770.00	775.00
4	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
5	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
6	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
7	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
8	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
9	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
10	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
11	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
12	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
13	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00

14	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
15	770.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
16	770.00	770.00	770.00	775.00	775.00	775.00	775.00	775.00
17	770.00	770.00	770.00	770.00	775.00	775.00	775.00	775.00
18	770.00	770.00	770.00	770.00	770.00	770.00	775.00	775.00
19	770.00	770.00	770.00	770.00	770.00	770.00	770.00	770.00
20	770.00	770.00	770.00	770.00	770.00	770.00	770.00	770.00
	9	10	11	12	13	14	15	16
1	770.00	770.00	770.00	779.00	780.00	782.00	785.00	785.50
2	770.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
3	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
4	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
5	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
6	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
7	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
8	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
9	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
10	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
11	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
12	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
13	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
14	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
15	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
16	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
17	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
18	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
19	775.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
20	770.00	770.00	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	775.00	775.00	775.00	788.00				
3	775.00	775.00	775.00	788.00				
4	775.00	775.00	775.00	788.00				
5	775.00	775.00	775.00	789.00				
6	775.00	775.00	775.00	789.00				
7	775.00	775.00	775.00	790.00				
8	775.00	775.00	775.00	790.00				
9	775.00	775.00	775.00	790.00				
10	775.00	775.00	775.00	790.00				
11	775.00	775.00	775.00	791.00				
12	775.00	775.00	775.00	791.00				
13	775.00	775.00	775.00	791.00				
14	775.00	775.00	775.00	792.00				
15	775.00	775.00	775.00	792.00				
16	775.00	775.00	775.00	793.00				
17	775.00	775.00	775.00	793.00				

18	775.00	775.00	775.00	793.00
19	775.00	775.00	775.00	794.00
20	795.00	795.00	795.00	795.00

Transmissivity in I-Direction in gpd/ft:

	1	2	3	4	5	6	7	8
1	0.	0.	0.	0.	0.	0.	0.	0.
2	0.	0.	0.	0.	0.	0.	0.	0.
3	0.	0.	0.	0.	0.	0.	0.	68077.
4*****	47455.	52364.	49091.	55909.	68182.	80455.	110455.	
5*****	73800.	81000.	75000.	88500.	102000.	56700.	60200.	
6*****	106200.	106200.	94500.	115500.	121500.	60200.	63000.	
7*****	113400.	138600.	121500.	121500.	129000.	63000.	63000.	
8*****	142200.	145800.	126000.	129000.	129000.	63000.	63000.	
9*****	145800.	162000.	135000.	135000.	129000.	60200.	60200.	
10*****	129600.	138600.	108000.	112500.	115500.	55300.	55300.	
11*****	129600.	138600.	108000.	108000.	108000.	50400.	50400.	
12*****	129600.	113400.	94500.	94500.	94500.	44100.	47600.	
13*****	81000.	86400.	75000.	75000.	81000.	37800.	41300.	
14*****	97200.	97200.	81000.	88500.	88500.	44100.	44800.	
15	0.	97200.	93600.	75000.	72000.	67500.	35000.	37800.
16	0.	0.	0.	81000.	78000.	75000.	72000.	63000.
17	0.	0.	0.	0.	33750.	47500.	56250.	57500.
18	0.	0.	0.	0.	0.	0.	9000.	9000.
19	0.	0.	0.	0.	0.	0.	0.	0.
20	0.	0.	0.	0.	0.	0.	0.	0.
	9	10	11	12	13	14	15	16
1	0.	0.	0.	*****				
2	0.	57857.	63214.	67500.	63214.	63214.	67500.	75214.
3	72692.	93462.	103846.	109615.	114231.	114231.	159923.	201462.
4	117273.	122727.	135000.	141818.	141818.	147273.	198545.	255273.
5	60200.	66500.	72800.	75600.	32400.	32400.	103880.	133560.
6	66500.	69300.	72800.	75600.	33900.	33900.	114660.	147420.
7	66500.	72800.	72800.	32400.	33900.	35100.	114660.	147420.
8	63000.	63000.	69300.	29700.	31200.	32400.	110740.	147420.
9	60200.	65100.	63000.	27000.	27000.	27000.	88200.	131040.
10	53900.	58100.	25800.	25800.	25800.	25800.	84280.	108360.
11	50400.	50400.	21600.	21600.	21600.	23100.	75460.	102060.
12	50400.	53900.	22500.	23100.	22500.	23100.	79380.	102060.
13	44100.	47600.	47600.	20700.	20700.	21000.	70560.	94500.
14	45500.	46200.	46900.	47600.	20400.	20400.	68600.	90720.
15	41300.	42700.	44100.	45500.	20400.	20400.	68600.	90720.
16	70500.	81000.	85500.	90000.	93000.	94500.	138600.	183600.
17	62500.	65000.	67500.	72500.	75000.	78750.	115500.	153000.
18	45000.	48000.	50000.	54000.	56000.	58000.	82600.	113400.
19	7500.	3333.	37500.	39167.	44167.	49167.	63000.	91500.

20	0.	0.	*****		
	17	18	19	20	
1	*****				
2	108000.	145714.	192857.	*****	
3	197308.	219231.	228462.	*****	
4	260182.	294545.	300000.	*****	
5	280800.	315000.	330000.	*****	
6	315900.	351000.	357000.	*****	
7	315900.	366000.	378000.	*****	
8	329400.	372000.	378000.	*****	
9	315900.	393000.	426000.	*****	
10	237600.	297000.	405000.	*****	
11	221400.	258000.	339000.	*****	
12	232200.	258000.	270000.	*****	
13	213300.	246000.	258000.	*****	
14	202500.	237000.	285000.	*****	
15	207900.	243000.	243000.	*****	
16	194400.	225000.	243000.	*****	
17	162000.	192500.	202500.	*****	
18	122400.	144000.	154000.	*****	
19	102000.	120000.	128333.	*****	
20	*****				

Transmissivity in J-Direction in gpd/ft:

	1	2	3	4	5	6	7	8
1	0.	0.	0.	0.	0.	0.	0.	0.
2	0.	0.	0.	0.	0.	0.	0.	0.
3	0.	0.	0.	0.	0.	0.	0.	123900.
4	*****	43500.	52364.	64800.	73800.	90000.	106200.	145800.
5	*****	51250.	61364.	75000.	88500.	102000.	56700.	60200.
6	*****	73750.	80455.	94500.	115500.	121500.	60200.	63000.
7	*****	78750.	105000.	121500.	121500.	129000.	63000.	63000.
8	*****	98750.	110455.	126000.	129000.	129000.	63000.	63000.
9	*****	101250.	122727.	135000.	135000.	129000.	60200.	60200.
10	*****	90000.	105000.	108000.	112500.	115500.	55300.	55300.
11	*****	90000.	105000.	108000.	108000.	108000.	50400.	50400.
12	*****	90000.	85909.	94500.	94500.	94500.	44100.	47600.
13	*****	56250.	65455.	75000.	75000.	81000.	37800.	41300.
14	*****	67500.	73636.	81000.	88500.	88500.	44100.	44800.
15	0.	67500.	70909.	75000.	72000.	67500.	35000.	37800.
16	0.	0.	0.	81000.	78000.	75000.	72000.	63000.
17	0.	0.	0.	0.	40500.	57000.	67500.	69000.
18	0.	0.	0.	0.	0.	0.	18900.	18900.
19	0.	0.	0.	0.	0.	0.	0.	0.
20	0.	0.	0.	0.	0.	0.	0.	0.
	9	10	11	12	13	14	15	16

1	0.	0.	0.	*****				
2	0.	113400.	123900.	132300.	123900.	103250.	59063.	45500.
3	132300.	170100.	189000.	199500.	207900.	173250.	129938.	113167.
4	154800.	162000.	178200.	187200.	187200.	162000.	117000.	104000.
5	60200.	66500.	72800.	75600.	32400.	27000.	46375.	41222.
6	66500.	69300.	72800.	75600.	33900.	28250.	51188.	45500.
7	66500.	72800.	72800.	32400.	33900.	29250.	51188.	45500.
8	63000.	63000.	69300.	29700.	31200.	27000.	49438.	45500.
9	60200.	65100.	63000.	27000.	27000.	22500.	39375.	40444.
10	53900.	58100.	25800.	25800.	25800.	21500.	37625.	33444.
11	50400.	50400.	21600.	21600.	21600.	19250.	33688.	31500.
12	50400.	53900.	22500.	23100.	22500.	19250.	35438.	31500.
13	44100.	47600.	47600.	20700.	20700.	17500.	31500.	29167.
14	45500.	46200.	46900.	47600.	20400.	17000.	30625.	28000.
15	41300.	42700.	44100.	45500.	20400.	17000.	30625.	28000.
16	70500.	81000.	85500.	90000.	93000.	78750.	61875.	56667.
17	75000.	78000.	81000.	87000.	90000.	78750.	61875.	56667.
18	94500.	100800.	105000.	113400.	117600.	101500.	77438.	73500.
19	21600.	9600.	108000.	112800.	127200.	118000.	81000.	81333.
20	0.	0.	*****					
	17	18	19	20				

1	*****		
2	61895.	71400.	75600.*****
3	105000.	99750.	83160.*****
4	100421.	97200.	79200.*****
5	82105.	78750.	66000.*****
6	92368.	87750.	71400.*****
7	92368.	91500.	75600.*****
8	96316.	93000.	75600.*****
9	92368.	98250.	85200.*****
10	69474.	74250.	81000.*****
11	64737.	64500.	67800.*****
12	67895.	64500.	54000.*****
13	62368.	61500.	51600.*****
14	59211.	59250.	57000.*****
15	60789.	60750.	48600.*****
16	56842.	56250.	48600.*****
17	56842.	57750.	48600.*****
18	75158.	75600.	64680.*****
19	85895.	86400.	73920.*****
20	*****		

Aquitard vertical hydraulic conductivity
in gpd/sq ft:

	1	2	3	4	5	6	7	8
1	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000	0.000000

6	0.000000	0.000000	0.000000	0.000000
7	0.000000	0.000000	0.000000	0.000000
8	0.000000	0.000000	0.000000	0.000000
9	0.000000	0.000000	0.000000	0.000000
10	0.000000	0.000000	0.000000	0.000000
11	0.000000	0.000000	0.000000	0.000000
12	0.000000	0.000000	0.000000	0.000000
13	0.000000	0.000000	0.000000	0.000000
14	0.000000	0.000000	0.000000	0.000000
15	0.000000	0.000000	0.000000	0.000000
16	0.000000	0.000000	0.000000	0.000000
17	0.000000	0.000000	0.000000	0.000000
18	0.000000	0.000000	0.000000	0.000000
19	0.000000	0.000000	0.000000	0.000000
20	0.000000	0.000000	0.000000	0.000000

Aquitard thickness in ft:

	1	2	3	4	5	6	7	8
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	9	10	11	12	13	14	15	16
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	17	18	19	20
1	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00
12	0.00	0.00	0.00	0.00
13	0.00	0.00	0.00	0.00
14	0.00	0.00	0.00	0.00
15	0.00	0.00	0.00	0.00
16	0.00	0.00	0.00	0.00
17	0.00	0.00	0.00	0.00
18	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00
20	0.00	0.00	0.00	0.00

Simulation factor in gpd/ft:

	1	2	3	4	5	6	7	8
1	0.	0.	0.	0.	0.	0.	0.	0.
2	0.	0.	0.	0.	0.	0.	0.	0.
3	0.	0.	0.	0.	0.	0.	0.	0.
4	0.	0.	0.	0.	0.	0.	0.	0.
5	0.	0.	0.	0.	0.	0.	0.	0.
6	0.	0.	0.	0.	0.	0.	0.	0.
7	0.	0.	0.	0.	0.	0.	0.	0.
8	0.	0.	0.	0.	0.	0.	0.	0.
9	0.	0.	0.	0.	0.	0.	0.	0.

10	0.	0.	0.	0.	0.	0.	0.	0.
11	0.	0.	0.	0.	0.	0.	0.	0.
12	0.	0.	0.	0.	0.	0.	0.	0.
13	0.	0.	0.	0.	0.	0.	0.	0.
14	0.	0.	0.	0.	0.	0.	0.	0.
15	0.	0.	0.	0.	0.	0.	0.	0.
16	0.	0.	0.	0.	0.	0.	0.	0.
17	0.	0.	0.	0.	0.	0.	0.	0.
18	0.	0.	0.	0.	0.	0.	0.	0.
19	0.	0.	0.	0.	0.	0.	0.	0.
20	0.	0.	0.	0.	0.	0.	0.	0.
	9	10	11	12	13	14	15	16
1	0.	0.	0.	0.	0.	0.	0.	0.
2	0.	0.	0.	0.	0.	0.	0.	0.
3	0.	0.	0.	0.	0.	0.	0.	0.
4	0.	0.	0.	0.	0.	0.	0.	0.
5	0.	0.	0.	0.	0.	0.	0.	0.
6	0.	0.	0.	0.	0.	0.	0.	0.
7	0.	0.	0.	0.	0.	0.	0.	0.
8	0.	0.	0.	0.	0.	0.	0.	0.
9	0.	0.	0.	0.	0.	0.	0.	0.
10	0.	0.	0.	0.	0.	0.	0.	0.
11	0.	0.	0.	0.	0.	0.	0.	0.
12	0.	0.	0.	0.	0.	0.	0.	0.
13	0.	0.	0.	0.	0.	0.	0.	0.
14	0.	0.	0.	0.	0.	0.	0.	0.
15	0.	0.	0.	0.	0.	0.	0.	0.
16	0.	0.	0.	0.	0.	0.	0.	0.
17	0.	0.	0.	0.	0.	0.	0.	0.
18	0.	0.	0.	0.	0.	0.	0.	0.
19	0.	0.	0.	0.	0.	0.	0.	0.
20	0.	0.	0.	0.	0.	0.	0.	0.
	17	18	19	20				
1	0.	0.	0.	0.				
2	0.	0.	0.	0.				
3	0.	0.	0.	0.				
4	0.	0.	0.	0.				
5	0.	0.	0.	0.				
6	0.	0.	0.	0.				
7	0.	0.	0.	0.				
8	0.	0.	0.	0.				
9	0.	0.	0.	0.				
10	0.	0.	0.	0.				
11	0.	0.	0.	0.				
12	0.	0.	0.	0.				
13	0.	0.	0.	0.				

14	0.	0.	0.	0.
15	0.	0.	0.	0.
16	0.	0.	0.	0.
17	0.	0.	0.	0.
18	0.	0.	0.	0.
19	0.	0.	0.	0.
20	0.	0.	0.	0.

Aquifer specific yield factor as a decimal:

	1	2	3	4	5	6	7	8
1	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
2	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
3	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
4	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
5	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
6	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
7	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
8	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
9	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
10	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
11	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
12	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
13	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
14	*****	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
15	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
16	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
17	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
18	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
19	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
20	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
	9	10	11	12	13	14	15	16
1	0.200000	0.200000	0.200000	*****	*****	*****	*****	*****
2	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
3	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
4	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
5	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
6	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
7	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
8	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
9	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
10	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
11	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
12	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
13	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
14	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
15	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000

16 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000
 17 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000
 18 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000
 19 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000 0.200000
 20 0.200000 0.200000*****

17 18 19 20

1*****
 2 0.200000 0.200000 0.200000*****
 3 0.200000 0.200000 0.200000*****
 4 0.200000 0.200000 0.200000*****
 5 0.200000 0.200000 0.200000*****
 6 0.200000 0.200000 0.200000*****
 7 0.200000 0.200000 0.200000*****
 8 0.200000 0.200000 0.200000*****
 9 0.200000 0.200000 0.200000*****
 10 0.200000 0.200000 0.200000*****
 11 0.200000 0.200000 0.200000*****
 12 0.200000 0.200000 0.200000*****
 13 0.200000 0.200000 0.200000*****
 14 0.200000 0.200000 0.200000*****
 15 0.200000 0.200000 0.200000*****
 16 0.200000 0.200000 0.200000*****
 17 0.200000 0.200000 0.200000*****
 18 0.200000 0.200000 0.200000*****
 19 0.200000 0.200000 0.200000*****
 20*****

Areal recharge rate in inches per year= 7.500

Stream node number= 1

I-coordinate of stream node= 2

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 80.00

Streambed length simulated at node in ft= 300.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000

Stream surface elevation in ft= 777.00

Streambed base elevation in ft= 769.00

Stream node number= 2

I-coordinate of stream node= 2

J-coordinate of stream node= 13

Streambed width simulated at node in ft= 150.00

Streambed length simulated at node in ft= 300.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 777.00
Streambed base elevation in ft= 769.00

Stream node number= 3
I-coordinate of stream node= 3
J-coordinate of stream node= 13
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 140.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 778.00
Streambed base elevation in ft= 770.00

Stream node number= 4
I-coordinate of stream node= 3
J-coordinate of stream node= 12
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 150.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 778.00
Streambed base elevation in ft= 770.00

Stream node number= 5
I-coordinate of stream node= 3
J-coordinate of stream node= 11
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 150.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 778.00
Streambed base elevation in ft= 770.00

Stream node number= 6
I-coordinate of stream node= 3
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 90.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 778.00

Streambed base elevation in ft= 770.00

Stream node number= 7

I-coordinate of stream node= 4

J-coordinate of stream node= 10

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 90.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000

Stream surface elevation in ft= 779.00

Streambed base elevation in ft= 771.00

Stream node number= 8

I-coordinate of stream node= 4

J-coordinate of stream node= 9

Streambed width simulated at node in ft= 180.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000

Stream surface elevation in ft= 779.00

Streambed base elevation in ft= 771.00

Stream node number= 9

I-coordinate of stream node= 4

J-coordinate of stream node= 8

Streambed width simulated at node in ft= 80.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000

Stream surface elevation in ft= 779.00

Streambed base elevation in ft= 771.00

Stream node number= 10

I-coordinate of stream node= 5

J-coordinate of stream node= 8

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 3.000

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 772.00

Stream node number= 11
I-coordinate of stream node= 6
J-coordinate of stream node= 8
Streambed width simulated at node in ft= 160.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 772.00

Stream node number= 12
I-coordinate of stream node= 6
J-coordinate of stream node= 7
Streambed width simulated at node in ft= 100.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 772.00

Stream node number= 13
I-coordinate of stream node= 7
J-coordinate of stream node= 7
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 772.00

Stream node number= 14
I-coordinate of stream node= 8
J-coordinate of stream node= 6
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 772.00

Stream node number= 15
I-coordinate of stream node= 8

J-coordinate of stream node= 5
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 773.00

Stream node number= 16
I-coordinate of stream node= 9
J-coordinate of stream node= 5
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 773.00

Stream node number= 17
I-coordinate of stream node= 9
J-coordinate of stream node= 4
Streambed width simulated at node in ft= 160.00
Streambed length simulated at node in ft= 300.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 773.00

Stream node number= 18
I-coordinate of stream node= 10
J-coordinate of stream node= 4
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 300.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 773.00

Stream node number= 19
I-coordinate of stream node= 10
J-coordinate of stream node= 3
Streambed width simulated at node in ft= 100.00

Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 782.00
Streambed base elevation in ft= 774.00

Stream node number= 20
I-coordinate of stream node= 11
J-coordinate of stream node= 3
Streambed width simulated at node in ft= 150.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 782.00
Streambed base elevation in ft= 774.00

Stream node number= 21
I-coordinate of stream node= 12
J-coordinate of stream node= 3
Streambed width simulated at node in ft= 80.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 783.00
Streambed base elevation in ft= 775.00

Stream node number= 22
I-coordinate of stream node= 12
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 100.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 783.00
Streambed base elevation in ft= 775.00

Stream node number= 23
I-coordinate of stream node= 13
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 150.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 784.00
Streambed base elevation in ft= 776.00

Stream node number= 24
I-coordinate of stream node= 14
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 200.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 784.00
Streambed base elevation in ft= 776.00

Stream node number= 25
I-coordinate of stream node= 15
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 175.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 785.00
Streambed base elevation in ft= 777.00

Stream node number= 26
I-coordinate of stream node= 16
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 120.00
Streambed length simulated at node in ft= 450.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 3.000
Stream surface elevation in ft= 785.00
Streambed base elevation in ft= 777.00

Stream node number= 27
I-coordinate of stream node= 9
J-coordinate of stream node= 13
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 125.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00
Streambed base elevation in ft= 770.00

Stream node number= 28

I-coordinate of stream node= 9

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 29

I-coordinate of stream node= 10

J-coordinate of stream node= 13

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 125.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 30

I-coordinate of stream node= 10

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 125.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 31

I-coordinate of stream node= 11

J-coordinate of stream node= 13

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 32

I-coordinate of stream node= 11

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 33

I-coordinate of stream node= 12

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 125.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 34

I-coordinate of stream node= 14

J-coordinate of stream node= 14

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 170.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 35

I-coordinate of stream node= 14

J-coordinate of stream node= 15

Streambed width simulated at node in ft= 130.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 790.00

Streambed base elevation in ft= 770.00

Stream node number= 36

I-coordinate of stream node= 15

J-coordinate of stream node= 13
Streambed width simulated at node in ft= 160.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 790.00
Streambed base elevation in ft= 770.00

Stream node number= 37
I-coordinate of stream node= 15
J-coordinate of stream node= 14
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 790.00
Streambed base elevation in ft= 770.00

Stream node number= 38
I-coordinate of stream node= 15
J-coordinate of stream node= 15
Streambed width simulated at node in ft= 150.00
Streambed length simulated at node in ft= 350.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 790.00
Streambed base elevation in ft= 770.00

Stream node number= 39
I-coordinate of stream node= 3
J-coordinate of stream node= 5
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 300.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 40
I-coordinate of stream node= 3
J-coordinate of stream node= 6
Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 300.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 41
I-coordinate of stream node= 3
J-coordinate of stream node= 7
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 300.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 42
I-coordinate of stream node= 3
J-coordinate of stream node= 8
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 150.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 43
I-coordinate of stream node= 4
J-coordinate of stream node= 4
Streambed width simulated at node in ft= 300.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 44
I-coordinate of stream node= 4
J-coordinate of stream node= 5
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 45
I-coordinate of stream node= 4
J-coordinate of stream node= 6
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 46
I-coordinate of stream node= 4
J-coordinate of stream node= 7
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 47
I-coordinate of stream node= 4
J-coordinate of stream node= 8
Streambed width simulated at node in ft= 80.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 48
I-coordinate of stream node= 5
J-coordinate of stream node= 4
Streambed width simulated at node in ft= 300.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 49

I-coordinate of stream node= 5

J-coordinate of stream node= 5

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 50

I-coordinate of stream node= 5

J-coordinate of stream node= 6

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 51

I-coordinate of stream node= 5

J-coordinate of stream node= 7

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 52

I-coordinate of stream node= 6

J-coordinate of stream node= 4

Streambed width simulated at node in ft= 200.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 53

I-coordinate of stream node= 6

J-coordinate of stream node= 5

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 54

I-coordinate of stream node= 6

J-coordinate of stream node= 6

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 55

I-coordinate of stream node= 7

J-coordinate of stream node= 4

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 56

I-coordinate of stream node= 7

J-coordinate of stream node= 5

Streambed width simulated at node in ft= 250.00

Streambed length simulated at node in ft= 250.00

Streambed thickness simulated at node in ft= 1.00

Hydraulic conductivity of streambed

simulated at node in gpd/sq ft= 0.052

Stream surface elevation in ft= 780.00

Streambed base elevation in ft= 760.00

Stream node number= 57

I-coordinate of stream node= 8

J-coordinate of stream node= 3
Streambed width simulated at node in ft= 350.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 58
I-coordinate of stream node= 8
J-coordinate of stream node= 4
Streambed width simulated at node in ft= 240.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 59
I-coordinate of stream node= 9
J-coordinate of stream node= 3
Streambed width simulated at node in ft= 350.00
Streambed length simulated at node in ft= 150.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 60
I-coordinate of stream node= 10
J-coordinate of stream node= 2
Streambed width simulated at node in ft= 165.00
Streambed length simulated at node in ft= 225.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 1.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.01	770.01	770.01	770.01	770.01	770.01	770.01	770.01
2	770.01	770.01	770.01	770.01	770.01	770.01	770.01	770.01
3	770.01	770.01	770.01	770.01	770.01	770.01	770.01	775.85
4	775.00	775.00	775.07	775.19	775.26	775.37	775.66	776.31
5	775.00	775.00	775.16	775.26	775.37	775.53	775.78	777.18
6	775.00	775.00	775.20	775.38	775.59	775.85	776.09	777.41
7	775.00	775.00	775.28	775.59	776.05	776.70	777.29	776.01
8	775.00	775.00	775.37	775.93	776.97	776.81	776.06	775.44
9	775.00	775.00	775.52	776.35	776.00	775.77	775.47	775.20
10	775.00	775.00	775.78	776.06	775.57	775.36	775.21	775.09
11	775.00	775.00	775.91	775.54	775.30	775.18	775.10	775.04
12	775.00	775.00	775.92	775.36	775.17	775.09	775.05	775.03
13	775.00	775.00	775.80	775.21	775.07	775.04	775.03	775.04
14	775.00	775.00	774.93	774.94	774.97	774.99	775.01	775.06
15	775.00	773.85	773.93	774.55	774.80	774.90	774.97	775.01
16	770.01	772.15	772.16	773.87	774.50	774.68	774.87	774.96
17	770.01	770.01	770.01	772.13	773.75	773.88	774.72	774.92
18	770.01	770.01	770.01	770.01	771.22	771.45	774.50	774.56
19	770.01	770.01	770.01	770.01	770.01	770.01	770.48	770.49
20	770.01	770.01	770.01	770.01	770.01	770.01	770.01	770.01
	9	10	11	12	13	14	15	16
1	770.01	770.01	770.01	779.00	780.00	782.00	785.00	785.50
2	770.01	776.19	776.86	779.00	780.00	782.00	785.00	785.50
3	776.34	777.37	777.75	777.55	776.95	777.07	777.37	777.14
4	777.34	777.14	776.33	776.03	775.86	775.84	775.88	775.87
5	777.27	776.17	775.72	775.54	775.48	775.45	775.43	775.44
6	776.01	775.49	775.28	775.20	775.13	775.11	775.15	775.19
7	775.44	775.21	775.12	775.09	775.04	775.04	775.06	775.10
8	775.19	775.09	775.05	775.03	775.02	775.02	775.03	775.07
9	775.09	775.04	775.03	775.02	775.01	775.01	775.02	775.06
10	775.04	775.02	775.02	775.01	775.01	775.01	775.02	775.04
11	775.03	775.02	775.02	775.01	775.01	775.01	775.03	775.04
12	775.05	775.06	775.05	775.03	775.01	775.02	775.07	775.04
13	775.14	775.21	775.32	775.10	775.03	775.06	775.24	775.06
14	775.27	775.24	775.32	775.20	775.08	775.28	775.36	775.07
15	775.06	775.07	775.08	775.07	775.06	775.24	775.27	775.08
16	775.01	775.03	775.05	775.07	775.09	775.12	775.15	775.16
17	774.99	775.03	775.09	775.14	775.19	775.24	775.27	775.32
18	774.98	775.07	775.26	775.43	775.61	775.75	775.80	775.92
19	774.68	778.01	776.30	777.06	777.93	778.42	778.58	778.85
20	770.29	770.05	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	777.99	778.58	780.35	788.00
4	776.18	776.71	778.67	788.00
5	775.63	776.15	778.31	789.00
6	775.42	775.97	778.28	789.00
7	775.34	775.93	778.39	790.00
8	775.30	775.93	778.49	790.00
9	775.28	775.94	778.60	790.00
10	775.24	775.90	778.64	790.00
11	775.21	775.81	778.57	791.00
12	775.18	775.72	778.35	791.00
13	775.17	775.67	778.20	791.00
14	775.17	775.66	778.20	792.00
15	775.19	775.65	778.11	792.00
16	775.25	775.71	778.19	793.00
17	775.45	775.92	778.36	793.00
18	776.10	776.58	778.92	793.00
19	779.15	779.62	781.57	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 2.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.02	770.02	770.02	770.02	770.02	770.02	770.02	770.02
2	770.02	770.02	770.02	770.02	770.02	770.02	770.02	770.02
3	770.02	770.02	770.02	770.02	770.02	770.02	770.02	777.01
4	775.00	775.00	775.20	775.48	775.70	775.99	776.54	777.46
5	775.00	775.00	775.36	775.64	775.92	776.25	776.66	778.28
6	775.00	775.00	775.46	775.86	776.27	776.69	777.05	778.31
7	775.00	775.00	775.60	776.18	776.84	777.56	778.13	776.86
8	775.00	775.00	775.73	776.57	777.69	777.60	776.89	776.03
9	775.00	775.00	775.92	776.94	776.71	776.46	776.05	775.56
10	775.00	775.00	776.18	776.61	776.13	775.84	775.57	775.29
11	775.00	775.00	776.28	775.99	775.69	775.48	775.31	775.16
12	775.00	775.00	776.27	775.70	775.42	775.27	775.17	775.11
13	775.00	775.00	776.08	775.41	775.19	775.11	775.09	775.12
14	775.00	775.00	774.99	774.94	774.95	774.97	775.02	775.13
15	775.00	773.92	774.00	774.40	774.64	774.78	774.90	775.03

16	770.02	773.23	773.26	773.80	774.20	774.43	774.71	774.90
17	770.02	770.02	770.02	773.13	773.34	773.64	774.50	774.81
18	770.02	770.02	770.02	770.02	772.00	772.37	774.09	774.26
19	770.02	770.02	770.02	770.02	770.02	770.02	770.89	770.94
20	770.02	770.02	770.02	770.02	770.02	770.02	770.02	770.02
	9	10	11	12	13	14	15	16
1	770.02	770.02	770.02	779.00	780.00	782.00	785.00	785.50
2	770.02	777.51	778.04	779.00	780.00	782.00	785.00	785.50
3	777.66	778.69	779.02	778.77	778.22	778.41	778.85	778.75
4	778.50	778.32	777.51	777.13	776.91	776.89	776.97	777.06
5	778.41	777.27	776.66	776.38	776.29	776.25	776.19	776.29
6	776.93	776.19	775.82	775.63	775.47	775.41	775.54	775.67
7	776.05	775.63	775.41	775.32	775.18	775.16	775.27	775.41
8	775.56	775.32	775.20	775.13	775.08	775.08	775.15	775.30
9	775.29	775.17	775.10	775.06	775.04	775.04	775.10	775.24
10	775.16	775.10	775.07	775.04	775.03	775.03	775.08	775.19
11	775.11	775.08	775.06	775.04	775.03	775.04	775.09	775.17
12	775.13	775.16	775.14	775.08	775.05	775.07	775.18	775.17
13	775.29	775.42	775.57	775.25	775.11	775.18	775.47	775.20
14	775.46	775.46	775.58	775.39	775.22	775.55	775.68	775.25
15	775.14	775.18	775.23	775.21	775.19	775.51	775.59	775.33
16	775.02	775.11	775.19	775.27	775.37	775.47	775.56	775.62
17	775.00	775.14	775.31	775.49	775.66	775.80	775.92	776.09
18	775.01	775.26	775.76	776.18	776.61	776.92	777.10	777.41
19	774.40	778.01	777.74	778.88	780.20	781.00	781.38	781.81
20	770.56	770.10	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	779.91	780.87	783.07	788.00				
4	777.69	778.75	781.40	788.00				
5	776.78	777.87	780.89	789.00				
6	776.34	777.51	780.76	789.00				
7	776.13	777.37	780.84	790.00				
8	776.02	777.33	780.94	790.00				
9	775.94	777.32	781.05	790.00				
10	775.83	777.24	781.12	790.00				
11	775.73	777.08	781.09	791.00				
12	775.67	776.91	780.88	791.00				
13	775.63	776.82	780.72	791.00				
14	775.64	776.81	780.73	792.00				
15	775.72	776.85	780.70	792.00				
16	775.94	777.07	780.92	793.00				
17	776.47	777.60	781.34	793.00				
18	777.87	778.95	782.39	793.00				
19	782.32	783.18	785.73	794.00				

20 795.00 795.00 795.00 795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 3.64000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.03	770.03	770.03	770.03	770.03	770.03	770.03	770.03
2	770.03	770.03	770.03	770.03	770.03	770.03	770.03	770.03
3	770.03	770.03	770.03	770.03	770.03	770.03	770.03	778.10
4	775.00	775.00	775.40	775.86	776.24	776.71	777.39	778.34
5	775.00	775.00	775.59	776.07	776.51	776.96	777.45	778.94
6	775.00	775.00	775.72	776.33	776.86	777.36	777.75	778.78
7	775.00	775.00	775.88	776.64	777.37	778.08	778.56	777.49
8	775.00	775.00	776.00	776.98	778.07	778.05	777.47	776.60
9	775.00	775.00	776.16	777.26	777.17	776.97	776.59	775.99
10	775.00	775.00	776.39	776.93	776.56	776.29	775.99	775.60
11	775.00	775.00	776.46	776.31	776.05	775.82	775.61	775.37
12	775.00	775.00	776.42	775.96	775.68	775.50	775.36	775.26
13	775.00	775.00	776.21	775.59	775.34	775.24	775.19	775.24
14	775.00	775.00	775.12	775.02	774.99	775.01	775.05	775.22
15	775.00	774.24	774.31	774.47	774.60	774.73	774.86	775.06
16	770.03	773.89	773.94	773.98	774.14	774.34	774.61	774.87
17	770.03	770.03	770.03	773.68	773.35	773.70	774.39	774.76
18	770.03	770.03	770.03	770.03	772.55	772.99	773.78	774.08
19	770.03	770.03	770.03	770.03	770.03	770.03	771.26	771.36
20	770.03	770.03	770.03	770.03	770.03	770.03	770.03	770.03
	9	10	11	12	13	14	15	16
1	770.03	770.03	770.03	779.00	780.00	782.00	785.00	785.50
2	770.03	778.56	778.80	779.00	780.00	782.00	785.00	785.50
3	778.69	779.52	779.74	779.50	779.08	779.35	779.91	780.00
4	779.21	779.08	778.42	778.08	777.89	777.92	778.06	778.30
5	779.08	778.14	777.56	777.26	777.21	777.19	777.14	777.38
6	777.66	776.92	776.49	776.23	776.01	775.92	776.16	776.47
7	776.67	776.16	775.86	775.73	775.46	775.43	775.67	776.01
8	776.03	775.67	775.47	775.33	775.21	775.22	775.43	775.78
9	775.61	775.39	775.26	775.17	775.11	775.13	775.29	775.63
10	775.37	775.24	775.17	775.09	775.07	775.09	775.23	775.51
11	775.25	775.20	775.14	775.09	775.07	775.10	775.24	775.45
12	775.27	775.29	775.26	775.16	775.11	775.16	775.36	775.45
13	775.45	775.61	775.79	775.42	775.23	775.34	775.74	775.51
14	775.63	775.67	775.82	775.61	775.42	775.84	776.04	775.62

15	775.25	775.35	775.44	775.45	775.44	775.87	776.06	775.85
16	775.09	775.28	775.47	775.67	775.89	776.10	776.28	776.49
17	775.07	775.35	775.71	776.06	776.39	776.68	776.93	777.28
18	775.12	775.58	776.45	777.15	777.80	778.31	778.66	779.17
19	774.16	778.01	779.14	780.45	781.98	782.96	783.53	784.08
20	770.83	770.17	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	781.28	782.43	784.55	788.00				
4	779.20	780.58	783.26	788.00				
5	778.20	779.67	782.79	789.00				
6	777.63	779.21	782.61	789.00				
7	777.29	779.00	782.65	790.00				
8	777.09	778.89	782.71	790.00				
9	776.95	778.84	782.80	790.00				
10	776.76	778.74	782.89	790.00				
11	776.59	778.55	782.92	791.00				
12	776.50	778.35	782.78	791.00				
13	776.46	778.26	782.68	791.00				
14	776.51	778.31	782.75	792.00				
15	776.71	778.45	782.84	792.00				
16	777.12	778.87	783.22	793.00				
17	778.00	779.71	783.84	793.00				
18	779.94	781.49	785.13	793.00				
19	784.74	785.83	788.31	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 5.36800

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.05	770.05	770.05	770.05	770.05	770.05	770.05	770.05
2	770.05	770.05	770.05	770.05	770.05	770.05	770.05	770.05
3	770.05	770.05	770.05	770.05	770.05	770.05	770.05	778.97
4	775.00	775.00	775.63	776.28	776.82	777.39	778.11	778.99
5	775.00	775.00	775.83	776.49	777.05	777.58	778.10	779.39
6	775.00	775.00	775.95	776.72	777.35	777.88	778.27	779.09
7	775.00	775.00	776.09	776.97	777.75	778.42	778.84	777.97
8	775.00	775.00	776.18	777.25	778.32	778.35	777.88	777.10
9	775.00	775.00	776.31	777.46	777.49	777.36	777.02	776.43

10	775.00	775.00	776.51	777.14	776.89	776.66	776.39	775.95
11	775.00	775.00	776.56	776.53	776.35	776.14	775.93	775.64
12	775.00	775.00	776.51	776.16	775.93	775.75	775.60	775.47
13	775.00	775.00	776.30	775.75	775.52	775.40	775.35	775.40
14	775.00	775.00	775.27	775.17	775.10	775.10	775.14	775.34
15	775.00	774.55	774.64	774.65	774.68	774.77	774.89	775.13
16	770.05	774.35	774.42	774.22	774.25	774.38	774.61	774.91
17	770.05	770.05	770.05	774.05	773.56	773.88	774.41	774.81
18	770.05	770.05	770.05	770.05	773.02	773.45	773.57	774.04
19	770.05	770.05	770.05	770.05	770.05	770.05	771.59	771.79
20	770.05	770.05	770.05	770.05	770.05	770.05	770.05	770.05
	9	10	11	12	13	14	15	16
1	770.05	770.05	770.05	779.00	780.00	782.00	785.00	785.50
2	770.05	779.29	779.28	779.00	780.00	782.00	785.00	785.50
3	779.44	780.06	780.20	779.98	779.70	780.06	780.73	781.02
4	779.70	779.61	779.11	778.84	778.74	778.84	779.08	779.50
5	779.53	778.79	778.32	778.07	778.08	778.13	778.15	778.56
6	778.23	777.58	777.17	776.92	776.67	776.61	776.98	777.49
7	777.24	776.73	776.40	776.26	775.90	775.89	776.31	776.88
8	776.51	776.11	775.85	775.66	775.48	775.52	775.92	776.53
9	775.99	775.71	775.52	775.37	775.26	775.32	775.67	776.28
10	775.66	775.48	775.37	775.21	775.17	775.23	775.53	776.07
11	775.47	775.38	775.28	775.18	775.15	775.22	775.52	775.96
12	775.46	775.47	775.43	775.29	775.22	775.31	775.67	775.96
13	775.64	775.82	776.02	775.63	775.41	775.57	776.11	776.06
14	775.80	775.90	776.08	775.90	775.70	776.20	776.53	776.28
15	775.41	775.58	775.75	775.82	775.84	776.38	776.75	776.71
16	775.25	775.57	775.92	776.27	776.66	777.02	777.32	777.74
17	775.25	775.71	776.29	776.84	777.36	777.81	778.22	778.80
18	775.38	776.06	777.28	778.22	779.07	779.74	780.27	780.99
19	773.98	778.01	780.43	781.79	783.39	784.46	785.16	785.83
20	771.09	770.25	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	782.33	783.52	785.41	788.00				
4	780.58	782.08	784.50	788.00				
5	779.66	781.29	784.15	789.00				
6	779.06	780.83	784.00	789.00				
7	778.67	780.59	784.02	790.00				
8	778.41	780.44	784.06	790.00				
9	778.21	780.37	784.12	790.00				
10	777.97	780.26	784.23	790.00				
11	777.76	780.07	784.30	791.00				
12	777.65	779.90	784.25	791.00				
13	777.64	779.86	784.24	791.00				

14	777.77	779.99	784.40	792.00
15	778.11	780.27	784.61	792.00
16	778.71	780.86	785.12	793.00
17	779.84	781.89	785.85	793.00
18	782.02	783.81	787.16	793.00
19	786.60	787.79	789.98	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 7.41600

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.06	770.06	770.06	770.06	770.06	770.06	770.06	770.06
2	770.06	770.06	770.06	770.06	770.06	770.06	770.06	770.06
3	770.06	770.06	770.06	770.06	770.06	770.06	770.06	779.59
4	775.00	775.00	775.87	776.70	777.35	777.97	778.67	779.47
5	775.00	775.00	776.04	776.86	777.51	778.08	778.60	779.71
6	775.00	775.00	776.14	777.03	777.72	778.27	778.64	779.32
7	775.00	775.00	776.24	777.21	778.02	778.66	779.05	778.34
8	775.00	775.00	776.31	777.43	778.48	778.57	778.19	777.52
9	775.00	775.00	776.41	777.60	777.71	777.64	777.38	776.84
10	775.00	775.00	776.58	777.29	777.13	776.97	776.74	776.32
11	775.00	775.00	776.62	776.70	776.59	776.44	776.24	775.95
12	775.00	775.00	776.57	776.33	776.15	776.00	775.86	775.72
13	775.00	775.00	776.37	775.91	775.71	775.60	775.55	775.61
14	775.00	775.00	775.41	775.34	775.27	775.25	775.28	775.51
15	775.00	774.78	774.91	774.86	774.85	774.90	775.00	775.28
16	770.06	774.67	774.78	774.48	774.44	774.53	774.73	775.08
17	770.06	770.06	770.06	774.36	773.85	774.13	774.54	774.98
18	770.06	770.06	770.06	770.06	773.44	773.83	773.46	774.16
19	770.06	770.06	770.06	770.06	770.06	770.06	771.89	772.24
20	770.06	770.06	770.06	770.06	770.06	770.06	770.06	770.06
	9	10	11	12	13	14	15	16
1	770.06	770.06	770.06	779.00	780.00	782.00	785.00	785.50
2	770.06	779.75	779.58	779.00	780.00	782.00	785.00	785.50
3	779.95	780.43	780.52	780.34	780.17	780.63	781.41	781.87
4	780.04	779.99	779.64	779.46	779.45	779.64	780.00	780.58
5	779.85	779.29	778.94	778.77	778.85	779.00	779.14	779.72
6	778.68	778.16	777.82	777.61	777.40	777.41	777.94	778.65
7	777.74	777.29	776.99	776.87	776.47	776.52	777.15	777.96
8	776.99	776.60	776.32	776.10	775.89	775.99	776.64	777.51

9	776.41	776.10	775.88	775.68	775.53	775.66	776.28	777.18
10	776.00	775.79	775.65	775.42	775.36	775.49	776.05	776.88
11	775.76	775.63	775.50	775.34	775.31	775.45	775.99	776.73
12	775.70	775.71	775.64	775.48	775.41	775.57	776.16	776.74
13	775.86	776.07	776.29	775.90	775.67	775.91	776.67	776.90
14	776.02	776.17	776.41	776.27	776.09	776.68	777.23	777.25
15	775.64	775.91	776.18	776.34	776.41	777.08	777.69	777.92
16	775.53	776.01	776.53	777.07	777.65	778.17	778.62	779.28
17	775.58	776.23	777.02	777.78	778.48	779.09	779.67	780.47
18	775.78	776.68	778.19	779.33	780.33	781.14	781.83	782.73
19	773.87	778.01	781.56	782.92	784.52	785.66	786.46	787.22
20	771.34	770.35	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	783.16	784.30	785.97	788.00
4	781.78	783.25	785.35	788.00
5	781.02	782.63	785.14	789.00
6	780.48	782.25	785.03	789.00
7	780.08	782.02	785.07	790.00
8	779.80	781.87	785.11	790.00
9	779.58	781.79	785.17	790.00
10	779.33	781.70	785.29	790.00
11	779.12	781.56	785.41	791.00
12	779.03	781.44	785.43	791.00
13	779.08	781.48	785.51	791.00
14	779.32	781.71	785.76	792.00
15	779.78	782.11	786.06	792.00
16	780.52	782.81	786.65	793.00
17	781.75	783.91	787.40	793.00
18	783.94	785.76	788.66	793.00
19	788.06	789.24	791.09	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 9.93000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.08	770.08	770.08	770.08	770.08	770.08	770.08	770.08
2	770.09	770.09	770.09	770.09	770.09	770.09	770.09	770.09
3	770.09	770.09	770.09	770.09	770.09	770.09	770.09	780.01

4	775.00	775.00	776.09	777.05	777.78	778.42	779.08	779.81
5	775.00	775.00	776.22	777.16	777.87	778.46	778.97	779.95
6	775.00	775.00	776.28	777.27	778.00	778.56	778.92	779.50
7	775.00	775.00	776.36	777.39	778.22	778.84	779.20	778.65
8	775.00	775.00	776.39	777.56	778.61	778.73	778.43	777.89
9	775.00	775.00	776.48	777.69	777.87	777.87	777.67	777.23
10	775.00	775.00	776.63	777.40	777.33	777.23	777.05	776.69
11	775.00	775.00	776.68	776.84	776.80	776.70	776.55	776.29
12	775.00	775.00	776.62	776.48	776.37	776.26	776.15	776.03
13	775.00	775.00	776.44	776.08	775.93	775.85	775.80	775.88
14	775.00	775.00	775.55	775.54	775.49	775.49	775.52	775.77
15	775.00	774.96	775.15	775.11	775.10	775.14	775.23	775.55
16	770.08	774.89	775.06	774.77	774.73	774.80	774.99	775.39
17	770.08	770.08	770.08	774.68	774.21	774.45	774.81	775.32
18	770.09	770.09	770.09	770.09	773.88	774.22	773.47	774.48
19	770.09	770.09	770.09	770.09	770.09	770.09	772.20	772.76
20	770.08	770.08	770.08	770.08	770.08	770.08	770.08	770.08
	9	10	11	12	13	14	15	16
1	770.08	770.08	770.08	779.00	780.00	782.00	785.00	785.50
2	770.09	780.04	779.78	779.00	780.00	782.00	785.00	785.50
3	780.30	780.68	780.75	780.62	780.56	781.10	781.99	782.60
4	780.29	780.28	780.05	779.96	780.05	780.34	780.83	781.55
5	780.10	779.69	779.45	779.37	779.53	779.80	780.10	780.83
6	779.05	778.67	778.42	778.28	778.15	778.28	778.98	779.85
7	778.18	777.82	777.58	777.52	777.17	777.33	778.17	779.17
8	777.45	777.11	776.85	776.65	776.46	776.68	777.59	778.69
9	776.85	776.55	776.33	776.11	775.97	776.21	777.14	778.31
10	776.40	776.18	776.03	775.75	775.69	775.94	776.83	777.97
11	776.11	775.97	775.81	775.62	775.60	775.87	776.74	777.79
12	776.02	776.03	775.95	775.76	775.72	776.02	776.93	777.83
13	776.17	776.40	776.64	776.26	776.07	776.44	777.50	778.07
14	776.33	776.54	776.84	776.79	776.63	777.34	778.21	778.56
15	775.99	776.37	776.76	777.03	777.18	778.01	778.90	779.43
16	775.98	776.62	777.31	778.03	778.81	779.49	780.11	780.99
17	776.07	776.90	777.90	778.84	779.71	780.48	781.22	782.22
18	776.34	777.43	779.16	780.45	781.58	782.50	783.33	784.37
19	773.84	778.01	782.56	783.90	785.51	786.68	787.56	788.39
20	771.62	770.48	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	783.84	784.90	786.35	788.00				
4	782.80	784.17	785.97	788.00				
5	782.23	783.74	785.88	789.00				
6	781.80	783.46	785.84	789.00				
7	781.46	783.29	785.92	790.00				

8	781.20	783.17	785.98	790.00
9	781.00	783.12	786.06	790.00
10	780.78	783.07	786.19	790.00
11	780.61	782.99	786.35	791.00
12	780.59	782.96	786.44	791.00
13	780.71	783.08	786.60	791.00
14	781.05	783.40	786.91	792.00
15	781.61	783.88	787.28	792.00
16	782.40	784.63	787.91	793.00
17	783.63	785.69	788.64	793.00
18	785.66	787.39	789.80	793.00
19	789.25	790.36	791.87	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 12.90000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.11	770.11	770.11	770.11	770.11	770.11	770.11	770.11
2	770.11	770.11	770.11	770.11	770.11	770.11	770.11	770.11
3	770.11	770.11	770.11	770.11	770.11	770.11	770.11	780.28
4	775.00	775.00	776.26	777.33	778.10	778.74	779.37	780.04
5	775.00	775.00	776.36	777.38	778.13	778.73	779.22	780.11
6	775.00	775.00	776.39	777.44	778.20	778.76	779.12	779.63
7	775.00	775.00	776.44	777.52	778.36	778.98	779.32	778.91
8	775.00	775.00	776.45	777.65	778.70	778.85	778.63	778.22
9	775.00	775.00	776.53	777.77	778.01	778.06	777.92	777.59
10	775.00	775.00	776.68	777.48	777.49	777.46	777.33	777.06
11	775.00	775.00	776.72	776.96	776.99	776.95	776.84	776.65
12	775.00	775.00	776.67	776.62	776.58	776.52	776.45	776.38
13	775.00	775.00	776.50	776.24	776.15	776.12	776.10	776.23
14	775.00	775.00	775.68	775.74	775.74	775.77	775.82	776.13
15	775.00	775.08	775.35	775.37	775.38	775.44	775.55	775.94
16	770.11	775.05	775.29	775.08	775.06	775.14	775.36	775.85
17	770.11	770.11	770.11	775.00	774.61	774.84	775.20	775.79
18	770.11	770.11	770.11	770.11	774.33	774.63	773.64	774.98
19	770.11	770.11	770.11	770.11	770.11	770.11	772.54	773.39
20	770.11	770.11	770.11	770.11	770.11	770.11	770.11	770.11
	9	10	11	12	13	14	15	16
1	770.11	770.11	770.11	779.00	780.00	782.00	785.00	785.50
2	770.11	780.22	779.90	779.00	780.00	782.00	785.00	785.50

3	780.53	780.85	780.92	780.84	780.87	781.50	782.48	783.20
4	780.46	780.49	780.37	780.37	780.55	780.94	781.55	782.39
5	780.28	780.00	779.87	779.88	780.11	780.50	780.97	781.81
6	779.35	779.10	778.95	778.90	778.87	779.16	780.01	781.00
7	778.57	778.31	778.16	778.16	777.94	778.23	779.27	780.40
8	777.88	777.61	777.42	777.26	777.17	777.54	778.69	779.95
9	777.29	777.04	776.85	776.64	776.58	776.97	778.21	779.58
10	776.82	776.64	776.50	776.21	776.21	776.63	777.86	779.24
11	776.51	776.39	776.23	776.02	776.07	776.51	777.75	779.08
12	776.40	776.43	776.36	776.18	776.21	776.68	777.96	779.16
13	776.55	776.82	777.10	776.75	776.64	777.18	778.59	779.48
14	776.74	777.02	777.40	777.45	777.35	778.22	779.42	780.09
15	776.47	776.97	777.48	777.88	778.12	779.12	780.30	781.08
16	776.57	777.36	778.22	779.10	780.05	780.88	781.65	782.70
17	776.70	777.70	778.86	779.95	780.97	781.86	782.74	783.87
18	777.01	778.26	780.12	781.52	782.76	783.77	784.71	785.83
19	773.94	778.09	783.34	784.73	786.35	787.56	788.49	789.37
20	771.93	770.83	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	784.39	785.34	786.62	788.00				
4	783.64	784.89	786.42	788.00				
5	783.26	784.63	786.44	789.00				
6	782.95	784.46	786.47	789.00				
7	782.70	784.36	786.60	790.00				
8	782.50	784.30	786.69	790.00				
9	782.36	784.29	786.79	790.00				
10	782.19	784.30	786.94	790.00				
11	782.10	784.30	787.14	791.00				
12	782.15	784.35	787.29	791.00				
13	782.36	784.55	787.51	791.00				
14	782.76	784.93	787.88	792.00				
15	783.37	785.44	788.29	792.00				
16	784.16	786.18	788.92	793.00				
17	785.31	787.18	789.61	793.00				
18	787.13	788.69	790.65	793.00				
19	790.23	791.21	792.42	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 16.50000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW

COLUMN

	1	2	3	4	5	6	7	8
1	770.14	770.14	770.14	770.14	770.14	770.14	770.14	770.14
2	770.14	770.14	770.14	770.14	770.14	770.14	770.14	770.14
3	770.14	770.14	770.14	770.14	770.14	770.14	770.14	780.46
4	775.00	775.00	776.39	777.52	778.31	778.96	779.57	780.20
5	775.00	775.00	776.46	777.54	778.31	778.91	779.40	780.23
6	775.00	775.00	776.46	777.56	778.34	778.91	779.26	779.74
7	775.00	775.00	776.49	777.61	778.47	779.08	779.41	779.13
8	775.00	775.00	776.50	777.72	778.77	778.96	778.79	778.51
9	775.00	775.00	776.56	777.83	778.12	778.22	778.15	777.93
10	775.00	775.00	776.71	777.56	777.63	777.66	777.60	777.43
11	775.00	775.00	776.75	777.06	777.17	777.19	777.14	777.04
12	775.00	775.00	776.71	776.75	776.78	776.78	776.76	776.78
13	775.00	775.00	776.56	776.40	776.39	776.41	776.44	776.65
14	775.00	775.00	775.79	775.95	776.01	776.09	776.19	776.57
15	775.00	775.18	775.52	775.63	775.70	775.80	775.96	776.44
16	770.14	775.16	775.49	775.42	775.43	775.56	775.84	776.43
17	770.14	770.14	770.14	775.35	775.06	775.30	775.69	776.40
18	770.14	770.14	770.14	770.14	774.81	775.10	774.00	775.67
19	770.14	770.14	770.14	770.14	770.14	770.14	772.96	774.19
20	770.14	770.14	770.14	770.14	770.14	770.14	770.14	770.14
	9	10	11	12	13	14	15	16
1	770.14	770.14	770.14	779.00	780.00	782.00	785.00	785.50
2	770.14	780.34	779.98	779.00	780.00	782.00	785.00	785.50
3	780.68	780.97	781.05	781.01	781.13	781.83	782.89	783.71
4	780.58	780.66	780.63	780.71	780.97	781.46	782.18	783.10
5	780.42	780.25	780.22	780.31	780.60	781.11	781.76	782.68
6	779.61	779.47	779.43	779.48	779.55	780.01	781.01	782.06
7	778.92	778.77	778.71	778.80	778.74	779.20	780.39	781.59
8	778.29	778.11	778.00	777.92	777.99	778.53	779.88	781.22
9	777.72	777.56	777.43	777.29	777.36	777.94	779.43	780.91
10	777.27	777.15	777.06	776.82	776.94	777.55	779.10	780.62
11	776.96	776.89	776.75	776.61	776.76	777.41	779.01	780.52
12	776.87	776.94	776.89	776.78	776.92	777.61	779.26	780.67
13	777.03	777.36	777.70	777.41	777.43	778.17	779.92	781.06
14	777.26	777.64	778.11	778.27	778.26	779.30	780.82	781.74
15	777.08	777.70	778.33	778.86	779.21	780.38	781.79	782.77
16	777.28	778.21	779.20	780.22	781.31	782.26	783.15	784.31
17	777.44	778.57	779.85	781.07	782.20	783.19	784.17	785.37
18	777.76	779.12	781.04	782.53	783.85	784.94	785.95	787.14
19	774.27	778.44	783.92	785.42	787.09	788.34	789.31	790.21
20	772.34	771.66	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				

2	786.00	786.00	787.00	788.00
3	784.83	785.69	786.82	788.00
4	784.33	785.46	786.76	788.00
5	784.13	785.35	786.87	789.00
6	783.95	785.29	786.98	789.00
7	783.80	785.27	787.15	790.00
8	783.68	785.28	787.28	790.00
9	783.60	785.32	787.41	790.00
10	783.52	785.38	787.58	790.00
11	783.52	785.46	787.82	791.00
12	783.65	785.59	788.02	791.00
13	783.92	785.85	788.29	791.00
14	784.37	786.27	788.69	792.00
15	784.99	786.79	789.12	792.00
16	785.73	787.50	789.74	793.00
17	786.77	788.41	790.38	793.00
18	788.39	789.75	791.30	793.00
19	791.03	791.88	792.83	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 20.80000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.18	770.18	770.18	770.18	770.18	770.18	770.18	770.18
2	770.18	770.18	770.18	770.18	770.18	770.18	770.18	770.18
3	770.18	770.18	770.18	770.18	770.18	770.18	770.18	780.58
4	775.00	775.00	776.47	777.64	778.45	779.10	779.70	780.31
5	775.00	775.00	776.52	777.64	778.43	779.04	779.52	780.31
6	775.00	775.00	776.51	777.64	778.44	779.01	779.36	779.83
7	775.00	775.00	776.53	777.67	778.54	779.15	779.49	779.32
8	775.00	775.00	776.53	777.77	778.83	779.04	778.94	778.78
9	775.00	775.00	776.59	777.88	778.21	778.37	778.35	778.26
10	775.00	775.00	776.74	777.63	777.77	777.86	777.85	777.80
11	775.00	775.00	776.79	777.17	777.34	777.42	777.43	777.45
12	775.00	775.00	776.75	776.88	776.98	777.06	777.10	777.23
13	775.00	775.00	776.63	776.57	776.64	776.73	776.82	777.14
14	775.00	775.00	775.91	776.17	776.32	776.46	776.62	777.11
15	775.00	775.26	775.69	775.91	776.06	776.23	776.46	777.05
16	770.18	775.25	775.66	775.78	775.86	776.05	776.42	777.12
17	770.18	770.18	770.18	775.72	775.57	775.84	776.29	777.11

18	770.18	770.18	770.18	770.18	775.34	775.65	774.59	776.49
19	770.18	770.18	770.18	770.18	770.18	770.18	773.54	775.14
20	770.18	770.18	770.18	770.18	770.18	770.18	770.18	770.18
	9	10	11	12	13	14	15	16
1	770.18	770.18	770.18	779.00	780.00	782.00	785.00	785.50
2	770.18	780.42	780.04	779.00	780.00	782.00	785.00	785.50
3	780.79	781.06	781.15	781.16	781.35	782.10	783.23	784.13
4	780.68	780.79	780.85	781.00	781.32	781.89	782.71	783.70
5	780.53	780.47	780.52	780.69	781.03	781.64	782.45	783.42
6	779.83	779.81	779.86	780.00	780.18	780.81	781.93	783.01
7	779.24	779.20	779.23	779.40	779.54	780.16	781.48	782.69
8	778.68	778.61	778.59	778.61	778.87	779.58	781.08	782.44
9	778.17	778.10	778.06	778.01	778.27	779.03	780.72	782.22
10	777.75	777.71	777.69	777.58	777.86	778.67	780.46	782.03
11	777.47	777.48	777.40	777.37	777.68	778.55	780.42	782.01
12	777.41	777.55	777.56	777.57	777.87	778.77	780.71	782.21
13	777.61	778.02	778.44	778.25	778.43	779.38	781.38	782.65
14	777.88	778.36	778.93	779.23	779.33	780.55	782.29	783.36
15	777.80	778.53	779.27	779.92	780.39	781.70	783.27	784.35
16	778.08	779.11	780.21	781.32	782.52	783.56	784.55	785.75
17	778.25	779.47	780.83	782.13	783.35	784.41	785.47	786.71
18	778.55	779.97	781.90	783.45	784.84	785.99	787.06	788.26
19	774.94	779.11	784.39	786.01	787.73	789.01	790.01	790.92
20	772.96	773.05	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	785.19	785.97	786.97	788.00				
4	784.90	785.92	787.03	788.00				
5	784.85	785.93	787.22	789.00				
6	784.79	785.96	787.38	789.00				
7	784.74	786.02	787.60	790.00				
8	784.71	786.09	787.76	790.00				
9	784.71	786.19	787.92	790.00				
10	784.72	786.32	788.12	790.00				
11	784.80	786.47	788.39	791.00				
12	785.00	786.66	788.64	791.00				
13	785.32	786.97	788.95	791.00				
14	785.79	787.41	789.37	792.00				
15	786.39	787.94	789.80	792.00				
16	787.09	788.60	790.39	793.00				
17	788.02	789.42	790.99	793.00				
18	789.43	790.59	791.81	793.00				
19	791.67	792.40	793.14	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 26.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.22	770.22	770.22	770.22	770.22	770.22	770.22	770.22
2	770.22	770.22	770.22	770.22	770.22	770.22	770.22	770.22
3	770.22	770.22	770.22	770.22	770.22	770.22	770.22	780.66
4	775.00	775.00	776.52	777.72	778.54	779.19	779.78	780.38
5	775.00	775.00	776.56	777.70	778.51	779.12	779.60	780.38
6	775.00	775.00	776.54	777.70	778.51	779.08	779.44	779.91
7	775.00	775.00	776.56	777.72	778.60	779.21	779.55	779.50
8	775.00	775.00	776.56	777.81	778.88	779.12	779.08	779.04
9	775.00	775.00	776.62	777.92	778.31	778.51	778.56	778.59
10	775.00	775.00	776.77	777.70	777.90	778.06	778.11	778.19
11	775.00	775.00	776.83	777.27	777.52	777.67	777.75	777.90
12	775.00	775.00	776.80	777.02	777.21	777.36	777.47	777.73
13	775.00	775.00	776.69	776.76	776.92	777.09	777.26	777.70
14	775.00	775.00	776.03	776.42	776.66	776.88	777.11	777.73
15	775.00	775.34	775.86	776.22	776.46	776.72	777.02	777.74
16	770.22	775.33	775.84	776.19	776.34	776.62	777.08	777.88
17	770.22	770.22	770.22	776.14	776.14	776.46	776.98	777.90
18	770.22	770.22	770.22	770.22	775.94	776.28	775.41	777.43
19	770.22	770.22	770.22	770.22	770.22	770.22	774.34	776.26
20	770.22	770.22	770.22	770.22	770.22	770.22	770.22	770.22
	9	10	11	12	13	14	15	16
1	770.22	770.22	770.22	779.00	780.00	782.00	785.00	785.50
2	770.22	780.48	780.09	779.00	780.00	782.00	785.00	785.50
3	780.87	781.14	781.24	781.28	781.53	782.33	783.52	784.47
4	780.75	780.90	781.04	781.24	781.63	782.26	783.17	784.20
5	780.62	780.65	780.79	781.02	781.40	782.10	783.05	784.05
6	780.03	780.12	780.26	780.49	780.77	781.54	782.76	783.84
7	779.54	779.61	779.74	779.99	780.32	781.08	782.48	783.67
8	779.06	779.11	779.20	779.32	779.78	780.64	782.23	783.55
9	778.62	778.66	778.73	778.80	779.28	780.20	781.99	783.45
10	778.26	778.33	778.40	778.46	778.93	779.91	781.84	783.36
11	778.03	778.14	778.15	778.30	778.81	779.85	781.88	783.44
12	778.02	778.27	778.36	778.53	779.03	780.12	782.21	783.70
13	778.28	778.78	779.30	779.23	779.62	780.74	782.87	784.17
14	778.60	779.19	779.86	780.30	780.51	781.87	783.74	784.86
15	778.60	779.43	780.28	781.03	781.59	783.01	784.66	785.77
16	778.94	780.05	781.21	782.39	783.65	784.75	785.80	787.02

17	779.11	780.39	781.79	783.13	784.40	785.52	786.62	787.86
18	779.39	780.84	782.73	784.31	785.74	786.92	788.03	789.22
19	776.00	780.06	784.85	786.54	788.30	789.60	790.61	791.50
20	773.93	774.98	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	785.48	786.18	787.09	788.00				
4	785.36	786.28	787.24	788.00				
5	785.44	786.39	787.49	789.00				
6	785.48	786.51	787.71	789.00				
7	785.53	786.64	787.96	790.00				
8	785.59	786.78	788.16	790.00				
9	785.67	786.93	788.35	790.00				
10	785.76	787.10	788.57	790.00				
11	785.92	787.32	788.87	791.00				
12	786.17	787.57	789.15	791.00				
13	786.53	787.92	789.48	791.00				
14	787.02	788.36	789.92	792.00				
15	787.59	788.88	790.35	792.00				
16	788.23	789.50	790.92	793.00				
17	789.06	790.23	791.46	793.00				
18	790.28	791.26	792.19	793.00				
19	792.20	792.81	793.38	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 32.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.28	770.28	770.28	770.28	770.28	770.28	770.28	770.28
2	770.28	770.28	770.28	770.28	770.28	770.28	770.28	770.28
3	770.28	770.28	770.28	770.28	770.28	770.28	770.28	780.73
4	775.00	775.00	776.55	777.76	778.60	779.26	779.85	780.44
5	775.00	775.00	776.59	777.75	778.56	779.18	779.66	780.43
6	775.00	775.00	776.57	777.74	778.56	779.14	779.50	779.97
7	775.00	775.00	776.59	777.76	778.65	779.26	779.61	779.67
8	775.00	775.00	776.58	777.85	778.93	779.20	779.22	779.30
9	775.00	775.00	776.65	777.97	778.40	778.66	778.76	778.93
10	775.00	775.00	776.80	777.77	778.05	778.26	778.39	778.60
11	775.00	775.00	776.87	777.39	777.71	777.93	778.08	778.38

12	775.00	775.00	776.85	777.18	777.45	777.68	777.87	778.28
13	775.00	775.00	776.77	776.97	777.23	777.49	777.73	778.32
14	775.00	775.00	776.17	776.69	777.03	777.35	777.66	778.41
15	775.00	775.42	776.05	776.57	776.91	777.26	777.65	778.50
16	770.28	775.41	776.03	776.64	776.87	777.24	777.80	778.71
17	770.28	770.28	770.28	776.59	776.78	777.16	777.76	778.76
18	770.28	770.28	770.28	770.28	776.59	776.99	776.44	778.45
19	770.28	770.28	770.28	770.28	770.28	770.28	775.41	777.47
20	770.28	770.28	770.28	770.28	770.28	770.28	770.28	770.28
	9	10	11	12	13	14	15	16
1	770.28	770.28	770.28	779.00	780.00	782.00	785.00	785.50
2	770.28	780.52	780.12	779.00	780.00	782.00	785.00	785.50
3	780.93	781.19	781.31	781.38	781.69	782.53	783.76	784.75
4	780.81	781.00	781.20	781.46	781.89	782.58	783.54	784.61
5	780.70	780.82	781.02	781.30	781.72	782.49	783.55	784.57
6	780.22	780.40	780.63	780.92	781.29	782.18	783.47	784.53
7	779.83	780.00	780.22	780.53	781.04	781.92	783.37	784.51
8	779.44	779.60	779.79	780.01	780.67	781.65	783.26	784.51
9	779.09	779.25	779.42	779.62	780.30	781.36	783.17	784.52
10	778.80	778.98	779.14	779.41	780.07	781.19	783.13	784.55
11	778.65	778.87	778.98	779.34	780.03	781.21	783.27	784.72
12	778.70	779.06	779.25	779.62	780.30	781.52	783.63	785.03
13	779.01	779.62	780.25	780.31	780.89	782.14	784.26	785.51
14	779.38	780.07	780.84	781.40	781.73	783.18	785.06	786.17
15	779.45	780.37	781.29	782.12	782.77	784.24	785.91	787.00
16	779.84	781.00	782.20	783.41	784.69	785.82	786.90	788.09
17	780.02	781.32	782.72	784.08	785.37	786.50	787.62	788.82
18	780.29	781.73	783.55	785.13	786.56	787.75	788.86	790.01
19	777.42	781.19	785.35	787.06	788.81	790.12	791.12	791.98
20	775.34	777.24	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	785.71	786.35	787.18	788.00				
4	785.73	786.56	787.40	788.00				
5	785.91	786.76	787.71	789.00				
6	786.05	786.95	787.96	789.00				
7	786.18	787.14	788.26	790.00				
8	786.32	787.33	788.48	790.00				
9	786.46	787.52	788.69	790.00				
10	786.62	787.75	788.93	790.00				
11	786.86	788.01	789.25	791.00				
12	787.16	788.31	789.55	791.00				
13	787.55	788.68	789.91	791.00				
14	788.03	789.13	790.35	792.00				
15	788.57	789.63	790.78	792.00				

16	789.16	790.20	791.32	793.00
17	789.89	790.87	791.83	793.00
18	790.96	791.77	792.49	793.00
19	792.61	793.12	793.56	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 39.60000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.34	770.34	770.34	770.34	770.34	770.34	770.34	770.34
2	770.34	770.34	770.34	770.34	770.34	770.34	770.34	770.34
3	770.34	770.34	770.34	770.34	770.34	770.34	770.34	780.78
4	775.00	775.00	776.57	777.80	778.64	779.30	779.90	780.49
5	775.00	775.00	776.61	777.78	778.60	779.22	779.71	780.47
6	775.00	775.00	776.59	777.77	778.60	779.19	779.55	780.04
7	775.00	775.00	776.61	777.79	778.69	779.32	779.67	779.84
8	775.00	775.00	776.60	777.89	778.97	779.28	779.35	779.56
9	775.00	775.00	776.67	778.02	778.50	778.81	778.97	779.27
10	775.00	775.00	776.83	777.85	778.19	778.48	778.67	779.02
11	775.00	775.00	776.91	777.51	777.91	778.21	778.44	778.87
12	775.00	775.00	776.90	777.34	777.71	778.03	778.30	778.86
13	775.00	775.00	776.84	777.19	777.55	777.91	778.23	778.97
14	775.00	775.00	776.32	776.98	777.44	777.84	778.24	779.13
15	775.00	775.50	776.25	776.94	777.40	777.85	778.32	779.29
16	770.34	775.50	776.23	777.13	777.45	777.92	778.59	779.57
17	770.34	770.34	770.34	777.08	777.46	777.91	778.60	779.67
18	770.34	770.34	770.34	770.34	777.30	777.76	777.63	779.54
19	770.34	770.34	770.34	770.34	770.34	770.34	776.70	778.75
20	770.34	770.34	770.34	770.34	770.34	770.34	770.34	770.34
	9	10	11	12	13	14	15	16
1	770.34	770.34	770.34	779.00	780.00	782.00	785.00	785.50
2	770.34	780.56	780.15	779.00	780.00	782.00	785.00	785.50
3	780.98	781.24	781.37	781.47	781.81	782.68	783.95	784.97
4	780.86	781.08	781.33	781.63	782.10	782.83	783.85	784.93
5	780.78	780.96	781.23	781.55	781.99	782.82	783.96	784.98
6	780.39	780.66	780.96	781.32	781.75	782.73	784.06	785.09
7	780.10	780.37	780.67	781.03	781.69	782.65	784.11	785.20
8	779.81	780.08	780.37	780.67	781.49	782.55	784.14	785.30
9	779.55	779.82	780.10	780.41	781.27	782.41	784.18	785.42
10	779.35	779.65	779.89	780.36	781.19	782.38	784.27	785.56

11	779.28	779.62	779.84	780.40	781.26	782.51	784.49	785.80
12	779.41	779.88	780.18	780.74	781.58	782.86	784.88	786.15
13	779.77	780.49	781.21	781.41	782.15	783.45	785.48	786.64
14	780.18	780.98	781.82	782.48	782.91	784.38	786.22	787.27
15	780.33	781.32	782.29	783.17	783.87	785.36	786.98	788.02
16	780.76	781.95	783.15	784.37	785.64	786.76	787.84	788.96
17	780.96	782.25	783.64	784.98	786.26	787.37	788.47	789.61
18	781.25	782.65	784.40	785.92	787.31	788.47	789.56	790.64
19	779.03	782.31	786.00	787.62	789.30	790.57	791.55	792.37
20	777.13	779.30	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	785.88	786.48	787.26	788.00
4	786.01	786.78	787.53	788.00
5	786.28	787.05	787.88	789.00
6	786.50	787.30	788.16	789.00
7	786.70	787.54	788.48	790.00
8	786.90	787.77	788.73	790.00
9	787.10	788.00	788.96	790.00
10	787.32	788.25	789.21	790.00
11	787.62	788.56	789.55	791.00
12	787.96	788.89	789.87	791.00
13	788.36	789.28	790.24	791.00
14	788.84	789.73	790.68	792.00
15	789.35	790.21	791.10	792.00
16	789.90	790.75	791.63	793.00
17	790.55	791.36	792.10	793.00
18	791.49	792.16	792.71	793.00
19	792.93	793.35	793.69	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 48.50000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.42	770.42	770.42	770.42	770.42	770.42	770.42	770.42
2	770.42	770.42	770.42	770.42	770.42	770.42	770.42	770.42
3	770.42	770.42	770.42	770.42	770.42	770.42	770.42	780.82
4	775.00	775.00	776.59	777.83	778.68	779.35	779.94	780.54
5	775.00	775.00	776.63	777.81	778.64	779.27	779.75	780.51

6	775.00	775.00	776.61	777.80	778.64	779.23	779.60	780.10
7	775.00	775.00	776.63	777.83	778.73	779.36	779.72	779.99
8	775.00	775.00	776.63	777.93	779.02	779.36	779.48	779.80
9	775.00	775.00	776.70	778.06	778.60	778.96	779.18	779.60
10	775.00	775.00	776.86	777.92	778.34	778.69	778.95	779.44
11	775.00	775.00	776.95	777.63	778.11	778.49	778.79	779.37
12	775.00	775.00	776.96	777.51	777.97	778.38	778.73	779.44
13	775.00	775.00	776.92	777.41	777.89	778.34	778.75	779.62
14	775.00	775.00	776.47	777.28	777.86	778.36	778.83	779.85
15	775.00	775.59	776.45	777.33	777.90	778.46	779.01	780.09
16	770.42	775.58	776.44	777.64	778.06	778.63	779.41	780.47
17	770.42	770.42	770.42	777.60	778.20	778.71	779.50	780.62
18	770.42	770.42	770.42	770.42	778.06	778.59	778.93	780.68
19	770.42	770.42	770.42	770.42	770.42	770.42	778.15	780.06
20	770.42	770.42	770.42	770.42	770.42	770.42	770.42	770.42
	9	10	11	12	13	14	15	16
1	770.42	770.42	770.42	779.00	780.00	782.00	785.00	785.50
2	770.42	780.59	780.18	779.00	780.00	782.00	785.00	785.50
3	781.03	781.29	781.42	781.54	781.91	782.81	784.10	785.14
4	780.91	781.15	781.45	781.78	782.28	783.04	784.09	785.19
5	780.84	781.09	781.40	781.76	782.21	783.08	784.28	785.31
6	780.55	780.90	781.25	781.65	782.14	783.18	784.53	785.53
7	780.35	780.71	781.07	781.47	782.24	783.27	784.71	785.74
8	780.16	780.53	780.89	781.27	782.20	783.31	784.86	785.94
9	780.00	780.37	780.74	781.15	782.15	783.33	785.02	786.15
10	779.89	780.29	780.61	781.26	782.21	783.43	785.21	786.37
11	779.90	780.36	780.67	781.42	782.39	783.66	785.51	786.68
12	780.11	780.69	781.09	781.82	782.76	784.04	785.93	787.07
13	780.53	781.34	782.15	782.46	783.32	784.62	786.51	787.56
14	780.99	781.86	782.77	783.50	784.00	785.46	787.19	788.15
15	781.21	782.24	783.26	784.17	784.89	786.34	787.88	788.84
16	781.69	782.88	784.08	785.28	786.52	787.60	788.63	789.67
17	781.92	783.20	784.55	785.84	787.07	788.14	789.19	790.24
18	782.28	783.60	785.24	786.69	788.01	789.12	790.15	791.16
19	780.61	783.46	786.67	788.16	789.77	790.98	791.92	792.68
20	779.10	781.19	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.02	786.58	787.31	788.00				
4	786.23	786.95	787.63	788.00				
5	786.57	787.27	788.00	789.00				
6	786.84	787.56	788.31	789.00				
7	787.10	787.84	788.65	790.00				
8	787.35	788.10	788.92	790.00				
9	787.60	788.36	789.16	790.00				

10	787.87	788.64	789.42	790.00
11	788.21	788.98	789.77	791.00
12	788.58	789.34	790.11	791.00
13	788.99	789.74	790.49	791.00
14	789.47	790.18	790.93	792.00
15	789.96	790.65	791.35	792.00
16	790.47	791.16	791.86	793.00
17	791.06	791.72	792.31	793.00
18	791.91	792.46	792.88	793.00
19	793.18	793.53	793.79	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 59.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.51	770.51	770.51	770.51	770.51	770.51	770.51	770.51
2	770.51	770.51	770.51	770.51	770.51	770.51	770.51	770.51
3	770.51	770.51	770.51	770.51	770.51	770.51	770.51	780.86
4	775.00	775.00	776.60	777.85	778.71	779.38	779.97	780.57
5	775.00	775.00	776.64	777.84	778.67	779.30	779.79	780.54
6	775.00	775.00	776.62	777.83	778.67	779.27	779.65	780.15
7	775.00	775.00	776.64	777.86	778.77	779.41	779.77	780.14
8	775.00	775.00	776.65	777.97	779.06	779.43	779.60	780.03
9	775.00	775.00	776.73	778.11	778.69	779.10	779.38	779.91
10	775.00	775.00	776.90	778.00	778.48	778.90	779.22	779.83
11	775.00	775.00	776.99	777.76	778.31	778.77	779.13	779.85
12	775.00	775.00	777.01	777.68	778.24	778.73	779.15	780.00
13	775.00	775.00	777.01	777.65	778.24	778.78	779.26	780.27
14	775.00	775.00	776.63	777.60	778.29	778.89	779.44	780.57
15	775.00	775.68	776.67	777.73	778.43	779.09	779.72	780.90
16	770.51	775.68	776.66	778.17	778.70	779.37	780.25	781.37
17	770.51	770.51	770.51	778.14	778.96	779.55	780.43	781.59
18	770.51	770.51	770.51	770.51	778.84	779.44	780.22	781.81
19	770.51	770.51	770.51	770.51	770.51	770.51	779.63	781.32
20	770.51	770.51	770.51	770.51	770.51	770.51	770.51	770.51
	9	10	11	12	13	14	15	16
1	770.51	770.51	770.51	779.00	780.00	782.00	785.00	785.50
2	770.51	780.62	780.20	779.00	780.00	782.00	785.00	785.50
3	781.06	781.32	781.46	781.60	781.99	782.90	784.21	785.27
4	780.94	781.21	781.55	781.90	782.42	783.20	784.27	785.38

5	780.90	781.20	781.55	781.94	782.39	783.28	784.53	785.55
6	780.68	781.10	781.51	781.94	782.46	783.54	784.90	785.87
7	780.58	781.01	781.43	781.85	782.71	783.77	785.18	786.16
8	780.48	780.93	781.36	781.79	782.81	783.94	785.44	786.44
9	780.41	780.88	781.32	781.81	782.90	784.09	785.69	786.71
10	780.39	780.89	781.27	782.07	783.10	784.31	785.97	787.01
11	780.50	781.05	781.45	782.35	783.39	784.63	786.34	787.38
12	780.79	781.46	781.94	782.80	783.81	785.06	786.79	787.80
13	781.27	782.15	783.03	783.43	784.36	785.62	787.35	788.29
14	781.77	782.71	783.66	784.44	784.98	786.39	787.98	788.86
15	782.06	783.14	784.18	785.09	785.81	787.20	788.62	789.49
16	782.62	783.81	784.98	786.14	787.31	788.33	789.29	790.24
17	782.90	784.14	785.43	786.65	787.81	788.82	789.79	790.75
18	783.33	784.56	786.07	787.41	788.64	789.68	790.65	791.57
19	782.17	784.63	787.32	788.68	790.19	791.35	792.22	792.93
20	780.97	782.92	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	786.12	786.66	787.35	788.00
4	786.40	787.07	787.70	788.00
5	786.78	787.44	788.10	789.00
6	787.11	787.76	788.43	789.00
7	787.41	788.06	788.78	790.00
8	787.69	788.35	789.06	790.00
9	787.98	788.63	789.31	790.00
10	788.29	788.94	789.58	790.00
11	788.66	789.30	789.94	791.00
12	789.05	789.67	790.29	791.00
13	789.48	790.08	790.67	791.00
14	789.94	790.53	791.12	792.00
15	790.42	790.98	791.53	792.00
16	790.91	791.47	792.03	793.00
17	791.46	792.00	792.46	793.00
18	792.23	792.68	793.00	793.00
19	793.37	793.66	793.86	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 72.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW COLUMN

	1	2	3	4	5	6	7	8
1	770.62	770.62	770.62	770.62	770.62	770.62	770.62	770.62
2	770.62	770.62	770.62	770.62	770.62	770.62	770.62	770.62
3	770.62	770.62	770.62	770.62	770.62	770.62	770.62	780.89
4	775.00	775.00	776.62	777.87	778.74	779.41	780.00	780.60
5	775.00	775.00	776.65	777.86	778.70	779.33	779.82	780.57
6	775.00	775.00	776.64	777.85	778.71	779.31	779.69	780.19
7	775.00	775.00	776.66	777.88	778.80	779.45	779.82	780.26
8	775.00	775.00	776.67	778.00	779.11	779.49	779.71	780.22
9	775.00	775.00	776.75	778.15	778.78	779.23	779.55	780.18
10	775.00	775.00	776.93	778.07	778.62	779.09	779.46	780.18
11	775.00	775.00	777.03	777.87	778.50	779.02	779.45	780.28
12	775.00	775.00	777.06	777.84	778.49	779.06	779.54	780.51
13	775.00	775.00	777.09	777.87	778.57	779.19	779.74	780.85
14	775.00	775.00	776.78	777.90	778.70	779.39	780.00	781.23
15	775.00	775.77	776.89	778.12	778.94	779.68	780.38	781.65
16	770.62	775.77	776.88	778.69	779.31	780.06	781.04	782.22
17	770.62	770.62	770.62	778.67	779.68	780.33	781.30	782.49
18	770.62	770.62	770.62	770.62	779.59	780.25	781.39	782.89
19	770.62	770.62	770.62	770.62	770.62	770.62	780.96	782.51
20	770.62	770.62	770.62	770.62	770.62	770.62	770.62	770.62
	9	10	11	12	13	14	15	16
1	770.62	770.62	770.62	779.00	780.00	782.00	785.00	785.50
2	770.62	780.64	780.21	779.00	780.00	782.00	785.00	785.50
3	781.09	781.35	781.49	781.64	782.05	782.98	784.29	785.36
4	780.97	781.26	781.62	782.00	782.52	783.32	784.41	785.51
5	780.94	781.29	781.67	782.07	782.53	783.43	784.72	785.73
6	780.80	781.27	781.71	782.17	782.71	783.81	785.17	786.12
7	780.78	781.26	781.71	782.15	783.07	784.14	785.53	786.47
8	780.75	781.27	781.75	782.21	783.28	784.41	785.86	786.80
9	780.76	781.30	781.79	782.34	783.49	784.67	786.19	787.13
10	780.83	781.39	781.82	782.72	783.80	784.99	786.54	787.48
11	781.02	781.64	782.11	783.10	784.18	785.39	786.97	787.89
12	781.38	782.12	782.67	783.61	784.66	785.86	787.44	788.33
13	781.92	782.86	783.80	784.25	785.22	786.43	788.00	788.83
14	782.49	783.47	784.45	785.26	785.81	787.15	788.60	789.38
15	782.86	783.96	784.99	785.90	786.61	787.90	789.20	789.98
16	783.49	784.66	785.79	786.89	787.99	788.94	789.83	790.68
17	783.80	785.00	786.21	787.36	788.45	789.38	790.28	791.15
18	784.31	785.44	786.81	788.05	789.19	790.16	791.06	791.90
19	783.61	785.71	787.91	789.14	790.55	791.65	792.48	793.13
20	782.71	784.46	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.20	786.71	787.38	788.00				

4	786.52	787.16	787.75	788.00
5	786.93	787.55	788.16	789.00
6	787.29	787.90	788.50	789.00
7	787.62	788.22	788.87	790.00
8	787.94	788.53	789.16	790.00
9	788.25	788.82	789.42	790.00
10	788.59	789.14	789.69	790.00
11	788.98	789.52	790.06	791.00
12	789.40	789.91	790.41	791.00
13	789.83	790.32	790.80	791.00
14	790.29	790.77	791.25	792.00
15	790.76	791.22	791.66	792.00
16	791.23	791.70	792.15	793.00
17	791.75	792.20	792.57	793.00
18	792.47	792.85	793.08	793.00
19	793.51	793.76	793.91	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 87.40000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.75	770.75	770.75	770.75	770.75	770.75	770.75	770.75
2	770.75	770.75	770.75	770.75	770.75	770.75	770.75	770.75
3	770.75	770.75	770.75	770.75	770.75	770.75	770.75	780.91
4	775.00	775.00	776.63	777.89	778.76	779.43	780.03	780.63
5	775.00	775.00	776.67	777.88	778.73	779.36	779.85	780.59
6	775.00	775.00	776.65	777.88	778.73	779.34	779.72	780.23
7	775.00	775.00	776.67	777.91	778.83	779.48	779.85	780.35
8	775.00	775.00	776.68	778.03	779.14	779.55	779.80	780.38
9	775.00	775.00	776.77	778.19	778.85	779.34	779.70	780.40
10	775.00	775.00	776.95	778.13	778.74	779.25	779.67	780.47
11	775.00	775.00	777.07	777.98	778.67	779.25	779.72	780.64
12	775.00	775.00	777.11	777.99	778.72	779.35	779.89	780.95
13	775.00	775.00	777.17	778.08	778.87	779.56	780.16	781.36
14	775.00	775.00	776.93	778.18	779.08	779.83	780.50	781.81
15	775.00	775.85	777.08	778.48	779.39	780.21	780.98	782.31
16	770.75	775.85	777.08	779.16	779.85	780.68	781.74	782.97
17	770.75	770.75	770.75	779.14	780.33	781.04	782.08	783.30
18	770.75	770.75	770.75	770.75	780.26	780.98	782.43	783.85
19	770.75	770.75	770.75	770.75	770.75	770.75	782.12	783.58

20	770.75	770.75	770.75	770.75	770.75	770.75	770.75	770.75
	9	10	11	12	13	14	15	16
1	770.75	770.75	770.75	779.00	780.00	782.00	785.00	785.50
2	770.75	780.66	780.22	779.00	780.00	782.00	785.00	785.50
3	781.11	781.37	781.52	781.67	782.10	783.03	784.35	785.42
4	781.00	781.30	781.68	782.07	782.60	783.40	784.50	785.61
5	780.98	781.36	781.76	782.18	782.63	783.54	784.84	785.85
6	780.89	781.40	781.86	782.33	782.90	784.00	785.36	786.29
7	780.93	781.45	781.93	782.38	783.33	784.41	785.78	786.68
8	780.97	781.53	782.04	782.53	783.63	784.76	786.16	787.05
9	781.05	781.63	782.16	782.75	783.93	785.09	786.54	787.42
10	781.19	781.79	782.25	783.22	784.33	785.49	786.96	787.81
11	781.45	782.13	782.64	783.69	784.80	785.96	787.42	788.25
12	781.89	782.67	783.27	784.27	785.33	786.48	787.92	788.72
13	782.49	783.47	784.44	784.93	785.91	787.05	788.47	789.22
14	783.11	784.12	785.12	785.94	786.49	787.74	789.06	789.77
15	783.56	784.67	785.69	786.58	787.26	788.46	789.65	790.35
16	784.25	785.40	786.48	787.52	788.55	789.44	790.24	791.01
17	784.60	785.75	786.89	787.97	788.98	789.84	790.67	791.45
18	785.18	786.21	787.46	788.59	789.65	790.56	791.38	792.14
19	784.89	786.65	788.41	789.53	790.86	791.91	792.68	793.28
20	784.24	785.79	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.25	786.74	787.40	788.00				
4	786.60	787.22	787.78	788.00				
5	787.04	787.63	788.21	789.00				
6	787.42	787.99	788.56	789.00				
7	787.77	788.33	788.93	790.00				
8	788.11	788.65	789.23	790.00				
9	788.44	788.96	789.49	790.00				
10	788.79	789.29	789.77	790.00				
11	789.21	789.67	790.14	791.00				
12	789.64	790.08	790.50	791.00				
13	790.07	790.50	790.89	791.00				
14	790.54	790.94	791.34	792.00				
15	791.01	791.39	791.75	792.00				
16	791.47	791.86	792.23	793.00				
17	791.97	792.35	792.64	793.00				
18	792.64	792.96	793.15	793.00				
19	793.62	793.83	793.95	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 105.90000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	770.91	770.91	770.91	770.91	770.91	770.91	770.91	770.91
2	770.91	770.91	770.91	770.91	770.91	770.91	770.91	770.91
3	770.91	770.91	770.91	770.91	770.91	770.91	770.91	780.93
4	775.00	775.00	776.63	777.91	778.78	779.45	780.05	780.64
5	775.00	775.00	776.67	777.89	778.74	779.38	779.87	780.61
6	775.00	775.00	776.66	777.89	778.75	779.36	779.74	780.25
7	775.00	775.00	776.68	777.93	778.86	779.50	779.88	780.42
8	775.00	775.00	776.70	778.05	779.17	779.59	779.87	780.49
9	775.00	775.00	776.79	778.22	778.91	779.42	779.81	780.56
10	775.00	775.00	776.97	778.18	778.83	779.38	779.82	780.68
11	775.00	775.00	777.09	778.06	778.80	779.42	779.92	780.91
12	775.00	775.00	777.15	778.10	778.89	779.56	780.15	781.27
13	775.00	775.00	777.22	778.23	779.09	779.83	780.48	781.75
14	775.00	775.00	777.03	778.39	779.36	780.17	780.89	782.25
15	775.00	775.92	777.23	778.76	779.74	780.62	781.44	782.82
16	770.91	775.92	777.23	779.52	780.28	781.18	782.30	783.55
17	770.91	770.91	770.91	779.51	780.85	781.60	782.70	783.93
18	770.91	770.91	770.91	770.91	780.81	781.57	783.27	784.62
19	770.91	770.91	770.91	770.91	770.91	770.91	783.07	784.45
20	770.91	770.91	770.91	770.91	770.91	770.91	770.91	770.91
	9	10	11	12	13	14	15	16
1	770.91	770.91	770.91	779.00	780.00	782.00	785.00	785.50
2	770.91	780.67	780.23	779.00	780.00	782.00	785.00	785.50
3	781.13	781.38	781.53	781.69	782.12	783.06	784.39	785.46
4	781.01	781.32	781.72	782.11	782.65	783.45	784.56	785.67
5	781.00	781.40	781.82	782.24	782.70	783.61	784.93	785.93
6	780.95	781.48	781.96	782.45	783.02	784.13	785.48	786.40
7	781.03	781.58	782.08	782.53	783.51	784.59	785.94	786.82
8	781.12	781.71	782.25	782.75	783.87	784.99	786.36	787.21
9	781.25	781.87	782.42	783.03	784.23	785.39	786.78	787.61
10	781.45	782.09	782.56	783.58	784.70	785.84	787.23	788.03
11	781.77	782.49	783.03	784.13	785.24	786.36	787.73	788.50
12	782.26	783.09	783.71	784.75	785.81	786.91	788.25	788.98
13	782.92	783.92	784.92	785.43	786.41	787.50	788.81	789.49
14	783.58	784.62	785.62	786.45	787.00	788.17	789.39	790.04
15	784.09	785.20	786.21	787.09	787.75	788.88	789.96	790.61
16	784.84	785.96	787.00	788.00	788.98	789.80	790.55	791.24
17	785.23	786.33	787.41	788.43	789.37	790.19	790.95	791.67
18	785.87	786.81	787.96	789.01	790.00	790.85	791.62	792.32

19	785.94	787.40	788.81	789.84	791.10	792.10	792.83	793.39
20	785.51	786.85	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.28	786.76	787.41	788.00				
4	786.65	787.26	787.80	788.00				
5	787.11	787.68	788.23	789.00				
6	787.50	788.05	788.59	789.00				
7	787.87	788.40	788.97	790.00				
8	788.22	788.73	789.27	790.00				
9	788.56	789.04	789.54	790.00				
10	788.93	789.38	789.82	790.00				
11	789.36	789.78	790.19	791.00				
12	789.80	790.19	790.56	791.00				
13	790.24	790.61	790.95	791.00				
14	790.71	791.06	791.40	792.00				
15	791.18	791.51	791.81	792.00				
16	791.63	791.97	792.29	793.00				
17	792.12	792.45	792.70	793.00				
18	792.77	793.04	793.19	793.00				
19	793.70	793.88	793.97	794.00				
20	795.00	795.00	795.00	795.00				

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 128.10001

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	771.10	771.10	771.10	771.10	771.10	771.10	771.10	771.10
2	771.10	771.10	771.10	771.10	771.10	771.10	771.10	771.10
3	771.10	771.10	771.10	771.10	771.10	771.10	771.10	780.93
4	775.00	775.00	776.64	777.91	778.79	779.46	780.06	780.65
5	775.00	775.00	776.68	777.90	778.75	779.39	779.88	780.62
6	775.00	775.00	776.66	777.90	778.76	779.37	779.75	780.27
7	775.00	775.00	776.69	777.94	778.87	779.52	779.89	780.47
8	775.00	775.00	776.70	778.07	779.18	779.62	779.91	780.57
9	775.00	775.00	776.80	778.24	778.94	779.47	779.88	780.67
10	775.00	775.00	776.99	778.21	778.88	779.46	779.93	780.83
11	775.00	775.00	777.11	778.11	778.88	779.53	780.07	781.09
12	775.00	775.00	777.17	778.18	779.00	779.72	780.33	781.50
13	775.00	775.00	777.26	778.34	779.25	780.03	780.71	782.02

14	775.00	775.00	777.11	778.54	779.56	780.42	781.16	782.57
15	775.00	775.96	777.34	778.95	779.99	780.92	781.77	783.19
16	771.10	775.97	777.34	779.79	780.59	781.54	782.71	783.99
17	771.10	771.10	771.10	779.78	781.24	782.02	783.16	784.40
18	771.10	771.10	771.10	771.10	781.22	782.00	783.90	785.21
19	771.10	771.10	771.10	771.10	771.10	771.10	783.79	785.11
20	771.10	771.10	771.10	771.10	771.10	771.10	771.10	771.10
	9	10	11	12	13	14	15	16
1	771.10	771.10	771.10	779.00	780.00	782.00	785.00	785.50
2	771.10	780.67	780.24	779.00	780.00	782.00	785.00	785.50
3	781.14	781.39	781.54	781.70	782.14	783.08	784.41	785.49
4	781.02	781.33	781.74	782.14	782.68	783.49	784.60	785.70
5	781.02	781.43	781.85	782.28	782.74	783.66	784.98	785.98
6	780.99	781.54	782.03	782.52	783.10	784.21	785.56	786.47
7	781.10	781.67	782.18	782.63	783.63	784.71	786.04	786.90
8	781.23	781.84	782.38	782.90	784.03	785.14	786.49	787.32
9	781.39	782.03	782.60	783.23	784.44	785.58	786.94	787.73
10	781.63	782.29	782.78	783.83	784.95	786.08	787.42	788.17
11	782.00	782.74	783.30	784.42	785.53	786.63	787.94	788.66
12	782.53	783.38	784.03	785.09	786.14	787.21	788.47	789.15
13	783.22	784.25	785.26	785.79	786.76	787.81	789.03	789.67
14	783.92	784.97	785.97	786.81	787.35	788.47	789.61	790.21
15	784.48	785.59	786.59	787.45	788.09	789.16	790.18	790.78
16	785.27	786.38	787.38	788.34	789.28	790.06	790.76	791.40
17	785.69	786.76	787.79	788.76	789.66	790.43	791.15	791.81
18	786.38	787.26	788.32	789.31	790.25	791.06	791.79	792.44
19	786.74	787.97	789.10	790.06	791.27	792.24	792.94	793.46
20	786.48	787.66	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.30	786.78	787.42	788.00				
4	786.68	787.28	787.81	788.00				
5	787.15	787.71	788.25	789.00				
6	787.55	788.09	788.61	789.00				
7	787.93	788.44	789.00	790.00				
8	788.29	788.78	789.30	790.00				
9	788.63	789.10	789.57	790.00				
10	789.02	789.44	789.85	790.00				
11	789.46	789.84	790.23	791.00				
12	789.90	790.26	790.59	791.00				
13	790.35	790.68	790.99	791.00				
14	790.82	791.13	791.44	792.00				
15	791.29	791.58	791.85	792.00				
16	791.74	792.04	792.33	793.00				
17	792.22	792.51	792.73	793.00				

18	792.85	793.10	793.22	793.00
19	793.75	793.91	793.99	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 154.70000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	771.33	771.33	771.33	771.33	771.33	771.33	771.33	771.33
2	771.33	771.33	771.33	771.33	771.33	771.33	771.33	771.33
3	771.33	771.33	771.33	771.33	771.33	771.33	771.33	780.94
4	775.00	775.00	776.64	777.92	778.79	779.47	780.06	780.66
5	775.00	775.00	776.68	777.91	778.76	779.40	779.88	780.62
6	775.00	775.00	776.66	777.91	778.77	779.38	779.76	780.28
7	775.00	775.00	776.69	777.94	778.88	779.53	779.90	780.49
8	775.00	775.00	776.71	778.07	779.19	779.63	779.94	780.62
9	775.00	775.00	776.80	778.25	778.97	779.51	779.93	780.74
10	775.00	775.00	776.99	778.23	778.92	779.51	779.99	780.92
11	775.00	775.00	777.12	778.15	778.94	779.60	780.15	781.21
12	775.00	775.00	777.19	778.23	779.08	779.81	780.44	781.65
13	775.00	775.00	777.29	778.41	779.35	780.16	780.86	782.20
14	775.00	775.00	777.16	778.64	779.69	780.57	781.34	782.78
15	775.00	775.99	777.41	779.08	780.16	781.12	781.99	783.44
16	771.33	776.00	777.42	779.96	780.80	781.78	782.98	784.28
17	771.33	771.33	771.33	779.96	781.50	782.30	783.47	784.72
18	771.33	771.33	771.33	771.33	781.49	782.30	784.34	785.61
19	771.33	771.33	771.33	771.33	771.33	771.33	784.29	785.57
20	771.33	771.33	771.33	771.33	771.33	771.33	771.33	771.33
	9	10	11	12	13	14	15	16
1	771.33	771.33	771.33	779.00	780.00	782.00	785.00	785.50
2	771.33	780.67	780.24	779.00	780.00	782.00	785.00	785.50
3	781.14	781.39	781.55	781.71	782.15	783.09	784.42	785.50
4	781.03	781.34	781.75	782.15	782.70	783.51	784.62	785.73
5	781.03	781.45	781.88	782.31	782.76	783.68	785.01	786.01
6	781.02	781.58	782.07	782.56	783.14	784.26	785.61	786.51
7	781.15	781.73	782.24	782.69	783.70	784.78	786.11	786.96
8	781.29	781.91	782.47	782.99	784.13	785.24	786.56	787.38
9	781.48	782.14	782.71	783.35	784.56	785.70	787.03	787.81
10	781.74	782.42	782.91	783.98	785.11	786.22	787.53	788.26
11	782.14	782.90	783.47	784.61	785.72	786.80	788.06	788.76
12	782.70	783.57	784.23	785.30	786.35	787.39	788.60	789.26

13	783.42	784.46	785.48	786.01	786.98	788.00	789.17	789.78
14	784.14	785.20	786.21	787.04	787.57	788.66	789.74	790.32
15	784.74	785.85	786.84	787.68	788.31	789.35	790.32	790.89
16	785.56	786.65	787.64	788.57	789.48	790.23	790.90	791.51
17	786.00	787.05	788.05	788.98	789.85	790.59	791.28	791.91
18	786.73	787.57	788.57	789.51	790.42	791.19	791.90	792.52
19	787.30	788.36	789.30	790.21	791.38	792.33	793.01	793.51
20	787.17	788.22	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	786.31	786.79	787.42	788.00
4	786.70	787.29	787.82	788.00
5	787.17	787.73	788.26	789.00
6	787.58	788.11	788.63	789.00
7	787.96	788.47	789.01	790.00
8	788.33	788.81	789.32	790.00
9	788.68	789.13	789.59	790.00
10	789.07	789.47	789.87	790.00
11	789.52	789.88	790.25	791.00
12	789.96	790.30	790.61	791.00
13	790.42	790.73	791.01	791.00
14	790.89	791.18	791.46	792.00
15	791.36	791.63	791.87	792.00
16	791.81	792.08	792.35	793.00
17	792.29	792.55	792.75	793.00
18	792.91	793.13	793.23	793.00
19	793.78	793.93	794.00	794.00
20	795.00	795.00	795.00	795.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
2	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
3	771.59	771.59	771.59	771.59	771.59	771.59	771.59	780.94
4	775.00	775.00	776.64	777.92	778.79	779.47	780.07	780.66
5	775.00	775.00	776.68	777.91	778.76	779.40	779.89	780.63
6	775.00	775.00	776.67	777.91	778.77	779.38	779.77	780.28
7	775.00	775.00	776.70	777.95	778.88	779.53	779.91	780.51

8	775.00	775.00	776.71	778.08	779.20	779.64	779.95	780.65
9	775.00	775.00	776.81	778.25	778.98	779.53	779.95	780.78
10	775.00	775.00	777.00	778.24	778.94	779.54	780.03	780.97
11	775.00	775.00	777.13	778.16	778.97	779.64	780.20	781.28
12	775.00	775.00	777.20	778.25	779.12	779.87	780.51	781.73
13	775.00	775.00	777.30	778.45	779.41	780.23	780.94	782.30
14	775.00	775.00	777.19	778.69	779.77	780.67	781.45	782.90
15	775.00	776.01	777.45	779.16	780.26	781.24	782.12	783.59
16	771.59	776.02	777.46	780.06	780.92	781.92	783.15	784.45
17	771.59	771.59	771.59	780.07	781.65	782.47	783.66	784.92
18	771.59	771.59	771.59	771.59	781.65	782.47	784.61	785.85
19	771.59	771.59	771.59	771.59	771.59	771.59	784.60	785.85
20	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
	9	10	11	12	13	14	15	16
1	771.59	771.59	771.59	779.00	780.00	782.00	785.00	785.50
2	771.59	780.68	780.24	779.00	780.00	782.00	785.00	785.50
3	781.14	781.40	781.55	781.72	782.16	783.10	784.43	785.51
4	781.03	781.35	781.76	782.16	782.71	783.52	784.63	785.74
5	781.03	781.46	781.89	782.32	782.77	783.70	785.02	786.02
6	781.03	781.60	782.10	782.59	783.17	784.29	785.63	786.53
7	781.17	781.76	782.28	782.73	783.74	784.82	786.14	786.99
8	781.33	781.96	782.52	783.04	784.18	785.29	786.61	787.42
9	781.53	782.19	782.78	783.41	784.63	785.76	787.08	787.85
10	781.80	782.49	782.99	784.07	785.20	786.30	787.59	788.30
11	782.22	782.99	783.56	784.71	785.82	786.89	788.13	788.81
12	782.80	783.68	784.34	785.42	786.46	787.49	788.68	789.31
13	783.53	784.58	785.60	786.14	787.11	788.11	789.24	789.84
14	784.27	785.34	786.34	787.18	787.71	788.77	789.82	790.39
15	784.89	786.00	786.99	787.82	788.44	789.46	790.40	790.95
16	785.74	786.82	787.79	788.70	789.59	790.33	790.97	791.56
17	786.19	787.22	788.20	789.11	789.96	790.68	791.35	791.96
18	786.95	787.75	788.72	789.64	790.52	791.28	791.96	792.57
19	787.65	788.61	789.42	790.30	791.45	792.38	793.05	793.54
20	787.61	788.57	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.31	786.79	787.42	788.00				
4	786.71	787.30	787.83	788.00				
5	787.19	787.74	788.27	789.00				
6	787.60	788.12	788.63	789.00				
7	787.98	788.48	789.02	790.00				
8	788.35	788.82	789.33	790.00				
9	788.71	789.15	789.60	790.00				
10	789.10	789.49	789.88	790.00				
11	789.55	789.90	790.26	791.00				

12	790.00	790.32	790.63	791.00
13	790.45	790.75	791.03	791.00
14	790.93	791.20	791.48	792.00
15	791.39	791.65	791.89	792.00
16	791.85	792.11	792.36	793.00
17	792.32	792.57	792.76	793.00
18	792.94	793.15	793.24	793.00
19	793.80	793.94	794.00	794.00
20	795.00	795.00	795.00	795.00

OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR AREA C MODEL
WITH DISCHARGE TO RIVER

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
2	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
3	771.59	771.59	771.59	771.59	771.59	771.59	771.59	780.80
4	775.00	775.00	776.58	777.82	778.66	779.31	779.90	780.50
5	775.00	775.00	776.62	777.80	778.61	779.23	779.71	780.46
6	775.00	775.00	776.60	777.78	778.60	779.17	779.52	779.96
7	775.00	775.00	776.62	777.80	778.69	779.29	779.60	779.55
8	775.00	775.00	776.62	777.92	778.98	779.24	779.18	779.01
9	775.00	775.00	776.71	778.06	778.55	778.79	778.78	778.49
10	775.00	775.00	776.89	777.96	778.36	778.59	778.59	778.30
11	775.00	775.00	777.00	777.78	778.28	778.59	778.68	778.60
12	775.00	775.00	777.06	777.82	778.39	778.80	779.05	779.40
13	775.00	775.00	777.14	777.98	778.67	779.22	779.65	780.42
14	775.00	775.00	776.94	778.19	779.04	779.73	780.32	781.41
15	775.00	775.88	777.15	778.61	779.54	780.36	781.11	782.35
16	771.59	775.89	777.15	779.42	780.18	781.08	782.23	783.46
17	771.59	771.59	771.59	779.42	780.86	781.62	782.76	783.99
18	771.59	771.59	771.59	771.59	780.87	781.63	783.72	784.97
19	771.59	771.59	771.59	771.59	771.59	771.59	783.72	784.97
20	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
	9	10	11	12	13	14	15	16
1	771.59	771.59	771.59	779.00	780.00	782.00	785.00	785.50
2	771.59	780.60	780.18	779.00	780.00	782.00	785.00	785.50
3	781.01	781.28	781.43	781.57	781.99	782.94	784.29	785.39
4	780.87	781.11	781.43	781.82	782.39	783.25	784.40	785.56
5	780.75	780.95	781.30	781.76	782.32	783.34	784.73	785.80
6	780.19	780.47	780.92	781.51	782.23	783.60	785.20	786.23
7	779.60	779.80	780.35	781.10	782.40	783.84	785.57	786.61
8	778.80	778.69	779.53	780.46	782.33	784.03	785.93	786.98
9	777.82	776.50	778.48	779.95	782.32	784.25	786.31	787.37
10	777.47	775.74	777.83	780.44	782.71	784.66	786.75	787.79
11	778.04	776.48	778.44	781.24	783.42	785.28	787.29	788.29
12	779.56	779.69	780.68	782.58	784.36	786.04	787.89	788.82
13	781.16	781.96	783.30	784.00	785.40	786.88	788.55	789.38

14	782.53	783.48	784.63	785.69	786.36	787.81	789.24	789.98
15	783.53	784.61	785.68	786.66	787.41	788.71	789.90	790.59
16	784.71	785.81	786.87	787.89	788.93	789.79	790.55	791.26
17	785.28	786.36	787.41	788.43	789.38	790.21	790.98	791.70
18	786.15	787.00	788.09	789.09	790.07	790.90	791.67	792.36
19	786.96	788.03	789.01	789.96	791.17	792.16	792.87	793.42
20	786.93	788.00	787.00	790.00	793.00	795.00	795.00	795.00
	17	18	19	20				
1	786.00	786.00	787.00	788.00				
2	786.00	786.00	787.00	788.00				
3	786.24	786.75	787.40	788.00				
4	786.59	787.23	787.79	788.00				
5	787.04	787.64	788.22	789.00				
6	787.42	788.01	788.57	789.00				
7	787.78	788.35	788.95	790.00				
8	788.13	788.68	789.25	790.00				
9	788.47	789.00	789.52	790.00				
10	788.85	789.34	789.81	790.00				
11	789.30	789.75	790.18	791.00				
12	789.75	790.17	790.55	791.00				
13	790.21	790.60	790.95	791.00				
14	790.70	791.06	791.40	792.00				
15	791.18	791.52	791.82	792.00				
16	791.65	791.98	792.30	793.00				
17	792.15	792.47	792.71	793.00				
18	792.80	793.06	793.20	793.00				
19	793.72	793.89	793.98	794.00				
20	795.00	795.00	795.00	795.00				

OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR AREA C MODEL
WITH DISCHARGE TO LAKES

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
2	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
3	771.59	771.59	771.59	771.59	771.59	771.59	771.59	780.84
4	775.00	775.00	776.60	777.85	778.70	779.36	779.95	780.55
5	775.00	775.00	776.64	777.84	778.66	779.28	779.76	780.50
6	775.00	775.00	776.62	777.83	778.66	779.24	779.60	780.05
7	775.00	775.00	776.65	777.86	778.76	779.37	779.70	779.80
8	775.00	775.00	776.66	777.99	779.07	779.39	779.43	779.45
9	775.00	775.00	776.76	778.16	778.76	779.11	779.21	779.16
10	775.00	775.00	776.96	778.13	778.69	779.07	779.23	779.25
11	775.00	775.00	777.10	778.06	778.75	779.25	779.55	779.91
12	775.00	775.00	777.19	778.20	779.00	779.66	780.18	781.12
13	775.00	775.00	777.32	778.47	779.44	780.27	781.02	782.55
14	775.00	775.00	777.25	778.81	779.94	780.92	781.85	783.76
15	775.00	776.05	777.55	779.36	780.55	781.64	782.69	784.53
16	771.59	776.06	777.56	780.36	781.31	782.44	783.84	785.37
17	771.59	771.59	771.59	780.36	782.13	783.06	784.39	785.80
18	771.59	771.59	771.59	771.59	782.13	783.06	785.39	786.73
19	771.59	771.59	771.59	771.59	771.59	771.59	785.38	786.72
20	771.59	771.59	771.59	771.59	771.59	771.59	771.59	771.59
	9	10	11	12	13	14	15	16
1	771.59	771.59	771.59	779.00	780.00	782.00	785.00	785.50
2	771.59	780.62	780.20	779.00	780.00	782.00	785.00	785.50
3	781.05	781.31	781.47	781.63	782.07	783.03	784.39	785.50
4	780.92	781.18	781.53	781.94	782.52	783.39	784.56	785.72
5	780.82	781.09	781.48	781.95	782.50	783.53	784.95	786.02
6	780.40	780.76	781.25	781.85	782.58	783.96	785.56	786.55
7	779.98	780.27	780.86	781.59	782.94	784.38	786.08	787.04
8	779.40	779.40	780.29	781.23	783.11	784.78	786.60	787.54
9	778.70	777.54	779.55	781.05	783.42	785.29	787.22	788.08
10	778.72	777.19	779.25	781.97	784.22	786.09	788.00	788.72
11	779.77	778.54	780.56	783.39	785.49	787.24	789.00	789.49
12	781.87	782.46	783.65	785.51	787.13	788.67	790.23	790.31
13	784.20	785.72	787.75	787.91	788.89	790.32	791.88	791.13

14	786.06	787.46	789.12	789.85	790.22	792.18	792.93	791.77
15	786.31	787.71	788.97	789.84	790.45	791.62	792.40	792.12
16	786.87	788.10	789.16	790.07	790.86	791.55	792.17	792.43
17	787.23	788.35	789.35	790.24	791.03	791.69	792.28	792.67
18	787.93	788.73	789.65	790.51	791.33	792.03	792.64	793.09
19	788.52	789.39	790.04	790.85	791.93	792.81	793.43	793.83
20	788.47	789.34	787.00	790.00	793.00	795.00	795.00	795.00

	17	18	19	20
1	786.00	786.00	787.00	788.00
2	786.00	786.00	787.00	788.00
3	786.32	786.80	787.43	788.00
4	786.73	787.33	787.84	788.00
5	787.23	787.78	788.30	789.00
6	787.66	788.18	788.67	789.00
7	788.08	788.57	789.07	790.00
8	788.49	788.93	789.39	790.00
9	788.90	789.28	789.67	790.00
10	789.36	789.67	789.97	790.00
11	789.91	790.12	790.37	791.00
12	790.45	790.59	790.75	791.00
13	790.98	791.05	791.17	791.00
14	791.49	791.52	791.63	792.00
15	791.94	791.97	792.04	792.00
16	792.37	792.41	792.51	793.00
17	792.78	792.84	792.89	793.00
18	793.29	793.36	793.35	793.00
19	794.00	794.07	794.07	794.00
20	795.00	795.00	795.00	795.00

OUTPUT FILE FOR CALIBRATED SITE MODEL

MODEL DATA BASE SPECIFICATION:

Number of time increments= 20

Time increment number= 1

Time at end of time increment in days= 1.00000

Time increment in days= 1.00000

Time increment number= 2

Time at end of time increment in days= 2.20000

Time increment in days= 1.20000

Time increment number= 3

Time at end of time increment in days= 3.64000

Time increment in days= 1.44000

Time increment number= 4

Time at end of time increment in days= 5.36800

Time increment in days= 1.72800

Time increment number= 5

Time at end of time increment in days= 7.41600

Time increment in days= 2.04800

Time increment number= 6

Time at end of time increment in days= 9.93000

Time increment in days= 2.51400

Time increment number= 7

Time at end of time increment in days= 12.90000

Time increment in days= 2.97000

Time increment number= 8

Time at end of time increment in days= 16.50000

Time increment in days= 3.60000

Time increment number= 9

Time at end of time increment in days= 20.80000

Time increment in days= 4.30000

Time increment number= 10

Time at end of time increment in days= 26.00000

Time increment in days= 5.20000

Time increment number= 11

Time at end of time increment in days= 32.20000

Time increment in days= 6.20000

Time increment number= 12

Time at end of time increment in days= 39.60000

Time increment in days= 7.40000

Time increment number= 13

Time at end of time increment in days= 48.50000

Time increment in days= 8.90000

Time increment number= 14

Time at end of time increment in days= 59.20000

Time increment in days= 10.70000
 Time increment number= 15
 Time at end of time increment in days= 72.00000
 Time increment in days= 12.80000
 Time increment number= 16
 Time at end of time increment in days= 87.40000
 Time increment in days= 15.40000
 Time increment number= 17
 Time at end of time increment in days= 105.90000
 Time increment in days= 18.50000
 Time increment number= 18
 Time at end of time increment in days= 128.10001
 Time increment in days= 22.20000
 Time increment number= 19
 Time at end of time increment in days= 154.70000
 Time increment in days= 26.59999
 Time increment number= 20
 Time at end of time increment in days= 186.00000
 Time increment in days= 31.30000
 Number of grid columns= 10
 Number of grid rows= 11
 Number of units or layers= 1
 Number of production wells= 0
 Number of injection wells= 0
 Number of time-head observation wells= 0

Column Number	Grid Spacing (ft)
1	250.00
2	250.00
3	250.00
4	250.00
5	250.00
6	250.00
7	250.00
8	250.00
9	350.00
10	450.00

Row Number	Grid Spacing (ft)
1	250.00
2	250.00
3	250.00
4	250.00
5	250.00
6	250.00
7	250.00

8	250.00
9	250.00
10	250.00
11	250.00

Aquifer unit or layer number 1

Hydraulic Conductivity in I-Direction
in gpd/sq ft:

	1	2	3	4	5	6	7	8
1*****								
2*****	700.00	700.00	700.00	700.00	700.00	300.00	300.00	
3*****	700.00	700.00	700.00	700.00	300.00	300.00	300.00	
4*****	700.00	700.00	700.00	700.00	300.00	300.00	300.00	
5*****	700.00	700.00	700.00	700.00	300.00	300.00	300.00	
6*****	700.00	700.00	700.00	300.00	300.00	300.00	300.00	
7*****	700.00	700.00	700.00	300.00	300.00	300.00	300.00	
8*****	700.00	700.00	700.00	300.00	300.00	300.00	300.00	
9*****	700.00	700.00	700.00	700.00	300.00	300.00	300.00	
10*****	700.00	700.00	700.00	700.00	700.00	300.00	300.00	
11*****								

	9	10
1*****		
2 980.00*****		
3 980.00*****		
4 980.00*****		
5 980.00*****		
6 980.00*****		
7 980.00*****		
8 980.00*****		
9 980.00*****		
10 980.00*****		
11*****		

Hydraulic Conductivity in J-Direction
in gpd/sq ft:

	1	2	3	4	5	6	7	8
1*****								
2*****	700.00	700.00	700.00	700.00	700.00	300.00	250.00	
3*****	700.00	700.00	700.00	700.00	300.00	300.00	250.00	
4*****	700.00	700.00	700.00	700.00	300.00	300.00	250.00	
5*****	700.00	700.00	700.00	700.00	300.00	300.00	250.00	
6*****	700.00	700.00	700.00	300.00	300.00	300.00	250.00	
7*****	700.00	700.00	700.00	300.00	300.00	300.00	250.00	
8*****	700.00	700.00	700.00	300.00	300.00	300.00	250.00	
9*****	700.00	700.00	700.00	700.00	300.00	300.00	250.00	

10***** 700.00 700.00 700.00 700.00 700.00 300.00 250.00

11*****

9 10

1*****

2 437.50*****

3 437.50*****

4 437.50*****

5 437.50*****

6 437.50*****

7 437.50*****

8 437.50*****

9 437.50*****

10 437.50*****

11*****

Aquifer Thickness in ft:

	1	2	3	4	5	6	7	8
1	81.00	86.00	86.00	95.00	104.00	108.00	108.00	108.00
2	86.00	90.00	95.00	99.00	104.00	108.00	113.00	113.00
3	90.00	90.00	95.00	104.00	104.00	108.00	113.00	117.00
4	90.00	90.00	90.00	90.00	99.00	99.00	104.00	108.00
5	86.00	86.00	86.00	93.00	90.00	90.00	90.00	90.00
6	79.00	79.00	77.00	83.00	86.00	86.00	86.00	86.00
7	72.00	72.00	72.00	72.00	72.00	72.00	72.00	77.00
8	63.00	68.00	72.00	77.00	75.00	77.00	75.00	77.00
9	54.00	59.00	63.00	68.00	68.00	69.00	69.00	70.00
10	63.00	64.00	65.00	66.00	67.00	68.00	68.00	68.00
11	50.00	54.00	59.00	61.00	63.00	65.00	68.00	68.00

9 10

1 106.00 106.00

2 117.00 117.00

3 117.00 117.00

4 113.00 117.00

5 90.00 104.00

6 86.00 86.00

7 77.00 81.00

8 81.00 81.00

9 72.00 75.00

10 70.00 72.00

11 70.00 72.00

Aquifer top elevation in ft:

	1	2	3	4	5	6	7	8
1	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
2	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
3	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00

4	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
5	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
6	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
7	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
8	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
9	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
10	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00
11	790.00	790.00	790.00	790.00	790.00	790.00	790.00	790.00

9 10

1	790.00	790.00
2	790.00	790.00
3	790.00	790.00
4	790.00	790.00
5	790.00	790.00
6	790.00	790.00
7	790.00	790.00
8	790.00	790.00
9	790.00	790.00
10	790.00	790.00
11	790.00	790.00

Aquifer base elevation in ft:

	1	2	3	4	5	6	7	8
1	709.00	704.00	704.00	695.00	686.00	682.00	682.00	682.00
2	704.00	700.00	695.00	691.00	686.00	682.00	677.00	677.00
3	700.00	700.00	695.00	686.00	686.00	682.00	677.00	673.00
4	700.00	700.00	700.00	700.00	691.00	691.00	686.00	682.00
5	704.00	704.00	704.00	697.00	700.00	700.00	700.00	700.00
6	711.00	711.00	713.00	707.00	704.00	704.00	704.00	704.00
7	718.00	718.00	718.00	718.00	718.00	718.00	718.00	713.00
8	727.00	722.00	718.00	713.00	715.00	713.00	715.00	713.00
9	736.00	731.00	727.00	722.00	722.00	721.00	721.00	720.00
10	727.00	726.00	725.00	724.00	723.00	722.00	722.00	722.00
11	740.00	736.00	731.00	729.00	727.00	725.00	722.00	722.00

9 10

1	684.00	684.00
2	673.00	673.00
3	673.00	673.00
4	677.00	673.00
5	700.00	686.00
6	704.00	704.00
7	713.00	709.00
8	709.00	709.00
9	718.00	715.00
10	720.00	718.00
11	720.00	718.00

Initial head elevation in ft:

	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
3	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
4	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
5	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
6	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
7	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
8	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
9	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
10	778.00	775.00	775.00	775.00	775.00	775.00	775.00	775.00
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

	9	10
1	787.00	787.00
2	775.00	787.00
3	775.00	787.50
4	775.00	788.00
5	775.00	788.50
6	775.00	788.50
7	775.00	788.00
8	775.00	788.00
9	775.00	788.00
10	775.00	789.00
11	788.00	789.00

Transmissivity in I-Direction in gpd/ft:

	1	2	3	4	5	6	7	8
1	*****							
2	*****	63000.	66500.	69300.	72800.	75600.	33900.	33900.
3	*****	63000.	66500.	72800.	72800.	32400.	33900.	35100.
4	*****	63000.	63000.	63000.	69300.	29700.	31200.	32400.
5	*****	60200.	60200.	65100.	63000.	27000.	27000.	27000.
6	*****	55300.	53900.	58100.	25800.	25800.	25800.	25800.
7	*****	50400.	50400.	50400.	21600.	21600.	21600.	23100.
8	*****	47600.	50400.	53900.	22500.	23100.	22500.	23100.
9	*****	41300.	44100.	47600.	47600.	20700.	20700.	21000.
10	*****	44800.	45500.	46200.	46900.	47600.	20400.	20400.
11	*****							

	9	10
1	*****	*****
2	114660.	*****
3	114660.	*****
4	110740.	*****
5	88200.	*****
6	84280.	*****

7 75460.*****
 8 79380.*****
 9 70560.*****
 10 68600.*****
 11*****

Transmissivity in J-Direction in gpd/ft:

	1	2	3	4	5	6	7	8
1*****								
2*****	63000.	66500.	69300.	72800.	75600.	33900.	28250.	
3*****	63000.	66500.	72800.	72800.	32400.	33900.	29250.	
4*****	63000.	63000.	63000.	69300.	29700.	31200.	27000.	
5*****	60200.	60200.	65100.	63000.	27000.	27000.	22500.	
6*****	55300.	53900.	58100.	25800.	25800.	25800.	21500.	
7*****	50400.	50400.	50400.	21600.	21600.	21600.	19250.	
8*****	47600.	50400.	53900.	22500.	23100.	22500.	19250.	
9*****	41300.	44100.	47600.	47600.	20700.	20700.	17500.	
10*****	44800.	45500.	46200.	46900.	47600.	20400.	17000.	
11*****								

	9	10
1*****		
2 51188.*****		
3 51188.*****		
4 49438.*****		
5 39375.*****		
6 37625.*****		
7 33688.*****		
8 35438.*****		
9 31500.*****		
10 30625.*****		
11*****		

Aquitard vertical hydraulic conductivity
 in gpd/sq ft:

	1	2	3	4	5	6	7	8
1 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
2 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
3 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
4 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
5 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
6 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
7 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
8 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
9 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
10 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								
11 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000 0.000000								

	9	10
1	0.000000	0.000000
2	0.000000	0.000000
3	0.000000	0.000000
4	0.000000	0.000000
5	0.000000	0.000000
6	0.000000	0.000000
7	0.000000	0.000000
8	0.000000	0.000000
9	0.000000	0.000000
10	0.000000	0.000000
11	0.000000	0.000000

Aquitard thickness in ft:

	1	2	3	4	5	6	7	8
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	9	10
1	0.00	0.00
2	0.00	0.00
3	0.00	0.00
4	0.00	0.00
5	0.00	0.00
6	0.00	0.00
7	0.00	0.00
8	0.00	0.00
9	0.00	0.00
10	0.00	0.00
11	0.00	0.00

Simulation factor in gpd/ft:

	1	2	3	4	5	6	7	8
1	0.	0.	0.	0.	0.	0.	0.	0.
2	0.	0.	0.	0.	0.	0.	0.	0.
3	0.	0.	0.	0.	0.	0.	0.	0.
4	0.	0.	0.	0.	0.	0.	0.	0.
5	0.	0.	0.	0.	0.	0.	0.	0.

6	0.	0.	0.	0.	0.	0.	0.	0.
7	0.	0.	0.	0.	0.	0.	0.	0.
8	0.	0.	0.	0.	0.	0.	0.	0.
9	0.	0.	0.	0.	0.	0.	0.	0.
10	0.	0.	0.	0.	0.	0.	0.	0.
11	0.	0.	0.	0.	0.	0.	0.	0.

	9	10
1	0.	0.
2	0.	0.
3	0.	0.
4	0.	0.
5	0.	0.
6	0.	0.
7	0.	0.
8	0.	0.
9	0.	0.
10	0.	0.
11	0.	0.

Aquifer specific yield factor as a decimal:

	1	2	3	4	5	6	7	8
1	*****							
2	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
3	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
4	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
5	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
6	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
7	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
8	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
9	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
10	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000	0.200000
11	*****							

	9	10
1	*****	
2	0.200000	*****
3	0.200000	*****
4	0.200000	*****
5	0.200000	*****
6	0.200000	*****
7	0.200000	*****
8	0.200000	*****
9	0.200000	*****
10	0.200000	*****
11	*****	

Areal recharge rate in inches per year= 7.500

Stream node number= 1
I-coordinate of stream node= 3
J-coordinate of stream node= 9
Streambed width simulated at node in ft= 125.00
Streambed length simulated at node in ft= 125.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 2
I-coordinate of stream node= 3
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 3
I-coordinate of stream node= 4
J-coordinate of stream node= 9
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 125.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 4
I-coordinate of stream node= 4
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 125.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 780.00
Streambed base elevation in ft= 760.00

Stream node number= 5
I-coordinate of stream node= 5

J-coordinate of stream node= 9
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 761.00

Stream node number= 6
I-coordinate of stream node= 5
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 250.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 761.00

Stream node number= 7
I-coordinate of stream node= 6
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 125.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 761.00

Stream node number= 8
I-coordinate of stream node= 8
J-coordinate of stream node= 10
Streambed width simulated at node in ft= 250.00
Streambed length simulated at node in ft= 170.00
Streambed thickness simulated at node in ft= 1.00
Hydraulic conductivity of streambed
simulated at node in gpd/sq ft= 0.052
Stream surface elevation in ft= 781.00
Streambed base elevation in ft= 761.00

Stream node number= 9
I-coordinate of stream node= 9
J-coordinate of stream node= 9
Streambed width simulated at node in ft= 160.00

Streambed length simulated at node in ft= 350.00
 Streambed thickness simulated at node in ft= 1.00
 Hydraulic conductivity of streambed
 simulated at node in gpd/sq ft= 0.052
 Stream surface elevation in ft= 790.00
 Streambed base elevation in ft= 770.00

Stream node number= 10
 I-coordinate of stream node= 9
 J-coordinate of stream node= 10
 Streambed width simulated at node in ft= 250.00
 Streambed length simulated at node in ft= 350.00
 Streambed thickness simulated at node in ft= 1.00
 Hydraulic conductivity of streambed
 simulated at node in gpd/sq ft= 0.052
 Stream surface elevation in ft= 790.00
 Streambed base elevation in ft= 770.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 1.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	776.77	776.57	776.74	777.76	777.34	777.86
4	778.00	778.00	776.11	775.65	775.58	775.56	775.57	776.04
5	778.00	778.00	775.91	775.35	775.21	775.14	775.17	775.54
6	778.00	778.00	775.82	775.25	775.11	775.05	775.09	775.40
7	778.00	778.00	775.77	775.22	775.08	775.03	775.06	775.33
8	778.00	778.00	775.76	775.24	775.11	775.06	775.09	775.36
9	778.00	778.00	775.81	775.41	775.43	775.30	775.27	775.56
10	778.00	778.00	776.23	776.00	776.27	776.95	776.65	777.09
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	780.70	787.50						
4	778.80	788.00						
5	778.05	788.50						
6	777.66	788.50						
7	777.43	788.00						

8	777.50	788.00
9	777.94	788.00
10	779.96	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 2.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	777.64	777.55	777.86	779.28	779.17	780.12
4	778.00	778.00	776.88	776.41	776.34	776.37	776.56	777.60
5	778.00	778.00	776.55	775.87	775.63	775.49	775.63	776.54
6	778.00	778.00	776.39	775.64	775.38	775.21	775.34	776.16
7	778.00	778.00	776.32	775.56	775.26	775.14	775.26	775.99
8	778.00	778.00	776.32	775.62	775.36	775.23	775.34	776.08
9	778.00	778.00	776.46	775.96	776.00	775.81	775.83	776.59
10	778.00	778.00	776.97	776.78	777.23	778.29	778.13	779.04
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
9 10								
1	787.00	787.00						
2	787.00	787.00						
3	783.47	787.50						
4	781.63	788.00						
5	780.61	788.50						
6	779.98	788.50						
7	779.64	788.00						
8	779.78	788.00						
9	780.56	788.00						
10	782.96	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 3.64000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
-----	--------	--	--	--	--	--	--	--

	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.09	778.16	778.59	780.17	780.54	781.78
4	778.00	778.00	777.41	777.10	777.11	777.25	777.75	779.26
5	778.00	778.00	777.02	776.45	776.20	776.04	776.38	777.84
6	778.00	778.00	776.82	776.11	775.80	775.53	775.84	777.21
7	778.00	778.00	776.73	775.97	775.58	775.38	775.66	776.95
8	778.00	778.00	776.76	776.08	775.74	775.56	775.82	777.11
9	778.00	778.00	776.96	776.54	776.63	776.45	776.63	777.91
10	778.00	778.00	777.44	777.37	777.95	779.25	779.39	780.71
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

	9	10
1	787.00	787.00
2	787.00	787.00
3	784.89	787.50
4	783.51	788.00
5	782.57	788.50
6	781.90	788.50
7	781.54	788.00
8	781.73	788.00
9	782.62	788.00
10	784.76	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 5.36800

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.35	778.56	779.08	780.75	781.55	782.95
4	778.00	778.00	777.78	777.67	777.80	778.10	778.96	780.75
5	778.00	778.00	777.40	777.00	776.83	776.74	777.37	779.24
6	778.00	778.00	777.17	776.60	776.33	776.06	776.60	778.44
7	778.00	778.00	777.08	776.42	776.02	775.80	776.31	778.11
8	778.00	778.00	777.12	776.56	776.23	776.07	776.56	778.34
9	778.00	778.00	777.34	777.08	777.25	777.18	777.61	779.33
10	778.00	778.00	777.73	777.82	778.50	779.96	780.42	782.06
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						

1	787.00	787.00
2	787.00	787.00
3	785.68	787.50
4	784.73	788.00
5	783.99	788.50
6	783.39	788.50
7	783.07	788.00
8	783.28	788.00
9	784.13	788.00
10	785.86	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 7.41600

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.52	778.84	779.44	781.17	782.29	783.76
4	778.00	778.00	778.04	778.12	778.40	778.87	780.06	781.97
5	778.00	778.00	777.70	777.50	777.48	777.53	778.46	780.56
6	778.00	778.00	777.47	777.10	776.93	776.77	777.57	779.72
7	778.00	778.00	777.37	776.90	776.55	776.44	777.20	779.36
8	778.00	778.00	777.42	777.04	776.79	776.75	777.50	779.63
9	778.00	778.00	777.64	777.55	777.84	777.92	778.66	780.67
10	778.00	778.00	777.94	778.15	778.93	780.51	781.24	783.09
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	786.14	787.50						
4	785.51	788.00						
5	784.99	788.50						
6	784.50	788.50						
7	784.24	788.00						
8	784.43	788.00						
9	785.18	788.00						
10	786.54	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 9.93000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.64	779.05	779.72	781.48	782.85	784.34
4	778.00	778.00	778.25	778.51	778.93	779.56	781.01	782.95
5	778.00	778.00	777.96	777.97	778.12	778.35	779.58	781.76
6	778.00	778.00	777.75	777.59	777.57	777.64	778.69	780.97
7	778.00	778.00	777.65	777.39	777.18	777.27	778.30	780.64
8	778.00	778.00	777.70	777.51	777.40	777.59	778.61	780.91
9	778.00	778.00	777.89	777.97	778.40	778.68	779.73	781.89
10	778.00	778.00	778.09	778.42	779.29	780.96	781.91	783.89
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	786.43	787.50						
4	786.04	788.00						
5	785.69	788.50						
6	785.33	788.50						
7	785.12	788.00						
8	785.30	788.00						
9	785.92	788.00						
10	786.98	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 12.90000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.73	779.23	779.95	781.73	783.27	784.75
4	778.00	778.00	778.42	778.83	779.38	780.14	781.79	783.69
5	778.00	778.00	778.18	778.40	778.71	779.13	780.59	782.74
6	778.00	778.00	778.00	778.06	778.21	778.55	779.82	782.09

7	778.00	778.00	777.91	777.86	777.83	778.20	779.46	781.80
8	778.00	778.00	777.95	777.97	778.02	778.48	779.74	782.06
9	778.00	778.00	778.10	778.35	778.91	779.39	780.71	782.90
10	778.00	778.00	778.21	778.64	779.58	781.32	782.45	784.49
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

9 10

1	787.00	787.00
2	787.00	787.00
3	786.62	787.50
4	786.39	788.00
5	786.19	788.50
6	785.93	788.50
7	785.77	788.00
8	785.92	788.00
9	786.43	788.00
10	787.27	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 16.50000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW

COLUMN

	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.81	779.37	780.14	781.93	783.58	785.04
4	778.00	778.00	778.56	779.11	779.77	780.64	782.42	784.26
5	778.00	778.00	778.38	778.78	779.26	779.85	781.48	783.55
6	778.00	778.00	778.24	778.50	778.82	779.45	780.88	783.04
7	778.00	778.00	778.15	778.32	778.47	779.16	780.59	782.83
8	778.00	778.00	778.18	778.39	778.62	779.37	780.81	783.04
9	778.00	778.00	778.28	778.68	779.36	780.03	781.57	783.72
10	778.00	778.00	778.31	778.83	779.83	781.63	782.88	784.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

9 10

1	787.00	787.00
2	787.00	787.00
3	786.75	787.50
4	786.64	788.00
5	786.54	788.50
6	786.37	788.50
7	786.24	788.00

8	786.37	788.00
9	786.79	788.00
10	787.47	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 20.80000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.87	779.48	780.30	782.08	783.81	785.25
4	778.00	778.00	778.69	779.34	780.09	781.03	782.90	784.67
5	778.00	778.00	778.55	779.10	779.71	780.44	782.20	784.16
6	778.00	778.00	778.44	778.88	779.34	780.23	781.77	783.81
7	778.00	778.00	778.36	778.72	779.05	780.03	781.57	783.67
8	778.00	778.00	778.38	778.77	779.16	780.17	781.74	783.84
9	778.00	778.00	778.43	778.97	779.75	780.59	782.29	784.35
10	778.00	778.00	778.39	778.98	780.04	781.87	783.22	785.27
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
9 10								
1	787.00	787.00						
2	787.00	787.00						
3	786.84	787.50						
4	786.81	788.00						
5	786.80	788.50						
6	786.69	788.50						
7	786.59	788.00						
8	786.70	788.00						
9	787.04	788.00						
10	787.61	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 26.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN
-----	--------

	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.92	779.57	780.42	782.20	783.98	785.40
4	778.00	778.00	778.78	779.52	780.34	781.35	783.27	784.98
5	778.00	778.00	778.69	779.36	780.08	780.92	782.76	784.63
6	778.00	778.00	778.61	779.20	779.78	780.89	782.49	784.40
7	778.00	778.00	778.54	779.07	779.55	780.77	782.38	784.32
8	778.00	778.00	778.55	779.09	779.62	780.85	782.49	784.45
9	778.00	778.00	778.57	779.21	780.08	781.05	782.85	784.83
10	778.00	778.00	778.46	779.11	780.21	782.07	783.48	785.51
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

	9	10
1	787.00	787.00
2	787.00	787.00
3	786.91	787.50
4	786.93	788.00
5	786.98	788.50
6	786.92	788.50
7	786.85	788.00
8	786.93	788.00
9	787.22	788.00
10	787.70	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 32.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.96	779.64	780.51	782.29	784.10	785.51
4	778.00	778.00	778.86	779.66	780.54	781.58	783.53	785.19
5	778.00	778.00	778.80	779.57	780.37	781.29	783.17	784.96
6	778.00	778.00	778.74	779.45	780.12	781.38	783.03	784.83
7	778.00	778.00	778.69	779.34	779.94	781.33	782.98	784.80
8	778.00	778.00	778.68	779.34	779.97	781.36	783.04	784.90
9	778.00	778.00	778.67	779.39	780.33	781.39	783.26	785.17
10	778.00	778.00	778.51	779.21	780.34	782.21	783.67	785.68
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						

1	787.00	787.00
2	787.00	787.00
3	786.95	787.50
4	787.02	788.00
5	787.11	788.50
6	787.09	788.50
7	787.02	788.00
8	787.10	788.00
9	787.35	788.00
10	787.77	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 39.60000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.98	779.69	780.57	782.35	784.19	785.58
4	778.00	778.00	778.91	779.76	780.67	781.73	783.70	785.33
5	778.00	778.00	778.88	779.71	780.56	781.53	783.44	785.18
6	778.00	778.00	778.83	779.62	780.35	781.72	783.39	785.12
7	778.00	778.00	778.78	779.53	780.21	781.72	783.39	785.11
8	778.00	778.00	778.77	779.51	780.22	781.72	783.42	785.20
9	778.00	778.00	778.74	779.52	780.50	781.63	783.55	785.40
10	778.00	778.00	778.55	779.28	780.43	782.31	783.80	785.80
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
9 10								
1	787.00	787.00						
2	787.00	787.00						
3	786.98	787.50						
4	787.07	788.00						
5	787.19	788.50						
6	787.19	788.50						
7	787.14	788.00						
8	787.21	788.00						
9	787.43	788.00						
10	787.81	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 48.50000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.00	779.72	780.61	782.38	784.23	785.62
4	778.00	778.00	778.94	779.82	780.75	781.83	783.81	785.42
5	778.00	778.00	778.92	779.80	780.68	781.68	783.61	785.32
6	778.00	778.00	778.88	779.72	780.50	781.93	783.61	785.29
7	778.00	778.00	778.85	779.64	780.38	781.96	783.64	785.31
8	778.00	778.00	778.83	779.62	780.38	781.94	783.66	785.38
9	778.00	778.00	778.78	779.60	780.61	781.78	783.72	785.54
10	778.00	778.00	778.57	779.32	780.49	782.37	783.89	785.87
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	786.99	787.50						
4	787.11	788.00						
5	787.24	788.50						
6	787.26	788.50						
7	787.21	788.00						
8	787.27	788.00						
9	787.48	788.00						
10	787.84	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 59.20000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.73	780.62	782.40	784.26	785.64
4	778.00	778.00	778.96	779.85	780.79	781.88	783.87	785.47
5	778.00	778.00	778.94	779.84	780.75	781.77	783.70	785.39
6	778.00	778.00	778.91	779.78	780.58	782.05	783.74	785.39

7	778.00	778.00	778.88	779.71	780.47	782.10	783.78	785.42
8	778.00	778.00	778.87	779.68	780.47	782.07	783.80	785.49
9	778.00	778.00	778.81	779.65	780.67	781.87	783.82	785.62
10	778.00	778.00	778.59	779.35	780.52	782.41	783.93	785.91
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

9 10

1	787.00	787.00
2	787.00	787.00
3	787.00	787.50
4	787.13	788.00
5	787.27	788.50
6	787.30	788.50
7	787.25	788.00
8	787.31	788.00
9	787.51	788.00
10	787.85	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 72.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.63	782.41	784.27	785.65
4	778.00	778.00	778.96	779.86	780.81	781.90	783.90	785.49
5	778.00	778.00	778.96	779.86	780.78	781.81	783.75	785.43
6	778.00	778.00	778.93	779.81	780.61	782.11	783.80	785.44
7	778.00	778.00	778.90	779.74	780.52	782.17	783.86	785.48
8	778.00	778.00	778.88	779.71	780.51	782.13	783.86	785.54
9	778.00	778.00	778.82	779.67	780.70	781.91	783.87	785.66
10	778.00	778.00	778.59	779.36	780.54	782.43	783.96	785.93
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

9 10

1	787.00	787.00
2	787.00	787.00
3	787.01	787.50
4	787.13	788.00
5	787.28	788.50
6	787.31	788.50
7	787.27	788.00

8	787.33	788.00
9	787.53	788.00
10	787.86	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 87.40000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.64	782.41	784.28	785.66
4	778.00	778.00	778.97	779.87	780.82	781.91	783.91	785.50
5	778.00	778.00	778.96	779.87	780.79	781.82	783.77	785.44
6	778.00	778.00	778.94	779.82	780.63	782.13	783.83	785.46
7	778.00	778.00	778.90	779.75	780.54	782.20	783.89	785.50
8	778.00	778.00	778.89	779.73	780.53	782.16	783.89	785.56
9	778.00	778.00	778.83	779.68	780.72	781.93	783.89	785.68
10	778.00	778.00	778.60	779.37	780.55	782.44	783.97	785.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

9 10

1	787.00	787.00
2	787.00	787.00
3	787.01	787.50
4	787.14	788.00
5	787.29	788.50
6	787.32	788.50
7	787.28	788.00
8	787.34	788.00
9	787.53	788.00
10	787.87	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 105.90000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN
-----	--------

	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.64	782.42	784.28	785.66
4	778.00	778.00	778.97	779.87	780.82	781.92	783.91	785.50
5	778.00	778.00	778.96	779.88	780.80	781.83	783.78	785.45
6	778.00	778.00	778.94	779.82	780.64	782.14	783.84	785.47
7	778.00	778.00	778.91	779.76	780.54	782.21	783.90	785.51
8	778.00	778.00	778.89	779.73	780.54	782.17	783.90	785.57
9	778.00	778.00	778.83	779.69	780.72	781.94	783.90	785.69
10	778.00	778.00	778.60	779.37	780.55	782.44	783.97	785.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00

	9	10
1	787.00	787.00
2	787.00	787.00
3	787.01	787.50
4	787.14	788.00
5	787.29	788.50
6	787.32	788.50
7	787.28	788.00
8	787.34	788.00
9	787.53	788.00
10	787.87	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 128.10001

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.64	782.42	784.28	785.66
4	778.00	778.00	778.97	779.87	780.82	781.92	783.91	785.50
5	778.00	778.00	778.96	779.88	780.80	781.83	783.78	785.45
6	778.00	778.00	778.94	779.83	780.64	782.14	783.84	785.47
7	778.00	778.00	778.91	779.76	780.55	782.21	783.90	785.52
8	778.00	778.00	778.89	779.73	780.54	782.17	783.91	785.57
9	778.00	778.00	778.83	779.69	780.72	781.94	783.91	785.69
10	778.00	778.00	778.60	779.37	780.55	782.44	783.97	785.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						

1	787.00	787.00
2	787.00	787.00
3	787.01	787.50
4	787.14	788.00
5	787.29	788.50
6	787.33	788.50
7	787.29	788.00
8	787.34	788.00
9	787.54	788.00
10	787.87	789.00
11	788.00	789.00

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 154.70000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.64	782.42	784.28	785.66
4	778.00	778.00	778.97	779.87	780.82	781.92	783.91	785.50
5	778.00	778.00	778.96	779.88	780.80	781.83	783.78	785.45
6	778.00	778.00	778.94	779.83	780.64	782.14	783.84	785.47
7	778.00	778.00	778.91	779.76	780.55	782.21	783.90	785.52
8	778.00	778.00	778.89	779.73	780.54	782.17	783.91	785.57
9	778.00	778.00	778.83	779.69	780.72	781.94	783.91	785.69
10	778.00	778.00	778.60	779.37	780.55	782.44	783.97	785.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	787.01	787.50						
4	787.14	788.00						
5	787.29	788.50						
6	787.33	788.50						
7	787.29	788.00						
8	787.34	788.00						
9	787.54	788.00						
10	787.87	789.00						
11	788.00	789.00						

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	779.01	779.74	780.64	782.42	784.28	785.66
4	778.00	778.00	778.97	779.87	780.82	781.92	783.91	785.50
5	778.00	778.00	778.96	779.88	780.80	781.83	783.78	785.45
6	778.00	778.00	778.94	779.83	780.64	782.14	783.84	785.47
7	778.00	778.00	778.91	779.76	780.55	782.21	783.90	785.52
8	778.00	778.00	778.89	779.73	780.54	782.17	783.91	785.57
9	778.00	778.00	778.83	779.69	780.72	781.94	783.91	785.69
10	778.00	778.00	778.60	779.37	780.55	782.44	783.97	785.94
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	787.01	787.50						
4	787.14	788.00						
5	787.29	788.50						
6	787.33	788.50						
7	787.29	788.00						
8	787.34	788.00						
9	787.54	788.00						
10	787.87	789.00						
11	788.00	789.00						

OUTPUT FILE FOR THE SINGLE WELL EXTRACTION SYSTEM FOR SITE MODEL

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.33	779.03	780.07	782.05	784.03	785.51
4	778.00	778.00	776.91	778.19	779.62	781.00	783.39	785.22
5	778.00	778.00	772.80	777.02	779.06	780.57	783.08	785.08
6	778.00	778.00	776.59	777.78	778.97	781.02	783.15	785.09
7	778.00	778.00	777.87	778.51	779.39	781.36	783.34	785.19
8	778.00	778.00	778.38	779.03	779.85	781.61	783.50	785.33
9	778.00	778.00	778.58	779.32	780.40	781.62	783.66	785.53
10	778.00	778.00	778.50	779.21	780.41	782.33	783.86	785.87
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	786.97	787.50						
4	787.06	788.00						
5	787.19	788.50						
6	787.22	788.50						
7	787.19	788.00						
8	787.26	788.00						
9	787.48	788.00						
10	787.84	789.00						
11	788.00	789.00						

OUTPUT FILE FOR THE THREE WELL EXTRACTION SYSTEM FOR SITE MODEL

COMPUTATION NODAL RESULTS:

TIME(DAYS)= 186.00000

HEAD OR DRAWDOWN (FT) IN UNIT OR LAYER 1:

ROW	COLUMN							
	1	2	3	4	5	6	7	8
1	778.00	779.00	779.25	779.40	779.50	783.50	785.00	786.00
2	778.00	778.50	779.25	779.40	779.50	783.50	785.00	786.00
3	778.00	778.00	778.52	778.92	779.84	781.86	783.85	785.39
4	778.00	778.00	777.82	777.80	778.96	780.40	782.97	784.97
5	778.00	778.00	776.89	775.30	777.60	779.42	782.38	784.69
6	778.00	778.00	776.40	774.15	776.59	779.54	782.26	784.60
7	778.00	778.00	776.55	774.32	776.53	779.77	782.42	784.69
8	778.00	778.00	777.40	777.07	778.09	780.41	782.75	784.90
9	778.00	778.00	778.02	778.39	779.61	780.91	783.16	785.24
10	778.00	778.00	778.27	778.83	780.05	782.07	783.63	785.73
11	778.00	778.00	778.00	778.50	779.50	783.00	785.50	787.00
	9	10						
1	787.00	787.00						
2	787.00	787.00						
3	786.93	787.50						
4	786.99	788.00						
5	787.08	788.50						
6	787.08	788.50						
7	787.04	788.00						
8	787.14	788.00						
9	787.39	788.00						
10	787.80	789.00						
11	788.00	789.00						

DISTRIBUTIONNo. of
CopiesOFFSITE

2 DOE/Office of Scientific
and Technical Information

6 R. Lester
Office of Environmental
Management
Restoration Branch
2750 ABW/EMR
WPAFB, OH 45433-5000

Air Force Logistics Command
Headquarters
Area A, Building 262
HQ AFLC/DEV
WPAFB, OH 45433

T. Ballard
United States Environmental
Protection Agency
Region V (5HS-11)
230 S. Dearborn St.
Chicago, IL 60604

2 B. Buthker
Ohio Environmental
Protection Agency
Southwest District Office
40 S. Main St.
Dayton, OH 45402-2086

K. Davidson
Ohio Environmental
Protection Agency
1800 WaterMark Dr.
Columbus, OH 43266

K. Dovantzis
PRC Environmental
Management Inc.
233 N. Michigan Ave.
Suite 1620
Chicago, IL 60601

No. of
CopiesOFFSITE (continued)

2 R. Eastmond
International Technology
Corporation
Richland Regional Office
1045 Jadwin Ave., Suite C
Richland, WA 99352

4 J. Register
International Technology
Corporation
Cincinnati Regional Office
11499 Chester Rd.
Cincinnati, OH 45246

ONSITEDOE Richland Operations Office

J. Shadel
Federal Building
Room 514, Area 700
825 Jadwin Ave.
Richland, WA 99352

3 Environmental Management
Operations (EMO)

T. Page
D. Reed
Records Management
723 The Parkway
Richland, WA 99352

6 Pacific Northwest Laboratory

Publishing Coordinator
Technical Report Files (5)

END

DATE
FILMED

11 / 23 / 92