

ORNL/SUB-7257/7  
JULY, 1978

**MASTER**

FEASIBILITY STUDY

COMPARISON OF COAL- AND NUCLEAR-FUELED  
ALTERNATIVES FOR PROCESS STEAM  
AND BY PRODUCT ELECTRICAL POWER GENERATION

FOR THE

E.I. DU PONT DE NEMOURS & COMPANY, INCORPORATED  
PLANT SITE  
VICTORIA, TEXAS

950 8283

**DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED**



**Power Systems Engineering, Inc.**

8705-07 Katy Freeway • P. O. Box 19398 • Houston, Texas 77024 • (713) 464-9451

## DISCLAIMER

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

FEASIBILITY STUDY

COMPARISON OF COAL- AND NUCLEAR-FUELED  
ALTERNATIVES FOR PROCESS STEAM  
AND BY PRODUCT ELECTRICAL POWER GENERATION

FOR THE

E.I. DU PONT DE NEMOURS & COMPANY, INCORPORATED  
PLANT SITE  
VICTORIA, TEXAS

Report prepared by  
POWER SYSTEMS ENGINEERING, INCORPORATED  
P. O. Box 19398  
Houston, Texas 77024

July, 1978

for  
OAK RIDGE NATIONAL LABORATORY  
Oak Ridge, Tennessee 37830  
operated by  
UNION CARBIDE CORPORATION  
for the  
DEPARTMENT OF ENERGY  
Contract No. W-7405-eng-26

**NOTICE**  
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

NOTICE

✓  
MN ONLY

**PORTIONS OF THIS REPORT ARE ILLEGIBLE. It**  
**has been reproduced from the best available**  
**copy to permit the broadest possible avail-**  
**ability.**



**Power Systems Engineering, Inc.**

8705-07 Katy Freeway • P. O. Box 19398 • Houston, Texas 77024 • (713) 464-9451

**DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED**

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the U.S. Department of Energy, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America  
Available from  
National Technical Information Service  
Springfield, Virginia 22151

Price: Printed Copy \$7.25; Microfiche \$3.00

This feasibility study has been funded by the Department of Energy (DOE) and is the product of the joint efforts of the following participants:

Power Systems Engineering, Incorporated  
The Babcock and Wilcox Company, Nuclear Power Generation  
Division  
United Engineers and Constructors, Incorporated  
Oak Ridge National Laboratory  
E. I. Du Pont De Nemours and Company, Incorporated

PSE acknowledges the participation of the above organizations and appreciates their assistance in the preparation and review of this report.



## TABLE OF CONTENTS

	PAGE No.
1.0 EXECUTIVE SUMMARY . . . . .	1-1
1.1 Project Background and Description . . . . .	1-1
1.2 Major Considerations and Conclusions . . . . .	1-2
1.2.1 Site Feasibility . . . . .	1-2
1.2.2 Economic Feasibility . . . . .	1-3
1.3 Study Scope . . . . .	1-5
1.4 System Designs . . . . .	1-6
1.4.1 Nuclear Systems . . . . .	1-6
1.4.2 Coal Systems . . . . .	1-8
1.5 Summary of Recommendations . . . . .	1-8
Figures 1-1 to 1-10 . . . . .	1-10 to 1-20
Tables 1-1 to 1-3 . . . . .	1-21 to 1-22
 2.0 INTRODUCTION. . . . .	 2-1
 3.0 SYSTEMS DESCRIPTIONS . . . . .	 3-1
3.1 Design Requirements . . . . .	3-1
3.1.1 Description of Existing Plant . . . . .	3-1
3.1.1.1 General . . . . .	3-1
3.1.1.2 Historical and Structural Geology . . . . .	3-1
3.1.1.3 Site Geology . . . . .	3-2
3.1.2 Steam and Power Requirements . . . . .	3-3
3.1.3 Study Premises . . . . .	3-3
3.2 Study Systems . . . . .	3-4
3.2.1 PE-CNSG. . . . .	3-4
3.2.1.1 Plant Layout . . . . .	3-4
3.2.1.2 Nuclear Steam Generating System . . . . .	3-6
3.2.1.2.1 Reactor Coolant System . . . . .	3-6
3.2.1.2.2 Auxiliary Systems . . . . .	3-7
3.2.1.2.3 Reactor Plant Instrumentation & Control System . . . . .	3-8
3.2.1.2.4 Containment . . . . .	3-8
3.2.1.3 Refueling, Maintenance, and Inspection . . . . .	3-9
3.2.1.4 Secondary/Tertiary Systems . . . . .	3-10
3.2.1.4.1 Introduction. . . . .	3-10
3.2.1.4.2 Study Cases . . . . .	3-10
3.2.1.4.3 Secondary System Description . . . . .	3-11
3.2.1.4.4 Tertiary Systems . . . . .	3-12
3.2.1.4.5 System Control . . . . .	3-12
3.2.1.4.6 Condensing Cycle Turbine-Generator System. . . . .	3-14
3.2.1.5 Construction Techniques . . . . .	3-14
3.2.2 Coal Fueled Steam/Power Plant . . . . .	3-15
3.2.2.1 Plant Layout . . . . .	3-15
3.2.2.2 Study Cases . . . . .	3-16
3.2.2.3 Design Criteria . . . . .	3-16
3.2.2.3.1 Coal Yard . . . . .	3-16
3.2.2.3.2 Boilers . . . . .	3-17
3.2.2.3.3 Electrostatic Precipitator . . . . .	3-17



TABLE OF CONTENTS (Continued)

3.2.2.3.4	Flue Gas Desulfurization (FGD) System . . . . .	3-17
3.2.2.3.5	Bottom Ash Disposal System . . . . .	3-18
3.2.2.3.6	Steam Turbine Generator . . . . .	3-18
3.2.2.4	Construction Schedule . . . . .	3-18
	Figures 3-1 to 3-24 . . . . .	3-19 to 3-42
	Table 3-1 . . . . .	3-43
4.0	ECONOMICS . . . . .	4-1
4.1	Economic Philosophy and Methods . . . . .	4-1
4.1.1	Escalation Schedules . . . . .	4-2
4.1.1.1	General Inflation Escalation Rate . . . . .	4-2
4.1.1.2	Construction Labor Escalation Rate . . . . .	4-2
4.1.1.3	Construction Material Escalation Rate . . . . .	4-2
4.1.1.4	Construction Composite Escalation Rate . . . . .	4-2
4.1.1.5	Operating Labor Escalation Rate . . . . .	4-2
4.1.1.6	Operation Composite Escalation Rate . . . . .	4-2
4.1.1.7	Fuel (Primary) Escalation Rate . . . . .	4-3
4.1.1.8	Number 6 Fuel Oil Escalation Rate . . . . .	4-3
4.1.2	Federal Income Tax Rate . . . . .	4-3
4.1.3	Investment Tax Credit . . . . .	4-3
4.1.4	State Tax (Ad Valorem) Rate . . . . .	4-3
4.1.5	State Sales Tax Rate . . . . .	4-3
4.1.6	Insurance Rate . . . . .	4-4
4.1.7	Construction Labor . . . . .	4-4
4.1.8	Operations Labor . . . . .	4-4
4.1.9	Plant Availability . . . . .	4-4
4.1.10	Plant Factor . . . . .	4-4
4.1.11	Backup Operation . . . . .	4-4
4.1.12	Electrical Power Expense or Credit . . . . .	4-5
4.1.13	Working Capital . . . . .	4-5
4.1.14	Introductory Expense . . . . .	4-5
4.1.15	Depreciation . . . . .	4-6
4.1.16	Cash Flow Pro Forma Statement . . . . .	4-6
4.1.16.1	Column (1) Capital Expense . . . . .	4-6
4.1.16.2	Column (2) Backup Operating Expense . . . . .	4-6
4.1.16.3	Column (3) Net Change in Working Capital . . . . .	4-6
4.1.16.4	Column (4) Investment Cash Flow . . . . .	4-6
4.1.16.5	Column (5) Fuel Expense . . . . .	4-6
4.1.16.6	Column (6) Operating Expense . . . . .	4-7
4.1.16.7	Column (7) Total Annual Expense . . . . .	4-7
4.1.16.8	Column (8) Depreciation . . . . .	4-7
4.1.16.9	Column (9) Introductory Expense . . . . .	4-7
4.1.16.10	Column (10) Adjusted Operating Expense . . . . .	4-7
4.1.16.11	Column (11) Federal Income Tax . . . . .	4-7
4.1.16.12	Column (12) Net Operating Expense . . . . .	4-7
4.1.16.13	Column (13) Investment Tax Credit . . . . .	4-8
4.1.16.14	Column (14) Total Cash Flow . . . . .	4-8
4.1.16.15	Column (15) Net Nash Flow . . . . .	4-8





TABLE OF CONTENTS (Continued)

4.1.16.16	Column (16) Discounted Cash Flow . . . . .	4-8
4.1.16.17	Column (17) Net Present Value . . . . .	4-8
4.1.17	Steam Cost . . . . .	4-8
4.2	Capital Estimates . . . . .	4-10
4.2.1	Nuclear Plants . . . . .	4-10
4.2.2	Coal Plants . . . . .	4-13
4.3	Fuel Economics . . . . .	4-14
4.3.1	Nuclear Fuel . . . . .	4-14
4.3.2	Coal . . . . .	4-15
4.3.3	Number 6 Fuel Oil . . . . .	4-16
4.4	Operating Economics . . . . .	4-16
4.4.1	Operating Load and Backup Expense . . . . .	4-16
4.4.2	Plant Availability . . . . .	4-17
4.4.2.1	Nuclear Plants . . . . .	4-17
4.4.2.2	Coal Plants . . . . .	4-18
4.4.3	Annual Operating Expense . . . . .	4-19
4.4.3.1	Nuclear Plants . . . . .	4-19
4.4.3.2	Coal Plants . . . . .	4-19
4.5	Comparative Economics . . . . .	4-19
4.5.1	Nuclear Plants . . . . .	4-20
4.5.1.1	Plants Satisfying Process Steam Temperature Requirements . . . . .	4-20
4.5.1.2	Benchmark Plants . . . . .	4-20
4.5.2	Coal Plants . . . . .	4-21
4.5.3	Economic Comparison of Optimum Coal and Nuclear Plants. . . . .	4-22
4.6	NPV Sensitivity to Variations in Economic Parameters . . . . .	4-22
4.6.1	NPV Sensitivity to Variation in Capital Investment . . . . .	4-23
4.6.2	NPV Sensitivity to Primary Fuel Cost . . . . .	4-23
4.6.3	NPV Sensitivity to Variations in Primary Fuel Cost Escalation Rate . . . . .	4-23
4.6.4	NPV Sensitivity to Variations in Number 6 Fuel Oil Costs . . . . .	4-23
4.6.5	NPV Sensitivity to Variations in Number 6 Fuel Oil Costs Escalation Rate . . . . .	4-23
4.6.6	NPV Sensitivity to Annual Operating Costs . . . . .	4-24
4.6.7	NPV Sensitivity to Power Credit . . . . .	4-24
4.6.8	NPV Sensitivity to Availability . . . . .	4-24
4.6.9	Use of Table 4-13 . . . . .	4-24
	Figures 4-1 to 4-27 . . . . .	4-25 to 4-54
	Table 4-1 to 4-13 . . . . .	4-55 to 4-73
5.0	CONCLUSIONS . . . . .	5-1
5.1	Site Feasibility . . . . .	5-1
5.2	Economic Feasibility . . . . .	5-2
5.3	Technical Feasibility . . . . .	5-3
6.0	RECOMMENDATIONS . . . . .	6-1

REFERENCES

## ABSTRACT

The purpose of the study was to evaluate the technical and economic feasibility of a small, (365 Mwt) nuclear reactor for supplying process steam and electricity as a replacement for energy sources using increasingly scarce natural gas or oil. The Du Pont Chemical Plant Site at Victoria, Texas, was chosen as representative of industrial installations that require sizeable amounts of process steam and electricity. For comparison purposes conventional coal-fired boilers were also evaluated.

It was determined that both nuclear- and coal-based process energy supply systems are technically feasible. For the specific steam/electricity demands at the reference site, the coal-fired plant proved to be economically more attractive than the nuclear units. For an application requiring a base-loaded supply of saturated steam, utilizing full reactor capacity, the nuclear option appears competitive for coal costing \$37/ton in 1978 dollars.



## 1.0 EXECUTIVE SUMMARY

### 1.1 Project Background and Description

The work discussed in this report has been sponsored by the Department of Energy (DOE). Participants in the cooperative study included Oak Ridge National Laboratory (ORNL); Power Systems Engineering, Inc. (PSE), Houston, Texas; The Babcock and Wilcox Company, Nuclear Power Generation Division (B&W), Lynchburg, Virginia; and United Engineers and Constructors, Inc. (UE&C), Philadelphia, Pennsylvania. PSE acted as the study coordinator under subcontract ORNL-Sub-7257 and was supported by ORNL, B&W, and UE&C.

The present study is an outgrowth of previous DOE - sponsored studies by ORNL, B&W, and UE&C, in which the generalized economic and commercial feasibility of utilizing small nuclear reactors to provide industrial process steam was investigated (References 1 and 2). The work being reported herein addresses the specific siting, technical, and economic feasibility of utilizing B&W's Process Energy Consolidated Nuclear Steam Generator (PE-CNSG) design as a process steam generator for an existing chemical facility. To provide a comparative basis for evaluating the economic feasibility of the PE-CNSG, the study included a comparable site, technical and economic evaluation of coal-fired process steam generation systems. Coal was chosen as the alternative fuel because it is the most abundant domestic fuel resource and because of the great emphasis being placed on its use.

The Du Pont plant site at Victoria, Texas, was chosen as one of three to be studied in the Gulf Area (References 3 and 4). This site was chosen as representative of large industrial process steam users and because it appeared to be suited for both the PE-CNSG and the coal applications. The study was designed to yield results applicable at numerous sites. In the course of the study, Du Pont provided such site, technical and economic inputs as were required in order to generate a complete and meaningful feasibility evaluation for the specific site under study. The DuPont participation was contributed by Du Pont. Without this support on the part of Du Pont, which amounted to approximately four man-months, this study would not have been possible.

This section is a summary of the work accomplished and summarizes information contained in more detail in later sections of the report.

The stated objective of the work performed was the evaluation of the site, technical and economic feasibility of utilizing a small nuclear reactor as a process steam generator at a specific industrial site. Generalized feasibility has previously been investigated for the hypothetical "Middletown, U.S.A." site for the B&W PE-CNSG nuclear system. (Reference 2). In order to demonstrate economic feasibility, the nuclear system must be compared to an alternative steam supply system, either an existing system at the site, or a new system. Since Du Pont currently uses natural gas or fuel oil at its Victoria site, and since neither of these fuels is as domestically abundant as coal, it was decided to evaluate a new coal-fired facility as the alternative to the



## 1.1 Project Background and Description - (Continued)

PE-CNSG. B&W, UE&C, and ORNL provided all site evaluations, technical information, and cost estimates for three candidate nuclear systems plus two benchmark systems. The benchmark systems were studied to aid in evaluating the economic impact of the addition of electrical generation and oil-fired superheating to the basic nuclear steam generator system. PSE's scope of work included estimating fuel-oil fired superheat systems for those nuclear plant system options requiring them, as well as the development of the coal plant configuration and cost estimates for comparison with the nuclear plants. The eight coal plant designs were developed, estimated and analyzed, including four high-sulfur Illinois coal-fired and four low-sulfur Wyoming coal-fired plants. PSE then performed the economic evaluations of the coal/nuclear alternatives using net present value (NPV) cash flow economic methods.

The base date for all economic comparisons is January 1, 1978. Cash flows reported in current dollars are escalated beyond January 1, 1978. Where discount rates have been applied, the "present" date is January 1, 1978. The study assumes all equity funding, i.e., no cost of capital or debt service has been considered.

## 1.2 Major Considerations and Conclusions

### 1.2.1 Site Feasibility

The preliminary site feasibility study has been based on existing geological, topographic, meteorological, population, and seismic information supplied by Du Pont for their Victoria, Texas Plant Site. The study failed to disclose any condition that would preclude the construction and operation of either the PE-CNSG or coal-fired process steam systems. There was no attempt made to generate new site information, and the conclusions infer no assurance that in-depth site studies will bear out these preliminary conclusions. The available data indicate that this site is probably quite well suited for nuclear as well as for fossil-fueled installations of the type studied. Final site suitability would be subject to detailed study.

Figure 1-1 shows the PE-CNSG plant layout which has been selected for the study. Figure 1-2 presents the coal plant layout. The study plants were located in areas designated by Du Pont as acceptable. They are not necessarily optimum locations, but are judged to be representative and feasible locations.



### 1.2.2 Economic Feasibility

A total of five PE-CNSG plant configurations and eight coal plant configurations were evaluated on the basis of economics tailored to the Victoria plant site. Each nuclear plant and each coal plant was compared on the basis of net present value (NPV) over a 30 year total project life in order to arrive at an optimum pair of plants from which to make the final economic choice. No attempt has been made to compare these study plants with existing facilities.

Because of the seven year construction period for the nuclear plants and the four year period for the coal plants, economic comparisons were made under two sets of assumptions regarding project start times. In both comparisons, the nuclear plants are assumed to begin construction on January 1, 1978. Coal plant economics were generated first under the assumption that the coal plants start construction concurrently with the nuclear plants. An additional set of coal plant economics was generated under the assumption that the coal plants were to start operation concurrently with the nuclear plants (i.e., start construction on January 1, 1981). The major economic impact that occurs as a result of the difference in nuclear and coal plant construction time requirements is the penalty incurred by the nuclear plants for the number 6 fuel oil equivalent of the steam required by the user during the last three years of nuclear plant construction for the cases where the coal plants go into operation three years prior to the nuclear plants. The removal of this three year fuel oil expense from the nuclear plant economics improves its net present value as shown when comparing Figures 1-3 and 1-5.

Capital cost estimates are of a quality consistent with the scope of this feasibility study; i.e., they are budgetary in nature. The estimates represent neither the maximum nor minimum costs, but rather represent average costs to be expected for the systems under study. Capital investment costs for each study plant are summarized in Tables 1-1 and 1-2. Refer to section 1.4.1 and 1.4.2 for plant descriptions.

The optimum nuclear plant configuration within the constraint of DuPont steam requirements, is one which delivers a maximum of 1,000,000 lb/hr process steam flow at 550 psig and 750°F, while generating an average of 26.1 MW net electrical power via a condensing-cycle turbine-generator in the PE-CNSG secondary steam loop. This is identified as Nuclear Case 5 in the body of the report. For this study, it is considered to be "Nth-of-a-Kind" and exclusive of "First-of-a-Kind" costs.

For both assumptions for construction start date, the optimum coal plant configuration is one which delivers a maximum of 1,000,000 lb/hr process steam at 550 psig and 750°F while generating an average 36.1 MW net electrical power via an extraction-condensing turbine generator. Boiler design steam conditions are 1500 psig at 950°F. This plant is Coal Case 7.

The results for these two plants are shown in Figures 1-3 through 1-6 for both the concurrent nuclear/coal plant construction start date and the concurrent nuclear/coal plant operation start date.



### 1.2.2 Economic Feasibility - (Continued)

The nuclear plant is presented for both reprocessing and non-reprocessing fuel cycles, while the coal plant is presented as a high-sulfur coal plant with flue gas scrubbing for 1978 delivered coal prices of \$1.20, \$1.40 and \$1.60/10<sup>6</sup>Btu.

Under the assumptions in force for this study, the coal plant is seen to be the economic choice for 1978 coal prices up to approximately \$2.10-\$2.20/10<sup>6</sup>Btu for concurrent nuclear/coal plant construction start date and up to \$2.40-\$2.50/10<sup>6</sup>Btu for concurrent nuclear/coal plant operation start date.

Since these 1978 coal prices are quite high and not to be realistically expected, the coal plant is the economic choice of this study. It is judged to be possible to obtain \$1.20/10<sup>6</sup>Btu high-sulfur coal and the \$1.40-\$1.60 high sulfur coal price is quite likely obtainable on long term contract.

The PE-CNSG plants are much more capital-intensive projects than the coal-fired plants. Even though the PE-CNSG annual operating costs are substantially lower than annual costs for coal plants, the large capital investment required for the PE-CNSG results in low NPV's that are not competitive with the coal-fired option studied.

For comparison purposes, Figures 1-4 and 1-6 also show the fuel cost of process steam derived from number 6 fuel oil. This comparison is idealized in that it assumes that all capital related costs have ceased and that operating and maintenance costs are zero. For the idealized conditions just cited, oil may be an attractive alternative to either coal or nuclear systems.

The relatively high energy costs predicted for nuclear (compared to earlier estimates) arise from several factors. The average industrial steam load of 723,000 lb/hr. amounts to only 56% of rated reactor capacity, and while the excess steaming capacity is used to generate electricity, power generation does not provide sufficient net revenue to yield attractive overall steam production costs. For a PE-CNSG producing steam only, a rise in industrial steam load from 56% to 100% of reactor capacity would lower steam cost by about 20%.

The requirement for superheated steam imposes an additional cost penalty on the PE-CNSG since a supplemental oil fired superheater is required to elevate the reactor steam to about 750°F. Thus, oil provides about one-fifth of the energy consumed to produce process steam during normal operations. Superheating increases steam costs by about 10%.

A PE-CNSG application for supplying base-load saturated steam to industry, either prime steam or via cogeneration, probably would be more attractive.



### 1.2.2 Economic Feasibility - (Continued)

Present results project saturated steam costs of about \$2/10<sup>6</sup>Btu in 1978 dollars for a 1,288,000 lb/hr constant steam demand and a 15% discount rate. Oil based superheat would increase the steam cost to about \$2.20/10<sup>6</sup>Btu; this is roughly equal to the cost of superheated process steam from a Case 7 coal based plant with a 0.85 plant availability factor and burning high sulfur coal costing \$1.70/10<sup>6</sup>Btu or \$37/ton.

### 1.2.3 Technical Feasibility

All PE-CNSG and coal-fired process steam generation systems studied are technically feasible. Both types of systems represent essentially state-of-the-art technology. An application of the PE-CNSG would be a First-of-a-Kind (FOAK) installation and as such the Nuclear Regulatory Commission (NRC) would have to be satisfied concerning the PE-CNSG safety features. There is no reason to anticipate that the PE-CNSG would prove technically unsatisfactory to the NRC in light of both its small size and its application of essentially state-of-the-art technology. Considerable preparation for soliciting NRC approval has already been factored into the PE-CNSG design.

The coal plant poses no apparent problems from a technical licensing standpoint. However there is a degree of uncertainty about future environmental requirements. Based on current environmental regulations, the coal plant design studied are acceptable in the Victoria, Texas area if the flue-gas is scrubbed.

### 1.3 Study Scope

This feasibility study has been designed specifically around the requirements of the Du Pont plant site at Victoria, Texas. The study includes site, technical, and economic comparisons between B&W's PE-CNSG and coal-fired facilities for the generation of up to 1,000,000 lb/hr. of process steam at 550 psig and 750<sup>o</sup>F. Several alternatives of each concept (nuclear/coal) have been investigated, some of which include cogeneration of electrical power. PE-CNSG and coal cycles have been individually developed to make best use of the potentials inherent in each, subject to the conditions required by the Du Pont plant site application. The most economically attractive nuclear and coal options are compared in detail.

In order to insure that this study is compatible with the specific plant site, Du Pont has supplied certain site, technical, and economic information. This information includes site layout and topography, suggested study sites, soil and subsoil data, and economic inputs including state and local tax rates, insurance rates, labor rates, and backup steam supply costs. Information not supplied by Du Pont has been estimated. All of the above parameters are documented in the body of the report.



### 1.3 Study Scope - (Continued)

Significant study premises are itemized below:

- (1) Du Pont supplies, at their existing header, deaerated and treated boiler feedwater (including makeup) in sufficient quantities for each study plant. The feedwater is supplied at 50 psig and 280°F.
- (2) Du Pont receives, at their existing header, 550 psig, 750°F steam from the study plants. Two of the five nuclear study plants supply saturated steam to the process. These plants were studied to gain insight into the effects of superheating with fuel oil and of operating the PE-CNSG at reduced load.
- (3) Study plants having different availabilities, capacities or operating life are equalized economically by charging the study plant with the number 6 fuel oil equivalent of any steam deficit with reference to the steam flow requirement. In so doing, each plant is compared on the basis of equal total Btu production over the life of the project.
- (4) Study plants having power generating capability are charged a utility backup fee for capability in excess of 15 MWe. Auxiliary power and/or net power generated by study plants is routed through Du Pont's existing substation, PPS-3.
- (5) Service water, potable water, and fire water are provided by Du Pont at existing headers.
- (6) Estimates include provisions for absorbing additional heat rejection loads resulting from the operation of the study plants.
- (7) The study plants include provisions for all other items necessary for engineering, construction and operation. The cost of Du Pont internal administration and management has not been estimated.

This feasibility study compares the PE-CNSG with coal-fired alternatives. No attempt has been made to compare these systems with those facilities currently being operated by Du Pont.

### 1.4 System Designs

#### 1.4.1 Nuclear Systems

The PE-CNSG is an integral pressurized water reactor (PWR) pressurized by an electrically heated, external pressurizer. The reactor pumps are of the wet-motor type with impeller located within the reactor vessel. The steam generator consists of 12 modular, once-through units





#### 1.4.1 Nuclear Systems - (Continued)

located above the top level of the core in the annulus between the core and pressure vessel. See Figure 1-7. Steam from the steam generators is delivered to reboilers where tertiary (process) steam is generated. This process steam is then delivered either directly to process or to a fired superheater as required. Electrical power can be generated in the secondary steam loop if total secondary steam is not required for process steam generation.

See Figure 1-8 for the PE-CNSG containment arrangement and Table 1-3 for reactor coolant system design parameters. Reference 1 gives a complete description of the basic PE-CNSG system, and Section 3. of this report summarizes the design features particular to this study.

Five configurations of this standard PE-CNSG were designed and studied. Reboiler, superheater, fuel cycle and electrical generation designs have been varied. See Figure 1-9 for the simplified diagram of the cases. The following design points were considered:

- Case 1 - 810,000 lb/hr maximum (649,000 lb/hr average) process steam at 550 psig, 750°F. Du Pont to supply steam in excess of 810,000 lb/hr. No electrical generation. Plant Factor, 0.41 - Fig. 3-6
- Case 2 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam at 550 psig, 750°F. No electrical generation. Plant Factor, 0.45 - Fig. 3-7
- Case 3 - 810,000 lb/hr maximum (649,000 lb/hr average) process steam at 550 psig, saturated. No electrical generation. Plant Factor, 0.41 - Fig. 3-8
- Case 4 - 1,288,000 lb/hr process steam flow (maximum that the CNSG with reboilers will deliver) at 550 psig, saturated. No electrical generation. Plant Factor, 0.80 - Fig. 3-9.
- Case 5 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam flow at 550 psig, 750°F with provisions for generating condensing cycle electrical power with reactor secondary steam when system is delivering less than design steam flow to process. Plant Factor, 0.80 - Fig. 3-10.

Plant Factor is defined as annual energy output divided by maximum possible annual energy output assuming continuous, full load reactor operation.



#### 1.4.2 Coal Systems

Four coal-fueled boiler cycles were studied and each cycle was developed to fire either high-sulfur Illinois coal (10,900 Btu/lb) with flue gas scrubbing or low-sulfur Wyoming coal (8,250 Btu/lb) without flue gas scrubbing, for a total of eight coal plant designs. See Figure 1-10 for a typical schematic arrangement of a high-sulfur coal-fired steam generator system. Each of the coal plant designs satisfies the 1,000,000 lb/hr peak process steam flow requirement. Electrical cogeneration was investigated to more fully utilize the potential of the coal plant concept. The following cases were considered:

Case 1 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam flow at 550 psig, 750°F. No electrical generation. Boiler designed at 580 psig, 750°F. Illinois Coal. Plant Factor, 0.67

Case 2 - Same as 1 except Wyoming Coal.

Case 3 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam flow at 550 psig, 750°F with steam flow not required for process directed through a condensing cycle turbine-generator. Boiler designed at 580 psig, 750°F. Illinois coal. Plant Factor, 0.92.

Case 4 - Same as 3 except Wyoming Coal.

Case 5 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam flow generated at 1,500 psig, 950°F, and delivered to process at 550 psig, 750°F through a back pressure turbine-generator. Illinois Coal. Plant Factor, 0.67.

Case 6 - Same as 5 except Wyoming Coal.

Case 7 - 1,000,000 lb/hr maximum (723,000 lb/hr average) process steam flow generated at 1,500 psig, 950°F and delivered to process through an extraction-condensing turbine-generator at 550 psig, 750°F. Illinois Coal. Plant Factor, 0.92.

Case 8 - Same as 7 except Wyoming Coal.

Plant Factor is defined in Section 1.4.1.

#### 1.5 Summary of Recommendations

The economic analyses have shown that on an all-equity, NPV basis, the nuclear plants are not competitive economically with coal fired plants for this specific application under the present ground rules. A number of constraints particular to this application have been identified which seems to place an economic penalty on the nuclear option. The following recommendations, if pursued, might determine if removal of the constraints would bring about a significant improvement in the relative ranking of small industrial reactors.



1.5 Summary of Recommendations - (Continued)

- (1) Consider debt financing in cash flow analyses. This is necessary due to the wide differences in capital investment required between the nuclear and coal plants.
- (2) Study the economics of converting existing plants to accept saturated steam. This improves the economics of the CNSG plant considerably, especially as the steam demand increases towards the CNSG generating capacity.
- (3) If use of saturated steam is not feasible, consider alternative fuels for superheating, including waste or by-product fuels. Since Du Pont is currently firing their waste fuels to produce steam, this recommendation does not apply to them. It is stated here as a recommendation for similar applications where waste or by-product fuel sources exist but are not being used to generate steam.






FIGURE 1-1 PE-CNSG SITE PLAN 4

<small>This drawing is the property of Power Systems Engineering, Inc. No other use, copying, or reproduction of it, nor information derived therefrom, shall be given to others without the expressed written consent of Power Systems Engineering, Inc. The use of it in the field of a project to which it is related is subject to the approval of Power Systems Engineering, Inc.</small>	<b>REFERENCE DRAWINGS:</b> DUPONT SITE DEVELOPMENT MAP NO. 9000 UG & C Dwg G7009.011-PH-1	<table border="1"> <thead> <tr> <th>REV.</th> <th>REVISION</th> <th>BY</th> <th>DATE</th> <th>ISSUED FOR</th> <th>DATE</th> <th>REV.</th> <th>SCALE</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>ISSUED FOR DESIGN</td> <td>...</td> <td>5/21/78</td> <td>...</td> <td>...</td> <td>...</td> <td>1" = 400'</td> </tr> <tr> <td>2</td> <td>ISSUED FOR PRELIMINARY</td> <td>...</td> <td>10/27/78</td> <td>...</td> <td>...</td> <td>...</td> <td>1" = 400'</td> </tr> </tbody> </table>	REV.	REVISION	BY	DATE	ISSUED FOR	DATE	REV.	SCALE	1	ISSUED FOR DESIGN	...	5/21/78	...	...	...	1" = 400'	2	ISSUED FOR PRELIMINARY	...	10/27/78	...	...	...	1" = 400'	<table border="1"> <thead> <tr> <th>DATE</th> <th>BY</th> <th>SCALE</th> </tr> </thead> <tbody> <tr> <td>8-9-77</td> <td>...</td> <td>1" = 400'</td> </tr> <tr> <td>...</td> <td>...</td> <td>...</td> </tr> </tbody> </table>	DATE	BY	SCALE	8-9-77	...	1" = 400'	...	...	...	<p style="text-align: right;"><b>Power Systems Engineering, Inc.</b> HOUSTON, TEXAS</p> <p><b>SITE PLAN--</b>  <b>CONSOLIDATED NUCLEAR STEAM GENERATOR (CNSG)</b>  <b>FEASIBILITY STUDY</b></p> <p>PROJECT NO. 4027</p>	<p>Draw. No. 4027-M-410.1</p> <p>REVISIONS:</p> <p>Sheet 1 of 1</p>
	REV.	REVISION	BY	DATE	ISSUED FOR	DATE	REV.	SCALE																														
1	ISSUED FOR DESIGN	...	5/21/78	...	...	...	1" = 400'																															
2	ISSUED FOR PRELIMINARY	...	10/27/78	...	...	...	1" = 400'																															
DATE	BY	SCALE																																				
8-9-77	...	1" = 400'																																				
...	...	...																																				




FIGURE 1-2 COAL PLANT  
SITE PLAN

This drawing is the property of Power Systems Engineering, Inc. Further use, copying, or reproduction without written consent of Power Systems Engineering, Inc. is prohibited.	<b>REFERENCE DRAWINGS:</b> DUPONT SITE DEVELOPMENT MAP NO. 9000 P&E DWG NO. 4027-M-400-2		<b>REVISION</b>		<b>SCALE</b> 1" = 400'		<b>Power Systems Engineering, Inc.</b> HOUSTON, TEXAS			
	NO.	DATE	ISSUED FOR	DATE	BY	DATE	DATE	DATE		
1	12/21/76	ISSUED FOR REPORT				12-2-77	12-2-77	12-2-77		
2	10/1/77	ISSUED FOR PRELIMINARY								
						DATE 5/1/78 BY [Signature]		DATE 5/1/78 BY [Signature]		
							<b>SITE PLAN</b> <b>COAL-FIRED UTILITY BOILER SYSTEM</b> <b>FEASIBILITY STUDY</b>		DWG. NO. <b>4027-M-400.1</b> REVISION: 1 OF 2	
							ELEMENT: DUPONT - VEG-TERRAIN, SURVEY		PROJECT NO: 4027	

	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	See Curves
DESIGN STEAMFLOW-LB/HR	1,000,000	1,000,000
PROCESS STEAMFLOW-LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6\text{Btu}$	See Curves	N/A




FIGURE 1-3 COMPARISON OF OPTIMUM COAL AND NUCLEAR PLANTS



CASE	COAL	NUCLEAR
FUEL CYCLE	N/A	See Curves
DESIGN STEAMFLOW-LB/HR	1,000,000	1,000,000
PROCESS STEAMFLOW-LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6\text{Btu}$	See Curves	N/A

NOTE: Nuclear/Coal Plants  
Start Construction  
January 1, 1978





FIGURE 1-4: COMPARISON OF STEAM COSTS OF OPTIMUM COAL AND NUCLEAR PLANTS.



	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	See Curves
DESIGN STEAMFLOW-LB/HR	1,000,000	1,000,000
PROCESS STEAMFLOW-LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - \$10 <sup>6</sup> Btu	See Curves	N/A



DISCOUNT RATE - %  
 FIGURE 1-5 COMPARISON OF OPTIMUM COAL AND NUCLEAR PLANTS



	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	See Curves
DESIGN STEAMFLOW-LB/HR	1,000,000	1,000,000
PROCESS STEAMFLOW-LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6\text{Btu}$	See Curves	N/A

NOTE: Coal Plant Construction Starts January 1, 1981




FIGURE 1-6 - COMPARISON OF STEAM COSTS OF OPTIMUM COAL AND NUCLEAR PLANTS.

Figure 1-7 PE-CNSG Reactor Vessel




FIGURE 1-8

365 MWt PE-CNSG CONTAINMENT ARRANGEMENT









FIGURE 1-9  
 DUPONT STUDY CASES



FLUE GAS TREATMENT SYSTEM  
HIGH SULPHUR COAL

DWG. NO. FIG. 1-10

REV.



Power Systems  
Engineering, Inc.

P.O. Box 19398  
Houston, Texas 77024

BY DENNIS JOB NO. 4027 DATE 10/6/77 Sh of

0.1 LBS PARTICULATE/10<sup>6</sup> BTU FUEL  
1.2 LBS SO<sub>2</sub>/10<sup>6</sup> BTU FUEL

400' STACK




TABLE 1-1  
**PE-CNSG CAPITAL COST ESTIMATES**  
 (\$1,000's - BASE JANUARY 1, 1978)

		CASE				
		1	2	3	4	5
PROCESS STEAM DESIGN CONDITION:	FLOW - LB/HR	810,000	1,000,000	810,000	1,288,000	1,000,000
	PRESSURE - PSIG	550	550	550	550	550
	TEMPERATURE - °F	750	750	474*	474*	750
DESIGN POWER GENERATION	MW (GROSS)	0	0	0	0	34

		ESTIMATES														
		1			2			3			4			5		
	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	
LAND	96	---	96	96	----	96	96	----	96	96	----	96	96	----	96	
STRUCTURES AND IMPROVEMENTS	23,921	684	24,605	23,972	-684	24,656	23,921	634	24,555	24,022	634	24,636	24,264	863	25,127	
REACTOR PLANT	58,682	---	58,682	58,682	---	58,682	58,682	---	58,682	58,682	---	58,682	58,682	---	58,682	
TURBINE PLANT	---	---	---	---	---	---	---	---	---	---	---	---	6,346	---	6,346	
SECONDARY/TERTIARY/SUPERHEATER SYSTEMS	3,027	4,778	7,805	3,641	5,101	8,742	3,027	3,091	6,118	4,244	3,091	7,335	3,975	5,101	9,076	
ELECTRICAL PLANT	7,466	---	7,466	7,466	---	7,466	7,466	---	7,466	7,466	---	7,466	8,881	1,093	9,974	
MISCELLANEOUS PLANT EQUIPMENT	2,978	---	2,978	2,978	---	2,978	2,978	---	2,978	2,978	---	2,978	3,122	---	3,122	
OTHER COSTS	2,200	---	2,200	2,200	---	2,200	2,200	---	2,200	2,200	---	2,200	2,500	---	2,500	
UNDISTRIBUTED COSTS	16,090	1,111	17,201	16,090	1,176	17,266	16,090	764	16,854	16,090	764	16,854	17,250	1,430	18,680	
SUBTOTAL	114,460	6,573	121,033	115,125	6,961	122,086	114,460	4,489	118,949	115,758	4,489	120,247	125,116	8,487	133,603	
CONTINGENCY	6,327	667	6,994	6,414	705	7,119	6,327	458	6,785	6,484	458	6,942	7,426	858	8,284	
TOTAL ESTIMATE			128,027			129,205			125,734			127,189			141,887	

\* SATURATED STEAM

1-20



TABLE 1-2

## COAL PLANT CAPITAL COST ESTIMATES

(\$1,000's - BASE JANUARY 1, 1978)

		C A S E							
		1	2	3	4	5	6	7	8
PROCESS STEAM FLOW	- LB/HR	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000
DESIGN CONDITIONS PRESSURE	- PSIG	550	550	550	550	550	550	550	550
	TEMPERATURE - °F	750	750	750	750	750	750	750	750
DESIGN POWER GENERATION	MW (GROSS)	0	0	30.4	30.4	25	25	51.5	51.5
TYPE OF COAL		HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR

		E S T I M A T E S							
LAND		\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400
SITWORK		1,125	1,125	1,125	1,125	1,125	1,125	1,125	1,125
BUILDINGS AND STRUCTURES		183	183	183	183	183	183	183	183
COAL YARD		8,747	8,747	8,747	8,747	8,747	8,747	8,747	8,747
STEAM GENERATOR		15,650	15,560	15,650	15,560	17,500	16,450	17,500	16,450
TURBINE-GENERATOR		----	----	4,410	4,410	3,431	3,359	6,310	6,310
PROCESS MECHANICAL EQUIPMENT		4,584	5,057	5,534	6,000	4,731	5,231	5,664	6,074
ELECTRICAL		3,088	3,115	4,460	4,457	4,236	4,233	4,866	4,863
CIVIL-STRUCTURAL		732	580	921	777	863	689	961	816
PROCESS PIPING AND INSTRUMENTATION		3,998	3,998	4,387	4,387	4,549	4,549	4,834	4,834
FLUE GAS DESULFURIZATION FACILITIES		7,655	----	7,655	----	8,220	----	8,225	----
UNDISTRIBUTED COSTS		<u>6,120</u>	<u>3,853</u>	<u>7,365</u>	<u>6,455</u>	<u>7,418</u>	<u>6,339</u>	<u>7,359</u>	<u>7,464</u>
SUBTOTAL		\$ 52,282	\$ 42,626	\$ 60,837	\$ 52,491	\$ 61,403	\$ 51,305	\$ 66,174	\$ 57,266
CONTINGENCY		<u>5,228</u>	<u>4,264</u>	<u>6,084</u>	<u>5,248</u>	<u>6,140</u>	<u>5,130</u>	<u>6,617</u>	<u>5,727</u>
TOTAL ESTIMATE		\$ <u>57,510</u>	\$ <u>46,890</u>	\$ <u>66,921</u>	\$ <u>57,739</u>	\$ <u>67,543</u>	\$ <u>56,435</u>	\$ <u>72,791</u>	\$ <u>62,993</u>

1-21



Table 1-3 Reactor Coolant System Parameters

NOMINAL VALUES

<u>Design Performance Summary</u>	<u>Metric</u>	<u>English</u>
Power	365 MWt	365 MWt
Steam pressure at SG outlet (at full load)	5.52 MPa	800 psia
Steam temperature at SG outlet	270°C	518°F
Steam flow	191 kg/s	1.512 x 10 <sup>6</sup> lb/hr
Feedwater inlet temperature	204°C	400°F
Nominal core inlet temperature	300°C	571.6°F
Nominal core outlet temperature	319°C	606.4°F
Reactor vessel average temperature	309.4°C	589°F
RCS flow	3289 kg/s	26.06 x 10 <sup>6</sup> lb/hr

Equipment Data/Design Performance Data

No. of SG modules	12	12
RCS total primary volume	106.9 m <sup>3</sup>	3775 ft <sup>3</sup>
Primary water volume	99.8 m <sup>3</sup>	3525 ft <sup>3</sup>
Pressurizer gas volume	7.08 m <sup>3</sup>	250 ft <sup>3</sup>
Reactor Vessel ID	3.99 m	157 in.
No. of Control Rod Assemblies	17	17
No. of fuel assemblies	57	57
RC pump flow (four used)	1.196 m <sup>3</sup> /s	18,950 gpm
RC pump head	32.31 m	106 ft
RC pump expected power, hot	0.326 MW	437 hp
Pressurizer		
Overall length	8.969 m	29 ft, 5.125 in.
Sheel OD	2.013 m	79.25 in.





## 2.0 INTRODUCTION

To date, there have been no domestic applications of nuclear steam generation for industrial applications. Until the advent of the small PE-CNSG, nuclear plants had been much too large to consider for use by a single industrial user. Also, in the Gulf Coast area, the incentive for industrial users to convert from inexpensive, plentiful, and clean natural gas fuel has been virtually nonexistent until the pending fossil fuel shortage was recognized recently.

With the stated national goal of energy independence coupled with the domestic fuel oil and natural gas shortages and large oil import requirements at increasing and unpredictable cost, attention has been focused on increased utilization of abundant domestic fuels. The most abundant domestic fuel is coal, followed by nuclear fuel. Therefore, the current interest in energy production is now centered on the utilization of these two fuels. The Gulf Coast is an area in which an industrial nuclear steam generation plant might prove economically attractive. Major coal deposits are located some distance from the Gulf Coast, and coal prices are expected to contribute to the nuclear plant appeal along the Gulf Coast more so than at other locations nearer coal supplies.

The B&W PE-CNSG is a small nuclear reactor, being approximately one-tenth the size and output of central generating station reactor plant. The 365-MW thermal capacity of the PE-CNSG is suited for applications requiring 1 to 1.2 million lb/hr of process steam. While the PE-CNSG is a pressurized water reactor (PWR) and designed to deliver saturated or slightly superheated steam, it is feasible to superheat this steam in an external fossil fired superheater with some economic penalty.

The technical and economic feasibility of using the PE-CNSG to provide process steam for industrial use has been found attractive for the hypothetical "Middletown, U.S.A." site in previous studies by ERDA, ORNL, B&W, and UE&C (Reference 1). It is the intent of this study to determine PE-CNSG feasibility for an actual plantsite; namely, Du Pont's site at Victoria, Texas.

The Du Pont site was chosen as a study site because it is within the range of PE-CNSG applicability and is typical of large industrial steam users. In addition, Du Pont and other Texas industries are faced with cutbacks in their current natural gas supplies and increases in the price of natural gas. Therefore, if industry is to expand its operations, or even maintain current output, an alternative fuel is going to have to be utilized. Du Pont has already made provisions to burn number 6 fuel oil as a backup fuel, and the evaluation of coal as an alternative fuel has already been initiated by Du Pont.

The study report herein has been designed to complement Du Pont's in-house efforts to find economical alternative sources of energy for process steam production. Coal has been chosen for comparison with the nuclear option because Du Pont is also studying coal and because coal is the most plentiful domestic fuel and offers promise of being economically attractive.



## 2.0 INTRODUCTION - (Continued)

The nuclear plants and coal plants considered in this study have been designed to match, in steam output and conditions, the following Du Pont requirements:

Steamflow:	
Peak	1,000,000 lb/hr
Annual Average	723,000 lb/hr
Pressure	550 psig
Temperature	750 °F

While a coal plant can be sized and optimized around the stated conditions, the PE-CNSG capacity is fixed by design except for changes in operating mode and auxiliary equipment. The Du Pont requirements do not fully utilize the steaming capacity of the PE-CNSG, but the nuclear plants studied have been optimized by including by-product electrical power to make more efficient use of the available steaming capacity.

The coal plants studied have been optimized as well through the incorporation of backpressure and/or extraction-condensing cycle electrical power generation.

This study has been a cooperative effort. Those participating in the study are the following:

Oak Ridge National Laboratory (ORNL)  
Power Systems Engineering, Inc. (PSE)  
The Babcock and Wilcox Company, Nuclear Power Generation  
Division (B&W)  
United Engineers and Constructors, Inc. (UE&C)  
E.I. Du Pont De Nemours and Company, Inc. (Du Pont)

The study has been funded by the Department of Energy (DOE). Du Pont provided all information necessary to interface this study with their requirements, and without Du Pont's significant contribution, this study would not have been possible.

The study was directed by ORNL with PSE acting as study coordinator. PSE was responsible for the physical interfacing of all study plants to the existing Du Pont system and for the development of all coal plant aspects of the study. The economic evaluation of alternatives was the responsibility of PSE as was the assembly of this final report. B&W and UE&C were responsible for all aspects of nuclear study plant development, site evaluations and reporting.



### 3.0 SYSTEMS DESCRIPTIONS

#### 3.1 Design Requirements

##### 3.1.1 Description of Existing Plant

###### 3.1.1.1 General

The site is large with adequate space for either the coal or nuclear alternative. Access to the site is by highway (Texas 185), daily rail (Southern Pacific and Missouri Pacific), and sea-level barge canal approximately 100 feet wide and 10 feet deep (8 feet deep into the plant). The Guadalupe river is adjacent to the barge canal. The site is at an average elevation of 65 feet MSL, or about 30 feet above the 100-year flood level. The nearest residential population center to the plant is about 3 miles distant having a population of about 500 people. The city of Victoria is about 10 miles away and has a population of approximately 50,000. The principal use of land adjacent to Du Pont's property is for beef cattle grazing and farming. It is expected that the surrounding areas will tend towards industrialization in the future. Figure 3-1 locates the site.

Du Pont is a net purchaser of electrical power at the present time and the present electrical demand exceeds the generating capacity of all systems studied herein. Total steam production capability is  $2.3 \times 10^6$  lb/hr.

Cooling water and plant runoff are held in a pond for analysis and treatment prior to discharge into the river.

###### 3.1.1.2 Historical and Structural Geology

The tertiary structures in the Gulf region, known as growth-faults, consist of a series of generally gulfward oriented faults in Louisiana and Texas initiated as a result of slumping, and often associated with salt or clay. The age of development and formation of the faulting is lower for faults nearer the Gulf. The oldest Pleistocene structures occur closest to the present shore and appear as large isolated salt deposits while the recent Pleistocene and salt structures are developing further south on what is known as the continental shelf. The sedimentation process presently is taking place in this area.

The thickness of the Quaternary strata reaches 12,000 feet of hard clays and silts (neritic deposits) which alternate with dune sands and hard clays and silts (shore deposits). Subsidence, consolidation, erosion and sedimentation as well as oxidation are some of the common features of this phase.

The structural geology of the Gulf Coastal Plain is rather complex and started its development more than 230 million years before present (mybp). The presence of salt and its movement during the Tertiary (65 to 2 mybp) have been responsible for the development of many types of salt structures. This motion has been sustained by continued sedimentary loading in the Gulf. Also, a system of normal faults are known



### 3.1.1.2 Historical and Structural Geology - (Continued)

to have developed in association with the development of salt domes.

In contrast to these, another system of structures known as growth faults exists in the Gulf Coastal Plain. These faults are most of the time dipping southward 40 to 60 degrees. This angle decreases as the fault extends downward, essentially becoming a bedding plain fault. The results therefore are essentially within the sedimentary sequence and not an extension of the deeply buried tertiary structures. The movement of these faults is contemporaneous and associated with sediment deposition. Since this is a rather slow phenomenon, it is believed that strain accumulation leading to sudden movement and generation of seismic energy cannot take place.

### 3.1.1.3 Site Geology

A detailed geologic study on a rectangular area 5.4 x 8.1 miles with the Du Pont Victoria Plant at the center was prepared by Wm. H. Price. Co., Austin, Texas, with the purpose to determine the Oakville-Catahoula Strata injection capacity. The study shows that this is an area of massive sand development in the lower Miocene interval. It further indicates that the study area exhibits typical coastal geology with the sands dipping toward the coast and broken by down-to-the-coast faulting. Only minor faulting (less than 200 feet throw) occur in the study area, although major faulting on the order of 1000 feet occurs several miles to the southwest and to the east of this region. It appears that a deep-seated salt intrusion occurs beneath the plant site area causing a local anticlinal structure which is fragmented by minor faulting.

The base of the Pleistocene (lissie) consists of fresh water sand which is the main aquifer (300 - 350 feet) from which sanitary water is obtained. The Pleistocene continues to the surface with marine clays of the outer coastal plain, known as Beaumont and having a thickness of about 500 feet. The Guadalupe River is the main supplier of water for the plant which requires about 30,000 gpm.

The soil reports made available by Du Pont show six borings (about 200 feet) which are located 1500 feet SE of the proposed PE-CNSG site. The boring supervision and testing of samples was performed by Trinity Testing Laboratories, Inc., Austin, Texas, who also prepared the foundation report. The results confirm a characteristic common to the Texas clays, the upper layer generating volume change problems, i. e., swelling or shrinkage depending on the conditions which are present. As the volume-change of these mostly bentonitic type clays affects mainly the surface layers, deep foundations are devoid of these problems if properly treated.

The borings have indicated the presence of expandable soils up to 16 feet from the surface. These consist of clay and sand clay with caliche and do normally require special treatment if foundations are placed on them. Below this depth normally follows silty sands and then sandy clay. These soils are dense or stiff and possess higher bearing values.



### 3.1.1.3 Site Geology - (Continued)

Past experience with nuclear plants in the Gulf Coast area shows that plants located in similar soils and geologic conditions can be licensed.

### 3.1.2 Steam and Power Requirements

Du Pont currently operates two natural gas/waste-fuel-fired steam generation systems with number 6 oil backup:

- (1) 650,000 lb/hr, 550 psi/saturated steam directly to process. Steam is delivered to process at 550, 175, and 15 psi.
- (2) 1,400,000 lb/hr, 550 psi/750°F. Normal generation is about 1,200,000 lb/hr annual average. In this system are numerous power turbines exhausting at 175 psi with exhaust steam being desuperheated and delivered to process. Total mechanical power generation from steam is approximately 20,000 horsepower.

The second system, (2), is the one which was "replaced" for the feasibility study. Since a certain amount of steam must be generated in this system out of the necessity to burn waste fuels, the levelized annual nuclear or coal steam generation delivered to the Du Pont system must be limited to 723,000 lb/hr at 550 psi/750°F. Since existing power turbines are to be maintained, the PE-CNSG/coal system interface is the existing 550 psi/750°F steam header.

Du Pont supplies deaerated feedwater with a conductivity of one micromho or better at approximately 50 psig and 280°F. Therefore, the interface for feedwater is at Du Pont's feedwater header, with boiler feed pumps being the first major equipment in the study scope.

### 3.1.3 Study Premises

Significant study premises are itemized below:

(1) Du Pont supplies, at their existing header, deaerated and treated boiler feedwater (including makeup) in sufficient quantities for each study plant. The feedwater is supplied at 50 psig and 280°F.

(2) Du Pont receives, at their existing header, 550 psig, 750°F steam from the study plants. Two of the five nuclear study plants supply saturated steam to the process. These plants were studied to gain insight into the effects of superheating with fuel oil and of operating the PE-CNSG at reduced load.

(3) Study plants having different availabilities, capacities, or operating life are equalized economically by charging the study plant with the number 6 fuel oil equivalent of any steam deficit with reference to the steam flow requirement. In so doing, each plant is compared on the basis of equal total Btu production over the life of the project.



### 3.1.3 Study Premises

(4) Study plants having power generating capability are charged a utility backup fee for capability in excess of 15 MWe. Auxiliary power and/or net power generated by study plants is routed through Du Pont's existing substation, PPS-3.

(5) Service water, potable water, and fire water are provided by Du Pont at existing headers.

(6) Estimates include provisions for absorbing additional heat rejection loads resulting from the operation of the study plants.

(7) The study plants include provisions for all other items necessary for engineering, construction and operation. The cost of Du Pont internal administration and management has not been estimated.

This feasibility study compares the PE-CNSG with coal-fired alternatives. No attempt has been made to compare these systems with those facilities currently being operated by Du Pont.

## 3.2 Study Systems

### 3.2.1 Process Energy - Consolidated Nuclear Steam Generator Facility

#### 3.2.1.1 Plant Layout

The plant layout and balance of plant (BOP) design for this study are based on a previous land-based PE-CNSG industrial application study conducted by B&W in conjunction with UE&C. The objective of this study has been to modify the previous study plant layout, conceptual design, and cost estimates to incorporate the site-specific and user-related criteria of the existing Du Pont plant.

This section discusses the site layout and plot plan for the PE-CNSG for the Du Pont site. The major factors affecting the layouts are first discussed, followed by a description of the actual layout for the site.

As discussed in Section 3.1.1.3, the site is characterized by soils which are prone to significant amounts of heave and settlement. Based upon these and other soil characteristics expected to be encountered at the site, a "floating foundation" concept was selected. This foundation concept consists of a thick concrete mat supporting one building (called "nuclear island") which houses all safety-related systems and which would further ensure evenly distributed loads on the foundation mat to minimize differential settlements. Hanford Nuclear Plant (Units 3 and 4) for Washington Public Power Supply System is an example of a central station nuclear plant using the "floating foundation" concept because of soil conditions similar to those at the Du Pont site.

Soil conditions also have a major influence on the type of ultimate heat sink employed. A once-through intake and discharge system may be feasible for the site, but licensing problems may arise because of soil conditions which are far from ideal (such as the plant founded on rock) for such a system. To avoid these potential problems a two-cell wet mechanical draft cooling tower with a basin for a 30 day supply of



### 3.2.1.1 Plant Layout - (Continued)

makeup water is used. In any case, the difference in capital costs for the cooling tower and the once-through systems is believed to be small and cannot have a significant effect on the economic conclusions of this study.

Off-site power requirements of the nuclear plant were met by tapping the two independent 138 KV lines which serve the existing plant. A transformer is used for each 138 KV line to reduce the voltage to 4.16 KV. A circuit from each transformer is routed to the proposed PE-CNSG plant via an underground duct bank.

The site layout and plot plan based on these basic criteria were developed as shown in Figures 3-2 and 3-3 respectively. The particular location shown for the nuclear plant was selected for study purposes, and no attempt was made to determine if alternate locations may be more desirable based upon safety and/or economic considerations. The nuclear island, as discussed previously, contains the reactor service building which houses the reactor containment, the ultimate heat sink with the water reservoir, the diesel generator, the fuel oil storage building and the control building. The borated and demineralized water storage tanks are located on the roof of the reactor service building. The nuclear island proposed is considered to be a reasonable concept for the particular geological and soil conditions expected at the Du Pont site. The cost estimates assume that the reactor service, control diesel generator, and diesel fuel oil storage are contained in separate buildings, which is the basis for previous PE-CNSG studies. Specifically, it is assumed that the cost of the nuclear island is equal to a concept utilizing separate building. It is more than likely, however, that the nuclear island with a floating foundation will require additional strength in the mat, exterior walls, some interior walls, and the roof. While an evaluation of the additional cost is beyond the scope of this study, it is believed that the direct capital costs for the nuclear plant possibly may be higher by an amount up to \$2,000,000 for an installation using this concept. The cost estimates presented in Section 4.0 do not reflect this potential additional cost.

The administration and process heat service buildings provide space for offices, change rooms, maintenance shop, spare parts storage, etc. The process area is an open area with ground floor slab and individual equipment foundations and supports. All facilities are located in two main sections that are joined by an underground piping tunnel which permits the installation of an access road through the middle of the plant layout. The access road permits easy movement of equipment and personnel around the site.

For the purposes of this study, it is assumed that the bottom of the foundation for the nuclear island is approximately 35 feet below existing grade.

### 3.2.1.2 Nuclear Steam Generating System

The Consolidated Nuclear Steam Generator (CNSG) concept was originally developed to provide propulsion power for commercial nuclear ships. This marine nuclear propulsion system, on which the PE-CNSG for industrial use is based, evolved as an advanced ship propulsion reactor having size, weight, and reactor safety benefits. The CNSG design was an extension and advancement of Babcock & Wilcox's experience beginning in the late 1950s with the company's activities in the NSS Savannah program. Design modifications to the basic concept have been made as a result of design reviews by both governmental and industrial groups. Modifications to the marine CNSG design were made only to change the design to landbased application where significant benefits could be realized.

#### 3.2.1.2.1 Reactor Coolant System

The PE-CNSG is an integral pressurized water system in which the core, steam generator, and reactor pumps are located within the 157-inch inside diameter cylindrical reactor vessel (Figure 3-4). An electrically heated pressurizer of conventional design is connected externally to the pressure vessel to maintain the coolant in a sub-cooled liquid condition.

The steam generator consists of 12 modular once through units located above the top level of the core in the annulus between the core and pressure vessel. A steam generator module can be isolated in the unlikely event of tube failure, with total steam output being reduced by only about 8%. Each steam generator module incorporates counter-flow heat transfer with shell-side boiling to produce saturated steam. The control scheme developed for this application maintains the reactor coolant average temperature constant at 589°F between 100% and 50% power and decreases the temperature linearly between 50% and 0% load. The steam pressure varies from 800 psia at 100% power to 1100 psia at 50% power and remains constant at 1100 psia below 50% power.

Four primary coolant pump motors are mounted on the reactor vessel head with the shafts passing through the head to the impellers inside the vessel. The pumps are rated at 18,950 gpm and 106 ft head are vertical, single-stage, single-suction, constant-speed mixed-flow units. They are glandless, wet stator/rotor machines with no mechanical seal between the pump and motor. The pump motors are cooled by an external heat exchanger.

The reactor core consists of 57 fuel assemblies with Zircaloy-4 tubes containing slightly enriched UO<sub>2</sub> pellets enclosed by welded end plugs. Tubes containing fuel are supported in assemblies by a spring-clip grid structure and end fittings. The 17 control rod assemblies, which control reactor power, are clusters of neutron absorber rods containing B<sub>4</sub>C that move in guide tubes within the fuel assemblies.





### 3.2.1.2.1 Reactor Coolant System - (Continued)

During operation the reactor coolant is pumped downward through the steam generator tubes where the coolant transfers heat to the secondary side feedwater, thereby producing saturated steam. Leaving the steam generator modules, the coolant flows downward over mixing vanes and then turns upward into the core at the bottom of the reactor vessel. Heat generated by fission in the nuclear fuel raises the coolant temperature as it passes upward through the core. The coolant continues to flow upward until it reaches the reactor coolant pump suction.

Reactor coolant system parameters are shown in Table 3-1.

### 3.2.1.2.2 Auxiliary Systems

A number of auxiliary systems are required to support the reactor coolant system. Major systems are listed below with a brief functional description.

Makeup and Purification System - Regulates inventory of the reactor coolant system during all modes of operation and removes corrosion products, fission products, and other impurities from the reactor coolant.

Decay Heat Removal System - Removes fission product decay heat from the reactor core during normal cooldown or following reactor trip and during shutdown, and provides cooling water injection to the reactor vessel and core under emergency conditions.

Emergency Decay Heat System - Removes heat from the reactor coolant system via the steam generators during accident conditions.

Chemical Addition & Boron Recovery System - Transfers, stores, recovers and thereby changes concentration of boric acid in the reactor coolant system during normal operation.

Reactor Plant Service Water System - Supplies cooling water to the reactor plant from the available water sources.

Component Cooling Water System - Transfers heat from various sources in the reactor plant to the reactor plant service water system via heat exchangers.

Containment Drywell Cooling System - Removes heat from the containment drywell atmosphere during both normal operating and emergency loss-of-coolant accident (LOCA) conditions.

Reactor Building Ventilation System - Provides ventilation of various areas in the reactor building and controls release of radioactive gases to the environment via filters.

Radwaste Disposal System - Collects, stores, and disposes of all solid, liquid, and gaseous wastes generated by normal operation of the reactor plant.



### 3.2.1.2.2 Auxiliary Systems - (Continued)

Post-LOCA Combustible Gas Control System - Injects Halon 1301 into containment following a LOCA to prevent ignition of hydrogen.

Sampling System - Provides a means of remotely sampling primary coolant, key auxiliary system effluents, and all waste gases.

Suppression Pool Cooling System - Maintains the containment suppression pool water temperature and chemistry at required levels during normal and emergency conditions.

### 3.2.1.2.3 Reactor Plant Instrumentation & Control Systems

The following sub-systems comprise the reactor plant instrumentation and control systems and provide for control, monitoring and safe shut-down of the reactor plant.

- Integrated Control System
- Nuclear Instrumentation System
- Reactor Protection System
- Non-Nuclear Instrumentation and Control Systems
- Engineered Safety Features Actuation System
- Safety-Related Control and Instrumentation System
- Control Rod Drive Control System
- Incore Monitoring Systems

### 3.2.1.2.4 Containment

The PE-CNSG nuclear steam system is enclosed by a containment vessel the purpose of which is to condense and contain the steam-water mixture that would discharge from a postulated pipe break in the PE-CNSG.

The pressure-suppression containment (Figure 3-5) comprises a dry well into which the steam-water mixture expands after being discharged through the break, a wet well containing a large volume of water for condensing the steam as it discharges through the vent pipes, and a suppression system air space into which the containment non-condensable gases are collected after condensation of the steam in the wet well. Because the steam is condensed in the wet well, the PE-CNSG containment can be relatively small and still produce a reasonably low design pressure (105 psig). The large PWR nuclear power plants do not have pressure-suppression containments and, thus, with the rapid release of steam-water mixtures, the containment must be very large to maintain a reasonably low design pressure.

Because of the compact reactor design and resulting suitability of pressure suppression containment as well as improved loss-of-coolant-accident (LOCA) transient characteristics of the PE-CNSG, the relatively small containment can be housed within the reactor service building in contrast to the loop-type PWRs where the containment is a large separate structure outside the reactor service building. The pressure-containing wall of the cylindrical PE-CNSG containment is 38 feet in diameter by 64 feet high. The containment is free-standing and bottom-



#### 3.2.1.2.4 Containment - (Continued)

supported. An upper closure is provided for refueling, inspection, and maintenance. The containment has a normal personnel access at about mid-height, which is closed and sealed during operation. Access to the area under the reactor vessel and through the NSS/containment load-bearing support plate is provided by an access tunnel and a bolted containment closure.

The PE-CNSG containment is surrounded by a concrete biological shield which protects against direct radiation from the PE-CNSG core and induced radioactivity in the primary coolant. The concrete biological shield and the reactor service building itself provide two additional barriers to the containment for minimizing the accidental release of radioactivity to the environment. This is accomplished by controlling and isolating these areas and filtering the air that is released to the environment.

#### 3.2.1.3 Refueling, Maintenance, and Inspections

The PE-CNSG fuel handling systems provide a safe, effective means of transporting and handling nuclear fuel from the time of its arrival at the plant in an unirradiated condition until its departure from the plant after post-irradiation cooling. Supporting systems have been designed to minimize the possibility of mishandling which could cause fuel damage or potential release of fission products.

The land-based PE-CNSG uses a conventional method of "wet" refueling where all operations are performed underwater. Underwater transfer of spent fuel assemblies will provide an effective, transparent radiation shield as well as a reliable cooling medium for removal of decay heat. Use of borated water provides an added safety margin that will ensure subcritical conditions during refueling. Both new and spent fuel storage are housed in the fuel storage pool located next to the reactor containment inside the reactor service building.

The refueling outage is estimated to be 30 days if performed every 12 months, 35 days if performed every 18 months, and 40 days if performed every 24 months. The outage days shown include not only the refueling time but also time for maintenance and inspections. The additional outage time for longer refueling cycles is for estimated additional maintenance due to the longer plant operating time.

The PE-CNSG has been designed to be highly accessible for the performance of Code-required inservice inspection. Through the use of remote examination devices, all the welds and components requiring examination under the rules of Section XI of the ASME Boiler and Pressure Vessel Code, 1975 Winter Addenda, can be examined.

The initial inspection results obtained prior to critical operation of the plant form the base map against which future inspection results will be compared. Any subsequent changes in inspection results recorded



### 3.2.1.3 Refueling, Maintenance, and Inspections - (Continued)

During the post operational inspection will be compared and evaluated against the original base data and Code-established fracture mechanics criteria. Manual scanning will be used wherever possible to provide economical inspection.

Piping and other associated components are designed taking maximum inspectability into account. Access requirements for the performance of inservice examinations required by the Code are well defined and will be applied to the maximum extent possible consistent with effective design and operation of the Nuclear Steam Plant.

The PE-CNSG is designed to facilitate any maintenance that may be required. In addition, the equipment is arranged for minimal radiation exposure to personnel during maintenance or repair. For example, in the event that it becomes necessary to plug a defective steam generator tube, the straight-tube design of the steam generator facilitates the insertion and subsequent plugging of each end of the defective tube using remote plugging techniques. Tube plugging would be conducted during a refueling outage when the vessel head and upper flow distributor are removed. Sufficient water is added between the steam generator and the maintenance personnel so that radiation doses are acceptably low.

### 3.2.1.4 Secondary/Tertiary Systems

#### 3.2.1.4.1 Introduction

In the process heat applications, it is desirable to have an additional loop or separation barrier between the reactor coolant (primary system) and the process steam (tertiary system) to minimize the possibility of radioactive contamination of the process steam. Although primary-to-secondary system leakage is not expected, the possibility of activity in secondary system steam is not excluded as a conservative design consideration. To avoid any possible radioactive carryover to the process steam, a third loop or tertiary system is provided with process steam evaporators (herein referred to as reboilers) used to transfer heat from the secondary system. Although operational experience may indicate that reboilers can be eliminated from the design for certain applications, it is believed prudent to include them for initial plant design.

#### 3.2.1.4.2 Study Cases

Five cases for supplying the process steam requirements of the process plant were devised and a reboiler system was designed for each case. Design points for each case are as follows:

Case 1 - 810,000 #/hr process steam @ 550 psig and 750°F, - Fig. 3-6

Case 2 - 1,000,000 #/hr process steam @ 550 psig and 750°F - Fig. 3-7

Case 3 - 810,000 #/hr. process steam @ 550 psig, saturated - Fig. 3-8

Case 4 - Maximum process steam that CNSG will deliver @ 550 psig saturated Fig. 3-9.



#### 3.2.1.4.2 Study Cases - (Continued)

Case 5 - 1,000,000 #/hr process steam @ 550 psig, 750°F, with the CNSG operating at maximum power and the excess secondary steam to be used in a condensing turbine for electric power generation - Fig. 3-10.

Cases 1, 3 and 5 require an oil-fired superheater to be located in the user's process plant in order to superheat the process steam to 750°F.

#### 3.2.1.4.3 Secondary System Description

The major components of the system are the reboilers and feedwater heaters. The reboilers are U-tube and shell heat exchangers with the secondary steam from the CNSG condensing in the tubes and the process fluid heated on the shell side.

A large drain reservoir is located in the condensate line between the reboilers and feedheater. This tank has a volume of 2500 ft<sup>3</sup> and serves as a four-fold purpose. This is: (1) to ensure a supply of fluid to the feedheater in the liquid state, (2) to provide the CNSG system with a 5-minute makeup supply (at maximum flow conditions) of steam generator coolant should it be required in an emergency situation, (3) to provide a location for hydrogen injection for control of oxygen in the secondary system and (4) to provide a water level which may be monitored to determine makeup requirements. During normal operation, the condensate enters the tank from the reboilers via spray nozzles. The tank contains approximately 2000 ft<sup>3</sup> of stored water, and the hydrogen gas collects above the water. The spray system provides adequate exposure of water to hydrogen gas to ensure entrainment of the hydrogen in the water. The water ultimately passes through the tank to the feedwater heaters.

The feedwater heaters are used to cool the secondary water on the tube side while heating the process fluid on the shell side. All secondary water from the tube sides of the reboilers passes through the feedheaters.

The water leaves the feedheaters and enters the suction side of the motor-driven centrifugal feedwater pump. The system has two feedwater pumps, each with 100% capacity, to provide full backup capability. The pump increases the water pressure and discharges the water to the steam generators.

Systems are provided for filtration and purification of the secondary water. An electro-magnetic filter is located downstream of the feedwater pumps. This system is designed to handle 100% of the flow. The system filters the CNSG secondary water to eliminate suspended magnetic solids formed during plant operation. The demineralization system is located downstream of the electromagnetic filter. The system is designed to handle up to 100 gpm of the system flow. The water first passes through a letdown cooler where the temperature is reduced from 400 F to 120 F. The demineralizer system is used for purification of both the letdown fluid and the makeup water.



#### 3.2.1.4.3 Secondary System Description - (Continued)

The system is intended for intermittent use depending on water quality conditions. The demineralizer discharges directly to the suction side of the feedwater pumps. Secondary system sample lines are provided on both the influent and effluent sides of the demineralizer and are used to monitor both the need for and effectiveness of the demineralizer.

The makeup system is tied directly into the demineralization system. The makeup system is controlled by the level in the drain reservoir. Water is added by the makeup system through the demineralizer when the bypass system is in operation.

If the bypass line is not in use, water is added directly to the feedwater pump inlet piping.

A chemical addition system is included for corrosion control. This system consists of hydrazine addition for oxygen control and ammonia addition for pH control. The system is manually controlled, based on input from sample readings, and used during system heatup and cooldown. Provisions for hydrogen addition have been made in the drain reservoir to suppress oxygen generated in the water by radiolysis as the water passes through the CNSG steam generator near the nuclear core. The oxygen concentration in the system is controlled to a maximum 7 ppb.

#### 3.2.1.4.4 Tertiary System

The tertiary system steam is produced on the shell side of the reboilers. Tertiary system water is returned from the user's process at 280 F and 67 psia. It then enters the suction side of the tertiary feed pump. The system has two feed pumps, each with 100% capacity. The water is increased in pressure by the pumps and then enters the shell side of the feedwater heaters, where it is partially heated while cooling the secondary fluid. At the feedwater heater outlet, the fluid is ready to enter the shell side of the reboilers. Steam leaves the reboilers at saturated conditions, and is superheated for cases 1, 2 and 5.

Solids buildup in the reboiler is controlled by blowdown. There is one blowdown cooler in the system with a common intake line connected directly to the shell side of the reboilers and discharging to the user. The continuous blowdown rate is 1% flow for control of solids.

The tertiary system fluid is sampled from the blowdown cooler discharge line. This method of sampling allows examination of effluent from the reboilers without affecting operation.

#### 3.2.1.4.5 System Control

The CNSG reactor and reboiler systems are monitored and controlled by computer systems. The Operator Information System (OIS) computer provides display, logging, and alarm monitoring of reactor and reboiler systems. The OIS also provides diagnostic monitoring of other computer systems. The Plant Control System (PCS) controls the PE-CNSG and re-



#### 3.2.1.4.5 System Control - (Continued)

boiler by monitoring plant variables and initiating control action as well as by interfacing with the control console and OIS.

##### Secondary System

Reboiler heating steam is supplied by the main steam from the CNSG compartment. The heating steam is controlled via control valves that regulate the flow to the reboilers. These control valves are monitored and controlled by the plant control system. If the heating steam demand becomes too low for the control valves to operate satisfactorily, one or more of the reboilers can be valved out of service. The process steam demand also regulates reactor power level. The secondary fluid level in the drain reservoir is monitored and controlled by the plant control system via the makeup supply. The plant control system automatically adjusts the makeup water supply valve to allow more or less flow to the secondary system, which ultimately adjusts the level in the drain reservoir to a preset value.

Feedwater flow is controlled by the action of the feed control valve and pumps in response to signals from the plant control system. In steady-state conditions, the feed flow matches steam flow, but the flows may differ during transients.

The flow through the demineralization system is controlled by the operator through the operator information system. Temperature sensors measure effluent temperature of the letdown cooler, and flow rate is determined with a flow orifice. These values are monitored by the plant control system and, if the effluent temperature rises above 120 F, flow is stopped to avoid damaging the resins in the demineralizer. The pressure drop through the demineralizer is monitored by the OIS. This pressure measurement along with sample readings of both the influent and effluent are used to determine the need for demineralizer resin replacement.

The secondary chemical addition system is monitored by the operator information system. The ammonium hydroxide tank level is measured and transmitted by this system to the control room. The flow rates of both the hydrazine and ammonium hydroxide addition system are monitored by the operator information system and the rates are controlled manually by the operator.

##### Tertiary System

Two identical redundant feedwater pumps are included in the system design. During normal operation, one pump is running while the other remains idle. If the operating pump should fail, flow will be picked up by the idle pump. Both pumps have built-in recirculation loops with flow orifices.



### Tertiary System - (Continued)

The feedwater pumps discharge to the shell side of the feedwater heater where the fluid is heated before going into the reboilers. The feedwater to the reboilers is controlled by individual control valves; each valve is controlled by its respective reboiler water level. The level controller maintains the liquid level slightly above the tube bundle to prevent tube dry-out and excessive static pressure in the shell. If, during low-flow demand periods, the control valves fail to operate satisfactorily, one or more reboilers can be valved out of service. As the control valves are closed, the feedwater pump head increases and flow in the recirculation loop around the pumps increases.

Flow to the blowdown cooler is controlled manually by individual valves on each blowdown line. A flow orifice, located just downstream of the blowdown cooler is used by the operator information system to monitor flow. The blowdown fluid is cooled to 120 F by the cooler and flow is controlled remotely by an OIS-actuated throttle valve. The blowdown is discharged to the user's water system. Reboiler sampling is accomplished by a small line coming directly off the blowdown line. This system allows intermittent or continuous monitoring of samples from the reboilers.

#### 3.2.1.4.6 Condensing Cycle Turbine - Generator System

A schematic flow diagram for the turbine generator system for nuclear case 5 is shown in Figure 3-10. Of the 555,000 lb/hr of secondary steam directed to the turbine generator system, only 412,000 lb/hr passes through the turbine to the condenser with the remaining being used for feedwater heating under normal operating conditions. The turbine generator consists of a 3600 rpm, 34 MWe single flow non-reheat steam turbine with a direct coupled, 3600 rpm, three phase, 60 hertz, air cooled synchronous generator. The exhaust steam from the turbine is condensed in a condenser designed at 3.5" Hg vacuum. The turbine is designed to operate satisfactorily without external moisture separators. Condensate from the condenser is pumped to the deaerator by two 650 gpm condensate pumps. The deaerator is an open heat exchanger tank which directly mixes the condensate with the remainder of secondary steam directed to the turbine generator system. This feedwater joins with the secondary feedwater from the process energy system and is pumped to the steam generators by means of secondary feed pumps. Condenser heat is removed by the circulating water systems. This heat is then rejected to the atmosphere by a single cell mechanical draft cooling tower.

#### 3.2.1.5 Construction Techniques

The consolidated plant layout described in Section 3.2.1.1 lends itself to construction techniques that use a fixed lifting device, such as a 300 ton stiff-leg crane, for all major lifts. This device will help to speed construction by making heavy lifts readily available and facilitating component placement.





### 3.2.1.5 Construction Techniques - (Continued)

The load-bearing structure for the entire reactor complex is a steel plate 4-inches thick and 38 feet in diameter. This plate is shop-fabricated to include the code-welded, 4-foot-high bottom segment of the reactor containment cylindrical sections.

The reactor vessel support pedestal upon which the skirt-supported reactor vessel will be positioned is centrally located on this plate. Webbing structures distribute the load from the vessel support pedestal to the support plate. The prefabricated, stress-relieved support plate and attachments are transported to the site, set on the reactor service building concrete base, jacked level, and grouted into position with cement. The reactor support pedestal is then ground to reactor vessel mounting flatness requirements.

The upper portion of the 38-foot-diameter, 64-foot-high containment vessel structure is shop-fabricated. This large containment segment would be lifted into position and circle-seam welded to the load-bearing base plate segments to form the containment vessel. Major components can then be lifted and placed, and the concrete shielding can be poured. The outer steel containment wall is covered with crushable material and is used as an inner form for the shield wall concrete to facilitate construction. The crushable material separates the concrete and steel and provides space for differential expansion and contraction. An access tunnel under the load-bearing base plate permits access to the bottom head of the reactor vessel and to incore instrumentation guide tubes and nozzles located there.

The reactor vessel is transported to the site in one piece, except for the head. The reactor vessel internals are prefitted to eliminate major field assembly problems.

### 3.2.2 Coal Fueled Steam/Power Plant

#### 3.2.2 Plant Layout

The study plant layout is shown on Figures 3-12 and 3-13. The area for the coal facility was designated by Du Pont and PSE did not attempt to optimize the location.

The site layout shows the maximum land usage anticipated for the size coal plant. The largest steam turbine generator, including a sub-station, condenser and cooling tower is shown, although this equipment does not apply to all study cases. Wyoming coal was used to size the coal storage pile and two flue gas desulfurization (FGD) systems with a bypass are shown also. At the time the estimates were finalized the FGD system was not required for firing Wyoming compliance coal. Although the FGD system is shown on the layout it was not included in the cost estimate for the Wyoming coal cases. Schematics of the flue gas treatment systems are shown in figures 3-14 and 3-15.



### 3.2.2.1 Plant Layout - (Continued)

No pilings have been used at the site in the past and land subsidence has not been a problem. Based on this information and the fact that the foundations for the coal plant would be similar to existing foundations at the site, no pilings were included.

### 3.2.2.2 Study Cases

Eight cases were selected for this study; four high-sulfur coal cases and four low-sulfur coal cases. The energy balance diagrams show the major components of each study case, the design steam conditions, the generator power output, auxiliary power load, and fuel requirement at a process steam load of 700,000 lb/hr and the maximum process steam load of 1,000,000 lb/hr. The following is a brief description of each study case:

CASE No.	COAL	BOILER DESIGN CONDITIONS				LEVELIZED ANNUAL CONDITIONS					ENERGY BALANCE DIAGRAM
		FLOW 10 <sup>3</sup> lb/hr	PRESS. PSIG	TEMP °F	GENERATOR CYCLE	FLOW 10 <sup>3</sup> lb/hr	PRESS PSIG	TEMP °F	NET MW	COAL 10 <sup>6</sup> Btu/hr	
1.	ILLINOIS	1,000	580	750	-	723	550	750	-	1,008	3-16
2.	WYOMING	1,000	580	750	-	723	550	750	-	1,029	3-17
3.	ILLINOIS	1,000	580	750	COND	723	550	750	10.9	1,288	3-18
4.	WYOMING	1,000	580	750	COND	723	550	750	18.3	1,315	3-19
5.	ILLINOIS	1,000	1,500	950	BACK PRESS.	723	550	750	9.0	998	3-20
6.	WYOMING	1,000	1,500	950	BACK PRESS.	723	550	750	9.9	1,019	3-21
7.	ILLINOIS	1,000	1,500	950	BACK PRESS.	723	550	750	36.1	1,380	3-22
8.	WYOMING	1,000	1,500	950	BACK PRESS.	723	550	750	38.3	1,409	3-23

All of the above data are based on two percent blowdown and a feedwater temperature of 280°F.

### 3.2.2.3 Design Criteria

The design criteria for each major component of the steam/power plant is as follows.

#### 3.2.2.3.1 Coal Yard

A 100-car unit train was selected as the method of coal delivery with a car positioner and a rotary car dumper used to unload the cars into an underground hopper and conveyor, which conveys the coal to the storage pile. The track length was sized at 6000 feet, which is capable of accommodating the 100-car unit train. It was assumed that enough trackage was available between the coal yard track and main line to store a full train prior to unloading.



#### 3.2.2.3.1 Coal Yard - (Continued)

The coal storage pile was sized for a 60 day supply of low-sulfur Wyoming coal. Three storage piles were used to keep the storage pile within the unit train track and to use a stacker and reclaimer with a standard span.

A separate stacker and reclaimer were specified to permit the simultaneous unloading of a unit train and the transport of coal to the plant. The stacker and reclaimer can be transferred to different piles by a cross track at one end of the coal yard.

Many design concepts are available for coal delivery and transport to the boilers. PSE selected a design which will provide an automated form of unloading and transport to the boiler. No attempt was made to optimize the design based on economics.

#### 3.2.2.3.2 Boilers

The boilers were specified for the conditions indicated on the energy balance diagrams. Auxiliary equipment was quoted with the boiler including pulverizers, FD Fan, ID Fan, Air Preheater, feedwater controls and combustion controls.

#### 3.2.2.3.3 Electrostatic Precipitator

The electrostatic discharge precipitator was specified on the basis of 85% of the ash in the coal being converted to fly ash and entering the precipitator. The design discharge particulate emission level was specified at the EPA limit of 0.1 lbs. of particulate/10<sup>6</sup> Btu of fuel. This requires a precipitator which is more than 99% efficient. A fly-ash storage silo with 60 hour capacity was specified to permit flyash storage over weekends.

#### 3.2.2.3.4 Flue Gas Desulfurization (FGD) System

A limestone slurry FGD system was specified for high sulfur coal plants to limit SO<sub>2</sub> stack emissions to 1.2 lbs SO<sub>2</sub>/10<sup>6</sup> Btu of fuel which represents the EPA new source limit in effect at the time of this study. This represents approximately 78 percent sulfur removal. A single scrubbing train was estimated as well as a bypass system to allow unit operation during short-term scrubber outages. This system was selected over other competitive systems because it is the most widely used system today. However, PSE did not attempt to optimize the type of FGD system based on economics or reliability.

In the specified system the bypass duct allows addition of flue gas downstream of the scrubber to heat the flue gas leaving the scrubber above the saturation point to prevent corrosion. The limestone slurry FGD system produces a sludge effluent which will not set up and is unsuitable for a landfill. However, if the fly ash from the precipita-



#### 3.2.2.3.4 Flue Gas Desulfurization (FGD) System - (Continued)

tor is combined with the sludge, as shown in Figure 3-24, the mixture can be used as a landfill. This method was used for the study cases. A limestone storage area has been included to provide a 30 day limestone supply. The limestone storage area was based on truck shipments of limestone.

#### 3.2.2.3.5 Bottom Ash Disposal System

This system was specified on the basis of 25% of the ash in the coal being converted to bottom ash. The bottom ash is collected in hoppers at the bottom of the boiler. From there it is sluiced to a landfill in the area near the coal storage pile.

#### 3.2.2.3.6 Steam Turbine Generator

Steam turbines were specified for the steam conditions shown on the energy balance diagrams and direct-connected to a hydrogen cooled synchronous generator rated at 3600 RPM, 3 phase, 60 Hertz, 13.8 KVA and .90 power factor with a power output as shown on the energy balance diagrams. Power from the generator was stepped up to a transmission voltage of 23 KV and connected to the existing substation PPS3. A station service transformer was included to supply coal plant auxiliaries. A separate tie from PPS3 was made to supply the auxiliaries if the turbine is shutdown.

#### 3.2.2.4 Construction Schedule

A construction schedule for a typical study case is presented in Figure 3-24.







Figure 3-1 - GEOGRAPHIC LOCATION OF THE STUDY SITE



1. REACTOR CONTAINMENT
2. REACTOR SERVICE BUILDING
3. CONTROL, DIESEL GENERATOR & ULTIMATE HEAT SINK BLDG.
4. PROCESS AREA
5. PIPING TUNNEL
6. PROCESS HEAT SERVICE BUILDING
7. ADMINISTRATION BUILDING
8. CONDENSATE STORAGE TANK
9. ACCESS ROAD
10. RAILROAD SIDING - FUEL CAR
11. TWO INDEPENDENT 5KV UNDERGROUND FEEDERS
12. PARKING AREA

NOTES:  
 1. BOILED WATER STORAGE TANK DEMINERALIZED WATER STORAGE TANK + MAKE-UP TANKS ARE LOCATED ON ROOF OF REACTOR SERVICE BUILDING

FIGURE 3-2 PE-CNSG SITE PLAN

This drawing is the property of Power Systems Engineering, Inc. Neither this drawing, nor reproductions of it, nor information derived from it, shall be given to others without the expressed written consent of Power Systems. No use is to be made of it which is, or may be, injurious to Power Systems.

REF DWGS:  
 UE & C DNG 6509-011-PH-1

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	
							NONE	
				PRELIM.			DWN.	DATE
				APPV.			PENNIS	5/22/78
				BID			CHK.	DATE
				CONST.			APPV.	DATE
				REV.			1/14	5/23/78
1	REDRAWN & ISSUED FOR REPORT	DRL	9/24/78	FINAL				

 **Power Systems Engineering, Inc.**  
 HOUSTON, TEXAS

SITE PLAN  
 CNSG FEASIBILITY STUDY

DWG. NO.  
 4027-M-4102  
 REV. 1

CLIENT: DUPONT-VICTORIA, TX PROJECT NO. 4027

SHT. \_\_\_ OF \_\_\_

3-21




FIGURE 3-3 PE-CNSG SITE PLAN 4

This drawing is the property of Power Systems Engineering, Inc. Reproduction of this drawing, for purposes other than those for which it was prepared, without the expressed written consent of Power Systems Engineering, Inc. is prohibited.

REFERENCE DRAWINGS:  
 DUPONT SITE DEVELOPMENT MAP NO. 5000  
 UE & C DWG 6509.011-PH-1

REV.	REVISION	BY	DATE	ISSUED FOR	DATE	INT.	SCALE
1	ISSUED FOR PERIOD	DLG	5/21/78				1" = 400'
2	ISSUED FOR PRELIMINARY	WEL	10/17				

Power Systems Engineering, Inc.  
 HOUSTON, TEXAS

SITE PLAN -  
 CONSOLIDATED NUCLEAR STEAM GENERATOR (CNSG)  
 FEASIBILITY STUDY

CLIENT: DUPONT - WILCOX, TEXAS PROJECT NO: 4

DWG. NO. 4027-M-410.1  
 REVISION: 1

Figure 3-4 PE-CNSG Reactor Vessel








FIGURE 3-5

365 MWt PE-CNSG CONTAINMENT ARRANGEMENT




This drawing is the property of Power Systems Engineering, Inc. No part of this drawing may be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the express written consent of Power Systems Engineering, Inc. or its authorized representative.



NR	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
1	964	975	547	1193
2	964	963	542	1193
3	964	960	542	539
4	964	960	542	539
5	964	960	542	539
6	964	960	542	539
7	964	955	414	391
8	1,014	955	400	376
9	1,014	1150	400	376
10	964	1125	400	376
11	50	1125	400	376
12	50	955	120	90
13	818	50	280	249
14	818	675	280	250
15	818	613	445	425
16	818	613	445	425
17	810	600	491	1203
18	810	600	489	1203
19	810	550	750	1332

REF: BARCOCK & WILCOX  
LETTER MRT-TI-89  
DATED 8/3/77

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INT.	SCALE
				PRELIM.			NONE
				APPV.			
				SID			
				CCNST.			
				REV.			
				FINAL			



**Power Systems Engineering, Inc.**  
HOUSTON, TEXAS


DRG. NO.

**FIG. 3-6**

CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027

**ENERGY BALANCE DIAGRAM  
CONSOLIDATED NUCLEAR STEAM  
GENERATOR - CASE NO. I**


This drawing is the property of Power Systems Engineering, Inc. It shall be given to anyone without the written consent of Power Systems Engineering, Inc. The use of this drawing is restricted to the project for which it was prepared.



NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
1	1182	895	527	1196
2	1182	875	521	1196
3	1182	872	530	525
4	1182	872	530	525
5	1182	872	530	525
6	1182	872	530	525
7	1182	865	411	228
8	1232	865	400	376
9	1232	1070	400	376
10	1182	1045	400	376
11	50	1045	400	376
12	50	865	120	90
13	1010	50	280	249
14	1010	635	250	250
15	1010	616	442	410
16	1010	615	442	410
17	1000	610	491	1203
18	1000	600	489	1203
19	1000	550	750	1382

REF: BARCOCK & WILCOX  
LETTER MRT-77-89  
DATED 8/3/77


NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE
				PRELIM.			NONE
				APPV.			DANS 7/27/77
				BID			
				INST.			APPV. 5/22/77
				REV.			
				FINAL			


**Power Systems Engineering, Inc.**  
 HOUSTON, TEXAS

**ENERGY BALANCE DIAGRAM  
 CONSOLIDATED NUCLEAR STEAM  
 GENERATOR — CASE NO. II**

CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027

DRG. NO. \_\_\_\_\_  
 FIG. 3-7  
 SHT. \_\_\_\_\_ OF \_\_\_\_\_



NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
1	964	975	543	1193
2	964	963	542	1193
3	964	960	542	539
4	964	960	542	539
5	964	960	542	539
6	964	960	542	539
7	964	955	414	391
8	1014	955	400	376
9	1014	1150	400	376
10	964	1125	400	376
11	50	1125	400	376
12	50	955	120	90
13	818	50	250	249
14	818	633	240	250
15	818	614	445	425
16	818	613	445	425
17	810	610	491	1203
18	810	550	480	1203

This drawing is the property of Power Systems Engineering, Inc. It is to be used only for the project and location specified. No part of this drawing is to be reproduced or transmitted in any form or by any means electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without the written permission of Power Systems Engineering, Inc.

REF: BASCOCK & WILCOX  
 LETTER M21-TI-89  
 DATED 8/3/77


NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE
				PRELIM.			NONE
				APPV.			OWN. DENNIS 9/29/77
				BID			DATE
				CONST.			APPV. Duv 5/22/78
				REV.			DATE
				FINAL			

Power Systems Engineering, Inc.  
 HOUSTON, TEXAS

**ENERGY BALANCE DIAGRAM**  
**CONSOLIDATED NUCLEAR STEAM**  
**GENERATOR - CASE NO. III**

DWG. NO. FIG. 3-8


CLIENT: DUPONT-VICTORIA TEXAS PROJECT NO. 4027



NO.	FLOW (1000 LB/HZ)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (KCAL/LB)
1	1512	785	518	1199
2	1512	755	514	1199
3	1512	749	513	503
4	1512	749	513	503
5	1512	749	513	503
6	1512	749	513	503
7	1512	739	403	385
8	1562	739	400	376
9	1562	960	400	376
10	1512	935	400	376
11	50	935	400	376
12	50	739	120	90
13	1301	500	280	249
14	1301	585	280	250
15	1301	566	411	333
16	1301	565	411	333
17	1282	560	452	1204
18	1282	550	480	1204

This diagram is a schematic representation of the process and should not be used for design or construction purposes. It is intended for informational purposes only.

REF: BARCOCK & WILCOX LETTER MZT-TI-89 DATED 8/3/77	NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	Power Systems Engineering, Inc. HOUSTON, TEXAS		DRG. NO.	
					PRELIM.			NONE			ENERGY BALANCE DIAGRAM CONSOLIDATED NUCLEAR STEAM GENERATOR — CASE NO. IV CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027	
					APPV.			DWN. DANKS	DATE 9/29/77			
					SID			CHE.	DATE			
					CONST.			REV.	DATE			
				FINAL				DATE				



NR	FLOW (1000 LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
1	1512	785	518	1199
2	1177	755	514	1199
3	1177	752	514	504
4	1177	752	514	504
5	1177	752	514	504
6	1177	752	514	504
7	1177	748	411	323
8	1562	748	400	376
9	1562	920	400	376
10	1512	935	400	376
11	50	935	400	376
12	50	748	120	90
13	1010	50	280	249
14	1010	635	280	250
15	1010	614	410	359
16	1010	613	410	359
17	1000	610	491	1203
18	1000	600	489	1203
19	1000	550	750	1382
20	336	755	514	1199
21	250	755	514	1199
22	250	7.5" Hg	121	89
23	250	755	122	92
24	86	755	514	1199
25	336	750	400	376

GROSS GENERATION - 21 MW

REF: BARLOCK & WILCOX  
LETTER M-21-TI-89  
DATED 8/3/77

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE
				PRELIM.			NONE
				APPV.			
				BID			
				CONST.			
				REV.			
				FINAL			

Power Systems Engineering, Inc.  
HOUSTON, TEXAS


**ENERGY BALANCE DIAGRAM  
CONSOLIDATED NUCLEAR STEAM  
GENERATOR - CASE NO. V**

FIG. 3-10

CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027


This drawing is the property of Power Systems Engineering, Inc. and is loaned to you for your use only. It is not to be reproduced, copied, or distributed in any form without the written consent of Power Systems Engineering, Inc. The information contained herein is confidential and its disclosure to any other party is strictly prohibited.

FIGURE 3-11 - NUCLEAR PLANT Nth OF A KIND CONSTRUCTION SCHEDULE



**EQUIPMENT LIST**

- 1 LIMESTONE UNLOADING HOPPER
- 2 LIMESTONE STORAGE PILE
- 3 CATALYST STORAGE BIN
- 4 MAKE UP CATALYST FEED TANK
- 5 STORAGE SILO
- 6 SLURRY FEED TANK
- 7 LIMESTONE PREPARATION & FEED BUILDING
- 8 SCRUBBER BY-PASS DUCT
- 9 CONVEYOR
- 10 CEPLOS BUILDING
- 11 SLURRY DRAIN PUMP
- 12 PRECIPITATOR
- 13 CONTROL ROOM, WAREHOUSE
- 14 BUNKER
- 15 COAL CRUSHERS
- 16 STREAM TUBING AREA & PUMP STATION
- 17 CONDENSATE TANK
- 18 COOLING TOWER
- 19 SET ASH SILO
- 20 SLUDGE/SLAG LOADING TERMINAL
- 21 SLURRY REACTOR TANK
- 22 GRUBBER
- 23 THICKENER
- 24 TRACK
- 25 WAGON/DRUMMAL STORAGE PILE
- 26 RAILROAD
- 27 COAL CAR DUMPER & POSITIONER
- 28 COAL STORAGE
- 29 RECLAIMER
- 30 STACKER
- 31 ASH STORAGE



**FIGURE 3-13 COAL PLANT  
SITE PLAN**

1. FOR NOTES & REF. DRAWINGS SEE 4027-M-4001

NOTES:

NO.	REVISIONS	BY	DATE	SCALE 1" = 100' (1/4")	PROJECT
1	ISSUED FOR REVIEW	TRC	4/17/76		POWER ENGINEERING CONSULTANTS, INC. 10000 WEST 10TH AVENUE, DENVER, COLORADO 80202 SITE PLAN COAL-FIRED UTILITY BOILER SYSTEM FEASIBILITY STUDY CLIENT: DUPONT - VICTORIA, TEXAS, 4027-M-4002
2	ISSUED FOR PROGRAMMING	TRC	1/1/77		

3-30



3-31




FIGURE 3-12 COAL PLANT SITE PLAN

This drawing is the property of Power Systems Engineering, Inc. No other use, reproduction or disclosure of its information derived from it, shall be given without the expressed written consent of Power Systems. No use is to be made of it which is, or may be, injurious to Power Systems.

REFERENCE DRAWINGS:  
 DUPONT SITE DEVELOPMENT MAP NO. 5000  
 PGE DNG NO. 4027-M-400.2

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INT.	SCALE
1	ISSUED FOR REPORT	DGL	9/21/76				1/8" = 1'-0"
2	ISSUED FOR PRELIMINARY	DRG	10/1/77				1/8" = 1'-0"

Power Systems Engineering, Inc. HOUSTON, TEXAS		DWG. NO.	4027-M-400.1
SITE PLAN COAL-FIRED UTILITY BOILER SYSTEM FEASIBILITY STUDY		REVISION:	1
CLIENT: DUPONT - VICTORIA, TEXAS		PROJECT NO.:	4027
		SHEET	1 OF 2

# FLUE GAS TREATMENT SYSTEM HIGH SULPHUR COAL

DWG. NO. REV.  
Fig. 3-14




**Power Systems  
Engineering, Inc.**

P.O. Box 19398  
Houston, Texas 77024

BY DENNIS JOB N.O. 4027 DATE 10/6/77 Sh of

0.1 LBS PARTICULATE/10<sup>6</sup> BTU FUEL  
1.2 LBS SO<sub>2</sub>/10<sup>6</sup> BTU FUEL

400' STACK



FLUE GAS TREATMENT SYSTEM  
LOW SULPHUR COAL


DWG. NO. Fig. 3-15  
REV.




Power Systems  
Engineering, Inc.

P.O. Box 19398  
Houston, Texas 77024

BY DENNIS JOB NO. 4027 DATE 10/6/77 Sh of




This drawing is the property of Power Systems Engineering, Inc. It is to be used only for the project and location specified. It is not to be used for any other project or location. It is not to be used for any other purpose. It is not to be used for any other purpose.



PERC LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
NORMAL	1	700	580	750	1379
	2	---	---	---	---
	3	---	---	---	---
	4	700	550	750	1379
	5	714	50	280	250
	6	714	750	280	250
	7	14	650	497	459
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 902 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 0					
AUX. POWER LOAD - 7.2 MW					
NET POWER OUTPUT - -7.2 MW					
MAXIMUM	1	1000	580	750	1379
	2	---	---	---	---
	3	---	---	---	---
	4	1000	550	750	1379
	5	1020	50	280	250
	6	1020	750	280	250
	7	20	650	497	489
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 1288 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 0					
AUX. POWER LOAD - 9.1 MW					
NET POWER OUTPUT - -9.1 MW					

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	Power Systems Engineering, Inc. HOUSTON, TEXAS	ENERGY BALANCE DIAGRAM COAL FUELED POWER PLANT HIGH SULPHUR COAL-CASE NO. 1 SHEET NO. 3-16	
							NONE			
										CWS. DENNIS 4-30-77 APPV. CHE. DATE
										APPV. C.W. 5/24/78 CONST. DATE REV.
										FINAL
CLUB, DUPONT-VICTORIA, TEXAS PROJECT NO. 4027								SHEET NO. 3-16		

This drawing is the property of Power Systems Engineering, Inc. It shall not be drawn, nor reproduced, nor transmitted, nor in any way be disseminated, without the expressed written consent of Power Systems Engineering, Inc. For use in the design of a project, it is intended to be used as a guide only.



PROC LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
NORMAL	1	700	520	750	1379
	2	—	—	—	—
	3	—	—	—	—
	4	700	550	750	1379
	5	714	50	250	250
	6	714	750	230	250
	7	14	650	497	485
	8	—	—	—	—
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 920 × 10 <sup>6</sup> BTU/HR (HRV)					
GEN. OUTPUT — 0					
AUX. POWER LOAD — 6.4 MW					
NET POWER OUTPUT — -6.4 MW					
MAXIMUM	1	1000	520	750	1379
	2	—	—	—	—
	3	—	—	—	—
	4	1000	550	750	1379
	5	1020	50	250	250
	6	1020	750	230	250
	7	20	650	497	485
	8	—	—	—	—
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1315 × 10 <sup>6</sup> BTU/HR (HRV)					
GEN. OUTPUT — 0					
AUX. POWER LOAD — 8.1 MW					
NET POWER OUTPUT — -8.1 MW					

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE
				PRELIM.			NONE
				APPV.			
				BID			
				CONST.			
				REV.			
				FINAL			

**Power Systems Engineering, Inc.**  
HOUSTON, TEXAS


**ENERGY BALANCE DIAGRAM**  
**COAL FUELED POWER PLANT**  
**LOW SULPHUR COAL-CASE NO. 2**

CLIENT: DUFONT-VICTORIA, TEXAS PROJECT NO. 4027

Dwg. NO. **3-17**  
Sht. \_\_\_ of \_\_\_




This drawing is the property of Power Systems Engineering, Inc. Neither this drawing nor the information contained hereon shall be given to others without the express written consent of Power Systems Engineering, Inc. No part of this drawing shall be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Power Systems Engineering, Inc.



PROC. LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP. (°F)	ENTHALPY (BTU/LB)
NORMAL	1	1000	550	750	1379
	2	300	550	750	1379
	3	—	—	—	—
	4	700	550	750	1379
	5	1020	50	250	250
	6	1020	750	250	251
	7	20	650	457	457
	8	300	4" H <sub>2</sub> O	126	94
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1315 × 10 <sup>6</sup> BTU/HR (H <sub>2</sub> )					
GEN. OUTPUT — 30.4 MW					
AUX. POWER LOAD — 10.3 MW					
NET POWER OUTPUT — 20.1 MW					
MAXIMUM	1	1000	550	750	1379
	2	0	—	—	—
	3	—	—	—	—
	4	1000	550	750	1379
	5	1020	50	250	250
	6	1020	750	250	251
	7	20	650	457	457
	8	0	—	—	—
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1315 × 10 <sup>6</sup> BTU/HR (H <sub>2</sub> )					
GEN. OUTPUT — 0					
AUX. POWER LOAD — 6.0 MW					
NET POWER OUTPUT — -6.0 MW					

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	<b>Power Systems Engineering, Inc.</b> HOUSTON, TEXAS	
				PRELIM.			NONE	DWN.	DATE
				APPV.				DEWING	9-30-77
				BID				CHE.	DATE
				CONST.				APPV.	DATE
				REV.				(Signature)	9/2/77
				FINAL					
<b>ENERGY BALANCE DIAGRAM</b> <b>COAL FUELED POWER PLANT</b> <b>LOW SULPHUR COAL-CASE NO. 4</b>								DWG. NO. <b>3-19</b>	
CLIENT DUPONT-VICTORIA, TEXAS PROJECT NO. 4027								SHE. ___ OF ___	




PRD. LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
NORMAL	1	700	1500	950	1461
	2	700	1450	950	1461
	3	700	550	745	1375
	4	700	550	745	1375
	5	714	50	250	249
	6	714	1650	280	252
	7	14	1550	602	620
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 9000 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 16.2 MW					
AUX POWER LOAD - 7.8 MW					
NET POWER OUTPUT - 8.4 MW					
MAXIMUM	1	1000	1500	950	1461
	2	1000	1450	950	1461
	3	1000	550	745	1375
	4	1000	550	745	1375
	5	1000	50	250	249
	6	1000	1650	280	252
	7	20	1550	602	620
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 1380 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 25 MW					
AUX POWER LOAD - 11.1 MW					
NET POWER OUTPUT - 13.9 MW					

This drawing is the property of Power Systems Engineering, Inc. and is loaned to you for your information only. It is not to be used for any other purpose without the express written consent of Power Systems Engineering, Inc. All rights are reserved.

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	Power Systems Engineering, Inc. HOUSTON, TEXAS	ENERGY BALANCE DIAGRAM COAL FUELED POWER PLANT HIGH SULPHUR COAL-CASE NO. 5	C.W.G. NO. 3-20
				PRELIM.			NONE			
				APPV.			DATE			
				BID			DATE			
				CONST.			DATE			
				REV.			DATE			
				FINAL			DATE			
CLARK, DUPONT-VICTORIA, TEXAS PROJECT NO 4027								SHEET _____ OF _____		




This drawing is the property of Power Systems Engineering, Inc. Neither the drawing nor its reproduction or a copy hereof shall be loaned, copied, or otherwise used in whole or in part without the expressed written consent of Power Systems Engineering, Inc. No part of this drawing shall be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Power Systems Engineering, Inc.



PRX LOAD	No	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
NORMAL	1	700	1500	950	1461
	2	700	1450	950	1461
	3	700	520	745	1336
	4	700	550	740	1333
	5	714	50	250	249
	6	714	1650	250	252
	7	14	1550	602	620
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 9800 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 10.2 MW					
AUX POWER LOAD - 0.9 MW					
NET POWER OUTPUT - 9.3 MW					
MAXIMUM	1	1000	1500	950	1461
	2	1000	1450	950	1461
	3	1000	520	745	1332
	4	1000	550	740	1333
	5	1020	50	250	249
	6	1020	1650	250	252
	7	20	1550	602	620
	8	---	---	---	---
	9	---	---	---	---
	10	---	---	---	---
	11	---	---	---	---
FUEL - 14000 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT - 25 MW					
AUX POWER LOAD - 9.8 MW					
NET POWER OUTPUT - 15.2 MW					

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE	<b>Power Systems Engineering, Inc.</b> HOUSTON, TEXAS	<b>ENERGY BALANCE DIAGRAM</b> <b>COAL FUELED POWER PLANT</b> <b>LOW SULPHUR COAL-CASE NO. 6</b> CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027	DWG. NO. <b>3-21</b>
	PRELIM.						DRAWN			
	APPV.						DATE			
	BID						CHE.			
	CONST.						DATE			
REV.						APPV.	DATE	SHE. <u>  </u> OF <u>  </u>		
FINAL						DATE				

This drawing is the property of Power Systems Engineering, Inc. No part of this drawing may be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Power Systems Engineering, Inc. The user of this drawing is to be held responsible for any errors or omissions.



PROG. LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP. (°F)	ENTHALPY (BTU/LB)
NORMAL	1	1000	1500	950	1461
	2	1000	1450	950	1461
	3	700	580	755	1376
	4	700	550	740	1379
	5	1020	0	280	249
	6	1020	1650	280	252
	7	20	1550	602	620
	8	300	4' H <sub>2</sub> O	126	96
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1435 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT — 51.5 MW					
AUX. POWER LOAD — 13.0 MW					
NET POWER OUTPUT — 38.5 MW					
MAXIMUM	1	1040	1500	950	1461
	2	1040	1450	950	1461
	3	1000	580	755	1382
	4	1000	540	750	1379
	5	1060	0	280	249
	6	1060	1650	280	252
	7	20	1550	602	620
	8	40	4' H <sub>2</sub> O	126	94
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1435 x 10 <sup>6</sup> BTU/HR (HHV)					
GEN. OUTPUT — 17.5 MW					
AUX. POWER LOAD — 11.4 MW					
NET POWER OUTPUT — 6.1 MW					

NO.	REVISION	BY	DATE	SEAL FOR	DATE	INIT.	SCALE
							NONE
				PRELIM.			
				APPV.			
				BID			
				CONS.			
				REV.			
				FINAL			

DATE: DENNIS 9-20-77

APPV: DW 5/22/77

**Power Systems Engineering, Inc.**  
HOUSTON, TEXAS

DRG. NO. 3-22


**ENERGY BALANCE DIAGRAM**  
**COAL FUELED POWER PLANT**  
**HIGH SULPHUR COAL—CASE NO. 7**

CLIENT: DUPONT-VICTORIA, TEXAS

PROJECT NO: 4027


INT. \_\_\_\_\_

This drawing is the property of Power Systems Engineering, Inc. Neither the drawing, nor reproductions of it, nor information derived from it, shall be given in whole or in part without the express written consent of Power Systems Engineering, Inc. No use is to be made of it without its express written consent.



PROG LOAD	NO.	FLOW (10 <sup>3</sup> LB/HR)	PRESSURE (PSIG)	TEMP (°F)	ENTHALPY (BTU/LB)
NORMAL	1	1000	1500	950	1461
	2	1000	1450	950	1461
	3	700	580	745	1376
	4	700	550	740	1375
	5	1020	0	280	247
	6	1020	1650	280	252
	7	20	1550	602	620
	8	300	4" H <sub>2</sub> O	126	96
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1466 × 10 <sup>6</sup> BTU/HR (HHV)					
GEN OUTPUT — 51.5					
AUX. POWER LOAD — 10.9 MW					
NET POWER OUTPUT — 40.6 MW					
MAXIMUM	1	1040	1500	950	1461
	2	1040	1450	950	1461
	3	1000	580	755	1382
	4	1000	550	750	1379
	5	1060	0	280	247
	6	1060	1650	280	252
	7	20	1550	602	620
	8	40	4" H <sub>2</sub> O	126	96
	9	—	—	—	—
	10	—	—	—	—
	11	—	—	—	—
FUEL — 1466 × 10 <sup>6</sup> BTU/HR (HHV)					
GEN OUTPUT — 17.5 MW					
AUX. POWER LOAD — 9.8 MW					
NET POWER OUTPUT — 7.7 MW					

NO.	REVISION	BY	DATE	ISSUED FOR	DATE	INIT.	SCALE
							NONE
				PRELIM.			
				APPV.			
				BID			
				CONST.			
				REV.			
				FINAL			



**Power Systems Engineering, Inc.**  
HOUSTON, TEXAS

**ENERGY BALANCE DIAGRAM**  
**COAL FUELED POWER PLANT**  
**LOW SULPHUR COAL—CASE NO. 8**

CLIENT: DUPONT-VICTORIA, TEXAS PROJECT NO. 4027

DWG. NO.  
**3-23**

SHT.      OF

Time - Months

Activities

1. Engineering
2. Order Major Equipment
3. Site Work
4. Foundations
5. Boiler, TG Erection
6. Mechanical Installation
7. Electrical Installation
8. Coal Terminal
9. Startup & Test




Figure 3-24 - COAL PLANT CONSTRUCTION SCHEDULE



Table 3-1 Reactor Coolant System Parameters

NOMINAL VALUES

<u>Design Performance Summary</u>	<u>Metric</u>	<u>English</u>
Power	365 MWt	365 MWt
Steam pressure at SG outlet (at full load)	5.52 MPa	800 psia
Steam temperature at SG outlet	270°C	518°F
Steam flow	191 kg/s	1.512 x 10 <sup>6</sup> lb/hr
Feedwater inlet temperature	204°C	400°F
Nominal core inlet temperature	300°C	571.6°F
Nominal core outlet temperature	319°C	606.4°F
Reactor vessel average temperature	309.4°C	589°F
RCS flow	3289 kg/s	26.06 x 10 <sup>6</sup> lb/hr

Equipment Data/Design Performance Data

No. of SG modules	12	12
RCS total primary volume	106.9 m <sup>3</sup>	3775 ft <sup>3</sup>
Primary water volume	99.8 m <sup>3</sup>	3525 ft <sup>3</sup>
Pressurizer gas volume	7.08 m <sup>3</sup>	250 ft <sup>3</sup>
Reactor Vessel ID	3.99 m	157 in.
No. of Control Rod Assemblies	17	17
No. of fuel assemblies	57	57
RC pump flow (four used)	1.196 m <sup>3</sup> /s	18,950 gpm
RC pump head	32.31 m	106 ft
RC pump expected power, hot	0.326 MW	437 hp
Pressurizer		
Overall length	8.969 m	29 ft, 5.125 in.
Sheel OD	2.013 m	79.25 in.



## 4.0 ECONOMICS

### 4.1 Economic Philosophy and Methods

The investments being studied in this report (nuclear and coal process steam generation plants) are mutually exclusive projects. No attempt has been made to compare the study alternatives with the economics of continued utilization of existing facilities at the Du Pont site. The economic method chosen for the analyses is the "Net Present Value" (NPV) method. This method is commonly used in the industrial sector for preliminary evaluation of investment alternatives. Cash flows from project go-ahead through 30 years project life are developed which include all major cash flows that result from the implementation of each study project.

Since the nuclear study plants require seven years to construct versus four years for the coal plants, two economic analyses have been prepared. In both analyses nuclear plant construction starts on January 1, 1978. The first analysis considers that the coal plants start construction concurrently with the nuclear plants and thus begin operation three years prior to the nuclear plants. The second set of analyses considers that coal plant construction starts January 1, 1981, and coal plants start operation concurrently with the nuclear plants.

The base date for all economic studies is January 1, 1978, and all cash estimates are reported as of that date. In the analyses, cash flows are reported in current end-of-year dollars having been escalated per schedules suggested by Du Pont or estimated by PSE. The resultant net cash flow from each analysis is discounted at rates of 10, 15 and 20 percent to arrive at a range of NPVs for each alternative. These NPVs are then compared to determine the option most attractive from an economic standpoint, namely, the alternative having the highest NPV (or the lowest negative NPV, as is the case with these "expense center" projects).

Should the NPVs of competing projects cross between the 10 and 20 percent discount rates, the choice of alternatives would not be clear and further analysis should be performed. While such crossings do occur in the results of this study, the NPVs which do cross are so nearly the same over the prescribed range of discount rates, that further analysis would not materially aid in selection of one alternative over another. Thus, the projects are said to be equivalent under the set of assumptions applied to each. Therefore, for the purposes of this study, the NPV method is the sole method employed for economic evaluation of alternative projects. Present value steam costs are presented for each study plant as complementary information.

The following sections summarize the various economic parameters which have been employed in these analyses. The cash flow pro forma statement is described with definitions of each column including mathematical formulae and descriptions of methods. An example of a cash-flow analysis is provided in order to illustrate the method. Refer to Figure 4-1.



#### 4.1.1 Escalation Schedules

Since escalation is very real factor in today's economic climate, its effect is accounted for in these studies. Table 4-1 summarizes escalation rates as they have been applied in these analyses. Following are discussions of each of the rates of escalation:

##### 4.1.1.1 General Inflation Escalation Rate

The general inflation escalation rate is applied to the working capital account and to the introductory expense.

##### 4.1.1.2 Construction Labor Escalation Rate

The construction labor escalation rate is combined with the construction material escalation rate to form a construction composite rate which is then applied to applicable capital expenditures during construction.

##### 4.1.1.3 Construction Material Escalation Rate

The construction material escalation rate is combined with the construction labor escalation rate as in 4.1.1.4. This rate is also combined with the operating labor escalation rate as described in 4.1.1.6.

##### 4.1.1.4 Construction Composite Escalation Rate

The construction composite escalation rate is formed from labor and material escalation rates (4.1.1.2, 4.1.1.3) as follows:

$$\begin{aligned} \text{Construction composite rate} &= 0.35 \text{ X construction labor rate} \\ &+ 0.65 \text{ X construction material} \\ &\text{rate.} \end{aligned}$$

The construction composite escalation rate is applied to cash flow occurring during, and related to, construction.

##### 4.1.1.5 Operating Labor Escalation Rate

The operations composite escalation rate is combined with the construction materials escalation rate to form an operations composite rate as described in 4.1.1.6.

##### 4.1.1.6 Operation Composite Escalation Rate

The operations composite escalation rate is formed from operating labor and materials rates (4.1.1.3, 4.1.1.5) as follows:

$$\begin{aligned} \text{Operations composite rate} &= 0.4 \text{ X operating labor rate} \\ &+ 0.6 \text{ X construction material rate.} \end{aligned}$$



#### 4.1.1.6 Operation Composite Escalation Rate - (Continued)

The operations composite escalation rate is applied to all study plant operating costs subject to escalation except fuel, including the electrical power costs or credits.

#### 4.1.1.7 Fuel (Primary) Escalation Rate

The fuel escalation rate is applied to primary fuel expenses (i.e., coal and nuclear fuel).

#### 4.1.1.8 Number 6 Fuel Oil Escalation Rate

The number 6 fuel oil escalation rate is applied to backup operating expense and to the fuel oil cost for superheating nuclear-generated steam where the fuel-oil fired superheater is employed.

#### 4.1.2 Federal Income Tax Rate

The federal income tax rate is applied to adjusted operating expense which is the cost of operations including annual operating expense, fuel expense, depreciation, state sales tax, and introductory expenses. The federal income tax rate is 48 percent. Since these projects generate no revenue, income taxes appear as credits to the project, implying that sufficient corporate tax liability exist to allow taking such a credit.

#### 4.1.3 Investment Tax Credit

The investment tax credit is applied to all capitalizable expense during construction. Only land is exempt from the investment tax credit in this study. The investment tax credit rate is 10 percent.

#### 4.1.4 State Tax (Ad Valorem) Rate

The state ad valorem tax is computed as the state rate times the total capital investment and remains a fixed annual expense not subject to escalation for the life of the project operation. The ad valorem tax rate is 1.3 percent.

#### 4.1.5 State Sales Tax Rate

The state sales tax rate is applied to an estimate of taxable capital expenditure during construction only. During operating years state sales tax is included in all expense estimates. State tax is estimated during construction as follows:





#### 4.1.5 State Sales Tax Rate - (Continued)

State sales tax = Sales tax rate X (0.7 X capital expenditure)  
(Nuclear Plants)

State sales tax = Sales tax rate X (0.5 X capital expenditure)  
(Coal Plants)

The sales tax is not applied to land expense. The sales tax rate is 4 percent.

#### 4.1.6 Insurance Rate

The insurance rate is applied to the total capital investment and remains a fixed annual expense not subject to escalation for the life of the project operation. The insurance rate is 0.1 percent.

#### 4.1.7 Construction Labor

The construction labor hourly rate is \$12.20, which includes labor, insurance, taxes, construction equipment, small tools and expendables, contractors home office and field overhead, and profit.

#### 4.1.8 Operations Labor

The operating staff labor hourly rate is \$12.40 which includes the base labor rate plus overhead burdens. Table 4-9 presents a breakdown of the operating staff requirements for the nuclear plants. Table 4-12 presents this breakdown for coal plants.

#### 4.1.9 Plant Availability

Plant availability is defined as the decimal percent of a year which the study plant is available for operation at any load within its design capability. The plant availability is 0.8 for nuclear study plants and 0.92 for coal study plants.

#### 4.1.10 Plant Factor

Plant factor is defined as the annual energy produced by the plant (reactor or coal plant) divided by the maximum possible energy that could be produced annually by continuous, full load operation.

#### 4.1.11 Backup Operation

Backup operating expense is assumed to be the No. 6 fuel oil equivalent of the amount of backup steam flow supplied annually by Du Pont from existing facilities as a result of study plant unavailability, lack of capacity or differences in operating life. The nuclear cases, in which the construction period is three years longer than that for the



#### 4.1.11 Backup Operation - (Continued)

coal cases, are debited with backup operating expenses in the amount of the No. 6 fuel oil equivalent of the Du Pont steam requirement during the last three years of construction for the cases in which coal plants start construction concurrently with nuclear plants. No components of fixed charges or depreciation on existing facilities are included in the backup charge. In addition to backup charges for the number 6 fuel oil equivalent of steam, there is a utility electrical power backup charge of \$3.26/KW/month assessed to those plants which generate in excess of 15 MW gross electrical power. The charge is applied to study plant gross power generation in excess of 15MW. For coal cases 5 and 6, the electrical power backup charge is calculated for 0.8 times gross power generation less 15 MW since the fraction of time at higher power output is low. Table 4-10 summarizes backup expenses for both number 6 fuel oil and for electrical power. These backup expenses are charged to the study plant net of taxes.

#### 4.1.12 Electrical Power Expense or Credit

Credit for power generation or expense for auxiliary power generation is computed on the basis of 29.6 mills/kwhr on January 1, 1978. The value of electrical power is assumed to escalate at the operations composite rate.

#### 4.1.13 Working Capital

A working capital account is established in the cash flow analysis as an entry in the year prior to commercial operation. The only entries during the operating years for working capital are those increases necessary to maintain the capital account in current dollars. The working capital is computed as follows:

##### Nuclear Plants

Working Capital =  $0.06 \times (\text{Annual operating expense} + \text{fixed charges})$   
+  $0.25 \times \text{total annual fuel expense}$

##### Coal Plants

Working Capital =  $0.06 \times (\text{Annual operating expense} + \text{fixed charges})$   
+ 30 days limestone + 60 days coal inventory

#### 4.1.14 Introductory Expense

The introductory expense includes an estimate of miscellaneous startup expenses such as setting up offices, obtaining startup personnel, and purchasing miscellaneous supplies. The introductory expense column of the cash flow analysis also includes state sales tax during construction.



#### 4.1.15 Depreciation

Qualifying capitalizable expenditures are depreciated over 23 years of operation with the first three years depreciated double-declining balance and the remaining 20 years by the sum-of-year-digits method.

#### 4.1.16 Cash Flow Pro Forma Statement

Figure 4-1 is a sample cash flow summary. In this section, each column is defined.

##### 4.1.16.1 Column (1) - Capital Expense

Capital expense cash flow is developed from the total capital investment and an estimated schedule of expenditure. The base year estimate is apportioned to the appropriate year and escalated via the construction composite rate (4.1.1.4). The land expense is returned in year 30 at its escalated value.

##### 4.1.16.2 Column (2) - Backup Operating Expense

The base year backup operating expense (4.1.10) is escalated according to the number 6 fuel oil escalation rate (4.1.1.8) and entered in each year of operation at its current dollar value, net of taxes (i.e., 52 percent of the escalated backup operating charge is entered).

##### 4.1.16.3 Column (3) - Net Change in Working Capital

The base year working capital estimate (4.1.12) is escalated according to the general inflation rate (4.1.1.1) and entered in the year prior to commercial operation. The net change in working capital thereafter is only the escalation to maintain constant value in current dollars. Total working capital is returned in the last year of operation.

##### 4.1.16.4 Column (4) - Investment Cash Flow

Investment cash flow is the sum of columns (1), (2) and (3).

##### 4.1.16.5 Column (5) - Fuel Expense

The sum of primary fuel (coal or nuclear) and secondary fuel (number 6 fuel for the oil fired superheater where applicable in nuclear plants) expenses is entered in this column after having been escalated according to the (primary) fuel escalation rate (4.1.1.7) and the number 6 fuel oil escalation rate (4.1.1.8), respectively. For coal plants the base year fuel expense estimate is escalated and entered. For nuclear cases, discrete nuclear cash expenditures (Table 4-2) are escalated and entered.

#### 4.1.16.6 Column (6) - Operating Expense

Operating expense includes all annual expenses incurred during the operating life of the project. Power expenses (or credits where applicable) are included as are fixed charges (ad valorem taxes and insurance). The non-fixed portions of the operating expense are escalated according to the operations composite escalation rate (4.1.1.6).

#### 4.1.16.7 Column (7) - Total Annual Expense

Column (7) is the sum of fuel expenses, column (5), and operating expense, column (6).

#### 4.1.16.8 Column (8) - Depreciation

Qualifying capital expenses incurred during construction are depreciated per 4.1.14 and the resulting depreciation entered in column (8).

#### 4.1.16.9 Column (9) - Introductory Expense

The introductory expense as defined in 4.1.13 is escalated from its base year value to the year prior to operation and entered in column (9). Also entered in column (9) are state sales tax estimates computed as described in 4.1.5. Thus, the year prior to operation is entered as the sum of the escalated introductory expense plus the sales tax for that year.

#### 4.1.16.10 Column (10) - Adjusted Operating Expense

This column is the sum of columns (5), (6), (8) and (9) (expenses subject to tax (credit) less depreciation). Income tax (credit) is computed from this column.

#### 4.1.16.11 Column (11) - Federal Income Tax

Column (11) is computed as column (10) times the federal income tax rate. The federal income tax is taken to be credit if column (10) shows a cash outflow (negative cash flow).

#### 4.1.16.12 Column (12) - Net Operating Expense

Column (12) is adjusted operating expense, column (10), less federal income tax, column (11) (or increased by federal income tax when the tax is a credit).



#### 4.1.16.13 Column (13) - Investment Tax Credit

All of the capital expenditures of column (1) qualify for the investment tax credit except the land expense. Column (13) reflects this credit.

#### 4.1.16.14 Column (14) - Total Cash Flow

Column (14) is the sum of net operating expense, column (12); investment tax credit, column (13); and depreciation, column (8). The resultant column (14) is total expense charged to operations reduced by federal tax (credits).

#### 4.1.16.15 Column (15) - Net Cash Flow

Column (15) is the sum of investment cash flow, column (4), and total cash flow, column (14). Net cash flow is the actual cash flow, in current dollars, that can be anticipated for the investment under consideration.

#### 4.1.16.16 Column (16) - Discounted Cash Flow

Each year's net cash flow, column (15), is discounted to January 1, 1978, to form column (16). For this study, discount rates of 10, 15 and 20 percent were assumed.

#### 4.1.16.17 Net Present Value

The sum of the discounted net cash flow values from column (16) is the net present value of the investment. The various study plants are evaluated on the basis of maximum net present value (minimum negative present value).

#### 4.1.17 Steam Costs

The present value steam costs for each of the study cases has been calculated for discount rates of 10, 15, and 20%. These costs, when escalated at the effective project composite escalation rate, multiplied by Du Pont's total annual Btu requirement then discounted and summed, will yield a present value that is equal to the project NPV at the same discount rate. Expressed mathematically, the steam costs are determined as follows:

4.1.17 Steam Costs - (Continued)

$$PVSC = \frac{NPV}{@DR}$$

$$SBTU \times \sum_{I=NC+1}^N \left[ \frac{(1 + RSE/100)^I}{(1 + DR/100)^I} \right]$$

- Where:
- N = Total project life, years
  - NC = Number of years of construction
  - I = Year index
  - SBTU = Annual steam generation,  $10^6$ Btu.
  - RSE = Rate of steam cost escalation, percent
  - DR = Discount rate, percent
  - NPV = Study plant net present value at DR,  $10^6$ \$
  - PVSC = Present value steam cost,  $\$/10^6$ Btu

For all nuclear cases, total project life (N) is 30 years and construction time (NC) is seven years, implying an operating life of 23 years for the nuclear cases. For coal cases in which construction begins concurrently with nuclear plants and operation begins three years prior to nuclear plant operation, the nuclear cases are charged for steam (number 6 fuel oil cost equivalent) during the last three years of construction. In order to make a consistent comparison of steam costs between nuclear and coal plants, the total heat generated as steam must be the same. Therefore, for comparison of steam costs in the cases just described, the last three years of construction for the nuclear plants are considered as operating years by virtue of the fuel oil charge which equalizes the Btu generation with that of the coal plants. Thus the steam costs are calculated for both nuclear and coal plants on the basis of a total life (N) of 30 years and construction period (NC) of four years, or an operating life (N-NC) of 26 years. This applies only to the calculation of steam costs in the case of concurrent nuclear/coal start construction dates. For the cases of concurrent nuclear/coal operation start dates, both types of plants are considered to have a 30 year life and seven years of construction (thus 23 years of operation) for the purposes of steam cost calculations.



## 4.2 Capital Estimates

### 4.2.1 Nuclear Plants

Total nuclear plant Nth-of-A-Kind (NOAK) capital costs have been estimated by B&W, UE&C, and PSE. The scope of responsibility for the estimates is shown in Table 4-3. Capital estimates appear in Table 4-4. Many of these costs are based on previous estimates which were revised to reflect the particular situation for the Du Pont site.

The estimates are based on a 40-hour work week and no allowance has been made for construction premium time. Capital cost estimates do not include owner's G&A costs such as license fees, printing of safety analysis reports, attendance of personnel at hearings, preparation of testimony, legal fees, construction and operation of an information center at plant site, talks by company management and staff members before civic groups, and the G&A overhead assignable to the project.

In general, NOAK costs are lower than First-of-A-Kind (FOAK) costs due to elimination of nonrepetitive first-time engineering and due to labor learning experience. B&W NOAK equipment costs are lower due to a B&W shop labor learning curve and the elimination of first-time engineering. These improvement factors are based on past B&W experience with central station plant engineering and equipment.

A reduction in UE&C equipment scope costs results from field labor learning where there is a carryover of supervisor personnel from one project to another and from nonrepetitive engineering efforts such as preparation of construction procedures, etc.

#### First-Of-A-Kind Cost Estimates

The nuclear plant costs and the overall economic comparison are based on NOAK costs and thus include no FOAK expenses. For this study it has been assumed that the FOAK costs would be borne by others; possibly EPRI, the U.S. Government, or other organization if deployment of small industrial reactors becomes a national objective.

First-of-a-Kind (FOAK) work is defined as follows:

Those work activities which are nonrepetitive for follow-on units, including nonrepetitive elements of engineering, licensing, and test and evaluation efforts required to develop design parameters, demonstrate safety to the regulatory authorities, and verify design adequacy.

Generic activities as defined above include fabrication processes, baseline component and system design, resolution of generic licensing issues, and first-of-kind engineering proof test and evaluation programs. The detailed engineering and construction tasks for the first unit include, but are not limited to, the following FOAK tasks:



#### 4.2.1 Nuclear Plants - (Continued)

##### Engineering

1. Development of reactor plant baseline design (component and system specifications and drawings).
2. Design and stress analyses required to satisfy regulatory agencies.
3. Development of reactor plant checkout, startup, and operating procedures.
4. Support of test and evaluation programs.
5. Architectural and construction design.
6. Development of balance-of-plant system and equipment designs.
7. Development of balance-of-plant checkout, startup, and operating procedures.

##### Fabrication and Construction

1. Manufacturing development for welding procedures, special fixtures, and ASME Code cases.
2. Development of special fabrication processes for shop and field construction.
3. Preparation of detailed shop processing and construction schedules.

##### Licensing

1. Resolution of generic issues related to the class of reactors.
2. Determination of necessary supportive environmental monitoring programs.
3. Preparation of generic parts of preliminary and final safety analysis reports.

##### Inservice and Initial Operational Tests and Inspections

1. Baseline techniques for code in-service inspection.
2. Flow-induced vibration evaluation of reactor internals.
3. Hot functional test programs (field).





#### 4.2.1 Nuclear Plants - (Continued)

##### Hardware

1. Design and manufacture of special tools and handling equipment for major components.
2. Design and construction of fueling and refueling equipment and special tools.

In addition to the FOAK work items discussed above, certain test and evaluation programs are required to verify design adequacy or to demonstrate the margin of conservatism of the design. The test and evaluation programs also support the licensing process.

##### Test and Evaluation

1. Steam generator functional performance, secondary side flow distribution, and downcomer performance.
2. Steam generator fouling and chemical cleaning.
3. Upper internals vibration.
4. Control rod guide structure.
5. Fuel assembly prototype detail design and fabrication.
6. Fuel assembly life test.
7. Primary pump prototype.
8. Pressure suppression containment.
9. Reactor coolant temperature sensor.
10. Containment pressure suppression tests (not included as part of the cost estimate provided herein).

The total plant FOAK costs are estimated to be approximately \$25 million to \$50 million, including all FOAK costs in the area of engineering, shop and field construction, licensing, in-service and initial operational tests and inspections and hardware design and manufacture. This total plant FOAK estimate assumes all first-of-kind costs are applied to a single program and concept. In reality, many are common to three programs involving integral nuclear steam systems of similar or identical design: The PE-CNSG, the Maritime M-CNSG, and the higher power level CNSS concept. All three program studies and design activities have been supported at least in part by federal agency funding. A construction project involving any one of these programs would give impetus to the others, so some sharing of these first-of-a-kind costs over a period of six to eight years between programs can be considered. In this respect, first-of-a-kind government support of these programs should be especially cost-



#### 4.2.1 Nuclear Plants - (Continued)

effective. If FOAK costs could be shared between programs, the above estimated range of FOAK costs for a given program such as PE-CNSG could be reduced correspondingly.

The FOAK cost estimates discussed above are not based on an extensive investigation in this study but rather are based on work previously done in the Phase I study and in M-CNSG program activities. If an industrial process energy user should decide to proceed further with this study, the balance-of-plant FOAK costs should be determined in more detail.

The previous estimates do not include consideration of government legislation to provide nuclear accident liability insurance similar to Price-Anderson legislation. This may be required to cover industrial organizations as an incentive to establish nuclear plants for initial industrial installations. The estimates also exclude the cost of longer first-time construction schedules and resultant cost increases for pioneer plants.

#### 4.2.2 Coal Plants

Total coal plant costs have been estimated by PSE. Capital estimates are presented in Table 4-5. The estimates represent costs for the complete coal plant including all coal handling systems, scrubbing systems (where required), ash and sludge handling systems, and auxiliaries required under the scope of this study.

Specifications were written for major equipment items and submitted to vendors who returned budget quotations. The items estimated in this manner are as follows:

- Steam Generator (Boiler)
- Flue Gas Desulfurization System
- Electrostatic Precipitator System
- Coal Stacker/Reclaimer System
- Rail Car Roller/Positioner System
- Ash Handling System
- Turbine-Generator

The costs of auxiliary systems not obtained through quotation were estimated by PSE as were engineering and installation not provided by Du Pont including site preparation.

The estimates are based on a 40-hour work week and no allowance has been made for construction premium time. The capital estimates do not include Du Pont G&A costs, license fees, environmental impact study costs or other incidental expenses that would be assignable to internal Du Pont overhead.



## 4.3 Fuel Economics

### 4.3.1 Nuclear Fuel

The nuclear fuel costs used in this study are based on a typical nuclear fuel "cycle" such as that depicted in Figure 4-2. The cycle includes all of the major processes that occur from the mining of the uranium ore to the final disposal of the fuel. The criteria for determining the cost of each process are listed in Table 4-6. These criteria were supplied by Oak Ridge National Laboratory and represent 1985 costs in terms of January 1, 1978 dollars.

Fuel cycle costs were generated as discrete cash flows for input to the economic analysis computer program. These cash flows are given in Table 4-2. Nuclear fuel cycle costs were assumed to escalate at a rate of 6 percent per year.

Each process in the fuel cycle is briefly described below including its contribution to the total fuel cycle cost. The total fuel cycle cost for this study ranges from 49 to 53¢/10<sup>6</sup>Btu for the reprocessing fuel cycle to 60 to 66¢/10<sup>6</sup>Btu for the non-reprocessing fuel cycle.

- U<sub>3</sub>O<sub>8</sub> - The uranium ore is found, mined, and milled to produce U<sub>3</sub>O<sub>8</sub> yellowcake. This is about 46 to 51% of the total fuel cycle cost, depending on the exact cycle..
- Conversion - The yellowcake (U<sub>3</sub>O<sub>8</sub>) is converted to a gas, UF<sub>6</sub>. This is approximately 1% of the total fuel cycle cost.
- Enrichment - The UF<sub>6</sub> is currently fed into the U. S. Government gaseous diffusion enrichment facilities. (Consideration is being given to the construction of privately owned enriching facilities.) Here, the ratio (enrichment) of U-235 to U-238 atoms is increased from that naturally occurring (0.00711) to between 0.02 and 0.04. The customer is charged for the number of separative work units (SWUs) used. The number of SWUs is proportional to the total amount of enriched uranium obtained and also to the final uranium enrichment. This part of the fuel cycle typically is about 28 to 33% of the total fuel cycle cost.
- Conversion & Fabrication - The enriched UF<sub>6</sub> is then converted to powdered UO<sub>2</sub>. The powdered UO<sub>2</sub> is formed into pellets and loaded into fuel rods, which are then arranged into fuel assemblies. This process is about 13 to 21% of the total fuel cycle cost.



#### 4.3.1 Nuclear Fuel - (Continued)

Spent Fuel - After the fuel assemblies are "burned" in the reactor  
Shipping & to produce energy, they are unloaded from the reactor  
Disposal and are allowed to cool for several months before  
shipping. The fuel is now either reprocessed or permanently stored without reprocessing. In reprocessing, the fuel rods are disassembled, the fuel pellets are dissolved, and the remaining uranium and valuable isotopes are recovered, while the rest is disposed of in a radioactive waste storage facility. The recovery of the uranium and valuable isotopes is a credit which helps reduce the overall fuel cycle costs. These credits have been taken in the  $U_3O_8$  and enrichment cost elements. The reprocessing and shipping costs are approximately 17% of the total fuel cycle costs. This is nearly offset by the plutonium credit, which has been specified by the ORNL criteria (Table 4-6). Permanent storage of the fuel assemblies in the nonreprocessing case is about 7% of the total fuel cycle cost.

#### 4.3.2 Coal

In this study, it is assumed that for a project of this size the industrial user would purchase coal under long term contract from a mine in lieu of purchasing reserves or participating in a mining operation. It is also assumed that the user would contract for unit-train delivery of the coal from the mine to the plant site. The estimated delivered cost of high-sulfur Illinois coal (10,900 Btu/lb) and low-sulfur Wyoming coal (8250 Btu/lb) are presented in Table 4-7. On the basis of a 100-car, 10,000 ton capacity unit train and 1575 tons per day of Illinois coal, one unit train every six days will be required. For Wyoming coal at 2080 tons per day, one unit train every five days will be required.

High-sulfur coal from Illinois was assumed, although the range of delivered prices would include high-sulfur coal delivered from anywhere within the same approximate radius of Victoria. There have been no long-term contracts for Illinois coal disclosed as yet for plants in Texas, and this fact makes it difficult to estimate accurately the delivered price of high-sulfur coal.

Conversely, there is experience with Wyoming low-sulfur coal in Texas, and the  $\$1.35/10^6$ Btu price falls within the range for which contracts are being made. In order that high-sulfur coal remain competitive, it is reasonable to assume that its delivered price will remain no greater than, and generally less than that of low-sulfur coals. The user's actual contract negotiations will finally determine either high- or low-sulfur coal prices, but it is believed that the  $\$1.20/10^6$ Btu (high-sulfur) and  $\$1.35/10^6$ Btu (low-sulfur) price estimates are feasible.



#### 4.3.2 Coal - (Continued)

As is the case with current delivered coal prices, future price determinations are quite difficult to project accurately. It has been assumed that the price of coal will escalate at a rate of 6 percent, a rate slightly higher than the general inflation rate. As discussed in Section 4.6.3, the effects of different escalation rates for coal and nuclear fuels have been determined and are seen to be quite significant, with the nuclear cycle be less sensitive.

Barge transportation of coal has not been considered in this study. Savings in transportation costs could be realized through the use of barge transportation over part or all of the route from the mine to the site. Should coal come into widespread use in Texas and other locations potentially serviceable by barge, river traffic will increase significantly and could ultimately become saturated. While rail transportation facilities are expected to also undergo periods of shortages, ultimately the rail capacity can be increased to accommodate the demand. Disregarding these limitations, the exclusive use of rail transportation for this study has introduced a degree of conservatism into the results which are affected by fuel price.

#### 4.3.3 Number 6 Fuel Oil

Number 6 fuel oil is used for superheating nuclear-generated steam in a fired superheater for nuclear cases 1, 2 and 5. It is also used as fuel for operating backup (existing) steam generation facilities for all coal and nuclear study plants. The base price for number 6 fuel oil has been taken as \$2.60/10<sup>6</sup>Btu for the purpose of this study. The escalation of fuel oil price is assumed to be at a rate of 6 percent per year.

### 4.4 Operating Economics

#### 4.4.1 Operating Load and Backup Expense

The operating load is determined from the specified steam demand schedule supplied by Du Pont. The levelized annual steam demand is calculated as follows:

<u>REQUIRED STEAM FLOW LB/HR</u>	<u>PERCENT OF TIME REQUIRED</u>	<u>WEIGHTED STEAM FLOW LB/HR</u>
600,000	20	120,000
700,000	49	343,000
810,000	23	186,000
900,000	6	54,000
1,000,000	2	20,000

LEVELIZED ANNUAL STEAM FLOW : 723,000 LB/HR

#### 4.4.1 Operating Load and Backup Expense - (Continued)

Thus, to meet the process steam flow requirement, study plants are required to provide process steam at a levelized rate of 723,000 lb/hr, with the capability of meeting the schedule outlined above. In computing the annual operating expenses, each study plant was operated so as to satisfy the levelized steam flow requirement, subject to its plant availability. To obtain steam-load-related annual expense (fuel, backup operation, power credit or expense, etc.) the expenses first were determined for level annual operation at 723,000 lb/hr steam load and then adjusted by the appropriate plant availability. In so doing, constant operating efficiencies and linear operating characteristics are implied.

Backup operating expense is calculated as follows:

$$\begin{aligned} \text{Levelized Backup Steam Requirement} &= 723,000 \text{ lb/hr} \times (1 - \text{Availability}) \\ \text{Annual Backup Btu Requirement} &= \text{Levelized Backup Steam} \\ &\quad \text{Requirement} \times 8760 \text{ Hr/Yr} \times \\ &\quad \text{Btu/Lb. Steam} \\ \text{Annual Backup Operating Expense} &= \text{Annual Backup Steam Requirement} \\ &\quad \times \$ \text{ cost of No. 6 Fuel Oil/}10^6\text{Btu} \\ &\quad \div \text{Boiler efficiency (86\%)} \end{aligned}$$

For nuclear cases 1 and 3, where the design capacity is only 810,000 lb/hr steam flow, an additional penalty for backup operating expense has been included.

For concurrent nuclear/coal construction start date cases, in which the nuclear plants require three years longer to construct than do the coal plants, the lifetime steam output of these nuclear cases is forced to be equal to that of the coal cases through a backup charge in years 5, 6 and 7 during nuclear construction. These backup charges are the No.6 fuel oil equivalent of Du Pont's steam requirement during each of those three years. See section 4.1.10 for a complete description of backup operating expenses.

#### 4.4.2 Plant Availability

##### 4.4.2.1 Nuclear Plants

The cumulative availability of Babcock & Wilcox's seven large operating nuclear steam systems (NSS) through June 30, 1977, ranges from 0.61 for the lowest to 0.92 for the highest, with a mean of 0.74 over the entire period of their commercial operation. Note that this refers only to nuclear system availability as opposed to plant availability. Ongoing work by B&W's Nuclear Power Generation Division to improve product reliability and thus minimize maintenance downtime has enabled B&W nuclear units to achieve this excellent availability record to date, and the data trend has been towards more reliable operation as operations continue.



#### 4.4.2.1 Nuclear Plants - (Continued)

Through an extensive study of nuclear plant reliability, B&W has identified the nuclear system components that have contributed most highly to plant outages (low reliability). Such equipment as reactor coolant pump seals, control rod drives, pressurizer spray valves, and surveillance specimen holder tubes have contributed significantly to the NSS unavailability. Programs have been implemented within B&W that have either corrected the problem or that have identified potential corrections. This ongoing product reliability improvement program has as its objective an increase in total plant availability.

The equipment improvement program for the large B&W NSS plants has direct impact on increasing the PE-CNSG availability by feeding forward pertinent design improvement during the design stages of the PE-CNSG. Some design improvement modifications on NSS plant equipment, such as control rod drives, have direct application to the PS-CNSG, as these drives (in shortened form) are used on the PE-CNSG. Some NSS equipment problems, such as seals on primary coolant pumps, do not apply to the PE-CNSG, as it uses glandless wet stator machines with no mechanical seals between the pump and motor.

Considering the current availability of B&W operating NSS's and the potential improvements which should occur by the time of PE-CNSG operation, a plant availability of 0.80 was chosen for the PE-CNSG nuclear fuel cycle studies. A 12-month refueling period was chosen. Availability is defined in section 4.1.9. Plant factor is defined in section 4.1.10. For nuclear cases 4 and 5, a reactor plant factor of 0.80 was assumed. To achieve this plant factor, the NSS availability must of course be greater than 0.80. Since most process plants operate near rated load most of the time, the availability required to achieve a 0.80 plant factor would probably have to be only slightly above 0.80. This is considered to be achievable, as previously discussed.

At 0.80 plant availability the system is available for design-condition operation 292 days per year and unavailable 73 days per year due to annual maintenance, refueling, or unscheduled outages.

#### 4.4.2.2 Coal Plants

Industrial coal plants, with their around-the-clock maintenance attention, are capable of achieving quite high plant availability factors. For this study, a plant availability of 0.92 has been selected. Translated, this factor means that the coal plant will be available to deliver design steam flow or operate at any load 92% of the time, or 336 days per year. The remaining 29 days per year the coal plant will be unavailable either because of scheduled maintenance or because of unanticipated operating difficulties.



#### 4.4.3 Annual Operating Expense

##### 4.4.3.1 Nuclear Plants

Nuclear plant annual operating costs (less fuel) have been estimated by ORNL and PSE and are reported in Table 4-8. Staff requirements for plant operations are tabulated in Table 4-9. Costs for operating the superheater and turbine - generator are reflected in additional staff for the nuclear cases which utilize an oil-fired superheater and/or have electrical generation capability.

Fuel costs for nuclear cases 1, 2 and 5 include the cost of number 6 fuel oil for a fired process steam superheater. For cases 3 and 4 which have no superheater, only the nuclear fuel component applies.

Because of the batch method of fueling the nuclear reactor, nuclear fuel costs are reported as discrete cash flow expenses for each year from first fueling through the life of the project. These nuclear fuel cash flow expenses are summarized in Table 4-2 for each fuel cycle considered in these analyses. The fuel expenses are net expenses and include the cost of new fuel and credits for spent fuel where such credits apply (reprocessing cycles). For nonreprocessing cycles, the spent fuel is "thrown away" and no salvage value is assigned. Costs for spent fuel storage are included.

For plants including the number 6 fuel-oil fired superheater, the number 6 fuel oil expense is added to the nuclear cash flow in each year of operation (after escalation of both fuel oil and nuclear fuel expenses). Number 6 fuel oil expenses are summarized in Table 4-10, including the cost of oil required for superheating and for backup operation. (Backup operation is not considered as an annual operating expense per se. See Section 4.1 for the treatment of all cash flow components.)

##### 4.4.3.2 Coal Plants

Coal plant annual operating cost estimates are reported in Table 4-11. Staff requirements for plant operation are tabulated in Table 4-12. Adjustments in staff have been made according to requirements of plant configuration.

Limestone for SO<sub>x</sub> scrubbing is estimated at \$7.00 per ton. Sludge and/or ash disposal has been estimated to cost \$0.05/10<sup>6</sup>Btu of high-sulfur coal fired and \$0.035/10<sup>6</sup>Btu of low sulfur coal fired.

#### 4.5 Comparative Economics

The net present value (NPV) and present value steam costs of the five nuclear plants and eight coal plants were determined for discount rates of 10, 15, and 20 percent as outlined in 4.1. Figures 4-3 through 4-27 summarize the results. The assumption for coal plant construction start date is noted on the curves.





#### 4.5 Comparative Economics - (Continued)

Economic results by plant type (coal, nuclear) are discussed in the following section, followed by a discussion of the results of the coal vs. nuclear economic comparisons.

##### 4.5.1 Nuclear Plants

###### 4.5.1.1 Plants Satisfying Process Steam Temperature Requirements

Nuclear plant cases 1, 2, and 5 satisfy the required steam conditions of 750 F and 550 psig delivered to process. Case 1 is designed to deliver a maximum of 810,000 lb/hr of steam to process, while cases 2 and 5 are designed deliver the specified 1,000,000 lb/hr peak steam flow demand. For economic evaluation, the nuclear plant for case 1 is assumed to be supplemented by a number 6 oil-fired peaking unit in order that the total process steam output from Case 1 is identical to that for Cases 2 and 5. The supplemental steam is charged at the fuel oil equivalent value of the Case 1 steam deficit, net of taxes. (Table 4-10). Case 5 is designed with condensing cycle electrical power generation capability via a turbine-generator inserted into the secondary steam loop which generates a net 26.1 MW power for use by Du Pont. Each of these three plants has been analyzed for operation per Section 4.1. The results of the economic analysis are presented in Figures 4-3 through 4-6.

Case 5 has the highest NPV (the lowest negative NPV) for discount rates under 20 percent and is the economic choice for that range of discount rates. The results for case 5 show that the addition of electrical generating capacity reduces the cost of process steam relative to the steam-only case 2.

It is evident by comparing cases 1 and 2 that the capital savings realized from the reduced steam capacity and consequently lower superheating cost in case 1 is offset by the increased backup operating expense required. The relative attractiveness of cases 1, 2, and 5 was not influenced by changes in the coal-fired plant schedule (Figures 4-3 and 4-4 versus Figures 4-5 and 4-6) or by associated changes in oil requirements. It can be concluded that the 1,000,000 lb/hr steam capacity chosen for the case 5 design is appropriate and is the proper economic choice for discount rates under 20 percent.

###### 4.5.1.2 Benchmark Plants (Saturated Steam)

Cases 3 and 4 were designed with no facilities for superheating the steam. Case 3 is identical to case 1 with the single exception of steam superheat capability and thus provides a benchmark determination of the economic effect of the superheat capability for an average steam flow rate of 723,000 lb/hr. Figures 4-7 through 4-10 present the results of the economic study of the effect of superheating. In each case the addition of superheat is seen to decrease NPV approximately \$20,000,000 at a discount rate of 10 percent and approximately \$5,500,000 at 20 percent. Steam costs are increased 6 to 12 percent by the addition of oil-fired superheating.

#### 4.5.1.2 Benchmark Plants (Saturated Steam) - (Continued)

In order to gain an appreciation of the penalty incurred by operating a saturated-steam only PE-CNSG at less than its design capability, a further hypothetical comparison was developed. For this comparison, case 4, it was assumed that Du Pont has a constant annual saturated steam demand of: (a) 723,000 lb/hr and (b) 1,288,000 lb/hr.

Assuming that only the steam demand varied while other assumptions remained the same, present value steam costs were determined for both 1,288,000 and 723,000 lb/hr steam flows. The results of this comparison are presented in Figure 4-11. The unit cost for saturated steam is seen to be reduced approximately 20% as a result of using the PE-CNSG at its full capacity.

#### 4.5.2 Coal Plants

Each of the coal plant designs satisfies Du Pont's process steam requirements, including flow, pressure, and temperature. Cases 1, 3, 5, and 7 are high sulfur-coal-fired plants with flue gas sulfur scrubbing; cases 2, 4, 6, and 8 are low-sulfur-coal-fired plants without scrubbing facilities. See Section 3.0 for technical descriptions of these plants. Cases 1 and 2 provide steam only and include no electrical power generation capability. The remaining plant designs include various schemes for power generation by means of backpressure, condensing, or a combination extraction-condensing turbine generator.

Figures 4-12 through 4-15 present the results of the economic evaluation of the high-sulfur-coal-fired plants. Among these plant concepts, the case 7 coal plant is the economic choice over the range of discount rates studied.

Figures 4-16 through 4-19 present the results of the economic evaluation of the low-sulfur coal-fired plants. The Case 6 plant is seen to be the economic choice in Figures 4-16 and 4-17, while the case 6 and case 8 plants are economically equivalent in Figures 4-18 and 4-19. Deferring the start of coal-fired plant construction from 1978 to 1981 does not alter the relative economic attractiveness of the various plant concepts studied.

The optimum high- and low-sulfur coal-fired plants are compared in Figures 4-20 through 4-23. Were low-sulfur coal firing without flue gas scrubbing to be allowed, the low-sulfur plants would be the economic choice. However, it is a virtual certainty that all new coal fired plants will be required to scrub flue gas. The addition of flue gas scrubbing to the low-sulfur plants would decrease their NPV below that of the high-sulfur plant, case 7. Therefore the case 7 high-sulfur coal fired plant is the economic choice for comparison with case 5 nuclear plant.



#### 4.5.3 Economic Comparison of Optimum Coal and Nuclear Plants

The case 5 nuclear plant and case 7 coal plant are compared in Figures 4-24 through 4-27. At the present time, there is no nuclear fuel reprocessing allowed in the United States. However, the possibility that fuel reprocessing may become feasible in the future cannot be ruled out entirely. The results of the Case 5 nuclear plant economics are presented assuming both reprocessing and non-reprocessing fuel cycles. Because of the low sensitivity of nuclear plant economics to fuel costs, the impact of non-reprocessing is quite small. The non-reprocessing fuel cycle increases the fuel cost over that of the reprocessing fuel cycle by approximately 10 percent. The case 7 high-sulfur coal-fired plant is presented assuming coal prices of \$1.20, \$1.40, and \$1.60/  $10^6$  Btu. At a discount rate of 15 percent, the coal plant is the economic equivalent of the nuclear plant (Base case) at a coal price between \$2.00 and \$2.20/ $10^6$  Btu for the concurrent nuclear/coal construction start date assumption (Figure 4-24 and 4-25) and between \$2.40 and \$2.50/ $10^6$  Btu for the concurrent nuclear/coal operation start date assumption (Figures 4-26 and 4-27). To illustrate the effect of plant availability, the NPV of the coal plant firing \$1.20/ $10^6$  Btu coal is shown for an availability of 0.85.

Refer to Section 4.1.17 and note that the present value steam cost is a function of net present value, annual steam Btu production and a discount factor (same value for all coal and nuclear cases for the same discount rate and escalation rate). In the case of concurrent construction, implying 26 years of operation, this discount factor is calculated over the range 5 to 30 years. For the concurrent operation assumption, implying 23 years of operation, the discount factor is calculated over the range 8 to 30 years, thus lowering the factor and tending to increase the present value steam cost.

The higher present value steam cost for the nuclear case as shown in Figure 4-27 is the result of the discount factor decreasing at a rate faster than that of the improvement of nuclear plant net present value. The approximately equal coal present value steam cost in both Figures 4-24 and 4-27 is the result of the coal plant net present value and the discount factor decreasing at the same rate.

#### 4.6. NPV Sensitivity to Variations in Economic Parameters

Seven economic variables have significant impact on the NPV of the investments being considered in this study:

- .. Capital Investment
- .. Primary Fuel Cost (Coal, Nuclear Fuel)
- .. Primary Fuel Cost Escalation
- .. Secondary Fuel (Number 6 Fuel Oil)
- .. Operating Cost (Less Fuel)
- .. Power Cost/(Credit)
- .. Availability

#### 4.6 NPV Sensitivity To Variations in Economic Parameters-(Continued)

In order to evaluate the sensitivity of NPV to these parameters, coal case 7 and nuclear case 5 were analyzed for a range of variations in the parameters. Both cases are for the concurrent construction start date, January 1, 1978. The results of this sensitivity study are presented in Table 4-13 and discussed in the following section.

##### 4.6.1 NPV Sensitivity to Variation in Capital Investment

Both plants exhibit approximately the same sensitivity to capital investment costs. At low discount rates the nuclear plants are slightly more sensitive due to the capital intensiveness of the nuclear plant.

##### 4.6.2 NPV Sensitivity to Primary Fuel Cost

The annual expense for nuclear fuel is significantly less than for coal. This fact is apparent in the sensitivity of nuclear plant NPV to primary fuel cost variations, which is approximately one-third to one-fourth of the coal plant sensitivity to coal price.

##### 4.6.3 NPV Sensitivity to Variations in Primary Fuel Cost Escalation Rate

As was observed for primary fuel cost, the effect on NPV of varying fuel cost escalation rate is significantly greater for the coal plant. The amplification of sensitivity by a factor of more than four is, once again, related to the relative prices of coal fuel and nuclear fuel.

##### 4.6.4 NPV Sensitivity to Variations in Number 6 Fuel Oil Costs

Because the nuclear plant uses number 6 fuel oil for superheating steam as well as for a backup operating fuel, its NPV is more sensitive to variations in fuel oil cost. Note that the nuclear plants exhibit a higher sensitivity to number 6 fuel oil cost than to the primary nuclear fuel costs.

##### 4.6.5 NPV Sensitivity to Variations in Number 6 Fuel Oil Cost Escalation Rate

For the reason stated in 4.6.4, the nuclear plant is twice as sensitive to fuel oil price escalations as is the coal plant.



#### 4.6 NPV Sensitivity to Variations in Economic Parameters - (Continued)

##### 4.6.6 NPV Sensitivity to Annual Operating Costs (Less Primary Fuel)

The difference in sensitivity to nonprimary fuel operating costs between nuclear and coal plants reflects the higher coal plant base operating cost. The coal plant NPV is approximately twice as sensitive to such variations.

##### 4.6.7 NPV Sensitivity to Power Credit

The case 7 coal plant generates approximately 38% more net electrical power and it is therefore more sensitive to changes in the credit allowed for this power generation.

##### 4.6.8 NPV Sensitivity to Availability

Both nuclear and coal plants exhibit a rather high sensitivity to plant availability, with coal plants being more sensitive than nuclear plants.

##### 4.6.9 Use of Table 4-13

Table 4-13 can be used in conjunction with Figure 4-24 to construct NPVs for coal and nuclear plants not actually analyzed. Variations in the economic parameters should be limited to  $\pm 10$  percent for good accuracy, except that coal price variations of up to  $+50$  percent will yield accurate results. Variations in excess of those stated will be less accurate and should be attempted with caution. For variations in escalation rates,  $+1$  percentage point will yield good accuracy. Variations larger than  $1$  percentage point will yield doubtful accuracy. Availability variations should not exceed  $15$  percent.

This table has been constructed from analyses performed on nuclear case 5 and coal case 7 with concurrent construction start dates, and its use should be limited to these cases.



ECONOMIC ANALYSIS SUMMARY

CASH FLOW SUMMARY

CLIENT - DUPONT (NUCLEAR)  
CASE - 5  
PSE JOB - 4027

FUEL CYCLE 5R  
(TABLE 4-2)

YEAR	(1) CAPITAL EXPENSE	(2) BACKUP OPERATING EXPENSE	(3) NET CHANGE IN WORKING CAPITAL	(4) INVESTMENT CASH FLOW  (1+2+3)	(5) FUEL EXPENSE	(6) OPERATING EXPENSE	(7) TOTAL ANNUAL EXPENSE (5+6)	(8) DEPRECIATION	(9) INTROD. EXPENSE	(10) ADJUSTED OPERATING EXPENSE (7-8+9)
1	-103056	0	0	-103056	0	0	0	0	0	
2	-319573	0	0	-319573	0	0	0	-8628	-8628	
3	-4038043	0	0	-4038043	0	0	0	-109027	-109027	
4	-21010387	0	0	-21010387	0	0	0	-567280	-567280	
5	-60833996	-14872984	0	-75706980	0	0	0	-1642518	-1642518	
6	-85955575	-15765363	0	-101720938	-22936292	0	-22936292	0	-2320801	
7	-28759210	-16711265	-2681787	-48152282	-8270272	0	-8270272	0	-4327752	
8	0	-4465685	-134089	-4599774	-11832797	409856	-11422941	17430786	0	
9	0	-4733626	-140794	-4874420	-12374374	553632	-11820742	16638478	0	
10	0	-5017644	-147833	-5165477	-12957150	706035	-12251115	15846169	0	
11	0	-5318702	-155225	-5473928	-13693373	867582	-12826091	14337010	0	
12	0	-5637824	-162986	-5800811	-14515293	1038822	-13476471	13620160	0	
13	0	-5976094	-171136	-6147230	-15386211	1220336	-14165875	12903309	0	
14	0	-6334660	-179693	-6514352	-16309383	1412741	-14896642	12186459	0	
15	0	-6714739	-188677	-6903416	-17287946	1616691	-15671256	11469608	0	
16	0	-7117624	-198111	-7315735	-18325223	1832877	-16492346	10752758	0	
17	0	-7544681	-208017	-7752697	-19424737	2062035	-17362702	10035907	0	
18	0	-7997362	-218417	-8215779	-20590221	2304941	-18285279	9319057	0	
19	0	-8477203	-229338	-8706542	-21825634	2562423	-19263211	8602206	0	
20	0	-8985836	-240805	-9226641	-23135172	2835353	-20299819	7885356	0	
21	0	-9524986	-252845	-9777831	-24523282	3124659	-21398623	7168505	0	
22	0	-10096485	-265488	-10361973	-25994679	3431324	-22563356	6451655	0	
23	0	-10702274	-278762	-10981036	-27554360	3756388	-23797972	5734804	0	
24	0	-11344411	-292700	-11637111	-29207422	4100956	-25106665	5017954	0	
25	0	-12025075	-307335	-12332410	-30960079	4466198	-26493881	4301103	0	
26	0	-12746580	-322702	-13069282	-32817684	4853355	-27964328	3584253	0	
27	0	-13511374	-338837	-13850212	-34786745	5263741	-29523003	2867402	0	
28	0	-14322057	-355779	-14677836	-36873949	5698751	-31175199	2150552	0	
29	0	-15181380	-373568	-15554948	-39086386	6159861	-32926526	1433701	0	
30	565797	-16092263	7844925	-7681541	-41431570	6648637	-34782932	716851	0	
COL. TOTALS	-200454043	-257218197	0	-457672240	-572100734	66927196	-505173538	200454043	-8976007	-714603589

FIGURE 4-1 - CASH FLOW EXAMPLE

4-25



ECONOMIC ANALYSIS SUMMARY

PAGE 2 OF 2

CASH FLOW SUMMARY

CLIENT - DUPONT (NUCLEAR)  
CASE - 5  
PSE JOB - 4027

FUEL CYCLE 5R  
(TABLE 4-2)

YEAR	(11) FEDERAL INCOME TAX (-TRX10)	(12) NET OPERATING EXPENSE (10+11)	(13) INVESTMENT TAX CREDIT (-ITCX1)	(14) TOTAL CASH FLOW (8+12+13)	(15) NET CASH FLOW (4+14)	(16) DISCOUNTED CASH FLOW DR=15.0
1	-0	0	-0	-0	-103056	-89614
2	4142	-4487	31957	27471	-292103	-220872
3	52333	-56694	403804	347110	-3690933	-2426848
4	272295	-294986	2101039	1806053	-19204334	-10980140
5	788409	-854109	6083400	5229290	-70477690	-35039868
6	12123405	-13133688	8595557	-4538131	-106259069	-45938728
7	6047051	-6550972	2875921	-3675051	-51827333	-19483814
8	13849789	-15003938	0	2426848	-2172926	-710333
9	13660425	-14798794	0	1839684	-3034736	-862661
10	13486697	-14610588	0	1235581	-3929896	-971410
11	13038289	-14124813	0	212199	-5251730	-1130973
12	13006383	-14090248	0	-470088	-6270899	-1172076
13	12993208	-14075976	0	-1172666	-7319896	-1189688
14	12999888	-14083213	0	-1896754	-8411106	-1188730
15	13027615	-14113249	0	-2643641	-9547057	-1173281
16	13077650	-14167454	0	-3414696	-10730431	-1146705
17	13161332	-14247377	0	-4211370	-11964067	-1111772
18	13250081	-14354255	0	-5035198	-13250977	-1070747
19	13325400	-14490017	0	-5887811	-14594353	-1025477
20	13528884	-14654291	0	-6770935	-15997576	-977456
21	13712222	-14854907	0	-7686402	-17464233	-927887
22	13927205	-15087805	0	-8636151	-18998123	-877724
23	14175733	-15357044	0	-9622239	-20603276	-827725
24	14459817	-15664802	0	-10646848	-22283959	-778474
25	14781592	-16013391	0	-11712288	-24044699	-730421
26	15143319	-16405262	0	-12821010	-25890291	-683901
27	15547395	-16843011	0	-13975609	-27825820	-639155
28	15926360	-17329390	0	-15178838	-29856674	-596351
29	16492909	-17867318	0	-16433617	-31988565	-555594
30	17039896	-18459887	0	-17743036	-25424577	-383989
COL. TOTALS	343009722	-371593866	20091678	-151048144	-608720384	

NET PRESENT VALUE ==-134912414

FIGURE 4-1 (Continued)

4-26



ECONOMIC ANALYSIS SUMMARY

CASH FLOW SUMMARY

CLIENT - DUPONT (H.S. COAL)  
CASE - 7  
PSE JOB - 4027

COAL PRICE \$1.20/10<sup>6</sup>Btu

YEAR	(1) CAPITAL EXPENSE	(2) BACKUP OPERATING EXPENSE	(3) NET CHANGE IN WORKING CAPITAL	(4) INVESTMENT CASH FLOW (1+2+3)	(5) FUEL EXPENSE	(6) OPERATING EXPENSE	(7) TOTAL ANNUAL EXPENSE (5+6)	(8) DEPRECIATION	(9) INTROD. EXPENSE	(10) ADJUSTED OPERATING EXPENSE (7-8+9)
1	-3125641	0	0	-3125641	0	0	0	0	-53925	-53925
2	-22511650	0	0	-22511650	0	0	0	0	-450233	-450233
3	-42702098	0	0	-42702098	0	0	0	0	-854042	-854042
4	-19803098	0	-2692208	-22495306	0	0	0	0	-2482102	-2482102
5	0	-2287663	-134610	-2422374	-17860005	5460556	-12399449	7459565	0	-19659015
6	0	-2424923	-141341	-2566264	-18931606	5849334	-13082272	7120494	0	-20202766
7	0	-2570418	-148408	-2718826	-20067502	6261438	-13806064	6781423	0	-20587487
8	0	-2724644	-155828	-2880472	-21271552	6698269	-14573283	6135573	0	-20708556
9	0	-2888122	-163620	-3051742	-22547845	7161309	-15386536	5820794	0	-21215330
10	0	-3061409	-171801	-3233210	-23900716	7652132	-16248584	5522016	0	-21770600
11	0	-3245094	-180391	-3425485	-25334759	8172405	-17162354	5215237	0	-2237392
12	0	-3439800	-189410	-3629210	-26854845	8723893	-18130951	4908459	0	-23039410
13	0	-3646189	-198881	-3845068	-28466135	9308471	-19157664	4601680	0	-23759344
14	0	-3864959	-208825	-4073784	-30174103	9928124	-20245979	4294901	0	-24540581
15	0	-4096856	-219266	-4316123	-31984550	10584956	-21399594	3988123	0	-25387716
16	0	-4342668	-230229	-4572897	-33903622	11281197	-22622425	3681344	0	-26303769
17	0	-4603228	-241741	-4844969	-35937840	12019214	-23918326	3374565	0	-27293191
18	0	-4879422	-253828	-5133250	-38094110	12801511	-25292599	3067787	0	-28360386
19	0	-5172187	-266519	-5438706	-40379757	13630746	-26749011	2761008	0	-29510019
20	0	-5482518	-279845	-5762363	-42802542	14509735	-28292807	2454229	0	-30747036
21	0	-5811469	-293838	-6105307	-45370695	15441464	-29929231	2147451	0	-32076602
22	0	-6160157	-308529	-6468687	-48092936	16429096	-31663841	1840672	0	-33504513
23	0	-6529767	-323956	-6853723	-50978513	17475986	-33502527	1533893	0	-35038420
24	0	-6921553	-340154	-7261706	-54037223	18585689	-35451534	1227115	0	-36678649
25	0	-7336846	-357161	-7694007	-57279457	19761975	-37517482	920336	0	-39437818
26	0	-7777057	-375020	-8152076	-60716224	21008838	-39707386	613557	0	-40320944
27	0	-8243680	-393771	-8637451	-64359198	22330513	-42028685	306779	0	-42335464
28	0	-8738301	-413459	-9151760	-68220750	23731488	-44489262	0	0	-44489262
29	0	-9262599	-434132	-9696731	-72313995	25216521	-47097473	0	0	-47097473
30	2357487	-9818355	9116772	1655904	-76652834	26790657	-49862177	0	0	-49862177
COL. TOTALS	-85785000	-135329881	0	-221114882	*056533315	356815517	-699717797	85785000	-3840302	-789343099

FIGURE 4-1 (Continued)

4-27





ECONOMIC ANALYSIS SUMMARY

CASH FLOW SUMMARY

CLIENT - DUPONT (H.S. COAL)

COAL PRICE \$1.20/10<sup>6</sup>Btu

CASE - 7  
PSE JOB - 4027

YEAR	(11) FEDERAL INCOME TAX (-TRX10)	(12) NET OPERATING EXPENSE (10+11)	(13) INVESTMENT TAX CREDIT (-ITCX1)	(14) TOTAL CASH FLOW (8+12+13)	(15) NET CASH FLOW (4+14)	(16) DISCOUNTED CASH FLOW DR=15.0
1	25884	-28041	269624	241583	-2884058	-2507877
2	216112	-234121	2251165	2017044	-20494603	-15492866
3	409940	-444102	4270210	3826108	-38975990	-25561595
4	1191409	-1290693	1980310	689617	-21805689	-12467474
5	9532327	-10326688	0	-2837122	-5289396	-2629785
6	9697328	-10505438	0	-3384944	-5951208	-2572872
7	9881994	-10705493	0	-3924070	-6642897	-2497311
8	9940251	-10768205	0	-4633632	-7513504	-2456178
9	10183359	-11031972	0	-5203177	-8254919	-2346563
10	10449888	-11320712	0	-5798696	-9031906	-2232549
11	10741244	-11333348	0	-6421110	-9848595	-2116459
12	11058917	-11980493	0	-7072035	-10701245	-2000139
13	11404485	-12354859	0	-7753179	-11598247	-1885039
14	11779623	-12761258	0	-8466357	-12540140	-1772281
15	12186104	-13201612	0	-9213490	-13529613	-1662715
16	12625809	-13677960	0	-9996616	-14569513	-1556968
17	13100732	-14192460	0	-10817894	-15672833	-1455485
18	13612985	-14747401	0	-11679614	-16812864	-1350565
19	14164809	-15345210	0	-12584202	-18022908	-1266385
20	14758577	-15988459	0	-13534230	-19296593	-1179027
21	15396807	-16679875	0	-14532424	-20637731	-1096497
22	16082166	-17422347	0	-15581675	-22050361	-1018740
23	16817482	-18218938	0	-16695045	-23538768	-945656
24	17605751	-19072897	0	-17845783	-25107489	-877112
25	18450152	-19987665	0	-19067329	-26761337	-812946
26	19354053	-20986891	0	-20353333	-28505409	-752980
27	20321023	-22014441	0	-21707662	-30345113	-697023
28	21354846	-23134416	0	-23134416	-32286176	-644877
29	22606787	-24490286	0	-24490286	-34187417	-593785
30	23933845	-25928332	0	-25928332	-24272428	-366588
COL. TOTALS	378884688	-410458412	8771309	-315902103	-537016984	


NET PRESENT VALUE = -94828317

FIGURE 4-1 (Continued)

4-28



FIGURE 4-2 NUCLEAR FUEL CYCLE



4-29



	CASE 1	CASE 2	CASE 5
FUEL CYCLE	REPROCESSING	REPROCESSING	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*	1,000,000	1,000,000
PROCESS STEAM FLOW-LB/HR	723,000	723,000	723,000
NET POWER GENERATION-MW	SEE CURVES	SEE CURVES	SEE CURVES
PLANT AVAILABILITY	0.80	0.80	0.80
PLANT FACTOR	0.41	0.45	0.80

\*PEAKING WITH EXISTING FACILITIES

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-3 COMPARISON OF NUCLEAR PLANTS  
GENERATING SUPERHEATED STEAM

	CASE 1	CASE 2	CASE 5
FUEL CYCLE	REPROCESSING	REPROCESSING	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*	1,000,000	1,000,000
PROCESS STEAM FLOW-LB/HR	723,000	723,000	723,000
NET POWER GENERATION-MW	SEE CURVES	SEE CURVES	SEE CURVES
PLANT AVAILABILITY	0.80	0.80	0.80
PLANT FACTOR	0.41	0.45	0.80

\*PEAKING WITH EXISTING FACILITIES

NOTE: NUCLEAR/COAL PLANTS START CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-4 COMPARISON OF PRESENT VALUE COST OF STEAM FROM NUCLEAR PLANTS GENERATING SUPERHEATED STEAM.

	CASE 1	CASE 2	CASE 5
FUEL CYCLE	REPROCESSING	REPROCESSING	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*	1,000,000	1,000,000
PROCESS STEAM FLOW-LB/HR	723,000	723,000	723,000
NET POWER GENERATION-MW	SEE CURVES	SEE CURVES	SEE CURVES
PLANT AVAILABILITY	0.80	0.80	0.80
PLANT FACTOR	0.41	0.45	0.80

\*PEAKING WITH EXISTING FACILITIES

NOTE: COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.




FIGURE 4-5 COMPARISON OF NUCLEAR PLANTS  
GENERATING SUPERHEATED STEAM



	CASE 1	CASE 2	CASE 5
FUEL CYCLE	REPROCESSING	REPROCESSING	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*	1,000,000	1,000,000
PROCESS STEAM FLOW-LB/HR	723,000	723,000	723,000
NET POWER GENERATION-MW	SEE CURVES	SEE CURVES	SEE CURVES
PLANT AVAILABILITY	0.80	0.80	0.80
PLANT FACTOR	0.41	0.45	0.80

\*PEAKING WITH EXISTING FACILITIES

NOTE: COAL PLANT CONSTRUCTION STARTS  
JANUARY 1, 1981




FIGURE 4-6 COMPARISON OF PRESENT VALUE COST  
OF STEAM FROM NUCLEAR PLANTS  
GENERATING SUPERHEATED STEAM



FUEL CYCLE	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*
PROCESS STEAM FLOW-LB/HR	723,000
NET POWER GENERATION-MW	0
PLANT AVAILABILITY	0.80
PLANT FACTOR	0.41
NO. 6 FUEL OIL PRICE-\$/10 <sup>6</sup> Btu	2.60

\*PEAKING WITH EXISTING FACILITIES

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-7 EFFECT OF OIL-FIRED SUPERHEATER  
ON NUCLEAR PLANT ECONOMICS



FUEL CYCLE	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*
PROCESS STEAM FLOW-LB/HR	723,000
NET POWER GENERATION-MW	0
PLANT AVAILABILITY	0.80
PLANT FACTOR	0.41
NO. 6 FUEL OIL PRICE - $\$/10^6\text{Btu}$	2.60

\* PEAKING WITH EXISTING FACILITIES

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978




FIGURE 4-8 EFFECT OF OIL-FIRED SUPERHEATER ON  
NUCLEAR PLANT STEAM COSTS





FUEL CYCLE	REPROCESSING
DESIGN STEAM FLOW-LB/HR	810,000*
PROCESS STEAM FLOW-LB/HR	723,000
NET POWER GENERATION-MW	0
PLANT AVAILABILITY	0.80
PLANT FACTOR	0.41
NO. 6 FUEL OIL PRICE - \$/10 <sup>6</sup> BTU	2.60

\*PEAKING WITH EXISTING FACILITIES

NOTE: COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.




FIGURE 4-9 EFFECT OF OIL-FIRED SUPERHEATER  
ON NUCLEAR PLANT ECONOMICS

FUEL CYCLE	REPROCESSING
DESIGN STEAM FLOW - LB/HR	810,000*
PROCESS STEAM FLOW- LB/HR	723,000
NET POWER GENERATION -MW	0
PLANT AVAILABILITY	0.80
PLANT FACTOR	0.41
NO. 6 FUEL OIL PRICE - $\$/10^6$ BTU	2.60

\*PEAKING WITH EXISTING FACILITIES

NOTE: COAL PLANT CONSTRUCTION STARTS  
JANUARY 1, 1981




FIGURE 4-10 EFFECT OF OIL-FIRED SUPERHEATER ON  
NUCLEAR PLANT STEAM COSTS



CASE	4
FUEL CYCLE	REPROCESSING
DESIGN STEAM FLOW - LB/HR	1,288,000
PROCESS STEAM FLOW- LB/HR	SEE CURVES
NET POWER GENERATION - MW	0
PLANT AVAILABILITY	0.80
PLANT FACTOR	SEE CURVES

SATURATED STEAM

NOTE: INCLUDES NUMBER 6 FUEL COST FOR STEAM GENERATION DURING LAST 3 YEARS OF NUCLEAR CONSTRUCTION. NUCLEAR/COAL PLANTS START CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-11 EFFECT OF STEAM FLOW RATE ON PRESENT VALUE STEAM COSTS FOR NUCLEAR CASE 4

DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.20

NOTE: NUCLEAR/COAL PLANTS START CONSTRUCTION JANUARY 1, 1978




FIGURE 4-12 COMPARISON OF HIGH-SULFUR COAL PLANTS WITH FLUE-GAS SCRUBBING



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.20

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-13 COMPARISON OF HIGH-SULFUR COAL  
PLANT STEAM COSTS (WITH FLUE-GAS  
SCRUBBING)

DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.20

NOTE: COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.





FIGURE 4-14 COMPARISON OF HIGH-SULFUR COAL  
PLANTS WITH FLUE-GAS SCRUBBING



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.20

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1981




FIGURE 4-15 - COMPARISON OF HIGH SULFUR COAL PLANT  
STEAM COSTS (WITH FLUE GAS SCRUBBING)

DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.35

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978




FIGURE 4-16 COMPARISON OF LOW-SULFUR COAL  
PLANTS WITHOUT FLUE-GAS SCRUBBING





DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.35

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978




FIGURE 4-17 COMPARISON OF LOW-SULFUR COAL  
PLANT STEAM COSTS (WITHOUT  
FLUE-GAS SCRUBBING)



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION-MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.35

NOTE. COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.




FIGURE 4-18 COMPARISON OF LOW-SULFUR COAL  
PLANTS WITHOUT FLUE-GAS SCRUBBING



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
COAL COST - $\$/10^6$ BTU	1.35

NOTE: COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.




FIGURE 4-19 COMPARISON OF LOW-SULFUR COAL PLANT  
STEAM COSTS (WITHOUT FLUE GAS SCRUBBING)

DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
HIGH-SULFUR COAL COST - $\$/10^6\text{BTU}$	1.20
LOW-SULFUR COAL COST - $\$/10^6\text{BTU}$	1.35

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-20 HIGH-SULFUR VS. LOW-SULFUR COAL  
PLANTS OPTIMUM CONFIGURATION

DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
HIGH-SULFUR COAL COST - $\$/10^6$ BTU	1.20
LOW-SULFUR COAL COST - $\$/10^6$ BTU	1.35

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1978.




FIGURE 4-21 COMPARISON OF HIGH-SULFUR VS. LOW-SULFUR COAL PLANT STEAM COSTS (OPTIMUM CONFIGURATIONS)



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
HIGH-SULFUR COAL COST - $\$/10^6$ BTU	1.20
LOW-SULFUR COAL COST - $\$/10^6$ BTU	1.35

NOTE: COAL PLANT CONSTRUCTION  
STARTS JANUARY 1, 1981.




FIGURE 4-22 HIGH-SULFUR VS. LOW-SULFUR COAL  
PLANTS OPTIMUM CONFIGURATION



DESIGN STEAM FLOW - LB/HR	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000
NET POWER GENERATION - MW	SEE CURVES
PLANT AVAILABILITY	0.92
PLANT FACTOR	SEE CURVES
HIGH-SULFUR COAL COST - $\$/10^6$ BTU	1.20
LOW-SULFUR COAL COST - $\$/10^6$ BTU	1.35

NOTE: NUCLEAR/COAL PLANTS START  
CONSTRUCTION JANUARY 1, 1981





FIGURE 4-23 HIGH-SULFUR VS. LOW-SULFUR COAL PLANT  
STEAM COSTS (OPTIMUM CONFIGURATION)

	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	SEE CURVES
DESIGN STEAM FLOW LB/HR	1,000,000	1,000,000
PROCESS STEAM FLOW LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6$ BTU	SEE CURVES	N/A



DISCOUNT RATE - %  
 FIGURE 4-24 COMPARISON OF OPTIMUM COAL AND NUCLEAR PLANTS



	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	SEE CURVES
DESIGN STEAM FLOW LB/HR	1,000,000	1,000,000
PROCESS STEAM FLOW LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6$ BTU	SEE CURVES	N/A




FIGURE 4-25 COMPARISON OF STEAM COSTS OF OPTIMUM COAL AND NUCLEAR PLANTS.

CASE	COAL	NUCLEAR
FUEL CYCLE	7	5
DESIGN STEAM FLOW LB/HR	1,000,000	1,000,000
PROCESS STEAM FLOW LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST - $\$/10^6$ BTU	SEE CURVES	N/A




FIGURE 4-26 COMPARISON OF OPTIMUM COAL AND NUCLEAR PLANTS



	COAL	NUCLEAR
CASE	7	5
FUEL CYCLE	N/A	SEE CURVES
DESIGN STEAM FLOW - LB/HR	1,000,000	1,000,000
PROCESS STEAM FLOW - LB/HR	723,000	723,000
NET POWER GENERATION-MW	36.1	26.1
PLANT AVAILABILITY	0.92	0.80
PLANT FACTOR	0.92	0.80
COAL COST -/10 <sup>6</sup> BTU	SEE CURVES	N/A

NOTE: COAL PLANT CONSTRUCTION STARTS JANUARY 1, 1981.




FIGURE 4-27 COMPARISON OF STEAM COSTS OF OPTIMUM COAL AND NUCLEAR PLANTS.

TABLE 4-1

ESCALATION RATE SCHEDULES

	<u>YEAR 1</u>	<u>YEAR 2</u>	<u>YEAR 3</u>	<u>YEAR 4</u>	<u>YEAR 5</u>	<u>6 THRU 30</u>
GENERAL INFLATION	6.0	5.0	5.0	5.0	5.0	5.0
CONSTRUCTION LABOR	8.0	8.0	8.0	6.0	6.0	6.0
CONSTRUCTION MATERIALS	7.0	6.0	6.0	6.0	6.0	6.0
CONSTRUCTION COMPOSITE	7.3	6.7	6.7	6.0	6.0	6.0
OPERATIONS LABOR	8.0	7.0	7.0	7.0	7.0	6.0
OPERATIONS COMPOSITE	7.4	6.4	6.4	6.4	6.4	6.0
FUEL (PRIMARY)	6.0	6.0	6.0	6.0	6.0	6.0
No. 6 FUEL OIL	6.0	6.0	6.0	6.0	6.0	6.0

Escalation rates are expressed in percentage points.



TABLE 4-2

NUCLEAR FUEL CYCLES  
CASH FLOW - \$1,000's  
FUEL CYCLE NUMBER

YEAR	1R	4R	5R	5N
1 thru 5	0	0	0	0
6	\$14,511	\$14,826	\$16,169	\$16,169
7	2,631	2,691	5,500	5,500
8	2,404	2,460	4,682	5,867
9	2,422	2,462	4,583	5,863
10	2,384	2,422	4,494	5,860
11	2,362	2,402	4,472	5,858
12	2,308	2,349	4,472	5,858
13	2,611	2,659	4,472	5,858
14	2,223	2,259	4,472	5,858
15	2,284	2,315	4,472	5,858
16	2,284	2,315	4,472	5,858
17	2,284	2,315	4,472	5,858
18	2,284	2,315	4,472	5,858
19	2,284	2,315	4,472	5,858
20	2,613	2,651	4,472	5,858
21	2,223	2,259	4,472	5,858
22	2,284	2,315	4,472	5,858
23	2,284	2,315	4,472	5,858
24	2,284	2,315	4,472	5,858
25	2,284	2,315	4,472	5,858
26	2,284	2,315	4,472	5,858
27	2,613	2,651	4,472	5,858
28	2,223	2,259	4,472	5,858
29	2,284	2,315	4,472	5,858
30	2,284	2,315	4,472	5,858

R = Reprocessing  
N = Non-reprocessing

BASE DATE - January 1, 1978

TABLE 4-3

365 Mwt PE-CNSG STUDIES

SCOPE OF RESPONSIBILITY FOR PRICING	UE&C	B&M	PSE
<u>LAND AND LAND RIGHTS</u>	X		
<u>STRUCTURES AND IMPROVEMENTS</u>			
YARD WORK	X		
CONTAINMENT STRUCTURE			
SUBSTRUCTURE	X		
SUPERSTRUCTURE	X		
CONCRETE SHIELDING	X		
STEEL CONTAINMENT AND COMPONENTS	X		
BUILDING SERVICES			
REACTOR COMPARTMENT VENTILATION SYSTEM	X		
CONTAINMENT DRY WELL COOLING SYSTEM	X		
POST LOCA COMBUSTIBLE GAS CONTROL SYSTEM	X		
LIGHTING AND SERVICE WIRING	X		
REACTOR SERVICE BUILDING	X		
CONTROL BUILDING	X		
DIESEL GENERATOR AND FUEL OIL BUILDING	X		
ADMINISTRATION BUILDING	X		
PROCESS BUILDING	X		
PROCESS HEAT SERVICE BUILDING	X		
WATER TREATMENT BUILDING	X		
SERVICE WATER INTAKE	X		
<u>REACTOR PLANT EQUIPMENT</u>			
REACTOR EQUIPMENT			
EQUIPMENT COMPONENTS			
REACTOR VESSEL SHELL, HEAD, INTERNALS		X	
STEAM GENERATORS		X	
PRIMARY PUMPS (incl. HEAT EXCHANGER, SERVICE AND MAINTENANCE TOOLS)		X	
INSULATION (REACTOR VESSEL)		X	
REACTOR CONTROL EQUIPMENT			
CONTROL RODS AND CONTROL ROD DRIVES		X	
HANDLING EQUIPMENT (HEAD STORAGE STAND AND INTERNALS HANDLING EQUIPMENT)		X	
FIELD INSTALLATION OF ALL REACTOR EQUIPMENT	X		



REACTOR COOLANT SYSTEM	
EQUIPMENT COMPONENTS	
PRESSURIZER AND HEATERS	X
PRESSURIZER SURGE AND SPRAY LINE	X
PRESSURIZER RELIEF LINE	X
PRESSURIZER RELIEF VALVES	X
INSULATION (PRESSURIZER, AND SURGE, SPARY AND RELIEF LINES)	X
FIELD INSTALLATION OF ALL REACTOR COOLANT SYSTEM	X
SAFEGUARDS COOLING SYSTEMS	
DECAY HEAT REMOVAL SYSTEM	
DECAY HEAT REMOVAL PUMPS	X
DECAY HEAT REMOVAL HEAT EXCHANGER	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF DECAY HEAT REMOVAL SYSTEM	X
EMERGENCY DECAY HEAT REMOVAL SYSTEM	
EMERGENCY DECAY HEAT REMOVAL PUMPS	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF EMERGENCY DECAY HEAT REMOVAL SYSTEM	X
RADIOACTIVE WASTE TREATMENT AND DISPOSAL SYSTEMS	
LIQUID WASTE DISPOSAL SYSTEM	
ALL EQUIPMENT	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF LIQUID WASTE DISPOSAL SYSTEM	X
GASEOUS WASTE DISPOSAL SYSTEM	
ALL EQUIPMENT	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF GASEOUS WASTE DISPOSAL SYSTEM	X
SOLID WASTE DISPOSAL SYSTEM	
ALL EQUIPMENT	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF SOLID WASTE DISPOSAL SYSTEM	X
NUCLEAR FUEL HANDLING AND STORAGE SYSTEMS	
ALL EQUIPMENT	X
PIPING AND VALVES	X
INSULATION	X
FIELD INSTALLATION OF NUCLEAR FUEL HANDLING AND STORAGE SYSTEMS	X



	UE&C	B&W	PSE
<b>NITROGEN AND HYDROGEN GAS SYSTEM</b>			
ALL EQUIPMENT	X		
PIPING	X		
FIELD INSTALLATION OF NITROGEN AND GAS SYSTEM	X		
<b>COOLANT PURIFICATION AND CHEMICAL TREATMENT SYSTEMS</b>			
<b>MAKEUP AND PURIFICATION SYSTEM</b>			
MAKEUP TANK		X	
MAKEUP PUMPS AND MOTORS		X	
PURIFICATION DEMINERALIZERS		X	
BORATED WATER STORAGE TANK	X		
FILTERS		X	
LETDOWN COOLERS		X	
PIPING AND VALVES	X		
INSULATION	X		
FIELD INSTALLATION OF MAKEUP AND PURIFICATION SYSTEM	X		
<b>CHEMICAL ADDITION AND BORON RECOVERY SYSTEM</b>			
R-C BLEED HOLD-UP TANKS		X	
R-C BLEED EVAPORATOR DISTILLATE TEST TANKS		X	
CONCENTRATED BORIC ACID STORAGE TANKS		X	
BORIC ACID MIX TANK		X	
BORIC ACID ADDITION TANK		X	
CAUSTIC MIX TANK		X	
LITHIUM HYDROXIDE MIX TANK		X	
R-C BLEED EVAPORATOR FEED PUMPS		X	
R-C DISTILLATE TRANSFER PUMPS		X	
R-C BLEED EVAPORATOR DISTILLATE TEST TANK PUMPS		X	
CAUSTIC PUMP			X
CHEMICAL ADDITION PUMP		X	
DEBORATION DEMINERALIZERS		X	
DISTILLATE DEMINERALIZERS		X	
R-C BLEED EVAPORATOR DEMINERALIZERS		X	
R-C DEGASIFIER PACKAGE		X	
R-C BLEED EVAPORATOR PACKAGE		X	
BORIC ACID BIN AND SCREW CONVEYOR		X	
BORIC ACID FILTERS		X	
MAKEUP AND PURIFICATION DEMINERALIZERS		X	
PIPING AND VALVES	X		
INSULATION	X		
FIELD INSTALLATION OF CHEMICAL ADDITION AND BORON RECOVERY SYSTEM	X		
<b>COMPONENT COOLING SYSTEM</b>			
COMPONENT COOLING WATER SURGE TANK		X	
COMPONENT COOLING WATER PUMPS AND MOTORS		X	
COMPONENT COOLING WATER BOOSTER PUMPS AND MOTORS		X	
COMPONENT COOLING WATER ELECTROMAGNETIC FILTER		X	
COMPONENT COOLING WATER HEAT EXCHANGERS		X	





	UE&C	B&W	PSE
PIPING AND VALVES	X		
INSULATION	X		
FIELD INSTALLATION OF COMPONENT COOLING WATER SYSTEM	X		
<b>MISCELLANEOUS PLANT EQUIPMENT</b>			
DEMINEALIZED WATER STORAGE TANK	X		
EQUIPMENT AND FLOOR DRAINS COLLECTION TANK	X		
DEMINEALIZER FLUSH TANK	X		
CASK DECONTAMINATION DRAIN COLLECTION TANK	X		
DEMINEALIZER FLUSH TANK PUMPS	X		
CASK DECONTAMINATION DRAIN PUMP AND MOTOR	X		
CASK DECONTAMINATION DRAIN COLLECTION FILTER	X		
SAMPLE COOLERS	X		
PIPING AND VALVES	X		
INSULATION	X		
FIELD INSTALLATION OF MISC. PLANT EQUIPMENT	X		
<b>MISCELLANEOUS SUSPENSE ITEMS</b>			
FINAL ALIGNMENT AND CHECKING, FIELD PAINTING, QUALIFICATION OF WELDERS, STANDBY LABOR DURING STARTUP	X		
<b>ULTIMATE HEAT SINK</b>			
EQUIPMENT, PIPING, VALVES, INSULATION AND FIELD INSTALLATION	X		
MAKEUP WATER PIPING AND VALVES AND FIELD INSTALLATION			X
<b>SERVICE WATER SYSTEM</b>			
EQUIPMENT, PIPING, VALVES, INSULATION AND FIELD INSTALLATION	X		
MAKEUP WATER PIPING AND VALVES AND FIELD INSTALLATION			X
<b>INSTRUMENTATION AND CONTROLS</b>			
NSS INSTRUMENTS AND CONTROLS		X	
INSTRUMENT PIPING AND TUBING	X		
FIELD INSTALLATION OF INSTRUMENTATION AND CONTROLS	X		
<b><u>PROCESS ENERGY EQUIPMENT</u></b>			
<b>SECONDARY SYSTEM</b>			
REBOILERS		X	
FEED HEATERS		X	
PURIFICATION ION EXCHANGER		X	
COOLERS		X	
SECONDARY FEED PUMPS	X		
ELECTRO MAGNETIC FILTERS		X	
DRAIN TANK		X	
MOISTURE SEPARATORS		X	

	UE&C	B&W	PSE
CHEMICAL ADDITION EQUIPMENT		X	
PIPING AND VALVES	X		
INSULATION	X		
INSTRUMENTATION	X		
FIELD INSTALLATION OF SECONDARY SYSTEM	X		
<b>TERTIARY SYSTEM</b>			
FEED AND PROCESS RETURN PUMPS	X		
DENERATOR		X	
SUPERHEATER (Incl. FUEL SUPPLY SYSTEM)			X
PIPING AND VALVES - INSIDE PROCESS BLDG.	X		
- FROM PROCESS BLDG TO USER'S PLANT			X
INSULATION - INSIDE PROCESS BLDG.	X		
- FROM PROCESS BLDG. TO USER'S PLANT			X
FIELD INSTALLATION - INSIDE PROCESS BLDG.	X		
- FROM PROCESS BLDG. TO USER'S PLANT			X
INSTRUMENTATION	X		
<b>TURBINE - GENERATOR SYSTEM</b>			
EQUIPMENT	X		
PIPING AND VALVES	X		
INSULATION	X		
INSTRUMENTATION	X		
FIELD INSTALLATION OF TURGINE - GENERATOR SYSTEM	X		
<u>ELECTRIC PLANT EQUIPMENT</u>			
SWITCH GEAR	x		
STATION SERVICE EQUIPMENT (Incl. T-G's and D-G's)	X		
SWITCHBOARDS	X		
PROTECTIVE EQUIPMENT	X		
ELECTRICAL STRUCTURES AND WIRING CONTAINERS	X		
POWER AND CONTROL WIRING	X		
<u>MISCELLANEOUS PLANT EQUIPMENT</u>			
TRANSPORTATION AND LIFTING EQUIPMENT	X		
AIR, WATER AND STEAM SERVICE SYSTEMS	X		
COMMUNICATIONS EQUIPMENT	X		
FURNISHINGS AND FIXTURES	X		



UE&C    B&W    PSE

UNDISTRIBUTED COST

ENGINEERING AND HOME OFFICE SERVICES

    NUCLEAR PLANT

    BALANCE-OF-PLANT

FIELD SUPERVISION, QUALITY CONTROL AND JOB OFFICE  
EXPENSE

TEMPORARY FACILITIES

CONSTRUCTION EQUIPMENT

CONSTRUCTION SERVICES

                  X  
                  X  
                  X  
                  X  
                  X  
                  X

OTHER PLANT COST

LICENSING AND PUBLIC RELATIONS EXPENSE,  
OPERATOR TRAINING AND SPARE PARTS

X



TABLE 4-4

## PE-CNSG CAPITAL COST ESTIMATES

(\$1,000's - BASE JANUARY 1, 1978)

		CASE														
		1			2			3			4			5		
PROCESS STEAM DESIGN CONDITIONS	FLOW - LB/HR PRESSURE - PSIG TEMPERATURE - °F	810,000			1,000,000			810,000			1,288,000			1,000,000		
		550			550			550			550			550		
		750			750			474*			474*			750		
DESIGN POWER GENERATION	MW (GROSS)	0			0			0			0			34		
		ESTIMATES														
		CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS	CNSG	SUPER-HEATER & PROCESS INTER-FACING	SUB-TOTALS
LAND		96	---	96	96	---	96	96	---	96	96	---	96	96	---	96
STRUCTURES AND IMPROVEMENTS		23,921	684	24,605	23,972	684	24,656	23,921	634	24,555	24,022	634	24,636	24,264	863	25,127
REACTOR PLANT		58,682	---	58,682	58,682	---	58,682	58,682	---	58,682	58,682	---	58,682	58,682	---	58,682
TURBINE PLANT		---	---	---	---	---	---	---	---	---	---	---	---	6,346	---	6,346
SECONDARY/TERTIARY/SUPERHEATER SYSTEMS		3,027	4,778	7,805	3,641	5,101	8,742	3,027	3,091	6,118	4,244	3,091	7,335	3,975	5,101	9,076
ELECTRICAL PLANT		7,466	---	7,466	7,466	---	7,466	7,466	---	7,466	7,466	---	7,466	8,881	1,093	9,974
MISCELLANEOUS PLANT EQUIPMENT		2,978	---	2,978	2,978	---	2,978	2,978	---	2,978	2,978	---	2,978	3,122	---	3,122
OTHER COSTS		2,200	---	2,200	2,200	---	2,200	2,200	---	2,200	2,200	---	2,200	2,500	---	2,500
UNDISTRIBUTED COSTS		16,090	1,111	17,201	16,090	1,176	17,266	16,090	764	16,854	16,090	764	16,854	17,250	1,430	18,680
SUBTOTAL		114,460	6,573	121,033	115,125	6,961	122,086	114,460	4,489	118,949	115,758	4,489	120,247	125,116	8,487	133,603
CONTINGENCY		6,327	667	6,994	6,414	705	7,119	6,327	458	6,785	6,484	458	6,942	7,426	858	8,284
TOTAL ESTIMATE				128,027			129,205			125,734			127,189			141,887

\* SATURATED STEAM



**TABLE 4-5**  
**COAL PLANT CAPITAL COST ESTIMATES**  
(\$1,000's - BASE: JANUARY 1, 1978)

		C A S E							
		1	2	3	4	5	6	7	8
PROCESS STEAM FLOW	- LB/HR	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000	1,000,000
DESIGN CONDITIONS PRESSURE	- PSIG	550	550	550	550	550	550	550	550
DESIGN CONDITIONS TEMPERATURE	- °F	750	750	750	750	750	750	750	750
DESIGN POWER GENERATION	MM (GROSS)	0	0	30.4	30.4	25	25	51.5	51.5
TYPE OF COAL		HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR

		E S T I M A T E S							
LAND		\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400	\$ 400
SITWORK		1,125	1,125	1,125	1,125	1,125	1,125	1,125	1,125
BUILDINGS AND STRUCTURES		183	183	183	183	183	183	183	183
COAL YARD		8,747	8,747	8,747	8,747	8,747	8,747	8,747	8,747
STEAM GENERATOR		15,650	15,560	15,650	15,560	17,500	16,450	17,500	16,450
TURBINE-GENERATOR		----	----	4,410	4,410	3,431	3,359	6,310	6,310
PROCESS MECHANICAL EQUIPMENT		4,584	5,057	5,534	6,000	4,731	5,231	5,664	6,074
ELECTRICAL		3,088	3,115	4,460	4,457	4,236	4,233	4,866	4,863
CIVIL-STRUCTURAL		732	588	921	777	863	689	961	816
PROCESS PIPING AND INSTRUMENTATION		3,998	3,998	4,387	4,387	4,549	4,549	4,834	4,834
FLUE GAS DESULFURIZATION FACILITIES		7,655	----	7,655	----	8,220	----	8,225	----
UNDISTRIBUTED COSTS		<u>6,120</u>	<u>3,853</u>	<u>7,365</u>	<u>6,455</u>	<u>7,418</u>	<u>6,339</u>	<u>7,359</u>	<u>7,464</u>
SUBTOTAL		\$ 52,282	\$ 42,626	\$ 60,837	\$ 52,491	\$ 61,403	\$ 51,305	\$ 66,174	\$ 57,266
CONTINGENCY		<u>5,228</u>	<u>4,264</u>	<u>6,084</u>	<u>5,248</u>	<u>6,140</u>	<u>5,130</u>	<u>6,617</u>	<u>5,727</u>
TOTAL ESTIMATE		\$ <u>57,510</u>	\$ <u>46,890</u>	\$ <u>66,921</u>	\$ <u>57,739</u>	\$ <u>67,543</u>	\$ <u>56,435</u>	\$ <u>72,791</u>	\$ <u>62,993</u>



TABLE 4-6

CRITERIA FOR FUEL CYCLE COSTS

(Source - ORNL)

<u>BASIC COSTS</u> <u>1/1/78 DOLLARS</u>	<u>WITH</u> <u>REPROCESSING</u>	<u>WITHOUT</u> <u>REPROCESSING</u>
U <sub>3</sub> O <sub>8</sub> (\$/lb)	43	43
CONVERSION COST (\$/Kg)	3.80	3.80
ENRICHMENT COST (\$/SWU)	100	100
TAILS CONCENTRATION (% U-235)	0.25	0.25
FUEL RECOVERY COST (\$/Kg)	196	---
FISSILE PLUTONIUM VALUE (\$/g)	33	---
DISPOSAL (\$/Kg)	---	1.00



TABLE 4-7

COAL PRICE ESTIMATES

Wyoming Low-Sulfur Coal - 8,250 Btu/Lb

Illinois High-Sulfur Coal - 10,900 Btu/Lb

	<u>COST - \$/MBtu</u>	
	<u>WYOMING</u>	<u>ILLINOIS</u>
Rail Transportation	\$ .88	\$ .40
Coal Cost at mine	<u>\$ .47</u>	<u>\$ .80</u>
Delivered Price	\$1.35	\$1.20

NOTE: These prices include all costs for delivered coal. It is assumed that the purchaser does not own the unit train.



TABLE 4-8

PE-CNSG TOTAL ANNUAL EXPENSE  
ESTIMATES (LESS NUCLEAR FUEL\*)

(\$1,000's - BASE JANUARY 1, 1978)

PLANT AVAILABILITY 0.80

		C A S E				
		1	2	3	4	5
PROCESS STEAM DESIGN/OPERATING CONDITIONS	FLOW - 10 <sup>3</sup> LB/HR	810/723	1,000/723	810/723	1,288/723	1,000/723
	PRESSURE - PSIG	550	550	550	550	550
	TEMPERATURE - °F	750	750	479**	479**	750
DESIGN POWER GENERATION	MW (GROSS)	0	0	0	0	34
FUEL CYCLE NUMBER*		1R	4R	1R	5R	5R

		E S T I M A T E S				
STAFF		\$ 2,100	\$ 2,100	\$ 1,935	\$ 1,935	\$ 2,150
MAINTENANCE MATERIAL		850	850	850	850	850
SUPPLIES AND EXPENSES		325	325	325	325	325
GENERAL/ADMINISTRATIVE		270	270	270	270	270
NUCLEAR LIABILITY INSURANCE		340	340	340	340	340
NUCLEAR INSPECTION FEE		22	22	22	22	22
SUBTOTAL		3,907	3,907	3,742	3,742	3,957
POWER EXPENSE (CREDIT)		1,245	1,245	1,245	1,245	(5,419)
NO. 6 FUEL OIL FOR SUPERHEATING†		2,707	2,742	---	---	2,742
TOTAL ESCALATING EXPENSE (LESS NUCLEAR FUEL)		<u>7,859</u>	<u>7,894</u>	<u>4,987</u>	<u>4,987</u>	<u>1,280</u>
TAXES AND INSURANCE (FIXED)		1,792	1,809	1,760	1,781	1,986
TOTAL ANNUAL EXPENSE (LESS NUCLEAR FUEL)		<u>9,651</u>	<u>9,703</u>	<u>6,747</u>	<u>6,768</u>	<u>3,266</u>

\* See Table 4-2 for nuclear fuel cycle costs.

\*\* Saturated Steam

† No. 6 Fuel Oil Cost - \$2.60/MBtu

4-67





TABLE 4-9

NUCLEAR PLANT OPERATIONS MANPOWER\*

	<u>NUMBER</u>
<b>PLANT MANAGEMENT:</b>	
PLANT MANAGER	1
ASSISTENT PLANT MANAGER	1
TECHNICAL ASSISTANTS	<u>2</u>
SUB-TOTAL	4
<b>ADMINISTRATION:</b>	
OFFICE SUPERINTENDENT	1
CLERKS	2
STOCKMEN	2
ADDITIONAL SECURITY GUARDS	<u>16</u>
SUB-TOTAL	21
<b>OPERATIONS:</b>	
SUPERINTENDENT	1
SHIFT SUPERVISORS	5
OPERATING SUPERVISORS	5
CONTROL OPERATORS	5
AUXILIARY OPERATORS	5
QUALITY ASSURANCE REPRESENTATIVE	<u>1</u>
SUB-TOTAL	22
<b>MAINTENANCE:</b>	
SUPERINTENDENT	1
FORMEN	2
MECHANICS	3
REPAIRMEN	3
REPAIRMEN HELPERS	3
UTILITY MEN	<u>2</u>
SUB-TOTAL	14



TABLE 4-9 Cont'd.

	<u>NUMBER</u>
<b>INSTRUMENTATION &amp; CONTROLS:</b>	
INSTRUMENT AND CONTROLS ENGINEER	1
TECHNICIANS	2
REPAIRMEN	<u>1</u>
SUB-TOTAL	4
<b>REACTOR ENGINEERING:</b>	
REACTOR ENGINEER	1
TECHNICAL ASSISTANT	<u>1</u>
SUB-TOTAL	2
<b>CHEMISTRY AND HEALTH PHYSICS:</b>	
RADIOCHEMICAL ENGINEER	1
TECHNICAL ASSISTANT	2
TECHNICIANS	2
RADIATION CONTROL HELPER	2
HEALTH PHYSICIST	<u>1</u>
SUB-TOTAL	8
TOTAL MANPOWER REQUIREMENT	<u><u>75</u></u>

\* Manpower for steam generation only. For nuclear cases 1, 2 and 5 add 4 men for superheater operations. For Case 5 add an additional 4 men for turbine-generator operations.



TABLE 4-10

BACKUP OPERATING EXPENSES - \$1000's

	<u>No. 6 FUEL OIL</u>		<u>POWER</u>	<u>TOTAL</u>
	(5)	(7)	(6)	
<u>NUCLEAR PLANTS (9)</u>				
Case 1	Years 5-7 (1)	\$ 21,373	\$ 0	\$21,373
	Years 8-30	8,059 (8)	0	8,059
Case 2	Years 5-7 (1)	21,373	0	21,373
	Years 8-30	7,387 (8)	0	7,387
Case 3	Years 5-7 (1)	21,373	0	21,373
	Years 8-30	5,352	0	5,352
Case 4	Years 5-7 (2) (3)	18,286	0	18,286
	Years 8-30	3,657	0	3,657
Case 4	Years 5-7 (2) (4)	32,576	0	32,576
	Years 8-30	6,515	0	6,515
Case 5	Years 5-7 (1)	21,373	0	21,373
	Years 8-30	7,387 (8)	743	7,387
<u>COAL PLANTS (years 5-30) (10)</u>				
Case 1		\$ 1,860	\$ 0	\$ 1,860
Case 2		1,860	0	1,860
Case 3		1,860	602	2,462
Case 4		1,860	602	2,462
Case 5		1,860	196	2,056
Case 6		1,860	196	2,056
Case 7		1,860	1,428	3,288
Case 8		1,860	1,428	3,288

NOTES:

- (1) No. 6 Fuel not charged in years 5, 6, and 7 when coal and nuclear plants are assumed to start operation concurrently.
- (2) Only concurrent construction start date case considered.
- (3) Assumed 723,000 lb/hr saturated steam demand.
- (4) Assumed 1,288,000 lb/hr saturated steam demand.
- (5) No. 6 Fuel oil price - \$2.60/10<sup>6</sup>Btu.
- (6) Backup power charged @ \$3.26/KW/MO. for peak gross electrical power generation over 15MW (Except coal cases 5 and 6, where backup is calculated based on 0.8 X peak).
- (7) Backup fuel is sufficient to make up the difference between annual Btu produced and annual Btu required by Du Pont.
- (8) Includes No. 6 fuel for superheating.
- (9) Availability 0.80
- (10) Availability 0.92

Base Date - January 1, 1978

Power Systems Engineering, Inc. 

TABLE 4-11

COAL PLANT TOTAL ANNUAL EXPENSE

(\$1,000's - BASE JANUARY 1, 1978)

PLANT AVAILABILITY - 0.92

		C A S E							
		1	2	3	4	5	6	7	8
PROCESS STEAM DESIGN/OPERATING CONDITIONS	FLOW - 10 <sup>3</sup> LB/HR	1,000/723	1,000/723	1,000/723	1,000/723	1,000/723	1,000/723	1,000/723	1,000/723
	PRESSURE - PSIG	550	550	550	550	550	550	550	550
	TEMPERATURE - °F	750	750	750	750	750	750	750	750
DESIGN POWER GENERATION - MW (GROSS)		0	0	30.4	30.4	25	25	51.5	51.5
COAL TYPE *		HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR	HIGH SULFUR	LOW SULFUR

		E S T I M A T E S							
STAFF	\$	1,780	1,548	1,909	1,676	1,909	1,676	1,909	1,676
MAINTENANCE MATERIAL		600	502	700	640	720	620	820	711
LIMESTONE		235	---	326	---	252	---	347	---
ASH/SLUDGE DISPOSAL		347	248	479	343	371	265	514	367
MISCELLANEOUS SUPPLIES		215	179	323	245	249	189	314	261
SUBTOTAL		3,177	2,477	3,737	2,904	3,501	2,750	3,904	3,015
POWER EXPENSE (CREDIT)		1,804	1,603	(4,079)	(4,366)	(2,147)	(2,362)	(8,611)	(9,137)
COAL EXPENSE		9,011	10,342	12,455	14,305	9,649	11,083	13,346	15,330
TOTAL ESCALATING EXPENSE		13,992	14,422	12,113	12,843	11,003	11,471	8,639	9,208
TAXES AND INSURANCE (FIXED)		805	656	937	808	946	790	1,019	882
TOTAL ANNUAL EXPENSE		14,797	15,078	13,050	13,651	11,949	12,261	9,658	10,030

\* High Sulfur Coal Cost - \$1.20/MBtu; Low Sulfur Coal Cost - \$1.35/MBtu



TABLE 4-12

COAL PLANT OPERATIONS MANPOWER\*

	<u>Number</u>
<b>MANAGEMENT STAFF:</b>	
PLANT MANAGER	1
MECHANICAL ENGINEER	1
ELECTRICAL/INSTRUMENTATION ENGINEER	1
PURCHASING AGENT }	1
WAREHOUSEMAN }	
PAYROLL CLERK }	1
RECEPTIONIST/SECRETARY }	
	<hr/>
SUB-TOTAL	5
 <b>MAIN CONTROL ROOM:</b>	
SUPERVISOR	1
OPERATORS:	
BOILER	10
TURBINE-GENERATOR	5
INSTRUMENTATION	5
	<hr/>
SUB-TOTAL	21
 <b>ROVING:</b>	
WATER TREATMENT	5
PRECIPITATOR/DUST COLLECTION	5
ASH HANDLING	5
	<hr/>
SUB-TOTAL	15
 <b>COAL HANDLING:</b>	
SUPERVISOR	1
COAL RECEIVING AND STACKING	4
COAL RECLAIMING AND DELIVERY	2
ASH PONDS	2
	<hr/>
SUB-TOTAL	9



TABLE 4-12 Cont'd.

	<u>Number</u>
FLUE GAS DESULFURIZATION:	
SUPERVISOR	1
LIMESTONE HANDLING	1
CONTROL ROOM	5
SLUDGE DISPOSAL	2
	<hr/>
SUB-TOTAL	9
 MAINTENANCE:	
SUPERVISOR	1
PREVENTATIVE	4
STANDBY	10
	<hr/>
SUB-TOTAL	15
TOTAL MANPOWER	<u>74</u>

\*INCLUDES MANPOWER FOR TURBINE GENERATOR AND FLUE GAS  
DESULFURIZATION FACILITIES.



	<u>COAL</u>	<u>NUCLEAR</u>	BASE CASES: Coal Case 7 (High Sulfur Coal @ \$1.20/MMBtu)
Process Steam Flow - LB/HR	723,000	723,000	
Net Power Gen. - MW	36.1	26.1	Nuclear Case 5 (Reprocessing Fuel Cycle)
Plant Factor	.92	.80	

PARAMETER	SENSITIVITIES					
	% CHANGE IN NPV/% CHANGE IN PARAMETER					
	10% DISCOUNT RATE		15% DISCOUNT RATE		20% DISCOUNT RATE	
	COAL	NUCLEAR	COAL	NUCLEAR	COAL	NUCLEAR
CAPITAL INVESTMENT	-0.4	-0.5	-0.5	-0.5	-0.6	-0.6
PRIMARY FUEL COST	-0.7	-0.2	-0.6	-0.2	-0.4	-0.1
PRIMARY FUEL ESCALATION*	-11.1	-2.4	-7.4	-1.6	-5.0	-1.2
NO. 6 FUEL OIL COST	<-0.1	-0.4	<-0.1	-0.3	<-0.1	-0.3
NO. 6 FUEL OIL ESCALATION*	-2.7	-5.4	-1.8	-3.7	-1.2	-2.7
(Less OPERATING COST Primary Fuel)	-0.2	-0.1	-0.2	-0.1	-0.1	-0.1
POWER CREDIT	+0.5	+0.2	+0.4	+0.1	+0.3	+0.1
AVAILABILITY *	+0.9	+0.8	+0.7	+0.5	+0.6	+0.4

\*PER. PERCENTAGE POINT

Example: A 1% Increase in nuclear (primary) fuel cost results in a 0.2% Decrease in net present value at 15% discount rate.

TABLE 4-13 COMPARISON OF NET PRESENT VALUE SENSITIVITY TO ECONOMIC PARAMETER VARIATIONS



## 5.0 CONCLUSIONS

### 5.1 Site Feasibility

This section treats the results of the preliminary evaluation of the suitability of the Du Pont site for siting a nuclear power plant such as the PE-CNSG. The objective of this evaluation was to identify gross site inadequacies, such as possible active faults, which could place very serious limitations on locating the PE-CNSG at the site and could lead to complex licensing problems and the associated substantially higher costs that could accrue.

Although proper investigation of such potential inadequacies would require extensive field studies, it was felt that the stated objective could be met by a site visit and by examination of Du Pont's available geologic data. This has been accomplished, but the costs associated with site suitability studies and site preparation or remedial work, that might be revealed later by actual field investigations, have not been factored into the economic assessment.

As pointed out before, the objective of the site evaluation was to identify major geological inadequacies if any. Brief consideration was also given to some other site-related factors. The findings listed below are preliminary and are subject to future verification.

- (1) No gross site characteristics were identified which would preclude locating a nuclear plant at the Du Pont site.
- (2) From a licensing standpoint, surface faulting and subsidence are major geological considerations which will have to be addressed. Liquifaction, however, should not be of concern because of the high density of the existing sands.
- (3) As of now, there are no borings drilled at the proposed PE-CNSG location. However, considering the characteristics of the upper soils, only light or less important structures should be placed on these soils.
- (4) According to available information, the overpressure that would result at the proposed CNSG site if the nearest storage container exploded would be approximately 0.01 psi. This is small, and the 24 inch diameter natural gas transmission pipeline running just south of the proposed CNSG site seems to be of more significance in estimating explosion overpressure. While an analysis is beyond the scope of the study, it is believed that the gas pipeline will not be a limiting factor in locating the CNSG plant at the Du Pont site.





## 5.1 Site Feasibility - (Continued)

The physical requirements for nuclear plant siting are more restrictive than those for a conventional coal plant. Thus, the lack of apparent site difficulties affecting nuclear siting appears to ensure that there would be no problems in locating a coal plant physically on the site.

The licensing of a nuclear plant is based on safety considerations and analyses which demonstrate the even under conditions associated with the "design basis" loss-of-coolant accident and with a number of conservative assumptions, the reactor core will be adequately cooled and no fuel melting or fission product released will occur. Federal regulations (10 CFR Part 100), however, state that as an aid in evaluating a proposed site an applicant should assume a fission product release from the core together with containment leakage for the purpose of determining that the radiation dose to human individuals around the site is below certain values. The Nuclear Regulatory Commission requires further conservative ("worst case") assumptions for siting analysis, including lower radiation limits to humans plus conservative assumptions with respect to atmospheric dispersion and human inhalation. These conservative assumptions are designed to ensure that the reactor site will be such that radiation exposure to the population will be minimized in the event of an accident.

The results of the siting analysis determine the so-called "Exclusion Area" (EA) and the "Low Population Zone" (LPZ) to be associated with the nuclear plant site. The EA is the area surrounding the reactor in which the reactor licensee has the authority to determine all activities within the area, including removal of personnel and property. In selecting a site for a nuclear power plant, it is necessary to provide for an exclusion area in which the applicant has the authority to control activities within the area. This is typically accomplished by providing a fence with guards to monitor and control the personnel who enter the area.

The LPZ is an area that immediately surrounds the exclusion area in which the population number and distribution is such that there is a reasonable probability that appropriate measures could be taken in their behalf in the unlikely event of a reactor accident. A fence would not typically be used at the LPZ since this area can contain residential dwellings and occupants not under the control of the plant owner.

At a typical large electrical generating nuclear plant, the EA can be as large as a circular area with radius of 0.4 mile, and the LPZ as large as an area with a radius of 3 miles. Because of the small size and inherent safety features of the PE-CNSG, the radius of the LPZ was calculated to be 900 feet and the EA was calculated to be so small as to be virtually at the reactor building. This implies that



## 5.1 Site Feasibility - (Continued)

an individual standing near the reactor building following a reactor accident would not receive a radiation dose in two hours that exceeds regulatory acceptable limits nor would a person standing at the LPZ boundary receive a radiation dose that exceeds safe limits even if he stands at the location for the entire duration of the activity release (usually assumed to be 30 days).

Due to the very low EA and LPZ distances that result from a PE-CNSG reactor accident, it is recommended for this site that the EA boundary be moved out to the 900-foot distance so that the EA and LPZ are the same. This implies that a fence would be placed around the reactor plant at a 900 foot radius with appropriate security guards to control and monitor personnel entering the site. Since the process plant then would be outside of the LPZ, even the worst assumed reactor accident conditions should not interfere with continued operation of the plant with auxiliary steam.

From a radiation standpoint, it is concluded that the proposed plantsite will be acceptable for licensing based on the limited study performed.

## 5.2 Economic Feasibility

The case 5 nuclear plant is the optimum of the five nuclear plants studied under the established net present value (NPV) criterion. This configuration is designed to meet Du Pont's stated process steam requirements and generates a 26.1 MW of electrical power on a 26.1 MW levelized annual basis.

The case 7 high-sulfur coal-fired plant is the optimum coal plant. The case 6 or case 8 low-sulfur coal-fired plants actually have slightly higher NPVs but do not include expenses for flue gas scrubbing, which most probably will be required. Therefore it has been concluded that the case 7 plant is more representative of a realistic alternative. The case 7 coal plant also satisfies Du Pont's process steam requirements, while generating 36.1 MW of electrical power on a levelized annual basis.

Under the assumptions in force for the study and for this particular application, it is concluded that the coal-fired plant is the economic choice for coal prices less than \$2.00-\$2.20/10<sup>6</sup>Btu for the concurrent construction start date plants and less than \$2.40-\$2.50/10<sup>6</sup>Btu for the concurrent operation start date plants.

The relatively high energy costs predicted for nuclear (compared to earlier estimates) arise from several factors. The average industrial steam load of 723,000 lb/hr amounts to only 56% of rated reactor capacity, and while the excess steaming capacity is used to generate electricity, power generation does not provide sufficient net revenue to yield attractive overall steam production costs. For a PE-CNSG producing steam only a rise in industrial steam load from 56% to 100% of reactor capacity would lower steam cost by about 20%.



## 5.2 Economic Feasibility - (Continued)

Du Pont's requirement for superheated steam imposes an additional cost penalty on the PE-CNSG since a supplemental oil-fired superheater is required to elevate the reactor steam to about 750°F. Thus, oil provides about one-fifth of the energy consumed to produce process steam during normal operations. Superheating increases steam costs by about 10%.

A PE-CNSG application for supplying base-load saturated steam to industry, either prime steam or via cogeneration; probably would be more attractive. Present results, project saturated steam costs of about \$2/10<sup>6</sup>Btu in 1978 dollars for a 1,288,000 lb/hr constant steam demand and a 15% discount rate. Oil based superheat would increase the steam cost to about \$2.20/10<sup>6</sup>Btu; this is roughly equal to the cost of superheated process steam from a case 7 coal-fired plant with a 0.85 plant availability factor and burning high-sulfur coal costing \$1.70/10<sup>6</sup>Btu, or \$37/Ton.

Sensitivity studies showed that the nuclear plant economics are less sensitive to fuel prices than the coal-fired plants.

Since the capital investments required for nuclear and coal plants are widely different, a NPV analysis may not provide sufficient economic information to allow a final choice to be made. However, a more detailed evaluation that considers company financing explicitly, is beyond the scope of the present study. It is expected that consideration of debt financing in place of equity financing would improve the economic outlook for the capital intensive nuclear option.

## 5.3 Technical Feasibility

All CNSG and coal-fired process steam generation systems studied are technically feasible. Both types of systems represent essentially state-of-the-art technology.

For the CNSG plants, the major technologically related uncertainty is the Nuclear Regulatory Commission's (NRC) licensing requirements. The CNSG application considered in this study would be a "First-of-a-kind" installation. As such, there is no direct precedent to guide the NRC in its licensing procedures. B&W has expended considerable effort towards generic-type licensing of the reactor plant itself. Since the plant is an extension of previous marine applications and calls for no technological advances, and since the design appears to offer certain safety advantages, there is no reason to doubt its licenseability.

### 5.3 Technical Feasibility - (Continued)

The coal plant poses no apparent problems from a technical licensing standpoint. Environmental standards may become more stringent in the future. However, as of the date of this study, all coal plants considered would be acceptable from an environmental standpoint in the Victoria, Texas, area if flue gases are scrubbed.



## 6.0 RECOMMENDATIONS

This feasibility study has demonstrated that both the PE-CNSG and coal alternatives are feasible process steam generation systems for the Du Pont plant site at Victoria, Texas. The economic analyses have shown that, on an all-equity, net present value basis, the optimum PE-CNSG configuration is not competitive with the optimum coal plant configuration. Any future studies aimed at more fully defining PE-CNSG and coal plant economics should consider these aspects:

- (1) Consider cost of capital in cash flow analyses. This is necessary due to the wide differences in capital investment required between the nuclear and coal plants.
- (2) Study the economics of coupling the PE-CNSG to existing industrial plants that have been modified to accept saturated steam. This improves the economics of the PE-CNSG plant considerably, especially as the steam demands increases towards full PE-CNSG capacity.
- (3) Consider alternative fuels for superheating, including waste or by-product fuels not currently fired to produce steam.

Item (1) will certainly be a factor in the final decision to proceed with any alternative steam supply system. The wide difference in capital required for a PE-CNSG plant relative to a coal-fired plant would have to be economically justifiable. The return on the differential capital investment for the more expensive alternative would have to be determined in light of a comparison to the alternative investment, with cost of capital included in the analysis. The effect of cost of capital becomes increasingly important as the amounts of capital investment become more highly unequal. The PE-CNSG offers potentially high savings in annual costs, but with its high capital investment, a complete economic picture can be obtained only with debt service costs included as a part of the economic analyses.

The PE-CNSG is a pressurized water reactor (PWR). A generic characteristic of PWRs is that they generate saturated or only slightly superheated steam. While superheating the PWR steam presents no real technical obstacle, it can have a significant impact on PE-CNSG economics for applications where superheated steam is required, depending on the fuel used. Thus, any further study ought to consider the economics of alternative superheater fuels and/or process plant modifications which would allow use of saturated steam.



#### REFERENCES

1. "A Small Pressurized Water Reactor for Process Energy" prepared by Babcock and Wilcox under contract to the Oak Ridge National Laboratory, Report No. BAW-1428 (ORNL/SUB-4390/2) June 1976.
2. O. H. Klepper, L. C. Fuller, and M. L. Meyers, "Assessment of a Small Pressurized Water Reactor for Industrial Energy", ORNL/TM 5881, October 1977.
3. "Comparison of Coal - and Nuclear-Fueled Alternatives for Process Steam and By Product Electrical Power Generation for the PPG Industries, Incorporated, Plant Site, Lake Charles, Louisiana", prepared by Power Systems Engineering under contract to Oak Ridge National Laboratory, ORNL/SUB-7257/8
4. "Duval Corporation Application Study, Nuclear Process Energy From PE-CNSG", prepared by Babcock & Wilcox under contract to Oak Ridge National Laboratory BAW-1448, ORNL/SUB-4390/5 December, 1977.

