E&TR

UCRL--52000-84-6

DE84 014465

Energy and Technology Review

Lawrence Livermore National Laboratory

June 1984

- Earthquake-Hazard Analysis for Nuclear Power Plants** 1
We have applied a unique probabilistic approach, using the weighted opinions of experts to supplement sparse data, to estimate the seismic hazard at nine older plants in the northeastern United States.
- Reactor-Coolant Piping: Realistic Failure Assessment** 2
Our analysis of failure modes in reactor-coolant piping suggests that current design criteria are overly severe. More realistic guidelines would produce substantial savings without compromising plant safety.
- Human Factors in Reactor Facility Design** 26
We are supplying the Nuclear Regulatory Commission and the U.S. Department of Energy with technical information on human-factors engineering in the design of nuclear-reactor control rooms to assist in their continuing efforts to improve nuclear reactor safety.
- Abstracts** 37

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NOTICE
PORTIONS OF THIS REPORT ARE REPRODUCIBLE
IT HAS BEEN REPRODUCED FROM THE BEST
AVAILABLE COPY TO PERMIT THE BROADEST
POSSIBLE AVAILABILITY.

MASTER

UCRL-52000-84-6
Distribution Category UC-2
June 1984

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

About the Cover

This computer-generated, abstract piping maze suggests the complex subject of nuclear reactor safety, to which this issue is dedicated. Reactor safety is complex because it involves disciplines as diverse as human-factors engineering (the design of complex systems and controls for efficient maintenance and operation by people of normal size and strength), probabilistic analysis (which seeks to combine the opinions of experts with available data to arrive at valid and realistic conclusions regarding seismic and other risks), and failure-mode analysis (which examines the possible causes and consequences of a catastrophic failure in the primary-coolant piping of a reactor). The worst possible pipe failure in a reactor is the double-ended guillotine break, illustrated in the lower right corner of the cover.

Scientific Editor

Frank A. Morrison, Jr.

General Editors

Robert A. Condouris
Richard B. Crawford
Lauren de Vore
Mary Ann Esser
Palmer T. Van Dyke

Graphics Designer

Paul Harding

Artists

Linda Davis
Kimberly Smith

Compositor

Louisa Cardoza

Art Credit

C. Jackson Mayes (cover)

Earthquake-Hazard Analysis for Nuclear Power Plants

Using the weighted opinions of experts to supplement sparse data enables us to produce realistic seismic-hazard estimates.

Earthquakes are not merely a west-coast phenomenon. There are regions classed as having at least moderate seismic risk in more than 39 of the 50 states of this country. The most severe historic earthquake (in terms of area catastrophically affected) in the contiguous United States occurred not in California but as one in the series that struck New Madrid, Missouri, in 1811 and 1812. Furthermore, the area of comparable damage in a severe eastern earthquake is much larger than in a western one of the same magnitude and could simultaneously threaten widely separated facilities (as illustrated in Fig. 1, which compares the New Madrid and the 1906 San Francisco earthquakes).¹ Therefore, earthquake hazards must be taken into account in reactor design regardless of where the facility is located.

The major concern about earthquakes as a threat to nuclear power plants is the potential for release of radioactive material. In a conventional power plant, it might be possible to accept a certain amount of structural damage from an earthquake, so long as it caused no loss of life. In a nuclear power plant, however, damage that allows radioactive material to escape (whether it causes

structural damage or merely interferes with the operation of a critical safety system) is unacceptable. The design requirements are consequently more stringent, making it important to define completely the seismic hazard at each nuclear facility.

Through the Nuclear Systems Safety Program at LLNL, we have been developing a probabilistic method for estimating seismic hazards to assist the Nuclear Regulatory Commission (NRC) in its assessments of seismic safety at nuclear power plants.² Our results form an important part of the technical data base the NRC uses as part of its Systematic Evaluation Program to determine the appropriate hazard level for evaluating seismic safety in nine of the oldest nuclear power plants in the eastern U.S. (Fig. 2). We are in the process of improving our methods and extending our models to apply to the seismic hazard at all nuclear power plants east of the Rocky Mountains.

Analysis of Earthquake Hazard

Seismic hazard is a measure of some geophysical or mechanical characteristic

For further information contact
Don L. Bernreuter (415) 422-0305
or Dae H. Chung (415) 422-0268.

Fig. 1

Eastern earthquakes are disquietingly different from western earthquakes. The shaded areas represent regions of roughly comparable observed damage for the San Francisco (1906) and New Madrid (1811-12) earthquakes. Even though the San Francisco earthquake had a greater magnitude, the New Madrid earthquake caused damage in a much larger area. (M is the Richter magnitude.)

Fig. 2

Locations of the nine nuclear power-plant sites in the eastern U.S. that we evaluated for seismic hazards using our probabilistic approach. As a cross check, the NRC independently evaluated the same sites with a deterministic method, a modified tectonic-province approach. Also shown are some of the seismic source zones used in the NRC evaluation.

Deterministic Approach

Probabilistic Approach

Step 1

Determine seismic sources

Step 2

Select governing earthquake

Step 3

Determine attenuation

Step 4

Determine loading at site

Model earthquake recurrence

Determine attenuation

Determine probability of nonexceedence

Fig. 3

The four steps in deterministic and probabilistic approaches to calculating seismic loading, displayed in parallel to point up their differences and similarities. The first step in both is to specify local (fault) and regional (tectonic province) source regions. The two approaches then diverge. In the deterministic approach, a governing earthquake is selected. Allowances are made for attenuation with distance from the source, and the loading at the site is calculated. (A governing earthquake is defined as the most damaging historical earthquake associated with the site and assumed to occur within 10 to 15 km of the site if in the same province or at the closest boundary if in an adjoining province.) In the probabilistic approach, on the other hand, an earthquake recurrence model is determined for each source from a linear regression analysis relating earthquake size (magnitude or intensity) to frequency of occurrence, terminated at the largest earthquake expected from each source. Then, the ground motion at the site from the different earthquakes at different distances is calculated, and the effects of all earthquakes (different sizes, locations, and sources) are integrated with the recurrence information to calculate the probabilities that given levels of ground motion will not be exceeded within given time periods.

of the potential seismic events, such as peak acceleration, that can affect a given site (see the box about earthquakes on p. 8). We used both probabilistic and deterministic approaches in our study to estimate seismic hazards. The earthquake characteristics we quantified are related to ground shaking: its intensity (and the likelihood of experiencing that intensity) and its frequency distribution.

A typical seismic-hazard analysis, whether deterministic or probabilistic, consists of identifying the seismic sources, defining an earthquake occurrence model for each source,

formulating an attenuation model, and evaluating the seismic hazard or loading at the site. Although most techniques of seismic analysis involve these four steps, differences in key assumptions and modeling details can produce significantly different results. Figure 3 illustrates the four steps as carried out in deterministic and probabilistic approaches (see the box on p. 15 for a comparison of these two methods of analysis).

Four unique features of our approach, called the Uniform Hazard Methodology, make it especially useful in analyzing the

Fig. 4

The 130-page questionnaire submitted to the geologic and seismologic experts who served on our panel. This detailed and lengthy questionnaire contained discussions of analysis and modeling techniques, data to assess, pages of questions to answer, maps and charts to complete, and requested a self-evaluation of uncertainty.

seismic hazard for sites in the central and eastern United States. It (1) incorporates subjective input from experts explicitly, (2) includes all earthquakes, small and large, (3) combines exceedance probabilities (the likelihood of exceeding a certain value of ground motion) due to earthquakes from all sources and at all distances from the site, and (4) provides for a formal treatment of uncertainty. In contrast, other methods restrict the available data base, however inadequate, confine their attention to the "largest credible earthquake," however that may be defined, produce ground-motion-frequency distributions that represent only one event or one restricted class of events, and provide only crude estimates of uncertainty.

Subjective Input From Experts

Any analysis of seismic hazard involves a great deal of professional judgment because it is necessary to form opinions from fragmentary data. Because this judgment usually is incorporated informally, the resulting analyses are only as good as the analysts' experience. The low level of seismic activity in the central and eastern United States and the lack of instrumental records make estimates of the seismic hazard for that region particularly uncertain and subject to wide individual variations.

One of the most innovative features of our method is its explicit use of expert opinion to complement the historical

data. We formally solicit subjective input from panels of experts and incorporate it into the results using state-of-the-art procedures in expert-opinion technology. We put considerable effort into selecting knowledgeable experts and consultants to assure a balanced input.

Our first panel, consisting of experts on eastern U.S. seismicity, identified the relevant seismic sources, defined an earthquake occurrence model for each source, and formulated an attenuation model. Each of the ten experts on the panel filled out a detailed questionnaire (Fig. 4) that asked for:

- The configuration of seismic source zones in the central and eastern U.S.
- The maximum earthquake magnitude or intensity expected in each zone.
- The earthquake activity rate and recurrence statistics associated with each zone.
- The methods suitable for predicting ground-motion attenuation in each zone from an earthquake of a given size at a given distance.

In addition, each expert was asked to rate, on a scale of one to ten, his own confidence in each of his responses.

No two seismic experts normally will agree exactly (Table 1), and sometimes a single expert may have more than one opinion based on different sets of assumptions (Fig. 5). Our method specifically takes this variability into account. Rather than look for a consensus at the input stage, we processed the input from each expert individually, including his uncertainties about the various parameters, to determine his estimate of the seismic hazard at each site. Then, we synthesized the various hazard results thus obtained, using a complex weighting method derived from each expert's self-ranking. This procedure has the advantage of providing seismic-hazard curves for each expert and of establishing sensitivity for each set of assumptions.

Because our seismic-hazard analysis involved new techniques and complex model building, we formed a peer-review panel of seismologists and engineering statisticians. We asked the four members of the review panel to

Table 1 Variation among expert estimates of the largest earthquake for the zone containing the Dresden nuclear-power reactor site in central Illinois. (The body-wave magnitude, m_b , is defined for compressional waves at teleseismic distances.)

Number of experts	Estimated largest earthquake magnitude, m_b
2	4.5 - 5.0
1	4.3 - 5.8
2	5.0 - 6.0
1	5.8 - 6.4
1	More than 7

Fig. 5

Two seismic zonation maps based on the judgment of a single expert about geological and seismic characteristics in the eastern U.S. The numbers in the zones are arbitrary indices. (a) Seismic zones (regions within which frequency of occurrence, distribution of magnitudes, and overall effects are all similar) based on what the expert regards as the most probable set of hypotheses. (b) An alternative set of zones, based on different hypotheses the expert considers somewhat less likely. Our probabilistic method provides a rational means to combine these differing inputs into a coherent whole.

evaluate our method of analyzing seismic hazard, our expert-opinion questionnaire, and the usefulness of our results.

In the opinion of this peer-review panel, the section of the questionnaire dealing with the development of ground-motion models gave the least satisfactory results. We, therefore, invited a third panel consisting of four experts with extensive experience in formulating ground-motion models to review this aspect of the analysis. These experts provided written comments on such topics as ground-shaking-intensity attenuation, data-base issues, vibrational-frequency-distribution spectra, magnitude scales, regression weighting, and near-field models.

We also worked with a fourth panel, a joint NRC/LLNL steering committee, to manage and evaluate the subjective input. This panel discussed and made decisions about such issues as uncertainties and ways of treating diverse information from experts.

Uniform-Hazard Spectrum

To be useful in a seismic safety evaluation, an estimate of the seismic hazard at the site of a nuclear power plant must be as complete as possible. To enable meaningful comparison of seismic hazards among different sites and of individual estimates of seismic hazards at a single site, all the analyses must follow a uniform approach and must use compatible systems of measurement.

Our probabilistic approach enables us to define a uniform-hazard spectrum in which the probability of exceeding a given amplitude is obtained for each vibrational frequency. We develop the spectrum point-by-point by considering each frequency independently, neglecting any correlation between differing spectral amplitudes, and calculating predictions for one frequency at a time.

To do this, we consider all potential earthquakes contributing to the seismicity at the site, large and small, using appropriate seismicity, attenuation, and exposure models, and compute the cumulative contribution to the loading at the given frequency as a cumulative distribution function of the loading.

Then, we plot the spectral acceleration vs frequency and use the loading corresponding to the return period of interest as the appropriate spectral amplitude for design at the given frequency. We repeat this procedure for each of the other frequencies within the frequency range of interest and thereby build up the spectrum.

Since each frequency is treated independently and the specific spectral shapes corresponding to particular earthquakes are deliberately suppressed, our uniform-hazard spectrum is independent of the characteristics of any single event. For example, the ground motion from a nearby small earthquake is likely to be rich in high-frequency vibrations and relatively lacking in low frequencies. Conversely, if the event is distant, low frequencies probably will dominate its spectrum. Superposing both high and low frequencies (and the resulting amplitudes) in the analysis is a conservative approach because no structure will have to resist more than one earthquake at a time.

Treatment of Uncertainty

In this study for the NRC's Systematic Evaluation Program, we considered both systematic and random uncertainty. Systematic uncertainty is that associated with errors in the form and parameters of the models used in the analysis (e.g., the elements of the attenuation law, upper-bound magnitudes, and site amplification factors) whereas random uncertainty is that associated with independent variation in parameters (e.g., the magnitudes of different earthquakes, given their common distribution).

We treated systematic uncertainty in several ways, depending on the parameter. For instance, our system of processing the input from each expert on an individual basis, deferring the formation of a consensus to the results stage, allows conflicting individual systematic biases to compensate for one another. We treated systematic uncertainty in the geometry of the seismic source by considering two bounding hypotheses and attempting no combination of the associated results. We treated systematic uncertainty in

attenuation through sensitivity analysis by considering different alternative attenuations.

Other uncertainties such as those in the mean occurrence rate and in the magnitude distribution, including the upper magnitude cutoff, we initially treated as random. We have improved this treatment in our current project, in which we are characterizing seismic hazards in reactors throughout the eastern U.S., by using a full Monte Carlo uncertainty analysis.

Results

One of the most interesting aspects of this study is the diversity of views

among experts, not only about zonation and the other parameters of the earthquake occurrence model but also about the largest earthquake that can occur in a given zone. For example, estimates of the magnitude of the largest earthquake for the zone containing the Dresden site in central Illinois varied from 4.5 to more than 7 (see Table 1). This is an enormous range, representing almost a thousand-fold variation in energy release.

One of the reasons for such wide variations in interpretation, in addition to the paucity of information about seismicity in the eastern United States, is the degree of uncertainty involved

Earthquakes

An earthquake is any perceptible earth tremor or shaking from natural (that is, volcanic or tectonic) causes. Earthquakes originate underground and usually give little or no warning. Therefore, to study them we need instruments (seismometers) that can lie dormant for long periods of time and automatically record data when needed. Seismometers also must be sensitive to small tremors yet rugged enough to survive violent shaking.

To visualize how a simplified earthquake starts, imagine an enormous block of gelatine with a vertical knife-slit through the middle of its lower half. Gigantic hands are slowly pushing the right side forward and pulling the left side back along the slit, creating a strain on the upper half of the block that gradually splits it. When the split reaches the upper surface, the two halves of the block spring apart and jiggle back and forth before settling into a new alignment. Inhabitants on the upper surface would interpret the shaking as an earthquake. Such an earthquake with purely horizontal movement would be most unusual, however; most earthquakes involve at least some vertical displacement as well. In addition, although surface rupture may not occur in every earthquake, surface displacement is a key clue to detecting an active fault.

Seismologists are interested primarily in the magnitude of an earthquake (the intensity of motion at its underground focus), its depth and epicentral location, and what they can learn about the earth's interior structure by measuring the polarizations, strengths, and arrival times of the various earthquake waves at a large

number of seismic stations. Seismic engineers, on the other hand, deal with the ground motion that can be expected at a particular site as a result of earthquakes in that region. Seismic engineers use the seismologist's data to determine the sideways and vertical loading (accelerations) that an earthquake could apply to a building or other structure.

The response of a structure to earthquake loading depends not only on the direction and magnitude of the forces acting on it (the amplitudes of the various ground-motion components) but also on their vibrational frequency. One part of a structure may be tuned to short-period (high-frequency) waves and another to long-period (low-frequency) waves. The frequency distribution (or spectrum) of a local earthquake is usually relatively rich in short-period waves. However, the spectrum of a distant earthquake is usually poor in short-period waves but rich in long-period waves because short-period waves tend to die out (attenuate) more rapidly with distance from the focus than do long-period waves.

In estimating the seismic hazard at a particular site, it is also necessary to take into account the return period (the length of time between successive events) for earthquakes as a function of the ground-motion parameters of displacement, peak velocity, and peak acceleration. As a general rule, minor events are much more frequent than major ones (as light breezes are more numerous than tornadoes), and earthquakes are no exception. It is necessary to exercise judgment in interpreting earthquake data so as to design against realistic hazards rather than vanishingly remote possibilities.

in seismic measurements. For example, Fig. 6 plots peak-acceleration measurements in the Imperial Valley earthquake of October 15, 1979, vs distance from the fault. The scatter in the data contributes to the difficulty in making precise estimates of seismic hazards.

Despite the large differences of opinion among the experts about the various input parameters to the seismic-hazard model, the net seismic hazard computed in the range of return periods from 100 to 10 000 years is relatively consistent. (The return period is the average interval between occurrences for an event of a given magnitude.) Figure 7 illustrates this consistency by comparing the 1000-year return spectra for a site in the midwestern U.S. calculated from the input of each of the experts.

Validation

Considering the widely different views among experts about the key parameters of the analysis, it would be useful to compare the computed hazard with the historical record. This is a difficult task because reliable measurements are available only for the recent past. We can, however, produce pseudo-historical estimates of the magnitude and epicentral location in early earthquakes from newspaper accounts and insurance records of regional damage. From these, we can estimate the probability of there having been a given level of ground motion at the reactor site in the past by combining these estimates with a ground-motion model. When we do this, we obtain reasonable agreement between such pseudo-historical estimates and our calculated estimates of the seismic hazard. This suggests that our complex model building has led to reasonable estimates of the seismic hazard at the sites being investigated.

One of the ways to evaluate our results would be to compare them with those from a deterministic technique such as the tectonic-province approach. (Any continental body can be divided into regions of similar seismic properties, called tectonic provinces.) In such an approach, estimates are made of what

Fig. 6

Measurements of peak acceleration in the Imperial Valley earthquake of October 15, 1979, plotted as a function of distance from the fault. The scatter in the data for even this recent and well-instrumented event illustrates one of the factors contributing to the uncertainties in estimating seismic hazard. (The colored band is the region within one standard deviation of the mean.)

Fig. 7

Estimates of seismic response at a single site, calculated from the input of various independent experts and plotted separately on logarithmic scales for four parameters: displacement, velocity, acceleration, and period. Although the experts differed greatly on the magnitudes of some of the input parameters, the application of our uniform-hazard model greatly reduced the range of disputed opinion and brought the response curves into substantial agreement.

would happen at the site in question if the largest historical earthquake in the province were to be repeated within 10 to 15 km of the plant; estimates also are made of the effects at the site of repeating the largest historical earthquakes in adjacent provinces (as

determined in previous NRC licensing positions) at the province boundary closest to the site.³ The largest estimated ground motion at the site from these different earthquakes determines the seismic input to design. Table 2 lists the magnitudes and distances of the

Table 2 Hypothetical controlling earthquakes used by the NRC to estimate the earthquake hazard at nine nuclear power plants located in the eastern U.S. (see Fig. 2) for comparison with our probabilistic estimates. Local earthquakes all had the same magnitude and were evaluated at the same epicentral distance. Distant historic earthquakes were evaluated at the closest tectonic-province boundary. (The body-wave magnitude, m_b , is defined for compressional waves at teleseismic distances.)

Site	Local earthquakes		Distant earthquakes	
	Magnitude, m_b	Distance, km	Magnitude, m_b	Distance, km
1. Yankee Rowe	5.3	10-15	6.0 (White Mt.)	80
2. Haddam Neck	5.3	10-15	6.0 (White Mt.)	130
3. Millstone	5.3	10-15	6.0 (White Mt.)	140
4. Oyster Creek	5.3	10-15	6.0 (White Mt.)	375
			5.8 (S. Valley)	550
5. Ginna	5.3	10-15	5.75 (Clarendon) ^a	55
6. Dresden	5.3	10-15	7.5 (New Madrid)	280
			6.7 (Wabash)	200
7. Palisades	5.3	10-15	7.5 (New Madrid)	315
			6.7 (Wabash)	300
8. LaCrosse	5.3	10-15	7.5 (New Madrid)	600
			6.7 (Wabash)	530
9. Big Rock Point	5.3	10-15	7.5 (New Madrid)	760
			6.7 (Wabash)	650

^aClarendon-Linden fault.

Table 3 Predicted peak accelerations and velocities at nine nuclear reactor sites in the eastern U.S. produced by two different estimation techniques, a deterministic modified tectonic-province method and the probabilistic uniform-hazard approach. The deterministic method tends to suppress individual differences among sites located in the same tectonic province whereas the uniform-hazard approach produces values that more realistically reflect the differing seismic characteristics of the various sites.

Site	Acceleration, cm/s^2		Velocity, cm/s	
	Deterministic	Probabilistic	Deterministic	Probabilistic
1	123	195	11	22
2	123	202	9	20
3	123	184	9	18
4	123	161	9	18
5	132	169	10	17
6	132	124	20	16
7	132	102	12	15
8	132	91	9	14
9	132	81	9	11

controlling earthquakes for each of the nine sites considered in this study (see Fig. 2).

Using these events, the NRC then applied a series of theoretical and empirical equations to predict the peak accelerations and velocities at each site. To deal with differences in these equations, the NRC investigators averaged selected results representing the most appropriate theoretical and empirical relationships to arrive at final estimates of peak acceleration and velocity. Table 3 shows the controlling largest peak accelerations and velocities estimated at each site and compares them with the peaks associated with our probabilistic uniform-hazard spectra.

Comparison of Probabilistic and Deterministic Results

The peak accelerations estimated from our uniform-hazard approach equal or exceed those of the deterministic approach at most of the sites. The exceptions are four sites that lie in areas of low seismicity and low estimated seismic hazard. The uniform-hazard peak velocities are almost all larger than the deterministic peak velocities because probabilistic techniques take into account larger-than-historical earthquakes that, according to sensitivity studies, have a disproportionate effect on peak velocities. In general, the 1000-year uniform-hazard peaks bracket the deterministic peaks, indicating substantial agreement.

Differences between the two sets of values result from the ability of the uniform-hazard approach to overcome the artificial constraints posed by the tectonic-province approach. Thus, according to the deterministic methods, sites 2 and 9 are similarly situated and must use similar seismic input for design purposes, so that the estimated peak velocity for both would be 9 cm/s (Table 3). The probabilistic approach, in contrast, takes into account the real difference in seismicity and perceived earthquake hazard at these two sites,

making the estimated peak velocity at site 2 almost twice that at site 9.

Conclusions

The most significant result of this ongoing study is our development of a valid method for supplementing the sparse seismic data available for nuclear reactor sites in the eastern United States with expert judgment and insight. Our estimates of the seismic hazard at the sites investigated are in reasonable agreement with the historical earthquake record. Because there is no way to verify our results directly, they may be interpreted as giving only the relative hazard at the various sites. □

Key Words: earthquake—New Madrid, San Francisco; expert-opinion technology; Nuclear Regulatory Commission (NRC); Nuclear Systems Safety Program (NSSP); probabilistic hazard evaluation; tectonic province; Uniform Hazard Methodology.

Notes and References

1. This simultaneous threat and its effect on all aspects of seismic safety was discussed in *Energy and Technology Review* for April 1982 (UCRL-52000-82-4), p. 1.
2. U.S. Nuclear Regulatory Commission, NUREG/CR-1582, "Seismic Hazard Analysis," 5 Volumes.
Volume 1, "Overview and Executive Summary," D. L. Bernreuter and C. Minichino, Lawrence Livermore National Laboratory (1983).
Volume 2, "A Methodology for the Eastern U.S.," Lawrence Livermore National Laboratory/TERA Corporation (1980).
Volume 3, "Solicitation of Expert Opinion," Lawrence Livermore National Laboratory (1980).
Volume 4, "Application of Methodology, Results and Sensitivity Studies," D. L. Bernreuter, Lawrence Livermore National Laboratory (1981).
Volume 5, "Review Panel, Ground Motion Panel and Feedback Results," D. L. Bernreuter, Lawrence Livermore National Laboratory (1981).
3. L. Reiter and R. E. Jackson, "Seismic Hazards Review for the Systematic Evaluation Program—Use of Probability in Decision Making," U.S. Nuclear Regulatory Commission, Document NUREG-0967 (1983).

Reactor-Coolant Piping: Realistic Failure Assessment

Our failure-mode analysis of reactor-coolant piping suggests that current design criteria are overly severe. Substituting more realistic guidelines would produce substantial savings without compromising plant safety.

For further information contact
Garry S. Holman (415) 423-4981.

In following the guidelines and regulations of the U.S. Nuclear Regulatory Commission (NRC), the nuclear industry has been basing its power-plant designs on the predicted effects of the largest possible loss-of-coolant accident, the double-ended guillotine break (DEGB) of the largest reactor-coolant pipe (Fig. 1). A DEGB involves instantaneous pipe breakage, with the broken ends offset to let the highly pressurized and heated water gush out unimpeded. Designers of nuclear power plants have generally contended both that such an accident is extremely unlikely and that its effects would be more severe than those of any other break or leak.

The possibility of a DEGB controls many aspects of plant design. For example, the emergency core-cooling systems must have enough capacity to keep up with the DEGB's rapid coolant-loss rate. A DEGB would pressurize the containment building with high-temperature steam, creating an extreme environment in which safety-related

mechanical and electrical components must continue to function.

Furthermore, increases in pressure and temperature following a loss-of-coolant accident would place additional loads on the reactor containment building. The escaping jet of boiling water would violently batter all structures and components in its path and induce tremendous reaction loads at pipe and component supports. If unrestrained, the broken pipe ends could whip about and cause additional damage.

Current NRC requirements stipulate that pipes inside the containment building must be restrained against whip caused by any break, at their ends as well as in between. Such restraints are always numerous (90 to 100 of them on primary coolant piping alone in a typical boiling-water reactor plant) and are often complex and massive, congesting the already cramped confines of a typical reactor containment building. These pipe-whip restraints represent a major capital cost for a new plant, and, because routine in-service examination of critical

welds sometimes means removing and reinstalling them, often to close tolerances, they increase personnel radiation exposure and plant maintenance costs.

Another important NRC requirement is that safety-related items must be designed to withstand the combined effects of a DEGB and a safe-shutdown earthquake (SSE), the maximum potential earthquake postulated for a reactor site. This further requirement became controversial in recent years when the postulated DEGB and SSE loads were doubled to allow for such phenomena as asymmetric-blowdown loads on the reactor vessel and the reactor's internal equipment. (If only one pipe breaks, the sideways thrust caused by blowdown through this broken pipe will be asymmetric and will place severe stresses on the reactor vessel.) This change made it much more difficult and costly to implement the load-combination requirement, particularly in the design of the reactor's internal structures and support systems.

In addition, concerns arose that designing for such unlikely and extreme loads could be counterproductive, reducing reliability during normal plant operation. For example, present seismic design methods tend to produce relatively stiff systems with multiple supports, which means that the cyclic thermal stresses under normal operating temperatures are greater than in a system that is more flexible. Restriction of pipe movement at an improperly designed or installed pipe-whip restraint could have similar effects.

In view of these factors, the NRC is beginning to reassess its design requirements related to pipe break through our Load Combination Program conducted as part of the Laboratory's Nuclear Systems Safety Program. We are performing independent probabilistic analyses to improve the technical basis for this reassessment. Only the NRC can decide how our results will ultimately affect nuclear-power-plant regulations, but our research provides a realistic technical foundation on which they can base their decisions.

In our studies, we examine both direct and indirect modes of DEGB. The direct mode involves cracks that grow, usually in the welds, from the combined effects of cyclic loads (e.g., temperature, pressure, flexure) and from corrosion. The indirect mode addresses seismically induced secondary causes such as the failure of supports for massive components. If it can be shown that the loads imposed by an earthquake will not induce a DEGB, then the two can be considered independent random events whose probability of occurring together

Fig. 1

Reactor-coolant pipe and pipe-whip restraint in a nuclear power plant. A typical weld (the broad, light gray band) can be seen to the right of the band in this pipe. These pipes can be viewed only when the reactor is shut down. During plant operation, all monitoring and leak detection must be done remotely by instruments.

is negligible. This would make it possible to remove the design requirement that DEGB and SSE loads be combined.

If it could be established that the DEGB itself has a negligible probability, this would have even further reaching consequences. Pipe and component supports could be designed for reduced reaction loads. Loads due to jet impingement, as well as the environmental effects caused by a loss-of-coolant accident, could be modified accordingly. Pipe-whip restraints could be eliminated altogether; without a double-ended break, the pipe would at least hang together. This last benefit would apply to operating plants as well, because pipe restraints removed for routine weld inspection would not have to be reinstalled.

Probabilistic analyses of overall nuclear-power-plant risk¹ have indicated that smaller pipe breaks, being more probable, may pose a greater risk than a DEGB in a main reactor-coolant pipe.

Nevertheless, the main coolant pipes are of the most immediate interest for our NRC confirmatory research because their failure would generate the most severe loads. Although we have limited our present study accordingly, we believe that our probabilistic methods of analysis (see the box on p. 15) are applicable to assessments of the probability of breaks in other piping systems.

Scope of the Study

We have concentrated on estimating the probability of a DEGB in the reactor-coolant-loop piping of pressurized-water reactor (PWR) systems manufactured by Westinghouse and by Combustion Engineering. A similar assessment of the reactor-cooling-loop piping in Babcock and Wilcox reactors, now in progress, will complete our generic study of PWR plants. We have begun a study of primary coolant piping in the generically different boiling-water reactor (BWR) plants manufactured by General Electric.

Fig. 2

(a) Typical four-loop Westinghouse pressurized-water reactor showing the stainless steel reactor-coolant-loop piping (color). These pipes are about 75 cm in diameter with walls more than 6 cm thick, and the water inside them is pressurized to 15.4 MPa at a temperature of up to 310°C. (b) Typical two-loop nuclear steam-supply system designed by Combustion Engineering. In all but one of these plants, the reactor-coolant piping (color) is made of carbon steel, ranging in diameter from 76 to 106 cm with wall thicknesses up to 9.5 cm. Pressures and temperatures are slightly higher than in the Westinghouse plants.

The principal components of a typical four-loop Westinghouse system are the reactor pressure vessel, the four steam generators, and the four reactor-coolant pumps (Fig. 2a). Each reactor-coolant loop consists of a hot leg from the pressure vessel to the steam generator, a crossover pipe connecting the steam generator and the coolant pump, and a cold leg between the coolant pump and the reactor pressure vessel. The primary piping, nozzles, and fittings are fabricated from various grades of cast and wrought stainless steel, principally

Type 304. All four loops are identical, except for the pressurizer connection on one (the pressurizer controls the amount of fluid in the primary system). Neither the pressurizer nor the interconnecting surge line is included in our present study.

The system manufactured by Combustion Engineering differs from the Westinghouse system mainly in that it uses only two steam generators. The reactor-coolant-loop piping (Fig. 2b) includes a single hot leg, two suction legs (crossover legs), and two discharge legs

Probabilistic Methods of Analysis

Over the past several years, probabilistic techniques have gained increased acceptance for analyzing the safety of all kinds of complex systems, including nuclear power plants. In contrast to deterministic methods, which consider fixed values of the parameters affecting safety, probabilistic techniques use parameter distributions to provide more realistic assessments of design adequacy.

In essence, a typical deterministic calculation directly compares the strength of a component and the anticipated stresses that will be applied to it. The component is judged to be adequate if its strength exceeds the stress, inadequate if it does not. According to the guidelines of the ASME Code,² the analysis should combine conservatively low values of strength with worst-case loads to provide a safety margin. This margin allows for deviations in the actual material strength, variations in the actual load conditions, approximations in the methods used to calculate component stresses, and additional factors not explicitly considered in the analysis.

The probabilistic approach substitutes randomly varying values for the fixed lower- and upper-bound values of the deterministic calculations, explicitly taking variations in strength and applied stress (including occurrence rates) into consideration. The area where the statistical distributions of these variables overlap defines the probability that stress exceeds strength (i.e., that the component will fail). Therefore, instead of setting out to determine the safety margin of a design, we now determine its reliability. The design is considered safe if the probability of failure is acceptably low.

Deciding what constitutes an acceptably low failure probability is a matter of judgment, usually taking into account the potential consequences of failure. The more

serious the consequences, the lower the tolerable failure probability and the more stringent the regulations designed to prevent failures. This is the fundamental logic underlying the risk-management concept of safety.

The distinction between deterministic and probabilistic approaches is even more pronounced if there are many design parameters involved in the calculation. The more parameters involved, the more conservative (or overconservative) a deterministic analysis becomes because each additional safety factor compounds with the others. Probabilistic analyses avoid the compounding effect by statistically distributing each parameter, thereby yielding more realistic results.

Moreover, sensitivity studies based on the probabilistic approach can give important information about unsound design areas and about how each parameter influences the overall reliability of a design. Uncertainty analyses can establish how the uncertainties in input data or in modeling techniques affect the estimated probability of failure. For example, it was a sensitivity study that showed how piping systems designed for combined DEGB and SSE loads could be too stiff to yield gracefully to normal temperature changes. Uncertainty analyses can show which parameters are critical and must be known precisely and which ones can remain uncertain because their precise values make little difference.

The probabilistic approach, because of these desirable capabilities, is being used increasingly in many engineering fields. Nevertheless, the deterministic approach still plays an important role, especially when there is inadequate data for constructing the statistical distributions needed in the probabilistic approach. Thus, deterministic and probabilistic approaches complement each other for assessing design reliability.

(cold legs). The reactor-coolant-loop piping in all but one of the Combustion Engineering plants is fabricated from Type SA516 Grade 70 carbon steel with stainless steel cladding 3.2 mm thick.

The pressure on the primary coolant in all these plants is about 15.5 MPa, and the temperature is about 300°C. Pipe diameters range from 70 to 106 cm, and wall thicknesses range from 6 to 10 cm. The actual number of weld joints may vary slightly from plant to plant. Because it is so stiff, the reactor-coolant piping in both systems is supported solely by the major loop components, without additional spring- or constant-load hangers.

Probability of a Direct DEGB

The postulated mechanism leading to a direct DEGB in the reactor-coolant piping is the growth of cracks at the welded joints. Improper welding or heat treatment during assembly can cause cracks before plant operation, or cracks can develop later through corrosion. If they are allowed to grow unchecked, such cracks could penetrate the pipe wall, causing leaks or even a pipe break. It is important, therefore, both to understand how cracks grow and to be able to detect and monitor existing cracks during plant operation.

Fig. 3

Distributions of (a) initial crack depth and (b) aspect ratio at plant startup (assuming there is any crack), plotted as the percentage of cracks having a given aspect ratio (or greater) vs the aspect ratio. There will almost certainly be very small cracks, but these can grow throughout a plant's operating life (forty years) without posing a threat of pipe break. Upper and lower bounds represent ranges used in our uncertainty analyses.

Crack Growth

Two of the major input factors in our estimates of the probability of a direct DEGB are the depth and length distributions of as-manufactured cracks. We base our crack-depth distribution on investigations of cracks actually found in nuclear and nonnuclear vessels in this country and the United Kingdom.³ From this distribution, we see, for example, that fewer than one crack in a thousand will have an initial depth greater than 5 cm. The probability of smaller initial cracks is significantly higher, but very small cracks can grow throughout a plant's life (forty years) without ever posing a threat to pipe reliability.

Figure 3 illustrates the conditional probability of a crack having a certain depth (given that a crack exists) at plant startup. When we multiply this result by the probability that there is any crack in a certain volume of weld material, we obtain the absolute probability of having a crack greater than this depth. Distributions of crack length, usually expressed in terms of the aspect ratio (the ratio of half-length to depth), are similarly defined.

Various nondestructive inspection methods, such as ultrasound, allow us to detect and monitor cracks and repair them before they cause a leak or break. No one method is 100% effective, however; each misses some cracks. We express the detection probability as a function of crack depth, based on direct laboratory comparisons of destructive and nondestructive examinations of preflawed test specimens. Our analyses include the effects of preservice inspection on the probability of a DEGB. We also can include the effects of in-service inspection, but we have neglected these in our PWR studies because the quality of such inspections varies greatly from plant to plant and therefore cannot be modeled with reasonable confidence.

The crack-growth characteristics of the pipe material and the loads applied to the pipe govern the rate at which a crack propagates through the pipe wall. Factors affecting crack growth include fatigue, corrosion, and sudden extreme loads (such as earthquakes). Fatigue cracking depends largely on the magnitude and

occurrence rate of cyclic thermal stresses that a plant experiences during normal operation. Stress-corrosion cracking depends on the alloy content of the pipe material and on other factors including water chemistry (particularly dissolved oxygen content), residual stresses at weld joints, and weakening or brittleness caused by improper heat treatment during and after welding.

Assuming circumferential (crosswise) semielliptical cracks, we calculate increases in crack length and depth using well-established techniques of linear-elastic fracture mechanics. Both fatigue growth per stress cycle and time-dependent stress-corrosion growth are correlated empirically to the local loads at the crack tip, expressed in terms of a stress-intensity factor. The stress-intensity factor, in turn, depends on the stresses applied to the weld joint being considered, including stresses due to earthquakes.

Both the intensity of an earthquake and its probability of occurrence determine its effect on the probability of a DEGB. We take the manufacturer's design stresses for the safe shutdown earthquake, modify them to account for the inherent conservatism in design calculations, and then define stresses for larger and smaller earthquakes based on an assumed linear relationship between peak ground acceleration and stress magnitude. (Because SSE stresses are usually below the elastic limit of the pipe material, this is a valid assumption for smaller earthquakes. The assumption is conservative for larger earthquakes because it neglects yielding that can partially relieve stresses.) The probability that an earthquake exceeding a given ground acceleration would occur at the plant site defines the probability that seismically induced stresses would actually occur.

Leak Detection

Many designers contend that the materials used in reactor-coolant pipes are so tough that even a crack through the pipe wall large enough to cause a detectable leak will grow only slowly. Early detection of coolant leaking through such a crack would make it

possible to repair the crack and prevent a DEGB. In our analyses, we first consider the probability that a leak will not be detected as a function of the calculated flow rate through the crack. We then assess how the leak-detection capability affects the probability of a DEGB. We also estimate the probability that the pipe will leak without breaking apart.

To determine when a crack has grown large enough to cause a DEGB, we must take into account the appropriate failure mechanism of the pipe material in question. The most likely failure mechanism in the ductile stainless steel used in Westinghouse reactor piping is net section collapse, which occurs when the stress in the uncracked part of the pipe at the break exceeds the material flow stress. In the carbon steel used in Combustion Engineering reactor piping, the predominant failure mechanism is tearing instability, which also has to do with ductile failure.

PRAISE

Figure 4 is a flow diagram for PRAISE (Piping Reliability Assessment Including Seismic Events), a Monte Carlo simulation code we developed to take the factors discussed above (and others) into account and calculate the probability of a direct DEGB. A typical PRAISE calculation may include several thousand replications for each welded joint. Each replication of the simulation starts with a single circumferential crack in the inside pipe surface; the initial crack depth and aspect ratio are each randomly selected from the appropriate probability density function. The simulation checks to determine whether an ultrasonic or hydrostatic test detects the crack before plant operation begins. If the crack is detected (in which case it would be repaired), the calculation starts over with a new assumed flaw.

If the crack goes undetected, the simulation subjects it to a typical stress history consisting of normal operating conditions, anticipated transients, and postulated earthquakes. PRAISE translates this stress history into stress-intensity factors at the crack tip, from which the crack-growth model for the particular pipe material ultimately

calculates the increases in crack size. For cracks that grow through the pipe wall, the code calculates the corresponding leak rate and uses this in conjunction with leak-detection models to determine whether the leak is large enough to be

detected and then repaired. If the leak is not detected, the DEGB failure criterion (based on either net section collapse or tearing instability) is used to determine whether the particular crack size leads to a DEGB.

After all PRAISE replications are completed for all weld joints of interest, we can estimate the DEGB probability for the entire piping system being considered. We typically express our results for all reactor-coolant loops over the full forty-year lifetime of the plant in terms of the probability of one DEGB per reactor year.

Many of the models in PRAISE—crack growth and leak rate among them—are deterministic. Thus, a probabilistic code like PRAISE provides a framework in which we can run thousands of deterministic calculations and reduce their results to a single parameter—failure probability—on which we can judge design reliability. In addition, PRAISE enables us to perform uncertainty and sensitivity evaluations that are beyond the capabilities of more usual methods.

PWR Plant Analyses

We began our analysis of Westinghouse PWR plants with a pilot study of Unit 1 of the Zion nuclear power plant (in Zion, Illinois, about 65 km north of Chicago) operated by Commonwealth Edison. We developed fracture-mechanics assessment methods and conducted extensive sensitivity studies to identify the key parameters affecting the probability of a DEGB. We also conducted uncertainty analyses to establish how the uncertainties in the input parameters affect the final DEGB probability.

After completing the Zion study, we made a generic evaluation of DEGB probability for other Westinghouse plants. We grouped closely similar plants, thus avoiding the need to perform a separate analysis for each. In this generic study, we calculated best estimates for 17 plants deemed representative of all the Westinghouse PWR plants east of the Rocky Mountains. (We assessed the Westinghouse PWR plants on the west

Fig. 4

Flow chart showing how the PRAISE Monte Carlo code estimates the probability of a direct DEGB. PRAISE uses both generic input such as crack-growth relationships for various pipe materials and site-specific information such as seismic stress probabilities at pipe welds.

coast site by site because there are so few and because seismicity varies so widely in the region.)

Results

From our results, we concluded that the median probability of a direct DEGB is very low for the eastern plants, about 10^{-12} events per reactor year, or one event per trillion reactor years (Fig. 5a). To establish confidence bounds on the overall probability of a DEGB, we attached confidence bounds on the five parameters revealed by our Zion study to most significantly affect the probability of a DEGB (initial crack depth, initial crack length, thermal stresses, seismic loads, and seismic hazard). Our worst-case result, derived from upper-bound values of all parameters and taken at a 90% statistical confidence limit, was still only about 10^{-10} events per reactor year, or less than one event per ten billion reactor years.

The results of this generic study of eastern Westinghouse plants indicate that the probability that an earthquake will cause a direct DEGB in the reactor-coolant-loop piping is negligible. Even earthquakes several times the intensity of the SSE increase the probability of a DEGB by less than ten times the value calculated assuming no earthquakes at all. Therefore, even though we have not yet completed our evaluation of Westinghouse west-coast PWR plants, we expect that the higher seismicity of this region will have no dramatic effect on the probability of a direct DEGB in the reactor-coolant piping.

We also estimated the probability of a leak without a DEGB for the eastern Westinghouse plants (Fig. 5b) and determined that a leak is at least a thousand times more likely than a DEGB. This finding supports the view that DEGBs may be prevented by early leak detection and repair.

The results of our generic study of Combustion Engineering plants indicate that the probability of a direct DEGB in their reactor-coolant-loop piping is equally low (Table 1). The probability of a DEGB for the carbon-steel piping used in these plants is higher than that for the more ductile stainless steel piping used

in Westinghouse plants if we neglected the effects of nondestructive inspection. However, because cracks are easier to detect in carbon steel than in stainless steel, the improved detection capability roughly equalizes the direct-DEGB probabilities for the two reactor-coolant systems. This clearly illustrates the ability of probabilistic techniques to determine

Fig. 5

The probability of a direct DEGB (a) or a leak (b) in the reactor-coolant-loop piping of Westinghouse plants east of the Rocky Mountains. We performed best-estimate evaluations of 17 plants deemed representative of all Westinghouse plants in this region. By carrying uncertainties in a few governing parameters all the way through the calculation, we were able to establish confidence limits (10 and 90%) on our estimated leak and DEGB probabilities. The significantly higher probability in (b) suggests that it is valid to assume that piping will almost always leak detectably before breaking, making it possible to prevent a DEGB by shutting down the plant and repairing the pipe.

Table 1 Best-estimate probabilities of a leak and a direct double-ended guillotine break for Combustion Engineering nuclear power plants.

Plant	Events per reactor year	
	Leak	DEGB
Palo Verde 1, 2, 3	1.5×10^{-8}	4.6×10^{-13}
San Onofre 2, 3	2.2×10^{-8}	1.0×10^{-13}
WPPSS 3	1.8×10^{-8}	6.1×10^{-12}
Waterford	1.8×10^{-8}	9.0×10^{-12}
Other Combustion Engineering plants	2.1×10^{-8}	5.5×10^{-12}

Fig. 6

Schematic representation of a DEGB induced indirectly by an earthquake. A seismic event could break a crane or the supports of a critical piece of equipment and this failure could, in turn, break the reactor-coolant piping.

how the interaction of seemingly unrelated parameters can affect overall pipe reliability.

The results of our study also indicated that the probability that an earthquake will cause a direct DEGB in a Combustion Engineering plant is as negligible as it is for the eastern Westinghouse plants.

Probability of an Indirect DEGB

Although we conclude that earthquake contributions to a direct DEGB in reactor-coolant-loop piping are insignificant, we must also consider the possibility that an earthquake might topple some other component that would, in turn, break a reactor-coolant pipe and thereby indirectly cause a DEGB (Fig. 6).

To evaluate the probability of an indirect DEGB, we identify critical components, such as supports for heavy pumps, and determine for each the seismic fragility (i.e., the relation between its seismic response and its probability of failure). Next, we determine for each component the probability that its failure will lead to a DEGB. Finally, we combine the earthquake probability distribution for the reactor site with the plant's overall fragility (derived from the individual component fragilities) and estimate the absolute probability of an indirect DEGB.

In our studies of Westinghouse and Combustion Engineering plants, we included only those elements whose failure could contribute significantly to the probability of an indirectly induced DEGB. The critical components we identified in our Zion pilot study included the overhead crane, the supports for the steam generator, the reactor-coolant pump, and the reactor pressure vessel. For each, we identified the modes of failure and calculated the seismic fragility. We also determined the response of each critical support element to dead loads, thermal loads, and seismic loads, and computed the median factor of safety against seismic failure and the standard deviations representing randomness and uncertainty.

In our study of the rest of the Westinghouse and Combustion Engineering plants, we evaluated fragilities using information on equipment failure modes, design margins, and seismic response supplied to us by the reactor vendors and plant owners. Because design calculations are inherently conservative (to account for such indeterminate factors as soil response, modeling assumptions, and structural damping, among others), we applied reasonable correction factors to these design margins to obtain a best estimate of the actual seismic capacity of the equipment. For each component, we then combined the probability distributions of its capacity with the seismic response to obtain a fragility curve (Fig. 7a) describing the probability of component failure as a function of peak ground acceleration.

Next, we established the conditional probability of a DEGB given the failure of each component. For example, assume that the trolley falls from the overhead crane. If the trolley misses the reactor pressure vessel, the coolant pipes, the pumps, and the steam generators, no DEGB results. Considering only the layout of the Zion plant and assuming that all positions of the crane are equally likely, a falling crane trolley would have only about one chance in seven of causing a DEGB. (In reality, even this figure is conservative because the crane is parked away from the critical components during plant operation.)

Although there is evidence that the coolant pipes could be seriously deformed without breaking, we made the conservative assumption that failure of the supports for any critical component (e.g., the steam generator) would always cause a DEGB.

After multiplying each component's fragility by the appropriate conditional probability of a DEGB, we combined the resultant modified fragilities into a single plant fragility describing the probability that any component failure resulting in a DEGB will occur for a given peak ground acceleration. We then convolved this result with the seismic hazard of the site to yield the absolute probability of an indirect DEGB.

Earthquake Hazard

Seismic hazard is defined as the probability of occurrence of an earthquake that exceeds a given intensity. In estimating the seismic hazard, we take into account the earthquake history of the region, zones of potential future earthquakes, and the attenuation characteristics of the regional geology at a reactor site. The result is a set of seismic-hazard curves (Fig. 7b) plotting the annual probability of exceedance as a function of peak ground acceleration.

As part of our study of Westinghouse PWR plants, we developed a set of generic seismic-hazard curves that are characteristic for all sites east of the Rocky Mountains (see the article on p. 1). We used these same generic curves, where applicable, for the Combustion Engineering plants. Plants located on the more seismically active west coast were assessed using site-specific seismic-hazard information.

Fig. 7

Steps in estimating the probability of an indirect DEGB. (a) We first determine the seismic fragility of critical supports or equipment and combine the results for individual components into a single plant fragility modified by the conditional probability (at confidence levels of 10, 50, and 90%) that a support or equipment failure will cause a DEGB. (b) Then, we establish the seismic hazard at the plant site. We combine this with the plant fragility to estimate the probability (again, at the three confidence levels) of an indirect DEGB. By carrying input uncertainties through the analysis, we can establish the uncertainty in our final results.

Our study of 46 Westinghouse plants located east of the Rocky Mountains indicated that an indirect DEGB is very unlikely. Our best estimate of the median probability of an indirect DEGB for these plants is about 10^{-7} events per reactor year, or one event in ten million reactor years (Table 2).

As part of this study, we selected and analyzed in greater detail two plants with higher-than-average seismic fragility, one that had originally been designed for combined SSE and DEGB loads and one that had been designed for the SSE alone. Even for these two plants, the maximum DEGB probability is only on the order of 10^{-5} , or one event per hundred thousand reactor years.

Interestingly, the results for these two plants imply that the reliability of heavy-component supports is as much a function of the particular analysis technique as it is of load combination. We found that the older plant, designed for the SSE alone, before the load-combination requirement went into effect, actually has a slightly lower probability of a DEGB than the more modern plant (one event every 400 000 reactor years vs every 300 000 reactor years). Apparently, the reduced conservatism, and therefore the greater realism, in the more sophisticated analysis methods used to design the newer plant offsets the effect of the more severe (i.e., combined) design loads, yielding a DEGB probability similar to that of the older plant.

Our site-specific evaluations of two west-coast plants indicate that the median probability of an indirect DEGB in their reactor-coolant loops is about three events per million reactor years, with an upper bound (90% confidence limit) of five events per million reactor years. These values are only about ten times higher than the corresponding generic probabilities for plants east of the Rocky Mountains and are similar to the indirect DEGB probabilities estimated for the two low-seismic-capacity eastern plants. The probabilities of an indirect DEGB for the Combustion Engineering plants that we evaluated typically were even lower than for the Westinghouse plants (Table 3).

Our analyses of indirect-DEGB probabilities assumed that all systems and components were correctly designed, fabricated, and installed. Because design and construction errors are a real possibility, however, it is important to assess their potential effect on the probability of a pipe break. In principle, we could treat design and construction errors probabilistically just like any other parameter but, since failures of heavy component supports are so rare, it may be impossible to develop a suitable distribution.

Therefore, we performed a limited sensitivity study to determine what degree of error would be required to significantly change the probability of an indirect DEGB. Although such a limited study cannot, by itself, resolve the important question of design and

Table 2 Comparison of best-estimate probabilities of an indirect double-ended guillotine break for all 46 Westinghouse nuclear power plants located east of the Rocky Mountains and for the two of these with the lowest seismic capacity (included in the 46-plant average).

Cases	Events per billion reactor years, confidence level		
	10%	Median	90%
Low-seismic-capacity plants designed for:			
SSE alone	1.0×10^{-7}	2.4×10^{-6} ¹	2.0×10^{-5}
SSE plus DEGB	2.3×10^{-7}	3.3×10^{-6}	2.3×10^{-5}
Average of all 46 units	2.0×10^{-9}	1.0×10^{-7}	7.0×10^{-6}

construction errors, the results are encouraging. They suggest that only gross errors (those that presumably would be detectable by the tight quality-control procedures associated with reactor-coolant piping) could make an indirect DEGB anything but extremely unlikely.

Replacing the DEGB

Elimination of the possibility of a DEGB as a design basis for the reactor-coolant piping would require the NRC to develop suitable replacement criteria for use in licensing new plants. The current trend in this area is toward defining a less severe but more likely standard pipe break, one with a more restricted flow area. The reduced flow rate would correspondingly reduce depressurization loads on the reactor pressure vessel and internal equipment, reaction loads on pipe and component supports, and jet impingement loads. It also would eliminate entirely the need to consider pipe whip in accident analyses.

In 1981, the Federal Republic of Germany established a regulatory

precedent for eliminating the DEGB in the design of reactor-coolant piping. Their current guidelines for PWR plants retain the DEGB as a design basis for areas benefiting from the DEGB requirement, e.g., the discharge capacity of emergency core-cooling systems, containment design pressures, and the environmental conditions affecting the performance of safety-related mechanical and electrical equipment.⁴ Jet impingement loads, support loads, and loads on the reactor pressure vessel and internal equipment, however, are now calculated on the basis of a reduced pipe break that takes 15 ms to open (vs the 1 ms specified in current NRC regulations) and has a flow area of 10% that of the affected pipe.

One must remember that reactor-coolant piping represents only a small fraction of the total piping in a typical PWR plant. However, it would be impractical to try to define specific regulations for each individual pipe system. If piping design criteria are to be applied realistically, we feel that they should focus, instead, on the causes of

Table 3 Best-estimate probabilities of an indirect double-ended guillotine break for Combustion Engineering nuclear power plants and west-coast Westinghouse plants.

Plant	Seismic-hazard curves	Events per reactor year, confidence level		
		10%	Median	90%
Combustion Engineering				
Palo Verde Units 1, 2, 3	Site-specific	4.0×10^{-19}	3.8×10^{-16}	1.0×10^{-13}
	Generic	2.4×10^{-12}	5.4×10^{-10}	1.1×10^{-7}
San Onofre Units 2, 3	Site-specific ^a	3.5×10^{-18}	4.6×10^{-17}	3.2×10^{-14}
	Site-specific ^a	5.0×10^{-17}	1.1×10^{-11}	2.1×10^{-9}
WPPSS 3	Site-specific	8.0×10^{-11}	2.9×10^{-9}	1.5×10^{-7}
Waterford	Generic	1.1×10^{-10}	1.3×10^{-8}	3.0×10^{-7}
Other Combustion Engineering plants	Generic	9.0×10^{-10}	6.6×10^{-8}	1.2×10^{-6}
		5.0×10^{-7}	1.4×10^{-6}	1.1×10^{-5}
Westinghouse (west-coast)	Site-specific ^a	3.1×10^{-10}	5.4×10^{-9}	9.5×10^{-7}
		1.3×10^{-7}	4.7×10^{-6}	4.9×10^{-5}

^aDifferent representations of the site-specific seismic hazard were used in the evaluation.

pipe break. Such criteria might require that particular adverse situations, such as unstable crack growth, be prevented; they might also identify contributory factors that a licensee would have to consider in demonstrating compliance. This would tell the license applicant what must be done, not how to do it, leaving him responsible for selecting and justifying an appropriate solution.

Summary and Conclusions

Our research at LLNL is providing technical information for the NRC to use in deciding whether eliminating the possibility of a double-ended guillotine break should be dropped as a design requirement for light-water reactor-coolant piping. Our probabilistic analyses indicate that the probability of a DEGB in the reactor-coolant-loop piping is very small for Westinghouse and Combustion Engineering pressurized-water reactor plants. These results further indicate that:

- The probability of an indirect DEGB caused by the seismically induced failure of heavy component supports is thousands of times greater than that of a DEGB caused by crack growth at welded joints and, thus, represents the dominant cause of a DEGB in PWR reactor-coolant piping.

- The probability that crack growth will cause a leak is at least a thousand times greater than the probability of a break, suggesting that cracks can be detected before or when they leak and repaired long before they cause the reactor-coolant piping to break.

- Large earthquakes increase the probability of a direct DEGB by less than one order of magnitude over the probability of a direct DEGB without earthquakes, indicating that the probability that a direct DEGB will result from a seismic event is negligibly low.

- Only gross design and construction errors—errors so large that they would be easily detected by standard quality-control procedures applied to reactor-coolant piping—could significantly change the probability of an indirect DEGB.

Our results indicate that a reevaluation of the DEGB design requirement for PWR reactor-coolant

piping is warranted. Related design requirements that also should be reevaluated include asymmetric blowdown, installation of pipe-whip restraints, and the coupling of the loads from a large loss-of-coolant accident and a safe-shutdown earthquake.

Early in 1984, we presented these results to the influential NRC Advisory Committee on Reactor Safeguards. Afterward, the Committee advised the NRC staff that ours is an "acceptable and proper" approach to the pipe-failure problem.⁵ Our results were subsequently referenced in a recent NRC decision allowing the Duke Power Company to decouple loss-of-coolant and safe-shutdown-earthquake loads.⁶ Although we expect our work eventually to influence NRC's generic design regulations, it is gratifying that we have already aided the NRC in making a near-term licensing decision affecting an individual plant.

The important influence that such research can have on the regulatory process should be even more apparent after we complete a similar evaluation of boiling-water reactor (BWR) plants. Corrosion cracking has been observed in the reactor-coolant piping of many older BWR plants, leading to plans to replace entire piping systems with corrosion-resistant piping at a cost of up to \$100 million per plant. Most of this cost is for replacement power that must be purchased during the projected six-month shutdown required to do the job according to present guidelines.

The NRC has commissioned our study on BWR power plants to help resolve licensing issues associated with pipe replacement. Among these are the improvement in reliability to be gained by using corrosion-resistant piping and the need to install pipe-whip restraints on the new piping. Our results may make it possible to justify performing the work in segments instead of all at once. This would extend pipe replacement over several normal refueling outages and eliminate the long shutdown, at a substantial cost saving.

The estimated cost of this BWR study is less than \$1 million, an insignificant amount compared with the potential

financial impact of the NRC's licensing decisions. By funding research such as ours, the NRC obtains a realistic basis for its important regulatory decisions, enabling it to protect public health and safety without burdening industry (and eventually the individual consumer) with unreasonable costs. □

Key Words: computer code—PRAISE; double-ended guillotine break (DEGB); loss-of-coolant accident (LOCA); Nuclear Regulatory Commission (NRC); Nuclear Systems Safety Program (NSSP); piping—reactor coolant; safe-shutdown earthquake (SSE).

Notes and References

1. For example, the well-known study by N. Rasmussen, *An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants*,

- U.S. Nuclear Regulatory Commission, Rept. WASH-1400 (NUREG-75/014) (1975).
2. *Boiler and Pressure Vessel Code*, American Society of Mechanical Engineers.
3. *An Assessment of the Integrity of PWR Pressure Vessels*, report by a study group commissioned by HRH Health and Safety Executive and chaired by W. Marshall, United Kingdom (October 1976).
4. *Guidelines for Pressurized Water Reactors*, prepared by the Reactor Safety Commission of the Federal Republic of Germany, 3rd Edition (October 1981).
5. J. J. Ray, Chairman of the Advisory Committee on Reactor Safeguards, in a letter to W. J. Dirks, Executive Director for Operations, U.S. Nuclear Regulatory Commission, on the subject of fracture-mechanics approach to pipe failure (June 14, 1983).
6. H. R. Denton, Director of the Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, in a letter to W. H. Owen, Executive Vice President, Duke Power Company, on the coupling of loads due to a loss-of-coolant accident and a safe-shutdown earthquake (October 17, 1983).

Human Factors in Reactor Facility Design

Our research in human-factors engineering is providing technical information for the Nuclear Regulatory Commission and the U.S. Department of Energy to use in improving their reactor-safety regulations and operations.

For further information contact
L. Rolf Peterson (415) 423-0952.

The accident at the Three Mile Island (TMI) power plant in March of 1979 was a turning point for the nuclear industry in this country. It provided valuable lessons for the Nuclear Regulatory Commission (NRC) and workers in the nuclear industry. It revealed, among other things, that human errors in operation and maintenance contribute significantly to the extent of damage to the reactor and the release of radioactive material in such an incident and that the design of the reactor's control room contributes to these human errors.

The accident at TMI is a striking example of the impact of human factors on safety at nuclear power plants. The main feedwater system had shut down and the valve controlling the auxiliary feedwater flow, the only backup water supply for removing heat from the primary reactor-coolant system, was closed. An indicator light that should have alerted the operators to this condition was on but they could not see it because it was covered by a maintenance tag hanging on the console. Thus, a poor design and operating practice (it should not have been possible

to obscure the operator's view of the indicator lights) led to a communication breakdown and blocked the simple procedures that would have prevented or decreased the severity of the accident.

From these lessons, the NRC identified several areas in which improvement was needed.^{1,2} These included operator training, maintenance practices and procedures, and human-factors engineering in the control room. The NRC funded major programs to ensure that these improvements would be made.

At the Laboratory, our Nuclear Systems Safety Program is assisting the NRC to resolve issues concerning human-factors engineering. Working with the NRC, we have developed guidelines for evaluating the design of reactor control rooms. For the past three years, audit teams from LLNL and the NRC have evaluated existing control rooms and proposed control-room designs throughout the country. We are also assisting with programs to apply human-factors engineering to Department of Energy (DOE) facilities.

Control-Room Reviews for the NRC

As a result of the TMI accident, the NRC now requires that each nuclear-power-plant licensee perform a detailed control-room design review. The purpose of this review is to identify and correct design features that interfere with normal operation and response to emergencies. A major objective of these corrections is to improve the information provided to the control-room operators to help them prevent accidents or cope with them if they occur.

Guidelines (NUREG 0700) prepared by the NRC with our assistance describe four phases of a control-room design review to be carried out by licensees¹: planning, review, assessment and implementation, and reporting. Figure 1 gives an overview of the phases of a control-room design review and the products required by each current and prospective licensee.

Elements of a Control-Room Design Review

The utility's required program plan must describe how the elements of its control-room design review will be implemented. The basic elements of such a review are described below.

Establishment of a qualified multidisciplinary review team. Each licensee must select a review team that encompasses a wide range of professional disciplines to fulfill the various review functions (technical task performance, project direction, administrative support, and documentation). A typical team would include a nuclear systems engineer, an engineer or architect with experience in control-room design, a senior reactor operator or operations technical advisor with operating experience, and a human-factors engineer. When this element of a licensee's control-room review is audited, we examine documents outlining the responsibilities of the review-team members, their resumes, and their procedures for carrying out the review. During site visits, we often interview review-team members for additional information.

Function and task analyses. The licensee must identify the tasks of a control-room operator and define the information and controls needed for emergency operations. We review these

Fig. 1

Overview of the phases and products involved in a detailed control-room design review.

functions to determine exactly how the control-room operator's tasks are organized. Our objective here is to establish the operator's input and output requirements, which then serve as benchmarks for an examination of the adequacy of control-room equipment, such as controls, data displays, and instrumentation.

Control-room inventory. The control-room inventory identifies all equipment within the control room. The licensee must compare this data set with the information and control requirements identified through the analysis of operator tasks and show that the available control-room equipment fills all operator needs.

Fig. 2

NRC guidelines identify human factors that must be reviewed when evaluating the design of nuclear-power-plant control rooms. (a) For example, for control and monitoring actions that must occur in sequence, all necessary controls and displays should be within the viewing range and

the maximum extended reach of the seated operator. (b) Verbal communications should be intelligible using normal or only slightly raised voice levels. (c) Manipulation of a control should not obscure the related display.

Control-room survey to identify deviations from accepted human-factors principles. The control-room survey is a systematic comparison of control-room design features with human-factors engineering guidelines and checklists developed by the NRC with our assistance. Audit teams observe and measure specific features of the control-room design to identify characteristics of equipment, instruments, room layout, or ambient conditions that may interfere with smooth operation and rapid and appropriate response to emergencies. Such features are called human-factors engineering discrepancies.

Figure 2 shows examples of human factors identified in the guidelines. These include the effect of sound levels on verbal communication and the correct placement of controls (within reach of most operators, neither too high nor too low on vertical panels, and near but below the related display so that the operator's hand remains out of the line of sight).

Assessment of human-factors engineering discrepancies to determine which are hazardous enough to demand correction. In this step, the licensee's reviewers identify those discrepancies associated with operator errors whose consequences could unacceptably reduce the plant's margin of safety.

Selection of design improvements to eliminate discrepancies. In this step, the reviewers screen human-factors engineering discrepancies to identify those that can be corrected by simple changes and those that require more sophisticated analysis. It is also possible in this step to choose among alternative ways of correcting a given discrepancy.

Verification that the selected design improvements will correct the original discrepancy without introducing new ones. This step provides for an investigation of the effectiveness of the proposed remedy and the elimination of cures that produce problems of their own.

Coordination of control-room improvements with changes introduced through other programs. Without this step, it might be possible

for various independent groups (such as programs for operator training or for upgrading emergency procedures), all with the common goal of improving reactor safety, to be working at cross purposes.

Control-room reviews encompass many factors that affect the overall operating effectiveness: the layout of the control room, the adequacy of the information provided the operator, the arrangement and identification of important controls and instrumentation displays, the usefulness of the audio and visual alarm systems, and the ease of recording and accessing information.

The NRC, with our assistance, evaluates the organization, process, and results of each control-room design review. This evaluation consists of reviews of the utility's documentation and site visits to audit the progress of its design-review programs.

Human-Factors Engineering Discrepancies

Although each control room is unique and presents its own set of human-factors engineering discrepancies, certain kinds of difficulties are typical. For example, most control rooms are very large, with many widely separated or awkwardly placed controls (Fig. 3). Their design is reminiscent of control systems that have served well in hydroelectric and fossil-fuel power-generating plants where emergencies may, at worst, deprive large numbers of customers of the power on which they have come to depend. This large size and awkward organization leads to excessive operator movement, with consequent confusion and chances for errors. In a reactor control room, where a mismanaged emergency can have severe environmental consequences, smooth and efficient operation is vital.

Another typical problem is poor layout and grouping of controls. As designers of aircraft cockpits learned long ago, all controls and indicators for a given function should be close to each other and separate from similar controls and indicators for other functions. (Flying a large aircraft, like operating a reactor,

involves long periods with little to do but monitor the equipment, interspersed with times when prompt and effective control is essential.) When designers rely on operator memory alone to associate indicators and controls (Fig. 4), the result is, all too often, an increase in operator errors.

Yet another common human-factors engineering discrepancy in many existing control rooms is the presence of outdated technology. For example, in an age of computers and pushbutton convenience, some controls are built so stiff that it takes both hands to operate one of them.

The use of familiar but outmoded techniques may make it easier for control-room designers, but it puts an unnecessary burden on the operators and reduces their efficiency.

Human-Factors Engineering for the DOE

The DOE has asked us to examine the status of human-factors engineering at DOE reactors and to develop a program for improvement. We are now preparing recommendations for such a program at DOE nuclear facilities to increase operational safety and to improve operating performance by reducing human errors. We are recommending that useful applications of human-factors engineering at DOE nuclear facilities be evaluated to improve the interfaces between the operating personnel and the systems they operate. The program plan also will recommend a human-factors engineering program to be implemented through DOE orders, administrative directives, or policy statements.

We are also preparing a standard plan for the review of human-factors engineering at existing DOE nuclear facilities by DOE field offices and contractors. This review plan will

Fig. 3

Typical discrepancies in human-factors engineering found in existing control rooms include (a) maintenance tags that obscure control switches and labels, (b) controls on a vertical console that are beyond

the view and reach of average-sized workers without requiring stretching or use of a stool or ladder, (c) telephones with short cords that hinder operator mobility.

recommend methods of identifying human-factors engineering discrepancies, assessing their importance, and determining appropriate corrections. The plan will contain recommendations for facility changes that can be implemented through simple enhancements and systems engineering modifications, as well as administrative and procedural improvements to reduce opportunities for human error in operations and maintenance.

Human-Factors Engineering Workshop

As a logical extension of our analyses and recommendations for the DOE, we recently developed a workshop introduction to human-factors engineering and its applications for DOE operations, engineering, and management personnel. In the workshop, participants are presented with the basic elements of a model human-factors engineering program and are walked through practical problem-solving exercises derived from conditions that workshop instructors have observed at commercial nuclear power plants and at DOE-owned nuclear facilities. Workshop participants review

photographs of human-factors engineering discrepancies identified in existing control rooms and learn simple ways of correcting them. For example, they learn that paint, labels, and tape provide inexpensive but effective and immediate ways of improving control-board clarity.

Another workshop exercise focuses on aids to effective job performance. One such aid is the use of improved manuals in which clear illustrations are cross-keyed to written instructions. Another is the replacement of complex blueprints (intelligible only to engineers) with cut-away drawings that maintenance personnel can interpret quickly and efficiently. Participants also learn how appropriate formats and styles of presentation can clarify written procedures and reduce the likelihood of human error.

These workshops also provide a forum for discussion of the dynamics and consequences of stress and other topics that are important to the broad application of human-factors engineering. Participants examine the three levels of operator behavior in the performance of their duties (skilled-based, rule-based, and knowledge- and reasoning-

Fig. 4

The location of controls, displays, and annunciator warning systems within a single panel should make the most effective use of the viewing and manual manipulative area. (a) Unsystematically placed controls and labels on a black panel. We have added the striped lines to show the various functional groups, which should be distinguished by spacing,

color coding, or other enhancement techniques. (b) Alarm panels that are not, but should be, located above the related controls and displays for easy association and prompt response. We have strung three tapes on this console to indicate which annunciator alarm pertains to which control.

based) and discuss appropriate contexts for recommending each level. Most routine tasks can be accomplished with only skill- and rule-based behavior, but it is important to provide enough information for the knowledge- and reasoning-based behavior required in emergencies.

Another important topic for exploration is the way that future developments in control-room technology will affect human-factors engineering.

Another important topic for exploration is the way that future developments in control-room technology will affect human-factors engineering. Already, we are beginning to see control rooms in which touch-panel controls replace rows of switches and knobs, and cathode-ray-tube displays replace banks of meters and warning lights and reams of wiring and plumbing diagrams.

These and other computer-related elements bring a shift in emphasis. Instead of having the operator walk back and forth, consulting meters and gauges to determine the status of the reactor and then going somewhere else to push the appropriate buttons, we have a stationary operator with information and controls brought within easy reach. The workshop deals with both the great potential and the flexibility introduced by this new technology and the resultant problems (such as operator boredom) that may arise.

Maintenance Guidelines

In another of our projects for the DOE, we are preparing comprehensive guidelines for human-factors engineering design in the maintenance of DOE nuclear facilities. These guidelines are intended to provide designers and design-review teams with human-factors engineering principles to enhance the design of nuclear facilities, to aid in the inspection of facilities, systems, and equipment, and to prevent human errors during system maintenance. A draft of the guidelines has been prepared and is being reviewed and field-tested by the DOE.

The guidelines focus on the design features that can potentially affect preventive and corrective maintenance. Prime consideration is given to making it easier, through the design of systems and equipment, for the technician to perform routine maintenance tasks such as inspection, troubleshooting, repair, adjustment, and servicing.

The overall objective of systems design for maintainability is to make the proper maintenance of equipment and systems as fast, easy, inexpensive, and safe as possible. Specific objectives include limiting the number of maintenance technicians required and reducing system down-time, the frequency of design-dictated maintenance (and consequent maintenance-support costs), and the potential for maintenance error. The guidelines we have developed provide the design team with general human-factors engineering principles to help satisfy these objectives. The guidelines are organized into three

(a)

(b)

(c)

Fig. 5

Principles governing systems design for engineered hardware. (a) Equipment should be divided into as many modules as electrically and mechanically feasible for efficient use of space and for overall equipment reliability. The replaceable units should be as functionally independent of each other as possible with minimum interaction among units. (b) Access

doors should be hinged on the bottom, or a latch should be provided to hold the door open, allowing the use of both hands. (c) Cable fanning permits easy maintenance, and proper cable routing avoids sharp bends and tripping hazards and allows quick and easy testing, repair, and replacement.

sections that correspond with the three major influences on system design for maintainability: engineered hardware, facility support, and personnel.

Engineered hardware. The engineering of hardware covers such* system features as unitization and modularization, the packaging and mounting of components within a system, and the accessibility of equipment. In subdividing complex equipment into easily replaceable modules, for example, it is important to make the individual units as functionally independent as possible and to minimize

interactions among units. In providing access to equipment, doors should either hinge down or latch upward; it should not be necessary to hold the access door open with one hand, leaving only one hand with which to perform the maintenance. These and other principles governing systems design for engineered hardware are illustrated in Fig. 5.

Facility support. Guidelines for facility support include recommendations for the appropriate design of hand tools, platform shelters, and working and storage areas to improve accessibility and ease of maintenance (Fig. 6). We

		Recommended dimensions, cm		
		Minimum	Best	Arctic
(A)	Two men passing abreast	107	137	152
(B)	Two men passing facing	76	91	91
Catwalk dimensions				
(C)	Height	160	165	190
(D)	Shoulder width	56	61	81
(E)	Walking width	30	38	38
(F)	Vertical entry hatch			
	Round or square	46	56	81
(G)	Horizontal entry hatch			
	Shoulder width	46	56	81
	Height	38	51	61
(H)	Crawl through pipe			
	Round or square	63	76	81
Supine workspace				
(I)	Height	51	61	66
(J)	Length	185	190	198
Squatting workspace				
(K)	Height	122	—	129
(L)	Width	69	91	102
	Optimum display area		69-109	
	Optimum control area		48-86	
Stooping workspace				
(M)	Width	91	102	112
	Optimum display area		81-122	
	Optimum control area		69-100	
Kneeling workspace				
(N)	Width	107	122	127
(O)	Height	142	—	150
(P)	Optimum work point		69	
	Optimum display area		71-112	
	Optimum control area		51-89	
Kneeling crawl space				
(Q)	Height	79	91	96
(R)	Length	150	—	157
Prone work or crawl space				
(S)	Height	43	51	61
(T)	Length	244	—	—

Fig. 6

Guidelines for facility support include recommendations for the design of workspace and storage areas. The minimum, best, and arctic dimensions

for spaces technicians are required to work in or pass through are given in the table. (Arctic dimensions allow room for bulky protective clothing.)

also make general recommendations on the design of computer rooms for maintainability. For example, computer systems should be housed in a well-lighted controlled environment with temperature, humidity, and noise levels maintained within specified ranges.

Personnel. The guidelines for personnel address topics related to human needs and abilities. Maintenance work is hard enough at its best; there is no justification for making it harder, more complex, or more uncomfortable than necessary. Figure 7 plots the effects of humidity and temperature on work efficiency. Figure 8 illustrates engineering anthropometry guidelines relating the design of tasks to the strength of the people who will be expected to perform them. Other topics within this area include the presentation of maintenance-related information and additional environmental conditions and constraints affecting maintainability such as light, noise, and vibration.

Fig. 7

The effects of temperature and humidity on the work efficiency of maintenance technicians. The working environment also should not exceed the tolerance limits for factors such as lighting, noise, and vibration.

Fig. 8

Engineering anthropometry guidelines relating the design of tasks to the strength of the people who perform them. Equipment, systems, and fac-

ilities should be designed for maintenance by technicians of normal strength. The table indicates appropriate strength limits for men.

Future Work

Our work on human-factors engineering is moving into new and related areas, including the review of systems for displaying safety parameters, study of the impact of computer use in control rooms, and assessment of the effects of earthquakes on control-room instruments and operator performance. We also expect to apply our human-factors engineering methods outside the nuclear-power-plant control room and to examine all aspects of reactor maintenance and operation where human-factors engineering is important. □

Key Words: control-room design review; human factors—engineering, discrepancy, safety; nuclear

reactor—design, safety; Nuclear Systems Safety Program (NSSP); Three Mile Island.

Notes and References

1. U.S. Nuclear Regulatory Commission, *NRC Action Plan Developed as a Result of the TMI-2 Accident* (NUREG-0660), Washington, D.C. (May 1980).
2. U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Division of Licensing, *Clarification of TMI Action Plan Requirements* (NUREG-0737), Washington, D.C. (November 1980) and Supplement 1 (December 1982).
3. U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Division of Human Factors Safety, *Guidelines for Control-Room Design Reviews* (NUREG-0700), Washington, D.C. (September 1981).

Earthquake-Hazard Analysis for Nuclear Power Plants

Studies have shown that strong shaking from an earthquake can pose serious hazards to components such as coolant loops, valves, and pumps that are critical to the safe operation of a nuclear power plant. The potential effects of an earthquake are thus an important set of considerations in siting, designing, and building such a plant. Assessing the seismic hazard at existing sites also is essential since it assures appropriate regulations for earthquake safety at operating plants. We are using a probabilistic approach with unique features to develop estimates of the seismic hazard at nine older plants in the northeastern United States.

Contact Don L. Bernreuter (415) 422-0305 or Dae H. Chung (415) 422-0268.

Reactor-Coolant Piping: Realistic Failure Assessment

Probabilistic analysis of the factors that can lead to failure of reactor-coolant piping have been made, with special emphasis on the possible role of seismic stresses. Results suggest that current Nuclear Regulatory Commission (NRC) regulations, which mandate that designs allow for a simultaneous earthquake and double-ended guillotine pipe break, are overly severe. Our findings indicate that the contribution of earthquake stresses to the frequency of pipe breaks caused by crack growth and the likelihood that a pipe will crack apart without first leaking detectably are both negligible. Revised NRC guidelines taking these findings into account would produce substantial savings without compromising plant safety.

Contact: Garry S. Holman (415) 423-4981.

Human Factors in Reactor Facility Design

Our Nuclear Systems Safety Program is helping the Nuclear Regulatory Commission (NRC) and the U.S. Department of Energy (DOE) in their efforts to improve reactor safety by supplying technical information on human-factors engineering, including ways to alleviate operator stress and reduce operator errors through enlightened control-room design. Human-factors engineering covers such topics as the proper placement of displays and controls to avoid operator errors and the provision of enough space around equipment for ease of maintenance. We are evaluating the detailed control-room design reviews that the NRC requires of licensees to identify and correct design discrepancies that could lead to accidents or interfere with effective management.

Contact: L. Rolf Peterson (415) 423-0952.

Recent Titles

Articles published in recent issues of the *Energy and Technology Review* are grouped below according to their chief sponsors, the Assistant Secretaries of the U.S. Department of Energy. Research funded by other Federal agencies is listed under Work for Others.

ENERGY RESEARCH

Computer Simulation of Particulate Flow (May 1984)
Energy-Flow Diagrams: An LLNL Contribution to Energy Analysis (May 1984)
Magma Evolution (May 1984)
Single-Chromosome Gene Libraries of Human DNA (Brief—May 1984)
High-Speed Cell Sorting: A Tenfold Increase in Sorting Rate (March 1984)
Visualizing Chromosomes in Human Sperm (March 1984)
Predictions of Atmospheric Carbon Dioxide: What Are the Uncertainties? (December 1983)

FOSSIL ENERGY

Dispersion Tests of Liquefied Gaseous Fuels (Brief—May 1984)
The Centolla Partial-Seam CRIP Test (Brief—March 1984)
The Chemistry of Oil Shale Processing (January 1984)
Hydraulic Fracturing and Methane Recovery in Coalbeds (December 1983)

DEFENSE PROGRAMS

Military Application

Raman Spectroscopy of Shocked Water (Brief—April 1984)
Silicone Cushions for Engineering Applications (April 1984)
Synchrotron-Radiation Research Facility (Brief—April 1984)
Artificial Intelligence in Chemical Analysis (February 1984)
Providing Innovative System Monitoring and Reliability Assessment
Through Microengineering (February 1984)
Toward a Science of Welding (February 1984)
Modeling Dynamic Consolidation in Metal Powders (January 1984)
Abrasive Superpolishing of Metal Optics (December 1983)

LABORATORY REVIEWS

LLNL in the Developing Livermore Valley (April 1984)
Preparing for the Super Supercomputers (March 1984)

WORK FOR OTHERS

Defense Advanced Research Projects Agency

Combustion Synthesis: A New Area of Research in Materials Science (January 1984)

Nuclear Regulatory Commission

Earthquake-Hazard Analysis for Nuclear Power Plants (June 1984)
Human Factors in Reactor Facility Design (June 1984)
Reactor-Coolant Piping: Realistic Failure Assessment (June 1984)

United States Geological Survey

The Strength of Ice (April 1984)