DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

EGG-EAST--9031

DE93 007045

SURVEY OF THERMAL-HYDRAULIC MODELS OF COMMERCIAL NUCLEAR POWER PLANTS

**J. C. Determan
C. E. Hendrix**

Published December 1992

**Idaho National Engineering Laboratory
EG&G Idaho, Inc.
Idaho Falls, Idaho 83415**

**Prepared for the
Division of Reactor Systems Safety
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
Under DOE Idaho Field Office
Contract DE-AC07-76ID01570
FIN A6328**

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ABSTRACT

A survey of existing nuclear power plant decks has been performed; data collected for decks at the Idaho National Engineering Laboratory, Los Alamos National Laboratory, and Code Applications and Maintenance Program members are presented. A PC based database used to hold the data is described. Recommendations for improvement of the NRC's analysis capability are presented.

CONTENTS

ABSTRACT	iii
SUMMARY	vii
ACKNOWLEDGEMENTS	ix
1. INTRODUCTION	1
2. GROUP CLASSIFICATION OF DOMESTIC LWRS	2
3. LIST OF THERMAL-HYDRAULIC MODELS	7
4. PC BASED DATABASE	11
5. REFERENCES	12
Appendix A—Data Gathered in the Survey	
Appendix B—Using the Database Programs	

TABLES

2-1. U.S. NPP categories	3
2-2. CAMP member NPPs in survey	6
3-1. List of thermal-hydraulic input decks	8
3-2. Input deck applications matrix	9

SUMMARY

A survey of the thermal-hydraulic models of nuclear power plants has been performed to identify the NRC's current analytical capabilities for critical event response. The survey also supports ongoing research for accident management.

The results of the survey are presented here. The PC database which records detailed data on each model is described.

ACKNOWLEDGEMENTS

The authors of this report would like to thank Don Fletcher, Dick Schultz, Ron Beelman, Phil Wheatley, John Burt, Bob Hanson, Len Ward, Chuck Dobbe, and Paul Bayless for their input to this document.

Survey of Thermal-Hydraulic Models of Commercial Nuclear Power Plants

1. INTRODUCTION

The NRC's response to critical events and its support of ongoing research depend on their current thermal-hydraulic modeling capability. Knowledge of the existence and capabilities of input decks of domestic light water reactors (LWRs) could greatly accelerate the NRC's analysis of critical events. This knowledge also helps identify the strengths and weaknesses of the NRC's present modeling capabilities.

The purpose of this report is to document the existence of nuclear power plant (NPP) input decks and to identify possible enhancements to the NRC's NPP modeling capability. This report is intended as a living document. Decks from the Idaho National Engineering Laboratory (INEL), Los Alamos National Laboratory (LANL), and the code applications and maintenance program (CAMP) members are currently incorporated. Methods for enhancing the NRC's modeling capability are presented. These suggested improvements are focused on the NRC's capability for modeling LWR systems with the RELAP5, TRAC-PF1, and TRAC-BD1 codes. A system for classifying the existing domestic LWRs into distinct groups of similar type, based on the August 28, 1980 letter by J. A. Dearien,¹ is presented as an aid to identifying the enhancements noted above.

Section 2 presents the LWR classification system. The input decks currently identified are listed in Section 3. Section 4 describes the PC based database used to store the data.

Appendix A presents the data for each plant currently included in the survey. Appendix B describes the use of the database and its associated programs.

2. GROUP CLASSIFICATION OF DOMESTIC LWRs

Domestic commercial LWRs fall into two broad categories: pressurized water reactors (PWR) or boiling water reactors (BWR). Domestic LWRs may be further classified by vendor. The BWRs are produced by General Electric (GE), and the PWRs are produced by Westinghouse (W), Combustion Engineering (CE), and Babcock and Wilcox (B&W). Each vendor has produced different reactor designs over the years, varying such things as the core size and coolant loop arrangement. LWRs with a common vendor and reactor design may be considered similar from a thermal-hydraulic modeling standpoint. A thermal-hydraulic model of one LWR may be applied to any similar LWR with only minor modifications to the model. Therefore, classifying domestic LWRs indicates the minimum set of thermal-hydraulic models needed to allow analysis of incidents at any domestic LWR quickly.

Domestic LWRs have been classified by J. A. Dearien^[1]; this system was modified to account for differences in fuel bundle design, and to correct errors in the original list^[2]. The principal parameters considered in grouping BWRs include: 1) nuclear steam supply system (NSSS) design; 2) number of fuel bundles; 3) vessel ID; 4) fuel bundle design; and, 5) containment design. The principal parameters considered in grouping PWRs include: 1) reactor vendor; 2) coolant loop design; 3) number of fuel bundles; 4) fuel bundle design; and, 5) containment design (Westinghouse PWRs only). Thermal power was not considered in grouping the plants because it depends primarily upon the number and design of the fuel bundles, and would be redundant. Table 2-1 lists the U.S. NPPs by group, states the distinguishing characteristics of each group, and indicates individual differences possessed by plants within the group. Table 2-2 provides the same information on foreign NPPs for which thermal-hydraulic input decks are available through CAMP. Comparing the entries in Table 2-1 will allow the analyst to estimate the level of effort needed to modify an input deck to represent a different plant in the same or a similar group.

Table 2-1. U.S. NPP categories.

Group	Plants in group	Group Description	Vessel ID (in.)	Coolant loops ^a	Number of bundles	Bundle design	Containment design ^b
General Electric							
G1	Big Rock Point	BWR/1	106		84	11 x 11	Steel sphere
G2	Oyster Creek Nine Mile Point 1	BWR/2	213		560	8 x 8	1
			213		532	8 x 8	1
G3	Monticello	Low Power BWR/3	205		484	8 x 8	1
G4	Millstone 1; Pilgrim 1	Medium Power BWR/3	224		580	8 x 8	1
G5	Quad Cities 1,2 Dresden 2,3	High Power BWR/3	251		724	8 x 8	1
			251		724	9 x 9	1
G6	Duane Arnold Vermont Yankee	Low Power BWR/4	183		368	8 x 8	1
			205		368	8 x 8	1
G7	FitzPatrick; Hatch 1,2 Brunswick 1,2 Cooper	Medium Power BWR/4	218		560	8 x 8	1
			218		560	8 x 8	1c
			218		548	8 x 8	1
G8	Browns Ferry 1,2,3; Peach Bottom 2,3 Fermi 2; Hope Creek 1 Limerick 1,2 Susquehanna 1,2	High Power BWR/4	251		764	8 x 8	1
			251		764	8 x 8	1
			251		764	8 x 8	2c
			251		764	9 x 9	2c
G9	WNP-2 LaSalle County 1,2; Nine Mile Point 2	BWR/5	251		764	9 x 9	2
			251		764	8 x 8	2c
G10	Clinton; River Bend	Low Power BWR/6	218		624	8 x 8	3
G11	Perry 1,2	Medium Power BWR/6	238		748	8 x 8	3
G12	Grand Gulf	High Power BWR/6	251		800	8 x 8	3

a. Applies to PWRs only

b. 1—Drywell and free standing torus

2—Over/under with free standing steel pressure vessel

3—Suppression pool type

1c—Drywell and concrete torus with steel liner

2c—Over/under steel liner inside concrete

Table 2-1. (continued).

Group	Plants in group	Group Description	Vessel ID (in.) ^a	Coolant loops	Number of bundles	Bundle design	Containment design
Westinghouse							
W1	South Texas Project 1,2	High Power 4 Loop		4	193	17 x 17 ^b	Dry
W2	Braidwood 1,2; Byron 1,2; Callaway; Conanche Peak 1,2; Millstone 3; Salem 1,2; Seabrook; Trojan; Vogtle 1,2; Wolf Creek; Diablo Canyon 1,2; Catawba 1,2; McGuire 1,2; Sequoyah 1,2; Watts Bar 1,2; Donald C. Cook 2	Medium Power 4 Loop		4	193	17 x 17	Dry
				4	193	17 x 17	Ice
W3	Zion 1,2; Indian Point 2,3; Donald C. Cook 1	Low Power 4 Loop		4	193	15 x 15	Dry
				4	193	15 x 15	Ice
W4	Haddam Neck	Unique 4 Loop		4	157	15 x 15	Dry
W5	Yankee Rowe	Unique 4 Loop		4	76	16 x 16 ^c	Dry
W6	Beaver Valley 1,2; North Anna 1,2; Joseph M. Farley 1,2; Shearon Harris 1; Virgil C. Summer	High Power 3 Loop		3	157	17 x 17	Sub-atmospheric
				3	157	17 x 17	Dry
W7	Surry 1,2; Robinson 2; Turkey Point 3,4	Med%wm Power 3 Loop		3	157	15 x 15	Sub-atmospheric
				3	157	15 x 15	Dry
W8	San Onofre 1	Low Power 3 Loop		3	157	14 x 14	Dry
W9	Kewaunee; Prairie Island 1,2; Point Beach 1,2; R.E. Ginna	2 Loop		2	121	14 x 14	Dry

a. Applies to BWRs only

b. Active fuel length 168 in

c. Unique PWR fuel: cruciform shim rod unit between bundles.

Table 2-1. (continued).

Group	Plants in group	Group Description	Vessel ID (in.) ^a	Coolant loops	Number of bundles	Bundle design	Containment design ^b
Combustion Engineering							
C1	Maine Yankee	Unique CE		3	217	14 x 14	
C2	Palo Verde 1,2,3; WNP 3	High Power CE		2 x 4	241	16 x 16 ^c	
C3	San Onofre 2,3; Waterford 3	Medium Power CE		2 x 4	217	16 x 16 ^c	
C4	St. Lucie 2	Unique CE		2 x 4	217	16 x 16 ^d	
C5	Calvert Cliffs 1,2; Millstone 2; St. Lucie 1	Low Power CE		2 x 4	217	14 x 14	
C6	Palisades	Unique CE		2 x 4	204	15 x 15	
C7	Nuclear One 2	Unique CE		2 x 4	177	16 x 16 ^c	
C8	Fort Calhoun	Unique CE		2 x 4	133	14 x 14	
Babcock & Wilcox							
B1	Bellefonte 1,2; WNP 1	High Power, Raised Loop		2 x 4	205	17 x 17	
B2	Davis Besse 1	Low Power, Raised Loop		2 x 4	177	15 x 15	
B3	Crystal River 3; Nuclear One 1; Oconee 1,2,3; TMI 1; Rancho Seco	Low Loop		2 x 4	177	15 x 15	

a. Applies to BWRs only

b. Applies to Westinghouse PWRs only

c. Active fuel length 150 in

d. Active fuel length 136.7 in

Table 2-2. CAMP Member NPPs in Survey Which Are Similar to U.S. Plants.

Group	Plants in group	Group Description	Vessel ID (in.) ^a	Coolant loops ^b	Number of bundles	Bundle design	Containment design ^c
Westinghouse							
W2	Phillipsburg 2 ⁽¹⁾	Medium Power 4 Loop		4	193	16 x 16	Dry
W6	Almaraz 1 ⁽¹⁾ ; Asco 2 ⁽³⁾ ; Doel 4 ⁽⁴⁾ ; Ko-ri 3 ⁽⁷⁾ ; Ringhals 4 ⁽⁸⁾ ; Tihange 2 ⁽⁹⁾ ; Vandellós 2 ⁽¹⁰⁾ ; Yong-Gwang 2 ⁽¹¹⁾	High Power 3 Loop		3	157	17 x 17	Dry
W7	Ringhals 2 ⁽¹²⁾	Medium Power 3 Loop		3	157	15 x 15	Dry
W9	Borssele ⁽¹³⁾ ; Doel 2 ⁽¹⁴⁾ ; Ko-ri 1 ⁽¹⁵⁾	2 Loop		2	121	14 x 14	Dry
General Electric							
G3	Santa Maria de Garona ⁽¹⁶⁾	Low Power BWR/3	211		400	8 x 8	3
G10	Cofrentes ⁽¹⁷⁾	Low Power BWR/6	232		624	8 x 8	3

a. Applies to BWRs only

b. Applies to PWRs only

c. 1—Drywell and free standing torus
 2—Over/under with free standing steel pressure vessel
 3—Suppression pool type
 1c—Drywell and concrete torus with steel liner
 2c—Over/under steel liner inside concrete

3. LIST OF THERMAL-HYDRAULIC MODELS

A search was made to identify the LWR systems that have been modeled with the commonly used thermal-hydraulic analysis codes. A summary giving the plant name, plant group, and model applications is presented here for each deck. Detailed information for each model, as recorded in the PC data base, is given in Appendix A.

Table 3-1 lists the thermal-hydraulic plant input decks identified in the survey. The input decks are grouped by analysis code and listed alphabetically within each group. The plant group from Table 2-1, the code version, and the custodian organization are listed for each input deck. Input decks frequently contain data considered proprietary to the vendor or utility of the plant being modeled, therefore the proprietary status of each deck is indicated in the table.

Table 3-2 is a matrix of input deck applications. Seventeen common reactor transients are listed along the top of the matrix and the input decks are listed alphabetically along the left edge of the matrix. An entry of "A" in the matrix indicates an assessment or application of the input deck. There are no reported applications of the CESSAR RELAP5/MOD1, Generic B&W TRAC-PF1/MOD1, Grand Gulf TRAC-BD1, or Robinson 2 RELAP5/MOD3 input decks.

Table 3-1. List of thermal-hydraulic input decks.

Plant	Group	Code version	Proprietary	Source
RELAP5:				
Almaraz 1	W6	RELAP5/MOD2	Yes	CAMP
Borssele	W9	RELAP5/MOD2	Yes	CAMP
Browns Ferry 1	G8	RELAP5/MOD2	Yes	INEL
Calvert Cliffs 1	C5	RELAP5/MOD2	Yes	INEL
CESSAR	C2	RELAP5/MOD1	Yes	INEL
Davis-Besse	B2	RELAP5/MOD2	Yes	INEL
Doel 2	W9	RELAP5/MOD2	No	CAMP
Doel 4	W6	RELAP5/MOD2	No	CAMP
Ko-ri 1	W9	RELAP5/MOD2	No	CAMP
Ko-ri 3	W6	RELAP5/MOD3	Yes	CAMP
North Anna	W6	RELAP5/MOD2	Yes	INEL
Nuclear Or 2	C7	RELAP5/MOD1.5	Yes	INEL
Oconee 1	B3	RELAP5/MOD2	Yes	INEL
Phillipsburg 2	W2	RELAP5/MOD2	Yes	CAMP
RESAR 3S	W2	RELAP5/MOD2	Yes	INEL
Robinson 2	W7	RELAP5/MOD2	Yes	INEL
Robinson 2	W7	RELAP5/MOD3	Yes	INEL
Tihange 2	W6	RELAP5/MOD2	Yes	CAMP
Vandellios 2	W6	RELAP5/MOD2	Yes	CAMP
Yankee Rowe	W5	RELAP5/MOD3	Yes	INEL
Yong-Gwang 2	W6	RELAP5/MOD2	No	CAMP
Zion 1	W3	RELAP5/MOD2	Yes	INEL
RELAP5/SCDAP:				
Bellefonte 1,2	B1	RELAP5/MOD2/SCDAP	No	INEL
Calvert Cliffs 1	C5	RELAP5/MOD3/SCDAP	Yes	INEL
Oconee 1	B3	RELAP5/MOD3/SCDAP	Yes	INEL
Seabrook	W2	RELAP5/MOD3/SCDAP	Yes	INEL
Surry 1	W7	RELAP5/MOD2/SCDAP	Yes	INEL
TRAC-P:				
Asco	W6	TRAC-PF1/MOD1	Yes	CAMP
Calvert Cliffs 1	C5	TRAC-PF1/MOD1	Yes	LANL
Davis-Besse	B2	TRAC-PF1/MOD1	Yes	LANL
Generic B&W PWR	—	TRAC-PF1/MOD1	Yes	LANL
Oconee 1	B3	TRAC-PF1/MOD1	Yes	LANL
R.E. Ginna	W9	TRAC-PF1/MOD1	Yes	LANL
RESAR 3S	W2	TRAC-PF1/MOD1	Yes	LANL
Ringhals 2	W7	TRAC-PF1/MOD1	Yes	CAMP
Ringhals 4	W6	TRAC-PF1/MOD1	Yes	CAMP
Robinson 2	W7	TRAC-PF1/MOD1	Yes	LANL
TMI 1	B3	TRAC-PF1/MOD1	Yes	LANL
Vandellios 2	W6	TRAC-PF1/MOD1	Yes	CAMP
Zion 1	W3	TRAC-PF1/MOD1	Yes	LANL
TRAC-B:				
Black Fox	G11	TRAC-BF1	No	INEL
Browns Ferry 1	G8	TRAC-BD1	Yes	INEL
BWR/6-218	G10	TRAC-BF1	No	INEL
Cofrentes	G10	TRAC-BF1	Yes	CAMP
Dresden 3	G5	TRAC-BD2	Yes	INEL
Grand Gulf	G12	TRAC-BD1	Yes	INEL
LaSalle	G9	TRAC-BF1	Yes	INEL
Santa Maria de Garona	G3	TRAC-BF1	Yes	CAMP

Table 3-2. Input deck applications matrix.

A = Application																		
Input deck		Code																
		Large break	Small break	Steam line breaks	Steam generator tube ruptures	Snuck open PORV	Plant blackout	ATWS	Return to power transients	Feedwater transients	Loss of load	Turbine trip	Control rod drop (ejection)	Particular plant incident	Plant trip	Feed and bleed recovery	Severe accident scenarios	Instrument tube ruptures
Almaraz 1					A		A			A								
Asco 2							A			A				A ^a				
Bellefonte 1			A				A			A							A	
Black Fox		A	A				A	A										
Borssele														A ^d				
Browns Ferry 1								A									A	
Browns Ferry 1										A	A	A			A			
BWR/6-218		A	A												A			
Calvert Cliffs 1			A							A								
Calvert Cliffs 1		A	A							A								
Calvert Cliffs 1							A											
CESSAR																		
Cofrentes										A		A						
Davis-Besse										A						A		
Davis-Besse										A								
Doel 2					A													
Doel 4											A			A ^c	A			
Dresden 3		A																
Generic B&W PWR			A							A								
Grand Gulf																		
Kori 1							A											
Kori 3														A ^b				
LaSalle														A ^c				
North Anna 2				A			A		A									
Nuclear One 2					A		A					A						
Oconee 1			A	A	A					A								
Oconee 1		A	A															

Table 3-2. (continued).

Input deck		Code																	
		Large break	Small break	Steam line breaks	Steam generator tube ruptures	Suck open PORV	Plant blackout	ATWS	Return to power transients	Feedwater transients	Loss of load	Turbine trip	Control rod drop (ejection)	Particular plant incident	Plant trip	Feed and bleed recovery	Severe accident scenarios	Instrument tube ruptures	
Oconee 1		A										A				A			
Phillipsburg 2															A				
R. E. Ginna					A											A			
RESAR 3S																			
RESAR 3S		A									A								
Ringhals 2																			
Ringhals 4										A					A	A			
Robinson 2			A	A	A	A				A									
Robinson 2																A			
Robinson 2			A		A														
Santa Maria de Garona		A									A								
Seabrook															A				
Seabrook																	A		
SNUPPS			A	A	A					A									
Surry 1																	A		
Tihange 2															A				
TMI 1		A														A			
Vandellos 2											A	A							
Vandellos 2											A	A							
Yankee Rowe			A	A	A									A ^d					
Yong-Gwang 2																			
Zion 1																		A	
Zion 1										A									

a. Pressurizer spray faulty opening transient.

b. Inadvertent safety injection.

c. NC instability.

d. NC decay heat removal test.

e. Spray start-up test

4. PC BASED DATABASE

The information gathered in this survey is most easily stored in a PC based database. As new information becomes available, it can be added to the database. Furthermore, information is easily accessed with a query program. Information on models for a particular plant may be queried; should there be none, the database will respond with information on models for similar plants. Models of plants belonging to a particular classification, models that run under a particular code, or models useful for a specific application may also be queried for and obtained.

Input decks may be queried by plant name, group, type, or vendor, by the code they run under, by application that the model may be used for, or by any combination of these specifications. The selection of these search parameters is menu driven. After selection of the parameters, a search is initiated which will locate the plant decks which most closely match the requirements. Therefore, if no decks exist for the specified plant, decks of plants from the same group, type, or vendor, in that order, will be located. The information may be viewed on the screen, or sent to a file or printer.

An input program allows for maintenance of the database.

The data collected for each NPP considered in the survey is discussed in Appendix A, and the data from input decks located in the survey is given.

Instructions for using the database are found in Appendix B.

The query and input programs may be run under dBASE III PLUS or FoxBASE+ on IBM or similar machines. A runtime module is included with the compiled codes for those users without access to either of the above mentioned database management systems. The database and programs may be acquired by sending one 5.25" floppy disk to

John Determan
MS 2403
P. O. Box 1625
Idaho Falls, ID 83415

5. REFERENCES

1. Correspondence—J. A. Dearien, to R. E. Tiller, *Categorization of BWR and PWR Plants for SASA Work*, JAD-220-80, August 28, 1980.
2. James Varley, *World Nuclear Industry Handbook 1992*, Nuclear Engineering International, Sutton England.
3. G. Gerth, *Assessment Study of RELAP5/MOD2 Cycle 36.04 Based on the Commissioning Test Reactor Trip at Full Load at the Phillipsburg 2 Nuclear Power Plant*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0057, April 1992.
4. A. Lopez, *Application of Full Power Blackout for C.N. Almaraz with RELAP5/MOD2*, Central Nuclear de Almaraz, ICAP-00205, ICSP-AL-BOUT-R, June 1991.
5. F. Reventos, *Assessment and Application of Blackout Transients at Asco NPP with RELAP5/MOD2*, Asociacion Nuclear Asco, ICAP-00201, ICSP-AS-BOUT-R, June 1991.
6. P. Moeyaert, et al, *Assessment Study of RELAP5/MOD2, Cycle 36.04, Based on Spray Start-up test for DOEL-4*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0020, July 1989.
7. Kyun-Tae Kim, et al, *Assessment of RELAP5/MOD3 Versio%w5m5 Using Inadvertent Safety Injection Data of Kori Unit 3 Plant*, Korea Institute of Nuclear Safety, ICAP-00213.
8. A. Sjoberg, *Assessment of TRAC-PF1/MOD1 Against an Inadvertent Feedwater Line Isolation Transient in the Ringhals 4 Power Plant*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0038, March 1992.
9. G.P. Rouel, et al, *Assessment Study of RELAP5/MOD2 Cycle 36.05 Based on the Tihange-2 Reactor Trip of January 11, 1983*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0044, March 1992.
10. A. Querol, et al, *Assessment of TRAC-PF1/MOD1 Against a Load Rejection from 100% to 50% in the Vandellós II Nuclear Power Plant*, Union Iberoamericana de Tecnologia Electrica, ICAP-00175, ICSP-V2R50-T, October 1990.
11. N. Arne, et al, *Assessment of RELAP5/MOD2 Computer Code Against the Natural Circulation Test Data from Yong-Gwang Unit 2*, Korea Electric Power Corporation, ICAP-00208.
12. F. Pelayo, et al, *Assessment of TRAC-PF1/MOD1 Against an Inadvertent Steam Line Isolation Valve Closure in the Ringhals 2 Power Plant*, Studsvik Energiteknik A.B., ICAP-00143, Studsvik/NP-88/14, February 1988.

13. L. Winters, *Assessment of RELAP5/MOD2 Against a Natural Circulation Experiment in Nuclear Power Plant Borssele*, Netherlands Energy Research Foundation, ICAP-00136, ECN-89-91, November 1989.
14. E.J. Stubbe, *Assessment Study of RELAP5/MOD2 Cycle 36.01: Based on the Doel 2 Steam Generator Tube Rupture Incident of June 1979*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0008, October 1986.
15. B. Chung, et al, *Assessment of RELAP5/MOD2 Code Using Loss of Offsite Power Transient Data of KNU #1 Plant*, Office of Nuclear Regulatory Research, U.S. Nuclear Regulatory Commission, NUREG/IA-0030, April 1990.
16. J.V. Lopez, et al, *Recirculation Suction Large Break LOCA Analysis of Santa Maria de Garona Nuclear Power Plant Using TRAC-BF1 (G1J1)*, Polytechnical University of Madrid, ICAP-00188, ICSP-GA-LOCA-T, February 1991.
17. F. Castrillo, et al, *Assessment of the "Turbine Trip Transient" in Cofrentes NPP with TRAC-BF1, Hidroelectrica Espanola*, ICAP00202, ICSP-CO-TTRIP-T, June 1991.

Appendix A

Data Gathered in the Survey

Appendix A

Data Gathered in the Survey

The data can be divided into three categories: NPP data, input deck data, and report data. For all domestic NPPs and foreign plants similar to domestic plants for which thermal-hydraulic input decks are known to exist the information which categorizes them, specifically, vendor, type and similarity grouping is included in the database. It is this information that allows the query program to determine what other plant models could be of use when no model information is available for the plant in question. Other helpful information includes the plant's rated power output, the number and geometry of fuel assemblies in the reactor, the plant's location and licensing date.

Information regarding the status and capabilities of each plant deck considered in the survey has been gathered. The decks are identified by the plant name and thermal-hydraulic code related to each deck. The QA status and availability of each deck are noted, as are references to it. Documented assessments and applications of each deck are listed. The steady state conditions available are listed. A brief model description is included.

The custodian organization of each deck is noted, and telephone numbers of administrative and technical contacts are given. The technical contact is important because the information about each deck must be considered as representative, rather than as exhaustive; further information may be obtained by consulting the technical contact.

The report number, issue date, title, and principle author for every reference are included in the database.

Below is the database output for the decks located in the survey.

PLANT: Almaraz 1
Location: Spain
Vendor: W
License Date: 10/81
Utility: Central Nuclear de Almaraz
Type: 3-Loop
MWt: 2696
MWe: 930
of Bundles: 157 17x17
Group #: W6
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00205
Issue Date: 6/91
Author: A. Lopez
Title: APPLICATION OF FULL POWER BLACKOUT FOR C.N. ALMARAZ WITH RELAP5/MOD2

Report Number: ICAP-00220
Issue Date: 9/91
Author: A. Lopez
Title: APPLICATION OF FULL POWER STEAM GENERATOR TUBE RUPTURE EVENT FOR C. N. ALMARAZ WITH RELAP5/MOD2

Steady States: 100% power
Assessments: Plant Blackout
 Steam Generator Tube Ruptures
Applications: None reported

COMPONENT DESCRIPTION

Core: 5 node core with average and hot channels modeled
Vessel: No guide tube flow modeled
Containment: Pressure boundary
Balance of Plant: No feedtrain, detailed SGs
Primary or Recirc: One double loop, one single loop
Main Steam: Detailed steam lines
Control Systems: Detailed trip and control system
Auxiliary Systems: ECCS, AFW
Fuel Rod Behavior: None
Kinetics: Power input table only

PLANT: Asco 2
Location: Spain
Vendor: W
License Date: 2/86
Utility: Asociacion Nuclear Asco
Type: 3-Loop
MWt: 2696
MWe: 930
of Bundles: 157 17x17
Group #: W6
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00217
Issue Date: 6/91
Author: R. Martinez, et al
Title: ASSESSMENT OF TRAC-PF1/MOD1 AGAINST A
LOSS OF MAIN FEEDWATER IN ASCO NUCLEAR
POWER PLANT

Report Number: ICAP-00201
Issue Date: 6/91
Author: F. Reventos
Title: ASSESSMENT AND APPLICATION OF BLACKOUT
TRANSIENTS AT ASCO NPP WITH RELAP5/MOD2

Report Number: ICAP-00203
Issue Date: 6/91
Author: F. Reventos
Title: ASSESSMENT OF A PRESSURIZER SPRAY FAULTY
OPENING TRANSIENT AT ASCO NPP WITH
RELAP5/MOD2

Steady States: 100% power
Assessments: Feedwater Transients
Plant Blackout
Applications: None reported

COMPONENT DESCRIPTION

Core:	1D, six axial levels
Vessel:	Simple vessel model
Containment:	Pressure Boundary
Balance of Plant:	No feedtrain, detailed SGs
Primary or Recirc:	One double loop, one single loop
Main Steam:	detailed steam lines
Control Systems:	SG level, turbine runback, steam dump, PZR level, RCS temperature
Auxiliary Systems:	ECCS modeled
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT: Bellefonte 1
Location: Scottsboro, Ala.
Vendor: B&W
License Date: indefinite
Utility: Tennessee Valley Authority
Type: 2-Loop High
MWt: 3640
MWe: 1213
of Bundles: 205 17x17
Group #: B1
Code: RELAP5/SCDAP/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: C A Dobbe 208-526-9424
Technical Contact: C A Dobbe 208-526-9424

REFERENCES

Report Number: EGG-NTP-6704
Issue Date: 10/84
Author: C. A. Dobbe, et. al.
Title: ANALYSIS OF A STATION BLACKOUT TRANSIENT
FOR THE BELLEFONTE PRESSURIZED WATER
REACTOR

Report Number: NUREG/CR-4741
Issue Date: 3/87
Author: P. D. Bayless, et. al.
Title: FEEDWATER TRANSIENT AND SMALL BREAK LOSS
OF COOLANT ACCIDENT ANALYSES FOR THE
BELLEFONTE NUCLEAR PLANT

Steady States: 100% Power/ 100% Flow
Assessments: None
Applications: Small Break LOCA
Plant Blackout
Feedwater Transients
Severe Accident Scenarios

COMPONENT DESCRIPTION

Core: Single channel and three channel core
models were developed
Vessel: 2 node lower plenum, 13 node downcomer,
8 node upper plenum/ upperhead
Containment: 1 node containment

Balance of Plant:	Feedwater is included
Primary or Recirc:	Both loops are modeled in detail
Main Steam:	Both steam lines are modeled in detail
Control Systems:	SG level
Auxiliary Systems:	Auxiliary feedwater, LPI, HPI, and accumulator are included
Fuel Rod Behavior:	SCDAP input included
Kinetics:	Power input table used

PLANT: Black Fox
Location: N/A
Vendor: GE
License Date: N/A
Utility: N/A
Type: BWR/6 238" CONTAINMENT
MWt: 3579
MWe: 1205
of Bundles: 732 8x8
Group #: G11
Code: TRAC-BF1/MOD
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: R P Martin 208-526-2880

REFERENCES

Report Number: NUREG/CR-5882
Issue Date: 6/92
Author: R. P. Martin
Title: TRAC-B Thermal-Hydraulic Analysis of the
Black Fox Boiling Water Reactor

Steady States: 100% Power; 40% Power/60% Flow
Assessments: None
Applications: Large Break LOCA
Small Break LOCA
Plant Blackout
ATWS

COMPONENT DESCRIPTION

Core: Three CHAN components, twelve nodes each
Vessel: Eleven Axial levels, three radial rings
Containment: Pressure boundary
Balance of Plant: From last feedwater heater to turbine
bypass
Primary or Recirc: Two Recirculation loops modeled
Main Steam: MSIV, TBV, and TSV modeled
Control Systems: Recirc. pump speed, ECCS controls,
Isolation controls
Auxilliary Systems: ECCS
Fuel Rod Behavior: None
Kinetics: Point kinetics

PLANT: Borssele
Location: Netherlands
Vendor: KWU
License Date: 10/73
Utility: NV Provinciale Zeeuwse Energie Maatschappij
Type: 2-Loop
MWt: 1365
MWe: 452
of Bundles: 121 15x15
Group #: W9
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00136
Issue Date: 11/89
Author: L. Winters
Title: Assessment of RELAP5/MOD2 Against a
 Natural Circulation Experiment in
 Nuclear Power Plant Borssele

Steady States: 13 MWt, 15.32 MPa, 548.4 K
Assessments: Natural Circulation Experiment
Applications: None reported

COMPONENT DESCRIPTION

Core: Single channel, six level core
Vessel: core bypass, upper head leakage
Containment: Pressure boundary
Balance of Plant: Detailed SG, no feedtrain
Primary or Recirc: Two explicit loops, detailed pressurizer
Main Steam: Detailed steamlines
Control Systems: pressurizer pressure and level, SG level
Auxiliary Systems: ECCs, volume control system
Fuel Rod Behavior: None
Kinetics: None

PLANT: Browns Ferry 1
Location: Decatur, Ala.
Vendor: GE
License Date: 8/74
Utility: Tennessee Valley Authority
Type: BWR/4 251" ID CONTAINMENT 1
MWt: 3293
MWe: 1065
of Bundles: 764 8x8
Group #: G8
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: EGG-NTAP-5993
Issue Date: 8/82
Author: W. C. Jouse, et. al.
Title: A RELAP5 ANALYSIS OF A BREAK IN THE
SCRAM DISCHARGE VOLUME AT THE BROWNS
FERRY UNIT ONE PLANT

Report Number: EGG-SAAM-6397
Issue Date: 11/83
Author: W. C. Jouse
Title: DRAFT PRELIMINARY REPORT (CODE) FOR
COMMENT RELAP5/MOD1.6 BWR/4 ATWS
DEMONSTRATION CALCULATION ON THE BROWNS
FERRY UNIT 1 NUCLEAR PLANT

Report Number: EGG-NTAP-6002
Issue Date: 9/82
Author: R. R. Schultz, et. al.
Title: THE STATION BLACKOUT TRANSIENT AT THE
BROWNS FERRY UNIT ONE PLANT A SEVERE
ACCIDENT SEQUENCE ANALYSIS

Report Number: NUREG/CR-4165
Issue Date: 5/87
Author: R. J. Dallman
Title: SEVERE ACCIDENT SEQUENCE ANALYSIS
PROGRAM - ANTICIPATED TRANSIENT WITHOUT
SCRAM SIMULATIONS FOR BROWNS FERRY

NUCLEAR PLANT UNIT 1

Report Number:	FIN NO. A6477
Issue Date:	7/84
Author:	R. G. Hanson, et. al.
Title:	EFFECTS OF CONTROL SYSTEM FAILURES ON TRANSIENTS AND ACCIDENTS AT A GENERAL ELECTRIC BOILING WATER REACTOR APPENDICES A. B. C. AND D
Steady States:	100% Power/100% Flow
Assessments:	None
Applications:	ATWS Severe Accident Scenarios

COMPONENT DESCRIPTION

Core:	Average assembly and hot channel modeled 12 node assembly, 3 node bypass
Vessel:	4 node lower plenum, 5 node downcomer, 5 node upper plenum and steam dome
Containment:	Containment model available: CONTEMPT/ LT-028 model
Balance of Plant:	Feedwater and turbines are modeled
Primary or Recirc:	The two recirculation loops are lumped as one. The jet pumps are modeled.
Main Steam:	Six node steam line. MSIV, SRVs and bypass valves are modelled
Control Systems:	Recirc. pump speed, FW, drain, FW heater extraction steam flow
Auxiliary Systems:	HPCI, LPCI, RCIC, Control rod drive
Fuel Rod	
Behavior:	FRAP-T6 modelling is used
Kinetics:	Point kinetics

PLANT: Browns Ferry 1
Location: Decatur, Ala.
Vendor: GE
License Date: 8/74
Utility: Tennessee Valley Authority
Type: BWR/4 251" ID CONTAINMENT 1
MWt: 3293
MWe: 1065
of Bundles: 764 8x8
Group #: G8
Code: TRAC-BD1/MOD1
Q/A: N

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: J D Burtt 208-526-9089

REFERENCES

Report Number: FIN NO. A6047
Issue Date: 11/84
Author: J. D. Burtt
Title: DRAFT PRELIMINARY REPORT FOR COMMENT
 TRAC-BD1/MOD1 ASSESSMENT USING BROWNS
 FERRY BWR/4 STARTUP TEST DATA

Steady States: 100% Power/100% Flow
Assessments: Feedwater Transients
 Loss of Load
 Turbine Trip
 Plant Trip
Applications: None

COMPONENT DESCRIPTION

Core: 1-dimensional 3 channel core. Average
 peripheral, and hot assemblies modeled
Vessel: 3-D vessel with 10 axial, and four
 radial regions
Containment: Pressure boundary
Balance of Plant: Feedwater modeled
Primary or Recirc: Both loops are modeled with 3 nodes per
 loop. Jet pumps are modeled
Main Steam: 2 node steam line with the MSIV, SRVs,
 bypass valve and the PRVs modeled
Control Systems: Recirculation pumps
Auxiliary Systems: None
Fuel Rod Behavior: None
Kinetics: Point kinetics

PLANT: BWR/6-218
Location: N/A
Vendor: GE
License Date: N/A
Utility: N/A
Type: BWR/6 218" CONTAINMENT
MWt: 2894
MWe: N/A
of Bundles: 624 8x 8
Group #: G10
Code: TRAC-BF1/MOD
Q/A: N

Organization: EG&G Idaho, Inc.
Admin. Contact: P D Wheatley 208-526-9348
Technical Contact: P D Wheatley 208-526-9348

REFERENCES

Report Number: EGG-NTAP-6073
Issue Date: 10/82
Author: P. D. Wheatley
Title: Scaling Analysis of the FIST Facility
 Using TRAC-BD1

Report Number: NUREG/CR-4391
Issue Date: 8/86
Author: W. L. Weaver, et al
Title: TRAC-BF1 Manual: Extensions to
 TRAC-BD1/MOD1

Steady States: 100% Power/100% Flow
Assessments: None
Applications: Plant Trip
 Large Break LOCA
 Small Break LOCA

COMPONENT DESCRIPTION

Core: Three radial rings, one azimuthal sector
 two axial levels
Vessel: Four radial rings, one azimuthal sector
 nine axial levels
Containment: Pressure boundary
Balance of Plant: No feedtrain modelled
Primary or Recirc: Two recirc loops modelled
Main Steam: ADS, SRV modelled

Control Systems: Steam line valve area
Auxilliary Systems: HPCS, LPCS, and LPCI
Fuel Rod Behavior: None
Kinetics: Decay heat curves used

PLANT:	Calvert Cliffs 1	
Location:	Lusby, Md.	
Vendor:	C-E	
License Date:	5/75	
Utility:	Baltimore Gas & Electric Co.	
Type:	2X4 Loop	
MWt:	2570	
MWe:	825	
# of Bundles:	217 14x14	
Group #:	C5	
Code:	RELAP5/MOD2	
Q/A:	Y	
 Organization:	 EG&G Idaho, Inc.	
Admin. Contact:	G W Johnsen	208-526-9854
Technical Contact:	C B Davis	208-526-9470

REFERENCES

Report Number:	NUREG/CR-4966 V1
Issue Date:	10/87
Author:	D. J. Hanson, et. al.
Title:	EVALUATION OF OPERATIONAL SAFETY AT BABCOCK AND WILCOX PLANTS. VOLUME 1 -- RESULTS OVERVIEW

Steady States:	100% Power/ 100% Flow
Assessments:	None
Applications:	Small Break LOCA Feedwater Transients

COMPONENT DESCRIPTION

Core:	3 Node core, no bypass modeled
Vessel:	2 node lower plenum, 7 node downcomer, 7 node upper plenum/ upper head
Containment:	1 node containment
Balance of Plant:	Main feedwater and turbine are modeled
Primary or Recirc:	All loops are modeled in detail
Main Steam:	Both steam lines modeled in detail
Control Systems:	Reactor coolant pressure regulator, pressurizer level, feedwater regulator
Auxiliary Systems:	Auxiliary feedwater, HPI, LPI, Accumulator, and charging systems
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT:	Calvert Cliffs 1	
Location:	Lusby, Md.	
Vendor:	C-E	
License Date:	5/75	
Utility:	Baltimore Gas & Electric Co.	
Type:	2X4 Loop	
MWt:	2570	
MWe:	825	
# of Bundles:	217 14x14	
Group #:	C5	
Code:	RELAP5/SCDAP/MOD3	
Q/A:	Y	
 Organization:	 EG&G Idaho, Inc.	
Admin. Contact:	G W Johnsen	208-526-9854
Technical Contact:	J C Determan	208-526-2888

REFERENCES

None

Steady States:	100% Power/ 100% Flow
Assessments:	None
Applications:	Large Break LOCA Small Break LOCA Feedwater Transients

COMPONENT DESCRIPTION

Core:	3 channel, 10 Node core, bypass modeled
Vessel:	Split downcomer
Containment:	1 node containment
Balance of Plant:	Main feedwater and turbine are modeled
Primary or Recirc:	All loops are modeled in detail
Main Steam:	Both steam lines modeled in detail
Control Systems:	Reactor coolant pressure regulator, pressurizer level, feedwater regulator
Auxiliary Systems:	Auxiliary feedwater, HPI, LPI, Accumulator, and charging systems
Fuel Rod Behavior:	SCDAP input for outer, middle, and center channels of core
Kinetics:	Input power table only

PLANT: Calvert Cliffs 1
Location: Lusby, Md.
Vendor: C-E
License Date: 5/75
Utility: Baltimore Gas & Electric Co.
Type: 2X4 Loop
MWt: 2570
MWe: 825
of Bundles: 217 14x14
Group #: C5
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: J F Lime 505-667-4097
Technical Contact: J F Lime 505-667-4097

REFERENCES

Report Number: NUREG/CR-4109
Issue Date: 2/85
Author: G. D. Spriggs, et. al.
Title: TRAC-PF1 ANALYSES OF POTENTIAL
PRESSURIZED-THERMAL-SHOCK TRANSIENTS AT
CALVERT CLIFFS / UNIT 1 A COMBUSTION
ENGINEERING PWR

Report Number: LA-UR-85-2868
Issue Date: 8/85
Author: Rick Jenks
Title: COOLDOWN TO RESIDENT-HEAT REMOVAL ENTRY
CONDENSATION USING ATMOSPHERIC DUMP
VALVES AND AUXILIARY PRESSURIZER SPRAY
FOLLOWING A LOSS-OF-OFFSITE-POWER AT CC1

Report Number: LA-UR-85-2039
Issue Date: 1985
Author: B. E. BOYACK
TITLE: ATMOSPHERIC STEAM DUMP COOLDOWN OF
CALVERT CLIFFS-1 FOLLOWING A SMALL-BREAK
LOSS-OF-COOLANT ACCIDENT WITH FAILURE OF
THE HIGH PRESSURE INJECTION SYSTEM

Report Number: LA-UR-85-0960
Issue Date: 1985
Author: R. Jenks
Title: ALTERNATIVE COOLDOWN METHODS FOLLOWING A

**LOSS-OF-OFFSITE POWER (LOSP) EVENT AT
CALVERT CLIFFS UNIT 1**

Report Number: LA-UR-85-0424
Issue Date: 1985
Author: R. Jenks
Title: COOLDOWN PERFORMANCE CAPABILITY FOR
CALVERT CLIFFS-1 ASSUMING VARIOUS
ATMOSPHERIC DUMP VALVE SIZES

Report Number: LA-UR-84-3947
Issue Date: 1984
Author: R. P. Jenks
Title: COOLDOWN TO RESIDUAL HEAT REMOVAL ENTRY
CONDITIONS USING ATMOSPHERIC DUMP VALVES
AND AUXILIARY PRESSURIZER SPRAY
FOLLOWING A LOSS-OF-OFFSITE POWER AT
CALVERT CLIFFS-UNIT 1

Report Number: LA-UR-84-3860
Issue Date: 1984
Author: B. Boyack
Title: Use of an Atmospheric Steam Dump
PROCEDURE TO COOL AND DEPRESSURIZE
CALVERT CLIFFS-1 FOLLOWING A SMALL-BREAK
LOSS-OF-COOLANT ACCIDENT WITH FAILURE OF
THE HIGH-PRESSURE INJECTION SYSTEM

Report Number: LA-UR-84-3589
Issue Date: 1984
Author: R. P. Jenks
Title: COOLDOWN PERFORMANCE CAPABILITY FOR
CALVERT CLIFFS-1 ASSUMING VARIOUS
ATMOSPHERIC DUMP VALVE SIZES

Report Number: LA-UR-84-3266
Issue Date: 1984
Author: E. Horley
Title: COMBINED MAIN-STEAM-LINE BREAK /
LOSS-OF-FEEDWATER TRANSIENT IN THE
CALVERT CLIFFS-1 PWR

Report Number: LA-UR-84-3006
Issue Date: 1984
Author: R. Jenks
Title: ALTERNATIVE COOLDOWN METHODS FOLLOWING A
LOSS-OF-OFFSITE POWER (LOSP) EVENT AT

CALVERT CLIFFS UNIT 1

Report Number:	LA-UR-84-1973
Issue Date:	1984
Author:	B. E. Boyack, et al
Title:	AN ASSESSMENT OF THE UTILITY OF FEED-AND-BLEED OPERATING MAPS (CALVERT CLIFFS-1)
Report Number:	LA-UR-83-3375
Issue Date:	1983
Author:	R. Smith
Title:	LOSS-OF-FEEDWATER TRANSIENT FOR THE CALVERT CLIFFS-1 PWR
Report Number:	LA-UR-83-3260
Issue Date:	1983
Author:	Russel Smith
Title:	LOSS-OF-OFFSITE-POWER TRANSIENT FOR THE CALVERT CLIFFS-1 PWR
Report Number:	LA-UR-83-2895
Issue Date:	1983
Author:	J. Lime
Title:	REVIEW OF THE TRAC-PF1 CALVERT CLIFFS-1 PLANT MODEL
Report Number:	LA-UR-85-4146
Issue Date:	1985
Author:	B. E. Boyack
Title:	AN ALTERNATE METHOD OF DECAY-HEAT REMOVAL IN A C & E PLANT FOLLOWING A SBLOCA
Report Number:	LA-UR-85-3501
Issue Date:	9/85
Author:	G. Willcutt
Title:	TECHNICAL EVALUATION REPORT FOR THE TRAC ANALYSES OF SMALL-BREAK LOSS-OF-COOLANT ACCIDENTS TO EVALUATE COMBUSTION ENGINEERING MODELS USED TO ESTABLISH REACTOR-COOLANT-PUMP TRIP SET-POINT CRITERIA
Report Number:	LA-UR-85-2038
Issue Date:	1985
Author:	B. E. Boyack
Title:	AN ALTERNATIVE METHOD OF DECAY-HEAT REMOVAL IN COMBUSTION-ENGINEERING PLANT FOLLOWING A SMALL-BREAK

LOSS-OF-COOLANT ACCIDENT

Report Number: LA-UR-85-036
Issue Date: 1985
Author: B. E. Boyack
Title: AN ALTERNATIVE METHOD OF DECAY-HEAT
REMOVAL IN A C-E PLANT FOLLOWING A
SBLOCA

Report Number: LA-UR-84-2809
Issue Date: 9/84
Author: J. Koenig, et al
Title: TRAC-PF-1 ANALYSES OF POTENTIAL
PRESSURIZED-THERMAL-SHOCK TRANSIENTS AT
A COMBUSTION ENGINEERING PWR

Report Number: LA-UR-84-2757
Issue Date: 1984
Author: J. Koenig, et al
Title: TRAC/PF1 ANALYSES OF POTENTIAL
PRESSURIZED-THERMAL-SHOCK TRANSIENTS AT
A COMBUSTION-ENGINEERING PWR

Report Number: LA-UR-84-2083
Issue Date: 7/84
Author: G. Spriggs, et al
Title: TRAC-PF1 ANALYSES OF POTENTIAL
PRESSURIZED-THERMAL-SHOCK TRANSIENTS AT
A COMBUSTION-ENGINEERING PWR

Report Number: LA-UR-84-0502
Issue Date: 1984
Author: J. Koenig, et al
Title: TRAC-PF1 ANALYSES OF POTENTIAL
PRESSURIZED-THERMAL-SHOCK TRANSIENTS AT
A COMBUSTION-ENGINEERING PWR

Report Number: LA-UR-84-0131
Issue Date: 1984
Author: J. Koenig, et al
Title: EFFECTS OF PUMP OPERATION DURING
POSTULATED STEAM-LINE-BREAK IN A CE
PLANT

Report Number: LA-UR-83-1913
Issue Date: 1983
Author: J. Koenig

Title: TRAC THERMAL-HYDRAULIC PREDICTIONS OF A
STEAM-LINE-BREAK IN A CE PLANT AND PAPER.

Report Number: LA-UR-82-0914

Issue Date: 4/82

Author: J. F. Lime

Title: TRAC MODELING OF A COLD-LEG SMALL-BREAK
TRANSIENT IN A COMBUSTION ENGINEERING
PRESSURIZED WATER REACTOR

Steady States: 100% power

Assessments: None

Applications: Plant Blackout

COMPONENT DESCRIPTION

Core: 6 level, 1-D

Vessel: 1-Dimensional

Containment: Pressure boundary

Balance of Plant: Detailed secondary

Primary or Recirc: All loops modeled

Main Steam: MSIVs, atmospheric dump, SRVs

Control Systems: MFP speed, SG level, PZR heater, steam
bypass dump, makeup/letdown

Auxiliary Systems: Auxiliary feedwater, HPI

Fuel Rod Behavior: Basic rod conduction

Kinetics: Input power table only

PLANT:	CESSAR
Location:	N/A
Vendor:	C-E
License Date:	N/A
Utility:	N/A
Type:	2x4 Loop
MWt:	N/A
MWe:	N/A
# of Bundles:	N/A
Group #:	C5
Code:	RELAP5/MOD2
Q/A:	N

Organization:	EG&G Idaho, Inc.	
Admin. Contact:	P D Bayless	208-526-9027
Technical Contact:	P D Bayless	208-526-9027

REFERENCES

None

Steady States:	100% power
Assessments:	None
Applications:	None reported

COMPONENT DESCRIPTION

Core:	6-node, single channel core with hot channel
Vessel:	Includes core bypass and upper head leak path
Containment:	Pressure boundary
Balance of Plant:	No feedtrain
Primary or Recirc:	Both loops explicit, detailed pressurizer
Main Steam:	Includes MSIVs and stop valve
Control Systems:	None
Auxiliary Systems:	ECCS. makeup, letdown, SG aux. feed
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT: Cofrentes
Location: Spain
Vendor: GE
License Date: 3/85
Utility: Hidroelectrica Espanola
Type: BWR/6 232" ID CONTAINMENT
MWt: 2894
MWe: 958
of Bundles: 624 8x 8
Group #: G10
Code: TRAC-BF1/MOD
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00202
Issue Date: 6/91
Author: F. Castrillo
Title: ASSESSMENT OF THE "TURBINE TRIP TRANSIENT" IN COFRENTES NPP WITH TRAC-BF1

Report Number: ICAP-00189
Issue Date: 2/91
Author: F. Castrillo
Title: Assessment of the "One Feedwater Pump Trip Transient" in Cofrentes NPP with TRAC-BF1

Steady States: 71% power,94% flow; 95% power,94% flow
Assessments: Turbine Trip
 Feedwater Transients
Applications: None reported

COMPONENT DESCRIPTION

Core: 3 radial rings, 2 axial levels
Vessel: 4 radial rings, 8 axial levels
Containment: Pressure boundary
Balance of Plant: No feedtrain
Primary or Recirc: Both recirc. loops modeled, all jetpumps on each line lumped together
Main Steam: Detailed steam line
Control Systems: Pressure control, feedwater control, Recirc. flow control (manual mode)
Auxiliary Systems: LPCI, HPCI, LPCS
Fuel Rod Behavior: None
Kinetics: Point kinetics

PLANT:	Davis-Besse
Location:	Oak Harbor, Ohio
Vendor:	B&W
License Date:	7/78
Utility:	Toledo Edison Co.
Type:	2-Loop High
MWt:	2633
MWe:	874
# of Bundles:	177 15x15
Group #:	B2
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	C B Davis 208-526-9470

REFERENCES

Report Number:	NUREG/CR-4946
Issue Date:	8/87
Author:	C. B. Davis
Title:	DAVIS-BESSE UNCERTAINTY STUDY
Steady States:	92% Power
Assessments:	None
Applications:	Feedwater Transients Feed and Bleed Recovery

COMPONENT DESCRIPTION

Core:	6 node core
Vessel:	2 node lower plenum, 7 node downcomer, 7 node upper plenum/upper head
Containment:	Pressure boundary
Balance of Plant:	Main feedwater is modeled
Primary or Recirc:	Both legs modeled
Main Steam:	2 node steamline. MSIVs and condensers are modeled.
Control Systems:	Steamline safety valves, makeup HPI, LPI SG level, pressurizer liquid level
Auxiliary Systems:	Makeup, HPI, LPI, condenser
Fuel Rod Behavior:	None
Kinetics:	Power vs. time table

PLANT: Davis-Besse
Location: Oak Harbor, Ohio
Vendor: B&W
License Date: 7/78
Utility: Toledo Edison Co.
Type: 2-Loop High
MWt: 2633
MWe: 874
of Bundles: 177 15x15
Group #: B2
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: J F Lime 505-667-4097
Technical Contact: J F Lime 505-667-4097

REFERENCES

Report Number: LA-UR-86-1782
Issue Date: 1986
Author:
Title: RAPID-RESPONSE ANALYSIS OF THE
DAVIS-BESSE LOSS-OF-FEEDWATER EVENT ON
JUNE 9, 1985

Report Number: LA-UR-86-0205
Issue Date: 1/86
Author: J. F. Lime, et al
Title: RAPID-RESPONSE ANALYSIS OF THE
DAVIS-BESSE LOSS-OF-FEEDWATER EVENT OF
JUNE 9, 1985

Report Number: LA-UR-85-3083
Issue Date: 8/85
Author: J. F. Lime, et al
Title: RAPID-RESPONSE ANALYSIS OF THE
DAVIS-BESSE LOSS-OF-FEEDWATER EVENT ON
JUNE 9, 1985

Steady States: 100% core power
Assessments: Feedwater Transients
Applications: Feedwater Transients

COMPONENT DESCRIPTION

Core:	1 radial ring, 2 azimuthal sectors, 4 axial levels
Vessel:	2 radial rings, 2 azimuthal sectors, 12 axial levels; guide tubes, vent valves
Containment:	Pressure Boundary
Balance of Plant:	Detailed Secondary
Primary or Recirc:	Both loops modeled in detail
Main Steam:	Includes turbine stop valves
Control Systems:	Complete SG control, PORV
Auxiliary Systems:	Auxiliary feedwater
Fuel Rod Behavior:	8 radial condensation nodes in fuel, gap and clad
Kinetics:	Input power table only

PLANT:	Doel 2
Location:	Belgium
Vendor:	W
License Date:	12/75
Utility:	Indivision Doel
Type:	2-Loop
MWt:	1187
MWe:	392
# of Bundles:	121 14 x 14
Group #:	W9
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	R R Schultz 208-526-9508

REFERENCES

Report Number:	NUREG/IA-0008
Issue Date:	9/86
Author:	E.J. Strubbe
Title:	Assessment Study of RELAP5/MOD2 Cycle 36.01: Based on the DOEL-2 Steam Generator Tube Rupture Incident of June 1979

Steady States:	6 MWt decay, 155 bar, 255 C
Assessments:	Steam Generator Tube Ruptures
Applications:	None reported

COMPONENT DESCRIPTION

Core:	Single channel, four node core, constant decay heat
Vessel:	Core bypass and upper head leakage paths modeled
Containment:	Pressure Boundary
Balance of Plant:	No feed train, detailed steam generators
Primary or Recirc:	Both loops explicit, detailed pressurizer
Main Steam:	Atmospheric dump valves
Auxilliary Systems:	AUX feed, HPSI, Makeup and letdown
Fuel Rod Behavior:	None
Kinetics:	None
Control Systems:	Basic trip system

PLANT: Doel 4
Location: Belgium
Vendor: W*
License Date: 7/85
Utility: Societes Reunies d'Energie du Bassin de l'Escaut
Type: 3-Loop
MWt: 3000
MWe: 1010
of Bundles: 157 17x17
Group #: W6
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: NUREG/IA-0020
Issue Date: 7/89
Author: P. Moeyaert, et al
Title: Assessment Study of RELAP5/MOD2, Cycle 36.04 Based on Spray Start-up Test for Doel-4

Report Number: NUREG/IA-0043
Issue Date: 3/92
Author: E.J. Strubbe, et al
Title: Assessment Study of RELAP5/MOD2 Cycle 36.04 Based on the Doel-4 Manual Loss of Load Test of November 23, 1985

Report Number: NUREG/IA-0051
Issue Date: 3/92
Author: M. De Vlamincx, et al
Title: Assessment Study of RELAP5/MOD2 Cycle 36.05 Based on the Doel 4 Reactor Trip of November 22, 1985

Steady States: 0% core power, 155 bars; 98% core power
Assessments: Loss of Load
Plant Trip
Applications: None reported

COMPONENT DESCRIPTION

Core:	Single channel, five level core
Vessel:	Core bypass and upper head leakage
Containment:	Pressure boundary
Balance of Plant:	Detailed SG, no feedtrain
Primary or Recirc:	All three loops explicit
Main Steam:	Detailed Steamlines
Control Systems:	Pressurizer pressure, feedwater, steamdump
Auxilliary Systems:	SI, accumulators, chemical and volume
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT: Dresden 3
Location: Morris, Ill.
Vendor: GE
License Date: 11/71
Utility: Commonwealth Edison Co.
Type: BWR/3 251" ID CONTAINMENT 1
MWt: 2527
MWe: 773
of Bundles: 724 9x9
Group #: G5
Code: TRAC-BD1/MOD
Q/A: N

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: C B Davis 208-526-9470

REFERENCES

Report Number: EGG-NTAP-6090
Issue Date: 9/82
Author: C. B. Davis
Title: AN ANALYSIS OF A SPECTRUM OF LARGE-BREAK LOCAs IN A BWR/3 USING TRAC-BD1

Steady States: 102% rated power
Assessments: None
Applications: Large Break LOCA

COMPONENT DESCRIPTION

Core: 10 cell core
Vessel: 13 axial nodes, 4 radial, 1 azimuthal
Containment: Pressure boundary
Balance of Plant: Main feedwater is modeled
Primary or Recirc: "Intact" and "broken" loops are modeled.
 There are 14 nodes per loop with the
Main Steam: 2 node steam line with the MSIV included
Control Systems: Feedwater steam line flow and pressure
 (may not be functional)
Auxiliary Systems: HPCI, LPCS, ADS
Fuel Rod Behavior: None
Kinetics: Point kinetics

PLANT: Generic B&W PWR
Location: N/A
Vendor: B&W
License Date: N/A
Utility: N/A
Type: 2-Loop Low
MWt: N/A
MWe: N/A
of Bundles: 177 15 x 15
Group #: B3
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: M W Cappiello 505-667-4097
Technical Contact: M W Cappiello 505-667-4097

REFERENCES

Report Number: LA-UR-83-3079
Issue Date: 4/86
Author: C. E. Watson
Title: A TRAC-PF1 CALCULATION OF A
 TURBINE-BYPASS-VALVE FAILURE ACCIDENT IN
 A GENERIC B & W PLANT

Report Number: LA-UR-83-3001
Issue Date: 1983
Author: R.J. Henninger, et al
Title: LOSS-OF-OFFSITE-POWER-INITIATED
 LOSS-OF-FEEDWATER TRANSIENTS FOR B & W
 PLANTS

Report Number: LA-UR-83-2786
Issue Date: 1983
Author: R. J. Henninger, et al
Title: SMALL-BREAK LOCA RECOVERY IN B & W
 PLANTS

Report Number: LA-UR-83-2559
Issue Date: 1983
Author: C. Watson
Title: MODEL CHANGES, STEADY-STATE CONDITIONS
 AND TRANSIENT ASSUMPTIONS FOR A TRAC
 CALCULATION OF A TURBINE-BYPASS VALVE
 FAILURE IN A GENERIC B & W PLANT

Report Number: LA-UR-83-0818
Issue Date: 1983
Author: J. R. Ireland
Title: SMALL-BREAK LOCA RECOVERY IN B & W PLANTS

Report Number: LA-UR-83-0657
Issue Date: 10/83
Author: B. E. Boyack, et al
Title: TRAC-PF1 CALCULATION OF B & W PRESSURIZED THERMAL SHOCK TRANSIENTS-OVERCOOLING CAUSED BY TURBINE BYPASS VALVE FAILURES

Report Number: LA-UR-82-3676
Issue Date: 1982
Author: B. E. Boyack, et al
Title: TRAC-PF1 CALCULATION OF B & W PRESSURIZED THERMAL SHOCK TRANSIENTS-OVERCOOLING CAUSED BY TURBINE BYPASS VALVE FAILURES

Report Number: LA-UR-82-2841
Issue Date: 1982
Author: B. Bassett
Title: CALCULATIONS OF PRESSURIZED THERMAL SHOCK TRANSIENTS IN B & W PLANTS

Report Number: LA-UR-82-0911
Issue Date: 4/82
Author: B. Bassett
Title: TRAC ANALYSIS OF STEAM-GENERATOR OVERFILL TRANSIENTS FOR BABCOCK-AND-WILCOX PRESSURIZED WATER REACTORS

Steady States: No information provided
Assessments: None
Applications: Small break LOCA
Feedwater transients

COMPONENT DESCRIPTION

No information provided

PLANT: Garona
Location: Spain
Vendor: GE
License Date: 5/71
Utility: Centrales Nucleares del Norte, SA
Type: BWR/3 188" ID CONTAINMENT
MWt: 1380
MWe: 440
of Bundles: 400 8x8
Group #: G3
Code: TRAC-BF1/MOD
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00188
Issue Date: 2/91
Author: J.V. Lopez, et al
Title: Recirculation Suction Large Break LOCA
 Analysis of Santa Maria de Garona
 Nuclear Power Plant Using TRAC-BF1(G1J1)

Report Number: ICAP-00204
Issue Date: 6/91
Author: J.L. Crespo, et al
Title: Assessment of MSIV Full Closure for
 Santa Maria de Garona NPP Using TRAC BF1
 (G1J1)

Steady States: 104% thermal core power
Assessments: Loss of Load
Applications: Large Break LOCA

COMPONENT DESCRIPTION

Core: 2 axial levels, 3 radial rings
Vessel: 8 axial levels, 4 radial rings, control
 rod guide tube flow paths, core bypass
Containment: Pressure boundary
Balance of Plant: Simulated feed and steam lines
Primary or Recirc: One broken loop, one intact loop
Main Steam: simulated steam line
Control Systems: Recirc pump speed
Auxilliary Systems: Core spray, HPCI
Fuel Rod Behavior: None
Kinetics: Point kinetics

PLANT: Grand Gulf
Location: Port Gibson, Miss.
Vendor: GE
License Date: 7/85
Utility: System Energy Resources, Inc.
Type: BWR/6 238" ID CONTAINMENT 3
MWt: 3579
MWe: 1142
of Bundles: 732 8x8
Group #: G12
Code: TRAC-BD1/MOD
Q/A: N

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: P D Wheatley 208-526-9348

REFERENCES

None

Steady States: Steady state control system used
Assessments: None
Applications: None

COMPONENT DESCRIPTION

Core: 8 hydraulic levels
Vessel: 9 axial segments, 4 radial segments, 1 azimuthal segment
Containment: Pressure boundary
Balance of Plant: Feedwater is modeled
Primary or Recirc: Both recirculation loops modeled with 6 nodes per loop. Jet pumps modeled
Main Steam: 5 node steam lines, MSIV and SRVs are modeled
Control Systems: turbine flow, turbine outlet flow area, steam extraction
Auxiliary Systems: None
Fuel Rod Behavior: None
Kinetics: Power vs. time

PLANT:	Kori 1
Location:	Korea
Vendor:	W
License Date:	1978
Utility:	Korea Electric Power Corporation
Type:	2-Loop
MWt:	1723
MWe:	587
# of Bundles:	121 14x14
Group #:	W9
Code:	RELAP5/MOD2
Q/A:	Y

Organization:	EG&G Idaho, Inc.	
Admin. Contact:	R R Schultz	208-526-9508
Technical Contact:	R R Schultz	208-526-9508

REFERENCES

Report Number:	NUREG/IA-0030
Issue Date:	4/90
Author:	Bud-Dong Chong, et al
Title:	ASSESSMENT OF RELAP5/MOD2 CODE USING LOSS OF OFFSITE POWER TRANSIENT DATA OF KNU #1 PLANT

Steady States:	77.5% full power
Assessments:	Plant Blackout
Applications:	None reported

COMPONENT DESCRIPTION

Core:	Single channel, 3 node core
Vessel:	Guide tube modeled, no leak paths
Containment:	Pressure boundary
Balance of Plant:	No feedtrain
Primary or Recirc:	Both loops modeled explicitly
Main Steam:	Detailed steam lines
Control Systems:	Steam dump, turbine trip
Auxiliary Systems:	Auxiliary feedwater
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT:	Kori 3
Location:	Korea
Vendor:	W
License Date:	1/85
Utility:	Korea Electric Power Corporation
Type:	3-Loop
MWt:	2775
MWe:	800
# of Bundles:	157 17x17
Group #:	W6
Code:	RELAP5/MOD3
Q/A:	Y

Organization:	EG&G Idaho, Inc.	
Admin. Contact:	R R Schultz	208-526-9508
Technical Contact:	R R Schultz	208-526-9508

REFERENCES

Report Number:	ICAP-00213
Issue Date:	---
Author:	Kyun-Tae Kim, et al
Title:	ASSESSMENT OF RELAP5/MOD3 VERSION 5M5 USING INADVERTENT SAFETY INJECTION DATA OF KORI UNIT 3 PLANT

Steady States:	83% full power
Assessments:	Feedwater Transients
Applications:	None reported

COMPONENT DESCRIPTION

Core:	12 node single channel core
Vessel:	3 channel split downcomer
	Guide tube and leakage flows modeled
Containment:	Pressure boundary
Balance of Plant:	Detailed SGs, no feedtrain
Primary or Recirc:	All 3 loops modeled
Main Steam:	Steam lines modeled in detail
Control Systems:	Feedwater controller modeled
Auxiliary Systems:	Safety injection system
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT:	LaSalle County 1
Location:	Seneca, Ill.
Vendor:	GE
License Date:	1/84
Utility:	Commonwealth Edison Co.
Type:	BWR/5 251" ID CONTAINMENT 2c
MWt:	3293
MWe:	1036
# of Bundles:	764 8x8
Group #:	G9
Code:	TRAC-BD1/MOD
Q/A:	N
Organization:	EG&G Idaho, Inc.

Admin. Contact:	G W Johnsen	208-526-9854
Technical Contact:	J R Larson	208-526-9609

REFERENCES

None

Steady States:	85% full power
Assessments:	Stability Analysis
Applications:	None

COMPONENT DESCRIPTION

No information

PLANT:	North Anna 2
Location:	Mineral, Va.
Vendor:	W
License Date:	12/80
Utility:	Virginia Power Co.
Type:	3-Loop
MWt:	2652
MWe:	915
# of Bundles:	157 17x17
Group #:	W6
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	J D Burt 208-526-9089

REFERENCES

Report Number:	EGG-NTAP-6082
Issue Date:	11/82
Author:	J. D. Burt
Title:	AUDIT CALCULATIONS FOR A MAIN STEAM LINE BREAK IN NORTH ANNA, UNIT 2 USING THE RELAP5 COMPUTER CODE

Steady States:	None
Assessments:	None
Applications:	Steam Line Breaks Plant Blackout Return to Power Transients

COMPONENT DESCRIPTION

Core:	Split core model for return to power calculations. 12 core nodes
Vessel:	4 node split lower plenum, 18 node split downcomer, split upper plenum region
Containment:	Pressure boundary
Balance of Plant:	Feedwater system modeled
Primary or Recirc:	19 nodes per loop.
Main Steam:	3 nodes, MSIV modeled. Steam generators: 8 node primary, 8 node secondary
Control Systems:	Pressurizer heaters, spray line flow, RCP speed, feedwater, steam flow.
Auxiliary Systems:	Accumulator
Fuel Rod Behavior:	None
Kinetics:	Point kinetics feedback as a function of five plant parameters.

PLANT: Nuclear One 2
Location: Russellville, Ark.
Vendor: C-E
License Date: 3/80
Utility: Arkansas Power & Light Co.
Type: 2X4 Loop
MWt: 2452
MWe: 858
of Bundles: 177 16x16
Group #: C7
Code: RELAP5/MOD1.5
Q/A: N

Organization: EG&G Idaho, Inc.
Admin. Contact: P D Bayless 208-526-9027
Technical Contact: P D Bayless 208-526-9027

REFERENCES

Report Number: EGG-NTAP-6226
Issue Date: 4/83
Author: P.D. Bayless
Title: ANALYSIS OF STEAM GENERATOR TUBE RUPTURES IN ARKANSAS NUCLEAR ONE UNIT 2

Report Number: EGG-NTAP-6309
Issue Date: 9/83
Author: P.D. Bayless
Title: ANALYSIS OF THE JUNE 24, 1980 LOSS OF OFF-SITE POWER TRANSIENT AT ARKANSAS NUCLEAR ONE UNIT 2

Report Number: EGG-SAAM-6415
Issue Date: 9/83
Author: P.D. Bayless
Title: ANALYSIS OF THE JANUARY 29, 1980 TURBINE TRIP AT ARKANSAS NUCLEAR ONE UNIT 2

Steady States: 100% Power / 100% Flow
Assessments: Plant blackout
 Turbine trip
Applications: Steam Generator Tube Ruptures

COMPONENT DESCRIPTION

Core:	6 node core, 6 node bypass
Vessel:	3 node lower plenum, 10 node downcomer, 5 node upper plenum/upper head region.
Containment:	Pressure boundary
Balance of Plant:	Main feedwater is modeled
Primary or Recirc:	Both loops modeled in detail
Main Steam:	Both steam lines modeled in detail
Control Systems:	
Auxiliary Systems:	Emergency feedwater, HPCI, charging and let down systems are included.
Fuel Rod Behavior:	None
Kinetics:	Power vs. time tables

PLANT:	Oconee 1
Location:	Seneca, S.C.
Vendor:	B&W
License Date:	7/73
Utility:	Duke Power Co.
Type:	2-Loop Low
MWt:	2452
MWe:	846
# of Bundles:	177 15x15
Group #:	B3
Code:	RELAP5/MOD2
Q/A:	Y
 Organization:	 EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	C D Fletcher 208-526-9859

REFERENCES

Report Number:	EGG-NTAP-6190
Issue Date:	3/83
Author:	M. A. Bolander, et. al.
Title:	RELAP5 ANALYSIS OF OCONEE-1 PRESSURIZED WATER REACTOR TRANSIENTS FOR THE PRESSURIZED THERMAL SHOCK INTEGRATION STUDY

Report Number:	NUREG/CR-3761
Issue Date:	6/84
Author:	C. D. Fletcher, et. al.
Title:	RELAP5 THERMAL-HYDRAULIC ANALYSES OF PRESSURIZED THERMAL SHOCK SEQUENCES FOR THE OCONEE-1 PRESSURIZED WATER REACTOR

Report Number:	EGG-RTH-7066
Issue Date:	10/85
Author:	M. A. Bolander
Title:	RELAP5 THERMAL-HYDRAULIC ANALYSES FOR TWO PRESSURIZED THERMAL SHOCK SEQUENCES FOR THE OCONEE-1 PWR

Steady States:	100% Power / 100% Flow
Assessments:	None
Applications:	Steam Line Breaks Feedwater Transients Small Break LOCA Steam Generator Tube Ruptures

COMPONENT DESCRIPTION

Core:	6 Node core, 6 Node bypass
Vessel:	2 node lower plenum, 9 node downcomer, 10 node upper plenum/ upper head region
Containment:	Pressure boundary
Balance of Plant:	Feedwater and turbine valves
Primary or Recirc:	Both loops modelled. 27 Nodes per loop. Pressurizer spray line is included
Main Steam:	Steam lines, MSIV, turbine stop valves, turbine bypass valves are modeled
Control Systems:	B&W integrated control system (ICS) is modeled.
Auxiliary Systems:	HPI, LPI, Accumulators, emergency feedwater
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT:	Oconee 1
Location:	Seneca, S.C.
Vendor:	B&W
License Date:	7/73
Utility:	Duke Power Co.
Type:	2-Loop Low
MWt:	2452
MWe:	846
# of Bundles:	177 15x15
Group #:	B3
Code:	RELAP5/SCDAP/MOD3
Q/A:	Y
 Organization:	 EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	J C Determan 208-526-2888

REFERENCES

Report Number:	EGG-EAST-9793
Issue Date:	7/91
Author:	J.C. Determan, et al
Title:	DEVELOPEMENT OF A SCDAP/RELAP5/MOD3 MODEL OF OCONEE 1 FOR USE WITH THE NUCLEAR PLANT ANALYZER

Steady States:	100% Power / 100% Flow
Assessments:	None
Applications:	Large Break LOCA Small Break LOCA

COMPONENT DESCRIPTION

Core:	Single channel, six-node core
Vessel:	2 node lower plenum, 10 node upper plenum/upper head region
Containment:	Pressure boundary
Balance of Plant:	Feedwater and turbine valves
Primary or Recirc:	Both loops modelled. Pressurizer spray line is included
Main Steam:	Steam lines, MSIV, turbine stop valves, turbine bypass valves are modeled
Control Systems:	B&W integrated control system (ICS) is modeled.
Auxiliary Systems:	HPI, LPI, Accumulators, emergency feedwater
Fuel Rod Behavior:	SCDAP input for single channel core
Kinetics:	Point Kinetics

PLANT: Oconee 1
Location: Seneca, S.C.
Vendor: B&W
License Date: 7/73
Utility: Duke Power Co.
Type: 2-Loop Low
MWt: 2452
MWe: 846
of Bundles: 177 15x15
Group #: B3
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: M W Cappiello 505-667-4097
Technical Contact: M W Cappiello 505-667-4097

REFERENCES

Report Number: NUREG/CR-3706
Issue Date: 5/85
Author: B. Bassett, et. al.
Title: TRAC ANALYSES OF SEVERE OVERCOOLING
TRANSIENTS FOR THE OCONEE-1 PWR

Report Number: NUREG/CR-4140
Issue Date: 4/85
Author:
Title: DOMINANT ACCIDENT SEQUENCES IN OCONEE-1
PRESSURIZED WATER REACTOR

Report Number: LA-UR-86-1310
Issue Date: 4/86
Author: Henry J. Stumpf
Title: USE OF TURBINE BYPASS VALVES TO CODE AND
DEPRESSURIZE OCONEE-1 FOLLOWING A
SMALL-BREAK LOSS-OF-COOLANT ACCIDENT
WITH FAILURE OF THE HIGH PRESSURE
INJECTION SYSTEM

Report Number: LA-UR-84-3284
Issue Date: 1984
Author: B. Nassersharif
Title: INTERFACING SYSTEMS LOSS-OF-COOLANT
ACCIDENT IN OCONEE-1 PRESSURIZED WATER
REACTORS

Report Number:	LA-UR-84-2721
Issue Date:	1984
Author:	J. Dearing
Title:	ANALYSIS OF SMALL-SMALL BREAK LOCA SEQUENCES FOR THE OCONEE-1 PWR
Report Number:	LA-UR-84-2640
Issue Date:	1984
Author:	B. Nassersharif
Title:	INTERFACING SYSTEMS LOSS-OF-COOLANT ACCIDENT IN OCONEE-1 PRESSURIZED WATER REACTOR
Report Number:	LA-UR-84-2309
Issue Date:	1984
Author:	B. Boyack
Title:	AN ASSESSMENT OF THE UTILITY OF FEED-AND-BLEED OPERATING MAPS (OCONEE-1)
Report Number:	LA-UR-84-2078
Issue Date:	1984
Author:	R. Henninger, et al
Title:	"LOFW-INITIATED ATWS FOR OCONEE-1 USING TRAC-PF1/MOD1
Report Number:	LA-UR-84-2077
Issue Date:	1984
Author:	B. Nassersharif
Title:	INTERFACING SYSTEMS LOSS-OF-COOLANT ACCIDENT IN OCONEE-1 PRESSURIZED WATER REACTOR
Report Number:	LA-UR-83-3182
Issue Date:	1983
Author:	J. Ireland
Title:	TRAC ANALYSES OF SEVERE OVERCOOLING TRANSIENTS FOR THE OCONEE-1 PWR
Report Number:	LA-UR-83-3011
Issue Date:	10/83
Author:	J. Ireland
Title:	TRAC ANALYSIS AND SUPPORT OF OCONEE-1 PTS STUDIES
Report Number:	LA-UR-83-2894
Issue Date:	10/83
Author:	R. Henninger

Title: LOSS-OF-FEEDWATER TRANSIENTS FOR
OCONEE-1

Report Number: LA-UR-83-2888

Issue Date: 1983

Author: J. Dearing

Title: ANALYSIS OF SMALL-SMALL BREAK LOCA
SEQUENCES IN THE OCONEE-1 PLANT

Report Number: LA-UR-83-2883

Issue Date: 1983

Author: R. Henninger

Title: COMBINED SECONDARY-SIDE
BREAK/LOSS-OF-FEEDWATER TRANSIENTS FOR
OCONEE-1

Report Number: LA-UR-83-2816

Issue Date: 9/83

Author: M. Burkett, et al

Title: TRAC-PF1- PRESSURIZED THERMAL SHOCK
CALCULATIONS FOR SEVERAL
SMALL-BREAK-LOSS-OF-COOLANT ACCIDENT
TRANSIENTS IN THE OCONEE-1 NUCLEAR POWER
PLANT

Report Number: LA-UR-83-2346

Issue Date: 8/83

Author: J. Ireland

Title: TRAC ANALYSIS AND SUPPORT OF OCONEE-1
PTS STUDIES

Report Number: LA-UR-83-2288

Issue Date: 1983

Author: J. Dearing

Title: ANALYSIS OF SMALL-SMALL-BREAK LOCA
SEQUENCES IN THE OCONEE-1 POWER PLANT

Report Number: LA-UR-83-0960

Issue Date: 3/83

Author: B. Bassett

Title: TRAC THERMAL-HYDRAULIC ANALYSIS OF THE
OCONEE-1 PWR FOR THE PRESSURIZED THERMAL
SHOCK PROJECTS

Report Number: LA-TCN-TN-83-1

Issue Date: 1983

Author: J. Ireland

Title:	TRAC ANALYSIS OF SEVERE OVERCOOLING TRANSIENTS FOR THE OCONEE-1 PWR
Report Number:	LA-UR-82-3720
Issue Date:	12/82
Author:	M. W. Burkett
Title:	TRAC-PF1 PRESSURIZED THERMAL SHOCK CALCULATION FOR SEVERAL SMALL BREAK TRANSIENTS IN THE OCONEE-1 NUCLEAR POWER PLANT
Steady States:	100% Power/ 100% Flow
Assessments:	Turbine Trip
Applications:	Large Break LOCA Feed and Bleed Recovery

COMPONENT DESCRIPTION

Core:	6 axial levels, 6 theta segments, 1 radial ring
Vessel:	14 axial levels, 2 radial rings, 6 azimuthal segments
Containment:	Pressure boundary
Balance of Plant:	Main feedwater is modeled
Primary or Recirc:	Both loops modeled in detail
Main Steam:	Pressure boundary
Control Systems:	Basic plant protection
Auxiliary Systems:	HPI, LPI, accumulators
Fuel Rod Behavior:	Detailed reflood mode
Kinetics:	Input power table only

PLANT:	Phillipsburg 2
Location:	Germany
Vendor:	KWU
License Date:	4/85
Utility:	Kernkraftwerk Phillipsburg
Type:	4-Loop
MWt:	3765
MWe:	1300
# of Bundles:	193 16x16
Group #:	W2
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	R R Schultz 208-526-9508

REFERENCES

Report Number:	NUREG/IA-0057
Issue Date:	4/92
Author:	G. Gerth
Title:	Assessment Study of RELAP5/MOD2 Cycle 36.04 Based on the Commissioning Test Reactor Trip at Full Load at the Phillipsburg 2 Nuclear Power Plant
Steady States:	100% power
Assessments:	Plant Trip
Applications:	None reported

COMPONENT DESCRIPTION

Core:	Single channel, 8 level core
Vessel:	Core bypass and upper head leakage paths
Containment:	Pressure boundary
Balance of Plant:	Detailed SG, no feedtrain
Primary or Recirc:	One triple loop, one single loop, simple pressurizer
Main Steam:	Detailed steamline
Control Systems:	No information
Auxilliary Systems:	No information
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT: R. E. Ginna
Location: Ontario, N.Y.
Vendor: W
License Date: 7/70
Utility: Rochester Gas & Electric Corp.
Type: 2-Loop
MWt: 1300
MWe: 470
of Bundles: 121 14x14
Group #: W9
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: J F Lime 505-667-4097
Technical Contact: J F Lime 505-667-4097

REFERENCES

Report Number: LA-UR-86-2818
Issue Date: 8/86
Author: J. F. Lime, et al
Title: THE GINNA TUBE-RUPTURE EVENT : A
PLANT-TRANSIENT BENCHMARK FOR TRAC

Report Number: LA-UR-86-0205
Issue Date: 1/86
Author: J. F. Lime, et al
Title: RAPID-RESPONSE ANALYSIS OF THE
DAVIS-BESSE LOSS-OF-FEEDWATER EVENT OF
JUNE 9, 1985

Report Number: LA-UR-85-3117
Issue Date: 8/85
Author: R. P. Jenks, et al
Title: PRELIMINARY TRAC CALCULATION OF R. E.
GINNA STEAM GENERATOR TUBE-RUPTURE EVENT
ON JANUARY 25, 1982

Report Number: NUREG/CR-4988
Issue Date: 9/87
Author: J. F. Lime, et al
Title: A TRAC-PF1/MOD1 ANALYSIS OF THE GINNA
TUBE-RUPTURE EVENT ON JANUARY 25, 1982

Steady States: 100% core power
Assessments: Steam Generator Tube Ruptures

Applications: Steam Generator Tube Ruptures

COMPONENT DESCRIPTION

Core:	1 radial ring, 4 azimuthal sectors
Vessel:	2 radial rings, 4 azimuthal sectors, 12 axial levels
Containment:	Pressure boundary
Balance of Plant:	
Primary or Recirc:	both loops modeled individually
Main Steam:	turbine stop valve, steam dump
Control Systems:	SG level, PORV control, turbine trips, main feedwater trips,
Auxiliary Systems:	Auxiliary feedwater
Fuel Rod Behavior:	8 radial nodes, conduction and reflood
Kinetics:	Input power table only

PLANT:	RESAR
Location:	N/A
Vendor:	W
License Date:	N/A
Utility:	N/A
Type:	4-Loop
MWt:	N/A
MWe:	N/A
# of Bundles:	193 17 x 17
Group #:	W2
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	J M Cozzoul 208-526-9901

REFERENCES

Report Number:	NUREG/CR-4384
Issue Date:	3/86
Author:	
Title:	BREAK SPECTRUM ANALYSIS FOR SMALL BREAK LOSS OF COOLANT ACCIDENTS IN A RESAR-3S PLANT
Report Number:	EGG-NTAP-6032
Issue Date:	9/82
Author:	
Title:	BEST ESTIMATE ANALYSIS OF A SMALL BREAK LOCA IN A RESAR-3S PRESSURIZED WATER REACTOR
Steady States:	100% power, 100% Flow
Assessments:	None
Applications:	Small Break LOCA Feed and bleed recovery

COMPONENT DESCRIPTION

Core:	Six node, single channel core
Vessel:	Guide tube bypass modeled
Containment:	Pressure boundary
Balance of Plant:	Detailed steam generators, no feedtrain
Primary or Recirc:	3 lumped loops, 1 explicit loop
Main Steam:	Pressure boundary
Control Systems:	None
Auxiliary Systems:	ECCS modeled on lumped loop
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT:	RESAR
Location:	N/A
Vendor:	W
License Date:	N/A
Utility:	N/A
Type:	4-Loop
MWt:	N/A
MWe:	N/A
# of Bundles:	193 17 x 17
Group #:	W2
 Code:	 TRAC-PF1/MOD2
Q/A:	Y
 Organization:	 Los Alamos National Laboratory
Admin. Contact:	J W Spore 505-667-2125
Technical Contact:	J W Spore 505-667-2125

REFERENCES

Report Number:	LA-UR-85-0858
Issue Date:	3/85
Author:	R. Fujita, et al
Title:	TRAC-PF1 ANALYSIS OF A BEST-ESTIMATE LARGE-BREAK LOCA IN A WESTINGHOUSE PWR WITH FOUR LOOPS AND 17X17 FUEL
 Report Number:	 LA-UR-84-2056
Issue Date:	1984
Author:	J. F. Lime
Title:	LOSS-OF-FEEDWATER/FEED AND BLEED IN A WESTINGHOUSE THREE-LOOP, LOW-HEAD SAFETY INJECTION PWR
 Report Number:	 LA-UR-84-0109
Issue Date:	1/84
Author:	E. Barts, et al
Title:	TRAC-PF1 STUDY OF LOSS OF PUMP SEALS IN A WESTINGHOUSE PWR
 Report Number:	 LA-UR-85-3117
Issue Date:	8/85
Author:	R. P. Jenks, et al
Title:	PRELIMINARY TRAC CALCULATION OF R. E. GINNA STEAM GENERATOR TUBE-RUPTURE EVENT ON JANUARY 25, 1982

Report Number: LA-UR-82-3237
Issue Date: 11/82
Author: J. F. Lime
Title: TRAC-PD2 CALCULATIONS OF A
MAIN-STEAM-LINE BREAK IN A WESTINGHOUSE
PRESSURIZED WATER REACTOR-COOLANT PUMP
TRIP

Report Number: LA-UR-82-3235
Issue Date: 11/82
Author: J. F. Lime
Title: TRAC-PD2 CALCULATION OF A COLD-LEG SMALL
BREAK IN A WESTINGHOUSE FOUR-LOOP
PRESSURIZED WATER REACTOR

Report Number: NUREG/CR-3312
Issue Date: 5/83
Author: J. E. Elliott
Title: EFFECTS OF THE REACTOR COOLANT PUMPS
FOLLOWING A SMALL BREAK IN A
WESTINGHOUSE PWR

Steady States:
Assessments: None
Applications: Large Break LOCA

COMPONENT DESCRIPTION

Core:
Vessel: 17 axial levels, 4 radial rings,
8 theta segments
Containment: Pressure boundary
Balance of Plant: Feedwater modeled
Primary or Recirc: All four loops modeled
Main Steam: Steam line modeled
Control Systems: Basic plant protection for LBLOCA
Auxiliary Systems: HPI, LPI, accumulator
Fuel Rod Behavior: None
Kinetics: Point Kinetics

PLANT:	Ringhals 2	
Location:	Sweden	
Vendor:	W	
License Date:	5/75	
Utility:	Statens Vattenfallsverk	
Type:	3-Loop	
MWt:	2440	
MWe:	800	
# of Bundles:	157 15x15	
Group #:	W7	
Code:	TRAC-PF1/MOD1	
Q/A:	Y	
 Organization:	 EG&G Idaho, Inc.	
Admin. Contact:	G W Johnsen	208-526-9854
Technical Contact:	R R Schultz	208-526-9508

REFERENCES

Report Number:	ICAP-00145
Issue Date:	2/88
Author:	F. Pelayo, et al
Title:	Assessment of TRAC-PF1/MOD1 Against an Inadvertent Steam Line Isolation Valve Closure in the Ringhals 2 Power Plant

Steady States:	80% core power
Assessments:	Loss of Load
Applications:	None reported

COMPONENT DESCRIPTION

Core:	5 axial levels, average core and hot rod
Vessel:	1-D vessel, core bypass, upper head leakage
Containment:	Pressure boundary
Balance of Plant:	Detailed SG, no feedtrain
Primary or Recirc:	2 double loop one single loop detailed pressurizer
Main Steam:	Detailed steamlines
Control Systems:	Pressurizer pressure and level, steam line break protection
Auxilliary Systems:	Detailed accumulator, HPSI, LPSI, CVCS
Fuel Rod Behavior:	None
Kinetics:	Point kinetics

PLANT:	Ringhals 4
Location:	Sweden
Vendor:	W
License Date:	11/83
Utility:	Statens Vattenfallsverk
Type:	3-Loop
MWt:	2775
MWe:	915
# of Bundles:	157 17x17
Group #:	W6
Code:	TRAC-PF1/MOD1
Q/A:	Y
 Organization:	 EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	R R Schultz 208-526-9508

REFERENCES

Report Number:	NUREG/IA-0038
Issue Date:	3/92
Author:	A. Sjoberg
Title:	Assessment of TRAC-PF1/MOD1 Against an Inadvertent Feedwater Line Isolation Transient in the Ringhals 4 Power Plant

Report Number:	ICAP-00053
Issue Date:	3/87
Author:	A. Sjoberg
Title:	Assessment of TRAC-PF1/MOD1 Against a Loss of Grid Transient in Ringhals 4 Power Plant

Steady States:	100% core power
Assessments:	Plant Blackout Feedwater Transients
Applications:	None reported

COMPONENT DESCRIPTION

Core:	1-D, seven levels
Vessel:	1-D, core bypass, basic nodalization
Containment:	Pressure boundary
Balance of Plant:	Detailed SG, no feedtrain
Primary or Recirc:	All 3 loops lumped into one, detailed pressurizer
Main Steam:	detailed steamline
Control Systems:	Pressurizer pressure and level, scram turbine trip and SG aux feed on SG level
Auxilliary Systems:	None
Fuel Rod Behavior:	None
Kinetics:	Point Kinetics

PLANT: Robinson 2
Location: Hartsville, S.C.
Vendor: W
License Date: 3/71
Utility: Carolina Power & Light Co.
Type: 3-Loop
MWt: 2094
MWe: 665
of Bundles: 157 15x15
Group #: W7
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: G W Johnsen 208-526-9854
Technical Contact: C D Fletcher 208-526-9859

REFERENCES

Report Number: NUREG/CR-3977
Issue Date: 4/85
Author: C. D. Fletcher, et. al.
Title: RELAP5 THERMAL-HYDRAULIC ANALYSES OF PRESSURIZED THERMAL SHOCK SEQUENCES FOR THE H. B. ROBINSON UNIT 2 PRESSURIZED WATER REACTOR

Report Number: NUREG/CR-3935
Issue Date: 5/85
Author: C. D. Fletcher, et. al.
Title: THERMAL-HYDRAULIC ANALYSES OF OVERCOOLING SEQUENCES FOR THE H. B. ROBINSON UNIT 2 PRESSURIZED THERMAL SHOCK STUDY

Steady States: 2300 MWt (rated), 2200 MWt, Hot Standby
Assessments: Plant Trip
Applications: Small Break LOCA
 Steam Line Breaks
 Steam Generator Tube Ruptures
 Stuck Open PORV
 Feedwater Transients
 Feed and Bleed Recovery

COMPONENT DESCRIPTION

Core:	Six node average core and six node bypass
Vessel:	3 Node Lower Plenum, 12 Node downcomer Seven Node Upper Plenum/ Upper head
Containment:	Pressure boundary
Balance of Plant:	Feedwater and Turbines modelled
Primary or Recirc:	All three loops modelled explicitly, 130 total volumes
Main Steam:	Steam lines are modelled to the condenser
Control Systems:	Steam dump, SG level, pressurizer level and pressure
Auxiliary Systems:	HPI, LPI, Makeup, Accumulator, Auxiliary Feedwater
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT:	Robinson 2
Location:	Hartsville, S.C.
Vendor:	W
License Date:	3/71
Utility:	Carolina Power & Light Co.
Type:	3-Loop
MWt:	2094
MWe:	665
# of Bundles:	157 15x15
Group #:	W7
Code:	RELAP5/MOD3
Q/A:	N

Organization:	EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	P A Roth 208-526-9188

REFERENCES

None

Steady States:	2300 MWt (rated)
Assessments:	None
Applications:	None

COMPONENT DESCRIPTION

Core:	Six node average core and six node bypass
Vessel:	3 Node Lower Plenum, 12 Node downcomer Seven Node Upper Plenum/ Upper head
Containment:	Pressure boundary
Balance of Plant:	Feedwater and Turbines modelled
Primary or Recirc:	All three loops modelled explicitly, 130 total volumes
Main Steam:	Steam lines are modelled to the condenser
Control Systems:	Steam dump, SG level, pressurizer level and pressure
Auxiliary Systems:	HPI, LPI, Makeup, Accumulator, Auxiliary Feedwater
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT:	Robinson 2
Location:	Hartsville, S.C.
Vendor:	W
License Date:	3/71
Utility:	Carolina Power & Light Co.
Type:	3-Loop
MWt:	2094
MWe:	665
# of Bundles:	157 15x15
Group #:	W7
Code:	TRAC-PF1/MOD1
Q/A:	Y
Organization:	Los Alamos National Laboratory
Admin. Contact:	J F Lime 505-667-4097
Technical Contact:	J F Lime 505-667-4097

REFERENCES

Report Number:	LA-UR-84-2101
Issue Date:	6/84
Author:	J. F. Lime
Title:	A PRIMARY-SYSTEM FEED-AND-BLEED TRANSIENT IN A THREE-LOOP PRESSURIZED WATER REACTOR FOLLOWING A COMPLETE LOSS OF FEEDWATER WITH DELAYED REACTOR TRIP
Steady States:	100% core power
Assessments:	None
Applications:	Small Break LOCA Steam Generator Tube Ruptures Feed and Bleed Recovery

COMPONENT DESCRIPTION

Core:	1 radial ring, 6 azimuthal sectors, 4 axial levels
Vessel:	2 radial rings, 6 azimuthal sectors, 12 axial levels
Containment:	Pressure boundary
Balance of Plant:	Steam generators modeled in detail
Primary or Recirc:	All loops modeled individually
Main Steam:	Turbine stop valves and steam dump valves modeled
Control Systems:	SG level, PORV, main feedwater, aux. feedwater, pressurizer pressure
Auxiliary Systems:	pressurizer heater control
Fuel Rod Behavior:	8 radial nodes in fuel, gap, and cladding
Kinetics:	Input power table only

PLANT:	Seabrook
Location:	Seabrook, N.H.
Vendor:	W
License Date:	/90
Utility:	New Hampshire Yankee
Type:	4-Loop
MWt:	3425
MWe:	1150
# of Bundles:	193 17x17
Group #:	W2
Code:	RELAP5/MOD2
Q/A:	Y
Organization:	EG&G Idaho, Inc.
Admin. Contact:	P D Bayless 208-526-9027
Technical Contact:	P D Bayless 208-526-9027

REFERENCES

Report Number:	EGG-NTP-6700
Issue Date:	9/84
Author:	P. D. Bayless, et. al.
Title:	ANALYSIS OF A STATION BLACKOUT TRANSIENT AT THE SEABROOK NUCLEAR POWER PLANT

Steady States:	100% Power/ 100% Flow
Assessments:	None
Applications:	Plant Blackout Severe Accident Scenarios

COMPONENT DESCRIPTION

Core:	2 core models: 1) single channel 6 nodes 2) three channel with crossflow
Vessel:	3 node lower plenum, 11 node downcomer, 9 node upper plenum/ upper head
Containment:	Pressure boundary
Balance of Plant:	Feedwater modeled
Primary or Recirc:	Three loops lumped into one, plus one single loop.
Main Steam:	MSIV and SRV modeled
Control Systems:	None
Auxiliary Systems:	None
Fuel Rod Behavior:	None
Kinetics:	Power vs. time table

PLANT: Seabrook
Location: Seabrook, N.H.
Vendor: W
License Date: /90
Utility: New Hampshire Yankee
Type: 4-Loop
MWt: 3425
MWe: 1150
of Bundles: 193 17x17
Group #: W2
Code: RELAP5/SCDAP/MOD3
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: K R Jones 208-526-0809
Technical Contact: K R Jones 208-526-0809

REFERENCES

Report Number: NUREG/CR-5787
Issue Date: 3/92
Author: K. R. Jones, et al
Title: TIMING ANALYSIS OF PWR FUEL PIN FAILURE

Steady States: 100% Power/ 100% Flow
Assessments: None
Applications: Severe Accident Scenarios

COMPONENT DESCRIPTION

Core: 3 channel, 9 node core
Vessel: 2 channel split downcomer
Containment: Pressure boundary
Balance of Plant: Feedwater modeled
Primary or Recirc: Three loops lumped into one, plus one single loop.
Main Steam: MSIV and SRV modeled
Control Systems: None
Auxiliary Systems: None
Fuel Rod Behavior: SCDAP fuel model used
Kinetics: Point kinetics

PLANT:	SNUPPS	
Location:	N/A	
Vendor:	W	
License Date:	N/A	
Utility:	N/A	
Type:	4-Loop	
MWt:	N/A	
MWe:	N/A	
# of Bundles:	193 17 x 17	
Group #:	W2	
Code:	RELAP5/MOD2	
Q/A:	N	
Organization:	EG&G Idaho, Inc.	
Admin. Contact:	G W Johnsen	208-526-9854
Technical Contact:	C M Kullberg	208-526-9565

REFERENCES

Report Number:	NUREG/CR-5557
Issue Date:	4/90
Author:	C.M. Kullberg
Title:	RELAP5 Thermal-Hydraulic Analysis of the SNUPPS Pressurized Water Reactor

Steady States:	100% power, 100% flow
Assessments:	None
Applications:	Plant Blackout Small Break LOCA Steam Line Breaks Steam Generator Tube Ruptures Feedwater Transients

COMPONENT DESCRIPTION

Core:	Single channel, 3 node core
Vessel:	Guide tube flow and leakages modeled
Containment:	Pressure boundary
Balance of Plant:	Detailed feedtrain and SGs
Primary or Recirc:	All four loops modeled
Main Steam:	Detailed steam lines modeled
Control Systems:	None
Auxiliary Systems:	Accumulator, HPI, LPI modeled
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT: Surry 1
Location: Gravel Neck, Va.
Vendor: W
License Date: 12/72
Utility: Virginia Power Co.
Type: 3-Loop
MWt: 2441
MWe: 781
of Bundles: 157 15x15
Group #: W7
Code: RELAP5/SCDAP/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: P D Bayless 208-526-9027
Technical Contact: P D Bayless 208-526-9027

REFERENCES

Report Number: NUREG/CR-5214
Issue Date: 10/88
Author: P. D. Bayless
Title: ANALYSES OF NATURAL CIRCULATION DURING A
 SURRY STATION BLACKOUT USING SCDAP/
 RELAP5

Steady States: 12% core power
Assessments: None
Applications: Severe Accident Scenarios
 Plant Blackout

COMPONENT DESCRIPTION

Core: 2 core models: 1) Single channel, 10
 node core 2) 3 channel, 10 node core
Vessel: 2 node lower plenum, 11 node downcomer.
 8 node upper plenum/ upper head
Containment: Pressure boundary
Balance of Plant: Feedwater modeled
Primary or Recirc: All three loops modeled
Main Steam: One node steam line with MSIV, PORV and
 Safety valves
Control Systems: None
Auxiliary Systems: Auxiliary feedwater, HPI, LPI,
 Accumulator
Fuel Rod Behavior: SCDAP used
Kinetics: Point kinetics.

PLANT: Three Mile Island 1
Location: Londonderry Twp., Pa.
Vendor: B&W
License Date: 9/74
Utility: GPU Nuclear Corp.
Type: 2-Loop Low
MWt: 2452
MWe: 808
of Bundles: 177 15x15
Group #: B3
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: B B Boyack 505-667-4097
Technical Contact: B B Boyack 505-667-4097

REFERENCES

Report Number: LA-UR-89-2115
Issue Date: 6/89
Author: Frank Motley
Title: NATURAL CIRCULATION AND STRUCTURAL HEATUP IN TMI-2 AFTER CORE RECOVERY

Report Number: LA-UR-88-3348
Issue Date: 10/88
Author: Frank Motley, et al
Title: MODELING OF THE TMI-2 ACCIDENT WITH MELPROG/TRAC AND CALCULATION RESULTS FOR PHASES 1 AND 2

Report Number: LA-UR-88-1364
Issue Date: 4/88
Author: Richard Jenks
Title: PRELIMINARY MODELING OF THE TMI-2 ACCIDENT WITH MELPROG/TRAC

Report Number: LA-UR-85-1404
Issue Date: 8/85
Author: B. Nassersharif
Title: ANALYSIS OF MULTIPLE-TUBE RUPTURE IN BOTH STEAM GENERATORS FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR

Report Number: LA-UR-85-0946
Issue Date: 1985
Author: B. Nassersharif
Title: ANALYSIS OF MULTIPLE TUBE RUPTURES IN BOTH STEAM GENERATORS FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR. (NEWPORT)

Report Number:	LA-UR-85-0355
Issue Date:	1/85
Author:	B. Nassersharif
Title:	ALTERNATE STEAM GENERATOR TUBE RUPTURE MITIGATION STRATEGIES FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR DURING A LOSS-OF-OFFSITE POWER
Report Number:	LA-UR-85-0182
Issue Date:	1985
Author:	B. Nassersharif
Title:	ALTERNATE STEAM GENERATOR TUBE RUPTURE MITIGATION STRATEGIES FOR THE THREE MILE ISLAND UNIT 1 DURING A LOSS-OF-OFFSITE POWER
Report Number:	LA-UR-85-3555
Issue Date:	1985
Author:	B. Nassersharif
Title:	ALTERNATE STEAM GENERATOR TUBE RUPTURE MITIGATION STRATEGIES FOR THE THREE MILE ISLAND UNIT 1 DURING A LOSS-OF-OFFSITE POWER (DENVER PAPER)
Report Number:	LA-UR-84-3588
Issue Date:	1984
Author:	B. Boyack
Title:	ALTERNATIVE STEAM GENERATOR TUBE RUPTURE MITIGATION ON STRATEGIES FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR DURING A LOSS-OF-OFFSITE POWER
Report Number:	LA-UR-84-2586
Issue Date:	1984
Author:	B. Nassersharif
Title:	ANALYSIS OF MULTIPLE TUBE RUPTURES IN BOTH STEAM GENERATORS FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR
Report Number:	LA-UR-84-3465
Issue Date:	1984
Author:	B. Nassersharif
Title:	ALTERNATE STEAM GENERATOR TUBE RUPTURE MITIGATION STRATEGIES FOR THE THREE MILE ISLAND-1 PRESSURIZED WATER REACTOR DURING A LOSS-OF-OFFSITE POWER
Report Number:	LA-UR-83-2335
Issue Date:	8/83
Author:	E. Schwegler
Title:	FUEL MODELS AND RESULTS FROM THE TRAC-PF1/MIMAS TMI-2 ACCIDENT

CALCULATION

Report Number: LA-UR-83-1743
Issue Date: 1983
Author: R. Henninger, et al
Title: TRAC-PF1 FEED-AND-BLEED CALCULATIONS FOR TMI-1 ANS PAPER

Report Number: LA-UR-83-0963
Issue Date: 3/83
Author: E. C. Schwegler
Title: FUEL MODELS AND RESULTS FROM THE TRAC-PF1/MIMAS TMI-2 ACCIDENT CALCULATION

Report Number: LA-UR-83-0904
Issue Date: 1983
Author: P. J. Maudlin
Title: INTEGRATED ANALYSIS OF THE TMI-2 ACCIDENT

Report Number: LA-UR-83-0737
Issue Date: 1983
Author: P. Maudlin, et al
Title: DAMAGE ASSESSMENT OF TMI-2

Report Number: LA-UR-82-5096
Issue Date: 6/82
Author: J. R. Ireland
Title: THREE MILE ISLAND AND MULTIPLE FAILURE ACCIDENTS

Report Number: LA-UR-82-3278
Issue Date: 11/82
Author: D. Dobranich
Title: STEAM GENERATOR TUBE RUPTURE ANALYSIS FOR TMI-1

Report Number: LA-UR-82-1786
Issue Date: /83
Author:
Title: TRAC ANALYSIS OF STEAM-GENERATOR OVERFILL TRANSIENTS FOR TMI-1

Report Number: LA-UR-81-1230
Issue Date: 4/81
Author: J. R. Ireland
Title: THERMAL HYDRAULIC AND CORE DAMAGE ANALYSES OF THE TMI-2 ACCIDENT

Report Number: LA-UR-80-5044
Issue Date: 10/80

Author:	W. R. Stratton
Title:	ALTERNATIVE EVENT SEQUENCES - TECHNICAL STAFF ANALYSIS REPORT ON ALTERNATIVE EVENT SEQUENCES TO PRESIDENT'S COMMISSION ON THE ACCIDENT AT THREE MILE ISLAND
Report Number:	LA-UR-80-1069
Issue Date:	4/80
Author:	W. L. Kirchner
Title:	FUEL DAMAGE ESTIMATES FOR THE TMI-2 REACTOR
Report Number:	LA-UR-80-0998
Issue Date:	4/80
Author:	R. D. Burns
Title:	EVALUATION OF THE THREE MILE ISLAND ACCIDENT IN THE CONTEXT OF WASH - 1400
Report Number:	LA-UR-80-0997
Issue Date:	4/80
Author:	P. K. Mast
Title:	ANALYSIS OF EARLY CORE DAMAGE AT THREE MILE ISLAND
Report Number:	LA-UR-79-2968
Issue Date:	10/79
Author:	W. L. Kirchner
Title:	FUEL DAMAGE ESTIMATES FOR THE TMI-2 REACTOR
Report Number:	LA-UR-79-2948
Issue Date:	10/79
Author:	R. D. Burns
Title:	EVALUATION OF THE THREE MILE ISLAND ACCIDENT IN THE CONTEXT OF WASH - 1400
Report Number:	LA-UR-79-2942
Issue Date:	10/79
Author:	P. K. Mast, et al
Title:	ANALYSIS OF EARLY CORE DAMAGE AT THREE MILE ISLAND
Report Number:	LA-UR-79-2425
Issue Date:	9/79
Author:	W. L. Kirchner
Title:	PRELIMINARY CALCULATIONS RELATED TO THE ACCIDENT AT THREE MILE ISLAND
Report Number:	LA-TN-MIMAS-82-3
Issue Date:	1982
Author:	P. Maudlin, et al

Title: DAMAGE ASSESSMENT OF TMI-2

Report Number: LA-TN-MIMAS-82-1

Issue Date: 1982

Author: P. Maudlin, et al

Title: A STUDY OF VESSEL FLOW RESISTANCE FOR TMI-2

Report Number: NUREG/CR-1353

Issue Date: 3/80

Author: J.R. Ireland, et al

Title: PRELIMINARY CALCULATIONS RELATED TO THE ACCIDENT AT THREE MILE ISLAND

Steady States: 100% core power

Assessments: None

Applications: Large Break LOCA
Feed and Bleed Recovery

COMPONENT DESCRIPTION

Core: 6 axial levels, 6 theta segments,
1 radial ring

Vessel: 14 axial levels, 2 radial rings, 6
azimuthal segments, 6 vent valves

Containment: Pressure boundary

Balance of Plant: Feedwater modeled

Primary or Recirc: Both loops modeled in detail

Main Steam: Pressure boundary

Control Systems: Basic plant protection

Auxiliary Systems: HPI, LPI, Accumulators

Fuel Rod Behavior: Detailed reflood mode

Kinetics: Input power table only

PLANT:	Tihange 2
Location:	Belgium
Vendor:	FRA
License Date:	3/83
Utility:	Societe Intercommunale Belge de Gaz et d'Electricite
Type:	3-Loop
MWt:	2785
MWe:	941
# of Bundles:	157 17x17
Group #:	W6
Code:	RELAP5/MOD2
Q/A:	Y
 Organization:	 EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	R R Schultz 208-526-9508

REFERENCES

Report Number:	NUREG/IA-0044
Issue Date:	3/92
Author:	G.P. Rouel, et al
Title:	Assessment Study of RELAP5/MOD2 Cycle 36.05 Based on the Tihange-2 Reactor Trip of January 11, 1983
 Steady States:	 100% core power
Assessments:	Plant Trip
Applications:	None reported

COMPONENT DESCRIPTION

Core:	Single channel, five level core
Vessel:	Core bypass, upper head leakage paths
Containment:	Pressure boundary
Balance of Plant:	Detailed SGs, no feedtrain
Primary or Recirc:	3 explicit loops, detailed pressurizer
Main Steam:	Detailed steam lines
Control Systems:	
Auxilliary Systems:	ECCS, chemical and volume control
Fuel Rod Behavior:	
Kinetics:	None

PLANT: Vandellos 2
Location: Spain
Vendor: W
License Date: 3/88
Utility: Asociacion Nuclear Vandellos
Type: 3-Loop
MWt: 2775
MWe: 982
of Bundles: 157 17x17
Group #: W6
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00215
Issue Date: 9/91
Author: C. Llopis
Title: ASSESSMENT OF RELAP5/MOD2 AGAINST A LOAD REJECTION FROM 100% TO 50% POWER IN THE VANDELLOS II NUCLEAR POWER PLANT

Report Number: ICAP-00216
Issue Date: ---
Author: C. Llopis
Title: ASSESSMENT OF RELAP5/MOD2 AGAINST A TURBINE TRIP FROM 100% POWER IN THE VANDELLOS II NUCLEAR POWER PLANT

Report Number: ICAP-00218
Issue Date: 9/91
Author: C. Llopis, et al
Title: ASSESSMENT OF RELAP5/MOD2 AGAINST A 10% LOAD REJECTION TRANSIENT FROM 75% STEADY STATE IN THE VANDELLOS II NUCLEAR POWER PLANT

Report Number: ICAP-00219
Issue Date: 9/91
Author: C. Llopis
Title: ASSESSMENT OF RELAP5/MOD2 AGAINST A MAIN FEEDWATER TURBOPUMP TRIP TRANSIENT IN THE VANDELLOS II NUCLEAR POWER PLANT

Steady States:	75% power; 100% power; 99.2% power
Assessments:	Loss of Load Turbine Trip Feedwater Transients
Applications:	None reported

COMPONENT DESCRIPTION

Core:	Single channel, 6 node core
Vessel:	Core bypass included
Containment:	Pressure boundary
Balance of Plant:	Detailed SG secondary, no feedtrain
Primary or Recirc:	All 3 loops lumped into 1
Main Steam:	Detailed steamline
Control Systems:	Rod control, pressurizer level, FW, and turbine and steam dump control
Auxiliary Systems:	None
Fuel Rod Behavior:	None
Kinetics:	Point Kinetics

PLANT: Vandellos 2
Location: Spain
Vendor: W
License Date: 3/88
Utility: Asociacion Nuclear Vandellos
Type: 3-Loop
MWt: 2775
MWe: 982
of Bundles: 157 17x17
Group #: W6
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00175
Issue Date: 9/90
Author: A. Querol, et al
Title: ASSESSMENT OF TRAC-PF1/MOD1 AGAINST A
 LOAD REJECTION FROM 100% TO 50% IN THE
 VANDELLOS II NUCLEAR POWER PLANT

Report Number: ICAP-00176
Issue Date: 9/90
Author: A. Querol
Title: ASSESSMENT OF TRAC-PF1/MOD1 AGAINST A
 TURBINE TRIP FROM 100% POWER IN THE
 VANDELLOS II NUCLEAR POWER PLANT

Steady States: 100% power
Assessments: Loss of Load
 Turbine Trip
Applications: None reported

COMPONENT DESCRIPTION

Core: Single channel, 6 node core
Vessel: Core bypass included
Containment: Pressure boundary
Balance of Plant: Detailed SG secondary, no feedtrain
Primary or Recirc: All 3 loops lumped into 1
Main Steam: Detailed steamline
Control Systems: Rod control, pressurizer level, FW, and
 turbine and steam dump control
Auxiliary Systems: None
Fuel Rod Behavior: None
Kinetics: Point Kinetics

PLANT:	Yankee Rowe
Location:	Rowe, Mass.
Vendor:	W
License Date:	7/61
Utility:	Yankee Atomic Electric Co.
Type:	4-Loop
MWt:	540
MWe:	167
# of Bundles:	76 16x16
Group #:	W5
Code:	RELAP5/MOD3
Q/A:	N
 Organization:	 EG&G, Idaho Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	P A Roth 208-526-9188

REFERENCES

None

Steady States:	Hot zero power; 100% core power
Assessments:	None
Applications:	Small Break LOCA

COMPONENT DESCRIPTION

Core:	Single channel, 6 node core
Vessel:	3 downcomer channels, each split into quarters
Containment:	Pressure boundary
Balance of Plant:	Simulated main and aux. feed
Primary or Recirc:	4 explicit loops
Main Steam:	Includes SRVs and TBVs, each line
Control Systems:	SG level
Auxilliary Systems:	SI
Fuel Rod Behavior:	None
Kinetics:	Power input table

PLANT: Yong-Gwang 2
Location: Korea
Vendor: W
License Date: 6/87
Utility: Korea Electric Power Corporation
Type: 3-Loop
MWt: 2785
MWe: 900
of Bundles: 157 17x17
Group #: W6
Code: RELAP5/MOD2
Q/A: Y

Organization: EG&G Idaho, Inc.
Admin. Contact: R R Schultz 208-526-9508
Technical Contact: R R Schultz 208-526-9508

REFERENCES

Report Number: ICAP-00208
Issue Date: ---
Author: Namsung Arne, et al
Title: ASSESSMENT OF RELAP5/MOD2 COMPUTER CODE
 AGAINST THE NATURAL CIRCULATION TEST
 DATA FROM YONG-GWANG UNIT 2

Steady States: 3% full power
Assessments: Natural circulation test
Applications: None reported

COMPONENT DESCRIPTION

Core: Single channel, six node core
Vessel: Guide tube flow, core bypass , and
 leakage paths modeled
Containment: Pressure boundary
Balance of Plant: No feed train
Primary or Recirc: One double loop, one single loop
Main Steam: Steam lines modeled
Control Systems: Steam dump
Auxiliary Systems: ECCS
Fuel Rod Behavior: None
Kinetics: Point Kinetics

PLANT:	Zion 1
Location:	Zion, Ill.
Vendor:	W
License Date:	12/73
Utility:	Commonwealth Edison Co.
Type:	4-Loop
MWt:	3250
MWe:	1040
# of Bundles:	193 15x15
Group #:	W3
Code:	RELAP5/MOD2
Q/A:	Y
 Organization:	 EG&G Idaho, Inc.
Admin. Contact:	G W Johnsen 208-526-9854
Technical Contact:	C B Davis 208-526-9470

REFERENCES

Report Number:	NUREG/CR-4672
Issue Date:	12/86
Author:	C. D. Fletcher
Title:	ANALYSIS OF INSTRUMENT TUBE RUPTURES IN WESTINGHOUSE 4-LOOP PRESSURIZED WATER REACTORS

Steady States:	100% Power/ 100% Flow
Assessments:	None
Applications:	Instrument Tube Ruptures

COMPONENT DESCRIPTION

Core:	Six node core, Six node bypass
Vessel:	4 node lower plenum, 14 node downcomer, 10 node upper plenum/upper head
Containment:	Pressure boundary
Balance of Plant:	Feedwater modeled
Primary or Recirc:	3 primary loops lumped into 1, plus one single loop. 17 nodes per loop.
Main Steam:	Pressure boundary
Control Systems:	None
Auxiliary Systems:	auxiliary feedwater, LPI,HPI, accumulators
Fuel Rod Behavior:	None
Kinetics:	Input power table only

PLANT: Zion 1
Location: Zion, Ill.
Vendor: W
License Date: 12/73
Utility: Commonwealth Edison Co.
Type: 4-Loop
MWt: 3250
MWe: 1040
of Bundles: 193 15x15
Group #: W3
Code: TRAC-PF1/MOD1
Q/A: Y

Organization: Los Alamos National Laboratory
Admin. Contact: B B Boyack 505-667-4097
Technical Contact: B B Boyack 505-667-4097

REFERENCES

Report Number: NUREG/CR-2656
Issue Date: 5/82
Author: N.S. DeMuth, et al
Title: LOSS-OF-FEEDWATER TRANSIENTS FOR THE
ZION-1 PRESSURIZED WATER REACTOR

Report Number: LA-UR-84-3083
Issue Date: 1984
Author: B. D. Boyer
Title: AN ASSESSMENT OF THE UTILITY OF
FEED-AND-BLEED OPERATING MAP (ZION-1)

Report Number: LA-UR-83-3376
Issue Date: 1983
Author: B. E. Boyack,
Title: COMBINED MAIN FEED LINE BREAK/
LOSS-OF-FEEDWATER TRANSIENT IN THE
ZION-1 PWR

Report Number: LA-UR-83-3251
Issue Date: 1983
Author: B. Nassersharif
Title: COMBINED STEAM-GENERATOR-TUBE-RUPTURE
AND LOSS-OF-FEEDWATER TRANSIENTS FOR THE
ZION-1 PWR

Report Number: LA-UR-83-2787
Issue Date: 1983

Author:	B. E. Boyack
Title:	COMBINED MAIN-STEAM-LINE-BREAK/ LOSS-OF-FEEDWATER TRANSIENTS IN THE ZION-1 PWR
Report Number:	LA-UR-83-2684
Issue Date:	1983
Author:	B. E. Boyack
Title:	SHUTDOWN TO RESIDUAL HEAT REMOVAL COOLING IN THE ZION-1 PWR FOLLOWING A SEVERE LOSS-OF-FEEDWATER EVENT
Report Number:	LA-UR-83-1943
Issue Date:	1983
Author:	C. Watson, et al
Title:	STEAM-GENERATOR-TUBE-RUPTURE WITH OPERATOR ACTION ANALYSIS FOR ZION-1
Report Number:	LA-UR-83-2224
Issue Date:	1983
Author:	B. Boyack
Title:	LOSS-OF-FEEDWATER TRANSIENTS FOR THE ZION-1 PWR
Report Number:	LA-UR-83-1731
Issue Date:	6/83
Author:	B. Boyack
Title:	SEVERE LOSS-OF-FEEDWATER TRANSIENTS IN THE ZION-1 PWR
Report Number:	LA-UR-83-1714
Issue Date:	1983
Author:	B. Boyack
Title:	LOSS-OF-OFFSITE POWER TRANSIENT FOR THE ZION-1 PWR ANS PAPER
Report Number:	LA-UR-82-3713
Issue Date:	12/82
Author:	C. E. Watson
Title:	STEAM GENERATOR TUBE RUPTURE WITH OPERATOR ACTION ANALYSIS FOR ZION-1
Report Number:	LA-UR-82-3236
Issue Date:	1982
Author:	D. Dobranich
Title:	STEAM GENERATOR TUBE RUPTURE ANALYSIS FOR ZION-1

Report Number:	LA-UR-82-1333
Issue Date:	1982
Author:	N. S. DeMuth
Title:	LOSS-OF-FEEDWATER TRANSIENTS FOR THE ZION-1 PRESSURIZED WATER REACTOR
Report Number:	LA-UR-85-0858
Issue Date:	3/85
Author:	R. Fujita, et al
Title:	TRAC-PF1 ANALYSIS OF A BEST-ESTIMATE LARGE-BREAK LOCA IN A WESTINGHOUSE PWR WITH FOUR LOOPS AND 17X17 FUEL
Report Number:	LA-UR-84-2056
Issue Date:	1984
Author:	J. F. Lime
Title:	LOSS-OF-FEEDWATER/FEED AND BLEED IN A WESTINGHOUSE THREE-LOOP, LOW-HEAD SAFETY INJECTION PWR
Report Number:	LA-UR-84-0109
Issue Date:	1/84
Author:	E. Barts, et al
Title:	TRAC-PF1 STUDY OF LOSS OF PUMP SEALS IN A WESTINGHOUSE PWR
Report Number:	LA-UR-85-3117
Issue Date:	8/85
Author:	R. P. Jenks, et al
Title:	PRELIMINARY TRAC CALCULATION OF R. E. GINNA STEAM GENERATOR TUBE-RUPTURE EVENT ON JANUARY 25, 1982
Report Number:	LA-UR-82-3237
Issue Date:	11/82
Author:	J. F. Lime
Title:	TRAC-PD2 CALCULATIONS OF A MAIN-STEAM-LINE BREAK IN A WESTINGHOUSE PRESSURIZED WATER REACTOR-COOLANT PUMP TRIP
Report Number:	LA-UR-82-3235
Issue Date:	11/82
Author:	J. F. Lime
Title:	TRAC-PD2 CALCULATION OF A COLD-LEG SMALL BREAK IN A WESTINGHOUSE FOUR-LOOP PRESSURIZED WATER REACTOR

Report Number: NUREG/CR-3312
Issue Date: 5/83
Author: J. E. Elliott
Title: EFFECTS OF THE REACTOR COOLANT PUMPS
FOLLOWING A SMALL BREAK IN A
WESTINGHOUSE PWR

Report Number: LA-UR-85-4145
Issue Date: 1985
Author: Bahram Nassersharif
Title: ANALYSIS OF STEAM GENERATOR TUBE—
RUPTURE EVENTS COMBINED WITH AUXILIARY—
FEEDWATER CONTROL—SYSTEM FAILURE FOR
THE THREE MILE ISLAND, UNIT 1 AND ZION,
UNIT 1 PRESSURIZED WATER REACTOR

Report Number: LA-UR-85-2816
Issue Date: 1985
Author: Bahram Nassersharif
Title: ANALYSIS OF STEAM GENERATOR TUBE—
RUPTURE EVENTS COMBINED WITH AUXILIARY—
FEEDWATER CONTROL—SYSTEM FAILURE FOR
THREE MILE ISLAND, UNIT 1 AND ZION, UNIT 1
PRESSURIZED WATER REACTORS

Report Number: LA-UR-85-1773
Issue Date: 1985
Author: Bahram Nassersharif
Title: ANALYSIS OF STEAM GENERATOR TUBE—
RUPTURE EVENTS COMBINED WITH AUXILIARY—
FEEDWATER CONTROL—SYSTEM FAILURE FOR
THREE MILE ISLAND, UNIT 1 AND ZION,
UNIT 1 PRESSURIZED WATER REACTORS

Report Number: LA-UR-84-3221
Issue Date: 1984
Author: B. Nassersharif, et al
Title: UNMITIGATED BORON DILUTION EVENTS IN
OCONEE - 1, CALVERT CLIFFS, AND ZION - 1
PRESSURIZED WATER REACTORS DURING
SHUTDOWN

Report Number: LA-UR-82-1821
Issue Date: 6/82
Author: James F. Lime
Title: TRAC/PD2 MODELING OF A COLD-LEG
0.0002 M2 BREAK IN BABCOCK AND WILCOX,

COMBUSTION ENGINEERING, AND WESTINGHOUSE PRESSURIZED WATER REACTORS

Steady States: 100% core power
Assessments: None
Applications: Feedwater Transients

COMPONENT DESCRIPTION

Core: 4 levels, 2 theta, 1 radial
Vessel: 10 levels, 2 theta, 2 radial
Containment: Pressure boundary
Balance of Plant: Detailed secondary
Primary or Recirc: Three loops modeled as one, pressurizer
loop in detail
Main Steam: Steam lines modeled; SRV and ARVs are
modeled. Steam generators modeled; no
Control Systems: PORV, SRV, PRT, ARV
Auxiliary Systems: ECCS system
Fuel Rod Behavior: Detailed rod conductive and reflood
heat transfer
Kinetics: Input power table only

Appendix B

Using the Database Programs

Appendix B

Using the Database Programs

B.1 The Data Input Program

This program allows editing and appending of data into the primary database files: the plant information, report information, and deck information files. At the main menu the user may select the database file to be edited. Once this has been done the user is viewing the records from the chosen database and has the option of editing existing records, inserting or appending new records, deleting records, and moving through the database file. Selections are made from the prompt at the bottom line of the screen by typing the letter which designates the desired action.

B.2 The Query Program

The query program is a user friendly program for extracting information from the database. Search parameters are selected from menus so the typing is minimal, and typing errors are eliminated.

The database may be searched by specifying the desired search parameters with the **SELECTION** option and letting the program narrow down the full database until only those entries which satisfy all the parameters remain. The intermediate lists of plant decks which are generated along the way are accessible to the user by using the **PREVIOUS** and **NEXT** features to move between lists; if the final list is unsatisfactory you can back up to a more general, more extensive list.

The user may specify any of the plant categories (i.e. plant name, group, type or vendor), the modeling code, or the application (such as a large break LOCA), when using the selection option. Any combination of one plant category, an application, and a code may be specified. Plant categories above the chosen category in the hierarchy are automatically supplied by the program, those below are left at the default value of "Any" which informs the program to ignore those parameters when conducting the search. For convenience, the categories group, type, and vendor may be set by specifying a plant name from that category. For example, if you are interested in finding models for plants similar to Wolf Creek you may set the group, type or vendor parameter by choosing the name Wolf Creek in response to the "By Plant" option, and then carry out the search. Even if the user knows nothing about the plant whose deck he needs to locate, beyond the name of the plant, he can easily find if that deck is available. If it is not, the program will automatically locate the best alternative decks for plants of a similar group, type, or vendor, in that order.

The user should leave the **SELECTION** option by choosing "Go" after setting the search parameters. "Go" initiates the automatic search; "Exit" aborts the **SELECTION** option. In either case control returns to the main menu. **SHOW** will display the list of plant decks found by the search

and allow the user to scroll through the list of decks and choose one to look at in more detail. All the data about the plant deck will be displayed. A report may also be sent to a printer or file if the user desires.

Menus, and messages, combine to make the program easy to use.

END

**DATE
FILMED**

5 / 3 / 93